Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049]** **BU 5860**
**Substation No/ Name :- 214419 / 33/11 KV KATEWADI**
**Feeder No / Name : 201 / KATEWADI (AG)** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1463 | .1867 | .181 | .1463 | .1402 | .1307 | .1578 |
| 2 | .1463 | .1509 | 1.4251 | 1.6095 | 1.0595 | .1307 | .1433 |
| 3 | .1463 | .168 | 1.4746 | 1.6461 | 1.4327 | .1494 | .1433 |
| 4 | .1646 | | 1.4746 | 1.7193 | 1.3279 | .168 | .1448 |
| 5 | .1646 | .1494 | 1.5074 | 1.8107 | 1.3763 | .2054 | .1646 |
| 6 | .2402 | .1867 | 1.6244 | 1.9753 | 1.5402 | .2427 | .2218 |
| 7 | .2772 | .2614 | 1.9006 | 2.3594 | 1.6712 | .2987 | .2587 |
| 8 | .2402 | .2054 | 2.0972 | 2.3045 | 1.8842 | .1867 | .2402 |
| 9 | | .1638 | 2.1136 | 2.4949 | | .1646 | .2012 |
| 10 | | 1.9989 | .1829 | .1463 | | 1.6827 | 2.1399 |
| 11 | | 2.3266 | .1463 | .1294 | | 2.3777 | 2.4143 |
| 12 | | 2.5069 | .128 | .0924 | | 2.5606 | 2.4508 |
| 13 | | 2.5396 | .1097 | .0914 | | 2.4874 | 2.5057 |
| 14 | | 2.5232 | .1097 | .0739 | | 2.5057 | 2.5972 |
| 15 | | 2.5069 | .0914 | .0732 | | 2.5057 | 2.524 |
| 16 | 2.3777 | 2.3152 | .128 | .0747 | .0934 | 2.4143 | 2.4508 |
| 17 | .3734 | 2.3712 | .1463 | .128 | .3326 | 2.1956 | 2.2314 |
| 18 | .4668 | .1646 | .2033 | .2195 | .462 | .197 | .2195 |
| 19 | .5041 | .2427 | .2195 | .2012 | .5415 | .2172 | .2195 |
| 20 | .4668 | .2012 | .2012 | .1543 | .4805 | .2195 | .1829 |
| 21 | .1646 | .1867 | .2033 | .1543 | .4435 | .1791 | .1463 |
| 22 | .1463 | .2012 | .1646 | .1543 | | .1629 | .1646 |
| 23 | .1478 | .1829 | .1646 | .1417 | .1494 | .1402 | .1463 |
| 24 | .128 | .1646 | .1829 | .1463 | .1433 | .1494 | .1448 |
| **Max** | **2.3777** | **2.5396** | **2.1136** | **2.4949** | **1.8842** | **2.5606** | **2.5972** |
| **Min** | **.128** | **.1494** | **.0914** | **.0732** | **.0934** | **.1307** | **.1433** |
| **Avg** | **.3707** | **.9524** | **.6742** | **.7520** | **.8174** | **.9030** | **.9256** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049]** **BU 5860**
**Substation No/ Name :- 214419 / 33/11 KV KATEWADI**
**Feeder No / Name : 202 / 11 kKV KATEWADI (GFSS)** **GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2957 | .3547 | .3898 | .3018 | .4031 | .3326 | .3898 |
| 2 | .2957 | .3881 | .4075 | .2987 | .3898 | .3109 | .3772 |
| 3 | .3326 | .3734 | | .3174 | .4075 | .3696 | .4024 |
| 4 | .4108 | .4108 | .4298 | .3734 | .4656 | .3547 | .4694 |
| 5 | .4854 | 1.0456 | .4477 | .5228 | .5068 | .3921 | .5375 |
| 6 | .6161 | .5415 | .5249 | .6224 | .5853 | .5415 | .6036 |
| 7 | .6535 | .6908 | .567 | .7167 | .5316 | .6535 | .6468 |
| 8 | .6161 | .6535 | .5975 | .6348 | .6653 | .6722 | .6219 |
| 9 | | .5281 | .5281 | .5304 | | .5228 | .4887 |
| 10 | | .3772 | .4904 | .4207 | | .3921 | .3982 |
| 11 | | .3584 | .3475 | .3326 | | .3174 | .3982 |
| 12 | | .3206 | .3584 | .3142 | | .2587 | .3511 |
| 13 | | .3018 | .3018 | .2743 | | .2402 | .2715 |
| 14 | | .2829 | .3018 | .2218 | | .2378 | .2172 |
| 15 | | .2829 | .2829 | .1848 | | .2801 | .2534 |
| 16 | .2801 | .2957 | .3018 | .3361 | .2957 | .3361 | .3361 |
| 17 | .3547 | .4251 | .4024 | .3734 | | .362 | .3734 |
| 18 | .4854 | .5544 | .499 | .4854 | | .4755 | .3361 |
| 19 | .5601 | .5544 | .499 | .5853 | | .5611 | .5544 |
| 20 | .5601 | .4805 | .462 | | | .5121 | .5041 |
| 21 | .4854 | .4251 | .4251 | | | .5121 | .4668 |
| 22 | .3547 | .3772 | .3734 | | | .5175 | .3921 |
| 23 | .3361 | .3944 | .3018 | .4252 | .3841 | .439 | .3547 |
| 24 | .3174 | .3361 | .4031 | .3018 | .4115 | .3174 | .4207 |
| **Max** | **.6535** | **1.0456** | **.5975** | **.7167** | **.6653** | **.6722** | **.6468** |
| **Min** | **.2801** | **.2829** | **.2829** | **.1848** | **.2957** | **.2378** | **.2172** |
| **Avg** | **.4376** | **.4481** | **.4192** | **.4083** | **.4588** | **.4129** | **.4236** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049]** **BU 5860**
**Substation No/ Name :- 214419 / 33/11 KV KATEWADI**
**Feeder No / Name : 205 / 11 KV INDUSTRIAL** **SHEDDABLE FEEDER HAVING WEEKLY**
**Feeder KV- 11 / OUTGOING** **STAGGERING (MIDC, EQUIVALENT)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3658 | .3881 | .3814 | .4024 | .2801 | .4251 | .3224 |
| 2 | .3475 | .4066 | .39 | .462 | .2961 | .3921 | .2591 |
| 3 | .3475 | .4481 | .3856 | .4435 | .2743 | .3696 | .2846 |
| 4 | .3658 | .4294 | .3721 | .439 | .2667 | .3511 | .285 |
| 5 | .4207 | 1.0164 | .3982 | .4854 | .2782 | .4251 | .3772 |
| 6 | .439 | .4251 | .3898 | .4854 | .2667 | .4481 | .4344 |
| 7 | .439 | .462 | .3898 | .4854 | .2858 | .4805 | .4075 |
| 8 | .4024 | .4755 | .4294 | .3841 | .1715 | .4435 | .2804 |
| 9 | | .4115 | .4115 | .3734 | | .439 | .2829 |
| 10 | | .3086 | .4458 | .462 | | .3475 | .2987 |
| 11 | | .3086 | .3772 | .3734 | | .4572 | .3361 |
| 12 | | .3772 | .3086 | .4805 | | .3841 | .3734 |
| 13 | | .3772 | .3429 | .4481 | | .3475 | .4108 |
| 14 | | .3429 | .3429 | .4805 | | .3841 | .439 |
| 15 | | .3429 | .4115 | .4668 | | .3841 | .5658 |
| 16 | .3921 | .3696 | .3772 | .5228 | .4066 | .3841 | .439 |
| 17 | .3353 | .3881 | .4854 | .4572 | .4805 | .4024 | .3475 |
| 18 | .4668 | .4435 | .4294 | .4572 | .4251 | .3681 | .3841 |
| 19 | .5041 | .462 | .4108 | .4938 | .3881 | .3601 | .3658 |
| 20 | .4668 | .462 | .4294 | | .4066 | .3856 | .3475 |
| 21 | .4854 | .3696 | .4294 | | .4251 | .3898 | .3292 |
| 22 | .4854 | .3521 | .4024 | | | .3801 | .3109 |
| 23 | .4024 | .3391 | .3841 | .3018 | .4805 | .3018 | .3109 |
| 24 | .3841 | .4207 | .3772 | .4024 | .2881 | .4066 | .2972 |
| **Max** | **.5041** | **1.0164** | **.4854** | **.5228** | **.4805** | **.4805** | **.5658** |
| **Min** | **.3353** | **.3086** | **.3086** | **.3018** | **.1715** | **.3018** | **.2591** |
| **Avg** | **.4147** | **.4220** | **.3959** | **.4432** | **.3388** | **.3941** | **.3537** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049]** **BU 5860**
**Substation No/ Name :- 214419 / 33/11 KV KATEWADI**
**Feeder No / Name : 206 / 11 KV GAWARKHOPAD AG** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0328 | .0503 | .0351 | .0492 | .0543 | .0671 | .0354 |
| 2 | .0328 | .0497 | .7773 | .8192 | .506 | .0671 | .0358 |
| 3 | .0328 | .0497 | .8288 | .8192 | .5441 | .0503 | .0532 |
| 4 | .0328 | .0503 | .8097 | .8192 | .6154 | .0046 | .0543 |
| 5 | .0328 | .0503 | .852 | .852 | .6882 | .0503 | .0549 |
| 6 | .0492 | .0497 | .8259 | .852 | .7773 | .0503 | .0554 |
| 7 | .0492 | .0497 | .9945 | .9503 | .9175 | | .0549 |
| 8 | .0492 | .0373 | .9831 | .9831 | | .0503 | .0537 |
| 9 | | .0492 | 1.0486 | 1.0395 | | .0328 | .0324 |
| 10 | | 1.0159 | .0549 | .037 | | .8848 | 1.0486 |
| 11 | | 1.1469 | .0549 | .0335 | | 1.0322 | 1.0608 |
| 12 | | 1.2452 | .0549 | .0335 | | 1.0814 | 1.065 |
| 13 | | | .0549 | .0332 | | 1.0814 | 1.065 |
| 14 | | 1.2289 | .0366 | .0332 | | 1.1142 | 1.0814 |
| 15 | | 1.2452 | .0366 | | | 1.1797 | 1.0442 |
| 16 | 1.1934 | 1.1271 | .0366 | .0366 | .0332 | 1.1469 | 1.0322 |
| 17 | 1.1437 | 1.1603 | .0335 | .0328 | .0328 | 1.2308 | 1.0486 |
| 18 | .0663 | .0671 | .0335 | .0328 | .0335 | .0362 | .0492 |
| 19 | .0503 | .0819 | .0335 | .0492 | .0503 | .0549 | .0492 |
| 20 | .0497 | .0671 | .0503 | | .0335 | .0543 | .0492 |
| 21 | .0503 | .0663 | .0503 | | .0503 | .0354 | .0328 |
| 22 | .0503 | .0543 | .0492 | | | .0549 | .0328 |
| 23 | .0497 | .0514 | .0492 | .0351 | .0671 | .0554 | .0492 |
| 24 | .0492 | .0503 | .0354 | .0492 | .0354 | .0671 | .0549 |
| **Max** | **1.1934** | **1.2452** | **1.0486** | **1.0395** | **.9175** | **1.2308** | **1.0814** |
| **Min** | **.0328** | **.0373** | **.0335** | **.0328** | **.0328** | **.0046** | **.0324** |
| **Avg** | **.1773** | **.3932** | **.3258** | **.3795** | **.2959** | **.4123** | **.3830** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049] BU 5860**
**Substation No/ Name :- 214420 / 33/11 KV PANDARE S/STN**
**Feeder No / Name : 202 / 11 KV DHAKALE SINGLE PH. SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3086 | .3395 | .3429 | .3086 | .3086 | .3395 | .3086 |
| 2 | .3086 | .3206 | .6859 | .7202 | .6401 | .3206 | .3086 |
| 3 | .3086 | .2743 | .6859 | .8059 | .6401 | .3395 | .3086 |
| 4 | .3258 | .3086 | .9431 | .8059 | .6859 | .3772 | .3086 |
| 5 | .4458 | .3772 | 1.1831 | .9945 | .7621 | .415 | .4287 |
| 6 | .5144 | .4527 | 1.5089 | 1.2003 | 1.0212 | .5281 | .583 |
| 7 | .5487 | .547 | 1.6289 | 1.6461 | 1.4022 | .5658 | .7373 |
| 8 | .6344 | .5847 | 1.8347 | 1.8004 | 1.5242 | .6036 | .6001 |
| 9 | .4458 | .415 | 1.8004 | 1.6461 | 1.7147 | .415 | .3772 |
| 10 | 1.3032 | 1.0974 | .2743 | .3601 | .3601 | 1.2689 | 1.0364 |
| 11 | 1.5775 | 1.7833 | .2401 | .3086 | .3395 | 1.5089 | 1.6461 |
| 12 | 1.8004 | 1.7147 | .1886 | .2401 | .2452 | 1.6918 | 1.7833 |
| 13 | | 1.9033 | | .2058 | .2263 | 1.7223 | 1.8004 |
| 14 | 1.8176 | 1.9204 | | .1886 | .2263 | 1.7985 | 1.8176 |
| 15 | 1.7833 | 1.7147 | .1715 | .1715 | .2263 | | 1.6118 |
| 16 | 1.9719 | 1.4918 | | .1886 | .2641 | 1.7071 | 1.4575 |
| 17 | 1.9204 | 1.5089 | .1543 | .2401 | .3395 | 1.0517 | 1.046 |
| 18 | .4527 | .3944 | .4801 | | .4904 | .4458 | .463 |
| 19 | .6413 | .6001 | .6001 | .6001 | .6602 | .5487 | .5658 |
| 20 | .5658 | .5487 | .5316 | .5487 | .6036 | .5144 | .5144 |
| 21 | .5281 | .4801 | .463 | .4973 | .5281 | .463 | .4973 |
| 22 | .4527 | .4115 | .3944 | .3772 | .415 | .3772 | .3772 |
| 23 | .415 | .3772 | .3429 | .3258 | .3584 | .3429 | .3772 |
| 24 | | .3395 | .3429 | .3258 | .3258 | .3395 | .3258 |
| **Max** | **1.9719** | **1.9204** | **1.8347** | **1.8004** | **1.7147** | **1.7985** | **1.8176** |
| **Min** | **.3086** | **.2743** | **.1543** | **.1715** | **.2263** | **.3206** | **.3086** |
| **Avg** | **.8668** | **.8294** | **.7046** | **.6307** | **.5962** | **.7689** | **.8034** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049]** **BU 5860**
**Substation No/ Name :- 214420 / 33/11 KV PANDARE S/STN**
**Feeder No / Name : 203 / 11 KV MIDC FEEDER** **SHEDDABLE FEEDER HAVING WEEKLY**
**Feeder KV- 11 / OUTGOING** **STAGGERING (MIDC, EQUIVALENT)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3086 | .3395 | .2058 | .2915 | .2058 | .1509 | .0343 |
| 2 | .2401 | .3395 | .2229 | .2572 | .2058 | .0943 | .0343 |
| 3 | .2401 | .2641 | .1715 | .2915 | .1715 | .0943 | .0343 |
| 4 | .2401 | .2263 | .1715 | .3086 | .2058 | .0943 | .0343 |
| 5 | .2572 | .2263 | .1715 | .3086 | .1715 | .1509 | .0343 |
| 6 | .2743 | .2263 | .2058 | .3772 | .1029 | .1509 | .0343 |
| 7 | .2743 | .2263 | .2058 | .3601 | .1543 | .1886 | .0343 |
| 8 | .2743 | .2452 | .2229 | .2572 | .1029 | .2452 | .0343 |
| 9 | .1715 | .3018 | .2401 | .4287 | .1372 | .415 | .2572 |
| 10 | .3772 | .3772 | .6344 | .703 | .3086 | .5658 | .4115 |
| 11 | .3772 | .3258 | .6173 | .6516 | .3018 | .5658 | .3601 |
| 12 | .3395 | .583 | .4287 | .6687 | .2452 | .3601 | .2572 |
| 13 | .3395 | .2401 | | .3429 | .3395 | .2229 | .12 |
| 14 | .3772 | .2401 | | .1886 | .3772 | .1715 | .1543 |
| 15 | .415 | .4458 | .2915 | .4287 | .3395 | | .0857 |
| 16 | .7167 | .4458 | | .5658 | .2829 | .5487 | .0857 |
| 17 | .6602 | .4287 | .6859 | .3944 | .2641 | .3601 | .0514 |
| 18 | .4904 | .4973 | .583 | | .2452 | .1543 | .1372 |
| 19 | .4527 | .12 | .3429 | .3086 | .2263 | .2401 | .0857 |
| 20 | .3772 | .1372 | .2743 | .3086 | .2263 | .1715 | .0857 |
| 21 | .3772 | .12 | .2915 | .1886 | .2263 | .12 | .0686 |
| 22 | .3772 | .2058 | .1029 | .1886 | .1886 | .1543 | .0514 |
| 23 | .3395 | .1543 | .1372 | .1715 | .1886 | .0343 | .0686 |
| 24 | | .3395 | .2401 | .2743 | .2401 | .2263 | .0343 |
| **Max** | **.7167** | **.583** | **.6859** | **.703** | **.3772** | **.5658** | **.4115** |
| **Min** | **.1715** | **.12** | **.1029** | **.1715** | **.1029** | **.0343** | **.0343** |
| **Avg** | **.3607** | **.2940** | **.3070** | **.3593** | **.2274** | **.2383** | **.1079** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049]** **BU 5860**
**Substation No/ Name :- 214420 / 33/11 KV PANDARE S/STN**
**Feeder No / Name : 204 / 11 KV PANDHRE SINGLE PH. SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2 | | | 1.166 | 1.2003 | 1.0669 | | |
| 3 | | | 1.166 | 1.2003 | 1.0669 | | |
| 4 | | | 1.166 | 1.2003 | 1.0669 | | |
| 5 | | | 1.286 | 1.3375 | 1.1431 | | |
| 6 | | | 1.6632 | 1.4918 | 1.2955 | | |
| 7 | | | 1.7318 | 1.6804 | 1.6156 | | |
| 8 | | | 1.7833 | 1.869 | 1.7375 | | |
| 9 | | | 1.7833 | 1.9547 | 1.7528 | | |
| 10 | 1.989 | 1.8861 | | | | 1.8519 | 1.6461 |
| 11 | 2.0062 | 2.0062 | | | | 1.8442 | 2.2119 |
| 12 | 2.2634 | 2.2119 | | | | 1.8747 | 2.2634 |
| 13 | 2.1091 | 2.1776 | | | | 1.9966 | 2.2634 |
| 14 | 2.1262 | 2.1776 | | | | 1.8747 | 2.2977 |
| 15 | 2.0576 | 1.989 | | | | | 2.1434 |
| 16 | 2.1262 | 1.9204 | | | | 1.9052 | 2.1091 |
| 17 | 1.7318 | 1.9033 | | | | 1.7223 | 1.9547 |
| **Max** | **2.2634** | **2.2119** | **1.7833** | **1.9547** | **1.7528** | **1.9966** | **2.2977** |
| **Min** | **1.7318** | **1.8861** | **1.166** | **1.2003** | **1.0669** | **1.7223** | **1.6461** |
| **Avg** | **2.0512** | **2.0340** | **1.4682** | **1.4918** | **1.3432** | **1.8671** | **2.1112** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049] BU 5860**
**Substation No/ Name :- 214423 / 33/11 KV JALGOAN S/STN**
**Feeder No / Name : 202 / 11 KV DEULGAON SINGLE PHASING Feeder KV- 11 / OUTGOING SINGLE PHASING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2572 | .2641 | .2743 | .2641 | .2743 | .3018 | .3018 |
| 2 | .2401 | .2641 | .2572 | .2641 | .2743 | .2641 | .3772 |
| 3 | .2915 | .3018 | .2743 | .2641 | .2915 | .3395 | .3772 |
| 4 | .3429 | .3395 | .3086 | .3395 | .3258 | .415 | .4904 |
| 5 | .4801 | .4715 | .4115 | .4715 | .4287 | .5658 | .6413 |
| 6 | .7202 | .7356 | .6516 | .7167 | .6859 | .8488 | .7356 |
| 7 | .9945 | .9431 | .7202 | .7922 | .703 | 1.0751 | 1.0751 |
| 8 | 1.166 | 1.3957 | .6413 | .6224 | .6036 | 1.2449 | 1.1883 |
| 9 | 1.2346 | 1.3203 | .4904 | .4904 | .4904 | 1.2071 | 1.0974 |
| 10 | .2743 | .2229 | .7922 | .6516 | .679 | .2829 | .2058 |
| 11 | .1543 | .1543 | 1.226 | .7716 | .9431 | .132 | .1715 |
| 12 | .12 | .12 | 1.3203 | .9431 | 1.0185 | .132 | .1372 |
| 13 | .0857 | .1372 | 1.4712 | 1.1488 | 1.1317 | .1132 | .1372 |
| 14 | .0686 | .12 | 1.5278 | 1.0631 | 1.226 | .1132 | .1372 |
| 15 | .0857 | .1029 | 1.5089 | 1.046 | 1.3014 | .132 | .1543 |
| 16 | .0857 | .1543 | 1.5089 | 1.046 | 1.226 | .1509 | .1886 |
| 17 | .1698 | .1715 | 1.1694 | .9945 | 1.1694 | .2075 | .2572 |
| 18 | .3772 | .4801 | .4527 | .3429 | .3584 | .3961 | .3944 |
| 19 | .6036 | .6173 | .5847 | .5487 | .6413 | .6036 | .5487 |
| 20 | .5658 | .5144 | .547 | .4973 | .5093 | .547 | .4801 |
| 21 | .4527 | .4287 | .4527 | .4115 | .5281 | .4527 | .4287 |
| 22 | .3961 | .3772 | .3961 | .3429 | .3961 | .3772 | .3429 |
| 23 | .3395 | .3258 | .3395 | .3086 | .3584 | .3584 | .3258 |
| 24 | .2743 | .3018 | .3086 | .3018 | .2915 | .3206 | .3395 |
| **Max** | **1.2346** | **1.3957** | **1.5278** | **1.1488** | **1.3014** | **1.2449** | **1.1883** |
| **Min** | **.0686** | **.1029** | **.2572** | **.2641** | **.2743** | **.1132** | **.1372** |
| **Avg** | **.4075** | **.4277** | **.7348** | **.6101** | **.6607** | **.4409** | **.4389** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049] BU 5860**
**Substation No/ Name :- 214423 / 33/11 KV JALGOAN S/STN**
**Feeder No / Name : 204 / 11 KV SYNBACHIWADI SINGLE SINGLE PHASING PHAS Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0857 | .0943 | .1029 | .1132 | .1029 | .1132 | .0943 |
| 2 | .0857 | .0943 | .1715 | .1509 | .1715 | .1132 | .0943 |
| 3 | .1029 | .0943 | .1715 | .1886 | .2229 | .1132 | .1132 |
| 4 | .12 | .0943 | .2058 | .2263 | .2401 | .1097 | .1509 |
| 5 | .1543 | .132 | .2229 | .2829 | .2915 | .1509 | .1886 |
| 6 | .2058 | .2263 | .3086 | .3395 | .3601 | .1886 | |
| 7 | .2572 | .3018 | .4115 | .547 | .5144 | .2641 | .2452 |
| 8 | .2058 | .2641 | .4715 | .5658 | .5281 | .2641 | .2263 |
| 9 | .1543 | .1886 | .4715 | .6036 | .4904 | .1886 | .1886 |
| 10 | .3944 | .3086 | .1698 | .1029 | .132 | .2829 | .3086 |
| 11 | .4458 | .5144 | .1509 | .0857 | .132 | .4715 | .4287 |
| 12 | .6344 | .5658 | .1132 | | .132 | .5658 | .4801 |
| 13 | .6687 | .6173 | .1132 | .1029 | .132 | .6036 | .5316 |
| 14 | .6344 | .6001 | .1132 | .0686 | .132 | .6036 | .5487 |
| 15 | .5658 | .5487 | .0943 | .0857 | .132 | .6036 | .5144 |
| 16 | .583 | .5316 | .0754 | .0686 | .132 | .5658 | .4458 |
| 17 | .6602 | .5658 | .1132 | .1029 | .1509 | .547 | .3772 |
| 18 | .1509 | .1543 | .2075 | .1543 | .1886 | .1698 | .1543 |
| 19 | .2641 | .2401 | .1886 | .2229 | .2075 | .2075 | .2229 |
| 20 | .2075 | .2058 | .1886 | .1886 | .1509 | .1698 | .1886 |
| 21 | .1509 | .1715 | .1523 | .1715 | .1509 | .1509 | .1715 |
| 22 | .1132 | .1543 | .132 | .1543 | .1698 | | .1543 |
| 23 | .1132 | .1372 | .1132 | .1372 | .1509 | .1132 | .1372 |
| 24 | .1029 | .0943 | .12 | .1132 | .12 | .132 | .0943 |
| **Max** | **.6687** | **.6173** | **.4715** | **.6036** | **.5281** | **.6036** | **.5487** |
| **Min** | **.0857** | **.0943** | **.0754** | **.0686** | **.1029** | **.1097** | **.0943** |
| **Avg** | **.2942** | **.2875** | **.1910** | **.2077** | **.2140** | **.2910** | **.2635** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049] BU 5860**
**Substation No/ Name :- 214423 / 33/11 KV JALGOAN S/STN**
**Feeder No / Name : 205 / 11 KV SONPIRWADI SINGLE SINGLE PHASING PHASIN Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2915 | .3018 | .2743 | .3206 | | .3206 | .2829 |
| 2 | .4287 | .4338 | .2915 | .3018 | .2915 | .3395 | .3395 |
| 3 | .463 | .5281 | .3086 | .3395 | .3086 | .415 | .4527 |
| 4 | .583 | .6036 | .3944 | .415 | .3429 | .4904 | .5658 |
| 5 | .6859 | .7922 | .463 | .6413 | .4801 | .6602 | .679 |
| 6 | .9259 | 1.0374 | .7716 | .8488 | .7716 | .9054 | .811 |
| 7 | 1.286 | 1.358 | .9431 | 1.0562 | .9602 | 1.0562 | 1.094 |
| 8 | 1.3203 | 1.6409 | .9431 | .811 | .8488 | 1.4335 | 1.4146 |
| 9 | 1.286 | 1.6409 | .679 | .6979 | .7545 | 1.1317 | 1.1317 |
| 10 | .3944 | | 1.094 | .9431 | .8488 | .4527 | .2572 |
| 11 | .2229 | | 1.5466 | 1.1145 | 1.3957 | .2075 | .1886 |
| 12 | .1543 | .1029 | 1.7164 | 1.2003 | 1.5089 | .1886 | .1543 |
| 13 | .2058 | .1543 | | 1.5089 | 1.4712 | .1509 | .1372 |
| 14 | .1715 | .1715 | 1.6975 | 1.5089 | 1.4712 | .1509 | .1372 |
| 15 | .1886 | .2058 | 1.7353 | 1.3203 | 1.4146 | .1509 | .1372 |
| 16 | .2058 | .2229 | .7167 | 1.4232 | 1.3957 | .2075 | .1715 |
| 17 | .2829 | .2401 | 1.5278 | 1.2517 | 1.358 | .2263 | .2229 |
| 18 | .5847 | .4973 | .547 | .4458 | .439 | .5093 | .5144 |
| 19 | .8865 | .7545 | .7922 | .7545 | .7545 | .6979 | .6687 |
| 20 | .7733 | .6516 | .695 | .6516 | .6602 | .6224 | .5658 |
| 21 | .6224 | .5144 | .5093 | .4801 | .4904 | .5281 | .4801 |
| 22 | .4527 | .3944 | .4338 | .3944 | .3772 | .415 | .3944 |
| 23 | .3395 | .3258 | .3772 | .3086 | .3395 | .3395 | .3086 |
| 24 | .3086 | .3206 | .2915 | .3206 | .3086 | .3206 | .2829 |
| **Max** | **1.3203** | **1.6409** | **1.7353** | **1.5089** | **1.5089** | **1.4335** | **1.4146** |
| **Min** | **.1543** | **.1029** | **.2743** | **.3018** | **.2915** | **.1509** | **.1372** |
| **Avg** | **.5443** | **.5860** | **.8152** | **.7941** | **.8257** | **.4967** | **.4747** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049] BU 5860**
**Substation No/ Name :- 214423 / 33/11 KV JALGOAN S/STN**
**Feeder No / Name : 206 / 11 KV JALGAON (KP) SINGLE SINGLE PHASING PHAS Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3601 | .3018 | .3086 | .3395 | .3258 | .3395 | .3395 |
| 2 | .4458 | .415 | .3086 | .3584 | .3258 | .3772 | .3772 |
| 3 | .4801 | .4904 | .3258 | .3395 | .3258 | .4338 | .4527 |
| 4 | .5487 | .6602 | .3944 | .415 | .3944 | .4715 | .5281 |
| 5 | .6173 | .7922 | .4287 | .5281 | .4287 | .6036 | .6036 |
| 6 | .7545 | 1.0374 | .6516 | .7545 | .6344 | .8488 | .8299 |
| 7 | 1.0288 | 1.1128 | .9088 | .9619 | .8745 | 1.0751 | 1.1317 |
| 8 | 1.166 | 1.4523 | .7545 | .7545 | .7545 | 1.3014 | 1.3014 |
| 9 | 1.1317 | 1.358 | .4527 | .3206 | .5847 | 1.0751 | 1.0631 |
| 10 | .3086 | .2743 | .9242 | .7716 | .9054 | .3961 | .2743 |
| 11 | | .2229 | 1.2637 | .9431 | 1.1317 | .2263 | .2229 |
| 12 | .1886 | .1715 | 1.6221 | 1.286 | 1.2637 | .2075 | .1715 |
| 13 | .1715 | .1715 | 1.6787 | 1.3717 | 1.3203 | .1509 | .1715 |
| 14 | .1886 | .1886 | 1.5278 | 1.3203 | 1.3957 | .1886 | .1715 |
| 15 | .1543 | .2058 | 1.5655 | 1.4403 | 1.3957 | .2263 | .1886 |
| 16 | .2058 | .2058 | | 1.3889 | 1.3203 | .2829 | .2058 |
| 17 | .3395 | .2229 | 1.2637 | 1.286 | 1.2637 | .3018 | .2743 |
| 18 | .5658 | | .5658 | .5144 | .4715 | .5281 | .5144 |
| 19 | .7167 | .6859 | .6602 | .7202 | .6413 | .6413 | .6516 |
| 20 | .6036 | .583 | .6036 | .6516 | .5281 | .5658 | .5487 |
| 21 | .5093 | .4458 | .5281 | .5487 | .4904 | .4904 | .4458 |
| 22 | .3961 | .3772 | .4338 | .4115 | .3961 | .4527 | .3944 |
| 23 | .3395 | .3429 | .3961 | .3429 | .3772 | .3961 | .3429 |
| 24 | .3772 | .3206 | .3258 | .3772 | .3429 | .3395 | .3584 |
| **Max** | **1.166** | **1.4523** | **1.6787** | **1.4403** | **1.3957** | **1.3014** | **1.3014** |
| **Min** | **.1543** | **.1715** | **.3086** | **.3206** | **.3258** | **.1509** | **.1715** |
| **Avg** | **.5043** | **.5234** | **.7779** | **.7561** | **.7455** | **.4967** | **.4818** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049] BU 5860**
**Substation No/ Name :- 214425 / 33/11 KV PAHUNEWADI**
**Feeder No / Name : 201 / 11 KV KARKHANA SINGLE PHASING Feeder KV- 11 / OUTGOING SINGLE PHASING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .415 | .4287 | .4338 | .4252 | .4287 | | .4904 |
| 2 | .415 | .3772 | 1.046 | | .8916 | .4252 | .4904 |
| 3 | .415 | .4287 | 1.046 | 1.0631 | .9431 | .5138 | .4904 |
| 4 | .415 | .6859 | 1.0631 | | 1.0631 | | .4904 |
| 5 | .9054 | .9259 | 1.2517 | 1.2226 | 1.2003 | .815 | .8916 |
| 6 | 1.0631 | 1.1317 | 1.3717 | | 1.3375 | | 1.046 |
| 7 | 1.2174 | 1.2346 | 1.5061 | 1.5947 | 1.4575 | 1.134 | 1.2174 |
| 8 | 1.0974 | 1.166 | 1.587 | | 1.5775 | | 1.1317 |
| 9 | .9054 | .8573 | 1.4575 | 1.5238 | 1.4575 | .7087 | .811 |
| 10 | 1.4883 | 1.4575 | .6224 | .567 | .6516 | 1.1517 | 1.3203 |
| 11 | 1.749 | 1.6461 | .4252 | .4801 | .5316 | 1.4706 | 1.3916 |
| 12 | 1.7318 | 1.5546 | .4961 | .4801 | | 1.166 | 1.3599 |
| 13 | 1.6975 | 1.6804 | | .463 | .443 | 1.3546 | 1.0753 |
| 14 | 1.6461 | | | .4287 | | 1.4575 | .9488 |
| 15 | 1.6289 | 1.4575 | .4607 | .4287 | .3898 | 1.5089 | 1.2334 |
| 16 | 1.6461 | 1.5089 | | .4801 | | 1.4922 | 1.2334 |
| 17 | 1.7147 | 1.3375 | .567 | .5487 | .5138 | 1.4232 | 1.1385 |
| 18 | .6344 | .7545 | .7265 | .6859 | .7087 | .8059 | .8505 |
| 19 | .8573 | .8402 | | .8916 | | .7716 | .8859 |
| 20 | .823 | .8865 | .815 | .8573 | .7796 | .8299 | .815 |
| 21 | .7202 | .6979 | | .703 | | .7545 | .7442 |
| 22 | .6001 | .6413 | .6733 | .583 | .5316 | .6979 | .6379 |
| 23 | .4801 | .4715 | | .4801 | | .5658 | .5316 |
| 24 | .4338 | .4287 | .4338 | .443 | .463 | .443 | .5093 |
| **Max** | **1.749** | **1.6804** | **1.587** | **1.5947** | **1.5775** | **1.5089** | **1.3916** |
| **Min** | **.415** | **.3772** | **.4252** | **.4252** | **.3898** | **.4252** | **.4904** |
| **Avg** | **1.0292** | **.9826** | **.8879** | **.7175** | **.8539** | **.9745** | **.9056** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049] BU 5860**
**Substation No/ Name :- 214425 / 33/11 KV PAHUNEWADI**
**Feeder No / Name : 202 / 11 KV SHARADANAGAR SINGLE SINGLE PHASING PHAS Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3018 | .3086 | .3018 | .2835 | .2743 | | .3206 |
| 2 | .2641 | .2572 | .9259 | | .9774 | .2835 | .3206 |
| 3 | .2641 | .3086 | .9259 | .9568 | 1.0631 | .3366 | .3206 |
| 4 | .2641 | .4287 | 1.0185 | | 1.1488 | | .3018 |
| 5 | .5281 | .5658 | 1.0288 | 1.134 | 1.2346 | .6201 | .4904 |
| 6 | .6224 | .6859 | 1.1488 | | 1.286 | | .679 |
| 7 | .7716 | .7888 | 1.3546 | 1.382 | 1.3375 | .7973 | .8402 |
| 8 | .7733 | .6516 | 1.4232 | | 1.3375 | | .8865 |
| 9 | .5658 | .4973 | 1.4232 | 1.4706 | 1.3717 | .5316 | .6224 |
| 10 | 1.3466 | 1.3375 | .4338 | .4252 | .4801 | 1.2757 | 1.166 |
| 11 | 1.6289 | 1.4575 | .3544 | .4287 | .4252 | 1.5415 | 1.2809 |
| 12 | 1.6118 | 1.5604 | .3189 | .4115 | | 1.4403 | 1.2334 |
| 13 | 1.5432 | 1.5604 | .3366 | .3772 | .3544 | 1.5261 | 1.2018 |
| 14 | 1.5089 | 1.3717 | | .3601 | | 1.4403 | 1.1702 |
| 15 | 1.4575 | 1.4737 | .3898 | .3601 | .3366 | 1.4403 | 1.1227 |
| 16 | 1.4403 | 1.4575 | | .4287 | | 1.4403 | 1.0753 |
| 17 | 1.3889 | 1.4575 | .4075 | .4115 | .443 | 1.4232 | 1.0753 |
| 18 | .4458 | .5658 | .5316 | .6173 | .4961 | .5658 | .6024 |
| 19 | .6344 | .6979 | | .703 | | .6036 | .6379 |
| 20 | .5658 | .6036 | .5847 | .5658 | .5847 | .6224 | .567 |
| 21 | .5144 | .5281 | | .4801 | | .5658 | .5493 |
| 22 | .4287 | .4527 | .6733 | .4115 | .4607 | .4904 | .4607 |
| 23 | .3429 | .3395 | | .3429 | | .3772 | .3721 |
| 24 | .3395 | .3258 | .3018 | .2835 | .2915 | .3012 | .3395 |
| **Max** | **1.6289** | **1.5604** | **1.4232** | **1.4706** | **1.3717** | **1.5415** | **1.2809** |
| **Min** | **.2641** | **.2572** | **.3018** | **.2835** | **.2743** | **.2835** | **.3018** |
| **Avg** | **.8147** | **.8201** | **.7307** | **.5917** | **.7724** | **.8812** | **.7349** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049] BU 5860**
**Substation No/ Name :- 214425 / 33/11 KV PAHUNEWADI**
**Feeder No / Name : 203 / 11 KV YELEWASTI SINGLE PHASING Feeder KV- 11 / OUTGOING SINGLE PHASING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3018 | .2743 | .3206 | .2835 | .2743 | | .2829 |
| 2 | .3018 | .2572 | .6413 | | .5316 | .2835 | .2641 |
| 3 | .3018 | .3258 | .6413 | .6201 | .5487 | .3189 | .2641 |
| 4 | .3018 | .4115 | .6413 | | .6001 | | .2641 |
| 5 | .679 | .5487 | .7545 | .7796 | .6687 | .5138 | .5281 |
| 6 | .7545 | .703 | .8299 | | .7888 | | .6602 |
| 7 | .8865 | .7888 | .8573 | .8505 | .8573 | .8505 | .6979 |
| 8 | .7733 | .6859 | .8916 | | .8916 | | .6979 |
| 9 | .547 | .5487 | .8573 | .8859 | .9259 | .567 | .547 |
| 10 | .9214 | .8573 | .3961 | .3366 | .3772 | .7796 | .7733 |
| 11 | .9259 | .9602 | .2481 | .3601 | .3366 | .8505 | .68 |
| 12 | 1.0117 | .9602 | .3012 | .2915 | | .823 | .7432 |
| 13 | .9774 | .9431 | .2835 | .2915 | .3012 | .8402 | .759 |
| 14 | .9259 | .9619 | | .2743 | | .8488 | .7274 |
| 15 | .9259 | .9808 | .2481 | .2572 | .2835 | .8676 | .6325 |
| 16 | .9774 | .9602 | | .2915 | | .8865 | .759 |
| 17 | 1.046 | .9774 | .3898 | .3429 | .3898 | .8488 | .68 |
| 18 | .4973 | .4904 | .4607 | .4458 | .4784 | .547 | .5316 |
| 19 | .583 | .6413 | | .583 | | .5281 | .567 |
| 20 | .5487 | .5658 | .5847 | .5144 | .5316 | .5281 | .5493 |
| 21 | .463 | .4715 | | .463 | | .4715 | .5316 |
| 22 | .3601 | .4338 | .3898 | .3601 | .4252 | .415 | .443 |
| 23 | .3258 | .3395 | | .3086 | | .3395 | .4252 |
| 24 | .3206 | .2915 | .3206 | .2835 | .2915 | .2835 | .3018 |
| **Max** | **1.046** | **.9808** | **.8916** | **.8859** | **.9259** | **.8865** | **.7733** |
| **Min** | **.3018** | **.2572** | **.2481** | **.2572** | **.2743** | **.2835** | **.2641** |
| **Avg** | **.6524** | **.6408** | **.5294** | **.4412** | **.5279** | **.6196** | **.5546** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049] BU 5860**
**Substation No/ Name :- 214425 / 33/11 KV PAHUNEWADI**
**Feeder No / Name : 204 / 11 KV 22 PHATA AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1886 | .1715 | .1886 | .1772 | .1715 | | .1886 |
| 2 | .6859 | .6173 | .2075 | | .1715 | .6556 | .7167 |
| 3 | .7545 | .6516 | .2075 | .1949 | .2743 | .7265 | .6979 |
| 4 | .7733 | .6859 | .2263 | | .3601 | | .6979 |
| 5 | .823 | .8059 | .3772 | .2835 | .4115 | .9036 | .9054 |
| 6 | .9259 | .8916 | .4904 | | .4458 | | .9259 |
| 7 | 1.2071 | .9431 | .547 | .5316 | .4973 | 1.0631 | 1.1317 |
| 8 | 1.1831 | 1.1317 | .5093 | | .463 | | 1.2346 |
| 9 | 1.1488 | .9945 | .3018 | | .3772 | 1.0631 | 1.0974 |
| 10 | .2481 | .2401 | .9259 | .9745 | .9602 | .2126 | .2263 |
| 11 | .1543 | .1698 | 1.0099 | .9602 | .9745 | .1949 | .1772 |
| 12 | .1372 | .1509 | 1.0631 | 1.0288 | | .1509 | .1595 |
| 13 | .1372 | .1509 | 1.1517 | 1.0288 | .9036 | .132 | .1417 |
| 14 | .1372 | .1509 | | 1.0117 | | .1509 | .1417 |
| 15 | .1543 | | 1.0631 | 1.0288 | .9214 | .1698 | .1417 |
| 16 | .1715 | .2075 | | 1.0288 | | .1886 | .1949 |
| 17 | .2401 | .2641 | .9391 | .9945 | .9745 | .2829 | .2481 |
| 18 | .3429 | .3206 | .6379 | .2743 | .567 | .3584 | .2835 |
| 19 | .3601 | .3395 | | .3258 | | .3395 | .3544 |
| 20 | .3086 | .3018 | .567 | .2743 | .2658 | .3018 | .2835 |
| 21 | .2743 | .2641 | | .2401 | | .2641 | .2481 |
| 22 | .2401 | .2075 | .4252 | .1886 | .1949 | .2075 | .1949 |
| 23 | .1886 | .1886 | | .1715 | | .1886 | .1772 |
| 24 | .1886 | .1715 | .1886 | .1772 | .1715 | .1772 | .1886 |
| **Max** | **1.2071** | **1.1317** | **1.1517** | **1.0288** | **.9745** | **1.0631** | **1.2346** |
| **Min** | **.1372** | **.1509** | **.1886** | **.1715** | **.1715** | **.132** | **.1417** |
| **Avg** | **.4572** | **.4357** | **.5804** | **.5734** | **.5059** | **.3866** | **.4482** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049]** **BU 5860**
**Substation No/ Name :- 214425 / 33/11 KV PAHUNEWADI**
**Feeder No / Name : 205 / 11 KV KHANDAJ AG** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2075 | .1886 | .2641 | .2303 | .2401 | | .2263 |
| 2 | 1.6461 | 1.6804 | .2641 | | .2401 | 1.3289 | 1.5089 |
| 3 | 1.5546 | 1.749 | .2641 | .2303 | .3258 | 1.382 | 1.5089 |
| 4 | 1.5708 | 1.869 | .2829 | | .3772 | | 1.5261 |
| 5 | 1.5851 | 2.0062 | .4904 | .4784 | .463 | 1.6478 | 1.4937 |
| 6 | 1.829 | 2.0748 | .6036 | | .5487 | | 1.8519 |
| 7 | 2.1338 | 2.3663 | .7167 | .6379 | .6859 | 2.2325 | 1.89 |
| 8 | 2.2253 | 2.4006 | .6413 | | .5487 | | 2.0119 |
| 9 | 2.0729 | 2.0576 | .415 | .4252 | .4287 | 2.1262 | 1.829 |
| 10 | .2835 | .3086 | 1.829 | 2.1971 | 2.2977 | .2835 | .3018 |
| 11 | .2058 | .2641 | 2.4097 | 2.3663 | 2.4451 | .2126 | .2126 |
| 12 | .2058 | .1509 | 2.4806 | 2.3663 | | .1886 | .1772 |
| 13 | .1715 | .1509 | 2.5514 | 2.4863 | 2.3034 | .1509 | .1595 |
| 14 | .1715 | .1509 | | 2.4863 | | .1886 | .1772 |
| 15 | .1715 | .1509 | 2.5514 | 2.4348 | 2.1971 | .1698 | .1772 |
| 16 | .1715 | .2263 | | 2.4006 | | .1509 | .2126 |
| 17 | .2058 | .3018 | 2.3034 | 2.3491 | 2.1439 | .3018 | .2835 |
| 18 | .3601 | .4904 | .4252 | .3772 | .4075 | .415 | .3544 |
| 19 | .4973 | .4527 | | .4458 | | .3772 | .4961 |
| 20 | .4115 | .4527 | .443 | .4115 | .443 | .3395 | .3898 |
| 21 | .3429 | .3772 | | .3429 | | .3206 | .3189 |
| 22 | .2915 | .3018 | .2835 | .3258 | .2835 | .3018 | .2835 |
| 23 | .2401 | .2641 | | .2743 | | .2641 | .2658 |
| 24 | .2263 | .2058 | .2641 | .2303 | .2572 | .2658 | .2263 |
| **Max** | **2.2253** | **2.4006** | **2.5514** | **2.4863** | **2.4451** | **2.2325** | **2.0119** |
| **Min** | **.1715** | **.1509** | **.2641** | **.2303** | **.2401** | **.1509** | **.1595** |
| **Avg** | **.7826** | **.8601** | **1.0254** | **1.1748** | **.9243** | **.6324** | **.7451** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049]** **BU 5860**
**Substation No/ Name :- 214433 / 33/11 KV PARAWADI S/STN.**
**Feeder No / Name : 201 / 11 KV PARWADI SINGLE PHASING Feeder KV- 11 / OUTGOING** **SINGLE PHASING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2241 | .2829 | .3018 | .2241 | .2241 | .2241 | .3018 |
| 2 | .8962 | 1.4575 | .3018 | .2241 | .2241 | .8642 | .8097 |
| 3 | .9602 | .9717 | .3018 | .2614 | .2614 | .8802 | .8097 |
| 4 | .9602 | .9717 | .3395 | .2614 | .3361 | .8802 | .8097 |
| 5 | 1.0402 | 1.0364 | .3772 | .5415 | .4108 | .9442 | .8907 |
| 6 | 1.0883 | 1.1498 | .6036 | .7095 | .5041 | .9602 | 1.085 |
| 7 | 1.2803 | 1.2955 | .6979 | .7842 | .5041 | 1.2003 | 1.247 |
| 8 | 1.4403 | 1.2963 | .5788 | .5041 | .5041 | 1.2323 | 1.291 |
| 9 | 1.3123 | 1.2963 | .5041 | .5228 | .415 | 1.1843 | 1.1768 |
| 10 | .2987 | .3547 | 1.1363 | 1.0486 | .9945 | .3547 | .3018 |
| 11 | .2241 | .2614 | 1.2803 | 1.2289 | 1.21 | .2641 | .1886 |
| 12 | .168 | .1867 | 1.3603 | 1.4746 | 1.3592 | .2241 | .2075 |
| 13 | .168 | .112 | 1.4563 | 1.4419 | 1.3923 | .1494 | .1509 |
| 14 | .168 | .1307 | 1.4563 | 1.4091 | 1.2929 | .1307 | .1509 |
| 15 | .1494 | .1307 | 1.4243 | 1.4582 | 1.3094 | .1494 | .132 |
| 16 | .168 | .1494 | 1.3603 | 1.3927 | 1.2763 | .168 | .1698 |
| 17 | .2054 | .2452 | 1.326 | 1.3413 | 1.1768 | .2829 | .2829 |
| 18 | .4481 | .415 | .4527 | .4338 | .3018 | | .4715 |
| 19 | .4668 | .6224 | .6224 | .5093 | .4527 | .4527 | .5788 |
| 20 | .5041 | .4904 | | .5093 | .3206 | .4715 | .415 |
| 21 | .3547 | .3772 | .415 | .3395 | .2641 | .3772 | .3018 |
| 22 | .2829 | .3206 | .3361 | .2641 | .2241 | .3018 | .2641 |
| 23 | .2829 | .3206 | .2054 | .2241 | .2241 | .3018 | .2263 |
| 24 | .2241 | .2829 | .3018 | .2054 | .2241 | .2241 | .3018 |
| **Max** | **1.4403** | **1.4575** | **1.4563** | **1.4746** | **1.3923** | **1.2323** | **1.291** |
| **Min** | **.1494** | **.112** | **.2054** | **.2054** | **.2241** | **.1307** | **.132** |
| **Avg** | **.5548** | **.5899** | **.7452** | **.7214** | **.6419** | **.5314** | **.5235** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049] BU 5860**
**Substation No/ Name :- 214433 / 33/11 KV PARAWADI S/STN.**
**Feeder No / Name : 203 / 11 KV SHIRSUPHAL SINGLE SINGLE PHASING PHASIN Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2241 | .2263 | .2829 | .2241 | .2054 | .2241 | .2641 |
| 2 | .2241 | .2263 | .2591 | .3841 | .2241 | .2241 | .2641 |
| 3 | .2614 | .2263 | .2591 | .3841 | .2241 | .2241 | .2641 |
| 4 | .2641 | .2829 | .2591 | .3841 | .3361 | .2241 | .3206 |
| 5 | .4294 | .4338 | .2753 | .3841 | .3361 | .2614 | .3772 |
| 6 | .5788 | .5847 | .3725 | .5761 | .4641 | .5041 | .5658 |
| 7 | .5601 | .6602 | .5506 | .6081 | .6081 | .6161 | .6413 |
| 8 | .5415 | .5415 | .6081 | .6722 | .6722 | .5415 | .5788 |
| 9 | | .4294 | .6722 | .6722 | .7042 | .415 | .3584 |
| 10 | .4096 | .5441 | .2427 | .168 | .3206 | .4481 | .373 |
| 11 | .4915 | .6241 | .2614 | .1867 | .2452 | .6081 | .5801 |
| 12 | .5898 | .6562 | .2054 | .2614 | .2641 | .6241 | .5197 |
| 13 | .5898 | .6562 | .2054 | .2614 | .2452 | .6401 | .3201 |
| 14 | .6062 | .6241 | .2054 | .2614 | .2641 | .6722 | .4807 |
| 15 | .5571 | .6401 | .2427 | .2427 | .2263 | .6722 | .4973 |
| 16 | .5243 | .4961 | .2614 | .2241 | .2452 | .6562 | .4641 |
| 17 | .5243 | .5304 | .3018 | .2641 | .3018 | 1.6032 | .3812 |
| 18 | .2614 | .3395 | .4338 | .4527 | .3584 | .3961 | .3961 |
| 19 | .3734 | .415 | .5281 | .5788 | .4527 | .4904 | .4481 |
| 20 | .4294 | .3772 | .415 | .4715 | .3395 | .415 | .3734 |
| 21 | .2987 | .3018 | .3395 | .3772 | .3206 | .3395 | .3018 |
| 22 | .2263 | .2829 | .2641 | .2614 | | .2641 | .2829 |
| 23 | .2263 | .2829 | .2241 | .2054 | .2241 | .2641 | .2075 |
| 24 | .2241 | .2263 | .2829 | .2241 | .2075 | .2241 | .2641 |
| **Max** | **.6062** | **.6602** | **.6722** | **.6722** | **.7042** | **1.6032** | **.6413** |
| **Min** | **.2241** | **.2263** | **.2054** | **.168** | **.2054** | **.2241** | **.2075** |
| **Avg** | **.4094** | **.4420** | **.3314** | **.3638** | **.3387** | **.4813** | **.3969** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049] BU 5860**
**Substation No/ Name :- 214433 / 33/11 KV PARAWADI S/STN.**
**Feeder No / Name : 204 / 11 KV NIMBODI SINGLE PHASING Feeder KV- 11 / OUTGOING SINGLE PHASING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2614 | .3772 | .3772 | .2987 | .2987 | .2987 | .3772 |
| 2 | 1.1843 | 1.4575 | .3772 | .2987 | .2987 | 1.0562 | |
| 3 | 1.2803 | 1.4575 | .3772 | .2987 | .2987 | 1.1523 | 1.1336 |
| 4 | 1.4403 | 1.5384 | .4715 | .4481 | .4481 | 1.1523 | 1.2146 |
| 5 | 1.4403 | 1.6194 | .6036 | .7095 | .5228 | 1.2803 | 1.2955 |
| 6 | 1.9204 | 1.749 | .7545 | .8215 | .7468 | 1.5043 | 1.6129 |
| 7 | 2.1605 | 1.8976 | .7545 | .8962 | .8962 | 1.9204 | 1.8185 |
| 8 | 2.0805 | 2.1862 | .6722 | .7095 | .8215 | 1.9524 | 1.989 |
| 9 | 2.1765 | 2.2565 | .5228 | .5228 | .6348 | 1.9204 | 1.9227 |
| 10 | .4481 | .4108 | 1.6804 | 1.8023 | 1.8945 | .2987 | .4854 |
| 11 | .3361 | .3018 | 2.2405 | 1.8351 | 2.3205 | .2641 | .2263 |
| 12 | .2241 | .2987 | 2.3205 | 1.8842 | 2.5857 | .2263 | .2641 |
| 13 | .2241 | .2241 | 2.5606 | 1.9662 | 2.4646 | .2241 | .2452 |
| 14 | .1867 | .2614 | 2.5766 | 2.0645 | 2.5526 | .2241 | .2641 |
| 15 | .1867 | .2614 | 2.3205 | 2.13 | 2.4531 | .2241 | .2452 |
| 16 | .1867 | .2614 | 2.4966 | 2.2611 | 2.3537 | | .2641 |
| 17 | .2241 | .3772 | 2.5857 | 2.5819 | 2.2045 | .3772 | .3734 |
| 18 | .4481 | .5601 | .5788 | .5601 | .5093 | .7545 | .6535 |
| 19 | .5228 | .7167 | .7282 | .7167 | .6535 | .7545 | .7282 |
| 20 | .5601 | .6161 | .6224 | .6348 | .5788 | .7167 | .6348 |
| 21 | .5228 | .4904 | .4715 | .4904 | .3921 | .5658 | .4527 |
| 22 | .3772 | .3772 | .4108 | .4108 | .3361 | .3772 | .415 |
| 23 | .3772 | .3772 | .2987 | .2987 | .2987 | .3772 | .3772 |
| 24 | .2614 | .3772 | .3772 | .2987 | .3018 | .2987 | .3772 |
| **Max** | **2.1765** | **2.2565** | **2.5857** | **2.5819** | **2.5857** | **1.9524** | **1.989** |
| **Min** | **.1867** | **.2241** | **.2987** | **.2987** | **.2987** | **.2241** | **.2263** |
| **Avg** | **.7929** | **.8521** | **1.1325** | **1.0391** | **1.1194** | **.7792** | **.7552** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049] BU 5860**
**Substation No/ Name :- 214441 / 33/11 SANGAVI S/STN**
**Feeder No / Name : 201 / 11 KV KAMBALESHWAR SINGLE SINGLE PHASING PHAS Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1509 | .12 | .112 | .12 | .112 | .1029 | .1357 |
| 2 | .4207 | .3048 | .112 | .1029 | .112 | .4725 | .4409 |
| 3 | .4755 | .3353 | .1509 | .1543 | .112 | .503 | .4917 |
| 4 | .5228 | .4458 | .2241 | .2229 | .1494 | .5792 | .5256 |
| 5 | .6024 | .4268 | .2614 | .2572 | .2241 | .6401 | .5596 |
| 6 | .7468 | .4572 | .3772 | .3429 | .3734 | .6859 | .6344 |
| 7 | .8215 | .6173 | .415 | .3944 | .4854 | .7621 | .8573 |
| 8 | .8962 | .6097 | .3734 | .2713 | .4108 | .7926 | .823 |
| 9 | .7842 | .4877 | .2987 | .2229 | .3361 | .7316 | .8309 |
| 10 | .1463 | .12 | .7468 | .7373 | .8192 | .1372 | .1865 |
| 11 | .1372 | | .9496 | .9877 | .852 | | .1715 |
| 12 | .1372 | .112 | .8987 | 1.0136 | .8848 | | .1029 |
| 13 | .12 | .1132 | .78 | .9709 | .9831 | | .0857 |
| 14 | .1029 | .1132 | .9774 | .9335 | 1.0159 | | .0857 |
| 15 | .1029 | .112 | .9496 | .8478 | .945 | | .1029 |
| 16 | .1029 | .1509 | .9665 | .8097 | .9145 | .1187 | .1372 |
| 17 | .1543 | .1867 | .9496 | .9335 | .8535 | .1526 | .1372 |
| 18 | .2572 | .2241 | | .2614 | .2229 | .2543 | .2572 |
| 19 | .3086 | .3734 | .3086 | .3361 | .2743 | .3052 | .2926 |
| 20 | .2743 | .3361 | .2713 | .3018 | .2572 | .2713 | .2401 |
| 21 | .2572 | .2987 | .2401 | .2614 | .2058 | .2743 | .2229 |
| 22 | .2229 | .2241 | .1886 | .2263 | .1715 | .1865 | .2058 |
| 23 | .2058 | .1132 | .1372 | .1886 | .12 | .1357 | .1715 |
| 24 | .1509 | .1372 | .112 | .12 | .1509 | .12 | .1357 |
| **Max** | **.8962** | **.6173** | **.9774** | **1.0136** | **1.0159** | **.7926** | **.8573** |
| **Min** | **.1029** | **.112** | **.112** | **.1029** | **.112** | **.1029** | **.0857** |
| **Avg** | **.3376** | **.2791** | **.4696** | **.4591** | **.4577** | **.3803** | **.3264** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049]** **BU 5860**
**Substation No/ Name :- 214441 / 33/11 SANGAVI S/STN**
**Feeder No / Name : 202 / 11 KV SHIRWALI SINGLE PHASING Feeder KV- 11 / OUTGOING** **SINGLE PHASING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2452 | .2401 | .2452 | .2641 | .2641 | .2401 | .2829 |
| 2 | .2614 | .2229 | .6104 | .6413 | .5571 | .2401 | .2829 |
| 3 | .3361 | .2743 | .6036 | .679 | .5571 | .3086 | .3018 |
| 4 | .3734 | .3429 | .639 | .7167 | .5898 | .3772 | .3584 |
| 5 | .4481 | .4458 | .7291 | .7356 | .6882 | .4458 | .4527 |
| 6 | .5281 | .583 | .788 | .7733 | .7935 | .583 | .5847 |
| 7 | .6602 | .6001 | .8421 | .9242 | .788 | .6516 | .6413 |
| 8 | .5975 | .583 | .8987 | .9808 | .7712 | .6173 | .5847 |
| 9 | .4854 | .4287 | .8029 | .8865 | .7625 | .4115 | .5228 |
| 10 | 1.1389 | .8383 | .4668 | .3584 | .4481 | .8916 | 1.8757 |
| 11 | .945 | 1.1016 | .3961 | .3584 | .3086 | 1.0082 | 1.707 |
| 12 | .9145 | .9995 | .3772 | .3547 | .2058 | .9997 | |
| 13 | .8688 | 1.0174 | .2641 | .2614 | .3429 | 1.0185 | |
| 14 | .8993 | 1.0174 | .2829 | .2614 | .2401 | .9709 | |
| 15 | .9145 | | .3018 | .3018 | .1715 | .9619 | .884 |
| 16 | .9145 | | .3174 | .3361 | .2401 | .9431 | .945 |
| 17 | .9297 | .9667 | .3547 | .3772 | .2743 | 1.0562 | .8993 |
| 18 | .4458 | .5658 | .3961 | .5658 | .583 | .5658 | .6001 |
| 19 | .583 | .6348 | .6413 | .6348 | .5487 | .6413 | .6584 |
| 20 | .5144 | .5601 | .5658 | .5601 | .4801 | .547 | .5144 |
| 21 | .4801 | .4527 | .4904 | .4481 | .4287 | .4904 | .4801 |
| 22 | .3772 | .3961 | .4108 | .3734 | .3601 | .415 | .3944 |
| 23 | .3086 | .2801 | .3206 | .3361 | .2743 | .3018 | .3429 |
| 24 | .2614 | .2743 | .2427 | .2641 | .2801 | .2572 | .2829 |
| **Max** | **1.1389** | **1.1016** | **.8987** | **.9808** | **.7935** | **1.0562** | **1.8757** |
| **Min** | **.2452** | **.2229** | **.2427** | **.2614** | **.1715** | **.2401** | **.2829** |
| **Avg** | **.6013** | **.5830** | **.4995** | **.5164** | **.4566** | **.6227** | **.6474** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049] BU 5860**
**Substation No/ Name :- 214441 / 33/11 SANGAVI S/STN**
**Feeder No / Name : 203 / 11 KV BARAVNAGAR SINGLE PHASIN Feeder KV- 11 / OUTGOING SINGLE PHASING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1886 | .1372 | .1509 | .1696 | .1494 | .1715 | .1696 |
| 2 | .1867 | .1372 | .2374 | .3086 | .2374 | .1543 | .1526 |
| 3 | .2614 | .1715 | .2622 | .2543 | .2987 | .1715 | .1865 |
| 4 | .3361 | .2743 | .3018 | .2713 | .3361 | .2743 | .2374 |
| 5 | .4066 | .3429 | .3734 | .3052 | .3561 | .3772 | .3561 |
| 6 | .5601 | .5487 | .415 | .3391 | .3795 | .4973 | .5426 |
| 7 | .6584 | .5487 | .6413 | .5256 | | .6001 | .5596 |
| 8 | .6036 | .4973 | .7122 | .7122 | .7468 | .5487 | .5426 |
| 9 | .4481 | .3772 | .8676 | .7291 | .7842 | .4115 | .4287 |
| 10 | .7468 | .5571 | .3734 | .3086 | .2713 | .5182 | .6613 |
| 11 | .6401 | .7122 | .2035 | .2987 | .2058 | .823 | .7537 |
| 12 | .7011 | .6882 | .1696 | .1867 | .1372 | .8648 | .8192 |
| 13 | .6706 | .7449 | .1017 | .1867 | .12 | | .7011 |
| 14 | .6859 | .8215 | .0848 | .1494 | .12 | .7291 | .7011 |
| 15 | .7011 | .7842 | .1187 | .1886 | .12 | .7291 | .7373 |
| 16 | .6706 | .7842 | .1696 | .2263 | .12 | .7122 | .7209 |
| 17 | .5792 | .5228 | .2374 | .2641 | .3086 | .7461 | .503 |
| 18 | .4115 | .4108 | | .4108 | .3429 | .3222 | .4458 |
| 19 | .4115 | .4904 | .4578 | .4481 | .3772 | .4239 | .4572 |
| 20 | .3772 | .415 | .373 | .3734 | .2915 | .3944 | .3772 |
| 21 | .3086 | .3361 | .3222 | .2987 | .2572 | .3086 | .3429 |
| 22 | .2572 | .2263 | .2572 | .2641 | .2401 | .2374 | .2058 |
| 23 | .2058 | .1494 | .2058 | .2241 | .2058 | .1696 | .2058 |
| 24 | .1867 | .1372 | .1494 | .1696 | .1886 | .1886 | .1696 |
| **Max** | **.7468** | **.8215** | **.8676** | **.7291** | **.7842** | **.8648** | **.8192** |
| **Min** | **.1867** | **.1372** | **.0848** | **.1494** | **.12** | **.1543** | **.1526** |
| **Avg** | **.4668** | **.4506** | **.3124** | **.3172** | **.2867** | **.4510** | **.4574** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049]** **BU 5860**
**Substation No/ Name :- 214441 / 33/11 SANGAVI S/STN**
**Feeder No / Name : 205 / 11 KV PONDKULE SINGLE PHASING Feeder KV- 11 / OUTGOING** **SINGLE PHASING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1132 | .1029 | .1132 | .1132 | .112 | .1029 | .0943 |
| 2 | .112 | | .3391 | .3206 | .2949 | .1029 | .1132 |
| 3 | .112 | .12 | .3605 | .3395 | .3052 | .1372 | .1509 |
| 4 | .1494 | .1372 | .4481 | .3961 | .3277 | .1715 | .2075 |
| 5 | .1867 | .2058 | .4854 | .4294 | .3605 | .2058 | .2263 |
| 6 | .2614 | .2743 | .5228 | .4904 | .421 | .2743 | .2641 |
| 7 | .3206 | .2915 | .6348 | .6602 | .5765 | .3086 | .3018 |
| 8 | .2987 | .2743 | .6443 | | .6371 | .2743 | .2829 |
| 9 | .2241 | .2058 | .6062 | .7356 | .6783 | .2058 | .2452 |
| 10 | .6348 | .5182 | .2614 | .1886 | .1357 | .442 | .547 |
| 11 | .5487 | .6104 | .1698 | .1494 | .1372 | .7545 | 1.012 |
| 12 | .5944 | .6203 | .1509 | .1307 | .1372 | .7167 | 1.0753 |
| 13 | .5487 | .6348 | .0943 | .1307 | .12 | .6722 | 1.012 |
| 14 | .6859 | .6722 | .1132 | | .12 | .679 | .4877 |
| 15 | .6097 | | .1132 | | .12 | .6413 | .4877 |
| 16 | .6097 | 1.0174 | .112 | .1867 | .12 | .547 | .5182 |
| 17 | .6097 | .679 | .2427 | .2241 | .1715 | .6602 | .5487 |
| 18 | .2058 | .2427 | .2241 | .2427 | .1886 | .2075 | .2572 |
| 19 | .2229 | .2452 | .2614 | .2614 | .2229 | .2263 | .2195 |
| 20 | .2401 | .1867 | .2263 | .2427 | .2058 | .2075 | .1886 |
| 21 | .1886 | .1494 | .2075 | .1867 | .2058 | .1698 | .1715 |
| 22 | .1715 | .132 | .1509 | .1494 | .1372 | .1509 | .1372 |
| 23 | .1372 | .1132 | .1132 | .1307 | .12 | .1132 | .12 |
| 24 | .1052 | .12 | .1132 | .1132 | .112 | .1029 | .0943 |
| **Max** | **.6859** | **1.0174** | **.6443** | **.7356** | **.6783** | **.7545** | **1.0753** |
| **Min** | **.1052** | **.1029** | **.0943** | **.1132** | **.112** | **.1029** | **.0943** |
| **Avg** | **.3288** | **.3433** | **.2795** | **.2772** | **.2486** | **.3364** | **.3651** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049] BU 5860**
**Substation No/ Name :- 214441 / 33/11 SANGAVI S/STN**
**Feeder No / Name : 206 / 11 KV PATILWASTI SINGLE PHASIN Feeder KV- 11 / OUTGOING SINGLE PHASING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1886 | .1715 | .1509 | .1677 | .1698 | .1715 | .1677 |
| 2 | .7468 | .5792 | .168 | .1677 | .1867 | .5243 | .6979 |
| 3 | .7392 | .639 | .1867 | .2012 | .1867 | .5182 | .6539 |
| 4 | .7011 | .6554 | .2263 | .2347 | .2614 | .6097 | .6874 |
| 5 | .7421 | .6401 | .2987 | .3185 | .3361 | .7537 | .7712 |
| 6 | .7842 | .7373 | .4108 | .4191 | .4108 | .8356 | .9389 |
| 7 | .8859 | .8029 | .5228 | .4862 | .5228 | .8848 | .9156 |
| 8 | 1.0082 | .7773 | .4854 | .4191 | .4854 | .8848 | |
| 9 | 1.0082 | .7011 | .3395 | .39 | .4108 | .7926 | .8718 |
| 10 | .1867 | .2058 | .9709 | .8383 | .7842 | .2229 | .218 |
| 11 | .1715 | .1494 | .9724 | 1.0242 | .8192 | .1844 | .2058 |
| 12 | .1715 | .1494 | 1.0059 | 1.0829 | .852 | .1341 | .1715 |
| 13 | .1372 | .1509 | .9054 | 1.0456 | .9175 | .1341 | .1372 |
| 14 | .12 | .1494 | .9892 | 1.0456 | .9503 | | .12 |
| 15 | .1372 | .112 | .9556 | .9503 | .9503 | .1341 | .12 |
| 16 | .1715 | .112 | .9054 | 1.0082 | .9667 | .1677 | .1715 |
| 17 | .2401 | .1886 | .9221 | .9709 | .9503 | .218 | .2229 |
| 18 | .3258 | .3395 | | .3772 | .2743 | .3018 | .3429 |
| 19 | .3772 | .4481 | .4359 | .4481 | .3772 | .3521 | .4115 |
| 20 | .3429 | .3734 | .3688 | .3734 | .3601 | .3018 | .3086 |
| 21 | .2915 | .3361 | .3018 | .3018 | .2743 | .3018 | .2743 |
| 22 | .2401 | .2241 | .2347 | .2241 | .1886 | .2347 | .2058 |
| 23 | .2058 | | .1844 | .1886 | .1715 | .1844 | .1886 |
| 24 | | .1715 | .1494 | .1677 | .1698 | .1715 | .1844 |
| **Max** | **1.0082** | **.8029** | **1.0059** | **1.0829** | **.9667** | **.8848** | **.9389** |
| **Min** | **.12** | **.112** | **.1494** | **.1677** | **.1698** | **.1341** | **.12** |
| **Avg** | **.4314** | **.3832** | **.5257** | **.5355** | **.4990** | **.3921** | **.3908** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049] BU 5860**
**Substation No/ Name :- 214441 / 33/11 SANGAVI S/STN**
**Feeder No / Name : 207 / 11 KV SANGAVI SINGLE PHASING Feeder KV- 11 / OUTGOING SINGLE PHASING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2241 | .2058 | .1886 | .2075 | .2263 | .2058 | .2452 |
| 2 | .2987 | .1677 | .2241 | .1886 | .2054 | .2458 | .2641 |
| 3 | .3292 | .2058 | .2987 | .2263 | .2614 | .2622 | .3018 |
| 4 | .3658 | .2401 | .3734 | .3206 | .373 | .3277 | .3961 |
| 5 | .4024 | .3048 | .5228 | .3921 | .5228 | .3932 | .4338 |
| 6 | .4481 | .3658 | .7545 | .6602 | .7655 | .442 | .4904 |
| 7 | .5093 | .3658 | .8215 | .8299 | .8402 | .4572 | .5658 |
| 8 | .4572 | .381 | .7468 | .7356 | .7468 | .4877 | .5281 |
| 9 | .439 | .3353 | .5975 | .6036 | .6348 | .4572 | .4904 |
| 10 | .2987 | .3258 | .4854 | .4527 | .4854 | .3772 | .415 |
| 11 | .2743 | .3395 | .4904 | .2987 | .426 | .3206 | .6858 |
| 12 | .2743 | .2801 | .3395 | .4854 | .426 | .2926 | .5486 |
| 13 | .1543 | .168 | .4527 | .4668 | .3932 | .2452 | .4116 |
| 14 | .1715 | .1494 | .4527 | .5228 | .4096 | .2263 | .2058 |
| 15 | .2058 | .1494 | .4527 | .4481 | .3932 | .2641 | .2058 |
| 16 | .2743 | .1494 | .4338 | .4481 | .4096 | .3395 | .3086 |
| 17 | .4115 | | .4481 | .5228 | .3605 | .5281 | .3772 |
| 18 | .4973 | .4481 | | .7095 | .4458 | .6036 | .6001 |
| 19 | .583 | .7095 | .7733 | .6722 | .5144 | .679 | .6584 |
| 20 | .5487 | .5975 | .6036 | .5281 | .4801 | .547 | .463 |
| 21 | .4458 | .5281 | .4904 | .4481 | .3772 | .4904 | .4115 |
| 22 | .3772 | .3772 | .3961 | .3772 | .2743 | .3961 | .2896 |
| 23 | .2743 | .2263 | .2641 | .2987 | .2229 | .2829 | .2743 |
| 24 | .2241 | .2401 | .1867 | .2263 | .2427 | .2058 | .2452 |
| **Max** | **.583** | **.7095** | **.8215** | **.8299** | **.8402** | **.679** | **.6858** |
| **Min** | **.1543** | **.1494** | **.1867** | **.1886** | **.2054** | **.2058** | **.2058** |
| **Avg** | **.3537** | **.3157** | **.4695** | **.4612** | **.4349** | **.3782** | **.4090** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049] BU 5860**
**Substation No/ Name :- 214472 / 33 KV MALEGAON (KH)**
**Feeder No / Name : 201 / 11 KV SALOBA AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0474 | | .0633 | .0633 | .0474 | .0633 | .0633 |
| 2 | .8697 | .8539 | .0474 | .0474 | .0474 | .8855 | .8381 |
| 3 | .8697 | .8855 | .0474 | .0474 | .0474 | .8855 | .8381 |
| 4 | .8697 | .8381 | .0474 | .0474 | .0633 | .9014 | .8539 |
| 5 | .8697 | .8539 | .0633 | .0633 | .0633 | .9014 | .8539 |
| 6 | .9014 | .8855 | .0633 | .0633 | .0633 | .9646 | .8855 |
| 7 | 1.012 | .933 | .0791 | .0791 | .0791 | .9962 | .9646 |
| 8 | 1.0911 | .9646 | .0791 | .0949 | .0791 | 1.0595 | 1.0279 |
| 9 | 1.012 | 1.0437 | .0633 | .0474 | .0633 | 1.0595 | 1.0595 |
| 10 | .0474 | .0474 | 1.1385 | 1.1702 | 1.1544 | .0633 | .0474 |
| 11 | 1.3125 | .0474 | 1.2334 | 1.2334 | 1.2492 | .0474 | .0474 |
| 12 | .056 | .0474 | 1.2967 | 1.2809 | 1.2651 | .0633 | .0474 |
| 13 | .0474 | .0316 | 1.2809 | 1.2651 | 1.2492 | .0316 | .0474 |
| 14 | .0474 | .0316 | 1.2651 | 1.2492 | 1.2334 | .0316 | .0474 |
| 15 | .0474 | .0474 | 1.2651 | 1.2334 | 1.2334 | .0316 | .0316 |
| 16 | .0316 | .0633 | 1.2651 | 1.2334 | 1.186 | .0316 | .0474 |
| 17 | .0633 | .0474 | 1.2176 | | 1.1544 | .0633 | .0474 |
| 18 | .0474 | .0791 | .0633 | .0633 | .0633 | .0474 | .0633 |
| 19 | .0633 | .0791 | .0633 | .0791 | .0633 | .0791 | .0633 |
| 20 | .0633 | .0791 | .0633 | .0791 | .0633 | .0791 | .0633 |
| 21 | .0633 | .0633 | .0633 | .0633 | .0633 | .0633 | .0633 |
| 22 | .0633 | .0633 | .0633 | .0633 | .0633 | .0633 | .0633 |
| 23 | .0633 | .0633 | .0633 | .0474 | .0633 | .0633 | .0633 |
| 24 | .0474 | .0633 | .0633 | .0633 | .0474 | .0633 | .0633 |
| **Max** | **1.3125** | **1.0437** | **1.2967** | **1.2809** | **1.2651** | **1.0595** | **1.0595** |
| **Min** | **.0316** | **.0316** | **.0474** | **.0474** | **.0474** | **.0316** | **.0316** |
| **Avg** | **.4003** | **.3527** | **.4566** | **.4208** | **.4461** | **.3558** | **.3413** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049]** **BU 5860**
**Substation No/ Name :- 214472 / 33 KV MALEGAON (KH)**
**Feeder No / Name : 202 / 11 KV YAMAI AG** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0972 | .0983 | .081 | .0972 | .0819 | .1134 | .081 |
| 2 | .0972 | .0983 | 1.4737 | | 1.6221 | .0972 | .081 |
| 3 | .0972 | .0983 | 1.4575 | 1.4575 | 1.5893 | .0972 | .081 |
| 4 | .1134 | .1147 | 1.4575 | 1.4575 | 1.5402 | .0972 | .0972 |
| 5 | .1457 | .1311 | 1.4899 | 1.4899 | 1.5023 | .1134 | .1134 |
| 6 | .1781 | .1802 | 1.5384 | 1.5546 | 1.5893 | .1781 | .1296 |
| 7 | .1943 | .213 | 1.6194 | 1.6842 | 1.7204 | .1943 | .1781 |
| 8 | .2105 | .2458 | 1.7976 | 1.8138 | 1.8023 | .1943 | .1619 |
| 9 | .1296 | .1638 | 1.7976 | 1.7976 | 1.6385 | .1619 | .1296 |
| 10 | 1.704 | 1.7328 | .1457 | .1475 | .1296 | 1.668 | 1.8138 |
| 11 | 1.9334 | 1.9271 | .1296 | .1311 | .1296 | 1.8785 | 1.9433 |
| 12 | 2.1136 | 2.0405 | .1296 | .1147 | .1134 | 1.9433 | 1.8461 |
| 13 | 2.0153 | 1.9919 | .1296 | .0819 | .0972 | 1.9109 | 1.9109 |
| 14 | 2.0809 | 1.9757 | .0972 | .1147 | .0972 | 1.9109 | 1.8785 |
| 15 | 2.0153 | 1.9433 | .0972 | .0819 | .0972 | 1.8461 | 1.9109 |
| 16 | 1.9662 | 1.749 | .1134 | .0819 | .1134 | 1.9109 | 1.9109 |
| 17 | 1.8679 | 1.749 | .1134 | .0983 | .1134 | 1.8785 | 1.8138 |
| 18 | .1475 | .1296 | .1457 | .1311 | .1619 | .1134 | .1296 |
| 19 | .1475 | .1457 | .1457 | .1475 | .1781 | .1296 | .1457 |
| 20 | .1802 | .1619 | .1457 | .1475 | .1781 | .1457 | .1619 |
| 21 | .1475 | .1619 | .1296 | .1638 | .1781 | .1457 | .1457 |
| 22 | .1311 | .1296 | .1134 | .1311 | .1619 | .1296 | .1296 |
| 23 | .1147 | .0972 | .0972 | .0983 | .1134 | .1134 | .1134 |
| 24 | .0972 | .0983 | .081 | .0972 | .0983 | .1134 | .081 |
| **Max** | **2.1136** | **2.0405** | **1.7976** | **1.8138** | **1.8023** | **1.9433** | **1.9433** |
| **Min** | **.0972** | **.0972** | **.081** | **.0819** | **.0819** | **.0972** | **.081** |
| **Avg** | **.7469** | **.7240** | **.6053** | **.5705** | **.6270** | **.7119** | **.7078** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049] BU 5860**
**Substation No/ Name :- 214472 / 33 KV MALEGAON (KH)**
**Feeder No / Name : 203 / 11 KV NAGESHWAR GFSS GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5415 | .5041 | .5041 | .5228 | .5228 | .5228 | .5228 |
| 2 | .5041 | .4854 | .4854 | .4854 | .4854 | .5041 | .5228 |
| 3 | .5041 | .5228 | .4854 | .4854 | .4854 | .5041 | .5228 |
| 4 | .5601 | .5788 | .5228 | .5228 | .5228 | .5228 | .5601 |
| 5 | .6535 | .6535 | .6348 | .6348 | .6348 | .5975 | .6348 |
| 6 | .8215 | .8589 | .8029 | .8215 | .7655 | .8215 | .8488 |
| 7 | 1.2136 | 1.2323 | 1.0642 | 1.0829 | 1.0269 | 1.1203 | 1.1763 |
| 8 | 1.1389 | 1.1949 | 1.0456 | 1.0456 | 1.0829 | 1.0829 | 1.1576 |
| 9 | .9522 | 1.0082 | .9335 | .9335 | .9522 | .9709 | 1.0456 |
| 10 | .8962 | .8962 | .8215 | .8962 | 1.0456 | .9149 | .9335 |
| 11 | .8402 | .7468 | .8962 | .9522 | .9709 | .8215 | .9149 |
| 12 | .7468 | .8029 | .8589 | | .7468 | .7655 | .7842 |
| 13 | .6348 | .7468 | .7842 | .8215 | .5601 | .7468 | .7095 |
| 14 | .6161 | .7468 | .6722 | .7095 | .5975 | .7468 | .7468 |
| 15 | .6161 | .7095 | .6722 | .7655 | .6722 | .7282 | .7095 |
| 16 | .6161 | .6722 | .6722 | .8215 | .6722 | .6722 | .5415 |
| 17 | .6908 | .6348 | .7655 | .7468 | .6348 | .6161 | .7655 |
| 18 | .8402 | .7842 | .8215 | .8402 | .7095 | .7842 | .9335 |
| 19 | .8962 | .8589 | .8962 | .8402 | .8215 | .9335 | .9335 |
| 20 | .9335 | .8962 | .9149 | .9149 | .8215 | .9335 | .9335 |
| 21 | .8215 | .8402 | .8215 | .7842 | .7842 | .8402 | .8676 |
| 22 | .7655 | .7282 | .7095 | .6722 | .7095 | .7282 | .7655 |
| 23 | .6535 | .5601 | .6348 | .5788 | .6722 | .6348 | .6722 |
| 24 | .5601 | .4854 | .5041 | .5228 | .5041 | .5228 | .5041 |
| **Max** | **1.2136** | **1.2323** | **1.0642** | **1.0829** | **1.0829** | **1.1203** | **1.1763** |
| **Min** | **.5041** | **.4854** | **.4854** | **.4854** | **.4854** | **.5041** | **.5041** |
| **Avg** | **.7507** | **.7562** | **.7468** | **.7566** | **.7251** | **.7515** | **.7795** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049]** **BU 5860**
**Substation No/ Name :- 214472 / 33 KV MALEGAON (KH)**
**Feeder No / Name : 204 / 11 KV NANDAN EXPRESS** **NON SHEDDABLE EXPRESS HV FEEDERS**
**Feeder KV- 11 / OUTGOING** **(CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3018 | .3174 | .2829 | .3584 | .3734 | .3772 | .2263 |
| 2 | .3395 | .3547 | .2641 | .3584 | .3734 | .3206 | .2263 |
| 3 | .3395 | .3361 | .2641 | .3395 | .4294 | .3206 | .2263 |
| 4 | .3395 | .2987 | .2829 | .3395 | .3734 | .3018 | .2452 |
| 5 | .3772 | .2987 | .3206 | .3772 | .3921 | .3395 | .2641 |
| 6 | .4715 | .2987 | .3961 | .415 | | .2641 | .3395 |
| 7 | .4715 | .4481 | .3772 | .4338 | .4481 | .3206 | .3395 |
| 8 | .3395 | .5228 | .4338 | .3772 | .4294 | .3395 | .3961 |
| 9 | .3206 | .2801 | .3961 | .3772 | .3361 | .6602 | .415 |
| 10 | .7842 | .415 | .679 | .6908 | .5847 | .6979 | .3961 |
| 11 | .7468 | .4904 | .7167 | .6722 | .6036 | .6602 | .415 |
| 12 | .5601 | .547 | .4715 | .5975 | .6413 | .6036 | .4715 |
| 13 | .5975 | .4338 | .2263 | .3921 | .4527 | .3018 | .3961 |
| 14 | .5415 | .415 | .6036 | .5601 | .4715 | .4904 | .3206 |
| 15 | .5228 | .3961 | .5658 | .5788 | .5093 | .5658 | .5093 |
| 16 | .3174 | .3206 | .4715 | .5415 | .3584 | .4904 | .547 |
| 17 | .2614 | .3584 | .415 | .3921 | .4338 | .3395 | .5658 |
| 18 | .5041 | .6036 | .5093 | .5041 | .547 | .3395 | .5281 |
| 19 | .4854 | .4338 | .5093 | .5041 | .5281 | .3395 | .547 |
| 20 | .4854 | .3961 | .5093 | .5228 | .5281 | .3584 | .547 |
| 21 | .4854 | .415 | .4715 | .4854 | .5658 | .3772 | .5658 |
| 22 | .4668 | .3772 | .4338 | .4668 | .5847 | .4527 | .6413 |
| 23 | .4294 | .3395 | .3961 | .4294 | .5281 | .415 | .4715 |
| 24 | .2829 | .3174 | .2829 | .3584 | .4108 | .3961 | .2263 |
| **Max** | **.7842** | **.6036** | **.7167** | **.6908** | **.6413** | **.6979** | **.6413** |
| **Min** | **.2614** | **.2801** | **.2263** | **.3395** | **.3361** | **.2641** | **.2263** |
| **Avg** | **.4488** | **.3923** | **.4283** | **.4613** | **.4741** | **.4197** | **.4094** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049] BU 5860**
**Substation No/ Name :- 214472 / 33 KV MALEGAON (KH)**
**Feeder No / Name : 205 / 11 KV NIAM EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS**
**Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0943 | | .0943 | .0943 | .0943 | .1132 | .0943 |
| 2 | .0943 | .0943 | .0943 | .0943 | .0943 | .1132 | .0943 |
| 3 | .0943 | .1132 | .0943 | .0943 | .0943 | .1132 | .0943 |
| 4 | .0943 | .1132 | .0943 | .0943 | .0943 | .1132 | .0943 |
| 5 | .0943 | .1132 | .0943 | .0943 | .1132 | .1132 | .0943 |
| 6 | .0943 | .1132 | .0943 | .0943 | .1132 | .0943 | .0943 |
| 7 | .0943 | .0943 | .0943 | .0943 | .0943 | .0943 | .0943 |
| 8 | .0943 | .0943 | .0943 | .0943 | .0943 | .0943 | .1132 |
| 9 | .0943 | .1132 | .1132 | .0943 | .1132 | .1132 | .1132 |
| 10 | .1509 | .132 | .132 | .1509 | .1698 | .1132 | .1509 |
| 11 | .1509 | .132 | .1698 | .1698 | .1509 | .1698 | .1509 |
| 12 | .1509 | .1698 | .1698 | .1509 | .1698 | .1886 | .1509 |
| 13 | .2075 | .1886 | .1698 | .1509 | .1698 | .2075 | .1509 |
| 14 | .2075 | .1886 | .1698 | .1509 | .1509 | .1886 | .1509 |
| 15 | .1886 | .1886 | .1698 | .1698 | .1509 | .1886 | .1509 |
| 16 | .1698 | .1698 | .1886 | .1698 | .132 | .1698 | .132 |
| 17 | .132 | .1509 | .132 | .1132 | .1132 | .132 | .1132 |
| 18 | .1132 | .132 | .0943 | .1132 | .1132 | .1132 | .132 |
| 19 | .1132 | .132 | .1132 | .1132 | .1097 | .1132 | .1132 |
| 20 | .1132 | .132 | .1132 | .1132 | .1097 | .1132 | .1132 |
| 21 | .1132 | .132 | .1132 | .1132 | .1132 | .1132 | .1132 |
| 22 | .1132 | .1132 | .1132 | .1132 | .1132 | .1132 | .1132 |
| 23 | .1132 | .1132 | .0943 | .1132 | .1132 | .1132 | .0943 |
| 24 | .0943 | .0943 | .1132 | .0943 | .0943 | .1132 | .0943 |
| **Max** | **.2075** | **.1886** | **.1886** | **.1698** | **.1698** | **.2075** | **.1509** |
| **Min** | **.0943** | **.0943** | **.0943** | **.0943** | **.0943** | **.0943** | **.0943** |
| **Avg** | **.1242** | **.1312** | **.1218** | **.1187** | **.1200** | **.1297** | **.1171** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049] BU 5860**
**Substation No/ Name :- 214491 / 33/11 KV SHIRSUPHAL**
**Feeder No / Name : 201 / 11 KV SHIRSUPHAL SINGLE SINGLE PHASING PHASIN Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .218 | .1886 | .2058 | .1886 | .2058 | .1886 | .2035 |
| 2 | .2035 | .1886 | .2915 | .4801 | .583 | .2401 | .2374 |
| 3 | .3185 | .2058 | .2915 | .583 | .6516 | .2915 | .2713 |
| 4 | .4024 | .2058 | .2915 | .6173 | .6859 | .3258 | .3391 |
| 5 | .4917 | .3258 | .4287 | .6859 | .7202 | .3772 | .4024 |
| 6 | .5197 | .463 | .6516 | .7888 | .7888 | .463 | .6443 |
| 7 | .57 | .583 | .7545 | .9088 | .8573 | .5487 | .7042 |
| 8 | .5365 | .583 | .9945 | .9602 | .9259 | .4801 | .6539 |
| 9 | .4115 | .3772 | .9259 | .8745 | .823 | .3944 | .407 |
| 10 | .6344 | .4973 | .3601 | .3258 | .3086 | .6859 | .373 |
| 11 | .9431 | .7373 | .2572 | .2915 | .2743 | .8059 | |
| 12 | 1.046 | .8573 | .2401 | .2401 | .2572 | .823 | |
| 13 | .9259 | 1.0288 | .2058 | .2058 | .2229 | .8573 | |
| 14 | .9945 | 1.0117 | .2058 | .2058 | .2401 | .8745 | |
| 15 | 1.046 | .9945 | .2401 | .2229 | .2401 | .8402 | |
| 16 | .9945 | .9945 | .2572 | .2401 | .2743 | .7888 | .7969 |
| 17 | .9602 | .9431 | .2743 | .2572 | .2915 | .703 | .7545 |
| 18 | .2915 | .3601 | .3429 | .463 | .3429 | .4287 | .6706 |
| 19 | .3429 | .3601 | .4115 | .5487 | .4287 | .5144 | .5365 |
| 20 | .3944 | .3944 | .4973 | .4801 | .4801 | .583 | .5087 |
| 21 | .3086 | .3086 | .4115 | .3772 | .3429 | .4801 | .4409 |
| 22 | .2743 | .2743 | .4115 | .1715 | .2743 | .3086 | .2883 |
| 23 | .2401 | .2401 | .2401 | .2743 | .2401 | .2743 | .2454 |
| 24 | .2486 | .2058 | .2058 | .2058 | .2401 | .2058 | .2321 |
| **Max** | **1.046** | **1.0288** | **.9945** | **.9602** | **.9259** | **.8745** | **.7969** |
| **Min** | **.2035** | **.1886** | **.2058** | **.1715** | **.2058** | **.1886** | **.2035** |
| **Avg** | **.5549** | **.5137** | **.3915** | **.4415** | **.4458** | **.5201** | **.4584** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049] BU 5860**
**Substation No/ Name :- 214491 / 33/11 KV SHIRSUPHAL**
**Feeder No / Name : 202 / 11 KV GADIKHEL SINGLE PHASING Feeder KV- 11 / OUTGOING SINGLE PHASING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2347 | .2401 | .2572 | .2058 | .2229 | .2229 | .2035 |
| 2 | .2818 | .2401 | .1715 | .4359 | .5144 | .2915 | .2713 |
| 3 | .3185 | .2401 | .1715 | .5087 | .5487 | .3258 | .3018 |
| 4 | .3521 | .2401 | .1715 | .5487 | .6344 | .3601 | .3353 |
| 5 | .3856 | .2401 | .3086 | .6173 | .7202 | .4287 | .3481 |
| 6 | .4191 | .3086 | .4287 | .6516 | .7716 | .463 | .4144 |
| 7 | .4527 | .4287 | .5316 | .6859 | .8402 | .4973 | .431 |
| 8 | .373 | .3772 | .6001 | .7293 | .8573 | .3429 | .4024 |
| 9 | .2915 | .3258 | .6344 | .6443 | .8059 | .3086 | .2622 |
| 10 | .4115 | .3429 | .3086 | .1715 | .1715 | .4458 | .2347 |
| 11 | .6001 | .5144 | .1715 | .1543 | .1543 | .5316 | |
| 12 | .6687 | .6516 | .12 | .12 | .1372 | .583 | |
| 13 | .6344 | .6859 | .1372 | .1029 | .12 | .6001 | |
| 14 | .6173 | .703 | .1543 | .12 | .1372 | .6344 | |
| 15 | .7373 | .7202 | .1715 | .1372 | .1543 | .6001 | |
| 16 | .6516 | .7202 | .1886 | .1543 | .1715 | .5658 | .5935 |
| 17 | .6173 | .6859 | .2058 | .1715 | .1886 | .5487 | .6135 |
| 18 | .1886 | .1543 | .2743 | .3086 | .2915 | .2743 | .5138 |
| 19 | .2572 | .2401 | .3601 | .3772 | .3601 | .4115 | .3898 |
| 20 | .3429 | .3429 | .4115 | .4458 | .4115 | .4801 | .3391 |
| 21 | .3086 | .3086 | .3429 | .3772 | .463 | .3772 | .3222 |
| 22 | .2572 | .2572 | .3086 | .3086 | .3086 | .2743 | .3052 |
| 23 | .2401 | .2572 | .2743 | .2915 | .2743 | .2572 | .298 |
| 24 | .2515 | .2401 | .2572 | .2401 | .2572 | .2401 | .2347 |
| **Max** | **.7373** | **.7202** | **.6344** | **.7293** | **.8573** | **.6344** | **.6135** |
| **Min** | **.1886** | **.1543** | **.12** | **.1029** | **.12** | **.2229** | **.2035** |
| **Avg** | **.4122** | **.3944** | **.2901** | **.3545** | **.3965** | **.4194** | **.3587** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049] BU 5860**
**Substation No/ Name :- 214491 / 33/11 KV SHIRSUPHAL**
**Feeder No / Name : 203 / 11 KV ATOLEWASTI SINGLE PHASIN Feeder KV- 11 / OUTGOING SINGLE PHASING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1341 | .1715 | .3086 | .12 | .12 | .12 | .1017 |
| 2 | .1844 | .1715 | .12 | .3258 | .3086 | .1372 | .1357 |
| 3 | .1696 | .1715 | .1372 | .3772 | .3772 | .1372 | .1526 |
| 4 | .1844 | .1715 | .1372 | .4115 | .3944 | .1543 | .1844 |
| 5 | .2035 | .1715 | .1372 | .4458 | .4287 | .1715 | .2035 |
| 6 | .2155 | .1715 | .2058 | .4801 | .4458 | .2229 | .2012 |
| 7 | .2543 | .2058 | .2572 | .5144 | .463 | .2401 | .218 |
| 8 | .2035 | .2058 | .3429 | .5487 | .4801 | .2058 | |
| 9 | .1715 | .12 | .3601 | .463 | .4115 | .1715 | .1526 |
| 10 | .2572 | .2401 | .1372 | .1372 | .1372 | .3429 | .2374 |
| 11 | .1715 | .4287 | .0686 | .12 | .1029 | .3772 | |
| 12 | .5316 | .4973 | .0343 | .1029 | .0857 | .4115 | |
| 13 | .5316 | .4801 | .0686 | .0857 | .0686 | .3772 | |
| 14 | .3772 | .463 | .0686 | .0686 | .0857 | .3772 | |
| 15 | .463 | .4287 | .1029 | .0686 | .0857 | .3772 | |
| 16 | .463 | .2743 | .1029 | .0857 | .1029 | .3601 | .3052 |
| 17 | .4458 | .2572 | .12 | .0857 | .1029 | .3429 | .3222 |
| 18 | .1715 | .1886 | .1372 | | .1543 | .1886 | .1772 |
| 19 | .1715 | .2058 | .2058 | .1715 | .2058 | .2058 | .1949 |
| 20 | .1715 | .2058 | .2229 | .2229 | .2401 | .2058 | .1696 |
| 21 | .1715 | .2058 | .2058 | .2058 | .2058 | .1715 | .1578 |
| 22 | .1715 | .1886 | .1886 | .1715 | .1715 | .1372 | .1402 |
| 23 | .1715 | .1715 | .1715 | .1543 | .1543 | .1372 | .1227 |
| 24 | .1509 | .1715 | .1715 | .1543 | .1372 | .1372 | .1187 |
| **Max** | **.5316** | **.4973** | **.3601** | **.5487** | **.4801** | **.4115** | **.3222** |
| **Min** | **.1341** | **.12** | **.0343** | **.0686** | **.0686** | **.12** | **.1017** |
| **Avg** | **.2559** | **.2487** | **.1672** | **.2401** | **.2279** | **.2379** | **.1831** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049] BU 5860**
**Substation No/ Name :- 214491 / 33/11 KV SHIRSUPHAL**
**Feeder No / Name : 204 / 11 KV PATILWASTI SINGLE PHASIN Feeder KV- 11 / OUTGOING SINGLE PHASING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1341 | .12 | .1372 | .1029 | .0857 | .1029 | .0671 |
| 2 | .1187 | .12 | .6516 | .6516 | .6687 | .12 | .1187 |
| 3 | .1526 | .12 | | .7545 | .7373 | .1372 | .1357 |
| 4 | .1865 | .1372 | .6516 | .823 | .7888 | .1372 | .1677 |
| 5 | .2204 | .1715 | .6859 | .8573 | .8402 | .1715 | .2035 |
| 6 | .2347 | .2058 | .7716 | .9088 | .8916 | .2058 | .2543 |
| 7 | .3113 | .2401 | .8916 | .9259 | .9431 | .2572 | .2883 |
| 8 | .285 | .2572 | .9259 | .9945 | 1.0117 | .2229 | .2374 |
| 9 | .2572 | .2401 | .8573 | .8916 | .9259 | .1372 | .1526 |
| 10 | .7202 | .7888 | .2058 | .1029 | .12 | .583 | .7461 |
| 11 | .9431 | .9431 | .1715 | .0857 | .12 | .7545 | |
| 12 | 1.0974 | .9945 | .12 | .0686 | .1029 | .823 | |
| 13 | 1.0802 | .9602 | .1715 | .0686 | .0857 | .8573 | |
| 14 | 1.0631 | .9602 | .2058 | .0857 | .0857 | .8916 | |
| 15 | 1.046 | .9259 | .2058 | .0857 | .0857 | .8573 | |
| 16 | 1.0631 | .9602 | .2058 | .1029 | .1029 | .8573 | .8987 |
| 17 | 1.0974 | 1.0288 | .1886 | .12 | .1029 | .8573 | 1.0004 |
| 18 | .1715 | .1715 | .1715 | .1715 | .1372 | .1715 | 1.0174 |
| 19 | .2058 | .2058 | .1715 | .2058 | .1715 | .2058 | .2103 |
| 20 | .2401 | .2058 | .2058 | .1715 | .1543 | .2058 | .1753 |
| 21 | .1886 | .1715 | .2401 | .1543 | .1372 | .1372 | .1578 |
| 22 | .1372 | .1715 | .1372 | .1543 | .1029 | .1029 | .1227 |
| 23 | .1372 | .1543 | .1715 | .1029 | .1029 | .1029 | .1063 |
| 24 | .1341 | .1372 | .1372 | .1029 | .0857 | .1029 | .0838 |
| **Max** | **1.0974** | **1.0288** | **.9259** | **.9945** | **1.0117** | **.8916** | **1.0174** |
| **Min** | **.1187** | **.12** | **.12** | **.0686** | **.0857** | **.1029** | **.0671** |
| **Avg** | **.4677** | **.4330** | **.3601** | **.3622** | **.3579** | **.3751** | **.3234** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049] BU 5860**
**Substation No/ Name :- 214491 / 33/11 KV SHIRSUPHAL**
**Feeder No / Name : 205 / 11 KV TILEKARWASTI SINGLE SINGLE PHASING PHAS Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0678 | .0686 | .0686 | .0686 | .0686 | .0686 | .0848 |
| 2 | .6036 | .5316 | .0686 | .0343 | .0857 | .583 | .3561 |
| 3 | .6274 | .5316 | .0686 | .0343 | .0857 | .6516 | .407 |
| 4 | .6443 | .5316 | .0686 | .0514 | .0857 | .6859 | .4191 |
| 5 | .6706 | .6001 | .0686 | .0686 | .0686 | .703 | .4409 |
| 6 | | .6859 | .0686 | .0686 | .0686 | .7545 | .4807 |
| 7 | .9665 | .7373 | .0686 | .0857 | .0686 | .823 | .6299 |
| 8 | .9221 | .8059 | .1029 | .1029 | .0686 | .7888 | .6796 |
| 9 | .8916 | .8059 | .1029 | .0686 | .0686 | .7202 | .6962 |
| 10 | .0686 | .0686 | .823 | .9259 | .823 | .0686 | .0678 |
| 11 | .0686 | .0686 | 1.0974 | 1.046 | .8573 | .0686 | |
| 12 | .0686 | .0686 | 1.286 | 1.0974 | .9259 | .0686 | |
| 13 | .0686 | .0686 | 1.3375 | 1.166 | .9602 | .0686 | |
| 14 | .0686 | .0686 | 1.3889 | 1.2346 | .9945 | .0686 | |
| 15 | .0686 | .0686 | 1.2689 | 1.1831 | 1.0288 | .0686 | |
| 16 | .0686 | .0857 | 1.1831 | 1.1145 | .9945 | .0686 | .0678 |
| 17 | .1029 | .0857 | 1.0631 | 1.0974 | .9431 | .0686 | .0701 |
| 18 | .12 | .0857 | .1029 | .0686 | .0514 | | .0709 |
| 19 | .12 | .1029 | .12 | .0857 | .0686 | | .0678 |
| 20 | .1029 | .1029 | .1372 | .0857 | .0686 | .0686 | .0701 |
| 21 | .0686 | .0857 | .1543 | .0686 | .0686 | .0686 | .0701 |
| 22 | .0686 | .0857 | .12 | .0686 | .0686 | .0686 | .0701 |
| 23 | .0686 | .0686 | .1029 | .0686 | .0686 | | .0709 |
| 24 | .0671 | .0686 | .0686 | .0857 | .0686 | .0686 | .0678 |
| **Max** | **.9665** | **.8059** | **1.3889** | **1.2346** | **1.0288** | **.823** | **.6962** |
| **Min** | **.0671** | **.0686** | **.0686** | **.0343** | **.0514** | **.0686** | **.0678** |
| **Avg** | **.2866** | **.2701** | **.4558** | **.4158** | **.3608** | **.3144** | **.2572** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049]** **BU 5860**
**Substation No/ Name :- 214491 / 33/11 KV SHIRSUPHAL**
**Feeder No / Name : 206 / 11KV GARMALA SINGLE PHASING Feeder KV- 11 / OUTGOING** **SINGLE PHASING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1341 | .1715 | .1715 | .1715 | .1543 | .1543 | .2035 |
| 2 | .1006 | .1029 | .1715 | .1715 | .1543 | .1543 | .1187 |
| 3 | .1526 | .1029 | .1715 | .1886 | .1715 | .1715 | .1509 |
| 4 | .2035 | .1029 | .2058 | .2229 | .2058 | .2229 | .2035 |
| 5 | .2374 | .1715 | .2572 | .2401 | .2229 | .2401 | .2012 |
| 6 | .2713 | .2572 | .3086 | .3429 | .2915 | .2743 | .2713 |
| 7 | .4239 | .3086 | .3429 | .3429 | .2743 | .2915 | .3185 |
| 8 | .407 | .3772 | .3772 | .4115 | .2572 | .2572 | .285 |
| 9 | .3772 | .3086 | .1886 | .3258 | .2401 | .2743 | .2818 |
| 10 | .1372 | .2058 | .2572 | .2058 | .2572 | .1715 | .1658 |
| 11 | .1543 | .1715 | .3601 | .2229 | .2743 | .2058 | |
| 12 | .1715 | .1372 | .4287 | .2401 | .2915 | .2401 | |
| 13 | .1543 | .1372 | .4801 | .2743 | .3086 | .2572 | |
| 14 | .1543 | .1543 | .4115 | .3086 | .3429 | .2229 | |
| 15 | .1886 | .1543 | .3944 | .2915 | .3772 | .2058 | |
| 16 | .2058 | .1372 | .3429 | .2572 | .3086 | .1715 | .2374 |
| 17 | .2229 | .2058 | .3086 | .2401 | .2743 | .1715 | .2035 |
| 18 | .2229 | .2743 | .2058 | .2572 | .2058 | .2572 | .3189 |
| 19 | .3944 | .2743 | .2401 | .2743 | .3258 | .2915 | .3366 |
| 20 | .3258 | .2058 | .3086 | .3258 | | .2915 | .3012 |
| 21 | .2401 | .2058 | .2743 | .2915 | .2915 | .2915 | .2481 |
| 22 | .2058 | .2058 | .2058 | .1886 | .1715 | .2229 | .1753 |
| 23 | .1715 | .2058 | .2058 | .1715 | .1543 | .2058 | .1417 |
| 24 | .1509 | .1715 | .1715 | .1886 | .1715 | .1543 | .2035 |
| **Max** | **.4239** | **.3772** | **.4801** | **.4115** | **.3772** | **.2915** | **.3366** |
| **Min** | **.1006** | **.1029** | **.1715** | **.1715** | **.1543** | **.1543** | **.1187** |
| **Avg** | **.2253** | **.1979** | **.2829** | **.2565** | **.2490** | **.2251** | **.2298** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049]** **BU 5860**
**Substation No/ Name :- 214497 / 33 KV UNDAWADI (KP)**
**Feeder No / Name : 201 / 11 KV KARKHEL SINGLE PHASING Feeder KV- 11 / OUTGOING** **SINGLE PHASING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3258 | .3601 | .3429 | .3258 | .4287 | .3429 | .3429 |
| 2 | .3048 | .3506 | .3601 | .3086 | .4801 | .3429 | .2134 |
| 3 | .2896 | .381 | .3772 | .3772 | .5144 | .3601 | .2286 |
| 4 | .2743 | .4115 | | .4458 | .5658 | .3772 | .2743 |
| 5 | .4268 | .4268 | | .6687 | .6173 | .463 | .3353 |
| 6 | .6401 | .6554 | .9602 | .9602 | .9602 | .6173 | .5182 |
| 7 | 1.0059 | .9145 | 1.0974 | 1.0974 | 1.0631 | .7888 | .7773 |
| 8 | 1.0974 | .9755 | .9259 | .7545 | .8916 | .8573 | .8383 |
| 9 | 1.0974 | .945 | .6516 | | .6859 | .5316 | .823 |
| 10 | .3429 | .3944 | .6401 | .442 | .4572 | .5792 | .3772 |
| 11 | | .2915 | .8535 | .7621 | .6859 | .6554 | |
| 12 | .1886 | .2572 | .9297 | .9145 | .7316 | .7773 | |
| 13 | .2058 | .2401 | .823 | .884 | .7468 | .7621 | |
| 14 | .1715 | .2401 | .8383 | .823 | .7621 | .3963 | |
| 15 | .1886 | .2401 | .8078 | .8535 | .884 | .7164 | |
| 16 | .2058 | .2572 | .884 | .8993 | .8383 | .7468 | .3086 |
| 17 | .3429 | .3772 | .884 | .823 | .7773 | .7316 | .4801 |
| 18 | .5316 | .6516 | .6687 | .5144 | .6173 | .6859 | .6859 |
| 19 | .7888 | .823 | .6687 | .8059 | .8059 | .7373 | .7373 |
| 20 | .6859 | .6859 | .823 | .6516 | .6516 | .6687 | .6687 |
| 21 | .5487 | .5487 | .5487 | .5487 | .5487 | .5144 | .5144 |
| 22 | .5144 | .4458 | .4458 | .4801 | .4801 | .4287 | .4287 |
| 23 | .4287 | .3772 | .3429 | .3429 | .4115 | .3772 | .3601 |
| 24 | .3258 | .3258 | .3429 | .3258 | .3429 | .3601 | .3429 |
| **Max** | **1.0974** | **.9755** | **1.0974** | **1.0974** | **1.0631** | **.8573** | **.8383** |
| **Min** | **.1715** | **.2401** | **.3429** | **.3086** | **.3429** | **.3429** | **.2134** |
| **Avg** | **.4753** | **.4823** | **.6917** | **.6526** | **.6645** | **.5758** | **.4871** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049] BU 5860**
**Substation No/ Name :- 214497 / 33 KV UNDAWADI (KP)**
**Feeder No / Name : 202 / 11 KV kHARADWADI SINGLE PHASIN Feeder KV- 11 / OUTGOING SINGLE PHASING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3086 | .3086 | .2572 | .2572 | .3429 | .2572 | .2743 |
| 2 | .2896 | .3048 | .2572 | .2572 | .3944 | .2572 | .1677 |
| 3 | .2439 | .3506 | .2743 | .2743 | .4287 | .2743 | .1829 |
| 4 | .2591 | .3963 | .3601 | .3601 | .4801 | .3429 | .2286 |
| 5 | .3048 | .4725 | .5487 | .5487 | .4973 | | .3048 |
| 6 | .5792 | .5792 | .8059 | .5487 | .7888 | .823 | .4725 |
| 7 | .8078 | .7926 | .8573 | .9945 | .9431 | .8573 | .6249 |
| 8 | .8535 | .8383 | .7716 | .8059 | .8745 | .823 | .6097 |
| 9 | .7926 | .7468 | .6001 | | .6001 | .5658 | .5487 |
| 10 | .3258 | .3258 | .6097 | .5792 | .5335 | .4877 | .3258 |
| 11 | .2401 | .1715 | .7926 | .7316 | .6401 | .4877 | |
| 12 | .1372 | .1372 | .7621 | .7164 | .7316 | .4725 | |
| 13 | .1715 | .1372 | .6706 | .6859 | .7468 | .4877 | |
| 14 | .2058 | .1372 | .6401 | .6706 | .7621 | .5335 | |
| 15 | .1715 | .1543 | .6706 | .6401 | .8383 | .5182 | |
| 16 | .1886 | .1543 | .7316 | .6097 | .6859 | .4572 | .2915 |
| 17 | .2229 | .3086 | .7468 | .5639 | .6097 | .5335 | .3944 |
| 18 | .5316 | .6344 | .6173 | .463 | .5182 | .583 | .6516 |
| 19 | .8059 | .7545 | .7545 | .7202 | .703 | .6859 | .6516 |
| 20 | .6001 | .6344 | .6344 | .6001 | .6001 | .6173 | .6173 |
| 21 | .5487 | .4801 | .4801 | .4973 | .4801 | .4115 | .4287 |
| 22 | .4973 | .3944 | .3944 | .4287 | .4287 | .3429 | .3601 |
| 23 | .4115 | .3086 | .2915 | .3429 | .3429 | .3086 | .2743 |
| 24 | .3258 | .2743 | .2572 | .2572 | .2572 | .2572 | .2743 |
| **Max** | **.8535** | **.8383** | **.8573** | **.9945** | **.9431** | **.8573** | **.6516** |
| **Min** | **.1372** | **.1372** | **.2572** | **.2572** | **.2572** | **.2572** | **.1677** |
| **Avg** | **.4093** | **.4082** | **.5744** | **.5458** | **.5928** | **.4950** | **.4044** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049] BU 5860**
**Substation No/ Name :- 214497 / 33 KV UNDAWADI (KP)**
**Feeder No / Name : 203 / 11 KV UNDAWADI GFSS GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0686 | .1029 | .0914 | .0762 | .1029 | .0762 | .0762 |
| 2 | .0686 | .1372 | .0762 | .0762 | .1372 | .0857 | .0762 |
| 3 | .0686 | .1715 | .0762 | .0914 | .1543 | .0857 | .0914 |
| 4 | .0857 | .1886 | .1219 | .1067 | .1715 | .1372 | .1372 |
| 5 | .1372 | .2058 | .1829 | .1372 | .1886 | .1219 | .1829 |
| 6 | .1886 | .2743 | .2439 | .2286 | .2743 | .2439 | .2286 |
| 7 | .2743 | .3086 | .2743 | .1981 | .2743 | .2743 | .2743 |
| 8 | .1829 | .2058 | .2134 | .1981 | .2401 | .2134 | .1981 |
| 9 | .1372 | .1715 | .1981 | | .2058 | .1372 | .1829 |
| 10 | .12 | .1524 | .1372 | .1372 | .1524 | .1219 | .1677 |
| 11 | .0686 | .1067 | .0762 | .0686 | .1219 | .0914 | |
| 12 | | .0762 | .061 | .0857 | .0914 | .061 | |
| 13 | .0514 | .0762 | .061 | .0686 | .0914 | .061 | |
| 14 | .0343 | .0762 | .061 | .0514 | .0762 | .0457 | |
| 15 | .0514 | .061 | .061 | .0857 | .061 | .061 | |
| 16 | .0686 | .0762 | .061 | .0686 | .061 | .0762 | .0914 |
| 17 | .0857 | .0914 | .0762 | .1029 | .0762 | .0914 | .1067 |
| 18 | .1886 | .1524 | .1524 | .1372 | .1886 | .1524 | .1524 |
| 19 | .2743 | .1981 | .1981 | .2572 | .2286 | .2134 | .2134 |
| 20 | .2229 | .1677 | .1829 | .2058 | .1829 | .1829 | .1829 |
| 21 | .1886 | .1524 | .1524 | .1543 | .1372 | .1372 | .1372 |
| 22 | .1543 | .1219 | .1219 | .1372 | .1219 | .1067 | .1219 |
| 23 | .1029 | .1067 | .0762 | .12 | .1067 | .0914 | .0762 |
| 24 | .0686 | .0686 | .0914 | .0762 | .0857 | .0762 | .0762 |
| **Max** | **.2743** | **.3086** | **.2743** | **.2572** | **.2743** | **.2743** | **.2743** |
| **Min** | **.0343** | **.061** | **.061** | **.0514** | **.061** | **.0457** | **.0762** |
| **Avg** | **.1257** | **.1438** | **.1270** | **.1247** | **.1472** | **.1227** | **.1460** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049] BU 5860**
**Substation No/ Name :- 214497 / 33 KV UNDAWADI (KP)**
**Feeder No / Name : 204 / 11 KV SONWADI AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1715 | .2401 | .1715 | .1543 | .1715 | .1372 | .1372 |
| 2 | .1543 | .1981 | .0914 | .0914 | .1886 | .12 | .1372 |
| 3 | .1372 | .2286 | .1219 | .1219 | .2229 | .0857 | .1543 |
| 4 | .1715 | .2591 | .1677 | .1677 | .1886 | .0857 | .1715 |
| 5 | .1886 | .2286 | .2439 | .2591 | .2058 | .12 | .2058 |
| 6 | .2401 | .2743 | .381 | .381 | .2572 | .1886 | .2572 |
| 7 | .2915 | .5335 | .5182 | .5335 | .2915 | .1715 | .2401 |
| 8 | .2572 | .6249 | .6859 | .5944 | .2401 | .2058 | .1886 |
| 9 | .1886 | .6249 | .6401 | | .1886 | | .1543 |
| 10 | .3353 | .12 | .1372 | .1372 | | .2286 | .3506 |
| 11 | .5792 | .0857 | .0686 | .1029 | | .3963 | |
| 12 | .6554 | .0514 | .0857 | .0857 | | .503 | |
| 13 | .6859 | .0686 | .0686 | .0857 | .5792 | .5335 | |
| 14 | .7011 | .0686 | .0686 | .0686 | .6097 | .4877 | |
| 15 | .7164 | .0686 | .0686 | .0857 | .6401 | .4877 | |
| 16 | .7316 | .0857 | .0686 | .0514 | .5792 | .5182 | .4725 |
| 17 | .6706 | .1029 | .1029 | .1029 | .5639 | .4572 | .4268 |
| 18 | .1715 | .1715 | .1886 | .1372 | .1715 | .12 | .1543 |
| 19 | .3086 | .2572 | .2572 | .2743 | .2743 | .2058 | .2058 |
| 20 | .2058 | .2401 | .2401 | .2572 | .2572 | .1886 | .2401 |
| 21 | .2743 | .2058 | .2058 | .1886 | .1886 | .1715 | .1715 |
| 22 | .2401 | .2058 | .1886 | .1715 | .1715 | .1543 | .1543 |
| 23 | .2572 | .1886 | .1715 | .1886 | .1715 | .1543 | |
| 24 | .1715 | .2058 | .1715 | .1543 | .1543 | .1543 | .1543 |
| **Max** | **.7316** | **.6249** | **.6859** | **.5944** | **.6401** | **.5335** | **.4725** |
| **Min** | **.1372** | **.0514** | **.0686** | **.0514** | **.1543** | **.0857** | **.1372** |
| **Avg** | **.3544** | **.2224** | **.2131** | **.1911** | **.3008** | **.2555** | **.2209** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049] BU 5860**
**Substation No/ Name :- 214497 / 33 KV UNDAWADI (KP)**
**Feeder No / Name : 205 / 11 KV SABALEWADI SINGLE PHASIN Feeder KV- 11 / OUTGOING SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2915 | .3429 | .2915 | .2915 | .3258 | .2572 | .2915 |
| 2 | .2743 | .3772 | .3086 | .3086 | .3429 | .3048 | .2743 |
| 3 | .2743 | .3944 | .3086 | .3258 | .3772 | .4115 | .3048 |
| 4 | .2591 | .3601 | .3258 | .3601 | .3086 | .5335 | .3506 |
| 5 | .3048 | .3429 | .3601 | .3506 | .3601 | .6859 | .3963 |
| 6 | .381 | .3772 | .3944 | .3944 | .4115 | .9907 | .503 |
| 7 | .4115 | .4458 | .3944 | .3429 | .463 | 1.0517 | .823 |
| 8 | .4268 | .3601 | .3429 | .3601 | .4115 | 1.0669 | 1.0059 |
| 9 | .3048 | .3258 | .2915 | | .3258 | .9602 | |
| 10 | .2572 | .7621 | .7926 | .6859 | .5335 | .2229 | .2572 |
| 11 | | 1.1431 | 1.2498 | 1.1126 | .6859 | .2058 | |
| 12 | | 1.6004 | 1.5089 | 1.0669 | 1.1888 | .1715 | |
| 13 | .1715 | 1.6156 | 1.5546 | 1.1431 | 1.2193 | .1715 | |
| 14 | .1886 | 1.6309 | 1.5851 | 1.2041 | 1.2955 | .1543 | |
| 15 | .2058 | 1.0974 | 1.448 | 1.1888 | 1.1431 | .1372 | |
| 16 | .2401 | 1.5394 | 1.3413 | 1.1736 | 1.0364 | .1372 | .1886 |
| 17 | .2572 | 1.448 | 1.2498 | 1.1431 | .9602 | .1886 | .2229 |
| 18 | .3429 | .2401 | .2572 | .2401 | .2572 | .3429 | .3429 |
| 19 | .4801 | .4115 | .4115 | .3772 | .3772 | .3944 | .3944 |
| 20 | .4458 | .3772 | .3772 | .3601 | .3601 | .3772 | .3772 |
| 21 | .4287 | .3258 | .3258 | .3429 | .3429 | .3601 | .3601 |
| 22 | .3772 | .3086 | .3086 | .3258 | .3258 | .3258 | .3258 |
| 23 | .3429 | .2915 | .3086 | .2915 | .3086 | .3086 | .2915 |
| 24 | .3086 | .3086 | .2743 | .3086 | .3086 | .2743 | .2915 |
| **Max** | **.4801** | **1.6309** | **1.5851** | **1.2041** | **1.2955** | **1.0669** | **1.0059** |
| **Min** | **.1715** | **.2401** | **.2572** | **.2401** | **.2572** | **.1372** | **.1886** |
| **Avg** | **.3170** | **.6844** | **.6671** | **.5956** | **.5696** | **.4181** | **.3890** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049] BU 5860**
**Substation No/ Name :- 214497 / 33 KV UNDAWADI (KP)**
**Feeder No / Name : 206 / 11 KV JARADWADI SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0686 | .1029 | .0857 | .0686 | .0686 | .0514 | .0686 |
| 2 | .0686 | .1219 | .2286 | .2286 | .0857 | .0514 | .0686 |
| 3 | .0686 | .1677 | .2286 | .2286 | .1029 | .0686 | .0686 |
| 4 | .0857 | .1981 | .2743 | .2591 | .0514 | .0857 | .0857 |
| 5 | .12 | .2286 | .3201 | .3201 | .0686 | .12 | .1029 |
| 6 | .1543 | .2743 | .4115 | .4268 | .1372 | .1372 | .12 |
| 7 | .1715 | .6097 | .6249 | .6249 | .1372 | .1372 | .1715 |
| 8 | .1372 | .7773 | .8993 | .8993 | .1372 | .1543 | .1715 |
| 9 | .12 | .8383 | .7926 | | .12 | .1372 | .1543 |
| 10 | .4877 | .1029 | .1067 | .12 | .4725 | .4725 | .3201 |
| 11 | .5639 | .0857 | .1029 | .1029 | .7621 | .6097 | |
| 12 | .7468 | .0857 | .0857 | .0686 | .8993 | .6554 | |
| 13 | .7621 | .0857 | .1029 | .0686 | .9145 | .7316 | |
| 14 | .7621 | .0857 | .0857 | .0857 | .945 | .7468 | |
| 15 | .7926 | .0857 | .0857 | .0514 | .9907 | .7316 | |
| 16 | .823 | .12 | .0857 | .0857 | .8383 | .6249 | .4572 |
| 17 | .7316 | .12 | .12 | .0857 | .823 | .6097 | .6859 |
| 18 | .1029 | .1372 | .12 | .1029 | .1067 | .1372 | .1543 |
| 19 | .12 | .1372 | .1372 | .1372 | .1372 | .1372 | .1372 |
| 20 | .1029 | .12 | .12 | .1029 | .1029 | .12 | .12 |
| 21 | .0857 | .1029 | .1029 | .0857 | .0857 | .1029 | .1029 |
| 22 | .1029 | .0857 | .0857 | .0686 | .0686 | .0857 | .0686 |
| 23 | .12 | .0857 | .0686 | .0857 | .0514 | .0686 | .0686 |
| 24 | .0686 | .0686 | .0857 | .0686 | .0514 | .0514 | .0686 |
| **Max** | **.823** | **.8383** | **.8993** | **.8993** | **.9907** | **.7468** | **.6859** |
| **Min** | **.0686** | **.0686** | **.0686** | **.0514** | **.0514** | **.0514** | **.0686** |
| **Avg** | **.3070** | **.2011** | **.2234** | **.1903** | **.3399** | **.2845** | **.1682** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049]** **BU 5860**
**Substation No/ Name :- 214500 / 33/11 KV MEKHALI**
**Feeder No / Name : 201 / 11 KV MEKHALI GFSS** **GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | .5975 | .5487 | .6516 | .5144 | .5144 |
| 2 | .5415 | .5228 | .6161 | .5144 | .5658 | .5487 | .5658 |
| 3 | | .5601 | .6348 | .5144 | .5487 | .5658 | .6516 |
| 4 | .5601 | .7095 | .6348 | .5658 | .5487 | .6173 | .7202 |
| 5 | | .7842 | .6722 | .6173 | .583 | .6516 | .7545 |
| 6 | .5975 | .8589 | .7095 | .6859 | .6516 | .7545 | |
| 7 | | .9335 | .7468 | .7888 | .7716 | .823 | |
| 8 | .6161 | .7842 | .7655 | .703 | .6859 | .7202 | |
| 9 | | .6161 | | .583 | .583 | .5658 | .5228 |
| 10 | .5601 | .5228 | .4801 | .4801 | .4801 | .5316 | .4481 |
| 11 | .4481 | .5228 | .4458 | .4671 | .463 | .3944 | .4108 |
| 12 | .4108 | .5041 | .4115 | .4115 | .4115 | .3772 | .3734 |
| 13 | .3734 | .5041 | .3944 | .3944 | .3772 | .3429 | .3361 |
| 14 | .3361 | .5281 | .3772 | .3429 | .3429 | .3601 | .3547 |
| 15 | .3547 | .5228 | .3601 | .3772 | .3429 | .3772 | .3734 |
| 16 | .4668 | .5281 | .3944 | .4115 | .3944 | .3772 | .4108 |
| 17 | .4668 | .5093 | .4801 | .4801 | .4458 | .463 | |
| 18 | .6722 | .6535 | .6001 | .5658 | .5316 | .6344 | .6535 |
| 19 | .8775 | .7468 | .7545 | .7716 | .6687 | .6859 | .7468 |
| 20 | .6348 | .8029 | .6859 | .823 | .7202 | .7373 | .8402 |
| 21 | .5975 | .6535 | .6687 | .7888 | .6173 | .6859 | .7468 |
| 22 | .5788 | .5415 | .6516 | .7545 | .583 | .5487 | .7095 |
| 23 | .5601 | .5601 | .6173 | .7202 | .5658 | .5144 | .5601 |
| 24 | | .4481 | | .6001 | .6859 | .5487 | .4973 |
| **Max** | **.8775** | **.9335** | **.7655** | **.823** | **.7716** | **.823** | **.8402** |
| **Min** | **.3361** | **.4481** | **.3601** | **.3429** | **.3429** | **.3429** | **.3361** |
| **Avg** | **.5363** | **.6225** | **.5772** | **.5796** | **.5508** | **.5558** | **.5595** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049] BU 5860**
**Substation No/ Name :- 214500 / 33/11 KV MEKHALI**
**Feeder No / Name : 203 / 11 KV SONGAON AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .2427 | .2241 | .1886 | .2572 | .2058 | .2058 |
| 2 | 2.0538 | 1.7737 | .2241 | .1886 | .2401 | 1.7833 | 1.2346 |
| 3 | | 1.8671 | .2614 | .2058 | .2229 | 1.8519 | 1.3032 |
| 4 | 2.1658 | 1.9418 | .2801 | .2058 | .2572 | 1.8861 | 1.3717 |
| 5 | | 1.9791 | .2801 | .2401 | .2743 | 1.9204 | 1.406 |
| 6 | 2.2405 | 2.0351 | .2801 | .2743 | .3086 | 1.9547 | |
| 7 | | 2.0725 | .2987 | .3429 | .3601 | 1.989 | |
| 8 | 2.3152 | 2.2405 | .2987 | .3258 | .3429 | 2.0576 | 1.8671 |
| 9 | | 1.8484 | .2229 | .2572 | .2572 | 2.1605 | 2.0725 |
| 10 | .1307 | .1867 | 1.6289 | 1.9547 | 1.9719 | .1886 | .1307 |
| 11 | .1494 | .168 | 1.9547 | 2.4177 | 2.3491 | .1372 | .112 |
| 12 | .1307 | .168 | 2.3663 | 2.4006 | 2.4006 | .12 | .112 |
| 13 | .112 | .168 | 2.4006 | 2.4006 | 2.4691 | .12 | .112 |
| 14 | .0934 | .1698 | 2.4348 | 2.5377 | 2.572 | .1029 | |
| 15 | .1307 | .1867 | 2.4177 | 2.5034 | 2.5034 | .1029 | .1307 |
| 16 | .1307 | .1867 | 2.4177 | 2.5377 | 2.4006 | .12 | .1494 |
| 17 | .1494 | .168 | 2.4006 | 2.3834 | 2.2291 | .1886 | .168 |
| 18 | .2614 | .2241 | .2743 | .2572 | .2401 | .2572 | .168 |
| 19 | .3174 | .2614 | .3258 | .3429 | .3086 | .2572 | |
| 20 | .2801 | .2987 | .3086 | .3601 | .3429 | .2743 | .2801 |
| 21 | .2614 | .2829 | .2743 | .3429 | .2743 | .2743 | .2241 |
| 22 | .2614 | .2641 | .2401 | .3086 | .2572 | .2572 | .2054 |
| 23 | .2427 | .2241 | .2229 | .2743 | .2401 | .2401 | .1867 |
| 24 | | .2614 | | .2058 | .2743 | .2229 | .2229 |
| **Max** | **2.3152** | **2.2405** | **2.4348** | **2.5377** | **2.572** | **2.1605** | **2.0725** |
| **Min** | **.0934** | **.168** | **.2229** | **.1886** | **.2229** | **.1029** | **.112** |
| **Avg** | **.6348** | **.8008** | **.9582** | **.9774** | **.9731** | **.7780** | **.5831** |

 Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049]** **BU 5860**
**Substation No/ Name :- 214500 / 33/11 KV MEKHALI**
**Feeder No / Name : 204 / 11 KV NIRAWAGAJ GFSS** **GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .3174 | .2614 | .2747 | .3086 | .2743 | .2743 |
| 2 | .2427 | .3361 | .2614 | .2572 | .2743 | .2572 | .2572 |
| 3 | | .3734 | .2987 | .2401 | .2572 | .2401 | .3086 |
| 4 | .2801 | .3921 | .3361 | .3086 | .3086 | .3086 | .4458 |
| 5 | | .4108 | .3734 | .3429 | .3772 | .3429 | .5144 |
| 6 | .3206 | .4854 | .4108 | .4458 | .4801 | .4287 | |
| 7 | | .6161 | .4481 | .5144 | .5487 | .5144 | |
| 8 | .3174 | .4294 | .5041 | .4801 | .5144 | .463 | |
| 9 | | .2614 | .3258 | .3258 | .4115 | .3086 | .3361 |
| 10 | .2801 | .2263 | .2743 | .2743 | .3258 | .2572 | .2427 |
| 11 | .2241 | .2054 | .2229 | .2401 | .2058 | .2229 | .2054 |
| 12 | .1867 | .2054 | .1715 | .1372 | .1886 | .2058 | .1867 |
| 13 | .168 | .2054 | .1715 | .1372 | .1715 | .1886 | .168 |
| 14 | .1867 | .2241 | .1543 | .1715 | .1886 | .1715 | |
| 15 | .2054 | .2241 | .1715 | .1715 | .1886 | .1715 | .112 |
| 16 | .2241 | .2241 | .1886 | | .2401 | .1715 | .1867 |
| 17 | .2614 | .2427 | .3429 | .2743 | .2572 | .2572 | .2801 |
| 18 | .3547 | .2987 | .3772 | .3772 | .3086 | .3601 | |
| 19 | .4854 | .3547 | .4115 | .4801 | .3429 | .3944 | .3361 |
| 20 | .3734 | .4481 | .4287 | .4458 | .3944 | .4115 | .4294 |
| 21 | .3361 | .3361 | .3772 | .4287 | .3258 | .3772 | .3734 |
| 22 | .2614 | | .3601 | .4115 | .3086 | .3429 | .2987 |
| 23 | .2614 | .2987 | .3429 | .3772 | .2743 | .3086 | .2987 |
| 24 | | .2801 | | .3086 | .3429 | .2915 | .2915 |
| **Max** | **.4854** | **.6161** | **.5041** | **.5144** | **.5487** | **.5144** | **.5144** |
| **Min** | **.168** | **.2054** | **.1543** | **.1372** | **.1715** | **.1715** | **.112** |
| **Avg** | **.2761** | **.3216** | **.3137** | **.3228** | **.3143** | **.3029** | **.2919** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049] BU 5860**
**Substation No/ Name :- 214500 / 33/11 KV MEKHALI**
**Feeder No / Name : 205 / 11 KV ZARGADWADI AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .2241 | .2987 | .309 | .2915 | .2743 | .2401 |
| 2 | 2.4272 | 2.0538 | .2987 | .2743 | .2743 | 1.9547 | 1.0288 |
| 3 | | 2.2405 | .2987 | .2572 | .2572 | 2.0576 | 1.0974 |
| 4 | 2.5766 | 2.4272 | .3174 | .3086 | .3086 | 2.1605 | 1.166 |
| 5 | | 2.4646 | .3361 | .3944 | .3772 | | 1.2003 |
| 6 | 2.6886 | 2.4832 | .3734 | .4801 | .5144 | 2.3663 | |
| 7 | | 2.4832 | .4108 | .5487 | .5658 | 2.4006 | |
| 8 | | 2.7073 | .4668 | .5144 | .5144 | 2.4348 | |
| 9 | | 2.4086 | .3772 | .3944 | .3944 | 2.6063 | |
| 10 | .2427 | .2801 | 2.0919 | 2.0748 | 2.2462 | .2229 | .0934 |
| 11 | .2241 | .2614 | 2.2462 | 2.7092 | 2.1262 | .1886 | |
| 12 | .2054 | .2614 | 2.8635 | 2.7778 | 2.2291 | .1372 | .056 |
| 13 | .1867 | .2641 | 2.8807 | 2.8807 | 2.3663 | .1372 | |
| 14 | .1494 | .2427 | 2.8464 | 2.9321 | 2.5206 | .1029 | .0747 |
| 15 | .168 | .2427 | 2.8292 | 2.915 | 2.4691 | .12 | |
| 16 | .1867 | .2427 | 2.7949 | 2.6749 | 2.3663 | .12 | .0747 |
| 17 | .2241 | .2241 | 2.572 | 2.4177 | 2.1262 | .1715 | |
| 18 | .3361 | .2987 | .3429 | .3601 | .2915 | .1543 | .2172 |
| 19 | .4668 | .3361 | .4458 | .4115 | .4115 | .3086 | |
| 20 | .4294 | .4108 | .4287 | .3944 | .4287 | .3429 | .3734 |
| 21 | .4108 | .3734 | .3944 | .3772 | .3772 | .3772 | |
| 22 | .3547 | .3361 | .3772 | .3601 | .3429 | .3086 | .3174 |
| 23 | .3361 | .2987 | .3429 | .3429 | .3258 | .2743 | .2987 |
| 24 | | .2427 | | .3258 | .3086 | .3086 | .2572 |
| **Max** | **2.6886** | **2.7073** | **2.8807** | **2.9321** | **2.5206** | **2.6063** | **1.2003** |
| **Min** | **.1494** | **.2241** | **.2987** | **.2572** | **.2572** | **.1029** | **.056** |
| **Avg** | **.6831** | **.9920** | **1.1580** | **1.1431** | **1.0181** | **.8491** | **.4640** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049]** **BU 5860**
**Substation No/ Name :- 214528 / 33/11 KV LONI BHAPKAR SSTN**
**Feeder No / Name : 201 / 11KV LONI FEEDER** **SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2587 | .2829 | .2801 | .2294 | .3142 | .3174 | .3292 |
| 2 | .2587 | .2829 | .3277 | .3277 | .394 | .3174 | .2926 |
| 3 | .2926 | .3018 | .3605 | .426 | .4656 | .3174 | .2561 |
| 4 | .4344 | .3395 | .4752 | .5243 | .5609 | .3921 | .2926 |
| 5 | .5373 | .5658 | .6226 | .7865 | .7186 | .5415 | .3292 |
| 6 | .6447 | .7655 | .7209 | .852 | .929 | .6535 | .5121 |
| 7 | .703 | .8589 | .9995 | .9831 | 1.166 | .7282 | .7682 |
| 8 | .6447 | .6908 | 1.2452 | 1.1065 | 1.3056 | .6722 | .7316 |
| 9 | .5304 | .5228 | 1.0486 | 1.0898 | 1.2346 | .5487 | .5121 |
| 10 | .5304 | .7209 | .3658 | .3475 | .3734 | .8718 | .7011 |
| 11 | .9945 | 1.0322 | .3292 | .3326 | .3734 | 1.0898 | 1.046 |
| 12 | 1.1603 | 1.1797 | .3292 | .3326 | .3361 | 1.2071 | 1.1191 |
| 13 | 1.1961 | 1.3599 | .3109 | .2772 | .2987 | 1.2407 | 1.0802 |
| 14 | 1.1768 | 1.3108 | .2926 | .2402 | .2614 | 1.3413 | 1.0288 |
| 15 | .8785 | 1.2452 | .2561 | .3292 | .2987 | 1.2407 | .9602 |
| 16 | 1.094 | 1.1469 | .2926 | .2957 | .2987 | 1.2407 | 1.0631 |
| 17 | 1.0774 | 1.065 | .3292 | .3326 | .3361 | 1.2407 | |
| 18 | | .4344 | .4755 | .4835 | .4854 | .439 | .4706 |
| 19 | .6161 | .6348 | .6219 | .6859 | .8962 | .6219 | .6626 |
| 20 | .5601 | .5788 | .5487 | .6268 | .7655 | .6584 | .543 |
| 21 | .5415 | .5228 | .5121 | .4207 | .6348 | .5853 | .4572 |
| 22 | .3772 | .3547 | .3292 | | .4854 | .4755 | .3841 |
| 23 | .3584 | .3361 | .3292 | .3658 | .4108 | .439 | .3142 |
| 24 | .2772 | .3018 | .3174 | .2622 | .3142 | .3361 | .3658 |
| **Max** | **1.1961** | **1.3599** | **1.2452** | **1.1065** | **1.3056** | **1.3413** | **1.1191** |
| **Min** | **.2587** | **.2829** | **.2561** | **.2294** | **.2614** | **.3174** | **.2561** |
| **Avg** | **.6584** | **.7015** | **.4883** | **.5069** | **.5691** | **.7299** | **.6182** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049] BU 5860**
**Substation No/ Name :- 214528 / 33/11 KV LONI BHAPKAR SSTN**
**Feeder No / Name : 203 / 11 KV PALSHI FEEDER SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2957 | .2641 | .2987 | .2561 | .2957 | .2987 | .2926 |
| 2 | .2033 | .2058 | .2987 | .2561 | .2957 | .2949 | .3018 |
| 3 | .2561 | .373 | .2987 | .2926 | .3326 | .2949 | .3018 |
| 4 | .3801 | .4748 | .3734 | .3292 | .3658 | .3605 | .4024 |
| 5 | .5373 | .5426 | .5041 | .439 | .5014 | .5735 | .6036 |
| 6 | .7888 | .8987 | .5975 | .5121 | .5731 | .7701 | .9054 |
| 7 | .9088 | 1.0852 | .7095 | .6767 | .6859 | 1.065 | 1.1065 |
| 8 | .9835 | 1.2209 | .5788 | .503 | .5552 | 1.1305 | 1.0562 |
| 9 | .8745 | 1.0486 | .3547 | .3688 | .3142 | .8886 | 1.0288 |
| 10 | .2801 | .2241 | 1.0974 | .9313 | .8029 | .1829 | .1848 |
| 11 | .1867 | .2427 | 1.3169 | 1.2174 | 1.2452 | .128 | .1294 |
| 12 | .1494 | .168 | 1.4632 | 1.3735 | 1.3435 | .1463 | .112 |
| 13 | .1294 | .1307 | 1.5729 | 1.442 | 1.4419 | .128 | .0747 |
| 14 | .1097 | .0983 | 1.5181 | 1.3413 | 1.4255 | .128 | .0934 |
| 15 | .1097 | .1307 | 1.5181 | 1.358 | 1.3435 | .1463 | .0943 |
| 16 | .112 | .1307 | 1.4632 | 1.5123 | 1.278 | .1646 | .1294 |
| 17 | .1867 | .1307 | 1.4449 | 1.2003 | .9995 | .1646 | .1307 |
| 18 | .3361 | .2614 | .3292 | .3109 | .2801 | .2926 | .3109 |
| 19 | .5228 | .5041 | .5304 | .5014 | .5228 | .5121 | .4706 |
| 20 | .4854 | .4854 | .4755 | .4344 | .4294 | .5853 | .4024 |
| 21 | .4108 | .4294 | .3658 | .4024 | .3921 | .5487 | .3475 |
| 22 | .3772 | .3547 | .3292 | .3475 | .3547 | .439 | .3142 |
| 23 | .3206 | .3174 | .3292 | .3142 | .3361 | .3292 | .2772 |
| 24 | .3142 | .2829 | .2987 | .2743 | .2957 | .2987 | .2926 |
| **Max** | **.9835** | **1.2209** | **1.5729** | **1.5123** | **1.4419** | **1.1305** | **1.1065** |
| **Min** | **.1097** | **.0983** | **.2987** | **.2561** | **.2801** | **.128** | **.0747** |
| **Avg** | **.3858** | **.4169** | **.7528** | **.6915** | **.6838** | **.4113** | **.3901** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049] BU 5860**
**Substation No/ Name :- 214528 / 33/11 KV LONI BHAPKAR SSTN**
**Feeder No / Name : 204 / 11KV KARHATI FEEDER SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2402 | .2452 | .2427 | .2926 | .2402 | .2614 | .2926 |
| 2 | .2402 | .2452 | .6062 | .3932 | .7712 | .2614 | .2561 |
| 3 | .2402 | .2641 | .8029 | .4588 | .7888 | .2801 | .2561 |
| 4 | .394 | .3018 | .9012 | .5243 | .8413 | .3921 | .3292 |
| 5 | .567 | .6036 | 1.0978 | .7865 | .964 | .5415 | .5121 |
| 6 | .6447 | .7655 | 1.2452 | .9831 | 1.2003 | .6535 | .6219 |
| 7 | .7164 | .7655 | 1.3599 | 1.2452 | 1.3226 | .7842 | .7316 |
| 8 | .6447 | .6161 | 1.4255 | 1.5089 | 1.5089 | .4668 | .6584 |
| 9 | .4024 | .5041 | 1.4419 | 1.4419 | 1.326 | .4191 | |
| 10 | .9116 | .9831 | .2926 | .2772 | .2987 | 1.1736 | 1.1488 |
| 11 | 1.1469 | 1.278 | .2561 | .2772 | .2614 | 1.4754 | 1.4582 |
| 12 | 1.2125 | 1.3599 | .2561 | .2402 | .2427 | 1.4083 | 1.5238 |
| 13 | 1.2289 | 1.5074 | .2378 | .2218 | .2427 | 1.3748 | 1.4746 |
| 14 | 1.4746 | 1.4746 | .2378 | .2402 | .2241 | 1.3413 | 1.4918 |
| 15 | 1.5565 | 1.4255 | .2378 | .2587 | .2427 | 1.576 | 1.3375 |
| 16 | 1.3592 | 1.5238 | .2195 | .2957 | .2614 | 1.5424 | 1.3904 |
| 17 | 1.1271 | 1.5238 | .2195 | .2772 | .2801 | 1.6827 | 1.1831 |
| 18 | .4668 | .4854 | .2561 | .4163 | .4294 | .3841 | .5068 |
| 19 | .5415 | .7468 | .7133 | .6268 | .5975 | .6219 | .6447 |
| 20 | .5601 | .6348 | .6401 | .5487 | .5601 | .5853 | .5249 |
| 21 | .5415 | .5228 | .5487 | .4938 | .4854 | .5487 | .4572 |
| 22 | .415 | .3361 | .439 | .3658 | .3734 | .5121 | .3658 |
| 23 | .3395 | .2987 | .3658 | .2587 | .2987 | .3292 | .2772 |
| 24 | .2587 | .2829 | .2427 | .3292 | .2402 | .2614 | .2926 |
| **Max** | **1.5565** | **1.5238** | **1.4419** | **1.5089** | **1.5089** | **1.6827** | **1.5238** |
| **Min** | **.2402** | **.2452** | **.2195** | **.2218** | **.2241** | **.2614** | **.2561** |
| **Avg** | **.7179** | **.7789** | **.5953** | **.5318** | **.5834** | **.7866** | **.7711** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049] BU 5860**
**Substation No/ Name :- 214542 / 33/11 KV BARAV NAGAR SUBSTATIO**
**Feeder No / Name : 201 / 11 KV SHIVGIRI FEEDER SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2075 | .2058 | .3206 | .2263 | .2012 | .2075 | .2263 |
| 2 | .3401 | .4115 | .3206 | .2263 | .2195 | .4024 | .3725 |
| 3 | .4481 | .4115 | .3772 | .2263 | .2195 | .4024 | .3887 |
| 4 | .4024 | .4458 | .415 | .2641 | .2561 | .4287 | .3887 |
| 5 | .4024 | .4458 | .4715 | .3395 | .3292 | .503 | .4144 |
| 6 | .4915 | .5144 | .4715 | .4715 | .4755 | .5868 | .4807 |
| 7 | .5735 | | .5093 | .5281 | .5041 | .5735 | .6062 |
| 8 | .6241 | .7202 | .415 | .3772 | .4755 | .6874 | .6327 |
| 9 | .5079 | .6859 | .2452 | .2829 | .3361 | .6093 | .6722 |
| 10 | .2058 | .1867 | .5624 | .6802 | .7099 | .1509 | .2054 |
| 11 | .2058 | .1494 | .8179 | .8745 | .8025 | .1698 | .168 |
| 12 | .1029 | .128 | .8173 | .8907 | .7926 | .132 | .1307 |
| 13 | | .1097 | .8333 | .8583 | .7526 | .1307 | .1307 |
| 14 | .12 | .1307 | .8488 | .8097 | .7926 | .1132 | .1307 |
| 15 | .1372 | .1494 | .828 | .7773 | .7926 | .128 | .1463 |
| 16 | .1867 | .1848 | .8436 | .6478 | .7827 | .1629 | .1646 |
| 17 | .1715 | .2033 | .8069 | .6478 | .7676 | .2218 | .1646 |
| 18 | .2743 | | .3292 | .3475 | .2772 | .3142 | .2743 |
| 19 | .4115 | .4715 | .415 | .4207 | .3395 | .4294 | .4294 |
| 20 | .3772 | .3961 | .3772 | .3841 | .3961 | .3961 | .3921 |
| 21 | .3086 | .3395 | .3395 | .2926 | .3206 | .3206 | .3174 |
| 22 | .2401 | .2641 | | .2561 | .2263 | .2641 | .2801 |
| 23 | .1886 | .2263 | .2263 | .2012 | .2263 | .2328 | .2241 |
| 24 | .2075 | .1886 | .2075 | .2263 | .2012 | .2075 | .2263 |
| **Max** | **.6241** | **.7202** | **.8488** | **.8907** | **.8025** | **.6874** | **.6722** |
| **Min** | **.1029** | **.1097** | **.2075** | **.2012** | **.2012** | **.1132** | **.1307** |
| **Avg** | **.3102** | **.3168** | **.5130** | **.4690** | **.4665** | **.3240** | **.3153** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049]** **BU 5860**
**Substation No/ Name :- 214542 / 33/11 KV BARAV NAGAR SUBSTATIO**
**Feeder No / Name : 202 / 11 KV DAM FEEDER( SANGAVI PANI Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0037 | .0171 | .0152 | .0037 | .0189 | .0152 | .0037 |
| 2 | .0037 | .0171 | .0152 | .0037 | .0189 | .0152 | .0037 |
| 3 | .0037 | .0171 | .0152 | .0037 | .0189 | .0152 | .0037 |
| 4 | .0237 | .024 | .0152 | .0037 | .0189 | .0152 | .0218 |
| 5 | .0237 | .024 | .0305 | .024 | .037 | .0152 | .0223 |
| 6 | .0661 | .024 | .0305 | .0243 | .0732 | .061 | .0625 |
| 7 | .0602 | | .061 | .0648 | .0732 | .061 | .0594 |
| 8 | .0617 | .072 | .061 | .0625 | .0732 | .061 | .0601 |
| 9 | .0432 | .0686 | .061 | .0632 | .061 | .0152 | .0624 |
| 10 | .0703 | .061 | .0602 | .0549 | .061 | .0617 | .0732 |
| 11 | .0686 | .061 | .052 | .0549 | .061 | .05 | .0732 |
| 12 | .0514 | .061 | .0406 | .0549 | .061 | .0547 | .0732 |
| 13 | | .0457 | .0409 | .0549 | .0457 | .0421 | .0549 |
| 14 | .0514 | .0457 | .0409 | .0549 | .0457 | .0427 | .0549 |
| 15 | .0343 | .0457 | .0475 | .0549 | .0457 | .0427 | .0549 |
| 16 | .0343 | .0305 | .0244 | .0549 | .0457 | .0425 | .0549 |
| 17 | .0343 | .0305 | .0398 | .0549 | .0305 | .0409 | .0366 |
| 18 | .0343 | .0152 | .0211 | .0366 | .0152 | .0282 | .0366 |
| 19 | .0171 | .0152 | .0037 | .0183 | .0152 | | .0189 |
| 20 | .0171 | .0152 | .0036 | .0183 | .0152 | .0035 | .0189 |
| 21 | .0171 | .0152 | .0036 | .0183 | .0152 | .0036 | .0189 |
| 22 | .0171 | .0152 | | .0189 | .0152 | .0034 | .0189 |
| 23 | .0171 | .0152 | .0037 | .0187 | .0152 | .0032 | .0189 |
| 24 | .0036 | .0171 | .0152 | .0037 | .0189 | .0152 | .0037 |
| **Max** | **.0703** | **.072** | **.061** | **.0648** | **.0732** | **.0617** | **.0732** |
| **Min** | **.0036** | **.0152** | **.0036** | **.0037** | **.0152** | **.0032** | **.0037** |
| **Avg** | **.0329** | **.0328** | **.0305** | **.0344** | **.0375** | **.0308** | **.0379** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (R)[049] BU 5860**
**Substation No/ Name :- 214542 / 33/11 KV BARAV NAGAR SUBSTATIO**
**Feeder No / Name : 203 / 11 KV BHIKOBA NAGAR FEEDER SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3206 | .2743 | .3206 | .3018 | .3361 | .3395 | .3395 |
| 2 | .5468 | .6001 | .3206 | .2829 | .3361 | .7316 | .5937 |
| 3 | .5851 | .6516 | .3772 | .3018 | .3547 | .6783 | .6642 |
| 4 | .6478 | .6516 | .4715 | .415 | .3921 | .7042 | .6882 |
| 5 | .7125 | .7202 | .6036 | .547 | .5228 | .7545 | .7373 |
| 6 | .8421 | .823 | .6979 | .7356 | .7282 | .8886 | .8453 |
| 7 | .9393 | | .7356 | .8488 | .7842 | 1.1233 | .9555 |
| 8 | 1.0437 | 1.1488 | .6036 | .7167 | .8029 | 1.1873 | 1.0936 |
| 9 | .9922 | 1.2003 | .415 | .3921 | .5093 | 1.1248 | 1.085 |
| 10 | .3429 | .3361 | 1.012 | 1.0364 | 1.1111 | .3361 | .3361 |
| 11 | .2743 | .3174 | 1.2651 | 1.3279 | 1.3272 | .3174 | .2987 |
| 12 | .2401 | .2743 | 1.2955 | 1.3441 | 1.3272 | .2587 | .2987 |
| 13 | | .2195 | 1.3592 | 1.3927 | 1.2803 | .2743 | .2987 |
| 14 | .1715 | .2303 | 1.2967 | 1.3279 | 1.2955 | .2772 | .2926 |
| 15 | .2058 | .2481 | 1.2029 | 1.2631 | 1.3108 | .2743 | .2926 |
| 16 | .2401 | .3077 | 1.2967 | 1.1012 | 1.1888 | .2715 | .2926 |
| 17 | .3772 | .362 | 1.189 | 1.1336 | 1.1443 | .3696 | .2926 |
| 18 | .4458 | .4668 | .4805 | .4887 | .5041 | .499 | .4435 |
| 19 | .583 | .6908 | .5847 | .5611 | .5281 | .5847 | .5975 |
| 20 | .5487 | .5658 | .5281 | .5415 | .6036 | .547 | .5415 |
| 21 | .4458 | .4904 | .4527 | .4854 | .5093 | .4904 | .5041 |
| 22 | .3429 | .3584 | | .4294 | .4338 | .3961 | .3921 |
| 23 | .3086 | .3206 | .3395 | .3547 | .3584 | .3584 | .3361 |
| 24 | .3206 | .3086 | .3206 | .3018 | .3361 | .3395 | .3395 |
| **Max** | **1.0437** | **1.2003** | **1.3592** | **1.3927** | **1.3272** | **1.1873** | **1.0936** |
| **Min** | **.1715** | **.2195** | **.3206** | **.2829** | **.3361** | **.2587** | **.2926** |
| **Avg** | **.4990** | **.5029** | **.7465** | **.7346** | **.7510** | **.5469** | **.5233** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (U)[048]** **BU 5851**
**Substation No/ Name :- 214414 / 33/11 KV MIDC No. I BARAMATI**
**Feeder No / Name : 201 / Paras -MIDC- Feeder KV- 11 / OUTGOING** **SHEDDABLE FEEDER HAVING WEEKLY STAGGERING (MIDC, EQUIVALENT)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2452 | .2477 | .1715 | .2263 | .2452 | .2286 | .3584 |
| 2 | .2452 | .2286 | .1905 | .2263 | .2263 | .2477 | .3584 |
| 3 | .2452 | .2286 | .2096 | .2452 | .2263 | .2667 | .3772 |
| 4 | .2641 | .2286 | .2286 | .2452 | .2452 | .2858 | .3772 |
| 5 | .2641 | .2667 | .2477 | .2452 | .2452 | .3239 | .3961 |
| 6 | .2641 | .2667 | .2096 | .2263 | .2452 | .3048 | .3961 |
| 7 | .3018 | .2858 | .2286 | .2263 | .2829 | .3048 | .3772 |
| 8 | .2641 | .3048 | .2477 | .2641 | .2829 | .3048 | .3961 |
| 9 | .3772 | .3429 | .3429 | .2829 | .3239 | .4572 | .4904 |
| 10 | .381 | .2096 | .3772 | .5144 | .4001 | .5281 | .5601 |
| 11 | .381 | .2096 | .3961 | .5335 | .362 | .5093 | .5975 |
| 12 | .3429 | .2286 | .5281 | .4763 | .4001 | .547 | .6348 |
| 13 | .3429 | .2286 | .3772 | .3048 | .362 | .415 | .4854 |
| 14 | .381 | .2477 | .4527 | .4763 | .3429 | .4715 | .5975 |
| 15 | .381 | .2858 | .4715 | .5906 | .381 | .4527 | .5601 |
| 16 | .381 | .2477 | .4715 | .5335 | .381 | .5847 | .5975 |
| 17 | .381 | .2286 | .5281 | .5906 | .4763 | .5658 | .6348 |
| 18 | .3429 | .2286 | .4904 | .4954 | .4572 | .5658 | .5975 |
| 19 | .3239 | .2096 | .4904 | .4572 | .4001 | .5093 | .5415 |
| 20 | .3048 | .1905 | .3772 | .4001 | .362 | .4715 | .4294 |
| 21 | .2858 | .1905 | .3395 | .2641 | .362 | .3961 | .3921 |
| 22 | .3048 | .2096 | .2641 | .2641 | .3048 | .3772 | .3361 |
| 23 | .2858 | .1905 | .2641 | .2641 | .2667 | .3584 | .3361 |
| 24 | .2641 | .2667 | .1715 | .2641 | .2641 | .2667 | .3772 |
| **Max** | **.381** | **.3429** | **.5281** | **.5906** | **.4763** | **.5847** | **.6348** |
| **Min** | **.2452** | **.1905** | **.1715** | **.2263** | **.2263** | **.2286** | **.3361** |
| **Avg** | **.3148** | **.2405** | **.3365** | **.3590** | **.3269** | **.4060** | **.4669** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (U)[048] BU 5851**
**Substation No/ Name :- 214414 / 33/11 KV MIDC No. I BARAMATI**
**Feeder No / Name : 202 / Naka footwear Feeder KV- 11 / OUTGOING**
**SHEDDABLE FEEDER HAVING WEEKLY STAGGERING (MIDC, EQUIVALENT)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .9242 | 1.4098 | .7049 | .9619 | .9619 | .7621 | 1.0374 |
| 2 | .9054 | 1.3336 | .7621 | .9619 | .9619 | .724 | 1.0374 |
| 3 | .9054 | 1.1431 | .8002 | .9431 | .9431 | .7621 | 1.0562 |
| 4 | .9054 | .9526 | .7049 | .9619 | .9242 | .8002 | 1.0374 |
| 5 | .9619 | .7621 | .6668 | .9619 | .9242 | .8573 | 1.0185 |
| 6 | .9808 | .724 | .8002 | .9431 | .9431 | .8954 | 1.0374 |
| 7 | 1.0374 | .6478 | 1.0479 | .9808 | .9431 | .9907 | 1.0562 |
| 8 | 1.0185 | .6097 | .9717 | 1.1506 | .9997 | | 1.4523 |
| 9 | 1.358 | .6478 | 1.2384 | 1.094 | 1.1241 | 1.1431 | 1.7353 |
| 10 | 1.4861 | .743 | 1.5466 | 1.7718 | .9335 | 1.1694 | 1.6804 |
| 11 | 1.5242 | .7621 | 1.5089 | 1.7147 | 1.0098 | 1.5089 | 1.7177 |
| 12 | 1.6004 | .9335 | 1.773 | 1.6766 | 1.1241 | 1.773 | 1.5684 |
| 13 | 1.6004 | .9526 | 1.6221 | 1.1812 | 1.086 | 1.5089 | 1.7177 |
| 14 | 1.6194 | 1.0098 | 1.6598 | 1.4289 | 1.086 | 1.3203 | 1.643 |
| 15 | 1.6194 | | 1.6975 | 1.6575 | 1.0098 | 1.5466 | 1.6804 |
| 16 | 1.6385 | | 1.6409 | 1.8099 | 1.0098 | 1.5844 | |
| 17 | 1.6385 | .5144 | 1.6221 | 1.8671 | 1.0288 | 1.5089 | 1.643 |
| 18 | 1.6004 | .6478 | 1.7353 | 1.7528 | 1.0098 | 1.1317 | 1.5684 |
| 19 | 1.5242 | 1.0288 | 1.6221 | 1.6194 | .9526 | 1.6975 | 1.419 |
| 20 | 1.448 | .9526 | 1.6598 | 1.5432 | .8954 | 1.3203 | 1.2696 |
| 21 | 1.3717 | .9526 | 1.5844 | 1.6032 | .9526 | 1.2071 | 1.1389 |
| 22 | 1.6004 | .8002 | 1.3769 | 1.5278 | .9145 | 1.1128 | 1.0456 |
| 23 | 1.5623 | .7049 | .8676 | 1.2637 | .8954 | .9808 | .8215 |
| 24 | .9431 | 1.448 | .6668 | .9808 | .9808 | .8002 | 1.0751 |
| **Max** | **1.6385** | **1.448** | **1.773** | **1.8671** | **1.1241** | **1.773** | **1.7353** |
| **Min** | **.9054** | **.5144** | **.6668** | **.9431** | **.8954** | **.724** | **.8215** |
| **Avg** | **1.3239** | **.8946** | **1.2617** | **1.3482** | **.9839** | **1.1785** | **1.3242** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (U)[048] BU 5851**
**Substation No/ Name :- 214414 / 33/11 KV MIDC No. I BARAMATI**
**Feeder No / Name : 203 / Ganesh Mandir SHEDDABLE URBAN**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8676 | 1.0669 | .9907 | .9242 | .8676 | .8954 | .9054 |
| 2 | .8676 | 1.0479 | 1.0479 | .9054 | .8676 | .8573 | .9054 |
| 3 | .8865 | 1.105 | 1.105 | .9054 | .8488 | .8954 | .9242 |
| 4 | .8676 | 1.1431 | 1.0479 | .9054 | .8488 | .9526 | .9242 |
| 5 | .9619 | 1.2955 | 1.1812 | 1.1317 | .9242 | 1.086 | 1.1128 |
| 6 | 1.2826 | 1.6004 | 1.2384 | 1.4335 | 1.3392 | 1.2765 | 1.5466 |
| 7 | 1.8296 | 1.8099 | 1.1622 | 1.6975 | 1.5278 | 1.848 | 1.905 |
| 8 | 1.9239 | 1.9814 | 1.9433 | 1.9427 | 1.773 | 1.9814 | 1.9993 |
| 9 | 1.5655 | 1.9052 | 1.6766 | 1.6032 | 1.6004 | 1.4098 | 1.6221 |
| 10 | 1.5242 | 1.3336 | 1.5089 | 1.3717 | 1.5813 | 1.3769 | 1.4003 |
| 11 | 1.4098 | 1.2765 | 1.4712 | 1.3146 | 1.4098 | 1.3203 | 1.2696 |
| 12 | 1.1431 | 1.2574 | 1.2826 | 1.2384 | 1.2193 | 1.226 | 1.1949 |
| 13 | 1.1431 | 1.1622 | 1.3014 | 1.1812 | 1.2193 | 1.2071 | 1.1949 |
| 14 | 1.1812 | 1.1241 | 1.2071 | 1.086 | 1.0479 | 1.094 | 1.0456 |
| 15 | 1.1812 | 1.0098 | 1.094 | 1.0669 | 1.0669 | 1.1317 | 1.0829 |
| 16 | 1.2193 | 1.0669 | 1.2071 | 1.1241 | 1.086 | 1.1317 | 1.1389 |
| 17 | 1.2193 | 1.2193 | 1.2449 | 1.3527 | 1.1622 | 1.2071 | 1.2696 |
| 18 | 1.2384 | 1.5432 | 1.6221 | 1.5813 | 1.5242 | 1.6598 | 1.643 |
| 19 | 1.3336 | 1.7337 | 1.773 | 1.6956 | 1.6575 | 1.8861 | 1.7551 |
| 20 | 1.448 | 1.6575 | 1.7353 | 1.6956 | 1.6385 | 1.8296 | 1.587 |
| 21 | 1.5242 | 1.5623 | 1.5844 | 1.4901 | 1.5242 | 1.5466 | 1.3817 |
| 22 | 1.2955 | 1.3717 | 1.3203 | 1.1694 | 1.3717 | 1.2826 | 1.2696 |
| 23 | 1.1812 | 1.086 | 1.0562 | 1.0562 | 1.0479 | 1.1128 | 1.0456 |
| 24 | .9054 | 1.105 | .9145 | .9431 | .9054 | .9145 | .9431 |
| **Max** | **1.9239** | **1.9814** | **1.9433** | **1.9427** | **1.773** | **1.9814** | **1.9993** |
| **Min** | **.8676** | **1.0098** | **.9145** | **.9054** | **.8488** | **.8573** | **.9054** |
| **Avg** | **1.2500** | **1.3527** | **1.3215** | **1.2840** | **1.2525** | **1.2971** | **1.2945** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (U)[048] BU 5851**
**Substation No/ Name :- 214414 / 33/11 KV MIDC No. I BARAMATI**
**Feeder No / Name : 204 / RUI HOSPITAL SHEDDABLE URBAN**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1698 | .2096 | .1524 | .1886 | .1698 | .1715 | .1886 |
| 2 | .1698 | .1905 | .1715 | .1698 | .1698 | .1524 | .1698 |
| 3 | .1698 | .1905 | .1905 | .1698 | .1698 | .1715 | .1698 |
| 4 | .1698 | .2096 | .2096 | .1886 | .1698 | .1905 | .1886 |
| 5 | .1886 | .2286 | .1905 | .1886 | .1698 | .2096 | .1886 |
| 6 | .2075 | .2286 | .2096 | .2075 | .1698 | .2286 | .2075 |
| 7 | .2263 | .2477 | .2096 | .2075 | .1698 | .2096 | .2263 |
| 8 | .2641 | .2667 | .2096 | .2263 | .1886 | .2477 | .2452 |
| 9 | .2641 | .2858 | .2286 | .2452 | .2096 | .2477 | .2452 |
| 10 | .2667 | .3429 | .2829 | .2477 | .2477 | .2829 | .2427 |
| 11 | .2858 | .3048 | .2641 | .2858 | .2286 | .3206 | .2614 |
| 12 | .2858 | .2667 | .2075 | .2667 | .1905 | .3206 | .2801 |
| 13 | .2858 | .2477 | .1886 | .2096 | .1715 | .2829 | .2241 |
| 14 | .3048 | .2286 | .1886 | .1905 | .1524 | .2263 | .2241 |
| 15 | .3048 | .2096 | .1886 | .1905 | .1524 | .2452 | .2427 |
| 16 | .2858 | .1905 | .1886 | .1905 | .1524 | .2452 | .2427 |
| 17 | .2858 | .1905 | .1886 | .2286 | .1715 | .2263 | .2241 |
| 18 | .2858 | .2477 | .2452 | .2477 | .2096 | .2829 | .2427 |
| 19 | .2858 | .2477 | .2452 | .2667 | .2286 | .2641 | .2241 |
| 20 | .2858 | .2477 | .2452 | .2477 | .2286 | .2452 | .2427 |
| 21 | .2858 | .2286 | .2263 | .2452 | .2477 | .2452 | .2427 |
| 22 | .2667 | .1905 | .2263 | .2263 | .2286 | .2263 | .2614 |
| 23 | .2477 | .2096 | .2263 | .2263 | .2477 | .2263 | .2241 |
| 24 | .1886 | .2286 | .1715 | .1886 | .1886 | .1905 | .1886 |
| **Max** | **.3048** | **.3429** | **.2829** | **.2858** | **.2477** | **.3206** | **.2801** |
| **Min** | **.1698** | **.1905** | **.1524** | **.1698** | **.1524** | **.1524** | **.1698** |
| **Avg** | **.2492** | **.2350** | **.2106** | **.2188** | **.1931** | **.2358** | **.2249** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (U)[048] BU 5851**
**Substation No/ Name :- 214414 / 33/11 KV MIDC No. I BARAMATI**
**Feeder No / Name : 205 / Kalyani Corner Feeder KV- 11 / OUTGOING**
**SHEDDABLE FEEDER HAVING WEEKLY STAGGERING (MIDC, EQUIVALENT)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4904 | .6097 | .6097 | .4527 | .4338 | .4191 | .4904 |
| 2 | .4904 | .5716 | .5906 | .4527 | .4338 | .4572 | .4904 |
| 3 | .4904 | .5716 | .5716 | .4715 | .4527 | .4954 | .4527 |
| 4 | .5093 | .5716 | .6097 | .4715 | .4527 | .4191 | .4527 |
| 5 | .5093 | .6478 | .6478 | .4904 | .4527 | .5335 | .4715 |
| 6 | .5093 | .724 | .6097 | .4904 | .5093 | .5716 | .4715 |
| 7 | .5847 | .8002 | .5716 | .547 | .547 | .4763 | .4715 |
| 8 | .8488 | .8383 | .9145 | .8865 | .4527 | .7811 | .8676 |
| 9 | .8488 | .8573 | .8954 | 1.0185 | .6859 | .8002 | .7545 |
| 10 | .8383 | .8002 | .7922 | .6097 | .381 | .6979 | .7468 |
| 11 | .8002 | .743 | .6224 | .6859 | .362 | .6979 | .7842 |
| 12 | .7621 | .7811 | .8676 | .8383 | .381 | .9054 | .9335 |
| 13 | .8002 | .6478 | .6036 | .5144 | .3429 | .6602 | .7468 |
| 14 | .8383 | .8383 | .9054 | .8764 | .4001 | .7733 | .8215 |
| 15 | .8383 | 1.1812 | .9808 | 1.1241 | .4572 | .811 | .8402 |
| 16 | .8002 | .8383 | .7922 | .9145 | .4572 | .7922 | .8029 |
| 17 | .7621 | .6859 | .6979 | .9145 | .4191 | .7356 | .7468 |
| 18 | .724 | .5716 | .6036 | .724 | .4001 | .5658 | .4668 |
| 19 | .6859 | .5525 | .6224 | .6478 | .4001 | .5658 | .4854 |
| 20 | .6478 | .4763 | .5847 | .6668 | .3429 | .5847 | .5228 |
| 21 | .5716 | .5906 | .5658 | .6413 | .381 | .6036 | .5601 |
| 22 | .6478 | .7049 | .5281 | .7167 | .381 | .6413 | .5975 |
| 23 | .6478 | .6859 | .5847 | .7733 | .4001 | .6602 | .6722 |
| 24 | .5093 | .6097 | .6287 | .4715 | .4527 | .381 | .5093 |
| **Max** | **.8488** | **1.1812** | **.9808** | **1.1241** | **.6859** | **.9054** | **.9335** |
| **Min** | **.4904** | **.4763** | **.5281** | **.4527** | **.3429** | **.381** | **.4527** |
| **Avg** | **.6731** | **.7041** | **.6834** | **.6834** | **.4325** | **.6262** | **.6317** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (U)[048] BU 5851**
**Substation No/ Name :- 214477 / 33/11 kV Textile park**
**Feeder No / Name : 201 / Geeta textile SHEDDABLE FEEDER HAVING WEEKLY**
**Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2279 | .1696 | .1402 | .1509 | .1341 | .1402 | .1715 |
| 2 | .2103 | .1677 | .1402 | .1509 | .1357 | .1402 | .1715 |
| 3 | .1928 | .1677 | .1402 | .1509 | .1357 | .1402 | .1715 |
| 4 | .1928 | .1677 | .1402 | .1526 | .1341 | .1402 | .1715 |
| 5 | .1928 | .1509 | .1402 | .1509 | .1526 | .1402 | .1715 |
| 6 | .1928 | .1509 | .1578 | .1677 | .1509 | .1578 | .1715 |
| 7 | .1928 | .1509 | .1753 | .1844 | .1526 | .1753 | .1715 |
| 8 | .2103 | .1509 | .1753 | .1844 | .1696 | .1578 | .1715 |
| 9 | .4382 | .1715 | .4557 | .5144 | .4458 | .4458 | .4458 |
| 10 | .3258 | .1543 | .4458 | .463 | .4115 | .5144 | .4801 |
| 11 | .3429 | .1543 | .4115 | .4115 | .4115 | .4801 | .4973 |
| 12 | .3772 | .1543 | .3944 | .3944 | .4458 | .4287 | .5144 |
| 13 | .4115 | .12 | .3601 | .3601 | .3772 | .3429 | .4801 |
| 14 | .3086 | .1372 | .5144 | .5144 | .4801 | .4115 | .5144 |
| 15 | .4287 | .1543 | .4973 | .5144 | .5144 | .4458 | .583 |
| 16 | .463 | .1715 | .583 | .6001 | .5487 | .4458 | .583 |
| 17 | .5083 | .1928 | .631 | .6516 | .5316 | .4801 | .6173 |
| 18 | .2629 | .1753 | .3506 | .3681 | .2804 | .3258 | .3155 |
| 19 | .2774 | .1578 | .2601 | .2629 | .2279 | .2915 | |
| 20 | .2774 | .1578 | .1865 | .1526 | .1753 | .1543 | .1734 |
| 21 | .2204 | .1578 | .1509 | .1526 | .1753 | .1543 | .1696 |
| 22 | .1844 | .1578 | .1509 | .1341 | .1578 | .1715 | .1341 |
| 23 | .1677 | .1578 | .1509 | .1341 | .1402 | .1886 | .1341 |
| 24 | .2279 | .1677 | .1578 | .1509 | .1357 | .1402 | .1715 |
| **Max** | **.5083** | **.1928** | **.631** | **.6516** | **.5487** | **.5144** | **.6173** |
| **Min** | **.1677** | **.12** | **.1402** | **.1341** | **.1341** | **.1402** | **.1341** |
| **Avg** | **.2848** | **.1591** | **.2879** | **.2947** | **.2760** | **.2756** | **.3124** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (U)[048] BU 5851**
**Substation No/ Name :- 214477 / 33/11 kV Textile park**
**Feeder No / Name : 202 / Dattakrupa Engineering Feeder KV- 11 / OUTGOING SHEDDABLE FEEDER HAVING WEEKLY STAGGERING (MIDC, EQUIVALENT)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1189 | .1337 | .1337 | .1429 | .1486 | .1337 | .12 |
| 2 | .104 | .1269 | .1337 | .1448 | .1269 | .1337 | .12 |
| 3 | .104 | .1286 | .1337 | .1303 | .1303 | .1337 | .12 |
| 4 | .104 | .1303 | .1337 | .1337 | .1269 | .1337 | .12 |
| 5 | .104 | .1337 | .1337 | .1337 | .1286 | .1337 | .1372 |
| 6 | .104 | .1286 | .1337 | .1337 | .1286 | .1337 | .1543 |
| 7 | .1189 | .1286 | .1337 | .1303 | .1189 | .1337 | .1543 |
| 8 | .1337 | .1303 | .1337 | .1486 | .1448 | .1337 | .1543 |
| 9 | .1337 | .1543 | .208 | .1907 | .1614 | .1467 | .1907 |
| 10 | .3961 | .2401 | .2934 | .3081 | .176 | .2494 | .2972 |
| 11 | .3521 | .2229 | .3081 | .3227 | .176 | .2641 | .3081 |
| 12 | .3227 | .2229 | .2934 | .3374 | .2054 | .3258 | .2934 |
| 13 | .2787 | .1886 | .176 | .1907 | .132 | .2201 | .2054 |
| 14 | .3081 | .2058 | .2934 | .3227 | .1467 | .3081 | .2347 |
| 15 | .3814 | .2058 | .3227 | .3227 | .1614 | .3144 | .2934 |
| 16 | .3227 | .1715 | .3227 | .2934 | .132 | .2641 | .2054 |
| 17 | .3269 | .1486 | .3041 | .2054 | .176 | .2572 | .2347 |
| 18 | .2675 | .1486 | .2972 | .2 | .1932 | .2743 | .1738 |
| 19 | .208 | .1635 | .1833 | .2286 | .1635 | .2915 | .1783 |
| 20 | .1269 | .1783 | .1286 | .1932 | .1486 | .2572 | .1486 |
| 21 | .1337 | .1635 | .1593 | .1715 | .1486 | .1372 | .1486 |
| 22 | .1143 | .1486 | .1486 | .1715 | .1486 | .1372 | .1783 |
| 23 | .1189 | .1486 | .1448 | .1486 | .1635 | .1372 | .1932 |
| 24 | .1337 | .1337 | .1486 | .1486 | .1486 | .1486 | .1372 |
| **Max** | **.3961** | **.2401** | **.3227** | **.3374** | **.2054** | **.3258** | **.3081** |
| **Min** | **.104** | **.1269** | **.1286** | **.1303** | **.1189** | **.1337** | **.12** |
| **Avg** | **.2007** | **.1619** | **.2001** | **.2022** | **.1515** | **.2001** | **.1875** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (U)[048] BU 5851**
**Substation No/ Name :- 214478 / 33/11 kV MIDC Baramati - II**
**Feeder No / Name : 201 / Airport SHEDDABLE FEEDER HAVING WEEKLY**
**Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.9052 | 2.4387 | 1.6385 | 2.191 | 2.0957 | 2.0005 | 2.21 |
| 2 | 1.8099 | 2.3815 | 1.6385 | 2.21 | 2.0767 | 2.0005 | 2.21 |
| 3 | 1.8099 | 2.3815 | 1.6385 | 2.1529 | 2.0386 | 1.9814 | 2.2291 |
| 4 | 1.7147 | 2.3434 | 1.6385 | 2.191 | 2.0576 | 2.0195 | 2.21 |
| 5 | 1.7147 | 2.2862 | 1.7147 | 2.1719 | 2.0386 | 2.0005 | 2.1719 |
| 6 | 1.7147 | 2.2481 | 1.9052 | 2.0957 | 2.0386 | 2.0386 | 2.1719 |
| 7 | 1.9052 | 1.9814 | 2.0957 | 2.1719 | 1.9052 | 2.0386 | 2.1719 |
| 8 | 2.2862 | 1.8099 | 2.2862 | 2.2481 | 1.9433 | 2.191 | 2.1338 |
| 9 | 2.2291 | 1.9052 | 2.572 | 2.572 | 2.3815 | 2.5149 | 2.7244 |
| 10 | 2.8578 | 1.7909 | 2.7054 | 2.7244 | 2.4577 | 2.7054 | 2.8387 |
| 11 | 2.6673 | 1.7528 | | 2.8959 | 2.5149 | 3.0483 | 2.934 |
| 12 | 2.572 | 1.3527 | 2.5149 | .7811 | 2.6292 | 2.8578 | 3.1055 |
| 13 | 2.3243 | 1.5242 | 2.6292 | 2.6101 | 2.572 | 2.8578 | 2.9721 |
| 14 | 2.6863 | 1.7337 | 2.8197 | 2.7625 | 2.4958 | 2.8578 | 2.8387 |
| 15 | 2.572 | 1.6956 | 3.1055 | 2.8387 | 2.5339 | 2.8959 | 3.0483 |
| 16 | 2.7054 | 1.5813 | 3.0102 | 2.8769 | 2.572 | 2.934 | 3.2007 |
| 17 | 2.7054 | 1.6385 | 2.9912 | 2.4958 | 2.3053 | 2.9912 | 2.7435 |
| 18 | 2.5339 | 1.7147 | 2.572 | 2.3434 | 2.1719 | 2.7054 | 2.5149 |
| 19 | 2.2862 | 1.7337 | 2.7244 | 2.5911 | 2.1719 | 2.5149 | 2.3053 |
| 20 | 2.21 | 1.7528 | 2.6292 | 2.5339 | 1.9243 | 2.1719 | 2.3624 |
| 21 | 2.2291 | 1.7909 | 2.4006 | 2.2862 | 1.9814 | 2.4958 | 2.4006 |
| 22 | 2.3243 | 1.829 | 2.3053 | 2.3243 | 1.9624 | 2.4387 | 2.4387 |
| 23 | 2.5149 | 1.8861 | 2.2481 | 2.2862 | 1.9433 | 2.4006 | 2.4958 |
| 24 | 2.0576 | 2.4387 | 1.7147 | 2.191 | 2.0957 | 1.9433 | 2.2481 |
| **Max** | **2.8578** | **2.4387** | **3.1055** | **2.8959** | **2.6292** | **3.0483** | **3.2007** |
| **Min** | **1.7147** | **1.3527** | **1.6385** | **.7811** | **1.9052** | **1.9433** | **2.1338** |
| **Avg** | **2.2640** | **1.9163** | **2.3260** | **2.3561** | **2.2045** | **2.4418** | **2.5283** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (U)[048] BU 5851**
**Substation No/ Name :- 214478 / 33/11 kV MIDC Baramati - II**
**Feeder No / Name : 202 / Water Supply MIDC SHEDDABLE FEEDER HAVING WEEKLY**
**Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .724 | .6668 | .2858 | .6478 | .6668 | .5716 | .6859 |
| 2 | .6859 | .6287 | .2858 | .6287 | .6097 | .5525 | .6668 |
| 3 | .6478 | .6287 | .2858 | .6478 | .6859 | .5716 | .6859 |
| 4 | .5716 | .6097 | .3429 | .6287 | .6859 | .5525 | .6859 |
| 5 | .5716 | .5716 | .3429 | .6668 | .724 | .5716 | .6668 |
| 6 | .5716 | .5144 | .3429 | .743 | .7621 | .6478 | .6859 |
| 7 | .6478 | .6478 | .4763 | .6859 | .7049 | .7049 | .6859 |
| 8 | .7621 | .4763 | .8573 | .743 | .8002 | .724 | .7049 |
| 9 | .7621 | .4572 | .8764 | .9526 | .8954 | .8764 | .8954 |
| 10 | .9907 | .3429 | .9526 | .9717 | .9526 | .9526 | 1.086 |
| 11 | .8764 | .3239 | .8764 | 1.0479 | 1.0288 | .9145 | 1.0288 |
| 12 | .8192 | .381 | .9145 | | .8764 | .9335 | .5906 |
| 13 | .8573 | .3239 | .8954 | .5716 | .9526 | .9145 | .5716 |
| 14 | .8764 | .2667 | .9526 | .9145 | .7811 | .8764 | .5716 |
| 15 | .9145 | .2477 | 1.0479 | 1.0479 | .8764 | .9145 | .7621 |
| 16 | .9145 | .3239 | 1.105 | 1.105 | .9335 | .8954 | .9526 |
| 17 | .9907 | .3429 | .9526 | 1.0288 | .9526 | .8192 | .8764 |
| 18 | .8764 | .2858 | .9526 | .8383 | .8764 | .6478 | .8383 |
| 19 | .6097 | .2477 | .8573 | .6668 | .8192 | .6478 | .8002 |
| 20 | .4763 | .2667 | .8573 | .743 | .743 | .6859 | .7621 |
| 21 | .724 | .2858 | .7049 | .7621 | .7049 | .724 | .724 |
| 22 | .7049 | .3048 | .7049 | .7049 | .6478 | .6859 | .6668 |
| 23 | .6859 | .3239 | .6668 | .6859 | .5906 | .6859 | .6287 |
| 24 | .7621 | .724 | .2858 | .6287 | .5906 | .5335 | .6859 |
| **Max** | **.9907** | **.724** | **1.105** | **1.105** | **1.0288** | **.9526** | **1.086** |
| **Min** | **.4763** | **.2477** | **.2858** | **.5716** | **.5906** | **.5335** | **.5716** |
| **Avg** | **.7510** | **.4247** | **.7009** | **.7853** | **.7859** | **.7335** | **.7462** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (U)[048] BU 5851**
**Substation No/ Name :- 214506 / 33KV/11 KV Baramati City**
**Feeder No / Name : 201 / Shriramnagar SHEDDABLE URBAN**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .381 | .3429 | .3239 | .3239 | .3429 | .3429 | .3239 |
| 2 | .3429 | .3048 | .3048 | .3048 | .3048 | .2858 | .3048 |
| 3 | .3048 | .2858 | .3048 | .3048 | .3048 | .3048 | .3048 |
| 4 | .3048 | .362 | .3239 | .3239 | .3429 | .3048 | .3239 |
| 5 | .381 | .4191 | .362 | .362 | .3429 | .3429 | .381 |
| 6 | .4954 | .4572 | .4382 | .4763 | .381 | .4572 | .4763 |
| 7 | .6859 | .6668 | .6287 | .6287 | .5335 | .5906 | .6859 |
| 8 | .7621 | .7811 | .6287 | .7049 | .6859 | .7049 | .743 |
| 9 | .6097 | .6097 | .6287 | .6287 | .6478 | .6478 | .6478 |
| 10 | .5716 | .5525 | .5525 | .6097 | .6287 | .5525 | .5906 |
| 11 | .5716 | .5525 | .5335 | .5716 | .5525 | .5335 | .5716 |
| 12 | .4954 | .4763 | .5716 | .5335 | .4763 | .5144 | .5525 |
| 13 | .4763 | .4954 | .4954 | .5335 | .4572 | .4763 | .5335 |
| 14 | .4763 | .4763 | .4763 | .4572 | .4191 | .4572 | .4954 |
| 15 | .4763 | .4954 | .4954 | .4572 | .4001 | .4572 | .4954 |
| 16 | .4763 | .5335 | .4382 | .5335 | .4001 | .4763 | .5144 |
| 17 | .5335 | .5906 | .5144 | .5335 | .4572 | .5144 | .5335 |
| 18 | .6478 | .6668 | .6668 | .6478 | .5716 | .6859 | .7621 |
| 19 | .7811 | .743 | .7621 | .724 | .6287 | .724 | .743 |
| 20 | .6859 | .6859 | .7049 | .6859 | .6097 | .6668 | .6859 |
| 21 | .6287 | .6097 | .5906 | .6097 | .5716 | .5906 | .6287 |
| 22 | .4954 | .4954 | .5335 | .5335 | .5144 | .5335 | .5335 |
| 23 | .4191 | .4001 | .4191 | .4191 | .4191 | .4191 | .4191 |
| 24 | .381 | .3429 | .3429 | .3429 | .3429 | .3429 | .362 |
| **Max** | **.7811** | **.7811** | **.7621** | **.724** | **.6859** | **.724** | **.7621** |
| **Min** | **.3048** | **.2858** | **.3048** | **.3048** | **.3048** | **.2858** | **.3048** |
| **Avg** | **.5160** | **.5144** | **.5017** | **.5104** | **.4723** | **.4969** | **.5255** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (U)[048] BU 5851**
**Substation No/ Name :- 214506 / 33KV/11 KV Baramati City**
**Feeder No / Name : 202 / Desai Estate SHEDDABLE URBAN**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5716 | .5335 | .5335 | .5335 | .5716 | .5716 | .5716 |
| 2 | .5716 | .4954 | .5335 | .5144 | .5335 | .5335 | .5525 |
| 3 | .5335 | .4191 | .5144 | .5144 | .5716 | .5716 | .5525 |
| 4 | .5335 | .5525 | .5335 | .5525 | .5716 | .5716 | .5906 |
| 5 | .6478 | .6478 | .5525 | .5906 | .6097 | | .6478 |
| 6 | .8002 | .724 | .6859 | .7621 | .6859 | .8002 | .8192 |
| 7 | .9526 | .8764 | .8002 | .8573 | .8383 | .8954 | .8954 |
| 8 | .8764 | .8954 | .8573 | .9145 | .8764 | .8954 | .9335 |
| 9 | .8764 | .8383 | .9526 | .9145 | .8764 | .8954 | .8764 |
| 10 | .7811 | .8192 | .8192 | .8002 | .8573 | .8573 | .8573 |
| 11 | .743 | .8002 | .8573 | .8002 | .8002 | .7811 | .7811 |
| 12 | .743 | .724 | .8002 | .7621 | .7049 | .7621 | .724 |
| 13 | .6859 | .6859 | .724 | .7621 | .6668 | .7049 | .6859 |
| 14 | .6287 | .6668 | .724 | .6478 | .6097 | .6478 | .6478 |
| 15 | .6478 | .6478 | .7049 | .6859 | .6287 | .6668 | .6859 |
| 16 | .6668 | .6478 | .7049 | .6859 | .6287 | .6859 | .6859 |
| 17 | .7049 | .7621 | .7621 | .724 | .6668 | .724 | .8192 |
| 18 | .8954 | .9526 | 1.0288 | .8383 | .8002 | .9907 | 1.0098 |
| 19 | 1.0288 | 1.0098 | 1.0479 | 1.0669 | .9526 | 1.0479 | 1.0669 |
| 20 | .9907 | .9907 | .9717 | .9907 | .9335 | 1.0098 | .9907 |
| 21 | .9335 | .8764 | .8954 | .8764 | .9145 | .9145 | .9145 |
| 22 | .8192 | .7811 | .8192 | .8002 | .8573 | .8002 | .8573 |
| 23 | .6668 | .6478 | .6859 | .6859 | .7049 | .6859 | .7049 |
| 24 | .6097 | .5716 | .5525 | .5525 | .5716 | .5906 | .6097 |
| **Max** | **1.0288** | **1.0098** | **1.0479** | **1.0669** | **.9526** | **1.0479** | **1.0669** |
| **Min** | **.5335** | **.4191** | **.5144** | **.5144** | **.5335** | **.5335** | **.5525** |
| **Avg** | **.7462** | **.7319** | **.7526** | **.7430** | **.7264** | **.7654** | **.7700** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (U)[048] BU 5851**
**Substation No/ Name :- 214506 / 33KV/11 KV Baramati City**
**Feeder No / Name : 203 / Ashoknagar SHEDDABLE URBAN**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3048 | .3048 | .2743 | .3048 | .3429 | .3429 | .3048 |
| 2 | .3048 | .3048 | .2743 | .2858 | .3048 | .3429 | .3048 |
| 3 | .2667 | .2477 | .2572 | .2858 | .3429 | .3048 | .2858 |
| 4 | .2667 | .3048 | .2743 | .3048 | .3429 | .3429 | .3048 |
| 5 | .381 | .381 | .2915 | .3239 | .381 | .362 | .3429 |
| 6 | .4572 | .4191 | .3601 | .4191 | .4191 | .4191 | .4954 |
| 7 | .4954 | .5525 | .3944 | .4572 | .4572 | .5525 | .5525 |
| 8 | .5335 | .5335 | .4801 | .5525 | .5335 | .5906 | .5906 |
| 9 | .5335 | .4763 | .5335 | .5525 | .5335 | | .5144 |
| 10 | .4572 | .4973 | .5144 | .5335 | .5335 | .4763 | .4973 |
| 11 | .5335 | .4287 | .5144 | .5335 | .5144 | .5906 | .5487 |
| 12 | .5906 | .4801 | .4763 | .5335 | .5144 | .5335 | .5144 |
| 13 | .5525 | .4801 | .5144 | .5335 | .4763 | .5335 | .5144 |
| 14 | .5144 | .463 | .4954 | .5335 | .4954 | .5144 | .4801 |
| 15 | .5525 | .4458 | .4954 | .5335 | .5144 | .5335 | .463 |
| 16 | .5144 | .4801 | .4572 | .4954 | .4572 | .5335 | .4973 |
| 17 | .5335 | .4801 | .4763 | .4954 | .4572 | .5525 | .5144 |
| 18 | .6859 | .583 | .6097 | .6478 | .6097 | .724 | .6516 |
| 19 | .724 | .6859 | .7049 | .7621 | .7049 | .743 | .6687 |
| 20 | .7049 | .6344 | .6668 | .724 | .6478 | .6859 | .6687 |
| 21 | .5906 | .5316 | .5525 | .6097 | .5716 | .6097 | .5658 |
| 22 | .4763 | .4287 | .4954 | .5335 | .5144 | .5144 | .4801 |
| 23 | .4001 | .3429 | .4001 | .4191 | .4382 | .4001 | .3944 |
| 24 | .3429 | .3429 | .2915 | .3239 | .3429 | .381 | .3429 |
| Max | **.724** | **.6859** | **.7049** | **.7621** | **.7049** | **.743** | **.6687** |
| Min | **.2667** | **.2477** | **.2572** | **.2858** | **.3048** | **.3048** | **.2858** |
| Avg | **.4882** | **.4512** | **.4502** | **.4874** | **.4771** | **.5036** | **.4791** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (U)[048] BU 5851**
**Substation No/ Name :- 214506 / 33KV/11 KV Baramati City**
**Feeder No / Name : 204 / T.C. College SHEDDABLE URBAN**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .724 | .6287 | .6001 | .6097 | .6097 | .6097 | .6478 |
| 2 | .6859 | .6097 | .6001 | .5716 | .5716 | .5716 | .6287 |
| 3 | .6859 | .5716 | .583 | .5716 | .5716 | .5716 | .6097 |
| 4 | .6478 | .6478 | .6001 | .6668 | .6097 | .5906 | .6287 |
| 5 | .9907 | .724 | .703 | .8002 | .8764 | .9335 | .8383 |
| 6 | 1.2574 | .8764 | .9431 | .9907 | 1.1431 | 1.1431 | |
| 7 | 1.4098 | 1.2955 | 1.2174 | 1.3717 | 1.2193 | 1.4289 | 1.5432 |
| 8 | 1.2574 | 1.2955 | 1.2517 | 1.467 | 1.2955 | 1.448 | 1.448 |
| 9 | 1.0669 | 1.2003 | 1.4861 | 1.2955 | 1.3336 | 1.3336 | 1.2955 |
| 10 | 1.0098 | 1.0802 | .9145 | 1.2955 | 1.2384 | 1.2384 | 1.1317 |
| 11 | .9717 | 1.0288 | 1.2193 | 1.2955 | 1.1431 | 1.1622 | 1.166 |
| 12 | 1.086 | .9774 | 1.2003 | 1.1812 | 1.1241 | 1.1812 | 1.1145 |
| 13 | 1.0669 | .9602 | 1.1431 | 1.1431 | 1.0288 | 1.0288 | 1.0802 |
| 14 | 1.0669 | .9602 | 1.1622 | 1.0669 | 1.105 | 1.1622 | 1.0117 |
| 15 | 1.0098 | .9602 | 1.2003 | 1.105 | 1.0288 | 1.1431 | 1.046 |
| 16 | 1.0669 | 1.046 | 1.1622 | 1.1431 | 1.0288 | 1.1241 | 1.0802 |
| 17 | 1.1431 | 1.166 | 1.2765 | 1.1431 | 1.105 | 1.1812 | 1.1831 |
| 18 | 1.467 | 1.3375 | 1.6194 | 1.6004 | 1.3146 | 1.6194 | 1.4746 |
| 19 | 1.5623 | 1.4746 | 1.6766 | 1.7147 | 1.448 | 1.6766 | 1.5261 |
| 20 | 1.448 | 1.3546 | 1.5623 | 1.6004 | 1.3527 | 1.4289 | 1.4403 |
| 21 | 1.2193 | | 1.3146 | 1.3336 | 1.2003 | 1.3146 | 1.2003 |
| 22 | .9907 | .9259 | 1.105 | 1.1431 | 1.1241 | 1.0098 | .9431 |
| 23 | .7811 | .7373 | .8573 | .8002 | .8383 | .8192 | .7545 |
| 24 | .724 | .6287 | .6173 | .6287 | .6478 | .6478 | .6859 |
| **Max** | **1.5623** | **1.4746** | **1.6766** | **1.7147** | **1.448** | **1.6766** | **1.5432** |
| **Min** | **.6478** | **.5716** | **.583** | **.5716** | **.5716** | **.5716** | **.6097** |
| **Avg** | **1.0558** | **.9777** | **1.0840** | **1.1058** | **1.0399** | **1.0987** | **1.0643** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (U)[048] BU 5851**
**Substation No/ Name :- 214506 / 33KV/11 KV Baramati City**
**Feeder No / Name : 205 / Khandobanagar SHEDDABLE URBAN**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .9526 | .9145 | .7888 | .9526 | .8764 | .9145 | .9526 |
| 2 | .9145 | .8764 | .7888 | .9335 | .8764 | .8764 | .9145 |
| 3 | .8764 | .8002 | .7716 | .9145 | .8383 | .8383 | .8954 |
| 4 | .8764 | .9335 | .7888 | .9907 | .8383 | .8954 | .9526 |
| 5 | 1.1431 | 1.105 | .9088 | 1.0479 | 1.1431 | 1.1812 | 1.086 |
| 6 | 1.448 | 1.3527 | 1.2689 | 1.448 | 1.2574 | 1.4861 | 1.5432 |
| 7 | 1.6766 | 1.6575 | 1.4918 | 1.6575 | 1.5242 | 1.6956 | 1.7718 |
| 8 | 1.7147 | 1.848 | 1.6461 | 1.848 | 1.7528 | 1.8099 | 1.7909 |
| 9 | 1.5242 | 1.7337 | 1.7909 | 1.7337 | 1.5623 | 1.5432 | 1.6575 |
| 10 | 1.5242 | 1.4575 | 1.8671 | 1.6385 | 1.6004 | 1.6194 | 1.4575 |
| 11 | 1.2955 | 1.4232 | 1.7718 | 1.6004 | 1.5813 | 1.5813 | 1.3375 |
| 12 | 1.5432 | 1.3375 | 1.6194 | 1.4861 | 1.467 | 1.4861 | 1.3032 |
| 13 | 1.4289 | 1.1831 | .743 | 1.3336 | .7811 | 1.467 | 1.2346 |
| 14 | 1.4289 | 1.286 | 1.5051 | .7621 | 1.2574 | 1.4098 | 1.2346 |
| 15 | 1.4861 | 1.3203 | 1.5051 | 1.3717 | 1.3146 | 1.448 | 1.2346 |
| 16 | 1.6004 | 1.3032 | 1.5242 | 1.3336 | 1.2765 | 1.3527 | 1.3375 |
| 17 | 1.6194 | 1.3546 | 1.5623 | .6478 | 1.2765 | 1.467 | 1.3717 |
| 18 | 1.9624 | 1.7147 | 1.8671 | 1.7147 | 1.6956 | 1.8671 | 1.7318 |
| 19 | 2.0386 | 1.7661 | 1.9433 | 1.9052 | 1.7718 | 1.9243 | 1.7147 |
| 20 | 1.7909 | 1.6118 | 1.7147 | 1.7147 | 1.7147 | 1.829 | 1.5432 |
| 21 | 1.6194 | 1.406 | 1.6194 | 1.5242 | 1.6194 | 1.6194 | 1.4403 |
| 22 | 1.3336 | 1.2003 | 1.4098 | 1.4098 | 1.4861 | 1.4289 | 1.2517 |
| 23 | 1.1431 | .9431 | 1.2003 | 1.0669 | 1.1622 | 1.1431 | 1.0631 |
| 24 | .9526 | .9526 | .823 | .9907 | .9145 | 1.0288 | .9907 |
| **Max** | **2.0386** | **1.848** | **1.9433** | **1.9052** | **1.7718** | **1.9243** | **1.7909** |
| **Min** | **.8764** | **.8002** | **.743** | **.6478** | **.7811** | **.8383** | **.8954** |
| **Avg** | **1.4122** | **1.3117** | **1.3717** | **1.3344** | **1.3162** | **1.4130** | **1.3255** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**BARAMATI (U)[048] BU 5851**
**Substation No/ Name :- 214506 / 33KV/11 KV Baramati City**
**Feeder No / Name : 206 / Avchat Estate SHEDDABLE URBAN**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8764 | .8954 | .7716 | .8002 | .8764 | .9145 | .8764 |
| 2 | .8764 | .8764 | .7716 | .7811 | .8383 | .8383 | .8573 |
| 3 | .8383 | .8383 | .7545 | .7621 | .8002 | .8002 | .8383 |
| 4 | .8383 | .8383 | .7545 | .8002 | .8383 | .8192 | .8764 |
| 5 | 1.0288 | .9907 | .7888 | .8764 | .9526 | .9907 | .9526 |
| 6 | 1.1812 | 1.0098 | 1.0288 | 1.1622 | 1.1431 | 1.1431 | 1.1812 |
| 7 | 1.2574 | 1.2193 | 1.0974 | 1.1431 | 1.2193 | 1.2384 | 1.3146 |
| 8 | 1.2193 | 1.3717 | 1.166 | 1.2765 | 1.2955 | 1.3336 | 1.3908 |
| 9 | 1.1431 | 1.2574 | 1.2574 | 1.2574 | 1.2193 | 1.1431 | 1.2574 |
| 10 | 1.2765 | 1.2346 | 1.3527 | 1.3717 | 1.2574 | 1.3908 | 1.3032 |
| 11 | 1.3336 | 1.2346 | 1.3908 | 1.4861 | 1.2384 | 1.3146 | 1.2689 |
| 12 | 1.3336 | | 1.4289 | 1.448 | 1.2765 | 1.3146 | 1.2689 |
| 13 | 1.3717 | 1.2346 | 1.4098 | 1.3717 | 1.2193 | 1.2955 | 1.2689 |
| 14 | 1.2384 | 1.2003 | 1.3146 | 1.3336 | 1.1431 | 1.2765 | 1.2003 |
| 15 | 1.2765 | 1.0364 | 1.2765 | 1.2955 | 1.0479 | 1.3146 | 1.2003 |
| 16 | 1.4098 | 1.2003 | 1.3527 | 1.3717 | 1.0479 | 1.3527 | 1.2346 |
| 17 | 1.448 | 1.3032 | 1.4289 | 1.448 | 1.1431 | 1.467 | 1.3032 |
| 18 | 1.7718 | 1.6118 | 1.829 | 1.7147 | 1.448 | 1.9052 | 1.749 |
| 19 | 1.9433 | 1.8176 | 1.9624 | 1.9052 | 1.6385 | 1.9433 | 1.749 |
| 20 | 1.7909 | 1.6461 | 1.8099 | 1.829 | 1.5242 | 1.829 | 1.6461 |
| 21 | 1.5432 | 1.3717 | 1.448 | 1.4861 | 1.3717 | 1.5242 | 1.3717 |
| 22 | 1.2384 | 1.0974 | 1.2384 | 1.2574 | 1.2574 | 1.2765 | 1.166 |
| 23 | 1.0669 | .9259 | 1.0288 | 1.105 | 1.0669 | 1.086 | .9602 |
| 24 | .9145 | .8954 | .7888 | .8383 | .9145 | .9145 | .9145 |
| **Max** | **1.9433** | **1.8176** | **1.9624** | **1.9052** | **1.6385** | **1.9433** | **1.749** |
| **Min** | **.8383** | **.8383** | **.7545** | **.7621** | **.8002** | **.8002** | **.8383** |
| **Avg** | **1.2590** | **1.1786** | **1.2271** | **1.2551** | **1.1574** | **1.2678** | **1.2146** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 212004 / Switching Station Indapur**
**Feeder No / Name : 202 / 11 KV Kalthan GFSS GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 01-DEC-17 | 03-DEC-17 | 05-DEC-17 |
|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .3086 | |
| 2 | | .2915 | |
| 3 | | .2572 | |
| 4 | | .1886 | |
| 5 | | .2743 | |
| 6 | | .3601 | |
| 7 | | .5658 | |
| 8 | | .4973 | |
| 9 | | .4115 | |
| 10 | | | .2591 |
| 11 | | | .2439 |
| 12 | | | .2134 |
| 13 | | | .1829 |
| 14 | | | .1677 |
| 15 | | | .1524 |
| 16 | | | .1829 |
| 17 | | 1.1431 | |
| 24 | .5668 | .3601 | |
| **Max** | **.5668** | **1.1431** | **.2591** |
| **Min** | **.5668** | **.1886** | **.1524** |
| **Avg** | **.5668** | **.4235** | **.2003** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052]** **BU 5894**
**Substation No/ Name :- 212004 / Switching Station Indapur**
**Feeder No / Name : 204 / Moremala** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 3.0483 |
| Max | 3.0483 |
| Min | 3.0483 |
| Avg | 3.0483 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 212004 / Switching Station Indapur**
**Feeder No / Name : 205 / 11 KV Kandalgaon GFSS GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2439 | .2572 | .2591 | .1981 | .1715 | .2683 | .3077 |
| 2 | .2134 | .2401 | .2949 | .2286 | .1543 | .2881 | .3125 |
| 3 | .2286 | .2058 | .2883 | .2439 | .1715 | .3222 | .2949 |
| 4 | .2591 | .2572 | .3185 | .3201 | .1886 | .3241 | .2543 |
| 5 | .3506 | .3258 | .3321 | .381 | .2401 | .3239 | .2561 |
| 6 | .4115 | .4287 | .4287 | .4115 | .2915 | .3887 | .2881 |
| 7 | .4572 | .463 | .39 | .4268 | .463 | .3605 | .3185 |
| 8 | .3658 | .4115 | .3841 | .3506 | .4115 | .3005 | .2915 |
| 9 | .2591 | .3258 | .3315 | .3201 | .3258 | .2561 | .2896 |
| 10 | .2572 | | .3201 | .3429 | .2949 | .2347 | .2591 |
| 11 | .2401 | .3258 | .2896 | .2915 | .3353 | .1865 | .2439 |
| 12 | .2229 | .2561 | .2743 | .2743 | .1619 | .16 | .2134 |
| 13 | .2229 | .2401 | .2439 | .2743 | .1802 | .1509 | .1829 |
| 14 | .2058 | .1844 | .2591 | .2572 | .1543 | .1989 | .1677 |
| 15 | .2058 | .1989 | .2286 | .2401 | .1698 | .1886 | .1524 |
| 16 | .1886 | .2229 | 2.1033 | .2915 | .144 | .1966 | .1829 |
| 17 | .2229 | .2429 | .3048 | .3258 | .1943 | .2374 | .2134 |
| 18 | .2572 | .285 | .3506 | .3944 | .2347 | .2543 | .2591 |
| 19 | .3086 | .2949 | .3658 | .3601 | .2105 | .3185 | .3048 |
| 20 | .3944 | .2968 | .3201 | .3086 | .2401 | .3239 | .3506 |
| 21 | .4287 | .3391 | .2896 | .2743 | .2652 | .2883 | .2439 |
| 22 | .4115 | .2267 | .2743 | .2572 | .2347 | .2683 | .2134 |
| 23 | .3429 | .2458 | .2591 | .2401 | .2204 | .3041 | .1981 |
| 24 | .2743 | .3086 | .1989 | .2134 | .2229 | .2543 | .3561 |
| **Max** | **.4572** | **.463** | **2.1033** | **.4268** | **.463** | **.3887** | **.3561** |
| **Min** | **.1886** | **.1844** | **.1989** | **.1981** | **.144** | **.1509** | **.1524** |
| **Avg** | **.2905** | **.2862** | **.3796** | **.3011** | **.2367** | **.2666** | **.2565** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052]** **BU 5894**
**Substation No/ Name :- 212004 / Switching Station Indapur**
**Feeder No / Name : 206 / Kalthan Ag** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2134 | .2915 | .4696 | .3658 | .2881 | .4641 | .4359 |
| 2 | .2286 | .2572 | .4694 | .3963 | .2721 | 1.8785 | 1.6278 |
| 3 | 1.5394 | 1.9547 | .4321 | .4268 | .2458 | 1.8244 | 1.9725 |
| 4 | 1.6309 | 2.0748 | .4961 | .4572 | .1739 | 1.9498 | 1.95 |
| 5 | 1.7223 | 2.0233 | .5765 | .5182 | .2683 | 2.0165 | 1.8564 |
| 6 | 1.7528 | 2.1091 | .5761 | .5639 | .3361 | 2.1026 | 1.9006 |
| 7 | 1.7985 | 2.1948 | .5935 | .5944 | .5344 | 1.9204 | 1.8947 |
| 8 | 1.829 | 2.332 | .5761 | .503 | .4807 | 2.0165 | 2.0405 |
| 9 | 1.8595 | 2.2462 | .4111 | .3963 | .3932 | 2.0454 | 1.7528 |
| 10 | .2572 | .285 | 1.8442 | 1.9719 | 2.0317 | .5243 | .4572 |
| 11 | .3086 | .3605 | 1.9509 | 2.0748 | 2.1125 | .4801 | .3963 |
| 12 | .3429 | .4239 | 2.0424 | 2.2119 | 2.3868 | .4372 | .3658 |
| 13 | .3601 | .3978 | 2.0881 | 2.2805 | 2.2672 | .3201 | .4268 |
| 14 | .3772 | .4049 | 2.1338 | 2.3148 | 2.2874 | .3637 | .4572 |
| 15 | .3944 | .431 | 2.1186 | 2.2805 | 2.0965 | .4359 | .442 |
| 16 | .3601 | .4001 | 2.1033 | 2.2291 | 2.2447 | .4578 | .4268 |
| 17 | .4115 | .5256 | 2.0424 | 2.2119 | 2.2405 | .426 | .4572 |
| 18 | .4801 | .4858 | .4115 | .4458 | .2683 | .4144 | .5182 |
| 19 | .5316 | .4115 | .4725 | .583 | .3239 | .4359 | .5944 |
| 20 | .463 | .5197 | .5182 | .5658 | .407 | .3841 | .503 |
| 21 | .4458 | .3841 | .5639 | .4973 | .3647 | .4696 | .442 |
| 22 | .3944 | .4475 | .4877 | .4287 | .431 | .4641 | .3963 |
| 23 | .3601 | .4748 | .4572 | .4115 | .4001 | .4372 | .3506 |
| 24 | .2591 | .3258 | .421 | .3963 | .3481 | .4578 | .4696 |
| **Max** | **1.8595** | **2.332** | **2.1338** | **2.3148** | **2.3868** | **2.1026** | **2.0405** |
| **Min** | **.2134** | **.2572** | **.4111** | **.3658** | **.1739** | **.3201** | **.3506** |
| **Avg** | **.7634** | **.9067** | **1.0107** | **1.0469** | **.9668** | **.9469** | **.9223** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052]** **BU 5894**
**Substation No/ Name :- 214403 / 33/11KV BAWADA**
**Feeder No / Name : 201 / Sarate** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7545 | .6602 | .6602 | .6602 | .6602 | .6602 | .6602 |
| 2 | .7545 | .6602 | 1.2803 | 1.2803 | 1.3717 | .6602 | .6602 |
| 3 | .7545 | .6602 | 1.3765 | 1.406 | 1.3717 | .6602 | .6602 |
| 4 | | .9431 | 1.6575 | 1.406 | 1.5242 | .9431 | .7545 |
| 5 | | 1.5089 | 1.8861 | 1.7185 | 1.6766 | 1.5089 | 1.1317 |
| 6 | | | 2.3663 | 2.0805 | 2.2291 | | |
| 7 | | | 2.4863 | 2.4215 | 2.6292 | | |
| 8 | | | 2.5149 | 2.7435 | | | |
| 9 | 1.4327 | 1.5089 | 2.4006 | 2.4291 | 2.2377 | | |
| 10 | 1.7747 | 1.8623 | 1.1317 | 1.226 | 1.226 | 1.6604 | 2.0557 |
| 11 | 2.0005 | 1.9528 | 1.3203 | .9431 | .9431 | 1.8623 | 1.8976 |
| 12 | 1.9204 | 1.9204 | .8488 | .7545 | .9431 | 1.709 | 1.8976 |
| 13 | 1.9204 | 1.9204 | .7545 | | .7468 | 1.709 | 1.8976 |
| 14 | 1.8061 | 1.929 | .7545 | .7316 | .7545 | 1.7309 | 1.7747 |
| 15 | 1.7747 | | .7545 | .8488 | .7545 | | 1.7747 |
| 16 | 1.7604 | 1.9814 | .7545 | .8488 | .7545 | 1.6556 | 1.8976 |
| 17 | 1.5604 | 2.1348 | .9431 | 1.0374 | 1.0374 | 1.6975 | 1.8976 |
| 18 | 1.5089 | | 1.226 | 1.4146 | 1.3203 | | 1.4937 |
| 19 | 1.5089 | | 1.5089 | 1.4146 | 1.5089 | | 1.6032 |
| 20 | 1.4146 | 1.3203 | | 1.4146 | 1.3203 | 1.3203 | 1.4146 |
| 21 | 1.1317 | 1.1317 | | 1.0374 | | 1.1317 | 1.226 |
| 22 | .9431 | .9431 | .9431 | .9431 | .9431 | .8488 | 1.0374 |
| 23 | .7545 | .7545 | | .6602 | .7545 | .7545 | .8488 |
| 24 | .7545 | .7545 | .7545 | .7545 | .6602 | .7545 | |
| **Max** | **2.0005** | **2.1348** | **2.5149** | **2.7435** | **2.6292** | **1.8623** | **2.0557** |
| **Min** | **.7545** | **.6602** | **.6602** | **.6602** | **.6602** | **.6602** | **.6602** |
| **Avg** | **1.3805** | **1.3637** | **1.3487** | **1.3119** | **1.2440** | **1.2510** | **1.3991** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052]** **BU 5894**
**Substation No/ Name :- 214403 / 33/11KV BAWADA**
**Feeder No / Name : 202 / Ganeshwadi** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1753 | .1753 | .1791 | .1753 | .1734 | .2572 | .1696 |
| 2 | .1753 | .1753 | 1.4842 | 1.3279 | 1.3717 | .2658 | .1715 |
| 3 | .1791 | .1753 | 1.4842 | 1.406 | 1.3717 | .2658 | .1715 |
| 4 | .1791 | .1772 | 1.5813 | 1.4403 | 1.3717 | .2658 | .1753 |
| 5 | .3658 | .2686 | | 1.5623 | 1.3717 | .362 | .2686 |
| 6 | .3734 | .3734 | 1.7004 | | 1.5813 | .3658 | .3696 |
| 7 | .4668 | .3734 | 1.8976 | 1.8747 | 1.9433 | .3658 | |
| 8 | .4668 | .3696 | 2.0557 | 2.0005 | | .3658 | |
| 9 | .3544 | .2658 | 2.0309 | 2.0062 | 2.0557 | .2658 | |
| 10 | 1.9528 | 1.8976 | .2801 | .1753 | .2658 | 1.6556 | 1.7394 |
| 11 | 2.1605 | 2.1348 | .1772 | .1658 | .1772 | 2.0805 | 2.1872 |
| 12 | 2.1605 | 2.1605 | .1753 | | .1753 | 2.0576 | 2.1872 |
| 13 | 2.2405 | 2.1605 | .1715 | | .1677 | 2.0576 | 2.1872 |
| 14 | 2.2377 | 2.1605 | .1715 | | .1658 | 2.0833 | |
| 15 | 2.2377 | 2.1605 | .1753 | | .1638 | | |
| 16 | 2.21 | 2.1091 | .1753 | | .1638 | | |
| 17 | 2.0062 | 2.0309 | .1791 | | .2401 | 1.929 | 2.0833 |
| 18 | .2743 | .2715 | .2801 | .2715 | .2601 | .2715 | .2715 |
| 19 | .2743 | .2743 | .3658 | .2629 | .3506 | .2658 | .2572 |
| 20 | .2743 | .2715 | | .2629 | .3506 | .2258 | .2572 |
| 21 | .2743 | .181 | | .2601 | .2572 | .1734 | .2486 |
| 22 | .1772 | .181 | .2743 | .2601 | .2572 | .1696 | .2486 |
| 23 | .1715 | .1791 | | .1734 | .2543 | .1696 | .2486 |
| 24 | .1753 | .1696 | .1791 | .1791 | .1734 | .2572 | .1696 |
| **Max** | **2.2405** | **2.1605** | **2.0557** | **2.0062** | **2.0557** | **2.0833** | **2.1872** |
| **Min** | **.1715** | **.1696** | **.1715** | **.1658** | **.1638** | **.1696** | **.1696** |
| **Avg** | **.8985** | **.8623** | **.7509** | **.8120** | **.6375** | **.7353** | **.7451** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214403 / 33/11KV BAWADA**
**Feeder No / Name : 205 / Bhandgaon 2 SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 30-NOV-17 | 01-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .4877 | | .4268 |
| 2 | | .5639 | | |
| 3 | | .5639 | | |
| 4 | | .6516 | | |
| 5 | | .7335 | | |
| 6 | | .9031 | | |
| 7 | | .8802 | | |
| 8 | | .9412 | | |
| 10 | .5639 | | .4534 | |
| 11 | .5411 | | .4868 | |
| 12 | .6954 | | .3487 | |
| 13 | .6859 | | .3487 | |
| 14 | .6763 | | .4134 | |
| 15 | .6668 | | .4001 | |
| 16 | .7773 | | .4877 | |
| 17 | .5106 | | .5106 | |
| 18 | .6087 | | .7545 | |
| 19 | .7125 | | .5182 | |
| 20 | .6097 | | .4801 | |
| 21 | .5401 | | .4134 | |
| 22 | .5401 | | .4201 | |
| 23 | .5401 | | .4201 | |
| 24 | | .4877 | | .4268 |
| **Max** | **.7773** | **.9412** | **.7545** | **.4268** |
| **Min** | **.5106** | **.4877** | **.3487** | **.4268** |
| **Avg** | **.6192** | **.6903** | **.4611** | **.4268** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052]** **BU 5894**
**Substation No/ Name :- 214403 / 33/11KV BAWADA**
**Feeder No / Name : 206 / Ganeshwadi 2** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2343 | .1372 | .2201 | .2172 | .2229 | .2172 | .2229 |
| 2 | .2343 | .1372 | .7716 | .7811 | .724 | .1543 | .2201 |
| 3 | .2343 | .1486 | .7716 | .7811 | .724 | .1543 | .2229 |
| 4 | .2343 | | .7811 | .7811 | .724 | .1581 | .2258 |
| 5 | .2515 | .1734 | .7811 | 1.0669 | .7621 | .1715 | .2343 |
| 6 | .2572 | .1753 | .8802 | .9145 | .7811 | .1772 | .2543 |
| 7 | .2515 | .1753 | .9374 | 1.0669 | .9602 | .1829 | |
| 8 | .2515 | .1734 | 1.0669 | 1.0936 | | .2772 | |
| 9 | .2 | .2058 | 1.2498 | 1.1717 | 1.0669 | .2315 | |
| 10 | 1.2651 | 1.2803 | .1486 | .1257 | .1658 | 1.086 | 1.2803 |
| 11 | 1.2498 | 1.4232 | .1562 | .1486 | .1677 | 1.2955 | 1.2346 |
| 12 | 1.2651 | 1.4746 | .1543 | | .1715 | 1.3375 | 1.2346 |
| 13 | 1.2651 | 1.4575 | .1505 | | .1334 | 1.3375 | 1.2346 |
| 14 | 1.3717 | 1.4403 | .1524 | | .1353 | 1.2955 | |
| 15 | 1.3889 | 1.4403 | .1524 | | .1467 | | |
| 16 | 1.4232 | 1.4232 | .1524 | | .1486 | | |
| 17 | 1.3889 | 1.2651 | .1524 | | .2229 | 1.2193 | 1.0802 |
| 18 | .1581 | .1524 | .2629 | .2743 | .2372 | .1715 | .2686 |
| 19 | .1543 | .2086 | .3201 | .2286 | .1562 | .2029 | .2315 |
| 20 | .1334 | .1972 | | .2286 | .2343 | .2 | .2315 |
| 21 | .1353 | .2172 | | .2229 | .2315 | .2029 | .3239 |
| 22 | .1334 | .2172 | .2172 | .2229 | .2258 | .2172 | .3239 |
| 23 | .1334 | .2172 | | .2229 | .2143 | .2172 | .3239 |
| 24 | .2343 | .1334 | .2201 | .2172 | .2229 | .2143 | .2229 |
| **Max** | **1.4232** | **1.4746** | **1.2498** | **1.1717** | **1.0669** | **1.3375** | **1.2803** |
| **Min** | **.1334** | **.1334** | **.1486** | **.1257** | **.1334** | **.1543** | **.2201** |
| **Avg** | **.5770** | **.6032** | **.4619** | **.5425** | **.3817** | **.4873** | **.5206** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214403 / 33/11KV BAWADA**
**Feeder No / Name : 207 / Lakhewadi SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1753 | .1772 | .0886 | .1715 | .1772 | .181 | .1734 |
| 2 | .1753 | .1772 | .8069 | .8916 | .7859 | .1791 | .1715 |
| 3 | .1753 | .1772 | .8916 | .8916 | .7859 | .1791 | .1734 |
| 4 | .1791 | .1791 | .8916 | .8688 | .7859 | .1791 | .1772 |
| 5 | .2801 | .2772 | .9907 | .8916 | .8573 | .2743 | .2715 |
| 6 | .3734 | .2829 | 1.0936 | 1.0669 | 1.0669 | .3734 | .3734 |
| 7 | .2801 | .2801 | 1.2193 | 1.2955 | 1.2346 | .3772 | |
| 8 | .2801 | .2743 | 1.448 | 1.3717 | | .3772 | |
| 9 | .1791 | .1791 | 1.4861 | 1.3717 | 1.3375 | .2715 | |
| 10 | 1.1888 | 1.2193 | .1829 | .1791 | .1791 | 1.0002 | 1.1574 |
| 11 | 1.3546 | 1.2955 | .0905 | .1753 | .1791 | 1.1431 | 1.1888 |
| 12 | 1.448 | 1.3117 | .0876 | .1753 | .1791 | 1.1431 | 1.1888 |
| 13 | 1.448 | 1.2955 | .0867 | .0772 | .0857 | 1.1584 | 1.1888 |
| 14 | 1.3937 | 1.3546 | .1715 | .0772 | .0857 | 1.1584 | 1.0402 |
| 15 | 1.3375 | 1.3717 | .1791 | .1753 | .1677 | 1.247 | 1.0402 |
| 16 | 1.2793 | 1.4118 | .1753 | .1753 | .1677 | .9145 | 1.0402 |
| 17 | 1.2193 | 1.4118 | .1753 | .1753 | .1715 | 1.2193 | |
| 18 | .1848 | .1829 | .2743 | .1867 | .1791 | .2801 | .3658 |
| 19 | .1848 | .2772 | .2743 | .181 | .2772 | .3658 | .362 |
| 20 | .1829 | .181 | | .181 | .2772 | .2715 | .2715 |
| 21 | .1772 | .1829 | | .1772 | .1829 | .1791 | .2543 |
| 22 | .1734 | .1829 | .1791 | .1772 | .1829 | .1734 | .2543 |
| 23 | .1715 | .181 | | .1772 | .1848 | .1734 | .1696 |
| 24 | .1791 | .1677 | .0886 | .1715 | .1772 | .1829 | .1734 |
| **Max** | **1.448** | **1.4118** | **1.4861** | **1.3717** | **1.3375** | **1.247** | **1.1888** |
| **Min** | **.1715** | **.1677** | **.0867** | **.0772** | **.0857** | **.1734** | **.1696** |
| **Avg** | **.5842** | **.5847** | **.5182** | **.4701** | **.4221** | **.5418** | **.5518** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214409 / 33 KV PIMPRI BK**
**Feeder No / Name : 201 / Ganeshwadi Ag Feeder SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0876 | .0762 | .0914 | .0819 | .0857 | .0762 | .0819 |
| 2 | .0876 | .0762 | 1.4232 | 1.3441 | 1.2431 | .0762 | .0819 |
| 3 | .0857 | .0762 | 1.406 | 1.3927 | 1.2431 | .0762 | .0819 |
| 4 | .0857 | .0762 | 1.406 | 1.3927 | 1.2431 | .0762 | .0819 |
| 5 | .0857 | .0762 | 1.5023 | 1.5565 | 1.2431 | .0762 | .0819 |
| 6 | .0857 | .0762 | 1.4842 | 1.5565 | 1.2431 | .0762 | .0819 |
| 7 | .0857 | .0762 | 1.5623 | 1.5565 | 1.2289 | .0762 | |
| 8 | .0857 | .0762 | 1.6385 | 1.5565 | 1.3108 | .0762 | |
| 9 | .0762 | .0819 | 1.6385 | 1.5927 | | | |
| 10 | 1.5242 | 1.5623 | .0819 | | .0762 | 1.2289 | 1.6289 |
| 11 | | 1.7185 | | .0857 | | 1.4232 | 1.5813 |
| 12 | 1.6766 | | | .0857 | .0762 | 1.6385 | 1.5623 |
| 13 | | 1.8185 | | .0857 | | 1.7204 | 1.6404 |
| 14 | 1.6766 | | | | .0762 | 1.7204 | 1.6404 |
| 15 | | 1.8747 | | | | 1.7204 | |
| 16 | | | | | .0762 | 1.7204 | 1.6404 |
| 17 | 1.6004 | 1.8976 | | .0857 | .0762 | 1.7204 | 1.5432 |
| 18 | | .0857 | .0819 | .0876 | .0762 | .0819 | .0857 |
| 19 | | .0914 | .0848 | | | .0819 | |
| 20 | | | .0819 | | | .0819 | |
| 21 | | | .0819 | .0876 | | .0819 | .0914 |
| 22 | | .0914 | | .0876 | | .0819 | |
| 23 | .0762 | .0914 | .4096 | .0876 | .0762 | .0819 | .0905 |
| 24 | .0876 | .0762 | .0914 | .0819 | .0857 | .0762 | .0819 |
| **Max** | **1.6766** | **1.8976** | **1.6385** | **1.5927** | **1.3108** | **1.7204** | **1.6404** |
| **Min** | **.0762** | **.0762** | **.0819** | **.0819** | **.0762** | **.0762** | **.0819** |
| **Avg** | **.4938** | **.5263** | **.8166** | **.7114** | **.5913** | **.6117** | **.7105** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214409 / 33 KV PIMPRI BK**
**Feeder No / Name : 202 / Ozare -Pimpri Bk- SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3429 | .3048 | .362 | .4096 | .3429 | .3048 | .4096 |
| 2 | .3429 | .3048 | 1.7185 | 1.8023 | 1.3927 | .3048 | .4096 |
| 3 | .4191 | .3048 | 1.6766 | 1.8023 | 1.4746 | .3048 | .3277 |
| 4 | .4191 | .381 | 1.7747 | 1.8023 | 1.4746 | .381 | .3277 |
| 5 | .503 | .381 | 1.8519 | 1.8842 | 1.5565 | .381 | .4096 |
| 6 | .503 | .4572 | 2.0062 | | 1.6385 | .4572 | |
| 7 | .503 | .4572 | 2.1605 | 2.2939 | 1.7004 | .4572 | .4096 |
| 8 | .503 | .381 | 2.2939 | 2.2939 | 1.8623 | .4572 | |
| 9 | .3953 | .4287 | 2.2939 | 2.4577 | | .4915 | |
| 10 | 2.1338 | 2.2138 | .4096 | | .3048 | 1.4746 | 1.8976 |
| 11 | | 2.3434 | .3277 | .2543 | | 1.5813 | 1.8747 |
| 12 | 2.4387 | | .3277 | .2543 | .1524 | 1.9662 | 2.0309 |
| 13 | | 2.4215 | .3277 | .2543 | | 2.13 | 2.1091 |
| 14 | 2.4387 | 2.5777 | .3277 | .2543 | .1524 | 2.13 | 2.0833 |
| 15 | | | .3277 | .2543 | | 2.13 | |
| 16 | | 2.5463 | .3277 | .2543 | .1524 | 2.13 | 2.0062 |
| 17 | 2.2862 | 2.5777 | .3277 | .3391 | .2286 | 2.13 | 2.0833 |
| 18 | | .543 | .3277 | .4287 | .3048 | .4915 | .4287 |
| 19 | | | .4096 | | | .4915 | |
| 20 | | .6401 | .4096 | | | | |
| 21 | | | .4096 | .3429 | | .4096 | .5144 |
| 22 | | .4525 | .4096 | .3429 | | .4096 | |
| 23 | .3048 | .3429 | .4096 | .3429 | .3048 | .4572 | .4572 |
| 24 | .3429 | .3048 | .3429 | .4096 | .3429 | .3048 | |
| **Max** | **2.4387** | **2.5777** | **2.2939** | **2.4577** | **1.8623** | **2.13** | **2.1091** |
| **Min** | **.3048** | **.3048** | **.3277** | **.2543** | **.1524** | **.3048** | **.3277** |
| **Avg** | **.9251** | **1.0182** | **.8983** | **.9239** | **.8366** | **.9468** | **1.1112** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214409 / 33 KV PIMPRI BK**
**Feeder No / Name : 203 / LIS -Shriram Lift- SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0876 | .0857 | .0905 | .0819 | .0857 | .0857 | .0819 |
| 2 | .5087 | .5144 | .0905 | .0819 | .0857 | .4287 | .0819 |
| 3 | .503 | .5144 | .0895 | .0819 | .0857 | .4287 | .2458 |
| 4 | .503 | .5144 | .0905 | .0819 | .0857 | .4287 | .2458 |
| 5 | .503 | .5144 | .0905 | .0819 | .0857 | .4287 | .2458 |
| 6 | .503 | .5144 | .0905 | | .0857 | .4287 | .2458 |
| 7 | .503 | .5144 | .0857 | .0819 | .0857 | .4287 | .2458 |
| 8 | .503 | .5144 | .0819 | .0819 | .0857 | .4287 | .4096 |
| 9 | .5144 | .4744 | .0819 | .0876 | | .4096 | .4287 |
| 10 | .0857 | .0857 | .4915 | | .5144 | .0819 | .0857 |
| 11 | | .0857 | .4915 | .5868 | | .0819 | |
| 12 | .0857 | | .4915 | .5868 | .5144 | .0819 | |
| 13 | | | .4915 | .5868 | | .0819 | |
| 14 | .0857 | | .4915 | .5868 | .5144 | .0819 | .0914 |
| 15 | | | .5487 | .5868 | | .0819 | |
| 16 | | | .4915 | .5868 | .5144 | .0819 | |
| 17 | .0857 | | .4915 | .5868 | .5144 | .0819 | |
| 18 | | .0857 | .0819 | .0876 | .0857 | .0819 | .0914 |
| 19 | | | .0819 | | | .0819 | |
| 20 | | | .0819 | | | .0819 | |
| 21 | | | .0819 | .0876 | | .0819 | |
| 22 | | | .0819 | .0876 | | .0819 | |
| 23 | .0857 | .0914 | .0819 | .0857 | .0857 | .0819 | .0857 |
| 24 | .0876 | .0857 | .0905 | .0819 | .0857 | .0857 | .0819 |
| **Max** | **.5144** | **.5144** | **.5487** | **.5868** | **.5144** | **.4287** | **.4287** |
| **Min** | **.0857** | **.0857** | **.0819** | **.0819** | **.0857** | **.0819** | **.0819** |
| **Avg** | **.3097** | **.3282** | **.2234** | **.2599** | **.2197** | **.1970** | **.1905** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214409 / 33 KV PIMPRI BK**
**Feeder No / Name : 204 / Girvi SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3429 | .3048 | .3429 | .4096 | .3429 | .3429 | .4096 |
| 2 | 1.0898 | 1.0669 | .3582 | .3277 | .3429 | .9145 | .9831 |
| 3 | 1.1469 | 1.1431 | .4287 | .3277 | .3391 | .9145 | .9831 |
| 4 | 1.1469 | 1.1431 | .5258 | .3277 | .4239 | .9145 | .9831 |
| 5 | 1.1469 | 1.1431 | .6859 | .3277 | .5868 | .9145 | .9831 |
| 6 | 1.2289 | 1.2289 | .663 | .4096 | .7545 | 1.0669 | 1.1469 |
| 7 | 1.4746 | 1.2955 | .7716 | .4915 | .7545 | 1.1431 | 1.2289 |
| 8 | 1.5565 | 1.5242 | .6554 | .4915 | .6706 | 1.2193 | 1.2289 |
| 9 | 1.2955 | | .6554 | .5144 | | 1.2289 | 1.1717 |
| 10 | .4096 | | 1.3108 | | 1.2289 | .4096 | .3429 |
| 11 | | | 1.4746 | 1.3927 | | .3953 | .1715 |
| 12 | .1524 | | 1.6385 | 1.4746 | 1.2955 | .3277 | .1734 |
| 13 | | | 1.6385 | 1.3927 | | .3277 | |
| 14 | .1638 | | 1.6385 | 1.3927 | 1.2955 | .3277 | |
| 15 | | | 1.6385 | 1.3927 | | .3277 | |
| 16 | | | 1.6385 | 1.3927 | 1.2193 | .3277 | |
| 17 | .2458 | | 1.6385 | 1.3927 | 1.2193 | .3277 | .3391 |
| 18 | | | .4096 | .6001 | .381 | .4096 | .6335 |
| 19 | | | .4096 | | | .4096 | |
| 20 | | | .4096 | | | | |
| 21 | | | .4096 | .3429 | | .4915 | .4525 |
| 22 | | | .4572 | .3429 | | .4915 | |
| 23 | .3048 | .3429 | .4096 | .3429 | .3048 | .4096 | .3506 |
| 24 | .3429 | .3048 | .362 | .4096 | .3429 | .3048 | .4096 |
| **Max** | **1.5565** | **1.5242** | **1.6385** | **1.4746** | **1.2955** | **1.2289** | **1.2289** |
| **Min** | **.1524** | **.3048** | **.3429** | **.3277** | **.3048** | **.3048** | **.1715** |
| **Avg** | **.8032** | **.9497** | **.8571** | **.7379** | **.7189** | **.6064** | **.7054** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052]** **BU 5894**
**Substation No/ Name :- 214410 / 33/11KV BHATNIMGAON**
**Feeder No / Name : 201 / Bhat Nimgaon** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7621 | .6859 | | | | .8383 | .6859 |
| 2 | .7621 | .6859 | | | | | .6859 |
| 3 | .7621 | .6859 | | | | .8383 | .7621 |
| 4 | .7621 | .7621 | | | | .8383 | .7621 |
| 5 | .7621 | .7621 | | | | .9145 | .7621 |
| 6 | .7621 | .7621 | | | | .9145 | .7621 |
| 7 | .7621 | .9145 | | | | .9145 | .7621 |
| 8 | .7621 | .9145 | | | | .9145 | .7621 |
| 10 | | | 1.1022 | .9145 | .8383 | | |
| 11 | | | 1.1022 | .9145 | .8383 | | |
| 12 | | | 1.0174 | .9907 | .9145 | | |
| 13 | | | | .9907 | .9145 | | |
| 14 | | | 1.0174 | .9907 | .9145 | | |
| 15 | | | 1.1869 | .9907 | .9907 | | |
| 16 | | | 1.1869 | .9907 | .9907 | | |
| 17 | | | 1.1869 | .9907 | 1.1431 | | |
| 18 | | | 1.1869 | | | | |
| **Max** | **.7621** | **.9145** | **1.1869** | **.9907** | **1.1431** | **.9145** | **.7621** |
| **Min** | **.7621** | **.6859** | **1.0174** | **.9145** | **.8383** | **.8383** | **.6859** |
| **Avg** | **.7621** | **.7716** | **1.1234** | **.9717** | **.9431** | **.8818** | **.7431** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214410 / 33/11KV BHATNIMGAON**
**Feeder No / Name : 202 / Babhulgaon SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2572 | .2572 | .2429 | .3391 | .2572 | .2572 | .3429 |
| 2 | .2572 | .2572 | .2429 | 1.4413 | 1.1431 | .5144 | .4287 |
| 3 | .2572 | .5144 | 1.4575 | 1.5261 | 1.2193 | .5144 | .381 |
| 4 | .3429 | .3429 | 1.6194 | 1.6956 | 1.2193 | .5144 | .4572 |
| 5 | .5144 | .3429 | 1.6194 | 1.6956 | 1.3717 | .6859 | .4572 |
| 6 | .5144 | .5144 | 1.9433 | 2.0348 | 1.6766 | .6859 | .4572 |
| 7 | .6859 | .5144 | 1.9433 | 2.0348 | 1.9052 | .6859 | .381 |
| 8 | .6001 | .5144 | 1.7814 | 2.2043 | 2.0576 | .5144 | .4287 |
| 9 | .6001 | .4287 | 1.7004 | 2.2043 | 1.9052 | .4287 | .3429 |
| 10 | 2.0576 | 2.0243 | .3391 | .3429 | .3429 | 1.5242 | 1.8652 |
| 11 | 2.1338 | 2.1052 | .3391 | | .2286 | 1.7528 | 1.8652 |
| 12 | 2.0576 | 2.1862 | | | .1524 | 1.829 | 2.2043 |
| 13 | 1.9814 | 2.1862 | | | .1524 | 1.9814 | 2.0348 |
| 14 | 1.9814 | 2.1052 | .5087 | | .1715 | 1.829 | 2.2043 |
| 15 | 1.9814 | 2.1052 | .5087 | | .1715 | 1.829 | 2.2043 |
| 16 | 1.9814 | 2.1052 | | | .1715 | 1.7528 | 2.2043 |
| 17 | 2.0576 | 2.1862 | | .2572 | .2286 | 1.6004 | 2.0348 |
| 18 | .1715 | | | | .2572 | .1715 | .3391 |
| 19 | .1715 | | .3391 | .5144 | .2572 | .1715 | .3391 |
| 20 | .2572 | .2429 | .3391 | .5144 | .2572 | .1715 | .3391 |
| 21 | .2572 | .2429 | | .4287 | .2572 | .1715 | |
| 22 | .1715 | .2429 | | .3429 | | .1715 | |
| 23 | .1715 | .2429 | | .2572 | | .2572 | .1715 |
| 24 | .2572 | .1715 | 1.6194 | .3391 | .2572 | .2572 | .2572 |
| **Max** | **2.1338** | **2.1862** | **1.9433** | **2.2043** | **2.0576** | **1.9814** | **2.2043** |
| **Min** | **.1715** | **.1715** | **.2429** | **.2572** | **.1524** | **.1715** | **.1715** |
| **Avg** | **.9050** | **.9924** | **1.0340** | **1.0690** | **.7118** | **.8447** | **.9882** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052]** **BU 5894**
**Substation No/ Name :- 214410 / 33/11KV BHATNIMGAON**
**Feeder No / Name : 203 / Rakhundemala AG** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0857 | .0857 | .081 | .0848 | .0857 | .0762 | .0857 |
| 2 | .2286 | .2286 | .081 | .0848 | .0857 | .3048 | .2286 |
| 3 | .2286 | .2286 | .081 | .0848 | .0857 | .3048 | .2286 |
| 4 | .2286 | .3048 | .081 | .0848 | .0857 | .381 | .3048 |
| 5 | .3048 | .3048 | .081 | .0848 | .0857 | .381 | .3048 |
| 6 | .381 | .3048 | .081 | .0848 | .0857 | .381 | .3048 |
| 7 | .381 | .381 | .081 | .0848 | .0857 | .381 | .3048 |
| 8 | .381 | .381 | .081 | .0848 | .0857 | .381 | .3048 |
| 9 | .381 | .381 | .081 | .0848 | .0857 | .381 | .3048 |
| 10 | .0857 | .081 | .4239 | .381 | .3048 | .0857 | .0848 |
| 11 | .0857 | .081 | .4239 | .4572 | .381 | .0857 | .0848 |
| 12 | .0857 | .081 | .4239 | .4572 | .381 | .0857 | |
| 13 | .0857 | .081 | | .4572 | .381 | .0857 | .0848 |
| 14 | .0857 | .081 | .4239 | .4572 | .381 | .0857 | |
| 15 | .0762 | .081 | .4239 | .4572 | .381 | .0857 | .0848 |
| 16 | .0762 | .081 | | .4572 | .381 | .0857 | .0848 |
| 17 | .0857 | .081 | | .381 | .3048 | .0857 | .0848 |
| 18 | .0857 | .081 | | | .0857 | .0857 | .0848 |
| 19 | .0857 | .081 | .0848 | .0857 | .0857 | .0857 | .0848 |
| 20 | .0857 | .081 | .0848 | .0857 | .0857 | .0857 | .0848 |
| 21 | .0857 | .081 | | .0857 | .0857 | .0857 | |
| 22 | .0857 | .081 | | .0857 | | .0857 | |
| 23 | .0857 | .081 | | .0857 | | .0857 | .0857 |
| 24 | .0857 | .0476 | 2.4291 | .0848 | .0857 | .0857 | .0857 |
| **Max** | **.381** | **.381** | **2.4291** | **.4572** | **.381** | **.381** | **.3048** |
| **Min** | **.0762** | **.0476** | **.081** | **.0848** | **.0857** | **.0762** | **.0848** |
| **Avg** | **.1611** | **.1576** | **.3204** | **.2079** | **.1862** | **.1774** | **.1653** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052]** **BU 5894**
**Substation No/ Name :- 214410 / 33/11KV BHATNIMGAON**
**Feeder No / Name : 204 / Chandrabhaga AG** **FEEDER SEPERATION/PURE AG**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0857 | .0857 | .081 | .0848 | .0857 | .0857 | .0857 |
| 2 | .3048 | .2572 | .081 | .0848 | .0857 | .381 | .2286 |
| 3 | .3048 | .2286 | .081 | .0848 | .0857 | .381 | .3048 |
| 4 | .3048 | .3048 | .081 | .0848 | .0857 | .381 | .3048 |
| 5 | .3048 | .3048 | .0838 | .0848 | .0857 | .4572 | .3048 |
| 6 | .3048 | .3048 | .081 | .0848 | .0857 | .4572 | .3048 |
| 7 | .3048 | .381 | .081 | .0848 | .0857 | .4572 | .381 |
| 8 | .381 | .381 | .081 | .0848 | .0857 | .4572 | .4572 |
| 9 | .381 | .381 | .081 | .0848 | .0857 | .4572 | .4572 |
| 10 | .0857 | .081 | .3391 | .381 | .4572 | .0857 | .0848 |
| 11 | .0857 | .0934 | .3391 | .4572 | .4572 | .0857 | .0848 |
| 12 | .0857 | .081 | .5087 | .4572 | .4572 | .0857 | .0848 |
| 13 | .0857 | .081 | | .4572 | .4572 | .0857 | .0848 |
| 14 | .0857 | .081 | .5087 | .4572 | .4572 | .0857 | .0848 |
| 15 | .0857 | .081 | .5087 | .4572 | .5335 | .0857 | .0848 |
| 16 | .0857 | .081 | | .4572 | .5335 | | .0848 |
| 17 | .0857 | .081 | | .4572 | .0857 | .0857 | .0848 |
| 18 | .0857 | .081 | | | .0857 | .0857 | .0848 |
| 19 | .0857 | .081 | .0848 | .0857 | .0857 | .0857 | .0848 |
| 20 | .0857 | .081 | .0848 | .0857 | .0857 | .0857 | .0848 |
| 21 | .0857 | .081 | | .0857 | .0857 | .0857 | |
| 22 | .0857 | .081 | | .0857 | | .0857 | |
| 23 | .0857 | .0838 | | .0857 | | .0857 | .0857 |
| 24 | .0857 | .0857 | .081 | .0848 | .0857 | .0857 | .0857 |
| **Max** | **.381** | **.381** | **.5087** | **.4572** | **.5335** | **.4572** | **.4572** |
| **Min** | **.0857** | **.081** | **.081** | **.0848** | **.0857** | **.0857** | **.0848** |
| **Avg** | **.1651** | **.1610** | **.1875** | **.2112** | **.2108** | **.2050** | **.1788** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214410 / 33/11KV BHATNIMGAON**
**Feeder No / Name : 205 / Bhatnimgaon GFSS GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | .2572 |
| Max | .2572 |
| Min | .2572 |
| Avg | .2572 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214426 / 33/11KV KATI S/STN**
**Feeder No / Name : 201 / kati SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5853 | .6219 | .6219 | .6036 | .5304 | .4973 | |
| 2 | 1.2437 | .5853 | .6219 | .6036 | .547 | .9116 | 1.1012 |
| 3 | 1.2803 | .5853 | .6584 | .6219 | .547 | .9116 | |
| 4 | 1.3169 | .6584 | .7682 | .6219 | .6464 | 1.0277 | |
| 5 | 1.7193 | .8779 | .9511 | .7682 | .7956 | 1.2266 | 1.4251 |
| 6 | 2.4508 | 1.2254 | 1.1706 | 1.1706 | .9945 | 1.5581 | 1.8138 |
| 7 | 2.7435 | 1.4632 | 1.4266 | 1.2986 | 1.1934 | 2.2542 | 2.5263 |
| 8 | 3.0727 | 1.39 | 1.3169 | 1.2803 | | 2.3537 | 2.6397 |
| 9 | 2.6707 | .9389 | .9389 | 1.0974 | .8886 | 2.2611 | 2.3703 |
| 10 | .57 | 2.0081 | 2.1052 | 2.2314 | 1.9271 | .5487 | .5636 |
| 11 | .4694 | | 2.6397 | 2.4086 | 2.4291 | .4752 | .4641 |
| 12 | .4024 | 2.5587 | 2.5587 | 2.7801 | 2.1376 | .4752 | .4475 |
| 13 | .3688 | 2.8664 | | 2.4741 | 2.4129 | .3932 | .431 |
| 14 | .4694 | | | 2.8166 | 2.2672 | | .4144 |
| 15 | .503 | 2.9473 | 2.3805 | 2.8349 | 2.2024 | .3768 | .4641 |
| 16 | .5197 | 2.753 | 2.2186 | 2.3868 | 2.17 | .4752 | .4973 |
| 17 | .695 | 2.6216 | 2.2447 | 2.2874 | 1.9559 | .5967 | .6299 |
| 18 | .9694 | .9511 | .7701 | .8951 | .7625 | .9282 | .9614 |
| 19 | 1.2071 | 1.2071 | 1.0608 | 1.0277 | .8785 | .9448 | .9945 |
| 20 | .9511 | .9511 | .9145 | .8288 | .7293 | .7293 | .7956 |
| 21 | .8048 | .8779 | .823 | .663 | .6299 | .6299 | .5967 |
| 22 | .695 | .6584 | .7316 | .5801 | .4973 | .5636 | |
| 23 | .6219 | .6219 | .6219 | .5304 | .4807 | .5304 | .5138 |
| 24 | .5853 | .6219 | .6219 | .6036 | .5304 | .4807 | .5138 |
| **Max** | **3.0727** | **2.9473** | **2.6397** | **2.8349** | **2.4291** | **2.3537** | **2.6397** |
| **Min** | **.3688** | **.5853** | **.6219** | **.5304** | **.4807** | **.3768** | **.4144** |
| **Avg** | **1.1215** | **1.3632** | **1.2803** | **1.3923** | **1.2241** | **.9196** | **1.0082** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214426 / 33/11KV KATI S/STN**
**Feeder No / Name : 202 / Reda SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3109 | .3109 | .3292 | .3109 | .3149 | .2984 | |
| 2 | .3292 | .6219 | .9145 | .7537 | .7956 | .2984 | .3018 |
| 3 | .3292 | .7316 | .9145 | .8779 | .7956 | .2984 | |
| 4 | .4024 | .9511 | 1.0059 | .8573 | .8619 | .3315 | |
| 5 | .6401 | 1.1706 | 1.0159 | 1.0486 | 1.0774 | .4973 | .503 |
| 6 | .7682 | 1.5546 | 1.4266 | 1.1797 | 1.326 | .7127 | .6874 |
| 7 | .9145 | 2.0119 | 1.5074 | 2.0119 | 1.6244 | .779 | .788 |
| 8 | .8048 | 2.13 | 2.0325 | 2.0972 | | .6796 | .7209 |
| 9 | .6036 | 1.5708 | 2.1052 | 2.1399 | 1.668 | .4915 | .5636 |
| 10 | 1.4089 | .3353 | .3856 | .3658 | .4024 | 1.0322 | 1.1437 |
| 11 | 1.8138 | | .3018 | .2926 | .285 | 1.4091 | 1.1934 |
| 12 | 1.8947 | .2515 | .2347 | .2926 | .2683 | 1.6385 | 1.5083 |
| 13 | 1.7814 | .218 | .2347 | .2378 | .218 | 1.3599 | 1.5746 |
| 14 | 1.7328 | | | .2378 | .218 | 1.4746 | 1.6244 |
| 15 | 1.7166 | .2012 | .2515 | | .2347 | 1.5238 | 1.5746 |
| 16 | 1.7652 | .2347 | .3018 | .2543 | .2915 | 1.5893 | 1.5581 |
| 17 | 1.6876 | .3292 | .3292 | .3315 | .3315 | 1.5415 | 1.4752 |
| 18 | .4755 | .4207 | .6219 | .8785 | .4807 | .6133 | .5138 |
| 19 | .6584 | .7316 | .7316 | .6299 | .5967 | .5967 | .6274 |
| 20 | .5487 | .567 | .6401 | .4973 | .4807 | .4641 | .4807 |
| 21 | .4755 | .5121 | .5121 | .4144 | .3647 | .3812 | .3315 |
| 22 | .4024 | .3475 | .4024 | .3647 | .3315 | .2818 | .2984 |
| 23 | .3292 | .3292 | .3292 | .3149 | .2984 | .2818 | .2652 |
| 24 | .3292 | .3292 | 1.5242 | .3292 | .3149 | .2984 | .2818 |
| **Max** | **1.8947** | **2.13** | **2.1052** | **2.1399** | **1.668** | **1.6385** | **1.6244** |
| **Min** | **.3109** | **.2012** | **.2347** | **.2378** | **.218** | **.2818** | **.2652** |
| **Avg** | **.9218** | **.7209** | **.7849** | **.7269** | **.5905** | **.7864** | **.8579** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214426 / 33/11KV KATI S/STN**
**Feeder No / Name : 203 / Shetphal Haveli SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2801 | .3841 | .2934 | .2934 | .3064 | .298 | |
| 2 | .9231 | .3201 | .2934 | .439 | .3243 | .7042 | .6602 |
| 3 | .9339 | .439 | .3018 | .3201 | .3243 | .7042 | |
| 4 | 1.0486 | .4268 | .3658 | .3841 | .442 | .7682 | |
| 5 | 1.2742 | .5182 | .442 | .4401 | .6154 | .9602 | .9172 |
| 6 | 1.6057 | .7209 | .5487 | .5357 | .7125 | 1.2483 | 1.1544 |
| 7 | 1.9753 | .9511 | .6097 | .7287 | .7682 | 1.7238 | 1.6129 |
| 8 | 2.0317 | .6706 | .7811 | .7011 | | 1.8351 | 1.7869 |
| 9 | 1.7859 | .5365 | | .6249 | .5944 | 1.704 | 1.7284 |
| 10 | .3734 | 1.7711 | 1.5181 | 1.39 | 1.3592 | .4588 | .3477 |
| 11 | .285 | | 1.9685 | 1.5699 | 1.5546 | .3277 | .5944 |
| 12 | .2286 | 1.9757 | 1.9372 | 1.8515 | 1.5935 | .3277 | .2286 |
| 13 | .212 | 1.8785 | 1.8185 | 1.7695 | 1.7185 | .3277 | .1943 |
| 14 | .208 | | | 1.7604 | 2.0729 | .3277 | .1829 |
| 15 | .2515 | 1.6446 | 1.6248 | 1.8842 | 1.6248 | .3277 | .2286 |
| 16 | .2743 | 1.8343 | 1.6248 | 1.7185 | 1.6762 | .3277 | .2401 |
| 17 | .4054 | 1.8623 | 1.5074 | 1.6049 | 1.4198 | .4268 | .3536 |
| 18 | .5487 | .4268 | .5792 | .6173 | .4725 | .6371 | .5937 |
| 19 | .5761 | .7537 | .5761 | .6706 | .5639 | .6097 | .6173 |
| 20 | .4534 | .5335 | .4938 | .5716 | .4666 | .4715 | .4512 |
| 21 | .4512 | .439 | .4268 | .4287 | .3467 | .4058 | .3201 |
| 22 | .3292 | .3201 | .3292 | .3681 | .3239 | .3018 | .2934 |
| 23 | .2801 | .3109 | .3067 | .3155 | .3109 | .2972 | .2934 |
| 24 | .2801 | .2801 | .3064 | .3018 | .3155 | .2743 | .2972 |
| **Max** | **2.0317** | **1.9757** | **1.9685** | **1.8842** | **2.0729** | **1.8351** | **1.7869** |
| **Min** | **.208** | **.2801** | **.2934** | **.2934** | **.3064** | **.2743** | **.1829** |
| **Avg** | **.7090** | **.8635** | **.8479** | **.8871** | **.8655** | **.6581** | **.6236** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214426 / 33/11KV KATI S/STN**
**Feeder No / Name : 204 / 11 kv Pandharwadi SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2012 | .2012 | .2378 | .2378 | .2195 | .2075 | |
| 2 | .1829 | .439 | .6767 | .6767 | .5921 | .2012 | .1991 |
| 3 | .1829 | .5487 | .6687 | .7316 | .5921 | .2012 | |
| 4 | .2926 | .7682 | .823 | .9877 | .6882 | .2896 | |
| 5 | .4024 | .8596 | .9511 | 1.0159 | .8573 | .3856 | .4031 |
| 6 | .4755 | 1.134 | 1.1706 | 1.1336 | 1.0288 | .5258 | .5611 |
| 7 | .5487 | 1.3352 | 1.2803 | 1.4266 | 1.3176 | .6089 | .5973 |
| 8 | .4938 | 1.6461 | 1.4998 | 1.4746 | | .4588 | .5373 |
| 9 | .4024 | 1.166 | 1.4419 | 1.3443 | 1.3599 | .3768 | .3982 |
| 10 | 1.0279 | .2957 | .2378 | .2743 | .2587 | .9995 | .9172 |
| 11 | 1.3117 | | .2218 | | .2772 | 1.278 | .8421 |
| 12 | 1.2963 | .3077 | .2218 | .2012 | .2402 | 1.2125 | 1.1873 |
| 13 | 1.3603 | .3109 | .2241 | .2195 | .2218 | 1.278 | 1.186 |
| 14 | 1.3916 | | | .1829 | .2241 | 1.1961 | 1.1702 |
| 15 | 1.2431 | .2427 | .2218 | .2012 | .2218 | 1.2944 | 1.1843 |
| 16 | 1.2342 | .3018 | .2427 | .2743 | .2218 | 1.2125 | 1.1203 |
| 17 | 1.4632 | .3658 | .2926 | .3174 | .2772 | 1.2883 | 1.0883 |
| 18 | .3109 | .3292 | .4024 | .4163 | .3582 | .4481 | .3881 |
| 19 | .4755 | .4207 | .3658 | .4207 | .439 | .4024 | .4435 |
| 20 | .3658 | .4024 | .3292 | .362 | .3326 | .3696 | .3511 |
| 21 | .3658 | .3658 | .3109 | .3077 | .2772 | .3174 | .2772 |
| 22 | .2926 | .3109 | .2926 | .2534 | .2614 | .2801 | .2054 |
| 23 | .2195 | .2561 | .2743 | .2378 | .2452 | .2263 | .2054 |
| 24 | .2012 | .2195 | .2561 | .2378 | .2378 | .2263 | .2263 |
| Max | **1.4632** | **1.6461** | **1.4998** | **1.4746** | **1.3599** | **1.2944** | **1.1873** |
| Min | **.1829** | **.2012** | **.2218** | **.1829** | **.2195** | **.2012** | **.1991** |
| Avg | **.6559** | **.5558** | **.5497** | **.5624** | **.4674** | **.6369** | **.6423** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214427 / 33/11 KV LONI(D) S/STN**
**Feeder No / Name : 201 / Loni SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5316 | .583 | .5487 | .5316 | .6219 | .5144 | .5144 |
| 2 | .985 | .9602 | .583 | .5731 | .6089 | .9945 | .9431 |
| 3 | 1.0395 | 1.0117 | .5487 | .5493 | .6201 | 1.0288 | .9602 |
| 4 | 1.0852 | 1.0974 | .4858 | .6733 | .6733 | 1.1145 | .9945 |
| 5 | 1.3094 | 1.2346 | .7716 | .8149 | .8059 | 1.286 | 1.2003 |
| 6 | 1.5939 | 1.5089 | 1.0288 | 1.0029 | 1.0277 | 1.3765 | 1.406 |
| 7 | 1.7101 | 1.6518 | 1.1488 | 1.2178 | 1.2071 | 1.6461 | 1.5775 |
| 8 | 1.7101 | 1.8138 | 1.1145 | 1.2136 | 1.166 | 1.7147 | 1.8004 |
| 9 | 1.7661 | 1.7652 | 1.0288 | 1.0566 | 1.0517 | 1.5384 | 1.6632 |
| 10 | .8954 | .8573 | 1.4575 | 1.7878 | 1.8004 | .6344 | .8328 |
| 11 | .823 | .7716 | 1.7204 | 1.8861 | 1.9719 | .5487 | .6626 |
| 12 | .7716 | .7125 | 1.7238 | 1.9667 | 1.8785 | .583 | |
| 13 | .7716 | .6516 | 1.7772 | 2.1491 | 1.8623 | .583 | |
| 14 | | .6001 | 1.8461 | 2.1262 | 1.8785 | .5316 | .6135 |
| 15 | .7716 | .5182 | 1.8785 | 1.9719 | 1.9547 | .5144 | .5014 |
| 16 | .7716 | .6859 | 1.8679 | 1.9204 | 1.8461 | | .4607 |
| 17 | .9602 | .7202 | 1.8623 | 1.9071 | 1.3592 | .6859 | .4298 |
| 18 | 1.0974 | .823 | 1.0277 | .9088 | .9088 | 1.0288 | 1.0631 |
| 19 | 1.1317 | .8573 | 1.0454 | .964 | 1.0288 | .9945 | 1.0808 |
| 20 | 1.0288 | .7716 | .9465 | .8859 | .9431 | .8573 | 1.0029 |
| 21 | .8573 | .7202 | .788 | .8059 | .703 | .7545 | .788 |
| 22 | .6859 | .6516 | .6516 | .6201 | .6001 | .6516 | .6379 |
| 23 | .6173 | .583 | .5316 | .6135 | .5144 | .6001 | .6268 |
| 24 | .5373 | .583 | .5487 | .543 | .6135 | .5144 | .5487 |
| **Max** | **1.7661** | **1.8138** | **1.8785** | **2.1491** | **1.9719** | **1.7147** | **1.8004** |
| **Min** | **.5316** | **.5182** | **.4858** | **.5316** | **.5144** | **.5144** | **.4298** |
| **Avg** | **1.0196** | **.9222** | **1.1222** | **1.1954** | **1.1519** | **.8998** | **.9231** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052]** **BU 5894**
**Substation No/ Name :- 214427 / 33/11 KV LONI(D) S/STN**
**Feeder No / Name : 202 / Varkute** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2303 | .2401 | .2401 | .2686 | .2401 | .2241 | .2058 |
| 2 | .2534 | .2401 | .8322 | .8848 | .7362 | .2241 | .2058 |
| 3 | .2303 | .2401 | .8802 | .9945 | .7522 | .2241 | .2058 |
| 4 | .3224 | .3086 | .9602 | .9503 | .7682 | .2401 | .2401 |
| 5 | .4298 | .5144 | 1.0402 | 1.2209 | .9602 | .2881 | .3772 |
| 6 | .5609 | .6173 | 1.2003 | 1.4419 | 1.1203 | .4001 | .5144 |
| 7 | .691 | .6859 | 1.3923 | 1.4723 | 1.2003 | .6081 | .583 |
| 8 | .6379 | .6173 | 1.4403 | 1.6057 | 1.6004 | .5601 | .583 |
| 9 | .4656 | .4801 | 1.4883 | 1.6057 | 1.5203 | .4801 | .463 |
| 10 | 1.4091 | 1.5203 | .3898 | .3361 | .3681 | 1.286 | 1.2209 |
| 11 | 1.6194 | | .3582 | .2561 | .3201 | 1.5775 | |
| 12 | 1.6194 | 1.6804 | .2658 | .16 | .2241 | 1.6461 | 1.3763 |
| 13 | 1.6356 | 1.6004 | .2534 | .2241 | .208 | 1.6118 | 1.4091 |
| 14 | 1.6032 | 1.5203 | .2481 | .208 | | 1.5089 | 1.4255 |
| 15 | 1.587 | 1.4883 | .2835 | .2401 | .2401 | 1.4575 | 1.4723 |
| 16 | 1.5384 | 1.4403 | .3582 | .2881 | .3041 | 1.3717 | 1.1831 |
| 17 | 1.6461 | 1.5203 | .3982 | .3521 | .3201 | 1.3717 | 1.0682 |
| 18 | .4458 | .4961 | .6626 | .5281 | .4321 | .4458 | .4382 |
| 19 | .5658 | .5281 | .5973 | .5601 | .4801 | .4973 | .5138 |
| 20 | .4801 | .4001 | .5373 | .4801 | .4001 | .3772 | .4835 |
| 21 | .3772 | .3681 | .3898 | .4001 | .3041 | .3086 | .3258 |
| 22 | .3086 | .3201 | .2835 | .2721 | .2401 | .2572 | .2303 |
| 23 | .2401 | .2401 | .2715 | .2561 | .2401 | .2401 | .2126 |
| 24 | .2303 | .2401 | .2401 | .2658 | .2401 | .2241 | .2229 |
| **Max** | **1.6461** | **1.6804** | **1.4883** | **1.6057** | **1.6004** | **1.6461** | **1.4723** |
| **Min** | **.2303** | **.2401** | **.2401** | **.16** | **.208** | **.2241** | **.2058** |
| **Avg** | **.7970** | **.7525** | **.6255** | **.6363** | **.5748** | **.7263** | **.6505** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214427 / 33/11 KV LONI(D) S/STN**
**Feeder No / Name : 203 / AGOTI SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4382 | .463 | .5144 | .5552 | .4801 | .5144 | .463 |
| 2 | .5014 | .4458 | 1.4575 | 1.4403 | 1.4403 | .5144 | .4458 |
| 3 | .4784 | .463 | 1.5432 | 1.5249 | 1.4575 | .5144 | .463 |
| 4 | .5731 | .5144 | 1.8861 | 1.5223 | 1.5432 | .5144 | .4973 |
| 5 | .7011 | .583 | 2.0576 | 1.6409 | 1.6289 | .6001 | .583 |
| 6 | .815 | .7545 | 2.3148 | 1.9006 | 1.8004 | .7716 | .7545 |
| 7 | .905 | .8573 | 2.4006 | 2.0645 | 2.2634 | .8573 | |
| 8 | .8596 | .823 | 2.6578 | 2.4531 | 2.4348 | .6001 | |
| 9 | .724 | .703 | 2.692 | 2.4863 | 2.4006 | .6859 | |
| 10 | 1.8299 | 2.4006 | .5609 | .5658 | .5144 | 1.8004 | |
| 11 | 2.3644 | | .5373 | .5487 | .4287 | 2.2024 | 1.7604 |
| 12 | 2.572 | 2.572 | .2865 | .5487 | .3944 | 2.2024 | 2.1605 |
| 13 | 2.4291 | 2.2462 | | .4287 | .4287 | 2.2024 | 2.1052 |
| 14 | 2.2996 | 2.4863 | .4344 | .4801 | .4801 | 2.17 | 2.364 |
| 15 | 2.3148 | 2.572 | .5731 | .5144 | | 2.1376 | 2.0405 |
| 16 | | 2.4863 | .6379 | .4801 | | 2.1376 | 2.0729 |
| 17 | 2.0081 | 2.4863 | .7164 | .4458 | .4801 | 2.0919 | 2.0885 |
| 18 | .583 | .6516 | .8775 | .6859 | .7202 | .583 | .6516 |
| 19 | .6859 | .3429 | .7701 | .6859 | .7716 | .6516 | .7164 |
| 20 | .6173 | .6859 | .7164 | .6001 | .6001 | .583 | .6516 |
| 21 | .5487 | .6001 | .6379 | .583 | .5487 | .5487 | .543 |
| 22 | .4973 | .5658 | .5373 | .4801 | .5144 | .4801 | .443 |
| 23 | .4801 | .5316 | .5373 | .463 | .5144 | .4801 | .4298 |
| 24 | .4607 | .463 | .5144 | .5373 | .463 | .4801 | .463 |
| **Max** | **2.572** | **2.572** | **2.692** | **2.4863** | **2.4348** | **2.2024** | **2.364** |
| **Min** | **.4382** | **.3429** | **.2865** | **.4287** | **.3944** | **.4801** | **.4298** |
| **Avg** | **1.1168** | **1.1608** | **1.1244** | **.9848** | **1.014** | **1.0968** | **1.0849** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052]** **BU 5894**
**Substation No/ Name :- 214427 / 33/11 KV LONI(D) S/STN**
**Feeder No / Name : 205 / Chandgaon** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2126 | .2401 | .2572 | .2149 | .2195 | .3086 | .3258 |
| 2 | .6859 | .6173 | .2572 | .2126 | .2149 | 1.046 | .823 |
| 3 | .7265 | .6344 | .2572 | .2353 | .2172 | 1.1145 | .823 |
| 4 | .7186 | .6516 | .2572 | .2865 | .2172 | 1.1145 | .8402 |
| 5 | .7545 | | .2743 | .3292 | .2534 | 1.1145 | .8573 |
| 6 | .78 | .7202 | .2743 | .3898 | .2743 | 1.267 | .8745 |
| 7 | .7712 | .7888 | .2743 | .4298 | .2896 | 1.1498 | .8916 |
| 8 | .8139 | .823 | .2572 | .3582 | .3077 | 1.2003 | .9602 |
| 9 | .8596 | .8573 | .2801 | .394 | .2743 | 1.2003 | .9774 |
| 10 | .2865 | .2743 | .7122 | 1.2437 | 1.3203 | .3601 | .3761 |
| 11 | .2058 | .2743 | 1.2071 | 1.3112 | 1.448 | .3772 | .2534 |
| 12 | .1886 | .2743 | 1.2266 | 1.3672 | 1.2955 | .3772 | .2686 |
| 13 | .1886 | .3239 | 1.3077 | 1.262 | 1.3717 | .4115 | .2835 |
| 14 | .1715 | .2572 | 1.3717 | 1.4266 | 1.286 | .4115 | .2865 |
| 15 | .1715 | .2429 | 1.2631 | 1.382 | 1.2955 | .3429 | .3224 |
| 16 | .2229 | .2591 | 1.3108 | 1.4632 | 1.3717 | .3429 | .3258 |
| 17 | .3086 | .25 | 1.326 | 1.4022 | 1.448 | .3429 | .3224 |
| 18 | .3772 | .3258 | .4344 | .2865 | .4115 | .3601 | .2865 |
| 19 | .3944 | .3429 | .5014 | .2561 | .4115 | .3772 | .2865 |
| 20 | .3429 | .2743 | .394 | .2149 | .3429 | .3601 | .2172 |
| 21 | .2915 | .2896 | .2865 | .2195 | .3429 | .3429 | .1791 |
| 22 | .2401 | .2591 | .2481 | .2172 | .3429 | .3429 | .1791 |
| 23 | .2401 | .2743 | .2481 | .2195 | .3258 | .3258 | .181 |
| 24 | .2172 | .2401 | .2743 | .2507 | .2172 | .3086 | .3258 |
| **Max** | **.8596** | **.8573** | **1.3717** | **1.4632** | **1.448** | **1.267** | **.9774** |
| **Min** | **.1715** | **.2401** | **.2481** | **.2126** | **.2149** | **.3086** | **.1791** |
| **Avg** | **.4238** | **.4128** | **.6042** | **.6405** | **.6458** | **.6208** | **.4778** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052]** **BU 5894**
**Substation No/ Name :- 214427 / 33/11 KV LONI(D) S/STN**
**Feeder No / Name : 402 / 33KV Ananad Techno** **NON SHEDDABLE EXPRESS HV FEEDERS**
**Feeder KV- 33 / OUTGOING** **(CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4887 | .4115 | .2263 | .4252 | .3801 | .2172 | .4115 |
| 2 | .3224 | .4115 | .3395 | .4344 | .3801 | .2058 | .3601 |
| 3 | .3224 | .4115 | .2263 | .3224 | .3841 | .2172 | .3601 |
| 4 | .3721 | .4115 | .3395 | .3224 | .3801 | .3258 | .3086 |
| 5 | .4344 | .4115 | .3395 | .3641 | .3841 | .2058 | .3601 |
| 6 | .3681 | .4115 | .4527 | .4344 | .3841 | .2263 | .4115 |
| 7 | .4252 | .4115 | .3395 | .4835 | .3801 | .2263 | .4115 |
| 8 | .4835 | .4115 | .3395 | .4298 | .3801 | .1086 | .4115 |
| 9 | .3681 | .4115 | .3361 | .4344 | .3841 | .3086 | .4115 |
| 10 | .3841 | .3395 | .4252 | .3841 | .4344 | .4115 | .3721 |
| 11 | .4115 | .3395 | .4298 | .3841 | .4527 | .3601 | .3326 |
| 12 | .3601 | .3258 | .4207 | .439 | .4527 | .3601 | .1646 |
| 13 | .3601 | .3395 | .3189 | .3841 | .4344 | .3601 | .1086 |
| 14 | .3601 | .4527 | .3721 | .4298 | .3921 | .3601 | .3224 |
| 15 | .3601 | .4344 | .3761 | .3841 | .4344 | .3601 | .3258 |
| 16 | .3601 | .3258 | .3721 | .439 | .3961 | .3601 | .3761 |
| 17 | .4115 | .2915 | .3801 | .3721 | .3258 | .3601 | .3801 |
| 18 | .4115 | .3258 | .4938 | .439 | .3395 | .3601 | .4887 |
| 19 | .4115 | .4527 | .4207 | .3841 | .3258 | .3601 | .4887 |
| 20 | .4115 | .3395 | .4344 | .3841 | .2263 | .3601 | .3258 |
| 21 | .4115 | .3395 | .4252 | .4252 | .2172 | .3601 | .1595 |
| 22 | .4115 | .3395 | .4835 | .3841 | .2263 | .4115 | .1075 |
| 23 | .4115 | .3395 | .4252 | .3841 | .2172 | .4115 | .1075 |
| 24 | .4784 | .4115 | .3395 | .3224 | .3841 | .2263 | .4115 |
| **Max** | **.4887** | **.4527** | **.4938** | **.4835** | **.4527** | **.4115** | **.4887** |
| **Min** | **.3224** | **.2915** | **.2263** | **.3224** | **.2172** | **.1086** | **.1075** |
| **Avg** | **.3975** | **.3792** | **.3773** | **.3996** | **.3623** | **.3110** | **.3299** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214436 / 33/11 KV KALTHAN S/S**
**Feeder No / Name : 201 / kalthan SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2829 | .2801 | .3841 | .3174 | .3018 | .2801 | .3109 |
| 2 | .3395 | .2829 | .7865 | .6485 | .503 | .2987 | .3326 |
| 3 | .3772 | .2987 | .7865 | .6516 | .6036 | .2987 | .3696 |
| 4 | .5281 | .3326 | .7935 | .6859 | .5868 | .3361 | .394 |
| 5 | .5658 | .4251 | .8192 | .6952 | .5868 | .4435 | .4344 |
| 6 | .5658 | .5121 | .8192 | .7209 | .6203 | .5487 | .5194 |
| 7 | .5658 | .5487 | .8356 | .8551 | .6203 | .5487 | .4887 |
| 8 | .4338 | .4481 | .852 | .9724 | .6539 | .4435 | .4572 |
| 9 | .2829 | .3142 | .8192 | .8309 | .6539 | .2957 | .3109 |
| 10 | .9389 | .8097 | .2378 | .2075 | .1867 | .7373 | .8097 |
| 11 | 1.0277 | .9069 | .2033 | .1886 | .1867 | .8059 | .8192 |
| 12 | 1.0608 | .8192 | .1663 | .1886 | .1509 | .7888 | .852 |
| 13 | 1.0774 | .8259 | .1478 | .1698 | .1494 | .8139 | .8288 |
| 14 | 1.0562 | .8192 | | .1698 | .1132 | .8478 | .8453 |
| 15 | 1.0277 | .7209 | .1663 | .1886 | .1132 | .8817 | .8288 |
| 16 | 1.0059 | .7865 | .1848 | .2075 | .1494 | .8745 | .7865 |
| 17 | .9054 | .8288 | .1867 | .2075 | .1867 | .8916 | .8192 |
| 18 | .2987 | .4108 | .3174 | .3018 | .2957 | .2926 | .2614 |
| 19 | .3881 | .4108 | .3696 | .3018 | .4066 | .4163 | .4066 |
| 20 | .3696 | .3881 | .3881 | .3395 | .4066 | .3841 | .4066 |
| 21 | .3696 | .3696 | .3292 | .3395 | .3511 | .3658 | .3841 |
| 22 | .3142 | .3326 | .2957 | .3018 | .3142 | .2926 | .3292 |
| 23 | .2801 | .3326 | .2957 | .2829 | .2801 | .2957 | .3142 |
| 24 | .2829 | .2801 | .3174 | .3142 | .3018 | .2801 | .3109 |
| **Max** | **1.0774** | **.9069** | **.852** | **.9724** | **.6539** | **.8916** | **.852** |
| **Min** | **.2801** | **.2801** | **.1478** | **.1698** | **.1132** | **.2801** | **.2614** |
| **Avg** | **.5977** | **.5202** | **.4566** | **.4203** | **.3634** | **.5193** | **.5258** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214436 / 33/11 KV KALTHAN S/S**
**Feeder No / Name : 202 / kalashi SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6036 | .567 | .5729 | .6697 | .6036 | .5121 | .6154 |
| 2 | .6036 | .4435 | 1.278 | 1.1317 | 1.0059 | .4066 | .6154 |
| 3 | .6413 | .4435 | 1.3108 | 1.1361 | 1.0059 | .4066 | .6268 |
| 4 | .7167 | .499 | 1.3272 | 1.153 | 1.0562 | .462 | .6335 |
| 5 | .7545 | .5487 | 1.3592 | 1.1736 | 1.0898 | .5544 | .6089 |
| 6 | .8299 | .6219 | 1.3923 | 1.2071 | 1.1401 | .6401 | .6626 |
| 7 | .7545 | .7059 | 1.4255 | 1.3413 | 1.1401 | | .6805 |
| 8 | .7545 | .7059 | 1.4586 | 1.326 | 1.1401 | .5487 | .4656 |
| 9 | .7545 | .567 | 1.4419 | 1.3077 | 1.1401 | .4805 | .4298 |
| 10 | 1.4918 | 1.4419 | .5373 | .6036 | .4251 | 1.1488 | 1.3599 |
| 11 | 1.6057 | 1.5238 | .394 | .5658 | .4251 | 1.358 | 1.3927 |
| 12 | 1.6712 | 1.5939 | .4656 | .5658 | .3734 | 1.3748 | 1.4091 |
| 13 | 1.6712 | 1.6194 | .4835 | .5281 | | 1.576 | 1.3927 |
| 14 | 1.6409 | 1.6876 | .5014 | .5281 | | 1.5424 | |
| 15 | 1.6575 | 1.6842 | .5068 | .5658 | | 1.5261 | 1.3763 |
| 16 | 1.6712 | 1.8858 | .4887 | .5658 | .4251 | 1.4746 | 1.4419 |
| 17 | 1.5415 | 1.8298 | .5611 | .6036 | .4572 | 1.4754 | 1.4091 |
| 18 | .6219 | | .6516 | .8299 | .5487 | .5304 | .7655 |
| 19 | .724 | .6653 | .6219 | .8299 | .6036 | .5973 | |
| 20 | .6878 | .6468 | .5487 | .8676 | .5853 | .5792 | .7023 |
| 21 | .6516 | .6283 | .5792 | .7922 | .5792 | .543 | .6468 |
| 22 | .6219 | .5914 | .6154 | .7167 | .5853 | .543 | .439 |
| 23 | .6219 | .5975 | .6335 | .6036 | .5792 | .5611 | .5175 |
| 24 | .6036 | .6036 | .5788 | .6335 | .6036 | .567 | .5973 |
| **Max** | **1.6712** | **1.8858** | **1.4586** | **1.3413** | **1.1401** | **1.576** | **1.4419** |
| **Min** | **.6036** | **.4435** | **.394** | **.5281** | **.3734** | **.4066** | **.4298** |
| **Avg** | **.9957** | **.9609** | **.8222** | **.8436** | **.7387** | **.8438** | **.8540** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052]** **BU 5894**
**Substation No/ Name :- 214436 / 33/11 KV KALTHAN S/S**
**Feeder No / Name : 203 / karewadi** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5847 | .6401 | .7762 | .6697 | .6224 | .5853 | .591 |
| 2 | 1.2407 | 1.2071 | .7577 | .6697 | .6036 | 1.1736 | 1.2346 |
| 3 | 1.2742 | 1.21 | .7392 | .6805 | .6413 | 1.1904 | 1.2174 |
| 4 | 1.2742 | 1.2431 | .7499 | .6805 | .6413 | 1.21 | 1.2378 |
| 5 | 1.3077 | 1.2431 | .7842 | .7164 | .6224 | 1.21 | 1.2378 |
| 6 | 1.3245 | 1.278 | .8215 | .7164 | .6979 | 1.2597 | 1.2071 |
| 7 | 1.4586 | 1.3927 | .7468 | .567 | .6413 | 1.3599 | 1.2887 |
| 8 | 1.6095 | 1.4746 | .6908 | .5853 | .5281 | 1.3927 | 1.3748 |
| 9 | 1.576 | 1.4419 | .6535 | .4572 | .5281 | 1.3592 | 1.3757 |
| 10 | .4938 | .5487 | 1.5089 | 1.5089 | 1.3923 | .4525 | .4108 |
| 11 | .462 | .5601 | 1.7436 | 1.7353 | 1.5074 | .3658 | .4108 |
| 12 | .462 | .5601 | 1.8107 | 1.6095 | 1.5238 | .3658 | .4251 |
| 13 | .3734 | .5175 | 1.643 | 1.6766 | 1.5238 | .3658 | .3361 |
| 14 | .3547 | .462 | 1.5249 | 1.6766 | 1.5238 | .3658 | .4108 |
| 15 | .3734 | .5415 | 1.6108 | 1.6766 | 1.5074 | .3658 | .4435 |
| 16 | .4251 | .5729 | 1.643 | 1.6766 | 1.491 | .3292 | .5041 |
| 17 | .5487 | .6584 | 1.6787 | 1.6263 | 1.5083 | .4024 | .5359 |
| 18 | .6219 | .7655 | .5304 | .6979 | .462 | .5121 | .6722 |
| 19 | .6697 | .7023 | .5487 | .6979 | .5487 | .4887 | .6348 |
| 20 | .6516 | .7282 | .5304 | .6979 | .5304 | .5249 | .6516 |
| 21 | .6335 | .7023 | .543 | .6413 | .567 | .5068 | .6584 |
| 22 | .6516 | .6838 | .5792 | .6413 | .567 | .5121 | .6838 |
| 23 | .6401 | .6838 | .6219 | .6224 | .5792 | .543 | .6468 |
| 24 | .5847 | .6335 | .6653 | .6335 | .6224 | .5792 | .5792 |
| Max | **1.6095** | **1.4746** | **1.8107** | **1.7353** | **1.5238** | **1.3927** | **1.3757** |
| Min | **.3547** | **.462** | **.5304** | **.4572** | **.462** | **.3292** | **.3361** |
| Avg | **.8165** | **.8521** | **.9959** | **.9817** | **.8909** | **.7259** | **.7820** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214436 / 33/11 KV KALTHAN S/S**
**Feeder No / Name : 204 / 11Kv Gangawalan SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3772 | .3881 | .2218 | .2054 | .2263 | .1867 | .2195 |
| 2 | .7377 | .7461 | .2241 | .2218 | .2263 | .6952 | .6859 |
| 3 | .7712 | .78 | .2801 | .2772 | .2641 | .7291 | .7202 |
| 4 | .7712 | .7969 | .3361 | .3292 | .3018 | .7291 | .8131 |
| 5 | .8048 | .8383 | .3921 | .3475 | .3772 | .78 | .7969 |
| 6 | .8718 | .9892 | .4481 | | .415 | .8551 | .8551 |
| 7 | 1.0395 | 1.1603 | .4435 | .439 | .4527 | 1.0227 | 1.0059 |
| 8 | 1.1401 | 1.2266 | .4755 | .4572 | .415 | 1.0277 | 1.0395 |
| 9 | 1.1401 | 1.1437 | .4435 | .4024 | .3772 | 1.0395 | 1.0227 |
| 10 | .4755 | .2987 | 1.0513 | 1.0059 | 1.0004 | .2743 | .2957 |
| 11 | .4251 | .3696 | .9724 | 1.1065 | 1.1401 | .1829 | .2987 |
| 12 | .3696 | .2957 | 1.1401 | 1.2071 | 1.1437 | .1663 | .3142 |
| 13 | .3734 | .3174 | 1.1401 | 1.2742 | 1.1271 | .1829 | .2614 |
| 14 | .3881 | .3361 | 1.1603 | 1.2742 | 1.0608 | .1829 | .2614 |
| 15 | .3921 | .3361 | 1.1869 | 1.2407 | 1.0608 | .2012 | .2614 |
| 16 | .4066 | .3547 | 1.1736 | 1.2071 | 1.0277 | .2195 | .2987 |
| 17 | .4435 | .3658 | 1.1869 | 1.1401 | 1.0059 | .2402 | .3174 |
| 18 | .5304 | .4066 | .3475 | .3772 | .2427 | .2926 | .4435 |
| 19 | .5487 | | .3326 | .3772 | .2772 | .3292 | .5175 |
| 20 | .5121 | .3142 | .2801 | .3772 | .2241 | .3109 | .4755 |
| 21 | .4435 | .2241 | .2587 | .3395 | .1867 | .2772 | .4024 |
| 22 | .4066 | .2987 | .2241 | .3018 | .2054 | .2054 | .3142 |
| 23 | .3881 | .3174 | .2218 | .2263 | .2054 | .2033 | .2987 |
| 24 | .3772 | .3881 | .3326 | .2241 | .1886 | .1886 | .2033 |
| **Max** | **1.1401** | **1.2266** | **1.1869** | **1.2742** | **1.1437** | **1.0395** | **1.0395** |
| **Min** | **.3696** | **.2241** | **.2218** | **.2054** | **.1867** | **.1663** | **.2033** |
| **Avg** | **.5889** | **.5518** | **.5947** | **.6243** | **.5480** | **.4384** | **.5051** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214439 / 33 KV NIR NIMGAON**
**Feeder No / Name : 201 / Sarati AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1886 | .0914 | .1829 | .1829 | .1829 | .1886 | .1143 |
| 2 | 1.0669 | 1.0974 | .1524 | .1829 | .1524 | 1.1584 | 1.1736 |
| 3 | 1.1431 | 1.2407 | .1829 | .2134 | .1829 | 1.2193 | 1.2407 |
| 4 | 1.1431 | 1.3077 | .2134 | .2439 | .2439 | 1.3108 | 1.2574 |
| 5 | 1.2193 | 1.4083 | .2439 | .3048 | .3048 | 1.3717 | 1.3077 |
| 6 | 1.3717 | 1.576 | .3048 | .3658 | .3353 | 1.6461 | 1.4083 |
| 7 | 1.7375 | 1.8442 | .3658 | .3963 | .3658 | 1.6766 | 1.7101 |
| 8 | 2.0748 | 1.8442 | .3353 | .3353 | .3353 | 1.7223 | 1.861 |
| 9 | 1.8442 | | .3048 | .3048 | .2439 | 1.768 | 1.7436 |
| 10 | .1337 | .1981 | 1.4632 | 1.4632 | 1.5242 | .1257 | .2134 |
| 11 | .1337 | .1829 | 1.8595 | 1.7071 | 1.89 | .0857 | .2439 |
| 12 | .0857 | .1829 | 1.9509 | 1.9814 | 1.9814 | .0934 | .2439 |
| 13 | .0857 | .1524 | 2.0119 | 1.9509 | 1.829 | .0762 | .2134 |
| 14 | .0857 | .1829 | 2.0881 | 2.0119 | 1.768 | .0857 | .2134 |
| 15 | .0762 | .1981 | 2.1033 | 2.0424 | 1.829 | .0857 | .2286 |
| 16 | .0838 | .1829 | 2.0119 | 2.0424 | 1.829 | .0838 | .2286 |
| 17 | .0686 | .1524 | 2.0119 | 1.89 | 1.829 | .1334 | .2439 |
| 18 | .1166 | .2286 | .3048 | .2439 | .2829 | .1943 | .3048 |
| 19 | .2515 | .3048 | .3353 | .3048 | .3395 | .2515 | .381 |
| 20 | .2286 | .2286 | .3048 | .2439 | .3395 | .2286 | .3048 |
| 21 | .1219 | .2134 | .2743 | .2134 | .2829 | .1578 | .2743 |
| 22 | .1238 | .1829 | .2134 | .2134 | .1886 | .1524 | .2439 |
| 23 | .1115 | .1829 | .1829 | .1829 | .1886 | .1147 | .2134 |
| 24 | .1886 | .1235 | .1829 | .1829 | .1829 | .1886 | .1486 |
| **Max** | **2.0748** | **1.8442** | **2.1033** | **2.0424** | **1.9814** | **1.768** | **1.861** |
| **Min** | **.0686** | **.0914** | **.1524** | **.1829** | **.1524** | **.0762** | **.1143** |
| **Avg** | **.5702** | **.5786** | **.8161** | **.8002** | **.7763** | **.5883** | **.6465** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214439 / 33 KV NIR NIMGAON**
**Feeder No / Name : 202 / CHAKATI SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2915 | .3018 | .3239 | .2915 | .3239 | .2915 | .3429 |
| 2 | .2915 | .3018 | .8745 | .8097 | .8097 | .3239 | .3086 |
| 3 | .2915 | .3018 | .9069 | .8745 | .8421 | .3239 | .3086 |
| 4 | .2915 | .3353 | .9393 | .9393 | .8745 | .3239 | .3086 |
| 5 | .2915 | .3353 | 1.004 | .9717 | .9393 | .3239 | .3429 |
| 6 | | .3688 | 1.1012 | 1.1012 | 1.004 | .3239 | .4115 |
| 7 | .3239 | .3353 | 1.3927 | 1.3279 | 1.0688 | .3239 | |
| 8 | .2915 | .3018 | 1.4899 | 1.4251 | 1.2308 | .3239 | |
| 9 | .3018 | .2347 | 1.4251 | 1.2631 | 1.0364 | .2267 | |
| 10 | 1.1401 | 1.1984 | .1943 | .1943 | .1943 | .9054 | 1.0669 |
| 11 | 1.5089 | 1.6518 | .1619 | .1619 | .1619 | 1.1065 | 1.2803 |
| 12 | 1.643 | 1.8138 | .1296 | .0972 | .1619 | 1.2071 | 1.2803 |
| 13 | 1.7436 | 1.9109 | .0972 | .0972 | .1619 | 1.3077 | 1.2193 |
| 14 | 1.7101 | 1.8785 | .0972 | .0972 | .1619 | 1.3077 | 1.2193 |
| 15 | 1.7101 | 1.7814 | .0972 | .0972 | .0972 | 1.3077 | 1.2193 |
| 16 | 1.643 | 1.6518 | .0972 | .1296 | .0972 | 1.3413 | 1.1584 |
| 17 | 1.7772 | 1.6518 | .1619 | .1619 | .1619 | 1.3413 | 1.1279 |
| 18 | .3018 | .3239 | .2915 | .2915 | .3239 | .3018 | .2743 |
| 19 | .4359 | .3563 | .3239 | .3563 | .3239 | .3688 | .381 |
| 20 | .3353 | .3239 | .2915 | .3239 | .2915 | .3353 | .3048 |
| 21 | .3018 | .2915 | .3239 | .3239 | .2591 | .3353 | .3048 |
| 22 | .2683 | .3239 | .3239 | .3239 | .2591 | .3018 | .3048 |
| 23 | .2683 | .3239 | .2915 | .3239 | .2591 | .3018 | .3048 |
| 24 | .2915 | .2683 | 2.4291 | .2915 | .3239 | .2591 | .3429 |
| **Max** | **1.7772** | **1.9109** | **2.4291** | **1.4251** | **1.2308** | **1.3413** | **1.2803** |
| **Min** | **.2683** | **.2347** | **.0972** | **.0972** | **.0972** | **.2267** | **.2743** |
| **Avg** | **.7589** | **.7736** | **.6154** | **.5115** | **.4737** | **.6173** | **.6577** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214439 / 33 KV NIR NIMGAON**
**Feeder No / Name : 203 / 11 kV Nirnimgaon Ag Feeder KV- 11 / OUTGOING**
**SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .253 | .2683 | .253 | .253 | .253 | .253 | .2347 |
| 2 | .7907 | .9054 | .253 | .253 | .253 | .7907 | .8383 |
| 3 | .7907 | .9389 | .2846 | .2846 | .2846 | .8539 | .9054 |
| 4 | .9488 | | .3163 | .3163 | .3163 | .9172 | .9724 |
| 5 | 1.1069 | 1.1401 | .3795 | .3795 | .4111 | 1.0437 | 1.1065 |
| 6 | 1.2651 | 1.2407 | .506 | .506 | .5376 | 1.2334 | 1.3748 |
| 7 | 1.3916 | 1.4754 | .5506 | .506 | .4744 | 1.4232 | 1.5424 |
| 8 | 1.5181 | 1.6095 | .4744 | .4744 | .4428 | 1.6446 | 1.6766 |
| 9 | 1.576 | 1.5424 | .4111 | .3479 | .3163 | 1.5813 | 1.7101 |
| 10 | .2347 | .2214 | 1.2018 | 1.2018 | 1.2018 | .2267 | .2286 |
| 11 | .1677 | .2214 | 1.5181 | 1.5497 | 1.3599 | .1781 | .1524 |
| 12 | .1677 | .1265 | 1.6446 | 1.5813 | 1.5181 | .1619 | .1219 |
| 13 | .1341 | | 1.7078 | 1.5813 | 1.5813 | .1677 | .1219 |
| 14 | .1341 | | 1.7078 | 1.5813 | 1.4232 | .1341 | .1219 |
| 15 | .1341 | | 1.3599 | 1.5813 | 1.1069 | .1677 | .1219 |
| 16 | .1341 | .1265 | 1.6446 | 1.6446 | 1.3599 | .2012 | .1829 |
| 17 | .1677 | .1898 | 1.6129 | 1.5813 | 1.4232 | .2012 | .2743 |
| 18 | .3353 | .3479 | .3479 | .3163 | .3479 | .4024 | .3658 |
| 19 | .4694 | .4428 | .4111 | .4428 | .3479 | .4359 | .4572 |
| 20 | .3688 | .3795 | .3163 | .3795 | .3163 | .4024 | .3658 |
| 21 | .3018 | .3479 | .2846 | .3163 | .253 | .3353 | .3048 |
| 22 | .2683 | .2846 | .253 | .2846 | .253 | .2683 | .3048 |
| 23 | .2347 | .253 | .253 | .253 | .253 | .2347 | .2743 |
| 24 | .253 | .2347 | 2.2862 | .253 | .253 | .253 | .2347 |
| **Max** | **1.576** | **1.6095** | **2.2862** | **1.6446** | **1.5813** | **1.6446** | **1.7101** |
| **Min** | **.1341** | **.1265** | **.253** | **.253** | **.253** | **.1341** | **.1219** |
| **Avg** | **.5478** | **.6148** | **.8324** | **.7445** | **.6786** | **.5630** | **.5831** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214439 / 33 KV NIR NIMGAON**
**Feeder No / Name : 204 / 11 kV Gondi Ag SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5658 | .5658 | .6036 | .6036 | .6036 | .6036 | .5658 |
| 2 | .5658 | .5658 | 1.8176 | 1.7147 | 1.5775 | .6036 | .6036 |
| 3 | .5658 | .6036 | 1.8861 | 1.7833 | 1.6118 | .6036 | .679 |
| 4 | .6413 | .679 | 1.9547 | 1.8519 | 1.6804 | .6413 | .7167 |
| 5 | .7545 | .7922 | 2.0576 | 1.989 | 1.8176 | .7545 | .7922 |
| 6 | .9054 | .9054 | 2.2977 | 2.1948 | 1.989 | .9431 | .9054 |
| 7 | 1.1317 | 1.094 | 2.5377 | 2.4006 | 2.4691 | 1.1317 | |
| 8 | 1.1317 | 1.094 | 2.6406 | 2.572 | 2.6406 | 1.0562 | |
| 9 | 1.0562 | | | 2.5377 | 2.6063 | 1.1317 | |
| 10 | 2.3807 | 2.452 | .8865 | .8299 | .8488 | 1.9616 | 2.4691 |
| 11 | 2.6825 | 2.7435 | .679 | .7167 | .6602 | 2.431 | 3.0178 |
| 12 | 3.1352 | 2.7606 | .6413 | .5658 | .5658 | 2.3137 | 3.0693 |
| 13 | 2.7664 | 2.5892 | .6036 | .4715 | .5658 | | 2.9664 |
| 14 | 2.649 | 2.5549 | .5093 | .4527 | .5658 | | 2.8807 |
| 15 | 2.6155 | | | .4527 | .4715 | | 2.572 |
| 16 | 2.649 | 2.6235 | .6036 | .5281 | .4715 | .3688 | 2.6749 |
| 17 | 2.5484 | 2.6749 | .7545 | | .7167 | .3688 | 2.7435 |
| 18 | .9619 | 1.1317 | 1.2071 | 1.1317 | .8299 | .7167 | .6859 |
| 19 | 1.2826 | 1.1694 | 1.1694 | 1.1694 | .9431 | 1.1694 | .9774 |
| 20 | 1.1317 | .9808 | 1.0185 | .9808 | .9431 | 1.094 | .7926 |
| 21 | .9431 | .8676 | .9054 | .8299 | .7545 | .7545 | .7888 |
| 22 | .7922 | .7167 | .7167 | .7167 | .679 | .679 | .7716 |
| 23 | | .679 | .679 | .679 | .6413 | .6036 | .6859 |
| 24 | .5658 | .5658 | .6036 | .6036 | .6413 | .6413 | .5658 |
| **Max** | **3.1352** | **2.7606** | **2.6406** | **2.572** | **2.6406** | **2.431** | **3.0693** |
| **Min** | **.5658** | **.5658** | **.5093** | **.4527** | **.4715** | **.3688** | **.5658** |
| **Avg** | **1.4966** | **1.4004** | **1.2170** | **1.2077** | **1.1373** | **.9796** | **1.5202** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214439 / 33 KV NIR NIMGAON**
**Feeder No / Name : 205 / 11 kV Sarati Gfss GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1132 | .1086 | .0943 | .1132 | .0943 | .0943 | .1097 |
| 2 | .1132 | .1097 | .1132 | .1132 | .0943 | .0943 | .1086 |
| 3 | .1132 | .1086 | .1132 | .1132 | .1132 | .0943 | .1267 |
| 4 | .1132 | .1267 | .1509 | .132 | .132 | .0943 | .1267 |
| 5 | .1509 | .1463 | .1886 | .1509 | .1509 | .1132 | .1463 |
| 6 | .1886 | .1829 | .2075 | .1886 | .1886 | .1509 | .2012 |
| 7 | .2075 | .2012 | .2452 | .2075 | .1886 | .1886 | .2195 |
| 8 | .2075 | .181 | .1886 | .1677 | .1698 | .1886 | .1991 |
| 9 | .181 | | .1698 | .1509 | .132 | .1509 | .1463 |
| 10 | .1086 | .0943 | .0943 | .132 | .1132 | .1086 | .1029 |
| 11 | .0914 | .0943 | .0943 | .1132 | .0754 | .0914 | .0857 |
| 12 | .0732 | | .0754 | .0943 | .0754 | .0732 | .0686 |
| 13 | .0732 | | .0566 | .0943 | .0754 | .0732 | .0514 |
| 14 | .0732 | | .0377 | .0754 | .0754 | .0732 | .0514 |
| 15 | .0914 | | .0566 | .0566 | .0754 | .0747 | .0686 |
| 16 | .0914 | .0943 | .0754 | .0943 | .0754 | .0914 | .0857 |
| 17 | .1097 | .1132 | .0943 | .0943 | .1132 | .0914 | .1029 |
| 18 | .1463 | .1886 | .1543 | .1509 | .1132 | .1463 | .1372 |
| 19 | .1646 | .1698 | .1698 | .1509 | .1509 | .1646 | .1715 |
| 20 | .1463 | .132 | .1509 | .132 | .1132 | .1463 | .1372 |
| 21 | .128 | .1132 | .1509 | .1132 | .1132 | .1086 | .12 |
| 22 | .1097 | .1132 | .132 | .1132 | .1132 | .1097 | .1029 |
| 23 | .1097 | .0943 | .1132 | .0943 | .0943 | .1097 | .1029 |
| 24 | .1132 | .1097 | .0943 | .1132 | .0943 | .0943 | .1086 |
| **Max** | **.2075** | **.2012** | **.2452** | **.2075** | **.1886** | **.1886** | **.2195** |
| **Min** | **.0732** | **.0943** | **.0377** | **.0566** | **.0754** | **.0732** | **.0514** |
| **Avg** | **.1258** | **.1306** | **.1259** | **.1233** | **.1140** | **.1136** | **.1201** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214439 / 33 KV NIR NIMGAON**
**Feeder No / Name : 206 / 11 kV Bhagatwadi Ag SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .08 | .1006 | .0914 | .0914 | .061 | .0533 | .1029 |
| 2 | .4801 | .7042 | .061 | .061 | .061 | .4801 | .6859 |
| 3 | | .7712 | .0914 | .0914 | .0914 | .5335 | .7042 |
| 4 | .8002 | .8048 | .1219 | .1219 | .1219 | .5335 | .7712 |
| 5 | .9335 | .9054 | .1829 | .1829 | .1829 | .6135 | .8383 |
| 6 | 1.0669 | 1.073 | .3048 | .2743 | .3048 | .6668 | .9054 |
| 7 | 1.0136 | 1.3413 | .3048 | .3048 | .3048 | .8269 | 1.1065 |
| 8 | 1.0136 | 1.4083 | .2743 | .2134 | .2439 | .8802 | 1.1065 |
| 9 | 1.2407 | 1.3077 | .1829 | .1524 | .1524 | .8002 | 1.0059 |
| 10 | .0838 | .0914 | 1.0669 | .9755 | .8002 | .1006 | .0914 |
| 11 | .0671 | .061 | 1.1584 | 1.0974 | .8802 | .0838 | .061 |
| 12 | .0671 | .0457 | 1.1888 | 1.1279 | .9335 | .0671 | .061 |
| 13 | .0671 | .061 | 1.2193 | 1.0669 | .8802 | .0671 | .0457 |
| 14 | .0671 | .061 | 1.1584 | 1.0364 | .8002 | .0671 | .0457 |
| 15 | .0671 | | .945 | 1.0364 | .4001 | .0671 | .0305 |
| 16 | .0671 | .0457 | 1.0059 | 1.0364 | .4801 | .0838 | .0457 |
| 17 | .0838 | .061 | 1.0364 | 1.0669 | .4534 | .0671 | .061 |
| 18 | .1677 | .1219 | .1524 | .1219 | .1067 | .1677 | .1524 |
| 19 | .2347 | .2134 | .2439 | .2134 | .1334 | .2347 | .2286 |
| 20 | .1677 | .1829 | .1829 | .1829 | .1334 | .2012 | .1829 |
| 21 | .1341 | .1219 | .1524 | .1219 | .1067 | .1677 | .1372 |
| 22 | .1341 | .0914 | .1219 | .1219 | .08 | .1341 | .1219 |
| 23 | .1006 | .0914 | .0914 | .0914 | .0533 | .1341 | .0914 |
| 24 | .08 | .1006 | 2.0243 | .0914 | .061 | .0533 | .1029 |
| **Max** | **1.2407** | **1.4083** | **2.0243** | **1.1279** | **.9335** | **.8802** | **1.1065** |
| **Min** | **.0671** | **.0457** | **.061** | **.061** | **.0533** | **.0533** | **.0305** |
| **Avg** | **.3573** | **.4246** | **.5568** | **.4534** | **.3261** | **.2952** | **.3619** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214448 / 33/11 KV KALEWADI S/STN**
**Feeder No / Name : 201 / 11KV PALASDEO AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3429 | .2439 | .2134 | .3429 | .3429 | .3429 | .2286 |
| 2 | .3429 | .2134 | 1.0669 | .884 | .9145 | .3086 | .2286 |
| 3 | .3048 | .2134 | 1.1584 | .9145 | 1.0517 | .3086 | .2286 |
| 4 | .381 | .2134 | 1.3717 | .9907 | 1.0288 | .3429 | .2286 |
| 5 | .4572 | .2134 | 1.4022 | 1.0364 | 1.1145 | .4115 | .2286 |
| 6 | | .1829 | 1.3717 | 1.0364 | 1.3717 | .5144 | .5487 |
| 7 | | .1677 | 1.4327 | 1.0974 | 1.2955 | .6687 | .6516 |
| 8 | | .4572 | 1.4175 | 1.2651 | 1.2346 | .6687 | .503 |
| 9 | | .3601 | 1.2803 | 1.2193 | 1.1736 | .6001 | .442 |
| 10 | | 1.1126 | .4458 | .4115 | .3963 | 1.0669 | 1.1584 |
| 11 | | | .3429 | .3429 | .3963 | 1.2498 | 1.2193 |
| 12 | 1.2041 | 1.2803 | .3429 | .4973 | .3658 | 1.3717 | 1.4022 |
| 13 | 1.1888 | 1.2955 | .3772 | | .3658 | 1.3717 | 1.4327 |
| 14 | 1.2193 | 1.3565 | .3429 | .3429 | .3353 | 1.4327 | 1.387 |
| 15 | 1.2193 | 1.4022 | .3772 | .3429 | .3353 | 1.387 | 1.3717 |
| 16 | 1.2498 | 1.448 | .3429 | .3429 | .3658 | 1.3717 | 1.3717 |
| 17 | 1.2803 | 1.4022 | .3429 | .3429 | .4458 | 1.3108 | 1.3565 |
| 18 | .3201 | .3353 | .3772 | .4287 | .4115 | .4115 | .3086 |
| 19 | .3048 | .3658 | .3772 | .4287 | .4115 | .4115 | .3258 |
| 20 | .3048 | .3963 | .3772 | .4287 | .3429 | .3353 | .3086 |
| 21 | .2439 | .3658 | .3429 | .3772 | .3944 | .3048 | .3258 |
| 22 | .2439 | .2896 | .3429 | .3772 | .3772 | .2439 | .3258 |
| 23 | .2439 | .2286 | .3429 | .3429 | .3772 | .2286 | .3086 |
| 24 | .3429 | .2439 | .2286 | .3429 | .3429 | .3772 | .2286 |
| **Max** | **1.2803** | **1.448** | **1.4327** | **1.2651** | **1.3717** | **1.4327** | **1.4327** |
| **Min** | **.2439** | **.1677** | **.2134** | **.3429** | **.3353** | **.2286** | **.2286** |
| **Avg** | **.6219** | **.5995** | **.6674** | **.6146** | **.6330** | **.7101** | **.6717** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214448 / 33/11 KV KALEWADI S/STN**
**Feeder No / Name : 202 / 11KV RUI SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5144 | .5144 | .4115 | .5144 | .5144 | .5316 | .4115 |
| 2 | .5144 | .4458 | .823 | .8383 | 1.0288 | .5144 | .4287 |
| 3 | .5144 | .4458 | 1.0631 | .9145 | .9145 | .5144 | .4287 |
| 4 | .5144 | .4801 | 1.3375 | .9907 | .9145 | .5487 | .4287 |
| 5 | .6001 | .5144 | 1.406 | 1.1888 | .9907 | .5487 | .4287 |
| 6 | | .6001 | 1.6118 | 1.326 | 1.0669 | .6859 | .5487 |
| 7 | | .8059 | 1.6804 | 1.3413 | 1.5089 | .7202 | .7202 |
| 8 | | .6859 | 1.7147 | 1.4022 | 1.5432 | .7202 | .7202 |
| 9 | | .5487 | 1.4327 | 1.3717 | 1.5775 | .7202 | .5144 |
| 10 | | .8688 | .4115 | .3658 | .3429 | 1.0364 | |
| 11 | | | .4115 | .3429 | .3429 | 1.0974 | 1.2003 |
| 12 | 1.1736 | 1.2041 | .4115 | .2572 | .3086 | 1.2193 | 1.3032 |
| 13 | 1.1126 | 1.2041 | .4458 | .2572 | .3086 | 1.2193 | 1.3717 |
| 14 | 1.2498 | 1.2041 | .4115 | .2572 | .3429 | 1.1431 | 1.3375 |
| 15 | 1.3108 | 1.2041 | .3772 | .2572 | .3429 | 1.1126 | 1.3032 |
| 16 | 1.3108 | 1.2193 | .4115 | .2572 | .3429 | 1.0974 | 1.3032 |
| 17 | 1.2498 | 1.5089 | .4458 | .3429 | .4115 | 1.1584 | 1.2346 |
| 18 | .3258 | .5487 | .583 | .6001 | .6173 | .6859 | .4801 |
| 19 | .5487 | .7202 | .5487 | .6173 | .583 | .6859 | .5144 |
| 20 | .5144 | .7888 | .5144 | .6687 | .5487 | .6516 | .5487 |
| 21 | .5144 | .6859 | .5144 | .5144 | .5316 | .5487 | .4115 |
| 22 | .5144 | .583 | .5144 | .5144 | .5144 | .4115 | .4287 |
| 23 | .5144 | .4458 | .4801 | | .5316 | .4115 | .4801 |
| 24 | .5144 | .5144 | .4458 | .4801 | .5144 | .5316 | .4115 |
| **Max** | **1.3108** | **1.5089** | **1.7147** | **1.4022** | **1.5775** | **1.2193** | **1.3717** |
| **Min** | **.3258** | **.4458** | **.3772** | **.2572** | **.3086** | **.4115** | **.4115** |
| **Avg** | **.7506** | **.7714** | **.7670** | **.6792** | **.6935** | **.7715** | **.7373** |

 Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052]** **BU 5894**
**Substation No/ Name :- 214448 / 33/11 KV KALEWADI S/STN**
**Feeder No / Name : 203 / 11KV NHAVI** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3429 | .3658 | .3048 | .3429 | .3048 | .3086 | .2743 |
| 2 | 1.286 | .9297 | .3048 | .3601 | .3048 | .7316 | .7011 |
| 3 | 1.1431 | .9907 | .2743 | .3429 | .0762 | .7621 | .7621 |
| 4 | 1.1431 | .9907 | .2743 | .3086 | .3353 | .884 | .7621 |
| 5 | 1.2193 | 1.0669 | .3353 | .2915 | .381 | 1.0212 | .7621 |
| 6 | | 1.3717 | .3353 | .2743 | .4572 | 1.2498 | 1.0669 |
| 7 | | 1.5242 | .4268 | .2572 | .381 | 1.2651 | 1.1584 |
| 8 | | 1.5851 | .4572 | .2572 | .3658 | 1.387 | 1.4327 |
| 9 | | 1.4784 | .4801 | .2572 | .3353 | 1.3717 | 1.3413 |
| 10 | | .2915 | 1.2193 | 1.3375 | .884 | .3944 | .2915 |
| 11 | | | 1.2955 | 1.4575 | .9145 | .1372 | .2439 |
| 12 | | .1715 | 1.3413 | 1.4575 | 1.0364 | .1372 | .2439 |
| 13 | | .2401 | 1.4175 | 1.2955 | 1.2193 | .1372 | .2134 |
| 14 | .2591 | .3086 | 1.4937 | 1.5242 | 1.3108 | .1372 | .2134 |
| 15 | .3353 | .2915 | 1.6004 | 1.448 | 1.3413 | .1372 | .1981 |
| 16 | .3201 | .2743 | 1.4937 | 1.448 | 1.3108 | .1524 | .2134 |
| 17 | | .3048 | 1.3108 | 1.448 | 1.2498 | .1981 | .2286 |
| 18 | .4115 | .3658 | .2915 | .3429 | .3258 | .3201 | .2743 |
| 19 | .3658 | .3963 | .2915 | .3429 | .3258 | .3353 | .3086 |
| 20 | .4115 | .4268 | .3086 | .3429 | .3258 | .4115 | .3258 |
| 21 | .3658 | .4877 | .4115 | .3429 | .3258 | .3772 | .3601 |
| 22 | .4115 | .4572 | .3429 | .3429 | .3086 | .2743 | .3772 |
| 23 | .4115 | .3353 | .3429 | .3429 | .3258 | .2743 | .3772 |
| 24 | .3429 | .3658 | .3353 | .3429 | .3048 | .2915 | .2743 |
| **Max** | **1.286** | **1.5851** | **1.6004** | **1.5242** | **1.3413** | **1.387** | **1.4327** |
| **Min** | **.2591** | **.1715** | **.2743** | **.2572** | **.0762** | **.1372** | **.1981** |
| **Avg** | **.5846** | **.6531** | **.6954** | **.6879** | **.6021** | **.5290** | **.5169** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214448 / 33/11 KV KALEWADI S/STN**
**Feeder No / Name : 204 / 11KV KALEWADI AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4287 | .3048 | .3048 | .2401 | .2572 | .2401 | .2439 |
| 2 | 1.2193 | .9145 | .3048 | .2572 | | 1.0669 | .9145 |
| 3 | 1.2193 | .9907 | .2743 | .2572 | | 1.0974 | .9907 |
| 4 | 1.2193 | 1.0669 | .2743 | .2743 | .2572 | 1.1279 | .9907 |
| 5 | 1.448 | 1.0669 | .2439 | .3086 | .2572 | 1.1584 | .9907 |
| 6 | | 1.1736 | .3048 | .3258 | .2572 | 1.2803 | 1.0974 |
| 7 | | 1.2498 | .3353 | .3258 | .2286 | 1.3413 | 1.2193 |
| 8 | | 1.387 | .3658 | .2401 | .2743 | 1.3108 | 1.2193 |
| 9 | | 1.3717 | .3429 | .2572 | .3048 | 1.2955 | 1.2003 |
| 10 | | .1886 | 1.2803 | 1.5699 | 1.3717 | .2134 | .1715 |
| 11 | | | 1.3413 | 1.829 | 1.4746 | .2134 | .2058 |
| 12 | .1829 | .1715 | 1.5394 | 1.829 | 1.6804 | .2439 | .2743 |
| 13 | .2591 | .2058 | 1.768 | 1.829 | 1.7318 | .2896 | .3086 |
| 14 | .3353 | .2229 | 1.768 | 2.0119 | 1.8176 | .3048 | .3429 |
| 15 | .3658 | .2229 | 1.768 | 1.829 | 1.7833 | .1524 | .3429 |
| 16 | .381 | .1715 | 1.5699 | 1.829 | 1.7147 | .2591 | .3048 |
| 17 | .3658 | .2743 | 1.5699 | 1.829 | 1.5261 | .3201 | .2439 |
| 18 | .381 | .2439 | .2743 | .1715 | .2401 | .2896 | .2743 |
| 19 | .3658 | .3048 | .2915 | .2572 | .2401 | .2439 | .2572 |
| 20 | .3658 | .3658 | .2915 | .2572 | .2401 | .2439 | .2743 |
| 21 | .3048 | .3963 | .3086 | .2572 | .2401 | .2439 | .2743 |
| 22 | .3048 | .3963 | .2915 | .2743 | .2401 | .2439 | .2743 |
| 23 | .3048 | .3658 | .3086 | .2572 | .2229 | .2439 | .2743 |
| 24 | .4287 | .3048 | .3353 | .2743 | .2572 | .2401 | .2439 |
| **Max** | **1.448** | **1.387** | **1.768** | **2.0119** | **1.8176** | **1.3413** | **1.2193** |
| **Min** | **.1829** | **.1715** | **.2439** | **.1715** | **.2229** | **.1524** | **.1715** |
| **Avg** | **.5489** | **.5809** | **.7274** | **.7830** | **.7553** | **.5694** | **.5389** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214448 / 33/11 KV KALEWADI S/STN**
**Feeder No / Name : 205 / 11 KV IRRIGATION SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2572 | .2743 | .1715 | .2058 | .2058 | .1715 | .2134 |
| 2 | .2572 | .2743 | .6687 | 1.0669 | .9145 | .1715 | .1981 |
| 3 | .2286 | .2743 | .823 | 1.0669 | .9145 | .1715 | .1981 |
| 4 | .2286 | .2743 | .9259 | 1.0974 | .9145 | .2058 | .1981 |
| 5 | .2286 | .2743 | 1.0974 | 1.0974 | .9145 | .2058 | .2134 |
| 6 | | .3201 | 1.2689 | 1.1126 | .9907 | .2401 | .2591 |
| 7 | | .3048 | 1.3375 | 1.1279 | 1.286 | .2401 | .2896 |
| 8 | | .2591 | 1.3032 | 1.2346 | 1.2003 | .1886 | .2591 |
| 9 | | .2915 | 1.1279 | 1.2193 | 1.166 | .1524 | .2058 |
| 10 | | 1.3108 | .2401 | .1372 | .1372 | 1.0517 | 1.2003 |
| 11 | | | .2401 | .1372 | .1372 | 1.2803 | 1.2689 |
| 12 | 1.0974 | 1.448 | .2401 | .1372 | .1715 | 1.2955 | 1.3717 |
| 13 | 1.2193 | 1.4022 | .2572 | .1372 | .1715 | 1.326 | 1.4403 |
| 14 | 1.2193 | 1.4022 | .2572 | .1372 | .2058 | 1.387 | 1.4746 |
| 15 | 1.2498 | 1.3717 | .2743 | .1715 | .2058 | 1.4022 | 1.4403 |
| 16 | 1.3413 | 1.4022 | .2401 | .1715 | .2058 | 1.3717 | 1.3717 |
| 17 | 1.4022 | 1.4746 | .2229 | .2058 | .2401 | 1.3717 | 1.4403 |
| 18 | .2439 | .1715 | .2058 | .2058 | .2058 | .1829 | .1886 |
| 19 | .2743 | .2058 | .2058 | .2058 | .1715 | .2134 | .2058 |
| 20 | .2743 | .2743 | .2229 | .2058 | .1715 | .2286 | .2058 |
| 21 | .2743 | .2743 | .2058 | .2058 | .1543 | .2286 | .2058 |
| 22 | .2743 | .2401 | .2058 | .2058 | .1715 | .2286 | .1886 |
| 23 | .2743 | .2058 | .2058 | .2058 | .1543 | .2134 | .1886 |
| 24 | .2572 | | .2058 | .2058 | .2058 | .1715 | .2134 |
| **Max** | **1.4022** | **1.4746** | **1.3375** | **1.2346** | **1.286** | **1.4022** | **1.4746** |
| **Min** | **.2286** | **.1715** | **.1715** | **.1372** | **.1372** | **.1524** | **.1886** |
| **Avg** | **.5890** | **.6241** | **.5064** | **.4960** | **.4674** | **.5709** | **.6016** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214448 / 33/11 KV KALEWADI S/STN**
**Feeder No / Name : 206 / 11KV KALEWADI GAONTHAN GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2058 | .1715 | .1715 | .1543 | .1715 | .1543 | .1715 |
| 2 | .2058 | .1715 | .1715 | .1372 | .1715 | .1543 | .1715 |
| 3 | .2058 | .1715 | .1715 | .1372 | .2572 | .1543 | .1715 |
| 4 | .2572 | .2572 | .2058 | .1372 | .3429 | .1715 | .1715 |
| 5 | .4287 | .3258 | .2743 | .3258 | .4287 | .2401 | .2572 |
| 6 | .6001 | .463 | .3086 | .4287 | .6001 | .3772 | .463 |
| 7 | .4287 | .6516 | .3772 | .6001 | .4572 | .6001 | .6173 |
| 8 | | .5316 | .4801 | .4458 | .4801 | .4973 | .5316 |
| 9 | | .4287 | .4115 | .4801 | .4287 | .4973 | .4458 |
| 10 | | .2915 | .3086 | .2915 | .4287 | .2915 | |
| 11 | | | .2915 | .2058 | .3772 | .2572 | |
| 12 | .2743 | .2743 | .2401 | .1715 | .3429 | .2058 | |
| 13 | .2058 | .2572 | .1715 | .1715 | .3429 | .1543 | |
| 14 | .1715 | .1543 | .1543 | .1715 | .2743 | .1543 | |
| 15 | .1715 | .1543 | .1543 | .1715 | .2401 | .1543 | .2572 |
| 16 | .2058 | .2229 | .2401 | .1715 | .2229 | .2058 | .2572 |
| 17 | .2743 | .2743 | .2915 | .2743 | .2743 | .3086 | .3086 |
| 18 | .3944 | .4115 | .4115 | .4287 | .4115 | .4458 | .3086 |
| 19 | .4287 | .4458 | .3772 | .4287 | .4115 | .4115 | .2915 |
| 20 | .3772 | .4458 | .3429 | .3429 | .3772 | .4115 | .2915 |
| 21 | .2572 | .4115 | .2915 | .2743 | .3086 | .3429 | .2915 |
| 22 | .2058 | .2743 | .2058 | .2058 | .2401 | .2058 | .2401 |
| 23 | .1715 | .1715 | .1715 | .1715 | .2058 | .1715 | .1715 |
| 24 | .2058 | .1715 | .1715 | .1543 | .1524 | .1543 | .1715 |
| **Max** | **.6001** | **.6516** | **.4801** | **.6001** | **.6001** | **.6001** | **.6173** |
| **Min** | **.1715** | **.1543** | **.1543** | **.1372** | **.1524** | **.1543** | **.1715** |
| **Avg** | **.2838** | **.3101** | **.2665** | **.2701** | **.3312** | **.2801** | **.2942** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214448 / 33/11 KV KALEWADI S/STN**
**Feeder No / Name : 207 / 11KV PALASDEO GAONTHAN GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0857 | .0857 | .0857 | .0686 | .1029 | .0514 | .0857 |
| 2 | .0857 | .0686 | .0857 | .0857 | .0857 | .0514 | .0686 |
| 3 | .0857 | .0686 | .0857 | .1029 | .1029 | .0686 | .0686 |
| 4 | .1029 | .0857 | .0857 | .1029 | .12 | .0686 | .0857 |
| 5 | .1372 | .1029 | .1029 | .1372 | .1372 | .0686 | .12 |
| 6 | .1715 | .1543 | .1372 | .1715 | .1543 | .1029 | .1543 |
| 7 | .1715 | .1886 | .1543 | .2058 | .1372 | .1715 | .1886 |
| 8 | | .1715 | .1543 | .1543 | .1372 | .1543 | .1543 |
| 9 | | .1543 | .1372 | .1029 | .1543 | .1543 | .1543 |
| 10 | | .12 | .1029 | .12 | .12 | .1029 | .1029 |
| 11 | | | .0686 | .1029 | .12 | .1029 | .1029 |
| 12 | .12 | .1029 | .0686 | .0857 | | .12 | .1029 |
| 13 | .1029 | .0857 | .0686 | .0857 | | .1029 | .0857 |
| 14 | .1029 | .0857 | .0686 | | .0857 | .1029 | .0857 |
| 15 | .12 | .0857 | .0686 | .0857 | .0857 | .1029 | .0857 |
| 16 | .12 | .1029 | .0857 | .0857 | .0686 | .0857 | .0857 |
| 17 | .12 | .12 | .1029 | .0857 | .0857 | .0857 | .1372 |
| 18 | .1543 | .1029 | .1029 | .12 | .12 | .12 | .1372 |
| 19 | .1543 | .1372 | .1029 | .12 | .12 | .1543 | .12 |
| 20 | .1543 | .1715 | .12 | .1029 | .12 | .1543 | .12 |
| 21 | .1543 | .1715 | .1372 | .0857 | .12 | .12 | .12 |
| 22 | .12 | .1029 | .1372 | .0857 | .0857 | .0857 | .0686 |
| 23 | .1029 | .0857 | .1372 | .1029 | .0686 | .0857 | .0514 |
| 24 | .0857 | .1029 | .0857 | .0686 | .0857 | .0686 | .0857 |
| **Max** | **.1715** | **.1886** | **.1543** | **.2058** | **.1543** | **.1715** | **.1886** |
| **Min** | **.0857** | **.0686** | **.0686** | **.0686** | **.0686** | **.0514** | **.0514** |
| **Avg** | **.1226** | **.1156** | **.1036** | **.1073** | **.1099** | **.1036** | **.1072** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214448 / 33/11 KV KALEWADI S/STN**
**Feeder No / Name : 208 / 11KV BANDEWADI AG FEEDER SEPERATION/PURE AG**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2 | | | .7926 | .9907 | .8383 | | |
| 3 | | | .8535 | 1.0059 | .8383 | | |
| 4 | | | .9145 | .9145 | .9145 | | |
| 5 | | | .9755 | 1.0212 | .9145 | | |
| 6 | | | .945 | 1.0059 | .9145 | | |
| 7 | | | .9145 | 1.0059 | 1.0669 | | |
| 8 | | | .945 | 1.0212 | 1.0517 | | |
| 9 | | | .9145 | .9145 | 1.0212 | | |
| 10 | | 1.1431 | | | | 1.0364 | 1.0974 |
| 11 | | | | | | 1.0974 | 1.1279 |
| 12 | 1.1279 | 1.1126 | | | | 1.0059 | 1.1584 |
| 13 | 1.0669 | 1.1126 | | | | 1.1126 | 1.1584 |
| 14 | 1.0974 | 1.1279 | | | | 1.1584 | 1.0669 |
| 15 | 1.1584 | 1.1126 | | | | 1.1888 | 1.0669 |
| 16 | 1.1736 | 1.1126 | | | | 1.1431 | 1.0364 |
| 17 | 1.1736 | 1.1279 | | | | 1.1126 | 1.0669 |
| **Max** | **1.1736** | **1.1431** | **.9755** | **1.0212** | **1.0669** | **1.1888** | **1.1584** |
| **Min** | **1.0669** | **1.1126** | **.7926** | **.9145** | **.8383** | **1.0059** | **1.0364** |
| **Avg** | **1.1330** | **1.1213** | **.9069** | **.9850** | **.9450** | **1.1069** | **1.0974** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214448 / 33/11 KV KALEWADI S/STN**
**Feeder No / Name : 209 / 11KV DALAJ AG FEEDER SEPERATION/PURE AG**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4287 | .4268 | .3658 | .1543 | .1543 | .1886 | .3048 |
| 2 | 1.4575 | 1.0974 | .3353 | .1543 | .1372 | .7926 | .9907 |
| 3 | 1.2955 | 1.1431 | .3048 | .1543 | .6859 | .9145 | 1.0669 |
| 4 | 1.2955 | 1.2193 | .2743 | .1715 | .2229 | .9145 | 1.0669 |
| 5 | 1.3717 | 1.2193 | .2743 | .1715 | .2743 | .9145 | 1.0669 |
| 6 | | 1.448 | .3048 | .1886 | .2572 | .9297 | 1.2193 |
| 7 | | 1.4632 | .3658 | | .2286 | .9297 | 1.2498 |
| 8 | | 1.6461 | .4268 | .1715 | .2743 | 1.0517 | 1.4022 |
| 9 | | 1.6004 | .4115 | .2058 | .3048 | .9145 | 1.4632 |
| 10 | | .2915 | 1.4632 | 1.1584 | 1.448 | .1524 | |
| 11 | | | 1.4937 | 1.9814 | 1.4937 | .2439 | |
| 12 | .2591 | .2743 | 1.5242 | 1.9814 | 1.5699 | .2591 | |
| 13 | .3963 | .2915 | 1.7661 | 2.1795 | 1.6918 | .2591 | .2743 |
| 14 | .4572 | .3772 | 1.5242 | 1.9814 | 1.768 | .2743 | .2743 |
| 15 | .6001 | .3772 | 1.5089 | 2.1795 | 1.7375 | .3048 | |
| 16 | .5335 | .3429 | 1.3717 | 1.9814 | 1.7223 | .3658 | |
| 17 | .5335 | .3963 | 1.1888 | 1.9814 | 1.6461 | .3353 | .2743 |
| 18 | .5335 | .2591 | .2058 | .2543 | .2401 | .3658 | .3258 |
| 19 | .5144 | .3048 | .2058 | .2286 | .2401 | .3048 | .3258 |
| 20 | .4572 | .3658 | .2058 | .2058 | .1715 | .3048 | .3258 |
| 21 | .4115 | .3963 | .2058 | .2058 | .1886 | .3048 | .3601 |
| 22 | .4268 | .3963 | .2058 | .1715 | .1715 | .3048 | .3601 |
| 23 | .4268 | .381 | .2058 | .1372 | .1715 | .3048 | .3601 |
| 24 | .4287 | .4268 | .381 | .1715 | .1372 | .1886 | .3048 |
| **Max** | **1.4575** | **1.6461** | **1.7661** | **2.1795** | **1.768** | **1.0517** | **1.4632** |
| **Min** | **.2591** | **.2591** | **.2058** | **.1372** | **.1372** | **.1524** | **.2743** |
| **Avg** | **.6571** | **.7019** | **.6883** | **.7900** | **.7057** | **.4926** | **.6851** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214448 / 33/11 KV KALEWADI S/STN**
**Feeder No / Name : 401 / 33 KV VALMONT NON SHEDDABLE EXPRESS HV FEEDERS**
**Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .2058 | .1543 | .2058 | .1029 | | .3601 |
| 2 | .2572 | .2058 | .1543 | .2058 | .1029 | | .2058 |
| 3 | .2572 | .1029 | .2058 | .2058 | .1029 | | .1029 |
| 4 | .2572 | .1029 | .3086 | .2058 | .1029 | | .1029 |
| 5 | .2058 | .1029 | .3086 | .2058 | .1029 | | .1029 |
| 6 | .1029 | .1029 | .1543 | .2572 | | | .1029 |
| 7 | .2058 | .2058 | .2058 | .2572 | | .1543 | .1029 |
| 8 | .2058 | .2572 | .2058 | .3086 | | .2058 | .2572 |
| 9 | .2058 | .1029 | .2058 | .2572 | | .2058 | .1029 |
| 10 | .2058 | .3601 | .2058 | .2572 | | .1543 | .2572 |
| 11 | .3601 | | .2058 | .2572 | | .3601 | .2572 |
| 12 | .3086 | .2058 | .2058 | .2572 | | .2058 | .1543 |
| 13 | .3086 | .2058 | .2058 | .2572 | | .2058 | .2058 |
| 14 | .2572 | .2058 | .2058 | .2572 | | .2572 | .2058 |
| 15 | .2058 | .2572 | .2058 | .2058 | | .2058 | .2058 |
| 16 | .2572 | .2572 | .2058 | .2572 | | .2572 | .2572 |
| 17 | .3086 | .2058 | .2058 | .3086 | | .2058 | .3601 |
| 18 | .2058 | .2058 | .2058 | .3086 | | .3601 | .3086 |
| 19 | .3086 | .2058 | .2058 | .3086 | | .3601 | .2572 |
| 20 | .3086 | .3086 | .2058 | .2572 | | .3601 | .2572 |
| 21 | .2572 | .1543 | .2572 | .2572 | | .3601 | .2572 |
| 22 | .2058 | .1543 | .2058 | .3086 | | .2572 | .2572 |
| 23 | .2058 | .1543 | .2058 | .2572 | | .3601 | .2572 |
| 24 | .3086 | .2058 | .2058 | .2058 | .2058 | | .3086 |
| **Max** | **.3601** | **.3601** | **.3086** | **.3086** | **.2058** | **.3601** | **.3601** |
| **Min** | **.1029** | **.1029** | **.1543** | **.2058** | **.1029** | **.1543** | **.1029** |
| **Avg** | **.2483** | **.1946** | **.2101** | **.2529** | **.1201** | **.2633** | **.2186** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214455 / 33/11 KV SHIRSODI S/STN**
**Feeder No / Name : 201 / Shirsodi SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2401 | .1097 | .0335 | .0343 | .0366 | .12 | .1715 |
| 2 | .2058 | .1097 | .6203 | .4115 | .4298 | .0857 | .1715 |
| 3 | .2229 | .1097 | .6371 | .4801 | .4835 | .0857 | .1715 |
| 4 | .2058 | .1097 | .6539 | .583 | .5014 | .0857 | .1715 |
| 5 | .2229 | .1097 | .6874 | .6687 | .5373 | .0857 | .1715 |
| 6 | .2401 | .1097 | .6706 | .6859 | .5731 | .0857 | .1886 |
| 7 | .2401 | .1097 | .7042 | .703 | .6447 | .1029 | .1886 |
| 8 | .2229 | .1463 | .7712 | .7202 | .7537 | .1029 | .1715 |
| 9 | .1543 | .1463 | .8383 | .7545 | .7362 | .12 | .1029 |
| 10 | .7287 | .788 | .1006 | .0732 | .0732 | .7716 | .788 |
| 11 | .7935 | .8215 | .1029 | .0366 | .1844 | .8573 | .9313 |
| 12 | .8259 | .8551 | .12 | .0732 | .1844 | .9259 | .964 |
| 13 | .8259 | .8215 | .1372 | .1097 | .1509 | .9088 | .964 |
| 14 | .8097 | .788 | .1372 | .128 | .1677 | .9259 | |
| 15 | .8097 | .7712 | .1372 | .2561 | .1677 | .9431 | |
| 16 | .8097 | .788 | .1543 | .2926 | .1677 | .9431 | |
| 17 | .9114 | .8215 | .1029 | .2743 | .1509 | .9602 | .8596 |
| 18 | .0732 | .0335 | .1029 | .0732 | .1677 | .1029 | .0732 |
| 19 | .0914 | .0335 | .0686 | .0549 | .1715 | .1543 | .0914 |
| 20 | .1097 | .0503 | .0343 | .0366 | .1543 | .2058 | .0732 |
| 21 | .1097 | .0503 | .0343 | .0366 | .1543 | .2572 | .0366 |
| 22 | .128 | .0335 | .0343 | .0366 | .12 | .2058 | .0366 |
| 23 | .1097 | .0335 | .0343 | .0366 | .12 | .2058 | .0343 |
| 24 | .0514 | .1097 | .0335 | | .0366 | .12 | .1715 |
| **Max** | **.9114** | **.8551** | **.8383** | **.7545** | **.7537** | **.9602** | **.964** |
| **Min** | **.0514** | **.0335** | **.0335** | **.0343** | **.0366** | **.0857** | **.0343** |
| **Avg** | **.3809** | **.3275** | **.2896** | **.2852** | **.2862** | **.3901** | **.3111** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214455 / 33/11 KV SHIRSODI S/STN**
**Feeder No / Name : 202 / padasthal SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5658 | .6401 | .5487 | .583 | .5853 | .6001 | .6001 |
| 2 | .823 | .6584 | 1.286 | 1.7318 | 1.3847 | .6001 | .6001 |
| 3 | .823 | .695 | 1.3889 | 1.7833 | 1.4373 | .6001 | .6001 |
| 4 | .823 | .695 | 1.4918 | 1.8004 | 1.4373 | .6001 | .6001 |
| 5 | .823 | .7682 | 1.5947 | 1.8004 | 1.5074 | .6687 | .6516 |
| 6 | .9088 | .8596 | 1.7147 | 1.8861 | 1.5604 | .823 | .7373 |
| 7 | .8916 | .9511 | 1.8347 | 1.8861 | 1.6632 | .8573 | .823 |
| 8 | .6859 | .8048 | 1.8861 | 1.9033 | 1.8004 | .7202 | .7545 |
| 9 | .583 | .695 | 1.9547 | 1.9231 | 1.749 | .4973 | .6173 |
| 10 | 1.4899 | 1.7147 | .463 | .4938 | .6036 | 1.4575 | 1.7661 |
| 11 | 1.9919 | 2.0405 | .4458 | .4938 | .5316 | 1.5775 | 1.8519 |
| 12 | 1.9433 | 2.1091 | .4801 | | .3086 | 1.7147 | 1.9376 |
| 13 | 1.9433 | 2.0748 | | .3841 | .3429 | 1.869 | 1.9376 |
| 14 | 1.9433 | 2.0919 | | .4024 | .3772 | 1.9033 | 1.8861 |
| 15 | 1.9433 | 2.1262 | .3772 | .5121 | .4115 | 2.0062 | |
| 16 | 1.8461 | 2.0405 | .3944 | .5853 | .4458 | 1.9376 | 1.869 |
| 17 | 1.9719 | 1.9547 | .463 | .6584 | .583 | 1.9204 | 1.9547 |
| 18 | .567 | .5144 | .6173 | .823 | .6859 | .5144 | .567 |
| 19 | .6036 | .5144 | .6173 | .8596 | .7373 | .5316 | .7133 |
| 20 | .6401 | .5316 | .6344 | .823 | .7202 | .5658 | .695 |
| 21 | .6401 | .5487 | .6344 | .7682 | .6859 | .6001 | .6401 |
| 22 | .6036 | .5316 | .6173 | .7133 | .6344 | .6344 | .6401 |
| 23 | .6219 | .5144 | .6173 | .6584 | .6173 | .6001 | .6001 |
| 24 | .5658 | .6584 | .5144 | .583 | .6219 | .6173 | .6001 |
| **Max** | **1.9919** | **2.1262** | **1.9547** | **1.9231** | **1.8004** | **2.0062** | **1.9547** |
| **Min** | **.5658** | **.5144** | **.3772** | **.3841** | **.3086** | **.4973** | **.567** |
| **Avg** | **1.0934** | **1.1139** | **.9353** | **1.0459** | **.8930** | **1.0174** | **1.0279** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214455 / 33/11 KV SHIRSODI S/STN**
**Feeder No / Name : 203 / 11kv Ajoti SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4458 | .439 | .463 | .3601 | .4207 | | .3772 |
| 2 | 1.3717 | 1.4746 | .4973 | .4115 | .4572 | 1.4089 | 1.2955 |
| 3 | 1.8861 | 1.5089 | .5316 | .4115 | .4938 | 1.3927 | 1.3279 |
| 4 | 1.8861 | 1.5775 | .5658 | .4287 | .5121 | 1.4413 | 1.3279 |
| 5 | 1.9719 | 1.6632 | .6001 | .5228 | .567 | 1.4251 | 1.3603 |
| 6 | 2.0062 | 1.7318 | .6173 | .5487 | .6219 | 1.6194 | 1.5546 |
| 7 | 1.989 | 1.8004 | .6516 | .6344 | .6219 | 1.7166 | 1.6356 |
| 8 | 2.0233 | 1.9547 | .583 | .5144 | .5853 | 1.8138 | 1.6842 |
| 9 | 1.8623 | 1.8519 | .4458 | .4115 | .439 | 1.8004 | 1.587 |
| 10 | .3429 | .3292 | 1.8519 | 2.0576 | 1.989 | .2915 | .3109 |
| 11 | .2915 | .3258 | 2.332 | 2.2805 | 2.1948 | .2572 | |
| 12 | .2743 | .3258 | 2.2977 | 2.2634 | 2.2291 | .2743 | .2012 |
| 13 | .2572 | .3086 | 2.2634 | 2.2291 | 2.1262 | .2401 | .2195 |
| 14 | .2401 | .3086 | 2.2291 | 2.1262 | 2.0233 | .2058 | .2561 |
| 15 | .2401 | .3258 | 2.2291 | 2.0748 | 1.9547 | .1886 | .2743 |
| 16 | .2401 | .3258 | 2.1948 | 2.0233 | 1.9547 | .2572 | .2743 |
| 17 | .3292 | .3258 | 2.1262 | 1.9376 | 1.9547 | .2743 | .2926 |
| 18 | .3841 | .4458 | .3944 | .4755 | .3258 | .4115 | .4572 |
| 19 | .4207 | .4287 | .3601 | .4755 | .4458 | .4115 | .5121 |
| 20 | .4755 | .463 | .4108 | .4572 | .463 | .4115 | .4755 |
| 21 | .4938 | .4287 | .3944 | .4207 | .4458 | .4115 | .4572 |
| 22 | .439 | .463 | .4115 | .4024 | .3772 | .3944 | .4755 |
| 23 | .4572 | .4458 | .4115 | .439 | .3772 | .3772 | .4115 |
| 24 | .3944 | .439 | .4458 | .3944 | .439 | .3772 | .3772 |
| **Max** | **2.0233** | **1.9547** | **2.332** | **2.2805** | **2.2291** | **1.8138** | **1.6842** |
| **Min** | **.2401** | **.3086** | **.3601** | **.3601** | **.3258** | **.1886** | **.2012** |
| **Avg** | **.8634** | **.8205** | **1.0545** | **1.0125** | **1.0008** | **.7566** | **.7454** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214455 / 33/11 KV SHIRSODI S/STN**
**Feeder No / Name : 204 / 11kv Malwadi SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1543 | .2561 | .2012 | .1372 | .1829 | .1543 | .2058 |
| 2 | .6859 | .6805 | .218 | .1543 | .1829 | .9069 | .8259 |
| 3 | .8573 | .7522 | .2347 | .1715 | .2195 | .9231 | .8421 |
| 4 | .8573 | .7522 | .2347 | .1715 | .2561 | .9231 | .8421 |
| 5 | .8573 | .8238 | .2515 | .1886 | .2561 | .9231 | .8421 |
| 6 | 1.0117 | .8413 | .2683 | .1886 | .2926 | 1.004 | 1.0202 |
| 7 | .9945 | .8939 | .285 | .1886 | .2926 | 1.1174 | 1.1174 |
| 8 | 1.2003 | 1.0166 | .2683 | .2058 | .2926 | 1.1336 | 1.1984 |
| 9 | 1.0688 | .9991 | .2683 | .1886 | .2926 | 1.2346 | 1.166 |
| 10 | .2229 | .1646 | 1.0395 | 1.406 | 1.3847 | .2401 | .2195 |
| 11 | .2229 | .1509 | 1.3717 | 1.5089 | 1.4251 | .1715 | |
| 12 | .2229 | .2347 | 1.3889 | 1.6118 | 1.3748 | .1886 | .1463 |
| 13 | .2229 | .218 | 1.3717 | 1.6632 | 1.3413 | .2058 | .1829 |
| 14 | .2572 | .2012 | | 1.6118 | 1.3077 | .1886 | .2561 |
| 15 | .2572 | .1844 | | 1.5775 | 1.2574 | .2058 | .2561 |
| 16 | | .218 | | 1.5604 | 1.2071 | .2229 | .2195 |
| 17 | .2926 | .2683 | 1.4918 | 1.5089 | 1.1736 | .2401 | .2926 |
| 18 | .2926 | .3018 | .1715 | .1829 | .1174 | .2572 | .2743 |
| 19 | .2926 | .2515 | .1543 | .2195 | .1543 | .2614 | .2743 |
| 20 | .2926 | .218 | .1372 | .2195 | .1715 | .2058 | .2195 |
| 21 | .2743 | .2012 | .1494 | .2195 | .1543 | .2229 | .2012 |
| 22 | .2561 | .2012 | .12 | .2195 | .1543 | .2229 | .2195 |
| 23 | .2561 | .1844 | .1543 | .2195 | .1543 | .2229 | .2058 |
| 24 | .1543 | .2561 | .1844 | .1372 | .1829 | .1543 | .2058 |
| **Max** | **1.2003** | **1.0166** | **1.4918** | **1.6632** | **1.4251** | **1.2346** | **1.1984** |
| **Min** | **.1543** | **.1509** | **.12** | **.1372** | **.1174** | **.1543** | **.1463** |
| **Avg** | **.4872** | **.4279** | **.4745** | **.6442** | **.5762** | **.4805** | **.4884** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214465 / 33 KV KANDALGAON**
**Feeder No / Name : 201 / Kandalgaon SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0697 | | .2012 | .064 | .0743 | .1029 | .1029 |
| 2 | .2858 | .3086 | .2012 | .1238 | .0892 | .3086 | .5228 |
| 3 | .2858 | | .2035 | .0991 | .0937 | | .5228 |
| 4 | .3041 | | .2012 | .1097 | .0937 | .3772 | .5228 |
| 5 | .3185 | | .1989 | .1286 | .096 | | .5228 |
| 6 | .3227 | .3086 | .1989 | .1372 | .1326 | .463 | .5601 |
| 7 | .4548 | | .1966 | .1219 | .112 | .6001 | .5975 |
| 8 | .4401 | .463 | .1638 | .0914 | .125 | .6516 | .6722 |
| 9 | .4458 | .5258 | .1943 | .0914 | .1235 | | .5609 |
| 10 | | .1619 | | .6097 | .6859 | .1029 | .0983 |
| 11 | | .1943 | | .7011 | .7202 | .1029 | .1296 |
| 12 | | .192 | | .743 | .7202 | .1029 | .0949 |
| 13 | | .2241 | | .7526 | .6859 | .1029 | .1265 |
| 14 | | .2591 | | .6836 | .7716 | .1029 | .128 |
| 15 | | .2915 | | .6539 | .8573 | .1372 | .128 |
| 16 | | .2915 | | .6241 | | .1715 | .1296 |
| 17 | | .2683 | | .6836 | .8573 | .1372 | .1296 |
| 18 | | .2713 | | .0793 | .1372 | .1372 | .1658 |
| 19 | | .2683 | | .0793 | .8573 | .12 | .1677 |
| 20 | | .2683 | | .0777 | | .1029 | .1341 |
| 21 | | .2683 | .064 | .0823 | | .1029 | .1017 |
| 22 | | .2713 | .064 | .0617 | | .1029 | .1006 |
| 23 | | .2347 | .064 | .064 | | .1029 | .1017 |
| 24 | .0697 | .12 | 2.4291 | .064 | .064 | .1029 | .1029 |
| **Max** | **.4548** | **.5258** | **2.4291** | **.7526** | **.8573** | **.6516** | **.6722** |
| **Min** | **.0697** | **.12** | **.064** | **.0617** | **.064** | **.1029** | **.0949** |
| **Avg** | **.2997** | **.2732** | **.3370** | **.2886** | **.3840** | **.2017** | **.2677** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214465 / 33 KV KANDALGAON**
**Feeder No / Name : 202 / Mahadev Nagar SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2858 | | .4973 | .2667 | .2896 | .4287 | .5144 |
| 2 | .5001 | .6859 | .503 | .4087 | .2972 | .8573 | .8573 |
| 3 | .5001 | | .4973 | .4334 | .3048 | .8573 | .9335 |
| 4 | .5792 | .6859 | .4973 | .5068 | .3906 | .9431 | |
| 5 | .6516 | | .4973 | .2334 | .4801 | | 1.0269 |
| 6 | .6602 | .823 | .4973 | .535 | .4973 | 1.0974 | |
| 7 | .8802 | | .4915 | .5335 | .4687 | 1.2003 | 1.2136 |
| 8 | .8802 | 1.1317 | .4915 | .4572 | .4687 | 1.2689 | 1.307 |
| 9 | | 1.2136 | | .381 | .3858 | | 1.3146 |
| 10 | | .3239 | | .9907 | 1.286 | .4287 | .4049 |
| 11 | | .3239 | | 1.0669 | | .4287 | |
| 12 | | .3163 | | 1.0669 | 1.406 | .4287 | .3201 |
| 13 | | .3201 | | 1.1288 | | .4287 | .4001 |
| 14 | | .3239 | | 1.0997 | 1.406 | .4287 | .4801 |
| 15 | | .3239 | | 1.0551 | | .4287 | .4001 |
| 16 | | .3239 | | 1.0402 | 1.3717 | .4287 | .4049 |
| 17 | | .4144 | | 1.0402 | 1.3375 | .6001 | .4858 |
| 18 | | .503 | | .1981 | .4287 | .5487 | .663 |
| 19 | | .503 | | .1981 | | .5487 | .663 |
| 20 | | .503 | | .1943 | | .5144 | .6706 |
| 21 | | .503 | .3201 | .2058 | | .5144 | .6706 |
| 22 | | .503 | .3201 | .2058 | | .5144 | .5801 |
| 23 | | .503 | .2667 | .2134 | | .5144 | .5868 |
| 24 | .2905 | .3429 | .503 | .2667 | .2477 | .4287 | .5144 |
| **Max** | **.8802** | **1.2136** | **.503** | **1.1288** | **1.406** | **1.2689** | **1.3146** |
| **Min** | **.2858** | **.3163** | **.2667** | **.1943** | **.2477** | **.4287** | **.3201** |
| **Avg** | **.5809** | **.5286** | **.4485** | **.5719** | **.6917** | **.6290** | **.6863** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214465 / 33 KV KANDALGAON**
**Feeder No / Name : 203 / Hingangaon SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1859 | | .2321 | .16 | .1981 | .3086 | .2401 |
| 2 | .2286 | .3086 | 1.0136 | .6811 | .823 | .3086 | .2572 |
| 3 | .2572 | | 1.0136 | .8688 | .9374 | | .2572 |
| 4 | .2751 | .3429 | 1.0208 | .8916 | .9998 | .3772 | |
| 5 | .3041 | | 1.0387 | .8916 | 1.0562 | | |
| 6 | .3521 | .4458 | 1.0631 | .9214 | 1.094 | .5144 | |
| 7 | .3814 | | 1.1694 | .9755 | 1.0311 | .463 | |
| 8 | .3227 | .4115 | 1.2536 | 1.0212 | 1.0623 | .3944 | |
| 9 | .2378 | .2846 | 1.2048 | 1.0364 | 1.0802 | | |
| 10 | | 1.0985 | | .2134 | .2572 | 1.1576 | |
| 11 | | 1.3112 | | .1806 | | 1.307 | |
| 12 | | 1.3321 | | .1524 | .2401 | 1.3443 | .8859 |
| 13 | | 1.3289 | | .1505 | | 1.3256 | .964 |
| 14 | | 1.2757 | | .1486 | .2229 | 1.307 | .9991 |
| 15 | | 1.2934 | | .1783 | | 1.2696 | 1.0099 |
| 16 | | 1.2715 | | .208 | .2401 | 1.2136 | 1.0099 |
| 17 | | 1.3169 | | .2378 | .2572 | 1.307 | .985 |
| 18 | | .3353 | | .1882 | .3429 | 1.2346 | 1.086 |
| 19 | | .3315 | | .1981 | | .3429 | .3315 |
| 20 | | .2984 | | .1749 | | .3086 | .285 |
| 21 | | .2652 | .1707 | .1646 | | .2614 | .2486 |
| 22 | | .2515 | .16 | .1646 | | .2401 | .2347 |
| 23 | | .2321 | .16 | .1707 | | .2401 | .218 |
| 24 | .1859 | .2915 | 2.4291 | .16 | .1981 | .3086 | .2401 |
| **Max** | **.3814** | **1.3321** | **2.4291** | **1.0364** | **1.094** | **1.3443** | **1.086** |
| **Min** | **.1859** | **.2321** | **.16** | **.1486** | **.1981** | **.2401** | **.218** |
| **Avg** | **.2731** | **.7014** | **.9177** | **.4224** | **.6275** | **.7397** | **.5783** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214465 / 33 KV KANDALGAON**
**Feeder No / Name : 204 / 11 Kv Sardewadi SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2286 | | .2515 | .16 | .16 | .5144 | .3429 |
| 2 | .2858 | .2058 | 1.086 | .6192 | .6516 | .5144 | .3429 |
| 3 | .2896 | | 1.086 | .724 | .6859 | | .3429 |
| 4 | .2896 | .2058 | 1.0745 | .743 | .7811 | .5144 | .4287 |
| 5 | .362 | | 1.0745 | .743 | .8002 | | .4287 |
| 6 | .3668 | .2572 | 1.0631 | .8173 | .8288 | .5487 | |
| 7 | .3668 | | 1.2403 | .9145 | .9374 | .3601 | .4287 |
| 8 | .3668 | .2743 | 1.2536 | 1.0669 | .9374 | .3601 | .4287 |
| 9 | .2972 | .2214 | 1.2269 | 1.0669 | .9259 | | .3163 |
| 10 | | 1.2536 | | .381 | .4287 | 1.1203 | 1.1517 |
| 11 | | 1.4175 | | .4572 | | 1.2136 | 1.3289 |
| 12 | | 1.4175 | | .3048 | .4801 | 1.4003 | 1.3146 |
| 13 | | 1.4175 | | .301 | | 1.4937 | 1.4175 |
| 14 | | 1.4175 | | .2972 | .463 | 1.4937 | 1.4022 |
| 15 | | 1.4327 | | .3715 | | 1.4937 | 1.4175 |
| 16 | | 1.4327 | | .3715 | .4801 | 1.4937 | 1.4175 |
| 17 | | 1.448 | | .4458 | .5144 | 1.4937 | 1.4327 |
| 18 | | .2515 | | .2477 | .5658 | .2572 | .2515 |
| 19 | | .2486 | | .2477 | | .3429 | .2543 |
| 20 | | .2515 | | .1943 | | .3429 | .2543 |
| 21 | | .2486 | .2134 | .2058 | | .3429 | .2543 |
| 22 | | .2515 | .2134 | .2058 | | .3429 | .2486 |
| 23 | | .2515 | .16 | .2134 | | .3429 | .2515 |
| 24 | .2324 | .2058 | .2515 | .16 | .16 | .5144 | .3429 |
| **Max** | **.3668** | **1.448** | **1.2536** | **1.0669** | **.9374** | **1.4937** | **1.4327** |
| **Min** | **.2286** | **.2058** | **.16** | **.16** | **.16** | **.2572** | **.2486** |
| **Avg** | **.3086** | **.7055** | **.7842** | **.4691** | **.6125** | **.7858** | **.6869** |

 Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052]** **BU 5894**
**Substation No/ Name :- 214465 / 33 KV KANDALGAON**
**Feeder No / Name : 205 / Kandalgaon GFSS** **GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0232 | | .0343 | .0213 | .0248 | .0343 | .0343 |
| 2 | .0429 | .0343 | .0343 | .0248 | .0446 | .0343 | .0343 |
| 3 | .0572 | | .0509 | .0434 | .061 | | .0514 |
| 4 | .0724 | .0514 | .0678 | .0743 | .0781 | .0686 | .0514 |
| 5 | | | .1006 | .1219 | .096 | | .0857 |
| 6 | .1027 | .12 | .1174 | .1219 | .116 | .1372 | .12 |
| 7 | .1027 | | .1147 | .1067 | .125 | .1372 | |
| 8 | .088 | .0857 | .0829 | .0914 | .125 | .12 | .1029 |
| 9 | .0743 | .0663 | .0648 | .0762 | .0926 | | .081 |
| 10 | | .0497 | | .061 | .0686 | .0514 | .0655 |
| 11 | | .0328 | | .0457 | | .0343 | .0486 |
| 12 | | .0328 | | .0457 | .0343 | .0343 | .0324 |
| 13 | | .0328 | | .0301 | | .0343 | .0324 |
| 14 | | .0332 | | .0297 | .0343 | .0343 | .0324 |
| 15 | | .0332 | | .0297 | | .0343 | .0324 |
| 16 | | .0328 | | .0297 | .0343 | .0343 | .0328 |
| 17 | | .0503 | | .0297 | .0514 | .0343 | .0492 |
| 18 | | .0678 | | .0297 | .0857 | .0857 | .1029 |
| 19 | | .0848 | | .0396 | | .1029 | .1029 |
| 20 | | .0857 | | .0389 | | .0686 | .0857 |
| 21 | | .0678 | .032 | .0309 | | .0514 | .0509 |
| 22 | | .0509 | .0213 | .0309 | | .0343 | .0514 |
| 23 | | .0343 | .0213 | .0213 | | .0343 | .0343 |
| 24 | .0232 | .0343 | .0343 | .0213 | .0248 | .0343 | .0343 |
| **Max** | **.1027** | **.12** | **.1174** | **.1219** | **.125** | **.1372** | **.12** |
| **Min** | **.0232** | **.0328** | **.0213** | **.0213** | **.0248** | **.0343** | **.0324** |
| **Avg** | **.0652** | **.0540** | **.0597** | **.0498** | **.0685** | **.0588** | **.0587** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214466 / 33/11 KV BIJEWADI**
**Feeder No / Name : 201 / Bijewadi SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3772 | .3734 | .5487 | .3772 | .3734 | .3734 | .3734 |
| 2 | 1.5089 | 1.5432 | 1.326 | .3772 | .3734 | 1.7147 | 1.7147 |
| 3 | 1.5089 | 1.5432 | 1.326 | .3772 | .3734 | 1.7147 | 1.7147 |
| 4 | 1.4632 | 1.5432 | 1.326 | .3772 | .3734 | 1.7147 | 1.7147 |
| 5 | 1.8099 | 1.5432 | .543 | .3772 | .3734 | 1.7147 | 1.7147 |
| 6 | 1.7718 | 1.7147 | .543 | .3772 | .3734 | 1.7147 | 1.7147 |
| 7 | 1.7528 | 1.8861 | .543 | .5601 | .3734 | 1.8861 | 1.8861 |
| 8 | 1.7718 | 2.0576 | .462 | .3772 | .3734 | 1.8861 | 2.0576 |
| 9 | 1.7147 | 2.0576 | .462 | .1886 | .3734 | 1.8861 | 2.0576 |
| 10 | .1867 | .1867 | .1829 | 1.9433 | 2.0576 | .1867 | .1867 |
| 11 | .1867 | .2743 | 2.0576 | 2.1338 | 2.3148 | .1638 | |
| 12 | .1867 | .2743 | 2.2291 | 2.1338 | 2.4006 | .1638 | .1867 |
| 13 | .3734 | .4572 | 2.4006 | 2.1338 | 2.4006 | .2486 | .2801 |
| 14 | .3734 | .4525 | 2.4006 | 2.1338 | 2.4006 | .2458 | .3734 |
| 15 | .3734 | .543 | 2.4006 | 2.2862 | 2.4006 | .2458 | .3734 |
| 16 | .3734 | .543 | 2.4006 | 2.2862 | 2.4006 | .2458 | .3734 |
| 17 | .3734 | .5487 | 2.0576 | 1.9814 | 2.3148 | .2458 | .3734 |
| 18 | .3734 | .5487 | .3772 | .3734 | .3734 | .3506 | .3734 |
| 19 | .3734 | .5487 | .3772 | .3734 | .3734 | .3734 | .3734 |
| 20 | .3734 | .5487 | .3772 | .3734 | .3734 | .3734 | .3734 |
| 21 | .3734 | .5487 | .3772 | .3734 | .3734 | .3734 | .3734 |
| 22 | .3734 | .543 | .3772 | .3734 | .3734 | .3734 | .3734 |
| 23 | .3734 | .543 | .3772 | .3734 | .3734 | .3734 | .3734 |
| 24 | .3772 | .3734 | .543 | .3772 | .3734 | .3734 | .3734 |
| **Max** | **1.8099** | **2.0576** | **2.4006** | **2.2862** | **2.4006** | **1.8861** | **2.0576** |
| **Min** | **.1867** | **.1867** | **.1829** | **.1886** | **.3734** | **.1638** | **.1867** |
| **Avg** | **.7802** | **.8832** | **1.0840** | **.9600** | **1.0277** | **.7893** | **.8569** |

 Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052]** **BU 5894**
**Substation No/ Name :- 214466 / 33/11 KV BIJEWADI**
**Feeder No / Name : 202 / Gaagargaon** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1886 | .1715 | .0676 | .0943 | .1867 | .1715 | .1715 |
| 2 | .1886 | .1715 | .0676 | 1.3203 | .8097 | .1715 | .1715 |
| 3 | .1886 | .1715 | .0676 | 1.3203 | .8097 | .1715 | .1715 |
| 4 | .1886 | .1715 | .0676 | 1.307 | .8097 | .1715 | .1715 |
| 5 | .1886 | .1715 | 1.1069 | 1.307 | .7621 | .1715 | .1715 |
| 6 | .1886 | .1715 | 1.1069 | 1.307 | .9145 | .1715 | .1715 |
| 7 | .1886 | .1715 | 1.1069 | 1.2003 | .9145 | .1715 | .1715 |
| 8 | .1829 | .1715 | 1.1336 | 1.286 | .9145 | .1715 | .1715 |
| 9 | .1867 | .1715 | 1.1469 | 1.3146 | .9907 | .1715 | .1715 |
| 10 | 1.4575 | 1.3717 | .0762 | .1867 | .0857 | 1.2003 | 1.2003 |
| 11 | 1.5432 | 1.2955 | .0934 | .1867 | .0857 | 1.1069 | |
| 12 | 1.5432 | 1.2955 | .0934 | .1867 | .0857 | 1.1069 | .9717 |
| 13 | 1.5432 | 1.2955 | .0934 | .1867 | .0857 | 1.1069 | 1.0669 |
| 14 | 1.5432 | 1.2955 | .0924 | .1867 | .0857 | 1.0936 | 1.0669 |
| 15 | 1.5432 | 1.2955 | .1848 | .1867 | .0857 | 1.0936 | 1.0669 |
| 16 | 1.5432 | 1.2955 | .1848 | .1867 | .0857 | 1.186 | 1.1336 |
| 17 | 1.4575 | 1.2955 | .1848 | .1867 | .1715 | 1.2289 | 1.0669 |
| 18 | .0857 | .081 | .0943 | .1867 | .1715 | .0781 | .0934 |
| 19 | .1715 | .0819 | .0943 | .1867 | .1715 | .1715 | .0934 |
| 20 | .1715 | .0819 | .0943 | .1867 | .1715 | .1715 | .0934 |
| 21 | .1715 | .0686 | .0943 | .1867 | .1715 | .1715 | .0934 |
| 22 | .1715 | .0676 | .0943 | .1867 | .1715 | .1715 | .0934 |
| 23 | .1715 | .0648 | .0943 | .1867 | .1715 | .1715 | .0934 |
| 24 | .1886 | .1715 | .0648 | .0943 | .1867 | .1715 | .1715 |
| **Max** | **1.5432** | **1.3717** | **1.1469** | **1.3203** | **.9907** | **1.2289** | **1.2003** |
| **Min** | **.0857** | **.0648** | **.0648** | **.0943** | **.0857** | **.0781** | **.0934** |
| **Avg** | **.6248** | **.5250** | **.3127** | **.5485** | **.3791** | **.4906** | **.4282** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214466 / 33/11 KV BIJEWADI**
**Feeder No / Name : 203 / Bijawadi GFSS GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2829 | .2801 | .3734 | .2829 | .2801 | .2801 | .2801 |
| 2 | .2829 | .2801 | .3734 | .2829 | .2801 | .2801 | .2801 |
| 3 | .2829 | .2801 | .3734 | .2829 | .2801 | .2801 | .2801 |
| 4 | .2829 | .3734 | .3734 | .2829 | .3734 | .2801 | |
| 5 | .3772 | .4668 | .4668 | .3772 | .4668 | .3734 | .3734 |
| 6 | .5658 | .5601 | .6535 | .5658 | .5601 | .4668 | .5601 |
| 7 | .5658 | .6535 | .7468 | | .6535 | .5601 | .6535 |
| 8 | .5601 | .7468 | .7468 | .5658 | .6535 | .5601 | .5601 |
| 9 | .5658 | .3734 | .5544 | .4668 | .5601 | .4668 | .4668 |
| 10 | .4668 | .3734 | .5601 | .4668 | .4668 | .3734 | .3734 |
| 11 | .3734 | .362 | .3658 | .3734 | .4668 | .3772 | |
| 12 | .3734 | .362 | .2743 | .3734 | .3734 | .1886 | .2801 |
| 13 | .2801 | .3658 | .2743 | .2801 | .2801 | .1886 | .2801 |
| 14 | .2801 | .2743 | .2743 | .2801 | .2801 | .1886 | .2801 |
| 15 | .2801 | .2743 | .2772 | .1867 | .2801 | .2743 | .2801 |
| 16 | .2801 | | .2772 | .1867 | .2801 | .362 | .2801 |
| 17 | .2801 | .2772 | | .2801 | .2801 | .3658 | .2801 |
| 18 | .3734 | .462 | .3734 | .3734 | .3734 | .4572 | .4668 |
| 19 | .4668 | .4668 | .3772 | .4668 | .4668 | .4668 | .4668 |
| 20 | .4668 | .4668 | .4715 | .4668 | .4668 | .4668 | .4668 |
| 21 | .3734 | .4668 | .4715 | .4668 | .3734 | .3734 | .4668 |
| 22 | .3734 | .4668 | .3772 | .3734 | .2801 | .2801 | .3734 |
| 23 | .2801 | .3734 | .2829 | .2801 | .2801 | .2801 | .2801 |
| 24 | .2829 | .2801 | .3772 | .2829 | .2801 | .2801 | .2801 |
| **Max** | **.5658** | **.7468** | **.7468** | **.5658** | **.6535** | **.5601** | **.6535** |
| **Min** | **.2801** | **.2743** | **.2743** | **.1867** | **.2801** | **.1886** | **.2801** |
| **Avg** | **.3749** | **.4037** | **.4216** | **.3585** | **.3890** | **.3529** | **.3777** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052]** **BU 5894**
**Substation No/ Name :- 214466 / 33/11 KV BIJEWADI**
**Feeder No / Name : 204 / PUNKULWADI AG** **FEEDER SEPERATION/PURE AG**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2829 | .2429 | .2458 | .2829 | .2429 | .2429 | .2429 |
| 2 | | 1.2146 | 1.2289 | .2829 | .2429 | 1.1336 | 1.1336 |
| 3 | | 1.2955 | 1.2289 | .2829 | .2429 | 1.1336 | 1.1336 |
| 4 | | 1.3765 | 1.2289 | .2829 | .2429 | 1.1336 | 1.1336 |
| 5 | | 1.4575 | .3277 | .3772 | .3239 | 1.2955 | 1.2955 |
| 6 | | 1.6194 | .4096 | .4715 | .4049 | 1.4575 | 1.4575 |
| 7 | .9745 | 1.7814 | .4096 | .5601 | .4049 | 1.6194 | 1.7814 |
| 8 | 1.448 | 2.1052 | .4096 | .4049 | .4049 | 1.8623 | 1.9433 |
| 9 | 1.5432 | 2.1052 | .4096 | .4049 | .3239 | 1.8623 | 2.1052 |
| 10 | .081 | .2429 | .3277 | 1.5384 | 1.6194 | .1619 | .2429 |
| 11 | .081 | .1638 | 2.1033 | 2.0805 | 2.0243 | .1638 | |
| 12 | .081 | .2458 | 2.3148 | 2.0805 | 2.1862 | .1638 | .1619 |
| 13 | | .1638 | 2.4006 | 1.9204 | 2.1862 | .1638 | .2429 |
| 14 | .2429 | .1638 | 2.572 | 1.9204 | 2.1052 | | .2429 |
| 15 | .2429 | .1638 | 2.3472 | 1.8404 | 1.9433 | | .2429 |
| 16 | .3239 | | 2.2291 | 1.7604 | 1.7814 | .1638 | .1619 |
| 17 | .2429 | .1638 | 2.0576 | 1.7004 | 1.3765 | .2458 | .1619 |
| 18 | .3239 | .3277 | .2829 | .2429 | .2429 | .3277 | .3239 |
| 19 | .4049 | .3277 | .3772 | .3239 | .3239 | .4049 | .4049 |
| 20 | .3239 | .3277 | .3772 | .3239 | .3239 | .4049 | .4049 |
| 21 | .3239 | .3277 | .3772 | .2429 | .3239 | .3239 | .3239 |
| 22 | .2429 | .2458 | .2829 | .2429 | .2429 | .3239 | .3239 |
| 23 | .2429 | .2458 | .2829 | .2429 | .2429 | .2429 | .2429 |
| 24 | .2829 | .2429 | .2458 | .2829 | .2429 | .2429 | .2429 |
| **Max** | **1.5432** | **2.1052** | **2.572** | **2.0805** | **2.1862** | **1.8623** | **2.1052** |
| **Min** | **.081** | **.1638** | **.2458** | **.2429** | **.2429** | **.1619** | **.1619** |
| **Avg** | **.4272** | **.7196** | **1.0199** | **.8372** | **.8333** | **.6852** | **.6935** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214468 / 33/11KV Nimgaon Ketki**
**Feeder No / Name : 201 / 11kv Pitkeshwer SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .3772 | .3961 | | .4338 | .4115 | .415 |
| 2 | .3772 | .3772 | .8676 | .5144 | .8299 | | .3961 |
| 3 | | .3772 | .9054 | | .8676 | .3601 | .4527 |
| 4 | .4287 | .3944 | .9431 | .8573 | .9242 | | .5093 |
| 5 | | .4287 | 1.2826 | | 1.1506 | .4115 | .5847 |
| 6 | .6173 | .5487 | 1.3957 | 1.286 | 1.2637 | .5144 | .6413 |
| 7 | .4287 | .583 | 1.6032 | 1.6289 | 1.773 | | .547 |
| 8 | | | 1.9993 | 1.7604 | 2.0182 | | .547 |
| 9 | | | 1.9239 | 1.7404 | 1.9805 | | |
| 10 | 1.4586 | 1.3565 | | | | 1.4074 | 1.3889 |
| 11 | 1.5939 | | | | | 1.5939 | 1.4575 |
| 12 | 1.8313 | | | | | 1.7295 | 1.6289 |
| 13 | 1.7974 | 1.4586 | | | | 1.7295 | 1.5432 |
| 14 | 1.0343 | 1.6712 | | | | 1.7295 | 1.4937 |
| 15 | 1.4752 | 1.9109 | .2374 | .3258 | .373 | 1.6956 | 1.286 |
| 16 | 1.5939 | 1.8143 | .39 | .3294 | .4239 | 1.5261 | 1.2003 |
| 17 | 1.4232 | 1.8484 | | .4715 | .4578 | 1.5844 | 1.3094 |
| 18 | .5144 | .3961 | | .6036 | .4973 | .4904 | .4458 |
| 19 | .5144 | .4715 | | .5658 | | .4715 | .4973 |
| 20 | .463 | .547 | | .5281 | .5144 | .4338 | .3944 |
| 21 | .4287 | .4904 | | .4904 | | .4338 | |
| 22 | .3944 | .4338 | | .4527 | .4973 | .4338 | |
| 23 | .3772 | .415 | | .4338 | .4287 | | |
| 24 | .3601 | .3814 | .3961 | .3429 | .4338 | .4115 | .415 |
| **Max** | **1.8313** | **1.9109** | **1.9993** | **1.7604** | **2.0182** | **1.7295** | **1.6289** |
| **Min** | **.3601** | **.3772** | **.2374** | **.3258** | **.373** | **.3601** | **.3944** |
| **Avg** | **.9006** | **.8141** | **1.0284** | **.7707** | **.8746** | **.9649** | **.8577** |

 Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052]** **BU 5894**
**Substation No/ Name :- 214468 / 33/11KV Nimgaon Ketki**
**Feeder No / Name : 202 / Vyahali** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .6344 | .6979 | | .6602 | .7716 | .7167 |
| 2 | .7202 | .6344 | .7922 | .8059 | .7922 | | .7167 |
| 3 | | .6415 | .9054 | .8288 | .8676 | .7545 | .7167 |
| 4 | | | .9619 | 1.0059 | .9619 | | .7922 |
| 5 | | .7802 | 1.1128 | 1.2431 | 1.1506 | .8573 | .9619 |
| 6 | .7202 | 1.1145 | 1.2449 | 1.3413 | 1.2637 | 1.1145 | 1.2826 |
| 7 | 1.0802 | 1.1488 | 1.4901 | 1.6108 | 1.7164 | | 1.2637 |
| 8 | | | 2.1125 | 1.989 | 2.1502 | | 1.2637 |
| 9 | | | 1.7164 | 1.8233 | 2.0182 | | |
| 10 | 1.5261 | 1.4413 | | | | 1.2548 | 1.4575 |
| 11 | 1.8299 | 1.8991 | | | | | 1.3717 |
| 12 | 1.9669 | 1.9161 | | | | | 1.8004 |
| 13 | | 1.8652 | | | | | 1.5432 |
| 14 | 1.95 | 1.6766 | | | | 1.8313 | 1.5432 |
| 15 | 1.95 | 1.6787 | .4191 | .4973 | .5256 | 1.8821 | 1.4575 |
| 16 | 1.95 | 1.7604 | .5256 | .5426 | .4917 | 1.6278 | 1.3923 |
| 17 | 1.95 | | | .8865 | .7969 | 1.6409 | 1.4918 |
| 18 | .9015 | 1.8861 | | 1.0374 | .9431 | .8865 | .8322 |
| 19 | .9882 | .8676 | | .9808 | | .8676 | .9362 |
| 20 | .9189 | .8865 | | .9431 | 1.0631 | .8676 | .823 |
| 21 | .8669 | .7922 | | .8488 | | .811 | |
| 22 | .7802 | .6979 | | .7356 | 1.0288 | .7733 | |
| 23 | .6661 | .6979 | | .6979 | .9259 | | |
| 24 | .6516 | .6415 | .6979 | .5144 | .6602 | .8573 | .6979 |
| **Max** | **1.9669** | **1.9161** | **2.1125** | **1.989** | **2.1502** | **1.8821** | **1.8004** |
| **Min** | **.6516** | **.6344** | **.4191** | **.4973** | **.4917** | **.7545** | **.6979** |
| **Avg** | **1.2598** | **1.1830** | **1.0564** | **1.0185** | **1.0598** | **1.1199** | **1.1531** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214468 / 33/11KV Nimgaon Ketki**
**Feeder No / Name : 203 / 11KV INDAPUR SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .3121 | .3584 | .3772 | .3961 | .3429 | .4527 |
| 2 | .3944 | .3121 | .6036 | .5144 | .6224 | | .3961 |
| 3 | | .3086 | .6413 | .7716 | .7167 | .2915 | .4338 |
| 4 | | .3429 | .7167 | 1.0117 | .7922 | | .4715 |
| 5 | .463 | .3772 | .7733 | 1.0288 | .8865 | .3429 | .5847 |
| 6 | .4973 | .5487 | .9242 | 1.0631 | .9997 | .4287 | .6979 |
| 7 | .5144 | .583 | 1.1694 | 1.0059 | 1.3392 | | .6413 |
| 8 | | | 1.5089 | 1.5415 | 1.5089 | | |
| 9 | | | 1.4712 | 1.5746 | 1.4712 | | |
| 10 | 1.1961 | 1.17 | | | | .9724 | 1.0631 |
| 11 | 1.4074 | 1.2887 | | | | 1.0513 | 1.1145 |
| 12 | 1.3735 | 1.2378 | | | | 1.2887 | 1.286 |
| 13 | 1.3735 | 1.3565 | | | | 1.2548 | |
| 14 | 1.4243 | 1.4074 | | | | 1.2039 | 1.2003 |
| 15 | 1.3395 | 1.2289 | .2374 | .2915 | .407 | 1.2146 | 1.0974 |
| 16 | 1.4582 | 1.17 | .3391 | .3429 | .407 | 1.1469 | 1.1145 |
| 17 | 1.4074 | 1.3203 | .3561 | .3961 | .4409 | 1.2449 | 1.0774 |
| 18 | .4334 | .4338 | .373 | .547 | .4287 | .4338 | .5028 |
| 19 | .3988 | .4715 | .407 | .5281 | | .4715 | .4801 |
| 20 | .3988 | .5093 | .4287 | .4904 | .463 | .5281 | .4287 |
| 21 | .3601 | .4527 | .4287 | .4527 | | .5093 | |
| 22 | .3258 | .3772 | .3772 | .415 | .4115 | .4715 | |
| 23 | .3086 | .3584 | .3772 | .415 | .3772 | | |
| 24 | .3429 | .3086 | .3584 | .3429 | .3961 | .3601 | .4527 |
| **Max** | **1.4582** | **1.4074** | **1.5089** | **1.5746** | **1.5089** | **1.2887** | **1.286** |
| **Min** | **.3086** | **.3086** | **.2374** | **.2915** | **.3772** | **.2915** | **.3961** |
| **Avg** | **.8114** | **.7216** | **.6237** | **.6900** | **.7097** | **.7532** | **.7498** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214468 / 33/11KV Nimgaon Ketki**
**Feeder No / Name : 204 / 11KV Varkute(kh) SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | 1.2136 | 1.4335 | 1.0288 | 1.2826 | 1.1317 | 1.2071 |
| 2 | 1.5432 | 1.491 | 1.3769 | 1.0402 | 1.2826 | | 1.4146 |
| 3 | | 1.4582 | 1.3769 | .9602 | 1.3203 | 1.5432 | 1.4712 |
| 4 | 1.7147 | 1.5261 | 1.4146 | 1.0402 | 1.3769 | | 1.6221 |
| 5 | | 1.7604 | 1.4901 | 1.1488 | 1.4712 | 1.6289 | 1.7353 |
| 6 | 2.2291 | 2.7978 | 1.773 | 1.2483 | 1.6409 | 1.7147 | 2.1691 |
| 7 | 2.6578 | 2.8487 | 1.7353 | 1.6289 | 1.5278 | 2.6578 | 2.9613 |
| 8 | 3.7723 | 3.8561 | | | | 3.3608 | 3.5837 |
| 9 | 3.7473 | 3.5778 | | | | 3.1722 | 3.1722 |
| 10 | | | 2.7726 | 3.0013 | 2.6282 | | |
| 11 | | | 3.8152 | 3.2726 | 3.2726 | | |
| 12 | | | 3.7304 | 3.2861 | 3.1878 | | |
| 13 | | | 3.6456 | 3.1824 | 2.8826 | | |
| 14 | | | 3.4591 | 2.9835 | 2.8487 | | |
| 15 | .7461 | .7461 | 2.6621 | 3.0498 | 2.9165 | .3222 | .6859 |
| 16 | .9496 | .8648 | 3.2386 | 3.0333 | 2.8656 | .763 | .8402 |
| 17 | 1.0682 | 1.2071 | 3.2217 | 2.6029 | 2.5774 | .9997 | 1.0402 |
| 18 | 1.3523 | 1.5466 | .9326 | 1.1883 | .8573 | 1.358 | 1.2656 |
| 19 | 1.4737 | 1.5844 | 1.0117 | 1.226 | | | 1.335 |
| 20 | 1.3176 | 1.6221 | 1.1317 | 1.2826 | 1.2003 | 1.2637 | 1.2517 |
| 21 | 1.283 | 1.5655 | 1.2136 | 1.3014 | | 1.2449 | |
| 22 | 1.2483 | 1.5089 | 1.1145 | 1.3203 | 1.1317 | 1.2071 | |
| 23 | 1.2309 | 1.4712 | 1.0174 | 1.2637 | 1.1257 | | |
| 24 | 1.1145 | 1.2003 | 1.4335 | .9431 | 1.2826 | 1.0802 | 1.2071 |
| **Max** | **3.7723** | **3.8561** | **3.8152** | **3.2861** | **3.2726** | **3.3608** | **3.5837** |
| **Min** | **.7461** | **.7461** | **.9326** | **.9431** | **.8573** | **.3222** | **.6859** |
| **Avg** | **1.7155** | **1.7814** | **2.0455** | **1.8651** | **1.9340** | **1.5632** | **1.6851** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214468 / 33/11KV Nimgaon Ketki**
**Feeder No / Name : 205 / Nlmgaon GFSS GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .2229 | .2641 | .373 | .2829 | .3086 | .2641 |
| 2 | .3258 | .2229 | .2452 | .3561 | .2263 | | .2641 |
| 3 | | .2229 | .2452 | .3052 | .2829 | .2401 | .2829 |
| 4 | .3086 | .2229 | .3395 | .2883 | .3395 | | .3961 |
| 5 | | .3772 | .3961 | .2883 | .5093 | .2401 | .5093 |
| 6 | .5316 | .6001 | .6224 | .3222 | .5847 | .5144 | .6224 |
| 7 | .6859 | .6859 | .679 | .6274 | .679 | .6687 | .7167 |
| 8 | .6516 | .6173 | .6979 | .5426 | .679 | .6516 | .6413 |
| 9 | .5256 | .5596 | .547 | .5087 | .547 | .5144 | .4801 |
| 10 | .4096 | .39 | .547 | .407 | .4409 | .39 | .4287 |
| 11 | .373 | .3561 | .373 | .373 | .4409 | .3277 | .4287 |
| 12 | | .39 | .3561 | .3561 | .3277 | .3113 | .4115 |
| 13 | .3113 | .2713 | .3391 | .2883 | .3391 | .2713 | .3772 |
| 14 | .3052 | .373 | .3222 | .39 | .3391 | .3222 | .2743 |
| 15 | .3052 | .3113 | .3561 | .3561 | .3222 | .3222 | .3086 |
| 16 | .3391 | .3185 | .3222 | .373 | .2883 | .3391 | .373 |
| 17 | .39 | .3961 | .3601 | .3584 | .3391 | .415 | .3391 |
| 18 | .4458 | .6036 | .4115 | .4527 | .4287 | .5658 | .4917 |
| 19 | .4557 | .5658 | .4287 | .4715 | | .5281 | .5087 |
| 20 | .3988 | .5658 | .463 | .4715 | .6173 | .4715 | .4239 |
| 21 | .3429 | .3961 | .5144 | .3961 | | .415 | |
| 22 | .2713 | .3206 | .463 | .3395 | .463 | .3584 | |
| 23 | .2374 | .2829 | .4115 | .3018 | .4287 | | |
| 24 | .4115 | .2204 | .2641 | .3772 | .2829 | .3601 | .2641 |
| **Max** | **.6859** | **.6859** | **.6979** | **.6274** | **.679** | **.6687** | **.7167** |
| **Min** | **.2374** | **.2204** | **.2452** | **.2883** | **.2263** | **.2401** | **.2641** |
| **Avg** | **.4013** | **.3956** | **.4154** | **.3885** | **.4177** | **.4065** | **.4194** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214468 / 33/11KV Nimgaon Ketki**
**Feeder No / Name : 206 / 11 KV Gotondi SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .6415 | .679 | .5144 | .6036 | | .6979 |
| 2 | 1.286 | 1.3413 | .679 | .5144 | .7167 | | 1.5089 |
| 3 | | 1.3592 | .7167 | .463 | .7356 | 1.286 | 1.5466 |
| 4 | 1.5432 | 1.4413 | .7545 | .463 | .811 | | 1.6787 |
| 5 | | 1.8004 | .9619 | .5144 | .9808 | 1.6289 | 1.9239 |
| 6 | | 2.5149 | 1.226 | .8573 | 1.1317 | 1.8861 | 2.3765 |
| 7 | 2.1434 | 2.6658 | 1.0374 | 1.0288 | 1.0374 | 2.572 | 2.8481 |
| 8 | 3.4294 | 2.8166 | | | | 3.0864 | 3.3385 |
| 9 | 2.9504 | .39 | | | | 3.0007 | 2.7435 |
| 10 | | | 2.6406 | 2.3868 | 2.4078 | 1.3395 | |
| 11 | | | 3.5947 | 2.9504 | 2.9843 | 1.2887 | |
| 12 | | | 3.5778 | 3.083 | 2.9673 | 1.2548 | |
| 13 | | | 3.3532 | 3.1327 | 2.8826 | 1.5939 | |
| 14 | | | .5935 | 3.083 | 2.73 | 1.6712 | |
| 15 | .3185 | .1696 | 3.086 | 2.9172 | 2.8147 | 1.6448 | .4287 |
| 16 | .5087 | .5243 | 3.2386 | 2.652 | 2.0687 | .4748 | .5144 |
| 17 | .5935 | .7733 | 3.2322 | 2.7538 | 2.3061 | .811 | .6935 |
| 18 | 1.0056 | .9242 | .4973 | .811 | .5144 | 1.0374 | .8149 |
| 19 | .9536 | .9054 | .6274 | .8488 | | .9619 | 1.0056 |
| 20 | .7628 | .8865 | .6859 | .8488 | .583 | .9054 | .7888 |
| 21 | .6935 | .811 | .7202 | .7922 | | .8299 | |
| 22 | .6762 | .7167 | .6859 | .7545 | .583 | .7545 | |
| 23 | .6415 | .679 | .6344 | .7167 | .6001 | | |
| 24 | .6235 | .6344 | .679 | .6001 | .6413 | .6001 | .6979 |
| **Max** | **3.4294** | **2.8166** | **3.5947** | **3.1327** | **2.9843** | **3.0864** | **3.3385** |
| **Min** | **.3185** | **.1696** | **.4973** | **.463** | **.5144** | **.4748** | **.4287** |
| **Avg** | **1.2087** | **1.1577** | **1.5410** | **1.4857** | **1.5050** | **1.4314** | **1.4754** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214468 / 33/11KV Nimgaon Ketki**
**Feeder No / Name : 207 / Fadtare NON SHEDDABLE EXPRESS HV FEEDERS**
**Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | .0226 | .0206 | .0226 | | .0226 |
| 2 | | | .0226 | .0206 | .0226 | | .0226 |
| 3 | | | .0226 | .0206 | .0226 | .0206 | .0226 |
| 4 | | | .0226 | .024 | .0226 | | .0226 |
| 5 | | | .0226 | .0206 | .0226 | | .0226 |
| 6 | | | .0226 | .0206 | .0302 | .0206 | .0302 |
| 7 | | | .0302 | .0206 | .0302 | .0206 | .0226 |
| 8 | .0206 | | .0302 | .0206 | .0302 | .0291 | .0226 |
| 9 | .0203 | | .1886 | .1715 | .2641 | .2401 | |
| 10 | .2035 | .0268 | .2075 | .2058 | .1696 | .2374 | .2229 |
| 11 | .1865 | .0271 | .2204 | .1886 | .2374 | .2374 | .2058 |
| 12 | .2204 | .0271 | .2401 | .2058 | .1526 | .2374 | .2058 |
| 13 | .1966 | .0271 | .2401 | .1696 | .2035 | .1865 | .1543 |
| 14 | .1715 | .0262 | .1372 | .2035 | .2035 | .2035 | .2058 |
| 15 | .1865 | .0262 | .2058 | .2374 | .2035 | .2204 | .1886 |
| 16 | .2035 | .0268 | .2035 | .2204 | .2204 | .1865 | .2058 |
| 17 | .2229 | .0302 | .1715 | .1886 | .2204 | .2263 | .2401 |
| 18 | .1696 | .0226 | | .2263 | .2058 | .1132 | .2229 |
| 19 | .2572 | .0226 | .2058 | .2263 | | .1509 | .2229 |
| 20 | .1886 | .0226 | .1886 | .2075 | .2058 | .2075 | .2035 |
| 21 | .2204 | .0226 | .1715 | .2075 | | .2075 | |
| 22 | .2229 | .0226 | .1543 | .2263 | .2229 | .2263 | |
| 23 | .2401 | .0226 | .1886 | .1509 | .2058 | | |
| 24 | | | .0226 | .2058 | .1698 | .2058 | .0226 |
| **Max** | **.2572** | **.0302** | **.2401** | **.2374** | **.2641** | **.2401** | **.2401** |
| **Min** | **.0203** | **.0226** | **.0226** | **.0206** | **.0226** | **.0206** | **.0226** |
| **Avg** | **.1832** | **.0252** | **.1279** | **.1421** | **.1404** | **.1672** | **.1245** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214468 / 33/11KV Nimgaon Ketki**
**Feeder No / Name : 208 / 11 KV KACHARWADI. SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .3258 | .3961 | .4115 | .4338 | .4458 | .415 |
| 2 | | .3258 | .6224 | .4144 | .7356 | | .3961 |
| 3 | | .3258 | .7167 | .5967 | .7922 | .3601 | .415 |
| 4 | | .3772 | .7922 | .779 | .9054 | | .4904 |
| 5 | | .6001 | .9619 | .8288 | 1.1506 | .4973 | .6036 |
| 6 | | .6859 | 1.226 | 1.326 | 1.4335 | .6344 | .7545 |
| 7 | | .6859 | 1.4901 | 1.4918 | 1.6975 | | .7922 |
| 8 | | | 1.8296 | 1.9062 | 2.0182 | | |
| 9 | | | 1.9616 | 1.8233 | 1.5089 | | |
| 10 | 1.2548 | 1.065 | | | | | 1.3032 |
| 11 | 1.8482 | 1.6549 | | | | | 1.286 |
| 12 | 1.8482 | 1.8652 | | | | | 1.3717 |
| 13 | 1.7974 | 1.8821 | | | | | 1.3717 |
| 14 | 1.8652 | 1.7974 | | | | | 1.3717 |
| 15 | 1.8143 | 1.7974 | .2204 | .3121 | .3222 | | 1.286 |
| 16 | 1.8652 | 1.7368 | .39 | .3467 | .4409 | 1.6278 | 1.3717 |
| 17 | 1.8991 | 1.8296 | .4287 | .5093 | .4409 | 1.7918 | 1.2431 |
| 18 | .5201 | .4715 | .5087 | .6979 | | .5658 | .5721 |
| 19 | .6687 | .4904 | .4973 | .6602 | | .5658 | .6935 |
| 20 | .4973 | .5281 | .5144 | .6224 | .5487 | .5658 | .5721 |
| 21 | .4334 | .4715 | .463 | .547 | | .5093 | |
| 22 | .3814 | .4338 | .4973 | .4904 | | .4527 | |
| 23 | .3294 | .3961 | .4458 | .4338 | .5144 | | |
| 24 | | .3258 | .3961 | .4115 | .4338 | .463 | .415 |
| **Max** | **1.8991** | **1.8821** | **1.9616** | **1.9062** | **2.0182** | **1.7918** | **1.3717** |
| **Min** | **.3294** | **.3258** | **.2204** | **.3121** | **.3222** | **.3601** | **.3961** |
| **Avg** | **1.2159** | **.9124** | **.7557** | **.7689** | **.8918** | **.7066** | **.8802** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214468 / 33/11KV Nimgaon Ketki**
**Feeder No / Name : 401 / 33 KV Sonai NON SHEDDABLE EXPRESS HV FEEDERS**
**Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | 2.1845 | 2.1502 | 2.9127 | 1.6975 | 2.1605 | 2.1502 |
| 2 | 2.572 | 2.2405 | 2.2634 | 2.2405 | 1.6975 | | 2.3765 |
| 3 | | 2.2405 | 2.2634 | 2.3525 | 1.8107 | 2.8807 | 2.2634 |
| 4 | 2.8292 | 2.2405 | 2.1502 | 2.6326 | 2.1502 | | 2.3765 |
| 5 | | 2.3525 | 2.037 | 2.8006 | 2.2068 | 2.5206 | 2.4331 |
| 6 | 2.4177 | 2.4086 | 2.1502 | 2.6326 | 2.4897 | 2.4691 | 2.5463 |
| 7 | | 2.4646 | 2.32 | 2.4086 | 2.6595 | 2.0576 | 2.4331 |
| 8 | 2.0576 | 1.9044 | 1.9239 | 2.5766 | 2.5463 | | 2.5463 |
| 9 | 1.9839 | 2.0165 | 2.4897 | 2.8006 | 2.8292 | 2.5206 | 2.572 |
| 10 | 1.6787 | 1.9839 | 2.2068 | 2.9127 | 2.4926 | 2.1874 | 2.572 |
| 11 | 1.7204 | 1.9839 | 2.3525 | 2.8006 | 2.4926 | 2.2382 | 2.1605 |
| 12 | 1.6787 | 1.7804 | 2.5206 | 2.4086 | 2.5434 | 2.2382 | 1.8519 |
| 13 | 1.6787 | 1.4752 | 2.2405 | 2.1845 | 2.1365 | 2.0348 | 1.3889 |
| 14 | 1.6221 | 1.5089 | 1.9044 | 2.8006 | 1.8821 | 1.933 | 1.6461 |
| 15 | 1.6712 | 1.6221 | 1.7924 | 2.5766 | 1.9839 | 1.6278 | 1.0288 |
| 16 | 1.6278 | 2.1125 | 1.5769 | 2.4086 | 1.8313 | 1.6278 | 1.5432 |
| 17 | 1.6278 | 2.7161 | 1.7924 | 1.9805 | 2.2891 | 2.6029 | 1.6244 |
| 18 | 1.9044 | 2.5463 | 2.2405 | 1.9239 | 2.2119 | 2.4897 | 2.1285 |
| 19 | 2.4086 | 2.4331 | 2.9127 | 2.037 | | 2.4897 | 2.2405 |
| 20 | 2.5206 | 2.6029 | 2.8006 | 1.6975 | 2.0576 | 2.5463 | 2.4086 |
| 21 | 2.3525 | 2.7161 | 2.8006 | 1.8673 | | 2.6029 | |
| 22 | 2.2965 | 2.4331 | 2.6886 | 2.037 | 2.1091 | 2.5463 | |
| 23 | 2.2965 | 2.2634 | 2.3525 | 1.8673 | 2.1091 | | 1.6804 |
| 24 | 2.572 | 2.1845 | 2.037 | 2.8006 | 1.8107 | 2.1605 | 2.037 |
| **Max** | **2.8292** | **2.7161** | **2.9127** | **2.9127** | **2.8292** | **2.8807** | **2.572** |
| **Min** | **1.6221** | **1.4752** | **1.5769** | **1.6975** | **1.6975** | **1.6278** | **1.0288** |
| **Avg** | **2.0758** | **2.1840** | **2.2486** | **2.4025** | **2.1835** | **2.2967** | **2.0913** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214502 / 33/11 KV Wadapuri**
**Feeder No / Name : 201 / 11 KV Vitthalwadi SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4588 | .4805 | .4024 | .4572 | .4755 | .4961 | .426 |
| 2 | .4915 | .4525 | 2.1365 | 2.2207 | 2.0517 | .4908 | .4862 |
| 3 | .5304 | .4525 | 2.1704 | 2.2081 | 2.0856 | .4733 | .5365 |
| 4 | .57 | .5853 | 2.2131 | 2.4451 | 2.1704 | .4733 | .5868 |
| 5 | .6036 | .6805 | 2.4478 | 2.6353 | 2.3148 | .5258 | .6371 |
| 6 | .6706 | .8505 | 2.7978 | 2.9835 | 2.5549 | .7712 | .8048 |
| 7 | .788 | .9465 | 3.12 | 3.5151 | 2.8292 | .9991 | .9602 |
| 8 | .8745 | .8842 | 3.504 | 3.5608 | 3.2895 | .9189 | .8573 |
| 9 | .6687 | .6783 | 3.2653 | 3.2922 | 3.1017 | .6104 | .6874 |
| 10 | 2.6642 | | .5197 | .5596 | .5304 | 2.4413 | 2.6467 |
| 11 | 3.219 | 2.7368 | .5197 | .57 | .4917 | 2.649 | 3.086 |
| 12 | 3.3753 | 3.4899 | .4191 | .4641 | .4475 | 2.9664 | 2.967 |
| 13 | 3.195 | | .3887 | .4527 | .4641 | 3.155 | 2.8509 |
| 14 | 3.0476 | | | .431 | .4915 | 3.2236 | 2.753 |
| 15 | 3.1327 | | | .4862 | .4915 | 3.3653 | 2.6558 |
| 16 | 3.2487 | 3.2693 | | .5636 | .5079 | 3.0178 | 2.6871 |
| 17 | 3.0167 | 3.199 | | | .5243 | 3.0521 | 2.7018 |
| 18 | .5729 | .6401 | .7499 | .6099 | .7783 | .6539 | .6516 |
| 19 | .8686 | .8871 | .924 | .961 | .8688 | .7042 | .7059 |
| 20 | .7577 | .7023 | .7682 | .823 | .7522 | .7712 | .6516 |
| 21 | .6767 | .5853 | .567 | .6219 | .7164 | .823 | .5973 |
| 22 | .5914 | .5121 | .5121 | .5544 | .6447 | .6859 | .543 |
| 23 | .5544 | .439 | .4755 | .5175 | .6024 | .6001 | .4887 |
| 24 | .4752 | .5175 | .462 | .439 | .4938 | .567 | .4915 |
| **Max** | **3.3753** | **3.4899** | **3.504** | **3.5608** | **3.2895** | **3.3653** | **3.086** |
| **Min** | **.4588** | **.439** | **.3887** | **.431** | **.4475** | **.4733** | **.426** |
| **Avg** | **1.4605** | **1.1495** | **1.4182** | **1.3640** | **1.2366** | **1.4348** | **1.3525** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214502 / 33/11 KV Wadapuri**
**Feeder No / Name : 202 / 11 KV Gokhali SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4752 | .4805 | .5487 | .4572 | .4938 | .5138 | .5197 |
| 2 | .7127 | 1.2308 | .4917 | .4298 | .4748 | 1.0166 | .8048 |
| 3 | 1.0562 | 1.2489 | .4578 | .4344 | .4917 | 1.0517 | .9221 |
| 4 | 1.3077 | 1.2437 | .4862 | .4961 | .5256 | 1.1919 | 1.0395 |
| 5 | 1.4083 | 1.2894 | .5868 | .5201 | .583 | 1.2971 | 1.3203 |
| 6 | 1.5947 | 1.7364 | .6783 | .6344 | .6516 | 1.5074 | 1.5775 |
| 7 | 2.0233 | 2.1735 | .6443 | .703 | .583 | 1.6651 | 1.6461 |
| 8 | 2.1434 | 2.2018 | .6036 | .5256 | .5765 | 1.9938 | 1.9376 |
| 9 | 2.1091 | 2.0178 | .4641 | .4287 | .4191 | 1.9161 | 1.7101 |
| 10 | .3856 | .3681 | 1.3413 | 1.4582 | 1.2763 | .3277 | .333 |
| 11 | .3521 | .3887 | 2.0454 | 1.6095 | 1.8482 | .3856 | .2543 |
| 12 | | .3277 | 1.7772 | 2.0056 | 1.989 | .3429 | .2486 |
| 13 | .2622 | | 1.8623 | 1.9951 | 1.9227 | .3258 | .2622 |
| 14 | .3441 | .3018 | 2.13 | 1.9227 | 1.8023 | .3086 | .2429 |
| 15 | .3978 | .3149 | 2.13 | 1.9616 | 1.7532 | .3086 | .2105 |
| 16 | .3481 | .3018 | 1.9662 | 1.9062 | 1.6221 | .3258 | .2785 |
| 17 | .431 | .4144 | 1.7166 | 1.8275 | 1.5565 | .3429 | .3812 |
| 18 | .6283 | .5304 | .5487 | .462 | .4706 | .5533 | .5973 |
| 19 | .7207 | .7023 | .6653 | .6838 | .5792 | .5182 | .6516 |
| 20 | .6468 | .6283 | .6036 | .5853 | .5373 | .5365 | .6335 |
| 21 | .5853 | .6036 | .6036 | .567 | .5373 | .5197 | .5973 |
| 22 | .5544 | .5853 | .5487 | .5359 | .5194 | .5658 | .5792 |
| 23 | .5175 | .5487 | .5121 | .5175 | .5138 | .5365 | .5611 |
| 24 | .4752 | .4805 | .5729 | .4755 | .4755 | .5138 | .4915 |
| **Max** | **2.1434** | **2.2018** | **2.13** | **2.0056** | **1.989** | **1.9938** | **1.9376** |
| **Min** | **.2622** | **.3018** | **.4578** | **.4287** | **.4191** | **.3086** | **.2105** |
| **Avg** | **.8469** | **.8748** | **.9994** | **.9643** | **.9251** | **.7736** | **.7417** |

 Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052]** **BU 5894**
**Substation No/ Name :- 214502 / 33/11 KV Wadapuri**
**Feeder No / Name : 203 / 11 KV Wadapuri GFSS** **GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0492 | .0739 | .0549 | .0732 | .0549 | .0532 | .0492 |
| 2 | .0503 | .0543 | .0509 | .0537 | .0509 | .0526 | .0671 |
| 3 | .0671 | .0543 | .0678 | .0543 | .0678 | .0526 | .0671 |
| 4 | .0671 | .0914 | .0838 | .0709 | .0848 | .0526 | .1006 |
| 5 | .0857 | .1433 | .1006 | .1214 | .1543 | .1052 | .1509 |
| 6 | .1372 | .2303 | .1696 | .2229 | .2058 | .1402 | .2058 |
| 7 | .2058 | .2454 | .2204 | .2229 | .2229 | .2279 | .2058 |
| 8 | .1715 | .1734 | .1677 | | .1696 | .156 | .1543 |
| 9 | .1372 | .1187 | .116 | .1543 | .1509 | .1526 | .1029 |
| 10 | .0876 | .08 | .1006 | .1017 | .0995 | .0983 | .0876 |
| 11 | .0503 | .0648 | .0838 | .0671 | .0678 | .0838 | .0848 |
| 12 | .0492 | .0655 | | .0829 | .0829 | .0838 | .0663 |
| 13 | .0492 | .0663 | .0648 | .0671 | .0663 | .0686 | .0655 |
| 14 | .0492 | .0503 | .0655 | .0663 | .0492 | .0686 | .0486 |
| 15 | .0497 | .0497 | | .0671 | .0492 | .0686 | .0486 |
| 16 | .0829 | .0671 | .0655 | .0663 | .0655 | .0838 | .0655 |
| 17 | .0829 | .0829 | .0648 | .0838 | .0819 | .0838 | .0829 |
| 18 | .1109 | .1097 | .1463 | .1109 | .1448 | .0983 | .1629 |
| 19 | .1478 | .1663 | .1294 | .1663 | .1629 | .1006 | .1991 |
| 20 | .1294 | .1294 | .1463 | .128 | .1267 | .1006 | .1267 |
| 21 | .1097 | .1097 | .0914 | .1097 | .1075 | .1006 | .0905 |
| 22 | .0924 | .0914 | .0914 | .0924 | .0716 | .0838 | .0724 |
| 23 | .0739 | .0732 | .0732 | .0739 | .0532 | .0838 | .0543 |
| 24 | .0655 | .0739 | .0739 | .0732 | .0732 | .0532 | .0655 |
| **Max** | **.2058** | **.2454** | **.2204** | **.2229** | **.2229** | **.2279** | **.2058** |
| **Min** | **.0492** | **.0497** | **.0509** | **.0537** | **.0492** | **.0526** | **.0486** |
| **Avg** | **.0917** | **.1027** | **.1013** | **.1013** | **.1027** | **.0939** | **.1010** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052]** **BU 5894**
**Substation No/ Name :- 214502 / 33/11 KV Wadapuri**
**Feeder No / Name : 204 / 11 kV Pingalewasti Ag** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1638 | .1294 | .1646 | .1463 | .1829 | .1772 | .1638 |
| 2 | .1844 | .1267 | .3561 | .3224 | .3391 | .1578 | .2347 |
| 3 | .1844 | .1267 | .39 | .3077 | .39 | .1402 | .285 |
| 4 | .2229 | .1646 | .4359 | .3544 | .4578 | .1402 | .3353 |
| 5 | .2572 | .2149 | .57 | .4681 | .5487 | .2454 | .3856 |
| 6 | .3086 | .3544 | .6613 | .6687 | .7716 | .4031 | .4191 |
| 7 | .4458 | .5434 | .9665 | .9088 | .9774 | .5258 | .5316 |
| 8 | .5144 | .4681 | 1.0059 | 1.0004 | 1.153 | .4508 | .463 |
| 9 | .3353 | .3222 | .8951 | 1.046 | .9389 | .3561 | .3856 |
| 10 | .6836 | .5761 | .2515 | .2035 | .2321 | .6226 | .6661 |
| 11 | .9221 | .8259 | .1677 | .1677 | .1865 | .6859 | .7969 |
| 12 | .8192 | .8192 | .1341 | .1326 | .0497 | .7373 | .8288 |
| 13 | .7701 | .8951 | .1619 | .1509 | .1658 | .8059 | .8684 |
| 14 | .7865 | .8718 | .1638 | .1326 | .1802 | .6516 | .8097 |
| 15 | .8288 | .8453 | .1638 | .1509 | .1638 | .583 | .7773 |
| 16 | .779 | .8383 | .1638 | .1658 | .1802 | .6036 | .7537 |
| 17 | .7459 | .7625 | .2267 | .2515 | .1966 | .6516 | .6962 |
| 18 | .2957 | .2926 | .4024 | .3696 | .3077 | .3353 | .2715 |
| 19 | .3881 | .4066 | .3696 | .4066 | .362 | .2683 | .3258 |
| 20 | .3326 | .3326 | .3109 | .3292 | .3761 | .2572 | .3077 |
| 21 | .2012 | .2561 | .2195 | .2561 | .3224 | .2229 | .2715 |
| 22 | .1848 | .2012 | .2012 | .1848 | .2507 | .2012 | .2353 |
| 23 | .1663 | .1646 | .1829 | .1478 | .1949 | .2012 | .1991 |
| 24 | .1802 | .1478 | .1478 | .1646 | .1646 | .1772 | .1802 |
| **Max** | **.9221** | **.8951** | **1.0059** | **1.046** | **1.153** | **.8059** | **.8684** |
| **Min** | **.1638** | **.1267** | **.1341** | **.1326** | **.0497** | **.1402** | **.1638** |
| **Avg** | **.4459** | **.4453** | **.3630** | **.3515** | **.3789** | **.4001** | **.4663** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214502 / 33/11 KV Wadapuri**
**Feeder No / Name : 206 / 11 kV Ramwadi Ag SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .503 | .4435 | .5121 | .5121 | .4572 | .4784 | .8192 |
| 2 | .7377 | .9774 | .4917 | .4656 | .4409 | .9816 | 1.1401 |
| 3 | 1.0059 | .9955 | .5426 | .4706 | .4917 | 1.0517 | 1.2689 |
| 4 | 1.3077 | 1.0974 | .6371 | .567 | .6104 | 1.1218 | 1.3375 |
| 5 | 1.5089 | 1.2178 | .8048 | .8322 | .7888 | 1.2971 | 1.5089 |
| 6 | 1.9784 | 1.5592 | 1.1022 | 1.046 | 1.046 | 1.56 | 1.8229 |
| 7 | 2.2977 | 2.0332 | 1.2548 | 1.166 | 1.2346 | 1.9281 | 1.9281 |
| 8 | 2.4006 | 2.3232 | 1.1401 | 1.0852 | 1.1022 | 2.2365 | 2.3487 |
| 9 | 1.1317 | 2.1365 | .8951 | 1.166 | .8551 | 2.0517 | 2.191 |
| 10 | .5609 | .5921 | 1.6598 | 1.6278 | 1.4089 | .5407 | .5959 |
| 11 | .5365 | .5344 | 2.0287 | 1.8778 | 1.8482 | .6173 | .4409 |
| 12 | .426 | .5243 | 2.0119 | 2.0719 | 2.0388 | .6516 | .4144 |
| 13 | .4752 | | 2.0891 | 2.079 | 1.9393 | .7545 | .3932 |
| 14 | .5079 | .4527 | 2.1628 | 2.0388 | 1.8351 | .7545 | .3887 |
| 15 | .4641 | .4807 | 2.0153 | 1.9951 | 1.8023 | .7202 | .3887 |
| 16 | | .5365 | 1.9826 | 1.9227 | 1.8187 | .9054 | .4752 |
| 17 | .547 | .5967 | 1.7652 | 1.7772 | 1.7859 | 1.166 | .5801 |
| 18 | .8686 | .8596 | .9694 | .7762 | .8145 | 1.073 | .9593 |
| 19 | 1.0719 | 1.0534 | .9979 | 1.0164 | 1.0679 | 1.0059 | .8869 |
| 20 | .8316 | .924 | .7865 | .7865 | .9313 | 1.1317 | .8145 |
| 21 | .6401 | .7682 | .6401 | .6584 | .788 | 1.166 | .724 |
| 22 | .5729 | .6219 | .567 | .5914 | .6805 | 1.0631 | .6516 |
| 23 | .5544 | .4938 | .5304 | .4805 | .6024 | .9945 | .5973 |
| 24 | .4915 | .5175 | 2.7435 | .5121 | .4755 | .5316 | .852 |
| **Max** | **2.4006** | **2.3232** | **2.7435** | **2.079** | **2.0388** | **2.2365** | **2.3487** |
| **Min** | **.426** | **.4435** | **.4917** | **.4656** | **.4409** | **.4784** | **.3887** |
| **Avg** | **.9313** | **.9452** | **1.2638** | **1.1468** | **1.1193** | **1.0743** | **.9803** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214504 / 33/11 kV Agoti**
**Feeder No / Name : 201 / 11 KV CHITALKARWADI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0183 | .0343 | .0183 | .0191 | .0171 | .0183 | .0191 |
| 2 | .0183 | .0171 | .2743 | .2096 | .1715 | | .0191 |
| 3 | .0183 | .0171 | .3292 | .2096 | .1715 | .0183 | .0191 |
| 4 | .0183 | .0171 | .3658 | .2096 | .1715 | .0171 | .0191 |
| 5 | .0366 | .0171 | .3841 | .2096 | .1715 | .0183 | .0381 |
| 6 | .0366 | .0343 | .4024 | .2667 | .2229 | .0366 | .0381 |
| 7 | .0366 | .0343 | .4024 | .3048 | .2229 | .0366 | .0381 |
| 8 | .0183 | .0171 | .439 | .4001 | .2572 | .0366 | .0381 |
| 9 | .0183 | .0171 | .4938 | .4191 | .2572 | .0366 | .0343 |
| 10 | .5658 | .5487 | .0191 | .0171 | .0171 | .3292 | .4458 |
| 11 | .6001 | .5487 | .0191 | .0171 | .0171 | .4024 | .4458 |
| 12 | .6516 | | .0191 | .0171 | .2058 | .3772 | .5316 |
| 13 | .6516 | .5487 | .0191 | .0171 | .1886 | .3772 | .5144 |
| 14 | .6516 | .5853 | .0191 | .0171 | .0183 | .3772 | .5316 |
| 15 | .6173 | .5487 | .0191 | .0171 | .0183 | .4108 | .5487 |
| 16 | | .567 | .0191 | .0171 | .0183 | .3429 | .5487 |
| 17 | | .5853 | .0191 | .0171 | .0183 | .3601 | .5487 |
| 18 | .1715 | .0366 | .0191 | .0343 | .0183 | .0191 | .0343 |
| 19 | .0343 | .0183 | .0191 | .0343 | .0183 | .0191 | .0343 |
| 20 | .0343 | .0183 | .0191 | .0343 | .0183 | .0191 | .0343 |
| 21 | .0343 | .0183 | .0191 | .0343 | .0366 | .0191 | .0343 |
| 22 | .0343 | .0183 | .0191 | .0171 | .0366 | .0191 | .0171 |
| 23 | .0343 | .0183 | .0191 | .0171 | .0183 | .0191 | .0171 |
| 24 | .0183 | .0343 | .0183 | .0191 | .0171 | .0183 | .0191 |
| **Max** | **.6516** | **.5853** | **.4938** | **.4191** | **.2572** | **.4108** | **.5487** |
| **Min** | **.0183** | **.0171** | **.0183** | **.0171** | **.0171** | **.0171** | **.0171** |
| **Avg** | **.1963** | **.1870** | **.1415** | **.1073** | **.0970** | **.1447** | **.1904** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214504 / 33/11 kV Agoti**
**Feeder No / Name : 202 / 11 KV LAXMI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .128 | .1886 | .2012 | .2096 | .2229 | .1829 | .1524 |
| 2 | .1463 | .1715 | .8962 | .7811 | .7373 | .1829 | .0953 |
| 3 | .1646 | .1715 | .8779 | .7811 | .7373 | .2012 | .0953 |
| 4 | .1646 | .1715 | .9145 | .7811 | .7373 | .2195 | .0953 |
| 5 | .1463 | .1715 | .9328 | .7811 | .7373 | .2012 | |
| 6 | .1829 | .1715 | .9145 | .7811 | .7373 | .2195 | .0953 |
| 7 | .1646 | .1715 | .8962 | .7811 | .7373 | .2195 | .0953 |
| 8 | .1646 | .1715 | .9145 | .7811 | .7545 | .2012 | .0953 |
| 9 | .1646 | .1886 | .9145 | .8764 | .7545 | .1543 | .0857 |
| 10 | .9774 | .9145 | .1905 | .2229 | .2058 | .6401 | .823 |
| 11 | 1.0631 | .8779 | .1905 | .2229 | .2229 | .8413 | .8402 |
| 12 | 1.0631 | | .1905 | .2229 | .2229 | .823 | .8745 |
| 13 | 1.0631 | .8779 | .1905 | .2229 | .2561 | .823 | .8745 |
| 14 | 1.0631 | .9431 | .1905 | .2401 | .2743 | .823 | .823 |
| 15 | 1.0631 | .9328 | .1905 | .2401 | .2743 | .8962 | .823 |
| 16 | 1.0631 | .8962 | .2858 | .2229 | .2378 | .823 | .823 |
| 17 | 1.046 | .9145 | .2858 | .2229 | .2012 | .8573 | .823 |
| 18 | .1715 | .2195 | .2858 | .2229 | .1646 | .1905 | .1372 |
| 19 | .1715 | .2075 | .2096 | .2229 | .1829 | .1905 | .1372 |
| 20 | .1715 | .2195 | .2096 | .2229 | .2012 | .1905 | .1372 |
| 21 | .1886 | | .2096 | .2229 | .2195 | .1905 | .1029 |
| 22 | .1886 | .2012 | .2096 | .2229 | .2378 | .1524 | .1372 |
| 23 | .1886 | .1646 | .2096 | .2229 | .2012 | .1524 | .12 |
| 24 | .1646 | .1886 | .1829 | .2096 | .2229 | .2195 | .1524 |
| **Max** | **1.0631** | **.9431** | **.9328** | **.8764** | **.7545** | **.8962** | **.8745** |
| **Min** | **.128** | **.1646** | **.1829** | **.2096** | **.1646** | **.1524** | **.0857** |
| **Avg** | **.4614** | **.4153** | **.4456** | **.4133** | **.3950** | **.3998** | **.3669** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052]** **BU 5894**
**Substation No/ Name :- 214504 / 33/11 kV Agoti**
**Feeder No / Name : 203 / 11 KV TALEMALA FEEDER** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2012 | .1543 | .2012 | .2096 | .12 | .2012 | .1905 |
| 2 | .8048 | .6859 | .2012 | .2096 | .12 | .695 | .5716 |
| 3 | .8413 | .6859 | .2012 | .2096 | .12 | .7682 | .5716 |
| 4 | .8413 | .6859 | .2195 | .2096 | .12 | .8048 | .5716 |
| 5 | .9145 | .6859 | .2378 | .2858 | .1543 | .8413 | .6668 |
| 6 | .9877 | .8573 | .2561 | .3429 | .2058 | .8779 | .724 |
| 7 | .9877 | .8573 | .2926 | .362 | .2915 | .9145 | .7621 |
| 8 | 1.0242 | .8916 | .3109 | .3048 | .2572 | .9145 | .8573 |
| 9 | 1.0242 | .8916 | .2743 | .2286 | .1715 | .8779 | .7888 |
| 10 | .2058 | .2378 | 1.0669 | .9945 | .9431 | .1646 | .1372 |
| 11 | .2058 | .2195 | 1.2955 | 1.1145 | .9088 | .128 | .1372 |
| 12 | .2058 | | 1.2955 | 1.2003 | .9088 | .12 | .12 |
| 13 | .2058 | .2561 | 1.3336 | 1.2003 | .9259 | .1029 | .1372 |
| 14 | .2058 | .2378 | 1.3336 | 1.166 | 1.0059 | .1029 | .1543 |
| 15 | .2058 | .2195 | 1.3336 | 1.166 | 1.0059 | .112 | .1372 |
| 16 | .2058 | .2012 | 1.3336 | 1.0974 | 1.0425 | .1372 | .1715 |
| 17 | .2229 | .2195 | 1.3336 | 1.0974 | .9877 | .1524 | .2401 |
| 18 | .2229 | .2561 | .2096 | .1543 | .2378 | .2858 | .2401 |
| 19 | .2229 | .2561 | .2286 | .1543 | .2378 | .2667 | .2641 |
| 20 | .2229 | .2926 | .2286 | .1543 | .2561 | .2667 | .2401 |
| 21 | .2229 | .2561 | .2286 | .1543 | .2743 | .2667 | .2401 |
| 22 | .1543 | .2378 | .2096 | .1372 | .2561 | .1905 | .2401 |
| 23 | .1543 | .2195 | .2096 | .1372 | .2378 | .1905 | .1543 |
| 24 | .2195 | .1543 | .2195 | .2096 | .12 | .2195 | .1905 |
| **Max** | **1.0242** | **.8916** | **1.3336** | **1.2003** | **1.0425** | **.9145** | **.8573** |
| **Min** | **.1543** | **.1543** | **.2012** | **.1372** | **.12** | **.1029** | **.12** |
| **Avg** | **.4463** | **.4200** | **.5856** | **.5208** | **.4545** | **.4001** | **.3545** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052]** **BU 5894**
**Substation No/ Name :- 214504 / 33/11 kV Agoti**
**Feeder No / Name : 204 / 11 KV GOLEWASTI FEEDER** **SHEDDABLE RURAL**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2012 | .1029 | .128 | .2096 | .2401 | .1463 | .1905 |
| 2 | .2926 | .2572 | .128 | | .2401 | .439 | .4954 |
| 3 | .3292 | .2572 | .1463 | .1524 | .2401 | .439 | .4954 |
| 4 | .3292 | .3429 | .1829 | .1524 | .2401 | .4755 | .4954 |
| 5 | .3658 | .3429 | .2012 | .2286 | .2743 | .5487 | .4954 |
| 6 | .439 | .3429 | .2012 | .2667 | .2743 | .5853 | .4954 |
| 7 | .439 | .3429 | .2195 | .3048 | .3429 | .6219 | .5335 |
| 8 | .5304 | .4287 | .2378 | .2667 | .3429 | .695 | .3048 |
| 9 | .5121 | .4287 | .2378 | .3429 | .3429 | .6401 | .5487 |
| 10 | .2058 | .2195 | .6668 | .8745 | .823 | .1829 | .2058 |
| 11 | .2058 | .2012 | .9145 | .9431 | .8745 | .1829 | .2058 |
| 12 | .2058 | .2378 | .9526 | .9431 | .9602 | .1715 | .2229 |
| 13 | .2058 | .2195 | .9526 | .9431 | .8916 | .1715 | .2058 |
| 14 | .1715 | .2012 | .9526 | 1.0974 | .9328 | .1715 | .2401 |
| 15 | .1715 | .1829 | 1.0479 | 1.0974 | .9328 | .2561 | .2401 |
| 16 | .1715 | .2012 | 1.0479 | 1.0288 | .9511 | .2572 | .2915 |
| 17 | .1886 | .2195 | 1.105 | .9774 | .9877 | .362 | .2915 |
| 18 | .2401 | .2195 | .2477 | .4115 | .3475 | .2096 | .2915 |
| 19 | .2058 | .2195 | .2667 | .4115 | .4024 | .2286 | .2915 |
| 20 | .2058 | .2561 | .2667 | .3772 | .3658 | .2286 | .2743 |
| 21 | .2058 | .2195 | .2667 | .4115 | .3841 | .2286 | .2572 |
| 22 | .1372 | .1829 | .2096 | .3429 | .2561 | .1905 | .2058 |
| 23 | .1029 | .1463 | .2096 | .2915 | .1829 | .1905 | .1715 |
| 24 | .1829 | .1029 | .1463 | .2096 | .2401 | .1829 | .1905 |
| **Max** | **.5304** | **.4287** | **1.105** | **1.0974** | **.9877** | **.695** | **.5487** |
| **Min** | **.1029** | **.1029** | **.128** | **.1524** | **.1829** | **.1463** | **.1715** |
| **Avg** | **.2602** | **.2448** | **.4557** | **.5341** | **.5029** | **.3252** | **.3183** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214504 / 33/11 kV Agoti**
**Feeder No / Name : 205 / 11 KV GUNAWAREWASTI FEEDER SHEDDABLE RURAL**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2012 | .1715 | .1646 | .2286 | .1886 | .1829 | .2096 |
| 2 | .1829 | .1715 | .8048 | .7621 | .6516 | .1829 | .2096 |
| 3 | .2012 | .1715 | .8779 | .7621 | .6859 | .1829 | .2096 |
| 4 | .2195 | .1715 | .9145 | .8573 | .6859 | .2012 | .2096 |
| 5 | .2561 | .1715 | .9877 | .8573 | .6859 | .2378 | .2858 |
| 6 | .2926 | .2572 | 1.0974 | .9717 | .7716 | .2561 | .381 |
| 7 | .3109 | .2915 | 1.134 | 1.105 | .7716 | .2926 | .381 |
| 8 | .3292 | .2401 | 1.1706 | 1.105 | .8573 | .3292 | .3048 |
| 9 | .2743 | .2058 | 1.134 | 1.0669 | .8573 | .2572 | .2401 |
| 10 | .823 | .9511 | .1905 | .1372 | .12 | .9511 | .8916 |
| 11 | .8745 | 1.0608 | .1524 | .1372 | .1029 | 1.0425 | .8916 |
| 12 | .8745 | 1.0974 | .1524 | .1029 | .1029 | 1.0608 | .9896 |
| 13 | .8916 | 1.1706 | .1524 | .1029 | .0857 | .9602 | .9088 |
| 14 | .8916 | 1.1706 | .1524 | .1029 | .1097 | .9602 | .9259 |
| 15 | .8573 | 1.134 | .1524 | .12 | .1097 | 1.0425 | .9602 |
| 16 | | 1.0974 | .2096 | .1715 | .128 | .9945 | .9602 |
| 17 | | 1.1157 | .2096 | .1886 | .1463 | 1.086 | .9602 |
| 18 | .2229 | .1829 | .3048 | .2229 | .1463 | .1905 | .2058 |
| 19 | .2229 | .2195 | .3429 | .2229 | .1829 | .2477 | .2058 |
| 20 | .2229 | .2378 | .3429 | .2229 | .2195 | .2477 | .2058 |
| 21 | .1886 | .2561 | .2858 | .2229 | .2378 | .2477 | .2058 |
| 22 | .1886 | .2012 | .2096 | .1886 | .2561 | .2096 | .1886 |
| 23 | .1886 | .1646 | .2286 | .1886 | .2378 | .2096 | .1886 |
| 24 | .1829 | .1715 | .1829 | .2286 | .1886 | .2195 | .2096 |
| **Max** | **.8916** | **1.1706** | **1.1706** | **1.105** | **.8573** | **1.086** | **.9896** |
| **Min** | **.1829** | **.1646** | **.1524** | **.1029** | **.0857** | **.1829** | **.1886** |
| **Avg** | **.4044** | **.5035** | **.4814** | **.4282** | **.3554** | **.4914** | **.4721** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214504 / 33/11 kV Agoti**
**Feeder No / Name : 207 / AGOTHI GFSS GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0549 | .0514 | .0549 | .0572 | .0514 | .0549 | .0572 |
| 2 | .0549 | .0514 | .0549 | .0572 | .0514 | .0549 | .0572 |
| 3 | .0732 | .0514 | .0549 | .0572 | .0514 | .0549 | .0572 |
| 4 | .0732 | .0686 | .0732 | .0572 | .0514 | .0732 | .0572 |
| 5 | .0914 | .0857 | .0732 | .0953 | .0686 | .0732 | .0762 |
| 6 | .1097 | .1029 | .1097 | .1143 | .1029 | .1097 | .0953 |
| 7 | .1097 | .1029 | .1097 | .1143 | .1029 | .1097 | .1143 |
| 8 | .0914 | .0686 | .0914 | .0762 | .0857 | .0914 | .0953 |
| 9 | .0732 | .0686 | .0914 | .0953 | .0686 | .0549 | .0857 |
| 10 | .0343 | .0549 | .0572 | .0686 | .0686 | .0732 | .0514 |
| 11 | .0514 | .0366 | .0381 | .0343 | .0686 | .0549 | .0343 |
| 12 | .0514 | .0366 | .0381 | .0343 | .0686 | .0183 | .0185 |
| 13 | .0343 | .0366 | .0381 | .0343 | .0732 | .0171 | .0171 |
| 14 | .0343 | .0183 | .0381 | .0343 | .0732 | .0171 | .0343 |
| 15 | .0343 | .0366 | .0381 | .0343 | .0732 | .0183 | .0171 |
| 16 | | .0366 | .0381 | .0514 | .0366 | .0171 | .0343 |
| 17 | | .0366 | .0381 | .0514 | .0366 | .0572 | .0514 |
| 18 | .0857 | .0549 | .0762 | .0514 | .0549 | .0572 | .0514 |
| 19 | .0857 | .0549 | .0572 | .0686 | .0549 | .0572 | .0686 |
| 20 | .0857 | .0732 | .0953 | .0686 | .0549 | .0572 | .0686 |
| 21 | .0857 | .0732 | .0953 | .0686 | .0732 | .0572 | .0686 |
| 22 | .0686 | .0732 | .0572 | .0514 | .0549 | .0572 | .0514 |
| 23 | .0514 | .0549 | .0572 | .0343 | .0514 | .0572 | .0514 |
| 24 | .0549 | .0514 | .0549 | .0572 | .0514 | .0549 | .0572 |
| **Max** | **.1097** | **.1029** | **.1097** | **.1143** | **.1029** | **.1097** | **.1143** |
| **Min** | **.0343** | **.0183** | **.0381** | **.0343** | **.0366** | **.0171** | **.0171** |
| **Avg** | **.0677** | **.0575** | **.0638** | **.0611** | **.0637** | **.0562** | **.0571** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214505 / 33/11 kV REDANI SUBSTATION**
**Feeder No / Name : 201 / 11 KV REDANI AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6001 | .6668 | .6668 | .6401 | .5373 | .6668 | .6668 |
| 2 | .6135 | .6668 | .7802 | .7287 | .8059 | .6668 | .6668 |
| 3 | .6401 | .6668 | .7802 | .7373 | .8954 | .6668 | .6668 |
| 4 | .7468 | .7621 | .8573 | .8192 | .8488 | .7621 | .6668 |
| 5 | .8488 | .9526 | .9536 | .9717 | .9374 | .8573 | .7392 |
| 6 | 1.094 | 1.0479 | 1.1269 | 1.1469 | 1.0936 | 1.0479 | .8954 |
| 7 | 1.0479 | .9526 | 1.5927 | 1.4575 | 1.3279 | 1.0479 | .985 |
| 8 | 1.0374 | .9526 | 1.9662 | 1.6194 | 1.7394 | .9526 | .964 |
| 9 | .8488 | .7392 | 1.9204 | 1.9433 | | .8573 | .8059 |
| 10 | 1.2498 | 1.2955 | .6335 | .543 | .5487 | 1.2717 | 1.2289 |
| 11 | 1.1717 | 1.6404 | .4525 | .4668 | .4763 | 1.5927 | 1.3927 |
| 12 | 1.3717 | 1.7394 | .3658 | .3734 | .381 | 1.5203 | 1.3765 |
| 13 | 1.5242 | 1.9433 | .2743 | .2801 | .2601 | 1.6004 | 1.3927 |
| 14 | 1.6004 | 1.9433 | .2743 | .2801 | .2601 | 1.3108 | 1.4746 |
| 15 | 1.2041 | 1.9433 | .2629 | .2743 | | 1.4403 | 1.4575 |
| 16 | 1.5242 | 1.8519 | .2743 | .3658 | .2629 | 1.5203 | 1.3108 |
| 17 | 1.5432 | 1.929 | .3506 | .4477 | .3582 | | 1.2146 |
| 18 | .6668 | .6668 | .7316 | .6535 | .6468 | .6468 | .5487 |
| 19 | .7621 | .9526 | .823 | .9335 | .823 | .7888 | .8145 |
| 20 | .7621 | .8488 | .823 | .7316 | .7392 | .7164 | .7316 |
| 21 | .7621 | .7392 | .7316 | .6535 | .7621 | .7164 | .7316 |
| 22 | .7621 | .6668 | .7316 | .5487 | .7621 | .6668 | .6335 |
| 23 | .6668 | .6668 | .7316 | .5487 | .6668 | .6668 | .6401 |
| 24 | .6135 | .6668 | .6668 | .7316 | .5258 | .6668 | .6668 |
| **Max** | **1.6004** | **1.9433** | **1.9662** | **1.9433** | **1.7394** | **1.6004** | **1.4746** |
| **Min** | **.6001** | **.6668** | **.2629** | **.2743** | **.2601** | **.6468** | **.5487** |
| **Avg** | **.9859** | **1.1209** | **.7822** | **.7457** | **.7118** | **.9848** | **.9447** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214505 / 33/11 kV REDANI SUBSTATION**
**Feeder No / Name : 202 / 11 KV BORATWADI AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2629 | .3239 | .2858 | .3658 | .2686 | .2429 | .2801 |
| 2 | .9488 | .9145 | .2858 | .3658 | .2686 | .7811 | .763 |
| 3 | .9602 | .9145 | | .362 | .2743 | .7907 | .763 |
| 4 | .9488 | .9602 | .2858 | .3658 | .3658 | | .9116 |
| 5 | 1.1574 | 1.2146 | .381 | .4572 | .4477 | .9717 | .9012 |
| 6 | 1.4403 | 1.4918 | .5716 | .5487 | .5487 | 1.1603 | 1.1203 |
| 7 | 1.7004 | 1.6385 | .5487 | .5487 | .5487 | 1.3765 | 1.3279 |
| 8 | 1.6804 | 1.7814 | .4525 | .4572 | .4572 | 1.3765 | 1.4403 |
| 9 | 1.7814 | 1.5203 | .4763 | .3658 | .3734 | 1.3765 | 1.3603 |
| 10 | .2543 | | 1.2289 | 1.2651 | 1.1288 | .2801 | .2743 |
| 11 | .1429 | .1905 | 1.7204 | 1.4661 | 1.4842 | .1753 | .1829 |
| 12 | .141 | .1696 | 1.7204 | 1.5623 | 1.5623 | .1829 | .181 |
| 13 | .1276 | .1715 | 1.7814 | 1.6404 | 1.5813 | .1867 | .1829 |
| 14 | .1276 | .1886 | 1.7814 | 1.6004 | 1.6604 | .181 | .1829 |
| 15 | .0953 | | 1.8023 | 1.6404 | | .1829 | .1829 |
| 16 | .1886 | .1429 | 1.7814 | 1.5623 | 1.5813 | .1791 | .1829 |
| 17 | .2829 | .1562 | 1.7814 | 1.5623 | 1.5623 | | .1829 |
| 18 | .3582 | .3582 | .4525 | .3506 | .3353 | .3391 | .2743 |
| 19 | .3582 | .4525 | .3658 | .4572 | .3239 | .4239 | .2743 |
| 20 | .3582 | .4287 | .3658 | .4668 | .3315 | .3506 | .362 |
| 21 | .381 | .3315 | .3506 | .3734 | .3163 | .2686 | .2743 |
| 22 | .381 | .381 | .362 | .2801 | .2429 | .2629 | .2715 |
| 23 | .381 | .381 | .362 | .2801 | .2429 | .2543 | .2743 |
| 24 | .2686 | .3277 | .381 | .3658 | .2801 | .2429 | .2743 |
| **Max** | **1.7814** | **1.7814** | **1.8023** | **1.6404** | **1.6604** | **1.3765** | **1.4403** |
| **Min** | **.0953** | **.1429** | **.2858** | **.2801** | **.2429** | **.1753** | **.181** |
| **Avg** | **.6136** | **.6563** | **.8489** | **.7796** | **.7038** | **.5267** | **.5177** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214505 / 33/11 kV REDANI SUBSTATION**
**Feeder No / Name : 203 / 11 KV REDANI GFSS GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1791 | .1886 | .1886 | .1829 | .1867 | .1886 | .1791 |
| 2 | .181 | .1886 | .1886 | .1829 | .1867 | .1886 | .1791 |
| 3 | .1867 | .1886 | .1886 | .1829 | .1867 | .1886 | .181 |
| 4 | .1867 | .1886 | .1886 | .1829 | .1867 | .1886 | .1829 |
| 5 | .2801 | .2829 | .2801 | .2743 | .2801 | .2829 | .2743 |
| 6 | .2743 | .3772 | .3772 | .3658 | .2801 | .3772 | .2743 |
| 7 | .2801 | .3772 | .4715 | .3658 | .3772 | .3772 | .1848 |
| 8 | .2801 | .3734 | | .3658 | .3734 | .3696 | .3734 |
| 9 | .1886 | .1848 | .2801 | .2743 | .3734 | .1886 | .2801 |
| 10 | .1886 | .2801 | .3658 | .2801 | .2715 | .2801 | .1829 |
| 11 | .2715 | .1848 | .2743 | .1867 | .2743 | .2801 | .1829 |
| 12 | .2629 | .181 | .2658 | .2829 | .2743 | .2801 | .1829 |
| 13 | .2572 | .181 | .2743 | .2829 | .2715 | .2686 | .1829 |
| 14 | .2572 | .1867 | .2743 | .2801 | .1753 | .1867 | .1829 |
| 15 | .1715 | .1829 | .2743 | .1867 | | .1867 | .1886 |
| 16 | .1753 | .1867 | .2743 | .1867 | .2715 | .1867 | .1829 |
| 17 | .181 | .181 | .2743 | .2801 | .1829 | | .1772 |
| 18 | .2801 | .3696 | .3658 | .2801 | .2829 | .3734 | .1829 |
| 19 | .2829 | .2829 | .2743 | .2829 | .2829 | .2801 | .2743 |
| 20 | .2829 | .2829 | .2658 | .2829 | .2829 | .3658 | .2743 |
| 21 | .1886 | .1886 | .181 | .1867 | .2829 | .2772 | .2715 |
| 22 | .1886 | .1886 | .1886 | .1867 | .1886 | .2772 | .2743 |
| 23 | .1886 | .1886 | .1829 | .1867 | .1886 | .1867 | .1829 |
| 24 | .1867 | .1886 | .1886 | .1829 | .1867 | .1886 | .1791 |
| **Max** | **.2829** | **.3772** | **.4715** | **.3658** | **.3772** | **.3772** | **.3734** |
| **Min** | **.1715** | **.181** | **.181** | **.1829** | **.1753** | **.1867** | **.1772** |
| **Avg** | **.2250** | **.2335** | **.2647** | **.2472** | **.2543** | **.2595** | **.2171** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214505 / 33/11 kV REDANI SUBSTATION**
**Feeder No / Name : 204 / 11 KV Lakhewadi FEEDER SEPERATION/PURE AG**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6401 | .6468 | .6535 | .7316 | .5373 | .6401 | .6428 |
| 2 | .6268 | .6468 | .9116 | 1.0974 | .8488 | .6535 | .6415 |
| 3 | .6135 | .6468 | .9116 | .9717 | .9374 | .6535 | .6435 |
| 4 | .7316 | .7392 | 1.0059 | .9831 | .9488 | .7468 | .6415 |
| 5 | .823 | .9335 | 1.1022 | 1.1469 | 1.0936 | .8488 | .8196 |
| 6 | .9335 | 1.0374 | 1.2717 | 1.3927 | 1.2003 | .9431 | .9913 |
| 7 | 1.0374 | .9335 | 1.6385 | 1.6385 | 1.406 | .924 | .9871 |
| 8 | .823 | .8402 | 1.7004 | 1.8623 | 1.7394 | .8316 | .8299 |
| 9 | .6401 | .6335 | 1.6604 | 1.7814 | 1.2193 | .6401 | .6455 |
| 10 | 1.3279 | 1.448 | .4572 | .4572 | .4382 | 1.4008 | 1.4746 |
| 11 | 1.7004 | | .3658 | .3506 | .4477 | 1.8755 | 1.7204 |
| 12 | 1.7604 | 2.0243 | .3658 | .362 | .443 | 2.06 | |
| 13 | 1.9204 | 2.1052 | .3658 | .3467 | .3429 | 1.9671 | 1.4746 |
| 14 | 1.8976 | 1.9204 | .3658 | .2801 | .3429 | 2.0147 | 1.7004 |
| 15 | 1.6404 | 2.0805 | .3658 | .2686 | | 1.9456 | 1.7814 |
| 16 | 1.9528 | 1.7966 | .3658 | .3506 | .443 | 1.8492 | 1.8023 |
| 17 | 1.8976 | 1.8185 | .3658 | .4477 | .4382 | | 1.7814 |
| 18 | .7316 | .6468 | .6401 | .6401 | .5258 | .6521 | .543 |
| 19 | .7392 | .8316 | .823 | .7973 | .7392 | .8333 | .8145 |
| 20 | .7392 | .8316 | .7316 | .7316 | .7392 | .8299 | .7316 |
| 21 | .7392 | .7316 | .724 | .6401 | .6468 | .7285 | .724 |
| 22 | .7392 | .6468 | .7316 | .5487 | .6468 | .7354 | .6335 |
| 23 | .6468 | .6468 | .7316 | .5601 | .6401 | .6435 | .6335 |
| 24 | .6535 | .6468 | .6468 | .7316 | .5373 | .6401 | .6501 |
| **Max** | **1.9528** | **2.1052** | **1.7004** | **1.8623** | **1.7394** | **2.06** | **1.8023** |
| **Min** | **.6135** | **.6335** | **.3658** | **.2686** | **.3429** | **.6401** | **.543** |
| **Avg** | **1.0815** | **1.0971** | **.7876** | **.7966** | **.7523** | **1.0894** | **1.0134** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214505 / 33/11 kV REDANI SUBSTATION**
**Feeder No / Name : 205 / BHODANI AG FEEDER SEPERATION/PURE AG**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2686 | .2829 | .2743 | .2743 | .2686 | .1886 | .2795 |
| 2 | .381 | .2972 | .1791 | .2629 | .2743 | .301 | .3688 |
| 3 | .3858 | .3048 | .2715 | .2743 | .2801 | .3048 | .3688 |
| 4 | .4687 | .3048 | .2715 | .2743 | .3772 | .3201 | .4411 |
| 5 | .5535 | .4687 | .4572 | .3658 | .4668 | .4096 | .5516 |
| 6 | .5601 | .5668 | .5487 | .5487 | .5658 | .4973 | .6798 |
| 7 | .6478 | .7287 | .5487 | .5487 | .5601 | .6944 | |
| 8 | .8697 | .7811 | .4572 | .4572 | .5601 | .7621 | .824 |
| 9 | .8002 | .6687 | .4572 | .3658 | .2801 | .6773 | .7416 |
| 10 | .1886 | .2829 | .6554 | .5335 | .4401 | .2766 | .2658 |
| 11 | .1848 | | .7811 | .7716 | .6773 | .1844 | .1829 |
| 12 | .1867 | .1886 | .8192 | .7811 | .6773 | .1825 | .181 |
| 13 | .1848 | .2829 | .9012 | .7811 | .6773 | .1812 | .1829 |
| 14 | | .1886 | .9012 | .7811 | .6539 | .2749 | .2743 |
| 15 | .1905 | .1886 | .9012 | .7811 | | .2818 | .2743 |
| 16 | .1886 | .1886 | .8907 | .7811 | .5201 | .2701 | .2743 |
| 17 | .2829 | .2829 | .8097 | .7116 | .4458 | | .2743 |
| 18 | .462 | .3696 | .3658 | .3772 | .3772 | .4611 | .362 |
| 19 | .462 | .4572 | .3658 | .4715 | .3696 | .5624 | .362 |
| 20 | .462 | .462 | .362 | .3658 | .3734 | .4611 | .362 |
| 21 | .3696 | .3734 | .3658 | .2743 | .3734 | .4687 | .3658 |
| 22 | .2801 | .2801 | .2743 | .2801 | .2829 | .3746 | .2743 |
| 23 | .2801 | .2801 | .2658 | .2801 | .2829 | .2821 | .2743 |
| 24 | .2801 | .2829 | .2801 | .2743 | .2801 | .2829 | .2789 |
| Max | **.8697** | **.7811** | **.9012** | **.7811** | **.6773** | **.7621** | **.824** |
| Min | **.1848** | **.1886** | **.1791** | **.2629** | **.2686** | **.1812** | **.181** |
| Avg | **.3886** | **.3701** | **.5169** | **.4841** | **.4376** | **.3782** | **.3671** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214526 / 33 KV Tannu**
**Feeder No / Name : 201 / Chavanwasti AG FEEDER SEPERATION/PURE AG**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3801 | .3921 | .3429 | .4024 | .3239 | .3429 | .2896 |
| 2 | 1.4403 | 1.4998 | .3429 | .362 | .3113 | 1.2193 | 1.2955 |
| 3 | 1.5203 | 1.643 | .3429 | .362 | .3439 | 1.2193 | 1.3603 |
| 4 | 1.5813 | 1.643 | .4287 | .362 | .3077 | 1.3717 | 1.3603 |
| 5 | 1.7394 | 1.829 | .4287 | .3982 | .3239 | 1.5242 | 1.4403 |
| 6 | 1.8976 | 1.8671 | .4287 | .4706 | .421 | 1.5242 | 1.4864 |
| 7 | 1.9925 | 1.3832 | .4287 | .4344 | .4858 | 1.6766 | 1.7553 |
| 8 | 2.0083 | 1.9109 | .5144 | .4344 | .421 | 1.829 | 1.8501 |
| 9 | 1.9925 | 2.2032 | .4706 | .4108 | .3887 | 1.8861 | .3353 |
| 10 | .2347 | .3429 | 1.9766 | 2.2779 | 1.6766 | .362 | .3239 |
| 11 | .2012 | .3429 | 2.0557 | 2.4272 | 1.6766 | .2534 | .3353 |
| 12 | .1966 | .4287 | 2.1032 | 2.3472 | 1.7528 | .2172 | .2429 |
| 13 | .2378 | .3429 | 2.1348 | 2.2672 | 1.7528 | .2172 | .2515 |
| 14 | .2829 | .3429 | 2.1822 | 2.2672 | 1.829 | .2172 | .2743 |
| 15 | .2715 | .2572 | 2.1822 | 2.2939 | 1.829 | .2172 | .2429 |
| 16 | .362 | .2572 | 2.1822 | 2.3472 | 1.9052 | .2715 | .3018 |
| 17 | .4525 | .4801 | 2.1822 | 2.3472 | 1.9052 | .3439 | .2429 |
| 18 | .4854 | .3429 | .5014 | .3734 | .3429 | .4887 | .4108 |
| 19 | .3353 | .3429 | .5068 | .4191 | .3429 | .4525 | .362 |
| 20 | .4108 | .3429 | .4525 | .5658 | .2572 | .3982 | .3258 |
| 21 | .3353 | .3429 | .4163 | .4858 | .2572 | .3439 | .3982 |
| 22 | .3239 | .3429 | .3982 | .3734 | .2572 | .3258 | .362 |
| 23 | .3353 | .3429 | .3982 | .362 | .2572 | .2896 | .3239 |
| 24 | .3801 | .3921 | .3429 | .3982 | .3239 | .2572 | .2896 |
| **Max** | **2.0083** | **2.2032** | **2.1822** | **2.4272** | **1.9052** | **1.8861** | **1.8501** |
| **Min** | **.1966** | **.2572** | **.3429** | **.362** | **.2572** | **.2172** | **.2429** |
| **Avg** | **.8082** | **.8173** | **.9893** | **1.0496** | **.8205** | **.7187** | **.6609** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214526 / 33 KV Tannu**
**Feeder No / Name : 202 / Tannu Ag1 FEEDER SEPERATION/PURE AG**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1097 | .1006 | .0857 | .128 | .181 | .1715 | .0914 |
| 2 | .1097 | .1463 | .6097 | .5601 | .5668 | .1715 | .0914 |
| 3 | .128 | .1463 | .6097 | .5601 | .6335 | .1715 | .1097 |
| 4 | .1448 | .1006 | .6097 | .6081 | .6154 | .1715 | .128 |
| 5 | .1448 | .1463 | .6097 | .6081 | .6478 | .1715 | .1463 |
| 6 | .181 | .1463 | .7621 | .6401 | .6554 | .1715 | .1463 |
| 7 | .181 | .1886 | .8383 | .6401 | .6697 | .1715 | |
| 8 | .2172 | .1311 | .8383 | .5921 | .6478 | .1715 | |
| 9 | .2172 | .1296 | .8539 | .6478 | .7602 | .1715 | |
| 10 | 1.1336 | .8383 | .1448 | .1677 | .1715 | .6562 | .6097 |
| 11 | 1.166 | .9145 | .1086 | .0838 | .1715 | .788 | .6401 |
| 12 | 1.1065 | .9907 | .1267 | .0905 | .1715 | .7362 | .8507 |
| 13 | 1.2696 | 1.0669 | .1267 | .0819 | .1715 | .7682 | .8507 |
| 14 | 1.0562 | 1.0669 | .1448 | .0934 | .1715 | .8002 | .7712 |
| 15 | .9145 | .9907 | .181 | .0747 | .1715 | .8002 | .7712 |
| 16 | .884 | .9907 | .1991 | .0648 | .1715 | .8322 | .9054 |
| 17 | 1.0526 | .9145 | .2353 | .0648 | .1715 | .8322 | .9717 |
| 18 | .1867 | .1524 | .3292 | .1867 | .1715 | .1791 | .1341 |
| 19 | .1867 | .1715 | .3109 | .2683 | .1715 | .1791 | .1867 |
| 20 | .1494 | .1715 | .2743 | .1677 | .1715 | .1791 | .1867 |
| 21 | .1307 | .0857 | .2378 | .181 | .1715 | .1463 | .112 |
| 22 | .128 | .0857 | .1829 | .1677 | .1715 | .1463 | .1134 |
| 23 | .1307 | .0857 | .1463 | .1619 | .1715 | .1463 | .1134 |
| 24 | .1097 | .1097 | .0857 | .128 | .181 | .1715 | .128 |
| **Max** | **1.2696** | **1.0669** | **.8539** | **.6478** | **.7602** | **.8322** | **.9717** |
| **Min** | **.1097** | **.0857** | **.0857** | **.0648** | **.1715** | **.1463** | **.0914** |
| **Avg** | **.4599** | **.4113** | **.3605** | **.2903** | **.3317** | **.3710** | **.3837** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052]** **BU 5894**
**Substation No/ Name :- 214526 / 33 KV Tannu**
**Feeder No / Name : 203 / Narsinghpur** **FEEDER SEPERATION/PURE AG**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3801 | .3734 | .2572 | .394 | .3658 | .2572 | .394 |
| 2 | .3801 | .4108 | .6097 | .4858 | .4858 | .2572 | .394 |
| 3 | .394 | .4359 | .6859 | .4858 | .503 | .3429 | .3982 |
| 4 | .4477 | .503 | .7621 | .5668 | .5668 | .3429 | .4572 |
| 5 | .5373 | .5197 | .7621 | .6478 | .6478 | .3429 | .5373 |
| 6 | .6268 | .679 | .7621 | .7042 | .8215 | .4287 | .591 |
| 7 | .6805 | .7167 | .7621 | .7362 | .7712 | .4287 | |
| 8 | .5194 | .4858 | .8383 | .7682 | .6706 | .3429 | |
| 9 | .6447 | .4191 | .8223 | .7373 | .6554 | .3429 | |
| 10 | .6516 | .6097 | .3258 | .3353 | .3429 | .6562 | .6036 |
| 11 | .6706 | .7621 | .2896 | .3353 | .2572 | .7362 | .6036 |
| 12 | .6478 | .7621 | .3258 | .1677 | .3429 | .7362 | .6722 |
| 13 | .6554 | .7621 | .3258 | .1619 | .2572 | .7362 | |
| 14 | | .6859 | .3077 | .2105 | .2572 | .7682 | .7468 |
| 15 | .4877 | .7621 | .3077 | .2715 | .2572 | .7682 | .6478 |
| 16 | .6478 | .7621 | .362 | .362 | .3429 | .7682 | .8688 |
| 17 | .5944 | .7621 | .3982 | .3239 | .3429 | .7682 | .8962 |
| 18 | .3277 | .3048 | .5249 | .2724 | .3429 | .4477 | .4049 |
| 19 | .4108 | .3429 | .5792 | .439 | .3429 | .4525 | .362 |
| 20 | .4108 | .3429 | .543 | .3605 | .3429 | .4477 | .3982 |
| 21 | .3734 | .2572 | .5068 | .3605 | .2572 | .4163 | .3801 |
| 22 | .4163 | .2572 | .4525 | .4344 | .2572 | .4119 | .3982 |
| 23 | .415 | .2572 | .4024 | .3239 | .2572 | .3982 | .4108 |
| 24 | .3801 | .3353 | .2572 | .394 | .3734 | .2572 | .394 |
| **Max** | **.6805** | **.7621** | **.8383** | **.7682** | **.8215** | **.7682** | **.8962** |
| **Min** | **.3277** | **.2572** | **.2572** | **.1619** | **.2572** | **.2572** | **.362** |
| **Avg** | **.5087** | **.5212** | **.5071** | **.4283** | **.4193** | **.4940** | **.5279** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214526 / 33 KV Tannu**
**Feeder No / Name : 204 / Girve2 FEEDER SEPERATION/PURE AG**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2896 | .181 | .2572 | .2715 | .1619 | .2572 | .1463 |
| 2 | 1.0745 | .8048 | .3429 | .2715 | .2429 | .7621 | .7287 |
| 3 | 1.1104 | .6706 | .2572 | .2715 | .2458 | .7621 | .7682 |
| 4 | 1.1012 | .8145 | .2572 | | .3258 | .8383 | .8002 |
| 5 | 1.2003 | 1.0974 | .2572 | .362 | .3239 | .9145 | .8802 |
| 6 | 1.3123 | .8745 | .4287 | .4344 | .4344 | .9907 | .9282 |
| 7 | 1.3757 | 1.1401 | .4287 | .4344 | .3887 | .9907 | 1.0437 |
| 8 | 1.4548 | 1.2574 | .4287 | .4344 | .4527 | 1.1431 | 1.2176 |
| 9 | 1.4074 | 1.448 | .3982 | .3239 | .3353 | 1.0669 | 1.186 |
| 10 | .2267 | .2572 | 1.2651 | 1.1336 | 1.0669 | .181 | .1867 |
| 11 | .1619 | .1715 | 1.2967 | 1.1822 | 1.1431 | .1267 | .1867 |
| 12 | .1677 | .1715 | 1.3441 | 1.2955 | 1.1431 | .1086 | .1677 |
| 13 | .1619 | .1715 | 1.3283 | 1.2955 | 1.2193 | .0905 | .0934 |
| 14 | .1457 | .2572 | .506 | 1.3413 | 1.2193 | .1086 | .0914 |
| 15 | .1448 | .2572 | 1.2651 | 1.0202 | 1.1431 | .1086 | .0943 |
| 16 | .2172 | .2572 | 1.2967 | .8048 | 1.1431 | .1267 | .0819 |
| 17 | .2715 | .2572 | 1.3125 | 1.1336 | 1.0669 | .1448 | .0754 |
| 18 | .2896 | .3429 | .4344 | .2534 | .1715 | .2507 | .2172 |
| 19 | .2614 | .2572 | .3982 | .2267 | .1715 | .2172 | .2896 |
| 20 | .2614 | .2286 | .362 | .1677 | .1715 | .1791 | .2534 |
| 21 | .1677 | .2572 | .2715 | .299 | .1715 | .1448 | .1629 |
| 22 | .1715 | .2572 | .2743 | .2347 | .1715 | .1463 | .1629 |
| 23 | .1844 | .2572 | .2715 | .2591 | .1715 | .1463 | .1457 |
| 24 | .2865 | .181 | .2572 | .2715 | .1829 | .1715 | .1448 |
| **Max** | **1.4548** | **1.448** | **1.3441** | **1.3413** | **1.2193** | **1.1431** | **1.2176** |
| **Min** | **.1448** | **.1715** | **.2572** | **.1677** | **.1619** | **.0905** | **.0754** |
| **Avg** | **.5603** | **.4946** | **.6225** | **.5966** | **.5528** | **.4157** | **.4189** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214527 / 33/11 KV MIDC, LONI DEOKAR**
**Feeder No / Name : 201 / 11 KV KHADI CRASHER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0381 | .013 | .0381 | .0381 | .013 | | |
| 2 | | .013 | | | .013 | | |
| 3 | | .013 | .0381 | .0381 | .013 | | |
| 4 | | .013 | | | .013 | | |
| 5 | .0381 | .013 | | | .013 | | |
| 6 | | .013 | .0381 | .0381 | .013 | | |
| 7 | .0381 | .013 | .0381 | .0381 | .013 | | |
| 8 | .0381 | .013 | .0381 | .0381 | .0259 | | |
| 9 | | .013 | .0381 | .0381 | .0259 | | |
| 10 | .0381 | .013 | .0381 | .0381 | .0259 | | .0305 |
| 11 | .013 | .0381 | .0381 | .013 | | | .013 |
| 12 | .013 | | | .013 | | | .013 |
| 13 | .013 | | | .013 | | .0343 | .013 |
| 14 | .013 | | | .013 | | | .013 |
| 15 | .013 | | | .013 | | | .013 |
| 16 | .013 | | | .013 | | | .013 |
| 17 | .013 | | | .013 | | | .013 |
| 18 | .013 | | | .013 | | | .013 |
| 19 | .013 | | .0381 | .013 | | .0191 | .013 |
| 20 | .0194 | | | .0194 | | .0457 | .013 |
| 21 | .0194 | | | .0194 | | .0457 | .013 |
| 22 | .013 | | | .0194 | | .0457 | .0194 |
| 23 | .013 | | | .0194 | | .0457 | .0194 |
| 24 | .0381 | .013 | .362 | .0381 | .013 | | |
| **Max** | **.0381** | **.0381** | **.362** | **.0381** | **.0259** | **.0457** | **.0305** |
| **Min** | **.013** | **.013** | **.0381** | **.013** | **.013** | **.0191** | **.013** |
| **Avg** | **.0216** | **.0151** | **.0705** | **.0238** | **.0165** | **.0394** | **.0152** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214527 / 33/11 KV MIDC, LONI DEOKAR**
**Feeder No / Name : 202 / 11KV BORATEWADI NHAVI SHEDDABLE RURAL**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .381 | .3239 | .381 | .381 | .3239 | .3429 | .3429 |
| 2 | | .3239 | | | .4858 | .3429 | .3429 |
| 3 | .381 | .3239 | .8002 | .5335 | .4858 | .3429 | .3429 |
| 4 | | .3239 | | | .4858 | .3772 | .3601 |
| 5 | .4572 | .3239 | | .8383 | .6478 | .4115 | .3601 |
| 6 | | .3887 | 1.1431 | | .7449 | .4115 | .3772 |
| 7 | .4572 | .421 | 1.2193 | .9526 | .8097 | .4458 | .3772 |
| 8 | .4954 | .421 | 1.2574 | 1.2193 | 1.0688 | .4115 | .4115 |
| 9 | | .3239 | 1.2955 | 1.2574 | .9717 | .4115 | |
| 10 | .7621 | .9717 | .2667 | .3048 | .2267 | .7545 | .8573 |
| 11 | 1.0364 | | .2667 | .2267 | .2401 | .9945 | 1.004 |
| 12 | 1.2146 | 1.2689 | | | .2401 | 1.0631 | 1.0364 |
| 13 | 1.2955 | 1.286 | | | .2401 | 1.0974 | 1.0364 |
| 14 | 1.2955 | 1.286 | | .2591 | .2401 | 1.0631 | 1.004 |
| 15 | 1.2146 | 1.2346 | | .2591 | .2401 | .8402 | .9069 |
| 16 | 1.1336 | 1.2346 | | .3239 | .2743 | .9774 | .9069 |
| 17 | 1.166 | 1.2003 | | .3563 | .2743 | 1.0288 | .8745 |
| 18 | .2915 | .3772 | | .3563 | .3086 | .3772 | .3239 |
| 19 | .2915 | .3772 | .381 | .1425 | .4973 | .3772 | .3887 |
| 20 | .3239 | .3772 | | .3239 | .4287 | .3772 | .421 |
| 21 | .3239 | .3429 | | .3239 | .4287 | .3601 | .3563 |
| 22 | .3239 | .3429 | | .3239 | .3429 | .3429 | .3239 |
| 23 | .3239 | .3429 | | .3239 | .3429 | .3429 | .3239 |
| 24 | .381 | .3239 | .381 | .381 | .3239 | .3429 | .3429 |
| **Max** | **1.2955** | **1.286** | **1.2955** | **1.2574** | **1.0688** | **1.0974** | **1.0364** |
| **Min** | **.2915** | **.3239** | **.2667** | **.1425** | **.2267** | **.3429** | **.3239** |
| **Avg** | **.6775** | **.6148** | **.7392** | **.4783** | **.4447** | **.5765** | **.5662** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214527 / 33/11 KV MIDC, LONI DEOKAR**
**Feeder No / Name : 203 / 11 KV TONTECH FEEDER SHEDDABLE FEEDER MIDC EQUIVALENT**
**Feeder KV- 11 / OUTGOING HAVING WEEKLY STAGGERING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0191 | .0057 | .0191 | .0191 | .0057 | | |
| 2 | | .0057 | | | .0057 | | |
| 3 | .0191 | .0057 | | .0191 | .0057 | | |
| 4 | | .0057 | .0191 | | .0057 | | |
| 5 | | .0057 | | | .0057 | | |
| 6 | .0191 | .0057 | .0191 | .0191 | .0057 | | |
| 7 | .0191 | .0057 | | .0191 | .0057 | | |
| 8 | .0381 | .0057 | .0191 | .0191 | .0057 | .0191 | |
| 9 | | .0057 | .0191 | | .0057 | .0191 | .0152 |
| 10 | .0572 | .0057 | .0191 | .0572 | .0057 | .0191 | .0686 |
| 11 | .0171 | | .0191 | .0171 | .0114 | .061 | .0114 |
| 12 | .0171 | .0171 | | .0171 | .0114 | .0457 | .0114 |
| 13 | .0171 | .0171 | | .0114 | .0152 | .0305 | .0114 |
| 14 | .0171 | .0171 | | .0057 | .0152 | .0152 | .0171 |
| 15 | .0171 | .0171 | | .0057 | .0152 | .0152 | .0114 |
| 16 | .0114 | .0171 | | .0114 | .0171 | .0152 | .0114 |
| 17 | .0171 | .0171 | | .0114 | .0171 | .0152 | .0114 |
| 18 | .0057 | .0171 | | .0057 | .0171 | .0305 | .0171 |
| 19 | .0057 | .0171 | .0381 | .0057 | .0171 | .0305 | .0114 |
| 20 | .0057 | .0171 | | .0057 | .0171 | .0305 | .0114 |
| 21 | .0057 | .0171 | | .0057 | .0171 | .0305 | .0107 |
| 22 | .0057 | .0171 | | .0057 | .0171 | .0152 | .0114 |
| 23 | .0057 | .0171 | | .0057 | .0171 | .0152 | .0114 |
| 24 | .0191 | .0057 | .181 | .0191 | .0057 | | |
| **Max** | **.0572** | **.0171** | **.181** | **.0572** | **.0171** | **.061** | **.0686** |
| **Min** | **.0057** | **.0057** | **.0191** | **.0057** | **.0057** | **.0152** | **.0107** |
| **Avg** | **.0170** | **.0116** | **.0392** | **.0143** | **.0112** | **.0255** | **.0162** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214527 / 33/11 KV MIDC, LONI DEOKAR**
**Feeder No / Name : 204 / 11 KV KAUTHALI FEEDER SHEDDABLE RURAL**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .381 | .3563 | .381 | .381 | .3563 | .3429 | .3601 |
| 2 | | .3563 | | | .7449 | .3429 | .3601 |
| 3 | .381 | .3563 | | .724 | .8097 | .3429 | .3772 |
| 4 | | .3563 | 1.1431 | | .8907 | .3772 | .3772 |
| 5 | .5716 | .4534 | | | .9717 | .4115 | .4115 |
| 6 | | .5182 | 1.2955 | | 1.0526 | .4115 | .4801 |
| 7 | .6859 | .6478 | | 1.3717 | 1.1336 | .6173 | .583 |
| 8 | .7621 | .5506 | 1.5623 | 1.6004 | 1.2308 | .6173 | .703 |
| 9 | | .4858 | 1.5432 | 1.6004 | 1.1984 | .5144 | .5658 |
| 10 | .7621 | .6478 | .381 | .2667 | .2915 | .8059 | .7888 |
| 11 | .6478 | 1.1812 | .3048 | .2267 | .2401 | .6516 | .9393 |
| 12 | .6478 | 1.166 | | .2267 | .2401 | 1.1145 | .9717 |
| 13 | 1.0688 | 1.2003 | | | .2401 | 1.286 | 1.0688 |
| 14 | 1.0688 | 1.2003 | | .2267 | .2401 | 1.3032 | 1.1012 |
| 15 | | 1.2003 | | | .2743 | 1.3889 | .6478 |
| 16 | 1.004 | 1.166 | | | .3086 | 1.3032 | 1.1336 |
| 17 | 1.1336 | 1.166 | | | .3772 | 1.1831 | .3563 |
| 18 | .2915 | .3772 | | | .4801 | .4458 | .3239 |
| 19 | .3239 | .4287 | .4572 | .3239 | .5144 | .4115 | .3239 |
| 20 | .3563 | .5144 | | .3563 | .5144 | .3772 | .3239 |
| 21 | .3563 | .4287 | | .3563 | .4801 | .3601 | .2915 |
| 22 | .3563 | .3429 | | .3563 | .4458 | .3429 | .2591 |
| 23 | .3563 | .3429 | | .3563 | .4115 | .3601 | .2591 |
| 24 | .381 | .3563 | .381 | .381 | .3563 | .3429 | .3601 |
| **Max** | **1.1336** | **1.2003** | **1.5623** | **1.6004** | **1.2308** | **1.3889** | **1.1336** |
| **Min** | **.2915** | **.3429** | **.3048** | **.2267** | **.2401** | **.3429** | **.2591** |
| **Avg** | **.6072** | **.6583** | **.8277** | **.5836** | **.5751** | **.6523** | **.5570** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214527 / 33/11 KV MIDC, LONI DEOKAR**
**Feeder No / Name : 205 / 11 KV MIDC OFFICE SHEDDABLE FEEDER MIDC EQUIVALENT**
**Feeder KV- 11 / OUTGOING HAVING WEEKLY STAGGERING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0381 | .0107 | .0381 | .0381 | .0107 | | .0305 |
| 2 | | .0107 | | | .0107 | | .0305 |
| 3 | .0381 | .0107 | .0381 | .0381 | .0107 | | .0305 |
| 4 | | .0107 | | | .0107 | | .0305 |
| 5 | | .0107 | .0381 | | .0107 | | .0305 |
| 6 | .0381 | .0107 | | .0381 | .0107 | | .0305 |
| 7 | .0381 | .0107 | .0381 | .0381 | .0107 | | .0305 |
| 8 | .0381 | .0107 | .0381 | .0381 | .0107 | | .0305 |
| 9 | | .0107 | .0381 | .0381 | .0107 | | .0305 |
| 10 | .0953 | .0107 | .0381 | .0572 | .0107 | | .0514 |
| 11 | .0267 | .0381 | .0381 | .0107 | | | .0267 |
| 12 | .0107 | | | .0107 | | .0762 | .0107 |
| 13 | .0107 | | | .0107 | | .0457 | .0267 |
| 14 | .0107 | | | .0107 | | .0762 | .016 |
| 15 | .0107 | | | .016 | | .0514 | .0267 |
| 16 | .0107 | | | .0213 | | .0686 | .0213 |
| 17 | .0107 | | | .0213 | | .0857 | .0267 |
| 18 | .0107 | | | .0213 | | .0457 | .0107 |
| 19 | .0107 | | .0381 | .0213 | | .0686 | .0107 |
| 20 | .016 | | | .0107 | | .0686 | .0107 |
| 21 | .016 | | | .0107 | | .0457 | .0107 |
| 22 | .016 | | | .0107 | | .0457 | .0107 |
| 23 | .016 | | | .0107 | | .0343 | .0107 |
| 24 | .0381 | .016 | .362 | .0381 | .0107 | .0229 | .0305 |
| **Max** | **.0953** | **.0381** | **.362** | **.0572** | **.0107** | **.0857** | **.0514** |
| **Min** | **.0107** | **.0107** | **.0381** | **.0107** | **.0107** | **.0229** | **.0107** |
| **Avg** | **.0250** | **.0134** | **.0705** | **.0243** | **.0107** | **.0566** | **.0240** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214527 / 33/11 KV MIDC, LONI DEOKAR**
**Feeder No / Name : 206 / 11 KV CMP FEEDER SHEDDABLE FEEDER MIDC EQUIVALENT**
**Feeder KV- 11 / OUTGOING HAVING WEEKLY STAGGERING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1905 | .0286 | .0381 | .1905 | .0286 | .1715 | .1886 |
| 2 | | .0286 | | | .0286 | .1715 | .1715 |
| 3 | .1905 | .0229 | .0381 | | .0286 | .1715 | .1715 |
| 4 | | .0229 | | .2286 | .0286 | .2058 | .1715 |
| 5 | | .0229 | .0762 | | .0286 | .2058 | .1886 |
| 6 | .2286 | .0171 | | .2667 | .0343 | .2229 | .2401 |
| 7 | .2286 | .0114 | .2096 | .3048 | .04 | .2572 | .2743 |
| 8 | .2667 | .0114 | .2477 | .3048 | .0457 | .2572 | .2915 |
| 9 | | .0086 | .2286 | .3048 | .0457 | .2572 | .2401 |
| 10 | .3048 | .0086 | .1905 | .3048 | .0457 | .2572 | .2572 |
| 11 | .0457 | .1143 | .2286 | .04 | .2743 | .2572 | .0457 |
| 12 | .0457 | .1029 | | .04 | .2743 | .3086 | .0457 |
| 13 | .0457 | .1029 | | .0457 | .2743 | .2743 | .04 |
| 14 | .04 | .1029 | | .04 | .2743 | .2743 | .0343 |
| 15 | .04 | .1029 | | .04 | .2743 | .2229 | .04 |
| 16 | .04 | .1029 | | .2267 | .2743 | .1715 | .04 |
| 17 | .04 | .1029 | | .04 | .2743 | .2058 | .04 |
| 18 | .0343 | .0857 | | .04 | .2743 | .2058 | .04 |
| 19 | .0343 | .0857 | .2286 | .0343 | .2401 | .2058 | .0343 |
| 20 | .0343 | .0857 | | .0343 | .2401 | .2058 | .0286 |
| 21 | .0343 | .0857 | | .0343 | .2401 | .1886 | .0286 |
| 22 | .0343 | .0514 | | .0343 | .2401 | .1886 | .0286 |
| 23 | .0343 | .0343 | | .0343 | .2401 | .1886 | .0286 |
| 24 | .1905 | .0343 | .6335 | .1905 | .0286 | .1715 | .1886 |
| **Max** | **.3048** | **.1143** | **.6335** | **.3048** | **.2743** | **.3086** | **.2915** |
| **Min** | **.0343** | **.0086** | **.0381** | **.0343** | **.0286** | **.1715** | **.0286** |
| **Avg** | **.1052** | **.0574** | **.2120** | **.1324** | **.1574** | **.2186** | **.1191** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214537 / 33/11 KV BABHULGAON**
**Feeder No / Name : 201 / 11 KV BABHULGAON AG FEEDER SEPERATION/PURE AG**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1543 | .2195 | .1886 | .1886 | .1991 | .1715 | .1991 |
| 2 | .5668 | .6219 | .1715 | .1886 | .1991 | .503 | .5335 |
| 3 | .6516 | .7316 | .2058 | .2058 | .2507 | .5335 | .5335 |
| 4 | .6478 | .7316 | .2401 | .2401 | .2865 | .5792 | .5792 |
| 5 | .7287 | .7499 | .2572 | .2743 | .3086 | .6097 | .6706 |
| 6 | .7773 | .7682 | .2915 | .3429 | | .6554 | .7468 |
| 7 | .8097 | .8596 | .3086 | .3601 | .3601 | .6859 | .7773 |
| 8 | .8421 | .8413 | .2743 | .3429 | .3086 | .7865 | .7773 |
| 9 | .823 | .823 | .2401 | .2572 | .2572 | .7865 | .6859 |
| 10 | .12 | .1463 | .664 | .7011 | .6554 | .1829 | .1991 |
| 11 | .1372 | .1267 | .6706 | .8962 | .7865 | .0857 | .12 |
| 12 | .12 | .1267 | .6706 | .8962 | .7682 | .0857 | .12 |
| 13 | .0857 | .112 | | .8779 | .7499 | .0857 | .1029 |
| 14 | .0857 | .0934 | .7011 | .8413 | .7499 | .0686 | .12 |
| 15 | .1029 | .1109 | .7011 | .8048 | .7316 | .1029 | .1543 |
| 16 | .1029 | .1629 | .7011 | .7865 | .7316 | .1372 | .1372 |
| 17 | .1372 | .1629 | .7316 | .7499 | .695 | .1543 | .1372 |
| 18 | .2401 | .2572 | .2572 | .2743 | .2378 | .2743 | .2572 |
| 19 | .2572 | .2915 | .2743 | .3292 | .2561 | .2572 | .3086 |
| 20 | .2401 | .2401 | .2401 | .2572 | .2058 | .2401 | .2401 |
| 21 | .2012 | .2058 | .2058 | .2279 | .1886 | .1991 | .2743 |
| 22 | .2195 | .1886 | .1715 | .1886 | .1715 | .1991 | .2926 |
| 23 | .2195 | .1886 | .1715 | .1991 | .1543 | .1991 | .2926 |
| 24 | .1715 | .2012 | .1886 | .1886 | .1991 | .1715 | .1991 |
| **Max** | **.8421** | **.8596** | **.7316** | **.8962** | **.7865** | **.7865** | **.7773** |
| **Min** | **.0857** | **.0934** | **.1715** | **.1886** | **.1543** | **.0686** | **.1029** |
| **Avg** | **.3518** | **.3734** | **.3707** | **.4425** | **.4109** | **.3231** | **.3524** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214537 / 33/11 KV BABHULGAON**
**Feeder No / Name : 202 / 11 KV CHINCHMALA AG FEEDER SEPERATION/PURE AG**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0514 | .0914 | .0686 | .0857 | .0747 | .0686 | .0566 |
| 2 | 1.0526 | 1.0974 | .0686 | .0686 | .0747 | 1.0059 | .9907 |
| 3 | 1.0688 | 1.134 | .0857 | .0686 | .0934 | 1.0059 | .9907 |
| 4 | 1.0526 | 1.134 | .0857 | .0857 | .0934 | 1.0212 | .9907 |
| 5 | 1.0526 | 1.1523 | .1029 | .0857 | .0934 | 1.0364 | 1.0059 |
| 6 | 1.0688 | 1.1706 | .1029 | .1029 | .1109 | 1.0364 | 1.0059 |
| 7 | 1.0688 | 1.1523 | .12 | .1029 | .1109 | 1.0364 | .9602 |
| 8 | 1.0526 | 1.134 | .1029 | .12 | .1109 | 1.2437 | .9602 |
| 9 | 1.0364 | 1.0974 | .1029 | .1029 | .0747 | 1.2803 | 1.0059 |
| 10 | .0514 | .0549 | .9555 | .9907 | 1.0212 | .0366 | .0566 |
| 11 | .0171 | .0377 | .884 | 1.134 | 1.262 | .0343 | .0686 |
| 12 | .0343 | .0189 | .945 | 1.1523 | 1.2803 | .0343 | .0343 |
| 13 | .0373 | .0189 | | 1.1706 | 1.2803 | .0171 | .0171 |
| 14 | .0343 | .0189 | .9145 | 1.1888 | 1.2803 | .0171 | .0171 |
| 15 | .0171 | .0377 | .945 | 1.2254 | 1.2803 | .0171 | .0171 |
| 16 | .0171 | .0377 | .9755 | 1.2437 | 1.262 | .0171 | .0343 |
| 17 | .0514 | .0566 | 1.0212 | 1.2986 | 1.262 | .0857 | .0343 |
| 18 | .0686 | .0739 | .0686 | .0914 | .0549 | .0857 | .0857 |
| 19 | .0857 | .0934 | .0857 | .0914 | .0914 | .0857 | .0857 |
| 20 | .1029 | .0857 | .0857 | .0754 | .0686 | .0934 | .0857 |
| 21 | .0914 | .0686 | .0857 | .0566 | .0857 | .0924 | .0914 |
| 22 | .0914 | .0686 | .0686 | .0747 | .0857 | .0566 | .0732 |
| 23 | .1097 | | .0686 | .0747 | .0857 | .056 | .0914 |
| 24 | .0514 | .1097 | .0686 | .0686 | .0747 | .0686 | .0566 |
| **Max** | **1.0688** | **1.1706** | **1.0212** | **1.2986** | **1.2803** | **1.2803** | **1.0059** |
| **Min** | **.0171** | **.0189** | **.0686** | **.0566** | **.0549** | **.0171** | **.0171** |
| **Avg** | **.3902** | **.4324** | **.3484** | **.4483** | **.4713** | **.3972** | **.3673** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214537 / 33/11 KV BABHULGAON**
**Feeder No / Name : 203 / 11 KV DEVKARWASTI AG FEEDER SEPERATION/PURE AG**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2058 | .1829 | .1715 | .1715 | .1991 | .1715 | .2149 |
| 2 | .2058 | .1646 | .3725 | .4268 | .2896 | .1715 | .2149 |
| 3 | .2058 | .1829 | .4049 | .4268 | .2896 | .1715 | .2328 |
| 4 | .2058 | .1829 | .4049 | .4268 | .3048 | .1886 | .2303 |
| 5 | .2229 | .2195 | .421 | .442 | .3353 | .2058 | .2401 |
| 6 | .2401 | .2378 | .4372 | .442 | .4115 | .2229 | .2401 |
| 7 | .2401 | .2195 | .4534 | .4572 | .4268 | .2229 | .2401 |
| 8 | .1886 | .1646 | .4973 | .442 | .4268 | .1829 | .2126 |
| 9 | .1715 | .1463 | .4696 | .4268 | .4268 | .1646 | .1663 |
| 10 | .4287 | .5304 | .12 | .12 | .0914 | .3658 | .2915 |
| 11 | .4877 | .4572 | .1029 | .128 | .1097 | .4049 | .2896 |
| 12 | .4725 | .4572 | .12 | .128 | .128 | .3601 | .3048 |
| 13 | .5182 | .4725 | | .128 | .1097 | .3239 | .3506 |
| 14 | .503 | .4572 | .1029 | .1097 | .1097 | .3077 | .3353 |
| 15 | .5182 | .442 | .1029 | .128 | .1097 | .3258 | .2896 |
| 16 | .4725 | .4115 | .1494 | .1463 | .128 | .3077 | .2896 |
| 17 | .4572 | .442 | .1543 | .1463 | .1463 | .3601 | .2743 |
| 18 | .1372 | .181 | .1715 | .2195 | .1829 | .1543 | .1372 |
| 19 | .1715 | .1991 | .1886 | .1646 | .1646 | .1886 | .1372 |
| 20 | .1886 | .1543 | .2058 | .1928 | .1543 | .2058 | .1543 |
| 21 | .2012 | .1715 | .1715 | .1949 | .1886 | .2058 | .1463 |
| 22 | .1829 | .1715 | .1543 | .1928 | .1886 | .2149 | .1646 |
| 23 | .2012 | .1715 | .1715 | .1991 | .1886 | .2149 | .1646 |
| 24 | .1677 | .2012 | .1715 | .1715 | .1991 | .1886 | .2149 |
| **Max** | **.5182** | **.5304** | **.4973** | **.4572** | **.4268** | **.4049** | **.3506** |
| **Min** | **.1372** | **.1463** | **.1029** | **.1097** | **.0914** | **.1543** | **.1372** |
| **Avg** | **.2914** | **.2759** | **.2487** | **.2513** | **.2212** | **.2430** | **.2307** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 214537 / 33/11 KV BABHULGAON**
**Feeder No / Name : 204 / 11 KV GAIKWADWASTI AG FEEDER SEPERATION/PURE AG**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1372 | .2195 | .1372 | .1543 | .1629 | .1372 | .1448 |
| 2 | .1372 | .2195 | .4858 | .381 | .3506 | .1372 | .1448 |
| 3 | .1715 | .2378 | | .381 | .3506 | .1715 | .1448 |
| 4 | .2572 | .2561 | .5668 | .4268 | .381 | .2058 | .1629 |
| 5 | .2743 | .2743 | .6478 | .4877 | .442 | .2572 | .2149 |
| 6 | .3086 | .2743 | .6802 | .5792 | .6554 | .2915 | .2743 |
| 7 | .3429 | .3475 | .7287 | .6097 | .6706 | .3086 | .2915 |
| 8 | .3429 | .3292 | .7716 | .6401 | .6859 | .2926 | .2629 |
| 9 | .2915 | .2926 | .7287 | .6706 | .6706 | .2195 | .2353 |
| 10 | .6687 | .7865 | .2229 | .1886 | .1991 | .6036 | .5944 |
| 11 | .7926 | .823 | .1715 | .2195 | .2012 | .7611 | .7011 |
| 12 | .7926 | .8383 | .2401 | .2195 | .2195 | .7935 | .7468 |
| 13 | .7926 | .8383 | | .2195 | .2195 | .7935 | .7316 |
| 14 | .7011 | .8383 | .2229 | .2378 | .2378 | .8097 | .7468 |
| 15 | .6859 | .823 | .2572 | .2561 | .2378 | .7773 | .7164 |
| 16 | .7011 | .7926 | .2572 | .2378 | .2743 | .7611 | .6554 |
| 17 | .6401 | .7621 | .2401 | .2561 | .2743 | .7287 | .6401 |
| 18 | .2743 | .2058 | .2572 | .2926 | .2561 | .1543 | .1886 |
| 19 | .2401 | .2328 | .2572 | .2743 | .2926 | .1715 | .1886 |
| 20 | .1886 | .2058 | .2401 | .2401 | .2058 | .1629 | .1715 |
| 21 | .2012 | .1715 | .2058 | .2058 | .1715 | .1294 | .1829 |
| 22 | .1829 | .1372 | .1543 | .1448 | .1372 | .1267 | .1829 |
| 23 | .2012 | .1372 | .1543 | .1448 | .12 | .128 | .1829 |
| 24 | .1372 | .2195 | .1372 | .1543 | .1629 | .1372 | .128 |
| **Max** | **.7926** | **.8383** | **.7716** | **.6706** | **.6859** | **.8097** | **.7468** |
| **Min** | **.1372** | **.1372** | **.1372** | **.1448** | **.12** | **.1267** | **.128** |
| **Avg** | **.3943** | **.4276** | **.3529** | **.3176** | **.3158** | **.3775** | **.3598** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052]** **BU 5894**
**Substation No/ Name :- 217021 / 132/33/11 KV S/STN.INDAPUR**
**Feeder No / Name : 201 / Indapur** **SHEDDABLE URBAN**
**Feeder KV- 11 / OUTGOING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 2.2862 |
| Max | 2.2862 |
| Min | 2.2862 |
| Avg | 2.2862 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052]** **BU 5894**
**Substation No/ Name :- 217021 / 132/33/11 KV S/STN.INDAPUR**
**Feeder No / Name : 202 / kandalga on Feeder KV- 11 / OUTGOING** **SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 1.6194 |
| Max | 1.6194 |
| Min | 1.6194 |
| Avg | 1.6194 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052]** **BU 5894**
**Substation No/ Name :- 217021 / 132/33/11 KV S/STN.INDAPUR**
**Feeder No / Name : 203 / pimpri kh** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | .9945 |
| Max | .9945 |
| Min | .9945 |
| Avg | .9945 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 217021 / 132/33/11 KV S/STN.INDAPUR**
**Feeder No / Name : 204 / kalthan (Indapur Switching Inc Feeder KV- 11 / INCOMING NON SHEDDABLE EXPRESS HV FEEDERS (CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 3.0483 |
| Max | 3.0483 |
| Min | 3.0483 |
| Avg | 3.0483 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 217046 / 132 KV BAWADA**
**Feeder No / Name : 405 / 33kv Bhatnimgaon LIS SHEDDABLE HV(AGRICULTURE)**
**Feeder KV- 33 / OUTGOING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 1.5432 |
| Max | 1.5432 |
| Min | 1.5432 |
| Avg | 1.5432 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 217046 / 132 KV BAWADA**
**Feeder No / Name : 701 / Nira-Bhima SSKL**
**Feeder KV- 132 / OUTGOING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | .9054 |
| Max | .9054 |
| Min | .9054 |
| Avg | .9054 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**INDAPUR[052] BU 5894**
**Substation No/ Name :- 217046 / 132 KV BAWADA**
**Feeder No / Name : 702 / Karmyaogi S.S.K.Ltd NON SHEDDABLE EHV INDUSTRIAL FEEDERS**
**Feeder KV- 132 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | .4527 |
| Max | .4527 |
| Min | .4527 |
| Avg | .4527 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214415 / 33/22 KV BHIGWAN S/STN.**
**Feeder No / Name : 301 / 22KV BHIGWAN AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2058 | | .0747 | .2058 | .1829 | .2058 | .2058 |
| 2 | .2058 | | .0747 | 1.5089 | .1829 | .2743 | .2058 |
| 3 | .2058 | | .0747 | 1.6461 | 1.3108 | .2743 | .2058 |
| 4 | .2058 | | .0747 | 1.8519 | 1.4022 | .2743 | .2058 |
| 5 | .2058 | | .0747 | 1.989 | 1.768 | .2743 | .2058 |
| 6 | .2401 | | .112 | 2.1605 | 1.6766 | .2401 | .2743 |
| 7 | .3086 | | .1494 | 2.332 | 1.829 | .2743 | .3772 |
| 8 | .2743 | | .112 | 2.332 | 2.1948 | .2401 | .3429 |
| 9 | | | .0747 | 2.4006 | 2.1338 | .2743 | |
| 10 | | 2.2348 | .2058 | .1715 | .2058 | 1.8519 | .9335 |
| 11 | | 2.8753 | .2401 | | .2058 | 2.7435 | 1.0082 |
| 12 | | 3.3608 | .1715 | | .2058 | 2.8121 | 2.5019 |
| 13 | | 3.2861 | .2058 | | .2058 | 3.0178 | 2.5393 |
| 14 | | | .2401 | | .1715 | 3.0178 | 3.062 |
| 15 | | 3.3981 | .1715 | | .2058 | 2.9492 | 3.0994 |
| 16 | | 3.2861 | .2058 | | .2401 | 2.7435 | 3.1741 |
| 17 | | 2.9874 | .2058 | | .1715 | 2.572 | 2.9127 |
| 18 | | .3361 | .2058 | | .2058 | .3086 | .2987 |
| 19 | | .2987 | .2743 | | .2058 | .2743 | .2614 |
| 20 | | .2987 | .2743 | | .1715 | .2743 | .2241 |
| 21 | | | .2743 | | .2058 | .2401 | .2614 |
| 22 | | .2241 | .2743 | | .2058 | .2401 | .2614 |
| 23 | | .2241 | .2058 | .1943 | .1715 | .2058 | .2614 |
| 24 | .2401 | | 1.4937 | .2058 | .1829 | .2058 | .2058 |
| **Max** | **.3086** | **3.3981** | **1.4937** | **2.4006** | **2.1948** | **3.0178** | **3.1741** |
| **Min** | **.2058** | **.2241** | **.0747** | **.1715** | **.1715** | **.2058** | **.2058** |
| **Avg** | **.2325** | **1.9009** | **.2279** | **1.4165** | **.6518** | **1.0745** | **1.0012** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214415 / 33/22 KV BHIGWAN S/STN.**
**Feeder No / Name : 302 / 22KV KHANOTA BHIGWAN SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7125 | | .7625 | .7125 | .7449 | .7449 | .7773 |
| 2 | .7125 | | 3.3482 | 3.1093 | 3.1417 | .7449 | .7773 |
| 3 | .7125 | | 3.6466 | 3.2388 | 3.2065 | .8421 | .7773 |
| 4 | .8421 | | 3.8786 | 3.4332 | 3.2388 | .8745 | .9069 |
| 5 | .9717 | | 4.5085 | 3.6275 | 3.4979 | 1.0688 | 1.0364 |
| 6 | 1.2955 | | 4.6411 | 3.8866 | 3.7894 | 1.166 | 1.2955 |
| 7 | 1.2955 | | 4.7074 | 4.1457 | 4.0809 | 1.2631 | 1.3603 |
| 8 | 1.0364 | | .3315 | 4.4048 | 4.2429 | 1.0364 | 1.166 |
| 9 | .7449 | | 4.1438 | 4.4696 | 4.1152 | .7773 | .8421 |
| 10 | | 3.6275 | .6802 | .7125 | .7773 | 3.4332 | |
| 11 | | 4.4262 | .583 | | .6154 | 4.2105 | |
| 12 | | 4.795 | .583 | | .5182 | 4.0809 | 3.8561 |
| 13 | | 4.9726 | .583 | | .4858 | 4.2105 | |
| 14 | | | .5182 | | .5182 | 4.2105 | 4.1579 |
| 15 | | 4.8731 | .5506 | | .5182 | 4.2753 | 4.4932 |
| 16 | | 5.0057 | .5506 | | .6478 | 4.4048 | 4.4932 |
| 17 | | 4.8068 | .6478 | | .6478 | 4.0486 | 4.5603 |
| 18 | | .8951 | .8745 | | .8421 | .9069 | |
| 19 | | 1.1271 | 1.004 | | 1.0364 | 1.004 | 1.1065 |
| 20 | | 1.1271 | .9393 | | 1.004 | 1.004 | .9724 |
| 21 | | 1.0277 | .9393 | | .9393 | .9717 | 1.0059 |
| 22 | | .8951 | .8421 | | .8745 | .9069 | .8718 |
| 23 | | .8288 | 1.446 | .7773 | .8421 | .7926 | .7712 |
| 24 | .7125 | | 1.4937 | .7449 | .7449 | .7773 | .8097 |
| **Max** | **1.2955** | **5.0057** | **4.7074** | **4.4696** | **4.2429** | **4.4048** | **4.5603** |
| **Min** | **.7125** | **.8288** | **.3315** | **.7125** | **.4858** | **.7449** | **.7712** |
| **Avg** | **.9036** | **2.9544** | **1.7585** | **2.7719** | **1.7113** | **1.9898** | **1.8019** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214415 / 33/22 KV BHIGWAN S/STN.**
**Feeder No / Name : 303 / 22KV BHIGWAN GFSS GAOTHAN FEEDER**
**Feeder KV- 22 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8916 | | .8962 | .9602 | .9717 | .8573 | .9602 |
| 2 | .8916 | | .8962 | .8916 | 1.2308 | .8916 | .9602 |
| 3 | .8916 | | .8962 | 1.0288 | 1.4899 | 1.0288 | .9602 |
| 4 | 1.0974 | | 1.0456 | 1.2346 | 1.5546 | 1.2346 | 1.166 |
| 5 | 1.4403 | | 1.5684 | 1.5775 | 1.6842 | 1.5089 | 1.5775 |
| 6 | 1.8861 | | 2.0165 | 1.989 | 1.9433 | 1.989 | 1.989 |
| 7 | 2.332 | | 2.4646 | 2.2634 | 2.0729 | 2.2977 | 2.4691 |
| 8 | 2.1948 | | 2.4272 | 2.1948 | 1.9109 | 2.2291 | 2.2977 |
| 9 | 1.8176 | | 1.9418 | 1.9547 | 3.2693 | 1.7833 | 1.8861 |
| 10 | | 1.8138 | .7011 | 1.6118 | 1.3717 | 1.6461 | 1.6057 |
| 11 | | 1.6057 | 1.5089 | | 1.3717 | 1.406 | 1.4937 |
| 12 | | 1.3817 | 1.2689 | | 1.2003 | 1.2003 | 1.3443 |
| 13 | | 1.307 | 1.3375 | | 1.1317 | 1.166 | 1.0242 |
| 14 | | | 1.166 | | 1.0974 | 1.0974 | 1.1949 |
| 15 | | 1.1949 | 1.0631 | | .9945 | 1.1317 | 1.3817 |
| 16 | | 1.307 | 1.0631 | | 1.0631 | 1.166 | 1.3443 |
| 17 | | 1.4937 | 1.406 | | 1.3032 | 1.3032 | 1.531 |
| 18 | | 1.9418 | 1.8176 | | 1.6118 | 1.8861 | 1.7924 |
| 19 | | 1.9418 | 1.9204 | | 1.7147 | 1.9547 | 2.0911 |
| 20 | | 1.9791 | 1.6461 | | 1.5089 | 1.7147 | 1.7924 |
| 21 | | 1.6057 | 1.406 | | 1.3717 | 1.5089 | 1.4937 |
| 22 | | 1.2323 | 1.2003 | | 1.166 | 1.2346 | 1.307 |
| 23 | | 1.0456 | 1.0288 | 1.0364 | 1.0631 | 1.1317 | 1.0829 |
| 24 | .9602 | | 1.6346 | 1.0288 | .9717 | .9259 | 1.0288 |
| **Max** | **2.332** | **1.9791** | **2.4646** | **2.2634** | **3.2693** | **2.2977** | **2.4691** |
| **Min** | **.8916** | **1.0456** | **.7011** | **.8916** | **.9717** | **.8573** | **.9602** |
| **Avg** | **1.4403** | **1.5269** | **1.4300** | **1.4810** | **1.4612** | **1.4289** | **1.4906** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214415 / 33/22 KV BHIGWAN S/STN.**
**Feeder No / Name : 306 / 22 KV KUMBHARGAON AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2743 | | .3292 | .2058 | .2058 | .2058 | .2058 |
| 2 | 2.0576 | | .3292 | .2058 | .2058 | 1.7833 | 1.7833 |
| 3 | 2.1262 | | .3292 | .2743 | .2058 | 1.9204 | 1.8176 |
| 4 | 2.1262 | | .3361 | .2743 | .2058 | 2.0576 | 1.8519 |
| 5 | 2.1948 | | .3658 | .3086 | .2401 | 2.0919 | 1.9204 |
| 6 | 2.2977 | | .3658 | .3429 | .2401 | 2.1262 | 1.989 |
| 7 | 2.6063 | | .4024 | .3772 | .2401 | 2.1605 | 2.1262 |
| 8 | 2.6406 | | .4024 | .2401 | .2058 | 2.332 | 2.1605 |
| 9 | 2.7435 | | .2561 | .2401 | .2058 | 2.3663 | 2.2634 |
| 10 | | .2401 | 2.5034 | 2.5377 | 2.1033 | .2058 | .2195 |
| 11 | | .2195 | 3.155 | | 2.572 | .2058 | .2195 |
| 12 | | .3658 | 3.0521 | | 2.8807 | .2058 | .2561 |
| 13 | | .4024 | 3.2579 | | 2.9492 | .1372 | .1463 |
| 14 | | | 3.3265 | | 2.9492 | .1372 | .2561 |
| 15 | | .2926 | 3.2922 | | 2.7435 | .2058 | .2926 |
| 16 | | .3658 | 2.915 | | 2.7778 | .2058 | .2926 |
| 17 | | .439 | 2.9835 | | 2.5034 | .2058 | .2926 |
| 18 | | .439 | .2401 | | .2058 | .2743 | |
| 19 | | .3658 | .2743 | | .2058 | .2743 | .2561 |
| 20 | | .3292 | .2401 | | .2058 | .2401 | .2195 |
| 21 | | .3292 | .2743 | | .2058 | .2401 | .2195 |
| 22 | | .439 | .2743 | | .2058 | .2058 | .2195 |
| 23 | | .3292 | .2743 | .2058 | .2058 | .2058 | .2195 |
| 24 | .2743 | | .3292 | .2743 | .2058 | .2058 | .2058 |
| **Max** | **2.7435** | **.439** | **3.3265** | **2.5377** | **2.9492** | **2.3663** | **2.2634** |
| **Min** | **.2743** | **.2195** | **.2401** | **.2058** | **.2058** | **.1372** | **.1463** |
| **Avg** | **1.9342** | **.3505** | **1.2295** | **.4572** | **1.0365** | **.8416** | **.8449** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214435 / 33/11 KV GHOLAPWADI**
**Feeder No / Name : 201 / TAWASHI SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5487 | .6859 | | .5487 | .5658 | .5144 | .5658 |
| 2 | .5144 | .5316 | | .7888 | .823 | .5316 | .5658 |
| 3 | .6001 | .6001 | .7202 | .7545 | .8573 | .5487 | .6516 |
| 4 | .7716 | .6516 | .7888 | .7888 | .8745 | .6516 | .823 |
| 5 | .9602 | .6859 | .9602 | .9259 | .9602 | .8402 | .9774 |
| 6 | 1.2346 | .9088 | 1.1317 | 1.3032 | 1.1317 | 1.1831 | 1.1145 |
| 7 | 1.166 | 1.3717 | 1.3546 | 1.4403 | 1.406 | 1.1831 | 1.2517 |
| 8 | .9945 | 1.406 | 1.6118 | 1.6461 | 1.5432 | 1.0802 | 1.1317 |
| 9 | .9431 | 1.3717 | 1.6118 | 1.6804 | 1.5604 | .7545 | .7716 |
| 10 | 1.3032 | 1.3203 | .583 | .4801 | .5316 | 1.1317 | 1.2517 |
| 11 | 1.6804 | 1.8004 | .4801 | .4115 | .4115 | 1.749 | 1.6975 |
| 12 | 1.8004 | 1.8861 | .4115 | .3429 | .3944 | 1.869 | 1.6461 |
| 13 | 1.869 | 1.8519 | .3429 | .3086 | .3601 | 1.7661 | 1.6118 |
| 14 | 1.5947 | 1.8176 | .3429 | .2572 | .3601 | 1.6975 | 1.5775 |
| 15 | 1.7147 | | .3429 | .3086 | .3086 | 1.6975 | 1.5432 |
| 16 | 1.6975 | 1.6118 | .4801 | .4115 | .3601 | 1.6632 | 1.4575 |
| 17 | 1.1831 | 1.5604 | .4801 | .4973 | .4801 | 1.5947 | 1.2689 |
| 18 | .8573 | .8745 | .9602 | .8573 | .7716 | .8059 | .7888 |
| 19 | 1.0117 | 1.046 | .9945 | .9945 | .9602 | .9945 | .9602 |
| 20 | 1.1488 | .9259 | .9431 | .9259 | .9088 | .8916 | .8916 |
| 21 | .8573 | .7888 | .8402 | .8573 | .8059 | .823 | .8059 |
| 22 | .823 | .6173 | .6344 | .703 | .6687 | .7716 | .6859 |
| 23 | .7373 | .583 | .6173 | .6516 | .5658 | .6859 | .583 |
| 24 | .5658 | .7202 | .5487 | .583 | .6001 | .5487 | .583 |
| **Max** | **1.869** | **1.8861** | **1.6118** | **1.6804** | **1.5604** | **1.869** | **1.6975** |
| **Min** | **.5144** | **.5316** | **.3429** | **.2572** | **.3086** | **.5144** | **.5658** |
| **Avg** | **1.1074** | **1.1138** | **.7810** | **.7695** | **.7587** | **1.0824** | **1.0502** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214435 / 33/11 KV GHOLAPWADI**
**Feeder No / Name : 202 / SAPKALWADI (THORATWADI OLD) SINGLE PHASING Feeder KV- 11 / OUTGOING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | .3506 |
| Max | .3506 |
| Min | .3506 |
| Avg | .3506 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214435 / 33/11 KV GHOLAPWADI**
**Feeder No / Name : 203 / 11KV JAMB SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2743 | .3086 | .3086 | .2915 | .2572 | .3086 | .2572 |
| 2 | .703 | .703 | .3258 | .2743 | .2743 | .7545 | .7373 |
| 3 | .7202 | .823 | .3258 | .3086 | .3086 | .7888 | .823 |
| 4 | .7545 | .8573 | .3429 | .3429 | .4287 | .9088 | .8916 |
| 5 | .8059 | .9945 | .5144 | .4973 | .5144 | .9602 | .9945 |
| 6 | 1.0117 | 1.1488 | .7888 | .7202 | .7202 | 1.0288 | 1.0802 |
| 7 | 1.166 | 1.286 | .8573 | .8059 | | 1.3546 | 1.1488 |
| 8 | 1.3717 | 1.3889 | .6516 | .6344 | .6859 | 1.3375 | 1.3203 |
| 9 | 1.3717 | 1.2346 | .4973 | .463 | .4458 | 1.3546 | 1.2346 |
| 10 | .8573 | .2915 | 1.0802 | 1.3032 | 1.166 | .2915 | .3086 |
| 11 | .2229 | .2401 | 1.3717 | 1.4575 | 1.4746 | .2058 | .2058 |
| 12 | .1715 | .1715 | 1.5261 | | 1.5261 | .1715 | .1886 |
| 13 | .1372 | .1543 | 1.406 | 1.6118 | 1.4918 | .1372 | .1886 |
| 14 | .12 | .1543 | 1.4575 | 1.6289 | 1.4403 | .1372 | .1715 |
| 15 | .1543 | .1715 | 1.4918 | 1.5775 | 1.4403 | .12 | .1543 |
| 16 | .1715 | | 1.5432 | 1.6118 | 1.4232 | .1715 | .2058 |
| 17 | .2915 | | 1.4403 | 1.5432 | 1.5089 | .3086 | .3086 |
| 18 | .4287 | | .4801 | .5144 | .4801 | .4458 | .4973 |
| 19 | .6173 | .6859 | .6173 | .583 | .5487 | .6001 | .6344 |
| 20 | .5316 | .6173 | .5316 | .5144 | .5316 | .5658 | .4801 |
| 21 | .4287 | .4801 | .463 | .4287 | .4115 | .4458 | .4287 |
| 22 | .3944 | .3429 | .3429 | .3429 | .3429 | | .3772 |
| 23 | .3429 | .3258 | .3258 | .3086 | .3086 | .3429 | .2915 |
| 24 | .3086 | .3258 | .6592 | .3086 | .2915 | .2915 | .2915 |
| **Max** | **1.3717** | **1.3889** | **1.5432** | **1.6289** | **1.5261** | **1.3546** | **1.3203** |
| **Min** | **.12** | **.1543** | **.3086** | **.2743** | **.2572** | **.12** | **.1543** |
| **Avg** | **.5566** | **.6050** | **.8062** | **.7858** | **.7835** | **.5666** | **.5508** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214435 / 33/11 KV GHOLAPWADI**
**Feeder No / Name : 204 / 11KV UDMAI GAOTHAN GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .0343 | .0343 | .0343 | .0171 | .0343 | .0343 |
| 2 | .0171 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| 3 | .0171 | .0171 | .0343 | .0171 | .0343 | .0171 | .0343 |
| 4 | .0171 | .0343 | .0343 | .0343 | .0343 | .0171 | .0343 |
| 5 | .0343 | .0343 | .0343 | .0514 | .0343 | .0343 | .0343 |
| 6 | .0343 | .0343 | .0343 | .0343 | .0171 | .0514 | .0343 |
| 7 | .0171 | .0343 | .0343 | .0343 | .0171 | .0343 | .0343 |
| 8 | .0343 | .0171 | .0343 | .0514 | .0343 | .0171 | .0171 |
| 9 | .0514 | .0514 | .0343 | .0343 | .0514 | .0343 | .0514 |
| 10 | .0514 | .0514 | .0343 | .0343 | .0514 | .0514 | .0514 |
| 11 | .0514 | .0343 | .0514 | .0171 | .0514 | .0343 | .0514 |
| 12 | .0343 | .0171 | .0343 | .0171 | .0343 | .0171 | .0343 |
| 13 | .0171 | .0343 | .0514 | .0171 | .0343 | .0171 | .0343 |
| 14 | .0171 | .0171 | | .0171 | .0343 | .0171 | .0171 |
| 15 | .0171 | .0171 | | .0171 | .0343 | .0171 | .0171 |
| 16 | .0171 | .0171 | .0171 | .0171 | .0171 | .0343 | .0171 |
| 17 | .0171 | .0171 | .0171 | .0171 | .0171 | .0171 | .0171 |
| 18 | .0171 | .0171 | .0343 | .0171 | .0171 | .0171 | .0171 |
| 19 | .0171 | .0343 | .0343 | .0171 | .0343 | .0343 | .0343 |
| 20 | .0171 | .0343 | .0171 | .0171 | .0343 | .0343 | .0171 |
| 21 | .0343 | .0171 | .0343 | .0171 | .0171 | .0171 | .0171 |
| 22 | .0171 | .0171 | .0343 | .0171 | .0171 | .0171 | .0171 |
| 23 | .0171 | .0343 | .0171 | .0343 | .0171 | .0171 | .0171 |
| 24 | .0343 | .0171 | .0343 | .0171 | .0171 | .0171 | .0343 |
| **Max** | **.0514** | **.0514** | **.0514** | **.0514** | **.0514** | **.0514** | **.0514** |
| **Min** | **.0171** | **.0171** | **.0171** | **.0171** | **.0171** | **.0171** | **.0171** |
| **Avg** | **.0261** | **.0278** | **.0327** | **.0257** | **.0293** | **.0264** | **.0293** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214435 / 33/11 KV GHOLAPWADI**
**Feeder No / Name : 205 / KURAWALI SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5144 | .6859 | .5658 | .583 | .5316 | .5316 | .5144 |
| 2 | .7545 | .8745 | .583 | .5487 | .5144 | .823 | .9259 |
| 3 | .7888 | .9945 | .583 | .583 | .6173 | .8916 | .9945 |
| 4 | .8916 | 1.1488 | .6173 | .6344 | .8059 | .9945 | 1.0631 |
| 5 | 1.0117 | 1.2346 | .8573 | .8916 | .9602 | 1.1317 | 1.2689 |
| 6 | 1.2517 | 1.5089 | 1.2174 | 1.0802 | 1.1145 | 1.3717 | 1.4403 |
| 7 | 1.7147 | 1.6975 | 1.2003 | 1.1488 | 1.0631 | 1.6289 | 1.6975 |
| 8 | 1.869 | 1.749 | 1.0631 | .9774 | .9431 | 1.6804 | 1.8519 |
| 9 | 1.749 | 1.6975 | .7888 | .7373 | .6859 | 1.6289 | 1.8519 |
| 10 | .5658 | .6173 | 1.3717 | 1.4575 | 1.3203 | .583 | .5658 |
| 11 | .3944 | .4287 | 1.1145 | 1.8004 | 1.8004 | .4115 | .463 |
| 12 | .3601 | .3772 | 1.6975 | 1.8004 | 1.9033 | .3772 | .4287 |
| 13 | .3601 | .2286 | | 1.8176 | 1.7661 | .2915 | .4115 |
| 14 | .3601 | .3086 | 1.7147 | 1.8004 | 1.6461 | .3086 | .3772 |
| 15 | .3772 | .3772 | 1.6975 | 1.6461 | 1.5775 | .3258 | .3601 |
| 16 | .3944 | .4287 | | 1.8176 | 1.5604 | .4287 | .4115 |
| 17 | .583 | .5658 | 1.3717 | 1.7147 | 1.3717 | .6344 | .5316 |
| 18 | .7202 | .8402 | .823 | .7545 | .703 | .8059 | .8059 |
| 19 | .9259 | .9431 | .9774 | .9431 | .8745 | .9774 | .9431 |
| 20 | .8573 | .8573 | .8059 | .7202 | .7716 | .7373 | .7888 |
| 21 | .7373 | .8059 | .703 | .6516 | .703 | .3601 | .7545 |
| 22 | .6859 | .6001 | .6859 | .6001 | .6516 | .3772 | .6687 |
| 23 | .6687 | .583 | .6516 | .5658 | .6001 | .4801 | .5316 |
| 24 | .5487 | .583 | .5658 | .6173 | .5487 | .5487 | .5316 |
| **Max** | **1.869** | **1.749** | **1.7147** | **1.8176** | **1.9033** | **1.6804** | **1.8519** |
| **Min** | **.3601** | **.2286** | **.5658** | **.5487** | **.5144** | **.2915** | **.3601** |
| **Avg** | **.7952** | **.8390** | **.9844** | **1.0788** | **1.0431** | **.7637** | **.8409** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214435 / 33/11 KV GHOLAPWADI**
**Feeder No / Name : 206 / 11KV THORATWADI (NEW) SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2229 | .3258 | .2401 | .2058 | .2229 | .2229 | .2058 |
| 2 | .3429 | .3944 | .2572 | .1886 | .2401 | .3772 | .3086 |
| 3 | .4115 | .4801 | .2572 | .2058 | .2743 | .4115 | .4287 |
| 4 | .5316 | .5658 | .2743 | .2401 | .4287 | .4801 | .5316 |
| 5 | .6001 | .6859 | .4458 | .4115 | .4973 | .5658 | .6001 |
| 6 | .6344 | .823 | .6173 | .583 | .6173 | .6344 | .6516 |
| 7 | .7373 | | .7716 | .7373 | .823 | .8059 | .7888 |
| 8 | .9602 | .9774 | .5316 | .3658 | .4458 | 1.0117 | 1.0288 |
| 9 | 1.0288 | 1.1317 | .463 | .463 | .4973 | .9774 | .9945 |
| 10 | .3086 | .3086 | .9088 | .8573 | .9088 | .3258 | .3086 |
| 11 | .2058 | .2401 | 1.4575 | | 1.1145 | .2229 | .1886 |
| 12 | .1543 | .1543 | 1.4232 | 1.2689 | 1.166 | .12 | .1543 |
| 13 | | | 1.3889 | 1.3032 | 1.1488 | .1372 | .1543 |
| 14 | .1715 | .1543 | 1.3375 | 1.2346 | 1.1145 | .1372 | .1715 |
| 15 | .1372 | .1715 | 1.3546 | 1.2346 | .9774 | .1543 | .1715 |
| 16 | .2229 | .2572 | 1.286 | 1.166 | 1.0802 | .1886 | .2058 |
| 17 | .3086 | .3429 | 1.1488 | 1.0288 | .8745 | .2401 | .2572 |
| 18 | .463 | .4287 | .4801 | .463 | .3944 | .4458 | .5144 |
| 19 | .5144 | .4973 | .5144 | .4458 | .463 | .4973 | .4973 |
| 20 | .4801 | .4115 | .4115 | .4458 | .4287 | .463 | .4115 |
| 21 | .4115 | .3429 | .3601 | .3429 | .3601 | .4287 | .3601 |
| 22 | .3944 | .2743 | .2743 | .2401 | .2743 | .3944 | .3086 |
| 23 | .3429 | .2572 | .2572 | .2229 | .2229 | .3429 | .2401 |
| 24 | .2401 | .3429 | .2401 | .2401 | .2058 | .2058 | .2229 |
| **Max** | **1.0288** | **1.1317** | **1.4575** | **1.3032** | **1.166** | **1.0117** | **1.0288** |
| **Min** | **.1372** | **.1543** | **.2401** | **.1886** | **.2058** | **.12** | **.1543** |
| **Avg** | **.4272** | **.4349** | **.6959** | **.6041** | **.6159** | **.4080** | **.4044** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214449 / 33/11 KV KAZAD S/STN.**
**Feeder No / Name : 201 / 11KV BHAWANINAGAR AG SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3944 | .3772 | .3601 | .3772 | .3429 | .3772 | .3772 |
| 2 | .3944 | .3772 | 1.166 | 1.0364 | 1.0688 | .3772 | .3772 |
| 3 | .3944 | .4458 | 1.1984 | 1.1336 | 1.1336 | .3772 | .4904 |
| 4 | .4458 | .5144 | 1.1984 | 1.1336 | 1.1984 | .4115 | .6036 |
| 5 | .5487 | .583 | 1.2308 | 1.1984 | 1.2793 | .583 | .6413 |
| 6 | .6344 | .6344 | 1.2955 | 1.2308 | 1.4232 | .6516 | .7167 |
| 7 | .703 | .6687 | 1.587 | 1.3279 | 1.3603 | .6173 | .679 |
| 8 | .6516 | .6516 | 1.6518 | 1.6842 | 1.4575 | .6344 | .679 |
| 9 | .4801 | .5144 | 1.6842 | 1.6518 | 1.4899 | .4801 | .4527 |
| 10 | 1.5947 | 1.5061 | .4527 | .3429 | .4115 | 1.3603 | 1.5546 |
| 11 | 1.8176 | 1.7166 | .3018 | .2401 | .3429 | 1.6194 | 1.668 |
| 12 | 1.8107 | 1.8138 | .3018 | .2058 | .2743 | 1.7004 | 1.7166 |
| 13 | 1.9376 | 1.6518 | .2263 | .1886 | .2229 | 1.7166 | 1.587 |
| 14 | 1.8945 | 1.6842 | .2263 | .2058 | .2401 | 1.6194 | 1.6518 |
| 15 | 1.869 | 1.7004 | .2263 | .2058 | .2401 | 1.6194 | 1.6032 |
| 16 | 1.8519 | 1.7004 | .2263 | .1715 | .2915 | 1.6194 | 1.5223 |
| 17 | 1.7318 | 1.7166 | .2263 | .2058 | .3429 | 1.6194 | 1.4575 |
| 18 | .5144 | .5144 | .5658 | .5144 | .4287 | .4801 | .5144 |
| 19 | .5144 | .583 | .679 | .5316 | .4801 | .5487 | .583 |
| 20 | .4801 | .4801 | .5281 | .5487 | .4458 | .4115 | .4458 |
| 21 | .463 | .4458 | .4904 | .5144 | .4115 | .3429 | .4115 |
| 22 | .4115 | .4115 | .4527 | .4115 | .4115 | .3429 | .3772 |
| 23 | | .3772 | .415 | .3944 | .3944 | .3772 | .3772 |
| 24 | .4115 | .3772 | .3601 | .3772 | .3772 | .3944 | .3772 |
| **Max** | **1.9376** | **1.8138** | **1.6842** | **1.6842** | **1.4899** | **1.7166** | **1.7166** |
| **Min** | **.3944** | **.3772** | **.2263** | **.1715** | **.2229** | **.3429** | **.3772** |
| **Avg** | **.9543** | **.8936** | **.7105** | **.6597** | **.6696** | **.8451** | **.8694** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214449 / 33/11 KV KAZAD S/STN.**
**Feeder No / Name : 202 / 11KV SHINDEWADI SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3429 | .3429 | .3429 | .3772 | .3258 | .3772 | .3772 |
| 2 | .3429 | .3429 | .3563 | .2915 | .3563 | .3772 | .415 |
| 3 | .3772 | .3944 | .3887 | .3239 | .4858 | .4115 | .4715 |
| 4 | .4115 | .4287 | .3887 | .3887 | .6154 | .4801 | .5281 |
| 5 | .5144 | .5316 | .4534 | .421 | .6964 | .5487 | .6224 |
| 6 | .6173 | .6001 | .5182 | .5182 | .7935 | .6516 | .679 |
| 7 | .6859 | .7202 | .8097 | .7449 | .8745 | .7545 | .8299 |
| 8 | .7545 | .6859 | 1.0364 | 1.166 | 1.0202 | .7545 | .7922 |
| 9 | .6173 | .4801 | 1.1336 | 1.1336 | 1.1336 | .6173 | .679 |
| 10 | .7545 | .6802 | .415 | .4458 | .3772 | .583 | .7773 |
| 11 | .8718 | .8097 | .2829 | .2743 | .2743 | .8097 | .9393 |
| 12 | .9259 | 1.0364 | .2829 | .2572 | .2401 | .8421 | .9393 |
| 13 | .9431 | 1.004 | .2452 | .2058 | .2058 | .8421 | .9717 |
| 14 | .9602 | 1.004 | .2452 | .2229 | .2058 | .9069 | .9717 |
| 15 | .9088 | 1.0364 | .2452 | .2058 | .2058 | .6802 | .9069 |
| 16 | .8916 | 1.004 | .2075 | .2229 | .2058 | .8097 | .8745 |
| 17 | .8916 | .8097 | .2641 | .3086 | .2058 | .9393 | .8097 |
| 18 | .5144 | .5487 | .5281 | .5487 | .5487 | .6224 | .6516 |
| 19 | .5316 | .6859 | .5658 | .583 | .6173 | .6859 | .6516 |
| 20 | .5487 | .5144 | .6036 | .5144 | .4801 | .4973 | .5144 |
| 21 | .463 | .4801 | .4904 | .4458 | .4458 | .4287 | .4458 |
| 22 | .3772 | .4115 | .4527 | .3772 | .4115 | .4115 | .4115 |
| 23 | .3429 | .3772 | .415 | .3601 | .3772 | .415 | .4115 |
| 24 | .3429 | .3429 | .3429 | .415 | .3429 | .3772 | .415 |
| **Max** | **.9602** | **1.0364** | **1.1336** | **1.166** | **1.1336** | **.9393** | **.9717** |
| **Min** | **.3429** | **.3429** | **.2075** | **.2058** | **.2058** | **.3772** | **.3772** |
| **Avg** | **.6222** | **.6363** | **.4589** | **.4480** | **.4769** | **.6177** | **.6703** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214449 / 33/11 KV KAZAD S/STN.**
**Feeder No / Name : 203 / 11KV KAZAD AG SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5144 | .5144 | .5316 | .5658 | .5658 | .5487 | .6413 |
| 2 | .5344 | .5316 | .5316 | .5658 | .5487 | .583 | .679 |
| 3 | .6316 | .6516 | .5487 | .6413 | .6001 | .6516 | .6478 |
| 4 | .6964 | .7202 | .6173 | .7167 | .6516 | .6859 | .7125 |
| 5 | .8097 | .8745 | .6859 | .9431 | .7716 | .7202 | .7773 |
| 6 | .9555 | 1.1576 | .8573 | 1.1694 | .9088 | .7888 | .9717 |
| 7 | 1.1984 | 1.3032 | 1.0631 | 1.226 | | 1.3032 | 1.2955 |
| 8 | 1.3117 | 1.5261 | .9602 | 1.094 | .823 | 1.406 | 1.2955 |
| 9 | 1.4575 | 1.5604 | .7888 | .9054 | .6859 | 1.2308 | 1.2955 |
| 10 | .463 | .5144 | 1.0688 | 1.004 | 1.1336 | .5281 | .5487 |
| 11 | .3429 | .3429 | 1.4575 | 1.3603 | 1.2955 | .4904 | .3601 |
| 12 | .3086 | .3086 | 1.6518 | 1.3765 | 1.2955 | .3018 | .3429 |
| 13 | .2401 | .3086 | 1.4251 | 1.2955 | 1.3441 | .3772 | .3429 |
| 14 | .2743 | .2572 | 1.5546 | 1.3603 | 1.3603 | .2641 | .2572 |
| 15 | .2915 | .2743 | 1.3765 | 1.4251 | 1.3927 | .2641 | .2572 |
| 16 | .3086 | .2915 | 1.4899 | 1.3603 | 1.3765 | .3429 | .2915 |
| 17 | .4801 | .5144 | 1.4251 | 1.3441 | 1.2955 | .4287 | .5144 |
| 18 | .6516 | .7545 | .9054 | .6859 | .6001 | .7545 | .7716 |
| 19 | .703 | .8745 | 1.0562 | .7888 | .823 | .8916 | .8745 |
| 20 | .7545 | .6516 | .8488 | .6859 | .6859 | .6859 | .7202 |
| 21 | .6516 | .6173 | .679 | .6516 | .6001 | .6173 | .6516 |
| 22 | .5316 | .583 | .6413 | .6173 | .6001 | .5487 | .6173 |
| 23 | .5316 | .5487 | .6036 | .6001 | .583 | .6036 | .583 |
| 24 | .5487 | .5144 | .5316 | .5658 | .583 | .5658 | .6036 |
| **Max** | **1.4575** | **1.5604** | **1.6518** | **1.4251** | **1.3927** | **1.406** | **1.2955** |
| **Min** | **.2401** | **.2572** | **.5316** | **.5658** | **.5487** | **.2641** | **.2572** |
| **Avg** | **.6330** | **.6748** | **.9708** | **.9562** | **.8924** | **.6493** | **.6689** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214449 / 33/11 KV KAZAD S/STN.**
**Feeder No / Name : 204 / 11KV WADACHA MALA AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3772 | .4458 | .4115 | .4527 | .4115 | .4115 | .4527 |
| 2 | .3772 | .4458 | .3725 | .4534 | .4534 | .4115 | .4904 |
| 3 | .4115 | .4801 | .4049 | .4858 | .583 | .4458 | .5658 |
| 4 | .4458 | .5658 | .4534 | .5506 | .6802 | .5144 | .6036 |
| 5 | .5487 | .6344 | .5182 | .6154 | .8097 | .6173 | .6173 |
| 6 | .6173 | .6859 | .5992 | .7125 | .8583 | .7202 | .703 |
| 7 | .7373 | .7545 | .8421 | .9231 | .9717 | .7373 | .8676 |
| 8 | .6516 | .6859 | 1.166 | 1.0688 | 1.0802 | .6344 | .7167 |
| 9 | .463 | .5316 | 1.1822 | 1.0688 | 1.085 | .4973 | .6224 |
| 10 | .7373 | .7125 | .3584 | .3772 | .3258 | .6316 | .7287 |
| 11 | .8573 | .8745 | .2641 | .3086 | .2058 | .8745 | .8745 |
| 12 | .9602 | .9717 | .2641 | .2401 | .1886 | 1.0202 | .9717 |
| 13 | .9945 | 1.0364 | .2075 | .2229 | .2401 | .9393 | 1.046 |
| 14 | 1.0288 | 1.1012 | .2641 | .2058 | .1886 | 1.0688 | .9555 |
| 15 | 1.0288 | 1.085 | .2641 | .2401 | .2058 | .8097 | .9231 |
| 16 | 1.046 | 1.1174 | .2641 | .2058 | .2401 | .8907 | .9602 |
| 17 | .9774 | .7449 | .3206 | .2401 | .3086 | .9717 | .8907 |
| 18 | | .4458 | .5658 | .4458 | .3601 | .6036 | .5316 |
| 19 | .5144 | .6344 | .679 | .6173 | .5658 | .6344 | .6173 |
| 20 | .5658 | .5316 | .6224 | .583 | .5658 | .5658 | .5144 |
| 21 | .5144 | .5144 | .5093 | .5144 | .4801 | .4973 | .4973 |
| 22 | .4801 | .4801 | .4904 | .463 | .4458 | .463 | .463 |
| 23 | .463 | .4458 | .4527 | .4458 | .4458 | .4904 | .463 |
| 24 | .3944 | .4458 | .4287 | .4527 | .4287 | .4115 | .4527 |
| **Max** | **1.046** | **1.1174** | **1.1822** | **1.0688** | **1.085** | **1.0688** | **1.046** |
| **Min** | **.3772** | **.4458** | **.2075** | **.2058** | **.1886** | **.4115** | **.4527** |
| **Avg** | **.6605** | **.6821** | **.4961** | **.4956** | **.5054** | **.6609** | **.6887** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214449 / 33/11 KV KAZAD S/STN.**
**Feeder No / Name : 205 / 11KV LAKADI AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2229 | .2229 | .2058 | .2263 | .2058 | .2058 | .2263 |
| 2 | 1.1336 | 1.1949 | .2058 | .2263 | .2058 | 1.1336 | .9717 |
| 3 | 1.166 | 1.2071 | .2401 | .2452 | .2401 | 1.166 | 1.0364 |
| 4 | 1.2689 | 1.2574 | .2743 | .2641 | .2743 | 1.2308 | 1.1498 |
| 5 | 1.2955 | 1.358 | .2743 | .3018 | .2915 | 1.2955 | 1.2308 |
| 6 | 1.4251 | 1.4922 | .3086 | .3395 | .3258 | 1.3603 | 1.3279 |
| 7 | 1.8861 | 1.7833 | .3772 | | .3944 | 1.7814 | 1.5223 |
| 8 | 1.8138 | 1.9547 | .3429 | .415 | .3429 | 1.9109 | 1.7814 |
| 9 | 1.9433 | 1.7436 | .2743 | .3018 | .2743 | 1.9433 | 1.7814 |
| 10 | .2229 | .2572 | 1.5223 | 1.5546 | 1.6194 | .3429 | .2058 |
| 11 | | .1543 | 2.1214 | 1.8299 | 1.9595 | .1698 | .1886 |
| 12 | .0857 | .1372 | 2.1376 | 2.0567 | 1.8947 | .1698 | .1715 |
| 13 | .1029 | .1715 | 2.1538 | 2.2024 | 2.0405 | .132 | .1372 |
| 14 | .1029 | .1543 | 2.0081 | 2.17 | | .1132 | .1372 |
| 15 | .1372 | .1372 | 2.0081 | 2.1862 | | .1132 | .12 |
| 16 | .1372 | .1543 | 2.0729 | 2.0243 | 1.6194 | .1372 | .1372 |
| 17 | .1543 | .1715 | 1.9757 | 1.9595 | 1.7976 | .1543 | .1715 |
| 18 | .2058 | .2743 | .3206 | .2743 | .3429 | .3206 | .2572 |
| 19 | .2229 | .3086 | .3772 | .3258 | .3086 | .3258 | .2915 |
| 20 | .2401 | .2401 | .3206 | .2915 | .2401 | .2401 | .2401 |
| 21 | .2229 | .2401 | .2641 | .2572 | .2401 | .2229 | .2401 |
| 22 | .2058 | .2229 | .2263 | .2401 | .2229 | .2229 | .2401 |
| 23 | .2229 | .2229 | .2263 | .2229 | .2229 | .2263 | .2229 |
| 24 | .2229 | .2058 | .2058 | .2263 | .2229 | .2058 | .2263 |
| **Max** | **1.9433** | **1.9547** | **2.1538** | **2.2024** | **2.0405** | **1.9433** | **1.7814** |
| **Min** | **.0857** | **.1372** | **.2058** | **.2229** | **.2058** | **.1132** | **.12** |
| **Avg** | **.6366** | **.6361** | **.8518** | **.8757** | **.6948** | **.6302** | **.5840** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214464 / 33 KV NIM SAKHAR**
**Feeder No / Name : 201 / 11KV NIMSAKHAR AG SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3086 | .3239 | .3086 | .3429 | .4049 | .3086 | .2743 |
| 2 | .3086 | .3239 | .2743 | .3086 | .4858 | .2915 | .2743 |
| 3 | .3258 | .3239 | | .3772 | .503 | .2572 | .2915 |
| 4 | .3772 | .3239 | .3772 | .4801 | .4858 | .4115 | .3429 |
| 5 | .5658 | .4049 | .4973 | .6001 | .5668 | .583 | .5487 |
| 6 | .7716 | .4858 | .6173 | .7716 | .6478 | .7545 | .7545 |
| 7 | .8402 | .5668 | .7373 | .9431 | .6478 | .9259 | .8402 |
| 8 | .9088 | .6154 | .8745 | 1.0288 | .8097 | .7202 | .8059 |
| 9 | .6687 | | .7716 | .9431 | .8097 | .5658 | .6344 |
| 10 | .8097 | .823 | .3429 | .4144 | .463 | .6344 | .8097 |
| 11 | .8097 | .8573 | .4115 | .4049 | .3601 | .7545 | .5668 |
| 12 | .8097 | .8573 | .2743 | .3239 | .3086 | .6859 | .5668 |
| 13 | .8097 | .823 | .2743 | .3239 | .2401 | .7545 | .503 |
| 14 | .8097 | .8402 | .2058 | | .2058 | .6859 | .4858 |
| 15 | .8097 | .8573 | .2058 | | .2229 | .7373 | .503 |
| 16 | .8097 | .8916 | .2058 | .3239 | .2229 | .7716 | .503 |
| 17 | .8097 | .8402 | .3429 | .4049 | .3601 | .8402 | .4858 |
| 18 | .3315 | .583 | .4801 | .4973 | .4973 | .5487 | .5668 |
| 19 | .3239 | .8059 | .7545 | .5868 | .7202 | .5316 | .5668 |
| 20 | .5668 | .6173 | .6859 | .5935 | .6173 | .6173 | .4858 |
| 21 | .4858 | .5144 | .6173 | .503 | .5144 | .4973 | .4049 |
| 22 | .4144 | .4287 | .4115 | .4915 | .4115 | .4115 | .4049 |
| 23 | .3315 | .3429 | .3429 | .4049 | .3772 | .3429 | .4191 |
| 24 | .3086 | .3239 | .3258 | .3429 | .4096 | .3258 | .2743 |
| **Max** | **.9088** | **.8916** | **.8745** | **1.0288** | **.8097** | **.9259** | **.8402** |
| **Min** | **.3086** | **.3239** | **.2058** | **.3086** | **.2058** | **.2572** | **.2743** |
| **Avg** | **.5965** | **.5989** | **.4495** | **.5187** | **.4705** | **.5816** | **.5131** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214464 / 33 KV NIM SAKHAR**
**Feeder No / Name : 202 / 11KV SARAFWADI 1 AG SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3429 | .2429 | .4801 | .3429 | .3239 | .2743 | .3086 |
| 2 | .3429 | .2486 | .6687 | .2572 | | .2572 | .3086 |
| 3 | .3772 | .2429 | .8402 | .2572 | .4858 | .2401 | .3429 |
| 4 | .4287 | .2429 | 1.0288 | .5144 | .4858 | .3601 | .3944 |
| 5 | .5487 | .3239 | 1.2003 | .8573 | .5668 | .4973 | .5487 |
| 6 | .703 | .4858 | 1.3889 | 1.2003 | .7287 | .6344 | .6516 |
| 7 | .823 | .6706 | 1.5604 | 1.286 | | .7716 | .8059 |
| 8 | .7202 | .6478 | 1.749 | 1.7147 | 1.2955 | .6687 | .7716 |
| 9 | .5316 | .4144 | 1.6804 | 1.6289 | 1.6194 | .5658 | .5658 |
| 10 | .9717 | .9945 | .2743 | .3277 | .3429 | .9088 | 1.2955 |
| 11 | 1.1336 | 1.6804 | .2743 | .2267 | .2572 | 1.1831 | 1.1336 |
| 12 | 1.2955 | 1.7318 | .2058 | .2347 | .2058 | 1.3375 | 1.1336 |
| 13 | 1.5089 | 1.749 | .2058 | .2561 | .2058 | 1.406 | 1.1336 |
| 14 | 1.4918 | 1.6632 | | .2267 | .2058 | .9259 | .9717 |
| 15 | 1.5089 | 1.5947 | .2058 | .2267 | | 1.3717 | 1.0059 |
| 16 | 1.4918 | 1.5261 | .2058 | .2429 | .2058 | 1.3375 | .8097 |
| 17 | 1.2955 | 1.4232 | .2058 | .3239 | .3258 | 1.2517 | .8097 |
| 18 | .4049 | .4458 | .4115 | .4858 | .4287 | .4458 | .4049 |
| 19 | .4858 | .6001 | .5487 | .4858 | .4973 | .583 | .4049 |
| 20 | .4858 | .583 | .3429 | .503 | .4801 | .4458 | .4049 |
| 21 | .4144 | .4973 | .3429 | .4049 | .4115 | .3944 | .4049 |
| 22 | .4144 | .4115 | .3429 | .3239 | .3601 | .3601 | .4049 |
| 23 | .3239 | .3429 | .3429 | .3239 | .3258 | .3429 | .4049 |
| 24 | .3429 | .2429 | .3086 | .3429 | .3239 | .2915 | .3086 |
| **Max** | **1.5089** | **1.749** | **1.749** | **1.7147** | **1.6194** | **1.406** | **1.2955** |
| **Min** | **.3239** | **.2429** | **.2058** | **.2267** | **.2058** | **.2401** | **.3086** |
| **Avg** | **.7662** | **.7919** | **.6441** | **.5414** | **.4801** | **.7023** | **.6554** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214464 / 33 KV NIM SAKHAR**
**Feeder No / Name : 203 / 11KV KHOROCHI 1 AG** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7373 | .3239 | .703 | .6173 | .4858 | .6859 | .6516 |
| 2 | 1.0288 | .8097 | .6859 | .6173 | .4858 | .6859 | .7888 |
| 3 | 1.0288 | .8097 | .6516 | .6859 | .4858 | .7202 | .823 |
| 4 | 1.0631 | .9945 | .7202 | .7716 | .503 | .8573 | .8916 |
| 5 | 1.286 | 1.1336 | .7888 | .8573 | .503 | 1.0117 | 1.0802 |
| 6 | 1.5604 | 1.1603 | .8573 | .9602 | .503 | 1.166 | 1.2346 |
| 7 | 1.869 | 1.2955 | .9259 | .9602 | .5668 | 1.6289 | 1.5432 |
| 8 | 2.0062 | 1.4575 | .9945 | .8916 | .5668 | 1.8519 | 1.7147 |
| 9 | 1.7833 | 1.4918 | .7888 | .823 | .4915 | 1.6804 | 1.6975 |
| 10 | .3239 | .5316 | 1.0288 | .9831 | 1.3375 | .5316 | .2429 |
| 11 | .2915 | .4458 | 1.7147 | 1.2955 | 1.5947 | | .3239 |
| 12 | .2429 | | 1.8004 | 1.3565 | 1.6461 | .3601 | .3239 |
| 13 | .2515 | | 1.7147 | 1.326 | 1.6118 | | .2429 |
| 14 | .2429 | .4287 | 1.7147 | 1.3108 | 1.5604 | | .2429 |
| 15 | .2429 | .4458 | 1.7147 | 1.3108 | 1.7318 | .4115 | .2429 |
| 16 | .2429 | .463 | 1.7147 | 1.1336 | 1.7318 | .4458 | .2515 |
| 17 | .3239 | .5658 | 1.5432 | 1.065 | 1.6975 | .5487 | .3563 |
| 18 | .4049 | .7888 | .6859 | .4858 | .6687 | .7888 | .4534 |
| 19 | .5668 | .8916 | .823 | .5668 | .823 | .9259 | .4858 |
| 20 | .5668 | .823 | .6859 | .6478 | .7202 | .7888 | .4915 |
| 21 | .503 | .7888 | .6859 | .6706 | .6859 | .7202 | .4858 |
| 22 | .3239 | .7545 | .6859 | .6706 | .6687 | .703 | .503 |
| 23 | .3239 | .7202 | .6173 | .4858 | .6859 | .6859 | .4858 |
| 24 | .7373 | .3239 | .7202 | .6173 | .503 | .703 | .6516 |
| **Max** | **2.0062** | **1.4918** | **1.8004** | **1.3565** | **1.7318** | **1.8519** | **1.7147** |
| **Min** | **.2429** | **.3239** | **.6173** | **.4858** | **.4858** | **.3601** | **.2429** |
| **Avg** | **.7480** | **.7931** | **1.0403** | **.8796** | **.9274** | **.8525** | **.6754** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214464 / 33 KV NIM SAKHAR**
**Feeder No / Name : 204 / 11KV EXPRESS MODERN ENGG. NON SHEDDABLE EXPRESS HV FEEDERS**
**Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0171 | .0166 | .0171 | .0171 | .0162 | .0171 | .0171 |
| 2 | .0171 | .017 | .0171 | .0171 | .0162 | .0171 | .0171 |
| 3 | .0171 | .016 | .0171 | .0171 | .0162 | .0171 | .0171 |
| 4 | .0171 | .0162 | .0171 | .0171 | .0162 | .0171 | .0171 |
| 5 | .0171 | .0162 | .0171 | .0171 | .0162 | .0171 | .0171 |
| 6 | .0171 | .0162 | .0171 | .0171 | .0162 | .0171 | .0171 |
| 7 | .0171 | .0164 | .0171 | .0171 | .0162 | .0171 | .0171 |
| 8 | .0171 | .0162 | .0171 | .0171 | .0162 | .0171 | .0171 |
| 9 | .0171 | .0166 | .0171 | .0171 | .0164 | .0343 | .0171 |
| 10 | .0162 | .0171 | .0171 | .0162 | .0171 | .0171 | .0162 |
| 11 | .0162 | .0171 | .0171 | .0168 | .0171 | .0171 | .0162 |
| 12 | .0162 | .0171 | .0171 | .0164 | .0171 | .0171 | .0162 |
| 13 | .0162 | .0171 | .0171 | .0162 | .0171 | .0171 | .016 |
| 14 | .0166 | .0171 | .0171 | .0164 | .0171 | .0171 | .0162 |
| 15 | .0162 | .0171 | .0171 | .0164 | .0171 | .0343 | .0162 |
| 16 | .0162 | .0171 | .0171 | .0164 | .0171 | .0171 | .0168 |
| 17 | .0162 | .0171 | .0343 | .0162 | .0171 | .0171 | .0162 |
| 18 | .0162 | .0171 | .0171 | .0164 | .0171 | .0171 | .0162 |
| 19 | .0162 | .0171 | .0171 | .0162 | .0171 | .0171 | .0162 |
| 20 | .0162 | .0171 | .0171 | .0162 | .6344 | .0171 | .0162 |
| 21 | .0162 | .0171 | .0171 | .0166 | .0171 | .0171 | .0162 |
| 22 | .0162 | .0171 | .0171 | .0162 | .0171 | .0171 | .0162 |
| 23 | .0162 | .0171 | .0171 | .0162 | | .0171 | .0162 |
| 24 | .0171 | .0162 | .0171 | .0171 | .0164 | .0171 | .0171 |
| **Max** | **.0171** | **.0171** | **.0343** | **.0171** | **.6344** | **.0343** | **.0171** |
| **Min** | **.0162** | **.016** | **.0171** | **.0162** | **.0162** | **.0171** | **.016** |
| **Avg** | **.0166** | **.0168** | **.0178** | **.0167** | **.0436** | **.0185** | **.0166** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214464 / 33 KV NIM SAKHAR**
**Feeder No / Name : 205 / 11KV SARAFWADI 2** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3258 | .3391 | .3258 | .3086 | .3239 | .3429 | .3772 |
| 2 | .3258 | .4268 | .4458 | .3429 | | .3258 | .3772 |
| 3 | .3429 | .017 | .5658 | .3429 | .5868 | .3086 | .3944 |
| 4 | .3944 | .4049 | .6859 | .4287 | .5668 | .463 | .4458 |
| 5 | .5658 | .4973 | .8059 | .6001 | .6706 | .6173 | .6173 |
| 6 | .7545 | .5668 | .583 | .8573 | 1.1336 | .7716 | .8402 |
| 7 | .8916 | .8097 | 1.046 | 1.3203 | 1.1822 | .9431 | .9774 |
| 8 | .8573 | .663 | | 1.4918 | 1.1736 | .8059 | .8745 |
| 9 | | .6154 | 1.2517 | 1.4746 | 1.2308 | .6001 | .703 |
| 10 | .3887 | .6516 | .4801 | .4049 | .5316 | .9602 | .9069 |
| 11 | | 1.0288 | .3086 | .3239 | .3601 | 1.2174 | .8907 |
| 12 | | 1.0631 | | .1966 | .2915 | 1.166 | .9878 |
| 13 | | 1.046 | | .1966 | .2743 | 1.3032 | .8097 |
| 14 | | 1.0288 | | .2294 | .2572 | 1.3032 | .8097 |
| 15 | .9945 | 1.0631 | .3429 | .2347 | .2743 | 1.3546 | .8097 |
| 16 | 1.0526 | 1.0802 | .3429 | .3113 | .2915 | 1.3032 | .664 |
| 17 | .9717 | 1.0974 | .4801 | .426 | .4458 | 1.1831 | .6478 |
| 18 | .6802 | .5316 | .6516 | .6964 | .6687 | .6516 | .6478 |
| 19 | .6478 | .7716 | .703 | .6478 | .8059 | .7373 | .6478 |
| 20 | .6874 | .583 | .5144 | .6274 | .6344 | .583 | .6478 |
| 21 | .5801 | .5144 | .463 | .4915 | .5144 | .5316 | .4858 |
| 22 | .4973 | .4458 | .3601 | .503 | .3944 | .4973 | .4858 |
| 23 | .4144 | .3772 | .3086 | .4191 | .3772 | .4287 | .3239 |
| 24 | .3258 | .3401 | .3429 | .3086 | .3401 | .3601 | .3772 |
| **Max** | **1.0526** | **1.0974** | **1.2517** | **1.4918** | **1.2308** | **1.3546** | **.9878** |
| **Min** | **.3258** | **.017** | **.3086** | **.1966** | **.2572** | **.3086** | **.3239** |
| **Avg** | **.6157** | **.6651** | **.5504** | **.5494** | **.5796** | **.7816** | **.6562** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214464 / 33 KV NIM SAKHAR**
**Feeder No / Name : 206 / 11KV KHOROCHI- 2 SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6173 | .6478 | .703 | .6859 | .6706 | .6859 | .703 |
| 2 | .6516 | .7459 | .6687 | .6859 | .6706 | .6516 | .7545 |
| 3 | .6516 | .8097 | .6516 | .7716 | .6478 | .6687 | .7545 |
| 4 | .703 | .9717 | .7373 | .9431 | .8097 | .8573 | .823 |
| 5 | .9945 | .9717 | .823 | 1.0288 | 1.004 | 1.0631 | 1.0117 |
| 6 | 1.2346 | 1.1603 | .9088 | 1.2003 | 1.0526 | 1.2689 | 1.166 |
| 7 | 1.4918 | 1.3765 | .9945 | 1.2003 | 1.1336 | 1.4746 | 1.3203 |
| 8 | 1.6289 | 1.5089 | 1.4232 | 1.1831 | 1.2146 | 1.5261 | 1.4746 |
| 9 | 1.286 | 1.4575 | 1.2003 | 1.0802 | 1.2631 | 1.2689 | 1.3717 |
| 10 | .6478 | .7545 | 1.2174 | 1.3763 | 1.3032 | .703 | .7287 |
| 11 | | .5658 | 1.4232 | 1.6194 | 1.5604 | .5487 | .4049 |
| 12 | .421 | .4973 | 1.3889 | 1.668 | 1.5604 | .4115 | .3725 |
| 13 | .4144 | | 1.5089 | 1.7814 | 1.5261 | .3944 | .4049 |
| 14 | .4049 | .4973 | 1.5089 | 1.7101 | 1.4575 | .4287 | .4049 |
| 15 | .4049 | .5487 | 1.5089 | 1.6876 | 1.4403 | .463 | .3353 |
| 16 | .4372 | .5658 | 1.5089 | 1.4413 | 1.406 | .463 | .3239 |
| 17 | .5668 | .6687 | 1.406 | 1.2955 | 1.3889 | .583 | .7287 |
| 18 | 1.0526 | 1.046 | 1.0288 | 1.0688 | .9602 | 1.0288 | .9878 |
| 19 | 1.0774 | 1.5261 | 1.2174 | .9831 | 1.3203 | 1.2174 | .9717 |
| 20 | 1.094 | 1.2517 | 1.0288 | .9878 | 1.1831 | 1.166 | .9717 |
| 21 | .9717 | 1.0631 | .9431 | .8383 | .9945 | .9602 | .9393 |
| 22 | .8097 | .8916 | .7545 | .6706 | .8059 | .8745 | .8097 |
| 23 | .6478 | | .6859 | .6706 | .7545 | .8059 | .6478 |
| 24 | .6173 | .5992 | .7202 | .6859 | .6539 | .703 | .703 |
| **Max** | **1.6289** | **1.5261** | **1.5089** | **1.7814** | **1.5604** | **1.5261** | **1.4746** |
| **Min** | **.4049** | **.4973** | **.6516** | **.6706** | **.6478** | **.3944** | **.3239** |
| **Avg** | **.8186** | **.9148** | **1.0817** | **1.1360** | **1.1159** | **.8423** | **.7964** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214479 / 33/11kv kalas sub-station**
**Feeder No / Name : 201 / 11KV PILEWADI AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1638 | .1638 | .1311 | .1311 | .1311 | .1475 | .1638 |
| 2 | .1638 | .1638 | .1475 | .1311 | .1475 | .1311 | .1802 |
| 3 | .1966 | .1638 | .1638 | .1475 | .1638 | .1475 | .1966 |
| 4 | .2294 | .1802 | .1802 | .1802 | .1802 | .1638 | .213 |
| 5 | .2458 | .1966 | .2294 | .213 | .213 | .2458 | .2458 |
| 6 | .2949 | .3113 | .3113 | .3113 | .2785 | .3113 | .3277 |
| 7 | .3768 | | .3768 | .3113 | .3441 | .3932 | .3932 |
| 8 | .3441 | .3605 | 1.5074 | 1.1797 | 1.3927 | .3605 | .4096 |
| 9 | .2949 | .12 | 1.6549 | 1.448 | 1.6549 | .2785 | .2458 |
| 10 | .213 | .1829 | 1.6712 | 1.5699 | 1.6221 | .2294 | .1966 |
| 11 | .1475 | .1372 | 1.7368 | 1.5699 | 1.5729 | .1638 | .1966 |
| 12 | .1147 | .1524 | 1.5893 | 1.5242 | 1.5402 | .1638 | .1638 |
| 13 | .1638 | .12 | 1.5729 | 1.4937 | 1.5074 | .1638 | |
| 14 | .1311 | .1219 | 1.4746 | 1.4327 | 1.4746 | .1311 | .1638 |
| 15 | .0983 | .1372 | 1.491 | 1.2955 | 1.3599 | .1311 | .1638 |
| 16 | 1.8679 | 1.7071 | .1147 | .1067 | .1311 | 1.5729 | 1.3927 |
| 17 | 1.9334 | | .1475 | | .1475 | 1.6385 | 1.5402 |
| 18 | 1.8842 | | .1802 | | .1966 | 1.5402 | 1.4419 |
| 19 | 1.6057 | | .2458 | .2439 | .2458 | 1.3435 | 1.3108 |
| 20 | 1.4419 | | .2294 | .2439 | .2622 | 1.2289 | 1.1797 |
| 21 | 1.2452 | | .1638 | .2439 | .2294 | 1.0978 | .9175 |
| 22 | 1.1961 | | .1475 | .1677 | .1638 | 1.0159 | .7701 |
| 23 | | | .1311 | .1219 | | .9667 | .7701 |
| 24 | .1638 | .1638 | .4817 | .1311 | .1219 | .1475 | .1638 |
| **Max** | **1.9334** | **1.7071** | **1.7368** | **1.5699** | **1.6549** | **1.6385** | **1.5402** |
| **Min** | **.0983** | **.12** | **.1147** | **.1067** | **.1219** | **.1311** | **.1638** |
| **Avg** | **.6312** | **.2739** | **.6700** | **.6454** | **.6557** | **.5714** | **.5542** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214479 / 33/11kv kalas sub-station**
**Feeder No / Name : 202 / 11KV AKOLE AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5571 | .5312 | .2054 | .2054 | .1867 | .7842 | .7042 |
| 2 | .5571 | .5376 | .2241 | .2075 | .2075 | .7468 | .7362 |
| 3 | .5898 | .5693 | .2452 | .2075 | .2263 | .7468 | .8097 |
| 4 | .5898 | .5921 | .2614 | .2054 | .2427 | .7842 | .8848 |
| 5 | .6554 | .6241 | | .2241 | .2614 | .7287 | .9667 |
| 6 | .9145 | .6964 | .2614 | .2801 | .2614 | .7611 | 1.1336 |
| 7 | .8848 | .9667 | .2987 | .3206 | .2772 | .9831 | 1.3435 |
| 8 | .2561 | .3142 | .3174 | .2743 | .2772 | .2427 | .2801 |
| 9 | .2241 | .2134 | .2587 | .1829 | .2614 | .2427 | .1966 |
| 10 | .2054 | .1829 | .2378 | .1677 | .1867 | .2054 | .1638 |
| 11 | .1478 | .1524 | .168 | .1219 | .1494 | .1494 | .1829 |
| 12 | .1109 | .1524 | .1494 | .1219 | .1494 | .1494 | .1829 |
| 13 | | .0914 | .1494 | .1067 | .112 | .1307 | .1829 |
| 14 | | .0914 | .1307 | .0914 | .112 | .1307 | .1829 |
| 15 | | .1067 | .112 | .1219 | .112 | .112 | .1829 |
| 16 | | | 1.8299 | 1.5851 | 1.4582 | .112 | .1311 |
| 17 | | | 1.6842 | 1.5699 | 1.5565 | .1132 | .1463 |
| 18 | .1848 | | 1.7652 | 1.448 | 1.278 | .2054 | .1886 |
| 19 | .2614 | | 1.5223 | 1.2346 | .9995 | .2402 | .2195 |
| 20 | .2241 | | 1.2631 | 1.0974 | .9503 | .2218 | .2195 |
| 21 | .1867 | | 1.0936 | .9907 | .852 | .2054 | .2012 |
| 22 | .1867 | | 1.1203 | .9602 | .7935 | .1848 | .1829 |
| 23 | .1886 | | 1.1012 | .9145 | | .1867 | .1848 |
| 24 | .5571 | .5312 | .2054 | .2241 | .1696 | .8029 | .7042 |
| **Max** | **.9145** | **.9667** | **1.8299** | **1.5851** | **1.5565** | **.9831** | **1.3435** |
| **Min** | **.1109** | **.0914** | **.112** | **.0914** | **.112** | **.112** | **.1311** |
| **Avg** | **.3938** | **.3971** | **.6350** | **.5360** | **.4818** | **.3821** | **.4297** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214479 / 33/11kv kalas sub-station**
**Feeder No / Name : 203 / 11KV KALAS AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2622 | .3018 | .3018 | .3018 | .2987 | .2987 | .2641 |
| 2 | .2926 | .2987 | .4534 | .7186 | .7125 | .2987 | .3018 |
| 3 | .3292 | .2987 | .4696 | .7811 | .7773 | .3174 | |
| 4 | .3658 | .3142 | .6226 | .8539 | .8583 | .3361 | .3734 |
| 5 | .3605 | .3326 | .8192 | .9602 | 1.0526 | .3734 | .4108 |
| 6 | .4755 | .4805 | 1.0486 | 1.1336 | 1.2944 | .4108 | .4435 |
| 7 | .4755 | .5487 | 1.4746 | 1.6842 | 1.5729 | .4435 | .4435 |
| 8 | .4024 | .4435 | 1.9334 | 1.9433 | 1.8351 | .4481 | .4066 |
| 9 | .3326 | .2743 | 1.7814 | 2.0348 | 1.8679 | .4066 | .3292 |
| 10 | 1.1984 | 1.2803 | .2614 | .2439 | .2987 | 1.2452 | 1.3108 |
| 11 | 1.8461 | 1.6156 | .2241 | .1829 | .2801 | 1.8461 | 1.9662 |
| 12 | 2.1628 | 1.5851 | | .1829 | .2427 | 1.9662 | 1.9662 |
| 13 | 2.1628 | 1.4632 | | | .2241 | 1.9757 | 1.9334 |
| 14 | 2.0972 | 1.6461 | | | .1867 | 1.9989 | 1.8679 |
| 15 | 1.704 | 1.829 | .1867 | .1829 | .1494 | 1.9006 | 1.6385 |
| 16 | 1.9334 | 2.0576 | .2241 | .1219 | .1494 | 1.8351 | 1.5729 |
| 17 | 1.8679 | 1.7974 | .2614 | .1524 | .1494 | 1.6712 | 1.7924 |
| 18 | .3326 | | .3696 | .1829 | .2801 | .2614 | .3658 |
| 19 | .4108 | | .4435 | .3048 | .3361 | .3696 | .3772 |
| 20 | .3361 | | .3696 | .2743 | .3361 | .2987 | .4024 |
| 21 | .3361 | | .3734 | .3086 | .2987 | | .3658 |
| 22 | .2987 | | .3395 | .2439 | .2987 | .2957 | .3292 |
| 23 | .2987 | | .2987 | .2713 | | .2614 | .3142 |
| 24 | .2926 | .2987 | .2987 | .2987 | .2743 | .2987 | .2614 |
| **Max** | **2.1628** | **2.0576** | **1.9334** | **2.0348** | **1.8679** | **1.9989** | **1.9662** |
| **Min** | **.2622** | **.2743** | **.1867** | **.1219** | **.1494** | **.2614** | **.2614** |
| **Avg** | **.8573** | **.937** | **.5979** | **.6074** | **.5989** | **.8503** | **.8451** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214479 / 33/11kv kalas sub-station**
**Feeder No / Name : 204 / 11KV KALAS GAOTHAN GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4024 | .3772 | .3961 | .3772 | .4108 | .3547 | .415 |
| 2 | .3841 | .3961 | .415 | .415 | .4338 | .3547 | .4338 |
| 3 | .3841 | .415 | .4338 | .4527 | .4715 | .3734 | .4527 |
| 4 | | .4481 | .4668 | .5093 | .5093 | .4294 | .4715 |
| 5 | | .4854 | .5228 | .5601 | .5228 | .4668 | .5041 |
| 6 | .3605 | .5544 | .6348 | .6908 | .5601 | .5415 | .5975 |
| 7 | .439 | .6468 | .6722 | .7392 | .5847 | .6348 | .6348 |
| 8 | .3658 | .5975 | .6161 | .7023 | .6468 | .5601 | .6838 |
| 9 | .5415 | .442 | .4805 | .442 | .5041 | .4668 | .4588 |
| 10 | .3921 | .3258 | .4668 | .381 | .4108 | .3921 | .3277 |
| 11 | .2427 | .1981 | .3547 | .3506 | .3547 | .2801 | .2622 |
| 12 | .112 | .2401 | .2801 | .3048 | .2801 | .2427 | .2622 |
| 13 | .132 | .1715 | .2614 | .1981 | .2229 | .2241 | .2561 |
| 14 | .132 | .1715 | .2054 | .1981 | .2241 | .2054 | .2561 |
| 15 | .1307 | .1715 | .2241 | .2286 | .112 | .2241 | .2561 |
| 16 | .1307 | .2229 | .2614 | .2591 | .1494 | .1698 | .2561 |
| 17 | .1494 | .2713 | .2987 | .4115 | .1867 | .3361 | .3475 |
| 18 | .4668 | | .4294 | .4115 | .2241 | .5228 | .439 |
| 19 | .5975 | | .6348 | .4725 | .3734 | .6161 | .5281 |
| 20 | .5281 | | .5788 | .5121 | .4854 | .5415 | .5658 |
| 21 | .4668 | | .5093 | .4239 | .4481 | .5041 | .5121 |
| 22 | .4338 | | .4481 | .4239 | .3547 | .4854 | .439 |
| 23 | .3961 | | .415 | .407 | | .4668 | .4481 |
| 24 | .4108 | .3772 | .3961 | .3772 | .373 | .3547 | .4108 |
| **Max** | **.5975** | **.6468** | **.6722** | **.7392** | **.6468** | **.6348** | **.6838** |
| **Min** | **.112** | **.1715** | **.2054** | **.1981** | **.112** | **.1698** | **.2561** |
| **Avg** | **.3454** | **.3618** | **.4334** | **.4270** | **.3845** | **.4062** | **.4258** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214479 / 33/11kv kalas sub-station**
**Feeder No / Name : 205 / 11KV AKOLE-2 AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2926 | .3018 | .3018 | .2427 | .2987 | .2987 | .3018 |
| 2 | .2683 | 1.1873 | .3206 | .2263 | .3018 | 1.2696 | 1.0936 |
| 3 | 1.1797 | 1.2186 | .3174 | .2263 | .3018 | 1.166 | 1.1248 |
| 4 | 1.2452 | 1.2809 | .3361 | .2452 | .2987 | 1.2146 | 1.1843 |
| 5 | 1.3108 | 1.3763 | .3361 | .2614 | .3142 | 1.2955 | 1.2308 |
| 6 | 1.5074 | 1.5074 | .3361 | .3361 | .3511 | 1.3279 | 1.2955 |
| 7 | 1.6385 | 1.8679 | .3734 | .3696 | .4066 | 1.7166 | 1.6057 |
| 8 | 1.9334 | 2.1628 | .3326 | .3696 | .4108 | 1.9433 | 1.9662 |
| 9 | 1.8461 | 1.9204 | .2957 | .2591 | .3734 | 1.7814 | 1.7695 |
| 10 | .2614 | .1829 | 1.4575 | 1.4632 | 1.5402 | .2614 | .2458 |
| 11 | .1848 | .1524 | 1.9757 | 1.0479 | 2.0645 | .1867 | .2195 |
| 12 | .1478 | | 2.2348 | 1.6156 | 2.0481 | .2241 | .2195 |
| 13 | | .1219 | 2.2024 | 1.989 | 1.9662 | .2241 | .2195 |
| 14 | | .1524 | 2.2672 | 1.9204 | 1.9006 | .2241 | .1829 |
| 15 | | .1524 | 2.1628 | 1.7985 | 1.8023 | .1848 | .1829 |
| 16 | | .1524 | 2.0485 | 1.829 | | | .1638 |
| 17 | | .2035 | 1.8785 | 1.8595 | | .2614 | .2743 |
| 18 | .3696 | | .3326 | .2134 | | .3696 | .3658 |
| 19 | .4066 | | .4066 | .2743 | .2614 | .4108 | .3605 |
| 20 | .2987 | | .3326 | .2439 | .3361 | .3734 | .3277 |
| 21 | .2987 | | .3361 | .2713 | .3734 | .3361 | .2949 |
| 22 | .2987 | | .3018 | .2713 | .2949 | .2957 | .3109 |
| 23 | .2987 | | .2614 | .2439 | | .2957 | .3292 |
| 24 | .3475 | .2987 | .8535 | .2614 | .2743 | .2915 | .2987 |
| **Max** | **1.9334** | **2.1628** | **2.2672** | **1.989** | **2.0645** | **1.9433** | **1.9662** |
| **Min** | **.1478** | **.1219** | **.2614** | **.2134** | **.2614** | **.1848** | **.1638** |
| **Avg** | **.7439** | **.8376** | **.9167** | **.7433** | **.7960** | **.6936** | **.6487** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214479 / 33/11kv kalas sub-station**
**Feeder No / Name : 206 / 11KV BORI-BIRANGUDWADI AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4915 | .4915 | | | .9667 | .5243 | .4588 |
| 2 | .6226 | .4915 | | | .9995 | .5079 | .4752 |
| 3 | .5243 | .5079 | | | 1.0159 | .5079 | .4915 |
| 4 | .5571 | .5243 | | | 1.0322 | .5243 | .5079 |
| 5 | .5735 | .5407 | | | 1.1469 | .5407 | .5407 |
| 6 | .5735 | .5407 | | | 1.3927 | .5407 | .5079 |
| 7 | .5407 | .5079 | | | 1.9989 | .5243 | .4915 |
| 8 | 1.5729 | 1.5402 | | | .4588 | 1.6549 | 1.491 |
| 9 | 1.7695 | | | .5335 | .5407 | 2.0809 | 1.8679 |
| 10 | 2.13 | | | .4725 | .5975 | 2.1464 | 1.5729 |
| 11 | 1.9498 | | | .4115 | .5407 | 2.1464 | 1.4746 |
| 12 | 1.917 | | | .4268 | .5407 | 1.9826 | 1.4746 |
| 13 | 1.9334 | | | .4268 | .5243 | 1.9662 | 1.4419 |
| 14 | 1.8842 | | | .4115 | .4915 | 2.0317 | 1.4091 |
| 15 | 1.7532 | | | .5256 | .4915 | 1.8187 | 1.3763 |
| 16 | .2294 | | | .4572 | .4588 | .3605 | .2294 |
| 17 | .3768 | | | .4725 | .4752 | .3768 | .4915 |
| 18 | .3768 | | | .442 | .4915 | .4752 | .3441 |
| 19 | .4915 | | | .4877 | .5243 | .5243 | .4588 |
| 20 | .4752 | | | .4572 | .5735 | .4588 | .4915 |
| 21 | .4424 | | | .442 | .5243 | .4752 | .4588 |
| 22 | .4752 | | | .442 | .5079 | .4588 | .426 |
| 23 | .547 | | | .4268 | | .4588 | .3932 |
| 24 | .4915 | .4915 | .3506 | | .884 | .5243 | .4588 |
| **Max** | **2.13** | **1.5402** | **.3506** | **.5335** | **1.9989** | **2.1464** | **1.8679** |
| **Min** | **.2294** | **.4915** | **.3506** | **.4115** | **.4588** | **.3605** | **.2294** |
| **Avg** | **.9458** | **.6262** | **.3506** | **.4557** | **.7469** | **.9838** | **.8056** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214479 / 33/11kv kalas sub-station**
**Feeder No / Name : 207 / 11KV JAYHIND EXPRESS FEEDER Feeder KV- 11 / OUTGOING NON SHEDDABLE EXPRESS HV FEEDERS (CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 29-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8 | .1463 | | | | | |
| 9 | .1867 | | | .2054 | .1848 | |
| 10 | .168 | .1494 | .0137 | .1867 | .1867 | |
| 11 | .168 | .1307 | .0137 | .168 | .1698 | |
| 12 | .1494 | | | .168 | .2241 | |
| 13 | .0754 | .112 | .0107 | .1307 | .1307 | |
| 14 | .1494 | .1494 | .0091 | .168 | .168 | |
| 15 | .0739 | .1698 | .0107 | .1867 | .2033 | |
| 16 | .1494 | .1867 | .0122 | .1867 | .1867 | |
| 17 | .112 | .1698 | .0076 | .168 | .1646 | |
| 18 | .1867 | .1494 | .1067 | .1867 | .1848 | |
| 19 | .1494 | .1494 | .0122 | .1867 | .1663 | .1463 |
| 20 | | .1494 | .0107 | .1494 | .0934 | |
| 21 | | | | .112 | | |
| 22 | | | .0457 | | | |
| **Max** | **.1867** | **.1867** | **.1067** | **.2054** | **.2241** | **.1463** |
| **Min** | **.0739** | **.112** | **.0076** | **.112** | **.0934** | **.1463** |
| **Avg** | **.1429** | **.1516** | **.023** | **.1695** | **.1719** | **.1463** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214487 / 33 KV Sansar**
**Feeder No / Name : 201 / 11KV DHEKALEWADI AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3688 | | .443 | | .3898 | | .443 |
| 2 | | | | | .7209 | | .4607 |
| 3 | .4694 | | 1.0059 | | .8048 | | .4607 |
| 4 | .5365 | | 1.0898 | | 1.1568 | | .4961 |
| 5 | .6371 | | 1.3245 | | 1.5089 | | .6024 |
| 6 | .788 | .8505 | 1.5089 | 1.4083 | 1.6933 | .8328 | .7442 |
| 7 | .8383 | .8682 | 1.7939 | 1.6933 | 1.861 | .8859 | .8859 |
| 8 | .6539 | .7442 | 1.9448 | 1.9113 | 1.8945 | .7655 | .7973 |
| 9 | .5533 | .6379 | 1.8778 | 1.8275 | 1.9113 | .5493 | .567 |
| 10 | 1.5592 | 1.6263 | .5138 | .3721 | .4961 | 1.2071 | 1.6095 |
| 11 | 1.8275 | 1.7939 | .4252 | .3189 | .4075 | 1.6263 | 1.7541 |
| 12 | 1.8442 | 1.9784 | .3366 | .2835 | .3544 | 1.6766 | 1.8267 |
| 13 | 1.9448 | 1.861 | .3012 | .2481 | .2835 | 1.6598 | 1.7187 |
| 14 | 1.9448 | 1.8275 | .2658 | .2658 | .2835 | | 1.6655 |
| 15 | 1.8442 | 1.7604 | .2126 | .3189 | .2835 | 1.5927 | 1.5769 |
| 16 | 1.7269 | 1.7101 | .2126 | .4075 | .3721 | 1.5089 | 1.5249 |
| 17 | 1.7269 | 1.6933 | .3012 | .4784 | .4784 | 1.6095 | 1.5592 |
| 18 | .5316 | .6556 | .5847 | .6379 | .6201 | .6201 | .4424 |
| 19 | .6379 | .6379 | | .6733 | .6556 | .6733 | .6133 |
| 20 | | .6024 | | .6379 | .6024 | .6201 | .5636 |
| 21 | | .6024 | | .5847 | .567 | .6024 | .5304 |
| 22 | .5316 | .5493 | | .5847 | .5316 | .567 | .503 |
| 23 | .443 | .5316 | | .5316 | .5138 | | .503 |
| 24 | .3856 | .443 | .8467 | .4075 | .4607 | .4961 | .4784 |
| **Max** | **1.9448** | **1.9784** | **1.9448** | **1.9113** | **1.9113** | **1.6766** | **1.8267** |
| **Min** | **.3688** | **.443** | **.2126** | **.2481** | **.2835** | **.4961** | **.4424** |
| **Avg** | **1.0378** | **1.1249** | **.8327** | **.7153** | **.7855** | **1.0290** | **.9303** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214487 / 33 KV Sansar**
**Feeder No / Name : 202 / KRUSHNA MANDIR GFSS GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1132 | | .0754 | | .0754 | | .0943 |
| 2 | .1132 | | .0754 | | .0566 | | .0943 |
| 3 | .0943 | | .0943 | | .1132 | | .132 |
| 4 | .1132 | | .1132 | | .1886 | | .1886 |
| 5 | .1698 | | .1886 | | .2263 | | .2401 |
| 6 | .3018 | .2641 | .2641 | .2075 | .2829 | .3018 | .2829 |
| 7 | .3206 | | .3395 | .2452 | .2915 | .2829 | .3018 |
| 8 | .3018 | .2263 | .3395 | .2075 | .2829 | .2263 | .3018 |
| 9 | .2452 | .1886 | .2263 | .1886 | .2641 | | .2263 |
| 10 | .1886 | .1886 | .1886 | .1698 | .2075 | .1698 | .1698 |
| 11 | .132 | .1698 | .1698 | .132 | .1698 | .132 | .1334 |
| 12 | .1132 | .132 | .132 | .1132 | .132 | .0943 | .1143 |
| 13 | .1132 | .1509 | .1132 | .1132 | .1132 | .1132 | .1143 |
| 14 | .0943 | .1132 | .1132 | .0754 | .1132 | .0943 | .1143 |
| 15 | .1132 | .0943 | .0943 | .0754 | .1132 | .0943 | .1143 |
| 16 | .0943 | .0943 | .1132 | .1132 | .132 | .1132 | .1334 |
| 17 | .132 | .132 | .132 | .1509 | .132 | .12 | .1524 |
| 18 | .1886 | .2263 | .1886 | .2075 | .1698 | .2452 | .2286 |
| 19 | .2452 | .2263 | .2075 | .2075 | .2452 | .2452 | .2096 |
| 20 | .2075 | .1886 | | .1886 | .2263 | .1886 | .1905 |
| 21 | .1698 | .1886 | | .1509 | .1886 | .1698 | .1715 |
| 22 | .132 | .1698 | | .132 | .1698 | .1509 | .1334 |
| 23 | .0943 | .1698 | | .0943 | .132 | .1029 | .1143 |
| 24 | .132 | .0943 | .1132 | .1132 | .0754 | .1132 | .0943 |
| **Max** | **.3206** | **.2641** | **.3395** | **.2452** | **.2915** | **.3018** | **.3018** |
| **Min** | **.0943** | **.0943** | **.0754** | **.0754** | **.0566** | **.0943** | **.0943** |
| **Avg** | **.1635** | **.1677** | **.1641** | **.1519** | **.1709** | **.1643** | **.1688** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214487 / 33 KV Sansar**
**Feeder No / Name : 203 / 11KV BELWADI AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2241 | | .2507 | | .2865 | | .3077 |
| 2 | .4801 | | .2328 | | .2865 | | .8322 |
| 3 | .5731 | | .2328 | | .3224 | | |
| 4 | .6268 | | .2865 | | .3403 | | |
| 5 | .8954 | | .3224 | | .3582 | | |
| 6 | 1.1641 | 1.0722 | .3582 | | .394 | .2561 | |
| 7 | 1.6118 | 1.7124 | .4477 | .4835 | .4298 | .2721 | .6882 |
| 8 | 1.8804 | 1.8884 | .4298 | .4298 | .4525 | .2561 | .9442 |
| 9 | 1.8604 | 1.5524 | .3582 | .3224 | .3403 | 1.1043 | .9922 |
| 10 | .2328 | .2149 | 1.3253 | 1.5684 | 1.4883 | .2149 | .1267 |
| 11 | .1433 | .1612 | 1.5043 | 1.9204 | 1.9685 | .1791 | .1134 |
| 12 | .1075 | .1612 | 1.8404 | 2.0165 | 2.0485 | .1612 | 1.1104 |
| 13 | .1254 | .1433 | 2.1125 | | 2.0325 | .1433 | 1.1641 |
| 14 | .1075 | .1433 | 2.0645 | 1.2643 | 1.9784 | .1433 | .1296 |
| 15 | | .1612 | 2.0165 | 1.5203 | 1.8244 | .1433 | .16 |
| 16 | | .1612 | 1.8724 | 1.7764 | 1.7284 | .1433 | .16 |
| 17 | .197 | | 1.7604 | 1.8084 | 1.5844 | .9922 | .176 |
| 18 | .3045 | .2865 | | .3403 | .3224 | .3224 | .3041 |
| 19 | .3761 | .3761 | .3361 | .3582 | .3403 | .3801 | .3239 |
| 20 | .3403 | .3045 | | .3224 | .3224 | .3224 | .3041 |
| 21 | .3045 | .3045 | | .3045 | .3403 | .3224 | .2881 |
| 22 | .2865 | .2865 | | .3045 | .3224 | .3224 | .2881 |
| 23 | .2686 | .2865 | | .2865 | .3045 | .3045 | .2721 |
| 24 | .2241 | .2686 | .2686 | .2686 | .2865 | .2865 | .3224 |
| **Max** | **1.8804** | **1.8884** | **2.1125** | **2.0165** | **2.0485** | **1.1043** | **1.1641** |
| **Min** | **.1075** | **.1433** | **.2328** | **.2686** | **.2865** | **.1433** | **.1134** |
| **Avg** | **.5607** | **.5269** | **.9484** | **.8997** | **.8376** | **.3300** | **.4504** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214487 / 33 KV Sansar**
**Feeder No / Name : 204 / 11KV BORI AG** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .056 | | .0354 | | .0373 | | .0373 |
| 2 | .2481 | | .0354 | | .0373 | | .4075 |
| 3 | .2835 | | .0373 | | .056 | | .4252 |
| 4 | .3189 | | .056 | | .056 | | .4607 |
| 5 | .3544 | | .056 | | .0747 | | .5138 |
| 6 | .4784 | .3721 | .0747 | .0934 | .0934 | .4607 | .5493 |
| 7 | .5847 | .4607 | .0934 | | .0934 | .5493 | .567 |
| 8 | .567 | .5316 | .0934 | .112 | .0747 | .6201 | .5847 |
| 9 | .5493 | .567 | .0747 | .0747 | .0934 | | .6024 |
| 10 | .0747 | .0747 | .5493 | .6201 | .567 | .0934 | .056 |
| 11 | .0747 | .056 | .6379 | .6733 | .7973 | .0747 | .056 |
| 12 | .0747 | .056 | .7265 | .7265 | .7796 | .0747 | .0747 |
| 13 | .056 | .056 | .7442 | .7442 | .8328 | .0747 | .0747 |
| 14 | .056 | .056 | .7087 | .7796 | .7796 | .056 | .0747 |
| 15 | .0373 | .5601 | .6556 | .7973 | .6733 | .056 | .056 |
| 16 | .0373 | .056 | .6733 | .7947 | .6733 | .0747 | .056 |
| 17 | .056 | .056 | | .7762 | .6556 | .0747 | .0554 |
| 18 | .0747 | .0747 | .056 | .0532 | .056 | .0747 | .0554 |
| 19 | .0747 | .0747 | | .056 | .0934 | .0747 | .056 |
| 20 | | .056 | | 1.7364 | .0747 | .056 | .056 |
| 21 | | .056 | | .056 | .056 | .056 | .056 |
| 22 | .0747 | .056 | | .056 | .056 | .056 | .0373 |
| 23 | .056 | .056 | | .0373 | .056 | .0373 | .0373 |
| 24 | .056 | .056 | .0354 | .056 | .0373 | .056 | .0373 |
| **Max** | **.5847** | **.567** | **.7442** | **1.7364** | **.8328** | **.6201** | **.6024** |
| **Min** | **.0373** | **.056** | **.0354** | **.0373** | **.0373** | **.0373** | **.0373** |
| **Avg** | **.1929** | **.1753** | **.2968** | **.4579** | **.2835** | **.1455** | **.2078** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214487 / 33 KV Sansar**
**Feeder No / Name : 205 / 11KV SANASAR GAOTHAN GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7023 | | .499 | | .5359 | | .5729 |
| 2 | .6653 | | .5175 | | .5359 | | .5914 |
| 3 | .7207 | | .5544 | | .5729 | | .6653 |
| 4 | .7762 | | .6099 | | .6653 | | .7762 |
| 5 | .8871 | | .7207 | | .7947 | | .9431 |
| 6 | 1.386 | 1.2012 | .8871 | 1.0349 | .961 | 1.3121 | 1.0185 |
| 7 | 1.2012 | 1.1458 | 1.0534 | 1.0349 | 1.0903 | 1.0903 | 1.0562 |
| 8 | 1.0164 | 1.0719 | .9979 | .9055 | .961 | 1.2567 | 1.1458 |
| 9 | 1.0349 | .924 | 1.0164 | .7762 | 1.0164 | | .7392 |
| 10 | .7762 | .7577 | .8131 | .5914 | .8871 | .5729 | .7023 |
| 11 | .6099 | | .6653 | .6283 | .6468 | .462 | .6099 |
| 12 | .5544 | .2957 | .5359 | .5175 | .5544 | .4066 | .5175 |
| 13 | .499 | .462 | .4435 | .4435 | .4435 | .3511 | .499 |
| 14 | .499 | .462 | .4435 | .4251 | .4066 | .462 | .4805 |
| 15 | .4435 | .4805 | .4251 | .4805 | .4805 | .5544 | .4066 |
| 16 | .4435 | .499 | .3142 | .5544 | .5359 | .3326 | .5415 |
| 17 | .6653 | .6838 | .4805 | .6283 | .5359 | .499 | .7023 |
| 18 | 1.0164 | .924 | .7762 | .8316 | .7947 | .7947 | .8316 |
| 19 | 1.1458 | .9979 | .8501 | 1.0534 | .8316 | .9055 | .9795 |
| 20 | | .8686 | | .924 | .7947 | .056 | .9055 |
| 21 | .8316 | .8686 | | .7762 | .5359 | .6468 | .8131 |
| 22 | .7392 | .8316 | | .7392 | .5175 | .6283 | .7392 |
| 23 | .6283 | .7577 | | .6838 | .499 | .6099 | .6838 |
| 24 | .7023 | .6099 | .6468 | .3696 | .5914 | .5359 | .5788 |
| **Max** | **1.386** | **1.2012** | **1.0534** | **1.0534** | **1.0903** | **1.3121** | **1.1458** |
| **Min** | **.4435** | **.2957** | **.3142** | **.3696** | **.4066** | **.056** | **.4066** |
| **Avg** | **.7802** | **.7690** | **.6625** | **.7052** | **.6745** | **.6376** | **.7292** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214487 / 33 KV Sansar**
**Feeder No / Name : 206 / 11KV CHATRAPATI KARKHANA SINGLE PHASING**
**AG Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4572 | | .4458 | | .463 | | .463 |
| 2 | .4268 | | 1.0364 | | 1.0517 | | .3772 |
| 3 | .4115 | | 1.1736 | | 1.2498 | | .5144 |
| 4 | .4572 | | 1.2193 | | 1.3565 | | .7202 |
| 5 | .6097 | | 1.448 | | 1.448 | | 1.0288 |
| 6 | .8993 | .9774 | 1.7375 | 1.4632 | 1.5699 | 1.046 | 1.1145 |
| 7 | .9602 | 1.2174 | 1.9509 | 1.7985 | 1.7985 | 1.2689 | 1.166 |
| 8 | .9755 | 1.0631 | 1.9357 | 1.9509 | 1.6766 | 1.046 | 1.0288 |
| 9 | .7926 | .8402 | 1.9204 | 1.9204 | 1.8595 | | .8573 |
| 10 | 1.8747 | 1.7071 | .703 | .6173 | .6859 | 1.6004 | 1.768 |
| 11 | 1.9204 | 1.9814 | .6344 | .5144 | .583 | 1.829 | 2.073 |
| 12 | 2.0271 | 1.9662 | .4973 | .4801 | .5144 | 1.8138 | 2.0508 |
| 13 | 2.0424 | 1.9966 | .4458 | .463 | .463 | 1.9204 | 2.1033 |
| 14 | 1.9509 | 1.9814 | .4458 | | .4287 | 1.89 | 2.1325 |
| 15 | 2.0119 | 2.0119 | .4287 | .4801 | .4458 | 1.8747 | 2.0332 |
| 16 | 2.0271 | 1.9966 | .4801 | .5144 | .5316 | 2.3101 | 1.9631 |
| 17 | 1.9204 | 1.9814 | .5487 | | .5487 | | 1.893 |
| 18 | .8916 | .823 | .823 | .7888 | .7716 | .8745 | .7316 |
| 19 | .9431 | .9774 | .8573 | .8573 | .8059 | .9431 | .7926 |
| 20 | | .8402 | | .7545 | .7373 | .703 | .7011 |
| 21 | .703 | .8573 | | .6516 | .703 | .6859 | .5944 |
| 22 | .6173 | .7888 | | .6173 | .6687 | .6344 | .5639 |
| 23 | .5144 | .703 | | .6036 | .6001 | 5.9671 | .5335 |
| 24 | .4877 | .4801 | .6001 | .4801 | .5144 | .5316 | .5144 |
| **Max** | **2.0424** | **2.0119** | **1.9509** | **1.9509** | **1.8595** | **5.9671** | **2.1325** |
| **Min** | **.4115** | **.4801** | **.4287** | **.463** | **.4287** | **.5316** | **.3772** |
| **Avg** | **1.1270** | **1.3258** | **.9666** | **.8797** | **.8948** | **1.5846** | **1.1549** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214498 / 33/11 KV SHETFALGADE**
**Feeder No / Name : 201 / 11KV PIMPALE AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2058 | .2477 | .3048 | .2858 | .3086 | .2667 | .2667 |
| 2 | 1.3765 | 1.3765 | .3048 | .2858 | .3258 | 1.3441 | 1.3117 |
| 3 | 1.4089 | 1.4575 | .3048 | .2858 | .3429 | 1.4575 | 1.3765 |
| 4 | 1.4575 | 1.829 | .3239 | .3239 | .3429 | 1.8099 | 1.4089 |
| 5 | 1.5384 | 1.6194 | .3429 | .381 | .3772 | 1.6194 | 1.5061 |
| 6 | 1.7004 | 1.7004 | .4191 | .4763 | .4287 | 1.7652 | 1.5061 |
| 7 | 2.2348 | 1.9271 | .5144 | .5144 | .5144 | 2.0891 | 1.7652 |
| 8 | 2.4615 | 2.2348 | .5335 | .4382 | .4973 | 2.2672 | 2.0891 |
| 9 | 2.3805 | 2.1052 | .4572 | .4382 | .463 | 2.251 | 2.0891 |
| 10 | .2915 | .2858 | 2.4196 | 2.3624 | 2.1719 | .2477 | .2229 |
| 11 | .2858 | .2858 | 2.934 | 2.8578 | 1.9271 | .2477 | .2058 |
| 12 | .2858 | .3048 | 3.1245 | 2.4646 | 2.2348 | .2477 | .1543 |
| 13 | .1905 | .3048 | 3.1055 | 2.4326 | 2.4453 | .2667 | .1543 |
| 14 | .2286 | .2667 | 3.0864 | 2.4326 | 2.4615 | .2477 | .1372 |
| 15 | .2667 | .3048 | 3.0864 | 2.3045 | 2.4615 | .2477 | .1372 |
| 16 | .3048 | .3048 | 2.5339 | 2.1605 | 2.4291 | .2858 | .1543 |
| 17 | .3239 | .2667 | 2.7054 | 2.1605 | 2.4291 | .3048 | .1886 |
| 18 | .4191 | .381 | .362 | .3429 | .3429 | .4382 | .3429 |
| 19 | .4572 | .4572 | .4763 | .4458 | .362 | .4382 | .3429 |
| 20 | .381 | .381 | .381 | .3772 | .381 | .4382 | .3086 |
| 21 | .4382 | .3429 | .3429 | .3601 | .3239 | .362 | .2915 |
| 22 | .3429 | .3048 | .3239 | .3429 | .3239 | .2858 | .2743 |
| 23 | .2667 | .3239 | .3048 | .3258 | .3048 | .2858 | .2572 |
| 24 | .2229 | .2477 | .2858 | .2858 | | .2858 | .2667 |
| **Max** | **2.4615** | **2.2348** | **3.1245** | **2.8578** | **2.4615** | **2.2672** | **2.0891** |
| **Min** | **.1905** | **.2477** | **.2858** | **.2858** | **.3048** | **.2477** | **.1372** |
| **Avg** | **.8112** | **.8025** | **1.2074** | **1.0452** | **1.0522** | **.8125** | **.6983** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214498 / 33/11 KV SHETFALGADE**
**Feeder No / Name : 202 / 11KV LAMJEWADI AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1029 | .1143 | .0953 | .0953 | .0857 | .0953 | .0953 |
| 2 | .0857 | .1143 | .3429 | .4001 | .2753 | .0953 | .1143 |
| 3 | .0857 | .1143 | .362 | .4191 | .2915 | .0953 | .1143 |
| 4 | .1029 | .1334 | .381 | .4572 | .3239 | .1143 | .1334 |
| 5 | .12 | .1524 | .4382 | .4954 | .3887 | .1524 | .1524 |
| 6 | .1715 | .1905 | .5525 | .5716 | .421 | .1905 | .1905 |
| 7 | .2229 | .2286 | .7621 | .8002 | .5668 | .1905 | .2286 |
| 8 | .2058 | .2096 | .8192 | .8002 | .6802 | .2286 | .2286 |
| 9 | .1886 | .1905 | .8002 | .6859 | .6316 | .1524 | .1905 |
| 10 | .5182 | .4696 | .0953 | .1334 | .0953 | .502 | .6964 |
| 11 | .724 | .7287 | .1524 | .0953 | .1143 | .6802 | .6964 |
| 12 | .6316 | .8192 | .1334 | .1017 | .0953 | .7449 | .6964 |
| 13 | .5992 | .8002 | .0953 | .1187 | .0953 | .7287 | .7125 |
| 14 | .743 | .7621 | .0762 | .1017 | .1334 | .7773 | .7611 |
| 15 | .8192 | .7811 | .0953 | .1017 | .0953 | .7287 | .7125 |
| 16 | .743 | .8002 | .0762 | .1017 | .0953 | .7287 | .7125 |
| 17 | .6802 | .724 | .1143 | .0848 | .0953 | .7449 | .6802 |
| 18 | .0953 | .1143 | .1143 | .1029 | .1905 | .1143 | .12 |
| 19 | .1143 | .1524 | .1524 | .1372 | .2096 | .1143 | .1372 |
| 20 | .1334 | .1524 | .1334 | .12 | .1524 | .1334 | .12 |
| 21 | .1524 | .1334 | .1143 | .1029 | .1334 | .1143 | .12 |
| 22 | .1334 | .1334 | .0953 | .1029 | .1143 | .0953 | .12 |
| 23 | .1143 | .1143 | .0953 | .1029 | .0953 | .0953 | .1029 |
| 24 | .1029 | .1143 | .0953 | .0953 | .0857 | .0953 | .0953 |
| **Max** | **.8192** | **.8192** | **.8192** | **.8002** | **.6802** | **.7773** | **.7611** |
| **Min** | **.0857** | **.1143** | **.0762** | **.0848** | **.0857** | **.0953** | **.0953** |
| **Avg** | **.3163** | **.3436** | **.2580** | **.2637** | **.2277** | **.3213** | **.3305** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214498 / 33/11 KV SHETFALGADE**
**Feeder No / Name : 203 / 11KV SHETPHALGADE AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .12 | .1334 | .1524 | .1715 | .12 | .1715 | .1715 |
| 2 | .12 | .1334 | .5906 | .5906 | .5668 | .1715 | .1715 |
| 3 | .1029 | .1524 | .6097 | .6097 | .583 | .1905 | .1715 |
| 4 | .12 | .1905 | .6478 | .6478 | .583 | .2286 | .1905 |
| 5 | .1543 | .2286 | .7049 | .6668 | .6964 | .2477 | .2286 |
| 6 | .2572 | .2667 | .8002 | .7811 | .8745 | .2858 | .3048 |
| 7 | .3086 | .3239 | 1.2574 | 1.1241 | 1.166 | .4001 | .4191 |
| 8 | .3086 | .3429 | 1.5051 | 1.2955 | 1.247 | .4001 | .4382 |
| 9 | .2743 | .3048 | 1.3717 | 1.3146 | 1.166 | .3239 | .3239 |
| 10 | .9717 | .8421 | .1905 | .2286 | .2286 | .9555 | .9231 |
| 11 | 1.2955 | 1.2631 | .2096 | .2477 | .1715 | 1.2146 | 1.085 |
| 12 | 1.2793 | 1.5813 | .2096 | .2035 | .2096 | 1.3765 | 1.166 |
| 13 | 1.247 | 1.5813 | .1905 | .2035 | .2286 | 1.2793 | 1.2308 |
| 14 | 1.0202 | 1.5432 | .1715 | .1865 | .1905 | 1.3279 | .9231 |
| 15 | 1.1012 | 1.5623 | .2096 | .1865 | .1524 | 1.3927 | .8745 |
| 16 | 1.2308 | 1.2765 | .2096 | .1696 | .1715 | 1.2308 | 1.0364 |
| 17 | 1.3908 | 1.2765 | .3048 | .2204 | .2096 | 1.1984 | .9717 |
| 18 | .1905 | .2477 | .3239 | .2058 | .2477 | .2477 | .2058 |
| 19 | .2286 | .2858 | .3429 | .3086 | .2667 | .2477 | .2743 |
| 20 | .2667 | .2858 | .3429 | .2743 | .2477 | .2667 | .2743 |
| 21 | .2477 | .2477 | .3048 | .2229 | .2286 | .2477 | |
| 22 | .1905 | .1905 | .2096 | .1715 | .2096 | .2096 | .1886 |
| 23 | .1524 | .1905 | .1715 | .1543 | .1905 | .1905 | .1715 |
| 24 | .12 | .1334 | .1715 | .1715 | .1372 | .1905 | .1715 |
| **Max** | **1.3908** | **1.5813** | **1.5051** | **1.3146** | **1.247** | **1.3927** | **1.2308** |
| **Min** | **.1029** | **.1334** | **.1524** | **.1543** | **.12** | **.1715** | **.1715** |
| **Avg** | **.5291** | **.6077** | **.4668** | **.4315** | **.4205** | **.5832** | **.5181** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214498 / 33/11 KV SHETFALGADE**
**Feeder No / Name : 204 / 11KV SHETPHALGADE GAOTHAN GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1886 | .1715 | .1715 | .1905 | .1886 | .1905 | .1715 |
| 2 | .1886 | .1715 | .1715 | .1715 | .1886 | .1905 | .1905 |
| 3 | .1886 | .1905 | .1524 | .1715 | .1698 | .2286 | .1905 |
| 4 | .2075 | .2286 | .3239 | .2286 | .1698 | .2667 | .2667 |
| 5 | .3018 | .2667 | .4572 | .3429 | .3395 | .3048 | .3048 |
| 6 | .4715 | .4954 | .5906 | .5335 | .4715 | .4763 | .4954 |
| 7 | .5847 | .5906 | | .5906 | .547 | | .5716 |
| 8 | .5281 | .5525 | .5144 | .4572 | .5093 | .5335 | .5716 |
| 9 | .4338 | .4001 | .4001 | .381 | .3772 | .4001 | .381 |
| 10 | .2987 | .2667 | .2858 | .2667 | .3048 | .2858 | .2801 |
| 11 | .2667 | .2096 | .2096 | .2667 | .2477 | .2477 | .2241 |
| 12 | .2096 | .2096 | .2096 | .2427 | .2286 | .2096 | .2054 |
| 13 | .1715 | .2096 | .1715 | .168 | .1715 | .1905 | .2054 |
| 14 | .1715 | .1715 | .1715 | .168 | .1715 | .1715 | .168 |
| 15 | .1715 | .1715 | .1524 | .2054 | .1715 | .1715 | .1494 |
| 16 | .1715 | .1905 | .1715 | .1867 | .1905 | .1905 | .168 |
| 17 | .2286 | .2667 | .2667 | .2241 | .2286 | .2286 | .2054 |
| 18 | .3048 | .3048 | .381 | .3174 | .2858 | .381 | .3921 |
| 19 | .3429 | .4382 | .4191 | .4294 | .3429 | .381 | .4338 |
| 20 | .4001 | .381 | .3429 | .3395 | .381 | .4001 | .3584 |
| 21 | .3239 | .2667 | .2858 | .3018 | .2667 | .3429 | .2829 |
| 22 | .2096 | .2286 | .2286 | .2452 | .2477 | .2667 | .2263 |
| 23 | .1905 | .1905 | .1905 | .2263 | .2096 | .2286 | .2075 |
| 24 | .1886 | .1715 | .1905 | .1905 | .1886 | .1905 | .1905 |
| **Max** | **.5847** | **.5906** | **.5906** | **.5906** | **.547** | **.5335** | **.5716** |
| **Min** | **.1715** | **.1715** | **.1524** | **.168** | **.1698** | **.1715** | **.1494** |
| **Avg** | **.2810** | **.2810** | **.2808** | **.2852** | **.2749** | **.2816** | **.2850** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214498 / 33/11 KV SHETFALGADE**
**Feeder No / Name : 205 / 11KV MHASOBACHI WADI AG SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3772 | .4191 | .4572 | .4572 | .3772 | .4382 | .4382 |
| 2 | .3772 | .4954 | .9717 | .9907 | .7449 | .4191 | .4382 |
| 3 | .3944 | .6668 | 1.0098 | 1.0288 | .7773 | .4954 | .5716 |
| 4 | .4458 | .8573 | 1.0479 | 1.086 | .8097 | .5716 | .8764 |
| 5 | .5487 | .9526 | 1.1812 | 1.2193 | .9555 | .7621 | .9526 |
| 6 | .9431 | 1.0479 | 1.3527 | 1.448 | 1.247 | 1.0098 | 1.0669 |
| 7 | 1.1317 | 1.2193 | 1.8861 | 2.0576 | 1.6194 | 1.2193 | 1.2193 |
| 8 | .9602 | 1.1241 | 2.0957 | 2.0386 | 1.9595 | 1.105 | 1.1431 |
| 9 | .7373 | .8573 | 1.9814 | 2.1338 | 1.8785 | .8383 | .8192 |
| 10 | 1.247 | 1.247 | .6097 | .5906 | .6097 | 1.2308 | 1.2631 |
| 11 | 1.4899 | 1.8861 | .5716 | .4382 | .4382 | 1.5708 | 1.4251 |
| 12 | 1.6194 | 2.1148 | .3429 | .2713 | .3239 | 1.749 | 1.4575 |
| 13 | 1.6842 | 2.0386 | .3239 | .3052 | .3239 | 1.8461 | 1.5223 |
| 14 | 1.668 | 2.0195 | .3239 | .2713 | .3048 | 1.6518 | 1.5546 |
| 15 | 1.6194 | 2.0195 | .3429 | .2543 | .3048 | 1.6356 | 1.4413 |
| 16 | 1.7166 | 2.1529 | .4001 | .3391 | .3239 | 1.6194 | 1.3441 |
| 17 | 1.6518 | 1.9624 | .4763 | .373 | .4763 | 1.6194 | 1.2631 |
| 18 | .6097 | .743 | | .6344 | .5716 | .6097 | .6859 |
| 19 | .8002 | .9717 | | .7888 | .8573 | .7621 | .7716 |
| 20 | .743 | .7621 | .743 | .7202 | .7621 | .7049 | .6173 |
| 21 | .6478 | .6287 | .5716 | .5487 | .5525 | .6097 | .4801 |
| 22 | .5716 | .5144 | .5716 | .4458 | .5335 | .4954 | .4458 |
| 23 | .4382 | .4954 | .4763 | .4115 | .4763 | .4763 | .4287 |
| 24 | .3772 | .4191 | .3963 | .4572 | | .4572 | .4572 |
| **Max** | **1.7166** | **2.1529** | **2.0957** | **2.1338** | **1.9595** | **1.8461** | **1.5546** |
| **Min** | **.3772** | **.4191** | **.3239** | **.2543** | **.3048** | **.4191** | **.4287** |
| **Avg** | **.9500** | **1.1506** | **.8243** | **.8046** | **.7490** | **.9957** | **.9451** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214498 / 33/11 KV SHETFALGADE**
**Feeder No / Name : 206 / 11KV NIRGUDE AG SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2401 | .2477 | .3048 | .3048 | .2229 | .2858 | .2667 |
| 2 | .6316 | .6964 | .2477 | .2477 | .1886 | .8383 | .7773 |
| 3 | .6478 | .7611 | .2477 | .2477 | .1715 | .7449 | .8097 |
| 4 | .6802 | .8097 | .2667 | | .1886 | .7935 | .8907 |
| 5 | .7611 | .8907 | .3048 | .2667 | .2229 | .8421 | .9717 |
| 6 | .7935 | 1.1241 | .362 | .2667 | .2743 | .8907 | 1.0688 |
| 7 | 1.085 | 1.1498 | .362 | .4954 | .3258 | 1.2308 | 1.5813 |
| 8 | 1.3279 | 1.4089 | .362 | .4382 | .3258 | 1.587 | 1.587 |
| 9 | 1.2955 | 1.5223 | .4191 | .362 | .3429 | 1.5061 | 1.5546 |
| 10 | .2401 | .4191 | 1.3527 | 1.4289 | 1.085 | .3429 | .3258 |
| 11 | .2096 | .3239 | 1.7718 | 1.9052 | 1.1174 | .2286 | .2401 |
| 12 | .2096 | .2858 | 1.9624 | 1.7604 | 1.4899 | .2477 | .2401 |
| 13 | .2477 | .3239 | 2.0195 | 1.7284 | 1.6518 | .2477 | .2401 |
| 14 | .2286 | .2477 | 2.1338 | 1.7284 | 1.5708 | .2477 | .2058 |
| 15 | .2096 | .2477 | 2.0576 | 1.4723 | 1.6032 | .2477 | .2572 |
| 16 | .1905 | .3239 | 1.7147 | 1.6004 | 1.6766 | .2858 | .2229 |
| 17 | .2858 | .3429 | 1.7147 | 1.4403 | 1.4575 | .3048 | .1886 |
| 18 | .3048 | .362 | .2477 | .2743 | .2286 | .3429 | .2743 |
| 19 | .381 | .4382 | .3239 | .3429 | .3239 | .3239 | .2743 |
| 20 | .362 | .362 | .3048 | .3086 | .3429 | .3048 | .2572 |
| 21 | .3239 | .3239 | .3048 | .2915 | .2858 | .2858 | .2229 |
| 22 | .2667 | .3048 | .2858 | .2915 | .2667 | .3048 | .2401 |
| 23 | .2667 | .3048 | .2858 | .2572 | .2858 | .2858 | .2401 |
| 24 | .2229 | .2477 | .2858 | .3048 | .2572 | .2858 | .2667 |
| **Max** | **1.3279** | **1.5223** | **2.1338** | **1.9052** | **1.6766** | **1.587** | **1.587** |
| **Min** | **.1905** | **.2477** | **.2477** | **.2477** | **.1715** | **.2286** | **.1886** |
| **Avg** | **.4755** | **.5612** | **.8184** | **.7724** | **.6628** | **.5419** | **.5502** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214530 / 33/11 KV LASURNE**
**Feeder No / Name : 201 / 11 KV BAJARANGWADI SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0732 | .0754 | .0754 | .0732 | .0754 | .0754 | .1097 |
| 2 | .0732 | .0754 | .25 | .3292 | .1943 | .0754 | .1097 |
| 3 | .0732 | .0754 | .253 | .439 | .1966 | .0754 | .1097 |
| 4 | .0732 | .0943 | .3239 | .5121 | .2267 | .0943 | .1097 |
| 5 | .1829 | .132 | .3887 | .5658 | .3277 | .1509 | .1509 |
| 6 | .1829 | .1886 | .4374 | .5487 | .3932 | .1698 | .1829 |
| 7 | .1829 | .1886 | .7042 | .8048 | .5898 | .1509 | .1463 |
| 8 | .1463 | .132 | .9602 | 1.0974 | .7907 | .1307 | .1097 |
| 9 | .1097 | .0943 | 1.0242 | .8413 | .8905 | .0934 | .0732 |
| 10 | .7926 | .8539 | .0732 | .0754 | .0554 | .7316 | .6706 |
| 11 | 1.142 | 1.2163 | .0732 | .0373 | .0554 | 1.0242 | .7716 |
| 12 | 1.1431 | 1.1523 | .0732 | .0301 | .0373 | .9511 | .7716 |
| 13 | 1.1561 | 1.0753 | .0366 | .0366 | .0373 | .9511 | .7225 |
| 14 | 1.07 | .9686 | .0366 | .0377 | .0351 | .9511 | .7074 |
| 15 | .8124 | .9804 | .0366 | .037 | .0366 | .9877 | .602 |
| 16 | .9374 | .9686 | .0732 | .0709 | .0366 | .9877 | .6622 |
| 17 | .7827 | .8951 | .0732 | .1109 | .0895 | .9511 | .602 |
| 18 | .1075 | .1494 | .1097 | .1478 | .112 | .0732 | .1254 |
| 19 | .1109 | .1494 | .0732 | .1132 | .112 | .1097 | .1307 |
| 20 | .112 | .1132 | .0732 | .1132 | .0943 | .1097 | .1109 |
| 21 | .0943 | .1132 | .0732 | .1132 | .0943 | .1132 | .0934 |
| 22 | .0934 | .0754 | .0732 | .0754 | .0747 | .1132 | .0747 |
| 23 | .0934 | .0754 | .0732 | .1132 | .0754 | .1097 | .0747 |
| 24 | .0732 | .0943 | .0754 | .0754 | .0754 | .0754 | .1097 |
| **Max** | **1.1561** | **1.2163** | **1.0242** | **1.0974** | **.8905** | **1.0242** | **.7716** |
| **Min** | **.0732** | **.0754** | **.0366** | **.0301** | **.0351** | **.0732** | **.0732** |
| **Avg** | **.4008** | **.4140** | **.2268** | **.2666** | **.1961** | **.3857** | **.3055** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214530 / 33/11 KV LASURNE**
**Feeder No / Name : 202 / 11 KV RAJMUDRA** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1829 | .1886 | .1886 | .1886 | .1886 | .1698 | .1829 |
| 2 | 1.1706 | 1.1336 | .1886 | .1463 | .2641 | 1.1984 | 1.2803 |
| 3 | 1.2071 | 1.1069 | .1886 | .1463 | .2614 | 1.1203 | 1.3535 |
| 4 | 1.2437 | 1.1523 | .2241 | .1829 | .2641 | 1.0883 | 1.39 |
| 5 | 1.3169 | 1.2289 | .2641 | .2195 | .2641 | 1.0753 | 1.4266 |
| 6 | 1.3535 | 1.3279 | .3018 | .2926 | .2987 | 1.3279 | 1.4632 |
| 7 | 1.5729 | 1.6385 | .3018 | .2561 | .3018 | 1.4403 | 1.829 |
| 8 | 2.0119 | 1.9334 | .2641 | .2561 | .2614 | 1.7814 | 1.8861 |
| 9 | 2.0485 | 1.9433 | .2263 | .1829 | .2075 | 1.8299 | 1.9387 |
| 10 | .1307 | .1509 | 1.9022 | 1.7814 | 1.6644 | .1463 | .1478 |
| 11 | .1848 | .1448 | 2.4508 | 2.1136 | 1.9595 | | .1663 |
| 12 | .1646 | .181 | 2.4508 | 1.9662 | 1.8461 | .0732 | .1463 |
| 13 | .1463 | .1848 | 2.4143 | 2.1052 | 1.9524 | .0732 | .1075 |
| 14 | .128 | .1463 | 2.5972 | 2.0645 | 2.1052 | .0732 | |
| 15 | .128 | .1848 | 2.4874 | 2.0317 | 2.0485 | .0732 | |
| 16 | .1448 | .2218 | 2.1948 | 2.1628 | 1.9134 | .0732 | .1097 |
| 17 | .1433 | .1829 | 2.1582 | 2.0972 | 1.8976 | .1097 | .1296 |
| 18 | .2218 | | .1829 | .2641 | .1867 | .1829 | .2054 |
| 19 | .2614 | .2641 | .2195 | .2641 | .2427 | .2561 | .2614 |
| 20 | .2427 | .2263 | .1829 | .2263 | .2263 | .2195 | .1867 |
| 21 | .2241 | .1886 | .1829 | .2263 | .1886 | .1829 | .1867 |
| 22 | .2241 | .1886 | .1829 | .2263 | .1867 | .1829 | .1867 |
| 23 | .1867 | .1886 | .1829 | .1867 | .168 | .1829 | .168 |
| 24 | .1829 | .1867 | .1886 | .1829 | .1867 | .1698 | .1829 |
| **Max** | **2.0485** | **1.9433** | **2.5972** | **2.1628** | **2.1052** | **1.8299** | **1.9387** |
| **Min** | **.128** | **.1448** | **.1829** | **.1463** | **.168** | **.0732** | **.1075** |
| **Avg** | **.6176** | **.6215** | **.9219** | **.8238** | **.7952** | **.5665** | **.6789** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214530 / 33/11 KV LASURNE**
**Feeder No / Name : 203 / 11 KV JACHAK** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1463 | .1132 | .1132 | .1463 | .1132 | .1132 | .1509 |
| 2 | .4755 | .4062 | .1132 | .1097 | .1509 | .4696 | .5304 |
| 3 | .5121 | .4111 | .1132 | .1097 | .1509 | .4641 | .5853 |
| 4 | .6219 | .4481 | .1494 | .1097 | .1867 | .5281 | .6584 |
| 5 | .8779 | .5121 | .2263 | .1463 | .2241 | .6167 | .695 |
| 6 | .9511 | .7449 | .2641 | .2561 | .2614 | .6882 | .8676 |
| 7 | 1.39 | 1.0242 | .2641 | .2561 | .3018 | 1.0242 | 1.2449 |
| 8 | 1.4632 | 1.3123 | .2641 | .2561 | .2641 | 1.2803 | 1.3535 |
| 9 | 1.5729 | 1.2967 | .2263 | .1829 | .1886 | 1.2018 | 1.3535 |
| 10 | .128 | .1132 | 1.1706 | 1.1248 | .9686 | .1097 | .1307 |
| 11 | .0739 | .0747 | 1.829 | 1.2803 | 1.3757 | .0732 | .0747 |
| 12 | .0739 | .0739 | 1.8473 | 1.5089 | 1.5223 | .0732 | .056 |
| 13 | .0732 | .0724 | 1.829 | 1.5339 | 1.4864 | .0732 | .0554 |
| 14 | .0732 | .0724 | 1.9239 | 1.142 | 1.4685 | .0366 | .0362 |
| 15 | .0549 | .0739 | 1.9022 | 1.2334 | 1.2193 | .0732 | .0362 |
| 16 | .0554 | .0732 | 1.829 | 1.2334 | 1.2654 | .0732 | .0716 |
| 17 | .1052 | .1109 | 1.829 | 1.1069 | 1.1584 | .1132 | .1109 |
| 18 | .1307 | .1886 | .1463 | .1886 | .1494 | .1463 | .168 |
| 19 | .1886 | .2241 | .1829 | .2241 | .1886 | .1829 | .1886 |
| 20 | .1698 | .1886 | .1829 | .2263 | .1886 | .1829 | .1494 |
| 21 | .168 | .1509 | | .1509 | .1494 | .1463 | .1509 |
| 22 | .1509 | .1509 | .1463 | .1509 | .1307 | .1463 | .132 |
| 23 | .112 | .1494 | .1463 | .1132 | .1307 | .1463 | .132 |
| 24 | .1463 | .1132 | .1132 | .1463 | .1132 | .1132 | .1463 |
| **Max** | **1.5729** | **1.3123** | **1.9239** | **1.5339** | **1.5223** | **1.2803** | **1.3535** |
| **Min** | **.0549** | **.0724** | **.1132** | **.1097** | **.1132** | **.0366** | **.0362** |
| **Avg** | **.4048** | **.3375** | **.7309** | **.5390** | **.5565** | **.3365** | **.3783** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214530 / 33/11 KV LASURNE**
**Feeder No / Name : 204 / 11 KV LASURNE GAONTHAN GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8413 | .7922 | .8676 | .8413 | .8589 | .8299 | .8413 |
| 2 | .8048 | .7922 | .8676 | .8413 | .8676 | .8488 | .8413 |
| 3 | .8779 | .8676 | .9242 | 1.0242 | .9054 | .9054 | .8779 |
| 4 | 1.0242 | .9808 | 1.0829 | 1.2071 | .9808 | 1.0185 | 1.3535 |
| 5 | 1.1706 | 1.1694 | 1.2323 | 1.3169 | 1.2696 | 1.1317 | 1.4266 |
| 6 | 1.3535 | 1.4523 | 1.531 | 1.39 | 1.4563 | 1.2826 | 1.4632 |
| 7 | 1.4632 | 1.4563 | 1.5466 | 1.4335 | 1.4335 | 1.4563 | 1.3535 |
| 8 | 1.1706 | 1.2323 | 1.307 | 1.2437 | 1.2323 | 1.2752 | 1.0974 |
| 9 | 1.0242 | .9795 | .9979 | .9511 | .9877 | 1.0059 | .9145 |
| 10 | .8596 | .8413 | .8779 | .788 | .8954 | .7316 | .567 |
| 11 | .724 | .6805 | .7316 | .6805 | .7796 | .7316 | .6089 |
| 12 | .6447 | .5959 | .6584 | .5609 | .3982 | .5853 | .6447 |
| 13 | .5611 | .5316 | .5853 | .4607 | .4961 | .4755 | .4961 |
| 14 | .5194 | .4961 | .6219 | .4207 | .4908 | .4755 | .443 |
| 15 | .3982 | .4908 | .6584 | .3856 | .4557 | .439 | .5083 |
| 16 | .4031 | .6379 | .7316 | .4298 | .5609 | .5853 | .5373 |
| 17 | .6733 | .362 | .9877 | .788 | .6733 | .8048 | .6733 |
| 18 | .961 | 1.0456 | 1.0974 | 1.0456 | 1.0242 | 1.0242 | .9979 |
| 19 | 1.1203 | 1.2323 | 1.1706 | 1.1576 | 1.1458 | 1.2071 | 1.1576 |
| 20 | 1.0829 | 1.1203 | 1.0185 | 1.0456 | 1.0349 | 1.0974 | .9896 |
| 21 | 1.0082 | 1.0829 | .9511 | 1.0082 | 1.0082 | .9511 | .9522 |
| 22 | .8589 | .9709 | .9145 | .8962 | .8962 | .8779 | .8962 |
| 23 | .8215 | .8962 | .8779 | .8299 | .8215 | .8676 | .8215 |
| 24 | .8413 | .8215 | .8589 | .8779 | .8589 | .8299 | .8413 |
| **Max** | **1.4632** | **1.4563** | **1.5466** | **1.4335** | **1.4563** | **1.4563** | **1.4632** |
| **Min** | **.3982** | **.362** | **.5853** | **.3856** | **.3982** | **.439** | **.443** |
| **Avg** | **.8837** | **.8970** | **.9625** | **.9010** | **.8972** | **.8933** | **.8877** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214530 / 33/11 KV LASURNE**
**Feeder No / Name : 205 / 11 KV LINGE** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2561 | .2218 | .2641 | .2561 | .2641 | .3174 | .2561 |
| 2 | .2561 | .2218 | .9014 | 1.0974 | .9831 | .3361 | .2561 |
| 3 | .2561 | .2241 | .9061 | 1.1706 | .9717 | .3361 | .2926 |
| 4 | .2561 | .2614 | .9831 | 1.2437 | 1.004 | .3696 | .3292 |
| 5 | .3292 | .2987 | .9804 | 1.2803 | 1.0364 | .4066 | .3292 |
| 6 | .3292 | .3326 | .9998 | 1.3535 | 1.0688 | .4251 | .3292 |
| 7 | .3475 | .3326 | 1.2631 | 1.4998 | 1.4091 | .4066 | .3292 |
| 8 | .2926 | .3142 | 1.4403 | 1.829 | 1.4563 | .3881 | .2926 |
| 9 | .2195 | .2561 | | 1.829 | 1.5497 | .3475 | .2378 |
| 10 | 1.3748 | 1.4864 | .2195 | .2303 | .2561 | 1.3763 | 1.3123 |
| 11 | 1.5466 | 1.6446 | .1463 | .3224 | .3109 | 1.6827 | 1.5339 |
| 12 | 1.2315 | 1.7654 | .1463 | .2804 | .3077 | 1.9387 | 1.5623 |
| 13 | 1.6716 | 1.6716 | .1829 | .2865 | .3077 | | 1.4529 |
| 14 | 1.5623 | 1.7236 | .2561 | .181 | .2865 | 1.7558 | 1.4074 |
| 15 | 1.6716 | 1.5813 | .1829 | .1791 | .3045 | 1.9022 | 1.3435 |
| 16 | 1.5813 | 1.4685 | .2012 | .2835 | .3012 | | 1.2811 |
| 17 | 1.5352 | 1.439 | .1949 | | .3544 | 1.829 | |
| 18 | .2172 | .2957 | .2561 | | .3658 | .1829 | |
| 19 | .2926 | .2957 | .2561 | .3361 | .3658 | .2926 | .2614 |
| 20 | .2926 | .2614 | .2561 | .2987 | .3658 | .2926 | .2587 |
| 21 | .2561 | .2614 | .2561 | .2987 | .3511 | .2561 | .2378 |
| 22 | .2561 | .2587 | .2561 | .2614 | .3547 | .2561 | .2012 |
| 23 | .2378 | .2614 | .2561 | .2587 | .3326 | .2561 | .1829 |
| 24 | .2561 | .2378 | .2614 | .2561 | .2614 | .3361 | .2561 |
| **Max** | **1.6716** | **1.7654** | **1.4403** | **1.829** | **1.5497** | **1.9387** | **1.5623** |
| **Min** | **.2172** | **.2218** | **.1463** | **.1791** | **.2561** | **.1829** | **.1829** |
| **Avg** | **.6886** | **.7132** | **.4811** | **.6833** | **.6071** | **.7132** | **.6338** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214535 / 33/11 KV SHELGAON**
**Feeder No / Name : 201 / 11KV KADBANWADI AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1187 | .1357 | .1357 | .1357 | .1187 | .1357 | .1187 |
| 2 | .1357 | .1357 | .5256 | .6274 | .6443 | .1357 | .1187 |
| 3 | .1357 | .1526 | .5426 | .6443 | .6613 | .1526 | .1187 |
| 4 | .1526 | .1526 | .5765 | .6613 | .7291 | .1526 | .1357 |
| 5 | .1526 | .1696 | .6274 | .6952 | .7461 | .1526 | .1526 |
| 6 | .1696 | .1865 | .6613 | .7291 | .78 | .1696 | .1865 |
| 7 | .2543 | .2035 | .9496 | 1.0174 | 1.1022 | .2035 | .2204 |
| 8 | .2035 | .1696 | 1.1191 | 1.17 | 1.2887 | .2035 | .2035 |
| 9 | .1696 | .1526 | 1.153 | 1.3395 | 1.2548 | .1357 | .1357 |
| 10 | .6952 | .7122 | .1017 | .1017 | .1017 | .9156 | .763 |
| 11 | .9496 | .9326 | .0678 | .1017 | .0848 | .9496 | 1.0174 |
| 12 | 1.0852 | 1.1022 | .0678 | .1017 | .0848 | 1.1869 | 1.0174 |
| 13 | 1.153 | 1.3226 | .0678 | .0848 | .0848 | 1.2039 | .9835 |
| 14 | 1.1869 | 1.3565 | .0678 | .0678 | .0678 | 1.2209 | |
| 15 | 1.1869 | 1.2548 | | .0848 | .0678 | 1.1869 | .8478 |
| 16 | .8817 | 1.2209 | | .0848 | .0678 | 1.2378 | .8478 |
| 17 | .8478 | 1.1869 | .1187 | .1017 | .1017 | 1.1361 | .8139 |
| 18 | .1696 | .1357 | .1696 | .1526 | .1526 | .1696 | .1526 |
| 19 | .1865 | .1696 | .2035 | .1526 | .1696 | .2035 | .1696 |
| 20 | .1865 | .1696 | .1696 | .1696 | .1696 | .1696 | .1357 |
| 21 | .1526 | .1696 | .1696 | .1526 | .1357 | .1357 | .1187 |
| 22 | .1187 | .1526 | .1696 | .1357 | .1357 | .1187 | .1017 |
| 23 | .1357 | .1357 | .1357 | .1187 | .1357 | .1187 | .1187 |
| 24 | .1187 | .1187 | .1357 | .1187 | .1187 | .1357 | .1357 |
| **Max** | **1.1869** | **1.3565** | **1.153** | **1.3395** | **1.2887** | **1.2378** | **1.0174** |
| **Min** | **.1187** | **.1187** | **.0678** | **.0678** | **.0678** | **.1187** | **.1017** |
| **Avg** | **.4395** | **.4833** | **.3607** | **.3646** | **.3752** | **.4804** | **.3745** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214535 / 33/11 KV SHELGAON**
**Feeder No / Name : 202 / 11KV TELODHA AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1698 | .2263 | .1698 | .1698 | .1886 | .1886 | .1886 |
| 2 | .9054 | .9619 | .1509 | .1886 | .2075 | .7733 | .8299 |
| 3 | .9431 | .9808 | .1509 | .2075 | .2263 | .811 | .9054 |
| 4 | .9808 | 1.0185 | .1698 | .2075 | .2641 | .9242 | 1.0185 |
| 5 | 1.0185 | 1.1506 | .2075 | .2641 | .2641 | .9808 | 1.1128 |
| 6 | 1.094 | 1.226 | .2641 | .3018 | .2829 | 1.094 | 1.2071 |
| 7 | 1.5844 | 1.5466 | .2452 | .2641 | .3018 | 1.4712 | 1.5466 |
| 8 | 1.9239 | 1.8484 | .2641 | .2452 | .2641 | 1.7353 | 1.8107 |
| 9 | 1.8673 | 1.773 | .1886 | .1698 | .1886 | 1.7353 | 1.6975 |
| 10 | .1132 | .1132 | 1.5278 | 1.5089 | 1.5466 | .1132 | .1132 |
| 11 | .0754 | .0754 | 2.037 | 1.8107 | 1.6975 | .0754 | .0943 |
| 12 | .0754 | .0754 | 2.1502 | 1.7164 | 1.6598 | .0754 | .1132 |
| 13 | .0754 | .0754 | 2.1313 | 1.7918 | 1.6975 | .0943 | .1132 |
| 14 | .0943 | .0754 | 2.1125 | 1.8296 | 1.7353 | .0943 | .1132 |
| 15 | .0943 | .0754 | 2.1125 | 1.8107 | 1.773 | .1132 | .132 |
| 16 | .1132 | .0943 | 1.9427 | 1.8107 | 1.7353 | .1509 | .1509 |
| 17 | .1509 | .132 | 1.8484 | 1.6221 | 1.6598 | .1509 | .1698 |
| 18 | .2263 | .2263 | .2641 | .2641 | .1886 | .1886 | .2452 |
| 19 | .2075 | .2263 | .2452 | .2263 | .1886 | .2641 | .2641 |
| 20 | .2075 | .2263 | .2263 | .2075 | .2075 | .1886 | .2641 |
| 21 | .1886 | .2075 | .1886 | .2075 | .2075 | .1698 | .2263 |
| 22 | .1886 | .2075 | .1886 | .1886 | .1886 | .1886 | .1886 |
| 23 | .1886 | .1886 | .1886 | .1886 | .1886 | .1886 | .2075 |
| 24 | .1698 | .1886 | .1886 | .1698 | .1886 | .1886 | .1886 |
| **Max** | **1.9239** | **1.8484** | **2.1502** | **1.8296** | **1.773** | **1.7353** | **1.8107** |
| **Min** | **.0754** | **.0754** | **.1509** | **.1698** | **.1886** | **.0754** | **.0943** |
| **Avg** | **.5273** | **.5383** | **.7985** | **.7238** | **.7105** | **.4983** | **.5376** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214535 / 33/11 KV SHELGAON**
**Feeder No / Name : 203 / 11KV NAZARKAR AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1658 | .1658 | .1658 | .1823 | .1823 | .1492 | .1326 |
| 2 | | .1823 | .6464 | .6464 | .663 | .1492 | .1326 |
| 3 | .1823 | .1823 | .6299 | .663 | .6796 | .1658 | .1658 |
| 4 | .1989 | .1989 | .663 | .6962 | .7127 | .1823 | .1658 |
| 5 | .1989 | .2155 | .6962 | .7956 | .7459 | .1989 | .1989 |
| 6 | .2321 | .2321 | .7956 | .8619 | .7956 | .2321 | .2486 |
| 7 | .2486 | .2486 | 1.0277 | 1.0277 | 1.0277 | .2652 | .2321 |
| 8 | .2486 | .1989 | 1.2266 | 1.2597 | 1.326 | .1989 | .2155 |
| 9 | .1658 | .1326 | 1.2266 | 1.326 | 1.326 | .1492 | .1492 |
| 10 | 1.0608 | .9116 | .0995 | .116 | .1326 | .9282 | .8619 |
| 11 | 1.326 | 1.2763 | .0829 | .0995 | .0995 | 1.1105 | .779 |
| 12 | 1.2929 | 1.326 | .0663 | .0829 | .0829 | 1.1934 | 1.0774 |
| 13 | 1.326 | 1.3094 | .0663 | .0829 | .0829 | 1.1603 | 1.1271 |
| 14 | 1.3426 | 1.2431 | .0829 | .0829 | .0829 | 1.1437 | 1.0608 |
| 15 | 1.326 | 1.3757 | .0829 | .0829 | .0829 | 1.1603 | 1.1271 |
| 16 | 1.094 | 1.3757 | .0995 | .0829 | .0829 | 1.1603 | 1.0608 |
| 17 | 1.0277 | 1.326 | .116 | .116 | .116 | 1.1271 | .9945 |
| 18 | .1492 | .1492 | .1658 | .1658 | .1492 | .1326 | .1492 |
| 19 | .1823 | .1492 | .1989 | .1658 | .1492 | .1658 | .1989 |
| 20 | .1823 | .1492 | .1823 | .1658 | .1492 | .1658 | .1326 |
| 21 | .1658 | .1658 | .1658 | .1658 | .1326 | .1492 | .1326 |
| 22 | .1658 | .1658 | .1658 | .1658 | .1492 | .1492 | .1326 |
| 23 | .1658 | .1658 | .1658 | .1658 | .1492 | .1492 | .1658 |
| 24 | .1658 | .1658 | .1658 | .1658 | .1658 | .1658 | .1658 |
| Max | **1.3426** | **1.3757** | **1.2266** | **1.326** | **1.326** | **1.1934** | **1.1271** |
| Min | **.1492** | **.1326** | **.0663** | **.0829** | **.0829** | **.1326** | **.1326** |
| Avg | **.5484** | **.5422** | **.3743** | **.3902** | **.3861** | **.4897** | **.4503** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214535 / 33/11 KV SHELGAON**
**Feeder No / Name : 204 / 11KV SHIRSATWADI AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2829 | .3395 | .2829 | .3206 | .3018 | .2452 | .2641 |
| 2 | .811 | .8488 | .2452 | .3395 | .3206 | .8676 | .7545 |
| 3 | .8676 | .8676 | .2829 | .3395 | .3395 | .9054 | .8299 |
| 4 | .9431 | .9054 | .3584 | .415 | .3395 | .9997 | .9242 |
| 5 | 1.0562 | 1.226 | .4527 | .5658 | .4338 | 1.094 | .9997 |
| 6 | 1.2826 | 1.3203 | .5281 | .6036 | .5281 | 1.2449 | 1.2071 |
| 7 | 1.8107 | 1.8484 | .6036 | .5658 | .6036 | 1.6975 | 1.6975 |
| 8 | 1.9616 | 2.2634 | .6224 | .5281 | .5281 | 1.8861 | 1.8107 |
| 9 | 1.7353 | 1.9616 | .4904 | .4338 | .4527 | 1.7918 | 1.6598 |
| 10 | .2641 | .2641 | 1.4335 | 1.358 | 1.3957 | .2452 | .2641 |
| 11 | .1698 | .2075 | 1.8861 | 1.6598 | 1.6598 | .2075 | .1886 |
| 12 | .1886 | .1698 | 1.9239 | 1.7353 | 1.7353 | .1886 | .1698 |
| 13 | .1886 | .1698 | 1.9427 | 1.7353 | 1.6975 | .1698 | .1886 |
| 14 | .1886 | .1509 | 1.9616 | 1.7164 | 1.6221 | .1509 | |
| 15 | .1698 | .1886 | 1.9993 | 1.6787 | 1.5466 | .1698 | .1698 |
| 16 | .1698 | .2263 | 1.9805 | 1.3203 | 1.5844 | .1698 | .1886 |
| 17 | .2829 | .3018 | 1.7353 | 1.3392 | 1.4335 | .2452 | .2829 |
| 18 | .415 | .3772 | .4715 | .4527 | .415 | .3961 | .415 |
| 19 | .3584 | .3772 | .4527 | .4338 | .415 | .4527 | .415 |
| 20 | .3206 | .3772 | .415 | .415 | .415 | .3772 | .3395 |
| 21 | .3395 | .3395 | .3772 | .3584 | .3395 | .3395 | .3206 |
| 22 | .3206 | .3395 | .3395 | .3018 | .3018 | .3018 | .3018 |
| 23 | .3018 | .3206 | .3018 | .2829 | .3018 | .2641 | .2829 |
| 24 | .2829 | .3018 | .3018 | .3018 | .3018 | .2641 | .2641 |
| **Max** | **1.9616** | **2.2634** | **1.9993** | **1.7353** | **1.7353** | **1.8861** | **1.8107** |
| **Min** | **.1698** | **.1509** | **.2452** | **.2829** | **.3018** | **.1509** | **.1698** |
| **Avg** | **.613** | **.6539** | **.8912** | **.8000** | **.7922** | **.6114** | **.6060** |

 Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214535 / 33/11 KV SHELGAON**
**Feeder No / Name : 205 / 11 KV SHELGAON GAOTHAN GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3772 | .415 | .3395 | .415 | .415 | .3961 | .3772 |
| 2 | .4527 | .4338 | .3584 | .4904 | .4527 | .415 | .3772 |
| 3 | .5093 | .4527 | .3772 | .4904 | .4715 | .4527 | .4338 |
| 4 | .5658 | .4527 | .415 | .6036 | .4715 | .547 | .547 |
| 5 | .679 | .7167 | .6413 | .7167 | .6036 | .6413 | .6602 |
| 6 | .7545 | .7733 | .7356 | .7733 | .7167 | .7922 | .7922 |
| 7 | .7167 | .7545 | .7733 | .7356 | .7545 | .7922 | .7922 |
| 8 | .7167 | .6413 | .7356 | .6413 | .7167 | .679 | .6602 |
| 9 | .5093 | .5658 | .6036 | .5093 | .5281 | .4904 | |
| 10 | .3772 | .415 | .4715 | .4527 | .4904 | .3772 | .2263 |
| 11 | .2829 | .3395 | .3772 | .4338 | .3772 | .3584 | .1886 |
| 12 | .2829 | .3395 | .3395 | .2829 | .3395 | .2641 | .1698 |
| 13 | .2263 | .2641 | .2829 | .2829 | .3206 | .2641 | .1509 |
| 14 | .1886 | .2452 | .2452 | .3018 | .2829 | .2452 | |
| 15 | .2452 | .3206 | .2829 | .3018 | .2641 | .2452 | .3395 |
| 16 | .2829 | .3018 | .3018 | .2829 | .3018 | .3018 | .3395 |
| 17 | .3584 | .3584 | .3584 | .3206 | .415 | .3395 | .4338 |
| 18 | .5281 | .5281 | .6413 | .6224 | .5658 | .5093 | .5658 |
| 19 | .5093 | .547 | .6036 | .6036 | .6036 | .6036 | .6413 |
| 20 | .4904 | .547 | .5658 | .6036 | .6413 | .547 | .5658 |
| 21 | .4715 | .4715 | .4904 | .5093 | .547 | .4904 | .4904 |
| 22 | .4715 | .4527 | .4527 | .4338 | .4338 | .415 | .4338 |
| 23 | .3772 | .415 | .3772 | .3961 | .415 | .3772 | .3961 |
| 24 | .3772 | .3772 | .7278 | .3772 | .3772 | .4338 | .415 |
| **Max** | **.7545** | **.7733** | **.7733** | **.7733** | **.7545** | **.7922** | **.7922** |
| **Min** | **.1886** | **.2452** | **.2452** | **.2829** | **.2641** | **.2452** | **.1509** |
| **Avg** | **.4480** | **.4637** | **.4791** | **.4825** | **.4794** | **.4574** | **.4544** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214535 / 33/11 KV SHELGAON**
**Feeder No / Name : 206 / 11KV VIRZARA AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .16 | .208 | .192 | .2241 | .2401 | .192 | .192 |
| 2 | .16 | .208 | .4161 | .3841 | .4161 | .192 | .192 |
| 3 | .176 | .2241 | .4161 | .4001 | .4321 | .208 | .192 |
| 4 | .192 | .2241 | .4481 | .4001 | .4321 | | .208 |
| 5 | .208 | .2401 | .4961 | .4321 | .4481 | .2401 | .2401 |
| 6 | .2241 | .2401 | .5601 | .4481 | .4801 | .2561 | .2561 |
| 7 | .2241 | .2401 | .8002 | .7202 | .7682 | .2881 | .2401 |
| 8 | .2561 | .2241 | 1.1203 | 1.1203 | 1.0883 | .2561 | .208 |
| 9 | .192 | .2241 | 1.0722 | 1.1523 | 1.0242 | .192 | .128 |
| 10 | .7842 | .6882 | .096 | .096 | .112 | .5441 | .5761 |
| 11 | .9282 | .9762 | .16 | .128 | .096 | .9282 | |
| 12 | 1.2003 | 1.0562 | .192 | .128 | .16 | 1.0082 | |
| 13 | 1.1843 | 1.1203 | .176 | .128 | .128 | .9922 | .6081 |
| 14 | 1.1523 | 1.0242 | .16 | .128 | .096 | 1.0082 | .5761 |
| 15 | 1.1683 | 1.0883 | .176 | .144 | .08 | .9602 | .6722 |
| 16 | 1.1363 | .7682 | .16 | .16 | .08 | .9442 | .8322 |
| 17 | 1.0883 | .7362 | .192 | .192 | .128 | .9442 | .7202 |
| 18 | .176 | .1658 | .3041 | .2561 | .2241 | .192 | .192 |
| 19 | .208 | .176 | .2561 | .2401 | .192 | .192 | .192 |
| 20 | .208 | .176 | .2561 | .2241 | .192 | .192 | .176 |
| 21 | .208 | .192 | .2401 | .2241 | .192 | .192 | .16 |
| 22 | .208 | .176 | .2401 | .2241 | .192 | .176 | .16 |
| 23 | .208 | .176 | .2401 | .2241 | .192 | .176 | .176 |
| 24 | .16 | .208 | .176 | .2241 | .2241 | .192 | .176 |
| **Max** | **1.2003** | **1.1203** | **1.1203** | **1.1523** | **1.0883** | **1.0082** | **.8322** |
| **Min** | **.16** | **.1658** | **.096** | **.096** | **.08** | **.176** | **.128** |
| **Avg** | **.4921** | **.4483** | **.3561** | **.3334** | **.3174** | **.4550** | **.3215** |

 Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214536 / 33/11 KV KALAMB**
**Feeder No / Name : 201 / 11 KV BHORKARWADI FEEDER SEPERATION/PURE AG**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0554 | .0554 | .056 | .0549 | .0554 | .0554 | .0554 |
| 2 | .0554 | .0549 | .2987 | .213 | .2218 | .0549 | .0554 |
| 3 | .0554 | .0549 | .2987 | .213 | .2402 | .0549 | .0739 |
| 4 | .0739 | .0739 | .3018 | .2622 | .2772 | .0554 | .0739 |
| 5 | .0924 | .0914 | .3174 | .2949 | .2957 | .0914 | .0924 |
| 6 | .1294 | .1294 | .3395 | .3441 | .3326 | .1478 | .1294 |
| 7 | .1294 | .1294 | .415 | .4096 | .3881 | .1478 | .1478 |
| 8 | .1478 | .128 | .4108 | .3932 | .3881 | .1463 | .1294 |
| 9 | .0914 | .0934 | .4527 | .4251 | .3658 | .0924 | .0914 |
| 10 | .3326 | .3547 | .0914 | .0739 | .0554 | .4435 | .3441 |
| 11 | .4024 | .4481 | .0549 | .0554 | .0366 | .5175 | .4424 |
| 12 | .462 | .4108 | .0549 | .037 | .0554 | .462 | .4915 |
| 13 | .4024 | .5228 | .0732 | .037 | .0732 | .5175 | .4915 |
| 14 | .4207 | .5415 | .0549 | .037 | .0554 | .5544 | .5079 |
| 15 | .4251 | .4854 | .0366 | .037 | .0366 | .5544 | .4915 |
| 16 | .4755 | | .0549 | .0554 | .0739 | .5729 | .4915 |
| 17 | .4066 | | .0732 | .0554 | .0739 | .5175 | .4752 |
| 18 | .0739 | | .0914 | .0739 | .1097 | .0924 | .0914 |
| 19 | .1097 | | .1097 | .0924 | .1097 | .1109 | .0914 |
| 20 | .0914 | .112 | .0914 | .0924 | .0914 | .0739 | .0732 |
| 21 | .0924 | .0934 | .0914 | .0739 | .0739 | .0739 | .0549 |
| 22 | .0732 | .0754 | .0732 | .0554 | .0732 | .0554 | .0549 |
| 23 | .0732 | .056 | .0732 | .0554 | .0554 | .0554 | .0549 |
| 24 | .0554 | .0549 | .056 | .0549 | .0554 | .0549 | .0554 |
| **Max** | **.4755** | **.5415** | **.4527** | **.4251** | **.3881** | **.5729** | **.5079** |
| **Min** | **.0554** | **.0549** | **.0366** | **.037** | **.0366** | **.0549** | **.0549** |
| **Avg** | **.1970** | **.1983** | **.1655** | **.1457** | **.1498** | **.2293** | **.2109** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214536 / 33/11 KV KALAMB**
**Feeder No / Name : 202 / 11 KV KALAMB GAOTHAN GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3142 | .2926 | .3772 | .2591 | .3142 | .3109 | .3511 |
| 2 | .3142 | .2957 | .3734 | .2591 | .3142 | .3142 | .3326 |
| 3 | .3326 | .2957 | .3921 | .2591 | .3326 | .3326 | .3511 |
| 4 | .4066 | .3292 | .4481 | .2949 | .4435 | .4024 | .4066 |
| 5 | .5544 | .5729 | .5228 | .426 | .5729 | .5729 | .5544 |
| 6 | .7577 | .7499 | .7468 | .5243 | .7392 | .7499 | .7577 |
| 7 | .8871 | .9145 | .9054 | .7701 | .8686 | .8962 | .9055 |
| 8 | .7947 | .8316 | .8962 | .6964 | .8501 | .7947 | .8131 |
| 9 | .6653 | .7095 | .7095 | .5668 | .7392 | .7023 | .5407 |
| 10 | .4938 | .5975 | .5571 | .6099 | .5487 | .5359 | .5079 |
| 11 | .4066 | .5228 | .5898 | .4805 | .5359 | .499 | .4096 |
| 12 | .3658 | | .4915 | .4435 | .439 | .4251 | .4096 |
| 13 | .3326 | | .426 | .4251 | .3881 | .4066 | .3401 |
| 14 | .3326 | | .3441 | .4066 | .4024 | .3881 | .3077 |
| 15 | .3109 | .4854 | .3768 | .4435 | .4066 | .3881 | .3239 |
| 16 | .3658 | | .3932 | .5175 | .4024 | .4066 | .3563 |
| 17 | .4435 | | .421 | .5359 | .5121 | .4805 | .4096 |
| 18 | .6219 | | .5898 | .6283 | .6283 | .6283 | .5898 |
| 19 | .6838 | | .6554 | .7392 | .7023 | .7392 | .639 |
| 20 | .6283 | .7922 | .583 | .6653 | .6283 | .6468 | .5506 |
| 21 | .5304 | .6036 | .4752 | .5359 | .5487 | .5175 | .4915 |
| 22 | .4251 | .5228 | .3401 | .4066 | .4805 | .4435 | .4096 |
| 23 | .3326 | .3921 | .3401 | .3511 | .3658 | .3881 | .3768 |
| 24 | .3326 | .2957 | .3734 | .2753 | .3326 | .3511 | .3696 |
| Max | **.8871** | **.9145** | **.9054** | **.7701** | **.8686** | **.8962** | **.9055** |
| Min | **.3109** | **.2926** | **.3401** | **.2591** | **.3142** | **.3109** | **.3077** |
| Avg | **.4847** | **.5414** | **.5137** | **.48** | **.5207** | **.5134** | **.4794** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214536 / 33/11 KV KALAMB**
**Feeder No / Name : 203 / 11 KV RANGAON FEEDER SEPERATION/PURE AG**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2587 | .2561 | .2452 | .2743 | .2587 | .2561 | .2772 |
| 2 | .5175 | .4066 | .2641 | .2561 | .2587 | .4066 | .4066 |
| 3 | .6283 | .4435 | .3018 | .2926 | .2772 | .4435 | .4435 |
| 4 | .6468 | .439 | .3395 | .3292 | .3326 | .5121 | .4805 |
| 5 | .7023 | .5175 | .415 | .439 | .4066 | .6099 | .5544 |
| 6 | .7577 | .6767 | .4904 | .5121 | .499 | .7682 | .7577 |
| 7 | .961 | .8413 | .4904 | .5853 | .5175 | 1.0059 | .961 |
| 8 | 1.0349 | .8686 | .5281 | .5304 | .5544 | .9795 | 1.0719 |
| 9 | .961 | .8215 | .4108 | .4024 | .499 | .9425 | .8192 |
| 10 | .3475 | .2987 | .4858 | .7392 | .7499 | .3142 | .2926 |
| 11 | .2772 | .2614 | .6062 | .7762 | .9511 | .2587 | .2378 |
| 12 | .2195 | .2427 | .6226 | 1.1088 | .9979 | .1848 | .2561 |
| 13 | .2218 | .2614 | .7865 | 1.0719 | .9055 | .2402 | .2012 |
| 14 | .1663 | .2241 | .8684 | 1.0349 | .9328 | .2587 | .1829 |
| 15 | | .2054 | .8192 | .924 | .8501 | .462 | .2012 |
| 16 | | | .8848 | .8501 | .8779 | .3142 | .2378 |
| 17 | | | .8848 | .8131 | .9511 | .3696 | .2743 |
| 18 | .3841 | | .3658 | .3881 | .3511 | .4435 | .4066 |
| 19 | .4435 | | .462 | .4435 | .4251 | .5175 | .3881 |
| 20 | .4066 | .3772 | .3841 | .4066 | .4066 | .499 | .3292 |
| 21 | .3292 | .3395 | .3475 | .3696 | .3475 | .4435 | .3109 |
| 22 | .2957 | .2829 | .3109 | .3142 | .2957 | .4066 | .2743 |
| 23 | .2587 | .2263 | .2957 | .2957 | .2743 | .3696 | .2743 |
| 24 | .2587 | .2587 | .2452 | .2772 | .2772 | .2587 | .2957 |
| **Max** | **1.0349** | **.8686** | **.8848** | **1.1088** | **.9979** | **1.0059** | **1.0719** |
| **Min** | **.1663** | **.2054** | **.2452** | **.2561** | **.2587** | **.1848** | **.1829** |
| **Avg** | **.4799** | **.4125** | **.4940** | **.5598** | **.5499** | **.4694** | **.4140** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214536 / 33/11 KV KALAMB**
**Feeder No / Name : 204 / 11 KV WALCHANDNAGAR FEEDER SEPERATION/PURE AG**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1109 | .1109 | .1494 | .1463 | .1478 | .1478 | .1848 |
| 2 | .1109 | .1097 | .1494 | .1638 | .2218 | .1463 | .1848 |
| 3 | .1294 | .1097 | .2241 | .1638 | .2587 | .1463 | .2218 |
| 4 | .1663 | .1294 | .2614 | .2294 | .2772 | .1663 | .2218 |
| 5 | .2218 | .1646 | .2987 | .2622 | .2957 | .2378 | .2587 |
| 6 | .2957 | .2772 | .3361 | .3277 | .3326 | .3142 | .3326 |
| 7 | .3511 | .3142 | .415 | .426 | .4251 | .3511 | .3881 |
| 8 | .3142 | .3109 | .4527 | .4752 | .499 | .3292 | |
| 9 | .2378 | .2614 | .4854 | .426 | .4938 | .2957 | .2743 |
| 10 | .3511 | .3174 | .2012 | .2402 | .2402 | .3696 | .3441 |
| 11 | .3658 | .4294 | .1829 | .1478 | .2012 | .4435 | .4096 |
| 12 | .3881 | .4668 | .1463 | .1478 | .1663 | .3696 | .4096 |
| 13 | .3658 | .4108 | .128 | .1294 | .1463 | .4251 | .3768 |
| 14 | .3841 | .3734 | .0914 | .1109 | .1478 | .4251 | .3605 |
| 15 | .3881 | .3734 | .0914 | .1109 | .128 | .4066 | .3277 |
| 16 | .3658 | | .1463 | .1478 | .1294 | .4066 | .3113 |
| 17 | .4435 | | .1463 | .1848 | .1663 | .3881 | .2949 |
| 18 | .1848 | | .2012 | .2402 | .1829 | .2033 | .1829 |
| 19 | .2378 | | .2195 | .2587 | .2378 | .2957 | .2195 |
| 20 | .2012 | .2641 | .2195 | .2587 | .2378 | .2772 | .2195 |
| 21 | .2033 | .2263 | .2195 | .2402 | .1848 | .2218 | .1829 |
| 22 | .1463 | .2054 | .1646 | .1848 | .1646 | .2033 | .1829 |
| 23 | .128 | .168 | .1646 | .1663 | .1478 | .1848 | .1463 |
| 24 | .1294 | .1097 | .1494 | .1463 | .1478 | .1463 | .1848 |
| **Max** | **.4435** | **.4668** | **.4854** | **.4752** | **.499** | **.4435** | **.4096** |
| **Min** | **.1109** | **.1097** | **.0914** | **.1109** | **.128** | **.1463** | **.1463** |
| **Avg** | **.2592** | **.2566** | **.2185** | **.2223** | **.2325** | **.2876** | **.2704** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214536 / 33/11 KV KALAMB**
**Feeder No / Name : 205 / 11 KV CHHIKHALI FEEDER SEPERATION/PURE AG**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0554 | .0549 | .056 | .0732 | .0739 | .0549 | .0554 |
| 2 | .0554 | .0554 | .5658 | .3932 | .3881 | .0739 | .0554 |
| 3 | .0554 | .0554 | .5601 | .3932 | .4251 | .0739 | .0739 |
| 4 | .0739 | .0732 | .5975 | .4588 | .462 | .0732 | .0739 |
| 5 | .0924 | .0739 | .6348 | .5243 | .5175 | .1109 | .1109 |
| 6 | .1294 | .1097 | .7095 | .5898 | .6535 | .1463 | .1478 |
| 7 | .1663 | .1463 | .9054 | .6882 | .7577 | .128 | .1663 |
| 8 | .1294 | .1097 | .8775 | .6554 | .7947 | .1478 | .1109 |
| 9 | .0924 | .0747 | .8215 | .6226 | .7762 | .0924 | .0914 |
| 10 | .8048 | .6535 | .0914 | .0739 | .0732 | .7023 | .6062 |
| 11 | .7577 | .8962 | .0549 | .0739 | .0739 | .8501 | .7209 |
| 12 | .7316 | .7842 | .0549 | .0554 | .0732 | .8501 | .6718 |
| 13 | .7762 | .9335 | .0366 | .0554 | .0739 | .8686 | .6554 |
| 14 | .7392 | .9335 | .0549 | .0554 | .0549 | .8402 | .6718 |
| 15 | .8413 | .8215 | .0549 | .0554 | .0554 | .8686 | .6554 |
| 16 | .9055 | | .0366 | .0554 | .0549 | .8871 | .639 |
| 17 | | | .0549 | .0739 | .0549 | .7577 | .5735 |
| 18 | .0549 | | .0914 | .0739 | .0924 | .0924 | .0914 |
| 19 | .0924 | | .1097 | .1294 | .0739 | .1109 | .1097 |
| 20 | .0924 | .1132 | .0914 | .1109 | .0924 | .0739 | .0914 |
| 21 | .0732 | .0934 | .0732 | .0924 | .0732 | .0739 | .0732 |
| 22 | .0554 | .056 | .0732 | .0924 | .0739 | .0554 | .0549 |
| 23 | .0554 | .056 | .0732 | .0924 | .0549 | .0554 | .0549 |
| 24 | .0739 | .0554 | .056 | .0732 | .0739 | .0554 | .0554 |
| **Max** | **.9055** | **.9335** | **.9054** | **.6882** | **.7947** | **.8871** | **.7209** |
| **Min** | **.0549** | **.0549** | **.0366** | **.0554** | **.0549** | **.0549** | **.0549** |
| **Avg** | **.3002** | **.3075** | **.2806** | **.2318** | **.2457** | **.3351** | **.2755** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 214536 / 33/11 KV KALAMB**
**Feeder No / Name : 206 / 11 KV LALPURI FEEDER SEPERATION/PURE AG**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1848 | .1848 | .2054 | .2012 | .2218 | .1848 | .2218 |
| 2 | .3696 | .3658 | .2054 | .1829 | .2033 | .4207 | .3696 |
| 3 | .4435 | .3658 | .2054 | .2012 | .2033 | .4207 | .4066 |
| 4 | .4805 | .4066 | .2263 | .2561 | .2587 | .4805 | .4805 |
| 5 | | .4938 | .2641 | .2926 | .3142 | .5853 | .5914 |
| 6 | .5914 | | .3734 | .3292 | .3696 | .7023 | .7577 |
| 7 | .8316 | | .415 | .3841 | .4251 | .8501 | .8871 |
| 8 | .8871 | | .3395 | .3658 | .3696 | .9511 | .9425 |
| 9 | .823 | .7468 | .2614 | .2926 | .2926 | .8316 | .7537 |
| 10 | .2033 | .2241 | .639 | .6838 | .7023 | .1848 | |
| 11 | | .2054 | .7537 | .8871 | .8596 | .1478 | |
| 12 | | | .8684 | .8871 | .8501 | .1294 | .1829 |
| 13 | .1109 | | .9012 | .9425 | .8048 | .1294 | .1829 |
| 14 | .1097 | | .8356 | .924 | .8131 | .1294 | .1463 |
| 15 | .1478 | .1307 | .8356 | .8871 | .8048 | .1478 | .128 |
| 16 | .1663 | | .7865 | .8131 | .7392 | .1663 | .128 |
| 17 | .2012 | | .7537 | .7947 | .8131 | .1848 | .1463 |
| 18 | .2587 | | .2561 | .2218 | .2195 | .2033 | .2378 |
| 19 | .2743 | | .3326 | .3142 | .2743 | .3142 | .2772 |
| 20 | .2378 | .2829 | .2926 | .2772 | .2743 | .2957 | .2561 |
| 21 | .2218 | .2641 | .2561 | .2587 | .2587 | .2587 | .2195 |
| 22 | .2012 | .2452 | .2195 | .2402 | .2195 | .2218 | .2012 |
| 23 | .1829 | .2054 | .2195 | .2218 | .2033 | .2218 | .2012 |
| 24 | .1848 | .1829 | .2054 | .2012 | .2218 | .1829 | .2218 |
| **Max** | **.8871** | **.7468** | **.9012** | **.9425** | **.8596** | **.9511** | **.9425** |
| **Min** | **.1097** | **.1307** | **.2054** | **.1829** | **.2033** | **.1294** | **.128** |
| **Avg** | **.3387** | **.3075** | **.4438** | **.4608** | **.4465** | **.3477** | **.3609** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 217007 / 132 KV WALCHANDNAGAR**
**Feeder No / Name : 301 / 22KV KALAMB AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | .7011 |
| Max | .7011 |
| Min | .7011 |
| Avg | .7011 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 217007 / 132 KV WALCHANDNAGAR**
**Feeder No / Name : 302 / 22KV Nimgaon (K) SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | .7011 |
| Max | .7011 |
| Min | .7011 |
| Avg | .7011 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 217007 / 132 KV WALCHANDNAGAR**
**Feeder No / Name : 303 / 22KV BHAVANINAGAR AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | .7926 |
| Max | .7926 |
| Min | .7926 |
| Avg | .7926 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 217007 / 132 KV WALCHANDNAGAR**
**Feeder No / Name : 304 / 22KV BHIGWAN INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY**
**Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | .7011 |
| Max | .7011 |
| Min | .7011 |
| Avg | .7011 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 217007 / 132 KV WALCHANDNAGAR**
**Feeder No / Name : 305 / 22KV WALCHANDNAGAR IND. SHEDDABLE FEEDER HAVING WEEKLY**
**Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 1.7071 |
| Max | 1.7071 |
| Min | 1.7071 |
| Avg | 1.7071 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 217007 / 132 KV WALCHANDNAGAR**
**Feeder No / Name : 306 / SUBSTATION I**
**Feeder KV- 22 / OUTGOING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | .7011 |
| Max | .7011 |
| Min | .7011 |
| Avg | .7011 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 217007 / 132 KV WALCHANDNAGAR**
**Feeder No / Name : 308 / 22KV COLONY SUPPLY**
**Feeder KV- 22 / OUTGOING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | .7011 |
| Max | .7011 |
| Min | .7011 |
| Avg | .7011 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 217007 / 132 KV WALCHANDNAGAR**
**Feeder No / Name : 309 / SUBSTATION II**
**Feeder KV- 22 / OUTGOING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | .7011 |
| Max | .7011 |
| Min | .7011 |
| Avg | .7011 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 218030 / 220/33 KV SUB-STATION BHIGWAN**
**Feeder No / Name : 401 / 33KV BHIGWAN Feeder KV- 33 / INCOMING**
**NON SHEDDABLE EXPRESS HV FEEDERS (CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8 | 8.8512 | 6.1671 | 5.679 | 9.6342 | 9.9451 | 8.2488 | 1.0517 |
| 16 | | 9.1558 | 1.0517 | 1.0517 | 1.5089 | 1.1888 | 8.5768 |
| 24 | 2.4451 | 2.3348 | 1.0517 | 2.1033 | 1.0517 | 2.4188 | 2.7435 |
| Max | **8.8512** | **9.1558** | **5.679** | **9.6342** | **9.9451** | **8.2488** | **8.5768** |
| Min | **2.4451** | **2.3348** | **1.0517** | **1.0517** | **1.0517** | **1.1888** | **1.0517** |
| Avg | **5.6482** | **5.8859** | **2.5941** | **4.2631** | **4.1686** | **3.9521** | **4.124** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 218030 / 220/33 KV SUB-STATION BHIGWAN**
**Feeder No / Name : 402 / WATER WORKS Feeder KV- 33 / OUTGOING NON SHEDDABLE WATER SUPPLY AND UTILITY**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 |
|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) |
| 8 | .4578 | | |
| 24 | .679 | .7356 | 1.0517 |
| Max | .679 | .7356 | 1.0517 |
| Min | .4578 | .7356 | 1.0517 |
| Avg | .5684 | .7356 | 1.0517 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 218030 / 220/33 KV SUB-STATION BHIGWAN**
**Feeder No / Name : 408 / STATION TRF I Feeder KV- 33 / OUTGOING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 2.5606 |
| Max | 2.5606 |
| Min | 2.5606 |
| Avg | 2.5606 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**BARAMATI DIVISION[511]**
**WALCHANDNAGAR SUB-DN[723] BU 4723**
**Substation No/ Name :- 218030 / 220/33 KV SUB-STATION BHIGWAN**
**Feeder No / Name : 802 / M/S BILT GRAPHIC PAPER PRODUCT Feeder KV- 220 / OUTGOING NON SHEDDABLE EHV INDUSTRIAL FEEDERS (CONTINOUS PROCESS)(NO STAGGERING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 7.9256 |
| Max | 7.9256 |
| Min | 7.9256 |
| Avg | 7.9256 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051] BU 5886**
**Substation No/ Name :- 214421 / 33/11 KV KURKUMBH**
**Feeder No / Name : 201 / 11 KV CHAKEN SHEDDABLE FEEDER HAVING WEEKLY**
**Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | 1.8099 | 1.3443 | 1.869 | 1.5623 | 1.6956 | |
| 2 | | 2.0005 | 1.3352 | 1.8519 | 1.5242 | 1.6004 | |
| 3 | | 1.9814 | 1.3394 | 1.8347 | 1.5623 | 1.5242 | |
| 4 | | 2.0195 | 1.3717 | 1.8176 | 1.5242 | 1.5623 | |
| 5 | | 2.0005 | 1.4003 | 1.8004 | 1.5242 | 1.5813 | |
| 6 | | 1.9814 | 1.3817 | 1.8004 | 1.5242 | 1.5242 | |
| 7 | | 2.0195 | 1.6804 | 1.8176 | 1.5242 | 1.5813 | |
| 8 | | 1.4098 | .905 | 1.4403 | 1.5242 | | |
| 9 | | 1.7718 | 1.7318 | 1.6956 | 1.6766 | | |
| 10 | 1.9814 | 1.7528 | 2.0576 | 1.6766 | 2.3053 | | 1.7528 |
| 11 | 1.9814 | 1.8099 | 1.9547 | 1.2955 | 1.9052 | | 1.9052 |
| 12 | 2.2481 | 1.7918 | 1.8861 | 2.0576 | 2.1719 | | 1.6004 |
| 13 | 1.9814 | 1.448 | 1.7147 | 2.0957 | 1.8099 | | 1.6004 |
| 14 | 1.7718 | 1.3394 | 1.4575 | 1.6766 | 1.6956 | | 1.3717 |
| 15 | 2.1338 | 1.267 | 1.5775 | 1.6766 | 2.0005 | | 1.6766 |
| 16 | 2.0957 | 1.2308 | 1.7147 | 1.6766 | 1.9624 | | 1.9052 |
| 17 | 2.1148 | 1.1706 | 1.5432 | 1.6766 | 2.1148 | | 1.9052 |
| 18 | 2.0767 | 1.1949 | 1.8519 | 1.6766 | 1.829 | | 1.6766 |
| 19 | 1.7909 | 1.1523 | 1.9204 | 1.9814 | 1.7909 | | 1.5242 |
| 20 | 1.7909 | 1.1222 | 1.5775 | 1.7909 | 1.5242 | | 1.4861 |
| 21 | 2.0195 | | 1.7833 | 1.6004 | 1.7718 | | 1.3717 |
| 22 | 1.9814 | | 1.7661 | 1.829 | 1.6194 | | 1.3717 |
| 23 | 1.9433 | | 1.8861 | 1.7528 | 1.6956 | | |
| 24 | | 2.0957 | 1.267 | 1.869 | 1.6004 | 1.7147 | |
| **Max** | **2.2481** | **2.0957** | **2.0576** | **2.0957** | **2.3053** | **1.7147** | **1.9052** |
| **Min** | **1.7718** | **1.1222** | **.905** | **1.2955** | **1.5242** | **1.5242** | **1.3717** |
| **Avg** | **1.9937** | **1.6367** | **1.6020** | **1.7608** | **1.7393** | **1.598** | **1.6268** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051] BU 5886**
**Substation No/ Name :- 214421 / 33/11 KV KURKUMBH**
**Feeder No / Name : 202 / 11 KV TASC SHEDDABLE FEEDER HAVING WEEKLY**
**Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | 2.0767 | 1.7737 | 1.749 | 1.9433 | 2.1719 | |
| 2 | | 2.0195 | 1.7375 | 1.6975 | 1.9052 | 2.1338 | |
| 3 | | 1.9814 | 1.8111 | 1.6118 | 1.9814 | 2.0957 | |
| 4 | | 1.9624 | 1.8298 | 1.5775 | 2.0195 | 2.0767 | |
| 5 | | 1.9052 | 1.8484 | 1.5604 | 1.9814 | 2.0576 | |
| 6 | | 1.829 | 1.8298 | 1.5432 | 1.9814 | 2.0195 | |
| 7 | | 1.7718 | 1.773 | 1.4918 | 2.0576 | 2.0386 | |
| 8 | | 1.5813 | .2883 | 1.5947 | 2.0576 | | |
| 9 | | 1.7718 | 1.749 | 1.848 | 1.9814 | | |
| 10 | 2.21 | 1.9052 | 1.9547 | 1.829 | 2.3053 | | 1.9814 |
| 11 | 2.2862 | 1.7737 | 1.7147 | 1.5242 | 2.3243 | | 1.9814 |
| 12 | 2.3053 | 1.6651 | 1.8519 | 2.21 | 2.1719 | | 2.0576 |
| 13 | 2.21 | 1.7924 | 1.7147 | 2.1338 | 2.0195 | | 2.0576 |
| 14 | 2.1338 | 1.8298 | 1.6632 | 1.6766 | 2.0386 | | 2.0576 |
| 15 | 2.2291 | 1.8099 | 1.7147 | 1.9052 | 2.21 | | 2.0576 |
| 16 | 2.21 | 1.8461 | 1.749 | 1.9052 | 2.1719 | | 2.0576 |
| 17 | 2.2481 | 1.9791 | 2.0748 | 1.829 | 2.3624 | | 2.0576 |
| 18 | 2.2862 | 1.9185 | | 1.829 | 2.2862 | | 2.0576 |
| 19 | 2.2481 | 1.9185 | 1.6804 | 1.829 | 2.4006 | | 1.9052 |
| 20 | 2.0957 | 1.9185 | 1.8519 | 1.829 | 2.3053 | | 1.9052 |
| 21 | 2.1719 | | 1.6975 | 1.829 | 2.21 | | 1.829 |
| 22 | 1.9243 | | 1.869 | 1.9052 | 2.1719 | | 1.829 |
| 23 | 1.9624 | | 1.6461 | 1.9052 | 2.191 | | |
| 24 | | 2.0576 | 1.6827 | 1.8176 | 1.9433 | 2.191 | |
| **Max** | **2.3053** | **2.0767** | **2.0748** | **2.21** | **2.4006** | **2.191** | **2.0576** |
| **Min** | **1.9243** | **1.5813** | **.2883** | **1.4918** | **1.9052** | **2.0195** | **1.829** |
| **Avg** | **2.1801** | **1.8721** | **1.7176** | **1.7763** | **2.1259** | **2.0981** | **1.9873** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051]** **BU 5886**
**Substation No/ Name :- 214421 / 33/11 KV KURKUMBH**
**Feeder No / Name : 203 / 11 KV ICL** **SHEDDABLE FEEDER HAVING WEEKLY**
**Feeder KV- 11 / OUTGOING** **STAGGERING (MIDC, EQUIVALENT)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | 1.6956 | 1.2127 | 1.3203 | 1.4861 | 2.572 | |
| 2 | | 1.7528 | 1.2696 | 1.3375 | 1.448 | 2.4768 | |
| 3 | | 1.7147 | 1.3014 | 1.3546 | 1.5242 | 2.2862 | |
| 4 | | 1.6004 | 1.3032 | 1.3546 | 1.4861 | 2.3243 | |
| 5 | | 1.5242 | 1.3575 | 1.3717 | 1.448 | 2.2862 | |
| 6 | | 1.3336 | 1.3937 | 1.3717 | 1.448 | 2.4768 | |
| 7 | | 1.3146 | 1.3937 | 1.3717 | 1.448 | 2.3243 | |
| 8 | | 1.2574 | 1.3756 | 1.166 | 1.5242 | | |
| 9 | | 1.2193 | 1.3717 | 1.448 | 1.5242 | | |
| 10 | 1.3717 | 1.105 | 1.3717 | 1.5242 | 1.6766 | | 2.7435 |
| 11 | 1.5242 | 1.4449 | 1.3717 | 1.5242 | 1.7528 | | 2.6673 |
| 12 | 1.4289 | 1.4937 | 1.3889 | 1.448 | 1.5242 | | 3.0483 |
| 13 | 1.2955 | 1.307 | 1.3375 | 1.448 | 1.8099 | | 2.5911 |
| 14 | 1.5432 | 1.1949 | 1.3032 | 1.448 | 2.0195 | | 3.2007 |
| 15 | 1.467 | 1.1218 | 1.3375 | 1.5242 | 1.9052 | | 3.3913 |
| 16 | 1.4861 | 1.1706 | 1.3546 | 1.5242 | 1.9052 | | 3.3532 |
| 17 | 1.5432 | 1.1827 | 1.5261 | 1.5242 | 1.9052 | | 3.4294 |
| 18 | 1.5242 | | 1.5775 | 1.5242 | 2.7435 | | 2.5911 |
| 19 | 1.5623 | 1.134 | 1.3889 | 1.5242 | 2.6292 | | 2.7435 |
| 20 | 1.3908 | 1.1462 | 1.3203 | 1.5242 | 2.3053 | | 2.6673 |
| 21 | 1.448 | | 1.3717 | 1.448 | 2.8769 | | 2.4387 |
| 22 | 1.6956 | | 1.3546 | 1.3717 | 2.8578 | | 2.6673 |
| 23 | 1.6194 | | 1.3889 | 1.4098 | 2.6673 | | |
| 24 | | 1.7528 | 1.1946 | 1.3375 | 1.448 | 2.6673 | |
| **Max** | **1.6956** | **1.7528** | **1.5775** | **1.5242** | **2.8769** | **2.6673** | **3.4294** |
| **Min** | **1.2955** | **1.105** | **1.1946** | **1.166** | **1.448** | **2.2862** | **2.4387** |
| **Avg** | **1.4929** | **1.3733** | **1.3570** | **1.4250** | **1.8901** | **2.4267** | **2.8871** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051] BU 5886**
**Substation No/ Name :- 214421 / 33/11 KV KURKUMBH**
**Feeder No / Name : 204 / 11 KV VINAMAX SHEDDABLE FEEDER HAVING WEEKLY**
**Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .0381 | .0373 | | .0381 | .0381 | |
| 2 | | .0381 | .0366 | .0343 | .0381 | .0381 | |
| 3 | | .0381 | .0373 | | .0381 | .0381 | |
| 4 | | .0381 | .0373 | .0343 | .0381 | .0381 | |
| 5 | | .0381 | .0373 | .0343 | .0381 | .0381 | |
| 6 | | .0381 | .0366 | .0343 | .0381 | .0381 | |
| 7 | | .0381 | .0362 | .0343 | .0381 | .0381 | |
| 8 | | .0381 | .0362 | .0343 | .0381 | | |
| 9 | | .0381 | .0343 | .0381 | .0381 | | |
| 10 | .0381 | .0381 | .0343 | .0381 | .0381 | | .0381 |
| 11 | .0381 | .0362 | .0343 | .0381 | .0381 | | .0381 |
| 12 | .0381 | .0373 | .0343 | .0381 | .0381 | | .0381 |
| 13 | .0381 | .0373 | .0343 | .0381 | .0381 | | .0381 |
| 14 | .0381 | .0362 | .0343 | .0381 | .0381 | | .0381 |
| 15 | .0381 | .0362 | .0343 | .0381 | .0381 | | .0381 |
| 16 | .0381 | .0362 | .0343 | .0381 | .0381 | | .0381 |
| 17 | .0381 | .0362 | .0343 | .0381 | .0381 | | .0381 |
| 18 | .0381 | .0362 | .0343 | .0381 | .0381 | | .0381 |
| 19 | .0381 | .0362 | .0343 | .0572 | .0381 | | .0381 |
| 20 | | .0362 | .0343 | .0381 | .0381 | | .0381 |
| 21 | .0381 | | .0343 | .0381 | .0381 | | .0381 |
| 22 | .0381 | | .0343 | .0381 | .0381 | | .0381 |
| 23 | .0381 | | .0343 | .0381 | .0381 | | |
| 24 | | .0381 | .0373 | | .0381 | .0381 | |
| **Max** | **.0381** | **.0381** | **.0373** | **.0572** | **.0381** | **.0381** | **.0381** |
| **Min** | **.0381** | **.0362** | **.0343** | **.0343** | **.0381** | **.0381** | **.0381** |
| **Avg** | **.0381** | **.0373** | **.0353** | **.0379** | **.0381** | **.0381** | **.0381** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051] BU 5886**
**Substation No/ Name :- 214421 / 33/11 KV KURKUMBH**
**Feeder No / Name : 205 / 11 KV KHADI CRUSHER SHEDDABLE FEEDER HAVING WEEKLY**
**Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .5335 | .4481 | | .5335 | .5335 | |
| 2 | | .5335 | .4801 | .463 | .5335 | .5335 | |
| 3 | | .5335 | .5415 | .463 | .5335 | .5335 | |
| 4 | | .5335 | .5601 | .4801 | .5335 | .5335 | |
| 5 | | .5335 | .5601 | .4801 | .4954 | .5335 | |
| 6 | | .5335 | .543 | .5144 | .5716 | .5335 | |
| 7 | | .5906 | .724 | .6344 | .7621 | .7621 | |
| 8 | | .6097 | .905 | 1.2689 | .9907 | | |
| 9 | | .6478 | 1.3717 | 1.4098 | 1.2193 | | |
| 10 | 1.467 | .7621 | 1.166 | 1.9814 | 2.1719 | | 1.829 |
| 11 | 1.7147 | .7087 | 1.9204 | 1.1431 | 1.9433 | | 1.9052 |
| 12 | 1.6385 | .7316 | 1.5089 | 1.0669 | 1.7337 | | 1.7528 |
| 13 | 1.086 | .724 | | 1.1431 | 1.086 | | 1.2193 |
| 14 | 1.0669 | .6535 | 1.1317 | 1.5242 | .9907 | | 1.448 |
| 15 | 1.105 | .5975 | 1.166 | 2.0195 | 1.7147 | | 2.1338 |
| 16 | 1.1241 | .5601 | 1.1831 | 2.0195 | 1.5242 | | 2.2481 |
| 17 | 1.5242 | .4854 | 1.0974 | 2.0195 | 1.8861 | | 2.3624 |
| 18 | .7621 | .4854 | 1.0802 | .7621 | .724 | | .7621 |
| 19 | | .4854 | .5144 | .5335 | .5335 | | .6097 |
| 20 | | .4477 | .4801 | .5335 | .5335 | | .5335 |
| 21 | .5335 | | .4115 | .5335 | .5335 | | .4954 |
| 22 | .5335 | | .4287 | .5335 | .5335 | | .4954 |
| 23 | .5335 | | .4458 | .5335 | .5335 | | |
| 24 | | .5335 | .4527 | .4458 | .5335 | .5335 | |
| **Max** | **1.7147** | **.7621** | **1.9204** | **2.0195** | **2.1719** | **.7621** | **2.3624** |
| **Min** | **.5335** | **.4477** | **.4115** | **.4458** | **.4954** | **.5335** | **.4954** |
| **Avg** | **1.0908** | **.5821** | **.8313** | **.9785** | **.9645** | **.5621** | **1.3688** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051] BU 5886**
**Substation No/ Name :- 214421 / 33/11 KV KURKUMBH**
**Feeder No / Name : 206 / 11 KV PANDHAREWADI AG FEEDER SEPERATION/PURE AG**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .7621 | .9709 | .7202 | .724 | .7621 | |
| 2 | | .7621 | .8859 | .703 | .7049 | .8002 | |
| 3 | | 1.1622 | 1.8099 | 1.6118 | 1.8671 | .7621 | |
| 4 | | 1.3146 | 1.9909 | 1.6804 | 2.0576 | .7621 | |
| 5 | | 1.9052 | 2.0725 | | 2.3243 | .8573 | |
| 6 | | 2.7625 | 2.0725 | 1.8861 | 2.6292 | .9526 | |
| 7 | | 3.1436 | 2.0725 | 1.9547 | 2.8578 | 1.2003 | |
| 8 | | 3.2198 | 1.1203 | | 3.2007 | | |
| 9 | | 3.0102 | 2.8292 | 1.7147 | 3.2007 | | |
| 10 | 2.7816 | 2.4768 | 2.572 | 1.7147 | 2.6292 | | .6287 |
| 11 | .4382 | .3898 | .5144 | .6097 | .4763 | | 1.829 |
| 12 | .4191 | .3801 | .4458 | | .4382 | | 2.1719 |
| 13 | .4191 | .3547 | .4287 | | .4001 | | 2.0576 |
| 14 | .4191 | .2896 | .4115 | .4001 | .4191 | | 2.2862 |
| 15 | .4191 | .362 | .4287 | .4572 | .4572 | | 2.2862 |
| 16 | .4763 | .4706 | .463 | .4954 | | | 2.21 |
| 17 | .7621 | .543 | .5144 | .6859 | .5335 | | 2.1719 |
| 18 | .8573 | .8596 | .823 | .9717 | .8954 | | 2.4006 |
| 19 | 1.1431 | .9335 | 1.166 | 1.1431 | 1.0288 | | 1.0288 |
| 20 | 1.2003 | 1.0136 | 1.0631 | 1.1431 | 1.0098 | | 1.1241 |
| 21 | 1.0288 | | .9945 | .9907 | .9717 | | .9717 |
| 22 | .8573 | | .8402 | .8573 | .8573 | | .8192 |
| 23 | .8192 | | .7373 | .7621 | .7621 | | |
| 24 | | .7811 | .9134 | .7373 | .724 | .7621 | |
| **Max** | **2.7816** | **3.2198** | **2.8292** | **1.9547** | **3.2007** | **1.2003** | **2.4006** |
| **Min** | **.4191** | **.2896** | **.4115** | **.4001** | **.4001** | **.7621** | **.6287** |
| **Avg** | **.8600** | **1.2808** | **1.1725** | **1.0620** | **1.3552** | **.8574** | **1.6912** |

 Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051]** **BU 5886**
**Substation No/ Name :- 214428 / 33/11 KV PATAS**
**Feeder No / Name : 202 / 11 Kv Railway** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3601 | .3772 | .4115 | .4191 | .3601 | .3601 | .3944 |
| 2 | .3772 | .3772 | .4458 | .4191 | .3601 | .3429 | .4287 |
| 3 | .4287 | .4115 | .4801 | .4763 | .4801 | .5792 | .6401 |
| 4 | .5144 | .4458 | .6001 | .5716 | .6001 | .7011 | .7468 |
| 5 | .6001 | .583 | .7202 | .724 | .6859 | .7621 | .7926 |
| 6 | .7716 | .7888 | .823 | .9526 | .7716 | .8078 | 1.0517 |
| 7 | .8745 | .823 | 1.046 | 1.086 | .9945 | 1.1431 | 1.4937 |
| 8 | .8573 | .9774 | 1.0631 | .9907 | .8916 | 1.6309 | 1.8442 |
| 9 | .7716 | .8573 | 1.0974 | .9602 | .8573 | 2.0957 | 2.0576 |
| 10 | .7373 | .8745 | .9945 | .8916 | .823 | 2.1529 | 2.0405 |
| 11 | 1.6613 | | 1.8595 | 1.829 | 1.9204 | .724 | .6516 |
| 12 | 2.0729 | | 2.4539 | 2.3624 | 2.2558 | .6478 | .6859 |
| 13 | 2.1795 | | 2.5606 | 2.3167 | 2.2253 | .6478 | .6001 |
| 14 | 2.0576 | | 2.5911 | 2.3472 | 1.829 | .6668 | .6001 |
| 15 | 2.1033 | | 2.4387 | 2.3167 | 1.9966 | .6287 | .5487 |
| 16 | 2.1186 | | 2.3777 | 2.271 | 2.2977 | .4973 | .5316 |
| 17 | 1.9814 | | 2.553 | 2.3663 | 1.989 | .463 | .6668 |
| 18 | 1.6004 | 1.4746 | 2.3434 | 1.9719 | 1.6975 | .6001 | .7049 |
| 19 | .6859 | .7888 | .7811 | .6516 | .6344 | .7888 | .743 |
| 20 | .6516 | .7202 | .743 | .6001 | .6001 | .6687 | .6668 |
| 21 | .5144 | .6001 | .6478 | .5316 | .5487 | .6001 | .6287 |
| 22 | .4458 | .5144 | .5144 | .5144 | .5144 | .4973 | .4973 |
| 23 | .4115 | .4801 | .4763 | .3944 | .4287 | .3772 | .3772 |
| 24 | .3429 | .4115 | .4287 | .4382 | .3772 | .3601 | .3429 |
| **Max** | **2.1795** | **1.4746** | **2.5911** | **2.3663** | **2.2977** | **2.1529** | **2.0576** |
| **Min** | **.3429** | **.3772** | **.4115** | **.3944** | **.3601** | **.3429** | **.3429** |
| **Avg** | **1.0467** | **.6768** | **1.2688** | **1.1834** | **1.0891** | **.7810** | **.8223** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051] BU 5886**
**Substation No/ Name :- 214428 / 33/11 KV PATAS**
**Feeder No / Name : 203 / 11 kv Vasunde SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2915 | .3429 | .2915 | .3048 | .2915 | .2915 | .2915 |
| 2 | .8745 | .2743 | .3086 | .3048 | .2743 | .2572 | .2743 |
| 3 | .8745 | .7621 | .823 | .8764 | .4877 | .3429 | .3086 |
| 4 | 1.1145 | .945 | 1.0288 | 1.105 | .5944 | .3772 | .4287 |
| 5 | 1.3717 | 1.1584 | 1.286 | 1.6575 | .7468 | .4801 | .5487 |
| 6 | 1.5604 | 1.5775 | 1.7661 | 2.3624 | 1.5089 | .6344 | .6859 |
| 7 | 1.9376 | 1.8747 | 2.2977 | 2.7054 | 1.9814 | .7545 | .7545 |
| 8 | 2.3148 | 2.0424 | 1.6118 | 1.9052 | 2.3167 | .5487 | .6001 |
| 9 | 2.2253 | 2.0424 | 1.5851 | 1.448 | 2.1643 | .4572 | .3772 |
| 10 | 1.829 | 1.9966 | 1.4937 | 1.6766 | 1.9662 | .3429 | .2058 |
| 11 | .2058 | | .1886 | .2743 | .2401 | 1.2765 | 1.286 |
| 12 | .1886 | | .2058 | .2401 | .2058 | 1.7528 | 1.4575 |
| 13 | .1715 | | .2401 | .2401 | .2058 | 2.0005 | 1.4575 |
| 14 | .1372 | | .2058 | .2401 | .2229 | 1.6575 | 1.4918 |
| 15 | .1543 | | .2058 | | .2229 | 1.8099 | 1.5089 |
| 16 | .1543 | | .1886 | .2743 | .2229 | 1.4327 | 1.3375 |
| 17 | .2058 | | .381 | .3429 | .2572 | 1.3413 | 1.3336 |
| 18 | .2915 | .3429 | .4382 | .3772 | .3601 | 1.2498 | 1.2765 |
| 19 | .5316 | .6001 | .6287 | .5316 | .5487 | .4973 | .5716 |
| 20 | .4801 | .5658 | .5716 | .5144 | .5144 | .4801 | .5335 |
| 21 | .4458 | .463 | .5144 | .4458 | .4287 | .3944 | .4954 |
| 22 | .4115 | .3601 | .4001 | .3429 | .4115 | .3429 | .3429 |
| 23 | .3772 | .3258 | .362 | .2915 | .3772 | .3258 | .3429 |
| 24 | .3086 | .3429 | .3086 | .3239 | .2915 | .3429 | .2915 |
| **Max** | **2.3148** | **2.0424** | **2.2977** | **2.7054** | **2.3167** | **2.0005** | **1.5089** |
| **Min** | **.1372** | **.2743** | **.1886** | **.2401** | **.2058** | **.2572** | **.2058** |
| **Avg** | **.7691** | **.9422** | **.7222** | **.8167** | **.7017** | **.8080** | **.7584** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051]** **BU 5886**
**Substation No/ Name :- 214428 / 33/11 KV PATAS**
**Feeder No / Name : 204 / 11 KV Kusegaon** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6001 | .6173 | .6344 | .6859 | .703 | .7373 | .8573 |
| 2 | .6344 | .6173 | .6516 | .7049 | .6859 | .703 | .7888 |
| 3 | .823 | .6859 | .6859 | .8002 | .823 | .7316 | .7926 |
| 4 | 1.1145 | .7202 | 1.0288 | 1.0288 | .9602 | .8535 | 1.0364 |
| 5 | 1.3717 | 1.3717 | 1.3375 | 1.2765 | 1.286 | 1.0974 | 1.2041 |
| 6 | 1.5604 | 1.5432 | 1.5432 | 1.5432 | 1.5604 | 1.4175 | 1.4327 |
| 7 | 1.6118 | 1.5089 | 1.5261 | 1.7147 | 1.6975 | 2.0271 | 1.829 |
| 8 | 1.3889 | 1.2689 | 1.4403 | 1.6575 | 1.2689 | 2.2558 | 2.2558 |
| 9 | .9945 | 1.0631 | 1.2174 | 1.2003 | 1.2346 | 2.6673 | 2.2977 |
| 10 | .8059 | .7888 | .9945 | .9088 | .9945 | 2.553 | 1.2346 |
| 11 | 1.9509 | | 2.2253 | 2.0729 | 2.2862 | .7811 | .6001 |
| 12 | 2.6368 | | 2.8197 | 2.9264 | 2.6216 | .724 | .6344 |
| 13 | 2.0271 | | 3.2617 | 2.7435 | 2.5911 | .7049 | .6173 |
| 14 | | | 3.094 | 2.6825 | 1.9662 | 1.0288 | .6173 |
| 15 | 2.6978 | | 3.155 | 2.652 | 2.4691 | .9335 | .583 |
| 16 | 2.3929 | | 2.9264 | 2.5911 | 2.7435 | .6001 | .7202 |
| 17 | 2.3167 | | 3.5627 | 2.6749 | 2.4006 | .7888 | 1.0479 |
| 18 | 2.1186 | 1.8176 | 3.1245 | 1.8347 | 2.2634 | 1.0288 | 1.1431 |
| 19 | 1.2689 | 1.3375 | 1.3908 | 1.286 | 1.2689 | 1.3717 | 1.4098 |
| 20 | 1.0974 | 1.3032 | 1.2955 | 1.3032 | 1.2003 | 1.3375 | 1.3336 |
| 21 | .9945 | 1.0288 | 1.0479 | 1.1145 | 1.1145 | 1.2003 | 1.2384 |
| 22 | .6859 | .8059 | .9145 | .8402 | 1.0288 | 1.0631 | .8916 |
| 23 | .6516 | .7202 | .8002 | .7373 | .8916 | .9602 | .8402 |
| 24 | .6173 | .6516 | 2.572 | .724 | .7202 | .823 | .8916 |
| **Max** | **2.6978** | **1.8176** | **3.5627** | **2.9264** | **2.7435** | **2.6673** | **2.2977** |
| **Min** | **.6001** | **.6173** | **.6344** | **.6859** | **.6859** | **.6001** | **.583** |
| **Avg** | **1.4070** | **1.0500** | **1.8021** | **1.571** | **1.5325** | **1.1829** | **1.0957** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051]** **BU 5886**
**Substation No/ Name :- 214428 / 33/11 KV PATAS**
**Feeder No / Name : 205 / 11Kv kamthekar L.I.S.(winary) Feeder KV- 11 / OUTGOING** **SHEDDABLE HV(AGRICULTURE)**

| DATE | 29-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 3 | | .0171 | | .0191 | .0381 | .0572 |
| 4 | | .0171 | | .0191 | .0572 | .0572 |
| 5 | | .0171 | .0572 | .0191 | .0572 | |
| 6 | | .0171 | .0572 | .0191 | .0762 | |
| 7 | .0514 | .0514 | .0572 | .0762 | .0762 | |
| 8 | .0514 | .0514 | .0572 | .0572 | .0762 | |
| 9 | .0381 | | | .0572 | .0762 | |
| 10 | .0381 | | .0381 | | .0762 | |
| 11 | .0381 | .0191 | .0381 | | .0191 | |
| 12 | .0381 | .0572 | .0572 | | .0762 | |
| 13 | .0572 | .0572 | .0572 | | | |
| 14 | .0572 | .0381 | .0572 | | | |
| 15 | .0953 | .0381 | .1143 | | | |
| 16 | .1143 | .0762 | .0381 | | .0381 | |
| 17 | .0953 | .0191 | .0343 | | .0381 | |
| 18 | .0191 | .0191 | .0171 | | | |
| **Max** | **.1143** | **.0762** | **.1143** | **.0762** | **.0762** | **.0572** |
| **Min** | **.0191** | **.0171** | **.0171** | **.0191** | **.0191** | **.0572** |
| **Avg** | **.0578** | **.0354** | **.0523** | **.0381** | **.0588** | **.0572** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051] BU 5886**
**Substation No/ Name :- 214463 / 33 /11 KV DEULGAON**
**Feeder No / Name : 201 / 11 KV H.Berdi AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0732 | .0732 | .0686 | .0732 | .0762 | .0732 | .0686 |
| 2 | .0732 | .0732 | .0686 | .0732 | .0762 | .0732 | .0686 |
| 3 | .5609 | .583 | .5258 | .5731 | .5906 | .0732 | .0686 |
| 4 | .5959 | .583 | .5959 | .5731 | .5906 | .0732 | .0686 |
| 5 | .631 | .583 | .5959 | .6089 | .6668 | .0732 | .0686 |
| 6 | .6859 | .583 | .6485 | .6661 | .6859 | .0914 | .0857 |
| 7 | .7545 | .6859 | .6661 | .8063 | .7049 | .0914 | .1029 |
| 8 | .8745 | .8048 | .8859 | .8916 | .8383 | .0914 | .0857 |
| 9 | .8916 | .7973 | .8413 | .9526 | | .0857 | .0953 |
| 10 | .823 | .815 | .7537 | .9335 | .8413 | .0857 | .0762 |
| 11 | .0366 | | .0366 | .0381 | .037 | 1.0631 | 1.0288 |
| 12 | .0366 | | .0366 | .0381 | .037 | 1.0985 | 1.0479 |
| 13 | .0366 | | .0366 | .0381 | .037 | 1.1871 | 1.0669 |
| 14 | .0549 | | .0366 | .0381 | .037 | 1.2403 | 1.105 |
| 15 | .0366 | | .0366 | .0381 | .037 | 1.2403 | 1.1812 |
| 16 | .0549 | | .0366 | .0572 | .037 | 1.2403 | 1.2384 |
| 17 | .0914 | | .0549 | .0762 | .037 | 1.2403 | 1.2003 |
| 18 | .0914 | .0686 | .0732 | .0953 | .0914 | 1.134 | 1.1431 |
| 19 | .0914 | .0686 | .0914 | .0762 | .0914 | .0686 | .0381 |
| 20 | .0732 | .0686 | .0914 | .0762 | .0732 | .0686 | .0381 |
| 21 | .0914 | .0686 | .0914 | .0762 | .0732 | .0686 | .0572 |
| 22 | .0914 | .0686 | .0914 | .0762 | .0732 | .0686 | .0762 |
| 23 | .0914 | .0686 | .0914 | .0762 | .0732 | .0686 | .0762 |
| 24 | .0732 | .0914 | .0686 | .0762 | | .0732 | .0762 |
| **Max** | **.8916** | **.815** | **.8859** | **.9526** | **.8413** | **1.2403** | **1.2384** |
| **Min** | **.0366** | **.0686** | **.0366** | **.0381** | **.037** | **.0686** | **.0381** |
| **Avg** | **.2881** | **.3579** | **.2718** | **.2928** | **.2639** | **.4447** | **.4234** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051] BU 5886**
**Substation No/ Name :- 214463 / 33 /11 KV DEULGAON**
**Feeder No / Name : 202 / 11 KV Wadgaon AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0914 | .0914 | .1372 | .1097 | .0953 | .0914 | .12 |
| 2 | .0914 | .0914 | .1029 | .1097 | .1143 | .0914 | .12 |
| 3 | .0914 | .0914 | .1029 | .1097 | .1143 | 1.0867 | .8764 |
| 4 | .0914 | .0914 | .1029 | .1097 | .1143 | 1.0867 | .8764 |
| 5 | .1097 | .0914 | .12 | .1097 | .1143 | 1.1218 | .9922 |
| 6 | .128 | .128 | .12 | .1463 | .1143 | 1.1488 | 1.0454 |
| 7 | .1097 | .128 | .1372 | .1463 | .1143 | 1.166 | 1.0631 |
| 8 | .0914 | .1463 | .1372 | .128 | .1143 | 1.3717 | 1.1517 |
| 9 | .0914 | .1886 | .128 | .1334 | | .7164 | 1.2955 |
| 10 | .0914 | .2572 | .1097 | .1334 | .0914 | 1.4864 | 1.3146 |
| 11 | 1.8176 | | 1.5432 | 1.6956 | 1.5775 | .0686 | .0381 |
| 12 | 1.8519 | | 1.6461 | 1.8861 | 1.5775 | .0686 | .0381 |
| 13 | 1.8861 | | 1.7147 | 1.9052 | 1.6461 | .0686 | .0572 |
| 14 | 1.9547 | | 1.7147 | 1.8861 | 1.6461 | .0857 | .0572 |
| 15 | 1.749 | | 1.749 | 1.8671 | 1.6632 | .0857 | .0762 |
| 16 | 1.8004 | | 1.6804 | 1.848 | 1.6118 | .0857 | .0762 |
| 17 | 1.9376 | | 1.7147 | 1.8099 | 1.5089 | .0857 | .1143 |
| 18 | 1.8861 | 1.6108 | 1.749 | 1.7718 | 1.4746 | .0686 | .1334 |
| 19 | .1463 | .1372 | .1463 | .0762 | .1097 | .0857 | .1524 |
| 20 | .1097 | .1372 | .1463 | .0762 | .1097 | .12 | .1524 |
| 21 | .128 | .1372 | .1463 | .0953 | .1097 | .12 | .1334 |
| 22 | .128 | .1372 | .0914 | .0953 | .1097 | .12 | .1143 |
| 23 | .1097 | .1372 | .1463 | .0953 | .1097 | .12 | .1143 |
| 24 | .1097 | .1097 | .1372 | .0953 | | .0914 | .1143 |
| **Max** | **1.9547** | **1.6108** | **1.749** | **1.9052** | **1.6632** | **1.4864** | **1.3146** |
| **Min** | **.0914** | **.0914** | **.0914** | **.0762** | **.0914** | **.0686** | **.0381** |
| **Avg** | **.6918** | **.2183** | **.6468** | **.6850** | **.6473** | **.4434** | **.4261** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051] BU 5886**
**Substation No/ Name :- 214463 / 33 /11 KV DEULGAON**
**Feeder No / Name : 203 / 11 KV Pedgaon AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1463 | .128 | .1543 | .1463 | .0762 | .128 | .12 |
| 2 | .1463 | .128 | .1543 | .1463 | .1524 | .128 | .12 |
| 3 | .1463 | .1463 | .1715 | .1463 | .1524 | 1.2346 | 1.258 |
| 4 | .1463 | .1463 | .1715 | .1463 | .1905 | 1.2346 | 1.3432 |
| 5 | .1646 | .1829 | .1715 | .1463 | .1905 | 1.2346 | 1.3289 |
| 6 | .2012 | .2195 | .1886 | .1829 | .2096 | 1.2346 | 1.3969 |
| 7 | .2195 | .2195 | .1886 | .2195 | .2286 | 1.2346 | 1.4327 |
| 8 | .1646 | .1646 | .1907 | .1463 | .2096 | 1.5775 | 1.4685 |
| 9 | .1463 | .12 | .1463 | .1334 | | 1.6289 | 1.5623 |
| 10 | .1097 | .1029 | .1463 | .0953 | .1097 | 1.6651 | 1.5623 |
| 11 | 1.6804 | | 1.7147 | 2.2672 | 1.406 | .0343 | .0572 |
| 12 | 1.8176 | | 1.8861 | 2.2862 | 1.8861 | .0343 | .0572 |
| 13 | 1.8861 | | 2.1434 | 2.2862 | 1.989 | .0343 | .0572 |
| 14 | 1.9204 | | 2.1434 | 2.2672 | 2.0233 | .0343 | .0572 |
| 15 | 1.9547 | | 2.1262 | 2.1719 | 2.0233 | .0343 | .0572 |
| 16 | 1.9204 | | 2.1262 | 2.191 | 1.989 | .0514 | .0572 |
| 17 | 1.8861 | | 2.1262 | 2.191 | 1.989 | .0857 | .1334 |
| 18 | 1.8176 | 1.6651 | 2.1605 | 2.191 | 1.7833 | .1372 | .1524 |
| 19 | .1829 | .1715 | .1646 | .0953 | .1463 | .1372 | .1524 |
| 20 | .1646 | .1543 | .1646 | .1334 | .128 | .1715 | .1524 |
| 21 | .1463 | .1543 | .1463 | .1334 | .1646 | .1372 | .1524 |
| 22 | .1463 | .1543 | .1463 | .1334 | .1646 | .1372 | .1524 |
| 23 | .1463 | .1543 | .1463 | .1334 | .1646 | .12 | .1524 |
| 24 | .1463 | .1463 | .1543 | .1334 | | .1463 | .1524 |
| **Max** | **1.9547** | **1.6651** | **2.1605** | **2.2862** | **2.0233** | **1.6651** | **1.5623** |
| **Min** | **.1097** | **.1029** | **.1463** | **.0953** | **.0762** | **.0343** | **.0572** |
| **Avg** | **.7253** | **.2446** | **.7930** | **.8385** | **.7898** | **.5248** | **.5473** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051] BU 5886**
**Substation No/ Name :- 214463 / 33 /11 KV DEULGAON**
**Feeder No / Name : 204 / 11 KV D. Raje AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1097 | .0914 | .1029 | .0914 | .0762 | .1097 | .0686 |
| 2 | .1097 | .0914 | .1029 | .0914 | .0762 | .1097 | .0686 |
| 3 | .8413 | .7545 | .7888 | .7202 | .9335 | .0914 | .0857 |
| 4 | .8916 | .7888 | .8859 | .7202 | 1.0098 | .0914 | .0857 |
| 5 | .9602 | .823 | 1.0631 | .7202 | 1.105 | .1097 | .1029 |
| 6 | 1.0974 | .9602 | 1.1871 | 1.0802 | 1.1431 | .1463 | .1372 |
| 7 | 1.2689 | 1.1317 | 1.258 | 1.286 | 1.2003 | .1829 | .1543 |
| 8 | 1.4232 | 1.3375 | 1.5043 | 1.3717 | 1.3717 | .1829 | .1372 |
| 9 | 1.4403 | 1.4327 | 1.3717 | 1.5623 | | .1029 | .1334 |
| 10 | 1.2689 | 1.4327 | 1.3032 | 1.5813 | 1.1317 | .1715 | .1143 |
| 11 | .0732 | | .0732 | .0572 | .0914 | 1.5223 | 1.3336 |
| 12 | .0732 | | .0732 | | .0914 | 1.6118 | 1.3717 |
| 13 | .0732 | | .0732 | .0572 | .0914 | 1.7556 | 1.5051 |
| 14 | .0732 | | .0732 | .0762 | .0914 | 1.7737 | 1.5623 |
| 15 | .0549 | | .0732 | .0762 | .0914 | 1.7737 | 1.6004 |
| 16 | .0549 | | .0914 | .1334 | .0914 | 1.7375 | 1.6766 |
| 17 | .0732 | | .0914 | .1524 | .1097 | 1.7375 | 1.6956 |
| 18 | .128 | .1029 | .0914 | .1524 | .1829 | 1.6289 | 1.7147 |
| 19 | .128 | .1029 | .1463 | .0953 | .1463 | .1029 | .0762 |
| 20 | .0914 | .1029 | .128 | .0953 | .1097 | .1029 | .0762 |
| 21 | .0914 | .1029 | .1097 | .0762 | .1097 | .1029 | .0953 |
| 22 | .0914 | .1029 | .1097 | .0762 | .1097 | .1029 | .0953 |
| 23 | .0914 | .1029 | .1097 | .0762 | .128 | .0686 | .0953 |
| 24 | .1097 | .0914 | .1029 | .0762 | | .128 | .0953 |
| **Max** | **1.4403** | **1.4327** | **1.5043** | **1.5813** | **1.3717** | **1.7737** | **1.7147** |
| **Min** | **.0549** | **.0914** | **.0732** | **.0572** | **.0762** | **.0686** | **.0686** |
| **Avg** | **.4424** | **.5619** | **.4548** | **.4533** | **.4315** | **.6437** | **.5867** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051] BU 5886**
**Substation No/ Name :- 214463 / 33 /11 KV DEULGAON**
**Feeder No / Name : 207 / 11 KV VITTHAL NAGAR AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1829 | .1463 | .1715 | .1829 | .1905 | .1646 | .1372 |
| 2 | .1463 | .1463 | .1715 | .1829 | .1905 | .1646 | .1372 |
| 3 | .4908 | .6859 | .6135 | .5959 | .6859 | .1463 | .1372 |
| 4 | .5258 | .6859 | .631 | .5959 | .724 | .128 | .1372 |
| 5 | .5609 | .6859 | .6733 | .631 | .743 | .1097 | .12 |
| 6 | .631 | .7202 | .7265 | .6661 | .7621 | .0914 | .0857 |
| 7 | .7545 | .8059 | .7087 | .7545 | .7621 | .0914 | .0686 |
| 8 | .9945 | .8573 | .8505 | .7888 | .7811 | .0914 | .0686 |
| 9 | .8573 | .8859 | .8238 | .8954 | | .0857 | .0953 |
| 10 | .8573 | .8505 | .8413 | .8954 | .7011 | .0857 | .1143 |
| 11 | .0914 | | .0914 | .0762 | .0554 | .7888 | .8192 |
| 12 | .0914 | | .0914 | .0953 | .1097 | .8505 | .9335 |
| 13 | .0914 | | .0914 | .0953 | .1097 | .8328 | .9526 |
| 14 | .1097 | | .0914 | .0953 | .1097 | .7796 | 1.0288 |
| 15 | .1097 | | .1097 | .0953 | .1097 | .9036 | 1.0669 |
| 16 | .1097 | | .1097 | .0953 | .1097 | .8859 | 1.0669 |
| 17 | .1463 | | .1097 | .0953 | .1097 | .8328 | 1.0098 |
| 18 | .128 | .1372 | .1097 | .0953 | .128 | .7796 | .9335 |
| 19 | .1829 | .1372 | .1463 | .1143 | .1646 | .1372 | .0572 |
| 20 | .1646 | .1372 | .1829 | .1334 | .1829 | .1372 | .0953 |
| 21 | .1829 | .1372 | .1829 | .1524 | .1829 | .1372 | .0953 |
| 22 | .1829 | .1715 | .1829 | .1715 | .1829 | .1372 | .1143 |
| 23 | .1829 | .1715 | .1829 | .1905 | .1829 | .1372 | .1143 |
| 24 | .1829 | .1829 | .1715 | .1905 | | .1829 | .1143 |
| **Max** | **.9945** | **.8859** | **.8505** | **.8954** | **.7811** | **.9036** | **1.0669** |
| **Min** | **.0914** | **.1372** | **.0914** | **.0762** | **.0554** | **.0857** | **.0572** |
| **Avg** | **.3316** | **.4438** | **.3361** | **.3285** | **.3308** | **.3617** | **.3960** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051] BU 5886**
**Substation No/ Name :- 214463 / 33 /11 KV DEULGAON**
**Feeder No / Name : 208 / 11KV DEULGAON GAOTHAN GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4024 | .4024 | .3506 | .4024 | .4572 | .4024 | .3155 |
| 2 | .4024 | .4207 | .3506 | .4024 | .4382 | .439 | .3506 |
| 3 | .439 | .439 | .4733 | .439 | .4572 | .439 | .3506 |
| 4 | .5487 | .5121 | .6201 | .5121 | .5144 | .5121 | .5316 |
| 5 | .7316 | .695 | .8596 | .695 | .6097 | .695 | .6805 |
| 6 | .9145 | .8413 | .9774 | .8779 | 1.0288 | .9877 | .8059 |
| 7 | .9511 | 1.0242 | .905 | 1.0242 | .9907 | 1.0425 | .9774 |
| 8 | .7316 | .7682 | .7701 | .7682 | .7049 | .7316 | .8059 |
| 9 | .6219 | .5316 | .695 | .724 | | .5258 | .4763 |
| 10 | .439 | .3681 | .5487 | .4954 | .5121 | .4382 | .4572 |
| 11 | .3292 | .2427 | .3292 | | .4435 | .2947 | .3239 |
| 12 | .2561 | .208 | .2926 | .3048 | .3326 | .2427 | .3048 |
| 13 | .2561 | .208 | .2561 | .3048 | .2957 | .208 | .3048 |
| 14 | .2561 | .208 | .2743 | .3048 | .2957 | .208 | .3048 |
| 15 | .2743 | .2254 | .2743 | .3048 | .2957 | .208 | .3239 |
| 16 | .3109 | | .3292 | .362 | .2957 | .2427 | .3239 |
| 17 | .3658 | .208 | .3658 | .5335 | .2957 | .3294 | .4954 |
| 18 | .5487 | .5847 | .5487 | .6668 | .5175 | .5316 | .6478 |
| 19 | .7682 | .6984 | .7316 | .724 | .695 | .6024 | .7049 |
| 20 | .695 | .6201 | .7682 | .8192 | .6584 | .6626 | .724 |
| 21 | .5487 | .5316 | .5487 | .5525 | .5487 | .5316 | .743 |
| 22 | .4755 | .4031 | .5121 | .5144 | .4755 | .4207 | .5525 |
| 23 | .439 | .3681 | .439 | .4763 | .439 | .3681 | .5144 |
| 24 | .4024 | .4024 | .3681 | .4572 | | .4024 | .4763 |
| **Max** | **.9511** | **1.0242** | **.9774** | **1.0242** | **1.0288** | **1.0425** | **.9774** |
| **Min** | **.2561** | **.208** | **.2561** | **.3048** | **.2957** | **.208** | **.3048** |
| **Avg** | **.5045** | **.4744** | **.5245** | **.5507** | **.5137** | **.4778** | **.5207** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051]** **BU 5886**
**Substation No/ Name :- 214523 / 33/11 KV RAWANGAON SUBSTATION**
**Feeder No / Name : 201 / 11 KV KHADKI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1311 | .125 | .1311 | .1311 | .128 | .128 | .1265 |
| 2 | .1311 | .125 | .1326 | .1311 | .1326 | .1326 | .128 |
| 3 | .144 | .125 | .1311 | .128 | .1311 | 1.2803 | 1.3403 |
| 4 | .1406 | .1423 | .125 | .128 | .1406 | 1.2696 | 1.468 |
| 5 | .1543 | .1423 | .125 | .128 | .1372 | 1.2955 | 1.5063 |
| 6 | .1677 | .1581 | .1524 | .1406 | .1505 | 1.3146 | 1.5341 |
| 7 | .1829 | .1581 | .1505 | .1543 | .1505 | 1.5775 | 1.5844 |
| 8 | .1524 | .1219 | .1543 | .1543 | .1806 | 1.7743 | 1.6095 |
| 9 | .1204 | .1128 | .1543 | .1235 | .1219 | 1.7615 | 1.685 |
| 10 | .1189 | .1097 | .1113 | .1143 | .1158 | 1.6598 | 1.387 |
| 11 | 1.251 | 1.8404 | 1.9433 | 2.1247 | 2.1778 | .1189 | .1189 |
| 12 | 1.6467 | 2.3672 | 2.2024 | 2.2939 | 2.2939 | .1174 | .1189 |
| 13 | 2.0081 | 2.3005 | 2.4356 | 2.3739 | 2.4272 | .1158 | .1174 |
| 14 | 2.4006 | 2.2672 | 2.3579 | 2.432 | 2.3838 | .1143 | .1174 |
| 15 | 2.2217 | .3368 | 2.2801 | 2.332 | 2.2874 | .1158 | .1158 |
| 16 | 2.034 | 2.0748 | 2.1765 | 2.2801 | 2.0469 | .1158 | .1174 |
| 17 | 1.8637 | 1.949 | 1.8861 | 2.0119 | 1.8381 | .1174 | .1189 |
| 18 | 1.7105 | 1.6975 | 1.6095 | 1.7615 | 1.6324 | .1174 | .1189 |
| 19 | .1219 | .1486 | .1189 | .1423 | .1265 | .1189 | .1204 |
| 20 | .1219 | .1486 | .1219 | .1389 | .125 | .1204 | .1204 |
| 21 | .1235 | .1505 | .125 | .1355 | .125 | .1355 | .1219 |
| 22 | | .1204 | .1265 | .1235 | .1235 | | .1524 |
| 23 | .125 | .1204 | .128 | .1235 | .1219 | | .1543 |
| 24 | .1296 | .125 | .125 | .1311 | .125 | .1235 | .1235 |
| **Max** | **2.4006** | **2.3672** | **2.4356** | **2.432** | **2.4272** | **1.7743** | **1.685** |
| **Min** | **.1189** | **.1097** | **.1113** | **.1143** | **.1158** | **.1143** | **.1158** |
| **Avg** | **.7479** | **.7070** | **.7918** | **.8224** | **.8010** | **.6193** | **.5877** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051]** **BU 5886**
**Substation No/ Name :- 214523 / 33/11 KV RAWANGAON SUBSTATION**
**Feeder No / Name : 202 / 11 KV RAWANGAON GAVTHAN FEEDE Feeder KV- 11 / OUTGOING** **GAOTHAN FEEDER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .679 | .7468 | .6602 | .679 | .7167 | .6535 | .7356 |
| 2 | .679 | .7095 | .6602 | .6979 | .6413 | .6602 | .6602 |
| 3 | .9431 | .6535 | .6602 | .9431 | .6348 | .7167 | .8676 |
| 4 | 1.3203 | .9808 | .8488 | 1.1317 | .8299 | .8589 | 1.0829 |
| 5 | 1.6975 | 1.3014 | 1.1317 | 1.3203 | 1.0562 | 1.1128 | 1.2883 |
| 6 | 1.7924 | 1.6221 | 1.5089 | 1.5466 | 1.4712 | 1.4901 | 1.5123 |
| 7 | 1.9418 | 1.9427 | 1.7737 | 1.7551 | 1.5844 | 1.6787 | 1.7177 |
| 8 | 1.531 | 1.643 | 1.4784 | 1.5497 | 1.363 | 1.4937 | 1.531 |
| 9 | 1.3256 | 1.3491 | 1.307 | 1.2696 | 1.0829 | 1.2382 | 1.2012 |
| 10 | .9055 | .9145 | .9877 | .9145 | 1.0349 | .9694 | .8048 |
| 11 | .7947 | .6468 | .724 | .7682 | .924 | .8413 | .7164 |
| 12 | .6653 | .5121 | | .5487 | .6838 | .695 | .5373 |
| 13 | .5304 | .4706 | .5121 | .4755 | .6283 | .543 | .5014 |
| 14 | .4024 | .4607 | .4755 | .4024 | .5544 | .3982 | .443 |
| 15 | .5487 | .4656 | .5487 | .439 | .5175 | .5487 | .443 |
| 16 | .7133 | .5014 | .5487 | .5611 | .5853 | .695 | .695 |
| 17 | .8686 | .543 | .7316 | .6516 | .6878 | .8686 | .8501 |
| 18 | 1.0349 | .9877 | 1.1088 | 1.1827 | .8215 | 1.0164 | .9979 |
| 19 | 1.0349 | 1.1949 | 1.307 | 1.3817 | 1.0082 | .9795 | 1.3443 |
| 20 | 1.0642 | 1.1203 | 1.1576 | 1.1576 | 1.0829 | .9522 | 1.1576 |
| 21 | 1.0829 | 1.0456 | 1.0829 | 1.0082 | 1.1203 | .9335 | .9335 |
| 22 | | .9335 | .8962 | .9431 | .8962 | | .8299 |
| 23 | .9335 | .7468 | .7095 | .8962 | .7095 | | .7545 |
| 24 | .679 | .8402 | .6602 | .679 | .8215 | .6722 | .7842 |
| **Max** | **1.9418** | **1.9427** | **1.7737** | **1.7551** | **1.5844** | **1.6787** | **1.7177** |
| **Min** | **.4024** | **.4607** | **.4755** | **.4024** | **.5175** | **.3982** | **.443** |
| **Avg** | **1.0073** | **.9305** | **.9339** | **.9543** | **.8940** | **.9098** | **.9329** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051]** **BU 5886**
**Substation No/ Name :- 214523 / 33/11 KV RAWANGAON SUBSTATION**
**Feeder No / Name : 203 / 11 KV NANDADEVI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3772 | .4108 | .362 | .362 | .3772 | .3961 | .3961 |
| 2 | .3772 | .4251 | .362 | .362 | .3772 | .3772 | .415 |
| 3 | 1.7604 | 1.8233 | 1.7814 | 1.8404 | 1.6644 | .3772 | .3734 |
| 4 | 1.8976 | | 1.9204 | 1.9204 | 1.7368 | .3961 | .3734 |
| 5 | 2.0557 | 2.3205 | 1.9204 | 2.0005 | 1.8084 | .3961 | .3921 |
| 6 | 2.2138 | 2.6052 | 1.9204 | 2.0805 | 1.8884 | .4527 | .4108 |
| 7 | 2.372 | 2.8182 | 2.0805 | 2.2405 | 1.9204 | .4481 | .4294 |
| 8 | 2.3878 | 2.5587 | 2.4006 | 2.3045 | 2.343 | .3734 | .4481 |
| 9 | 2.4036 | 2.3045 | 2.3205 | 2.1506 | 2.2348 | .3326 | .3696 |
| 10 | 2.2771 | 2.1872 | 2.0805 | 1.9753 | 2.2085 | .2804 | .2195 |
| 11 | .2987 | .181 | .1829 | .1646 | .1463 | 1.9559 | 1.829 |
| 12 | .2987 | .1463 | .1629 | .1463 | .1448 | 2.1216 | 2.0062 |
| 13 | .2957 | .1448 | .1433 | .1463 | .1463 | 2.2939 | 2.0833 |
| 14 | .2587 | .1448 | .1448 | .1433 | .1646 | | 2.1559 |
| 15 | .2772 | .1448 | .1463 | .1433 | .1663 | 2.1765 | 2.1872 |
| 16 | .2957 | .1448 | .1478 | .1629 | .1829 | 2.1125 | 2.1559 |
| 17 | .3326 | .1448 | .1848 | .2172 | .2172 | 2.0241 | |
| 18 | .3696 | .3258 | .3326 | .3326 | .3292 | 1.9372 | 1.9997 |
| 19 | .3881 | .362 | .4251 | .4481 | .3734 | .3734 | .3547 |
| 20 | .4108 | .362 | .4251 | .4294 | .3734 | .3734 | .3547 |
| 21 | .4338 | .362 | .4024 | .3734 | .3734 | .3961 | .3547 |
| 22 | | .362 | .3841 | .3734 | .3734 | | .3772 |
| 23 | .4108 | .362 | .362 | .3734 | .3921 | | .3772 |
| 24 | .3772 | .3921 | .362 | .362 | .3772 | .3921 | .3772 |
| **Max** | **2.4036** | **2.8182** | **2.4006** | **2.3045** | **2.343** | **2.2939** | **2.1872** |
| **Min** | **.2587** | **.1448** | **.1433** | **.1433** | **.1448** | **.2804** | **.2195** |
| **Avg** | **.9813** | **.9145** | **.8731** | **.8772** | **.8467** | **.9517** | **.8887** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051] BU 5886**
**Substation No/ Name :- 214523 / 33/11 KV RAWANGAON SUBSTATION**
**Feeder No / Name : 204 / 11 KV RAWANGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2987 | .2957 | .2987 | .2987 | .3395 | .2987 | .2801 |
| 2 | .2987 | .3142 | | .2987 | .3395 | .3018 | .2987 |
| 3 | .3361 | .3361 | .2987 | .3361 | .3395 | 1.6385 | 1.3279 |
| 4 | .3547 | .3734 | .2987 | .3547 | .3361 | 1.6575 | 1.406 |
| 5 | .3734 | .3921 | .3361 | .3734 | .3584 | 1.6712 | 1.5935 |
| 6 | .3734 | .4108 | .3734 | .3921 | .3772 | 1.6876 | 1.6667 |
| 7 | .3734 | .4481 | | .3921 | .3921 | 2.0153 | 1.6821 |
| 8 | .3326 | .3696 | .3734 | .3921 | .3734 | 2.1296 | 1.7593 |
| 9 | .2561 | .3326 | .3326 | .2987 | .2987 | 2.1605 | 1.821 |
| 10 | .2195 | .2195 | .2715 | .2427 | .2402 | 1.6461 | 1.6975 |
| 11 | 1.7204 | 2.1348 | 2.0715 | 2.3685 | 2.2405 | .2587 | .1463 |
| 12 | 2.13 | 2.3205 | 2.2725 | 2.4615 | 2.4615 | .2587 | .1463 |
| 13 | 2.5587 | 2.5606 | 2.4166 | 2.372 | 2.4966 | .2241 | .1448 |
| 14 | 2.753 | 2.5606 | 2.3365 | 2.2028 | 2.5911 | .1867 | .1433 |
| 15 | 2.6246 | 2.5606 | 2.2138 | 2.284 | 2.4646 | | .1433 |
| 16 | 2.5126 | 2.4215 | 2.1506 | 2.2965 | 2.1715 | | .1463 |
| 17 | 2.3878 | 2.2377 | 2.1506 | 2.2685 | 1.9136 | .1663 | .1848 |
| 18 | 2.2771 | 2.4025 | 2.1091 | 2.2184 | 1.8903 | .2587 | .2587 |
| 19 | .1848 | .362 | .3511 | .3511 | .2801 | .2587 | .3018 |
| 20 | .2218 | .3696 | .3511 | .3326 | .2614 | .2801 | .3018 |
| 21 | .2587 | .2957 | .3361 | .2957 | .2614 | .2614 | .2987 |
| 22 | | .2987 | .3361 | .2987 | .2801 | | .2987 |
| 23 | .2772 | .2987 | .3174 | .3174 | .2987 | | .2987 |
| 24 | .2987 | .3142 | .2987 | .2987 | .3395 | .2987 | .2614 |
| **Max** | **2.753** | **2.5606** | **2.4166** | **2.4615** | **2.5911** | **2.1605** | **1.821** |
| **Min** | **.1848** | **.2195** | **.2715** | **.2427** | **.2402** | **.1663** | **.1433** |
| **Avg** | **1.0183** | **1.0262** | **1.0134** | **.9894** | **.9727** | **.8829** | **.6920** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051] BU 5886**
**Substation No/ Name :- 214534 / 33/11 kV Malthan Daund**
**Feeder No / Name : 201 / 11 kV WATLUJ Ag feeder SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .0686 | .0739 | .0934 | .0724 |
| 2 | | .0734 | .1075 | .0747 | .0714 |
| 3 | | .6478 | .0943 | .0701 | .0714 |
| 4 | | .6964 | .6024 | .0848 | .0869 |
| 5 | | .7343 | .8326 | .0678 | .1027 |
| 6 | | .7202 | .9979 | .0848 | .104 |
| 7 | | .6554 | 1.0277 | .0678 | .0667 |
| 8 | | .6554 | .852 | | .0686 |
| 9 | | .7125 | .8383 | .0556 | .0676 |
| 10 | .6802 | .6478 | .7202 | .0533 | |
| 11 | .0251 | | | .679 | .7274 |
| 12 | .0179 | | | .7968 | .8002 |
| 13 | .0381 | | | .8223 | .9069 |
| 14 | .045 | | | .7968 | .9831 |
| 15 | .0381 | | | .7968 | .8583 |
| 16 | .0305 | | | .8179 | .9012 |
| 17 | .0305 | | | .828 | .8383 |
| 18 | .0533 | .0693 | .1029 | .8322 | .8848 |
| 19 | .0686 | .0754 | .1029 | .0724 | .0754 |
| 20 | .0587 | .0943 | .1052 | .0686 | .0754 |
| 21 | .0541 | .0754 | .1086 | .0695 | .1132 |
| 22 | .0541 | .0934 | .1109 | .0714 | .0943 |
| 23 | .0676 | .112 | .1109 | .0714 | .1132 |
| 24 | | .0705 | .0943 | .112 | .0743 |
| **Max** | **.6802** | **.7343** | **1.0277** | **.8322** | **.9831** |
| **Min** | **.0179** | **.0686** | **.0739** | **.0533** | **.0667** |
| **Avg** | **.0901** | **.3648** | **.4049** | **.3255** | **.3547** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051] BU 5886**
**Substation No/ Name :- 214534 / 33/11 kV Malthan Daund**
**Feeder No / Name : 202 / 11 kV Rajegaon Ag SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | .4146 | .567 | .5975 | .3772 |
| 2 | | | | .3898 | .5316 | .6348 | |
| 3 | | 1.3213 | 1.6956 | 1.448 | .5788 | 2.0157 | 1.8839 |
| 4 | | 1.2971 | 1.7604 | 1.7909 | 1.9982 | 1.9839 | 1.8099 |
| 5 | | 1.3289 | 1.7939 | 1.8755 | 2.1491 | 2.0008 | 1.9366 |
| 6 | | 1.4327 | 1.8107 | 2.0774 | 2.3411 | 2.0178 | 2.0513 |
| 7 | | 1.8073 | 2.1795 | 2.0576 | 2.2085 | 2.0008 | 1.9281 |
| 8 | .6539 | 2.1132 | 2.2131 | 2.0458 | 1.9757 | 2.0008 | 1.9631 |
| 9 | .57 | 1.9631 | 1.9616 | 1.7924 | 1.8067 | 1.893 | 1.7511 |
| 10 | 1.3923 | 1.858 | 1.7939 | 1.5844 | 1.5181 | 1.6804 | 1.3763 |
| 11 | 1.9448 | 2.1439 | 2.0576 | 2.0056 | 1.7695 | 1.4575 | 1.5154 |
| 12 | 2.0119 | 2.1704 | 2.2634 | 2.2043 | 1.9227 | 1.6484 | 1.6129 |
| 13 | 2.1216 | 2.2291 | 2.3491 | 2.332 | 2.0119 | 1.6964 | 1.7284 |
| 14 | 2.2131 | 2.2634 | 2.4006 | 2.1548 | 2.079 | 1.7284 | 1.9433 |
| 15 | 2.2634 | 2.2382 | 2.332 | 2.1293 | 2.2043 | 1.7764 | 1.7924 |
| 16 | 2.34 | 2.2552 | 2.2291 | 2.3061 | 2.2466 | 1.7236 | 1.8785 |
| 17 | 2.3472 | 2.3739 | 2.0517 | 2.5034 | 2.146 | 1.7284 | 1.8896 |
| 18 | 2.4478 | 2.4587 | 2.2786 | 2.4006 | 2.1026 | 2.0233 | 1.7814 |
| 19 | | | .5489 | .8029 | .4115 | .5281 | .7468 |
| 20 | | | .5335 | .7545 | .4382 | .5182 | .7167 |
| 21 | | | .4934 | .6722 | .4706 | .4723 | .6722 |
| 22 | | | .4534 | .5914 | .499 | .4146 | .5975 |
| 23 | | | .4534 | .5729 | .5175 | .3887 | .5788 |
| 24 | | | | .4207 | .5658 | .5601 | .3963 |
| **Max** | **2.4478** | **2.4587** | **2.4006** | **2.5034** | **2.3411** | **2.0233** | **2.0513** |
| **Min** | **.57** | **1.2971** | **.4534** | **.3898** | **.4115** | **.3887** | **.3772** |
| **Avg** | **1.846** | **1.9534** | **1.6978** | **1.5553** | **1.4608** | **1.3954** | **1.4316** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051] BU 5886**
**Substation No/ Name :- 214534 / 33/11 kV Malthan Daund**
**Feeder No / Name : 203 / VASANTDADA SUGAR INSTITUTE PURELY LIS FEEDERS**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 3 | .1296 | .0343 | .0532 | .0739 | .0351 | .0514 |
| 4 | .1311 | .0335 | .0549 | .052 | .0339 | .0514 |
| 5 | .1341 | .0339 | .0543 | .0354 | .0339 | .0686 |
| 6 | .1326 | .0339 | .0537 | .0905 | .0339 | .0857 |
| 7 | .1326 | .0339 | .0532 | .104 | .0339 | .0857 |
| 8 | .1326 | .0339 | .0537 | .128 | .0339 | .0857 |
| 9 | .1341 | .0335 | .0474 | .1147 | .0366 | .0848 |
| 10 | .1341 | | .0316 | .1406 | .0362 | .0486 |
| 11 | .1677 | .0549 | .0492 | .1134 | .0724 | .0772 |
| 12 | .1677 | .0543 | .0335 | .1311 | .0732 | .0625 |
| 13 | .1677 | .0549 | .0509 | .116 | .0724 | .0791 |
| 14 | .1677 | .0549 | .0328 | .1492 | .0543 | .112 |
| 15 | .1677 | .0549 | .0663 | .1341 | .0724 | .0474 |
| 16 | .1341 | .0543 | .1006 | .0995 | .0537 | .08 |
| 17 | .0848 | .0724 | .1187 | .116 | .0543 | .1147 |
| 18 | .0848 | .0543 | .0848 | .1509 | .0848 | .048 |
| **Max** | **.1677** | **.0724** | **.1187** | **.1509** | **.0848** | **.1147** |
| **Min** | **.0848** | **.0335** | **.0316** | **.0354** | **.0339** | **.0474** |
| **Avg** | **.1377** | **.0461** | **.0587** | **.1093** | **.0509** | **.0739** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051] BU 5886**
**Substation No/ Name :- 216613 / Aalegaon Substation**
**Feeder No / Name : 300 / Auxilary**
**Feeder KV- 22 / OUTGOING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 3.7723 |
| Max | 3.7723 |
| Min | 3.7723 |
| Avg | 3.7723 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051]** **BU 5886**
**Substation No/ Name :- 216613 / Aalegaon Substation**
**Feeder No / Name : 301 / 22 Kv Boribel Feeder AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 3.7723 |
| Max | 3.7723 |
| Min | 3.7723 |
| Avg | 3.7723 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051]** **BU 5886**
**Substation No/ Name :- 216613 / Aalegaon Substation**
**Feeder No / Name : 302 / 22 KV KHANOTA AALEGAON AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 3.7723 |
| Max | 3.7723 |
| Min | 3.7723 |
| Avg | 3.7723 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051]** **BU 5886**
**Substation No/ Name :- 216613 / Aalegaon Substation**
**Feeder No / Name : 303 / 22KV ALEGAON AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 3.7723 |
| Max | 3.7723 |
| Min | 3.7723 |
| Avg | 3.7723 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051]** **BU 5886**
**Substation No/ Name :- 216613 / Aalegaon Substation**
**Feeder No / Name : 701 / 132 kV Daund Sugar** **NON SHEDDABLE EHV INDUSTRIAL FEEDERS**
**Feeder KV- 132 / OUTGOING** **(CONTINOUS PROCESS)(NO STAGGERING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 22.6338 |
| Max | 22.6338 |
| Min | 22.6338 |
| Avg | 22.6338 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051] BU 5886**
**Substation No/ Name :- 217015 / 132KV DAUND**
**Feeder No / Name : 300 / Auxilary**
**Feeder KV- 22 / OUTGOING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 3.7723 |
| Max | 3.7723 |
| Min | 3.7723 |
| Avg | 3.7723 |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051]** **BU 5886**
**Substation No/ Name :- 217015 / 132KV DAUND**
**Feeder No / Name : 301 / 22 KV KEDGAON SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 7.5446 |
| Max | 7.5446 |
| Min | 7.5446 |
| Avg | 7.5446 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051]** **BU 5886**
**Substation No/ Name :- 217015 / 132KV DAUND**
**Feeder No / Name : 302 / 22 KV DAUND** **SHEDDABLE URBAN**
**Feeder KV- 22 / OUTGOING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 23 | 3.7723 |
| 24 | 3.7723 |
| Max | 3.7723 |
| Min | 3.7723 |
| Avg | 3.7723 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051]** **BU 5886**
**Substation No/ Name :- 217015 / 132KV DAUND**
**Feeder No / Name : 303 / 22 KV RAILWAY** **SHEDDABLE URBAN**
**Feeder KV- 22 / OUTGOING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 23 | 7.5446 |
| 24 | 3.7723 |
| Max | 7.5446 |
| Min | 3.7723 |
| Avg | 5.6585 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051]** **BU 5886**
**Substation No/ Name :- 217015 / 132KV DAUND**
**Feeder No / Name : 304 / 22 KV KURKUMBH SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 3.7723 |
| Max | 3.7723 |
| Min | 3.7723 |
| Avg | 3.7723 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051] BU 5886**
**Substation No/ Name :- 217015 / 132KV DAUND**
**Feeder No / Name : 305 / 22 kv Dychem FEEDER SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 3.7723 |
| Max | 3.7723 |
| Min | 3.7723 |
| Avg | 3.7723 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051] BU 5886**
**Substation No/ Name :- 217015 / 132KV DAUND**
**Feeder No / Name : 307 / 22KV GIRIM GAVTHAN GAOTHAN FEEDER**
**Feeder KV- 22 / OUTGOING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 7.5446 |
| Max | 7.5446 |
| Min | 7.5446 |
| Avg | 7.5446 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051]** **BU 5886**
**Substation No/ Name :- 217015 / 132KV DAUND**
**Feeder No / Name : 308 / 22KV BORAWAKE NAGAR GAOTHAN FEEDER GAVTHAN Feeder KV- 22 / OUTGOING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 3.7723 |
| Max | 3.7723 |
| Min | 3.7723 |
| Avg | 3.7723 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051]** **BU 5886**
**Substation No/ Name :- 217015 / 132KV DAUND**
**Feeder No / Name : 309 / 22 KV S R P F** **SHEDDABLE URBAN**
**Feeder KV- 22 / OUTGOING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 23 | 3.7723 |
| Max | 3.7723 |
| Min | 3.7723 |
| Avg | 3.7723 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051] BU 5886**
**Substation No/ Name :- 217015 / 132KV DAUND**
**Feeder No / Name : 310 / Colony**
**Feeder KV- 22 / OUTGOING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 3.7723 |
| Max | 3.7723 |
| Min | 3.7723 |
| Avg | 3.7723 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051] BU 5886**
**Substation No/ Name :- 217015 / 132KV DAUND**
**Feeder No / Name : 401 / 33 KV DEULGAON RAJE**
**Feeder KV- 33 / OUTGOING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 11.3168 |
| Max | 11.3168 |
| Min | 11.3168 |
| Avg | 11.3168 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051] BU 5886**
**Substation No/ Name :- 218029 / 220 KV KURKUMBH**
**Feeder No / Name : 400 / Auxilary**
**Feeder KV- 33 / OUTGOING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 5.6584 |
| Max | 5.6584 |
| Min | 5.6584 |
| Avg | 5.6584 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051]** **BU 5886**
**Substation No/ Name :- 218029 / 220 KV KURKUMBH**
**Feeder No / Name : 401 / 33KV OLD Cipla Express** **NON SHEDDABLE EXPRESS HV FEEDERS**
**Feeder KV- 33 / OUTGOING** **(CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 5.6584 |
| Max | 5.6584 |
| Min | 5.6584 |
| Avg | 5.6584 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051] BU 5886**
**Substation No/ Name :- 218029 / 220 KV KURKUMBH**
**Feeder No / Name : 402 / 33 KV PEARL EXP**
**Feeder KV- 33 / OUTGOING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 5.6584 |
| Max | 5.6584 |
| Min | 5.6584 |
| Avg | 5.6584 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051]** **BU 5886**
**Substation No/ Name :- 218029 / 220 KV KURKUMBH**
**Feeder No / Name : 403 / 33 KV Kedgaon** **NON SHEDDABLE EXPRESS HV FEEDERS**
**Feeder KV- 33 / OUTGOING** **(CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 11.3168 |
| Max | 11.3168 |
| Min | 11.3168 |
| Avg | 11.3168 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051]** **BU 5886**
**Substation No/ Name :- 218029 / 220 KV KURKUMBH**
**Feeder No / Name : 405 / 33KV New Cipla Express Feeder KV- 33 / OUTGOING** **NON SHEDDABLE EXPRESS HV FEEDERS (CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 5.6584 |
| Max | 5.6584 |
| Min | 5.6584 |
| Avg | 5.6584 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051] BU 5886**
**Substation No/ Name :- 218029 / 220 KV KURKUMBH**
**Feeder No / Name : 406 / 33KV Allik Amines Exp. NON SHEDDABLE EXPRESS HV FEEDERS**
**Feeder Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 5.6584 |
| Max | 5.6584 |
| Min | 5.6584 |
| Avg | 5.6584 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051] BU 5886**
**Substation No/ Name :- 218029 / 220 KV KURKUMBH**
**Feeder No / Name : 408 / 33 KV UNDAWADI (KP)**
**Feeder KV- 33 / INCOMING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 5.6584 |
| Max | 5.6584 |
| Min | 5.6584 |
| Avg | 5.6584 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051]** **BU 5886**
**Substation No/ Name :- 218029 / 220 KV KURKUMBH**
**Feeder No / Name : 409 / 33 KV KIRAN SOLAR** **NON SHEDDABLE EXPRESS HV FEEDERS**
**Feeder KV- 33 / OUTGOING** **(CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 5.6584 |
| Max | 5.6584 |
| Min | 5.6584 |
| Avg | 5.6584 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**DOUND[051]** **BU 5886**
**Substation No/ Name :- 218029 / 220 KV KURKUMBH**
**Feeder No / Name : 803 / 220kv Reliance Feeder** **NON SHEDDABLE EHV INDUSTRIAL FEEDERS**
**Feeder KV- 220 / OUTGOING** **(CONTINOUS PROCESS)(NO STAGGERING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 37.723 |
| Max | 37.723 |
| Min | 37.723 |
| Avg | 37.723 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214432 / 33/11 KV KEDGAON S/STN**
**Feeder No / Name : 201 / 11 kv kedgaon feeder SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6001 | .6135 | .7059 | .7186 | .6485 | .631 | .6878 |
| 2 | .6001 | .5258 | .6878 | .7186 | .6733 | .7888 | .8764 |
| 3 | .6173 | .4961 | .7343 | .7186 | .7059 | 1.0517 | 1.1963 |
| 4 | .6516 | .5201 | .7316 | .7362 | .724 | 1.1393 | 1.4118 |
| 5 | .6859 | .6173 | .8059 | .7802 | .7602 | 1.1919 | 1.5775 |
| 6 | .8402 | | .8596 | .8322 | .788 | 1.3696 | 1.6991 |
| 7 | .8573 | .8402 | .9412 | .9465 | .8775 | 1.6644 | 1.7718 |
| 8 | .8573 | .8238 | .9774 | .9015 | .8682 | 1.7878 | 1.825 |
| 9 | .703 | .6516 | | .7628 | .8322 | 1.8176 | 1.9418 |
| 10 | .6859 | .724 | .8669 | .8059 | .8149 | .8322 | 1.6766 |
| 11 | 1.2146 | | 1.8204 | 1.7528 | 1.8724 | .7442 | .703 |
| 12 | 1.3599 | | 1.9418 | 2.0683 | 1.9418 | .6697 | .7373 |
| 13 | 1.6518 | | 2.0458 | 2.1325 | 2.0458 | .6024 | .703 |
| 14 | 1.587 | | 1.9071 | 2.1384 | 1.9591 | .6268 | .703 |
| 15 | 1.5061 | 1.7918 | 1.7684 | 2.1971 | 1.9765 | .6268 | .6859 |
| 16 | 1.5546 | | 1.6991 | 2.0805 | 1.8204 | .6556 | .6001 |
| 17 | 1.4575 | | 1.7164 | 2.0285 | 1.7511 | .8859 | .6687 |
| 18 | 1.4251 | 1.9004 | 1.7337 | 1.9845 | 1.6991 | 1.0136 | .7888 |
| 19 | .7362 | .9313 | .7975 | .9671 | .7628 | .8596 | .8573 |
| 20 | .703 | .905 | .7712 | .905 | .7802 | .8682 | .823 |
| 21 | .6859 | .8596 | .7537 | .8238 | .8149 | .8775 | .7888 |
| 22 | .6859 | .7964 | .7362 | .7964 | .7011 | .788 | .7716 |
| 23 | .6859 | .7602 | .7108 | .7442 | .631 | .7973 | .6859 |
| 24 | .6173 | .6344 | .6984 | .7108 | .7164 | .631 | .7421 |
| **Max** | **1.6518** | **1.9004** | **2.0458** | **2.1971** | **2.0458** | **1.8176** | **1.9418** |
| **Min** | **.6001** | **.4961** | **.6878** | **.7108** | **.631** | **.6024** | **.6001** |
| **Avg** | **.9571** | **.8466** | **1.1483** | **1.2188** | **1.1319** | **.9550** | **1.0384** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214432 / 33/11 KV KEDGAON S/STN**
**Feeder No / Name : 202 / 11 kv Dapodi feeder SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8059 | .7202 | .8869 | .9816 | .8954 | .9114 | .9231 |
| 2 | .8059 | .6859 | 1.0498 | .9816 | 1.1462 | .8764 | .8954 |
| 3 | .945 | 1.1336 | 1.4148 | 1.4737 | 1.6476 | .8764 | .8859 |
| 4 | 1.0669 | 1.3279 | 1.4327 | 1.5257 | 1.7737 | .8669 | .9412 |
| 5 | 1.2193 | 1.4899 | 1.6655 | 1.595 | 1.8099 | .9465 | .9774 |
| 6 | 1.4937 | 1.6004 | 2.0774 | 1.6297 | 2.1538 | 1.1789 | 1.0387 |
| 7 | 1.8442 | 1.8299 | 2.268 | 1.6297 | 2.2805 | 1.4723 | 1.0985 |
| 8 | 1.9966 | 2.1862 | 2.3487 | 1.7684 | 2.3405 | 1.1096 | 1.134 |
| 9 | 2.1262 | 2.0729 | | 1.8204 | 2.3232 | 1.0056 | 1.0631 |
| 10 | 2.0405 | .8688 | 2.5659 | .8869 | .9882 | .9671 | .9431 |
| 11 | .5144 | | .7455 | .8507 | .9536 | 1.9667 | 1.4937 |
| 12 | .5784 | | .7802 | .8326 | .8669 | 2.1735 | 1.7375 |
| 13 | .6516 | | | | .7975 | 2.2325 | 1.829 |
| 14 | .6485 | | .7975 | .8507 | .7716 | 2.2365 | 1.6918 |
| 15 | .6344 | .8962 | .8322 | .8145 | .7888 | 2.2436 | 1.6613 |
| 16 | .6344 | .905 | .8149 | .8507 | .7802 | 2.2539 | 1.4937 |
| 17 | .7373 | .8954 | | .9134 | .7545 | 2.1262 | 1.4022 |
| 18 | .8916 | 1.0454 | | 1.1584 | .9709 | 1.9845 | 1.448 |
| 19 | 1.0631 | 1.1041 | .9536 | 1.267 | 1.1616 | 1.134 | 1.0117 |
| 20 | 1.0288 | 1.0679 | .9709 | 1.2357 | 1.0749 | 1.1462 | .9774 |
| 21 | .9602 | 1.0498 | .9882 | 1.0924 | 1.0341 | 1.0808 | .9602 |
| 22 | .9259 | 1.0136 | .964 | 1.0277 | .9991 | 1.0387 | .9431 |
| 23 | .8916 | .9412 | .9816 | 1.0136 | .9114 | 1.0136 | .9259 |
| 24 | .823 | .8573 | .905 | .9816 | .9774 | .9114 | .9774 |
| **Max** | **2.1262** | **2.1862** | **2.5659** | **1.8204** | **2.3405** | **2.2539** | **1.829** |
| **Min** | **.5144** | **.6859** | **.7455** | **.8145** | **.7545** | **.8669** | **.8859** |
| **Avg** | **1.0553** | **1.1846** | **1.2722** | **1.1818** | **1.2584** | **1.4064** | **1.1856** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214432 / 33/11 KV KEDGAON S/STN**
**Feeder No / Name : 203 / 11 Kv Handalwadi SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6001 | .6135 | .7059 | .7282 | .691 | .6661 | .6154 |
| 2 | .6687 | .5487 | .7059 | .7282 | .6697 | .8589 | .8238 |
| 3 | .7202 | .5144 | .724 | .7186 | .7964 | .9709 | .9362 |
| 4 | .7545 | .463 | .7362 | .7186 | .8507 | 1.1393 | 1.0923 |
| 5 | .8059 | .6516 | .8238 | .9015 | .9145 | 1.1789 | 1.2269 |
| 6 | .8573 | .8573 | .905 | .9362 | .9671 | 1.283 | 1.283 |
| 7 | 1.0117 | 1.0692 | .9955 | .9882 | 1.0387 | 1.5083 | 1.491 |
| 8 | .8916 | .8916 | .9774 | .9015 | 1.0317 | 1.4918 | 1.6124 |
| 9 | .8402 | .8745 | | .7802 | .9568 | 1.4918 | 1.6651 |
| 10 | .6859 | .905 | .9362 | .7712 | .9015 | .7087 | 1.4327 |
| 11 | 1.1336 | | 1.8204 | 1.7337 | 1.7164 | .6201 | |
| 12 | 1.1822 | | 1.9071 | 2.0683 | 1.8551 | .5731 | .5658 |
| 13 | 1.7124 | | 1.9765 | 2.1085 | 1.9418 | .5373 | .5316 |
| 14 | 1.7814 | | 1.8898 | 1.9982 | 1.9071 | .5611 | .6516 |
| 15 | 1.7328 | 1.9313 | 1.8551 | 2.0157 | 1.8378 | .5552 | .5144 |
| 16 | 1.749 | 1.9313 | 1.7857 | 1.9806 | 1.6991 | .5552 | .4458 |
| 17 | 1.7004 | 1.949 | 1.7661 | 1.9071 | 1.647 | .6733 | .6001 |
| 18 | 1.5061 | 1.893 | 1.7857 | 1.9313 | 1.595 | .7796 | .7545 |
| 19 | | .8869 | .7802 | .8859 | .7802 | .8859 | .7373 |
| 20 | .6859 | .8507 | .7712 | .8954 | .7802 | .8145 | .7202 |
| 21 | .6344 | .7783 | .7537 | .8145 | .7802 | .724 | .6097 |
| 22 | .6687 | .7164 | .7455 | .788 | .7282 | .6733 | .6516 |
| 23 | .6516 | .7421 | .7362 | .7783 | .6661 | .6626 | .6859 |
| 24 | .6173 | .6344 | .7164 | .7362 | .7087 | .6661 | .6697 |
| **Max** | **1.7814** | **1.949** | **1.9765** | **2.1085** | **1.9418** | **1.5083** | **1.6651** |
| **Min** | **.6001** | **.463** | **.7059** | **.7186** | **.6661** | **.5373** | **.4458** |
| **Avg** | **1.0257** | **.9851** | **1.1652** | **1.2006** | **1.1442** | **.8575** | **.8833** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214432 / 33/11 KV KEDGAON S/STN**
**Feeder No / Name : 204 / 11 KV KADETHAN SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8059 | .6173 | .7964 | .7186 | .7973 | .8764 | .8507 |
| 2 | .8059 | .5144 | .7964 | .7186 | .8869 | .8764 | .7964 |
| 3 | 1.2955 | .9069 | 1.6289 | 1.5604 | 1.134 | .8669 | .8238 |
| 4 | 1.3717 | 1.1336 | 1.6655 | 1.5604 | 1.7375 | .9114 | .8954 |
| 5 | 1.5242 | 1.6194 | 1.9313 | 1.647 | 1.7364 | .9362 | .9774 |
| 6 | 1.7375 | 1.8023 | 2.1616 | 1.9071 | 2.1085 | 1.0749 | 1.1584 |
| 7 | 1.9814 | 2.0243 | 2.2502 | 2.1325 | 2.3034 | 1.3176 | 1.267 |
| 8 | 2.0424 | 1.8884 | 2.2624 | 2.2018 | 2.392 | 1.2003 | .1086 |
| 9 | 1.89 | 1.8947 | | 2.2885 | 2.3211 | 1.0749 | 1.0631 |
| 10 | 1.9919 | .9412 | .9362 | 1.0166 | .8669 | 1.0277 | .9602 |
| 11 | .6344 | | .8669 | .9955 | .8669 | 2.3059 | 1.8747 |
| 12 | .6859 | | .8322 | 1.0387 | .9015 | 2.6699 | 2.21 |
| 13 | .703 | | .8495 | 1.0566 | .9362 | 2.9127 | 2.1033 |
| 14 | .7373 | | .8495 | .8669 | .9536 | 2.8349 | 2.1643 |
| 15 | | .8869 | .8495 | .8939 | .9362 | 2.8086 | 2.0424 |
| 16 | .7373 | .8688 | .8669 | .9412 | .9709 | 2.7566 | 2.1033 |
| 17 | .7716 | .8328 | .9362 | | 1.0056 | 2.8045 | 1.9357 |
| 18 | .8916 | 1.1104 | 1.0229 | 1.2489 | 1.0749 | 2.7694 | 1.9662 |
| 19 | 1.0288 | 1.1946 | 1.0229 | 1.2894 | 1.1443 | 1.086 | 1.046 |
| 20 | .964 | 1.134 | 1.0056 | 1.2178 | 1.0576 | 1.0387 | .9945 |
| 21 | .8745 | 1.086 | 1.0166 | 1.086 | .9816 | .9492 | .8916 |
| 22 | .7888 | 1.0317 | .8764 | .9774 | .929 | .9134 | .823 |
| 23 | .7373 | .9231 | .7186 | .9134 | .8764 | .905 | .7888 |
| 24 | .7888 | .6859 | .8145 | .7186 | .905 | .8764 | .8869 |
| **Max** | **2.0424** | **2.0243** | **2.2624** | **2.2885** | **2.392** | **2.9127** | **2.21** |
| **Min** | **.6344** | **.5144** | **.7186** | **.7186** | **.7973** | **.8669** | **.1086** |
| **Avg** | **1.1213** | **1.1548** | **1.1720** | **1.2607** | **1.2427** | **1.5747** | **1.2805** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214432 / 33/11 KV KEDGAON S/STN**
**Feeder No / Name : 205 / Dairy Industrial SHEDDABLE FEEDER HAVING WEEKLY**
**Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .061 | .029 | .0543 | .0526 | .0543 | .0701 | .0532 |
| 2 | .061 | .0452 | .0537 | .0526 | .0543 | .0526 | .0537 |
| 3 | .061 | .0149 | .0543 | .052 | .0543 | .0526 | .0532 |
| 4 | .0457 | .0297 | .0543 | .052 | .0724 | .0526 | .0543 |
| 5 | .0457 | .0457 | .0526 | .052 | .0537 | .0693 | .0709 |
| 6 | .0457 | .0286 | .0543 | .0526 | .0537 | .0693 | .0532 |
| 7 | .0457 | .0457 | .0724 | .052 | .0709 | .0693 | .0724 |
| 8 | .061 | .0286 | .0724 | .052 | .0724 | .0693 | .0532 |
| 9 | .0305 | .061 | .0693 | .0693 | .0724 | .0686 | .0709 |
| 10 | .0429 | .0716 | .0693 | .1086 | | .1267 | .0762 |
| 11 | .0762 | | | .1448 | .0867 | .1772 | .1219 |
| 12 | .0594 | | .0693 | .0905 | .0867 | .1254 | .061 |
| 13 | .0429 | | | .0905 | .0867 | .1063 | .061 |
| 14 | .061 | | .0693 | .1075 | .0693 | .0905 | .061 |
| 15 | .061 | .0724 | .0693 | .0895 | .0867 | .0895 | .0457 |
| 16 | .0594 | .0724 | .0693 | .0724 | .0867 | .1075 | .061 |
| 17 | .061 | .0362 | .052 | .1086 | .0693 | .0886 | .0305 |
| 18 | .0457 | .0549 | .052 | .0895 | .0693 | .0709 | .0457 |
| 19 | .061 | .0543 | .0526 | .1086 | .0693 | .0724 | .0457 |
| 20 | .0762 | .0724 | .052 | .0905 | .0693 | .0716 | .0457 |
| 21 | .0914 | .0716 | .052 | .0732 | .0693 | .0724 | .061 |
| 22 | .061 | .0724 | .0701 | .0716 | .0701 | .0716 | .061 |
| 23 | .0457 | .0724 | .0701 | .0716 | .0693 | .0724 | .061 |
| 24 | .061 | .0286 | .0724 | .0526 | .0724 | .0701 | .0543 |
| **Max** | **.0914** | **.0724** | **.0724** | **.1448** | **.0867** | **.1772** | **.1219** |
| **Min** | **.0305** | **.0149** | **.052** | **.052** | **.0537** | **.0526** | **.0305** |
| **Avg** | **.0568** | **.0504** | **.0617** | **.0774** | **.0704** | **.0828** | **.0595** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214432 / 33/11 KV KEDGAON S/STN**
**Feeder No / Name : 206 / 22 FATA SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6173 | .4801 | .543 | | .5792 | .5895 | .5316 |
| 2 | .5487 | .4382 | .543 | | .543 | 1.0517 | .7973 |
| 3 | .583 | .3772 | .6154 | | .724 | 1.1393 | .9671 |
| 4 | .6173 | .4973 | .6516 | | .7964 | 1.1919 | 1.2357 |
| 5 | .7716 | .6001 | .7602 | | .8954 | 1.262 | 1.3112 |
| 6 | .9602 | .7282 | .8775 | | 1.0498 | 1.5074 | 1.5769 |
| 7 | 1.0974 | .8916 | 1.086 | | 1.1222 | 1.8551 | 1.773 |
| 8 | .8916 | .9774 | 1.0029 | .9536 | 1.0679 | 1.9105 | 2.1262 |
| 9 | .7888 | .823 | | .7802 | .9774 | 1.9033 | 2.1845 |
| 10 | | .7964 | .9015 | .7164 | .9536 | .7059 | 1.829 |
| 11 | | | 1.9071 | 1.7528 | 1.8204 | .5792 | .5487 |
| 12 | 1.4899 | | 1.9938 | 2.1262 | 1.8551 | .543 | .1715 |
| 13 | 1.8299 | | 2.0805 | 2.2085 | 1.9071 | .5068 | .5144 |
| 14 | 1.9006 | | 2.0631 | 2.3743 | 2.0805 | | .5316 |
| 15 | 1.8724 | 2.1439 | 2.0631 | 2.3565 | 2.1152 | .5249 | .5658 |
| 16 | 1.8947 | 2.1176 | 2.0631 | 2.1735 | 2.0285 | .5249 | .5487 |
| 17 | 1.9595 | 1.8959 | 1.9418 | 2.0631 | 1.9418 | .6516 | .6516 |
| 18 | 1.9433 | 2.0553 | 1.8204 | 1.9281 | 1.9071 | .8326 | .703 |
| 19 | .8059 | .8869 | 1.0056 | .8326 | .7455 | .9134 | .8573 |
| 20 | .7202 | .8145 | .9015 | .788 | .6935 | .8417 | .823 |
| 21 | .6516 | .7164 | .7362 | .724 | .6485 | .788 | .7716 |
| 22 | .6173 | .6878 | .6661 | .724 | .6068 | .7522 | .703 |
| 23 | .5658 | .6154 | .5959 | .7059 | .5959 | .724 | .6859 |
| 24 | .6516 | .5144 | .5792 | | .6878 | .5959 | .6379 |
| **Max** | **1.9595** | **2.1439** | **2.0805** | **2.3743** | **2.1152** | **1.9105** | **2.1845** |
| **Min** | **.5487** | **.3772** | **.543** | **.7059** | **.543** | **.5068** | **.1715** |
| **Avg** | **1.0808** | **.9529** | **1.1912** | **1.4505** | **1.1809** | **.9519** | **.9603** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214432 / 33/11 KV KEDGAON S/STN**
**Feeder No / Name : 208 / SHRI.SWAMI SAMARTH GAOTHAN FEEDER**
**GAONTHAN Feeder KV- 11 /**
**OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5792 | .643 | .8145 | .8063 | .8328 | .8764 | .8682 |
| 2 | .5792 | .6097 | .8145 | .8063 | .8505 | .8669 | .815 |
| 3 | .6097 | .571 | .9774 | .7802 | .8869 | .9114 | .8859 |
| 4 | .6401 | .7888 | 1.086 | .7802 | .9568 | .9114 | .9362 |
| 5 | .7926 | .8173 | 1.1641 | .9015 | 1.086 | 1.0166 | 1.134 |
| 6 | .9602 | 1.0059 | 1.2536 | 1.0749 | 1.1584 | 1.1919 | 1.2483 |
| 7 | 1.2955 | 1.1717 | 1.382 | 1.2483 | 1.4842 | 1.387 | 1.4706 |
| 8 | 1.2346 | 1.2955 | 1.5947 | 1.283 | 1.5249 | 1.2136 | 1.5592 |
| 9 | 1.1736 | 1.2346 | | 1.3176 | 1.5384 | 1.3032 | 1.4883 |
| 10 | 1.0848 | 1.3112 | 1.387 | 1.3253 | 1.387 | 1.2715 | 1.0669 |
| 11 | .9556 | | 1.2136 | 1.2483 | 1.283 | 1.2127 | 1.0669 |
| 12 | .7926 | | 1.1616 | 1.1963 | 1.166 | 1.1584 | .8688 |
| 13 | .945 | | 1.1096 | 1.2048 | 1.0402 | 1.1222 | .8078 |
| 14 | .945 | | 1.1096 | 1.1096 | 1.0802 | 1.1462 | .7468 |
| 15 | .9145 | 1.5927 | | 1.1218 | 1.0749 | 1.0924 | .8383 |
| 16 | .8573 | 1.4175 | 1.0749 | 1.2178 | 1.0576 | 1.0985 | .8383 |
| 17 | 1.0364 | 1.4118 | 1.0402 | 1.2403 | 1.0402 | 1.1584 | .9297 |
| 18 | 1.1584 | 1.5746 | | 1.3611 | 1.0923 | 1.2403 | 1.0974 |
| 19 | 1.3108 | 1.647 | 1.0749 | 1.4661 | 1.1616 | 1.4327 | 1.2346 |
| 20 | 1.1431 | 1.5203 | 1.1096 | 1.3394 | 1.1043 | 1.3073 | 1.1888 |
| 21 | 1.0059 | 1.2851 | 1.1443 | 1.2048 | 1.0517 | 1.1871 | 1.0974 |
| 22 | .8535 | 1.1584 | .9816 | 1.1222 | .964 | 1.1222 | .8688 |
| 23 | .823 | .8869 | .8063 | 1.0029 | .8669 | 1.0136 | .7316 |
| 24 | .5944 | .7621 | .8326 | .8063 | .905 | .8764 | .9214 |
| **Max** | **1.3108** | **1.647** | **1.5947** | **1.4661** | **1.5384** | **1.4327** | **1.5592** |
| **Min** | **.5792** | **.571** | **.8063** | **.7802** | **.8328** | **.8669** | **.7316** |
| **Avg** | **.9285** | **1.1353** | **1.1016** | **1.1236** | **1.1081** | **1.1299** | **1.0296** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214442 / 33/11 KV SHAJPUR S/STN**
**Feeder No / Name : 201 / 11 kv Grant Apparel SHEDDABLE FEEDER HAVING WEEKLY**
**Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.5789 | 1.7909 | 1.2765 | 2.0957 | 2.1529 | 1.8099 | 1.9052 |
| 2 | 2.4977 | 1.6956 | 1.2955 | 2.0767 | 2.1148 | 1.7909 | 1.8671 |
| 3 | | 1.6956 | 1.2955 | 2.1148 | 1.9805 | 1.7528 | 1.829 |
| 4 | 2.1795 | 1.6385 | 1.2384 | 2.037 | 1.9805 | 1.7528 | 1.7528 |
| 5 | 2.1464 | 1.6004 | 1.2003 | 2.1148 | 1.9993 | 1.7337 | 1.6956 |
| 6 | 2.1348 | 1.5623 | 1.4861 | 1.9978 | 1.9418 | 1.6956 | 1.7737 |
| 7 | 2.1765 | 1.5432 | 1.5844 | 1.9805 | 2.0538 | 1.829 | 1.9589 |
| 8 | 2.1643 | 1.5623 | 2.5393 | 2.5206 | 2.2032 | 2.4143 | 2.4086 |
| 9 | 2.524 | 1.8111 | 2.8567 | 2.8959 | 2.5766 | 2.5953 | 2.6155 |
| 10 | 2.3891 | 1.7177 | 2.8166 | 2.9321 | 2.3152 | 2.6606 | 2.9447 |
| 11 | 2.4691 | 1.6817 | 3.1093 | 2.8715 | 2.4086 | 2.8166 | 3.095 |
| 12 | 2.0233 | 1.2136 | 2.7511 | 2.3152 | 2.1845 | 2.3285 | 2.5158 |
| 13 | 2.2291 | 1.3817 | 3.0178 | 2.584 | 2.2405 | 2.5882 | 3.1459 |
| 14 | 2.6063 | 1.9605 | 2.8121 | 2.5579 | 2.4459 | 2.914 | 2.8715 |
| 15 | 2.8416 | 1.7353 | 2.5892 | 2.5158 | 2.3899 | 2.7149 | 2.5789 |
| 16 | 2.9813 | 1.448 | 2.7949 | 2.3663 | 2.2148 | 2.7149 | 2.9264 |
| 17 | 2.8898 | 1.5497 | 2.7606 | 2.4348 | 2.2592 | 2.7873 | 3.006 |
| 18 | 2.7244 | 1.4523 | 2.7511 | 2.915 | 2.553 | 2.6783 | 2.915 |
| 19 | 2.6863 | 1.5432 | 2.4577 | 2.4579 | 2.4196 | 2.4577 | 2.7435 |
| 20 | 1.9243 | 1.3146 | 1.8671 | 2.0351 | 1.8099 | 2.0957 | 1.9433 |
| 21 | 2.4196 | 1.2955 | 2.4196 | 2.4958 | 2.0195 | 2.3434 | 2.3148 |
| 22 | 2.5149 | 1.5051 | 2.6101 | 2.5911 | 2.0576 | 2.4768 | 2.3053 |
| 23 | 2.4577 | 1.2384 | 2.572 | 2.4006 | 2.0195 | 2.2862 | 2.4006 |
| 24 | 2.5591 | 2.21 | 1.2574 | 2.2862 | 2.1719 | 1.9052 | 2.0957 |
| **Max** | **2.9813** | **2.21** | **3.1093** | **2.9321** | **2.5766** | **2.914** | **3.1459** |
| **Min** | **1.9243** | **1.2136** | **1.2003** | **1.9805** | **1.8099** | **1.6956** | **1.6956** |
| **Avg** | **2.4399** | **1.5895** | **2.2233** | **2.3997** | **2.1880** | **2.2976** | **2.4004** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214442 / 33/11 KV SHAJPUR S/STN**
**Feeder No / Name : 202 / sahajpur GFSS GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0895 | .1143 | .0953 | .1143 | .0953 | .0953 | .0953 |
| 2 | .0905 | .1143 | .0953 | .1143 | .0953 | .0953 | .0953 |
| 3 | | .1143 | .1143 | .1143 | .1143 | .1334 | .1143 |
| 4 | .1341 | .1334 | .1524 | .1132 | .1509 | .1524 | .1334 |
| 5 | .1475 | .1715 | .1715 | .1715 | | .1524 | .1715 |
| 6 | .2056 | .2477 | .2858 | .2614 | | .2667 | .2801 |
| 7 | .2401 | .3048 | .3018 | .2829 | .2801 | .3048 | .2957 |
| 8 | .1829 | .2286 | .2241 | .2241 | .2427 | .2075 | .168 |
| 9 | .1753 | .168 | .1867 | .1448 | .168 | .168 | .1646 |
| 10 | .181 | .1494 | .2012 | .1086 | .1307 | .1448 | .1097 |
| 11 | .12 | .1294 | .1097 | .0914 | .0934 | .1097 | .0905 |
| 12 | .1372 | .0934 | .0905 | .0934 | .0747 | .1109 | .0905 |
| 13 | .12 | .112 | .128 | .0943 | .0747 | .1086 | .1097 |
| 14 | .0686 | .1307 | .0857 | .0747 | .0747 | .0905 | .0914 |
| 15 | | .0876 | .0857 | .0905 | .0747 | .0905 | .0914 |
| 16 | .128 | .1267 | .0857 | .0857 | .0709 | .1086 | .0914 |
| 17 | .1646 | .168 | .1029 | .1029 | .112 | .1267 | .112 |
| 18 | .1334 | .2075 | .1629 | .1334 | .1334 | .1698 | .1715 |
| 19 | .2096 | .1905 | .1905 | .1848 | .1524 | .1524 | .1905 |
| 20 | .1715 | .1715 | .1715 | .1494 | .1524 | .1334 | .1715 |
| 21 | .1334 | .1334 | .1334 | .1334 | .1334 | .1143 | .1372 |
| 22 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 | .1334 |
| 23 | .1143 | .0953 | .1143 | .1143 | .1143 | .1143 | .1143 |
| 24 | .1052 | .1143 | .0953 | .1143 | .0953 | .0953 | .0953 |
| **Max** | **.2401** | **.3048** | **.3018** | **.2829** | **.2801** | **.3048** | **.2957** |
| **Min** | **.0686** | **.0876** | **.0857** | **.0747** | **.0709** | **.0905** | **.0905** |
| **Avg** | **.1439** | **.1509** | **.1458** | **.1344** | **.1249** | **.1400** | **.1383** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214442 / 33/11 KV SHAJPUR S/STN**
**Feeder No / Name : 203 / 11 Kv Khamgaon GFSS GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.97 | 2.4006 | 2.5149 | 2.5149 | 2.2862 | .9717 | .9717 |
| 2 | 1.9204 | 2.4577 | 2.572 | 2.5339 | 2.3434 | .9717 | 1.0288 |
| 3 | | 2.4577 | 2.6863 | 2.572 | 2.3765 | 1.1431 | 1.0288 |
| 4 | 1.7147 | 2.5149 | 2.8578 | 2.7161 | 2.4897 | 1.4289 | 1.1431 |
| 5 | 2.0008 | 2.7435 | 2.9721 | 2.7625 | 2.7161 | 1.6004 | 1.3717 |
| 6 | 2.2377 | 2.8578 | 3.4294 | 3.0247 | 2.9687 | 1.7718 | 1.4003 |
| 7 | 2.6825 | 3.0483 | 3.5056 | 3.2442 | 3.006 | 1.6575 | 1.423 |
| 8 | 2.5987 | 3.0864 | | 2.4272 | 2.894 | 1.5089 | 1.251 |
| 9 | 1.0164 | 1.1203 | 1.9418 | 1.086 | 1.2323 | 1.2323 | 1.0059 |
| 10 | | .9896 | 1.4998 | 1.0679 | 1.0829 | .9593 | .9335 |
| 11 | .8745 | .2218 | 1.39 | .9694 | 1.0456 | 2.5972 | 2.3529 |
| 12 | .8402 | .9896 | 1.3394 | .9896 | .9896 | 2.6612 | 2.6063 |
| 13 | .6687 | 1.0098 | 1.2986 | .9431 | .9149 | 2.6244 | 2.5789 |
| 14 | .7545 | .9709 | 1.1145 | .9709 | .8962 | 2.6606 | 2.5423 |
| 15 | .8326 | .964 | 1.0117 | .1629 | .9522 | 2.4796 | 2.2497 |
| 16 | | .9231 | 1.1488 | .1543 | .8328 | 2.552 | 2.6886 |
| 17 | | .9709 | 1.2174 | .1886 | .8962 | 2.4434 | 2.9313 |
| 18 | 1.2193 | 1.1694 | 1.6651 | .362 | 1.1812 | 2.6972 | 2.6101 |
| 19 | 1.4861 | 1.3908 | 1.4289 | 1.4784 | 1.4289 | 1.2955 | 1.3908 |
| 20 | 1.3146 | 1.3717 | 1.3717 | 1.363 | 1.3146 | 1.2765 | 1.2955 |
| 21 | 1.2765 | 1.2955 | 1.2955 | 1.3336 | 1.2765 | 1.2574 | 1.0974 |
| 22 | 1.1431 | 1.1241 | 1.2574 | 1.2003 | 1.1431 | 1.1431 | 1.1622 |
| 23 | 2.4577 | 2.4768 | 2.4577 | 2.2291 | 1.0288 | 1.0288 | 1.086 |
| 24 | 1.9765 | 2.4006 | 2.5149 | 2.5149 | 2.2862 | 1.0098 | .9717 |
| **Max** | **2.6825** | **3.0864** | **3.5056** | **3.2442** | **3.006** | **2.6972** | **2.9313** |
| **Min** | **.6687** | **.2218** | **1.0117** | **.1543** | **.8328** | **.9593** | **.9335** |
| **Avg** | **1.5493** | **1.7065** | **1.9344** | **1.6171** | **1.6493** | **1.7072** | **1.6301** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214442 / 33/11 KV SHAJPUR S/STN**
**Feeder No / Name : 401 / 33kv Shakti Roofing SHEDDABLE FEEDER HAVING WEEKLY**
**Feeder KV- 33 / OUTGOING STAGGERING (MIDC, EQUIVALENT)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.7193 | 2.0005 | 1.6004 | 1.6575 | 2.0576 | 1.829 | 1.829 |
| 2 | | 2.0576 | 1.5432 | 1.6575 | 1.829 | 1.8861 | 1.7718 |
| 3 | | 2.1148 | 1.5432 | 1.5432 | 1.9239 | 1.7718 | 1.8861 |
| 4 | 1.286 | 2.0576 | 1.6004 | 1.5844 | 2.037 | 1.829 | 1.6575 |
| 5 | 1.3226 | 1.7147 | 1.4861 | 1.6004 | 1.7924 | 1.829 | 1.7147 |
| 6 | 1.2431 | 1.7147 | 1.5432 | 1.5123 | 1.6244 | 1.7147 | 1.5123 |
| 7 | 1.358 | 1.7718 | 1.358 | 1.5432 | 1.5123 | 1.7718 | 1.386 |
| 8 | 1.0562 | 1.829 | 1.5123 | .8402 | 1.4003 | 1.6409 | 1.3443 |
| 9 | 1.7741 | 1.6804 | 1.7924 | .7602 | 1.3443 | 2.1845 | 1.9753 |
| 10 | 1.7918 | 1.8484 | 1.8107 | .6516 | 1.2323 | 1.9547 | 2.0302 |
| 11 | 1.4918 | 1.885 | 1.4815 | .823 | 1.2323 | 2.3594 | 1.7918 |
| 12 | 1.8519 | 2.0165 | 1.5746 | .8402 | 1.2883 | 2.2731 | 1.7375 |
| 13 | 1.286 | | 1.4815 | .7922 | 1.3443 | 1.6289 | 1.4661 |
| 14 | 1.9033 | | 1.3375 | .8402 | 1.6804 | 2.009 | 1.8107 |
| 15 | 1.9547 | 1.5775 | 1.6975 | .7716 | 1.7924 | 2.2805 | 1.9753 |
| 16 | 1.701 | 1.4661 | 1.8519 | .6687 | 1.7541 | 2.2262 | 1.9204 |
| 17 | 1.8107 | 1.5684 | 1.5432 | .823 | 1.7924 | 2.009 | 1.8484 |
| 18 | 2.0576 | 1.5278 | 1.6289 | 1.2574 | 1.8861 | 2.037 | 1.8861 |
| 19 | 1.9433 | 1.3717 | 1.6004 | 1.386 | 1.8861 | 1.8861 | 1.8861 |
| 20 | 1.9433 | 1.7147 | 1.6004 | 1.3443 | 1.829 | 1.829 | 1.8861 |
| 21 | 1.7147 | 1.7718 | 1.5432 | 1.4861 | 1.7718 | 1.7718 | 1.4403 |
| 22 | 2.2291 | 1.7147 | 1.6575 | 1.5432 | 1.829 | 1.8861 | 1.6004 |
| 23 | 2.1148 | 1.5432 | 1.7147 | 1.6004 | 1.8861 | 1.8861 | 1.7147 |
| 24 | 1.6124 | 2.0576 | 1.5432 | 1.7147 | 1.7147 | 1.829 | 1.829 |
| **Max** | **2.2291** | **2.1148** | **1.8519** | **1.7147** | **2.0576** | **2.3594** | **2.0302** |
| **Min** | **1.0562** | **1.3717** | **1.3375** | **.6516** | **1.2323** | **1.6289** | **1.3443** |
| **Avg** | **1.6894** | **1.7729** | **1.5852** | **1.2184** | **1.6850** | **1.9301** | **1.7458** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214443 / 33/11 KV RAHU S/STN**
**Feeder No / Name : 202 / 11 KV RAHU AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .5316 | .5316 | .5304 | | .5316 | |
| 2 | | .5487 | .5316 | .5304 | | .5316 | |
| 3 | | 1.4575 | .5658 | 1.3413 | | .5487 | |
| 4 | | 1.4575 | 1.3203 | 1.3592 | | .6173 | |
| 5 | | 1.4575 | 1.5775 | 1.4918 | | .6516 | |
| 6 | | 1.5775 | 1.6461 | 1.6057 | | .7373 | |
| 7 | | 1.6632 | 1.7318 | 1.6549 | | | .6859 |
| 8 | 1.5424 | 1.749 | 1.8347 | 1.8351 | 1.869 | | .6516 |
| 9 | | 1.7833 | 1.8347 | 1.8233 | 1.869 | | .5487 |
| 10 | | 1.7147 | 1.7833 | 1.7532 | 1.7661 | | .4287 |
| 11 | | .3429 | .3258 | .3561 | .3601 | | 1.9547 |
| 12 | | .3258 | .2652 | .2984 | .3429 | | 1.9547 |
| 13 | | .3086 | .2321 | .2622 | .3258 | | 1.9376 |
| 14 | | | .2347 | .2515 | .3258 | | 1.869 |
| 15 | | .2915 | .2458 | .2652 | .3258 | | 1.8519 |
| 16 | | .3086 | .2818 | | .3258 | | 1.8176 |
| 17 | | .3429 | .3277 | .3315 | .4801 | | 1.8519 |
| 18 | | .4801 | .4475 | .3978 | .5144 | | 1.7833 |
| 19 | | .4973 | .5079 | .5138 | .5316 | | .4801 |
| 20 | | .5144 | .5304 | | .5658 | | .5144 |
| 21 | | .5144 | .5426 | | .5658 | | .4973 |
| 22 | | .5144 | .5407 | .5407 | .5658 | | .4973 |
| 23 | | .5144 | | | .5487 | | .4801 |
| 24 | .5079 | .5144 | .5316 | .5571 | | .5487 | .5316 |
| **Max** | **1.5424** | **1.7833** | **1.8347** | **1.8351** | **1.869** | **.7373** | **1.9547** |
| **Min** | **.5079** | **.2915** | **.2321** | **.2515** | **.3258** | **.5316** | **.4287** |
| **Avg** | **1.0252** | **.8439** | **.7987** | **.8850** | **.7052** | **.5953** | **1.1298** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214443 / 33/11 KV RAHU S/STN**
**Feeder No / Name : 203 / 11 KV MADHAV NAGAR FEEDER SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6173 | .583 | .6203 | | .6173 | |
| 2 | .6173 | .6001 | .6299 | | .6173 | |
| 3 | .6173 | .6173 | .6443 | | 1.3203 | |
| 4 | .6516 | .6516 | .5898 | | 1.3889 | |
| 5 | .703 | .6859 | .6464 | | 1.4403 | |
| 6 | .6859 | .7202 | .639 | | 1.4918 | |
| 7 | .7202 | .7545 | .6874 | | | 1.4232 |
| 8 | .6859 | .6516 | .5967 | .6859 | | 1.4403 |
| 9 | .5487 | .5658 | .4915 | .6173 | | 1.3889 |
| 10 | .4287 | .463 | .431 | .4973 | | |
| 11 | 1.2346 | 1.286 | 1.1142 | | | .463 |
| 12 | 1.3889 | 1.4091 | 1.4089 | 1.5089 | | .463 |
| 13 | 1.4232 | 1.4251 | 1.4752 | 1.6461 | | .4287 |
| 14 | 1.4403 | 1.442 | 1.5089 | 1.6804 | | .4287 |
| 15 | 1.406 | 1.4251 | 1.4752 | 1.6461 | | .3944 |
| 16 | 1.4746 | 1.4255 | | 1.6289 | | .3944 |
| 17 | 1.4575 | 1.442 | 1.442 | 1.5775 | | .4287 |
| 18 | 1.406 | 1.442 | 1.4255 | 1.5432 | | .4973 |
| 19 | .583 | .5571 | .5735 | .5487 | | .5658 |
| 20 | .583 | .547 | | .583 | | .583 |
| 21 | .5658 | .5967 | | .6001 | | .583 |
| 22 | .583 | .5967 | .5898 | .6001 | | .583 |
| 23 | .583 | | | .6001 | | .583 |
| 24 | .6001 | .583 | .5735 | | .6001 | .6173 |
| **Max** | **1.4746** | **1.442** | **1.5089** | **1.6804** | **1.4918** | **1.4403** |
| **Min** | **.4287** | **.463** | **.431** | **.4973** | **.6001** | **.3944** |
| **Avg** | **.8752** | **.8900** | **.8782** | **1.0642** | **1.068** | **.6627** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214443 / 33/11 KV RAHU S/STN**
**Feeder No / Name : 204 / 11 Kv Patethan Feeder SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2401 | .2743 | .2785 | | .1886 | |
| 2 | .2401 | .2915 | .2713 | | .1886 | |
| 3 | 1.2346 | 1.2346 | 1.2431 | | .2401 | |
| 4 | 1.2517 | 1.286 | 1.2548 | | .3086 | |
| 5 | 1.286 | 1.3717 | 1.3413 | | .4115 | |
| 6 | 1.3717 | | 1.5074 | | .4973 | |
| 7 | 1.5947 | 1.6289 | 1.6956 | | | .6001 |
| 8 | 1.7661 | 1.869 | 1.8442 | | | .5144 |
| 9 | 1.7318 | 1.8176 | 1.7901 | | | .3601 |
| 10 | 1.6975 | 1.7147 | 1.7604 | | | |
| 11 | .3086 | .2915 | .285 | .2915 | | 1.7147 |
| 12 | .3258 | .2984 | .2984 | .3086 | | 1.869 |
| 13 | .3086 | .3353 | .3113 | .3086 | | |
| 14 | .0343 | .3315 | .3052 | .3086 | | 1.6461 |
| 15 | .2572 | .3812 | .2984 | .2743 | | 1.6804 |
| 16 | .3086 | .2012 | | .2572 | | 1.7833 |
| 17 | .3258 | .2622 | .3277 | .3086 | | 1.7661 |
| 18 | .4458 | .3812 | .4024 | .3944 | | 1.7833 |
| 19 | .463 | .3856 | .4372 | .4458 | | .3601 |
| 20 | .4287 | .3688 | | .4287 | | .3601 |
| 21 | .3944 | .3401 | | .3429 | | .3429 |
| 22 | .3086 | .2984 | .2984 | .2743 | | .3086 |
| 23 | .2401 | | | .2058 | | .2743 |
| 24 | .2229 | .2572 | .2818 | | .2058 | .2401 |
| **Max** | **1.7661** | **1.869** | **1.8442** | **.4458** | **.4973** | **1.869** |
| **Min** | **.0343** | **.2012** | **.2713** | **.2058** | **.1886** | **.2401** |
| **Avg** | **.6994** | **.7100** | **.8116** | **.3192** | **.2915** | **.9752** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214443 / 33/11 KV RAHU S/STN**
**Feeder No / Name : 205 / 11 KV TELE WADI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6859 | .583 | .7042 | | .5658 | |
| 2 | .7202 | .6001 | .6874 | | .5487 | |
| 3 | .7373 | .6687 | .6706 | | 2.452 | |
| 4 | .8059 | .7202 | .6783 | | 2.6063 | |
| 5 | .9602 | .9945 | .852 | | 2.7092 | |
| 6 | 1.0631 | 1.1317 | 1.046 | | 2.8464 | |
| 7 | 1.2517 | 1.2003 | 1.1869 | | | 2.8464 |
| 8 | 1.2003 | 1.0802 | 1.0343 | 1.0631 | | 2.915 |
| 9 | .7716 | .9259 | .8383 | .8916 | | 2.7949 |
| 10 | .8059 | .7716 | .8619 | .7545 | | 2.4177 |
| 11 | 2.915 | 2.915 | 2.7639 | 2.7949 | | .6516 |
| 12 | 3.6008 | 3.315 | 3.315 | 3.0521 | | .6859 |
| 13 | 3.5665 | 3.4642 | 3.6456 | 3.2407 | | .6516 |
| 14 | 3.5151 | 3.5208 | 3.5471 | 3.5322 | | .6687 |
| 15 | 3.3436 | 3.5637 | 3.4408 | 3.3436 | | .6859 |
| 16 | 3.4294 | 3.6466 | | 3.2579 | | .7373 |
| 17 | 3.3608 | | 3.437 | 3.2579 | | .8059 |
| 18 | 3.2922 | 3.152 | 3.2653 | 3.2065 | | .8745 |
| 19 | .7202 | .7969 | .8192 | .7373 | | .823 |
| 20 | .6859 | .7459 | | | | .7888 |
| 21 | .6687 | .7042 | | .6516 | | .7202 |
| 22 | .583 | .6796 | .6718 | .6173 | | .7202 |
| 23 | .5487 | | | .6001 | | .7202 |
| 24 | .6687 | .583 | .7045 | | .583 | .7545 |
| **Max** | **3.6008** | **3.6466** | **3.6456** | **3.5322** | **2.8464** | **2.915** |
| **Min** | **.5487** | **.583** | **.6706** | **.6001** | **.5487** | **.6516** |
| **Avg** | **1.6625** | **1.6256** | **1.7085** | **2.0668** | **1.7588** | **1.1812** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214443 / 33/11 KV RAHU S/STN**
**Feeder No / Name : 206 / 11 kv SOMESHWAR FEEDER SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1187 | .1029 | .116 | | .0857 | |
| 2 | .1357 | | .116 | | .0857 | |
| 3 | 1.8347 | 1.9376 | 2.0178 | | .1029 | |
| 4 | 1.8861 | 2.0748 | 2.1195 | | .1029 | |
| 5 | 2.0576 | 2.1262 | 2.0972 | | .1029 | |
| 6 | 2.1434 | 2.1605 | 2.323 | | .1029 | |
| 7 | 2.1948 | 2.2119 | 2.2939 | | | .1357 |
| 8 | | 2.332 | 2.3266 | 2.2634 | | .12 |
| 9 | 2.3148 | 2.3663 | 2.4366 | 2.2805 | | .0857 |
| 10 | 2.3834 | 2.3663 | 2.6023 | 2.4006 | | .1029 |
| 11 | .0686 | .0686 | .0829 | .0686 | | 2.3834 |
| 12 | .0686 | .0663 | .0648 | .0686 | | 2.7435 |
| 13 | .0686 | .0663 | .0663 | .0686 | | 2.7263 |
| 14 | .0857 | .0655 | .0648 | .0686 | | 2.7778 |
| 15 | .0514 | | .0655 | .0686 | | 2.8121 |
| 16 | .0686 | | | .0857 | | 2.8635 |
| 17 | .0686 | | .0829 | .1029 | | 2.7092 |
| 18 | .0857 | .0829 | .0819 | .1029 | | 2.7092 |
| 19 | .0857 | .116 | .0995 | .1029 | | .1029 |
| 20 | .0857 | .1147 | | .12 | | .12 |
| 21 | .0857 | .0995 | | .1372 | | .1372 |
| 22 | .1029 | .1006 | .116 | .1543 | | .12 |
| 23 | .1029 | | | .12 | | .12 |
| 24 | .1017 | .1029 | .0995 | | .1029 | .1187 |
| **Max** | **2.3834** | **2.3663** | **2.6023** | **2.4006** | **.1029** | **2.8635** |
| **Min** | **.0514** | **.0655** | **.0648** | **.0686** | **.0857** | **.0857** |
| **Avg** | **.7043** | **.9769** | **.9637** | **.5133** | **.0980** | **1.2716** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214443 / 33/11 KV RAHU S/STN**
**Feeder No / Name : 207 / 11 Kv Walaki SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .3772 | .4115 | .3441 | | .3772 | |
| 2 | | .3944 | .4115 | .3647 | | .3772 | |
| 3 | | .4287 | .4115 | .3605 | | 2.4348 | |
| 4 | | .4801 | .4801 | .4191 | | 2.4691 | |
| 5 | | .5144 | .5487 | .4807 | | 2.5034 | |
| 6 | | .5487 | .6344 | .5636 | | 2.5549 | |
| 7 | | .6344 | .6859 | .6443 | | | 2.7949 |
| 8 | | .583 | .5658 | .5365 | .5144 | | 2.7949 |
| 9 | | .4287 | .4458 | .3647 | .3944 | | 2.7949 |
| 10 | | .3772 | .3601 | .3932 | .3258 | | 2.6578 |
| 11 | | 2.9664 | 3.1893 | 2.9504 | 2.915 | | .2229 |
| 12 | | 3.3265 | 3.195 | 3.1017 | 3.0521 | | .2401 |
| 13 | | 3.5665 | 3.4252 | 3.2386 | 3.2407 | | .2058 |
| 14 | | 3.6523 | 3.3316 | 3.315 | 3.275 | | .2401 |
| 15 | | 3.4294 | 3.3573 | 3.3425 | 3.2407 | | .2401 |
| 16 | | 3.4979 | 3.1824 | | 3.1722 | | .2572 |
| 17 | | 3.5665 | 3.1855 | 3.315 | 3.0521 | | .3772 |
| 18 | | 3.4294 | 3.2217 | 3.2861 | 3.0007 | | .3772 |
| 19 | | .4973 | .4144 | .4807 | .4287 | | .4458 |
| 20 | | .4458 | .3932 | | .4801 | | .4287 |
| 21 | | .4115 | .407 | | .4458 | | .4115 |
| 22 | | .3944 | .3647 | .3978 | .3944 | | .4115 |
| 23 | | .3944 | | | .3944 | | .3772 |
| 24 | .3647 | .3772 | .4115 | .3441 | | .3772 | .3772 |
| **Max** | **.3647** | **3.6523** | **3.4252** | **3.3425** | **3.275** | **2.5549** | **2.7949** |
| **Min** | **.3647** | **.3772** | **.3601** | **.3441** | **.3258** | **.3772** | **.2058** |
| **Avg** | **.3647** | **1.4468** | **1.4363** | **1.4122** | **1.7704** | **1.5848** | **.8697** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214443 / 33/11 KV RAHU S/STN**
**Feeder No / Name : 208 / 11 Kv Bafna Express SHEDDABLE FEEDER HAVING WEEKLY**
**Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)**

| DATE | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0509 | .0514 | .0497 | | .0514 | |
| 2 | .0509 | .0514 | .0492 | | .0514 | |
| 3 | .0509 | .0514 | .0503 | | .0514 | |
| 4 | .0509 | .0514 | .0497 | | .0514 | |
| 5 | .0509 | .0514 | .0492 | | .0514 | |
| 6 | .0509 | .0514 | .0497 | | .0514 | |
| 7 | .0509 | .0514 | .0492 | | | |
| 8 | .0509 | .0514 | .0509 | .0514 | | .0514 |
| 9 | .0514 | .0514 | .0497 | .0514 | | .0514 |
| 10 | .0514 | .0514 | .0497 | .0514 | | .0514 |
| 11 | .0514 | .0686 | .0838 | .0514 | | .0514 |
| 12 | .0857 | .0497 | .0663 | .0514 | | .0686 |
| 13 | .0686 | .0509 | .0492 | .0514 | | .0514 |
| 14 | .0514 | .0497 | .0819 | .0514 | | .0514 |
| 15 | .0514 | .0497 | .0829 | .0514 | | .0514 |
| 16 | .0514 | .0503 | | .0514 | | .0514 |
| 17 | | .0497 | .0497 | .0514 | | .0514 |
| 18 | .0514 | .0497 | .0503 | .0514 | | .0514 |
| 19 | .0514 | .0492 | .0497 | .0343 | | .0514 |
| 20 | .0514 | .0497 | | .0514 | | .0514 |
| 21 | .0514 | .0492 | | .0514 | | .0514 |
| 22 | .0514 | .0497 | .0492 | .0514 | | .0514 |
| 23 | .0514 | | | .0514 | | .0514 |
| 24 | .0509 | .0514 | .0486 | | .0514 | .0509 |
| **Max** | **.0857** | **.0686** | **.0838** | **.0514** | **.0514** | **.0686** |
| **Min** | **.0509** | **.0492** | **.0486** | **.0343** | **.0514** | **.0509** |
| **Avg** | **.0534** | **.0514** | **.0554** | **.0503** | **.0514** | **.0524** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214443 / 33/11 KV RAHU S/STN**
**Feeder No / Name : 209 / 11 Kv RAHU GAVTHAN GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4801 | .4287 | .4752 | | .463 | |
| 2 | .4458 | .4287 | .4807 | | .463 | |
| 3 | .4801 | .5487 | .4588 | | .5316 | |
| 4 | .6859 | .6859 | .5243 | | .6173 | |
| 5 | .7373 | .7888 | .6554 | | .7202 | |
| 6 | .823 | .8916 | .7537 | | .8745 | |
| 7 | .9088 | .9431 | .8886 | | | .8402 |
| 8 | .7888 | .8402 | .6796 | .7888 | | .7545 |
| 9 | .6687 | .7373 | .6539 | .6859 | | .6001 |
| 10 | .5658 | .703 | .5898 | .583 | | .5658 |
| 11 | .5658 | .6173 | .5407 | .5658 | | .4973 |
| 12 | .5658 | .5138 | .5426 | .5144 | | .3772 |
| 13 | .5487 | .4862 | .4748 | .4458 | | .4115 |
| 14 | | .4424 | .4144 | .3944 | | .4287 |
| 15 | .4458 | .426 | .4096 | .4115 | | .463 |
| 16 | .463 | .4359 | | .4287 | | .463 |
| 17 | .4973 | .4641 | .426 | .4801 | | .463 |
| 18 | | .5197 | .4973 | .5658 | | .4287 |
| 19 | .703 | .5935 | .6274 | .6344 | | .6001 |
| 20 | .6173 | .5426 | | .6516 | | .583 |
| 21 | .5316 | .57 | | .583 | | .5487 |
| 22 | .4801 | .4973 | .5079 | .5316 | | .5144 |
| 23 | .4287 | | | .5144 | | .5144 |
| 24 | .5144 | .4287 | .4915 | | .4801 | .4973 |
| **Max** | **.9088** | **.9431** | **.8886** | **.7888** | **.8745** | **.8402** |
| **Min** | **.4287** | **.426** | **.4096** | **.3944** | **.463** | **.3772** |
| **Avg** | **.5884** | **.5884** | **.5546** | **.5487** | **.5928** | **.5306** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214443 / 33/11 KV RAHU S/STN**
**Feeder No / Name : 210 / TAKALI BHIMA DAUND AG FEEDER Feeder KV- 11 / OUTGOING SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER**

| DATE | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3086 | .3086 | .3521 | | .3258 | |
| 2 | .2915 | .3086 | .3856 | | .3258 | |
| 3 | 1.869 | 1.869 | | | .3429 | .3429 |
| 4 | | 2.0233 | 2.0008 | | .4458 | |
| 5 | 2.0405 | 2.1262 | 2.1795 | | .4801 | |
| 6 | 2.3148 | 2.3148 | 2.2377 | | .5658 | |
| 7 | 2.4348 | 2.4863 | 2.4247 | | | .6173 |
| 8 | 2.4863 | 2.6235 | 2.5434 | 2.6063 | | .5487 |
| 9 | 2.5034 | 2.6063 | 2.4863 | 2.6578 | | .4115 |
| 10 | 2.4006 | 2.4177 | 2.5316 | 2.6063 | | .2915 |
| 11 | .0686 | .1715 | .2347 | .1715 | | 2.4348 |
| 12 | .1543 | .1802 | | .1715 | | 2.4006 |
| 13 | .2058 | .1492 | .2035 | .2058 | | 2.6406 |
| 14 | .2572 | .1989 | .1619 | .2058 | | 2.6406 |
| 15 | .1715 | .1638 | .1638 | .2058 | | 2.6235 |
| 16 | .1715 | | | .2229 | | 2.6235 |
| 17 | .1886 | | .2458 | .2401 | | 2.6749 |
| 18 | .3429 | .3647 | .3052 | .3429 | | 2.6406 |
| 19 | .3944 | .4424 | .431 | .4287 | | .4115 |
| 20 | .3772 | .4096 | | .4801 | | .3944 |
| 21 | .3258 | .4144 | | .4458 | | .3772 |
| 22 | .3086 | .3277 | | .3429 | | .3429 |
| 23 | .2915 | | | .3429 | | .3086 |
| 24 | .3258 | .3086 | .3605 | | .3429 | .3258 |
| **Max** | **2.5034** | **2.6235** | **2.5434** | **2.6578** | **.5658** | **2.6749** |
| **Min** | **.0686** | **.1492** | **.1619** | **.1715** | **.3258** | **.2915** |
| **Avg** | **.8797** | **1.0579** | **1.1322** | **.7298** | **.4042** | **1.3185** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214443 / 33/11 KV RAHU S/STN**
**Feeder No / Name : 401 / Shreenath Mhaskoba Cogen. NON SHEDDABLE EXPRESS HV FEEDERS**
**Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | .8402 |
| Max | .8402 |
| Min | .8402 |
| Avg | .8402 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214444 / 33/11 KV PARGAON S/STN**
**Feeder No / Name : 201 / 11 Kv Pargaon Feeder SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2743 | .2743 | .3174 | .3921 | .3086 | .3086 | .3429 |
| 2 | .2743 | .2743 | .3174 | .3921 | .2915 | .3429 | .3429 |
| 3 | | .3429 | .3547 | .4108 | .2743 | .4115 | .3772 |
| 4 | .3258 | .4287 | .4108 | .5228 | .3429 | .4458 | .4801 |
| 5 | .4115 | .5144 | .5228 | .5975 | .4287 | .4973 | .5487 |
| 6 | .5144 | .6001 | .7095 | .7282 | .4973 | | .6173 |
| 7 | .5487 | .6687 | .8029 | .8029 | .6001 | .6516 | .7545 |
| 8 | .6001 | .5658 | .6859 | .7468 | .6001 | .5144 | .6516 |
| 9 | .4458 | .463 | .5658 | .6001 | .3772 | .4115 | .5041 |
| 10 | .3258 | .4115 | .463 | .4973 | .3772 | .3258 | .3547 |
| 11 | 1.2174 | .9945 | 1.3889 | 1.4918 | 1.5604 | 1.3375 | 1.2795 |
| 12 | 1.2346 | 1.1145 | 1.4232 | 1.5089 | 1.7318 | 1.3717 | 1.3394 |
| 13 | 1.2517 | | 1.5261 | 1.5089 | 1.6461 | 1.4403 | 1.3213 |
| 14 | 1.2689 | | 1.5775 | 1.5604 | 1.6118 | 1.5432 | 1.3352 |
| 15 | 1.286 | | 1.4918 | 1.6289 | 1.5775 | 1.5947 | 1.4118 |
| 16 | 1.2346 | 1.3717 | 1.5604 | 1.6461 | 1.6289 | 1.6118 | 1.448 |
| 17 | 1.2689 | 1.4998 | 1.6461 | 1.5775 | 1.6118 | 1.5947 | 1.448 |
| 18 | 1.2517 | 1.5546 | 1.6975 | 1.6632 | 1.6975 | 1.6118 | 1.448 |
| 19 | .4287 | .5415 | .6161 | .4973 | .4973 | .463 | .463 |
| 20 | .3772 | .5041 | .5601 | .3944 | .463 | .4801 | .4287 |
| 21 | .3601 | .4481 | .5228 | .3601 | .4287 | .4115 | .3601 |
| 22 | .3258 | .3921 | .4481 | .3601 | .3944 | .3772 | .3601 |
| 23 | .3086 | .3547 | .4294 | .3258 | .3429 | .3429 | .3258 |
| 24 | .2915 | .2915 | .3174 | .4108 | .3086 | .3258 | .3258 |
| **Max** | **1.286** | **1.5546** | **1.6975** | **1.6632** | **1.7318** | **1.6118** | **1.448** |
| **Min** | **.2743** | **.2743** | **.3174** | **.3258** | **.2743** | **.3086** | **.3258** |
| **Avg** | **.6881** | **.6481** | **.8482** | **.8594** | **.8166** | **.8007** | **.7612** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214444 / 33/11 KV PARGAON S/STN**
**Feeder No / Name : 202 / 11 KV SHINDEWADI SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3601 | .3258 | .4481 | .3734 | .3772 | .3086 | .3086 |
| 2 | .3429 | .3086 | .4481 | .3734 | .3429 | .3086 | .3086 |
| 3 | | .3429 | .4481 | .4108 | .3086 | .3429 | .4115 |
| 4 | .3772 | .4287 | .4668 | .4294 | .4115 | .3944 | .463 |
| 5 | .4115 | .463 | .5228 | .4668 | .4973 | .463 | .4973 |
| 6 | .4458 | .5144 | .5601 | .5788 | .5316 | .5144 | .583 |
| 7 | .4801 | .6001 | .7282 | .7282 | .6001 | .5658 | .6173 |
| 8 | .5144 | .4458 | .463 | .5415 | .4973 | .4287 | .4801 |
| 9 | .4287 | .3429 | .3772 | .3944 | .4458 | .3772 | .3921 |
| 10 | .2743 | .2915 | .3086 | .3944 | .3086 | .2743 | .2614 |
| 11 | 1.0802 | 1.0288 | 1.1145 | 1.286 | 1.0802 | 1.0631 | 1.0791 |
| 12 | 1.286 | 1.2689 | 1.3889 | 1.4746 | 1.4575 | 1.2689 | 1.0791 |
| 13 | 1.2003 | | 1.286 | 1.2517 | 1.5089 | 1.3203 | 1.0974 |
| 14 | 1.166 | | 1.3375 | 1.3717 | 1.4746 | 1.3032 | 1.0059 |
| 15 | 1.2346 | | 1.166 | 1.5061 | 1.4575 | 1.2003 | 1.0608 |
| 16 | 1.3203 | 1.3546 | | 1.3889 | 1.406 | 1.2346 | 1.0425 |
| 17 | 1.3032 | 1.4661 | | 1.2689 | 1.3717 | 1.286 | 1.1523 |
| 18 | 1.286 | 1.5384 | 1.286 | 1.2003 | 1.3032 | 1.3032 | 1.262 |
| 19 | .4458 | .5228 | .4854 | .3772 | .4115 | .4287 | .4458 |
| 20 | .4287 | .4668 | .4481 | .4458 | .4115 | .3601 | .4115 |
| 21 | .4287 | .4668 | .4294 | .4287 | .3944 | .3429 | .3772 |
| 22 | .3944 | .4668 | .4108 | .4115 | .3429 | .3258 | .3429 |
| 23 | .3772 | .4481 | .3734 | .4287 | | .3086 | .2743 |
| 24 | .3429 | .3601 | .4481 | .3547 | .3944 | .3086 | .2915 |
| **Max** | **1.3203** | **1.5384** | **1.3889** | **1.5061** | **1.5089** | **1.3203** | **1.262** |
| **Min** | **.2743** | **.2915** | **.3086** | **.3547** | **.3086** | **.2743** | **.2614** |
| **Avg** | **.6926** | **.6406** | **.6793** | **.7452** | **.7537** | **.6680** | **.6352** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214444 / 33/11 KV PARGAON S/STN**
**Feeder No / Name : 203 / 11 Kv Nangaon Feeder SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 1.8861 |
| Max | 1.8861 |
| Min | 1.8861 |
| Avg | 1.8861 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214444 / 33/11 KV PARGAON S/STN**
**Feeder No / Name : 204 / 11 Kv HATAWALAN GFSS GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.0791 | 1.0242 | .9694 | 1.0425 | 1.0791 | 1.0974 | 1.0425 |
| 2 | 1.0608 | 1.0059 | .9955 | 1.0425 | 1.0242 | 1.1157 | 1.0791 |
| 3 | | 1.2254 | 1.0498 | 1.0974 | .9877 | 1.5546 | 1.1888 |
| 4 | 1.0242 | 1.3717 | 1.2803 | 1.2437 | 1.2803 | 1.701 | 1.2803 |
| 5 | 1.262 | 1.5729 | 1.6461 | 1.5912 | 1.5912 | 1.829 | 1.5261 |
| 6 | 1.5912 | 1.7741 | 1.8642 | 1.9204 | 1.8656 | 1.957 | 1.7741 |
| 7 | 1.8027 | 1.9936 | 2.0995 | 2.0668 | 2.1216 | 2.0851 | 1.957 |
| 8 | 1.9753 | 1.7924 | 1.7741 | 1.8656 | 1.9387 | 1.7193 | 1.7193 |
| 9 | 1.5947 | 1.5775 | 1.701 | 1.701 | 1.5775 | 1.4918 | 1.5546 |
| 10 | 1.4746 | 1.3169 | 1.4998 | 1.4266 | 1.5261 | 1.3203 | 1.2071 |
| 11 | 1.0802 | 1.2071 | 1.2803 | 1.1523 | 1.4575 | 1.166 | 1.0425 |
| 12 | .8573 | 1.0608 | | 1.0242 | .9602 | 1.0288 | .9511 |
| 13 | | .8048 | | | | .8916 | .8775 |
| 14 | | .7499 | 1.0425 | | | .823 | .8029 |
| 15 | | .8596 | | | | .8059 | .8962 |
| 16 | | .9145 | | | | .8402 | .9149 |
| 17 | | 1.0082 | | 1.2071 | | .9431 | 1.1523 |
| 18 | | 1.2883 | 1.829 | 1.4449 | | 1.2689 | 1.6278 |
| 19 | 1.8004 | 1.6644 | 1.8839 | 1.7741 | 1.9993 | 1.5432 | 1.6461 |
| 20 | 1.5729 | 1.4377 | 1.7375 | 1.4632 | 1.5729 | 1.4815 | 1.6644 |
| 21 | 1.5729 | 1.2803 | 1.5181 | 1.3717 | 1.4449 | 1.4266 | 1.5912 |
| 22 | 1.3352 | 1.1888 | | 1.3352 | 1.4083 | 1.2986 | 1.262 |
| 23 | 1.0974 | 1.0974 | 1.0974 | 1.262 | 1.134 | 1.1888 | 1.1706 |
| 24 | 1.0608 | 1.0608 | .9511 | 1.0608 | 1.134 | 1.1157 | .9877 |
| **Max** | **1.9753** | **1.9936** | **2.0995** | **2.0668** | **2.1216** | **2.0851** | **1.957** |
| **Min** | **.8573** | **.7499** | **.9511** | **1.0242** | **.9602** | **.8059** | **.8029** |
| **Avg** | **1.3672** | **1.2616** | **1.4566** | **1.4047** | **1.4502** | **1.3205** | **1.2882** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214444 / 33/11 KV PARGAON S/STN**
**Feeder No / Name : 205 / 11 Kv Khutbav GFSS GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6036 | .5304 | .6584 | .5975 | .567 | .567 | .7682 |
| 2 | .567 | .4938 | .5853 | .6722 | .5487 | .5487 | .7865 |
| 3 | | .5487 | .6722 | .6767 | .5304 | .6767 | .7682 |
| 4 | .6767 | .6401 | .7316 | .695 | .6401 | .7682 | .7316 |
| 5 | .7682 | .7316 | .7865 | .7682 | .7316 | .8779 | .8962 |
| 6 | .8596 | .823 | .8779 | .9877 | .823 | .9511 | .9877 |
| 7 | .8962 | .9328 | .9877 | .9877 | .9145 | 1.0059 | 1.1523 |
| 8 | .9328 | .9328 | .9145 | 1.134 | 1.1157 | 1.1888 | 1.0059 |
| 9 | .6859 | .8596 | .8962 | .8596 | .8916 | .8916 | .7316 |
| 10 | .6859 | .9145 | .8596 | 1.0425 | .8916 | .9088 | .7468 |
| 11 | .6516 | 1.0608 | 1.0242 | .9328 | .7545 | .823 | .7316 |
| 12 | .5487 | .8413 | .7133 | .823 | .6859 | .7888 | .6908 |
| 13 | .5144 | .8413 | .7499 | .567 | .6173 | .7545 | .6535 |
| 14 | .5487 | .7682 | .6401 | .5853 | .5658 | .6859 | .5975 |
| 15 | .5487 | .695 | .6401 | .6401 | .583 | .6173 | .5601 |
| 16 | .5853 | .4755 | .6219 | .695 | .5658 | .7202 | .5228 |
| 17 | .7682 | .6908 | .6036 | .7316 | .5144 | .7545 | .6348 |
| 18 | .8779 | .7468 | .9145 | .8596 | .6173 | .8916 | .7133 |
| 19 | 1.0974 | 1.1203 | 1.0269 | 1.0059 | .7316 | .9602 | .8596 |
| 20 | .8962 | .9709 | .9328 | .9145 | .7133 | 1.0242 | .823 |
| 21 | .9694 | .8779 | .8596 | .9877 | .695 | .9328 | .7316 |
| 22 | .7865 | .8413 | .8962 | .9145 | .6036 | .8779 | .6767 |
| 23 | .6767 | .8402 | .6722 | .7682 | .5853 | .8048 | .6036 |
| 24 | .6401 | .5487 | .7865 | .5975 | .567 | .5853 | .7682 |
| **Max** | **1.0974** | **1.1203** | **1.0269** | **1.134** | **1.1157** | **1.1888** | **1.1523** |
| **Min** | **.5144** | **.4755** | **.5853** | **.567** | **.5144** | **.5487** | **.5228** |
| **Avg** | **.7298** | **.7803** | **.7938** | **.8102** | **.6856** | **.8169** | **.7559** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214444 / 33/11 KV PARGAON S/STN**
**Feeder No / Name : 206 / 11 Kv Delwadi Ag SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0686 | .0686 | .0747 | .112 | .0686 | .0686 | .0686 |
| 2 | .0857 | .0686 | .0747 | .112 | .0686 | .0686 | .0686 |
| 3 | | .0686 | .0747 | .112 | .0686 | .0857 | .0686 |
| 4 | .0686 | .0686 | .0747 | .112 | .0857 | .1029 | .0686 |
| 5 | .0686 | .0686 | .0747 | .1307 | .0857 | .1029 | .0686 |
| 6 | .1372 | .0857 | .0934 | .1494 | .1029 | .12 | .0857 |
| 7 | .0857 | .0857 | .112 | .1494 | .1029 | .12 | .0857 |
| 8 | .1029 | .1029 | .1029 | .0934 | .0857 | .1029 | .0686 |
| 9 | .0343 | .0686 | .1029 | .0686 | .0686 | .0686 | .112 |
| 10 | .0343 | .0686 | .0857 | .0343 | .0514 | .0514 | .0934 |
| 11 | 1.046 | .9431 | .8745 | 1.2346 | 1.0974 | 1.046 | 1.1765 |
| 12 | 1.0288 | 1.046 | 1.166 | 1.3112 | 1.166 | 1.2517 | 1.1888 |
| 13 | .9945 | | 1.2003 | 1.166 | 1.166 | 1.3375 | 1.1706 |
| 14 | .9602 | | 1.2689 | 1.2003 | 1.1831 | 1.3375 | 1.0974 |
| 15 | .9945 | | 1.1488 | 1.2517 | 1.1317 | 1.3032 | 1.134 |
| 16 | .9774 | 1.0974 | 1.1831 | 1.2174 | 1.1145 | 1.2689 | 1.1523 |
| 17 | .9945 | 1.1706 | 1.2003 | 1.1488 | 1.0974 | 1.2003 | 1.1584 |
| 18 | .9602 | 1.1706 | 1.2269 | 1.1317 | 1.1831 | 1.1831 | 1.1946 |
| 19 | .0514 | .0747 | .056 | .0686 | .0514 | .0514 | .0514 |
| 20 | .0514 | .0747 | .112 | .0686 | .0686 | .0514 | .0514 |
| 21 | .0514 | .0747 | .112 | .0686 | .0686 | .0514 | .0514 |
| 22 | .0514 | .0747 | .1307 | .0686 | .0686 | .0686 | .0549 |
| 23 | .0686 | .0747 | .112 | .0857 | .0686 | .0686 | .0549 |
| 24 | .0857 | .0686 | .0934 | .112 | .0686 | .0686 | .0686 |
| **Max** | **1.046** | **1.1706** | **1.2689** | **1.3112** | **1.1831** | **1.3375** | **1.1946** |
| **Min** | **.0343** | **.0686** | **.056** | **.0343** | **.0514** | **.0514** | **.0514** |
| **Avg** | **.3914** | **.3154** | **.4481** | **.4670** | **.4301** | **.4658** | **.4331** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214444 / 33/11 KV PARGAON S/STN**
**Feeder No / Name : 207 / 11kv Hatawalan AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5847 | .6201 | .6535 | .6908 | .1772 | .1595 | .1772 |
| 2 | .567 | 1.2934 | .6535 | .6722 | .1543 | .1595 | .1595 |
| 3 | | 1.382 | 1.1393 | 1.1888 | 1.0631 | 1.5947 | 1.7896 |
| 4 | 1.0808 | 1.3998 | 1.262 | 1.3717 | 1.2403 | 1.7187 | 2.1085 |
| 5 | | 1.4706 | 1.3321 | 1.4998 | 1.4352 | 1.8073 | 2.1794 |
| 6 | 1.3717 | 1.4883 | 1.4022 | 1.5203 | 1.5947 | 2.0022 | 2.268 |
| 7 | 1.3998 | 1.5061 | 1.4403 | 1.6644 | 1.8073 | 2.1262 | 2.3211 |
| 8 | 1.4706 | 1.5592 | 1.7187 | 1.8461 | 1.825 | 2.268 | 2.3565 |
| 9 | 1.5604 | 1.7541 | 1.8073 | 1.7896 | 1.9719 | 2.2805 | 2.4977 |
| 10 | 1.4918 | 1.7718 | 1.8073 | 1.9313 | 1.8861 | 2.2634 | 2.3891 |
| 11 | .7716 | .8402 | .8328 | .9214 | .0686 | .1029 | .112 |
| 12 | .6687 | .9391 | .8859 | .9214 | .0857 | .0686 | .0747 |
| 13 | | .9391 | | | | .0857 | .0747 |
| 14 | | .8916 | .691 | | | .0686 | .0747 |
| 15 | | .9745 | | | | .0514 | .0747 |
| 16 | | 1.0454 | | | | .0514 | .0747 |
| 17 | | 1.0829 | | .1417 | | .1029 | .0747 |
| 18 | | 1.0642 | .7282 | .2058 | | .1029 | .0747 |
| 19 | .691 | 1.0082 | .7468 | .2303 | .2303 | .2572 | .2303 |
| 20 | .7442 | .9522 | .7095 | .2303 | .2126 | .2303 | .2126 |
| 21 | .7087 | .7468 | .6722 | .1949 | .1772 | .1949 | .1949 |
| 22 | .691 | .7282 | .7282 | .1772 | .1772 | .1772 | .1772 |
| 23 | .6556 | .6908 | .6722 | .1772 | .1595 | .1772 | .1595 |
| 24 | .5847 | .6379 | .6722 | .7095 | .1595 | .1595 | .1772 |
| **Max** | **1.5604** | **1.7718** | **1.8073** | **1.9313** | **1.9719** | **2.2805** | **2.4977** |
| **Min** | **.567** | **.6201** | **.6535** | **.1417** | **.0686** | **.0514** | **.0747** |
| **Avg** | **.9401** | **1.1161** | **1.0278** | **.9042** | **.8014** | **.7588** | **.8347** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214444 / 33/11 KV PARGAON S/STN**
**Feeder No / Name : 401 / 33kv visaka NON SHEDDABLE EXPRESS HV FEEDERS**
**Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8544 | .2094 | .801 | .5993 | .6168 | .7752 | .7809 |
| 2 | .8431 | .1811 | .7954 | | .5149 | .6337 | .7695 |
| 3 | | .2094 | .7786 | .6329 | .5715 | .7752 | .679 |
| 4 | .1641 | .2659 | .7114 | .6049 | .6168 | .6111 | .7299 |
| 5 | .4414 | .2942 | .6497 | .5769 | .6734 | .7582 | .6847 |
| 6 | .5036 | .2094 | .6329 | .4481 | .7413 | .6903 | .6734 |
| 7 | .5772 | .1641 | .5881 | .801 | .7978 | .6734 | .6677 |
| 8 | .6394 | .1358 | .5545 | .8738 | .7413 | .7073 | .481 |
| 9 | .5602 | .1584 | .5715 | .7582 | .6337 | .928 | .168 |
| 10 | .1924 | .1358 | .5772 | .6847 | .5206 | .9393 | .196 |
| 11 | .1584 | .1301 | .4583 | .43 | .464 | .8714 | .1512 |
| 12 | .1584 | .215 | .2716 | .8884 | .8318 | .8601 | .1176 |
| 13 | .43 | .1528 | .5715 | .662 | .6507 | .8261 | |
| 14 | .464 | .1471 | .9167 | .5602 | .7695 | .696 | |
| 15 | .8601 | .1358 | .7186 | .6168 | .6394 | .6451 | |
| 16 | .911 | .1471 | .7582 | .696 | .5885 | .6734 | |
| 17 | .662 | .1344 | .8035 | .8997 | .464 | .696 | .8346 |
| 18 | .6903 | .2633 | .8458 | .5036 | .7299 | .8092 | .9914 |
| 19 | .6677 | .3473 | .7562 | .3791 | .6564 | .7809 | .9223 |
| 20 | .6507 | .3809 | .8234 | .7299 | .696 | .8884 | .8092 |
| 21 | .6734 | .5769 | .8402 | .8431 | .8205 | .8601 | .7016 |
| 22 | .5319 | .6554 | .4985 | .8205 | .7752 | .7978 | .6734 |
| 23 | .4017 | .7674 | .5657 | .7922 | .8657 | .7922 | .6337 |
| 24 | .8431 | .2377 | .8066 | .5769 | .7752 | .8714 | .8035 |
| **Max** | **.911** | **.7674** | **.9167** | **.8997** | **.8657** | **.9393** | **.9914** |
| **Min** | **.1584** | **.1301** | **.2716** | **.3791** | **.464** | **.6111** | **.1176** |
| **Avg** | **.5599** | **.2606** | **.6790** | **.6686** | **.6731** | **.7733** | **.6234** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214482 / 33/11 Kv WARWAND S/STN.**
**Feeder No / Name : 201 / 11 Kv Warwand Gavthan GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .547 | .5731 | .5544 | .4904 | .4854 | .5014 | .4887 |
| 2 | .5281 | .6089 | .5487 | .4904 | .4668 | .6268 | .5249 |
| 3 | .5487 | .6268 | .695 | .5121 | .5601 | .8059 | .5249 |
| 4 | .6268 | .8238 | .8048 | .6767 | .7095 | 1.0745 | .5853 |
| 5 | .7164 | 1.182 | .9328 | 1.0974 | .9335 | 1.3146 | .7602 |
| 6 | 1.4022 | 1.3672 | 1.363 | 1.3432 | 1.2883 | 1.4022 | 1.1403 |
| 7 | 1.5043 | 1.2269 | 1.5497 | 1.4022 | 1.4784 | 1.4842 | 1.5729 |
| 8 | 1.2269 | 1.0867 | 1.363 | 1.0867 | 1.423 | 1.267 | 1.2071 |
| 9 | 1.0745 | .8962 | 1.0166 | .8326 | 1.0566 | 2.3891 | .7888 |
| 10 | .7522 | .7682 | .8238 | .7602 | 1.0387 | .905 | .8589 |
| 11 | .7164 | .6584 | .631 | .6447 | .7164 | .8326 | .7011 |
| 12 | .6268 | | .631 | .6805 | .5373 | .724 | .5959 |
| 13 | .5731 | | .5959 | .591 | .5014 | .6335 | .5434 |
| 14 | .5731 | | .5258 | .591 | .4656 | .543 | .4382 |
| 15 | .5014 | | .5083 | .591 | .7164 | .5249 | .4031 |
| 16 | .6447 | | .5609 | .6089 | .7522 | .5068 | .4557 |
| 17 | .6805 | | .6089 | .6485 | .6268 | .5792 | .5784 |
| 18 | .7164 | | .7011 | .7602 | .8059 | .724 | .7343 |
| 19 | .8238 | 1.1088 | .8775 | .8871 | .8417 | .8413 | .8417 |
| 20 | .7343 | 1.0269 | .8596 | .8131 | .9671 | .8507 | .823 |
| 21 | .7522 | .924 | .7545 | .7468 | 1.0745 | .7783 | .7865 |
| 22 | .8059 | .8131 | .6979 | .6722 | .7522 | .724 | .6979 |
| 23 | .788 | .7095 | .6036 | .5975 | .7164 | .4887 | .5658 |
| 24 | .5658 | .5373 | .5729 | .5093 | .5041 | .5194 | .4938 |
| **Max** | **1.5043** | **1.3672** | **1.5497** | **1.4022** | **1.4784** | **2.3891** | **1.5729** |
| **Min** | **.5014** | **.5373** | **.5083** | **.4904** | **.4656** | **.4887** | **.4031** |
| **Avg** | **.7679** | **.8787** | **.7825** | **.7514** | **.8091** | **.8767** | **.7130** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214482 / 33/11 Kv WARWAND S/STN.**
**Feeder No / Name : 202 / 11 Kv Fargade Mala SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2263 | .2507 | .2667 | .2263 | .2477 | .2507 | .2012 |
| 2 | .2263 | .2507 | | .2452 | .2477 | .2507 | .2012 |
| 3 | .6401 | .4477 | .5182 | .5853 | .5243 | .2686 | .181 |
| 4 | .6767 | .5373 | .5506 | .6401 | .5571 | .2686 | .1829 |
| 5 | .7164 | .5731 | .5992 | .6767 | .6226 | .2865 | .2195 |
| 6 | .788 | .6485 | .6964 | .7164 | .7045 | .298 | .2743 |
| 7 | .9465 | .8764 | .8745 | .8413 | .8583 | .3258 | .3475 |
| 8 | 1.1218 | 1.0867 | 1.0526 | .9816 | 1.0364 | .3077 | .3292 |
| 9 | 1.1999 | 1.0364 | 1.1043 | 1.0364 | 1.1104 | .2172 | .2279 |
| 10 | 1.0029 | .9717 | 1.0517 | .9231 | 1.0029 | .181 | .1928 |
| 11 | .1075 | .1524 | .1753 | .1905 | .1612 | .9431 | .7186 |
| 12 | .1254 | | .1578 | .1715 | .1433 | .9945 | .964 |
| 13 | .1075 | | .1227 | .1715 | .1612 | 1.166 | .964 |
| 14 | .1254 | | .1227 | .1715 | .1791 | 1.1145 | .9114 |
| 15 | .1254 | | .1227 | .1524 | .1791 | 1.0974 | .9114 |
| 16 | .1791 | | .1227 | .1905 | .1612 | .9431 | .8764 |
| 17 | .1612 | | .1612 | .1905 | .1612 | .9774 | .7888 |
| 18 | .1791 | | .2103 | .3048 | .1791 | .8916 | .7362 |
| 19 | .2149 | .3429 | .3045 | .3429 | .2686 | .2378 | .2507 |
| 20 | .2865 | .2858 | .2743 | .2858 | .2686 | .2534 | .2378 |
| 21 | .3045 | .2858 | .2452 | .2858 | .2507 | .2172 | .2195 |
| 22 | .3045 | .2858 | .2452 | .2858 | .2865 | .1991 | .2263 |
| 23 | .2865 | .2667 | .2263 | .2667 | .2507 | .2012 | .2075 |
| 24 | .2263 | .2686 | .2477 | .2263 | .2477 | .2149 | .2012 |
| **Max** | **1.1999** | **1.0867** | **1.1043** | **1.0364** | **1.1104** | **1.166** | **.964** |
| **Min** | **.1075** | **.1524** | **.1227** | **.1524** | **.1433** | **.181** | **.181** |
| **Avg** | **.4283** | **.5040** | **.4110** | **.4212** | **.4088** | **.5044** | **.4405** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214482 / 33/11 Kv WARWAND S/STN.**
**Feeder No / Name : 203 / 11 Kv Punarvasan SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .132 | .1791 | .128 | .1132 | .1307 | .1254 | .1097 |
| 2 | .1132 | .197 | .1294 | .132 | .1307 | .1254 | .1097 |
| 3 | .128 | .197 | .1294 | .1463 | .1307 | .3403 | .5611 |
| 4 | .1463 | .2149 | .1478 | .1646 | .1494 | .5014 | .567 |
| 5 | .1829 | .2149 | .1848 | .197 | .1867 | .6268 | .6241 |
| 6 | .2328 | .2103 | .2427 | .2195 | .2241 | .8059 | .7537 |
| 7 | .2103 | .1928 | .2452 | .2103 | .2427 | .8573 | .8939 |
| 8 | .2103 | .1753 | .2241 | .1928 | .2054 | .9602 | .929 |
| 9 | .1612 | .1524 | .1578 | .1307 | .1612 | .9431 | .8764 |
| 10 | .1254 | .112 | .1227 | .1307 | .1254 | .8916 | .8764 |
| 11 | 1.0208 | .8855 | 1.0341 | .9804 | .0895 | .0732 | .0526 |
| 12 | 1.0029 | | 1.2094 | 1.247 | | .0543 | .0351 |
| 13 | .8417 | | 1.2094 | 1.3117 | 1.2536 | .0549 | .0526 |
| 14 | .8954 | | 1.3321 | 1.3117 | 1.2715 | .0373 | .0526 |
| 15 | 1.0387 | | 1.3496 | 1.2955 | 1.2178 | .0366 | .0526 |
| 16 | 1.0745 | | 1.3146 | 1.2631 | 1.1999 | .0549 | .0526 |
| 17 | 1.0566 | | 1.2795 | 1.1498 | 1.182 | .0732 | .0876 |
| 18 | .8417 | | 1.0341 | 1.0526 | 1.0029 | .1097 | .1075 |
| 19 | .1612 | .2054 | .1612 | .1867 | .1791 | .1463 | .1433 |
| 20 | .197 | .1848 | .1463 | .168 | .197 | .1463 | .1463 |
| 21 | .197 | .1663 | .132 | .168 | .197 | .128 | .128 |
| 22 | .1791 | .1478 | .132 | .1494 | .2149 | .1097 | .132 |
| 23 | .1791 | .1478 | .1132 | .1494 | .1612 | .1097 | .1132 |
| 24 | .132 | .1791 | .1307 | .1132 | .1307 | .1433 | .1097 |
| **Max** | **1.0745** | **.8855** | **1.3496** | **1.3117** | **1.2715** | **.9602** | **.929** |
| **Min** | **.1132** | **.112** | **.1132** | **.1132** | **.0895** | **.0366** | **.0351** |
| **Avg** | **.4358** | **.2213** | **.5121** | **.5077** | **.4341** | **.3106** | **.3153** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214482 / 33/11 Kv WARWAND S/STN.**
**Feeder No / Name : 204 / 11 NARAYAN BET GFSS GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8299 | .8775 | .9522 | .9808 | .9431 | .8954 | 1.0136 |
| 2 | .8299 | .9671 | .9335 | .9619 | .9242 | .8596 | 1.0136 |
| 3 | .823 | 1.0745 | .9522 | .9511 | .9997 | .9671 | 1.0136 |
| 4 | .8962 | 1.1104 | .9709 | 1.0059 | 1.0562 | 1.0745 | 1.0498 |
| 5 | .985 | 1.1641 | 1.0082 | 1.1641 | 1.1016 | 1.1641 | 1.1222 |
| 6 | 1.2715 | 1.3969 | 1.363 | 1.3717 | 1.3443 | 1.3672 | 1.3213 |
| 7 | 1.4198 | 1.3432 | 1.6244 | 1.3847 | 1.531 | 1.448 | 1.6126 |
| 8 | 1.3847 | 1.262 | 1.643 | 1.2971 | 1.475 | 1.5565 | 1.5249 |
| 9 | 1.4148 | 1.1389 | 1.4899 | 1.2136 | 1.3253 | 1.3937 | 1.1043 |
| 10 | 1.1641 | 1.307 | 1.5249 | 1.1203 | 1.2536 | 1.3352 | 1.1393 |
| 11 | .8954 | | 1.1568 | 1.2883 | .9134 | 1.3394 | .8764 |
| 12 | .9134 | | .929 | 1.1999 | .8954 | 1.0317 | .8063 |
| 13 | .8775 | | 1.1393 | .985 | .8596 | 1.1041 | .7888 |
| 14 | .8954 | | .8063 | .8954 | | .8413 | .7537 |
| 15 | .8954 | | .9991 | .8238 | 1.0745 | | .7011 |
| 16 | .9313 | | 1.0867 | 1.1462 | 1.1104 | | .7537 |
| 17 | 1.0029 | | 1.3146 | .9593 | 1.0387 | 1.4118 | .8939 |
| 18 | 1.0745 | | 1.1393 | 1.267 | 1.0745 | 1.3756 | 1.0924 |
| 19 | 1.2894 | 1.7002 | 1.4327 | 1.2136 | 1.3432 | 1.5023 | 1.3253 |
| 20 | 1.3432 | 1.4969 | 1.3169 | 1.3256 | 1.4327 | 1.4842 | 1.2254 |
| 21 | 1.0745 | 1.2883 | 1.1883 | 1.2323 | 1.3432 | 1.2851 | 1.0791 |
| 22 | 1.0924 | 1.1203 | 1.0374 | 1.1389 | 1.4327 | 1.1584 | .9335 |
| 23 | .8954 | 1.0082 | .9997 | | .9671 | .9955 | .8865 |
| 24 | .8488 | .8238 | .8589 | .9808 | .9619 | .8417 | .9955 |
| **Max** | **1.4198** | **1.7002** | **1.643** | **1.3847** | **1.531** | **1.5565** | **1.6126** |
| **Min** | **.823** | **.8238** | **.8063** | **.8238** | **.8596** | **.8413** | **.7011** |
| **Avg** | **1.0437** | **1.1925** | **1.1611** | **1.1264** | **1.1479** | **1.2015** | **1.0428** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214482 / 33/11 Kv WARWAND S/STN.**
**Feeder No / Name : 205 / 11 KV Deulgaon Gada Ag SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2641 | .2686 | .2858 | .2641 | .3048 | .3045 | .2926 |
| 2 | .2641 | .2865 | .2858 | .2263 | .2858 | .2865 | .2896 |
| 3 | .2743 | .3045 | .2858 | .2378 | .2858 | .5014 | .9259 |
| 4 | .2926 | .3045 | .3048 | .2743 | .3048 | .8059 | .9362 |
| 5 | .3045 | .3403 | .3239 | .3292 | .3239 | .9671 | .9816 |
| 6 | .3403 | .3761 | .4191 | .3582 | .4001 | 1.1393 | 1.1765 |
| 7 | .333 | .3582 | .4572 | .3856 | .4572 | 1.5432 | 1.4548 |
| 8 | .3155 | .3155 | .4382 | .4207 | .4382 | 1.7318 | 1.8519 |
| 9 | .2865 | .3239 | .4031 | .3239 | .3582 | 1.9033 | 1.9631 |
| 10 | .2149 | .2667 | .333 | .2858 | .3761 | 1.8004 | 1.9281 |
| 11 | 2.1491 | 1.3757 | 2.1735 | 1.6842 | 1.7372 | .2561 | .1928 |
| 12 | 2.3282 | | 2.6818 | 2.1792 | 2.1491 | .1646 | .1753 |
| 13 | 2.4356 | | 3.0148 | 2.251 | 2.3282 | .1629 | .1753 |
| 14 | 2.3282 | | 2.8921 | 2.2119 | 2.3461 | .1097 | .1578 |
| 15 | 2.2923 | | 2.7519 | 2.1464 | 2.2923 | | |
| 16 | 2.1491 | | 2.5591 | 2.0645 | 2.2386 | | .1753 |
| 17 | 1.9163 | | 2.3487 | 1.9433 | 2.2386 | .1829 | .1928 |
| 18 | 1.576 | | 2.0332 | 1.668 | 1.5223 | .2378 | .2865 |
| 19 | .2865 | .4382 | .3403 | .381 | .3224 | .4024 | .3403 |
| 20 | .3045 | .4191 | .3475 | .362 | .3403 | .3982 | .3475 |
| 21 | .3045 | .362 | .3395 | .362 | .3582 | .3658 | .3292 |
| 22 | .2865 | .3429 | .3395 | .3429 | .3582 | .2896 | .3206 |
| 23 | .2686 | .3239 | .3206 | .3239 | .3045 | .2926 | .3018 |
| 24 | .2829 | .2507 | .3048 | .3018 | .3048 | .2865 | .2926 |
| **Max** | **2.4356** | **1.3757** | **3.0148** | **2.251** | **2.3461** | **1.9033** | **1.9631** |
| **Min** | **.2149** | **.2507** | **.2858** | **.2263** | **.2858** | **.1097** | **.1578** |
| **Avg** | **.9083** | **.3916** | **1.0827** | **.8887** | **.9323** | **.6424** | **.6560** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214482 / 33/11 Kv WARWAND S/STN.**
**Feeder No / Name : 206 / KHOR AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 1.8861 |
| Max | 1.8861 |
| Min | 1.8861 |
| Avg | 1.8861 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214482 / 33/11 Kv WARWAND S/STN.**
**Feeder No / Name : 401 / 33kv mahananda express NON SHEDDABLE EXPRESS HV FEEDERS**
**Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1132 | .2149 | .1715 | .1132 | .1143 | .2149 | .1132 |
| 2 | .1132 | .2686 | .1715 | .1132 | .1143 | .1075 | .1143 |
| 3 | .1097 | .2686 | .1715 | .1097 | .1143 | .1075 | .1143 |
| 4 | .1097 | .2149 | .1143 | .1097 | .1143 | .1075 | .1143 |
| 5 | .1075 | .1075 | .1143 | .1646 | .1143 | .1075 | .1143 |
| 6 | .1612 | .2149 | .1143 | .2686 | .2286 | .2629 | .1715 |
| 7 | .2103 | .3155 | .2286 | .2103 | .2858 | .1086 | .1715 |
| 8 | .5258 | .3155 | .3429 | .2629 | .2858 | .5601 | .1715 |
| 9 | .591 | .6287 | .631 | .6287 | .591 | .5658 | .1578 |
| 10 | .6447 | .6859 | .6836 | .5716 | .591 | .679 | .4733 |
| 11 | .6984 | .743 | .7362 | .8573 | .6447 | .6224 | .4733 |
| 12 | .591 | | .6836 | .743 | .591 | .7922 | .631 |
| 13 | .5373 | | .631 | .743 | .6447 | .6224 | .4733 |
| 14 | .591 | | | .743 | .5373 | .7922 | .5258 |
| 15 | .6447 | | .631 | .6859 | .3761 | .679 | .4207 |
| 16 | .3761 | .2858 | .6836 | .6859 | .2686 | .6224 | .3681 |
| 17 | .3224 | .2858 | .5784 | .743 | .2686 | .679 | .2103 |
| 18 | .3224 | .2286 | .5784 | .9145 | .4298 | .679 | .1075 |
| 19 | .2686 | .4001 | .7522 | .4001 | .4835 | .2263 | .0537 |
| 20 | .2686 | .2858 | .6584 | .2858 | .3761 | .2263 | .1097 |
| 21 | .2149 | .2858 | .6584 | .2286 | .3224 | .1698 | .1646 |
| 22 | .1075 | .2858 | .5658 | .1715 | .2686 | .1698 | .1698 |
| 23 | .1075 | .2858 | .3961 | .1715 | .2149 | .1132 | .1698 |
| 24 | .1132 | .2149 | .2286 | .1132 | .1715 | .2149 | .1132 |
| **Max** | **.6984** | **.743** | **.7522** | **.9145** | **.6447** | **.7922** | **.631** |
| **Min** | **.1075** | **.1075** | **.1143** | **.1097** | **.1143** | **.1075** | **.0537** |
| **Avg** | **.3271** | **.3268** | **.4576** | **.4183** | **.3396** | **.3929** | **.2378** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214499 / 33/11 KV DAHITANE S/STN.**
**Feeder No / Name : 201 / 11 KV DEVKARWADI AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4207 | .5258 | | .4207 | .4733 | .4207 | .4252 |
| 2 | .4298 | .4908 | | .4607 | .4656 | .4252 | .4656 |
| 3 | .4382 | .4656 | | .5014 | .4298 | .4298 | 1.6289 |
| 4 | .4607 | .5014 | | .5373 | .4854 | 1.7909 | 1.7013 |
| 5 | .4801 | .543 | | .5731 | .543 | 1.7909 | 1.7193 |
| 6 | .5144 | .5792 | | .6516 | .6447 | 1.8267 | 1.7551 |
| 7 | .6219 | .5014 | | .6878 | .6516 | 2.1357 | 1.949 |
| 8 | .6154 | .5373 | | .6154 | .6089 | 2.4977 | 2.0199 |
| 9 | .3982 | .4706 | | .5014 | .4706 | 2.3891 | 2.1357 |
| 10 | .362 | | | .394 | .394 | 2.3529 | 2.0416 |
| 11 | 1.5203 | | | 1.97 | 2.4356 | .2896 | .2896 |
| 12 | 1.9022 | | | 2.4977 | 2.8654 | .2534 | .2896 |
| 13 | 1.9387 | | | 2.4806 | 2.8654 | .2534 | .2172 |
| 14 | 2.0119 | | | 2.5072 | 2.758 | .2172 | .2103 |
| 15 | 2.1216 | | | 2.8597 | 2.758 | .2865 | .2149 |
| 16 | 2.0633 | | | 2.3282 | 2.758 | .3224 | |
| 17 | 2.0271 | | | 2.1491 | 2.6147 | .362 | |
| 18 | 1.9909 | | | 1.9909 | 2.5339 | .3982 | .3982 |
| 19 | .394 | | .4252 | .4706 | .5121 | .4298 | .4961 |
| 20 | .4298 | | .4607 | .4961 | .4508 | .4656 | |
| 21 | .4607 | | .4252 | .4887 | .4161 | .4298 | .4908 |
| 22 | .4961 | | .4656 | .5121 | .4557 | .3898 | .4557 |
| 23 | .5316 | | .4298 | .4733 | .4207 | .4252 | .4557 |
| 24 | .5609 | | .3856 | | .4733 | .4607 | |
| **Max** | **2.1216** | **.5792** | **.4656** | **2.8597** | **2.8654** | **2.4977** | **2.1357** |
| **Min** | **.362** | **.4656** | **.3856** | **.394** | **.394** | **.2172** | **.2103** |
| **Avg** | **.9663** | **.5128** | **.4320** | **1.1551** | **1.2285** | **.8768** | **.9680** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214499 / 33/11 KV DAHITANE S/STN.**
**Feeder No / Name : 202 / 11 KV DAHITANE GFSS GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3155 | .3155 | | | .2896 | .2804 | .3189 |
| 2 | .3045 | .298 | | .2481 | .3224 | .2658 | .3582 |
| 3 | .3856 | .394 | | .3224 | .3582 | .3045 | .3982 |
| 4 | .443 | 1.6834 | | .394 | .4334 | .3582 | .4344 |
| 5 | .4973 | .4706 | | .4656 | .5068 | .5373 | .4656 |
| 6 | .5144 | .4887 | | .5068 | .6268 | .591 | .4298 |
| 7 | .6036 | .4656 | | .5611 | .6697 | .6335 | .4607 |
| 8 | .5249 | .5014 | | .4525 | .5373 | .4887 | .443 |
| 9 | .3982 | .3982 | | .4119 | .4525 | .3258 | .362 |
| 10 | .362 | | | .394 | .3761 | .3801 | .3045 |
| 11 | .362 | | | .3582 | .3224 | .3258 | .2715 |
| 12 | .3292 | | | .3077 | .2896 | .2715 | .3077 |
| 13 | .3109 | | | .2835 | .3224 | .2172 | .2353 |
| 14 | .3292 | | | .3045 | .2865 | .181 | .2715 |
| 15 | .2926 | | | .3258 | .3403 | .2149 | .2686 |
| 16 | .3077 | | | .3403 | .3403 | .2507 | |
| 17 | .3258 | | | .4477 | .3403 | .2715 | |
| 18 | .3439 | | | .5068 | .394 | .2896 | |
| 19 | .3224 | | .3189 | .4525 | .4207 | .3045 | .4252 |
| 20 | | | .3366 | .4252 | .3641 | .3224 | .4252 |
| 21 | .3544 | | .3544 | .3982 | .3294 | .3403 | .4207 |
| 22 | .3189 | | .3224 | .3658 | .2947 | .3544 | .4031 |
| 23 | | | .2865 | .333 | .2804 | .3189 | .3681 |
| 24 | .298 | | .3155 | | .3155 | .3012 | |
| **Max** | **.6036** | **1.6834** | **.3544** | **.5611** | **.6697** | **.6335** | **.4656** |
| **Min** | **.2926** | **.298** | **.2865** | **.2481** | **.2804** | **.181** | **.2353** |
| **Avg** | **.3747** | **.5573** | **.3224** | **.3912** | **.3839** | **.3387** | **.3686** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214499 / 33/11 KV DAHITANE S/STN.**
**Feeder No / Name : 203 / 11 KV DAHITANE AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0526 | .0526 | | | | .0351 | .0354 |
| 2 | .0537 | .0526 | | | | .0354 | .0358 |
| 3 | .7888 | .8954 | | .9671 | 1.379 | 1.3969 | .0362 |
| 4 | .8859 | .9313 | | 1.0029 | 1.3176 | .0358 | .0362 |
| 5 | .8745 | .9774 | | 1.0387 | 1.3575 | .0358 | .0358 |
| 6 | .8916 | 1.0136 | | 1.1584 | 1.3432 | .0358 | .0358 |
| 7 | .9694 | 1.0745 | | 1.1765 | 1.4842 | | .0354 |
| 8 | 1.1222 | 1.1104 | | 1.2851 | 1.5223 | .0362 | .0354 |
| 9 | 1.1584 | 1.2127 | | 1.4506 | 1.647 | .0362 | .0362 |
| 10 | 1.1765 | | | 1.4327 | 1.5581 | .0362 | .0358 |
| 11 | | | | .0358 | .0358 | 1.9909 | |
| 12 | | | | .0362 | .0358 | 2.1538 | 2.1176 |
| 13 | | | | .0354 | .0358 | 2.1719 | 2.1719 |
| 14 | | | | .0358 | | 2.1538 | 2.1538 |
| 15 | | | | | .0358 | 2.1132 | 2.1132 |
| 16 | | | | | .0358 | 2.0774 | |
| 17 | | | | .0358 | .0358 | 2.0633 | |
| 18 | | | | .0362 | .0358 | 2.0271 | 1.8823 |
| 19 | | | .0532 | .0362 | .0366 | .0358 | .0354 |
| 20 | .0537 | | .0532 | .0354 | .0347 | .0358 | .0354 |
| 21 | .0532 | | .0532 | .0362 | .0347 | .0358 | .0351 |
| 22 | .0532 | | .0537 | | .0526 | .0354 | .0351 |
| 23 | .0532 | | | | .0351 | .0354 | .0351 |
| 24 | .0526 | | | | | .0354 | |
| **Max** | **1.1765** | **1.2127** | **.0537** | **1.4506** | **1.647** | **2.1719** | **2.1719** |
| **Min** | **.0526** | **.0526** | **.0532** | **.0354** | **.0347** | **.0351** | **.0351** |
| **Avg** | **.5493** | **.8134** | **.0533** | **.5785** | **.6027** | **.8108** | **.5486** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214543 / 33/11kv Pimpalgaon Substation**
**Feeder No / Name : 201 / 11kv Siddeshwar Feeder SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0457 | .0648 | .0671 | .0503 | .0671 | .0503 | .0457 |
| 2 | .0457 | .0671 | .0671 | .0503 | .0671 | .0503 | .061 |
| 3 | .3048 | .3353 | .3353 | .3353 | .503 | .0671 | .061 |
| 4 | .3353 | .3521 | .3353 | .4191 | .5365 | .0671 | .0762 |
| 5 | .3506 | .3688 | .3688 | .4694 | .57 | .0838 | .1067 |
| 6 | .3506 | .4024 | .4024 | .503 | .6036 | .1006 | .1067 |
| 7 | .381 | .4527 | .4862 | .503 | .6371 | .1174 | .1219 |
| 8 | .442 | .503 | .5197 | .6203 | .6371 | .1006 | .0914 |
| 9 | .4191 | .8886 | .4572 | .5335 | .6203 | .061 | .0678 |
| 10 | .3856 | .4694 | .4268 | .5335 | .6036 | .0457 | .0509 |
| 11 | .0503 | .1174 | .0457 | .0457 | .0335 | .8383 | 1.153 |
| 12 | .0503 | .0838 | .0457 | .0305 | .0503 | .9145 | 1.153 |
| 13 | .0335 | .0838 | .0457 | .0305 | .0503 | .9755 | 1.1022 |
| 14 | .0335 | .1006 | .0305 | .0305 | .0335 | .9755 | 1.1361 |
| 15 | .0168 | .1006 | .0457 | .0305 | .0335 | 1.0364 | 1.17 |
| 16 | .0335 | .1174 | .0457 | .0305 | .0503 | 1.0517 | 1.1361 |
| 17 | .0335 | .0671 | .0457 | .0457 | .0503 | .9907 | 1.1233 |
| 18 | .0503 | .0671 | .0762 | .0671 | .0838 | .9907 | 1.1191 |
| 19 | .0838 | .0671 | .0671 | .0671 | .0838 | .061 | .0838 |
| 20 | .0838 | .0838 | .0671 | .0671 | .0838 | .061 | .0671 |
| 21 | .0838 | .0671 | .0671 | .0671 | .0671 | .061 | .0671 |
| 22 | .0838 | .0671 | .0671 | .0671 | .0671 | .061 | .0671 |
| 23 | .0838 | .0671 | .0671 | .0671 | .0671 | .0457 | .0671 |
| 24 | .061 | .0671 | .0671 | .0671 | | .0671 | .0457 |
| **Max** | **.442** | **.8886** | **.5197** | **.6203** | **.6371** | **1.0517** | **1.17** |
| **Min** | **.0168** | **.0648** | **.0305** | **.0305** | **.0335** | **.0457** | **.0457** |
| **Avg** | **.1601** | **.2109** | **.1771** | **.1971** | **.2435** | **.3698** | **.4283** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 214543 / 33/11kv Pimpalgaon Substation**
**Feeder No / Name : 202 / 11kv Matoba GFSS GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7011 | .7042 | .7209 | .7377 | .788 | .7377 | .7621 |
| 2 | | .7042 | .7545 | .7042 | .7545 | .7377 | .8383 |
| 3 | .9907 | .7712 | .8718 | .8215 | .8551 | .8048 | .9145 |
| 4 | 1.1736 | .8383 | 1.0059 | .9389 | .9724 | .9054 | .9755 |
| 5 | 1.1431 | .9054 | | 1.073 | 1.073 | 1.0059 | 1.0669 |
| 6 | 1.1279 | 1.0395 | 1.2742 | 1.1904 | 1.1904 | 1.1736 | 1.1279 |
| 7 | 1.2651 | 1.3413 | 1.4083 | 1.3077 | 1.3077 | 1.3748 | 1.2346 |
| 8 | .9602 | 1.1233 | 1.1065 | 1.0059 | 1.1736 | 1.2071 | 1.0517 |
| 9 | .8383 | .8886 | .8535 | .8535 | 1.0059 | .8383 | |
| 10 | .503 | .7209 | .7773 | .7773 | .7545 | .6706 | .8048 |
| 11 | .7545 | .7209 | .7316 | .7011 | .7042 | .6097 | .8309 |
| 12 | .57 | .7545 | .6859 | .7011 | .7042 | .6249 | .7291 |
| 13 | .5868 | .7545 | .5487 | .6097 | .5365 | .6097 | .6783 |
| 14 | .6706 | .788 | .5639 | .5944 | .6706 | .6097 | .7122 |
| 15 | .6706 | .7042 | .5792 | .5944 | .6203 | .5639 | .6783 |
| 16 | .5868 | .6371 | .5487 | .4877 | .6203 | .5792 | .6783 |
| 17 | .6539 | .8048 | .6249 | .6859 | .6371 | .6249 | 1.0174 |
| 18 | .8886 | .8718 | .8383 | .8551 | .8383 | .8535 | .9326 |
| 19 | 1.0395 | .9221 | .9221 | .9556 | 1.0059 | .9297 | 1.1065 |
| 20 | 1.0059 | .9724 | .8718 | 1.0562 | .9389 | .8688 | 1.0395 |
| 21 | .8551 | .8383 | .9054 | 1.0059 | .8551 | .8688 | .9389 |
| 22 | .8383 | .788 | .8718 | .8886 | .8551 | .7621 | .8718 |
| 23 | .8048 | .7545 | .8718 | .8551 | | .7164 | .9054 |
| 24 | .7011 | .7377 | .7209 | .7712 | .8215 | .7712 | .7011 |
| **Max** | **1.2651** | **1.3413** | **1.4083** | **1.3077** | **1.3077** | **1.3748** | **1.2346** |
| **Min** | **.503** | **.6371** | **.5487** | **.4877** | **.5365** | **.5639** | **.6783** |
| **Avg** | **.8404** | **.8369** | **.8286** | **.8405** | **.8558** | **.8104** | **.8955** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 217013 / YAwat Sub-station**
**Feeder No / Name : 300 / Auxilary Consumption**
**Feeder KV- 22 / OUTGOING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | .4858 |
| Max | .4858 |
| Min | .4858 |
| Avg | .4858 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 217013 / YAwat Sub-station**
**Feeder No / Name : 301 / 22 KV INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY**
**Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 1.2003 |
| Max | 1.2003 |
| Min | 1.2003 |
| Avg | 1.2003 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 217013 / YAwat Sub-station**
**Feeder No / Name : 302 / 22 Kv Pimpalgaon Feeder SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | .6478 |
| Max | .6478 |
| Min | .6478 |
| Avg | .6478 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 217013 / YAwat Sub-station**
**Feeder No / Name : 303 / 22 kv Bhuleshwar feeder SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | .8573 |
| Max | .8573 |
| Min | .8573 |
| Avg | .8573 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 217013 / YAwat Sub-station**
**Feeder No / Name : 304 / 22 Kv Yawat Feeder SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | .4858 |
| Max | .4858 |
| Min | .4858 |
| Avg | .4858 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 217013 / YAwat Sub-station**
**Feeder No / Name : 305 / 22 Kv Supa Feeder SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | .4572 |
| Max | .4572 |
| Min | .4572 |
| Avg | .4572 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 217013 / YAwat Sub-station**
**Feeder No / Name : 306 / 22 Kv Rahu Feeder SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 1.4575 |
| Max | 1.4575 |
| Min | 1.4575 |
| Avg | 1.4575 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 217013 / YAwat Sub-station**
**Feeder No / Name : 307 / 22 KV DECCAN NON SHEDDABLE EXPRESS HV FEEDERS**
**Feeder KV- 22 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | .1524 |
| Max | .1524 |
| Min | .1524 |
| Avg | .1524 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 217013 / YAwat Sub-station**
**Feeder No / Name : 309 / 22 KV YAWAT GFSS GAOTHAN FEEDER**
**Feeder KV- 22 / OUTGOING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | .4858 |
| Max | .4858 |
| Min | .4858 |
| Avg | .4858 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 217013 / YAwat Sub-station**
**Feeder No / Name : 310 / 22 KV SUPA GFSS GAOTHAN FEEDER**
**Feeder KV- 22 / OUTGOING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | .1524 |
| Max | .1524 |
| Min | .1524 |
| Avg | .1524 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 217013 / YAwat Sub-station**
**Feeder No / Name : 401 / 33 KV PARGAON**
**Feeder KV- 33 / OUTGOING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | .8002 |
| Max | .8002 |
| Min | .8002 |
| Avg | .8002 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 217013 / YAwat Sub-station**
**Feeder No / Name : 402 / 33 KV RAHU FEEDER**
**Feeder KV- 33 / INCOMING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 2.3148 |
| Max | 2.3148 |
| Min | 2.3148 |
| Avg | 2.3148 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 217013 / YAwat Sub-station**
**Feeder No / Name : 403 / 33 KV SAHAJPUR**
**Feeder KV- 33 / INCOMING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 23 | .6859 |
| 24 | 5.6584 |
| Max | 5.6584 |
| Min | .6859 |
| Avg | 3.1722 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 217013 / YAwat Sub-station**
**Feeder No / Name : 404 / 33 kv MINAKSHI NON SHEDDABLE EXPRESS HV FEEDERS**
**Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | .8745 |
| Max | .8745 |
| Min | .8745 |
| Avg | .8745 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 217013 / YAwat Sub-station**
**Feeder No / Name : 406 / 33 KV LIEBHERR NON SHEDDABLE EXPRESS HV FEEDERS**
**Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | .2 |
| Max | .2 |
| Min | .2 |
| Avg | .2 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 217045 / 132/33 KV JANAI S/STN**
**Feeder No / Name : 405 / 33/11 KV Supa S/stn**
**Incomer Feeder KV- 33 /**
**INCOMING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 5.6584 |
| Max | 5.6584 |
| Min | 5.6584 |
| Avg | 5.6584 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**KEDGAON S/DN.[701] BU 4701**
**Substation No/ Name :- 217045 / 132/33 KV JANAI S/STN**
**Feeder No / Name : 406 / Kedgaon( Warwand)**
**Feeder KV- 33 / INCOMING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 5.6584 |
| Max | 5.6584 |
| Min | 5.6584 |
| Avg | 5.6584 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 213332 / 22 KV RANJANGAON SWITCHING NO1**
**Feeder No / Name : 301 / DSM Express Feeder KV- 22 / OUTGOING**
**NON SHEDDABLE EXPRESS HV FEEDERS (CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7167 | .9431 | .8676 | .1143 | .1132 | .8299 | .724 |
| 2 | .8299 | 1.0562 | .7545 | .0762 | .1509 | .679 | .7621 |
| 3 | .9431 | .7922 | .9431 | | .1132 | .7922 | .8383 |
| 4 | .8676 | 1.1317 | .8299 | .0762 | .1132 | .6036 | .8764 |
| 5 | .9054 | .8676 | .9054 | .0762 | .1509 | .679 | .9526 |
| 6 | .8299 | 1.1317 | .9808 | .0762 | .1509 | .5658 | .9907 |
| 7 | .9054 | 1.0562 | .1132 | .0762 | .1132 | .3772 | 1.0288 |
| 8 | .6413 | .9808 | .0754 | .1143 | .0754 | .6036 | .5335 |
| 9 | .1509 | .6413 | .2263 | .1524 | .1132 | .4527 | .4191 |
| 10 | .1132 | .6036 | .4572 | .3772 | .1886 | .381 | .415 |
| 11 | .3395 | .1132 | .3429 | .3018 | .3395 | .381 | .3772 |
| 12 | .3018 | .1132 | .3048 | .5281 | .2263 | .3048 | .2263 |
| 13 | .0754 | .4527 | .4572 | .0754 | .3018 | .4954 | .7167 |
| 14 | .0754 | .6036 | .381 | .4904 | .3395 | .6478 | 1.0562 |
| 15 | .7545 | .679 | .3429 | .3395 | .5281 | .4572 | 1.0185 |
| 16 | .9431 | .9054 | .1143 | .1132 | .5281 | .8002 | .9808 |
| 17 | .1509 | 1.0185 | .0762 | .1132 | .415 | .8764 | .9054 |
| 18 | .7922 | 1.0185 | .0762 | .1132 | .8299 | .8764 | 1.094 |
| 19 | .9431 | 1.1694 | .1143 | .1132 | .8299 | .8383 | 1.0562 |
| 20 | 1.0562 | 1.1694 | .1143 | .1132 | .8676 | .9526 | .679 |
| 21 | 1.094 | 1.0562 | .1143 | .1132 | .7922 | .8764 | .679 |
| 22 | 1.1317 | 1.2449 | .1143 | .1132 | .8299 | .7621 | 1.094 |
| 23 | 1.1694 | 1.0185 | .1143 | .1132 | .8299 | .7621 | .9431 |
| 24 | .7922 | 1.1317 | .7167 | .1143 | .1132 | .7545 | .6859 |
| **Max** | **1.1694** | **1.2449** | **.9808** | **.5281** | **.8676** | **.9526** | **1.094** |
| **Min** | **.0754** | **.1132** | **.0754** | **.0754** | **.0754** | **.3048** | **.2263** |
| **Avg** | **.6885** | **.8708** | **.3974** | **.1693** | **.3772** | **.6562** | **.7939** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 213332 / 22 KV RANJANGAON SWITCHING NO1**
**Feeder No / Name : 302 / Pepsico Express Feeder KV- 22 / OUTGOING**
**NON SHEDDABLE EXPRESS HV FEEDERS (CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.6598 | 1.773 | 1.5844 | 1.6385 | 1.6598 | 1.5844 | 1.2955 |
| 2 | 1.8107 | 1.6975 | 1.773 | 1.6004 | 1.5466 | 1.5089 | 1.2193 |
| 3 | 1.6975 | 1.8107 | 1.6975 | 1.5242 | 1.5844 | 1.6221 | 1.2574 |
| 4 | 1.6221 | 1.6975 | 1.5844 | 1.5623 | 1.5089 | 1.6975 | 1.1431 |
| 5 | 1.7353 | 1.6598 | 1.6598 | 1.6004 | 1.5466 | 1.6598 | 1.0669 |
| 6 | 1.8107 | 1.8484 | 1.6975 | 1.6385 | 1.5844 | 1.5844 | .9907 |
| 7 | 1.6975 | 1.773 | 1.7353 | 1.6385 | 1.5844 | 1.5844 | .9145 |
| 8 | 1.5089 | 1.773 | 1.773 | 1.829 | 1.7353 | 1.6975 | 1.0288 |
| 9 | 1.5089 | 1.8484 | 1.6975 | | 1.6975 | 1.5089 | .9145 |
| 10 | 1.8861 | 1.773 | 1.7909 | 1.8484 | 1.7353 | 1.6004 | 1.0185 |
| 11 | 1.8484 | 1.8107 | 1.6004 | 1.8107 | 1.6598 | 1.5623 | 1.094 |
| 12 | 1.8484 | 1.773 | 1.6004 | 1.6221 | 1.6221 | 1.6004 | 1.094 |
| 13 | 1.7353 | 1.7353 | 1.6004 | 1.4335 | 1.6598 | 1.6004 | 1.2071 |
| 14 | 1.7353 | 1.773 | 1.7147 | 1.4335 | 1.5844 | 1.5623 | .9808 |
| 15 | 1.9616 | 1.6598 | 1.5242 | 1.4335 | 1.5844 | 1.5242 | .8676 |
| 16 | 1.8107 | 1.8484 | 1.7528 | 1.6975 | 1.6221 | 1.5623 | 1.0185 |
| 17 | 1.5089 | 1.8107 | 1.6385 | 1.6598 | 1.6221 | 1.5623 | .8676 |
| 18 | 1.8107 | 1.9239 | 1.6385 | 1.6221 | 1.5844 | 1.5242 | 1.0185 |
| 19 | 1.7353 | 1.8861 | 1.6385 | 1.6221 | 1.6221 | 1.448 | .9054 |
| 20 | 1.7353 | 1.7353 | 1.6766 | 1.6598 | 1.5844 | 1.2193 | .8676 |
| 21 | 1.773 | 1.6598 | 1.7147 | 1.773 | 1.6598 | 1.3336 | .9431 |
| 22 | 1.7353 | 1.5844 | 1.5242 | 1.6975 | 1.5844 | 1.448 | .8676 |
| 23 | 1.773 | 1.6975 | 1.6004 | 1.6221 | 1.5844 | 1.3717 | .8299 |
| 24 | 1.773 | 1.8107 | 1.6598 | 1.6766 | 1.5844 | 1.6221 | 1.3336 |
| **Max** | **1.9616** | **1.9239** | **1.7909** | **1.8484** | **1.7353** | **1.6975** | **1.3336** |
| **Min** | **1.5089** | **1.5844** | **1.5242** | **1.4335** | **1.5089** | **1.2193** | **.8299** |
| **Avg** | **1.7384** | **1.7651** | **1.6616** | **1.6367** | **1.6142** | **1.5412** | **1.0310** |

 Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 213332 / 22 KV RANJANGAON SWITCHING NO1**
**Feeder No / Name : 303 / G &F Block MIDC Feeder KV- 22 / OUTGOING**
**NON SHEDDABLE EXPRESS HV FEEDERS (CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 5.9823 | 6.3375 | 5.4108 | 3.7342 | 6.4015 | 4.5344 | 6.6301 |
| 2 | 5.6775 | 6.8279 | 5.1821 | 3.7723 | 6.0966 | 4.3439 | 6.5539 |
| 3 | 5.7537 | 6.4883 | 4.9535 | 3.8104 | 6.0204 | 4.6868 | 6.592 |
| 4 | 6.0585 | 6.9787 | 5.144 | 4.4582 | 5.4108 | 4.5725 | 6.5539 |
| 5 | 6.2872 | 6.7524 | 5.0678 | 5.0297 | 5.2584 | 4.4963 | 6.5539 |
| 6 | 6.0966 | 6.9033 | 5.2584 | 5.487 | 5.0678 | 4.6106 | 6.4777 |
| 7 | 6.4396 | 4.8285 | 3.9247 | 5.9823 | 4.5344 | 5.4108 | 6.4015 |
| 8 | 7.0111 | 5.7339 | 3.6961 | 5.7918 | 5.2202 | 5.2584 | 7.0111 |
| 9 | 7.5065 | 6.0734 | 4.5725 | 7.316 | 4.8011 | 6.0966 | 8.1924 |
| 10 | 7.8464 | 6.6301 | 4.4582 | 7.6589 | 5.0297 | 6.6682 | 7.5446 |
| 11 | 7.0165 | 6.4396 | 1.3717 | 7.5446 | 5.0678 | 6.5539 | 8.421 |
| 12 | 8.035 | 6.3253 | 4.1914 | 6.973 | 4.6106 | 6.7825 | 7.7351 |
| 13 | 7.5446 | 6.1728 | 4.0771 | 3.8485 | 4.7249 | 2.8197 | 7.7351 |
| 14 | 7.7332 | 5.6394 | 4.1533 | 6.8968 | 4.9154 | 7.6589 | 8.0399 |
| 15 | 6.9787 | 6.4777 | 4.039 | 6.973 | 4.9154 | 7.1636 | 7.4303 |
| 16 | 8.0727 | 5.868 | 4.1914 | 7.0492 | 4.3439 | 7.0873 | 7.7351 |
| 17 | 4.1872 | 6.3253 | 4.4201 | 6.8968 | 4.4963 | 7.5446 | 7.9637 |
| 18 | 6.6392 | 5.7537 | 4.5344 | 6.973 | 4.4582 | 7.4303 | 7.5065 |
| 19 | 6.4883 | 5.3727 | 3.658 | 6.592 | 4.1914 | 6.9349 | 7.5065 |
| 20 | 6.8279 | 5.0297 | 3.5818 | 6.1347 | 4.382 | 6.4396 | 6.9349 |
| 21 | 5.998 | 5.868 | 3.9247 | 6.0585 | 4.8773 | 6.7063 | 7.3541 |
| 22 | 6.262 | 5.5632 | 3.8485 | 6.0966 | 4.6868 | 6.9349 | 6.7063 |
| 23 | 5.8093 | 5.4489 | 3.5818 | 6.6682 | 4.1914 | 6.8587 | 6.4777 |
| 24 | 5.868 | 6.6015 | 5.2584 | 3.658 | 6.5158 | 4.4201 | 6.592 |
| **Max** | **8.0727** | **6.9787** | **5.4108** | **7.6589** | **6.5158** | **7.6589** | **8.421** |
| **Min** | **4.1872** | **4.8285** | **1.3717** | **3.658** | **4.1914** | **2.8197** | **6.4015** |
| **Avg** | **6.5883** | **6.1017** | **4.2708** | **5.8918** | **5.0091** | **5.9172** | **7.1937** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 213332 / 22 KV RANJANGAON SWITCHING NO1**
**Feeder No / Name : 304 / Wheels India EXPS Feeder KV- 22 / OUTGOING**
**NON SHEDDABLE EXPRESS HV FEEDERS (CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .9122 | .9122 | .8642 | 1.7147 | 1.3214 | .9602 | 1.6766 |
| 2 | 1.1763 | 1.1763 | .9362 | 1.6385 | 1.2437 | 1.0322 | 1.6385 |
| 3 | 1.0802 | .9842 | 1.0082 | 1.6004 | 1.0883 | .9214 | 1.6004 |
| 4 | .9842 | 1.6975 | | 1.5242 | 1.2437 | 1.0867 | 1.5242 |
| 5 | .9362 | .9122 | | 1.5623 | 1.3992 | .9922 | 1.5623 |
| 6 | 1.1043 | .9164 | | 1.4861 | 1.5287 | .9922 | 1.6004 |
| 7 | .9362 | | .7922 | 1.4098 | 1.0364 | .945 | 1.5242 |
| 8 | 1.2003 | .9842 | 1.0562 | 1.6766 | 1.0623 | 1.773 | .9907 |
| 9 | .9602 | .8402 | .8642 | 1.7528 | 1.0623 | .8402 | 1.4098 |
| 10 | 1.5364 | 1.1043 | 1.9052 | 1.3733 | .9442 | 1.4098 | 1.1831 |
| 11 | 1.0082 | .9842 | 1.3717 | 1.2696 | .9217 | 1.4861 | 1.0517 |
| 12 | 1.0322 | .8162 | 1.448 | 1.0883 | .9667 | 1.3717 | .8676 |
| 13 | 1.4643 | 1.0802 | 1.829 | 1.323 | .9217 | 1.7147 | 1.3672 |
| 14 | 1.5604 | .9362 | 1.6004 | 1.2993 | .9667 | 1.448 | 1.078 |
| 15 | 1.1763 | 1.2483 | 1.8671 | 1.3938 | .9667 | 2.4768 | 1.446 |
| 16 | .9842 | .7682 | 1.4098 | .8977 | 1.0341 | 1.5242 | 1.6221 |
| 17 | .7202 | .9842 | 1.7528 | 1.1812 | 1.0924 | 1.6004 | .9728 |
| 18 | 1.2963 | 1.1523 | 1.6385 | 1.512 | 1.1043 | 1.5242 | 1.078 |
| 19 | 1.4163 | 1.0322 | 2.2862 | 1.4647 | 1.0562 | 1.6004 | 1.2357 |
| 20 | 1.1043 | 1.0562 | 1.2193 | 1.1576 | 1.0562 | 1.6004 | .9728 |
| 21 | .7202 | .9122 | 1.5623 | 1.1576 | 1.0322 | 1.6385 | 1.078 |
| 22 | 1.2963 | 1.0802 | 1.829 | 1.3702 | 1.0322 | 1.7147 | .9465 |
| 23 | 1.3923 | 1.1523 | 1.7528 | 1.4411 | 1.0322 | 1.6766 | 1.3672 |
| 24 | 1.0562 | 1.3443 | .8162 | 1.7909 | 1.3474 | 1.0802 | 1.7147 |
| **Max** | **1.5604** | **1.6975** | **2.2862** | **1.7909** | **1.5287** | **2.4768** | **1.7147** |
| **Min** | **.7202** | **.7682** | **.7922** | **.8977** | **.9217** | **.8402** | **.8676** |
| **Avg** | **1.1273** | **1.0467** | **1.4195** | **1.4202** | **1.1025** | **1.3921** | **1.3129** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 213332 / 22 KV RANJANGAON SWITCHING NO1**
**Feeder No / Name : 305 / 22 KV POLYONE Feeder KV- 22 / OUTGOING**
**NON SHEDDABLE EXPRESS HV FEEDERS (CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3018 | .3018 | .1132 | .2286 | .1886 | | |
| 2 | .2641 | .2641 | .1132 | .2286 | .1886 | | |
| 3 | .3018 | .2641 | .0754 | .2286 | .2263 | | |
| 4 | .2641 | .3018 | .1132 | .2286 | .2263 | | |
| 5 | .2641 | .2641 | .0754 | .2286 | .2641 | | |
| 6 | .3018 | .3018 | .1132 | .2667 | .2263 | | |
| 7 | .3018 | .3018 | .0754 | .2667 | .2641 | | |
| 8 | .2263 | .2641 | .1509 | .2667 | | .2263 | .3429 |
| 9 | .2641 | .2263 | .0754 | .2286 | | .1886 | .2667 |
| 10 | .3018 | .2263 | .0762 | .415 | | .2286 | .3018 |
| 11 | .3395 | .2641 | .1143 | .3395 | | .2667 | .3018 |
| 12 | .3018 | .2641 | .1143 | .3772 | | .3048 | .3772 |
| 13 | .2641 | .2263 | .0762 | .3772 | | .3048 | .3395 |
| 14 | .3395 | .2263 | .1143 | .3018 | | .3048 | .3018 |
| 15 | .3018 | .1509 | .1143 | .3018 | | .2667 | .3018 |
| 16 | .2641 | .1509 | .1143 | .2263 | | .2667 | .3018 |
| 17 | .1132 | .1132 | .1905 | .2641 | | .2286 | .2641 |
| 18 | .3018 | .1509 | .1524 | .2641 | | .2286 | .3018 |
| 19 | .2263 | .1886 | .2286 | .2641 | | .2286 | .3018 |
| 20 | .2263 | .2263 | .2286 | .2641 | | .2286 | .2641 |
| 21 | .2641 | .2263 | .2667 | .2263 | | .2667 | .3018 |
| 22 | .2263 | .1886 | .2286 | .2263 | | .3048 | .2641 |
| 23 | .2263 | .1886 | .2286 | .2263 | | .2667 | .2641 |
| 24 | .3018 | .2641 | .1132 | .2286 | .2263 | | .2667 |
| **Max** | **.3395** | **.3018** | **.2667** | **.415** | **.2641** | **.3048** | **.3772** |
| **Min** | **.1132** | **.1132** | **.0754** | **.2263** | **.1886** | **.1886** | **.2641** |
| **Avg** | **.2704** | **.2311** | **.1361** | **.2698** | **.2263** | **.2569** | **.2979** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 213342 / 22 kV Ranjangaon MIDC SW II**
**Feeder No / Name : 301 / Classic auto tube NON SHEDDABLE EXPRESS HV FEEDERS**
**Feeder KV- 22 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.2634 | 1.6975 | 2.2634 | 2.0748 | 1.8861 | 1.8861 | 2.0748 |
| 2 | 2.2634 | 1.6975 | 2.0748 | 2.0748 | 1.8861 | 1.6975 | 2.2634 |
| 3 | 2.0748 | 1.8861 | 1.5844 | 1.8861 | 1.6975 | 1.5089 | 2.0748 |
| 4 | 2.2634 | 1.6975 | 1.5089 | 2.0748 | 1.8861 | 1.6975 | 1.8861 |
| 5 | 2.0748 | 1.8861 | 1.6975 | 2.2634 | 1.8861 | 1.6975 | 2.0748 |
| 6 | 1.8861 | 1.8861 | 1.5844 | 1.8861 | 1.6975 | 1.5089 | 2.2634 |
| 7 | 1.1317 | 1.8861 | 1.5844 | 2.0748 | 2.0748 | 1.5089 | 1.1317 |
| 8 | 2.2634 | 2.0748 | 1.5089 | 1.8861 | 1.8861 | 2.2634 | 1.8861 |
| 9 | 1.8861 | 1.8861 | 1.8861 | 2.0748 | 1.8861 | 1.5089 | 1.8861 |
| 10 | 1.8671 | 1.5089 | 1.8861 | 1.5089 | 1.8861 | 1.8861 | 1.5089 |
| 11 | 1.8107 | 1.3203 | 1.8861 | 1.6975 | 1.5089 | 1.1317 | 1.8861 |
| 12 | 1.6975 | 1.5089 | 1.5089 | 1.8861 | 1.5089 | 1.8861 | 1.5089 |
| 13 | 1.1317 | 1.6975 | 1.6975 | 1.6975 | 1.5089 | 1.5089 | 2.0748 |
| 14 | 1.8107 | 2.0748 | 1.6975 | 1.5089 | 1.6975 | 1.5089 | 2.452 |
| 15 | 1.1317 | .7545 | .3772 | 1.5089 | 1.1317 | 1.1317 | |
| 16 | | 1.8861 | 1.8861 | 1.8861 | 2.0748 | 2.0748 | 2.2634 |
| 17 | 2.0748 | 2.0748 | 2.0748 | 2.0748 | 2.1125 | 2.2634 | 2.2634 |
| 18 | 2.0748 | 2.0748 | 2.0748 | 2.0748 | 2.0748 | 2.452 | 1.8861 |
| 19 | 2.0748 | 2.2634 | 2.2634 | 1.8861 | 2.0748 | 2.0748 | 1.5089 |
| 20 | 2.2634 | 1.8861 | 2.452 | 1.8861 | 2.2634 | 1.8861 | 1.8861 |
| 21 | 1.8861 | 2.2634 | 1.8861 | | 2.2634 | 2.0748 | 2.2634 |
| 22 | 2.0748 | 2.2634 | 2.0748 | 1.8861 | 2.2634 | 2.0748 | 2.0748 |
| 23 | 1.1317 | 1.5089 | 1.1317 | 1.6975 | 1.8861 | 1.8861 | 1.8861 |
| 24 | 2.0748 | 1.4632 | 2.452 | 2.2634 | 1.6975 | 1.8861 | 2.2634 |
| **Max** | **2.2634** | **2.2634** | **2.452** | **2.2634** | **2.2634** | **2.452** | **2.452** |
| **Min** | **1.1317** | **.7545** | **.3772** | **1.5089** | **1.1317** | **1.1317** | **1.1317** |
| **Avg** | **1.8788** | **1.7978** | **1.7934** | **1.9025** | **1.8641** | **1.7918** | **1.9682** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 213342 / 22 kV Ranjangaon MIDC SW II**
**Feeder No / Name : 302 / Jabil Circuit NON SHEDDABLE EXPRESS HV FEEDERS**
**Feeder KV- 22 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.4335 | 1.3817 | 1.3203 | 1.1694 | 1.1203 | .5281 | 1.4712 |
| 2 | 1.3203 | 1.419 | 1.2826 | 1.358 | .9709 | .6036 | 1.4335 |
| 3 | 1.358 | 1.3817 | 1.2071 | 1.3203 | .8215 | .5658 | 1.3957 |
| 4 | 1.2826 | 1.3817 | 1.1694 | 1.2826 | .8589 | .6036 | 1.358 |
| 5 | 1.3203 | 1.307 | 1.2826 | 1.358 | .7468 | .5658 | 1.3957 |
| 6 | 1.3957 | 1.419 | 1.3203 | 1.3203 | .7842 | 1.1317 | 1.4335 |
| 7 | 1.358 | 1.307 | 1.358 | 1.358 | .679 | 1.3203 | 1.4712 |
| 8 | 1.3957 | 1.358 | 1.4335 | 1.358 | .6722 | 1.4712 | 1.4335 |
| 9 | 1.3443 | 1.6221 | 1.4335 | 1.4335 | .7167 | 1.4335 | 1.4712 |
| 10 | 1.4335 | 1.5089 | 1.3203 | 1.3957 | .679 | 1.3957 | 1.5089 |
| 11 | 1.4712 | 1.5466 | 1.5089 | 1.5089 | .679 | 1.4712 | 1.5089 |
| 12 | 1.419 | 1.5466 | 1.5089 | 1.4937 | .7167 | 1.5089 | 1.5466 |
| 13 | 1.4712 | | 1.4712 | 1.4563 | .7167 | 1.5089 | 1.5844 |
| 14 | 1.4712 | 1.5844 | 1.5466 | 1.531 | .7545 | 1.4712 | 1.5844 |
| 15 | 1.5844 | 1.5466 | 1.5089 | 1.419 | .679 | 1.5089 | |
| 16 | 1.5089 | 1.5089 | 1.4335 | 1.4937 | .6413 | 1.5844 | 1.5466 |
| 17 | 1.5466 | 1.4712 | 1.4712 | 1.5466 | .6036 | 1.5466 | 1.5089 |
| 18 | 1.4712 | 1.4335 | 1.358 | 1.4937 | .6036 | 1.5089 | 1.5089 |
| 19 | 1.5089 | 1.3957 | 1.3957 | 1.307 | .6036 | 1.5089 | 1.5466 |
| 20 | 1.4937 | 1.3957 | 1.3203 | 1.419 | .5658 | 1.4712 | 1.5089 |
| 21 | 1.419 | 1.5466 | 1.2449 | 1.3443 | .5658 | 1.3957 | 1.3957 |
| 22 | 1.2696 | 1.3957 | 1.2449 | 1.2696 | .6413 | 1.4335 | 1.358 |
| 23 | 1.2696 | 1.3203 | 1.2449 | 1.1949 | .6036 | 1.358 | 1.4335 |
| 24 | 1.358 | 1.3443 | 1.3203 | 1.2071 | 1.307 | .5281 | 1.2346 |
| **Max** | **1.5844** | **1.6221** | **1.5466** | **1.5466** | **1.307** | **1.5844** | **1.5844** |
| **Min** | **1.2696** | **1.307** | **1.1694** | **1.1694** | **.5658** | **.5281** | **1.2346** |
| **Avg** | **1.4127** | **1.4401** | **1.3627** | **1.3766** | **.7388** | **1.2260** | **1.4625** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 213342 / 22 kV Ranjangaon MIDC SW II**
**Feeder No / Name : 303 / Haier NON SHEDDABLE EXPRESS HV FEEDERS**
**Feeder KV- 22 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 3.7723 |
| Max | 3.7723 |
| Min | 3.7723 |
| Avg | 3.7723 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 213342 / 22 kV Ranjangaon MIDC SW II**
**Feeder No / Name : 304 / Starion NON SHEDDABLE EXPRESS HV FEEDERS**
**Feeder KV- 22 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4954 | .5281 | .5281 | .5658 | .5281 | .4904 | .9054 |
| 2 | .5335 | .4904 | .4904 | .4904 | .4527 | .4527 | .9808 |
| 3 | .5335 | .4904 | .4527 | .6036 | .415 | .3772 | .8299 |
| 4 | .4572 | .4527 | .4904 | .5281 | .4904 | .415 | 1.0185 |
| 5 | .4954 | .5281 | .5658 | .4527 | .5281 | .4527 | .9431 |
| 6 | .5335 | .5658 | .5281 | .5281 | .4527 | .7545 | 1.0185 |
| 7 | .4572 | .5281 | .4904 | .6036 | .3772 | 1.0185 | 1.094 |
| 8 | .5335 | .3772 | .4904 | .5658 | .415 | 1.0185 | 1.358 |
| 9 | .5658 | .5281 | .7922 | .6413 | .4527 | 1.0669 | 1.5844 |
| 10 | .6036 | .4527 | .5658 | | .4527 | 1.1431 | 1.5089 |
| 11 | .6036 | .415 | .6036 | .6413 | .4527 | 1.448 | 1.4335 |
| 12 | .5658 | .4527 | .4904 | .6036 | .4527 | 1.1431 | 1.4712 |
| 13 | .4904 | .415 | .4527 | .4904 | .4904 | 1.0669 | 1.5466 |
| 14 | .6036 | .4904 | .4904 | .5658 | .415 | 1.1431 | 1.5466 |
| 15 | | .3772 | .6036 | .6036 | .3772 | 1.3717 | |
| 16 | .4904 | .4527 | .4527 | .5281 | .4527 | 1.4098 | 1.1694 |
| 17 | .6036 | .4904 | .5281 | .5281 | .3772 | .9907 | 1.1317 |
| 18 | .5658 | .3772 | .4904 | .5658 | .3772 | .9526 | 1.0562 |
| 19 | .4904 | .3772 | .6036 | .4904 | .415 | .9808 | .9808 |
| 20 | .5658 | .6036 | .6413 | .5658 | .3772 | 1.0185 | .9054 |
| 21 | .5658 | .6036 | .4527 | .5281 | .5281 | .8299 | .9431 |
| 22 | .5281 | .4527 | .4904 | .6036 | .4904 | 1.0185 | .8676 |
| 23 | .4527 | .4527 | .4904 | .5281 | .5281 | .8299 | .9054 |
| 24 | .5335 | .4904 | .5658 | .4527 | .5658 | .5281 | .9431 |
| **Max** | **.6036** | **.6036** | **.7922** | **.6413** | **.5658** | **1.448** | **1.5844** |
| **Min** | **.4527** | **.3772** | **.4527** | **.4527** | **.3772** | **.3772** | **.8299** |
| **Avg** | **.5334** | **.4747** | **.5313** | **.5511** | **.4527** | **.9134** | **1.1366** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 213342 / 22 kV Ranjangaon MIDC SW II**
**Feeder No / Name : 305 / 22 KV Ohusang NON SHEDDABLE EXPRESS HV FEEDERS**
**Feeder KV- 22 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5281 | .4527 | .6036 | .5281 | .4904 | | .3772 |
| 2 | .5658 | .4904 | .5658 | .5658 | .5281 | | .415 |
| 3 | .4904 | .415 | .5281 | .6036 | .4527 | | .3395 |
| 4 | .5658 | .4527 | .5281 | .5281 | .4904 | | .2263 |
| 5 | .5281 | .4904 | .6036 | .6036 | .4527 | | .1886 |
| 6 | .6413 | .5281 | .5658 | .5281 | .415 | | .2263 |
| 7 | .6413 | .5658 | .6036 | .6036 | .4527 | .2641 | .2263 |
| 8 | .5658 | .4904 | .6036 | .5658 | | .5281 | .4527 |
| 9 | .5281 | .6413 | .6413 | .5281 | | .3772 | .3018 |
| 10 | .5281 | .5281 | .4904 | .5281 | | .415 | .3395 |
| 11 | .4904 | .6413 | .4527 | .5281 | | .4115 | .3772 |
| 12 | .5281 | .5658 | .5281 | .6036 | | .3018 | .3772 |
| 13 | .4904 | .5658 | .4904 | .6036 | | .4527 | .3018 |
| 14 | .5281 | .6036 | .4904 | .5281 | | .415 | .4527 |
| 15 | | .5281 | .4527 | .5281 | | .3395 | |
| 16 | .5658 | .5281 | .4904 | .6036 | | .415 | .415 |
| 17 | .5281 | .4904 | .5281 | .4904 | | .415 | .4527 |
| 18 | .4904 | .4527 | .5281 | .5281 | | .3772 | .415 |
| 19 | .4904 | .5658 | .5658 | .4904 | | .4527 | .4904 |
| 20 | .5281 | .6036 | .6036 | .5281 | | .415 | .4527 |
| 21 | .5658 | .6036 | .4904 | .5281 | | .2641 | .2641 |
| 22 | .5281 | .5658 | .5281 | .5658 | | .415 | .3395 |
| 23 | .5281 | .5658 | .4527 | .5281 | | | .3772 |
| 24 | .5658 | .4904 | .6036 | .6036 | .5281 | | .4527 |
| **Max** | **.6413** | **.6413** | **.6413** | **.6036** | **.5281** | **.5281** | **.4904** |
| **Min** | **.4904** | **.415** | **.4527** | **.4904** | **.415** | **.2641** | **.1886** |
| **Avg** | **.5396** | **.5344** | **.5391** | **.5517** | **.4763** | **.3912** | **.3592** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 214333 / 33/11 kv Pabal**
**Feeder No / Name : 201 / 11 kv Pabal** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4854 | | | | | |
| 2 | .4854 | | .4668 | | | |
| 3 | .724 | | | | | |
| 4 | 1.307 | | | | | |
| 5 | 1.9044 | | 2.5393 | | .5788 | |
| 6 | 2.2592 | | | | .8688 | |
| 7 | 2.6886 | | 2.9874 | | .8954 | |
| 8 | | | 3.062 | | | |
| 9 | 2.7633 | | | | | |
| 10 | 2.8006 | 3.006 | | 2.4434 | | .5041 |
| 11 | .5975 | | | | | |
| 12 | .5249 | .4668 | | | | |
| 13 | .5228 | | | | | 3.4728 |
| 14 | .5041 | .4668 | | | | |
| 15 | .5228 | | | | | |
| 16 | .4854 | .4668 | | | | |
| 17 | .5601 | | | | | |
| 18 | .6161 | | | .5316 | | |
| 19 | .7468 | | | .724 | | |
| 20 | .6722 | .7468 | | | | |
| 21 | .6348 | | | .6283 | | .6161 |
| 22 | .5601 | | | | | |
| 23 | .5228 | | | | | |
| 24 | .4854 | .4668 | .4668 | | | |
| **Max** | **2.8006** | **3.006** | **3.062** | **2.4434** | **.8954** | **3.4728** |
| **Min** | **.4854** | **.4668** | **.4668** | **.5316** | **.5788** | **.5041** |
| **Avg** | **1.0162** | **.9367** | **1.9045** | **1.0818** | **.781** | **1.531** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 214333 / 33/11 kv Pabal**
**Feeder No / Name : 202 / 11 kv Dhamari SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5601 | | | | | |
| 2 | .7095 | | .5975 | | | |
| 4 | 1.3443 | | | | | |
| 5 | 2.0538 | | 4.0329 | | .9335 | |
| 6 | 2.2592 | | | | 1.3169 | |
| 7 | 3.0434 | | 4.2383 | | 1.576 | |
| 8 | 3.6595 | | 4.2943 | | | |
| 9 | 3.8089 | | | | | |
| 10 | 4.0329 | 4.425 | | 3.9819 | | .6908 |
| 11 | .5228 | | | | | |
| 12 | .4108 | .6348 | | | | |
| 13 | .4481 | | | | | 2.838 |
| 14 | .5041 | .5601 | | | | |
| 15 | .5228 | | | | | |
| 16 | .5788 | .4854 | | | | |
| 17 | .7095 | | | | | |
| 18 | .9149 | .8215 | | .7442 | | |
| 19 | .8962 | | | 1.2308 | | |
| 20 | 1.0082 | | | | | |
| 21 | .6722 | | | .9425 | | .8962 |
| 22 | .7095 | | | | | |
| 23 | .6348 | | | | | |
| 24 | .5601 | .6161 | .5975 | | | |
| **Max** | **4.0329** | **4.425** | **4.2943** | **3.9819** | **1.576** | **2.838** |
| **Min** | **.4108** | **.4854** | **.5975** | **.7442** | **.9335** | **.6908** |
| **Avg** | **1.3289** | **1.2572** | **2.7521** | **1.7249** | **1.2755** | **1.475** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 214333 / 33/11 kv Pabal**
**Feeder No / Name : 203 / 11 kv Kendur SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7842 | | | | | |
| 2 | .7842 | | | | | |
| 3 | .8402 | | | | | |
| 4 | .9709 | | | | | |
| 5 | 1.2136 | | .9709 | | 2.0058 | |
| 6 | 1.4003 | | | | 2.7351 | |
| 7 | 1.4003 | | 1.4377 | | 2.959 | |
| 8 | 1.3256 | | 1.3443 | | | |
| 9 | .7842 | | | | | |
| 10 | .4481 | 1.0082 | | .4477 | | 2.2779 |
| 11 | 1.7924 | | | | | |
| 12 | 2.0351 | 4.4437 | | | | |
| 13 | 2.2592 | | | | | .3361 |
| 14 | 2.5766 | | | | | |
| 15 | 2.5019 | | | | | |
| 16 | 2.4832 | 4.7238 | | | | |
| 17 | 2.5019 | | | | | |
| 18 | .5601 | 3.8462 | | 3.1642 | | |
| 19 | 1.3443 | | | 1.0608 | | |
| 20 | 1.1949 | 1.1016 | | | | |
| 21 | .8962 | | | .8501 | | .8029 |
| 22 | .5975 | | | | | |
| 23 | .5415 | | | | | |
| 24 | .7842 | .3547 | .6348 | | | |
| **Max** | **2.5766** | **4.7238** | **1.4377** | **3.1642** | **2.959** | **2.2779** |
| **Min** | **.4481** | **.3547** | **.6348** | **.4477** | **2.0058** | **.3361** |
| **Avg** | **1.3342** | **2.5797** | **1.0969** | **1.3807** | **2.5666** | **1.1390** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 214333 / 33/11 kv Pabal**
**Feeder No / Name : 204 / 11kv Pabal Gaothan GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1307 | | | | | |
| 2 | .1307 | | .1494 | | | |
| 3 | .168 | | | | | |
| 4 | .2054 | | | | | |
| 5 | .2801 | | .2614 | | .2054 | |
| 6 | .3361 | | | | .3292 | |
| 7 | .3921 | | .4108 | | .3475 | |
| 8 | .3547 | | .3734 | | | |
| 9 | .3547 | | | | | |
| 10 | .3547 | .3174 | | .2561 | | .3921 |
| 11 | .2987 | | | .2012 | | |
| 12 | .2801 | .3734 | | .2172 | | |
| 13 | .2801 | | | | | .2987 |
| 14 | .2614 | .2801 | | .2126 | | |
| 15 | .2987 | | | .1629 | | |
| 16 | .3547 | .2427 | | .1646 | | |
| 17 | .3174 | | | | | |
| 18 | .2987 | .2801 | | .2126 | | |
| 19 | | | | .2772 | | |
| 20 | .2801 | .3361 | | | | |
| 21 | .2241 | | | .2801 | | .2614 |
| 22 | .1867 | | | | | |
| 23 | .1494 | | | | | |
| 24 | .1307 | .1494 | .1494 | | | |
| **Max** | **.3921** | **.3734** | **.4108** | **.2801** | **.3475** | **.3921** |
| **Min** | **.1307** | **.1494** | **.1494** | **.1629** | **.2054** | **.2614** |
| **Avg** | **.2638** | **.2827** | **.2689** | **.2205** | **.2940** | **.3174** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 214333 / 33/11 kv Pabal**
**Feeder No / Name : 205 / 11 KV Kendur dhamari Gfss GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2614 | | | | | |
| 2 | .2614 | | .2427 | | | |
| 3 | .4108 | | | | | |
| 4 | .5601 | | | | | |
| 5 | .6348 | | .5415 | | .4066 | |
| 6 | .7095 | | | | .5853 | |
| 7 | .7095 | | .7655 | | .7499 | |
| 8 | .6161 | | .7468 | | | |
| 9 | .5228 | | | | | |
| 10 | .4108 | .5975 | | .499 | | .4668 |
| 11 | .3734 | | | .3841 | | |
| 12 | .3547 | .5041 | | .4024 | | |
| 13 | .3174 | | | .3109 | | .3361 |
| 14 | .2801 | .4668 | | .3109 | | |
| 15 | .3361 | | | .3012 | | |
| 16 | .3547 | .4481 | | .2896 | | |
| 17 | .4108 | | | .3801 | | |
| 18 | .4854 | | | .4163 | | |
| 19 | .6348 | | | .5544 | | |
| 20 | .6722 | .5788 | | | | |
| 21 | .543 | | | .5041 | | .4668 |
| 22 | .5228 | | | | | |
| 23 | .3547 | | | | | |
| 24 | .2614 | .3174 | .2801 | | | |
| **Max** | **.7095** | **.5975** | **.7655** | **.5544** | **.7499** | **.4668** |
| **Min** | **.2614** | **.3174** | **.2427** | **.2896** | **.4066** | **.3361** |
| **Avg** | **.4583** | **.4855** | **.5153** | **.3957** | **.5806** | **.4232** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 214514 / 33/22 kV PIMPALE JAGTAP Sub St**
**Feeder No / Name : 201 / 11 KV pimple jagtap Feeder KV- 11 / OUTGOING SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2054 | .2241 | .1867 | .1867 | .2241 | .1867 | .1867 |
| 2 | .2054 | .2241 | .2241 | .1867 | .1867 | .1867 | .1867 |
| 3 | .2054 | .2614 | .2241 | .1867 | .1867 | .1867 | .2614 |
| 4 | .2987 | .2614 | .2987 | .2054 | .2614 | .2614 | .2614 |
| 5 | .3361 | .5228 | .3361 | .2987 | .3361 | .3361 | .3361 |
| 6 | .3734 | .4481 | .4481 | .4108 | .4481 | .4108 | .4854 |
| 7 | .5041 | .4854 | .4854 | .4481 | .5601 | .4668 | .4481 |
| 8 | .4294 | .4481 | .4481 | .4108 | .4481 | .4481 | .3361 |
| 9 | .3174 | .3361 | .3361 | .2987 | .3361 | .3174 | .3361 |
| 10 | .2241 | .2614 | .2614 | .2241 | .2614 | .2614 | .3361 |
| 11 | 1.0456 | 1.0456 | 1.1203 | 1.0829 | .9724 | 1.1203 | .8215 |
| 12 | 1.2696 | 1.1203 | 1.1203 | 1.2323 | 1.0562 | 1.1576 | 1.0082 |
| 13 | 1.2323 | 1.1576 | 1.1203 | 1.2883 | 1.0395 | 1.1576 | 1.0082 |
| 14 | 1.2696 | 1.2323 | 1.307 | 1.2696 | 1.073 | 1.1203 | .9709 |
| 15 | 1.1203 | 1.1949 | 1.419 | 1.2323 | 1.0227 | 1.0456 | .8962 |
| 16 | 1.1203 | 1.2323 | 1.3443 | 1.2696 | .9556 | 1.0456 | .8962 |
| 17 | 1.1576 | 1.2696 | 1.1203 | 1.1203 | .8551 | 1.0829 | .8589 |
| 18 | 1.1203 | 1.2323 | 1.0456 | 1.1203 | .8383 | 1.0082 | .7842 |
| 19 | .3361 | .3361 | .4108 | .3361 | .2427 | .3361 | .3361 |
| 20 | .3361 | .3361 | .3361 | .3361 | .2987 | .3361 | .2987 |
| 21 | .3361 | .2614 | .2987 | .3361 | .2801 | .3361 | .2241 |
| 22 | .2987 | .2241 | .1867 | .2614 | .2241 | .2614 | .2241 |
| 23 | .2614 | .2241 | .1867 | .2241 | .2054 | .2241 | .1867 |
| 24 | .2054 | .2614 | 1.8861 | .1867 | .2241 | .1867 | .2241 |
| **Max** | **1.2696** | **1.2696** | **1.8861** | **1.2883** | **1.073** | **1.1576** | **1.0082** |
| **Min** | **.2054** | **.2241** | **.1867** | **.1867** | **.1867** | **.1867** | **.1867** |
| **Avg** | **.5920** | **.6084** | **.6730** | **.5897** | **.5224** | **.5617** | **.4963** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 214514 / 33/22 kV PIMPALE JAGTAP Sub St**
**Feeder No / Name : 301 / 22 KV Pimpale Jagtap AG Feeder KV- 22 / OUTGOING SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7468 | .7468 | .8215 | .8215 | .8215 | .7468 | |
| 2 | .7468 | .7468 | .7468 | .8215 | .7842 | .7468 | |
| 3 | .8589 | 1.0456 | .8215 | .8589 | .8215 | .8589 | |
| 4 | 1.0082 | 1.1203 | 1.4937 | .9709 | 1.1203 | .9709 | |
| 5 | 1.1949 | 1.8671 | 1.643 | 1.1949 | 1.3443 | 1.2696 | |
| 6 | 1.4563 | 1.7177 | 1.7924 | 1.643 | 1.5684 | 1.6057 | |
| 7 | 1.643 | 1.9418 | 1.8671 | 1.8671 | 1.8671 | 1.8671 | |
| 8 | 1.531 | 1.6057 | 1.7177 | 1.6057 | 1.7551 | 1.643 | |
| 9 | 1.1949 | 1.1203 | 1.1203 | 1.1203 | 1.1203 | 1.1949 | 1.531 |
| 10 | .8962 | 1.0082 | .9335 | .8962 | .9709 | .8589 | |
| 11 | 4.2943 | 3.9956 | 3.9209 | 3.7715 | 3.0849 | 3.6969 | |
| 12 | 4.8171 | 4.9291 | 4.481 | 3.7342 | 3.6214 | 1.0082 | |
| 13 | 4.7798 | 4.6677 | 4.6677 | 4.1076 | 3.8561 | 1.0829 | 1.3443 |
| 14 | 4.9291 | 4.7051 | 4.481 | 4.2943 | 3.9232 | 1.0082 | 1.2696 |
| 15 | 5.0412 | 4.5931 | 4.4063 | 4.3317 | 3.2861 | .9709 | .7468 |
| 16 | 4.5557 | 4.481 | 3.7342 | 4.2196 | | .9709 | 1.1576 |
| 17 | 4.481 | 4.4063 | 3.6969 | | 3.2861 | 1.0829 | 1.1949 |
| 18 | 4.481 | 4.4437 | 3.7715 | 3.8462 | 3.219 | 1.3443 | 1.531 |
| 19 | 1.3817 | 1.307 | 1.3443 | 1.307 | 1.307 | 1.307 | 1.4937 |
| 20 | 1.307 | 1.4563 | 1.3443 | 1.307 | 1.307 | 1.3817 | 1.419 |
| 21 | 1.2696 | 1.3443 | 1.1949 | 1.2323 | 1.1949 | 1.1576 | 1.3443 |
| 22 | 1.1203 | .9709 | 1.0456 | 1.1576 | .9709 | 1.2696 | 1.1203 |
| 23 | 1.0456 | .8215 | .8962 | 1.0829 | .8215 | | .9335 |
| 24 | .7468 | .8962 | .8215 | .8215 | .9709 | .7842 | |
| **Max** | **5.0412** | **4.9291** | **4.6677** | **4.3317** | **3.9232** | **3.6969** | **1.531** |
| **Min** | **.7468** | **.7468** | **.7468** | **.8215** | **.7842** | **.7468** | **.7468** |
| **Avg** | **2.3136** | **2.3308** | **2.1985** | **2.0441** | **1.8705** | **1.2534** | **1.2572** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 214514 / 33/22 kV PIMPALE JAGTAP Sub St**
**Feeder No / Name : 303 / 22 KV Industrial Feeder KV- 22 / OUTGOING SHEDDABLE FEEDER HAVING WEEKLY STAGGERING (MIDC, EQUIVALENT)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.3957 | 1.3817 | .7468 | 1.3443 | 1.8671 | 1.4712 | 1.7924 |
| 2 | 1.358 | 1.419 | .9335 | 1.307 | 1.7177 | 1.4937 | 1.8298 |
| 3 | 1.4335 | 1.4937 | .8215 | 1.419 | 1.4563 | 1.5466 | 1.4563 |
| 4 | 1.5466 | 1.6804 | .7842 | 1.3443 | 1.1203 | 1.5089 | 1.643 |
| 5 | 1.6221 | 1.1949 | .7842 | 1.4937 | 1.4937 | 1.5466 | 1.8298 |
| 6 | 1.6598 | 1.4563 | .8215 | 1.419 | 1.4937 | 1.4712 | 1.7551 |
| 7 | 1.4335 | 1.0082 | 1.1576 | 1.3817 | 1.3817 | 1.2826 | 1.7177 |
| 8 | 1.8107 | 1.0082 | 1.531 | 2.0911 | 1.8671 | 1.9044 | 2.1658 |
| 9 | 1.9418 | 1.2323 | 2.1285 | 2.1285 | 1.531 | 2.0911 | 1.7551 |
| 10 | 2.0165 | 1.2323 | 1.6057 | 2.1285 | 1.8298 | 2.3899 | 1.1949 |
| 11 | 2.0538 | 1.419 | 2.0911 | 2.3899 | 2.0911 | 2.0911 | 2.0538 |
| 12 | 2.3525 | 1.2696 | 1.7924 | 2.4272 | 1.7551 | 2.3899 | 2.1285 |
| 13 | 2.3525 | 1.2323 | 1.6804 | 2.3899 | 1.6804 | 2.1285 | 2.2032 |
| 14 | 2.1658 | 1.307 | 2.0538 | 2.5766 | 2.3152 | 2.2405 | 2.1658 |
| 15 | 2.2032 | 1.2696 | 2.0165 | 2.5393 | 1.9044 | 2.1658 | 2.4646 |
| 16 | 2.2405 | 1.0082 | 1.6804 | 2.4272 | 2.4646 | 2.1285 | 2.3152 |
| 17 | 2.0911 | 1.0082 | 2.0911 | 2.3525 | 2.1658 | 2.0538 | 2.3152 |
| 18 | 2.2405 | 1.0082 | 2.0165 | 2.0911 | 2.3899 | 2.2405 | 2.0165 |
| 19 | 1.9044 | .9709 | 1.643 | 1.7551 | 2.1658 | 1.6804 | 2.1658 |
| 20 | 1.9791 | .8962 | 1.7551 | 1.6804 | 1.9791 | 1.5684 | 2.0538 |
| 21 | 2.0538 | .8962 | 1.8298 | 1.8298 | 2.0538 | 1.9418 | 1.9791 |
| 22 | 1.8671 | .8215 | 1.8671 | 1.8671 | 1.773 | 1.5684 | 1.8671 |
| 23 | 1.4937 | .7842 | 1.7924 | 1.8671 | 1.773 | 1.4563 | 1.7177 |
| 24 | 1.4335 | 1.7551 | .6348 | | 1.8671 | 1.5089 | 1.4937 |
| **Max** | **2.3525** | **1.7551** | **2.1285** | **2.5766** | **2.4646** | **2.3899** | **2.4646** |
| **Min** | **1.358** | **.7842** | **.6348** | **1.307** | **1.1203** | **1.2826** | **1.1949** |
| **Avg** | **1.8604** | **1.1981** | **1.5108** | **1.9239** | **1.8390** | **1.8279** | **1.9200** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 214541 / 33/11 KV Kanhur Mesai**
**Feeder No / Name : 201 / 11 KV Khanur AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | .6516 |
| Max | .6516 |
| Min | .6516 |
| Avg | .6516 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 214541 / 33/11 KV Kanhur Mesai**
**Feeder No / Name : 203 / 11 KV Varude AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | .2012 |
| Max | .2012 |
| Min | .2012 |
| Avg | .2012 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 217052 / 132 kV Whirlpool**
**Feeder No / Name : 301 / Kondapuri Industrial Feeder KV- 22 / OUTGOING SHEDDABLE FEEDER HAVING WEEKLY STAGGERING (MIDC, EQUIVALENT)**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 3.7723 |
| Max | 3.7723 |
| Min | 3.7723 |
| Avg | 3.7723 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 217052 / 132 kV Whirlpool**
**Feeder No / Name : 302 / Ranjangaon Ag Feeder KV- 22 / OUTGOING SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 3.7723 |
| Max | 3.7723 |
| Min | 3.7723 |
| Avg | 3.7723 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 217052 / 132 kV Whirlpool**
**Feeder No / Name : 303 / 22 kv LG NON SHEDDABLE EXPRESS HV FEEDERS**
**Feeder KV- 22 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 3.7723 |
| Max | 3.7723 |
| Min | 3.7723 |
| Avg | 3.7723 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 217052 / 132 kV Whirlpool**
**Feeder No / Name : 304 / 22 KV RANJANGAON GAOTHAN GAOTHAN FEEDER**
**Feeder KV- 22 / OUTGOING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 23 | 3.7723 |
| 24 | 1.5432 |
| Max | 3.7723 |
| Min | 1.5432 |
| Avg | 2.6578 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 217052 / 132 kV Whirlpool**
**Feeder No / Name : 702 / 132 KV Whirlpool NON SHEDDABLE EHV INDUSTRIAL FEEDERS**
**Feeder KV- 132 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 1.6461 |
| Max | 1.6461 |
| Min | 1.6461 |
| Avg | 1.6461 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 217052 / 132 kV Whirlpool**
**Feeder No / Name : 703 / M/S. Neosym Industries NON SHEDDABLE EHV INDUSTRIAL FEEDERS**
**Feeder KV- 132 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 4.7325 |
| Max | 4.7325 |
| Min | 4.7325 |
| Avg | 4.7325 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 217052 / 132 kV Whirlpool**
**Feeder No / Name : 704 / M/S. John Deere NON SHEDDABLE EHV INDUSTRIAL FEEDERS**
**Feeder KV- 132 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 22.6338 |
| Max | 22.6338 |
| Min | 22.6338 |
| Avg | 22.6338 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 217052 / 132 kV Whirlpool**
**Feeder No / Name : 705 / M/S.Essar Steel NON SHEDDABLE EHV INDUSTRIAL FEEDERS**
**Feeder KV- 132 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 23 | 6.5844 |
| Max | 6.5844 |
| Min | 6.5844 |
| Avg | 6.5844 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 218031 / 220 KV RANJANGAON**
**Feeder No / Name : 300 / Auxillary II**
**Feeder KV- 22 / OUTGOING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 3.7723 |
| Max | 3.7723 |
| Min | 3.7723 |
| Avg | 3.7723 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 218031 / 220 KV RANJANGAON**
**Feeder No / Name : 301 / Appolo Feeder KV- 22 / OUTGOING**
**SHEDDABLE FEEDER HAVING WEEKLY STAGGERING (MIDC, EQUIVALENT)**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 3.7723 |
| Max | 3.7723 |
| Min | 3.7723 |
| Avg | 3.7723 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 218031 / 220 KV RANJANGAON**
**Feeder No / Name : 302 / IBP Shikrapur SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 23 | 6.7825 |
| 24 | 3.7723 |
| Max | **6.7825** |
| Min | **3.7723** |
| Avg | **5.2774** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 218031 / 220 KV RANJANGAON**
**Feeder No / Name : 303 / Mahaganpati SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 7.1216 |
| Max | 7.1216 |
| Min | 7.1216 |
| Avg | 7.1216 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 218031 / 220 KV RANJANGAON**
**Feeder No / Name : 304 / Wheel India Feeder KV- 22 / OUTGOING SHEDDABLE FEEDER HAVING WEEKLY STAGGERING (MIDC, EQUIVALENT)**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 3.7723 |
| Max | 3.7723 |
| Min | 3.7723 |
| Avg | 3.7723 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 218031 / 220 KV RANJANGAON**
**Feeder No / Name : 305 / TREDEGAR EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS**
**Feeder KV- 22 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 3.7723 |
| Max | 3.7723 |
| Min | 3.7723 |
| Avg | 3.7723 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 218031 / 220 KV RANJANGAON**
**Feeder No / Name : 306 / Varude Ganegaon SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 3.7723 |
| Max | 3.7723 |
| Min | 3.7723 |
| Avg | 3.7723 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 218031 / 220 KV RANJANGAON**
**Feeder No / Name : 307 / 22 kV Bombay Dyeing NON SHEDDABLE EXPRESS HV FEEDERS**
**Feeder KV- 22 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 3.7723 |
| Max | 3.7723 |
| Min | 3.7723 |
| Avg | 3.7723 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 218031 / 220 KV RANJANGAON**
**Feeder No / Name : 308 / 22 kV Tata Eaton NON SHEDDABLE EXPRESS HV FEEDERS**
**Feeder KV- 22 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 1.9204 |
| Max | 1.9204 |
| Min | 1.9204 |
| Avg | 1.9204 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 218031 / 220 KV RANJANGAON**
**Feeder No / Name : 309 / IKEL NON SHEDDABLE EXPRESS HV FEEDERS**
**Feeder KV- 22 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 3.7723 |
| Max | 3.7723 |
| Min | 3.7723 |
| Avg | 3.7723 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 218031 / 220 KV RANJANGAON**
**Feeder No / Name : 310 / G & F Block**
**Feeder KV- 22 / INCOMING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 3.7723 |
| Max | 3.7723 |
| Min | 3.7723 |
| Avg | 3.7723 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 218031 / 220 KV RANJANGAON**
**Feeder No / Name : 311 / switching sub stn-2**
**Feeder KV- 22 / INCOMING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 3.7723 |
| Max | 3.7723 |
| Min | 3.7723 |
| Avg | 3.7723 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 218031 / 220 KV RANJANGAON**
**Feeder No / Name : 312 / 22 kv wheels-2 SHEDDABLE FEEDER HAVING WEEKLY**
**Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 6.0357 |
| Max | 6.0357 |
| Min | 6.0357 |
| Avg | 6.0357 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 218031 / 220 KV RANJANGAON**
**Feeder No / Name : 313 / 22 kv itc NON SHEDDABLE EXPRESS HV FEEDERS**
**Feeder KV- 22 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | .7545 |
| Max | .7545 |
| Min | .7545 |
| Avg | .7545 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 218031 / 220 KV RANJANGAON**
**Feeder No / Name : 314 / varude gaothan GAOTHAN FEEDER**
**Feeder KV- 22 / OUTGOING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 3.7723 |
| Max | 3.7723 |
| Min | 3.7723 |
| Avg | 3.7723 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 218031 / 220 KV RANJANGAON**
**Feeder No / Name : 316 / 22 KV JOTUN NON SHEDDABLE EXPRESS HV FEEDERS**
**Feeder KV- 22 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 3.7723 |
| Max | 3.7723 |
| Min | 3.7723 |
| Avg | 3.7723 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 218031 / 220 KV RANJANGAON**
**Feeder No / Name : 317 / SCA Hygine** **NON SHEDDABLE EXPRESS HV FEEDERS**
**Feeder KV- 22 / OUTGOING** **(CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | .2058 |
| Max | .2058 |
| Min | .2058 |
| Avg | .2058 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 218031 / 220 KV RANJANGAON**
**Feeder No / Name : 703 / 132 kV BEKART 1 NON SHEDDABLE EHV INDUSTRIAL FEEDERS**
**Feeder KV- 132 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 22.6338 |
| Max | 22.6338 |
| Min | 22.6338 |
| Avg | 22.6338 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 218031 / 220 KV RANJANGAON**
**Feeder No / Name : 704 / 132 kV BEKART 2 NON SHEDDABLE EHV INDUSTRIAL FEEDERS**
**Feeder KV- 132 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 4.321 |
| Max | 4.321 |
| Min | 4.321 |
| Avg | 4.321 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 218031 / 220 KV RANJANGAON**
**Feeder No / Name : 705 / 132 KV Kalyani NON SHEDDABLE EHV INDUSTRIAL FEEDERS**
**Feeder KV- 132 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 4.7325 |
| Max | 4.7325 |
| Min | 4.7325 |
| Avg | 4.7325 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 218031 / 220 KV RANJANGAON**
**Feeder No / Name : 801 / 220 kv Fiat 1 NON SHEDDABLE EHV INDUSTRIAL FEEDERS**
**Feeder KV- 220 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 37.723 |
| Max | 37.723 |
| Min | 37.723 |
| Avg | 37.723 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIKRAPUR S/DN.[699] BU 4699**
**Substation No/ Name :- 218031 / 220 KV RANJANGAON**
**Feeder No / Name : 802 / 220 kV FIAT 2 NON SHEDDABLE EHV INDUSTRIAL FEEDERS**
**Feeder KV- 220 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 23 | 4.1152 |
| 24 | 37.723 |
| Max | 37.723 |
| Min | 4.1152 |
| Avg | 20.9191 |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055]** **BU 0833**
**Substation No/ Name :- 214450 / 33 KV MANDANGAON FARATA**
**Feeder No / Name : 203 / Junamala** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .2949 | .3353 | .2652 | .3429 | .2652 | .3353 |
| 2 | | .2949 | .3353 | .2652 | 1.7147 | .2652 | .3353 |
| 3 | | 1.4091 | 1.1736 | 1.4586 | | .2652 | .3353 |
| 4 | | 1.4091 | 1.4083 | 1.5249 | 1.7147 | .2652 | .3688 |
| 5 | | 1.4746 | 1.6766 | 1.7238 | 1.7147 | .3315 | .4024 |
| 6 | | 1.5729 | 2.0119 | 1.9062 | 1.749 | .4641 | .503 |
| 7 | | 1.9989 | 2.079 | 2.0553 | 1.8861 | .5304 | .6036 |
| 8 | 1.6385 | | 2.2801 | 2.1879 | 2.0576 | .4641 | .4694 |
| 9 | 2.13 | | 2.2874 | 2.2805 | 2.0222 | | .3277 |
| 10 | 2.2283 | | 2.3205 | 2.3148 | 2.0553 | | .2949 |
| 11 | .1638 | | | .1715 | .1326 | | 1.7695 |
| 12 | .1638 | | | .1543 | .1326 | | 2.1628 |
| 13 | .1638 | | | .1543 | .1326 | | 2.13 |
| 14 | .0983 | | | .1543 | .1326 | | 2.0972 |
| 15 | .0983 | | | .1543 | .1326 | | 2.0972 |
| 16 | .0983 | | | .1543 | .1989 | | 2.0972 |
| 17 | .1638 | | | .1715 | .1989 | | 2.0972 |
| 18 | .2949 | | | .3429 | .2652 | | 2.0972 |
| 19 | .3277 | | .3978 | .4115 | .3315 | | .3605 |
| 20 | .3932 | | .3932 | .4458 | .3315 | | .3932 |
| 21 | .3277 | | .3315 | .4748 | .2652 | | .3605 |
| 22 | .3277 | | .3315 | .4458 | .2652 | | .3605 |
| 23 | .2949 | | | .4115 | | | .3277 |
| 24 | | .2949 | .2683 | .2652 | .3353 | .2652 | .3353 |
| **Max** | **2.2283** | **1.9989** | **2.3205** | **2.3148** | **2.0576** | **.5304** | **2.1628** |
| **Min** | **.0983** | **.2949** | **.2683** | **.1543** | **.1326** | **.2652** | **.2949** |
| **Avg** | **.5571** | **1.0937** | **1.1754** | **.8289** | **.8233** | **.3462** | **.9442** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055] BU 0833**
**Substation No/ Name :- 214450 / 33 KV MANDANGAON FARATA**
**Feeder No / Name : 304 / GFSS Mandavgan Farata GAOTHAN FEEDER**
**Feeder KV- 22 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3429 | .439 | .4359 | .3315 | .3429 | .3277 | .3688 |
| 2 | | .4024 | .4024 | .3315 | .3429 | .3277 | .3688 |
| 3 | | .3292 | .3688 | .3277 | .3429 | .2984 | .4359 |
| 4 | .4115 | .3658 | .4694 | .4915 | .3429 | .3277 | .503 |
| 5 | .5121 | .439 | .57 | .5571 | .4115 | .4915 | .57 |
| 6 | .6584 | .6219 | .6371 | .6226 | .583 | .5898 | .7377 |
| 7 | .8048 | .7316 | .7042 | .6554 | .6173 | .6882 | |
| 8 | .7316 | | .6706 | .6226 | .7202 | .6882 | .6036 |
| 9 | .5853 | | .5967 | .6173 | | | .6219 |
| 10 | .5487 | | .5243 | .5144 | .5898 | | .5487 |
| 11 | .439 | | .2294 | .4801 | .4588 | | .4024 |
| 12 | .3658 | | .3277 | .4115 | .3932 | | .4024 |
| 13 | .5121 | | .426 | .4115 | .3605 | | .3292 |
| 14 | .4024 | | .4588 | .3772 | .3932 | | .3658 |
| 15 | .3658 | | .3932 | .4115 | .3932 | | .3658 |
| 16 | .3658 | | .4588 | .4115 | .3932 | | .3658 |
| 17 | .439 | | .4915 | .4115 | .3932 | | .4024 |
| 18 | .6584 | | .5898 | .6516 | .5898 | | .5121 |
| 19 | .8048 | | .6882 | .6173 | .6226 | | .7316 |
| 20 | .7316 | | .6226 | .7468 | .5571 | | .6584 |
| 21 | .5853 | | .5243 | .6859 | .4588 | | .5853 |
| 22 | .5121 | | .3932 | .6173 | .426 | | .439 |
| 23 | .439 | | | .4115 | .4115 | | .439 |
| 24 | .3429 | .439 | .3688 | .3277 | .3429 | .3605 | .4024 |
| **Max** | **.8048** | **.7316** | **.7042** | **.7468** | **.7202** | **.6882** | **.7377** |
| **Min** | **.3429** | **.3292** | **.2294** | **.3277** | **.3429** | **.2984** | **.3292** |
| **Avg** | **.5254** | **.4710** | **.4936** | **.5019** | **.4560** | **.4555** | **.4852** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055] BU 0833**
**Substation No/ Name :- 214450 / 33 KV MANDANGAON FARATA**
**Feeder No / Name : 305 / Gfss Inamgaon - Babulsar GAOTHAN FEEDER**
**Feeder KV- 22 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8718 | 1.0974 | 1.073 | .9945 | .8916 | .9945 | 1.0059 |
| 2 | .8718 | 1.0242 | 1.1401 | .9831 | .8916 | .9503 | .9389 |
| 3 | .8916 | 1.0242 | 1.1736 | .9945 | 1.0288 | .9614 | 1.0059 |
| 4 | .9602 | 1.0974 | 1.2407 | .9945 | 1.2003 | 1.0486 | 1.3413 |
| 5 | 1.0974 | 1.1706 | 1.5089 | 1.2597 | 1.5432 | 1.278 | 1.5424 |
| 6 | 1.7147 | 1.1706 | 1.7436 | 1.5074 | 1.9204 | 1.5912 | 1.6766 |
| 7 | 1.7147 | 2.1948 | 1.9113 | 1.7695 | 1.7147 | 1.8351 | 1.8442 |
| 8 | 1.6461 | | 1.643 | 1.5581 | 1.5775 | 1.5581 | 1.576 |
| 9 | 1.4632 | | 1.3763 | .9602 | .9831 | | 1.3535 |
| 10 | 1.2437 | | 1.1271 | .8916 | 1.0277 | | 1.1706 |
| 11 | 1.1706 | | .7293 | .7545 | .6962 | | 1.0974 |
| 12 | 1.0974 | | .663 | .6859 | .6226 | | 1.0974 |
| 13 | 1.1706 | | .6226 | .6859 | .5636 | | 1.0242 |
| 14 | 1.0974 | | .5571 | .6516 | .6962 | | 1.0242 |
| 15 | 1.0974 | | .4641 | .6173 | .7956 | | 1.0242 |
| 16 | 1.0242 | | .6554 | .6173 | .852 | | 1.0608 |
| 17 | .9877 | | 1.0608 | .6859 | .8951 | | 1.0974 |
| 18 | 1.0242 | | 1.2452 | 1.3717 | 1.1271 | | 1.1706 |
| 19 | 1.2437 | | 1.4419 | 1.9204 | 1.3435 | | 1.2437 |
| 20 | 1.3169 | | 1.2452 | 1.7147 | 1.2597 | | 1.39 |
| 21 | 1.3169 | | 1.1603 | 1.2003 | 1.1469 | | 1.3169 |
| 22 | 1.2437 | | 1.0277 | 1.0288 | .9945 | | 1.2437 |
| 23 | 1.1706 | | | .9602 | | | 1.1706 |
| 24 | .9602 | 1.0974 | 1.0059 | .9831 | .8916 | .9831 | .9389 |
| **Max** | **1.7147** | **2.1948** | **1.9113** | **1.9204** | **1.9204** | **1.8351** | **1.8442** |
| **Min** | **.8718** | **1.0242** | **.4641** | **.6173** | **.5636** | **.9503** | **.9389** |
| **Avg** | **1.1832** | **1.2346** | **1.1224** | **1.0746** | **1.0723** | **1.2445** | **1.2231** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055] BU 0833**
**Substation No/ Name :- 214451 / 33/22/11 KV NHAVARA**
**Feeder No / Name : 202 / 11 KV Ambale Gaothan GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .3045 | .2507 | .2507 | | .394 | .3582 |
| 2 | | .2686 | .2865 | .2686 | | .3224 | .2686 |
| 3 | | .2507 | .2507 | .3224 | | .4119 | .2865 |
| 4 | | .2507 | .2686 | .4298 | | .4835 | .4298 |
| 5 | | .2865 | .3582 | .5731 | | .5373 | .4835 |
| 6 | | .2686 | .5552 | .6805 | | .5731 | .6447 |
| 7 | | .6447 | .6984 | .7522 | | .7164 | .7164 |
| 8 | .4835 | .6447 | .7522 | .8596 | .7522 | .6447 | .6805 |
| 9 | 1.0924 | .6984 | .7701 | .8954 | | .8596 | .9134 |
| 10 | .8954 | .5731 | .7164 | .8596 | .9134 | .6805 | .8954 |
| 11 | .7522 | .4298 | .5731 | .7701 | .7701 | .6447 | .7522 |
| 12 | .3403 | .3224 | .6089 | .8417 | .5014 | .4656 | .3224 |
| 13 | .6626 | .3045 | .5731 | .5014 | .5194 | .4668 | .5373 |
| 14 | | | .5373 | .6089 | .5014 | .5975 | .5014 |
| 15 | | | .6089 | .6805 | .5014 | | .6089 |
| 16 | | | .6805 | .5552 | | | .6805 |
| 17 | | .394 | .5373 | .4835 | | .6268 | .5552 |
| 18 | | .5373 | .6984 | .6089 | | .8417 | .6626 |
| 19 | | .6626 | .7701 | | | .788 | .7522 |
| 20 | | .5373 | .7522 | | | .8238 | .6805 |
| 21 | | .4656 | .6447 | | | .7522 | .6268 |
| 22 | | .3582 | .5731 | | | .6805 | .591 |
| 23 | | .2865 | .5014 | | | .4298 | .5228 |
| 24 | .4298 | .3582 | .2686 | .4656 | .4656 | .4656 | .4119 |
| **Max** | **1.0924** | **.6984** | **.7701** | **.8954** | **.9134** | **.8596** | **.9134** |
| **Min** | **.3403** | **.2507** | **.2507** | **.2507** | **.4656** | **.3224** | **.2686** |
| **Avg** | **.6652** | **.4213** | **.5514** | **.6004** | **.6156** | **.6003** | **.5784** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055] BU 0833**
**Substation No/ Name :- 214451 / 33/22/11 KV NHAVARA**
**Feeder No / Name : 203 / 11 KV Kolape Wasti Ag SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .2865 | .2686 | .2149 | | .2149 | .2686 |
| 2 | | .2686 | .2507 | .2507 | | | .2865 |
| 3 | | .2328 | .2507 | | | .9492 | 1.0924 |
| 4 | | .2686 | .2686 | .3403 | | 1.1283 | 1.2715 |
| 5 | | .3224 | .3582 | .4298 | | 1.3432 | 1.2894 |
| 6 | | .3403 | .4656 | .5014 | | 1.6118 | 1.3969 |
| 7 | .4835 | .6089 | .9134 | .5373 | | 1.8804 | 1.6655 |
| 8 | .4119 | .5014 | .4477 | .5014 | .5014 | 1.97 | 1.8446 |
| 9 | .3582 | .3582 | .3224 | .3045 | | 2.0595 | 1.9163 |
| 10 | .2507 | | .2328 | .3224 | .3224 | 1.97 | 1.8267 |
| 11 | 2.0237 | 1.8267 | 1.9342 | 1.773 | 1.9521 | .2149 | .2149 |
| 12 | 2.3998 | 2.4356 | 1.97 | 2.0416 | 2.0953 | .1791 | .1791 |
| 13 | 2.5968 | 2.5789 | 2.4714 | 2.3282 | 2.3461 | .1612 | .1791 |
| 14 | | 2.561 | 2.364 | 2.2923 | 2.364 | .197 | .1791 |
| 15 | | 2.5431 | 2.4714 | 2.2744 | 2.364 | | .1791 |
| 16 | | 2.5072 | 2.4356 | 2.3282 | | | .197 |
| 17 | | 2.4356 | 2.3819 | 2.2744 | | .2328 | .197 |
| 18 | | 2.4177 | 2.3282 | 2.2028 | | .3403 | .2507 |
| 19 | | .394 | .5014 | | | .4119 | .394 |
| 20 | | .3582 | .3582 | | | .3582 | .3761 |
| 21 | | .3224 | .3224 | | | .3045 | .3224 |
| 22 | | .3045 | .2865 | | | .2686 | .2865 |
| 23 | | .2865 | .2507 | | | .2686 | .2507 |
| 24 | .2507 | .3045 | .2865 | .2328 | .2328 | .2328 | .2328 |
| **Max** | **2.5968** | **2.5789** | **2.4714** | **2.3282** | **2.364** | **2.0595** | **1.9163** |
| **Min** | **.2507** | **.2328** | **.2328** | **.2149** | **.2328** | **.1612** | **.1791** |
| **Avg** | **1.0969** | **1.0636** | **1.0059** | **1.1750** | **1.5223** | **.7761** | **.6790** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055] BU 0833**
**Substation No/ Name :- 214451 / 33/22/11 KV NHAVARA**
**Feeder No / Name : 301 / Nhavara SHEDDABLE FEEDER HAVING WEEKLY**
**Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .7468 | | .6722 | | .7095 | .6089 |
| 2 | | .7095 | .5975 | .7468 | | .6722 | .6348 |
| 3 | | .7095 | .6348 | .7095 | | .7468 | .6348 |
| 4 | | .8215 | .6722 | .8215 | | .8215 | .6722 |
| 5 | | .8962 | .7468 | .9709 | | .8962 | .7095 |
| 6 | | 1.1576 | 1.0456 | .9709 | | 1.0829 | .8962 |
| 7 | 1.3443 | 1.3443 | 1.1203 | 1.2323 | | 1.307 | 1.1203 |
| 8 | 1.3817 | 1.3443 | 1.1203 | 1.1949 | 1.3443 | 1.307 | 1.1576 |
| 9 | 1.2696 | 1.1203 | 1.1203 | 1.0829 | | 1.1949 | .8962 |
| 10 | 1.1203 | | 1.0082 | .9709 | 1.0829 | 1.1203 | .8589 |
| 11 | .9709 | .9335 | .9709 | .8589 | .8962 | .8962 | .8215 |
| 12 | .8962 | .7468 | .9709 | .8215 | .8962 | .8589 | .7468 |
| 13 | .7842 | .7842 | .8589 | .8962 | .8589 | .8215 | .7095 |
| 14 | | .8215 | .8215 | .8589 | .8589 | .7842 | .7468 |
| 15 | | .8215 | .7842 | .8215 | .8589 | | .7842 |
| 16 | | .8215 | .8962 | .8215 | | | .7468 |
| 17 | | .8589 | .8215 | .9709 | | .7842 | .8215 |
| 18 | | .9335 | 1.0829 | 1.0082 | | 1.0082 | .9709 |
| 19 | | .9709 | 1.1949 | | | 1.0082 | 1.1203 |
| 20 | | .8962 | 1.0829 | | | .9335 | 1.0082 |
| 21 | | .7842 | .9709 | | | .8215 | .9335 |
| 22 | | .7468 | .8962 | | | .7468 | .8215 |
| 23 | | .6722 | .8215 | | | .7468 | .7842 |
| 24 | .7095 | .7468 | .6348 | .7468 | .7468 | .7468 | .6722 |
| **Max** | **1.3817** | **1.3443** | **1.1949** | **1.2323** | **1.3443** | **1.307** | **1.1576** |
| **Min** | **.7095** | **.6722** | **.5975** | **.6722** | **.7468** | **.6722** | **.6089** |
| **Avg** | **1.0596** | **.8865** | **.9076** | **.9041** | **.9429** | **.9098** | **.8282** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055] BU 0833**
**Substation No/ Name :- 214451 / 33/22/11 KV NHAVARA**
**Feeder No / Name : 302 / Nimbone SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .5228 | | | .4108 | .4108 |
| 2 | | .4481 | | | .3734 | .3734 |
| 3 | | 4.369 | | | .4108 | .3734 |
| 4 | | 4.7424 | | | .4854 | .4481 |
| 5 | | 4.9665 | | | .5228 | .5228 |
| 6 | | 5.3399 | | | .7095 | .6348 |
| 7 | 6.0494 | 5.9747 | | | .7842 | .7164 |
| 8 | 6.3481 | 6.6469 | | 6.4228 | .6722 | .7095 |
| 9 | 6.7215 | 6.7962 | | | .5228 | .6348 |
| 10 | 6.1614 | | | 6.2361 | 1.0456 | .4108 |
| 11 | .3734 | | | | 5.3026 | 4.8171 |
| 12 | .3734 | | .3734 | | 6.2734 | 5.6386 |
| 13 | .4108 | | | | 6.6095 | 6.1614 |
| 14 | | | .3734 | | 6.7215 | 5.9747 |
| 15 | | | .3361 | | | 5.9374 |
| 16 | | | .4108 | | 6.7589 | 5.5266 |
| 17 | | | .4108 | | 6.6095 | 5.7507 |
| 18 | | | .5228 | | 6.3481 | 5.4146 |
| 19 | | | | | .6722 | .7468 |
| 20 | | | | | .4854 | .5975 |
| 21 | | | | | .4481 | .5228 |
| 22 | | | | | .4108 | .4481 |
| 23 | | | | | .4108 | .4108 |
| 24 | | .5228 | | .4108 | .4108 | .4854 |
| **Max** | **6.7215** | **6.7962** | **.5228** | **6.4228** | **6.7589** | **6.1614** |
| **Min** | **.3734** | **.4481** | **.3361** | **.4108** | **.3734** | **.3734** |
| **Avg** | **3.7769** | **4.0329** | **.4046** | **4.3566** | **2.3217** | **2.2361** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055] BU 0833**
**Substation No/ Name :- 214451 / 33/22/11 KV NHAVARA**
**Feeder No / Name : 303 / 22 KV Alegaon AG feeder SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER**

| DATE | 04-DEC-17 | 05-DEC-17 |
|---|---|---|
| HR | Load (MW) | Load (MW) |
| 1 | .4854 | .5228 |
| 2 | .4854 | .5228 |
| 3 | 4.4063 | 3.4355 |
| 4 | 4.5931 | |
| 5 | 4.7424 | |
| 6 | 4.8544 | 4.0703 |
| 7 | 5.676 | 4.4063 |
| 8 | 5.676 | 5.1158 |
| 9 | 5.8627 | 5.0412 |
| 10 | 5.4893 | 4.7424 |
| 11 | .2987 | |
| 12 | .2987 | .1867 |
| 13 | .2614 | .2614 |
| 14 | .2614 | .2614 |
| 15 | .2987 | .2614 |
| 16 | .2987 | .3361 |
| 17 | .3361 | .4481 |
| 18 | .5601 | .5601 |
| 19 | .7842 | .7842 |
| 20 | .6348 | .7095 |
| 21 | .5975 | .6348 |
| 22 | .5975 | .5601 |
| 23 | .4854 | .4854 |
| 24 | .4854 | .5228 |
| **Max** | **5.8627** | **5.1158** |
| **Min** | **.2614** | **.1867** |
| **Avg** | **2.0196** | **1.6128** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055] BU 0833**
**Substation No/ Name :- 214451 / 33/22/11 KV NHAVARA**
**Feeder No / Name : 305 / 22 Kv Mallikarjun GFSS GAOTHAN FEEDER**
**Feeder KV- 22 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .7468 | .8215 | 1.0456 | | .5601 | .6348 |
| 2 | | .6722 | .6722 | 1.0829 | | .5228 | .6722 |
| 3 | | .5975 | .6348 | 1.1949 | | .6722 | .6348 |
| 4 | | .8215 | .6722 | 1.419 | | .8589 | .7468 |
| 5 | | .9335 | .7468 | 1.6057 | | .9335 | |
| 6 | | .9335 | 1.3443 | 1.7177 | | 1.0829 | 1.1949 |
| 7 | 1.9044 | 1.1576 | 1.4937 | 1.9418 | | 1.1203 | 1.3443 |
| 8 | 1.7551 | 1.0456 | 1.307 | 1.6804 | 1.8298 | 1.0456 | 1.0829 |
| 9 | 1.4563 | 1.0082 | 1.1203 | 1.5684 | | .8962 | .7095 |
| 10 | 1.307 | | .9335 | 1.3443 | 1.4563 | .7842 | .8215 |
| 11 | .8215 | .8589 | .8962 | 1.0456 | .6722 | .8215 | .6722 |
| 12 | .6722 | .7842 | .9335 | .8962 | .5975 | .7842 | .5975 |
| 13 | .6722 | .7095 | .8215 | .9335 | .5601 | .7468 | .4854 |
| 14 | | .8215 | .8215 | .7842 | .5601 | .6722 | .5228 |
| 15 | | .7842 | .8962 | .8215 | .5601 | .7468 | .4481 |
| 16 | | .8962 | .9709 | .9709 | | .7842 | .5975 |
| 17 | | .7842 | 1.1203 | .9335 | | .9709 | .6348 |
| 18 | | 1.0082 | 1.3443 | 1.2323 | | 1.0829 | .9709 |
| 19 | | 1.1949 | 1.9044 | | | 1.1203 | 1.3443 |
| 20 | | .9709 | 1.5684 | | | .8215 | 1.0456 |
| 21 | | .8962 | 1.3817 | | | .7842 | .9335 |
| 22 | | .8589 | 1.2323 | | | .7095 | .8215 |
| 23 | | .8589 | 1.1949 | | | .5601 | .7842 |
| 24 | .8589 | | | 1.1203 | 1.0829 | .5975 | .6348 |
| **Max** | **1.9044** | **1.1949** | **1.9044** | **1.9418** | **1.8298** | **1.1203** | **1.3443** |
| **Min** | **.6722** | **.5975** | **.6348** | **.7842** | **.5601** | **.5228** | **.4481** |
| **Avg** | **1.1810** | **.8792** | **1.0797** | **1.2284** | **.9149** | **.8200** | **.7972** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055] BU 0833**
**Substation No/ Name :- 214452 / 33KV/22KV MALTHAN**
**Feeder No / Name : 301 / TAKALI HAJI SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 |
|---|---|---|
| HR | Load (MW) | Load (MW) |
| 1 | .4481 | .6722 |
| 2 | 1.3443 | 1.2696 |
| 3 | 1.419 | 2.3899 |
| 4 | 1.4937 | 2.6139 |
| 5 | 1.9044 | 2.6886 |
| 6 | 2.3899 | 2.838 |
| 7 | 2.9127 | 3.2861 |
| 8 | 3.2487 | 3.3608 |
| 9 | 3.4728 | |
| 10 | 3.3608 | |
| 11 | .6348 | .5601 |
| 12 | .4108 | .6722 |
| 13 | .4108 | .2987 |
| 14 | .4481 | |
| 15 | .3734 | |
| 16 | .3361 | |
| 17 | .3361 | |
| 18 | .5975 | |
| 19 | .8589 | |
| 20 | .7468 | |
| 21 | .6348 | .8215 |
| 22 | .6348 | .5601 |
| 23 | .5601 | |
| 24 | .3734 | .5228 |
| Max | **3.4728** | **3.3608** |
| Min | **.3361** | **.2987** |
| Avg | **1.2230** | **1.6110** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055]** **BU 0833**
**Substation No/ Name :- 214452 / 33KV/22KV MALTHAN**
**Feeder No / Name : 302 / Kavathe** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 22 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 |
|---|---|---|
| HR | Load (MW) | Load (MW) |
| 1 | .4481 | .6722 |
| 2 | 1.1949 | 1.643 |
| 3 | 1.419 | 2.0165 |
| 4 | 1.4937 | 2.7633 |
| 5 | 1.4937 | 2.838 |
| 6 | 1.531 | 2.9874 |
| 7 | 2.838 | 3.0994 |
| 8 | 3.3608 | 3.1741 |
| 9 | 3.5475 | |
| 10 | 3.3608 | |
| 11 | .6722 | .8962 |
| 12 | | .6722 |
| 13 | | .6722 |
| 14 | .6722 | |
| 15 | .9335 | |
| 18 | .9335 | |
| 19 | 1.0456 | |
| 20 | .8215 | |
| 21 | .6722 | .8962 |
| 22 | .6722 | 1.0082 |
| 23 | .5601 | |
| 24 | .3734 | .5975 |
| **Max** | **3.5475** | **3.1741** |
| **Min** | **.3734** | **.5975** |
| **Avg** | **1.4022** | **1.7097** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055] BU 0833**
**Substation No/ Name :- 214452 / 33KV/22KV MALTHAN**
**Feeder No / Name : 303 / Shastabad SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 |
|---|---|---|
| HR | Load (MW) | Load (MW) |
| 1 | .5601 | .8962 |
| 2 | .5975 | 1.0456 |
| 3 | .6722 | 1.1949 |
| 4 | .8215 | 1.1949 |
| 5 | .8962 | 1.1949 |
| 6 | 1.0082 | 1.1949 |
| 7 | 1.1203 | 1.1203 |
| 8 | 1.1949 | 1.1576 |
| 9 | .9709 | |
| 10 | .7095 | |
| 11 | 2.0911 | 1.9791 |
| 12 | 3.0247 | 3.0994 |
| 13 | 3.062 | 2.726 |
| 14 | 3.0994 | |
| 15 | 3.2114 | |
| 16 | 2.7633 | |
| 17 | 2.3152 | |
| 18 | 2.2779 | |
| 19 | .9335 | |
| 20 | .8589 | |
| 21 | .8215 | .9335 |
| 22 | .8215 | 1.0082 |
| 23 | .8962 | |
| 24 | .5228 | .7468 |
| **Max** | **3.2114** | **3.0994** |
| **Min** | **.5228** | **.7468** |
| **Avg** | **1.4688** | **1.3923** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055] BU 0833**
**Substation No/ Name :- 214452 / 33KV/22KV MALTHAN**
**Feeder No / Name : 304 / 22 KV Kawathe Gaothan GAOTHAN FEEDER**
**Feeder KV- 22 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5228 | .5228 | .4481 | .4481 | .5228 | .4854 | .4481 |
| 2 | .5975 | .6722 | .6722 | .4481 | .5975 | .5228 | .4481 |
| 3 | .6722 | .7842 | .7468 | .5228 | .6722 | .5601 | .5228 |
| 4 | .7468 | .7842 | .8962 | .5975 | .7468 | .6348 | .6722 |
| 5 | .8215 | .8215 | 1.0456 | .7842 | .8215 | .8962 | .7468 |
| 6 | .8962 | 1.0456 | 1.1203 | 1.0082 | .8962 | 1.0456 | .8215 |
| 7 | 1.0456 | 1.1203 | 1.1576 | 1.0456 | 1.0082 | 1.1949 | .9709 |
| 8 | 1.1576 | 1.419 | 1.1576 | .8962 | .9335 | 1.086 | 1.0082 |
| 9 | 1.0456 | | .9709 | 1.0456 | .9709 | .9709 | .8215 |
| 10 | .9335 | | .8962 | .9709 | .8589 | .8962 | .7468 |
| 11 | .7842 | .6722 | .7842 | .6348 | .7842 | .6722 | .4108 |
| 12 | .6348 | .5601 | .7095 | .5975 | .5975 | .4854 | .4108 |
| 13 | .5228 | .4108 | .5228 | .5228 | .4854 | .3734 | .2987 |
| 14 | .4481 | | .5975 | .5228 | .4481 | .3734 | .2987 |
| 15 | .5228 | | .6348 | .5228 | .4108 | .4481 | .2987 |
| 16 | .4108 | | .6722 | .5228 | | .5228 | .3734 |
| 17 | .4481 | | .6722 | .5601 | | .7095 | .3734 |
| 18 | .7095 | | .9709 | .5975 | .7842 | .7842 | .6722 |
| 19 | 1.0082 | | 1.0829 | .6722 | .8962 | .8962 | .7468 |
| 20 | .9335 | | .8962 | .6722 | .9709 | .9709 | .8962 |
| 21 | .7468 | .8215 | .7095 | .7468 | .7095 | .7468 | .9709 |
| 22 | | .6348 | .6348 | .6722 | .5601 | .5228 | .4481 |
| 23 | .5228 | | .5601 | .5975 | .5228 | .4481 | .4108 |
| 24 | .4854 | .4854 | .4481 | .4481 | .4481 | .4854 | .4481 |
| **Max** | **1.1576** | **1.419** | **1.1576** | **1.0456** | **1.0082** | **1.1949** | **1.0082** |
| **Min** | **.4108** | **.4108** | **.4481** | **.4481** | **.4108** | **.3734** | **.2987** |
| **Avg** | **.7225** | **.7682** | **.7920** | **.6691** | **.7112** | **.6972** | **.5944** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055] BU 0833**
**Substation No/ Name :- 214452 / 33KV/22KV MALTHAN**
**Feeder No / Name : 305 / 22 kv industrial feeder SHEDDABLE FEEDER HAVING WEEKLY**
**Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | .0373 | | .0373 | |
| 2 | | | | .0373 | | .0373 | |
| 3 | | | | .0373 | | .0373 | |
| 4 | | | | .0373 | | .0373 | |
| 5 | | | .112 | .0373 | .1494 | .0373 | |
| 6 | | | | .0373 | .2614 | .0373 | |
| 7 | | | .0747 | .0373 | .2987 | .0373 | |
| 8 | | | .112 | .1494 | .2987 | .0747 | .1124 |
| 9 | | | .0747 | .2241 | .2987 | .112 | .0373 |
| 10 | | | .0373 | .0373 | .112 | .112 | |
| 11 | .0373 | | | .0373 | .1867 | .1494 | |
| 12 | | .2241 | .1494 | .1867 | .2241 | .1494 | |
| 13 | | .2614 | .2241 | .2614 | .1867 | .112 | |
| 14 | | | .0373 | .1494 | .2241 | .112 | |
| 15 | | | .0373 | .112 | .2614 | | |
| 16 | | | | .1494 | | .2241 | |
| 17 | | | .112 | .2241 | | .2241 | |
| 18 | | | .0747 | | .0747 | .2614 | |
| 19 | | | .0373 | | .0373 | .0373 | |
| 20 | | | .0373 | | | | |
| 21 | | | .0373 | | | | |
| 22 | | .6348 | .0373 | | .0373 | | |
| 23 | | | .0373 | | .0373 | | |
| 24 | | | | .0377 | | .0373 | |
| **Max** | **.0373** | **.6348** | **.2241** | **.2614** | **.2987** | **.2614** | **.1124** |
| **Min** | **.0373** | **.2241** | **.0373** | **.0373** | **.0373** | **.0373** | **.0373** |
| **Avg** | **.0373** | **.3734** | **.077** | **.1017** | **.1792** | **.0983** | **.0749** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055] BU 0833**
**Substation No/ Name :- 214452 / 33KV/22KV MALTHAN**
**Feeder No / Name : 306 / 22 kv Amdabad SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2241 | .2241 | .1867 | .1867 | .1867 | .1867 | .2614 |
| 2 | .2241 | .2241 | .2241 | .1867 | .2241 | .8962 | .2241 |
| 3 | .2241 | .2241 | .2241 | .2241 | .2241 | .9709 | .8962 |
| 4 | .2614 | .2614 | .2614 | .2241 | .2614 | 1.1576 | 1.1949 |
| 5 | .2614 | .2614 | .2614 | .2534 | .2614 | 1.2323 | 1.4937 |
| 6 | .2614 | .2987 | .2987 | .2987 | .2987 | 1.3817 | 1.5684 |
| 7 | .2241 | .3361 | .3361 | .2987 | | 1.4563 | 1.643 |
| 8 | .1867 | .2987 | .2987 | .2614 | | 1.6057 | 1.419 |
| 9 | .2241 | | .2614 | .2987 | .3361 | 1.8671 | 1.3443 |
| 10 | .2614 | | .3361 | .1867 | .2987 | | 1.1949 |
| 11 | 1.3443 | 1.3443 | 1.7924 | 1.6804 | 1.7177 | | .1867 |
| 12 | 1.9418 | 1.7177 | 1.9791 | 1.8298 | 1.9418 | | .1494 |
| 13 | 2.0538 | 1.9418 | 2.0911 | 2.0538 | 1.8671 | .1494 | .1494 |
| 14 | 2.0911 | | 2.0911 | 2.0165 | 1.9044 | .112 | .112 |
| 15 | 2.0911 | | 2.1285 | 2.0538 | 1.9418 | .112 | .112 |
| 16 | 1.9791 | | | 1.9791 | | .112 | .112 |
| 17 | 1.9044 | | | 1.9044 | | .1494 | .1867 |
| 18 | 1.7924 | | 2.0911 | 1.8671 | 1.7177 | .2614 | .2241 |
| 19 | .2614 | | .2987 | .3734 | .2614 | .2614 | .2987 |
| 20 | .2241 | | .2614 | .2987 | .2241 | .2614 | .2614 |
| 21 | .2241 | .1867 | .2241 | .2241 | .1867 | .2241 | .2241 |
| 22 | .2241 | .1867 | .2241 | .1867 | .2241 | .2241 | .1886 |
| 23 | .1867 | | .1867 | .1867 | .1867 | .2614 | .2241 |
| 24 | .2241 | .1867 | .1867 | .1867 | .1867 | .1867 | .2614 |
| **Max** | **2.0911** | **1.9418** | **2.1285** | **2.0538** | **1.9418** | **1.8671** | **1.643** |
| **Min** | **.1867** | **.1867** | **.1867** | **.1867** | **.1867** | **.112** | **.112** |
| **Avg** | **.7873** | **.5495** | **.7384** | **.8025** | **.7226** | **.6224** | **.5804** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055]** **BU 0833**
**Substation No/ Name :- 214452 / 33KV/22KV MALTHAN**
**Feeder No / Name : 307 / 22 kv Malthan Gaothan** **GAOTHAN FEEDER**
**Feeder KV- 22 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1494 | .2241 | .112 | .112 | .112 | .112 | .1494 |
| 2 | .1867 | .2241 | .112 | .1494 | .1494 | .1494 | .1867 |
| 3 | .1867 | .2614 | .1494 | .1494 | .1494 | .1494 | .1867 |
| 4 | .2241 | .2614 | .1867 | .1867 | .1867 | .1867 | .2241 |
| 5 | .2614 | .2987 | .2241 | .2534 | .1867 | .2241 | .2614 |
| 6 | .2614 | .3361 | .2987 | .2987 | .2241 | .2614 | .2987 |
| 7 | .2987 | .3361 | .2987 | .3361 | .2614 | .3361 | .2987 |
| 8 | .3361 | .2987 | .2987 | .2614 | .2987 | .2614 | .2987 |
| 9 | .2614 | | .2614 | .2241 | .2987 | .2241 | .2614 |
| 10 | .2241 | | .1867 | .1867 | .2987 | .2241 | .2241 |
| 11 | .2241 | .2241 | .1494 | | .2241 | .1494 | .1867 |
| 12 | .1867 | .1867 | .1494 | .112 | .1867 | .1494 | .1494 |
| 13 | .1494 | .1494 | .1494 | .1494 | .1867 | .1494 | .1494 |
| 14 | .112 | | .112 | .112 | .1867 | .112 | .1494 |
| 15 | .1494 | | .1494 | .112 | .1867 | .112 | .1494 |
| 16 | .1494 | | .1494 | .112 | | .1494 | .112 |
| 17 | .1494 | | .1867 | .1494 | | .1494 | .1867 |
| 18 | .1867 | | .2614 | .1867 | .2614 | .1867 | .1867 |
| 19 | .2614 | | .2987 | .1867 | .2241 | .2614 | .2614 |
| 20 | .2614 | | .2614 | .2241 | .1867 | .2614 | .2614 |
| 21 | .2241 | .1494 | .2241 | .2241 | .1867 | .2614 | .2241 |
| 22 | .2241 | .1867 | .2241 | .1867 | .1867 | .1867 | .2241 |
| 23 | .1867 | | .1867 | .1494 | .1494 | .1494 | .2241 |
| 24 | .112 | .1867 | .112 | .112 | .112 | .112 | .1494 |
| **Max** | **.3361** | **.3361** | **.2987** | **.3361** | **.2987** | **.3361** | **.2987** |
| **Min** | **.112** | **.1494** | **.112** | **.112** | **.112** | **.112** | **.112** |
| **Avg** | **.2070** | **.2374** | **.1976** | **.1815** | **.2020** | **.1883** | **.2085** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055] BU 0833**
**Substation No/ Name :- 214461 / 33 KV TAKALI HAJI**
**Feeder No / Name : 202 / 11 kv Shingawadi SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2477 | .2263 | .2667 | .2477 | .2286 | .3018 | .2477 |
| 2 | .2477 | .2641 | .2667 | .2477 | .2286 | .4715 | .2477 |
| 3 | .2667 | .3018 | .2667 | .2477 | .2477 | .4715 | .4191 |
| 4 | .2858 | .3206 | .2667 | .2858 | .2477 | .4715 | .4191 |
| 5 | .3239 | .3395 | .2667 | .3429 | .2858 | .5281 | .4763 |
| 6 | .362 | .3961 | .4572 | .381 | .3239 | .5658 | .5144 |
| 7 | .4191 | .4338 | .4954 | .4382 | .4191 | .811 | .7621 |
| 8 | .4763 | .5281 | .5906 | .5144 | .4763 | .8865 | 1.0669 |
| 9 | .4338 | .4527 | .5716 | .5906 | .4763 | .9997 | 1.086 |
| 10 | .4715 | .4904 | .4763 | .5335 | .4527 | 1.0288 | .9526 |
| 11 | .9431 | .8676 | 1.105 | .8954 | 1.0374 | .381 | .3048 |
| 12 | 1.0374 | 1.094 | 1.3717 | 1.0669 | 1.1317 | .4001 | .3239 |
| 13 | | .6413 | 1.467 | 1.1622 | 1.3203 | .4191 | .3429 |
| 14 | .9431 | | 1.4098 | .8192 | | .4382 | .3429 |
| 15 | 1.0185 | | 1.4098 | 1.2193 | 1.1317 | .4191 | |
| 16 | 1.094 | | 1.3908 | 1.2193 | 1.1317 | .4954 | |
| 17 | 1.1317 | | 1.3146 | 1.1622 | 1.0374 | .381 | .2286 |
| 18 | 1.1317 | | .8764 | .9526 | .8488 | .4001 | .3239 |
| 19 | | | .381 | .3239 | .3018 | .381 | .3429 |
| 20 | .3772 | .3395 | .362 | .2858 | .3395 | .2858 | .3239 |
| 21 | .3584 | .3395 | .3239 | .2286 | | .2858 | .2667 |
| 22 | .2641 | .3018 | .3048 | .2477 | | .2667 | .2667 |
| 23 | .2641 | .2641 | .2858 | .2286 | | .2477 | .2667 |
| 24 | .2477 | .2058 | .2641 | .2667 | .2477 | .3018 | .2477 |
| **Max** | **1.1317** | **1.094** | **1.467** | **1.2193** | **1.3203** | **1.0288** | **1.086** |
| **Min** | **.2477** | **.2058** | **.2641** | **.2286** | **.2286** | **.2477** | **.2286** |
| **Avg** | **.5612** | **.4337** | **.6746** | **.5795** | **.5957** | **.4850** | **.4443** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055] BU 0833**
**Substation No/ Name :- 214461 / 33 KV TAKALI HAJI**
**Feeder No / Name : 204 / 11 kv Temkarwadi SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .362 | .3772 | .381 | .4763 | .4001 | .3772 | .3239 |
| 2 | .362 | .4527 | .381 | .4572 | .4001 | .6602 | .3239 |
| 3 | .4191 | .4904 | .381 | .4954 | .4191 | .8488 | .9907 |
| 4 | .5144 | .5281 | .381 | .5716 | .4763 | 1.3203 | 1.0288 |
| 5 | .5716 | .5658 | .4572 | .6668 | .5716 | 1.4146 | 1.086 |
| 6 | .6668 | .6602 | .6097 | .8192 | .6668 | 1.4523 | 1.2193 |
| 7 | .8383 | .8676 | .8573 | 1.0098 | .8573 | 1.6975 | 1.4861 |
| 8 | .8764 | .9808 | 1.105 | 1.0479 | .9717 | 2.0936 | 1.848 |
| 9 | .8865 | .8865 | 1.0669 | .9526 | .9717 | 2.1879 | 1.9052 |
| 10 | .7733 | .8676 | .8573 | .9526 | .9431 | 2.1338 | 1.8099 |
| 11 | 1.9805 | 1.6975 | 2.1338 | 2.0386 | 2.0748 | .7049 | .6478 |
| 12 | 2.2068 | 2.3388 | 2.7435 | 2.3815 | 2.2634 | | .6287 |
| 13 | 2.0748 | 2.452 | 2.7054 | 2.4577 | 2.3765 | .6859 | .5525 |
| 14 | 2.2634 | | 2.5911 | 2.4577 | 2.4143 | .6668 | |
| 15 | 2.3011 | | 2.6482 | 2.4196 | 2.2634 | .6287 | |
| 16 | 2.3577 | | 2.7244 | 2.3434 | | .6478 | .5716 |
| 17 | 2.3011 | | 2.4768 | 2.1529 | 2.1691 | .6097 | .5525 |
| 18 | 2.2634 | | 2.0386 | 2.0767 | 1.9239 | .6097 | .6097 |
| 19 | .6413 | | .724 | .6668 | | .5716 | .5525 |
| 20 | .6224 | .6413 | .6668 | .6287 | .5658 | .4763 | .4572 |
| 21 | | .6036 | .6097 | .5525 | .5281 | .4382 | .4382 |
| 22 | .5281 | .5093 | .5716 | .4954 | .4904 | .4001 | .4001 |
| 23 | .4527 | .415 | .5335 | .4382 | .4527 | .3429 | |
| 24 | .362 | .3772 | .3961 | .4954 | .4191 | .3772 | .3429 |
| **Max** | **2.3577** | **2.452** | **2.7435** | **2.4577** | **2.4143** | **2.1879** | **1.9052** |
| **Min** | **.362** | **.3772** | **.381** | **.4382** | **.4001** | **.3429** | **.3239** |
| **Avg** | **1.1576** | **.8729** | **1.2517** | **1.2106** | **1.1191** | **.9281** | **.8465** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055]** **BU 0833**
**Substation No/ Name :- 214461 / 33 KV TAKALI HAJI**
**Feeder No / Name : 205 / Sablewadi** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4954 | .415 | .5144 | .4954 | .4763 | .5281 | .4954 |
| 2 | .5144 | | .5144 | .5144 | .4954 | .547 | .5335 |
| 3 | .6097 | .5658 | .6097 | .6859 | .6478 | .5658 | .5335 |
| 4 | .6478 | .6602 | .6287 | .7621 | .6859 | .6224 | .5716 |
| 5 | .6859 | .7545 | .6478 | .8573 | .7621 | .7167 | .6097 |
| 6 | .743 | .8299 | .8954 | 1.0479 | .9145 | .7356 | .6859 |
| 7 | 1.1812 | 1.2071 | 1.2384 | 1.2574 | 1.2193 | .8299 | .7811 |
| 8 | 1.5051 | 1.4712 | 1.7147 | 1.3717 | 1.467 | .8865 | .8764 |
| 9 | 1.4335 | 1.3957 | 1.8099 | 1.3527 | 1.5242 | .7922 | .8002 |
| 10 | 1.2826 | 1.3203 | 1.5242 | 1.2384 | 1.5089 | .6859 | .5144 |
| 11 | .7545 | .7167 | .6859 | .6478 | | 1.2765 | 1.0288 |
| 12 | .6979 | .6602 | .8192 | .4763 | .679 | 1.448 | 1.105 |
| 13 | | .7545 | .7811 | .6668 | .6224 | 1.5242 | 1.1241 |
| 14 | .6979 | | .7811 | .7811 | .5658 | 1.1812 | 1.1431 |
| 15 | .679 | | .7621 | .7049 | .6224 | 1.2955 | |
| 16 | .6602 | | .7621 | .724 | .6602 | 1.448 | |
| 17 | .6413 | | .7621 | .8002 | .679 | 1.3336 | .7621 |
| 18 | .6224 | | .7049 | .8002 | .6979 | 1.2193 | .7811 |
| 19 | .6413 | | .6859 | .6859 | | .5525 | .5144 |
| 20 | .6036 | .7545 | .6097 | .6287 | | .5144 | .4763 |
| 21 | .5658 | .5658 | .4954 | .5525 | | .4954 | .4572 |
| 22 | .5281 | .6036 | .4954 | .4954 | .5281 | .5144 | .4763 |
| 23 | .4527 | .5281 | .4763 | .4954 | .5281 | .4763 | .4954 |
| 24 | .4763 | .4527 | .5281 | .4954 | .4954 | .5093 | .4572 |
| **Max** | **1.5051** | **1.4712** | **1.8099** | **1.3717** | **1.5242** | **1.5242** | **1.1431** |
| **Min** | **.4527** | **.415** | **.4763** | **.4763** | **.4763** | **.4763** | **.4572** |
| **Avg** | **.7443** | **.8033** | **.8103** | **.7724** | **.7890** | **.8624** | **.6919** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055] BU 0833**
**Substation No/ Name :- 214461 / 33 KV TAKALI HAJI**
**Feeder No / Name : 206 / Takali Haji SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8002 | .7545 | .8383 | .8002 | .9335 | .9054 | .8192 |
| 2 | .8002 | 1.0374 | .8383 | .7811 | .9526 | .9431 | .8383 |
| 3 | 1.2955 | 1.1317 | 1.3336 | 1.3527 | 1.3908 | 1.0374 | .8954 |
| 4 | 1.3908 | 1.5089 | 1.3336 | 1.8099 | 1.4861 | 1.1317 | .9526 |
| 5 | 1.467 | | 1.4289 | 2.0957 | 1.5242 | 1.226 | 1.0288 |
| 6 | 1.6194 | 1.7918 | 1.8099 | 2.4768 | 1.7337 | 1.3203 | 1.1431 |
| 7 | 2.572 | 2.7349 | 2.572 | 3.0293 | 2.5149 | 1.5655 | 1.3336 |
| 8 | 3.0483 | 3.3196 | 3.5246 | 3.2579 | 3.0864 | 1.6221 | 1.3336 |
| 9 | 3.263 | 3.3008 | 3.8104 | 2.8578 | 3.1626 | 1.5089 | 1.1431 |
| 10 | 2.9801 | 3.2065 | 3.6199 | 2.7435 | 3.1121 | 1.1812 | .9145 |
| 11 | 1.094 | .9619 | 1.2955 | 1.0479 | 1.1883 | 2.3434 | 2.0957 |
| 12 | 1.0374 | .811 | 1.2574 | | 1.0562 | 2.8578 | 2.191 |
| 13 | | .9997 | 1.2765 | 1.1622 | .9997 | 3.0674 | 2.4006 |
| 14 | .8488 | | 1.2765 | 1.0669 | .9431 | 3.1245 | 2.4196 |
| 15 | 1.0185 | | 1.2574 | 1.0479 | .9619 | 2.8197 | |
| 16 | 1.094 | | 1.2384 | 1.0669 | 1.0374 | 3.0293 | |
| 17 | 1.1883 | | 1.2384 | 1.105 | 1.094 | 2.9912 | 1.6575 |
| 18 | 1.2826 | | 1.1622 | 1.2003 | 1.1506 | 2.7244 | 1.9243 |
| 19 | 1.2826 | | 1.1431 | 1.2955 | 1.2071 | 1.2574 | .9335 |
| 20 | 1.2071 | 1.1128 | 1.086 | 1.1241 | | .9335 | .8573 |
| 21 | 1.1317 | .9619 | .8954 | 1.0479 | .6602 | .9145 | .7811 |
| 22 | 1.0374 | .8676 | .8764 | .9907 | .9431 | .8954 | .743 |
| 23 | .9431 | .811 | .8573 | .9717 | .9054 | .8573 | .743 |
| 24 | .7621 | .8299 | .811 | .8192 | .9526 | .9054 | .8192 |
| **Max** | **3.263** | **3.3196** | **3.8104** | **3.2579** | **3.1626** | **3.1245** | **2.4196** |
| **Min** | **.7621** | **.7545** | **.811** | **.7811** | **.6602** | **.8573** | **.743** |
| **Avg** | **1.4419** | **1.5378** | **1.5325** | **1.5283** | **1.4346** | **1.7151** | **1.2713** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055] BU 0833**
**Substation No/ Name :- 214461 / 33 KV TAKALI HAJI**
**Feeder No / Name : 207 / 11 Kv Dongargan SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2477 | .2263 | .3048 | .2858 | .2667 | .2641 | .2858 |
| 2 | .2477 | .3772 | .3048 | .2667 | .2667 | .7545 | .3048 |
| 3 | .2667 | .3772 | .2667 | .2667 | .2477 | .8299 | .8192 |
| 4 | .2858 | .415 | .3048 | .3239 | .3048 | .9054 | .8573 |
| 5 | .3429 | .4527 | .3429 | .362 | .362 | .9431 | .8954 |
| 6 | .4382 | .4904 | .4954 | .4763 | .4572 | 1.0185 | 1.0669 |
| 7 | .5716 | .5658 | .6859 | .5716 | .5716 | 1.2826 | 1.2955 |
| 8 | .5525 | .5281 | .6478 | .5335 | .5335 | 1.5089 | 1.4289 |
| 9 | .4904 | .5281 | .6859 | .5716 | .5906 | 1.5089 | 1.4098 |
| 10 | .4338 | .5281 | .7049 | .4763 | .5658 | 1.5242 | 1.3717 |
| 11 | 1.226 | 1.2071 | 1.6385 | 1.2574 | 1.4146 | .3429 | .2858 |
| 12 | 1.3203 | 1.4146 | 1.8671 | 1.6004 | 1.6032 | .3048 | .2667 |
| 13 | | 1.5655 | 1.9052 | 1.6385 | 1.7353 | .3048 | .2286 |
| 14 | 1.4146 | | 1.9052 | 1.6575 | 1.6975 | .2858 | .2286 |
| 15 | 1.5466 | | 1.8861 | 1.5623 | 1.6032 | .3429 | |
| 16 | 1.5089 | | 1.8671 | 1.6004 | 1.5089 | .3429 | |
| 17 | 1.5089 | | 1.7147 | 1.448 | 1.4146 | .381 | .2286 |
| 18 | 1.5089 | | 1.2955 | 1.467 | 1.2826 | .4191 | .2858 |
| 19 | .415 | | .4572 | .4191 | | .4954 | .4382 |
| 20 | .3772 | .4527 | .4382 | .381 | .415 | .381 | .381 |
| 21 | .3395 | .3584 | .381 | .3048 | .3772 | .3429 | .362 |
| 22 | .3018 | .3584 | .3429 | .2667 | | .3048 | .3239 |
| 23 | .2641 | .2926 | .3048 | .2667 | .3018 | .3048 | .3048 |
| 24 | .2477 | .2263 | .3018 | .2858 | .2858 | .2641 | .3048 |
| **Max** | **1.5466** | **1.5655** | **1.9052** | **1.6575** | **1.7353** | **1.5242** | **1.4289** |
| **Min** | **.2477** | **.2263** | **.2667** | **.2667** | **.2477** | **.2641** | **.2286** |
| **Avg** | **.6894** | **.5758** | **.8771** | **.7621** | **.8094** | **.6399** | **.6079** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055] BU 0833**
**Substation No/ Name :- 214470 / 33/11KV JAMBUT**
**Feeder No / Name : 204 / 11 KV Gajare Mala SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4424 | .5281 | | .4481 | .4744 | .3953 | 1.1336 |
| 2 | .4424 | .5121 | .4161 | .4961 | .4902 | .3795 | 1.1984 |
| 3 | .5601 | .5121 | .4481 | .5121 | .5441 | 1.2651 | 1.3123 |
| 4 | .6081 | .6081 | .4481 | .5601 | .5921 | 1.4232 | 1.4083 |
| 5 | .6562 | | .4801 | .6081 | .4321 | 1.5813 | 1.4083 |
| 6 | 1.1069 | .427 | .6325 | .6401 | .4481 | 1.7394 | |
| 7 | 1.0279 | .9172 | .7116 | .7042 | 1.1363 | 1.9204 | 1.8884 |
| 8 | .9282 | .8697 | .7907 | .6483 | 1.0242 | 2.2297 | 2.0873 |
| 9 | .7522 | .68 | .6483 | .5376 | .5441 | 2.3045 | .933 |
| 10 | .5761 | .4902 | .5376 | .5921 | .5441 | 2.17 | .7274 |
| 11 | 2.0645 | 2.119 | 2.6566 | 2.2565 | 2.0005 | .2401 | |
| 12 | 2.5934 | 2.4669 | 2.9447 | 2.5926 | 2.3525 | | .4586 |
| 13 | 2.6408 | 2.4985 | 2.9254 | 2.5606 | 2.4166 | | .427 |
| 14 | 2.6408 | 2.5301 | 2.9412 | 2.6406 | 2.4669 | | .427 |
| 15 | 2.5934 | 2.4669 | 2.9096 | 2.4326 | 2.451 | | .253 |
| 16 | 2.372 | 2.5617 | 2.9096 | 2.4806 | 2.451 | | .2846 |
| 17 | 2.1822 | 2.0715 | 2.5301 | 2.4036 | 2.119 | | .3041 |
| 18 | 2.3245 | | | 2.4669 | 2.0873 | 1.0595 | .7042 |
| 19 | .8223 | .6325 | .7842 | .8697 | .5535 | 1.0242 | .8962 |
| 20 | .8322 | .5601 | .6401 | .9014 | .4801 | .8848 | .8002 |
| 21 | .7362 | .5121 | .5601 | .759 | .4428 | .7042 | .6401 |
| 22 | .5761 | .4801 | .4481 | .6642 | .4481 | .5506 | .5601 |
| 23 | .5601 | .4641 | .4481 | .506 | .4744 | .4534 | .8642 |
| 24 | .4424 | .5441 | .4801 | .4481 | .4744 | .4428 | .4534 |
| **Max** | **2.6408** | **2.5617** | **2.9447** | **2.6406** | **2.4669** | **2.3045** | **2.0873** |
| **Min** | **.4424** | **.427** | **.4161** | **.4481** | **.4321** | **.2401** | **.253** |
| **Avg** | **1.2701** | **1.1569** | **1.2860** | **1.2387** | **1.1437** | **1.1538** | **.8714** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055] BU 0833**
**Substation No/ Name :- 214470 / 33/11KV JAMBUT**
**Feeder No / Name : 206 / 11 Kv GurunathNagar SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4915 | .3841 | .6401 | .4801 | .4744 | .4428 | .4696 |
| 2 | .4915 | .4161 | .7202 | .4801 | .4744 | .3953 | .4696 |
| 3 | .9602 | 1.1203 | 1.2003 | 1.4403 | 1.1523 | .4744 | .4641 |
| 4 | 1.0402 | 1.2643 | 1.2163 | 1.6004 | 1.2323 | .5535 | .4801 |
| 5 | 1.2003 | 1.3125 | 1.2163 | 1.7604 | 1.4403 | .6009 | .4801 |
| 6 | .7116 | 1.439 | 1.2963 | 1.8976 | 1.6644 | .6325 | |
| 7 | .7116 | 1.6446 | 1.5813 | 1.9608 | 1.9845 | .68 | .6722 |
| 8 | 1.6004 | 1.8818 | 2.2138 | 1.9608 | 1.8884 | .7362 | .6642 |
| 9 | 2.0485 | .4744 | .5218 | .4428 | .4641 | .5761 | 1.3916 |
| 10 | 1.5844 | .3637 | .3953 | .3841 | .3521 | | 1.5497 |
| 11 | .2401 | .2056 | .4161 | .2721 | .16 | 1.2963 | 1.5655 |
| 12 | .1898 | .1265 | .2241 | .2561 | .128 | .3201 | 1.6288 |
| 13 | .1739 | | .2846 | .2241 | .16 | .2881 | 1.6129 |
| 14 | .1581 | .1898 | .3321 | .16 | .1581 | 1.7124 | 1.4548 |
| 15 | .1581 | .2056 | .3479 | .192 | .1581 | 1.6604 | 1.0279 |
| 16 | .1423 | .3321 | .3795 | .2721 | .1581 | .2688 | 1.0437 |
| 17 | .2056 | .3479 | .4744 | .2846 | .1898 | 1.4232 | .2401 |
| 18 | .4744 | .5218 | .6009 | .4744 | .3953 | 1.4232 | .4161 |
| 19 | .6958 | .8223 | .8322 | .6958 | .68 | .5441 | .5761 |
| 20 | .6081 | .7202 | .7682 | .5851 | .6325 | .5407 | .4801 |
| 21 | .4961 | .6081 | .6401 | .5535 | .5535 | .4801 | .4481 |
| 22 | .4481 | .5761 | .5281 | .5218 | .4428 | .4696 | .4321 |
| 23 | .4321 | .5761 | .4801 | | .3953 | .4858 | .4161 |
| 24 | .4915 | .3841 | .5761 | .4481 | .4744 | .4744 | .4696 |
| **Max** | **2.0485** | **1.8818** | **2.2138** | **1.9608** | **1.9845** | **1.7124** | **1.6288** |
| **Min** | **.1423** | **.1265** | **.2241** | **.16** | **.128** | **.2688** | **.2401** |
| **Avg** | **.6564** | **.6920** | **.7453** | **.7542** | **.6589** | **.7165** | **.8023** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055] BU 0833**
**Substation No/ Name :- 214483 / 33/11 kv Shirasgaon Kata**
**Feeder No / Name : 201 / 11 kv Shirasgaon Kata SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 30-NOV-17 | 01-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .3772 | | .3961 | .3429 |
| 2 | | .3921 | | .3961 | .3258 |
| 3 | | .3734 | | 1.749 | 2.6406 |
| 4 | | .4481 | | 2.0153 | 2.7435 |
| 5 | | .4854 | | 2.2045 | 2.9492 |
| 6 | | .6348 | | 2.7515 | 3.1722 |
| 7 | | .7468 | | 3.2327 | 3.5665 |
| 8 | | .6722 | | 3.4888 | 3.6523 |
| 9 | | .5041 | | 3.5471 | 3.4979 |
| 10 | .4049 | .4668 | .4049 | 3.4974 | 3.5151 |
| 11 | 3.5303 | | 3.4008 | .2743 | .3429 |
| 12 | 4.4048 | | 3.9514 | .2401 | |
| 13 | 4.6091 | | 4.2105 | .2229 | |
| 14 | 4.7405 | | 4.193 | .2058 | |
| 15 | 4.5877 | | 4.2928 | .2058 | |
| 16 | 4.5058 | | 4.1438 | .2401 | |
| 17 | 4.6411 | | 3.8952 | .2572 | |
| 18 | 3.6797 | | 3.7792 | .3772 | |
| 19 | .5788 | | .4481 | .4973 | |
| 20 | .5281 | | .4294 | .4458 | |
| 21 | .4527 | | .3961 | .4115 | |
| 22 | .3961 | | .3772 | .3601 | |
| 23 | .3772 | | .415 | .3429 | |
| 24 | | .415 | | .3772 | .3429 |
| **Max** | **4.7405** | **.7468** | **4.2928** | **3.5471** | **3.6523** |
| **Min** | **.3772** | **.3734** | **.3772** | **.2058** | **.3258** |
| **Avg** | **2.6741** | **.5014** | **2.4527** | **1.1557** | **2.2577** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055] BU 0833**
**Substation No/ Name :- 214483 / 33/11 kv Shirasgaon Kata**
**Feeder No / Name : 202 / 11 kv Pimpalsuti SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 30-NOV-17 | 01-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .0189 | | .3772 | .3086 |
| 2 | | .3584 | | .3584 | .3086 |
| 3 | | 1.7404 | | .3772 | .3086 |
| 4 | | 1.6842 | | .415 | .3429 |
| 5 | | 1.8399 | | .4481 | .3772 |
| 6 | | 1.9559 | | .4854 | .4115 |
| 7 | | 2.5194 | | .6722 | .4801 |
| 8 | | 2.6558 | | .5788 | .4973 |
| 9 | | 2.652 | | .3734 | .3944 |
| 10 | 2.753 | 2.5526 | 2.4777 | .2641 | .2915 |
| 11 | .2452 | | .2641 | 2.1948 | 2.4006 |
| 12 | .1698 | | .2241 | 2.332 | |
| 13 | .1698 | | .1867 | 2.4006 | |
| 14 | .1509 | | .1867 | 2.5377 | |
| 15 | .1698 | | .2054 | 2.572 | |
| 16 | .1698 | | .2054 | 2.6406 | |
| 17 | .1886 | | .2614 | 2.5892 | |
| 18 | .4338 | | .3584 | 2.5377 | |
| 19 | .4715 | | .4481 | .3944 | |
| 20 | .415 | | .3921 | .3601 | |
| 21 | .3772 | | .3772 | .3429 | |
| 22 | .3584 | | .3772 | .2915 | |
| 23 | .3584 | | .3772 | .2743 | |
| 24 | | .3395 | | .3395 | .2915 |
| **Max** | **2.753** | **2.6558** | **2.4777** | **2.6406** | **2.4006** |
| **Min** | **.1509** | **.0189** | **.1867** | **.2641** | **.2915** |
| **Avg** | **.4594** | **1.6652** | **.4530** | **1.0899** | **.5344** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055] BU 0833**
**Substation No/ Name :- 214483 / 33/11 kv Shirasgaon Kata**
**Feeder No / Name : 203 / 11 kv Shirasgaon Kata Gfss GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 30-NOV-17 | 01-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .0747 | | .0934 | .1029 |
| 2 | | .0754 | | | .0857 |
| 3 | | .0754 | | .0943 | .1029 |
| 4 | | .1132 | | .112 | .1372 |
| 5 | | .112 | | .1494 | .1715 |
| 6 | | .1867 | | .1848 | .1715 |
| 7 | | .2801 | | .2772 | .2058 |
| 8 | | .2801 | | .2218 | .2401 |
| 9 | | .2614 | | .2218 | .2058 |
| 10 | .1619 | .2054 | .1619 | .1848 | .1543 |
| 11 | .0934 | | .1478 | .1372 | .0857 |
| 12 | .0934 | | .0166 | .12 | |
| 13 | .112 | | .1663 | .1029 | |
| 14 | .0934 | | .1307 | .1029 | |
| 15 | | | .1307 | .1029 | |
| 16 | | | .1494 | .1029 | |
| 17 | | | .112 | .1372 | |
| 18 | .1867 | | .1494 | .1372 | |
| 19 | .2427 | | .2218 | .1715 | |
| 20 | .1867 | | .2033 | .1715 | |
| 21 | .1494 | | .1478 | .1372 | |
| 22 | .112 | | .0934 | .1029 | |
| 23 | | | .0934 | .1029 | |
| 24 | | 1.8861 | | .0934 | .1029 |
| **Max** | **.2427** | **1.8861** | **.2218** | **.2772** | **.2401** |
| **Min** | **.0934** | **.0747** | **.0166** | **.0934** | **.0857** |
| **Avg** | **.1432** | **.3228** | **.1375** | **.1418** | **.1472** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055] BU 0833**
**Substation No/ Name :- 214483 / 33/11 kv Shirasgaon Kata**
**Feeder No / Name : 204 / 11 kv Chinchani SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 30-NOV-17 | 01-DEC-17 |
|---|---|---|
| HR | Load (MW) | Load (MW) |
| 1 | | .3018 |
| 2 | | .2801 |
| 3 | | 2.2996 |
| 4 | | 2.3967 |
| 5 | | 2.9172 |
| 6 | | 2.9172 |
| 7 | | 2.982 |
| 8 | | 2.4777 |
| 9 | | 3.2156 |
| 10 | | 3.1493 |
| 18 | .3584 | |
| 20 | .3547 | |
| 21 | .3361 | |
| 22 | .2987 | |
| 24 | | 1.8861 |
| **Max** | **.3584** | **3.2156** |
| **Min** | **.2987** | **.2801** |
| **Avg** | **.3370** | **2.2567** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055]** **BU 0833**
**Substation No/ Name :- 214483 / 33/11 kv Shirasgaon Kata**
**Feeder No / Name : 205 / 11 kv Nirvee** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 30-NOV-17 | 01-DEC-17 |
|---|---|---|
| HR | Load (MW) | Load (MW) |
| 1 | | .3395 |
| 2 | | .3361 |
| 3 | | .3361 |
| 4 | | .3772 |
| 5 | | .3772 |
| 6 | | .4527 |
| 7 | | .679 |
| 8 | | .5228 |
| 9 | | .4481 |
| 10 | | .3206 |
| 18 | 2.6886 | |
| 19 | .5093 | |
| 20 | .4338 | |
| 21 | .3772 | |
| 22 | .3361 | |
| 24 | | 1.8861 |
| Max | **2.6886** | **1.8861** |
| Min | **.3361** | **.3206** |
| Avg | **.869** | **.5523** |

 Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055]** **BU 0833**
**Substation No/ Name :- 214483 / 33/11 kv Shirasgaon Kata**
**Feeder No / Name : 206 / 11 kv Zapfa** **NON SHEDDABLE EXPRESS HV FEEDERS**
**Feeder KV- 11 / OUTGOING** **(CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 30-NOV-17 | 01-DEC-17 |
|---|---|---|
| HR | Load (MW) | Load (MW) |
| 1 | | .0943 |
| 2 | | .0943 |
| 4 | | .112 |
| 5 | | .1494 |
| 6 | | .1867 |
| 7 | | .2801 |
| 8 | | .2614 |
| 9 | | .2801 |
| 10 | | .2427 |
| 18 | .2772 | |
| 19 | .2587 | |
| 20 | .1307 | |
| 21 | .1494 | |
| 22 | .1307 | |
| 24 | | 1.8861 |
| **Max** | **.2772** | **1.8861** |
| **Min** | **.1307** | **.0943** |
| **Avg** | **.1893** | **.3587** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055] BU 0833**
**Substation No/ Name :- 214522 / 33/11 KV NImone Sub station**
**Feeder No / Name : 201 / 11 KV NIMONE GAOTHAN GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .1509 | .132 | .132 | .132 | .132 | .132 |
| 2 | | .132 | .132 | | .132 | .132 | .132 |
| 3 | | .1509 | .132 | .1509 | .1509 | .1509 | .132 |
| 4 | | .1886 | .1509 | .2263 | .1886 | .1886 | .1509 |
| 5 | | .2263 | .1886 | .3395 | .2075 | .2263 | .1886 |
| 6 | | .3206 | .2829 | .3961 | .2641 | .3018 | .3018 |
| 7 | .2641 | .3772 | .415 | | .3395 | .3772 | .3584 |
| 8 | .2641 | .415 | .3206 | .3772 | .3584 | .3772 | .3584 |
| 9 | .3772 | .4904 | .3772 | .3395 | .3961 | .415 | .415 |
| 10 | .3395 | .3395 | .3584 | .2263 | .3395 | .3206 | .3292 |
| 11 | .2075 | .2452 | .2452 | .2452 | .2263 | .2641 | .2263 |
| 12 | .1886 | .2075 | .2263 | .1886 | .1886 | .1886 | .1886 |
| 13 | .1509 | .1698 | .1698 | .1509 | .1509 | .1509 | .1698 |
| 14 | .1509 | .1698 | .1698 | .132 | .1509 | .1509 | .1509 |
| 15 | .1698 | .1698 | .1886 | .132 | .1509 | .1509 | .1509 |
| 16 | .1698 | .1509 | .1509 | .132 | .1509 | .1698 | .1509 |
| 17 | .1886 | .1509 | .1509 | .1509 | .1886 | .2263 | .1509 |
| 18 | .2075 | .2075 | .2263 | .1698 | .2263 | .2641 | .2263 |
| 19 | .3018 | .3206 | .3018 | .3018 | .2829 | .2829 | .3206 |
| 20 | .2641 | .3018 | .2641 | .2452 | .2452 | .2641 | .2263 |
| 21 | .2452 | .2263 | .2263 | .2075 | .1509 | .2075 | .2263 |
| 22 | .1886 | .132 | .1886 | .1698 | .1509 | .1698 | .2263 |
| 23 | .1698 | .132 | .1886 | .1509 | .1509 | .1509 | .1886 |
| 24 | | .1509 | .132 | .1509 | .1509 | .1509 | .132 |
| **Max** | **.3772** | **.4904** | **.415** | **.3961** | **.3961** | **.415** | **.415** |
| **Min** | **.1509** | **.132** | **.132** | **.132** | **.132** | **.132** | **.132** |
| **Avg** | **.2264** | **.2303** | **.2216** | **.2143** | **.2114** | **.2256** | **.2180** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055]** **BU 0833**
**Substation No/ Name :- 214522 / 33/11 KV NImone Sub station**
**Feeder No / Name : 205 / 11 KV Kurhadwadi AG** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .1509 | .128 | .1509 | .1509 | .1509 | .128 |
| 2 | | .1698 | .128 | .1509 | .1698 | .1509 | .128 |
| 3 | | | .128 | .1509 | .1698 | .9054 | .7537 |
| 4 | | .1886 | .1463 | .1886 | .1886 | .9724 | .7865 |
| 5 | | .2263 | .2195 | .2263 | .2263 | 1.0059 | .8848 |
| 6 | | .3018 | .3109 | .2641 | .3018 | 1.0395 | .9503 |
| 7 | .415 | .3206 | .4024 | .3584 | .2075 | 1.1065 | 1.0978 |
| 8 | .3734 | .3395 | .3961 | .3395 | .3018 | 1.2407 | 1.1961 |
| 9 | .3395 | .2926 | .2641 | .2641 | .2829 | 1.2289 | .9389 |
| 10 | .2263 | .2195 | .2452 | .2263 | .2263 | 1.1142 | 1.1065 |
| 11 | 1.1069 | 1.0978 | 1.2071 | 1.0753 | 1.2071 | .1097 | .1509 |
| 12 | 1.2809 | 1.3108 | 1.4754 | 1.1702 | 1.3748 | .0732 | .0754 |
| 13 | 1.4864 | 1.4582 | 1.5089 | 1.2492 | 1.4083 | .0914 | .0754 |
| 14 | 1.5223 | 1.4746 | 1.4754 | 1.2967 | 1.4419 | .1097 | .0943 |
| 15 | 1.4899 | 1.3927 | 1.4419 | 1.3283 | 1.3413 | .1097 | .0754 |
| 16 | 1.4232 | 1.4255 | 1.4419 | 1.3283 | 1.2071 | .1097 | .0754 |
| 17 | 1.4232 | 1.4255 | 1.4586 | 1.3283 | 1.3077 | .1463 | .1132 |
| 18 | 1.3272 | 1.4419 | 1.4754 | 1.3441 | 1.3748 | .1829 | .2263 |
| 19 | .3018 | .3109 | .3395 | .3395 | .3018 | .3109 | .3395 |
| 20 | .2641 | .2561 | .4904 | .2641 | .2641 | .2926 | .2263 |
| 21 | .1698 | .1829 | .1886 | .2075 | .1886 | .1646 | .1698 |
| 22 | .1698 | .1463 | .1509 | .1698 | .1886 | .1463 | .1698 |
| 23 | .1698 | .1463 | .1509 | .1509 | .1509 | .1463 | .1509 |
| 24 | | .1509 | .128 | .1509 | .1509 | .1509 | .128 |
| **Max** | **1.5223** | **1.4746** | **1.5089** | **1.3441** | **1.4419** | **1.2407** | **1.1961** |
| **Min** | **.1698** | **.1463** | **.128** | **.1509** | **.1509** | **.0732** | **.0754** |
| **Avg** | **.7935** | **.6274** | **.6376** | **.5718** | **.5889** | **.4608** | **.4184** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055] BU 0833**
**Substation No/ Name :- 214522 / 33/11 KV NImone Sub station**
**Feeder No / Name : 206 / 11 KV Pimpachiwadi SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .2561 | .0183 | .3395 | .2587 | .3018 | .2561 |
| 2 | | .3109 | .3109 | .3395 | .2772 | .3018 | .2561 |
| 3 | | 1.8679 | 2.0317 | 2.0119 | 1.5684 | .3395 | .2926 |
| 4 | | 1.8564 | 2.0645 | 2.1125 | 1.749 | .415 | .3292 |
| 5 | | 1.9204 | 2.13 | 2.1795 | 1.7814 | .4904 | .4024 |
| 6 | | 2.0243 | 2.13 | 2.2131 | 1.9498 | .5281 | .5121 |
| 7 | 2.5484 | 2.3868 | 2.4249 | 2.4813 | 2.3371 | .6413 | .6036 |
| 8 | 2.8166 | 2.8995 | 2.7526 | 2.8166 | 2.6852 | .5228 | .5853 |
| 9 | 2.7526 | 2.8673 | 2.5484 | 2.5301 | 2.7496 | .4572 | .4527 |
| 10 | 2.7035 | 2.7526 | 2.6825 | 2.2994 | 2.5484 | .3841 | .4527 |
| 11 | .2743 | .2743 | .3395 | .2772 | .3018 | 2.0972 | 2.079 |
| 12 | .2587 | .2012 | .2263 | .2772 | .3018 | 2.5232 | 2.7831 |
| 13 | .2402 | .1829 | .2263 | .2587 | .2641 | 2.6871 | 2.5149 |
| 14 | | .1646 | .2263 | .2587 | .2263 | 2.6707 | 2.4143 |
| 15 | .1848 | .1646 | .2263 | .2218 | .2263 | 2.7199 | 2.3472 |
| 16 | .2218 | .1646 | .2263 | .2402 | .2263 | 2.7362 | 2.3472 |
| 17 | .2587 | .1829 | .2263 | .2957 | .3018 | 2.7035 | 2.2131 |
| 18 | .3326 | .3292 | .4527 | .3921 | .3772 | 2.6871 | 2.2131 |
| 19 | .5658 | .5121 | .6036 | .5847 | .5281 | .5487 | .5228 |
| 20 | .4481 | .439 | .5281 | .4481 | .4527 | .5487 | .3772 |
| 21 | .3696 | .4024 | .3772 | .3326 | .3395 | .3292 | .3018 |
| 22 | .3326 | | .3772 | .2957 | .3395 | .3109 | .3018 |
| 23 | .2561 | .3292 | .3395 | .2587 | .3395 | .2926 | .2641 |
| 24 | | .2561 | .3292 | .3395 | .2587 | .3018 | .2926 |
| **Max** | **2.8166** | **2.8995** | **2.7526** | **2.8166** | **2.7496** | **2.7362** | **2.7831** |
| **Min** | **.1848** | **.1646** | **.0183** | **.2218** | **.2263** | **.2926** | **.2561** |
| **Avg** | **.9103** | **.9889** | **.9916** | **.9918** | **.9329** | **1.1475** | **1.0465** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055]** **BU 0833**
**Substation No/ Name :- 214532 / 33/11 Ganegaon Dumala**
**Feeder No / Name : 201 / 11 SANGAMESHWAR AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 |
|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) |
| 2 | | | .168 |
| 7 | | .1867 | .2614 |
| 8 | | | .2427 |
| 10 | | .1307 | |
| 11 | | 2.3472 | |
| 14 | | 2.3807 | |
| 16 | | 2.2466 | |
| 18 | | 2.1795 | |
| 19 | | .1867 | |
| 23 | | .168 | |
| 24 | .1698 | .168 | .168 |
| **Max** | **.1698** | **2.3807** | **.2614** |
| **Min** | **.1698** | **.1307** | **.168** |
| **Avg** | **.1698** | **1.1105** | **.2100** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055] BU 0833**
**Substation No/ Name :- 214532 / 33/11 Ganegaon Dumala**
**Feeder No / Name : 202 / 11 KV UDANSHAHA BABA AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 |
|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) |
| 2 | | .1307 | .1494 |
| 7 | | | .7712 |
| 8 | | | .8383 |
| 10 | | .7377 | |
| 11 | | .1307 | |
| 14 | | .0549 | |
| 16 | | .0747 | |
| 18 | | .2054 | |
| 19 | | .2452 | |
| 23 | | .132 | |
| 24 | .168 | .1494 | .1509 |
| Max | **.168** | **.7377** | **.8383** |
| Min | **.168** | **.0549** | **.1494** |
| Avg | **.168** | **.2067** | **.4775** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055] BU 0833**
**Substation No/ Name :- 214532 / 33/11 Ganegaon Dumala**
**Feeder No / Name : 303 / 11 kv Tandali Ag SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 |
|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) |
| 2 | | | .0526 |
| 7 | | | .3241 |
| 8 | | | .3549 |
| 10 | | .3944 | |
| 12 | | .0173 | |
| 16 | | .0175 | |
| 18 | | .0347 | |
| 19 | | .0514 | |
| 23 | | .0537 | |
| 24 | .0543 | .0566 | .0537 |
| Max | **.0543** | **.3944** | **.3549** |
| Min | **.0543** | **.0173** | **.0526** |
| Avg | **.0543** | **.0894** | **.1963** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**DOUND DIVISION[510]**
**SHIRUR[055]** **BU 0833**
**Substation No/ Name :- 217010 / 132/33/22 KV SHIRUR**
**Feeder No / Name : 305 / MALLIKARJUN SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 3.7723 |
| Max | 3.7723 |
| Min | 3.7723 |
| Avg | 3.7723 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**BHOR[056] BU 0841**
**Substation No/ Name :- 214484 / 33 KV NIGUDGHAR**
**Feeder No / Name : 201 / 11 KV SHIRWALI GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0225 | .0347 | .0372 | .0112 | .0343 | .0278 | .0349 |
| 2 | .0271 | .0343 | .0372 | .0152 | .0351 | .0316 | .0229 |
| 3 | .0278 | .0351 | .0372 | .0164 | .0351 | .0305 | .0229 |
| 4 | .0251 | .0351 | .0372 | .0145 | .0343 | .0263 | .0229 |
| 5 | .0282 | .0347 | .0377 | .0149 | .0343 | .0282 | .0229 |
| 6 | .0301 | .0343 | .0389 | .0463 | .0339 | .0316 | .0244 |
| 7 | .0509 | .1134 | .0594 | .0753 | .0762 | .0514 | .0429 |
| 8 | .112 | .0934 | .0823 | .0762 | .0667 | .0497 | .0181 |
| 9 | .0328 | .0743 | .0667 | .0543 | .0514 | .0339 | .0181 |
| 10 | .0434 | .0541 | .029 | .0173 | .0309 | .044 | .0171 |
| 11 | .0354 | .061 | .0602 | .0383 | .0914 | .0429 | .0556 |
| 12 | .0389 | .0591 | .0766 | .0267 | .0556 | .04 | .0762 |
| 13 | .0495 | .0581 | .0366 | .0457 | .0743 | .0406 | .0724 |
| 14 | .0533 | .0591 | .0168 | .0305 | .0791 | .0259 | .0278 |
| 15 | .0533 | .0383 | .0351 | .0305 | .0434 | .0251 | .0903 |
| 16 | .0533 | .061 | .0564 | .0282 | .0526 | .0518 | .0518 |
| 17 | .0934 | .072 | .0394 | .0457 | .0457 | .0629 | .0949 |
| 18 | .1006 | .0705 | .0876 | .0492 | .0497 | .08 | .0914 |
| 19 | .1052 | .0876 | .0934 | .0886 | .0709 | .0886 | .0914 |
| 20 | .1052 | .0886 | .0934 | .0895 | .0724 | .0716 | .0867 |
| 21 | .0701 | .0848 | .0739 | .0732 | .0686 | | .0678 |
| 22 | .0514 | .0617 | .0532 | .0716 | .0474 | | .0492 |
| 23 | .0537 | .0406 | .0316 | .0526 | .0406 | | .0423 |
| 24 | .0383 | .0526 | .0377 | .0282 | | .0434 | .0354 |
| **Max** | **.112** | **.1134** | **.0934** | **.0895** | **.0914** | **.0886** | **.0949** |
| **Min** | **.0225** | **.0343** | **.0168** | **.0112** | **.0309** | **.0251** | **.0171** |
| **Avg** | **.0542** | **.0599** | **.0523** | **.0433** | **.0532** | **.0442** | **.0492** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**BHOR[056] BU 0841**
**Substation No/ Name :- 214484 / 33 KV NIGUDGHAR**
**Feeder No / Name : 202 / 11 KV WAGHJAI GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0857 | .1307 | .0753 | .0747 | .0914 | .0747 | .0566 |
| 2 | .0838 | .1294 | .0753 | .0754 | .0914 | .0709 | .0566 |
| 3 | .0876 | .1109 | .0753 | .0693 | .0905 | .0739 | .0566 |
| 4 | .0848 | .112 | .0753 | .0747 | .0905 | .0693 | .0566 |
| 5 | .0876 | .1294 | .0762 | .0716 | .0914 | .0905 | .0566 |
| 6 | .1109 | .1307 | .0937 | .0724 | .1097 | .1109 | .0747 |
| 7 | .168 | .2054 | .124 | .1509 | .1478 | .1509 | .0781 |
| 8 | .1949 | .2172 | .176 | .1991 | .1848 | .1478 | .1067 |
| 9 | .2427 | .2126 | .1718 | .2012 | .1433 | .1267 | .0905 |
| 10 | .1698 | .1886 | .16 | .1772 | .1433 | .1372 | .0819 |
| 11 | .1526 | .16 | .1509 | .1772 | .1174 | .1311 | .081 |
| 12 | .1341 | .1423 | .108 | .1753 | .112 | .108 | .0671 |
| 13 | .1311 | .1505 | .1075 | .1865 | .1543 | .0892 | .1475 |
| 14 | .1311 | .1128 | .1214 | .1696 | .176 | .0734 | .1219 |
| 15 | .1094 | .1094 | .1075 | .116 | .1355 | .0903 | .1134 |
| 16 | .1147 | .1235 | .124 | .1475 | .128 | .0857 | .116 |
| 17 | .1781 | .1524 | .1448 | .1492 | .1265 | .0987 | .1372 |
| 18 | .2241 | .1526 | .1791 | .1791 | .1433 | .1492 | .1949 |
| 19 | .2614 | .1991 | .2075 | .2054 | .2241 | .1463 | .2241 |
| 20 | .2452 | .2149 | .2075 | .2075 | .1886 | .1646 | .2452 |
| 21 | .2241 | .1949 | .1886 | .2075 | .1886 | | .2054 |
| 22 | .1867 | .1526 | .1509 | .1494 | .1294 | | .1294 |
| 23 | .1307 | .1107 | .0943 | .1132 | .1075 | | .0838 |
| 24 | .1006 | .1307 | .0914 | .0943 | .0934 | .0829 | .0566 |
| **Max** | **.2614** | **.2172** | **.2075** | **.2075** | **.2241** | **.1646** | **.2452** |
| **Min** | **.0838** | **.1094** | **.0753** | **.0693** | **.0905** | **.0693** | **.0566** |
| **Avg** | **.1517** | **.1531** | **.1286** | **.1435** | **.1337** | **.1082** | **.1099** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**BHOR[056]** **BU 0841**
**Substation No/ Name :- 214484 / 33 KV NIGUDGHAR**
**Feeder No / Name : 203 / 11 KV Raireshwar** **GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5493 | .5487 | .5194 | .4904 | .5487 | .4706 | .3961 |
| 2 | .5493 | .5487 | .5194 | .4656 | .5304 | .4755 | .3734 |
| 3 | .567 | .5175 | .5194 | .4755 | .5304 | .4656 | .3734 |
| 4 | .5552 | .5487 | .5194 | .4481 | .5249 | .4409 | .3734 |
| 5 | .5197 | .5487 | .5194 | .4435 | .5304 | .4904 | .3734 |
| 6 | .7059 | .6219 | .5792 | .547 | .6283 | .6468 | .4481 |
| 7 | .8596 | .7682 | .7316 | .6908 | .8131 | .823 | .5228 |
| 8 | .8939 | .8326 | .8596 | .8413 | .8413 | .905 | .5415 |
| 9 | .9745 | .8596 | .8589 | .9511 | .815 | .8954 | .5544 |
| 10 | .9774 | .9362 | 1.0692 | 1.134 | .9465 | .8842 | .4435 |
| 11 | .9724 | .8718 | 1.0117 | .8764 | .8682 | .7282 | .5373 |
| 12 | .8817 | .7625 | .2743 | .2629 | .929 | .7545 | .591 |
| 13 | .7461 | .7865 | .3155 | .8916 | .8764 | .6952 | .4801 |
| 14 | .7537 | .6321 | .929 | .823 | .7973 | .6783 | .5083 |
| 15 | .78 | .6962 | .9114 | .823 | .8573 | .6415 | .5138 |
| 16 | .7969 | .7459 | 1.0808 | .8139 | .9391 | .6687 | .5316 |
| 17 | .8383 | .8309 | 1.0099 | .8288 | .9362 | .7282 | .6379 |
| 18 | .9465 | 1.0229 | 1.1104 | 1.0974 | .9593 | .9412 | .7164 |
| 19 | 1.267 | 1.2071 | 1.1706 | 1.2012 | 1.0974 | .9335 | .924 |
| 20 | 1.1706 | 1.134 | 1.0456 | 1.1643 | 1.0082 | .8299 | .8501 |
| 21 | .9877 | .9877 | .9709 | .9979 | .8871 | | .7468 |
| 22 | .8131 | .7316 | .811 | .8775 | .7762 | | .5788 |
| 23 | .7316 | .5731 | .5914 | .7282 | .6024 | | .4024 |
| 24 | .5847 | .5487 | .5373 | .4755 | .6099 | .567 | .4108 |
| **Max** | **1.267** | **1.2071** | **1.1706** | **1.2012** | **1.0974** | **.9412** | **.924** |
| **Min** | **.5197** | **.5175** | **.2743** | **.2629** | **.5249** | **.4409** | **.3734** |
| **Avg** | **.8093** | **.7609** | **.7694** | **.7645** | **.7855** | **.6983** | **.5346** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**BHOR[056] BU 0841**
**Substation No/ Name :- 214484 / 33 KV NIGUDGHAR**
**Feeder No / Name : 205 / Pombardi Ag FEEDER SEPERATION/PURE AG**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 |
|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0173 | .0156 | | | |
| 2 | .0154 | .0156 | | | |
| 3 | .0151 | .0164 | | | |
| 4 | .0354 | .0164 | | | |
| 5 | .0162 | .016 | | | |
| 6 | .0339 | .016 | | | |
| 7 | .0168 | .016 | | | |
| 9 | | .0819 | .0829 | .1791 | .0876 |
| 10 | | .0819 | .0983 | .1492 | .0819 |
| 11 | | .1174 | .1357 | .1578 | .0892 |
| 12 | | .1147 | .0848 | .1543 | .0937 |
| 13 | | .1311 | .0648 | .1966 | .104 |
| 14 | | .156 | .104 | .1311 | .104 |
| 15 | | .1326 | .1341 | .1457 | .132 |
| 16 | | .1326 | .1187 | .144 | .1189 |
| 24 | .0151 | .0162 | | | |
| **Max** | **.0354** | **.156** | **.1357** | **.1966** | **.132** |
| **Min** | **.0151** | **.0156** | **.0648** | **.1311** | **.0819** |
| **Avg** | **.0207** | **.0673** | **.1029** | **.1572** | **.1014** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**BHOR[056] BU 0841**
**Substation No/ Name :- 214544 / 33/11 KV KHANAPUR**
**Feeder No / Name : 201 / VEESGAON GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1543 | .1663 | .168 | .1543 | .1646 | .1646 | .1341 |
| 2 | .1372 | .1509 | .1698 | .1341 | .1663 | .1463 | .1341 |
| 3 | .1341 | .1494 | .1494 | .1341 | .1494 | .1463 | .1341 |
| 4 | .1341 | .168 | .168 | .1372 | .1698 | .1463 | .1475 |
| 5 | .1677 | .2054 | .2241 | .2058 | .1991 | .1646 | .1475 |
| 6 | .2347 | .3109 | .2987 | .2743 | .2772 | .2743 | .2012 |
| 7 | .3944 | .4668 | .3921 | .4115 | .462 | .439 | .2458 |
| 8 | .4938 | .5093 | | .4938 | .5601 | .5487 | .2515 |
| 9 | .3898 | .4887 | .4854 | .4607 | .547 | .4572 | .285 |
| 10 | .4108 | .4854 | .4784 | .5228 | .5788 | .4252 | .2378 |
| 11 | .3772 | .4294 | .439 | .5175 | .5658 | .4572 | .2427 |
| 12 | .4294 | .4108 | .4801 | .5281 | .503 | .3944 | .2402 |
| 13 | .4805 | .5228 | .463 | .5041 | .4481 | .4115 | .2987 |
| 14 | .4668 | .5228 | .4458 | .462 | .4481 | .3856 | .3206 |
| 15 | .4481 | .4854 | .4382 | .4207 | .4481 | .3688 | .2743 |
| 16 | .5281 | | .443 | .4715 | .4481 | .3521 | .2801 |
| 17 | .462 | .5415 | .5304 | .5041 | .4572 | .3772 | .3142 |
| 18 | .4527 | .5228 | .4784 | .5601 | .5228 | .3944 | .3921 |
| 19 | .6036 | .6348 | .5784 | .6602 | .567 | .3898 | .4854 |
| 20 | .5359 | .5601 | .5304 | .5975 | .5487 | .439 | .499 |
| 21 | .499 | .5228 | .4287 | .5121 | .5121 | | .4481 |
| 22 | .3961 | .3395 | .3258 | .4066 | .3841 | | .3018 |
| 23 | .2801 | .2241 | .2572 | .2957 | .2743 | .1341 | .2241 |
| 24 | .1715 | .2054 | .1867 | .1715 | .2427 | .1829 | .1372 |
| **Max** | **.6036** | **.6348** | **.5784** | **.6602** | **.5788** | **.5487** | **.499** |
| **Min** | **.1341** | **.1494** | **.1494** | **.1341** | **.1494** | **.1341** | **.1341** |
| **Avg** | **.3659** | **.3923** | **.3721** | **.3975** | **.4019** | **.3273** | **.2657** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**NIRA[050] BU 5878**
**Substation No/ Name :- 214418 / 33KV/22KV JEJURI SUBSTATION**
**Feeder No / Name : 301 / 22KV JEJURI(U) FEEDER SHEDDABLE URBAN**
**Feeder KV- 22 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7468 | .7468 | .6722 | .6722 | .7468 | .5601 | .5975 |
| 2 | .7468 | .6722 | .6722 | .6348 | .6722 | .3734 | .5975 |
| 3 | .7468 | .6722 | .7095 | .6722 | .6722 | .3734 | .5975 |
| 4 | .7842 | .7095 | .7095 | .7468 | .7468 | .5601 | .5975 |
| 5 | .9335 | .9335 | .6722 | .7842 | .8215 | .8215 | .5975 |
| 6 | 1.0829 | .9335 | .8589 | .8962 | 1.0456 | 1.2323 | .9335 |
| 7 | 1.2323 | 1.2323 | 1.1949 | 1.1949 | 1.1203 | 1.2323 | |
| 8 | 1.3443 | 1.2323 | 1.419 | 1.2696 | 1.419 | 1.2323 | 1.307 |
| 9 | 1.0829 | 1.1203 | 1.1949 | 1.1203 | 1.3443 | .9709 | 1.1203 |
| 10 | 1.0082 | 1.0829 | 1.1203 | 1.1949 | 1.2696 | .8962 | 1.0456 |
| 11 | 1.0829 | 1.0829 | 1.0829 | 1.1203 | 1.1949 | 1.0456 | 1.0829 |
| 12 | 1.0082 | .9709 | 1.0829 | 1.0456 | 1.1203 | | 1.0456 |
| 13 | 1.0082 | 1.0456 | 1.1576 | 1.1203 | 1.1949 | 1.1203 | 1.0082 |
| 14 | 1.0456 | 1.0082 | 1.1576 | 1.0456 | 1.1203 | 1.0082 | .9335 |
| 15 | .9709 | 1.0082 | 1.1203 | 1.1203 | 1.0456 | 1.0082 | .8962 |
| 16 | 1.0082 | 1.0082 | 1.0456 | 1.1203 | 1.0456 | .9709 | .8962 |
| 17 | 1.1203 | 1.0082 | 1.1576 | 1.1203 | 1.0456 | 1.0082 | .7842 |
| 18 | 1.1949 | 1.1576 | 1.2323 | 1.1949 | 1.1949 | 1.2696 | 1.1203 |
| 19 | 1.2696 | 1.3443 | 1.419 | 1.419 | 1.2696 | 1.2696 | 1.2696 |
| 20 | 1.2323 | 1.307 | 1.307 | 1.3443 | 1.2696 | 1.1576 | 1.2323 |
| 21 | 1.1576 | 1.1203 | 1.1576 | 1.1949 | 1.1203 | 1.0082 | 1.1576 |
| 22 | .9335 | | 1.0456 | 1.0456 | 1.0456 | .8589 | 1.0456 |
| 23 | .7842 | .8215 | .7842 | .9709 | .8589 | .7468 | .8215 |
| 24 | .7468 | .6722 | .6722 | .6722 | .8215 | .7468 | .6348 |
| **Max** | **1.3443** | **1.3443** | **1.419** | **1.419** | **1.419** | **1.2696** | **1.307** |
| **Min** | **.7468** | **.6722** | **.6722** | **.6348** | **.6722** | **.3734** | **.5975** |
| **Avg** | **1.0113** | **.9952** | **1.0269** | **1.0300** | **1.0502** | **.9335** | **.9271** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**NIRA[050]** **BU 5878**
**Substation No/ Name :- 214418 / 33KV/22KV JEJURI SUBSTATION**
**Feeder No / Name : 305 / 22KV NAZARE GFSS GAOTHAN FEEDER**
**Feeder KV- 22 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .381 | .381 | .381 | .381 | .4572 | .381 | .3429 |
| 2 | .381 | .381 | .4572 | .381 | .381 | .381 | .3048 |
| 3 | .4572 | .381 | .4572 | .4572 | .381 | .4572 | .3048 |
| 4 | .6097 | .5716 | .5335 | .4954 | .5335 | .5716 | .4572 |
| 5 | .6859 | .7621 | .5335 | .5716 | .6859 | .724 | .5716 |
| 6 | .8383 | .8002 | .7621 | .8383 | .8383 | .8764 | .8764 |
| 7 | .8764 | .9145 | .9907 | .9526 | .9145 | .9526 | .9907 |
| 8 | .9907 | .9145 | .9145 | .8764 | .9145 | .9526 | 1.0288 |
| 9 | | .9145 | .8764 | .8764 | .9526 | 1.0288 | .9526 |
| 10 | .8764 | .6478 | .9145 | .9907 | .9145 | .9907 | .9526 |
| 11 | .5335 | .6478 | .6859 | .9907 | .9145 | .9526 | .8383 |
| 12 | .8383 | .6097 | .724 | .8383 | .8002 | .8383 | .8383 |
| 13 | .7621 | .5716 | .6478 | .8383 | .6478 | .3429 | .6859 |
| 14 | .8383 | .6097 | .6478 | .7621 | .7621 | .8002 | .7621 |
| 15 | .8383 | .5335 | .724 | .7621 | .7621 | .8002 | .6859 |
| 16 | .8383 | .6097 | .8383 | .8383 | .8002 | .8383 | .6478 |
| 17 | .8383 | .6097 | .9145 | .6097 | .7621 | .8383 | .724 |
| 18 | .8383 | .6478 | .8383 | .7621 | .8002 | .8383 | .724 |
| 19 | .9526 | .7621 | .9907 | .9145 | .9145 | .8764 | .9145 |
| 20 | .9526 | .724 | .8383 | .7621 | .8383 | .8002 | .8002 |
| 21 | .8383 | .6478 | .7621 | .6859 | .7621 | .724 | .724 |
| 22 | .6097 | .4954 | .4954 | .6097 | .5716 | .5335 | .5716 |
| 23 | .5335 | .381 | .4572 | .5335 | .5335 | .4191 | .4954 |
| 24 | .381 | .4572 | .381 | .4191 | .4572 | .4191 | .3429 |
| **Max** | **.9907** | **.9145** | **.9907** | **.9907** | **.9526** | **1.0288** | **1.0288** |
| **Min** | **.381** | **.381** | **.381** | **.381** | **.381** | **.3429** | **.3048** |
| **Avg** | **.7256** | **.6240** | **.6986** | **.7145** | **.7208** | **.7224** | **.6891** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**NIRA[050] BU 5878**
**Substation No/ Name :- 214418 / 33KV/22KV JEJURI SUBSTATION**
**Feeder No / Name : 306 / 22KV WALHA GFSS GAOTHAN FEEDER**
**Feeder KV- 22 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3048 | .381 | .381 | .381 | .381 | .381 | .2667 |
| 2 | .381 | .381 | .4572 | .4191 | .381 | .381 | .2667 |
| 3 | .4572 | .381 | .5335 | .4572 | .381 | .4954 | .3048 |
| 4 | .6097 | .4572 | .5716 | .5335 | .4572 | .724 | .4191 |
| 5 | .6859 | .5716 | .6478 | .5716 | .6097 | .724 | .5716 |
| 6 | .8002 | .8764 | .8383 | .9145 | .8383 | .8383 | .8383 |
| 7 | .9145 | .9526 | 1.0288 | .9907 | .9145 | .9526 | .9526 |
| 8 | .7621 | .8383 | .6478 | .8764 | .9145 | .8764 | .8383 |
| 9 | .6859 | .4954 | .7621 | .724 | .6859 | .7621 | .7621 |
| 10 | .6859 | .4191 | .724 | .0686 | .9907 | .6859 | .5335 |
| 11 | .5716 | .6478 | .6859 | .6859 | | .6097 | .6478 |
| 12 | .4954 | .5335 | .6097 | .6859 | .6097 | .5335 | .6097 |
| 13 | .5335 | .4954 | .6478 | .6097 | .4954 | .4954 | .6478 |
| 14 | .5335 | .5335 | .5716 | .6097 | .5335 | .5716 | .5716 |
| 15 | .5335 | .4191 | .6478 | .6097 | .4954 | .5335 | .5335 |
| 16 | .5716 | .4954 | .6859 | .6097 | .5335 | .5335 | .6097 |
| 17 | .5716 | .5716 | .724 | .6097 | .6478 | .6097 | .6478 |
| 18 | | .724 | .8383 | .7621 | .724 | .7621 | .6478 |
| 19 | .9526 | .724 | .9145 | .9907 | .8764 | .7621 | .9145 |
| 20 | .9145 | .6859 | .8383 | .9145 | .8383 | .6859 | .8002 |
| 21 | .8002 | .6478 | .8002 | .8383 | .7621 | .5716 | .724 |
| 22 | .6478 | .5335 | .6478 | .6859 | .6097 | .4191 | .6097 |
| 23 | .4572 | .381 | .4572 | .5335 | .4954 | .3429 | .4954 |
| 24 | .3048 | .4954 | .381 | | .381 | .4572 | .3048 |
| **Max** | **.9526** | **.9526** | **1.0288** | **.9907** | **.9907** | **.9526** | **.9526** |
| **Min** | **.3048** | **.381** | **.381** | **.0686** | **.381** | **.3429** | **.2667** |
| **Avg** | **.6163** | **.5684** | **.6684** | **.6557** | **.6329** | **.6129** | **.6049** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**NIRA[050]** **BU 5878**
**Substation No/ Name :- 214471 / 33/11KV PARINCHE**
**Feeder No / Name : 201 / 11KV KALDARI AG** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6859 | .1029 | .0686 | .061 | .0857 | .5792 |
| 2 | .7716 | .12 | .0857 | .061 | .0857 | .6401 |
| 3 | .7716 | .1029 | .0857 | .061 | .1029 | .6401 |
| 4 | .7011 | .12 | .1029 | .0762 | .0857 | .7316 |
| 5 | .8535 | .12 | .1372 | .1067 | .1029 | .7621 |
| 6 | .9755 | .1543 | .1715 | .1524 | .1543 | .7926 |
| 7 | 1.3203 | .1715 | .1372 | .1372 | .1543 | .9755 |
| 8 | .1524 | .1029 | .12 | .1219 | .12 | .1372 |
| 9 | .0686 | 1.2346 | 1.2498 | 1.2803 | .0857 | .0857 |
| 10 | .0686 | 1.5242 | 1.4632 | 1.7071 | .0686 | .0686 |
| 11 | .0686 | 1.8861 | 1.6156 | 1.7071 | .0686 | .0514 |
| 12 | .0686 | 1.829 | 1.5546 | 1.6613 | .0514 | .0514 |
| 13 | .0686 | | 1.5242 | 1.6918 | .0343 | .0514 |
| 14 | .0686 | 1.5699 | 1.5546 | 1.5546 | .0343 | .0514 |
| 15 | .0686 | 1.5242 | 1.5699 | 1.5394 | .0343 | .0686 |
| 16 | .0686 | 1.5089 | 1.6156 | 1.5394 | | .0514 |
| 17 | .0686 | | .12 | .061 | .0857 | .0686 |
| 18 | .0686 | | .12 | .1067 | .0857 | .1029 |
| 19 | .0686 | | .1543 | .1219 | .1029 | .1372 |
| 20 | .0686 | | .1372 | .1372 | .1029 | .12 |
| 21 | .0514 | | .12 | .1067 | .0857 | .1029 |
| 22 | .0514 | | .1029 | .1067 | .0514 | |
| 23 | .0514 | | .0857 | .0914 | .0514 | .0857 |
| 24 | .7545 | .1029 | .0686 | .061 | .0857 | .5792 |
| **Max** | **1.3203** | **1.8861** | **1.6156** | **1.7071** | **.1543** | **.9755** |
| **Min** | **.0514** | **.1029** | **.0686** | **.061** | **.0343** | **.0514** |
| **Avg** | **.3318** | **.7609** | **.5819** | **.5938** | **.0835** | **.3015** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**NIRA[050] BU 5878**
**Substation No/ Name :- 214471 / 33/11KV PARINCHE**
**Feeder No / Name : 202 / 11 KV PARINCHE AG SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1372 | .2058 | .6001 | .4725 | .7202 | .1029 |
| 2 | .1372 | .2058 | .6859 | .503 | | .0686 |
| 3 | .1372 | .1715 | .7011 | .5487 | .9431 | .0686 |
| 4 | .1543 | .1543 | .7621 | .5487 | 1.0288 | .1029 |
| 5 | .1715 | .1886 | .823 | .5487 | .9945 | .1715 |
| 6 | .1715 | .2058 | .8535 | .9297 | .9088 | .2058 |
| 7 | .1715 | .2572 | 1.1888 | .9297 | 1.0631 | .1715 |
| 8 | .1543 | .1715 | .1886 | .1524 | 1.2003 | .1372 |
| 9 | 1.2803 | .1715 | .1543 | | 1.5089 | .8993 |
| 10 | 1.4937 | .1372 | .1543 | | 1.6118 | .9297 |
| 11 | 1.4937 | .1029 | .1543 | .1524 | | .9145 |
| 12 | 1.6766 | .0857 | .1029 | .1067 | 1.6804 | .6097 |
| 13 | 1.8861 | .0857 | .1029 | .061 | | .823 |
| 14 | 1.8861 | | .1029 | .1219 | 1.8861 | .7621 |
| 15 | 1.7147 | | .1029 | .1372 | 1.9547 | .7773 |
| 16 | 1.6804 | | .1029 | .1372 | 1.6766 | .7468 |
| 17 | .12 | | .1029 | | .0686 | .0914 |
| 18 | .1372 | | .1543 | .1981 | .0686 | .1372 |
| 19 | .1372 | | .1715 | .1677 | .1029 | .1715 |
| 20 | .1372 | | .1715 | .1829 | .1372 | .1715 |
| 21 | .1715 | | .1715 | .1677 | .1715 | .1543 |
| 22 | .1372 | | .1715 | .1524 | .1715 | .1372 |
| 23 | .1372 | | .1715 | .3658 | .1372 | .1372 |
| 24 | .1372 | .1715 | .4458 | .3963 | .4115 | .1372 |
| **Max** | **1.8861** | **.2572** | **1.1888** | **.9297** | **1.9547** | **.9297** |
| **Min** | **.12** | **.0857** | **.1029** | **.061** | **.0686** | **.0686** |
| **Avg** | **.6442** | **.1654** | **.3475** | **.3324** | **.8784** | **.3595** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**NIRA[050]** **BU 5878**
**Substation No/ Name :- 214471 / 33/11KV PARINCHE**
**Feeder No / Name : 203 / 11KV VEER AG** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0857 | .1029 | .884 | .8535 | .9945 | .0686 |
| 2 | .0857 | .1372 | .8535 | .9602 | .9945 | .0686 |
| 3 | .0857 | .12 | .9431 | .8535 | 1.0288 | .1029 |
| 4 | .0857 | .1029 | 1.0288 | .884 | 1.0117 | |
| 5 | .12 | .12 | .945 | .9145 | 1.0288 | .1372 |
| 6 | .12 | .1372 | .9755 | 1.0212 | 1.0802 | .1372 |
| 7 | .1219 | .1543 | 1.2041 | 1.1736 | 1.166 | .1372 |
| 8 | .12 | .1372 | .1029 | .0914 | .0857 | .1029 |
| 9 | 1.326 | .1029 | .0686 | .061 | 1.3375 | 1.0974 |
| 10 | 1.6766 | .0686 | .0514 | .061 | 1.6804 | 1.0364 |
| 11 | 1.7071 | .0686 | .0514 | .061 | 1.8861 | 1.2346 |
| 12 | 1.6766 | .0686 | .0514 | .061 | 1.8861 | 1.1126 |
| 13 | 1.6766 | .1029 | .0514 | | 1.8004 | 1.2803 |
| 14 | 1.8004 | | .0514 | .0457 | 1.749 | 1.2651 |
| 15 | 1.7833 | | .0514 | .061 | 1.6118 | 1.2498 |
| 16 | 1.7833 | | .0514 | .061 | 1.6804 | 1.2193 |
| 17 | .0514 | | .0514 | .061 | .0686 | .0686 |
| 18 | .0343 | | .1029 | .0762 | .1029 | .1029 |
| 19 | .1029 | | .1372 | .0914 | .1372 | .1029 |
| 20 | .1372 | | .1372 | .1067 | .1372 | .1029 |
| 21 | .1715 | | .12 | .1067 | .1029 | .12 |
| 22 | .1372 | | .1029 | .1067 | .1029 | .12 |
| 23 | .1029 | | .1029 | .0914 | .1029 | .1029 |
| 24 | .1029 | .1029 | .7926 | .8078 | .9602 | .0686 |
| **Max** | **1.8004** | **.1543** | **1.2041** | **1.1736** | **1.8861** | **1.2803** |
| **Min** | **.0343** | **.0686** | **.0514** | **.0457** | **.0686** | **.0686** |
| **Avg** | **.6290** | **.1090** | **.3714** | **.3744** | **.9474** | **.4800** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**NIRA[050]** **BU 5878**
**Substation No/ Name :- 214471 / 33/11KV PARINCHE**
**Feeder No / Name : 204 / 11KV VEER GFSS** **GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1543 | .2058 | .1715 | .1677 | .1715 | .1372 |
| 2 | .1543 | .1886 | .1715 | .1677 | .1715 | .1715 |
| 3 | .1543 | .1715 | .2058 | .1677 | .1715 | .2743 |
| 4 | .1886 | .2229 | .3429 | .1981 | .1886 | .3772 |
| 5 | .2915 | .2229 | .4458 | | .2915 | .4458 |
| 6 | .4287 | .4458 | .4801 | .3963 | .463 | .4115 |
| 7 | .4973 | .4973 | .5144 | .4572 | .5316 | .4458 |
| 8 | .381 | .4458 | .4287 | .3963 | .3772 | .4801 |
| 9 | .3601 | .3772 | .3772 | .3506 | .3772 | .3772 |
| 10 | .3429 | .3429 | .3258 | .3506 | .3429 | .3086 |
| 11 | .3086 | .3258 | .3086 | .3048 | .3086 | .3086 |
| 12 | .3086 | .3086 | .3086 | .3048 | .3086 | .2572 |
| 13 | .3086 | .3086 | .3086 | .2591 | .3086 | .2229 |
| 14 | .3086 | .2915 | .2915 | .2591 | .3086 | .2229 |
| 15 | .3086 | .3086 | .2915 | .2591 | .3258 | .2401 |
| 16 | .3086 | .2915 | .2915 | .2439 | .3429 | .2401 |
| 17 | .3429 | | .2915 | .2134 | .3429 | .2572 |
| 18 | .3772 | | .5144 | .3201 | .3429 | .3772 |
| 19 | .4115 | | .4458 | .3201 | .4115 | .463 |
| 20 | .3772 | | .3772 | .3353 | .3429 | .3772 |
| 21 | .3772 | | .3429 | .2743 | .3086 | .2915 |
| 22 | .3429 | | .2401 | .2134 | .2401 | .2229 |
| 23 | .2401 | | .1886 | .1677 | .2058 | .2058 |
| 24 | .1372 | .1715 | .1715 | .1677 | .1715 | .1715 |
| **Max** | **.4973** | **.4973** | **.5144** | **.4572** | **.5316** | **.4801** |
| **Min** | **.1372** | **.1715** | **.1715** | **.1677** | **.1715** | **.1372** |
| **Avg** | **.3088** | **.3016** | **.3265** | **.2737** | **.3065** | **.3036** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**NIRA[050] BU 5878**
**Substation No/ Name :- 214471 / 33/11KV PARINCHE**
**Feeder No / Name : 205 / 11KV KALDARI GFSS GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0514 | .0686 | .0514 | .0514 | .0686 | .0686 |
| 2 | .0514 | .0857 | .0686 | .0514 | .0686 | .0686 |
| 3 | .0514 | .1029 | .0686 | .0686 | .0686 | .1029 |
| 4 | .0514 | .0857 | .1715 | .0686 | .0686 | .1715 |
| 5 | .0857 | .12 | .2058 | .1372 | .1029 | .2058 |
| 6 | .2401 | .2572 | .2401 | .2401 | .2229 | .2572 |
| 7 | .2439 | .2743 | .2743 | .2743 | .2572 | |
| 8 | .1829 | .2229 | .2229 | .2401 | .2229 | .2401 |
| 9 | .1715 | .2229 | .2058 | .1543 | .1886 | .2058 |
| 10 | .1372 | .1715 | .1543 | .1543 | .1715 | .1715 |
| 11 | .1372 | .1543 | .1372 | .12 | .1715 | .1715 |
| 12 | | .12 | .1372 | .0857 | .0686 | .1029 |
| 13 | .1372 | .12 | .0686 | | .0514 | .0857 |
| 14 | .1029 | .1372 | .0686 | .1029 | .0686 | .0686 |
| 15 | .0686 | .0857 | .0686 | .1029 | .0686 | .0857 |
| 16 | .0686 | .0686 | .1029 | .0857 | | .1029 |
| 17 | .1029 | | .1029 | .1372 | .0686 | .1029 |
| 18 | .1372 | | .1715 | .2229 | .1372 | .2058 |
| 19 | .1372 | | .2229 | .1886 | .2401 | .2401 |
| 20 | .1715 | | .2058 | .2058 | .2058 | .2401 |
| 21 | .2058 | | .1886 | .1715 | .1715 | .1543 |
| 22 | .1715 | | .1029 | .12 | .1372 | .1029 |
| 23 | .1372 | | .0686 | .0857 | .1029 | .0857 |
| 24 | .0514 | .0686 | .0514 | .0514 | .0686 | .0686 |
| **Max** | **.2439** | **.2743** | **.2743** | **.2743** | **.2572** | **.2572** |
| **Min** | **.0514** | **.0686** | **.0514** | **.0514** | **.0514** | **.0686** |
| **Avg** | **.1259** | **.1392** | **.1400** | **.1357** | **.1305** | **.1439** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**NIRA[050]** **BU 5878**
**Substation No/ Name :- 214471 / 33/11KV PARINCHE**
**Feeder No / Name : 206 / 11KV PARINCHE GFSS** **GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0914 | .1372 | .1543 | .12 | .12 | .1715 |
| 2 | .1029 | .1372 | .1715 | .12 | .1372 | .1372 |
| 3 | .1029 | .1543 | .1715 | .12 | .12 | .1715 |
| 4 | .1029 | .1372 | .2058 | .1886 | .12 | .2058 |
| 5 | .1372 | .1543 | .2743 | .2401 | .1543 | .2743 |
| 6 | .2572 | .2572 | .3086 | .2915 | .2572 | .3086 |
| 7 | .3258 | .3086 | .3429 | .3258 | .3086 | .3086 |
| 8 | .4458 | .4458 | .5487 | .2058 | .4801 | .3086 |
| 9 | .3258 | .4801 | .5316 | .2229 | .3601 | .1715 |
| 10 | .3429 | .4115 | .5144 | | .2058 | .1715 |
| 11 | .3772 | .4458 | .2401 | .2229 | .1715 | .1715 |
| 12 | .3772 | .4801 | .2743 | .2229 | .1372 | .1372 |
| 13 | .3772 | .4458 | .4801 | .1715 | .1372 | .1372 |
| 14 | .4115 | | .3772 | .1715 | .1715 | .12 |
| 15 | | | .3601 | .1715 | .1715 | .12 |
| 16 | .4115 | | .4458 | .1543 | .1715 | .1372 |
| 17 | .5144 | | .3772 | .1543 | .1715 | .1372 |
| 18 | .5144 | | .4458 | .2572 | .1715 | .2401 |
| 19 | .5144 | | .3772 | .2572 | .2743 | .3086 |
| 20 | .4801 | | .3429 | .2743 | .3429 | .2743 |
| 21 | .4115 | | .2743 | .2401 | .3086 | .2401 |
| 22 | .3429 | | .2058 | .1715 | .2401 | .1886 |
| 23 | .2401 | | .1543 | .1372 | .2058 | .1543 |
| 24 | .0914 | .1372 | .1543 | .12 | .12 | .1715 |
| **Max** | **.5144** | **.4801** | **.5487** | **.3258** | **.4801** | **.3086** |
| **Min** | **.0914** | **.1372** | **.1543** | **.12** | **.12** | **.12** |
| **Avg** | **.3173** | **.2952** | **.3222** | **.1983** | **.2108** | **.1986** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**NIRA[050]** **BU 5878**
**Substation No/ Name :- 214471 / 33/11KV PARINCHE**
**Feeder No / Name : 207 / 11KV KAMBALWADI** **NON SHEDDABLE EXPRESS HV FEEDERS**
**Feeder KV- 11 / OUTGOING** **(CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 29-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0686 | .0686 | .12 | .0686 | .0857 | .0686 |
| 2 | .0686 | .0514 | .12 | .0686 | .0686 | .0686 |
| 3 | .1372 | .0686 | .12 | .0686 | .0686 | .0686 |
| 4 | .1372 | .0686 | .12 | .0686 | .0686 | .0686 |
| 5 | .0686 | .12 | .12 | .0686 | .0857 | .0686 |
| 6 | .0686 | .12 | .12 | .0686 | .0686 | .0686 |
| 7 | .0686 | .12 | .12 | .0686 | .0857 | .0686 |
| 8 | .0686 | .12 | .12 | .0686 | .0686 | .0686 |
| 9 | .0686 | .1372 | .12 | .0686 | .0686 | .0686 |
| 10 | .0686 | .12 | .0686 | .0686 | .0686 | .0686 |
| 11 | .0686 | .0514 | .0686 | | .0686 | .0686 |
| 12 | .0686 | .0171 | .1372 | .0686 | .0686 | .0686 |
| 13 | .0686 | .0514 | .0686 | .0686 | .0686 | .0686 |
| 14 | .0686 | | .1372 | .0686 | .0686 | .0514 |
| 15 | .0686 | | .1372 | .0686 | .0686 | .0686 |
| 16 | .0686 | | .1372 | .0686 | .0686 | .0686 |
| 17 | .0686 | | .0171 | .0686 | .0171 | .0686 |
| 18 | .0686 | | .0191 | .0514 | .0171 | .0686 |
| 19 | .0686 | | .0191 | .0514 | .0686 | .0686 |
| 20 | .0686 | | .0686 | | .0686 | .0514 |
| 21 | .0686 | | .0686 | .0686 | .0686 | .0686 |
| 22 | .0686 | | .0686 | .0686 | .0686 | .0686 |
| 23 | .0686 | | .0514 | .0686 | .0686 | .0686 |
| 24 | .061 | .0514 | .12 | .0514 | .0686 | .0686 |
| **Max** | **.1372** | **.1372** | **.1372** | **.0686** | **.0857** | **.0686** |
| **Min** | **.061** | **.0171** | **.0171** | **.0514** | **.0171** | **.0514** |
| **Avg** | **.074** | **.0833** | **.0945** | **.0663** | **.0664** | **.0672** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**NIRA[050]** **BU 5878**
**Substation No/ Name :- 214471 / 33/11KV PARINCHE**
**Feeder No / Name : 209 / 11KV TONDAL AG** **FEEDER SEPERATION/PURE AG**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5658 | .0514 | .0343 | .0305 | .0343 | .4572 |
| 2 | .5658 | .0343 | .0343 | .0305 | .0343 | .4268 |
| 3 | .503 | .0343 | .0343 | .0305 | .0514 | .4268 |
| 4 | .583 | .0343 | .0514 | .0457 | .0343 | .5144 |
| 5 | .5182 | .0343 | .0686 | .061 | .0343 | .5487 |
| 6 | .6687 | .0514 | .0857 | .0762 | .0686 | .6097 |
| 7 | .7202 | .0857 | .1029 | .0762 | .0857 | .7316 |
| 8 | .0686 | .0514 | .0857 | .0762 | .0857 | .0514 |
| 9 | .0343 | 1.0059 | 1.2689 | .9335 | .0343 | .0514 |
| 10 | .0343 | 1.3032 | 1.1584 | .3067 | .0343 | .0514 |
| 11 | .0343 | 1.3203 | 1.3108 | 1.0269 | .0343 | .0686 |
| 12 | .0171 | 1.2041 | 1.2803 | .9335 | | .0171 |
| 13 | .0343 | 1.2651 | 1.2498 | 1.0802 | | .0343 |
| 14 | .0171 | 1.326 | 1.2498 | 1.0822 | .0514 | .0171 |
| 15 | .0343 | 1.2193 | 1.2193 | 1.0669 | .0343 | .0171 |
| 16 | .0343 | 1.3375 | 1.2193 | 1.0974 | .0514 | .0343 |
| 17 | .0343 | | .0514 | .0457 | .0514 | .0514 |
| 18 | .0343 | | .0514 | .0457 | .0514 | .0514 |
| 19 | .0343 | | .0686 | .0457 | .0686 | .0686 |
| 20 | .0343 | | .0686 | .0457 | .0857 | .0686 |
| 21 | .0514 | | .0514 | .0457 | .0514 | .0686 |
| 22 | .0686 | | .0514 | .0457 | .0514 | .0514 |
| 23 | .0514 | | .0343 | .0305 | .0343 | .0514 |
| 24 | .5487 | .0343 | .0343 | .0305 | .0343 | .4572 |
| **Max** | **.7202** | **1.3375** | **1.3108** | **1.0974** | **.0857** | **.7316** |
| **Min** | **.0171** | **.0343** | **.0343** | **.0305** | **.0343** | **.0171** |
| **Avg** | **.2204** | **.6113** | **.4527** | **.3454** | **.0499** | **.2053** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**NIRA[050] BU 5878**
**Substation No/ Name :- 214517 / 33/11NAZARE SUB-STATION**
**Feeder No / Name : 201 / 11KV PANDESHWAR GFSS GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0146 | .1646 | .1663 | .1663 | .168 | .168 | .1448 |
| 2 | .1463 | .1848 | .1848 | .1829 | .1698 | .1478 | .1646 |
| 3 | .1326 | .2054 | .1867 | .2033 | .1848 | .1478 | .1663 |
| 4 | .1646 | .2587 | .2614 | .2427 | .2378 | .168 | .1867 |
| 5 | .1848 | .3921 | .3772 | .3584 | .3511 | .2801 | .2715 |
| 6 | .4668 | .6413 | .5847 | .5847 | .5658 | .547 | .5415 |
| 7 | .6036 | .5847 | .5609 | .6036 | .5959 | .6224 | .6224 |
| 8 | .4527 | .4668 | .4854 | .4294 | .5041 | .4904 | .499 |
| 9 | .3547 | .3292 | .3511 | .3142 | .3841 | .3292 | .3439 |
| 10 | .2534 | .2353 | .2658 | .2172 | .2378 | .2658 | .1829 |
| 11 | .197 | .2172 | .1991 | .2012 | .1949 | .2149 | .1829 |
| 12 | .1254 | .2241 | .1772 | .1387 | .1772 | .1772 | .1848 |
| 13 | .1267 | .168 | .1433 | .1448 | .1578 | .1612 | .1829 |
| 14 | .1109 | .1595 | .1612 | .168 | .1372 | .1595 | .1848 |
| 15 | .1463 | .1612 | .1612 | .1867 | .1387 | .1791 | .1478 |
| 16 | .1463 | .1578 | .1949 | .1865 | .1578 | .1907 | .1829 |
| 17 | .124 | .2054 | .2303 | | | .2058 | .2801 |
| 18 | .3109 | .2926 | .3475 | | .2926 | .3361 | .3734 |
| 19 | .4668 | .462 | .5175 | .5359 | .5415 | .5041 | .4108 |
| 20 | .4294 | .4481 | .4251 | .4668 | .3961 | .4805 | .4294 |
| 21 | .3326 | .3547 | .3326 | .3258 | .3395 | .3841 | .3361 |
| 22 | .2033 | .2402 | .2195 | .2172 | .2614 | .2427 | .2427 |
| 23 | .2241 | .2054 | .1829 | .1867 | .1663 | .1867 | .1867 |
| 24 | .1478 | .1663 | .1646 | .1663 | .1698 | .168 | .1494 |
| **Max** | **.6036** | **.6413** | **.5847** | **.6036** | **.5959** | **.6224** | **.6224** |
| **Min** | **.0146** | **.1578** | **.1433** | **.1387** | **.1372** | **.1478** | **.1448** |
| **Avg** | **.2444** | **.2886** | **.2867** | **.2831** | **.2839** | **.2815** | **.2749** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**NIRA[050] BU 5878**
**Substation No/ Name :- 214517 / 33/11NAZARE SUB-STATION**
**Feeder No / Name : 202 / 11KV PANDESHWAR AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2006 | .2343 | .0934 | .0924 | .1132 | .208 | .2241 |
| 2 | .2006 | .2846 | .0943 | .112 | .0924 | .2267 | .2105 |
| 3 | .2056 | .3241 | .1109 | .1307 | .0934 | .2294 | .2294 |
| 4 | .2241 | .4001 | .1097 | .1509 | .132 | .2458 | .2321 |
| 5 | .3077 | .4534 | .1848 | .2075 | .2241 | .3149 | .3239 |
| 6 | .5735 | .57 | .2452 | .2801 | .3206 | .4641 | .4744 |
| 7 | .7293 | .7459 | .3206 | .3395 | .3547 | .5898 | .6958 |
| 8 | .2452 | .2263 | .2452 | .2829 | .2987 | .2641 | .2614 |
| 9 | .1886 | .1307 | .6722 | .7522 | .7116 | .2075 | .168 |
| 10 | .1307 | .0934 | .8223 | .9442 | .9442 | .1294 | .1494 |
| 11 | .112 | .0739 | .8642 | 1.0595 | .9602 | .1109 | .128 |
| 12 | .0747 | .0747 | 1.0688 | .9014 | 1.0688 | .0747 | .1478 |
| 13 | .0924 | .1052 | .8065 | .8855 | .9842 | .0934 | .1463 |
| 14 | .112 | .1086 | .9282 | .9374 | .9488 | .0924 | .1478 |
| 15 | .0924 | .0934 | .9717 | 1.0562 | .8749 | .1097 | .128 |
| 16 | .1109 | .112 | .9762 | .9145 | .7968 | .1109 | .1307 |
| 17 | .1109 | .0934 | .112 | | .1267 | .1448 | .128 |
| 18 | .1886 | .1629 | .168 | | .1829 | .2241 | .1478 |
| 19 | .2427 | .2641 | .2614 | .3018 | .2641 | .2534 | .1494 |
| 20 | .2075 | .2241 | .2241 | .3361 | .2263 | .2172 | .1848 |
| 21 | .1509 | .1595 | .168 | .2241 | .1886 | .1829 | .1494 |
| 22 | .0934 | .112 | .1307 | .1494 | .1307 | .1494 | .0934 |
| 23 | .0924 | .112 | .112 | .1494 | .112 | .1086 | .0934 |
| 24 | .2006 | .208 | .0924 | .0924 | .112 | .2056 | |
| **Max** | **.7293** | **.7459** | **1.0688** | **1.0595** | **1.0688** | **.5898** | **.6958** |
| **Min** | **.0747** | **.0739** | **.0924** | **.0924** | **.0924** | **.0747** | **.0934** |
| **Avg** | **.2036** | **.2236** | **.4076** | **.4682** | **.4276** | **.2066** | **.2063** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**NIRA[050] BU 5878**
**Substation No/ Name :- 214517 / 33/11NAZARE SUB-STATION**
**Feeder No / Name : 203 / 11KV KOTHALE AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3353 | .4111 | .2149 | .2012 | .1867 | .602 | .5624 |
| 2 | .3201 | .442 | .181 | .2218 | .2075 | .6401 | .6401 |
| 3 | .3241 | .4843 | .1829 | .2195 | .2033 | .6706 | .6478 |
| 4 | .3437 | .5693 | .1848 | .2587 | .2195 | .7099 | .6962 |
| 5 | .3906 | .6481 | .2402 | .2801 | .2772 | .7562 | .7449 |
| 6 | .5535 | .7773 | .3326 | .3326 | .3547 | .8124 | .7811 |
| 7 | .9122 | 1.0623 | .4024 | .4108 | .3921 | 1.1043 | 1.1069 |
| 8 | .3292 | .2715 | .3921 | .3142 | .3921 | .2926 | .3174 |
| 9 | .2561 | .2658 | 1.3245 | 1.3904 | 1.3735 | .2587 | .2614 |
| 10 | .1791 | .2378 | 1.821 | 2.0005 | 1.8084 | .2587 | .2801 |
| 11 | .2172 | .2587 | 2.0424 | 2.2024 | 2.0325 | .2561 | .2743 |
| 12 | .1612 | .2427 | 2.0557 | 2.3805 | 2.1538 | .2772 | .2743 |
| 13 | .1629 | .2715 | 2.0216 | 2.3365 | 2.0965 | .2561 | .2715 |
| 14 | .181 | .2957 | 2.1373 | 2.2497 | 2.0399 | .2378 | .2195 |
| 15 | .1829 | .3326 | 2.1862 | 2.2725 | 1.8903 | .2587 | .2195 |
| 16 | .2033 | .3142 | 2.1125 | 2.1664 | 1.8185 | .2987 | .1867 |
| 17 | .2103 | .3109 | .2172 | | .2454 | .2772 | .1848 |
| 18 | .2195 | .2865 | .2561 | | .2772 | .2801 | .1867 |
| 19 | .2587 | .3109 | .2896 | .2896 | .2987 | .2987 | .2218 |
| 20 | .2587 | .3045 | .3045 | .2801 | .2772 | .2715 | .2743 |
| 21 | .2172 | .2715 | .2715 | .2534 | .2561 | .2507 | .2012 |
| 22 | .1949 | .2328 | .2378 | .2328 | .2353 | .2126 | .1829 |
| 23 | .1629 | .2303 | .2303 | .2241 | .2149 | .2012 | .181 |
| 24 | .3353 | .3858 | .2103 | .2149 | .2075 | .587 | .5533 |
| **Max** | **.9122** | **1.0623** | **2.1862** | **2.3805** | **2.1538** | **1.1043** | **1.1069** |
| **Min** | **.1612** | **.2303** | **.181** | **.2012** | **.1867** | **.2012** | **.181** |
| **Avg** | **.2879** | **.3841** | **.8271** | **.9424** | **.8108** | **.4195** | **.3946** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**NIRA[050] BU 5878**
**Substation No/ Name :- 214517 / 33/11NAZARE SUB-STATION**
**Feeder No / Name : 204 / 11KV NAZARE AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2709 | .2778 | .0934 | .1097 | .112 | .3763 | .3437 |
| 2 | .2709 | .3048 | .0924 | .1294 | .1267 | .3963 | .3841 |
| 3 | .2743 | .3479 | .1097 | .1494 | .1463 | .4115 | .4534 |
| 4 | .3086 | .3841 | .1267 | .1478 | .1478 | .4321 | .4744 |
| 5 | .3437 | .381 | .1867 | .1867 | .1867 | .463 | .4999 |
| 6 | .4744 | .4687 | .2241 | .2427 | .2587 | .5312 | .578 |
| 7 | .6722 | .6642 | .2353 | .2801 | .2561 | .7099 | .6483 |
| 8 | .2241 | .1663 | .2402 | .2033 | .2378 | .2054 | .2172 |
| 9 | .1663 | .1646 | .7407 | .9646 | .8488 | .1663 | .2012 |
| 10 | .1463 | .1646 | .8916 | 1.1873 | 1.078 | .128 | .1463 |
| 11 | .128 | .1448 | .9633 | 1.2498 | 1.0957 | .1267 | .1086 |
| 12 | .128 | .1307 | 1.0517 | 1.034 | 1.1248 | .1267 | .128 |
| 13 | .1075 | .1267 | .9145 | 1.1888 | 1.0957 | .1097 | .1097 |
| 14 | .1214 | .1494 | 1.0517 | 1.2342 | 1.0822 | .1086 | .1109 |
| 15 | .1227 | .1463 | 1.2342 | 1.2346 | 1.0623 | .128 | .1097 |
| 16 | .1417 | .1267 | 1.1883 | 1.0974 | 1.0562 | .1267 | .1294 |
| 17 | .1227 | .1254 | .1075 | | | .1075 | .128 |
| 18 | .1478 | .1433 | .1646 | | .1478 | .1478 | .1478 |
| 19 | .1867 | .1848 | .2033 | .2033 | .1867 | .1867 | .1478 |
| 20 | .1612 | .1463 | .1663 | .2241 | .168 | .2241 | .1848 |
| 21 | .1463 | .1267 | .1463 | .181 | .1494 | .181 | .1494 |
| 22 | .1086 | .1267 | .1294 | .1448 | .1494 | .1254 | .128 |
| 23 | .1097 | .1086 | .1267 | .1307 | .1294 | .1029 | .1463 |
| 24 | .2526 | .2812 | .1075 | .1097 | .1132 | .3612 | .3125 |
| **Max** | **.6722** | **.6642** | **1.2342** | **1.2498** | **1.1248** | **.7099** | **.6483** |
| **Min** | **.1075** | **.1086** | **.0924** | **.1097** | **.112** | **.1029** | **.1086** |
| **Avg** | **.2140** | **.2247** | **.4373** | **.5288** | **.4765** | **.2493** | **.2495** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**NIRA[050] BU 5878**
**Substation No/ Name :- 214520 / 33/22 KV NIRA SUBSTATION**
**Feeder No / Name : 301 / 22 KV NIRA U GFSS GAOTHAN FEEDER**
**Feeder KV- 22 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3772 | .3734 | .3018 | .3361 | .3361 | .3734 | .3395 |
| 2 | .3772 | .3361 | | .3361 | .3361 | .3734 | .3395 |
| 3 | .4527 | .3361 | .3772 | .3361 | .3361 | .3734 | .3772 |
| 4 | .5281 | .3361 | .4527 | .3734 | .4481 | .4108 | .4527 |
| 5 | .6036 | .3734 | .5228 | .5228 | .5601 | .5228 | .5228 |
| 6 | .6722 | .5601 | .5975 | .5975 | .6348 | .6722 | .6722 |
| 7 | .8501 | .7842 | .8501 | .8215 | .8962 | .8962 | .8871 |
| 8 | .8131 | .7095 | .8501 | .8962 | .8589 | .8215 | .8131 |
| 9 | .7468 | .5975 | .7468 | .7842 | .7468 | .7392 | .6722 |
| 10 | .7468 | .5601 | .6348 | .7392 | .7468 | .6283 | .6348 |
| 11 | .6348 | .5975 | .6348 | .6283 | .6348 | .6283 | .5975 |
| 12 | .6348 | .5975 | .6348 | .6348 | .5975 | .6283 | .6348 |
| 13 | .5975 | .6348 | .6348 | .6348 | | .5914 | .5601 |
| 14 | .5975 | .5975 | .5975 | .5601 | .5601 | .5544 | .4854 |
| 15 | .5601 | .4854 | .5601 | .5975 | .5228 | .5914 | .5975 |
| 16 | .5975 | .5975 | .5975 | .6283 | .5228 | .5914 | .5975 |
| 17 | .5975 | .5601 | .6722 | .7023 | .5601 | .6283 | .6348 |
| 18 | .7095 | .6348 | .7842 | .7842 | .6348 | .6653 | .7468 |
| 19 | .7468 | .7762 | .8589 | .7842 | .7095 | .7392 | .7842 |
| 20 | .7095 | .6653 | .7468 | .7468 | .7468 | .7392 | .7468 |
| 21 | .6348 | .6653 | .6722 | .6722 | .6722 | .6722 | .6722 |
| 22 | .5601 | .5975 | .6348 | .5975 | .5975 | .5975 | .6348 |
| 23 | .4854 | .5228 | .4854 | .4481 | .5601 | .4481 | .5228 |
| 24 | .4527 | .4481 | .5228 | .3734 | .3734 | | .3772 |
| **Max** | **.8501** | **.7842** | **.8589** | **.8962** | **.8962** | **.8962** | **.8871** |
| **Min** | **.3772** | **.3361** | **.3018** | **.3361** | **.3361** | **.3734** | **.3395** |
| **Avg** | **.6119** | **.5561** | **.6248** | **.6057** | **.5910** | **.6037** | **.5960** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**NIRA[050] BU 5878**
**Substation No/ Name :- 214520 / 33/22 KV NIRA SUBSTATION**
**Feeder No / Name : 302 / 22KV RAKH GAONTHAN GAOTHAN FEEDER**
**Feeder KV- 22 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4 | | | | | .4108 | | |
| 5 | .2987 | .2987 | .2987 | .2987 | .4854 | .3734 | .2987 |
| 6 | .3734 | .3734 | .4108 | .4108 | .5601 | .4481 | .3734 |
| 7 | .5175 | .5601 | .4805 | .5228 | | .5601 | .4805 |
| 8 | .4066 | .4108 | .3696 | .4854 | .4481 | .2957 | .4066 |
| 9 | .3361 | .3361 | .2987 | .4854 | .3734 | .2957 | .4481 |
| 10 | .4854 | .3734 | .3361 | .4854 | .2987 | .2957 | .4481 |
| 11 | .2987 | .2987 | .4481 | .4481 | | | .3734 |
| 12 | .1867 | .2614 | .4066 | .3361 | .4481 | | .4108 |
| 13 | .1867 | .2218 | .2614 | .2987 | | | |
| 14 | .1867 | .2241 | .2987 | .1867 | | | |
| 15 | .1867 | .2987 | .3734 | .4066 | | | |
| 16 | .1867 | .2987 | .3696 | .4066 | | | .2987 |
| 17 | .2241 | .2957 | .2987 | .4435 | .3734 | | .3361 |
| 18 | .4435 | .4108 | .6722 | .5975 | .4108 | .2957 | .3734 |
| 19 | .4481 | .4435 | .4854 | .4108 | .4481 | .3326 | .3734 |
| 20 | .4108 | .3696 | .4108 | .3361 | .4108 | .2987 | .3361 |
| 21 | .3361 | .2957 | .3734 | .2987 | .3361 | .2987 | .2987 |
| 22 | | | .2987 | | .2987 | | |
| 24 | | | .2218 | | | | |
| **Max** | **.5175** | **.5601** | **.6722** | **.5975** | **.5601** | **.5601** | **.4805** |
| **Min** | **.1867** | **.2218** | **.2218** | **.1867** | **.2987** | **.2957** | **.2987** |
| **Avg** | **.3243** | **.3395** | **.3744** | **.4034** | **.4079** | **.3494** | **.3754** |

 Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**NIRA[050]** **BU 5878**
**Substation No/ Name :- 214520 / 33/22 KV NIRA SUBSTATION**
**Feeder No / Name : 303 / 22KV NIRA (U) AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3429 | .3353 | .4024 | 2.4813 | 2.5194 | 2.2466 | .407 |
| 2 | .3429 | .3353 | .407 | 2.5484 | 2.726 | 2.2801 | .407 |
| 3 | .407 | .3353 | .407 | 2.6155 | 2.3868 | 2.3472 | .4694 |
| 4 | .4694 | .3353 | .4694 | | 2.5526 | 2.5149 | .5365 |
| 5 | .5365 | .4024 | .5365 | 2.8166 | 2.7515 | 2.6155 | .57 |
| 6 | .57 | .5365 | .5365 | 3.219 | 3.1493 | 2.8502 | .57 |
| 7 | .57 | .57 | .503 | 3.722 | 3.6466 | 3.0849 | .57 |
| 8 | .503 | .4694 | .4694 | .4428 | .3978 | .4024 | .4694 |
| 9 | 3.152 | 3.4202 | .4435 | .3688 | .4024 | 3.3288 | 3.5471 |
| 10 | 3.9567 | 4.292 | .3688 | .394 | .4024 | 3.8089 | 3.8455 |
| 11 | 4.0908 | 4.6609 | .4066 | | .4024 | 4.2379 | 4.0444 |
| 12 | 4.225 | 4.5268 | .3353 | | .3688 | 4.2379 | 3.9118 |
| 13 | 4.225 | 4.6609 | .3353 | .4656 | .3688 | 4.2696 | 3.8786 |
| 14 | 4.0573 | 4.3256 | .2957 | | .3688 | 4.2696 | 3.746 |
| 15 | 4.0573 | 4.292 | .3696 | .4298 | .3353 | 4.1747 | 3.7129 |
| 16 | 3.9903 | 3.8897 | .3582 | | .3353 | 3.7635 | 3.514 |
| 17 | .2987 | .3353 | .3353 | .4805 | .3353 | .3018 | .3315 |
| 18 | .4435 | .4854 | .4359 | .5373 | .3688 | .3688 | .3978 |
| 19 | .4694 | .5365 | .503 | .5636 | .4694 | .57 | .5304 |
| 20 | .4359 | .5365 | .503 | .4973 | .4694 | .5365 | .4973 |
| 21 | .4024 | .503 | .4694 | .4641 | .4359 | .4694 | .5304 |
| 22 | .3688 | .4694 | .4359 | .431 | .4024 | .4359 | .431 |
| 23 | .3688 | .4694 | .3688 | .431 | .4024 | .4359 | .431 |
| 24 | .407 | .3353 | .4359 | 2.4813 | 2.4863 | 2.2131 | .407 |
| **Max** | **4.225** | **4.6609** | **.5365** | **3.722** | **3.6466** | **4.2696** | **4.0444** |
| **Min** | **.2987** | **.3353** | **.2957** | **.3688** | **.3353** | **.3018** | **.3315** |
| **Avg** | **1.6121** | **1.7108** | **.4221** | **1.3363** | **1.1868** | **2.3235** | **1.5732** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**NIRA[050] BU 5878**
**Substation No/ Name :- 214520 / 33/22 KV NIRA SUBSTATION**
**Feeder No / Name : 304 / 22 KV Mandki Bhairavanth**
**Expre Feeder KV- 22 / OUTGOING**

| DATE | 29-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7011 | | .7011 | .6661 | .6661 | |
| 2 | .7011 | | .7011 | | .6661 | |
| 3 | .7011 | | .7011 | .6661 | .6661 | |
| 4 | .7011 | | .7011 | .7011 | .6661 | |
| 5 | .7362 | | .7011 | .7011 | .6661 | |
| 6 | .7282 | | .7011 | .7011 | .6661 | |
| 7 | .7282 | | .7362 | .7362 | .6661 | .6661 |
| 8 | .7282 | | .7362 | .7011 | .631 | .6661 |
| 9 | .7628 | .1494 | .7362 | .7362 | .6661 | .6661 |
| 10 | .7762 | .1478 | .7282 | .7362 | .6661 | .7011 |
| 11 | .7282 | .112 | .7762 | .7362 | .6661 | .7011 |
| 12 | .7282 | .6241 | .7762 | .7362 | .6661 | .7362 |
| 13 | .7282 | .7362 | .7842 | .7362 | .6661 | .7011 |
| 14 | .6588 | .7362 | .7282 | .7362 | .6661 | .7011 |
| 23 | | .7011 | .7011 | .6661 | | |
| 24 | .7011 | | .7011 | .7011 | .6661 | |
| **Max** | **.7762** | **.7362** | **.7842** | **.7362** | **.6661** | **.7362** |
| **Min** | **.6588** | **.112** | **.7011** | **.6661** | **.631** | **.6661** |
| **Avg** | **.7206** | **.4581** | **.7257** | **.7105** | **.6638** | **.6924** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**NIRA[050] BU 5878**
**Substation No/ Name :- 214520 / 33/22 KV NIRA SUBSTATION**
**Feeder No / Name : 307 / 22KV THOPATEWADI GAONTHAN GAOTHAN FEEDER**
**Feeder KV- 22 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 5 | | | | | .2987 | | |
| 6 | .2987 | .2987 | | .2987 | .3361 | .2987 | .2987 |
| 7 | .3361 | .3361 | .2987 | .3734 | .4108 | .3361 | .3361 |
| 8 | .3734 | .3361 | .3326 | .3734 | .4108 | .2987 | .2926 |
| 9 | .2587 | .2987 | .2987 | .2987 | .4854 | | .3361 |
| 10 | .2987 | .1478 | .2614 | .4435 | .3361 | .3326 | |
| 11 | .2241 | .4435 | .4481 | .3326 | .3361 | .3326 | .3734 |
| 12 | .2957 | .2987 | .3696 | .4108 | .4108 | .3292 | |
| 13 | .2987 | .2957 | .3361 | .4805 | .5281 | .3292 | |
| 14 | .2614 | | .4066 | .4066 | .4481 | .3326 | .2987 |
| 15 | .2241 | .2218 | .2987 | .4435 | .3361 | | |
| 16 | .1867 | .2987 | .4108 | .3326 | .4108 | .3696 | .3361 |
| 17 | .2587 | .2957 | .1848 | .3696 | | | |
| 18 | .1867 | .2987 | .2987 | .2957 | | | |
| 19 | .2987 | .2926 | .2987 | .3361 | | | |
| 20 | .2987 | .2926 | .2987 | .2987 | | | |
| 21 | | | .2987 | .2987 | | | |
| **Max** | **.3734** | **.4435** | **.4481** | **.4805** | **.5281** | **.3696** | **.3734** |
| **Min** | **.1867** | **.1478** | **.1848** | **.2957** | **.2987** | **.2987** | **.2926** |
| **Avg** | **.2733** | **.2968** | **.3227** | **.3621** | **.3957** | **.3288** | **.3245** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SASWAD[047] BU 5801**
**Substation No/ Name :- 214424 / 33 KV SASWAD**
**Feeder No / Name : 301 / 22 KV PURANDAR AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0754 | .1132 | .1341 | .3201 | .3201 | .2591 | .1132 |
| 2 | .0754 | .1132 | .1341 | .2591 | .2561 | .2622 | .0754 |
| 3 | .0754 | .1132 | .1341 | .2591 | .2561 | .3277 | .0377 |
| 4 | .0754 | .1132 | .1341 | .3201 | .3521 | .3201 | .0377 |
| 5 | .1509 | .1132 | .1341 | .4481 | .4481 | .3201 | .0754 |
| 6 | .1509 | .1509 | .1341 | .506 | .5121 | .4687 | .1132 |
| 7 | .1509 | .1867 | .1677 | .6958 | .6325 | .5247 | .1132 |
| 8 | .112 | .1494 | .1677 | .1677 | .1677 | .1658 | .1029 |
| 9 | .4744 | .4481 | .1494 | .1494 | .112 | .6859 | .3563 |
| 10 | .6958 | .6642 | | .1494 | .112 | .8048 | .3563 |
| 11 | .759 | .8223 | | .112 | .1494 | .8619 | .4801 |
| 12 | .8539 | .8749 | | .0747 | .112 | .9945 | .4161 |
| 13 | .8855 | .5761 | | .1494 | .1494 | .9175 | .5121 |
| 14 | .8855 | | | .1494 | .112 | .9717 | .4161 |
| 15 | .2321 | .1677 | .0747 | .1494 | .112 | .9831 | .3932 |
| 16 | .8192 | .1867 | | .0995 | .0747 | .9175 | .3563 |
| 17 | .112 | .1494 | .0747 | .1006 | .4481 | .0747 | .0747 |
| 18 | .1132 | .1509 | .0754 | .1006 | .1311 | .0671 | .0671 |
| 19 | .1132 | .1132 | .1132 | .1372 | .1341 | | .0671 |
| 20 | .1132 | .1132 | .1006 | .1006 | .1006 | .1029 | .0671 |
| 21 | .1132 | .1132 | .1006 | .1006 | .1311 | .0671 | .1326 |
| 22 | .1132 | .1006 | .1341 | .1006 | .0754 | .0754 | .0754 |
| 23 | .1132 | .1006 | .1341 | .1341 | .0754 | .0754 | .0754 |
| 24 | .1132 | .1132 | .1341 | .3201 | .3201 | .2915 | .0754 |
| **Max** | **.8855** | **.8749** | **.1677** | **.6958** | **.6325** | **.9945** | **.5121** |
| **Min** | **.0754** | **.1006** | **.0747** | **.0747** | **.0747** | **.0671** | **.0377** |
| **Avg** | **.3073** | **.2499** | **.1239** | **.2127** | **.2206** | **.4582** | **.1913** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SASWAD[047]** **BU 5801**
**Substation No/ Name :- 214424 / 33 KV SASWAD**
**Feeder No / Name : 302 / 22 KV SHIVARI AG** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 22 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2641 | .3018 | .2401 | 1.0242 | 1.0688 | .9831 | .2263 |
| 2 | .2641 | .2641 | .2401 | .9602 | .9717 | .9831 | .2263 |
| 3 | .3018 | .2641 | .2743 | .9602 | .9069 | 1.1469 | .2263 |
| 4 | .3018 | .3772 | .3429 | 1.2163 | 1.1984 | 1.1469 | .3018 |
| 5 | .3772 | .4481 | .3772 | 1.6004 | 1.4251 | 1.2955 | .3772 |
| 6 | .5658 | .5601 | .5144 | 1.9608 | 1.7924 | 1.6194 | .5258 |
| 7 | .6722 | .7095 | .6859 | 2.5309 | 2.6749 | 2.1052 | .631 |
| 8 | .5601 | .5228 | | .7888 | .7888 | .8669 | .4207 |
| 9 | 2.0805 | 1.9524 | .4527 | .6348 | .5601 | 2.2786 | 1.2308 |
| 10 | 2.6246 | 2.2497 | | .5601 | .4108 | 2.713 | 1.6324 |
| 11 | 2.9264 | 2.7435 | | .5601 | .4108 | 2.3868 | 1.6004 |
| 12 | 3.0178 | 2.9264 | | .4481 | .3734 | 2.7854 | 1.4723 |
| 13 | 3.0483 | 1.9204 | | .5228 | .5228 | 2.8182 | 1.5364 |
| 14 | 2.8959 | | | .4854 | .4108 | 2.6216 | 1.3443 |
| 15 | .9831 | .5144 | .3361 | .4481 | .4854 | 2.5911 | 1.2803 |
| 16 | 2.6558 | .4481 | | .3647 | | 2.4615 | 1.2452 |
| 17 | .4108 | .5601 | .3734 | .3353 | .3734 | .0747 | .2347 |
| 18 | .5601 | .6413 | .6722 | .5487 | .5658 | .3052 | |
| 19 | .7011 | .7011 | .7922 | .6516 | .5365 | | .5487 |
| 20 | .7011 | .7468 | .57 | .5967 | .5487 | .5658 | .4973 |
| 21 | .5258 | .5609 | .5487 | .5144 | .5144 | .4115 | .4359 |
| 22 | .5601 | .583 | .5144 | .5487 | .5144 | .4527 | .415 |
| 23 | .5281 | .5144 | .5487 | .4801 | .5258 | .3772 | .3772 |
| 24 | .3018 | .3018 | .2401 | .8322 | .9069 | .9175 | .1886 |
| **Max** | **3.0483** | **2.9264** | **.7922** | **2.5309** | **2.6749** | **2.8182** | **1.6324** |
| **Min** | **.2641** | **.2641** | **.2401** | **.3353** | **.3734** | **.0747** | **.1886** |
| **Avg** | **1.1595** | **.9049** | **.4543** | **.8156** | **.8038** | **1.4743** | **.7380** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SASWAD[047]** **BU 5801**
**Substation No/ Name :- 214424 / 33 KV SASWAD**
**Feeder No / Name : 303 / 22 KV KHALAD AG** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 22 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.8861 | 1.8861 | | .2683 | .2683 | .4527 | 1.5813 |
| 2 | 1.8442 | 1.8442 | .4024 | .2683 | .2683 | .4527 | 1.5813 |
| 3 | 1.8233 | 1.6956 | .4024 | .2683 | .2683 | .4527 | 1.4746 |
| 4 | 2.0119 | 1.8442 | .4024 | .2683 | .3353 | .5792 | 1.4746 |
| 5 | 2.5194 | 2.3205 | .4024 | .2683 | .4024 | .5792 | 1.9433 |
| 6 | 2.9835 | 2.652 | .5365 | .4024 | .5365 | .7011 | 2.2024 |
| 7 | 4.0162 | 3.4408 | .6706 | .0488 | .5365 | .5609 | 3.0864 |
| 8 | .7468 | .7392 | .5365 | .5365 | .5365 | .5487 | .5487 |
| 9 | .4024 | 2.8045 | | 4.0695 | 4.2052 | .5601 | .2683 |
| 10 | .4024 | .7956 | | 5.4698 | 5.0389 | .5975 | .4481 |
| 11 | .4024 | .4024 | | 5.6363 | 5.3086 | .4481 | .4481 |
| 12 | .4024 | .4024 | | 5.8299 | 5.1821 | .4481 | .2987 |
| 13 | .4024 | .4024 | | 5.5708 | 4.6963 | .5601 | .2987 |
| 14 | .4024 | .6706 | | 5.3132 | 4.5344 | .3734 | .2987 |
| 15 | | 4.2798 | 6.5539 | 5.1852 | 4.481 | .4481 | .2987 |
| 16 | | 5.3772 | | 4.923 | 4.5344 | .4481 | .2987 |
| 17 | .5975 | 4.923 | 4.8583 | .3978 | .5975 | .2987 | .2987 |
| 18 | .2987 | 1.9433 | 5.1821 | .4481 | .6036 | | .2263 |
| 19 | .6036 | .6036 | 3.3684 | .4527 | .3978 | | .5243 |
| 20 | .6036 | .5609 | .4527 | .3978 | .5304 | .5975 | .3978 |
| 21 | .6036 | .6036 | .3978 | .4115 | .5304 | .4527 | .4481 |
| 22 | .5975 | .4024 | .4024 | .4024 | .4527 | .4527 | .4527 |
| 23 | .5975 | .4024 | .2683 | .4024 | .4527 | .4527 | .4527 |
| 24 | 1.7833 | 1.7147 | .4024 | | .2683 | .4527 | 1.3717 |
| **Max** | **4.0162** | **5.3772** | **6.5539** | **5.8299** | **5.3086** | **.7011** | **3.0864** |
| **Min** | **.2987** | **.4024** | **.2683** | **.0488** | **.2683** | **.2987** | **.2263** |
| **Avg** | **1.1787** | **1.7796** | **1.5775** | **2.0539** | **1.8736** | **.4963** | **.8635** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SASWAD[047] BU 5801**
**Substation No/ Name :- 214424 / 33 KV SASWAD**
**Feeder No / Name : 304 / 22 KV SASWAD U NO 1 SHEDDABLE URBAN**
**Feeder KV- 22 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .679 | .7545 | .7545 | .7545 | .7545 | .679 | .6722 |
| 2 | .679 | .679 | .7545 | .7545 | .7545 | .679 | .6722 |
| 3 | .679 | .679 | .7545 | .7545 | .7545 | .679 | .6348 |
| 4 | .7545 | .7545 | .8299 | .8299 | .7545 | .7468 | .7468 |
| 5 | .9054 | .9431 | .9054 | .8676 | .8299 | .8589 | .9335 |
| 6 | 1.2071 | 1.5089 | 1.2449 | 1.3203 | 1.1317 | 1.307 | 1.2936 |
| 7 | 1.8861 | 1.8107 | 1.6221 | 1.6221 | 1.6221 | 1.848 | 1.7741 |
| 8 | 1.6221 | 1.7353 | 1.5844 | 1.6598 | 1.7353 | 1.6632 | 1.4784 |
| 9 | 1.358 | 1.3957 | 1.4335 | 1.5089 | 1.4335 | 1.358 | 1.5089 |
| 10 | 1.2071 | 1.2071 | | 1.3203 | 1.2826 | 1.2071 | 1.2449 |
| 11 | 1.1694 | 1.1317 | | 1.1203 | 1.1949 | 1.2071 | 1.1317 |
| 12 | 1.1317 | 1.0185 | | 1.0829 | 1.1203 | 1.1203 | 1.0185 |
| 13 | 1.0185 | 1.0185 | | 1.0456 | 1.0456 | 1.0456 | 1.0562 |
| 14 | 1.0562 | 1.0562 | | .9335 | .9335 | 1.0456 | .9808 |
| 15 | .9808 | | 1.4937 | .9335 | .9709 | 1.0456 | .9808 |
| 16 | 1.0185 | .9335 | 1.307 | .9709 | .9709 | 1.0082 | 1.0456 |
| 17 | 1.1949 | 1.0829 | 1.2696 | .9335 | 1.1203 | 1.1203 | 1.1203 |
| 18 | 1.4563 | 1.4712 | 1.5466 | | 1.4335 | 1.5466 | 1.4712 |
| 19 | 1.6632 | 1.6632 | 1.8107 | 1.6975 | 1.6975 | 1.7353 | 1.7353 |
| 20 | 1.6632 | 1.4784 | 1.6975 | 1.5844 | 1.5466 | 1.5775 | 1.4746 |
| 21 | 1.4784 | 1.4784 | 1.3957 | 1.4712 | 1.3817 | 1.3375 | 1.3957 |
| 22 | 1.2071 | 1.1694 | 1.1317 | 1.2826 | 1.1203 | 1.2323 | 1.1203 |
| 23 | .9431 | .9431 | .9054 | 1.0185 | .9335 | .9335 | .8962 |
| 24 | .7545 | .7545 | .7545 | .7545 | .7545 | .7468 | .7468 |
| **Max** | **1.8861** | **1.8107** | **1.8107** | **1.6975** | **1.7353** | **1.848** | **1.7741** |
| **Min** | **.679** | **.679** | **.7545** | **.7545** | **.7545** | **.679** | **.6348** |
| **Avg** | **1.1547** | **1.1594** | **1.2208** | **1.1401** | **1.1365** | **1.1553** | **1.1306** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SASWAD[047] BU 5801**
**Substation No/ Name :- 214424 / 33 KV SASWAD**
**Feeder No / Name : 305 / 22 KV DIWA GOATHAN GAOTHAN FEEDER**
**Feeder KV- 22 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1509 | .1509 | .1509 | .1509 | .1509 | .1509 | .0377 |
| 2 | .1509 | .1509 | .1509 | .1509 | .1509 | .1132 | .0377 |
| 3 | .1509 | .1509 | .1509 | .1509 | .1509 | .1132 | .0377 |
| 4 | .1509 | | .1509 | .1509 | .1509 | .1132 | .0754 |
| 5 | .2263 | | .1886 | .1886 | .1886 | .1886 | .0754 |
| 6 | .415 | .3772 | .3772 | .3772 | .3772 | .415 | .1132 |
| 7 | .4904 | .4904 | .3772 | .4904 | .4527 | .4854 | .1132 |
| 8 | .415 | .415 | .415 | .3395 | .4904 | .4108 | .0754 |
| 9 | .3395 | .3395 | .3395 | .3395 | .3772 | .3018 | .0754 |
| 10 | .2641 | .2263 | | .3018 | .3395 | .3018 | |
| 11 | .2263 | .1886 | | .2641 | .3018 | .2641 | |
| 12 | .2263 | .1509 | | .2614 | .2987 | .2241 | |
| 13 | .1509 | .1509 | | .2241 | .2614 | .1867 | .0377 |
| 14 | .1886 | .1886 | | .2241 | .2241 | .2241 | |
| 15 | .1886 | .1886 | .2587 | .2241 | .2614 | .2241 | |
| 16 | .1867 | .1494 | .2614 | .2241 | .1867 | .1867 | |
| 17 | .1867 | .1867 | .2614 | .2614 | .2241 | .2241 | .3361 |
| 18 | .2641 | .2641 | .3734 | .3772 | .3018 | .3018 | .415 |
| 19 | .415 | .415 | .415 | .4527 | .415 | .3734 | .4854 |
| 20 | .415 | .3772 | .3772 | .4527 | .3772 | .3734 | .4854 |
| 21 | .3772 | .3395 | .3395 | .3772 | .3361 | .3395 | .3734 |
| 22 | .3018 | .2641 | .2263 | .2641 | .2641 | | .3018 |
| 23 | .2263 | .1886 | .1886 | .1886 | .1886 | .0377 | .2263 |
| 24 | .1886 | .1509 | .1509 | .1509 | .1509 | .1509 | .0377 |
| **Max** | **.4904** | **.4904** | **.415** | **.4904** | **.4904** | **.4854** | **.4854** |
| **Min** | **.1509** | **.1494** | **.1509** | **.1509** | **.1509** | **.0377** | **.0377** |
| **Avg** | **.2623** | **.2502** | **.2712** | **.2745** | **.2759** | **.2480** | **.1856** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SASWAD[047] BU 5801**
**Substation No/ Name :- 214424 / 33 KV SASWAD**
**Feeder No / Name : 306 / 22 KV KHALAD GAONTHAN GAOTHAN FEEDER**
**Feeder KV- 22 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1886 | .1886 | .1886 | .2263 | .1886 | .1886 | .1886 |
| 2 | .1886 | .1886 | .1886 | .2263 | .1886 | .1886 | .1886 |
| 3 | .1886 | .1886 | .1886 | .2263 | .1886 | .2641 | .2641 |
| 4 | .1886 | .2263 | .2641 | .2641 | .2641 | .3018 | .3395 |
| 5 | .3395 | .3772 | .3018 | .3395 | .3395 | .3395 | |
| 6 | .5281 | .5281 | .5281 | .5658 | .5281 | .5601 | .5601 |
| 7 | .6413 | .6413 | .6413 | .6413 | .679 | .6348 | .6722 |
| 8 | .4904 | .5281 | .6036 | .5281 | .6413 | .5228 | .5601 |
| 9 | .415 | .3772 | .4527 | .3772 | .4527 | .415 | .415 |
| 10 | | .3018 | | .415 | .415 | .3018 | .3772 |
| 11 | .2641 | .3018 | | .3018 | .3395 | .2641 | .2641 |
| 12 | .1886 | .2263 | | .2614 | .2987 | .2614 | .3018 |
| 13 | .2263 | .1886 | | .1867 | .1867 | .1867 | .2641 |
| 14 | .1886 | .1509 | | .2614 | .2241 | .1867 | |
| 15 | .2263 | .1886 | .3734 | .2614 | .2614 | .1867 | .2263 |
| 16 | .2614 | .2241 | | .2614 | .2241 | .2241 | .2241 |
| 17 | .2241 | .2614 | .3361 | .2987 | .2614 | .2614 | .2987 |
| 18 | .4527 | .3772 | .4854 | .4904 | .4481 | .415 | .5281 |
| 19 | .6348 | .6036 | .6413 | .7167 | .5658 | | .5975 |
| 20 | .5228 | .5658 | .6036 | .5658 | .5281 | .5601 | .5281 |
| 21 | .4904 | .4527 | .5281 | | .4854 | .4481 | .4481 |
| 22 | .3018 | .3395 | .3772 | .3772 | .3772 | .3395 | .3395 |
| 23 | .2263 | .3018 | .2641 | .2263 | .3018 | .2641 | .2263 |
| 24 | .2263 | .1886 | .1886 | .2263 | .1886 | .2263 | .2263 |
| **Max** | **.6413** | **.6413** | **.6413** | **.7167** | **.679** | **.6348** | **.6722** |
| **Min** | **.1886** | **.1509** | **.1886** | **.1867** | **.1867** | **.1867** | **.1886** |
| **Avg** | **.3306** | **.3299** | **.3975** | **.3585** | **.3574** | **.3279** | **.3654** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SASWAD[047] BU 5801**
**Substation No/ Name :- 214424 / 33 KV SASWAD**
**Feeder No / Name : 307 / 22 KV SASWAD AG SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4161 | .4207 | .0754 | .1132 | .1132 | .0377 | .3315 |
| 2 | .407 | .4115 | .0754 | .1132 | .1132 | .0377 | .3315 |
| 3 | .407 | .4748 | .0754 | .1132 | .1132 | .0377 | .3315 |
| 4 | .4024 | .4694 | .0754 | .1132 | .1132 | .0754 | .3277 |
| 5 | .503 | .5365 | .0754 | .1132 | .1132 | .0377 | .3277 |
| 6 | .5967 | .6036 | .1132 | .1132 | .1132 | .0377 | .3605 |
| 7 | .8192 | .7209 | .1509 | .1509 | .1886 | .0754 | .5243 |
| 8 | .112 | .112 | .1509 | .1509 | .1509 | .0754 | .1132 |
| 9 | .1509 | .9602 | 1.166 | 1.0974 | 1.0974 | .1132 | .1132 |
| 10 | .1509 | 1.1401 | | 1.4083 | 1.2742 | .1132 | .1132 |
| 11 | .0754 | 1.2803 | | 1.2597 | 1.326 | .1132 | .1132 |
| 12 | .1509 | 1.2266 | | 1.5402 | 1.3763 | .0747 | .1132 |
| 13 | .0754 | 1.1142 | | 1.6385 | .5571 | .112 | .1132 |
| 14 | .0754 | 1.2308 | | 1.4746 | 1.2955 | .0747 | .0754 |
| 15 | .1509 | 1.4403 | 1.4918 | 1.4899 | 1.3603 | .0747 | .0754 |
| 16 | .0747 | 1.5074 | 1.3108 | 1.3748 | 1.3435 | .0747 | |
| 17 | .0754 | .0754 | .7865 | .0754 | .0747 | .0754 | .0754 |
| 18 | .0747 | .0754 | .7956 | | .0754 | .0754 | .0754 |
| 19 | .1132 | .0754 | .5243 | .0754 | .0754 | | .0754 |
| 20 | .0754 | .0754 | .1132 | .0747 | .0754 | .0754 | .0754 |
| 21 | .0754 | .0754 | .1132 | .0754 | .0754 | .0686 | .0754 |
| 22 | .0754 | .0754 | .1132 | .1132 | .0377 | .0377 | .0377 |
| 23 | .0754 | .0754 | .1132 | .0754 | .0377 | .0754 | .0377 |
| 24 | .4908 | .4908 | .0754 | .1132 | .1132 | .0377 | .3315 |
| **Max** | **.8192** | **1.5074** | **1.4918** | **1.6385** | **1.3763** | **.1132** | **.5243** |
| **Min** | **.0747** | **.0754** | **.0754** | **.0747** | **.0377** | **.0377** | **.0377** |
| **Avg** | **.2343** | **.6112** | **.3892** | **.5594** | **.4672** | **.0700** | **.1804** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SASWAD[047]** **BU 5801**
**Substation No/ Name :- 214424 / 33 KV SASWAD**
**Feeder No / Name : 308 / 22 KV PURANDAR GAONTHAN** **GAOTHAN FEEDER**
**Feeder KV- 22 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .1886 | .0754 | .1132 | .1886 | .0377 | .1509 |
| 2 | | .1886 | .0754 | .1132 | .1509 | .0377 | .1886 |
| 3 | | .1509 | .0754 | .1132 | .1509 | .0754 | .1886 |
| 4 | | .1886 | .0754 | .1132 | .1886 | .0754 | .1886 |
| 5 | | .2641 | .0754 | .1132 | .1886 | .0754 | .2263 |
| 6 | | .1886 | .1509 | .1886 | .2263 | .1132 | .2641 |
| 7 | | .2641 | .2263 | .3018 | .3018 | .1509 | .3395 |
| 8 | | .1509 | .1886 | .2641 | .2263 | .1132 | .2641 |
| 9 | | .1132 | .2263 | .1886 | .1132 | .1132 | .2641 |
| 10 | | .0754 | | .2641 | .1132 | .0754 | .2263 |
| 11 | | .0754 | | .2641 | .1132 | .1509 | .1886 |
| 12 | .1886 | .0754 | | .2614 | .2241 | .1867 | .2263 |
| 13 | .2263 | .0754 | | .1867 | .2241 | .1867 | .1509 |
| 14 | .2641 | .0754 | | .2614 | .2987 | .2241 | .2263 |
| 15 | .1509 | .0754 | .2987 | .2241 | .2614 | .2241 | .1509 |
| 16 | .2241 | .0747 | .2241 | .2614 | .2241 | .2614 | .1867 |
| 17 | .2263 | .0754 | .2614 | .2614 | .1494 | .2614 | .1867 |
| 18 | .2263 | .0754 | .1867 | .2263 | .2263 | .2641 | .2641 |
| 19 | .3018 | .1886 | .1867 | .2614 | .1509 | .2263 | .2641 |
| 20 | .2641 | .1509 | .1509 | .2263 | .1494 | .2641 | .2263 |
| 21 | .2641 | .1509 | .1509 | .2641 | .0754 | .2241 | .2614 |
| 22 | .2263 | .1132 | .1886 | .2263 | .0754 | .2263 | .2263 |
| 23 | .1886 | .0754 | .2263 | .2263 | .0754 | .1886 | .1886 |
| 24 | | .2263 | .0754 | .1886 | .3018 | .0377 | .1509 |
| **Max** | **.3018** | **.2641** | **.2987** | **.3018** | **.3018** | **.2641** | **.3395** |
| **Min** | **.1509** | **.0747** | **.0754** | **.1132** | **.0754** | **.0377** | **.1509** |
| **Avg** | **.2293** | **.1367** | **.1641** | **.2130** | **.1833** | **.1581** | **.2166** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SASWAD[047] BU 5801**
**Substation No/ Name :- 214424 / 33 KV SASWAD**
**Feeder No / Name : 309 / 22 KV SHIVARI GAONTHAN GAOTHAN FEEDER**
**Feeder KV- 22 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3018 | .3395 | .2263 | .3018 | .3018 | .2641 | .3018 |
| 2 | .3018 | .3395 | .2263 | .3018 | .3018 | .2641 | .2641 |
| 3 | .3395 | .3395 | .2263 | .3018 | .3018 | .2641 | .2641 |
| 4 | .3772 | .3395 | .2641 | .3395 | .3395 | .3018 | .3395 |
| 5 | .415 | .3772 | .3395 | .7167 | .3772 | .3018 | .415 |
| 6 | .4527 | .5281 | .3772 | .4527 | .415 | .3395 | |
| 7 | .5281 | .5658 | .3772 | .5658 | .5658 | .4527 | .5601 |
| 8 | .4527 | .3772 | .4527 | .3772 | .415 | .415 | .415 |
| 9 | .5658 | .3772 | .5658 | .5658 | .679 | | .6036 |
| 10 | .679 | .3395 | | .6348 | .6036 | .7545 | .7545 |
| 11 | .6413 | .3395 | | .7468 | .6722 | .7095 | .7545 |
| 12 | .679 | .3395 | | .5975 | .6348 | .7023 | .679 |
| 13 | .5658 | .3018 | | .5601 | .5601 | .5914 | .4904 |
| 14 | .679 | .3772 | | .5544 | .5914 | .6283 | .5658 |
| 15 | .4904 | .3395 | .7468 | .5975 | .5975 | .6722 | .5658 |
| 16 | .5601 | .3361 | .7468 | .5601 | .5228 | .6348 | .5601 |
| 17 | .4108 | .4108 | .6348 | .4854 | | .4854 | .4854 |
| 18 | .4904 | .3018 | .5281 | | .4481 | .4904 | |
| 19 | .5658 | .415 | .6036 | .5175 | .4904 | .5658 | .5658 |
| 20 | .5601 | .3772 | .4527 | | .4527 | .4854 | .4481 |
| 21 | .5281 | .3018 | .4435 | .415 | .4108 | .4854 | .4481 |
| 22 | .4904 | .3395 | .415 | .3772 | .3018 | .3772 | .3395 |
| 23 | .3772 | .2641 | .3772 | .3395 | .3018 | .3395 | .3018 |
| 24 | .3395 | .3772 | .2263 | .3018 | .3018 | .2641 | .3018 |
| **Max** | **.679** | **.5658** | **.7468** | **.7468** | **.679** | **.7545** | **.7545** |
| **Min** | **.3018** | **.2641** | **.2263** | **.3018** | **.3018** | **.2641** | **.2641** |
| **Avg** | **.4913** | **.3643** | **.4332** | **.4823** | **.4603** | **.4691** | **.4738** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SASWAD[047]** **BU 5801**
**Substation No/ Name :- 214424 / 33 KV SASWAD**
**Feeder No / Name : 310 / 22 KV SASWAD NO 2** **SHEDDABLE URBAN**
**Feeder KV- 22 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3772 | .3772 | .3772 | .3772 | .3772 | .3772 | .3772 |
| 2 | .3772 | .3772 | .3772 | .3772 | .3772 | .3772 | .3772 |
| 3 | .3772 | .3772 | .3772 | .3772 | .3772 | .3772 | .4527 |
| 4 | .3772 | .3772 | .3772 | .3772 | .3772 | .3772 | .4854 |
| 5 | .4527 | .4527 | .415 | .3772 | .3772 | .3772 | .6348 |
| 6 | .7545 | .679 | .6413 | .6413 | .6413 | .6722 | .7468 |
| 7 | 1.2071 | | .9808 | .9054 | .9054 | 1.0456 | 1.2323 |
| 8 | 1.0562 | 1.0562 | 1.0185 | 1.1317 | 1.0562 | .9335 | 1.1088 |
| 9 | .8676 | .8299 | .9054 | .8299 | .9431 | .8299 | .8299 |
| 10 | .679 | .679 | | .8299 | .7545 | .679 | .7167 |
| 11 | .6413 | .679 | | .6722 | .7545 | .6722 | .679 |
| 12 | .5658 | .5281 | | .6722 | .6722 | .5975 | .6413 |
| 13 | .5281 | .5281 | | .5975 | .5975 | .5975 | .6036 |
| 14 | .5658 | .4904 | | .5975 | .4854 | .5228 | .4904 |
| 15 | .5658 | .5281 | .9335 | .5601 | .4854 | .5601 | .5658 |
| 16 | .5601 | .4854 | .7468 | .5601 | .5975 | .5975 | .5975 |
| 17 | .5601 | .5601 | .7468 | .6348 | .6722 | .6348 | .6722 |
| 18 | .7842 | .6036 | .9431 | | .8676 | .8215 | .9054 |
| 19 | .8589 | .7468 | .9808 | .9431 | .9054 | .9431 | .9054 |
| 20 | .7468 | .7468 | .9335 | .8676 | .7922 | .8676 | .8676 |
| 21 | .7468 | .7468 | .8299 | .7545 | .7468 | .7922 | .7545 |
| 22 | .679 | .6413 | .679 | .679 | .6722 | .6722 | .6348 |
| 23 | .5281 | .5658 | .4527 | .5281 | .5601 | .5601 | .4481 |
| 24 | .4527 | .3772 | .3772 | .415 | .3772 | .3772 | .3772 |
| **Max** | **1.2071** | **1.0562** | **1.0185** | **1.1317** | **1.0562** | **1.0456** | **1.2323** |
| **Min** | **.3772** | **.3772** | **.3772** | **.3772** | **.3772** | **.3772** | **.3772** |
| **Avg** | **.6379** | **.5840** | **.6891** | **.6394** | **.6405** | **.6359** | **.6710** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SASWAD[047]** **BU 5801**
**Substation No/ Name :- 214424 / 33 KV SASWAD**
**Feeder No / Name : 311 / 22 KV DIWA AG** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 22 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3018 | .3772 | .3772 | 1.0364 | 1.1336 | 1.0059 | .3018 |
| 2 | .3018 | .3772 | .3772 | 1.0364 | .9717 | .9945 | .3018 |
| 3 | .3018 | .3772 | .3772 | .9717 | .9717 | .9945 | .3772 |
| 4 | .3772 | .3772 | .4527 | 1.2308 | 1.2308 | 1.1603 | .4527 |
| 5 | .4527 | .4527 | .4904 | 1.5043 | 1.5546 | 1.3108 | .4527 |
| 6 | .6036 | .6036 | .6413 | 1.9608 | 1.7711 | 1.704 | .5281 |
| 7 | .7545 | .679 | .7167 | 2.4371 | 2.2809 | 2.2283 | .3772 |
| 8 | .7545 | .7545 | .8676 | .679 | .679 | .5975 | .3772 |
| 9 | 2.1765 | 2.13 | .8299 | .6036 | .679 | 2.4006 | .6859 |
| 10 | 2.6246 | 2.3746 | | .6036 | .6036 | 2.7183 | 1.3108 |
| 11 | 2.8959 | 2.9264 | | .6722 | .5658 | 2.9492 | |
| 12 | 2.8959 | 2.9874 | | .6348 | .5975 | 2.915 | |
| 13 | 2.8349 | 2.2497 | | .7468 | .5975 | 2.6558 | |
| 14 | 1.6194 | 2.5 | | .6722 | .5975 | 2.3594 | |
| 15 | 2.4996 | 2.4996 | .6348 | .5975 | | 2.4326 | |
| 16 | 2.6558 | 2.6882 | .3361 | .5601 | | 2.332 | |
| 17 | .4904 | .4854 | .8589 | .5975 | | .4108 | .8619 |
| 18 | .5658 | .0754 | .8215 | .6348 | .6036 | .5281 | .5658 |
| 19 | .6722 | .7545 | .8299 | .6036 | .6413 | .5658 | .6036 |
| 20 | .5281 | .679 | .7842 | .6036 | .5658 | .4801 | .6036 |
| 21 | .5281 | .6036 | .6036 | .4854 | .4904 | .4115 | .4024 |
| 22 | .4527 | .5658 | .5281 | .4527 | .4527 | | .3772 |
| 23 | .3772 | .3772 | .4527 | .5281 | .4527 | .3018 | .3772 |
| 24 | .3018 | .3772 | .4527 | .9175 | .9717 | .9389 | .3018 |
| **Max** | **2.8959** | **2.9874** | **.8676** | **2.4371** | **2.2809** | **2.9492** | **1.3108** |
| **Min** | **.3018** | **.0754** | **.3361** | **.4527** | **.4527** | **.3018** | **.3018** |
| **Avg** | **1.1653** | **1.1780** | **.6017** | **.8654** | **.8768** | **1.4955** | **.5144** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SASWAD[047] BU 5801**
**Substation No/ Name :- 214437 / 33 KV PISAWARE**
**Feeder No / Name : 201 / 11 KV BABAWADI SINGLE PHASING**
**SINGLEPHASING Feeder KV- 11 /**
**OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.2186 | 1.3889 | 1.5089 | 1.5083 | .2263 | .1886 | .2075 |
| 2 | 1.3435 | 1.5432 | 1.5261 | 1.4575 | .2263 | .1886 | .2075 |
| 3 | 1.3426 | 1.6975 | 1.4918 | 1.4582 | .2263 | .1886 | .2054 |
| 4 | 1.4723 | 1.7661 | 1.5261 | 1.6804 | .2641 | .2263 | .2241 |
| 5 | 1.5729 | 1.8519 | 1.6617 | 1.8233 | .3018 | .3174 | .2241 |
| 6 | 1.8564 | 2.0062 | 1.8652 | 1.8679 | .3772 | .2801 | .3734 |
| 7 | 1.9845 | 2.2291 | 2.2634 | 2.0153 | .3961 | .3734 | .3921 |
| 8 | .2622 | .2743 | .2241 | .3018 | .3018 | .3174 | .2987 |
| 9 | .2829 | .1886 | .2641 | .2829 | 2.3148 | 2.304 | 2.0553 |
| 10 | .2641 | .1886 | .2452 | .2452 | 2.5892 | 2.6791 | 2.4459 |
| 11 | .2452 | .2075 | .2241 | | 2.6852 | 2.6282 | 2.13 |
| 12 | .2452 | .2075 | .2241 | .2452 | 2.7161 | 2.5774 | 2.2874 |
| 13 | .2263 | .2263 | .2241 | .2263 | 2.5692 | 2.5774 | 2.1376 |
| 14 | .2263 | .2263 | .2241 | .2263 | 2.42 | 2.5434 | 2.0809 |
| 15 | .2263 | .2263 | .2241 | .2452 | 2.4863 | 2.5095 | 1.8591 |
| 16 | .2263 | .2075 | | .2452 | 2.536 | 2.5604 | 1.8623 |
| 17 | .2263 | .2241 | | .2641 | .2241 | .2829 | .2347 |
| 18 | .2452 | .2614 | | .2829 | .2241 | .2452 | .2543 |
| 19 | .2829 | .3734 | .3584 | .3018 | .2772 | .2263 | .3018 |
| 20 | .3206 | .3547 | .4706 | .3206 | .2587 | .2263 | .2812 |
| 21 | .3018 | .3174 | .3391 | .2829 | .2402 | .2241 | .2622 |
| 22 | .2829 | .2801 | .2263 | .2263 | .2614 | .2241 | .2267 |
| 23 | .2641 | .2195 | .1886 | .2641 | .2218 | .2054 | .1886 |
| 24 | 1.2597 | 1.4523 | 1.4232 | 1.6221 | .2263 | .1867 | .2241 |
| **Max** | **1.9845** | **2.2291** | **2.2634** | **2.0153** | **2.7161** | **2.6791** | **2.4459** |
| **Min** | **.2263** | **.1886** | **.1886** | **.2263** | **.2218** | **.1867** | **.1886** |
| **Avg** | **.6741** | **.7466** | **.7954** | **.7563** | **1.0238** | **1.0117** | **.8735** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SASWAD[047] BU 5801**
**Substation No/ Name :- 214437 / 33 KV PISAWARE**
**Feeder No / Name : 202 / 11 KV MALSHIRAS SINGLE PHASING SINGLEPHASING Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4344 | .4338 | .5093 | .4298 | .8916 | .9877 | .7373 |
| 2 | .3982 | .4338 | .4904 | .4477 | .9259 | 1.0679 | .8059 |
| 3 | .5194 | .4527 | .5093 | .5121 | .9945 | 1.1999 | 1.0288 |
| 4 | .6036 | .5093 | .5601 | .5973 | 1.3032 | 1.3523 | 1.0631 |
| 5 | .6984 | .5658 | .6535 | .788 | 1.3717 | 1.5091 | 1.1145 |
| 6 | .8326 | .679 | .9335 | .9412 | 1.4403 | 1.6956 | 1.3717 |
| 7 | .905 | .7545 | 1.0164 | .9671 | 1.9719 | 2.1216 | 1.8143 |
| 8 | .6805 | .7356 | .8775 | .6268 | .6516 | | .5975 |
| 9 | 1.9719 | 1.989 | 2.0953 | | .5788 | .567 | .5847 |
| 10 | 2.0919 | 2.4006 | 2.5072 | 1.4403 | .5788 | .439 | .4298 |
| 11 | 2.332 | 2.2291 | 2.4863 | 2.0062 | .5601 | .4108 | .4252 |
| 12 | 2.0405 | 2.3663 | 2.5604 | 2.3148 | .5415 | .3547 | .3681 |
| 13 | 2.1605 | 2.3148 | 2.4926 | 2.4006 | .5228 | .3734 | .3224 |
| 14 | 2.1776 | 2.2291 | 2.4587 | 2.4691 | .4715 | .3921 | .394 |
| 15 | 2.1434 | 2.5034 | 2.4587 | 2.4177 | | .3921 | .3721 |
| 16 | 2.0405 | 2.2043 | 2.4926 | 2.3834 | .4481 | .3734 | .3012 |
| 17 | .3224 | .4854 | | .3584 | .4108 | .4715 | .4298 |
| 18 | .6413 | .6722 | .5731 | .6979 | .7095 | .3734 | .6089 |
| 19 | .7545 | .8962 | .5731 | .8488 | .8417 | .3841 | .7059 |
| 20 | .8488 | .8507 | .905 | .8865 | .7701 | .7842 | .6379 |
| 21 | .811 | .7282 | .8048 | .7545 | .7164 | .7282 | .5258 |
| 22 | .679 | .6348 | .6335 | .6413 | .5975 | .6161 | .4961 |
| 23 | .4527 | .547 | .5014 | .547 | .5041 | .5041 | .4252 |
| 24 | .4656 | .4338 | .547 | .4525 | .823 | .8215 | .7716 |
| **Max** | **2.332** | **2.5034** | **2.5604** | **2.4691** | **1.9719** | **2.1216** | **1.8143** |
| **Min** | **.3224** | **.4338** | **.4904** | **.3584** | **.4108** | **.3547** | **.3012** |
| **Avg** | **1.1252** | **1.1687** | **1.2887** | **1.1273** | **.8098** | **.7791** | **.6805** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SASWAD[047] BU 5801**
**Substation No/ Name :- 214437 / 33 KV PISAWARE**
**Feeder No / Name : 203 / 11 KV RISEPISE SINGLE PHASING Feeder KV- 11 / OUTGOING SINGLE PHASING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5658 | .6036 | .5658 | .6036 | .823 | .8596 | .823 |
| 2 | .5847 | .6036 | .6036 | .5658 | .8059 | .7619 | .7716 |
| 3 | .6224 | .6224 | .5281 | .6036 | .8402 | .8859 | .8059 |
| 4 | .6602 | .6602 | .5975 | .679 | .8573 | .9362 | .8573 |
| 5 | .6979 | .679 | .7095 | .7316 | .8916 | .9945 | .9259 |
| 6 | .7922 | .7356 | .9335 | .7922 | .9259 | 1.0004 | .9774 |
| 7 | .8488 | .7733 | 1.0164 | .8676 | 1.0117 | 1.1934 | 1.1191 |
| 8 | .7545 | .7545 | | .7545 | .7468 | .7095 | .7282 |
| 9 | .8573 | .9431 | .9054 | 1.0117 | .6535 | .6413 | .6224 |
| 10 | .8916 | .8916 | 1.2136 | 1.2517 | 5.7133 | .5975 | .6413 |
| 11 | .9259 | .9259 | 1.0852 | 1.2174 | .6161 | .5788 | .6224 |
| 12 | .8916 | .9259 | 1.1191 | 1.1831 | .5788 | .5601 | .6036 |
| 13 | .9431 | .9774 | 1.1022 | 1.166 | .5601 | .5601 | .6036 |
| 14 | .8745 | 1.0117 | 1.1361 | 1.1488 | .5601 | .5041 | .6224 |
| 15 | .8916 | 1.0288 | 1.1022 | 1.1488 | .5228 | .5601 | .6224 |
| 16 | .9259 | 1.1022 | 1.1191 | 1.1317 | .4527 | .5788 | .6036 |
| 17 | .4908 | .5975 | | .5847 | .5601 | .5847 | .6224 |
| 18 | .6413 | .7468 | .6413 | .6413 | .6838 | .3734 | .6602 |
| 19 | .6602 | .8775 | .7922 | .679 | .7468 | .4668 | .7167 |
| 20 | .679 | .8962 | .7545 | .7733 | .7468 | .7655 | .6722 |
| 21 | .6979 | .7468 | .7095 | .7167 | .7468 | .7282 | .6468 |
| 22 | .6602 | .6348 | .6602 | .6602 | .6722 | .6535 | .6413 |
| 23 | .6036 | .6413 | .6224 | .6224 | .6161 | .6161 | .6413 |
| 24 | .5847 | .6036 | .6224 | .6224 | .823 | .8954 | .8573 |
| **Max** | **.9431** | **1.1022** | **1.2136** | **1.2517** | **5.7133** | **1.1934** | **1.1191** |
| **Min** | **.4908** | **.5975** | **.5281** | **.5658** | **.4527** | **.3734** | **.6036** |
| **Avg** | **.7394** | **.7910** | **.8427** | **.8399** | **.9231** | **.7086** | **.7253** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SASWAD[047] BU 5801**
**Substation No/ Name :- 214437 / 33 KV PISAWARE**
**Feeder No / Name : 204 / 11 KV BHULESHWAR 3 PHASE SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .679 | 1.2346 | 1.3717 | 1.2742 | .5658 | .6413 | .6344 |
| 2 | .7362 | 1.3203 | 1.3889 | 1.3435 | .5847 | .6602 | .7545 |
| 3 | .8065 | 1.3889 | | 1.4752 | .6036 | .6413 | .7922 |
| 4 | 1.0311 | 1.5432 | 1.4922 | 1.5023 | .7545 | .7545 | .9054 |
| 5 | 1.5242 | 1.6975 | 1.7295 | 1.5844 | 1.1128 | .8402 | .9335 |
| 6 | 1.9393 | 2.0062 | 2.0348 | 1.6091 | 1.1694 | .9335 | 1.1949 |
| 7 | 1.9498 | 2.4691 | .9431 | 1.9845 | 1.2449 | 1.2883 | 1.1763 |
| 8 | .8063 | .679 | .8962 | .6935 | .9619 | 1.1203 | 1.0642 |
| 9 | .679 | .6001 | .8316 | .679 | 1.8004 | 2.0178 | 1.3916 |
| 10 | .4715 | .5847 | .6535 | .6036 | 2.3739 | 2.4587 | 1.2809 |
| 11 | .4527 | .547 | | .5658 | 2.3739 | 2.5265 | 1.6766 |
| 12 | .4715 | .5975 | .6722 | .463 | 2.652 | 2.6282 | 1.8821 |
| 13 | .5658 | .6348 | | .4715 | 2.7018 | 2.5434 | 1.6556 |
| 14 | .5281 | .6535 | .5041 | .4527 | 2.5692 | 2.4417 | 1.5242 |
| 15 | .5093 | .5975 | .5601 | .4715 | 2.6189 | 2.5095 | 1.4632 |
| 16 | .5093 | .6535 | .5975 | .5093 | 2.652 | 2.3739 | 1.4815 |
| 17 | .6413 | .7842 | | .547 | .663 | .3772 | .3856 |
| 18 | .8488 | .8402 | .8779 | .7545 | .8048 | .8775 | .6979 |
| 19 | .8865 | 1.0269 | .9774 | .8488 | .985 | 1.0269 | .6944 |
| 20 | .9431 | 1.0269 | .7522 | .9431 | .9313 | .8962 | .6478 |
| 21 | .8488 | .9149 | .7011 | .811 | .924 | .8402 | .5801 |
| 22 | .679 | .7842 | .6588 | .7167 | .8402 | .7842 | .4409 |
| 23 | .6036 | .7842 | .5596 | .6413 | .7468 | .7468 | .4252 |
| 24 | .4778 | 1.0974 | 1.2003 | 1.1576 | .6036 | .6722 | .6535 |
| **Max** | **1.9498** | **2.4691** | **2.0348** | **1.9845** | **2.7018** | **2.6282** | **1.8821** |
| **Min** | **.4527** | **.547** | **.5041** | **.4527** | **.5658** | **.3772** | **.3856** |
| **Avg** | **.8162** | **1.0194** | **.9701** | **.9210** | **1.3849** | **1.3584** | **1.0140** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SASWAD[047] BU 5801**
**Substation No/ Name :- 214437 / 33 KV PISAWARE**
**Feeder No / Name : 205 / 11 kV RAJURI SINGLE PHASING Feeder KV- 11 / OUTGOING SINGLE PHASING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4108 | .3772 | .6535 | .3391 | .6001 | .5068 | .3429 |
| 2 | .3801 | .3772 | .6036 | .5144 | .7202 | .5853 | .4287 |
| 3 | .4854 | .3961 | .6224 | .5731 | .823 | .7964 | .5144 |
| 4 | .5304 | .4338 | .7095 | .7059 | 1.0117 | .8688 | .7202 |
| 5 | .6224 | .5093 | .7842 | .7964 | 1.166 | 1.0288 | .7545 |
| 6 | .8676 | .679 | 1.0642 | .9997 | 1.2003 | 1.2209 | .9774 |
| 7 | .9808 | 1.0562 | 1.0829 | 1.1694 | 1.7147 | 1.5927 | 1.2209 |
| 8 | .6935 | 1.0185 | .9335 | 1.0185 | 1.0082 | .8871 | .8962 |
| 9 | .9259 | 1.286 | 1.2378 | 1.5432 | .7468 | .6602 | .6413 |
| 10 | 1.0802 | 1.869 | 1.8313 | 1.9204 | .6535 | .3734 | .4854 |
| 11 | 1.3717 | 2.0576 | 1.8652 | 2.2068 | .4854 | .3174 | .3734 |
| 12 | 1.4575 | 2.0008 | 1.8313 | | .3734 | .2801 | .4066 |
| 13 | 1.5947 | 1.95 | 1.6956 | | .3734 | .2987 | .3292 |
| 14 | 1.3889 | 1.9161 | 1.8313 | | .3361 | .3361 | .3292 |
| 15 | 1.2346 | 1.8313 | 1.8313 | | .3361 | .3174 | .3439 |
| 16 | 1.166 | 1.6289 | 1.8313 | | .3361 | .2987 | .3142 |
| 17 | .3734 | .4108 | | | .3734 | .5658 | .4435 |
| 18 | .5093 | .8402 | .6009 | .7545 | .7545 | .7468 | .6401 |
| 19 | .679 | 1.0269 | .9808 | .8488 | .8962 | .8215 | .9997 |
| 20 | .9431 | 1.0082 | .8589 | .9054 | .9808 | .7842 | .8589 |
| 21 | .9054 | | .724 | .8488 | .9431 | .5975 | .6401 |
| 22 | .679 | .7468 | .4755 | .5658 | .7545 | .5415 | .4805 |
| 23 | .5093 | .7545 | .3582 | .4904 | .7167 | .4668 | .4706 |
| 24 | .362 | .3772 | .7655 | .4119 | .4115 | .2865 | .3429 |
| **Max** | **1.5947** | **2.0576** | **1.8652** | **2.2068** | **1.7147** | **1.5927** | **1.2209** |
| **Min** | **.362** | **.3772** | **.3582** | **.3391** | **.3361** | **.2801** | **.3142** |
| **Avg** | **.8396** | **1.0675** | **1.0945** | **.9229** | **.7382** | **.6325** | **.5814** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SASWAD[047] BU 5801**
**Substation No/ Name :- 214437 / 33 KV PISAWARE**
**Feeder No / Name : 206 / 11 KV Mavadi/Pimpari SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1949 | .2572 | .2012 | .2543 | .1886 | .2263 | .2075 |
| 2 | .1829 | .3086 | .2195 | .2204 | .2075 | .2263 | .2075 |
| 3 | .2149 | .3429 | .2218 | .3189 | .1698 | .2452 | .2801 |
| 4 | .2715 | .3772 | .2454 | .3582 | .2829 | .2614 | .3921 |
| 5 | .3294 | .4115 | .2915 | .4024 | .4715 | .2801 | .4294 |
| 6 | .5784 | .4287 | .4973 | .4656 | .5847 | .4481 | .5658 |
| 7 | .6201 | | .6173 | .631 | .6602 | .6099 | .5975 |
| 8 | .4409 | .3584 | .3734 | .3881 | .547 | .4854 | .4668 |
| 9 | .3395 | .2263 | .3174 | .3018 | .5144 | .4144 | .431 |
| 10 | .1886 | .2263 | .2614 | .2075 | .5087 | .5426 | .4588 |
| 11 | .1509 | .1698 | .2427 | .2263 | .6783 | .5596 | .5182 |
| 12 | .1509 | .1886 | .2241 | .2452 | .7122 | .5935 | .5121 |
| 13 | .2263 | .2263 | .2241 | .2263 | .7122 | .5765 | |
| 14 | .2263 | .2452 | .2241 | .2263 | .7122 | .5935 | .4374 |
| 15 | .2075 | .2452 | .2241 | .2452 | .703 | .5935 | .3281 |
| 16 | .2263 | .2241 | .2054 | .2641 | .703 | .6104 | .3437 |
| 17 | .2263 | .2353 | | .2452 | .2427 | .2241 | .1907 |
| 18 | .3395 | .3921 | .3475 | .3584 | .3696 | .3734 | .2686 |
| 19 | .3772 | .5041 | .5093 | .3961 | .4251 | .4854 | .4024 |
| 20 | .3961 | .4854 | .5249 | .4904 | .4435 | .4294 | .3506 |
| 21 | .4338 | .3734 | .3475 | .3772 | .3734 | .3734 | .3224 |
| 22 | .3395 | .2614 | .2353 | .7733 | .2987 | .2801 | .2303 |
| 23 | .2075 | .1867 | .1753 | .2075 | .2641 | .2054 | .1844 |
| 24 | .1772 | .1886 | .2012 | .2126 | .1886 | .2263 | .1867 |
| **Max** | **.6201** | **.5041** | **.6173** | **.7733** | **.7122** | **.6104** | **.5975** |
| **Min** | **.1509** | **.1698** | **.1753** | **.2075** | **.1698** | **.2054** | **.1844** |
| **Avg** | **.2936** | **.2984** | **.3014** | **.3351** | **.4567** | **.4110** | **.3614** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SASWAD[047]** **BU 5801**
**Substation No/ Name :- 214540 / 33 KV Bopgaon**
**Feeder No / Name : 301 / 22 KV Garade Gaothan** **GAOTHAN FEEDER**
**Feeder KV- 22 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.1317 | .9054 | .9054 | .9431 | 1.0562 | .9808 | |
| 2 | 1.1317 | .8676 | .8299 | .9431 | .9808 | 1.0562 | .5658 |
| 3 | | .8676 | .9808 | .9431 | 1.094 | 1.0562 | .5658 |
| 4 | 1.3203 | .9054 | .9808 | .9431 | 1.0562 | 1.1317 | .7545 |
| 5 | 1.5089 | 1.2071 | 1.4335 | 1.5089 | 1.5844 | 1.6221 | 1.1317 |
| 6 | 1.8861 | 2.1879 | 1.9239 | 2.0748 | 2.1125 | 2.0748 | 1.5089 |
| 7 | 2.452 | 2.2634 | 2.2257 | 2.2634 | 2.2634 | 2.1125 | 1.5089 |
| 8 | 2.0748 | 1.9616 | .9054 | 2.2634 | 2.1502 | 1.5844 | 1.1317 |
| 9 | 1.4712 | 1.3957 | 1.8861 | 1.6975 | 1.9993 | 1.6221 | .9431 |
| 10 | 1.2449 | 1.8107 | 1.5089 | 1.358 | 1.8107 | 1.5089 | .6413 |
| 11 | 1.094 | 1.6598 | 1.6975 | 1.3957 | 2.037 | 1.3203 | .7167 |
| 12 | 1.5089 | .7167 | 1.8861 | 1.4335 | 1.8107 | 1.3203 | .4527 |
| 13 | 1.5089 | .6413 | 1.5089 | 1.5844 | 1.4712 | 1.3203 | 1.2826 |
| 14 | .8676 | .4904 | 1.3203 | 1.5089 | 1.4712 | 1.1317 | .6413 |
| 15 | .9431 | .4904 | | 1.358 | 1.5844 | 1.1317 | 1.2071 |
| 16 | 1.1317 | | 1.5089 | 1.4712 | | 1.3203 | 1.5089 |
| 17 | 1.5089 | | | .3772 | 1.5844 | 1.3203 | 1.8861 |
| 18 | 1.8861 | 1.0562 | 1.8861 | 2.037 | 1.5844 | 1.6975 | 1.8861 |
| 19 | 2.1125 | 2.1502 | 2.0748 | 2.1125 | | 2.0748 | 1.8861 |
| 20 | 1.9239 | 1.9239 | 1.8861 | 2.1125 | .4904 | 1.8861 | 1.8861 |
| 21 | | 1.6975 | 1.6975 | 1.8107 | 1.6975 | 1.5089 | 1.7353 |
| 22 | 1.2826 | 1.2071 | 1.5089 | 1.4335 | 1.5844 | .7545 | 1.2449 |
| 23 | 1.1317 | 1.1317 | 1.1317 | 1.2071 | 1.1694 | .9431 | 1.1317 |
| 24 | 1.1317 | .8676 | .9431 | .9431 | 1.094 | .9431 | .9431 |
| **Max** | **2.452** | **2.2634** | **2.2257** | **2.2634** | **2.2634** | **2.1125** | **1.8861** |
| **Min** | **.8676** | **.4904** | **.8299** | **.3772** | **.4904** | **.7545** | **.4527** |
| **Avg** | **1.4661** | **1.2911** | **1.4832** | **1.4885** | **1.5312** | **1.3926** | **1.1809** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SASWAD[047] BU 5801**
**Substation No/ Name :- 214540 / 33 KV Bopgaon**
**Feeder No / Name : 302 / 22 KV Kodit Ag** **SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 22 / OUTGOING** **DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.3565 | 1.0288 | 1.0174 | .3018 | .3395 | .3018 | |
| 2 | 1.6956 | 1.3203 | 1.2071 | .3018 | .3772 | .3018 | .3018 |
| 3 | 2.0348 | 1.2003 | | .3018 | .3772 | .3018 | .3018 |
| 4 | 2.0348 | 1.0402 | | .3018 | .3395 | .3018 | .3395 |
| 5 | 2.0348 | 2.2382 | | .4527 | .4527 | .3772 | .3772 |
| 6 | 2.3739 | 2.8121 | | .6036 | .6036 | .5281 | .415 |
| 7 | 2.5434 | 2.8182 | 1.012 | .6036 | .6413 | .6413 | .1886 |
| 8 | .5658 | .415 | .2263 | .6036 | .6413 | .5658 | 1.0562 |
| 9 | .4527 | .3395 | 3.0521 | 3.219 | 3.2819 | .4904 | .3772 |
| 10 | .4904 | .3772 | 3.6046 | 4.1289 | 4.0306 | .4527 | .2641 |
| 11 | .5281 | .3772 | 4.4239 | 4.2101 | 5.0172 | .4904 | .2641 |
| 12 | .5281 | .3395 | 4.4239 | 4.5085 | 4.26 | .5281 | .3018 |
| 13 | .5658 | .3395 | 4.4239 | 4.5877 | 4.3256 | .4904 | |
| 14 | .2641 | .3772 | 4.5877 | 4.3911 | 4.1945 | .4527 | .3772 |
| 15 | .3018 | .1886 | | 4.0634 | 4.1945 | .4527 | .3772 |
| 16 | .3395 | | 4.4239 | 3.9979 | | .4904 | .4904 |
| 17 | .4904 | | | .415 | .3772 | .415 | .4904 |
| 18 | .415 | .1886 | .415 | .4904 | .5658 | .5281 | .5658 |
| 19 | .415 | .3772 | .4904 | .6036 | | .4527 | .5658 |
| 20 | .415 | .4527 | .4527 | .6036 | .4904 | .3395 | .5658 |
| 21 | | .3772 | .4527 | .5281 | .4527 | | .4904 |
| 22 | .3395 | .3395 | .415 | .4527 | .3772 | .3018 | .4527 |
| 23 | .3018 | .3395 | .3772 | .3772 | .3395 | .3018 | .3772 |
| 24 | 1.0174 | .8288 | .9835 | .3018 | .3772 | .3395 | .3018 |
| **Max** | **2.5434** | **2.8182** | **4.5877** | **4.5877** | **5.0172** | **.6413** | **1.0562** |
| **Min** | **.2641** | **.1886** | **.2263** | **.3018** | **.3395** | **.3018** | **.1886** |
| **Avg** | **.9350** | **.8234** | **1.9994** | **1.6812** | **1.6389** | **.4281** | **.4201** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SASWAD[047] BU 5801**
**Substation No/ Name :- 214540 / 33 KV Bopgaon**
**Feeder No / Name : 303 / 22 KV Bhiwari Ag SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3018 | .3018 | .2641 | 1.0174 | .8718 | .852 | |
| 2 | .3395 | .3018 | .2641 | 1.0174 | .8383 | .8192 | .1886 |
| 3 | .3395 | .3018 | .3018 | 1.0059 | .8817 | .8718 | .3018 |
| 4 | .3395 | .3018 | .3018 | 1.3413 | .9496 | .9054 | .3018 |
| 5 | .3772 | .3772 | .4527 | 1.5089 | 1.0852 | 1.0395 | .4527 |
| 6 | .5658 | .7545 | .679 | 1.6766 | 1.3923 | 1.3077 | .6413 |
| 7 | .6413 | .8299 | .7545 | 1.6766 | 1.8107 | 1.4754 | .7167 |
| 8 | .5658 | .7922 | .679 | .7167 | .7167 | .7167 | .6036 |
| 9 | 1.8861 | 1.5089 | .5658 | .5281 | .5281 | 1.5546 | .7377 |
| 10 | 2.13 | 1.5729 | .4527 | .4527 | .4527 | 1.9662 | .7377 |
| 11 | 2.2611 | 2.2283 | .3772 | .4527 | .4527 | 2.0317 | .7773 |
| 12 | 2.5232 | 2.1628 | .4904 | .5281 | .5281 | 2.2672 | .7042 |
| 13 | 2.0805 | 2.332 | .4527 | .415 | .5281 | 2.1052 | .7362 |
| 14 | 2.5274 | 2.0645 | .4527 | .415 | .4527 | 1.9433 | .6009 |
| 15 | 2.0081 | 1.3443 | | .4527 | .4904 | 1.1336 | .6081 |
| 16 | 1.7078 | | .4527 | .4527 | | 1.5813 | .6154 |
| 17 | .3772 | .4527 | | .4527 | .3395 | .415 | .3018 |
| 18 | .6036 | .5658 | .5281 | .5658 | .6413 | .5281 | .5281 |
| 19 | .6036 | .6413 | .679 | .6413 | | .6413 | .6413 |
| 20 | .5658 | .6036 | .6413 | .6413 | .6413 | .5281 | .5658 |
| 21 | | .5281 | .5658 | .5281 | .5658 | | .4904 |
| 22 | .415 | .415 | .4527 | .4904 | .5281 | .3772 | .3772 |
| 23 | .3772 | .3395 | .3772 | .3772 | .4527 | .3772 | .3395 |
| 24 | .2641 | .3018 | .2641 | .9431 | .7377 | .6722 | .3772 |
| **Max** | **2.5274** | **2.332** | **.7545** | **1.6766** | **1.8107** | **2.2672** | **.7773** |
| **Min** | **.2641** | **.3018** | **.2641** | **.3772** | **.3395** | **.3772** | **.1886** |
| **Avg** | **1.0348** | **.9140** | **.4750** | **.7624** | **.7221** | **1.1352** | **.5368** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214422 / 33/11 KV SUPA**
**Feeder No / Name : 201 / 11 KV Vadhane AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4163 | .3982 | .3582 | .6097 | .9907 |
| 2 | .4119 | .4344 | .3258 | .7926 | 1.0669 |
| 3 | .4119 | .4706 | .3077 | 1.0059 | 1.1279 |
| 4 | .4477 | .5068 | .3982 | 1.4022 | 1.2346 |
| 5 | .5731 | .5068 | .5068 | 1.7071 | 1.3717 |
| 6 | .7164 | .5731 | .591 | 1.8138 | 1.5242 |
| 7 | .7164 | .7164 | .724 | 2.0576 | 1.829 |
| 8 | .6089 | .6447 | .6516 | .4119 | .6516 |
| 9 | 2.4387 | 2.8959 | 1.4632 | .3761 | .3963 |
| 10 | 3.0483 | 3.2007 | 2.3777 | .2865 | .3048 |
| 11 | 2.9264 | 3.2312 | 3.094 | .3582 | .2591 |
| 12 | 2.7435 | 3.2617 | 3.1855 | .3582 | .2743 |
| 13 | 2.8959 | 3.4294 | 3.2465 | .3582 | .2896 |
| 14 | | 3.2769 | 3.094 | .3582 | .2439 |
| 15 | | 3.0483 | 3.0178 | .3045 | |
| 16 | 3.2922 | 3.0483 | 2.9721 | .3224 | |
| 17 | .3582 | .2865 | .5194 | .3761 | .2743 |
| 18 | .4298 | .4656 | .4298 | .4298 | .3658 |
| 19 | .3224 | .7164 | .6089 | .5731 | .5487 |
| 20 | .3582 | .6516 | .5731 | .5014 | .4877 |
| 21 | .3982 | .5731 | .5014 | .4344 | .4268 |
| 22 | .4344 | .5014 | .4163 | .3982 | .3658 |
| 23 | .3982 | .4119 | .362 | .3258 | .3048 |
| 24 | | .362 | .4344 | .5335 | .6706 |
| **Max** | **3.2922** | **3.4294** | **3.2465** | **2.0576** | **1.829** |
| **Min** | **.3224** | **.2865** | **.3077** | **.2865** | **.2439** |
| **Avg** | **1.1594** | **1.4005** | **1.2566** | **.6706** | **.6822** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214422 / 33/11 KV SUPA**
**Feeder No / Name : 202 / 11 KV Supa Gaothan GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3768 | .3887 | .3292 | .3887 | .2743 | .426 | .3292 |
| 2 | .426 | .421 | .3292 | .421 | .2572 | .4096 | .3292 |
| 3 | .4239 | .4534 | .3292 | .4534 | .2572 | .3932 | .3292 |
| 4 | .6104 | .5182 | .4344 | .4858 | .4801 | .5243 | .439 |
| 5 | .7291 | .6478 | | .5182 | .6859 | .7045 | .6697 |
| 6 | .8648 | .7125 | 1.0029 | .7125 | .7716 | .852 | 1.0029 |
| 7 | .9835 | 1.004 | 1.0745 | .9393 | .8573 | .9831 | .9671 |
| 8 | .6154 | .8954 | .9671 | .7545 | .7545 | .8238 | .8596 |
| 9 | .3239 | .5792 | .6154 | .6173 | .5243 | .6805 | .6173 |
| 10 | .3887 | .4344 | .5182 | .5144 | .39 | .4706 | .3772 |
| 11 | .3239 | .362 | .4858 | .4801 | .3561 | .3982 | .3258 |
| 12 | .2915 | .3258 | .4534 | .3086 | .3222 | .3801 | .3429 |
| 13 | .3239 | | .421 | .2915 | .3052 | .362 | .3772 |
| 14 | .3401 | .362 | .5182 | .3258 | .3113 | .362 | .2915 |
| 15 | .3563 | .3258 | .4858 | .3429 | .3391 | .2896 | .3429 |
| 16 | .3239 | .3258 | .3887 | .3086 | .3052 | .3077 | .3772 |
| 17 | .5182 | .6447 | .3887 | .3429 | .39 | .362 | .4115 |
| 18 | .6154 | .8059 | .583 | .583 | .5079 | .5731 | .5487 |
| 19 | .7449 | .905 | .5506 | .6859 | | .8688 | .8059 |
| 20 | .6802 | .788 | .3887 | .6516 | .7537 | .7164 | .7716 |
| 21 | .421 | .6516 | .3563 | .4801 | .6226 | .6697 | .5316 |
| 22 | .3887 | .4706 | .3887 | .4458 | .5243 | .4706 | .4801 |
| 23 | .3563 | .362 | .3563 | .3772 | .4588 | .362 | .4115 |
| 24 | .3932 | .3239 | .3292 | .3239 | .2743 | .4096 | .3292 |
| **Max** | **.9835** | **1.004** | **1.0745** | **.9393** | **.8573** | **.9831** | **1.0029** |
| **Min** | **.2915** | **.3239** | **.3292** | **.2915** | **.2572** | **.2896** | **.2915** |
| **Avg** | **.4925** | **.5525** | **.5085** | **.4897** | **.4662** | **.5333** | **.5112** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214422 / 33/11 KV SUPA**
**Feeder No / Name : 203 / 11 KV Baburdi Ag Feeder SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1526 | .1619 | .6859 | .7125 | .5487 | .1311 | .128 |
| 2 | .1696 | .1943 | .7621 | .9393 | .5487 | .1526 | .128 |
| 3 | .1457 | .1943 | .7926 | 1.004 | .5792 | .1475 | .128 |
| 4 | .1781 | .2267 | .8383 | 1.166 | .884 | .1341 | .16 |
| 5 | .2204 | .2591 | .9145 | 1.2955 | 1.0669 | .1638 | .2241 |
| 6 | .2294 | .2915 | 1.0974 | 1.3927 | 1.448 | .1966 | .3201 |
| 7 | .2267 | .3239 | 1.5242 | 1.6842 | 1.829 | .1802 | .3201 |
| 8 | .2591 | .2915 | .2031 | .3048 | .4572 | .1619 | .2721 |
| 9 | 1.9433 | 1.829 | .1457 | .2439 | .213 | 1.4175 | 1.2193 |
| 10 | 1.9757 | 1.768 | .1296 | .1524 | .1638 | 1.6461 | 1.5242 |
| 11 | 1.9433 | 2.21 | .081 | .1219 | .1475 | 1.6461 | 1.4632 |
| 12 | 1.9757 | 2.21 | .0972 | .0914 | .1147 | 1.6461 | 1.4937 |
| 13 | 2.0243 | 2.0729 | .081 | .0762 | .0983 | 1.6461 | 1.5242 |
| 14 | 2.0567 | 2.0729 | .0648 | .0762 | .0983 | 1.6461 | 1.4327 |
| 15 | 1.9433 | 1.9814 | .0486 | .0762 | .1147 | 1.7985 | 1.3717 |
| 16 | 1.9271 | 1.9357 | .1296 | .0914 | .1147 | 1.7528 | 1.326 |
| 17 | .2267 | .081 | .1134 | .0914 | .1311 | .0937 | .2134 |
| 18 | .1943 | .1619 | .1943 | .2439 | .1475 | .1406 | .1829 |
| 19 | .1943 | .2187 | .1619 | .2591 | .2374 | .25 | .2134 |
| 20 | .1781 | .2187 | .1619 | .2286 | .213 | .2031 | .1981 |
| 21 | .1943 | .1718 | .1619 | .1677 | .1966 | .192 | .1524 |
| 22 | .1619 | | .1619 | .1524 | .1638 | .16 | .1372 |
| 23 | .1781 | .1406 | .1781 | .1372 | .1475 | .144 | .1219 |
| 24 | .1526 | .1619 | .5487 | .4858 | .5182 | .1475 | .128 |
| **Max** | **2.0567** | **2.21** | **1.5242** | **1.6842** | **1.829** | **1.7985** | **1.5242** |
| **Min** | **.1457** | **.081** | **.0486** | **.0762** | **.0983** | **.0937** | **.1219** |
| **Avg** | **.7855** | **.8338** | **.3866** | **.4664** | **.4242** | **.6583** | **.5993** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214422 / 33/11 KV SUPA**
**Feeder No / Name : 204 / 11 KV Chandugadewadi Ag Feeder KV- 11 / OUTGOING**
**SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1017 | .1457 | .2134 | .3563 | .2286 | .1475 | .1097 |
| 2 | .1147 | .1457 | .2134 | .3887 | .2439 | .1311 | .1097 |
| 3 | .1457 | .1457 | .2241 | .421 | .2439 | .1475 | .1097 |
| 4 | .1147 | .1619 | .2241 | .421 | .2743 | | .1097 |
| 5 | .1638 | .2267 | .25 | .4534 | .3048 | .1802 | .128 |
| 6 | .1802 | .1943 | .3048 | .4858 | .3658 | .1966 | .2195 |
| 7 | .1966 | .1943 | | .3887 | .4268 | .1966 | .2172 |
| 8 | .1619 | .2149 | | .1524 | .1829 | .181 | .1791 |
| 9 | .4858 | .4481 | | .1219 | .1147 | .381 | .3658 |
| 10 | .5182 | .4481 | | .0914 | .0678 | .3353 | .4268 |
| 11 | .4858 | | | .0762 | .0509 | .3658 | .4572 |
| 12 | | .3658 | | .061 | .0509 | .4572 | .4268 |
| 13 | .4534 | | | .061 | .0509 | .4725 | .3963 |
| 14 | .4049 | .5487 | | .061 | .0509 | .4725 | .3658 |
| 15 | .421 | .5639 | | .061 | .0492 | .4877 | .3353 |
| 16 | .4372 | .5639 | .0486 | .061 | .0492 | .503 | .3201 |
| 17 | .1943 | .0362 | .0486 | .061 | | .0716 | .1524 |
| 18 | .1619 | .181 | .1619 | .1219 | .1475 | .1254 | .1677 |
| 19 | .1943 | .2353 | .1134 | .1829 | .213 | .2149 | .1829 |
| 20 | .1619 | .2507 | .1134 | .1677 | .1966 | .1991 | .2896 |
| 21 | .1943 | .197 | .0972 | .1677 | .1802 | .181 | .1524 |
| 22 | .1619 | .181 | .1296 | .1524 | .1638 | .1448 | .1372 |
| 23 | .1457 | .1448 | .1457 | .1372 | .1311 | .1267 | .1067 |
| 24 | .1147 | .1619 | .2267 | .2915 | .2286 | .1311 | .1097 |
| **Max** | **.5182** | **.5639** | **.3048** | **.4858** | **.4268** | **.503** | **.4572** |
| **Min** | **.1017** | **.0362** | **.0486** | **.061** | **.0492** | **.0716** | **.1067** |
| **Avg** | **.2485** | **.2616** | **.1677** | **.2060** | **.1746** | **.2544** | **.2323** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214422 / 33/11 KV SUPA**
**Feeder No / Name : 205 / 11 KV Supa Ag Feeder SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6226 | 1.2955 | .2172 | .3239 | .2058 | .8356 | .7011 |
| 2 | .7537 | 1.3279 | .2172 | .3563 | .1886 | .9339 | .7621 |
| 3 | .9012 | 1.3927 | .2172 | .3887 | .1715 | 1.0322 | .823 |
| 4 | 1.0513 | 1.4899 | .2534 | .3887 | .2743 | 1.2452 | .884 |
| 5 | 1.5769 | 1.587 | .3258 | .421 | .4115 | 1.4582 | .9907 |
| 6 | 1.7859 | 2.1376 | .5194 | .4858 | .4801 | 1.7368 | 1.3413 |
| 7 | 2.3922 | 2.1376 | .5609 | .5182 | .5487 | 1.8515 | 1.7071 |
| 8 | 2.2672 | .4298 | .5731 | .4801 | .5487 | .4163 | .3658 |
| 9 | .2267 | .3582 | 2.4291 | 2.0576 | 1.7368 | .3439 | .2713 |
| 10 | .2591 | .2507 | 2.5263 | 2.7435 | 2.6707 | .2507 | .2058 |
| 11 | .1943 | | 2.5911 | 2.8121 | 2.7035 | .2149 | .2058 |
| 12 | .1943 | .1448 | 2.7854 | 3.1207 | 2.7526 | .1791 | .1886 |
| 13 | .1781 | .1433 | 2.915 | 3.0007 | 2.8182 | .1629 | .2058 |
| 14 | .1943 | .1791 | 2.9473 | 2.915 | 2.7526 | .1629 | .2058 |
| 15 | .1781 | .1715 | 2.753 | 2.7435 | 2.556 | .2149 | .1715 |
| 16 | .1619 | .181 | 2.5911 | 2.572 | | .197 | .1543 |
| 17 | .1457 | .0362 | .3563 | .2058 | .3052 | .2172 | .1715 |
| 18 | .1619 | .3582 | .3887 | .4115 | .3277 | .3582 | .2572 |
| 19 | .1943 | .5249 | .1296 | .5144 | .3768 | .4298 | .4115 |
| 20 | .1781 | .4298 | .1457 | .4801 | .3441 | .3582 | .3429 |
| 21 | .3239 | .2865 | .1619 | .3429 | .2949 | .2896 | .2743 |
| 22 | .2915 | .2534 | .1943 | .3086 | .2949 | .2353 | .2374 |
| 23 | .1619 | .2172 | .1943 | .2572 | .2785 | .2172 | .2058 |
| 24 | .4915 | .6478 | .2172 | .2267 | .2058 | .7373 | .6097 |
| **Max** | **2.3922** | **2.1376** | **2.9473** | **3.1207** | **2.8182** | **1.8515** | **1.7071** |
| **Min** | **.1457** | **.0362** | **.1296** | **.2058** | **.1715** | **.1629** | **.1543** |
| **Avg** | **.6203** | **.6948** | **1.0921** | **1.1698** | **1.0108** | **.5866** | **.4873** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214422 / 33/11 KV SUPA**
**Feeder No / Name : 206 / 11 KV Baburdi Gaothan GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1311 | .081 | .0762 | .1457 | .0762 | .1475 | .0762 |
| 2 | .1147 | .081 | .0762 | .1619 | .0762 | .1311 | .0762 |
| 3 | .1526 | .0648 | .0762 | .1943 | .061 | .1638 | .0762 |
| 4 | .1638 | .0648 | .0953 | .1619 | .1219 | .1696 | .1143 |
| 5 | .213 | .081 | .1448 | .1457 | .1829 | .213 | .1829 |
| 6 | .2458 | .0972 | .2896 | .1619 | .1981 | .2543 | .2926 |
| 7 | .2622 | .0972 | .2686 | .1296 | .2286 | .2865 | .2865 |
| 8 | .1943 | .1086 | .2507 | .1067 | .2134 | .197 | .2149 |
| 9 | .0486 | .1086 | .081 | .0914 | .1475 | .1254 | .0914 |
| 10 | .0486 | .1086 | .0648 | .061 | .0819 | .0716 | .061 |
| 11 | .0324 | | .0486 | .0457 | .0655 | .0537 | .061 |
| 12 | .0324 | .0724 | .0324 | .0457 | .0492 | .0362 | .061 |
| 13 | .0324 | .0543 | .0486 | .0457 | .0492 | .0362 | .061 |
| 14 | .0324 | .0362 | .0486 | .0457 | .0509 | .0362 | .0457 |
| 15 | .0324 | .0543 | .0486 | .0457 | .0492 | .0362 | .0457 |
| 16 | .0324 | .0543 | .0648 | .061 | .0509 | .0358 | .0457 |
| 17 | .0648 | .0724 | .0486 | .061 | .0819 | .0362 | .061 |
| 18 | .1296 | .1448 | .0972 | .1219 | .1311 | .1075 | .1372 |
| 19 | .1296 | .2353 | .0972 | .1829 | .2294 | .2149 | .1829 |
| 20 | .1457 | .2149 | .081 | .1524 | .1802 | .1991 | .1677 |
| 21 | .1296 | .181 | .081 | .1524 | .1526 | .1629 | .1219 |
| 22 | .1134 | .1448 | .1943 | .1372 | .1638 | .0905 | .1067 |
| 23 | .0648 | .0905 | .1619 | .1219 | .1526 | .0905 | .0914 |
| 24 | .1187 | .081 | .0762 | .1943 | .0762 | .1311 | .0762 |
| **Max** | **.2622** | **.2353** | **.2896** | **.1943** | **.2294** | **.2865** | **.2926** |
| **Min** | **.0324** | **.0362** | **.0324** | **.0457** | **.0492** | **.0358** | **.0457** |
| **Avg** | **.1111** | **.1013** | **.1064** | **.1156** | **.1196** | **.1261** | **.1141** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214422 / 33/11 KV SUPA**
**Feeder No / Name : 207 / 11 KV Dandwadi Ag SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1475 | .1457 | .9907 | .9717 | 1.0974 | | .1715 |
| 2 | .1311 | .1457 | 1.0669 | 1.004 | 1.166 | | .1715 |
| 3 | .1475 | .1619 | 1.0669 | 1.2308 | 1.2346 | .1475 | .1715 |
| 4 | .1802 | .1943 | 1.0974 | 1.2955 | 1.3032 | .213 | .1905 |
| 5 | .2204 | .2267 | 1.1584 | 1.3927 | 1.406 | .2949 | .2172 |
| 6 | .2622 | .2915 | 1.2955 | 1.4899 | 1.6461 | | .3258 |
| 7 | .3113 | .3077 | 1.7223 | 1.7652 | 2.0062 | .3277 | .3761 |
| 8 | .3239 | .3224 | .2686 | .3258 | .3429 | .3258 | .2865 |
| 9 | 2.2672 | 1.8747 | .1619 | .2743 | .2622 | 1.9204 | 1.7147 |
| 10 | 2.3482 | 2.1033 | .1943 | .2058 | .213 | 2.0119 | 2.2977 |
| 11 | 2.1862 | | .1134 | .1886 | .2035 | 2.0729 | 2.3663 |
| 12 | 2.2186 | 2.3015 | .1296 | .1715 | .213 | 2.0881 | 2.2291 |
| 13 | 2.1052 | 2.2405 | .1457 | .1715 | .1638 | 2.0881 | 2.1434 |
| 14 | 2.1376 | 2.2558 | .1619 | .1543 | | 2.0881 | 2.0748 |
| 15 | 2.0567 | 2.2558 | .1296 | .1715 | .1802 | 2.0576 | 1.8861 |
| 16 | 2.0081 | 1.9662 | .1943 | .1543 | .1475 | 2.0729 | 1.8004 |
| 17 | .0972 | .1791 | .1943 | .1715 | .1865 | .197 | .2743 |
| 18 | .1943 | .2715 | .2429 | .2743 | .2458 | .3045 | .2915 |
| 19 | .2267 | .2896 | .1619 | .2743 | .2883 | .3439 | .3086 |
| 20 | .1943 | .2507 | .1943 | .2401 | .2458 | .3258 | .2743 |
| 21 | .1943 | .2507 | .2267 | .2572 | .213 | .2896 | .2743 |
| 22 | .1619 | .2353 | .1943 | .2401 | .1966 | .2715 | .2401 |
| 23 | .1509 | .2172 | .2105 | .2229 | .1696 | .2195 | .2058 |
| 24 | .1311 | .1619 | .9602 | .6478 | 1.0631 | .1475 | .1715 |
| **Max** | **2.3482** | **2.3015** | **1.7223** | **1.7652** | **2.0062** | **2.0881** | **2.3663** |
| **Min** | **.0972** | **.1457** | **.1134** | **.1543** | **.1475** | **.1475** | **.1715** |
| **Avg** | **.8501** | **.8109** | **.5118** | **.5540** | **.6171** | **.9432** | **.8526** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214430 / 33/11 KV MURTI**
**Feeder No / Name : 201 / 11 KV Murti single phasing Feeder KV- 11 / OUTGOING** **SINGLE PHASING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5144 | .5213 | .2241 | .1829 | .1619 | .8215 | .743 |
| 2 | .583 | .5213 | .2241 | .2058 | .1619 | .8619 | .8025 |
| 3 | .6859 | .5575 | .2241 | .2401 | .1619 | .8619 | .8025 |
| 4 | .823 | .6773 | .2241 | .2743 | .1619 | .9783 | .9808 |
| 5 | 1.0288 | .8535 | .2987 | .3086 | .2949 | 1.1736 | 1.0997 |
| 6 | 1.3375 | 1.1265 | .3734 | .3429 | .3647 | 1.3889 | 1.1888 |
| 7 | 1.4575 | 1.3599 | .4108 | .3429 | .4359 | 1.6446 | 1.3375 |
| 8 | .2058 | .3277 | .4481 | .3601 | .3647 | .3647 | .4668 |
| 9 | .1943 | .2427 | 1.3375 | 1.2003 | 1.2483 | .2241 | .2572 |
| 10 | .1296 | .2241 | 1.286 | 1.3969 | 1.5242 | .1494 | .2058 |
| 11 | | .1494 | 1.3717 | 1.3672 | 1.8435 | .1307 | .1886 |
| 12 | .096 | .1494 | 1.3375 | 1.4563 | 1.7284 | .1307 | .1715 |
| 13 | | .112 | 1.286 | 1.5158 | 1.713 | .112 | .1886 |
| 14 | .128 | .112 | 1.4232 | 1.6049 | 1.7593 | .112 | .1886 |
| 15 | .112 | .112 | 1.5432 | 1.6049 | 1.9134 | .112 | .1886 |
| 16 | .096 | .112 | 1.5775 | 1.6049 | 1.781 | .112 | .2058 |
| 17 | .1457 | .1494 | .2401 | .1494 | .1619 | .1494 | .2401 |
| 18 | .2105 | .2614 | .2572 | .2614 | .2105 | .2987 | .2743 |
| 19 | .3277 | .3734 | .3086 | .3921 | .2949 | .4108 | .3086 |
| 20 | .3113 | .3921 | .3086 | .3361 | .2949 | .3734 | .2401 |
| 21 | .2785 | .2987 | .2743 | .2987 | .2429 | .3361 | .2058 |
| 22 | .2105 | .2614 | .2743 | .2614 | .2267 | .2987 | .0171 |
| 23 | .1943 | .2427 | .2401 | .2241 | .2267 | .2801 | .1715 |
| 24 | .5144 | .5502 | .2054 | .2058 | .1781 | .6371 | .6241 |
| **Max** | **1.4575** | **1.3599** | **1.5775** | **1.6049** | **1.9134** | **1.6446** | **1.3375** |
| **Min** | **.096** | **.112** | **.2054** | **.1494** | **.1619** | **.112** | **.0171** |
| **Avg** | **.4357** | **.4037** | **.6541** | **.6724** | **.7273** | **.4984** | **.4624** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214430 / 33/11 KV MURTI**
**Feeder No / Name : 202 / 11 KV Jogwadi single Phasing Feeder KV- 11 / OUTGOING** **SINGLE PHASING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .12 | .112 | .208 | .1886 | .1692 | .112 | .1307 |
| 2 | .1029 | .112 | .208 | .2401 | .2 | .112 | .1307 |
| 3 | .1029 | .112 | .208 | .2743 | .2286 | .112 | .1307 |
| 4 | .1372 | .1619 | .2378 | .3086 | .2896 | .112 | .1494 |
| 5 | .1715 | .2267 | .4755 | .3429 | .3521 | .2429 | .2241 |
| 6 | .1886 | .2785 | .6539 | .3772 | .4458 | .3647 | .3547 |
| 7 | .2058 | .3481 | .6241 | .6173 | .4816 | .3647 | .4108 |
| 8 | .2229 | .2949 | .3174 | .12 | .2622 | .3277 | .3921 |
| 9 | .3429 | .4607 | .2229 | .12 | .1943 | .4161 | .4115 |
| 10 | .5068 | .5647 | .1372 | .112 | .1619 | .4458 | .4115 |
| 11 | .4923 | .5944 | .12 | .0934 | .112 | .5053 | .3772 |
| 12 | .5135 | .5944 | .1372 | .0934 | .096 | .4755 | .3429 |
| 13 | .4988 | .5944 | .12 | .0934 | .08 | .5053 | .4115 |
| 14 | .535 | .5647 | .12 | .0934 | .08 | .5053 | .4458 |
| 15 | .5135 | .5647 | .1372 | .0934 | .096 | .5053 | .4458 |
| 16 | .4988 | .535 | .1543 | .0934 | .096 | .5053 | .4801 |
| 17 | .112 | .1494 | .1543 | .1307 | .1619 | .1494 | .12 |
| 18 | .1943 | .1867 | .2572 | .1867 | .2105 | .2054 | .12 |
| 19 | .2622 | .2987 | .2401 | .3174 | .2622 | .2987 | .1543 |
| 20 | .2622 | .2987 | .2743 | .2614 | .2267 | .2614 | .1715 |
| 21 | .1943 | .2241 | .2401 | .2241 | .1781 | .2241 | .1543 |
| 22 | .1619 | .1867 | .1715 | .168 | .1619 | .1867 | .1372 |
| 23 | .128 | .1307 | .1543 | .1307 | .112 | .1494 | .1372 |
| 24 | .12 | .112 | .1783 | .1886 | .1692 | .112 | .1307 |
| **Max** | **.535** | **.5944** | **.6539** | **.6173** | **.4816** | **.5053** | **.4801** |
| **Min** | **.1029** | **.112** | **.12** | **.0934** | **.08** | **.112** | **.12** |
| **Avg** | **.2745** | **.3211** | **.2397** | **.2029** | **.2012** | **.3000** | **.2656** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214430 / 33/11 KV MURTI**
**Feeder No / Name : 203 / 11 KV Morgaon single Phasing Feeder KV- 11 / OUTGOING** **SINGLE PHASING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1029 | .08 | .208 | .2401 | .2286 | .08 | .0747 |
| 2 | .1029 | .08 | .2378 | .2743 | .2286 | .08 | .0747 |
| 3 | .1029 | .08 | .2378 | .3086 | .2606 | .08 | .0747 |
| 4 | .12 | .112 | .2675 | .4115 | .2606 | .112 | .112 |
| 5 | .1372 | .1457 | .5053 | .5144 | .4458 | .1619 | .1494 |
| 6 | .1715 | .1943 | .6241 | .6173 | .6321 | .2267 | .2241 |
| 7 | .1886 | .2622 | .5944 | .6859 | .6706 | .2622 | .2241 |
| 8 | .2401 | .128 | .168 | .1372 | .1781 | .1457 | .1867 |
| 9 | .3144 | .4458 | .1372 | .1543 | .1296 | .4458 | .583 |
| 10 | .6241 | .5944 | .1372 | .1494 | .096 | .6241 | .5144 |
| 11 | .7827 | .6539 | .1219 | .112 | .08 | .6687 | .3258 |
| 12 | .7827 | .6836 | .12 | .0934 | .08 | .6539 | .3429 |
| 13 | .7526 | .6836 | .0914 | .0934 | .08 | .6836 | .3772 |
| 14 | .7676 | .6836 | .1543 | .0934 | .064 | .6836 | |
| 15 | .6984 | .7133 | .1543 | .0934 | .064 | .6539 | .3258 |
| 16 | .6161 | .7133 | .1372 | .0934 | .064 | .6539 | .3429 |
| 17 | .064 | .112 | .1715 | .1307 | .08 | .0747 | .1372 |
| 18 | .128 | .1494 | .2572 | .1494 | .128 | .1494 | .1372 |
| 19 | .1943 | .2054 | .2743 | .2054 | .1943 | .2054 | .1715 |
| 20 | .1781 | .2241 | .2743 | .168 | .1457 | .168 | .1886 |
| 21 | .1619 | .1494 | .2401 | .1494 | .128 | .1494 | .1886 |
| 22 | .096 | .1307 | .2058 | .112 | .096 | .112 | .1543 |
| 23 | .096 | .112 | .1715 | .0934 | .08 | .0934 | .1372 |
| 24 | .12 | .08 | .1783 | .2401 | .1692 | | .0747 |
| **Max** | **.7827** | **.7133** | **.6241** | **.6859** | **.6706** | **.6836** | **.583** |
| **Min** | **.064** | **.08** | **.0914** | **.0934** | **.064** | **.0747** | **.0747** |
| **Avg** | **.3143** | **.3090** | **.2362** | **.2217** | **.1910** | **.3117** | **.2227** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214430 / 33/11 KV MURTI**
**Feeder No / Name : 204 / 11 KV Tardoli single phasing Feeder KV- 11 / OUTGOING** **SINGLE PHASING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1543 | .128 | .208 | .2401 | .3041 | .1943 | .2241 |
| 2 | .1543 | .128 | .2229 | .2401 | .3814 | .1943 | .2241 |
| 3 | .1372 | .128 | .2378 | .2743 | .3814 | .1943 | .2241 |
| 4 | .1715 | .2105 | .2972 | .3429 | .5053 | .2622 | .2614 |
| 5 | .2058 | .2949 | .6241 | .4801 | .7133 | .3277 | .4108 |
| 6 | .2401 | .4359 | .8025 | .823 | .884 | .3812 | .5228 |
| 7 | .2743 | | .8322 | .9602 | 1.0185 | .5197 | .5228 |
| 8 | .3258 | .2949 | .3547 | .2058 | .4144 | .3277 | .4668 |
| 9 | .4344 | .7133 | .0171 | .2401 | .3113 | .7727 | .6687 |
| 10 | .8025 | .8916 | .1886 | .2241 | .1943 | 1.07 | .9088 |
| 11 | .9297 | 1.0254 | .2058 | .1867 | .1943 | 1.1294 | 1.1317 |
| 12 | .7526 | 1.0402 | .1715 | .1867 | .1943 | 1.0997 | 1.0288 |
| 13 | .873 | 1.07 | .2229 | .168 | .1619 | 1.1591 | .9945 |
| 14 | .8993 | 1.07 | .1886 | .168 | .1619 | 1.1294 | .7773 |
| 15 | .873 | 1.0105 | .2058 | .1867 | .1781 | 1.1294 | .8745 |
| 16 | .8993 | .9659 | .2229 | .2054 | .2105 | 1.0997 | 1.0974 |
| 17 | .1296 | .1494 | .2058 | .1867 | .2105 | | .1886 |
| 18 | .2267 | .2241 | .3086 | .2987 | .2949 | .3174 | .2058 |
| 19 | .3113 | .3361 | .3429 | | .3647 | .4668 | .2401 |
| 20 | .2785 | .3361 | .3772 | .4108 | .3113 | .4481 | .3086 |
| 21 | .2622 | .2614 | .3086 | .2987 | .2949 | .3734 | .2743 |
| 22 | .1781 | .2241 | .3086 | .2614 | .2429 | .2987 | .2572 |
| 23 | .1619 | .1867 | .2743 | .2241 | .2267 | .2427 | .2401 |
| 24 | .1543 | .128 | .1486 | .2401 | .2606 | .2105 | .2241 |
| **Max** | **.9297** | **1.07** | **.8322** | **.9602** | **1.0185** | **1.1591** | **1.1317** |
| **Min** | **.1296** | **.128** | **.0171** | **.168** | **.1619** | **.1943** | **.1886** |
| **Avg** | **.4096** | **.4893** | **.3032** | **.3066** | **.3506** | **.5804** | **.5116** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214430 / 33/11 KV MURTI**
**Feeder No / Name : 205 / 11 KV Modhave single phasing Feeder KV- 11 / OUTGOING** **SINGLE PHASING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2058 | .2286 | .1494 | .2058 | .128 | .2896 | .2972 |
| 2 | .2058 | .2606 | .1494 | .2058 | .128 | .4108 | .3567 |
| 3 | .2401 | .2606 | .1494 | .2401 | .128 | .535 | .3864 |
| 4 | .3086 | .3475 | .1494 | .2743 | .1619 | .6241 | .4161 |
| 5 | .3429 | .4401 | .2241 | .2058 | .2267 | .6472 | .5053 |
| 6 | .5144 | .5498 | .3734 | .3258 | .2949 | .6321 | .5498 |
| 7 | .6687 | .7926 | .4294 | .3601 | | .9217 | .6836 |
| 8 | .2401 | .2785 | .3361 | .381 | .3277 | .3277 | .2987 |
| 9 | .2785 | .2614 | .6859 | .7545 | .6161 | .3174 | .2743 |
| 10 | .1619 | .2241 | .6859 | .9511 | .8619 | .2241 | .1886 |
| 11 | | .1494 | .9945 | .9214 | .9907 | .168 | .1715 |
| 12 | .096 | .1494 | 1.0288 | .8916 | .9031 | .168 | .1886 |
| 13 | .112 | .1494 | 1.0802 | .8619 | .873 | .168 | .1715 |
| 14 | .096 | .1494 | .9602 | .8322 | .8471 | .168 | .1886 |
| 15 | .096 | | 1.0288 | .8322 | .8322 | .168 | .1715 |
| 16 | .096 | .168 | .823 | .8173 | .7188 | .168 | .1715 |
| 17 | .112 | .2054 | .2401 | .168 | .1619 | .1867 | .2058 |
| 18 | .2622 | .2987 | .3429 | .2241 | .2622 | .2241 | .2401 |
| 19 | .3812 | .4108 | .3772 | .4108 | .3481 | .4108 | .3086 |
| 20 | .3441 | .4108 | .3429 | .3547 | .2949 | .3734 | .3086 |
| 21 | .2753 | .2987 | .3086 | .2987 | .2622 | .3361 | .2286 |
| 22 | .1943 | .2241 | .2401 | .2241 | .1943 | .2614 | .2743 |
| 23 | .1619 | .168 | .2401 | .168 | .1619 | .1867 | .2401 |
| 24 | .2229 | .1715 | .1494 | .2058 | .128 | .2462 | .2378 |
| **Max** | **.6687** | **.7926** | **1.0802** | **.9511** | **.9907** | **.9217** | **.6836** |
| **Min** | **.096** | **.1494** | **.1494** | **.168** | **.128** | **.168** | **.1715** |
| **Avg** | **.2442** | **.2868** | **.4787** | **.4631** | **.4283** | **.3401** | **.2943** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214430 / 33/11 KV MURTI**
**Feeder No / Name : 206 / 11KV Ambi Single Phasing SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1715 | .1781 | .208 | .2401 | .2606 | .2105 | .2054 |
| 2 | .1715 | .1781 | .2229 | .2401 | .2896 | .1943 | .1867 |
| 3 | .1886 | .1781 | .2378 | .3086 | .2896 | .1943 | .1867 |
| 4 | .2058 | .2785 | .2675 | .5658 | .3521 | .2622 | .2241 |
| 5 | .2401 | .3812 | .3567 | .7545 | .4108 | .3647 | .3734 |
| 6 | .3086 | .503 | .5053 | .9259 | .4755 | .4359 | .4854 |
| 7 | .0343 | .5935 | .5201 | .823 | .5117 | .5087 | .5228 |
| 8 | .5144 | .503 | .4668 | .2058 | .3932 | .4144 | .5228 |
| 9 | .4401 | .5053 | .3258 | .2401 | .3441 | .535 | .6173 |
| 10 | .6093 | .535 | .2401 | .2241 | .2105 | .5944 | .6687 |
| 11 | .6984 | .4904 | .2058 | .1867 | .1943 | .6539 | .8745 |
| 12 | .6687 | .5944 | .2058 | .1867 | .128 | .639 | .8573 |
| 13 | .6923 | .6241 | .1372 | .1867 | .144 | .6836 | .8745 |
| 14 | .6923 | .6241 | .1886 | | .1943 | .6836 | .823 |
| 15 | .639 | .5944 | .2058 | | | .6539 | .583 |
| 16 | .5944 | .5647 | .2401 | | | .6241 | .4115 |
| 17 | .144 | .2241 | .2401 | | .2267 | | .2401 |
| 18 | .3605 | .4108 | .2743 | .4108 | .3277 | .3361 | .2401 |
| 19 | .503 | .5601 | .3086 | .5601 | .3978 | .4854 | .2572 |
| 20 | .431 | .5788 | .3086 | .4854 | .3978 | .4481 | .3086 |
| 21 | .3605 | .4481 | .2572 | .4108 | .3277 | .3921 | .3429 |
| 22 | .2267 | .3361 | .2572 | .2987 | .2785 | .3361 | .2743 |
| 23 | .1943 | .2241 | .2058 | .2241 | .2267 | .2427 | .2401 |
| 24 | .1524 | .1781 | .208 | .2229 | .2572 | .2105 | .2241 |
| **Max** | **.6984** | **.6241** | **.5201** | **.9259** | **.5117** | **.6836** | **.8745** |
| **Min** | **.0343** | **.1781** | **.1372** | **.1867** | **.128** | **.1943** | **.1867** |
| **Avg** | **.3851** | **.4286** | **.2748** | **.3850** | **.3017** | **.4393** | **.4394** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214431 / 33/11 KV HOL**
**Feeder No / Name : 201 / 11 KV Waki single Phasing SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2214 | .168 | .1265 | .168 | .253 | .3734 | .2214 |
| 2 | .2846 | .168 | .1898 | .168 | .2846 | .3734 | .2846 |
| 3 | .3479 | .168 | .2214 | .168 | .3163 | .3734 | .3479 |
| 4 | .3795 | .2241 | .2846 | .2054 | .3795 | .3921 | .3795 |
| 5 | .5376 | .2987 | .3163 | .2801 | .5243 | .4481 | .4428 |
| 6 | .6009 | .4481 | .3795 | .4668 | .5535 | .5729 | .6958 |
| 7 | .5693 | .4854 | .3563 | .5228 | .5535 | .7282 | .759 |
| 8 | .3321 | .4294 | .421 | .4294 | .3479 | .4294 | .3795 |
| 9 | .2688 | .6161 | .7773 | .9149 | .253 | .3361 | .3005 |
| 10 | .2105 | .6478 | .8745 | 1.0202 | .2105 | .2591 | .1619 |
| 11 | .1619 | .7773 | .7773 | .9555 | .1781 | .1619 | .1457 |
| 12 | .1457 | .7935 | .8583 | .9717 | .1134 | .1134 | .1457 |
| 13 | .1296 | .8421 | .8421 | 1.0364 | .1457 | .1134 | .1134 |
| 14 | .0972 | .8583 | .9393 | 1.004 | .1134 | .1296 | .0972 |
| 15 | .1296 | .8745 | | .9555 | .1619 | .1296 | .1134 |
| 16 | .1134 | .8421 | .9717 | .8583 | .1457 | .1296 | .1296 |
| 17 | .1619 | .1619 | .1457 | .1457 | .1943 | .1943 | .1457 |
| 18 | .3547 | .2214 | .3734 | | .4108 | .3479 | .3361 |
| 19 | .4108 | .2846 | .4108 | .3163 | .3734 | .3795 | .3326 |
| 20 | .3734 | .3479 | .3547 | .3479 | .3361 | .3479 | .3174 |
| 21 | .2801 | .3163 | .3174 | .2214 | .2987 | .2372 | .2801 |
| 22 | .2241 | .2214 | .2054 | .1898 | .2241 | .2214 | .2054 |
| 23 | .1494 | .1898 | .168 | .1265 | .1867 | .1423 | .1867 |
| 24 | .1739 | .168 | .1265 | .168 | .2372 | .3174 | .2056 |
| **Max** | **.6009** | **.8745** | **.9717** | **1.0364** | **.5535** | **.7282** | **.759** |
| **Min** | **.0972** | **.1619** | **.1265** | **.1265** | **.1134** | **.1134** | **.0972** |
| **Avg** | **.2774** | **.4397** | **.4538** | **.5061** | **.2832** | **.3021** | **.2803** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214431 / 33/11 KV HOL**
**Feeder No / Name : 202 / 11 KV Hol single Phasing SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1989 | .5636 | .5304 | .5304 | .1989 | .2652 | .2652 |
| 2 | .2652 | .5636 | .5967 | .5304 | .2652 | .2652 | .2652 |
| 3 | .3315 | .5636 | .5967 | .5304 | .3315 | .2652 | .2652 |
| 4 | .3978 | .5967 | .663 | .5304 | .3978 | .3315 | .2652 |
| 5 | .4641 | .5967 | .663 | .5967 | .4641 | .3978 | .3315 |
| 6 | .5304 | .7293 | .7293 | .7956 | | .5304 | .5967 |
| 7 | .5967 | .9282 | .7956 | .8619 | .4641 | .663 | .663 |
| 8 | .5304 | .5304 | | .4641 | .4641 | .5967 | .5967 |
| 9 | .8619 | .3978 | | .3978 | .7293 | .9282 | .9282 |
| 10 | .9945 | .2652 | | .2652 | .9282 | .9945 | .9945 |
| 11 | .9945 | .1989 | .3315 | .1989 | .9282 | .9945 | .9945 |
| 12 | .9945 | .1989 | .2652 | .1989 | .9945 | 1.0608 | .9282 |
| 13 | .9945 | .1326 | .2652 | .1326 | .9282 | 1.0608 | .7956 |
| 14 | .9282 | .1326 | .1989 | .1326 | .9282 | 1.0608 | .8619 |
| 15 | .8619 | .1326 | .1989 | .1989 | .9945 | .9945 | .8619 |
| 16 | .7956 | .1989 | .1989 | .1989 | .9945 | .9945 | .8619 |
| 17 | .1989 | .2652 | .2652 | .2652 | .2652 | .2652 | .1989 |
| 18 | .3978 | .3315 | .3978 | .4678 | .3978 | .3315 | .4641 |
| 19 | .5304 | .3978 | .5304 | .5304 | .5304 | .3978 | .5304 |
| 20 | .4973 | .4641 | .4641 | .5304 | .4641 | .4481 | .3978 |
| 21 | .3978 | .5304 | .3978 | .4641 | .3978 | .3978 | .3978 |
| 22 | .3315 | .4641 | .3315 | .3978 | .3315 | .3315 | .3315 |
| 23 | .2652 | .3978 | .2652 | .3315 | .3315 | .2652 | .3315 |
| 24 | .1989 | .5304 | .5304 | .5304 | .1989 | .2652 | .2652 |
| **Max** | **.9945** | **.9282** | **.7956** | **.8619** | **.9945** | **1.0608** | **.9945** |
| **Min** | **.1989** | **.1326** | **.1989** | **.1326** | **.1989** | **.2652** | **.1989** |
| **Avg** | **.5649** | **.4213** | **.4388** | **.4201** | **.5621** | **.5877** | **.5580** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214431 / 33/11 KV HOL**
**Feeder No / Name : 203 / 11 KV SASTEWADI SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7773 | .0554 | .0486 | .0739 | .9717 | .9979 | .9069 |
| 2 | .7773 | .0554 | .0648 | .0739 | .9717 | .9979 | .9069 |
| 3 | .8745 | .0554 | .0648 | .0739 | 1.0364 | .9979 | .9393 |
| 4 | 1.0364 | .0554 | .0648 | .0739 | 1.1012 | 1.1088 | .9393 |
| 5 | 1.1012 | .0739 | .081 | .0739 | 1.1336 | 1.3121 | .9717 |
| 6 | 1.166 | .0924 | .0972 | .1109 | 1.1498 | 1.46 | 1.1984 |
| 7 | 1.1822 | .1109 | .108 | .1109 | 1.3927 | 1.5524 | 1.2793 |
| 8 | .0648 | .0739 | .108 | .0924 | .0648 | .1109 | .081 |
| 9 | .081 | 1.4969 | 1.5586 | 1.7187 | .0648 | .0739 | .081 |
| 10 | | 1.4198 | 1.6204 | 1.5432 | .0463 | .0617 | .0617 |
| 11 | | 1.5741 | 1.6975 | 1.713 | .0617 | .0463 | .0617 |
| 12 | .0463 | 1.6204 | 1.6975 | 1.5895 | .0617 | .0463 | .0617 |
| 13 | .0617 | 1.5895 | 1.6975 | 1.6204 | .0617 | .0463 | .0617 |
| 14 | .0463 | 1.6049 | 1.6512 | 1.6667 | .0772 | .0463 | .0617 |
| 15 | .0617 | 1.4815 | 1.6358 | 1.5278 | .0772 | .0617 | .0463 |
| 16 | .0617 | 1.5278 | 1.5432 | 1.4661 | .108 | .0772 | .0926 |
| 17 | .0463 | .0617 | .0617 | .0617 | .0617 | .0617 | .0463 |
| 18 | .1478 | .081 | .0924 | .0924 | .0924 | .081 | .0739 |
| 19 | .0739 | .081 | .0924 | | .0924 | .081 | .0924 |
| 20 | .0739 | .081 | .0924 | .0972 | .0924 | .0648 | .0924 |
| 21 | .0739 | .0648 | .0924 | .081 | .0924 | .0648 | .0739 |
| 22 | .0739 | .0625 | .0924 | .0324 | .0739 | .0648 | .0739 |
| 23 | .0739 | .0486 | .0924 | .0648 | .0739 | .0648 | .0924 |
| 24 | .7449 | .0554 | .0486 | .0739 | .9393 | .9425 | .8907 |
| **Max** | **1.1822** | **1.6204** | **1.6975** | **1.7187** | **1.3927** | **1.5524** | **1.2793** |
| **Min** | **.0463** | **.0486** | **.0486** | **.0324** | **.0463** | **.0463** | **.0463** |
| **Avg** | **.3930** | **.5593** | **.6002** | **.6101** | **.4125** | **.4343** | **.3828** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214431 / 33/11 KV HOL**
**Feeder No / Name : 204 / 11KV Chopadaj SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .506 | .1848 | .1265 | .2218 | .7432 | .7392 | .6009 |
| 2 | .5376 | .1848 | .1898 | .2218 | .6958 | .7392 | .6009 |
| 3 | .6009 | .1848 | .2214 | .2218 | .759 | .7392 | .6009 |
| 4 | .6325 | .2218 | .2846 | .2957 | .8223 | .7762 | .6009 |
| 5 | .6958 | .3326 | .3163 | .3696 | .8539 | .8131 | .6009 |
| 6 | .6958 | .5544 | .3479 | .5544 | .9172 | .9979 | .8223 |
| 7 | .7274 | .6283 | .3795 | .6653 | 1.0437 | 1.1458 | .8855 |
| 8 | .4744 | .5544 | | .5544 | .4111 | .6283 | .4744 |
| 9 | .2214 | 1.0456 | | 1.2197 | .3795 | .5175 | .3795 |
| 10 | .2214 | 1.012 | | 1.1069 | .253 | .2846 | .253 |
| 11 | .1898 | 1.012 | .9488 | 1.2018 | .253 | .1898 | .2214 |
| 12 | .1581 | 1.1069 | 1.0753 | 1.1702 | .2214 | .1265 | .1581 |
| 13 | .1265 | 1.1385 | 1.0437 | 1.1069 | | .2214 | .1265 |
| 14 | .1581 | 1.1069 | 1.1702 | 1.1702 | .1898 | .2214 | .1265 |
| 15 | .1581 | .9804 | 1.1385 | 1.2018 | .2214 | .2214 | .1581 |
| 16 | .1265 | .9172 | 1.1702 | 1.1069 | .2214 | .2214 | .1581 |
| 17 | .1898 | .1898 | .2214 | .1898 | .253 | .2214 | .1581 |
| 18 | .4066 | .2214 | .4435 | .4435 | .5175 | .2846 | .4066 |
| 19 | .4435 | .2846 | .4435 | .3795 | .4435 | .3795 | .4435 |
| 20 | .4066 | .3795 | .3696 | .3795 | .4066 | .3479 | .3696 |
| 21 | .3326 | .3795 | .3326 | .3479 | .3696 | .2846 | .3326 |
| 22 | .2587 | .3479 | .2957 | .253 | .2587 | .2214 | .2218 |
| 23 | .1848 | .2214 | .2587 | .2214 | .2587 | .2214 | .2218 |
| 24 | .4744 | .1848 | .0949 | .2218 | .6325 | .7023 | .6009 |
| **Max** | **.7274** | **1.1385** | **1.1702** | **1.2197** | **1.0437** | **1.1458** | **.8855** |
| **Min** | **.1265** | **.1848** | **.0949** | **.1898** | **.1898** | **.1265** | **.1265** |
| **Avg** | **.3720** | **.5573** | **.5177** | **.6177** | **.4837** | **.4686** | **.3968** |

Date:- 05-02-18

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214431 / 33/11 KV HOL**
**Feeder No / Name : 205 / 11 KV LOKHANDWADI SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1326 | .8215 | .663 | .7468 | .1326 | .2801 | .1326 |
| 2 | .1326 | .8215 | .7293 | .7468 | .1326 | .2801 | .1326 |
| 3 | .1326 | .8215 | .7956 | .7842 | .1326 | .3361 | .1326 |
| 4 | .1326 | .8962 | .8619 | .9335 | .1989 | .4108 | .1326 |
| 5 | .1989 | 1.0829 | .9945 | 1.0829 | .2652 | .5228 | .1989 |
| 6 | .1989 | 1.307 | 1.0608 | 1.3256 | .3315 | .6722 | .2652 |
| 7 | .1989 | 1.5684 | 1.0364 | 1.6617 | .2652 | .7282 | .3315 |
| 8 | .1989 | .4108 | | .3734 | .1989 | .5041 | .1989 |
| 9 | 1.326 | .2801 | | .2987 | 1.2597 | 1.3817 | 1.2597 |
| 10 | 1.5708 | .1629 | | .2534 | 1.5708 | 1.4575 | 1.3927 |
| 11 | 1.5061 | .0724 | .2172 | .1991 | 1.7004 | 1.4737 | 1.3603 |
| 12 | 1.6194 | .0724 | .1629 | .1991 | 1.8138 | 1.4899 | 1.4737 |
| 13 | 1.5708 | .0724 | .0724 | .181 | 1.7328 | 1.5061 | 1.1984 |
| 14 | 1.4251 | .0724 | .1629 | .1448 | 1.6356 | 1.5223 | 1.3117 |
| 15 | 1.3117 | | .1448 | .1448 | 1.4737 | 1.4737 | 1.3603 |
| 16 | 1.3603 | .0724 | .0724 | .0724 | 1.3927 | 1.3765 | 1.1822 |
| 17 | .1629 | .1448 | .1991 | .2534 | | .2353 | .2715 |
| 18 | .3734 | .1989 | .4294 | .4481 | .4294 | .2652 | .5415 |
| 19 | .4668 | .2652 | .4481 | .3978 | .4481 | .3315 | .5601 |
| 20 | .3734 | .3315 | .4108 | .3978 | .4108 | .2652 | .5041 |
| 21 | .3174 | .3315 | .3547 | .3315 | .3734 | .2155 | .4481 |
| 22 | .2801 | .2652 | .2614 | .2652 | .3361 | .2155 | .3734 |
| 23 | .2241 | .1326 | | .1989 | .2987 | .1326 | .3547 |
| 24 | .1326 | .7655 | .5967 | .6908 | .1326 | .2801 | .1326 |
| **Max** | **1.6194** | **1.5684** | **1.0608** | **1.6617** | **1.8138** | **1.5223** | **1.4737** |
| **Min** | **.1326** | **.0724** | **.0724** | **.0724** | **.1326** | **.1326** | **.1326** |
| **Avg** | **.6395** | **.4770** | **.4837** | **.5055** | **.7246** | **.7232** | **.6354** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214431 / 33/11 KV HOL**
**Feeder No / Name : 206 / 11 KV Korhale KH single SINGLE PHASING**
**Phasin Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5636 | 1.8233 | 1.7238 | 1.7404 | .5636 | .5636 | .5636 |
| 2 | .6299 | 1.8233 | 1.8896 | 1.7404 | .6299 | .5636 | .6299 |
| 3 | .7293 | 1.8233 | 1.9559 | 1.7404 | .7293 | .6299 | .7293 |
| 4 | .7956 | 1.8233 | 1.989 | 1.7901 | .8951 | .6962 | .7293 |
| 5 | .8951 | 1.9062 | 2.0553 | 1.8896 | .9614 | .8453 | .779 |
| 6 | .9945 | 2.0056 | 2.0885 | 1.9559 | 1.0111 | 1.0608 | 1.0608 |
| 7 | 1.0774 | 2.1216 | .7459 | 2.1051 | .9614 | 1.1105 | 1.094 |
| 8 | .8619 | .779 | .7459 | .7625 | .9282 | .9448 | .8951 |
| 9 | 2.2874 | .663 | .6133 | .6299 | 2.1382 | 2.1714 | 2.1216 |
| 10 | 2.3537 | .4641 | .431 | .4475 | 2.3703 | 2.2211 | 2.2377 |
| 11 | 2.3371 | .3647 | .3812 | .3812 | 2.42 | 2.1548 | 2.2045 |
| 12 | 2.3371 | .3315 | .3315 | .3149 | 2.4531 | 2.2377 | 2.1216 |
| 13 | 2.3205 | .2984 | .3315 | .2652 | 2.4531 | 2.1714 | 2.0885 |
| 14 | 2.3537 | .2486 | .3149 | .2652 | 2.3537 | 2.1382 | 2.0388 |
| 15 | 2.2377 | .2818 | .3149 | .2818 | 2.3868 | 2.1051 | 2.0388 |
| 16 | 2.1879 | .431 | .3978 | .3647 | 2.3205 | 2.0553 | 1.6244 |
| 17 | .4475 | .547 | .4475 | .4641 | .4641 | .4807 | .4807 |
| 18 | .779 | .5636 | .8122 | | .8619 | .5636 | .8453 |
| 19 | .8288 | .7293 | .8619 | .7956 | .7459 | .7293 | .7956 |
| 20 | .7293 | .7956 | .7459 | .7956 | .6962 | .6299 | .6962 |
| 21 | .6464 | .8619 | .6962 | .7293 | .663 | .5967 | .6299 |
| 22 | .5967 | .7293 | .5967 | .663 | .5967 | .5636 | .5801 |
| 23 | .547 | .5304 | .5636 | .6299 | .5636 | .5304 | .547 |
| 24 | .5304 | 1.7238 | 1.6907 | 1.7072 | .5304 | .5636 | .5138 |
| **Max** | **2.3537** | **2.1216** | **2.0885** | **2.1051** | **2.4531** | **2.2377** | **2.2377** |
| **Min** | **.4475** | **.2486** | **.3149** | **.2652** | **.4641** | **.4807** | **.4807** |
| **Avg** | **1.2528** | **.9862** | **.9469** | **.9765** | **1.2791** | **1.1803** | **1.1686** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214462 / 33/11 KV MURUM**
**Feeder No / Name : 201 / 11 KV Karkhana Single phasing Feeder KV- 11 / OUTGOING** **SINGLE PHASING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3277 | .3113 | .5735 | .4458 | .6718 | .3277 | .4096 |
| 2 | .3277 | .3277 | .5735 | .6718 | .6554 | .3277 | .426 |
| 3 | .3932 | | .5898 | .7209 | .6718 | .3932 | .4588 |
| 4 | .4752 | .4588 | .6554 | .78 | .7373 | .4915 | .4915 |
| 5 | .5735 | .5898 | .8029 | .852 | .852 | .6226 | .5407 |
| 6 | .7209 | .7209 | .9831 | .9995 | 1.0322 | .7209 | .6718 |
| 7 | .8192 | .9012 | 1.1142 | 1.1797 | 1.1961 | .7865 | .8987 |
| 8 | .6554 | .7209 | .6554 | .639 | .7209 | .7209 | .6718 |
| 9 | 1.0486 | 1.1305 | .5735 | .6226 | .6062 | 1.1797 | 1.1305 |
| 10 | 1.3435 | 1.3108 | .5138 | .426 | .4588 | 1.278 | 1.3108 |
| 11 | 1.3599 | 1.3108 | .4588 | .4096 | .5228 | 1.3108 | 1.3599 |
| 12 | 1.3763 | 1.2452 | .4096 | .426 | .4481 | 1.3272 | 1.278 |
| 13 | 1.3108 | 1.2452 | .3768 | .4096 | .4481 | 1.278 | 1.2616 |
| 14 | 1.2616 | 1.2289 | .3605 | .426 | .3932 | 1.2289 | 1.2125 |
| 15 | 1.2452 | 1.1797 | .4024 | .4096 | .3932 | 1.2209 | 1.1797 |
| 16 | 1.2125 | 1.2452 | .4096 | .4752 | .426 | 1.1797 | 1.0486 |
| 17 | .4424 | *** | | .4424 | .4424 | .5243 | .4752 |
| 18 | .5898 | .6554 | .5735 | .639 | .6554 | .6299 | .6226 |
| 19 | .7537 | .7865 | .7865 | .7537 | .6718 | .6613 | .6554 |
| 20 | .6554 | .6554 | .7209 | .6554 | .6882 | .6718 | .6882 |
| 21 | .5571 | .6062 | .6104 | .6062 | .5243 | .6226 | .6226 |
| 22 | .4588 | .4915 | .4915 | .4588 | .4588 | .5079 | .5079 |
| 23 | .3605 | .3605 | .4588 | .3277 | .426 | .4588 | .4096 |
| 24 | .3277 | .3113 | .5898 | .3605 | .6718 | .3277 | .3768 |
| **Max** | **1.3763** | **42.6003** | **1.1142** | **1.1797** | **1.1961** | **1.3272** | **1.3599** |
| **Min** | **.3277** | **.3113** | **.3605** | **.3277** | **.3932** | **.3277** | **.3768** |
| **Avg** | **.7749** | **2.6258** | **.5950** | **.5890** | **.6155** | **.7833** | **.7795** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214462 / 33/11 KV MURUM**
**Feeder No / Name : 202 / 11 KV Malashi Single Phasing Feeder KV- 11 / OUTGOING** **SINGLE PHASING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5571 | .4915 | .1475 | .1638 | .1638 | .5243 | .57 |
| 2 | .5571 | .4915 | .1475 | .1638 | .1638 | .5243 | .5571 |
| 3 | .5898 | .5079 | .1638 | .1966 | .1802 | .5735 | .5898 |
| 4 | .6226 | .5243 | .213 | .2294 | .1966 | .5898 | .6062 |
| 5 | .6718 | .5735 | .2622 | .2622 | .2458 | .6226 | .639 |
| 6 | .7209 | .6882 | .3441 | .3441 | .3277 | .6554 | .6718 |
| 7 | .7865 | .852 | .4096 | .4096 | .3932 | .7209 | .7611 |
| 8 | .3605 | .3605 | .3113 | .3441 | .426 | .3932 | .3932 |
| 9 | .1966 | .2622 | .7209 | .7373 | .8356 | .2294 | .2622 |
| 10 | .1966 | .1966 | .8029 | .9503 | .9175 | .1802 | .1966 |
| 11 | .1802 | .1966 | .8356 | 1.0486 | .852 | .1658 | .1802 |
| 12 | .1638 | .1475 | .8684 | .9831 | .9175 | .1802 | .1802 |
| 13 | .1966 | .1966 | .9012 | .9503 | .7865 | .1638 | .1475 |
| 14 | .1475 | .1638 | .9175 | .9012 | .7865 | .1475 | .1966 |
| 15 | .1638 | .1802 | .8848 | .7865 | .7537 | .1638 | .1475 |
| 16 | .1802 | .213 | .9012 | .8356 | .7209 | .1966 | .1638 |
| 17 | .2294 | .1966 | | .2294 | .213 | .213 | .213 |
| 18 | .2622 | .2949 | .2949 | .2949 | .3113 | .2785 | .2622 |
| 19 | .3113 | .3277 | .3277 | .3605 | .2949 | .2785 | .2785 |
| 20 | .3441 | .3277 | .3113 | .3277 | .2949 | .2949 | .2949 |
| 21 | .2949 | .2785 | .2949 | .2949 | .2622 | .3113 | .2785 |
| 22 | .2458 | .2294 | .2622 | .2458 | .2294 | .2949 | .2294 |
| 23 | .1966 | .1966 | .2294 | .1966 | .1966 | .2622 | .1966 |
| 24 | .5735 | .4915 | .1475 | .1802 | .1638 | .5243 | .5079 |
| **Max** | **.7865** | **.852** | **.9175** | **1.0486** | **.9175** | **.7209** | **.7611** |
| **Min** | **.1475** | **.1475** | **.1475** | **.1638** | **.1638** | **.1475** | **.1475** |
| **Avg** | **.3646** | **.3495** | **.4652** | **.4765** | **.4431** | **.3537** | **.3552** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214462 / 33/11 KV MURUM**
**Feeder No / Name : 203 / 11 KV Murum Single phasing SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.1797 | 1.1797 | .285 | .3113 | .2949 | 1.4419 | 1.065 |
| 2 | 1.1797 | 1.1633 | .2683 | .3277 | .2785 | 1.4582 | 1.1142 |
| 3 | 1.2289 | 1.1469 | .285 | .3605 | .2949 | 1.5402 | 1.1633 |
| 4 | 1.278 | 1.1797 | .3353 | .3932 | .3277 | 1.5402 | 1.2289 |
| 5 | 1.3272 | 1.2289 | .4862 | .4409 | .4096 | 1.6057 | 1.3426 |
| 6 | 1.3763 | 1.2944 | .6203 | .5735 | .5571 | 1.704 | 1.4255 |
| 7 | 1.6057 | 1.3435 | .6706 | .7209 | .639 | 1.8351 | 1.491 |
| 8 | .5735 | .6062 | .6539 | .5571 | .639 | .639 | .5898 |
| 9 | .426 | .4191 | 1.4419 | 1.8351 | 2.1792 | .3605 | .4096 |
| 10 | .2785 | .285 | 1.8233 | 2.2119 | 2.0972 | .2949 | .2949 |
| 11 | .2622 | .2683 | 1.8564 | 2.2283 | 2.0317 | .2294 | .2622 |
| 12 | .2949 | .2347 | 1.8515 | 2.2447 | 2.0972 | .2622 | .2622 |
| 13 | .2622 | .285 | 1.9006 | 2.13 | 2.0317 | .2785 | .2294 |
| 14 | .2458 | .2515 | 1.9498 | 2.13 | 1.9662 | .2622 | .2458 |
| 15 | .2622 | .2683 | 1.9989 | 1.9989 | 1.9334 | .2785 | .2458 |
| 16 | .2949 | .3018 | 1.9662 | 1.9826 | 1.9006 | .2949 | .2785 |
| 17 | .3277 | .285 | | .3113 | .2949 | .3149 | .2949 |
| 18 | .3768 | .4359 | .3768 | .3605 | .4588 | .3932 | .426 |
| 19 | .4915 | .503 | .4748 | .5079 | .4588 | .426 | .4588 |
| 20 | .4915 | .4862 | .4752 | .4752 | .4915 | .4752 | .4915 |
| 21 | .4588 | .4191 | .4915 | .4424 | .426 | .426 | .4424 |
| 22 | .3932 | .3521 | .3932 | .3605 | .3768 | .3932 | .3932 |
| 23 | .3277 | .3185 | .3441 | .3277 | .3277 | .3856 | .2785 |
| 24 | 1.1797 | | .285 | .3018 | .2949 | 1.4419 | 1.0442 |
| **Max** | **1.6057** | **1.3435** | **1.9989** | **2.2447** | **2.1792** | **1.8351** | **1.491** |
| **Min** | **.2458** | **.2347** | **.2683** | **.3018** | **.2785** | **.2294** | **.2294** |
| **Avg** | **.6718** | **.6198** | **.9232** | **.9806** | **.9503** | **.7617** | **.6449** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214462 / 33/11 KV MURUM**
**Feeder No / Name : 204 / 11 KV Shinde Express NON SHEDDABLE EXPRESS HV FEEDERS**
**Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4481 | .3734 | .3547 | .4294 | .3921 | .5788 | .4294 |
| 2 | .4108 | .3921 | .3734 | .4294 | .3734 | .5601 | .4294 |
| 3 | .3921 | .3921 | .3734 | .4481 | .3734 | .5228 | .4481 |
| 4 | .3734 | .3921 | .3734 | .4481 | .3921 | .5415 | .4668 |
| 5 | .4108 | .4108 | .3921 | .4668 | .3921 | .5601 | .5228 |
| 6 | .3734 | .3921 | .3921 | .4668 | .3921 | .5415 | .4854 |
| 7 | .4108 | .3921 | .2987 | .4481 | .3921 | .5228 | .4854 |
| 8 | .4668 | .4108 | .3921 | .4668 | .3921 | .4108 | .4481 |
| 9 | .3921 | .4294 | .4294 | .3734 | .4294 | .4424 | .4668 |
| 10 | .4108 | .5041 | .4108 | .5415 | .5228 | .5228 | .5041 |
| 11 | .5041 | .4854 | .4294 | .5415 | .5041 | .5415 | .5228 |
| 12 | .5041 | .4801 | .4481 | .5601 | .5415 | .5228 | .5228 |
| 13 | .5041 | .5228 | .4668 | .5601 | .4668 | .5228 | .5415 |
| 14 | .5041 | .5041 | .4294 | .5415 | .5041 | .5415 | .5415 |
| 15 | .5041 | .5041 | .4294 | .4294 | .5228 | .5228 | .5415 |
| 16 | .5788 | .5041 | .4481 | .5415 | .5228 | | .5415 |
| 17 | .5041 | .5415 | | .5415 | .4854 | .5228 | .5601 |
| 18 | .4481 | .3547 | .4481 | .5228 | .5228 | .5041 | .5601 |
| 19 | .4481 | .3174 | .4294 | .5041 | .4854 | .426 | .5601 |
| 20 | .3734 | .3361 | .3921 | .4668 | .4108 | .426 | .5415 |
| 21 | .4854 | .3734 | .3921 | .4108 | .3921 | .4481 | .5041 |
| 22 | .4854 | .3734 | .3734 | .4108 | .3734 | .4481 | .5041 |
| 23 | .4108 | .3547 | .3921 | .4108 | .3921 | .4481 | .5041 |
| 24 | .4481 | .3921 | .3547 | .3441 | .4108 | .5788 | .3921 |
| **Max** | **.5788** | **.5415** | **.4668** | **.5601** | **.5415** | **.5788** | **.5601** |
| **Min** | **.3734** | **.3174** | **.2987** | **.3441** | **.3734** | **.4108** | **.3921** |
| **Avg** | **.4497** | **.4222** | **.4010** | **.4710** | **.4411** | **.5068** | **.5010** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214462 / 33/11 KV MURUM**
**Feeder No / Name : 205 / 11KV Wayalpatta single phasing Feeder KV- 11 / OUTGOING SINGLE PHASING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1638 | .1638 | .5407 | .3932 | .4424 | .1802 | .1802 |
| 2 | .1638 | .1802 | .5243 | .426 | .4424 | .1802 | .2204 |
| 3 | .1966 | .1966 | .5407 | .4409 | .4588 | .1966 | .2294 |
| 4 | .2622 | .2622 | .5735 | .4588 | .4915 | .2294 | .2294 |
| 5 | .2949 | .3113 | .6062 | .4752 | .5735 | .2785 | .2713 |
| 6 | .3605 | .3768 | .6718 | .5079 | .6554 | .3277 | .3277 |
| 7 | .3605 | .426 | .7701 | .6718 | .8684 | .3932 | .3856 |
| 8 | .3605 | .3768 | .2949 | .3315 | .3605 | .3605 | .3277 |
| 9 | .852 | .9175 | .3113 | .2949 | .2949 | .9831 | .9995 |
| 10 | .9995 | .9503 | .2458 | .2622 | .1802 | 1.0486 | 1.0486 |
| 11 | .9012 | .9831 | .1966 | .1966 | .213 | 1.0159 | .9503 |
| 12 | .9503 | .9012 | .1677 | .1802 | .1311 | .8848 | .9831 |
| 13 | .9503 | .8848 | .1638 | .1475 | .1638 | .9995 | .9339 |
| 14 | .9339 | .8848 | .1509 | .1475 | .1638 | 1.0322 | .9175 |
| 15 | .9667 | .852 | .1475 | .1638 | .1638 | 1.0486 | .9012 |
| 16 | .9831 | .852 | .1696 | .1966 | .1638 | 1.1469 | .639 |
| 17 | .213 | .1638 | | .2294 | .1966 | .213 | .2294 |
| 18 | .2949 | .3113 | .3113 | .2785 | .2949 | .2294 | .3441 |
| 19 | .3441 | .3277 | .39 | .3277 | .2785 | .2458 | .3277 |
| 20 | .2785 | .2785 | .373 | .2622 | .2458 | .2458 | .2949 |
| 21 | .2458 | .2622 | .2591 | .213 | .2294 | .2294 | .2458 |
| 22 | .1966 | .2294 | .1966 | .1802 | .1966 | .213 | .213 |
| 23 | .1802 | .1966 | .1966 | .1638 | .1802 | .1966 | .1966 |
| 24 | .1638 | .1638 | .5407 | .3932 | .4424 | .1802 | .1802 |
| **Max** | **.9995** | **.9831** | **.7701** | **.6718** | **.8684** | **1.1469** | **1.0486** |
| **Min** | **.1638** | **.1638** | **.1475** | **.1475** | **.1311** | **.1802** | **.1802** |
| **Avg** | **.4840** | **.4772** | **.3627** | **.3059** | **.3263** | **.5025** | **.4824** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214473 / 33/11 KV WADGAON NIMBALKAR**
**Feeder No / Name : 201 / 11 KV Chilaimala Ag SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0701 | .3353 | .2538 | .3048 | .2606 | .0886 | .0537 |
| 2 | .0532 | .3353 | .2572 | .3048 | .2972 | .0716 | .0537 |
| 3 | .0532 | .3201 | .2641 | .3048 | .301 | .0716 | .0537 |
| 4 | .0709 | .3201 | .2934 | .3048 | .3048 | .0895 | .0537 |
| 5 | .0709 | .3353 | .2934 | .3201 | .3161 | .0895 | .0732 |
| 6 | .0716 | .3506 | .3227 | .3506 | .3281 | .1075 | .0724 |
| 7 | .1063 | .3658 | .3864 | .4115 | .3353 | .124 | .0934 |
| 8 | .0838 | .0857 | .0724 | .0857 | .0566 | .1227 | .0895 |
| 9 | .5201 | .0686 | .0914 | .0514 | .0566 | .431 | .5182 |
| 10 | .6401 | .0671 | .1097 | .0819 | .0895 | .5498 | .6401 |
| 11 | .6249 | .0829 | .1029 | .0829 | .1063 | .5944 | .6249 |
| 12 | .6249 | .1029 | .1029 | .0829 | .1052 | .602 | .6097 |
| 13 | .5944 | .1006 | .0857 | .0983 | .104 | .5719 | .6097 |
| 14 | .6097 | .1147 | .0857 | .116 | | .6097 | .5639 |
| 15 | .5944 | .0983 | .0857 | .0857 | .1017 | .6249 | .5944 |
| 16 | .5182 | | .0857 | .0943 | .1029 | .5639 | .5792 |
| 17 | .0663 | .1006 | .0857 | .0701 | .104 | .0343 | .0514 |
| 18 | .0663 | .1029 | .0857 | .0686 | .1052 | .0526 | .0514 |
| 19 | .0686 | .1052 | .1029 | .0876 | .1227 | .0886 | .0514 |
| 20 | .0686 | .1052 | .1029 | .0709 | .1227 | .0876 | .0514 |
| 21 | .0686 | .0886 | .0857 | .0857 | .1227 | .0886 | .0514 |
| 22 | .0514 | .0867 | .0857 | .0709 | .1227 | .0709 | .0514 |
| 23 | .0514 | .0848 | .0857 | .0701 | .1052 | .0526 | .0514 |
| 24 | .0686 | .3201 | .2679 | .2743 | .2675 | .1063 | .0537 |
| **Max** | **.6401** | **.3658** | **.3864** | **.4115** | **.3353** | **.6249** | **.6401** |
| **Min** | **.0514** | **.0671** | **.0724** | **.0514** | **.0566** | **.0343** | **.0514** |
| **Avg** | **.2424** | **.1773** | **.1581** | **.1616** | **.1712** | **.2456** | **.2374** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214473 / 33/11 KV WADGAON NIMBALKAR**
**Feeder No / Name : 202 / 11 KV Wadgaon GFSS GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2241 | .2012 | .2427 | .2241 | .2241 | .2378 | .2587 |
| 2 | .2218 | .2012 | .2452 | .2241 | .2218 | .2378 | .2402 |
| 3 | .2218 | .2195 | .2452 | .2427 | .2587 | .2378 | .2587 |
| 4 | .2587 | .2772 | .2378 | .2801 | .2957 | .2561 | .2926 |
| 5 | .3326 | .3547 | .3077 | .3547 | .3361 | .3258 | .3403 |
| 6 | .4435 | .4294 | .3982 | .4668 | .4251 | .4298 | .4755 |
| 7 | .5041 | .5415 | .5138 | .5041 | .5544 | .5138 | .5788 |
| 8 | .5359 | .5068 | | .4755 | .4801 | .4681 | .5175 |
| 9 | .3881 | .4298 | | .3224 | .4481 | .4755 | .4435 |
| 10 | .3361 | .3696 | | .2987 | .3439 | .3696 | .3506 |
| 11 | .2507 | .3018 | .3142 | | .3326 | .2987 | .2804 |
| 12 | .2507 | .2452 | .2801 | .3361 | .2641 | .2534 | .2686 |
| 13 | .2058 | .2263 | .2241 | .2987 | .2263 | .2241 | .2279 |
| 14 | .1886 | .2075 | .2801 | .2587 | .3018 | .2172 | .2241 |
| 15 | .1886 | .2075 | .2801 | .2614 | .3018 | .2402 | .2286 |
| 16 | .2229 | .2075 | .2801 | .2957 | .2829 | .2402 | .2477 |
| 17 | .2987 | .3018 | .3174 | .2957 | .3018 | .3109 | .3174 |
| 18 | .3696 | .415 | .4294 | .3326 | .3361 | .3696 | .3881 |
| 19 | .3439 | .4344 | .4294 | .4668 | .439 | .4294 | .4163 |
| 20 | .3801 | .4024 | | .4435 | .4024 | .4066 | .3881 |
| 21 | .3475 | .3841 | .3696 | .3696 | .3475 | .3696 | .3658 |
| 22 | .2715 | .3361 | .3326 | .3361 | .3109 | .3361 | .3109 |
| 23 | .2279 | .2614 | .2402 | .2561 | .2743 | .2614 | .2587 |
| 24 | .2218 | .2012 | .2452 | .2195 | .2218 | .2561 | .2587 |
| **Max** | **.5359** | **.5415** | **.5138** | **.5041** | **.5544** | **.5138** | **.5788** |
| **Min** | **.1886** | **.2012** | **.2241** | **.2195** | **.2218** | **.2172** | **.2241** |
| **Avg** | **.3015** | **.3193** | **.3107** | **.3289** | **.3305** | **.3236** | **.3307** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214473 / 33/11 KV WADGAON NIMBALKAR**
**Feeder No / Name : 203 / 11 KV CHOUDHARWADI GFSS GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2957 | .2401 | .2454 | .2507 | .2587 | .2926 | .2957 |
| 2 | .2587 | .2507 | .2481 | .2561 | .2561 | .2926 | .2587 |
| 3 | .2957 | .2686 | .2715 | .2957 | .2534 | .2957 | .2587 |
| 4 | .3734 | .3292 | .3109 | .3547 | .3326 | .3326 | .3292 |
| 5 | .4854 | .4294 | .4435 | .4481 | .4481 | .4294 | .4755 |
| 6 | .6535 | .6908 | .6348 | .7095 | .6468 | .6535 | .695 |
| 7 | .7655 | .7468 | .7282 | .7842 | .7655 | .7023 | .7655 |
| 8 | .6653 | .6335 | .5544 | .591 | .7095 | .6653 | .7023 |
| 9 | .4668 | .4477 | .4481 | | .462 | .4525 | .4294 |
| 10 | .3429 | .3812 | .3475 | .4251 | .3439 | .439 | .3086 |
| 11 | .2984 | .3239 | .3189 | | .3189 | .3326 | .2949 |
| 12 | .2652 | .3125 | .3189 | .3881 | .2804 | .2957 | |
| 13 | .2622 | .2778 | .3086 | .3292 | .2743 | .2402 | .2785 |
| 14 | .2721 | .2286 | .3258 | .2957 | .2683 | .2987 | .2721 |
| 15 | .2721 | .2343 | .3258 | .2957 | .2622 | .3547 | .25 |
| 16 | .2656 | .2688 | .3086 | .3142 | .2949 | .3881 | .25 |
| 17 | .3563 | .3185 | .3086 | .3142 | .3315 | .4294 | .3086 |
| 18 | .4382 | .4075 | .4298 | .4066 | .3814 | .4805 | .4252 |
| 19 | .5194 | .5121 | .543 | .5175 | .4938 | .5228 | .4835 |
| 20 | .4733 | .4938 | .4706 | .462 | .4755 | .4805 | .4755 |
| 21 | .4115 | .4525 | .4298 | .3734 | .4344 | .4108 | .4115 |
| 22 | .3601 | .3467 | .3429 | .3326 | .3982 | .3511 | .3601 |
| 23 | .2984 | .2515 | .3086 | .2987 | .3582 | .2987 | .2915 |
| 24 | .2926 | .2572 | .2374 | .2507 | .2614 | .3224 | .2957 |
| **Max** | **.7655** | **.7468** | **.7282** | **.7842** | **.7655** | **.7023** | **.7655** |
| **Min** | **.2587** | **.2286** | **.2374** | **.2507** | **.2534** | **.2402** | **.25** |
| **Avg** | **.3912** | **.3793** | **.3837** | **.3952** | **.3879** | **.4067** | **.3876** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214473 / 33/11 KV WADGAON NIMBALKAR**
**Feeder No / Name : 204 / 11 KV Wadgaon Ag SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1478 | .7362 | .7316 | .7811 | .7865 | .2195 | .1494 |
| 2 | .1433 | .7362 | .7011 | .8002 | .8322 | .2218 | .1478 |
| 3 | .1478 | .7362 | .7407 | .8002 | .8322 | .2218 | .1478 |
| 4 | .1478 | .7362 | .7499 | | .8322 | .2218 | .1478 |
| 5 | .2218 | .7682 | .7499 | .8322 | .9175 | .2587 | .1494 |
| 6 | .2241 | .8421 | .8749 | .8962 | .9175 | .2957 | .1478 |
| 7 | .2172 | 1.0242 | 1.012 | 1.0242 | 1.0753 | .2926 | .2218 |
| 8 | .2172 | .1463 | .1463 | .1402 | .1494 | .2896 | .2241 |
| 9 | 1.0883 | .2195 | .2195 | .2058 | .2241 | .9998 | 1.39 |
| 10 | 1.2498 | .2149 | .2218 | .2218 | .2926 | 1.3108 | 1.2498 |
| 11 | 1.2651 | .2149 | .2172 | .1478 | .2561 | 1.2803 | 1.2193 |
| 12 | 1.1873 | .2126 | .2561 | .1478 | .2172 | 1.3443 | 1.2193 |
| 13 | 1.1584 | .2507 | .2561 | .1478 | .2149 | 1.3108 | 1.2803 |
| 14 | 1.2803 | .2865 | .2534 | .1494 | .2149 | 1.2803 | 1.0669 |
| 15 | 1.1888 | .2865 | .2534 | .1478 | .2126 | 1.3108 | 1.2193 |
| 16 | 1.1873 | .2896 | .2534 | .1448 | .2149 | 1.2803 | 1.1888 |
| 17 | .2058 | .2926 | .2534 | .1478 | .2172 | .2172 | .1448 |
| 18 | .2149 | .2957 | .2534 | .1448 | .2534 | .2195 | .1448 |
| 19 | .2896 | .2957 | .2534 | .2172 | .2926 | .2172 | .2218 |
| 20 | .2896 | .2926 | .2195 | .2218 | .2926 | .2172 | .2218 |
| 21 | .2172 | .2896 | .2195 | .2218 | .2926 | .2195 | |
| 22 | .2172 | .2896 | .2195 | .2172 | .2926 | | .1848 |
| 23 | .2195 | .2865 | .2195 | .2195 | .2561 | .1494 | .1848 |
| 24 | .1448 | .7042 | .7225 | .7316 | .7865 | .2561 | .1463 |
| **Max** | **1.2803** | **1.0242** | **1.012** | **1.0242** | **1.0753** | **1.3443** | **1.39** |
| **Min** | **.1433** | **.1463** | **.1463** | **.1402** | **.1494** | **.1494** | **.1448** |
| **Avg** | **.5363** | **.4353** | **.4166** | **.3787** | **.4531** | **.5928** | **.5399** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214473 / 33/11 KV WADGAON NIMBALKAR**
**Feeder No / Name : 205 / 11 KV MUDHALE SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6653 | 1.0117 | 1.1271 | 1.1401 | 1.1012 | .679 | .6653 |
| 2 | .6348 | 1.0117 | 1.2407 | 1.1401 | 1.1797 | .679 | .6219 |
| 3 | .6283 | 1.0288 | 1.3565 | 1.2003 | 1.2125 | .679 | .6283 |
| 4 | .7468 | | 1.4243 | 1.406 | 1.3108 | .7922 | .7316 |
| 5 | .9709 | 1.3375 | 1.5261 | 1.6095 | 1.5249 | .9808 | .9511 |
| 6 | 1.2567 | 1.6632 | 1.7804 | 1.9113 | 1.6712 | 1.2826 | 1.2197 |
| 7 | 1.307 | 1.9376 | 2.1091 | 2.146 | 2.0481 | 1.2323 | 1.251 |
| 8 | 1.0719 | .9979 | 1.1016 | .9335 | .9795 | 1.0269 | 1.1088 |
| 9 | 1.7124 | .6838 | .8299 | .7468 | .6535 | 1.7269 | 1.9589 |
| 10 | 1.989 | .5228 | .5658 | .5359 | .5601 | 2.0005 | 1.9725 |
| 11 | 2.1382 | .462 | .462 | .3696 | .4108 | 2.1376 | 2.0553 |
| 12 | 1.9662 | .4251 | .4251 | .3696 | .3547 | 2.1956 | 2.0056 |
| 13 | 2.146 | .4066 | .4294 | .3361 | .3361 | 1.9334 | 1.9393 |
| 14 | 2.0719 | .3696 | .4294 | .2772 | .3547 | 1.9433 | 1.5249 |
| 15 | 1.9989 | .3696 | .4481 | .2957 | .3511 | 2.0481 | 1.7072 |
| 16 | 1.8187 | .3881 | .462 | .3361 | .3696 | 2.0081 | 1.6575 |
| 17 | .462 | .499 | .499 | .3696 | .3841 | .4024 | .3696 |
| 18 | .8131 | .7655 | .7655 | .5228 | .5544 | .695 | .7842 |
| 19 | 1.1576 | 1.0456 | 1.0642 | 1.0269 | .9149 | 1.0082 | 1.0829 |
| 20 | 1.0829 | 1.0082 | 1.0456 | .9522 | .9709 | .924 | 1.0082 |
| 21 | .9335 | .8676 | .9709 | .8589 | .8299 | .8779 | .8962 |
| 22 | .7842 | .7922 | .8215 | .7392 | .7922 | .7762 | .8029 |
| 23 | .7356 | .7356 | .7655 | .6653 | .7545 | .7095 | .7356 |
| 24 | .6653 | .9602 | .9614 | 1.073 | 1.0814 | .7167 | .6653 |
| **Max** | **2.146** | **1.9376** | **2.1091** | **2.146** | **2.0481** | **2.1956** | **2.0553** |
| **Min** | **.462** | **.3696** | **.4251** | **.2772** | **.3361** | **.4024** | **.3696** |
| **Avg** | **1.2399** | **.8387** | **.9421** | **.8734** | **.8625** | **1.2273** | **1.1810** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214473 / 33/11 KV WADGAON NIMBALKAR**
**Feeder No / Name : 206 / 11 KV DAREKAR MALA SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0377 | .6642 | .6401 | .6401 | .5506 | .0377 | .0566 |
| 2 | .0377 | .6722 | .6481 | .6097 | .5898 | .0377 | .0566 |
| 3 | .0377 | .6562 | .6874 | .6097 | .5898 | .0377 | .0754 |
| 4 | .0377 | .6562 | .703 | .6097 | .5898 | .0566 | .0754 |
| 5 | .0566 | .6722 | .6944 | .6097 | .6401 | .0754 | .0754 |
| 6 | .0566 | .6882 | .7253 | .6249 | .6401 | .0943 | .0754 |
| 7 | .0754 | .7042 | .7811 | .6706 | .7209 | .0754 | .0934 |
| 8 | .0754 | .056 | .0566 | .056 | .0747 | .0754 | .0943 |
| 9 | .8192 | .0747 | .0566 | .056 | .0566 | .7716 | .9175 |
| 10 | .8078 | .0566 | .0377 | .0566 | .0566 | .9012 | .8688 |
| 11 | .8078 | .0377 | .0566 | .0754 | .0566 | .9717 | .884 |
| 12 | .8383 | .0377 | .0566 | .0566 | .0377 | 1.0719 | .9145 |
| 13 | .7926 | .0377 | .0377 | .0377 | .0377 | .8802 | .8993 |
| 14 | .8535 | .0377 | .0377 | .0189 | .0377 | .9012 | .7621 |
| 15 | .8535 | .0377 | .0377 | .0189 | .0377 | .9602 | .823 |
| 16 | .8535 | .0377 | .0377 | .0377 | .0377 | .9231 | .884 |
| 17 | .0373 | .0566 | .0377 | .0377 | .0566 | .0377 | .0566 |
| 18 | .0754 | .0566 | .0566 | .0377 | .0566 | .0566 | .0566 |
| 19 | .0943 | .0754 | .0566 | .0566 | .0754 | .0754 | .0943 |
| 20 | .0566 | .0754 | .0754 | .0754 | .0754 | .0566 | .0754 |
| 21 | .0566 | .0566 | .0566 | .0566 | .0754 | .0566 | .0754 |
| 22 | .0566 | .0566 | .0566 | .0377 | .0754 | .0377 | .0566 |
| 23 | .0566 | .0566 | .0566 | .0377 | .0566 | .056 | .0566 |
| 24 | .0377 | .6401 | .6321 | .6249 | .5571 | .0377 | .0566 |
| **Max** | **.8535** | **.7042** | **.7811** | **.6706** | **.7209** | **1.0719** | **.9175** |
| **Min** | **.0373** | **.0377** | **.0377** | **.0189** | **.0377** | **.0377** | **.0566** |
| **Avg** | **.3130** | **.2584** | **.2634** | **.2397** | **.2409** | **.3452** | **.3368** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214496 / 33/11KV Korhale S/Stn.**
**Feeder No / Name : 201 / 11 KV Late Ag SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1143 | .9145 | .8573 | .8573 | .8573 | .1143 | .0857 |
| 2 | .1143 | | .8573 | .8573 | .8573 | .1143 | .0857 |
| 3 | .1143 | | .8573 | .8573 | .8573 | .1143 | .0857 |
| 4 | .1334 | | .8573 | .8573 | .8764 | .1143 | .0857 |
| 5 | .1334 | | .9259 | .9526 | .9145 | .1334 | .1029 |
| 6 | .1524 | | .9431 | .9717 | 1.0098 | .1524 | .1372 |
| 7 | .1715 | | 1.1488 | 1.2955 | 1.1812 | .1524 | .12 |
| 8 | .1524 | | .12 | .1143 | .1143 | .1334 | .0857 |
| 9 | | .0686 | .1029 | .0762 | .0953 | .1029 | 1.448 |
| 10 | 1.4861 | | .0686 | .0572 | .0762 | 1.4575 | 1.5623 |
| 11 | 1.5813 | .0514 | .0514 | .0572 | .0572 | 1.5604 | 1.6766 |
| 12 | 1.5623 | | | .0572 | .0572 | 1.5432 | 1.5623 |
| 13 | 1.5432 | .0514 | .0514 | .0572 | .0381 | 1.4746 | 1.3908 |
| 14 | 1.3717 | .0514 | .0514 | .0572 | .0381 | 1.5089 | |
| 15 | 1.4098 | .0686 | .0514 | .0572 | .0381 | 1.4575 | 1.448 |
| 16 | 1.448 | .0686 | .0343 | .0572 | .0381 | 1.4746 | 1.3717 |
| 17 | .0572 | .0686 | .0514 | .0953 | .0572 | .0686 | .0572 |
| 18 | .1334 | .12 | .0953 | .1334 | .1143 | .0857 | .0762 |
| 19 | .1334 | .1372 | .1334 | .1524 | .1143 | .12 | .1143 |
| 20 | .1334 | .1372 | .1334 | .1524 | .1334 | .1029 | .1334 |
| 21 | .1334 | .12 | .1334 | .1334 | .1143 | .1029 | .1143 |
| 22 | .0953 | .12 | .1143 | .1334 | .0953 | .1029 | .1143 |
| 23 | .0953 | .1029 | .1143 | .1334 | .1143 | .1029 | .1143 |
| 24 | .1143 | .9145 | .823 | .8573 | .8383 | .1143 | .0857 |
| **Max** | **1.5813** | **.9145** | **1.1488** | **1.2955** | **1.1812** | **1.5604** | **1.6766** |
| **Min** | **.0572** | **.0514** | **.0343** | **.0572** | **.0381** | **.0686** | **.0572** |
| **Avg** | **.5384** | **.1997** | **.3729** | **.3763** | **.3620** | **.5170** | **.5243** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214496 / 33/11KV Korhale S/Stn.**
**Feeder No / Name : 202 / 11 KV Korhale Ag SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.1812 | .2477 | .1715 | .1905 | .1905 | 1.2955 | 1.0974 |
| 2 | 1.1812 | .2477 | .1715 | .1905 | .1905 | 1.2955 | 1.0974 |
| 3 | 1.1812 | .2477 | .1715 | .1905 | .1905 | 1.2955 | 1.0974 |
| 4 | 1.2193 | .2477 | .1715 | .1905 | .2286 | 1.3336 | 1.1145 |
| 5 | 1.2765 | .2667 | .1886 | .2096 | .2667 | 1.3908 | 1.166 |
| 6 | | .2858 | .2401 | .2858 | .2667 | 1.448 | 1.2003 |
| 7 | 1.467 | .3048 | .2572 | .2667 | .2667 | 1.5623 | 1.406 |
| 8 | .1905 | .2667 | .1715 | .2286 | .2286 | .1905 | .1715 |
| 9 | | 1.3375 | 1.5432 | 1.6385 | | .1372 | .1334 |
| 10 | .1143 | 1.5432 | 1.5604 | 1.7528 | | .0857 | .1143 |
| 11 | .0762 | 1.7318 | 1.5775 | 2.0576 | 1.0669 | .0857 | .1143 |
| 12 | .0762 | 1.749 | 1.6632 | 2.0005 | 1.7528 | .0857 | .0953 |
| 13 | .0953 | 1.7661 | 1.6632 | 1.8671 | 1.8099 | .0514 | .0953 |
| 14 | .1143 | 1.6632 | 1.7147 | 1.848 | 1.9052 | .0686 | |
| 15 | .0762 | 1.7147 | 1.6461 | 1.829 | 1.9052 | .0686 | .0953 |
| 16 | .0762 | 1.6461 | 1.5947 | 1.5242 | 1.829 | .0686 | .0953 |
| 17 | .1143 | .0857 | .0686 | .1143 | .0953 | .1029 | .0953 |
| 18 | .1905 | .1372 | .1905 | .1524 | .0762 | .1372 | .1334 |
| 19 | .2667 | .1886 | .2096 | .2286 | .1905 | .1886 | .1524 |
| 20 | .2667 | .2058 | .2477 | .2096 | .2096 | .1886 | .1905 |
| 21 | .2477 | .2058 | .2286 | .1905 | .2096 | .1715 | .1905 |
| 22 | .2477 | .2058 | .2096 | .1905 | .1905 | .1715 | .1905 |
| 23 | .2477 | .1715 | .1905 | .1715 | .1905 | .1715 | .1905 |
| 24 | 1.1812 | .2477 | .1715 | .1905 | .1905 | 1.2955 | 1.0974 |
| **Max** | **1.467** | **1.7661** | **1.7147** | **2.0576** | **1.9052** | **1.5623** | **1.406** |
| **Min** | **.0762** | **.0857** | **.0686** | **.1143** | **.0762** | **.0514** | **.0953** |
| **Avg** | **.5040** | **.6964** | **.6676** | **.7383** | **.6114** | **.5371** | **.4928** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214496 / 33/11KV Korhale S/Stn.**
**Feeder No / Name : 203 / 11KV Kurnewadi single SINGLE PHASING**
**Phasing Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5716 | .381 | .3772 | .4001 | .5335 | .6859 | .6173 |
| 2 | .5716 | .381 | .3772 | .4001 | .5335 | .6859 | .6173 |
| 3 | .5716 | .381 | .3772 | .4001 | .5335 | .6859 | .6173 |
| 4 | .6668 | .5525 | .4458 | .4001 | .6097 | .8002 | .6859 |
| 5 | .724 | .724 | .6516 | .7621 | .724 | .9526 | .8573 |
| 6 | .8002 | .7621 | .8916 | 1.0288 | 1.0288 | 1.1812 | 1.0288 |
| 7 | 1.0669 | 1.0669 | .9259 | .9145 | 1.0288 | 1.3717 | 1.166 |
| 8 | .724 | .8383 | .7545 | .8002 | .8002 | .8002 | .703 |
| 9 | | .9945 | 1.0974 | 1.3336 | 1.5242 | .4458 | .4572 |
| 10 | .381 | 1.0631 | 1.3032 | 1.3717 | 1.5242 | .3429 | .3429 |
| 11 | .3048 | 1.0631 | 1.3032 | 1.3527 | 1.5242 | .2401 | .2858 |
| 12 | .2667 | 1.2346 | 1.2003 | 1.2574 | 1.5242 | .2058 | .2286 |
| 13 | .1905 | 1.2689 | 1.3375 | 1.4098 | 1.4861 | .1715 | .2477 |
| 14 | .2286 | 1.2003 | 1.3375 | 1.448 | 1.448 | .2058 | |
| 15 | .2286 | 1.0631 | 1.2003 | 1.4861 | 1.448 | .2058 | .2667 |
| 16 | .2667 | 1.166 | 1.166 | | 1.4861 | .2058 | .3048 |
| 17 | .381 | .3601 | .3601 | .6097 | .3048 | .463 | .381 |
| 18 | .6859 | .5487 | .6668 | .6478 | .6287 | .5316 | .4763 |
| 19 | .8383 | .7373 | .8002 | .8383 | .7621 | .6859 | .7621 |
| 20 | .8002 | .6516 | .724 | .8192 | .7049 | .6344 | .724 |
| 21 | .6097 | .583 | .6478 | .8002 | .6287 | .5487 | .6097 |
| 22 | .4954 | .4801 | .5335 | .724 | .5144 | .463 | .4954 |
| 23 | .4954 | .3772 | .4572 | .6097 | .4572 | .3944 | .4572 |
| 24 | .5716 | .381 | .3601 | .4001 | .5335 | .6859 | .6001 |
| **Max** | **1.0669** | **1.2689** | **1.3375** | **1.4861** | **1.5242** | **1.3717** | **1.166** |
| **Min** | **.1905** | **.3601** | **.3601** | **.4001** | **.3048** | **.1715** | **.2286** |
| **Avg** | **.5409** | **.7608** | **.8040** | **.8789** | **.9288** | **.5664** | **.5623** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214496 / 33/11KV Korhale S/Stn.**
**Feeder No / Name : 204 / MATKARWASTI SEPARATED AG FEEDERS HAVING SPECIAL**
**Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8383 | .0572 | .0514 | .0572 | .0572 | .8954 | .823 |
| 2 | .8383 | .0572 | .0686 | .0572 | .0572 | .8954 | .823 |
| 3 | .8383 | .0572 | .0686 | .0572 | .0572 | .8954 | .823 |
| 4 | .8573 | .1143 | .0686 | .0572 | .0572 | .8954 | .823 |
| 5 | .8764 | .1143 | .0857 | .0572 | .0762 | .9335 | .8573 |
| 6 | .8954 | .1143 | .0857 | .0762 | .0762 | .9907 | .8916 |
| 7 | 1.105 | .1143 | .1029 | .0762 | .0762 | 1.2193 | 1.0802 |
| 8 | .1143 | .1143 | .1029 | .0572 | .0572 | .1143 | .1029 |
| 9 | | 1.2003 | 1.3375 | 1.6385 | 1.4861 | .0857 | .0953 |
| 10 | .0762 | 1.4918 | 1.6804 | 1.7528 | 1.5623 | .0686 | .0953 |
| 11 | .0762 | 1.6975 | 1.749 | 1.9052 | 1.7337 | .0514 | .0953 |
| 12 | .0572 | 1.6461 | 1.749 | 1.9243 | 1.9433 | .0514 | .0762 |
| 13 | .0572 | 1.6804 | 1.6632 | 1.8671 | 1.7718 | .0514 | .0572 |
| 14 | .0572 | 1.6804 | 1.6118 | 1.8861 | 1.7909 | .0514 | |
| 15 | .0762 | 1.6461 | 1.3717 | 1.7909 | 1.7909 | .0686 | .0572 |
| 16 | .0762 | 1.5089 | 1.3717 | 1.6575 | 1.6575 | .0686 | .0572 |
| 17 | .0953 | .0857 | .0514 | .0572 | .0572 | .0686 | .0762 |
| 18 | .1143 | .0857 | .0953 | .0762 | .0953 | .0857 | .0762 |
| 19 | .0762 | .12 | .0762 | .0762 | .0762 | .1029 | .0953 |
| 20 | .1143 | .1029 | .0762 | .0762 | .0762 | .0686 | .0762 |
| 21 | .0953 | .0686 | .0762 | .0762 | .0762 | .0686 | .0762 |
| 22 | .0953 | .0686 | .0762 | .0572 | .0762 | .0686 | .0762 |
| 23 | .0953 | .0514 | .0572 | .0572 | .0762 | .0514 | .0762 |
| 24 | .8383 | .0572 | .0514 | .0572 | .0572 | .8954 | .7888 |
| **Max** | **1.105** | **1.6975** | **1.749** | **1.9243** | **1.9433** | **1.2193** | **1.0802** |
| **Min** | **.0572** | **.0514** | **.0514** | **.0572** | **.0572** | **.0514** | **.0572** |
| **Avg** | **.3637** | **.5806** | **.5720** | **.6438** | **.6184** | **.3644** | **.3521** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214496 / 33/11KV Korhale S/Stn.**
**Feeder No / Name : 205 / 11 KV BAJARANGWADI GFSS GAOTHAN FEEDER**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4001 | .381 | .3772 | .4191 | .4954 | .4191 | .3429 |
| 2 | .4001 | .381 | .3772 | .4191 | .4954 | .4191 | .3601 |
| 3 | .4001 | .381 | .3772 | .4191 | .4954 | .4191 | .3772 |
| 4 | .5525 | .5525 | .4287 | .5716 | .5335 | .5716 | .4115 |
| 5 | .7049 | .7049 | .6173 | .7621 | .724 | .724 | .6001 |
| 6 | .9145 | .7049 | .8402 | .9526 | .8573 | .9526 | .7716 |
| 7 | .9717 | .743 | .8916 | .7621 | .8764 | .9907 | .8059 |
| 8 | .8192 | .7621 | .7202 | .724 | .8383 | .7811 | .6687 |
| 9 | | .5487 | .5144 | .6097 | .6287 | .5487 | .4954 |
| 10 | .5335 | .4458 | .4801 | .5144 | .5716 | .4801 | .4572 |
| 11 | .4763 | .4115 | .4458 | .4954 | .5335 | .4115 | .4572 |
| 12 | .4001 | .3772 | .3944 | .4572 | .4191 | .3772 | .4572 |
| 13 | .4191 | .3601 | .3429 | .4382 | .4572 | .3429 | .4001 |
| 14 | .4191 | .3429 | .3429 | .4382 | .4572 | .3258 | |
| 15 | .4382 | .3601 | .3429 | .4572 | .4382 | .3258 | .381 |
| 16 | .4382 | .4115 | .3944 | .4001 | .4763 | .3429 | .381 |
| 17 | .4763 | .463 | .4973 | .4763 | .5144 | .4458 | .4954 |
| 18 | .6668 | .6001 | .6287 | .5335 | .6097 | .6001 | .5716 |
| 19 | .6859 | .6173 | .724 | .6668 | .6478 | .6173 | .6287 |
| 20 | .6668 | .6001 | .6478 | .724 | .6478 | .5658 | .6478 |
| 21 | .5335 | .5487 | .5906 | .7049 | .6097 | .5144 | .6097 |
| 22 | .4763 | .4287 | | .6097 | .5144 | .4458 | .4763 |
| 23 | .4191 | .3944 | .4954 | .4954 | .4763 | .3944 | .4572 |
| 24 | .4001 | .381 | .3601 | .4191 | .4954 | .4191 | .3601 |
| **Max** | **.9717** | **.7621** | **.8916** | **.9526** | **.8764** | **.9907** | **.8059** |
| **Min** | **.4001** | **.3429** | **.3429** | **.4001** | **.4191** | **.3258** | **.3429** |
| **Avg** | **.5484** | **.4959** | **.5144** | **.5612** | **.5755** | **.5181** | **.5050** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214524 / 33/11 KV Morgaon**
**Feeder No / Name : 201 / mayureshwar SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2075 | .2614 | .1029 | .1219 | .1134 | .2401 | .2241 |
| 2 | .2075 | .2614 | .1029 | .1219 | .1619 | .2401 | .2241 |
| 3 | .2075 | .2987 | .1029 | .1219 | .1781 | .2572 | .2241 |
| 4 | .2075 | .2987 | .1029 | .1372 | .1943 | .2743 | .2241 |
| 5 | .3206 | .3361 | .1524 | | .2105 | .3086 | .2801 |
| 6 | .415 | .3361 | .2286 | .1524 | .2105 | .3258 | .4108 |
| 7 | .4108 | .3921 | .2286 | .2286 | .2591 | .3601 | |
| 8 | .2812 | .3734 | .2572 | .2743 | .3086 | .3547 | .3734 |
| 9 | .1943 | .1781 | .2401 | .2915 | .2915 | .1875 | .1875 |
| 10 | .2105 | .1677 | .2572 | .2801 | .2572 | .25 | .1677 |
| 11 | .2267 | .1524 | .2378 | .3361 | .2229 | .2031 | .1677 |
| 12 | .2105 | .1677 | .2427 | .2987 | .2058 | .2343 | .1677 |
| 13 | .2429 | .1677 | .2427 | .3174 | .2058 | .192 | .1677 |
| 14 | .1619 | .1677 | .2241 | .2987 | .2058 | .2241 | .1829 |
| 15 | .1781 | .1829 | .2427 | .2801 | .2229 | .2401 | .1981 |
| 16 | .1619 | .1981 | .2427 | .2614 | .2229 | .2401 | .1829 |
| 17 | .2987 | .2743 | .2987 | .2427 | .2401 | .2801 | .2401 |
| 18 | .3547 | .2743 | .3734 | .3361 | .3086 | .3361 | .3086 |
| 19 | .4481 | .3601 | .4481 | .4481 | .3601 | .3361 | .1886 |
| 20 | .3734 | .3429 | .3734 | .4108 | .3429 | .3547 | .3258 |
| 21 | .3734 | .3258 | .3086 | .3734 | .3086 | .3361 | .2915 |
| 22 | .3361 | .2401 | .2572 | .3361 | .2743 | .2987 | .2572 |
| 23 | .2614 | .1886 | .2058 | .3361 | .2572 | .2241 | .2401 |
| 24 | .2075 | .2614 | .081 | .1219 | .1134 | .2401 | .2241 |
| **Max** | **.4481** | **.3921** | **.4481** | **.4481** | **.3601** | **.3601** | **.4108** |
| **Min** | **.1619** | **.1524** | **.081** | **.1219** | **.1134** | **.1875** | **.1677** |
| **Avg** | **.2707** | **.2587** | **.2314** | **.2664** | **.2365** | **.2724** | **.2373** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214524 / 33/11 KV Morgaon**
**Feeder No / Name : 202 / RADHAKRISHNA SINGLE PHASING**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0943 | .0934 | .1219 | .1219 | .0648 | .12 | .1307 |
| 2 | .0943 | .0934 | .1219 | .1219 | .0972 | .12 | .1307 |
| 3 | .0943 | .1494 | .1219 | .1524 | .1943 | .12 | .1307 |
| 4 | .1132 | .1867 | .1219 | .1829 | .2429 | .1372 | .1307 |
| 5 | .2241 | .2241 | .2439 | .1981 | .2591 | .1715 | .1867 |
| 6 | .2614 | .2614 | .3048 | .2439 | .2753 | .2229 | .2427 |
| 7 | .2801 | .2801 | .3201 | .3353 | .3887 | .2572 | .2987 |
| 8 | .1406 | .1867 | .1372 | .1981 | .2572 | .1886 | .1867 |
| 9 | .421 | .3239 | .1543 | .1372 | .1372 | .3281 | .3734 |
| 10 | .4858 | .381 | .12 | .0934 | .1372 | .3281 | .4115 |
| 11 | .421 | .2286 | .0914 | .112 | .1372 | .4374 | .381 |
| 12 | .4534 | .4115 | .0934 | .1307 | .1029 | .4374 | .3506 |
| 13 | .4049 | .4115 | .112 | .0934 | .1372 | .4481 | .3658 |
| 14 | .3887 | .381 | .112 | .0934 | .1029 | .4321 | .3506 |
| 15 | .3401 | .3658 | .112 | .0934 | .12 | .4001 | .3506 |
| 16 | .3401 | .3506 | .112 | .112 | .1372 | .4001 | .2896 |
| 17 | .112 | .1029 | .1494 | .112 | .1029 | .1494 | .1886 |
| 18 | .1494 | .1372 | .1867 | .1867 | .1715 | .168 | .2229 |
| 19 | .2054 | .2058 | .2241 | .2427 | .1886 | .2054 | .2572 |
| 20 | .1867 | .1715 | .2241 | .2241 | .1886 | .2054 | .1886 |
| 21 | .1867 | .1543 | .1715 | .2054 | .1715 | .1867 | .1543 |
| 22 | .1494 | .12 | .1372 | .1494 | .1372 | .168 | .1543 |
| 23 | .0934 | .1029 | .1029 | .1494 | .12 | | |
| 24 | .0943 | .0934 | .081 | .0914 | .0648 | .12 | .1307 |
| **Max** | **.4858** | **.4115** | **.3201** | **.3353** | **.3887** | **.4481** | **.4115** |
| **Min** | **.0934** | **.0934** | **.081** | **.0914** | **.0648** | **.12** | **.1307** |
| **Avg** | **.2389** | **.2257** | **.1532** | **.1575** | **.1640** | **.2501** | **.2438** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214524 / 33/11 KV Morgaon**
**Feeder No / Name : 203 / 11 KV MANGOBACHI WADI SHEDDABLE RURAL**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1698 | .0934 | | .4268 | .3239 | .1372 | .1307 |
| 2 | .1698 | .0934 | .4572 | .4877 | .421 | .1372 | .1307 |
| 3 | .1698 | .1494 | .4572 | .4877 | .4858 | .1372 | .1307 |
| 4 | .1698 | .1867 | .4572 | .5182 | .5506 | .1543 | .1307 |
| 5 | .2054 | .1867 | .6097 | .5792 | .583 | .1715 | .1867 |
| 6 | .2241 | .2054 | .7011 | .6401 | .6154 | .2229 | .2241 |
| 7 | .2427 | .2241 | .7468 | .9145 | .8583 | .2058 | .2427 |
| 8 | .1562 | .168 | .12 | .1219 | .1543 | .1372 | .168 |
| 9 | .7935 | .8259 | .12 | .0857 | .1029 | .8436 | .6249 |
| 10 | 1.0526 | 1.0364 | .1029 | .0934 | .0686 | 1.0467 | .8078 |
| 11 | 1.085 | 1.1431 | .0914 | .0747 | .0514 | 1.0936 | .8078 |
| 12 | 1.2146 | 1.2346 | .0934 | .0747 | .0686 | 1.1873 | .8078 |
| 13 | 1.2308 | 1.1126 | .0934 | .0747 | .0686 | 1.1523 | .8383 |
| 14 | 1.166 | 1.0974 | .0934 | .0747 | .0686 | 1.1523 | .7926 |
| 15 | 1.0688 | 1.0822 | .0934 | .0747 | .0686 | 1.1683 | .7468 |
| 16 | 1.085 | 1.0669 | .0934 | .0747 | .0686 | 1.0883 | .7316 |
| 17 | .0934 | .0857 | .0934 | .0747 | | .0934 | .1029 |
| 18 | .0934 | .0857 | .1307 | .1494 | .1372 | .1867 | .1715 |
| 19 | .1867 | .1715 | .1867 | .1867 | .1886 | .1867 | |
| 20 | .1867 | .1543 | .1867 | .1867 | .1715 | .1867 | .1543 |
| 21 | .1494 | .1372 | .1543 | .1867 | .1543 | .1867 | .1543 |
| 22 | .1307 | .1372 | .1543 | .1494 | .1543 | .168 | .1543 |
| 23 | .0934 | .1372 | .1372 | .1494 | .1372 | .1494 | .1543 |
| 24 | .1698 | .0934 | .3563 | .3353 | .3239 | .1372 | .1307 |
| **Max** | **1.2308** | **1.2346** | **.7468** | **.9145** | **.8583** | **1.1873** | **.8383** |
| **Min** | **.0934** | **.0857** | **.0914** | **.0747** | **.0514** | **.0934** | **.1029** |
| **Avg** | **.4711** | **.4545** | **.2491** | **.2592** | **.2533** | **.4721** | **.3706** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214525 / 33/11 KV Nimbut**
**Feeder No / Name : 201 / 11 KV Baramati Agro Express Fe Feeder KV- 11 / OUTGOING**

**NON SHEDDABLE EXPRESS HV FEEDERS (CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2572 | | .2401 | | | | .1886 |
| 2 | .2572 | | .2572 | .2401 | .2401 | | .1715 |
| 4 | | | | .2743 | .2743 | | |
| 5 | .2915 | | .2915 | | | | .2401 |
| 6 | .2915 | | .3086 | .2743 | .3086 | | .2572 |
| 7 | .3086 | | .3258 | | | | .2743 |
| 8 | .2915 | | | .2743 | .2401 | | .2572 |
| 9 | .2915 | | | | | | .2229 |
| 10 | .2743 | .3086 | .2572 | .3086 | .2401 | .2572 | .2058 |
| 11 | | .2915 | | | | | .2058 |
| 12 | | .2743 | .2743 | .2743 | | .2229 | .2229 |
| 13 | | .3429 | | | | | .2401 |
| 14 | | .2743 | .3086 | .2401 | | .2058 | .2058 |
| 15 | | .2915 | | | | | .1886 |
| 16 | | .3258 | .2743 | .2743 | | .2401 | .2229 |
| 17 | | .3086 | | | | | .2058 |
| 18 | | .2743 | .2743 | | | .2572 | |
| 19 | | .2572 | | | | .2401 | |
| 20 | | .2572 | .2743 | | | .2229 | |
| 21 | | .2572 | | | | .2058 | |
| 22 | | .2401 | .3086 | | | .1886 | |
| 23 | | .2401 | | | | .1886 | |
| 24 | .2401 | | .2229 | .2401 | .2401 | | .1715 |
| **Max** | **.3086** | **.3429** | **.3258** | **.3086** | **.3086** | **.2572** | **.2743** |
| **Min** | **.2401** | **.2401** | **.2229** | **.2401** | **.2401** | **.1886** | **.1715** |
| **Avg** | **.2782** | **.2817** | **.2783** | **.2667** | **.2572** | **.2229** | **.2176** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214525 / 33/11 KV Nimbut**
**Feeder No / Name : 202 / 11 KV CHAUDHARWADI AG SHEDDABLE RURAL**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.2003 | | 1.166 | | | | 1.1317 |
| 2 | 1.2346 | | 1.3032 | .1029 | .1029 | | 1.1831 |
| 4 | | | | .0857 | .1029 | | |
| 5 | 1.6461 | | 1.6289 | | | | 1.4403 |
| 6 | 1.7147 | | 1.7147 | .1029 | .1372 | | 1.6461 |
| 7 | 1.749 | | 1.749 | | | | 1.7318 |
| 8 | .1029 | | | .1372 | .1372 | | .0514 |
| 9 | .0857 | | | | | | .0514 |
| 10 | .0857 | .0857 | 2.2805 | 2.4006 | 2.572 | .1372 | .0686 |
| 11 | | .0857 | | | | | .0686 |
| 12 | | .0857 | 2.4006 | 1.8861 | | .1029 | .0686 |
| 13 | | .0857 | | | | | .1029 |
| 14 | | .0857 | 2.2462 | 2.5377 | | .0686 | |
| 15 | | .0857 | | | | | .0857 |
| 16 | | .1029 | 2.2291 | 2.4006 | | .1029 | .0857 |
| 17 | | .0857 | | | | | .0857 |
| 18 | | .0857 | .0686 | .1372 | | .1029 | |
| 19 | | .1029 | | | | .12 | |
| 20 | | .1029 | .0686 | .1029 | | .12 | |
| 21 | | .12 | | | | .1029 | |
| 22 | .1029 | .12 | .0857 | .1372 | | .12 | |
| 23 | | .12 | | | | .1029 | |
| 24 | 1.166 | | 1.0288 | .1029 | .1029 | | 1.0974 |
| **Max** | **1.749** | **.12** | **2.4006** | **2.5377** | **2.572** | **.1372** | **1.7318** |
| **Min** | **.0857** | **.0857** | **.0686** | **.0857** | **.1029** | **.0686** | **.0514** |
| **Avg** | **.9088** | **.0967** | **1.3823** | **.8445** | **.5259** | **.1080** | **.5933** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214525 / 33/11 KV Nimbut**
**Feeder No / Name : 203 / 11 KV GADADARWADI SHEDDABLE RURAL**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0514 | | .0686 | | | | |
| 2 | .0686 | | .0686 | .8573 | .8745 | | |
| 4 | | | | .9431 | .8916 | | |
| 5 | .0514 | | .0857 | | | | .0171 |
| 6 | .0514 | | .0686 | 1.1145 | .9259 | | .0171 |
| 7 | .0686 | | .0857 | | | | .0171 |
| 8 | .0686 | | | 1.2003 | 1.0631 | | .0171 |
| 9 | 1.2346 | | | | | | 1.286 |
| 10 | 1.3203 | | .0686 | .0686 | .0343 | 1.286 | 1.3889 |
| 11 | | 1.4232 | | | | | 1.3546 |
| 12 | | 1.4746 | .0343 | .0514 | | 1.3889 | 1.3032 |
| 13 | | 1.3717 | | | | | 1.3203 |
| 14 | | 1.4918 | .0343 | .0686 | | .1029 | 1.2689 |
| 15 | | 1.4575 | | | | | 1.2003 |
| 16 | | 1.406 | .1029 | .0343 | | .1029 | 1.166 |
| 17 | | .0514 | | | | | .0514 |
| 18 | | .0686 | .0686 | | | .0343 | |
| 19 | | .0514 | | | | .0171 | |
| 20 | | .0514 | .0686 | | | .0171 | |
| 21 | | .0343 | | | | .0171 | |
| 22 | | .0343 | .0686 | | | | |
| 23 | | .0514 | | | | | |
| 24 | .0514 | | .0686 | .823 | .823 | | |
| **Max** | **1.3203** | **1.4918** | **.1029** | **1.2003** | **1.0631** | **1.3889** | **1.3889** |
| **Min** | **.0514** | **.0343** | **.0343** | **.0343** | **.0343** | **.0171** | **.0171** |
| **Avg** | **.3296** | **.6898** | **.0686** | **.5735** | **.7687** | **.3708** | **.8006** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214525 / 33/11 KV Nimbut**
**Feeder No / Name : 204 / 11 KV SORTEWADI AG SHEDDABLE RURAL**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.2003 | | 1.0802 | | | | 1.1145 |
| 2 | 1.2346 | | 1.1145 | .1372 | .1029 | | 1.1831 |
| 4 | | | | .12 | .0857 | | |
| 5 | 1.3717 | | 1.3375 | | | | 1.3375 |
| 6 | 1.4575 | | 1.3546 | .1372 | .1029 | | 1.3717 |
| 7 | 1.5432 | | 1.3717 | | | | 1.406 |
| 8 | .1029 | | | .1715 | .1372 | | .1029 |
| 9 | .12 | | | | | | .1029 |
| 10 | .1372 | .1372 | 1.8519 | 2.0576 | 2.0576 | .1372 | .12 |
| 11 | | .0857 | | | | | |
| 12 | | .0514 | 2.0576 | 1.8861 | | .1029 | .12 |
| 13 | | .0343 | | | | | .12 |
| 14 | | .0343 | 1.8861 | 1.7147 | | .1029 | .1029 |
| 15 | | .0343 | | | | | .1029 |
| 16 | | .0514 | 1.749 | 1.8861 | | .1029 | .1029 |
| 17 | | .0343 | | | | | .0857 |
| 18 | | .3944 | .1029 | | | .12 | |
| 19 | | .1029 | | | | .1372 | |
| 20 | | .12 | .1372 | | | .12 | |
| 21 | | .1372 | | | | .1372 | |
| 22 | | | .1029 | | | .1543 | |
| 23 | | .1372 | | | | .1372 | |
| 24 | 1.166 | | 1.0631 | .1372 | .1029 | | 1.0974 |
| **Max** | **1.5432** | **.3944** | **2.0576** | **2.0576** | **2.0576** | **.1543** | **1.406** |
| **Min** | **.1029** | **.0343** | **.1029** | **.12** | **.0857** | **.1029** | **.0857** |
| **Avg** | **.9259** | **.1042** | **1.1699** | **.9164** | **.4315** | **.1252** | **.5647** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 214525 / 33/11 KV Nimbut**
**Feeder No / Name : 205 / 11 KV NIMBUT AG SHEDDABLE RURAL**
**Feeder KV- 11 / OUTGOING**

| DATE | 29-NOV-17 | 30-NOV-17 | 01-DEC-17 | 02-DEC-17 | 03-DEC-17 | 04-DEC-17 | 05-DEC-17 |
|---|---|---|---|---|---|---|---|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0343 | | .0686 | | | | .0514 |
| 2 | .0343 | | .0514 | .8916 | 1.0288 | | .0686 |
| 4 | | | | .9431 | .8745 | | |
| 5 | .0343 | | .0686 | | | | .0514 |
| 6 | | | .0514 | 1.0117 | 1.0288 | | .0686 |
| 7 | .0343 | | .0514 | | | | .0686 |
| 8 | .0343 | | | 1.0288 | 1.0288 | | .0686 |
| 9 | .9259 | | | | | | 1.0288 |
| 10 | | 1.0631 | .0686 | .0686 | .0686 | 1.0288 | 1.1317 |
| 11 | | 1.0974 | | | | | 1.1145 |
| 12 | | 1.1317 | .0343 | .0343 | | 1.046 | 1.0974 |
| 13 | | 1.0631 | | | | | 1.1317 |
| 14 | | 1.1145 | .0343 | .0343 | | 1.0288 | 1.0974 |
| 15 | | 1.1145 | | | | | 1.0631 |
| 16 | | 1.1145 | .0343 | .0343 | | 1.1145 | 1.046 |
| 17 | | .0343 | | | | | .0343 |
| 18 | | .0343 | .0686 | | | .0514 | |
| 19 | | .0343 | | | | .0514 | |
| 20 | | .0343 | .0514 | | | .0514 | |
| 21 | | .0343 | | | | .0514 | |
| 22 | | .0514 | .0343 | | | .0514 | |
| 23 | | .0514 | | | | .0514 | |
| 24 | .0343 | | .0686 | .8573 | .9431 | | .0514 |
| **Max** | **.9259** | **1.1317** | **.0686** | **1.0288** | **1.0288** | **1.1145** | **1.1317** |
| **Min** | **.0343** | **.0343** | **.0343** | **.0343** | **.0686** | **.0514** | **.0343** |
| **Avg** | **.1617** | **.5695** | **.0528** | **.5449** | **.8288** | **.4527** | **.5733** |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 217047 / 132KV Someshwar**
**Feeder No / Name : 401 / 33/11 KV MURUM s/stn Incommer Feeder KV- 33 / INCOMING**

**NON SHEDDABLE EXPRESS HV FEEDERS (NON-CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | .543 |
| Max | .543 |
| Min | .543 |
| Avg | .543 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 217047 / 132KV Someshwar**
**Feeder No / Name : 402 / 33/11 KV HOL substation Incom Feeder KV- 33 / OUTGOING**

**NON SHEDDABLE EXPRESS HV FEEDERS (NON-CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 12 | .7716 |
| 24 | .4201 |
| Max | .7716 |
| Min | .4201 |
| Avg | .5959 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 217047 / 132KV Someshwar**
**Feeder No / Name : 403 / 33/11 KV Korhale INCOMER NON SHEDDABLE EXPRESS HV FEEDERS**
**Feeder KV- 33 / INCOMING (NON-CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | 1.1317 |
| Max | 1.1317 |
| Min | 1.1317 |
| Avg | 1.1317 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 217047 / 132KV Someshwar**
**Feeder No / Name : 404 / 33/11 KV Nimbut s/stn I/C Feeder KV- 33 / INCOMING**
**NON SHEDDABLE EXPRESS HV FEEDERS (NON-CONTINOUS PROCESS)(NO STAGGERING)**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | .543 |
| Max | .543 |
| Min | .543 |
| Avg | .543 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 217047 / 132KV Someshwar**
**Feeder No / Name : 405 / 33 KV Nira Substation**
**InComer Feeder KV- 33 / INCOMING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | .7716 |
| Max | .7716 |
| Min | .7716 |
| Avg | .7716 |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**

Feederwise Load Information for **All Feeders**

From 29-NOV-17 and 05-DEC-17

**BARAMATI ZONE[052]**
**BARAMATI CIRCLE[511]**
**SASWAD DIVISION[509]**
**SOMESHWAR SUB-DN.[722] BU 4722**
**Substation No/ Name :- 217047 / 132KV Someshwar**
**Feeder No / Name : 701 / Someshwar SSK Ltd NON SHEDDABLE EHV INDUSTRIAL FEEDERS**
**Feeder KV- 132 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING**

| DATE | 01-DEC-17 |
|---|---|
| HR | Load (MW) |
| 24 | .4344 |
| Max | .4344 |
| Min | .4344 |
| Avg | .4344 |