

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

BHOSARI DIVISION[309]

AKURDI SUB-DN.[595] BU 4595

Substation No/ Name :- 213013 / 22/22 KV Akurdi

Feeder No / Name : 301 / AKURDI I

HV Non-Express Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	13.5269	13.1459	12.9554	13.908	13.908	14.289	14.0985
2	13.3364	12.7648	12.5743	14.0985	13.908	14.0985	13.7174
3	13.1459	12.3838	12.1933	13.3364	13.3364	13.7174	13.5269
4	12.7648	12.3838	12.5743	13.1459	12.9554	13.7174	13.7174
5	13.1459	12.9554	13.1459	13.1459	13.3364	14.0985	13.908
6	14.0985	13.5269	13.7174	13.7174	14.4795	14.8606	14.4795
7	15.0511	15.0511	14.8606	14.289	15.6226	15.6226	15.8132
8	14.67	15.8132	16.0037	15.0511	16.1942	16.7658	16.3847
9	14.67	18.671	19.052	17.7184	19.052	19.8141	19.2425
10	14.67	21.5288	21.5288	20.3856	21.7193	22.1003	22.4814
11	14.67	23.0529	22.8624	20.5762	23.2434	23.815	9.907
12	11.6217	22.4814			22.4814	23.0529	
13	4.5725	19.6236	19.052	17.9089	19.6236	20.3856	19.2425
14	4.5725		21.3382	19.2425	10.6691	21.5288	21.9098
15	13.7174	21.5288	21.7193	20.0046	22.4814	22.6719	22.4814
16	14.0985	22.2908	20.1951	20.1951	22.6719	21.9098	22.6719
17	13.3364	22.1003	21.3382	19.052	22.6719	23.0529	22.1003
18	13.7174	20.7667	20.1951	17.9089	20.3856	20.9572	20.9572
19	13.908	19.433	14.4795	16.7658	20.5762	20.1951	20.5762
20	15.0511	18.671	18.2899	17.3373	19.052	18.8615	19.8141
21		16.9563	18.0994	16.7658	18.0994	18.2899	18.671
22	15.0511	16.1942	16.9563	16.0037	16.9563	17.5278	
23	13.908	15.0511	15.6226	15.0511	15.8132	15.8132	15.6226
24	13.908	13.1459	13.7174	14.4795	14.0985	14.4795	14.4795
Max	15.0511	23.0529	22.8624	20.5762	23.2434	23.815	22.6719
Min	4.5725	12.3838	12.1933	13.1459	10.6691	13.7174	9.907
Avg	13.0962	17.3705	17.0640	16.5255	17.6390	18.4011	17.5365

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

BHOSARI DIVISION[309]

AKURDI SUB-DN.[595] BU 4595

Substation No/ Name :- 213013 / 22/22 KV Akurdi

Feeder No / Name : 302 / AKURDI II HV Non-Express Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	13.908	14.289	15.2416	16.5752	12.5743	15.0511	15.0511
2	14.0985	14.4795	14.289	16.7658	12.9554	14.8606	14.67
3	13.1459	13.5269	13.3364	15.6226	12.3838	14.289	14.67
4	12.9554	12.9554	13.5269	14.0985	11.8122	13.908	14.4795
5	12.9554	13.7174	13.908	13.3364	12.0028	14.4795	14.4795
6	13.908	14.4795	15.4321	13.1459	12.9554	15.0511	14.8606
7	10.8596	15.8132	14.8606	12.3838	14.289	14.8606	14.8606
8	13.7174	20.5762	20.3856	13.908	19.8141	19.2425	19.052
9	14.8606	21.7193	20.9572	14.0985	20.1951	21.9098	20.9572
10	15.6226	24.7676	21.5288	16.1942	22.6719	21.7193	22.6719
11	16.1942	24.196	20.7667	15.2416	22.6719	21.9098	21.1477
12	16.7658	21.7193			20.0046	19.433	19.433
13	15.4321	22.2908	18.2899	14.289	21.3382	21.7193	20.3856
14	14.8606		20.5762	14.8606	20.9572	21.5288	21.5288
15	15.4321	21.7193	19.8141	14.67	19.8141	20.1951	20.1951
16	17.5278	21.9098	20.7667	16.1942	19.8141	19.2425	20.0046
17	16.9563	22.2908	19.433	14.0985	20.1951	19.2425	20.3856
18	16.1942	18.8615	18.0994	15.2416	19.6236	18.671	19.6236
19	15.8132	17.9089	16.1942	13.3364	17.1468	17.5278	17.7184
20	16.3847	17.5278	15.8132	15.2416	19.2425	19.052	19.2425
21		18.2899	16.1942	15.4321	19.2425	20.5762	18.2899
22	15.0511	18.8615	20.3856	15.0511	20.1951	18.671	
23	13.5269	15.8132	16.0037	13.1459	15.2416	15.6226	16.0037
24	12.9554	14.67	15.8132	16.5752	12.7648	16.0037	15.4321
Max	17.5278	24.7676	21.5288	16.7658	22.6719	21.9098	22.6719
Min	10.8596	12.9554	13.3364	12.3838	11.8122	13.908	14.4795
Avg	14.7446	18.3645	17.4616	14.7612	17.4961	18.1153	18.0497

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

BHOSARI DIVISION[309]

AKURDI SUB-DN.[595] BU 4595

Substation No/ Name :- 213013 / 22/22 KV Akurdi

Feeder No / Name : 303 / Yamunanagar
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	8.1924	7.6208	8.0018	8.1924	8.1924	8.5734	8.3829
2	8.0018	7.4303	7.6208	8.0018	8.0018	8.3829	8.1924
3	8.0018	7.4303	7.6208	7.8113	8.0018	8.1924	8.1924
4	8.0018	7.4303	8.0018	7.8113	8.0018	8.1924	8.1924
5	8.1924	8.0018	8.3829	8.0018	8.1924	8.3829	8.3829
6	8.5734	8.3829	8.5734	8.3829	8.9544	8.9544	8.7639
7	8.7639	8.7639	8.7639	8.7639	9.145	8.9544	9.526
8	8.3829	8.9544	9.3355	9.145	9.3355	9.3355	9.7165
9	8.0018	10.2881	10.6691	10.4786	10.4786	10.4786	10.8596
10	7.8113	12.0028	12.1933	12.5743	11.8122	12.0028	12.1933
11	7.4303	12.9554	12.9554	12.5743	12.5743	12.9554	
12	7.2398	12.9554			12.5743	12.9554	12.9554
13		10.8596	10.6691	10.6691	10.6691	11.0502	10.6691
14			12.0028	12.0028	1.1431	12.0028	12.7648
15	6.4777	12.5743	12.1933	12.3838	12.5743	12.7648	12.9554
16	7.2398	12.7648	10.6691	12.5743	12.3838	11.8122	12.9554
17	7.4303	12.7648	12.0028	11.8122	12.7648	13.1459	12.5743
18	7.4303	11.6217	11.4312	11.0502	11.0502	11.6217	11.8122
19	7.6208		5.9061	10.2881	11.8122	11.4312	11.6217
20	8.5734	10.8596	10.2881	10.4786	11.2407	11.0502	11.6217
21		9.7165	10.0976	9.907	10.2881	10.4786	10.8596
22	8.5734	9.3355	9.907	9.7165	9.7165	10.0976	
23	8.1924	8.7639	9.145	9.145	9.145	9.145	9.526
24	8.3829	7.8113	8.3829	8.5734	8.5734	8.5734	8.5734
Max	8.7639	12.9554	12.9554	12.5743	12.7648	13.1459	12.9554
Min	6.4777	7.4303	5.9061	7.8113	1.1431	8.1924	8.1924
Avg	7.9293	9.9677	9.7745	10.0147	9.8594	10.4389	10.5132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

BHOSARI DIVISION[309]

AKURDI SUB-DN.[595] BU 4595

Substation No/ Name :- 213013 / 22/22 KV Akurdi

Feeder No / Name : 305 / D-III BLOCK
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.3346	5.5251	4.9535	5.7156	5.7156	5.7156	5.7156
2	5.3346	5.3346	4.9535	6.0966	5.9061	5.7156	5.5251
3	5.144	4.9535	4.5725	5.5251	5.3346	5.5251	5.3346
4	4.763	4.9535	4.5725	5.3346	4.9535	5.5251	5.5251
5	4.9535	4.9535	4.763	5.144	5.144	5.7156	5.5251
6	5.5251	5.144	5.144	5.3346	5.5251	5.9061	5.7156
7	6.2872	6.2872	6.0966	5.5251	6.4777	6.6682	6.2872
8	6.2872	6.8587	6.6682	5.9061	6.8587	7.4303	6.6682
9	6.6682	8.3829	8.7639	7.2398	8.7639	9.3355	8.5353
10	6.8587	9.526	9.3355	7.8113	9.907	10.0976	10.2881
11	7.2398	10.0976	9.907	8.0018	10.6691	10.8596	9.907
12	4.382	9.526			9.907	10.0976	9.526
13	4.5725	8.7639	8.3829	7.2398	8.9544	9.3355	8.5734
14	4.5725		9.3355	7.2398	9.526	9.526	9.145
15	7.2398	8.9544	9.526	7.6208	9.907	9.907	9.526
16	6.8587	9.526	9.526	7.6208	10.2881	10.0976	9.7165
17	5.9061	9.3355	9.3355	7.2398	9.907	9.907	9.526
18	6.2872	9.145	8.7639	6.8587	9.3355	9.3355	9.145
19	6.2872	8.3829	8.5734	6.4777	8.7639	8.7639	8.9544
20	6.4777	7.8113	8.0018	6.8587	7.8113	7.8113	8.1924
21		7.2398	8.0018	6.8587	7.8113	7.8113	7.8113
22	6.4777	6.8587	7.0492	6.2872	7.2398	7.4303	
23	5.7156	6.2872	6.4777	5.9061	6.6682	6.6682	6.0966
24	5.5251	5.3346	5.3346	5.9061	5.5251	5.9061	5.9061
Max	7.2398	10.0976	9.907	8.0018	10.6691	10.8596	10.2881
Min	4.382	4.9535	4.5725	5.144	4.9535	5.5251	5.3346
Avg	5.8564	7.3557	7.3060	6.5108	7.7875	7.9622	7.7020

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

BHOSARI DIVISION[309]

AKURDI SUB-DN.[595] BU 4595

Substation No/ Name :- 213013 / 22/22 KV Akurdi

Feeder No / Name : 307 / FORCE MOTOR

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0483	3.4294	2.8578	3.0483	1.1431	2.6673	2.6673
2	3.2388	3.4294	2.6673	2.8578	1.1431	2.6673	2.4768
3	3.0483	3.0483	2.2862	2.8578	1.1431	2.2862	2.2862
4	3.0483	2.8578	2.2862	2.2862	1.1431	1.9052	2.2862
5	3.2388	2.8578	1.9052	1.9052	1.1431	2.0957	2.0957
6	3.4294	3.0483	2.0957	1.7147	1.1431	2.0957	2.0957
7	3.2388	3.0483	1.9052	1.3336	1.5242	1.9052	2.0957
8	4.5725	5.9061	4.1914	1.3336	3.4294	4.0009	3.4294
9	4.5725	5.7156	4.5725	1.5242	3.6199	4.763	4.9535
10	4.763	6.8587	4.1914	1.5242	4.5725	4.0009	4.382
11	5.9061	6.4777	3.8104	1.5242	4.5725	4.5725	3.4294
12	3.8104	6.6682			4.1914	4.382	3.4294
13	4.763	6.0966	3.4294	1.5242	4.5725	4.763	4.382
14	4.0009		4.1914	1.5242	3.8104	4.5725	4.382
15	4.5725	6.2872	3.4294	1.3336	3.8104	4.0009	3.8104
16	5.3346	5.9061	4.1914	1.5242	4.5725	4.1914	3.2388
17	4.763	6.8587	4.0009	1.3336	4.382	3.4294	4.1914
18	4.382	3.8104	4.0009	1.3336	4.382	3.6199	3.2388
19	4.0009	3.8104	3.2388	1.3336	3.6199	3.8104	3.4294
20	4.0009	2.6673	3.4294	1.3336	3.4294	3.0483	3.6199
21		3.8104	3.6199	1.5242	3.8104	4.1914	3.0483
22	3.0483	4.0009	4.0009	1.3336	4.1914	3.2388	
23	2.4768	3.0483	2.6673	1.3336	2.8578	2.8578	3.0483
24	1.9052	3.4294	2.8578	3.0483	1.1431	2.8578	2.8578
Max	5.9061	6.8587	4.5725	3.0483	4.5725	4.763	4.9535
Min	1.9052	2.6673	1.9052	1.3336	1.1431	1.9052	2.0957
Avg	3.8767	4.4814	3.2968	1.7561	3.0563	3.4135	3.2554

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

BHOSARI DIVISION[309]

AKURDI SUB-DN.[595] BU 4595

Substation No/ Name :- 213013 / 22/22 KV Akurdi

Feeder No / Name : 308 / TEMPO WOLLRope
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.3346	5.5251	5.144	5.3346	4.5725	5.3346	5.3346
2	5.5251	5.9061	4.9535	5.7156	4.9535	5.144	5.144
3	5.3346	5.3346	4.5725	5.3346	4.763	4.763	5.144
4	5.144	4.9535	4.5725	5.144	4.382	5.144	5.144
5	4.9535	5.3346	4.9535	4.763	4.382	5.144	5.3346
6	4.9535	4.9535	5.5251	4.5725	4.5725	5.3346	5.144
7	4.763	5.5251	5.3346	4.1914	4.763	4.763	5.144
8	5.3346	5.7156	6.0966	4.763	5.9061	5.144	5.7156
9	6.2872	6.4777	6.4777	4.9535	7.2398	6.6682	6.8587
10	6.2872	6.8587	6.4777	5.5251	6.6682	6.6682	7.2398
11	6.0966	6.6682	6.8587	5.3346	6.8587	6.4777	6.6682
12	5.9061	6.2872			6.6682	6.2872	6.8587
13	5.7156	6.4777	5.7156	4.9535	6.2872	6.2872	6.4777
14	6.0966		5.9061	5.144	6.0966	6.4777	6.8587
15	6.0966	6.2872	6.2872	5.3346	6.2872	6.6682	7.0492
16	6.4777	6.6682	6.4777	5.3346	6.6682	6.2872	7.0492
17	6.0966	6.6682	6.0966	4.9535	6.4777	6.2872	6.6682
18	5.9061	6.2872	5.7156	5.3346	5.9061	5.9061	6.4777
19	5.7156	5.7156	5.3346	4.763	5.5251	5.5251	5.5251
20	5.5251	5.5251	5.3346	4.9535	5.3346	5.7156	5.5251
21		5.5251	5.144	4.763	5.5251	5.5251	5.7156
22	5.5251	5.7156	5.9061	4.763	5.7156	5.7156	
23	5.144	5.3346	5.3346	4.9535	4.763	5.144	5.3346
24	5.5251	5.7156	5.3346	5.5251	4.763	5.5251	5.3346
Max	6.4777	6.8587	6.8587	5.7156	7.2398	6.6682	7.2398
Min	4.763	4.9535	4.5725	4.1914	4.382	4.763	5.144
Avg	5.6410	5.8896	5.6328	5.0612	5.6283	5.7474	5.9890

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

BHOSARI DIVISION[309]

AKURDI SUB-DN.[595] BU 4595

Substation No/ Name :- 213013 / 22/22 KV Akurdi

Feeder No / Name : 309 / TEMPO TRACTOR

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.7621	.7621	.5716	.0762	.381	.381
2	.7621	.7621	.7621	.5716	.0762	.381	.381
3	.5716	.7621	.7621	.5716	.0762	.381	.381
4	.5716	.7621	.7621	.5716	.0762	.381	.381
5	.5716	.7621	.7621	.5716	.0762	.381	.381
6	.7621	.7621	.9526	.5716	.0762	.381	.381
7	1.3336	1.1431	.9526	.5716	.9526	.5716	.5716
8	1.9052	1.9052	1.9052	.0762	1.9052	1.7147	1.9052
9	1.9052	1.9052	1.9052		1.9052	1.7147	1.9052
10	2.0957	1.9052	1.9052		1.9052	1.9052	1.9052
11	1.9052	1.9052	1.7147		1.9052	1.7147	
12	1.5242	1.5242			1.5242	1.3336	1.5242
13	1.7147	1.7147	1.5242		1.7147	1.7147	1.7147
14	1.7147		1.7147		1.5242	1.7147	1.5242
15		1.5242	1.5242		1.5242	1.5242	1.5242
16	.381	.7621	1.1431		.5716	.5716	.5716
17	.7621	.7621	.7621		.5716	.5716	.5716
18	.7621	.9526	.9526		.5716	.5716	.381
19	.7621	.7621	.7621		.5716	.5716	.5716
20	.7621	.9526	.9526		.381	.381	.381
21		.9526	.9526	.0762	.5716	.5716	.5716
22	.7621	.9526	.9526	.0762	.5716	.5716	
23	.7621	.9526	.9526	.0762	.5716	.381	.5716
24	.7621	.7621	.9526	.5716	.0762	.381	.381
Max	2.0957	1.9052	1.9052	.5716	1.9052	1.9052	1.9052
Min	.381	.7621	.7621	.0762	.0762	.381	.381
Avg	1.0825	1.1266	1.1431	.4065	.8240	.8653	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

BHOSARI DIVISION[309]

AKURDI SUB-DN.[595] BU 4595

Substation No/ Name :- 213013 / 22/22 KV Akurdi

Feeder No / Name : 310 / G-BLOCK

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6673	2.6673	2.6673	3.0483	2.8578	2.8578	2.8578
2	2.4768	2.4768	2.4768	2.8578	2.6673	2.8578	2.8578
3	2.4768	2.4768	2.2862	2.6673	2.6673	2.6673	2.6673
4	2.4768	2.4768	2.4768	2.4768	2.6673	2.6673	2.8578
5	2.6673	2.8578	2.6673	2.6673	2.8578	3.0483	2.8578
6	3.2388	3.4294	3.0483	3.0483	3.6199	3.4294	3.4294
7		3.8104	3.6199	3.4294	4.0009	4.1914	4.0009
8		3.6199	3.6199	3.8104	4.0009	4.0009	4.0009
9		3.4294	3.6199	3.8104	3.4294	3.6199	3.4294
10	.381	3.4294	3.4294	3.8104	3.4294	3.4294	3.4294
11		3.4294	3.4294	3.6199	3.2388		
12	3.6199	3.0483			3.0483	3.0483	3.0483
13	3.2388	3.0483	3.0483	3.4294	3.0483	3.0483	3.0483
14	3.0483		3.0483	3.4294	3.0483	3.0483	2.8578
15	2.6673	2.8578	3.4294	3.4294	2.8578	3.0483	2.8578
16	3.0483	3.0483	3.2388	3.6199	3.0483	2.8578	2.8578
17	3.0483	3.0483	3.2388	3.4294	3.0483	3.0483	3.0483
18	3.0483	3.2388	3.2388	3.6199	3.2388	3.2388	3.2388
19	3.4294	4.0009	3.6199	3.8104	3.6199	3.6199	3.8104
20	4.1914	4.382	4.382	4.5725	4.382	4.382	4.382
21		4.0009	4.382	4.5725	4.382	4.5725	4.382
22	3.8104	3.6199	4.0009	4.1914	4.1914	4.0009	
23	3.2388	3.2388	3.6199	3.6199	3.4294	3.4294	3.4294
24	2.6673	2.8578	2.6673	3.0483	3.0483	3.0483	3.0483
Max	4.1914	4.382	4.382	4.5725	4.382	4.5725	4.382
Min	.381	2.4768	2.2862	2.4768	2.6673	2.6673	2.6673
Avg	2.9180	3.2388	3.2720	3.4791	3.3262	3.3548	3.2908

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

BHOSARI DIVISION[309]

AKURDI SUB-DN.[595] BU 4595

Substation No/ Name :- 213013 / 22/22 KV Akurdi

Feeder No / Name : 311 / SRA1

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0957	1.9052	3.8104	4.5725	4.0009	3.8104	3.8104
2	2.0957	1.9052	3.4294	4.763	4.1914	3.8104	3.8104
3	1.9052	1.9052	3.4294	4.1914	3.8104	4.1914	4.1914
4	1.7147	1.9052	3.4294	3.6199	3.6199	3.8104	3.8104
5	1.5242	1.9052	3.6199	3.4294	3.6199	3.8104	3.8104
6	1.5242	2.2862	3.8104	3.2388	3.6199	3.8104	3.8104
7	1.5242	2.2862	3.0483	2.8578	3.0483	3.4294	3.0483
8	1.9052	3.4294	4.5725	4.0009	4.5725	4.382	4.0009
9	2.0957	4.1914	5.3346	3.8104	4.5725	5.144	4.9535
10	2.0957	5.7156	5.5251	5.3346	6.0966	5.7156	5.7156
11	2.2862	5.7156	4.9535		6.0966		
12	1.9052	4.1914			4.5725	4.382	4.5725
13		4.9535	4.5725	4.382	5.7156	5.9061	4.763
14			5.7156	4.763	6.4777	5.7156	5.9061
15	2.0957	4.763	5.144	4.5725	5.3346	4.9535	4.9535
16	2.2862	5.5251	5.7156	5.7156	4.9535	5.7156	6.2872
17	2.2862	4.9535	5.3346	4.382	5.7156	5.9061	5.9061
18	2.0957	4.5725	4.1914	4.9535	5.5251	5.3346	6.2872
19	1.9052	3.6199	3.2388	3.4294	3.8104	4.0009	4.382
20	1.9052	4.0009	1.7147	4.382	5.7156	5.5251	5.3346
21		4.0009	2.0957	4.5725	4.9535	5.7156	4.5725
22	1.9052	4.5725	5.5251	4.763	5.5251	5.144	
23	1.9052	3.2388	3.4294	3.2388	3.6199	3.8104	3.4294
24	2.0957	1.9052	4.0009	4.382	3.8104	4.1914	3.8104
Max	2.2862	5.7156	5.7156	5.7156	6.4777	5.9061	6.2872
Min	1.5242	1.9052	1.7147	2.8578	3.0483	3.4294	3.0483
Avg	1.9596	3.6282	4.1583	4.2434	4.7074	4.7050	4.5985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

BHOSARI DIVISION[309]

AKURDI SUB-DN.[595] BU 4595

Substation No/ Name :- 213405 / 22/22 KV EWS SW. STATION

Feeder No / Name : 301 / EWS O/G Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.5335	.4954	.5335	.5716	.4954	.4954
2	.4191	.5335	.4954	.4954	.4954	.4572	.4572
3	.4191	.4572	.4572	.4954	.4954	.4954	.4572
4	.4191	.4572	.4572	.5335	.5335	.4954	.4572
5	.4954	.5335	.4954	.5335	.5716	.5716	.5335
6	.5716	.6097	.6097	.5716	.6859	.7621	.7621
7	.6859	.7621	.6478	.6478	.8002	.724	.7621
8	.6859	.7621	.724	.8002	.8002	.724	.724
9	.6859	.724	.8002	.8383	.7621	.6859	.6859
10	.5716	.6478	.6478	.7621	.5335	.5716	.6097
11	.5716	.5335	.5716	.6859	.5335	.5716	.6097
12	.4954	.5335	.5335	.6478	.5716	.5335	.4954
13	.5335	.4572	.5335	.6097	.4954	.4572	.4954
14	.4572	.4954	.5335	.5335	.4572	.4572	.4572
15	.4572	.4191	.4954	.5335	.4572	.4191	.4191
16	.4572	.4191	.4191	.5716	.4191	.4191	
17	.4572	.4572	.4572	.5335	.4191	.381	.4191
18	.6859	.4572	.4954	.6097	.4572	.4191	.4954
19	.5335		.6097	.6859	.5335	.5716	.6097
20	.6478		.6859	.724	.724	.724	.6478
21	.7621		.7621	.7621	.724	.7621	.724
22	.724	.724	.724	.7621	.724	.6859	.6859
23	.6478	.5335	.6859	.6859	.6478	.6478	.6478
24	.4572	.5716	.4572	.5335	.6097	.5335	.5335
Max	.7621	.7621	.8002	.8383	.8002	.7621	.7621
Min	.4191	.4191	.4191	.4954	.4191	.381	.4191
Avg	.5573	.5534	.5748	.6288	.5843	.5652	.5732

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

BHOSARI DIVISION[309]

AKURDI SUB-DN.[595] BU 4595

Substation No/ Name :- 213405 / 22/22 KV EWS SW. STATION

Feeder No / Name : 302 / HARGUDE WASTI Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669	1.1431	1.105	1.1812	1.1431	1.1812	1.1812
2	1.0669	1.1431	1.105	1.1431	1.105	1.1812	1.2193
3	1.105	1.2193	1.1431	1.1431	1.1431	1.1812	1.1812
4	1.1431	1.2574	1.1431	1.1431	1.1431	1.2193	1.1812
5	1.1431	1.2193	1.1812	1.1812	1.1812	1.1812	1.2193
6	1.1812	1.2574	1.1812	1.2193	1.2193	1.2193	1.1812
7	1.105	1.2193	1.1431	1.105	1.1812	1.1812	1.1812
8	1.1431	1.1812	1.1431	1.1431	1.1812	1.1812	1.2574
9	.9907	1.1812	1.1812	1.2193	1.1812	1.3336	1.2955
10	1.0669	1.1812	1.4098		1.3336	1.448	1.448
11	1.0288	1.2574	1.5242	1.4098	1.4861	1.4098	1.4098
12	1.0669	1.3336	1.3717	1.2955	1.2574	1.2955	1.3336
13	1.1431	1.1431	1.2193	1.2193	1.2193	1.2955	1.2193
14		1.3336	1.3717	1.4861	1.3336	1.448	1.2193
15		1.2574	1.2955	1.2574	1.2574	1.3717	1.4861
16		1.3717	1.448	1.3717	1.448	1.2574	
17		1.2193	1.448	1.2574	1.3717	1.4098	1.3717
18		1.1812	1.3717	1.1812	1.3336	1.3717	1.3336
19	1.2574	1.0669	1.1812	1.1431	1.2574	1.2574	1.4098
20	1.2955	1.0288	1.105	1.105	1.1812	1.2574	1.1812
21	1.1812	1.0669	1.105	1.105	1.1431	1.1812	1.1431
22	1.2574	1.1431	1.2193	1.1812	1.1812	1.2574	1.1812
23	1.1431	1.105	1.1812	1.1812	1.1812	1.1812	1.1812
24	1.105	1.1431	1.105	1.1812	1.1431	1.1812	1.1812
Max	1.2955	1.3717	1.5242	1.4861	1.4861	1.448	1.4861
Min	.9907	1.0288	1.105	1.105	1.105	1.1812	1.1431
Avg	1.1311	1.1939	1.2368	1.2110	1.2336	1.2701	1.2607

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

BHOSARI DIVISION[309]

AKURDI SUB-DN.[595] BU 4595

Substation No/ Name :- 213405 / 22/22 KV EWS SW. STATION

Feeder No / Name : 303 / KOHINOOR Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0381	.0381	.0381	.0381	.0381
2	.0381	.0381	.0381	.0381	.0381	.0381	.0381
3	.0381	.0381	.0381	.0381	.0381	.0381	.0381
4	.0381	.0381	.0381	.0381	.0381	.0381	.0381
5	.0381	.0381	.0381	.0381	.0381	.0381	.0381
6	.0762	.0762	.0381	.0381	.0381	.0762	.0762
7	.0762	.0762	.0381	.0381	.0381	.0762	.0762
8	.0381	.0381	.0381	.0762	.0381	.0762	.0381
9	.0762	.0381	.0762	.0762	.0762	.0381	.0381
10	.0381	.0762	.0762	.0381	.0381	.0381	.0381
11	.0762	.0381	.0381	.0381	.0381	.0381	.0381
12	.0381	.0381	.0381	.0762	.0381	.0381	.0381
13	.0381	.0381	.0381	.0381	.0381	.0381	.0381
14	.0381	.0381	.0381	.0381	.0381	.0381	.0381
15	.0381	.0381	.0381	.0381	.0381	.0381	.0381
16	.0381	.0381	.0381	.0381	.0381	.0381	
17	.0381	.0381	.0381	.0381	.0381	.0381	.0381
18	.0381	.0381	.0381	.0381	.0381	.0381	.0381
19	.0381	.0381	.0381	.0381	.0381	.0381	.0381
20	.0381	.0381	.0381	.0381	.0381	.0381	.0762
21	.0381	.0381	.0381	.0381	.0381	.0381	.0381
22	.0381	.0762	.0381	.0381	.0381	.0381	.0381
23	.0381	.0381	.0381	.0381	.0381	.0381	.0381
24	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Max	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.0445	.0445	.0413	.0429	.0397	.0429	.0431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

BHOSARI DIVISION[309]

AKURDI SUB-DN.[595] BU 4595

Substation No/ Name :- 213405 / 22/22 KV EWS SW. STATION

Feeder No / Name : 304 / CHIKHALI Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.448	1.6004	1.6004	1.7528	1.7909	1.6385	1.6004
2	1.3717	1.4861	1.5242	1.6385	1.7528	1.6385	1.7147
3	1.4098	1.3336	1.5623	1.6004	1.6766	1.829	1.6385
4	1.4861	1.3717	1.5623	1.6004	1.6766	1.7528	1.6766
5	1.5623	1.5623	1.6004	1.6766	1.7147	1.7909	1.7147
6	1.6385	1.829	1.6766	1.7528	1.7528	1.829	1.9814
7	1.7528	1.9814	1.9433	1.9814	2.0957	2.1338	1.9814
8	1.7909		1.9052	2.0195	2.0195	2.1338	2.0195
9	1.5623	1.8671	1.9052	2.1338	1.9052	1.8671	1.9433
10	1.5242	1.829	2.0195	2.2481		1.8671	1.8671
11	1.5623	1.9814	2.0195	2.0576	2.0576	1.7909	1.9052
12	1.4861	1.6766	1.9052	2.0957	1.829	1.6766	1.9052
13	1.4098	1.6385	1.7909	1.9052	1.7909	1.6766	1.6385
14	1.4861	1.6766	1.6766	1.9814	1.829	1.8671	1.7147
15	1.448	1.6385	1.829	1.9814	1.829	1.7909	1.6766
16	1.4861	1.7528	1.829	2.0576	1.829	1.7528	
17	1.4861	1.7909		1.9814	1.829	1.7147	1.8671
18	1.3336	1.7909	1.829	2.1719	1.9052	1.829	1.9814
19	1.6004		1.9052	1.9814	1.9814	1.9814	2.1338
20	1.8671	2.1338	2.1719	2.3243	2.1719	2.1719	2.2862
21	1.9433	2.0576	2.2481	2.2862	2.1719	2.2481	2.2481
22	1.9814	1.829	2.21	2.2862	2.1338	2.2481	2.3243
23	1.7909	1.7147	2.0957	2.0576	1.9433	2.0576	1.9814
24	1.5242	1.6766	1.6385	1.829	1.8671	1.6385	1.829
Max	1.9814	2.1338	2.2481	2.3243	2.1719	2.2481	2.3243
Min	1.3336	1.3336	1.5242	1.6004	1.6766	1.6385	1.6004
Avg	1.5813	1.7372	1.8456	1.9751	1.8936	1.8719	1.8969

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

BHOSARI DIVISION[309]

AKURDI SUB-DN.[595] BU 4595

Substation No/ Name :- 213412 / 22 kV CDC SEC 18 SW. STATION

Feeder No / Name : 301 / SHAHUNAGAR Urban/Sheddable Urban Feeder
Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8107	2.037	1.8484	2.3765	2.3011	2.3011	2.2634
2	1.8107	1.9993	1.8107	2.3765	2.1879	2.3011	2.1879
3	1.773	1.9616	1.773	2.3011	2.0748	2.1879	2.3011
4	1.7353	1.9239	1.7353	2.3011	1.9993	2.2257	2.3765
5	1.7353	1.8861	1.7353	2.2634	2.1125	2.037	2.452
6	1.9993	2.1879	1.9616	2.2257	2.4143	2.3011	2.3388
7	2.3765	2.4897	1.9993	2.1125	2.4897	2.4897	2.5274
8	2.452	2.5274	2.4143	2.2257	2.452	2.5274	2.5652
9	2.2634	2.452	2.452	2.452	2.3765	2.3388	2.4143
10	2.3765	2.6029	2.6029	2.5652	2.452	2.452	2.4143
11	2.3765	2.6029	2.6406	2.5652	2.5652	2.5274	2.4897
12	2.3388	2.452	2.5652	2.5274	2.4143	2.452	2.3765
13	2.2257	2.4143	2.5274	2.3765	2.4143	2.452	2.452
14	2.1502	2.3011	2.3388	2.3765	2.3388	2.3011	2.2634
15	2.2257	2.2634	2.4143	2.4143	2.3011	2.2634	2.2634
16	2.3011	2.3011	2.3765	2.4143	2.3011	2.3011	2.3011
17	2.3011	2.2634	2.4143	2.3765		2.3765	2.3388
18	2.5274	2.3388	2.3388	2.4897	2.4143	2.3765	2.4143
19	2.5652	2.3765	2.6783	2.4143	2.6783	2.6029	2.7161
20	3.0178	2.9801	3.1687	3.2065	3.2065	3.2442	3.2065
21	3.0178	2.8669	3.0933	3.2442	3.0933	3.2065	3.2065
22	2.7915	2.6406	2.8669	3.0178	2.9424	3.0556	3.0178
23	2.5652	2.3011		2.7538	2.7161	2.7538	2.7161
24	1.9993	2.1502	2.1125	2.3388	2.4143	2.4143	2.3388
Max	3.0178	2.9801	3.1687	3.2442	3.2065	3.2442	3.2065
Min	1.7353	1.8861	1.7353	2.1125	1.9993	2.037	2.1879
Avg	2.2807	2.3467	2.3421	2.4881	2.4635	2.4787	2.4976

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

BHOSARI DIVISION[309]

AKURDI SUB-DN.[595] BU 4595

Substation No/ Name :- 213412 / 22 kV CDC SEC 18 SW. STATION

Feeder No / Name : 302 / SONAVANEWASTI Urban/Sheddable Urban Feeder
Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6029	2.6783	2.6406	2.6406	2.6029	2.7161	2.6783
2	2.5274	2.7161	2.6783	2.5652	2.5652	2.6783	2.6406
3	2.5652	2.6783	2.6783	2.5652	2.5274	2.6783	2.7161
4	2.5274	2.6783	2.6406	2.452	2.5652	2.6406	2.8669
5	2.5652	2.7161	2.6406	2.4143	2.6029	2.6406	2.7915
6	2.6029	2.6783	2.6783	2.6029	2.6783	2.7538	2.6783
7	2.5274	2.6783	2.6783	2.6783	2.6406	2.6783	2.7161
8	2.5652	2.6029	2.6406	2.6029	2.6783	2.6783	2.6783
9	2.4143	2.9047	2.8292	2.9047	2.9424	2.8292	3.0178
10	2.452	3.7723	3.6591	3.546	3.546	3.8855	3.9609
11	2.3765	3.6969	3.9609		3.81	4.1872	4.1495
12	2.3011	3.8855	4.0364	3.7346	3.9986	3.8855	4.1495
13	2.452	2.9801	2.9424	2.8292	2.7915		2.9801
14	2.5274	3.5837	3.8477	3.5082	3.3573	3.8855	3.7346
15	2.4143	3.5837	3.9232	3.5837	3.9609	3.6214	3.8855
16	2.4143	3.9232		3.3951	3.6969	3.6591	3.9609
17	2.4897	3.7723	3.6591	3.131	3.6591	3.3196	3.81
18	2.5274	3.3951	3.2065	3.131	3.4328	3.4328	3.5082
19	2.452	3.2065	3.3196	3.0178	3.4705	3.5082	3.3951
20	2.6406	2.9801	3.0556	2.8669	3.0178	3.1687	3.1687
21	2.7161	2.7538	2.9047	2.6783	2.8292	2.9424	3.0933
22	2.6029	2.7915	2.8292	2.7538	2.9047	2.8669	
23	2.6406	2.6783		2.6406	2.9047	2.7915	2.8669
24	2.6406	2.6783	2.6783	2.6406	2.6406	2.7538	2.7538
Max	2.7161	3.9232	4.0364	3.7346	3.9986	4.1872	4.1495
Min	2.3011	2.6029	2.6406	2.4143	2.5274	2.6406	2.6406
Avg	2.5227	3.0839	3.0967	2.9080	3.0760	3.1392	3.2261

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

BHOSARI DIVISION[309]

AKURDI SUB-DN.[595] BU 4595

Substation No/ Name :- 213412 / 22 kV CDC SEC 18 SW. STATION

Feeder No / Name : 303 / JADHAVWADI Urban/Sheddable Urban Feeder
Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.3944	.8299	4.8663	5.0926	5.168	5.3189	5.3189
2	5.3567	4.489	4.7908	5.0926	4.9794	5.3189	5.2435
3	5.2435	4.4136	4.7531	5.0172	4.8285	5.2058	5.168
4	5.2435	4.3004	4.7154	4.9417	4.7908	5.0926	5.2435
5		4.2627	4.7154	5.0172	4.904	4.8285	5.168
6	5.2058	4.5645	4.7154	5.1303	5.1303	5.0926	5.0926
7	4.9794	4.904	4.6022	3.7723	5.2058	4.9794	5.0172
8	5.0926	5.2812	4.6022	3.9609	5.3944	5.2812	5.2812
9	5.0172	5.0926	5.2435		5.3944	5.4321	5.6584
10	5.2058	5.8471	5.8093	5.6584	5.9225	6.1866	6.2997
11	5.1303	6.3752	6.0357	6.4506	6.0357	5.9225	6.6392
12	4.7908	6.0357	5.8471	6.8656	6.0734	5.998	6.5638
13	4.5268	5.2812	4.7154	5.8848	5.3189	5.8093	6.1866
14	4.225	5.6962	5.1303	6.5638	5.5076	5.7339	5.8471
15	4.489		6.0357	6.6015	5.9225	6.0357	6.1111
16	4.6776	5.7716	6.1866	6.6392	5.8471	6.4129	6.4506
17	4.3759	5.7339	5.8471	6.5638	5.9602	6.1488	6.0734
18	4.3004	5.8093	5.9225	6.2243	5.7716	6.1866	6.0357
19	4.2627	5.7339	6.1866	5.998	6.0357	6.2243	5.7716
20	5.0549	6.3375	6.262	6.4883	6.1111	6.8279	6.3375
21	5.3189	5.998	6.1111	6.2997	5.8093	6.4883	5.8848
22	5.168	5.6207	5.8471	5.9602	5.8093	6.1866	6.1111
23	4.9794	5.4698		5.9225	5.7716	5.7339	5.3944
24	5.583	4.904	5.0549	5.2058	5.3189	5.3944	5.4321
Max	5.583	6.3752	6.262	6.8656	6.1111	6.8279	6.6392
Min	4.225	.8299	4.6022	3.7723	4.7908	4.8285	5.0172
Avg	4.9401	5.1631	5.3911	5.7109	5.5421	5.7433	5.7638

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

BHOSARI DIVISION[309]

AKURDI SUB-DN.[595] BU 4595

Substation No/ Name :- 213412 / 22 kV CDC SEC 18 SW. STATION

Feeder No / Name : 304 / Express PMC/PCMC Water Only one consumer of WW with HT-IV
supply Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3772	.381	.3772	.381	.3429	.381
2	.3048	.3429	.3429	.3395	.381	.3429	.3429
3	.3429	.381	.381	.3018	.4191	.3048	.381
4	.3048	.3429	.381	.3018	.381	.2667	.4191
5	.5335	.381	.381	.2641	.4954	.4191	.4572
6	.4954	.5335	.5335	.5281	.5716	.5335	.5335
7	.3048	.5716	.3048	.3018	.5716	.4954	.4191
8	.3429	.4904	.3048	.2641	.4572	.4954	.4572
9	.4572	.6859	.2667	.3429	.6478	.5281	.2641
10	.4572	.4572	.2667	.6478	.6478	.6413	.5658
11	.6859	.3048	.2667	.4572	.3048	.4527	.5658
12	.4572	.381	.2667	.4572	.4572		.3395
13	.381	.3048	.2667	.3429	.3429		.3395
14	.4191	.3429	.5335	.3429	.3048	.2263	.3395
15	.4904	.3395	.5335	.3429	.381	.2667	.3048
16	.5281	.3395	.5335	.4954	.3772	.4191	.381
17	.415	.3395	.3429	.4572	.4572	.3429	.3772
18	.5281	.3395	.4572	.4572	.3395	.4191	.3395
19	.4904	.2641	.3048	.4572	.3395	.3429	.3395
20	.415	.4527	.4191	.4572	.3429	.3429	.4572
21	.4954	.2667	.415	.4572	.3429	.3429	.3429
22	.3048	.2667	.3395	.2641	.4191	.4191	.4572
23	.3048	.3048		.3048	.2667	.3048	.381
24	.3772	.3048	.381	.3772	.381	.381	.381
Max	.6859	.6859	.5335	.6478	.6478	.6413	.5658
Min	.3048	.2641	.2667	.2641	.2667	.2263	.2641
Avg	.4241	.3798	.3741	.3892	.4171	.3923	.3986

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

BHOSARI DIVISION[309]

AKURDI SUB-DN.[595] BU 4595

Substation No/ Name :- 213412 / 22 kV CDC SEC 18 SW. STATION

Feeder No / Name : 305 / R. T. O. Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.9808	.9808	1.2449	1.094	1.2071	1.1317
2	.9431	.9431	.9431	1.2449	1.0185	1.2071	1.094
3	.9431	.9431	.9054	1.1317	1.0562	1.094	1.0562
4	.9054	.9431	.8676	1.1694	.9808	1.094	1.1317
5	.9054	.9431	.8676	1.0562	1.0562	.9808	1.1694
6	1.094	1.0185	.9431	1.2449	1.2449	1.2071	1.1694
7	1.3957	1.3957	1.0185	1.094	1.3203	1.3203	1.358
8	1.358	1.2826	1.2449	1.2071	1.3203	1.358	1.3957
9	1.2071	1.2449	1.2826	1.3203	1.1694	1.1694	1.1694
10	1.2071	1.2826	1.358	1.3957	1.1694	1.2071	1.2071
11	1.1694	1.2071	1.2826	1.3203	1.2449	1.2071	1.1694
12	1.1317	1.1694	1.2826	1.3203	1.1694	1.2071	1.1694
13		1.1317	1.1694	1.1694	1.094	1.1317	.9808
14	1.094	1.0185	1.1317	1.0562	1.094	1.0562	.9431
15	.9808	1.0562	1.0562	1.1694	1.094	1.0562	1.0562
16		1.1317	1.094	1.1317	1.094	1.0562	1.1317
17		1.1317	1.094	1.1694	1.094	1.0185	1.0562
18	1.5089	1.1317	1.094	1.2826	1.094	1.0562	1.0185
19	1.3957	1.2826	1.2449	1.2449	1.2826	1.1694	1.2826
20	1.5466	1.2826	1.4335	1.4712	1.4712	1.5089	1.5089
21	1.5466	1.358	1.3957	1.4712	1.4712	1.4712	1.4335
22	1.3957	1.2826	1.4335	1.4335	1.4335	1.4712	1.3957
23	1.2071	1.094		1.2826	1.2826	1.3203	1.2449
24	.9808	1.0562	1.0185	1.2071	1.1317	1.1694	1.1694
Max	1.5466	1.3957	1.4335	1.4712	1.4712	1.5089	1.5089
Min	.9054	.9431	.8676	1.0562	.9808	.9808	.9431
Avg	1.1838	1.1380	1.1366	1.2433	1.1867	1.1977	1.1851

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

BHOSARI DIVISION[309]

AKURDI SUB-DN.[595] BU 4595

Substation No/ Name :- 213430 / 22/22 KV RIVER RESIDENCY

Feeder No / Name : 301 / RIVER RESIDENCY O/G Urban/Sheddable Urban Feeder
Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3772	.3772	.3772	.3772	.3772	.3395
2	.3395	.3395	.3395	.3395	.3772	.3772	.3018
3	.3395	.3395	.3395	.3395	.3395	.3395	.3018
4	.3395	.3772	.3395	.3395	.3395	.3395	.2641
5		.3772	.3018	.3395	.3395	.3395	.3018
6	.3772	.3395	.2641	.2641	.3018	.3018	.3395
7	.3018	.3395	.2641	.2641	.3018	.3018	.3395
8	.3772	.3395	.3018	.3018	.3018	.3018	.3018
9	.3772	.3772	.3395	.3395	.3018	.3018	.3395
10	.3772	.3772	.3395	.3772	.3395	.3395	.3018
11	.3772	.3395	.3395	.3772	.3395	.3395	.3395
12	.3395	.3395	.3395	.415	.3018	.3772	.3395
13	.3395	.3018	.3018	.415	.2641	.3018	.3018
14	.3395	.3395	.2641	.3395	.2641	.3018	.3018
15	.3395	.3395	.3018	.3395	.3018	.3018	.2641
16	.3395	.3018	.2641	.3395	.3018	.3018	.2641
17	.3018	.3395	.3395	.3395	.2641	.3018	.2641
18		.3395	.3018	.3395	.2641	.3018	.3018
19	.415	.4527	.415	.415	.3395	.3772	.3772
20	.4904	.4904	.4904	.4527	.4527	.4904	.4527
21	.4527	.4527	.4527	.4527	.4527	.4904	.4527
22	.4904	.415	.4527	.4527	.4527	.4527	.4527
23	.4527	.415	.415	.4527	.4527	.415	.415
24	.415	.3772	.3772	.3772	.415	.3772	.415
Max	.4904	.4904	.4904	.4527	.4527	.4904	.4527
Min	.3018	.3018	.2641	.2641	.2641	.2641	.2641
Avg	.3772	.3678	.3442	.3662	.3411	.3442	.3496

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

BHOSARI DIVISION[309]

AKURDI SUB-DN.[595] BU 4595

Substation No/ Name :- 213430 / 22/22 KV RIVER RESIDENCY

Feeder No / Name : 302 / BARNEWASTI Urban/Sheddable Urban Feeder
Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.8861	2.1125	2.2779	2.1125	2.0165	2.2257
2		1.8107	2.0748	2.1879	2.1502	1.9791	2.1502
3		1.773	2.0748	2.1879	2.037	1.9791	2.037
4		1.8107	2.037	2.1502	1.9993	1.9418	1.9993
5		1.8484	1.9616	2.1502	2.1125	1.9616	1.9616
6		1.9239	1.9239	2.1879	2.0748	1.9791	1.9993
7		1.9616	1.9993	2.1502	2.1125	2.1285	2.1879
8		1.9993	2.1502	2.1879	2.2257	2.2405	2.1502
9		2.5274	2.5652	2.4272	2.4143	2.3899	2.1502
10		2.9424	3.0178	2.9874	2.8292	2.8006	3.3573
11		3.0178	3.2065	3.062	3.131	2.9569	3.2819
12		2.5274	3.3196	2.8753	3.0178	3.2861	2.9424
13		2.5274	2.6783	2.6139	2.452	2.6886	2.3765
14		3.1687	3.0933	2.838	2.7915	2.9874	2.9424
15		3.131	3.131	1.9239	3.1687	3.062	3.1687
16		3.2114	3.2861	2.8753	3.062	3.2065	3.062
17		3.062	3.2114	2.6513	2.8006	2.9127	3.0994
18	1.6221	2.726	3.062	2.5766	2.5393	2.7633	2.5019
19	1.8107	2.726	2.9127	2.4646	2.5393	2.6029	2.4272
20	1.8861	2.4646	2.8006	2.2634	2.3899	2.7161	2.4646
21	1.8861	2.2779	2.5019	2.3011	2.1658	2.2779	2.3152
22	1.9616	2.2634	2.2634	2.2634	2.0911	2.3011	2.3388
23	1.9239	2.1879	2.3525	2.1502	2.0911		2.3011
24		1.8861	2.2257	2.3152	2.1502	2.0165	2.1125
Max	1.9616	3.2114	3.3196	3.062	3.1687	3.2861	3.3573
Min	1.6221	1.773	1.9239	1.9239	1.9993	1.9418	1.9616
Avg	1.8484	2.4025	2.5818	2.4195	2.4358	2.4867	2.4814

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

BHOSARI DIVISION[309]

BHOSARI II SUB-DN.[615] BU 4615

Substation No/ Name :- 213433 / ALANKAPURAM SWITCHING

Feeder No / Name : 301 / KHADI M/C ROAD

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7353	1.6975	1.6221	1.6221	1.7353	1.8107	1.8107
2	1.6975	1.6598	1.6975	1.6975	1.7353	1.773	1.8107
3	1.7353	1.6221	1.6975	1.8107	1.6975	1.7353	1.8107
4	1.7353	1.6221	1.6598	1.8107	1.6975	1.773	1.773
5	1.7353	1.6598	1.6598	1.773	1.6975	1.773	1.8107
6	1.6975	1.6975	1.6975	1.6975	1.7353	1.773	1.8107
7	1.6598	1.6975	1.6598	1.5844	1.7353	1.8107	1.773
8	1.6221	1.6598	1.6598	1.5089	1.8107	1.6598	1.6975
9	1.7353	2.2634	1.8484	1.4335	2.1879	1.9239	2.1502
10	2.2634	2.9047	3.0178	1.3957		3.0933	2.7161
11	2.452	3.5082	3.2442	1.358	2.8292	3.2819	3.546
12	2.4897	3.7346	2.4143	1.4335	2.8669	3.3951	2.9047
13	2.5652	3.0178	2.5652	1.5089	2.7915	2.6406	2.6029
14		2.6406	2.5274	1.4335	.7922	2.4143	2.8292
15	.9808	3.131	3.0556	1.5089	2.9047	3.3951	3.0933
16	.9431	2.2634	2.6029	1.5844	2.8292	3.5837	3.131
17	2.452	1.5466	2.6406	1.6975	2.9047	3.8855	3.2442
18	1.9993	2.1879	2.4143	1.6221	2.5652	2.9424	2.4897
19	1.6221		1.8861	1.6221	1.7353		1.8484
20	.9054	1.6221	1.6975	1.6221	1.773	1.8107	1.8484
21	1.6598	1.6598	1.8484	1.773	1.8484	1.8107	1.773
22	1.7353	1.8107	1.8107	1.8107	1.8861	1.8484	1.773
23	1.6975	24.4822	1.8107	1.773	1.8107	1.8484	1.773
24	1.7353	1.6975	1.6975	1.773	1.773	1.8107	1.8484
Max	2.5652	24.4822	3.2442	1.8107	2.9047	3.8855	3.546
Min	.9054	1.5466	1.6221	1.358	.7922	1.6598	1.6975
Avg	1.7763	3.1212	2.1015	1.6189	2.0584	2.3388	2.2445

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

BHOSARI DIVISION[309]

BHOSARI II SUB-DN.[615] BU 4615

Substation No/ Name :- 213433 / ALANKAPURAM SWITCHING

Feeder No / Name : 302 / SAI MANDIR

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6413	.679	.6413	.9431	.679	.7167	.679
2	.6413	.6413	.6413	.8676	.7167	.7167	.7167
3	.6413	.6413	.6413	.8299	.7167	.679	.7167
4	.6413	.6413	.6413	.7922	.7167	.679	.679
5	.679	.679	.679	.8299	.7545	.7545	.7167
6	.7545	.7922	.679	.8299	.7545	.7922	.8299
7	.7922	.7922	.8299	.7922	.7922	.8676	.9431
8	.8299	.9054	.9054	.7922	.8299	.9054	.9054
9	.679	.8676	.8676	.7922	.7922	.8299	.9054
10	.679	.9808	.9808	.7167		.8676	.9431
11	.679	.9054	.8676	.679	.7922	.9054	.7922
12	.7167	.9054	.8299	.679	.7922	.8676	.8299
13		.8299	.8299	.7545	.7922	.7167	.8299
14		.8676	.8299	.7922	.7922	.8299	.8299
15		.8676	.7922	.7545	.8299	.8299	.8676
16		.8299	.7545	.7167	.7922	.8676	.8676
17	.7545	.7922	.7922	.7167	.7922	.8299	.7545
18	.7922	.7545	.7922	.6413	.7922	.7545	.7922
19	.8299		.8676	.7545	.8676	.7545	.9054
20	.9431	1.094	.9431	.9431	1.0185	1.0562	1.0562
21	.9054	1.0185	1.0185	.9054	1.0185	.9808	.9808
22	.8676	.9054	1.0185	.8299	.9808	.9808	.9431
23	.0754	.8299	.9808	.7545	.9054	.9054	.8676
24	.679	.679	.679	.9808	.679	.8299	.7167
Max	.9431	1.094	1.0185	.9808	1.0185	1.0562	1.0562
Min	.0754	.6413	.6413	.6413	.679	.679	.679
Avg	.7111	.8217	.8126	.7953	.8086	.8299	.8362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

BHOSARI DIVISION[309]

BHOSARI II SUB-DN.[615] BU 4615

Substation No/ Name :- 213433 / ALANKAPURAM SWITCHING

Feeder No / Name : 303 / CHARHOLI PHATA

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5089	1.6221	1.5466	1.9239	1.8107	1.6975	1.7353
2	1.5089	1.5844	1.5089	1.9239	1.8107	1.6598	1.6975
3	1.5089	1.5844	1.5089	1.8107	1.8861	1.6221	1.6975
4	1.5089	1.6221	1.5089	1.8107	1.9616	1.6598	1.6598
5	1.5844	1.6975	1.6221	1.8861	2.037	1.8861	1.773
6	1.7353	1.8484	1.6975	1.9239	2.1125	1.9239	2.1125
7	1.8484	2.2257	2.2257	1.9993	2.1125	2.7161	2.3388
8	2.037	2.7915	2.6783	1.9239	2.1502	2.5652	2.7538
9	2.6783	2.7915	2.7161	1.8861	2.1125	2.3765	2.3765
10	2.6406	2.4143	2.4897	1.9993		2.7161	2.7538
11	2.6406	3.0556	2.452	1.9239	2.1125	1.9616	2.1502
12	2.2634	2.6406	2.8669	2.4143	2.8669	2.6406	2.037
13	2.452	2.6406	2.7915	2.3388	1.8861	1.9616	2.1879
14	1.8861	2.0748	2.6406	1.8861	2.2634	1.9616	1.8861
15	2.4143	2.3388	2.3765	1.5844	2.5652	2.7161	2.1125
16	2.452	2.1502	2.7161	1.6598	2.5652	2.8669	2.4143
17	2.1502	1.9616	1.5089	1.5844	2.9047	2.3011	2.2634
18	1.6221	2.3388	1.6975	1.6598	2.3765	2.2257	2.2634
19	2.1125	1.773	1.773	1.7353	1.9239	1.8861	1.6598
20	2.5652	2.037	2.6406	2.2257	2.3388	2.1879	2.1502
21	2.0748	2.3388	2.7915	2.1879	2.1879	2.6029	2.6029
22	1.9616	1.8107	2.4897	2.0748	2.3011	2.1125	2.6406
23	1.8107	1.773	2.2634	1.9616	1.9239	2.037	1.8861
24	1.6598	1.6975	1.6221	2.037	1.773	1.8107	1.8107
Max	2.6783	3.0556	2.8669	2.4143	2.9047	2.8669	2.7538
Min	1.5089	1.5844	1.5089	1.5844	1.773	1.6221	1.6598
Avg	2.0260	2.1172	2.1722	1.9317	2.1732	2.1706	2.1235

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

BHOSARI DIVISION[309]

PRADHIKARAN SUB-DN[676] BU 4676

Substation No/ Name :- 213423 / 22 KV Celestial City S/W stn

Feeder No / Name : 301 / 22 KV Ravet (KIWALE old) Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904			.5281	.5281		.5281
2	.4527		.4904	.5658	.5281		.4527
3	.4527				.5281		.4527
4	.5281			.5281	.5281		.4904
5			.4527		.5658		.5281
6	.6036		.4904	2.3663	.5658		.5658
7			.5281	2.6749			.6036
8	.6036		.5658		.6036	.6413	.5281
9	.5281	.7545	.5281	.5281	.5658	.5281	.4904
10	.5658	.6413	.4904	.6036	.5281	.5658	.5281
11	.4904	.5658	.4904			.5281	.5281
12	.5281	.5281	.5281			.5658	.5281
13	.4527	.4904	.5281	.5281	.4527	.5281	.4904
14		.4904	.4527	.5281	.4904	.4904	.4904
15				.5658	.5281	.4904	.5281
16		.4904	.5281			.4904	
17				.5281			
18	.4904	.4527	.5281	.4904			
19	.5658			.4904		.5281	
20	.679		.6413	.6413		.6413	
21	.679	.5658		.679		.6413	
22	.679		.679	.679			
23		.5281		.6036		.6036	
24	.5281			2.1605	.5658		.5281
Max	.679	.7545	.679	2.6749	.6036	.6413	.6036
Min	.4527	.4527	.4527	.4904	.4527	.4904	.4527
Avg	.5481	.5508	.5281	.8716	.5368	.5571	.5163

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

BHOSARI DIVISION[309]

PRADHIKARAN SUB-DN[676] BU 4676

Substation No/ Name :- 213423 / 22 KV Celestial City S/W stn

Feeder No / Name : 302 / 22 kv Celestial City Urban/Sheddable Urban Feeder
Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509			.2641	.2263		.2263
2	.1509		.1886	.2263	.2263		.2263
3	.1509			.2263	.2263		.1886
4	.1509			.2263	.2263		.1886
5	.1509		.1886	.2263	.2263		.1886
6	.1886		.1509	.2263	.2263		.1886
7	.2263		.1509	.2263	.2263		.2263
8	.1886		.1886	.2263	.2263	.2263	.2641
9	.2263	.3772	.2641	.2263	.2641	.2641	.2263
10	.2263	.6413	.2641	.2263	.2263	.2263	.1886
11	.2263	.2641	.2263			.2263	.1886
12	.1886	.2263	.2263			.2263	.1886
13	.1886	.1886	.2263	.2641	.2641	.1886	.1886
14		.1886	.2263	.2641	.2263	.1886	.1509
15		.1886		.2263	.1886	.1886	.1509
16		.2263	.1886			.1886	
17				.1886			
18	.2263	.4527		.1886			
19	.2263			.2263		.2263	
20	.2641		.2641	.2641		.2641	
21	.3018	.2641	.2263	.2641		.2641	
22	.2641		.2641	.2641			
23		.2263		.2641		.2641	
24	.1886			.2641	.2263		.2263
Max	.3018	.6413	.2641	.2641	.2641	.2641	.2641
Min	.1509	.1886	.1509	.1886	.1886	.1886	.1509
Avg	.2045	.2949	.2163	.2371	.2290	.2263	.2004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

BHOSARI DIVISION[309]

PRADHIKARAN SUB-DN[676] BU 4676

Substation No/ Name :- 213423 / 22 KV Celestial City S/W stn

Feeder No / Name : 303 / 22 kv Kiwale (New) Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.7154			2.6406	2.3388		2.3388
2	4.5645		2.2634	2.7161	2.2634		2.2634
3	5.0926			2.5652	2.2634		2.1879
4	5.0926			2.5652	2.452		2.2634
5			2.3388	2.452	2.2634		2.6406
6	6.3375		2.5274	2.6029	2.452		2.8292
7	6.0357		2.8292	2.7915	2.5652		3.131
8	6.0357		2.7161	2.8292	2.6406	2.7161	2.8292
9	.6413		2.7161	2.8669	2.6783	2.7161	2.7538
10	.6036	.3395	2.7161	2.9047	2.7161	2.6406	2.6406
11	.6036	2.9047	2.4897	2.7161		2.5652	2.6406
12	.5281	2.8292	2.4143			2.5274	2.452
13	.5658	2.6783	2.3765	2.6783	2.2257	2.3765	2.4897
14		2.6029	2.3765	2.7161	2.5652	.415	2.3765
15		2.6783		2.6783	2.6029	2.3388	2.5274
16		2.7161	2.2634			2.2634	
17				2.5652			
18	2.452	2.5274	3.131	2.3388			
19	2.7161			2.6406		2.8669	
20	3.2442		3.5837	3.2819		3.0933	
21	3.2065	2.6406		3.131		3.0933	
22	3.0178		3.2065	3.0933			
23		2.6783		2.7538		2.7915	
24	4.904			2.6029	2.452		2.452
Max	6.3375	2.9047	3.5837	3.2819	2.7161	3.0933	3.131
Min	.5281	.3395	2.2634	2.3388	2.2257	.415	2.1879
Avg	3.3532	2.4595	2.6632	2.7332	2.4628	2.4926	2.5510

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

BHOSARI DIVISION[309]

PRADHIKARAN SUB-DN[676] BU 4676

Substation No/ Name :- 213423 / 22 KV Celestial City S/W stn

Feeder No / Name : 304 / 22 kv Adarshnagar Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8299				.4904		.4904
2	.8299		.8299		.4904		.4527
3	.8299				.4904		.415
4	.9054				.4904		.4904
5	.9808		.9054		.5281		.5281
6	1.0562		.8676		.5281		.5658
7	.9808		1.0185		.5658		.679
8	.9808		1.0185		.6036	.5658	.5658
9	.9054	.679	.5281		.4904	.4527	.5281
10	.7922	.5281	.5281	.6036	.4904	.4904	.4904
11	.3772	.415	.4904			.4527	.3772
12		.3772	.4527			.4527	.3772
13		.3395	.3772	.4527	.5281	.415	.3772
14		.3772	.3772		.4904	.415	.3772
15		.3772		.5281	.4527	.415	.3772
16		.3772	.3772			.415	
17				.4527			
18	1.094	.7922	.5281	.4527			
19	1.0562			.4527		.5281	
20	1.2071		.6413	.6036		.6036	
21	1.2071	1.1317		.6413		.6413	
22	1.1694			.6413			
23		.0754	.6036	.5658		.5658	
24	.8676				.5281		.5281
Max	1.2071	1.1317	1.0185	.6413	.6036	.6413	.679
Min	.3772	.0754	.3772	.4527	.4527	.415	.3772
Avg	.9453	.4972	.6363	.5395	.5120	.4933	.4762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

BHOSARI DIVISION[309]

PRADHIKARAN SUB-DN[676] BU 4676

Substation No/ Name :- 213436 / 22 KV Devi Indrayani S/W

Feeder No / Name : 301 / 22 KV Dehugaon Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	2.6749	1.6804		2.2291	2.0919	2.6406
2	1.2689	2.6063	1.7833		2.0919	1.9204	2.5377
3	1.749	2.572	1.749		2.1262	2.1262	2.5034
4	1.8519	2.5377	1.8861		2.2291	2.1948	2.5034
5	2.2291	3.1893	1.8176		2.332	2.3663	3.2579
6	2.572	3.5665	1.9204	2.3663	2.6063	2.6406	3.6008
7	2.7778	3.738	2.0233	2.6749		2.6749	3.7037
8	2.6749	3.5665	1.9204	2.6406		2.7092	3.5322
9	3.0864	3.7037	1.8861	2.6749		2.5377	3.6008
10	3.4294		1.8176	2.4348		2.4348	3.6351
11	2.7778	2.4006	1.6461	2.4348	2.2634	2.332	3.3951
12	2.8464		1.5432		2.1262	2.0576	3.1893
13	2.572	2.1262	1.406	2.0576	1.9547	2.0919	3.0178
14	2.6063	2.1948	1.5775	2.2291	2.1948	2.0919	2.9835
15	2.6406	1.4746	1.5432		1.989	2.1948	2.8807
16	2.7092	2.1948	1.5775	1.166	2.1948	2.0919	
17	2.8121	2.0919	1.3717	2.572	2.1605	1.9547	1.8861
18	2.7435	2.2634	1.6118	2.4348	2.3663	2.2291	2.0576
19	3.0521	.3086	1.8176	2.7092	2.5034	2.4348	3.0178
20	3.6351	2.0576	3.0521	3.0178	3.0178	2.915	3.155
21	3.5665	2.0233	2.8464	2.7435	2.8121	2.915	3.1207
22	3.3951	1.8519	2.6063	2.572	2.7435	2.8121	
23	3.155	1.6804	2.332	2.5377	2.4348	2.4348	2.7092
24	1.4403	2.7092	1.5775		2.332	2.3663	2.7778
Max	3.6351	3.738	3.0521	3.0178	3.0178	2.915	3.7037
Min	1.2689	.3086	1.3717	1.166	1.9547	1.9204	1.8861
Avg	2.6235	2.4333	1.8747	2.4541	2.3354	2.3591	2.9866

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

DECCAN GYMAKHANA S/D[611] BU 4611

Substation No/ Name :- 213370 / 22/11 kV Devagi Substation

Feeder No / Name : 201 / 11 KV Suma Shilp Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7356	.6979	.7167	.9431	.8676	.7545
2	.8299	.7545	.679	.6979	.9242	.8488	.7167
3	.811	.7167	.6602	.7356	.8865	.8299	.7167
4	.7922	.7356	.679	.7545	.7733	.811	.6979
5	.8865	.7733	.6224	.7733	.7922	.8299	.7167
6	.9242	.7545	.6413	.8299	.7545	.8865	.7356
7	1.0185	.7545	.7545	.8676	.7922	1.0562	.811
8	1.1128	.811	.8676	.8865	.7733	1.1506	.9619
9	1.226	1.1317	.9431	.9242	1.1128	1.2449	1.2826
10	1.4146	1.6221	1.094	.9619	1.6787	1.5466	1.6221
11	1.5089	1.6598	1.2826	1.1506	1.905	1.7164	1.6975
12	1.5655	1.6032	1.3203	1.1128	1.7353	1.6975	1.7541
13	1.5655	1.6221	1.226	1.1506	1.6787	1.773	1.6221
14	1.5844	1.6787	1.2637	1.1128	1.6787	1.8484	1.6598
15	1.6221	1.6787	1.2637	1.094	1.6975	1.8861	1.6787
16	1.6221	1.7353	1.1317	1.1128	1.6032	1.9239	1.6409
17	1.6598	1.6787	1.1317	1.0751	1.6787	1.7164	1.6032
18	1.5844	1.6221	1.226	.9808	1.6032	1.7164	1.6975
19	1.6409	1.5278	1.3014	1.0374	1.7164	1.6221	1.7918
20	1.5466	1.4523	1.3203	1.1317	1.7353	1.5466	1.6598
21	1.4335	1.2449	1.2826	1.1128	1.4523	1.4523	1.5089
22	1.094	1.0751	1.0185	1.0751	1.2826	1.226	1.1694
23	1.0185	.8488	.8488	1.0374	.9431	.9619	1.0374
24	.7733	.7545	.6979	.6979	.9431	.8676	.811
Max	1.6598	1.7353	1.3203	1.1506	1.905	1.9239	1.7918
Min	.7545	.7167	.6224	.6979	.7545	.811	.6979
Avg	1.2496	1.2071	.9981	.9596	1.2952	1.3344	1.2645

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

DECCAN GYMAKHANA S/D[611] BU 4611

Substation No/ Name :- 213370 / 22/11 kV Devagi Substation

Feeder No / Name : 202 / 11 KV PYC Gymkhana Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9997	1.1317	1.0185	1.1317	1.0185	.9808	1.0562
2	1.0185	1.094	1.0562	1.1128	.9997	.9619	1.0562
3	1.0751	1.0562	1.094	1.094	.9619	.9808	1.0185
4	1.0562	1.0751	1.1128	1.1128	.9431	.9431	1.0185
5	.9997	1.1128	1.1694	1.1317	.9808	.9997	1.0562
6	1.1317	1.1883	1.2071	1.1506	1.0374	1.1128	1.0751
7	1.226	1.226	1.2449	1.226	1.1317	1.2449	1.1317
8	1.3203	1.358	1.4523	1.3203	1.2449	1.4901	1.3014
9	1.7353	1.7164	1.6598	1.3203	1.5466	1.6975	1.7164
10	2.0748	2.2445	2.32	1.4523	2.1313	2.1691	2.1125
11	2.2257	2.5274	2.3954	1.5278	2.4709	2.2634	2.2445
12	2.452	2.5463	2.5652	1.905	2.4897	2.3011	2.4897
13	2.1879	2.4331	2.4143	1.773	2.32	2.2068	2.3011
14	2.2634	2.2822	2.1879	1.6221	2.3011	2.2634	2.3577
15	2.2822	2.3388	2.2445	1.5466	2.3954	2.2634	2.3011
16	2.2634	2.452	2.1313	1.5466	2.2822	2.2257	1.5466
17	2.2257	2.2822	1.8861	1.3957	2.3388	2.1879	1.5089
18	2.2257	2.3388	1.9993	1.3392	2.037	2.0748	1.4335
19	2.3577	2.2822	2.0559	1.5278	2.2634	2.2822	1.5089
20	2.2822	1.905	2.037	1.773	2.0748	2.2068	1.5655
21	1.905	1.5278	1.9993	1.6409	1.8673	1.9616	1.6032
22	1.5278	1.4335	1.5655	1.6221	1.7541	1.5655	1.2637
23	1.4712	1.2449	1.3014	1.5844	1.3203	1.4523	1.0185
24	1.0751	1.1506	1.0562	1.1317	1.0562	.9997	1.0751
Max	2.452	2.5463	2.5652	1.905	2.4897	2.3011	2.4897
Min	.9997	1.0562	1.0185	1.094	.9431	.9431	1.0185
Avg	1.7243	1.7478	1.7156	1.4162	1.7070	1.7015	1.5317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

DECCAN GYMAKHANA S/D[611] BU 4611

Substation No/ Name :- 213370 / 22/11 kV Devagi Substation

Feeder No / Name : 203 / 11 KV Sanjivani Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3584	.3584	.3772	.3395	.3395	.3961	.3772
2	.3395	.3395	.3584	.3584	.3584	.3772	.3772
3	.3206	.3206	.3206	.3772	.3395	.3584	.3395
4	.3584	.3395	.3395	.3584	.3206	.3395	.3395
5	.3772	.3584	.3584	.3395	.3206	.3584	.3584
6	.415	.3395	.3772	.3206	.3584	.3772	.3961
7	.4715	.3772	.415	.3584	.3772	.4527	.3961
8	.5281	.415	.4527	.3961	.415	.547	.415
9	.5847	.5847	.547	.3772	.6036	.6036	.6036
10	.6413	.6602	.6602	.3961	.679	.6224	.7167
11	.6602	2.2445	.6979	.4527	.7356	.7733	.679
12	.6413	2.3954	.6979	.4527	.811	.6602	.7167
13	.7545	2.4709	.7922	.415	.811	.7167	.7545
14	.7545	2.2634	.7167	.4715	.7167	.7167	.7545
15	.7545	2.4331	.7545	.4338	.7922	.679	.679
16	.679	.679	.6413	.3772	.679	.6602	.679
17	.6413	.6413	.5847	.4527	.6224	.6602	.679
18	.5847	.5847	.5281	.3961	.5847	.6036	.5847
19	.5658	.5847	.6224	.4338	.547	.6036	.6036
20	.6036	.5658	.5658	.5093	.5281	.547	.547
21	.5658	.4904	.6036	.4715	.5093	.5093	.5658
22	.4904	.4715	.5847	.4527	.4527	.5093	.4904
23	.4715	.4338	.4338	.415	.415	.4338	.4715
24	.3584	.3584	.3772	.3772	.3395	.3961	.3961
Max	.7545	2.4709	.7922	.5093	.811	.7733	.7545
Min	.3206	.3206	.3206	.3206	.3206	.3395	.3395
Avg	.5383	.8629	.5336	.4055	.5273	.5376	.5383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

DECCAN GYMAKHANA S/D[611] BU 4611

Substation No/ Name :- 213370 / 22/11 kV Devagi Substation

Feeder No / Name : 301 / 22 KV Paranjpe Scheme

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.0754	.0754	.0754	.0754	.0377
2	.0754	.0754	.0754	.0754	.0754	.0754	.0377
3	.0377	.0754	.0754	.0754	.0754	.0754	.0377
4	.0377	.0754	.0754	.0377		.0754	.0377
5	.0377	.0754	.0754	.0377	.0377	.0754	.0377
6	.0377	.0754	.0754	.0377	.0377	.0754	.0377
7	.0377	.0754	.0754	.0377	.0377	.0754	.0377
8	.0377	.0754	.0754	.0377	.0377	.0754	.0377
9	.0377	.0754	.0754	.0377	.0377	.0754	.0377
10	.0754	.0754	.0754	.0754	.0754	.1132	.1509
11	.1886	.2641	.1886	.7922	.6036	.3772	.3772
12	.2263	.3018	.3018	.8299	.8299	.7545	.7545
13	.2641	.3018	.3018	.8299	.8299	.7545	.7545
14	.2641	.3018	.3018	.7922	.8299	.7545	.8299
15	.2641	.3018	.3018	.7922	.7922	.7922	.7922
16	.3018	.3018	.3018	.7545	.7545	.8299	.7922
17	.3018	.3018	.8299	.8299	.8299	.8299	.8299
18	.3018	.3018	.8299	.8299	.8299	.7545	.8299
19	.3018	.2263	.8299	.8299	.8299	.7922	.8299
20	.3018	.3018	.8299	.8299	.7545	.7545	.8299
21	.1886	.3018	.8299	.8299	.6413	.7545	.8299
22	.0754	.1886	.3772	.8299	.4904	.4527	.4904
23	.0754	.0754	.1132	.7922	.2263	.0754	.1132
24	.0754	.0754	.0754	.1132	.5658	.1132	.0754
Max	.3018	.3018	.8299	.8299	.8299	.8299	.8299
Min	.0377	.0754	.0754	.0377	.0377	.0754	.0377
Avg	.1509	.1792	.2986	.4668	.4477	.3992	.4008

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

KOTHRUD SUB-DN.[613] BU 4613

Substation No/ Name :- 213004 / 22KV SNDT

Feeder No / Name : 203 / 11 KV KOTHRUD

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1389	1.2136		1.2323	1.2696	1.2883	1.2696
2	1.1203	1.1763		1.1763	1.2136	1.1949	1.1949
3	1.1016	1.2323		1.1203	1.1763	1.1389	1.1576
4	1.2136	1.307	1.251	1.1949	1.2323	1.1576	1.2136
5	1.3256	1.3817	1.307	1.251	1.3256	1.251	1.3443
6	1.4377	1.4563	1.363	1.307	1.4003	1.4563	1.531
7	1.7551	1.5497	1.531	1.4377	1.5497	1.7177	1.6991
8	1.8858	1.643	1.7364	1.5684	1.8484	1.8298	1.8671
9	2.0725	1.9231	1.8484	1.7177	2.1285	2.0165	2.0538
10	2.1285	2.1285	2.2779	1.8671	2.3899	2.3339	2.2405
11	2.4086	2.4086	2.6326	2.1285	2.5766	2.6513	2.5019
12	2.4272	2.4832	2.5393	2.1098	2.4832	2.6326	2.5766
13	2.2965	2.4646	2.3712	1.9978	2.2032	2.3899	2.3899
14	2.2779	2.4272	2.1658	1.8298	2.3712	2.3152	2.2592
15	2.1658	2.4086	2.2032	1.8298	2.2965	2.2779	2.1845
16	2.3525	2.4832	2.1845	1.7551	2.3339	2.3712	2.3525
17	2.3899	2.5206	2.1098	1.7364	2.3899	2.4272	2.3712
18	2.3712	2.4086	2.2032	1.7737	2.3152	2.3899	2.3525
19	2.4272		2.3339	2.0538	2.3152	2.3712	2.5019
20	2.2965	2.2779	2.2965	2.2405	2.3525	2.4832	2.5206
21	2.0351	1.9791	2.0351	1.9978	2.0538	2.0725	2.2032
22	1.7364	1.7177	1.7551	1.5684	1.8484	1.8298	1.8484
23	1.5497	1.475	1.6057	1.5684	1.6244	1.6244	1.643
24	1.251	1.307	1.2696	1.363	1.3817	1.4003	1.3443
Max	2.4272	2.5206	2.6326	2.2405	2.5766	2.6513	2.5766
Min	1.1016	1.1763	1.251	1.1203	1.1763	1.1389	1.1576
Avg	1.8819	1.8858	1.9533	1.6594	1.9200	1.9426	1.9426

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

KOTHRUD SUB-DN.[613] BU 4613

Substation No/ Name :- 213004 / 22KV SNDT

Feeder No / Name : 301 / 22 KV PUAD ROAD

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1719	2.3243		1.9814	2.1338	2.0576	2.0195
2	2.2481	2.21		1.5242	1.9814	1.9433	1.9814
3	2.4006	2.3624		1.8671	1.9814	1.9052	1.9433
4	2.6673	2.553		1.9433	2.1338	1.8671	1.9052
5	3.0102	2.8578		2.0195	2.2862	2.1338	1.9814
6	3.315	3.0864		2.1719	2.4387	2.5911	2.553
7	3.3913	3.3913		2.3624	2.6292	2.7435	2.7054
8	3.6199	3.5437		2.7054	2.7435	2.8578	2.8959
9	3.4675	3.2007	5.4108	2.7435	2.6673	2.7435	2.8197
10	3.4294	3.4675	4.6868	2.8959	2.6292	2.7816	2.7054
11	3.0483	3.1245	4.7249	2.8959	3.2007	2.6673	2.7054
12	2.7816	2.8959	4.6106	2.7816	2.6673	2.5911	2.5911
13	2.7816	2.8578	4.6487	2.6673	2.6292	2.5149	2.6292
14	2.7054	2.7054	3.2007	2.553	2.5911	2.553	2.3624
15	2.5911	2.6673	3.2007	2.4387	2.4387	2.4006	2.3243
16	3.0102	3.0864	2.4768	2.4006	2.4768	2.4006	2.3624
17	3.0102	3.2388	2.6673	2.553	2.5149	2.5911	2.5149
18	3.3913	3.1626	2.7435	2.6292	2.7054	2.7435	2.7435
19	3.7723		3.1626	3.0864	3.0864	3.1245	2.9721
20	3.5818	5.0678	3.5437	3.4294	3.4294	3.5056	3.4294
21	3.4294	5.4108	3.2769	3.2769	3.315	3.315	3.2769
22	3.5437	4.763	2.8959	2.7054	2.934	2.9721	2.9721
23	2.8959	3.8485	2.7054	2.6673	2.5911	2.6673	2.6673
24	2.3243	2.4387	3.2769	2.21	2.2862	2.21	2.2481
Max	3.7723	5.4108	5.4108	3.4294	3.4294	3.5056	3.4294
Min	2.1719	2.21	2.4768	1.5242	1.9814	1.8671	1.9052
Avg	3.0245	3.2289	3.5770	2.5212	2.6038	2.5784	2.5546

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

KOTHRUD SUB-DN.[613] BU 4613

Substation No/ Name :- 213004 / 22KV SNDT

Feeder No / Name : 302 / ARAI-1

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.8299	.679	.5658	.3429	.7167	.5281
2	.7167	.7922	.6036	.5281	.3429	.7167	.5281
3	.7167	.7922	.679	.5281	.3395	.7167	.5281
4	.7545	.8299	.6413	.4527	.2641	.7167	.4527
5	.7167	.8299	.6036	.3772	.3395	.7167	.4527
6	.679	.8299	.6036	.3395	.3395	.7167	.5658
7	.7545	.8676		.3395	.415	.7545	.5281
8	.679	.7922		.3395	.4527	.7167	.4904
9	1.3957	1.6221	1.2826	.3395	1.6975	1.5089	1.6975
10	1.5466	1.8107	1.358	.3772	1.7353	1.6221	1.9616
11	1.6598	1.8107	1.6598	.3772	1.8861	1.7353	1.8107
12	1.9993	2.1502	1.6975	.1132	2.1125	1.8107	2.1125
13	1.5466	1.6598	1.4712	.3772	1.6221	1.6975	1.773
14	1.6221	1.5844	1.2449	.3772	2.037	1.5466	1.773
15	2.0748	1.9616	1.5466	.3772	2.2634	2.1125	2.1125
16	1.6975	1.8107	1.4335	.3772	2.4143	1.8861	1.9993
17	1.6598	1.8484	1.0562	.3772	1.773	1.5089	1.6598
18	1.2826	1.5089	.679	.3772	1.6221	1.2826	1.4335
19	1.5844	1.3957	.415	.3395	1.5466	1.094	1.4712
20	1.5466	1.2826	.3772	.3772	1.2826	1.2826	1.2826
21	1.6221	1.2449	.3772	.3772	1.2449	1.1694	1.2826
22	.8299	.7167	.5658	.3395	.7922	.6036	.6413
23	.7922	.7167	.6413	.3395	.7468	.6036	.679
24	.7167	.8299	.679	.5658	.3395	.7468	.5658
Max	2.0748	2.1502	1.6975	.5658	2.4143	2.1125	2.1125
Min	.679	.7167	.3772	.1132	.2641	.6036	.4527
Avg	1.2228	1.2716	.9225	.3866	1.1647	1.1659	1.1804

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

KOTHRUD SUB-DN.[613] BU 4613

Substation No/ Name :- 213004 / 22KV SNDT

Feeder No / Name : 303 / ARAI-2

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1143	.1143	.1143	.1143	.1143	.1143
2	.1143	.1143	.1143	.1143	.1143	.1143	.1143
3	.1143	.1143	.1143	.1143	.1143	.1143	.1143
4	.1143	.1143	.1143	.1143	.1143	.1143	.1143
5	.1143	.1143	.1143	.1143	.1143	.1143	.1143
6	.1143	.1143	.1143	.1143	.1143	.1143	.1143
7	.1143	.1143	.1143	.1143	.1143	.1143	.1143
8	.1143	.1143	.1143	.1143	.1143	.1143	.1143
9	.1143	.1143	.1143	.1143	.1143	.1143	.1143
10	.1143	.1143	.1143	.1143	.1143	.1143	.1143
11	.1143	.1143	.1143	.1143	.1143	.1143	.1143
12	.1143	.1143	.1143	.1143	.1143	.1143	.1143
13	.1143	.1143	.1143	.1143	.1143	.1143	.1143
14	.1143	.1143	.1143	.1143	.1143	.1143	.1143
15	.1143	.1143	.1143	.1143	.1143	.1143	.1143
16	.1143	.1143	.1143	.1143	.1143	.1143	.1143
17	.1143	.1143	.1143	.1143	.1143	.1143	.1143
18	.1143	.1143	.1143	.1143	.1143	.1143	.1143
19	.1143	.1143	.1143	.1143	.1143	.1143	.1143
20	.1143	.1143	.1143	.1143	.1143	.1143	.1143
21	.1143	.1143	.1143	.1143	.1143	.1143	.1143
22	.1143	.1143	.1143	.1143	.1143	.1143	.1143
23	.1143	.1143	.1143	.1143	.1143	.1143	.1143
24	.1143	.1143	.1143	.1143	.1143	.1143	.1143
Max	.1143	.1143	.1143	.1143	.1143	.1143	.1143
Min	.1143	.1143	.1143	.1143	.1143	.1143	.1143
Avg	.1143	.1143	.1143	.1143	.1143	.1143	.1143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

KOTHRUD SUB-DN.[613] BU 4613

Substation No/ Name :- 213004 / 22KV SNDT

Feeder No / Name : 304 / 22 KV SNDT PUMPING

Only one consumer of WW with HT-IV

Feeder KV- 22 / OUTGOING

DATE	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4954	.4954	.4954	.6478
2		.5716	.4954	.4954	.6478
3		.6859	.6859	.6859	.724
4		.7621	.8002	.724	.724
5		.8764	.9145	.8002	.9145
6		.9526	.9907	.8764	1.0669
7		.6859	.8383	.724	.7621
8		.724	.724	.724	.8002
9		.724	.7621	.7621	.8383
10		.7621	.5335	.7621	.6097
11		.5335	.5335	.5335	
12		.5335	.5335	.7621	.6097
13		.4954	.7621	.5335	.6097
14		.5335		.7621	.6097
15		.7621	.724	.5716	.6097
16	1.0669	.724	.7621	.8383	.8383
17	1.0669	.724	.7621	.8383	.8383
18	1.0288		.5335	.8383	.8002
19	.724	.4954	.5335	.6097	.6097
20	.5335	.5335	.5335	.6097	.6097
21	.5335	.5335	.5335	.6097	.6097
22	.724	.724	.724	.6097	.6097
23	.4954	.724	.724	.6097	.6097
24		.4954	.4954	.4954	.6478
Max	1.0669	.9526	.9907	.8764	1.0669
Min	.4954	.4954	.4954	.4954	.6097
Avg	.7716	.6544	.6693	.6780	.7107

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

KOTHRUD SUB-DN.[613] BU 4613

Substation No/ Name :- 213004 / 22KV SNTD

Feeder No / Name : 305 / 22 KV PETHKAR INCOMER 1 HV Non-Express Feeder
Feeder KV- 22 / INCOMING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7177	1.8671		1.9791	2.0911	2.0911	2.0165
2	1.6804	1.7924		1.9044	1.9791	2.0165	1.9791
3	1.6804	1.9418		1.8298	2.2405	1.9791	1.9418
4	2.3152	2.1658		1.9418	2.5019	2.1285	1.9791
5	2.5393	2.4646		2.1658	2.6886	2.2032	2.3152
6	2.726	2.6886		2.3525	2.9127	2.3152	2.8753
7	2.9127	2.9127		2.6139	2.9874	2.95	2.9874
8	3.0994	3.1367		2.8006	2.95	2.9127	3.1367
9	3.062	3.1367	3.1367	3.0994	2.9874	2.95	3.0247
10	2.8006	2.7633	2.8753	3.0247	2.7633	2.6513	2.726
11	.5975	2.5393	2.7633	2.95	2.6886	2.4272	2.6139
12	2.5019	2.4646	2.726	2.726	2.5019	2.2779	2.4646
13	2.3152	2.3899	2.3899	2.6139	2.3152	2.3525	2.3525
14	2.1285	2.2779	2.3525	2.5019	2.3525	2.3899	2.1658
15	2.0165	2.2032	2.3152	2.3525	2.2779	2.3152	2.1285
16	2.0538	2.2032	2.3152	2.4646	2.2405	2.2779	2.2032
17	2.0911	2.2779	2.3525	2.5019	2.2405	2.2779	2.1285
18	2.2405	2.4272	2.4646	2.5766	2.3525	2.3152	2.2405
19	2.726	2.9874	2.8006	2.838	2.726	2.6886	2.6513
20	3.0247	3.062	3.1741	3.2861	3.2861	3.2861	3.3234
21	3.0994	2.9874	2.9874	3.3608	3.2861	3.2861	3.2487
22	2.838	2.6886	2.9874	3.062	3.062	2.8753	3.0994
23	2.4646	2.2405	2.5393	2.726	2.6886	2.6139	2.6513
24	1.9044	2.0538	1.9791	2.2032	2.2032	2.2779	2.4646
Max	3.0994	3.1367	3.1741	3.3608	3.2861	3.2861	3.3234
Min	.5975	1.7924	1.9791	1.8298	1.9791	1.9791	1.9418
Avg	2.3557	2.4864	2.6349	2.5781	2.5968	2.4941	2.5299

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

KOTHRUD SUB-DN.[613] BU 4613

Substation No/ Name :- 213020 / 22 KV LOKMANYA SWITCHING

Feeder No / Name : 304 / 22 KV SAUDAMINI Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	1.5242	1.5242	1.5242	1.5242	1.5242	1.5242
2	2.8578	1.5242	1.3336	1.5242	1.5242	1.5242	1.5242
3	1.3336	1.3336	1.5242	1.5242	1.3336	1.3336	1.3336
4	1.3336	1.3336	1.3336		1.3336	1.3336	1.3336
5	1.3336	1.3336	1.3336	1.5242	1.5242	1.5242	1.5242
6	1.9052		1.5242	1.5242	1.7147	1.7147	1.9052
7	5.144	2.0957	1.7147	1.5242	2.0957	2.0957	2.0957
8	2.2862	2.2862	1.9052	1.7147	2.0957	2.2862	2.4768
9	2.6673	2.4768	2.2862	2.0957	2.8578	2.6673	2.6673
10	2.6673	2.6673	2.4768	2.0957		2.6673	2.6673
11	2.4768	2.6673	2.4768	2.0957	2.8578	2.6673	2.8578
12	2.4768	2.6673	2.2862	2.0957	2.6673	2.6673	2.4768
13	2.4768	2.4768	2.2862	1.9052	2.4768	2.4768	2.4768
14	2.2862	2.0957	2.0957	1.9052	2.2862	2.4768	2.2862
15	2.2862	2.4768	2.0957	1.9052	2.4768	2.2862	2.4768
16	2.2862	2.4768	1.9052	1.7147	2.4768	2.2862	2.4768
17	2.2862	2.2862	2.0957	1.9052	2.2862	2.4768	2.2862
18	2.2862	2.2862	2.0957	1.9052	2.4768	2.2862	2.2862
19	2.2862		2.0957	2.0957	2.2862	2.2862	2.2862
20	2.4768	2.4768	2.2862	2.2862	2.4768	2.4768	2.4768
21	2.2862	2.2862	2.4768	2.2862	2.4768	2.4768	2.4768
22	2.0957	1.9052	2.0957	2.0957	2.2862	2.2862	2.0957
23	1.9052	1.7147	1.9052	1.9052	1.9052	1.9052	1.9052
24	1.5242	1.5242	1.5242	1.7147	1.7147	1.7147	1.7147
Max	5.144	2.6673	2.4768	2.2862	2.8578	2.6673	2.8578
Min	1.3336	1.3336	1.3336	1.5242	1.3336	1.3336	1.3336
Avg	2.2704	2.0871	1.9449	1.8638	2.1371	2.1434	2.1513

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

KOTHRUD SUB-DN.[613] BU 4613

Substation No/ Name :- 213020 / 22 KV LOKMANYA SWITCHING

Feeder No / Name : 305 / 22 KV VED BHAVAN Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4768	2.6673	2.6673	2.8578	2.8578	2.8578	2.8578
2	2.4768	2.6673	2.4768	2.6673	2.6673	2.6673	2.6673
3	2.2862	2.4768	2.4768	2.6673	2.4768	2.4768	2.4768
4	2.2862	2.2862	2.2862	2.4768	2.4768	2.4768	2.4768
5		2.4768	2.2862	2.6673	2.6673	2.6673	2.8578
6	.9526	3.2388	2.8578	2.8578	3.2388	3.2388	3.4294
7	.9526	3.8104	3.4294	3.0483	3.8104	4.0009	3.8104
8	4.1914	3.8104	3.8104	3.6199	4.1914	4.1914	3.8104
9	4.1914	4.0009	4.0009	4.0009	4.0009	4.0009	4.0009
10	3.6199	3.6199	3.8104	4.0009		3.6199	3.4294
11	3.2388	3.4294	3.8104	3.6199	3.8104	3.6199	3.4294
12	3.2388	3.4294	3.4294	3.4294	3.4294	3.2388	3.0483
13	3.0483	3.0483	3.2388	3.4294	3.0483	3.2388	2.8578
14	2.8578	2.8578	3.0483	3.0483	3.0483	3.0483	2.8578
15	2.8578	2.8578	3.2388	3.0483	2.8578	3.0483	3.0483
16	2.8578	2.8578	3.0483	3.0483	3.0483	3.0483	3.0483
17	2.8578	3.0483	3.0483	3.2388	2.8578	3.0483	3.0483
18	3.0483	3.0483	3.2388	3.2388	3.0483	3.2388	3.2388
19	3.4294	3.8104	3.8104	3.6199	3.8104	3.4294	3.6199
20	3.8104	4.0009	4.1914	4.1914	4.0009	4.1914	4.1914
21	3.8104	3.8104		4.0009	4.1914	4.0009	4.1914
22	3.8104	3.6199	1.1431	3.6199	3.8104	3.8104	4.0009
23	3.4294	3.0483	4.0009	3.4294	3.4294	3.4294	3.4294
24	2.6673	2.8578	2.6673	3.2388	3.0483	3.0483	3.0483
Max	4.1914	4.0009	4.1914	4.1914	4.1914	4.1914	4.1914
Min	.9526	2.2862	1.1431	2.4768	2.4768	2.4768	2.4768
Avg	2.9738	3.1992	3.1311	3.2944	3.2968	3.3182	3.2865

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

KOTHRUD SUB-DN.[613] BU 4613

Substation No/ Name :- 213020 / 22 KV LOKMANYA SWITCHING

Feeder No / Name : 306 / 22 KV SUNDER NAGARI Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	1.7147	1.9052	1.9052	1.9052	1.9052	1.9052
2	1.7147	1.7147	1.7147	1.7147	1.7147	1.7147	1.7147
3	1.5242	1.5242	1.7147	1.7147	1.7147	1.7147	1.7147
4	1.5242	1.7147	1.7147	1.7147	1.7147	1.7147	1.7147
5	1.5242	1.7147	1.7147	1.7147	1.9052	2.0957	1.9052
6	2.0957	2.2862	2.0957	1.9052	2.2862	2.4768	2.2862
7	2.4768	2.2862	2.2862	2.0957	2.6673	2.6673	2.6673
8	2.8578	2.8578	2.6673	2.4768	3.0483	3.0483	3.0483
9	2.6673	3.0483	3.0483	2.8578	3.0483	3.0483	2.8578
10	2.4768	2.4768	3.0483	3.2388		2.8578	3.0483
11	2.2862	2.8578	3.2388	3.2388	2.6673	2.8578	2.8578
12	2.2862	2.6673	3.0483	2.8578	2.6673	2.6673	2.6673
13	2.0957	2.4768	2.8578	2.8578	2.6673	2.6673	2.6673
14	2.0957	2.4768	2.6673	2.8578	2.8578	2.6673	
15		2.4768	2.6673	2.6673	2.4768	2.4768	2.2862
16	1.9052	2.2862	2.2862	2.4768	2.2862	2.2862	2.2862
17	2.0957	2.4768	2.4768	2.6673	2.4768	2.4768	2.4768
18	2.2862	2.4768	2.4768	2.6673	2.4768	2.4768	2.4768
19	2.4768	2.8578	2.8578	2.8578	2.8578	2.8578	2.6673
20	2.8578	2.8578	3.2388	3.0483	3.0483	3.2388	3.2388
21	2.8578	2.8578		3.0483	3.0483	3.2388	3.6199
22	2.4768	2.6673	2.8578	2.8578	2.6673	2.8578	2.8578
23	2.2862	2.2862	2.4768	2.0957	2.4768	2.4768	2.4768
24	1.9052	1.7147	1.9052	2.0957	2.0957	2.0957	2.0957
Max	2.8578	3.0483	3.2388	3.2388	3.0483	3.2388	3.6199
Min	1.5242	1.5242	1.7147	1.7147	1.7147	1.7147	1.7147
Avg	2.1951	2.3656	2.4768	2.4847	2.4685	2.5244	2.5016

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

KOTHRUD SUB-DN.[613] BU 4613

Substation No/ Name :- 213374 / 22/11 KV PETHKAR

Feeder No / Name : 201 / 11 KV Pethkar Samrajya Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0943	.0943	.0953	.1132	.1132	.0566
2	.0943	.0754	.0943	.0953	.0943	.0943	.056
3	.0762	.0754	.0943	.0953	.0943	.0943	.0572
4	.0762	.0934	.0953	.0762	.1132	.132	.0572
5	.1132	.1307	.1143	.1132	.1509	.1886	.0572
6	.2241	.2075	.1698	.1698	.2241	.2075	.0762
7	.2241	.2054	.168	.1663	.2241	.1509	.0762
8	.2075	.1886	.1886	.1698	.2263	.1509	.0572
9	.2241	.1867	.2075	.2075	.1886	.132	.0754
10	.1867	.2075	.0189	.2075	.2075	.1307	.0754
11	.2096	.1494	.1886	.1886	.1886	.1109	.0747
12	.2054	.1494	.1886	.1886	.1509	.0934	.0566
13	.1494	.1494	.1509	.1886	.1509	.1494	.0566
14	.0934	.1494	.132	.1698	.1509	.1494	.0754
15	.0934	.1494	.132	.1509	.1307	.0381	.0566
16	.0934	.1307	.132	.132	.1307	.0572	.0754
17	.112	.1132	.132	.132	.1307	.0572	.0754
18	.1132	.132	.1132	.1132	.0914	.0566	.056
19	.132	.132	.132	.132	.132	.0762	.0754
20	.1509	.1509	.1509	.1509	.1509	.0754	.0943
21	.1886	.1509	.1509	.2452	.1698	.0762	.0943
22	.1524	.1509	.1698	.1524			.0762
23	.1132	.132	.1509	.1334	.132	.0762	.0754
24	.0943	.0943	.0943	.1143	.1132	.0572	.0762
Max	.2241	.2075	.2075	.2452	.2263	.2075	.0943
Min	.0762	.0754	.0189	.0762	.0914	.0381	.056
Avg	.1426	.1416	.1360	.1495	.1504	.1073	.0693

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

KOTHRUD SUB-DN.[613] BU 4613

Substation No/ Name :- 213374 / 22/11 KV PETHKAR

Feeder No / Name : 202 / 11 KV Paramhans Nagar Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8326	.8779	.8596	.9979	1.0164	.9979	.9795
2	.8413	.8596	.8145	.924	.9511	.9795	.9055
3	.823	.8326	.8145	.8507	.8779	.924	.9055
4	.8413	.8501	.8048	.8326	.8596	.8779	.9055
5	.8869	.924	.8779	.8962	.9709	.9694	.9795
6	1.1041	1.1389	1.0642	.9694	1.2883	1.2382	1.2197
7	1.3394	1.3306	1.1458	1.1088	1.3121	1.3121	1.2986
8	1.3756	1.363	1.307	1.2567	1.3306	1.3121	1.3676
9	1.5181	1.4784	1.4563	1.4045	1.4969	1.4415	1.46
10	1.39	1.46	1.46	1.46	1.423	1.423	1.3676
11		1.3306	1.3676	1.4784	1.4045	1.3535	1.3676
12	1.3756	1.3535	1.4815	1.46	1.3676	1.2437	1.2803
13	1.1523	1.2071	1.262	1.386	1.2567	1.2254	1.2127
14	1.1157	1.1458	1.2254	1.3121	1.1827	1.1643	1.1523
15	1.1222	1.1643	1.2071	1.2752	1.1458	1.1458	1.1458
16	1.1041	1.1827	1.2071	1.2567	1.0903	1.1458	1.1273
17	1.2071	1.2012	1.1888	1.2567	1.1088	1.1088	1.1273
18	1.3169	1.3121	1.2437	1.2752	1.1462	1.1706	1.1222
19	1.3535	1.4045	1.4449	1.4045	1.3253	1.3213	1.3611
20	1.5023	1.423	1.5546	1.6817	1.5203	1.5565	1.5746
21	1.5181	1.4415	1.5729	1.5524	1.5565	1.5364	1.5023
22	1.3306	1.2489	1.4415	1.4266			1.39
23	1.1273	1.0974	1.2382	1.3306	1.262	1.2254	1.2012
24	.9145	1.0164	.9328	1.1203	1.0719	1.0164	1.0903
Max	1.5181	1.4784	1.5729	1.6817	1.5565	1.5565	1.5746
Min	.823	.8326	.8048	.8326	.8596	.8779	.9055
Avg	1.1779	1.1935	1.2072	1.2466	1.2159	1.2039	1.2102

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

KOTHRUD SUB-DN.[613] BU 4613

Substation No/ Name :- 213374 / 22/11 KV PETHKAR

Feeder No / Name : 203 / 11 KV Shivtirth Nagar Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075	.2286	.2075	.2452	.2641	.2263	.2263
2	.2075	.2096	.1905	.2263	.2452	.2075	.2075
3	.1886	.1905	.1905	.1886	.2075	.2263	.2075
4	.2263	.1905	.1886	.1886	.2263	.2641	.2075
5	.2667	.2641	.2263	.2263	.2641	.2801	.3018
6	.3772	.3734	.3206	.3361	.3921	.3547	.4294
7	.4108	.3961	.3584	.3395	.3921	.4108	.3511
8	.4338	.4338	.415	.3584	.4338	.3395	.4338
9	.4338	.4527	.4715	.4338	.4527	.3772	.415
10	.3961	.3429	.3961	.4527	.3961	.362	.3961
11	.3881	.3772	.3772	.4338	.3395	.3239	.3734
12	.2987	.3395	.3584	.415	.3395	.2263	.3018
13	.2829	.2829	.2477	.3584	.2452	.3206	.2477
14	.2263	.2829	.2477	.3206	.2452	.2829	.2096
15	.1886	.2641	.2286	.2829	.2075	.2829	.1886
16	.2075	.2641	.2667	.2641	.2096	.2641	.2263
17	.2286	.2452	.2667	.2829	.2286	.2987	.2286
18	.2641	.2829	.2858	.3018	.2263	.2452	.2263
19	.2829	.3206	.3239	.3772	.2801	.2829	.2829
20	.381	.3395	.362	.3584	.3584	.3584	.3584
21	.3584	.3206	.362	.362	.3395	.3584	.3584
22	.3584	.3206	.3206	.3584			.3584
23	.3048	.2829	.3048	.3584	.3018	.2829	.2858
24	.2263	.2477	.2263	.2641	.2477	.2477	.2667
Max	.4338	.4527	.4715	.4527	.4527	.4108	.4338
Min	.1886	.1905	.1886	.1886	.2075	.2075	.1886
Avg	.2977	.3022	.2976	.3222	.2975	.2967	.2954

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

KOTHRUD SUB-DN.[613] BU 4613

Substation No/ Name :- 213374 / 22/11 KV PETHKAR

Feeder No / Name : 204 / 11 KV Sutardara

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4424	.547	.5281	.5658	.6036	.679	.5847
2	.4475	.5228	.5281	.5281	.5658	.7545	.5658
3	.431	.5228	.5281	.5093	.5281	.8488	.5658
4	.4694	.5228	.5093	.5093	.5281	.8589	.547
5	.503	.5847	.6036	.5658	.6036	.9054	.7733
6	.7127	.8299	.7922	.679	.9242	.9242	.9431
7	.7712	.8865	.8865	.8488	.9242	.8865	.9431
8	.7969	.9242	.9431	.9619	.9054	.8865	.9054
9	.7373	.8215	.8299	.8962	.8676	.8402	.7842
10	.7545	.6161	.6722	.7468	.679	.6348	.6348
11		.5914	.6099	.7095	.5601	.5544	.5544
12	.5175	.5359	.5914	.6535	.5788	.5175	.499
13	.5729	.5552	.6099	.6535	.6161	.5914	.5544
14	.5601	.5975	.6161	.6535	.6161	.5914	.6099
15	.5041	.5788	.5788	.6722	.5788	.5601	.5788
16	.5228	.5975	.6348	.6722	.5914	.5788	.5729
17	.5601	.5975	.6348	.6908	.5601	.5544	.5729
18	.5729	.7282	.7095	.7282	.6401	.6401	.567
19	.6099	.8402	.8215	.8029	.7865	.7499	.6767
20	.8131	.8589	.9335	.9335	.9425	.9055	.924
21	.8402	.8775	.8402	.9896	.9335	.9795	.961
22	.8589	.8589	.9054	.9149	.9149		.9335
23	.7356	.679	.7733	.7922	.7733	.7733	.7922
24	.4807	.6036	.5658	.6224	.6413	.6602	.6602
Max	.8589	.9242	.9431	.9896	.9425	.9795	.961
Min	.431	.5228	.5093	.5093	.5281	.5175	.499
Avg	.6180	.6783	.6936	.7208	.7026	.7337	.6960

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

KOTHRUD SUB-DN.[613] BU 4613

Substation No/ Name :- 213374 / 22/11 KV PETHKAR

Feeder No / Name : 301 / 22 KV Pethkar O/G

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0381	.0381	.0381	.0381	.0762
2	.0381	.0381	.0381	.0381	.0381	.0381	.0762
3	.0381	.0381	.0381	.0381	.0381	.0381	.0762
4	.0381	.0381	.0381	.0381	.0381	.0381	.0762
5	.0381	.0381	.0381	.0381	.0762	.0381	.1143
6	.0381	.0381	.0381	.0381	.0381	.0381	.1524
7	.0762	.0762	.0762	.0381	.0762	.0381	.1524
8	.0762	.0762	.0762	.0381	.0762	.0762	.1524
9	.0762	.0762	.0381	.0381	.0762	.0381	.1905
10	.0381	.0381	.0381	.0762	.0762	.0762	.1905
11	.0381	.0381	.0762	.0381	.0381	.0762	.1524
12	.0381	.0381	.0381	.0381	.0381	.0762	.1524
13	.0381	.0381	.0381	.0381	.0762	.0762	.1524
14	.0381	.0381	.0381	.0381	.0381	.0381	.0762
15	.0381	.0381	.0381	.0381	.0381	.1143	.0762
16	.0381	.0381	.0381	.0381	.0381	.1524	.0762
17	.0381	.0381	.0381	.0381	.0381	.1524	.1143
18	.0381	.0381	.0381	.0381	.0381	.1524	.0762
19	.0762	.0381	.0381	.0381	.0381	.1524	.0762
20	.0762	.0381	.0762	.0762	.0762	.1905	.1143
21	.0762	.0381	.0381	.0762	.0762	.1905	.1524
22	.0762	.0762	.0762	.0762	.0762		.1143
23	.0762	.0762	.0762	.0762	.0381	.0762	.0762
24	.0381	.0762	.0381	.0762	.0381	.0762	.0762
Max	.0762	.0762	.0762	.0762	.0762	.1905	.1905
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0762
Avg	.0508	.0476	.0476	.0476	.0524	.0861	.1143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

WARGE SUB-DN.[614] BU 4614

Substation No/ Name :- 213008 / 22KV DAHANUKAR

Feeder No / Name : 201 / 11KV HAPPY COLONY Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.724	.724	.8145	.823	.8316	.8145
2	.6335	.7316	.724	.7316	.823	.8316	.724
3	.6401	.6401	.7316	.6401	.7316	.8316	.6401
4	.6401	.6401	.7316	.6401	.724	.8316	.6401
5	.6335	.724	.7316	.724	.724	.8316	.724
6	.905	.9145	.8145	.724	.905	.9335	.9145
7	.9955	1.0059	.905	.905	.9955	1.0269	1.0059
8	1.1765	1.1765	1.086	.9955	1.1888	1.1203	1.086
9			1.1203	1.1203	1.1203	1.2136	1.1088
10			1.2136	1.2136	1.226	1.1203	1.086
11			1.2136	1.1203	1.086	1.1203	1.1317
12			1.2136	1.0269	1.086	1.0269	1.1088
13			1.0269	1.0269	.924	.9335	.9335
14			.9335	.9335	.9335	.9335	.9431
15			.9335	.9335	.9431	.9335	.924
16			.9335	.9335	.924	.9335	
17	.9335	.9335	.9335	.905	.905	.9145	.9335
18	.9335	1.0374	1.0269	.905	.9145	.9145	1.0269
19	1.0269	1.1203	1.1203	1.0059	1.0164	.9955	1.1203
20	1.2136	1.226	1.1203	1.1765	1.1888		1.1203
21	1.2136	1.1203	1.2136	1.1765	1.1088		1.2136
22	1.1203	1.1203	1.086	1.0974	1.2136	1.086	1.1203
23	1.0059	.905	.905	1.0059	1.0269	1.0059	.9335
24	.8145	.8145	.724	.8145	.9145	.9335	.905
Max	1.2136	1.226	1.2136	1.2136	1.226	1.2136	1.2136
Min	.6335	.6401	.724	.6401	.724	.8316	.6401
Avg	.9131	.9271	.9653	.9404	.9769	.9684	.9634

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

WARGE SUB-DN.[614]

BU 4614

Substation No/ Name :- 213008 / 22KV DAHANUKAR

Feeder No / Name : 205 / 11KV WARJE

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.181	.181	.1829	.181	.1829	.181
2	.181	.1829	.181	.1829	.181	.1829	.1829
3	.181	.1829	.1829	.1829	.1829	.1829	.1829
4	.181	.1829	.1829	.181	.1829	.1829	.181
5	.181	.181	.181	.181	.181	.1829	.181
6	.2715	.2715	.181	.181	.2743	.2772	.2743
7	.2743	.2743	.2715	.2715	.2715	.2772	.2743
8	.2743	.2743	.2743	.2715	.2715	.2772	.2715
9			.2772	.2772	.2829	.2772	.2801
10			.2772	.2772	.2829	.1829	.1886
11			.1829	.2772	.181	.1829	.181
12			.1829	.2772	.1867	.1829	.1848
13			.1829	.2772	.1886	.1829	.1848
14			.1829	.1829	.1848	.1829	.181
15			.1829	.1829	.1886	.1886	.181
16			.1829	.1829	.1848	.1829	.1867
17	.1829	.1829	.1829	.181	.1867		.1848
18	.1829	.1829	.1886	.181	.1848		.1829
19	.1829	.2772	.1829	.2715	.1829		.1829
20	.2772	.2801	.2772	.2743	.2772		.2772
21	.2772	.1829	.2772	.2715	.2743		.2772
22	.2772	.1829	.1848	.2743	.2772	.2715	.2772
23	.2743	.181	.2715	.2715	.1829	.2715	.1829
24	.1829	.181	.181	.181	.181	.1829	.181
Max	.2772	.2801	.2772	.2772	.2829	.2772	.2801
Min	.181	.181	.181	.181	.181	.1829	.181
Avg	.2227	.2114	.2097	.2281	.2147	.2124	.2101

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

WARGE SUB-DN.[614]

BU 4614

Substation No/ Name :- 213008 / 22KV DAHANUKAR

Feeder No / Name : 206 / ADITYA GARDEN

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8488	.9431	.9431	1.0269	.9431	.9335	1.0374
2	.8402	.9335	.9431	1.0269	.8488	.9335	.9335
3	.8402	.8402	.8402	.9335	.8402	.9335	.9335
4	.7468	.8402	.8402	.9431	.8402	.9335	.9335
5	.8488	.9431	.9335	1.0374	.9431	.9335	1.0374
6	1.1317	1.226	1.1203	1.1317	1.2136	1.2136	1.307
7	1.1203	1.2136	1.226	1.1317	1.3203	1.2136	1.2136
8	1.226	1.307	1.226	1.1203	1.3203	1.2136	1.3203
9			1.2136	1.2136	1.1088	1.1203	1.086
10			1.1203	1.2136	1.1765	1.1203	1.0374
11			1.1203	1.1203	1.1088	1.0269	1.0164
12			1.1203	1.2136	1.0374	.9335	.9431
13			.8316	1.2136	1.0164	.9335	.9431
14			1.0269	1.1203	1.0374	.9335	.924
15			1.0269	1.0269	1.0164	.9335	.9431
16			1.0269	1.0269	.9955	.9335	.924
17	.9335	1.0269	1.1203	1.1317	3.8409	1.0374	.9335
18	.9335	1.1203	1.1203	1.1317	1.1088	1.0374	1.0269
19	1.1203	1.2136	1.2136	1.226	1.1888	1.1203	1.2136
20	1.2136	1.307	1.4146	1.4003	1.386		1.307
21	1.3203	1.307	1.307	1.4146	1.307		1.4003
22	1.307	1.2136	1.307	1.4146	1.307	1.4003	1.307
23	1.226	1.1317	1.226	1.226	1.2136	1.226	1.1203
24	.9431	1.0374	.9431	1.0374	1.1203	1.0269	1.1317
Max	1.3203	1.307	1.4146	1.4146	3.8409	1.4003	1.4003
Min	.7468	.8402	.8316	.9335	.8402	.9335	.924
Avg	1.0375	1.1003	1.0921	1.1451	1.2183	1.0496	1.0822

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

WARGE SUB-DN.[614]

BU 4614

Substation No/ Name :- 213008 / 22KV DAHANUKAR

Feeder No / Name : 207 / 11KV TIRUPATI NAGAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7392	.7392	.6468	.6468	.7316	.6468	.6468
2	.6468	.6401	.6468	.6401	.6401	.6468	.6401
3	.6468	.6401	.5487	.5487	.6401	.6468	.5487
4	.5487	.6401	.5487	.5487	.7392	.7023	.5487
5	.6468	.7392	.6468	.6468	.7392	.7468	.7392
6	.8316	.924	.8316	.7392	.924	.9335	.924
7	1.0164	.9145	.8316	.924	.924	.9335	.924
8	1.1088	1.0059	1.0164	.8316	.9145	1.0269	1.0164
9			1.0269	1.0269	1.0164	.9335	.9431
10			.9335	1.1203	1.0498	.9335	.905
11			.9335	1.0269	.924	.8316	.8402
12			.8316	1.0269	.8316	.8316	.7468
13			.7392	.9335	.8488	.8316	.724
14			.8316	.9335	.6602	.7392	.7392
15			.8316	.8316	.7468	.7392	.724
16			.7392	.7392	.7545	.7392	
17	.7392	.7392	.8402	.8316	.7392		.7392
18	.8402	.9335	.8316	.924	.7316		.8316
19	.9335	1.0269	.9335	1.0164	.8316		.9335
20	1.0269	1.0269	1.1203	1.1088	1.0059		.9335
21	1.0269	1.0269	1.0269	1.0164	1.0059		1.1203
22	1.0164	.9335	1.0164	1.0059	1.0269	1.1088	1.0269
23	1.0164	.8316	.924	.9145	.8316	1.0164	.8316
24	.6468	.7392	.7392	.7392	.7316	.7468	.7392
Max	1.1088	1.0269	1.1203	1.1203	1.0498	1.1088	1.1203
Min	.5487	.6401	.5487	.5487	.6401	.6468	.5487
Avg	.8395	.8438	.8340	.8634	.8329	.8281	.8159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHAND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

WARGE SUB-DN.[614] BU 4614

Substation No/ Name :- 213008 / 22KV DAHANUKAR

Feeder No / Name : 302 / 22KV MULSHI

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6975	1.6975	2.2405	1.8671	1.8671	1.8671	1.8861
2	1.6975	1.4937	2.2405	1.6804	1.6804	1.8671	1.8861
3	1.6804	1.4937	2.0748	1.6975	1.4937	1.8671	1.6804
4	1.6804	1.4937	2.0538	1.5089	1.6975	1.8671	1.6804
5	1.6975	1.6975	2.0748	1.4937	1.6975	1.8671	1.6975
6	1.8861	1.8861	2.2634	1.6975	1.8671	1.8671	1.8861
7	1.8671	2.0748	2.4272	1.6975	2.0538	2.0538	2.2405
8	2.4272	2.2405	2.4272	1.8671	2.0538	2.4272	2.4272
9			2.6406	1.8671	3.0769	3.0178	3.2065
10			3.2065	2.2405	2.0119	3.5837	3.5113
11			3.2065	2.2405	3.5837	3.5837	3.5475
12			3.0178	2.2405	3.6961	3.3951	3.3951
13			2.4272	2.2405	3.2579	3.3951	3.2579
14			2.6406	2.2405	3.0445	3.2065	3.3608
15			2.4272	2.0538	3.2579	3.0178	
16			2.6139	2.0538	3.5837	3.2065	
17	3.1741	3.2065	2.4272	2.0748	3.5475	3.3608	3.3951
18	2.9874	3.2065	2.4272	2.0538	3.0178	3.1741	3.2065
19	2.9874		2.2405	2.2405	2.9874	2.9874	3.0178
20	3.0178	2.8006	2.2405	2.452	2.8292	3.2065	2.8292
21	2.4272	2.4272	2.2405	2.452	2.4272	2.6139	2.4272
22	2.2405	2.0538	2.0748	2.2405	2.2405	2.2634	2.2405
23	2.0748	1.8861	2.0748	2.2405	2.0538	2.2634	2.0538
24	1.8671	1.8861	2.452	1.8671	1.8861	1.8671	2.0538
Max	3.1741	3.2065	3.2065	2.452	3.6961	3.5837	3.5475
Min	1.6804	1.4937	2.0538	1.4937	1.4937	1.8671	1.6804
Avg	2.2131	2.1030	2.4233	2.0128	2.5380	2.6594	2.5858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

WARGE SUB-DN.[614]

BU 4614

Substation No/ Name :- 213008 / 22KV DAHANUKAR

Feeder No / Name : 303 / GANDHI BHAVAN

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	1.3203	1.1317	1.3203	1.3203	1.2936	1.3203
2	1.1203	1.3203	1.1317	1.307	1.307	1.2936	1.3203
3	1.1203	1.1203	1.1203	1.1203	1.1203	1.2936	1.1203
4	1.1317	1.1203	1.1203	1.1203	1.1203	1.2936	1.1203
5	1.1317	1.1317	1.1317	1.3203	1.3203	1.4937	1.1317
6	1.6804	1.4937	1.5089	1.3203	1.6975	1.6804	1.6975
7	1.6975	1.6804	1.5089	1.5089	1.5089	1.6804	1.6975
8	1.8671	1.8861	1.5089	1.6975	1.6975	1.8671	1.8861
9			2.0538	1.6632	1.848	1.8671	1.848
10			1.8671	1.8671	1.8099		1.6289
11			1.6632	1.8671	1.6804	1.4937	1.6804
12			1.6632	1.8671	1.4937	1.4784	1.5089
13			1.4784	1.8671	1.4784	1.4937	1.4784
14			1.2936	1.6632	.724	1.2936	1.3203
15			2.6981	1.4784	1.3203	1.1088	
16			1.2936	1.4784	1.2936	1.1088	
17	1.6804	1.2936	1.4937	1.5089	1.3203	1.3203	1.2936
18	1.6804	1.4937	1.4784	1.5089	1.4937	1.3203	1.4784
19	1.6632	1.6804	1.6632	1.6975	1.5089	1.4937	1.4784
20	1.8671	1.6804	1.6804	1.8861	1.8671	1.8861	1.6804
21	1.8671	1.6632	1.6632	1.8861	1.8861	1.8861	1.8671
22	1.6632	1.6632	3.3608	1.8671	1.8671	1.8861	1.8671
23	1.6975	1.5089	1.6975	1.6804	1.6632	1.6975	1.4784
24	1.3203	1.307	1.3203	1.5089	1.5089	1.4784	1.4937
Max	1.8671	1.8861	3.3608	1.8861	1.8861	1.8861	1.8861
Min	1.1203	1.1203	1.1203	1.1203	.724	1.1088	1.1203
Avg	1.5200	1.4602	1.6055	1.5838	1.4940	1.5091	1.518

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

WARGE SUB-DN.[614]

BU 4614

Substation No/ Name :- 213307 / 22KV KARVE NAGAR

Feeder No / Name : 201 / 11KV SUSHIL GANGA

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.567	.567	.6036	.6767	.6401	.6401	.5658
2	.5304	.5487	.567	.6584	.6036	.6036	.5281
3	.5487	.5304	.5487	.6401	.5487	.5487	.5281
4	.5121	.5487	.5304	.6219	.5487	.5121	.5281
5	.5304	.5853	.5487	.5487	.5853	.567	.5281
6	.5853	.6767	.5853	.5853	.6584	.6219	.6224
7	.7499	.695	.6767	.5853	.7682	.695	.7922
8	.8596	.811	.7682	.695	.823	.7682	.8865
9	.9328	.823	.8413	.823	.8779	.8779	.8865
10	.9511	.8779	.9145	.823		.8779	.9242
11	.823	.9145	.9328	.9511	.8413	.8779	.8676
12	.7133	.8596	1.0242	.9145	.8779		.8299
13	.7316	.7865	.8596	.7865	.8048	.823	.8299
14	.6401	.7499	.8048	.7865	.7682	.7499	.7733
15	.6401	.7316	.7545	.7499		.7499	.811
16	.7922	.7733	.7356	.7499		.7499	.7922
17	.8299	.811	.7922	.7682		.7499	.8488
18	.8676	.8865	.6859	.8048		.823	.9054
19	.9808	.9997	1.094	.9328		.8962	.9619
20	1.0562	.9997	1.0608	.6584		1.0242	1.0562
21	.9328	.9145	1.0059	.9877	1.0374	.9997	.9619
22	.8596	.8413	.8413	.9328	.9328	.8865	.8488
23	.7499	.7133	.7865	.823	.7682	.7202	.7545
24	.5853	.6401	.6219	.7316	.7499	.695	.6979
Max	1.0562	.9997	1.094	.9877	1.0374	1.0242	1.0562
Min	.5121	.5304	.5304	.5487	.5487	.5121	.5281
Avg	.7487	.7619	.7744	.7598	.7550	.7590	.7804

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHAND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

WARGE SUB-DN.[614]

BU 4614

Substation No/ Name :- 213307 / 22KV KARVE NAGAR

Feeder No / Name : 202 / 11KV GANESH NAGAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.499	.5228	.5041	.5228	.5788	.5975	.5658
2	.4668	.5041	.4854	.4854	.5601	.5601	.5093
3	.4668	.4668	.4668	.4668	.5228	.5228	.5093
4	.4481	.4668	.4668	.4481	.5041	.5041	.5093
5	.4854	.5041	.5041	.4854	.5601	.5415	.5093
6	.4854	.6161	.5788	.5228	.6348	.5788	.7356
7	.6348	.6722	.6161	.5601	.7282	.6348	.7922
8	.7655	.7468	.6722	.6535	.7468	.7095	.8299
9	.7947	.703	.7468	.6908	.7655	.7655	.8299
10	.7207	.7095	.7468	.7468		.7842	.7733
11	.7207	.8029	.8402	.7095	.8029	.7468	.811
12	.7577	.8029	.8402	.6908	.7655	.7282	.7167
13	.6838	.7468	.7282	.6722	.7095	.6722	.679
14	.6908	.6722	.6722	.6535	.6535	.6722	.6602
15	.7023	.6908	.6979	.6348		.6535	.679
16	.7356	.7545	.6602	.6348		.7095	.7167
17	.7545	.7733	.6979	.6348		.7095	.7356
18	.7733	.7545	.7545	.6348		.7468	.7545
19	.4338	.7922	.7922	.7282		.7468	.7733
20	.7922	.7733	.811	.8029		.8402	.8299
21	.7468	.6908	.7655	.7842	.7545	.7545	.7545
22	.6908	.6722	.6908	.7468	.7282	.6979	.7167
23	.6535	.6161	.6535	.7095	.6722	.6413	.6602
24	.5175	.5601	.5228	.5601	.6535	.5975	.6036
Max	.7947	.8029	.8402	.8029	.8029	.8402	.8299
Min	.4338	.4668	.4668	.4481	.5041	.5041	.5093
Avg	.6425	.6673	.6631	.6325	.6671	.6715	.6940

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

WARGE SUB-DN.[614]

BU 4614

Substation No/ Name :- 213307 / 22KV KARVE NAGAR

Feeder No / Name : 206 / 11KV MEENATAI THAKARE NGR Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4805	.5175	.5175	.5359	.5359	.5359	.5281
2		.499	.499	.499	.499	.499	.4338
3		.4805	.4805	.462	.462	.462	.4338
4	.6653	.462	.462	.4435	.462	.4066	.4338
5	.5175	.5175	.499	.4435	.5175	.4066	.4338
6	.5544	.5729	.5175	.462	.5914	.4805	.4338
7	.5914	.5914	.6099	.5359	.6653	.4805	.6036
8	.6653	.7207	.7023	.6468	.7392	.7023	.7167
9	.7392	.7023	.7207	.6838	.7762	.7577	.7167
10	.7762	.7023	.7947	.7762		.7947	.7167
11	.6653	.6838	.7947	.7207	.7392	.7947	.7733
12	.5729	.6468	.7207	.6653	.6838	.7023	.6036
13	.5729	.6283	.6283	.6283	.5914	.6468	.5487
14	.5359	.5729	.6283	.5729	.5729	.6099	.4973
15	.5175	.5544	.5847	.5914		.5914	.5847
16	.5847	.6036	.5847	.5914		.6099	.6224
17	.6224	.679	.6413	.5914		.6653	.6602
18	.6979	.7545	.6979	.6283		.6653	.7167
19	.6979	.7922	.7922	.6653		.7207	.7922
20	.7922	.7762	.8299	.7762		.8131	.811
21	.7023	.7207	.7577	.7392	.811	.7733	.7733
22	.6838	.6653	.7023	.6838	.7947	.7167	.7167
23	.6099	.5914	.6468	.6099	.6653	.6602	.6413
24	.499	.5175	.5175	.5544	.5729	.6099	.5847
Max	.7922	.7922	.8299	.7762	.811	.8131	.811
Min	.4805	.462	.462	.4435	.462	.4066	.4338
Avg	.6247	.6230	.6388	.6045	.6282	.6294	.6157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

WARGE SUB-DN.[614] BU 4614

Substation No/ Name :- 213371 / 22/11KV KAKADE CITY

Feeder No / Name : 201 / 11 KV SHRIRAM SOCIETY Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0747	.0754	.0754	.0754	.0754	.0754
2	.0377	.0377	.0377	.0189	.0754	.0754	.0754
3		.0343	.0377	.0377	.0377	.0754	.0377
4	.0754	.0377	.0377	.0377	.0377	.0377	.0377
5	.0754	.0754	.0754	.0754	.0754	.0754	.0754
6	.0747	.0754	.0747	.0747	.0754	.1132	.0754
7	.0747	.0747	.0747	.0747	.0747	.0747	.0747
8	.0739	.0739		.0739	.0747	.0747	.0747
9	.0739	.0739	.112	.0739	.112	.0747	.0747
10	.0747	.0724	.0747	.112	.0754	.0747	.0747
11	.0724	.112	.0747	.112	.0732	.0747	.0671
12		.0747		.0747	.0747	.0747	
13	.0747	.0747	.0739	.0747	.0747	.0373	.0747
14	.0724	.0747	.0732	.0747	.0747	.0732	.037
15		.0732	.0739	.0747			.0373
16	.0754		.0739	.0747			.0747
17	.0362	.0747	.0739	.0747	.0747	.0747	
18	.037	.0739	.0739	.0747	.0747	.0747	.0747
19	.0739	.0747	.0739	.0747	.0747	.0747	.0754
20	.0739	.112	.112	.112	.112	.0747	.1132
21	.0739	.112	.0747	.112	.112	.0747	.112
22	.0739	.0747	.0754	.112	.0373	.0747	.1132
23	.0747		.0747	.0747	.0373	.0747	.0754
24		.0754	.0747	.0747	.0747		.0747
Max	.0754	.112	.112	.112	.112	.1132	.1132
Min	.0362	.0343	.0377	.0189	.0373	.0373	.037
Avg	.0687	.0744	.0729	.0771	.0731	.0731	.0730

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

WARGE SUB-DN.[614]

BU 4614

Substation No/ Name :- 213371 / 22/11KV KAKADE CITY

Feeder No / Name : 202 / 11KV TAPODHAM

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.5975	.6036	.6413	.6413	.679	.679
2	.5281	.5658	.5658	.6036	.6036	.6413	.6036
3	.4904	.5658	.5658	.5658	.5658	.6036	.5658
4	.5658	.6036	.6036	.5658	.6036	.6413	.6413
5	.6036	.6413	.6036	.6036	.6413	.679	.679
6	.6348	.6348	.6348	.5975	.7167	.7545	.7545
7	.7842	.7023	.7468	.6348	.8215	.8215	.8215
8	.8686	.8779		.7392	.8589	.8589	.9335
9	.8215	.8131	.7468	.8048	.7842	.8501	.8131
10	.7468	.7468	.8589	.8501	.7682	.7468	.7842
11	.7468		.7762	.8131	.7842	.7468	.7842
12	.6348	.7095		.8589		.7095	
13	.5601	.6722	.7316	.7468	.6722	.6722	.5975
14	.6348	.7095	.6447	.7468	.6653	.7468	.6722
15	.6348	.6348	.695	.7468			.6722
16	.6348		.6653	.7468			.6516
17	.5975	.6722	.7316	.7095	.6722	.6722	
18	.6653	.7392	.7392	.7468	.7316	.7095	.6722
19	.8048	.8589	.8131	.7842	.7842	.7468	.7842
20	.8501	.9335	.8871	.9335	.924	.8962	.924
21	.8501	.8962	.8589	.8962	.8962	.9709	.8871
22	.8501	.8215	.8215	.8131	.8589	.8962	.8962
23	.7468		.7842	.7842	.7842	.8589	.8589
24		.6413	.6348	.6722	.7095		.7095
Max	.8686	.9335	.8871	.9335	.924	.9709	.9335
Min	.4904	.5658	.5658	.5658	.5658	.6036	.5658
Avg	.6878	.7161	.7142	.7336	.7375	.7572	.7448

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

WARGE SUB-DN.[614]

BU 4614

Substation No/ Name :- 213371 / 22/11KV KAKADE CITY

Feeder No / Name : 203 / 11KV KAKADE CITY

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2241	.2263	.2263	.2263	.2263	.2263
2	.1886	.1886	.1886	.1886	.1886	.1886	.1886
3	.1886	.1886	.1886	.1886	.1886	.1886	.1886
4	.1886	.1886	.1886	.1886	.1886	.2263	.1886
5	.2263	.2263	.2263	.2263	.2263	.2263	.2263
6	.2614	.2614	.2614	.2241	.2614	.2614	.2641
7	.2614	.2957	.2614	.2241	.2987	.2987	.2614
8	.3326	.3326		.2957	.3734	.2987	.2987
9	.3734	.2957	.2987	.3326	.3734	.3696	.3734
10	.3361	.2987	.3361	.3696	.3734	.3361	.3734
11	.2987	.3361	.3696	.3326	.2987	.3361	.3361
12	.2614			.2987	.2987	.3361	
13	.2614	.2987	.2957	.3361	.2263		
14	.2241	.2241	.2587	.2614		.2241	.2195
15	.2241	.2241	.2218	.2614			.2241
16	.2241		.2241	.2614			.2241
17	.2561	.2241	.2218	.2614		.2241	
18	.2241	.2957	.2587	.2987	.2241	.2241	.2218
19	.2957	.2987	.2614	.2987	.2614	.2241	.2587
20	.2957	.2987	.2957	.2987	.2987	.2987	.3018
21	.2957	.2987	.2987	.2987	.2987	.2987	.2987
22	.2957	.2614	.2987	.2987	.2987	.2987	.2987
23	.2614		.2614	.2614	.2987	.2614	.2614
24	.2241	.2263	.2614	.2241	.2614		.2241
Max	.3734	.3361	.3696	.3696	.3734	.3696	.3734
Min	.1886	.1886	.1886	.1886	.1886	.1886	.1886
Avg	.2578	.2613	.2593	.2690	.2732	.2673	.2599

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

WARGE SUB-DN.[614]

BU 4614

Substation No/ Name :- 213371 / 22/11KV KAKADE CITY

Feeder No / Name : 204 / 11KV MALWADI

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5089	1.4563	2.037	1.6221	1.4335		
2	1.4335	1.4335	1.8861	1.5844	1.358		
3	1.4335	1.3957	1.8484	1.4712	1.358		
4	1.5089	1.4335	1.8107	1.4335	1.4712		
5	1.5466	1.5089	2.0748	1.5089	1.5089		.0377
6	1.5684	1.5684	2.0911	.1494	1.5684		.0377
7	1.7924	1.848	2.4646	1.643	1.8671		.0377
8	1.8671	1.922		1.848	2.0538	.0373	.0373
9	1.9044	2.2916		1.9753	2.2405	.037	.0373
10	2.3525	3.0247	2.4272	2.2916	3.0933	.0377	.0373
11	1.7924	3.0247	2.6612	2.4025	3.2861	.0373	.0373
12	1.2696			2.0538	2.9874	.0373	
13	1.8671	2.3899	2.6981	1.9044		.0373	.0373
14		2.9874	2.809	1.9044		.0373	.0373
15	2.1285	3.062	3.0361	1.9044			.0373
16			2.9938	1.8671			.0373
17	2.0538	3.0994	2.8166	1.8671			
18	1.9589	2.726	2.6513	1.8671		.0366	
19	1.8656	2.2405	2.3525	1.7924		.037	
20	1.7741	2.1658	2.0698	1.7177		.0373	.0373
21	1.7558	2.0165	2.0538	1.6804		.0373	.0377
22	1.7002	1.8671	1.9044	1.643		.0373	.0373
23	1.6804		1.7924	1.6057		.0373	.0373
24	1.6057	1.5089	2.0911	1.6804	1.4937		.0373
Max	2.3525	3.0994	3.0361	2.4025	3.2861	.0377	.0377
Min	1.2696	1.3957	1.7924	.1494	1.358	.0366	.0373
Avg	1.7440	2.1415	2.3129	1.7257	1.9785	.0372	.0374

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

WARGE SUB-DN.[614]

BU 4614

Substation No/ Name :- 213371 / 22/11KV KAKADE CITY

Feeder No / Name : 301 / 22KKV ADITYA I/C

HV Non-Express Feeder

Feeder KV- 22 / INCOMING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.7051	4.257	2.9874	4.4063	4.3381	2.3152	4.5268
2	4.0364	4.0741	2.838	4.1076	4.1495	2.2634	4.225
3	3.8089	3.8477	2.6139	3.9986	4.0741	2.3011	3.9986
4	4.0329	3.9232	2.5652	4.0741	3.9986	2.6406	4.225
5	4.3759	4.3004	2.5652	3.9918	4.225	3.0933	4.4513
6	4.7051	4.7051	2.9127	4.1823	4.7798	3.2487	4.8544
7	5.3772	5.3224	3.2861	4.8171	5.4519	3.5848	5.2279
8	5.7133	5.9137		5.2854	5.788	3.9582	5.9
9	5.676	5.9507	3.6591	6.0246	6.1241	5.9	5.9
10	5.8029	6.0616	6.4312	6.3481		6.2734	6.3855
11	5.7507	6.3108	6.3203	6.2734			6.4228
12	5.3772	5.5266	6.1355	6.1241		6.1241	
13	4.4437	5.4519	5.4332	5.4146		5.7507	5.1578
14	3.6561	5.4146	5.655	5.2279		5.788	5.6386
15	4.7424	5.5639	5.5601	5.2279			5.6386
16		6.3108	5.5441	5.2279			5.676
17	4.8544	5.5266	5.692	5.3772		5.9374	
18	5.0636	5.8398	5.8253	5.2652	3.5117	5.788	4.9528
19	5.7289	6.012	5.9747	5.788	3.6946	5.9	5.3189
20	6.0616	6.5348	6.616	6.3481	4.257	6.4975	6.4883
21	6.0246	6.3481	6.5722	6.3855	4.4437	6.1988	6.3108
22	5.8029	4.0329	6.1988	6.0867		5.9747	6.0357
23	5.2652		5.5639	5.4519	3.9582	5.1532	5.5076
24	4.8544	4.4513	3.062	4.8171	2.5019		4.5931
Max	6.0616	6.5348	6.616	6.3855	6.1241	6.4975	6.4883
Min	3.6561	3.8477	2.5652	3.9918	2.5019	2.2634	3.9986
Avg	5.0374	5.2904	4.7831	5.2605	4.3531	4.7346	5.3380

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

WARGE SUB-DN.[614]

BU 4614

Substation No/ Name :- 213371 / 22/11KV KAKADE CITY

Feeder No / Name : 303 / 22 KV NDA

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2071	1.1576	1.1317	1.0719	1.1317	1.1317	1.1317
2	1.094	1.1317	1.0562	1.0082	1.0185	1.0185	1.0562
3	1.0562	1.0562	1.0562	.9907	.9808	.9808	.9808
4	1.0562	1.0562	1.0562	1.0669	1.0562	.9431	.9808
5	1.0829	1.1317	1.1949	1.0562	1.0562	.9808	1.0562
6	1.0829	1.1949	1.1203	1.0185	1.1317	1.0082	1.1317
7	1.1949	1.1458	1.1203	1.1576	1.2696	1.1203	1.0829
8	1.2696	1.3676		1.2567	1.307	1.2323	1.2696
9	1.4937		1.2323	1.4045	1.2696	1.419	1.6804
10	1.3611	1.6804	1.531	1.419		1.5844	
11	1.3817	1.531	1.6632	1.307		1.643	
12	1.3957	1.4937		1.2696		1.531	
13	1.3443	1.3443	1.4045	1.1203			1.419
14	1.307	1.307	1.3169	1.1949		1.2696	1.1203
15	1.1949	1.1203	1.2567	1.1576			1.1088
16			1.1827	1.0829			1.1203
17	1.1203	1.0242	.9979	1.1949		1.0082	
18	1.2567	1.1576	1.1203	1.1949	1.0082	1.0082	1.1088
19	1.5524	1.419	1.3443	1.4937	1.3817	1.1088	1.4335
20	1.6057	1.6057	1.5524	1.7551	1.3817	1.4937	1.6598
21	1.5154	1.5684	1.5684	1.5684	1.4563	1.5684	1.6263
22	1.5524	1.3817	1.4937	1.4563	1.3817	1.4563	1.419
23	1.307		1.3443	1.3817	1.2696	1.3817	1.358
24	1.2323	1.2323	1.1949	1.2323	1.2696	1.2323	1.2696
Max	1.6057	1.6804	1.6632	1.7551	1.4563	1.643	1.6804
Min	1.0562	1.0242	.9979	.9907	.9808	.9431	.9808
Avg	1.2898	1.2908	1.2700	1.2442	1.2106	1.2438	1.2507

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

WARGE SUB-DN.[614]

BU 4614

Substation No/ Name :- 213372 / 22/11KV ADITYA GARDEN CITY

Feeder No / Name : 201 / 11KV GARDEN CITY

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7059	.7499	.7207	.7783	.7682	.7865	.7865
2	.6805	.724	.6767	.7522	.724	.8326	.724
3	.6201	.6805	.6516	.724	.6584	.6767	.695
4	.6201	.6805	.6401	.7023	.6283	.6516	.7392
5	.6626	.7059	.6653	.5975	.6722	.695	.7682
6	.8779	.7682	.7282	.679	.7842	.7842	.8215
7	.8589	.8775	.7095	.7167	.8871	.9242	.8596
8	.9335	1.531	.7392	.7922	.823	.8215	.8507
9	.9896	.8962	.8962	.8299	.9055	.8676	.8962
10	.9522	.9149	.8316	.9997		.8962	.8962
11		.8589	.8596	.9896	.9054	.8775	.8871
12	.8779	.8215	.7964	.9055	.8488	.8413	.8589
13	.8779	.7922	.8048	.8779	.7499	.8316	.8686
14	.7499	.7655	.8326	.8501	.7499	.7602	.7577
15	.7421	.7577	.7316	.8501	.7499	.7865	.7499
16	.7421	.7682	.8048	.8686	.7682	.7577	.7947
17	.7682	.8316	.7499	.8596	.7682	.7865	.7865
18	.8048	.8501	.8048	.8871	.7499	.7762	.7682
19	.9896	1.5708	.8686	.9511	.823	.8596	.8871
20	1.0269	1.0608	1.0642	1.1088	1.0059	1.0608	1.0425
21	1.0829	1.0534	1.0642	1.0719	1.0059	1.1088	1.0791
22	.9709	.9795	1.0349	1.0791	1.0425	1.0242	1.0349
23	.961	.8962	.9694	.9896	1.0608	.9774	.9877
24	.7602	.823	.7602	.8596	.8871	.8413	.8413
Max	1.0829	1.5708	1.0642	1.1088	1.0608	1.1088	1.0791
Min	.6201	.6805	.6401	.5975	.6283	.6516	.695
Avg	.8372	.8899	.8085	.8634	.8246	.8427	.8492

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

WARGE SUB-DN.[614]

BU 4614

Substation No/ Name :- 213372 / 22/11KV ADITYA GARDEN CITY

Feeder No / Name : 202 / 11KV ATUL NAGAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.086	1.0608	1.0269	1.0974	1.1222	1.1157	1.1088
2	.9671	1.0498	.9774	1.0974	1.0974	1.134	1.0608
3	.8954	1.0208	.9511	1.0719	1.0498	1.2437	1.0136
4	.9134	1.0029	.924		1.0608	1.0317	1.0974
5	.9593	1.0566	.9877	1.0349	1.086	1.0974	1.2567
6	1.134	1.1523	1.1763	1.1317	1.1706	1.2696	1.3817
7	1.3676	1.423	1.307	1.226	1.475	1.4712	1.4969
8	1.4937	1.587	1.4449	1.4335	1.587	1.5708	1.5912
9	1.9605	1.5123	1.4969	1.5655	1.4969	1.4415	1.39
10	1.7364	1.4377	1.5364	1.6409	1.475	1.4266	1.4784
11	1.4003	1.307	1.4998	1.5497	1.419	1.4083	1.3169
12	1.2851	1.2323	1.4842	1.4969	1.3817	1.3491	1.307
13	.9955	1.1949	1.3717	1.4784	1.2752	1.1888	1.262
14	1.267	1.2136	1.2986	1.3676	1.2012	1.2012	1.1888
15	1.1765	1.2752	1.2127	1.3169	1.2012	1.0974	1.1888
16	1.1283	1.2071	1.2127	1.3169	1.1458	1.1273	1.2012
17	1.2308	1.2197	1.2437	1.3676	1.1827	1.0974	1.2254
18	1.386	1.4266	1.3535	1.4045	1.363	1.2752	1.2382
19	1.6244	1.6078	1.5181	1.5364	1.4563	1.4266	1.4998
20	1.6991	1.6644	1.6827	1.7926	1.6804	1.7556	1.7002
21	1.6991		1.6651	1.7558	1.7737	1.7375	1.7741
22	1.3957		1.5912	1.6448	1.6632	1.5565	1.643
23	1.307	1.3256	1.4449	1.4083	1.4266	1.4299	1.4969
24	.9694	1.1643	1.0974	1.2567	1.2127	1.2254	1.1888
Max	1.9605	1.6644	1.6827	1.7926	1.7737	1.7556	1.7741
Min	.8954	1.0029	.924	1.0349	1.0498	1.0317	1.0136
Avg	1.2949	1.2792	1.3127	1.3910	1.3335	1.3199	1.3378

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

WARGE SUB-DN.[614]

BU 4614

Substation No/ Name :- 213372 / 22/11KV ADITYA GARDEN CITY

Feeder No / Name : 203 / 11KV VOILA

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.2328	.2378	.2378	.2534	.2353	.2534
2	.2353	.2149	.2353	.2402	.2195	.2195	.2195
3	.2172	.1949	.2195	.2195	.2172	.2033	.2172
4	.2172	.1949	.1991	.2054	.1829	.3109	.2587
5	.2378	.2149	.2195	.2427	.2172	.3258	.2987
6	.2957	.2743	.3109	.2641	.2561	.3547	.3734
7	.3734	.3547	.3142	.2743	.3326	.3475	.3511
8	.4338	.3584	.3109	.3395	.3547	.3292	.3658
9	.3961	.3961	.3881	.3772	.3881	.3921	.3658
10	.3395		.3475	.3921		.3292	.3142
11	.3584	.2987	.3475	.3696	.3206	.2957	.2926
12	.3142	.3174	.3109	.3658	.3018	.2743	.2957
13	.2957	.2987	.2957	.3142	.2829	.2896	.2743
14	.2957	.3174	.2926	.2957	.2641	.2926	.2561
15	.2378	.2801	.2715	.2926	.2641	.2801	
16	.2378	.2587	.2743	.3142	.2641	.2587	.2402
17	.2957	.2926	.2561	.3292	.2829	.2561	.2772
18	.3174	.2957	.2957	.3511	.2987	.2957	.2957
19	.4294	.3658	.3734	.3475	.3361	.3292	.3511
20	.4108	.3881	.4108	.4066	.4108	.4066	.3841
21	.3921	.3658	.3881	.4207	.4108	.3982	.3841
22	.3174		.3696	1.0791	.3734	.3658	.3475
23	.2957	.3174	.3292	.3475	.3292	.3109	.362
24	.2926	.2896	.2587	.2926	.3142	.2926	.2957
Max	.4338	.3961	.4108	1.0791	.4108	.4066	.3841
Min	.2172	.1949	.1991	.2054	.1829	.2033	.2172
Avg	.3122	.2965	.3024	.3466	.2989	.3081	.3076

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

WARGE SUB-DN.[614]

BU 4614

Substation No/ Name :- 213372 / 22/11KV ADITYA GARDEN CITY

Feeder No / Name : 204 / 11KV MANGESHKAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5175	.7392	.5729	.6219	.6219	.6219	.6036
2	.6099	.695	.5304	.5853	.5792	.6468	.5611
3	.5487	.695	.5121	.5487	.543	.5729	.5487
4	.5121	.6154	.499	.6348	.5487	.5853	.5175
5	.4755	.6036	.5415	.7095	.6283	.6413	.5601
6	.6348	.7682	.6161	.7545	.7095	.6908	.6722
7	.8865	.9522	.7947	.7733	.8488	.8589	.9511
8	1.0098	.9619	.9328	.961	.9335	.9054	.924
9	1.094	1.2449	.9896	1.0374	.9709	.9335	1.0164
10	1.0751	1.226	1.2012	.8775	1.2449	1.1523	1.0608
11	1.0185	1.2826	1.1888	.8596	1.1883	1.0534	1.0719
12	1.0562	1.1949	.9979	.8962	1.226	1.1157	1.0642
13	.8865	1.1317	1.0208	.8596	.9145	1.0719	.9795
14	.8488	1.0082	.8507	.8962	.9511	1.0059	.9425
15	.9808	1.0562	.9328	.7865	.9431	1.0349	.9795
16	.9808	1.1273	1.0242	.8686	.9149	1.0456	.9145
17	1.0185	1.134	.9979	.8501	1.1016	1.0829	1.0425
18	1.086	1.1643	1.0534	.8779	1.1694	.9522	.8779
19	1.2003	1.134	1.0903	1.1016	1.1128	.9511	.961
20	1.1317	1.2382	1.1273	.961	1.0562	1.0974	.9511
21	1.0562		1.1458	.9795	1.0082	1.0242	.9795
22	.9431		.9328	.8596	.9335	.9145	.8779
23	.8962	.8596	.961	.8688	.7392	.7682	.8688
24	.6468	.7655	.5611	.7133	.695	.6838	.6335
Max	1.2003	1.2826	1.2012	1.1016	1.2449	1.1523	1.0719
Min	.4755	.6036	.499	.5487	.543	.5729	.5175
Avg	.8798	.9817	.8781	.8284	.8993	.8921	.8567

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

WARGE SUB-DN.[614]

BU 4614

Substation No/ Name :- 213372 / 22/11KV ADITYA GARDEN CITY

Feeder No / Name : 205 / 11 KV GANAPATI MATHA

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2936	1.2308		1.3169	1.2437		1.3676
2	1.2803	1.1584		1.2803	1.1584		1.3169
3	1.2437	1.1462		1.2826	1.1104		1.2567
4	1.1946	1.1104		1.2574	1.086		1.2936
5	1.3535	1.3394		1.5242	1.134		1.39
6	1.4784	1.5154		1.6221	1.3535		1.6461
7	1.7924	1.7551		1.6975	1.8671		1.7741
8	1.9616	1.9616		1.9052	1.848		1.9418
9	1.9239	2.1879	2.0538	2.0957	2.0995	2.1879	2.2405
10	1.8484	2.21	2.3152	2.2634	2.3388	2.7161	2.4646
11	1.6975	2.2862	2.4025	2.0538	2.3011	2.6406	2.6513
12	1.6975	1.8861	2.3045	1.9589	2.1879	2.5019	2.4508
13	1.3957	2.0559	1.7193	1.4632	1.8107	2.4272	1.848
14	1.358	1.9993	2.0119	1.6632	3.0933	2.268	2.2314
15	1.3957	2.2405	2.1132	1.7558	3.3951	2.1948	2.268
16	1.531	2.2634	2.0633	1.8111		2.1658	2.4025
17	1.5684	2.2032	1.9387	1.6632		2.2634	2.3411
18	1.4937	2.0538	1.9022	1.6263		2.2779	1.7741
19	1.7353	2.1068	2.0485	1.6632		2.1068	1.4415
20	1.8107	2.0328	1.9589	1.8656		2.0119	1.9589
21	1.8107		1.9022	1.829		1.848	1.9022
22	1.6598		1.7741	1.7013		1.7193	1.8111
23	1.5684		1.6095	1.5364		1.6289	1.6461
24	1.4415	1.3535		1.4045	1.2894		1.4266
Max	1.9616	2.2862	2.4025	2.2634	3.3951	2.7161	2.6513
Min	1.1946	1.1104	1.6095	1.2574	1.086	1.6289	1.2567
Avg	1.5639	1.8141	2.0079	1.6767	1.8323	2.1972	1.8686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

WARGE SUB-DN.[614]

BU 4614

Substation No/ Name :- 213372 / 22/11KV ADITYA GARDEN CITY

Feeder No / Name : 206 / 11 KV RAMNAGAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0526	.0532	.0732	.0549	.0543	.1075	.0549
2	.052	.0526	.0543	.0724	.0537	.0716	.0543
3	.0514	.0526	.0537	.0537	.0532	.0886	.0549
4	.0514	.0526	.0543	.0905	.0537	.0354	.0554
5	.0526	.0532	.0549	.0732	.0543	.0732	.0549
6	.0716	.0709	.0732	.1294	.0732	.0543	.0543
7	.0732	.0724	.1109	.1509	.0924	.1097	.0732
8	.0739	.0732	.0914	.1494	.112	.0732	.1109
9	.0739	.0732	.1086	.1494	.1478	.0924	.1097
10	.0739	.0549	.1463	.1294	.0924	.0732	.0924
11	.0739	.0362	.1086	.128	.0739	.1075	.0739
12	.0537	.0366	.0732	.1109	.0732	.1109	.0549
13	.0537	.0554	.0532	.1097	.0532	.128	.0724
14	.0537	.0366	.0716	.0914	.0724	.1086	.0716
15	.0532	.0358	.0543	.0549	.0549	.1254	.0732
16	.0532	.0537	.0543	.0716	.0549	.0709	.0716
17	.0537	.0724	.0543	.0709	.0549	.0895	.1086
18	.0537	.0716	.0732	.0905	.0732	.1086	.1254
19	.0543	.0905	.0914	.0716	.0732	.1254	.1086
20	.0732	.0895	.1109	.1433	.0914	.1463	.1097
21	.0732		.1097	.1254	.112	.128	.1109
22	.0724		.1294	.1086	.128	.1086	.112
23	.0716	.0549	.128	.0914	.1109	.0716	.0739
24	.0526	.0532	.0724	.1086	.0724	.0905	.0724
Max	.0739	.0905	.1463	.1509	.1478	.1463	.1254
Min	.0514	.0358	.0532	.0537	.0532	.0354	.0543
Avg	.0614	.0589	.0836	.1013	.0786	.0958	.0814

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

WARGE SUB-DN.[614]

BU 4614

Substation No/ Name :- 213443 / 22/11 KV URBAN GRAM

Feeder No / Name : 201 / 11 KV KONDHAWA DHAWADE

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7941	.786	.8589	.8794		.8794
2		.7922	.7487		.7674		.8421
3		.7978	.6927		.7674		.7674
4		.862	.6554		.7786		.7487
5	.7095	9.393	.7674		.8794		.8421
6		1.0374	.9354	.9149	.9354	1.0642	.8884
7		1.0789	1.0288	.9522	.9914	1.0456	1.0393
8	1.1763	1.124	1.0661	1.0829	1.0474	1.1389	1.1336
9	1.0904	1.0997	1.1968	1.1091	1.0101	1.0269	1.0393
10	.9877	1.012	1.0362	1.1333	1.012		.8865
11	.8757	.9111	.9223	.9765	.7804	.9298	.8865
12	.8943	.9167		.9653	.7804	.8701	.8299
13	.8738	.8458	.8943	.9223	.9037	.8738	.8299
14	.7922	.8234	.8533	.8103	.8066	.8047	.8205
15	.7423	.773	.7599	.8999		.8309	.8299
16	.7545	.8047	.7655	.8981		.8318	.8318
17	.811	.8234	.8402	.8419	.9431	.8852	.8261
18	.8337	.9466	.9335	.9429	.9223	.9054	.8507
19	.9714	1.0661	.9896	.9933	1.0694	1.0751	1.0242
20	1.1223	1.1595	1.1576	1.2659	1.2354	1.2449	1.1968
21	1.1411	1.1595	1.1576	1.2155	1.2449	1.2317	1.1968
22	1.1128	1.0288	1.0829	1.1408	1.1763	1.1781	1.1763
23	.9997	.9354		1.0288	1.0456	1.0101	1.0082
24	.8402	.8383	.8421	.8775	.8981	.8775	.9485
Max	1.1763	9.393	1.1968	1.2659	1.2449	1.2449	1.1968
Min	.7095	.773	.6554	.8103	.7674	.8047	.7487
Avg	.9294	1.2926	.9142	.9915	.9489	.9903	.9301

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

WARGE SUB-DN.[614]

BU 4614

Substation No/ Name :- 213443 / 22/11 KV URBAN GRAM

Feeder No / Name : 202 / 11 KV UTTAMNAGAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0562	1.0661		1.1781		1.6051
2		1.0298	.9653		1.1408		1.5108
3		1.0185	.8981		1.0661		1.4165
4		1.0808	.8421		1.0848		1.3411
5	1.0269	1.1864	.9167		1.1781		1.5297
6		1.326	1.1221	1.1203	1.2715	1.8671	1.624
7		1.4335	1.3088	1.307	1.4955	1.9978	1.905
8	1.531	1.4899	1.447	1.475	1.5889	2.2779	2.2954
9	1.3891	1.3891	1.4003	1.4731	1.3648	1.9791	2.0125
10	1.32	1.3219	1.3424	1.4806	1.2939		1.805
11	1.2155	1.2566	1.32	1.4153	1.2285	1.8764	1.7028
12	1.0885	1.1987	1.2454	1.3331	1.1651	1.6654	1.6353
13	1.081	1.1371	1.18	1.2603	1.1595	1.5889	1.6259
14	1.0544	1.0642	1.0717	1.1949	1.0773	1.531	1.5749
15	1.043	1.0717	1.1147	1.1819	1.124	1.5179	
16	1.0449	1.0661	1.0082	1.1949	1.06	1.5466	
17	1.0185	.9914	1.1203	1.2491	1.6806	1.5309	1.4146
18	1.1355		1.2136	1.2846	1.6787	1.7032	1.409
19	1.3203	1.4713	1.3443	1.2902	1.9842	1.9522	1.5146
20	1.5466	1.5889	1.5684	1.6692	2.2728	2.4312	1.7009
21	1.5674	1.5329	1.5497	1.6449	2.2822	2.3464	1.6262
22	1.5014	1.4955	1.4563	1.5329	2.0725	2.1602	1.5497
23	1.326	1.4022		1.3088	1.9044	1.9063	1.3817
24	1.0829	1.1694	1.1445	1.1763	1.2024	1.7177	1.686
Max	1.5674	1.5889	1.5684	1.6692	2.2822	2.4312	2.2954
Min	1.0185	.9914	.8421	1.1203	1.06	1.5179	1.3411
Avg	1.2385	1.2512	1.202	1.3470	1.4398	1.8665	1.6303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

WARGE SUB-DN.[614] BU 4614

Substation No/ Name :- 213443 / 22/11 KV URBAN GRAM

Feeder No / Name : 203 / 11 KV DANGAT PATIL NAGAR Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0495		.0514		1.1336
2			.0485		.0553		1.077
3			.0504		.0514		.9712
4			.0504		.0476		.9638
5	.0495		.0553		.0533		1.0959
6			.0553	.0495	.0533	1.6766	1.1902
7			.0553	.0476	.04	1.8861	1.3222
8	.0476		.0495	.0476	.0457	1.4861	1.4203
9	.0457				.0467	1.8861	1.9182
10	.0476					2.2253	2.4294
11	.0381					2.3777	2.4784
12	.0381					2.5339	2.3369
13	.0381					2.0652	2.3237
14						2.2577	2.2747
15						2.4272	2.4067
16		.0476	.0467		.0472	2.5123	2.418
17		.0476	.0467		.0453	2.4086	2.9405
18			.0476		2.7161	2.0502	2.6802
19		.0457	.0476		2.3426	1.6975	2.4822
20		.0495	.0476		2.1049	1.4712	2.3377
21		.04	.0476	.0476	1.9616	1.4787	2.3186
22		.0514	.0495	.0476	1.8099	1.2593	1.9624
23		.0495		.0495	1.7909	1.2212	1.8861
24	.0495		.0485	.0476	.0495	1.6766	1.2022
Max	.0495	.0514	.0553	.0495	2.7161	2.5339	2.9405
Min	.0381	.04	.0467	.0476	.04	1.2212	.9638
Avg	.0443	.0473	.0498	.0481	.7396	1.9262	1.8988

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

WARGE SUB-DN.[614]

BU 4614

Substation No/ Name :- 213443 / 22/11 KV URBAN GRAM

Feeder No / Name : 204 / 11 KV SHINDE PARK

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8959	.8794		.9914		1.0015
2		.8865	.8421		.9541		.945
3		.8846	.7674		.9354		.8884
4		.9883	.73		.9541		.8507
5	.9522	1.1053	.8981		1.0474		.9638
6		1.2524	1.0661	.9242	1.1408	1.1389	1.0204
7		1.3203	1.3088	1.226	1.3088	1.3443	1.3222
8	1.4377	1.5161	1.4022	1.251	1.5292	1.3817	1.3222
9	1.307	1.4451	1.4265	1.4638	1.3294	1.4003	1.3373
10	1.2005	1.3051		1.376	1.264	1.4209	1.2449
11	.9709	1.1893	1.2491	1.2902	1.1837	1.2248	1.0619
12	.9709	1.1333	1.1427	1.1987	1.1035	1.1147	1.0298
13	.9149	.9896	1.0194	1.0064	.9597	1.0493	1.0412
14	.8695	1.0493	1.0194	1.0941	.997	1.0176	.9808
15	.8771	1.0717	1.0325	1.1221	1.0885	1.0474	1.0223
16	.8733	1.0288	.9335	1.0605	.9846	1.0223	1.0261
17	.9242	1.081	1.0269	1.124	1.0393	1.0657	1.0041
18	.9544		1.0829	1.1109	1.0487	1.1543	1.0619
19	1.1091	1.2528	1.1576	1.1968	1.1742	1.1751	1.143
20	1.2373	1.2902	1.3256	1.3667	1.3712	1.4184	1.4395
21	1.3071	1.3574	1.3256	1.3275	1.4278	1.3957	1.3835
22	1.2543	1.3088	1.251	1.3126		1.3312	1.307
23	1.1128	1.2155		1.1221	1.2136	1.152	1.2136
24	.9335	.9619	.8794	1.0082	1.0474	1.0456	1.04
Max	1.4377	1.5161	1.4265	1.4638	1.5292	1.4209	1.4395
Min	.8695	.8846	.73	.9242	.9354	1.0176	.8507
Avg	1.0670	1.1534	1.0803	1.1885	1.1345	1.2053	1.1105

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

KOTHRUD DIVISION[306]

WARGE SUB-DN.[614] BU 4614

Substation No/ Name :- 217028 / 132 KV KOTHRUD

Feeder No / Name : 308 / 22 KV LOKMANYA SWITCHING HV Non-Express Feeder
Feeder KV- 22 / INCOMING

DATE	15-JUN-17
HR	Load (MW)
17	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

CHINCHWAD SUB-DN.[635] BU 4635

Substation No/ Name :- 213353 / Kunal Icon

Feeder No / Name : 301 / Roseland

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9044	2.838	2.6513	2.963	3.062	3.0247	2.9874
2	1.643	2.6886	2.6139	2.7069	2.9127	2.838	2.9127
3	1.643	2.6886	2.5393	2.5606	2.838	2.7633	2.6886
4	1.7177	2.7633	2.5393	2.5606	2.838	2.95	2.6139
5	3.1367	2.838	2.6139	2.6337	2.95	2.9874	3.1741
6	3.1741	2.95	2.7633	2.524	3.1367	3.062	3.4355
7	3.9582	3.8462	3.062	3.0727	3.9582	3.7342	3.8836
8	4.1766	3.9956	3.4743	3.4751	4.1076	4.8544	4.1076
9	3.9179	3.9918	4.0703	4.1766	4.145	4.257	4.0329
10	3.9956	4.0703	4.5184	4.3983	4.0703	4.0703	3.8089
11	3.6222	3.8836	4.4063	4.2875	3.8462	3.8836	3.8462
12		3.5848		4.3614		3.6222	
13	3.2861	3.4355	4.1076		3.5101	3.2861	3.4728
14	3.2487	3.2114	3.8836	4.0287	3.4355		3.3608
15	3.0994	3.2861	3.8836	4.0657	3.5475	3.3981	3.3981
16	3.2861	3.4355	3.8089	3.9548	3.3608	3.3981	3.5482
17	3.4355	3.3981	3.6969	3.807		3.2861	3.3634
18	3.2114	3.5101		3.9179			3.2526
19	4.0703	4.0703	4.0329	4.369	4.1076	3.9956	3.77
20	4.0703	4.5184	4.2943	4.481	4.369	4.369	4.3614
21	4.2135	3.8836	4.1823	4.369	4.4437	4.5184	4.3317
22	3.6961	3.7715	3.9956	4.0287	4.0703		3.8809
23	3.5113	3.3608	3.6961	3.8439	3.6969	3.6969	3.6222
24	2.0538	2.9874	2.95	3.4355	3.2487	3.1741	3.0994
Max	4.2135	4.5184	4.5184	4.481	4.4437	4.8544	4.3614
Min	1.643	2.6886	2.5393	2.524	2.838	2.7633	2.6139
Avg	3.2205	3.4586	3.5356	3.6531	3.6026	3.5795	3.5197

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

CHINCHWAD SUB-DN.[635] BU 4635

Substation No/ Name :- 213353 / Kunal Icon

Feeder No / Name : 302 / Mithras Park

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4937	1.4937	1.307	1.5364	1.643	1.4937	1.6057
2	1.419	1.3443	1.2696	1.39	1.4937	1.419	1.531
3	1.419	1.419	1.2696	1.2437	1.4937	1.3817	1.4937
4	1.3443	1.3443	1.307	1.2437	1.419	1.4937	1.5684
5	1.531	1.3443	1.307	1.3169	1.419	1.6057	1.6804
6	1.6804	1.4937	1.3443	1.3169	1.5684	1.6057	1.643
7	2.0538	2.0538	1.6057	1.5729	2.0911	2.1658	2.0911
8	1.922	1.9791	1.7002	1.5729	2.0165	1.9791	2.2032
9	2.0538	2.1068	2.0538	1.885	2.0165	2.0911	
10	2.0911	2.2405	2.2779		2.0538	2.1879	2.0538
11	1.7924	2.3152	2.4272	2.1068	2.2032	2.0165	2.2405
12		2.1285		2.4764		2.1658	
13	1.7924	1.9791	2.3525		2.0911	2.0165	1.9791
14	1.8671	1.9044	2.1285	2.2546	1.8671		1.9418
15	1.8671	1.9044	2.1285	2.1437	1.7924	1.8298	1.9044
16	1.7177	1.9044	2.1285	2.0328	1.8298	1.8671	1.848
17	1.8671	1.9791	2.0911	2.1068		1.7924	1.848
18	1.8671	2.0538		1.885			1.848
19	2.3525	2.2032	2.2779	2.4272	2.3152	2.2405	2.1807
20	2.5019	2.5019	2.6513	2.5766	2.5766	2.5019	2.4394
21	2.4764	2.2405	2.5393	2.6139	2.6513		2.5393
22	2.2177	2.1658	2.3525	2.3655	2.2405	2.5393	2.2032
23	1.9589	1.8298	1.9589	2.1658	1.9791	2.0538	1.9589
24	1.6057	1.6057	1.4937	1.7551	1.7551	1.7177	1.7177
Max	2.5019	2.5019	2.6513	2.6139	2.6513	2.5393	2.5393
Min	1.3443	1.3443	1.2696	1.2437	1.419	1.3817	1.4937
Avg	1.8649	1.8973	1.9078	1.9086	1.9293	1.9126	1.9327

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

CHINCHWAD SUB-DN.[635] BU 4635

Substation No/ Name :- 213353 / Kunal Icon

Feeder No / Name : 303 / 22 KV Kunal Icon

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975	.5601	.5975	.6584	.6722		.6722
2	.5975	.5601	.5975	.5853	.5975	.6722	.5601
3	.5975	.5228	.5975	.5853	.5975	.6348	.5975
4	.5601	.5228	.5975	.5853	.5975	.6722	.6348
5	.6722	.5975	.5975	.5853	.6348	.7095	.7095
6	.7842	.7095	.6348	.5853	.7095	.7095	.7468
7	.9335	.9335	.6722	.6584	.8962	.9335	1.0082
8	.924	.8962	.8131	.695	.9054	.8215	.9335
9	.8501	.8501	.8215	.7392	.7842	.8589	.8589
10	.7842	.7468	.8589		.7842	.8299	.8215
11	.8215	.8589	.9709	.961	.8589	.7468	.7842
12		.7468		.961		.7842	
13	.7095	.6722	.8962		.7095	.6348	.6722
14	.5975	.5975	.8215	.8501	.7468		.6722
15	.6722	.5975	.7468	.7392	.6722	.6722	.5601
16	.5975	.6348	.7095	.7392	.6348		.5914
17	.6348	.6348	.7095	.7762			.6653
18	.6722	.7468		.7762			.6653
19	.9335	.8962	.8589	.8962	.8962	.8215	.7762
20	.9709	1.0829	.8962	1.0082	.9709	.9335	.961
21	.961	.8962	.9335	.9335	1.0082	1.0082	.9709
22	.924	.8589	.8962	.961	.8962		.8871
23	.7392	.7468	.7762	.8589	.8215	.8589	.8131
24	.6348	.6348	.6348	.7468	.7468	.7095	.6722
Max	.9709	1.0829	.9709	1.0082	1.0082	1.0082	1.0082
Min	.5601	.5228	.5975	.5853	.5975	.6348	.5601
Avg	.7465	.7294	.7563	.7675	.7686	.7784	.7493

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

CHINCHWAD SUB-DN.[635] BU 4635

Substation No/ Name :- 213353 / Kunal Icon

Feeder No / Name : 304 / Rainbow

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1658	2.6139	2.3525	2.726	2.838	2.6783	2.8292
2	2.0911	2.5393	2.3152	2.5393	2.8006	2.6139	2.6783
3	2.1658	2.3899	2.2405	2.3899	2.8006	2.5652	2.7538
4	2.2032	2.3899	2.2405	2.3899	2.838	2.7161	2.9424
5	2.3899	2.4646	2.3152	2.4143	2.9127	2.9424	3.2065
6	3.0994	3.062	2.6886	2.6886	3.1367	3.0933	3.2442
7	3.3234	3.3234	3.062	2.95	3.5101	3.4328	3.546
8	3.2156	3.3234	3.1417	3.1741	3.1741	3.3573	3.2819
9	3.2526	3.2895	3.3608	3.3634	3.2861	3.1687	3.2065
10	3.0933	3.2442	3.0994		3.0556	3.0556	3.0178
11		3.0556	3.1367		3.0556	2.8669	3.0178
12		2.9047				2.6406	
13		2.7161	2.9874		2.7538	2.5652	2.5652
14		2.5274	2.8292	2.9127	2.6406		2.4897
15	3.3608	2.6406	2.7538	2.9127	2.6783	2.8006	2.6029
16	3.2442	2.6783	2.8006	3.0994	2.6406		2.5766
17	3.131	2.6513	2.9801	3.2114			2.6612
18	3.2065	2.9127		3.2487			2.9424
19	3.5082		3.131	3.3234	3.0933	3.2487	3.1741
20	3.6969		3.546	3.7715		3.6222	3.6222
21	3.6591	2.6886	3.6591	3.7342	3.7346	3.6591	3.6969
22	3.5113	2.6513	3.6591	3.6595	3.6214		3.6595
23	3.1367		3.2861	3.4728	3.2819	3.2861	3.3234
24	2.5766	2.8006	2.8006	3.062	2.9874	2.9424	2.838
Max	3.6969	3.3234	3.6591	3.7715	3.7346	3.6591	3.6969
Min	2.0911	2.3899	2.2405	2.3899	2.6406	2.5652	2.4897
Avg	3.0016	2.8032	2.9266	3.0522	3.042	3.0134	3.0381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

CHINCHWAD SUB-DN.[635] BU 4635

Substation No/ Name :- 213353 / Kunal Icon

Feeder No / Name : 305 / Vajankata Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1132	.1132	.1132	.1509	.1132	.1132
2	.1132	.1132	.1132	.1132	.1132	.1132	.1132
3	.1132	.1132	.1132	.1132	.1132	.1132	.1132
4	.1132	.1132	.1132	.1132	.1132	.1132	.1132
5	.1132	.1132	.1132	.1132	.1132	.1509	.1132
6	.1132	.1509	.1132	.1509	.1509	.1509	.1132
7	.1509	.1886	.1132	.1509	.1509	.1509	.1509
8	.1509	.1509	.1132	.1132	.1509	.1509	.1509
9	.1509	.1132	.0747	.1509	.1494	.1509	.1132
10	.1132	.1132	.112		.1132	.1132	.1132
11		.1132	.112		.1132	.0754	.1132
12		.1132					
13	.112	.0754	.0747		.1132	.1132	.1132
14	.0747	.0754	.1132	.1494	.0754		.0754
15	.112	.0754	.0754	.112	.0754	.0747	.0754
16	.0754	.0754	.1132	.1494	.0754		.112
17	.0754	.0754	.0754	.1494			.1132
18	.0754	.0754		.112			.1132
19	.1509	.1132	.0747	.1494	.1509	.112	.1132
20	.1509	.1509	.1132	.1867	.1509	.1494	.1509
21	.1509	.1509	.1509	.1494	.1509	.1509	.1509
22	.1509	.1494	.1509	.1509	.1509		.1494
23	.1132	.1132	.1494	.1478	.1132	.1494	.1494
24	.1132	.1132	.1132	.1132	.1509	.1132	.112
Max	.1509	.1886	.1509	.1867	.1509	.1509	.1509
Min	.0747	.0754	.0747	.112	.0754	.0747	.0754
Avg	.1182	.1147	.1095	.1351	.1257	.1255	.1195

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

CHINCHWAD SUB-DN.[635] BU 4635

Substation No/ Name :- 213353 / Kunal Icon

Feeder No / Name : 306 / Gharonda

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.0754	.0754	.0754	.0754	.0754
2	.0754	.0754	.0754	.0754	.0754	.0754	.0754
3	.0754	.0754	.0754	.0754	.0754	.0754	.0754
4	.0754	.0754	.0754	.0754	.0754	.0754	.0754
5	.0754	.0754	.0754	.0754	.0754	.0754	.0754
6	.0754	.0754	.0754	.0754	.0754	.0754	.0754
7	.1132	.1132	.0754	.0754	.0754	.0754	.0754
8	.0754	.0754	.0754	.0754	.0754	.1132	.0754
9	.1132	.0754	.0747	.0754	.0747	.0754	.0754
10	.0754	.1132	.0747		.0754	.0754	.0754
11		.0754	.112		.0754	.0754	.0754
12		.0754				.0754	
13	.0747	.0754	.0747		.0377	.0754	.0754
14	.0747	.0754	.0377	.0747	.0754		.0754
15	.0747	.0754	.0754	.0747	.0377	.0747	.0754
16	.0754	.0754	.0377	.0747	.0754		.0754
17	.0754	.0377		.0747			.0754
18	.0754	.0377	.0377	.0747			.1132
19	.0754	.0754	.0754	.0747	.0754	.0747	.0754
20	.0754	.1132	.0754	.0747	.0754	.0747	.0754
21	.0754	.0747	.0754	.0747	.0754	.1132	.0754
22	.1132	.0754	.0754	.1132	.0754		.0747
23	.0754	.0754	.0747	.0754	.0754	.112	.0747
24	.0754	.0754	.0754	.0754	.0754	.1132	.112
Max	.1132	.1132	.112	.1132	.0754	.1132	.1132
Min	.0747	.0377	.0377	.0747	.0377	.0747	.0747
Avg	.0805	.0770	.0718	.0770	.0718	.0832	.0786

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

CHINCHWAD SUB-DN.[635] BU 4635

Substation No/ Name :- 213353 / Kunal Icon

Feeder No / Name : 307 / Atul Enterprises

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1886	.1886	.2263	.1886	.1886	.1886
2	.1509	.1886	.1886	.1886	.1886	.1132	.1509
3	.1509	.1509	.1886	.1886	.1886	.1509	.1886
4	.1509	.1509	.1886	.1886	.1886	.1509	.1886
5	.1886	.1509	.1886	.2263	.1886	.1509	.1886
6	.2263	.2263	.2263	.2263	.2263	.1509	.2263
7	.3395	.3018	.2263	.1886	.2641	.2263	.2263
8	.2241	.3018	.1886	.1886	.2641	.2263	.2641
9	.2641	.3018	.2987	.2641	.2641	.2641	.3018
10	.2641	.2641	.2987		.3018	.2263	.2641
11		.2263	.2614		.2641	.2263	.2641
12		.2641				.2641	
13	.2614	.1886	.3018		.2263	.1886	.2263
14	.1867	.1886	.2263	.2614	.2263		.1886
15	.1867	.1509	.2263	.2241	.2263	.1867	.1886
16	.1886	.1886	.2263	.2614	.1886		.2263
17	.2263	.2263	.2641	.2987			.2263
18	.2263	.2641		.2614			.2263
19	.2641	.2641	.2641	.2987	.3018	.2614	.2641
20	.3018	.2641	.2641	.2987	.2641	.2987	.3018
21	.3018	.2641	.2641	.2987	.3395	.3018	.2641
22	.2641	.2641	.2641	.3018	.3018		
23	.2641	.2263	.2614	.2614	.2263	.2614	.2614
24	.1886	.2263	.1886	.2263	.2263	.2263	.2241
Max	.3395	.3018	.3018	.3018	.3395	.3018	.3018
Min	.1509	.1509	.1886	.1886	.1886	.1132	.1509
Avg	.2259	.2263	.2361	.2439	.2407	.2139	.2295

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

CHINCHWAD SUB-DN.[635] BU 4635

Substation No/ Name :- 213361 / 22 KV GANESHAM S/W

Feeder No / Name : 301 / 22 KV GANESHAM SOC. NO. 1

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	17-JUN-17	19-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.1494
2			.1494
3			.1494
4			.1494
5			.1494
6			.1494
7			.1494
8			.1494
9			.1494
24	.1494	.1494	.1494
Max	.1494	.1494	.1494
Min	.1494	.1494	.1494
Avg	.1494	.1494	.1494

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

CHINCHWAD SUB-DN.[635] BU 4635

Substation No/ Name :- 213378 / ELPRO SWITCHING STATION

Feeder No / Name : 301 / 22 kv Keshavnagar Urban/Sheddable Urban Feeder
Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8107	1.9616	1.8861	2.2634	2.2634	2.1125	2.037
2	1.773	1.8861	1.8107	2.1125	2.1879	1.9993	2.0748
3	1.7353	1.8107	1.8107	2.1125	2.1125	1.9616	1.9239
4	1.7353	1.8107	1.7353	2.1125	2.1125	1.9616	1.8861
5	1.9239	1.9993	1.8861	2.037	2.1879	2.2634	2.037
6	2.1879	2.2634	1.9993	1.9993	2.2634	2.5274	2.2634
7	2.5652	2.6406	2.1879	2.1502	2.5274	2.9047	2.4143
8	2.6406	2.6029	2.4143	2.5274	2.6783	2.6406	2.6406
9	2.332	2.5274	2.2291	2.3663	2.2634	2.2634	2.1948
10	2.1948	2.4143	2.3663	2.4006	2.1605	2.1948	2.0576
11	2.1948	2.452	2.3663	2.332	2.1262	2.0919	2.0919
12	1.8176	2.2257	2.0919	2.2291	2.0233	1.989	1.989
13	1.8176	2.1502	2.0576	2.1605	1.9204	1.9547	1.8861
14	1.8176	1.9616	1.8861	1.9547	1.8176	1.8176	1.749
15	1.749	1.9239	1.7833	2.0233	1.8861	1.7833	1.749
16	1.848	1.9616	1.7833	2.2257	1.9239	1.9239	1.8484
17	1.922	2.3388	1.8861	2.1879	1.9616	1.8861	1.9239
18	2.1437	2.1125	2.0233	2.2634	2.1125	2.1125	2.1125
19	2.5873		2.2634	2.5652	2.7161	2.6029	2.5652
20	3.0308	3.131	2.8121	3.0933	3.2065	3.1687	3.1687
21	2.9938	2.9424	3.0556	3.2065	3.2065	3.0933	3.2065
22	2.8669	2.5652	2.8669	3.0178	2.9047	2.9047	2.6406
23	2.452	2.4143	2.5274	2.6406	2.6406	2.5274	2.332
24	1.9993	2.1502	1.9616	2.3388	2.3388	2.2634	2.2257
Max	3.0308	3.131	3.0556	3.2065	3.2065	3.1687	3.2065
Min	1.7353	1.8107	1.7353	1.9547	1.8176	1.7833	1.749
Avg	2.1725	2.2716	2.1538	2.3467	2.3143	2.2895	2.2091

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

CHINCHWAD SUB-DN.[635] BU 4635

Substation No/ Name :- 213378 / ELPRO SWITCHING STATION

Feeder No / Name : 302 / 22 kv GOKHALE PARK Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9808	1.5844	1.5466	1.6598	1.6598	1.6975	1.5844
2	.8299	1.5089	1.5089	1.5089	1.5089	1.5466	1.4712
3	.8299	1.5089	1.4712	1.5089	1.8107	1.5089	1.4712
4	.8299	1.5089	1.4712	1.5089	1.5844	1.5089	1.4335
5	.9054	1.5844	1.5466	1.5844	1.6598	1.6598	1.5089
6	1.0562	1.773	1.6598	1.6598	1.8107	1.8484	1.6975
7	1.2071	1.9616	1.8484	1.7353	2.037	2.1879	1.8484
8	1.2449	1.9993	2.1125	2.1125	2.1125	2.1125	2.0748
9	1.166	1.9616	2.0576	1.9204	2.0919	1.989	1.989
10	1.2003	2.037	2.0919	2.1605	2.0919	2.0919	2.0233
11	1.166	1.358	2.0919	2.1948	2.0576	2.0233	2.2291
12	1.166	2.3011	2.0919	1.9547	2.0233	1.989	2.0576
13	1.0288	2.0748	2.0576	1.8861	1.8176	1.8176	1.9204
14	.9602	1.9993	1.9547	1.989	1.7833	1.8861	.8573
15	.9259	1.9993	1.989	1.9204	1.9616	1.9204	1.8861
16	1.1317	2.1125	1.989	2.1125	1.9993	2.1125	1.9993
17	.9431	2.1879	1.9547	2.1879	2.037	2.1502	2.1125
18	2.037	2.2257	1.989	2.2634	2.1502	2.1879	2.1125
19	2.2257		2.2291	2.3765	2.4897	2.4143	2.4143
20		2.7915	2.4691	2.7161	2.6029	2.7915	2.6406
21	2.3899	2.452	2.5274	2.4897	2.5274	2.5274	2.5652
22	2.1502	2.1502	2.2257	2.1879	2.3011	2.1502	1.989
23	1.9616	1.8484	1.9993	1.9239	2.037	1.9993	1.7833
24	1.0185	1.7353	1.6221	1.773	1.8107	1.773	1.7353
Max	2.3899	2.7915	2.5274	2.7161	2.6029	2.7915	2.6406
Min	.8299	1.358	1.4712	1.5089	1.5089	1.5089	.8573
Avg	1.2763	1.9419	1.9377	1.9723	1.9986	1.9956	1.8919

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

CHINCHWAD SUB-DN.[635] BU 4635

Substation No/ Name :- 213378 / ELPRO SWITCHING STATION

Feeder No / Name : 303 / 22 KV ELPRO FEEDER Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1886	.1886	.1886	.1886	.1886	.1509
2	.1132	.1509	.1509	.1509	.1509	.1509	.1509
3	.1132	.1509	.1509	.1132	.1509	.1509	.1509
4	.1132	.1509	.1509	.1509	.1886	.1509	.1509
5	.1509	.1509	.1886	.1509	.1886	.1886	.1886
6	.1509	.1886	.1509	.1509	.1886	.2263	.1886
7	.1886	.1886	.1509	.1509	.2263	.2641	.2263
8	.1509	.1886	.2641	.1509	.1886	.2263	.2263
9	.1715	.2641	.2401	.1715	.1715	.1715	.2401
10	.2401	.3018	.2401	.2058	.2401	.2743	.2401
11	.2058	.3018	.2401	.2401	.2401	.2401	.2743
12		.2263	.2401	.1715	.2743	.2401	.2401
13	.2058	.3018	.2401	.2058	.2401	.2058	.2058
14	.1715	.2263	.2058	.1715	.1715	.2058	.2058
15	.1715	.2263	.2401	.1715	.2263	.2058	.2058
16	.2263	.2641	.2401	.2263	.2263	.2263	.2263
17	.2263	.2263	.2401	.2263	.2641	.2263	.2263
18	.2263	.2641	.1715	.1886	.2641	.2263	.2263
19	.2263	.2641	.2401	.1886	.2641	.2641	.2641
20	.2641	.2641	.2743	.2641	.2641	.3018	.2641
21	.2641	.2263	.2641	.2263	.3018	.3018	.2641
22	.1886	.1886	.2641	.2263	.2263	.2641	.2058
23	.2263	.1886	.2263	.2263	.2263	.2263	.1715
24	.1509	.1886	.1509	.1886	.1886	.1886	.1886
Max	.2641	.3018	.2743	.2641	.3018	.3018	.2743
Min	.1132	.1509	.1509	.1132	.1509	.1509	.1509
Avg	.1852	.2201	.2131	.1878	.2192	.2215	.2118

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

CHINCHWAD SUB-DN.[635] BU 4635

Substation No/ Name :- 213378 / ELPRO SWITCHING STATION

Feeder No / Name : 305 / SHRIDHARNAGAR Urban/Sheddable Urban Feeder
Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7922	.7545	.7922	.8676	.8676	.8299
2	.7545	.7922	.679	.7545	.7922	.7545	.7545
3	.7167	.7545	.679	.7167	.7545	.7545	.7545
4	.7167	.7545	.7167	.7545	.7545	.7167	.7545
5	.7545	.8299	.7545	.7545	.7167	.7922	.7922
6	.8299	.9054	.8299	.7167	.7922	.9054	.7922
7	.9054	1.0185	.9054	.7545	.9431	1.0185	.8299
8	1.0185	1.094	.9431	.8299	1.0562	1.094	1.0562
9	1.166	1.358	.8573	.823	1.2689	1.166	1.166
10	1.3717	1.4712	.9945	.8573	1.406	1.3032	1.406
11	1.3717	1.5844	1.1317	.9602	1.3032	1.406	1.3717
12	1.4403	1.4712		.9602	1.3032	1.166	1.406
13	1.3032	1.4712	1.0288	.9602	1.3717	1.0974	1.2689
14	1.3375	1.5466	.9945	.9259	1.3717	1.2689	1.2689
15	1.2003	1.5844	1.0288	.9945	1.5089	1.2003	1.1317
16	1.5089	1.4335	1.0288	1.0562	1.4335	1.358	1.3203
17	1.5089	1.4712	.9945	.9431	1.3957	1.3957	1.5089
18	1.5089	1.5466	.9945	.8676	1.3203	1.3957	1.5089
19	1.4335		1.0288	.9808	1.5466	1.4712	1.5089
20	1.5466	1.4712		1.2071	1.5089	1.5466	1.5466
21	1.3203	1.2826	1.2071	1.2826	1.358	1.2449	1.2449
22	1.1317		1.094	1.2071	1.2826	1.1317	1.0288
23	.9808	.9054	.9808	1.0185	1.0185	1.0185	.9259
24	.8299	.8676	.7545	.8676	.9054	.9054	.8676
Max	1.5466	1.5844	1.2071	1.2826	1.5466	1.5466	1.5466
Min	.7167	.7545	.679	.7167	.7167	.7167	.7545
Avg	1.1421	1.2003	.9264	.9161	1.1658	1.1241	1.1268

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

CHINCHWAD SUB-DN.[635] BU 4635

Substation No/ Name :- 213378 / ELPRO SWITCHING STATION

Feeder No / Name : 306 / GAWADE COLONY Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3203	1.5466	1.4712	1.6221	1.6975	1.6975	1.6975
2	1.4335	1.5466	1.4712	1.5466	1.5466	1.5466	1.6221
3	1.2449	1.4712	1.5089	1.5466	1.5466	1.5466	1.5844
4	1.358	1.4712	1.5089	1.5089	1.5844	1.5844	1.5844
5	1.5089	1.6221	1.5844	1.6598	1.6975	1.6975	1.6975
6	1.8107	1.8484	1.7353	1.8484	1.9239	1.9239	1.8861
7	2.037	1.9993	1.8107	1.8861	2.3011	2.0748	2.2257
8	2.1125	2.0748	2.1125	2.037	2.1879	2.2257	2.1502
9	1.7833	2.0748	1.8519	1.8176	1.8861	1.8519	1.8519
10	1.7147	1.8861	1.9547	1.9547	1.7147	1.749	1.8519
11	1.6461	1.9993	1.8176	1.6461	1.749	1.406	1.749
12	1.5775	1.8107	1.6461	1.6118		1.5775	1.6118
13	1.5432	1.7353	1.6461	1.6118	1.406	1.5775	1.5775
14	1.5089	1.5466	1.4746	1.5432	1.5089	1.5089	1.5089
15	1.3375	1.6975	1.6804	1.5432	1.5089	1.4746	1.4746
16	1.419	1.6598	1.6804	1.7353	1.4335	1.6598	1.6975
17	1.1576	1.6221	1.6118	1.7353	1.3203	1.6598	1.4335
18	1.4563	1.5466	1.5089	1.094	1.5844	1.7353	1.6221
19	1.8671		1.6461	1.9993	1.9993	1.8484	1.8484
20	2.1807	1.6975	2.0233	2.3765	2.2634	2.3011	2.2634
21	2.1437	1.7353	2.1502	2.3388	2.2634	2.3388	2.1502
22	2.0748		2.1125	2.2634	2.1125	2.2634	1.9547
23	1.8484	1.8107	1.8861	2.0748	2.037	1.9993	1.7833
24	1.4335	1.5466	1.4712	1.6598	1.773	1.773	1.8861
Max	2.1807	2.0748	2.1502	2.3765	2.3011	2.3388	2.2634
Min	1.1576	1.4712	1.4712	1.094	1.3203	1.406	1.4335
Avg	1.6466	1.7250	1.7235	1.7775	1.7846	1.7926	1.7797

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

CHINCHWAD SUB-DN.[635] BU 4635

Substation No/ Name :- 213382 / 22 KV MIND SPACE S/W

Feeder No / Name : 301 / 22 KV LOKMANYA HOSPITAL Urban/Sheddable Urban Feeder
Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1829	.1905	.1905	.1905	.1981	.1905
2	.1524	.1677	.1829	.1829	.1524	.1829	.1905
3	.1524	.1524	.1677	.1677	.1524	.1677	.1905
4	.1524	.1524	.1524	.1524	.1524	.1829	.1905
5	.1524	.1829	.1905	.1981	.1905	.2134	.2286
6	.1905	.2134	.2362	.2286	.1905	.2362	.2286
7	.1905	.2439	.2286	.2362	.1905	.2515	.2286
8	.1905	.2515	.2324	.2324	.1905	.2362	.2286
9	.1905	.2591	.2401	.2667	.1905	.2782	.2286
10	.1867	.2667	.2286	.2439	.2858	.2515	.2591
11	.1753	.2667	.2286	.2743	.2439	.2515	.2439
12	.2401	.2286	.2286	.2439	.2324	.282	.2362
13	.2362	.2286	.1905	.2362	.2629	.2324	.2439
14	.2324	.2286	.1905	.2286	.2286	.2286	.2362
15	.2362	.2286	.1905	.221	.2401	.2324	.2401
16	.2324	.2286	.1905	.2286	.2324	.2324	.2439
17	.2286	.2439	.1829	.1905	.2439	.2286	.2286
18	.1981	.2324	.1981	.1905	.2362	.2286	.1981
19	.2134	.2286	.2286	.2286	.2401	.2286	.2477
20	.2515	.2324	.2591	.2286	.2439	.2286	.2591
21	.2515	.2286	.2515	.2286	.2858	.2286	.2743
22	.2324	.2324	.2362	.1905	.2591	.2286	.2515
23	.2134	.2286	.221	.1905	.2362	.1905	.2286
24	.1524	.1981	.1981	.1981	.1905	.2134	.1905
Max	.2515	.2667	.2591	.2743	.2858	.282	.2743
Min	.1524	.1524	.1524	.1524	.1524	.1677	.1905
Avg	.2002	.2212	.2102	.2157	.2193	.2264	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

CHINCHWAD SUB-DN.[635] BU 4635

Substation No/ Name :- 213382 / 22 KV MIND SPACE S/W

Feeder No / Name : 302 / 22 KV DALVINAGAR

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.7354	.6783	.724	.8764	.7621	.9145
2	.724	.7087	.6249	.6478	.8764	.7659	.8764
3	.6859	.6287	.6097	.6249	.8764	.7087	.8383
4	.6859	.5868	.602	.6097	.8383	.6592	.8383
5	.7621	.7545	.6478	.6783	.8764	.7545	.8764
6	.8383	.8612	.7011	.7202	.9145	.8993	.9145
7	.9907	1.0098	.8002	.8383	.9907	1.0517	.9907
8	.9526	.9107	.8573	.8459	.8764	.8612	.8764
9	.9145	.8345	.7964	.8307	.8002	.8497	.8383
10	.7468	.7621	.8383	.8345	.6973	.7087	.7011
11	.6592	.6859	.7621	.8192	.7011	.6897	.6325
12	.6173	.6859	.6859	.7545	.6859	.6287	.6173
13	.5982	.6859	.6859	.6935	.6097	.6516	.6249
14	.6059	.6859	.6097	.7011	.6173	.6249	.6135
15	.5792	.6097	.6097	.6935	.602	.6173	.6211
16	.5792	.6097	.6516	.7316	.6401	.6097	.6173
17	.6249	.6211	.6516	.6859	.6135	.6478	.6325
18	.6592	.6554	.6744	.724	.6287	.6859	.6554
19	.7659	.7697	.7583	.8383	.8154	.8383	.7849
20	.9335	.9526	.9602	.9145	.9869	.9145	.9983
21	.9602	.9374	.9831	.9907	.9793	.9907	.9907
22	.9374	.8993	.9755	.9526	.9755	.9526	1.0059
23	.8497	.7888	.8764	.9526	.9069	.9145	.8764
24	.7621	.7773	.724	.804	.9145	.804	.9145
Max	.9907	1.0098	.9831	.9907	.9907	1.0517	1.0059
Min	.5792	.5868	.602	.6097	.602	.6097	.6135
Avg	.7565	.7565	.7402	.7754	.8042	.7746	.8021

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

CHINCHWAD SUB-DN.[635] BU 4635

Substation No/ Name :- 213382 / 22 KV MIND SPACE S/W

Feeder No / Name : 303 / QUEENS TOWN RMU NO. 1 Urban/Sheddable Urban Feeder
Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1981	.1905	.1981	.3048	.2134	.2667
2	.1905	.1905	.1867	.1905	.2667	.202	.2667
3	.1905	.1867	.1715	.1867	.2667	.1867	.3048
4	.2286	.1753	.1829	.1753	.2667	.1905	.2667
5	.3429	.221	.2058	.2058	.2667	.2591	.3048
6	.3048	.2629	.2667	.2591	.3429	.301	.381
7	.381	.3277	.2515	.2439	.4191	.3658	.4191
8	.3429	.3506	.3315	.2667	.381	.3353	.3429
9	.3429	.3429	.3467	.2896	.3048	.3125	.3048
10	.3125	.3048	.3048	.3353	.282	.2667	.3163
11	.282	.2667	.2667	.3506	.2667	.282	.2553
12	.2553	.2667	.2667	.2782	.2439	.3277	.2439
13	.2324	.2667	.2286	.2972	.2743	.2477	.2553
14	.2324	.2286	.2286	.2439	.221	.2134	.2362
15	.2134	.1905	.1905	.2286	.202	.2286	.221
16	.2248	.2286	.2286	.282	.2477	.2362	.2439
17	.2439	.1981	.2477	.2667	.202	.2667	.2286
18	.2134	.2286	.2591	.2667	.2591	.2667	.2134
19	.2667	.2782	.2362	.2667	.2934	.2667	.2591
20	.3353	.2858	.3239	.2667	.301	.2667	.3239
21	.2553	.2896	.2743	.3048	.2858	.3048	.301
22	.2705	.2782	.2743	.2667	.301	.2667	.2743
23	.2515	.2515	.282	.3048	.2743	.3048	.282
24	.1905	.2248	.1981	.2477	.3048	.2515	.2667
Max	.381	.3506	.3467	.3506	.4191	.3658	.4191
Min	.1905	.1753	.1715	.1753	.202	.1867	.2134
Avg	.2623	.2518	.2477	.2593	.2824	.2651	.2824

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

CHINCHWAD SUB-DN.[635] BU 4635

Substation No/ Name :- 213434 / 22 KV Pradhikaran Switching

S/

Feeder No / Name : 301 / sector 29

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.679	.679	.7922	.7167	.679	.7545
2	.6036	.6036	.6036	.7545	.679	.6413	.7167
3	.5658	.6036	.5658	.7545	.7167	.6036	.679
4	.6413	.679		.679	.7545	.6413	.7167
5	.679	.8299	.679	.7545	.8299	.7167	.7545
6	.7545	.8299	.679	.7545	.8299	.8299	.8299
7	.9431	.9808	.7922	.7922	.9808	.9431	.9808
8	.9431	.8676	.8676	.8299	.9808	.9054	.9431
9	.8676	.8299	.9431	.8676	1.0562	.8676	.9054
10	1.0185	.9431	.9808	.9808	.9808	.9808	.9431
11	.9054	.9431		1.0562	.9431	1.0562	.9808
12		.9431	1.094	1.1317	.9431	.9431	.9431
13	.9431	.9431	1.0185	1.0185	.9054		.9431
14	.8299	.8676	.9808	.9808	.8299		.8676
15		.8676	.9431	.9808	.8299	.8299	.8676
16		.9054	.9431	1.0185	.8299	.8676	.8676
17	1.2449	.9054	.9808	1.1317	.9808	.9431	.9431
18	1.094	.9431	.9431	1.0562	.9808	.9431	.9431
19	1.094	1.094	1.0562	1.0562	1.094	.9808	1.1317
20	1.2071	1.094	1.2071	1.1694	1.2071	1.2071	1.2071
21	1.1694	1.0562	1.1317	1.1694	1.1317	1.2071	1.1317
22	.9431		.9808	.9431	1.0185	1.094	.9808
23	.8299	.7922		.7922	.8676	.8676	.8676
24	.6413	.7545	.679	.7922		.7545	.7922
Max	1.2449	1.094	1.2071	1.1694	1.2071	1.2071	1.2071
Min	.5658	.6036	.5658	.679	.679	.6036	.679
Avg	.8820	.8676	.8928	.9274	.9168	.8865	.9038

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

CHINCHWAD SUB-DN.[635] BU 4635

Substation No/ Name :- 213434 / 22 KV Pradhikaran Switching

S/

Feeder No / Name : 303 / 22 KV Vikasnagar

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9054	3.3573	4.7531	4.4136	4.1872	4.3004	3.4328
2	.8676	3.3196	4.8285	4.3759	3.9986	3.9986	3.3196
3	.8676	3.7723	4.6776	4.3004		4.1118	3.2819
4	.9054	3.9986	4.8285	4.3759		4.2627	3.3573
5	1.0562	4.1118	5.3189	4.4513	4.9794	4.6022	3.546
6		4.1118	5.3189	4.4513	5.0926	5.0172	4.1118
7	1.2449	4.5645	5.7339	4.904	5.6584	5.7716	4.4513
8	1.094	4.6022	6.262	5.1303	5.5076	5.4321	4.7908
9	1.1317	5.583	7.2051	5.5076	5.998	6.6392	5.583
10	1.1317	5.168	7.0542	5.5453	5.9602	6.5261	5.4698
11	1.2071	5.168		5.168	6.2997	6.3375	5.0172
12	1.094	4.5268	5.8848	5.0172	6.0357	4.8285	4.225
13	.9808	4.0741	5.6207	4.8663	5.0549	4.8285	4.1118
14	.9808	4.8285	5.2435	4.5645	4.8285		3.7723
15	3.9609	4.8663	5.0172	4.3381	4.6022	4.7154	3.6969
16	3.7723	4.4136	5.0549	4.3004	4.4513	3.5837	4.2627
17	3.6591	4.4513	5.2058	4.4513	4.4136	4.3381	4.225
18	3.7346	4.4513	5.1303	4.489	3.546	4.1118	4.3381
19	4.0364	4.5268	5.3944	4.1495		4.5268	5.0172
20	4.7908	6.262	5.6207	5.6962	5.5076	5.5453	5.5453
21	4.904	6.4129	5.8471	5.6207	5.6962	5.8093	5.4698
22	4.5645		5.5453	5.168	5.4698	5.4698	5.5453
23	4.1495			4.904	5.0926		4.9794
24	.9054	3.6969	4.7531	4.4136	4.4136	4.489	3.8477
Max	4.904	6.4129	7.2051	5.6962	6.2997	6.6392	5.583
Min	.8676	3.3196	4.6776	4.1495	3.546	3.5837	3.2819
Avg	2.2585	4.5576	5.4681	4.7751	5.0854	4.9657	4.3916

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

DAPODI SUB-DN.[593] BU 4593

Substation No/ Name :- 213018 / CIRT S/STN

Feeder No / Name : 303 / Kharalwadi

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.3772	.5658	.5281	.5281	.4527	.5281
2	.4904	.3772	.5281	.5658	.5281	.4527	.5281
3	.4904	.3772	.4904	.5281	.5281	.4527	.5281
4	.4527	.3772	.5281	.5281	.5281	.4527	.5281
5	.415	.3772	.5281	.5281	.5281	.4527	.5281
6	.3772	.3772	.5281	.5281	.5281	.4527	.5281
7	.3772	.3772	.6036	.5281	.5281	.4527	.5281
8	.3772	.3772	.6036	.6036	.5281		.6036
9	.415	.4904	.679	.6413	.6036	.5658	.6413
10	.4527	.6413	.7545	.679	.679	.7167	.7545
11	.5281	.7545	.7545	.679	.8299	.7545	.8299
12	.5281	.7545	.7922	.6413	.8299		.7922
13	.5658	.7545	.8299	.6413	.7922	.8299	.8299
14	.4904	.7545	.8299	.679	.8299	.7922	.7545
15	.4904	.7545	.8299	.679	.7545	.7545	.8299
16	.5281	.7922	.8299	.6413	.8299	.7167	.8676
17	.4904	.8299	.8299		.7545	.679	.7545
18	.4904	.7922		.6036	.7545	.679	.679
19	.4527			.6036	.7167	.679	.679
20	.4527	.7545	.7545	.679	.679	.679	.679
21	.415	.7167	.679	.6413	.6036	.6413	.6413
22	.415	.8299	.679	.679	.6036	.6036	.6036
23	.4904	.6413	.6413	.6036	.5281	.6036	.6036
24	.5658	.3772	.5658	.5281	.5281	.4904	.5281
Max	.5658	.8299	.8299	.679	.8299	.8299	.8676
Min	.3772	.3772	.4904	.5281	.5281	.4527	.5281
Avg	.4700	.5937	.6739	.6068	.6476	.6070	.6570

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

DAPODI SUB-DN.[593] BU 4593

Substation No/ Name :- 213018 / CIRT S/STN

Feeder No / Name : 306 / CME

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8292	3.0933	2.8669	3.0556	3.0178	3.1687	3.1687
2	2.7538	3.0178	2.5652	2.9424	3.0178	3.0933	3.0933
3	2.6783	3.0178	2.2634	3.0178	3.0178	3.0178	3.0178
4	2.7915	3.0178	2.6029	3.0178	3.0178	3.0178	3.0178
5	2.8669	3.0933	2.8669	3.0178	3.1687	3.2442	3.0933
6	3.1687	3.3196	3.0933	3.0178	3.546	3.3196	3.6969
7	3.5837	3.8477	3.3573	3.3951	3.7723	3.7723	3.6969
8	4.2627	3.7723	3.4705	3.5082	3.7723	3.7723	3.9232
9	3.5837	3.8477	3.6969	3.5082	3.7723	3.6969	3.7346
10	3.5837	3.8855	3.7723	3.3951	3.8104	3.6969	3.81
11	3.546	3.6969	3.7723	3.2819	2.6406	3.6591	3.6214
12		3.6969	3.8477	3.2819	2.4143		3.546
13	3.0933	3.6969	3.6969	3.3951	3.546	3.3951	3.4705
14	3.2065	3.6969	3.4705	3.2442	3.4705	3.3951	3.5082
15		3.6969	3.4328	3.0933	3.546	3.2819	3.3951
16	3.3196	3.5837	3.3951	3.1687	3.3196	3.2442	3.3951
17	3.3196	3.5082	3.3951	3.1687	3.3951	3.2442	3.4705
18	3.3196	3.6214		3.3573	3.6214	3.3573	3.5082
19	3.7723	.4904		3.5082	3.7723	3.6591	3.9232
20	4.225	3.0933	4.1495	4.2627	4.3759	4.4136	4.489
21	4.1495	4.0364	4.1495	4.1495	4.2627	4.3759	4.4513
22	3.9232		3.9232	4.0741	3.9232	4.1495	4.1495
23	3.5837	3.3951	3.6214	3.6969	3.6214	3.7723	3.6969
24	3.0178	3.1687	2.9801	3.0178	3.3196	3.3196	3.3951
Max	4.2627	4.0364	4.1495	4.2627	4.3759	4.4136	4.489
Min	2.6783	.4904	2.2634	2.9424	2.4143	3.0178	3.0178
Avg	3.3899	3.3606	3.3814	3.3573	3.4642	3.5246	3.5947

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

DAPODI SUB-DN.[593] BU 4593

Substation No/ Name :- 213018 / CIRT S/STN

Feeder No / Name : 307 / CIRT

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.0594	.0754	.064	.0556	.0747
2	.0754	.0754	.0518	.0754	.0655	.0564	.0754
3	.0754	.0754	.0594	.0754	.0671	.0564	.0732
4	.0754	.0754	.0648	.0754	.0655	.0533	.0732
5	.0754	.0754	.0633	.0754	.0663	.0533	.0747
6	.0754	.0754	.0633	.0754	.064	.0549	.0716
7	.0754	.0754		.0754	.0655	.0488	.0709
8	.1132	.0754	.0655	.0678	.0686	.0564	.0754
9	.1509	.0754	.0754	.0625	.0754	.0724	.0732
10	.1509	.0754	.0754	.0754	.0754	.0381	.0747
11	.1886	.0754	.0754	.0754	.0754	.0381	.1494
12	.1509	.0754	.0754	.0754	.0754		.112
13	.1132	.0754	.0754	.0754	.0754	.0754	.1109
14	.0754	.0754	.0754	.0754	.0754	.1494	.0732
15	.1509	.0754	.0754	.0754	.0754	.112	.0754
16	.1132	.1132	.0754	.0754	.112	.112	.0754
17	.0754	.1132	.0686	.0754	.0754	.0762	.0747
18	.0541	.0602	.0754	.0754	.0754	.0754	.0739
19	.0457		.0754	.0754	.0754	.0754	.0754
20	.0655	.0248	.0754	.0754	.0602	.0754	.0754
21	.0701	.0366	.0754	.0663	.0648	.0754	.0747
22	.0754	.0366	.0754	.0625	.0617	.0754	.0762
23	.0754	.0335	.0754	.0686	.0625	.0762	.0701
24	.0754	.0754		.0754	.0633	.0671	.0747
Max	.1886	.1132	.0754	.0754	.112	.1494	.1494
Min	.0457	.0248	.0518	.0625	.0602	.0381	.0701
Avg	.0947	.0706	.0705	.0733	.0710	.0708	.0804

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

DAPODI SUB-DN.[593] BU 4593

Substation No/ Name :- 213018 / CIRT S/STN

Feeder No / Name : 308 / J N Marshal

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.6022	4.904	4.6022	2.5652	3.7723	5.1303	5.0549
2	4.4513	4.904	4.4513	2.6292	3.6969	4.8285	4.8285
3	4.3004	4.904	3.8855	2.3388	3.6214	4.8285	4.6776
4	4.225	4.9417	3.7723	2.3388	3.6214	4.6776	4.6022
5	4.1495	4.904	4.1495	2.3388	3.7723	4.6022	4.5268
6	4.6399	4.9794	4.0364	2.3388	3.546	4.6022	4.5268
7	5.4698	5.2812	5.2058	2.3011	5.4321	5.3567	5.3567
8	6.5638	6.7901	6.2243	2.3765	7.1674	6.8656	7.1674
9	7.2051	7.356	6.8279	2.3765	7.4691	7.8087	7.8464
10	8.0727	7.8464	6.7901	2.3765	7.6578	7.8087	
11	7.6578	8.2991	6.7901	2.4143	7.4691	7.8087	8.2236
12	7.1674	8.2991	6.7901	2.4897	7.3183		8.5631
13	8.1859	7.9973	6.7147	2.4143	8.1859	8.1104	8.3368
14	8.1482	7.62	6.5638	2.2634	8.1859	8.1104	7.3183
15	7.4691	7.5823	6.3752	2.2634	7.3937	8.1104	7.3937
16	7.5446	7.5446	6.1488	2.2634	7.4314	6.941	8.1104
17	6.9033	7.5069	5.9225	2.3388	7.8841	6.9787	7.2805
18	6.2243	6.7524	5.8848	2.1125	6.5638	6.6015	6.7524
19	6.1111		4.9794	2.1502	5.8471	5.7716	6.0734
20	5.7716		4.9794	2.037	5.7716	5.998	5.7716
21	5.6962		5.0549	1.9616	5.5453	5.6207	5.7716
22	5.6584	.0754	4.1495	2.037	5.2812	5.6584	6.0357
23	4.6399	.0754	2.9424	3.0933	5.0549	4.904	5.1303
24	4.6399	4.904		2.6406	3.9232	4.7531	4.9794
Max	8.1859	8.2991	6.8279	3.0933	8.1859	8.1104	8.5631
Min	4.1495	.0754	2.9424	1.9616	3.546	4.6022	4.5268
Avg	6.0624	5.8794	5.3583	2.3525	5.9005	6.1685	6.2751

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

DAPODI SUB-DN.[593] BU 4593

Substation No/ Name :- 213356 / Sukhwani

Feeder No / Name : 301 / S T Stand Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.7528	1.6766	1.5242	1.448	1.6004	1.6766
2	1.2955	1.6766	1.6004	1.448	1.3717	1.5242	1.5623
3	1.2955	1.6004	1.4861	1.3717	1.3336	1.3717	1.4098
4	1.3336	1.4861	1.3717	1.3336	1.4098	1.4098	1.448
5	1.4098	1.6385	1.4098	1.3717	1.5242	1.4861	15.9275
6	1.448	1.8671	1.4861	1.4098	1.7528	1.6004	1.6766
7	1.4861	1.9433	1.5623	1.448	2.0195	1.6385	1.9052
8	2.1338	2.3243	1.6004	1.448	2.4387	2.0957	2.21
9	2.2481	2.6673	1.6004	1.6766	2.8197	2.1719	2.5911
10	2.6292	2.553	1.6766	1.5623	2.3243	2.7054	2.553
11	2.5911	2.553	1.9052	1.5623	3.0483	2.5149	3.0483
12	2.3624	2.8578	2.1719	1.6004	2.4387	2.7054	2.3624
13	2.6673	2.5149	.4954	1.6004	2.553	2.8959	2.5149
14	2.8197	2.5149	2.5911	1.3717	3.1626	2.2862	2.934
15	2.6673	2.934	1.8671	1.4861	2.934	2.9721	2.6673
16	2.4768	2.4768	1.7147	1.5242	2.553	2.4006	2.8959
17	2.5911	2.5149	2.0957	1.448	2.0576	2.21	2.8578
18	2.3243	2.5911	1.9433	1.4861	1.9052	2.4006	2.6673
19	2.5149	2.4768	2.1719	1.5623	2.3243	2.5149	2.6292
20	2.3624	2.1719	2.1719	1.8671	2.4387	2.4387	2.4768
21	2.4006	2.4768	2.0195	1.7909	2.5149	2.553	2.6292
22	1.9814	2.0957	1.9433	1.7147	2.2862	2.2481	2.4006
23	1.8671	1.829	1.9433	1.6766	1.9814	1.9814	2.1338
24	1.448	1.829	1.7528	1.6385	1.5242	1.7147	1.7528
Max	2.8197	2.934	2.5911	1.8671	3.1626	2.9721	15.9275
Min	1.2955	1.4861	.4954	1.3336	1.3336	1.3717	1.4098
Avg	2.0719	2.2228	1.7607	1.5385	2.1735	2.1434	2.8721

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

DAPODI SUB-DN.[593] BU 4593

Substation No/ Name :- 213356 / Sukhwani

Feeder No / Name : 302 / Acharya Atre

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8671	2.1338	1.9814	2.0576	2.1338	2.0195	2.0957
2	1.7528	2.0195	1.8671	1.9052	1.9814	1.9052	1.9433
3	1.7147	1.8671	1.7528	1.9433	2.0576	1.8671	1.7909
4	1.7528	1.7147	1.7147	2.0195	2.1719	1.7909	1.7528
5	1.9052	1.8671	1.9433	2.1338	2.2862	2.1338	1.9814
6	2.0576	2.0576	2.1719	2.21	2.3624	2.3624	2.3624
7	2.4006	2.6292	2.3243	2.2862	2.5149	2.5149	2.553
8	2.3624	2.5149	2.2862	2.2481	2.4768	2.4768	2.4006
9	2.2862	2.3243	2.2481	2.21	2.21	2.2862	2.2481
10	2.1719	2.21	2.21	2.1719	2.21	2.1719	2.21
11	4.1533	2.2481	2.1719	2.21	2.1338	2.1338	2.0957
12	3.8485	2.0957	2.1719	2.21	2.0957	1.9814	2.0195
13	3.6961	2.0957	2.0576	2.0957	2.0957	2.0195	2.0195
14	3.658	2.0195	1.9433	1.9052	1.9433	1.9433	1.9052
15	3.6199	1.9433	1.9433	2.0576	1.9814	1.9052	1.9052
16	2.0576	1.9052	1.9052	2.0195	1.9433	1.9433	1.9052
17	1.9814	1.9433	2.0576	2.0576	1.9433	1.9052	2.0195
18	2.0957	2.0576	2.0957	2.1338	2.0195	2.0576	2.0957
19	2.2481	2.2862	2.3624	2.2862	2.4387	2.4006	2.4006
20	2.6673	2.6292	2.7435	2.7816	2.7816	2.8197	2.8959
21	2.6292	2.5149	2.7435	2.7435	2.7435	2.7816	2.7816
22	2.5149	2.4006	2.6673	2.7054	2.5911	2.6292	2.5911
23	2.3624	2.21	2.4768	2.5149	2.4387	2.4768	2.4768
24	1.9433	2.2862	2.0576	2.21	2.2481	2.21	2.21
Max	4.1533	2.6292	2.7435	2.7816	2.7816	2.8197	2.8959
Min	1.7147	1.7147	1.7147	1.9052	1.9433	1.7909	1.7528
Avg	2.4895	2.1656	2.1624	2.2132	2.2418	2.1973	2.1942

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

DAPODI SUB-DN.[593] BU 4593

Substation No/ Name :- 213356 / Sukhwani

Feeder No / Name : 303 / sukhwani campus

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2286	.4572	.2286	.2286	.1905	.1905
2	.1905	.1905	.381	.1905	.1905	.1905	.1905
3	.1905	.1905	.381	.1905	.1905	.1905	.1905
4	.1905	.1905	.1905	.1905	.1905	.1524	.2286
5	.1905	.2286	.1905	.1905	.1905	.2286	.2286
6	.2286	.2667	.2286	.2286	.2286	.2667	.3048
7	.2667	.3048	.2286	.2667	.3048	.3048	.3048
8	.3048	.3048	.3048	.2667	.3048	.3429	.3048
9	.3048	.2667	.2667	.3048	.3048	.2667	.3048
10	.2667	.3048	.2667	.2667	.2667	.2667	.2286
11	.2667	.2286	.2667	.2667	.2286	.2286	.2286
12	.2286	.2286	.2667	.2667	.2667	.1905	.2286
13	.2286	.2286	.2286	.2286	.2286	.2286	.2286
14	.2286	.2286	.2286	.2667	.2286	.2286	.2286
15	.2286	.1905	.2286	.2286	.2286	.1905	.1905
16	.2286	.1905	.2286	.2286	.2286	.1905	.1905
17	.2286	.2286	.2286	.2286	.2286	.2286	.2667
18	.2667	.2286	.2667	.2286	.2667	.1524	.2667
19	.2667	.2667	.2667	.2667	.2667	.3048	.3429
20	.3048	.3048	.2667	.3429	.3048	.3048	.3048
21	.2667	.3048	.2667	.3048	.3048	.3048	.2667
22	.2667	.2667	.2667	.3048	.2667	.2667	
23	.1905	.2286	.2667	.2667	.2286	.2667	.2286
24	.2286	.2286	.4572	.2286	.2286	.2286	.2286
Max	.3048	.3048	.4572	.3429	.3048	.3429	.3429
Min	.1905	.1905	.1905	.1905	.1905	.1524	.1905
Avg	.2397	.2429	.2762	.2492	.2461	.2381	.2468

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

DAPODI SUB-DN.[593] BU 4593

Substation No/ Name :- 213359 / Swarganga

Feeder No / Name : 301 / Swarganga Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1207	.1531	.1344	.1307	.1698	.1584	.1509
2	.1419	.1433	.127	.1344	.1584	.1755	.1509
3	.1307	.1509	.1232	.127	.1606	.1584	.1433
4	.1195	.1358	.127	.1232	.166	.1396	.1471
5	.1509	.1358	.1307	.1195	.1698	.1584	.1622
6	.1735	.1924	.1456	.127	.1962	.1773	.2263
7	.249	.2641	.168	.1419	.2339	.2301	.2942
8	.2188	.2905	.1999	.1811	.2414	.2414	.2641
9	.2263	.2075	.2263	.2075	.2527	.2716	.2263
10	.2188	.2527	.2678	.2414	.2075	.2452	.2112
11	.1924	.166	.2414	.2565	.1811	.1531	.1547
12	.1396	.1584	.1433	.1509	.166	.1494	.1433
13	.1245	.1368	.1294	.1433	.132	.1307	.1584
14	.1207	.1456	.132	.132	.1344	.1232	.1509
15	.1245	.1396	.1433	.132	.1307	.1307	.1433
16	.1396	.1207	.1396	.1547	.1245	.1358	.132
17	.1358	.1307	.1245	.1358	.1283	.1169	.1169
18	.1283	.1471	.1283	.1584	.1283	.1283	.1307
19	.1698	.1698	.1584	.1773	.1584	.1643	.183
20	.1848	.1584	.1811	.1999	.1962	.1924	.1811
21	.1962	.1698	.1735	.1811	.2037	.1811	.1962
22	.1962	.166	.166	.1848	.1962	.1848	.1886
23	.1886	.1509	.1773	.1962	.1735	.1924	.1886
24	.1419	.166	.1307	.1698	.1773	.1718	.1584
Max	.249	.2905	.2678	.2565	.2527	.2716	.2942
Min	.1195	.1207	.1232	.1195	.1245	.1169	.1169
Avg	.1639	.1688	.1591	.1628	.1745	.1713	.1751

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

DAPODI SUB-DN.[593] BU 4593

Substation No/ Name :- 213359 / Swarganga

Feeder No / Name : 302 / Gangasky

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0425	.0446	.0446	.0456	.0573	.052	.0561
2	.0456	.0461	.0436	.0451	.0567	.0485	.0475
3	.0421	.0451	.0398	.0407	.0537	.0456	.0469
4	.0381	.0416	.0421	.0412	.0537	.0407	.0441
5	.0425	.0496	.0389	.0381	.0573	.0461	.0485
6	.0501	.052	.0475	.0421	.0716	.0615	.0573
7	.0754	.0953	.0709	.0461	.08	.1132	.0615
8	.0943	.083	.083	.0792	.0981	.083	.0905
9	.083	.0754	.0905	.0905	.0822	.0754	.0868
10	.0717	.049	.0868	.0971	.0747	.083	.0792
11	.1029	.0754	.083	.0732	.0792	.0747	.0641
12	.0566	.0679	.0717	.0739		.0528	.0528
13	.0485	.0566	.0528	.0501	.0485	.0485	.049
14	.048	.0566	.0517	.0471	.0523	.0485	.0453
15	.0507	.0523	.0517	.0439	.056	.0523	.0453
16	.043	.0485	.0554	.0461	.0485	.0394	.0451
17	.0501	.056	.0411	.0537	.0528	.0402	.0362
18	.0591	.0597	.0528	.0425	.0717	.0543	.0523
19	.0717	.0754	.0754	.0724	.0597	.0679	.0717
20	.0905	.083	.0672	.0876	.0754	.0754	.0554
21	.0792	.0905	.0635	.0679	.0859	.083	.0537
22	.0747	.0679	.0461	.0784	.0784	.0702	.0652
23	.0673	.0526	.0532	.0615	.0681	.0596	.0589
24	.0543	.0475	.0485	.0532	.0573	.0561	.0475
Max	.1029	.0953	.0905	.0971	.0981	.1132	.0905
Min	.0381	.0416	.0389	.0381	.0485	.0394	.0362
Avg	.0617	.0613	.0584	.0591	.0660	.0613	.0567

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

DAPODI SUB-DN.[593] BU 4593

Substation No/ Name :- 213359 / Swarganga

Feeder No / Name : 303 / YCM

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.249	.2942	.2112	.2112	.3433	.2934	.3056
2	.2263	.2867	.2075	.2037	.3169	.2565	.2678
3	.2226	.2716	.1979	.1962	.3018	.2603	.2427
4	.215	.2539	.1979	.1924	.3056	.2527	.239
5	.2054	.2614		.2112	.3131	.249	.2577
6	.2107	.2305	.2301	.2263	.3435	.2452	.2801
7	.2867	.3169	.2942	.2452	.3772	.3697	.3137
8	.3735	.4187	.4338	.2716	.4715	.4074	.4489
9	.3885	.4414	.4036	.2791	.4791	.4753	.4572
10	.5545	.4527	.4414	.2716	.5357	.4489	.5411
11	.5601	.4687	.4866	.2678	.4715	.4715	.5243
12	.5359	.4534	.4074			.4527	.5206
13	.4953	.4451	.4225	.2452	.4979	.415	.513
14	.5101	.4338	.3999	.2716	.4678	.4979	.5168
15	.5228	.4414	.3201	.2641	.4527	.4338	.5168
16	.4376	.3584	.3658	.2867	.4112	.3467	.43
17	.415	.4074	.3658	.2565	.3848	.3506	.4108
18	.4263	.3395	.3093	.2641	.3282	.301	.4414
19	.3506	.2829	.3735	.2641	.3471	.301	.3471
20	.3544	.3093	.3391	.2641	.3544	.2678	.3734
21	.3582	.2641	.3048	.2603	.3048	.2867	.2829
22	.3395	.2791	.2414	.2716	.3433	.298	.3093
23	.298	.2452	.2452	.3697	.3163	.2942	.2867
24	.2414	.2867	.2315	.2414	.3735	.2867	.3169
Max	.5601	.4687	.4866	.3697	.5357	.4979	.5411
Min	.2054	.2305	.1979	.1924	.3018	.2452	.239
Avg	.3657	.3435	.3231	.2537	.3844	.3443	.3810

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

DAPODI SUB-DN.[593] BU 4593

Substation No/ Name :- 213359 / Swarganga

Feeder No / Name : 304 / D Y PATIL

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5373	.5809	.5168	.5206	.5658	.5545	.5583
2	.4904	.5281	.5093	.5093	.513	.5508	.5206
3	.4715	.4866	.4979	.4979	.4942	.5319	.5055
4	.4527	.5394	.4904	.4904	.5243	.4979	.5168
5	.4979	.513	.4979	.5168	.5168	.5621	.5998
6	.513	.5432	.7167	.5583	.7507	.6149	.6073
7	.5658	.5847	.6979	.5696	.6375	.6639	.7658
8	.6602	.6602	.6828	.596	.7582	.762	.7884
9	.8789	.8789	.9186	.6564	.9544	.9091	1.011
10	1.1539	.9821	.9933	.7771		1.1315	1.1015
11	1.1763	1.1352	1.1315	.9373	1.124	1.18	1.192
12	1.1464	1.1088	1.053	.8514	1.0082	1.1165	1.1241
13	1.1315	1.0571	1.068	.8551	1.0269	1.0717	1.177
14	1.0866	1.0719	.9634	.8327	1.012	1.0269	1.1807
15	1.0754	1.012	.9373	.6941	1.0605	1.0717	1.1807
16	1.1053	1.068	.8978	.6752	.9074	.9933	1.0562
17	.8141	.7916	.7243	.6639	.7997	.7207	.8789
18	.8186	.8029	.7281	.6149	.9431	.8865	.9242
19	.7469	.6979	.8299	.679	.762	.6941	.7733
20	.7058	.7318	.7356	.6526	.7884	.7582	.8148
21	.713	.713	.7167	.6941	.7846	.7318	.7318
22	.7016	.6866	.679	.6526	.7771	.6903	.7469
23	.6715	.6111	.6488	.63	.6526	.6715	.713
24	.5696	.5923	.5696	.5658	.6073	.6375	.5923
Max	1.1763	1.1352	1.1315	.9373	1.124	1.18	1.192
Min	.4527	.4866	.4904	.4904	.4942	.4979	.5055
Avg	.7785	.7657	.7585	.6538	.7812	.7929	.8359

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

KHERALWADI SUB-DN.[594] BU 4594

Substation No/ Name :- 213015 / PIMPRI

Feeder No / Name : 303 / Pimprigaon Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0456	1.0829	1.0829	1.1949	1.1949	1.2567	1.2567
2	.9709	1.0082	1.0456	1.1203	1.1203	1.1827	1.1827
3	.9335	.9335	1.0082	1.0456	1.0829	1.0349	1.0349
4	.8962	.8962	.924	.9979	1.1203	1.0349	1.0349
5	.8589	.8962	.8871	.9979	1.1203	1.0349	1.0349
6	.9709	1.1576	.9709	1.0829	1.2323	1.1458	1.1458
7	1.1949	1.2323	1.1458	1.2071	1.2826	1.2936	1.2567
8	1.307	1.419	1.2936	1.39	1.358	1.3676	1.3817
9	1.2323	1.3443	1.1458	1.3306	1.2826	1.1458	1.2323
10	1.1088	1.2323	1.1458	1.1576		1.1088	1.1576
11	1.1088	1.1576	1.3306	1.307	1.1088	1.1088	1.2696
12	.9979	1.1949	1.3306	1.3817	1.2567	1.1827	
13	1.0185	1.2696	1.2567	1.3443	1.2567	1.1088	1.2323
14	.9054	1.2696	1.1827	1.307	1.1458	1.1827	1.1949
15	1.094	1.1576	1.1827	1.307	1.1458	1.1088	1.1203
16	1.1317	1.1576	1.2197	1.2696	1.1458	1.0349	1.1203
17	1.094	1.1576	1.2197	1.2323	1.1458	1.0608	1.1576
18	1.1694	1.419	1.2567	1.1949	1.1827	1.0974	1.1203
19	1.2449	1.419	1.4784	1.419	1.4784	1.2437	1.3817
20	1.4712	1.4563	1.5893	1.5684	1.5154	1.4632	1.5684
21	1.3957	1.419	1.4784	1.531	1.4415		1.5684
22	1.3957	1.307	1.3306	1.3817	1.4045	1.3169	1.3817
23	1.2936	1.2323	1.3676	1.3957	1.2936	1.3676	1.3817
24	1.1088	1.2567	1.1088	1.3817	1.3817	1.3676	1.2803
Max	1.4712	1.4563	1.5893	1.5684	1.5154	1.4632	1.5684
Min	.8589	.8962	.8871	.9979	1.0829	1.0349	1.0349
Avg	1.1229	1.2115	1.2076	1.2728	1.2477	1.1848	1.2389

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

KHERALWADI SUB-DN.[594] BU 4594

Substation No/ Name :- 213015 / PIMPRI

Feeder No / Name : 304 / Jawalkarwasti

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2449	1.6975	1.5466	1.6221	1.5466	1.6975	1.5684
2	1.2071	1.5089	1.5089	1.5466	1.5089	1.6598	1.531
3	1.1317	1.4712	1.4712	1.5089	1.5466	1.6598	1.4937
4	1.1317	1.3957	1.4335	1.4712	1.5844	1.8861	1.4937
5	1.1694	1.3957	1.3957	1.4335	1.6598	1.773	1.531
6	1.5844	1.2449	1.6975	1.6221	1.773	1.9616	1.9418
7	1.8861	1.9616	1.8861	1.773	1.9616	2.1502	2.1285
8	1.9993	1.9239	2.1879	2.037	1.8484	2.1879	2.1285
9	1.8861	1.8107	1.8861	1.9616	1.8484	2.037	2.0911
10	1.9239		1.9616	1.9616		1.8484	1.9044
11	1.8107	1.5844	1.7353	1.6221		1.9616	1.643
12	1.9993	1.5844	1.773	1.6221	1.4712		1.5844
13	1.7353	1.5089	1.6975	1.8484	1.4712	1.7924	1.9418
14	1.5844	1.5844	1.8107	1.6598	1.4335	1.7177	1.7551
15	1.6221	1.4712	1.6975	1.7353	1.5089	1.4563	1.5684
16	1.8861	1.9993	1.6975	1.8484	1.6221	1.3817	1.5089
17	1.9616	1.5089	1.773	1.7353	1.5844	1.3817	1.6598
18	1.773	1.773	1.7353	1.6598	1.6975	1.8671	1.773
19	1.5844	1.8484	2.037	1.8484	1.9239	2.0538	1.8484
20	2.2257	1.9616	2.037	2.2634	2.3011	2.1658	1.9616
21	2.1879	2.1502	2.1502	2.1502	2.3011		2.1502
22	2.1125	1.9993	1.9616		2.1125	2.2405	2.3765
23	2.0748	1.7353	1.8861	2.1879	1.9993	1.9044	2.1502
24	1.4712	1.9239	1.5844	1.773	1.6221	1.7353	1.6057
Max	2.2257	2.1502	2.1879	2.2634	2.3011	2.2405	2.3765
Min	1.1317	1.2449	1.3957	1.4335	1.4335	1.3817	1.4937
Avg	1.7164	1.6975	1.7730	1.7779	1.7421	1.8418	1.8058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

KHERALWADI SUB-DN.[594] BU 4594

Substation No/ Name :- 213015 / PIMPRI

Feeder No / Name : 306 / Waghere

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0562	1.094	1.0562	1.1694	1.1694	1.1576	1.1694
2	1.0185	1.0185	1.0185	1.094	1.0562	1.1576	1.1694
3	.9808	.9808	.9709	1.0562	1.0562	1.0829	1.094
4	.9431	.9808	.9431	1.0185	1.094	1.0829	1.094
5	1.0562	.9431	.9431	1.0185	1.1694	1.1317	1.1317
6	1.3203	1.3957	1.2449	1.2071	1.2071	1.3817	1.3957
7	1.3957	1.4335	1.358	1.3203	1.4712	1.531	5.168
8	1.4335	1.6598	1.3957	1.4335	1.5089	1.4563	1.4712
9	1.358	1.5089	1.4335	1.5089	1.3957	1.3443	1.4712
10	1.2826	1.2826	1.4335	1.4335		1.2323	1.3957
11	1.1317	1.2071	1.3203	1.358	1.2323	1.1576	1.094
12	.9054	1.094	1.094	1.3203	1.0829	1.0829	1.0562
13	.9054	1.0562	1.1317	1.2071	1.0082	1.1203	1.3203
14	.9054	1.0562	1.1317	1.1317	1.0829	1.0082	1.094
15	.8676	1.0562	1.1317	1.1317	1.0829	1.0082	1.0185
16	.9808	1.0562	1.0562	1.1317	1.0082	1.0456	.9808
17	1.0185	1.0829	1.094	1.094	1.0829	1.0562	1.0185
18		1.2323	1.2449	1.1317	1.1576	1.2071	1.0562
19	1.2826	1.4563	1.3957	1.358	.6348	1.358	1.4712
20	1.4712	1.419	1.5089	1.5844	1.4937	1.5466	1.4712
21	1.358	1.419	1.4335	1.4712	1.531		1.419
22	1.3957	1.3443	1.358	1.4335	1.419	1.4335	1.4335
23	1.3203	1.2323	1.3957	1.3817	1.1949	1.3957	1.358
24	1.094	1.2071	1.094	1.2449	1.2449		1.2449
Max	1.4712	1.6598	1.5089	1.5844	1.531	1.5466	5.168
Min	.8676	.9431	.9431	1.0185	.6348	1.0082	.9808
Avg	1.1514	1.2174	1.2162	1.2600	1.1906	1.2263	1.3999

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

KHERALWADI SUB-DN.[594] BU 4594

Substation No/ Name :- 213015 / PIMPRI

Feeder No / Name : 307 / GEC

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.6677	4.6677	4.5184	5.3026	5.2652	4.9665	4.9665
2	4.4063	4.5557	4.4063	5.0412	5.0412	4.8171	4.8171
3	4.3317	4.481	4.369	4.8544	4.7798	4.5931	4.5931
4	4.257	4.4437	4.2875	4.8171	4.7424	4.5931	4.6304
5	4.4437	4.369	4.4063	4.7798	4.8918	4.7798	4.6677
6	5.0785	5.3772	4.9291	5.2279		5.3772	5.3399
7	5.8627	5.8253	5.5639	5.655	5.676	5.9	5.8627
8	6.4602	6.3855	6.4602	6.4975	6.2734	6.4228	6.4228
9	5.9747	6.1988		6.6095	5.9747	6.1241	6.0867
10	5.8253	5.9747	6.012	4.9291		5.6013	5.7507
11	5.9374	6.1241	6.1988	7.2817	5.5266	5.5266	6.2361
12	5.6013	6.012	6.1988	6.9117		5.4146	5.9747
13	5.4146	5.7507	6.8709	6.6899	5.9747	5.3026	5.8253
14	5.3026	5.5266		6.3942	5.6013	5.1532	5.5639
15	5.2652	5.5266	5.0785	6.2464	5.7133	5.1532	5.3026
16	5.5639	5.7133		6.2094	5.9747	4.9291	5.1532
17	5.6386	5.676	7.0576	6.2094	5.9	5.1905	5.5639
18	6.1988	6.9456	7.2817	6.0246	6.2361	5.3772	5.7507
19			7.9912	6.9856	7.3564	6.1614	6.6469
20	7.6178	6.1614	8.5513	7.9096		6.7962	7.7671
21	7.3937	7.3937	8.0285	7.6509	7.7298		7.1696
22	6.5348	6.1988	6.9456	6.653	6.7962	6.0357	6.7589
23	5.676	5.2854	6.0494	6.5478	5.8627	5.9374	5.9747
24	4.8171	5.1158	4.8049	5.6013	5.5072	5.4146	5.4146
Max	7.6178	7.3937	8.5513	7.9096	7.7298	6.7962	7.7671
Min	4.257	4.369	4.2875	4.7798	4.7424	4.5931	4.5931
Avg	5.5769	5.6395	6.0005	6.1262	5.8412	5.4594	5.7600

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

KHERALWADI SUB-DN.[594] BU 4594

Substation No/ Name :- 213329 / EMPIRE SW STATION

Feeder No / Name : 301 / EMPIRE phase 1

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.5658	.5658	.6413	.6413	.6413	.6036
2	.4904	.5658	.4904	.6036	.5658	.6413	.5281
3	.4527	.5281	.4904	.5281	.5601	.5658	.4954
4	.4527	.6036	.4904	.6413	.5601	.5658	.5716
5	.5658	.6413	.4904	.5658	.6036	.6036	.6097
6	.6036	.679	.5281	.5281	.679	.6413	.6478
7	.7095	.679	.5658	.5658	.7545	.7545	.6478
8	.6722	.7545	.5658	.679	.7545	.7922	.724
9	.6722	.7167	.6036	.7167	.7468	.7922	.7545
10	.8299	.8676	.7922	.7545		.9054	.8299
11	.8676	.8676	.9431	.9054	.8299	.8676	
12	.8299	.7922	.8676	.7922	.8299	.8299	.8299
13	.7922	.8299	.8676	.7545	.7922	.8299	.8048
14	.7468	.7922	.8215	.7545	.7167	.8131	.7682
15	.7468	.7545	.7922	.7545	.7167	.7545	.8299
16	.7842	.8299	.8299	.8299	.7922	.7922	.9054
17	.7842	.8215	.8299	.7922	.7545	.8299	.7922
18	.7922	.8589	.8676	.7545	.8299	.8676	.8589
19	.8589	.8962	.9431	.8676	.924	.8589	.8962
20	.8962	.8589	.961	.9431	.924	.9335	1.0082
21	.7842	.7468	.8871	.8299	.8676	.8215	.8676
22	.7167	.7167	.724	.7922	.7167	.7621	
23	.6413	.6413	.724	.8299	.7922	.724	.7922
24	.5658	.6036	.6036	.679	.7545	.679	.6413
Max	.8962	.8962	.961	.9431	.924	.9335	1.0082
Min	.4527	.5281	.4904	.5281	.5601	.5658	.4954
Avg	.7009	.7338	.7185	.7293	.7438	.7611	.7458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

KHERALWADI SUB-DN.[594] BU 4594

Substation No/ Name :- 213329 / EMPIRE SW STATION

Feeder No / Name : 302 / EMPIRE phase 2

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6975	1.6126	1.4563	1.7718	1.4582	1.701	1.8099
2	1.6975	1.406	1.3226	1.5424	1.4083	1.5775	1.6289
3	1.5466	1.2548	1.4327	1.283	1.326	1.4419	1.5074
4	1.5466	1.2887	1.3672	1.3032	1.2929	1.4419	1.5424
5	1.5089	1.3375	1.3375	1.3032	1.2631	1.4419	1.5074
6	1.4937	1.3375	1.2742	1.2407	1.2803	1.3592	1.5074
7	1.4217	1.406	1.5043	1.2742	1.5089	1.5604	1.6655
8	1.7684	1.885	1.7193	1.3565	1.9387	1.9959	2.0553
9	2.1879	2.5393	2.2779	1.9547	2.452	2.5766	2.6029
10	3.3951	3.2442	3.5848	2.7721		3.3981	3.4328
11	4.5268	4.6022	5.0549	4.0009	4.7154		
12	5.1303	5.0549	5.2812	4.4963	5.2435	5.2058	5.168
13	5.0172	5.0172	5.2435	4.4513	5.1303	5.2812	5.2058
14	4.904	5.0172	5.4698	4.3759	5.1303	4.1118	5.1303
15	5.0549	5.2812	5.3944	4.5268	4.9794	4.904	5.3189
16	4.904	5.2435	5.3944	4.5268	5.2058	5.168	5.2435
17	4.9794	5.168	5.168	4.2676	4.9417	4.904	2.452
18	4.6399	4.904	4.6399	4.2676	4.7908	4.7531	4.7531
19	4.5268	3.0178	4.7531	4.4136	4.8663	4.6776	4.7154
20	4.3004	4.2627	4.8285	4.5645	4.8663	4.6022	4.8663
21	3.8477	3.8855	4.3759	4.3439	4.3759	4.225	4.1152
22	2.7161	2.8292	3.3196	3.1687	3.0556	3.0556	2.9424
23	2.0165	2.2405	2.3388	2.2779	2.6029	2.4143	2.4272
24	1.8107	1.829	1.7193	1.9185	1.6297	1.7909	1.9589
Max	5.1303	5.2812	5.4698	4.5645	5.2435	5.2812	5.3189
Min	1.4217	1.2548	1.2742	1.2407	1.2631	1.3592	1.5074
Avg	3.1933	3.1527	3.3441	2.9751	3.2810	3.1995	3.1981

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

KHERALWADI SUB-DN.[594] BU 4594

Substation No/ Name :- 213341 / 22KV MAHINDRA ROYALE

Feeder No / Name : 301 / Mahindra Royal ph I

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2641	.2641	.3018	.3018	.2641	.2641
2	.2241	.2641	.2641	.2641	.2561	.2641	.2641
3	.2241	.2263	.2263	.2641	.2641	.2641	.2641
4	.2241	.2641	.2641	.2641	.2641	.2263	.2263
5	.2614	.2641	.2641	.3018	.3018	.2641	.2263
6	.3018	.2641	.2263	.2263	.3018	.3018	.3018
7	.3018	.3018	.2641	.2241	.3018	.2641	.3018
8	.2641	.3018	.2641	.2614	.2561	.3018	.2641
9	.2641	.3018	.2641	.3018	.2641	.2641	.3018
10	.2641	.2641	.2641	.3018	.2641	.2263	.2641
11	.2263	.2263	.2263	.2641	.2263	.1886	.2263
12	.2263	.2263	.2263	.3018	.1886	.2263	.2263
13	.2263	.2263	.2641	.2641	.2263	.2263	.2263
14	.2263	.2263	.2641	.3018	.2263		.2263
15	.2263	.2263	.2263	.3018	.1886	.1867	.2263
16	.1886	.2641	.3018	.3018	.2263	.2263	.2263
17	.1886	.2263	.2641	.2641	.1886	.2263	.1886
18	.2263	.2641	.2641	.2641	.2641	.2641	.2641
19	.2641	.2641	.3018	.2641	.3018	.2614	.2641
20	.3395	.3018	.3018	.3395	.3395	.2987	.3018
21	.3395	.3018	.3772	.3395	.3018	.3018	.3395
22	.3018	.2641	.3018	.3395	.3018	.3395	.3395
23	.3018	.2641	.3395	.3395	.3395	.3395	.3018
24	.2241	.3018	.2641	.3018	.3018	.3018	.2641
Max	.3395	.3018	.3772	.3395	.3395	.3395	.3395
Min	.1886	.2263	.2263	.2241	.1886	.1867	.1886
Avg	.2525	.2625	.2704	.2875	.2665	.2621	.2625

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

KHERALWADI SUB-DN.[594] BU 4594

Substation No/ Name :- 213341 / 22KV MAHINDRA ROYALE

Feeder No / Name : 302 / Mahindra Royal ph II

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6722	.7468	.7095	.7842	.7545	.7545	.7545
2	.6348	.7095	.6722	.7095	.6413	.7167	.7167
3	.6348	.6722	.6348	.7095	.679	.679	.679
4	.5914	.6722	.6348	.6722	.7167	.6413	.679
5	.6653	.7095	.6722	.7095	.7922	.7167	.7545
6	.7762	.8215	.7468	.8589	.8676	.8299	.7922
7	.8501	.8962	.7842	.7602	.9431	.9054	.9054
8	.9335	.8962	.8589	.7682	.9431	.9145	.9431
9	.9808	.9808	1.0185	.8589	.9054	.9808	1.094
10	.9431	1.094	1.0185	.9335	1.0562	1.0185	1.094
11	.9808	1.0829	.9808	.9335	1.0562	.9431	1.094
12		1.0456	1.0562	.8589	1.0082	.9431	1.0185
13		1.0082	.9808	.8589	.9979	.9808	1.0185
14		.9709	1.0562	.7842	.9709		1.0185
15		.9431	.9431	.8299	.9335	.9431	.9808
16	1.3443	1.094	.9335	.8299	.8962	.9431	1.0082
17	1.2323	1.0185	.9709	.8299	.9709	.9979	1.0082
18	1.1203	1.0562	.9709	.8676	.9335	.961	.924
19	1.0242	.9431	.9335		.9808	.9335	.924
20	1.1088	.9808	1.0456	1.0562	1.0562	1.0829	1.0456
21	1.0349	.9808	1.0456	1.0185	1.0185	1.0456	1.0082
22	.9979	.8962	.9335	.9808	.9808	.9808	.9431
23	.8962	.8215	.961	.9431	.9054	.9431	.9431
24	.7095	.7842	.7095	.8299	.9054	.8299	.7922
Max	1.3443	1.094	1.0562	1.0562	1.0562	1.0829	1.094
Min	.5914	.6722	.6348	.6722	.6413	.6413	.679
Avg	.9066	.9094	.8863	.8429	.9131	.8994	.9225

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

KHERALWADI SUB-DN.[594] BU 4594

Substation No/ Name :- 213341 / 22KV MAHINDRA ROYALE

Feeder No / Name : 304 / Masulkar colony

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4937	1.4937	1.4937	1.5684	1.3203	1.7353	1.7177
2	1.419	1.4563	1.4563	1.4784	1.2826	1.6598	1.5684
3	1.419	1.4563	1.4563	1.5154	1.1694	1.773	1.6057
4	1.4937	1.3817	1.3306	1.4415	1.1317	1.7353	1.4746
5	1.6057	1.4784	1.4045	1.3535	1.2071	1.773	1.7002
6	1.7558	1.7372	1.5154	1.5927	1.3203	1.8107	1.8111
7	1.6827	1.6632	1.4784	1.267	1.3957	1.773	1.6632
8	2.0119	2.1068	1.885	1.2803	2.0119	2.1879	1.9753
9	2.037	1.9589	1.9239	1.2936	2.0698	2.1502	1.7924
10	2.1502	2.2405	2.1502	1.4937	2.0553	2.1879	2.037
11	1.9239	1.9387	1.8107	1.531	1.829	2.1879	1.8861
12	1.9239	1.97	1.9239	1.4937	1.8781	2.1502	1.9993
13	1.8861	1.949	1.9993	1.5684	1.893	2.1879	1.9993
14	1.8107	1.893	2.1125	1.419	1.9136		1.9993
15	1.7741	1.9239	1.8107	1.3957	1.6827	1.9418	1.922
16	1.5524	1.6975	1.5684	1.358	1.7375	1.7177	1.7002
17	1.848	2.0748	1.7193	1.358	1.9136	1.8671	1.8378
18	1.9959	2.2634	1.8427	1.4335	1.9631	2.0538	2.1033
19	1.9631	2.1502	1.9909	1.5466	2.0058	2.1285	2.1845
20	1.7718	1.9239	1.8111	1.6221	2.0119	2.0165	2.0774
21	2.0774	1.9993	1.9909	1.6221	2.1132	2.2405	2.2916
22	1.9547	1.922	2.0271	1.5466	2.0851	2.1948	2.0851
23	1.885	1.7741		1.4712	1.9993	2.1216	1.885
24	1.5684	1.5684	1.5154	1.6057	1.3957	1.8484	1.6804
Max	2.1502	2.2634	2.1502	1.6221	2.1132	2.2405	2.2916
Min	1.419	1.3817	1.3306	1.267	1.1317	1.6598	1.4746
Avg	1.7918	1.8342	1.7486	1.4690	1.7244	1.9758	1.8749

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

KHERALWADI SUB-DN.[594] BU 4594

Substation No/ Name :- 213341 / 22KV MAHINDRA ROYALE

Feeder No / Name : 305 / PMT KSB

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0698	2.1125	2.1879	1.9239	1.5466	2.2634	2.3388
2	2.1437	2.037	2.1502	1.8861	1.4335	2.1879	2.2634
3	2.0119	1.9616	2.1125	2.037	1.3957	2.3011	2.3011
4	2.0119	1.9239	2.0748	1.9616	1.5089	2.2257	2.2634
5	1.9753	1.8861	2.1125	2.037	1.5844	2.1502	2.2257
6	2.0165	1.8861	2.1502	2.0748	1.6461	2.1879	2.1502
7	1.7528	1.9239	1.9993	1.4586	1.7353	2.1125	1.8461
8	2.3655	2.7538	2.6406	1.8671	2.6703	2.9801	2.8669
9	3.0556	3.0933	3.4328	2.037	3.1687	3.4328	3.4328
10	3.1687	3.3196	3.546	2.2257	3.546	3.6214	3.9609
11	3.6969	3.6969	3.3573	2.037	3.7723	3.8855	3.9609
12		3.131	3.131	1.8484	3.1687	3.3951	3.3951
13		3.0178	3.2065	1.773	3.0556	3.0178	3.3196
14		3.1687	2.3011	1.8861	3.4705		3.1687
15		3.4328	3.2819	1.8861	3.546	3.6214	3.2442
16	2.4143	3.4328	2.7538	1.8484	3.0556	3.5837	3.0933
17	2.6406	3.3951	3.0556	2.0748	3.0178	3.3573	3.0556
18	2.452	2.4897	2.9424	1.7353	2.7915	2.6406	2.6783
19	2.452	2.8669	2.6783		2.6783	2.7915	2.6783
20	2.4897	2.6406	2.5652	1.8484	2.8292	2.7538	2.6029
21	2.1502	2.1502	2.2634	1.5844	2.452	2.3765	2.4143
22	2.4897	2.6406	2.5274	1.5844	2.452	2.5274	2.5274
23	2.452	2.3388	2.0748	1.6095	2.3765	2.3011	2.3011
24	2.3152	2.1125	2.1879	2.1502	1.5844	2.4143	2.1879
Max	3.6969	3.6969	3.546	2.2257	3.7723	3.8855	3.9609
Min	1.7528	1.8861	1.9993	1.4586	1.3957	2.1125	1.8461
Avg	2.4062	2.6422	2.6139	1.8859	2.5202	2.7882	2.7615

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

SANGHVI SUB-DN.[636] BU 4636

Substation No/ Name :- 213212 / 22/11 HINJWADI SUB STATION

Feeder No / Name : 201 / 11 KV RMU-2 FEEDER

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.2096	.2096	.2096	.2096	.2096	.1905
2	.1905	.2096	.2096	.2096	.2096	.2096	.1905
3	.1524	.1905	.2096	.2096	.2096	.2096	.1905
4	.1524	.1905	.2096	.2096	.2096	.2096	.1905
5	.1524	.2096	.2286	.2286	.2096	.2096	.1905
6	.1524	.2286	.2286	.2286	.2286	.2286	.1905
7	.1524	.2286	.2286	.2286	.2286	.2286	.2096
8	.1524	.2286	.2286	.2286	.2286	.2286	.1905
9	.2096	.2096	.2286	.2286		.2286	.1905
10	.2096	.2096	.2096	.2286	.2286	.1905	.1905
11	.2096	.2096	.2096		.2286	.1905	.1905
12		.2286	.2286	.2286	.2286	.1905	.1905
13	.2096	.2286	.2286	.2286	.2286	.1905	.2096
14	.2096	.2286	.2286	.2286	.2286	.1905	.1905
15	.2096	.2096	.2286	.2286	.2286	.1905	.1905
16	.2096	.2096	.2286	.2286	.2096	.1905	.1905
17	.2096	.2096	.2286	.2286	.2096	.1905	.2096
18	.2096	.2286	.2286	.2286	.2286	.2096	.1905
19	.2096	.1524	.2096	.2096	.2286	.1905	.1905
20	.2096	.1524	.2096	.2096	.2096	.1905	.1905
21	.2096	.1524	.2096	.2096	.2096	.1905	.1905
22	.2096	.2286	.2096	.2096	.2096	.1905	.1905
23	.2096	.2286	.2096	.2096	.2096	.1905	.1905
24	.2096	.2096	.2286	.2096	.2096	.2096	.1905
Max	.2096	.2286	.2286	.2286	.2286	.2286	.2096
Min	.1524	.1524	.2096	.2096	.2096	.1905	.1905
Avg	.1938	.2080	.2199	.2203	.2187	.2024	.1929

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

SANGHVI SUB-DN.[636] BU 4636

Substation No/ Name :- 213212 / 22/11 HINJWADI SUB STATION

Feeder No / Name : 202 / 11 KV GINOVA BIO FEEDER HV Express Feeder
Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7909	1.8099	1.829	1.7528	1.7147	1.829	1.829
2	1.7528	1.7909	1.7909	1.7528	1.7718	1.829	1.829
3	1.7528	1.7528	1.7909	1.7147	1.7337	1.8671	1.8671
4	1.7909	1.7528	1.7528	1.7147	1.7337	1.8099	1.8671
5	1.829	1.7909	1.8099	1.7147	1.7528	1.8099	1.829
6	1.8671	1.829	1.8671	1.7337	1.7147	1.8671	1.8671
7	1.8861	1.9243	1.9052	1.7909	1.829	1.8671	1.829
8	2.0005	2.0005	2.0386	1.848	1.9243	1.9243	1.9624
9	2.1338	2.1148	2.191	1.8671		2.1529	2.0386
10	2.1529	2.2291	2.2291	1.9624	2.21	2.191	2.191
11	2.2291	2.191	2.2481		2.1338	2.2862	2.0767
12	2.1148	2.1719	2.2481	1.9243	2.1148	2.0576	2.0576
13	2.0195	2.1148	2.0576	1.9052	2.0957	2.1148	2.1148
14	2.1719	2.1148	2.21	1.9433	2.1719	2.2291	2.1719
15	2.1719	2.2291	2.191	1.8671	2.1338	2.1719	2.191
16	2.0767	2.0957	2.0386		2.2291	2.1338	2.191
17	2.0386	2.1338	2.1529	1.7909	2.2291	2.1719	2.1719
18	2.0195	2.0005	1.9624	1.7528	2.0005	2.0195	2.0195
19	1.9624	1.8861	1.829	1.7909	2.0005	1.9433	1.9814
20	1.9814	1.829	1.9052	1.7909	2.0195	1.9624	1.8861
21	2.0005	1.7337	1.8861	1.7909	1.9624	1.848	1.9433
22	1.9243	1.8099	1.8671	1.7718	1.9243	1.8099	1.829
23	1.8861	1.8099	1.848	1.7528	1.8861	1.8099	1.8099
24	1.8099	1.848	1.848	1.8099	1.7528	1.848	1.848
Max	2.2291	2.2291	2.2481	1.9624	2.2291	2.2862	2.191
Min	1.7528	1.7337	1.7528	1.7147	1.7147	1.8099	1.8099
Avg	1.9735	1.9568	1.9790	1.8065	1.9582	1.9814	1.9751

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

SANGHVI SUB-DN.[636] BU 4636

Substation No/ Name :- 213212 / 22/11 HINJWADI SUB STATION

Feeder No / Name : 203 / 11 KV RMU I FEEDER SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4098	1.5051	1.3908	1.105	.6478	1.2765	1.2384
2	1.4098	1.448	1.3336	1.0479	.7049	1.2765	1.2384
3	1.3717	1.4098	1.2955	1.0288	.6478	1.2003	1.2765
4	1.3717	1.3717	1.1812	1.0288	.7049	1.2193	1.2003
5	1.448	1.4098	1.1812	1.0669	.8192	1.2193	1.2193
6	1.5051	1.467	1.1431	1.0669	1.0288	1.2003	1.1431
7	1.5051	1.5242	1.3717	.6859	1.2765	1.3336	1.2193
8	1.6766	1.6575	1.4289	.6668	1.6766	1.7528	1.5051
9	1.7718	1.9052	1.6575	.7049		1.9624	1.9052
10	2.0195	2.1529	1.6194	.7811	2.0005	2.0576	1.9624
11	2.0195	2.0195	1.7147		2.0957	2.0386	2.0576
12	2.0386	1.9624	1.6956	.7049	1.9624	1.8861	1.9052
13	2.21	1.9433	1.6194	.7811	2.0195	1.8099	1.9433
14	1.9814	1.9052	1.7147	.743	1.9433	1.9624	1.9814
15	2.0576	1.9814	1.6575	.743	1.9433	2.0767	2.0576
16	1.9624	1.7718	1.6956	.743	1.9624	1.9052	2.0386
17	1.8671	1.848	1.6004	.724	1.9052	1.6194	1.9052
18	1.8671	1.9052	1.467	.7049	1.7337	1.7718	1.7337
19	1.7528	1.5813	1.467	.4954	1.6575	1.6956	1.7528
20	1.9052	1.5623	1.2955	.6859	1.7718	1.6575	1.7528
21	1.7337	1.467	1.2765	.6478	1.6956	1.467	1.6194
22	1.6194	1.4098	1.2574	.6859	1.448	1.6004	1.3908
23	1.3336	1.448	1.2003	.6859	1.5623	1.4289	1.2955
24	1.448	1.5051	1.3908	1.1241	.6668	1.2193	1.3146
Max	2.21	2.1529	1.7147	1.1241	2.0957	2.0767	2.0576
Min	1.3336	1.3717	1.1431	.4954	.6478	1.2003	1.1431
Avg	1.7202	1.6734	1.4440	.8110	1.4728	1.6099	1.6107

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

SANGHVI SUB-DN.[636] BU 4636

Substation No/ Name :- 213212 / 22/11 HINJWADI SUB STATION

Feeder No / Name : 204 / 11 KV RMU III & IV FEEDER SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7909	1.7528	1.829	1.2193	1.6385	1.7909	1.7147
2	1.7147	1.7147	1.7147	1.1812	1.5623	1.829	1.6385
3	1.5242	1.6004	1.4861	1.1431	1.5813	1.7718	1.7528
4	1.5242	1.5623	1.4289	1.1431	1.5242	1.7147	1.6575
5	1.4861	1.5623	1.3717	1.1812	1.2765	1.6385	1.5813
6	1.4861	1.5432	1.3336	1.1812	1.086	1.448	1.4861
7	1.9243	1.3527	1.8099	1.1812	2.0957	1.6956	1.448
8	2.4387	2.4387	2.1338	1.2574	2.4958	2.4768	2.4577
9	2.8006	2.7816	2.6292	1.2384		2.8197	2.8959
10	2.7816	2.8578	2.4768	1.3336	2.9721	3.0864	3.0102
11	2.915	2.8578	2.5339		3.1436	3.1245	3.3722
12	2.915	2.4958	2.6482		2.9721	2.4196	3.1817
13	2.3815	2.3434	1.9814	1.2574	2.6863	2.4768	2.5149
14	2.4577	2.4577	2.0957	1.2384	2.572	2.4196	1.9814
15	2.3434	2.3434	1.848	1.2384	2.4958	2.4768	2.4768
16	2.191	2.1148	1.5432	1.2003	2.2291	2.0576	2.2862
17	1.8861	1.848	1.4098	1.1812	1.9243	2.0195	2.0767
18	1.7147	1.6766	1.2384	1.2193	1.7909	1.7909	1.848
19	1.6004	1.4861	1.1431	1.1622	1.6766	1.7337	1.7337
20	1.5432		1.1241	1.1241	1.6575	1.6385	1.6766
21	1.2955	1.2765	1.2193	1.2003	1.4861	1.4289	1.5432
22	1.3146	1.2384	1.1622	1.1431	1.3146	1.3908	1.3717
23	1.848	1.8861	1.2193	1.6956	1.8671	1.7337	1.848
24	1.8861	1.848	1.8099	1.2193	1.7337	1.848	1.8099
Max	2.915	2.8578	2.6482	1.6956	3.1436	3.1245	3.3722
Min	1.2955	1.2384	1.1241	1.1241	1.086	1.3908	1.3717
Avg	1.9902	1.9582	1.7163	1.2245	1.9905	2.0346	2.0568

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

SANGHVI SUB-DN.[636] BU 4636

Substation No/ Name :- 213212 / 22/11 HINJWADI SUB STATION

Feeder No / Name : 205 / 22 KV L & T FEEDER(PHASE- HV Non-Express Feeder
II) Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6859	.6097	.6097	.6478	.6097	.6097
2	.5716	.6097	.5716	.5335	.6478	.6097	.5335
3	.5716	.6097	.5716	.5335	.6097	.5335	.5335
4	.5716	.5716	.5716	.5335	.6097	.5335	.5716
5	.6097	.6097	.6097	.5716	.6478	.5716	.5716
6	.6097	.6478	.6097	.5716	.6097	.5716	.5335
7	.6859	.7621	.6097	.5716	.6097	.8002	.724
8	.9145	.9526	.6097	.5716	.9907	.9526	.9145
9	1.0288	.9907	.8383	.5716		.9526	.9526
10	1.3336	1.2193	.8764	.6097	1.1812	1.2193	1.2955
11	1.1812	1.1812	.8383	.6097	1.2955	1.2193	1.2193
12	1.3336	1.2193	.8002	.6097	1.2193	1.1812	1.2193
13	1.3336	1.1812	.7621	.6097	1.2955	1.2193	1.2955
14	1.3336	1.2193	.8002	.5716	1.1812	1.2574	1.1812
15	1.1812	1.2193	.6859	.6478	1.2193	1.2574	1.2574
16	1.1812	1.105	.6097	.724	1.2193	1.1812	1.1812
17	1.1431	1.0669	.6097	.6097	1.2574	1.1431	1.2193
18	1.1431	1.0288	.6097	.6097	1.1812	1.105	1.0288
19	1.0288		.5716	.6097	1.105	1.0669	1.0669
20	.9145	.381	.6097	.6478	.9907	.9145	.8764
21	.7621	.381	.6097	.6478	.8383	.8383	.8383
22	.7621	.4572	.6478	.5716	.7621	.7621	.7621
23	.724		.6097	.6097	.6097	.6097	.724
24	.6478	.6859	.6097	.6097	.6097	.6097	.6097
Max	1.3336	1.2193	.8764	.724	1.2955	1.2574	1.2955
Min	.5716	.381	.5716	.5335	.6097	.5335	.5335
Avg	.9240	.8539	.6605	.5986	.9278	.9050	.9050

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

SANGHVI SUB-DN.[636] BU 4636

Substation No/ Name :- 213357 / 22/22 KV PWD SWITCHING

Feeder No / Name : 301 / 22 KV NAVI SANGAVI FEEDERi Urban/Sheddable Urban Feeder
Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.679	.6413	2.2634	.7167	.679	.7167	.7167
2	.6413	.6036	2.2257	.679	.6413	.679	.679
3	.6036	.5658	2.1879	.679	.679	.679	.6413
4	.6036	.5658	.4904	.6036	.679	.6413	.6413
5	.679	.6413	.5658	.6036	.8299	.7545	.7545
6	.7545	.7545	.7167	.679	.8676	.8676	.8676
7	.9054	.9808	.8676	.7922	1.0185	1.0185	1.0185
8	1.0562		1.0185	.9054	1.0562	1.0185	1.0185
9	.8676	.9054	.9054	.9431	.9431	.8676	.8676
10	.7922	.9054	.8676	.9054	.8299	.8299	.8299
11	.7922	.8299	.8299	.9054	.8299	.7922	.7922
12	.7167	.7545	.7922	.8676	.7545	.7922	.7545
13	.7545	.7545	.7545	.7545	.7167	.6036	.7167
14	.7167	.7167	.7545	.7922	.679	.7167	.7167
15	.7167	.6413	.7167	.7922	.679	.679	.679
16	.679	.679	.7167	.7922	.6413	.679	.6413
17	.6413	.679	.7167	.7922	.6413	.679	.679
18	.679	.7167	.7922		.6413	.679	.7167
19	.8676		.8676		.7545	.8676	.9054
20	.9431		.9808	1.094	1.0185	.9808	1.0185
21		.9808	.9431	1.0562	.9808	.9808	.9808
22		.8676	.9054	.9808	.9808	.9808	.9808
23	.8676	.7545	.8299	.9054	.9054	.9054	.8676
24	.7167	.7167	.679	.8676		.7922	.7545
Max	1.0562	.9808	2.2634	1.094	1.0562	1.0185	1.0185
Min	.6036	.5658	.4904	.6036	.6413	.6036	.6413
Avg	.7579	.7455	.9745	.8231	.8020	.8000	.8016

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

SANGHVI SUB-DN.[636] BU 4636

Substation No/ Name :- 213357 / 22/22 KV PWD SWITCHING

Feeder No / Name : 302 / 22 KV SHITOLE NAGAR FEEDER Urban/Sheddable Urban Feeder
Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5466	1.6221	1.6221	1.6598	1.6598	1.7353	1.8861
2	1.5089	1.5466	1.5089	1.6221	1.6598	1.6975	1.8107
3	1.4712	1.4712	1.4712	1.5844	1.7353	1.6598	1.773
4	1.5089	1.4712	1.4712	1.5844	1.6598	1.7353	1.8484
5	1.6221	1.5844	1.5466	1.5844	1.8107	1.8861	1.8861
6	1.8107	1.8107	1.6975	1.6598	2.0748	2.037	1.9993
7	2.3011	2.3011	2.1502	2.1502	2.3765	2.3765	2.3011
8	2.5274		2.5652	2.452	2.6783	2.7915	2.6029
9	2.3765	2.5652	2.4897	2.4897	2.4143	2.5274	2.4897
10	2.1502	2.1502	2.1502	2.3011	2.1502	2.1879	2.0748
11	1.9239	1.8484	2.0748	2.1502	2.037	1.9616	1.8484
12	1.8484	1.9616	2.1125	1.9993	1.8484	1.8107	1.773
13	1.773	1.8861	1.8484	1.9239	1.773	1.773	1.6975
14	1.7353	1.773	1.8107	1.8861	1.8107	1.6975	1.6598
15	1.6598	1.6975	1.6975	1.8484	1.6975	1.7353	1.6598
16	1.6598	1.6975	1.6975	1.8484	1.6975	1.6975	1.5844
17	1.6975	1.6221	1.6598		1.6975	1.7353	1.5844
18	1.8484	1.8861	1.8484		1.8107	1.8107	1.773
19	2.2257		2.2257		2.2634	2.2634	2.1879
20	2.6029		2.6783	3.131	2.6783	2.6783	2.6406
21	2.4897	1.773	2.6406	2.8669	2.6406	2.6406	2.7161
22	2.2634	2.4897	2.4897	2.7538	2.452	2.5652	2.6406
23	2.037	2.037	2.1502	2.2634	2.2257	2.1879	2.3011
24	1.6598	1.8107	1.8107	1.8107	1.9616	1.9239	1.9239
Max	2.6029	2.5652	2.6783	3.131	2.6783	2.7915	2.7161
Min	1.4712	1.4712	1.4712	1.5844	1.6598	1.6598	1.5844
Avg	1.9270	1.8574	1.9757	2.0748	2.0339	2.0465	2.0276

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

SANGHVI SUB-DN.[636] BU 4636

Substation No/ Name :- 213357 / 22/22 KV PWD SWITCHING

Feeder No / Name : 303 / 22 ANAND NAGAR FEEDER Urban/Sheddable Urban Feeder
Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6406	2.6783	2.6029	2.6406	2.7161	2.7161	2.8669
2	2.5652	2.5652	2.452	2.4897	2.6406	2.6406	2.8292
3	2.4897	2.4897	2.2634	2.4897	2.6406	2.5652	2.7915
4	2.5274	2.4897	2.1502	2.5652	2.5652	2.5652	2.8669
5	2.6783	2.6029	2.2634	2.5274	2.9424	2.7538	3.0178
6	3.0933	3.131	2.452	2.5652	3.1687	3.2819	3.2442
7	3.3196	3.4328	2.9047	3.2065	3.3951	3.4328	3.3951
8	3.6591		3.546	3.5837	3.6591	3.6591	3.5082
9	3.5837	3.6969	3.6214	3.5082	3.5837	3.6214	3.4328
10	3.131	3.3951	3.3951	3.3196	3.4328	3.3573	3.1687
11	1.2449	3.3573	3.3196	3.2442	3.2819	3.2065	2.9801
12	1.1694	3.0933	3.2065	2.7915	3.0556	3.0556	2.9424
13	1.1694	2.8292	2.8292	2.5652	2.8292	2.7538	2.7915
14	1.1317	2.7538	2.7915	2.452	2.7538	2.6783	2.6783
15	1.1317	2.6406	2.7161	2.6406	2.6029	2.5652	2.6406
16	1.1317	2.7915	2.5274	2.6406	2.7161	2.6783	2.6406
17	2.7161	2.6783	2.8292	2.7538	2.7161	2.4897	2.5274
18	3.7346	2.5274	2.7915	2.9801	2.7915	2.7915	2.9047
19	3.3196		3.2819	3.2065	3.3196	3.0556	3.3951
20	.7545		3.6591	3.9232	3.81	3.8855	3.8855
21	3.6969	3.6969	3.6969	3.7723	3.6214	3.81	3.6591
22	3.3951	3.1687	3.546	3.5082	3.546		3.5837
23	3.1687	2.9047	3.2819	3.2819	3.3196	3.3951	3.3196
24	2.7915	2.9424	2.7538	2.7161	2.8669	2.9801	2.9424
Max	3.7346	3.6969	3.6969	3.9232	3.81	3.8855	3.8855
Min	.7545	2.4897	2.1502	2.452	2.5652	2.4897	2.5274
Avg	2.5102	2.9460	2.9534	2.9738	3.0823	3.0408	3.0838

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

SANGHVI SUB-DN.[636] BU 4636

Substation No/ Name :- 213358 / 22/22 KV ADITYA BIRLA

SWITCHIN

Feeder No / Name : 301 / 22 KV PRASUNDHAM FEEDER Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.415	.4527	.4572	.4527	.4527	.4904
2		.415	.4527		.4527	.4527	.4904
3		.415	.4527			.4527	.4904
4		.415	.4527	.4572		.4527	.4904
5		.5281	.4527	.4954	.4527	.4904	.4904
6	.5658	.6036	.4904	.4954	.5281	.6036	.6036
7	.679	.7167	.5281	.4954	.724	.7167	.7167
8	.7167	.7545	.6413	.6097	.6413	.6036	.679
9	.6097	.6478	.6097	.6478	.6478	.6097	.5716
10	.5716	.5716	.5716	.6478	.5716	.5716	.5335
11	.5716	.5716	.5335		.4954	.4572	
12	.5335	.4191					
13		.381	.5335	.4954	.4191	.381	.4191
14	.4191	.4191	.5716	.4572	.381	.381	.4191
15	.4191	.4191	.4191	.5335	.4191	.381	.3772
16	.4191	.4191	.4572	.4954	.415	.3772	
17		.4572	.5335	.5335	.3772	.4527	.415
18	.4954	.5716	.4954	.5335	.4527	.4904	.4527
19	.6478	.5716	.6097	.6097	.6036	.5658	.5658
20	.6859	.6859	.6859	.724	.679	.6036	.6036
21	.6859	.6478	.6478	.6478	.6036	.6413	.6413
22	.6413	.6413	.6478	.6413	.6413	.679	
23	.6413	.6036	.5716	.5658	.6036	.5658	.5716
24	.5281	.4904	.4904	.5335	.4904	.5281	.4904
Max	.7167	.7545	.6859	.724	.724	.7167	.7167
Min	.4191	.381	.4191	.4572	.3772	.3772	.3772
Avg	.5783	.5325	.5349	.5538	.5263	.5178	.5256

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

SANGHVI SUB-DN.[636] BU 4636

Substation No/ Name :- 213358 / 22/22 KV ADITYA BIRLA

SWITCHIN

Feeder No / Name : 302 / 22 KV DATTA NAGAR FEEDER Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.2634	2.9801	3.4675	3.3573	3.2442	3.2065
2		2.2634	2.9424		3.2819	3.2442	3.2065
3		2.2634	2.7915	3.315		3.1687	3.1687
4		2.2634	2.7915			3.2442	3.1687
5		2.2634	2.8669	3.2769	3.3196	3.3196	3.2442
6	2.5274	2.5652	3.1687	3.4294	3.5837	3.5837	3.546
7	3.0178	2.7915	3.4705	3.5437	2.5652	3.8477	3.7723
8	3.0556	2.2634	3.6969	4.0009	4.1495	3.9609	4.1118
9	3.0864	1.9814	4.3058	4.3058	4.4201	4.3058	4.3058
10	3.0102	3.3913	4.5344	4.4201	4.3439	4.4201	4.4582
11	2.934		4.6106		4.4963	4.3058	
12		3.2388		4.4582			
13		2.934	4.2676	4.3058		4.0009	4.0771
14		3.0483	4.2676	4.2295	3.8485	4.0009	3.9628
15		3.2007	4.1152	3.9247	3.8485	4.0009	4.0364
16		3.2007	4.3058	4.0009	3.7346	3.8855	
17		3.2769	4.3439	3.9628	3.7723	3.81	4.3004
18	3.0102	2.9721	4.3058	3.7723	3.6969	3.8477	4.0741
19	3.2007	1.5242	4.3439	4.1152	3.9609	3.7723	4.1495
20	3.3913	1.6766	4.8011	4.4201	4.0364	4.4136	4.4136
21	3.3532	2.8578	4.4582	4.4963	3.9232	4.3004	4.3381
22	3.131	3.7723	4.382	4.1118	3.7346	4.1118	
23	2.8669	3.5082	4.0771	3.8855	3.7723	3.6591	3.8104
24	2.3765	2.5274	3.2065	3.658	3.5082	3.3573	3.3573
Max	3.3913	3.7723	4.8011	4.4963	4.4963	4.4201	4.4582
Min	2.3765	1.5242	2.7915	3.2769	2.5652	3.1687	3.1687
Avg	2.9970	2.6977	3.8710	3.9572	3.7677	3.8176	3.8354

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

SANGHVI SUB-DN.[636] BU 4636

Substation No/ Name :- 213358 / 22/22 KV ADITYA BIRLA

SWITCHIN

Feeder No / Name : 303 / 22 KV ADITYA BIRLA FEEDER

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4572	.4191	.4191	.4191	.6859	.4191
2		.4191	.4191		.381	.4191	.381
3		.4191	.4572			.4191	.381
4		.4191	.6478	.5335		.4572	.381
5		.4191	.4954	.6097	.6478	.6478	.381
6	.381	.4191	.4527	.381	.6478	.6413	.381
7	.6859	.4954	.6097	.4572	.6859	.724	.6859
8	.724	.724	.7621	.6859	.8002	.7545	.8383
9	.8383	.9145	.9145	.6478	.8383	.8764	.9145
10	.8764	.9907	.9526	.4572	.9145	.9907	.9907
11	.9907	.9145	.9526		.9907	.9526	
12	1.0669	.9526		.6859	.6859		
13	1.1431		1.0669	.6859	.6859	1.1431	.9145
14	.8764	.9145	.8764	.4572	.9526	.8764	.8764
15	.9145	.8764	.9145	.4572	.9526	.9145	.9145
16	.9145	.9145	.9526		.9145	.6097	
17		.8764	.9526	.724	.9526	.8764	.8764
18	.8383	.8383	.8383	.6859	.724	.8383	.8383
19	.724	.5716	.8383	.6478	.7621	.8002	.7621
20	.8002	.8002	.7621	.4572	.724	.7621	.7621
21	.5335	.8002	.4954	.4572	.6859	.4954	.5716
22	.724	.4954	.6859	.6859	.4954	.5335	.5716
23	.6859	.6859	.6859	.6478	.6478	.6859	.6478
24	.6478	.6478	.6859	.6478	.6036	.6859	.6097
Max	1.1431	.9907	1.0669	.724	.9907	1.1431	.9907
Min	.381	.4191	.4191	.381	.381	.4191	.381
Avg	.7981	.6942	.7321	.5716	.7324	.73	.6714

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

SANGHVI SUB-DN.[636] BU 4636

Substation No/ Name :- 213358 / 22/22 KV ADITYA BIRLA

SWITCHIN

Feeder No / Name : 304 / 22 KV WAKAD ROAD FEEDER Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.7915	2.7161	3.0864	2.4897	2.3388	2.2257
2		2.7161	2.5274		2.3765	2.2257	2.1879
3		2.7161	2.5652	3.0483		2.1879	2.1125
4		2.7161	2.5652	3.0483		2.2634	2.1125
5		2.8669	2.7161	3.2769	2.4897	2.3388	2.3388
6	3.2442	3.3196	2.8669		2.7538	2.5274	2.6406
7	3.9609	3.9986	3.2819	.8383	3.2065	3.2065	3.0556
8	4.4136	4.3004	3.7723	2.8959		3.2442	3.3573
9	4.0771	3.8485	3.7723	2.5149		2.8959	3.0483
10	3.5056	3.5818		2.3624		2.6292	2.7054
11	3.6199	3.2769	3.658			2.4006	
12		3.0864		3.2769	2.9721		
13	3.5818	2.934	3.4675	2.9721	2.553	2.1719	2.0576
14	2.9721	2.8959	3.2388		2.2481	2.0576	2.0195
15	2.7435	2.8959	3.1626	3.8866	2.0957	1.9814	
16	2.6673	2.8197	3.2769	3.4675	1.5844	1.9993	
17		2.8959	3.2388	3.8485	2.1879	2.1125	2.2257
18	2.7435	4.6868	3.2769	.5335	2.1879	2.1502	2.2257
19	3.2388	4.9535	3.6199	.6097	2.5652	2.5274	2.5652
20	3.8485	5.3727	4.1152	3.7342	2.9801	2.9801	2.9801
21	4.0009	5.4108	4.1152	3.5818	3.0556	3.0178	3.0933
22	3.9986	5.1303	3.9628	3.4705	3.0556	3.0178	
23	3.546	4.6022	3.7723	3.0933	2.8292	2.7538	2.7054
24	2.9424	3.0933		3.2769	2.7161	2.4897	2.3388
Max	4.4136	5.4108	4.1152	3.8866	3.2065	3.2442	3.3573
Min	2.6673	2.7161	2.5274	.5335	1.5844	1.9814	2.0195
Avg	3.4767	3.6212	3.3185	2.8411	2.5748	2.5008	2.5261

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

SANGHVI SUB-DN.[636] BU 4636

Substation No/ Name :- 213358 / 22/22 KV ADITYA BIRLA

SWITCHIN

Feeder No / Name : 305 / 22 KV VENGASARKAR FEEDER Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.3011	2.1125	2.4006	1.773	1.8861	1.9239
2		2.1502	2.037		1.7353	1.8107	1.8107
3		2.1502	2.037			1.8107	1.8107
4		2.1125	2.037	2.4768		1.8861	1.8107
5		2.6406	2.1125		1.8861	1.9993	1.9616
6	2.7915	2.8669	2.5652	2.5911	2.2634	2.3011	2.8669
7	3.0178	3.0933	2.7161	2.7054	2.3765	2.6783	3.131
8	2.9801	2.9424	2.9047	2.7816	2.0748	2.4143	2.9801
9	2.8578	3.0483	2.934	3.0102	1.9052	2.2481	2.8197
10	2.0576	2.6673	2.7816	2.934	1.8671	2.1719	2.0195
11		2.4768	2.7054		1.7909	1.9814	
12		2.4006		2.6673	1.6004		
13		2.2862	2.4006	2.5149	1.5623	1.7528	1.6766
14		2.21	2.4006	2.4768	1.5623	1.7528	1.6766
15		2.2481	2.4006	2.5149	1.8671	1.829	
16		2.3624	2.4387		1.7353	1.8107	
17		2.4768	2.4387	2.6292	1.8107	1.8107	
18	3.0483	2.5911	2.6673	2.7816	1.8861	1.9616	2.1502
19	3.2007	2.6673	2.934	2.7435	2.1502	2.0748	2.1125
20	3.4675	3.0102	3.2388	3.2007	2.5652	3.0933	2.4143
21	3.3532	3.0483	3.0483	3.0864	2.5652	3.0556	3.0178
22	3.2442	2.8292	3.0483	3.0933	2.4897	2.9801	
23	2.8292	2.5274	2.8578	2.8669	2.3011	2.7915	2.7054
24	2.037	2.5274	2.2257	2.5149	2.5652	2.037	2.4897
Max	3.4675	3.0933	3.2388	3.2007	2.5652	3.0933	3.131
Min	2.037	2.1125	2.037	2.4006	1.5623	1.7528	1.6766
Avg	2.9071	2.5681	2.5671	2.7363	2.0151	2.1799	2.2988

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

SANGHVI SUB-DN.[636] BU 4636

Substation No/ Name :- 213360 / 22/22 KV PARK STREET

SWITCHING

Feeder No / Name : 301 / 22 KV RUBY PARK FEEDER Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1075	.1052	.112	.1086	.1052	.0716	.1063
2	.1086	.1052	.112	.1075	.104	.1063	.1063
3	.1109	.1063	.1109	.0716	.0701	.1063	.1063
4	.1109	.1075	.1109	.0732	.0709	.0716	.0716
5	.1109	.1075	.112	.0709	.0724	.0724	.1086
6	.1478	.1097	.112	.1075	.1097	.1097	.1109
7	.1848	.1478	.1109	.1063	.1494	.112	.1494
8	.1478	.1463	.1494	.1086	.1478	.1867	.1478
9	.1848	.1463	.1494	.1086	.1463	.1478	.1867
10	.1494	.1478	.1494	.1478	.1494	.1478	.1494
11	.1448	.112	.1494	.1867	.1109	.112	.112
12		.112	.112	.1478	.1109	.112	.1109
13		.0739	.1097	.1463	.1109	.0739	.0739
14		.0732	.0732	.1109	.0747	.0732	.0732
15		.0747	.0739	.1086	.0747	.0732	.0739
16		.0747	.112	.1097	.1097	.0732	.0732
17		.112	.0747	.1097	.0732	.1097	.0732
18		.0747	.112	.1109	.1109	.1097	.1097
19	.1829		.1463	.1097	.1109	.1086	.1463
20	.181	.1494	.1086	.1463	.1463	.1463	.1463
21	.1829	.1494	.1463	.1478	.1463	.1463	.1463
22	.1478	.1494	.1478	.1463	.1478	.1463	.1463
23	.1463	.1494	.1109	.1448	.1097	.1097	.1463
24	.1075	.1075	.112	.1086	.1075	.1075	.1075
Max	.1848	.1494	.1494	.1867	.1494	.1867	.1867
Min	.1075	.0732	.0732	.0709	.0701	.0716	.0716
Avg	.1445	.1149	.1174	.1185	.1112	.1097	.1159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

SANGHVI SUB-DN.[636] BU 4636

Substation No/ Name :- 213360 / 22/22 KV PARK STREET

SWITCHING

Feeder No / Name : 302 / 22 KV SAPHIRE PARK

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.1463	.1494	.1478	.1463	.1478	.1463
2	.1478	.1097	.1494	.1829	.1109	.1463	.1478
3	.1478	.1109	.112	.1463	.1097	.1448	.1463
4	.1478	.1109	.112	.1109	.1109	.1463	.1109
5	.1494	.1494	.112	.1109	.1478	.1478	.1478
6	.1494	.1886	.112	.1097	.1867	.1848	.1867
7	.1867	.2641	.1494	.1097	.2241	.1867	.2241
8	.1867	.1886	.1494	.1086	.1494	.1867	.1867
9	.1494	.1886	.1494	.1494	.1509	.1494	.1494
10	.1494	.1886	.1886	.1494	.1509	.1886	.1886
11	.1494	.1132	.1886	.1867	.1509	.1509	.1509
12		.1509	.1886	.1509	.1494	.1509	.1509
13		.112	.1494	.1494	.112	.1478	.1132
14		.112	.112	.1494	.112	.1494	.112
15		.1132	.112	.1494	.1132	.112	.112
16		.1132	.1509	.1494	.1132	.112	.1132
17		.1132	.1132	.1494	.1132	.112	.1132
18		.1132	.1132	.1494	.1109	.1494	.1509
19	.1848		.112	.1494	.112	.1494	.1509
20	.1494	.1494	.1509	.1886	.1494	.1867	.1886
21	.1867	.1494	.1509	.1509	.1494	.1867	.1509
22	.1886	.1494	.1886	.1867	.1867	.1867	.1886
23	.1867	.1494	.1886	.1867	.1867	.1867	.1886
24	.1463	.1478	.1494	.1478	.1494	.1867	.1848
Max	.1886	.2641	.1886	.1886	.2241	.1886	.2241
Min	.1463	.1097	.112	.1086	.1097	.112	.1109
Avg	.1619	.1449	.1438	.1487	.1415	.1582	.1543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

SANGHVI SUB-DN.[636] BU 4636

Substation No/ Name :- 213360 / 22/22 KV PARK STREET

SWITCHING

Feeder No / Name : 303 / 22 KV TOPAZ PARK FEEDER Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.1848	.1886	.2263	.2195	.1886	.1886
2	.2241	.1829	.1886	.1886	.2218	.1867	.1886
3	.2263	.1848	.1509	.1867	.1867	.1867	.1848
4	.2263	.1867	.1509	.1829	.1848	.1867	.1848
5	.2263	.2241	.1509	.181	.2218	.1886	.1867
6	.2263	.2641	.1886	.181	.2614	.2263	.2263
7	.2641	.3018	.1867	.181	.3018	.2641	.3018
8	.2641	.2641	.2263	.2218	.2641	.2263	.3018
9	.2641	.2641	.2641	.2241	.2263	.2667	.2667
10	.2641	.2641	.3018	.2641	.2263	.2667	.2286
11	.1886	.2667	.2667	.3018	.2641	.1905	.2286
12		.2286	.2286	.2641	.2263	.2286	.2263
13		.1905	.2263	.2241	.1886	.1524	.1886
14		.1132	.1886	.1867	.1509	.1509	.1509
15		.1886	.1886	.1867	.1509	.1509	.1509
16		.1509	.1867	.1867	.1509	.1509	.1509
17		.1509	.1509	.1867	.1509	.1509	.1509
18		.1886	.1509	.2286	.1886	.1509	.1509
19	.2614		.2286	.2263	.1886	.1886	.1905
20	.3018	.2641	.2286	.2667	.2263	.2286	.2286
21	.3018	.2263	.2286	.2667	.2641	.2667	.2667
22	.2614	.2263	.2286	.2667	.2641	.2263	.2641
23	.2641	.1886	.2667	.2614	.2614	.2641	.2641
24	.2195	.2218	.1886	.2263	.2614	.2241	.2241
Max	.3018	.3018	.3018	.3018	.3018	.2667	.3018
Min	.1886	.1132	.1509	.181	.1509	.1509	.1509
Avg	.2474	.2142	.2064	.2215	.2188	.2047	.2123

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

SANGHVI SUB-DN.[636] BU 4636

Substation No/ Name :- 213360 / 22/22 KV PARK STREET

SWITCHING

Feeder No / Name : 304 / 22 KV ROW HOUSE FEEDER Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2263	.1886	.2263	.2286	.2263	.2263
2	.1886	.1867	.1886	.1886	.1905	.2263	.2263
3	.2263	.1867	.1886	.1886	.1905	.1886	.1886
4	.2263	.1478	.1509	.1494	.1905	.1886	.1867
5	.1886	.1867	.1509	.1478	.1886	.1886	.2263
6	.2263	.2241	.1886	.1478	.2263	.1886	.2641
7	.2263	.2641	.1867	.1494	.2641	.1886	.3018
8	.2641	.2641	.2263	.1886	.2241	.2263	.2263
9	.2667	.2641	.2263	.2263	.2641	.2263	.2641
10	.2263	.2641	.2263	.2263	.2218	.2241	.2641
11	.1867	.2641	.2241	.1886	.2241	.1867	.2241
12		.2263	.2263	.2241	.2241	.1848	.2218
13		.1463	.1867	.1848	.1867	.1463	.2218
14		.1848	.1848	.1886	.1848	.1463	.1829
15		.1848	.1867	.1886	.1478	.1463	.1478
16		.1848	.1433	.1886	.1829	.1509	.2218
17		.1848	.1448	.1886	.1848	.1463	.2241
18		.1886	.1463	.1886	.1478	.1494	.1867
19	.0221		.1478	.1867	.1494	.1867	.1867
20	.2587	.2263	.2218	.2218	.2241	.2241	.2614
21	.2614	.1886	.2241	.2241	.2241	.2241	.2241
22	.2614	.1886	.1848	.2241	.2641	.2641	.2241
23	.3018		.2614	.2641	.2641	.2641	.2641
24	.1886	.2241	.1886	.2263	.2641	.2263	.2641
Max	.3018	.2641	.2614	.2641	.2641	.2641	.3018
Min	.0221	.1463	.1433	.1478	.1478	.1463	.1478
Avg	.2182	.2094	.1914	.1969	.2109	.1966	.2263

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

SANGHVI SUB-DN.[636] BU 4636

Substation No/ Name :- 213360 / 22/22 KV PARK STREET

SWITCHING

Feeder No / Name : 305 / 22 KV ROYAL RAHATGI FEEDER Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2263	.2263	.2263	.2286	.2263	.2286
2	.1886	.1905	.1886	.1886	.2286	.2286	.2286
3	.1886	.1905	.1886	.1905	.1886	.2286	.1905
4	.1886	.2286	.1886	.1524	.1886	.1905	.1886
5	.1886	.2641	.1886	.1494	.2263	.2286	.1886
6	.2641	.3018	.1886	.1867	.2667	.2667	.2641
7	.3018	.3395	.2241	.1867	.3048	.3048	.3048
8	.3018	.3018	.2641	.2263	.2667	.2641	.3048
9	.3018	.3018	.2641	.2641	.2667	.3048	.2667
10	.2641	.2641	.3048	.2667	.2263	.2667	.2286
11	.1886	.2641	.3048	.3048	.2263	.2286	.1886
12			.2667	.3048	.1886	.2286	.1886
13			.2667	.2667	.1886	.2286	.2263
14			.2263	.2667	.1886	.1886	.1509
15			.2263	.1905	.1524	.1509	.1509
16		.3429	.2263	.2286	.1905	.1509	.1509
17		.2641	.1886	.2286	.1886	.1886	.1509
18		.2263	.1886	.2286	.1886	.1867	.1509
19	.415		.2286	.3048	.2263	.2641	.2263
20	.4481	.4108	.2667	.3018	.2641	.3048	.3018
21	.415	.2987	.3018	.3018	.3018	.3429	.3395
22	.3395	.2614	.2641	.3018	.3018	.3048	.3018
23	.3048	.2241	.2641	.3018	.3018	.3048	.2641
24	.2241	.2641	.2263	.2263	.2641	.2641	.2667
Max	.4481	.4108	.3048	.3048	.3048	.3429	.3395
Min	.1886	.1905	.1886	.1494	.1524	.1509	.1509
Avg	.2792	.2719	.2363	.2415	.2318	.2436	.2272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

SANGHVI SUB-DN.[636] BU 4636

Substation No/ Name :- 213360 / 22/22 KV PARK STREET

SWITCHING

Feeder No / Name : 306 / 22 KV HEALTH CARE CENTRE Urban/Sheddable Urban Feeder

FEEDER Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373		.0377		.0377	.0373	.0373
2	.0377				.0373	.0373	.0377
3						.0373	.0377
6	.0377		.0377			.0381	.0377
7	.0377	.0381	.0373		.0381	.0381	.0762
8	.0377	.0377	.0377		.0377	.0373	.0754
9	.0754	.0377	.0754	.0377	.0762	.1143	.1143
10	.1509	.1143	.1132	.0754	.1132	.1524	.1509
11	.1886	.1905	.1886	.1509	.2263	.2286	.2263
12		.1905	.2241	.112	.1905	.1886	.2263
13		.1905	.1886	.1132	.1905	.2263	.1886
14		.1509	.1886	.1509	.1886	.2263	.1886
15		.1886	.1886	.1509	.1905	.2263	.1886
16		.2263	.1886	.1132	.1905	.2263	.1886
17		.2263	.2263	.1509	.1905	.2263	.1886
18		.1886	.1886	.1132	.1886	.1886	.1886
19	.1509		.1509	.1132	.1509	.1494	.1509
20	.1509	.112	.1886	.1132	.1509	.1132	.1509
21	.1132	.0747	.1132	.1143	.1132	.1132	.1132
22	.0747	.0747	.0754	.0754	.0754	.0754	.0754
23	.0377	.0373	.0377	.0373	.0747	.0373	.0366
24	.0373	.0373	.0377		.037	.037	.037
Max	.1886	.2263	.2263	.1509	.2263	.2286	.2263
Min	.0373	.0373	.0373	.0373	.037	.037	.0366
Avg	.0834	.1245	.1262	.1081	.1249	.1252	.1234

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

SANGHVI SUB-DN.[636] BU 4636

Substation No/ Name :- 213398 / 22/22 KV PADAMAJI SWICHING

Feeder No / Name : 301 / 22 KV PADAMAJI GREENS Urban/Sheddable Urban Feeder
 FEEDER Feeder KV- 22 /
 OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.2286	.2286	.2286	.2286
10		.2286	.2667	.2286
11		.2286	.2286	.1905
12		.2286	.2286	.1905
13		.2286	.1905	.1524
14		.1905	.1905	.1524
15		.1905	.1905	.1524
16		.1905	.1905	.1905
Max	.2286	.2286	.2667	.2286
Min	.2286	.1905	.1905	.1524
Avg	.2286	.2143	.2143	.1857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

SANGHVI SUB-DN.[636] BU 4636

Substation No/ Name :- 213399 / 22/22 KV DARADE JOG SWICHING

Feeder No / Name : 301 / 22 KV DARADE JOG FEEDER Urban/Sheddable Urban Feeder
Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.1132	.1132	.1132	.1132	.1132	.1132	.1132
8	.1132	.1132	.1132	.1509	.1509	.1509	.1509
9	.1509	.1509	.1509	.1509	.1132	.1132	.1132
10	.1509	.1509	.1509	.1132	.1132	.1132	.1132
11	.1132	.1132	.1132	.1132	.1132	.1132	.1132
12	.1132	.1132	.1132	.1132	.1132	.1132	.1132
13	.1132	.1132	.1132	.1132	.1132	.0754	.0754
14	.1132	.1132	.1132	.1132		.1132	.1132
15	.1132	.1132	.1132	.1132	.1132	.0754	.1132
16	.1132	.0754	.1132	.1132	.1132	.0754	.1132
17	.1132	.1132	.1132	.1132	.1132	.1132	.1132
18	.1132	.1132	.1132	.1132	.1132	.1132	.1132
19	.1132		.1132	.1132	.1132	.1132	.1132
20	.1132		.1132	.1132	.1132	.1509	.1509
21	.1132	.1132	.1132	.1132	.1132	.1132	.1132
22	.1132	.1132	.1132	.1132	.1132		.1132
23	.1132	.1132	.1132	.1132	.1132	.1132	.1132
Max	.1509	.1509	.1509	.1509	.1509	.1509	.1509
Min	.1132	.0754	.1132	.1132	.1132	.0754	.0754
Avg	.1176	.1157	.1176	.1176	.1156	.1108	.1154

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

SANGHVI SUB-DN.[636] BU 4636

Substation No/ Name :- 213402 / 22/22 KV SONIGRA KESAR

SWITCHI

Feeder No / Name : 301 / 22 KV MOUNT VERT FEEDER Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6554	.6554		.5898	.5898	.6882	.6882
2	.6554	.6226		.5243	.5571	.6554	.6554
3	.0655	.5898	.5243	.5243	.5571	.6226	.5898
4	.6226	.5571	.4915	.5243	.5571	.5898	.6226
5	.6554	.6226	.4915	.5243	.5571	.6554	.6554
6	.6882	.6882	.5243	.5571	.5898	.6882	.6882
7	.9503	.7537	.5243	.5898	.7537	.852	.8192
8	1.0159	.852	.6554	.6226	.8848	1.0159	.9175
9	.9503	.9503	1.0159	.9175		.9175	.9175
10	.0983	.8848	1.0159	1.0486		.8848	.852
11	.426	.8848	1.0159	1.0814		.852	
12		.7209	.9175	1.1142		.6554	.7865
13		.6882	.852	.9503		.5571	.6882
14		.5967	.0663	.7209			.6226
15	.3932	.4641	.7537	.7537		.4915	.6226
16	.8192	.5243	.7209	.5898	.6226	.6554	.5243
17	.7209	.6554	.7537	.5571	.5898	.6554	.4915
18	.7537	.6882	.7537	.8192	.5571	.6226	.5898
19	.7865		.8848	.7865	.6882	.7537	.7209
20	1.0159		.9175	.852	.852	.9503	.7865
21	.9175	.6554	1.835	.852	1.0159	.9175	.8192
22	.852		.7537	.7865	.9831	.9175	.8192
23	.7865	.6882	.7209	.6882	.8192	.7865	.7865
24	.6882	.7209		.6226	.6226	.7625	.7209
Max	1.0159	.9503	1.835	1.1142	1.0159	1.0159	.9175
Min	.0655	.4641	.0663	.5243	.5571	.4915	.4915
Avg	.6913	.6887	.7709	.7332	.6939	.7455	.7124

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

SANGHVI SUB-DN.[636] BU 4636

Substation No/ Name :- 213402 / 22/22 KV SONIGRA KESAR

SWITCHI

Feeder No / Name : 302 / 22 KV DYANASTY FEEDER Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3605	.3932		.2949	.2949	.3605	.3605
2	.3277	.3605		.2622	.2622	.3277	.3277
3	.3277	.3277	.2294	.2622	.2622	.3277	.3277
4	.3277	.3277	.2294	.2622	.2622	.2949	.3277
5	.3605	.3605	.2294	.2622	.2949	.3277	.3605
6	.3932	.3932	.2622	.2622	.3277	.3605	.3932
7	.5243	.426	.2949	.2949	.426	.3932	.4588
8	.5571	.4915	.2949	.3277	.3932	.4915	.5243
9	.5243	.5243	.3277	.426		.5243	.4588
10	.3605	.426	.4588	.5243		.426	.4588
11	.3277	.3605	.4588	.5571		.3277	
12		.3277	.4588	.5571		.3277	.3932
13		.3277	.4588	.5243		.3277	.3277
14		.2949	.3932	.4588			.2949
15	.3277	.2949	.3932	.4588		.2949	.2949
16	.3932	.2949	.3932	.3277	.3277	.2949	.2949
17	.3932	.3277	.3605	.3605	.3605	.3277	.2622
18	.3932	.3277	.3277	.3605	.3605	.3277	.2949
19	.426		.426	.426	.3932	.3932	.3605
20	.4588	.4915	.4915	.426	.426	.426	.3932
21	.4588	.426	.4588	.3932	.4588	.4915	.3605
22	.426		.3605	.426	.4588	.4588	.4588
23	.426		.3605	.3605	.426	.426	.3932
24	.3605	.3932		.3277	.2949	.3932	.3932
Max	.5571	.5243	.4915	.5571	.4588	.5243	.5243
Min	.3277	.2949	.2294	.2622	.2622	.2949	.2622
Avg	.4026	.3761	.3652	.3810	.3547	.3761	.3704

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

SANGHVI SUB-DN.[636] BU 4636

Substation No/ Name :- 213402 / 22/22 KV SONIGRA KESAR

SWITCHI

Feeder No / Name : 303 / 22 KV WIND WORD(MALPANI Urban/Sheddable Urban Feeder
GREEN) Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0663	.0663	.0663	.0995	.0663	.0663	.0663
2	.0663	.0663		.0663	.0663	.0663	.0663
3	.0663	.0663	.0663	.0663	.0663	.0663	.0663
4	.0663	.0663	.0663	.0663	.0663	.0663	.0663
5	.0663	.0663	.0663	.0663	.0663	.0663	.0663
6	.0663	.0663	.0663	.0663	.0663	.0663	.0663
7	.0995	.0663	.0995	.0663	.0995	.0995	.0663
8	.0995	.0995	.0995	.0995	.0995	.0995	.0995
9	.0995	.0995	.0107	.0995		.0995	.1326
10	.0995	.0995	.1326	.0995		.0983	.0983
11	.0995	.0995	.0995	.0995		.0983	
12		.0663	.0995	.0995		.0983	.0983
13		.0663	.0995	.0995		.0655	.0655
14		.0663		.0995			.0655
15	.0663	.0663	.0995	.0995		.0663	.0655
16	.0663	.0655	.0995	.0995	.0663	.0663	.0663
17	.0995	.0655	.0995	.0995	.0663	.0663	.0663
18	.0995	.0655	.1326	.0663	.0995	.0663	.1326
19	.0995		.0995	.0995	.0995	.0995	.1326
20	.0995	.0983	.0995	.1326	.0995	.0995	.0995
21	.0995	.0983	.0995	.0995	.0995	.1326	.0995
22	.0995		.0995	.0995	.0995	.0995	.0995
23	.0995		.0995	.0995	.0995	.0995	.0995
24	.0663	.0663		.0995		.0995	.0663
Max	.0995	.0995	.1326	.1326	.0995	.1326	.1326
Min	.0663	.0655	.0107	.0663	.0663	.0655	.0655
Avg	.0853	.0756	.0905	.0912	.0829	.0849	.0848

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

SANGHVI SUB-DN.[636] BU 4636

Substation No/ Name :- 213449 / 22/11 KV PETHKAR SUB

STATION

Feeder No / Name : 301 / 11 KV MALWADI FEEDER

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1334	.0762	.0953	.1334	.1402	.1753
2	.0953	.1524	.0762	.0953	.1334	.1578	.1578
3	.1143	.1143	.0572	.0762	.1715	.1402	.1578
4	.1334	.1715	.0572	.0953	.1905	.1417	.1227
5	.1905	.1524	.0572	.0953	.1524	.1052	.1052
6	.2096	.0762	.0381	.0762	.1334	.1227	.1578
7	.1334	.0953	.1486	.0953	.1524	.1227	.1227
8	.1143	.1334	.1524	.0762	.1334	.1052	.1052
9	.0953	.1334	.1334	.0572	.1715	.1578	.1524
10	.1524	.1402		.1402	.132	.1886	.1334
11	.1334	.1052	.2103	.1578	.1886	.2641	.1905
12		.1402	.2279	.1578	.2286	.2452	.1905
13	.1905	.1402	.1928	.0351	.2075	.1886	.2096
14	.0953	.1227	.1227	.1753	.1886		.1715
15	.1715	.1402	.1578	.0351	.1698	.1698	.1524
16	.1387	.104	.1402	.2629	.1928	.2454	.1905
17	.0347	.1387	.1402	.1928	.1753	.1928	.2096
18	.0693	.1753	.1052	.1928	.2279	.2454	.2096
19	.0347		.1402	.1753	.1753	.1753	.1905
20	.0693		.1227	.1578	.1753	.1753	.1905
21	.0867	.0175	.0876	.1578	.1052	.1928	.1905
22	.0762		.1143		.1227	.1052	.2454
23	.1334	.0191		.1715	.0876	.1052	.1402
24	.1715	.1524	.0191	.0953	.1334	.1402	.1578
Max	.2096	.1753	.2279	.2629	.2286	.2641	.2454
Min	.0347	.0175	.0191	.0351	.0876	.1052	.1052
Avg	.1199	.1218	.1172	.1248	.1618	.1664	.1679

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

PIMPRI DIVISION[301]

SANGHVI SUB-DN.[636] BU 4636

Substation No/ Name :- 213449 / 22/11 KV PETHKAR SUB

STATION

Feeder No / Name : 302 / 11 KV LEAGACY FEEDER

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.4268	.4382	.381	.3292	.3292
2	.4001	.4001	.4306	.4382	.381	.3292	.3292
3	.2858	.4191	.4268	.4572	.362	.3292	.3109
4	.3048	.4001	.4325	.4572	.3429	.3292	.3292
5	.3239	.362	.4344	.4763	.4001	.3658	.3292
6	.3429	.4382	.4382	.4287	.4382	.4207	.4024
7	.4191	.4763	.4592	.4572	.4572	.4572	.4207
8	.4572	.4572	.4382	.4954	.5335	.3109	.439
9	.4191	.4382	.4191	.5144	.4954	.2926	.362
10	.4001	.4024		.4572	.4527	.2641	.4572
11	.4001	.439	.4938	.4572	.4527	.2452	.4001
12		.4024	.4755	.4755	.4191	.2829	.4001
13	.362	.3658	.4572	.4024	.3206	.2452	.381
14	.3239	.3475	.4024	.4207	.3206		.381
15	.2667	.3841	.4572	.3841	.3584	.3584	.2667
16	.2743	.3658	.3658	.3841	.3475	.3658	.4191
17	.3841	.3475	.439	.3841	.3841	.3658	.4382
18	.3475	.4207	.4207	.3841	.3841	.3475	.4191
19	.4024		.3841	.3841	.4755	.3841	.5144
20	.4207		.439	.4755	.4755	.4572	.5144
21	.439	.4938	.4572	.4572	.4755	.4572	.4763
22	.4191		.4191		.4207	.439	.4207
23	.381	.4191		.381	.3841	.3841	.3658
24	.381	.3429	.423	.4191	.362	.3475	.3475
Max	.4572	.4938	.4938	.5144	.5335	.4572	.5144
Min	.2667	.3429	.3658	.381	.3206	.2452	.2667
Avg	.3711	.4049	.4336	.4360	.4094	.3525	.3939

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

AUNDH SUB-DN.[599] BU 4599

Substation No/ Name :- 212003 / Rohan nilay

Feeder No / Name : 201 / 11 kv rohan nilay - I Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1254	.1227	.1227	.124	.124	.124
2	.1017	.1254	.1052	.124	.1227	.124	.1063
3	.1029	.1063	.0876	.1052	.1063	.1052	.1052
4	.1017	.0876	.0867	.1052	.0876	.0876	.1063
5	.1017	.0867	.0886	.0876	.0876	.0867	.1052
6	.1402	.0876	.0876	.0876	.104	.0876	.124
7	.1578	.124	.124	.1214	.124	.1227	.1612
8	.1753	.1433	.1791	.1433	.1433	.1595	.197
9	.1595	.1417	.1646	.197	.1612	.1612	.1612
10	.1433	.1612	.1991	.1791	.1612	.1433	.1612
11	.1417	.1612	.1595	.197	.1433	.1254	.1075
12	.1402	.1227	.1417		.1254	.1075	.1075
13	.1052	.1402	.1254		.1075	.1075	.1075
14	.1052	.1052	.124		.1254	.0895	.1075
15	.1029	.1052	.1063	.1433	.1075	.1075	.1075
16	.1052	.1052	.1254	.1417	.1254	.1254	.104
17	.1227	.124	.1075	.1417	.1063	.1052	.1052
18	.1227	.1227	.1254	.1578	.1227	.1214	.1075
19	.1402	.1227	.1402	.1578	.1402	.156	.1214
20	.1578	.1402	.1433	.1612	.1612	.1578	.1612
21	.181	.156	.1433	.1772	.1772	.1753	.1791
22	.1629	.1417	.1433	.1595	.1791	.1612	.1448
23	.1612	.1267	.1448	.1417	.1417	.1417	.1463
24	.1052	.1448		.124	.1227	.124	.1227
Max	.181	.1612	.1991	.197	.1791	.1753	.197
Min	.1017	.0867	.0867	.0876	.0876	.0867	.104
Avg	.1309	.1253	.1294	.1417	.1295	.1253	.1284

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

AUNDH SUB-DN.[599] BU 4599

Substation No/ Name :- 212003 / Rohan nilay

Feeder No / Name : 202 / 11 kv Rohan nilay - II Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.037	.0549	.0373	.037	.0366	.037	.0366
2	.037	.0366	.0362	.037	.0366	.0366	.0366
3	.037	.037	.0362	.0185	.0366	.0366	.0185
4	.037	.0366	.0183	.0183	.0183	.0183	.0185
5	.037	.0366	.0181	.0187	.0183	.0183	.0185
6	.037	.0373	.0366	.0185	.0185	.0366	.037
7	.0554	.0366	.0366	.037	.037	.0549	.0554
8	.0554	.056	.056	.056	.056	.0549	.056
9	.0554	.056	.0747	.0554	.0554	.0554	.0554
10	.056	.056	.056	.0554	.0185	.037	.037
11	.056	.056	.056	.0554	.037	.0554	.037
12	.0554	.0373	.0554		.037	.037	.0554
13	.0366	.0366	.056		.037	.037	.0554
14	.0366	.037	.0554		.037	.037	.037
15	.0366	.0549	.0373	.037	.037	.037	.037
16	.037	.056	.0373	.0373	.037	.037	.037
17	.037	.0554	.037	.0549	.0366	.0549	.037
18	.037	.0554	.037	.0362	.0366	.037	.037
19	.0554	.0554	.037	.0549	.0366	.037	.0554
20	.0739	.0554	.0554	.056	.056	.0554	.0554
21	.0554	.0554	.0554	.056	.0373	.0554	.0554
22	.0554	.0373	.0554	.056	.056	.0373	.056
23	.056	.0373	.037	.0373	.0373	.0373	.0373
24	.037	.0549	.0373	.0373	.037	.0373	.037
Max	.0739	.056	.0747	.056	.056	.0554	.056
Min	.0366	.0366	.0181	.0183	.0183	.0183	.0185
Avg	.0462	.0470	.0440	.0414	.0370	.0407	.0416

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

AUNDH SUB-DN.[599] BU 4599

Substation No/ Name :- 212003 / Rohan nilay

Feeder No / Name : 203 / 11 kv Sanghavi road Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.4668	.415	.4108	.3921	.4435	.4294
2	.3734	.4668	.4066	.3734	.3921	.4435	.4294
3	.3734	.4294	.4108	.3734	.3547	.3841	.3511
4	.3772	.4108	.3696	.3734	.3361	.3881	.3511
5	.3734	.4108	.3511	.3361	.3326	.3881	.3511
6	.4527	.4108	.3511	.3361	.3511	.4207	.3881
7	.4904	.4715	.4066	.3547	.4251	.4435	.4481
8	.5093	.5415	.4668	.4108	.4854	.4854	.5093
9	.5281	.5093	.4904	.4108	.5041	.4805	.5041
10	.5415	.6036	.6036	.3921	.5601	.5544	.5228
11	.5415	.6413	.6413	.4294	.6348	.6348	.5975
12	.5601	.5975	.6348		.5788	.5975	.5601
13	.5228	.5228	.5544		.5788	.5601	.5415
14	.4668	.4668	.5415		.0373	.4854	.4481
15	.4668	.6348	.5788	.5228	.5415	.5228	.4477
16	.4904	.5658	.5093	.4854	.5228	.4854	.4668
17	.4527	.6413	.4338	.4854	.5601	.4755	.4668
18	.4715	.4715	.4527	.4854	.4854	.4854	.4854
19	.5093	.4904	.4904	.4854	.5658	.4481	.4854
20	.5847	.5658	.6036	.5658	.5415	.5601	.5601
21	.5847	.5359	.5601	.5601	.5228	.5601	.5228
22	.5847	.4854	.5847	.5601	.547	.5658	.547
23	.5281	.4715	.5093	.5228	.5658	.547	.5658
24	.5093	.5041	.4481	.4668	.4294	.4854	.4668
Max	.5847	.6413	.6413	.5658	.6348	.6348	.5975
Min	.3734	.4108	.3511	.3361	.0373	.3841	.3511
Avg	.4892	.5132	.4923	.4448	.4686	.4936	.4769

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

AUNDH SUB-DN.[599] BU 4599

Substation No/ Name :- 213021 / UNIVERSITY

Feeder No / Name : 205 / Kasturba

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17
HR	Load (MW)
9	.0187
Max	.0187
Min	.0187
Avg	.0187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

AUNDH SUB-DN.[599] BU 4599

Substation No/ Name :- 213021 / UNIVERSITY

Feeder No / Name : 206 / 11 kv NAFTC (UG)

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7392	.7023	.6584	.8871	.6584	.5228	.4854
2	.7392	.6283	.6348	.7392	.6283	.4854	.4481
3	.7023	.6283	.6283	.7392	.6283	.4481	.4108
4	.6584	.6653	.6283	.6653	.6283	.3772	.3772
5	.6653	.6584	.6722	.6722	.6653	.3772	.3361
6	.6653	.6584	.6653	.5228	.6653	.3584	.3361
7	.2427	.961	.924	.7762	.961	.5281	.4854
8	1.0829	1.0829	.9979	.8501	1.0719	.5601	.5228
9	1.1706	1.3394	1.1949	.8131	1.2936	.7095	1.4045
10	1.6598	1.4937	1.1949	.8962	1.6057	1.3443	1.39
11	1.4937	1.5684		.4854	1.5684		1.5154
12	1.419	1.0374		.5228	1.5684	1.531	1.4415
13	1.419	1.4937	.8962	.5228	1.531	1.531	1.4784
14	1.419	1.4937	1.1949	.5228	1.4784	1.4937	1.3306
15	1.5844	1.6057		.5228	1.4784	1.4937	1.4784
16	1.531	1.419	.961	.9979	.7468	.7545	1.5684
17	1.3817	1.2696	.8501	.8962	.7095	.6722	1.419
18	1.2323	1.0456	1.0349	.924	.5975	.7095	1.2696
19	1.2323		.9709	.9335	.5228	.5975	1.1949
20	1.2696	.924	1.0349	1.0456	.5601	.6348	1.0456
21	1.1576	.8871	.9709	1.0082		.5601	.5175
22	1.0242	.7392	.9979	.9709			
23	.7392	.8501	1.0349	.7023		.5041	.5601
24	.7762	.695	.6653	1.0349	.6584	.5415	.5041
Max	1.6598	1.6057	1.1949	1.0456	1.6057	1.531	1.5684
Min	.2427	.6283	.6283	.4854	.5228	.3584	.3361
Avg	1.0835	1.0368	.8958	.7771	.9631	.7607	.9356

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

AUNDH SUB-DN.[599] BU 4599

Substation No/ Name :- 213021 / UNIVERSITY

Feeder No / Name : 207 / Vidyapeeth Express

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6722	.7095	.6468	1.2567	.6099	1.307	1.307
2	.6653	.6908	.6283	1.2323	.6283	1.2826	1.2696
3	.6401	.6908	.6099	1.2197	.6036	1.2449	1.2323
4	.6535	.5975	.6099	.6099	.6099	1.2071	1.2323
5	.6283	.6838	.6161	.5975	.5853	1.2071	1.2323
6	.6283	.7023	.6036	.3142	1.2012	1.2826	1.2883
7	.6653	.695	.6653	.6099	1.2752	1.307	1.307
8	.7023	.7577	.6468	.6099	1.3676	1.3443	1.4937
9	.7577	.8048	.7023	.6283	1.46	1.6057	1.5912
10	.8589	.9335	.7468	1.307	1.7924	1.7741	1.8665
11	.9335	1.0269		1.307	1.9978		1.9387
12	.9896	.3772		1.358	2.0165	2.0911	1.9959
13	.9896	1.0082	.8402	1.2696	2.0351	2.0538	1.885
14	1.0082	1.0082	.8402	1.2696	1.9044	2.0538	1.885
15	.3018	.9709		1.2323	1.9959	2.0911	1.9404
16	.9709	.3361	.7655	.6161	1.9418	.6036	1.9605
17	.9335	.9709	.6908	.6161	1.8671	1.9044	1.8671
18	.8402	.8029	.6722	.5788	1.587	1.8671	1.5497
19	.8029		.6722	.6099	1.4937	1.4937	1.4937
20	.8029	.7207	.7095	.6722	.7095	1.5684	1.4937
21	.7842	.6908	.6908	1.3491		1.4563	1.419
22	.7468	.6767		.6468	1.419	1.419	
23	.7468	.6535	.6468	.6468		1.363	1.3817
24	.6653	.7207	.6468	.6653	1.2752	1.3443	1.3443
Max	1.0082	1.0269	.8402	1.358	2.0351	2.0911	1.9959
Min	.3018	.3361	.6036	.3142	.5853	.6036	1.2323
Avg	.7662	.7491	.6825	.8843	1.3807	1.5162	1.5641

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

AUNDH SUB-DN.[599] BU 4599

Substation No/ Name :- 213328 / UNITY INFRA

Feeder No / Name : 301 / 3 star & 5 star hotel

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7023	.6348	.4527	.4904	.2987	.2641	.2926
2	.5975	.6413	.4527	.3018	.2987	.2641	.2926
3	.5601	.6413	.3772	.3018	.1463	.1867	.2587
4	.4527	.6036	.3772	.3018	.1463	.1848	.2614
5	.4191	.5658	.3772	.2987	.1463	.1448	.2614
6	.381	.6413	.3772	.2987	.2263	.1433	.2614
7	.4572	.6413	.3772	.415	.2263	.2987	.3361
8	.6036	.7468	.3772	.415	.2641	.2641	.3361
9	.5975	.5335	.4904	.4527	.3018	.3018	.3361
10	.5658	.5335	.5281	.4527		.3048	.3361
11	.5658	.4954	.5335	.4527	.3018	.3048	
12	.5975	.4572	.4954	.4527	.3018	.3048	.3361
13	.6283	.4572	.4954	.4527	.2987	.2667	.2987
14	.4066	.4527	.4527	.415	.2987	.2641	.2987
15	.5975	.4904	.4954	.4527	.2987	.2263	.3772
16	.5121	.4904	.5281	.415	.3018	.1494	.3772
17	.5121	.5281	.4954	.2987	.1829	.1494	.3772
18	.5658	.415	.5658	.3395	.1905	.3734	.3395
19	.6722	.5228	.6722	.3395	.2286	.3361	.3772
20	.6348	.695	.6348	.3395	.4527	.3361	.3772
21	.6348	.6653	.6348	.415	.3395	.3326	.3772
22	.6348	.5601	.4904	.3395	.3018	.3395	.2987
23	.6348	.5281	.4527	.3395	.1886	.3395	.2957
24	.6722	.6722	.4904	.4904	.3395	.3734	.2957
Max	.7023	.7468	.6722	.4904	.4527	.3734	.3772
Min	.381	.415	.3772	.2987	.1463	.1433	.2587
Avg	.5669	.5672	.4843	.3863	.2644	.2689	.3217

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

AUNDH SUB-DN.[599] BU 4599

Substation No/ Name :- 213328 / UNITY INFRA

Feeder No / Name : 302 / Bhakti Cars

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1582	2.4394	2.3777	2.3525	2.5133	2.5503	2.5503
2	2.0485	2.3777	2.2314	2.3899	2.4025	2.5133	2.4874
3	2.0271	2.3411	2.1437	2.3525	2.3411	2.4143	2.4143
4	1.9909	2.3411	2.0328	2.3152	2.3045	2.3777	2.3411
5	2.0851	2.2314	2.1068	2.3152	2.4025	2.4764	2.3777
6	2.3152	2.4764	2.2916	2.3525	2.6886	2.6139	2.6242
7	2.6886	3.0178	2.4025	2.4272	2.9127	2.9047	3.0556
8	2.9424	3.2065	2.9127	2.6783	3.1687	3.2065	3.2442
9	3.2442	3.4705	3.1687	2.9801	3.7723	3.4328	3.546
10	3.2819	3.5837	3.5082	3.131		3.7723	3.8866
11	3.2819	3.3573	3.5082	3.2819	3.7342	3.5818	3.6199
12	3.0556	3.3573	3.3573	3.0933	3.5818	3.4675	3.315
13	2.9801	3.1687	3.2442	3.131	3.3913	3.1626	3.0483
14	2.8669	3.0556	2.9424	3.1687	3.0933	3.0864	2.8669
15		3.0933	2.9801	3.0933	3.0933		3.1245
16	2.9424	3.0556	3.131	3.131	3.315	3.2769	3.2769
17	3.0483	3.131	3.131	3.131	3.4294	3.315	3.2442
18	3.0864	3.2065	2.9801	2.9047	3.1245	3.2388	3.2442
19	2.9047	2.7161	3.131	3.0556	3.2769	3.0178	3.2065
20	3.5082	3.1687	3.3196	3.3951	3.6199	3.4328	3.5082
21	3.3196	3.0556	3.2442	3.2819	3.4675	3.3951	3.4328
22	3.1741	2.9127	3.131		3.3573	3.3573	3.2487
23	2.8829	2.6612	2.8753	3.0556	3.062	2.9874	2.9569
24	2.2916	2.5133	2.4874	2.726	2.7633	2.7633	2.6981
Max	3.5082	3.5837	3.5082	3.3951	3.7723	3.7723	3.8866
Min	1.9909	2.2314	2.0328	2.3152	2.3045	2.3777	2.3411
Avg	2.7880	2.9141	2.8600	2.8584	3.0790	3.0585	3.0549

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

AUNDH SUB-DN.[599] BU 4599

Substation No/ Name :- 213328 / UNITY INFRA

Feeder No / Name : 304 / Chive Vasti

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8484	2.1502	1.8484	2.037	2.0748	2.2481	2.0748
2	1.8484	2.1125	1.773	2.037	1.9616	2.1338	2.037
3	1.8107	2.037	1.7177	1.9993	1.9616	2.0957	1.9616
4	1.8861	2.037	1.643	1.9616	1.9616	2.0957	2.037
5	2.037	2.1125	1.7924	1.9993	2.037	2.21	2.2257
6	2.3011	2.3388	2.0748	2.0748	2.5911	2.6292	2.6673
7	2.6292	2.6673	2.3765	2.3624	2.6673	2.7054	2.6673
8	2.6673	2.553	2.4897	2.553	2.6292	2.7435	2.6292
9	2.4768	2.553	2.3243	2.553	2.4006	2.5149	2.3765
10	2.4143	2.5274	2.4387	2.4897		2.6292	2.4143
11	2.2862	2.452	2.553	2.3388	2.452	2.4387	2.3388
12	2.2481	2.3388	2.4768	2.3765	2.3388	2.1879	2.3388
13		2.2257	2.3243	2.1879	2.2257	2.1879	2.1879
14	1.9052	2.0576	.6413	1.8861	2.1879	2.1879	2.1879
15		2.21	.679	2.1879	2.2257	2.2257	2.2257
16	2.0748	2.2481	2.5274	2.2634	2.2634	2.3011	2.3011
17	.1509	2.2634	2.3388	2.0748	2.2257	2.1502	2.1125
18	.1478	1.8861	2.0911	1.9993	2.1879	2.1502	2.1125
19	2.6406	1.9239	2.1125	2.3011	2.3388	2.3011	2.4143
20	2.8197	2.2634	2.5911	2.5911	2.7538	2.7161	2.7538
21	2.7435	2.3624	2.7435	2.7816	2.8197	2.7161	2.8669
22	2.8197	2.3243	2.7054	2.6406	2.7054	2.6673	2.6783
23	2.4768	2.1125	2.4387	2.4143	2.553	2.5911	2.4768
24	1.9616	2.1879	1.9616	2.1879	2.1879	2.3388	2.2257
Max	2.8197	2.6673	2.7435	2.7816	2.8197	2.7435	2.8669
Min	.1478	1.8861	.6413	1.8861	1.9616	2.0957	1.9616
Avg	2.0997	2.2477	2.1110	2.2624	2.3370	2.3819	2.3463

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

AUNDH SUB-DN.[599] BU 4599

Substation No/ Name :- 213328 / UNITY INFRA

Feeder No / Name : 305 / Teerth Tower

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1462	1.0631	.9568	.9568	.9671	1.0985	1.0631
2	1.0985	1.0517	.8859	.9214	.9313	1.0166	1.0277
3	1.0985	.9816	.9015	.8764	.9214	.9816	1.0277
4	1.0517	.9816	.8322	.8764	.9214	.9816	.9816
5	1.0517	.9568	.8573	.8859	.9114	.9465	.9465
6	1.0867	1.0387	.8859	.8859	.9015	.9114	1.0277
7	1.267	1.0974	.9214	.8954	.9922	1.1104	1.0277
8	1.5154	1.3306	1.0974	.905	1.1222	1.2803	1.4266
9	2.1879	1.8861	1.5684	1.0349	1.8484	1.8861	2.0195
10		2.21	1.7353	1.1949		2.1719	2.21
11	2.2257	2.1719	1.773	1.3203	2.0957	2.1719	2.21
12	2.4143	2.21	1.9239	1.2826	1.9052	2.1719	2.2862
13	2.3765	2.1719	1.7353	1.2826	2.0957	2.0957	2.2481
14	2.2257	2.0195	1.531	1.2696	1.9814	2.1338	2.1338
15		2.2862	1.643	1.1827	2.1338		2.1719
16	.1463	2.0195	1.5466	1.1458	2.0576	1.9814	2.2481
17	.1097	2.0195	1.358	1.134	2.1719	1.773	2.0957
18	1.3336	1.773	1.2696	1.0974	1.7528	1.773	1.8484
19	1.1694	1.1694	1.307	1.0498	1.6766	1.7353	1.6598
20	1.5684	1.2323	1.2323	1.1706	1.7353	1.5844	1.6221
21	1.419	1.2567	1.1706	1.1706	1.4563	1.3957	1.4712
22	1.2936	1.1222	1.1222	1.134	1.3306	1.3169	1.3817
23	1.1584	1.0029	1.086	1.0498	1.1946	1.2308	1.2071
24	1.2803	1.1104	1.0029	1.0029	1.0029	1.1104	1.1462
Max	2.4143	2.2862	1.9239	1.3203	2.1719	2.1719	2.2862
Min	.1097	.9568	.8322	.8764	.9015	.9114	.9465
Avg	1.3738	1.5068	1.2643	1.0719	1.4829	1.5156	1.6037

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

AUNDH SUB-DN.[599] BU 4599

Substation No/ Name :- 213328 / UNITY INFRA

Feeder No / Name : 306 / Puranik Buildcon

HV Express Feeder

Feeder KV- 22 / INCOMING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.1132	.1143	.1132	.1132	.1132	.1132
2	.0754	.1132	.0762	.1132	.1132	.1132	.1132
3	.0754	.1132	.0762	.1132	.1132	.1132	.1132
4	.1132	.1132	.0762	.1132	.1132	.1132	.1132
5	.1132	.1132	.0762	.0754	.1132	.1132	.1132
6	.1132	.1132	.0762	.0754	.1132	.1132	.0754
7	.1132	.1509	.0762	.1132	.1132	.1132	.1509
8	.1509	.1524	.0762	.1132	.1132	.112	.1509
9	.1509	.1132	.1143	.1132	.1509	.1132	.112
10	.1494	.1509	.1143			.1494	.1494
11	.1478	.112	.1509	.1509	.1132	.1109	
12	.1109	.112	.0762	.1132		.1463	.1097
13	.0739	.0739	.1143	.1494	.112	.1097	.0732
14	.1109	.0747	.0762	.112	.1097	.1109	.0732
15		.0747	.1132	.1132	.0724	.112	.0732
16	.1097	.0732	.0754	.1132	.0739	.112	.0732
17	.1097	.0732	.1132	.1132	.1109	.112	.1097
18	.112	.0732	.1132	.1132	.1063	.1109	.1109
19	.112	.1097	.1086	.1463	.1075	.1478	.1097
20	.1109	.1109	.1075	.1478	.1448	.1867	.1463
21	.112	.112	.1097	.1478	.1494	.1478	.1463
22	.1132	.1132	.1463	.1478	.112	.112	.112
23	.1132	.1132	.112	.112	.1132	.112	.1132
24	.1132	.1132	.1143	.1494	.1132	.1132	.1132
Max	.1509	.1524	.1509	.1509	.1509	.1867	.1509
Min	.0739	.0732	.0754	.0754	.0724	.1097	.0732
Avg	.1122	.1077	.1003	.1205	.1134	.1213	.1117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

AUNDH SUB-DN.[599]

BU 4599

Substation No/ Name :- 213339 / 22/22 kv RMZ sstn

Feeder No / Name : 301 / Millenia - A

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5844	1.6598	1.7353	1.6598	1.6598	1.6975	1.6975
2	1.6975	1.6598	1.6598	1.6598	1.6975	1.7353	1.7353
3	1.7177	1.6221	1.6598	1.6221	1.6598	1.773	1.6975
4	1.643	1.6221	1.5844	1.6221	1.6221	1.6975	1.6598
5	1.5844	1.6221	1.6057	1.6221	1.6598	1.6598	1.6975
6	1.6804	1.6598	1.6975	1.6598	1.6598	1.6975	1.7353
7	1.9993	1.8484	1.7353	1.6804	1.7353	1.8484	1.9239
8	2.1285	2.2032	1.7353	1.773	2.2916	2.2032	2.2032
9	2.2916	2.4272	1.8671	1.773	2.4025	2.5393	2.5766
10	2.4025	2.6886	1.9044	1.773	2.5133	2.4646	2.5393
11	2.5133	2.7721	1.9791	1.8107	2.6139		
12	2.5019	2.6242	1.8484	1.8107	2.6886	2.4764	2.5873
13	2.3152	2.5133	1.8861	1.8107	2.6242	2.6981	2.5133
14	2.6242	2.5133	2.0748	1.773	2.5133	2.5503	2.5873
15	2.5503	2.5873	1.9239	1.8484	2.3152	2.5503	2.6242
16	2.4394	2.5503	1.9616	1.8107	2.4764	2.6612	2.4764
17	2.5019	2.5019	1.6221	1.8484	2.6337	2.5133	2.5873
18	2.5133	2.4394	1.6975	1.773	2.6337	2.5503	2.3525
19	2.3899		1.7924	1.773	2.5133	2.4394	2.3152
20	2.1502		1.773	1.7353	2.2546	2.1285	2.1125
21	1.9239	1.8671	1.7353	1.773	1.773	1.8107	1.8861
22	1.773	1.773	1.773	1.6975			1.9239
23	1.773	1.8671	1.7353	1.6975	1.773	1.7353	1.8484
24	1.7353	1.6598	1.6221	1.6598	1.6975	1.6975	1.6975
Max	2.6242	2.7721	2.0748	1.8484	2.6886	2.6981	2.6242
Min	1.5844	1.6221	1.5844	1.6221	1.6221	1.6598	1.6598
Avg	2.1014	2.1219	1.7754	1.7361	2.1483	2.1422	2.1295

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

AUNDH SUB-DN.[599] BU 4599

Substation No/ Name :- 213339 / 22/22 kv RMZ sstn

Feeder No / Name : 302 / Millenia - B

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6722	.6036	.6036	.6036	.5975	.6413	.6348
2	.7167	.6036	.6036	.6036	.6413	.6413	.6348
3	.6653	.6036	.5658	.6036	.6413	.6413	.6348
4	.6653	.6036	.5281	.6413	.5975	.6036	.6348
5	.6036	.6036	.6036	.6413	.5975	.6036	.5975
6	.6413	.6036	.6036	.6413	.6036	.6348	.6348
7	.679	.6413	.5658	.6036	.6413	.679	.679
8	.6722	.6413	.6348	.7095	.6722	.7167	.7095
9	.6036	.7167	.7095	.7095	.7468	.7167	.7095
10	.7545	.7167	.6348	.6036	.7095	.7468	.679
11	.7842	.679	.7167	.679	.7545		
12	.8131	.679	.7167	.679	.9335	.8589	.7095
13	.8501	.7762	.6036	.679	.8131	.7392	.7167
14	.7167	.8131	.6413	.679	.6722	.7842	.7095
15	.7468	.7545	.7468	.679	.679	.7167	.7468
16	.7842	.7922	.7468	.679	.7545	.7167	.7095
17	.7095	.7842	.7842	.679	.7095	.7468	.7095
18	.7842	.7468	.7023	.6653	.7095	.7167	.6722
19	.7545		.6653	.6413	.7167	.7167	.7095
20	.7468		.6722	.6413	.6413	.6413	.6413
21	.6036	.6036	.7095	.6413	.6036	.6413	.6413
22	.6036	.6036	.679	.6348			.6413
23	.6036	.6036	.6413	.6348	.6413	.6413	.6036
24	.6722	.6036	.6036	.6036	.6348	.6413	.6348
Max	.8501	.8131	.7842	.7095	.9335	.8589	.7468
Min	.6036	.6036	.5281	.6036	.5975	.6036	.5975
Avg	.7020	.6717	.6534	.6490	.6831	.6903	.6693

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

AUNDH SUB-DN.[599] BU 4599

Substation No/ Name :- 213339 / 22/22 kv RMZ sstn

Feeder No / Name : 304 / Amar apex Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2323	1.3443	1.2696	1.2826	1.3203	1.3817	1.3443
2	1.2449	1.2323	1.1949	1.2071	1.2826	1.3443	1.307
3	1.1458	1.1827	1.1949	1.1694	1.2071	1.307	1.2323
4	1.1088	1.1458	1.1576	1.0829	1.1317	1.1949	1.1694
5	1.0719	1.1088	1.1203	1.094	1.2071	1.2323	1.1949
6	1.2323	1.2696	1.1694	1.1694	1.2696	1.358	1.307
7	1.4335	1.3957	1.2449	1.1458	1.3957	1.3957	1.3957
8	1.773	1.6975	1.2567	1.2696	1.8484	1.8107	1.6975
9	2.1879	2.1502		1.419	2.1879	2.4143	2.1879
10	2.5274	2.7161		1.419	2.9801	2.6783	2.6406
11	2.7161	2.9801	1.8107	1.7353	3.131	2.8669	
12	2.8292	2.9801	2.0748	1.6975	3.131	2.8669	3.0178
13	2.8292	2.9047	1.773	1.5844	3.0178	2.8292	2.6406
14	2.7161	2.8669	1.6975	1.6598	2.9047	2.8292	2.7915
15	2.7161	2.9801	1.6598	1.6975	2.9047	2.7915	2.9047
16	2.8292	2.8669	1.6975	1.7353	3.0178	2.7915	2.9047
17	2.6783	2.8292	1.6598	1.773	2.9047	2.7538	2.9047
18	2.5652	2.6406	1.5466	1.6598	2.7161	2.7161	2.6029
19	2.4897		1.6221	1.6975	2.5652	2.5274	2.5274
20	2.452		1.8107	1.773	2.452	2.3765	2.4143
21	2.0748	2.0748	1.7353	1.6598	2.1125	2.0748	2.0748
22	1.8484	1.8107	1.5844	1.5844	1.8861	1.8107	1.8107
23	1.6221	1.5844	1.4563	1.4563	1.6975	1.6975	1.6598
24	1.3957	1.4712	1.4335	1.3443	1.3817	1.5089	1.4335
Max	2.8292	2.9801	2.0748	1.773	3.131	2.8669	3.0178
Min	1.0719	1.1088	1.1203	1.0829	1.1317	1.1949	1.1694
Avg	2.0300	2.0560	1.5077	1.4715	2.1522	2.1066	2.0506

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

AUNDH SUB-DN.[599] BU 4599

Substation No/ Name :- 213339 / 22/22 kv RMZ sstn

Feeder No / Name : 305 / kolte patil

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2641	.2641	.2195	.2641	.2641	.3018
2	.2263	.2641	.2641	.2614	.2641	.2641	.3018
3	.2641	.2241	.2263	.2241	.2641	.2641	.2641
4	.2641	.2218	.2263	.2263	.2263	.2641	.2641
5	.2641	.2218	.2241	.2263	.2263	.2218	.2641
6	.2614	.2614	.2641	.2641	.3018	.2614	.2957
7	.2987	.3018	.2587	.2218	.3018	.3018	.3018
8	.3395	.3395	.2641	.2641	.3395	.3018	.3395
9	.5601	.5281	.3395	.3018	.5601	.6348	.5281
10	.7095	.6722	.4527	.3018	.7762	.7316	.7392
11	.6722	.6653	.4527	.3395	.7842		
12	.7023	.6348	.4527		.7392	.7023	.7316
13	.6722	.6283	.415	.3395	.788	.7023	.695
14	.6722	.6653	.415	.3018	.6653	.6653	.724
15	.6653	.6653	.4527	.3018	.6584	.6348	.7392
16	.6653	.7392	.4527	.3018	.7316	.6653	.7023
17	.6283	.6653	.3772	.3018	.6653	.6878	.7316
18	.5975	.6447	.3772	.3018	.6516	.6584	.6584
19	.5228		.3772	.3395	.5281	.5228	.5601
20	.4527	.415	.3395	.3395	.415	.4854	.4527
21	.3772	.3772	.3395	.3395	.3772	.415	.415
22	.3395	.3395	.3395	.3018	.3395	.3395	.3395
23	.3018	.3018	.3018	.3018	.3018	.3395	.2987
24	.2614	.2641	.2641	.2641	.2641	.2987	.2641
Max	.7095	.7392	.4527	.3395	.788	.7316	.7392
Min	.2263	.2218	.2241	.2195	.2263	.2218	.2641
Avg	.4576	.4480	.3392	.2863	.4764	.4620	.4745

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

AUNDH SUB-DN.[599] BU 4599

Substation No/ Name :- 213339 / 22/22 kv RMZ sstn

Feeder No / Name : 306 / Felicita

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4335	1.5466	1.4335	1.5089	1.6221	1.5844	1.5466
2	1.358	1.5089	1.4335	1.4335	1.5844	1.5089	1.5089
3	1.2826	1.4712	1.358	1.3957	1.5089	1.4712	1.4712
4	1.358	1.4335	1.2826	1.3203	1.4335	1.3957	1.4335
5	1.358	1.4335	1.3336	1.3203	1.5844	1.4335	1.3957
6	1.5089	1.6221	1.358	1.3957	1.6598	1.6221	1.6975
7	1.773	1.7353	1.5466	1.5089	1.773	1.773	1.8107
8	1.773	1.8484	1.5466	1.5089	1.8484	1.9616	1.8107
9	2.2634	2.452	1.8484	1.7528	2.4143	2.5274	2.4143
10	2.8292	2.8669	1.358	1.9239	3.1367	2.9801	3.0178
11	3.131	3.2819	1.6975	2.2634	3.3234		
12	3.0556	3.2819	2.7915	2.3011	3.3234	3.2861	3.2861
13	3.0556	3.131	2.452	2.2634	8.2236	3.2487	3.062
14	3.131	3.2819	2.2257	2.3011	3.0994	3.1367	3.0994
15	3.062	3.2861	2.1879	2.1879	3.1367	3.1741	3.2114
16	2.9874	3.0247	2.0748	2.1502	3.2819	3.2065	3.2114
17	2.9127	3.1741	2.0748	2.1502	3.1687	3.0994	3.1741
18	2.8753	2.9199	1.9239	2.1502	3.0178	2.9199	2.9938
19	2.8669		2.452	2.4143	2.9801	3.0308	2.9127
20	2.9047		2.7161	2.5652	2.9047	2.9874	2.8753
21	2.5149	1.9993	2.5652	2.3765	2.5652	2.7161	2.5652
22	2.2257	2.1879	2.2257	2.2257			2.1879
23	1.9239	1.8107	1.9239	1.9239	1.9616	1.9993	1.8861
24	1.5242	1.6221	1.5466	1.6766	1.6975	1.6975	1.7353
Max	3.131	3.2861	2.7915	2.5652	8.2236	3.2861	3.2861
Min	1.2826	1.4335	1.2826	1.3203	1.4335	1.3957	1.3957
Avg	2.2962	2.3145	1.8899	1.9174	2.6630	2.3982	2.3612

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

AUNDH SUB-DN.[599] BU 4599

Substation No/ Name :- 213339 / 22/22 kv RMZ sstn

Feeder No / Name : 307 / AMAR EXPRESS

HV Express Feeder

Feeder KV- 22 / INCOMING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.8477	3.81	3.7723	3.7723	4.0741	4.0364	3.8855
2	3.8477	3.7723	3.4705	3.5082	3.7723	3.9609	3.81
3	3.8855	3.7346	3.0178	3.0178	3.0933	3.7346	3.7723
4	3.7723	3.5837	2.7538	2.4143	2.5652	3.5837	3.6969
5	3.6214	3.5837	2.3899	2.4143	2.6406	3.5082	3.5837
6	3.81	3.5837	3.3573	2.452	2.7538	3.7723	3.6969
7	3.9609	3.9609	3.8477	2.6029	4.3004	3.9232	4.0364
8	5.1303	5.168	3.8855	2.8669	3.3951	5.0926	5.3189
9	6.7147	6.9033		4.904	7.4314	7.3183	7.2805
10	7.7332	7.7332		4.6399	8.2991	7.9595	8.1482
11	7.3937	7.5823	5.6207	4.6399	8.4122	8.1859	
12	7.2428	7.9218	5.7339	4.9417	8.1859	8.0727	8.2613
13	7.62	7.8087	5.3944	4.8285	8.2236	8.035	8.1482
14	7.4691	4.5645	5.168	4.8285	8.2991	7.6578	7.9973
15	1.7353	5.9225		4.9417	8.0727	7.8841	7.5446
16	7.3937	7.6578	5.2812	5.0172	7.9973	7.7709	7.356
17	7.356	7.5823	5.1303	4.7154	7.9973	7.5823	7.6578
18	6.8279	7.0165	4.6776	4.6022	7.356	7.2051	7.4314
19	6.1111	3.4705	3.546	4.7908	6.4506	6.2997	6.2997
20	6.0734	.003	5.1303	5.2435	6.1488	6.1866	6.1111
21	5.6962	3.3196	5.1303	4.9417	5.8093	5.8471	5.9225
22	5.2435	4.7908	4.7154	4.9794	5.4698	3.5837	5.3944
23	4.7908	4.4513	4.4513	4.5645	4.904	5.0172	4.904
24	4.2627	4.225	3.8855	4.1495	4.1118	4.1118	4.2627
Max	7.7332	7.9218	5.7339	5.2435	8.4122	8.1859	8.2613
Min	1.7353	.003	2.3899	2.4143	2.5652	3.5082	3.5837
Avg	5.4808	5.0896	4.3028	4.1574	5.8235	5.8471	5.8487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

AUNDH SUB-DN.[599] BU 4599

Substation No/ Name :- 213346 / 22/11kv sanghavi nagar

Feeder No / Name : 201 / 11 kv Siddharth Nagar Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3921	.4108	.4108	.3018	.3361	.3361	.3018
2	.3921	.3921	.3772	.3018	.3018	.3206	.3018
3	.3921	.3734	.3734	.3018	.3018	.3174	.2641
4	.3734	.3734	.3734	.2641	.3361	.3174	.2987
5	.4108	.3921	.3772	.2614	.3395	.3361	.3018
6	.4668	.4294	.4108	.2987	.3584	.3361	.3395
7	.5041	.4854	.4668	.3361	.3584	.4108	.3547
8	.5041	.5228	.4715	.3921	.4338	.4294	.3961
9	.5788	.6535	.6348	.4481	.4854	.5228	.5041
10	.6535	.7282	.6535	.4481		.5415	.5601
11	.7545	.8215	.7282	.5228	.6348	.6535	.6535
12	.7167	.9149	.7282		.5975	.6722	.6722
13	.7095	.8589	.6722		.5415	.6161	.6161
14	.6161	.7842	.6161		.5601	.5601	.5601
15	.6602	.8215	.5975	.5975	.5975	.5601	.6348
16	.6722	.8402	.6161	.5041	.5975	.5601	.5975
17	.5975	.811	.6348	.5601	.6161	.5975	.6348
18	.6348	.7282	.5788	.5788	.5975	.5975	.6348
19	.6908	.679	.6535	.6722	.6722	.6161	.6722
20	.7095	.6602	.6722	.6535	.6722	.6535	.6348
21	.6348	.5788	.5788	.5228	.5415	.5415	.5847
22	.5601		.4715	.4481	.4481	.4715	.4854
23	.5041	.4668	.415	.3921	.3961	.3921	.4108
24	.4294	.4294	.4294	.3961	.3772	.3395	.3361
Max	.7545	.9149	.7282	.6722	.6722	.6722	.6722
Min	.3734	.3734	.3734	.2614	.3018	.3174	.2641
Avg	.5649	.6155	.5392	.4382	.4827	.4875	.4896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

AUNDH SUB-DN.[599] BU 4599

Substation No/ Name :- 213346 / 22/11kv sanghavi nagar

Feeder No / Name : 202 / 11 kv lokmangal Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0269	1.0456	.9709		1.0185	1.0082	1.0829
2	1.0269	1.0082	.9335		.9808	1.0082	1.0562
3	.9522	.9335	.8962		.9054	.9896	1.0082
4	.9522	.9522	.8589		.9808	.9335	1.094
5	.9335	.9522	.9054		1.0349	1.1694	1.1576
6	1.307	1.2136	.9808		1.0751	1.307	1.2071
7	1.4563	1.3256	1.1694		1.4377	1.4335	1.4335
8	1.3817	1.475	1.2637		1.358	1.419	1.5278
9	1.587	1.6244	1.5497		1.5684	1.587	1.6221
10	1.7364	1.7737	1.6617			1.7177	1.8298
11	1.6991	1.8858	1.8298		1.7364	1.7737	1.7551
12	1.7353	1.643	1.6804		1.6244	1.6057	1.6991
13	1.5497	1.643	1.6057		1.6057	1.6804	1.587
14	1.475	1.5497	1.6057		1.6244		1.5497
15	1.4712	1.6804	1.6244	1.6617	1.7177	1.531	1.5684
16	1.6057	1.6263	1.6244	1.475	1.8111	1.7364	1.6617
17	1.643	1.6244	1.4377		1.6804	1.643	1.6617
18	1.5123	1.587	1.475	1.363	1.6057	1.6244	1.6244
19	1.6244	1.6057	1.5684	1.5497	1.6244	1.6991	1.6991
20	1.6057	1.587	1.587	1.475	1.6804	1.6991	1.6991
21	1.4937	1.4712	1.4563	1.475	1.6057	1.587	1.5497
22	1.4377		1.2382	1.3817	1.4563	1.5089	1.419
23	1.307	1.1203	1.1949	1.1763	1.3256	1.2826	1.307
24	1.0642	1.1203	1.0642		1.0829	1.0456	1.1949
Max	1.7364	1.8858	1.8298	1.6617	1.8111	1.7737	1.8298
Min	.9335	.9335	.8589	1.1763	.9054	.9335	1.0082
Avg	1.3993	1.4108	1.3409	1.4447	1.4148	1.4343	1.4581

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

AUNDH SUB-DN.[599] BU 4599

Substation No/ Name :- 213346 / 22/11kv sanghavi nagar

Feeder No / Name : 203 / 11 kv Parihar chowk Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2427	.2614	.2427	.2614	.2641	.2641	.2614
2	.2427	.2427	.2263	.2614	.2614	.2801	.2641
3	.2427	.2427	.2054	.2241	.2263	.2614	.2641
4	.2427	.2427	.2075	.2075	.2241	.2641	.2614
5	.2427	.2614	.2241	.2075	.2641	.2614	.2641
6	.2801	.2614	.2452	.2075	.2641	.2801	
7	.3174	.3547	.2987	.2987	.3395	.3395	.3361
8	.3174	.3361	.2987	.3395	.3206	.3361	.3772
9	.3921	.4294	.4108	.3921	.3734	.4294	.4338
10	.6036	.6535	.5975	.3921		.6413	.6161
11	.6908	.7095	.8215	.5041	.7095	.6908	.6722
12	.7167	.8215	.8962		.7468	.7282	.6722
13	.7468	.8215	.7842		.7468	.6722	.6908
14	.7282	.7282	.7468		.6722	.6535	.6348
15	.7167	.7095	.7282	.6348	.6722	.6161	.6161
16	.6908	.6722	.6722	.5415	.6722	.5788	.6348
17	.5788	.5975	.5975	.4668	.5415	.5415	.5788
18	.6348	.5788	.5601	.5601	.5228	.5228	.5601
19	.6535	.5228	.5975	.6535	.5975	.5788	.5788
20	.6722	.5228	.6161	.6161	.5601	.6161	.6224
21	.5041	.4294	.5415	.4668	.4481	.5228	.5281
22	.3734		.3395	.3361	.3547	.3547	.3361
23	.3361	.2801	.3395	.3361	.3547	.3395	.3361
24	.2801	.2801	.2641	.3395	.2829	.3018	.3018
Max	.7468	.8215	.8962	.6535	.7468	.7282	.6908
Min	.2427	.2427	.2054	.2075	.2241	.2614	.2614
Avg	.4770	.4765	.4776	.3927	.4530	.4615	.4714

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

AUNDH SUB-DN.[599] BU 4599

Substation No/ Name :- 213346 / 22/11kv sanghavi nagar

Feeder No / Name : 205 / 11 kv Rohan Nilay HV Non-Express Feeder
Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0456	.9896	.9335	1.0456	1.1576	1.1694	1.0829
2	1.0082	.9896	.8962	1.0185	1.1203	1.1203	1.0082
3	.9149	.9709	.8589	.9808	1.094	1.0829	.8962
4	.9149	.9522	.8589	.9431	1.1576	1.0751	.9709
5	.9149	.9522	.8962	.9808	1.358	1.2323	1.1949
6	1.2136	1.1763	.9997	1.0374	1.358	1.3443	1.307
7	1.3443	1.3443	1.1016	1.1317	1.4712	1.5123	1.4937
8	1.4937	1.4563	1.2323	1.2637	1.3957	1.5123	1.4712
9	1.363	1.531	1.419	1.3817	1.5123	1.4563	1.5089
10	1.3817	1.419	1.6057	1.4003		1.5497	1.531
11	1.3443	1.4377	1.5497	1.4377	1.5684	1.4937	1.531
12	1.358	1.3443	1.5497		1.4377	1.4377	1.4563
13	1.251	1.1576	1.419		1.3817	1.307	1.3443
14	1.1389	1.0456	1.3256		1.2696	1.251	1.2696
15	1.1389	1.2136	1.307	1.5497	1.3256	1.3256	1.2883
16	1.1763	1.1016	1.2696	1.419	1.4377	1.3817	1.307
17	1.1203	1.1576	1.1763	1.3256	1.4003	1.363	1.2883
18	1.1389	1.226	1.1949	1.3443	1.363	1.307	1.1763
19	1.3443	1.3443	1.475	1.4563	1.5123	1.3817	1.4003
20	1.251	1.3817	1.643	1.5684	1.5497	1.587	1.5684
21	1.251	1.3957	1.5497	1.5684	1.531	1.5684	1.5497
22	1.475		1.5089	1.4937	1.5089	1.4712	1.4563
23	1.1389	1.0829	1.358	1.3443	1.3256	1.358	1.307
24	1.1576	1.1389	1.0082	1.2826	1.2637	1.2826	1.1949
Max	1.4937	1.531	1.643	1.5684	1.5684	1.587	1.5684
Min	.9149	.9522	.8589	.9431	1.094	1.0751	.8962
Avg	1.2033	1.2091	1.2557	1.2845	1.3696	1.3571	1.3168

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

AUNDH SUB-DN.[599] BU 4599

Substation No/ Name :- 213346 / 22/11kv sanghavi nagar

Feeder No / Name : 206 / L Square Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.1307	.0747	.0754	.1132	.1307	.1132
2	.112	.112	.0943	.0754	.0943	.132	.112
3	.0934	.112	.0747	.0747	.0934	.1307	.0934
4	.112	.112	.0754	.0747	.1132	.1132	.0943
5	.1307	.112	.0754	.0747	.112	.112	.112
6	.0934	.0934	.0934	.0934	.132	.112	.1307
7	.0934	.0934	.112	.1132	.0943	.132	.0747
8	.0747	.1307	.112	.0754	.112	.112	.132
9	.132	.1494	.1132	.0943	.1867	.1886	.1509
10	.132	.1509	.1494	.1132		.2263	.1867
11	.2054	.2054	.1867	.1132	.2614	.2452	.2614
12	.1886	.2054	.1886		.2614	.2829	.2427
13	.168	.1867	.1867		.2801	.2263	.2241
14	.2241	.2054	.1867		.2614	.2075	.2614
15	.1698	.1867	.1698	.1698	.2427	.2263	.2427
16	.1867	.1867	.168	.1698	.2614	.2427	.2054
17	.1867	.1867	.1698	.1886	.2427	.2054	.2241
18	.1494	.1494	.1494	.1509	.2241	.132	.2241
19	.1307	.1494	.1494	.1509	.2241	.1494	.2054
20	.1307	.1867	.1307	.1886	.168	.1494	.2241
21	.112	.1307	.1307	.1307	.168	.1867	.1886
22	.1494		.0943	.112	.1698	.168	.112
23	.1494	.0934	.112	.1132	.1509	.1132	.1494
24	.0934	.112	.0934	.0754	.1307	.132	.1307
Max	.2241	.2054	.1886	.1886	.2801	.2829	.2614
Min	.0747	.0934	.0747	.0747	.0934	.112	.0747
Avg	.1380	.1470	.1288	.1156	.1782	.1690	.1707

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

AUNDH SUB-DN.[599] BU 4599

Substation No/ Name :- 213346 / 22/11kv sanghavi nagar

Feeder No / Name : 301 / 22 kv chaitrali

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6722	.8589	.8215	.9431	.7545	.679	.8215
2	.5975	.7095	.6722	.5601	.679	.5975	.679
3	.5601	.5601	.5975	.5228	.6036	.5658	.6036
4	.5975	.5601	.5281	.5228	.5281	.5281	.5228
5	.5975	.5601	.5281	.5228	.5228	.5228	.5228
6	.5975	.5601	.5228	.5228	.5281	.5601	.5228
7	.6348	.5975	.5228	.5281	.5658	.5658	.6348
8	.9335	.9709	.7095	.7167	1.0562	.8962	1.0082
9	1.6804	1.7924	1.4937	1.2071	1.7177	1.9993	2.037
10	1.9791	1.9791	1.4937	1.2826		1.9791	1.9418
11	2.1658	2.2779	1.7177	1.2449	2.1285	2.1879	
12	2.3152	2.3899	1.9418		2.5019	2.452	2.3899
13	2.4272	2.3899	1.9791		2.3899	2.3765	2.3525
14	2.3525	2.3525	2.0165		2.4272	2.3765	2.3525
15	2.2032	2.3899	1.9418	1.6598	2.5019	2.452	2.2405
16	2.2032	2.4272	1.9044	1.6221	2.8006	2.5019	2.3525
17	2.3152	2.4272	1.7924	1.5844	2.3899	2.2779	2.3525
18	2.2405	2.3152	1.8298	1.5844	2.1658	2.1658	2.2405
19	2.2405	1.8671	1.7177	1.8861	2.1658	2.2405	2.1658
20	2.0538	1.7924	1.6804	1.8861	2.1285	2.0911	2.0911
21	1.8671	1.8484	1.531	1.4712	2.0538	1.8671	1.9791
22	1.4937		1.2696	1.0829	1.6057	1.419	1.3203
23	1.0829	1.0829	1.1203	1.0185	1.1203	1.0829	1.1576
24	.9709	1.0082	.8962	.9054	.8962	.8215	1.0082
Max	2.4272	2.4272	2.0165	1.8861	2.8006	2.5019	2.3899
Min	.5601	.5601	.5228	.5228	.5228	.5228	.5228
Avg	1.5326	1.5529	1.3012	1.1083	1.5753	1.5503	1.5347

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

AUNDH SUB-DN.[599] BU 4599

Substation No/ Name :- 213392 / Amar Paradigm

Feeder No / Name : 302 / Amar Paradigm Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1886	.1509	.1509	.1509	.1886
2	.1886	.1886	.1886	.1509	.1509	.1509	.1886
3	.1886	.1509	.1886	.1509	.1509	.1509	.1509
4	.1509	.1509	.1509	.1509	.1509	.1509	.1509
5	.1509	.1509	.1509	.1509	.1509	.1509	.1509
6	.1509	.1509	.1509	.1509	.1509	.1509	.1509
7	.1509	.1509	.1509	.1509	.1509	.1509	.1509
8	.3772	.3018	.1509	.1509	.1509	.3018	.3772
9	.5281	.5658	.1886	.1509		.679	.6413
10	.7167	.6036	.1886	.1509	.7545	.7545	.7545
11	.679	.7167	.2263	1.7353	.7922	.7545	.7922
12	.7167	.7167	.2263	.1509	.7922	.7922	.7545
13	.7167	.7167	.1886	.1509	.7922	.8299	1.8861
14	.7167	.679	.1886	.1509	.7922	.7545	.7922
15	.8676	.7167	.1886	.1509	.7545	.7545	.7167
16	.9054	.679	.1886	.1509	.7545	.7545	.7922
17	.679	.6413	.1886	.1509	.7545	.7167	.7922
18	.4904	.5281	.1886	.1509	.679	.6413	.7545
19	.3772	.3772	.1886	.1509	.415	.4527	.4904
20	.3772	.2263	.1509	.1509	.3018	.3395	.3772
21	.2263		.1509	.1509	.2641	.3018	.3018
22	.2263	.2263	.1509	.1509	.2263		.2263
23	.2263	.2263	.1509	.1509	.2263	.2263	.2263
24	.1886	.1886	.1886	.1509	.1509	.1509	.1886
Max	.9054	.7167	.2263	1.7353	.7922	.8299	1.8861
Min	.1509	.1509	.1509	.1509	.1509	.1509	.1509
Avg	.4244	.4018	.1776	.2169	.4199	.4461	.4998

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

AUNDH SUB-DN.[599] BU 4599

Substation No/ Name :- 213392 / Amar Paradigm

Feeder No / Name : 303 / D Mart

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3957	1.5089	1.3203	1.5089	1.6975	1.6975	1.4712
2	1.358	1.4335	1.3203	1.4335	1.6221	1.4335	1.4335
3	1.3203	1.358	1.3203	1.358	1.5089	1.4335	1.4335
4	1.3203	1.358	1.3203	1.358	1.5089	1.4335	1.4335
5	1.3203	1.358	1.3203	1.358	1.5089	1.4335	1.4335
6	1.3957	1.3957	1.3203	1.4335	1.5089	1.5089	1.4335
7	1.5466	1.5089	1.4712	1.4712	1.5844	1.5089	1.6598
8	1.6975	1.8861	1.5844	1.5844	1.5089	1.8861	1.8107
9	1.9993	2.1125	1.9616	1.7353		2.2257	2.1502
10	2.5652	2.6029	2.1125	1.8861	2.5652	2.4143	2.5652
11	2.3011	2.3765	2.2634	1.7353	2.6029	2.4897	2.3011
12	2.037	2.5274	2.2634	1.8861	2.5652	2.3011	2.4897
13	1.9993	2.4143	2.1125	1.8861	2.3765	2.4143	2.4143
14	2.037	2.1502	1.8861	1.8861	2.452	2.3011	2.3765
15	1.8107	2.5274	1.8861	2.0748	2.3388	2.1879	1.9616
16	2.1879	2.3388	2.2634	1.9616	2.2634	2.1125	1.9616
17	2.3388	2.3388	1.9993	1.8107	2.5652	2.452	2.1502
18	2.1879	2.2634	1.8107	1.7353	2.3011	2.1502	2.3011
19	2.1125	1.6221	1.9239	1.8861	2.3011	2.3388	2.2634
20	2.3011	1.8107	1.9616	2.1125	2.3011	2.2634	2.2634
21	2.1125		1.9616	2.1125	2.1502	2.1125	2.1879
22	1.9993	1.6221	1.6975	1.9993	1.9616		2.0748
23	1.7353	1.6975	1.6975	1.7353	1.8107	1.8484	1.8107
24	1.5466	1.6221	1.3957	1.5089	1.5844	1.7353	1.6598
Max	2.5652	2.6029	2.2634	2.1125	2.6029	2.4897	2.5652
Min	1.3203	1.358	1.3203	1.358	1.5089	1.4335	1.4335
Avg	1.8594	1.9058	1.7573	1.7274	2.0256	1.9862	1.9600

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

AUNDH SUB-DN.[599]

BU 4599

Substation No/ Name :- 213392 / Amar Paradigm

Feeder No / Name : 304 / Serenede and Iris

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0754	.0754	.0754	.0754	.0754	.0754
2	.0377	.0754	.0754	.0754	.0754	.0754	.0754
3	.0377	.0754	.0754	.0377	.0754	.0754	.0754
4	.0377	.0754	.0754	.0377	.0754	3.0933	.0754
5	.0377	.0754	.0754	.0377	.0754	.0754	.0754
6	.0754	.0754	.0754	.0754	.0754	.0754	.0754
7	.0754	.0754	.0754	.0754	.0754	.0754	.0754
8	.0754	.0754	.0754	.0754	.0754	.0754	.0754
9	.0754	.0754	.0754	.0754		.0754	.0754
10	.0732	.0754	.0754	.0754	.0754	.0754	.0754
11	.0377	.0754	.1132	.0754	.0754	.0754	.0754
12	.0377	.0754	.1132	.0754	.0754	.0754	.0754
13	.0754	.0754	.1132	.0754	.0754	.0754	.0754
14	.0754	.0377	.1132	.0754	.0754	.0754	.0754
15	.0754	.0754	.0754	.0754	.0754	.0754	.0754
16	.0754	.0754	.0754	.0754	.0754	.0754	.0754
17	.0754	.0754	.0754	.0754	.0754	.0754	.0754
18	.0754	.0754	.0754	.0754	.0754	.0754	.0754
19	.0754	.0754	.0754	.0754	.0754	.0754	.0754
20	.0754	.0754	.0754	.0754	.0754	.0754	.0754
21	.0754		.0754	.0754	.0754	.0754	.0754
22	.0754	.0754	.0754	.0754	.0754	.0754	.0754
23	.0754	.0754	.0754	.0754	.0754	.0754	.0754
24	.0754	.0754	.0754	.0754		.0754	.0754
Max	.0754	.0754	.1132	.0754	.0754	3.0933	.0754
Min	.0377	.0377	.0754	.0377	.0754	.0754	.0754
Avg	.0643	.0738	.0817	.0707	.0754	.2011	.0754

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

AUNDH SUB-DN.[599] BU 4599

Substation No/ Name :- 213392 / Amar Paradigm

Feeder No / Name : 305 / amar apex Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5285	.5487	.5487	.5487	.6001	.4024	.4443
2	.5007	.4938	.4938	.4938	.5716	.3841	.3734
3	.5007	.4938	.4938	.5144	.5144	.3841	.3734
4	.5007	.4938	.4938	.5144	.5144	.3658	.3734
5	.5007	.4938	.4938	.5144	.5144	.3658	.3734
6	.5285	.5761	.5213	.5144	.5716	.3658	.3734
7	.6398	.6584	.5487	.5761	.6859	.4024	.4668
8	.6954	.7407	.6036	.5761	.6573	.4755	.4854
9	.7133	.7407	.6584	.6036		.5857	.9808
10	.823	.8779		.7133	1.2826	.7773	1.2449
11	.8779	.8505	.8505	.7407	1.2826	.8002	1.2071
12	.8505	.8505	.7682	.7682	1.2071	.7087	1.2071
13	.8505	.7956	.7956	.7133	1.1317	.7087	1.2071
14	.7682	.823	.823	.743	1.094	.756	1.1317
15	.7956	.8779	.823	.743	.7468	.7796	1.1694
16	1.094	1.1317	1.0185	.8002	.7438	.9431	
17	1.1317	1.2826	.9431	.8002	.767	.9431	
18	1.1317	1.2071	.9808	.743	.7438	.9145	
19	1.2071	1.0562	1.0562	.8002	.767		
20	1.2071		.7956	.8573	.7903	.9431	
21	1.2071		.7956	.8288	.7316	.6851	
22	.823	.7682	.7956	.7716	.6497	.5525	
23	.6859	.6584	.6859	.7145	.5041	.535	
24	.5841	.6036	.5761	.6036	.6287	.4572	.4847
Max	1.2071	1.2826	1.0562	.8573	1.2826	.9431	1.2449
Min	.5007	.4938	.4938	.4938	.5041	.3658	.3734
Avg	.7977	.7738	.7202	.6749	.7696	.6189	.7435

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

AUNDH SUB-DN.[599]

BU 4599

Substation No/ Name :- 213392 / Amar Paradigm

Feeder No / Name : 306 / Unity Infra

HV Non-Express Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.5837	3.7723	3.5837	3.7723	3.7723	3.8477	3.81
2	3.5837	3.5837	3.3951	3.5837	3.7723	3.6214	3.6969
3	3.3951	3.3951	3.3951	3.3951	3.5837	3.5082	3.5837
4	3.3951	3.3951	3.2065	3.2065	3.5837	3.4705	3.4705
5	3.5837	3.5837	3.2065	3.2065	3.5837	3.4705	3.4705
6	3.7723	3.7723	3.2065	3.3951	3.7723	3.6214	3.6969
7	4.1495	4.3381	3.3951	3.3951	3.9609	3.9609	4.225
8	4.7154	4.7154	3.7723	3.7723	4.1495	4.4513	4.7908
9	5.4698	5.4321	4.7154	4.1495		5.2812	5.5076
10	5.6962	5.8471	5.4321	4.7154	6.1866	5.9602	6.0357
11	5.6207	5.4698	5.3567	4.7154	5.8471	5.6962	5.6584
12	5.5076	5.6207	5.2058	4.5268	5.4698	5.583	5.6584
13	5.3189	5.3944	5.0172	4.5268	5.583	5.3944	5.3567
14	5.1303	5.0926	4.6399	4.5268	5.1303	5.0549	4.9794
15	5.2058	5.2058	4.6776	4.3381	5.2812	5.0549	5.2812
16	3.1687	5.0549	4.6776	4.3381	5.3944	5.4698	5.4698
17	3.131	5.2058	4.5268	4.3381	5.5076	5.0926	5.2812
18	4.3759	4.9794	4.4513	3.1436	4.8285	4.904	5.0926
19	4.1495	3.9986	4.4513	3.1436	4.9417	4.904	5.0926
20	5.1303	4.6776	4.6022	4.7154	5.3189	4.904	5.2812
21	4.8285		4.5268	4.7154	4.9417	4.904	5.0172
22	4.7154	4.3381	4.5268	4.5268	4.7908	4.7531	4.7908
23	4.3381	3.9609	4.1495	4.3381	4.4513	4.3381	4.3381
24	3.7723	3.9609	3.7723	3.9609	3.9609	4.0741	4.0364
Max	5.6962	5.8471	5.4321	4.7154	6.1866	5.9602	6.0357
Min	3.131	3.3951	3.2065	3.1436	3.5837	3.4705	3.4705
Avg	4.4057	4.5563	4.2454	4.0186	4.6875	4.6384	4.7342

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

AUNDH SUB-DN.[599] BU 4599

Substation No/ Name :- 213392 / Amar Paradigm

Feeder No / Name : 308 / Balewadi Properties Urban/Sheddable Urban Feeder
Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2955	1.1431	1.1431	1.0288	1.105	1.0669	1.1431
2	1.2193	1.0669	1.0288	.9526	1.0669	1.0288	1.0288
3	1.2193	.9907	1.0288	.9526	1.0669	1.0288	1.0288
4	1.2193	.9907	1.0288	.9526	1.0669	1.0288	1.0288
5	1.2193	.9907	1.0288	.9526	1.1431	1.0288	1.0288
6	1.2193	1.0288	1.0288	.9526	1.2193	1.0288	1.0288
7	1.0288	1.105	1.0669		1.448	1.0288	1.0288
8	1.5623	1.829	.9907			1.6766	2.0576
9	2.7816	2.8959	1.1431	1.7147		3.0864	3.131
10	2.7816	2.7054	1.2574	1.1812	3.2769	3.0483	3.1626
11	2.8959	2.8959	1.5242	1.3336	3.2769	3.2007	3.1245
12	2.9721	3.1245	1.6766	1.448	3.4294	3.2388	3.3532
13	3.4294	3.2388	1.5623	1.5242	3.5056	3.2769	3.4294
14	3.315		1.7528	1.5242	3.5818	3.0102	3.4294
15		1.1812	1.6766	1.5242	3.315	3.2769	3.2388
16	3.0483	3.0933	1.5242	1.5623	3.3913	3.0483	3.3532
17	2.9047	3.0178	1.5623	1.4098	3.0864	2.8959	3.1245
18	2.5652	2.6406	1.4098	1.3717	2.9721	2.7435	2.8578
19	2.0957	.0754		1.4098	2.0957	2.0195	2.0957
20	1.9433	.0754	1.448	1.5242	1.9433	1.9433	1.9433
21	1.829		1.5242	1.4861	1.829	1.8671	1.8671
22	1.6385	1.6385	1.5242	1.448	1.7147		1.829
23	1.5242	1.3717	1.4098	1.448	1.6004	1.4861	1.5242
24	1.6004	1.2955	1.2955	1.2955	1.2574	1.3336	1.2574
Max	3.4294	3.2388	1.7528	1.7147	3.5818	3.2769	3.4294
Min	1.0288	.0754	.9907	.9526	1.0669	1.0288	1.0288
Avg	2.0569	1.7452	1.3320	1.3181	2.1996	2.1040	2.1706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

AUNDH SUB-DN.[599] BU 4599

Substation No/ Name :- 213392 / Amar Paradigm

Feeder No / Name : 309 / 43 privet drive

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1905	.1905	.2286	.1905	.1905
2	.1905	.1905	.1905	.1905	.1905	.1905	.1905
3	.1905	.1905	.1905	.1905	.1905	.1905	.1905
4	.1905	.1905	.1905	.1905	.1905	.1905	.1905
5	.1905	.1905	.1905	.1905	.1905	.1905	.1905
6	.1905	.1905	.1905	.1905	.1905	.1905	.1905
7	.1905	.1905	.1905	.1905	.1905	.2286	.1905
8	.1905	.2286	.2286	.1905	.2286	.2667	.2286
9	.2667	.2667	.2286	.2286		.2667	.2641
10	.3048	.3429	.3429	.2667	.3395	.3429	.3395
11	.3429	.3429	.3429	.2667	.3772	.381	.3018
12	.3048	.3048	.3429	.3048	.3018	.3429	.3395
13	.2667	.3048	.2667	.2667	.3395	.3048	.3018
14	.3048	.2667	.2667	.2667	3.546	.3048	.3018
15	.2667	.3048	.3048	.2667	.3048	.3429	.3395
16	.2641	.3395	.3018	.2667	.3429	.3048	.3048
17	.3018	.3018	.2641	.2667	.3429	.2667	.3048
18	.3018	.3395	.2263	.2667	.3048	.2667	.3048
19	.2641	.2641	.2263	.2667	.3048	.2667	.1524
20	.2641	.2641	.2667	.2667	.3048	.2667	.1524
21	.2641		.2667	.2667	.2667	.2667	.2667
22	.2286	.2286	.2286	.2667	.2667	.2667	.1524
23	.2286	.1905	.2286	.2286	.2286	.2286	.2286
24	.1905	.1905	.1905	.2286	.2286	.1905	.2286
Max	.3429	.3429	.3429	.3048	3.546	.381	.3395
Min	.1905	.1905	.1905	.1905	.1905	.1905	.1524
Avg	.2454	.2528	.2441	.2381	.4087	.2604	.2436

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

AUNDH SUB-DN.[599] BU 4599

Substation No/ Name :- 213392 / Amar Paradigm

Feeder No / Name : 310 / BizBay Urban/Sheddable Urban Feeder
Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0732	.0732		
10	.0362		.0366			.0762	
11	.0366	.0366	.0366		.0377	.0762	
12	.0366	.0366	.0366	.0503	.0377	.0762	.0377
13	.0366	.0366	.0366	.0732	.0754	.0762	
14	.0366	.0366	.0732	.0732	.3018	.0762	
15	.0732		.0732	.0732	.0762	.0762	
16	.0754		.0754	.0732	.0762	.0732	
17	.0754		.0754	.0732	.0762	.0732	
18	.0754		.0754	.0732	.0762	.0732	.0732
19	.0754	.0754	.0754	.0732	.0762	.0732	.0732
20	.0754	.0754	.0732	.0732	.0762	.0732	.0732
21	.0754		.0732	.0732	.0762	.0762	.0762
22	.0732	.0732	.0732	.0732	.0762	.0762	.0762
23	.0732	.0732	.0732	.0732	.0762	.0762	.0762
24	.0724	.0732	.0732	.0732	.0732	.0762	.0762
Max	.0754	.0754	.0754	.0732	.3018	.0762	.0762
Min	.0362	.0366	.0366	.0503	.0377	.0732	.0377
Avg	.0618	.0574	.0640	.0716	.0857	.0752	.0703

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

GANESH KHIND SUB-DN.[598] BU 4598

Substation No/ Name :- 213308 / ICC 22/11 S/S

Feeder No / Name : 201 / Crossword

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1886	.0943	.1886	.1886	.1886
2	.1886	.1886	.1886	.0943	.1886	.1886	.1886
3	.1886	.1886	.1886	.0943	.1886	.1886	.1886
4	.1886	.1886	.1886	.0943	.1886	.1886	.1886
5	.1886	.1886	.1886	.0943	.1886	.1886	.1886
6	.1886	.1886	.1886	.0943	.1886	.1886	.1886
7	.1886	.1886	.1886	.0943	.1886	.2829	.1886
8	.2829	.2829	.2829	.1886	.3772	.2829	.2829
9	.5658	.5658	.4715	.1886	.5658	.5658	.5658
10	.8488	.8488	.6602	.2829	1.0374	.9431	.8488
11	.9431	.9431	.5658	.2829	1.0374	.9431	.9431
12	.9431	.9431	.7545	.3772	.9431	.8488	.8488
13	.8488	.8488	.7545	.3772	.8488	.8488	.7545
14	.7545	.7545	.6602	.3772	.9431	.8488	.7545
15	.9431	.9431	.6602	.3772		.8488	.9431
16	.9431	.9431	1.6975	.2829	.9431	.8488	.8488
17	.8488	.6602	.6602	.2829	.9431	.9431	.8488
18	.7545	.8488	.6602	.2829	.8488	.8488	.7545
19	.6602	.7545	.4287	.2829	.6602	.7545	.6602
20	.5658	.5658	.4715	.1886	.5658	.6602	.5658
21	.4715	.4715	.4715	.1886	.4715	.5658	.5658
22	.2829	.2829	.2829	.1886	.2829	.3772	.2829
23	.1886	.1886	.1886	.1886	.1886	.1886	.1886
24	.1886	.1886	.1886	.1886	.1886	.1886	.1886
Max	.9431	.9431	1.6975	.3772	1.0374	.9431	.9431
Min	.1886	.1886	.1886	.0943	.1886	.1886	.1886
Avg	.5148	.5148	.4658	.2161	.5289	.5383	.5069

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

GANESH KHIND SUB-DN.[598] BU 4598

Substation No/ Name :- 213308 / ICC 22/11 S/S

Feeder No / Name : 202 / ashanagar

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3772	.3772	.3772	.3772	.3772	.3772
2	.3772	.3772	.3772	.3772	.3772	.3772	.3772
3	.3772	.3772	.3772	.3772	.3772	.3772	.3772
4	.3772	.3772	.3772	.3772	.3772	.3772	.3772
5	.3772	.3772	.3772	.3772	.3772	.3772	.3772
6	.4715	.5658	.4715	.4715	.4715	.4715	.4715
7	.4715	.4715	.4715	.4715	.5658	.5658	.5658
8	.6602	.5658	.5658	.4715	.6602	.6602	.6602
9	.7545	.7545	.5658	.5658	.7545	.7545	.7545
10	.8488	.7545	.6602	.4715	.8488	.8488	.8488
11	.8488	.8488	.6602	.4715	.9431	.8488	.8488
12	.7545		.6602	.4715	.8488	.8488	.8488
13	.8488	.8488	.5658	.5658	.8488	.8488	.8488
14	.7545	.6602	.6602	.4715	.8488	.8488	.7545
15	.8488	.7545	.5658	.4715		.8488	.7545
16	.7545	.8488	.5658	.4715	.8488	.8488	.8488
17	.7545	.8488	.5658	.4715	.7545	.8488	.8488
18	.6602	.7545	.4715	.4715	.7545	.7545	.7545
19	.6602	.6602	.4715	.4715	.6602	.6602	.7545
20	.6602	.6602	.5658	.5658	.7545	.7545	.7545
21	.5658	.6602	.5658	.4715	.5658	.6602	.6602
22	.5658	.4715	.5658	.4715		.5658	.5658
23	.4715	.4715	.4715	.4715	.4715	.4715	.4715
24	.3772	.4715	.4715	.4715	.3772	.4715	.4715
Max	.8488	.8488	.6602	.5658	.9431	.8488	.8488
Min	.3772	.3772	.3772	.3772	.3772	.3772	.3772
Avg	.6091	.6069	.5187	.4636	.6302	.6444	.6405

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

GANESH KHIND SUB-DN.[598] BU 4598

Substation No/ Name :- 213308 / ICC 22/11 S/S

Feeder No / Name : 203 / ICC Plot A

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2858	.2858	.2858	.2858	.2858	.2858
2	.2858	.2858	.2858	.2858	.2858	.2858	.2858
3	.2858	.2858	.2858	.2858	.2858	.2858	.2858
4	.2858	.2858	.2858	.2858	.2858	.2858	.2858
5	.2858	.2858	.2858	.2858	.2858	.2858	.2858
6	.2858	.2858	.2858	.2858	.2858	.2858	.2858
7	.2858	.381	.2858	.2858	.381	.381	.2858
8	.4763	.4763	.2858	.2858	.6668	.4763	.4763
9	.5716	.6668	.381	.2858	.7621	.8573	.8573
10	.8573	.8573	.4763	.2858	.9526	.8573	.8573
11	.9526	.9526	.4763	.381	1.0479	.9526	.9526
12	1.0479	.9526	.5716	.381	1.1431	.9526	
13	1.0479	.9526	.5716	.381	1.0479	1.0479	.9526
14	1.0479	.9526	.4763	.381	1.0479	1.0479	.9526
15	1.0479	1.0479	.5716	.381	1.0479	.6668	.9526
16	.9526	.9526	.4763	.381	1.0479	.9526	.9526
17	.8573	.9526	.4763	.381		.9526	.9526
18	.7621	.8573	.381	.2858	.8573	.8573	.8573
19	.7621	.6668	.381	.2858	.8573	.8573	.8573
20	.5716	.6668	.381	.2858	.7621	.7621	.7621
21	.4763	.4763	.2858	.2858	.5716	.5716	.4763
22	.381	.381	.2858	.2858	.4763	.4763	.381
23	.381	.381	.2858	.2858	.381	.381	.381
24	.381	.381	.2858	.2858	.2858	.2858	.2858
Max	1.0479	1.0479	.5716	.381	1.1431	1.0479	.9526
Min	.2858	.2858	.2858	.2858	.2858	.2858	.2858
Avg	.6073	.6112	.3771	.3136	.6544	.6271	.6047

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

GANESH KHIND SUB-DN.[598] BU 4598

Substation No/ Name :- 213308 / ICC 22/11 S/S

Feeder No / Name : 204 / ICC Plot C

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.381	.381	.381	.381	.381
2	.381	.381	.381	.381	.381	.381	.381
3	.381	.381	.381	.381	.381	.381	.381
4	.381	.381	.381	.381	.381	.381	.381
5	.381	.381	.381	.381	.381	.381	.381
6	.381	.381	.381	.381	.381	.381	.381
7	.381	.4763	.381	.381	.4763	.4763	.4763
8	.4763	.5716	.4763	.381	.5716	.5716	.5716
9	.5716	.6668	.4763	.4763	.6668	.6668	.7621
10	.9526	.8573	.6668	.4763	1.0479	.9526	.9526
11	.8573	.8573	.4763	.4763	.9526	.9526	.9526
12			.5716	.4763	.9526	1.0479	.9526
13	.8573	.8573	.6668	.5716	1.0479	.9526	.9526
14	.8573	.8573	.5716	.4763	1.0479	1.0479	.9526
15	.9526	.9526	.6668	.4763		1.0479	.9526
16	.9526	.8573	.5716	.4763	.9526	.9526	.9526
17	.8573	.8573	.5716	.4763	.9526	.8573	.9526
18	.8573	.7621	.5716	.4763	.9526	.8573	.8573
19	.7621	.7621	.4763	.4763	.7621	.7621	.7621
20	.5716	.4763	.4763	.4763	.5716	.6668	.6668
21	.4763	.4763	.381	.381	.4763	.5716	.4763
22	.4763	.381	.381	.381	.4763	.4763	.4763
23	.381	.381	.381	.381	.4763	.4763	.4763
24	.381	.381	.381	.381	.381	.381	.381
Max	.9526	.9526	.6668	.5716	1.0479	1.0479	.9526
Min	.381	.381	.381	.381	.381	.381	.381
Avg	.6047	.5964	.4763	.4326	.6544	.6668	.6589

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

GANESH KHIND SUB-DN.[598] BU 4598

Substation No/ Name :- 213308 / ICC 22/11 S/S

Feeder No / Name : 205 / Pyramid

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0566	.3772	.0566	.0566	
2	.0566	.0566	.0377	.2829	.0377	.0566	
3	.0377	.0377	.0377	.1886	.0566	.0377	
4	.0377	.0377	.0377	.0377	.0377	.0377	
5	.0377	.0377	.0377	.0566	.0377	.0566	
6	.0566	.0943	.0566	.0566	.0377	.0566	
7	.0754	.0566	.0566	.0566	.0566	.0566	.0943
8	.3772	.132	.0566	.0566	.0943	.0943	.0943
9	.3772	.1132	.0754	.0754	.0943	.1886	.0943
10	.3772	.1886	.1886	.1886	.1886	.1886	.1886
11	.1886	.1886	.2829	.3772	.2829	.4715	.1886
12	.4715	.3772	.5658	.3772	.4715	.4715	
13	.4715	.4715	.5658	.3772	.3772	.5658	.2829
14	.4715	.4715	.5658	.2829	.2829	.5658	.4715
15	.4715	.2829	.2829	.3772		.2829	.4715
16	.2829	.2829	.2829	.3772	.4715	.4715	.2829
17	.2829	.2829		.3772	.2829	.4715	.4715
18	.3772	.3772	.4715	.3772	.2829	.2829	.1886
19	.3772	.2829	.4715	.3772	.3772	.4715	.4715
20	.4715	.1886	.3772	.3772	.4715	.4715	.2829
21	.2829	.2829	.4715	.3772	.3772	.3772	.3772
22	.1886	.3772	.3772	.3772	.3772	.1886	.1886
23	.1886	.3772	.3772	.3772	.3772	.0943	.0943
24	.0943	.1886	.0943	.1886	.0943	.0943	.0943
Max	.4715	.4715	.5658	.3772	.4715	.5658	.4715
Min	.0377	.0377	.0377	.0377	.0377	.0377	.0943
Avg	.2546	.2185	.2534	.2656	.2271	.2546	.2552

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

GANESH KHIND SUB-DN.[598] BU 4598

Substation No/ Name :- 213308 / ICC 22/11 S/S

Feeder No / Name : 206 / Gokhale Nagar

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2936	1.2936	1.2936	1.2936	1.2936	1.2936	1.2936
2	1.2936	1.2936	1.2936	1.2936	1.2936	1.2936	1.2936
3	1.2936	1.2936	1.2936	1.2936	1.2936	1.2936	1.2936
4	1.2936	1.2936	1.2936	1.2936	1.2936	1.2936	1.2936
5	1.2936	1.2936	1.2936	1.2936	1.2936	1.2936	1.4784
6	1.6632	1.6632	1.5708	1.4784	1.6632	1.7556	1.6632
7	1.7556	1.848	1.6632	1.5708	1.848	1.848	1.848
8	1.7556	1.848	1.7556	1.5708	1.848	1.848	1.848
9	1.7556	1.848	1.7556	1.7556	1.848	1.8861	1.7556
10	1.6632	1.6632	1.6632	1.7556	1.6632	1.6632	
11	1.5708	1.6632	1.5708	1.7556	1.5708	1.5708	1.5708
12	1.4784		1.5708	1.6632	1.5708	1.386	
13	1.386	1.4784	1.5708	1.4784	1.4784	1.4784	1.4784
14	1.386	1.386	1.386	1.4784	1.386	1.386	1.386
15	1.2936	1.386	1.386	1.4784		1.386	1.386
16	1.2936	1.386	1.386	1.4784	1.386	1.2936	1.386
17	1.386	1.5708	1.4784	1.5708	1.5708	1.4784	1.4784
18	1.6632		1.6632	1.7556	1.5708	1.5708	1.5708
19	1.6632	1.7556	1.848	1.7556	1.848	1.7556	1.7556
20	1.9404	1.9404	2.0328	2.0328	2.0328	2.0328	2.0328
21	1.9404	1.848	1.9404	2.0328	1.9404	1.9404	1.9404
22	1.848	1.7556	1.848	1.848		1.848	1.848
23	1.7556	1.5708	1.6632	1.6632	1.7556	1.6632	1.7556
24	1.386	1.4784	1.386	1.4784	1.4784	1.5708	1.4784
Max	1.9404	1.9404	2.0328	2.0328	2.0328	2.0328	2.0328
Min	1.2936	1.2936	1.2936	1.2936	1.2936	1.2936	1.2936
Avg	1.5439	1.5708	1.5670	1.5862	1.5876	1.5762	1.5834

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

GANESH KHIND SUB-DN.[598] BU 4598

Substation No/ Name :- 213308 / ICC 22/11 S/S

Feeder No / Name : 207 / Hotel Merriott

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	1.1317	1.226	1.226	1.1317	1.1317	1.4146
2	1.0374	1.1317	1.226	1.226	1.1317	1.1317	1.4146
3	1.0374	1.1317	1.226	1.226	1.1317	1.1317	1.3203
4	1.0374	1.1317	1.1317	1.226	1.1317	1.1317	1.3203
5	1.0374	1.1317	1.1317	1.226	1.1317	1.1317	1.3203
6	1.0374	1.1317	1.1317	1.226	1.1317	1.1317	1.4003
7	1.0374	1.3203	1.1317	1.226	1.1317	1.3203	1.307
8	1.226	1.4146	1.6032	1.5089	1.3203	1.4146	1.307
9	1.226	1.3203	1.6032	1.6032	1.3203	1.4146	1.307
10	1.226	1.4146	1.6032	1.6032	1.226	1.3203	1.587
11	1.6032	1.5089	1.6975	1.6032	1.226	1.5089	1.4003
12	1.226	1.226	1.7918	1.6032	1.226	1.6032	1.4003
13	1.226	1.4146	1.6975	1.6032	1.6032	1.4146	1.587
14	1.3203	1.5089	1.6975	1.5089	1.6032	1.4146	1.4937
15	1.6975	1.6032	1.7918	1.6032		1.6975	1.587
16	1.6032	1.6032	1.6975	1.6032	1.6032	1.6032	1.4937
17	1.6032	1.6975	1.6032	1.6032	1.7918	1.7918	1.6804
18	1.7918	1.7918	1.1317	1.3717	1.6975	1.6975	1.6804
19	1.6975	1.5089	1.7918	1.7918	1.7918	1.7918	1.6804
20	1.6032	.9431	1.6975	1.6032	1.6975	1.8861	1.6804
21	1.7918	1.7918	1.6032	1.4146	1.6975	1.6975	1.7737
22	1.6975	1.6032	1.6975	1.4146	1.5089	1.7918	1.7737
23	1.5089	1.4146	1.6032	1.4146	1.5089	1.3203	1.4937
24	1.3203	1.226	1.226	1.5089	1.226	1.3203	1.226
Max	1.7918	1.7918	1.7918	1.7918	1.7918	1.8861	1.7737
Min	1.0374	.9431	1.1317	1.226	1.1317	1.1317	1.226
Avg	1.3635	1.3792	1.4893	1.4560	1.39	1.4500	1.4854

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

GANESH KHIND SUB-DN.[598] BU 4598

Substation No/ Name :- 213350 / 22/11KV Sus Road

Feeder No / Name : 201 / Vardayini

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.703	.7973	.7362	.8063	.8322	.7716	.8322
2	.6859	.7537	.6935	.7537	.7888	.7209	.8059
3	.6762	.7202	1.5947	.7108	.763	.7209	.7545
4	.6762	.703	.6687	.6859	.7461	.7202	.7377
5	.7888	.7373	.7282	.7202	.7802	.7455	.7716
6	.9922	.964	.8322	.7888	.9214	1.0099	.9568
7	1.2403	1.2357	.9568	.9536	1.182	1.267	1.2178
8	1.2851	1.1888	1.0679	1.0166	1.1641	1.1765	1.182
9	1.2127	1.2254	1.2437	1.0631		1.1946	1.267
10	1.1104	1.1706	1.2803	1.2127		1.2308	1.1283
11	.1478	1.0745	1.267	1.1999	1.1283	1.0454	1.1104
12	.1307	1.0631	1.1462	1.2178	1.0631	1.0277	1.0099
13	.1307	.964	.9991	1.134	.9709	.9745	.8859
14	1.251	.8764	.9671	.9671	.9036	.8764	.8589
15	.9362	.8063	.8954	.9492	.8505	.815	.7619
16	.9492	.8326	.9412	.9492	.7796	.7701	.815
17	.8859	.8328	.9214	.9492	.9036	.8596	.8238
18	.8682	.8669	.9816	.9922	.9602	.8987	.8495
19	1.1043	1.0608	1.0692	1.1694	1.0288	1.0513	.9774
20	1.2226	1.0974	1.1517	1.2536	1.1789	1.1963	1.1568
21	1.2178	1.1269	1.134	1.2489	1.1616	1.1789	1.1999
22	1.1584		1.0566	1.1283			1.1462
23	.985	.9036	.9922	1.0631	1.0277	1.0277	1.0387
24	.7975	.8505	.7888	.8682	.8764	.8939	.9036
Max	1.2851	1.2357	1.5947	1.2536	1.182	1.267	1.267
Min	.1307	.703	.6687	.6859	.7461	.7202	.7377
Avg	.8815	.9501	1.0047	.9917	.9529	.9641	.9663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

GANESH KHIND SUB-DN.[598] BU 4598

Substation No/ Name :- 213350 / 22/11KV Sus Road

Feeder No / Name : 202 / Bhagwati Nagar

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2637	1.3203	1.226	1.2637	1.1949	1.307	1.2449
2	1.2637	1.2826	1.1694	1.226	1.1203	1.2826	1.226
3	1.2449	1.2637	1.1317	1.2071	1.1016	1.226	1.1883
4	1.2071	1.2449	1.094	1.1317	1.0269	1.2136	1.1694
5	1.1883	1.2071	1.094	1.0751	1.0269	1.094	1.1506
6	1.1883	1.226	1.1128	1.0751	1.1389	1.1506	1.3443
7	1.2637	1.2071	1.1128	1.1506	1.1389	1.1506	1.251
8	1.2826	1.3203	1.2449	1.094	1.251	1.3203	1.251
9	1.4335	1.4712	1.3392	1.1883		1.4563	1.4377
10	1.6032	1.6975	1.3769	1.2071		1.3443	1.6244
11	1.5466	1.6221	1.4335	1.226	1.6244	1.3443	1.587
12	1.5123	1.5684	1.3443	1.1694	1.587	1.2883	1.5123
13	1.2136	1.419	1.2136	1.1694	1.4377	1.2323	1.4003
14	1.1949	1.643	1.4937	1.1128	1.6617	1.4937	1.4146
15		1.6804	1.4937	1.1506	1.7177	1.6991	1.4937
16	1.2637	1.7737	1.3014	1.3392	1.7551	1.6617	1.6991
17	1.7177	1.7364	1.2883	1.2637	1.7737	1.6617	1.6804
18	1.6804	1.6448	1.0185	1.3203	1.6804	1.6263	1.6632
19	1.5497	1.4003	1.0562	1.3957	1.251	1.5123	1.4937
20	1.5466	1.4563	1.2637	1.4712	1.2637	1.2449	1.3014
21	1.5089	1.4377	1.2637	1.4335	1.3014	1.2883	1.3203
22	1.4523		1.4146	1.226			1.2826
23	1.4335	1.3392	1.3957	1.1389	1.1883	1.2449	1.3769
24	1.3443	1.358	1.2826	1.3392	1.2323	1.3256	1.3203
Max	1.7177	1.7737	1.4937	1.4712	1.7737	1.6991	1.6991
Min	1.1883	1.2071	1.0185	1.0751	1.0269	1.094	1.1506
Avg	1.3871	1.4487	1.2569	1.2239	1.3559	1.3552	1.3931

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

GANESH KHIND SUB-DN.[598] BU 4598

Substation No/ Name :- 213350 / 22/11KV Sus Road

Feeder No / Name : 203 / Balaji Mandir

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2308	1.3535	1.2254	1.3491	1.3032	1.3575	1.3213
2	1.2127	1.2803	1.1765	1.2936	1.2536	1.3073	1.2894
3	1.1641	1.2382	1.1222	1.2071	1.2357	1.2894	1.2536
4	1.182	1.1827	1.1523	1.1584	1.2127	1.3032	1.267
5	1.3032	1.2197	1.2071	1.2127	1.2437	1.3213	1.2803
6	1.4998	1.4415	1.3306	1.3032	1.4632	1.448	1.4415
7	1.6078	1.7002	1.3676	1.39	1.5729	1.6827	1.7002
8	1.8107	1.8484	1.5684	1.4449	1.6095	1.922	1.6817
9	1.8107	1.922	1.7741	1.6817		1.885	1.885
10	1.9387	1.9204	1.922			1.9774	1.8823
11	1.7193	1.828	1.8656	1.9004	1.9547	1.8473	1.8461
12	1.701	1.9004	1.7556	1.8099	1.97	1.8642	1.7918
13	1.7556	1.7194	1.6651	1.6832	1.7372	1.7556	1.7193
14	1.6289	1.6278	1.6632	1.6644	1.7194	1.6655	1.6655
15	1.6289	1.6832	1.5524	1.5154	1.7013	1.6655	1.6461
16	1.6651	1.7194	1.5154	1.46	1.6832	1.6651	1.6651
17	1.6655	1.7556	1.4815	1.4449	1.7013	1.5939	1.6476
18	1.5565	1.5223	1.5203	1.5181	1.587	1.576	1.5043
19	1.7375	1.6301	1.6644	1.5927	1.7013	1.7193	1.6289
20	1.8665	1.773	1.7741	1.848	1.8656	1.9004	1.957
21	1.8111	1.7013	1.7187	1.8111	1.7741	1.828	1.7741
22	1.7187		1.6817	1.7002			1.7177
23	1.6244	1.4045	1.5708	1.6057	1.5384	1.5893	1.6057
24	1.3394	1.4632	1.2986	1.3817	1.3717	1.3756	1.4083
Max	1.9387	1.922	1.922	1.9004	1.97	1.9774	1.957
Min	1.1641	1.1827	1.1222	1.1584	1.2127	1.2894	1.2536
Avg	1.5908	1.6015	1.5239	1.5207	1.5809	1.6322	1.6075

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

GANESH KHIND SUB-DN.[598] BU 4598

Substation No/ Name :- 213350 / 22/11KV Sus Road

Feeder No / Name : 204 / Bharat Electronics

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.811	.8676	.811	.8488	.9145	.8775	.9619
2	.7733	.8299	.7733	.8299	.8779	.8316	.9335
3	.7282	.7922	.7468	.8029	.8686	.8316	.8962
4	.7468	.7733	.7655	.7655	.823	.9335	.8589
5	.8589	.811	.8488	.8488	.8775	.9335	.8402
6	1.1949	.9242	1.094	1.0185	1.2136	1.2696	1.1317
7	1.358	1.2071	1.226	1.1317	1.2696	1.3817	1.3957
8	1.2384	1.2765	1.1763	1.1317	1.307	1.2574	1.2883
9	1.1883	1.1812	1.8111	1.0751		1.358	1.1389
10	1.307	1.3336	1.4563	1.0534		1.358	1.2883
11	1.251	1.307	1.3817	1.1128	1.3769	1.3014	1.251
12	1.2883	1.2197	1.363	1.0456		1.1949	1.1949
13	1.2012	1.0974	1.2382	.9709	1.1763	1.1273	1.1458
14	1.1827	1.134	1.3306	.9709	1.2567	1.1088	1.1763
15	1.1883	1.2567	1.3121	.9431	1.2936	1.0534	1.2696
16	1.2071	1.2071	1.2696	.9808	1.2936	1.1576	1.2323
17	1.2136	1.1389	1.1827	.9619	1.1576	1.0974	1.2323
18	1.0642	1.0719	1.1389	.9896	1.1458	1.0425	1.1203
19	1.0751	1.1088	1.2323	1.0269	1.2012	1.0719	1.1203
20	1.226	1.2382	1.2883	1.2637	1.3014	1.2696	1.3014
21	1.2637	1.1827	1.2696	1.2449	1.2323	1.226	1.226
22	1.1883		1.1883	1.2323			1.1694
23	1.0562	.9808	1.1317	1.0719	1.0903	1.1694	1.1016
24	.8589	.9242	.8488	.9619	.961	.9522	1.0185
Max	1.358	1.3336	1.8111	1.2637	1.3769	1.3817	1.3957
Min	.7282	.7733	.7468	.7655	.823	.8316	.8402
Avg	1.1029	1.0810	1.1619	1.0118	1.1319	1.1219	1.1372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

GANESH KHIND SUB-DN.[598] BU 4598

Substation No/ Name :- 213350 / 22/11KV Sus Road

Feeder No / Name : 301 / Praj

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	1.6766	2.4768	1.6766	1.7909	1.7147	1.7147
2	1.448	1.6004	2.4006	1.6004	1.7147	1.6385	1.6766
3	1.4098	1.5242	2.2862	1.5623	1.6766	1.6004	1.6004
4	1.4098	1.5242	2.2862	1.5242	1.6766	1.5623	1.5623
5	1.4861	1.6004	2.3624	1.5623	1.7147	1.6004	1.6004
6	1.6766	1.829	2.553	1.6004	1.829	1.9433	1.7528
7	2.0195	2.0576	2.7816	1.6766	1.9814	2.0576	1.9052
8	1.9814	2.0195	2.8959	1.7528	2.1719	2.2862	2.0957
9	2.4387	2.3243	3.1245	1.9052		2.3243	2.2862
10	2.3243	2.3243	3.2388	1.8671		2.4006	2.3243
11	2.1719	2.2862	3.2007	2.0195	2.4387	1.6766	2.4006
12		2.1338	3.1245	1.9814	2.21	2.2862	2.1338
13		2.0195	2.934	1.9052	2.1338	2.1719	1.9814
14		1.9052	1.7147	1.6385	2.0576	1.9814	1.9052
15	2.4006	1.9814	1.7528		1.9814	1.9052	1.9433
16	2.2862	1.9433	1.7909	1.6766	2.1719	1.9433	2.0576
17	2.2862	2.1338	1.8671		2.0957	1.9814	2.0576
18	2.1338	2.0957	1.6385	1.7147	2.0576	1.9814	2.0957
19	2.1719		1.8671	1.829	2.0957	2.1338	2.0576
20	2.4006	2.4006	2.1338	2.1719	2.4006	2.3624	2.3624
21	2.3624	.9526	2.0957	2.1719	2.4006	2.2481	2.2862
22	2.1338		2.0576	2.1338	2.21		2.1338
23	1.9814	1.9052	1.9433	2.0195	1.9814	1.9814	1.9433
24	1.6004	1.7528	2.7435	1.829	1.8671	1.7909	1.7528
Max	2.4387	2.4006	3.2388	2.1719	2.4387	2.4006	2.4006
Min	1.4098	.9526	1.6385	1.5242	1.6766	1.5623	1.5623
Avg	1.9832	1.9087	2.3863	1.8100	2.0299	1.9814	1.9846

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

GANESH KHIND SUB-DN.[598] BU 4598

Substation No/ Name :- 213350 / 22/11KV Sus Road

Feeder No / Name : 302 / Indus

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.448	1.5242	1.448	1.5242	1.5242	1.5242	1.6004
2	1.4098	1.4861	1.3717	1.4861	1.5242	1.4861	1.5623
3	1.3717	1.448	1.2574	1.448	1.4861	1.448	1.448
4	1.3717	1.448	1.2574	1.4098	1.4861	1.448	1.448
5	1.4098	1.4861	1.2955	1.3717	1.5242	1.448	1.448
6	1.448	1.5623	1.4098	1.4098	1.5623	1.6004	1.5242
7	1.5242	1.6766	1.448	1.448	1.6385	1.6385	1.5623
8	1.7528	1.7909	1.5242	1.4861	1.7528	1.7528	1.829
9	1.9433	1.9814	1.6004	1.5623		2.0195	1.9433
10	1.9052	2.0957	1.9814	1.6766		2.21	2.2862
11	2.1719	2.21	1.9433	1.7909	2.4006	2.1338	2.2862
12	2.0576	2.21	1.9052	1.7528	2.2481	2.2481	2.2481
13	2.0195	2.0576		1.7147	2.1338	2.1338	1.9814
14	1.9433	1.8671	1.7909	1.7147	2.0576	2.0576	1.9433
15	1.9814	1.8671	1.829		2.0576	2.0195	1.9814
16	1.9052	1.9052	1.9814	1.7147		2.0957	2.0957
17	1.9052	1.8671	1.8671		2.0957	2.0957	2.0195
18	1.7909	1.9052	1.7147	1.6004	1.9814	1.829	1.9052
19	1.8671		1.7909	1.6004	1.9052	1.8671	1.9433
20	1.9433		1.8671	1.7909	2.0195	2.0576	1.9433
21	1.8671		1.829	1.7909	1.9433	1.8671	1.829
22	1.7909		1.7147	1.7909			1.829
23	1.7147	1.6385	1.7147	1.7528	1.7528	1.7528	1.7147
24	1.4861	1.6004	1.5242	1.6004	1.6004	1.6385	1.6385
Max	2.1719	2.21	1.9814	1.7909	2.4006	2.2481	2.2862
Min	1.3717	1.448	1.2574	1.3717	1.4861	1.448	1.448
Avg	1.7512	1.7814	1.6550	1.6108	1.8347	1.8423	1.8338

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

GANESH KHIND SUB-DN.[598] BU 4598

Substation No/ Name :- 213394 / 22KV/11KV Crystal Garden

Sub-S

Feeder No / Name : 202 / Meera Mohan

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.499	.5281	.547	.547	.5658	.5658	.547
2	.4854	.4904	.5281	.5281	.5281	.5281	.5281
3	.4854	.4904	.5281	.5093	.5281	.5281	.5281
4	.5228	.5093	.5093	.5093	.5093	.5093	.5093
5	.5975	.5281	.5093	.5281	.5093	.5093	.5093
6	.6348	.6413	.547	.5658	.6413	.6413	.6979
7	.8573	.8764	.6224	.6036	.8299	.7545	.7733
8	.7922	.7922	.7167	.6602	.811	.8488	.8865
9	.9997	1.0185	.9054	.811	1.1203	1.1088	
10	1.1576	1.2696	.9242	.8299	1.363	1.2883	
11	1.1389	1.1317	1.0751	.8192	1.2883	1.1643	1.2323
12	1.0534	1.1203	.9335	.8299	1.1576	1.1273	1.1763
13	1.0349	.9709	.8299	.7733	1.1016	1.1203	.9709
14	1.0185	1.0829	.8029	.7621	1.0456	1.0642	.9709
15	1.0136	1.0829	.7922	.7545	1.1576	1.1016	1.0642
16	1.0269	1.0456	.7922	.724	1.1203	1.1016	1.1203
17	.9896	1.0719	.7922	.7167	1.0534	1.0903	1.1273
18	.9522	.9979	.7922		1.0349	1.0349	.9795
19	.8962	.9145	.8299		1.0349	1.0082	.9522
20	.8589	.8962	.811		.9979	.9896	.9808
21	.8299	.8299	.8192		.9808	.9522	.9997
22	.7922	.6979	.7621	.7356	.9242	.8589	.8383
23	.6602	.6036	.7049	.7167	.7356	.7282	.6859
24	.5601	.5847	.5601	.5847	.6036	.6348	.6036
Max	1.1576	1.2696	1.0751	.8299	1.363	1.2883	1.2323
Min	.4854	.4904	.5093	.5093	.5093	.5093	.5093
Avg	.8274	.8406	.7348	.6755	.9018	.8858	.8492

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

GANESH KHIND SUB-DN.[598] BU 4598

Substation No/ Name :- 213394 / 22KV/11KV Crystal Garden

Sub-S

Feeder No / Name : 203 / 11 KV Orange County

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2507	.2561	.2743	.2743	.2743	.2772	.2587
2	.2353	.2378	.2743	.2561	.2561	.2561	.2587
3	.2353	.2378	.2561	.2561	.2561	.2561	.2402
4	.2715	.2378	.2378	.2378	.2378	.2378	.2402
5	.3258	.2743	.2378	.2378	.2378	.2378	.2801
6	.3475	.3109	.2561	.2561	.3109	.2926	.3174
7	.4207	.3696	.2686	.2743	.3658	.3658	.3547
8	.4066	.4108	.3511	.3206	.3734	.4481	.3921
9	.3881	.4294	.3881	.4207	.4294	.3921	
10	.3881	.3921	.4108	.4435	.4066	.3841	
11	.3326	.3658	.3547	.3881	.4024	.3881	.4066
12	.3326	.362	.4066	.3658	.3658	.362	.3292
13	.2896	.3292	.3439	.3841	.3403	.3761	.3403
14	.2743	.2926	.3475	.3475	.2865	.3045	.3224
15	.3077	.2926	.3142	.3439	.3077	.3224	.3045
16	.3109	.3109	.3326	.3658	.3077	.3077	.3077
17	.3077	.2926	.3475	.3326	.3077	.2865	.2896
18	.3012	.3292	.3475		.3189	.3189	.2835
19	.3077	.3506	.3511		.3403	.3582	.3582
20	.3077	.3403	.3511		.3547	.3982	.3696
21	.3361	.3326	.3696		.3734	.362	.3734
22	.3361	.3326	.3511	.3734	.3734	.3511	.3734
23	.3142	.3109	.3326	.3174	.3361	.3326	.3547
24	.2534	.2743	.2926	.3109	.2957	.2957	.2926
Max	.4207	.4294	.4108	.4435	.4294	.4481	.4066
Min	.2353	.2378	.2378	.2378	.2378	.2378	.2402
Avg	.3159	.3197	.3249	.3253	.3275	.3297	.3204

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

KHADKI SUB-DN.[600] BU 4600

Substation No/ Name :- 213001 / KOEL

Feeder No / Name : 201 / 11KV KHADKI BAZAAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9328	1.0425	.9511	1.0059	1.0242	1.0608	1.0608
2		.9877	.9145	.9694	.9877	1.0425	.9877
3	.9145	.9694	.9145	.9511	.9511	1.0059	.9694
4	.9145	.9511	.9145	.9511	.9877	.9694	.9877
5	.9511	.9877	.9511	.9328	1.0059	1.0242	1.0059
6	1.0059	1.1157	.9511	.9145	1.134	1.0974	1.0642
7	1.2254	1.2803	1.1157	1.0242	1.2254	1.2071	1.2071
8	1.1523	1.2071	1.1523		1.2071	1.2254	1.2071
9	1.0974	1.1888	1.0425	1.134	1.1157	1.0974	1.0974
10	1.1157	1.2071	1.134	1.2254		1.134	1.0974
11	1.2254	1.2254	1.2986	.3109	1.2437	1.2803	1.262
12	1.3352	1.2254	1.3535	1.1706	1.262	1.2803	1.3535
13	1.3535	1.1706	1.39	1.39	1.2254	1.3352	1.3352
14	1.0608	1.0608	1.3535	1.3352	1.2803	1.3352	1.2437
15	1.0791	1.2803	1.3535	1.2803	1.2437	1.262	1.2437
16	1.1523	1.2986	1.3535	1.3352	1.2254	1.2803	1.2803
17	1.3169	1.3535	1.2803	1.3352	1.3535	1.3169	1.2986
18	1.4266	1.4632	1.39	1.3535	1.2986	1.3352	1.3535
19	1.701	1.4815	1.6095	1.4632	1.4266	1.5546	1.6827
20	1.7558	1.6095	1.7558	1.7375	1.6095		1.8107
21	1.6095	1.4815	1.5729	1.6827	1.4083	1.6644	1.5729
22	1.3169	1.2071	1.2803	1.2803	1.3169	1.39	
23	1.2071	1.0974	1.1706	1.1523		1.2254	1.2254
24	1.0059	1.0974	1.0242	1.0608	1.0608	1.134	1.0974
Max	1.7558	1.6095	1.7558	1.7375	1.6095	1.6644	1.8107
Min	.9145	.9511	.9145	.3109	.9511	.9694	.9694
Avg	1.2111	1.2079	1.2178	1.1737	1.2088	1.2286	1.2367

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

KHADKI SUB-DN.[600] BU 4600

Substation No/ Name :- 213001 / KOEL

Feeder No / Name : 202 / 11 KV BOPODI

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2075	.2075	.2075	.2075	.2075	.2172
2	.1886	.1886	.2075	.1886	.2075	.2075	.1991
3	.1886	.1886	.1886	.1886	.1886	.2075	.1629
4	.1886	.1886	.1886	.1886	.2075	.2075	.1698
5	.2075	.2075	.1886	.1886	.2075	.2075	.2075
6	.2075	.2263	.2075	.2263	.2263	.2263	.2452
7	.2263	.2263	.2075	.1698	.2263	.2263	.2263
8	.2075	.2452	.2263	.132	.2641	.2263	.2263
9	.2263	.2452	.2263		.2641	.2263	.2641
10	.1886	.2452	.2263	.2263			.2452
11			.2452	.2263	.2641	.2452	.2452
12	.2641		.2452	.2263	.1886	.2263	.2452
13	.2075	.2263	.2452	.2075	.2452	.2263	.2641
14	.2075	.2263	.2829	.1886	.2452	.2263	.2641
15	.2075	.2452	.2829	.1886	.2263	.2452	.2641
16	.2075	.2263	.2641	.1886	.2263	.2263	.2452
17	.2075	.2452	.2641	.1886	.2263	.2075	.2263
18	.1886	.2263	.2641	.1886	.2075	.1886	.2452
19	.2452	.2263	.2829	.1886	.2452	.2263	.2829
20	.2641	.2641	.3018	.2075	.2829	.2641	.3018
21	.2641	.2452	.3018	.2263	.2641	.2829	.2829
22	.2641	.2452	.3206	.2263	.2641		
23	.2452	.2452	.2263	.2641		.2452	.2829
24	.2075	.2263	.2263	.2263	.2263	.2263	.2353
Max	.2641	.2641	.3206	.2641	.2829	.2829	.3018
Min	.1886	.1886	.1886	.132	.1886	.1886	.1629
Avg	.2173	.2280	.2428	.2025	.2323	.2263	.2413

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

KHADKI SUB-DN.[600] BU 4600

Substation No/ Name :- 213001 / KOEL

Feeder No / Name : 204 / 11 Kv Kirloskar1

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2054	.2075	.1886	.2054	.2263	.2241
2	.1886	.2054	.2075	.1886	.2054	.2263	.2241
3	.1886	.2241	.2075	.1886	.2054	.2263	.2054
4	.2075	.2241	.2075	.1886	.2075	.2263	.2054
5	.2075	.2054	.2075	.1886	.2054	.2075	.2054
6	.2075	.1867	.1698	.1698	.2241	.2263	.2241
7	.3395	.3361	.2452	.1698	.2987	.3395	.3174
8	.415	.4854	.3361	.1509	.4668	.4338	.5415
9	.5281	.7095	.6348	.1886	.6535	.6224	.6908
10	.679	.7095	.6722	.1867		.9054	.7095
11	.7545	.4108	.6535	.1867	.9335	.9242	.7545
12	.679	.7468	.6535	.168	.8215	.9054	.7545
13	.6036	.7655	.6535	.1867	.8962	.9431	.7733
14	.7545	.8962	.6908	.168	.9149	.8865	.7733
15	.7468	.9054	1.0269	.1867	.8962	.9997	.8676
16	.7655	.9242	.6348	.1867	.9709	.9242	.9242
17	.5601	.8299	.2987	.1867	.7842	.7167	.679
18	.4294	.7545	.2614	.1867	.5601	.6224	.6224
19	.4481	.3584	.2614	.2054	.4527	.5281	.5281
20	.3921	.2829	.168	.2054	.3961	.4715	.4527
21	.3547	.2641	.168	.2054	1.4083	.415	.4338
22	.3734	.2263	.1494	.2054	.3206	.3921	
23	.2427	.2075	.1307	.2054		.3921	.3584
24	.2075	.2241	.2075	.2054	.2054	.2054	.2427
Max	.7655	.9242	1.0269	.2054	1.4083	.9997	.9242
Min	.1886	.1867	.1307	.1509	.2054	.2054	.2054
Avg	.4375	.4703	.3772	.1874	.5560	.5403	.5092

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

KHADKI SUB-DN.[600] BU 4600

Substation No/ Name :- 213001 / KOEL

Feeder No / Name : 206 / 11 KV STN Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724	.0724	.0543	.0724	.0724	.0724	.0724
2	.0543	.0724	.0543	.0724	.0724	.0724	.0724
3	.0543	.0724	.0543	.0724	.0724	.0724	.0543
4	.0724	.0724	.0543	.0724	.0724	.0724	.0543
5	.0724	.0724	.0724	.0905	.0724	.0724	.0724
6	.0905	.0724	.0724	.0905	.1086	.1086	.0724
7	.1086	.0543	.0905	.0905	.0905	.1086	.0724
8	.0724	.0543	.0724	.0543	.0905	.0724	.0724
9	.0543	.0543	.0724	.0905	.0905	.0724	.0905
10	.0724	.0543	.0724	.0905		.0543	.0724
11	.0543	.0543	.0724	.0543	.0905	.0543	
12	.0543	.0543	.0543	.0543	.0724	.0543	.0543
13	.0543	.0543	.0543	.0724	.0724	.0724	.0724
14	.0543	.0543	.0724	.0543	.0724	.0543	.0724
15	.0724	.0724	.0381	.0543	.0724	.0543	.0724
16	.0543	.0724	.0724	.0543	.0724	.0543	.0724
17	.0724	.0724	.0724	.0543	.0724	.0724	.0724
18	.0724	.0724	.0724	.0543	.0543	.0724	.0724
19	.0724	.0724	.0905	.0543	.0724	.0724	.0905
20	.0905	.0905	.0905	.056	.0905	.0905	.1086
21	.0905	.0905	.0905	.0543	.0905	.0905	.0905
22	.0905	.0905	.0905	.0905	.0905		
23	.0724	.0724	.0724	.0905		.0724	.0905
24	.0724	.0724	.0724	.0724	.0724	.0724	.0724
Max	.1086	.0905	.0905	.0905	.1086	.1086	.1086
Min	.0543	.0543	.0381	.0543	.0543	.0543	.0543
Avg	.0709	.0686	.0702	.0695	.0790	.0724	.0749

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

KHADKI SUB-DN.[600] BU 4600

Substation No/ Name :- 213001 / KOEL

Feeder No / Name : 207 / KUNDAN KUSHAL

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5973	.6516	.5973	.6878	.6697	.6697	.6878
2	.5792	.6154	.5792	.7059	.6697	.6516	.6516
3	.5792	.5973	.5792	.6335	.6335	.6335	.6516
4	.5973	.6154	.5792	.6154	.6516	.6335	.6335
5	.6154	.6335	.5973	.5973	.6516	.6516	.6335
6	.6516	.7059	.5973	.5611	.7421	.7059	.6335
7	.8145	.8507	.7783	.8326	.8507	.7964	.7783
8	.8326	.8326	.7964	.8688	.8688	.7783	.8326
9		.724	.7964	.7602	.724	.724	.7421
10	.6335	.724	.6697	.724		.6154	.6516
11	.6697	.724	.7059	.7783	.6878	.6516	
12	.6335	.7602	.5973	.724	.6154	.5973	.6697
13	.6335	.7602	.6697	.6878	.6335	.6154	.6516
14	.6154	.6516	.7059	.6697	.6154	.6154	.6516
15	.6154	.6335	.6516	.6697	.6335	.6154	.6335
16	.5792	.6516	.6335	.6516	.6154	.6335	.5611
17	.6154	.6335	.6335	.6516	.6154	.5973	.5973
18	.6697	.6697	.7421	.724	.6154	.6335	.6335
19	.7783	.7421	.7783	.724	.7059	.724	.7602
20	.8326	.8326	.8688	.905	.8326	.8507	.8507
21	.8688	.8507	.8507	.8688	.8507	.8507	.8688
22	.8145	.7964	.8145	.8869	.8326		
23	.7783	.724		.7783		.8145	.7964
24	.6697	.6878	.6516	.7964	.724	.7059	.724
Max	.8688	.8507	.8688	.905	.8688	.8507	.8688
Min	.5792	.5973	.5792	.5611	.6154	.5973	.5611
Avg	.6815	.7112	.6902	.7293	.7018	.6854	.6952

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

KHADKI SUB-DN.[600] BU 4600

Substation No/ Name :- 213040 / 22/11 KV SUB STN ,IT PARK

BOPO

Feeder No / Name : 201 / IT PARK

Franchisee feeder(11 KV)

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0094	.0094	.0075	.0075	.0075	.0094	.0094
2	.0075	.0075	.0075	.0075	.0075	.0094	.0094
3	.0075	.0075	.0075	.0075	.0075	.0094	.0094
4	.0075	.0075	.0075	.0075	.0075	.0094	.0075
5	.0075	.0075	.0075	.0075	.0075	.0094	.0075
6	.0075	.0094	.0075	.0075	.0075	.0094	.0094
7	.0075	.0094	.0075	.0075	.0075	.0094	.0075
8	.0094	.0094	.0075	.0057	.0094	.0094	.0075
9	.0132	.0152	.0075	.0057	.0151	.017	.0132
10	.021	.021	.0057	.0057	.0226	.0207	.0207
11	.0207	.0207	.0094	.0057	.0226	.0226	.0226
12	.0226	.0207	.0113	.0057	.0226	.0207	.0207
13	.0189	.0207	.0094	.0057	.0207	.017	.017
14	.017	.0207	.0094	.0075	.0226	.0189	.0207
15	.0207	.0207	.0094	.0057	.0226	.0207	.0226
16	.0207	.0207	.0113	.0057	.0207	.0226	.0226
17	.0207	.0245	.0094	.0075	.0226	.0207	.0226
18	.0189	.0226	.0094	.0094	.0207	.0226	.0207
19	.017	.0151	.0094	.0094	.0189	.0189	.0189
20	.017	.0152	.0094	.0094	.017	.0189	.0189
21	.0132	.0113	.0094	.0094	.0132	.0132	.0132
22	.0113	.0094	.0094	.0094	.0113	.0094	.0113
23	.0094	.0094	.0075	.0075	.0094	.0094	.0113
24	.0094	.0094	.0094	.0075	.0075	.0094	.0094
Max	.0226	.0245	.0113	.0094	.0226	.0226	.0226
Min	.0075	.0075	.0057	.0057	.0075	.0094	.0075
Avg	.0140	.0144	.0086	.0073	.0147	.0149	.0148

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

KHADKI SUB-DN.[600] BU 4600

Substation No/ Name :- 213040 / 22/11 KV SUB STN ,IT PARK

BOPO

Feeder No / Name : 202 / TIP-TOP

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17
HR	Load (MW)	Load (MW)
1	.0238	.0274
2	.0219	.0256
3	.0219	.0256
4	.0238	.0274
5	.0238	.0274
6	.0293	.0311
7	.0329	.0348
8	.0348	.0348
9	.0348	.0329
10	.0238	.0329
11	.0238	.0311
12		.0293
13	.0219	.0274
14	.0219	.0274
15	.0219	
16	.0219	
17	.0274	
19	.0348	
20	.0238	
21	.0311	
22	.0311	
23	.0274	
24	.0274	.0274
Max	.0348	.0348
Min	.0219	.0256
Avg	.0266	.0295

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHAND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

KHADKI SUB-DN.[600] BU 4600

Substation No/ Name :- 213040 / 22/11 KV SUB STN ,IT PARK

BOPO

Feeder No / Name : 203 / MUMBAI-PUNE ROAD

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0226	.0261	.0245	.0245	.0264	.0264	.0283
2		.0261	.0245	.0245	.0264	.0264	.0264
3	.0245	.0243	.0226	.0245	.0264	.0245	.0264
4	.0245		.0226	.0245	.0264	.0226	.0264
5	.0226	.0245	.0226	.0226	.0245	.0264	.0264
6	.0245	.0264	.0226	.0226	.0264	.0264	.0264
7	.0264	.0302	.0264	.0245	.0302	.0302	.0302
8	.0283	.0302	.0283	.0264	.0302	.0321	.0302
9	.0321	.0321	.0321	.0245	.034	.034	.0321
10	.0321	.0321	.0302	.0283	.0321	.0321	.0321
11	.0302	.0321	.0283	.0245	.0302	.0321	.034
12	.0283	.0321	.0283	.0245	.0321	.0321	.0302
13	.0283	.0283	.0264	.0226	.0302	.0283	.0283
14	.0264	.0283	.0226	.0226	.0283	.0264	.0283
15	.0264	.0283	.0226	.0207	.0283	.0283	.0283
16	.0245		.0226	.0226	.0245	.0245	.0245
17	.0245	.0264	.0226	.0226	.0264	.0245	.0245
18	.0245	.0245	.0245	.0226	.0264	.0226	.0245
19	.0264		.0264	.0245	.0283	.0245	.0264
20	.0321	.0321	.034	.034	.0358	.034	.034
21	.034	.0302	.0321	.034	.0358	.0321	.034
22	.0321		.0302	.0321	.0321		.0321
23	.0283	.0264	.0283	.0302	.0321	.0321	.0302
24	.0226	.0264	.0245	.0264	.0283	.0264	.0283
Max	.034	.0321	.034	.034	.0358	.034	.034
Min	.0226	.0243	.0226	.0207	.0245	.0226	.0245
Avg	.0272	.0284	.0262	.0255	.0292	.0282	.0289

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

KHADKI SUB-DN.[600] BU 4600

Substation No/ Name :- 213040 / 22/11 KV SUB STN ,IT PARK

BOPO

Feeder No / Name : 204 / KHADAKI STATION

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0248	.0286	.0248	.0248	.0267	.0286	.0286
2	.0229	.0267	.0248	.0229	.0267	.0286	.0267
3	.0229	.0267	.0229	.0229	.0248	.0286	
4	.0248	.0267	.0229	.0229	.0248	.0286	.0267
5	.0305	.0267	.0248	.0229	.0248	.0286	.0286
6	.0305	.0286	.0267	.0248	.0305	.0286	.0286
7	.0286	.0324	.0286	.0457	.0305	.0114	.0305
8	.0343	.0343	.0343	.0514	.0324	.0343	.0324
9	.0343	.0343	.0343	.0533	.0343	.0362	.0343
10	.0324	.0343	.0343	.0533	.0324	.0343	.0343
11	.0191	.0324	.0343	.0324	.0324	.0324	.0324
12	.0305	.0324	.0324	.0286	.0286	.0305	.0286
13	.0286	.0324	.0305	.0286	.0305	.0305	.0286
14	.0305	.0324	.0286	.0286	.0286	.0305	.0286
15	.0305	.0324	.0286	.0286	.0286	.0286	.0286
16	.0286	.0324	.0286	.0286	.0305	.0286	.0286
17	.0267	.0286	.0267	.0286	.0305	.0267	.0267
18	.0286	.0286	.0286	.0267	.0305	.0267	.0267
19	.0305	.0286	.0305	.0305	.0305	.0305	.0286
20	.0343	.0324	.0324	.0343	.0343	.0343	.0343
21	.0343	.0324	.0324	.0343	.0343	.0343	.0343
22	.0343		.0324	.0324	.0343	.0324	.0324
23	.0305	.0286	.0305	.0305	.0305	.0324	.0324
24	.0267	.0286	.0248	.0267	.0267	.0305	.0286
Max	.0343	.0343	.0343	.0533	.0343	.0362	.0343
Min	.0191	.0267	.0229	.0229	.0248	.0114	.0267
Avg	.0292	.0305	.0292	.0318	.0299	.0299	.0300

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

KHADKI SUB-DN.[600] BU 4600

Substation No/ Name :- 213040 / 22/11 KV SUB STN ,IT PARK

BOPO

Feeder No / Name : 205 / 11 KV Patel Goyal Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0075	.0093	.0075	.0093	.0093	.0093	.0093
2	.0075	.0093	.0075	.0075	.0093	.0075	.0093
3	.0075	.0075	.0075	.0075	.0093	.0076	.0075
4	.0075	.0075	.0075	.0075	.0093	.0075	.0075
5	.0093	.0093	.0075	.0075	.0093	.0093	.0093
6	.0112	.0093	.0075	.0075	.0112	.0112	.0112
7	.0149	.0131	.0094	.0093	.0131	.0131	.0131
8	.0131	.0149	.0132	.0112	.0131	.0131	.0131
9	.0131	.0151	.0132	.0131	.0149	.0131	.0131
10	.0112	.0113	.0132	.0131	.0112	.0112	.0112
11	.0093	.0113	.0132	.0131	.0093	.0112	.0112
12	.0093	.0132	.0112	.0131	.0093	.0112	.0093
13	.0093	.0075	.0093	.0112	.0075	.0075	.0075
14	.0075	.0075	.0075	.0093	.0075	.0075	.0075
15	.0075	.0075	.0075	.0093	.0075	.0075	.0075
16	.0075	.0075	.0075	.0093	.0075	.0093	.0075
17	.0075	.0075	.0093	.0093	.0075	.0075	.0075
18	.0093	.0094	.0093	.0093	.0093	.0075	.0075
19	.0112	.0093	.0112	.0112	.0112	.0093	.0075
20	.0131	.0113	.0131	.0131	.0131	.0112	.0112
21	.0112	.0113	.0112	.0112	.0132	.0112	.0112
22	.0112		.0112	.0131	.0112	.0112	.0112
23	.0093	.0094	.0093	.0112	.0112	.0112	.0112
24	.0093	.0093	.0075	.0093	.0093	.0093	.0093
Max	.0149	.0151	.0132	.0131	.0149	.0131	.0131
Min	.0075	.0075	.0075	.0075	.0075	.0075	.0075
Avg	.0098	.0099	.0097	.0103	.0102	.0098	.0097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

KHADKI SUB-DN.[600] BU 4600

Substation No/ Name :- 213040 / 22/11 KV SUB STN ,IT PARK

BOPO

Feeder No / Name : 206 / 11 KV ROYAL HEIGHT SOCIETY Urban/Sheddable Urban Feeder

FEE Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0019	.0019	.0019				.0038
2	.0019	.0019	.0019				.0019
3	.0019	.0019	.0019				.0019
4	.0019	.0019	.0019				.0019
5	.0019	.0019	.0019				.0019
6	.0019	.0038	.0019				.0038
7	.0019	.0038	.0038				.0038
8	.0038	.0038	.0038				.0038
9	.0038		.0038				.0038
10				.0019	.0038		
11				.0019	.0038		
12				.0038	.0038		
13				.0038	.0038		
14				.0038	.0038		
15					.0019		
16						.0019	.0019
17						.0019	
18						.0019	
19						.0038	
20						.0019	
21	.0038	.0038				.0038	
22	.0038					.0038	
23	.0038	.0038				.0038	
24	.0019	.0038	.0038				.0038
Max	.0038	.0038	.0038	.0038	.0038	.0038	.0038
Min	.0019	.0019	.0019	.0019	.0019	.0019	.0019
Avg	.0026	.0029	.0027	.0030	.0035	.0029	.0029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

KHADKI SUB-DN.[600] BU 4600

Substation No/ Name :- 213406 / 22/22 KV SWITCHING STN

CASTALE

Feeder No / Name : 301 / Castle Royal 1

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0037	.0038	.0037	.0038	.0037	.0038	
2	.0037	.0038	.0037	.0038	.0037	.0038	.0037
3	.0037	.0038	.0037	.0038	.0037	.0038	.0037
4	.0037	.0038	.0037	.0038	.0037	.0038	.0037
5	.0037	.0038	.0037	.0038	.0038	.0038	.0037
6	.0037	.0038	.0037	.0038	.0038	.0038	.0037
7	.0038	.0038	.0037	.0038	.0038	.0038	.0038
8	.0037	.0038	.0037	.0038	.0038	.0038	.0037
9	.0038	.0038	.0037	.0038	.0038	.0038	.0037
10	.0038	.0037	.0038	.0038	.0038	.0038	.0038
11	.0038	.0038	.0038	.0038	.0038	.0038	.0038
12	.0038	.0038	.0038	.0038	.0038	.0038	.0038
13	.0038	.0038	.0038	.0038	.0038	.0038	.0038
14	.0038	.0038	.0038	.0038	.0038	.0038	.0038
15	.0038	.0038	.0038	.0038	.0038	.0038	.0038
16	.0038	.0038	.0038	.0038	.0038	.0038	.0038
17	.0038	.0038	.0038	.0038	.0038	.0038	.0038
18	.0038	.0038	.0038	.0038	.0038	.0038	.0038
19	.0038	.0038	.0038	.0038	.0038	.0038	.0038
20	.0038	.0038	.0038	.0038	.0038	.0038	.0038
21	.0038	.0038	.0038	.0038	.0038	.0038	.0038
22	.0038	.0038	.0038	.0038	.0038	.0038	
23	.0038	.0037	.0038	.0038	.0038	.0038	.0038
24	.0037	.0038	.0037	.0038	.0037	.0038	.0038
Max	.0038	.0038	.0038	.0038	.0038	.0038	.0038
Min	.0037	.0037	.0037	.0038	.0037	.0038	.0037
Avg	.0038	.0038	.0038	.0038	.0038	.0038	.0038

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

SHIVAJINAGAR S/DN.[597] BU 4597

Substation No/ Name :- 212001 / 11KV SHIVAJINAGAR

Feeder No / Name : 201 / Gaothan

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3921	.4108	.3734	.3921	.4108	.4108	.4108
2	.3734	.3734	.3547	.3547	.3734	.3734	.3734
3	.3734	.3547	.3361	.3547	.3734	.3734	.3547
4	.3734	.3547	.3361	.3547	.3734	.3547	.3547
5	.3921	.3734	.3361	.3734	.3921	.3734	.3734
6	.4294	.3921	.3547	.3734	.4294	.4294	.4294
7	.4854	.4481	.4481	.3921	.4854	.4854	.5041
8	.5415	.5228	.4854	.4481	.5601	.5041	.5601
9	.5975	.5975	.5975	.5041	.6348	.6535	.6161
10	.7095	.7282	.6722	.5228	.7282	.7095	.7095
11	.8215	.7655	.8402	.5601	.6908	.7282	.8029
12	.7468	.7468	.7842	.5975	.7282	.7655	
13	.7468	.7842	.7842	.5415	.7468	.7282	.7282
14	.7468	.7282	.8029	.5975	.7655	.7468	.8215
15	.7468	.7655	.7468	.5415	.7655	.7282	.7468
16		.7842	.6348	.5041	.7842	.7655	.7468
17	.7468	.7468	.6348	.5041	.7842	.7468	
18	.6722	.6161	.6348	.5228	.6908	.7095	.7095
19		.6722	.6161	.5788	.6722	.6908	.7282
20	.5788	.6348	.6161	.5975	.6535	.6722	.6908
21		.5601	.6161	.5788	.6535	.5975	
22	.5415	.5415	.5415	.5415	.5975	.5788	
23	.5041	.5041	.4854	.5228	.5041	.5228	.5228
24	.4108	.4108	.3921	.4481	.4481	.4481	.4481
Max	.8215	.7842	.8402	.5975	.7842	.7655	.8215
Min	.3734	.3547	.3361	.3547	.3734	.3547	.3547
Avg	.5681	.5757	.5593	.4878	.5936	.5874	.5816

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

SHIVAJINAGAR S/DN.[597] BU 4597

Substation No/ Name :- 212001 / 11KV SHIVAJINAGAR

Feeder No / Name : 202 / Tophkhana Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6224	.5281	.3772	.4904	.4904	.5847	.5658
2	.547	.3961	.3584	.4527	.4527	.547	.5281
3	.4904	.3772	.3584	.4338	.4527	.5093	.4715
4	.4904	.3772	.3584	.4338	.4715	.4715	.4527
5	.4904	.3961	.3772	.4527	.5093	.4715	.4527
6	.5281	.415	.4338	.4527	.547	.4338	.415
7	.5658	.4904	.4338	.4715	.6224	.5281	.6224
8	.5658	.6413	.547	.5093	.6602	.6979	.4904
9	.7356	.8865	.7922	.5281	.7733	.7545	.811
10	.9808	1.0185	.9054	.7922	.9997	.9997	.8865
11	1.0374	1.0185	.9997	.8299	.9997	1.1128	
12	1.0751	1.1128	1.1128	.811	1.0185	1.0562	1.0562
13	.9808	1.0374	1.0562	.7167	.9808	.9997	1.0562
14	.9431	.9808	1.0185	.7733	.9997	1.0562	1.0751
15	1.0562	.9997	1.0374	.6979	1.0562		1.0374
16		1.0751	1.0468	.7545	1.1128	1.0562	.964
17	.9054	1.0185	1.1883	.5658	.9808	1.0185	1.0867
18	.7922	.8488	1.1317	.6224	.9808	.9431	.7888
19		.6602	.9808	.6979	.9431	.8488	.8589
20	.9242	.4715	.9619	.6979	.9054	.8488	.7922
21	.6979	.7922	.8676	.7167	.7356	.6979	
22	.6602	.6602	.7356	.7922	.7922	.6979	
23	.6413	.5847	.679	.8299	.679	.6602	.6602
24	.679	.6036	.3961	.5658	.5658	.679	.6224
Max	1.0751	1.1128	1.1883	.8299	1.1128	1.1128	1.0867
Min	.4904	.3772	.3584	.4338	.4527	.4338	.415
Avg	.7459	.7246	.7564	.6287	.7804	.7684	.7473

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

SHIVAJINAGAR S/DN.[597] BU 4597

Substation No/ Name :- 212001 / 11KV SHIVAJINAGAR

Feeder No / Name : 204 / Shaniwar Peth

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3506	.3856	.3506	.4207	.4031	.4382	.4031
2	.333	.3506	.333	.3856	.3681	.4207	.3681
3	.333	.3506	.333	.3506	.3681	.4207	.3506
4	.3506	.3506	.3506	.3506	.3681	.4207	.3506
5	.3856	.3856	.3681	.3681	.4031	.4382	.3681
6	.4382	.4382	.4207	.4031	.4382	.4733	.4382
7	.5258	.4908	.4733	.4382	.4908	.5258	.5258
8	.5959	.5609	.5258	.5083	.5609	.5609	.5784
9	.5784	.6135	.631	.5784	.5959	.5959	.5784
10	.6485	.6661	.6836	.5258		.631	.6836
11	.7362	.7712	.8589	.5959	.7282	.7186	.7888
12	.7537	.8063	.8939	.5609	.631	.7537	.8238
13	.7712	.8063	.8063	.5083	.6836	.7712	.7888
14	.7537	.7712	.7362	.4908	.7011	.7011	.7186
15	.8063	.8413	.7712	.4733	.7537	.7011	.7362
16		.7888	.7537	.4557	.7888	.7712	.8063
17	.8238		.7537	.4557	.8238	.7712	.8238
18	.8063	.8238	.8063	.4908	.8238	.7888	.8238
19		.7888	.7888	.5609	.7888	.8063	.8764
20		.7712	.8063	.5959	.7712	.8238	.8764
21	.6836	.6836	.7186	.5434	.7537	.7362	
22	.5959	.5434	.6135	.5258	.5959	.6485	
23	.5258	.4557	.5083	.4908	.5434	.5434	.5609
24	.3856	.4207	.3856	.4382	.4382	.4733	.4908
Max	.8238	.8413	.8939	.5959	.8238	.8238	.8764
Min	.333	.3506	.333	.3506	.3681	.4207	.3506
Avg	.5801	.6028	.6113	.4798	.6009	.6222	.6254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

SHIVAJINAGAR S/DN.[597] BU 4597

Substation No/ Name :- 212002 / 11 KV MODI GANAPATI

Feeder No / Name : 201 / Chitrashala

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7					.3361		
8	.3658	.3772	.3206	.2987	.3734	.3696	.3734
9	.4207	.439	.3772	.3326	.4435	.4572	.4481
10	.4938	.4938	.4481	.3881	.499	.5175	.4904
11	.5175	.499	.5228	.3696	.5041	.5544	.5658
12		.499	.5359	.4024	.5359	.5658	.5601
13	.499	.5041	.4805	.3658	.4805	.5544	.5228
14	.5729	.4715	.5175	.3258	.462	.5175	.4854
15	.5788	.5041	.5228	.3077	.462	.4805	.4338
16	.5041	.5041	.4805	.3109	.462	.5359	.5281
17	.5415	.5041	.4668	.3292	.4854	.5359	
18	.5415	.5041	.4904	.3142	.4854	.5359	
19	.5281	.5228	.547	.3292	.4904	.5175	
20	.5093	.4668	.5281	.3475	.4481	.4805	
21				.3547	.4481		
23					.362		
Max	.5788	.5228	.547	.4024	.5359	.5658	.5658
Min	.3658	.3772	.3206	.2987	.3361	.3696	.3734
Avg	.5061	.4838	.4799	.3412	.4549	.5094	.4898

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

SHIVAJINAGAR S/DN.[597] BU 4597

Substation No/ Name :- 212002 / 11 KV MODI GANAPATI

Feeder No / Name : 202 / Sitaram Appt.

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7					.0953		
8	.112	.1307	.1307	.0934	.1334	.1334	.0953
9	.1698	.1509	.1494	.1132	.1524	.1524	.1334
10	.1698	.1698	.1698	.132	.2096	.1905	.1715
11	.2987	.3174	.3018	.2427	.2286	.3048	.3239
12	.3174	.3174	.3174	.2801	.2452	.3174	.3395
13	.3547	.3361	.3361	.2614	.2452	.2987	.3018
14	.2987	.2987	.3174	.2614	.2075	.3018	.2452
15	.2801	.3206	.3174	.2614	.2241	.2829	.2801
16	.2641	.3206	.3395	.2075	.2241	.2987	.2801
17	.3174	.3174	.3395	.2427	.2054	.2987	
18	.3584	.3174	.3547	.2054	.2263	.2987	
19	.3361	.3174	.2801	.1886	.2075	.3734	
20	.3361	.3018	.2614	.168	.1886	.3174	
21				.168	.1867		
23					.1334		
Max	.3584	.3361	.3547	.2801	.2452	.3734	.3395
Min	.112	.1307	.1307	.0934	.0953	.1334	.0953
Avg	.2779	.2782	.2781	.2018	.1946	.2745	.2412

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

SHIVAJINAGAR S/DN.[597] BU 4597

Substation No/ Name :- 212002 / 11 KV MODI GANAPATI

Feeder No / Name : 203 / Bank Of India

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7					.4668		
8	.5068	.6602	.5601	.4656	.5601	.5601	.4477
9	.5373	.8488	.6602	.5792	.7545	.7922	.5552
10	.8507	.9522	.8488	.6447	.8865	.8676	.8688
11	1.828	1.9427	1.905	1.5223	1.4523	1.9805	1.8642
12	2.0302	2.037	2.4143	2.1313	1.5278	2.1691	2.0668
13	2.3577	2.1879	2.3765	2.037	1.4335	2.2634	2.2068
14	2.32	2.3388	2.452	1.9805	1.3957	2.4143	2.2445
15	2.3011	2.2257	2.4272	1.9616	1.4815	2.3011	2.2405
16	2.2822	2.3954	2.4897	1.905	1.4937	2.3339	2.3954
17	2.452	2.5274	2.4272	1.9239	1.46	2.2405	
18	2.2779	2.0538	2.2405	1.773	1.4632	2.1658	
19	2.4143	1.8484	2.2592	1.2936	1.0974	2.1845	
20	2.3388	1.587	2.2218	1.1203	.8871	2.1658	
21				.8402	.7842		
23					.5087		
Max	2.452	2.5274	2.4897	2.1313	1.5278	2.4143	2.3954
Min	.5068	.6602	.5601	.4656	.4668	.5601	.4477
Avg	1.8844	1.8158	1.9448	1.4413	1.1033	1.8799	1.6544

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

SHIVAJINAGAR S/DN.[597] BU 4597

Substation No/ Name :- 213305 / 22/11 kv wakdewadi

Feeder No / Name : 201 / Godrej I

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.4001	.4001	.381	.4001	.4382	.4382
2	.381	.4001	.381	.381	.381	.4001	.4382
3	.362	.4001	.362	.381	.381	.381	.4191
4	.362	.381	.381	.381	.381	.4001	.4191
5	.381	.381	.4001	.381	.4191	.4191	.4382
6	.4191	.4001	.4382	.4001	.4572	.4954	.4763
7	.4001	.4191	.4382	.381	.4572	.4763	.4954
8	.4382	.4382	.4572	.4382	.4572	.4954	.5144
9	.5335	.5335	.4572	.4382	.5144	.5525	.5335
10	.5906	.5525		.4572	.5906		.5525
11	.5906		.5144	.4763	.5906	.5525	
12	.5525	.5335	.4954	.4572	.5906	.5335	.4763
13	.5335	.5335	.4572	.4572	.5335	.5144	.4382
14	.5335	.4763	.4001	.4382	.5716	.5144	.4572
15	.5906	.5144	.4954	.4572	.5144	.5525	.5525
16	.5525	.4954	.4572	.4572	.5144	.5906	.5716
17	.5335	.4763	.4382	.4382	.5144	.5716	.5716
18	.5525	.4763	.4382	.4382	.5144	.5525	.5525
19	.5335	.4382	.4191	.4572	.5144	.5716	.5525
20	.5144	.4382	.4572	.4763	.5144	.5144	.5335
21	.5144	.4572	.4382	.4763	.4572	.4954	.4954
22	.4382	.4572	.4191	.4572	.4954		.5144
23	.4382	.4382	.4191	.4572	.4763	.4763	.4763
24	.4001	.4191	.4382	.4001	.4382	.4572	.4572
Max	.5906	.5525	.5144	.4763	.5906	.5906	.5716
Min	.362	.381	.362	.381	.381	.381	.4191
Avg	.4803	.4548	.4349	.4318	.4866	.4980	.4945

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

SHIVAJINAGAR S/DN.[597] BU 4597

Substation No/ Name :- 213305 / 22/11 kv wakdewadi

Feeder No / Name : 202 / Godrej 2

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9242	.9054	.9054	.9054	.9054	.9431	.9431
2	.8865	.9054	.8865	.9054	.8865	.9242	.9054
3	.8676	.8865	.8676	.8865	.8676	.9054	.8676
4	.8865	.8865	.8488	.8865	.8676	.8865	.8488
5	.9054		.8676	.8865	.8676	.9054	.8488
6	.9054	.9242	.8865	.8865	.9242	.9242	.8676
7	1.1317	1.1128	1.0374	.9242	1.0562	.9619	.9997
8	1.4712	.0132	1.3957	.9808	1.5466	1.6409	1.5278
9	1.6787	1.4712	1.5466	1.094	1.773	1.7164	1.5844
10	1.8861	1.9239		1.094	1.905		2.0748
11	2.1879		1.8861	1.1694	2.1313	2.2068	2.2257
12	2.3388	2.3765	2.0748	1.4146	2.3388	2.2822	2.2634
13	2.3765	2.3577	1.9239	1.3769	2.2257		2.3765
14	2.32	2.3011	1.9239	1.4146	2.2822	2.3388	2.2445
15	2.3011	2.3577	1.9239	1.3014	2.2822	2.2822	2.3388
16	2.3388	2.4143	1.773	1.226	2.3765	2.3577	2.3577
17	2.2634	2.3577	1.5089	1.3203	2.2068	2.3388	2.3011
18	2.037	2.1313	1.6221	1.226	1.9427	2.1313	2.1313
19	1.9993	1.8484	1.4146	1.2826	2.037	2.0559	2.1125
20	1.8861	1.7541	1.4335	1.358	1.8107	1.9239	1.8484
21	1.6598	1.4146	1.2449	1.226	1.5844	1.5466	1.6032
22	1.2449	1.094	1.094	1.1694	1.094		1.3203
23	1.0185	.9808		1.0185	1.0562	1.0562	1.0185
24	.9054	.9997	.9619	.9619	.9619	.9997	1.0185
Max	2.3765	2.4143	2.0748	1.4146	2.3765	2.3577	2.3765
Min	.8676	.0132	.8488	.8865	.8676	.8865	.8488
Avg	1.6009	1.5190	1.3649	1.1215	1.5804	1.5871	1.6095

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

SHIVAJINAGAR S/DN.[597] BU 4597

Substation No/ Name :- 213305 / 22/11 kv wakdewadi

Feeder No / Name : 203 / SANGAM BRIDGE

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3584	.3772	.3584	.3584	.3772	.415	.3961
2	.3772	.3772	.3395	.3395	.3772	.3772	.3772
3	.3584	.3584	.3395	.3395	.3584	.3584	.3584
4	.3584	.3584	.3206	.3395	.3584	.3395	.3584
5	.3584	.3772	.3584	.3395	.3584	.3584	.3772
6	.415	.3772	.3772	.3206	.3772	.3961	.3772
7	.3961	.3772	.3395	.3584	.3584	.415	.3772
8	.3584	.3961	.3395	.3395	.3395	.3584	.3584
9	.4338	.4904	.415	.3395	.3961	.4338	.3961
10	.5658	.6979		.4338	.6602		.5847
11	.7356		.6979	.415	.7167	.7356	.7545
12	.7922	.9054	.6979	.4715	.7356	.7356	.7545
13	.7922	.9619	.7733	.4338	.7167	.679	.7356
14	.3772	.8865	.7545	.3772	.6979	.7167	.679
15	.8488	.9242	.7922	.3772	.7733	.7922	.7167
16	.7733	.9242	.7545	.3772	.7922	.811	.7733
17	.7922	.7922	.6979	.3584	.7922	.7356	.7167
18	.6413	.679	.6036	.3772	.6224	.6413	.6602
19	.6036	.547	.547	.4338	.5658	.5281	.547
20	.5093	.4715	.5093	.4715	.5093	.5281	.547
21	.4715	.4715	.4527	.4338	.4904	.4904	.4904
22	.4338	.4338	.3961	.4338	.4715		.4527
23	.4338	.3961		.415	.4527	.4338	.4338
24	.3961	.3961	.3772	.3961	.415	.4527	.3961
Max	.8488	.9619	.7922	.4715	.7922	.811	.7733
Min	.3584	.3584	.3206	.3206	.3395	.3395	.3584
Avg	.5242	.5642	.5110	.3867	.5297	.5333	.5258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

SHIVAJINAGAR S/DN.[597] BU 4597

Substation No/ Name :- 213305 / 22/11 kv wakdewadi

Feeder No / Name : 204 / May Fair tower

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3584	.3584	.3584	.3961	.3772	.3772	.3961
2	.3584	.3584	.3395	.3772	.3772	.3772	.3772
3	.3395	.3395	.3206	.3772	.3772	.3772	.3584
4	.3395	.3395	.3206	.3772	.3772	.3584	.3395
5	.3584	.3584	.3395	.3772	.3961	.3584	.3584
6	.3772	.3584	.3772	.3772	.415	.3772	.3961
7	.3961	.3772	.3584	.3584	.3772	.3772	.3961
8	.3772	.3961	.415	.415	.4338	.415	.415
9	.7167	.679		.415	.811	.679	.7545
10	1.1317	1.1128	.4338	.415	1.2449	1.2826	1.2449
11	1.226		.8299	.4338	1.3392	1.3203	1.2071
12	1.1317	1.1506	.7922	.415	1.3392	1.226	1.2071
13	1.1128	1.1317	.7167	.3961	1.1694	1.1694	1.1128
14	1.0751	1.1317	.7167	.3961	1.1694	1.0751	1.0751
15	1.2449	1.226	.7545	.3772	1.2071	1.2449	1.226
16	1.1317	1.3203	.6036	.415	1.226	1.2071	1.2637
17	1.1128	1.1694	.547	.3961	1.3014	1.1317	1.3014
18	.9431	.679	.4715	.3772	1.0374	.9054	.9619
19	.679	.547	.5093	.3961	.7733	.6413	.811
20	.5093	.4904	.4527	.4338	.5281	.5093	.547
21	.4338	.415	.4338	.4338	.4338	.4338	.4715
22	.3961	.3961	.415	.4338	.3961	.4338	.4715
23	.415	.3961		.415	.415	.4338	.4338
24	.3772	.3772	.3961	.415	.415	.3961	.415
Max	1.2449	1.3203	.8299	.4338	1.3392	1.3203	1.3014
Min	.3395	.3395	.3206	.3584	.3772	.3584	.3395
Avg	.6892	.6569	.4955	.4008	.7474	.7128	.7309

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

SHIVAJINAGAR S/DN.[597] BU 4597

Substation No/ Name :- 213305 / 22/11 kv wakdewadi

Feeder No / Name : 205 / milk Dairy

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.5658	.5658	.5658	.9431	.5658	.5658
2	.5658	.5658	.5658	.547	.9242	.547	.547
3	.547	.5658	.5658	.547	.9242	.5281	.5281
4	.5281	.547	.547	.547	.9242	.5093	.5093
5	.547	.5658	.5658	.9997	.9242	.5281	.547
6	.6036	.6036	.5847	.9242	.9431	.5658	.6036
7	.6413	.6413	.6602	.9431	1.0185	.6036	.6413
8	.6602	.6979	.6413	.9242	1.094	.6413	.679
9	1.094	1.0751	.7356	1.0374	1.6032	1.1317	1.1128
10	1.2449			1.1128	2.0182	1.1317	1.3769
11	1.4146	1.3014	.9242	1.1883	2.0182	.8865	1.4712
12	1.358	1.3203	.8488	1.0562	1.9427	1.4901	
13	1.3957	1.2826	.8488	1.1128	1.905	1.3392	1.2637
14	1.3392	1.2637	.9808	1.1128	1.2826	1.1883	1.3392
15	1.3769	1.3392	.9997	1.0374	2.037	1.2826	1.3769
16	1.3014	1.3203	.9997	1.0185	1.3014	1.3392	1.3203
17	1.3203	1.3769	.8676	1.0374	1.2826	1.3392	1.2826
18	1.1506	1.094	.811	.9619	1.094	1.094	1.1694
19	.8299	.6979	.7545	.9997	.8488	.9997	.9242
20	.7733	.6979	.6979	1.1317	.7356	.7922	.7733
21	.679	.679	.6979	1.0562	.6602	.679	.6979
22	.679	.6413	.6979	1.0185	.6224		.6979
23	.6224	.6036	.6413	.9808	.6036	.6224	.6036
24	.5847	.5847	.5847	.5847	.9431	.5847	.5847
Max	1.4146	1.3769	.9997	1.1883	2.037	1.4901	1.4712
Min	.5281	.547	.547	.547	.6036	.5093	.5093
Avg	.9093	.8709	.7299	.9352	1.1914	.8865	.8963

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

SHIVAJINAGAR S/DN.[597] BU 4597

Substation No/ Name :- 213305 / 22/11 kv wakdewadi

Feeder No / Name : 301 / Vodaphone

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0415	.0377	.0415	.0415	.0377	.0377
2	.0377	.0415	.0377	.0415	.0415	.0377	.0377
3	.0377	.0415	.0377	.0415	.0415	.0377	.0377
4	.0377	.0415	.0377	.0377	.0415	.0377	.0377
5	.0377	.0415	.0377	.0377	.0415	.0377	.0377
6	.0377	.0415	.0377	.0415	.0415	.0377	.0377
7	.0377	.0415	.0377	.0415	.0415	.0377	.0377
8	.0415	.0415	.0415	.0377	.0415	.0377	.0415
9	.0377	.0415		.0377	.0415		.0453
10	.0377	.0415	.0415	.0415	.0415		.0415
11	.0377		.0415	.0415	.0415	.0453	.0453
12	.0377	.0415	.0415	.0415	.0415	.0453	.0453
13	.0415	.0415	.0415	.0415	.0415	.0453	.034
14	.0415	.0415	.0415	.0415	.0415	.0415	.0453
15	.0377	.0453	.0415	.0075	.0453	.0453	.0453
16	.0415	.0453	.0453	.0415	.0415	.0453	.0453
17	.0415	.0453	.0415	.0415	.0415	.0453	.0453
18	.0415	.0415	.0415	.0453	.0415	.0453	.0415
19	.037	.0415	.0415	.0415	.0415	.0415	.0415
20	.0377	.0415	.0415	.0415	.0415	.0415	.0415
21	.0377	.0377	.0415	.0415	.0415	.0415	.0415
22	.0415	.0377	.0415	.0415	.0415	.0415	.0377
23	.0415	.0377		.0415	.0415	.0415	.0415
24	.0377	.0415	.0377	.0377	.0415	.0415	.0377
Max	.0415	.0453	.0453	.0453	.0453	.0453	.0453
Min	.037	.0377	.0377	.0075	.0415	.0377	.034
Avg	.0389	.0415	.0403	.0395	.0417	.0413	.0409

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

SHIVAJINAGAR S/DN.[597] BU 4597

Substation No/ Name :- 213305 / 22/11 kv wakdewadi

Feeder No / Name : 302 / Vascon

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0111	.0111	.0111	.0111	.0111	.0111	.0112
2	.0111	.0111	.0111	.0111	.0111	.0074	.0112
3	.0111	.0111	.0111	.0111	1.0719	.0074	.0112
4	.0111	.0111	.0074	.0111	.0111	.0074	.0112
5	.0111	.0111	.0111	.0111	.0111	.0074	.0112
6	.0111	1.0719	.0111	.0111	.0111	.0111	.0112
7	.0111	.0148	.0111	.0111	.0148	.0148	.0187
8	.0222	.037	.0185	.0111	.0185	.0261	.0261
9	.0444	.0444	.0259	.0111	.0517	.0411	.0523
10	.048	.0517		.0111		.056	.056
11			.0148	.0111	.0591	.056	.0485
12		.0517	.0148	.0111	.0517	.0523	.0523
13		.0554	1.5893	.0111	.0517	.0485	.056
14	.0517	.0554	.0259	.0111	.048	.056	.0523
15	.0517	.0554	.0333	.0148	.0517	.0523	.0597
16	.0517	.0554	.0259	.0148	.0517	.056	.0597
17	.048	.0517	.0296	.0111	.0554	.0523	.056
18	.048	.048	.0185	.0111	.0444	.0448	.0523
19	.0415	.037	.0185	.0111	.0407	.0411	.0448
20	.0333	.0296	.0185	.0111	.037	.0336	.0373
21	.0148	.0148	.0148	.0111	.0224	.0224	.0224
22	.0148	.0111	.0148	.0111	.0148	.0149	.0149
23	.0148	.0111		.0111	.0111	.0149	.0149
24	.0111	.0111	.0111	.0111	.0111	.0111	.0112
Max	.0517	1.0719	1.5893	.0148	1.0719	.056	.0597
Min	.0111	.0111	.0074	.0111	.0111	.0074	.0112
Avg	.0273	.0767	.0886	.0114	.0767	.0311	.0334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-17 and 21-JUN-17

PUNE ZONE[051]

GANESHKHIND (U) CIRCLE[517]

SHIVAJI NAGAR DIVISION[302]

SHIVAJINAGAR S/DN.[597] BU 4597

Substation No/ Name :- 213305 / 22/11 kv wakdewadi

Feeder No / Name : 303 / Bajaj

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	15-JUN-17	16-JUN-17	17-JUN-17	18-JUN-17	19-JUN-17	20-JUN-17	21-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0305	.0343	.0305	.0381	.0305
2	.0343	.0343	.0305	.0343	.0305	.0343	.0305
3	.0343	.0343	.0305	.0343	.0343	.0343	.0305
4	.0343	.0343	.0305	.0343	.0343	.0305	.0305
5	.0305	.0343	.0305	.0343	.0343	.0305	.0305
6	.0343	.0343	.0343	.0343	.0343	.0305	.0305
7	.0343	.0381	.0305	.0343	.0381	.0419	.0381
8	.0419	.0495	.0305	.0305	.0495	.0495	.0419
9	.0572	.0648		.0305	.0648		.0572
10	.0572	.0648	.0381	.0343		.0648	
11	.061	.0648	.0457	.0343	.0648	.0686	.0686
12	.061	.061	.0419	.0381	.0648	.0648	.0724
13	.0572	.061	.0495	.0343	.061	.0686	.0686
14	.061	.0648	.0495	.0343	.0686	.0686	.0724
15	.0648	.0686	.0457	.0381	.0686	.0686	.0686
16	.0648	.0648	.0457	.0343	.061	.0686	.0762
17	.061	.0648	.0381	.0381	.0686		.0686
18	.0572	.0533	.0381	.0381	.061	.0648	.061
19	.0495	.0457	.0419	.0343	.0533	.0533	.0533
20	.0495	.0419	.0381	.0343	.0457	.0495	.0495
21	.0457	.0419	.0381	.0343	.0419	.0457	.0457
22	.0419	.0343	.0381	.0343	.0381	.0381	.0419
23	.0381	.0381		.0343	.0343	.0343	.0343
24	.0343	.0381	.0343	.0343	.0343	.0343	.0343
Max	.0648	.0686	.0495	.0381	.0686	.0686	.0762
Min	.0305	.0343	.0305	.0305	.0305	.0305	.0305
Avg	.0475	.0486	.0378	.0346	.0485	.0492	.0494