

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 201 / 11 Kv Hutatma

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3174	.3772	.3734	.3772	.3395	.3734	.415
2	.3174	.3772	.3734	.3772	.3395	.3734	.415
3	.3174	.3772	.3734	.3772	.3395	.3734	.415
4	.3734	.3772	.3734	.415	.3395	.3734	.4481
5	.5041	.5658		.5601	.415	.5975	.6722
6	.6979	.7545	.8029	.7842	.6413	.8029	.8962
7	.8871	.9054		.9709	.811	.9335	.9896
8	.7468	.8029	.8962	.7655	.7733	.8402	.7282
9	.6535	.5788	.6722	.6161	.6653	.6535	.6401
10	.5847	.5373	.5359	.6161	.5228	.5792	.5544
11	.567	.5014	.543	.5975	.4481	.5792	.4805
12	.5373	.4607	.5249	.5975	.4108	.5359	.462
13	.5316	.4805	.567	.5853	.4108	.462	.4938
14	.5138	.4805	.4294	.5853	.4481	.4706	.5121
15	.5138	.4805	.5249	.5792	.4854	.4755	.4755
16	.5316		.5068	.543	.5041	.4344	
17	.5144	.5721	.5316	.543	.5975	.5601	.5316
18	.7316	.7842	.7023	.6584	.5975	.6348	.6335
19	.9055	.9335	.8501	.7392	.6219	.8589	.8686
20	.8413	.9335	.7762	.7095	.823	.8215	.8316
21	.7282	.7842	.6283	.6161	.7468	.7655	.7842
22	.5415	.5788	.5847	.5415	.5975	.6348	.5415
23	.4338	.4481	.4527	.3961	.4668	.4904	.4108
24	.0857	.3772	.3734	.3961	.3395	.3734	.4338
Max	.9055	.9335	.8962	.9709	.823	.9335	.9896
Min	.0857	.3772	.3734	.3772	.3395	.3734	.4108
Avg	.5574	.5856	.5635	.5811	.5285	.5832	.5928

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 202 / 11 Kv Walwa Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9757	.168	.168	.3772	1.5384	1.7147	1.4403
2	1.9757	.168	.168	.3772	1.5384	1.7718	1.4403
3	2.0081	.168	.168	.3584	1.5384	1.8099	1.4403
4	2.1052	.168	.168	.3584	1.5384	1.8652	1.8861
5	2.17	.2241	.168	.415	1.6289	1.8652	2.2634
6	2.2348	.3077	.2241	.4715	2.0144	2.0576	2.5377
7	.3206	.3258	.3174	.4904	.462	.4294	.547
8	.3018	.3511	.3361	.4338	.4435	.5041	.3755
9	.2713	.3142	.2987	.415			.3338
10	2.7808	2.8704	2.5101	.415		.4287	.0263
11	3.4252	3.2602	2.8654	.415		.381	.0657
12	3.4591	3.4019	3.1901	.415		.3749	.0833
13	3.4421	3.5082	3.1893	.415		.3749	.0833
14	3.1878	3.5082	3.2247	.3772		.3749	.0412
15	3.476	3.4551	3.4389	.3772		.3887	.0377
16	3.2217	3.1007	3.152	.3772		.3353	.0545
17	2.7681	2.9412	2.8833	.543	.3734	.439	.1886
18	.2075	.2054		.415	.4294	.362	.2452
19		.2614	.4715	.415	.2378	.4344	.2896
20	.2926	.2614	.4715	.4338	.567	.4054	.2715
21	.2772	.2614	.4338	.4338	.3734	.3909	.2743
22	.2241	.2054	.415	.4338	.3734	.4715	.2172
23	.1867	.1867	.3961	1.7187	1.7528	1.6057	1.5775
24	.0686	.168	.168	.3961	1.5927	1.7718	1.587
Max	3.476	3.5082	3.4389	1.7187	2.0144	2.0576	2.5377
Min	.0686	.168	.168	.3584	.2378	.3353	.0263
Avg	1.7557	1.2413	1.2533	.4699	1.0251	.8938	.7211

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 203 / 11 Kv.Bawachi LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6155	2.5606	2.6139	2.0165	1.307	2.2032
2	2.6155	2.5606	2.6139	2.0165	1.2803	2.2032
3	2.5972	2.5606	2.6139	2.0165	1.307	2.2032
4	2.5606	2.5606	2.6139	2.0538	1.307	2.3152
5	2.652	2.5606	2.6139	2.1658	1.6804	2.4646
6	2.7435	2.8715	2.894	2.2779	1.8671	2.6513
7	2.9995	2.9081	2.9874	2.2965	2.5206	2.7633
8	3.1093	2.9447	2.894	2.3899	2.6139	2.9313
9	3.0178	3.0178	2.894	2.4459	2.5953	2.9874
10	3.0544	3.0361	3.0434	2.4646	.2801	2.963
11	3.0544	3.0727	3.062	2.3525	2.4086	3.0178
12	3.091	3.091	.8215	2.2592	2.9687	3.0361
13	3.1093	3.091		2.2592	2.9874	2.9447
14	2.7069	3.091	.9335	2.2592	3.006	2.9813
15	3.0727	3.091	3.0807	2.2592	2.9127	2.9264
16	1.1888	1.1157	1.3256	1.0829	1.0456	1.0974
Max	3.1093	3.091	3.0807	2.4646	3.006	3.0361
Min	1.1888	1.1157	.8215	1.0829	.2801	1.0974
Avg	2.7618	2.7584	2.4670	2.1635	2.0055	2.6056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 204 / 11 KV Padawalwadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	1.5565	1.5746	1.2431	.128	.1307	.1132
2	.132	1.5565	1.5746	1.2431	.128	.1307	.1132
3	.132	1.5565	1.5746	1.2431	.128	.1307	.1132
4	.1698	1.5565	1.6289	1.3413	.128	.1307	.1509
5	.1886	1.5565	.0149		.1463	.1867	.2263
6	.2829	1.861	1.7375	1.5581	.2561	.3361	.3018
7	.3395	.2896	.2987	.3395	.3109	.3361	.3395
8	.3018	.2896	.2614	.2641	.2561	.2614	.2452
9	.2075	.1991	.2241	.2075	.1886	.168	.1886
10	.1886	.181	.1494	2.1216	.5041	2.2672	1.9725
11	.1698	.1448	.168	2.5526	2.4863	2.5587	2.4863
12	.1509	.1267	.168	2.7681	2.4863	2.753	2.7018
13	.132	.1086	.168	2.7362	2.652	2.6073	2.5857
14	.132	.1086	.1307	2.7526		2.4291	2.5029
15	.132	.1086	.1307	2.7526		2.5263	2.4863
16	.132	.1097	.1494	2.7349	2.3205	2.4291	2.3371
17	.1886		.1698	2.5819	2.2542	2.2672	1.9725
18	.2452	.2614	.1886	.1829	.2641	.2263	.2263
19	.2641	.2641	.2452	.2561		.2829	.2263
20	.2378	.2452	.2263	.2012	.2378	.2641	.2263
21	.2075	.2241	.1886	.1829	.1867	.2075	.2263
22	.1698	.1886	.1886	.1646	.168	.1698	.1698
23	1.5223	1.5746	1.2266	.128	.168	.132	.132
24	.0343	1.6057	1.5746	1.2597	.128	.1307	.1132
Max	1.5223	1.861	1.7375	2.7681	2.652	2.753	2.7018
Min	.0343	.1086	.0149	.128	.128	.1307	.1132
Avg	.2414	.6815	.5817	1.3398	.7393	.9609	.9232

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 205 / 11 KV Hutatma Dudh Sangh NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975	.6161	.6348	.5601	.4854	.6161	.6722
2	.5975	.6161	.6161	.5601	.4854	.5975	.6722
3	.5601	.6161	.6535	.5601	.4854	.5975	.6722
4	.5601	.6161	.6535	.5601	.4854	.5975	.6535
5	.5788	.6535	.6908	.5228	.4854	.6161	.6908
6	.5975	.6535	.6908	.5228	.5041	.5975	.6908
7	.5975	.6535	.7095	.5228	.5041	.6161	.7282
8	.5788	.6908	.7095	.5041	.5228	.6535	.7655
9	.6908	.7095	.7468	.5041	.4854	.6722	.7655
10	1.7364	.7655	.7655	.5228	.5975	.7095	.6722
11	.7468	.7655	.7655	.6348	.6161	.7282	.6908
12	.7655	.8215	.7655	.7095	.6348	.7655	.7655
13	.7655	.7842	.6908	.6348	.6161	.7095	.6535
14	.7468	.7842	.6535	.5601	.5601	.6722	.6535
15	.7282	.7468	.5601	.5415	.5601	.6535	.6535
16	.7282	.7095	.4294	.5415	.5601	.6722	.6908
17	.7282	.8029	.5041	.5415	.5415	.7095	.6908
18	.6908	.8215	.5228	.5788	.7095	.7095	.7095
19	.7842		.5228	.5788		.7095	.6348
20	.6584	.7842	.5601	.5601	.5847	.6908	.6348
21	.6908	.7468	.6161	.5601	.6348	.6722	.6348
22	.6908	.7282	.5788	.5228	.6348	.6722	.6722
23	.6535	.6161	.5601	.5788	.6908	.6908	.6348
24	.5975	.6535	.6161	.5788	.5601	.5975	.6908
Max	1.7364	.8215	.7655	.7095	.7095	.7655	.7655
Min	.5601	.6161	.4294	.5041	.4854	.5975	.6348
Avg	.7113	.7111	.6340	.5609	.5628	.6636	.6831

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 206 / 11KV Ahirwadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1886	.168	.1886	.1886	.168	.1698
2	.168	.1886	.168	.1886	.1886	.168	.1698
3	.168	.1886	.168	.1886	.1886	.168	.1698
4	.1848	.1886	.168	.1886	.1886		.1886
5	.2172	.2829	.2241	.3018	.2641		.2641
6	.3841	.3961	.3734	.4338	.415	.3361	.3395
7	.415	.415	.4294	.4904	.4338	.4668	.415
8	.3696	.3961	.3734	.415	.4108	.4668	.3961
9	.3921	.2896	.3174	.3511	.2614	.2801	.4066
10	.2987	.2829	.2534	.2772	.2801	.2957	.2987
11	.2801	.2641	.2534	.2402	.2614	.2378	.2743
12	.2452	.2075	.2507	.2033		.2033	.2149
13	.2054	.2075	.2172	.181			.1991
14	.1867	.1867	.2172	.181			.181
15	.1867	.1867	.1698	.1629			.1829
16	.168	.197		.1629	.2801	.2957	.2218
17	.2452	.1949	.3547	.2715	.3174	.3174	.2218
18	.3018	.3734	.4108	.3475	.3921	.3961	.3142
19	.4338	.4294	.4715	.4207		.4527	.4481
20	.4207	.4294	.4338	.3658	.3841	.4338	.4108
21	.3584	.3361	.3772	.3547	.4338	.3961	.3772
22	.2641	.2801		.2801	.5228	.2829	.2481
23	.1886	.1867	.2075	.1867	.1867	.2075	.1791
24	.0686	.1886	.1867	.1886	.1886	.1867	.1886
Max	.4338	.4294	.4715	.4904	.5228	.4668	.4481
Min	.0686	.1867	.168	.1629	.1867	.168	.1698
Avg	.2634	.2702	.2815	.2738	.3046	.3031	.2700

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 207 / 11KV Nagthane AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6964	.0566	.0566	.0566	.5668	.6001	.5571
2	.6964	.0566	.0566	.0566	.5668	.5935	.5571
3	.6802	.0566	.0566	.0566	.5668	.6001	.5571
4	.6802	.0566	.0566	.0566	.5668	.6001	.5735
5	.6964	.0566	.0566	.0566	.5668	.6001	.6226
6	.6964	.0566	.0566	.0566	.6478	.6274	.6554
7	.0566	.0566	.0566	.0566	.0566	.0566	.0566
8	.0566	.0754	.0566	.0566	.0754	.0566	.0566
9	.0566	.0566	.0566	.0566	.0566	.0566	.0566
10		.7293	.9878	.0566	.0566	.0566	.0566
11	1.1012	.8619	1.085	.0566	.0566	.0566	.0566
12	1.166	.9614	1.1012	.0566	1.5497	.0754	.0566
13	1.166	1.1271	1.0364	.0566	.0566	.0566	.0754
14	1.1336	1.2597	1.0364	.0566	.0566	.0566	.0754
15	1.085	1.2289	1.1012	.0566	.0566	.0754	.0754
16	1.0978	1.1469	1.0202	.0566	.0566	.0566	.0566
17	.9667	1.0322	.9393	.0377	.0566	.0566	.0566
18	.0754	.0566	.0566	.0566	.056	.0566	.0566
19	.0566	.056	.0566	.0566		.0566	.0566
20	.0549	.0566	.0566	.0566	.0549	.0566	.0566
21	.0754	.0566	.0566	.0566	.056	.0566	.0566
22	.0566	.0566	.0566	.0566	.0566	.0566	.0566
23	.0754	.0566	.0566	.583	.5426	.5407	.5506
24	.6964	.0566	.0566	.0566	.5668	.5935	.5571
Max	1.166	1.2597	1.1012	.583	1.5497	.6274	.6554
Min	.0549	.056	.0566	.0377	.0549	.0566	.0566
Avg	.5706	.3863	.3839	.0777	.3021	.2374	.2330

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 208 / 11KV Kisan No 3 LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1109	.1109	.0183	.0185	.0187	.0185
2	.1109	.1097	.0183	.0185	.0183	.0185
3	.1109	.1109	.0183	.0185	.0183	.0185
4	.1109	.1109	.0183	.0185	.0183	.0185
5	.1109	.1109	.0189	.0185	1.4815	.0185
6	.1109	.1109	.0183	.1109	1.4815	.0185
7	.1109	.1109	.112	.1109	.0183	.0185
8	.1109	.1109	.1097	.1109	.0183	.0185
9	.0185	.1109	.1097	.1109	.0183	.0185
10	.0185	.1109	.1109	.1109	.0183	
11	.1109	.1109	.1109	.1109	.0183	.0185
12	.1109	.1109	.1109	.1109	.0183	.0185
13	.1109	.1109	.1109	.1109	.0183	.0185
14	.1109	.1109	.1109	.1109	.0183	.0185
15	.1109	.1109	.1109	.1109	.0183	.1294
16	.1109	.1109	.112	.1109	.0183	.0185
Max	.1109	.1109	.112	.1109	1.4815	.1294
Min	.0185	.1097	.0183	.0185	.0183	.0185
Avg	.0994	.1108	.0762	.0820	.2012	.0259

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 401 / 33KV Walwa LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4938	.5487	.5487	.7133	.9877	1.2071
2	.4938	.5487	.5487	.7133	1.4815	1.2071
3	.5487	.5487	.5487	.9877	1.4815	1.2071
4	.5487	.5487	.5487	.9877	1.4815	1.4815
5	.5487	.5487	.5487	1.2071	1.4815	1.4815
6	.6036	.5487	.5487	1.2071	1.4815	1.5912
7	.6036	.5487	.5487		1.4815	1.6461
8	.6036	.5487	.2195	1.5912	1.6461	1.5912
9	.6036	.7133	.6584	1.5912	1.6461	1.5912
10	.2195	.7133	.7133	1.5912	1.5912	1.7558
11	.2195	.7133	.7133	1.5912	1.5912	1.9753
12	.2195	.7133	.823	1.5912	1.5912	2.0302
13	.2195	.7133	.7133	1.5912	1.5912	1.9753
14	.2195	.7133	.7133	1.5912	1.5912	1.9753
15	.2195	.7133	.9877	1.5912	1.5912	1.9753
16	.2195	.2195	.9877	.9328	.9328	1.262
Max	.6036	.7133	.9877	1.5912	1.6461	2.0302
Min	.2195	.2195	.2195	.7133	.9328	1.2071
Avg	.4115	.6001	.6482	1.2986	1.4781	1.6221

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 201 / 11 Kv. Shigaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6455	.0171	.0114	.0221	.6344	.5944	.6622
2	.6622	.0191	.0111	.0229	.643	.602	.6622
3	.6573	.0191	.0111	.0229	.6485	.602	.6706
4	.6687	.0198	.0111	.0229	.6398	.6097	.6706
5	.6748	.0206	.0114	.0232	.6485	.6327	.6706
6	.6516	.0372	.0114	.0236	.7375	.6562	.7225
7	.0657	.0383	.0131	.036	.0549	.0533	.0457
8	.0594	.0259	.0171	.0354	.0389	.0394	
9	.0457	.0263	.0171	.0229	.0412	.0377	.0263
10	1.1069	1.07	1.3123	.0389	.0417	.0236	.0244
11	1.4998		1.5497	.0286	.021	.021	.0274
12	1.4998		1.5497	.0183	.0225	.0198	.0263
13	1.4998	1.4232	1.531	.0152	.0191	.0198	.0229
14	1.5364	1.4232	1.531	.0152	.0263	.0229	.0164
15	1.5181	1.4352	1.531	.0149	.0187	.0229	.0187
16	1.4685	1.3717	1.2498	.0234	.032	.0229	.0198
17	1.3413	1.3117	1.1888	.0377	.0337	.0229	.0225
18	.0286	.0446	.0297	.0372	.0377	.0314	.0337
19	.0274	.0446	.0286	.0354	.0394		.0343
20	.0257	.0446	.0286	.0457	.0488	.032	.0377
21	.0257	.0297	.0274	.0326	.0337	.0217	.0394
22	.0251	.0332	.0274	.028	.0372	.0217	.0412
23	.024	.0171	.0269	.6226	.5213	.6081	.4451
24	.6516	.0229	.0114	.0229	.6371	.5792	.6287
Max	1.5364	1.4352	1.5497	.6226	.7375	.6562	.7225
Min	.024	.0171	.0111	.0149	.0187	.0198	.0164
Avg	.6837	.3861	.4891	.0520	.2357	.2303	.2421

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 202 / 11 Kv. Bhadkambe LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3841	.3681	.004	.3761	.3982	.3982
2	.3801	.3772	.004	.3801	.3982	.3982
3	.3841	.3772	.0067	.3801	.3982	.4024
4	.3982	.3772	.0057	.3801	.4024	.4024
5	.3898	.3856	.0067	.3801	.4024	.4024
6	.394	.3898	.0067	.3721	.4024	.3982
7	.3898	.3898	.0067	.3721	.3982	.3982
8	.394	.394	.0067	.3761	.3982	
9	.4024	.394	.0067	.3761	.3982	.3982
10	.4024	.3429	.004	.4024	.3982	.3982
11	.3982		.004	.3898	.3761	.3982
12	.3982		.004	.3982	.3721	.3982
13	.3982	.4024	.004	.4024	.3721	.4024
14	.4024	.3658	.0046	.3982	.3761	.4024
15	.4024	.3658	.0046	.394	.3801	.4024
16	.2402	.2195	.0051	.2229	.2103	.2353
22		.0332				
Max	.4024	.4024	.0067	.4024	.4024	.4024
Min	.2402	.0332	.004	.2229	.2103	.2353
Avg	.3849	.3455	.0053	.3751	.3801	.3890

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 203 / 11 Kv.Pokharni Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0358	.0354	.0377	.0554	.0554	.0532	
2	.0537	.0358	.0377	.037	.0549	.0543	.037
3	.0554	.0362	.0377	.0373	.056	.0549	.037
4	.0732	.0366	.0566	.056	.0554	.0554	.0373
5	.0724	.0549	.0566	.0747	.0732	.0747	.056
6	.0914	.0924	.0747	.1097	.0739	.0934	.0554
7	.0747	.0924	.132	.1097	.0924	.1097	.0739
8	.1017	.0895	.132	.0905	.0724	.0905	
9	.0857	.0514	.0943	.0716	.0549	.0686	.0914
10	.1063	.12	.0905	.0343	.0549	.0857	.0739
11	.08		.0663	.0354	.0739	.0829	.0514
12	.0633		.0648	.0358	.0549	.064	.0526
13	.0633	.0514	.0486	.0343	.0366	.048	.0532
14	.064		.0686	.0339	.0377	.048	.0543
15	.081	.0857	.0686	.1006	.0373	.048	.0537
16	.1326		.0701	.0332	.0347	.0781	.0543
17	.1147	.0514	.0543	.0543	.0351	.064	.0579
18	.0972	.12	.0549	.0739		.0724	.064
19	.1052	.1029	.0549	.128	.1075	.0905	.0829
20	.1052	.1029	.0914	.1109	.128	.0905	.1109
21	.0886	.1029	.0914	.0924	.128	.0905	.0732
22	.0716	.0747	.0914	.0554	.0924	.0724	.0554
23	.0354	.0566	.0543	.0366	.0537	.0543	.0566
24	.0686	.0351	.0377	.0537	.0537	.0358	.0354
Max	.1326	.12	.132	.128	.128	.1097	.1109
Min	.0354	.0351	.0377	.0332	.0347	.0358	.0354
Avg	.0800	.0714	.0695	.0648	.0660	.0700	.0599

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 204 / 11 Kv Shigaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.132	.1132	.1509	.1463	.132	.1509
2	.1294	.132	.1132	.1509	.1663	.132	.1509
3	.1494	.132	.1509	.1509	.168	.132	.1509
4	.2241	.132	.2263	.1509	.1663	.132	.1509
5	.2829	.1698	.2829	.1698	.1829	.2452	.1886
6	.2987	.3734	.3395	.3734	.3734	.3395	.3734
7	.3734	.4108	.4108	.4108	.4251	.4481	.4108
8	.3475	.3292	.3658	.3658	.2743	.4066	
9	.3077	.2534	.3511	.3258	.2534	.2715	.2896
10	.2328	.2328	.2328	.2507	.2126	.2126	.2303
11	.1791		.1991	.2279	.2126	.2126	.2035
12	.1791		.1991	.1928	.1949	.1052	.2058
13	.1448	.2328	.197	.1734	.1753	.1052	.2126
14	.1646	.2058	.2126	.1578	.156	.124	.2126
15	.1646	.2241	.2126	.156	.1578	.1433	.1791
16	.1772	.2012	.1753	.1734	.1734	.1578	.181
17	.1772	.2378	.2126	.2658	.2103	.2103	.1886
18	.2454	.2987	.2835	.3403	.3155	.3429	.1791
19	.3582	.4525	.3224	.4435	.4163	.3506	.4163
20	.3658	.4024	.362	.4207	.4024	.3544	.3696
21	.3326	.3361	.3658	.3696	.3361	.3361	.3292
22	.2587	.2801	.3361	.2452	.3018	.2641	.028
23	.1791	.1886	.1886	.1698	.1698	.1886	.1698
24	.1132	.132	.132	.1509	.1509	.1509	.1509
Max	.3734	.4525	.4108	.4435	.4251	.4481	.4163
Min	.1132	.132	.1132	.1509	.1463	.1052	.028
Avg	.2299	.2495	.2494	.2495	.2392	.2291	.2227

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 205 / 11 Kv Pokharni Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0183	.6161	.7482	.4988	.0171	.0366	.0366
2	.0183	.6161	.7482	.4988	.0177	.0366	.037
3	.0179	.6241	.7482	.5053	.0187	.037	.037
4	.0177	.6241	.7579	.5053	.0183	.037	.0373
5	.0179	.639	.7827	.5053	.0187	.0373	.0373
6	.0362	.7225	.7926	.5487	.037	.0566	.0566
7	.037	.0747	.0754	.0747	.037	.0747	.0566
8	.0572	.0739	.0754	.0739	.0351	.0554	
9	.0339	.0366	.0686	.0554	.0354	.037	.0373
10	.0474		.0362	.8488	.7621	.7316	.724
11	.032		.0362	1.0059	1.0235	.8619	1.2346
12	.032		.0358	1.1561	1.1584	.7735	1.3426
13	.0324	.0377	.0358	1.1728	1.1439	.8619	1.358
14	.032	.0377	.0343	1.2037	1.1294	1.0059	1.3413
15	.032	.0189	.0343	1.2193	1.1138	1.0059	1.2963
16	.0156	.0189	.0339	1.1439	1.0235	.9755	1.3117
17	.0158	.0189	.0532	1.2003	.9907	.8749	1.1003
18	.0158	.0189	.0543	.0497	.0537	.0362	.0469
19	.0343	.0189	.0543	.0509	.0732	.0362	.0474
20	.0343	.0189	.0543	.0514	.0732	.0362	.0537
21	.0351	.0189	.0537	.0335	.0549	.0537	.0532
22	.0351	.0189	.0532	.0168	.0543	.0358	.0514
23	.5792	.0189	.4401	.0158	.0358	.0354	.0339
24	.0137	.6748	.7482	.4988	.0156	.0362	.0343
Max	.5792	.7225	.7926	1.2193	1.1584	1.0059	1.358
Min	.0137	.0189	.0339	.0158	.0156	.0354	.0339
Avg	.0517	.2356	.2731	.5389	.3725	.3237	.4507

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 206 / Hutatma Sureshkumar LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0189	.0191	.0191	.0191
2	.0191	.0191	.0189	.0191	.0191	.0191
3	.0191	.0191	.0189	.0191	.0191	.0191
4	.0191	.0191	.0189	.0191	.0191	.0191
5	.0191	.0191	.0189	.0191	.0191	.0191
6	.1109	.0191	.0189	.0191	.0191	.0191
7	.2926	.132	.1294	.1494	.1307	.132
8	.2772	.2801	.2012	.1494	.1294	
9	.2926	.2987	.2743	.1494	.1294	.2801
10	.2987	.2743	.2987	.1478	.2987	.2829
11	.2801		.2801	.1463	.2614	.2957
12	.2772		.2801	.1478	.2614	.2957
13	.2772	.2926	.2801	.1463	.2614	.2957
14	.2772	.2926	.2772	.1463	.1294	.2926
15		.2926	.2772	.1463	.1294	.2896
16		.2926	.2772	.1448	.1294	.2587
Max	.2987	.2987	.2987	.1494	.2987	.2957
Min	.0191	.0191	.0189	.0191	.0191	.0191
Avg	.1771	.1622	.1681	.0993	.1235	.1692

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 207 / 11KV Bahadurwadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2787	.0189	.0189	.0189	.373	.208	.2408
2	.301	.0189	.0189	.0189	.4066	.2107	.2408
3	.3048	.0189	.0189	.0189	.4251	.1957	.2439
4	.2934	.0189	.0189	.0189	.4294	.1981	.2439
5	.3121	.0189	.0189	.0189	.4251	.2656	.2743
6	.3041	.0187	.0189	.0187	.4435	.2812	.301
7	.056	.0185	.0189	.0187	.0554	.0189	.0189
8	.0354	.0181	.0189	.0168	.0189	.0187	
9	.0358	.0183	.0189	.0166	.0189	.0177	.0189
10	.4374	.6173	.5487	.0191	.0185	.0187	.0189
11	.4572		.6401	.0189	.0185	.0189	.0189
12	.5792		.6401	.0189	.0185	.0189	.0189
13	.5792	.7202	.6401	.0171	.0183	.0189	.0189
14	.5937	.5487	.6401	.016	.0187	.0189	.0187
15	.5937	.6516	.6401	.0179	.0187	.0189	.0189
16	.5937	.5647	.5647	.0126	.0183	.0189	.0189
17	.6097	.7316	.5647	.0162	.0185	.0187	.0189
18	.0164	.0183	.0133	.0328	.016	.0166	.0173
19	.0171	.0189	.0126	.0343	.0164	.0185	.0177
20	.0171	.0189	.0126	.0347	.0191	.0185	.0189
21	.0175	.0189	.0124	.0185	.0185	.0187	.0185
22	.0177	.0189	.0124	.0189	.0187	.0187	.0187
23	.0183		.0183	.3121	.2641	.2317	.2027
24	.2751	.0177	.0189	.0189	.3121	.2201	.2317
Max	.6097	.7316	.6401	.3121	.4435	.2812	.301
Min	.0164	.0177	.0124	.0126	.016	.0166	.0173
Avg	.2810	.1959	.2146	.0322	.1420	.0878	.0982

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 401 / 33KV LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8488	.9054	.9054	.9054	.743	.8488
2	.8488	.9054	.9054	.9619	.8488	.8488
3	.8488	.9054	.9619	.9619	.8488	.8488
4	.9054	.9054	.9619	.9619	.8488	.8488
5	.9054	.9054	.9619	.9619	.8488	.8488
6	.9054	.9619	.9619	.9619	.8488	.8488
7	.9054	.9619	.9619	.9619	.8488	.8488
8	.9054	.9054	.9619	.9619	.9054	
9	.9619	.9619	.9054	.9619	.9619	.5658
10	.9619	.9619	.9619	1.0185	.9619	.2263
11	.9619		.9619	.9619	.9054	.679
12	.9619		.9619	.9619	.9054	
13	.9619	.9619	.9619	.9619	.9054	.9054
14	.9619	.6224	.9619	.7922	.9619	.9054
15	.9619	.6224	.9619	.9619	.9619	.9054
16	.8488	.5093	.7922	.8488	.8488	.7922
Max	.9619	.9619	.9619	1.0185	.9619	.9054
Min	.8488	.5093	.7922	.7922	.743	.2263
Avg	.9160	.8569	.9407	.9442	.8846	.7801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 201 / 11 KV Krishnamai AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3064				.1844	.1658	.1638
2	.3064				.1844	.1677	.1638
3	.3064				.1844	.1696	.1638
4	.3064				.1844	.1677	.1696
5	.3064				.1677	.1696	.1696
6	.3064				.1677	.1715	.1696
10	.3856	.4755	.5304				
11	.57		.5636				
12	.6464	.4572	.5304				
13	.6796	.4572	.5304				
14	.7209	.4755	.5304				
15	.7209	.5201	.4973				
16	.7459	.5182	.5304				
17	.6718	.4973	.4534				
23				.1943	.1457	.1658	.2267
24	.3201				.2012	.1562	.1638
Max	.7459	.5201	.5636	.1943	.2012	.1715	.2267
Min	.3064	.4572	.4534	.1943	.1457	.1562	.1638
Avg	.4866	.4859	.5208	.1943	.1775	.1667	.1738

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 202 / 11KV Mahalaxmi LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2403	1.258	1.3394	.0309	.032	.6089
2	1.2403	1.2894	1.3394	.0309	.0358	.6089
3	1.2403	1.2894	1.3394	.0309	.0349	.6089
4	1.2403	1.2894	1.3394	.0309	.0274	.6089
5	1.2403	1.2894	1.3394	.0309	.032	.6089
6	1.2403	1.2894	1.3394	.0309	.0383	.6089
7	1.262	1.2757	1.3394	.0514	.0404	.3224
8	1.262	1.2757	1.3394	.0412	.0495	.3189
9	1.2971	1.3112	1.2894	.0412	.0553	.7164
10	1.3937	1.3253	1.3032	.1029	.6024	1.3032
11	.7442	1.3253	.6516	.6335	.6024	1.3032
12	.7362	.7164	.6878	.7421	.6661	1.3032
13	.7186	.7164	.6805	.7316	.6661	1.3032
14	.7186	.7164	.6805	.7316	.6733	1.3032
15	1.3496	.7164	.6805	.7316	.6733	1.3032
16	1.3496	.7164	.6805	.6135	.6733	1.3032
18						1.3032
Max	1.3937	1.3253	1.3394	.7421	.6733	1.3032
Min	.7186	.7164	.6516	.0309	.0274	.3189
Avg	1.1421	1.1125	1.0856	.2879	.3064	.9080

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 203 / 11KV Yashwant AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7042			.5487	.583	.4641
2	.7042			.5487	.6001	.4641
3	.7042			.5487	.5935	.4641
4	.7042			.5375	.5935	.4694
5	.7042			.5548	.6173	.4694
6	.7042				.6516	.5365
10	1.286	1.286	1.3032			
11	1.5947	1.3375	1.406			
12	1.6108	1.2003	1.4746			
13	1.6108	1.2003	1.5432			
14	1.6278	.8916	1.5432			
15	1.4746	1.0631	1.5089			
16	1.4074	1.2346	1.4403			
17	1.3413	1.2689	1.4403			
23				.4801	.4475	.4973
24	.7042			.5316	.5765	.4915
Max	1.6278	1.3375	1.5432	.5548	.6516	.5365
Min	.7042	.8916	1.3032	.4801	.4475	.4641
Avg	1.1255	1.1853	1.4575	.5357	.5829	.4821

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 204 / 11 KV Ashta PWW

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0709	.0709		.0716	.0709	.0709	
2	.0709	.0709	.0724	.0716	.0701	.0709	.0709
3	.0709	.0716	.0724	.0716	.0701	.0709	.0709
4	.0709	.0716	.0724	.0716	.0701		.0716
5	.0709	.0716		.0716	.0701	.0701	.0716
6	.0709	.0716	.0724	.0716	.0701	.0724	.0716
7	.0709	.0709	.0724	.0716	.0693	.0716	.0716
8	.0709	.0709	.0724	.0716	.0693	.0709	.0709
9	.0709	.0716	.0716	.0716	.0693	.0716	.0709
10	.0724	.0716	.0716	.0716	.0709	.0716	.0716
11	.0724	.0716	.0716	.0716	.0709	.0716	.0716
12	.0716	.0716	.0716	.0716	.0701	.0709	.0716
13	.0716	.0716	.0716	.0716	.0693	.0709	.0716
14	.0716	.0716	.0716	.0716	.0693	.0709	.0716
15	.0724	.0716	.0716	.0716	.0701	.0709	.0716
16	.0716	.0716	.0716	.0716	.0701	.0709	.0716
17	.0701	.0716	.0716	.0709	.0709	.0716	.0716
18	.0701	.0716	.0701	.0701	.0701		.0686
19	.0701	.0709	.0701	.0701	.0693	.0701	.0686
20	.0701	.0724	.0701	.0709	.0701	.0701	.0686
21	.0693	.0724	.0686	.0701	.0693	.0701	.0686
22	.0701	.0724	.0701	.0709	.0701	.0701	.0686
23	.0701	.0724	.0686	.0709	.0709	.0701	.0686
24	.0709		.0724	.0701	.0709	.0709	.0701
Max	.0724	.0724	.0724	.0716	.0709	.0724	.0716
Min	.0693	.0709	.0686	.0701	.0693	.0701	.0686
Avg	.0709	.0716	.0713	.0712	.0701	.0709	.0706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 205 / 11KV Tryambkeshwar LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0044	.0566	.0053	.0053	.005	.0042
2	.0044	.0747	.0053	.0053	.0053	.0042
3	.0044	.0732	.0053	.0053	.0059	.0046
4	.0044	.0732	.0046	.0053	.0059	.0046
5	.0044	.0924	.0051	.0053	.0055	.0042
6	.0044	.0924	.0059	.0053	.0063	.0046
7	.112	.0914	.0059	.0053	.0452	.112
8	.2054	.1734	.1772	.1372	.0926	.197
9	.197	.1753	.1753	.1372	.2149	.197
10	.2172	.1578	.0053	.1372	.197	.197
11	.2149	.1753	.1372	.1372	.197	.197
12	.2353	.1772	.1372	.1387	.1595	.197
13	.2353	.1753	.1372	.1372	.1949	.197
14	.2353	.1772	.1372	.1387	.1949	.197
15	.2353	.1772	.1715	.1387	.1949	.197
16	.2353	.1578	.1029	.1372	.1949	.197
Max	.2353	.1772	.1772	.1387	.2149	.197
Min	.0044	.0566	.0046	.0053	.005	.0042
Avg	.1343	.1313	.0762	.0798	.1075	.1195

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 206 / 11KV Dhadak LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3321	.2656	.2622	.2881	.2372	.192
2	.3321	.2688	.2622	.2881	.2458	.192
3	.3321	.2688	.2622	.2881	.2429	.192
4	.3321	.2656	.2622	.2881	.2429	.192
5	.3321	.2721	.2622	.2881	.2458	.2241
6	.3321	.2721	.2785	.2881	.2486	.2241
7	.4801	.2656	.6882	.2881	.2401	.2241
8	.6882	.6802	.6882	.2915	.2458	.2241
9	.8619	.8848	.8848	.3239	.3725	.2241
10	.9054	.7956	.3932	.3887	.3563	.2294
11	.7545	.6962	.7293	.3521	.3563	.2294
12	.7373	.663	.7956	.3563	.373	.2294
13	.8356	.663	.7865	.3521	.373	.2294
14	.8619	.663	.7865	.3563	.3521	.2294
15	.8453	.6554	.7865	.3521	.3521	.2294
16	.5506	.3315	.6554	.3437	.3521	.2294
Max	.9054	.8848	.8848	.3887	.373	.2294
Min	.3321	.2656	.2622	.2881	.2372	.192
Avg	.5946	.4945	.5490	.3208	.3023	.2184

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 201 / 11KV Bagni AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0351	1.1336	.9831	1.0814	.0366	.0543	.0554
2	.0351	1.1469	.9555	1.0185	.0366	.0549	.0554
3	.0351	1.1603	.9442	1.0814	.0366	.0543	.0358
4	.0358	1.1469	.9555	1.0494	.037	.0537	.0543
5	.0537	1.1633	.9945	1.1142	.0554	.0537	.0549
6	.0549	1.1934	1.0277	1.0957	.056	.0732	.056
7	.0537	.0701	.0554	.128	.0716	.0924	.056
8	.0732	.0895	.0732	.0543	.0732	.0905	.056
9	.0633	.0514	.0554	.0351	.0492	.0701	.0543
10	.064	.0537	.0549	1.5729	1.7695	1.6078	1.7238
11	.0509	.0354	.0554	1.989	2.0553	1.989	
12	.0537	.0343	.0554	2.1879	2.0222	1.9433	1.9662
13	.0543	.0526	.0549	2.1879	1.9227	1.917	2.0553
14	.0537	.0351	.0554	2.1628	1.7204	1.9227	1.9595
15	.0537	.0351	.0549	2.0567	1.7859	1.8299	1.9989
16	.0543	.0351	.0554	2.0567	1.6712	1.8515	2.0153
17	.0497	.0351	.0537	2.0809	1.6409	1.8299	1.8785
18	.0709	.0351	.0543	.0526	.0509	.0532	.0554
19	.0724	.0351	.0537	.0543	.0709	.0554	.0554
20	.0532	.0532	.0543	.0532	.0732	.0732	.0543
21	.0526	.0532	.0549	.0543	.0739	.0549	.0537
22	.0514	.0526	.0554	.0537	.0716	.0526	.0549
23	1.1385	.9922	1.1012	.0358	.0537	.0532	.0554
24	.0343	1.1203	1.0442	1.1271	.0366	.0537	.0526
Max	1.1385	1.1934	1.1012	2.1879	2.0553	1.989	2.0553
Min	.0343	.0343	.0537	.0351	.0366	.0526	.0358
Avg	.0978	.4089	.3709	1.0160	.6446	.6619	.6286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 202 / 11KV Ashta Chadoli Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0312	.6226	.5569	.5121	.0316	.0474	.0463
2	.0312	.6226	.5335	.5182	.0316	.0486	.0463
3	.0312	.5992	.5335	.5121	.0316	.048	.0469
4	.0305	.5992	.5401	.506	.0474	.048	.0469
5	.0457	.6062	.5556	.5312	.0625	.0486	.0469
6	.0617	.5761	.6093	.5376	.0625	.0655	.0781
7	.1006	.0819	.0772	.0625	.0762	.0819	.0772
8	.0709	.0497	.0625	.0625	.0772	.0663	.0781
9	.0716	.0469	.0617	.061	.0655	.0655	.0474
10	.0526	.0312	.0625	.5487	.7202	.7459	.7042
11	.0509	.0312	.0633	.7011	.6882	.8029	
12	.0332	.0469		.679	.7459	.8288	.8002
13	.0339	.0457		.6481	.7209	.8356	.7125
14	.0332	.0452		.6958	.7625	.7956	.823
15	.0328	.0469		.6562	.7209	.7373	.8124
16	.0332	.0469		.7209	.7293	.7449	.7748
17	.0328	.0463		.7274	.7956	.7682	.7186
18	.0497	.0602	.0625	.0469	.1017	.064	.0474
19	.0678	.0762	.0633	.0625	.0829	.0791	.0617
20	.0663	.0772	.0625	.0625	.0678	.0781	.0617
21	.0671	.0762	.0617	.0617	.0686	.0625	.0625
22	.0497	.0753	.0457	.0463	.0686	.0625	.0625
23	.5571	.5624	.4843	.0309	.0514	.0633	.0469
24	.5166	.6154	.5864	.506	.0316	.0497	.0469
Max	.5571	.6226	.6093	.7274	.7956	.8356	.823
Min	.0305	.0312	.0457	.0309	.0316	.0474	.0463
Avg	.0896	.2370	.2790	.3957	.2851	.3016	.2717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 203 / 11KV SHIGAON RIVER AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1797	.0366	.037	.037	.9175	.852	.7373
2	1.1797	.0362	.037	.037	.9175	.8322	.6964
3	1.1797	.0366	.0373	.037	.9175	.8259	.6882
4	1.1934	.0362	.0377	.0373	.9175	.8192	.7042
5	1.2266	.0366	.0377	.037	.9175	.8029	.7202
6	1.2308	.037	.0377	.037	.9503	.7956	.7611
7	.0377	.037	.037	.0373	.0324	.0351	.0377
8	.0377	.037	.0373	.037	.0358	.0366	.0373
9	.037	.037	.037	.0377	.037	.0366	.037
10	1.4255	1.7404	1.9006	.0377	.0366	.037	.0373
11	1.9616	1.8399	1.9109	.0373	.037		.0373
12	2.0388	1.8945	1.9559	.0373	.0366	.037	.0362
13	2.2131	1.8778	1.906	.0377	.037	.0373	.0362
14	2.0885	1.9281	1.8976	.0377	.0366	.037	.0366
15	2.2298	1.9113	1.8435	.0377		.037	.037
16	2.0885	1.8023	1.8343	.0373	.0373	.037	.037
17	1.9826	1.8067	1.656	.0373	.0373	.0366	.0366
18	.0373	.0377	.0366	.0377	.037	.037	.037
19	.037	.0566	.037	.0377	.0366	.0373	.0373
20	.037	.0566	.037	.037	.037	.037	.0366
21	.037	.0566	.0366	.0373	.037	.0366	.037
22	.037	.0566	.037	.037	.037	.037	.0366
23	.037	.0377	.0377	1.0159	.8453	.7935	.823
24	1.1797	.037	.0373	.0366	.9175	.852	.7522
Max	2.2298	1.9281	1.9559	1.0159	.9503	.852	.823
Min	.037	.0362	.0366	.0366	.0324	.0351	.0362
Avg	1.0305	.6446	.6458	.0781	.3413	.3098	.2697

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 205 / 11KV BAGNI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2218	.2033	.2561	.1886	.2195	.2195
2	.2263	.2195	.2033	.2561	.1886	.2195	.2195
3	.2263	.2218	.1829	.2587	.1886	.2218	.1991
4	.2263	.2195	.1829	.2587	.1886	.2218	.2172
5	.2641	.2587	.2195	.2561	.2263	.2926	.1991
6	.3174	.2957	.2743	.2587	.2641	.2926	.3142
7	.3174	.3326	.3511	.3326	.3018	.3511	.3658
8	.3109	.2772	.2926	.3109	.2829	.3142	.3326
9	.3142	.2772	.2772	.2957	.2587	.3174	.3109
10	.2772	.2378	.2561	.2865	.2012	.2772	.2772
11	.2957	.2772	.2587	.2896	.2033	.2743	
12	.2772	.2715	.2402	.2481	.2033	.2587	.2303
13	.2195	.2743	.2561	.2507	.2012	.2427	.2686
14	.2402	.2561	.2587	.2507	.1663	.2587	.2534
15	.2587	.2353	.2587	.2507	.1463	.2561	.2561
16	.2402	.2353	.2587	.2629	.1848	.2957	.2218
17	.2587	.3696	.2926	.298	.2587	.3142	.2987
18	.4066	.3696	.3326	.3982	.3696	.3734	.4066
19	.462	.4207	.4024	.462	.462	.4854	.4435
20	.4066	.4525	.4251	.415	.4251	.4805	.4755
21	.3881	.3841	.4024	.3772	.4066	.462	.4207
22	.3326	.3326	.3326	.2829	.3142	.3841	.3439
23	.2402	.2587	.2587	.2263	.2561	.2896	.2561
24	.2218	.2218	.2195	.2957	.1886	.2218	.2402
Max	.462	.4525	.4251	.462	.462	.4854	.4755
Min	.2195	.2195	.1829	.2263	.1463	.2195	.1991
Avg	.2898	.2884	.2767	.2949	.2531	.3052	.2944

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 201 / 11 Kv Ashta Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	1.2193	1.1888	.8436	.0754	.0943	.1307
2	.2054	1.1888	1.1584	.7655	.0754	.0943	.1307
3	.2054	1.1138	1.0802	.6718	.0943	.0754	.112
4	.2054	1.0837	1.1111	.8905	.0943	.0754	.1307
5	.2054	1.1138	1.2029	.9998	.1132	.1132	.1307
6	.1494	1.358	1.3123	1.1092	.132	.132	.1494
7	.2241	.2149	.2012	.2241	.1698	.1494	.1494
8	.2241	.2172	.1848	.2054	.132	.168	.168
9	.2427	.1646	.1595	.1867	.1132	.1478	.168
10	.2054	.1646	.1772	1.3599	.9659	1.1584	1.406
11	.1267	.1478	.1402	1.6156			1.326
12	.1448	.1109	.156	1.8138	1.2041		1.4937
13	.1433	.128	.1372	1.8595			1.5851
14	.128	.128		1.448	1.2193		1.5394
15	.1294	.1075		1.4784	1.2342		1.5242
16	.1463	.1463		1.6461	1.2643		1.3717
17	.128	.1478		1.6004	1.2498		1.2193
18	.1478	.1663		.1478	.1848		.1433
19	.1663	.1494		.168	.1494		.1646
20	.1494	.1509		.1509	.1509		.1494
21	.1494	.1509		.112	.132		.1509
22	.1307	.132		.0943	.1132		.132
23	1.2041	1.0974		.0754	.1132		.0943
24	.2241	1.2346	1.1584	.9374	.0754	.0943	.2054
Max	1.2041	1.358	1.3123	1.8595	1.2643	1.1584	1.5851
Min	.1267	.1075	.1372	.0754	.0754	.0754	.0943
Avg	.2163	.4932	.6692	.8502	.4116	.2093	.5740

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 202 / 11KV PATOLE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8482	.08	.0972	.096	.9069	.9555	.7842
2	.7842	.08	.0972	.112	.9231	.9393	.6802
3	.6241	.08	.081	.112	.9393	.8907	.664
4	.5761	.064	.0972	.096	.9717	.8421	.8583
5	.6081	.096	.0972	.144	1.0526	.9878	1.085
6	.5601	.16	.1296	.176	1.2323	1.1498	1.3279
7	.176	.176	.1457	.192	.2105	.1619	.1457
8	.16	.16	.1619	.192	.1781	.1134	.1619
9	.6241	.144	.0972	.208	.1296	.1296	.1619
10	.7362	1.6484	1.7004	.096	.1134	.0972	.1457
11	2.1506	1.7814	2.3158	.08	.0972		.096
12	1.5971	2.4777	2.2672	.081	.081		.08
13	2.1285	2.2996	2.2186	.0972	.0972		
14	2.3045	2.3245		.0972	.081		
15	2.3845	2.1822		.081	.081		.0617
16	2.3365	2.0873		.081	.081		.064
17	1.0722	2.0557		.1134	.081		
18	.128	.1265		.1134	.0972		.064
19	.128	.1265		.1296	.1134		.16
20	.112	.1107		.1296	.1134		.144
21	.096	.1107		.1134	.0972		.128
22	.096	.1107		.0972	.081		.112
23	.096	.096		.8421	.8259		.7682
24	.9602	.08	.096	.096	.8907	.8907	.6562
Max	2.3845	2.4777	2.3158	.8421	1.2323	1.1498	1.3279
Min	.096	.064	.081	.08	.081	.0972	.0617
Avg	.8870	.7774	.6859	.1490	.3948	.6507	.3976

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 203 / 11 KV Ashta Gaothan 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4607	.5493	.567	.6379	.5847	.5493	.7265
2	.4252	.4961	.4961	.6556	.5847	.5316	.691
3	.4075	.4607	.4607	.6379	.5847	.4961	.6379
4	.443	.4784	.4607	.6024	.567	.4784	.691
5	.5138	.4961	.4961	.691	.567	.5316	.7265
6	.6379	.7265	.5847	.7442	.6556	.6024	.7619
7	.691	.8328	.7087	.7973	.8505	.7265	.7973
8	.7796	.9134	.8328	.8682	.8328	.8859	.8682
9	.815	.8596	.8682	.8505	.7442	.7796	.815
10	.9036	.7343	.8859	.8859	.691	.9036	.8505
11	.9036	.8596	.8682	.9036	.7265		.7973
12	.9214	.8505	.8328	.8505	.6733		.7619
13	.7087	.8859	.7619	.7796	.5316		.6733
14	.7442	.8859		.7973	.5316		.6024
15	.7796	.7973		.815	.5138		.6379
16	.7442	.8505		.815	.5138		.7087
17	.7619	.9922		.815	.4784		.7796
18	.8682	1.1694		.8859	.8505		.8505
19	1.0277	1.134		1.0808	.9922		1.0099
20	.9214	1.0099		.9465	.8859		.9214
21	.8505	.9036		.8859	.7619		.8859
22	.7796	.8682		.7537	.691		.7087
23	.7087	.7796		.5609	.5847		.5316
24	.4075	.5847	.6201	.691	.567	.5493	.7619
Max	1.0277	1.1694	.8859	1.0808	.9922	.9036	1.0099
Min	.4075	.4607	.4607	.5609	.4784	.4784	.5316
Avg	.7169	.7966	.6746	.7897	.6652	.6395	.7582

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 204 / 11KV BAWACHI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1629	.1867	.2241	.1928	.1848	.2075	.2279
2	.1448	.1867	.2075	.1578	.2054	.1886	.2279
3	.1629	.1698	.1886	.0526	.2054	.1867	.2103
4	.1991	.1886	.2075	.1928	.2033	.1698	.1928
5	.2353	.2075	.2263	.2454	.2402	.2241	.1928
6	.2353	.3395	.3734	.2804	.3142	.3174	.2454
7	.2896	.3142	.3361	.3506	.4066	.2772	.2454
8	.3258	.3258	.2957	.333	.3326	.2561	.2804
9	.2353	.2507	.2279	.2103	.2402	.2195	.2454
10	.2534	.394	.1928	.1753	.1715	.1753	.2103
11	.1991	.2804	.156	.1595	.1227		.1677
12	.2172	.1677	.1734	.1543	.12		.1543
13	.1612	.1174	.1578	.1372	.12		
14	.1433	.1326		.1326	.104		
15	.1612	.116		.1307	.1227		.1543
16	.1595	.181		.1294	.1227		.1715
17		.2172		.1663	.1372		.1886
18	.2149	.2896		.1848	.2149		.2279
19	.3258	.2743		.3326	.2957		.3155
20	.2743	.2772		.3174	.2772		.2686
21	.2378	.2614		.2801	.2241		.2353
22	.2218	.2614		.2427	.2054		.2218
23	.2218	.2427		.2054	.1867		.1848
24	.1267	.2054	.2427	.1928	.1848	.1886	.2279
Max	.3258	.394	.3734	.3506	.4066	.3174	.3155
Min	.1267	.116	.156	.0526	.104	.1698	.1543
Avg	.2134	.2328	.2293	.2065	.2059	.2192	.2180

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 205 / 11 KV Bawachi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	1.1873	.945	.8381	.1294	.1509	.2054
2	.1867	1.1092	.8951	.7748	.1294	.1509	.2054
3	.168	1.0467	.8025	.6009	.1294	.132	.1867
4	.168	.9297	.7716	.5693	.1307	.1307	.168
5	.1867	1.0212	.9105	.8381	.1494	.168	.168
6	.2054	1.1111	.9998	1.0753	.1867	.2075	.1867
7	.2054	.181	.1829	.1581	.2033	.1867	.1867
8	.2241	.1463	.1478	.2241	.1663	.1829	.1867
9	.2054	.1646	.1387	.2054	.1478	.1646	.1867
10	.1867	.1629	.1387	1.1401	.9957	1.1111	1.1361
11	.1663	.1463	.1402	1.4352	1.0837		1.3565
12	.1294	.1463		1.4969	1.3108		1.3717
13	.1463	.1612	.1372	1.4937	1.2955		1.3413
14	.1267	.1629		1.4784	1.2342		1.3717
15	.1075	.1387		1.4632	1.2803		1.3413
16	.1075	.1612		1.4327	1.1589		1.3108
17	.1227	.1629		1.3565	1.0974		1.2651
18	.1448	.1646		.1494	.1991		.1254
19	.1848	.1829		.1663	.1829		.1791
20	.1663	.1829		.1829	.1829		.1629
21	.168	.1663		.1663	.1663		.1433
22	.1867	.1867		.1463	.1494		.1448
23	1.1431	.884		.128	.1494		.1086
24	.1867	1.1888	.9145	.933	.1463	.132	.2054
Max	1.1431	1.1888	.9998	1.4969	1.3108	1.1111	1.3717
Min	.1075	.1387	.1372	.128	.1294	.1307	.1086
Avg	.2087	.4623	.5480	.7689	.5002	.2470	.5518

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 206 / 11KV Ashta Pump House

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5304	.695	.6697	.7499	.5487	.567	.7133
2	.4938	.6219	.6516	.7133	.5487	.5487	.6584
3	.5304	.5487	.6036	.6584	.567	.5304	.7133
4	.567	.4938	.6036	.6219	.567	.5121	.7499
5	.6036	.4755	.4938	.7133	.5853	.5853	.695
6	.6584	.695	.6584	.7865	.6401	.6584	.7316
7	.7133	.7133	.7133	.8596	.823	.7133	.7682
8	.7865	.7316	.7682	.8779	.8048	.7682	.7865
9	.7316	.695	.695	.7682	.7316	.6584	.7133
10	.6767	.695	.6584	.6036	.5487	.7316	.6584
11	.5853	.6516	.6219	.6401	.6219		.6036
12	.695	.6335	.6036	.6154	.128		
13	.6401	.5792	.567	.6154	.128		.5853
14	.5853	.5611		.5792	.1097		.567
15	.5487	.5611		.543	.128		.5121
16	.5853	.7602		.567	.128		.6036
17	.5304	.8688		.5853	.5121		.695
18	.7421	.9412		.6401	.8048		.7865
19	.9412	.9593		1.0608	.9328		.9694
20	.905	.9774		.9328	.8962		.9145
21	.8145	.9412		.823	.823		.9145
22	.8596	.8507		.7682	.7682		.7682
23	.7865	.7964		.6401	.6584		.6036
24	.4938	.7316	.7059	.7865	.5853	.567	.7499
Max	.9412	.9774	.7682	1.0608	.9328	.7682	.9694
Min	.4938	.4755	.4938	.543	.1097	.5121	.5121
Avg	.6669	.7158	.6439	.7146	.5662	.6219	.7157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244124 / 33/11KV KOREGAON SUBSTATION

Feeder No / Name : 201 / 11KV KOREGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.2452	.2427	.2241	.2263	.1698	.2452
2	.1867	.2452	.2427	.2075	.2263	.1698	.2427
3	.1848	.2402	.2641	.2075	.2641	.1698	.2614
4	.1886	.2772	.2987	.2241	.3018	.1698	.2587
5	.3395	.3361	.3772	.2957	.3584	.2075	.2987
6	.3395	.4108	.4715	.3772	.4904	.4904	.4108
7	.5788	.5788	.5415	.6348	.5658	.6036	.5975
8	.4938	.439	.5175	.5175	.4108	.499	.5359
9	.4075	.394	.4252	.3982	.362	.4572	.4755
10	.333	.3641	.3721	.3294	.2804	.3641	.3898
11	.333		.3506	.3641	.2658	.3222	.2947
12	.3121		.2947	.3121	.2126	.3052	.2947
13	.2947	.3155	.3121	.2774	.2149	.2915	.2947
14	.298	.298	.298	.2774	.181	.2804	.2774
15	.298	.2947	.2947	.2915	.1646	.2865	.2835
16	.3155	.3121	.298	.3052	.1646	.3121	.2572
17	.3681	.3544	.3641	.3601	.2012	.3544	.3391
18	.4887	.4656	.394	.5258	.3841	.4477	.4557
19	.6036	.543	.5175	.5792	.5914	.5487	.6036
20	.6036	.5914	.5914	.5041		.6099	.5729
21	.3326	.4481	.4854	.4527	.5228	.5041	.499
22	.3395	.3547	.3772	.3772	.3772	.4294	.3921
23	.2452	.2452	.2641	.2263	.2263	.2829	.2427
24	.2075	.2452	.2427	.2263	.2263	.1886	.2452
Max	.6036	.5914	.5914	.6348	.5914	.6099	.6036
Min	.1848	.2402	.2427	.2075	.1646	.1698	.2427
Avg	.3450	.3636	.3682	.3540	.3139	.3527	.3654

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244124 / 33/11KV KOREGAON SUBSTATION

Feeder No / Name : 202 / 11KV Bhadurwadi AG
(Koregaon) Feeder KV- 11 /
OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0895	.0848	.0829		.9779	.8488
2	.9393	.0895	.0857	.081		.9779	.8905
3	.8962	.0876	.0867	.0819		.9831	.9172
4	.9061	.1063	.0876	.0819		.9831	.9488
5	.9717	.1214	.0895	.1006		1.0202	1.012
6	1.0159	.1417	.0924	.1227		1.0688	1.0311
7	.1753	.1433	.1294	.1629	.1267	.1612	.1294
8	.1753	.124	.1478	.1595	.1629	.12	.1254
9	.1402	.12	.1772	.1387	.1543	.1267	.1417
10	1.5524		1.7924			.1227	.1227
11	2.0645		2.0805	.1214		.1214	.1063
12	2.0805		2.17	.12		.1006	.1174
13	2.1285	2.2348	2.0241	.096		.0819	.1107
14	2.0805	2.2085	1.8903	.096		.0995	.1147
15	1.9685	2.2348	1.8435	.1134	.0857	.116	.1017
16	1.8976	2.1822	1.7284	.116	.0995	.0995	.0972
17	1.7966	2.1052	1.6512	.1187	.1029	.12	.1147
18	1.9591	.1326	.1341	.1029	.1433		.124
19	.1402	.1372	.1174	.1052	.1417	.1402	.1433
20	.1267	.1254	.1174	.1075	.124	.1402	.1254
21	.1075	.1029	.1187	.1029	.124	.104	.1254
22	.1052	.1006	.1187	.0857	.1029	.0857	.0995
23	.0886	.0848	.0838		.9105	.8333	.7926
24	.9105	.0895	.0848	.08		.9779	.8179
Max	2.1285	2.2348	2.17	.1629	.9105	1.0688	1.0311
Min	.0886	.0848	.0838	.08	.0857	.0819	.0972
Avg	1.0533	.6077	.7057	.1081	.1899	.4157	.3816

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244124 / 33/11KV KOREGAON SUBSTATION

Feeder No / Name : 203 / 11KV Koregaon AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0248	.7407	.5569	.7727	.0343	.0492	.0503
2	.0255	.7407	.5569		.0263	.0486	.0503
3	.0274	.7316	.5639	.7621	.0229	.0497	.0509
4	.0267	.7621	.5792	.7716	.0263	.0497	.0509
5	.0429	.8179	.5864	.787	.0267	.0514	.0514
6	.0423	.8592	.6093	.7926	.0271	.0514	.0701
7	.0602	.0469	.0867	.0648	.0335	.0497	.0724
8	.0556	.0248	.0347	.0309	.0423	.048	.0526
9	.0343	.0332	.0412	.0349	.0377	.0526	.0514
10	.0423	.0332	.0354	1.2651	1.3748	1.2498	1.1544
11	.0303	.0332	.0271	1.4632	1.4998	1.4198	1.3279
12	.0303		.0282	1.5432	1.4998	1.4352	1.2037
13	.0263	.0343	.0217	1.7497	1.4529	1.4022	1.3272
14	.0274	.0332	.024	1.7654	1.4373	1.3717	1.25
15	.0286	.0314	.0234	1.7654	1.3757	1.2809	1.2186
16	.0274	.028	.032	1.781	1.3123	1.2963	1.174
17	.0335	.0343	.0328	1.7661	1.2334	1.2803	1.1431
18	.0343	.036	.0309	.052	.0263	.0678	.0492
19	.0366	.04	.0518	.0457	.0263	.0678	.0648
20	.0372	.0412	.048	.04	.0274	.0678	.048
21	.0349	.0389	.0427	.04	.0452	.0503	.048
22	.0326	.0343	.0419	.0406	.0503	.0497	.0633
23	.7621	.5569		.0337	.0492	.0503	.0486
24	.0232	.7621	.5569	.7827	.0343		.0503
Max	.7621	.8592	.6093	1.781	1.4998	1.4352	1.3279
Min	.0232	.0248	.0217	.0309	.0229	.048	.048
Avg	.0644	.2824	.2005	.7891	.4884	.5017	.4446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 201 / 11KV MARDWADI 1PH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
17	.2303
Max	.2303
Min	.2303
Avg	.2303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 202 / 11KV KARANDWADI 1PH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	.7381
Max	.7381
Min	.7381
Avg	.7381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 204 / 11 KV FALKEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	.5761
Max	.5761
Min	.5761
Avg	.5761

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 401 / 33 KV MARDWADI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-DEC-17
HR	Load (MW)
24	.6379
Max	.6379
Min	.6379
Avg	.6379

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 403 / 33 KV Ashta

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-DEC-17
HR	Load (MW)
24	1.9204
Max	1.9204
Min	1.9204
Avg	1.9204

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 404 / 33KV Kasbe Digraj
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-DEC-17
HR	Load (MW)
24	2.073
Max	2.073
Min	2.073
Avg	2.073

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 405 / 33 KV Nagaon

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-DEC-17
HR	Load (MW)
24	1.1694
Max	1.1694
Min	1.1694
Avg	1.1694

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 406 / 33 KV Koregaon

PURELY LIS FEEDERS

Feeder KV- 33 / INCOMING

DATE	01-DEC-17
HR	Load (MW)
24	.7442
Max	.7442
Min	.7442
Avg	.7442

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 407 / 33 KV Kasturi

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-DEC-17
HR	Load (MW)
24	4.1015
Max	4.1015
Min	4.1015
Avg	4.1015

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 201 / 11 KV ISLAMPUR-I FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0242	.961	.9979	1.0242	.9979	.9979	.961
2	.9979	.961	.9709	1.0242	.961	.9979	.9709
3	.961	.961	.9709	1.0349	.961	.9979	.9709
4	.9709	.961	1.0082	1.0719	.9709	.9979	.9335
5	.9511	.961	1.0349	1.0719	1.0082	1.0349	1.0082
6	1.1706	1.2696	1.2071	1.307	1.2197	1.1576	1.1827
7	1.39	1.6057	1.4266	1.7177	1.6095	1.7372	1.5729
8	1.6827	1.7177	1.6263	1.7002	1.6289	1.885	
9	1.4937	1.5524	1.4784	1.5524	1.4784	1.5524	1.6263
10	1.9044	1.8099	1.8461	1.8099	1.3306	1.9342	1.7737
11	1.5524	1.5203	1.3756	1.5729		1.5565	1.4632
12	1.4784	1.4685	1.267	1.4327		1.448	1.4266
13	1.39	1.3394	1.3032	1.3394	1.1706	1.3535	1.3032
14	1.3169	1.3169	1.2437	1.3032	1.1706	1.3169	1.3535
15	1.2803	1.2437	1.1706	1.3032	1.134	1.2308	1.2803
16	1.3169	1.2894	1.2437	1.3394	1.1458	1.2437	1.2071
17	1.3394	1.4266	1.3535	1.4998	1.1458	1.4266	1.2803
18	1.6827	1.7193	1.7193	1.829	1.6632	1.8099	1.7741
19	2.2916	2.1068	2.0485	1.9387	1.9418	2.2314	2.1068
20	1.848	1.9044	1.829	1.9022	1.8671	1.8656	1.829
21	1.7372	1.7002	1.7002	1.7193	1.7002	1.6651	1.6827
22	1.5154	1.4632	1.5893	1.5364	1.4784	1.4266	1.3169
23	1.2567	1.2071	1.2071	1.3169	1.2936	1.1706	1.1458
24	1.0242	1.0719	1.0349	1.0608	1.0608	1.0719	.9979
Max	2.2916	2.1068	2.0485	1.9387	1.9418	2.2314	2.1068
Min	.9511	.961	.9709	1.0242	.961	.9979	.9335
Avg	1.3990	1.3974	1.3605	1.4337	1.3154	1.4213	1.3551

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 202 / 11 KV Peth Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.3734	.3696	.4481	.4108	.3734	.4435
2	.5228	.3734	.3734	.4066	.4066	.3734	.4435
3	.5175	.3734	.3734	.4066	.4108	.3734	.4066
4	.5175	.3734	.3696	.4435	.4066	.3734	.4024
5	.5601	.3734	.4108	.4854	.4481	.4108	.4435
6	.8215	.5601	.5121	.6348	.5121	.5601	.6219
7	1.1576	.6348	.7023	.7023	.6283	.8871	.8131
8	1.1706	.6722	.7023	.7023	.6653	.8413	.8131
9	1.0349	.6283	.6283	.6535	.5601	.6653	.7164
10	.9877	.543	.5487	.6805	.4755	.6626	.7023
11		.5316	.5847	.5853	.3881	.543	.6135
12		.5316	.5792	.6135		.5847	.5194
13		.4477	.4706	.5068		.5258	.5138
14	.5258	.5068	.4755	.5014		.5731	.5316
15	.631	.5068	.5304	.5609		.4961	.567
16	.5731		.5373	.7087		.5914	.5731
17	.6805	.6584	.5373	.695	.6154	.5853	.6089
18	.8048	.7023	.6219	.8131	.7682	.7316	.7602
19	.9709	.8501	.8871	.7762	.961	.9979	.8779
20	.9335	.8871	.7762	.8131	.8871	.961	.8413
21	.8589	.7682	.7762	.695	.8501	.8501	.7762
22	.6722	.5914	.7282	.5914	.7023	.7392	.5544
23	.5228	.439	.5228	.4435	.5175	.5175	.439
24	.5601	.4108	.3696	.4481	.4435	.4066	.439
Max	1.1706	.8871	.8871	.8131	.961	.9979	.8779
Min	.5175	.3734	.3696	.4066	.3881	.3734	.4024
Avg	.7421	.5538	.5578	.5965	.5820	.6093	.6009

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 203 / 11 KV LIS FEEDER

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2696	.1486	1.0745	1.1317	1.1203	1.0745
2	1.2449	.1486	1.1104	1.1694	1.1949	1.0631
3	1.2449	.1486	1.134	1.2449	1.1949	1.0985
4	1.2323	.1486	1.1462	1.2323	1.1949	1.0985
5	1.2826	.0457	1.1462	1.2826	1.2696	1.1462
6	1.2826	.0457	1.182	1.2323	1.307	1.2403
7	1.3203	.0457	1.1946	1.2567	1.3443	1.2403
8	1.358	.0457	1.2178	1.2567	1.3817	
9	1.2696	.0377	1.3169	1.2437	1.3306	1.3676
10	1.3443	1.1763	1.3169	1.2803	1.3676	1.386
11	1.3443	1.2936	1.3169	1.2752	1.3676	1.3306
12	1.307	1.2803	1.3676	1.2752	1.3676	1.3676
13	1.307	1.2986	1.3491	1.2936	1.3121	1.3306
14	1.307	1.2803	1.1128	.2402	1.3676	1.2936
15	.0842	1.3169	1.2803	.0724	1.3676	1.3676
16	.0793		.1524	.0886	.1036	.0953
Max	1.358	1.3169	1.3676	1.2936	1.3817	1.386
Min	.0793	.0377	.1524	.0724	.1036	.0953
Avg	1.1424	.5641	1.1512	1.0360	1.2245	1.1667

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 204 / 11 KV ISLAMPUR-II FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1109	.112	.112	.0914	.0747	.0747
2	.1109	.1109	.1109	.112	.0924	.0747	.0739
3	.1109	.1109	.112	.1109	.0924	.0747	.0747
4	.112	.1109	.112	.1109	.0924	.0747	.0747
5	.112	.1109	.112	.1109	.0924	.112	.0739
6	.1867	.1829	.1478	.1494	.128	.1494	.1097
7	.1867	.2033	.1848	.2614	.1829	.168	.1478
8	.2218	.2427	.2218	.2561	.1448	.1867	.1829
9	.181	.1629	.1463	.1829	.1463	.1294	.1646
10	.1448	.1417	.1463	.1086	.1075	.0905	.1417
11	.1629	.1029	.132	.0886	.1086	.1075	.104
12	.1578	.1052	.1478	.1017	.0716	.0709	.1052
13	.1214	.1006	.1052	.0701	.0732	.0924	.0886
14	.1227	.1006	.1052	.0724	.0716	.0739	.0716
15	.1227		.1075	.0716	.0716	.0532	.0709
16	.1402		.1075	.0701	.0724	.0716	.1063
17	.1372	.1829	.1463	.0876	.1086	.0724	.1433
18	.1753	.1829	.1463	.1402	.1086	.1086	.1433
19	.2241	.2195	.2218	.1402	.1494	.1463	.2149
20	.2241	.2218	.2218	.1463	.1494	.1463	.2195
21	.2033	.1848	.2241	.1478		.1463	.2195
22	.1867	.1829	.1867	.1463	.1307	.1109	.1463
23	.1294	.1478	.1494	.1086	.112	.0739	.1109
24	.2858	.1109	.1109	.112	.1097	.0747	.0747
Max	.2858	.2427	.2241	.2614	.1829	.1867	.2195
Min	.1109	.1006	.1052	.0701	.0716	.0532	.0709
Avg	.1614	.1514	.1466	.1258	.1090	.1035	.1224

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 205 / 11 KV ISLAMPUR AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1806	.2134	.208	.0187	.0183	.0189	.0185
2	.1783	.1829	.2103	.0185	.0183	.0189	.0187
3	.1783	.1829	.2103	.0185	.0185	.0189	.0185
4	.1783	.1852	.1753	.0187	.0183	.0189	.0185
5	.1806	.1875	.1734	.0189	.0183	.0189	.0187
6	.1806	.2031	.208	.0373	.0366	.0189	.0366
7	.0377	.0377	.0358	.0373	.037	.0377	.0366
8	.0377	.0377	.0358	.0373	.0537	.0377	.0366
9	.0377	.0377	.0191	.0187	.0151	.0377	.0377
10	.0377	.0185	.0189	.2881	.0151	.3086	.25
11	.0377	.0191	.0189	.3841		.3749	
12	.0189		.0189	.4161	.1981	.4111	.3401
13	.0377		.0189	.3841	.2134	.4062	.2778
14	.0373	.0191		.427	.2372	.4062	.3086
15	.0373	.0191	.0191	.3125	.2846	.3749	.3521
16	.0373	.0191	.0381	.3841	.3086	.3795	
17	.0554	.0381	.0377	.4115	.2932	.4115	.3201
18	.056	.0373	.0377	.0351	.0189	.0347	.0351
19	.0377	.0373	.0377	.0351	.0189	.0358	
20	.0377	.0373	.0373	.0351	.0189	.0347	.0373
21	.0373	.0185	.0189	.0347	.0189	.0347	.0189
22	.0189	.0183	.0189	.0354	.0189	.0177	.0189
23	.1806	.2103	.0187	.0358	.0189	.0179	.1486
24	.1806	.2134	.2058	.0187	.0183	.0189	.0183
Max	.1806	.2134	.2103	.427	.3086	.4115	.3521
Min	.0189	.0183	.0187	.0185	.0151	.0177	.0183
Avg	.0849	.0897	.0792	.1442	.0833	.1456	.1127

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 401 / 33KV Ganesh Nagar

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8804	1.8861	2.0851	1.5524	1.6575	1.4266	1.3717
2	1.7375	1.8861	1.8656	1.4563	1.6575	1.4415	1.3717
3	1.6832	1.7718	1.8656	1.4563	1.5432	1.4415	1.2752
4	1.7558	1.829	1.8461	1.5123	1.7718	1.4563	1.3717
5	2.0302	1.9433	2.0633	1.6632	1.9433	1.5684	1.5912
6	2.4143	2.6863	2.4977	2.0725	2.2291	2.1285	2.1622
7	2.3525	2.6863	2.1285	2.524	2.6292	2.4646	2.4949
8	2.384	2.4577	2.4086	2.6063	2.6863	2.5206	2.6057
9	2.3285	1.9004	2.2862	2.1176	2.1399	2.2177	2.1719
10	2.3285	2.2805	2.3434	2.8235	2.6337	3.2156	3.2007
11	1.9753	2.009	1.8861	2.6292	2.4691	2.7166	2.8006
12	1.9753	1.8461	1.7718	2.3137	2.2497	2.8275	2.8006
13	1.701	1.7375	1.7147	2.9424	2.3594	2.7721	2.8006
14	1.6461	1.6832	1.6575	2.7869	2.1399	2.6063	2.8006
15	1.6461	1.6832	1.7147	2.8475	2.1948	2.4434	2.524
16	1.8656	1.8461	1.7718	2.7641	2.3594	2.7149	2.6292
17	2.1148	1.8461	1.9004	3.0293	2.3148	2.7435	2.3926
18	2.4577	2.4434	2.4143	1.829	2.2565	2.3891	2.2565
19	3.0864	2.8235	2.9384	1.8861	2.9081	3.0407	2.963
20	2.8578	2.5789	2.5206	3.0293	2.7435	2.7435	2.6886
21	2.5149	2.4143	2.5503	2.7435	2.4143	2.4143	2.4143
22	2.2291	1.9753	2.2731	2.3434	2.0851	2.1948	2.1399
23	2.1148	2.1948	1.9959	2.1148	1.7558	1.701	1.9547
24	1.9342	2.0005	2.0851	1.6632	1.7147	1.4815	1.4266
Max	3.0864	2.8235	2.9384	3.0293	2.9081	3.2156	3.2007
Min	1.6461	1.6832	1.6575	1.4563	1.5432	1.4266	1.2752
Avg	2.1256	2.1004	2.1077	2.2795	2.2024	2.2779	2.2587

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 201 / 11 KV MIDC FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2449	1.1317	1.2449	1.358	1.0562	.5658	1.2071
2	1.2449	1.1317	1.2071	1.358	1.094	.5658	1.2071
3	1.2449	1.1317	1.2071	1.358	1.094	.5658	1.2071
4	1.2449	1.1317	1.2071	1.358	1.094	.5658	1.2071
5	1.2826	.9997	1.2071	1.358	1.094	.8488	1.2071
6	1.2449	1.0185	1.2826	1.1317	.9997	.8299	1.2449
7	1.1694	1.0751	1.3203	1.1506		1.0185	1.3392
8	1.1317	.9431	1.2071	1.1694		.8676	1.3203
9	1.358	1.358	1.4335	1.1883		1.1694	1.3014
10	1.5655	1.5466	1.7353	1.4901		1.5466	1.6032
11	1.5844	1.6221	1.773	1.5844		1.8107	2.0182
12	1.6598	1.5089	1.7918	1.7353		1.9239	1.6975
13	1.358	1.226	1.8484	1.5278		1.8484	1.358
14	1.6598	1.6221	1.8673	1.4901		1.6221	1.7353
15	1.7164	1.6221	1.8107	1.773			2.0182
16	1.6975	1.5089	1.7353	1.5844		1.9239	1.7541
17	1.4712	1.4523	1.5844	1.5655		1.8107	1.6975
18	1.4712	1.2449	1.5089	1.4146		1.3957	1.4712
19	1.3014	1.0185	1.5089	1.2826		1.358	1.5278
20	1.1317	.9619	1.226	1.2449		1.094	1.1694
21	1.2637	1.2449	1.358	1.226		1.1694	1.2449
22	1.2449	1.358	1.3957	1.0374		1.1317	1.3014
23	1.226	1.358	1.2071	1.2071		1.1317	1.1883
24	1.3957	1.2637	1.3203	1.3957	1.1694	.5281	1.2071
Max	1.7164	1.6221	1.8673	1.773	1.1694	1.9239	2.0182
Min	1.1317	.9431	1.2071	1.0374	.9997	.5281	1.1694
Avg	1.3714	1.2700	1.4578	1.3745	1.0859	1.1866	1.4264

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 202 / 11 KV SAKHRALE GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0943	.0914	.0943	.0943	.0914	.1097
2	.0914	.0943	.0914	.0943	.0943	.1097	
3	.0914	.0943	.0914	.0943	.0943	.1097	.1097
4	.0914	.0943	.0914	.0943	.0943	.1097	.1097
5	.1097	.1132	.1463	.0943	.1132	.1097	.1097
6	.2012	.1886	.2012	.1886	.1886	.2012	.2427
7	.2378	.2452	.2195	.2641		.2378	.2957
8	.1829	.1867	.2012	.1867		.2012	.2241
9	.1829	.168	.1646	.1478		.1646	.1629
10	.1478	.1463	.1463	.1478		.1433	.1448
11	.1478	.128	.1254	.1463		.1433	.1254
12	.1478	.0914	.1227	.1254		.124	.1254
13	.1294	.1463	.1086	.1433		.1063	.1254
14	.128	.1097	.0914	.0876		.1063	.1075
15	.0895	.1097	.1052	.0701		.0876	.1254
16	.1075	.1097	.1029	.1075		.0876	.1448
17	.1646	.1463	.0867	.128		.104	.1463
18	.2033	.1829	.1463	.1848		.1715	.1646
19	.2033	.2195	.2033	.2241		.2534	.2587
20	.2033	.2012	.2054	.2427		.2353	.2218
21	.1867	.1829	.1867	.1867		.2353	.2241
22	.168	.1463	.1494	.168		.1829	.2054
23	.1097	.1097	.1132	.1307		.1463	.1132
24	.0914	.0943	.0914	.0943	.1132	.1097	.1097
Max	.2378	.2452	.2195	.2641	.1886	.2534	.2957
Min	.0895	.0914	.0867	.0701	.0943	.0876	.1075
Avg	.1462	.1418	.1368	.1436	.1132	.1488	.1612

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 203 / 11 KV BAHE AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0189	.0171	.6097	.5201	.4572	.503
2	.0171	.0189	.0171	.6097	.5201	.4572	.503
3	.0171	.0189	.0171	.6097	.5117	.4572	.503
4	.0171	.0189	.0171	.6097	.4967	.4572	.503
5	.0171	.0189	.0171	.6097	.4967	.4572	.503
6	.0171	.0189	.0171	.6562	.5944	.5487	.5487
7	.0171	.0189	.0171	.0189		.0152	.0189
8		.0189	.0171	.0187		.0152	.0189
9	.0171	.0189	.0171	.0189		.0152	.0189
10	1.0648	1.2811	1.1385	.0189		.0189	.0189
11	1.4232	1.4685		.0189		.0189	.0187
12	1.5339	.1562	1.4403	.0189		.0189	.0189
13	1.5655	1.1279	1.4403	.0189		.0189	.0187
14	1.5655	1.448	1.4403	.0189		.0189	.0187
15	1.5655	1.4632	1.3923	.0189		.0189	.0187
16		1.4632	1.3283	.0189		.0189	.0187
17		1.4022	1.1431	.0189		.0189	.0187
18	.0189	.0171	.0189	.0189		.0189	.0189
19	.0189	.0171	.0189	.0189		.0189	.0189
20	.0189	.0171	.0189	.0189	.0171	.0189	.0187
21	.0189	.0171	.0189	.0189	.0171	.0189	.0189
22	.0189	.0171	.0189	.0189	.0171	.0189	.0187
23	.0189	.0171	.5487	.4458	.3658	.4572	.0187
24	.0171	.0189	.0171	.5944	.535	.4572	.503
Max	1.5655	1.4685	1.4403	.6562	.5944	.5487	.5487
Min	.0171	.0171	.0171	.0187	.0171	.0152	.0187
Avg	.4279	.4209	.4408	.2103	.3720	.1684	.1619

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 204 / 11 KV DUDH SANGH FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.4527	.3772	.415	.4715	.4527	.415
2	.4527	.4527	.3772	.415	.4715	.4527	.415
3	.4527	.4527	.3772	.415	.4715	.3772	.415
4	.4527	.4527	.3772	.415	.4715	.4527	.415
5	.4527	.4338	.3772	.415	.4527	.3584	.415
6	.4527	.3395	.3961	.3395	.3395	.3584	.415
7	.2829	.2829	.3395	.3018		.3395	.3772
8	.2829	.2452	.2829	.3395		.3584	.3772
9	.3584	.3395	.3584	.415		.3584	.3961
10	.4715	.415	.4904	.5093		.4904	.4904
11	.5093	.4527	.5281	.5658		.4904	.5847
12	.547	.3961	.5281	.5847		.5281	.5847
13	.4715	.4527	.5281	.5658		.6413	.6224
14	.4715	.3961	.5093	.5093		.6602	.6224
15	.4527	.3961	.415	.5093		.6413	.5281
16		.3772	.415	.679		.5658	.5281
17	.4904	.415	.4904	.679		.5281	.547
18	.415	.4527	.5093	.679		.5093	.5658
19	.3961	.4527	.5093	.6413		.5093	.547
20	.3961	.4527	.5093	.5847	.415	.4527	.4715
21	.3772	.4527	.5281	.4904	.5658	.5093	.5093
22	.3772	.4572	.4904	.4715	.4904	.4904	.5093
23	.3584	.3961	.4527	.4527	.4904	.4527	.4527
24	.4527	.3961	.3772	.415	.4338	.4527	.415
Max	.547	.4572	.5281	.679	.5658	.6602	.6224
Min	.2829	.2452	.2829	.3018	.3395	.3395	.3772
Avg	.4273	.4089	.4393	.4920	.4612	.4763	.4841

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 205 / 11 KV NAGARPALIKA PWW
FEEDER Feeder KV- 11 /
OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3772	.3772	.3395	.3584	.3772	.3584
2	.3395	.3772	.3772	.3395	.3772	.3772	.3584
3	.3395	.3772	.3772	.3395	.3772	.3772	.3584
4	.3395	.0189	.3772	.3395	.3772	.3772	.3584
5	.3018	.3206	.3395	.3395	.3772	.3772	.3584
6	.3772	.3772	.3772	.3395	.3772	.3772	.415
7	.3584	.4527	.4338	.3772		.4338	.4527
8	.3584	.4338	.4527	.415		.4338	.4527
9	.3584	.4338	.4527	.4527		.4338	.4527
10	.3584	.4338	.4715	.4338		.4527	.4904
11	.3206	.4338	.4715	.4715		.4527	.4904
12	.3206	.4527	.4715	.4715		.4527	.4715
13	.3772	.415	.4527	.4338		.415	.4715
14	.3772	.415	.415	.4338		.415	.4527
15	.3772	.415	.415	.4338		.415	.4338
16		.415	.415	.4527		.415	.4338
17	.2454	.415	.415	.4527		.415	.4338
18	.2229	.3584	.415	.3584		.415	.4527
19	.3086	.3018	.3395	.3018		.3395	.2641
20	.3086	.2263	.2987	.2641	.3018	.2427	.1989
21	.2401	.2263	.1886	.2374	.3018	.1143	.1966
22	.2427	.3018	.1875	.2321	.3018	.1829	.192
23	.2804		.3395	.2486	.3395	.3395	.2715
24	.3584	.2926	.3772	.3584	.3395	.3584	.3584
Max	.3772	.4527	.4715	.4715	.3772	.4527	.4904
Min	.2229	.0189	.1875	.2321	.3018	.1143	.192
Avg	.3239	.3596	.3849	.3694	.3481	.3746	.3824

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 206 / 11 KV Kapuskhed Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.0754	.1097	.0943	.0754	.0914	.0754
2	.0732	.0754	.1097	.0943	.0754	.0914	.0754
3	.0732	.0754	.1097	.0943	.0754	.0914	.0754
4	.0914	.0754	.1097	.0943	.0754	.0914	.0754
5	.0914	.0943	.1097	.0943	.0943	.1097	.1509
6	.1646	.1886	.2012	.1886	.1698	.1829	.1886
7	.2012	.2452	.2378	.2641		.2195	.2263
8	.2012	.2241	.2378	.2241		.1886	.1867
9	.1829	.1629	.1829	.1848		.1463	.1478
10	.1294		.1109	.1402		.1063	.0895
11	.1109		.1052	.1052		.1075	.0876
12	.1109	.128	.0867	.0876		.0876	.0867
13	.128	.0732	.1052	.0876		.0876	.0701
14	.1267	.1097	.1387	.0876		.0867	.0701
15	.1646	.0914	.1052	.0876		.0686	.0886
16		.0914	.0905	.0876		.1029	.0886
17	.1097	.1097	.1086	.1448		.1372	.1075
18	.1663	.1463	.128	.1663		.156	.1463
19	.1848	.1829	.2033	.1867		.2012	.1867
20	.1097	.2195	.1848	.1867	.2012	.1829	.1867
21	.1848	.1829	.168	.168	.2012	.1663	.1867
22	.1494	.1463	.1509	.1494	.1829	.1307	.1494
23	.0914	.1097	.1132	.0943	.1097	.1132	.0943
24	.0732	.0754	.1097	.0943	.0943	.0914	.0754
Max	.2012	.2452	.2378	.2641	.2012	.2195	.2263
Min	.0732	.0732	.0867	.0876	.0754	.0686	.0701
Avg	.1301	.1311	.1382	.1336	.1232	.1266	.1215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 207 / 11 KV SAKHRALE Ag FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3749	.3953	.3749	.0171	.0145	.0171	.0171
2	.3749	.3953	.3749	.0171	.0145	.0171	.0171
3	.3749	.3953	.3749	.0171	.0145	.0171	.0171
4	.3749	.3953	.3749	.0171	.0145	.0171	.0171
5	.3749	.4428	.3749	.0171	.0162	.0171	.0171
6	.4374	.4428	.4374	.0171	.0162	.0171	.0171
7	.0171	.0156	.0171	.0185		.0171	.0171
8	.0171	.016	.0171	.0179		.0171	.0171
9	.0171	.0164	.0171	.0177			.0171
10	.0103	.0171	.0162	.3704		.1524	
11	.0114	.0171	.016	.5864			.5556
12	.0126	.0171	.0156	.5093		.8215	.4108
13	.0124	.0171	.0152	.6958		.788	.3475
14	.0126	.0171	.0141	.759		.823	.3944
15	.0128	.0171	.0145	.759		.8413	.5792
16	.0128	.0171	.0147	.759		.8299	.3688
17	.0156	.0171	.0152	.6958		.7545	.6661
18	.0168	.0171	.0164	.0168		.0171	.0187
19	.017	.0171	.0175	.0168		.0171	.0175
20	.0175	.0171	.0166	.0166		.0171	.0175
21	.0175	.0171	.0164	.0168		.0171	.0183
22	.0175	.0171	.0151	.016		.0171	.0183
23	.3953	.3749	.0171	.0145		.0171	.0343
24	.3749	.3953	.3749	.0171	.0143	.0171	.0171
Max	.4374	.4428	.4374	.759	.0162	.8413	.6661
Min	.0103	.0156	.0141	.0145	.0143	.0171	.0171
Avg	.1383	.1461	.1233	.2253	.0150	.2394	.1573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 209 / 11 KV Siddhanath LIS
feeder Feeder KV- 11 /
OUTGOING

PURELY LIS FEEDERS

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.3563	.3437	.3277	.0781	.3277
2	.1829	.3605	.3437	.3277	.0781	.3277
3	.1829	.3605	.3437	.3277	.0781	.3277
4	.216	.3605	.3437	.3277	.0781	.3277
5	.216	.3605	.3437	.3277	.0781	.3277
6	.2187	.3605	.3437	.3605	.0781	.3277
7	.1852	.3605	.3437	.3605	.0625	.3277
8	.1698	.3605	.3437	.3605	.0312	.3277
9	.1543	.3605	.3437	.3605	.3125	.3277
10	.1943	.3593	.3605	.3605	.3277	.2622
11	.1943	.3593	.3605	.3605	.3277	.2591
12	.1943	.3593	.3605	.3605	.3277	.2753
13	.1781	.3593	.3647	.3605	.3277	.2753
14	.1781	.3593	.3647	.3605	.3277	.2753
15	.2105	.3593	.3647	.3605	.3277	.2753
16		.3125	.2785	.2915	.2881	.2591
Max	.2187	.3605	.3647	.3605	.3277	.3277
Min	.1543	.3125	.2785	.2915	.0312	.2591
Avg	.1886	.3568	.3467	.3459	.1956	.3019

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 401 / 33 KV EXPRESS FEEDER
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1719	2.2634	2.2862	1.7147	1.9239	1.086	2.0576
2	2.1719	2.2634	2.2862	1.7147	1.9239	1.1431	2.0576
3	2.1719	2.2634	2.2862	1.7147	1.9239	1.1431	2.0576
4	2.1719	2.2634	2.2862	1.7147	1.9239	1.1431	2.0576
5	1.9433	2.037	2.2862	1.7147	1.8107	1.1431	2.0576
6	2.0576	2.0936	2.2291	1.829	1.4712	1.086	2.0005
7	2.0576	1.9805	2.2862	1.829		1.1431	1.9433
8	1.9433	1.9805	1.9433	1.829		1.1431	2.0576
9	2.0576	2.2068	2.0576	1.9433		1.2574	2.0005
10	1.5844	2.4006	1.9433	1.9239		1.7147	2.1502
11	2.2634	2.4006	2.0005	1.9805		1.829	2.3765
12	2.3765	2.5149	2.0005	1.9805		1.9433	2.0936
13	2.1502	2.2862	1.9433	1.9239		2.0576	2.2068
14	2.2634	2.1719	1.8861	1.8107		2.1719	2.1502
15	2.6595	2.1719	1.8861	1.9239		2.1719	2.32
16	2.3765	2.4006	1.8861	2.037		2.1719	2.32
17	2.4331	2.2291	2.0005	1.8673		2.1719	2.037
18	2.32	2.2068	1.9433	1.8162		2.0576	1.9239
19	2.2068	2.2862	1.7147	1.6975		2.0576	1.9239
20	2.32	2.1719	1.829	1.8673	.6859	2.0576	1.8673
21	2.2634	2.2862	1.829	1.9239	.6859	2.0576	1.9239
22	2.2068	2.2862	1.6575	1.9239	1.0288	2.0576	1.9239
23	2.2068	2.3434	1.7147	1.9239	1.0288	2.0576	2.037
24	2.1719	2.3765	2.3434	1.7147	1.9805	1.086	2.0576
Max	2.6595	2.5149	2.3434	2.037	1.9805	2.1719	2.3765
Min	1.5844	1.9805	1.6575	1.6975	.6859	1.086	1.8673
Avg	2.1896	2.2452	2.0219	1.8466	1.4898	1.6647	2.0667

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244053 / 33/11 KV RETHRE HARNAX STN

Feeder No / Name : 201 / 11 KV RHX & TAKARI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3206	.3395	.3361	.3696	.3361	.3206	.3174
2	.3018	.3206	.3326	.3395	.3395	.3206	.3206
3	.3018	.3206	.3361	.3395	.3395	.3206	.3206
4	.3206	.3584	.3547	.3395	.415	.3584	.3584
5	.3584	.4715	.5175	.415	.5601	.415	.4338
6	.5847	.679	.6535	.6036	.6348	.6413	.6224
7	.7577	.8131	.7762	.7947	.7577	.7842	.8215
8	.7133	.7522	.7655	.6984	.7133	.7316	.7202
9	.6805	.6733	.6838	.5552	.6379	.6805	.6805
10	.5784	.6099	.6201	.5847	.5014	.5548	.591
11	.5609	.5194	.631	.5375	.5316		.5316
12	.5721	.5601	.5316	.5258		.5316	.5144
13	.5548	.5729	.3121	.5197		.5087	.5144
14	.4908	.5228	.3012	.5256		.5144	.4733
15	.4854	.499	.5258	.4334		.5028	.4733
16	.4801	.4668	.5144	.4287		.4578	.5487
17	.5087	.5914	.6068	.503		.5079	.6001
18	.7796	.7842	.7011	.7522	.8954	.6859	.7186
19	.8507	.8589	.8507	.9134	.9511	.8954	.8596
20	.7316	.7577	.7392	.8688	.8413	.8596	.7947
21	.7023	.6722	.7282	.7499	.7392	.7133	.6908
22	.5914	.5415	.5359	.5304	.5975	.5853	.5228
23	.4108	.3881	.4108	.4108	.415	.3881	.3734
24	.3206	.3547	.3361	.3584	.3547	.3395	.3547
Max	.8507	.8589	.8507	.9134	.9511	.8954	.8596
Min	.3018	.3206	.3012	.3395	.3361	.3206	.3174
Avg	.5399	.5595	.5459	.5457	.5867	.5486	.5482

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244053 / 33/11 KV RETHRE HARNAX STN

Feeder No / Name : 202 / 11 KV TAKARI AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4858	.578	.5121	.0754	.0566	.0566	.0566
2	.4973	.5693	.502	.0754	.0566	.0566	.0566
3	.503	.5376	.502	.0566	.0566	.0566	.0566
4	.5365	.5441	.5243	.0566	.0754	.056	.0566
5	.547	.5506		.0754	.0747	.0747	.0747
6	.5967	.6081	.5571	.0943	.0934	.0934	.0747
7	.1109	.1132	.112	.112	.1132	.1109	.1097
8	.132	.1132	.1109		.0943	.0943	.112
9	.1132	.1132	.112		.0943	.1132	.0943
10	.1132	.112	.1132	.8097	.8684	.9995	.8718
11	.1132	.1132	.1132	1.166	1.0159		1.0883
12	.1132	.112	.0943	1.1633		1.1822	1.166
13	.112	.0943	.0754	1.1873		1.1498	1.1469
14	.0934	.0747	.0754	1.186		1.1633	1.1012
15	.0747	.0754	.0943	1.166		1.1174	1.0688
16	.1132	.112	.1132	.8002		1.0402	.9962
17	.1132	.0934	.0943	.8436		.9998	.9922
18	.1132	.1109	.0943	.0943	.1132	.1132	.0943
19	.1132	.112	.0943	.0754	.112	.1132	.0934
20	.1132	.0924	.0943	.0754	.1132	.1132	.0934
21	.1132	.0934	.0943	.0943	.1132	.1132	.0943
22	.0754	.0924	.0754	.0943	.0754	.0943	.0754
23	.0125	.4481	.0754	.0754	.0566	.0754	.4744
24	.4687	.578	.5121	.0754	.0754	.0566	.0754
Max	.5967	.6081	.5571	1.1873	1.0159	1.1822	1.166
Min	.0125	.0747	.0754	.0566	.0566	.056	.0566
Avg	.2241	.2517	.2063	.4297	.1810	.3932	.4218

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244053 / 33/11 KV RETHRE HARNAX STN

Feeder No / Name : 203 / 11 KV RETHRE HARNAX AG SEPARATED AG FEEDERS HAVING SPECIAL
 FEEDER Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0537	.0532	.0747	.9922	.7562	.7907	.7968
2	.0549	.0537	.0554	.9717	.7562	.7499	.7968
3	.0549	.0537	.056	.9717	.7655	.7186	.8065
4	.0543	.0543	.0747	.9831	.7811	.7274	.8322
5	.0549	.0543	.0747	1.0159		.7362	.8322
6	.0543	.0537	.0924	1.0242	.7907	.7811	.8381
7	.0716	.0895	.0934	.0739	.1132	.0886	.0503
8	.0724	.0701	.1294	.0701	.132	.0709	.0747
9	.0663	.0709	.112	.0693	.1509	.0867	.0754
10	1.2955	1.3603	1.4251	.0924	.1417	.0747	.0732
11	1.704	1.7444	1.8023	.0943	.1387		.0663
12	1.7368	1.8351	1.6712	.0754		.0566	.0655
13	1.6194	1.6964	1.5524	.0943		.0566	.0497
14	1.7166	1.4255	1.7859	.0943		.0566	.0671
15	1.7368	1.8564	1.6004	.0754		.0754	.0671
16	1.6004	1.6712	1.3435	.0754		.0754	.0829
17	.5506	1.4563	1.3279	.0754		.0943	.0857
18	.0358	.1086	.061	.0754		.0943	.1052
19		.0914	.0886	.0943	.1433	.0754	.0876
20	.0514	.0934	.0876	.0934	.1433	.0754	.0701
21	.0693	.1075	.0867	.0943	.1417	.0934	.0747
22	.052	.0924	.0693	.0943	.1448	.0754	.0724
23	.0537	.0747	.8539	.7468	.7274	.7655	.0724
24	.0526	.0532	.0747	.8855	.7468	.7907	.8124
Max	1.7368	1.8564	1.8023	1.0242	.7907	.7907	.8381
Min	.0358	.0532	.0554	.0693	.1132	.0566	.0497
Avg	.5571	.5925	.6081	.3722	.4108	.3135	.2898

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244053 / 33/11 KV RETHRE HARNAX STN

Feeder No / Name : 204 / 11KV Bhavaninagar LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4973	.4744	.4961	.5801	.0069	.0069
2	.5533	.5281	.5407	.5735	.0072	.0069
3	.5533	.5218	.5344	.5735	.0072	.0065
4	.5596	.5281	.5344	.5801	.0076	.0069
5	.547	.5441	.5281	.5668	.0076	.0069
6	.547	.5571	.5441	.5601	.0076	.0065
7	.5571	.5506	.5506	.0076	.0072	.0069
8	.5636	.5506	.5636	.0069	.0065	.0069
9	.5636	.5571	.5571	.0069	.0061	.0065
10	.5967	.5735	.6133	.0072	.0069	
11	.5967	.5761	.5801	.0065		.0065
12	.5967	.583	.5801	.0065	.0065	.0069
13	.5735	.0227	.5668	.0065	.0061	.0065
14	.5735	.4001	.5801	.0069	.0065	.0065
15	.5801	.5898	.5801	.0061	.0057	.0065
16	.5735	.5601	.5801	.0061	.0057	.0057
Max	.5967	.5898	.6133	.5801	.0076	.0069
Min	.4973	.0227	.4961	.0061	.0057	.0057
Avg	.5645	.5073	.5581	.2188	.0068	.0066

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244112 / 33/11 KV BAHE SUB-STATION

Feeder No / Name : 201 / 11 KV BAHE GOVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0895	.1109	.1109	.128	.1448	.1267	.1109
2	.0905	.1097	.1109	.1294	.1463	.1097	.1109
3	.0914	.1086	.1109	.1267	.1433	.1109	.1109
4	.1646	.1848	.1109	.1294	.2172	.2378	.1663
5	.2218	.3142	.2033	.2801	.2561	.3077	.2033
6	.2987	.2957	.2587	.3326	.2957	.3326	.3547
7	.3142	.3326	.3292	.3326	.3174	.2987	.3361
8	.2534	.2561	.2303	.2896	.2328	.2534	.2218
9	.2126	.197	.2103	.1734	.1928	.208	.1646
10	.1696	.1423	.1696	.1475	.1372	.1696	.1402
11	.1475	.144	.128	.16	.1029	.1619	.1475
12	.1457	.1147	.1457	.1094	.1107	.144	.1326
13	.1296	.1296	.1475	.1265	.1174	.1492	.1311
14	.128	.1326	.1326	.1492	.1134	.1311	.1475
15	.1357	.1326	.1265	.1492	.1134	.1457	.128
16	.1492	.1475	.1094	.1326	.1147	.1372	.112
17	.1543	.1619	.1296	.1562	.1423	.1562	.1423
18	.2058	.1844	.1886	.2126	.1886	.1981	.1989
19	.2328	.2507	.2303	.2534	.2507	.2534	.2481
20	.2896	.2507	.2481	.2195	.2172	.2353	.2149
21	.2195	.2218	.2172	.2218	.181	.2195	.2353
22	.168	.1494	.1646	.1663	.181		.197
23	.1294	.1109	.1267	.1463	.128	.1463	.1075
24	.0905	.1109	.1097	.1267	.1478	.1267	.1109
Max	.3142	.3326	.3292	.3326	.3174	.3326	.3547
Min	.0895	.1086	.1094	.1094	.1029	.1097	.1075
Avg	.1763	.1789	.1687	.1833	.1747	.1896	.1739

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244112 / 33/11 KV BAHE SUB-STATION

Feeder No / Name : 202 / 11 KV KHARATWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1802	.128	.0743				
2	.1823	.1311	.0743				
3	.1865	.1296	.0743				
4	.1886	.1475	.0743				
5	.2279	.1638	.0762			.0185	
6	.2686	.1543	.0743				
7		.0187		.0181			
8		.0187					
9	.0343						
10	.0173			.1524	.2105	.208	.213
11	.0168			.2343	.2429	.2688	.2881
12	.0166			.2469	.25	.3005	.3077
13	.0164			.2656	.2812	.3361	.3479
14	.0168			.3281	.2056	.3201	.3479
15	.0171			.2812	.2372	.3361	.3521
16	.0168			.2778	.2031	.3479	.3479
17	.0171			.2932	.1875	.3361	.3395
18	.0343						
19	.0354						
20	.0351						
21	.0189		.0173				
22	.0173					.1829	
23	.112	.0594					.1134
24	.1739	.128	.0743				
Max	.2686	.1638	.0762	.3281	.2812	.3479	.3521
Min	.0164	.0187	.0173	.0181	.1875	.0185	.1134
Avg	.0832	.1079	.0674	.2331	.2273	.2655	.2953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244112 / 33/11 KV BAHE SUB-STATION

Feeder No / Name : 203 / 11 KV HUBALWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0358	.0343	.0377	.4755	.4475	.3681	.4666
2	.0362	.0351	.0377	.4816	.4424	.3725	.4666
3	.0362	.0358	.0377	.4755	.427	.3768	.4666
4	.0366	.0362	.0377	.4877	.4321	.3856	.4666
5	.0543	.0543	.0566	.5093	.4428	.3953	.4666
6	.0549	.0366	.0754	.5218	.4744	.4481	.4607
7	.0554	.0554	.0754	.0543	.056	.0686	.0549
8	.0549	.0549	.0554	.0537	.0549	.0514	.0362
9	.0354	.0554	.0358	.0543	.0509	.0686	.037
10	.8642	1.004	.9646	.0324	.0526	.0537	.0362
11	1.1363	1.166	1.078	.0328	.0175	.0351	.0366
12	1.2003	1.166	1.1069	.0324			.037
13	1.1203	1.2003	1.1405	.0347			.0362
14	1.0883	1.278	1.1385	.0175	.0351		.0366
15	1.0562	1.2289	1.0802	.0351	.0351	.0332	.0358
16	1.0562	1.2125	1.0623	.0351	.0358	.052	.0343
17	.9922	1.166	.8223	.0301		.0343	.0351
18	.0509	.0377	.0347	.0537	.0351	.037	.0343
19	.0678	.056	.0354	.0554	.0526	.0566	.0347
20	.0514	.056	.0358	.0554	.0526	.0566	.0351
21	.0514	.0373	.0358	.0373		.0377	.0354
22	.0343	.0373	.0354	.037	.0316	.0377	.0351
23	.0343	.0373	.4843	.4475	.3321	.3567	.0358
24	.0358	.0343	.037	.4816	.4578	.3681	
Max	1.2003	1.278	1.1405	.5218	.4744	.4481	.4666
Min	.0343	.0343	.0347	.0175	.0175	.0332	.0343
Avg	.3850	.4215	.3975	.1888	.1983	.1759	.1487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244113 / 33/11 KV YEDEMACHHINDRA

Feeder No / Name : 201 / 11 KV MANCHHINDRANAT

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /
OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3239	.3048	.3429	.3048	.3048	.3048
2	.2858	.3239	.3048	.3239	.3048	.3048	.3048
3	.2858	.3239	.3048	.3239	.3048	.3048	.3048
4	.3429	.3239	.3239	.381	.362	.3048	.3429
5	.4382	.4191	.4572	.4763	.4572	.4382	.4572
6	.7545	.7922	.7167	.811	.724	.7922	.7733
7	.8676	.8775	.8589	.8775	.7655	.8865	.8299
8	.6722	.6653	.7282	.6722	.6036	.6722	.7468
9	.5729	.5487	.5853	.5544	.4854	.5544	.5175
10	.5194	.4163	.5304	.4656	.4024	.4163	.4733
11	.4557	.3582	.443	.4344	.3077	.3898	.3898
12	.4075		.4075	.3582	.333	.3641	
13	.3814	.3403	.3801	.3258	.3366	.3155	.3944
14	.3761	.3403	.3224	.3077	.3403	.3012	.3721
15	.3856	.3475	.3292	.3258	.2896	.2774	.3403
16	.3353	.3582	.3582	.3582	.3045	.3155	.3681
17	.3856	.4075	.4252	.4031	.3761	.3506	.4382
18	.6335	.5121	.5304	.6099	.567	.5853	.6201
19	.7947	.823	.7468	.7655	.7655	.8413	.823
20	.7655	.7282	.6908	.7095	.6908	.7655	.7207
21	.679	.6602	.6602	.6413	.6161	.6161	.6602
22	.5281	.4854	.5281	.4854	.4854	.5093	.5228
23	.3734	.362	.4001	.362	.3475	.3395	.3547
24	.3239	.3239	.3239	.5525	.3239	.3239	.3239
Max	.8676	.8775	.8589	.8775	.7655	.8865	.8299
Min	.2858	.3239	.3048	.3077	.2896	.2774	.3048
Avg	.4946	.4809	.4859	.4945	.4499	.4698	.4949

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244113 / 33/11 KV YEDEMACHHINDRA

Feeder No / Name : 202 / 11KV KRISHNA LIS

PURELY LIS FEEDERS

YEDEMACHHINDR Feeder KV- 11 /
OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.004	.5506	.5761	.583	.5401	.3953
2	.004	.5601	.5761	.5898	.5468	.3953
3	.0038	.5693	.583	.5898	.5468	.3795
4	.0038	.5761	.583	.583	.5693	.3795
5	.0038	.5761	.583	.583	.583	.3795
6	.0036	.583	.5761	.5761	.5624	.3795
7	.3005	.5441	.5761	.5761	.5601	.5601
8	.3906	.5441	.5601	.5761	.5121	.5761
9	.583	.5441	.5668	.5761	.5601	.5761
10	.5761	.5441	.5668	.5668	.5668	.5601
11	.5601	.5441	.583	.5506	.5601	.583
12	.5441	.5601	.5898	.5506	.5601	.5761
13	.5441	.5601	.583	.5668	.5693	.5761
14	.5441	.5441	.5761	.5668	.583	.5693
15	.5441	.5601	.5761	.5668	.583	.5693
16	.5441	.5601	.5624	.5761	.5668	.5624
Max	.583	.583	.5898	.5898	.583	.583
Min	.0036	.5441	.5601	.5506	.5121	.3795
Avg	.3221	.5575	.5761	.5736	.5606	.5011

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244113 / 33/11 KV YEDEMACHHINDRA

Feeder No / Name : 203 / 11KV Kilemachindragad Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.8078	.8173	.1334	.0572	.0714	
2	.8078	.8128	.8173	.1334	.0572	.0714	
3	.7926	.8128	.8278	.1107	.0572	.0638	
4	.8025	.7716	.8429	.1334	.0926	.0667	
5	.7225	.8619	.8951	.1715	.0914	.1143	
6	.8642	1.0517	1.0364	.1905	.1905	.1524	
7	.1638	.1429	.1429	.2012	.1677	.1905	
8	.1265	.1286	.1638	.1783	.1475	.1475	
9	.1021	.1219	.1067	.1021	.1638	.1265	
10	.1219	.0894	.1524	1.2037	1.1717	1.034	1.057
11	.0894	.0894	.1423	1.7341	1.4842	1.5497	1.4266
12	.0894	.1021	.1423	1.8976	1.6204	1.5813	1.5089
13	.0894		.1423	2.0241	1.6667	1.5895	1.6358
14	.0914	.0894	.1217	2.0715	1.6975	1.6091	1.6667
15	.0857	.0894	.1423	2.0241	1.5586	1.6091	1.7284
16	.076	.096	.1429	1.9372	1.5466	1.5242	1.6461
17	.1143	.1021	.1353	1.8056	1.4217	1.4449	1.5851
18	.1265	.1475	.1353	.1638	.1107	.1265	.1353
19	.1423	.1638	.1905	.1905	.1524	.1524	.1353
20	.1423	.1486	.1905	.1423	.1524	.1524	.1423
21	.1265	.1286	.1638	.1021	.1524	.1334	.1149
22	.0894	.1082	.1423	.0894	.1334	.0894	.1021
23	.6984	.7827	.1067	.0857	.0914	.0914	.6308
24	.8429	.7827	.8579	.1021	.0572	.0714	
Max	.8642	1.0517	1.0364	2.0715	1.6975	1.6091	1.7284
Min	.076	.0894	.1067	.0857	.0572	.0638	.1021
Avg	.3394	.3666	.3566	.7053	.5851	.5735	.9654

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244113 / 33/11 KV YEDEMACHHINDRA

Feeder No / Name : 204 / 11KV Shirte Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0497	.0486	.0648	.6802	.6081	.5441	.5441
2	.0497	.0486	.0486	.6478	.6081	.5441	.5441
3	.0509	.0486	.0486	.6478	.6081	.5441	.5441
4	.0509	.0486	.0486	.664	.6241	.5441	.5601
5	.0509	.0486	.0648	.6882	.6562	.5441	.5693
6	.0848	.081	.0972	.8002	.7522	.6562	.7116
7	.1029	.0972	.0972	.112	.096	.096	.0949
8	.0876	.0648	.0972	.096	.08	.08	.0791
9	.052	.0486	.081	.08	.064	.064	.0791
10	1.1065	1.3441	1.3117	.064	.048	.048	.0633
11	1.5565	1.7814	1.749	.064	.048	.048	.0633
12	1.7204	1.8461	1.8785	.064	.048	.048	.0474
13	1.8679	1.8623	1.8785	.064		.064	.0633
14	1.7204	1.8461	1.8138	.016		.048	.0633
15	1.8023	1.749	1.7652	.064		.048	.0633
16	1.7166	1.5546	1.6356	.08	.048	.064	.0633
17	1.7166	1.5546	1.4899	.064	.08	.08	.0633
18	.081	.0972	.081	.096	.096	.096	.0791
19	.0972	.0972	.081	.096	.096	.096	.0949
20	.0972	.1134	.081	.096	.096	.096	.0949
21	.081	.1134	.081	.096	.096	.08	.0791
22	.0648	.0972	.081	.064	.08	.08	.0633
23	.0486	.081	.6478	.6241	.5601	.5441	.0474
24	.048	.0486	.0648	.664	.6241	.5601	.5441
Max	1.8679	1.8623	1.8785	.8002	.7522	.6562	.7116
Min	.048	.0486	.0486	.016	.048	.048	.0474
Avg	.5960	.6134	.6370	.2763	.2865	.2340	.2175

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244120 / 33/11 KV Ganeshnager

Islampur

Feeder No / Name : 201 / 11 KV RAJARAM NAGER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1524	.1494	.1294	.1715	.1494	.1494
2	.112	.1524	.112	.1307	.1524	.112	.1307
3	.112	.1524	.112	.112	.1524	.112	.1307
4	.1132	.1715	.1132	.1307	.1715	.1132	.1294
5	.1132	.1715	.1132	.1478	.1905	.1132	.1463
6	.1509	.1715	.1509	.1463	.2096	.1509	.1478
7	.2263	.1905	.2263	.181	.2477	.2614	.2587
8	.2241	.2286	.2218	.2195	.2477	.2614	.2402
9	.2218	.2172	.2667	.2218	.2172	.2587	.2477
10	.2218	.2353	.2286	.1848	.2402	.2218	.2286
11	.2195	.2353	.2477	.1848	.2378	.2033	.2096
12	.2195	.2172	.2286	.1867	.2218	.2033	.2096
13	.1829	.181	.2286	.1867	.1463	.2033	.1715
14	.1829	.2172	.2096	.1829	.1097	.1848	.1905
15	.1829	.1991	.1905	.1791	.128	.1829	.181
16	.2033	.1991	.1715	.1829	.1097	.2012	.181
17	.2286	.1991	.1991	.2477	.1433	.2218	.1433
18	.2477	.2149	.1991	.2667	.2172	.2195	.2126
19	.3048	.2218	.2353	.2858	.2561	.2587	.2587
20	.2667	.2218	.2353	.2667	.2218	.2402	.2587
21	.2286	.2241	.2353	.2477	.2241	.2218	.2218
22	.1905	.1867	.2033	.2286	.1886	.2033	.1848
23	.1715	.1494	.1848	.2096	.1886	.1663	.1494
24	.1494	.1715	.1494	.1463	.1905	.1494	.1494
Max	.3048	.2353	.2667	.2858	.2561	.2614	.2587
Min	.112	.1494	.112	.112	.1097	.112	.1294
Avg	.1926	.1951	.1922	.1919	.1910	.1922	.1888

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244120 / 33/11 KV Ganeshnager

Islampur

Feeder No / Name : 202 / 11 KV Uran-Islampur

GAOTHAN FEEDER

Gaothan. Feeder KV- 11 /
OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6219	.8383	.7095	.6348	.7621	.6219	.5544
2	.5914	.8192	.6722	.6161	.724	.6219	.5544
3	.5544	.8192	.6348	.6099	.724	.6219	.5359
4	.5544	.8954	.6348	.6535	.8192	.7023	.567
5	.7392	.9717	.7023	.7133	.8954	.7762	
6	.924	1.0098	.924	.9511	.9526	1.0719	1.0791
7	.961	.9717	.9979	1.0349	.9717	1.0349	1.0164
8	.924	.9145	.924	.9709	.9907	.9335	.8871
9	.8131	.7421	.8764	.7602	.7947	.8501	.8573
10	.8501	.8326	.8764	.7316	.6767	.8501	.8764
11	.695	.7964	.7811	.7392	.439	.6838	.6859
12	.7499	.7059	.6478	.724	.3696	.7023	.6097
13	.6584	.6878	.6097	.7316	.5175	.6036	
14	.6401	.6154	.5716	.6878	.4344	.6036	.724
15	.6401	.6516	.6478	.6805	.439	.5853	.6219
16	.8501	.8145	.743	.815	.695	.7316	.7964
17	.9335	.724	.7762	1.086	.7011	.7392	.7164
18	.9907	.8764	.924	1.2574	.8238	.9055	.8505
19	1.2384	1.1584	1.1827	1.2955	1.1222	1.2197	1.1584
20	1.1431	1.0498	.8501	1.2193	1.1222	1.0829	1.0498
21	1.0479	.9877	1.0349	1.0098	.9774	.9709	.9877
22	.9145	.8413	.9145	.9526	.8779	.8962	.9145
23	.8383	.7316	.8316	.8764	.7316	.6722	.7392
24	1.7147	.7811	.7095	.6653	.7811	.6219	.5729
Max	1.7147	1.1584	1.1827	1.2955	1.1222	1.2197	1.1584
Min	.5544	.6154	.5716	.6099	.3696	.5853	.5359
Avg	.8578	.8432	.7990	.8507	.7643	.7960	.7889

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244120 / 33/11 KV Ganeshnager

Islampur

Feeder No / Name : 203 / 11KV Mahadev Nagar Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6283	.9145	.7392	.7207	.8383	.6283	.6283
2	.5975	.8954	.7023	.6468	.8192	.5914	.6099
3	.5975	.8954	.6653	.6348	.7811	.5914	.5487
4	.6348	.9145	.6722	.6348	.7811	.5975	.5914
5	.7095	.9335	.7468	.7059	.9335	.6348	.7207
6	.8589	.9907	.8962	.8779	1.0669	.8589	.8686
7	1.0456	1.0288	.9335	1.2197	1.1431	1.1203	1.1523
8	1.1949	1.2955	1.1827	1.3717	1.1622	1.2567	1.3306
9	.924	1.0136	1.105	1.0498	1.0425	1.0349	1.2193
10	1.1458	1.1222	1.1812	.9877	.9145	1.3169	1.2193
11	.961	.905	.9717	.9412	.8131	.8962	.9145
12	.8962	.8507	.8764	.9511	.7762	.8413	.8383
13	.8048	.7964	.8573	.905	.7577	.8779	.7621
14	.7682	.7964	.8383	.8413	.7023	.8413	.8573
15	.7316	.7602		.788	.7392	.7133	.7682
16	.7499	.7602	.7621	.7522	.7577	.7682	.7602
17	1.086	.8326	.8688	1.1622	.7602	.8326	.8326
18	1.2193	1.0745	1.2382	1.4861	1.1462	.8131	1.134
19	1.5813	1.39	1.4415	1.5432	1.4632	1.5181	1.448
20	1.448	1.2437	1.3306	1.4098	1.3169	1.3535	1.3169
21	1.1622	1.134	1.2012	1.3527	1.1706	1.1888	1.1706
22	1.105	.9145	1.0608	1.1431	.961	1.0242	.9877
23	.8954	.7762	.8779	.9717	.7762	.8131	.7762
24	.6653	.8383	.7392	.7499	.8954	.6653	.6584
Max	1.5813	1.39	1.4415	1.5432	1.4632	1.5181	1.448
Min	.5975	.7602	.6653	.6348	.7023	.5914	.5487
Avg	.9338	.9615	.9517	.9936	.9383	.9074	.9214

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244120 / 33/11 KV Ganeshnager

Islampur

Feeder No / Name : 204 / 11KV Urun Ag Feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.5335	.4687	.0754	.0762	.0762	.0732
2	.4214	.5335	.4374	.0754	.0762	.0754	.0732
3	.3913	.5716	.4062	.0754	.0762	.0754	.0739
4	.3963	.5906	.4012	.0747		.0754	.0747
5	.4268	.6097	.463	.0739	.0762	.0754	.0747
6	.4572	.6097	.4938	.0732	.0762	.0762	.0739
7	.1109	.0762	.0754	.0739	.0762	.0754	.0739
8	.0747	.0762	.0754	.0732	.0762	.0754	.0739
9	.0754	.064	.0762	.0724	.0655	.0747	.0762
10	.1132	.064	.0762	.8124	.7209	.7716	.7621
11	.1132	.064	.0762	.8002	.8539	.8402	.8954
12	.1132	.064	.0762	.9374	.7655	.9667	1.0288
13	.0754	.0678	.0762	.9877	.8124	.9503	1.105
14	.0754	.0678	.0762	1.0311	.7811	.9175	1.086
15	.0754	.0678	.0762	1.0883	.7811	.8848	.9831
16	.0754	.0678	.0762	.9488	.7373	.9339	.8642
17		.0678	.0671	1.2193	.7099	.8453	.6958
18	.0762	.0754	.0732	.0762	.0762	.0678	.0747
19	.0762	.0754	.0732	.0762	.0762	.0732	.0754
20	.0762	.0754	.0732	.0762	.0762	.0732	.0747
21	.0762	.0754	.0732	.0762	.0762	.0732	.0747
22	.0762	.0754	.0732	.0762	.0754	.0732	.0747
23	.5335	.463	.0739	.0762	.0754	.0732	.3201
24	.4458	.4763	.4687	.0739	.0762	.0762	.0747
Max	.5335	.6097	.4938	1.2193	.8539	.9667	1.105
Min	.0747	.064	.0671	.0724	.0655	.0678	.0732
Avg	.2088	.2297	.1836	.3760	.3171	.3458	.3690

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 201 / 11 KV BORGAON GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
14	.9526
Max	.9526
Min	.9526
Avg	.9526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 202 / 11 KV KHED GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	.9526
Max	.9526
Min	.9526
Avg	.9526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 203 / 11 KV WALWA FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 204 / 11 KV LIS BOR FEEDER

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
13	.9526
Max	.9526
Min	.9526
Avg	.9526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 205 / 11 KV KHED AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-DEC-17
HR	Load (MW)
24	1.1431
Max	1.1431
Min	1.1431
Avg	1.1431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 206 / 11 KV BORGON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-DEC-17
HR	Load (MW)
24	1.1431
Max	1.1431
Min	1.1431
Avg	1.1431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 403 / Rathare BK

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-DEC-17
HR	Load (MW)
24	2.8578
Max	2.8578
Min	2.8578
Avg	2.8578

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 701 / Rajaram Bpau SSK Sakharale NON SHEDDABLE EHV INDUSTRIAL FEEDERS

Feeder KV- 132 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-DEC-17
HR	Load (MW)
24	.0229
Max	.0229
Min	.0229
Avg	.0229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 201 / 11 KV Kasegaon Gaothan-
Village Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.2328		.2195		.2126	.1886
2	.1509	.2195		.2149		.2218	
3	.1509	.2195		.2507		.2587	
4	.1509	.2987		.2987		.3224	
5	.2263	.3734		.3921		.4298	
6	.415	.4525		.439		.5487	
7		.5853		.5853		.6401	
8	.5853	.5487		.543	.5487	.5729	
9	.5175	.4755	.4755	.4887	.3749	.5544	
10	.439	.439	.4607	.3982	.4435	.4435	
11	.3511	.3982	.2382	.3658	.3658	.3801	
12	.3658	.2743	.4252	.3403	.4024	.3475	
13	.3982	.3109	.4024	.3292	.3475	.3326	
14	.2896	1.2254	.362	.2926	.3258	.3326	
15	.2561	.2172	.3258	.2715	.3475	.2801	
16	.2378	.2561	.3086	.3109	.3681	.4298	
17	.4525	.3658	.4298	.3658	.4066		.4938
18	.5487		.5304	.5487	.5175		.6283
19	.6154		.567		.6036	.5853	.6767
20	.5487		.4805		.5175	.4755	.5611
21	.4163		.4207		.4251	.4805	.4755
22	.3658		.3511		.362		.362
23	.2353		.2402		.2534		.2172
24	.1886	.2328		.2195		.2126	
Max	.6154	1.2254	.567	.5853	.6036	.6401	.6767
Min	.1509	.2172	.2382	.2149	.2534	.2126	.1886
Avg	.3503	.3959	.4012	.3618	.4131	.4031	.4504

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 202 / 11 KV Nerle Gaothan feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3361		.3018		.3361	
2		.2987		.2561		.2987	
3		.2926		.2561		.2926	
4		.3511		.3361		.3658	
5		.4435		.4344		.4805	
6		.5415		.5228		.5601	
7		.5658		.4481		.5415	
8	.5914	.5658		.4904	.5121	.5658	
9	.4805	.5144	.3898	.3601	.4066	.4481	
10	.4805	.4668	.4755	.4115	.2926	.4108	
11	.3982	.4108	.439	.4435	.3109	.3961	
12	.4344	.3982	.4066	.4024	.3326	.3584	
13	.362	.3258	.3881	.3881	.4066	.3734	
14	.4024	.2926	.4755	.4572	.3658	.3772	
15	.439	.2033	.4024	.4024	.3511	.4338	
16	.4344		.4344	.462	.3429	.415	
17	.5658		.5601		.3326		.4527
18	.6535		.6413		.4481		.547
19	.8299		.6161		.6908		.6908
20	.6602		.6036		.5658		.6979
21	.5975		.547		.5658		.679
22	.5281		.4668		.439		.5601
23	.3841		.3395		.3734		.3734
24		.3395		.3018		.3395	
Max	.8299	.5658	.6413	.5228	.6908	.5658	.6979
Min	.362	.2033	.3395	.2561	.2926	.2926	.3734
Avg	.5151	.3967	.4790	.3926	.4210	.4114	.5716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 203 / 11 KV Tambave Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2641		.2614		.2507	
2		.2641		.2126		.2328	
3		.2658		.2126		.2378	
4		.3366		.3361		.3475	
5		.4024		.4108		.4066	
6		.4755		.462		.4805	
7		.5359		.5249		.5068	
8	.5121	.4938		.4887	.4607	.4938	
9	.439	.4755	.2896	.3841	.4435	.3881	
10	.4207	.4024	.2926	.2926	.2743	.3658	
11	.3982	.3258	.3077	.2896	.2896	.3658	
12	.4115	.2507	.2534	.3439		.2926	
13	.3772	.2835	.2743	.3109		.2926	
14	.2507	.2126	.2926	.3258	.2534	.2743	
15	.2896	.197	.2896	.2658	.2715	.2195	
16	.3475		.2896	.2896	.3258	.2172	
17	.3511	.2454	.3696		.2865		.2743
18	.3881		.4066		.3658		.3292
19	.4525		.3582		.4755		.4066
20	.3761		.4435		.4344		.4024
21	.4024		.4435		.3658		.394
22	.362		.3658		.2715		.3734
23	.3258		.2987		.2896		.3292
24		.2987		.2614		.2614	
Max	.5121	.5359	.4435	.5249	.4755	.5068	.4066
Min	.2507	.197	.2534	.2126	.2534	.2172	.2743
Avg	.3815	.3370	.3317	.3337	.3434	.3314	.3584

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 204 / 11 KV Wategaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.1494		.1612		.1478	.1132
2	.0754	.1086		.1478		.1433	
3	.0754	.1097		.1478		.1791	
4	.0754	.1848		.1772		.1886	
5	.1509	.1848		.2126		.2641	
6	.2263	.2561		.2987		.2957	
7		.3841		.3439		.3326	
8	.2561	.3475		.3658	.3292	.3439	
9	.2561	.3258	.3292	.3547	.2587	.2743	
10	.1928	.2926	.2926	.2614	.197	.2195	
11	.2103	.2926	.2743	.2218	.2149	.1848	
12	.2012	.2427	.2715	.2218		.2195	
13	.1991	.2103	.2534	.1463	.2149	.2241	
14	.2195	.1928	.2865	.1629	.1928	.1867	
15	.1829	.181	.2149	.1646	.1402	.1646	
16	.2534	.181	.2172	.1629	.1753	.1646	
17	.2561	.2195	.2715	.2195	.1886		.2772
18	.3841		.3109	.3658	.2587	.3326	.3292
19	.4298		.4572		.3658	.4066	.4294
20	.4066		.3982		.3511	.4066	.4938
21	.3258		.3258		.2915	.3696	.3475
22	.1867		.2743		.2241		.2172
23	.1494		.1646		.1463		.1629
24	.1132	.1494		.1612		.1478	
Max	.4298	.3841	.4572	.3658	.3658	.4066	.4938
Min	.0754	.1086	.1646	.1463	.1402	.1433	.1132
Avg	.2131	.2229	.2895	.2262	.2366	.2474	.2963

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 205 / 11 KV KASEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0623	1.1843		.0457		.0457	
2	1.0623	1.2125		.0457		.0457	
3	1.0623	1.2452		.0457		.0457	
4	.9374	1.2163		.0457		.0762	
5	.9374	1.1843		.061		.0838	
6	1.0623	1.1203		.0457		.061	
7		.0914		.0457		.061	
8	.061	.061		.0914	.061	.1067	
9	.061	.0949	.061	.061	.061	.061	
10	.0937	.0949	.0781	1.4373	1.2498	1.2803	
11	.0949	.0937	.0791		1.3592	1.4083	
12	.0791	.0937	.0937	1.8519	1.358	1.4883	
13	.08	.0791	.0949	1.9753	1.3889	1.4232	
14	.08	.0949	.0937	2.0622	1.4373	1.3763	
15	.08	.1094	.0937	2.0934	1.4842	1.3763	
16	.096	.0937	.1067	2.0934	1.4746	1.3283	
17	.0762		.1067		1.2811		
18	.0762		.061		.061		.061
19	.061		.061		.061		.061
20	.061		.061		.061		.0457
21	.061		.0457		.061		.0457
22	.061		.0457		.061		.0457
23	1.0562		.0457		.0457		.7842
24	1.0623	1.1203		.0457		.0457	
Max	1.0623	1.2452	.1067	2.0934	1.4842	1.4883	.7842
Min	.061	.061	.0457	.0457	.0457	.0457	.0457
Avg	.4072	.5406	.0752	.7529	.7191	.6067	.1739

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 206 / 11 KV NERLE AG. FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0457		1.1203		.7362	
2		.0457		1.1843		.7842	
3		.0625		1.1702		.7748	
4		.0625		1.2018		.759	
5		.0457		1.2018		.759	
6		.061		1.1523		.7842	
7		.0762		.061		.0762	
8	.061	.061		.061		.061	
9	.061	1.9997	.061	.061		.061	
10	2.7496	2.1559	2.1403	.0762		.0457	
11	2.6558	2.5309	2.1822	.0937		.061	
12	2.6715	2.5934	2.1872	.1094		.0457	
13	2.7183	2.5606	2.2028	.0937		.0457	
14	2.6871	2.6063	2.2862			.061	
15	2.7027	2.6871	2.3015			.0457	
16	2.6216	2.4996	2.1872			.0457	
17	2.6558		2.1872		.1094		.0457
18	.061		.061		.0457		.0457
19	.0762		.061		.061		.0457
20	.061		.061		.061		.061
21	.061		.061		.061		.061
22	.061		.061		.061		.0457
23	.0457		1.0883		.6722		.0457
24		.0457		1.1203		.7362	
Max	2.7496	2.6871	2.3015	1.2018	.6722	.7842	.061
Min	.0457	.0457	.061	.061	.0457	.0457	.0457
Avg	1.3719	1.1847	1.2753	.6219	.1530	.3460	.0501

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 207 / 11 KV Wategaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2483		.061		.061	
2		1.2944		.061		.061	
3		1.2944		.0457		.061	
4		1.2003		.0457		.0781	
5		1.1203		.0914		.0762	
6		1.0883		.125		.125	
7		.1562		.125		.125	
8	.1219	.0914		.1067	.1219	.1406	
9	.1219	.1094	.1219	.125	.1219	.1219	
10	.125	.1094	.0937	1.5779		1.6644	
11	.1219	.1094	.1107	2.1715		1.8724	
12	.1219	.0949	.1094	2.1403		2.1765	
13	.0937	.0949	.0937	2.1822		2.2885	
14	.1094	.0781	.0949	2.0805		2.3525	
15	.1094	.0937	.1107	2.0965		2.2405	
16		.0926	.1094	2.4166	.25	2.2565	
17	.0914		.125	2.1403	.2968		2.3205
18	.2031		.125		.0457		.125
19	.1406		.125		.2187		.125
20	.125		.125		.125		.125
21	.125		.125		.125		.125
22	.1094		.125		.0937		.0937
23	1.1843		.0762		.061		1.2803
24		1.2483		.061		.061	
Max	1.1843	1.2944	.125	2.4166	.2968	2.3525	2.3205
Min	.0914	.0781	.0762	.0457	.0457	.061	.0937
Avg	.1936	.5603	.1114	.9807	.1460	.9272	.5992

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 208 / 11 KV Tambave Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0457		1.3123		.7042	
2		.0457		1.3443		.7362	
3		.0457		1.3283		.7274	
4				1.3916		.7432	
5		.0625		1.4083		.7432	
6		.061		1.3443		.7682	
7		.061		.061		.061	
8	.061	.061		.061	.061	.061	
9	.061	.0625	.061	.0457	.061	.061	
10	2.2965	2.1403	.0926	.061	.0914	.0457	
11	2.3122	2.3015	.0937	.0914	.0914	.0457	
12	2.3746	2.2862	.0937	.0937	.1094	.0457	
13	2.4669	2.3167	.1067	.1094	.1094	.0457	
14	2.4371	2.4059	.1067	.1094	.0937	.0457	
15	2.4371	2.4669	.125	.1094	.0949	.0457	
16	2.2809	2.2497	.0937	.0937	.0937	.0457	
17	2.2809		.0937		.108		.0762
18	.061		.061		.061		.061
19	.061		.061		.061		.061
20	.061		.061		.061		.061
21	.061		.061		.061		.061
22	.0457		.061		.061		.061
23	.0457		1.3123		.6401		.0457
24		.0457		1.3123		.7042	
Max	2.4669	2.4669	1.3123	1.4083	.6401	.7682	.0762
Min	.0457	.0457	.061	.0457	.061	.0457	.0457
Avg	1.2090	1.0411	.1656	.6045	.1162	.3311	.0610

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 209 / 11 KV Someshwar

PURELY LIS FEEDERS

Bhairavnath LI Feeder KV- 11 /
OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1387	.0732		.0543	.0189
2	.1387	.0732		.056	.0181
3	.1387	.0724		.1307	.0181
4	.1387	.1086		.128	.0179
5	.1387	.1109		.1646	.0179
6	.1387	.1494		.2012	.0187
7		.7095		.7602	.5228
8	.8402	.8596		.8507	.5601
9	.8402	.8869	.8688	.8688	.5788
10	.8962	.8869	.8779	.8869	.567
11	.8779	.8779	.8779	.905	.5975
12	.8869	.8596	.8507	.7888	.5975
13	.8962	.8775	.8326	.7888	.5914
14	.8962	.8413	.8596	.7888	.5729
15	.8764	.8589	.0732	.8764	.5975
16	.6344	.8402	.9134	.8573	.6036
17		.8402			
Max	.8962	.8869	.9134	.905	.6036
Min	.1387	.0724	.0732	.0543	.0179
Avg	.5651	.5839	.7693	.5692	.3687

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 210 / 11 KV Krishna LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3375	.2401		.2229		.4531
2	1.3375	.2401		.2229		
3	1.3375	.3258		.2572		
4	1.3375	.463		.3944		
5	1.3375	1.166		.8916		
6	1.3546	1.3546		1.3003		
7		1.5261		1.3032		
8	1.3375	1.4746		1.3203	.0514	
9	1.5089	1.3717	1.4754	1.2517	.8916	
10	1.543	1.5604	1.4918	1.1393	.6001	
11	1.5083	1.5775	1.5089	1.2094	.6173	
12	1.5424	1.595	1.3435	.7011	.9431	
13	1.5261	1.595	1.3413	.7545	1.1145	
14	1.5432	1.6124	1.3904	.7888	1.5432	
15	1.5604	1.5947	1.2193	.4801	1.0802	
16		1.5947	1.3546	.2915	1.0117	
17		1.595				
24				.2229		
Max	1.5604	1.6124	1.5089	1.3203	1.5432	.4531
Min	1.3375	.2401	1.2193	.2229	.0514	.4531
Avg	1.4366	1.2286	1.3907	.7501	.8726	.4531

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 202 / 11 KV YELUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.4526	.1867	.2263	.2263	.1867	.1886
2	.3734	.415	.1829	.2075	.2075	.1829	.1698
3	.5487	.3772	.181	.1886	.1886	.1829	.1698
4	.5068	.3772	.2218	.2263	.1886	.181	.2263
5	.5914	.4904	.3361	.3018	.2641	.2172	.3206
6	.7012	.7168	.415	.4338	.4108	.3582	.3961
7	.961	1.0456	.499	.5415	.499	.5041	.5415
8	.887	.924	.4024	.4251	.4572	.4298	.4251
9	.695	.7682	.362	.3841	.362	.3658	.4024
10	.6584	.6584	.3109	.2926	.4252	.2896	.3224
11	.5792	.5193	.2715	.2353	.4656	.2715	.2328
12	.5068	.4206	.2328	.181	.1791	.2507	.2149
13	.4656	.439	.2353	.1791	.2353	.2149	.197
14	.4656	.439	.2534	.1791	.2195	.1772	.181
15	.4962	.4344	.2561	.181	.181	.1578	.181
16	.2835	.4298	.2534	.2195	.1829	.2303	.181
17	.6024	.6024		.3658	.2172	.3045	.2561
18	.7964	.8326	.362	.4251	.4066	.362	.3841
19	.998	.878	.4938	.5415	.4294	.567	.499
20	.4854	.961	.462	.5041	.4481	.5359	.4668
21	.9192	.8216	.3921	.415	.3772	.4108	.4294
22	.7733	.6412	.3206	.3395	.2987	.3395	.3395
23	.5658	.4526	.2263	.2641	.2263	.2263	.2641
24	.1698	.4904	.1886	.2263	.2263	.1886	.1886
Max	.998	1.0456	.499	.5415	.499	.567	.5415
Min	.1698	.3772	.181	.1791	.1791	.1578	.1698
Avg	.6001	.6078	.3063	.3118	.3051	.2973	.2991

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 203 / 11 KV Aitwadi Kh -Gaothan-

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.3396	.1867	.1886	.1886	.1829	.1509
2	.4298	.3396	.1867	.1886	.1698	.1791	.1509
3	.439	.3396	.1848	.1886	.1698	.181	.1509
4	.5974	.5281	.2195	.2263	.1698	.1886	.1886
5	.724	.5282	.3258	.3206	.2263	.2587	.2987
6	.8962	.7544	.4481	.3921	.3584	.3292	.3734
7	.8596	.9336	.4344	.4805	.5041	.499	.499
8	.7316	.8502	.4024	.439	.4435	.4024	.4572
9	.7164	.7094	.362	.362	.3658	.394	.362
10	.6378	.6584	.3841	.3258	.2896	.3224	.3045
11	.6024	.5608	.3258	.3045	.2481	.3012	.2507
12	.5258	.5068	.2865	.2865	.2172	.2629	.2353
13	.5258	.6036	.2658	.2507	.2534	.2427	.2172
14	.4962	.5174	.2279	.2534	.2195	.2058	.2172
15	.4962	.4854	.2454	.2353	.2195	.2254	.2328
16	.573	.4854	.2629	.3109	.2241	.2454	.2328
17	.591	.4908	.2804	.3109	.2103	.3012	.2686
18	.695	.7796	.3582	.3841	.4252	.3582	.3475
19	.924	.7964	.4525	.4854	.4706	.5249	.462
20	.8962	.8048	.439	.4668	.4755	.4755	.4481
21	.7544	.7392	.4066	.3772	.4024	.4251	.4108
22	.6036	.5914	.3361	.2829	.2957	.3174	.3018
23	.4904	.2614	.1886	.2452	.2241	.2452	.2263
24	.1848	.3772	.1886	.1886	.1886	.168	.1509
Max	.924	.9336	.4525	.4854	.5041	.5249	.499
Min	.1848	.2614	.1848	.1886	.1698	.168	.1509
Avg	.6149	.5826	.3083	.3123	.2900	.3015	.2891

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 204 / 11 KV WASHI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.1698	.1463	.1509	.1698	.1478	.1509
2	1.4327	.1509	.1433	.1509	.1509	.1463	.1509
3	.1753	.132	.1267	.132	.1509	.1463	.132
4	.2507	.132	.124	.1698	.1698	.181	.1886
5	.2926	.1886	.1267	.2263	.2263	.2561	.2829
6	.3018	.3018	.2957	.3395	.3018	.3155	.3395
7	.3772	.4294	.4656	.4108	.4294	.421	.4854
8	.4161	.4066	.362	.4066	.4207	.4359	.499
9	.3506	.3658	.3189	.3658	.3982	.4458	.439
10	.3366	.2614	.3109	.3292	.3658	.3506	.3224
11	.2835	.2172	.2715	.2896		.3155	.2328
12	.2454	.2126	.2149	.2715	.2058	.2454	.2149
13	.2454	.1898	.2149	.2353	.1829	.1734	.197
14	.2303	.2374	.1772	.2172	.2172	.1372	.1991
15	.2303	.2641	.1928	.1991	.2534		.181
16	.2507	.1341	.1715	.2172	.2561	.1578	.181
17	.2865	.1791	.1886	.2926	.2481	.1791	.2715
18	.362	.3258	.3155	.3658	.4066	.362	.3475
19	.499	.4024	.4207	.4668	.3932	.567	.4435
20	.4668	.4024	.4251		.3978	.5175	.4294
21	.415	.3658	.4108		.3315	.4108	.3734
22	.3018	.2926	.3018		.2683	.3395	.2641
23	.2263	.1867	.1886	.2987	.1867	.1886	.2263
24	.112	.1698	.1494	.1509	.168	.1494	.1509
Max	1.4327	.4294	.4656	.4668	.4294	.567	.499
Min	.112	.132	.124	.132	.1509	.1372	.132
Avg	.3431	.2549	.2526	.2708	.2739	.2865	.2793

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 205 / 11 KV Aitwade Kh Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0377	.0373	1.1768	.381	1.0059	.8192
2	.0366	.0377	.0377	1.1603	.381	.9389	.7956
3	.0358	.0377	.0377	1.1568	.4062	.9602	.779
4	.0526	.0377	.0377	1.1736	.427	.9465	.8383
5	.0543	.0377	.0373	1.2071	.4801	1.0745	.8886
6	.0566	.0566	.0566	1.2574	.5441	1.1919	.9724
7	.0943	.0754	.0754	.0754	.0566	.0857	.0754
8	.0566	.0754	.056	.0754	.0566	.0716	.0566
9	.0747	.0566	.0566	.0377	.0377	.0351	.0377
10	1.6956	2.0332	1.5424	.0366	.0377	.0377	.0377
11	1.8991	1.8564	1.7436	.0362	.0377	.0377	.0377
12	2.0119	1.9281	2.1195	.0354	.0377	.0373	.0366
13	2.0287	2.0119	2.0008	.0177	.0373	.037	.0362
14	2.0287	2.0348	1.8442	.0179	.0373	.0373	.0181
15	1.9839	2.0119	1.7238	.0179	.0377	.0377	.0183
16	1.95	1.8442	1.7269	.0183	.056	.0377	.0183
17	1.8991	1.8233	1.749	.0377	.0566	.0377	.037
18	.0566	.0566	.0377	.0566	.0566	.0377	.0566
19	.0566	.0566	.0566	.0566	.056	.0566	.0566
20	.0566	.056	.0566	.0566	.0566	.0566	.0566
21	.0566	.0377	.0377	.0566	.0566	.0566	.0566
22	.0377	.0377	.0377	.0377	.0566	.0377	.0566
23	.0377	.0377	1.1768		.9503	.8453	.0377
24	.0377	.0377	.0377	1.1934	.3311		.8356
Max	2.0287	2.0348	2.1195	1.2574	.9503	1.1919	.9724
Min	.0358	.0377	.0373	.0177	.0373	.0351	.0181
Avg	.6806	.6798	.6801	.3911	.1947	.3348	.2775

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 207 / 11 KV WASHI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1984	1.2631	1.1523	.0377	.0377	.0373	.0377
2	1.1934	1.2944	1.1469	.0377	.0377	.037	.0377
3	1.1869	1.2944	1.1736	.0377	.0377	.0366	.0377
4	1.2689	1.326	1.2689	.0377	.0377	.0362	.0377
5	1.262	1.3413	1.3321	.0566	.0566	.0732	.0377
6	1.1469	1.4083	1.2163	.0754	.0754	.0732	.0754
7	.1086	.0943	.0716	.0754	.0943	.0934	.0754
8	.0747	.0754	.0549	.0754	.0914	.0732	.0747
9	.0732	.0566	.0566	.0739	.0732	.0566	.0739
10	.0732	.056	.056		1.5089	1.1984	1.1603
11	.0543	.0566	.056	2.4863	1.4575	1.4746	1.5729
12	.0543	.0543	.056	2.5857	1.6004	1.4746	1.6907
13	.0537	.0566	.0554	2.6189	1.6004	1.5415	1.7604
14	.0537	.0566	.056	2.652	1.6766	1.5074	1.7604
15	.0566	.052	.0754	2.7681	1.5546	1.4899	1.7736
16	.0566	.056	.0754	2.6686	1.2651	1.4582	1.7901
17	.0754	.0566	.0754		1.2037	1.4083	1.6907
18	.0914	.0943	.0754		.1132	.0747	.0754
19	.0943	.0943	.0754		.0943	.0754	.0754
20	.0943	.0943	.0754		.0943	.0754	.0754
21	.0943	.0943	.0754		.0754	.0754	.0754
22	.0943	.0943	.0566		.0701	.0566	.0566
23	1.166	1.1523	.0377	.0566	.0566	.0377	.578
24	1.326	1.247		.0377	.0377	.0377	.0377
Max	1.326	1.4083	1.3321	2.7681	1.6766	1.5415	1.7901
Min	.0537	.052	.0377	.0377	.0377	.0362	.0377
Avg	.4563	.4779	.3641	.9636	.5396	.5209	.6109

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 208 / 11 KV YELUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3077	1.442	1.4586	.0566	.1132	.0754	.0566
2	1.3077	1.4586	1.4083	.0566	.1132	.0747	.0566
3	1.3375	1.4754	1.4403	.0566	.1132	.0549	.0566
4	1.4022	1.4754	1.6126	.0566	.1132	.0549	.0754
5	1.4327	1.5261	1.7193	.0754	.1132	.0554	.0754
6	1.3108	1.6278	1.6194	.0943	.132	.0747	.0943
7	.1075	.1132	.1097	.0943	.1294	.0934	.1132
8	.0905	.0943	.0934	.0943	.128	.0732	.112
9	.0754	.0754	.0739	.0934	.1097	.0724	.0739
10		.0747	.0754	2.6139	1.7924	1.5844	1.4045
11	.0754	.0747	.0754	2.8006	1.8861	2.037	1.8484
12	.0754	.362	.056	2.6886	1.905	2.037	2.0748
13	.0747	.0934	.0554	2.6513	1.905	1.9418	2.1125
14	.0732	.0754	.056	2.6139	1.8671	1.9044	2.1313
15	.0732	.0754	.0566	2.5766	1.8861	1.8484	2.0559
16	.0724	.0747	.056	2.5019	1.7551	1.6975	1.9805
17	.0905	.0867	.0739	2.4832	1.7353	1.4712	1.8861
18	.1132	.1402	.112	.132	.112	.0943	.1132
19	.132	.1463	.132	.1509	.1063	.1132	.1132
20	.132	.128	.1132	.1509	.1075	.1132	.1132
21	.1132	.1307	.1132	.132	.0934	.0943	.0943
22	.0943	.0914	.0943	.132	.0924	.0754	.0943
23	1.3923	1.5023	.0754	.132	.0943	.0754	.8223
24	1.419	1.4586	1.4251	.0566	.132	.0747	.0566
Max	1.4327	1.6278	1.7193	2.8006	1.905	2.037	2.1313
Min	.0724	.0747	.0554	.0566	.0924	.0549	.0566
Avg	.5349	.5751	.5044	.9373	.6890	.6580	.7340

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 209 / 11 KV Kundalwadi Ag feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366	.0377	.0362	1.5091	1.291	.3658	1.2071
2	.0358	.0377	.0366	1.4586	1.3395	1.3611	1.1869
3	.0351	.0377	.0366	1.4419	1.3395	1.3321	1.1869
4	.0362	.0377	.0716	1.4922	1.3904	1.3394	1.2209
5	.037	.0377	.0747	1.5261	1.4918	1.4266	1.3032
6	.0492	.0566	.0514	1.5947	1.5432	1.6598	1.3717
7	.0693	.0754	.0754	.0716	.0754	.0943	.0686
8	.0537	.0754	.0724	.0724	.0754	.0716	.0693
9	.0549	.0566	.0716	.0549	.0566	.0343	.0526
10	2.5149	2.7633	2.5265	.0362	.0358	.0305	.0351
11	2.5987	2.5774	2.6578	.0362	.0343	.0305	.0351
12	2.7469	2.572	2.8464	.0179	.0537	.0312	.0358
13	2.73	2.8121	2.7778	.0179	.0324	.032	.0358
14	2.713	2.7435	2.713	.0181	.0335	.0328	.0181
15	2.6282	2.4691	2.6791	.0181	.0343	.0335	.0181
16	2.572	2.713	2.5549	.0183	.0351	.0343	.0181
17	2.5377	2.5434	2.3569	.0377	.0358	.0343	.037
18	.0732		.0514	.0566	.0709	.0347	.0566
19	.0754	.0724	.0686	.0566	.0537	.0701	.0754
20	.0754	.0895	.0693	.0566	.0543	.0532	.0754
21	.0754	.056	.0701	.0566	.0537	.0537	.0566
22	.0566	.0549	.0526	.0566	.0724	.0362	.0566
23	.0377	.0347	1.4754	1.2574	1.4022	1.2717	.0377
24	.0373	.0377	.0358	1.5091	1.291	1.4937	1.2239
Max	2.7469	2.8121	2.8464	1.5947	1.5432	1.6598	1.3717
Min	.0351	.0347	.0358	.0179	.0324	.0305	.0181
Avg	.9117	.9562	.9776	.5196	.4957	.4566	.3951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244067 / 33/11 KV YEDENIPANI STN

Feeder No / Name : 202 / 11 KV ITKARE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0934	.0934	1.1702	1.0155	1.0974	1.0669
2	.0934	.0943	.0934	1.1561	1.0155	1.073	1.0669
3	.0934	.0934	.0934	1.1702	.9998	1.073	1.0669
4	.0934	.0934	.0934	1.1702	.9998	1.073	1.0974
5	.1307	.112	.112	1.2967	1.0936	1.1443	1.1728
6	.1646	.1509	.1463	1.4864	1.2498	1.4022	1.358
7	.1463	.1307	.1463	.1478	.1629	.132	.156
8	.1267	.1478	.128	.1448		.1132	.1227
9	.1267	.1109	.1294	.1267	.128	.1132	.1227
10	2.2177	2.1253	2.0165	.1097	.1097	.128	.0914
11	2.7069	2.4874	2.5606	.0934	.1132	.0914	.0914
12	2.8778	2.6886	2.8054	.0934	.0914	.0934	.0381
13	2.8959	2.8166	2.6703	.0934	.0943	.0934	.0381
14	2.8959	2.8166	2.6703	.0886	.0943	.0934	.0381
15	2.8597	2.7692	2.4508	.0886	.0754	.0924	.0381
16	2.652	2.7069	2.2546	.1097	.0732	.0924	.0381
17	2.2546	2.4874	2.2177	.1417	.0754	.0934	.0381
18	.1463	.1307	.1448	.1417	.0943	.1267	.1029
19	.1646	.1646	.1629		.1509	.1463	.1509
20	.1463	.1629	.1478	.1307	.1509	.1509	.1509
21	.132	.1478	.128	.112	.132	.124	.128
22	.112	.1463	.0914	.0924	.1132	.1267	.1132
23	.0943	.1097	1.1111	1.0185	1.2071	1.0974	.0914
24	.0914	.0934	.0934	1.1561	1.0311	1.2071	1.1584
Max	2.8959	2.8166	2.8054	1.4864	1.2498	1.4022	1.358
Min	.0914	.0934	.0914	.0886	.0732	.0914	.0381
Avg	.9714	.9533	.9401	.493	.4466	.4574	.3974

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244067 / 33/11 KV YEDENIPANI STN

Feeder No / Name : 204 / 11 KV ITKARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1463	.1494	.1463	.1463	.1463	.1494
2	.1494	.1463	.1494	.1463	.1463	.1463	.1494
3	.1494	.1463	.1494	.1463	.1463	.1463	.1494
4	.1494	.1463	.1494	.1463	.1463	.1463	.1494
5	.1867	.1829	.1494	.2012	.2012	.2012	.1867
6	.2614	.2743	.2427	.2926	.2926	.2926	.2801
7	.3174	.3841	.3361	.3658	.3475	.3658	.3511
8	.3511	.3109	.3174		.3109	.2926	.3547
9	.3174	.2743	.2801	.3109	.2743	.2561	.2801
10	.2561	.2427	.2195	.2561	.2561	.2987	.2614
11	.2378	.2427	.2378	.2743	.2195	.2427	.2957
12	.1991	.2427	.2378	.2353	.2195	.2427	.2241
13	.181	.2054	.1991	.1829	.1829	.2054	.2241
14	.1991	.1867	.1991	.1829	.1829	.2054	.2054
15	.1991	.2054	.1991	.1829	.1829	.2427	.1867
16	.1991	.2054	.181	.1663	.1829	.1867	.2561
17	.1991	.2427	.181	.2378	.2195	.168	.1848
18	.3326	.2987	.2957	.3292	.2926	.2987	.2926
19	.3841	.4066	.3841	.3841	.3658	.3658	.3658
20	.3658	.3881	.3292	.3475	.3658	.3658	.3658
21	.3109	.3326	.2743	.2926	.3292	.3109	.3658
22	.2561	.2801	.2378	.2378	.2561	.2743	.2743
23	.1646	.2054	.1829	.1829	.2195	.2427	.2195
24	.1494	.1463	.1494		.1463	.1646	.1494
Max	.3841	.4066	.3841	.3841	.3658	.3658	.3658
Min	.1494	.1463	.1494	.1463	.1463	.1463	.1494
Avg	.2361	.2435	.2263	.2386	.2347	.2420	.2467

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244111 / 33/11 KV Karanjawade S/S

Feeder No / Name : 201 / 11 KV Karanjawade Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.2195	.2218	.2402	.1829	.1848	.2033
2	.1829	.2195	.1848	.2402	.1829	.1848	.2033
3	.1829	.2195	.1848	.2402	.181	.1848	.2033
4	.2218	.2195	.2587	.2402	.2172	.2218	.2033
5	.2957	.2743	.2957	.2402	.2534	.2957	.2587
6	.3696	.4435	.3696	.415	.4024	.3696	.4108
7	.4024	.4805	.3326	.4108	.3658	.3696	.4251
8	.3361	.4024	.3658	.439	.3658	.4435	.3658
9	.3361	.3475	.4024	.3582	.3658	.4066	.3658
10	.3077	.3658	.4207	.3544	.3292	.4207	.3292
11	.3366	.3658	.3681	.3189	.2926	.3109	.3292
12	.3012	.3292	.3366	.3189	.2561	.2926	.2896
13	.2241	.2926	.2715	.2481	.1829	.2353	.2172
14	.2263	.2195	.2195	.2126	.1463	.1867	.2534
15	.2241	.2926	.2254	.2481	.2561	.1829	.2172
16	.2218	.2561	.2515	.2835	.2561	.2195	.2172
17	.2957	.2561	.2804	.3189	.2926	.2587	.2926
18	.4066	.3292	.3841	.3544	.3658	.3361	.3292
19	.5544	.5487	.5487		.5544	.5601	.5175
20	.5914	.5487	.567	.5487	.5914	.5175	.5544
21	.5228	.5121	.5121	.5121		.4435	.4805
22	.4108	.3696	.3921	.3658	.3696	.3326	.3326
23	.2926	.2587	.2614	.2012	.2218	.2218	.2218
24	.2195	.2378	.2218	.2402	.2012	.1848	.2033
Max	.5914	.5487	.567	.5487	.5914	.5601	.5544
Min	.1829	.2195	.1848	.2012	.1463	.1829	.2033
Avg	.3186	.3337	.3282	.3196	.2971	.3069	.3093

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244111 / 33/11 KV Karanjawade S/S

Feeder No / Name : 202 / 11 KV Devarde AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0311	1.1336	.9998	.056	.0566	.0373	.056
2	.9998	1.1336	.9998	.056	.0566	.0373	.056
3	.9998	1.1336	.9998	.056	.0566	.0373	.056
4	1.012	1.1336	1.0936	.056	.0747	.056	.056
5	1.0437	1.2308	1.2186	.0747	.0747	.056	.056
6	1.0753	1.3592	1.3123	.0934	.0754	.0747	.0747
7	.0934	.0934	.112	.112	.0754	.0934	.0934
8	.0747	.0914	.0747	.0934	.0747	.0747	.0739
9	.0747	.0732	.056	.0747	.056	.2241	.0549
10	.0739	.0549	.0187	1.3599	1.1873	1.1203	.9804
11	.0739	.0549	.0373	2.119	1.5935	1.5708	1.4548
12	.0724	.0732	.056	2.4036	1.7497	1.6194	1.7711
13	.0732	.0549	.056	2.5301	1.8122	1.2803	1.866
14	.0549	.0549	.0747	1.4232	1.7185	.8962	1.9292
15	.0549	.0366	.0747	1.6248	1.8122	1.247	1.8027
16	.0549	.0549	.0747	2.3122	1.6872	1.3279	1.8343
17	.0549	.0366	.0747	2.1914	1.5935	1.4575	1.6872
18	.0739	.0732	.0747	.0747	.0934	.0914	.056
19	.0747	.0732	.0747	.0747	.0747	.0739	.0747
20	.0747	.0732	.0732	.0934	.0747	.0747	.0747
21	.0747	.0732	.0739	.0747		.0747	.0747
22	.056	.0732	.0747	.0754	.0747	.0747	.0754
23	.9555	.8436	.056	.0754	.056	.056	.6173
24	1.0311	1.1336	1.0311	.056	.0754	.056	.056
Max	1.0753	1.3592	1.3123	2.5301	1.8122	1.6194	1.9292
Min	.0549	.0366	.0187	.056	.056	.0373	.0549
Avg	.3858	.4228	.3663	.7150	.6176	.4880	.6221

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244111 / 33/11 KV Karanjawade S/S

Feeder No / Name : 203 / KARVE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0554	.0373	.0373	.7074	.3125	.4801	.4961
2	.0554	.0373	.0373	.7074	.3086	.4801	.4961
3	.0554	.0373	.0373	.7164	.3086	.4801	.4801
4	.0732	.0373	.0373	.7164	.3395	.5121	.4801
5	.0732	.0373	.056	.787	.3658	.5761	.5121
6	.0914	.0747	.0747	.8333	.4877	.6081	.5992
7	.1109	.0934	.0747	.0934	.0732	.1097	.1097
8	.1109	.0914	.0934	.0747	.0549	.1097	.0914
9	.1109	.0914	.056	.0724	.0549	.0732	.0914
10	1.0155	.7811	.8796	.0914	.0549	.0905	.0739
11	1.6842	1.3748	1.5023	.0914		.0905	.0739
12	1.3927	1.6248	1.7814	.1097	.0549	.0905	.0739
13	2.0972	1.7166	1.8138	.0914	.0732	.0724	.0549
14	2.0645	1.9109	1.8404	.0905	.0549	.0543	.0732
15	2.1956	1.9757	1.7764	.0905	.0732	.0543	.0366
16	2.0481	1.8461	1.6762	.0905	.0549	.0543	.0732
17	1.8842	1.7166	1.6091	.1086	.0732	.0905	.0739
18	.0914	.056	.0686		.0732	.0724	.0739
19	.0934	.0747	.0895		.0914	.0934	.0747
20	.0934	.0747	.0914		.0732	.0934	.0747
21	.0747	.0747	.0732			.0747	.0739
22	.0747	.056	.0732		.0732	.0747	.0739
23	.056	.0747	.6554	.3125	.4062	.3521	.037
24	.0549	.0373	.0373	.7074	.3437	.5121	.4902
Max	2.1956	1.9757	1.8404	.8333	.4877	.6081	.5992
Min	.0549	.0373	.0373	.0724	.0549	.0543	.0366
Avg	.6524	.5805	.6030	.3417	.1730	.2208	.1995

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244111 / 33/11 KV Karanjawade S/S

Feeder No / Name : 204 / Ganesh Chikurde LIS Feeder

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1629	.1991	.2172	.2172	.181	.181
2	.1629	.2172	.2172	.2172	.181	.181
3		.2172	.2172	.2172	.181	.181
4	.1629	.2172	.2172	.2172	.181	.181
5	.181	.2172	.2172	.2172	.181	.181
6	.181	.2172	.2353	.2172	.2172	.181
7	.181	.2172	.2353	.2534	.2172	.2172
8	.181	.2172	.2353	.2534	.2172	.2172
9	.181	.2172	.2353	.2534	.2172	.2172
10	.181	.2172	.2534	.2172	.2172	.2172
11	.181	.2172	.2534	.2353	.2172	.2172
12	.181	.1267	.2534	.2172	.2172	.2172
13	.181	.1267	.2534	.2172	.2172	.2172
14		.1267	.2534	.2172	.2172	.2353
15	.2353	.2353	.2534	.2241	.2172	.2353
16	.2172	.2353	.2534	.2353		.2353
Max	.2353	.2353	.2534	.2534	.2172	.2353
Min	.1629	.1267	.2172	.2172	.181	.181
Avg	.1836	.2014	.2376	.2267	.2051	.2070

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 402 / 33 KV KASEGAON LIS FEEDER

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	4.2067
Max	4.2067
Min	4.2067
Avg	4.2067

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 403 / (Kurloop)Shirala

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-DEC-17
HR	Load (MW)
24	3.6808
Max	3.6808
Min	3.6808
Avg	3.6808

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 405 / 33 KV Dindayal Sut Girani NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING (NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-DEC-17
HR	Load (MW)
24	1.086
Max	1.086
Min	1.086
Avg	1.086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 406 / 33 KV Echo Board

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-DEC-17
HR	Load (MW)
24	4.3439
Max	4.3439
Min	4.3439
Avg	4.3439

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 407 / 33 KV Kasegaon Feeder
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-DEC-17
HR	Load (MW)
24	2.1719
Max	2.1719
Min	2.1719
Avg	2.1719

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 702 / 132 KV Peth Wategaon NON SHEDDABLE EHV INDUSTRIAL FEEDERS

Feeder Feeder KV- 132 / (CONTINUOUS PROCESS)(NO STAGGERING

OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	.631
Max	.631
Min	.631
Avg	.631

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 201 / 11 KV BIUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2967	1.4864	1.3916	.061		.0324	.0648
2	1.3123	1.5043	1.4083	.061		.0312	.0648
3	1.2346	1.4998	1.3748	.061		.032	.0648
4	1.2651	1.4998	1.4232	.061		.0617	.0648
5	1.2334	1.4815	1.3889	.0762		.0625	.081
6	1.3123	1.5181	1.406	.0762		.0625	.0972
7	.0937	.0949	.0949	.0914		.0633	.0972
8	.0949	.0937	.0949	.0762		.0633	.0648
9	.0949	.0633	.0949	.0762		.0316	.0648
10	.0914	.061	.061	2.1643		.8436	.6706
11	.061	.0625	.061	2.5263		1.1248	.7186
12	.0594	.0469	.061	2.9058	.4458	1.2186	1.9814
13	.0914	.0457	.061	2.8121	.6097	1.2193	2.2024
14	.0594	.0446	.061	2.7808	.9061	1.8122	2.2253
15		.0469	.061	2.5621	.8535	1.8595	2.2558
16	.0937	.0457	.061		.8749	2.0119	2.1338
17	.0892	.0625	.0762	1.9204		2.1052	2.0729
18	.0625	.0949	.0762	.0762	.0316	.0648	.0633
19	.0949	.0949	.0914		.032	.0648	.0949
20	.0949	.0949	.0762	.0305	.0474	.0648	.0949
21	.0949	.0949	.0762	.0305	.0648	.0648	.0949
22	.0625	.0949	.0762	.0305	.0316	.0648	.0633
23	1.3916	1.3599	.0762	.0305	.0312	.0648	1.0437
24	1.3283	1.4864	1.3599	.061	.0305	.0316	.0648
Max	1.3916	1.5181	1.4232	2.9058	.9061	2.1052	2.2558
Min	.0594	.0446	.061	.0305	.0305	.0312	.0633
Avg	.5049	.5408	.4589	.8441	.3299	.544	.6852

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 202 / 11 KV SHIRALA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1265	.3749	.3163	.0305		.032	.0324
2	.128	.3795	.3163	.0305		.0312	.0324
3	.096	.3795	.3163	.0305		.0316	.0324
4	.096	.4111	.3437	.0305		.032	.0324
5	.0926	.4012	.3395	.0305		.0316	.0324
6	.0625	.4111	.3437	.0305		.0312	.0324
7	.032	.0312	.0312	.0305		.032	.0324
8	.032	.0316	.0312	.0305		.0324	.0324
9	.032	.0312	.0312	.0305		.0312	.0324
10	.0305	.0305	.0305	.4374		.4268	.3658
11	.0312		.0305			.5624	.4572
12	.029		.0305	.5624	.1829	.5487	.4999
13	.0297	.0305	.0305	.5937		.5487	.4999
14	.0305	.0305	.0305	.6097		.5487	.4877
15	.0297	.0305	.0305	.5624	.1829	.5487	.5182
16	.0305	.0305	.0305		.3048	.5487	.503
17		.0305	.0305	.4572	.3353	.5182	.5155
18	.032	.032	.0305	.0305	.032	.0324	.0312
19	.032	.0312	.0305	.0305	.0316	.0324	.0312
20	.0312	.032	.0305	.0305	.0312	.0324	.0316
21	.0316	.0316	.0305	.0305	.0312	.0324	.0312
22	.032	.032	.0305	.0305	.0312	.0362	.0316
23	.4062	.2812	.0305	.0305	.0312	.0324	.3163
24	.125	.3795	.2846	.0305	.0305	.0316	.0324
Max	.4062	.4111	.3437	.6097	.3353	.5624	.5182
Min	.029	.0305	.0305	.0305	.0305	.0312	.0312
Avg	.0695	.1570	.1159	.1687	.1113	.1986	.1935

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 203 / 11 KV NATH AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0316	.0312	.032	.5121		.3841	.3887
2	.0316	.0312	.0312	.5155		.4062	.3239
3	.0312	.032	.0312	.5312		.4012	.3239
4	.032	.0316	.0312	.5441		.4321	.3239
5	.0309	.032	.032	.6249		.4687	.3887
6	.064	.0316	.032	.6874		.463	.3887
7	.0617	.0625	.0625	.0762		.064	.0486
8	.0625	.064	.0625	.0762		.064	.0648
9	.064	.0625	.064	.08		.0625	.0648
10	.7499	.8749	.823	.061		.0625	.0594
11	.8749	.9374	.9842	.0457		.0469	.0594
12	.9374	.9804	.9602	.0457	.0625	.061	.0457
13	.9374	.9282	.8802	.061	.061	.0446	.0457
14	.9374	.9374	1.0155	.061	.0457	.0446	.0446
15	.8535	.8124	1.085	.0625	.0457	.0446	.0457
16	.9061	.884	.9998		.0297	.061	.0457
17	.8124	.7499	.9842	.061	.0457	.0648	.0594
18	.0625	.0625	.0625	.0762	.0633	.081	.032
19	.0937	.0633	.061	.061	.0625	.0648	.0648
20	.096	.0625	.061	.061	.0625	.0648	.064
21	.064	.0633	.061	.061	.0625	.0648	.08
22	.0633	.0625	.0457	.0457	.032	.0648	.0316
23	.032	.0312	.5121	.4687	.3749	.421	.032
24	.032	.032	.0316	.4877	.4801	.3749	.3887
Max	.9374	.9804	1.085	.6874	.4801	.4687	.3887
Min	.0309	.0312	.0312	.0457	.0297	.0446	.0316
Avg	.3276	.3275	.3727	.2307	.1099	.1797	.1423

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 204 / 11 KV KAPARI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3479	.8539	.7274	1.1188		.727	.8421
2	.3178	.8977	.7575	1.1058		.7274	.8421
3	.2789	.919	.7553	1.1058		.7682	.8421
4	.3086	.9487	.8181	1.1188		.7902	.9069
5	.3109	.9854	.8322	1.1508		.8638	1.0041
6	.3711	.9926	.8436	1.169		1.0432	1.166
7	.2496	.3441	.2499	.2385		.2187	.1943
8	.3162	.2503	.2499	.2225		.2168	.1943
9	.2781	.253	.2842	.2546		.2187	.162
10	1.3116	1.6553	1.5348	1.0135		.958	.884
11	1.9365	1.8435	1.8869	1.2498		1.1736	.9884
12	2.3106	2.1445	1.9044	1.1385	.5716	1.2041	1.0501
13	2.4051	1.829	1.9204	1.1873		1.2361	1.076
14	2.1933	2.0927	1.9509	1.2194		1.2049	1.0958
15	2.1231	2.2977	1.8869	1.1111	.5266	1.1888	1.1431
16	2.1605	2.207	1.8869		.7422	1.1736	1.1279
17	1.9365	1.9967	1.8229	1.0821	.7925	1.166	1.1279
18	.1859	.2503	.2225	.2225	.1878	.1943	.1897
19	.2534	.2534	.2225	.192	.221	.1943	.1874
20	.2503	.2191	.2225	.2065	.2236	.1943	.2191
21	.221	.2195	.192	.1905	.2232	.1943	.1897
22	.1855	.3437	.192	.1585	.1931	.162	.1596
23	.8798	.6923	1.0547	.7347	.6878	.9393	.6604
24		.8539	.6957	1.0867	.8002	.6958	.8745
Max	2.4051	2.2977	1.9509	1.2498	.8002	1.2361	1.166
Min	.1855	.2191	.192	.1585	.1878	.162	.1596
Avg	.9188	1.0560	.9631	.7947	.4700	.7272	.7136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 206 / 11 KV BIUR GAOTAHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.1829	.1848	.2033		.2241	.181
2	.1494	.2218	.1848	.2033		.1848	.181
3	.1463	.2587	.1494	.2033		.1867	.181
4	.1848	.2926	.1509	.2218		.1867	.2172
5	.1829	.2987	.1478	.2926		.2957	.2534
6	.2614	.3326	.2218	.3696		.2926	.2896
7	.3658	.2926	.3292	.3696		.3292	.3258
8	.4024	.2218	.3696	.3109		.3326	.3982
9	.3292	.2957	.3292	.3921		.2926	.362
10	.3326	.3326	.3658	.4066		.3696	.2926
11	.2957	.2926	.3881	.3326		.3326	.2957
12	.2926	.2561	.3326	.2957	.1097	.3361	.2957
13	.2926	.2195	.2957	.2587	.1829	.2195	.2587
14	.3696	.2957	.2957	.2218	.3326	.1848	.2218
15	.2587	.2957	.2772	.2218		.2587	.2957
16	.2587	.3326	.2957	.2218	.2926	.2218	.2926
17	.3142	.3326	.3326	.2587		.2896	.3658
18	.3658	.4755	.3696	.4435	.5487	.362	.3292
19	.5487	.5601	.4805	.5359	.5914	.543	.5487
20	.4805	.4755	.4435	.5175	.5487	.5792	.4755
21	.4066	.4024	.4066	.4251	.3658	.3982	.4108
22	.2561	.3658	.3142	.3326	.2926	.2534	.2561
23	.1829	.2561	.2587	.2743	.2561	.2172	.2195
24	.1463	.1463	.1829	.2195	.2218	.2195	.181
Max	.5487	.5601	.4805	.5359	.5914	.5792	.5487
Min	.1463	.1463	.1478	.2033	.1097	.1848	.181
Avg	.2904	.3099	.2961	.3139	.3403	.2963	.2970

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 207 / 11 KV NATH GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366	.0366	.037	.0366		
2	.0373	.037	.037	.037		
3	.037	.0373	.0373	.0366		
4	.0366	.037	.0366	.0366		
5	.0373	.0373	.0366	.0549		
6	.037	.037	.037	.0549		
7	.037	.0373	.0373	.0554		
8	.037	.037	.037	.0554		
9	.037	.0373	.037	.0554		
10	.0366	.0366	.0554	.0366		
11	.0732	.0366	.0366	.0366		
12	.0366	.0732	.0549	.0366		
13	.0366	.0366	.0554	.0366		
14	.0366	.0366	.0549	.0366		
15	.0351	.0554	.0554	.0366		
16	.0366	.037	.0366	.0366		
17	.0549	.037	.0366	.0366		.0362
18	.037	.037	.0554	.0732		.0724
19	.0739	.0732	.0739	.0732		.0724
20	.0747	.0739	.0924	.0554		.0724
21	.0739	.0739	.0732	.0732		.0724
22	.037	.037	.0554	.037		.0724
23	.037	.037	.0366	.0366		.0362
24	.037	.037	.0373	.037	.0366	
Max	.0747	.0739	.0924	.0732	.0366	.0724
Min	.0351	.0366	.0366	.0366	.0366	.0362
Avg	.0437	.0438	.0476	.0459	.0366	.0621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 208 / 11 KV SHIRALA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.439	.439	.4481	.4435		.4481	.4344
2	.4435	.4854	.439	.4435		.5121	.4344
3	.4481	.5121	.5914	.4435		.5175	.4344
4	.4435	.5975	.5914	.5228		.4481	.5068
5	.439	.6722	.4435	.6653		.6584	.6516
6	.6653	.7392	.5853			.6722	.7964
7	.8871	.7316	.8131	.7577		.6653	.8688
8	.8131	.8131	.8048	.7468		.8962	.8688
9	.7316	.8048	.7392	.8131	1.2012	.8048	.7964
10	.5914	.6653	.7392	.6653		.7392	.7392
11	.7392	.6653	.8589	.6653		.6653	.7392
12	.7392	.7392	.8131	.6653	.8779	.5914	.7316
13		.5914	.7392	.6653	.8871	.5853	.5914
14	.6653	.6584	.7023	.6653	.6653	.6584	.5914
15	.5914	.5544	.6283	.6653	.7392	.5853	.5853
16	.5914	.7392	.6283	.6249	.5914	.5853	.5853
17	.6653	.7392	.6653	.7392		.6516	.6653
18	.7392	.8962	.8589	.8871	.8215	.724	.7468
19	.8962	.8871	.8501	.924	.8962	.8688	.8779
20	.8779	.8048	.8501	.8871	.9709	.9412	.7042
21	.8215	.8048	.7468	.8215	.7316	.7964	.8131
22	.6584	.5914	.6653	.7392	.6722	.6516	.5175
23	.439	.4435	.5544	.6722	.6584	.5068	.5121
24		.439	.4435	.4435	.4435	.439	.5068
Max	.8962	.8962	.8589	.924	1.2012	.9412	.8779
Min	.439	.439	.439	.4435	.4435	.439	.4344
Avg	.6512	.6673	.6750	.6768	.7813	.6505	.6541

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 209 / 11 KV KAPARI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.1463	.1494	.1294		.1494	.1086
2	.1097	.1494	.1867	.128		.1494	.1086
3	.1494	.1478	.1867	.1294		.1463	.1086
4	.1463	.1478	.2241	.1829		.1478	.1448
5	.1494	.1494	.2195	.1848		.112	.1448
6	.1109	.1478	.1848	.2012		.112	.181
7	.1829	.1829	.2587	.2195		.1494	.2172
8	.1867	.2218	.2218	.2241		.1848	.2534
9	.1478	.1848	.2241	.128	.1478	.1109	.2534
10	.2218		.1109	.2587		.2218	.1478
11	.1829	.2957	.1478	.2957		.2195	.2957
12	.2218	.2218	.1478	.2587	.1097	.2957	.2561
13	.2957	.1848	.1109	.2587	.1097	.2957	.2926
14	.1463	.2587	.1109	.2218	.0732	.2561	.2561
15	.2561	.2218	.1109	.2561	.0739	.2561	.2561
16	.2587	.2561	.1463	.1848	.1829	.1463	.2926
17	.2926	.1109	.1848	.1109		.181	.1463
18	.1867	.1109	.2195	.1663	.2195	.2172	.1478
19	.2241	.1848	.2614	.1829	.2218	.2172	.2241
20	.2218	.1494	.2218	.2587	.1829	.2172	.2218
21	.2614	.1829	.2218	.2378	.1478	.2534	.2614
22	.2241	.1494	.1848	.2218	.1109	.2534	.2587
23	.1867	.1463	.1829	.1829	.1494	.181	.1867
24		.1494	.1463	.1478	.1478	.1463	.1448
Max	.2957	.2957	.2614	.2957	.2218	.2957	.2957
Min	.1097	.1109	.1109	.1109	.0732	.1109	.1086
Avg	.1945	.1783	.1819	.1988	.1444	.1925	.2045

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 401 / 33 KV GLUCOSE EXPRESS

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.639	.5898	.4973	.5281		.6464	.6173
2	.5967	.4973	.4915	.6167		.6539	.6173
3	.639	.4915	.5533	.6167		.5967	.6173
4	.6962	.4527	.5967	.6722		.5407	.6173
5	.7042	.4475	.6464	.6642		.6962	.7202
6	.5967	.4424	.5898	.4321		.6962	.7202
7	.6962	.4915	.3521	.4801		.7459	.7202
8	.3932	.6464	.7865	.5898		.4915	.5658
9	.5967	.6464	.6882	.6241		.5407	.5658
10	.5624	.6562	.4915	.7202		.4801	.5344
11	.4687	.6093	.3932	.4687		1.7284	.7682
12	.4458	.4801	.4915	.6562	.1875	.6562	.4858
13	.703	.7287	.6882	.703	.0937	.4687	.5624
14	.4687	.703	.7865	.4687	.2881	.3658	.4687
15	.4687	.7682	.8356	.5155		.3749	.4858
16	.4218	.5487	.7865	.6562	.5624	.5944	.7499
17	.7499	.7287	.7865	.5944	.4115	.7716	.8436
18	.6882	.7956	.4424	.4801	.7373	.7716	.5898
19	.5407	.4915	.7373	.7373	.8453	.5144	.4475
20	.7459	.6962	.7202	.6099	.5967	.463	.6464
21	.5407	.6882	.6882	.6099	.5407	.6173	.6464
22	.4424	.4424	.5281	.4915	.547	.7202	.4973
23	.4915	.4424	.5281	.4915	.7373	.5658	.4973
24	.6464	.639	.4424	.4915	.5761	.6882	.6173
Max	.7499	.7956	.8356	.7373	.8453	1.7284	.8436
Min	.3932	.4424	.3521	.4321	.0937	.3658	.4475
Avg	.5809	.5885	.6062	.5799	.5103	.6412	.6084

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 201 / 11 KV CHARAN AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343				
2	.0343	.0343	.0343				
3	.0343	.0343	.0343				
4	.0343	.0343	.0343				
5	.0343	.0343	.0343				
6	.0343	.0343	.0343				
7			.0343				
10				.0343	.0514	.0343	.0343
11				.0686	.0857	.0686	.0514
12				.0857	.1029	.0686	.0514
13				.1372	.12	.0514	.0686
14				.1372	.0857	.0514	.0686
15				.1029	.1029	.0343	
16				.1029	.0686	.0514	.0686
17				.1029	.0686	.0514	.0686
23	.0343	.0343					.0343
24	.0343	.0343	.0343				
Max	.0343	.0343	.0343	.1372	.12	.0686	.0686
Min	.0343	.0343	.0343	.0343	.0514	.0343	.0343
Avg	.0343	.0343	.0343	.0965	.0857	.0514	.0557

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 202 / 11 KV MANDOOR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2229	.2401	.2229	.2401	.2401	.2058
2	.2058	.2058	.2229	.2058	.2401	.2401	.1715
3	.2058	.2058	.2058	.2058	.2401	.2229	.1715
4	.2058	.2058	.2058	.2058	.2401	.2229	.2058
5	.3086	.2572	.2401	.2572	.2743	.2743	.2401
6	.3944	.3429	.3429	.3258	.3601	.3601	.3086
7	.4973	.4973	.4973	.5144	.4973	.4801	.463
8	.5144	.4973	.5144	.5316	.5144	.3772	.4115
9	.4287	.4801	.4458	.5144	.4973	.3601	.3429
10	.3429	.4287	.4458	.463	.4458	.3258	.3086
11	.3429	.4458	.3772	.463	.3772	.3429	.2572
12	.3429	.3772	.3429	.3601	.3944	.3772	.3258
13	.2915	.3086	.2915	.3944	.3258	.3429	.2743
14	.2229	.2572	.3086	.3429	.3086	.3086	.2572
15	.2915	.2743	.3086	.3601	.2572	.2915	
16	.2915	.2572	.3429	.3086	.2915	.3086	.3086
17	.3944	.3601	.4115	.4458	.3601	.4458	.3944
18	.5316	.4801	.5658		.5144	.5487	.4801
19	.6859	.703	.6687		.6687	.6516	.6687
20	.6344	.6173	.6001		.6344	.583	.5487
21	.5658	.5658	.5658		.5316	.5144	.5144
22	.3944	.463	.4287		.3772	.4115	.3429
23	.2915	.3258	.3258		.3429	.2401	.2229
24	.2401	.2401	.2572	.2572	.2572	.2572	.2229
Max	.6859	.703	.6687	.5316	.6687	.6516	.6687
Min	.2058	.2058	.2058	.2058	.2401	.2229	.1715
Avg	.3694	.3758	.3815	.3544	.3830	.3637	.3325

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 203 / 11 KV CHARAN GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1543	.1543	.1543	.1543	.1543	.1715
2	.12	.1543	.1543	.1543	.1543		.1543
3	.1029	.1543	.1543	.1543	.1543	.1543	.1543
4	.1029	.1543	.1543	.1543	.1543	.1543	.1886
5	.1715	.1715	.1543	.1543	.1715	.1715	.2058
6	.2401	.2229	.2401	.2058	.2229	.2229	.2401
7	.3944	.3944	.3772	.4115	.4287	.4115	.4287
8	.463	.4458	.4458	.4458	.5487	.5144	.5144
9	.4458	.3601	.4287	.3772	.4801	.4801	.4458
10	.4115	.3429	.3772	.3772	.3944	.3772	.3601
11	.3944	.2915	.3429	.3944	.3772	.3601	.3772
12	.3601	.3258	.3601	.3601	.2915	.3429	.3429
13	.3086	.3086	.3086	.3086	.2915	.3601	.3086
14	.3086	.2401	.2743	.3086	.2572	.3086	.2915
15	.2401	.2915	.2591	.3258	.3086	.2572	
16	.2743	.2572	.2572	.2743	.2401	.2572	.3601
17	.3429	.3944	.2915	.3429	.2401	.3258	.4115
18	.3944	.4801	.4287		.3772	.4115	.4287
19	.5487	.6001	.5658		.583	.583	.6001
20	.5144	.5487	.5144		.4973	.5487	.4973
21	.4458	.4458	.4287		.4287	.4801	.463
22	.3258	.3258	.3429		.3429	.3772	.3429
23	.1886	.2058	.2058		.2229	.2058	.2229
24	.12	.1543	.1715	.1715	.1543	.1715	.1886
Max	.5487	.6001	.5658	.4458	.583	.583	.6001
Min	.1029	.1543	.1543	.1543	.1543	.1543	.1543
Avg	.3058	.3094	.308	.2820	.3115	.3317	.3347

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 204 / 11 KV MANDOOR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1372	.1372				
2	.1543	.12	.1372				
3	.1372	.12	.1543				
4	.1372	.12	.1543				
5	.1543	.12	.1543				
6	.1715	.12	.1715				
10				.2401	.2058	.12	.0686
11				.3429	.2572	.1372	.0686
12				.3086	.2915	.1715	.2915
13				.3944	.2743	.2229	.3258
14				.3772	.2401	.2401	.3429
15				.3772	.1715	.2572	
16				.3772	.1715	.2401	.2915
17				.3258	.1372	.2401	.2743
23	.1715	.1029					.1543
24	.343	.1715	.12				
Max	.343	.1715	.1715	.3944	.2915	.2572	.3429
Min	.1372	.1029	.12	.2401	.1372	.12	.0686
Avg	.1801	.1265	.1470	.3429	.2186	.2036	.2272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 401 / 33 KV WARNAWATI

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 33 / OUTGOING

UTILITY

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0823	.0772	.2726	.0874		.072	.0669
2	.0823	.0772	.2726	.0823		.072	.072
3	.0772	.1132	.2778	.0772		.072	.0669
4	.0772	.108	.2778	.0772		.072	.072
5	.0823	.1183	.2829	.0823		.072	.0772
6	.0874	.2058	.2829	.0926		.0772	.0874
7	.0926	.1492	.2881	.1029		.0823	.0772
8	.0977	.2212	.2932	.0926		.0874	.072
9	.0977	.2212	.2675	.0874	.072	.0823	
10	.0977	.2932	.2932	.0874	.072	.072	.0514
11	.0823	.2623	.2675	.0823		.072	.0669
12	.072	.2726	.2623	.072	.072	.3241	
13	.072	.2521	.2521	.072	.072	.2521	.0514
14	.072	.072	.2572	.072	.072	.2366	.0514
15	.072	.2623	.2315	.072	.072	.2521	.0514
16	.072	.2778	.2623	.072	.072	.2623	.0514
17	.072	.1646	.2572	.072	.072	.2778	.0566
18	.072	.2726	.2829		.072	.2366	.0566
19	.072	.2726	.2881		.072	.0617	.0617
20	.072	.2675	.2675		.072	.0514	.0617
21	.0823	.2675	.2675		.072	.0669	.0617
22	.0823	.2572	.1029		.072	.0514	.0566
23	.0772	.2726	.0874		.072	.0669	.0566
24	.0874	.0772	.2675	.0874		.072	.0617
Max	.0977	.2932	.2932	.1029	.072	.3241	.0874
Min	.072	.072	.0874	.072	.072	.0514	.0514
Avg	.0806	.2015	.2568	.0817	.072	.1269	.0631

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11KV CHIKHALI SUB

STATION

Feeder No / Name : 201 / 11 KV KANDE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7842	.7537	.7611	.0343	.0343	.0328	.0343
2	.7842	.8413	.7611	.0343	.0343	.0328	.0343
3	.7842	.7537	.7682	.0343	.0343	.0328	.0343
4	.7842	.7537	.7842	.0343	.0343	.0328	.0343
5	.7842	.7865	.7907	.0343	.0343	.0328	.0343
6	.8259	.852	.8223	.0343	.0343	.0328	.0343
7	.0305	.0343	.0343	.0343	.0339	.0857	.0343
8	.0305	.0343	.0351	.0343	.0335	.0328	.0343
9	.0343	.0347	.0343	1.4918	1.1469	.9831	1.17
10	.0343	.0358	.0343	1.6632	1.1797	1.1142	1.3203
11	.0343	.0358	.0343	1.5384	1.1797	1.1469	1.3203
12	.0343	.0358	.0343	1.5775	.8192	1.065	1.2717
13	.0343	.0358	.0343	1.6118	.9175	1.1469	1.2517
14	.0343	.0358	.0343	1.6095	.9511	1.0688	1.3032
15	.0343	.037	.0343	1.4575	.852	1.1142	1.2209
16	.0343	.0351	.0343	1.5089	.852	1.1012	1.094
17	.0343	.0343	.0343	.0343	.0328	.0324	.0343
18	.0343	.0339	.0343	.0343	.0328	.0324	.0343
19	.0343	.0339	.0343	.0343	.0328	.0332	.0343
20	.0343	.0343	.0343	.0343	.0328	.0343	.0343
21	.0343	.0347	.0343	.0343	.0328	.0343	.0343
22	.0343	.0343	.0343	.0343	.0328	.0343	.0343
23	.6882	.7537	.0343	.0339	.0366	.0343	.7202
24	.7748	.7537	.7611	.0343	.0343	.0328	.0343
Max	.8259	.852	.8223	1.6632	1.1797	1.1469	1.3203
Min	.0305	.0339	.0343	.0339	.0328	.0324	.0343
Avg	.2813	.2837	.2514	.5420	.3516	.3885	.4661

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11KV CHIKHALI SUB

STATION

Feeder No / Name : 202 / 11 KV NATOLI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3963	.3048	.3913	.0324	.0332	.0305	.0362
2	.3963	.3048	.3913	.0324	.0332	.0305	.0362
3	.3963	.3048	.3864	.0324	.0343	.0305	.0362
4	.3963	.3048	.4012	.0324	.0339		.0362
5	.3963	.3048	.4108	.0324	.0324	.0305	.0362
6	.4428	.3353	.4199	.0324	.0332	.0305	.0362
7	.0343	.0343	.0332		.0324	.0312	.0362
8	.0343	.0343	.0328		.0339	.0305	.0362
9	.0343	.0377	.0332		.0312	.0312	.0335
10	.0343	.037	.0343	.0339	.0312	.0343	.0343
11	.0343	.0358	.0343	.0332	.0312	.0343	.0332
12	.0343	.0351	.0343	1.1065	.6249	.6478	.7293
13	.0343	.0354	.0343	1.2431	.7186	.6802	.7956
14	.0343	.0373	.0343	1.3546	.7811	.6706	.8048
15	.0343	.0343	.0343	1.3757	.7186	.6706	.8951
16	.0343	.0347	.0343	1.4243	.6249	.7773	.8817
17	.0343	.0351	.0343	1.1934	.5624	.7773	.7293
18	.0343	.0339	.0343	.788	.5312	.5639	.5765
19	.0343	.032	.0324	.7209	.4687	.4572	.3978
20	.0343	.0316	.0343	.0332	.0305	.0343	.0332
21	.0343	.032	.0343	.0324	.0305	.0343	.0332
22	.0343	.0312	.0343	.0332	.0305	.0343	.0324
23	.2743	.3612	.0324	.0343	.0305	.0343	.2374
24		.3353	.3913	.0324	.0332	.0305	.0343
Max	.4428	.3612	.4199	1.4243	.7811	.7773	.8951
Min	.0343	.0312	.0324	.0324	.0305	.0305	.0324
Avg	.1412	.1295	.1403	.4587	.2311	.2490	.2738

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11KV CHIKHALI SUB

STATION

Feeder No / Name : 204 / 11 KV KANDE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867		.1494	.1698	.1357	.1463	.1509
2	.1867	.1463	.1494	.1698	.1029	.1463	.1509
3	.1867	.1463	.1494	.1698	.1372	.1463	.1509
4	.1867	.1463	.1509	.1698	.1372	.1463	.1509
5	.1886	.1463	.1886	.1698	.1357	.1463	.1886
6	.2263	.1829	.1886	.2263	.2401	.1829	.1886
7	.2218	.2195	.2241	.2614	.1943	.2195	.2241
8	.2218	.1646	.1848	.2587	.1715	.1829	.2218
9	.1829	.1086	.181	.1715	.1829	.1463	.1696
10	.1646	.1433	.2172	.1341	.1829	.1463	.1326
11	.1463	.1417	.1753	.1357	.1829	.128	.1372
12	.1829	.1753	.1715	.1372	.1829	.1402	.1619
13	.1829	.1086	.1715	.0972	.1829	.1402	.1715
14	.1463	.1086	.1715	.0995	.1463	.1052	.1715
15	.1463	.1402	.181	.1341	.1463	.1402	.1715
16	.1463	.1402	.1715	.1326	.1463	.1372	.1696
17	.1829	.2035	.1715	.1341	.1829	.1543	.1658
18	.2561	.208	.2058	.2058	.2195	.1928	.2058
19	.2561	.2195	.2743	.2321	.2926	.2561	.2058
20	.2561	.2195	.2561	.2058	.2561	.2614	.2401
21	.2195	.1867	.2195	.2058	.2195	.2427	.1715
22	.1829	.1494	.1867	.1715	.1829	.2241	.1715
23	.1829	.1867	.1886	.1372	.1463	.1867	.1619
24	.2054	.1829	.1867	.1698	.1372	.1463	.1494
Max	.2561	.2195	.2743	.2614	.2926	.2614	.2401
Min	.1463	.1086	.1494	.0972	.1029	.1052	.1326
Avg	.1936	.1641	.1881	.1708	.1769	.1694	.1743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11KV CHIKHALI SUB

STATION

Feeder No / Name : 205 / 11 KV NATOLI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724	.0543	.037	.0549	.0686	.0543	.056
2	.0724	.0543	.0366	.0549	.1029	.0543	.056
3	.0724	.0543	.0366	.0549	.1029	.0543	.056
4	.0724	.0543	.0732	.0549	.0972	.0543	.056
5	.0732	.0724	.1086	.0549	.1029	.0724	.0747
6	.1478	.1086	.1448	.1097	.1017	.1086	.112
7	.1463	.1448	.1448	.1463	.1006	.1463	.1478
8	.1463	.1267	.1075	.1478	.0983	.1448	.1463
9	.1267	.0347	.1075	.1357	.1086	.1448	.1029
10	.1086	.0343	.1086	.0995	.1086	.12	.1006
11	.1086	.1063	.1075	.0983	.1086	.1029	.1296
12	.1086	.1063	.1029	.0995	.0905	.1372	.1029
13	.1086	.104	.1029	.1029	.0905	.1029	.1006
14	.1086	.104	.1029	.0995		.0686	.1017
15		.1372	.1029	.1017	.0724	.1029	.1029
16	.1448	.0983	.0857	.1029	.0724	.0914	.1029
17	.181	.1341	.1029	.1017		.0914	.1075
18	.181	.2012	.1372	.1372	.1629	.1578	.1326
19	.2172	.1791	.2378	.1619	.2534	.2507	.2035
20	.2172	.181	.2172	.0972	.2172	.2378	.1943
21	.181	.1109	.1829	.1619	.181	.2195	.1326
22	.1267	.112	.1463	.1372	.1267	.1829	.0972
23	.0724	.0739	.0732	.1029	.1086	.0924	.0983
24	.0905	.0724	.037	.0549	.1029	.0724	.0924
Max	.2172	.2012	.2378	.1619	.2534	.2507	.2035
Min	.0724	.0343	.0366	.0549	.0686	.0543	.056
Avg	.1254	.1025	.1102	.1031	.1172	.1194	.1086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11KV CHIKHALI SUB

STATION

Feeder No / Name : 401 / 33 KV JYOTIRLING LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2515	.3441	.2012	.2458	.503	.2515
2	.503	.4915	.3521	.2949	.503	.503
3	.503	.4915	.503	.4915	.503	.503
4	.503	.4915	.4973	.4915	.503	.503
5	.503	.4915	.4973	.4915	.503	.503
6	.4973	.4915	.4915	.4915	.503	.503
7	.4973	.4915	.4858	.4915	.503	.503
8	.4915	.503	.4915	.4915	.503	.503
9	.503	.4973	.4915	.4858	.503	.4973
10	.503	.503		.4858	.5658	.4858
11	.503	.5087	.5596	.4858	.5658	
12	.2515	.5087	.5658	.503	.5658	.4858
13	.503	.5087	.5658	.4858	.5658	.4973
14		.5087	.5658	.4858	.503	.4973
15		.5087	.5658	.4858	.503	.4973
16		.5087	.5658	.4858	.503	.4858
Max	.503	.5087	.5658	.503	.5658	.503
Min	.2515	.3441	.2012	.2458	.503	.2515
Avg	.4625	.4905	.4933	.4621	.5187	.4813

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 201 / 11 KV WAKURDE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.0171	.0191	1.0322	.3086	.3429	
2	.0305	.0171	.0194	1.0159	.3401	.3429	
3	.0309		.0194	1.0159	.3125	.3429	
4	.0305	.0156	.0202	.9831	.3467	.6009	
5	.0305	.0156	.0221	.9945	.4163	.6009	
6	.0297	.0156	.0255	.9945	.5609	.6009	.664
7	.061	.041	.0526	.0762	.0686	.0373	.0667
8	.061	.041	.0714	.0762	.0693	.0373	.0734
9	.061	.0572	.0541	.061	.0686	.0419	.0714
10	1.1869	1.0174	1.0608	.0648	.0312	.0834	.0594
11	1.1869	1.2071	1.4251	.061	.0305	.0892	.0594
12	1.1294	1.4419	1.4582		.0343	.0629	
13	1.1294	1.4586	1.4083		.0343	.0572	
14		1.358	.8951		.0328	.0667	.0297
15	1.1934	1.1904	1.4251			.06	.0297
16	1.3094	1.2929	1.7772			.0472	.0305
17	1.1797	1.1934	1.7939	.0305	.032	.0465	.0312
18	.032	.0705		.0648	.032	.0657	.0625
19	.0343	.0846	.0305	.0625	.0396	.088	.061
20	.032	.0667	.061	.0633	.056	.0714	.061
21	.032	.0503	.061	.0309	.0312		.061
22	.0343	.0457	.0305	.0324	.0351	.0495	.0305
23	.0171	.0232	.8322	.2915	.3429	.463	.0305
24	.0297	.0171	.0191	1.0486	.3125	.3572	.6562
Max	1.3094	1.4586	1.7939	1.0486	.5609	.6009	.664
Min	.0171	.0156	.0191	.0305	.0305	.0373	.0297
Avg	.3866	.4669	.5470	.4210	.1607	.1981	.1222

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 202 / 11 KV TAKAVE AG

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1336	1.1523	1.1203	.0648	.0671	.0602	
2	1.1174	1.1523	1.1336	.0648	.0617	.0602	
3	1.1174	1.1523	1.1336	.0655	.0678	.0617	
4	1.1305	1.1797	1.1336	.0686	.0671	.0617	
5	1.1336	1.3108	1.1336	.0693	.0655	.0633	
6	1.166	1.3108	1.2289	.0724	.0648	.0671	.0724
7	.0857	.1029	.0867	.0848	.061	.0895	.0895
8	.0876	.1109	.104	.0857	.0648	.0895	.0895
9	.0876		.1063	.0848	.0926	.0663	.0895
10	.1848	.0335	.0838	1.3032	.7099		
11	.1848	.0312	.0876	1.9909	.7537	.3163	1.5424
12	.0781	.0857	.0876		.8745	.3321	.3681
13	.0781	.0526	.0857	2.2539	.8745	.4475	1.7604
14		.0995	.104	2.3312	.8745	1.3923	2.0008
15	.0594	.08	.104	2.2377		1.4582	1.8107
16	.0995	.0926	.104	2.0965		1.6575	2.1534
17	.0995	.104	.1006	1.6842		1.5581	1.9784
18	.1052	.0655	.0693	.0972	.0648	.0819	.0678
19	.1029	.0686	.0895	.0625	.0972	.0886	.1063
20	.0848		.0709	.0655	.0663	.0678	.0905
21	.0848	.096	.0838	.0663	.0648	.0686	.0895
22	.0648	.0819	.0701	.0625	.0617	.0663	.0686
23	1.0883	1.085	.0671	.0671	.0602	.0633	.8697
24	1.1336	1.1523	1.1203	.0655	.0625	.0602	.0434
Max	1.166	1.3108	1.2289	2.3312	.8745	1.6575	2.1534
Min	.0594	.0312	.0671	.0625	.0602	.0602	.0434
Avg	.4569	.4818	.3962	.6541	.2465	.3599	.7384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 203 / 11 KV PADALI AG.

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0286	.0183	.0278	.2469	.1543	.0732	
2	.0278	.0183	.0301	.25	.1619	.0812	
3	.0274	.0221	.0286	.25	.1543	.0812	
4	.0267	.0271	.029	.2591	.16	.1391	
5	.0267	.0271	.0305	.2622	.1989	.1391	
6	.0267	.0263	.0309	.2785	.2774	.1391	.1303
7	.0274	.0526	.0305	.0286	.0716	.0286	.0312
8	.0267	.0526	.0305	.0286	.0701	.0286	.0324
9	.0274	.0549	.0309	.0267	.0724	.0267	.0324
10	.4915	.3361	.3658	.0282	.0202	.0297	.0305
11	.4915	.4475	.502	.0286	.0206	.0286	.0305
12	.5312	.5121	.5121	.0343	.0206	.0297	.0286
13	.5312	.5668	.5693	.0347	.0221	.0278	.0267
14		.5898	.5376	.0297	.0221	.0305	.0267
15	.5761	.6241	.5535	.0312		.0019	.0274
16	.6081	.6009	.5761	.0648		.0019	.0267
17	.5376	.5693	.5693	.0305	.0232	.0019	.0274
18	.0232	.0305	.0286	.032	.0271	.0305	.0572
19	.0232	.0305	.0286	.0663	.0278	.032	.0594
20	.0217	.0301	.0286	.0655	.0271	.032	.0594
21	.0225	.0305	.0286	.0617	.0259	.032	.0286
22	.0175	.0293	.0286	.0312	.0236	.0309	.0267
23	.0171	.0293	.2134	.1235	.0732	.1158	.0267
24	.0286	.0183		.2469	.125	.0732	.1082
Max	.6081	.6241	.5761	.2785	.2774	.1391	.1303
Min	.0171	.0183	.0278	.0267	.0202	.0019	.0267
Avg	.1811	.1977	.2092	.1058	.0809	.0515	.043

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 204 / 11 KV PADALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0838	.104	.1029	.0924	.0526	.0701	
2	.0848	.104	.1029	.0914	.052	.0701	
3	.0848	.104	.1029	.0905	.0526	.0701	
4	.0848	.104	.1029	.0895	.052	.1227	
5	.1029	.1433	.104	.1075	.0686	.1227	
6	.1372	.1791	.1595	.1417	.0655	.1214	.1595
7	.2103	.2012	.2279	.2126		.1753	.1791
8	.2279	.2012	.2303	.208	.0838	.1753	.2303
9	.1677	.1677	.1907	.1696	.064	.1865	.1886
10	.1017	.1492	.1677	.1581	.08	.116	.1326
11	.1017	.1147	.1357	.1543	.08	.096	.0995
12	.0579	.0848	.1187	.125	.08	.112	.0625
13	.0579	.0781	.1006	.0972	.08	.0914	.061
14		.0678	.096	.08	.08	.081	.064
15	.0926	.0655	.1006	.0625		.0772	.0625
16	.0772	.0949	.104	.081		.112	.0617
17	.0869	.0995	.1357	.1235	.16	.1265	.0648
18	.156	.1823	.1928	.2103	.1966	.1865	.1658
19	.2149	.2507	.2172	.2534	.2427	.2658	.197
20	.2126	.1991	.1829	.2172	.197	.2303	.2012
21	.2103	.1991	.1829	.1907	.1629	.1829	.1829
22	.1612	.1612	.1595		.124	.1433	.1086
23	.1052	.1075	.104	.0351	.0701	.0876	.0905
24	.0838	.104	.1029	.1097	.0693	.0701	.0848
Max	.2279	.2507	.2303	.2534	.2427	.2658	.2303
Min	.0579	.0655	.096	.0351	.052	.0701	.061
Avg	.1263	.1361	.1427	.1348	.1007	.1289	.1262

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 205 / 11 KV WAKURDE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1075	.1254	.1227	.1109	.1402	.124	
2	.1075	.1254	.124	.1109	.1029	.124	
3	.1075	.1254	.124	.1109	.1387	.124	
4	.1063	.1254	.124	.1097	.1402	.1829	
5	.1075	.1772	.1254	.1294	.181	.1829	
6	.1663	.2218	.1848	.1867	.181	.1829	.1867
7	.2715	.2715	.3077	.2561	.2587	.3109	.2926
8	.2658	.2715	.3045	.2926	.2743	.3109	.3109
9	.2601	.2481	.2629	.2481	.2454	.2686	.2865
10	.218	.1753	.2035	.2149	.1696	.2279	.2103
11	.2105	.1886	.2058	.1734	.156	.208	.2058
12	.1718	.1907	.2155		.156	.1907	
13	.1823	.1715	.1543		.156	.1734	
14		.1907			.156	.1629	.2058
15	.1823	.1677	.1543			.1715	.2058
16	.2056	.2105	.2204			.1715	.218
17	.2105	.2315	.2105	.3258	.2486	.2105	.2429
18	.2774	.2883	.2804	.3506	.3467	.3294	.3086
19	.3898	.4119	.3696	.3988	.4207	.4207	.4024
20	.3045	.3658	.3174	.4108	.3721	.4024	.3696
21	.3045	.3142	.2987	.3326	.3292	.3326	.3174
22	.2172	.2195	.2218	.2195	.2012	.2587	.2218
23	.1254	.1433	.128	.1612	.124	.1463	.0943
24	.1063	.1254	.1214	.1097	.1402	.124	.1075
Max	.3898	.4119	.3696	.4108	.4207	.4207	.4024
Min	.1063	.1254	.1214	.1097	.1029	.124	.0943
Avg	.2003	.2119	.2079	.2238	.2109	.2226	.2463

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 206 / 11 KV TAKAVE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0739	.0747	.0943	.1052	.0924	
2	.0747	.0739	.0594	.0934	.1086	.0924	
3	.0747	.0739	.0747	.0934	.1075	.0924	
4	.0747	.0739	.0747	.0934	.1052	.0924	
5	.0747	.1848	.0934	.1478	.1296	.1663	
6	.168	.2218	.1698	.1867	.1886	.1663	.1509
7	.2926	.2534	.2926	.2587	.2774	.2587	.2614
8	.3258	.2534	.3258	.3045	.3077	.2587	.2772
9	.3467	.2572	.3045	.3189	.3155	.2896	.2896
10	.2012	.2515	.2713	.2427	.1989	.2401	.1772
11	.2012	.2713	.2347	.2172	.1966	.2204	.208
12	.1593	.213	.1658	.2012	.1966	.1802	.1715
13	.1593	.218	.1326	.2058	.192	.16	.1543
14		.1865	.1387	.1781	.192	.1075	.1715
15	.2347	.1802	.1715	.1875		.112	.124
16	.2241	.16	.1823	.1094		.1372	.1417
17	.1734	.218	.1966	.1966	.1791	.1715	.1928
18	.2126	.2629	.2804	.3189	.2507	.1829	.2353
19	.4207	.4024	.4207	.3681	.3658	.3361	.362
20	.3681	.3841	.4298	.3467	.3292	.3361	.2926
21	.3898	.2957	.3439	.3292	.2218	.2987	.2587
22	.2427	.2033	.2715	.2915	.1848	.2263	.1663
23	.1109	.112	.1307	.104	.0924	.112	.0924
24	.0754	.0739	.0747	.0943	.1029	.0924	.0934
Max	.4207	.4024	.4298	.3681	.3658	.3361	.362
Min	.0747	.0739	.0594	.0934	.0924	.0924	.0924
Avg	.2035	.2041	.2048	.2076	.1976	.1843	.2011

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 201 / 11 KV MANGLE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.125	.1433	.1174	.128
2	.128	.1494	.0995	.1307
3	.1475	.1463	.0995	.1097
4	.1696	.1612	.116	.1086
5	.218	.1907	.1341	.1097
6	.2294	.2058	.2012	.2126
7	.2401	.2987	.3292	.3292
8	.2507	.2804	.2865	.3189
9	.2481	.2427	.2561	.2454
10	.2686	.2374	.2481	.192
11	.2507	.2294	.2058	.2263
12		.2214	.2126	.2263
13	.2321	.2347	.2534	.2263
14	.2686	.2035	.2254	.2263
15	.2534	.208	.2172	.1886
16		.2321	.2303	.2641
17	.2915	.2591	.2561	.3395
18	.3429	.3189	.2713	
19	.4252	.4298	.3544	
20	.394	.3258	.3292	
21	.3258	.2896	.2835	
22	.2353	.2195	.2378	
23	.1581	.1715	.1612	
24		.1509	.1372	.1387
Max	.4252	.4298	.3544	.3395
Min	.125	.1433	.0995	.1086
Avg	.2477	.2313	.2193	.2067

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 203 / 11 KV MANGLE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5247	.4481	.4801	.0164	.0168	.0166	.0164
2	.4915	.426	.4801	.016	.0168	.0166	.0158
3	.4687	.4481	.4801	.0164	.0168	.0166	.0162
4	.4999	.4321	.4801	.0164	.0168	.0166	.016
5	.5121	.4641	.4481	.0164	.0168	.0166	.0164
6	.5937	.5121	.4801	.032	.0168	.0166	.016
7	.0154	.016	.016	.0324	.0168	.0166	.016
8	.0158	.016	.016	.0164	.0168	.0166	.016
9	.0158	.016	.016	.016	.0168	.0164	.0164
10	.0158	.016	.0164	.6401	.6371	.4801	.4915
11	.0158	.016	.0158	.7362	.6036	.5243	.5967
12		.016	.016	.7773	.57	.6104	.5571
13	.0158	.016	.0164	.8097	.5138	.5571	.5898
14	.0158	.016	.016	.8192	.5801	.5441	.5898
15	.0158	.016	.0164	.8288		.5079	.5898
16		.016	.016	.7625	.5801	.5121	.5571
17	.0158	.016	.0164	.7042	.5138	.6882	.5243
18	.0158	.016	.0158	.0168	.0166	.032	.0164
19	.0158	.016	.0328	.0168	.0166	.0328	.0164
20	.0158	.016	.032	.0168	.0166	.032	.0164
21	.0158	.016	.0316	.0168	.0166	.0164	.0164
22	.0158	.016	.0164	.0168	.0166	.016	.0164
23	.4902	.4481	.016	.0168	.0166	.0164	.2949
24	.5693	.4744	.4801	.016	.0168	.0166	.016
Max	.5937	.5121	.4801	.8288	.6371	.6882	.5967
Min	.0154	.016	.0158	.016	.0166	.016	.0158
Avg	.1987	.1629	.1521	.2656	.1855	.1973	.2098

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 204 / 11 KV CHIKHALWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0335	.0335	.0335	1.0814		
2	.0312	.0335	.0335	1.1191		
3	.0328	.0335	.0335	1.0242		
4	.0351	.0335	.0335	1.0364		
5	.0377	.0838	.0335	.9804		
6	.0655	.0335	.0335	1.2483		
7	.0754	.0671	.0335	.0655		.0328
8	.0762	.0671	.0335	.032		
9	.0762	.0335	.0328	.0332		
10	1.4098	1.6095	1.5043	.0332		
11	2.0008	1.643	1.7368	.0332		
12		1.3748	1.8343	.0332		
13	2.1956	1.9448	1.8679	.0332		
14	1.9334	1.8778	1.7924	.0332		
15	1.9662	1.8778	1.8679	.0663		
16		1.7772	1.6762	.0663		
17	1.6766	1.6095	1.6385	.0663		
18	.0671	.0335	.0633			
19	.0671	.0671	.0655			
20	.0671	.0671	.0671			
21	.0671	.0671	.0328			
22	.0671	.0335	.032			
23	.0339	.0335	1.0814		.6882	
24		.0335	.0335	1.0883		
Max	2.1956	1.9448	1.8679	1.2483	.6882	.0328
Min	.0312	.0335	.032	.032	.6882	.0328
Avg	.5722	.6029	.6498	.4485	.6882	.0328

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 205 / 11 KV DEOWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0351	.0351	.0381	.0377	.056	.037	.0377
2	.0362	.0358	.0381	.0373	.0373	.0362	.0373
3	.056	.0354	.0381	.0362	.0373	.0358	.0366
4	.0566	.0377	.0566	.0537	.056	.037	.056
5	.0732	.0739	.0747	.0747	.0934	.0747	.0732
6	.1267	.1307	.112	.1417	.1307	.1307	.1509
7	.1478	.168	.1463	.1463	.1478	.1294	.1595
8	.1267	.1254	.1433	.124	.128	.104	.1448
9	.1075	.0983	.124	.12	.1086	.1595	.1402
10	.1402	.1174	.1214	.1311	.0895	.128	.1214
11	.0867	.1134	.1097	.1017	.0876	.1063	.0895
12		.1107	.1086	.128	.0686	.0905	.0857
13	.0983	.1006	.0934	.0693	.0663	.0857	.0686
14	.0857	.0762	.0943	.0972	.0678	.0886	.0686
15	.0895	.0648	.1075	.0838	.0663	.0905	.0655
16		.1134	.1097	.0648	.0514	.0867	.0781
17	.1094	.1265	.124	.0995	.0791	.124	.1107
18	.1715	.1402	.1402	.12	.1267	.1448	.1402
19	.1791	.181	.181	.1772	.1663	.1612	.1991
20	.181	.1791	.1463	.1663	.1478	.2012	.1829
21	.1612	.1448	.1448	.1646	.1267	.1646	.1646
22	.1086	.1075	.1097	.1307	.1294	.1267	.0924
23	.0537	.0732	.0754	.0934	.056	.0732	.056
24		.0554	.056	.056	.0747	.056	.0554
Max	.181	.181	.181	.1772	.1663	.2012	.1991
Min	.0351	.0351	.0381	.0362	.0373	.0358	.0366
Avg	.1062	.1019	.1039	.1023	.0916	.1030	.1006

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 206 / 11 KV DHANTAKE WARANA

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.0358	.0354	.0709	.0354	.0358	.052
4	.0358	.0532	.0709	.0347	.0354	.052
5	.0358	.0532	.0709	.0693	.0358	.0532
6	.0381	.0532	.0709	.0709	.1433	.0532
7	.0381	.2149	.2303	.1417	.1433	.0709
8	.0381	.2149	.2303	.1417	.0716	.0709
9	.1478	.2303	.2303	.1417	.0709	.0716
10	.1478	.2303	.2303	.1417	.0693	.0716
11	.2402	.2303	.2303	.1417	.0709	.0716
12		.2303	.2303	.1417	.0709	.0716
13	.192	.2303	.2303	.1417	.0709	.0716
14	.048	.2303	.2303	.1417	.0709	.0716
15	.2149	.2303	.2303	.1433	.0686	.0716
16		.2303	.2303	.1433	.0709	.0716
17	.2126	.2303	.2303	.1433	.0716	.0895
18	.2126	.2303	.2303	.1433	.0716	.0716
Max	.2402	.2303	.2303	.1433	.1433	.0895
Min	.0358	.0354	.0709	.0347	.0354	.052
Avg	.1170	.1830	.1905	.1198	.0732	.0679

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 401 / 33KV INGRUL KAPARI LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4298	.4481	.7282	.3961	.6584	.679
2	.5487	.6653	.7282			.679
3	.6516	.6722	.7282	.4481	.6447	.679
4	.6584	.6722	.7282	.5658	.6379	.679
5	.7207	.6722	.7282	.6722	.6379	.679
6	.691	.6722	.7282	.6722	.6447	.7356
7	.7356	.7282	.7282	.6722	.679	.7356
8	.7356	.7282	.7282	.679	.679	.7356
9	.7356	.7282	.6722	.7356	.679	.7356
10	.7282	.7282	.6722	.7356	.7356	.7356
11	.7282	.7842	.7282	.7356	.7356	.7356
12		.7842	.7282	.7356	.7356	.7356
13		.7282	.7282	.7356	.7356	.7356
14		.7282	.7282	.7356	.7356	.7356
15		.7282	.7356	.7356	.7356	.7356
16		.1143	.1143	.1143	.1143	.1143
Max	.7356	.7842	.7356	.7356	.7356	.7356
Min	.4298	.1143	.1143	.1143	.1143	.1143
Avg	.6694	.6614	.6833	.6246	.6526	.6791

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244098 / 33/11 KV KANDUR S/STN.

Feeder No / Name : 201 / 11 KV KANDUR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3374	.2675	.2572	.0282	.0267	.0423	.0354
2	.3418	.2743	.2606	.0278	.0278	.0434	.04
3	.3418	.2675	.2641	.0278	.0286	.0429	.04
4	.3418	.2641	.2824	.0271	.029	.0423	.0429
5	.3418	.2675	.2824	.0282	.0297	.044	.0429
6	.3506	.3048	.301	.0423	.0301	.0446	.0457
7	.0417	.044	.0533	.0412	.0446	.0457	.044
8	.0417	.0423	.0434	.0417	.0457	.0474	.048
9	.04	.0423	.0423	.0417	.0423	.0446	.0423
10	.0417	.0372	.0423	.4999	.2896	.3479	.3086
11	.0423	.04	.0423	.5247	.3161		.4515
12	.0434	.0406	.0417	.8124	.3506	.4961	.4755
13	.0429	.04	.0423	.2429	.578	.4999	.4816
14	.0446	.0389	.0417	.7811	.578	.5197	.5182
15	.0457	.0377	.0434	.7562	.5487	.4666	.5053
16	.044	.0389	.044	.7407		.4877	.602
17	.0412	.04	.04	.6636		.4115	.5487
18	.0446	.0446	.0406		.044	.0354	.0423
19	.0457	.0572	.0434	.0474	.044	.0446	.0417
20	.0463	.0549	.0417	.0457	.0429	.0446	.0417
21	.0457	.0556	.0423	.0446	.0446	.0429	.0423
22	.0446	.0423	.0417	.044	.0434	.0417	.0423
23	.2972	.2143	.0423	.0394	.0423	.04	.1829
24	.3374	.2934	.2397	.0282	.0394	.0412	.0354
Max	.3506	.3048	.301	.8124	.578	.5197	.602
Min	.04	.0372	.04	.0271	.0267	.0354	.0354
Avg	.1411	.1187	.1090	.2425	.1485	.1703	.1959

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244098 / 33/11 KV KANDUR S/STN.

Feeder No / Name : 202 / 11 KV PUNVAT GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0543	.0747	.0549	.056	.0549	.0747	.0554
2	.0554	.056	.0554	.056	.0549	.0747	.0554
3	.0554	.056	.056	.056	.0549	.0747	.0554
4	.0554	.0747	.0934	.056	.0739	.0747	.0554
5	.1109	.112	.112	.1109	.112	.112	.0924
6	.1478	.168	.1494	.1646	.1494	.1478	.168
7	.1867	.1848	.1663	.2172	.2195	.2378	.1848
8	.181	.181	.2149	.197	.2149	.1991	.1991
9	.1663	.1949	.1991	.1578	.1791	.1865	.1991
10	.1417	.1715	.197	.1543	.1372	.1734	.1791
11	.1402	.1696	.197	.1526	.1357		.1417
12	.1372	.1526	.1772	.1341	.1326	.1357	.1227
13	.1017	.1509	.1772	.1174		.1357	.12
14	.1311	.1265	.1372	.116	.0972	.1341	.1417
15	.1296	.1235	.1357	.1235	.112	.1389	.1578
16	.1562	.1406	.1341	.1406	.1134	.1852	.1595
17	.1802	.1734	.1357	.1739	.1187	.1739	.1417
18	.2012	.1928	.1715	.197	.1227	.1907	.1753
19	.2804	.2507	.2481	.2926	.2328	.2534	.2481
20	.2534	.2561	.208	.2743	.2218	.2534	.1433
21	.2195	.2054	.1949	.2195	.1848	.2033	.1433
22	.1663	.1663	.1612	.181	.168	.1494	.1086
23	.0747	.0914	.128	.1086	.112	.112	.0914
24	.0543	.0747	.0543	.0747	.0724	.0747	.0739
Max	.2804	.2561	.2481	.2926	.2328	.2534	.2481
Min	.0543	.056	.0543	.056	.0549	.0747	.0554
Avg	.1409	.1478	.1483	.1472	.1337	.1520	.1339

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244098 / 33/11 KV KANDUR S/STN.

Feeder No / Name : 203 / 11 KV SAGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0754	.0739	.0747	.0566	.0754	.0566
2	.056	.0754	.0747	.0747	.0566	.0754	.0566
3	.056	.0754	.0754	.0747	.0566	.0754	.0566
4	.0566	.0754	.0943	.112	.0943	.0754	.0566
5	.0943	.0943	.1143	.1478	.1509	.0943	.1132
6	.1698	.1698	.1715	.1663	.1886	.1698	.1886
7	.2241	.1867	.2452	.2195	.2427	.2263	.2075
8	.2241	.2033	.2218	.2172	.2241	.2241	.2241
9	.1848	.1629	.2172	.2195	.2012	.181	.1991
10		.1772	.1991	.1595	.1629	.1715	.1991
11	.1254	.1753	.1791	.1543	.1387	.1753	.1791
12	.1227	.1387	.1629	.1509	.1341	.1357	.1417
13	.1052	.1372	.1543	.1372	.116	.1357	.1417
14	.1372	.1174	.1372	.1372	.1187	.1357	.124
15	.1341	.1147	.1341	.1475	.1174	.1357	.1433
16	.1326	.144	.1526	.1357	.12	.1638	.1772
17	.1372	.1715	.1543	.1696	.1227	.1677	.1595
18	.208	.2279		.2328	.2012	.197	.1772
19	.2686	.2896	.2378	.2587	.2587	.2534	.2481
20	.2561	.2743	.2303	.2587	.2614	.2218	.2507
21	.2218	.2241	.2328	.2241	.2241	.2241	.2507
22	.1867	.1867	.1612	.1867	.1867	.1886	.1629
23	.0934	.1307	.1294	.1132	.1132	.132	.1109
24	.056	.0754	.0924	.0934	.0754	.0943	.0754
Max	.2686	.2896	.2452	.2587	.2614	.2534	.2507
Min	.056	.0754	.0739	.0747	.0566	.0754	.0566
Avg	.1438	.1543	.1585	.1611	.1510	.1554	.1542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244098 / 33/11 KV KANDUR S/STN.

Feeder No / Name : 204 / 11KV DATT LIS FEEDER

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.1389	.0406			
9	.125	.1406	.1389	.088	.0724	.1524
10	.1406	.1389	.1406	.0892	.0892	.1505
11	.1406	.1406	.1406	.088	.088	.1524
12	.1406	.1406	.1389	.088	.0892	.1524
13	.1406	.1406	.1406	.088	.0914	.1505
14	.1389	.1406	.1389	.0869	.0914	.1486
15	.1406	.1406	.1372	.0869	.0892	.1467
16	.1406	.1406	.1406	.088	.088	.1524
Max	.1406	.1406	.1406	.0892	.0914	.1524
Min	.125	.1389	.0406	.0869	.0724	.1467
Avg	.1384	.1402	.1285	.0879	.0874	.1507

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244110 / 33/11 MIDC SHIRALA

Feeder No / Name : 201 / 11 KV KARMALA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7209	.8436	.8749	.1097	.0566	.0366	.0566
2	.7209	.7682	.8436	.0924	.0566	.037	.056
3	.7125	.7537	.8436	.0914	.0566	.0549	.056
4	.7682	.7773	.8539	.128	.0754	.0549	.0566
5	.8259	.8322	.8749	.1646	.0943	.0914	.0566
6	.9503	.8855	.9962	.1646	.132	.1097	.1509
7	.2926	.2926	.2218	.2743	.2075	.1848	.1886
8	.2561	.2587	.2218	.2561	.1509	.2012	.1886
9	.2195	.1848	.1829	.1829	.112	.112	.1886
10	.1829	.1478	.1646	1.1984		.1989	.1311
11	.1646	.1646	.1463	1.9662		.2591	.1658
12	.1829	.181	.1463	2.1628		.2915	.1966
13	.1829	.1848	.1463	2.2283		.2812	.213
14	.1629	.1478	.1463	2.2611		.2439	.1989
15	.1791	.1463	.1463	2.2283		.2469	.2294
16	.1791	.1448	.1478	1.9662		.216	.2294
17	.1772	.1829	.1646	1.9662		.2286	.2486
18	.2218	.1829	.2012	.1311		.1307	.128
19	.2987	.2614	.2772		.2195	.1494	.1829
20	.2772	.2801	.2561	.112	.1966	.1867	.1886
21	.2686	.2614	.2402	.1509	.1478	.1886	.1509
22	.2103	.1867	.1646	.0943	.1097	.132	.1017
23	1.0159	.8333	.128	.0747	.0732	.0754	.1357
24	.7209	.8535	.8951	.1097	.0566	.0366	.0566
Max	1.0159	.8855	.9962	2.2611	.2195	.2915	.2486
Min	.1629	.1448	.128	.0747	.0566	.0366	.056
Avg	.4122	.4065	.3869	.7876	.1164	.1562	.1482

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244110 / 33/11 MIDC SHIRALA

Feeder No / Name : 203 / 11 KV PADALIWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0663	.0671	.0503	1.3923	.9389	.7956	
2	.0663	.0671	.0503	1.3763	.8421	.7865	
3	.0497	.0503	.0503	1.3757	.8718	.7956	
4	.0497	.0335	.0503	1.3757	.8383	.779	
5	.0497	.0503	.0671	1.3592	.9054	.779	
6	.0819	.0503	.0671	1.3272	.9724	.7956	
7	.0995	.1006	.0838	.0819	.0829	.0829	.0579
8	.0995	.0838	.1006	.0983	.0995	.0829	.0724
9	.0995	.0648	.1006	.0838	.0829	.0829	.0724
10	1.9559	2.2801	2.0972	.0838		.0497	
11	2.2708	2.5484	2.3594	.0838		.0497	.0328
12	2.5149	2.5819	2.3594	.0671		.0497	.0332
13	2.5316	2.649	2.4478	.0671		.0497	.0497
14	2.3868	2.5587	2.42	.0671		.0497	.0497
15	2.3472	2.3967	2.3975	.0671		.0497	.0663
16	2.2969	2.2634	2.2801	.0671		.0663	.0663
17	2.3807	2.3137	1.9662	.0671		.0663	.0829
18	.0995	.0648	.0655	.0671		.0829	.0819
19	.1006	.0838	.0655	.0671	.0829	.0829	.0663
20	.0838	.0838	.0819	.0671	.0663	.0663	.0663
21	.0838	.0838	.0663	.0671	.0655	.0663	.0663
22	.0663	.0671	.0663	.0671	.0663	.0663	.0332
23	.0663	.0503	1.4251	1.0395	.7293		.0492
24	.0663	.0671	.0474	1.3763	.9724	.7956	
Max	2.5316	2.649	2.4478	1.3923	.9724	.7956	.0829
Min	.0497	.0335	.0474	.0671	.0655	.0497	.0328
Avg	.8297	.8609	.8653	.4913	.5078	.2857	.0592

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244110 / 33/11 MIDC SHIRALA

Feeder No / Name : 204 / 11 KV MIDC NEW

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.5281	.5093	.4904	.3772	.4527	.7545
2	.5281	.5093	.5093	.4904	.415	.4527	.7545
3	.4904	.4527	.4904	.4527	.415	.4338	.7545
4	.4904	.3772	.3772	.4527	.3395	.4338	.7545
5	.4527	.3395	.3018	.4338	.2926	.4338	.7733
6	.4527		.3206	.415	.3018	.415	.679
7	.4338	.3206	.3206	.4207	.3018	.3772	.9808
8	.6224	.3206	.3395	.4715	.3018	.415	1.1694
9	1.1317	.811	.9997	.679	1.5278	.4715	.7545
10	1.1694	1.0374	1.4901	1.4712		.6602	.7545
11	.8488	1.1317	1.2826	1.4335		.6036	.811
12	1.2071	1.1317	1.1883	1.1506		.547	.7356
13	.9997	1.1317	.9619	1.2071		.679	.5847
14	1.4146	1.094	.9997	1.2071		.7167	.5847
15	.7733	1.2449	1.094	1.2449		.7545	.8676
16	1.094	1.2637	1.1317	1.1317		.7922	.7545
17	.9619	1.2071	1.1694	.9054		.6602	.5847
18	.7922	1.2071	1.3769	.9431		.6602	.5281
19	1.0751	1.1694	1.0374	.9431	.3206	.6036	.415
20	.8488	.7167	.9431	.9054	.415	.415	.547
21	.7733	.679	.7167	.7922	.4715	.679	1.094
22	.5658	.6036	.5281	.4715	.5658	1.0185	1.1506
23	.5281	.6413	.4904	.3961	.4527	1.2071	1.2071
24	.5281	.5281	.5093	.4904	.415	.4715	.9054
Max	1.4146	1.2637	1.4901	1.4712	1.5278	1.2071	1.2071
Min	.4338	.3206	.3018	.3961	.2926	.3772	.415
Avg	.7796	.8020	.7953	.7916	.4609	.5981	.7875

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244121 / 33/11 KV BILASHI

Feeder No / Name : 201 / 11 KV MANGRUL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0164	.0166	.0164	.0995	.116	.0829	.0983
2	.0164	.0166	.0164	.0829	.116	.0829	.0983
3	.0164	.0166	.0164	.0829	.116	.0995	.0983
4	.0164	.0166	.0166	.0829	.0995	.0995	.0983
5	.0164	.0166	.0166	.0829	.0995	.1326	.0983
6	.0149	.0166	.0166	.0829	.116	.1326	.1147
7	.0149	.0166	.0166	.0166	.0166	.0166	.0164
8	.0164	.0166	.0166	.0166	.0166	.0166	.0164
9	.0164	.0166	.0166	.0164	.0166	.0164	.0164
10	.426	.4475	.4527	.0164	.0166	.0164	.0166
11	.6062	.6796	.6036	.0164	.0166	.0164	.0166
12	.7045	.6962	.6036	.0164	.0166	.0164	.0166
13	.6882	.7127	.6133	.0164	.0166	.0164	.0166
14	.6882	.7293	.5636	.0164	.0166	.0164	.0166
15	.7373	.7209	.5801	.0164	.0166	.0164	.0166
16	.6718	.6036	.5636	.0164	.0166	.0164	.0166
17	.5801	.5868	.5304	.0164	.0166		.0166
18	.0166	.0166	.0332	.0164	.0166		.0166
19	.0166	.0166	.0166	.0166	.0166	.0164	.0166
20	.0166	.0166	.0166	.0166	.0166	.0164	.0166
21	.0166	.0663	.0166	.0166	.0166	.0164	.0166
22	.0166	.0166	.0166	.0166	.0166	.0164	.0166
23	.0166	.0166	.0995	.116	.0829	.0655	.0166
24	.0164	.0166	.0164	.0995	.116	.0829	.0983
Max	.7373	.7293	.6133	.116	.116	.1326	.1147
Min	.0149	.0166	.0164	.0164	.0166	.0164	.0164
Avg	.2235	.2288	.2031	.0414	.0470	.0458	.0411

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244121 / 33/11 KV BILASHI

Feeder No / Name : 202 / 11 KV KOKARUD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.088	.1257	.0128	.0139	.0128	.0141
2	.0857	.0754	.1257	.0128	.0139	.0128	.0141
3	.0857	.0754	.1276	.0128		.0128	.0141
4	.0857	.7545	.1276	.0128	.0139	.0128	.0141
5	.0857	.0754	.1276	.0128	.0139	.0128	.0141
6	.1006	.1006	.1276	.0128	.0139	.0128	.0141
7	.0143	.0126	.0128	.0128	.0139	.0128	.0141
8	.0126	.0126	.0128	.0128	.0128	.0128	.0141
9	.0126	.0126	.0128	.0133	.0128	.0141	.0141
10	.0126	.0126	.013	.1867	.2298	.1128	.176
11	.0126	.0126	.013	.2667	.2298	.141	.2263
12	.0126	.0126	.0128	.3467	.2808	.2256	.2012
13	.0126	.0126	.0128	.3467	.2936	.2256	.2332
14	.0126	.0126	.0128	.3467	.2808	.2115	.2591
15		.0126	.0128	.3616		.2256	.285
16		.0126	.0128	.3338		.2256	.2591
17		.0126	.0128	.306			.2591
18		.0124	.0128	.0139	.0128		.013
19	.0126	.0124	.0128	.0139	.0128	.0141	.013
20	.0126	.0124	.0128	.0139	.0128	.0141	.013
21	.0126	.0124	.0128	.0139	.0128	.0141	.0128
22	.0126	.0124	.0128	.0139	.0128	.0141	.0128
23	.1006	.0867	.0128	.0139	.0128	.0141	.0894
24	.0857	.088	.1257	.0128	.0139	.0128	.0141
Max	.1006	.7545	.1276	.3616	.2936	.2256	.285
Min	.0126	.0124	.0128	.0128	.0128	.0128	.0128
Avg	.0434	.0644	.0461	.1128	.0757	.0713	.0914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244121 / 33/11 KV BILASHI

Feeder No / Name : 203 / 11 KV KOKARUD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2103	.2103	.1928	.2103	.2103	.2279	.2103
2	.1753	.1928	.1928	.1928	.2103	.1928	.2103
3	.1753	.1928	.1928	.1928	.2103	.1928	.1928
4	.2103	.1928	.2103	.1753	.1928	.1928	.1928
5	.2629	.2454	.2804	.2454	.2454	.2629	.2629
6	.4115	.3856	.4207	.4382	.4557	.4031	.3856
7	.5609	.5609	.5959	.6135	.6661	.6661	.5959
8	.631	.5959	.631	.631	.5959	.7011	.7011
9	.5609	.5258	.5609	.5609	.5784	.567	.5959
10	.4733	.4908	.5258	.4557	.4207	.5316	.4961
11	.4908	.4557	.5083	.4557	.3856	.4607	.4607
12	.4207	.4382	.4733	.4207	.4207	.4607	.4075
13	.4031	.3856	.4557	.3856	.4557	.4075	.4252
14	.3856	.3681	.4557	.3506	.4382	.3544	.3898
15	.1753	.3856	.3856	.3506		.4252	.3898
16	.2103	.4733	.4733	.4207	.4031	.4252	.4784
17	.2279	.4733	.4908	.4557	.4207		.5138
18	.2804	.5434	.5258	.5434	.5609		.6379
19	.7712	.7537	.6661	1.1218	.7362	.8063	.7011
20	.7186	.6661	.5959	1.0867	.6135	.7011	.6836
21	.5609	.5258	.5609	1.5775	.5258	.5609	.5609
22	.3856	.3856	.3856	1.262	.4207	.4382	.4207
23	.2629	.2454	.2629	.2804	.2629	.2804	.2629
24	.2103	.2103	.1928	.2103	.2103	.2279	.2279
Max	.7712	.7537	.6661	1.5775	.7362	.8063	.7011
Min	.1753	.1928	.1928	.1753	.1928	.1928	.1928
Avg	.3823	.4126	.4265	.5266	.4191	.4312	.4335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 201 / 11 KV Dafalapur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	.1696		.1867	.1886	.1581	
2	.168	.1696	.1307	.6344	.9431	.5535	.5973
3	.168	.1638		.7291	.9145	.5801	
4	.1867	.1696		.8139	1.0974	.5601	
5	.2801	.2949		.9556	1.2803	.7682	
6	.4251	.407		1.2742	1.3763	1.166	
7	.5359	.4694		1.6356	1.8351	1.5655	1.7318
8	.4481	.3768		1.9757	1.9662	1.9444	2.1026
9	.3174	.2949	.3174	1.8896	1.8515	1.8652	
10	1.7772	1.7695	1.7804	.2263	.2452	.176	.2218
11	2.4615	2.6113	2.4247	.2075	.2294	.2054	.2452
12	2.7854		2.2211	.1132	.0189		.2075
13	2.753		2.2045	.1886	.1802		.2075
14	2.4905		2.2186	.1509	.1619		.2075
15	2.6216		2.2024	.1698	.1475		.1698
16	2.6216		2.2186	.2075	.1638		.2263
17	2.5263		2.0567	.2452			.2075
18	.2915	.3142	.2801	.3206	.2591		.3584
19	.3605	.3511	.3361	.3772	.3353	.4024	.415
20	.3277		.2987	.3395	.2949		.3584
21	.2458		.2614	.2829	.2401		.3018
22	.213	.2054	.2241	.2641	.1943	.2033	.2263
23	.1802	.168	.1867	.2075	.1619	.1867	.2075
24	2.0122	.1696		.1867	.1886	.1492	
Max	2.7854	2.6113	2.4247	1.9757	1.9662	1.9444	2.1026
Min	.168	.1638	.1307	.1132	.0189	.1492	.1698
Avg	1.0986	.5065	1.2101	.5659	.6206	.6989	.4701

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 202 / 11 KV Baj AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.3121		.3361	.3395	.3239	
2	.4108	.3277	.4024	1.3413	1.6385	.6802	1.4548
3	.4108	.3239		1.861	1.6385	.6722	
4	.4481	.3201		2.0885	2.2939	.6481	
5	.5415	.4534		2.556	2.6216	1.3927	
6	.7023	.5792		2.8664	3.1459	2.6216	
7	.6908	.6062	.6805	3.5465	3.7521	2.2138	2.5434
8	.6348			3.6275	3.4408	3.3951	1.6817
9	.4294			2.6558	3.5719	3.5208	
10	2.982	2.8147	3.4873				
11	3.5391	3.1708	3.8504				
12	3.7813		3.8176				
13	3.7247		3.7193				
14	3.9352		3.9514				
15	3.6538		3.9514				
16	4.2391		3.1903				
17	3.7792		3.8056				
18	.3277	.4024	.3921	.4715	.4096		
19	.5079	.5487	.5788	.6036		.6516	.5658
20	.4915		.4854	.5658	.5197		.547
21	.4752		.4668	.5281	.3932		.4904
22	.4049	.439	.4108	.4338	.3605	.4207	.4338
23	.3605	.4207	.3734	.3584	.3113	.4207	.3772
24	.4294	.3563		.3361	.3395	.3149	
Max	4.2391	3.1708	3.9514	3.6275	3.7521	3.5208	2.5434
Min	.3277	.3121	.3734	.3361	.3113	.3149	.3772
Avg	1.5546	.7911	2.0977	1.5110	1.6518	1.3289	1.0118

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 203 / 11KV Mirwad AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.116		.168	.1698	.1372	
2	.6783	.6478	.6805	.168	.1698	.2058	.1307
3	.78	.6554		.168	.1698	.2058	
4	.9156	.6478		.1867	.2263	.2058	
5	1.073	1.3765		.2241	.2641	.2572	
6	1.4419	1.5893		.3142	.3772	.3439	
7	2.343	2.2283		.4108	.5093	.426	.4207
8	2.5911	2.9001		.3547	.415	.3481	.3881
9	2.5911	2.8807	2.9673	.2987	.3018	.2543	
10	.2587	.1802	.2587	1.8515	.6554	1.7814	2.0687
11	.1457	.1494	.1867	2.4086		3.3743	3.0476
12	.1457		.1307	3.0312			2.5396
13	.1296		.1307				2.9984
14	.1296		.1307	2.6543	2.3805		2.6216
15	.1475		.1307	2.7854	2.8664		3.2606
16	.1475		.1307	2.7035	2.9656		2.6052
17	.1296		.1307	2.6052			2.9165
18	.2429	.2587	.2427	.2452	.2458		.3018
19	.2949	.3658	.3174	.3772	.3605	.3326	.3395
20	.2458		.2987	.3395	.2591		.3018
21	.213		.2614	.2263	.1898		.2829
22	.1638		.1867	.2075	.1562	.2033	.2075
23	.1311	.168	.1867	.1886	.1341	.168	.1886
24	1.9281	.1147		.168	.1698	.0838	
Max	2.5911	2.9001	2.9673	3.0312	2.9656	3.3743	3.2606
Min	.1296	.1147	.1307	.168	.1341	.0838	.1307
Avg	.7090	.9519	.3982	.9602	.6493	.5552	1.4482

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 204 / 11 Kv Baj Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.1097		.0747	.0943	.0819	
2	.0934	.1097	.0943	.0747	.0943	.0905	.0762
3	.0934	.112		.0934	.0943	.0934	
4	.0934	.1097		.0934	.1132	.0905	
5	.112	.128		.1307	.1509	.1097	
6	.1848	.1417		.2218	.1886	.128	
7	.2614	.1463		.2801	.2263	.1646	.2587
8	.2427	.1646		.2427	.2263	.1595	.2218
9	.1867	.1463	.2241	.168	.1509	.1132	
10	.1663	.0914	.1307	.1132	.1509	.112	.1494
11	.1463	.112	.1132	.1132	.0914	.1307	.132
12	.1646		.1132	.0943	.0914		.1132
13	.1646		.0762	.0943	.0914		.1132
14	.0914		.0747	.0943	.0934		.0943
15	.0943		.0934	.0754	.0905		.0754
16	.0914		.0934	.1132	.1097		.0943
17	.128		.1494	.132	.0914		.0943
18	.1494		.1867	.2075			.2263
19	.2054	.2241	.2427	.2452	.1463	.2772	.2452
20	.1829		.2241	.2263	.1829		.2075
21	.1357		.1307	.1509	.128		.1509
22	.128	.1307	.0934	.132	.128	.1132	.1132
23	.1097	.112	.0934	.1132	.0914	.0943	.1132
24	.0934	.1097		.0934	.0943	.0924	
Max	.2614	.2241	.2427	.2801	.2263	.2772	.2587
Min	.0914	.0914	.0747	.0747	.0905	.0819	.0754
Avg	.1422	.1299	.1334	.1407	.1270	.1234	.1458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 205 / 11 KV Dafalapur GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1097		.0934	.0943	.0934	
2	.112	.1097	.0762	.0934	.0943	.0934	.0762
3	.112	.1097		.168	.0943	.0914	
4	.112	.1097		.1494	.1132	.0924	
5	.112	.1097		.1494	.1132	.0905	
6	.1307	.1307		.168	.132	.128	
7	.1307	.1296		.1494	.2075	.1698	
8	.112	.1663		.1307	.132	.1629	.1132
9	.0934	.1509	.0762	.112	.0943	.1086	.2033
10	.0934	.0914	.0943	.0943	.0754	.1463	.1132
11	.1509	.0943	.0762	.0943	.0754	.1867	.1132
12	.1646		.0762	.0754	.0732		.1132
13	.1463		.0762	.0943	.0732		.1132
14	.0914		.0747	.0943	.0732		.132
15	.0914		.112	.1132	.0732		.1132
16	.0914		.1307	.1132	.1109		.0943
17	.128		.1307	.1132	.0732		.0943
18	.1463	.168	.168	.1698	.128		.1886
19	.2012	.2033	.168	.2075	.1463	.1867	.2263
20	.1867		.168	.1886	.1147		.1886
21	.1463		.1494	.1698	.128		.1509
22	.128	.1132	.1307	.1509	.1307	.1307	.132
23	.1097	.0943	.1307	.1132	.0934	.0943	.1132
24	.1307	.1132		.112	.0943	.0914	
Max	.2012	.2033	.168	.2075	.2075	.1867	.2263
Min	.0914	.0914	.0747	.0754	.0732	.0905	.0762
Avg	.1264	.1252	.1149	.1299	.1058	.1244	.1341

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 206 / 11 KV ANKALE DORLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.3441		.4481	.3395	.2429	
2	1.5257	1.0774	1.3466	.4481	.3772	.2486	.3511
3	1.6766	1.065		.4481	.3772	.2429	
4	1.8564	1.1022		.4854	.415	.3315	
5	2.0481	1.5074		.5228	.5093	.4534	
6	2.4453	2.9635		.7865	.6224	.6133	
7	1.9109	2.6558					.6154
8	3.2712	3.5627					.4024
9	2.8502	3.5947	3.2861				
10	.499	.3978		2.7526	2.556	2.1956	2.2043
11	.3561	.3881		3.5555	3.6046	3.5227	3.7685
12				3.5063	3.9847		3.7029
13				3.6866	3.7685		3.4899
14				3.6374	3.2769		3.621
15				3.9323	3.3036		3.5227
16				3.4736	3.3913		3.1131
17				3.0148	3.2388		3.4408
18	.5087	.7682	.7282	.415	.3932		.5847
19	.6874	.8413	.8029	.6979	.5571	.6878	.6413
20	.5304		.8029	.6413	.4858		.5847
21	.5571		.6722	.5093	.3856		.4715
22	.426	.5611	.6348	.4527	.3113	.4207	.3961
23	.3725	.543	.5601	.3772	.2622	.3658	.3584
24	.2987	.373		.5228	.3395	.2458	
Max	3.2712	3.5947	3.2861	3.9323	3.9847	3.5227	3.7685
Min	.2987	.3441	.5601	.3772	.2622	.2429	.3511
Avg	1.2288	1.3591	1.1042	1.6340	1.5476	.7976	1.8393

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 201 / 11 KV Billur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1943	.1753	.1791	.1943	.2103	.2507	.1943
2	1.2955	.8764	.3898	.1943	.2149	.2149	.1943
3	1.4575	1.2094	.6733	.1943	.1943	.2591	.1943
4	1.4575	1.3717	.9465	.1943	.1943	.2591	.1943
5	1.5223	1.7177	1.4022	.2915	.2915	.3155	.2429
6	1.7004	1.8861	1.9719	.3239	.3239	.3506	.2591
7	2.1052	2.4006	2.2786	.3563	.3563	.3239	.2915
8	2.3482	2.4863	2.3211	.3239	.3239	.2949	.2429
9	2.3482	2.5139	2.0157		.2915	.2622	.1943
10	.1619	.1772	.1791			1.749	1.8138
11	.1772	.1417	.1619	2.0919		1.9433	2.2377
12	.1753		.1296	2.0576	2.2977	2.1862	2.3205
13			.1296			2.0243	2.3205
14		.1075	.0972	2.332	2.2977	1.6842	2.3205
15		.2126	.1134	2.6863		2.1376	2.1548
16	.1402	.2172		2.7286	2.3487	2.3158	2.1548
17	.1753	.1629	.2429	2.1033	2.2786	1.9433	2.1548
18	.2303	.1402	.2429	.2149		.1943	.1658
19	.2126	.2534	.2915		.2591	.2267	.2543
20	.2126	.2279	.2591	.2591		.1943	.2543
21	.2149	.1753	.2267	.2534		.2267	.2035
22	.2229	.2103	.1943	.2507	.2591	.2267	.1696
23	.1949	.2126	.1943	.2507	.2534	.1875	.1696
24	.1943	.1753	.1753	.1943	.2103	.2149	.1943
Max	2.3482	2.5139	2.3211	2.7286	2.3487	2.3158	2.3205
Min	.1402	.1075	.0972	.1943	.1943	.1875	.1658
Avg	.7972	.7751	.6442	.8748	.7415	.8327	.8707

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 202 / 11kv salmalgewadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.3856	.2629	.3239	.298	.2804	.3239
2	1.1336	1.1919	.6661	1.1012	1.166	1.0631	1.1012
3	1.2308	1.3321	1.0341	1.4251	1.5089	1.5604	1.1336
4	1.2308	1.7528	1.1789	1.4899	1.5775	1.5604	1.3603
5	1.2955	1.9281	1.3546	1.8138	1.9631	1.989	1.9757
6	1.6194	1.949	1.7147	2.1376	2.3891	2.452	2.2672
7	2.0729	2.572	2.4863	2.9473	3.3303	3.3665	2.915
8	2.332	2.6578	2.572	3.0769	2.6578	3.4027	2.753
9	2.0405	2.5415	2.3482	2.915	2.5968	2.8746	2.9473
10	2.4939	2.4539	2.5911	1.6518	2.1491	1.7166	1.6842
11	3.1725	3.155	3.0121	2.3579	2.0595	2.0081	2.1216
12	2.6642	3.5082	2.915	2.3663	2.0576	2.2348	2.1548
13	1.7528	3.1539	3.2388	2.3838		2.2348	2.1548
14	1.0517	3.0864	3.1741	2.5514	2.2386	2.1376	1.989
15	1.7528	3.4294	1.5223				1.989
16	1.4175	3.1893	1.8785		2.268	1.8138	1.989
17	2.572	3.155	2.8826	2.1262	1.9071	2.0405	2.1548
18	.3506	.3506	.3239	.333		.3887	.3315
19	.3681	.5121	.421		.3605	.421	.3978
20	.4075	.4298	.3563	.3605		.3887	.4144
21	.443	.3856	.3563	.394		.3563	.373
22	.3898	.3582	.3563	.3506	.3277	.3239	.3391
23	.3506	.3224	.3239	.3856	.3582	.3239	.2543
24	.2915	.3189	.2804	.3239	.3506	.3155	.3239
Max	3.1725	3.5082	3.2388	3.0769	3.3303	3.4027	2.9473
Min	.2915	.3189	.2629	.3239	.298	.2804	.2543
Avg	1.3636	1.8383	1.5521	1.5627	1.6613	1.5328	1.4770

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 203 / 11 KV Wajrawad ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3401	.2658	.3224	.2591	.3224	.3224	.2591
2	.3401		.2865	1.1012	1.0288	1.0517	.8907
3	.3563		.3544	1.6194	1.7147	1.7833	.9069
4	.3887		.3898	1.6194	1.7147	1.7833	1.1336
5	.421		.567	1.9433	2.1033	3.0864	1.8138
6	.5182	.3898	.6024	2.3805	2.5206	3.2922	2.3644
7	.6154	.5609	.6733	2.8016	3.0148	3.6199	2.6882
8	.5506	.394	.5028	2.8178	3.1493	3.6199	2.5263
9	.421		.3761	2.6558	3.658	3.1893	2.672
10	2.5101	2.3565	2.3838	.1943	.3239	.2915	.2105
11	2.9096	1.0631	2.834	.2591	.3239	.2915	.2035
12	1.0288	2.9973	3.1093	.2591	.3086	.2915	.2035
13	3.3665	2.8045	2.915			.3239	.1696
14	2.915	2.857	3.0769	.2591	.2915	.3239	.1696
15	3.0864	3.1361	2.915	.2591		.3239	.1696
16	2.9673	2.7435	2.915	.2591	.3506	.2429	.2543
17	3.083	3.2425	2.2672	.2591	.3887	.2591	.2543
18	.1791	.3898	.3239	.4298		.2915	.3391
19	.2715	.5014	.4372		.4588	.3563	.4239
20	.443	.5373	.4049	.3688		.3077	.4239
21	.3898	.2865	.3725	.3582		.2915	.3391
22	.3506	.4252	.2915	.3224	.3239	.2753	
23	.3155	.394	.2591	.3224	.362	.2591	
24	.3563	.2915	.3506	.2591	.3155	.3155	.2591
Max	3.3665	3.2425	3.1093	2.8178	3.658	3.6199	2.6882
Min	.1791	.2658	.2591	.1943	.2915	.2429	.1696
Avg	1.1718	1.3493	1.2054	.9549	1.1934	1.0914	.8489

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 205 / 11 kv Wajrwad Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905	.124	.0886	.1086	.1402	.1753	.1086
2	.0905	.1063	.1075	.1086	.1402	.1402	.1086
3	.0905	.1052	.1417	.1086	.1372	.1227	.1086
4	.0905	.1417	.1417	.1267	.1715	.124	.1086
5	.1086	.1753	.1772	.181	.2401	.1753	.1629
6	.2353	.2126	.2103	.2534	.2454	.2103	.2172
7	.3077	.2835	.2481	.3077	.2835	.2218	.2715
8	.2896	.2481	.2103	.2534	.2926	.2218	.1991
9	.1629	.1052	2.5415	.181	.2926	.2241	.1629
10	.1448	.1227	2.8045	.1448	.1448	.1629	.1991
11	.1227	.1075	.1267	.1227	.1075	.1629	.1294
12	.124	.0724	.0905	.124	.1052	.1448	.1294
13	.1052	.0895	.0905	.1227		.1086	.1294
14	.1227	.1063	.0905	.12	.0876	.1267	.1294
15	.1052	.1063	.1086	.1254		.1086	.1294
16	.1052	.124	.1086	.124	.0886	.1629	.1478
17	.1402	.1448	.1629	.1254	.0895	.1629	.1848
18	.1772	.2126	.2353	.1402		.2896	.2772
19	.181	.2896	.2896		.2614	.3077	.2402
20	.2195	.2149	.2534	.2926		.2715	.2772
21	.2126	.1402	.1991	.2507		.2172	.2218
22	.1753	.1063	.1267	.2454	.181	.1448	.2772
23	.1595	.1097	.1086	.2103	.1791	.1086	.1848
24	.0905	.1402	.0876	.1086	.1753	.1753	.1086
Max	.3077	.2896	2.8045	.3077	.2926	.3077	.2772
Min	.0905	.0724	.0876	.1086	.0876	.1086	.1086
Avg	.1522	.1495	.3646	.1689	.1770	.1779	.1756

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 206 / 11 kv Gugwad AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0324	.0354	.0354	.0648	.0351	.0358	
2	.1619	.124	.0886	.0648	.0351	.0358	.0324
3	.2267	.1254	.1578	.0648	.0324	.0486	.0486
4	.2267	.1772	.2103	.0648	.0324	.0486	.0648
5	.2591	.2454	.2629	.081	.0648	.0526	.0648
6	.2915	.3366	.3155	.0972	.0972	.0701	.0648
7	.3887	.3721	.3506	.0972	.0972	.0648	.0972
8	.421	.3856	.5144	.0972	.0648	.0648	.081
9	.3563	.3506	.5258	.0648	.0671	.0648	.0648
10	.0486	.0354	.0354	.3239	.2401	.2915	.421
11	.0351	.0358	.0486	.3429	.2401	.583	.6104
12	.0351	.0362	.0324	.3429	.5258	.583	.5087
13	.0354	.0362	.0162	.3429		.583	.5087
14	.0354	.0366	.0324	.3429	.5258	.6154	.5087
15	.0351	.0362	.0324	.5609		.583	.5087
16	.0354	.0362	.0324	.5487	.5258	.4858	.5087
17		.0358	.0324	.5144	.5316	.421	.5087
18		.0362	.0648	.0358		.0486	.0339
19		.0366	.081			.0648	.0509
20		.0358	.0648	.0324		.0648	.0678
21		.0362	.0648	.0351		.0648	.0509
22	.0351	.0358	.0648	.0351	.0324	.0486	.0339
23	.0354	.0354	.0648	.0358	.0358	.0486	.0339
24	.0324	.0351	.0351	.0648	.0358	.0351	.0324
Max	.421	.3856	.5258	.5609	.5316	.6154	.6104
Min	.0324	.0351	.0162	.0324	.0324	.0351	.0324
Avg	.1435	.1122	.1318	.1850	.1789	.2086	.2133

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 201 / 11 KV SHEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1492	.1658	.1638	.1848	.1658	.1658	.1781
2	.6796	.6299	.6226	.1829	.1658	.1658	.1619
3	.7459	.7209	.6554	.1829	.1658	.1658	.1619
4	.8288	.9503	.8848	.2172	.1658	.2486	.1943
5	.9069	1.1305	1.1305	.2865	.2652	.4096	.2591
6	1.2944	1.278	1.3108	.4733	.4588	.4641	.4534
7	1.6356	1.9826	1.9826	.6089	.5898	.5304	.5243
8	1.9919	2.1792	2.1628	.4163	.3277	.3978	.4096
9		2.0972	2.13	.2402	.2321	.2652	.2785
10	.1802	.1638	.2622	1.6194	1.2955	1.6057	1.4419
11	.1802	.2294	.213	1.9433	1.1336	2.13	2.1125
12	.1802	.1966	.2263	2.1125		2.1628	2.2405
13	.1638	.1966	.2075	2.2405	1.8299	2.3594	2.2672
14	.1802	.1966	.2263	2.2024	1.8461	2.2283	2.2672
15	.1619	.1966	.2075	2.1464	1.5223	2.2119	2.3045
16		.1802	.2452	2.1376		2.0972	2.2405
17	.2267	.2458	.2452	1.8023	1.587	1.9498	1.9662
18	.3401	.3734	.3547	.2652	.2622	.3077	.2683
19	.3887	.3932	.4251	.3277	.3441	.3887	.3239
20	.3725	.3605	.3658	.3239	.3353	.3239	.3277
21	.3239	.3113	.3109	.2622	.2984	.2753	.2622
22	.2652	.2458	.2772	.1966	.2458	.2458	.2458
23	.1989	.1966	.2587	.1966	.1989	.2105	.1658
24	.1638	.1658	.1638	.2218	.1823	.1638	.1781
Max	1.9919	2.1792	2.1628	2.2405	1.8461	2.3594	2.3045
Min	.1492	.1638	.1638	.1829	.1658	.1638	.1619
Avg	.5254	.6161	.6264	.8663	.6190	.8947	.8847

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 202 / 11 KV kashilingwadi AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0335	.0366	.037	.0373	.0503	.0332	.037
2	.6882	.6062	.6226	.0373	.0335		.037
3	.8192	.6882	.639	.0373	.0335	.0335	.037
4	.8097	.7537	.6882	.0373	.0335	.0332	.0554
5	.7373	.8356	.7865	.0747	.0503	.0503	.0739
6	.8097	.8684	.852	.1307	.0995	.0829	.1097
7	.9667		1.0442	.112	.116	.1174	.1294
8	1.0814		1.0774	.112	.0829	.0838	.0739
9	1.0814	1.0486	1.0978	.112	.0671	.0497	.0732
10	.0663	.0732	.0549	.9175	.7287	.8288	.8288
11	.0724	.0549	.0549	1.1469	.9231	.9945	1.0364
12	.0543	.0732	.0373	1.2146	1.0688	.8453	1.1336
13	.128	.0914	.056	1.166	1.0688	1.094	1.1142
14	.128	.0914	.0373	1.2616	1.004	1.1934	1.1336
15	.128	.0914	.056	1.2631	.9717	1.1271	1.1336
16	.128	.1097	.056	1.166	.8907	1.1142	1.1822
17	.1097	.0914	.056	1.1142	.8745	.9995	1.1142
18	.0914	.0732	.0747	.0663	.0492	.0914	.0671
19	.0914	.0914	.112	.0838	.0819	.1097	.0829
20	.0732	.0914	.0747	.0829	.0829	.0914	.0829
21	.0732	.0732	.0747	.0663	.0829	.0914	.0671
22	.0549	.0549	.056	.0503	.0671	.0549	.0503
23	.0549	.037	.056	.0503	.0497	.0554	.0503
24	.0328	.0366	.037	.0373	.0497	.0335	.037
Max	1.0814	1.0486	1.0978	1.2631	1.0688	1.1934	1.1822
Min	.0328	.0366	.037	.0373	.0335	.0332	.037
Avg	.3464	.2714	.3224	.4324	.3567	.4004	.4059

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 203 / 11 KV AWANDI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1492	.1478	.2012	.2241	.1658	.1658	.1848
2	.1658	.1478	.1829	.431	.3932	.426	.3647
3	.1844	.1478	.1829	.4641	.4696	.4858	.4475
4	.1658	.1848	.2378	.5138	.5344	.7373	.5243
5	.2515	.3326	.3841	.6133	.7935	1.0526	.5571
6	.3149	.4938	.5359	.7956	.9717	1.2289	.9667
7	.4641	.5121	.5487	1.094	1.4083	1.3603	1.3435
8	.3315	.3475	.4572	1.4586	1.4723	1.4575	1.5074
9		.2743	.2926	1.326	1.4403	1.5061	1.4419
10	1.3279	1.2308	1.2289	.2218	.1658	.2155	.2402
11	1.8351	1.6032	1.704	.1848	.1492	.2172	.1989
12	1.8515	1.7695	1.5893	.1448	.1492	.1646	.1989
13	1.7859	1.8515	1.3108	.1448	.1326	.2012	.1989
14	1.7368	1.7532	1.4746	.1829	.116	.2195	.1966
15	1.6712	1.704	1.5729	.1829	.0995	.2195	.1966
16	1.5249	1.8351		.2012	.1492	.1509	.1989
17	1.5746	1.5729		.1989	.1989	.2012	.1989
18	.2896	.3292		.1966	.2155	.2743	.2622
19	.3475	.4207	.3734	.3277	.3647	.3696	.3239
20	.3109	.3841	.3174	.2591	.3315	.3696	.3277
21	.2587	.3475	.2801	.1966	.2984	.2772	.2622
22	.2218	.2195	.2241	.1658	.2458	.2218	.2294
23	.1848	.2012	.2241	.1658	.1989	.1848	.1638
24	.1492	.1478	.2012	.2241	.1658	.1802	.1848
Max	1.8515	1.8515	1.704	1.4586	1.4723	1.5061	1.5074
Min	.1492	.1478	.1829	.1448	.0995	.1509	.1638
Avg	.7434	.7483	.6440	.4133	.4429	.4953	.4467

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 204 / 11 Kv Walekhindi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0187	.0187	.0187	.0187	.0187	.0187
2	.0187	.0187		.0187	.0187	.0187	.0187
3	.0187	.0187	.0187	.0187	.0187	.0187	.0187
4	.0187	.0187	.0187	.0187	.0187	.0187	.0187
5	.0373	.0373	.0373	.037	.0187	.0373	.0373
6	.0373	.0373	.056	.0549	.037	.0373	.056
7	.0373	.0373	.0554		.037	.0373	.056
8	.0373	.0373	.037		.0187	.0373	.0373
9	.0187	.0187	.037		.0189	.0187	.0187
10	.0187	.0187	.0185	.037	.0189	.0187	.0187
11	.0373	.0187	.0185	.037	.0187	.0373	.0187
12	.0187	.0187	.0185	.0187	.0187	.0187	.0187
13	.0187	.0187	.0185	.0187	.0187	.0189	.0189
14	.0187	.0187	.0185	.0189	.0187	.0189	.0189
15	.0187	.0189	.0185	.0189	.0187	.0189	.0189
16	.0187	.0373	.0185	.0189	.0187	.0189	.0189
17	.0187	.0373	.0185	.0187	.0187	.0189	.0189
18	.0373	.056	.0373	.037	.0189	.0373	.037
19	.0373	.056	.0373	.0549	.0377	.0377	.0549
20	.0373	.0373	.0373	.037	.0373	.056	.037
21	.0373	.0373	.0373	.037	.0373	.0373	.037
22	.0187	.0187	.0187	.0187	.0187	.0373	.037
23	.0187	.0187	.0187	.0187	.0187	.0187	.0187
24	.0187	.0187	.0187	.0187	.0187	.0187	.0187
Max	.0373	.056	.056	.0549	.0377	.056	.056
Min	.0187	.0187	.0185	.0187	.0187	.0187	.0187
Avg	.0257	.0280	.0275	.0274	.0226	.0273	.0280

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 205 / 11 KV SHEGAON GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0934	.0747	.0943	.0924	.0747	.0934
2	.0747	.0934	.0747	.0943	.0747	.0747	.0934
3	.0747	.0934	.0747	.0943	.0747	.0747	.0934
4	.0747	.1307	.112	.1132	.0747	.0747	.1307
5	.112	.168	.1494	.1509	.112	.112	.168
6	.168	.2054	.1867	.2263	.2012	.168	.2614
7	.2427	.2801	.2054	.2829	.2195	.2427	.2427
8	.1867	.2054	.1867	.2075	.181	.1867	.1867
9	.2427	.2241	.2054	.1698	.181	.168	.2614
10	.2241	.2427	.1867	.1698	.2012	.1494	.168
11	.1867	.1867	.168	.1698	.1646	.168	.1646
12	.2241	.1494	.1307	.0914	.1097	.1494	.1463
13	.1494	.1867	.112	.1097	.128	.168	.181
14	.1307	.132	.1307	.128	.128	.1494	.128
15	.168	.1509	.112	.1097	.128	.1307	.1646
16	.1307	.1698	.1307	.1086	.128	.1494	.1646
17	.1867	.2829	.2241	.1791	.0914	.2427	.181
18	.2801	.1886	.2829	.2658	.2801	.2641	.2686
19	.3361	.3018	.2829	.2896	.2427	.3361	.3258
20	.2427	.2452	.2452	.2012	.2241	.2614	.2172
21	.1867	.1698	.1698	.1829	.1867	.2054	.1663
22	.1307	.1132	.132	.1109	.1494	.1494	.1478
23	.112	.0934	.1132	.1097	.112	.112	.0924
24	.0747	.0934	.0747	.0943	.1097	.0747	.0934
Max	.3361	.3018	.2829	.2896	.2801	.3361	.3258
Min	.0747	.0934	.0747	.0914	.0747	.0747	.0924
Avg	.1673	.1750	.1569	.1564	.1498	.1619	.1725

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244058 / 33/11 KV UMRANI

Feeder No / Name : 201 / 11 KV Umrani AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1334	.1715			.168
2		.9374	.8383			.168
3		1.0155	.8383			.168
4		1.0155				.1867
5		1.0936	.9831			.2241
6		1.5813	1.3413			.2561
7		2.1822	1.6766			.2561
8		2.4806	2.0119			.1829
9		2.4966	2.2298		.1097	.1829
10		.1334	.0732		1.1469	1.4922
11		.1334			1.1469	
12	.1334	.1334	.0732		1.9662	
13	.1334	.0762	.0914	2.2775	1.1469	
14	.1334		.0914	2.2611	2.0481	
15	.1334	.0762	.0914	2.2119	2.0481	
16	.1524	.0762	.0914	2.13	2.0481	
17	.1524	.0762	.1097	1.9334	1.7695	
18	.2286	.0762	.1463	.2033	1.6385	
19	.2286	.1715	.1848		.1867	
20	.2286	.1905	.2054		.2263	
21	.2096	.2096	.2054		.1867	
22	.1715	.2096	.2033		.1867	
23	.1524	.1715	.1829			
24	1.8233	.1524	.1715			.1867
Max	1.8233	2.4966	2.2298	2.2775	2.0481	1.4922
Min	.1334	.0762	.0732	.2033	.1097	.168
Avg	.2985	.6445	.5460	1.8362	1.1325	.3156

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244058 / 33/11 KV UMRANI

Feeder No / Name : 202 / 11KV Khojanwadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2402	.2378		.2926	.2957
2		1.3283	2.1948		.2926	.2772
3		1.4232	2.0557		.2926	.2957
4		1.5023	2.2138		.3142	.2957
5		1.9204	2.5301		.3511	.3326
6		2.753	2.8464		.4854	.4251
7		3.1255			.5228	.4066
8		3.2653	3.0836		.5228	.4066
9		1.7072	3.131		.3841	.3881
10		.3761			2.982	2.625
11		.3761			3.0476	
12	.439	.4207	.4024		3.0803	
13	.439	.4207	.0366	1.7204	2.3758	
14	.4024		.0366	3.1493	3.2442	
15	.4572		.0549	3.315	3.3097	
16	.567		.4024	3.3648	3.2442	
17	.4938		.3801		3.195	
18	.5175		.4024	.3109	.4207	
19	.5359	.2378	.4024	.3292	.439	
20	.5359	.3658	.4108	.3734	.3326	
21	.462	.4024	.3921	.3547		
22	.462	.2926	.3734	.3547	.3326	
23	.2772	.2561	.3881	.3361	.3326	
24	1.9281	.2772	.2561		.3142	.1848
Max	1.9281	3.2653	3.131	3.3648	3.3097	2.625
Min	.2772	.2378	.0366	.3109	.2926	.1848
Avg	.5782	1.0890	1.0586	1.3609	1.3091	.5394

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244058 / 33/11 KV UMRANI

Feeder No / Name : 203 / 11 KV SINDUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0366	.0366		.0362	.0366
2		.037	.0366		.1898	.1677
3		.037	.0366		.1898	
4		.037	.0366		.2105	.1966
5		.037	.0366		.2458	.2294
6		.037	.0366		.2984	.3277
7		.037	.0366		.4144	.5243
8		.037	.0366		.5735	.5243
9		.037	.5487		.5898	.5407
10		.8162			.0366	.0366
11		.8162			.0366	
12	.8162		.6584		.0366	
13	.8162	.6226	.6203	.0366	.0366	
14	.8162	.5898	.6554	.0366	.0366	
15	.8002	.5898	.6554	.0366	.0366	
16	.8002	.5898	.6554	.0366	.0366	
17	.8002	.5898	.6009	.0366	.0366	
18	.037	.0366	.0549	.056	.0366	
19	.037	.0366	.0549	.056	.0366	
20	.037		.056	.0366	.0366	
21	.037		.0373	.0366	.0373	
22	.037		.037	.0366	.0373	
23	.037	.0366	.037	.0366	.0373	.2012
24	1.9281	.0366	.0366		.0366	.0366
Max	1.9281	.8162	.6584	.056	.5898	.5407
Min	.037	.0366	.0366	.0366	.0362	.0366
Avg	.5384	.2547	.2273	.0401	.1375	.2565

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244058 / 33/11 KV UMRANI

Feeder No / Name : 204 / 11 Kv Umrani Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0328	.0324		.0324	.0324
2		.0328	.0324		.0324	.0324
3		.0328	.0324		.0324	.0324
4		.0328	.0486		.0328	.0324
5		.0328	.0648		.0486	.0486
6		.0983	.1134		.0972	.0972
7		.1311	.081		.081	.1134
8		.0983	.081		.0648	.1134
9		.0655	.0648		.0486	.0648
10		.0328			.0324	.0486
11		.0328			.0324	
12	.0328	.0324	.0486		.0324	
13	.0328	.0324	.0324	.0324	.0324	
14	.0328	.0324	.0324	.0324	.0324	
15	.0492		.0324	.0324	.0324	
16	.0492		.0324	.0324	.0324	
17	.0655	.0324	.0486	.0324	.0324	
18	.1147	.0648	.0486	.0972	.0648	
19	.1311	.0972	.0972	.0972	.0972	
20	.1311	.0972	.0972	.081	.1134	
21	.0819	.0972	.081	.081	.0972	
22	.0655	.0486	.0486	.0486	.081	
23	.0328	.0486	.0486	.0486	.0648	
24	.1267	.0328	.0486		.0324	.0486
Max	.1311	.1311	.1134	.0972	.1134	.1134
Min	.0328	.0324	.0324	.0324	.0324	.0324
Avg	.0728	.0563	.0567	.0560	.0533	.0604

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 201 / 11 KV DEVANAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.253	.2896	.253	.2214	.2846	.2846	.2214
2	.253	.253	.253	1.3916	1.2176	1.2176	1.4232
3	.253	.253	.2846	1.6604	1.3441	1.3125	1.6604
4	.2846	.3321	.2846	2.0873	1.5339	1.8976	3.0836
5	.3163	.3637	.3005	2.2771	2.1664	2.3087	2.8147
6	.3637	.3795	.3637	2.5301	2.5934	2.4036	1.9134
7	.427	.3953	.3953	2.372		2.6882	
8	.3479	.3479	.3163	2.0715		2.7673	2.4669
9	.3163	2.6566	.2846	2.4827	2.7199	2.5617	2.7989
10	2.4985	2.5301	1.6604	.1898	.1898	.1265	.1581
11	2.5301	2.5301	2.0241	.1898	.1739	.1107	.1581
12		2.5301	1.3916	.1898	.1739	.1107	.1739
13			1.1069		.1898	.0791	.2214
14		2.4985	2.8147	.1265	.1898	.0949	.2214
15	2.6724	2.5301	3.0836	.2214	.1739	.0949	.2214
16	2.8622	2.372	2.8464	.253	.1581	.1581	.2214
17	3.0203	2.2138	2.6566	.2846	.2214	.253	.1898
18	.3321	.3163	.2846	.3163	.3321	.1898	.253
19	.3321	.3795	.3163	.3795	.3479	.2214	.3321
20	.3479	.3637	.2372	.3479	.3953	.2214	.3637
21	.3163	.3479	.2214	.3163	.4111	.253	.3637
22	.2846	.3163	.253	.2846	.3163	.253	.3163
23	.2214	.2846	.2214	.2846	.3005	.2214	.3163
24	.253	.253	.2846	.2214	.2846	.2846	.2214
Max	3.0203	2.6566	3.0836	2.5301	2.7199	2.7673	3.0836
Min	.2214	.253	.2214	.1265	.1581	.0791	.1581
Avg	.8803	1.0755	.9224	.9000	.7145	.8381	.8745

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 202 / 11 KV PACCHPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0579	.0434	.0579	.0579	.0579	.0724	.0434
2	.0579	.0434	.0579	.2896	.333	.3765	.2172
3	.0579	.0434	.0579	.4054	.4633	.4344	.362
4	.0579	.0434	.0579	.6081	.6081	.6661	.5502
5	.0579	.0724	.0724	.695	.8398	.7674	.7964
6	.0579	.0869	.0724	.8398	.9846	.8253	.724
7	.0579	.0869	.0724	.8109		.8398	
8	.0579	.0724	.0869	.7385	.8688	.8543	.8688
9	.0579	1.3611	.0434	.7385	.7964	.7964	.9846
10	.8109	.9846	.362	.0579	.0724	.0579	.0434
11	.9412	1.0136	.4633	.0579	.0434	.0434	.0434
12		1.0136	.695	.0579	.0434	.0434	.0579
13			.6081		.0434	.0434	.0579
14		.9122	.7529	.0579	.0434	.0434	.0579
15	1.0136	.8688	.8398	.0579	.0434	.0434	.0724
16	1.028	.8977	.9556	.0579	.0434	.0434	.0724
17	1.057	.8253	.8688	.0579	.0434	.0434	.0724
18	.0869	.0579	.0579	.0579	.0724	.0434	.0724
19	.0724	.0579	.0579	.0579	.0869	.0434	.0949
20	.0724	.0724	.0579	.0579	.0869	.0434	.0724
21	.0434	.0579	.0579	.0579	.0724	.0434	.0724
22	.0434	.0579	.0579	.0579	.0724	.0434	.0724
23	.0434	.0579	.0579	.0579	.0724	.0434	.0579
24	.0579	.0434	.0579	.0579	.0579	.0579	.0434
Max	1.057	1.3611	.9556	.8398	.9846	.8543	.9846
Min	.0434	.0434	.0434	.0579	.0434	.0434	.0434
Avg	.2758	.3815	.2721	.2606	.2543	.2630	.2396

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 203 / 11 KV Rawalgundwadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2267	.2591	.2915	.1943	.2915	.2915	.2267
2	.8907	1.247	.7907	.1943	.2753	.2591	.2267
3	1.1336	1.2146	1.1336	.2267	.3077	.3077	.2429
4	1.2955	1.3765	1.3279	.2267	.3563	.3401	.2267
5	1.5546	1.9433	1.9433	.2915	.3887	.3239	.2429
6	1.8461	2.2834	2.2834	.3239	.4049	.3725	.2753
7	2.5911	2.9312	3.0445	.2591		.3077	
8	2.7206	3.2712	3.0445	.1781	.2591	.3239	.2915
9	2.8664	.1943	3.0769	.3077	.1943	.3401	.2591
10	.1457	.1619	.2267	2.4291	2.5911	2.5911	2.4291
11	.1781	.1619	.2591	2.915	2.9797	3.0445	2.8502
12		.1619	.2915	3.0445	2.9797	3.0769	2.5484
13			.1943		2.9797	2.5587	2.834
14		.1296	.2429	1.587	.8259	2.672	2.753
15	.1296	.1296	.2429	2.8016	1.9595	2.7854	2.6558
16	.0486	.1457	.213	3.0769	2.251	2.8502	2.672
17	.0486	.1781	.2105	3.1255	2.6558	2.7206	2.8502
18	.4049	.3239	.2591	.3077	.3239	.2915	.3239
19		.421	.2591	.3887	.3563	.2267	.4049
20	.3725	.3887	.2915	.3887	.3401	.2591	.4049
21	.3401	.3563	.2591	.3563	.3401	.2915	.3725
22	.3077	.3239	.2915	.3239	.3077	.2915	.3239
23	.2915	.3239	.2429	.3239	.3401	.2591	.3239
24	.2267	.2591	.2915	.1943	.3239	.2915	.2591
Max	2.8664	3.2712	3.0769	3.1255	2.9797	3.0769	2.8502
Min	.0486	.1296	.1943	.1781	.1943	.2267	.2267
Avg	.8810	.7907	.8630	1.0202	1.0449	1.1282	1.1303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 204 / 11 kv Rawalgundwadi Gav

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0543	.0543	.0543	.0358	.0543	.0537	.0537
2	.0543	.0543	.0543	.0358	.0543	.0537	.0358
3	.0543	.0543	.0543	.0358	.0724	.0537	.0358
4	.0905	.0543	.0724	.0358	.0905	.0895	.0358
5	.1086	.1086	.1086	.0537	.1086	.1075	.0895
6	.1629	.1629	.1629	.0537	.1448	.1075	.1075
7	.1991	.1629	.1991	.0895		.1254	
8		.1267	.181	.0716	.0716	.0895	.0362
9	.0905	.1086	.0716	.1086	.0716	.0716	.0724
10	.1086	.0905	.0358	.1086	.0716	.0358	.0543
11	.0724	.0905	.0358	.0905	.0537	.0358	.0543
12		.0905	.0358	.1086	.0537	.0358	.0543
13			.0537		.0537	.0358	.0543
14		.0543	.0358	.0543	.0537	.0358	.0543
15	.0905	.0543	.0358	.0724	.0895	.0358	.0543
16	.0905	.0543	.0179	.0905	.0895	.0537	.0543
17	.0905	.0724	.0179	.1086	.1075	.0537	.1086
18	.1448	.181	.0358	.1629	.1433	.0716	.1629
19	.1629	.2353	.0537	.181	.1433	.0716	.1629
20	.1991	.181	.0537	.1448	.1254	.0895	.1448
21	.0543	.1448	.1791	.1086	.1075	.0895	.1086
22	.0543	.1086	.1791	.0724	.0537	.0895	.0905
23	.0543	.0724	.0895	.0724	.0537	.1254	.0724
24	.1743	.0543	.0543	.0537	.0543	.0537	.0716
Max	.1991	.2353	.1991	.181	.1448	.1254	.1629
Min	.0543	.0543	.0179	.0358	.0537	.0358	.0358
Avg	.1056	.1031	.0780	.0848	.0836	.0694	.0769

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 205 / 11 kv Pachhapur Amrutwadi
gav Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0181	.0185	.0185
2		.0181	.0185	.0185
3		.0181	.0185	.0185
4		.0181	.037	.0185
5		.0181	.037	.0185
6		.0362	.037	.037
7			.0554	
8		.037	.0185	.0362
9		.037	.037	.0181
10		.0185	.037	.0181
11		.0185	.0185	.0181
12		.0185	.0185	.0181
13		.0185	.0185	.0181
14	.0181	.0185	.0185	.0181
15	.0181	.0185	.0185	.0181
16	.0181		.0185	.0181
17	.0181	.0185	.0185	.0181
18	.0181	.0554	.0185	.0362
19	.0724	.0554	.0185	.0543
20	.0724	.0554	.037	.0543
21	.0724	.0185	.0554	.0543
22	.0181	.0185	.0554	.0362
23	.0187	.0185	.0554	.0181
24		.0181	.0185	.0185
Max	.0724	.0554	.0554	.0543
Min	.0181	.0181	.0185	.0181
Avg	.0345	.0259	.0293	.0261

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 201 / 11 KV Kosari AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867		.1715	.1524	.1677	.1372	
2	.2286		.1715	.4877	.5182	.3429	
3	.2058		.1715	.5639	.6859	.5144	
4	.1715		.1886	.7202	.7621	.703	
5	.1715		.2058	.8573	.9145	.823	
6	.2572		.2915	1.1145	.9602	.9431	
7	.3086		.3258	1.3717	1.0669	1.2689	
8	.3086		.2743	1.4918	1.0669	1.5604	
9	.381	.2572	.2058	1.4403	1.2346	1.5261	1.2346
10	1.3336	1.2346	.1715	.2286	.1715	.1886	.2229
11	1.9052	1.4403	1.749	.2858	.1715	.2058	.2915
12	1.9052	1.8519	1.7661	.2858	.1886	.2572	.2915
13	1.9814	1.8347	1.6804	.3239	.1715		.3086
14	1.9052	1.9547	1.5432	.3239	.1715		.3258
15	1.9052	2.1091	1.6804	.3239	.1886		.3086
16	1.9052			.2858	.2058		.3086
17	2.0005	1.5261	1.5261	.2858	.2058		.3086
18	.1905	.2572	.2572	.2058	.2229		.3258
19	.2286	.3429	.3086	.1715	.2572		.3429
20	.2058	.3258	.2915	.1715	.2229		.3258
21	.16	.2572	.2401	.1334	.1886		.2915
22	.16	.2229	.1829	.16	.1715		.2401
23	.1257	.1886	.2058	.1524	.1715		.2401
24	2.7778	.1257	.1715	.2058	.1524	.1543	
Max	2.7778	2.1091	1.7661	1.4918	1.2346	1.5604	1.2346
Min	.1257	.1257	.1715	.1334	.1524	.1372	.2229
Avg	.8712	.9286	.5992	.4893	.4266	.6635	.3578

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 202 / 11 KV Kumbharwadi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334		.1543	.1372	.1372	.1715	
2	.8383		.6001	.1543	.1219	.1543	
3	1.0288		.7202	.1372	.0857	.1543	
4	1.0288		.9431	.1715		.1715	
5	1.2003		1.0974	.2401		.2229	
6	1.5432		1.4575	.3258		.3258	
7	1.7147		1.8347	.3944		.4458	
8	1.8861		2.0405	.3258		.3429	
9	2.4196	2.332	1.8176	.2229	.2401	.2743	.1829
10	.1905	.2058	.1886	2.2862		1.406	.945
11	.2286	.2058	.2229	2.4387		1.7147	1.6309
12	.2858	.2572	.2229	2.4196	2.1948	2.2634	1.89
13	.3239	.2915	.2058	2.6482	2.3491		1.0974
14	.3048	.2743	.2058	2.6482	2.3148		2.0729
15	.2858	.2743	.2572	2.4768	2.0576		2.1186
16	.2858	.2439	.2743	2.4768	1.5089		1.4022
17	.2858	.2743	.3258	2.3243	1.6632		1.8595
18	.2572	.2743	.2743	.1715	.2743		.2439
19	.2572	.3258	.2915	.1715	.3086		.2591
20	.2915	.3086	.2915	.1715	.2915		.2591
21	.2058	.2229	.2229	.1467	.2229		.2401
22	.1334	.1886	.1886	.1467	.1886		.1829
23	.1334	.1715	.1543	.1524	.1715		.1829
24	.1524	.1029	.1543	.1543	.1524	.1715	
Max	2.4196	2.332	2.0405	2.6482	2.3491	2.2634	2.1186
Min	.1334	.1029	.1543	.1372	.0857	.1543	.1829
Avg	.6423	.3721	.5894	.9559	.8402	.6015	.9712

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 203 / 11 KV Birnal GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0533		.0686	.061	.0762	.0686	
2	.061		.0686	.061	.0762	.0686	
3	.0686		.0686	.061	.0857	.0686	
4	.0686		.0857	.0857	.0914	.0857	
5	.0686		.1029	.1029	.1067	.1029	
6	.0857		.1543	.1715	.1372	.1543	
7	.1372		.1886	.2229	.1524	.2229	
8	.1715		.1543	.1715	.1524	.2058	
9	.1905	.1543	.1543	.12	.1715	.1372	.1543
10	.1524	.1372	.1543	.1334	.1543	.1715	.1543
11	.0953	.1715	.1372	.1334	.1029	.1372	.1543
12	.0953	.1715	.12	.1334	.12	.12	.1543
13	.0953	.1543	.1029	.1143	.1029		.1543
14	.1143	.0857	.1029	.1143	.12		.1372
15	.1524	.1543	.1543	.1143	.1372		.12
16	.1524	.1543	.12	.1524	.0857		.1886
17	.1715	.1543	.1543	.2096	.12		.1886
18	.1905	.2058	.1715	.1715	.1543		.1886
19	.1715	.2572	.2229	.1715	.1715		.2229
20	.1715	.2401	.2401	.1372	.1886		.2229
21	.1372	.1543	.12	.0934	.12		.12
22	.0667	.12	.1029	.0934	.1029		.12
23	.0667	.0857	.0686	.0914	.1029		.12
24	.061		.0686	.0686	.0762	.1029	
Max	.1905	.2572	.2401	.2229	.1886	.2229	.2229
Min	.0533	.0857	.0686	.061	.0762	.0686	.12
Avg	.1166	.1600	.1286	.1246	.1212	.1266	.1600

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 204 / 11 KV Dhawadwadi GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0267		.0343	.0305	.0305	.0343	
2	.0305		.0343	.0305	.0343	.0343	
3	.0343		.0343	.0305	.0343	.0343	
4	.0343		.0343	.0343	.0305	.0343	
5	.0343		.0514	.0514	.0457	.0514	
6	.0343		.0857	.0686	.0762	.0686	
7	.0343		.1029	.1029	.0762	.1029	
8	.0343		.0857	.0857	.0457	.0686	
9	.0343	.0514	.0857	.0686	.0514	.0514	.0514
10	.0343	.0514	.0343	.0381	.0343	.0343	.0343
11	.0343	.0343	.0343	.0381	.0343	.0343	.0171
12	.0343	.0343	.0343	.0381	.0343	.0171	.0343
13	.0343	.0514	.0171	.0381	.0343		.0343
14	.0343	.0343	.0343	.0381	.0343		.0171
15	.0343	.0343	.0343	.0381	.0343		.0171
16	.0343	.0305	.0343	.0572	.0343		.0343
17	.0514	.0686	.0514	.0686	.0686		.0514
18	.0514	.0857	.0686	.0514	.0857		.1029
19	.0514	.0857	.0857	.0343	.0857		.0857
20	.0686	.0686	.0857	.0343	.0686		.0857
21	.0686	.0514	.0514	.0267	.0514		.0514
22	.0267	.0343	.0343	.0267	.0343		.0343
23	.0267	.0343	.0343	.0305	.0343		.0343
24	.0267	.0305	.0343	.0343	.0305	.0343	
Max	.0686	.0857	.1029	.1029	.0857	.1029	.1029
Min	.0267	.0305	.0171	.0267	.0305	.0171	.0171
Avg	.0379	.0488	.0507	.0457	.0468	.0462	.0457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 205 / 11 KV Hivare AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12		.1543	.1372	.1067	.12	
2	.5487		.6001	.1372		.12	
3	.6516		.6859	.1372	.12	.12	
4	.6516		.8573	.1715	.1219	.1372	
5	.6859		1.0631	.2229	.1524	.1543	
6	.6859		1.3546	.2743	.1981	.2229	
7	.8573		1.8347	.3429	.1524	.3086	
8	.9431		2.1434	.2915	.1524	.2572	
9	1.1317	2.0405	2.1434	.1886	.1715	.2401	.1829
10	.1715	.2058	.1886	2.2862	1.406	1.4575	1.6118
11	.1715	.2229	.2058	2.4577	1.8004	1.2003	2.1948
12	.2058	.1715	.2058	2.4768	2.2462	1.1317	2.0271
13	.2058	.2058	.2058	2.7625	2.2805		2.0271
14	.2058	.1886	.2058	2.4768	2.1948		2.2862
15	.1715	.1886	.2229	2.4768	2.0919		2.3472
16	.2058	.2058	.2401	2.3624	2.1262		2.2558
17	.2229	.2058	.2058	2.1262	1.9719		2.1491
18	.2401	.2572	.2229	.1029	.2058		.1829
19	.2401	.2915	.2572	.1029	.2572		.2401
20	.2401	.2743	.2401	.0857	.2229		.2229
21	.1715	.2401	.2229	.0934	.1886		.1524
22	.1334	.2229	.1715	.1067	.1372		.1219
23	.1334	.2058	.1715	.1067	.12		.1067
24	.12	.1372	.1715	.1543	.0914	.12	
Max	1.1317	2.0405	2.1434	2.7625	2.2805	1.4575	2.3472
Min	.12	.1372	.1543	.0857	.0914	.12	.1067
Avg	.3798	.3290	.5823	.9201	.8051	.4300	1.2073

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 206 / 11 KV Pratapur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0533		.0686	.0457	.061	.0514	
2	.061		.0686	.4877	.5144	.5316	
3	.0686		.0686	.5487	.6859	.6001	
4	.0514		.0857	.7202	.6859	.6859	
5	.0514		.0857	.8059	.6859	.7716	
6	.0514		.12	.8402	.7164	.9088	
7	.0857		.1372	1.166	.7621	1.166	
8	.0857		.0857	1.0974	.7621	1.3546	
9	.0857	.0686	.0514	1.0802	1.1488	1.3375	1.1431
10	.6859	1.166	.9945	.0572	.0514	.0514	.0457
11	1.0288	1.3546	1.3375	.0572	.0343	.0514	.061
12	1.2003	1.5089	1.6975	.0572	.0343	.0514	.0305
13	1.6118	1.4575	1.6975	.0572	.0343		.0305
14	1.5775	1.7147	1.8004	.0381	.1029		.0305
15	1.5432	.9431	1.6804	.0381	.0343		.0152
16	1.5432		1.5775	.0381	.0343		.0457
17	1.406	1.286	1.4575	.0572	.0514		.0457
18	.1029	.0686	.0857	.0343	.0686		.0762
19	.1372	.1029	.0857	.0267	.0857		.0914
20	.1372	.0857	.0686	.0267	.1029		.0914
21	.12	.0857	.0857	.04	.0857		.061
22	.08	.0857	.0686	.04	.0686		.0457
23	.0533	.0686	.0514	.0457	.0686		.0457
24	.0533	.061	.0686	.0514	.0305	.0686	
Max	1.6118	1.7147	1.8004	1.166	1.1488	1.3546	1.1431
Min	.0514	.061	.0514	.0267	.0305	.0514	.0152
Avg	.4948	.6705	.5637	.3107	.2879	.5869	.1240

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244114 / 33/11KV JIRGYAL

Feeder No / Name : 201 / 11 KV JIRGYAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1334	.1715	.1334	.1524	.1905	.1524
2	.0953	.1334	.1715	.7459	.7202	.9717	.6325
3	.0953	.1715	.1715	.8288	1.0279	1.2955	.9172
4	.0953	.1905	.1905	1.1934	1.1385	1.2955	1.1069
5	.1905	.2286	.2286	1.3757	1.4083	1.4575	1.3125
6	.2858	.3429	.3429	1.8099	1.7532	1.7814	1.6244
7	.2858	.4382	.4382	2.1792	2.4086	2.4291	2.536
8	.2858	.3048	.362	2.556	2.7035	2.5911	2.6023
9	.2286	.1905	.2667	2.5101	2.8837	2.5101	2.2939
10	1.1069	1.3763	1.7736	.1715	.1905	.1524	.1905
11	1.6004	2.4249	2.672	.1334	.0953	.0762	.0953
12	1.6004	2.3758	2.7854	.1143	.0953	.0953	.1143
13			2.7199	.1143	.0953	.0762	.1143
14		2.7526	2.834	.0953	.0953	.1143	.1334
15	2.4291	2.6406	2.6216	.0953	.0953	.1143	.0953
16	2.5911	2.9607	.5735	.1334	.0953	.0953	.1143
17	2.6882	2.6406	1.989	.1334	.1524	.1334	.1524
18	.2667	.3239	.1905	.2096	.2858	.2096	.2286
19	.3048	.381	.2858	.3429	.3429	.3429	.3429
20	.2667	.3048	.2286	.2477	.2858	.2858	.2477
21	.1905	.1905	.1715	.1905	.1905	.2286	.1905
22	.1524	.1715	.1524	.1524	.1905	.1524	.1715
23	.1524	.1715	.1334	.1524	.1905	.1524	.1524
24	.0953	.1334	.1524	.1334			.1524
Max	2.6882	2.9607	2.834	2.556	2.8837	2.5911	2.6023
Min	.0953	.1334	.1334	.0953	.0953	.0762	.0953
Avg	.6865	.9123	.9011	.6563	.7216	.7283	.6531

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244114 / 33/11KV JIRGYAL

Feeder No / Name : 202 / 11 KV SHINGANAPUR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2286	.2858	.2858	.2667	.2477	.2858
2	.4049	.3856	.3658	.3048	.2667	.2286	.2858
3	.4858	.5735	.4572	.3048	.2477	.1905	.2858
4	.4858	.7209	.5335	.3048	.2477	.1905	.3429
5	.6478	.8383	.7316	.3239	.3429	.2858	.381
6	.8097	.9724	1.065	.4001	.4572	.381	.4763
7	1.4575	1.6263	1.6385	.4954	.5335	.4763	.5144
8	1.6194	1.5746	1.8679	.4572	.4954	.4763	.4382
9	1.6575	1.4918	1.7204	.4001	.4191	.3239	.3429
10	.381	.2667	.2286	1.1105	1.1469	.9339	.9945
11	.362	.362	.3429	1.6244	1.3927	1.3435	1.4255
12	.4763	.4191	.381	1.7404	1.3927	1.4746	1.5565
13		.362	.4001	1.5893		1.5402	1.4089
14	.0953	.4001	.381	1.6385	1.6385	1.358	1.6385
15	.4001	.4001	.362	1.4586	1.7204	1.3735	1.2431
16	.362	.362	.3429	1.065	1.4746	1.4043	1.21
17	.4001	.362	.4572	1.2289	1.3927	1.2963	1.2431
18	.362	.4763	.4001	.2477	.2858	.3239	.3048
19	.4382	.4954	.4382	.4382		.4001	.381
20	.4191	.4572	.381	.4382	.381	.4191	.4001
21	.362	.4382	.3429	.362	.3239	.381	.3429
22	.2667	.4001	.3048	.2858	.2858	.3239	.3048
23	.2858	.3239	.3239	.2286	.2858	.3048	.2096
24	.2858	.2286	.2858	.2858	.2858		.2858
Max	1.6575	1.6263	1.8679	1.7404	1.7204	1.5402	1.6385
Min	.0953	.2286	.2286	.2286	.2477	.1905	.2096
Avg	.5544	.5902	.5849	.7091	.6947	.6816	.6793

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244114 / 33/11KV JIRGYAL

Feeder No / Name : 203 / 11 KV JIRGYAL GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0953	.0762	.0953	.0572	.0572	.0572
2	.0762	.0762	.0572	.0953	.0572	.0572	.0572
3	.0762	.0762	.0572	.0953	.0572	.0572	.0572
4	.0762	.0762	.0572	.0953	.0572	.0572	.0572
5	.1143	.0953	.0762	.0953	.0762	.0572	.0762
6	.1334	.1143	.1143	.1334	.1143	.0953	.0953
7	.1524	.1524	.1334	.1524	.1143	.1334	.1143
8	.1524	.0953	.0762	.0572	.0762	.0762	.0572
9	.0953	.0762	.0381	.0572	.0381	.0572	.0572
10	.0953	.0762	.0572	.0572	.0572	.0381	.0381
11	.1334	.1334	.0762	.0572	.0572	.0381	.0572
12	.0953	.0953	.0953	.0762	.0762	.0762	.0572
13		.0762	.0762	.0762	.0762	.0572	.0572
14	.0381	.0762	.0572	.0381	.0572	.0572	.0572
15	.0381	.0381	.0572	.0381	.0381	.0381	.0381
16	.0762	.0572	.0762	.0381	.0381	.0381	.0191
17	.0762	.0762	.0572	.0381	.0572	.0381	.0572
18	.1524	.0953	.0953	.0953	.0762	.0762	.1143
19	.1715	.1334	.1334	.1524	.1524	.1334	.1334
20	.1524	.1143	.1524	.1334	.1524	.1334	.1143
21	.1715	.4382	.1334	.1334	.1143	.1143	.1334
22	.1334	.0572	.1143	.0953	.0762	.0762	.0953
23	.1143	.0762	.0953	.0572	.0572	.0762	.0762
24	.0762	.0953	.0762	.0953	.0572	.0572	.0762
Max	.1715	.4382	.1524	.1524	.1524	.1334	.1334
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0191
Avg	.1077	.1040	.0850	.0858	.0746	.0707	.0731

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244114 / 33/11KV JIRGYAL

Feeder No / Name : 204 / 11 KV EKUNDI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.362	.3429	.3429	.3048	.2858	.3239
2	.6478	.6299	.5344	.362	.2858	.2858	.3239
3	.6478	.5735	.5668	.362	.3239	.2858	.3239
4	.6478	1.0159	.5668	.362	.3239	.2858	.3239
5	.8907	1.065	.8097	.381	.381	.2858	.4191
6	1.1336	1.1603	1.2029	.4572	.4763	.381	.4954
7	1.3765	1.4586	1.2654		.5335	.5716	.5525
8	1.0526	1.6575	1.4842	.5335	.4572	.5716	.5335
9	1.326	1.6575	1.4723	.4382	.4001	.4191	.4954
10	.4763	.4001	.4001	1.1142	1.0526	.7499	1.0277
11	.5335	.3429	.4191	1.5074	1.4575	1.0936	1.2431
12	.4954	.3048	.4572	1.6057	1.4575	1.2498	1.2071
13		.3239	.4382	1.6385	1.2955	1.2811	1.4089
14	.2477	.3239	.4382	1.4091	1.1336	1.3757	1.2431
15	.4191	.3048	.4382	1.1961	1.2146	1.1934	1.2431
16	.4954	.3048	.3429	1.3765	1.2146	1.0822	1.3599
17	.4763	.4001	.4191	1.3108	1.1336	1.2597	1.3927
18	.4954	.4572	.4954	.362	.2858	.2858	.3048
19	.5525	.5144	.5144	.5144	.4191	.4382	.5144
20	.4763	.4191	.4382	.4572	.381	.381	.4001
21	.362	.4001	.3429	.381	.2858	.3429	.362
22	.381	.4001	.3239	.3239	.2858	.3239	.3048
23	.3429	.381	.3048	.2858	.2858	.3239	.2667
24	.2858	.381	.362	.3239	.3239	.2858	.3239
Max	1.3765	1.6575	1.4842	1.6385	1.4575	1.3757	1.4089
Min	.2477	.3048	.3048	.2858	.2858	.2858	.2667
Avg	.6108	.6349	.5992	.7411	.6547	.6266	.6831

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244131 / 33/11 KV WALEKHINDI

Feeder No / Name : 201 / 11KV WALEKHINDI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-DEC-17
HR	Load (MW)
24	1.9559
Max	1.9559
Min	1.9559
Avg	1.9559

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244131 / 33/11 KV WALEKHINDI

Feeder No / Name : 202 / 11KV BEVNOOR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	1.8442
Max	1.8442
Min	1.8442
Avg	1.8442

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244132 / 33/11 KV BASARGI

Feeder No / Name : 201 / Basargi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17
HR	Load (MW)
24	1.8233
Max	1.8233
Min	1.8233
Avg	1.8233

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244132 / 33/11 KV BASARGI

Feeder No / Name : 202 / Basargi Gavtaon

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	.1448
Max	.1448
Min	.1448
Avg	.1448

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 202 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17
HR	Load (MW)
24	.543
Max	.543
Min	.543
Avg	.543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 203 / 11 KV MALLAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17
HR	Load (MW)
24	1.4575
Max	1.4575
Min	1.4575
Avg	1.4575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 204 / 11 KV Jath

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 205 / 11 KV Rampur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17
HR	Load (MW)
24	1.4575
Max	1.4575
Min	1.4575
Avg	1.4575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 206 / 11 KV Achakanhalli AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17
HR	Load (MW)
24	1.3904
Max	1.3904
Min	1.3904
Avg	1.3904

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 207 / 11 KV SUGAR FACTORY

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17
HR	Load (MW)
24	.0905
Max	.0905
Min	.0905
Avg	.0905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 208 / 11 kv Achakanhallii Gav
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-DEC-17
HR	Load (MW)
24	.1267
Max	.1267
Min	.1267
Avg	.1267

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 201 / 11kv k mahankal

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7499	.695	.5487	.695	.6401	.695	.7682
2	.7133	.6401	.5487	.695	.695	.6401	.7316
3	.7133	.6036	.6401	.695	.7316	.6219	.7316
4	.695	.6219	.7316	.7316	.7682	.7133	.8048
5	.7682	.7682	.7865	.7682	.823	.7682	.8413
6	.9328	.9511	.8596	.8779	.8596	1.0425	1.0242
7	1.0608	1.0974	.9328	1.134	1.0974	1.262	1.2803
8	1.1706	.9877	.9328	.9694	.9877	1.1706	1.1523
9	1.0791	.9877	.9145	.9877	.9511	1.0608	1.0608
10	.9145	.9328	.8779	.9145	.8962	.9511	1.0059
11	.823	.9145	.8413	.8596	.8962	.8779	1.0059
12	.9877	.9511	.8048	.7865	.823	.8048	.9328
13	.9145		.7133	.7316	1.0059	.8596	.9145
14	.823	.8962	.7865	.6584	.8048	.8962	.8413
15	.823	.8962	.8962	.6584	.7682	.8596	.823
16	.8779	.9511	.9694	.7499	.8962	.8962	.7682
17	.9328	1.0425	1.0608	.8413	.9145	.8962	.7865
18	1.2437	1.3535	1.1888	1.0974	1.2254		1.3717
19	1.4449	1.3535	1.0791	1.3352	1.262	1.3717	1.3535
20	1.2803	1.2803	1.1157	1.1706	1.3169	1.2437	1.1888
21	.9328	1.0425	.9145	1.0059	.9877	1.0425	1.0974
22	.8596	.9145	.823	.8413	.8413	.9328	.9145
23	.823	.695	.7316	.6584	.7865	.8413	.7316
24	.7499	.7316	.6584	.7316	.6584	.7316	.7682
Max	1.4449	1.3535	1.1888	1.3352	1.3169	1.3717	1.3717
Min	.695	.6036	.5487	.6584	.6401	.6219	.7316
Avg	.9297	.9264	.8482	.8581	.9015	.9209	.9541

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 202 / 11KV KUCHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1646	.128	.1097	.1646	.1097	.128	.128
2	.7865	.128	.1097	.1463	1.0974	.9511	1.0608
3	1.0242	.1097	.128	.1463	1.1888	1.0608	1.1706
4	1.134	.1097	.128	.1646	1.2803	1.0974	1.2071
5		.1463	.1463	.1463	1.39	1.1888	1.3169
6	1.1888	.1646	.1646	.1646	1.6095	1.2986	1.3535
7	1.4083	.2561	.2743	.2195	2.2314	1.7558	1.9022
8	1.7375	.2378	.2743	.2378	2.3777	1.8473	1.7558
9	1.7924	.2012	.2743	.2012	2.2862	1.9204	1.829
10	2.1582	1.8656	2.2497	.1463	.128	.128	.1463
11	2.3594		2.4143	.1463	.2195	.1463	.1646
12	2.1216	2.5057	2.396	.1463	.3292	.128	.1463
13	1.9022	2.3777	2.5057	.128	.2012	.1646	.1646
14	1.9753	2.4143	2.5423	.1463	.1646	.2012	.1646
15	2.1033	2.3411	2.4508	.1829	.1646	.1829	.1463
16	2.1765	2.4508	2.5057	.2012	.1829	.1829	.1646
17	1.957	2.3594	2.4326	.2012	.1829	.2012	.2012
18	.1829	.2012	.2012	.2378	.2378	.2012	.2012
19	.2195	.2378	.2378		.2378	.2195	.2195
20	.2195	.2195	.2195	.2195	.2743	.2195	.2378
21	.2378	.1829	.1829	.1829	.2012	.1829	.1829
22	.1646	.1463	.1646	.1646	.1829	.1646	.1646
23		.128	.1646	.128	.1463	.1463	.1097
24	.1646	.1463	.1097	.1646	.1097	.128	.128
Max	2.3594	2.5057	2.5423	.2378	2.3777	1.9204	1.9022
Min	.1646	.1097	.1097	.128	.1097	.128	.1097
Avg	1.2354	.8286	.9328	.1734	.6889	.5769	.5944

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 203 / 11 KV HINGANGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024	.3841	.4298	.4207	.3841	.3841	.4207
2	.4024	1.5364	1.5912	1.5546	.3841	.3658	.4024
3	.4024	1.5546	1.7375	1.6827	.4207	.3658	.4024
4	.3841	1.6095	1.829	1.829	.439	.3841	.3841
5	.4207	2.0485	2.1033	1.9022	.439	.4207	.439
6	.4755	2.5606	2.3777	1.8656	.4755	.4572	.4755
7	.4938	2.9264	3.4751	2.524	.4938	.4938	.4938
8	.4755	3.4568	3.2922	2.5423	.4572	.4755	.4755
9	.4755	2.8166	2.4326	2.7252	.439	.4572	.439
10	.4938	.439	.439	2.9995	2.6337	2.3228	2.3777
11	.5121	.4207	.439	3.0727	2.8715	2.7069	2.7252
12	.5304	.439	.4207	2.8532	2.3228	3.0178	2.6886
13	.4938	.4572	.4755	2.4143	2.6703	2.9995	2.4874
14	.4755	.4572	.4572	2.9995	2.8349	2.9264	2.2862
15	.4572	.4755	.439	2.7435	2.652	2.8898	2.268
16	.4207	.4572	.439	2.7435	2.6886	2.8166	2.3228
17	.4572	.4938	.4572	2.2862	2.7435	2.652	.4207
18	.4207	.5487	.4572	.4207	.4207	.4207	
19	.4755	.5487	.5121	.4755	.439	.4572	.4572
20	.4938	.5304	.4572	.4755	.439	.4755	.4755
21	.4572	.4755	.4207	.4755	.439	.4572	
22	.439	.4572	.439	.4572	.439	.439	
23	.4207	.439	.4207	.4024	.4024	.439	.439
24	.4024	.4024	.4207	.4207	.4024	.3841	.4207
Max	.5304	3.4568	3.4751	3.0727	2.8715	3.0178	2.7252
Min	.3841	.3841	.4207	.4024	.3841	.3658	.3841
Avg	.4534	1.0806	1.0818	1.7619	1.1805	1.2170	1.1096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 204 / 11KV Ranjani Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.2743	.2195	.2195	.2378	.2561	.2378
2	1.8656	.2743	.2195	.2012	1.6461	1.1888	1.9204
3	2.6155	.2561	.2743	.2012	1.7924	1.2437	2.2314
4	2.7069	.2378	.3292	.2012	2.0119	1.3717	2.3045
5	2.7984	.3292	.439	.2926	2.4691	2.1582	2.3411
6	2.8349	.4572	.439	.4207	2.8349	2.5972	2.3777
7	2.3228	.5487	.5304	.5487	3.6214	3.1276	3.2922
8	3.4202	.5121	.6036	.439	3.5117	3.1093	3.0361
9	3.6397	.4024	.439	.3658	3.4751	3.4751	3.219
10	3.6214	2.6155	3.5113	.4207	.3841	.3292	.2926
11	3.658		3.6199	.4938	.439	.3109	.3109
12	3.658	3.4934	3.6199	.3292	.4024	.3109	.2926
13	3.6214	3.2739	3.658	.3841	.3475	.3292	.2926
14	3.6397	3.6397	3.0361	.3475	.3658	.3109	.3109
15	3.6214	3.4751	2.3594	.439	.3109	.2926	.3292
16	3.4751	3.1459	3.5665	.439	.3292	.2926	.3658
17	2.9813	2.9264	3.3836	.4024	.2926	.2561	.3841
18	.4207	.4755	.4572	.4572	.4572	.3658	.4938
19	.4572	.4755	.4572	.5121	.4572	.4207	.4755
20	.4755	.4207	.4024	.4207	.4207	.3841	
21	.4024	.3475	.3658	.4024	.3841	.3292	.4024
22	.3658	.2743	.3292	.3658	.3292	.2926	.3475
23		.2561	.2743	.3475	.3109	.2561	.3109
24	.2743	.2743	.2195	.2195	.2743	.2926	.2561
Max	3.658	3.6397	3.658	.5487	3.6214	3.4751	3.2922
Min	.2561	.2378	.2195	.2012	.2378	.2561	.2378
Avg	2.3101	1.2342	1.3647	.3696	1.1294	.9709	1.1228

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 205 / 11KV Langerpeth Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012	.2195	.1646	.1646	.1829	.1463	.1829
2	.2012	2.7069	2.0851	2.4143	.1829	.1463	.1829
3	.1829	2.8715	2.1582	2.5972	.2195	.128	.2012
4	.1829	3.091	2.2314	2.4143	.2378	.1463	.2012
5	.2561	3.6214	2.3045		.2378	.2195	.2561
6	.3475	.5853	2.3777	2.6155	.2743	.3841	.3292
7	.4024	.6584	3.658	3.2739	.3475	.4024	.3841
8	.4024		3.658	3.1824	.3292	.3109	.2743
9	.3109		3.5848	3.4202	.2743	.2561	.2378
10	.2743		.1097	3.5665	3.3471	3.3288	3.6214
11	.2195		.1463	3.4751	2.9264	3.6214	3.2922
12	.2378	.2195	.1646	3.5848	3.658	3.2739	3.2922
13	.2561	.2561	.1463	3.3836	3.6031	3.658	
14	.2195	.2926	.1646	3.2373	3.2373	3.658	
15	.2195	.2743	.1829	3.1642	3.6031	3.6031	3.658
16	.2561	.2012	.2012	3.5117	3.219	3.5665	3.658
17	.3475	1.957	.2012	2.9264	3.2922	3.658	3.658
18	.1829	.2012	.3109	.2926	.2926	.2012	.3109
19	.3475	.2195	.3109	.2195	.3109	.2743	.3475
20	.2743	.2195	.2926	.2561	.2743	.2926	.3109
21	.2743	.2012	.2561	.2012	.2378	.2561	.2743
22	.2378	.1829	.2195	.2012	.2012	.2195	.2561
23		.1646	.2012	.1829	.1646	.2195	.2378
24	.2012	.1829	.1463	.1829	.1646	.1646	.1829
Max	.4024	3.6214	3.658	3.5848	3.658	3.658	3.658
Min	.1829	.1646	.1097	.1646	.1646	.128	.1829
Avg	.2624	.9163	1.0532	2.1073	1.2841	1.3390	1.1523

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 206 / 11KV S.Factory Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1646	.128	.1463	.1463	.1494	.128	.1867
2	1.8839	.1646	.1463	.1646	1.4937	1.2803	2.0165
3	2.0119	.1646	.1829	.1646	1.643	1.363	2.0911
4	2.0485	.1829	.2378	.1646	1.7737	1.4563	2.1285
5	2.0668	.2195	.2743	.2378	2.0538	1.7741	2.1472
6	2.0668	.3292	.3292	.2743	2.2779	2.3525	2.2218
7	2.3411	.3658	.3109	.3109	2.7446	2.7069	2.894
8	2.524	.2012	.2561	.2561	3.1367	2.9127	3.1181
9	2.8532	.2012	.2012	.2195	2.9874	2.8349	2.9687
10	5.999	2.7069	2.9813	.2012	.1307	.168	.2241
11	6.3284	3.1642	3.3105	.2012	.168	.1663	.2427
12	5.6698		3.1459		.1867	.2054	.2241
13	3.1276	2.9995	3.0178		.1867	.1867	.1867
14	6.182	2.9813	2.9813		.168	.2054	.1867
15	6.2918	2.7069	2.9447	.1307	.2987	.2241	.2054
16	6.1088	2.9447	2.963	.1867	.112	.2427	.1867
17	5.8162	2.6337	2.9081	.1494	.112	.2241	.2427
18	.5122	.2743	.2195	.2801	.2561	.2427	.2987
19	.2926	.2926	.2561	.3361	.2987	.2801	.3361
20	.2926	.2743	.2195	.2801	.056	.2801	
21	.2561	.2561	.2195	.2427	.2427	.2427	1.0974
22	.1829	.2012	.1829	.168	.1867	.1867	.9145
23	.1646	.1646	.1463	.168	.168	.1867	.1867
24	.1463	.1463	.1463	.1463	.1494	.1494	.1867
Max	6.3284	3.1642	3.3105	.3361	3.1367	2.9127	3.1181
Min	.1463	.128	.1463	.1307	.056	.128	.1867
Avg	2.7222	1.0306	1.1553	.2109	.8742	.8333	1.0649

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 207 / 11 KV Express MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.0549	.0914	.0732	.0549	.0366	.0914
2	.0732	.0366	.0732	.0549	.0366	.0183	.0549
3	.0549	.0366	.0366	.0549	.0366	.0183	.0549
4	.0549	.0366	.0366	.0366	.0366	.0183	.0732
5	.0549	.0366	.0366	.0366	.0366	.0183	.0549
6	.0549	.0366	.0366	.0366	.0366	.0183	.0732
7	.0732	.0914	.0549	.0549	.0183	.0183	.0914
8	.1097	.0549	.0366	.0914	.0183	.0366	.0914
9	.1097	.0732	.0366	.1097	.0549	.0549	.1097
10	.1463	.1097	.128	.0732	.0732	.0549	.0914
11	.128	.1829	.128	.2195	.0716	.128	.1097
12	.128	.1646	.128	.1463	.1097	.2012	.1097
13	.128	.1463	.128	.1463	.0914	.1829	.128
14	.2012	.1829	.128	.1463	.0366	.1646	.128
15	.1829	.1646	.1463	.128		.1463	.1463
16	.128	.1646	.1646	.1097	.0732	.1463	.0732
17	.0549	.1448	.1829	.0914	.0732	.0914	.0914
18	.0914	.1463	.0914	.128	.0366	.0914	.0732
19	.0732	.0914	.0732	.0914	.0366	.1097	.1097
20	.0732	.128	.0732	.0914	.0566	.128	
21	.1097	.1463	.0914	.1463	.0732	.1463	.1097
22	.1097	.1463	.0732	.1097	.0914	.1463	.128
23	.0914	.1646	.128	.1097	.0732	.1097	.128
24	.0732	.0732	.128	.0914	.0732	.0549	.0914
Max	.2012	.1829	.1829	.2195	.1097	.2012	.1463
Min	.0549	.0366	.0366	.0366	.0183	.0183	.0549
Avg	.0991	.1089	.0930	.0991	.0565	.0892	.0962

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 208 / 11KV Langerpeth Gao

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926	.3109	.3292	.3109	.2195	.2378	.2561
2	.2926	.3109	.3292	.2743	.2378	.2378	.2561
3	.2743	.2926	.3658	.2743	.2743	.2195	.2561
4	.2743	.3292	.4207	.2743	.2926	.2561	.2743
5	.3292	.3841	.4572	.3109	.3292	.2926	.3109
6	.3658	.4938	.4938	.4207	.3658	.3658	.4207
7	.5121	.5853	.6584	.6036	.5121	.3658	.5121
8	.5853	.6401	.5853	.4572	.2743	.439	.3658
9	.5304	.5121	.439	.4024	.4755	.4207	.3658
10	.5121	.4938	.4755	.3292	.4024	.3292	.4024
11	.4755		.4207	.2926	.3841	.2926	.3292
12	.4024	.5121	.3841	.2561	.3292	.2012	.3109
13	.3109	.3475	.3475	.2378	.2561	.2328	.1646
14	.3292	.3292	.3109	.2012	.2743	.2561	.1097
15	.3109	.3109	.2561	.2378	.2561	.2561	.2012
16	.3658	.2561	.3658	.2561	.2743	.2195	.1829
17	.3841	.3658	.4024	.3841	.2561	.2378	.2743
18	.3475	.5487	.5121	.439	.4572	.3109	.4755
19	.6584	.7499	.567	.5487	.5121	.4207	.5853
20	.5487	.5853	.5121	.5121	.4572	.4755	
21	.567	.567	.4207	.4938	.4207	.4207	.4938
22	.4938	.4938	.3841	.4207	.3475	.3658	.439
23		.3658	.3292	.2561	.2926	.2561	.3292
24	.2926	.3292	.3475	.3109	.2378	.2743	.2743
Max	.6584	.7499	.6584	.6036	.5121	.4755	.5853
Min	.2743	.2561	.2561	.2012	.2195	.2012	.1097
Avg	.4111	.4397	.4214	.3544	.3391	.3077	.3300

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 202 / 11KV Shirdhon Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1052	.1187	.1629	.1829	.1417	.1448	.1417
2	.0905	.759	.7164	1.0903	.1417	.1267	.1629
3	.0905	.7655	.8413	1.0719	.1433	.128	.1494
4	.0914	.8697	.9709	1.0242	.1612	.1463	.168
5	.1097	.8855	1.1616	1.2254	.181	.1646	.168
6	.1646	1.5181	1.4685	1.4118	.197	.2012	.1867
7	.1829	2.17	2.1735	1.8959	.2328	.2378	.2534
8	.2378	2.7046	2.2436	2.1384	.2353	.2561	.2587
9	.197	2.4619	2.4099	2.268		.2353	.1848
10	.1991	.1823	.1494	2.4714	2.9271	1.8404	2.0748
11	.1865	.1844		2.3487	2.1498	2.3312	2.1209
12	.1966		.2103	2.3034	2.2365	2.5549	2.5486
13	.1696	.2883	.2103	2.1971	2.2192	2.1434	1.9982
14	.1949	.2507	.2103	2.0332	2.2786	2.5139	2.3838
15	.1928	.2126	.2103	2.0683	2.2085	2.3491	2.6006
16	.1492	1.5947	.2103	2.0553	2.1033	2.2539	2.3232
17	.2294	.2454	.2481	2.0376	1.893	2.1498	2.3579
18		.2353	.2507	.1928	.1791	.1907	.2481
19	.2172	.2378	.2715	.2195	.2172	.2534	.2587
20	.2353	.2172	.2534	.2012	.2172	.1991	.2218
21	.2172	.2195	.2534	.2033	.181	.2172	.2402
22	.1578	.1612	.2149	.1629	.1791	.1629	.2172
23	.156		.1886	.1433	.1433	.124	
24	.1326	.1187	.1791	.181	.1254	.1463	.1402
Max	.2378	2.7046	2.4099	2.4714	2.9271	2.5549	2.6006
Min	.0905	.1187	.1494	.1433	.1254	.124	.1402
Avg	.1697	.7455	.6613	1.2970	.8997	.8780	.9308

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 203 / 11KV Borgaon Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.132	.132	.0943	.1132	.1132	.1109
2	.1132	.1132	.1132	.0754	.1132	.1132	.0934
3	.1132	.0943	.1132	.0754	.0943	.0943	.0943
4	.1132	.0943	.132	.0754	.0943	.0943	.0943
5	.1143	.0943	.132	.0943	.1132	.1132	.1132
6	.1334	.0943	.1509	.1524	.1509	.1334	.132
7	.1524	.1646	.1886	.1886	.2075	.2263	.1109
8	.1646	.1663	.168	.168	.2241	.1698	.112
9	.1698	.132	.1698	.1478	.1886	.1867	.1307
10	.128	.1848	.1478	.1478	.1463	.132	.168
11	.1294	.132	.1463	.128	.1629	.1307	.1478
12	.1097			.1307	.1629	.112	.1463
13	.1132	.132	.1086	.112	.1433	.0905	.132
14	.0819	.1307	.1086	.1132	.1417	.0914	.112
15	.0914	.1254	.1075	.132	.1214	.1109	.128
16		.1063	.1063	.1509	.104	.0943	.1132
17	.1075	.1075	.1063	.1886	.104	.0934	
18	.1595	.1791	.132	.2149	.1848	.1294	.1463
19	.2218	.2054	.1478	.2402	.2033	.2263	.2241
20	.2075	.1886	.1715	.2263	.2241	.1886	
21	.1698	.1886	.1698	.2075	.1867	.1698	
22	.132	.1509	.1509	.1698	.1524	.132	.1294
23	.132		.1509	.1509	.132	.1307	
24	.1698	.132	.132	.132	.132	.132	.1109
Max	.2218	.2054	.1886	.2402	.2241	.2263	.2241
Min	.0819	.0943	.1063	.0754	.0943	.0905	.0934
Avg	.1382	.1386	.1385	.1465	.1500	.1337	.1275

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 204 / 11KV Borgaon Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1646	.1663	.2054	.2075	.1494	.1886	.168
2	.1463	.9014	.953	1.0082	.1509	.1698	.1494
3	.1463	.8749	1.1523	.9762	.1698	.1698	.1509
4	.1646	.8905	1.2163	1.0242	.1698	.1886	.1698
5	.1848	.933	1.2498	1.0883	.1886	.1886	.1698
6	.2427	1.4074	1.3748	1.2163	.2263	.2263	.2263
7	.2801	2.3655	1.9109	1.5546	.2829	.3018	.2829
8	.2987	2.4166	2.4006	1.8404	.3018	.2987	.2987
9	.3696	2.1765	2.3967	2.1605	.3174	.2801	.2614
10	.3547	.3361	.2241	2.5911	2.1376	1.9925	2.3644
11	.4251	.3361	.2987	2.5101	1.5364	2.6235	2.5587
12	.3734		.2987	2.3967	1.5779	1.9599	2.753
13	.3511	.2427	.2801	2.2725	2.1247	2.3903	2.834
14	.3326	.2587	.2772	2.2885	2.2725	2.4006	2.8178
15	.3174	.2126	.2772	2.3205	2.3205	2.2184	2.8502
16		.3174	.3174	2.2138	2.2455	2.2929	2.8178
17	.3547	.3547	.3734	2.2771	2.0557	2.1348	2.6566
18	.3547	.3142	.4108		.2054	.2218	.2587
19	.2987	.3395	.3547	.2614	.2614	.2614	.3018
20	.2801	.112	.2987	.2452	.2614	.2452	.2829
21	.2452	.2614	.2801	.2452	.2241	.2427	.2641
22	.2054	.2241	.2427	.2263	.2054	.2241	.2241
23	.168		.2263	.2075	.2075	.1867	
24	.1629	.1663	.2241	.2263	.1886	.1886	.168
Max	.4251	2.4166	2.4006	2.5911	2.3205	2.6235	2.8502
Min	.1463	.112	.2054	.2075	.1494	.1698	.1494
Avg	.2705	.7095	.7185	1.3634	.8242	.8998	1.0882

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 205 / 11KV Shivganga Gao
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-DEC-17	02-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.112		.1109	.1075	.0857
2	.1109	.112		.1132	.0895	.0886
3	.0924	.1307		.1132	.0905	.1086
4	.1109	.1307		.132	.1086	.1086
5	.1097	.1307		.132	.1086	.1267
6	.128	.1307		.1509	.1086	.1267
7	.1097	.1698		.1509	.132	.132
8	.1086	.1132		.132	.1132	.1509
9	.132	.1132	.2614	.1075	.1132	.1109
10	.1509	.0943	.2614	.1132	.1991	.1509
11	.1829	.132	.1494	.1132	.2172	.1698
12	.1829	.1698	.1509	.132		.132
13	.1509	.1698	.132	.1509	.132	.0943
14	.2075	.1886	.132	.132	.2075	.168
15	.2614	.2263	.1509	.132	.2075	.1463
16	.1886	.2263	.1886	.132	.1307	.1214
17	.1886	.1509	.2075	.132	.128	.1867
18	.1509	.1109	.1132	.132	.1132	.0943
19	.1698	.1698	.1509	.132	.1698	.1646
20	.1698	.168	.1509	.1132	.1494	.1463
21	.1698		.168	.1132	.128	.1463
22	.1254		.1494	.1052	.1063	.1052
23	.1109		.1494	.1097	.0857	
24	.2194	.112		.1294	.1075	.0857
Max	.2614	.2263	.2614	.1509	.2172	.1867
Min	.0924	.0943	.1132	.1052	.0857	.0857
Avg	.1517	.1458	.1677	.1256	.1328	.1283

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 206 / 11KV Shirdhon Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-DEC-17	02-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1132		.1132	.1886	.132
2	.1132	.1132		.1132	.1509	.1132
3	.0943	.0943		.0943	.1509	.1132
4	.0943	.1132		.0943	.1698	.132
5	.132	.1132		.132	.1886	.132
6	.1698	.1698		.1698	.2075	.1698
7	.1867	.2614		.2054	.2614	.2801
8	.2195	.2033		.2218	.2033	.2218
9	.1772	.1646	.1829	.1848	.2172	.1829
10	.1772	.1387	.1663	.1132	.1772	.1463
11	.1612	.1844	.1646	.1307		.128
12	.1595	.1629	.1612	.1294	.1086	.1463
13	.1612	.1629	.1448	.1478	.1433	.1595
14	.1433	.1595	.1402	.1463	.156	.1595
15	.1417	.156	.1402	.1734	.1029	.1595
16	.1402	.1543	.1387	.1753	.1543	.1791
17	.1696	.1753	.1387	.1753	.1595	.156
18	.2172	.2353	.2195	.2534	.2481	.2149
19	.3511	.3326	.3174	.3174	.3326	.3109
20	.2641	.2801	.3018	.2801	.2801	.2801
21	.2452		.2829	.2452	.2829	.2614
22	.1886		.2452	.1905	.2075	.1886
23	.1509		.1886	.1886	.1509	
24	.2264	.1132		.1509	.1886	.132
Max	.3511	.3326	.3174	.3174	.3326	.3109
Min	.0943	.0943	.1387	.0943	.1029	.1132
Avg	.1749	.1715	.1955	.1728	.1926	.1782

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 207 / 11KV Alkud Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.132		.132	.1132	.1509
2	.4858	.1132		.4801	.4915	.6539
3	.4694	.1132		.5668	.4588	.6299
4	.5182	.1132		.6154	.4096	.6539
5	.6554	.132		.7045	.547	.6706
6	.7293	.2452		.9116	.7293	.7545
7	1.1271	.3395		1.4089	1.21	1.085
8	1.5746	.2641		1.7736	1.5912	1.6057
9	1.757	.2801	.3772	1.9062	1.4582	1.4746
10	1.873	1.1822	.3018	.132	.132	.1307
11	1.8515	1.6385	.1307	.132	.0943	.1509
12	1.4883	1.8187	.1307	.132	.1109	.1867
13	1.8515	1.8023	.112	.132	.1097	.1294
14	1.7695	1.8896	.112	.132	.112	.112
15	1.8515	1.8515	.1307	.132	.112	.112
16	1.8679	1.8351	.1494	.1132	.132	.112
17	1.6842	1.7204	.168	.112	.1307	.0924
18	.1886	.2033	.2263	.1509	.2075	
19	.2452	.2427	.2641	.2263	.2641	.2427
20	.2263	.2614	.2263	.2075	.2641	.2452
21	.2075		.1886	.1698	.2075	.0229
22	.168		.1698	.1698	.1886	.1698
23	.132		.1509	.132	.1509	
24	.264	.132		.1509	.1132	.1509
Max	1.873	1.8896	.3772	1.9062	1.5912	1.6057
Min	.132	.1132	.112	.112	.0943	.0229
Avg	.9632	.7767	.1892	.4468	.3891	.4335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 401 / 33 KV JOLLY BOARD
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER MIDC EQUIVALENT
HAVING WEEKLY STAGGERING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.5658	.9259	1.0288	1.1317	.1543	.8488
2	.6173	.5658	.8745	1.0288	1.0185	.1543	.9619
3	.7042	.679	.823	.9774	.9619	.1543	.5658
4	.8402	.6224	.823	.9259	.679	.1543	.679
5	.8402	.679	.9774	.9259	.5658	.2058	.679
6	1.0642	.5658	1.0802	.7202	.5658	.3086	.5658
7	.7842	.6224	.6173	.823	.5658	.3086	.5093
8	.5601	.679	.5144	.463	.3395	.2058	.6224
9	.9054	.7716	.7202	.5093	.1029	.2263	.7202
10	.9054	1.0288	.5144	.5093	.2058	.1698	.3601
11	.2263	.823	.3086	.5093	.2058	.3395	.1543
12	.679	.5658	.6687	.1698	.2572	.2829	.3086
13	.1698	.463	.5144	.3961	.1543	.2263	.463
14	.5658	.7716	.3086	.4527	.1543	.679	.6687
15	.5658	.6687	.4115	.2829	.2058	.4527	.3601
16	1.0185	.823	.7202	.5658	.2058	.7922	.2572
17	1.2449	.823	1.1831	.9054	.2058	.7922	.4115
18	1.2449	.4115	1.0802	1.0185	.2058	.5093	.7202
19	1.0185	.9774		.9619	.2058	.5658	.3601
20	.7356	.6687	.9774	.7356	.2058	.9054	.3086
21	.7922	.9259	1.0288	.7922	.2058	.5093	.2572
22	1.1317	1.0802	1.0288	.9619	.2058	.5658	.2058
23	.679		.9774	.9054	.1543	.5658	
24	.6173	.679	1.0288	.9259	.9619	.1543	.9054
Max	1.2449	1.0802	1.1831	1.0288	1.1317	.9054	.9619
Min	.1698	.4115	.3086	.1698	.1029	.1543	.1543
Avg	.7720	.7157	.7873	.7290	.4030	.3909	.5171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 201 / 11Kv Dudhebhavi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	05-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012	.2058	.2035		
2	1.4251	.2058	.1865		
3	1.5927	.2058	.1865		
4	1.5927	.1886	.2012		
5	1.8442	.1886	.2012		
6	2.0957	.2058	.218		
7	2.5149	.2229	.2347		
8	2.5149		.2012		
9	2.5149	.2229	.2012		
10	2.5892		2.7639	.1715	.12
11	2.6578		2.649	.12	.2058
12	2.8292		2.649		.2058
13	2.8121		2.5987		.1886
14	2.6235		2.9843	.12	.2058
15	2.5892		2.9843	.1543	.1886
16	2.4863		2.431	.1543	.1886
17	2.4177	2.6825	2.0957	.1715	.2058
18	.2058	.2204		.2058	
19	.2229	.218		.2229	
20	.2229	.2347		.2229	
21	.2229	.218		.2058	
22	.2058	.2012		.1886	
23	.2058	.2012		.1715	
24	.8097	.2058	.2012		
Max	2.8292	2.6825	2.9843	.2229	.2058
Min	.2012	.1886	.1865	.12	.12
Avg	1.6415	.3643	1.2884	.1758	.1886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 202 / 11KV Nagaj

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677		.1677	.1886	.1543	.2204
2	1.0059		.1677	.1886	1.2174	1.0174
3	1.3748		.1696	.1886	1.2346	1.1022
4	1.4251		.1844	.2058	1.286	1.0174
5	1.5424		.2012	.2229	1.3889	1.5261
6	1.8442		.2683	.2401	1.6975	1.6956
7	1.9281		.3353	.2572	2.0405	1.7804
8	1.9784		.2515	.2572	2.1948	1.6766
9		.2572	.2012		2.1605	1.3904
10	2.0748		1.9281	.1886	.3391	.1543
11			2.146	.1715	.3561	.1715
12	1.989		1.9281		.3561	.1715
13	2.0062		1.6766			.1715
14	1.9719		2.0119	.12	.2012	.1886
15	1.0117		2.146	.1543	.2012	.1715
16	1.7147		1.9784	.1543	.1526	.1715
17	1.5947	1.8778	1.8945	.1715	.1509	.1715
18	.2572	.1696		.1886		
19	.2915	.1677		.2229		
20	.2915	.1677		.2401		
21	.2743	.1677		.2058		
22	.2572	.1844		.1543		
23	.2058	.1844		.1543		
24	.1677		.1677	.1886		.2204
Max	2.0748	1.8778	2.146	.2572	2.1948	1.7804
Min	.1677	.1677	.1677	.12	.1509	.1543
Avg	1.1534	.3971	.9902	.1935	.9457	.7233

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 203 / 11KV Chorochi
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17
HR	Load (MW)
24	2.431
Max	2.431
Min	2.431
Avg	2.431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 204 / 11KV Dhalewadi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.218	.2401	.2347			.1886
2	.2012	.8745	.9389			.1715
3	.2012	.9431	1.1736			.1715
4	.2012	1.0288	1.3108			.1886
5	.2515	1.286	1.7604			.2572
6	.3688	1.7147	2.2131			.3429
7	.4694	1.9719	2.431			.3944
8	.3856		2.1795			.4115
9	.3185	2.0748	1.8442			.3601
10	.2915		.3018	2.4177	1.8652	2.0576
11	.2572		.2683	2.4863	2.7639	2.5892
12	.2572		.3018		2.713	2.6578
13	.1029		.3018		2.8995	2.7435
14	.12		.3018	1.5432	2.713	2.572
15	.0857		.3353	2.5892	2.8826	2.5892
16	.3601		.3353	2.7435	2.9334	2.7435
17	.4115	.2204	.3353	2.4177	2.9334	2.572
18	.4115	.1844		.2915		
19	.4287	.2515		.3086		
20	.4287	.2683		.3086		
21	.3601	.2683		.2572		
22	.3258	.2543		.2058		
23	.2572	.2347		.1886		
24	.7287	.2401	.2347			.1886
Max	.7287	2.0748	2.431	2.7435	2.9334	2.7435
Min	.0857	.1844	.2347	.1886	1.8652	.1715
Avg	.3101	.7535	.9335	1.3132	2.713	1.2889

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 205 / 11KV Chorochi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1214		.1387		.1372	.1543
2	.1214	.12	.1372		.1372	.1543
3	.12	.12	.1372		.12	.1543
4	.12	.12	.1372		.12	.1715
5	.1372	.12	.1734		.1543	.2427
6	.2058	.1372	.2454		.1886	.2743
7	.2601	.1543	.2915		.2401	.2743
8	.208		.2229		.2572	.2229
9	.1907	.2401	.1907		.2401	.2229
10	.1886		.1715	.1372	.1543	.1543
11	.1886		.1715	.1372	.1543	.1543
12	.1886		.156		.1372	.1543
13	.1715		.1402		.1372	.1543
14	.1715		.1543	.12	.1372	.1543
15	.1715		.1715	.1372	.1372	.1543
16	.1886		.1715	.1715	.1907	.1372
17	.2058	.2401	.1907	.1886	.1886	.2058
18	.2229	.2401		.2229		
19	.2572	.2427		.2401		
20	.2572	.2254		.2401		
21	.2229	.1715		.1372		
22	.1715	.1372		.1372		
23	.1372	.1387		.1372		
24	.1214	.12	.1387		.1372	.1526
Max	.2601	.2427	.2915	.2401	.2572	.2743
Min	.12	.12	.1372	.12	.12	.1372
Avg	.1812	.1685	.1745	.1672	.1649	.1829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 206 / 11 KV Dudhebhavi Gao

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1387	.1372	.0867		.1715	
2	.1372	.1372	.0857		.1543	
3	.1372	.1372	.0867		.1543	
4	.1543	.1543	.104		.1715	
5	.1715	.1715	.1029		.1886	
6	.2058	.1886	.104		.2058	
7	.2229	.2229	.12		.2058	
8	.2058		.1214		.2229	
9	.1907	.2572	.1214		.2058	
10	.2572		.1372	.1886	.2058	.2572
11	.2743		.1543	.1715	.2058	.2401
12	.2915		.1214		.2058	.2229
13	.2572		.104		.2254	.2229
14	.1886		.104	.1886	.2401	.2229
15	.1715		.1029	.2401	.2229	.2229
16	.1886		.12	.2572	.2254	.2229
17	.2229	.2229	.1387	.2572	.2401	.2401
18	.1886	.1543		.1886		
19	.1543	.156		.2058		
20	.1372	.1387		.2058		
21	.1372	.12		.1886		
22	.1372	.0867		.1886		
23	.1372	.0867		.1715		
24	.1387	.1372	.0867		.1715	
Max	.2915	.2572	.1543	.2572	.2401	.2572
Min	.1372	.0867	.0857	.1715	.1543	.2229
Avg	.1853	.1568	.1112	.2043	.2013	.2315

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 201 / 11KV Shelkewadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.2033	.2149	.2218	.1867	.2195	.1867
2	1.0814	.2241	.197	.1867	1.1012	1.0883	1.0364
3	1.1469	.2241	.181	.1867	1.1822	1.2955	1.1984
4	1.3748	.2427	.1829	.2427	1.5384	1.5729	1.4575
5	1.8143	.3018	.1829	.3361	2.2043	1.7814	2.1051
6	2.2213	.5658	.1791	.6036	2.4417	2.3045	2.3908
7	2.4813				3.1855	3.0148	2.8995
8	2.7831				3.3532	2.9797	3.2861
9	2.9007		.1791		3.2861	2.9447	2.7496
10	2.42	2.8334	.6478		.2587	.2507	.3511
11	2.9172	2.7526	3.3532	.3734	.2926	.2561	.2926
12	2.652	2.7526	3.2526	.2987	.2926	.197	.2957
13	2.3472	2.8182	.2187	.2454	.2715	.2353	
14	2.1795	2.9447		.2534	.2534	.2172	.2218
15	2.7161	2.7526		.2534	.2149	.2149	
16	2.9005	2.5301	3.3699	.2507	.2303	.3109	
17	2.8334	2.5606	3.0346	.2658	.2303	.3696	
18	.4294	.3582	2.0719	.4251	.3582		
19	.5281	.3898	.4854	.4854	.3982	.4338	.5415
20	.4715	.4344	.3982	.415	.4252	.3772	.4854
21	.3772	.3898	.3772	.3734	.362	.3734	.4527
22	.2987	.3189	.2801	.2829	.3189	.3018	.3174
23	.2402	.2686	.2402	.2054	.3109	.2241	.2614
24	.2218	.2012	.2149	.2218	.1867	.2686	.1867
Max	2.9172	2.9447	3.3699	.6036	3.3532	3.0148	3.2861
Min	.2218	.2012	.1791	.1867	.1867	.197	.1867
Avg	1.6483	1.2413	.9631	.3064	.9535	.9231	1.0903

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 202 / 11 KV GATHNANDRE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1132	.124	.1132	.1132	.124	.132
2	.1132	.7537	.583	.5144	.132	.1254	.1509
3	.1132	.8684	.6882	.5935	.132	.128	.1509
4	.1509	.9831	.8322	.7291	.1698	.1612	.1886
5	.1886	1.094	.9717	.9556	.2075	.2195	.2452
6	.2641	1.3094	1.2163	1.0608	.2263	.2507	.3018
7	.2075	1.4754	1.8351	1.3923		.2865	
8	.1886	1.4918		1.3757			
9	.1433	1.7736	1.4419	1.4752			
10	.1307	.1307	.1433		1.326	1.2452	1.4251
11	.112	.1097	.1509	1.5912	3.1458	1.6409	1.5415
12	.1294	.1097	.1294	1.5729			1.6409
13	.1109	.0905	.0924	1.5565			
14	.0934	.0724		1.6741	1.166	1.278	1.6907
15	.0554	.0724		1.7238	1.2125	1.3108	
16	.0724	.0895	.1075	1.6876	1.2955	1.6575	
17	.0934	.1063	.1109	1.6057	1.3763	1.7238	
18	.1698	.1612	.1867	.1886	.1791	.1886	
19	.2263	.1612	.2452	.2641	.1791	.2452	.2075
20	.2263	.181	.2075	.2075	.1991	.2075	.2075
21	.1698	.1612	.1698	.1698	.1791	.1886	.1698
22	.132	.1417	.1509	.1509	.1629	.1698	.1509
23	.132	.1254	.1307	.132	.1433	.1509	.132
24	.1132	.1132	.1254	.1132	.1132	.1417	.132
Max	.2641	1.7736	1.8351	1.7238	3.1458	1.7238	1.6907
Min	.0554	.0724	.0924	.1132	.1132	.124	.132
Avg	.1437	.4870	.4592	.9064	.6136	.5722	.5292

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 203 / 11KV Raiwadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0381	.0358	.0377	.0381	.037	.0377
2	.0377	.1739	.1802	.12	.0381	.0362	.0377
3	.0377	.2372	.2294	.1886	.0572	.0358	.0566
4	.0754	.3041	.3401	.2572	.0953	.0905	.0943
5	.1132	.3681	.4001	.3521	.132	.128	.1509
6	.1509	.583	.5441	.4973	.1698	.1423	.1886
7	.1509	.7209		.663		.112	
8	.132	.8356	.6325	.7865			
9	.1143	.7935	.6081	.7045			
10	.0943	.0754	.124		.506	.5506	.5668
11	.0739	.0549	.0566	.7842	1.613		.7287
12	.1097	.0366	.0377	.7362	.8192	.6154	.6964
13	.0739	.0358	.0366	.7186	.7209	.7748	
14	.0554	.0362		.7842	.6478	.7682	.7499
15	.0724	.0358		.7682	.6081	.7842	
16	.0732	.0709	.056	.6405	.6226	.6081	
17	.0739	.0716	.056	.6325	.5761	.5344	
18	.1109	.1063	.1109	.1307	.0886	.112	
19	.132	.1075	.112	.132	.1075	.132	.112
20	.1143	.1109	.1132	.1132	.1267	.1307	.1132
21	.0943	.0895	.0754	.0754	.0895	.1132	.0943
22	.0572	.0739	.0566	.0572	.0709	.0762	.056
23	.0572	.0532	.0377	.0572	.0701	.0566	.0373
24	.0566	.0381	.0354	.0377	.0572	.0701	.0566
Max	.1509	.8356	.6325	.7865	1.613	.7842	.7499
Min	.0377	.0358	.0354	.0377	.0381	.0358	.0373
Avg	.0882	.2105	.1847	.4032	.3455	.2813	.2361

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 204 / 11 KV Shelkewadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1509	.1097	.1509	.1715	.1663	.1334
2	.132	.1509	.1063	.132	.1698	.1646	.1334
3	.168	.1509	.1075	.132	.1698	.2172	.1334
4	.2241	.1886	.1448	.1509	.2263	.2686	.2263
5	.2829	.2286	.2195	.2263	.3361	.3109	.3395
6	.3961	.362	.3582	.3961	.4108	.3841	.415
7	.4066	.415	.4252	.4904	.4294	.4163	.4338
8		.3547	.0358	.4108	.4066	.3403	.3696
9		.2263	.3366	.3109	.2896	.2303	.2534
10	.3045	.2743	.2686		.2328	.2328	.2481
11	.1463	.2149	.2195	.2126	1.9591	.208	.2012
12		.1829	.1829	.2126	.2195	.1753	.1663
13		.1772	.1663	.2103	.197	.1448	
14	.168	.1791		.1791	.1267	.1448	.1867
15	.197	.1772		.1791	.1612	.1791	
16	.2427	.1991	.1867	.1753	.181	.181	
17	.2715	.2303	.2012		.2195	.2353	
18	.3109	.2149	.3206		.181	.3292	
19	.4338	.3224	.3772	.439	.2507	.3547	.3584
20	.3772	.3681	.4108	.3881	.3189	.3696	.3584
21	.3048	.2865	.3018	.3734	.2715	.2987	.3018
22	.2075	.2149	.2263	.3018	.2012	.2075	.2263
23	.1886	.1949	.1698	.1905	.1772	.1524	.1886
24	.168	.1698	.1663	.1509	.1905	.1612	.1524
Max	.4338	.415	.4252	.4904	1.9591	.4163	.4338
Min	.132	.1509	.0358	.132	.1267	.1448	.1334
Avg	.2540	.2348	.2292	.2578	.3124	.2447	.254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 205 / 11 KV GHATNANDRE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0762	.0532	.0566	.0572	.0526	.0762
2	.0572	.0762	.0537	.056	.0566	.0537	.0572
3	.0762	.0762	.0532	.056	.0566	.0532	.0572
4	.132	.0943	.0895	.0747	.1132	.0914	.1509
5	.1886	.132	.1267		.1509	.1463	.2075
6	.2452	.2263	.2126	.2263	.2075	.2149	.2829
7	.2801	.2829	.2328		.2641	.2561	.2829
8	.2075	.2075	.2303	.2241	.2452	.197	.2241
9	.1307	.1478	.1791	.168	.2896	.1629	.1848
10	.0943	.1294	.1063		.0754	.0895	.1097
11	.0754	.0914	.0747	.0905	.1828	.0905	.0732
12	.0747	.0532	.0732	.0895	.0914	.0724	.0724
13	.056	.0526	.0905	.0532	.0895	.0709	
14	.0754	.0526		.0537	.0724	.0543	.0549
15	.0905	.0709		.0537	.0724	.0543	
16	.0924	.0895	.0914	.0693	.0886	.056	
17	.128	.1063	.0905	.0905	.0886	.0914	
18	.1463		.2195	.1646	.1448	.181	
19	.2241	.1791	.2075	.2054	.1791	.2561	.2378
20	.2054	.2172	.1886	.1886	.1991	.2054	.2218
21	.1698	.1772	.1509	.1509	.1829	.1509	.168
22	.1132	.1063	.0943	.1334	.1227	.1143	.132
23	.0953	.0895	.0566	.0762	.0876	.0762	.0934
24	.0572	.0762	.0716	.0566	.0762	.0537	.0762
Max	.2801	.2829	.2328	.2263	.2896	.2561	.2829
Min	.056	.0526	.0532	.0532	.0566	.0526	.0549
Avg	.1280	.1222	.1249	.1113	.1331	.1185	.1454

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 206 / 11KV Raiwadi Gao

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0671	.0503	.0709	.0377	.0686	.0709	
2	.0678	.0678	.0716	.0189	.0497	.0724	.0663
3	.0678	.0686	.0716	.0189	.0497	.0724	.0671
4	.1086	.0701	.0709	.0377	.0701	.0732	.1086
5	.1463	.0895	.0895	.0566	.0895	.0886	.1267
6	.1463	.1109	.1075	.0754	.1086	.0949	.128
7	.1448	.1307	.1075	.0754	.128	.0972	.1463
8	.1097	.0566	.0709	.0754	.0934	.0905	.0554
9	.0724	.0566	.0358	.056	.0526	.0914	.0354
10	.0886	.0543	.0354		.0351	.0543	.0358
11	.0886	.0537	.0537	.0486	.0328	.0663	.0362
12	.0701	.0537	.052	.0343	.0328	.0537	.0362
13	.0492	.0532	.0358	.0332	.0532	.0671	
14	.0503	.0537		.0343	.0526	.0693	.0351
15	.0663	.0709		.0343	.0532	.0693	
16	.0354	.0905	.0686	.0339	.0537	.1029	
17	.0537	.0895	.0895	.0693	.0537	.0876	
18	.1097	.0876	.0876	.1063	.0914	.0732	
19	.0934	.0886	.0924	.0905	.0895	.0934	.112
20	.0747	.1086	.0924	.0732	.0886	.0924	.0747
21	.0566	.0895	.0732	.0566	.0895	.0739	.0747
22	.0716	.0905	.0532	.0716	.0876	.0701	.0549
23	.0701	.0905	.0377	.0686	.0716	.0663	.037
24	.0671	.0503	.0716		.0686	.0716	.0663
Max	.1463	.1307	.1075	.1063	.128	.1029	.1463
Min	.0354	.0503	.0354	.0189	.0328	.0537	.0351
Avg	.0823	.0761	.0700	.0549	.0693	.0776	.0720

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 207 / 11KV Jakhapur Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0754	.0724	.0373	.0754	.0732	.0566
2	.1696	.0754	.0724	.0189	.2012	.176	.176
3	.1696	.0754	.0716	.0189	.2347	.2214	.2241
4	.2035	.0943	.112	.0377	.285	.2561	.2721
5	.2458	.1132	.1417	.0934	.3353	.3441	.3277
6	.3113	.1698	.1791	.1867	.4191	.4161	.3932
7	.4424				.5735	.6062	.5735
8	.5898				.7373	.7935	.7373
9	.5898				.6882	.852	.7373
10	.5898	.6371	.7087			.0914	.0754
11	.6706	.5243	.6009	.168	.0377	.0377	.0943
12	.6203	.4696	.6325	.0934		.0754	.1132
13	.5365	.5735	.3725	.112		.0754	
14	.5197	.639		.112	.0366	.0754	.056
15	.57	.6478		.112	.0905	.0943	
16	.6274	.6722	.6562	.1307	.1254	.1307	
17	.6036	.6154	.5121	.112	.1612	.112	
18	.1132	.0914	.3681	.1494	.1578	.1494	
19	.132	.1267	.0934	.112	.1448	.1494	.0934
20	.1509	.1433	.0747	.112	.1433	.112	.0934
21	.1509	.124	.0747	.0934	.1267	.0943	.0934
22	.0943	.1075	.0747	.0934	.0914	.0943	.0747
23	.0943	.0895	.056	.0943	.0724	.0754	.0747
24	1.0898	.0943	.0895	.0373	.0754	.0716	.0566
Max	1.0898	.6722	.7087	.1867	.7373	.852	.7373
Min	.0934	.0754	.056	.0189	.0366	.0377	.056
Avg	.3908	.2933	.2612	.0962	.2292	.2157	.2275

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 208 / 11 KV AGALGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1132	.197	.112	.132	.1612	.132
2	.1132	.6554	1.4575	.703	.132	.1417	.1509
3	.1132	.7537	1.8404	.7682	.132	.1791	.1509
4	.168	.8951	1.8623	.9892	.1886	.2534	.2241
5	.2427	1.0898	1.8724	1.1904	.2801	.2926	.3361
6	.3361	1.5261	1.9433	1.5424	.3734	.3721	.4108
7	.3174	2.0008	1.9334	1.668	.4294		
8	.2241	2.0454	1.9757	1.6057	.3734		
9	.1867	1.5927	1.8023	1.8084	.2241		
10	.168	.1698	.2149		1.7124	1.6078	1.6549
11	.1867	.1463	.1829	1.4746	1.8724	1.3592	1.749
12	.1494	.1463	.1829	1.4091	1.7004	1.873	1.7652
13	.1294	.1063	.128	1.3108	1.7532	1.9393	
14	.1307	.0358		1.3927	1.668	1.9062	1.9161
15	.1307	.0354		1.3599	1.5074	1.8947	
16	.1494	.0537	.1829	1.3108		1.6712	
17	.168	.2507	.1646		1.4746	1.4255	
18	.1698	.2743	.2561		.2149	.2801	
19	.2829	.3045	.2926	.2801	.2534	.3361	.3109
20	.2641	.3582	.2587	.2801	.2865	.2801	.2743
21	.2075	.298	.2241	.2241	.2172	.2263	.2241
22	.1509	.2149	.1867	.1698	.181	.2075	.1867
23	.132	.2149	.1494	.1509	.1772	.1509	.1494
24	.1132	.1132	.1772	.1307	.132	.1612	.132
Max	.3361	2.0454	1.9757	1.8084	1.8724	1.9393	1.9161
Min	.1132	.0354	.128	.112	.132	.1417	.132
Avg	.1811	.5581	.7948	.9467	.6702	.7962	.6105

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 201 / 11 KV LONARWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)
7		2.8532
9		2.2361
10		.2801
11		.2829
12		.2641
13		.2957
14		.2427
15		.2452
16		.2402
24	.2561	
Max	.2561	2.8532
Min	.2561	.2402
Avg	.2561	.7711

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 202 / 11KV Kokle Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)
7		.5544
9		.462
10		3.006
11		3.3105
12		3.3951
13		3.4728
14		3.3265
15		3.2487
16		3.2442
24	.2772	
Max	.2772	3.4728
Min	.2772	.462
Avg	.2772	2.6689

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 203 / 11 KV IRALI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)
7		.2561
9		.3696
10		2.5206
11		2.7073
12		2.9424
13		2.9938
14		2.9874
16		2.9938
24	.2957	
Max	.2957	2.9938
Min	.2957	.2561
Avg	.2957	2.2214

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 204 / 11 KV LONARWADI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)
7		.112
9		.0934
10		.1132
11		.112
12		.1132
13		.112
14		.0943
15		.0934
16		.1132
24	.0934	
Max	.0934	.1132
Min	.0934	.0934
Avg	.0934	.1063

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 205 / 11 KV KOKLE GAO

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)
7		.0732
9		.0924
10		.112
11		.1132
12		.1109
13		.112
14		.0943
16		.0934
24	.1478	
Max	.1478	.1132
Min	.1478	.0732
Avg	.1478	.1002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 206 / 11 KV IRALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	.6335
Max	.6335
Min	.6335
Avg	.6335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244099 / 33/11 kv KAROLI

Feeder No / Name : 201 / 11 KV Shindewadi (H) Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-DEC-17
HR	Load (MW)
24	.8535
Max	.8535
Min	.8535
Avg	.8535

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244099 / 33/11 kv KAROLI

Feeder No / Name : 202 / 11 KV Kuktoli Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.128	.1646
2		.0914	.1646
3		.128	.1646
4		.1646	.2195
5		.2195	.2743
6		.2743	.3109
7		.3292	
8		.2561	
9		.2012	
10			1.8233
11	.1478	2.0809	
12	.1478	2.13	
13	.1478	2.1628	
14	.1109	1.8842	
15	.1109	1.9334	
16	.1109	1.8515	
17	.1848	1.7532	
18	.2218	.2012	
19		.2743	
20		.3292	
21		.2378	
22		.2012	
23		.1829	
24	.1663	.1646	.1646
Max	.2218	2.1628	1.8233
Min	.1109	.0914	.1646
Avg	.1499	.7469	.4108

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244099 / 33/11 kv KAROLI

Feeder No / Name : 203 / 11 KV Kongnoli Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17
HR	Load (MW)
24	.703
Max	.703
Min	.703
Avg	.703

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244099 / 33/11 kv KAROLI

Feeder No / Name : 204 / 11 KV Karoli Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.2743	.2378
2		.2378	.2378
3		.3109	
4		.3109	.3109
5		.3475	.4207
6		.3658	.4938
7		.4024	.439
8		.3475	.3841
9		.3475	.3109
10			.3292
11	.2378	.2561	
12	.2195	.2195	
13	.2195	.2012	
14	.1829	.2012	
15	.1829	.2195	
16	.1646	.2561	
17	.3658	.2743	
18	.4024	.4024	
19		.5487	
20		.5853	
21		.4049	
22		.2926	
23		.2743	
24	.2195	.3109	.2561
Max	.4024	.5853	.4938
Min	.1646	.2012	.2378
Avg	.2439	.3214	.3420

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244099 / 33/11 kv KAROLI

Feeder No / Name : 205 / 11 KV Sarati Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.0747	.0934
2		.5868	.5636
3		.6539	.6299
4		.7209	.6962
5		.8383	.7625
6		.9556	.8383
7		1.073	1.1401
8		1.1401	1.2431
9		1.0395	1.1603
10		.0934	.0924
11	1.1934	.0934	
12	1.2929	.0934	
13	1.094	.0747	
14	1.1271	.0747	
15	1.2597	.0747	
16	1.2929	.0747	
17	1.1603		
18	.1109		
20		.0934	
21		.112	
22		.0934	
23		.0934	
24	.0747	.0934	.0934
Max	1.2929	1.1401	1.2431
Min	.0747	.0747	.0924
Avg	.9562	.3880	.6648

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 201 / 11 KV Deshing GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1174	.1174	.1844	.1174	.1341	.1341	.2012
2	.1174	.1341	.1844	.1174	.1341	.1509	.2012
3	.1341	.1341	.2012	.1341	.1341	.1509	.218
4	.1677	.1509	.218	.1677	.1341	.1677	.2347
5	.218	.1677	.2347	.2012	.1677	.2683	.2515
6	.3185	.2012	.2515	.2683	.3018	.3185	.3018
7	.3521	.3185	.2683	.3185	.3018	.3856	.2683
8	.3018	.2515	.2683	.2683	.2515	.2683	.2683
9	.218	.2012	.218	.2347	.1677	.2347	.2012
10	.2012	.218	.1844	.1677	.2012	.218	.1844
11	.1844	.2012	.218	.1677	.218	.2347	.1844
12	.1677	.2012	.1844	.1341	.1677	.2515	.1844
13		.218	.1677	.1341	.1341	.1677	.218
14	.1677	.2347	.1677	.1341	.1341	.1509	.1677
15	.1844	.2347	.1341	.1341	.1341	.1677	.1677
16	.2347	.2347	.1509	.1341	.1509	.2012	.1844
17		.2515	.2012	.2347	.1677	.3018	.2347
18	.3688	.4024	.2683	.3688	.3185	.3521	.3353
19	.3688	.3353	.3521	.3688	.3688	.4024	.3353
20	.3521	.3688	.3353	.3353	.3018	.3353	.3353
21	.2347	.4024	.2515	.3185	.2012	.3353	.3353
22	.1677	.3353	.218	.2683	.1509	.2012	.2347
23	.1509	.2683	.1677	.1677	.1341	.1677	.1677
24	.4525	.1341	.1677	.1341	.1341	.1341	.1677
Max	.4525	.4024	.3521	.3688	.3688	.4024	.3353
Min	.1174	.1174	.1341	.1174	.1341	.1341	.1677
Avg	.2355	.2382	.2166	.2096	.1935	.2375	.2326

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 202 / 11 KV BANEWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0838	.1677	.0838	.1006	.0838	.1006
2		.0838	.1677	.0671	1.0395	.7545	.8383
3		.0838	.1844	.0838	1.0395	.8383	.9221
4		.0838	.1844	.1006	1.0395	1.0059	1.073
5		.1677	.1781	.1341	1.0395	1.3413	1.1401
6		.2012		.1509		1.4251	1.3077
7		.2515	.2012	.2515	1.9281	1.6095	1.9448
8		.2683	.2683	.218	2.0119	1.9113	2.2634
9		.2515	.2012	.2683	1.9784	2.1795	2.2131
10		1.8778	2.1125	.2683	.1341	.1174	.1844
11		2.3472	2.0957	.2683	.1677	.1006	.1677
12		2.3472		.218	.1677	.1844	.1341
13		2.2801	2.2466	.2012	.1844	.2012	
14	2.4646	2.3137	2.2634	.1844		.218	.2683
15	2.4478	2.2466	2.3137	.1844	.1677	.1677	.2683
16	2.4478	2.2131	2.3807	.1844	.1509	.1677	.2347
17	2.3472	2.0119	2.1125	.1844	.1509	.1677	.218
18	.1844	.1677	.1509	.218	.1677	.2347	.2012
19	.1844	.1677	.2012	.218	.1677	.2012	.2012
20	.1844	.1844	.1844	.2012	.1509	.1677	.1677
21	.1677	.1677	.1509	.1677	.1509	.1677	.1509
22	.1341	.1677	.1006	.1341	.1341	.1174	.1509
23	.1006	.1509	.0838	.1006	.1341	.1006	.1006
24	.5668	.0838	.1509	.0838	.1006	.0838	
Max	2.4646	2.3472	2.3807	.2683	2.0119	2.1795	2.2634
Min	.1006	.0838	.0838	.0671	.1006	.0838	.1006
Avg	1.0209	.8418	.8228	.1740	.5594	.5645	.6478

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 203 / 11 KV MORGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0838	.1341	.1341	.0671	.0838	.0671	.1174
2	.7377	.1341	.1341	.0671	.6203	.6706	.503
3	.788	.1341	.1174	.0838	.6203	.8048	.5868
4	.8215	.1341	.1174	.0838	.6203	.8383	.6706
5	.8551	.1341	.1174	.1006	.6203	.8383	.7377
6	1.0059	.1509	.1174	.1174	1.0227	.9221	.7712
7	1.0059	.1677	.1341	.1341	1.5089	1.0395	1.2071
8	1.1233	.1341	.1341	.1677	1.5424	1.3077	1.3748
9	1.4251	.1341	.1341	.1509	1.5257	1.3245	1.4251
10	1.5089	1.3077	1.3413	.1174	.1006	.1341	.1174
11	1.6095	1.5089	1.576	.1509	.1174	.1006	
12	1.576	1.643	1.7269	.1509	.1341		
13	1.576	1.6095	1.7101	.1509	.1341		.1341
14	1.5592	1.643	1.7101	.1174	.1006	.1174	.1341
15	1.576	1.5424	1.7101	.1174	.1006	.1174	.1341
16	1.5927	1.5089	1.7101	.1341		.1174	.1174
17	1.4251	1.3748	1.6598	.1509		.1174	.1509
18	.1341	.1341	.0838	.1509	.1341	.1174	.2012
19	.1341	.1509	.1174	.1509	.1341	.1174	.2012
20	.1341	.1174	.1006	.1509	.1341	.1174	.1677
21	.1341	.1174	.0838	.1509	.1341	.1174	.1509
22	.1341	.1174	.0838	.1509	.1174	.1006	.1509
23	.1341	.1341	.0838	.1174	.0671	.1006	.0838
24	.0838	.1341	.1341	.0671	.0838	.0671	.1006
Max	1.6095	1.643	1.7269	.1677	1.5424	1.3245	1.4251
Min	.0838	.1174	.0838	.0671	.0671	.0671	.0838
Avg	.8816	.5959	.6238	.1251	.4389	.4207	.4199

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 204 / 11 KV KHARSHING AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0335	.0503	.0838	.0335	.0335	.0335	.0671
2	.0335	.5868	.3353	.4191	.0335	.0335	.0671
3	.0335	.6706	.4191	.4191	.0335	.0503	.0838
4	.0503	.7545	.503	.4862	.0335	.0503	.0838
5	.0671	.8383	.5868	.5365	.0335	.0503	.1006
6	.1006	.8383	.6371	.6203	.1174	.0671	.1174
7	.1341	1.0898	.9724	.7377	.1174	.1174	.1006
8	.0838	1.3413	1.1401	1.0227	.1006	.0838	.1006
9	.0838	1.3748	1.2742	1.2239	.1006		.0838
10	.0838	.0671	.1006	1.4419	1.0059	1.0059	1.073
11	.0838	.0671	.0838	1.3748	1.3245	1.2071	1.1736
12	.0838	.0838	.0838	1.3748	1.3077	1.3413	1.3413
13		.0671	.1006	1.3413	1.2742	1.3748	1.3413
14	.0503	.0671	.0838	1.3748	1.2574	1.3748	1.3748
15	.0671	.0671	.0671	1.3245	1.1736	1.2071	1.3748
16	.0838	.0671	.0671	1.3245	1.0059	1.0898	1.0227
17	.0838	.0671	.0671	.8383	.9389	1.0059	1.073
18	.1006	.0838	.0671	.0838	.0671	.0671	.0503
19	.0838	.1006	.0838	.0838	.0838	.0671	.0671
20	.0838	.1174	.0671	.0838	.0838	.0671	.0671
21	.0838	.1174	.0671	.0671	.0838	.0671	.0671
22	.0671	.1006	.0335	.0671	.0838	.0503	.0671
23	.0503	.0838	.0335	.0335	.0335	.0503	.0503
24	.0335	.0503	.0838	.0335	.0335	.0335	.0503
Max	.1341	1.3748	1.2742	1.4419	1.3245	1.3748	1.3748
Min	.0335	.0503	.0335	.0335	.0335	.0335	.0503
Avg	.0722	.3647	.2934	.6811	.4317	.4563	.4583

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 206 / 11 KV HAROLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0492	.0492	.0819	.0503	.0492	.0328	.0655
2	.0503	.3277	.3277	.5407	.0492	.0328	.0655
3	.0492	.3605	.4096	.5571	.0492	.0492	.0819
4	.0492	.4915	.4915	.5735	.0492	.0492	.0983
5	.0655	.4915	.6226	.6062	.0492	.0492	.0983
6	.0838	.7373	.7537	.6554	.1147	.0655	.0983
7	.0983	.9339	.9503		.1147	.0819	.0819
8	.0983	.9667	1.0486	.7373	.0655	.0655	.0819
9	.0492	1.0159	1.1142	.7865	.0655	.0492	.0655
10	.0492	.0655	.0328	.9995	.8192	.6882	.9667
11	.0492	.0655	.0655	1.0322	.8848	.9175	.9831
12	.0492	.0819	.0492	1.0322	.9221	.9503	1.0486
13	.0655	.0819	.0328	1.0159	.9175	.9831	
14	.0655	.0819		.9831	.9175	.9995	1.0322
15	.0655	.0819	.0492	.9831	.9175	.9503	1.0322
16	.0655	.0819	.0492	.9831	.8192	.8848	1.0898
17	.0492	.0819	.0655	.7865	.7373	.6554	
18	.0819	.0983	.0655	.0819	.0655	.0655	.0655
19	.0655	.0983	.0819	.0819	.0819	.0655	.0983
20	.0671	.0983	.0819	.0819	.0655	.0655	.0983
21	.0492	.0819	.0819	.0655	.0655	.0655	.0983
22	.0492	.0819	.0492	.0655	.0492		.0655
23	.0492	.0655	.0492	.0492	.0328	.0492	.0655
24	.0328	.0492	.0655	.0492	.0492	.0328	.0503
Max	.0983	1.0159	1.1142	1.0322	.9221	.9995	1.0898
Min	.0328	.0492	.0328	.0492	.0328	.0328	.0503
Avg	.0603	.2738	.2878	.5564	.3313	.3412	.3378

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 201 / KHANDERAJURI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2286	.1905	.1905	.2096	.1905	.1905
2	.7202	.2286	.1715	.1905	.7042	.7209	.7459
3	.7202	.2286	.1715	.1905	.7682	.8785	.7459
4	.8002	.2286	.1905	.2096	.8322	1.0608	.7373
5	.9717	.3048	.2286	.2096	1.1012	1.2146	.9831
6	1.3765	.3429	.3048	.362	1.4746	1.3765	1.2146
7	1.6385	.4572	.4191	.4382		1.9919	1.9334
8	2.0481	.4001	.3239	.381	2.9338	2.4413	2.5911
9	2.3371	.362	.3239	.3429	2.934	2.5587	2.4166
10	2.4577	1.9498	1.9334	.2477	.2667	.2286	.2286
11	2.8346	2.3266	2.6686	.2286	.1715	.2286	.2096
12	2.8673	2.7526	2.7368	.2286	.1715	.2286	.2096
13	2.9959	2.5101	2.0809	.1905	.1905	.2286	.1905
14	2.915	2.6871	2.3537	.1715	.2096	.2096	.1905
15	2.6882	2.7044	2.556	.1715	.2286	.2096	.1905
16	2.5606	2.5888	2.8346	.2286	.2096	.2286	.2096
17	2.5126	2.5911	2.834	.2477	.1905	.2477	.2096
18	.2477	.2477	.2477	.2286	.3048	.2858	.2667
19	.3429	.3239	.3429	.362	.3429	.362	.3239
20	.3239	.2667	.3048	.3239	.3048	.3429	.3048
21	.2858	.2477	.2477	.2858	.2667	.3048	.2477
22	.2477	.2286	.2286	.2286	.2477	.2667	.2667
23	.2286	.2096	.1905	.2286		.2286	.2096
24	.9907	.2286	.1905	.1905	.2096	.2096	.2096
Max	2.9959	2.7526	2.8346	.4382	2.934	2.5587	2.5911
Min	.2286	.2096	.1715	.1715	.1715	.1905	.1905
Avg	1.4725	1.0269	1.0031	.2532	.6488	.6768	.6261

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 202 / 11 KV Khatav

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 203 / 11 KV Mallewadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1143	.0953	.1143	.0953	.0953	.1143
2	.0953	.5761	.6344	.583	.0953	.0953	.1143
3	.0953	.6081	.7122	.6613	.0953	.0953	.1143
4	.0953	.7042	.763	.7291	.0953	.1143	.1143
5	.1524	.8583	.8718	.7459	.1524	.1334	.1143
6	.1905	1.0277	1.2597	.7625	.2096	.1905	.1524
7	.2286	1.6078	1.6057	1.0159	.2286	.2286	.2477
8	.1905	2.1216	1.8785	1.2452	.2096	.1905	.2096
9	.1715	1.9498	1.8023	1.4922	.1715	.1524	.1524
10	.1524	.0953	.1143	1.5402	1.1523	1.4746	1.3435
11	.1334	.0953	.1524	1.7532	1.5223	1.6057	1.4575
12	.1334	.0953	.1334	1.7652	1.5546	1.6032	1.6712
13	.1524	.1143	.0953	1.5181	1.5893	1.6095	1.7204
14	.1524	.1143	.0953	1.6518	1.5565	1.587	1.7328
15	.1334	.0953	.0762	1.587		1.7532	1.7328
16	.1524	.1143	.1143	1.6032	1.5384	1.6712	1.7532
17	.1715	.1143	.1334	1.4883	1.3927	1.4575	1.668
18	.1905	.1715	.1715	.1524	.1715	.1524	.1334
19	.2096	.2096	.1905	.2096	.1905	.1905	.1715
20	.1905	.1905	.1905	.1715	.1715	.1715	.1715
21	.1715	.1524	.1524	.1524	.1524	.1524	.1334
22	.1524	.1143	.1143	.1334	.1334	.1334	.1334
23	.1334	.1143	.1143	.1143		.1143	.1143
24	.8764	.1143	.0953	.1143	.1143	.1143	.1143
Max	.8764	2.1216	1.8785	1.7652	1.5893	1.7532	1.7532
Min	.0953	.0953	.0762	.1143	.0953	.0953	.1143
Avg	.1842	.4781	.4819	.8877	.5724	.6286	.6410

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 204 / 11 kv shivganga

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572		.0762	.0762	.0762	.0762
2	.0572	.0762	.0572	.0762	.0762	.0572	.0762
3	.0572	.0572	.0572	.0762	.0762	.0572	.0762
4	.0572	.0572	.0572	.0762	.0762	.0572	.0762
5	.0762	.0572	.0572	.0762	.0762	.0762	.0762
6	.0762	.0572	.0762	.0762	.0762	.0762	.0762
7	.2286	.2096	.2286	.362	.0953	.2096	.0572
8	.3239	.1905	.1905	.3429	.1143	.1334	.2667
9	.9526	.1524	.0572	.3239	.1143	.0572	.3048
10	.2286	.0762	.0381	.3429	.3048	.0572	.2858
11	.2477	.1905	.3239	.381	.2858	.0381	.0762
12	.2667	.3048	.3429	.362	.3048	.1334	.3048
13	.2858	.1143	.3429	.2286	.0762	.1524	.2667
14	.2667	.1905	.1905	.3048	.1143	.1524	.1905
15	.2858	.3048	.3048	.2286	.1143	.1524	.2667
16	.2667	.2667	.2096	.1715	.1524	.1905	.1715
17	.2477	.1334	.0762	.1524	.2667	.2096	.2667
18	.2667	.1143	.0953	.0953	.2667	.1715	.1334
19	.0762	.0572	.0762	.0572	.0762	.0762	.0572
20	.0762	.0762	.0762	.0762	.0762	.0762	.0572
21	.0572	.0572	.0762	.0762	.0762	.0762	.0572
22	.0572	.0572	.0762	.0762	.0762	.0762	.0572
23	.0572	.0762		.0762		.0762	.0762
24	.0572	.0572	.0572	.0762	.0572	.0762	.0762
Max	.9526	.3048	.3429	.381	.3048	.2096	.3048
Min	.0572	.0572	.0381	.0572	.0572	.0381	.0572
Avg	.1929	.1246	.1394	.1746	.1317	.1048	.1429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 205 / 11KV Salgare

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.0953	.0953	.1143	.1143	.0953	.0953
2	.3725	.0953	.0953	.1143	.4001	.3772	.381
3	.3725	.0953	.0953	.1143	.4481	.4409	.4191
4	.4372	.0953	.1143	.1143	.4858	.4578	.4763
5	.4696	.1905	.1524	.1524	.583	.4973	.5258
6	.6226	.2286	.2286	.2477	.7287	.5636	.6001
7	.8356	.2667	.3048	.2858	1.326	1.0486	1.2071
8	.9172	.1905	.2096	.2286	1.6289	1.2597	1.6461
9	1.1961	.1715	.1524	.1715	1.6409	1.3757	1.5257
10	1.2955	1.0883	1.278	.1524	.1334	.1524	.1524
11	1.4575	1.3765	1.5089	.1334	.1524	.1334	.1334
12	1.5074	1.4575	1.6575	.1143	.1524	.1334	.1334
13	1.3763	1.4419	1.5581	.0953	.1334	.1334	.1143
14	1.3765	1.4582	1.5592	.0953	.1334	.1143	.0953
15	1.4746	1.4251	1.6448	.0953	.1524	.0762	.0953
16	1.3927	1.2125	1.6356	.1334	.1334	.0762	.1334
17	1.3108	1.2452	1.4922	.1334	.1143	.0762	.1334
18	.1524	.1905	.1715	.1334	.1524	.0953	.1524
19	.1905	.2286	.1905	.2096	.1715	.1715	.1334
20	.1524	.1715	.1715	.1905	.1715	.1524	.1334
21	.1524	.1715	.1715	.1715	.1334	.1334	.1143
22	.1334	.1715	.1524	.1524	.1143	.1143	.1143
23	.1143	.1524	.1524	.1334		.1143	.1143
24	.8955	.0953	.1143	.1334	.1143	.0953	.0953
Max	1.5074	1.4582	1.6575	.2858	1.6409	1.3757	1.6461
Min	.1143	.0953	.0953	.0953	.1143	.0762	.0953
Avg	.7633	.5548	.6211	.1508	.4051	.3287	.3635

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 206 / BELANKI gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953	.0953	.1143	.0953	.1334
2	.0953	.0953	.0953	.0953	.1143	.0953	.1334
3	.0953	.0953	.0953	.0953	.1143	.0953	.1334
4	.0953	.0953	.1143	.1143	.1143	.1334	.1334
5	.1905	.2096	.1524	.1715	.2286	.1715	.1524
6	.362	.3048	.2667	.3048	.362	.3048	.2667
7	.4382	.381	.381	.4191	.3429	.4572	.4191
8	.3429	.3239	.3239	.2286	.3239	.2957	.2858
9	.2858	.2667	.362	.3239	.2667	.2858	.2286
10	.2667	.1905	.2858	.2858	.1524	.3048	
11	.2286	.2286	.3239	.2858	.1905	.381	
12	.1905	.2477	.2477	.1905	.1905	.2858	
13	.1524	.2286	.1905	.1143	.1905	.1524	
14	.1905	.1905	.2096	.1715	.1524	.1524	
15	.2286	.1524	.2477	.1715	.2286	.1715	
16	.2286	.2286	.2096	.1905	.3429	.1905	
17	.2096	.2286	.1715	.2096	.0381	.2096	.2858
18	.3048	.2477	.2477	.2096	.1905	.2667	.2858
19	.3439	.3429	.3239	.3048	.3048	.3239	.2858
20	.2715	.2858	.3048	.3048	.2858	.2858	.2667
21	.2353	.1905	.1905	.2286	.2286	.2477	.2096
22	.1715	.1334	.1524	.1905	.1715	.1905	.1715
23	.1334	.1143	.1334	.1524		.1524	.1334
24	.8764	.1143	.0953	.1143	.1143	.1143	.1334
Max	.8764	.381	.381	.4191	.362	.4572	.4191
Min	.0953	.0953	.0953	.0953	.0381	.0953	.1334
Avg	.2514	.2080	.2175	.2072	.2071	.2235	.2152

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 201 / 11 Kv Arag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	04-DEC-17
HR	Load (MW)	Load (MW)
8	.1524	
24	.1524	.1715
Max	.1524	.1715
Min	.1524	.1715
Avg	.1524	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 202 / 11 KV Bedag gav

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	04-DEC-17
HR	Load (MW)	Load (MW)
8	.2477	
24	.2477	.3429
Max	.2477	.3429
Min	.2477	.3429
Avg	.2477	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 203 / 11 KV Vijaynagar
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	04-DEC-17
HR	Load (MW)	Load (MW)
8	.1715	
10		.2286
24	1.6957	.2286
Max	1.6957	.2286
Min	.1715	.2286
Avg	.9336	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 204 / 11 KV Bedag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	04-DEC-17
HR	Load (MW)	Load (MW)
8	.1524	
24	.1524	.1905
Max	.1524	.1905
Min	.1524	.1905
Avg	.1524	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 205 / 11 KV rade ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	04-DEC-17
HR	Load (MW)	Load (MW)
8	.362	
10		.381
24	.362	
Max	.362	.381
Min	.362	.381
Avg	.362	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 206 / 11 Kv Bolwad Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17
HR	Load (MW)
24	2.2863
Max	2.2863
Min	2.2863
Avg	2.2863

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244052 / 33/11 KV MALLEWADI

Feeder No / Name : 201 / 11 kv Erandoli Gav.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	1.7589
Max	1.7589
Min	1.7589
Avg	1.7589

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244052 / 33/11 KV MALLEWADI

Feeder No / Name : 203 / 11 KV Takali

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17
HR	Load (MW)
24	.905
Max	.905
Min	.905
Avg	.905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244052 / 33/11 KV MALLEWADI

Feeder No / Name : 204 / 11 kv Erandoli
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17
HR	Load (MW)
24	.1457
Max	.1457
Min	.1457
Avg	.1457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244052 / 33/11 KV MALLEWADI

Feeder No / Name : 206 / 11 KV VanKochiwadi feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-DEC-17
HR	Load (MW)
24	.2096
Max	.2096
Min	.2096
Avg	.2096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 201 / 11 KV Lingnoor Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.0924	.0943	.1494	.0876	.0724	.0895
2	.0867	.0905	.0914	.112	.0905	.0693	.0848
3	.1052	.0914	.0905	.1143	.0905	.0701	.0857
4	.1063	.0914	.0905	.1334	.0905	.0701	.1075
5	.1086	.0924	.1097	.1334	.0905	.0886	.1097
6	.1294	.1294	.1294	.1524	.1509	.128	.1494
7	.1509	.132	.1698	.1524	.1494	.112	.1494
8	.1524	.1132	.1509	.1509	.1307	.0747	.1109
9	.1132	.1132	.1509	.132	.0914	.0754	.0934
10	.1143	.1494	.1509	.1494	.0953	.1867	.1132
11	.1294	.2195	.1494	.1646	.128	.1478	.1294
12	.1478	.2172	.1494	.1663	.112	.1791	.112
13	.1478	.1646	.1143		.0762	.1494	.1307
14	.0754	.1494	.1132	.1478	.0739	.1143	.0924
15	.0943	.0943	.0934	.0943	.0754	.1509	.0943
16	.0381	.0953	.0747	.1143	.0953	.1132	.112
17	.0762	.1494	.0732	.1143	.0953	.1478	.0747
18	.1143	.1509	.1143	.1307	.1307	.2172	.1143
19	.2263	.2263	.2241		.1698	.2263	.1524
20	.2241	.2561	.2402	.2561	.168	.2641	.2096
21	.2195	.2241	.2402	.2241	.1867	.2054	.2075
22	.1663	.168	.2427	.1867	.1494	.1698	.1494
23	.1109	.1509	.2263	.112	.1143	.112	.112
24	.1143	.0924	.1143	.2075	.0934	.0762	.0886
Max	.2263	.2561	.2427	.2561	.1867	.2641	.2096
Min	.0381	.0905	.0732	.0943	.0739	.0693	.0747
Avg	.1277	.1439	.1416	.1499	.1140	.1342	.1197

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 202 / 11 KV Shindewadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1227	.1357	.1341	.1147	.0867	.0848	.104
2	.0754	1.0155	1.0364	1.0562	.0739	.056	.0572
3	.0943	1.0279	1.2955	1.166	.0762	.0572	.0572
4	.0953	1.0402	1.3599	1.2125	.0762	.0572	.0762
5	.0953	1.0526	1.4419	1.278	.0762	.0572	.0762
6	.1143	1.3763	1.5384	1.4255	.0953	.0943	.0754
7	.168	2.2211	2.0388	1.704	.1143		.1143
8	.1886	2.2298	2.3703	2.0885	.1524	.1132	.1509
9	.1658	2.2542	2.3807	2.1795	.1524	.0943	.1143
10	.1867	.0754	.132	1.8896	1.7532	1.757	.2155
11	.181	.0943	.1494	2.2377	2.0481	2.1879	1.989
12	.1867	.1132	.168	2.5194	2.1548	2.4143	2.3137
13	.2218		.168	2.4143	2.2542	1.5238	2.2466
14	.1886	.0943	.1698	2.4143	2.2542	2.0719	2.2131
15	.1867	.1698	.1698	2.4926	2.3137	2.2542	2.0957
16	.1886	.168	.1886	2.2542	1.7695	2.1216	2.1714
17	.1494	.168	.1698	2.0885	1.7204	.1509	2.3102
18	.1734	.2328	.2328	.0905	.1311	.124	.1372
19	.1663	.181	.1949	.168	.1387	.1612	.1509
20	.1646	.1791	.1753	.1663	.1433	.1595	.168
21	.181	.1612	.1578	.112	.124	.1478	.1478
22	.1433	.1402	.1417	.1063	.1052	.1463	.1433
23	.1402	.1372	.1372	.0886	.0995	.1075	.132
24	.12	.1372	.1174	.12	.0867	.0819	.1029
Max	.2218	2.2542	2.3807	2.5194	2.3137	2.4143	2.3137
Min	.0754	.0754	.1174	.0886	.0739	.056	.0572
Avg	.1541	.6263	.6695	1.3078	.7500	.6967	.7235

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 203 / 11 KV Landgewadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0762	.0572	.0572	.0381	.0381	.0381
2	.0381	.3763	.4428	.4531	.0381	.0381	.0381
3	.0381	.381	.5218	.4999	.0381	.0381	.0381
4	.0381	.3858	.6009	.5218	.0381	.0381	.0381
5	.0381	.3906	.6642	.5992	.0381	.0381	.0381
6	.0572	.6325	.6483	.6718	.0381	.0381	.0381
7	.0572	.8848	.9922	.7865	.0572	.0572	.0762
8	.0572	1.1469	1.1363	.9614	.0572	.0381	.0381
9	.0381	.9945	1.0722	1.0774	.0381	.0381	.0572
10	.0572	.0762	.0572	1.094	.7449	.7459	.7293
11	.0762	.0572	.0572	1.0111	.6554	.8619	1.094
12	.0762	.0572	.0572	.9945	.7748	.852	1.1271
13	.0762	.0572	.0572	1.0608		.852	.9945
14	.0572	.0381	.0572	1.0774	.9945	.9503	.9614
15	.0572	.0381		1.0608	.9945	1.0111	1.0442
16	.0572	.0381		1.0608	.9717	.9503	1.442
17	.0572	.0381	.0381	.9779	.9175	.9012	1.0442
18	.0762	.0572	.0762	.0739	.0572	.0572	.0762
19	.0953	.0953	.0762	.0953	.0762	.0762	.0953
20	.0762	.0953	.0762	.0762	.0762	.0762	.0953
21	.0762	.0953	.0762	.0572	.0572	.0572	
22	.0762	.0762	.0762	.0381	.0572	.0572	.0572
23	.0762	.0572	.0572	.0381	.0381	.0572	.0381
24	.0572	.0762	.0572	.0572	.0381	.0381	.0572
Max	.0953	1.1469	1.1363	1.094	.9945	1.0111	1.442
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.0611	.2592	.3162	.6001	.2972	.3294	.4024

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 204 / 11 KV Lingnoor Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1595	.2172	.1753	.1886	.1791	.2103	.1772
2	.884	.1867	.1509	.1698	.9755	.9686	.8383
3	.9877	.1867	.1509	.1698	1.0669	.9804	.8993
4	1.0031	.1886	.1698	.1698	1.0669	.9922	.9568
5	1.0467	.1886	.1886	.2075	1.2193	1.1385	1.012
6	1.2029	.2452	.2263	.2452	1.3123	1.2803	1.1142
7	1.6204	.2641	.2452	.2829	1.9662	1.5971	1.5043
8	1.9608	.2829	.3018	.2641	2.4413	2.0243	2.2939
9	2.1214	.2075	.2641	.2263	2.3922	1.9685	2.1376
10	2.3594	1.8884	2.1862	.2263	.2241	.1294	.1867
11	2.3482	2.3758	2.4531	.2452	.2614	.1663	.2241
12	2.2725	2.4905	2.7515	.2263	.2452	.2012	.2427
13	2.3967	2.4577	2.9165	.1848	.2641	.2054	.2427
14	2.4249	2.3594	2.7368	.1886	.2829	.2054	.2263
15	2.6216	2.4905	2.5587	.2075	.2452	.2054	.2241
16	2.4577	2.7526	2.4413	.2263	.2263	.2241	.2263
17	2.3594	2.6871	2.1956	.2452	.2452	.2641	.2641
18	.2587	.2172	.1629	.2534	.2926	.2195	.2957
19	.3361	.3174	.2715	.3361	.3174	.2987	.3206
20	.3174	.2587	.2561	.2987	.3142	.2801	.3018
21	.2587	.2587	.2587	.2033	.2772	.2587	.3018
22	.2172	.2402	.2614	.2172	.2507	.2378	.2402
23	.2172	.197	.2241	.2172	.2629	.197	.2218
24	.156	.2195	.1772	.2263	.1791	.2454	.1772
Max	2.6216	2.7526	2.9165	.3361	2.4413	2.0243	2.2939
Min	.156	.1867	.1509	.1698	.1791	.1294	.1772
Avg	1.3328	.9658	.9885	.2261	.6878	.6041	.6096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 205 / 11 KV Khatav Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3206	.3921	.5093	.4715	.3326	.3239	.415
2	.9054	.3584	.4527	.4338	1.0059	.8648	.8309
3	1.0059	.3584	.4715	.4527	1.2071	.8551	1.0852
4	1.2929	.3584	.4715	.4527	1.3413	1.0174	1.3077
5	1.4918	.3584	.4904	.4715	1.4754	1.4754	1.5424
6	1.6907	.415	.5093	.4904	1.7772	1.9448	1.9448
7	2.1216	.4338	.5658	.4904	2.0119	1.1568	2.1879
8	1.2407	.4338	.4854	.4527	2.2466	1.085	2.5194
9	1.3413	.3547	.3734	.547	2.3205	1.0059	2.2542
10	1.9227	1.8399	2.0222	.4805	.2801	.0943	.1886
11	2.3868	2.5232	1.2266	.4805	.3206	.2241	.2641
12	2.3868	2.6189	2.3537	.5228	.4108	.3361	.3395
13	2.2542	.7842	2.5526	.5601	.3921	.3734	.4481
14	2.42	1.7772	2.4863	.5544	.4024	.4481	.3018
15		2.3205	1.6575	.3018	.4066	.4294	.3734
16	2.42	2.6686	2.5526	.5914	.4066	.5228	.4108
17	2.3868	2.4863	2.4034	.6283	.2801	.4668	.415
18	.3361	.415	.4338	.5175	.3961	.4715	.4904
19	.4904	.7167	.4904	.679	.4527	.5281	.6036
20	.4527	.5658	.5281	.6413	.4527	.5093	.5281
21	.5281	.6036	.5281	.415	.4338	.5281	.4904
22	.4715	.5658	.5093	.3772	.415	.5093	.4527
23	.4338	.5281	.4904	.3395	.3961	.4527	.415
24	1.1205	.3961	.4904	.4904	.3395	.3772	.415
Max	2.42	2.6686	2.5526	.679	2.3205	1.9448	2.5194
Min	.3206	.3547	.3734	.3018	.2801	.0943	.1886
Avg	1.3661	1.0114	1.0439	.4934	.8127	.6667	.8427

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 201 / 11 KV Arag gav

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2033	.1886	.2075	.2263	.2263	.1867	.2075
2	.1848	.1886	.2075	.2075	.2075	.1886	.1886
3	.1886	.1886	.2075	.2075	.2075	.1886	.1886
4	.2075	.2075	.2075	.2075	.2075	.1886	.1886
5	.2534	.2075	.2452	.2263	.2452	.2263	.2075
6	.2896	.3018	.2829	.3018	.3395	.2658	.2829
7	.3012	.3961	.3772	.3206	.3658	.3366	.3772
8	.3403	.3696	.362	.3584	.3439	.3506	.3584
9	.3544	.3439	.3258	.3326	.3224	.3506	.3258
10	.3721	.4163	.3012	.3012		.3121	.2865
11	.3721	.3506	.2865	.2658		.3189	.3721
12	.3641	.298	.3012	.3294		.3544	.3294
13	.2774	.3086	.3045	.2947		.2774	.2743
14	.2572	.2401	.2507	.2774		.2601	.2713
15	.2572	.2947	.2629	.2601		.3155	.2713
16	.2865	.2947	.2915	.298		.3012	.3294
17	.3582	.298	.3155	.3506		.2915	.3721
18	.4298	.4784	.3898	.3898		.443	.3761
19	.4887	.4656	.4525	.4656		.4656	.3982
20	.4163	.4207	.4163	.4163	.4298	.3982	.4163
21	.3881	.3511	.3696	.3658	.3403	.3841	.3696
22	.3142	.3206	.3018	.2926	.2926	.2957	.3206
23	.2452	.2641	.2641	.2641	.2587	.2263	.2452
24	.2218	.2075	.2263	.2452	.2263	.2402	.2075
Max	.4887	.4784	.4525	.4656	.4298	.4656	.4163
Min	.1848	.1886	.2075	.2075	.2075	.1867	.1886
Avg	.3072	.3084	.2982	.3002	.2867	.2986	.2985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 202 / Arag mix Laxmiwadi
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3018	.3395	.3772	.132	.2829	.2829
2	.2641	.9012	1.0202	.9231	.132	.2641	.2641
3	.2641	1.0159	1.1336	1.004	.132	.2641	.2641
4	.2829	1.2616	1.3279	1.0883	.132	.2829	.2641
5	.3206	1.4091	1.4255	1.1363	.1509	.2829	.3018
6	.3395	1.668	1.6385	1.6409	.1886	.3395	.3584
7	.3395	2.2996	2.2377	1.8484	.2263	.3961	.415
8	.3395	2.6726	2.5692	2.3954	.2263	.3584	.2829
9	.2641	2.3158	2.7018	2.3765	.1886	.3206	.2641
10	.2829		.2452	2.3266		1.3763	1.7166
11	.3206		.3395	2.3537		1.757	1.9757
12	.3395	.1886	.3584	1.9334		2.0222	2.17
13	.3206		.1886	1.9919		1.8842	2.2024
14	.3206	.2641	.2829	2.1214		2.0388	2.2565
15	.3018	.3018	.2641	2.2283		1.9498	2.3365
16	.3206	.2641	.3206	2.2834		1.8515	2.3365
17	.3206	.3206	.3584	1.9062		1.7859	2.4413
18	.415	.3395	.3961	.2641		.2829	.3206
19	.4904	.4338	.5093			.3961	.3961
20	.5093	.415	.4904	.2075	.3961	.415	.3961
21	.4904	.415	.4715	.1886		.3772	.3961
22	.4527	.415	.415	.1698	.3584	.3395	.3395
23	.3961	.3772	.3961	.1509	.3206	.3018	.3018
24	.3206	.3584	.3584	.3772	.132	.3018	.2829
Max	.5093	2.6726	2.7018	2.3954	.3961	2.0388	2.4413
Min	.2641	.1886	.1886	.1509	.132	.2641	.2641
Avg	.3466	.8542	.8245	1.3606	.2089	.8280	.9403

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 203 / 11 KvAshoknagar

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1132	.0943	.1132	.0943	.1132	.1132
2	.6796	.1132	.0943	.1132	.7274	.7842	.6562
3	.1886	.1132	.0943	.1132	.7907	.8288	.7042
4	.7625	.1132	.0943	.1132	.8065	.8619	.7293
5	.8029	.1132	.1132	.132	.8802	.9054	.779
6	.9339	.132	.132	.1509	1.004	.9614	.8848
7	1.0322	.1509	.1509	.1509	1.6057	1.3923	1.3435
8	1.5729	.132	.1509	.1509	1.9227	1.5729	1.9227
9	1.749	.1132	.1132	.1509	1.9989	1.8515	1.8896
10	1.9044	1.4575	1.6712	.1698		.1132	.0943
11	2.13	1.8187	2.1136	.132		.132	.132
12	2.0317	2.0553	2.1464	.132		.1132	.1698
13	1.9109	1.989	2.1136	.132		.132	.1509
14	1.917	1.9498	2.0153	.1132		.1132	.132
15	1.8067	1.8842	2.1464	.1132		.1132	.1132
16	1.9062	1.9334	1.9989	.132		.132	.1132
17	1.8067	1.9271	1.9006	.132		.132	.132
18	.1698	.132	.1509	.1698		.132	.1509
19	.1886	.1886	.1698	.2263		.1698	.1886
20	.1886	.1886	.1698	.2075	.1698	.1698	.2075
21	.1886	.1698	.1698	.1698	.1509	.1698	.1886
22	.1698	.1509	.2075	.1509	.1509	.1509	.1509
23	.132	.0943	.1132	.1132	.132	.1132	.1132
24	.8753	.1132	.1132	.1132	.0943	.132	.1132
Max	2.13	2.0553	2.1464	.2263	1.9989	1.8515	1.9227
Min	.1132	.0943	.0943	.1132	.0943	.1132	.0943
Avg	1.0484	.7144	.7599	.1415	.7520	.4704	.4655

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 204 / railway station Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.0943	.1132	.1132	.0943	.1132	.0943
2	.4694	.0943	.1132	.1132	.4696	.4915	.4531
3	.4807	.0754	.1132	.1132	.4999	.5571	.4531
4	.4807	.0943	.132	.1132	.5376	.5967	.4586
5	.547	.0943	.132	.1132	.5693	.663	.4902
6	.6133	.132	.1698	.1698	.6874	.779	.5376
7	.7209	.132	.1698	.1509	1.0562	.9503	.7407
8	.8684	.0943	.1509	.1509	1.166	1.0978	.9122
9	.9555	.0943	.132	.1509	.5182	1.2125	.9646
10	1.0364	.8482	.8907	.1132		.0754	.0754
11	1.166	1.0688		.1132		.0566	.0943
12	1.1469	1.1469		.0943		.0566	.0943
13	1.1498	1.0437	1.0279	.0754		.0377	.0754
14	1.1984	1.0402	1.1043	.0754		.0377	.0566
15	1.1437	1.1043	1.0402	.0754		.0754	.0566
16	.8619	1.0722	1.0883	.0566		.0754	.0754
17	.8785	1.0242	.9762	.0943		.0566	.0754
18	.132	.132	.1509	.132		.1509	.132
19	.1886	.1698	.1698	.1509		.1509	.1509
20	.1509	.1698	.1698	.1509	.1509	.1509	.1886
21	.132	.1509	.1509	.132	.132	.132	.1509
22	.1132	.132	.132	.1132	.132	.1132	.132
23	.0943	.1132	.1132	.1132	.132	.0943	.1132
24	.1132	.0943	.132	.1132	.0943	.1132	.1132
Max	1.1984	1.1469	1.1043	.1698	1.166	1.2125	.9646
Min	.0943	.0754	.1132	.0566	.0943	.0377	.0566
Avg	.6148	.4257	.3806	.1163	.4457	.3266	.2787

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 205 / Malwadi Ag feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1132	.0943	.132	.0943	.1132	.0943
2	.0943	1.012	.8642	.8322	.0943	.0943	.0943
3	.0943	1.0753	.9122	.8322	.0943	.0943	.0943
4	.0943	1.1523	.9878	.8539	.0943	.0943	.0943
5	.132	1.2003	1.0562	.8855	.1132	.1132	.0943
6	.1698	1.4089	1.166	.9646	.1886	.132	.1509
7	.1698	1.8623	1.6032	1.4089	.1509	.1698	.1886
8	.1698	2.251	1.8623	1.6221	.1509	.1509	.1509
9	.1509	2.2283	2.0729	1.8023	.0943	.132	.1509
10	.1509	.1132	.1132	1.8564		1.5565	1.3765
11	.1509	.1132	.132	1.9271		2.0481	1.7924
12	.132	.1132	.132	2.0165		2.1136	1.8138
13	.1509	.0943	.132	2.0005		1.8947	1.8947
14	.132	.0943	.132	1.9524		1.9989	2.13
15		.132	.1509	1.9204		1.5708	1.9989
16	.1132	.0943	.132	2.0729		1.6032	1.9595
17	.0566	.1698	.1698	1.8842		1.5364	1.9334
18		.1886	.1886	.1886		.1698	.1698
19	.2075	.2263	.2263	.2075		.1886	.1886
20	.1698	.1886	.2075	.1886	.1886	.2075	.1698
21	.1509	.1698	.1886	.1698	.1886	.1698	.1698
22	.132	.1509	.1698	.1509	.1509	.132	.132
23	.1132	.1132	.1509	.1132	.132	.1132	.1132
24	.1132	.1132	.0943	.132	.0943	.1132	.1132
Max	.2075	2.251	2.0729	2.0729	.1886	2.1136	2.13
Min	.0566	.0943	.0943	.1132	.0943	.0943	.0943
Avg	.1346	.5991	.5391	1.0881	.1307	.6879	.7112

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244136 / 33/11kV SALGARE

Feeder No / Name : 201 / Salgare Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244136 / 33/11kV SALGARE

Feeder No / Name : 202 / Chabukswarwadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244136 / 33/11kV SALGARE

Feeder No / Name : 203 / Janraowadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 202 / 11 KV BHIVARGI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17
HR	Load (MW)
24	2.2672
Max	2.2672
Min	2.2672
Avg	2.2672

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 203 / 11 KV ANKALGI GAVTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-DEC-17
HR	Load (MW)
24	.1905
Max	.1905
Min	.1905
Avg	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 204 / 11 KV SANKH GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	.1905
Max	.1905
Min	.1905
Avg	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 205 / 11 KV ANKALGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17
HR	Load (MW)
24	2.4006
Max	2.4006
Min	2.4006
Avg	2.4006

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 206 / 11 KV ASANGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17
HR	Load (MW)
23	.181
24	.2715
Max	.2715
Min	.181
Avg	.2263

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 207 / 11 KV SANKH AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17
HR	Load (MW)
24	.2715
Max	.2715
Min	.2715
Avg	.2715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 201 / 11 KV AKKALWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17
HR	Load (MW)
24	1.5203
Max	1.5203
Min	1.5203
Avg	1.5203

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 202 / 11 KV BORGI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17
HR	Load (MW)
24	2.5396
Max	2.5396
Min	2.5396
Avg	2.5396

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 203 / 11 KV BALGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17
HR	Load (MW)
24	.2713
Max	.2713
Min	.2713
Avg	.2713

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 204 / 11 KV AKKALWADI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	.1829
Max	.1829
Min	.1829
Avg	.1829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 205 / 11 KV BORGI BALGAON
GAVTHAN Feeder KV- 11 /
OUTGOING

GAOTHAN FEEDER

DATE	01-DEC-17
HR	Load (MW)
24	.1905
Max	.1905
Min	.1905
Avg	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 201 / 11 KV SUSLAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.2801		.3734	.2218	.168	.2614
2	.2987	1.6194		2.2291		.1886	.3439
3	.3395	1.8861		2.2634	.2033	.2263	.3734
4	.3206	2.2939		2.2377	.2075	.3174	.4024
5	.3921	2.2672		2.3205	.2641	.2829	.3547
6	.5658	2.7854		2.3158	.3772	.3206	.4527
7	.5281	2.9984		2.8178	.4715	.3584	.4481
8	.5415	3.0639		2.753	.4527	.3772	.3921
9	.4854			2.6558	.3921	.3206	.3734
10	.4854		.3734	2.5101	1.6712	1.8884	1.5503
11	.4668		.3547	2.5101	1.9204	2.2222	1.9216
12			.3174	2.4939	2.1262	2.4646	2.3594
13	.5729		.3734	2.5911	2.2005	2.359	2.3122
14			.415	2.5101	2.2405	2.5301	2.4777
15			.3772	2.3594	2.3758	2.451	
16			.4715	2.5101	2.2405	2.5126	1.7436
17	.3547		.5041	2.1765	2.3365	2.2222	2.3137
18	.4668		.5041	.2721	.2865	.2439	.3189
19	.4715			.3475	.3258	.3206	.3511
20			.4527	.2926	.3696	.2743	.3174
21			.4108	.2772	.2829	.3206	.3292
22	.3206		.3734	.2587	.2054	.3772	.3142
23	.2829		.3734	.2402	.1886	.4207	
24	.2987	.2801		.3734	.2587	.1886	.3206
Max	.5729	3.0639	.5041	2.8178	2.3758	2.5301	2.4777
Min	.2829	.2801	.3174	.2402	.1886	.168	.2614
Avg	.4184	1.9416	.4078	1.7371	.9400	.9732	.9105

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 202 / 11 KV UMADI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2372	.0937		.0914	.112	.1619	.1718
2	.2721	.0937		.0937	.096	.1457	.208
3	.2591	.1094		.0937	.096	.1581	.1882
4	.2458	.1406		.1423	.144	.1718	.2286
5	.2656	.1562		.2241	.208	.1898	.2286
6	.2372	.2187		.2401	.2401	.2031	.25
7	.25	.25		.2778	.253	.2134	.2469
8	.2347	.208		.2469	.2241	.2229	.2143
9	.141			.1715	.1806	.1867	.1572
10	.1276		.16	.16	.1269	.1183	.1429
11	.1162		.12	.1286	.1166	.1143	.1593
12			.1181	.1715	.1238	.1463	.1269
13	.0823		.0827	.1738	.1425	.12	.1391
14			.08	.1738	.1463	.1536	.1097
15			.1105	.2027	.12	.1395	
16			.1417	.1593	.1349	.1463	.1299
17	.1417			.1882	.1829	.1532	.161
18	.2103		.2103	.2164	.2425	.2267	.184
19	.2782		.2572	.2561	.2667	.2503	.161
20			.286	.2267	.3144	.2258	.1509
21			.2469	.1957	.2201	.2006	.1446
22	.1337		.1406	.128	.1486	.216	.1555
23	.0892		.125	.112	.1524	.1957	.1709
24	.096	.0937		.1067	.1094	.1718	
Max	.2782	.25	.286	.2778	.3144	.2503	.25
Min	.0823	.0937	.08	.0914	.096	.1143	.1097
Avg	.1899	.1516	.1599	.1742	.1709	.1763	.1741

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 203 / 11 KV SONALGI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	.2926		.3174	.2987	.2829	.362
2	1.5623	.2743		.3206	1.7737	.5281	.7621
3	1.8671	.3475		.3584	2.0538	.6036	1.0479
4	2.4387	.3584		.415	2.3339	.7468	1.1317
5	2.6595	.4527		.4338	2.452	1.1317	2.7161
6	2.452	.4904		.4527	2.5149	2.6886	2.4006
7	2.8578	.5281		.4527	3.3951	3.062	3.296
8	1.8861	.5121		.4854	3.3951	3.3951	3.3532
9	2.6406			.5228	3.3951	1.3769	3.2007
10	2.2634		2.3339	.4854	.3921	.2614	.3361
11	2.2862		2.9874	.4481	.3734	.4706	.3206
12			2.894	.4854	.2641	.3696	.3361
13	2.7625		3.2065	.4854	.2829	.5487	.3547
14			3.2819	.4481	.2263	.462	.4108
15			2.6406	.5228	.2641	.4854	
16			2.4272	.5228	.3018	.499	.3658
17	3.2007		2.0538	.4854	.3734	.3511	.3801
18	.2957		.3511	.5359	.415	.4715	.3511
19	.3772		.3395	.4481	.4904	.5281	.3361
20			.3395	.4854	.5601	.4904	.3772
21			.3584	.3921	.4481	.415	.3921
22	.3475		.3361	.3734	.2829	.4527	.3584
23	.2926		.3361	.3361		.4904	.3361
24	.3018	.3109		.3361	.3361	.3772	.4338
Max	3.2007	.5281	3.2819	.5359	3.3951	3.3951	3.3532
Min	.2926	.2743	.3361	.3174	.2263	.2614	.3206
Avg	1.7162	.3963	1.7061	.4396	1.1575	.8537	1.0156

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 204 / 11 KV UMADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3467	.5117		.5556	.5719	.3163	.3353
2	.4001	1.4003		1.512	.5268	.3563	.3467
3	.421	1.2574		1.6804	.5201	.4191	.4344
4	.503	1.829		1.7718	.5719	.4111	.2841
5	.442	2.1948		1.949	.587	.3749	.3086
6	.4858	2.4806		2.1262	.7407	.4428	.823
7	.8078	2.8349		2.5606	.8642	.4999	.9783
8	.823	2.8586		2.5396	.9175	.6173	.9031
9	.8383			2.6459	.7926	.5556	.7827
10	.8322		.9568	2.4806	2.2662	2.0222	2.2314
11	.9031		.9568	2.3624	3.3532	1.9254	2.652
12			.9114	2.6558	2.6168	2.2405	2.9294
13	.8278		.7011	2.6949	2.332	1.7718	2.8125
14			.9114	2.7869	1.768	1.6217	2.8121
15			.7087	2.8132	2.4806	2.3548	
16			.6773	3.0498	1.5806	2.8467	2.1811
17	.7042		.6773	2.553	2.1491	2.3045	2.8041
18	.8535		.7468	.5796	.4458	.4207	.3814
19	.7716		.7716	.5944	.5868	.7316	.3269
20			.8333	.6321	.6874	.6173	.3374
21			.7716	.6554	.5668	.6859	.3121
22	.5639		.6173	.6249	.2972	.5268	.2972
23	.5487		.5556	.602	.3353	.4287	.3269
24	2.2405	.5117		.5864	.602	.3395	.3681
Max	2.2405	2.8586	.9568	3.0498	3.3532	2.8467	2.9294
Min	.3467	.5117	.5556	.5556	.2972	.3163	.2841
Avg	.7396	1.7643	.7712	1.7922	1.1734	1.0346	1.1291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 205 / 11 KV SUSLAD GAVTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.037		.0373	.0373		.0747
2	.0762	.0377		.0187	.0373		.1097
3	.0381	.0189		.0189	.0187		.0905
4	.0572	.0377		.0377	.0373		.0366
5	.0754	.056		.0943	.0747		.0754
6	.0943	.0934		.1132	.1132		.1132
7	.1143	.1307		.1132	.0943		.1132
8	.0754	.0943		.0943	.0943		.0914
9	.0189			.0754	.0549		.0829
10	.056		.052	.0377	.0381	.0537	.0625
11	.0373		.0347	.0377	.0566	.0446	.0503
12			.0175	.0566	.0373	.0316	.0366
13	.052		.0377	.0377	.0185		.0503
14			.0177	.0189	.0179		.0497
15			.0354	.0377	.032	.0625	
16			.0617	.0566	.0351	.08	.0556
17	.0829		.1189	.0566	.0914	.0937	.0926
18	.0724		.1337	.1254	.125	.1214	.125
19	.124		.1526	.1254	.1619	.1372	.1307
20			.1526	.0895	.1638	.0732	.0924
21			.1696	.1132	.0829	.0924	.0747
22	.0566		.056	.0377	.0648	.0724	.0543
23	.0354		.0373	.0373	.0492	.1097	.0732
24	.0381	.037		.0373	.0377		.0566
Max	.124	.1307	.1696	.1254	.1638	.1372	.1307
Min	.0189	.0189	.0175	.0187	.0179	.0316	.0366
Avg	.0645	.0603	.0770	.0628	.0656	.0810	.0779

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 201 / 11 KV MADGYAL AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1433	.1433	.2172	.1829	.1612	.1829	.1791
2	.6554	.1433	.181	.1829	.5937	.6478	.6468
3	.9831	.1448	.181	.1829	1.2498	1.2146	1.0898
4	1.1469		.1829	.2218	1.5623	1.6004	1.3413
5	1.3108	.2012	.4108	.3696	1.7185	1.7394	1.8442
6	1.6385	.3109	.5487	.5544	2.1348	1.5384	2.0576
7	2.2939	.3658	.6241	.5544	2.5606	2.0972	2.4291
8	2.1052	.2865	.5201	.3544	2.13	2.2721	2.6216
9	2.1052	.1791	.3544	.3544	2.2939	1.9433	1.2186
10	2.0805		1.3765	.1646	.1791	.2172	.1433
11	1.1203	1.5546	2.1052	.1448	.1254	.2195	.1463
12	1.5623	2.0972	2.2672	.1254	.1254	.2241	.1267
13	.9907	.9374		.1829	.128	.2263	.1254
14	2.0805	2.6852		.1829	.1267	.2263	.128
15		2.5911	2.332		.1463	.2263	.128
16		2.6852	2.3482		.181	.2241	.1267
17	1.5384	2.556	2.3891	.1254	.2218	.2241	.1463
18	.2195	.3258	.2149	.2149	.3898	.3506	.1829
19	.2561	.3982	.3189	.2686	.4572	.2103	.2378
20	.2507	.3582	.3506	.2686	.3696	.2103	.2378
21	.2149	.2926	.2629	.2149	.3439	.1753	.2012
22	.1791	.2126	.2126	.1791	.2865	.1753	.1646
23		.2126	.2126		.2195	.1753	
24	.1433	.1433	.2172	.2149	.1612	.1829	.1753
Max	2.2939	2.6852	2.3891	.5544	2.5606	2.2721	2.6216
Min	.1433	.1433	.181	.1254	.1254	.1753	.1254
Avg	1.0961	.8557	.8104	.2497	.7444	.6877	.6825

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 202 / 11 KV SONYAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3521	.0312	.0474	.048	.0312	.0324	.0324
2	.3201	.2372	.2214	.192	.0316	.0328	.0324
3	.3201	.4001	.2846	.3201	.0316	.0324	.0324
4	.4161	.4049	.4049	.3201	.032	.048	.0324
5	.6081	.4915	.5243	.3795	.0324	.0648	.0324
6	.6401	.4973	.6478		.0492	.0983	.0655
7	.6401	.7373	.8097	.6554	.0972		.0655
8	.7202	.6478	.7701	.6325	.0655	.096	.0492
9	.7202	.5506	.6401	.6478	.0324	.032	.0474
10	.6642		.0316	.6478	.3201	.4012	.3906
11	.6325	.0469	.0316	.6554	.5182	.463	.5601
12	.5376	.0625	.0312	.7287	.5182	.5068	.6325
13	.6009	.0625	.032	.6478	.506	.5068	.703
14	.0309	.064	.0324	.6478	.4687	.5068	.6249
15	.0316	.064	.0324	.6081	.4374	.5201	.6249
16	.0309	.0633	.0305	.6081	.463	.5335	.6249
17	.0312	.0316	.0286	.506	.4515	.5401	.5792
18	.0474	.0949	.0474	.032	.0648	.048	.0312
19	.064	.096	.08	.0486	.064	.048	.0474
20	.048	.0791	.08	.0486	.0486	.032	.048
21		.064	.048	.032	.0474	.0324	.0316
22	.0474	.0648	.048	.032	.032	.0324	.0316
23		.0648	.032		.0324	.0324	
24	.3521	.048	.048	.048	.0312	.032	.0324
Max	.7202	.7373	.8097	.7287	.5182	.5401	.703
Min	.0309	.0312	.0286	.032	.0312	.032	.0312
Avg	.3571	.2132	.2077	.3857	.1836	.2031	.2327

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 203 / 11 KV UTAGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0309	.048	.0648	.0648	.0457	.0469	.0474
2	.2286	.0486	.0648	.0324	.2972	.216	
3	.381	.0486	.0648	.0324	.4572	.4687	
4	.463	.0819	.081	.0819	.5335	.5535	
5	.5468	.1147	.1966	.1311	.6859	.6325	
6	.6249	.1638	.2458	.1966	.9012	.7125	
7	.9488	.1638	.2949	.2622	.9602	1.0364	
8		.1311	.2294	.1296	1.2003	.9069	
9	.8592	.1147	.1943	.1265	1.0155	.9259	.5716
10	.8383		.6173	.064	.0497	.0972	.0663
11	.7621	.7716	.7811	.0655	.0486	.0972	.0492
12	.9259	.8749	.9488	.0486	.0316	.0633	.0492
13	1.0031	.9686	1.0031	.0486	.0316	.0633	.0492
14	.9145	1.0753	1.0031	.0486	.048	.0625	.0497
15	.9374	1.0402	1.1717	.0486	.064	.0625	.0492
16	1.0031	.9145	1.2498	.0492	.0791	.0655	.0486
17	.9374	.8078	1.0623	.0655	.0949	.0655	.048
18	.1296	.1562	.16	.1147	.192	.1326	.1147
19	.1134	.1581	.1943	.116	.1898	.0829	.1311
20	.1147	.128	.1966	.116	.1094	.0819	.1296
21	.081	.096	.0983	.0781	.08	.0492	.096
22	.0486	.081	.0648	.0312	.0772	.0492	.0633
23		.081	.0648		.0625	.0474	
24	.0305	.048	.0648	.0648	.0463	.0469	.0474
Max	1.0031	1.0753	1.2498	.2622	1.2003	1.0364	.5716
Min	.0305	.048	.0648	.0312	.0316	.0469	.0474
Avg	.5419	.3529	.4216	.0877	.3042	.2736	.1007

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 204 / 11 KV SONYAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.1067	.0714	.0724	.1067	.0972	.08
2	.1067	.1067	.0867	.0724	.1067	.0823	.0781
3	.1372	.1189	.0876	.0724	.125	.0857	.0937
4	.1875	.144	.1097	.1158	.125	.1372	.1505
5	.2454	.1867	.1509	.1448	.1475	.1928	.1656
6	.2865	.2829	.2054	.1738	.197	.2772	.2408
7	.2896	.2402	.2957	.2054	.2195	.2957	.3045
8	.298	.2012	.2772	.1467	.2454	.1772	.2534
9	.1928	.1791	.2254	.132	.2012	.1696	.1738
10	.1524		.125	.1094	.1109	.1174	.125
11	.1097	.0926	.0914	.061	.1097	.1235	.1029
12	.0934	.0781	.0724	.1134	.1109	.1543	.0903
13	.08	.0781	.1014	.1134	.1294	.1543	.0869
14	.08	.0762	.1014	.1027	.0972		.0869
15	.0934	.0926	.1014	.0937	.0812		.0846
16	.096	.1372	.1158	.0937	.0892	.1372	.1097
17	.1303	.1448	.1448	.1189	.1158	.1677	.1692
18	.2286	.2343	.1738	.2343	.2187	.2439	.1932
19	.2343	.2656	.1738	.2343	.2656	.2286	.2031
20	.2372	.2429	.2027	.2214	.2315	.1829	.208
21	.1593	.192	.1738	.1593	.1718	.1389	.1635
22	.12	.1562	.1158	.12	.12	.1389	.12
23		.08	.1014		.1134	.1219	
24	.1067	.1067	.0823	.0724	.1067	.0983	.08
Max	.298	.2829	.2957	.2343	.2656	.2957	.3045
Min	.08	.0762	.0714	.061	.0812	.0823	.0781
Avg	.1634	.1541	.1411	.1297	.1478	.1601	.1462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 205 / 11 KV UTAGI VHASPETH

GAOTHAN FEEDER

GAVTHAN Feeder KV- 11 /
OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.0366	.056	.056	.0366	.056	.0566
2	.0549	.0366	.0566	.056	.0366	.0373	.0566
3	.0549	.0549	.056	.056	.0366	.0373	.0566
4	.0549	.0549	.056	.056	.0549	.0566	.0566
5	.0732	.0549	.0566	.056	.0554	.0739	.0754
6	.0914	.0876	.0747	.0934	.0914	.1132	.1132
7	.1097	.1097	.0943	.1132	.0914	.1132	.128
8	.0732	.0366	.0754	.1132	.0914	.0943	.0732
9	.1097	.0549	.0566	.1063	.0732	.0566	
10	.1097		.0905	.0914	.0914	.0724	.1097
11	.1097	.1075	.0905	.0914	.0914	.0724	.1097
12	.128	.104	.1063	.0492	.0924	.0648	.0914
13	.1097	.0905	.0693	.056	.1097	.0648	.0914
14	.0732	.1109	.052	.056	.1109	.0648	.0914
15	.0914	.1052	.0655		.112	.0543	.1097
16	.0914	.1029	.0655	.0554	.0732	.0543	.128
17	.128	.104	.0848	.0554	.0724	.0686	.0914
18	.112	.1254	.1052	.0924	.1097	.1109	.1294
19	.1109	.1307	.1086	.1109	.1307	.1109	.1478
20	.1097	.1132	.1267	.1097	.1109	.112	.1478
21	.0732	.0914	.1097	.0732	.0934	.0943	.1109
22	.0549	.0754	.0934	.0549	.0754	.0943	.0732
23		.0566	.056		.0754	.0943	
24	.0549	.0366	.0566	.056	.0549	.056	.0566
Max	.128	.1307	.1267	.1132	.1307	.1132	.1478
Min	.0549	.0366	.052	.0492	.0366	.0373	.0566
Avg	.0884	.0818	.0776	.0754	.0821	.0761	.0957

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 201 / 11 KV SIDHANATH AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1638	.1638	.1638	.1638	.2458	.1638	.1638
2	.8192	.1638	.1638	.1638	.4915	.4915	.8192
3	.8192	.1638	.1638	.1638		.4915	.8192
4	.8192	.1638	.1638	.1638		.4915	.8192
5	.9831	.1638	.1638	.1638		.9831	1.1469
6	1.4746	.1638	.1638	.1638		1.6385	1.6385
7	1.4746	.2458	.2458	.1638		1.7204	1.7204
8	1.6385	.1638	.2458	.1638	.6554	2.13	2.0748
9	1.6385	.1638	.1638	.1638	.8192	2.13	1.8023
10	1.8023	1.4746	1.6385	.1638	.5735	.1638	.2458
11	1.8023		1.6385	.1638	.1638	.1638	.2458
12	1.8023		1.9662	.1638	.1638	.1638	.2458
13	2.13	1.9662		.1638	.1638	.2458	.2458
14	2.13	1.9662	1.9662	.1638	.1638	.2458	.2458
15	1.6385	1.9662	1.9662	.1638	.2458	.2458	.2458
16	1.8023	1.9662	1.8023	.1638	.2458	.2458	.2458
17	1.8023	1.9662	1.8023	.1638	.2458	.2458	.2458
18	.1638	.1638	.1638	.1638	.2458	.2458	.2458
19	.1638	.1638	.1638	.2458	.2458	.2458	.2458
20	.1638	.1638	.1638	.2458	.2458	.2458	.3277
21	.1638	.1638	.1638	.1638	.2458	.1638	.1638
22	.1638	.1638	.1638	.1638	.1638	.1638	.1638
23	.1638	.1638	.1638	.1638	.1638	.1638	.1638
24	.1638	.1638	.1638	.1638	.1638	.1638	.1638
Max	2.13	1.9662	1.9662	.2458	.8192	2.13	2.0748
Min	.1638	.1638	.1638	.1638	.1638	.1638	.1638
Avg	1.0786	.6367	.6767	.1706	.2975	.5564	.6019

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 202 / 11 KV DARIKONUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0819	.0819	.0819	.0819	.1638	.0819	.0819
2	.0819		.3277	.3277	.1638	.0819	.0819
3	.0819	.2458	.3277	.3277	.1638	.0819	.0819
4	.0819	.3277	.3277	.3277	.1638	.0819	.0819
5	.0819	.3277	.3277	.4915	.1638	.0819	.0819
6	.1638	.6554	.6554	.6554	.1638	.0819	.1638
7	.1638	.8192	.9831	.6554	.1638	.1638	.1638
8	.0819	.9831	.9831	.9831	.1638	.0819	.0819
9	.0819	.9831	1.1469	1.3108	.1638	.0819	.0819
10	.0819	.0819	.0819	1.3108	.4915	1.1469	.6554
11	.0819	.0819	.0819	.6554	.8192	1.1469	.7373
12	.0819		.0819	.7373	.9831	1.1469	.8192
13	.0819	.0819	.0819	.7373	1.1469	1.1469	.9831
14	.0819	.0819	.0819	.6554	1.1469	1.1469	1.2289
15	.0819	.0819	.0819	.6554	1.1469	1.1469	1.1469
16	.0819	.0819	.0819	.7373	.8192	1.1469	1.1469
17	.0819	.0819	.0819	.7373	.9503	1.1469	.9831
18	.1638	.1638	.0819	.3277	.1638	.0819	.1638
19	.1638	.1638	.1638	.3277	.1638	.0819	.2458
20	.1638	.1638	.1638	.1638	.1638	.0819	.2458
21	.1638	.1638	.1638	.1638	.1638	.081	.1638
22	.0819	.0819	.1638	.1638	.0819	.0819	.1638
23	.0819	.0819	.0819	.1638	.0819	.0819	.1638
24	.0819	.0819	.0819	.0819	.1638	.0819	.0819
Max	.1638	.9831	1.1469	1.3108	1.1469	1.1469	1.2289
Min	.0819	.0819	.0819	.0819	.0819	.081	.0819
Avg	.1024	.2681	.2799	.5325	.4150	.4403	.4096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 203 / 11 KV SHEDYAL GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0566	.0566	.0566	.0566	.0566
2	.0566	.0566	.0566	.0566	.0566	.0566	.0566
3	.0566	.0566	.0566	.0566	.0566	.0566	
4	.0566	.0566	.0566	.0566	.0566	.0566	
5	.0566	.0566	.0566	.0566	.0566	.0566	.0566
6	.0754	.0566	.0566	.0566	.0566	.0566	.0754
7	.0754	.0943	.0943	.0943	.0566	.0943	.0754
8	.0566	.0566	.0566	.0943	.0566	.0566	.0566
9	.0566	.0566	.0566	.0509	.0566	.0566	.0566
10	.0566	.0566	.0566	.0509	.0566	.0566	.0566
11	.0566	.0566	.0566	.0509	.0566	.0566	.0377
12	.0566		.0566	.0566	.0566	.0566	.0377
13	.0566	.0492	.0566	.0566	.0566	.0377	.0566
14	.0566	.0566	.0509	.0377	.0566	.0377	.0566
15	.0566	.0566	.0509	.0566	.0566	.0377	.0377
16	.0566	.0566	.0566	.0566	.0566	.0566	.0566
17	.0566	.0566	.0566	.0566	.0566	.0566	.0566
18	.0943	.0943	.0566	.0943	.0943	.0566	.0566
19	.0943	.0943	.0943	.0943	.0943	.0943	.0943
20	.0943	.0943	.0943	.0943	.0943	.1132	.0943
21	.0943	.0943	.0943	.0943	.0943	.1132	.0943
22	.0492	.0566	.0566	.0566	.0566	.0943	.0943
23	.0492	.0566	.0566	.0566	.0566	.0754	.0566
24	.0566	.0566	.0566	.0566	.0566	.0566	.0566
Max	.0943	.0943	.0943	.0943	.0943	.1132	.0943
Min	.0492	.0492	.0509	.0377	.0566	.0377	.0377
Avg	.0638	.0645	.0624	.0645	.0629	.0645	.0626

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 204 / 11 KV SHEDYAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0848	.0819	.0819	.0848		.0819	.1696
2	.0848	.3277	.4915	.6783		.0819	
3	.0848	.3277	.4915	.8478		.0819	.1696
4	.0848	.3277	.4915	.8478		.0819	.1696
5	.0848	.6554	.8192	1.0174		.0819	.1696
6	.1696	1.8023	1.6385	1.3565			.1696
7	.1696	1.8023	1.9662	1.5261		.1638	.1696
8	.0848	1.8842	1.9662	1.6956		.0819	.1696
9	.0848	1.8842	1.6385	1.8652		.0819	.1696
10	.0848	.0819	.0819	1.8652	.8478	1.8023	1.6956
11	.0848	.0819	.0819	1.3565	1.6108	1.8023	1.8652
12	.0848		.0848	1.8652	1.8652	1.9662	1.8652
13	.0819	.0819	.0848	1.8652	1.9662	1.8652	1.95
14	.0819	.0819	.0848	1.6956	1.9662	1.8652	1.95
15	.0819	.0819	.0848	1.6956	1.7204	1.8652	2.0348
16	.0819	.0819		1.8652	1.3927	2.0348	2.2043
17	.0819	.0819	.0848	1.6108	1.3927	1.8652	1.8652
18	.1638	.1638	.0848		.1638	.1696	.1696
19	.1638	.1638	.1696		.1638	.1696	.2543
20	.1638	.1638	.1696		.1638	.1696	.2543
21	.1638	.1638	.1696		.1638	.1696	.1696
22	.0819	.0819	.1696		.0819	.1696	.1696
23	.0819	.0819	.0848		.0819	.1696	.1696
24	.1886	.0819	.0819	.0848		.0819	.1696
Max	.1886	1.8842	1.9662	1.8652	1.9662	2.0348	2.2043
Min	.0819	.0819	.0819	.0848	.0819	.0819	.1696
Avg	.1085	.4595	.4827	1.3235	.9701	.7349	.7889

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 205 / 11 KV DARIKONUR GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0566	.0566	.0566	.0566	.0566	.0377
2	.0377	.0566	.0566	.0566	.0566	.0566	.0377
3	.0377	.0566	.0566	.0566	.0566	.0566	.0377
4	.0377	.0566	.0566	.0566	.0566	.0566	.0566
5	.0566	.0566	.0566	.0566	.0566	.0566	.0566
6	.0566	.0566	.0566	.0566	.0566	.0566	.0566
7	.0566	.0943	.0943	.0566	.0566	.0943	.0566
8	.0566	.0566	.0566	.0566	.0566	.0566	.0566
9	.0566	.0566	.0566	.0566	.0566	.0566	.0566
10	.0566	.0566	.0566	.0566	.0566	.0566	.0566
11	.0566	.0566	.0566	.0566	.0566	.0566	.0566
12	.0566		.0566	.0566	.0566	.0566	.0566
13	.0566	.0566	.0566	.0566	.0566	.0377	.0377
14	.0566	.0566	.0566	.0377	.0566	.0377	.0377
15	.0566	.0566	.0566	.0377	.0566	.0377	.0566
16	.0566	.0566	.0566	.0566	.0566	.0377	.0566
17	.0566	.0566	.0566	.0566	.0566	.0566	.0377
18	.0943	.0943	.0566	.0943	.0943	.0566	.0566
19	.0943	.0943	.0943	.0943	.0943	.0943	.0566
20	.0943	.0943	.0943	.0943	.0943	.0943	.0943
21	.0943	.0943	.0943	.0943	.0943	.1132	.0566
22	.0566	.0566	.0566	.0566	.0566	.0754	.0566
23	.0566	.0566	.0566	.0566	.0566	.0754	.0566
24	.0566	.0566	.0566	.0566	.0566	.0566	.0377
Max	.0943	.0943	.0943	.0943	.0943	.1132	.0943
Min	.0377	.0566	.0566	.0377	.0566	.0377	.0377
Avg	.0597	.0648	.0629	.0613	.0629	.0621	.0527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 206 / 11 KV SIDDHANATH GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.0754	.0754	.2263	.0754	.0754
2	.0754	.0754	.0754	.0754	.2263	.0754	.0754
3	.0754	.0754	.0754	.0754	.2263	.0754	.0754
4	.0754	.0754	.0754	.0754	.2263	.0754	.0754
5	.0754	.0566	.0754	.0754	.2263	.0754	.0754
6	.0754	.0566	.0943	.132	.1886	.0754	.0754
7	.0754	.0943	.0943	.132	.1886	.0943	.0754
8	.0566	.0754	.0754	.0943	.0754	.0754	.0754
9	.0566	.0754	.0754	.0943	.0754	.0754	.0754
10	.0566	.0655	.0754	.0943	.0754	.0754	.0566
11	.0566	.0754	.0754	.0943	.0754	.0754	.0566
12	.0566		.0754	.0754	.0754	.0754	.0566
13		.0754	.0754	.0754	.0754	.0566	.0566
14	.0566	.0754	.0754	.0566	.0754	.0566	.0754
15	.0566	.0754	.0754	.0566	.0754	.0566	.0943
16	.0566	.0754	.0754	.0754	.0754	.0566	
17	.0566	.0754	.0754	.0754	.0754	.0754	.0943
18	.132	.132	.0943	.0943	.132	.0754	.132
19	.132	.132	.1509	.0943	.132	.1132	
20	.132	.132	.1509	.132	.132	.1132	.132
21	.132	.132	.1509	.132	.132	.1132	.1132
22		.0754	.0943	.0943	.0754	.1132	.0754
23	.0754	.0754	.0754	.1886	.0754	.0943	.0754
24	.0754	.0754	.0754	.0754	.2263	.0754	.0566
Max	.132	.132	.1509	.1886	.2263	.1132	.132
Min	.0566	.0566	.0754	.0566	.0754	.0566	.0566
Avg	.078	.084	.0880	.0935	.1320	.0801	.0797

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 207 / 11 KV DARIBADCHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677	.1829	.1638	.1638	.3277	.1638	.1677
2	.8383	.1638	.1638	.1638	1.6385	.6554	.8383
3	.8383	.1638	.1638	.1638	1.8023	.6554	.8383
4	.8383	.1638	.1638	.1638	1.6385	.6554	.8383
5	1.1736	.1638	.2458	.2458	1.8023	.9831	1.1736
6	1.6766	.2458	.3277	.3277	1.8023	1.6385	1.6766
7	1.8442	.3277	.4096	.3277	1.9662	2.13	1.7604
8	1.8442	.3277	.4096	.3277	2.13	2.13	1.8442
9	1.8442	.2458	.2458	.3277	1.9662	2.13	1.8442
10	1.8442	.9831	1.6385	.2458	.2458	.2458	.2515
11	2.0119	1.6385	1.9662	.2458	.2458	.1638	.2515
12	2.0119		2.13	.2458	.3277	.2458	.2458
13	1.9662	2.13	2.4577	.3277	.2458	.4191	.3277
14	1.9662	2.2119	2.4577	.3277	.2458	.4191	.2458
15	1.6385	2.2119	2.4577	.2458	.3277	.3353	.3277
16	1.8023	2.3758	2.13	.3277	.3277	.3353	.3277
17	1.8023	2.3758	1.3108	.3277	.3277	.3353	.3277
18	.3277	.3277	.2458	.2458	.3277	.4191	.3277
19	.3277	.3277	.2458	.4096	.3277	.3353	.3277
20	.3277	.3277	.2458	.3277	.3277	.3353	.3277
21	.3277	.3277	.2458	.4096	.3277	.3353	.3277
22	.2458	.2458	.2458	.2458	.2458	.2515	.3277
23	.1638	.1638	.1638	.1638	.1638	.2515	.3277
24	.2515	.1638	.1638	.1638	.1638	.1638	.1677
Max	2.0119	2.3758	2.4577	.4096	2.13	2.13	1.8442
Min	.1638	.1638	.1638	.1638	.1638	.1638	.1677
Avg	1.1700	.7738	.8500	.2697	.8022	.6555	.6425

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 208 / 11 KV MUCHANDI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1696	.1638	.1638	.1696	.2543	.1638	.1696
2	.1696	.4915	.4915	.6783	.2543	.1638	.1696
3	.1696	.4915	.5487	.8478	.2543	.1638	.1696
4	.1696	.4915	.4915	.8478	.2543	.1638	.2543
5	.1696	.6554	.8192	1.1869	.2543	.1638	.2543
6	.2543	.8192	1.6385	1.3565	.2543	.1638	.3391
7	.2543	1.6385	2.0481	1.5261	.2543	.2458	.3391
8	.1696		2.0481		.2543	.1638	.2543
9	.1886		1.6385	1.6956	.2543	.1638	.2543
10	.1696		.1638	1.6956	1.1869	1.4746	1.3565
11	.1696		.1638	1.6956	1.5261	1.4746	1.6956
12	.1696		.1696	1.8652	1.7804	1.6385	1.6956
13			.1696	1.8652	1.7204	1.6956	1.8652
14	.1638		.1696	1.6956	1.7204	1.6108	1.6956
15	.1638		.1696	1.4413	1.7204	1.6108	1.8652
16	.1638	.1638	.1638	1.6108	1.6385	1.6108	1.7804
17	.1638	.1638	.1638	1.5261	1.6385	1.5261	1.6108
18	.1638	.1638	.1638	.3391	.1638	.1696	.2543
19	.1638	.1638	.2458	.3391	.1638	.1696	.2543
20	.1638	.1638	.2458	.1696	.1638	.1696	.2543
21	.1638	.1638	.1638	.1696	.1638	.1696	.1696
22	.1638	.1638	.1638	.1696	.1638	.1696	.1696
23	.1638	.1638	.1638	.2543	.1638	.1696	.1696
24	.1696	.1638	.1638	.1696	.2543	.1638	.1696
Max	.2543	1.6385	2.0481	1.8652	1.7804	1.6956	1.8652
Min	.1638	.1638	.1638	.1696	.1638	.1638	.1696
Avg	.1753	.3891	.5222	1.0137	.6857	.6408	.7171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 201 / 11 KV TIKONDI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17
HR	Load (MW)
24	2.4966
Max	2.4966
Min	2.4966
Avg	2.4966

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 202 / 11 KV KONTEBOBLAD AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2515	.2035	.2402	.1715	.2241	.2614	.2033
2	.2347	.6036	.5256	.5487	.2195	.2561	.2241
3	.2347	.9282	.8551	.6783	.2195	.2587	.2241
4	.2347	1.1934	1.0059	.9496	.2218	.2743	.2427
5	.2374	1.4586	1.1797	1.1869	.2772	.3292	.2957
6	.3052	1.704	1.8138	1.6804	.3658	.3881	.3696
7	.39	2.3594	2.2939	2.2462	.4572	.462	.4251
8	.373	2.5911	2.7526	2.3663	.3658	.4572	.4108
9	.3521	2.6235	2.2024	2.3739	.3142	.3658	.2614
10	.3185	.2012	.2347	2.3908	1.4586	1.3763	1.4586
11	.3018	.3018	.0739	2.3739	2.2283	1.7238	
12	.3018	.3052	.2987	2.4143	2.2939	1.9662	1.8785
13	.2818	.2987	.2543	2.4813	2.2672	2.0972	2.2542
14	.3315	.3326	.2543		2.3482	2.2283	2.2939
15	.1989	.3361	.1341	2.1216	2.0553	2.0729	2.556
16	.218	.2801	.1509	2.3868	2.0972	1.9433	2.5194
17	.285	.2743	.1677	2.2708	2.1628	1.9662	2.2939
18	.3521	.3696	.2347	.2378	.3361	.2772	.2218
19	.407	.3658	.2713	.3658	.3881	.2957	.3292
20	.3222	.3292	.2374	.3326	.3326	.2957	.3292
21	.3052	.2926	.2035	.2772	.2926	.2614	.2772
22	.2374	.2587	.1865	.2402	.2926	.2614	.2241
23	.218	.2587	.1696	.2218	.2801	.2614	.2241
24	.2801	.2204	.2427	.1715	.2241	.2614	.2218
Max	.407	2.6235	2.7526	2.4813	2.3482	2.2283	2.556
Min	.1989	.2012	.0739	.1715	.2195	.2561	.2033
Avg	.2905	.7538	.6660	1.3256	.9051	.8476	.8582

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 203 / 11 KV PANDOZARI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2543	.2374	.2427	.2347	.2772	.2801	.2801
2	.3688	.2347	.2033	.2347	.5533	.4694	.431
3	.4527	.2515	.2195	.2321	.8048	.6133	.7956
4	.5533	.2515	.2743	.2486	.9892	.8215	.8785
5	.9496	.3521	.3658	.3315	1.2597	1.0562	1.0814
6	1.8482	.4409	.4163	.3688	1.5729	1.3435	1.491
7	2.5774	.5596	.6584	.4191	2.3922	2.2045	2.0809
8	2.431	.503	.6283	.4694	2.8673	2.4577	2.6235
9	2.3807	.4024	.4805	.4694	2.6543	2.2939	.9012
10	2.3137	1.5729	1.5061	.431	.2883	.2561	.0983
11	2.2045	2.2119	2.3205	.3978	.4024	.3174	.1865
12	2.4366	2.5069	2.5396	.3812	.4239	.3326	.3841
13	2.3266	2.6543	2.5888	.3856	.4458	.3142	.4668
14	2.4741	2.6189	2.556	.2683	.4481	.3511	.4805
15	2.1464	2.4034	2.5069	.2652	.4481	.3696	.5041
16	2.4863	2.2542	2.5692	.2984	.4805	.3547	.5487
17	2.1879	2.6699	2.3205	.3856	.4409	.3921	.5729
18	.3391	.3881	.3481	.4294	.439	.4668	.567
19	.39	.3881	.3856	.462	.4938	.462	.5359
20	.3018	.3292	.3353	.4251	.4024	.4251	.462
21	.2515	.3174	.285	.3658	.3511	.3511	.3881
22		.2801	.2515	.3292	.3142	.3174	.3292
23	.2204	.2801	.2515	.2926	.2614	.2987	.3292
24	.2987	.2374	.2614	.2515	.2957	.2801	.2957
Max	2.5774	2.6699	2.5888	.4694	2.8673	2.4577	2.6235
Min	.2204	.2347	.2033	.2321	.2614	.2561	.0983
Avg	1.3997	1.0144	1.0215	.3490	.8044	.7012	.6963

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 204 / 11 KV TIKONDI GAVTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0747	.056	.056	.056	.056	.056
2	.056	.0754	.056	.056	.056	.0554	.0566
3	.056	.0754	.0732	.0554	.0566	.0549	.0566
4	.056	.0934	.0739	.0739	.0754	.0732	.0754
5	.0943	.112	.0914	.1109	.0943	.1109	.112
6	.1509	.1494	.1829	.1307	.1494	.1646	.168
7	.1698	.2033	.1663	.1494	.2218	.1867	.1867
8	.1509	.1478	.128	.1494	.1848	.1494	.1478
9	.1307	.1109	.112	.1307	.1478	.1109	.1109
10	.112	.1294	.0914	.112	.1109	.0747	.0924
11	.0934	.0924	.0934	.0739	.0732	.0739	.0739
12	.0739	.0747	.0739	.0739	.0732		.0549
13	.0739	.0739	.0739	.0739	.0732		.0554
14	.0554	.0747	.0549	.0739	.0732	.0739	.0549
15	.0554	.0739	.0549	.0549	.0739	.0739	.0554
16	.0739	.0934	.0732	.0549	.0732	.0739	.0554
17	.0924	.0914	.1097	.0732	.0924	.1109	.0924
18	.1494	.1463	.1663	.1294	.1494	.1478	.1294
19	.1867	.1829	.1663	.9795	.1663	.1867	.1829
20	.2241	.1478	.1494	.1478	.1294	.168	.1463
21	.1509	.1109	.112	.1307	.112	.1494	.1294
22	.1132	.0747	.0934	.0934	.0934	.0924	.0934
23	.0747	.0739	.0747	.0747	.0739	.0739	.0747
24	.0566	.0747	.056	.0747	.0747	.056	.0739
Max	.2241	.2033	.1829	.9795	.2218	.1867	.1867
Min	.0554	.0739	.0549	.0549	.056	.0549	.0549
Avg	.1045	.1066	.0993	.1306	.1035	.1053	.0973

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 205 / 11 KV PANDOZARI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0381	.0381	.0381	.0381	.0381
2	.0381	.0381	.0381	.0381	.0381	.0381	.0381
3	.0381	.0381	.0381	.0381	.0381	.0381	.0381
4	.0381	.0572	.0572	.0572	.0572	.0572	.0572
5	.0572	.0762	.0572	.0572	.0572	.0762	.0572
6	.0953	.0953	.0762	.0953	.0953	.0953	.0953
7	.1143	.1334	.1143	.1143	.0953	.0953	.0953
8	.0762	.0762	.0953	.0953	.0762	.0953	.0953
9	.0572	.0572	.0572	.0953	.0572	.0572	.0572
10	.0381	.0381	.0572	.0381	.0381	.0381	.0381
11	.0381	.0381	.0572	.0381	.0381	.0191	.0191
12		.0381	.0381	.0191	.0381	.0191	.0381
13	.0191	.0381	.0381	.0191	.0191	.0191	.0381
14	.0191	.0191	.0381	.0191	.0381	.0191	.0191
15	.0191	.0191	.0191	.0191	.0191	.0191	.0191
16	.0191	.0381	.0381	.0191	.0191	.0381	.0191
17	.0381	.0381	.0572	.0191	.0191	.0381	.0381
18	.0762	.0572	.0953	.0762	.0572	.0762	.0572
19	.1334	.1143	.1143	.0953	.0953	.1143	.0953
20	.0762	.1143	.1143	.0953	.0953	.0762	.0762
21	.0572	.0953	.0762	.0762	.0572	.0572	.0572
22	.0572	.0572	.0572	.0381	.0381	.0572	.0572
23	.0381	.0572	.0572	.0381	.0381	.0381	.0381
24	.0381	.0381	.0381	.0572	.0381	.0381	
Max	.1334	.1334	.1143	.1143	.0953	.1143	.0953
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0530	.0588	.0611	.0540	.0500	.0524	.0514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 206 / 11 KV KAGNARI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012	.0339	.2033	.2035	.2033	.1494	.2054
2	.3481	.1526	.1829	.2035	.5765	.4527	.5365
3	.3978	.1526	.181	.2012	.7042	.5304	.7122
4	.4694	.1677	.2012	.218	.8215	.5967	.8139
5	.8383	.218	.2402	.2374	.9724	.8718	.9835
6	1.1568	.2515	.2402	.3052	1.2431	1.0814	1.1904
7	2.146	.4527	.4108	.3222	2.0972	1.9757	1.9113
8	2.1795	.4862	.4668	.373	2.3266	2.2611	2.0287
9	1.4582	.3052	.3921	.4239	2.2045	1.9559	.8648
10	1.8482		1.0486	.4409	.3052	.2561	.2378
11		1.8442	2.0885	.4748	.39	.462	.2033
12		1.326	2.343	.503	.4239	.5544	.462
13	1.8275	2.13	2.3594	.503	.5197	.5729	.5041
14	2.146	2.1548	2.2939	.4024	.5201	.5359	.5121
15	1.9784	2.2283	2.1033	.5087	.5249	.5853	.5487
16	1.9113	2.0885	2.3061	.5087	.2926	.567	.5544
17	1.8821	1.9826	2.1195	.5256	.1086	.5359	.5729
18	.2543	.2402	.2713	.5544	.2587	.4435	.439
19	.2883	.3142	.285	.4066	.2614	.3142	.3326
20	.2347	.2772	.285	.3475	.2402	.2957	.2772
21	.218	.2402	.2515	.2561	.2054	.2801	
22	.1696	.2241	.2347	.2195	.168	.2614	.168
23	.1696	.2218	.2204	.2033	.132	.2241	.168
24	.2241	.1526	.2218	.2204	.2033	.1494	.2218
Max	2.1795	2.2283	2.3594	.5544	2.3266	2.2611	2.0287
Min	.1696	.0339	.181	.2012	.1086	.1494	.168
Avg	1.0158	.7672	.8729	.3568	.6543	.6630	.6282

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 207 / 11 KV KAREWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.081	.0671	.0747	.081	.0739	.056	.0747
2	.081	.2294	.218	.2915	.0739	.0554	.0739
3	.08	.4096	.4588	.4696	.0739	.0549	.0739
4	.08	.4915	.5967	.6226	.112	.0724	.0739
5	.0972	.6062	.7127	.6554	.1294	.0732	.112
6	.1296	.7125	.852	.7956	.1848	.1294	.168
7	.1457	1.166	1.1469	1.0774	.2218	.1848	.1663
8	.1147	1.1984	1.2597	1.1271	.1867	.1848	.1478
9	.1147	1.085	1.004	1.1768	.1478	.1848	.1109
10	.1147	.0655	.1017	1.065	.3605	.8192	.6299
11	.1311	.0819	.112	.9831	.3277	1.1934	.6062
12	.1311	.0747	.112	1.0814		1.2616	1.1012
13	.0995	.1109	.0983	1.0486	.2818	1.3435	1.2763
14	.116	.1109	.0983	.7537	.2949	1.2308	1.2125
15	.0829	.0934	.0983	.9555	.3605	1.1498	1.0774
16	.1174	.1109		1.085	.8029	1.1142	1.3763
17	.1006	.112	.0972	1.1174	.2515	1.0814	1.3599
18	.0838	.1109	.1134	.0924	.0934	.0924	.1307
19	.1174	.128	.1311	.1478	.1494	.1109	.1478
20	.1187	.1109	.1311	.1478	.1478	.1109	.1294
21	.1017	.0924	.0983	.1097	.128	.0747	.0924
22	.0848	.0739	.081	.0914	.0914	.0747	.0739
23	.0671	.0739	.081	.0739	.0747	.0747	.0732
24	.0924	.0671	.0747	.081	.0739	.056	.0747
Max	.1457	1.1984	1.2597	1.1768	.8029	1.3435	1.3763
Min	.0671	.0655	.0747	.0739	.0739	.0549	.0732
Avg	.1035	.3076	.3370	.6304	.2019	.4493	.4318

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 201 / 11 KV SANMADI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953	.0953	.0953		.0953
2	.0953		.0953	.0791	.0953		.0953
3	.0953	.0953	.0953	.2458	.0953		.0953
4	.0953	.0953	.0953	.3239	.0953		.0953
5	.0953	.0953	.0953	.4321	.1905		.0953
6	.0953	.0953	.0953	.431	.1905		.0953
7	.1905	.1905	.0953	.1905		.0953	.1905
8	.1905	.1905	.1905	.1905	.0953	.0953	.0953
9	.1905	.1905	.0953	.1905	.0953	.0953	.0953
10	.0953	.0953	.0953	.0953	.0953	.0953	.0953
11	.0953	.0953	.0953	.0953	.0953	.0953	.0953
12	.0953	.0953	.0953	.0953	.0953	.0953	.0953
13	.0953	.0953	.0953	.0953	.0953	.0953	.0953
14	.0953	.0953	.0953	.0953	.0953	.0953	.0953
15	.0953	.0953	.0953	.0953	.0953	.0953	.0953
16	.0953	.0953	.0953	.0953	.0953	.0953	.0953
17	.0953	.0953	.0953		.0953	.0953	.0953
18	.0953	.0953	.0953	.0943	.1143	.0953	.0953
19	.0953	.0953	.0953	.0953	.0953	.0953	.1143
20	.0953	.0953	.0953	.0953	.0953	.0953	.1905
21	.0953	.0953	.0953	.0953	.0953	.0953	.0953
22	.0953	.0953	.0953	.0953	.0953	.0953	.0953
23	.0953	.0953	.0953	.0953	.0953	.0953	.0914
24	.0953	.0953	.0953	.0953	.0953		.1029
Max	.1905	.1905	.1905	.4321	.1905	.0953	.1905
Min	.0953	.0953	.0953	.0791	.0953	.0953	.0914
Avg	.1072	.1077	.0993	.1527	.1044	.0953	.1042

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 202 / 11 KV GHOLESHWAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0895	.0886	.0857	.0838	.1075	.0876	.0953
2	.12	.4641	.08		.1029	.0953	.0914
3	.1417	.426	.2949		.112	.0953	.0895
4	.1075	.4374	.3521		.1612	.0953	.0876
5	.1402	.442	.2968		.1543	.0953	.0905
6	.132	.4534	.3521		.1524	.0953	.1905
7	.132	.5847	.3163	.4961	.0914	.0934	.1334
8	.0953	.6767	.6241	.5155	.0934	.0943	.1143
9	.0953	.5441	.6562	.5468	.0943	.3125	.1132
10	.0953	.0943	.0914	.5376	.2439	.4321	.4012
11	.0934	.0943	.0914	.4999	.2709	.4572	.4586
12	.0934	.0934	.0924	.4744	.208	.506	.4902
13	.0934	.0914	.0914	.4801	.4915	.4588	.4586
14	.0943	.0943	.0905	.4641	.381	.4062	.427
15	.0943	.0943	.0905	.3277	.4374	.4161	.5155
16	.0934		.0914	.3521	.3953	.6554	.5624
17	.0924		.0914	.3549	.1075	.4725	.4268
18	.0943	.0886	.0886	.3258	.0934	.0943	.0943
19	.0895	.0886	.0876	.1086	.1097	.0895	.0876
20	.0876	.0914	.0914	.1075	.1097	.0857	.1075
21	.0934	.0886	.0934	.0943	.0943	.0943	.0943
22	.0943	.0943	.0876	.0857	.0895	.0953	.0895
23	.0914	.0914	.0895	.0895	.0876	.0895	.0857
24	.0953	.0886	.0876	.0857	.112	.0857	.0857
Max	.1417	.6767	.6562	.5468	.4915	.6554	.5624
Min	.0876	.0886	.08	.0838	.0876	.0857	.0857
Avg	.1021	.2414	.1839	.3174	.1792	.2293	.2246

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 203 / 11 KV KONIKUNUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012	.1406	.3353	.0914	.1097	.0857	.0943
2	.1753	.6478	.4475	.4858	.1543	.0943	.0895
3	.2614	.9488	.8539	.9831	.1867	.0857	.0905
4	.2126	.945	1.0322	.9922	.1829	.1052	.1494
5	.3696	1.0311	1.2334	1.0437	.1494	.1494	.1029
6	.2075	1.1305	1.3108	1.0608	.1524	.1698	.1905
7	.168	1.1961	1.2176	1.1305	.0876	.1311	.132
8	.168	.8002	1.2186	1.1363	.0983	.1307	.1132
9	.0934	1.3927	1.2483	1.142	.0848	.4287	.1097
10	.0876	.0876	.0886	1.1523	.2286	.8421	.8381
11	.0895	.0914	.0943	1.2803	.4062	1.2696	1.1523
12	.0914	.0895	.0934	1.4091	.8436	1.3108	1.4419
13	.0924	.0914	.0934	1.4091	1.4091	1.2811	1.4255
14	.0924	.0914	.0924	1.4255	1.2146	1.2631	1.4255
15	.1109	.0886	.0924	1.3443	1.1069	1.0936	1.3441
16	.1227	.0867	.0943	1.0517	1.2289	1.2163	1.278
17	.1214	.0848	.0953	1.1961	.1524	1.1822	
18	.1463	.1433	.1075	1.1641	.1265	.0895	.1097
19	.1612	.1402	.1494	.1052	.1311	.0838	.0876
20	.1829	.0914	.1402	.1433	.1029	.0895	.1433
21	.1402	.0934	.1478	.128	.112	.0943	.168
22	.128	.0934	.1475	.1715	.0857	.0895	.1829
23	.1612	.0819	.1341	.1433	.0876	.0857	.197
24	.1307	.1463	.096	.096	.1402	.0895	.0934
Max	.3696	1.3927	1.3108	1.4255	1.4091	1.3108	1.4419
Min	.0876	.0819	.0886	.0914	.0848	.0838	.0876
Avg	.1548	.4056	.4402	.8452	.3576	.4776	.4765

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 204 / 11 KV SANAMADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724	.0781		.0591	.0914	.0762	.0829
2	.096	.0772	.0753	.0572	.0876	.1543	.096
3	.1219	.0762	.0724	.0572	.1372	.1562	.0983
4	.1235	.0772	.0743	.06	.1357	.1638	.1017
5	.1147	.0791	.0705	.0781	.1357	.16	.1235
6	.1107	.0791	.0705	.0819	.1715	.1357	.0914
7	.1219	.0762	.0686	.0781	.1402	.1311	.112
8	.1355	.0743	.0676	.0772	.1433	.128	.2241
9	.1572	.0734	.0657	.0772	.1402	.1372	.2622
10	.1189	.1806	.0892	.0772	.1029	.0914	.0943
11	.2591	.2469	.1355	.0772	.0914	.0895	.0943
12	.2623	.2778	.2107	.0772	.0848	.0943	.0943
13	.2623	.2623	.2258	.0791	.0762	.0934	.0943
14	.2778	.2591	.2107	.0772	.061	.0895	.0943
15	.2469	.2408	.2258	.0819	.08	.0857	.0857
16	.2134	.1932	.2258	.08	.0857	.0648	
17	.2107	.2115	.2201	.0772	.0667	.0657	.0819
18	.0572	.0686	.1448	.0819	.0724	.0838	.0819
19	.0648	.0705	.0753	.08	.0705	.0819	.1006
20	.0667	.0724	.0753	.0762	.0743	.0762	.0914
21	.0869	.0743	.0743	.0629	.0734	.0838	.0467
22	.0686	.0676	.0724	.0895	.0819	.08	.0667
23	.0724	.0667	.0753	.0934	.0781	.0781	.0743
24	.0953	.0743	.0686	.0762	.0895	.0819	.0819
Max	.2778	.2778	.2258	.0934	.1715	.1638	.2622
Min	.0572	.0667	.0657	.0572	.061	.0648	.0467
Avg	.1424	.1274	.1172	.0755	.0988	.1034	.1032

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 205 / 11 KV GHOLESHWAR GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0934	.0886	.0914	.0876	.0895	.0943
2	.0876	.0953	.0943	.0943	.0914	.0953	.0895
3	.0895	.0895	.0876		.0876	.0953	.0934
4	.1772	.1867	.0857	.0934	.0934	.0895	.0857
5	.1753	.2743	.1791	.181	.1791	.1867	.1791
6	.2829	.2858	.1677	.2829	.2829	.2829	.1905
7	.2801	.2858	.1886	.1715	.0895	.1867	.2829
8	.1848	.1905	.1772	.1753	.0876	.1886	.1867
9	.1848	.181	.181	.1734	.0867	.0914	.0914
10	.0876	.0848	.0886	.1715	.0857	.0857	.0905
11	.0848	.0838	.0895	.0867	.0781	.0876	.0886
12	.0886	.0829	.0905	.0876	.0829	.1791	.0886
13	.0886	.0819	.0895	.0886	.08	.0876	.0914
14	.0895	.0838	.0886	.0905	.0876	.0943	.0943
15	.0895	.0838	.0886	.0857	.1829	.08	.0914
16	.1696	.0819	.0867	.0819	.1734	.0819	.0876
17	.1696	.16	.1715	.1677	.1791	.1658	.0876
18	.2515	.1638	.1791	.2458	.0857	.0848	.2601
19	.1638	.08	.1829	.1677	.0876	.1715	.1753
20	.1844	.0886	.1753	.16	.0934	.1753	.1715
21	.0895	.0876	.1829	.1867	.0943	.1848	.1886
22	.0943	.0934	.0857	.0914	.0895	.0914	.0895
23	.0895	.0876	.0876	.0934	.0876	.0857	.0905
24	.0953	.0914	.0914	.0895	.0857	.0895	.0895
Max	.2829	.2858	.1886	.2829	.2829	.2829	.2829
Min	.0848	.08	.0857	.0819	.0781	.08	.0857
Avg	.1412	.1299	.1262	.1373	.1108	.1271	.1283

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 206 / 11 KV NIGADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1433	.208	.1898	.1543	.168	.1372	.132
2	.1646	.5247	.3277		.1829	.132	.1791
3	.1867	.6554	.9831		.1991	.1791	.1578
4	.3506	.8482	1.0082		.1734	.2561	.1867
5	.3898	.8855	1.0623		.3544	.2987	.1867
6	.4527	1.1603	1.1469	.1543	.3961	.415	.4338
7	.3206	1.3757	1.2071		.2012	.3582	.3584
8	.2452	1.4752	1.3094	.6882	.2743	.3206	.3395
9	.2075	1.3435	1.2963	.9878	.2241	.2949	.2785
10	.0886	1.3435	.112	.639	.9393	.8259	1.094
11	.112	.0943	.0747		1.3748	.9755	1.278
12	.0914	.0943	.0754	.7011	1.278	1.3757	1.3592
13	.0914	.0943	.0943		1.2803	1.0648	1.4918
14	.0924	.0943	.1132		1.3272	1.0159	1.5249
15	.0924	.0943	.1132	1.134	1.1203	.9602	1.4582
16	.112	.0943	.1132	.8238	1.1934	1.0974	1.4089
17	.1494	.1132	.132	.6401	.1696	1.2452	1.4089
18	.2452	.1075	.2241	.2241	.2058		1.3672
19	.2561	.2241	.2926	.1753	.2507	.2054	.2263
20	.2149	.1753	.2103	.2987	.3292	.2743	.2328
21	.1715	.1463	.2012	.2075	.2075	.2641	.2263
22	.1698	.1509	.1829	.1646	.2149	.1791	.1791
23	.1829	.197	.168	.1663	.1715	.2241	.1578
24	.132	.2103	.1829	.1433	.1433	.1646	.1646
Max	.4527	1.4752	1.3094	1.134	1.3748	1.3757	1.5249
Min	.0886	.0943	.0747	.1433	.1433	.132	.132
Avg	.1943	.4879	.4509	.4564	.5158	.5332	.6596

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244109 / 33/11 KV LAVANGA

Feeder No / Name : 201 / 11 KV KONTEBOBLAD MIX
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1524	.1715	.1715	.1524	.1143
2	.1524	.663	.4321	.1524	.1715	.0953
3	.1334	.6706	.5304	.1905		.1143
4	.1524	.8383	.5668	.1715		.1334
5	.1715	1.0059	.7522	.1334		.1143
6	.1524	1.3413	1.085	.1715		.1334
7	.1905	1.8842	1.6164	.1715		.1524
8	.1715	1.6575	1.6964	.1905		.1715
9	.1715	1.6575	1.7238	.1334		
10	.1905	.1905	1.7124	.9922		.8619
11	.1524	.0953	1.7604	1.4918		.8619
12	.1715	.0953	1.7901	1.4746		1.326
13	.1905	.1143	1.4089	1.4746		1.4918
14	.1905		1.3592	1.0774		1.6575
15	.0953		1.5524	1.0526		1.8399
16	.1905		1.6164	1.065		1.9062
17	.1905		1.6741	1.2146		1.4918
18	.1905		.1715	.1334		.1905
19	.1905		.1334	.1334		.1715
20	.1905		.1334	.1524		.1524
21	.1905		.0953	.1905		.1715
22	.1905		.1715	.1524		.1715
23	.1524		.1524	.1715		.1524
24	.1905	.1524	.1334	.1334	.1524	.1143
Max	.1905	1.8842	1.7901	1.4918	.1715	1.9062
Min	.0953	.0953	.0953	.1334	.1524	.0953
Avg	.1723	.7513	.9350	.5165	.1588	.5909

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244109 / 33/11 KV LAVANGA

Feeder No / Name : 202 / 11 KV JALYAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	04-DEC-17	05-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1524	.2096	.1715	.1334
2	.1143	.7287	.3201	.2286	.1334
3	.0953		.3647	.2096	.1334
4	.1524		.4372	.2667	.1524
5	.1905		.5868	.2858	.1715
6	.2477	.9945	.8951	.2858	.1905
7	.3048	1.3765	1.2963	.3048	.2667
8	.2667	1.5061	1.4089	.2858	.2286
9	.2286	1.4746	1.3283	.2286	
10	.2096	.1524	1.3923	.8482	1.1271
11	.1905	.1524	1.4089	1.2643	1.3923
12	.2096	.1905	1.3603	1.3765	1.3592
13	.1905	.1524	1.0774	1.4575	1.4089
14	.1905		.9555	1.2955	1.4255
15	.1905		1.0242	1.2955	1.4586
16	.1905		1.1768	1.2146	1.4918
17	.1905		1.2803		1.442
18	.1905		.1905		.1715
19	.1715		.2286		.1524
20	.1905		.2477		.1715
21	.1905		.2096		.1715
22	.1905		.1905		.1524
23	.1524		.2096	.2667	.1524
24	.1524	.1524	.1905	.1905	.1524
Max	.3048	1.5061	1.4089	1.4575	1.4918
Min	.0953	.1524	.1905	.1715	.1334
Avg	.1889	.6394	.7496	.6376	.5930

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244109 / 33/11 KV LAVANGA

Feeder No / Name : 203 / 11 KV GIRGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	04-DEC-17	05-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.0953	.0762	.0572	.0953
2	.5601	.0953	.1143	.2785	.4973
3	.6401	.0953	.0953	.3647	.5304
4	.7287	.0953	.0953	.4049	.6133
5	.8097	.0953	.0572	.3521	.663
6	.9503	.1334	.0762	.7045	.7045
7	1.0814	.1905	.1334	1.1523	.7459
8	1.0978	.1905	.0572	1.2616	
9	1.1437	.1905	.1334	1.3927	
10	1.1934	.5668	.0762	.1334	.0953
11	1.2266	.9831	.0953	.0762	.0762
12	1.2597	1.1336	.0762	.0762	.0953
13	.9717	.9831	.0572	.0762	.1143
14	.9831		.0762	.0953	.1334
15	.9717		.0572	.0572	.1334
16	.8907		.0572	.0953	.1334
17	.8097		.0762	.0953	.1524
18	.0953		.0572	.0953	.1334
19	.0953		.0762	.0953	.1524
20	.0953		.0762	.0953	.1524
21	.1143		.0953	.0953	.1715
22	.1334		.0762	.1143	.1524
23	.1143		.1143	.1143	.1334
24	.1334	.1143	.0762	.0762	.0953
Max	1.2597	1.1336	.1334	1.3927	.7459
Min	.0953	.0953	.0572	.0572	.0762
Avg	.6756	.3545	.0826	.3067	.2625

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244109 / 33/11 KV LAVANGA

Feeder No / Name : 204 / 11 KV MORBAGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	04-DEC-17	05-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2858	.2096	.1905	.2286
2	1.0402	.2858	.1715	.5921	1.5746
3	1.2643	.3048	.1905	.7459	1.6575
4	1.4575	.3239	.2858	.7611	2.2377
5	1.6385	.3429	.3048	.9667	2.3205
6	1.9662		.3239	1.442	2.4577
7	2.7199	.4191	.4572	1.3603	2.4905
8	2.7846	.4191	.381	1.3094	2.9835
9	2.8178	.4191	.362	1.8623	
10	2.9172	2.0405	.2667	.2477	.1905
11	2.9504	2.6558	.3048	.2286	.1715
12	.8097	2.915	.2858	.2096	.1905
13	2.0165	3.2388	.2667	.2096	.1905
14	2.753		.2096	.2096	.2096
15	2.7664		.1905	.1905	.2096
16	2.5911		.2286	.1524	.2286
17	2.652		.3048	.1524	.2286
18	.1524		.2667	.1905	.2477
19	.1905		.2858	.1905	.2286
20	.2286		.362	.2858	.2667
21	.2477		.2477	.2858	.3048
22	.2858		.2667	.2286	.3239
23	.2858		.2477	.1905	.3048
24	.2667	.2858	.1524	.2286	.1905
Max	2.9504	3.2388	.4572	1.8623	2.9835
Min	.1524	.2858	.1524	.1524	.1715
Avg	1.5438	1.0720	.2739	.5180	.8451

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 201 / 11 KV KANKESHWAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.048	.048	.032	.048	.048	.048	.048
2	.8482	.8642	.7682	.048	.048	.048	.048
3	.8482	.8642	.7682	.048	.048	.048	.048
4	.8322	.8642	.7682	.048	.048	.048	.048
5	.8322	.9602	.8002	.048	.048	.048	.048
6	.9282	1.0082	.9122	.064	.048	.064	.064
7	1.1203	1.1843	1.0562	.08	.064	.08	.064
8	1.2163	1.3123	1.2323	.048	.048	.064	.048
9	1.2803	1.3603	1.2803	.048	.048	.048	.048
10	.032	.048	.0474	.032	.048	.032	.048
11	.032	.048	.0316	1.5203	1.6484	1.4883	1.2483
12	.032	.048	.0316	1.5524	1.6324	1.4723	1.2163
13	.032	.032	.0316	1.1203	1.6484	1.5844	1.2803
14	.048	.032	.0316	1.2803	1.5684	1.4883	1.3923
15	.0316	.032	.0316	1.5364	1.5364	1.5364	1.3763
16	.0474	.048	.0474	1.6004	1.5524	1.3123	1.3763
17	.0316	.032	.0474	1.5203	1.4403	1.2323	1.3283
18	.0474	.048	.0474	1.4883	1.4403	1.0562	
19	.0633	.064	.0633	.064	.064	.064	.08
20	.064	.048	.064	.064	.064	.064	.064
21	.064	.048	.064	.064	.064	.064	.064
22	.048	.048	.048	.064	.0492	.048	.064
23	.048	.048	.048	.048	.0492	.048	.048
24	.0497	.048	.048	.048	.048	.048	.048
Max	1.2803	1.3603	1.2803	1.6004	1.6484	1.5844	1.3923
Min	.0316	.032	.0316	.032	.048	.032	.048
Avg	.3594	.3807	.3459	.5201	.5542	.5014	.4390

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 202 / 11 KV MHAISHAL GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.3801	.3292	.2926	.3475	.3658	.4024
2	.3475	.3292	.2926	.2926	.3292	.3475	.4024
3	.3475	.3292	.2926	.2926	.2926	.3475	.4024
4	.3475	.3292	.2926	.2926	.2926	.3658	.4024
5	.3658	.3658	.3658	.3658	.4024	.439	.439
6		.4572	.439	.5304	.4938	.5487	.4938
7		.5304	.5853	.567	.567	.6767	.6036
8	.567	.4938	.5853	.5121	.5304	.5853	.5487
9	.5041	.4572	.4938	.4024	.439	.4938	.5304
10	.4668	.4024	.4938	.4024	.439	.4572	.4572
11	.4668	.3658		.4572	.3658	.4755	.4024
12	.5359	.4207	.567	.4207	.3658	.5487	.567
13	.5544	.4572	.5487	.4572	.4024	.5121	.5121
14	.3361	.4024	.4755	.4572	.3658	.4755	.6036
15	.3547	.4755	.4938	.439	.4755	.4755	.5304
16	.567	.4207	.5487	.4024	.5121	.5487	.567
17	.695	.5304	.6036	.4938		.6219	.6767
18	.7059	.5853	.6401	.6036	.7865	.8413	.7865
19	.8688	.8779	.8962	.7682	.9231	.8413	.8779
20	.7964	.8596	.8048	.7133	.7964	.7783	.7682
21	.6697	.7865	.6767	.6584	.7316	.7421	.7499
22	.543	.567	.5487	.5853	.5792	.5973	.6219
23	.3982	.4755	.4572	.439	.4525	.4755	.5121
24	.3658	.3801	.3841	.3292	.3658	.4024	.439
Max	.8688	.8779	.8962	.7682	.9231	.8413	.8779
Min	.3361	.3292	.2926	.2926	.2926	.3475	.4024
Avg	.5077	.4866	.5137	.4656	.4894	.5401	.5540

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 203 / 11 KV MAHAVEER AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.5138	.4475		.3481
3				.5138	.4475	.4144	.3481
4				.5138	.4475	.4144	.3647
5				.5138	.4475	.431	.3647
6				.5304	.4475	.4641	.3978
7				.5967	.5138	.4807	.431
8				.5801	.5801	.4973	.431
9				.5636	.6299	.5304	.4641
11	.7209	.8029	.8048				
12	.8048	.8029	.8718				
13	.8551	.8684	.9054				
14	.7907	.7865	.8886				
15	.779	.6554	.9389				
16	.7625	.7701	.9389				
17	.7373	.7701	.8551				
18	.7045	.7701	.7545				
Max	.8551	.8684	.9389	.5967	.6299	.5304	.4641
Min	.7045	.6554	.7545	.5138	.4475	.4144	.3481
Avg	.7694	.7783	.8698	.5408	.4952	.4618	.3937

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 204 / 11 KV NARWAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.064	.064	.064	.048	.048	.048	.048
2	.3795	.3681	.4961	.048	.048	.048	.048
3	.3795	.3681	.4961	.048	.048	.048	.048
4	.3795	.3681	.4961	.048	.048	.048	.048
5	.3953	.4481	.4961	.064	.048	.064	.048
6	.427	.4961	.5921	.08	.064	.064	.08
7	.6483	.7362	.8642	.096	.064	.064	.08
8	.9646	1.0402	1.0242	.08	.064	.08	.08
9	1.0753	1.1043	1.0242	.08	.08	.064	.08
10	.0633	.048	.0474	.064	.064	.048	.064
11	.0633	.064	.0633	1.0402	.7842	1.0562	.9922
12	.0633	.064	.0633	1.1203	.8322	1.1683	1.1843
13	.0633	.048	.0633	1.0722	.8162	1.0722	1.1363
14	.0474	.048	.0474	1.0402	.9922	.9922	1.1363
15	.0474	.064	.0791	1.0082	.9282	1.0082	1.2803
16	.0474	.064	.0633	.9602	.7842	.9762	1.2003
17	.0633	.064	.0474	.9442	.8162	.9282	1.2003
18	.0791	.08	.0633	.8322	.7362	.8322	1.0562
19	.1107	.096	.0949	.096	.0983	.08	.096
20	.112	.096	.096	.096	.0819	.0983	.096
21	.08	.096	.08	.096	.08	.0819	.096
22	.08	.064	.064	.08	.0655	.0819	.08
23	.064	.064	.064	.048	.0492	.064	.064
24	.064	.064	.064	.048	.048	.048	.048
Max	1.0753	1.1043	1.0242	1.1203	.9922	1.1683	1.2803
Min	.0474	.048	.0474	.048	.048	.048	.048
Avg	.2401	.2507	.2731	.3807	.3204	.3777	.4288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 205 / 11 KV MHAISHAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.081	.0648	.0648	.0648	.0648	.0648	.0648
2	.081	.0648	.0648	.9393	.8907	.9069	.7449
3	.081	.0648	.0648	.9393	.8907	.9069	.7449
4	.081	.0648	.0648	.9393	.8907	.9069	.7449
5	.081	.081	.0648	.9717	.9555	.9717	.7773
6	.0972	.0972	.0648	1.085	1.085	1.0688	.8097
7	.081	.081	.081	1.2793	1.4089	1.2955	.9231
8	.081	.081	.0648	1.4575	1.6032	1.4575	1.1012
9	.0648	.0648	.081	1.4413	1.668	1.6032	1.1984
10	.0972	.081	.0648	.0648	.0486	.0486	.0648
11	1.95	1.917	1.8461	.0486		.0486	.0625
12	.4144	1.9498	1.9595			.0648	.0648
13	2.1792	2.0317	1.9595	.0648		.0648	.0648
14	2.0481	1.9334	1.8461	.0648	.0648	.0648	.0486
15	1.9989	2.0481	1.8138	.0648	.081	.0648	.0648
16	2.0809	2.0481	1.7652	.0648	.0648	.0648	
17	1.9433	1.9006	1.749	.0648	.0648	.081	
18	1.749	1.4251	1.668	.0648	.0972	.081	.0648
19	.081	.081	.0972	.081	.0819	.081	.081
20	.081	.081	.081	.081	.0655	.0655	.081
21	.081	.081	.0972	.0648	.081	.0663	.081
22	.081	.0648	.081	.0648	.0655	.0655	.0648
23	.0648	.0648	.0648	.0648	.0655	.0648	.0648
24	.081	.0648	.0648	.0648	.0648	.0648	.0648
Max	2.1792	2.0481	1.9595	1.4575	1.668	1.6032	1.1984
Min	.0648	.0648	.0648	.0486	.0486	.0486	.0486
Avg	.6525	.6849	.6572	.4366	.4906	.4239	.3628

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 206 / 11 KV NARWAD GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0183	.0187	.037	.037	.037	.0185	.0185
2	.0183	.0373	.037	.037	.0185	.037	.037
3	.0183	.0187	.037	.037	.0185	.0185	.0185
4	.0183	.0187	.037	.037	.0185	.0185	.0185
5	.0183	.0187	.037	.037	.037	.0185	.0185
6	.0183	.0185	.037	.037	.037	.0185	.0185
7	.0183	.037	.037	.037	.037	.037	.0185
8	.0183	.0185	.037	.037	.037	.0185	.037
9	.0179	.037	.037	.037	.037	.037	.0185
10	.0358	.0185	.0185	.037	.037	.0185	.0185
11	.0179	.0185	.037	.037	.0373	.037	.0185
12	.0377	.037	.037	.037	.0373	.037	.0187
13	.0377	.0366	.037	.037	.0373	.037	.0187
14	.0377	.0185	.037	.0185	.0373	.037	.0187
15	.0377	.0183	.0185	.0185	.0373	.037	.0187
16	.0377	.0183	.037	.0185	.0373	.0185	.0187
17	.037	.0183	.0185	.0185	.0373	.037	.0187
18	.0358	.0366	.037	.0185	.0373	.037	.0373
19	.037	.037	.0185	.037	.037	.037	.0373
20	.0181	.037	.037	.037	.032	.037	.056
21	.0362	.0373	.0373	.037	.0373	.037	.0373
22	.0187	.037	.0373	.037	.0185	.037	.0373
23	.0373	.037	.037	.037	.0185	.037	.0373
24	.0366	.0187	.037	.037	.037	.0185	.037
Max	.0377	.0373	.0373	.037	.0373	.037	.056
Min	.0179	.0183	.0185	.0185	.0185	.0185	.0185
Avg	.0276	.0270	.0339	.0331	.0331	.0301	.0263

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 207 / 11 KV WATER WORKS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.052	.052	.0351	.0347	.0526	.0347	.0347
2	.052	.052	.0351	.0351	.0526	.0347	.0347
3	.052	.052	.0351	.0351	.0526	.0347	.0347
4	.052	.052	.0351	.0351	.0526	.0347	.0347
5	.052	.052	.0351	.0351	.0526	.0347	.0347
6	.052	.0532	.0354	.0351	.0526	.0347	.0347
7	.052	.0532	.0354	.0351	.0526	.0347	.0347
8	.052	.0532	.0354	.0351	.0526	.0347	.0347
9	.052	.0532	.0351	.0347	.0526	.0347	.0347
10	.0526	.0532	.0351	.0351	.0526	.0347	.0347
11	.0537	.1064	.0526	.0351	.0351	.052	.0347
12	.0354	.0532	.0526	.0351	.0351	.052	.0532
13	.0532	.0532	.0526	.0351	.0351	.052	.0532
14	.0532	.0351	.0526	.0351	.0351	.052	.0532
15	.0532	.0351	.0526	.0351	.0351	.052	.0532
16	.0351	.0351	.0526	.0351	.0526	.052	.0532
17	.0351	.0351	.0526	.0351	.0526	.052	.0532
18	.0347	.0347	.0526	.0351	.0526	.052	.0526
19	.0343	.0347	.0526	.0526	.0351	.0347	.0526
20	.0526	.0347	.0347	.0526	.0328	.0351	.0526
21	.0526	.0347	.0347	.0526	.0351	.0351	.0526
22	.0526	.0347	.0347	.0526	.0328	.0351	.0526
23	.0526	.0351	.0347	.0526	.0347	.0347	.0526
24	.0514	.052	.0351	.0347	.0526	.0347	.0347
Max	.0537	.1064	.0526	.0526	.0526	.052	.0532
Min	.0343	.0347	.0347	.0347	.0328	.0347	.0347
Avg	.0488	.0475	.0416	.0387	.0451	.0405	.0438

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 201 / 11 KV Dhavali Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191	.0191	.0191	.0191
2		.6874	.7459	.0191	.0191	.0191	.0191
3	.964	.7042	.7459	.0191	.0191	.0191	.0191
4	.964	.7122	.7459	.0191	.0191	.0191	.0191
5	.9991	.7202	.7459	.0191	.0191	.0191	.0191
6	1.1694	.823	.7956	.0191	.0191	.0191	.0191
7	1.0682	.9431	.7956	.0191	.0191	.0191	.0191
8	1.0343	1.0227	1.0288	.0191	.0191	.0191	.0191
9	.9945	.9496	1.0288	.0191	.0191	.0191	.0191
10	.0191	.0191	.0191	.0191	.0191	.0191	
11	.0191	.0191	.0191	1.3889	1.5089	1.7684	1.5775
12	.0191	.0191	.0191	1.358	1.5604	1.8204	1.5947
13	.0191	.0191	.0191	1.3748	1.6108		1.6461
14	.0191	.0191	.0191	1.3748	1.5592	1.7684	1.6118
15	.0191	.0191	.0191	1.4083	1.21		1.5947
16	.0191	.0191	.0191	1.4083	1.4575		1.6461
17	.0191	.0191	.0191	1.1736	1.4403	.763	1.6632
18	.0191	.0191	.0191	1.3226	1.4243	.9054	1.4922
19	.0191	.0191	.0191	.0191	.0191	.0191	.0191
20	.0191	.0191	.0191	.0191	.0191	.0191	.0191
21	.0191	.0191	.0191	.0191	.0191	.0191	.0191
22	.0191	.0191	.0191	.0191	.0191	.0191	.0191
23	.0191	.0191	.0191	.0191	.0191	.0191	.0191
24	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Max	1.1694	1.0227	1.0288	1.4083	1.6108	1.8204	1.6632
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.3260	.2862	.2891	.4631	.5032	.3491	.5701

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 202 / 11 KV Nilaji Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191	.0191	.0191	.0191
2	.0191	.0191	.0191	.7293	.6783	.5636	.0191
3	.0191	.0191	.0191	.7293	.6783	.6036	.4973
4	.0191	.0191	.0191	.7293	.6783	.6036	.4973
5	.0191	.0191	.0191	.7712	.6706	.6036	.4973
6	.0191	.0191	.0191	.8648	.7209	.7122	.4973
7	.0191	.0191	.0191	.9221	.8551	.9156	.6796
8	.0191	.0191	.0191	.9892	.9054	.9282	
9	.0191	.0191	.0191	.8215	.9389	.8951	.7045
10	.0191	.0191	.0191	.0191		.0191	.0191
11	1.643	1.4746	1.4746	.0191		.0191	.0191
12	1.3443	1.5074	1.531	.0191		.0191	.0191
13	1.3443	1.4377	1.4563	.0191		.0191	.0191
14	1.3443	1.5684	1.4563	.0191		.0191	.0191
15	1.3443	1.4377	1.419	.0191	.0191		.0191
16	1.3443	1.4003	1.4003	.0191	.0191	.0191	.0191
17	1.3443	1.3256	1.3817	.0191	.0191	.0191	.0191
18	1.3957	1.307	1.1128		.0191	.0191	.0191
19	.0191	.0191	.0191	.0191	.0191	.0191	.0191
20	.0191	.0191	.0191	.0191	.0191	.0191	.0191
21	.0191	.0191	.0191	.0191	.0191	.0191	.0191
22	.0191	.0191	.0191	.0191	.0191	.0191	.0191
23	.0191	.0191	.0191	.0191	.0191	.0191	.0191
24	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Max	1.643	1.5684	1.531	.9892	.9389	.9282	.7045
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.4754	.4902	.4807	.2975	.3335	.2657	.1608

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 203 / 11 KV Krishna Ghat

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.1494	.1478	.168	.168	.1524	.1829
2	.1448	.1494	.1478	.1494	.168	.1524	.1663
3	.1448	.1509	.1478	.1494	.168	.1524	.1663
4	.1448	.1509	.1478	.1494	.168	.0191	.1663
5	.2172	.1829	.1848	.2218	.1867	.1715	.1848
6	.2896	.2743	.2865	.2715	.2241	.2614	.2587
7	.3077	.3292	.2378	.3224	.2402	.3109	.2743
8	.3721	.3012	.3544	.333	.2561	.3012	.2865
9	.4161	.3681	.3681	.3012	.2865	.3155	.2835
10	.4578	.4024	.407	.4917	.362	.3772	.2126
11	.4801	.4191	.4287	.4748	.3561	.3772	.2279
12	.4748	.4578	.4578	.4641	.3561	.3772	.2774
13	.4409	.4527	.4527	.4359	.3185	.4024	.2572
14	.4287	.4239	.4191	.4024	.2622	.298	.2303
15	.4161	.373	.3561	.4024	.218	.2012	.2126
16	.4287	.4191	.407	.4024	.2454	.298	.2401
17	.4527	.4334	.4409	.4191	.2658	.1629	.2883
18	.3521	.4191	.3988	.3944	.2481	.2481	.2481
19	.2957	.3045	.333	.3814	.2587	.2926	.2743
20	.2772	.3189	.2686	.3506	.2587	.3077	.2218
21	.2241	.2743	.2715	.3142	.2241	.2896	.2218
22	.2054	.2241	.2218	.2054	.2075	.2587	.2075
23	.1867	.2012	.2054	.1867	.1698	.2378	.1886
24	.2027	.168	.1646	.1867	.168	.1509	.2172
Max	.4801	.4578	.4578	.4917	.362	.4024	.2883
Min	.1448	.1494	.1478	.1494	.168	.0191	.1663
Avg	.3128	.3062	.3023	.3158	.2410	.2548	.2290

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 204 / 11 KV Takali Bolwad Ag SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0943	.0943	.0934	.0943	.0943	.1132
2	.7545	.506	.6802	.0934	.0943	.0943	.0943
3	.7545	.5693	.6802	.0934	.0943	.0943	.0943
4	.7461	.5693	.6802	.0934	.0943	.0943	.0943
5	.763	.583	.6964	.132	.132	.0943	.132
6	.7956	.7209	.8322	.1698	.1509	.1509	.1698
7	1.0159	1.1469	1.1336	.1509	.1509	.1698	.168
8	1.247	1.4582	1.3272	.132	.132	.1307	.1494
9	1.3272	1.5238	1.5565	.1307	.132	.1509	.1109
10	.1307	.0655	.0905	.112	.1132	.1294	
11	.0934	.1132	.112	1.4582	1.3765	1.491	1.3599
12	.0934	.1132	.0924	1.4575	1.5384	1.5223	1.5074
13	.0914	.0943	.0905	1.4899	1.5684	1.5043	1.5546
14	.0739	.0914	.0914	1.4899	1.5043	1.4251	1.5061
15	.0747	.0732	.0914	1.4563	1.5061		1.5546
16	.0732	.0943	.0914	1.4563	1.5257		1.5384
17	.0716	.0934	.1109	1.4563	1.3927		1.5223
18	.1478	.1294	.1509	1.1984	1.2963		1.3765
19	.1698	.1509	.1509	.1886	.168	.1494	.1509
20	.1698	.1509	.1509	.1886	.1433	.1509	.1509
21	.1698	.1509	.1509	.1698	.1307	.132	.132
22	.132	.132	.132	.1509	.112	.1307	.1132
23	.1132	.0943	.1132	.132	.1132	.1307	.0943
24	.0943	.0943	.0943	.1132	.1132	.0943	.1307
Max	1.3272	1.5238	1.5565	1.4899	1.5684	1.5223	1.5546
Min	.0716	.0655	.0905	.0934	.0943	.0943	.0943
Avg	.3832	.3672	.3914	.5670	.5699	.3967	.6008

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 206 / 11 KV Dhavali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1698	.2075	.1886	.2075	.1886
2	.1698	.1886	.1698	.2075	.1886	.2075	.1886
3	.1698	.1886	.1698	.2075	.1886	.2075	.1886
4	.1698	.1886	.1698	.2075	.1886	.2075	.1886
5	.2452	.2075	.1698	.2452	.2452	.2075	.2263
6	.3018	.2829	.2452	.2829	.2829	.3018	.3018
7	.3584	.3584	.2641	.3206	.2829	.3395	.3395
8	.3395	.3206	.2452	.3206	.3018	.3395	.3018
9	.3018	.3018	.2452	.2075	.2641	.3018	.2829
10	.2641	.2263	.1698	.2263	.1886	.2452	
11	.2263	.2641	.1886		.2075	.2641	.2452
12	.2263	.2452	.2452	.2075	.1132	.2263	.2641
13		.2641	.1886	.2263	.1132	.1886	
14		.2452	.1886	.2263	.132	.1886	.2452
15		.2452	.1886	.2263	.1509		.2263
16	.2263	.2452	.1886	.2075	.1509	.2829	.2263
17	.2452	.2075	.2263	.2263	.1509	.1509	.2263
18	.3395	.2452	.3206	.3395	.3018	.3206	.3018
19	.3584	.3395	.3584	.3584	.3584	.3395	.3772
20	.3395	.3206	.3018	.3584	.3206	.3018	.3584
21	.3018	.2829	.2829	.3206	.3018	.2641	.3018
22	.2452	.2263	.2263	.2829	.2829	.2263	.2641
23	.2263	.2075	.2263	.2452	.2452	.2075	.2263
24	.2075	.1886	.1886	.2075	.2075	.2263	.1886
Max	.3584	.3584	.3584	.3584	.3584	.3395	.3772
Min	.1698	.1886	.1698	.2075	.1132	.1509	.1886
Avg	.2596	.2491	.2224	.2550	.2232	.2501	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 201 / Soni Gavathan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509		.132	.1509	.1509	.1698	.1509
2	.1509	.132	.1509	.1509	.1509	.1132	.1509
3	.1494	.132	.1509	.1509	.1494	.1132	.1509
4	.1509	.1509	.1509	.1509	.1494	.1509	.1698
5	.1886	.1886	.1698	.1698	.1867	.2075	.2075
6	.2427	.2614	.2241	.2452	.2614	.2427	.2829
7	.2801	.2801	.2987	.3206	.2987	.2641	.3206
8	.2427	.2241	.2427	.2614	.2614	.1698	.1867
9	.2054	.1867	.1867	.1829	.1867	.2075	.1991
10	.1867	.168	.1867	.1848	.1663	.168	.1629
11	.1494	.168	.168	.168	.1663	.1494	.1463
12	.1307	.168	.1494	.112	.1494	.1494	.1448
13	.1307	.1867	.1307	.1494	.0934	.168	.128
14	.1307	.1867	.1307	.1307	.1494	.1307	.1294
15	.1307	.1867	.1494	.1494	.1294	.112	.1463
16	.1307	.168	.168	.168	.1463	.1307	.1463
17	.1494	.2241	.1867	.1867	.1829	.1867	.1867
18	.2801	.2614	.2427	.2241	.2614	.2427	.2241
19	.3018	.3174	.3206	.3361	.3584	.3395	.3395
20	.3206	.3547	.3206	.3361	.3395	.3206	.3206
21	.2829	.2614	.2829	.2987	.3018	.3018	.3018
22	.1886	.2241	.2075	.2614	.2075	.2263	.2263
23	.1698	.1867	.1698	.2241	.132	.1698	.1698
24	.2366	.1509	.1509	.1509	.1886	.132	.1509
Max	.3206	.3547	.3206	.3361	.3584	.3395	.3395
Min	.1307	.132	.1307	.112	.0934	.112	.128
Avg	.1950	.2073	.1946	.2027	.1987	.1903	.1976

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 202 / 11 KV Bhose Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.132	.2075	.132	.2075	.2263	.1132
2	.1886	.132	.2075	.1132	.1886	.2075	.1132
3	.1886	.1698	.1886	.1132	.1886	.2075	.1132
4	.1886	.1886	.2075	.1698	.1886	.2075	.132
5	.1886	.2075	.2263	.2263	.2075	.1886	.1509
6	.1867	.3174	.2641	.3018	.2427	.1886	.1886
7	.2241	.1307	.2987	.3206	.3174	.2263	.2075
8	.1867	.2801	.2054	.2427	.2987	.2641	.2241
9	.2987	.2427	.2241	.3361	.3361	.2263	.2241
10	.3841	.2614	.2427	.2614	.2614	.3881	.3921
11	.3881	.4294	.2241	.1867	.2054	.2801	.3921
12	.3696	.4066	.3921	.1494	.2427	.3361	.4481
13	.4024	.4251	.112	.4294	.3174	.3921	.2054
14	.2587	.1307	.2801	.0187	.2801	.168	.1307
15	.4024	.2427	.2801	.2427	.3174	.2054	.4108
16	.439	.3174	.2054	.2427	.2987	.2801	.2801
17	.4755	.2801	.2801	.2054	.168	.2801	.4668
18	.3174	.2427	.3361	.2614	.3018	.1494	.3584
19	.2641	.2427	.2075	.2614	.2075	.2263	.3206
20	.2075	.2054	.2075	.2241	.2075	.1698	.2263
21	.2075	.1867	.2075	.2054	.2075	.1886	.2263
22	.2075	.2241	.1886	.168	.2075	.1698	.2263
23	.1698		.1698	.1867	.2263	.1509	.2263
24	.1509	.1509	.2263	.1509	.2075	.2263	.132
Max	.4755	.4294	.3921	.4294	.3361	.3921	.4668
Min	.1509	.1307	.112	.0187	.168	.1494	.1132
Avg	.2702	.2412	.2329	.2146	.2430	.2314	.2462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 203 / 11 KV Siddhewadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.0566	.0566	.0566	.0754	.0566
2	.1658	.1989	.2486	.0566	.0566	.0754	.0566
3	.1658	.2155	.2486	.0566	.0566	.0754	.0566
4	.1966	.2321	.2486	.0754	.0566	.0754	.0754
5	.2429	.2785	.2949	.0754	.0754	.0943	.0754
6	.2881	.426	.5441	.0943	.0934	.1132	.0943
7	.5761	.7449	.8162	.132	.112	.132	.1132
8	.7202	1.1012	1.1523	.112	.0747	.1132	.0934
9	.8802	1.2955	1.4083	.1307	.112	.0754	.112
10	.0934	.0747	.0934	.1307	.112	.0747	.112
11	.0934	.056	.056	1.2631	1.166	1.0883	.9878
12		.056	.056	1.2793	1.1984	1.1203	1.1174
13	.112	.056	.056	1.2308	1.1012	1.1203	1.1012
14	.0934	.056	.056	1.3117	1.0562	.1966	1.1012
15	.0934	.056	.056	1.2955	1.1523	1.0082	1.1012
16	.112	.056	.0747	1.085	1.085	1.1043	1.1012
17	.1307	.0747	.0934	1.166	1.1336	.9602	1.1822
18	.0934	.168	.1307	.9878	1.0202	.8962	1.0526
19	.1132	.1494	.1132	.112	.132	.1132	.132
20	.132	.1307	.1132	.1307	.132	.1132	.132
21	.1132	.112	.1132	.112	.1132	.132	.132
22	.0943	.0934	.0943	.112	.0943	.0943	.1132
23	.0943	.0747	.0754	.0934	.0754	.0754	.0754
24	.0754	.0943	.0566	.0754	.0754	.0754	.0566
Max	.8802	1.2955	1.4083	1.3117	1.1984	1.1203	1.1822
Min	.0754	.056	.056	.0566	.0566	.0747	.0566
Avg	.2067	.2448	.2607	.4656	.4309	.3751	.4263

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 204 / Soni AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.1132	.0943	.0943	.0377	.0754	.0754
2	.2401	.2486	.2652	.0943	.0377	.0754	.0754
3	.2486	.2486	.2652	.0943	.0377	.0754	.0754
4	.2458	.2622	.2652	.1132	.0377	.0754	.0943
5	.3239	.3277	.3277	.132	.0377	.0943	.132
6	.4321	.5571	.5601	.1509	.0377	.132	.1698
7	.6241	.8907	.8802	.2075	.0373	.2263	.1698
8	.8642	.9231	1.0242	.168	.0566	.1698	.1494
9	1.0402	1.1498	1.0242	.2054	.0934	.1886	.168
10	.1494	.1494	.168	.1494	.1307	.2241	.1867
11	.1494	.1867	.1867	.8907	1.247	.9922	1.0202
12	.168	.1867	.2241	1.0688	1.3765	1.0883	1.1012
13	.168	.2054	.0747	1.004	1.2146	1.1523	1.1012
14	.168	.2054	.0934	.9878	1.1363	1.0883	1.0688
15	.168	.2054	.168	1.004	1.1523	1.0402	1.166
16	.1867	.2241	.2054	1.004	1.1498	1.0883	1.1012
17	.2054	.2241	.2241	.2753	1.1363	1.1363	1.1822
18	.2241	.2241	.2241	.2012	1.004	1.0722	.6316
19	.1698	.2054	.2075	.056	.132	.1886	.1698
20	.1698	.1867	.1698	.056	.132	.1509	.1509
21	.132	.1494	.1509	.056	.1132	.132	.132
22	.1132	.1307	.132	.0373	.0943	.0943	.1132
23	.1132	.112	.1132	.0373	.0943	.0943	.1132
24	.0943	.1132	.0943	.0943	.0377	.0943	.0754
Max	1.0402	1.1498	1.0242	1.0688	1.3765	1.1523	1.1822
Min	.0943	.112	.0747	.0373	.0373	.0754	.0754
Avg	.2705	.3096	.2976	.3409	.4402	.4479	.4343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 206 / 11kv Karoli AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1509	.132	.132	.132	.132	.1509
2	.1989	.2652	.2347	.132	.132	.132	.1509
3	.1989	.2818	.2683	.132	.132	.132	.1509
4	.2458	.3149	.2683	.1698	.132	.1509	.1698
5	.3563	.3768	.3605	.2263	.1698	.2075	.1886
6	.4481	.6718	.7362	.3018	.2801	.3018	.2641
7	.7682	1.2308	1.0402	.3395	.3361	.3395	.3206
8	.9602	1.4899	1.4883	.3361	.2987	.1132	.3174
9	1.1043	1.6518	1.5203	.2614	.2614	.2075	.2054
10	.2054	.1307	.1494	.2241	.2054	.1494	.1867
11	.1867	.1307	.1867	1.0688	1.1822	1.0562	1.1984
12	.168	.168	.1867	1.3279	1.2308	1.2163	1.2308
13	.168	.1867	.1307	.0753	1.2793	1.2483	1.1498
14	.2054	.168	.1867	1.2631	1.2003	1.1203	1.247
15	.2054	.2054	.1867	1.2631	1.2323	1.1683	1.4089
16	.2054	.2427		1.2793	1.1498	1.1843	1.2955
17	.1867	.2241	.168	.9069	1.1203	1.0562	1.3117
18	.2987	.2241	.2241	.9717	.9878	1.0082	1.2308
19	.3018	.2801	.2829	.2241	.2829	.2829	.2829
20	.2829	.2987	.2641	.2987	.2829	.2452	.2641
21	.2452	.2427	.2452	.2241	.2263	.2075	.2452
22	.2075	.2054	.1886	.2054	.1698	.1698	.2263
23	.1886	.1509	.1698	.1867	.132	.1698	.1509
24	.2366	.1698	.1509	.1509	.1509	.132	.1509
Max	1.1043	1.6518	1.5203	1.3279	1.2793	1.2483	1.4089
Min	.1509	.1307	.1307	.0753	.132	.1132	.1509
Avg	.3218	.3942	.3813	.4875	.5295	.5055	.5624

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 207 / 11KV Bhose AG Spare
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.0943	.0754	.0943	.0754	.0943	.0943
2	.132	.0943	.0943	.8745	.8848	.7459	.7701
3	.132	.0943	.0943	.8848	.8848	.7625	.7865
4	.132	.0943	.0943	.9503	.9393	.7865	.852
5	.1509	.132	.0943	1.004	1.0364	.8192	.9231
6	.1494	.1307	.112	1.1984	1.2163	1.004	1.166
7	.1494	.1494	.1307	1.6194	1.7604	1.4575	1.5384
8	.168	.1494	.1494	1.9109	2.1445	1.8947	1.9271
9	.2054	.1494	.168	2.2024	2.1925	2.2024	2.17
10	.1494	.1494	.1867	.1307	.0934	.0934	.0934
11	2.2565	2.4615	2.4326	.112	.112	.0934	.0747
12	2.3045	2.6886	2.4615	.1307	.112	.0934	.1494
13	2.4966	2.4966	1.6484	.1307	.1307	.112	.1307
14	2.8006	2.5766	1.7976	.1307	.112	.112	.1307
15	2.5446	2.2245	1.6356	.1307	.1494	.112	.112
16	2.4326	2.6886	2.7366	.1307	.112	.112	.1494
17	2.2245	2.6406	2.5101	.1307	.0934	.1307	.168
18	1.9204	2.2085	2.2834	.1307	.1307	.1494	.1509
19	.0943	.112	.1509	.1307	.1494	.1494	.1509
20	.1132	.1307	.1509	.1494	.1509	.1509	.132
21	.1132	.112	.132	.112	.1509	.1509	.132
22	.0943	.112	.0943	.0934	.132	.132	.1132
23	.0943	.0934	.0943	.0934	.1132	.1132	.0943
24	.132	.0943	.0943	.0943	.0754	.1132	.0943
Max	2.8006	2.6886	2.7366	2.2024	2.1925	2.2024	2.17
Min	.0943	.0934	.0754	.0934	.0754	.0934	.0747
Avg	.8801	.9116	.8092	.5237	.5397	.4827	.5043

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 201 / 11 KV Savali Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1307	.1494	.1494	.1494	.1494	.1494
2	.168	.1294	.1494	.4435	.1663	.3734	.5228
3	.1867	.128	.1494	.6535	.2957	.5601	.6348
4	.1886	.1294	.1494	.6468	.8962	.7095	.7095
5	.2241	.1307	.1494	.7095	.9808	.7842	.7468
6	.2241	.1829	.168	.7023	1.1203	.8962	.8215
7	.2241	.2218	.2427	1.0829	1.307	1.3817	1.2696
8	.1848	.2427	.2614	1.4415	1.4784	1.6057	1.419
9	.1829	.2218	.1867	1.6263	1.6095	1.643	1.5684
10	.2587	.2218	.2241	.1307	.1478	.1509	.1698
11	.8871	1.7741	1.7737	.1494	.168	.1867	.168
12	1.2197	.9979	1.8671	.168	.1867	.1509	.1509
13	1.6804	1.7924	1.1203	.1867	.1867	.1698	.1307
14	1.848	1.7187	1.5684	.168	.1698	.168	.132
15		1.6632	1.6804	.1494	.1494	.1886	.1494
16	1.5729	1.7741	1.7924	.1494	.1509	.168	.1509
17	1.6632	1.7924	1.7364	.168	.1494	.168	.1867
18	1.6632	1.643	1.5524	.1886	.2241	.1886	.1132
19	.2241	.2241	.2241	.2614	.2427	.2263	.1307
20	.2195	.2241	.2218	.2263	.2241	.2241	.1307
21	.2218	.2241	.2195	.2241	.2241	.2241	.1109
22	.1867	.168	.1867	.1867	.1867	.1867	.0934
23	.1829	.1494	.1463	.1494	.168	.168	.0754
24	.0953	.1848	.1494	.1463	.1494	.1494	.1494
Max	1.848	1.7924	1.8671	1.6263	1.6095	1.643	1.5684
Min	.0953	.128	.1463	.1307	.1478	.1494	.0754
Avg	.5946	.6696	.6695	.4212	.4471	.4509	.4118

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 202 / 11 KV SAIPRASAD

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.5487	.5415	.4854	.4715	.4668	.5228
2	.4668	.5487	.5228	.4805	.4527	.4854	.4854
3	.4668	.5544	.5415	.4755	.4481	.4668	.5228
4	.4904	.5175	.5228	.4805	.4715	.4668	.5093
5	.4904	.5228	.5228	.4854	.4668	.4854	.5228
6	.5041	.4938	.4854	.4805	.4904	.4481	.4854
7	.5228	.439	.4854	.4481	.5544	.4668	.5041
8	.5544	.4805	.5041	.4572	.5601	.4668	.5228
9	.5853	.5041	.5601		.4805	.5601	.5415
10	.7577	.7762	.7282	.5975	.4668	.7167	.5658
11	.8501		.6908	.6722	.5175	.8029	.6036
12	.8501	.9145	.8402	.8215	.5487	.7545	.6722
13	.695	.9054	.7095	.7655	.5175	.7468	.7095
14	.7577	.8962	.8962	.6535	.5281	.7167	.7167
15		.8871	.8962	.5335	.4854	.6722	.7468
16	.8413	.7392	.8775	.6535	.4805	.7545	.7167
17	.8501	.7842	.8215	.7095	.5041	.7842	.6908
18	.7023	.7842	.7023	.5975	.5041	.7545	.679
19	.5415	.5788	.5601	.5658	.4668	.6036	.7282
20	.5487	.5601	.5175	.5228	.4668	.5601	.6036
21	.5544	.5041	.4527	.5281	.4668	.5415	.5415
22	.5975	.5041	.4805	.4854	.4481	.5788	.5093
23	.5914	.5228	.4854	.4715	.4294	.5415	.5228
24		.5914	.5228	.4755	.4668	.4668	.5601
Max	.8501	.9145	.8962	.8215	.5601	.8029	.7468
Min	.4668	.439	.4527	.4481	.4294	.4481	.4854
Avg	.6231	.6329	.6195	.5585	.4872	.5962	.5910

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 203 / 11 KV Savali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.1097	.1307	.1294	.1867	.1307	.1307
2	.1307	.1097	.1307	.1307	.132	.1307	.1307
3	.1509	.1109	.1307	.1294	.1494	.1307	.1307
4	.1509	.1109	.1307	.128	.1494	.1307	.1307
5	.168	.112	.1307	.1463	.1698	.132	.1307
6	.168	.1494	.1307	.1848	.1886	.168	.1494
7	.1663	.1848	.2054	.2054	.168	.1867	.2241
8	.1848	.1663	.168	.1867	.168	.2241	.1867
9	.1829	.168	.168	.1829	.1478	.1494	.168
10	.2033	.168	.1867		.128	.1509	.1494
11	.1848	.1663	.168	.056	.0924	.1494	.1509
12	.1663	.1663	.168	.168	.0747	.1698	.168
13	.1307	.168	.1307	.1494	.0924	.1509	.1698
14	.1478	.1663	.1867	.1494	.0914	.168	.1494
15		.128	.168	.1494		.1698	.1509
16	.1478	.1663	.1307	.1307	.0934	.1867	.1307
17	.1867	.168	.168	.1867	.132	.1848	.1663
18	.2402	.2054	.2033	.2263	.2452	.2241	.1867
19	.2614	.2987	.2614	.2641	.2641	.2614	.2801
20	.2561	.2801	.2402	.2801	.2241	.2587	.2614
21	.2218	.2241	.2195	.2829	.2241	.2054	.2033
22	.1848	.168	.1663	.2987	.168	.168	.1867
23	.168	.1307	.1494	.2987	.1307	.1307	.1294
24	.132	.1478	.1307	.128	.3174	.1307	.1307
Max	.2614	.2987	.2614	.2987	.3174	.2614	.2801
Min	.1307	.1097	.1307	.056	.0747	.1307	.1294
Avg	.1767	.1656	.1668	.1823	.1625	.1705	.1665

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 204 / BOTHRA FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7167	.439	.6722	.6535	.5601	.5041	.4854
2	.7095	.4435	.6348	.6401	.5228	.5228	.4668
3	.6722	.4854	.6535	.5914	.5281	.5228	.4481
4	.679	.4755	.6722	.5853	.5601	.5415	.5041
5	.6413	.5544	.6348	.5487	.5601	.5228	.5601
6	.5975	.6161	.6535	.5544	.5658	.5601	.6908
7	.5544	.6653	.5975	.5487	.5228	.5601	.6161
8	.5175	.5853	.6348	.4805	.4481	.4854	.4854
9	.4755	.6099	.7842	.499	.4066	.7842	.6161
10	.7762	.6099	.7095	.6908	.5601	.8299	.6413
11	.8501	.499	.8029	.8962	.5175	.8299	.6722
12	.8871	.5487	.8402	.8962	.4854	.7468	.7095
13	.4854	.3734	.2241	.6722	.4108	.7468	.7167
14	.3142	.3326	.7842	.8962	.3696	.7922	.7545
15		.5121	.8402	.8402	.2587	.7922	.7468
16	.8131	.8501	.8962	.7842	.2614	.7468	.7023
17	.8215	.7842	.7655	.7842	.3395	.7392	.6722
18	.7762	.7842	.7762	.7545	.2829		.6979
19	.7468	.5041	.4668	.679	.3395	.415	.3734
20	.6401	.4854	.2772	.6535	.3395	.3734	.4066
21	.5544	.4668	.2743	.6413	.3018	.3206	.4108
22	.3361	.7095	.7392	.6348	.2829	.4338	.4481
23	.3326	.6535	.6401	.6036	.5415	.4108	.5975
24	.7545	.3326	.6535	.6468	.5658	.5228	.4481
Max	.8871	.8501	.8962	.8962	.5658	.8299	.7545
Min	.3142	.3326	.2241	.4805	.2587	.3206	.3734
Avg	.6370	.5550	.6512	.6740	.4388	.5958	.5780

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 205 / 11 KV REX

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.6161	.5228	.4668	.6348	.6602	.8402
2	.6348	.6099	.5041	.462	.5544	.6722	.8029
3	.6348	.5853	.5228	.4668	.5544	.6722	.8402
4	.679	.5853	.4854	.462	.5601	.7095	.8215
5	.6722	.5914	.4668	.4755	.5975	.6535	.8215
6	.6979	.5601	.4481	.5175	.6036	.5601	.7655
7	.6348	.5415	.5601	.4854	.5601	.5601	.7842
8	.5544	.5304	.4854	.499	.5601	.5228	.7468
9	.9876	.5544	.5975	.499	.5914	.5415	.6535
10	.5359	.6468	.8029	.7095	.3921		.679
11	.4805	.6468	.7655	.5788	.4904	.5093	.6348
12	.5359	.462	.7842	.5601	.5601	.5228	.6535
13	.4854	.3174	.2054	.6348	.5281	.5228	.6036
14	.4251	.3841	.5228	.6908	.4854	.5544	.5601
15	.5121	.6653	.5041	.6535	.462	.5601	.3772
16	.462	.8871	.4854	.6161	.4481	.5975	.1867
17	.4668	.5975	.5601	.4294	.6653	.6283	.1478
18	.4294	.7842	.462	.6036	.7095	.6535	.1867
19	.4805	.7282	.6908	.7468	.5975	.6535	.4527
20	.5304	.7095	.7392	.7167	.6535	.7468	.4668
21	.4805	.6348	.5121	.6722	.6722	.7468	.4481
22	.4755	.5415	.462	.6535	.7282	.7282	.4294
23	.4805	.4854	.4854	.6413	.7282	.7655	.4481
24	1.2072	.4854	.4854	.4805	.6348	.7095	.8215
Max	1.2072	.8871	.8029	.7468	.7282	.7655	.8402
Min	.4251	.3174	.2054	.4294	.3921	.5093	.1478
Avg	.5870	.5896	.5442	.5717	.5822	.6283	.5905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 208 / 11KV KANADWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0934	.112	.0914	.132	.1307	.168
2	.112	.0914	.112	.1109	.112	.1307	.168
3	.112	.0924	.112	.112	.1132	.1307	.168
4	.0943	.0934	.112	.1307	.1307	.1307	.168
5	.0943	.1463	.112	.1294	.132	.1307	.168
6	.112	.1463	.1307	.128	.1494	.1494	.168
7	.1294	.1646	.1698	.1478	.132	.1494	.168
8	.1294	.1294	.2054	.1307	.1509	.1494	.1494
9	.1463	.1478	.1867	.128	.1307	.168	.1494
10	.1663	.2402	.2054	.1867	.1294	.1509	.1509
11	.1663	.2402	.2054	.1307	.112	.1698	.1307
12	.1848	.1646	.168	.2241	.1132	.1494	.1307
13	.112	.1629	.1307	.1494	.112	.1494	.1132
14	.1646	.1646	.168	.112	.0924	.1509	.1132
15		.1478	.168	.112	.0924	.168	.112
16	.1848	.2402	.1867	.112	.0934	.1478	.1478
17	.1867	.2241	.168	.1494	.0943	.1494	.168
18	.1848	.1867	.1848	.1698	.1307	.1886	.2241
19	.1463	.2054	.1867	.1867	.1494	.2614	.2263
20	.1646	.1867	.1663	.1698	.168	.1867	.1867
21	.1294	.1494	.128	.1494	.168	.1494	.1509
22	.112	.1307	.1109	.1509	.1494	.168	.1494
23	.1097	.112	.0934	.1307	.1307	.168	.1478
24	.1132	.0924	.112	.0934	.1307	.1307	.168
Max	.1867	.2402	.2054	.2241	.168	.2614	.2263
Min	.0943	.0914	.0934	.0914	.0924	.1307	.112
Avg	.1369	.1564	.1515	.1390	.1270	.1566	.1581

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244107 / 33/11KV Malgaon

Feeder No / Name : 201 / 11 KV malgaon Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2772	.2987	.3048	.3048	.3048	.3174	.3239
2	.2218	.2858	.2858	.2858	.3048	.3048	.3048
3	.2218	.3048	.2858	.2858	.2858	.3048	.3048
4	.2218	.3239	.3429	.2858	.2858	.3048	.3048
5	.2772	.362	.4191	.381	.381	.3429	.381
6	.3696	.5975	.4954	.4954	.4954	.4954	.5144
7	.5359	.5716	.5144	.5544	.5335	.5975	.5788
8	.5175	.5415	.5144	.5175	.5359	.5415	.5359
9	.4755	.4668	.4805	.462	.439	.5175	.5175
10	.4755	.4298	.4477	.4656	.3658	.4854	.4805
11	.4572	.394	.4477	.3761	.3109	.3944	.3898
12	.4163	.4075	.4207	.394		.373	.3506
13	.3658	.3544	.3658	.3582	.3142	.3506	.2804
14	.3475	.3189	.3077	.3109	.3326	.3086	.3189
15	.3475	.3761	.3258	.3292	.2218	.3506	.3012
16	.3658	.394	.3681	.3721	.3696	.4031	.3475
17	.499	.4344	.4075	.4681	.695	.4508	.439
18	.6468	.6697	.6201	.6068	.7865	.7186	.6584
19	.7207	.6838	.7468	.7973	.7762	.8145	.7133
20	.7842	.7207	.6535	.7265	.7762	.7499	.695
21	.6908	.5601	.5906	.6401	.6722	.6348	.5914
22	.5228	.5041	.4763	.4938	.5228	.5175	.462
23	.3734	.3547	.362	.3734	.3361	.4066	.3696
24	.2772	.2987	.3048	.3048	.3048	.3174	.3239
Max	.7842	.7207	.7468	.7973	.7865	.8145	.7133
Min	.2218	.2858	.2858	.2858	.2218	.3048	.2804
Avg	.4337	.4439	.4370	.4412	.4500	.4584	.4370

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244107 / 33/11KV Malgaon

Feeder No / Name : 202 / 11 KV Cannal AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2286	.2096	.2286	.2286	.2286	.2286
2	.2286	.2096	.2096	.5468	.5218	.5434	.5535
3	.2286	.2286	.2096	.5851	.7116	.6805	.6325
4	.2286	.2477	.2286	.7116	.7116	.823	.7362
5	.2858	.2667	.2858	.8802	.9145	.9214	.852
6	.4191	.4191	.362	1.0526	1.1728	1.3592	1.1437
7	.4763	.4954	.4191	1.4706	1.8056	1.6766	1.6644
8	.4191	.4954	.4954	1.8818	2.3685	2.2222	2.1376
9	.4954	.4763	.4572	2.0873	2.5309	2.5286	2.4291
10	.4763	.4763	.4954	.3429	.3048	.2667	.2286
11	1.4327	2.4352	2.4453	.4001	.362	.2858	.3239
12	2.3457	2.6871	2.6726	.3048	.381	.3048	.362
13	2.3624	2.5	2.6726	.3239	.4191	.3239	.362
14	2.4082	2.6235	2.5606	.2667	.381	.2858	.3429
15	2.4387	2.5149	2.4326	.3048	.3429	.2858	.2477
16	2.4383	2.5286	2.5286	.3429	.362	.1715	.3239
17	2.3303	2.4539	2.5286	.362	.381	.2667	.381
18	2.1948	2.0881	2.2138	.4191	.4001	.3239	.4382
19	.2858	.381	.4382	.4382	.4191	.4001	.4191
20	.4191	.4001	.4001	.4191	.4001	.381	.4001
21	.4191	.381	.3429	.381	.381	.3429	.362
22	.3048	.2858	.2667	.3048	.3429	.2858	.3048
23	.2858	.2286	.2286	.2286	.2286	.2477	.2667
24	.2286	.2286	.2286	.2286	.2286	.2286	.2286
Max	2.4387	2.6871	2.6726	2.0873	2.5309	2.5286	2.4291
Min	.2286	.2096	.2096	.2286	.2286	.1715	.2286
Avg	.9742	1.0533	1.0555	.6047	.6792	.6410	.6404

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244134 / 33/11KV Sidhewadi

Feeder No / Name : 201 / 11 KV Sidhewadi AG

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1509	.1307	.132	.1463	.132	
2	.1595	.2054	.2218	.132	.1294	.132	.132
3	.1595	.2534	.2683	.132	.1307	.132	.132
4	.1595	.4973	.3647	.132	.1448	.132	.1334
5	.2515	.5801	.4588	.1509	.1433	.1509	.1509
6	.4858	.5967	.5281	.1886	.1646	.1886	.1715
7	.852	.9393	.8907	.2263	.1848	.2452	.2075
8	.9717	1.1498	1.1043	.2075	.2075	.2452	.2075
9	1.0202	1.2163	1.1174	.1886	.1867	.2075	.1848
10	.0709	.1097	.0943	.1307	.1478	.1478	.1109
11	.0554	.1494	.1294	.9717	.7522	.7274	.7362
12	.1052		.1307	1.0279	.8802	.8855	.8436
13	.1052		.0934	1.0722	.9762	.9488	.8488
14	.1109	.0732	.1132	1.0883	.9282	.8802	.8179
15	.1307	.128	.132	1.0562	.9762	.6636	.8162
16	.0914	.128	.1294	.9804	.9282	.8962	.9122
17		.128	.1307	.9602	.8642	.8539	.8905
18	.1494	.1698	.1867	.9393	.8097	.6405	.7499
19	.2263	.168	.2263	.1478	.2075	.1886	.2075
20	.2263	.1663	.2075	.1886	.1886	.2075	.2075
21	.1886	.1698	.1886	.168	.1886	.1886	.1886
22	.1698	.168	.1698	.1663	.1698	.1698	.1698
23	.1509	.1478	.1509	.1698	.1509	.132	.1509
24	.1132	.1509	.1509	.132	.168	.132	.132
Max	1.0202	1.2163	1.1174	1.0883	.9762	.9488	.9122
Min	.0554	.0732	.0934	.1307	.1294	.132	.1109
Avg	.2638	.3385	.3049	.4454	.4073	.3845	.3957

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244134 / 33/11KV Sidhewadi

Feeder No / Name : 202 / 11KV Kalambi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.1132	.0943	.0943	.112	.1132	.1097
2	.0943	.1132	.0934	.0943	.1097	.1132	.1109
3	.0943	.132	.0934	.0943	.1294	.1132	.1132
4	.0943	.1509	.1109	.0943	.1307	.1132	.1478
5	.0943	.1509	.1097	.132	.1294	.1132	.1494
6	.132	.1509	.1294	.2452	.1463	.1509	.1494
7	.1509	.132	.1629	.2772	.1867	.1886	.2801
8	.1991	.1132		.1509	.2715	.1509	.2054
9	.2926		.2801	.181	.168	.2427	.2033
10	.3077	.2454	.2896	.1612	.1494	.2534	.298
11	.2033	.2515	.3688	.2012	.132	.3856	.0924
12	.2035	.362	.4115	.2353	.2195		.2172
13	.2035	.3391	.2427	.2427	.1663	.3403	
14	.1086	.1638	.2629	.2378	.0566	.3121	.2172
15	.1677	.2149	.3681	.3326	.2801	.2229	.3681
16	.2774	.2686	.2987	.394	.2263	.3189	.3898
17		.3155	.2587	.362	.1132	.3077	.2126
18	.3506	.3544	.181	.3224	.2075	.1943	.2947
19	.2054	.362	.2402		.2263	.2402	.2218
20	.2054	.1698	.2427	.2402	.2075	.2218	.2241
21	.1509	.1646	.2075	.1867	.1886	.1829	.1698
22	.132	.1494	.1509	.1509	.1698	.1886	.1509
23	.1132	.1294	.1132	.0128	.132	.132	.1132
24	.0943	.1132	.0934	.1132	.1109	.1132	.1132
Max	.3506	.362	.4115	.394	.2801	.3856	.3898
Min	.0943	.1132	.0934	.0128	.0566	.1132	.0924
Avg	.1726	.2026	.2089	.1981	.1654	.2049	.1979

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244134 / 33/11KV Sidhewadi

Feeder No / Name : 203 / 11 KV Kalambi Ag

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724	.0924	.0724	.0709	.0924	.0716	.0914
2	.0724	.0739	.0934	.1783	.181	.1372	.2
3	.0724	.112	.0924	.1783	.298	.1372	.2317
4	.0724	.112	.0914	.1783	.2915	.1372	.2709
5	.0732	.112	.1109	.2058	.3201	.2115	.3086
6	.112	.112	.112	.2705	.3525	.3715	.3353
7	.168	.1494	.1478	.5268	.7335	.6554	.5335
8	.2218	.1646	.1867	.6773	.8025	.7926	.7468
9	.1829	.1829	.181	.7621	.9181	.8993	.7977
10	.1543	.1829	.1772	.1086	.0848	.0867	.1227
11	.8109	.2149	.8509	.1294	.0886	.128	.1063
12	.9536	.7876	.9362	.128	.1063	.1448	.0848
13	.8802	.8509	.4451	.128	.0886	.1402	.0848
14	.8949	.888	.7468	.1254	.0709	.1075	.0848
15	.8768	.8322	.7977	.1097	.0886	.1063	.0886
16	.9065	.8173	.7876	.0924	.1097	.1267	.1448
17		.8322	.7482	.128	.0886	.1063	.1433
18	.9267	.6895	.6923	.1448	.128	.1478	.1448
19	.0905	.1029	.0914	.1646	.1109	.1307	.1307
20		.1052	.1097	.2054	.1109	.1294	.1294
21	.0905	.1075	.0905	.1867	.1097	.1109	.1294
22	.0914	.0905	.0895	.1509	.0914	.0914	.1097
23	.0709	.0895	.0716	.1109	.0724	.0905	.1097
24	.0724	.0709	.0739	.0709	.0934	.0716	.0895
Max	.9536	.888	.9362	.7621	.9181	.8993	.7977
Min	.0709	.0709	.0716	.0709	.0709	.0716	.0848
Avg	.3576	.3239	.3249	.2097	.2264	.2138	.2175

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244137 / 33/11KV NARWAD

Feeder No / Name : 201 / 11 KV NARWAD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0554	.0549	.0554	.056	.0732	.0554	.0554
2	.0554	.0366	.0549	.056	.0732	.0549	.0554
3	.0549	.0366	.0554	.056	.0566	.0549	.0549
4	.0549	.037	.0549	.056	.0566	.0739	.0554
5	.0739	.0554	.0739	.0747	.0934	.0732	.0739
6	.0747	.0732	.0924	.0732	.0724	.0924	.1097
7	.0924	.0924	.0914	.0724	.0914	.1097	.0924
8	.0924	.0732		.0914	.0914	.0924	.0914
9	.0924	.0554	.0924	.0724	.0914	.0914	.0732
10	.0739	.0732	.0732	.0905	.0914	.0739	.0905
11	.0732	.0732	.0914	.0724	.0732	.0732	.0648
12	.0732	.0924	.0914	.0724	.0732	.0739	.0655
13	.0739	.0924	.0724	.0732	.0739	.0732	.0724
14	.0732	.0914	.0543	.0732	.0732	.0732	.0732
15	.0739	.0924	.0549	.0543	.0739	.0554	.0549
16	.0934	.0924	.0732	.0905	.0739	.0739	.0724
17	.0914	.1097	.1086	.0905	.0732	.0732	.1086
18	.128	.128	.1448	.1086	.1294	.1294	.1086
19	.1478	.1478	.1463	.1448	.1294	.1663	.1629
20	.1478	.1294	.128	.1086	.128	.1463	.1267
21	.1097	.0914	.1097	.1086	.1097	.1294	.1109
22	.0732	.0739	.0732	.0905	.0924	.0914	.0924
23		.0739	.0732	.0724	.0549	.0732	.0554
24	.0549	.0554	.0732	.0754	.0732	.0554	.0732
Max	.1478	.1478	.1463	.1448	.1294	.1663	.1629
Min	.0549	.0366	.0543	.0543	.0549	.0549	.0549
Avg	.0841	.0805	.0843	.0806	.0843	.0858	.0831

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244137 / 33/11KV NARWAD

Feeder No / Name : 202 / 11 KV GAYRANWADI AG

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0566	.056	.0566	.0566	.056	.056
2	.5182	.3725	.4481	.0566	.056	.0566	.056
3	.5668	.4049	.4858	.056	.056	.056	.0566
4	.5921	.426	.502	.056	.0754	.0566	.056
5	.6478	.4534	.5281	.0566	.0762	.056	.0754
6	.664	.4858	.5668	.0754	.0953	.0747	.0934
7	.8642	.9555	.9122	.0934	.0943	.0943	.0754
8	1.1498	1.0595		.0943	.0943	.0747	.0747
9	1.2955	1.2146	1.166	.0754	.0754	.0754	.0747
10	.0934	.0754	.0754	.0754	.0943	.0754	.056
11	.0754	.0747		1.2452	1.1043	1.1174	1.1142
12	.0747	.0747		1.3435	1.1523	1.2003	1.2125
13	.0754	.0943		1.0526	1.1683	1.2163	1.1797
14	.0747	.0754		1.2308	1.1523	1.1683	
15	.0754	.0934	.0191	1.278	1.1363	.9717	1.1012
16	.0747	.0934		.8907	1.166		1.2631
17	.0754	.1132	.0572	1.0688	1.0242	.8162	1.247
18	.112	.112	.0953	1.065	.8162	.7773	
19	.132	.1307	.1132	.1132	.096	.112	
20	.1307	.132	.1132	.1143	.096	.1132	.1132
21	.1132	.112	.0943	.0953	.08	.0934	.0943
22	.0934	.0934	.0754	.0953	.064	.0747	.0754
23		.0754	.0754	.0747	.056	.0754	.056
24	.0754	.0747	.0754	.0754	.0566	.0566	.0754
Max	1.2955	1.2146	1.166	1.3435	1.1683	1.2163	1.2631
Min	.056	.0566	.0191	.056	.056	.056	.056
Avg	.3317	.2856	.3033	.4349	.4143	.3682	.3908

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244137 / 33/11KV NARWAD

Feeder No / Name : 203 / 11 KV BHAVANI AG

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.064	.0633	.0633	.064	.064	.064	.064
2	.5601	.3795	.5376	.064	.064	.064	.064
3	.6081	.4428	.5761	.064	.064	.064	.064
4	.6401	.506	.6241	.064	.064	.064	.064
5	.6882	.5851	.6562	.064	.08		.08
6	.7202	.7748	.7042	.064	.096	.096	.096
7	1.0402	1.186	.9762	.112	.096	.112	.112
8	1.3603	1.3599		.096	.096	.112	.096
9	1.4243	1.5339	1.4083	.08	.08	.08	.08
10	.0633	.064	.064	.081	.08	.08	.0648
11	.0633	.0791	.064	1.5203	1.3763	1.2163	1.3443
12	.0791	.0949	.08	1.6964	1.4723	1.4243	1.5043
13	.0791	.0791	.08	1.4413	1.4723	1.3923	1.4563
14	.0791	.0949	.08	1.5524	1.4563	1.3763	1.4563
15	.0791	.0791	.064		1.4403	1.3443	1.5061
16	.0791	.0949	.064	1.4723	1.3923	.9602	1.5223
17	.0949	.0949	.08	1.4563	1.2483	1.0082	1.5384
18	.1107	.1265	.112	1.3443	1.0883	1.0402	1.4089
19	.1265	.1423	.128	.112	.096	.112	.096
20	.1265	.1265	.128	.112	.096	.112	.112
21	.1107	.1265	.096	.08	.08	.112	.096
22	.0949	.0949	.064	.08	.064	.096	.064
23		.0791	.064	.08	.064	.08	.064
24	.08	.0791	.0791	.064	.064	.064	.08
Max	1.4243	1.5339	1.4083	1.6964	1.4723	1.4243	1.5384
Min	.0633	.0633	.0633	.064	.064	.064	.064
Avg	.3640	.3453	.2954	.5115	.5081	.4815	.5431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 201 / 11 KV Anjani AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0259	.0594	.0533	.0423	.0267	.0267	.04
2	.1486	.1806	.2709	.0434	.0429	.0297	.0406
3	.1806	.2134	.3201	.0446	.0572	.0389	.0463
4	.2408	.3125	.3749	.0762	.0983	.0937	.0474
5	.3269	.4481	.4062	.1094	.0972	.128	
6	.4572	.583	.4801	.128	.112	.1475	.144
7	.6874	.7373	.823	.1619	.1311	.144	.128
8	.9217	.9998	1.0936	.1406	.144	.1265	.125
9	1.0311	1.1363	1.3279	.1219	.1265	.0914	.0937
10	.0903	.0869	.0903	.1	.0857	.0556	
11	.0926	.1054	.1054	1.1203	.953	.695	.9259
12	.1054	.0724	.0549	1.1843	1.0623	.9065	1.2811
13	.088	.0892	.0892	.9014	1.1561	1.1138	1.1883
14	.1067	.0903	.0914	1.2003	1.2186	1.1126	1.2346
15	.0926	.0903	.108	1.1843	1.2967	1.1584	1.1873
16	.0926	.0857	.0914	1.0883	.8333	1.0974	1.1736
17	.0907	.0857	.1174	1.034	.7526		1.0385
18	.1395	.1067	.0937	.1219	.7225	.4001	.1852
19	.112	.128	.1107	.096	.0949	.0772	
20	.096	.1014	.0926	.0781	.0772	.0602	
21		.0743	.0743	.0617	.0587	.0572	.0617
22	.0772	.0743	.0587	.0446	.0434	.0434	.0429
23	.0594	.0533	.04	.04	.0406	.04	.0274
24	.0372	.0587	.0526	.0412	.0267	.0383	.0389
Max	1.0311	1.1363	1.3279	1.2003	1.2967	1.1584	1.2811
Min	.0259	.0533	.04	.04	.0267	.0267	.0274
Avg	.2305	.2489	.2675	.3819	.3858	.3340	.4525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 202 / 11 KV Bastavade Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1097	.1307	.0754	.0754	.112	.1433
2	.1052	.1109	.1307	.4641	.6554	.4161	.2652
3	.1052	.1086	.1307	.5506	.8356	.4915	.3277
4	.1734	.1417	.1509	.583	.9667	.5761	.4588
5	.1696	.1402	.1886	.664	1.1469	.6478	
6	.2012	.1966	.2452	.7362	1.3108	.7773	.6478
7	.2949	.2881	.3018	1.0242	1.4255	1.1523	.9922
8	.2652	.2915	.2829	1.3923	1.7695	1.6644	1.4899
9	.2347	.1966	.2054	1.3603	1.8299	1.5364	1.704
10	.1989	.2218	.2241	.1307	.1307	.0995	.1494
11	1.7284	1.5043	1.4723	.1867	.132	.0983	.1494
12	1.8122	1.7604	1.6644	.168	.112	.0838	.168
13	1.7711	1.7444	1.4864	.1494	.1307	.0663	.1494
14	1.8564	1.7764	1.7078	.1307	.1478	.1006	.1867
15	1.9433	2.0165	1.8404	.112	.1494	.1402	.2054
16	1.7924	2.0005	1.9204	.1494	.1307	.1433	.2241
17	1.6842	1.7711	1.7924	.1867	.168		.2614
18	1.4419	1.4198	1.5844	.2263	.1867	.1734	.2614
19	.2149	.2263	.2241	.2452	.2263	.1989	.2614
20	.2172	.2241	.2054	.2075	.2075	.1677	.2452
21		.2075	.2075	.1886	.1886	.1715	.2452
22	.1448	.1494	.132	.132	.1509	.1753	.1886
23	.1097	.1307	.1132	.1132	.132	.1402	.1509
24	.1311	.1086	.1307	.0943	.0943	.112	.1417
Max	1.9433	2.0165	1.9204	1.3923	1.8299	1.6644	1.704
Min	.1029	.1086	.1132	.0754	.0754	.0663	.1417
Avg	.7260	.7019	.6864	.3863	.5126	.4020	.3920

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 203 / 11 KV Dongarsoni AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2149	.2587	.2263	.2054	.2241	.2103
2	.2427	.2195	.3142	1.2483	.9665	1.4582	.8288
3	.2454	.2103	.2801	1.3117	1.0174	1.5424	1.3927
4	.2835	.2601	.3734	1.4899	1.1869	1.6385	1.8564
5	.4207	.3988	.7167	1.7652	2.8826	1.9448	
6	.7282	.703	.7922	1.9757	3.2217	2.5095	2.5232
7	.6874	.6718	.8865	2.6246	3.3573	3.1352	3.0887
8	.5801	.547	.7282	3.0727	3.2861	2.7349	3.2712
9	.4915	.5087	.5788	2.8327	3.2895	3.3196	3.2167
10	.3481	.499	.4668	.2561	.2743	.2401	.2772
11	3.0312	3.2526	3.1527	.3142	.3326	.2601	.3326
12	2.8182	3.0001	.7377	.3511	.2957	.333	.2957
13	2.9473	2.9172	1.0442	.3077	.3326	.2715	.3142
14	2.8327	3.1687	3.1687	.2896	.3511	.2743	
15	2.9959	3.0167	3.1207	.3326	.3696	.2715	.2957
16	3.0407	3.0664	3.1047	.4251	.3142	.3582	.3881
17	3.0121	2.8178	3.1047	.4805	.3511		.4805
18	2.3845	2.9835	2.9767	.4668	.4294	.5373	.4066
19	.503	.5144	.5601	.547	.5228	.5611	.5415
20	.4001		.4668	.4527	.4481	.4298	.4481
21		.3921	.415	.3961	.3734	.3294	.3772
22	.2926	.3361	.3206	.2801	.2614	.2835	.3018
23	.2534	.2587		.2241	.2241	.2534	.2452
24	.2347	.2172	.2561	.2452	.2241	.2218	.2103
Max	3.0407	3.2526	3.1687	3.0727	3.3573	3.3196	3.2712
Min	.2347	.2103	.2561	.2241	.2054	.2218	.2103
Avg	1.2615	1.3119	1.2098	.9132	1.0216	1.0057	.9683

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 204 / 11 KV Jarandi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0617	.0625	.061	.064	.081	.0633	.0949
2	.0625	.0633	.0594	.3401	.4858	.421	.1619
3	.0633	.0648	.0594	.4049	.6964		.3201
4	.096	.096	.0937	.4752	.9717	.5571	.4475
5	.1619	.1475	.144	.6226	1.1797	.6554	
6	.2458	.2458	.1966	.7209	1.4582	.5868	.8848
7	.2785	.2949	.2915	1.1469	1.5893	1.247	1.278
8	.2458	.2429	.2105	1.6032	1.6876	1.6964	1.6876
9	.1966	.1943	.2429	1.5339	1.668	1.6518	1.8679
10	.1781	.1457	.2401	.1094	.0926	.1296	.128
11	1.6129	1.6385	1.4723	.1107	.1492	.1943	.16
12	1.6804	1.5524	1.6842	.1781	.0972	.16	.1781
13	1.8404	1.2651	1.8623	.1781	.1781	.1781	.1311
14	1.8244	1.8351	1.3123	.16	.0972	.1619	.1638
15	1.8138	1.8785	1.6356	.176	.192	.192	.1638
16	2.0729	1.6964	1.6324	.144	.1619	.1943	.2105
17	1.9364	.8535		.1739	.1265		.1781
18	1.531	1.0802	1.1961	.1943	.208	.2214	.2458
19	.2105	.208	.1943	.2429	.2429	.2267	.2622
20	.192	.192	.1781	.2105	.1943	.1943	.1802
21		.144	.1265	.1781	.144	.144	.1475
22	.0972	.1134	.112	.1134	.096	.1107	.0633
23	.0191	.0781	.0772	.0972	.08	.0937	.0486
24	.8288	.0617	.0617	.0625	.096	.0791	.0937
Max	2.0729	1.8785	1.8623	1.6032	1.6876	1.6964	1.8679
Min	.0191	.0617	.0594	.0625	.08	.0633	.0486
Avg	.75	.5898	.5715	.3850	.4989	.4163	.3955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 205 / 11 KV Savalaj Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2033	.2241	.2587	.2641	.2452	.2241	.2427
2	.2054	.2241	.2402	.2452	.2263	.2241	.2427
3	.2075	.2241	.2427	.2452	.2452	.2241	.2402
4	.2641	.2587	.2427	.3395	.3206	.3018	.2534
5	.2987	.2957	.3018	.4527	.547	.4527	
6	.439	.5304	.4904	.5601	.5658	.5658	.5138
7	.5552	.6154	.5975	.6161	.5975	.6348	.6089
8	.443	.4835	.5041	.462	.4805	.4805	.4706
9	.3582	.3258	.3511	.3696	.3696	.4024	.4119
10	.3439	.2896	.2957	.3224	.3258	.3077	.3292
11	.3224	.2865	.2772	.3012	.2715	.2926	.3292
12	.2534	.2378	.2772	.2402	.2715	.2715	.2743
13	.2378	.2865	.2772	.2715	.2658	.2743	.2561
14	.2587	.2561	.3142	.2561	.2561	.2561	.2402
15	.2378	.2353	.2402	.2926	.2195	.2534	.2402
16	.2715	.2686	.3142	.3045	.2378	.3109	.2957
17	.3403	.3224	.4251	.3045	.3077		.2957
18	.5068	.4477	.4805	.5041	.4887	.4656	.4435
19	.6089	.6283	.5975	.6219	.6099	.5973	.6535
20	.5316	.5729	.5228	.5847	.5544	.5304	.5601
21		.4854	.4715	.499	.462	.4525	.4904
22	.2926	.4251	.415	.3734	.3361	.3658	.415
23	.2561	.3142	.3206	.2614	.2801	.3109	.3206
24	.0953	.2218	.2772	.2829	.2614	.2427	.2772
Max	.6089	.6283	.5975	.6219	.6099	.6348	.6535
Min	.0953	.2218	.2402	.2402	.2195	.2241	.2402
Avg	.3275	.3525	.3640	.3740	.3644	.3670	.3654

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 207 / 11 KV Savlaj Water Supply NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0143	.0147	.0133	.0149	.016	.0114	.0145
2	.0145	.0149	.013	.0145	.016	.013	.0147
3	.0147	.0151	.0141	.0145	.016	.013	.0143
4	.0147	.0143	.0152	.0149	.016	.0137	.0141
5	.0143	.0141	.016	.0149	.016	.0149	
6	.0145	.0149	.0164	.0152	.016	.0152	.0286
7	.0143	.029	.0152	.0156	.016	.0154	.029
8	.0147	.029	.0158	.016	.016	.0312	.0286
9	.0286	.0286	.0316	.016	.016	.032	.029
10	.029	.0305	.016	.016	.0305	.0309	.0149
11	.0286	.0301	.0156	.016	.0324	.0297	.0305
12	.0282	.029	.0156	.0164	.0139	.029	.0152
13	.0286	.0278	.0152	.016	.0135	.0286	.0149
14	.0145	.0282	.0156	.016	.0135	.029	.0152
15	.0147	.0267	.0152	.016	.0141	.0286	.0152
16	.0145	.0145	.0152	.016	.0162	.029	.0152
17	.0143	.0126	.0156	.016	.0158		.0152
18	.029	.0137	.0312	.016	.0158	.0286	.0156
19	.029	.0145	.0305	.016	.0156	.029	.0156
20	.029	.0116	.0152	.016	.0152	.0286	.0152
21		.012	.0149	.016	.0152	.029	.0149
22	.0145	.0126	.0145	.016	.0154	.0145	.0149
23	.0147	.0118	.0145	.016	.0124	.0145	.0149
24	.0145	.0145	.0114	.0149	.016	.0122	.0143
Max	.029	.0305	.0316	.0164	.0324	.032	.0305
Min	.0143	.0116	.0114	.0145	.0124	.0114	.0141
Avg	.0195	.0194	.0170	.0157	.0166	.0227	.0180

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 209 / 11 KV Savlaj Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.2561	.2218	.2075	.2263	.2218	.2172
2	.3277	.4641	.7116	.1886	.2452	.2218	.2149
3	.3932	.7209	.8124	.1886	.3772	.2427	.2103
4	.4858	.8097	.9602	.2452	.3961	.2987	.2774
5	.8642	1.0242	1.2452	.3584	.5093	.415	
6	1.2955	1.2651	1.4754	.5788	.5658	.5281	.4694
7	1.6644	1.8122	2.0891	.5914	.5975	.5281	.4801
8	2.2455	2.2497	2.4939	.5359	.4668	.4668	.3932
9	2.4006	2.5309	2.7199	.4251	.4294	.3361	.3315
10	.1791	.2534	.2241	.2772	.362	.2218	.3361
11	.2534	.2012	.2427	2.343	2.2939	2.0485	2.0485
12	.2218	.2353	.2614	2.2611	1.9757	2.2024	
13	.2218	.2402	.2427	2.1862	2.17	2.2138	1.9204
14	.2926	.2587	.2614	1.9919	2.1464		2.234
15	.2926	.3142	.2241	2.2186	1.4563	2.2672	2.3746
16	.2957	.3326	.2987	2.3758	1.917	2.3967	2.3746
17	.362	.3077	.3734	2.3205	1.8947		2.3746
18	.4298	.3475	.4294	.3109	1.8299	1.5546	2.119
19	.4344	.4294	.3734	.4108	.4481	.3856	.4481
20	.3544	.3921	.3395	.3734	.3734	.3582	.3921
21		.3361	.3395	.3547	.3174	.2896	.3547
22	.2896	.2587	.2829	.2801	.2427	.2715	.2829
23	.2715	.2378	.2452	.2427	.2218	.2378	.2452
24	.0191	.2534	.2195	.2263	.2427	.2195	.2195
Max	2.4006	2.5309	2.7199	2.3758	2.2939	2.3967	2.3746
Min	.0191	.2012	.2195	.1886	.2218	.2195	.2103
Avg	.5990	.6471	.7120	.8955	.9044	.8148	.9236

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 201 / 11 KV Manerajuri Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2715	.2481	.2957	.333	.2126	.298	.2218
2	.7202	.2534	.2987	.394	.7956	.8962	.9503
3	.9175	.2561	.3018	.4252	.8745	1.078	1.0402
4	1.2631	.2658	.3403	.3988	.8855	1.3272	1.2793
5	1.4864	.3258	.3982	.5014	1.0608	1.587	
6	1.6804	.5487	.547	.5959	1.5223	1.781	1.873
7	1.9109	.5792	.6767	.7421	2.1445	2.3457	2.0972
8	2.1605	.6024	.7167	.6626	2.7018	2.7366	2.3205
9	2.2455	.567	.6838	.6201	2.878	2.6871	2.6882
10	.4961	.5373	.6468	.5083		.2865	.394
11	2.3045	2.2862	2.5126	.4887		.3258	.4344
12	2.2613	2.3611	2.6558	.4656		.394	.4961
13	2.2497	2.5484	2.7199	.4887		.4755	.4557
14	2.3685	2.3457	2.4486	.4607	.3856	.5014	.4525
15	2.4291	2.5987	2.6871	.5068	.439	.543	.5014
16	2.652	2.6052	2.6246	.5731	.443	.5853	.5014
17	2.5069	2.3205	2.4074	.5548	.4656	.5373	.2835
18	2.2405	2.1293	2.359	.631	.5028	.5249	.5792
19	.443	.4961	.4298	.5373	.4908	.4024	.5601
20	.4557	.462	.3841	.4252	.4656	.3582	.5175
21	.4344	.4435	.4961	.362	.4252	.3292	.439
22	.3582	.3761	.4161	.3224	.3814	.2686	.362
23	.3258	.362	.3155	.2658	.2804	.2534	.2481
24	.2865	.2743	.3292	.3045	.2534	.2658	.2378
Max	2.652	2.6052	2.7199	.7421	2.878	2.7366	2.6882
Min	.2715	.2481	.2957	.2658	.2126	.2534	.2218
Avg	1.4362	1.0747	1.1538	.482	.8804	.8662	.8232

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 202 / 11 KV Yogewadi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1433	.1753	.1848	.2328	.181	.1612	.1417
2	.1829	.5121	.5571	.6405	.1772	.208	.1629
3	.2172	.5636	.8048	.7748	.1753	.2481	.1829
4	.2865	.6325	.9503	.9175	.181	.1928	.2149
5	.3258	.8421	1.0402	1.0722	.2126	.2896	
6	.3658	1.1203	1.1736	1.166	.3258	.3224	.3109
7	.4119	1.7736	1.6385	1.3599	.3881	.3467	.3511
8	.3982	1.8976	2.0957	1.6248	.3582	.3856	.3403
9	.3721	2.2874	2.1874	1.7438	.3258	.394	.3439
10	.3506	.2126	.2801	.2328		.3801	.2926
11	.3189	.2328	.3506	1.6004		.9282	1.6575
12	.3155	.2353	.4119	1.7404		1.2146	1.8138
13	.2865	.2715	.3721	1.6842		1.5402	1.8896
14	.2835	.3475	.2774	1.6907	.1612	1.7124	1.9109
15	.2629	.3142	.2454	1.6446			1.9608
16	.3189	.3142	.2896	1.7604	1.3592	1.6194	1.7497
17	.2896	.3142	.2686	1.406	1.4243	1.5524	1.4752
18	.2865	.3142	.2835	1.5746	1.406	1.5384	1.5684
19	.2686	.3511	.2427	.2686	.2896	.1791	.3315
20	.2658	.2772	.2303	.2353	.2427	.1629	.3189
21	.2353	.2534	.2279	.2126	.2279	.1595	.2454
22	.2149	.2254	.197	.2172	.1949	.1646	.1791
23	.181	.2218	.1734	.1791	.1433	.1448	.1753
24	.0191	.1772	.2033	.1753	.1772	.1402	.1433
Max	.4119	2.2874	2.1874	1.7604	1.4243	1.7124	1.9608
Min	.0191	.1753	.1734	.1753	.1433	.1402	.1417
Avg	.2751	.5778	.6119	1.0064	.4185	.6081	.7722

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 203 / 11 KV Bhosalenagar Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1612	.1433	.1646	.2103	.181	.1928	.1791
2	.1772	.5506	.6081	.5761	.1772	.1772	.2012
3	.1791	.6009	.8048	.6562	.1753	.1907	.197
4	.2195	.7202	.9835	.8381	.1791	.1629	.2172
5	.2534	.9945	1.0322	1.0648	.181	.1753	
6	.2865	1.2146	1.0517	1.2003	.3224	.2126	.2865
7	.3077	1.989	1.5592	1.3283	.3224	.2774	.3258
8	.3582	2.3365	1.9052	1.5154	.362	.3155	.3582
9	.3982	2.4777	2.3807	1.713	.4252	.3761	.3801
10	.394	.2481	.2658	.1595		.333	.3403
11	.3761	.362	.3403	1.7814		1.0883	1.7185
12	.3898	.4119	.4031	1.9559			1.9204
13	.3506	.3881	.3641	1.9669		1.4575	1.9559
14	.3544	.4066	.3189	1.9044	.9762	1.5813	1.9204
15	.3761	.4066	.3439	1.989	1.6358	1.6324	2.0405
16	.4207	.4066	.3761	1.9364	1.7029	1.6842	1.989
17	.3189	.3696	.3467	1.8461	1.5123	1.5971	1.8884
18	.3544	.2587	.4031	1.6446	1.4548	1.5844	1.8138
19	.3224	.3142	.3439	.3224	.2507	.2328	.2804
20	.2658	.2772	.3045	.3155	.2279	.2195	.3224
21	.2172	.2587	.2601	.2481	.208	.2218	.2658
22	.1772	.2033	.2481	.2149	.1949	.2012	.2279
23	.1791	.1829	.2103		.1578	.1791	.181
24	.1629	.1417	.1663	.197	.1772	.1612	.181
Max	.4207	2.4777	2.3807	1.989	1.7029	1.6842	2.0405
Min	.1612	.1417	.1646	.1595	.1578	.1612	.1791
Avg	.2917	.6526	.6327	1.1124	.5412	.6198	.8344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 204 / 11 KV Manerajuri Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2172	.2801	.2561	.2195	.1867	.2033	.1886
2	.2452	.2772	.2402	.2033	.1848	.2452	.181
3	.2587	.2896	.2427	.2534	.181	.2195	.2218
4	.2926	.2926	.2427	.2987	.1867	.2614	.2829
5	.3395	.2957	.2641	.3395	.2561	.2957	
6	.362	.3292	.3326	.3511	.3326	.3395	.3475
7	.3582	.3772	.3898	.3658	.4108	.3658	.3881
8	.3547	.3734	.3582	.5068	.3734	.362	.462
9		.4527	.5175	.5914	.3018	.2987	.5121
10	.415	.3361	.4435	.3658		.3326	.5544
11	.3018	.4066	.3658	.4481		.3292	.5658
12	.3734	.5175	.3361	.4805		.3077	.5228
13	.415	.4251		.4481		.2926	.2561
14	.2987	.4066	.2218	.2587		.3018	.4108
15	.3395	.4251	.4338	.4668		.2743	.4527
16	.2957	.5175	.4755	.4481	.2957	.2829	.4108
17	.3395	.5544	.5792	.4435	.3475	.3292	.4527
18	.4854	.5914	.7392	.4108	.415	.3982	.4904
19	.6036	.7023	.679	.679	.5228	.2865	.5975
20	.6348	.6283	.5975	.7167	.5914	.2534	.6722
21	.5175	.5601	.439	.4481	.4904	.2378	.5544
22	.4108	.3544	.362	.3696	.4024	.2149	.4481
23	.3326	.3224	.2218	.2987	.2172	.2195	.3292
24	.2241	.2957	.2715	.1867	.1829	.1829	.2033
Max	.6348	.7023	.7392	.7167	.5914	.3982	.6722
Min	.2172	.2772	.2218	.1867	.181	.1829	.181
Avg	.3659	.4171	.3917	.3999	.3266	.2848	.4133

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 205 / 11 KV AG LIS Feeder

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0358		.0189	.0183	.0179	.0179
2	.0362		.0358	.0354	.0366	.0181
3	.0549		.0543	.0362	.0362	.0366
4	.0537		.0549	.0358	.0358	.0358
5	.0554	.0351	.0554	.0366	.0354	
6	.0724	.0354	.0566	.0354	.0732	.0554
7	.0732	.0351	.0554	.0358	.0724	.0549
8	.0905	.0354	.0554	.0724	.0537	.0554
9	.0914	.0351	.0554	.0886	.0543	.0537
10	.0895	.0354	.037	.0905	.0532	.0549
11	.0876	.037	.0549	.0709	.0543	.0739
12	.0532	.0554	.0543	.0716	.0537	.0747
13	.0362	.0554	.0537	.0709	.0549	.0739
14	.0351	.0554	.0532	.0724	.0537	.0724
15	.0351	.0554	.0724	.0354	.0543	.0701
16		.0554	.0732	.0354	.0549	.0709
18				.0354		
24	.0191					
Max	.0914	.0554	.0732	.0905	.0732	.0747
Min	.0191	.0351	.0189	.0183	.0179	.0179
Avg	.0575	.0438	.0526	.0516	.0497	.0546

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 206 / 11 kv Yogewadi Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1109	.1307	.1086	.168	.1086	.1646	.112
2	.112	.1307	.1086	.128	.0924	.1494	.1097
3	.1509	.128	.1097	.1886	.0914	.1646	.1294
4	.1629	.1478	.1294	.2218	.0934		.1509
5	.1646	.1867	.1663	.2561	.1097	.1509	
6	.1848	.2218	.2303	.2402	.1494	.128	.1848
7	.1991	.1867	.2149	.2641	.1886	.1663	.2012
8	.2561	.1646	.1595	.3292	.1494	.168	.3921
9	.3018	.3921	.3721	.362	.3584	.0924	.4715
10	.3326	.3772	.3721	.3511		.128	.4294
11	.4854	.3696	.4024	.3772		.132	.4108
12	.4435	.3696	.4481	.3361		.1478	.3961
13	.1463	.2507	.3584	.3696		.1494	.3361
14	.3174	.1294	.1267	.1494	.1663	.128	.1478
15	.2829	.2772	.3326	.3734	.3801	.1109	.4338
16	.3361	.4066	.3841	.4527	.4668	.112	.3734
17	.3772	.3696	.4108	.3361	.4066	.128	.3961
18	.4527	.3012	.4251	.2957	.3439	.1698	.3584
19	.3734	.3547	.3584	.2614	.3921	.168	.2987
20	.3395	.2772	.3109	.2263	.3142	.1509	.2587
21	.1867	.1848	.1698	.1848	.1698	.1463	.1867
22	.1478	.1478	.1478	.1494	.1463	.1478	.1829
23	.1494	.124	.1646	.1478	.1494	.1307	.1478
24	.128	.132	.1075	.1448	.128	.1294	.132
Max	.4854	.4066	.4481	.4527	.4668	.1698	.4715
Min	.1109	.124	.1075	.128	.0914	.0924	.1097
Avg	.2559	.2400	.2549	.2631	.2202	.1419	.2713

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244089 / 33/11 KV WAIFALE

Feeder No / Name : 201 / 11 KV Waifale Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0572	.0762	.0762	.0762	.0572	.1334
2	.0762		.0762	.0762	.0762	.0572	.1334
3	.0762	.0572	.0762	.0762	.0762	.0572	.1524
4	.0762	.0572	.0572	.0762	.0762	.0572	.1524
5	.0762	.0953	.0572	.1143	.0762	.0762	.1905
6	.1143	.1524	.0572	.1334	.1143	.1524	.1905
7	.1143	.1524	.1143	.1524	.1334	.1524	.2286
8	.1524	.1334	.1524	.1715	.1524	.1143	.1524
9	.1524	.0762	.1143	.1715	.1143	.0953	.1334
10	.0762	.0762	.1143	.0953	.1143	.0953	.0762
11	.0762	.0762	.1143	.0953	.0762	.0762	.0762
12	.0762	.0762	.1143	.0762	.0572	.0572	.0762
13	.0762	.0572	.1143	.0762	.0572	.1334	.0762
14	.0762	.0572	.0762	.0572	.0572	.0572	.0762
15	.0762	.0572	.0953	.0572	.0572	.0572	.0572
16	.0762	.0572	.0953	.0572	.0572	.0572	.0572
17	.0953	.0953	.1334	.1143	.0762	.0953	.0953
18	.1905	.1334	.1334	.1334	.1143	.1334	.1334
19	.2286	.1905	.1143	.1334	.1143	.1905	
20	.1905	.1524	.1143	.1334	.1143	.1524	
21		.1524	.1143	.1143	.1143	.1334	.1334
22	.1143	.1524	.1334	.1143	.1143	.1334	
23	.0953	.1524	.0762	.0762	.0762	.1334	.1334
24	.0572	.0572	.1143	.0762	.0762	.0572	.1334
Max	.2286	.1905	.1524	.1715	.1524	.1905	.2286
Min	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Avg	.1052	.1011	.1016	.1024	.0905	.0993	.1234

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244089 / 33/11 KV WAIFALE

Feeder No / Name : 202 / 11 KV Waifale Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0762	.0762	.1029	.0762	.1715
2	.0762	.0762	.0762	.2561	.1029	.3982	.9795
3	.0762	.0762	.0762	.2401	.2774	.3982	1.1888
4	.0762	.0762	.0762	.6173	.4755		1.1888
5	.0762	.1334	.0762	.6173	.4854	.5373	1.2489
6	.1524	.3395	.1524	.7888	.6173	.8139	
7	.2286	.3018	.2286	.9602	.9175	1.1869	1.5023
8	.3048	.2641	.3048	1.2041	1.4746	1.5089	1.5203
9	.3048	.0953	.2096	1.6004	1.4746	1.5089	1.5023
10	.1334	.0953	.1524	.0953	.1334	.1334	.1334
11	1.5432	1.647	1.0288	.0953	.1143	.1715	.1334
12	1.6575	1.7896	1.0974	.0953	.0953	.1524	.0953
13	1.6194	1.8073	1.1269	.0953	.1143	.1334	.0953
14	1.6004	1.7364	1.4575	.0762	.1143	.1143	.0953
15	1.6324	1.7177	1.4746	.0762	.1334	.0953	.1143
16	1.6129	1.647	1.5261	.0953	.1524	.0953	.1143
17	1.5364	1.5432	1.2193	.1524	.1524	.0953	.1524
18	1.3923	1.595	1.286	.1905	.2286	.1334	.1715
19	.2286	.1905	.1905	.1905	.2286	.2096	
20	.1905	.1905	.1905	.1905	.2286	.1905	
21		.1143	.1524	.1524	.1715	.1905	.1334
22	.1524	.1143	.1524	.1334	.1334	.1715	.4191
23	.1143	.1143	.1143	.1143	.0953	.1715	.2286
24	.0191	.0762	.1143	.1143	.1143	.0762	.1715
Max	1.6575	1.8073	1.5261	1.6004	1.4746	1.5089	1.5203
Min	.0191	.0762	.0762	.0762	.0953	.0762	.0953
Avg	.6437	.6591	.5233	.3428	.3391	.3723	.5410

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789] BU 4789

Substation No/ Name :- 244089 / 33/11 KV WAIFALE

Feeder No / Name : 203 / 11 KV Biranwadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1334	.1905	.1524	.1905	.0953	.2286
2	.6173	.5144	.3048	.1524	.1905	.0953	.2286
3	.6241	.5144	.4458	.1524	.1524	.0953	.3048
4	.6584	.5144	.6241	.1334	.1524	.1143	.3048
5	.6935	.7621	.6584	.1334	.1524	.1905	.3048
6	1.2071	1.3146	.6241	.1715	.1524	.3734	
7	1.491	2.4143	.6241	.2286	.2667	.3772	.4763
8	2.2119	2.4034	2.692	.3239	.362	.3395	.381
9	1.9814		2.4539	.2667	.3048	.2667	.2667
10	.1715	.1715	.2286	.1905	.1905	.2286	.2477
11	.1715	.1905	.1905	2.4006	2.2405		2.3148
12	.1524	.1715	.1905	2.4272	2.2725		2.524
13	.1524	.1334	.1905	2.5206	2.2085		2.4806
14	.1524	.1524	.2096	2.2939	2.119	2.3777	2.5892
15	.1524	.1715	.2096	2.1759	2.0873	2.3777	2.3752
16	.2096	.1905	.2286	2.3929	2.0965	2.4615	2.5312
17	.2286	.2096	.3048	1.9814	2.0243	2.3529	2.268
18	.3239	.2667	.3048	2.0576	1.7368	2.2624	2.1085
19	.1334	.3429	.2096	.2096	.2858	.3584	
20	.2858	.3429	.2096	.2096	.2858	.3048	
21		.3048	.1905	.1905	.2096	.2477	.2477
22	.1905	.1905	.2096	.2096	.1905	.1905	.2286
23	.1524	.1905	.1905	.1905	.1334	.1905	.2286
24		.1334	.1905	.1905	.1905	.0953	.1905
Max	2.2119	2.4143	2.692	2.5206	2.2725	2.4615	2.5892
Min	.1143	.1334	.1905	.1334	.1334	.0953	.1905
Avg	.5489	.5102	.4948	.8898	.8415	.7331	1.0872

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244108 / 33/11 KV Koulage

Feeder No / Name : 201 / 11 KV Savarde Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.1698	.168	.1307	.1867	.1494	.168
2	.112	.1494	.1494	.3768	.4588	.25	.3567
3	.112	.168	.168	.3768	.4752	.2812	.3864
4	.1494	.1867	.1867	.4752	.502	.3749	.4214
5	.1848	.2241	.2427	.583	.5243	.4801	
6	.2926	.3395	.2987	.6964	.6554	.6241	.5093
7	.3881	.3961	.4108	.9012	.9602	.8802	.8482
8	.3142	.4108	.4294	.9922	1.3443	1.1843	1.2803
9	.4668	.4481	.4481	1.1843	1.5844	1.4883	1.5061
10	.4207	.4435	.4854	.2987		.3921	.2614
11	1.6032	1.5684	1.5912	.3921		.4294	.3547
12	1.6356	1.5844	1.6712	.4294			.3511
13	1.7004	1.6484	1.5497	.3921		.3696	.3326
14	1.7004	1.6324	1.3443	.4294		.4854	.3696
15	1.4403	1.6324	1.4089	.4108	.3734	.4854	.3841
16	1.6549	1.6324	1.3599	.4294	.4294	.4251	.3696
17	1.6356	1.6004	1.4251	.4481	.4294	.4207	.3696
18	1.5223	1.4403	1.3435	.4108	.4108	.4207	.3511
19	.3174	.3734	.3475	.3206	.2801	.3395	.2972
20	.3395	.3174	.3142	.3018	.2801	.2987	.3326
21	.2829	.2801	.2587	.2829	.2427	.2987	.2587
22	.2641	.2427	.2054	.2452	.2054	.2241	.1867
23	.2263	.2054	.1848	.1867	.1867	.1867	.1867
24	.1494	.1886	.1867	.1494	.1867	.168	.1867
Max	1.7004	1.6484	1.6712	1.1843	1.5844	1.4883	1.5061
Min	.112	.1494	.1494	.1307	.1867	.1494	.168
Avg	.7102	.7201	.6741	.4518	.5114	.4633	.4378

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244125 / 33/11 KV ANJANI (NAGEWADI)

Feeder No / Name : 201 / 11 kv Vadgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0953	.0953	.0953	.0953	.0943	.0943
2	.3887	.3239	.3239	.0762	.0953	.0943	.0754
3	.421	.3401	.3605	.0762	.0953	.0943	.132
4	.4858	.3887	.426	.1132	.1143	.1132	
5	.5571	.5506	.5636	.168	.1715	.1698	
6	.7373	.7935	.7625		.2667	.2641	.2829
7	1.0486	1.1822	1.0242	.3206	.3772	.3772	.3734
8	1.439	1.6164	1.587	.3018	.2452	.2263	.2641
9	1.6324	1.8564	1.6964	.2641	.2263	.1886	.2263
10	.1886	.1698	.1886	.2054	.1509	.1867	.2075
11	.2263	.1886	.2263	1.4998	1.4083	1.3923	1.439
12	.0549	.1886	.1698	1.4563	1.439	1.3435	1.4232
13	.2075	.1494	.1886	1.4998	1.3279	1.4243	1.7078
14	.1698	.168	.168	1.3916	1.3125	1.5238	1.6484
15	.1698	.1867	.168	1.5154	1.0155	1.5384	1.5339
16	.1886	.2054	.1886	1.5935	1.439	1.5364	1.7078
17	.2427	.2054	.2054	1.6762	1.1873	1.3927	1.2163
18	.2075	.2427	.1867	1.4243	1.2003	1.2803	1.3603
19	.2263	.2452	.1848	.2263	.2263	.1663	.2263
20	.1905	.2075	.2075	.1886	.1509	.1886	.1886
21	.1698	.1698	.1509	.1524	.132	.1509	.1509
22	.1143	.132	.1143	.1334	.1132	.132	.1132
23	.0953	.1132	.1143	.1143	.1132	.1132	.0953
24	.0191	.0953	.0953	.0953	.0953	.0943	.0943
Max	1.6324	1.8564	1.6964	1.6762	1.439	1.5384	1.7078
Min	.0191	.0953	.0953	.0762	.0953	.0943	.0754
Avg	.3865	.4089	.3915	.6343	.5416	.5869	.6619

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244125 / 33/11 KV ANJANI (NAGEWADI)

Feeder No / Name : 202 / 11KV Anjani Vadgaon
Gaothan Feeder KV- 11 /
OUTGOING

GAOTHAN FEEDER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1509	.1524	.1524	.1715	.1509	.1886
2	.1509	.1509	.1524	.1524	.1715	.1509	.1509
3	.1509	.1509	.1524	.132	.1715	.1509	.1509
4	.1886	.1886	.2096	.1509	.1905	.1886	.2641
5	.3018	.3206	.3048	.2829	.3239	.3018	
6	.415	.5093	.4338	.4715	.4572	.4527	.4904
7	.5093	.4904	.5093	.4904	.547	.5281	.5281
8	.3921	.2987	.3772	.3584	.3881	.3547	.3772
9	.2402	.2402	.2263	.2587	.2353	.2427	.2614
10	.2033	.2012	.2054	.1848	.1991	.1886	.1848
11	.1663	.1663	.1663	.1629	.1829	.1663	.1646
12	.1848	.1646	.1829	.1646	.1646	.1463	.128
13	.1646	.1646	.1663	.1463	.1629	.1448	.1829
14	.1478	.1646	.168	.1463	.1478	.1646	.1494
15	.1494	.1646	.1478	.1307	.1494	.1612	.168
16	.1509	.1663	.1646	.1132	.1478	.1646	.1663
17	.1829	.1848	.1991	.1494	.168	.1991	.1494
18	.333	.2561	.2561	.3142	.2772	.2614	.2801
19	.4481	.3921		.4854	.4481	.4668	.4527
20	.3772	.3961	.3961	.3921	.4294	.415	.4338
21	.3206	.3395	.3395	.3584	.3395	.3772	.3584
22	.2452		.2477	.2452	.3018	.3018	.2667
23	.2075	.2075	.2096	.1905	.2263	.2641	.2286
24	.0191	.1698	.1715	.1715	.1715	.1886	.2075
Max	.5093	.5093	.5093	.4904	.547	.5281	.5281
Min	.0191	.1509	.1478	.1132	.1478	.1448	.128
Avg	.2417	.2452	.2408	.2419	.2572	.2555	.2579

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244125 / 33/11 KV ANJANI (NAGEWADI)

Feeder No / Name : 203 / 11 KV Gavan Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0895	.0754	.0739	.0762	.0754	.0754	.0943
2	.0905	.0754	.0739	.7865	.6958	.6874	.8322
3	.0914	.0754	.0747	.9442	.759	.6874	.9175
4	.128	.0943	.112	1.0486	.8539	.759	.9602
5	.1663	.1698	.1494	1.1203	.9602	.8539	
6	.2427	.2641	.2075	1.2289	1.2483	1.0242	1.1043
7	.2987	.2829	.2829	1.5074	1.7004	1.4899	1.5223
8	.2614	.3018	.2452	1.7695	1.9595	1.6964	1.8515
9	.2241	.2614	.2075	1.9204	2.0891	2.0481	1.9662
10	.2614	.2033	.2075	.1132	.1097	.1829	.168
11	2.2611	2.5029	2.4086	.1663	.1494	.2054	.2054
12	2.3102	2.6686	2.4413	.1886	.1867	.168	.1867
13	2.2834	2.5232	2.7018	.1646	.168	.1663	.2075
14		2.4741	2.4966	.2012	.2054	.1867	.2075
15		2.4249	2.4249	.1829	.1698	.2033	.2054
16	2.2939	2.2348	2.2611	.2012	.0754	.2195	
17	2.2775	2.2024	2.1605		.0732	.181	.1867
18	2.0165	1.9845	1.8404	.2075	.1478	.1646	.2075
19	.2075	.2263	.1307	.2075	.2241	.1663	.2263
20	.1698	.1494	.1509	.1886	.1509	.1886	.2075
21	.1509	.1294	.132	.132	.132	.168	.1494
22	.132	.0924	.112	.1132	.132	.132	.132
23	.0943	.0739	.0943	.0943	.1132	.1132	.0943
24	.0191	.0754	.0739	.0754	.0754	.0943	.0943
Max	2.3102	2.6686	2.7018	1.9204	2.0891	2.0481	1.9662
Min	.0191	.0739	.0739	.0754	.0732	.0754	.0943
Avg	.7305	.8986	.8776	.5495	.5189	.4942	.5330

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244133 / 33/11 KV Manjarde Stn

Feeder No / Name : 201 / 11 KV DATTANAGAR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0747	.0754	.0754	.0754	.0566	.0754
2	.4161	.4062	.3906	.0566	.0754	.0566	.0754
3	.4161	.4161	.3906	.0566	.0754	.0566	.0754
4	.4481	.4481	.4428	.0566	.0754	.0754	.0754
5	.4801	.4999	.5535	.1509	.0943	.1132	
6	.5601	.5921	.6562	.1886	.1698	.1886	.1886
7	.8192	.9962	.9602	.2829	.2641	.2452	.2452
8	.7621	1.2193	1.1873	.2241	.2075	.2075	.2075
9	.9877	1.2809	1.2041	.1109	.112	.112	.1509
10	.0943	.0709	.0732	.0924		.0739	.0934
11	.0732	.0924	.0554	.945		.8429	.8951
12	.0709	.0739	.0532	1.0648		1.0084	.9998
13	.0732	.0732	.0366	1.0669		1.0254	1.0311
14	.0543	.0924	.037	1.1248	.5864	1.0385	.9998
15	.0724	.0905	.037	1.1561	.9374	1.1431	1.0311
16	.0886	.104	.0554	1.2191	1.034	1.2346	1.0936
17	.1267	.1326	.1097	1.0974	.9031	1.1138	.8951
18	.1612	.1578	.1494	.9297	.7468	.6144	.823
19	.168	.168	.1509	.1509	.1494	.168	.1509
20	.1509	.1698	.1698	.1509	.1494	.168	.1509
21	.132	.1509	.132	.132	.1307	.1307	.1132
22	.1132	.1132	.1109	.0943	.0943	.1132	.0943
23	.0934	.0943	.0924	.0754	.0754	.0943	.0754
24	.0566	.0747	.0754	.0754	.0754	.0566	.0754
Max	.9877	1.2809	1.2041	1.2191	1.034	1.2346	1.0936
Min	.0543	.0709	.0366	.0566	.0754	.0566	.0754
Avg	.2698	.3163	.3000	.4407	.3016	.4141	.4181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244133 / 33/11 KV Manjarde Stn

Feeder No / Name : 202 / 11 KV GOURGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.0526	.0686	.0716	.0709	.0701	.0709
2		.0526	.0716	.2058	.2934	.2858	.2934
3	.056	.0526	.0724	.3353	.2972	.3041	.2896
4	.0747	.0537	.0739	.3277	.3864	.3041	.3185
5	.0934	.0732	.0739	.3605	.4287	.3715	
6	.112	.0934	.1109	.4214	.5502	.4607	.4193
7	.0373	.1494	.181	.578	.7819	.7225	.6539
8	.128	.1086	.1646	.6249	.9808	.8993	.9602
9	.0848	.0914	.124		.9511	.7335	1.0059
10	.0829	.0867	.1463			.0905	.0886
11	.9482	.9065	.9105			.1075	.0693
12	1.1145	.9604	.9755	.0492		.0819	.0867
13	1.174	1.0551	.9755	.0709		.0772	.1075
14	1.2191	1.0837	1.0623	.0895	.0503		.0895
15	1.1584	1.0402	1.1203	.0716	.0701	.0838	.0895
16	1.0551	1.0269	1.2431	.0709	.1267	.1052	.1267
17	1.0848	.9701	.945	.0895	.0867	.0995	.124
18	.9288	.8398	.7682	.0934	.1063	.104	.1017
19	.1294		.112	.1663	.1294	.1494	.128
20	.0905	.1267	.1307	.1478	.128	.128	.1463
21	.1097	.1075	.1097	.1294	.1075	.1097	.1097
22	.0914	.0848	.0924	.0905	.0886	.0905	.0886
23	.0739	.0655	.0732	.0709	.0701	.0724	.0709
24	.0503	.048	.0648	.0716	.0693	.0678	.0716
Max	1.2191	1.0837	1.2431	.6249	.9808	.8993	1.0059
Min	.0373	.048	.0648	.0492	.0503	.0678	.0693
Avg	.4327	.3969	.4029	.1970	.2887	.2400	.2396

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244133 / 33/11 KV Manjarde Stn

Feeder No / Name : 203 / 11 KV MANJARDE VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0381	.0566	.0377	.0381	.0381	.0381
2	.0566	.0381	.0566	.0377	.0381	.0191	.0381
3	.0566	.0381	.0566	.0377	.0381	.0191	.0381
4	.0566	.0381	.0566	.0566	.0572	.0381	.0381
5	.0943	.0572	.0754	.0754	.0754	.0754	
6	.1132	.0754	.0953	.0943	.1132	.0943	.0953
7	.1307	.1509	.1307	.1132	.132	.1509	.1494
8	.0934	.0924	.1109	.1132	.0943	.0943	.1132
9	.0924	.056	.0754	.0934	.0566	.0566	.0747
10	.0377	.0362	.037	.0747		.0549	.0732
11	.0358	.0373	.0373			.0554	.0549
12	.0362	.0366	.0354	.037		.0373	.0366
13	.0351	.0358	.0377	.0373		.0549	.0566
14	.0185	.0373	.0377	.037	.0693	.056	.0373
15	.0373		.0377	.037	.0716	.0537	.0373
16	.0366	.037	.0377	.0362	.0543		.0366
17	.0362	.0537	.0739	.0543	.0543	.0532	.0373
18	.0716	.0895	.0934	.0934	.1097	.0905	.0747
19	.1307	.1478	.1132	.1494	.1463	.1494	.0747
20	.1132	.1646	.1132	.1307	.112	.132	.1307
21	.0943	.1307	.0943	.1132	.112	.0953	.1132
22	.0754	.0934	.0762	.0943	.0754	.0762	.0754
23	.0566	.0747	.0762	.0572	.0572	.0572	.0754
24	.0191	.0377	.056	.0377	.0381	.0381	.0572
Max	.1307	.1646	.1307	.1494	.1463	.1509	.1494
Min	.0185	.0358	.0354	.0362	.0381	.0191	.0366
Avg	.0660	.0694	.0696	.0717	.0772	.0691	.0677

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244139 / 33/11KV Jarandi

Feeder No / Name : 201 / 11 KV Jarandi Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0934	.0924	.0934	.112	.0905	.0943
2	.0633	.0943	.0943	.0914	.0739	.0905	.0934
3	.0655	.0943	.0943	.0747	.0934	.0934	.112
4	.0671	.0943	.0943	.0943	.132	.0943	.1509
5	.1052	.1132	.132	.112	.1509	.1698	.1663
6	.1867	.2263	.2402	.3258	.3292	.2075	.2263
7	.2641	.3018	.2715	.2865	.2896	.2641	.2829
8	.2263	.2075	.2054	.2686	.2378	.2075	.2075
9	.1698	.1509	.1715	.1753	.1448	.1509	.1509
10	.1646	.1629	.1595	.12	.1581	.168	.0943
11	.1307	.1478	.1463	.0934	.1214	.1494	.1509
12	.1448	.1307	.128	.1097	.1227	.1294	.1132
13	.112	.1132	.1109	.0934	.1063	.112	.0678
14	.1294	.1109	.0924	.0754	.104	.0934	.0686
15	.132	.128	.0934	.0747	.0943	.0943	.0671
16	.1646	.1629	.1097	.0739	.1214	.112	.0924
17	.1715	.1457	.1715	.128	.1187	.1478	.1132
18	.2149	.192	.2103	.1867	.1991	.1753	.1886
19	.2614	.2534	.2012	.2926	.2452	.2743	.2263
20	.2054	.2149	.2427	.2218	.2075	.2075	.1886
21	.2241	.2279	.1829	.2054	.1886	.168	.1698
22	.132	.1417	.1629	.168	.112	.1509	.1494
23	.112	.1254	.1463	.1478	.1132	.1307	.1075
24	.0876	.0924	.0924	.1109	.132	.0943	.112
Max	.2641	.3018	.2715	.3258	.3292	.2743	.2829
Min	.0633	.0924	.0924	.0739	.0739	.0905	.0671
Avg	.1509	.1552	.1519	.1510	.1545	.1490	.1414

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244139 / 33/11KV Jarandi

Feeder No / Name : 202 / 11 KV Jarandi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0754	.0943	.112	.112	.0943	.0934
2	.0754	.0754	.0747	.1658	.4481	.4268	.2984
3	.0754	.0754	.0739	.1966	.506	.4999	.4096
4	.0754	.0754	.0739	.2591	.6249	.6401	.4858
5	.132	.132	.132	.3041	.7011	.7362	.5344
6	.2075	.2263	.2075	1.0936	1.3748	.8421	.8002
7	.2641	.3018	.2829	1.2346	1.4232	1.2308	1.1984
8	.1698	.1886	.2075	1.0437	1.3923	1.3763	1.4575
9	.1494	.1509	.1698	1.1092	1.5061	1.4575	1.5043
10	.1463	.112	.1132	.0747	.132	.1109	.0747
11	1.4413	1.4251	1.1683	.0754	.112	.0943	.0934
12	1.5844	1.3603	1.2029	.056	.112	.0924	.0739
13	1.3283	1.2967	1.1883	.0739	.132	.0747	.0747
14	1.4706	1.4243	1.2498	.0377	.132	.0566	.0934
15	1.4563	1.4723	1.3916	.056	.1509	.056	.1132
16	1.6004	1.3748	1.2498	.0943	.132	.0754	.0934
17	1.4685	1.3748	1.2498	.112	.1307	.0934	.112
18	1.3272	1.2191	1.1111	.1478	.168	.1294	.1494
19	.2075	.2075	.1402	.2054	.1886	.2241	.1886
20	.1886	.1698	.1646	.1867	.1698	.1698	.1509
21	.1698	.1509	.1478	.1478	.1509	.1307	.132
22	.1132	.132	.132	.1307	.132	.1132	.1132
23	.0943	.1132	.112	.1132	.132	.0934	.0943
24	.0747	.0747	.0943	.0943	.0943	.0943	.0754
Max	1.6004	1.4723	1.3916	1.2346	1.5061	1.4575	1.5043
Min	.0747	.0747	.0739	.0377	.0943	.056	.0739
Avg	.5790	.5504	.5013	.2969	.4232	.3714	.3506

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244139 / 33/11KV Jarandi

Feeder No / Name : 203 / 11 KV Dahiwadi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0543	.056	.056	.0566	.056	.0566	.0566
2	.3086	.3048	.3048	.0554	.0739	.0566	.056
3	.3125	.3858	.3749	.0732	.0934	.056	.0754
4	.3437	.4843	.4321	.0895	.1132	.0566	.0934
5	.4001	.5668	.5079	.1109	.1307	.132	.1307
6	.5344	.6299	.5801	.168	.2218	.1886	.1886
7	.6718	.8848	.8962	.2218	.2561	.2075	.1698
8	.9282	1.0202	.9762	.1829	.2033	.1886	.1494
9	.8002	1.0722	1.0437	.128	.128	.0747	.112
10	.128	.1086	.0747	.1267	.0867	.0754	.1097
11	.1494	.0924	.12	.5761	.8802	.8855	.9172
12	.128	.0934	.0905	.8097	.9393	.9145	1.0595
13	.1086	.0914	.0732	.8802	1.012	.9568	.9414
14	.0867	.1109	.0739	1.0437	1.0562	.9998	.9686
15	.1267	.1097	.0732	1.1203	1.0562	1.0753	1.012
16	.1086	.1478	.0914	1.0883	1.0562	.7964	.9842
17	.12	.128	.0924	.9374	.828	.743	.9105
18	.1448	.1463	.1086	.6554	.7499	.6516	.8356
19	.168	.1494	.1478	.2149	.1307	.1848	.1307
20	.1494	.112	.132	.1829	.112	.1307	.1307
21	.1307	.0934	.1132	.1109	.0924	.1132	.112
22	.0934	.0739	.0934	.0934	.0732	.0934	.0934
23	.0747	.0747	.0754	.0754	.0747	.0754	.0739
24	.0543	.0554	.056	.056	.0566	.0566	.0566
Max	.9282	1.0722	1.0437	1.1203	1.0562	1.0753	1.0595
Min	.0543	.0554	.056	.0554	.056	.056	.056
Avg	.2552	.2913	.2745	.3774	.3950	.3654	.3903

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 201 / 11 KV KUMTHE NAGAON

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /
OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.1143	.132	.2667	.132	.1905	.132
2	.2286	.1143	.1132	.2477	.1132	.1905	.132
3	.2286	.1143	.112	.2477	.1132	.1715	.132
4	.2667	.1143	.1132	.2858	.112	.1715	.1307
5	.2667	.1334	.1663	.2858	.1509	.2096	.1886
6	.2858	.2667	.2614	.3429	.2427	.2858	.2587
7	.3429	.3048	.2614	.3429	.2829	.3429	.2987
8	.2286	.2477	.2614	.2858	.2587	.2667	.2772
9	.2096	.2286	.2075	.2286	.1867	.3429	.1886
10	.1905	.1715	.1905	.1867	.156	.1905	.156
11	.1524	.1715	.1772	.1509	.1543	.1715	.1524
12	.1524	.1715	.1753	.112	.1715	.1524	.1524
13	.1524	.1524	.1524	.1132	.1334	.1524	.1524
14	.1524	.1524	.1524	.1132	.1524	.1524	.1524
15	.1715	.1524	.1524	.112	.1524	.1524	.1524
16	.1715	.1715	.1524	.112	.1524	.1715	.1715
17	.1715	.1905	.1753	.132	.1524	.1905	.1905
18	.2149	.2218	.2126	.2614	.2096	.2263	.2172
19	.362	.3734	.2286	.3395	.3429	.2641	.2477
20	.2858	.3395	.2858	.3174	.3048	.2829	.2667
21	.2477	.2772	.3048	.3018	.2858	.2561	.3048
22	.2477	.2241	.2858	.2614	.2477	.2378	.3048
23	.1524	.1886	.2858	.2263	.1905	.2054	.2858
24	.2477	.1334	.1509	.2667	.1867	.1905	.168
Max	.362	.3734	.3048	.3429	.3429	.3429	.3048
Min	.1524	.1143	.112	.112	.112	.1524	.1307
Avg	.2241	.1971	.1963	.2309	.1910	.2154	.2006

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 204 / 11 KV Kumthe Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.1524	.1509	.1905	.112	.1524	.1307
2	.1905	.1524	.1509	.5155	.4372	.4578	.4586
3	.1905	.1524	.1494	.5937	.4374	.4578	.4752
4	.2286	.1334	.1509	.6859	.4534	.5344	.4687
5	.2286	.1524	.1848	.884	.5761	.5344	.6104
6	.2477	.2286	.2641	1.0526	.8436	.7432	.7343
7	.3239	.3048	.2614	1.247	1.2346	1.1544	1.1736
8	.2667	.2858	.2561	1.3904	1.7164	1.5971	1.6406
9	.2286	.2477	.2353	1.6518	1.89	1.781	1.7985
10	.1905	.2667	.2858	.1867	.1905	.1905	.1905
11	2.0317	1.9334	1.4529	.1494	.1905	.1715	.1524
12	1.9204	1.9364	2.0081	.0943	.1905	.1524	.1524
13	1.8351	1.9608	1.9134	.0754	.1524	.1524	.1524
14	1.9334	2.0567	1.8884	.0377	.2286	.1905	.1715
15	2.0005	2.0405	1.873	.1646	.2286	.1905	.2286
16	2.1376	1.1385	1.7604	.1867	.2286	.1524	.1905
17	2.0485	1.7604	1.7029	.2263	.1905	.1905	.1905
18	1.6716	.9907	1.6248	.2241	.1715	.1698	.2286
19	.2477	.2241	.1905	.1867	.2477	.2054	.2286
20	.2286	.1867	.2096	.1886	.2477	.2263	.2096
21	.2286	.1886	.2096	.1867	.2286	.2033	.2096
22	.2286	.1867	.2096	.1509	.1905	.1829	.2096
23	.1715	.1886	.1905	.1494	.1715	.1509	.1905
24	.2096	.1524	.168	.1905	.132	.1524	.132
Max	2.1376	2.0567	2.0081	1.6518	1.89	1.781	1.7985
Min	.1715	.1334	.1494	.0377	.112	.1509	.1307
Avg	.7999	.7092	.7288	.4421	.4454	.4206	.4303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 206 / 11 KV Upalavi Matkunki Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132		.1132	.2075	.0934	.0754	.0934
2	.5468	.6036	.5468	.1886	.0943	.0754	.0943
3	.6093	.5967	.5761	.1886	.0943	.0754	.0943
4	.6481	.5898	.5668	.2452	.0943	.0754	.0943
5	.8796	.7287	.6958	.2452	.1307	.1132	.1307
6	.9962	.8583	.9762	.2829	.1886	.1886	.1886
7	1.1385	1.4232	1.3748	.2829	.2641	.2641	.2378
8	1.4243	2.0165	1.768	.2452	.2402	.2587	.2402
9	1.8244	2.0485	1.4899	.2263	.1867	.2033	.2241
10	.1829	.1463	.2709	.3174	.1595	.1829	.1595
11	.168	.168	.298	1.8343	1.5402	1.3916	1.4723
12	.168	.1829	.3511	1.8747	1.4937	1.5466	1.6324
13	.168	.3012	.2126	1.866	1.5051	1.6248	1.7444
14	.168	.3012	.1629	1.7528	1.7394	1.656	1.7394
15	.168	.197	.2658	1.7444	1.5813	1.6288	1.8244
16	.1867	.1829	.3121	1.7004	1.4529	1.4352	1.9044
17	.1867	.2126	.2658	1.8122	1.3889	1.4232	1.7604
18	.2218	.2218	.2402	1.5971	1.3916	1.085	1.5779
19	.2452	.2241	.2218	.2033	.1886	.1886	.1509
20	.2263	.1848	.2075	.1848	.1698	.1886	.1509
21	.2075	.1848	.2075	.1494	.1509	.168	.1698
22	.2075	.1494	.2263	.1509	.1132	.1509	.1698
23	.1663	.1494	.2263	.1307	.0934	.1132	.1509
24	.132	.1478	.132	.2075	.1132	.0754	.0943
Max	1.8244	2.0485	1.768	1.8747	1.7394	1.656	1.9044
Min	.132	.1463	.1132	.1307	.0934	.0754	.0934
Avg	.4584	.5139	.4879	.7349	.6028	.5912	.6708

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 207 / Nagaon Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3206	.2218	.1886	.3206	.2075	.2218	.2075
2	.3018	.1848	.1886	.2829	.2054	.2218	.2075
3	.3018	.1848	.1867	.2452	.2075	.2241	.2054
4	.2829	.1848	.1886	.2263	.2075	.2241	.2075
5	.2829	.2195	.2075	.3206	.2452	.2587	.2427
6	.3018	.3109	.2614	.3584	.2926	.3292	.3395
7	.3206	.3142	.3018	.3584	.3142	.3475	.3547
8	.2801	.2957	.2743	.3174	.2772	.2926	.3018
9	.2801	.2587	.2772	.2561	.2241	.2561	.2801
10	.2195	.2561	.2103	.2218	.2012	.2195	.2561
11	.2195	.2561	.1772	.2378	.2012	.2561	.2012
12	.2195	.2378	.1829	.2614	.1829	.2378	.2195
13	.2012	.2195	.1991	.2772	.0914	.2378	.2561
14	.2012	.2012	.1991	.2427	.1097	.2195	.2561
15	.2195	.2012	.2126	.2218	.128	.2012	.2561
16	.2195	.2195	.2427	.2241	.1463	.2012	.2743
17	.2561	.2561	.3155	.2561	.1715	.2561	.2743
18	.3841	.4251	.3898	.4066	.3292	.4108	.3086
19	.4706	.4854	.4251	.4207	.439	.4338	.333
20	.4344	.4715	.4572	.4066	.3841	.439	.3658
21	.3801	.3734	.4108	.3841	.3658	.3734	.4294
22	.3801	.2987	.3734	.3361	.3109		.3734
23	.3511	.2402	.3584	.2641	.2561	.2614	.3511
24	.3206	.2772	.2054	.3584	.2241	.2402	.2075
Max	.4706	.4854	.4572	.4207	.439	.439	.4294
Min	.2012	.1848	.1772	.2218	.0914	.2012	.2012
Avg	.2979	.2748	.2681	.3002	.2384	.2767	.2796

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 208 / Nagaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0497	.0377	.0339	.0381	.0509	.0377
2	.0347	.0509	.0377	.2782	.426	.3125	.2949
3	.0347	.052	.0377	.3755	.421	.3549	.2812
4	.0526	.0532	.0377	.439	.4161	.3612	.2881
5	.0526	.0543	.0381	.5213	.4588	.3864	.3077
6	.0532	.0724	.0566	.602	.5506	.3909	.3441
7	.0532	.0716	.056	.6321	.7186	.6249	.5312
8	.0514	.0709	.0566	.8688		.8069	.6401
9	.0514	.0732	.056	.9414	1.0883	.9332	.7968
10	.0514	.0732	.0705	.056	.052	.0328	.0514
11	1.2342	.8522	1.1126	.0373	.0693	.0309	.0648
12	1.2811	1.1843	1.3748		.0549	.0271	.0486
13	1.3426	1.2643	1.2967		.0914	.0293	.0339
14	1.3735	1.3599	1.3426		.0716	.0271	.0343
15	1.3123	1.3283	1.3441		.0716	.0282	.0509
16	1.2967	1.2803	1.2809		.0732	.0469	.0537
17	1.2963	1.2041	1.1405	.0566	.0732	.044	.0724
18	1.1111	1.1843	1.0669	.0934	.0693	.0754	.0446
19	.0663	.0747	.0663	.0754	.0716	.056	.0514
20	.0678	.0747	.0663	.0747	.0693	.0566	.0693
21	.0663	.0566	.0671	.0566	.0693	.0566	.0686
22	.0663	.056	.0671	.0566	.0526	.0377	.0686
23	.0497	.0377	.0503	.0381	.0497	.0373	.0526
24	.0343	.0497	.0373	.0509	.0381	.0509	.0377
Max	1.3735	1.3599	1.3748	.9414	1.0883	.9332	.7968
Min	.0343	.0377	.0373	.0339	.0381	.0271	.0339
Avg	.4612	.4429	.4499	.2783	.2215	.2024	.1802

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 201 / 11 KV PED AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.1509	
2					.6173	
3					.9259	
4					1.0669	
5					1.3717	
6					1.8061	
7					2.1373	
9					2.452	
10					.1867	
11					.1132	
23	.1509	.1372		.1543	.1494	
24	.132		.132		.1543	.1463
Max	.1509	.1372	.132	.1543	2.452	.1463
Min	.132	.1372	.132	.1543	.1132	.1463
Avg	.1415	.1372	.132	.1543	.9276	.1463

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 202 / 11 KV HATNUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0943		.1132	
2			.5201		.1132	
3			.6773		.1132	
4			.8488		.1307	
5			1.0802		.1307	
6			1.4842		.1494	
7			1.704		.2054	
8					.2241	
9					.1478	
10					.1663	
11					1.4548	
12					1.4723	
13			1.9433			
23	.1132	.1029		.12	.0934	
24			.0943		.1029	.0914
Max	.1132	.1029	1.9433	.12	1.4723	.0914
Min	.1132	.1029	.0943	.12	.0934	.0914
Avg	.1132	.1029	.9385	.12	.3298	.0914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077] BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 204 / 11KV HATNUR GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.168	
2					.1494	
3					.1494	
4					.168	
5					.1867	
6					.2241	
7					.2801	
8					.2614	
9					.2054	
10					.1867	
11					.1402	
12					.1387	
23	.2263	.1734		.2241	.1886	
24	.1698		.1734		.1867	.1886
Max	.2263	.1734	.1734	.2241	.2801	.1886
Min	.1698	.1734	.1734	.2241	.1387	.1886
Avg	.1981	.1734	.1734	.2241	.1881	.1886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 206 / 11 KV PED GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0373	
2					.0373	
3					.0373	
4					.056	
5					.0747	
6					.1307	
7					.1867	
8					.168	
9					.056	
10					.056	
11					.0554	
12					.0362	
23	.0754	.052		.056	.0754	
24	.0754		.052		.0373	.0377
Max	.0754	.052	.052	.056	.1867	.0377
Min	.0754	.052	.052	.056	.0362	.0377
Avg	.0754	.052	.052	.056	.0746	.0377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077] BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 208 / VIJAYNAGAR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.1698	
2					.5944	
3					.7335	
4					.8802	
5					1.1888	
6					1.3546	
7					1.6347	
8					1.7751	
9					1.7897	
10					.1829	
11					.1463	
12					.1448	
23	.2075	.2058		.1886	.1509	
24	.132		.1867		.1715	.1307
Max	.2075	.2058	.1867	.1886	1.7897	.1307
Min	.132	.2058	.1867	.1886	.1448	.1307
Avg	.1698	.2058	.1867	.1886	.7798	.1307

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 209 / 11 KV HONAI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0373		.0377	
2			.0373		.3391	
3			.0377		.4287	
4			.0377		.5201	
5			.0373		.5548	
6			.056		.6068	
7			.0747		.6944	
8			.056		.7099	
9			.056		.7407	
10			.056		.0373	
11			.8583		.0373	
12					.0554	
23	.0377	.0362		.0343	.0377	
24	.0566		.0373		.0343	.0366
Max	.0566	.0362	.8583	.0343	.7407	.0366
Min	.0377	.0362	.0373	.0343	.0343	.0366
Avg	.0472	.0362	.1151	.0343	.3453	.0366

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 201 / 11 KV PANMALEWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.0943	.132	.1307	.1307	.0943	.1109
2	1.3272	1.1683	1.2597	.1132	.1132	.0943	.112
3	1.3272	1.2003	1.2289	.0934	.112	.0943	.112
4	1.3923	1.2631	1.2452	.1132	.132	.0943	.132
5	1.1469	1.3108	1.2597	.1307	.1509	.1132	.1494
6	1.2323	1.3279	1.3592	.1886	.1886	.1698	.1848
7	1.587	1.587	1.6907	.1867	.2614	.2075	.1848
8	1.8399	2.0481	2.2045	.2075	.2614	.2263	.2427
9	2.13	2.3594	2.343	.1774	.2452	.2075	.2033
10	.1543	.197	.1307	.181	.2241	.2241	.2033
11	.1823	.1307	.168	2.2996	2.4531	1.9826	2.2708
12	.2058	.112	.2075	2.4366	2.2542	2.304	2.42
13	.2658	.1867	.2054	2.652	2.3205	2.2611	
14	.2686	.2427	.2075	2.8509	2.2939	2.2874	
15	.2865	.2987	.2054	2.6023	2.2939	2.1956	.216
16	.3174	.2987	.1056	2.6023	2.1051		.2812
17	.2957	.2987	.2241	2.3205	1.7695		.5121
18	.2452	.2427	.2427	2.0645	1.6194	1.6194	1.4255
19	.2241	.1886	.2075	.2033	.1698	.2075	.2241
20	.1886	.1886	.2054	.2033	.1698	.2054	.1991
21	.1509	.1886	.1867	.1698	.1509	.1867	.1848
22		.1698	.168	.132	.1509	.1433	.1494
23	.112	.1494		.132	.1132	.132	.1294
24	.1097	.0943	.132	.1307	.1307	.0943	
Max	2.13	2.3594	2.343	2.8509	2.4531	2.304	2.42
Min	.1097	.0943	.1056	.0934	.112	.0943	.1109
Avg	.6566	.6394	.6661	.9301	.8256	.6884	.4594

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 202 / 11 KV BORGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0943	.1132	.0953	.112	.0754	.0934
2	.0953	.0953	.0943	.0953	.1132	.0762	.0943
3	.0953	.0747	.1132	.0943	.1132	.0762	.0943
4	.0754	.0747	.1132	.0747	.132	.0762	.0934
5	.1494	.1494	.1509	.132	.1886	.1334	.1132
6	.2263	.2075	.2241	.2241	.2263	.2286	.2427
7	.2241	.2614	.2772	.2218	.2614	.2452	.2801
8	.2054	.2241	.1867	.2218	.2427	.2427	.2241
9	.1478	.1629	.1663	.1756	.2033	.1663	.1774
10	.1448	.1387	.1646	.1417	.1097	.1494	.1791
11	.1433	.1417	.1307	.1097	.1075	.124	.1448
12		.0732	.1075	.1109	.1109	.1254	.1463
13		.0724	.0914	.0924	.0739	.1097	.1075
14	.0914	.0739	.0924	.0943	.0747	.0924	.0914
15	.0924	.0914	.0914	.0747	.0754	.0739	.0924
16	.0905	.0747	.0914	.0747	.0747	.0724	.0905
17	.1075	.1086	.1478	.1086	.1307	.0709	.0905
18	.1791	.197	.2012	.1949	.2033	.1463	.1463
19	.2926	.3109	.2957	.2926	.2587	.2926	.3077
20	.2772	.2987	.2614	.3142	.2614	.2772	.2772
21	.2263	.2241	.2241	.2614	.2241	.2427	.2427
22	.1905	.2054	.1509	.2054	.168	.2054	.2054
23	.132	.1132		.1294	.1132	.1494	.1307
24	.1132	.1143	.0943	.0953	.1307	.0754	.1056
Max	.2926	.3109	.2957	.3142	.2614	.2926	.3077
Min	.0754	.0724	.0914	.0747	.0739	.0709	.0905
Avg	.1542	.1493	.1558	.1515	.1546	.1470	.1571

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 203 / 11 KV SHIRGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.168
2			.1698
3			.1698
4			.2054
5			.2829
6			.4108
7			.4527
8			.3772
9			.2427
10			.1867
11		.168	.2241
12		.2481	.168
13		.2241	.168
14		.181	.1494
15		.2149	.2075
16		.3045	.2263
17		.3222	.1867
18		.3921	.2427
19		.4481	.4481
20		.415	.3856
21		.3772	.3395
22		.3048	.2858
23		.2614	.2096
24	.3481		.1886
Max	.3481	.4481	.4527
Min	.3481	.168	.1494
Avg	.3481	.2970	.2540

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 204 / 11 KV BORGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	.1698	.1886	.1494	.1509	.1698	.1494
2	.1811	.1715	.1886	1.6741	1.0526	1.3927	1.3279
3	.168	.1524	.1886	1.6385	1.0978	1.3763	1.3763
4	.1509	.1334	.2075	1.5729	1.1797	1.4089	1.4255
5	.1886	.2263	.2263	1.5581	1.2929		1.4575
6	.2641	.3018	.2614	1.5729	1.5746	1.5249	1.5729
7	.2614	.3584	.3174	1.8896	1.5565	1.7072	1.6194
8	.2829	.3018	.2987	1.9989	1.7204	1.989	1.873
9	.2427	.2829	.2987	1.917	2.0481	2.1051	1.8785
10	.2218	.2772	.2402	.2218	.1867	.2801	.2054
11	2.5857	2.3205	2.3805	.2054	.1867	.2987	.2241
12	2.5526	2.3868	2.6023	.2402	.2054	.2801	.2241
13		2.2542	2.5396	.2402	.1867	.2829	.2218
14	2.6852	2.3868	2.4863	.2614	.2241	.2987	.2241
15	2.6189	2.4366	2.4813	.2241	.2241	.2587	.2801
16	2.5301	2.3868	2.3922	.2614	.1867	.2772	.2427
17	2.6023	2.2939	2.2348	.2587	.1867	.2801	.2801
18	2.4034	2.5194	1.9919	.2587	.2263	.2801	.2614
19	.2587	.2801	.2263	.2452	.2641	.2641	.2801
20	.2772	.2829	.2241	.1886	.2641	.2614	.2614
21	.2614	.2641	.2263	.2075	.2075	.2452	.2263
22	.2427	.2427	.2075	.2075	.1886	.2075	.2241
23	.2241	.2075		.168	.1886	.1867	.1867
24	.168	.1886	.1886	.1792	.1509	.1698	.1811
Max	2.6852	2.5194	2.6023	1.9989	2.0481	2.1051	1.8785
Min	.1509	.1334	.1886	.1494	.1509	.1698	.1494
Avg	.9365	.9511	.9825	.7225	.6146	.6759	.6752

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 205 / 11 KV SHIRGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2427	.2427	.2075	.2641	.2641	.2641	.1086
2	1.326	1.2071	1.2125	.2641	.2614	.2452	.1014
3	1.3748	1.2146	1.2289	.2452	.2427	.2452	.0914
4	1.3435	1.3108	1.2929	.2801	.3018	.2641	.0934
5	1.4586	1.4251	1.3748	.381	.3961	.3772	.1294
6	1.6108	1.749	1.6766	.5335	.5144	.5335	.2241
7	2.0119	2.2382	2.2801	.6535	.6908	.6653	.2829
8	2.6155	2.5652	2.3868	.6348	.5281	.5228	.2614
9	2.6023	2.4577	2.4741	.4805	.4294	.4435	.2402
10	.2957	.3018	.362	.3856	.2241		.156
11	.3326	.3467	.3292	2.4086	2.3205	1.9757	2.2874
12	.3326	.3721	.2865	2.5194	2.4905	2.1538	2.2939
13		.298	.3109	2.6189	2.4577	2.1862	2.3562
14	.3258	.3174	.362	2.6355	2.4813	2.1862	2.2138
15	.362	.3696	.3658	2.652	2.4531	2.1376	2.3845
16	.4119	.3361	.3761	2.652	2.2775	2.0325	2.0805
17	.3292	.3582	.4024	2.5857	2.0325	.8535	2.1605
18	.4525	.4435	.4294	2.332	1.9662	.8583	1.9044
19	.6283	.5975	.5788	.591	.5914	.1774	.1867
20	.6348	.5601	.5415	.6036	.5788	.1867	.168
21	.5281	.4668	.4527	.5093	.4481	.1663	.1494
22	.4338	.4108	.362	.4191	.4108	.1405	.128
23	.3239	.2987		.3429	.3018	.1307	.1075
24	.2829	.2829	.2427	.2614	.2667	.2641	.1075
Max	2.6155	2.5652	2.4741	2.652	2.4905	2.1862	2.3845
Min	.2427	.2427	.2075	.2452	.2241	.1307	.0914
Avg	.8809	.8404	.8494	1.1356	1.0387	.8265	.8424

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 206 / 11 KV PANMALEWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0572	.0377	.056		.0566	.056
2	.0566	.056	.0377	.056		.0566	.0566
3	.049	.056	.0381	.056		.0566	.056
4	.0377	.0747	.0381	.0566		.0566	.0566
5	.0747	.112	.0572	.0754		.0754	.0747
6	.0943	.1307	.1132	.1132		.0943	.1132
7	.1307	.1646	.128	.1307	.1663	.1478	.132
8	.1109	.1109	.1086	.1109	.132	.1097	.128
9	.1143	.1063	.1075	.0754	.112	.0724	.1063
10	.1886	.0895	.0709	.104	.1063	.0747	.1086
11	.0747	.0693	.0732	.0905	.0886	.1006	.052
12	.0572	.0886	.0693	.1097	.0739		.0526
13		.0362	.0732	.0549	.0537	.0732	.0543
14	.0747	.0358	.0716	.0543	.0566	.0724	.0716
15	.0724	.0572	.0934	.0754	.0943	.0678	.0543
16	.0716	.0572	.1075	.0549	.0747	.056	.0543
17	.0724	.0526	.0934	.0716	.0924	.0848	.0693
18	.0754	.056	.1086	.1132	.1294	.128	.0724
19	.1829	.1791	.1791	.1829	.1698	.197	.1791
20	.1646	.1646	.1463	.1478	.1478	.168	.1646
21	.1294	.1294	.1294	.112	.112	.1478	.1478
22	.0943	.1109	.0934	.0943	.0747	.0943	.112
23	.0754	.0566		.0754	.0566	.0747	.0747
24	.056	.0754	.0377	.0554	.0762	.0566	.0566
Max	.1886	.1791	.1791	.1829	.1698	.197	.1791
Min	.0377	.0358	.0377	.0543	.0537	.056	.052
Avg	.0919	.0886	.0875	.0886	.1010	.0923	.0877

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 207 / 11 Kv Nimbalk Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1467		.1341	.1132		.092	.156
2	.1383		.12	1.5524	1.0985	1.2071	1.1949
3	.1334		.12	1.5497	1.1462	1.2071	1.2696
4	.1524		.1299	1.4632	1.2254	1.226	1.307
5	.168		.1257	1.5154	1.2567	1.2449	1.3306
6	.1928		.1635	1.5524	1.3256	1.2449	1.4266
7	.184		.197	1.7558	1.6095	1.4415	1.4815
8	.2147		.2012	1.8823	2.0452	1.8823	2.0237
9		.2054	.1844	1.8823	2.1176	1.8823	1.9845
10		.1802	.128		.104	.3734	
11	2.8344	2.9235	2.7995		.1372	.124	
12	3.12	3.1901	2.8527		.124	.144	
13		2.9944	2.8475		.156	.184	
14	3.0498	3.0653	2.7109		.156	.192	
15	3.2076	3.1007	2.7435		.136	.0419	
16	2.959	2.7938	2.5431		.148	.0419	
17	2.8172	2.5692	2.3777		.152	.241	
18	2.3102	2.5692	2.1357		.1886	.2191	
19		.2016	.1677		.184	.2286	
20		.1972	.184		.1677	.2147	
21		.1928	.1709		.176	.2103	
22		.1802	.1467		.1677	.2016	
23		.1383			.1	.1578	
24	.1383		.1341	.1174		.096	.1467
Max	3.2076	3.1901	2.8527	1.8823	2.1176	1.8823	2.0237
Min	.1334	.1383	.12	.1132	.1	.0419	.1467
Avg	1.3604	1.6335	1.0138	1.3384	.6328	.5874	1.2321

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 208 / 11kv VISAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0934	.0924	.112	.0934	.0943	.0934
2	.9217	.9922	.7655	.1132	.0924	.0943	.0943
3	.9602	1.0526	.8855	.0934	.0934	.0943	.0934
4	.9804	1.1012	.9762	.0943	.1132	.0943	.1132
5	1.0402	1.1523	1.0562	.112	.1143	.1132	.132
6	1.1385	1.2955	1.247	.1307	.132	.1509	.168
7	1.6324	1.6385	1.6057	.1867	.2054	.2054	.1886
8	1.8679	1.9662	2.0388	.2033	.2054	.2054	.168
9	1.9393	1.9989	1.9109	.1612	.1307	.1478	.1294
10	.1267	.1254	.1307	.1227	.1086	.128	.112
11	.1494	.128	.132	1.7204	1.9393	1.3765	1.8233
12	.1494	.0747	.1307	2.2211	2.0645	1.7695	2.1216
13		.1448	.1494	2.3205	2.0243	2.0222	2.3703
14	.1478	.168	.1478	2.4366	2.0481	2.2708	2.3703
15	.1509	.1463	.1494	1.989	1.9989	2.0153	2.3868
16	.168	.0739	.1478	2.1382	1.9662	2.1216	2.0317
17	.168	.124	.1463	1.9826	1.6741	1.7444	2.1714
18	.1663	.1494	.168	.9717	1.5249	1.5912	1.8233
19	.1867	.1867	.1867	.1867	.1663	.1509	.1886
20	.1698	.1663	.1886	.168	.168	.1494	.1698
21	.1698	.1663	.168	.1698	.1509	.132	.1509
22	.1509	.1478	.1307	.1698	.132	.1132	.132
23	.132	.1294		.112	.1132	.112	.112
24	.0859	.1132	.1097	.1294	.112	.1132	.0943
Max	1.9393	1.9989	2.0388	2.4366	2.0645	2.2708	2.3868
Min	.0747	.0739	.0924	.0934	.0924	.0943	.0934
Avg	.5512	.5556	.5506	.7519	.7238	.7088	.8016

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 201 / 11 KV ANKALKHOP GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.0686	.0857	.1029	.0857	.0514	.0686
2	.0686	.0686	.0857	.0686	.0857	.0343	.0514
3	.0686	.0686	.0857	.0686	.0857	.0343	.0514
4	.0686	.0686	.1029	.1029	.1029	.0343	.0686
5	.1029	.1029	.1372	.1372	.1372	.0343	.0686
6	.1715	.1715	.2058	.2058	.1886	.0686	.1029
7	.1715	.2401	.2229	.2743	.2229	.1372	.1029
8	.2058	.1715	.1886	.2058	.1715	.0686	.1029
9	.1715	.1029	.1715	.1715	.1372	.1029	.0857
10	.1029	.1372	.1372	.1372	.0857	.0686	.0686
11	.1029	.12	.12	.1715	.0857	.0686	.1029
12	.1029	.1715	.12	.12	.0857	.0686	.0686
13	.1029	.1372	.12	.12	.0514	.0686	.0686
14	.1029	.1372	.1029	.12	.0514	.0686	.0686
15	.12	.1932	.1029	.12	.0514	.0686	.0686
16	.1372	.1372	.1029	.12	.0514	.0686	.0686
17	.1715	.1543	.1029	.1372	.0514	.0686	.0686
18	.2058	.2058	.2058	.2229	.1029	.0686	.1372
19	.2058	.3086	.2401	.2743	.1029	.1372	.1372
20	.2401	.2572	.2743		.1029	.1372	.1372
21	.2058	.2229	.2401	.2401	.0686	.1029	.1029
22	.1715	.1715	.1715	.1715	.0686	.0686	.0686
23	.1715	.1372	.1372	.1372	.0686	.0686	.0686
24	.4287	.1372	.1029	.1372	.0857	.0514	.0686
Max	.4287	.3086	.2743	.2743	.2229	.1372	.1372
Min	.0686	.0686	.0857	.0686	.0514	.0343	.0514
Avg	.1543	.1538	.1486	.1551	.0972	.0729	.0836

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 202 / 11 KV AUDUMBER GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1029	.0857	.1029	.1029	.1029	.1029
2	.1029	.1029	.0857	.1029	.0857	.1029	.1029
3	.1029	.1029	.0857	.1029	.0857	.1029	.1029
4	.1372	.1029	.12	.1372	.1029	.1029	.1715
5	.1715	.1372	.1715	.1715	.1715	.1029	.1715
6	.2058	.1715	.2915	.2401	.2401	.2401	.2058
7	.1715	.2058	.2915	.2401	.2401	.2743	.2058
8	.1715	.1715	.2058	.2058	.1715	.2401	.2058
9	.1715	.1372	.1372	.1715	.1715	.1029	.12
10	.1372	.1372	.1372	.1715	.1029	.1029	.12
11	.1029	.1029	.1029	.1715	.1715	.1715	.1715
12	.0686		.1029	.1715	.1715	.1715	.1715
13	.0686	.12	.1029	1.7661	.1715	.1715	.1715
14	.0686	.1372	.1029	.1715	.1715	.1715	.3086
15	.0686	.1372	.1029	.1543	.1715	.1715	.1715
16	.0857	.1029	.1029	.1029	.1715	.1715	.1715
17	.1372	.1543	.1543	.12	.1715	.1715	.1715
18	.2058	.2743	.1715	.1715	.1715	.1715	.1715
19	.2401	.2915	.2058	2.692	.2058	.2401	.2058
20	.2743	.2572	.2743	.1715	.2401	.2401	.2401
21	.2058	.2058	.2401	.1715	.2058	.2058	.2058
22	.1715	.1715	.1715	.1715	.1715	.1543	.1715
23	.1715	.12	.1372	.1372	.1372	.1029	.1372
24	.1372	.1372	.1029	.1372	.1029	.1029	.1029
Max	.2743	.2915	.2915	2.692	.2401	.2743	.3086
Min	.0686	.1029	.0857	.1029	.0857	.1029	.1029
Avg	.1465	.1558	.1536	.3315	.1629	.1622	.1701

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 203 / 11 KV BHILAWADI GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2743	.2743	.2743	.2743	.2743	.2743
2	.2058	.2743	.2572	.2743	.2743	.2743	.2743
3	.2058	.2401	.2572	.2401	.2743	.2743	.2743
4	.3086	.2743	.2743	.3086	.3429	.2401	.3429
5	.4458	.3772	.3258	.3772	.4458	.4115	.4458
6	.583	.5144	.6173	.6173	.5487	.4801	.5144
7	.6516	.6516	.6516	.583	.5487	.6173	.6173
8	.5144	.5144	.5144	.5144	.6859	.4801	.5144
9	.4458	.4115	.4287	.3772	.4115	.4458	.3944
10	.3772	.3772	.3772		.3429	.4115	.3601
11	.3429	.3772	.3429		.3086	.3429	.3429
12	.3086	.3772	.3429	.3772	.3086	.3601	.3086
13	.3086	.3429	.3086	.3429	.3086	.3429	.2743
14	.3258	.3429	.3086	.3429	.3086	.3258	.2743
15	.3601	.3429	.3086	.3429	.3086	.3429	.2743
16	.3772	.3429	.3944	.3601		.3772	.3086
17	.5144	.4115	.3944	.0343	.3944	.4287	.3601
18	.6001	.6001	.4115	.583	.5316	.583	.4801
19	.6516	.6687	.5144	.6859	.583	.6859	.5487
20	.6173	.6173	.583		.6173	.6173	.583
21	.5487	.5144	.5144	.6344	.6516	.5144	.5144
22	.4458	.4287	.4458	.5144	.6173	.4458	.4115
23	.3772	.3086	.3772	.4458	.3086	.3429	.3429
24	.4287	.3429	.2743	.3086	.2915	.2743	.2743
Max	.6516	.6687	.6516	.6859	.6859	.6859	.6173
Min	.2058	.2401	.2572	.0343	.2743	.2401	.2743
Avg	.4244	.4136	.3958	.4066	.4212	.4122	.3879

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 204 / 11 KV NAGATHANE GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1372	.1372	.1372	.1543	.1715	.1543
2	.1372	.1372	.1372	.1372	.1543	.1715	
3	.1715	.1372	.1372	.1372	.1543	.1715	.1715
4	.2058	.1715	.1715	.1715	.1715	.2058	.2058
5	.2743	.2401	.2229	.2743	.2743	.2401	.2572
6		.3429	.3429	.4115	.4287	.3086	.3258
7	.3429	.4801	.4115	.4115	.4458	.4458	.4801
8	.2401	.3429	.3086	.3772	.3429	.3772	.3601
9	.2058	.2401	.2743	.3086	.2743	.3086	.2743
10	.1886	.2058	.2229	.1715	.2058	.2743	.2915
11	.1886	.2058	.2229	.1715	.2058	.2401	.1715
12	.1886	.1715	.2229	.1543	.2058	.2401	.1715
13	.1886	.2058	.2058	.1715	.1715	.2058	.1715
14	.1715	.1715	.2572	.1715	.1715	.1715	.2058
15	.12	.1715	.2058	.1715	.1543	.1886	.2058
16	.1372	.1715	.2058	.1715	.2229	.1715	.2229
17	.1715	.2058	.2229	.2058	.2572	.2058	.2229
18	.3086	.2915	.2743	.3086	.3086	.2229	
19	.3086	.3772	.3429	.4287	.3429	.3944	.3086
20	.3429	.3772	.4115		.3772	.3429	.3429
21	.3086	.3258	.3429	.3944	.4115	.2743	.3772
22	.2743	.2743	.2743	.3086	.3086	.2401	.2743
23	.2058	.2743	.2401	.2401	.2058	.1886	.1372
24	.4287	.1715	.1372	.1715	.1715	.1715	.1715
Max	.4287	.4801	.4115	.4287	.4458	.4458	.4801
Min	.12	.1372	.1372	.1372	.1543	.1715	.1372
Avg	.2281	.2429	.2472	.2438	.2551	.2472	.2502

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 205 / 11 KV ANKALKHOP AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	.0343	.0343	.0343	.0343
2	.2743	.3086	.3429	.0343	.0343	.0343	.0343
3	.3086	.3429	.3772	.0343	.0343	.0343	.0343
4	.3429	.4115	.4458	.0343	.0343	.0343	.0343
5	.3772	.4458	.4801	.0343	.0343	.0343	.0343
6	.4458	.5144	.5144	.0343	.0343	.0343	.0343
7	.5144	.5487	.6173	.0343	.0343	.0343	.0343
8	.5487	.583	.6859	.0343	.0343	.0343	.0343
9	.6516	.583	.6173	.0343	.0343	.0343	.0343
10	.0343	.0343	.0343	.0343	.0343	.0343	.0343
11	.0343	.0343	.0343	.8916	.9602	.823	.6516
12	.0343	.0343	.0343	1.0288	.9602	.8916	.7545
13	.0343	.0343	.0343	1.0288	.9259	.8573	.7545
14	.0343	.0343	.0343	1.0288	.8573	.8573	.7545
15	.0343	.0343	.0343	1.0631	.823	.823	.7545
16	.0343	.0343	.0343	1.0288	.823	.7202	.6859
17	.0343	.0343	.0343	.9602	.6516	.6859	.6516
18	.0343	.0343	.0343	.9259	.583	.6173	.6516
19	.0343	.0343		.0343	.0343	.0343	.0343
20	.0343	.0343	.0343		.0343	.0343	.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	.0343
22	.0343	.0343	.0343	.0343	.0343	.0343	.0343
23	.0343	.0343	.0343	.0343	.0343	.0343	.0343
24	1.3717	.0343	.0343	.0343	.0343	.0343	.0343
Max	1.3717	.583	.6859	1.0631	.9602	.8916	.7545
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.2229	.1786	.1998	.3683	.2972	.2844	.2586

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 206 / 11KV AUDUMBER AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	.0343	.0343	.0343	.0343
2	.6859	.7545	1.0288	.0343	.0343	.0343	.0343
3	.7202	.823	.9431	.0343	.0343	.0343	.0343
4	.823	.9259	1.0288	.0343	.0343	.0343	.0343
5	1.0288	1.0288	1.2003	.0343	.0343	.0343	.0343
6	1.2689	1.0974	1.2003	.0343	.0343	.0343	.0343
7	1.3375	1.2003	1.286	.0343	.0343	.0343	.0343
8	1.3717	1.3717	1.6461	.0343	.0343	.0343	.0343
9	1.5432	1.5432	1.6461	.0343	.0343	.0343	.0343
10		.0343	.0343		.0343	.0343	.0343
11		.0343	.0343	2.2291	1.8861	2.1262	2.1434
12			.0343	2.4691	2.0062	2.0748	2.2291
13			.0343	2.5377	2.0062	2.0576	2.2462
14			.0343	2.5034	1.8176		1.7147
15		.0343	.0343	2.5377	1.869	2.0576	1.5432
16			.0343	2.5034	1.6975	2.0576	1.3717
17			.0343	2.3148	1.5432	2.0576	1.3717
18		.0343	.0343	2.1948	1.166	1.7147	1.6461
19	.0343	.0343	.0343	.0343	.0343	.0343	.0343
20	.0343	.0343	.0343		.0343	.0343	.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	.0343
22	.0343	.0343	.0343	.0343	.0343	.0343	.0343
23	.0343	.0343	.0343	.0343	.0343	.0343	.0343
24	1.0669	.0343	.0343	.0343	.0343	.0343	.0343
Max	1.5432	1.5432	1.6461	2.5377	2.0062	2.1262	2.2462
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.6701	.4801	.4387	.8986	.6059	.6389	.6173

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 207 / 11 KV BHILAWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	.0343	.0343	.0343	.0343
2	.0343	.0343	.0343	.823	.9602	.823	.7716
3	.0343	.0343	.0343	.9259	.9602	.8916	.7716
4	.0343	.0343	.0343	.9945	.9602	.9259	.7888
5	.0343	.0343	.0343	1.0631	1.0288	.9602	.823
6	.0343	.0343	.0343	1.166	1.0288	.9945	.8916
7	.0343	.0343	.0343	1.2003	1.0974		.9602
8	.0343	.0343	.0343	1.2346	1.166	1.0974	.9602
9	.0343	.0343	.0343	1.166	1.166	1.0974	.9602
10	.0343	.0343	.0343	.0343	.0343	.0343	.0343
11	2.0576	2.332	2.0576	.0343	.0343	.0343	.0343
12	2.1262	2.332	2.5377	.0343	.0343	.0343	.0343
13	2.2291	2.4006	2.4691	.0343	.0343	.0343	.0343
14	2.332	2.4006	2.4006	.0343	.0343	.0343	.0343
15	2.4691	2.332	2.4006	.0343	.0343	.0343	.0343
16	2.332	2.332	2.2634	.0343	.0343	.0343	.0343
17	2.1605	2.1262	1.989	.0343	.0343	.0343	.0343
18	1.989	1.9204	1.7833	.0343	.0343	.0343	.0343
19	.0343	.0686	.0343	.0343	.0343	.0343	.0343
20	.0343	.0343	.0343		.0343	.0343	.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	.0343
22	.0343	.0343	.0343	.0343	.0343	.0343	.0343
23	.0343	.0343	.0343	.0343	.0343	.0343	.0343
24	1.2193	.0343	.0343	.0343	.0343	.0343	.0343
Max	2.4691	2.4006	2.5377	1.2346	1.166	1.0974	.9602
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.8096	.7816	.7688	.3951	.3715	.3191	.3115

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 208 / 11 KV NAGTHANE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0686	.0686	.0686	.1372	.0686	.0686
2	.0686	.0686	.0686	1.0288	.9602	.823	.7716
3	.0686	.0686	.0686	1.0974	.9602	.9602	.8573
4	.1029	.0686	.0686	1.166	.9945	.9945	.8573
5	.1372	.1372	.0686	1.2346	.9945	1.0631	.9602
6	.1715	.1715	.2058	1.3032	1.0288	1.2003	.9945
7	.2058	.2058	.1372	1.3717	1.2346	1.2689	1.2346
8	.2058	.1715	.1372	1.5775	1.0288	1.3717	1.3032
9	.2058	.1372	.1372	1.7833	1.4403	1.5775	1.5089
10	.1715	.1372	.1372	.1372	.1372	.1372	.1372
11	2.3491	2.9492	2.8292	.1372	.1372	.1372	.0686
12	3.0864	3.2236	3.0178	.1372		.1372	.0686
13	3.2579	3.155	2.9492	.1372		.1372	.0686
14	3.2922	3.0178	2.8121	.1372		.1372	.0686
15	3.2236	2.8807	2.7435	.1029		.1372	.0686
16	3.0864	2.8807	2.7435	.1029		.1372	.0686
17	2.5377	2.8121	2.6063	.1372		.0686	.0686
18	2.332	2.4006	2.0576	.1372	.1372	.1029	
19	.1029	.1372	.1372	.1372	.1372	.1372	.0686
20		.1372	.1372		.1372	.1029	.0686
21	.1372	.1372	.1372	.1372	.1029	.1029	.0686
22	.1372	.1372	.0686	.1219	.0686	.0686	.0686
23	.1372	.0686	.0686	.1372	.0686	.0686	.0686
24	1.2193	.1029	.0686	.0686	.1372	.0686	.0686
Max	3.2922	3.2236	3.0178	1.7833	1.4403	1.5775	1.5089
Min	.0686	.0686	.0686	.0686	.0686	.0686	.0686
Avg	1.1437	1.0531	.9781	.5391	.5468	.4587	.4167

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 201 / 11 KV YELAVI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0943	.0943	.0943	.0754	.0943	.0943
2	.2881	.3681	.3572	.0943	.0943	.0943	.0943
3	.2881	.3953	.3913	.0943	.0943	.0943	.0754
4	.3077	.3953	.4167	.0943	.1132	.1132	.0754
5	.3277	.4161	.4531	.0943	.1698	.1132	.0943
6	.3932	.5668	.502	.1509	.1886	.2075	.1509
7	.5967	.8002	.7865	.2075	.2263	.2075	.1886
8	.6958	.9717	1.0883	.2075	.2075	.1509	.1886
9	.8381	1.2308	1.1523	.1698	.132	.1478	.132
10	.132	.1307	.2126	.1307	.1307	.1307	.112
11	.1307	.1478	.1698	1.1385	.8539	.8642	.9374
12	.1307	.1494	.1372	1.2631	.8855	.9602	.9488
13	.1494	.1494	.0934	1.2334	.9105	1.0595	1.1248
14	.1307	.1867	.2241	1.2483	.8025	.8065	1.0437
15	.1494	.2054	.2241	1.1363	.7562	.9122	1.1523
16	.132	.1867	.1387	1.2003	.7811	.9717	1.0311
17	.132	.1867	.1355	1.0311	.8749	.9488	1.0753
18	.1886	.1867	.1677	.8642	.8436	.7202	.9061
19	.2075	.2075	.1509	.1646	.132	.132	.1509
20	.1886	.1886	.1509		.132	.132	.132
21	.1886	.1698	.1132	.132	.132	.1132	.132
22	.132	.1698	.0943	.1132	.1132	.1132	.132
23	.1132	.1132	.0943	.1132	.1132	.0943	.1132
24	.0943	.1132	.0943	.0943	.0943	.1132	.0943
Max	.8381	1.2308	1.1523	1.2631	.9105	1.0595	1.1523
Min	.0943	.0943	.0934	.0943	.0754	.0943	.0754
Avg	.2512	.3221	.3101	.4813	.3690	.3873	.4242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 202 / 11 KV Laxmi LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7635	1.6204	1.8143	1.1888	1.0235	.743
2	1.7804	1.8233	1.7238	1.4373	1.0669	.7628
3	1.7295	1.861	1.8107	1.5023	1.1092	.7827
4	1.7465	1.95	1.8347	1.5181	1.1843	.7977
5	1.2763	2.0233	1.9456	1.6057	1.2929	.8383
6	1.9806	2.0405	2.0858	1.6057	1.2616	.8642
7	2.5057	2.0458	2.3102	1.9805	1.6356	1.7741
8	2.5503	2.1312	2.2986	1.8898	1.587	2.0351
9	2.6513	2.8669	1.4529	2.0199	1.5947	2.0559
10	2.8006	2.8292	2.1849	2.0595	1.9427	2.037
11	2.838	2.9801	2.7073	2.8006	2.3011	2.5463
12	2.8006	2.6406	2.9424	2.8669	2.2634	2.6217
13	2.782	2.9424	2.8292	2.8006	2.1879	2.6029
14	2.9047	2.782	2.8104	2.8481	2.6972	2.6217
15	2.9424	2.6783	2.8481	2.8669	2.2822	2.6595
16	2.4394	2.3011	.0854	2.4709	2.2634	2.2634
Max	2.9424	2.9801	2.9424	2.8669	2.6972	2.6595
Min	1.2763	1.6204	.0854	1.1888	1.0235	.743
Avg	2.3432	2.3448	2.1053	2.0914	1.7309	1.7504

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 203 / 11 KV Yelavi Bu'wadi
 Gaonthan Feeder KV- 11 /
 OUTGOING

GAOTHAN FEEDER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2427	.2641	.2452	.2829	.2641	.2641	.2641
2	.2263	.2452	.2452	.2641	.2641	.2263	.2641
3	.2452	.2263	.2452	.2641	.2641	.2452	.2829
4	.3395	.2829	.2641	.3206	.2829	.2829	.3018
5	.9808	.415	.415	.3961	.3961	.415	.3584
6	.6224	.6224	.6224	.679	.679	.679	.6602
7	.679	.7167	.6602	.6979	.6979	.6979	.6979
8	.5175	.4854	.5601	.5601	.5415	.5228	
9	.3696	.3841	.4024	.4024	.3841	.4024	.3982
10	.3366	.3155	.3224	.3189	.2957	.2804	.3155
11	.2865	.2772	.2686	.2454	.2328	.2507	.2601
12	.2686	.2328	.2534	.2481	.2481	.2126	.2328
13	.2507	.2686	.2507	.2454	.2279	.2454	.2279
14	.2328	.2534	.2534	.2149	.208	.2103	.2507
15	.2328	.2303	.2715	.2149	.208	.2883	.2507
16	.2481	.2686	.2947	.2481	.2427	.2303	.2481
17	.3258	.3155	.3224	.3688	.3121	.2774	.3121
18	.4784	.4075	.3403	.362	.4755	.4706	.4252
19	.6401	.6283	.5729	.6468	.6283	.679	.6219
20	.5914	.5788	.5914		.5601	.5914	.5601
21	.5228	.5228	.5228	.5601	.5228	.5415	.5228
22	.3921	.3921	.415	.3961	.3961	.4527	.415
23	.3174	.3174	.2987	.3018	.3206	.3018	.3395
24	.2427	.2614	.2427	.2829	.2641	.2641	.2614
Max	.9808	.7167	.6602	.6979	.6979	.6979	.6979
Min	.2263	.2263	.2427	.2149	.208	.2103	.2279
Avg	.3996	.3713	.3700	.3705	.3715	.3763	.3683

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 204 / 11 KV Burungwadi
Industrial Feeder KV- 11 /
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.1981	.2187	.1257	.1758	.1981	.16
2	.208	.208	.2086	.1486	.184	.1783	.1362
3	.2195	.1758	.1627	.1257	.161	.1858	.1488
4	.2103	.1734	.1972	.1006	.1867	.192	.1829
5	.1879	.1652	.1894	.181	.1758	.1894	.1852
6	.2201	.2	.2107	.2623	.2353	.2258	.1875
7	.3224	.2427	.136	.3155	.2753	.2865	.2896
8	.2896	.3121	.0983	.3403	.2683	.2774	.3185
9	.3841	.3696	.2298	.3734	.415	.3772	.362
10	.3881	.3734	.2073	.4527	.4527	.3961	.5658
11	.4294	.3881	.2374	.3961	.5093	.7356	.7733
12	.4024	.4904	.3045	.4481	.3921	.4904	.4904
13	.3696	.3921	.2031	.4066	.4338	.415	.5281
14	.3921	.4066	.2056	.4904	.3734	.4706	.5281
15	.3772	.4715	.2073	.3801	.3206	.4481	.5658
16	.3772	.3772	.2056	.3366	.3734	.3841	.5847
17	.3292	.4338	.2204	.3206	.2601	.3544	.5228
18	.3326	.4108	.2286	.3582	.3258	.1829	.5281
19	.3841	.4904	.2656	.3658	.4435	.3326	.4715
20	.2835	.3856	.2818		.4527	.3772	.3391
21	.3721	.4294	.2591	.3439	.3258	.3696	.3258
22	.3801	.2926	.2241	.3403	.3881	.3641	.3353
23	.3086	.2715	.208	.2439	.2743	.2606	.2753
24	.2241	.2321	.213	.216	.2107	.2241	.3206
Max	.4294	.4904	.3045	.4904	.5093	.7356	.7733
Min	.1879	.1652	.0983	.1006	.161	.1783	.1362
Avg	.3172	.3288	.2135	.3075	.3172	.3298	.3802

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 205 / 11Kv Express Feeder

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.358	1.3203	1.5466	1.4146		1.5089	1.358
2	1.39	1.2826	1.6032	1.4523	1.6975	1.4523	1.3769
3	1.3957	1.226	1.4712	1.4712	1.7353	1.4335	1.3957
4	1.4523	1.3203	1.5466	1.4901	1.6975	1.4712	1.3957
5	1.5089	1.5089	1.5089	1.5089	1.7353	1.4146	1.5089
6	1.5655	1.4146	1.5089	1.5278	1.7353	1.5466	1.6032
7	1.6032	1.6598	1.7353	1.5278	1.5466	1.6975	1.7353
8	1.5655	1.8861	1.6975	1.6975	1.5278	1.5844	1.8107
9	1.1317	1.0374	1.226	1.0751	1.3014	1.094	1.094
10	1.2071	1.0751	1.0185	1.094	1.358	1.1317	1.2071
11	1.5089	1.358	1.5089	1.6032	1.226	1.5089	1.3203
12	1.358	1.7353	1.5278	1.6032	1.6598	1.4335	1.1317
13	1.773	1.7918	1.6975	1.6221	1.6975	1.6975	1.4901
14	1.6975	1.5466	1.8107	1.8484	1.4523	1.905	1.3203
15	1.7164	2.0182	1.8296	1.7353	1.7918	1.6975	2.0748
16	1.773	1.8673	1.6975	1.8861	1.8296	1.7353	1.905
17	1.5089	1.8107	1.6975	1.6598	1.7353	1.7164	1.5844
18	1.2449	1.0374	1.358	1.1317	1.2071	1.2071	1.1317
19	1.0562	.9808	1.1694	1.2826	1.1317	1.1506	1.094
20	.8402	.9431	1.094	1.1317	1.0562	1.1317	1.0562
21	.9431	1.1317	1.1317	.9808	1.1694	1.1317	1.3014
22	.9808	1.1694	1.2449	1.4146	1.0374	1.1506	1.0562
23	1.4146	1.3203	1.5089	1.4712	1.5089	1.6221	1.3392
24	1.3014	1.358	1.5466	1.3203	1.5089	1.4335	1.358
Max	1.773	2.0182	1.8296	1.8861	1.8296	1.905	2.0748
Min	.8402	.9431	1.0185	.9808	1.0374	1.094	1.0562
Avg	1.3873	1.4083	1.4869	1.4563	1.4933	1.4523	1.4020

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 206 / Yelavi Ag -2

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0259	.024	.0229	.0229	.0168	.0305	.02
2	.4801	.4024	.4409	.0173	.0093	.0227	.0187
3	.5087	.4973	.4862	.0173	.0137	.0213	.0114
4	.5365	.547	.5138	.0147	.0183		.0171
5	.5801	.5898	.5668	.0189	.0133	.0168	.0229
6	.7186	.8223	.7682	.0274	.0305	.0335	.0171
7	1.1523	1.3108	1.4251	.0461	.0343	.0244	.036
8	1.4586	1.6385	1.7859	.0518	.0549	.0514	.0488
9	1.6244	1.9006	1.9227	.0615	.0457	.0453	.0671
10	.032	.0457		.0842	.0768	.0732	.0846
11	.032	.0389	.0398	1.9662	1.3413	1.3077	1.5432
12	.0377	.0324	.04	1.9989	1.3413	1.643	1.5424
13	.0594	.0286	.0381	1.2039	1.2174	1.6095	1.7436
14	.0356	.04	.0362	1.7736	1.2887	1.6095	1.6095
15	.0324	.0326	.0324	1.8233	1.2209	1.6095	1.6575
16	.0396	.0532	.0457	1.7101	1.2209	1.4922	1.5424
17	.088	.0524	.0291	1.4918	1.3032	1.4582	1.6766
18	.0857	.0343	.0396	1.2431	1.073	1.0227	1.4243
19	.0324	.0274	.0366	.0389	.0286	.0446	.0396
20	.0244	.0244	.0343		.024	.0314	.0286
21	.0293	.0286	.0347	.0187	.0229	.0272	.0267
22	.0251	.0198	.0293	.0189	.021	.0251	.0297
23	.0171	.0231	.0309	.0189	.032	.0244	.0286
24	1.6766	.029	.0213	.036	.0198	.032	.0274
Max	1.6766	1.9006	1.9227	1.9989	1.3413	1.643	1.7436
Min	.0171	.0198	.0213	.0147	.0093	.0168	.0114
Avg	.3889	.3435	.3661	.5958	.4362	.5329	.5527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 201 / 11 KV VASAGADE GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905	.1097	.1097	.1086	.0905	.1097	.0905
2	.0724	.0914	.0914	.0914	.0895	.0924	.0895
3	.0716	.0914	.0739	.0895	.0914	.0924	.0709
4	.0716	.0924	.0732	.0895	.0732	.1097	.0716
5	.1086	.1307	.0924	.128	.1086	.128	.1086
6	.1646	.168	.1463	.1629	.1433	.1663	.1433
7	.197	.1663	.1663	.1991	.1791		.1991
8	.181	.1663	.1829	.1629	.1448		.1791
9	.1448	.1294	.128		.1097		.128
10	.128	.1294	.1109	.1075	.1086	.1086	.1086
11	.128	.128	.1097	.1075	.1097	.1075	.1097
12	.1307	.1109	.1109	.1075	.1109	.0895	.1086
13	.1132	.1109	.0914	.1075	.0914	.1086	.1075
14	.112	.1109	.0914	.1075	.0739	.1075	.1086
15	.112	.0732	.0905	.1086	.0914	.0905	.128
16	.112	.1109	.1097		.0924	.1075	.1254
17	.112	.1109	.1109	.1086	.1109	.1075	.1254
18	.1494		.1109	.1254	.1463	.1417	.1267
19	.168	.2195	.2218	.1612	.2402	.2149	.128
20	.1886		.2402	.2149	.2561	.2172	.2218
21	.168	.2195	.2218	.2172	.2195	.2149	.2218
22	.1463	.1848	.1848	.1791	.181	.181	.1848
23	.128	.1097	.1448	.1448	.128	.1629	.1478
24	.2469	.1097	.1109	.1075	.1097	.1109	.1097
Max	.2469	.2195	.2402	.2172	.2561	.2172	.2218
Min	.0716	.0732	.0732	.0895	.0732	.0895	.0709
Avg	.1352	.1306	.1302	.1335	.1292	.1319	.1310

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 202 / 11KV KHATAV GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1086	.1097	.0924	.1075	.1086	.0732	.1086
2	.0838	.0914	.0747	.0895	.0895	.2587	.0895
3	.0838	.0905	.0732	.0934	.0716	.0739	.0914
4	.0716	.0895	.1109	.0914	.0732	.1097	.0732
5	.1187	.1254	.1097	.1294	.128	.1294	.1254
6	.1696	.1791	.1629	.1629	.1629	.1448	.1791
7	.2058	.2012	.1829	.2149	.197		.2126
8	.1791	.1829	.1478	.181	.181		.181
9	.1402	.1612	.1097		.1433		.1433
10	.1254	.1227	.1109	.1254	.1086	.1267	.1086
11	.1097	.1086	.1294	.1075	.1109	.1075	.1097
12	.1086	.1109	.1109	.1086	.1097	.1086	
13	.0895	.0914	.0924		.0905	.1086	
14	.0895	.0739	.0934	.0914	.0549	.1075	
15	.0895	.0732	.0924	.0905	.0543	.1086	
16	.0895	.1097	.0747	.1075	.0549	.1075	
17	.1075	.1109	.0924	.1086	.0732	.1075	
18	.1433		1.6078	.1433	.1478	.1267	.1829
19	.1829	.2033	.2033	.1612	.2012	.2149	.2195
20	.2241	.2195	.2218	.1991	.2402	.2353	.2402
21	.2241	.1848	.1848		.1829	.2303	.2195
22	.1829	.1463	.1478	.181	.128		.2033
23	.168	.1109	.1433	.1448	.1109	.1629	.1463
24	.128	.1294	.1097	.1267	.128	.1109	.128
Max	.2241	.2195	1.6078	.2149	.2402	.2587	.2402
Min	.0716	.0732	.0732	.0895	.0543	.0732	.0732
Avg	.1343	.1316	.1866	.1317	.1230	.1377	.1535

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 203 / 11 KV SUKHWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0181	.0187	.0183	.0179	.0181	.0183	.0179
2	.6443	.0185	.0185	.0177	.3772	.4706	.4115
3	.6516	.0185	.0181	.0181	.4239	.4706	.4239
4	.6001	.0187	.0183	.0181	.4409	.5121	.431
5	.6344	.0185	.0183	.0183	.431	.5373	.3978
6	.6783	.0185	.0185	.0181	.5365	.5973	.503
7	.7712	.0183	.0181	.0179	.5801		.5765
8	1.0288	.0183	.0183	.0181	.6274		.6001
9	1.0442	.0183	.0181		.6371		.5935
10	.0187	.0183	.0183	.0179	.017	.0177	.0175
11	1.3077	1.0486	1.1469	.0179		.0181	.0177
12	1.2452		1.2431	.0181	.0162	.0179	.0179
13	1.2146		1.1469	.0181	.0164	.0181	
14	1.1469		1.065	.0181	.0166		
15	1.1203	1.0486	1.0364	.0179	.0154		
16	1.0082	1.0202	.9762	.0181	.0162		
17	.9374	.9503	.9116	.0179	.0164		
18	.8951	.9069	.8848	.0177	.0181	.0183	.0179
19	.0179	.0166	.0179	.0179	.0183	.0181	.0181
20	.0181		.0181	.0179	.0185	.0179	.0183
21	.0183	.0162	.0183	.0171	.0181	.0179	.0179
22	.0185	.0181	.0179	.0175	.0183	.0177	.0181
23	.0185	.0183	.0179	.0177	.0179	.0179	.0173
24	.0183	.0187	.0181	.0181	.0179		.0181
Max	1.3077	1.0486	1.2431	.0183	.6371	.5973	.6001
Min	.0179	.0162	.0179	.0171	.0154	.0177	.0173
Avg	.6281	.2624	.3626	.0179	.1875	.1741	.2176

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 204 / 11 KV VASAGADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2172	.2195	.2149	.2172	.2172	.2172	.2353
2	.197	1.1736	.788	.763	.2195	.2378	.2195
3	.197	1.1603	.8764	.7716	.1991		.2195
4	.2149	1.2071	.8859	.8059	.1991		.2172
5	.2378	1.2431	.9313	.8139	.2195		.2353
6	.2507	1.3413	1.0277	.9448	.2328		.2507
7	.2481	1.4255	1.2894	1.3108	.2303		.2481
8	.2353	1.4746	1.6124	1.5746	.2328		.2534
9	.2303	1.5893	1.7193		.2353		.2328
10	.2328	.2229	.2303	.2374	.2534	.2279	.2534
11	.2378	.2254	.2303	1.5261	1.701	1.8861	1.8442
12	.2378		.2149		1.828	1.8945	2.0454
13	.2402		.2149			1.8991	2.0622
14	.2402		.2149	2.0062	1.6301	1.9062	2.0957
15	.2427	.2126	.2172	2.0576	1.6301	1.8023	1.6164
16	.2427	.208	.2195	2.0719	1.6476	1.9281	1.9334
17	.2427	.2126	.2218	1.8652	1.6124	1.8107	1.9826
18	.2241	.2353	.2218	1.4575	1.3112	1.7939	1.8442
19	.2241	.2534	.2427	.2058	.2534	.2507	.2328
20	.2241	.2481	.2402	.2058	.2561	.2534	.2012
21	.2241	.2454	.2614	.2103	.2534	.2507	.2561
22	.2241	.2481	.2614	.2103	.2534	.2353	.2378
23	.2241	.2534	.2378	.2303	.2534	.2378	.2378
24	.2149	.2241	.2561	.2195	.2149	.2561	.2378
Max	.2507	1.5893	1.7193	2.0719	1.828	1.9281	2.0957
Min	.197	.208	.2149	.2058	.1991	.2172	.2012
Avg	.2294	.6487	.5346	.9384	.6558	1.0052	.7997

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 205 / 11 KV PARSHWNATH LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4748		.4694			
2	.5144		.4641			
3	.4801		.4748			
4	.4748		.4694			
5	.4641		.5175			
6	.4694		.5228			
7			.4359			
8	.4748	.4748	.4973			.4748
9	.4694	.5144	.4694			.5144
10		.4801	.4973	.4748	.5087	.4748
11	.4801	.5121	.4694	.4748	.4973	.4748
12	.4588		.4973	.4748	.4915	.4801
13	.4694		.4588	.4748	.4641	.4409
14	.4748		.4359	.4801	.4694	.4458
15	.4801	.4641	.4359	.4748	.4748	.4801
16	.4801	.4359	.4458	.4801		.4801
Max	.5144	.5144	.5228	.4801	.5087	.5144
Min	.4588	.4359	.4359	.4748	.4641	.4409
Avg	.4761	.4802	.4726	.4763	.4843	.4740

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 201 / 11 KV Tasgaon I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5093		.5415				.547
2	.4904		.5281				.5281
3	.4715		.5093				.5281
4	.4904		.5093				.547
5	.5658		.5847	.5658		.5281	.5658
6	.6413		.7392	.7392		.7356	.7922
7	.6722	.7133	.7577	.8131	.7842		.8029
8	.7577	.7499	.7682	.8048	.8048	.7762	.7947
9	.7865	.788			.6878	.7602	.7316
10	.7522		.788		.0895	.7975	.7973
11			.7442		.0895	.7796	.7712
12	.7522	.8939	.7796			.7888	
13	.7059	.7373	.6733	.7537		.7712	.7973
14		.7133				.691	.7701
15		.7362				.7442	
16	.7442	.8063	.7619		.9671	.7888	.788
17		.7545	.7282	.7888	.8859	.7628	
18	.9114	.9709	.9593	1.0208	.9955	.9745	1.0749
19	1.0608	1.0608	1.0242	1.0791	1.0534	1.1088	1.0679
20	.9328	.924	.9328	.961	.9795	.9522	.961
21		.7947	.823			.8589	.9335
22		.7655	.7282	.8029	.8402	.8215	
23	.6653	.6535	.6722		.6722	.6979	
24	.5281	.5175	.5601	.5788	.6413	.5788	.5847
Max	1.0608	1.0608	1.0242	1.0791	1.0534	1.1088	1.0749
Min	.4715	.5175	.5093	.5658	.0895	.5281	.5281
Avg	.691	.7862	.7197	.8098	.7301	.7851	.7570

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 202 / 11 KV Tasgaon II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4923		.535				.5498
2	.4527		.5068				.5357
3	.439		.4868				.5144
4	.4715		.4599				.5281
5	.5468		.6588	.5418		.5569	.6167
6	.6009		.7628	.7455		.7969	.8063
7	.7973	.8775	.8063	.815	.8682	.8859	.8869
8	.7537	.7537	.815	.7455	.8145	.7712	.8238
9	.6274	.6344			.6935	.6516	.7011
10		.6733	.6588		.6935	.691	.691
11		.7087	.57		.6203	.691	.6661
12	.6173	.6733	.5243		.6588	.6733	
13	.6274	.6687		.6556	.6415	.6733	.6556
14		.6344			.6104	.6344	.6001
15		.6344	.6036			.6415	
16	.6274	.6173	.6173			.6485	.6001
17		.6984	.6661	.7762		.7316	
18	.9808	.9522	.9709	1.0374	1.1317	.8962	.9997
19	1.1883	1.1506	1.0642	1.1506	1.1949	1.1883	1.2071
20	1.0349	1.0534	.9979	1.1016	1.0719	1.1203	1.0642
21		.905	.905		.9593	.9511	.9231
22		.7802	.7545	.8413	.8413	.8238	
23	.578	.6167			.6478	.6401	
24	.4923	.5053	.535	.5792	.663	.5498	.5281
Max	1.1883	1.1506	1.0642	1.1506	1.1949	1.1883	1.2071
Min	.439	.5053	.4599	.5418	.6104	.5498	.5144
Avg	.6664	.7521	.6950	.8172	.8074	.7608	.7315

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 203 / 11 KV WATER SUPPLY

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5609		.5375				.6241
2	.567		.5493				.631
3	.567		.5493				.631
4	.5609		.567				.6068
5	.5434		.5316	.6024			.6588
6	.5434		.4961	.5258		.5959	.6135
7	.5316	.5083	.5258	.6024	.6135	.5784	.5083
8	.5895	.5959	.5959	.6068	.6762	.6762	.5468
9	.7011	.6485			.6836	.6762	.7011
10	.631	.6173	.6556		.1097	.6173	.5784
11		.5138	.5847		.0423	.5847	.5316
12	.5138	.4298	.5493		.6135	.4075	
13	.4607	.4656	.5258	.4382	.3761	.4075	.5493
14		.3761			.2801	.4252	.4607
15		.4557	.4607			.5784	
16	.5083	.4854	.5784		.3982	.5201	.4733
17		.6068	.5258	.6068	.5784	.5658	
18	.6588	.6135	.6135	.6241	.631	.5258	.6588
19	.5784	.631	.631	.631	.5959	.5847	.5316
20	.5434	.5258	.5721	.5493	.5959	.5493	.4681
21		.4557	.4681		.3582	.6135	.4733
22		.443	.4733	.394	.4382	.5138	
23	.4207	.4656	.3898		.3658	.4525	
24	.5548		.5375	.5375	.5316	.3801	.6068
Max	.7011	.6485	.6556	.631	.6836	.6762	.7011
Min	.4207	.3761	.3898	.394	.0423	.3801	.4607
Avg	.5575	.5199	.5417	.5562	.4640	.5396	.5712

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 204 / 11KV NEW TASGAON

INDUSTRIAL FE Feeder KV- 11 /
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187		.0362				.0164
2	.0149		.0351				.0137
3	.0152		.0351				.0137
4	.016		.0354				.016
5	.0183		.0354	.0248		.0137	.0179
6	.0187		.0354	.0232		.0282	.0168
7	.0156	.0179	.0343	.0248	.0701	.0274	.0171
8	.0267	.0541	.0747	.0343	.0347	.0145	.0179
9	.0351	.0549			.0347	.0358	.0747
10	.1075	.1509	.1867		.0248	.1509	.1075
11		.1463	.1478		.0686	.1463	
12	.1387	.181	.1387		.1132	.2126	
13	.112	.1509	.0754	.1132	.0762	.1448	.1097
14		.1132			.0762	.0693	.1509
15		.1478	.181			.1109	
16	.112	.1063	.1097			.1063	.112
17		.1086	.0709	.1357		.112	
18	.1109	.0701	.1417	.0754	.0286	.1463	.1417
19	.0373	.0671	.0762	.1143	.0709	.1132	.0381
20	.0347	.112	.0179	.0724	.0716	.4588	.0248
21		.0716	.0164		.0164	.0171	.0179
22		.037	.0259	.0335	.0145	.016	
23	.0251	.0373	.0259		.0175	.0202	
24	.0194	.0236	.037	.0267	.0332	.0137	.0213
Max	.1387	.181	.1867	.1357	.1132	.4588	.1509
Min	.0149	.0179	.0164	.0232	.0145	.0137	.0137
Avg	.0487	.0917	.0715	.0617	.0501	.0979	.0516

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 205 / 11 KV NIMANI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377		.037				.0373
2	.0373		.0366				.037
3	.0377		.0366				.037
4	.0377		.0366				.037
5	.0377		.0373	.037		.0377	.0377
6	.0377		.0377	.0377		.0381	.0377
7	.0377	.0754	.0377	.0377	.0762	.0381	.0377
8	.0373	.0754	.0373	.0381	.0747	.0373	.0377
9	.037	.0377			.0377	.0377	.0739
10	.0381	.0366	.037		.0373	.037	.0373
11		.0377	.0366		.0381	.037	.0377
12	.0373	.0377	.0373		.0381	.0377	
13	.0373	.0377	.0377	.0381	.0377	.0377	.0381
14		.0377			.0381	.0373	.0377
15		.0377	.0381			.0377	
16	.037	.0377	.0377		.0377	.0362	.037
17		.037	.0366	.0373	.0377	.037	
18	.037	.0366	.0377	.0377	.0747	.0366	.0373
19	.5281	.0373	.0754	.0747	.0747	.0373	.0754
20	.0747	.0373	.0754	.0754	.0747	.0377	.0754
21		.0377	.0762		.0762	.0377	.0762
22		.0343	.0754	.0762	.0754	.0377	
23	.0754	.0373	.0377		.0373	.0373	
24	.1405	.0373	.037	.037	.0377	.0373	.0373
Max	.5281	.0754	.0762	.0762	.0762	.0381	.0762
Min	.037	.0343	.0366	.037	.0373	.0362	.037
Avg	.0746	.0415	.0442	.0479	.0532	.0374	.0454

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244087 / 33/11 KV TURACHI

Feeder No / Name : 201 / 11 KV NIMANI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.0953	.0953	.1334	.0953	.1143	.0762
2	.1905	.7099	.7907	.1143	.0953	.1143	.0762
3	.2286	.7343	.7811	.1143	.0953	.0953	.0762
4	.703	.7907	.8802	.1143	.0953	.0953	.0953
5	.759	.8025	.9014	.1524	.1143		.1334
6	.8697	.9014	.9488	.1905	.1905	.1524	.1715
7	1.0911	1.3435	1.247	.2096	.2096	.2096	.2096
8	1.4083	1.6821	1.6446	.2286	.1905	.2096	.2096
9	1.7078		1.9925	.2096	.1905	.2096	.1715
10	.1905	.1715	.1524	.1905	.1715	.2477	.1715
11	.2096	.1715	.2096	1.8519		2.4006	1.9757
12	.2286	.1715	.2096	2.0557			1.9498
13	.2286	.1715	.1905	2.1091		2.3624	2.1052
14	.2096	.1905	.1905	2.0833		2.2862	2.0809
15	.2096	.1905	.1905	2.1247		2.4006	2.2466
16	.2096	.2096	.2096	2.1142		2.5339	2.13
17	.2477	.2286	.2096	1.7375		1.7985	
18	.1905	.2286	.1715	1.6049		1.3435	1.7101
19	.2096	.2286	.1905	.1524		.1524	.1905
20	.1905	.2096	.1715	.1905		.1715	.1715
21	.1524	.1905	.1715	.1715		.1524	.1524
22	.1143	.1524	.1715	.1143		.1334	.1143
23	.1143	.1143	.1524	.1143		.1334	.1143
24	1.5242	.1143	.0953	.1334	.1143	.1143	.0953
Max	1.7078	1.6821	1.9925	2.1247	.2096	2.5339	2.2466
Min	.1143	.0953	.0953	.1143	.0953	.0953	.0762
Avg	.4709	.4262	.4987	.7590	.1420	.7923	.7142

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244087 / 33/11 KV TURACHI

Feeder No / Name : 202 / 11 KV TURACHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0381	.0572	.0762	.0572	.0762	.0572
2	.0762	.0381	.0572	.6167	.4744	.5218	.5376
3	.0762	.0381	.0572	.6325	.4999	.5601	.5468
4	.0953	.0381	.0572	.6722	.5155	.5535	.5851
5	.0953	.0572	.0762	.6722	.5376	.68	.6316
6	.1143	.0762	.1143	.7432	.5864	.7202	.6642
7	.1334	.0953	.1143	.9488	.8124	.8962	.8124
8	.1524	.0762	.0953	1.0402	1.034	1.0623	1.0031
9	.1334	.0572	.1143	1.1363	1.142	1.0467	1.186
10	.0953	.0572	.0953	.0953	.0953	.0953	.0762
11	1.4243	1.3599	1.3283	.0572		.0953	.0572
12	1.4413	1.3904	1.4403	.0572		.0762	.0572
13	1.5023	1.439	1.406	.0572		.0762	.0572
14	1.3748	1.2967	1.4232	.0572		.0953	.0572
15	1.4529	1.4706	1.3763	.0572		.0762	.0572
16	1.2809	1.4842	1.4232	.0572		.0572	.0572
17	1.2955	1.3441	1.4074	.0572		.0762	.0572
18	1.0987	1.3279	1.1717	.0572		.1334	.0762
19	.0762	.0762	.1143	.0762		.1143	.0953
20	.0762	.0953	.0953	.0762		.1143	.0953
21	.0762	.0953	.0953	.0762		.0953	.0762
22	.0572	.0762	.0762	.0572		.0953	.0762
23	.0572	.0572	.0762	.0572		.0762	.0572
24	.0762	.0572	.0572	.0762	.0572	.0762	.0762
Max	1.5023	1.4842	1.4403	1.1363	1.142	1.0623	1.186
Min	.0572	.0381	.0572	.0572	.0572	.0572	.0572
Avg	.5141	.5059	.5137	.3129	.5284	.3112	.2939

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244087 / 33/11 KV TURACHI

Feeder No / Name : 203 / 11 KV Dhavali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1698	.1848	.2054	.1886	.1867	.2218
2	.1848	.1698	.1886	.1886	.1886	.1848	.2218
3	.1848	.1698	.1867	.1867	.1698	.1867	.2054
4	.2012	.1886	.2096	.168	.1698	.1698	.2241
5	.2801	.2263	.2477	.1663	.1886	.1886	.2641
6	.4294	.4527	.3961	.2241	1.2752	.2957	.4066
7	.5601	.5975	.5544	.5544	.4938	.5731	.6535
8	.5228	.499	.4854	.4298	.4207	.4938	.5228
9	.4024		.3511	.3018	.333	.3403	.3881
10	.3681		.2896	.2429	.2401	.3155	.3077
11	.3052	.2835	.2713	.2896		.3077	.2507
12	.2804	.2481	.2572	.2507		.2686	.2103
13	.2683		.2629	.2481			.2507
14	.2401	.2896	.2601	.2534		.2896	.2629
15	.2481	.2926	.2427	.2229		.2926	.2715
16	.2427	.2926	.2401	.2429		.2534	.2865
17	.2572		.2374	.2454		.3142	.3155
18	.3506	.3658	.298	.4207		.3658	.3582
19	.5544	.4668	.5068	.5544		.5175	.5792
20	.4755	.5041	.4207	.5041		.3439	.5014
21	.3921	.4024	.3326			.4477	.4207
22	.2641	.3142	.2987	.2801		.3841	.2926
23	.2075	.2378	.2452	.2241		.3174	.2402
24	.3189	.1867	.2054	.2263	.2075	.1867	.2263
Max	.5601	.5975	.5544	.5544	1.2752	.5731	.6535
Min	.1829	.1698	.1848	.1663	.1698	.1698	.2054
Avg	.3217	.3179	.2989	.2883	.3523	.3141	.3284

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244087 / 33/11 KV TURACHI

Feeder No / Name : 204 / 11 kv RAJAPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0572	.0572	.0762	.0572	.0762	.0762
2	.0762	.0572	.0572	1.1523	1.1336	.7116	.6718
3	.0762	.0572	.0572	1.186	1.166	.7522	.6958
4	.0762	.0762	.0762	1.186	1.1363	.7432	.703
5	.0953	.0953	.0762	1.1843	1.1683	.8223	.7522
6	.1143	.1334	.1143	1.2643	1.247	.8802	.8592
7	.1715	.1715	.1524	1.3916	1.3757	1.0562	1.0911
8	.1715	.1143	.1524	1.749	1.6762	1.3443	1.3904
9	.1715		.0953	1.8501	1.8084	1.5023	1.4232
10	.1905		.0762	.0762	.0572	.0762	.0572
11	2.2186	2.2809	2.1862	.0953		.0762	.0762
12	2.4741	2.451	2.2119	.0953		.0572	.1143
13	2.5263	2.4371	2.2611	.0953		.0572	.1143
14	2.4486	2.372	2.2939	.0762		.0762	.0953
15	2.6543	2.3878	2.2672	.0762		.0762	.1143
16	2.5888	2.3746	2.0805	.1334		.1143	.1143
17	2.4326	2.4036	2.0165	.1334		.1143	.1143
18	2.2138	2.1091	1.9109	.1143		.1334	.1143
19	.1143	.0953	.1143	.1143		.1143	.1143
20	.0953	.1143	.0953			.1143	.1143
21	.1143	.1143	.0953	.0953		.1143	.0953
22	.0762	.0953	.0762	.0762		.0762	.0762
23	.0572	.0762	.0762	.0762		.0762	.0762
24	.0762	.0572	.0762	.0762	.0762	.0762	.0762
Max	2.6543	2.451	2.2939	1.8501	1.8084	1.5023	1.4232
Min	.0572	.0572	.0572	.0762	.0572	.0572	.0572
Avg	.8879	.9150	.7782	.5380	.9911	.3851	.3804

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244091 / 33/11 KV Bhilwadi (Malwadi

)

Feeder No / Name : 201 / 11 KV MALWADI INDUSTRIAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0343	.0446	.0314	.0227	.0381	.0351
2	.0514	.0286	.0377	.0324	.02	.0366	.032
3	.0514	.0267	.0377	.0314	.0307	.0366	.032
4	.0514	.0572	.0503	.056	.0227		.0351
5	.0629	.0594	.0514	.0594	.056		.0549
6	.0629	.0617	.0514	.0629	.04	.0579	.061
7	.0652	.0594	.0572	.064	.0488	.0671	.061
8	.0747	.0827	.0934	.068	.0594	.0732	.0857
9	.0827	.1698	.1433		.0503	.1267	.1036
10	.2241	.197	.1829	.1612	.0808	.1509	.0734
11	.2658	.2561	.2195	.1698	.1115	.2263	.1905
12	.2629	.2896	.2378	.2054	.1677	.2641	.2286
13	.2454	.3109	.2629	.2801	.1696	.2587	.2286
14	.2947	.2614	.2686	.1494	.1715	.1905	.2263
15	.2534	.2715	.2835	.1698	.1677	.2286	.2772
16	.2303	.3012	.2534	.2452	.1638	.168	.2263
17	.2033	.2686	.2587	.1524	.1562	.1698	.1905
18	.1646	.2402	.1867	.128	.0701	.1132	.0907
19	.084	.1478	.1509	.132	.0686	.1267	.064
20	.08	.125	.0894	.0351	.04	.0737	.061
21	.0907	.0934	.0787	.0503	.0686	.0747	.0518
22	.0774	.0583	.0492	.0488	.1132	.0747	.0625
23	.0617	.0503	.0747	.0412	.0686	.061	.0413
24	.1715	.0366	.0503	.0572	.0467	.0503	.061
Max	.2947	.3109	.2835	.2801	.1715	.2641	.2772
Min	.0514	.0267	.0377	.0314	.02	.0366	.032
Avg	.1362	.1453	.1339	.1057	.0840	.1212	.1073

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244091 / 33/11 KV Bhilwadi (Malwadi)

Feeder No / Name : 203 / 11 KV MALWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0709	.052	.0709	.0701	.0526	.0532	.0526
2	.0701	.0537	.0716	.4967	.4843	.4012	.4167
3	.0701	.0537	.0716	.6019	.4534	.4687	.4374
4	.0716	.0724	.1086	.5864	.4572	.506	.4374
5	.0914	.0924	.1267	.6249	.4801	.5281	.4481
6	.128	.1307	.1646	.6405	.5247	.5668	.5138
7	.1109	.1663	.1663	.7253	.664	.6554	.6722
8	.1629	.1448	.1109	.7716	.8381	.7682	.7748
9	.0867	.0867	.1075		.0474	.9393	.8539
10	.124	.0791	.1017	.0686	.0446	.052	.0838
11	1.1574	1.4083	1.3283	.0648	.048	.0492	.0848
12	1.3916	1.5384	1.4883	.0648	.0655	.0838	.0671
13	1.5497	1.5364	1.4373	.0995	.048	.08	.0678
14	1.5181	1.5061	1.3435	.0678	.0463	.1029	.0509
15	1.5684	1.3757	1.2809	.0486	.0469	.0876	.0671
16	1.5339	1.358	1.25	.0503	.048	.0663	.0655
17	1.4217	1.3283	1.2323	.0819	.0486	.0625	.0772
18	1.1574	1.1385	1.0802	.124	.0995	.081	.1227
19	.1086	.128	.1097	.1267	.1097	.1267	.1433
20	.1341	.1097	.1097	.1075	.1097	.1097	.1086
21	.0905	.0905	.0905	.0886	.0905	.0914	.1097
22	.0724	.0716	.0905	.0886	.0724	.0914	.0905
23	.0724	.0716	.0701	.0905	.0716	.0716	.0701
24	1.1431	.0686	.0709	.0693	.0876	.0537	.0693
Max	1.5684	1.5384	1.4883	.7716	.8381	.9393	.8539
Min	.0701	.052	.0701	.0486	.0446	.0492	.0509
Avg	.5794	.5276	.5034	.2504	.2099	.2540	.2452

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 201 / 11 KV ARWADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1638		.2321				.1966
2	1.4746		.1989				1.3923
3	1.5249		.1966				1.5249
4	1.5581		.1966				1.5249
5	1.6244		.1966	.1989		1.6598	1.5912
6	1.757		.2321	.2486		1.861	.1989
7	2.0885	.2915	.2984	.2984	2.0622	2.3304	.3647
8	2.3868	.3401	.3315	.2818	2.5652	2.6322	.3978
9	2.6322	.3277			2.6825	2.9172	.4144
10	.2105	.2622	.2818			.1989	.2429
11		2.4863	2.8841			.2321	.2591
12	3.1493	3.0167	2.9172				
13	3.1493	3.1493	2.8178	.2267			.2753
14		2.9835					
15		3.1161	2.7328				
16	3.0681	2.9835	2.5987		.285	.2622	.2401
17		2.8509	2.5652		.3018	.2622	
18	2.4863	2.3537	2.2634	.3041	.3353	.2949	.192
19	.3239	.3277	.2984	.3239	.3353	.2984	.3239
20	.2753	.2949	.2321	.3077	.3149	.2984	
21		.2949	.2984		.2818	.2652	.2915
22		.2652	.1989	.2429	.2652	.2321	
23	.208	.2321	.1823		.2155	.2294	
24	1.8732	.192	.2321	.1658	.1619	.1989	.2294
Max	3.1493	3.1493	2.9172	.3239	2.6825	2.9172	1.5912
Min	.1638	.192	.1823	.1658	.1619	.1989	.192
Avg	1.6641	1.4316	1.0175	.2599	.8172	.8858	.5682

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 204 / 11 KV DHAVLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0503		.0488				.0309
2	.0309		1.2186				.0229
3	.0309		1.2193				.0217
4	.0286		1.2803				.0194
5	.0305		1.4198	1.3108		.0259	.0274
6	.0343		1.6358	1.4815		.0272	.021
7	.0389		2.2455	1.8501	.0251	.0274	.032
8	.0305		2.6246	2.0241	.0305	.0457	.0343
9	.048				.044	.0244	.0419
10	.0381		.0617		.0442	.0351	.032
11			.0143		2.2405	2.4291	2.2672
12	.0686		.021		2.4486	2.1445	
13	.0686		.061	2.672	2.3045	2.3685	2.5911
14		.0686			2.2405	2.4326	
15		.0457	.0545			2.3685	
16	.0914	.0419	.0545		1.8027	2.1765	2.753
17		.0457	.0587		1.781	2.2455	
18	.0482	.0827	.0629	1.6404	1.5699	2.1872	2.0557
19	.0503	.072	.0526	.0526	.0545	.0663	.0663
20	.044	.064	.0545	.048	.0503	.0495	.0743
21		.0572	.0514		.0476	.0476	.0617
22		.0533	.0533	.0412	.0446	.0476	
23	.0387	.0457	.0549		.0472	.0396	
24	1.829	.0333	.0457	.0503	.028	.044	
Max	1.829	.0827	2.6246	2.672	2.4486	2.4326	2.753
Min	.0286	.0333	.0143	.0412	.0251	.0244	.0194
Avg	.1444	.0555	.5634	1.1171	.8708	.9416	.5972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 212 / 11 KV NIMANI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686		.0693				.0701
2	1.0669		.0701				1.1584
3	1.1111		.0724				1.1728
4	1.1111		.0732				1.1873
5	1.1561		.0732	.0747		1.0185	1.1873
6	1.2186		.1109	.112		1.1702	1.2651
7	1.5364	.1097	.112	.112	1.4723	1.4083	1.5043
8	1.6644	.1086	.0739		1.7814	1.5684	1.7604
9	1.8404	.112			1.7604	1.6964	1.9204
10	.1063	.1086	.0709		.0709	.1109	.0362
11		2.17	2.0405		.0716	.112	.0373
12	2.2939	2.4577	2.2939		.0724	.1097	
13	2.2939	2.3922	2.2672	.0732	.1097	.1097	.0754
14		2.3922			.0724	.1097	
15		2.332	2.2996			.0739	
16	2.5194	2.2672	2.2348		.0709	.1109	.0724
17		2.1445	2.0805		.1075	.1063	
18	2.0317	1.829	1.866	.1463	.1086	.1063	.1097
19	.1086	.1448	.1086	.112	.2195	.1097	.1086
20	.1097	.1463	.1433	.1109	.1052	.1086	.1097
21		.1086	.1097		.1052	.1086	.1097
22		.1086	.1063	.1097	.1063	.1097	
23	.0678	.0701	.0693		.0686	.0709	
24	.064	.0671	.0693	.0686	.0686	.0671	.0693
Max	2.5194	2.4577	2.2996	.1463	1.7814	1.6964	1.9204
Min	.064	.0671	.0693	.0686	.0686	.0671	.0362
Avg	1.1316	1.0594	.7461	.1022	.3748	.4193	.6641

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 401 / 33KV Hatnoor

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9239		2.2634				2.2634
2	1.9044		2.1502				2.2634
3	1.8107		2.037				2.1502
4	1.9239		2.037				2.1502
5	2.037		2.2634	2.2634		2.1285	2.3765
6	2.2634		2.6029	2.7435		2.7435	2.8292
7	2.4897		2.7161	2.7161	2.8578	2.7435	2.8292
8	2.4897	2.5149	2.7161	2.6029	2.7161	2.7161	2.7161
9	2.4897	2.6029			2.4331	2.6029	2.8292
10	2.8292	2.037				2.6886	2.8006
11		2.037	2.6029		1.1694	2.9127	2.7721
12	2.8006	2.9127	2.4897			2.3525	
13	2.6029	2.7161	1.8656	2.8006	1.1317	2.3525	2.9938
14		2.6029				2.7161	2.5766
15		2.6886	2.6029			2.9127	
16	2.6886	2.8006	2.6029		1.4563	2.9938	2.9938
17		2.8829	2.6886		1.9547	2.8829	
18	3.3265	3.2156	3.2487	3.4728	3.3608	3.2487	3.6214
19	3.5848	3.6969	3.6214	3.6969	3.3951	3.6969	3.5848
20	3.1687	3.2819	3.1687	3.2819	3.0556	3.3951	3.2819
21		2.8292	2.8292		2.6292	3.0556	2.9721
22		2.6029	2.4897	2.6029	2.4897	2.8292	
23	2.2634	2.2634	2.2634		2.0725	2.3765	
24	6.5638	2.037		2.2634	2.2634	2.0165	2.3765
Max	6.5638	3.6969	3.6214	3.6969	3.3951	3.6969	3.6214
Min	1.8107	2.037	1.8656	2.2634	1.1317	2.0165	2.1502
Avg	2.7312	2.6896	2.5630	2.8444	2.3561	2.7682	2.7569

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 405 / Sawlaj

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-DEC-17
HR	Load (MW)
10	1.2757
Max	1.2757
Min	1.2757
Avg	1.2757

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 406 / 33 KV Sut Girani

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-DEC-17
HR	Load (MW)
24	1.4003
Max	1.4003
Min	1.4003
Avg	1.4003

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 201 / 11 KV Kasabe Digraj

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.462	.2263	.2641	.362	.3772	.2452	.2641
2	.3696	.2263	.2641	.362	.3772	.2452	.2641
3	.3696	.2263	.3395	.362	.3772	.2452	.2829
4	.3696	.2452	.3395	.543	.3772	.2452	.2829
5	.3696	.3018	.4904	.591	.3961	.3395	.2641
6	.3696	.3961	.4904	.5552	.3961	.415	.3961
7	.439	.415	.679	.6268	.4338	.415	.3772
8	.3982	.3772	.679	.4835	.415	.3961	.3772
9	.362	.547	.547		.3395	.3206	.4527
10	.362	.6348	.362	.4938	.2829	.5041	.4904
11	.2743	.3921	.5068	.4938	.2452	.5041	.5093
12	.3292	.5788	.5194	.2926	.2641	.5041	.5093
13	.3841	.4294	.362	.2829	.2641	.4481	.5093
14	.4435	.5788	.4835	.3018	.2263	.5975	.5281
15	.6099	.5415	.5552	.3018	.2452	.5041	.6036
16	.5544	.4481	.4656	.3395	.2829	.4294	.3395
17	.5544	.3547	.5014	.3772	.2829	.3921	.5093
18	.6283	.6161	.5014	.6908	.3772	.6535	.6602
19	.7762	.8215	.5014	.6722	.4904	.7095	.8299
20	.7545	.6908	.5847	.5415	.4904	.7468	.811
21	.679	.6908	.7011	.4527	.415	.6161	.6979
22	.5281	.6413	.394	.3961	.3772	.6722	.6413
23	.4904	.5281	.4119	.3772	.3206	.5847	.5658
24	.4805	.2452	.4715	.362	.3772	.2641	.2829
Max	.7762	.8215	.7011	.6908	.4904	.7468	.8299
Min	.2743	.2263	.2641	.2829	.2263	.2452	.2641
Avg	.4733	.4647	.4756	.4461	.3513	.4582	.4770

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 202 / 11 KV NANDRE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0566	.0754	.0747	.0754	.0566	.0566
2	.3239	.2743	.2572	.0747	.0754	.0566	.0566
3	.3239	.2743	.2915	.0747	.0754	.0566	.0566
4	.3239	.2743	.2915	.0747	.0754	.0566	.0566
5	.3239	.3086	.2915	.0747	.0754	.0754	.0566
6	.3725	.3086	.2915	.0747	.0754	.0754	.0566
7	.3841	.3601	.3429	.056	.0754	.0754	.0566
8	.3795	.3772	.3601	.056	.0754	.0754	.0566
9	.0566	.4115	.4115	.0754	.0754	.0754	.0566
10	.0566	.0566	.0747	.0754	.0754	.0566	.0566
11	.0566	.0566	.0747	.6588	.5144	.631	.5487
12	.0566	.0566	.0747	.6859	.5316	.631	.5487
13	.0566	.0566	.0747	.703	.5144	.631	.5658
14	.0566	.0566	.0747	.6274	.4973	.6135	.5316
15	.0566	.0566	.0747	.6274	.4973	.6135	.5487
16	.0566	.0566	.0747	.6173	.4973	.5609	.5487
17	.0566	.0566	.056	.6274	.4801	.5144	.4458
18	.0566	.0566	.056	.5935	.4973	.463	.4287
19	.0566	.0566	.0747	.0754	.0754	.0566	.0566
20	.0566	.0566	.0747	.0754	.0754	.0566	.0566
21	.0566	.0754	.0747	.0754	.0754	.0566	.0566
22	.0566	.0754	.0747	.0754	.0754	.0566	.0566
23	.2185	.0754	.0747	.0754	.0754	.0566	.0566
24	.2084	.0566	.0754	.0747	.0754	.0566	.0566
Max	.3841	.4115	.4115	.703	.5316	.631	.5658
Min	.056	.0566	.056	.056	.0754	.0566	.0566
Avg	.1545	.1480	.1540	.2626	.2182	.2357	.2113

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 203 / 11 KV TUNG VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.0914	.0914	.1097	.1132	.1097	.1097
2	.1097	.0914	.0914	.1097	.112	.1097	.1097
3	.1097	.0914	.0914	.1097	.112	.1097	.1097
4	.1097	.1097	.0914	.128	.112	.1097	.1097
5	.1829	.1646	.128	.1463	.1494	.2012	.128
6	.2715	.2561	.2926	.2926	.2801	.2926	.2743
7	.2865	.2926	.2743	.2715	.2378	.2926	.2561
8	.2353	.2378	.2561	.2715	.2012	.2561	.2378
9	.2353	.2195	.2378	.2195	.1646	.2378	.2012
10	.1991	.2743	.2378	.2195	.0549	.2195	.2378
11	.1629	.2195	.2195	.2033	.0549	.2195	.2378
12	.181	.2012	.2195	.1829	.0514	.1829	.2195
13	.1829	.1829	.1829	.1478	.0549	.1829	.2195
14	.1829	.1829	.1829	.1478	.0549	.1829	.2012
15	.1463	.1463	.1646	.1478	.0183	.128	.128
16	.1646	.1463	.1463	.1109	.0183	.1097	.1097
17	.2012	.1646	.1829	.1848		.1829	.1646
18	.2743	.2378	.2561	.2218	.2561	.2195	.2378
19	.2926	.2926	.2926	.3206	.3292	.2926	.2743
20	.2743	.2743	.2926	.2743	.3109	.2926	.2926
21	.2561	.2561	.2743	.2641	.2561	.2561	.2743
22	.2012	.2195	.2378	.2241	.2561	.2195	.2378
23	.1646	.1646	.1829	.1886	.2926	.1829	.1646
24	.1109	.1097	.1097	.1097	.1698	.1097	.1097
Max	.2926	.2926	.2926	.3206	.3292	.2926	.2926
Min	.1097	.0914	.0914	.1097	.0183	.1097	.1097
Avg	.1936	.1928	.1974	.1919	.1592	.1958	.1936

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 205 / 11 KV TUNG AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0566	.0377	.0373	.0566	.0566	.0377
2	.4801	.4748	.426	.0373	.0566	.0566	.0377
3	.4801	.4748	.4915	.0373	.0566	.0566	.0377
4	.4801	.5087	.4915	.0373	.0566	.0566	.0377
5	.5121	.5087	.4915	.0373	.0566	.0566	.0377
6	.5441	.5426	.5571	.0373	.0566	.0566	.0377
7	.6081	.7461	.6882	.0373	.0566	.0566	.0566
8	.7116	.8648	.852	.0373	.0566	.0566	.0566
9	.7907	.9156	.8848	.0377	.0566	.0754	.0566
10	.0377	.0566	.0373	.0377	.0377	.0566	.0754
11	.0377	.0566	.056	1.2018	.78	1.2887	1.2887
12	.0377	.0566	.056	1.8679	.8987	.5506	1.3735
13	.0377	.0566	.056	1.2346	.8817	1.0174	1.2887
14	.0377	.0566	.0373	1.1584	.8309	1.419	1.2378
15	.0377	.0566	.0373	1.1574	1.0174	1.2717	1.17
16	.0566	.0566	.056	1.1873	.9835	1.2548	1.17
17	.0566	.0754	.056	1.2029	.9496	1.1736	1.0513
18	.0566	.0566	.056	1.0802	.8648	1.0059	.7461
19	.0566	.0566	.056	.0566	.0566	.0566	.0377
20	.0566	.0566	.056	.0566	.0566	.0566	.0377
21	.0566	.0566	.056	.0566	.0566	.0566	.0377
22	.0566	.0377	.056	.0566	.0566	.0377	.0377
23	.0566	.0377	.056	.0566	.0566	.0377	.0377
24	.0373	.0566	.0377	.0373	.0566	.0566	.0377
Max	.7907	.9156	.8848	1.8679	1.0174	1.419	1.3735
Min	.0373	.0377	.0373	.0373	.0377	.0377	.0377
Avg	.2234	.2468	.2369	.4494	.3372	.4112	.4177

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 206 / 11 KV Vasant LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1086	.0566	.0566	.0701	.0754	.0943
2	.1086	.0566	.0566	.0701	.0754	.0943
3	.1086	.0566	.0566	.0701	.0754	.0943
4	.1086	.0566	.0566	.0701	.0754	.0943
5	.1254	.0566	.0566	.0701	.0754	.0943
6	.1417	.0566	.0566	.0526	.0754	.0943
7	.1578	.0754	.0566	.1509	.0754	.0943
8	.1886	.2452	.2075	.1509	.1698	.132
9	.2229	.2452	.2075	.2452	.1509	.1509
10	.2452	.2263		.2452	.1509	.1509
11	.2452	.2641	.2561	.2829	.1886	.2829
12	.2452	.2829	.2896	.2829	.1886	.1886
13	.2452	.2829	.2715	.2829	.1698	.1886
14	.2452	.2641	.2715	.2452	.1886	.1698
15	.2452	.2263	.2715	.2452	.1886	.1698
16	.2452	.2263	.2715	.2829	.1698	.1698
Max	.2452	.2829	.2896	.2829	.1886	.2829
Min	.1086	.0566	.0566	.0526	.0754	.0943
Avg	.1867	.1674	.1629	.1761	.1308	.1415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 201 / 11 KV Mouje Digraj

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191	.0191	.0191	.0191
2	.0189	.0373	.0156	.0191	.0191	.0191	.0191
3	.0189	.0373	.0156	.0191	.0191	.0191	.0191
4	.0189	.0373	.0156	.0191	.0191	.0191	.0191
5	.0189	.0373	.0156	.0191	.0191	.0191	.0191
6	.0189	.0373	.0156	.0191	.0191	.0191	.0191
7	.0189	.0373	.0151	.0191	.0191	.0191	.0191
8	.0189	.0162	.0151	.0191	.0191		.0191
9	.0358	.0162	.0149		.0191	.0019	.0191
10	.0191	.0191	.0191	.0191	.0019	.0191	.0191
11	.0191	.0191	.0191	.0156	.0166	.0373	.0373
12	.0191	.0191	.0191	.0156	.0164	.0373	.0373
13	.0191	.0191	.0191		.0164	.0373	.0373
14	.0191	.0191	.0191	.0158	.0164	.0373	.0373
15	.0191	.0191	.0191	.0158	.0164	.0373	.0373
16	.0191	.0191	.0191	.0158	.0164	.0373	.0373
17	.0191	.0191	.0191	.0158	.0164	.0373	.0373
18	.0191	.0191	.0191	.0158	.0158	.0373	.0373
19	.0191	.0191	.0191	.0191	.0019	.0191	.0191
20	.0191	.0191	.0191	.0191	.0019	.0191	
21	.0191	.0191	.0191	.0191	.0019	.0191	.0191
22	.0191	.0191	.0191	.0191	.0019	.0191	.0191
23	.0191	.0191	.0191	.0191	.0019	.0191	.0191
24	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Max	.0358	.0373	.0191	.0191	.0191	.0373	.0373
Min	.0189	.0162	.0149	.0156	.0019	.0019	.0191
Avg	.0197	.0234	.0179	.0180	.0139	.0247	.0254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 203 / 11 kv PWW Bramhnal

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.0934	.1052	.1867	.104	.1063	.0876
2	.2241	.0934	.2149	.1867	.104	.1063	.2378
3	.2241	.0934	.2149	.1867	.1417	.1063	.2378
4	.2241	.0934	.2149	.1867	.1417	.1063	.2378
5	.2241	.0934	.2149	.1867	.1417	.1063	.2378
6	.2241	.0934	.2149	.1867	.1417	.1949	.2378
7	.2241	.0934	.2149	.1867	.1595	.1949	.2378
8	.2241	.2328	.2149	.1867	.1595	.2303	.2378
9	.2241	.2328	.2149		.1595	.1417	.2149
10	.2172	.2328	.181	.0754	.1433	.1753	.2195
11	.1629	.8245	.181	.0754	.1433	.1753	.2195
12	.1629	.0747	.1829	.0747	.1417	.1753	.2195
13	.1629	.0747	.1829	.0754	.1417	.1772	.2241
14	.1629	.0747	.1829	.0754	.1417	.1772	.2241
15	.1629	.1402	.1829	.0754	.1417	.2353	.2241
16	.1629	.1402	.1867	.0754	.1417	.2378	.2241
17	.0732	.1052	.1867	.0754	.1417	.2378	.2241
18	.0732	.1254	.1867	.0366	.1097	.2378	.2241
19	.0747	.1052	.1867	.0366	.1063	.2378	.0895
20	.0747	.1052	.1867	.104	.1063	.2378	.0895
21	.0747	.1052	.1829	.104	.1063	.2279	.0895
22	.0747	.1052	.1867	.104	.0709	.0876	.0895
23	.3986	.1052	.1867	.104	.0709	.0876	.0895
24	1.0249	.0934	.1052	.1867	.104	.0709	.0876
Max	1.0249	.8245	.2149	.1867	.1595	.2378	.2378
Min	.0732	.0747	.1052	.0366	.0709	.0709	.0876
Avg	.2117	.1471	.1880	.1205	.1277	.1697	.1877

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 204 / 11 KV Express LIS Feeder

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2427	.2427	.2195	.2241	.0191	.1646
2	.2241	.2241	.2195	.2195	.0191	.1646
3	.2241	.2241	.2195	.2241	.0191	.1646
4	.2241	.2427	.2195	.2241	.0191	.1646
5	.2241	.2427	.2195	.2241	.0191	.1646
6	.2241	.2241	.2195	.2241	.0191	.1646
7	.2241	.2241	.2195	.2241	.0191	.1646
8	.2241	.2218	.2195	.2241	.2054	.1629
9	.2241	.2218	.2195		.2054	.1629
10	.2241	.2218	.2195	.0686	.1867	.2195
11	.2241	.1991	.2195	.0686	.1867	.2195
12	.2241	.2195	.2195	.2427	.1867	.2195
13	.2241	.2195	.2195	.2263	.1867	.2218
14	.2241	.2195	.2195	.2263	.1867	.2218
15	.2427	.2195	.2195	.2263	.1867	.2218
16	.2195	.2195	.2378	.2263	.1867	.2241
23	.2195					
Max	.2427	.2427	.2378	.2427	.2054	.2241
Min	.2195	.1991	.2195	.0686	.0191	.1629
Avg	.2257	.2242	.2206	.2049	.1157	.1891

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 205 / 11 KV Yeshwant Express

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0631	1.0974	1.134	1.448	.2126	.8859
2	1.0631	1.0974	1.134	1.448	.2241	.8859
3	1.0631	1.0974	1.134	1.4632	.2126	.8859
4	1.0517	1.0974	1.134	1.4632	.2126	.8859
5	1.0517	1.0974	1.134	1.4175	.2126	.9568
6	1.0517	1.0974	1.134	1.4175	.2126	.9568
7	1.2269	1.4632	1.134	1.448	.9922	.9568
8	1.2269	1.3466	1.3466	1.448	.6722	1.2403
9	1.2403	1.3466	1.4883		1.0631	1.3466
10	2.9728	1.4883	1.5203	1.4883	1.3289	1.4327
11	1.4864	1.4883	1.5203	1.4175	1.3289	1.4327
12	1.4864	1.4175	1.5203	1.4175	1.3289	1.4327
13	1.4864	1.4175	1.5364	1.4175	1.3289	1.4632
14	1.5043	1.4175	1.5364	1.4175	1.386	1.4632
15	1.5043	1.4175	1.4632	1.4175	1.2536	1.4632
16	.8859	1.134	1.4632	.8859	1.2536	1.4632
24	.1524					
Max	2.9728	1.4883	1.5364	1.4883	1.386	1.4632
Min	.1524	1.0974	1.134	.8859	.2126	.8859
Avg	1.2657	1.2826	1.3333	1.4010	.8265	1.1970

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 206 / 11 KV NAWARASWADI

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.2926	.3366	.3012	.0924	.0886
2	.2987	.2926	.3366	.3012	.0886	.0886
3	.2987	.2926	.3366	.3012	.0924	.0886
4	.2987	.2926	.3366	.3077	.0924	.2328
5	.2987	.2926	.3366	.3077	.0924	.2328
6	.2987	.2926	.3366	.3077	.0924	.2328
7	.2987	.2926	.3366	.3077	.3544	.2328
8		.0886	.1772	.298	.3544	.2303
9	.2241	.0886	.3366		.3544	.2303
10	.1494	.0886	.4207	.0838	.3658	.3544
11	.1402	.2149	.4207	.3185	.3658	.3544
12	.1387	.0895	.4207	.3185	.3658	.3544
13	.1387	.0895	.4207	.3185	.3658	.3582
14	.1387	.0895	.4207	.3185	.3658	.3582
15	.1387	.3403	.4252	.3185	.2987	.3582
16	.1214	.3403	.4252	.3185	.2987	.362
Max	.2987	.3403	.4252	.3185	.3658	.362
Min	.1214	.0886	.1772	.0838	.0886	.0886
Avg	.2187	.2174	.3640	.2951	.2525	.2598

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244037 / 33/11 KV PRAKASH AGRO

Feeder No / Name : 201 / 11 KV Haripur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0164	.0171	.0189	.0189	.0179	.0162
2	.0189	.0168	.0171	.5535	.3563	.4111	.4374
3	.0189	.0171	.0171	.5535	.3887	.4062	.4428
4	.0189	.0175	.0171	.5535	.4161	.4049	.427
5	.0189	.0179	.0171	.5535	.427	.4161	.427
6	.0189	.0177	.0171	.6081	.3858	.4696	.4372
7	.0189	.0185	.0171	.6241	.4938	.5121	.4999
8	.0189	.0179	.0179	.664	.5851	.6154	.5468
9	.0189	.0181	.0179		.6167	.6154	.5468
10	.0189	.0181	.0189		.0154	.0149	.0189
11	1.0277	.9878	.9878		.0173	.0185	.0189
12	1.094	.7773	.9995		.0177	.0185	.0189
13	1.094	.9717	1.0688	.0189	.0179	.017	.0189
14	1.094	.9717	1.085	.0189	.0147	.0171	.0189
15	1.0774	.9488	1.0202	.0189	.016	.0181	.0189
16	1.0159	.9172	.9602	.0189	.0149	.0179	.0189
17	.9602	.8697	.9012	.0189	.0145	.0162	.0189
18	.8749	.8488	.8162	.0189	.0168	.0133	.0189
19	.0171	.0171	.0189	.0189	.0156	.0145	.0189
20	.0166	.0171	.0189	.0189	.0173	.0179	.0189
21	.016	.0171	.0189	.0189	.016	.0179	.0189
22	.0164	.0171	.0189	.0189	.0171	.0179	.0189
23	.0152	.0171	.0189	.0189	.0173	.0162	.0189
24	.0189	.0162	.0171	.0189	.0189	.0175	.0156
Max	1.094	.9878	1.085	.664	.6167	.6154	.5468
Min	.0152	.0162	.0171	.0189	.0145	.0133	.0156
Avg	.3553	.3154	.3385	.2178	.1640	.1718	.1692

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 201 / 11 kv Dudhgaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0177	.0133	.0152	.0175	.0133	.0168
2	.0175	.0175	.0133	.3077	.2896	.213	.2241
3	.0177	.0171	.0133	.2881	.2968	.213	.2486
4	.0171	.0173	.0133	.2968	.3005	.213	.2753
5	.0175	.0171	.0133	.3086	.3201	.213	.2622
6	.0177	.0175	.0133	.3321	.3479	.2622	.3077
7	.0179	.0175	.0133	.3795	.3593	.2915	.3481
8	.0181	.0171	.0133	.4001	.3841	.3077	.3201
9	.0168	.016	.0133	.4001	.3953	.3401	.3361
10	.0171	.0133	.0175	.0181	.0152	.0177	.0177
11	.6882	.7209	.5921	.0183		.0171	.0177
12	.6802	.7209	.583	.0185		.0168	.0156
13	.6882	.7209		.0183	.0266	.0164	.0154
14	.6882	.7045	.5601	.0173	.0266	.0162	.0156
15	.6962	.6718	.5601	.0171	.0266	.0171	.0156
16	.6554	.6554	.5121	.0171	.0133	.0162	.0154
17	.6154	.6226	.4696	.0149	.0133	.0162	.0152
18	.583	.5898	.4321	.0149	.0133	.0158	.0145
19	.0171	.0133	.0166	.0171	.0133	.0171	.0152
20	.0171	.0133	.016	.0173	.0133	.0175	.016
21	.0175	.0133	.017	.0175	.0133	.0171	.017
22	.0179	.0133	.0164		.0133	.017	.0171
23	.1703	.0133	.016	.0171	.0133	.0168	.016
24	.0164	.0175	.0133	.0154	.0173	.0133	.0166
Max	.6962	.7209	.5921	.4001	.3953	.3401	.3481
Min	.0164	.0133	.0133	.0149	.0133	.0133	.0145
Avg	.2386	.2358	.1714	.1290	.1332	.0965	.1075

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 202 / 11 KV Kavathe Piran
 Village Feeder KV- 11 /
 OUTGOING

GAOTHAN FEEDER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.1886	.168	.1886	.1867	.168	.1886
2	.1867	.1886	.168	.2096	.1867	.168	.2096
3	.1886	.1886	.168	.2286	.1867	.168	.2477
4	.1886	.1886	.168	.2096	.2263	.168	.2829
5	.1886	.2263	.168	.3772	.3584	.168	.3239
6	.3584	.4108	.3734	.4527	.4108	.4294	.4527
7	.415	.3734	.3547	.4715	.4527	.4108	.5093
8	.3772	.2987	.3174	.4108	.3395	.4108	.3961
9	.3018	.2614	.2427		.3018	.3361	.3361
10	.2614	.2427	.2402	.2801	.2829	.2743	.2614
11	.2263	.2427	.2353	.2012		.2195	.2241
12	.2263	.2241	.2715	.1829		.2353	.2263
13	.1509	.2054		.1848			.2614
14	.1132	.1867	.2033	.1867		.2033	.1886
15	.1509	.2054	.1867	.1848	.1867	.1867	.1886
16	.1886	.2241	.2218	.2012	.2241	.2012	.1867
17	.1867	.2614	.2195	.2378	.2427	.2686	.2263
18	.2641	.3174	.3292	.3292	.3361	.3292	.3018
19	.4527	.4481	.4294	.3326	.4481	.4251	.415
20	.4527	.4481		.4108	.4294	.4854	.415
21	.415	.3734	.4294	.415	.3734	.3921	.415
22	.2987	.3174	.3584	.3584	.3174	.3395	.2987
23	.2614	.2427	.2801	.2829	.2241	.2452	.2241
24	.2263	.1886	.1867	.2075	.2075	.1867	.2263
Max	.4527	.4481	.4294	.4715	.4527	.4854	.5093
Min	.1132	.1867	.168	.1829	.1867	.168	.1867
Avg	.2627	.2689	.2600	.2845	.2961	.2791	.2919

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 203 / 11 KV Kavathe Piran Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0091	.0097	.0114	.009	.0111	.0114	.009
2	.009	.0097	.0114	.6415	.4144	.5571	.5548
3	.0093	.0095	.0114	.6516	.4191	.5571	.5658
4	.0095	.0099	.0114	.6344	.4527	.5571	.5959
5	.0093	.0095	.0114	.6613	.5144	.5571	.5548
6	.0095	.0095	.0114	.703	.5304	.5898	.5316
7	.0095	.0097	.0114	.6687	.5533	.6226	.5375
8	.0095	.0095	.0114	.6274	.6001	.6554	.5658
9	.0088	.0088	.0114	.6344	.6443	.6882	.6068
10	.0095	.0114	.009	.0099	.0086	.0088	.0099
11	1.166	1.2407	1.1145	.0103		.009	.0095
12	1.2003	1.2071	1.166	.0109		.0086	.0099
13	1.2003	1.1904		.0111	.0095	.0088	.0099
14	1.2003	1.1904	1.1145	.0105	.0095	.0086	.0097
15	1.2136	1.1904	1.0802	.0105	.0095	.009	.0097
16	1.073	1.1736	1.0802	.0109	.0095	.0088	.0099
17	1.0395	1.1736	1.0974	.0107	.0095	.0088	.0099
18	1.0395	1.1568	.9088	.0105	.0095	.0086	.0097
19	.0099	.0114	.0086	.0105	.0114	.0086	.0103
20	.0103	.0114	.0088	.0105	.0114	.0088	.0099
21	.0099	.0114	.0086	.0105	.0114	.0086	.0097
22	.0097	.0114	.008	.0107	.0114	.0088	.0099
23	.0099	.0114	.0084	.0107	.0114	.009	.0099
24	.0088	.0099	.0114	.0082	.0109	.0114	.0091
Max	1.2136	1.2407	1.166	.703	.6443	.6882	.6068
Min	.0088	.0088	.008	.0082	.0086	.0086	.009
Avg	.3868	.4036	.3360	.2245	.1942	.2054	.1945

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 204 / 11 KV samdoli Village

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1372	.1494	.1341	.1698	.1307	.1372
2	.1372	.1357	.1494	.1357	.1509	.1307	.1357
3	.1387	.1372	.1494	.1509	.1494	.1307	.1886
4	.1578	.1372	.1494	.1326	.1509	.1307	.2012
5	.1753	.1578	.1494	.2035	.181	.1307	.1715
6	.1949	.2378	.2241	.2507	.197	.2241	.2058
7	.2481	.2195	.2241	.2303	.2126	.2054	.2204
8	.1949	.168	.2054	.2195	.181	.2054	.1949
9	.1791	.1646	.1867		.1509	.168	.1848
10	.181	.1829	.2402	.1663	.1698	.1886	.1867
11	.1646	.1829	.1991	.1509	.1494	.1698	.168
12	.1829	.1829	.1829	.1478	.1494	.1698	.168
13	.1646	.1829		.1478	.1307	.168	.168
14	.1267	.1829	.1848	.1478	.112	.1663	.1494
15	.128	.1829	.1433	.1478	.0934	.1478	.1478
16	.1478	.1829	.1646	.1494	.1307	.1867	.1478
17	.2427	.1829	.2452	.1867	.1494	.2241	.2054
18	.2614	.2801	.2801	.2402	.2427	.2772	.2452
19	.3174	.3361	.3439	.2378	.2987	.3077	.3361
20	.3174	.3361	.3439	.2715	.2987	.3292	.3174
21	.2987	.2987	.2865	.2896	.2614	.3045	.2987
22	.2353	.2614	.2481	.2641	.1867	.2715	.2328
23	.181	.2054	.1907	.2033	.1494	.1734	.1753
24	.1341	.1372	.168	.1526	.168	.1307	.156
Max	.3174	.3361	.3439	.2896	.2987	.3292	.3361
Min	.1267	.1357	.1433	.1326	.0934	.1307	.1357
Avg	.1936	.2006	.2091	.1896	.1764	.1947	.1976

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 205 / 11 KV Samdoli Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0189	.0189	.0191	.0189	.0189	.0191
2	.2829		.3086	.0191	.0189	.0189	.0191
3	.2829	.3772	.3086	.0191	.0189	.0189	.0191
4	.2829	.3772	.3086	.0191	.0189	.0189	.0191
5	.3395	.415	.3086	.0191	.0189	.0189	.0191
6	.3395	.415	.3429	.0191	.0189	.0189	.0191
7	.415	.4904	.4801		.0189	.0189	.0191
8	.4904	.5658	.4973	.0191	.0189	.0189	.0191
9	.5658	.6413	.6173	.0191	.0189	.0189	.0191
10	.0189	.0189	.0191	.0189	.0189	.0191	.0189
11	.0189	.0189	.0191	1.1317	.9259	.8676	.9054
12	.0189	.0189	.0191	1.1883	.9259	.8865	.8962
13	.0189	.0189		1.1694	.9259	.8676	.9808
14	.0189	.0189	.0191	1.1506	.8745	.8488	.9431
15	.0189	.0189	.0191	1.1317	.8402	.7922	.8676
16	.0189	.0189	.0191	1.094	.8059	.811	.8676
17	.0189	.0189	.0191	1.094	.7373	.7733	.7922
18	.0189	.0189	.0191	.9808	.6859	.7545	.679
19	.0189	.0189	.0191	.0189	.0189	.0191	.0189
20	.0189	.0189	.0191	.0189	.0189	.0191	.0189
21	.0189	.0189	.0191	.0189	.0189	.0191	.0189
22	.0189	.0189	.0191	.0189	.0189	.0191	.0189
23	.0189	.0189	.0191	.0189	.0189	.0191	.0189
24	.0189	.0189	.0189	.0191	.0189	.0189	.0191
Max	.5658	.6413	.6173	1.1883	.9259	.8865	.9808
Min	.0189	.0189	.0189	.0189	.0189	.0189	.0189
Avg	.1376	.1558	.1504	.4011	.2927	.2877	.3015

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 206 / 11 KV Shaurya Industries NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0747	.0514	.0747	.0686	.0343	.0434
2	.0686	.0747	.0514	.0732	.0686	.0343	.0572
3	.0686	.0747	.0514	.0709	.0686	.0343	.0743
4	.0686	.0747	.0514	.0678	.0686	.0343	.0579
5	.0686	.0747	.0514	.0678	.0686	.0514	.0714
6	.0686	.0747	.0514	.0671	.0686	.0514	.0655
7	.0686	.0747	.0514	.0686	.0686	.0343	.0686
8	.0686	.0686	.0514	.0648	.0171	.0343	.0671
9	.0514	.0686	.0686	.0724	.0171	.0514	.0857
10	.0747	.0686	.0638	.12	.0171	.0857	.112
11	.112	.0514	.0777	.0686	.0171	.132	.1307
12	.1307	.0686	.0791	.1029	.0171	.0594	.0934
13	.112	.0686		.1029	.0171	.0579	.0934
14	.112	.0857	.0838	.0857	.0171	.0983	.0747
15	.1294	.0686	.0497	.0857	.0171	.0495	.0934
16	.0747	.0686	.0693	.0857	.0171	.0457	.0934
17	.0934	.0686	.0714	.0857	.0514	.0486	.0934
18	.0934	.0514	.0429	.0857	.0514	.0526	.0514
19	.0343	.0514	.061	.0857	.0343	.0486	.0514
20	.0343	.0686	.0693	.0857	.0343	.0503	.0514
21	.0747	.0686	.0686	.0857	.0343	.0619	.112
22	.0747	.0686	.0537	.0686	.0686	.0886	.0747
23	.0747	.0514	.0747	.0686	.0343	.0829	.0747
24	.0686	.0747	.0514	.0762	.0686	.0343	.0572
Max	.1307	.0857	.0838	.12	.0686	.132	.1307
Min	.0343	.0514	.0429	.0648	.0171	.0343	.0434
Avg	.0789	.0685	.0607	.0800	.0421	.0565	.0770

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 207 / 11 kv warana kath ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.5144	.3239	.2949	.3467
3				.5426	.3315	.3113	.3258
4				.5144	.3605	.3113	.3641
5				.5426	.3681	.3113	.3391
6				.57	.3795	.3441	.3641
7				.6241	.4161	.3932	.3814
8				.6344	.4428	.4144	.3429
9				.5898	.4687	.3163	.3222
11	.823	.7865	.7545				
12	.8573	.8848	.8149				
13	.8916	.8848					
14	.823	.8951	.7716				
15	.8573	.8619	.7888				
16	.7712	.8288	.7362				
17	.7377	.7956	.8063				
18	.6706	.7459	.6588				
Max	.8916	.8951	.8149	.6344	.4687	.4144	.3814
Min	.6706	.7459	.6588	.5144	.3239	.2949	.3222
Avg	.8040	.8354	.7616	.5665	.3864	.3371	.3483

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 201 / 11 KV Budhgaon Village

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.431	.663	.7011	.4588		.5967	.6516
2	.426	.663				.5967	.6588
3		.5801	.6516			.5967	.6001
4		.5801	.6588			.5801	.6068
5	.431	.4801	.6516	.4475			.6001
6	.4752	.4801	.6344	.5304			.6068
7	.6554	.4973	.6173	.6203		.4973	.6516
8	.6133			.5967	.5243		
10		.4858			.4144		.6133
11		.4938	.6062				.5898
12		.4877			.4144		.5304
13		.5335	.3812				.503
14		.5093	.4915		.4973		.4641
15		.503	.6133		.4973		.5426
16		.5344	.6299		.4973		.5967
17		.6935	.6226		.5801		.6203
18		.7888	.6796		.6299	.7455	.7122
19			.7712				.8288
20	.7459		.7127				.7045
21			.6796				.7045
22	.7956		.6539		.663		.6874
24			.6935	.4807	.5801	.6299	.6935
Max	.7956	.7888	.7712	.6203	.663	.7455	.8288
Min	.426	.4801	.3812	.4475	.4144	.4973	.4641
Avg	.5717	.5608	.6361	.5224	.5298	.6061	.6270

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 202 / 11 KV Kaleran (Kavalpur) SEPARATED AG FEEDERS HAVING SPECIAL
 AG Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0648	.0497	.0693	.0492			.0701
2	.5506	.4973	.5335				.0526
3		.4973	.5401				.0867
4		.663	.6097			.0497	.0867
5	.6226	.7459	.6097	.0492			.0857
6	.6316	.7202	.7099	.0492			.0543
7	.7611	.7459	.7621	.081			.0905
8	.9503			.1134	.0655	.0497	
10		.0686			.0497		.0497
11		.0857	.0762				1.0159
12		.0867			.9945		1.1174
13		.0857	.064				1.1203
14		.0857	.081		1.0774		1.1984
15		.0857	.0648		1.0774		1.1633
16		.0857	.0655		1.1603		1.085
17		.0686	.0655		1.0774		1.0364
18		.0347	.0972		.9945	.7926	.8848
19			.0972				.0648
20	.0497		.081				.0648
21			.0655				.0819
22	.0497		.0655		.056		.0648
24		.0497	.0693	.0648	.0509	.0497	.0686
Max	.9503	.7459	.7621	.1134	1.1603	.7926	1.1984
Min	.0497	.0347	.064	.0492	.0497	.0497	.0497
Avg	.4601	.2739	.2488	.0678	.6604	.2354	.4544

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 203 / 11 KV Bisur village

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.2241	.1372	.112		.1867	.1715
2	.0747	.2241	.1372			.1696	.1734
3		.2241	.1372			.1989	.1928
4		.2801	.1372			.2241	.2103
5	.112	.2801	.1372	.112		.2241	.2103
6	.168	.2801	.1715	.1867			.1907
7	.2241	.2801	.1715	.2054		.1867	.2058
8	.168			.1867	.1698		
10		.2401			.168		.112
11		.1715	.112				.112
12		.1734					.0747
13			.0934				.0747
14		.12	.0934				.0934
15		.1052	.112		.1494		.0934
16		.0857	.112		.112		.0934
17		.104	.0934		.1326		.0934
18		.1372	.168		.1494	.1029	.1494
19			.2241				.2614
20	.1696		.2427				.2241
21			.2054				.2054
22	.2035		.168		.1867		.1867
24		.2241	.1372	.112	.168	.1867	
Max	.2241	.2801	.2427	.2054	.1867	.2241	.2614
Min	.0747	.0857	.0934	.112	.112	.1029	.0747
Avg	.1517	.1971	.1469	.1525	.1545	.1850	.1564

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 204 / 11 KV Budhgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0328		.0526	.0324		.0497	.0514
2	.0492	.048	.0532			.1658	.3121
3						.1989	.3048
4						.1989	.3048
5	.0486			.1943		.1989	
6	.0492		.0543	.2429			
7	.0486	.0497	.0543	.2949		.2486	.3048
8	.0486			.421	.4915		
10		.0509					.048
11		.5487	.663				.0486
12		.6401			.0497		.0486
13			.6554				.0492
14			.6962		.0497		.0486
15		.6097	.6226				.0486
16		.6097	.6226				.0492
17		.6097	.583				.0492
18		.503	.5344		.0497	.0358	.0497
19			.0492				.0492
20			.0492				.0492
21			.0486				.0486
22	.0497		.0486		.0497		.0492
24		.0497	.052	.0328	.0492	.0497	.0566
Max	.0497	.6401	.6962	.421	.4915	.2486	.3121
Min	.0328	.048	.0486	.0324	.0492	.0358	.048
Avg	.0467	.3719	.3025	.2031	.1233	.1433	.1037

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 205 / 11 KV Express college
feeder Feeder KV- 11 /
OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.0747	.0867	.132		.0747	.104
2	.0754	.0934				.0678	.12
3						.0663	
4		.0934				.112	.1214
5	.132			.132		.112	
6	.132		.0857	.132			.1372
7	.0754	.1187	.0857	.132		.112	.1494
8	.0754			.0754	.0747		
10		.0876			.1307		.1886
11		.0876	.1494				.1132
12		.0886			.112		.0943
13		.112	.0943				.0943
14		.12	.1509		.1017		.1886
15			.1132		.112		.1886
16		.1134	.1132		.0995		.0754
17		.112	.1132				.1509
18		.1134	.132		.112	.1387	.1509
19			.0754				.0754
20	.0934		.132				.0754
21			.132				.1509
22	.0934		.132		.0934		.1509
24			.0857	.132	.0754	.0678	.0857
Max	.132	.12	.1509	.132	.1307	.1387	.1886
Min	.0754	.0747	.0754	.0754	.0747	.0663	.0754
Avg	.1011	.1012	.1121	.1226	.1013	.0939	.1271

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 207 / 11 KV Jyptirling LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.056		.0754	.0373	.0514
2	.0943	.0663			.0663	
3		.0747			.0747	
4		.0678			.0747	
5	.0754	.0747		.0754	.1494	
6	.0754	.0663		.0943		.052
7	.0754	.0747	.0492	.0943	.1494	.0543
8	.0754			.0943		
9			.0492			
10						.0754
11			.0377			.0377
12						.1509
13			.1509			.132
14			.0943			.0934
15			.0189			.0373
16		.0514	.0754		.0972	.056
Max	.0943	.0747	.1509	.0943	.1494	.1509
Min	.0377	.0514	.0189	.0754	.0373	.0373
Avg	.0723	.0665	.0679	.0867	.0927	.0740

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 208 / 11 KV Bisur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0301	.0492	.0514	.0762			
2	.6241	.3277	.8383				.1214
3		.4915					
4		.8192	.8573				
5	.6923	.8288	.8907	.1054			
6	.7727	.9012	.9945	.1189			.1254
7	.9065	.9831	.9907	.104		.0497	.12
8	1.1138			.088	.0587		
10		.0693					.0772
11		.0701	.0903				1.1736
12		.0886					1.2492
13							1.1591
14			.0602		.8288		1.1888
15			.0602		.8619		1.2793
16			.0594		.8173		1.2803
17		.0686	.0892		.8619		.884
18		.0693	.0903		.8768	.9907	.8488
19			.0892				.061
20	.0492		.1067				.0772
21			.0926				.0617
22	.0492		.0914		.056		.0625
24		.0492	.0514	.0772	.0434	.0497	.0532
Max	1.1138	.9831	.9945	.1189	.8768	.9907	1.2803
Min	.0301	.0492	.0514	.0762	.0434	.0497	.0532
Avg	.5297	.3704	.3238	.0950	.5506	.3634	.5778

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081] BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 401 / 33 kv sherinala

Feeder KV- 33 / OUTGOING

DATE	05-DEC-17
HR	Load (MW)
10	.2458
12	2.4577
Max	2.4577
Min	.2458
Avg	1.3518

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 201 / 11 kV Dudhgaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1886	.1886	.2829	.1886	.1886
2	.1886	.1886	.1886	.1886	.2829	.1886	.1886
3	.1886	.1886	.1886	.1886	.2829	.1886	.1886
4	.2263	.1886	.1886	.1886	.2829	.2263	.1886
5	.3018	.2452	.2641	.2452	.3206	.2641	.2075
6	.3395	.3772	.3326	.3961	.3584	.3174	.3206
7	.3584	.3961	.3734	.415		.3734	.4527
8	.3206	.3206	.3734	.3772	.3395	.3361	.3584
9	.3395	.2641	.3206	.415	.3018	.3206	.3206
10	.3961	.2641	.3206	.5093	.3206	.2987	.2987
11	.3961	.2829	.3206	.3584	.2829	.3206	.2987
12	.415	.2641	.3584	.3584	.3018	.3206	.2829
13	.3961	.2829	.3206	.3772	.2641	.2829	.3206
14	.3395	.3018	.3772	.3584	.2452	.2641	.3547
15	.3206	.3206	.3772	.3961	.2641	.2641	.3734
16	.3018	.3174	.3206	.4338	.2641	.3018	.3511
17	.3395	.3174	.3395	.4338	.2987	.3772	.3881
18	.3584	.4435	.4527	.5304	.3511	.3395	.4207
19	.4527	.5121	.5093	.5487	.5121	.547	.5068
20	.4527	.462	.5281	.5121	.4805	.4527	.4572
21	.3772	.4108	.4715	.4854	.4108	.4527	.4294
22	.3395	.3361	.3206	.3772	.3018	.3395	.3174
23	.2263	.2641	.2452	.3018	.2263	.2452	.2452
24	.1886	.2075	.2263	.2075	.3018	.1886	.2075
Max	.4527	.5121	.5281	.5487	.5121	.547	.5068
Min	.1886	.1886	.1886	.1886	.2263	.1886	.1886
Avg	.323	.3060	.3295	.3663	.3164	.3083	.3194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 202 / 11 kV Sawalwadi Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191	.0191	.0191	.0191
2	.3418	.3856	.2743	.0191	.0191	.0191	.0191
3	.3418	.3856	.2743	.0191	.0191	.0191	.0191
4	.3418	.3856	.2623	.0191	.0191	.0191	.0191
5	.3612	.4024	.2968	.0191	.0191	.0191	.0191
6	.3763	.4359	.3163	.0381	.0191	.0191	.0381
7	.3913	.503	.3681	.0381	.0191	.0191	.0381
8	.4214	.503	.4049	.0381	.0191	.0191	.0381
9	.4214	.503	.4858	.0381	.0191	.0191	.0381
10	.0191	.0191	.0191	.0381	.0191	.0191	.0191
11	.0191	.0191	.0191	.5952	.3521	.7042	.6401
12	.0191	.0191	.0191	.5952		.3353	.6964
13	.0191	.0191	.0191	.6358	.583	.7545	.6718
14	.0191	.0191	.0381	.6222	.5668	.7377	.6154
15	.0191	.0191	.0191	.6173	.5601	.7377	.6062
16	.0191	.0191	.0381	.6447	.4961	.7042	.5668
17	.0381	.0191	.0191	.6173	.4784	.5575	.5121
18	.0381	.0191	.0191	.5487	.4858	.5575	.4321
19	.0381	.0381	.0191	.0191	.0191	.0381	.0381
20	.0381	.0191	.0191	.0191	.0191	.0381	.0191
21	.0191	.0191	.0191	.0191	.0191	.0381	.0191
22	.0191	.0191	.0191	.0191	.0191	.0191	.0191
23	.0191	.0191	.0191	.0191	.0191	.0191	.0191
24	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Max	.4214	.503	.4858	.6447	.583	.7545	.6964
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.1408	.1595	.1261	.2199	.1664	.2271	.2142

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 203 / 11 kV Dharan Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.5571	.6203	.3479	.3277
3				.5571	.6203	.3479	.3605
4				.5571	.6203	.3749	.3605
5				.5571	.6203	.4161	.3605
6				.5735	.6203	.4534	.4424
7				.7045	.6203	.4915	.4752
8				.7537	.6539	.6203	.5079
9				.8048	.6539	.6443	.5243
11	1.1401	1.1736	1.2071				
12	1.1401	1.2378	1.2239				
13	1.1736	1.1904	1.2239				
14	1.1904	1.1469	1.2239				
15	1.2239	1.1174	1.17				
16	1.1736	1.1012	1.1401				
17	1.1736	1.1012	1.1233				
18	1.073	1.0883	.9389				
Max	1.2239	1.2378	1.2239	.8048	.6539	.6443	.5243
Min	1.073	1.0883	.9389	.5571	.6203	.3479	.3277
Avg	1.1610	1.1446	1.1564	.6331	.6287	.4620	.4199

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 204 / 11 kV Bagani road Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191		.0191	.0191
2	.3479	.285	.2656	.0191		.0191	.0191
3	.3479	.285	.25	.0191		.0191	.0191
4	.3479	.285	.2721	.0191		.0191	.0191
5	.3479	.285	.2753	.0191		.0191	.0191
6		.3018	.2915	.0191		.0191	.0191
7	.4161	.3521	.3932	.0191		.0191	.0381
8	.4321	.4024	.426	.0191		.0191	.0191
9	.4372	.4694	.4424	.0191		.0191	.0191
10	.0191		.0191	.0191		.0191	.0381
11	.0191		.0191	.5761	.4862	.57	.4858
12	.0191	.0191	.0191	.5761	.503	.57	.0381
13	.0191	.0191		.5601	.216		.5304
14	.0191	.0191	.0191	.5601	.3725	.5868	.5365
15	.0191	.0191	.0191	.5535	.3841	.5868	.57
16	.0191	.0191	.0191	.5535	.4161	.5868	.5407
17	.0191	.0191	.0191	.5376	.3858	.5376	.4858
18	.0381	.0191	.0191	.5218	.4049	.4586	.4534
19	.0381	.0381	.0381	.0191	.0381	.0381	.0381
20	.0381	.0381	.0381		.0381	.0381	.0381
21	.0191	.0381	.0381		.0381	.0381	.0381
22	.0381	.0381	.0381		.0381	.0381	.0191
23	.0191	.0191	.0191		.0191	.0191	.0191
24	.0191	.0191	.0191	.0191		.0191	.0191
Max	.4372	.4694	.4424	.5761	.503	.5868	.57
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.1330	.1368	.1295	.2334	.2569	.1860	.1684

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 205 / 11 KV A1 PPS Express

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3961	.4108	.3772	.4527	.3772	.4527
2	.3961	.4108	.3772	.4527	.3772	.4527
3	.3961	.4108	.3772	.4527	.3772	.4527
4	.3961	.4108	.3772	.4527	.3961	.4527
5	.4715	.4108	.4527	.4527	.3961	.4527
6	.4715	.4481	.5093	.547	.415	.5281
7	.4715	.5415	.5281	.5658	.4904	.5281
8	.4904	.5415	.547	.6413	.5093	.5093
9	.5093	.5788	.6036	.6224	.5093	.547
10	.5093	.0566	.6413	.6224	.5658	.5658
11	.5093	.0377	.6224	.6413	.547	.5658
12	.5093	.4527	.6224	.6602	.547	.5281
13	.5093	.5658	.5847	.6224	.5847	.5847
14	.5093	.5847	.5847	.6413	.6036	.5847
15	.5847	.5847	.6036	.6036	.6036	.5847
16	.5847	.5658	.5847	.5847	.6036	.5847
Max	.5847	.5847	.6413	.6602	.6036	.5847
Min	.3961	.0377	.3772	.4527	.3772	.4527
Avg	.4822	.4382	.5246	.5635	.4939	.5234

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244090 / 33/11KV Nandre S/Stn

Feeder No / Name : 201 / 11 KV Nandre Village

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4715	.4715	.5914	.5658	.5281	.5068	.5281
2	.4527	.4527	.5658	.5281	.5281	.4706	.4904
3	.4527	.4536	.6224	.5281	.5093	.5093	.4904
4	.4527	.4527	.7545	.5281	.5281	.5093	.4904
5	.5914	.5658	1.0269	.7762	.6468	1.0185	.6036
6	.823	.8676	.9709	.9709	.8686		.9055
7	.8326	.8131	.9149	.9795	.9795	.8962	.8686
8	.8145	.811	.8048	.8048	.7133	.8589	.823
9	.7522	.7865	.823		.7499	.7207	.7682
10	.6626	.6219	.7133	.6697		.7207	.6878
11	.6626	.6335	.6335	.6268	.631	.6099	.6241
12	.6697	.6335	.6154	.6024	.591	.6283	.5847
13	.5973	.591	.6268	.543	.543	.5853	.5721
14	.5611	.591	.6089	.591	.4887	.567	.5373
15	.4755	.5493	.5552	.5028	.5014	.5487	.5201
16	.5121	.5731	.547	.5138			.5138
17	.6036	.5792	.6154	.591	.5611	.5487	.5611
18	.8238	.8048	.8413	.905	.8507	.7522	.7682
19	1.0791	1.0425	1.0903	1.0791	1.0498	1.0903	1.0498
20	.9979	.9511	1.0534	1.0534	1.0136	1.0456	1.0242
21	.9335	.9511	.9709	.9896	.905	.9619	.7947
22	.7545	.7947	.8215	.8676	.788	.8488	.7762
23	.6036	.7392	.7545	.6979	.7164	.6413	.6413
24	.547	.5281	.6468	.6413	.6036	.5373	.5658
Max	1.0791	1.0425	1.0903	1.0791	1.0498	1.0903	1.0498
Min	.4527	.4527	.547	.5028	.4887	.4706	.4904
Avg	.6720	.6774	.7570	.7198	.6952	.7080	.6746

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244090 / 33/11KV Nandre S/Stn

Feeder No / Name : 202 / 11 kV Nandre Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	03-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
12		.0377	
21			.0377
24	.3048		
Max	.3048	.0377	.0377
Min	.3048	.0377	.0377
Avg	.3048	.0377	.0377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244090 / 33/11KV Nandre S/Stn

Feeder No / Name : 203 / 11 KV Malbhag Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0189	.0189	.0189	.0189	.0189	.0377
2	.0189	.0189	.0189	.0943	.1132	.1132	.1132
3	.0189	.0189	.0189	.0943	.1132	.1132	.1132
4	.0189	.0189	.0189	.0943	.1132	.1132	.1132
5	.0189	.0189	.0189	.1132	.132	.132	.1132
6	.0189	.0189	.0189	.132	.132	.1509	.1132
7	.0377	.0189	.0189	.1509	.1698	.1509	.132
8	.0377	.0377	.0189	.1509	.2075	.1886	.1698
9	.0189	.0377	.0189	.1698	.2075	.2075	.1698
10	.0377	.0189	.0377	.0377		.0377	.0189
11	.2452	.2829	.2641	.0377	.0377	.0377	.0377
12	.2641	.3018	.2829	.0377	.0566	.0377	.0377
13	.3018	.3018	.2829		.0754	.0377	.0377
14	.2829	.3018	.2829	.0377	.0754	.0377	.0189
15	.2829	.2829	.2829	.0377	.0377	.0377	.0189
16	.3018	.2641	.2829	.0377		.0377	.0189
17	.2641	.2452	.2641	.0566	.0377	.0377	.0377
18	.2263	.2075	.2452	.0566	.0377	.0189	.0189
19	.0377	.0377	.0377	.0566	.0377	.0377	.0189
20	.0377	.0377	.0377	.0377	.0377	.0377	.0189
21	.0189	.0377	.0377	.0377	.0189	.0377	.0189
22	.0189		.0189	.0189	.0189	.0377	.0189
23	.0189	.0189	.0189	.0189	.0189	.0377	.0189
24		.0189	.0189	.0189	.0189	.0189	.0377
Max	.3018	.3018	.2829	.1698	.2075	.2075	.1698
Min	.0189	.0189	.0189	.0189	.0189	.0189	.0189
Avg	.1107	.1115	.1069	.0672	.0780	.0715	.0605

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244126 / 33/11 KV KAVALAPUR

Feeder No / Name : 201 / 11 KV KAVALAPUR VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2402	.2263	.2926	.2829	.2715	.2641	.2561
2	.2058	.2263	.2957	.2641	.2715	.2452	.2561
3	.2452	.2075	.2957	.2641	.2715	.2452	.2561
4	.2452	.2263	.3696	.2641	.3292	.2452	.2957
5	.2801	.3018	.4024	.3018	.4435	.3206	.4066
6	.4108	.4715	.5121	.4338	.5175	.4715	.5228
7	.4755	.5228	.4805	.5601	.5304	.5041	.5041
8	.4207	.4481	.4668	.4294	.4344	.4251	.4207
9	.4207	.4207	.462	.3982	.362	.3801	.3982
10	.4161	.3658	.333	.3439	.3366	.3292	.3294
11	.3429	.3841	.3506	.2629	.298	.3109	.3222
12	.298	.3658	.2804	.2743		.2926	.2629
13	.2947	.2957	.3012	.2743		.2715	.2743
14	.2804	.2402	.2804	.2601	.2507	.2561	.2804
15	.2686	.2743	.2835	.2427	.2481	.3109	.2835
16	.2303	.2561	.2629	.298	.2126	.2378	.2427
17	.298	.3077	.3155	.3121	.3077	.3475	.2883
18	.443	.4572	.4075	.4607	.3982	.4557	.4334
19	.543	.567	.567	.5853	.4854	.5258	.5249
20	.499	.5121	.5175	.5304	.4359	.4854	.499
21	.462	.462	.4668	.4938	.4854	.4733	.5041
22	.4108	.4435	.3961	.4207	.415	.4294	.4108
23	.2801	.3734	.3174	.3109	.3395	.3658	.3361
24	.2587	.2614	.2926	.2829	.2743	.2641	.2587
Max	.543	.567	.567	.5853	.5304	.5258	.5249
Min	.2058	.2075	.2629	.2427	.2126	.2378	.2427
Avg	.3446	.3591	.3729	.3563	.3600	.3524	.3570

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244126 / 33/11 KV KAVALAPUR

Feeder No / Name : 202 / 11 kv tukai ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0716	.0701	.0924	.0671	.0732	.0678
2	.4191	.4167	.381	.0739	.0671	.0739	.0686
3	.4428	.4374	.381	.0747	.1006	.0747	.0686
4	.4481	.4374	.381	.0747	.064	.0747	.0686
5	.4687	.4744	.463	.0934	.064	.0934	.0857
6	.4902	.5376	.5401	.112	.08	.112	.1075
7	.6562	.7811	.6249	.1307	.0937	.1307	.112
8	.4531	.9922	.884	.1097	.0983	.1254	.0924
9	.6718	1.1248	.7968	.0905	.1097	.0701	.0693
10	.0526	.0335	.0886	.0857	.0724	.0701	.048
11	.0709	.0343	.0876	.8535	1.0082	.8436	.9217
12	.0701	.0339	.0514	.9907	.9061		.9804
13	.0686	.0347	.0701	1.1584	.9259	.4641	.8592
14	.0671	.0343	.0716	1.1092	.6249	.6562	.8436
15	.052	.0171	.0905	1.1561	.7562	.9105	.8592
16	.0509	.0343	.0693	1.0059	.5944	.9061	.8951
17	.0497	.0867	.0709	.9907	.6173	.8855	.8592
18	.0895	.1029	.0914	.9259	.6327	.6401	.7316
19	.1109	.1029	.132	.1029	.112	.1109	.0905
20	.1097	.1029	.132	.0867	.112	.1097	.0914
21	.1097	.104	.112	.0876	.112	.1109	.0924
22	.0914	.104	.112	.0867	.0934	.0914	.0732
23	.0886	.1075	.0924	.0693	.0924	.0838	.0543
24	.0693	.0701	.0886	.0914	.0514	.0732	.0625
Max	.6718	1.1248	.884	1.1584	1.0082	.9105	.9804
Min	.0497	.0171	.0514	.0693	.0514	.0701	.048
Avg	.2196	.2615	.2451	.4022	.3107	.2950	.3418

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244126 / 33/11 KV KAVALAPUR

Feeder No / Name : 203 / 11 KV KONDAKA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0895	.0724	.0876	.0905	.1075	.0934	.0924
2	.0905	.0739	.0781	.3269	.4572	.2559	.381
3	.0895	.0739	.0781	.3462	.4572	.2743	.381
4	.1097	.0747	.0781	.3506	.5401	.2743	.381
5	.1267	.112	.0937	.381	.6173	.3201	.4572
6	.1433	.1698	.108	.4214	.6944	.4012	.5556
7	.197	.168	.1235	.5864	.703	.6019	.6405
8	.1772	.1478	.1475	.8333	1.0059	.884	.823
9	.1772	.1595	.112	.9259	1.0822	1.0494	.9755
10	.1294	.12	.1267	.0678	.112	.104	.1402
11	.9907	1.0936	1.0936	.0905	.1294	.1227	.1086
12	1.0212	1.1405	1.1385	.1097	.1109	.1063	.1052
13	.9934	1.1385	1.1702	.0895	.0914	.0895	.1267
14	.9907	1.1405	1.1717	.1052	.0724	.0886	.1294
15	1.1405	.9105	1.1873	.0867	.0724	.1075	.1307
16	1.1265	1.0623	1.1111	.1029	.0554	.0886	.1307
17	1.0686	1.0957	1.0802	.104	.0914	.0895	.1294
18	.9259	1.0936	1.0185	.1402	.1267	.1402	.1629
19	.1494	.1772	.168	.1448	.1478	.168	.1663
20	.1294	.1402	.1494	.1254	.112	.1478	.1663
21	.1307	.1417	.1294	.1267	.112		.1478
22	.128	.1227	.128	.1075	.1132	.1294	.1109
23	.1097	.1227	.1097	.1075	.112	.1109	.0924
24	.1086	.0905	.104	.0895	.1075	.0924	.0934
Max	1.1405	1.1405	1.1873	.9259	1.0822	1.0494	.9755
Min	.0895	.0724	.0781	.0678	.0554	.0886	.0924
Avg	.4310	.4434	.4497	.2442	.3013	.2496	.2762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 246001 / 110/33/11 KV VISHRAMBAG S/SN

Feeder No / Name : 210 / 11 KV Dhamni

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
23	.7362	.7362	.8322	.724	.6447	.7362	.6588
24	.924	.7011	.7011		.7316	.905	.7522
Max	.924	.7362	.8322	.724	.7316	.905	.7522
Min	.7362	.7011	.7011	.724	.6447	.7362	.6588
Avg	.8301	.7187	.7667	.724	.6882	.8206	.7055

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 246001 / 110/33/11 KV VISHRAMBAG S/SN

Feeder No / Name : 401 / 33KV KASABE DIGRAJ

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-DEC-17
HR	Load (MW)
10	5.3778
Max	5.3778
Min	5.3778
Avg	5.3778

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 246001 / 110/33/11 KV VISHRAMBAG S/SN

Feeder No / Name : 402 / 33KV SANGLI CITY -OLD

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-DEC-17
HR	Load (MW)
24	.0514
Max	.0514
Min	.0514
Avg	.0514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 246001 / 110/33/11 KV VISHRAMBAG S/SN

Feeder No / Name : 405 / 33KV SANGLI CITY -NEW

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-DEC-17
HR	Load (MW)
24	.0514
Max	.0514
Min	.0514
Avg	.0514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244080 / 33/11KV RISALA ROAD

Feeder No / Name : 201 / 11KV GYMKHANA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4908	.4961	.5068	.5373	.5792	.5316	.5316
2	.5014	.4607	.394	.543	.5853	.5316	.5014
3	.5014	.4656	.4298	.5487	.5487	.5138	.5068
4	.4706	.4656	.4656	.5121	.5544	.5138	.5068
5	.4706	.5373	.5014	.5121	.5914	.5138	.5121
6	.5121	.6024	.5373	.5544	.6219	.6024	.5487
7	.5487	.5914	.5373	.5914	.6584	.6089	.5914
8	.6154	.6219	.6154	.6219	.6516	.6447	.6584
9	.6516	.6516	.5853		.6516	.6984	.6516
10	.6379	.631	.6626	.7316	.6805	.724	.7087
11	.6805	.6733	.6219	.7164	.7522	.7087	.7087
12	.6805	.7087	.6335	.6733	.6805	.7087	.7087
13	.6447	.7087	.5792	.6805	.6733	.6447	.7164
14	.6447	.6878	.5792	.6805		.6447	.7164
15	.6447	.6447	.6089	.6447		.6379	.6878
16	.6805	.631	.5316	.6805	.7362	.6379	.6516
17	.7087	.6556	.5792	.7011	.7701	.7087	.6697
18	.9816	1.0029	.8413	1.0402	.9745	.9945	.9492
19	1.0631	1.0387	.8764	1.1568	1.0208	1.0277	1.0745
20	.9922	1.0317	.9114	1.0631	1.0387	.9922	1.0029
21	.9114	.905	.8063	.8764	.8859	.9114	.8596
22	.7011	.7602	.7362	.6935	.7619	.7712	.7522
23	.5609	.5731	.6024	.6516	.6556	.6379	.6024
24	.5201	.4961	.5194	.5731	.6154	.5552	.567
Max	1.0631	1.0387	.9114	1.1568	1.0387	1.0277	1.0745
Min	.4706	.4607	.394	.5121	.5487	.5138	.5014
Avg	.6590	.6684	.6109	.6950	.7131	.6860	.6827

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244080 / 33/11KV RISALA ROAD

Feeder No / Name : 202 / 11KV RAJWADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4961	.5316	.5611	.6379	.5487	.4477	.5792
2	.5014	.5014	.3982	.6024	.5487	.4252	.5853
3	.4656	.5014	.4298	.6089	.5175	.4298	.5487
4	.4706	.4961	.4656	.6089	.5175	.4075	.5487
5	.4755	.6024	.5373	.6154	.5175	.4075	.5175
6	.5121	.7011	.7522	.6516	.5601	.5552	.5175
7	.5175	.6653	.6805	.724	.5601	.5014	.5601
8	.5853	.6878	.724	.6878	.5175	.4656	.5544
9	.5792	.724	.724		.5487	.5373	.5068
10	.5792	.7888	.7282	.5792	.543	.5792	.567
11	.6219	.8063	.6805	.6379	.2896	.6733	.567
12	.6447	.8505	.7164	.7011		.567	.6024
13	.6733	.8238	.6626	.6379			.5792
14	.6805	.788	.6626	.6516			.567
15	.6516	.788	.5373	.5853		.6241	.5731
16	.6805	.7712	.6379	.5853	.7712	.631	.5731
17	.7087	.7888			.7442	.6661	.7701
18	.9114	.8954	.8413	.9816	.8939	.8573	.7783
19	1.0745	.9671	.8764	1.0517	.8413	.8238	.8775
20	1.0029	.905	.8505	.8505	.7973	.8596	.788
21	.7796	.7964	.8413	.7796	.7265	.6878	.6626
22	.7087	.724	.815	.6733	.6733	.6154	.6089
23	.631	.6447	.6661	.6154	.591	.6516	.543
24	.4961	.5316	.5731	.6379	.5792	.4477	.6154
Max	1.0745	.9671	.8764	1.0517	.8939	.8596	.8775
Min	.4656	.4961	.3982	.5792	.2896	.4075	.5068
Avg	.6437	.7200	.6679	.6866	.6143	.5846	.6080

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244080 / 33/11KV RISALA ROAD

Feeder No / Name : 203 / 11KV VAKHARBAG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4908	.4961	.5068	.5609	.5014	.5552	.567
2	.4557	.4557	.4525	.5373	.5014	.5373	.5316
3	.4656	.4557	.4477	.543	.4706	.5373	.5014
4	.4656	.4557	.4835	.5068	.4755	.5249	.5121
5	.4706	.4854	.5014	.5121	.4755	.5068	.5121
6	.4755	.5548	.5373	.5121	.5175	.5249	.5121
7	.5121	.5228	.4835	.5544	.5175	.5731	.5175
8	.543	.5914	.4887	.5544	.5121	.6089	.543
9	.6154	.5609	.5544		.5853	.6089	.5731
10	.6584	.567	.5973	.5792	.6516	.6516	.6379
11	.7023	.7087	.6535	.7316	.5731	.724	.7796
12	.724	.7602	.7023	.7712	.6878	.788	.8505
13	.7964	.788	.7577	.788	.788	.7796	.7796
14	.7964	.7964	.695	.788		.7712	.7442
15	.8048	.7164	.4706	.7964		.7796	.7522
16	.8326	.6805	.6733	.7964	.8322	.7011	.7164
17	.8688	.788	.7682	.8954	.9015	.8063	.8326
18	.9313	1.0498	1.0631	1.0631	1.0341	1.0288	1.0317
19	1.0029	1.0679	1.0387	1.134	1.0136	1.0166	.7164
20	.9313	.8596	.9568	.9114	.9922	.9709	.9671
21	.8505	.905	.9922	.7975	.8682	.9015	.8326
22	.6935	.7522	.7362	.6859	.788	.6935	.7522
23	.5548	.6447	.6588	.5853	.6268	.6588	.631
24	.5201	.4961	.543	.5959	.543	.5552	.5609
Max	1.0029	1.0679	1.0631	1.134	1.0341	1.0288	1.0317
Min	.4557	.4557	.4477	.5068	.4706	.5068	.5014
Avg	.6734	.6733	.6568	.7044	.6753	.7002	.6815

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244122 / 33/11 KV BALAJI MANDIR

Feeder No / Name : 201 / 11 KV Balaji Mill Road

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4694	.3704	.421	.3688	.4012	.4527	.4748
2	.421	.3549	.3953	.3681	.3658	.4527	.4641
3	.4049	.3353	.3953	.3841	.3658	.4641	.4475
4	.4049	.3353	.3906	.3795	.3658	.4428	.427
5	.4111	.3567	.3749	.4321	.3763	.4586	.4268
6	.4111	.3715	.3658	.4694	.4012	.4531	.4268
7	.421	.4167	.3749	.4062	.4481	.5506	.4744
8	.3906	.4321	.3906	.421	.4475	.4641	.5426
9	.4858	.567	.4752	.4527	.421	.5611	.5493
10	.5144	.6401	.6001	.5258	.4973	.6838	.6468
11	.5304	.5487	.6535	.5083	.4508	.6584	.7468
12	.543	.567	.6348	.4961	.4961	.695	.6838
13	.5731	.591	.5138	.4784	.4784	.695	.6767
14	.5373	.5493	.6089	.5249	.4458	.7316	.6089
15	.6036	.6908	.6268	.543	.4458	.7133	.6024
16	.6036	.6468	.4694	.5014	.4527	.7133	.5847
17	.6099	.5914	.4801	.5249	.4973	.5895	.5316
18	.6584	.679	.6036	.6219	.5144	.6401	.5138
19	.5544	.6401	.5792	.5373	.5375	.5731	.5611
20	.5552	.5792	.5731	.5258	.591	.5316	.5611
21	.5792	.5792	.5316	.567	.6089	.6653	.5373
22	.5316	.5792	.5373	.5201	.6268	.6653	.5493
23	.4748	.5373	.4908	.4862	.567	.591	.5138
24	.4862	.3953	.4372	.3978	.4167	.4748	.5201
Max	.6584	.6908	.6535	.6219	.6268	.7316	.7468
Min	.3906	.3353	.3658	.3681	.3658	.4428	.4268
Avg	.5073	.5148	.4968	.4767	.4675	.5800	.5446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244122 / 33/11 KV BALAJI MANDIR

Feeder No / Name : 202 / 11 KV Circuit House

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1132	.1132	.132	.1132	.1132	.1132
2	.0943	.0943	.0943	.1132	.0943	.1132	.1132
3	.0943	.0943	.0943	.1132	.0943	.1132	.0943
4	.0943	.0943	.0943	.1132	.0943	.1132	.0943
5	.1132	.1132	.1132	.132	.1132	.132	.1132
6	.132	.1509	.132	.1509	.1509	.1509	.1698
7	.1509	.2075	.1509	.1886	.2075	.1886	.1886
8	.1698	.2075	.132	.1886	.2075	.1886	.2075
9	.1509	.1132	.1509	.2075	.1886	.1886	.1698
10	.132	.1509	.1509	.1509	.1509	.1886	.132
11	.1132	.1132	.1509	.1509	.1509	.1698	.1132
12	.0934	.0943	.1509	.1132	.1509	.1886	.132
13	.0924	.132	.1132	.1132	.1698	.1132	.0943
14	.0934	.132	.1509	.1698	.1509	.1698	.132
15	.1509	.0943	.1509	.1509	.132	.1886	.1132
16	.1509	.1509	.1509	.1509	.1509	.1509	.1132
17	.1509	.132	.1886	.1698	.1886	.1372	.1509
18	.2075	.2263	.2241	.2075	.2263	.2218	.1886
19	.2427	.2263	.2263	.2427	.2263	.2452	.2075
20	.2452	.2263	.2263	.2452	.2263	.2263	.2263
21	.2263	.2263	.2263	.2075	.2263	.2075	.2263
22	.1886	.2075	.2075	.1886	.2075	.2075	.2075
23	.1698	.1509	.1886	.1698	.1698	.1698	.1509
24	.1132	.1132	.1132	.132	.1132	.132	.1132
Max	.2452	.2263	.2263	.2452	.2263	.2452	.2263
Min	.0924	.0943	.0943	.1132	.0943	.1132	.0943
Avg	.1451	.1485	.1539	.1626	.1627	.1674	.1485

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244122 / 33/11 KV BALAJI MANDIR

Feeder No / Name : 203 / 11 KV Timber Area

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2452	.2641	.2641	.2829	.2641	.2641	.2641
2	.2263	.2263	.2452	.2641	.2452	.2452	.2452
3	.2263	.2263	.2263	.2452	.2452	.2263	.2263
4	.2263	.2263	.2263	.2452	.2452	.2263	.2263
5	.2263	.2641	.2263	.2452	.2641	.2452	.2641
6	.2452	.3018	.2452	.2452	.2829	.2641	.3018
7	.2452	.2896	.2641	.2957	.3206	.2957	.3018
8	.3018	.3174	.3018	.3077	.2743	.3077	.3395
9	.3395	.3772	.3395	.3772	.3174	.3772	.3584
10	.3395	.3961	.3584	.3395	.3018	.3584	.3772
11	.3206	.415	.3395	.3772	.2641	.3961	.3961
12	.3077	.3395	.3395	.3772	.2452	.3584	.3772
13	.2865	.3206	.2481	.3206	.2641	.3395	.2804
14	.216	.3395	.2267	.2829	.2263	.3018	.2658
15	.3772	.3206	.2743	.3395	.2263		.3772
16	.3395	.3018	.2641	.3772	.2641		.3584
17	.3395	.3206	.3395	.3961	.2452		.3584
18	.5093	.3961	.3961	.4527	.3772	.6154	.4715
19	.4668	.415	.3961	.4527	.3961	.5415	.4715
20	.415	.3961	.3772	.415	.415	.4668	.415
21	.3961	.3772	.3584	.3961	.3772	.3961	.3772
22	.3584	.3018	.3018	.3584	.3584	.3395	.3395
23	.3018	.2452	.3018	.3206	.3018	.3018	.3206
24	.2641	.2829	.2641		.2829	.2641	.2641
Max	.5093	.415	.3961	.4527	.415	.6154	.4715
Min	.216	.2263	.2263	.2452	.2263	.2263	.2263
Avg	.3133	.3192	.2969	.3354	.2919	.3396	.3324

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244019 / 33/11 KV MADHAVNAGAR

Feeder No / Name : 201 / 11 KV MADHAVNAGAR FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4338	.4715	.4904	.4527	.415	.3395	.4527
2	.415	.4527	.5093	.415	.415	.3584	.415
3	.415	.4527	.4904	.3961	.4338	.3772	.3961
4	.415	.4715	.4904	.3772	.4527	.3961	.3772
5	.4338	.4527	.5093	.4527	.4904	.3961	.3961
6	.4715	.4527	.547	.547	.5281	.415	.547
7	.5093	.5281	.5658	.679	.5658	.4338	.5847
8	.4904	.547	.6413	.5281	.5093	.4715	.6036
9	.6979	.6413	.7356		.4715	.5658	.6602
10	.7922	.7545	.7545	.6036	.4527	.6602	.7167
11	.8299	.6602	.7545	.7167	.4715	.7545	.7545
12	.7545	.5847	.6036	.7356	.4527	.6413	.6602
13	.6401	.547	.6036	.6413	.4338	.6413	.5093
14	.6219	.6224	.6602	.6602	.4338	.7167	.6036
15	.6516	.6979	.7167	.6224	.415	.7356	.6979
16	.7701	.7167	.7356	.7545	.415	.811	.7167
17	.7356	.8131	.6413	.8488	.4527	.9242	.7733
18	.9431	.9492	.8299	.9431	.6036	.9465	.8299
19	.9242	.9511	.8488	.8488	.6413	.8505	.8676
20	.8299	.8029	.7356	.8488	.6036	.788	.7733
21	.7356	.7468	.6413	.7545	.5847	.7421	.679
22	.6413	.6348	.6602	.6602	.5281	.6653	.6036
23	.5658	.5601	.5658	.5847	.415	.5975	.547
24	.4338	.4715	.4668	.5093	.5093	.3584	.5093
Max	.9431	.9511	.8488	.9431	.6413	.9465	.8676
Min	.415	.4527	.4668	.3772	.415	.3395	.3772
Avg	.6313	.6243	.6332	.6339	.4873	.6078	.6114

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244019 / 33/11 KV MADHAVNAGAR

Feeder No / Name : 203 / 11 KV INDOTEX

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8149	.823	.8865	.9054	.8328	.8865	.9431
2	.8149	.823	.9242	.9242	.7973	.8865	.9431
3	.8149	.8402	.8865	.9242	.8059	.9054	.9431
4	.8322	.823	.9054	.9054	.788	.9054	.9242
5	.8322	.8402	.8865	.9054	.788	.8865	.9242
6	.8495	.8402	.9242	.9054	.788	.9054	.9242
7	.8669	.8573	.9242	.8865	.7964	.9054	.9242
8	.8322	.8573	.9242	.8676	.0187	.9431	.9242
9	.9242	.8669	.9054		.0377	.8962	.9242
10	.9242	.8669	.8589	.8328	.0377	.9242	.9054
11	.9054	.8669	.8589	.8238	.0377	.9242	.9242
12	.9054	.8669	.8413	.8238	.0377	.9242	.9242
13	.9054	.8495	.823	.7888	.0377	.9054	.9054
14	.9242	.8322	.823	.7362	.0377	.9054	.9054
15	.9242	.8322	.8402	.6836	.0377	.9431	.9054
16	.9431	.8495	.8402	.8413	.0189	.905	.9242
17	.823	.9054	.8402	.8413	.0377	.9431	.9242
18	.823	.8865	.8402	.8413	.0377	.9431	.9242
19	.8059	.9431	.7888	.8589	.7922	.9431	.9242
20	.8059	.9054	.7888	.8589	.8488	.9431	.9242
21	.823	.8865	.8059	.8413	.8676	.9431	.9242
22	.823	.9242	.8865	.8238	.8676	.9242	.9054
23	.8059	.9431	.8676	.8238	.8676	.9054	.9054
24	.8149	.823	.8865	.9242	.8589	.8865	.8865
Max	.9431	.9431	.9242	.9242	.8676	.9431	.9431
Min	.8059	.823	.7888	.6836	.0187	.8865	.8865
Avg	.8558	.8647	.8649	.8508	.4615	.9160	.9203

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244019 / 33/11 KV MADHAVNAGAR

Feeder No / Name : 205 / 11 KV COTTON MILL FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8676	.8488	.7545	.9242	.9054	.7922	.8865
2	.8676	.8488	.7356	.9242	.8488	.811	.9242
3	.8413	.8299	.7356	.9054	.7545	.8299	.9997
4	.8676	.8488	.7356	.9054	.695	.8488	.9431
5	.8865	.8676	.7356	.8865	.6602	.8488	.9242
6	.8865	.8676	.7922	.8865	.6602	.8676	.9242
7	.8865	.9242	.8676	.9619	.6602	.8676	.9431
8	.9242	.8865	.9242	.9808	.6036	.8676	.9431
9	.9997	.9431	1.0185		.5658	.9431	1.0562
10	1.358	1.4146	1.1317	1.1888	.5658	1.0562	1.1317
11	1.4901	1.3957	1.2071	1.3203	.547	1.094	1.2449
12	1.358	1.3769	1.1317	1.358	.5093	.9619	1.2826
13	1.1694	1.358	1.0562	1.2637	.5093	.9619	1.3203
14	1.1506	1.2449	1.0562	1.0974	.5093	.9997	1.2637
15	1.1317	1.094	1.094	1.0374	.4904	1.0185	1.1128
16	1.1317	1.2826	1.094	1.226	.5281	1.0562	1.4146
17	1.1317	1.1128	1.1694	1.2449	.5281	1.0374	1.3203
18	1.0374	1.0374	1.0562	1.2826	.547	1.0185	1.1883
19	.9619	1.0185	.9997	1.0374	.7545	.9997	1.094
20	.9431	.8865	.9619	.9054	.7733	.9619	.9808
21	.9431	.8488	.9054	.8865	.8299	.9242	.9431
22	.9054	.8676	.8676	.9054	.8299	.9242	.9054
23	.8865	.9242	.9054	.9431	.811	.9054	.9054
24	.8676	.8488	.8865	.8865	.8865	.8488	.9054
Max	1.4901	1.4146	1.2071	1.358	.9054	1.094	1.4146
Min	.8413	.8299	.7356	.8865	.4904	.7922	.8865
Avg	1.0206	1.0240	.9509	1.0417	.6655	.9352	1.0649

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244019 / 33/11 KV MADHAVNAGAR

Feeder No / Name : 208 / 11 KV SIE Ag FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.3658	.3395	.3241	.132	.0754	.0943
2	.0943	.381	.3241	.3241	.132	.0754	.0943
3	.0943	.3963	.3086	.3086	.1132	.0943	.0943
4	.0943	.3963	.2932	.3086	.1132	.1132	.0943
5	.1132	.4115	.2932	.3086	.1132	.1132	.1132
6	.132	.4268	.4012	.3658	.132	.1132	.1132
7	.1509	.1132	.132	.1698	.132	.1132	.1132
8	.1132	.0943	.1132	.5182	.4588	.381	.3704
9	.1509	.0943	.1132		.6249	.4572	.5556
10	.1509	.1132	.1132	.6226	.6327	.5468	.6859
11	.1509	.0943	.1132	.6554	.6874	.6249	.6859
12	.1132	.0943	.1132	.7045	.679	.5468	.6554
13	.0943	.0754	.0754	.7209	.6401	.5312	.6249
14	.0943	.0943	.0943	.7373	.6097	.5937	.6562
15	.0943	.0943	.0754	.6882	.5487	.6093	.7186
16	.0943	.1132	.0943	.1132	.0754	.0943	.0754
17	.0754	.1132	.0754	.132	.1132		
18	.1132	.132	.132	.1509	.1132		
19	.1509	.1698	.1509	.1698	.132	.1698	
20	.1509	.1509	.1509	.1886	.132	.1698	
21	.1509	.1509	.1509	.1698	.132	.1509	
22	.132	.1132	.1509	.132	.1132	.132	
23	.3658	.3704	.3395	.1509	.0754	.1132	
24	.0754	.3658		.3241		.0754	.0943
Max	.3658	.4268	.4012	.7373	.6874	.6249	.7186
Min	.0754	.0754	.0754	.1132	.0754	.0754	.0754
Avg	.1261	.2052	.1803	.3603	.2885	.2679	.3435

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 201 / 11 KV OM COLD

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.452	2.2822	2.2068	2.0748	2.1125	1.2637	2.1125
2	2.452	2.3011	2.1879	2.0748	2.0748	1.2826	2.037
3		2.2634	2.1879	2.1125	2.037	1.2826	1.8861
4		2.2822	2.1879	2.1125	1.9616	1.2637	1.8484
5		2.3011	2.2068	2.0748	1.9993	1.2637	1.8484
6		2.2822	2.2257	2.1125	1.9239	1.2826	1.8861
7		2.2634	2.2634	2.2068	1.7541	1.3203	1.9616
8		2.0748	2.2068	2.0182	1.358	1.3769	2.0559
9		2.2257	2.452	2.3954	1.226	2.1502	2.2634
10		2.6595	2.8669	2.7915	1.2826	2.452	2.6783
11		2.8669	2.9424	2.7349		2.6972	2.8669
12		3.0178	2.8104	2.8669		2.7349	2.9047
13		2.6217	2.5274	2.5652		2.4331	2.7349
14		2.8104	2.6029	2.6595		2.8292	2.8292
15		2.8292	2.6217	2.452		2.9613	2.8858
16		3.0178	2.7538	2.4331		2.9047	2.8292
17	2.7726	2.9235	2.6406	2.584	1.2826		2.6595
18	2.6972	2.6783	2.3388	2.4709	1.2826		2.6406
19	2.6029	2.3577	2.32	2.452	1.2449		2.6595
20	2.3388	2.2068	2.2634	2.3011	1.2637		2.32
21	2.3011	2.2257	2.0182	2.1502			2.3011
22	2.32	2.2822	2.0748	2.1879			2.3388
23	2.3011	2.1313	2.1125	2.1502			
24	2.4143	2.32	2.2445	2.0936	2.1502	1.2826	2.1125
Max	2.7726	3.0178	2.9424	2.8669	2.1502	2.9613	2.9047
Min	2.3011	2.0748	2.0182	2.0182	1.226	1.2637	1.8484
Avg	2.4652	2.4677	2.3860	2.3365	1.6636	1.9283	2.3765

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 202 / 11 KV KVC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3769	1.358	1.3203	1.2071	1.1317	.9997	1.1317
2	1.3957	1.3769	1.3203	1.1694	1.094	.9808	1.094
3		1.3769	1.3203	1.1694	1.0562	1.0185	1.0751
4		1.3957	1.3203	1.1694	1.0185	.9808	1.0751
5		1.3957	1.3014	1.1506	1.0751	.9619	1.094
6		1.4146	1.2637	1.1883	1.1128	1.0185	1.1128
7		1.4146	1.4901	1.3203	1.1317	1.0751	1.2071
8		1.2826	1.3957	1.2071	.9808	1.2071	1.358
9		1.6975	1.7164	1.4523	.9431	1.3769	1.5089
10		1.773	2.0182	1.8673	.9997	1.5844	1.5655
11		1.9427	2.0182	1.8484	.9431	1.9239	1.9993
12		1.9616	1.9616	1.9427	.9808	1.9805	2.0182
13		1.7353	1.8484	1.905	1.0185	1.7353	1.7541
14		1.7918	1.9805	1.905	1.0374	1.9616	2.0559
15		1.773	2.3011	1.9239	.9997	1.9805	2.2257
16		2.0182	2.0748	1.9427	1.094	2.1313	2.1313
17	1.8296	1.905	2.1125	2.037	1.1128		2.0748
18	2.0559	1.8861	2.0748	1.8107	1.1317		2.1879
19	1.9239	1.6975	1.6787	1.5466	1.1506		1.7541
20	1.6975	1.3392	1.5844	1.2071	.9997		1.3392
21	1.5844	1.3957	1.2637	1.1128			1.3014
22	1.4523	1.4901	1.2826	1.1317			1.2637
23	1.3392	1.3014	1.3203	1.1506			
24	1.3957	1.358	1.3203	1.2449	1.1694	1.0185	1.1694
Max	2.0559	2.0182	2.3011	2.037	1.1694	2.1313	2.2257
Min	1.3392	1.2826	1.2637	1.1128	.9431	.9619	1.0751
Avg	1.6051	1.5867	1.6370	1.4838	1.0563	1.4080	1.5434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 203 / 11 KV DIAMOND

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4146	1.4146	1.358	1.358	1.358	1.1883	1.3203
2	1.4712	1.4335	1.358	1.3957	1.3203	1.1317	1.2826
3		1.4523	1.358	1.3957	1.2826	1.0751	1.2071
4		1.4712	1.358	1.3957	1.2449	1.0185	1.2071
5		1.4901	1.3203	1.4146	1.2826	.9619	1.1694
6		1.5089	1.3014	1.4335	1.3957	.9054	1.2071
7		1.5278	1.5655	1.5089	.8676	1.1506	1.2826
8		.8299	1.3957	1.3957	.7167	.7167	1.358
9		1.5278	1.5466	1.1317	.3772	1.2826	1.358
10		1.6409	1.6221	1.226	.2641	1.6598	1.6409
11		1.5655	1.1694	1.6032	.2641	1.6221	.9997
12		1.4901	1.6032	1.1317	.2263	1.1128	1.0751
13		.9997	1.5089	1.4712	.2075	1.5466	1.0374
14		1.5089	1.5655	1.0374		1.6221	1.6032
15		1.5466	1.5844	1.2449		1.6787	1.6975
16		1.4901	1.6221	1.4335		1.6032	1.6032
17	1.5278	1.4712	1.5466	1.5466	.2263		1.7164
18	1.0374	1.6221	1.094	1.5278	.2452		1.6598
19	1.5466	1.6221	1.4901	1.358	.2452		1.6409
20	1.4335	1.3957	1.4523	1.358	.3206		1.3957
21	1.4146	1.4146	1.358	.7733			1.4901
22	1.3769	1.4712	1.2826	1.2826			1.5466
23	1.3392	1.5278	1.0751	1.358			
24	1.3957	1.3957	1.4335	.9431	1.3203	1.2449	1.3203
Max	1.5466	1.6409	1.6221	1.6032	1.3957	1.6787	1.7164
Min	1.0374	.8299	1.0751	.7733	.2075	.7167	.9997
Avg	1.3958	1.4508	1.4154	1.3219	.7314	1.2659	1.3834

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 204 / 11KV NATRAJ

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9997	1.0374	1.0562	1.0374	1.1317		1.1694
2	.9619	1.0562	1.0374	1.0185	1.0562	1.0562	
3		1.0751	1.0374	1.0185	1.0185	1.0751	1.0185
4		1.094	1.0374	1.0374	.9808	1.094	1.0185
5		1.1128	1.0562	1.094	1.0185	1.1128	.9808
6		1.1317	1.0751	1.1694	.9808	1.1317	.9808
7			1.2826	1.2449	1.0185	1.094	1.1317
8		1.1694	1.2637	1.3769	.9808	1.2826	1.358
9		1.5466	1.4335	1.5844	.8488	1.5466	1.6221
10		1.905	1.7918	1.9239	.8865	1.8861	1.9427
11		1.4146	1.6409	2.1313	.9242	1.7541	1.9805
12		2.2257	1.7353	1.9616	.9431	2.037	2.0748
13		1.6221	1.358	1.7353	.9619	1.5655	1.9616
14		1.8861	1.5655	2.037	.9242	2.0748	2.3577
15		1.905	1.8673	1.9616	.9054	2.1879	2.4331
16		1.8673	1.6975	1.8861	.2452	2.2634	2.2822
17	2.1125	1.905	1.7353	1.6975	.5658		2.452
18	1.6032	1.7353	1.6787	1.3957	.9242		1.5655
19	1.5278	1.6221	1.358	1.226	.9808		1.4523
20	1.2637	1.094	1.3203	1.226	1.0374		1.4146
21	1.2071	1.094	1.1128	1.1317			1.1506
22	1.1317	1.0751	1.1694	1.1694			1.0185
23	1.0751	1.0751	1.3014	1.1317			
24	1.0185	1.0374	1.0562	1.0562	1.1506		1.1883
Max	2.1125	2.2257	1.8673	2.1313	1.1506	2.2634	2.452
Min	.9619	1.0374	1.0374	1.0185	.2452	1.0562	.9808
Avg	1.2901	1.4212	1.3612	1.4272	.9278	1.5441	1.5706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 205 / 11 KV OMKAR

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7353	1.6598	1.4901	1.3957	1.6598	.7356	1.6975
2	1.6598	1.6032	1.4712	1.3957	1.6975	.7545	1.6221
3		1.5278	1.4712	1.3957	1.5844	.7922	1.5089
4		1.4901	1.4523	1.3769	1.5089	.811	1.4712
5		1.4523	1.4523	1.3203	1.6032	.8299	1.3957
6		1.3957	1.4712	1.226	1.4523	.8488	1.3957
7		1.3392	1.8673	1.4901	.6036	.811	1.358
8		1.7918	1.358	1.6598	.5658	1.0562	1.4712
9		1.7353	1.5844	1.7164	.5847	1.5089	1.6221
10		1.6787	1.6598	1.7918	.6036	1.6221	1.9993
11		1.4146	1.6598	1.8861	.5658	1.4335	1.2826
12		1.3769	2.0559	1.8296	.547	.9054	1.9427
13		1.905	1.9616	2.2257	.5847	2.1125	2.037
14		1.8861	1.8107	1.3014	.4715	1.8861	1.9805
15		2.1313	1.0562	1.5655	.3772	1.8673	2.037
16		2.32	2.0748	1.7353	.5847	1.773	1.5655
17	2.1879	1.4146	1.9993	1.6221	.5847		1.6787
18	.7733	1.3957	1.4146	1.9427	.6036		1.9239
19	1.8861	1.6787	1.9427	1.5466	.6224		1.9239
20	1.1128	1.4712	1.8296	1.6598	.4904		1.905
21	1.094	1.6221	1.7353	1.1317			1.3769
22	1.094	2.0182	1.5466	1.5089			.7356
23	1.0562	1.6032	1.358	1.6032			
24	1.8484	1.6975	1.5089	1.4146	1.226	.7167	1.7353
Max	2.1879	2.32	2.0748	2.2257	1.6975	2.1125	2.037
Min	.7733	1.3392	1.0562	1.1317	.3772	.7167	.7356
Avg	1.4448	1.6504	1.6347	1.5726	.8820	1.2038	1.6377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 206 / 11 kv Adimaya

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.094	1.094	1.1506	1.1128	1.1317	.9242	1.0562
2	1.094	1.1317	1.1506	1.1317	1.0562	.9054	1.0185
3		1.1694	1.1506	1.1317	1.0185	.9242	.9808
4		1.2071	1.1694	1.1317	.9808	.9054	.9808
5		1.2449	1.226	1.1694	.9997	.9242	.9808
6		1.2637	1.2071	1.2071	.9242	.9054	1.0185
7		1.3014	1.2826	1.0751		.9808	1.094
8		1.2637	1.3014	.9431	.7733	.9431	1.1317
9		1.5466	1.358	1.358		1.226	1.3203
10		1.6032	1.5655	1.773		1.4335	1.7353
11		1.9239	1.6032	1.7164		1.6598	1.5844
12		1.8107	1.5655	1.773		1.6409	1.5655
13		1.5655	1.4523	1.4901		1.6221	1.3392
14		1.5655	1.6221	1.6221		1.7353	1.4712
15		1.7164	1.7918	1.7541		1.7541	1.8484
16		1.5089	1.7164	1.9616		1.5844	1.8484
17	1.6787	1.7353	1.6221	1.6221	.7545		1.6598
18	1.3769	1.4901	1.4523	1.7164	.7545		1.5655
19	1.4901	1.4712	1.1317	1.358	.7356		1.226
20	1.2637	1.2071	1.094	1.3014	.7545		1.1506
21	1.226	1.1883	1.0374	1.0751			1.1317
22	1.1883	1.1883	1.1317	1.094			1.1317
23	1.1317	1.1317	1.1694	1.0751			
24	1.1317	1.0562	1.1694	1.094	1.0562	.9242	1.0185
Max	1.6787	1.9239	1.7918	1.9616	1.1317	1.7541	1.8484
Min	1.094	1.0562	1.0374	.9431	.7356	.9054	.9808
Avg	1.2675	1.3910	1.3384	1.3620	.9116	1.2349	1.2982

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 207 / 11 kv mandhana

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3769	1.1883	1.3014	1.1694	1.358	.9619	1.1694
2	1.3203	1.226	1.2826	1.1694	1.3203	.9431	1.1317
3		1.2637	1.2826	1.1694	1.2449	.9619	1.1317
4		1.2826	1.2826	1.1694	1.2071	.9619	1.094
5		1.3014	1.2826	1.1506	1.2637	.9808	1.094
6		1.3203	1.2637	1.1317	1.1317	.9808	1.1317
7		1.3392	1.4146	1.1506	.9619	.8865	1.2826
8		1.0751	1.2826	1.2449	.8488	.9619	1.3203
9		1.3769	1.4712	1.4901	.5658	1.2637	1.6221
10		1.5278	1.7353	1.8484	.4715	1.5278	1.773
11		1.5466	1.9616	1.8107	.7545	1.6598	1.4523
12		1.7353	1.7541	1.773	.9242	1.6032	1.5655
13		1.4712	1.4712	1.3014	.9431	1.358	1.4523
14		1.6975	1.7353	1.5844	.9619	1.7353	1.5655
15		1.8296	1.8296	1.5089	.9431	1.7541	1.6221
16		1.6787	1.7164	1.4335	.8865	1.8673	1.7164
17	1.2826	1.3957	1.6598	1.7353	.9054		1.7353
18	1.3203	1.6221	1.6221	1.6598	.9054		1.6787
19	1.4335	1.4901	1.358	1.6032			1.3392
20	1.3014	1.3203	1.3957	1.5089	.8865		1.4523
21	1.3203	1.358	1.4901	1.4523			1.3957
22	1.358	1.3957	1.5089	1.358			1.3203
23	1.358	1.3957	1.5466	1.1317			
24	1.3957	1.1694	1.3203	1.2449	1.3769	.9242	1.2637
Max	1.4335	1.8296	1.9616	1.8484	1.3769	1.8673	1.773
Min	1.2826	1.0751	1.2637	1.1317	.4715	.8865	1.094
Avg	1.3467	1.4170	1.4987	1.4083	.9931	1.2548	1.4048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 208 / 11 KV Devika

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1698	.1509	.1509	.1509	.1886	.1509
2	.1509	.1698	.1509	.1509	.1509	.1886	.1509
3		.1698	.1509	.1509	.1509	.1886	.1509
4		.1698	.1509	.1509	.1509	.1886	.1509
5		.1698	.1509	.1509	.1509	.1886	.1509
6		.1698	.1509	.1509	.1698	.1886	.1698
7		.1698	.1698	.1509	.1698	.1886	.1698
8		.2075	.1698	.1698	.1698	.1886	.1698
9		.2263	.2263	.1886	.1698	.1886	.1886
10		.2263	.3018	.2075	.1698	.1886	.1886
11		.3018	.3018	.2263	1.1317	.2641	.1886
12		.2452	.2641	.2075	1.2826	.2263	.1886
13		.2263	.2452	.1886	1.3203	.2452	.2075
14		.2263	.2641	.2075	1.358	.2452	.2075
15		.2452	.3018	.2075	1.3957	.2829	.1886
16		.2263	.2641	.2075	1.358	.2641	.1886
17	.2641	.1886	.2263	.2075	.1886		.2075
18	.2263	.1886	.2075	.1886	.1886		.1886
19	.2452	.1886	.1698	.1509	.1886		.1886
20	.1886	.1698	.1698	.1509	.1886		.1698
21	.1886	.1698	.1698	.1509			.1698
22	.1698	.1509	.1698	.1509			.1698
23	.1698	.1509	.1698	.1509			
24	.1509	.1698	.1509	.1698	.1509	.1886	.1509
Max	.2641	.3018	.3018	.2263	1.3957	.2829	.2075
Min	.1509	.1509	.1509	.1509	.1509	.1886	.1509
Avg	.1905	.1957	.2020	.1745	.4931	.2119	.1763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 402 / 33 KV Shah Presicast Unit NON SHEDDABLE EXPRESS HV FEEDERS
 III Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2263	.2263	.2263	.2377	.2999	.2263
2	.2263	.2263	.2263	.2263	.2263	.2999	.2263
3		.2263	.2263	.2263	.2263	.2999	.2263
4		.2263	.2263	.2263	.2263	.2999	.2263
5		.2263	.2263	.2263	.2263	.2999	.2263
6		.2263	.2263	.2263	.2263	.2999	.2263
7		.2263	.2263		.2377	.2263	.2263
8		.2263	.2263	.2263	.2546	.2263	.2263
9		.2263		.2263		.2263	.2263
10		.2263	.2263	.2263		.2263	.2263
11		.2263	.2263	.2263		.2263	.2263
12		.6281	.9733	1.2052		.2603	.2263
13		.2263	1.2279	1.2335		.2263	.2603
14		.2263	1.1373	1.2675		.2263	.2263
15		.2263	.2263	1.2392		1.2222	.2263
16		.7922	.2263	1.1543		1.16	.232
17	.2263	.2263	.2263	1.0864	.2263		.232
18	.9902	1.2449	.2263		.2999		4.6965
19	.2263	.2377	.2263	1.2279	.2999		.2546
20	.2263	.232	.2263	.2659	.2999		.2263
21	.2263	.232	.2263	.2263			.249
22	.2263	.232	.2263	.2263			.249
23	.2377	.2263	.2263	.2263			
24	.2263	.2263	.2263	.2263	.2263	.2999	.2263
Max	.9902	1.2449	1.2279	1.2675	.2999	1.2222	4.6965
Min	.2263	.2263	.2263	.2263	.2263	.2263	.2263
Avg	.3038	.3103	.3419	.5386	.2472	.3721	.4258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070] BU 1236

Substation No/ Name :- 244043 / 33/11 KV CHAKAN

Feeder No / Name : 201 / 11 KV Mahavir
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17
HR	Load (MW)
2	.3045
24	.1524
Max	.3045
Min	.1524
Avg	.2285

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244043 / 33/11 KV CHAKAN

Feeder No / Name : 202 / DATTANAND FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17
HR	Load (MW)
23	.1905
Max	.1905
Min	.1905
Avg	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244043 / 33/11 KV CHAKAN

Feeder No / Name : 203 / 11 KV Godavari

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17
HR	Load (MW)
24	.2858
Max	.2858
Min	.2858
Avg	.2858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244043 / 33/11 KV CHAKAN

Feeder No / Name : 404 / 33KV BASHKO

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-DEC-17
HR	Load (MW)
2	1.9004
24	.2286
Max	1.9004
Min	.2286
Avg	1.0645

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 201 / 11 KV Ankur

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7865	.7712	.8669	.8779	.8383	.0366	.8871
2	.7499	.7625	.8413	.7011	.8916	.0412	.924
3	.5868	.7537	.8413	.7628	.9511	.0457	.9877
4	.5258	.7042	.8322	.8048	.8954	.0549	1.086
5	.4664	.7042	.9015	.8139	.8954	.0503	1.0288
6	.4207	.6874	.8817	.823	.8779	.0457	.9724
7	.6706	.7712	1.0517	.4268	.823	.2881	.9282
8	.9389	.9816	1.1104	.4108	.724	.7377	.9922
9	1.1919	1.2308	1.4937	.3772	.1829	.6478	1.4784
10	1.2308	1.5684	1.5043	.8596	.2134	.9511	1.6598
11	1.4175	1.6095	1.6827	.8413		1.5684	1.595
12	1.2887	1.0631	1.643	.7407		1.2757	1.5684
13	.6767	1.5927	1.3032	.7975		1.3306	1.5684
14	1.4175	1.6598	1.643	.9922	.16	1.3306	1.5844
15	1.4327	1.5524	1.5364	.9671	.2096	1.3466	1.39
16	1.3611	1.5524	1.2894	.8859	.2195	1.4784	1.39
17	.8688	1.4632		.8413		1.1584	1.419
18	1.1096	1.3306	1.2567	.8048	.0907	1.2437	1.39
19	.9922	1.2757	1.0745	.8048	.1014	1.153	1.1088
20	.9015	1.1317	.8596	1.0745	.0747	1.0517	1.1203
21	.852	.9602	.8779	.5304	.0747	.9816	1.0242
22	.7956	.9389	.2934	.7773	.0594	.8916	.8596
23	.8139	.9054	.3201	.7865	.064	.9412	.7865
24	.7682	.8139	.8573	.8688	.7865	.0412	.8871
Max	1.4327	1.6598	1.6827	1.0745	.9511	1.5684	1.6598
Min	.4207	.6874	.2934	.3772	.0594	.0366	.7865
Avg	.9277	1.1160	1.0853	.7738	.4567	.7788	1.1932

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 202 / 11 KV LOKMAT

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.3864	.3567	.4801	.2286	.1753	.2972
2	.2286	.3963	.3201	.4694	.2286	.1829	.2972
3	.2362	.3963	.3064	.4534	.2286	.1677	.2926
4	.2439	.3963	.2972	.4481	.2286	.16	.2835
5	.2789	.4012	.3071	.4268	.2096	.1524	.2835
6	.2835	.4321	.3841	.3948	.2096	.1638	.2286
7	.3201	.3521	.2606	.4001	.2469	.2012	.2149
8	.3384	.5182	.4401	.4054	.1425	.1867	.3521
9	.7964	.961	.8688	.8299	.1551	.5761	
10	1.0456	1.0562	1.0562	.8779	.1905	.6935	.961
11	1.0562	1.2071	.9054	1.0242	.1867	.8688	1.0456
12	.8871	1.2826	.9511	.961	.1791	.7796	.8779
13	.7293	.8596	.8139	.7628	.1562	.7042	1.1069
14	1.0562	1.0456	.7865	.8326	.1867	.7628	.8299
15	1.0456	.9922	.961	.8238	.1966	1.0562	.8688
16	1.0562	.9054	.9808	.8779	.2195	.9511	.8131
17	.9175	.9709		.7712		.7628	.8779
18	.8131	.9054	.6379	.788	.16		.7087
19	.5304	.8048	.5624	.4755	.1753	.6783	.4214
20	.6299	.6154	.5304	.3628	.1638	.4115	.4108
21	.4428	.5182	.4801		.1524	.2743	.3246
22	.4374	.5087	.4641	.2743	.1448	.4374	.3109
23	.4268	.4801	.3429	.2743	.1334	.3612	.3429
24	.202	.3765	.4001	.4748	.2698	.1715	.2972
Max	1.0562	1.2826	1.0562	1.0242	.2698	1.0562	1.1069
Min	.202	.3521	.2606	.2743	.1334	.1524	.2149
Avg	.5922	.6987	.5832	.6039	.1910	.4730	.5412

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 206 / 11 KV MIDC Water Supply

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	.7167	.7545	.7167	.7167	.7167	.6602
2	.6413	.6413	.679	.6979	.7167	.6979	.6602
3	.679	.679	.6413	.679	.7167	.679	.6602
4	.7167	.679	.6413	.6602	.7545	.6413	.6602
5	.679	.7167	.6413	.7545	.7545	.7167	.6602
6	.679	.7545	.7356	.7733	.724	.7733	.6602
7	.7733	.7545	.7733	.7922	.811	.8865	.8865
8	.7922	.7545	.7545	.811	.811	.7545	.8488
9	.6602	.679	.6602	.6979	.679	.7356	.7167
10	.679	.6413	.6154	.6413	.6224	.7167	.6979
11	.5792	.543	.6224	.6413	.5068	.6413	.5973
12	.6468	.6036	.6036	.5658	.0362	.5973	.6036
13	.6036	.5544	.547	.5093	.0377	.0286	.5729
14	.0566	.5729	.5281	.5658	.0377	.5729	.5658
15	.5544	.6224	.5658	.5658		.547	.6036
16	.5658	.5658	.5249	.5281		.5658	.6036
17	.6413	.679		.5658		.6036	.6413
18	.9431	.9054	.9242	.8488	1.2449	.9431	.9054
19	1.2449	1.2449	1.226	1.2071	1.4146	1.1317	1.2449
20	1.2071	1.1883	1.1694	1.2071	1.3014	1.1317	1.2071
21	1.1694	1.1317	1.1506	1.1317	1.1883	1.1317	1.1506
22	.9997	1.0562	1.0185	.9997	1.0185	.9808	1.0374
23	.9054	.9431	.811	.8676	.8676	.7922	.811
24	.679	.7545	.7922	.7167	.7167	.7356	.5281
Max	1.2449	1.2449	1.226	1.2071	1.4146	1.1317	1.2449
Min	.0566	.543	.5249	.5093	.0362	.0286	.5281
Avg	.7398	.7659	.7557	.7560	.7465	.7384	.7577

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 207 / 11 KV Bharat Steel
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0091	.0046	.0091	.0061	.0046	.0061	.0046
2	.0061	.0046	.0069	.0076	.0046	.0091	.0046
3	.0091	.0046	.0069	.0091	.0046	.0122	.0046
4	.0213	.0046	.0046	.0046	.0046	.0152	.0046
5	.0152	.0046	.0046	.0076	.0046	.0274	.0046
6	.0183	.0274	.0366	.0076	.0076	.0518	.0046
7	.1829		.0297	.0213	.0015	.0457	.0046
8	.1943	.2652	.3155	.0244	.003	.176	.2705
9	1.6598	1.5089	.4755	.1677	.003	1.4632	1.5089
10	.3163	.2774	1.4937	1.5844	.0008	2.1948	1.2651
11	1.9342	.3315	1.2826	1.2803	.0019	1.2308	1.9418
12	.3932	1.358	1.5257	1.848	.029	1.7353	2.037
13	2.1879	1.4335	1.4937	.3628	.003	1.39	.282
14	1.9418	2.1125	1.7718	1.4937	.0137	1.9022	1.3032
15	2.3388	1.7924	1.5844	1.6598	.003	1.5364	1.3176
16	.061	.2926	1.8671	1.6598	.0076	2.2405	1.2696
17	.1357	.7392		1.4335		2.3152	.0114
18	1.5089	1.5684	.3155	1.358	.003	1.7177	.0335
19	1.4022	.0095	.0244	1.5089	.0061	1.5089	
20		.0091	.0244	.0133	.0046	.0061	.0152
21	.0076	.0069	.0046	.0061	.0061	.0061	.0046
22	.0091	.0069	.0198	.0061	.0046	.0061	.0046
23	.0046	.0091	.0076	.0046	.0046	.0076	.0076
24	.0061	.0046	.0091	.0061	.0046	.0046	.0046
Max	2.3388	2.1125	1.8671	1.848	.029	2.3152	2.037
Min	.0046	.0046	.0046	.0046	.0008	.0046	.0046
Avg	.6245	.5120	.5354	.6034	.0057	.8170	.4917

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244095 / 33/11 KV KUPWAD CITY

Feeder No / Name : 201 / 11 KV Milk Dairy

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
3	.3681
23	.0373
Max	.3681
Min	.0373
Avg	.2027

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244095 / 33/11 KV KUPWAD CITY

Feeder No / Name : 203 / 11 KV Mahalaxmi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
7	.3366
24	.0554
Max	.3366
Min	.0554
Avg	.196

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244095 / 33/11 KV KUPWAD CITY

Feeder No / Name : 205 / 11 KV Vidyanagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
3	.4031
24	.0732
Max	.4031
Min	.0732
Avg	.2382

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244095 / 33/11 KV KUPWAD CITY

Feeder No / Name : 208 / 11 KV Ashtavinayak

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	.0747
Max	.0747
Min	.0747
Avg	.0747

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 201 / 11 KV MIRAJ CITY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.905	.9412	.9511	.9145	.9328	.8688	.8596
2	.8688	.9145	.9145	.8779	.8962	.8413	.8048
3	.8688	.9145	.8869	.8779	.8962	.8326	.7964
4	.8688	.905	.8962	.8779	.8962	.8413	.8048
5	.9511	.9328	1.0059	.9328	1.0059	.924	.8871
6	1.0349	1.086	1.1706	1.134	1.1317	1.1157	1.1584
7	1.2567	1.2803	1.2254	1.3169	1.3121	1.3169	1.2178
8	1.4045	1.4118	1.2803		1.4083	1.4784	1.2934
9	1.4784	1.448	1.3937	1.4632	1.4661	1.2803	1.2894
10	1.5339	1.4266	1.3643	1.4118	1.4083	1.2986	1.2094
11	1.4969	1.3352	1.1789	1.2803	1.3717	1.2308	1.2403
12	1.423	1.3169	1.2094	1.3169	1.2803	1.1999	1.0402
13	1.3121	1.2127	1.2136	1.2936	1.2071	1.1706	.9882
14	1.2936	1.1765	1.1393	1.1273	1.086	1.1104	.2303
15	1.2752	1.1765	1.1218	1.1088	1.1041	1.1641	.9465
16	1.3306	1.1218	1.2445	1.2012	1.0059	.905	1.0517
17	1.3575	1.2445	1.2309	1.3306	1.1041	1.1283	1.0576
18	1.6832	1.5223	1.6095	1.5893	1.4632	1.3717	1.4198
19	1.7558	1.6827	1.6827	1.6834	1.5546	1.5927	1.6655
20	1.6278	1.6278	1.6278	1.5927	1.5364	1.5384	1.647
21	1.5364	1.5729	1.5546	1.5746	1.5364	1.4685	1.5023
22	1.386		1.3756	1.3394	1.3169	1.3213	1.3756
23	1.1888	1.0974	1.1888	1.1403	1.0608	1.0745	1.1104
24	.9671	1.0059	.9694	.9877	.9774	.9328	.9511
Max	1.7558	1.6827	1.6827	1.6834	1.5546	1.5927	1.6655
Min	.8688	.905	.8869	.8779	.8962	.8326	.2303
Avg	1.2835	1.2328	1.2265	1.2336	1.2066	1.1670	1.1062

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 204 / 11 KV MEDICAL COLLEGE
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1086	.1097	.128	.128	.128	.128	.1254
2	.1086	.1097	.1086	.1097	.1097	.128	.1097
3	.1086	.1097	.1086	.1097	.1097	.128	.1086
4	.1086	.1097	.1086	.1097	.1097	.128	.1097
5	.128	.128	.128	.128	.1463	.1294	.1109
6	.1478	.1829	.1463	.1463	.1886	.1463	.1267
7	.1663	.1829	.1646	.2195	.2218	.1829	.1612
8	.1848	.2195	.1646		1.4083	.2378	.1949
9	.2033	.2172	.181	.2195	.2172	.2012	.3045
10	.1848	.2353	.1772	.2715	.2743	.2012	.2454
11	.2033	.2743	.1907	.2561	.2534	.2896	.2481
12	.2218	.2012	.1402	.2926	.2561	.2686	.2254
13	.1848		.1372	.1848	.1991	.2012	.156
14	.1294		.1402	.2353	.2378	.197	.2303
15	.1478		.1402	.2218	.2195	.1791	.1578
16	.1663	.1402	.1402	.1848	.1629	.181	.1578
17	.1646	.1543	.1387	.1848	.1829	.1791	.156
18	.1646	.1543	.1463	.1848	.181	.1646	.1578
19	.1646	.1629	.1646	.1791	.1829	.181	.1433
20	.1463	.1463	.1646	.181	.1629	.1448	.1629
21	.1646	.1463	.1646	.181	.1829	.1612	.1629
22	.1829		.1646	.181	.1829	.1629	.1448
23	.1646		.1646	.1629	.1829	.1612	.1254
24	.1254	.1463	.128	.1463	.1448	.1463	.1463
Max	.2218	.2743	.1907	.2926	1.4083	.2896	.3045
Min	.1086	.1097	.1086	.1097	.1097	.128	.1086
Avg	.1575	.1648	.1475	.1834	.2352	.1762	.1655

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 205 / 11KV Dairy Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5914	.5544	.5487	.5487	.5544	.5373
2	.5121	.5544	.5359	.5175	.5316	.5359	.4887
3	.5121	.5487	.5359	.5121	.5316	.5359	.4887
4	.5487	.5544	.5487	.5359	.5316	.5359	.4706
5	.5853	.5487	.567	.5544	.6024	.567	.4887
6	.6283	.5853	.5914	.6099	.6556	.6219	.6036
7	.6283	.6401	.5914	.6401	.7167	.695	.7059
8	.6838	.6653	.6468	.6838	.7167	.7499	.6805
9	.7023	.7762	.6838	.7947	.7545	.8048	.7619
10	.7577	.7762	.7316	.7865	.7682	.8048	.823
11	.7842	.8413		.8402	.1663	.9134	.8048
12	.7655	.7392	.5975	.8402	.1478	.7865	.7682
13	.7468	.7682	.6908	.8029	.1646	.8145	.8145
14	.7655	.7282	.6224	.7655		.7682	.7499
15	.8029	.6535	.5788	.7468	.7762	.7164	.6653
16	.6348	.6908	.5975	.7655	.7762	.6984	.8131
17	.6584	.7095	.5975	.7655	.7682	.7602	.7316
18	.9145	.8775	.924	.8775	.9328	.8682	.8688
19	1.0349	.9593	.9425	1.0136	1.0059	.9877	1.0498
20	.961	.9145	.924	.9412	.9795	.9593	.9412
21	.8779	.8779	.8686	.905	.9055	.8779	.8688
22	.8048	.8048	.1646	.8145	.823	.7964	.7964
23	.695	.6767	.695	.695	.6767	.7164	.6697
24	.5973	.6099	.5544	.5914	.5973	.5914	.6516
Max	1.0349	.9593	.9425	1.0136	1.0059	.9877	1.0498
Min	.5121	.5487	.1646	.5121	.1478	.5359	.4706
Avg	.7146	.7122	.6411	.7312	.6555	.7359	.7184

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 206 / Vidya nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3109	.3109	.2957	.3292	.3292	.2957	.2865
2	.3109	.2926	.2772	.2957	.3012	.2743	.2715
3	.3109	.2957	.2587	.2957	.3012	.2743	.2715
4	.3109	.2957	.2561	.2957	.3012	.2772	.2534
5	.3475	.2926	.3109	.3326	.3366	.3142	.2534
6	.3881	.3658	.3326	.4066	.3898	.3511	.4024
7	.4251	.4024	.3511	.4435	.4715	.4024	.3982
8	.462	.439	.3696	.4435	.415	.3881	.394
9	.3696	.4163	.3881	.3511	.4527	.3658	.3189
10	.3511	.3658	.3292	.3326	.4024	.3658	.3292
11	.3326	.3292	.3395	.2957	.2957	.2865	.3292
12	.3174	.3109	.3361	.2957	.2772	.2926	.3109
13	.2987	.2743	.2987	.2801	.2957	.2534	.2896
14	.2987	.2801	.3018	.2987	.2926	.2561	.2743
15	.2801	.2641	.3174	.2801	.2743	.2507	.2926
16	.2987	.2614	.2987	.3174	.2587	.2686	.2772
17	.3326	.2987	.2957	.3361	.2587	.3258	.2926
18	.5175	.4294	.4805	.5041	.4207	.4075	.4163
19	.567	.5249	.5729	.5792	.5304	.5487	.5249
20	.5914	.5304	.5175	.5611	.5359	.5249	.543
21	.5487	.4755	.5359	.5611	.5175	.5121	.5249
22	.499	.439	.5121	.5068	.462	.4706	.4887
23	.4024	.3475	.4435	.4207	.3475	.4298	.3982
24	.3258	.3326	.2957	.4066	.3475	.3109	.362
Max	.5914	.5304	.5729	.5792	.5359	.5487	.543
Min	.2801	.2614	.2561	.2801	.2587	.2507	.2534
Avg	.3832	.3573	.3631	.3821	.3673	.3520	.3543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 401 / 33 KV Bedag outgoing(
Crossove Feeder KV- 33 /
INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.3982	3.3436	2.9835	2.7778	4.1701	2.8509	1.6118
2	3.5294	3.6214	2.8292	2.7161	3.7311	2.7349	1.262
3	3.6923	3.4979	3.5494	2.7161	3.7311	2.7349	1.9547
4	3.8409	3.6214	3.8066	2.5149	4.2798	2.7035	1.9753
5	4.1701	3.9283	3.9095	2.0119	4.8285	2.9984	2.0513
6	4.7188	4.3256	3.9438	2.5652	5.4841	3.5711	2.009
7	5.8711	6.3375	6.2243	5.08	7.4623	6.9473	4.8891
8	6.2552	4.8097	8.5711		8.9438	6.7341	6.5381
9		4.2267	7.6772	6.2872	8.3402	6.9799	6.1248
10		4.5713	6.4615	7.1228	5.3818	4.7188	4.8325
11		5.9968	7.8441	8.3453	4.0798	3.7466	6.5158
12		6.4883	7.4389	6.4472	6.0168	6.877	7.6017
13		6.7873	6.9685	7.5755	2.9675	7.7366	9.0135
14		6.0271	7.6269	6.286	3.7723	6.9845	8.742
15		7.2217	8.5597	6.7873	5.4824	6.6084	5.5967
16			7.7646	7.4932	8.155	1.7918	6.7873
17	3.4202	6.2243	4.9954	4.6742	6.2369	2.1491	7.1879
18	2.1605	3.1024	2.9835	4.4993	2.5434	2.3594	4.1267
19	2.1605	4.4119	2.4177	4.4525	2.1605	2.2805	2.8778
20	2.8807	2.3663	2.8292	4.1701	2.5206	1.8461	3.2036
21	2.7778	2.8778	2.7263	3.5117	2.3663	2.3102	3.095
22	3.3951	2.6235	2.7778	3.5294	2.9835	2.4434	3.3122
23	3.3436		2.7778	3.7466	2.5206	2.1948	3.7466
24	2.955	3.3436	3.1893	2.7778	3.8009	3.6214	2.0851
Max	6.2552	7.2217	8.5711	8.3453	8.9438	7.7366	9.0135
Min	2.1605	2.3663	2.4177	2.0119	2.1605	1.7918	1.262
Avg	3.7231	4.5343	5.0357	4.6995	4.6650	3.9968	4.4642

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071] BU 1228

Substation No/ Name :- 244070 / 33/11 KV KRIPAMAI

Feeder No / Name : 201 / 11 KV KRIPAMAYEE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	.0762
Max	.0762
Min	.0762
Avg	.0762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244070 / 33/11 KV KRIPAMAI

Feeder No / Name : 205 / 11KV SIDHIVINAYAK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
3	.2947
Max	.2947
Min	.2947
Avg	.2947

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 201 / 11KV Jagdish IRON

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0748				1.8107		2.0182
2	2.0559				1.905		2.2481
3	2.2481				1.9427		2.1338
4	1.8107				1.6787		2.3243
5	1.9616				2.21		1.6766
6	2.1879				2.2862		1.9993
7	2.0182				2.1125		2.1502
8	1.8673	2.1125	2.2481	2.0195	.961	.0972	1.8861
9	1.6194	2.3053	2.2862	2.0957	.4572	.7362	1.6221
10	1.5623	2.2672	2.3624		.2418	.4744	2.3243
11	1.5844	2.2068	2.2862	1.9052	.216	.8573	2.2862
12	1.5623	2.3053	2.2481	2.3243	.192	1.0349	2.2481
13	1.6004	.7682	2.2862	2.0957	.176	2.0538	2.2862
14	1.6385	1.0454	2.3243	1.7147	.1216	2.2257	2.3243
15	1.6766	2.3388	2.3243	1.7528	.144	2.21	2.4006
16	1.9433	2.3243		1.7337		2.0195	2.2257
17	2.1338	2.2862		2.3053		1.5466	1.6598
18		2.1719		1.5089		2.1338	2.2068
19	2.3624	2.0957		1.643		2.2068	2.3434
20	2.2862	1.6766		2.2862		1.4335	1.6221
21	2.2862	2.0957		2.2257		1.5278	1.0808
22	2.3243	2.3624		2.2862		2.2862	2.2672
23	2.2481	2.3243		1.6409		2.2672	1.1883
24	1.6956				1.9624		2.1313
Max	2.3624	2.3624	2.3624	2.3243	2.2862	2.2862	2.4006
Min	1.5623	.7682	2.2481	1.5089	.1216	.0972	1.0808
Avg	1.9456	2.0429	2.2957	1.9692	1.1511	1.5694	2.0272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 202 / 11 KV Mahabal

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4712				1.3769		1.3203
2	1.2071				1.3256		1.0456
3	1.3957				1.251		1.358
4	1.358				1.3203		1.3392
5	1.3014				1.3957		1.4146
6	1.226				.8871		1.4146
7	.8962				1.3769		1.3769
8	.8686	1.2449	1.6385	1.6975	.206	.4193	1.5242
9	1.8296	1.6575	1.5242	1.9052	.2629	1.1431	1.6766
10	1.6975	1.7918	1.3336	2.0748	.3246	1.2003	.567
11	1.094	1.8673	1.4098	1.8484	.2972	1.1431	1.9052
12	1.1812	1.1812	1.448	1.773	.2778	.6805	2.0195
13	1.2574	.8865	1.5242	1.7147	.2972	1.2803	1.9052
14	1.4098	1.1241	1.6766	1.2574	.3286	1.4861	1.4861
15	1.5242	1.086	1.9814	1.3717	.2	2.1338	1.8671
16	1.4861	1.7147		1.7353		1.226	1.0669
17	1.448	1.7909		1.6975		1.9993	1.7164
18	1.7528	1.0288		1.6194		1.2574	1.6194
19	1.7147	1.3336		.5316		1.1317	1.6575
20	1.5623	1.5242		1.094		1.1506	.9709
21	1.5242	1.2003		1.4861		1.6004	.9896
22	1.4098	.4687		1.4146		.8779	1.3014
23	.8871	1.0082		1.4901		.9425	1.4712
24	1.5432				1.5432		.8413
Max	1.8296	1.8673	1.9814	2.0748	1.5432	2.1338	2.0195
Min	.8686	.4687	1.3336	.5316	.2	.4193	.567
Avg	1.3769	1.3068	1.5670	1.5445	.7919	1.2295	1.4106

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 203 / 11KV Shreeji

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2543				.2401		.2254
2	.2241				.2601		.2515
3	.2214				.2683		.2374
4	.2315				.2543		.2721
5	.2214				.2315		.2469
6	.2372				.2458		.2713
7	.2134				.2107		.2883
8	.3801	.2743	.3696	.5914		.096	.5487
9	.567	.5853	.7468	.7468	.0838	.6413	.6722
10	.6036	.6099	.8383	.7733	.1006	.8383	.7167
11	.6413	.7095	.7545	.7842	.0914	.8002	.7545
12	.5716	.6161	.7095	.7762	.0777	.7621	.7922
13	.4572	.4763	.7468	.8299	.0732	.7922	.8299
14	.724	.7167	.7842	.9054	.0709	.8299	.8676
15	.8002	.724	.8299	.7621	.088	.8573	.8954
16	.7545	.7356		.7356		.7356	.8383
17	.6722	.7356		.7545		.7356	.6979
18	.6584	.679		.6653		.679	.7023
19	.5601	.543		.6468		.5792	.6154
20	.3018	.3429		.2321		.2915	.3086
21	.2743	.2743		.2572		.1974	.2258
22	.2429	.2256		.1957		.1833	.2241
23	.253	.3086		.2715		.2263	.2572
24	.2683				.2543		.2195
Max	.8002	.7356	.8383	.9054	.2683	.8573	.8954
Min	.2134	.2256	.3696	.1957	.0709	.096	.2195
Avg	.4306	.5348	.7225	.6205	.1700	.5778	.4983

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 204 / 11KV JK ICE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0056				.7529		.787
2	.9877				.6573		.8684
3	.8322				.6493		.7526
4	.7468				.6908		.631
5	.787				.4755		.7472
6	.5365				.5304		.6401
7	.5161				.6485		.8745
8	.6485	.612	.9465	1.2536	.6241	.5434	1.086
9	1.4335	1.6409	1.2803	1.2536	.6622	.9214	1.1812
10	1.6004	1.4289	1.4098	1.9052	.6836	1.6766	1.8671
11	1.7147	1.9427	1.7147	1.9433	.5868	1.7528	2.0195
12	1.829	1.3908	2.0576	2.0576	.5658	1.9052	2.1338
13	1.9052	1.7353	1.9052	1.6975	.2721	1.9616	2.0957
14	1.9433	1.9052	1.6766	1.2071	.2486	2.2257	2.0576
15	1.8671	1.8861	1.9239	1.9052	.2949	2.037	2.0748
16	1.829	1.9052		1.7353		1.5089	1.8861
17	1.7147	1.9814		1.0608		1.6975	1.2637
18	1.5623	1.5844		.9492		1.6057	1.2136
19	1.3336	1.2803		.788		1.6617	.9816
20	.9907	.9114		.5489		.8551	.7459
21	.8383	.9114		.5487		.8139	.7716
22	.7011	.9362		.5521		.8139	.8322
23	.9465	1.0517		.7716		.9991	1.0566
24	1.0808				.8223		.964
Max	1.9433	1.9814	2.0576	2.0576	.8223	2.2257	2.1338
Min	.5161	.612	.9465	.5487	.2486	.5434	.631
Avg	1.2229	1.4440	1.6143	1.2611	.5728	1.4362	1.2305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 205 / 11KV Shakti

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8939				.6882		.7133
2	.8596				.6019		.8402
3	.9231				.6718		.7865
4	.9313				.663		.8686
5	.8939				.6882		.8962
6	.9774				.7716		.9709
7	.7522				.5575		.9997
8	.7122	.9231	.6783	.905	.2572	.1547	1.105
9	.7783	1.1506	1.0974	1.0608	.2143	.5182	1.1812
10	.9526	1.1203	1.2193	1.1317	.2109	.591	1.3336
11	1.0288	1.3527	1.8107	1.5242	.2012	.9526	1.9239
12	1.2574	1.6956	1.9616	1.6766	.136	1.2193	2.0748
13	1.3336	1.7147	1.829	1.6004	.0838	1.2574	1.9993
14	1.5242	1.226	1.7147	1.6004	.0857	1.3336	1.773
15	1.6004	1.905	1.6385	1.8671	.1189	1.4098	1.9616
16	1.5242	1.9052		1.5655		1.5466	1.905
17	1.094	1.7909		1.7528		1.6385	1.9239
18	.9145	1.1317		.9328		1.0374	1.1812
19	.8764	1.0562		1.2382		1.0562	.9808
20	.8383	.9335		.9877		.9808	.8488
21	.7316	.9335		.8682		.9054	.7762
22	.6516	.924		.7202		.8962	.7947
23	.6036	.9671		.78		.9242	.8131
24	.8495				.6718		.6838
Max	1.6004	1.9052	1.9616	1.8671	.7716	1.6385	2.0748
Min	.6036	.9231	.6783	.7202	.0838	.1547	.6838
Avg	.9793	1.2956	1.4937	1.2632	.4139	1.0264	1.2223

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 206 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					1.3676		1.1949
2	1.4712				1.419		1.4969
3	1.6409				1.307		1.3817
4	1.3957				1.2254		1.2382
5	1.5089				1.4118		1.587
6	1.0576				1.0056		1.5684
7	1.3203				1.3491		
8	1.5655	1.419	1.5844	1.7924	1.1088	.6173	1.7147
9	2.1148	1.2003	1.7147	2.0576	.3765		1.8671
10	2.1879	1.9616	1.9052	2.0576	.2743	1.4861	2.0576
11	2.2634	2.037	1.8671		.3048	1.5242	1.9052
12	2.0957	1.8671	1.829		.3647	1.6004	1.7528
13	2.0195	1.7718	1.8671	2.0957	.3544	1.7528	1.7147
14	2.1719	2.1502		2.2862	.2705	1.829	1.6004
15	2.3624	1.7718	2.0576	2.1338	.3206	2.0957	2.1719
16	2.0957	2.0748		1.5623		1.9978	2.0936
17	2.0195	2.1502		2.1338		1.9433	2.0559
18	1.8671	2.0957		1.7353		1.9624	1.6956
19	1.9052	2.0195		1.6057		1.8296	1.7187
20	1.9433	1.9814		1.6409		1.7541	1.4901
21	1.9052	1.9052		1.6598		1.5278	.8596
22	1.8671	1.7147		1.7541		1.4901	1.4146
23	1.2071	1.6766		1.0903		.9231	1.4523
24	1.6787				1.419		.8775
Max	2.3624	2.1502	2.0576	2.2862	1.419	2.0957	2.1719
Min	1.0576	1.2003	1.5844	1.0903	.2705	.6173	.8596
Avg	1.8115	1.8623	1.8322	1.8290	.8674	1.6222	1.6048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071] BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 207 / 11 KV Priyanka

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17
HR	Load (MW)
24	.362
Max	.362
Min	.362
Avg	.362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 210 / 11KV Saptrang

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5079				.4458		.6767
2	.5935				.4917		.6089
3	.5868				.5375		.6836
4	.5243				.4424		.6268
5	.57				.5868		.5548
6	.5571				.6104		.5548
7	.5868				.5935		.6335
8	.5801	.5138	.5365	.7164	.2195	.2932	1.1203
9	.6908	.8299	1.3717	.8676	.206	1.1431	1.3336
10	.7468	1.358	1.6004	.6413	.1299	1.1812	.8215
11	.8215	1.0185	.3734	.9145	.1315	1.2071	1.3336
12	.7468	1.0751	.9808	.9907	.096	1.2826	1.448
13	.6722	.9619	1.0185	1.2574	.0838	1.2193	1.4861
14	1.1431	.9619	1.0669	1.4098	.0869	1.1812	1.5242
15	1.5242	1.0374	1.5623	1.3336	.096	1.3336	1.4861
16	1.5623	1.1431		.8962		1.2637	.8865
17	1.6004	1.2193		.7947		1.358	1.4712
18	.7545	1.3717		1.0751		.8865	1.226
19	.6584	1.0974				1.1694	.6036
20	.5609	.6089		1.1506		1.094	.9522
21	.9145	.7316		.9282		.3001	.8686
22	1.1203	.8413		.6661		.7316	.5784
23	1.2071	1.1949		.6661		.6805	1.0269
24	.5935				.3858		.724
Max	1.6004	1.3717	1.6004	1.4098	.6104	1.358	1.5242
Min	.5079	.5138	.3734	.6413	.0838	.2932	.5548
Avg	.8260	.9978	1.0638	.9539	.3215	1.0203	.9679

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 401 / 33KV Super Craft Foundry NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5373				3.0556		2.999
2	1.3443				2.6029		2.7161
3	3.1927				2.7161		2.9424
4	2.6029				2.5766		3.0556
5	2.7726				2.9687		.3041
6	1.9805				1.7541		2.7161
7	3.0556				1.4712		2.6595
8	1.8861	2.1719	1.4712	2.2634	1.3717	.064	2.2634
9	2.6595	1.4861	2.8292	2.8292	.2195	1.7147	1.5844
10	1.6975	3.1121	3.1687	3.0556	.1509	1.5844	3.1687
11	1.6975	2.6595	1.9239	2.8292	.1475	2.8006	2.9424
12	1.6004	3.1367	1.5844	2.7161	.144	3.1927	2.6029
13	1.4861	2.999	1.6975	2.4897	.1029	2.9424	2.5149
14	1.6975	1.5432	3.0556	1.9239	.0652	1.829	2.4006
15	1.9239	3.1121	3.2253	2.037	.072	2.1719	2.915
16	2.2862	3.0556		3.1927		1.4861	2.6029
17	2.6292	3.1687		3.0247		3.2819	1.4289
18	2.9424	2.0576		3.0807		2.7161	.9619
19	2.999	1.7147		3.0807		2.7161	1.4289
20	2.999	1.3717		1.358		1.9433	1.829
21	2.6292	2.8292		1.4712		3.2253	1.4289
22	1.9433	3.0556		1.3014		1.8673	3.1687
23	1.4712	2.6292		2.8006		1.4861	1.4289
24	2.037				3.0807		2.8292
Max	3.1927	3.1687	3.2253	3.1927	3.0807	3.2819	3.1687
Min	.5373	1.3717	1.4712	1.3014	.0652	.064	.3041
Avg	2.1696	2.5064	2.3695	2.4659	1.4062	2.1889	2.2872

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244118 / 33/11 KV SHANIVAR PETH MIRAJ

Feeder No / Name : 201 / 11 KV Shivaji Road Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
3	.2743
Max	.2743
Min	.2743
Avg	.2743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071] BU 1228

Substation No/ Name :- 248004 / 220 KV MIRAJ

Feeder No / Name : 401 / 33 KV SAHYADRI STARCH
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-DEC-17
HR	Load (MW)
10	1.262
24	1.5432
Max	1.5432
Min	1.262
Avg	1.4026

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071] BU 1228

Substation No/ Name :- 248004 / 220 KV MIRAJ

Feeder No / Name : 402 / 33KV SONI

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-DEC-17
HR	Load (MW)
24	7.3159
Max	7.3159
Min	7.3159
Avg	7.3159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071] BU 1228

Substation No/ Name :- 248004 / 220 KV MIRAJ

Feeder No / Name : 407 / 33KV MIDC MIRAJ
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-DEC-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 201 / 11KV JACKWELL LIS

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7922	.7023	.7545	.811	.7356	.7468	.7356
2	.7922	.6838	.7545	.7922	.7356	.7655	.7356
3	.7468	.7133	.7545	.7922	.7356	.7922	.7356
4	.7468	.7023	.7545	.7621	.7356	.8029	.7356
5	.7733	.6908	.7545	.7621	.7356	.7842	.7733
6	.7922	.7207	.7356	.7167		.8215	.7733
7	.7733	.7468	.7545	.6478	.7167	.6859	.7356
8	.7733	.7468	.7362	.811	.5847	.8192	.7356
9	.7922	.7468	.811		.6036	.8192	.6097
10	.6535	.7733	.4904	.743		.6668	.6097
11	.811	.7733	.7545	.743		.6668	.8299
12	.811	.7922	.7545	.743		.7922	.8215
13	.811	.7655	.7468	.743		.7362	.8029
14	.811	.6161	.7545	.743	.7356	.6661	.6535
15		.7733	.7545	.743	.7356	.7733	.6908
16	.8299	.7733	.7468	.743	.7545	.7922	.7545
17	.7468	.7733	.7282	.7049	.7356	.7733	.811
18	.7922	.6413	.7356	.6036	.7655	.6287	.811
19	.6722	.6413	.7356	.4527	.7733	.6478	.6668
20	.6348	.6219	.7356	.5658	.7545	.6413	.6668
21	.6668	.6219	.6602	.5847	.5906	.6413	.6478
22	.7545	.6401	.6602	.7282	.7049	.6036	.7922
23	.8589	.7316	.7922	.7545	.6668	.7282	.7922
24	.7922	.7167	.7011	.811	.7356	.811	.7356
Max	.8589	.7922	.811	.811	.7733	.8215	.8299
Min	.6348	.6161	.4904	.4527	.5847	.6036	.6097
Avg	.7664	.7129	.7317	.7175	.7124	.7336	.7357

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 202 / 11KV GANPATI MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6274	.6344	.7783	.6241	.6762	.6415	.6516
2	.6036	.6588	.7865	.6241	.6556	.6661	.6697
3	.57	.6836	.7947	.6154	.6201	.6241	.6335
4	.5765	.6661	.7947	.6154	.6135	.6485	.6268
5			.7537	.695	.6836	.6588	.6516
6	.6201	.6733	.7865	.6878	.7011	.6485	.6697
7	.6516	.6516	.7865	.7133	.7421	.6733	.7316
8	.7164	.7602	.7682	.7964	.7619	.7537	.7522
9	.7087	.724	.7087	.8764	.8048	.7619	.7522
10	.815	.7716	.7802	.7087	.7108	.8505	.8059
11	.9036	.9114	.8859	.7087	.9015	.9465	.9036
12	.929	.985	.9036	.7468	.8669	.929	.9745
13	.8328	.924	.8682	.7087	.8495	.8413	.9214
14	.8238	.8871	.7537	.7186	.7975	.929	.8764
15		.8962	.7712	.7011	.7712	.8238	.8764
16	.8328	.8962	.7973	.7011	.8059	.8589	.8682
17	.8589	.9511	.8413	.7712	.929	.9536	.9362
18	1.2174	1.5364	1.2209	1.17	1.3466	1.3435	1.3395
19	1.4217	1.5364	1.4403	1.283	1.4022	1.5257	1.4752
20	1.4563	1.2803	1.3546	1.2757	1.3672	1.4373	1.4217
21	1.0513	1.1706	1.046	1.0985	1.0576	1.2269	1.0923
22	.9088	1.0242	.9326	.9326	.9709	.9816	.8916
23	.7888	.8238	.788	.7888	.7975	.8149	.7461
24	.6274	.6443	.8507	.6687	.6762	.6588	.6687
Max	1.4563	1.5364	1.4403	1.283	1.4022	1.5257	1.4752
Min	.57	.6344	.7087	.6154	.6135	.6241	.6268
Avg	.8428	.8996	.8830	.8013	.8546	.8832	.8724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 203 / 11KV SANGLI WADI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5552	.5853	.6836	.5121	.4938	.4938	.4706
2	.5373	.5973	.6836	.5121	.4835	.5121	.4298
3	.5121	.6219	.6984	.5487	.4525	.499	.4207
4	.5121	.5792	.6984	.543	.4525	.5175	.4207
5	.6516	.6219	.7133	.6584	.7023	.5304	.5415
6	.7682	.6283	.7316	.6584	.7577	.5487	.7282
7	.8029	.7842	.7316	.8029	.7468	.7468	.7282
8	.7762	.7316	.7682	.7577	.7842	.6348	.6838
9	.7783	.724	.788	.6878	.7392	.7468	.6447
10	.7964	.7802	.7282	.7265	.6805	.7619	.6661
11	.7888	.8238	.7455	.7265	.5014	.6588	.6379
12	.703	.8059	.6733	.7265	.5014	.6588	.6485
13	.7265	.7522	.5316	.691	.439	.6588	.6201
14	.7164	.7499	.6626	.6135	.4656	.5201	.6201
15		.7059	.6805	.6135		.4961	.5847
16	.7186	.7499	.6268	.6135		.5434	.567
17	.7265	.7133	.7442	.6135		.5256	.6161
18	.823	.7133	.8238	.7973	.5792	.7373	.8059
19	.8596	.7133	.8954	.8682	.8869	.9036	.8939
20	.9134	.5784	.8954	.8505	.8688	.8596	.8775
21	.8596	.5784	.8238	.8507	.8048	.8869	.7865
22	.7783	.8063	.7783	.7421	.6584	.7343	.7602
23	.6268	.6836	.6219	.5914	.5914	.5973	.6268
24	.5552	.5611		.5304	.4938	.4805	.4706
Max	.9134	.8238	.8954	.8682	.8869	.9036	.8939
Min	.5121	.5611	.5316	.5121	.439	.4805	.4207
Avg	.7168	.6912	.7273	.6765	.6230	.6355	.6354

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 403 / 33 KV- BALAJIMANDIR

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8939	1.1431	.9671	.8688	.9134	1.0288	.9671
2	.8688	1.086	.9671	.8688	.8145	1.0288	.9671
3	.8145	1.086	.9877	.8779	.8145	1.0288	.8779
4	.823	1.0288	.8779	.8779	.8145	1.0288	.8871
5	.9231	.9717	.8871	.9877	.9231	1.0288	.9979
6	.9328	.9717	.8871	.9979	.9231	1.0288	.9979
7	.9328	1.0288	.8779	.9979	1.0425	1.1431	1.1088
8	.8779	1.0288	.8779	.9877	1.0317	1.1431	1.086
9	1.1431	1.1283	1.086	.9991	1.0208	1.086	1.2003
10	1.086	1.0517	1.2003	1.0208	.8745	1.182	1.2003
11	1.086	1.0402	1.1431	1.0208	.8842	1.1694	1.3146
12	1.086	1.0517	1.086	.9991	.8322	1.1694	1.2574
13	1.0288	1.0631	.9717	.9465	.823	1.1694	1.1431
14	.9717	.9568	1.0288		.8059	1.1163	1.1431
15		1.0517	1.1431	.9671	.8059	.9036	1.1431
16	1.1431	.9882	.9717	.9991	.9328	.8505	1.1431
17	1.1431	1.0631	1.0208	1.0208	1.0288	.7282	1.1431
18	1.2574	1.2757	1.1043	1.1568	1.1431	1.2717	1.1443
19	1.3146	1.2757	1.1694	1.182	1.2003	1.2226	1.1568
20	1.2003	1.0631	1.1043	1.182	1.2574	1.1694	1.1163
21	1.2574	1.0631	1.1043	1.182	1.2003	1.2757	1.1283
22	1.1431	1.0631	1.0631	1.0631	1.2574	1.182	1.0631
23	1.1431	.9877	1.0099	1.0317	1.086	1.0745	.9568
24	.8939	1.1431	.9877	.8688	.9134	1.0288	.9671
Max	1.3146	1.2757	1.2003	1.182	1.2574	1.2757	1.3146
Min	.8145	.9568	.8779	.8688	.8059	.7282	.8779
Avg	1.0419	1.0671	1.0218	1.0045	.9726	1.0858	1.0879

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 404 / 33 KV -MJP SHERINALA STAGE NON SHEDDABLE EXPRESS HV FEEDERS
 NO- Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1052	.1143	.1075	.1086	.1075	.1143	.2149
2	.1086	.1143	.1075	.1086	.1086	.1143	.1075
3	.1086	.1143	.1097	.1097	.1086	.1143	.1097
4	.1097	.1143	.1097	.1097	.1086	.1143	.1109
5	.1086	.1143	.1109	.1097	.1086	.1143	.1109
6	.1097	.1143	.1109	.1109	.1086	.1143	.1109
7		.1143	.1097	.1109	.1097	.1143	.1109
8	.1097	.1143	.1097	.1097	.0543	.0572	.1086
9	.1143	.1075	.1143		.0537	.1086	.1143
10	.1143	.1052	.1143	.1075	.1029	.1075	.1143
11	.1143	2.4714	.1143	.1075		.1063	.1143
12	.1143	.1052	.1143	.1052	.104	.1063	.1143
13	.1143	.1063	.1143	.1052	.1029	.1063	.1143
14	.1143	.1063	.2858	.1075	.1075	.1063	.1143
15		.1052	.1143	.1075	.1075	.1063	.1143
16	.1143	.104	.1143	.1052	.1097	.1063	.1143
17	.1143	.1063	.1075	.1075	.1143	.104	.1143
18	.1143	.1063	.2629	.1052	.1143	.1017	.104
19	.1143	.1063	.2658	.1075	.1143	.1063	.1052
20	.1143	.1063	.2629	.1075	.1143	.1063	.1063
21	.1143	.1063	.2629	.1075	.1143	.2126	.1075
22	.1143	.1063	.1063	.1063	.1143	.1075	.1063
23	.1143	.1097	.1063	.1086	.1143	.1075	.1063
24	.1052	.1143	.1097	.1086	.1075	.1143	.2149
Max	.1143	2.4714	.2858	.1109	.1143	.2126	.2149
Min	.1052	.104	.1063	.1052	.0537	.0572	.104
Avg	.1121	.2078	.1436	.1079	.1048	.1113	.1193

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 201 / 11KV RAMMANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.743	.7023	.7811	.7133	.7392	.7621	.7811
2	.724	.6584	.724	.695	.7133	.6859	.743
3	.7049	.6401	.6668	.6653	.7059	.6478	.7049
4	.6859	.6401	.6478	.6584	.6878	.6859	.6668
5	.724	.6584	.6859	.6878	.6878	.724	.7811
6	.7621	.6767	.743	.724	.7421	.7621	.8764
7	.7811	.7316	.8002	.7421	.7964	.8002	.8764
8	.8002	.8145	.8383	.7602	.7499	.8383	.8764
9	.8002	.7421	.8954		.8048	.8764	.8573
10	.743	.7499	.7621	.7316	.8192	.8383	.8192
11	.8383	.8192	.7621	.7621		.8383	.8192
12	.8383	.8192	.724	.7811	.7621	.8002	.8002
13	.8573	.7811	.6478	.724		.743	.7811
14	.743	.7621	.6478	.743	.724	.8002	.7621
15	.7811	.724	.6668	.7811	.724	.724	.743
16	.724	.724	.6287	.7811	.724	.743	.7811
17	.7811	.743	.6478	.8383	.8383	.8383	.743
18	1.0288	1.105	.8764	1.2765	1.1622	1.2193	1.0098
19	1.2437	1.2574	1.0425	1.2752	1.2384	1.2574	1.2955
20	1.134		1.0608	1.2197	1.2384	1.0288	1.2384
21	1.0974	1.105	1.0425	1.0974	1.1431	1.1622	1.1622
22	.9593	1.0288	.9511	1.0425	1.0479	1.105	1.0479
23	.8688	.9335	.8413	.8871	.9526	.9717	.9526
24	.7811	.7316	.8192	.7577	.7682	.7811	.8192
Max	1.2437	1.2574	1.0608	1.2765	1.2384	1.2574	1.2955
Min	.6859	.6401	.6287	.6584	.6878	.6478	.6668
Avg	.8394	.8064	.7876	.8411	.8532	.8597	.8724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 202 / 11KV SHAMRAO NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.5914	.6097	.6099	.6283	.6478	.6668
2	.5906	.567	.5716	.5975	.6161	.5906	.6097
3	.5716	.5544	.5525	.5544	.5914	.5716	.5335
4	.5335	.5544	.5335	.5544	.5975	.5525	.4763
5	.5906	.5914	.5716	.5914	.6283	.5716	.5716
6	.6287	.6283	.6478	.6468	.6838	.6478	.7049
7	.6668	.6161	.6668	.6468	.6838	.724	.743
8	.6859	.6468	.6859	.6401	.6468	.743	.7621
9	.743	.6584	.743		.6767	.743	.7811
10	.7811	.6838	.7811	.7207	.743	.724	.7811
11	.8002	.724	.7621	.743		.8002	.743
12	.7811	.7049	.7621	.7621	.6478	.7621	.7049
13	.7811	.7049	.6859	.743		.6097	.6668
14	.6287	.6097	.6478		.5906	.6287	.6287
15	.7049	.7049	.6287	.6859	.5906	.6478	.7049
16	.6287	.6287	.5906	.6859		.6287	.6478
17	.6859	.6668	.6287	.6668		.6668	.6478
18	.9526	.9907	.8954	1.086		.9907	.8954
19	1.0349	1.086	.9795	1.0349	1.1241	1.0098	1.0669
20	1.0164		.9055	1.0456	1.0288		1.0098
21	.9522	1.0098	.8686	1.0082	1.0288	1.0098	.9526
22	.8686	.9145	.8596	.9145	.9145	.9145	.8954
23	.7577	.7811	.7392	.8402	.9145	.8192	.7621
24	.6287	.6099	.6478	.6283	.6838	.6859	.724
Max	1.0349	1.086	.9795	1.086	1.1241	1.0098	1.0669
Min	.5335	.5544	.5335	.5544	.5906	.5525	.4763
Avg	.7343	.7056	.7069	.7457	.7379	.7256	.7367

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 204 / 11KV CIVIL HOSPITAL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.5228	.5144	.5228	.5415	.5335	.4763
2	.5144	.5041	.4954	.5228	.5601	.4572	.381
3	.4954	.4854	.4572	.5041	.5228	.381	.362
4	.4572	.5041	.4572	.4854	.5228	.4763	.3429
5	.4954	.5415	.5144	.4854	.5415	.5525	.381
6	.5335	.5228	.5716	.5041	.5601	.5716	.5525
7	.5716	.5415	.5906	.5601	.5788	.5716	.5335
8	.6287	.6535	.6287	.6722	.6535	.6478	.5335
9	.6097	.6722	.6478		.6722	.724	.5716
10	.5716	.6908	.6478	.5788	.5335	.7049	.6859
11	.6097	.6097	.6287	.6478		.6097	.6097
12	.6478	.7049	.4954	.5716	.2858	.5716	.6478
13	.5525	.381	.5906	.5906		.5144	.381
14	.5144	.5716	.5525		.3048	.6097	.5906
15	.4954	.5144	.4572	.5335	.2286	.5335	.5906
16	.4954	.4191	.381	.4954	.4763	.4191	.4191
17	.5716	.5525	.3429	.6097	.4572	.5716	.5906
18	.6287	.6668	.6287	.6859	.6859	.6859	.6478
19	.6908	.724	.6535	.5788	.7049	.7049	.6859
20	.6348		.6348	.5788	.7049	.6478	.6859
21	.6722	.6668	.6348	.6535	.6668	.6668	.6668
22	.5041		.4294	.6348	.6478		.6097
23	.5601	.5716	.5415	.4294	.5906	.5716	.5716
24	.5887	.5415	.5335	.5415	.5601	.5716	.5335
Max	.6908	.724	.6535	.6859	.7049	.724	.6859
Min	.4572	.381	.3429	.4294	.2286	.381	.3429
Avg	.5657	.5710	.5429	.5630	.5455	.5782	.5438

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 205 / Hanuman Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	.4251	.4191	.4251	.4481	.4191	.4191
2	.381	.3841	.381	.3881	.3881	.381	.4191
3	.362	.3696	.3429	.3881	.3658	.362	.4001
4	.362	.4066	.3239	.3696	.4024	.3429	.381
5	.4001	.4207	.381	.4066	.439	.4001	.4572
6	.4382	.4805	.4191	.4668	.499	.4763	.5335
7	.4572	.4435	.4572	.499	.5121	.5144	.4954
8	.5144		.4954	.462	.5359	.4954	.5144
9	.4382	.4066	.4382		.4251	.4763	.4954
10	.4191	.3658	.4191	.4066	.4001	.4572	.4572
11	.362	.3239	.4191	.3429		.362	.3239
12	.381	.3239	.3429	.3239	.2667	.3239	.3239
13	.362	.3429	.3429	.3429		.3239	.3429
14	.362	.3429	.3429	.3429	.3239	.3429	.3429
15	.362	.3048	.3239	.3429	.2858	.3239	.3239
16	.3429	.3239	.3429	.3048	.3048	.3048	.3239
17	.362	.3239	.3429	.362	.3239	.362	.3429
18	.5716	.4954	.5906	.6478	.6859	.6859	.4954
19	.7207	.7049	.7023	.7207	.743	.7811	.724
20	.7133		.7023	.7207	.724	.743	.724
21	.7207	.6668	.6653	.7392	.7049	.7049	.6859
22	.6283	.6287	.6283	.6584	.6097	.6287	.5716
23	.5175	.5144	.5228	.5487	.5335	.5335	.5335
24	.4572	.4481	.4382	.4435	.462	.4572	.4763
Max	.7207	.7049	.7023	.7392	.743	.7811	.724
Min	.3429	.3048	.3239	.3048	.2667	.3048	.3239
Avg	.4598	.4294	.4493	.4632	.4720	.4668	.4628

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 206 / 11KV TRIMURTI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.5041	.5716	.5041	.5041	.4763	.5144
2	.4572	.5041	.5525	.5041	.4854	.4572	.4954
3	.4382	.4668	.5335	.4854	.4854	.4382	.4763
4	.4572	.4668	.4954	.4854	.4668	.4572	.4572
5	.4954	.5041	.5144	.5041	.5228	.4954	.5335
6	.5335	.5415	.5335	.5415	.5788	.5906	.6287
7	.5716	.5975	.5716	.6535	.6722	.6668	.6668
8	.6287	.6722	.6097	.6535	.6908	.7049	.6859
9	.6859	.7468	.6668		.6722	.743	.7049
10	.8192	.7468	.7049	.8402	.8764	.9145	.724
11	.8192	.8764	.724	.8573		.9145	.8954
12	.8383	.8192	.7621	.8573	.8002	.8764	.8573
13	.8383	.8573	.724	.8573		.8764	.8573
14	.7811	.8002	.6859		.8192		.7811
15	.7621	.743	.6478	.8002	.7621	.8002	.5144
16	.743	.743	.6478	.8192	.7811	.8002	.5906
17	.7621	.8002	.6668	.8954	.7811	.8383	.8573
18	.9907	.9526	.8573	1.1812		1.1622	1.0288
19	1.0456	1.0669	.9709	1.1016	1.105	1.105	1.1812
20	1.0269		.9522	1.0642	1.0288	1.086	1.0479
21	.9149	.8192	.9149	.9522	.9717	.9145	.9526
22	.7468		.7468	.7842	.8954	.7811	.8002
23	.6535	.6478	.6535	.6535	.6668	.6859	.6668
24	.4954	.5228	.5906	.5415	.5415	.5335	.5716
Max	1.0456	1.0669	.9709	1.1812	1.105	1.1622	1.1812
Min	.4382	.4668	.4954	.4854	.4668	.4382	.4572
Avg	.7075	.7000	.6791	.7517	.7194	.7530	.7287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 404 / 33KV KOLHAPUR ROAD
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-DEC-17
HR	Load (MW)
24	.0514
Max	.0514
Min	.0514
Avg	.0514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244092 / 33 / 11 KV KOLHAPUR ROAD

Feeder No / Name : 201 / 11 KV SHASTRI CHOWK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.6224	.6413	.583	.6224	.6224	.6224
2	.5658	.5847	.5847	.5658	.6036	.6036	.6036
3	.5658	.5847	.5847	.5658	.6036	.5847	.5658
4	.5658	.6036	.5847	.5658	.6224	.5847	.5658
5	.5847	.6413	.6413	.6173	.6413	.6602	.6413
6	.7167	.7167	.6979	.7202	.7545	.7733	.7922
7	.7545	.8299	.7545	.7373	.8299	.8865	.8865
8	.8299	.811	.7922	.7545	.9054	.8488	.8676
9	.7716	.7202	.8488	.9054	.8488	.8676	.7922
10	.823	.823	.8676	.9054	.8488	.9054	.8299
11	.823	.823	.8299	.8865	.8488	.9242	.8676
12	.8059	.8573	.8488	.9054	.811	.8865	.8676
13	.7545	.7888	.811	.811	.8299	.8865	.811
14	.7202	.7716	.7733	.8299	.8299	.811	.8299
15	.7202	.7545		.8488	.7545	.811	.8299
16	.7545	.7888	.7356	.8865	.7545	.8299	.8299
17	.8488	.8676	.7202	.9242	.8676	.8865	.9619
18	1.2637	1.2449	.9602	1.2449	1.1694	1.2449	1.2071
19	1.2637	1.2637	1.0631	1.2826	1.2071	1.2449	1.226
20	1.1883	1.2071	1.0288	1.2449	1.2071	1.1883	1.2071
21	1.1317	1.0751	.9945	1.1317	1.1128	1.094	1.1128
22	1.0374	.9997	.9259	1.0185	.9997	.9997	.9808
23	.8488	.8299	.7888	.8488	.8488	.8488	.8299
24	.6602	.679	.6979	.6516	.6979	.679	.679
Max	1.2637	1.2637	1.0631	1.2826	1.2071	1.2449	1.226
Min	.5658	.5847	.5847	.5658	.6036	.5847	.5658
Avg	.8168	.8287	.7902	.8515	.8425	.8614	.8503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244092 / 33 / 11 KV KOLHAPUR ROAD

Feeder No / Name : 202 / 11 KV FRUIT MARKET

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0943	.0943	.0686	.0943	.0943	.0943
2	.0943	.0943	.0943	.0686	.0943	.0943	.0943
3	.0754	.0943	.0943	.0686	.0943	.0943	.0943
4	.0754	.0943	.0943	.0686	.0943	.0943	.0943
5	.0943	.0943	.0943	.0457	.0943	.0943	.0943
6	.0943	.1132	.0943	.0857	.0943	.0943	.0943
7	.0754	.0754	.0754	.0857	.0754	.0943	.0754
8	.0943	.0943	.0943	.0686	.0754	.0943	.0754
9	.0857	.1029	.0754	.1132	.0943	.132	.0754
10	.1029	.12	.132	.1132	.1132	.1509	.132
11	.1372	.12	.0943	.1698	.132	.1509	.132
12	.1372	.1372	.1509	.1886	.1132	.1698	.1509
13	.12	.0686	.0943	.1509	.132	.1132	.1509
14	.12	.1372	.1132	.1509	.0943	.1132	.1509
15	.1543	.1372		.1509	.1132	.1886	.1698
16	.1029	.1715	.1698	.1698	.0943	.132	.1509
17	.1132	.1886	.12	.1886	.1132	.1509	.1509
18	.1886	.1509	.1029	.1698	.1509	.1886	.2075
19	.1698	.1698	.1372	.1698	.1698	.1509	.1698
20	.1509	.1509	.12	.1509	.1509	.132	.1509
21	.132	.132	.12	.132	.132	.1132	.132
22	.132	.132	.1029	.132	.132	.132	.132
23	.1132	.1132	.1029	.1132	.1132	.1132	.1132
24	.0943	.0943	.0943	.0857	.0943	.0943	.1132
Max	.1886	.1886	.1698	.1886	.1698	.1886	.2075
Min	.0754	.0686	.0754	.0457	.0754	.0943	.0754
Avg	.1147	.1200	.1072	.1212	.1108	.1242	.1250

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244092 / 33 / 11 KV KOLHAPUR ROAD

Feeder No / Name : 402 / 33KV SHERINALA

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8292	2.7161	2.8292	2.572	2.7161	2.8292	2.8292
2	2.8292	2.7161	2.6595	2.572	2.6595	2.7726	2.6595
3	2.7726	2.7161	2.6595	2.572	2.6595	2.7726	2.6595
4	2.7161	2.7161	2.6595	2.572	2.6595	2.7726	2.6595
5	2.6595	2.8292	2.8292	2.6749	2.7161	2.7726	2.8292
6	3.1121	3.1121	2.999	3.035	3.1687	3.1687	3.0556
7	3.2253	3.2253	3.1121	3.035	3.3385	3.3951	
8	3.2819	3.2253	3.2819	3.0864	3.1687	3.3385	3.4517
9	3.1379	3.0864	3.3385	2.8292	3.2819	3.6214	3.2253
10	3.3436	3.2922	3.5648	3.3951	2.3765	3.5648	3.678
11	3.3951	3.4465	3.678	3.4517	2.32	3.678	3.9609
12	3.3436	3.3951	3.5648	3.3385	2.32	3.7912	3.9043
13	3.1893	3.2922	3.3951	3.2253	.2829	3.6214	3.6214
14	3.035	3.2922	3.4517	3.2253	2.32	3.5648	3.3951
15	3.3436	3.2922		3.2819	2.3765	3.2253	3.5648
16	3.3436	3.2922	3.2253	3.1121	2.4331	3.2819	3.5648
17	3.678	3.678	3.2407	3.4517	2.7161	3.2253	3.678
18	4.6399	4.5268	3.9095	4.1307	3.7346	4.6965	4.3004
19	4.5833	4.6399	4.321	4.0175	4.357	4.6399	4.5268
20	4.357	4.357	4.0124	4.0741	.2829	4.4136	4.357
21	3.9609	3.9043	3.7037	3.8477	3.7346	4.1872	3.8477
22	3.7346	3.7346	3.5494	3.5648	3.6214	3.678	3.7912
23	3.2253	3.3951	3.1379	3.2819	3.1687	3.4517	3.3385
24	2.9424	2.8858	3.0556	2.7778	2.8858	2.9424	2.9424
Max	4.6399	4.6399	4.321	4.1307	4.357	4.6965	4.5268
Min	2.6595	2.7161	2.6595	2.572	.2829	2.7726	2.6595
Avg	3.3616	3.3653	3.3121	3.2135	2.7208	3.4752	3.4713

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244094 / 33\11 KV VIJAYANAGAR

Feeder No / Name : 201 / 11 KV Government Colony

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2957		.3475	.3547	.3361	.3174	.3696
2	.2957		.3511	.3547	.3361	.3174	.3696
3	.2987		.3511	.3547	.3361	.3174	.3734
4	.2987		.3547	.3734	.3361	.3361	.4108
5	.3395		.3696	.4435	.3361	.3696	.4435
6	.415		.3921	.4435	.4805	.4435	.4481
7	.5093		.5228	.499	.5359	.5544	.4805
8	.5093		.4805	.499	.499	.4805	.5601
9	.4481		.499	.4435	.4435	.5175	.4481
10	.4024		.4066	.3547	.3658	.4435	.4108
11	.3658		.3696	.3361		.4066	.3361
12	.3696		.3142	.3361		.3696	.3142
13	.3511		.3142	.2987	.3898	.3511	.3142
14		.2926	.3142	.3018	.3224	.3511	.2987
15		.2926	.3142	.3206	.3292	.3326	.3018
16		.2926	.3326	.2987	.3142	.3326	.3395
17		.3292	.3511	.3326	.3292	.3326	.3361
18		.4607	.499	.5121	.4755	.5544	.4525
19		.5731	.6036	.6335	.6219	.6089	.6268
20		.5914	.6036	.6335	.6219	.6089	.6154
21		.5788	.6036		.5853	.5973	.5792
22		.5068	.5544	.5487	.5304	.5544	.543
23		.4207	.4435	.4207	.4435	.4435	.4163
24	.3326		.3475	.3734	.3696	.3547	.3658
Max	.5093	.5914	.6036	.6335	.6219	.6089	.6268
Min	.2957	.2926	.3142	.2987	.3142	.3174	.2987
Avg	.3737	.4339	.4183	.4116	.4245	.4290	.4231

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244094 / 33\11 KV VIJAYANAGAR

Feeder No / Name : 202 / 11 KV Vijaynagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2772	.3018	.3174	.2987	.2829	.2987	.3109
2	.2772	.3018	.3174	.2987	.2641	.2987	.3109
3	.2801	.3018	.3206	.2987	.2641	.2987	.3174
4	.2801	.3018	.3174	.3361	.2641	.3361	.3142
5	.2801	.2987	.3206	.3326	.2641	.3547	.3361
6	.3206	.3361	.3395	.3326	.3361	.3547	.3395
7	.3772	.3921	.3584	.4435	.4251	.3881	.4338
8	.4338	.4294	.462	.4435	.4435	.462	.4854
9	.4481	.4435	.4805	.499	.462	.4481	.4668
10	.3921	.3696	.4251	.3921	.4481	.4066	.3921
11	.3772	.3881	.3881	.3734	.4066	.4066	.3921
12	.3395	.3475	.4066	.3734	.4024	.3881	.3511
13	.3174	.3475	.3326	.3734	.3881	.3696	.3696
14	.2957	.3292	.3696	.3772	.3696	.3696	.3326
15	.2987	.3292	.3881	.4108	.3696	.3511	.3584
16	.2987	.3475	.3326	.2987	.3361	.3511	.3018
17	.3658	.3547	.2957	.3734	.3696	.3696	.3921
18		.462	.4435	.4805	.439	.5068	.462
19	.5304	.5121	.5487	.567	.5304	.5853	.5121
20	.5304	.543	.5304	.5304	.5487	.5611	.5121
21	.5121	.5068	.5487		.5121	.4755	.5121
22	.4572	.5228	.4805	.4938	.4805	.4938	.4572
23	.3881	.4024	.4066	.3696	.3696	.4066	.4024
24	.2957	.3142	.3142	.3174	.3142	.3174	.3142
Max	.5304	.543	.5487	.567	.5487	.5853	.5121
Min	.2772	.2987	.2957	.2987	.2641	.2987	.3018
Avg	.3641	.3827	.3935	.3919	.3871	.3999	.3907

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244094 / 33\11 KV VIJAYANAGAR

Feeder No / Name : 205 / 11 KV CENTRAL BUILDING

FEEDER Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4066		.4024	.4435	.4294	.4668	.4805
2	.4108	.4108	.4108	.4481	.4108	.4668	.4854
3	.4108	.4108	.4066	.4481	.4108	.4481	.4458
4	.4108	.4108	.4066	.4481	.4108	.4481	.4854
5	.4715	.4108	.4066	.4805	.4108	.4805	.4904
6	.547	.4481	.462	.4805	.4805	.4805	.4854
7	.6413	.5544	.4805	.4805	.6283	.6099	.6348
8	.6535	.6283	.4481	.6283	.6653	.6468	.6908
9	.6653	.7762	.5788	.7392	.6838	.8131	.7655
10	.7316	.7762	.5601	.7392	.7682	.8596	.7762
11	.695	.7762	.4668	.8131	.8131	.8596	.8316
12		.7577	.4481	.7392	.8048	.8596	.8131
13	.6653	.7577	.4294	.8131	.7682	.7207	.6722
14	.6161	.7133	.4108	.7468	.7762	.8131	.6722
15	.7133	.6219	.4668	.6161	.7762	.8131	.7282
16	.5914	.6219	.4668	.8215	.7762	.8131	.8501
17	.3881	.5975	.4481	.7023	.6653	.6468	.6653
18	.5304	.6283	.5487	.7023	.6219	.6653	.6283
19	.6036	.6219	.5487	.7023	.6584	.6584	.6219
20	.567	.567	.5121	.6468	.6219	.5853	.5487
21	.5487	.5121	.499		.5487	.5601	.5487
22	.499	.4755	.462	.5121	.5487	.5487	.499
23	.462	.4024	.4435	.499	.4805	.499	.499
24	.4435	.4435	.4251	.4435	.4805	.499	.4805
Max	.7316	.7762	.5788	.8215	.8131	.8596	.8501
Min	.3881	.4024	.4024	.4435	.4108	.4481	.4458
Avg	.5510	.5793	.4641	.6128	.6100	.6359	.6166

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244119 / 33/11 VISHRAMBAG STORES

Feeder No / Name : 203 / 11 KV VISHRAMBAG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2489	1.3717	1.3432	1.3717	1.4118	1.3432	1.2894
2	1.2357	1.2752	1.2357	1.262	1.2489	1.2357	1.2357
3	1.2357	1.2752	1.2489	1.2752	1.2357	1.2489	1.2489
4	1.2489	1.2883	1.2489	1.262	1.2357	1.2489	1.262
5	1.262	1.4003	1.2489	1.3169	1.3432	1.4266	1.3717
6	1.4415	1.5524	1.4815	1.6078	1.5912	1.5524	1.6244
7	1.7924	1.701	1.6244	1.7924	1.8656	1.885	1.9239
8	1.7924	1.7558	1.7187	1.7741	1.701	1.7187	1.9044
9	1.6804	1.6832	1.6244	1.9547	1.7741	1.7741	1.7924
10	1.6632	1.5912	1.6804	1.6832	1.5912	1.6461	1.701
11	1.5912	1.5912	1.6078	1.6289	1.5203	1.5912	1.3717
12	1.5203	1.5912	1.4815	1.6289	1.4661	1.5912	1.4815
13	1.5364	1.5364	1.4266	1.5203	1.4883	1.5364	1.5912
14	1.4266	1.4266	1.4266	1.5203	1.5043	1.4661	1.4266
15	1.3717	1.5364	1.2894	1.5364	1.3969	1.4661	1.3717
16	1.3717	1.4118	1.2894	1.4266	1.4266	1.4118	1.4815
17	1.4661	1.5203	1.4266		1.6118	1.5203	1.6832
18	2.1176	2.0199	1.9547		1.9136	2.1262	2.1491
19	2.4143	2.3388	2.2565		2.3388	2.364	2.5514
20	2.4143	2.364	2.2565		2.2857	2.2325	2.4177
21	2.1948	2.1491	2.0953		2.1262	2.1491	2.2028
22	1.9753	1.9342	1.9342		1.9136	1.9004	1.9004
23	1.6461	1.5581	1.5581		1.6118	1.6289	1.6118
24	1.3969	1.4266	1.382	1.3969	1.4661	1.3969	1.4506
Max	2.4143	2.364	2.2565	1.9547	2.3388	2.364	2.5514
Min	1.2357	1.2752	1.2357	1.262	1.2357	1.2357	1.2357
Avg	1.6269	1.6375	1.5767	1.5270	1.6279	1.6442	1.6685

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244119 / 33/11 VISHRAMBAG STORES

Feeder No / Name : 206 / 11 KV DATTANAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7522	.8059	.8596	.7522	.8145	.8505	.7522
2	.6984	.7602	.8059	.6984	.7602	.7602	.6984
3	.6984	.7602	.7522	.7133	.7522	.7602	.7059
4	.7059	.7682	.7522	.7133	.7522	.7602	.7207
5	.7133	.8316	.7522	.7682	.7133	.9425	.8316
6	.9425	.9877	.9134	1.0534	1.0974	1.1643	1.1643
7		1.3032	1.1946	1.3717	1.4266	1.4969	1.5123
8	1.262	1.182	1.2197	1.3169	1.3717	1.3717	1.4415
9	1.2752	1.2357	1.2752	1.4506	1.262	1.3169	1.2197
10	1.1523	1.182	1.262	1.1283	1.1403	1.1946	1.1946
11	1.1403	1.0745	1.1403	1.0208	.9568	1.086	1.1403
12	.9671	1.0099	1.1946	.9465	.9036	.9774	1.0317
13	.8505	.9671	.9774	.9036	.8322	.9134	.8939
14	.8688	.9036	.9231	.8505	.7973	.8059	.8939
15	.8059	.8939	.9036	.8505	.7973	.8059	.7888
16	.8059	.8413	.8505	.8059	.7888	.9134	.7973
17	.8413	.9568	.9231	1.0099	.8413	.9671	.9465
18	1.3672	1.3003	1.2094	1.3003	1.1831	1.2717	1.3003
19	1.4883	1.4723	1.4352		1.4352	1.4352	1.5249
20	1.4506	1.4352	1.3289	1.4352	1.4352	1.4883	1.4506
21	1.3969	1.3432	1.3289	1.4352	1.382	1.3969	1.3969
22	1.2894	1.2894	1.2357	1.2226	1.2757	1.2357	1.2894
23	1.0208	1.0208	.9671	1.1283	1.0631	1.0317	1.0208
24	.8505	.8596	.8779	.8059	.8688	.9036	.8596
Max	1.4883	1.4723	1.4352	1.4506	1.4352	1.4969	1.5249
Min	.6984	.7602	.7522	.6984	.7133	.7602	.6984
Avg	1.0149	1.0494	1.0451	1.0296	1.0271	1.0771	1.0657

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 201 / 11 KV Madgule AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9264	.3658	.2743	.3258	3.3288	3.0407	2.4434
2	2.8166	.3658	.2534	.3292	3.2579	2.9864	2.4508
3	2.3777	.4024	.2507	.3439	3.1459	2.9264	2.4434
4	2.4143	.4755	.2686	.3475	3.0407	2.8235	2.4874
5	2.4143	.5487	.2896	.3258	2.963	2.7511	2.4253
6	.5373	.5373	.3403	.3658	.362	.394	.4755
7	.5373	.5373	.3982	.3475	.3841	.3439	.4525
8	.5373	.5373	.4024	.3439	.4163	.2926	.3982
9	.5373	.5373	2.8349	.3475	.4572	.2534	.439
10	2.1719	1.6651	2.8054	.4525	.5068	.2743	.3982
11	3.0361	2.8959	2.8054	.3292	.5487	.2715	.3658
12	2.9264	3.5101	2.8959	.2896	.543	.2926	.3258
13	3.1824	3.4751	2.9264	.2507	.3582	.2926	.3292
14	4.3896	3.1878	2.8597	.2172	.3077	.2896	.181
15	3.2922	2.8959	2.8349	.2195	.2378	.2926	.1829
16	3.2922	2.7435	2.7873	.181	.2715	.2896	.2172
17	2.2314	2.5606	2.8166	.2378	.2686	.3077	.2195
18	.4344	.3258	2.7692	.3258	.3982	.3109	.2743
19	.5373	.3761	.3258	.362	.439	.3077	.2926
20	.5373	.3982	.3292	.394	.4163	.3292	.3258
21	.4656	.3761	.3258	.3439	.4525	.3439	.3475
22	.4706	.3258	.2743	3.8409	3.0445	2.5606	2.8959
23	.4755	.2865	.3258	3.4751	3.0407	2.552	
24	2.572	.439	.2896	.3258	3.2579	3.1093	2.5789
Max	4.3896	3.5101	2.9264	3.8409	3.3288	3.1093	2.8959
Min	.4344	.2865	.2507	.181	.2378	.2534	.181
Avg	1.8797	1.2404	1.3618	.5967	1.3103	1.1515	.9978

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 202 / 11 KV Atpadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7316	.7316	.724	1.0136	.6878	.7602	.9774
2	.7316	.7316	.7682	1.0242	.6626	.8048	.9877
3	.6584	.7316	.7602	1.0498	.6878	.8326	1.0498
4	.724	.7682	.788	1.0974	.724	.8596	1.0974
5	.724	.8048	.8596	1.1765	.7522	.8596	1.3575
6	1.1462	1.0745	1.0498	1.262	.9774	1.2489	1.4266
7	1.3611	1.3253		1.2803	1.2178	1.4632	1.448
8	1.3611	1.3611	1.4118	1.2851	1.3937	1.4118	1.4118
9	1.3611	1.3253	1.2851	1.3169	1.3717	1.3969	1.3535
10	1.5927	1.4327	1.3169	1.267	1.4118	1.4118	1.3756
11	1.39	1.4118	1.3032	1.2437	1.267	1.4632	1.3937
12	1.3169	1.1104	1.2851	1.3032	1.1462	1.3575	1.4083
13	1.3535	1.2308	1.2803	1.3253	1.1222	1.3717	1.4118
14	1.3535	1.182	1.267	1.3032	1.0745	1.267	1.2803
15	1.39	1.1584	1.267	1.3611	1.086	1.0974	1.2308
16	1.39	1.134	1.262	1.4118	1.1104	1.1765	1.2437
17	1.39	1.086	1.2308	1.4266	1.1584	1.2308	1.267
18	1.448	1.2308	1.2986	1.4842	1.3937	1.2127	1.5181
19	1.4327	1.3253	1.2803	1.4632	1.4563	1.1946	1.5203
20	1.3611	1.448	1.2851	1.448	1.4632	1.1584	1.3611
21	1.2178	1.2178	1.2986	1.2489	1.4118	1.1765	1.2308
22	.9412	.9774	1.2489	.9412	.9671	1.0974	1.086
23	.8779	.7964	1.1888	.724	.724	1.0498	
24	.7682	.8048	.7499	1.086	.7164	.7522	1.0498
Max	1.5927	1.448	1.4118	1.4842	1.4632	1.4632	1.5203
Min	.6584	.7316	.724	.724	.6626	.7522	.9774
Avg	1.1676	1.1000	1.1395	1.2310	1.0827	1.1523	1.2820

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 203 / 11 KV Pujarwadi AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366	.4755	.4887	.2715	.0543	.0358	.0724
2	.0366	.4755	.4835	.2743	.0366	.0362	.0732
3	.0366	.439	.4477	.1991	.0362	.0549	.0905
4	.0362	.439	.4525	.2012	.0366	.0543	.0914
5	.0543	.4755	.439	.181	.0543	.0543	.1086
6	.0716	.0716	.0543	.1646	.0537	.0914	.1267
7	.0895	.0895	.0537	.1629	.0724	.1097	.1267
8	.0895	.0895	.0724	.1646	.0716	.0724	.1267
9	.0716	.0716	.0914	.1629	.0537	.0724	.0914
10	.0724	.0362	.1086	.4024	.3982	.2172	.4344
11	.0366	.0358	.1086	.6516	.4572	.2743	.5792
12	.0366	.0362	.1086	.6447	.5068	.362	.5792
13	.0366	.0358	.128	.6878	.4344	.3658	.5373
14	.0366	.0362	.1267	.7164	.3801	.362	.5068
15	.0366	.0362	.1267	.6878	.3658	.362	.5068
16	.0366	.0366	.1267	.6584	.3801	.362	.543
17	.0549	.0362	.1448	.5068	.394	.3658	.6036
18	.0905	.0537	.1463	.0543	.0543	.3801	.0724
19	.1075	.0724	.1448	.0549	.0732	.1267	.0716
20	.0895	.0895	.1463	.0543	.0724	.1267	.0724
21	.0716	.0724	.1448	.0724	.0549	.128	.0724
22	.4163	.5014	.2926	.0549	.0362	.1086	.0549
23	.4938	.543	.3258	.0543	.0358	.1097	
24	.0366	.4938	.4755	.3658	.0549	.0362	.1086
Max	.4938	.543	.4887	.7164	.5068	.3801	.6036
Min	.0362	.0358	.0537	.0543	.0358	.0358	.0549
Avg	.0906	.1976	.2183	.3104	.1737	.1779	.2457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 204 / 11 KV Pujarwadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0732	.1097	.1267	.1075	.1448	.1267
2	.0914	.0732	.0905	.128	.1086	.1433	.128
3	.0732	.0732	.1086	.1267	.1267	.181	.1267
4	.0724	.1097	.1254	.1463	.1433	.1829	.1463
5	.1086	.1097	.1267	.1448	.1433	.181	.1448
6	.1791	.1433	.1448	.1646	.181	.2149	.1646
7	.2149	.2149	.181	.1829	.181	.2172	.1629
8	.1791	.2149	.2149	.1991	.181	.1791	.1433
9	.1791	.2149	.1829	.2195	.1463	.181	.1267
10	.1448	.181		.181	.1448	.181	.1433
11	.1829	.1791	.181	.1791	.1433	.1829	.1448
12	.1829	.181	.181		.181	.181	.1086
13	.1829	.1463	.1829	.2149	.1791	.181	.1086
14	.1829	.1448	.1991	.181	.181	.181	.0724
15	.1463	.1463	.2012	.1433	.1448	.1829	.0716
16	.1463	.1086	.1991	.1448	.1448	.1949	.1086
17	.1463	.1086	.1991	.1433	.1829	.181	.1097
18	.2172	.1463	.2172	.2172	.2172	.2012	.1448
19	.2865	.181	.2012	.2172	.2172	.0181	.2195
20	.2865	.2012	.1991	.2507	.2561	.181	.2172
21	.2865	.181	.1829	.181	.2172	.1629	.2195
22	.2172	.1448	.1629	.1448	.1448	.1448	.181
23	.1097	.1086	.1646	.1448	.1086		
24	.0914	.0914	.1086	.1629	.1075	.1097	.1448
Max	.2865	.2149	.2172	.2507	.2561	.2172	.2195
Min	.0724	.0732	.0905	.1267	.1075	.0181	.0716
Avg	.1666	.1449	.1680	.1715	.1620	.1699	.1419

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 205 / 11 KV Madgule Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.1463	.181	.2896	.181	.1463	.2534
2	.1463	.1463	.1829	.2926	.181	.181	.2561
3	.1463	.1463	.2172	.3077	.1791	.1829	.2534
4	.1448	.1463	.2195	.3109	.2172	.2172	.2743
5	.181	.2195	.2534	.2896	.2172	.2195	.2715
6	.2507	.2507	.2743	.2926	.3224	.2896	.2926
7	.3582	.3582	.3077	.3109	.3258	.3582	.2896
8	.3224	.2865	.3045	.3077	.2865	.2896	.2561
9	.2507	.2149	.2896	.3292	.2172	.2172	.2715
10	.181	.1448	.2896	.2172	.1254	.2172	.2195
11	.1829	.1097	.2896	.1075	.0905	.2195	.1448
12	.1829	.1086	.2743	.1086	.0905	.2534	.1448
13	.1829	.1254	.2715	.1086	.0895	.2561	.1448
14	.1829	.1086	.2926	.1075	.0905	.2715	.1097
15	.1829	.1075	.2896	.1448	.1267	.2743	.0362
16	.1829	.1448	.3109	.1433	.1267	.2715	.1086
17	.1829	.1433	.3077	.181	.1463	.2896	.1097
18	.2534	.181		.2507	.181	.2896	.2172
19	.3224	.2378	.2743	.2534	.2195	.2743	.3658
20	.3224	.2896	.2715	.2743	.2534	.2715	.3077
21	.2865	.2172	.2743	.2353	.2195	.2534	.2534
22	.181	.1791	.2896	.2172	.181	.2534	.1829
23	.1463	.1448	.2926	.1791	.1433	.2534	
24	.1463	.1463	.1463	.2896	.1448	.1448	.2534
Max	.3582	.3582	.3109	.3292	.3258	.3582	.3658
Min	.1448	.1075	.1463	.1075	.0895	.1448	.0362
Avg	.2111	.1793	.2654	.2312	.1815	.2456	.2181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 206 / 11 KV Atpadi AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	1.7558	1.9342	1.2437	.2172	.1463	.1629
2	.1463	1.7558	1.828	1.2308	.1829	.181	.1646
3	.1463	1.6827	1.7737	1.262	.1448	.1829	.1448
4	.1463	1.6827	1.7193	1.267	.1463	.181	.1463
5	.181	1.6827	1.6476	1.267	.181	.1791	.1629
6	.2149		.2172	.1646	.2507	.2172	.1646
7	.2507	.2149	.2195	.1629	.2534	.2561	.181
8	.2149	.2149	.2534	.1629	.2686	.2172	.1829
9	.1791	.1791	.1829	.1646	.2172	.1829	.2172
10		.2149	.1829	1.448	1.2178	.7602	1.4998
11	.1829	.2534	.181	2.5606	1.8823	2.1948	2.1719
12	.1829	.2195	.1629	2.8959	2.2923	2.3529	2.4356
13	.2195	.2172	.1646	2.8654	2.3529	1.9909	2.7511
14	.2195	.2172	.1629	2.9012	2.4143	1.8099	2.8898
15	.1829	.1829	.1646	2.5701	2.3529	1.8099	2.9321
16	.1829	.181	.1448	2.3411	2.2386	1.829	2.7069
17	.1463	.1791	.1448	2.4615	2.1719	1.9909	2.3891
18	.2534	.181	.1463	.2172	.1829	2.0119	.2378
19	.2865	.2195	.1463	.2328	.2195	.2561	.2896
20	.2865	.2172	.1448	.2534	.2172		.2743
21	.2865	.1829	.1448	.2195	.1829	.2534	.2534
22	2.0271	1.4842	1.267	.181	.181	.2743	.2195
23	2.0485	1.8625	1.1888	.1829	.1791	.2561	
24	.1463	1.829	1.8099	1.1765	.1829	.1448	.1991
Max	2.0485	1.8625	1.9342	2.9012	2.4143	2.3529	2.9321
Min	.1463	.1791	.1448	.1629	.1448	.1448	.1448
Avg	.3599	.7309	.6638	1.2264	.8388	.8556	.9903

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 401 / 33 KV Soot Girani

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2922	3.0727	3.0178	3.1276	2.7149	2.8235	2.9321
2	3.2922	3.0727	2.9321	3.095	2.7938	2.9012	2.9081
3	2.9321	3.0298	2.9012	3.0407	2.9321	3.0407	2.8778
4	3.0407	2.963	2.8235	3.0727	2.9321	3.1493	2.8532
5	3.095	2.963	2.9012	2.9864	3.0087	3.3471	2.7692
6	3.0624	2.7938	2.8235	2.963	3.0407	3.0407	2.7984
7	2.9012	2.6863	2.7938	2.9321	2.9081	2.8532	2.7149
8	2.9012	2.5789	2.7149	2.9081	2.7149	2.9321	2.6863
9	2.7938	2.7938	2.8778	2.9321	2.6863	3.0727	2.8235
10	2.7149	2.8235	2.8532	2.7435	3.095	2.9321	2.524
11		2.6337	2.7692	2.3348	2.8532	2.963	2.2262
12	2.7435	2.0633	2.7149	2.7435	2.6063	2.9321	2.6063
13	2.963	2.6863	2.6578	2.8235	2.6863	2.8778	2.9012
14	2.7435	2.8778	2.6606	2.7938	2.9321	2.8532	2.8235
15	2.7435	3.0727	2.6063	2.7149	2.8532	2.8235	2.8235
16	2.8532	3.0407	2.5789	2.8532	2.8235	2.7149	3.1161
17	2.963	3.0178	2.5766	3.0407	2.963	2.7149	3.4208
18	3.095	2.8778	2.6606	2.5789	2.9321	2.7149	2.8235
19	2.9012	2.6863	2.8235	2.7149	2.8235	2.7984	2.6063
20	2.9012	2.552	2.963	2.7435	2.7435	2.7692	2.963
21	2.7938	2.8532	3.0407	2.4977	2.9321	2.8235	3.2579
22	2.8235	2.9321	3.0727	2.7435	2.7401	2.8778	3.4208
23	2.8532	2.9864	3.1493	2.9321	2.6063	2.9321	
24	2.572	2.963	2.8778	3.1824	2.8532	2.7435	2.9321
Max	3.2922	3.0727	3.1493	3.1824	3.095	3.3471	3.4208
Min	2.572	2.0633	2.5766	2.3348	2.6063	2.7149	2.2262
Avg	2.9120	2.8342	2.8246	2.8541	2.8406	2.9013	2.8612

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 201 / 11 KV Nelkaranji AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	03-DEC-17	05-DEC-17	06-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
14				3.0167
15				2.7362
24	.1029	1.5415	.1578	
Max	.1029	1.5415	.1578	3.0167
Min	.1029	1.5415	.1578	2.7362
Avg	.1029	1.5415	.1578	2.8765

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 202 / 11 KV Zare AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	03-DEC-17	05-DEC-17	06-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
14				.0943
15				.0754
24	.6097	.0566	.8573	
Max	.6097	.0566	.8573	.0943
Min	.6097	.0566	.8573	.0754
Avg	.6097	.0566	.8573	.0849

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 203 / 11 KV Zare Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	03-DEC-17	05-DEC-17	06-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
14				.2587
15				.2957
24	.2957	.2534	.2801	
Max	.2957	.2534	.2801	.2957
Min	.2957	.2534	.2801	.2587
Avg	.2957	.2534	.2801	.2772

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 204 / 11 KV Nelkaranji Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	03-DEC-17	05-DEC-17	06-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11		.0905		
14				.1267
15				.1267
24	.1097		.0914	
Max	.1097	.0905	.0914	.1267
Min	.1097	.0905	.0914	.1267
Avg	.1097	.0905	.0914	.1267

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 205 / 11 KV Mitaki AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	03-DEC-17	05-DEC-17	06-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
14				1.5394
15				1.5851
24	.112	.8619	.0914	
Max	.112	.8619	.0914	1.5851
Min	.112	.8619	.0914	1.5394
Avg	.112	.8619	.0914	1.5623

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 206 / 11 KV Walvan AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	03-DEC-17	05-DEC-17	06-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
14				.0754
15				.0943
24	.6706	.0754	.7468	
Max	.6706	.0754	.7468	.0943
Min	.6706	.0754	.7468	.0754
Avg	.6706	.0754	.7468	.0849

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244041 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 201 / 11 KV Zare (Zare) AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.1463	.1227	.1075	.4999	.6859	.5418
2	.3018	.1448	.0876	.1075	.4744	.7545	.5053
3	.2984	.1448	.0867	.1097	.4744	.7282	.5053
4	.3018	.1791	.0857	.1463	.4999	.6344	.4877
5	.503	.197	.0857	.1663	.5937	.7459	.4999
6	.1753	.2715	.1029	.2218	.2427	.2772	.2195
7	.1734	.3475	.1227	.2957	.3326	.3174	.2957
8	.1734	.2587		.2561	.2957	.2353	.2534
9	.1543	.1848	.1612	.181	.2229	.1715	.2286
10	.5468		.6562		.2427	.1341	.156
11	1.6204	1.186	1.07	.1646	.181	.1357	.1341
12	1.7497	1.4232	1.4842		.1509	.12	.1311
13	1.9528	1.6716	1.2955	.1357	.104	.1029	.1543
14	1.8435	1.5779	1.3889	.116	.1357	.1187	.156
15	1.6288	1.5779	1.5851	.1187	.1017	.1174	.1265
16	1.531	1.5741	1.6766	.1372		.1357	.1067
17	1.4723	1.6004	1.3717	.156		.1492	.1543
18	.1696		.1715	.2126	.1227	.1696	.2401
19	.298	.1715	.2587	.3224	.1463	.2926	.2804
20	.2686	.1387	.2587	.2743	.2572	.2561	.2058
21	.1991	.1402	.2033	.2561	.2195	.2241	.2402
22	.181	.1372	.1463	.3658	.6171	.6562	.6099
23	.1629	.1372	.1463	.5624	.6321	.6171	.5256
24	.3353	.1463	.1372	.1267	.5182	.6401	.535
Max	1.9528	1.6716	1.6766	.5624	.6321	.7545	.6099
Min	.1543	.1372	.0857	.1075	.1017	.1029	.1067
Avg	.6824	.6071	.5524	.2064	.3212	.3508	.3039

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244041 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 202 / Vibhutwadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.104	.0739	.1214	.0549	.0905	.1029	.0732
2	.0857	.056	.124	.0543	.0724	.0876	.0724
3	.1029	.0549	.1227	.0549	.0724	.0886	.0724
4	.104	.0732	.104	.0554	.0914	.1029	.0739
5	.1052	.1267	.1402	.0566	.1097	.104	.0934
6	.1791	.1867	.1753	.1494	.168	.1698	.1867
7	.2126	.2033	.1772	.2075	.2033	.2058	.2054
8	.1578	.1867	.0934	.1663	.1848	.1928	.1478
9	.1433	.1463	.1052	.1494	.1006	.1791	.1867
10	.1214		.0914		.1341	.1772	.168
11	.1174	.0867	.1307	.1433	.0838	.1578	.1006
12	.1187	.1029	.0857		.08	.1387	.0857
13	.1174	.1326	.1227	.1086	.0857	.1372	.0876
14	.1174	.0857	.1417	.0876	.0857	.12	.112
15	.1326	.1326	.1372	.0886	.1357	.1372	.1311
16	.1174	.116	.1578	.0895	.1341	.1357	.0995
17	.12	.1174	.1341	.1227	.1802	.125	.1029
18	.1402	.1052	.12	.1734	.1097	.104	.12
19	.181	.124	.1307	.197	.1307	.1448	.1578
20	.1646	.1254	.132	.1829	.1698	.1629	.1433
21	.1663	.1433	.0934	.1646	.132	.1294	.1109
22	.1294	.1417	.0934	.1478	.0924	.0924	.1029
23	.112	.1402	.0747	.128	.1075	.0724	.0943
24	.1086	.0934	.1402	.0549	.0905	.1029	.0724
Max	.2126	.2033	.1772	.2075	.2033	.2058	.2054
Min	.0857	.0549	.0747	.0543	.0724	.0724	.0724
Avg	.1316	.1198	.1229	.1199	.1185	.1321	.1167

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244041 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 203 / 11 KV PIMPARI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.8288	.8288	.6722	.0953	.1143	.0762
2	.0953	.7956	.7545	.6478	.0762	.0953	.0762
3	.0953	.7373	.7459	.6325	.0762	.0953	.0762
4	.1143	.8421	.6706	.6401	.0953	.1143	.0762
5	.1143	.9831	1.0059	.6562	.1143	.1143	.0953
6	.1334	.1715	.1905	.1334	.1334	.1334	.1905
7	.1524	.2096	.2286	.1905	.2477	.1715	.2286
8	.1715	.1715	.1905	.1715	.2286	.1905	.1715
9	.1524	.1524	.1524	.1524	.1524	.1905	.1715
10	.1524		.0857		.9717	.5087	2.3807
11	.1524	.1334	.1524	1.491	2.1051	2.5987	
12	.1524	.1143	.1334		2.1628	2.536	2.6658
13	.1334	.1143	.1143	1.7204	1.6244	1.0059	2.42
14	.1334	.1143	.1334	1.587	2.4646	2.4531	2.4034
15	.1143	.1143	.0762	1.3763	2.3975	2.5692	2.3205
16	.1143	.1334	.1334		2.1548	2.6379	2.2377
17	.1334	.1334	.1524		1.6549	2.13	2.1216
18	.1524	.1524	.1524	1.3108	.1334	.1143	.1715
19	.1905	.1524	.1905	.1715	.1334	.2096	.1905
20	.1715	.1334	.1524	.1524	.1524	.1715	.1715
21	.1334	.1334	.1334	.1524	.1334	.1524	.1524
22	.5668	1.0059	.7522	.1334	.0953	.1143	.1334
23	.9995	.9945	.7202	.1143	.1143	.1143	.1334
24	.1143	.9012	.8383	.7042	.0953	.1143	.0953
Max	.9995	1.0059	1.0059	1.7204	2.4646	2.6379	2.6658
Min	.0953	.1143	.0762	.1143	.0762	.0953	.0762
Avg	.1899	.4010	.3620	.6405	.7339	.7771	.8156

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 201 / 11 KV Hivtad AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	1.8404	1.8564	1.6324	.104	.1006	.128
2	.1052	1.8185	1.9006	1.6129	.1052	.1017	.1294
3	.1063	1.7869	1.9448	1.6712	.1097	.12	.1478
4	.1254	1.8351	1.9204	1.5912		.1227	.1867
5	.1494	1.8351	1.9631	1.5074	.1387	.1867	.2241
6	.1886	.2743	.2835	.2561	.1715		.2587
7	.2427	.2481	.2507	.2294	.2427	.2614	.2957
8	.1848	.2172	.2103	.192	.1848	.2012	.2172
9	.1663	.1402	.1417	.0926	.1772	.1387	.1772
10	.1463		.1254	.9488	1.5249	1.6766	
11	.0905			2.3205	2.1548	2.3594	
12	.1063				2.4905	2.3594	
13	.104		.0823	3.1493	2.5888	2.652	
14	.1063		1.07	3.0498	2.3594	2.7846	
15	.1086			2.9504	2.4531	2.652	
16	.0857		.0869	2.556	2.4577	2.556	
17	.1052		.0983	2.4577		2.4577	
18	.1772		.1147	.156	.2229	.2103	
19	.2629		.2486	.2572	.208	.2865	
20	.2172		.1966	.2103	.2507	.2507	
21	.1829		.1677	.1772	.2126		
22	2.1548		1.6842	.1402	.1433		
23	2.0481		1.6804	.1017	.1097		
24	.0983	1.8564	1.8564	1.6518	.1029	.0983	.1433
Max	2.1548	1.8564	1.9631	3.1493	2.5888	2.7846	.2957
Min	.0857	.1402	.0823	.0926	.1029	.0983	.128
Avg	.3069	1.1852	.8516	1.2570	.8415	1.0788	.1908

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 202 / 11 KV Shetphale AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2125	.1848	.1791	.1629	1.491	.9877	1.2929
2	1.2125	.1829	.1772	.1646	1.491	1.0242	1.2266
3	1.2125	.1848	.1734	.168	1.4737	.9804	1.1469
4	1.2944	.2402	.2229	.2195	1.4922	1.0159	1.2125
5	1.4255	.2987	.2743	.3206	1.4746	.9717	1.2597
6	1.5746	.3734	.3506	.3734	.3121	.373	.3734
7	.3395	.3361	.3326	.3292	.3506	.3772	.415
8	.3018	.2801	.2715	.2686	.3018	.2772	.3174
9	.2241	.2587	.2378	.2012	.2241	.2241	.2241
10	1.6766		1.6651	.1848		.2427	
11	2.3205		2.4714	.1646	.1772	.2402	
12	2.8178		2.3232	.1646		.1848	
13	2.5692		2.2672	.1448		.1848	
14	2.4577		2.3266	.1433		.1829	
15	2.2939		2.2725	.1595		.1829	
16	2.3205		2.3482	.1753		.1829	
17	2.4863		2.3868	.2103		.181	
18	.2686		2.3868	.3121	.2835	.2896	
19	.3658		.2458	.3582	.3224	.3734	
20	.3511		.3239	.3439	.3045	.2987	
21	.3326		.3149	.2743	.2801		
22	.2614		.1886	1.6118	1.2136		
23	.1867		.1829	1.5074	1.2308		
24	1.2125	.1867	.1791	.1612	1.4737	.9877	1.3108
Max	2.8178	.3734	2.4714	1.6118	1.4922	1.0242	1.3108
Min	.1867	.1829	.1734	.1433	.1772	.181	.2241
Avg	1.2799	.2526	1.0043	.3385	.8175	.4649	.8779

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 203 / 11 KV Banpuri AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2651	.1052		.12	1.3599	1.3916	1.065
2	1.2955	.1063		.1254	1.3599	1.4083	1.065
3	1.3108	.124	.1254	.128	1.3599	1.3603	.9614
4	1.3599	.1433	.1448	1.7737	1.4091	1.2803	.9945
5	1.6244	.2195	.181	.2241	1.3923	1.1012	.9831
6	.2263	.2561	.2561	.2561	.2058	.3086	.2149
7	.2987	.2926	.2804	.2865	.2865	.2987	.2743
8	.2195	.2896	.2835	.2865	.2172	.2587	.2195
9	.1829	.208	.2454	.1791		.1772	.2195
10			1.9418	.1063		.1417	
11	2.2801		2.332	.104		.1227	
12	2.7496		2.4756	.0857		.1372	
13	2.6825		2.4691	.1029		.124	
14	2.7664		2.4006	.104		.1227	
15	2.431		2.2283	.12		.1052	
16	2.4531		2.1052	.1357		.1402	
17	2.536		2.0885	.1492		.1387	
18	.2279		.2294	.2058	.2328	.2103	
19	.2896		.2683	.2835	.2629	.2743	
20	.2402		.2279	.2328	.2303	.2195	
21	.2195		.2126	.1829	.2149		
22	.1791		.1402	1.3272	1.6804		
23	.1417		.1402	1.4083	1.6385		
24	1.2651	.1214		.1214	1.3599	1.3748	1.0242
Max	2.7664	.2926	2.4756	1.7737	1.6804	1.4083	1.065
Min	.1417	.1052	.1254	.0857	.2058	.1052	.2149
Avg	1.2280	.1866	.9893	.3354	.8807	.5093	.7021

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 204 / 11 KV Hivtad Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0895	.0867	.0876	.0895	.0857	.0924
2	.0914	.0914	.0867	.0886	.0914	.0867	.0914
3	.0914	.1097	.0857	.0876	.0895	.1063	.1109
4	.0905	.1109	.1052	.1254	.0747	.1075	.1307
5	.1097	.1294	.1254	.168	.1097	.132	.1509
6	.128	.1848	.181	.1829	.128	.1867	.1886
7	.1848	.2241	.2149	.2035	.181	.2263	.2427
8	.2012	.1867	.1829	.1715	.2012	.1791	.1867
9	.1463	.1402	.1433	.144	.1829	.1372	.1463
10	.1433		.124	.1029	.1294	.1052	
11	.1402		.1214	.1029	.1075	.0857	
12	.0886		.0983	.0126	.0876	.0857	
13	.0876		.1014	.0876	.0857	.0886	
14	.104		.1174	.1063	.0876	.1063	
15	.12		.096	.1075	.0886	.1075	
16	.1402		.1067	.12	.0876	.1052	
17	.1417		.1107	.1027		.1029	
18	.1791		.0949	.1417	.1829	.1478	
19	.2378		.208	.2328	.1829	.2241	
20	.2054		.1802	.1949	.1478	.2033	
21	.1848		.1677	.1448	.1294		
22	.1478		.104	.1254	.1097		
23	.0914		.1052	.0876	.0924		
24	.0914	.0886	.0886	.0886	.0886	.0838	.0934
Max	.2378	.2241	.2149	.2328	.2012	.2263	.2427
Min	.0876	.0886	.0857	.0126	.0747	.0838	.0914
Avg	.1349	.1355	.1265	.1257	.1198	.1283	.1434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 205 / 11 KV Shetphale Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1886	.1753	.2012	.2012	.2263
2	.1886	.1886		.1734	.197	.197	.2452
3	.1886	.1867	.1867	.1715	.2012	.2254	.2641
4	.1886	.2614	.2587	.3052	.2378	.2743	.3018
5	.2641	.3734	.3658	.4527	.2896	.3395	.3772
6	.4338	.5175	.5014	.5121	.4119	.4854	.5281
7	.5093	.4854	.4854	.4656	.4938	.5658	.4904
8	.415	.4527	.4435	.4252	.415	.4572	.415
9	.3395	.3658	.3292	.2772	.2987	.3696	.3361
10	.2987		.2865	.2772	.2263	.3326	
11	.2587		.2658	.2195	.2054	.2561	
12	.2195		.2454	.197	.1848	.2561	
13	.2149		.2149	.1734		.2378	
14	.2328		.2149	.1629		.2353	
15	.2481		.2195	.1791		.2172	
16	.2507		.2353	.2126	.2149	.2328	
17	.2715		.2534	.2254		.2172	
18	.3658		.2865	.3582	.3658	.3658	
19	.5041		.4784	.4938	.439	.5544	
20	.4294		.4119	.4119	.394	.4338	
21	.3734		.362	.3734	.3772		
22	.2801		.2263	.2957	.2987		
23	.2241		.2012	.2641	.2641		
24	.1886	.1886	.1886	.1791	.2054	.2075	.2263
Max	.5093	.5175	.5014	.5121	.4938	.5658	.5281
Min	.1886	.1867	.1867	.1629	.1848	.197	.2263
Avg	.2949	.3209	.2978	.2909	.2961	.3172	.3411

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 206 / 11 KV Banpuri Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.128	.1075	.12	.1075	.1086	.1267	.112
2	.1294	.1086	.1214	.1097	.1086	.1267	.1109
3	.128	.1097	.1227	.1109	.1075	.128	.1294
4	.1463	.1463	.1417	.168	.124	.1463	.1307
5	.1663	.1848		.2054	.1646	.1478	.1494
6	.2241	.2427		.2378	.2126	.2149	.1867
7	.2614	.2241		.2149	.2427	.2427	.2241
8	.2033	.1848	.1753	.1772	.2033	.2218	.2427
9	.1829	.1772	.1886	.1949	.2149	.1991	.1463
10			.1715	.197	.2058	.1829	
11	.1734		.1387	.1753	.1753	.1612	
12	.1753		.1402	.1543	.1402	.1791	
13	.1791		.1227	.1372	.1463	.1417	
14	.1578		.12	.1341	.1417	.1433	
15	.1387		.1402	.1526	.1433	.1417	
16	.1734		.1772	.1715	.1402	.1372	
17	.1829		.1907	.1844		.1829	
18	.2033		.2279	.1772	.208	.1772	
19	.2378		.2303	.2328	.2507	.2195	
20	.2172		.2103	.2172	.2126	.1829	
21	.1791		.1734	.1829			
22	.1612		.1267	.1463	.1629		
23	.1448		.1254	.1294	.128		
24	.1267	.124	.1227	.1063	.1097	.1254	.1132
Max	.2614	.2427	.2303	.2378	.2507	.2427	.2427
Min	.1267	.1075	.12	.1063	.1075	.1254	.1109
Avg	.1748	.1610	.1566	.1677	.1660	.1680	.1545

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 207 / 11 KV GOMEWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	1.0898	1.1096	.8048	.048	.052	
2	.0549	1.073	1.1096	.7956	.048	.052	
3	.0549	1.0174	1.1096	.7773	.0486	.0686	
4	.0732	.9156	.9465	.7373	.0655	.0686	
5	.0905	.8383	.8954	.7625	.0857	.0762	
6	.0914	.1219	.1372	.1372	.1097	.12	.0762
7	.124	.104	.1187	.1227	.1267	.1017	.0594
8	.0914	.0823	.1029	.1075	.0914	.0914	.08
9	.0914	.0564	.0678	.0924	.0876	.0924	.0648
10	.0667		.0686	1.0745	1.094	.9431	
11	.0457		.0876	1.7833	1.4255	1.3757	
12	.0472		.0716	1.7924	1.643	1.3757	
13	.0343		.0732	1.7004	1.643	1.6263	
14	.0389		.0732	1.6712	1.6766	1.6409	
15	.04		.0554	1.7328	1.576	1.5746	
16	.0412		.056	1.6804	1.4419	1.3904	
17	.0423		.0532	1.6324		1.3032	
18	.08		.0532	.0914	.0743	.0934	
19	.1036		.1433	.1448	.128	.1036	
20	.0854		.128	.128	.12	.088	
21	.0709		.1075	.124	.1063		
22	1.2574		.8383	.0876	.0895		
23	1.1233		.8288	.0412	.0406		
24	1.5432	1.0608	1.1096	.7865	.048	.0526	
Max	1.5432	1.0898	1.1096	1.7924	1.6766	1.6409	.08
Min	.0343	.0564	.0532	.0412	.0406	.052	.0594
Avg	.2228	.6360	.3894	.7837	.5138	.5853	.0701

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244081 / 33/11 KV Lingiware

Feeder No / Name : 201 / 11 KV Palaskhel

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9134	.0953	.1143	.0572	1.0288	.9774	.8842
2	.8859	.0762	.1143	.0572	1.0277	.9568	.8682
3	.8859	.0762	.0953	.0572	.9362	.9391	.8589
4	.8869	.0953	.0953	.0572	.9671	.9015	.8402
5	.8962	.1143	.0953	.0572	.9945	.9313	.8495
6	.1524	.1143	.0762	.0762	.0953	.0762	.1524
7	.1524	.0953	.0762	.1334	.1143	.1143	.1334
8	.1524	.0953	.0953	.1334	.1334	.1143	.1334
9	.1143	.0953	.1143	.1143	.1143	.1143	.1143
10	1.1222	.8413	.8993	.0762	.0762	.0953	.1143
11	1.643	1.643	1.6301	.0762	.0572	.0762	.0762
12	1.7002	1.7551	1.8073	.0572	.0572	.0762	.0381
13	1.7556		1.8004	.0572	.0572	.0762	.0572
14	1.6804	1.9605	1.5261	.0762	.0572	.0762	.0572
15	1.8267	1.7833	1.5424	.0762	.0572	.0572	.0572
16	1.8111	1.9105	1.5581	.0572	.0572	.0572	.0381
17	1.7551	1.7551	1.5074	.0762	.0572	.0572	.0762
18	.0953	.0762	.0953	.0762	.0762	.0572	.0572
19	.1143	.1143	.0953	.1143	.1334	.1524	.1524
20	.0953	.1143	.1143	.1143	.1334	.1524	.1524
21	.0953	.0762	.0953	.0953	.1143	.1143	.1143
22	.0762	.0953	.0762	1.0566	.9114	.8939	.8682
23	.0762	.0953	.0762	1.1104	1.0719	.9189	.929
24	.9568	.0953	.0762	.0762	1.0867	1.0166	.9568
Max	1.8267	1.9605	1.8073	1.1104	1.0867	1.0166	.9568
Min	.0762	.0762	.0762	.0572	.0572	.0572	.0381
Avg	.8268	.5727	.5740	.1641	.3923	.3751	.3575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244081 / 33/11 KV Lingiware

Feeder No / Name : 202 / 11 KV Rajewadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	1.1765	1.1576	1.0631	.0953	.0953	.0572
2	.0953	1.2894	1.2094	.9882	.0953	.0762	.0572
3	.0953	1.258	1.2803	1.0099	.0953	.0762	.0572
4	.1143	1.2517	1.1831	.9259	.0953	.0762	.0572
5	.1143	1.2483	1.2715	1.0517	.0953	.0953	.0572
6	.1334	.0953	.1143	.1143	.1334	.1143	.0953
7	.1334	.0953	.0953	.1143	.1334	.1143	.1143
8	.1334	.0762	.0953	.0953	.0953	.0953	.1143
9	.1143	.1143	.0953	.0762	.0572	.0953	.1143
10	.0953	.0953	.0953	.7343	.25	.9503	.8238
11	.0953	.1143	.0762	1.4815	.9389	1.5581	1.4529
12	.1143	.1143	.0762	1.825	1.4563	1.5769	1.7013
13	.0953		.0762	2.1437	1.5415	1.7684	1.595
14	.1143	.0572	.0953	2.0271	1.6461	1.8551	1.6297
15	.1143	.0953	.0953	1.8204	1.7194	1.869	1.6804
16	.1334	.1143	.0953	1.7372	1.7703	1.701	1.7164
17	.1334	.1334	.0953	1.7187	1.7737	1.4074	1.5083
18	.0953	.1524	.0953	.0953	.0953	.1143	.1334
19	.0953	.1143	.0953	.1143	.0572	.1334	.1524
20	.1143	.0953	.1334	.1334	.0572	.1334	.1524
21	.1143	.0953	.1334	.1334	.1143	.1143	.1143
22	1.0829	1.0456	1.0576	.1143	.0953	.0953	.1143
23	1.2003	.9774	1.0802	.1143	.0762	.0953	.1143
24	.0953	1.1393	1.1218	1.0924	.1143	.0953	.0762
Max	1.2003	1.2894	1.2803	2.1437	1.7737	1.869	1.7164
Min	.0953	.0572	.0762	.0762	.0572	.0762	.0572
Avg	.1968	.4760	.4552	.8635	.5251	.5961	.5704

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244081 / 33/11 KV Lingiware

Feeder No / Name : 203 / 11 KV Dhole Mala,
Dighanchi Feeder KV- 11 /
OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8215	.0572	.0953		.9313	.7455	.7602
2	.7842	.0572	.0762	.0762	.8413	.7421	.6984
3	.7922	.0762	.0762	.0572	.7888	.7362	.6984
4	.7762	.0762	.0762	.0572	.7975	.6859	.7059
5	.7577	.0762	.0953	.0572	.8688	.7265	.6733
6	.1143	.0572	.0953	.0762	.0762	.0762	.1143
7	.0953	.0572	.1143	.0953	.0953	.0953	.1143
8	.0953	.0762	.0953	.0953	.1143	.0953	.0953
9	.1143	.0762	.1143	.1143	.0762	.0953	.0953
10	.9896	.8029	.7537	.0953	.0953	.0572	.0953
11	1.3672	1.4864	1.4217	.0953	.0762	.0762	.0762
12	1.4746	1.5249	1.5238	.0953	.0762	.0762	.0762
13	1.576		1.5604	.0953	.0572	.0953	.1143
14	1.5415	1.6301	1.4685	.0953	.0572	.0953	.1143
15	1.5775	1.701	1.387	.1143	.0762	.0953	.1143
16	1.4737	1.7737	1.4148	.1143	.0762	.1143	.0762
17	1.531	1.439	1.382	.0953	.0762	.1143	.1143
18	.1143	.1143	.0762	.0953	.0762	.1143	.0953
19	.0953	.1143	.0762	.1143	.0953	.1334	.1143
20	.0762	.0953	.0953	.0953	.0953	.1334	.1334
21	.0953	.0953	.0953	.0953	.0762	.1143	.0953
22	.0762	.0762	.0762	.8764	.7442	.7865	.7133
23	.0762	.0762	.0762	.9214	.823	.7783	.7343
24	.8686	.0572	.0953	.0762	.9465	.8059	.788
Max	1.5775	1.7737	1.5604	.9214	.9465	.8059	.788
Min	.0762	.0572	.0762	.0572	.0572	.0572	.0762
Avg	.7202	.5042	.5142	.1610	.3349	.3162	.3088

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244081 / 33/11 KV Lingiware

Feeder No / Name : 204 / 11 KV Rajewadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0924	.0886	.0876	.0514	.0514	.052	.1086
2	.0924	.0857	.0895	.0532	.0514	.0537	.0895
3	.0905	.0867	.0886	.052	.0526	.056	.0905
4	.0914	.0914	.104	.0497	.0486	.0497	.0914
5	.1109	.0895	.1052	.0537	.052	.0724	.1097
6	.1646	.0934	.0924	.0924	.1463	.1132	.1478
7	.181	.1052	.0895	.1509	.1494	.1646	.1829
8	.1829	.1029	.128	.156	.0886	.1075	.1991
9	.104	.0867	.1478	.1075	.1086	.0857	.156
10	.1132	.1109	.0716	.0701	.0537	.1006	.1341
11	.112	.112	.0701	.0514	.0514	.1006	.0983
12	.0867	.132	.0492	.052	.0532	.1174	.0655
13	.0895		.0693	.0366	.0549	.1017	.08
14	.0747	.0724	.064	.0716	.0532	.0701	.08
15	.0732	.0895	.0686	.0343	.0526	.0526	.0663
16	.0857	.1052	.0532	.0351	.0549	.0514	.0492
17	.104	.0747	.0347	.056	.0526	.0602	.0838
18	.1307	.1254	.0716	.0543	.0543	.0829	.0867
19	.1387	.1433	.12	.1227	.1494	.1677	.1791
20	.1402	.1402	.1227	.1646	.1698	.1949	.197
21	.1372	.1214	.0724	.1227	.1227	.181	.1463
22	.104	.1254	.1109	.0914	.1075	.168	.1478
23	.1097	.1052	.0716	.0543	.0693	.128	.1463
24	.0914	.0895	.0934	.0526	.0709	.0543	.1086
Max	.1829	.1433	.1478	.1646	.1698	.1949	.1991
Min	.0732	.0724	.0347	.0343	.0486	.0497	.0492
Avg	.1125	.1034	.0865	.0765	.0800	.0994	.1185

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244106 / 33/11 KV Pujarwadi

Feeder No / Name : 201 / 11 KV Kauthuly

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3205	.2035	.1478	.181	2.5072	2.2382	.7377
2	2.4249	.2229	.1478	.1646	2.4356	2.1795	.7888
3	2.5434	.2058	.1494	.1646	2.3891	2.1963	.9114
4	2.4905	.2035	.1494	.1848	2.2986	2.2552	.9816
5	2.6189	.2229	.1478	.2172	2.5072	2.2119	1.1584
6	.2401	.2772	.2241	.2481	.2534	.2614	.1494
7	.2427	.2614	.2987	.2835	.3045	.2772	.1478
8	.2507	.2987	.2957	.2804	.2481	.2561	.1433
9	.2195	.2835	.2172	.298	.2454	.2279	.1433
10	1.6933	1.5927	1.2269	.2947		.2058	.1478
11		3.5482	3.2579	.2401	.2155	.1989	.1509
12		3.9232	2.6825	.2035	.218	.2012	.1509
13	3.3482	3.5482	3.315	.1677	.1989	.1989	.1509
14	3.3573	3.4743	3.1161	.1509	.1677	.2012	.1341
15	2.7161	3.4355	2.9492	.1865	.1658	.2012	.1509
16			3.0498	.2374	.1677	.2012	.1509
17	3.4421	1.7193	2.8502	.2401	.2035	.1989	.1509
18	.181	.2149	.1886	.2427	.2303	.2149	.2195
19	.3142	.2926	.2427	.2804	.2896	.2926	.2896
20	.3326	.2172	.2629	.2481	.2743	.2926	.2172
21	.2926	.2172	.2481	.2149	.2743	.2195	.2195
22	.2058	.1848	.2126	2.4348	2.2043	2.4691	2.5652
23	.1865	.1463	.2149	2.5486	2.1704		2.5274
24	2.3594	.2058	.1494	.1991	2.5514	2.2466	
Max	3.4421	3.9232	3.315	2.5486	2.5514	2.4691	2.5652
Min	.181	.1463	.1478	.1509	.1658	.1989	.1341
Avg	1.5133	1.0826	1.0727	.4130	.9792	.8455	.5386

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244106 / 33/11 KV Pujarwadi

Feeder No / Name : 202 / 11 KV Nimbawade

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1646	1.2209	1.4045	1.134	.1267	.1357	.1341
2	.1791	1.2174	1.386	1.0985	.1097	.1174	.1372
3	.1949	1.1831	1.4003	1.0745	.1097	.1341	.1402
4	.1791	1.153	1.3817	1.0745	.1294	.1357	.1402
5	.1949	1.1831	1.3676	1.1517	.1629	.1543	.181
6	.1734	.2402	.2241	.1949	.2328	.2033	.2241
7	.1829	.2241	.2241	.2126	.2303	.2218	.2587
8	.1646	.1494	.1848	.1928	.1928	.2012	.1791
9	.1433	.1417	.1448	.1928	.1578	.1928	.1791
10	.1174	.1174	.1417	.7802	1.094	1.2003	1.1088
11	.1341	.1478	.1387	2.5095	2.3205	1.9559	2.5652
12		.1509	.1372	2.5316	2.364	2.2466	2.7538
13	.0995	.1478	.1357	2.536	2.304	2.3205	1.6221
14	.1187	.1478	.1174	2.4366	2.3137	2.3137	2.3807
15	.1341	.1494	.1326	2.5149	2.1548	2.2466	2.6217
16	.1509		.1492	2.5316	2.1125	2.2801	2.5652
17	.1696	.1463	.1509	1.95	1.933	2.0885	2.4897
18	.1629	.1791	.1715	.1715	.1772	.2149	.2195
19	.2033		.1907	.208	.1991	.2195	.181
20	.1848	.2534	.1928	.2279	.1829	.2195	.181
21	.1646	.181	.1772	.1595	.1829	.1829	.1829
22	1.3546	1.4415	1.1317	.1595	.1357	.1715	.1509
23	1.2887	.1463	1.1963	.1433	.1357	.1578	.1509
24	.1646	1.2689	1.4563	1.1568	.1267	.1341	.1402
Max	1.3546	1.4415	1.4563	2.536	2.364	2.3205	2.7538
Min	.0995	.1174	.1174	.1433	.1097	.1174	.1341
Avg	.2619	.5087	.5557	1.0976	.7995	.8104	.8703

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244106 / 33/11 KV Pujarwadi

Feeder No / Name : 203 / 11 KV Kauthuly Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.197	.1017	.0924	.0905	.0905	.0848	.0503
2	.1595	.1029	.0924	.0732	.0732	.1006	.0514
3	.1214	.0857	.112	.0732	.0914	.0838	.0526
4	.1595	.0848	.112	.0924	.1109	.1017	.0526
5	.1402	.1543	.1294	.1109	.1294	.1372	.0543
6	.1772	.3326	.1867	.1267	.1448	.168	.0747
7	.2378	.2427	.2241	.1949	.2126	.2218	.0739
8	.1791	.168	.1848	.1753	.2103	.2012	.1254
9	.1612	.1595	.1991	.1753	.2454	.1578	.1254
10	.1341	.1174	.1595	.1387	.2486	.1543	.1848
11	.1677	.1294	.1387	.12	.2652	.1326	.1509
12		.1509	.1372	.0848	.1341	.1341	.1509
13	.0663	.1294	.1357	.0678	.0995	.1326	.0754
14	.1187	.0924	.1174	.0838	.1006	.1341	.1006
15	.1341	.112	.116	.1006	.1326	.1341	.1509
16	.1677		.1492	.1187	.1341	.1006	.2075
17	.1526	.128	.1509	.1372	.1865	.1492	
18	.181	.1612	.1543	.156	.2303	.1791	
19	.2402	.2378	.1907	.1928	.181	.2012	.3077
20	.1848	.181	.1753	.1772	.1646	.2195	.2896
21	.1463	.1629	.1417	.1254	.128	.2561	.2926
22	.12	.1663	.124	.1075	.1017	.2229	.1509
23	.0848	.1509	.1075	.1086	.1017		.132
24	.1791	.0686	.0934	.0905	.0905	.0838	
Max	.2402	.3326	.2241	.1949	.2652	.2561	.3077
Min	.0663	.0686	.0924	.0678	.0732	.0838	.0503
Avg	.1570	.1487	.1427	.1218	.1503	.1518	.1359

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244106 / 33/11 KV Pujarwadi

Feeder No / Name : 204 / Nimbawade Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1791	.1696	.1478	.1791	.1448	.1526	.1341
2	.2126	.1543	.1478	.1629	.1463	.1341	.1372
3	.208	.1543	.1494	.1463	.1294	.1509	.1578
4	.2195	.1696	.168	.1463	.1294	.1696	.1578
5	.1791	.2401	.1848	.1629	.1629	.1886	.181
6	.1886	.3326	.2614	.197	.2149	.2241	.2241
7	.2481	.2801	.2987	.2303	.3012	.2587	.2587
8	.2229	.2427	.2587	.2454	.298	.2378	.2507
9	.1734	.2126	.2172	.2629	.2254	.2103	.2686
10	.1677	.1844	.2126	.2774	.2321	.1886	.2587
11	.1844	.1848	.208	.2401	.2486	.1658	.2263
12		.1886	.2229	.2204	.2012	.1677	.1886
13	.1492	.1848	.1865	.2035	.1658	.1658	.1509
14	.1526	.1848	.1677	.218	.1677	.1677	.1677
15	.1677	.1867	.1492	.218	.1658	.1677	.2263
16	.1844		.1492	.2374	.1509	.1677	.2263
17	.2035	.1791	.1844	.2915	.2204	.1989	.2263
18	.2353	.2149	.2229	.3294	.2481	.2149	.2926
19	.2587	.2926	.2601	.3681	.2172	.2743	.2896
20	.2402	.2534	.298	.4031	.2012	.2926	.2715
21	.2378	.2172	.2481	.3544	.2012	.2926	.2743
22	.1886	.1848	.2126	.2835	.1696	.2572	.1886
23	.1526	.1886	.197	.2328	.1526	.2103	.1698
24	.2229	.1372	.168	.1991	.1629	.1509	.1753
Max	.2587	.3326	.2987	.4031	.3012	.2926	.2926
Min	.1492	.1372	.1478	.1463	.1294	.1341	.1341
Avg	.1990	.2060	.2050	.2421	.1941	.2004	.2126

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 201 / 11 KV Vithalapur

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17
HR	Load (MW)
24	1.5432
Max	1.5432
Min	1.5432
Avg	1.5432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 202 / 11 KV Dighanchi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17
HR	Load (MW)
24	1.5432
Max	1.5432
Min	1.5432
Avg	1.5432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 203 / 11 KV Rajewadi AG

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	1.5432
Max	1.5432
Min	1.5432
Avg	1.5432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 204 / 11 KV Rajewadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	1.2003
Max	1.2003
Min	1.2003
Avg	1.2003

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 205 / 11 KV Dighanchi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	1.4575
Max	1.4575
Min	1.4575
Avg	1.4575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 406 / 110 KV SADGURU SUGAR

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

FACTORY C Feeder KV- 132 /

(CONTINUOUS PROCESS)(NO STAGGERING

OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	10.2881
Max	10.2881
Min	10.2881
Avg	10.2881

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 201 / 11 KV Gorewadi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	1.1736	1.0004	.9995	.0857	.0709	.0716
2	.0876	1.1869	.9937	.9667	.0857	.0716	.0716
3	.0876	1.1869	.9816	.9503	.0876	.0532	.0716
4	.0895	1.2209	.9568	.9503	.1227	.0724	.0716
5	.1227	1.3413	.8573	.9667	.1214	.0895	.0716
6	.1715	.1543	.1417	.1402	.1715	.1433	.1433
7	.1886	.1715	.197	.2126	.1677	.2012	.2303
8	.2058	.1886	.181	.2279	.1715	.2218	.1772
9	.1526	.1357	.1463	.1402	.1696	.1629	.1402
10	.1372	.1372	.1372	.7796	.7042	.8573	.9496
11	.0848	.12	.12	1.8347		1.4737	1.576
12	.0678	.1029	.1017	1.8442		1.5769	1.757
13	.0678	.1029	.0848	1.9559	1.7368	1.8652	1.7974
14	.0857	.1029	.0848	1.9281	1.8351	1.8442	1.861
15	.0867	.1029	.0686	1.8515	1.8187	1.8652	1.7901
16	.0867	.1029	.0678	1.9662	1.6712	1.8442	1.8107
17	.1029	.1029	.1029	1.8233	1.491	1.7974	1.7924
18	.1357	.1715	.1578	.1372	.1372	.1387	.12
19	.1715	.1907	.2103	.2035		.1928	.1715
20	.2058	.1848	.2126	.2035	.1753	.1928	.1715
21	.1677	.1595	.1772	.1715	.1595	.1772	.1543
22	1.6617	1.4754	1.2944	.1187	.1052	.124	.12
23	1.4403	1.2548	1.1797	.1017	.0686	.0716	.0857
24	.0857	1.1736	.9724	1.0322	.0857	.0693	.0716
Max	1.6617	1.4754	1.2944	1.9662	1.8351	1.8652	1.861
Min	.0678	.1029	.0678	.1017	.0686	.0532	.0716
Avg	.2408	.5102	.4345	.8961	.5320	.6324	.6366

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 202 / 11 KV Bhivghat AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7461	.0678	.0716	.0709	.8383	.8916	.7459
2	.7122	.0671	.0724	.0716	.8383	.8842	.7459
3	.6706	.0678	.0716	.0537	.8288	.8573	.7459
4	.6706	.0678	.0724	.0537	.8288	.8573	.7625
5	.6706	.0838	.0895	.0532	.9054	.8095	.7865
6	.1017	.0838	.1097	.1227	.0848	.1267	.104
7	.1017	.1017	.1109	.124	.1017	.1433	.1227
8	.1187	.1017	.128	.1227	.0838	.0886	.0876
9	.0848	.1017	.0905	.0867	.0848	.0876	.0857
10	.57	.7461	.6783	.0686	.1017	.0848	.0848
11	1.4255	1.153	1.2887	.0693	.1017	.0678	.0867
12	1.6549	1.3904	1.5261	.0876	.0857	.1017	.0857
13	1.6876	1.4243	1.5261	.0709	.0857	.0848	.0867
14	1.4419	1.4243	1.5261	.1052		.0678	.0876
15	1.5729	1.3904	1.5261	.0848		.0678	.0686
16	1.3435	1.4582	1.5261	.0867	.0678	.0848	.0693
17	1.3927	1.3565	1.4582	.0686	.0857	.0848	.0686
18	.1017	.104	.0867	.1029	.104	.0857	.0857
19	.1187	.124	.1227	.1357		.104	.1029
20	.1017	.1075	.1052	.1187	.124	.0876	.1029
21	.1017	.1086	.1063	.1017	.1063	.0876	.1029
22	.0678	.0701	.0709	1.0852	.8573	1.0227	.6783
23	.0678	.0686	.0709	.9665	.763	.9116	.6613
24	.7461	.0678	.0701	.0709	.9221	.9088	.7625
Max	1.6876	1.4582	1.5261	1.0852	.9221	1.0227	.7865
Min	.0678	.0671	.0701	.0532	.0678	.0678	.0686
Avg	.6780	.4890	.5210	.1659	.3809	.3583	.3051

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 203 / 11 KV Khanapur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1361	.0509	.0876	.0886	1.1022	.9313	.2204
2	1.1022	.0671	.0895	.0716	1.1022	.8939	.2035
3	1.0898	.0678	.0886	.0716	1.1022	.8495	.2035
4	1.1022	.0671	.0905		1.0898	.8413	.2035
5	1.1736	.0848	.1097	.0709	1.1568	.8764	.2035
6	.1174	.1017	.1267	.1254	.1006	.0895	.0173
7	.1187	.1174	.128	.1254	.1006	.12	.0175
8	.1174	.1174	.1086	.124	.1006	.0876	.0351
9	.1174	.1187	.1433	.1227	.0838	.0886	.0351
10	.7625	.9835		.1029	.1187	.0678	.0177
11	1.8842	1.6617	1.8442	.0848		.0671	.3561
12	2.1136	1.9669	2.0856	.0693	.1187	.0678	.104
13	2.1956	2.0348	1.861	.0686	.1017	.0503	
14	2.2283	2.0687	1.8652		.1029	.0509	.0867
15	2.13	2.0008	1.8442	.0686	.0848	.0671	.0686
16	1.7695	2.0008	1.8442	.0867	.0848	.0848	.0572
17	1.7859	1.9669	1.8482	.0693	.1187	.1017	
18	.1017	.1387	.104	.0838	.104	.0867	.12
19	.1006	.1214	.1052	.1017		.1052	.12
20	.1017	.124	.1052	.1006	.0886	.1052	.1029
21	.1006	.1263	.1063	.0848	.0701	.0876	.1029
22	.0678	.0709	.0709	1.1568	1.1694		1.0174
23	.0671	.0867	.0886	1.2407	.9339	.2374	1.0852
24	1.1361	.0503	.0886	.0886	1.1869	.9745	.2204
Max	2.2283	2.0687	2.0856	1.2407	1.1869	.9745	1.0852
Min	.0671	.0503	.0709	.0686	.0701	.0503	.0173
Avg	.9425	.6748	.6450	.1912	.4646	.3014	.2090

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 204 / 11 KV Khanapur Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1341	.1341	.1595	.1772	.1509	.124	.1254
2	.1341	.1372	.1433	.1612	.1509	.1227	.1254
3	.1341	.1543	.1448	.1612	.1492	.1214	.1254
4	.1715	.1696	.1734	.1791	.1677	.12	.1254
5	.1715	.2035	.3086	.2126	.2035	.1578	.1612
6	.3052	.3185	.3721	.333	.2713	.2658	.2686
7	.4191	.4409	.4908	.4784	.407	.4119	.4252
8	.39	.407	.4252	.4382	.3353	.3439	.3721
9	.3353	.2713	.3582	.333	.3052	.2865	.2804
10	.2374	.2204	.2713	.2401	.2543	.2035	.2126
11	.2543	.1715	.1526	.2374		.2035	.1715
12	.218	.1715	.2543	.2058		.1526	.1736
13	.2012	.2401	.2374	.2058	.2374	.1526	.1715
14	.1865	.2401	.2374	.1907	.2229	.1526	.1736
15	.1886	.2572	.2374	.2254	.2374	.1696	.206
16	.2229	.2401	.2374	.2229	.2543	.2204	.208
17	.2572	.3086	.2713	.2427	.2035	.2374	
18	.407	.3772	.3814	.3258	.2743	.3258	.2743
19	.4748	.4733	.443	.407		.4382	.3601
20	.4239	.4252	.4252	.373	.3155	.4207	.3429
21	.3391	.3582	.3366	.2883	.2481	.3012	.2915
22	.2543	.2865	.2658	.2543	.208	.2303	.2401
23	.1865	.1772	.2126	.1865	.1417	.1433	.1543
24	.1357	.1696	.1612	.1772	.1696	.1227	.1254
Max	.4748	.4733	.4908	.4784	.407	.4382	.4252
Min	.1341	.1341	.1433	.1612	.1417	.12	.1254
Avg	.2576	.2647	.2792	.2607	.2337	.2262	.2224

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 205 / 11 KV Bhivghat Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0716	.0857	.1075	.0716	.0848	.0716	.0895
2	.0716	.0857	.0905	.0716	.0857	.0701	.0895
3	.0701	.0876	.0905	.0716	.0857	.0689	.0895
4	.0876	.1052	.0905	.0716	.1052	.0867	.0895
5	.1052	.1052	.128	.0886	.1227	.1052	.0895
6	.1372	.12	.1448	.1433	.1372	.1463	.1417
7	.1715	.1886	.2195	.2149	.1865	.2149	.2126
8	.1886	.2058	.1812	.1949	.1715	.1993	.1753
9	.2035	.1677	.1463	.2103	.1526	.197	.1578
10	.156	.1372	.1543	.1595	.1372	.1372	.1578
11	.2058	.1372	.1526	.156	.1543	.1174	.1543
12	.1696	.1543	.1341	.1715	.1387	.1357	.1734
13	.1543	.1543	.1509	.1734	.1029	.1341	.1029
14	.1029	.12	.1017	.1526	.1017	.1017	.1017
15	.1029	.1029	.0838	.1036	.0848	.0857	.104
16	.1029	.12	.0838	.1372	.0686	.0686	.0867
17	.104	.1543	.1187	.1387	.0857	.0857	.1017
18	.1715	.1734	.1402	.1372	.1753	.1402	.12
19	.2058		.1772	.2035		.1928	.1886
20	.1886	.197	.1772	.2035	.181	.1772	.1715
21	.1509	.181	.1595	.1543	.1612	.1772	.1543
22	.1187	.1578	.1417	.1357	.124	.1595	.12
23	.1029	.1075	.0886	.1006	.0876	.1075	.0857
24	.0686	.0848	.1086	.0886	.0848	.0724	
Max	.2058	.2058	.2195	.2149	.1865	.2149	.2126
Min	.0686	.0848	.0838	.0716	.0686	.0686	.0857
Avg	.1338	.1362	.1322	.1398	.1226	.1272	.1286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 206 / 11 KV Balawadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0848	1.5432	1.543	1.4091	.1029	.124	.1075
2	.0848	1.5432	1.5432	1.3927	.1052	.1052	.1075
3	.0857	1.5424	1.4251	1.3927	.1052	.1063	.1075
4	.1029	1.5927	1.3426	1.3927	.1227	.104	.1075
5	.12	1.8652	1.3413	1.4091	.1372	.1372	.1417
6	.1715	.1543	.1791	.1715	.1886	.1949	.2126
7	.2035	.2035	.2801	.2572	.2058	.2427	.2804
8	.1886	.1886	.1663	.2279	.2035	.1886	.2454
9	.1372	.1357	.1417	.1753	.1174	.1387	.1753
10	.0857	.1372	.1357	.9326	1.0898		1.2039
11	.1187	.12	.1174	2.4034	2.431	1.861	2.1963
12	.0848	.1029	.1187	1.7859	2.3758	1.7436	2.42
13		.12	.1006	2.3205	2.2939	2.4587	2.2801
14		.12	.1017		2.3594	2.3739	2.3061
15	.1029	.1029	.1017	2.0481	2.2775	2.3472	2.1879
16	.1214	.1372	.1006	2.1376	2.2611	2.3739	2.1548
17	.156	.1715	.12	2.0287	1.9989	2.364	2.2119
18	.1886	.1886	.1734	.1543		.1734	.12
19	.2229	.1928	.2103	.2058		.2454	.2229
20	.2058	.2172	.2103	.1677	.2058	.2103	.2058
21	.1844	.1829	.1753	.1526	.1928	.1578	.1715
22	1.933	2.0056	1.6409	.12	.1448	.1227	.1543
23	1.8347	1.7736	1.4746	.1017	.1254	.1063	.12
24	.0857	1.5432	1.5592	1.4255	.1006	.1254	.1075
Max	1.933	2.0056	1.6409	2.4034	2.431	2.4587	2.42
Min	.0848	.1029	.1006	.1017	.1006	.104	.1075
Avg	.2956	.6619	.5960	1.0353	.8702	.7828	.8145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 207 / 11 KV GOREWADI gaovthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.017	.017	.0181	.0179	.017	.0181	.0179
2	.0168	.0168	.0183		.0168	.0183	.0179
3	.017	.0168	.0362		.0168	.0179	.0179
4	.0168	.0339	.0358	.0179	.0339	.0354	.0179
5	.0335	.0335	.0549	.0177	.0335	.0358	.0179
6	.0509	.0503	.0739	.0709	.0509	.0732	.0716
7	.1017	.1017	.1463	.1254	.1187	.1267	.1063
8	.1187	.1017	.1629	.1417	.1187	.128	.1417
9	.1187	.1017	.1075	.1227	.1017	.1267	.0876
10	.1029	.1029	.0838	.124	.0857	.0503	.0876
11	.0678	.1029	.0848	.0701		.0509	.0514
12	.0678	.0686	.0678	.0532	.0857	.0509	.0347
13	.0514	.0686	.0509	.0347	.0514	.0509	.0351
14	.0343	.0686	.0503		.0343	.0509	.0351
15	.0171	.0514	.0339	.0354	.0339	.0509	.0354
16	.0343	.0514	.0339	.052	.0339	.0339	.0362
17	.052	.0686	.0509	.0701	.0339	.0509	.0354
18	.0848	.0876	.0867	.0848	.0693	.0867	.0514
19	.1017	.0886	.0886	.1187		.1063	.0857
20	.1017	.0732	.0886	.1017	.0905	.1417	.1029
21	.0848	.0543	.0532	.0838	.0716	.0709	.0857
22	.0509	.0358	.0532	.0678	.0354	.0532	.0686
23	.0339	.0181	.0177	.0339	.0179	.0358	.0343
24	.017	.017	.0179	.0177	.017	.0179	.0179
Max	.1187	.1029	.1629	.1417	.1187	.1417	.1417
Min	.0168	.0168	.0177	.0177	.0168	.0179	.0179
Avg	.0581	.0596	.0632	.0696	.0531	.0618	.0539

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244117 / 33/11 KV Hiware Substation

Feeder No / Name : 201 / PALASHI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1736	1.2323	1.1843	1.0402	.1475	.1334	.1334
2	1.1736	1.2323	1.1523	.9922	.1457	.1334	.1334
3	1.2039	1.2323	1.166	.9962	.1475	.1334	.1334
4	1.2548	1.2498	1.1683	1.012	.1658	.1524	.1524
5	1.3565	1.4074	1.3603	1.0722	.1844	.1905	
6	.2743	.3429	.3547	.3361	.3149	.3429	.362
7	.3222	.4572	.3921	.4294	.4024	.4382	.4572
8	.3018	.2858	.3361	.3174	.2883	.2858	.362
9	.2713	.3048	.3547	.2614	.2204	.2629	.3429
10	.218	.2378	.2772	.6249	.6203	.4902	.5668
11	.2629	.2378	.2926	1.3763	1.4586	1.3763	1.3763
12	.2477	.2378	.2402	1.3441	1.4723	1.5466	1.4419
13	.2096	.1991	.2012	1.2186	1.5181	1.5497	1.6632
14	.2096	.2328	.2012	1.4883	1.5497	1.5181	1.6632
15	.1905	.2534	.2587	1.6194	1.2346	1.4842	1.7269
16	.1905	.2534	.2743	1.5912	1.3592	1.6324	1.7269
17	.2587	.2715	.2987	1.7772	1.2809	1.6975	1.7661
18	.3429	.3361	.3361	.2172	.2035	.2155	.1753
19	.4001	.3734	.3921	.3403	.3429	.3239	.3109
20	.381	.3361	.3547	.3258	.3239	.3239	.2896
21	.3429	.3174	.2801	.2987	.2667	.2858	.2686
22	1.6518	1.4883	1.186	.2103	.1905	.1905	.1949
23	1.4685	1.3748	1.078	.1543	.1524	.1524	.1772
24	1.2378	1.2186	1.2018	1.0595	.1492	.1334	.1334
Max	1.6518	1.4883	1.3603	1.7772	1.5497	1.6975	1.7661
Min	.1905	.1991	.2012	.1543	.1457	.1334	.1334
Avg	.6227	.6297	.5976	.8376	.5892	.6247	.6764

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244117 / 33/11 KV Hiware Substation

Feeder No / Name : 202 / 11 KV HIVARE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1905	.2012	.1949	.9175	.8002	.8583
2	.1886	.1905	.1848	.1991	.8907	.8002	.8583
3	.1865	.1905	.1829	.1991	.9012	.8002	.8583
4	.2035	.1905	.2012	.2012	.9614	.8002	.8697
5	.2204	.2286	.2402	.2195	1.1105	.8745	
6	.2743	.362	.3361	.3547	.2984	.362	.381
7	.4359	.4763	.4481	.4668	.4527	.4954	.4382
8	.3647	.4191	.3921	.4294	.39	.4763	.4001
9	.3353	.3881	.3361		.3521	.3315	.2587
10	.8785	.5407	.4801	.3174	.2321	.2572	.2667
11	2.0576	1.692	1.5623	.2772	.213	.2378	.2667
12	2.0645	1.8903	1.9524	.2353	.2601	.2012	.2801
13	2.0557	2.0873	1.9919	.2507	.3048	.2427	.2641
14	2.0567	2.0005	1.9204	.2543	.3142	.2427	.2427
15	2.0567	2.1032	2.1348	.218	.2715	.2858	.2587
16	2.13	2.0325	1.9841	.1989	.2629	.2865	.2587
17	2.0005	1.8747	1.8976	.2883	.2629	.362	.2987
18	.2804	.2801	.2614	.4119	.3012	.362	.3395
19	.4572	.4481	.4294	.5068	.4763	.4382	.4382
20	.4191	.4108	.4108	.4435	.4382	.4001	.4338
21	.3239	.3547	.3547	.3734	.362	.362	.3696
22	.2667	.2587	.2772	1.4198	1.034	1.2803	1.1488
23	.2096	.2195	.2353	1.0513	.9172	1.1174	1.0059
24	.1865	.1905	.2033	.1991	.9724	.7968	.8802
Max	2.13	2.1032	2.1348	1.4198	1.1105	1.2803	1.1488
Min	.1865	.1905	.1829	.1949	.213	.2012	.2427
Avg	.8267	.7925	.7758	.3787	.5374	.5256	.5076

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244117 / 33/11 KV Hiware Substation

Feeder No / Name : 203 / 11 KV HIVARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0358	.0351	.0179	.0358		.0339	.0354
2	.0358	.0351	.0177	.0358		.0347	.0354
3	.0351	.0351	.0179	.0354		.0347	.0351
4	.0351	.0351	.0179	.0354		.0347	.0343
5	.0339	.0537	.0358	.0351		.0343	
6	.0526	.0686	.0532	.0543		.0526	.0503
7	.0686	.0686	.0895	.1254	.0171	.0857	.0701
8	.1017	.0829	.1063	.1075	.0701	.0995	.0701
9	.0514	.0678	.0526	.1267	.0514	.0848	.0335
10	.0876	.0838	.0709	.1052	.0848	.1006	.0686
11	.0716	.0514	.0709	.0716	.0671	.0857	.0686
12	.0857	.0347	.0701	.0701	.0514	.0829	.0895
13	.0503	.0351	.0693	.0709	.0663	.0339	.0366
14	.0347	.0179	.0526	.0179	.0663	.0857	.0724
15	.0497	.0177	.0693	.0526	.0509	.0671	.0876
16	.0339	.0716	.0351	.0514	.0671	.0848	.0358
17	.0663	.0354	.0709	.0678	.0671	.0497	.0914
18	.1029	.0724	.0709	.0934	.1029	.12	.1109
19	.0693	.0905	.0905	.0762	.1029	.0671	.0739
20	.0838	.0895	.0905	.0953	.0838	.0671	.0739
21	.0686	.0537	.0543	.0566	.0509	.0678	.0549
22	.0509	.0358	.0543	.0543	.052	.0347	.0543
23	.0347	.0179	.0358	.0358	.0335	.0347	.0358
24	.0351	.0351	.0181	.0354		.0339	.0354
Max	.1029	.0905	.1063	.1267	.1029	.12	.1109
Min	.0339	.0177	.0177	.0179	.0171	.0339	.0335
Avg	.0573	.0510	.0555	.0644	.0639	.0629	.0589

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244127 / 33/11 KV RENA VI SUBSTATION

Feeder No / Name : 201 / 11 KV RENA VI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7748	.052	.0463	.0509	.7716	.6481	.6405
2	.7042	.052	.0309	.0514	.7716	.6481	.6325
3	.7042	.0532	.0309	.0509	.7099	.6173	.6093
4	.6958	.0526	.0309	.0514	.7099	.6173	.6009
5	.7116	.0532	.0617	.0514	.7099	.5864	.5937
6	.0848	.0686	.0617	.0686	.0463	.0617	.0532
7	.0686	.0693	.0617	.0678	.0617	.0617	.052
8	.1017	.0857	.0926	.0686	.0772	.0617	.0905
9	.0857	.104		.0686	.0617	.0772	.0693
10	.6642	.6642	.759	.0617		.0617	.0709
11	1.2631	1.2334	1.2803	.0463		.0526	.0351
12	1.4251	1.2654	1.3123	.0463	.0617	.0526	.0354
13	1.3765	1.2963	1.3916	.0463	.0309	.0532	.0351
14	1.4089	1.2654	1.5524	.0463	.0309	.0526	.0354
15	1.587		1.439	.0463	.0309	.0526	.0351
16	1.5339	1.4043	1.5203	.0617	.0463	.0514	.0678
17	1.5043	1.4352	1.1385	.0617	.0463	.0474	.0686
18	.0678	.0617	.1029		.0617	.0503	.1017
19	.0876	.0617	.1017	.1235	.0617	.0686	.12
20	.0857	.0617	.1029	.0772	.0617	.0526	.1017
21	.0857	.0617	.0848	.0772	.0617	.0701	.1029
22	.0543	.0617	.0857	.9259	.7099	.7202	.8855
23	.052	.0617	.0678	.8796	.7099	.6642	.8749
24	.8381	.0526	.0617	.0514	.787	.6944	.6562
Max	1.587	1.4352	1.5524	.9259	.787	.7202	.8855
Min	.052	.052	.0309	.0463	.0309	.0474	.0351
Avg	.6652	.4164	.4964	.1340	.3009	.2552	.2737

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244127 / 33/11 KV RENA VI SUBSTATION

Feeder No / Name : 202 / 11 KV RENA VI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0537	.0566	.0732	.0716	.0732	.0732	.0566
2	.0532	.0566	.0732	.0724	.0732	.0732	.0566
3	.0537	.0566	.0732	.0732	.0732	.0732	.0566
4	.0543	.0754	.0914	.0724	.0732	.0732	.0566
5	.0716	.0754	.0914	.0895	.0732	.0732	.0754
6	.0905	.1132	.0914	.1075	.128	.1097	.112
7	.1629	.168	.1463	.1267	.1463	.1463	.1829
8	.1646	.1791	.128	.1433	.128	.1463	.1448
9	.1267	.1402	.1097	.1075	.0914	.128	.1254
10	.1254	.1063	.1075	.0914	.0732	.0732	.1086
11	.1052	.1052	.0905	.0732	.0732	.0549	.0537
12	.0886	.0732	.0716	.0732	.0732	.0554	.0526
13	.0724	.0732	.0895	.0914	.0732	.056	.0532
14	.0716	.0732	.0709	.0732	.0732	.0549	.0537
15	.0724	.0732	.0716	.0732	.0732	.0554	.0537
16	.0914	.0732	.0724	.0732	.0732	.0554	.0905
17	.0716	.0732	.0895	.0914	.0732	.0709	.0895
18	.1433	.1097	.1267	.128	.1097	.1097	.1086
19	.1494	.1829	.1433	.1463	.1463	.1478	.1463
20	.1494	.1463	.1267	.1463	.1463	.132	.1629
21	.1132	.1097	.1097	.1097	.1463	.1132	.1254
22	.0754	.0732	.0905	.0732	.0914	.0754	.0895
23	.0566	.0732	.0716	.0732	.0732	.0566	.0709
24	.0543	.0566	.0732	.0709	.0732	.0732	.0566
Max	.1646	.1829	.1463	.1463	.1463	.1478	.1829
Min	.0532	.0566	.0709	.0709	.0732	.0549	.0526
Avg	.0946	.0968	.0951	.0938	.0930	.0867	.0909

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 201 / 11 KV BURLI FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.9122	.8436	.823	.0377	.0394	.0412
2	.0343	.9122	.7499	.7225	.0372	.0383	.0394
3	.0349	.9231	.7316	.7499	.0383	.0394	.0406
4	.0406	.9231	.7316	.6481	.0394	.0406	.0429
5	.0579	.9717	.759	.6401	.0412	.0406	.0602
6	.0587	.0762	.088	.0903	.0594	.0564	.0926
7	.0753	.0743	.0869	.0903	.0914	.0753	.0772
8	.0892	.0743	.088	.0869	.0734	.0892	.0781
9	.0667	.0594	.0714	.0676	.0579	.0564	.0676
10	.0406	.0834	.0638	1.3077	1.326	1.278	1.1797
11	.0394	.0695	.0657	1.8679	1.6194	1.6712	1.4575
12	.048			1.9204	1.5181	1.7695	1.6712
13	.029			1.9662	1.3763	1.6644	1.6712
14	.029		.061	2.0645	1.4746	1.6324	1.5729
15	.0511		.0526	1.9292	1.4918	1.6095	1.3603
16	.0657	.0429	.0511	1.9662	1.3603	1.3603	1.4403
17	.0629	.0695	.0777	1.989	1.3603	1.4232	.2172
18	.0734	.0857	.0754	.0857	.0591	.0709	.0676
19	.0743	.1054	.0869	.0869	.0857	.0903	.0846
20	.0734	.1014	.0846	.0857	.0834	.0734	.08
21	.0714	.0846	.088	.0695	.0676	.0734	.0714
22	1.0814	1.0688	.8436	.0549	.0526	.0587	.0579
23	.9717	.9602	.8436	.0495	.048	.0423	.0526
24	1.7366	.9602	.8436	.8333	.0377	.0394	.04
Max	1.7366	1.0688	.8436	2.0645	1.6194	1.7695	1.6712
Min	.029	.0429	.0511	.0495	.0372	.0383	.0394
Avg	.2058	.4279	.3358	.8415	.5182	.5555	.4818

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 202 / 11 KV RAMANANDNAGAR 1

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.1886	.2263	.2241	.2263	.2263	.2241
2	.2263	.1886	.2263	.1867	.1886	.2241	.2263
3	.2263	.1886	.1886	.1886	.1886	.1886	.1867
4	.2241	.1886	.2263	.2263	.1886	.2263	.1867
5	.3018	.2641	.2263	.2987	.2263	.2987	.3018
6	.3018	.3772	.3018	.3772	.3395	.3772	.3772
7	.3772	.4904	.415	.4481	.4481	.4527	.4527
8	.4527	.4527	.4481	.5228	.4435	.5281	.5281
9	.5228	.4805	.5228	.5175	.362	.5175	.5121
10	.5121	.4805	.5121	.5658	.3658	.5014	.5121
11	.5258	.5175	.5014	.5121	.2865	.5121	.4706
12	.4344	.4344	.5014	.3982	.2835	.3898	.4298
13	.4066	.4435		.3696	.2896	.4344	.4024
14	.4024	.4108	.567	.439	.2303	.4481	.4298
15	.439	.5068	.5068	.4344	.2195	.5228	.439
16	.4854	.5068	.567	.4908	.2195	.5228	.4359
17	.439	.4344	.5853	.5121	.2149	.4115	.4161
18	.5121	.5853	.5914	.5487	.4252	.5014	.5121
19	.4805	.5853	.5853	.5544	.439	.5544	.5175
20	.5228	.5228	.5487	.4854	.4435	.5228	.5175
21	.4527	.4481	.4435		.3734	.415	.3772
22	.415	.3772	.3734		.3018	.3772	.4527
23	.3018	.3018	.3018	.2641	.2263	.3018	.3772
24	.2263	.2641	.2263	.2263	.2641	.2263	.2263
Max	.5258	.5853	.5914	.5658	.4481	.5544	.5281
Min	.2241	.1886	.1886	.1867	.1886	.1886	.1867
Avg	.3923	.4016	.4171	.3996	.2998	.4034	.3963

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 203 / 11 KV SAWANTPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0541	1.166	1.2955	.9877		.0406	.0383
2	.0417	1.166	1.166	.9755	.0417	.0417	.0354
3	.04	1.1523	1.1248	.8429	.0423	.0463	.0372
4	.0423	1.1523	1.1385	.8535	.0434	.0452	.0366
5	.0625	1.2955	1.1797	.8749	.0446	.064	.061
6	.0625	.0926	.0869	.0572	.061	.064	.081
7	.0892	.1094	.0892	.0892	.0743	.0734	.081
8	.0762	.0834	.0869	.1204	.0762	.0705	.0753
9	.0541	.0857	.0812	.0667	.0686	.0518	.0714
10	.0406	.0846	.0676	1.8461	1.1203	1.3123	1.3108
11	.0581	.1054	.0789	1.6842	1.2803	1.6644	1.5546
12	.06	.0648		2.2283	.9877	1.6644	1.8138
13	.0457	.0495		2.2283	1.4754		1.9204
14	.0412	.048	.0619	2.2283	1.5181	1.5813	1.7924
15	.0389	.0714	.0657	2.146	1.5364	1.7924	1.7924
16	.0533	.0789	.0503	2.2024	1.2498	1.6842	1.7924
17	.0629	.061	.0709	1.9433	1.2651	1.8138	1.6248
18	.0754	.1158	.1006	.0657	.061	.0581	.0581
19	.0695	.0892	.0869	.0705	.0724	.0762	.0705
20	.0714	.0987	.0834	.088	.0556	.0724	.0676
21	.0724	.0812	.0846		.0564	.0714	.0714
22	1.4419	1.5729	1.1385	.0549	.0541	.0594	.0556
23	1.3108	1.3603	1.1401	.0533	.0541	.0572	.0533
24	.0457	1.1797	1.2955	1.012	.0488	.0394	.0377
Max	1.4419	1.5729	1.2955	2.2283	1.5364	1.8138	1.9204
Min	.0389	.048	.0503	.0533	.0417	.0394	.0354
Avg	.1671	.4735	.4806	.9878	.4908	.5411	.6055

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 204 / 11 KV RAMANANDNAGAR 2

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.2641	.3018	.2987	.2641	.2641	.3018
2	.3018	.2641	.3018	.2957	.2641	.2641	.3018
3	.2263	.2641	.2641	.2614	.2641	.2641	.2614
4	.3772	.3018	.3018	.2957	.2641	.3734	.2614
5	.4481	.3772	.3772	.4527	.3018	.4527	.3772
6	.5281	.6036	.5658	.6036	.5281	.5281	.6036
7	.6036	.679	.7167	.7545	.6413	.6036	.7545
8	.6036	.6036	.679	.6036	.5658	.5228	.679
9	.5175	.5658	.679	.5975	.4527	.5228	.7023
10	.5228	.5544	.6024	.5975	.3772	.4854	.6154
11	.5014	.5228	.567	.5316	.3696	.4298	.5487
12	.4108	.5228		.4344	.3018	.4066	.4755
13	.3696	.4904		.4481	.3018	.439	.4435
14	.3658	.415	.6104	.5121	.3018	.4024	.4706
15	.5373	.4904	.5014	.4706	.2987	.3361	.4108
16	.5121	.4481	.5068	.439	.3018	.3734	.439
17	.5014	.4481	.5731	.4481	.2987	.3326	.4656
18	.7023	.6722	.5914	.6283	.5228	.5853	.5792
19	.7167	.7545	.679	.7095	.6036	.7167	.6722
20	.679	.679	.6722	.6036	.5228	.679	.6722
21	.5658	.6036	.5658	.5281	.4527	.6036	.5281
22	.4527	.5281	.4527	.4527	.3772	.5281	.4527
23	.3395	.3772	.3772	.3395	.3018	.3772	.3772
24	.3018	.3018	.3395	.3395	.3018	.3018	.3395
Max	.7167	.7545	.7167	.7545	.6413	.7167	.7545
Min	.2263	.2641	.2641	.2614	.2641	.2641	.2614
Avg	.4743	.4888	.5103	.4853	.3825	.4497	.4889

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 401 / 33 KV KBL

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-DEC-17
HR	Load (MW)
24	.2829
Max	.2829
Min	.2829
Avg	.2829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 201 / 11 KV Dudhondi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4111	.3795		.0625	.0625	.0633	.0633
2	.4111	.3795	.3637	.0625	.0625	.0633	.0474
3	.4111	.3953	.3479	.0625	.0625	.0633	.0474
4	.427	.4111	.4111	.0781	.0625	.0633	.0633
5	.427	.4428	.4744	.0781	.0781	.0791	.0791
6	.0791	.0949	.0949	.0781	.0937	.0949	.0791
7	.0949	.0949	.0949	.0937	.0937	.0791	.0937
8	.0949	.1265	.0791	.0937	.0937	.0791	.0781
9	.0949	.0949	.0791	.0781	.125	.0791	.0937
10	.0633	.0791	.0791	.4374	.4999	.4111	.4428
11	.0633	.0633	.0781	.9061	.6325	.6958	.7748
12	.0633	.0633	.0781	.9374	.6642		.8539
13	.0633	.0633	.0781	.9374	.6642	.8223	.8381
14	.0633	.0633	.0781	.8905	.6958	.7907	.8539
15	.0633	.0791	.0781	.9172	.6642		.8539
16	.0633	.0791	.0625	.8749	.4428		.8697
17	.0791	.0791	.0937	.8749	.506	.6642	.8381
18	.0819	.0949	.0937	.0781	.0791	.0791	.0791
19	.0949	.0949	.0937	.0781	.0949	.0949	.0791
20	.0791	.0949	.0937	.0781	.1107	.0791	.0633
21	.0791	.0791	.0781	.0625	.0791	.0791	.0633
22	.506	.4744	.0625	.0625	.0633	.0633	.2688
23	.4428	.3953	.0625	.0625	.0633	.0474	.2846
24	.4111	.3953	.3795	.0625	.0625	.0633	.0633
Max	.506	.4744	.4744	.9374	.6958	.8223	.8697
Min	.0633	.0633	.0625	.0625	.0625	.0474	.0474
Avg	.1945	.1924	.1493	.3311	.2524	.2169	.3280

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 202 / 11 KV Nagrale Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0492	.0655	.0655	.9282	.6226	.4752	.4915
2	.0492	.0655	.0655	.8951	.5898	.4588	.5243
3	.0655	.0655	.0655	.8848	.5898	.4424	
4	.0492	.0655	.0819	.852	.6062	.4588	.4915
5	.0655	.0983	.0983	.7537	.6226	.4915	.5243
6	.0655	.0983	.0819	.0819	.0983	.0819	.0655
7	.0983	.0983	.0819	.0983	.0983	.0819	.0819
8	.0655	.0983	.0819	.0983	.0983	.0819	.0655
9	.0655	.0983	.0655	.0819		.0655	.0983
10	.852	.3761	.0983	.0819	.0983	.0655	.0655
11	1.1797	1.3108	1.1603	.0819	.0819	.0655	.0819
12	1.6385	1.3108	1.4586	.0819	.0633		.0819
13	1.5893	1.5074	1.5249		.0655	.0655	.0819
14	1.5565	1.5729	1.5581	.0819	.0655	.0655	.0819
15	1.5893	1.5729	1.5249	.0819	.0655	.0655	.0655
16	1.4582	1.5565	1.5249	.0819	.0655	.0655	.0655
17	1.4582	1.4091	1.4255	.0819	.0655		.0819
18	.0819	.0819	.0829	.0819	.0819	.0655	.0983
19	.0819	.0819	.0663	.0983	.0983	.0655	.0983
20	.0983	.0983	.0663	.0819	.0983	.0983	.0983
21	.0983	.0819	.0663	.0983	.0819	.0655	.0983
22	.0983	.0819	.9614	.7701	.5571	.6299	.0983
23	.0819	.0655	.9614	.6882	.4915	.5571	.0983
24	.0655	.0819	.0655	.9282	.6554	.4915	.5243
Max	1.6385	1.5729	1.5581	.9282	.6554	.6299	.5243
Min	.0492	.0655	.0655	.0819	.0633	.0655	.0655
Avg	.5209	.4976	.5514	.3476	.2592	.2275	.1766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 203 / 11 KV Takari Exps

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.3155	.3601	.4115	.4908	.5487	.5487
2	.4334	.2804	.3429	.3856	.4908	.5087	.6154
3	.4508	.2774	.3641	.4298	.5316	.5087	.5609
4	.4458	.2774	.3856	.4458	.5316	.5487	.6089
5	.4458	.3086	.4207	.4908	.4908	.5487	.567
6	.463	.3052	.4207	.4801	.5201	.583	.583
7	.4801	.3052	.4508	.5258	.4801	.631	.6783
8	.5493	.3582	.4298	.4607	.4801	.6379	.5959
9	.4961	.4656	.4656	.5792	.4508	.6661	.6661
10	.4887	.3761	.4344	.5258	.4908	.6584	.6024
11	.4961	.4252	.3856	.5373	.5201	.6241	.567
12	.4207	.4557	.407	.4656	.5487		.567
13	.3721	.4207	.4557	.5068	.5258	.57	.724
14	.3721	.4607	.4115	.4681	.5493	.5426	.6024
15	.3641		.4207	.4908	.5959		.7164
16	.3641	.4207	.4207	.3944	.6379		.6201
17	.3189	.4207	.4508	.2835	.5609	.6154	.5487
18	.1341	.4508	.5544	.5201	.6024	.6379	.6661
19	.3258	.4854	.5609	.5316	.631	.7011	.5959
20	.3086	.5258	.5548	.5373	.6661	.7442	.5609
21	.3561		.583	.3641	.6241	.6241	.5316
22	.4119	.4161	.4458	.5087	.5895	.7442	.6135
23	.4298	.4207	.4458	.5087	.5487	.6371	.5144
24	.4409	.3658	.3814	.4359	.3189	.583	.57
Max	.5493	.5258	.583	.5792	.6661	.7442	.724
Min	.1341	.2774	.3429	.2835	.3189	.5087	.5144
Avg	.4082	.3881	.4397	.4703	.5365	.6126	.6010

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 204 / 11 KV Nagrale Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3696	.4805	.4805	.5175	.4066	.4435	.5175
2	.3881	.4805	.4435	.5175	.4066	.4066	.5175
3	.3881	.5175	.4805	.4805	.4435	.4435	.5544
4	.4251	.5914	.5914	.5914	.5544	.5914	.5914
5	.5544	.7023	.7392	.7762	.6838	.7392	.7392
6	.8871	1.0534	.961	.961	.924	.9979	.961
7	.9979	1.0903	1.1088	1.1088	1.0534	1.1088	1.1088
8	.7947	.8686	.9054	.8871	.924	.924	.924
9	.5914	.5914	.6653	.7392	.7023	.6653	.7392
10	.5359	.5544	.5544	.5544	.5544	.5544	.5544
11	.5544	.5544	.5544	.5544	.5175	.5175	.5175
12	.5175	.5175	.5914	.4805	.4805		.5175
13	.4435	.4805	.5914	.5175	.4805	.5544	.4066
14	.4435	.4435	.5544	.4435	.4435	.4435	.4251
15	.4251	.5175	.5175	.4066	.4435	.4066	.3696
16	.4805	.5544	.5175	.3696	.4066	.3696	.4435
17	.5544	.6283	.5544	.5175	.5544	.5544	.5544
18	.7392	.7762	.7392	.7392	.6653	.5914	.7392
19	.924	.924	.924	.8871	.8501	.924	
20	.8131	.8871	.924	.8131	.7762	.924	.8871
21	.7762	.8501	.7392	.7762	.7392	.8871	.8871
22	.7023	.7023	.7023	.7023	.6653	.7392	.7207
23	.5544	.5544	.5544	.5544	.5544	.5544	.5544
24	1.274	.5175	.5175	.5175	.4435	.4435	.5175
Max	1.274	1.0903	1.1088	1.1088	1.0534	1.1088	1.1088
Min	.3696	.4435	.4435	.3696	.4066	.3696	.3696
Avg	.6306	.6599	.6630	.6422	.6114	.6428	.6412

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 205 / Satteshwar LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3961	.4527	.4481	.4481	.0373	.3734
2	.4904	.4527	.4805	.4854	.0377	.3921
3	.5093	.5281	.4854	.5228	.0373	.3696
4	.4904	.5281	.5281	.5228	.0377	.3881
5	.5093	.547	.5281	.5228	.0377	.3696
6	.4904	.5281		.5228	.0377	.3921
7	.4904	.5281	.5281	.6413	.2641	.5788
8	.6036	.5281	.5281	.6161	.2641	.5601
9	.6224	.5281	.5093	.6348	.2641	.5975
10	.6224	.5281	.547	.6348		.5975
11	.6036	.5093	.5228	.6348	.1494	.5975
12	.6036	.5281	.5228	.6348		.5975
13	.6413	.5281	.5975	.6348		.5041
14	.6413	.5093	.6348	.3361	.4108	.4854
15	.4338	.5093	.6099	.2614	.168	.4854
16	.6036	.4904	.5788	.2614	.1109	.4481
Max	.6413	.547	.6348	.6413	.4108	.5975
Min	.3961	.4527	.4481	.2614	.0373	.3696
Avg	.5470	.5140	.5366	.5197	.1428	.4836

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 201 / 11 KV PALUS CITY FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.679	.6979	.7167	.6722	.6979	.7167	.695
2	.7167	.679	.7167	.6535	.6979	.7167	.6697
3	.6584	.679	.7545	.6653	.7356	.7167	.6468
4	.7356	.7167	.7545	.7133	.7167	.7922	.7095
5	.9054	.8865	.9808	.8048	.9808	1.0374	1.0456
6	1.094	1.2071	1.1389	1.1584	1.3014	1.2637	1.1506
7	1.4712	1.5844	1.3443	1.4842	1.4937	1.4563	1.531
8	1.6244	1.423	1.4937	1.3575	1.3306	1.419	1.46
9	1.423	1.2803	1.3676	1.2382	1.2254	1.2567	1.3394
10	1.2851	1.3169	1.3213	1.251	1.1883	1.2489	1.2489
11	1.2308	1.2567	1.2403	1.1888	1.1517	1.182	1.0985
12	1.1946	1.262	1.1584	1.0985	.9214	1.1641	1.1283
13	1.1283	1.086	1.0745	1.1283	.9745	1.0808	1.1641
14	1.0924	1.0566	1.0029	1.0566	.9412	1.1283	.985
15		1.0974	1.0208	1.1222	.9231	1.1104	1.0498
16	1.2715	1.1888	1.0566	1.0208	.9694	1.0924	1.1218
17	1.3611	1.1946	1.0692	1.2357	1.1403	1.1568	
18	1.7013	1.448	1.4998	1.6289	1.4266	1.5729	1.8625
19	1.7737	1.7375	1.5565	1.7372	1.6827	1.6651	1.885
20	1.6057	1.4632	1.4083	1.531	1.475	1.6095	1.6244
21	1.3443	1.3443	1.2752	1.1763	1.3256	1.2851	1.363
22	1.094	1.1317	1.0829	1.0829	1.1203	1.0608	1.1576
23	.811	.8488	.8215	.8488	.8865	.8686	.8865
24	.679	.6979	.7167	.7207	.7356	.7733	.7392
Max	1.7737	1.7375	1.5565	1.7372	1.6827	1.6651	1.885
Min	.6584	.679	.7167	.6535	.6979	.7167	.6468
Avg	1.1687	1.1368	1.1072	1.1073	1.0851	1.1406	1.1549

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 202 / 11 KV MIDC PALUS FEEDER SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.4904	.4904	.3961	.415	.4527	.4527
2	.4338	.4904	.4527	.3961	.3961	.4527	.4527
3	.4338	.5093	.4527	.415	.3961	.4715	.4108
4	.4338	.4904	.4527	.415	.415	.4715	.4668
5	.4527	.5093	.4904	.4527	.4527	.4715	.462
6	.4715	.5093	.4904	.4715	.4527	.4715	.4805
7	.5658	.5281	.4904	.5093	.4527	.5093	.5601
8	.5847	.6036	.5281	.5281	.4527	.5093	.7545
9	.6661	.8954	.8676	.7167	.547	.8962	.8676
10	1.2449	1.0269	.8589	.8328	.5093	.8686	1.0751
11	1.1317	1.0642	.8048	.9709	.4715	1.1128	.8402
12	.9619	.7545	.7167	1.1949	.415	.7356	.8676
13	1.0425	.9808	.8676	1.182	.415	.8939	1.1883
14	1.7541	1.8298	1.226	1.8107	.5281	1.4523	1.6032
15	1.6975	1.6617	.8869	1.7164	.5281	1.3203	2.0748
16	1.0562	1.7918	1.3769	1.5655	.5093	1.4523	1.1694
17	.811	.8865	.7922	1.1041	.4904	1.0608	1.3769
18	.7356	.8299	.6224	.6516	.4715	.9149	.5847
19	.5658	.7167	.547	.6413	.4715	.6602	.5281
20	.5281	.5847	.5093	.4338	.4715	.4904	.5093
21	.4715	.4904	.4715	.4338	.4904	.4904	.3961
22	.4904	.5281	.4527	.4338	.4904	.4668	.4904
23	.5093	.5093		.415	.4904	.4854	.4715
24	.4527	.4904	.4904	.415	.415	.4527	.4715
Max	1.7541	1.8298	1.3769	1.8107	.547	1.4523	2.0748
Min	.4338	.4904	.4527	.3961	.3961	.4527	.3961
Avg	.7478	.7988	.6669	.7543	.4645	.7318	.7731

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 203 / 11 KV GONDILWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	1.0494	1.1203	.8192	.1509	.168	.168
2	.1307	1.0494	1.0883	.7773	.1509	.168	.1478
3	.132	1.0212	1.1012	.7611	.1509	.168	.1848
4	.1698	1.0623	1.1174	.8192	.1509	.1848	.1829
5	.2263	1.0595	1.1336	.9116	.2075	.2587	.2378
6	.2452	.2829	.2801	.2926	.2829	.3142	.2534
7	.3395	.3395	.2987	.3547	.3395	.3142	.3439
8	.3174	.2957	.3547	.2926	.3142	.3142	.2926
9	.3142	.3174	.3142	.2561	.2957	.3326	.2686
10	.2987	.3018	.3142	1.1012		1.0562	1.1385
11	.2987	.3206	.2641	2.1376	1.6518	1.8187	1.8818
12	.2987	.1886	.2957	.9762	1.8947	1.945	1.9372
13	.3326	.2829	.2801	1.8138	2.0567	1.9997	2.119
14	.3326	.2452	.2587		2.1136	1.7966	2.1285
15	.3142	.2263	.2561	2.0891	1.9498	1.8903	2.1925
16	.3511	.2641	.2402	2.4486	1.7859	1.9292	2.198
17	.3326	.2241	.2534	2.4615	1.5655	1.7071	
18	.3174	.3142	.2378	.2353	.2218	.2033	.2378
19	.3174	.2772	.2743	.2801	.2587	.2896	.3174
20	.2987	.2926	.2715	.2987	.2801	.2957	.2829
21	.2801	.2957	.2926	.2427	.2427	.2772	.2829
22	1.7368	1.8564	1.2346	.2075	.1867	.2427	.2263
23	1.2342	1.4403		.1698	.1867	.2033	.1886
24	.1509	1.0957	1.1843	.8951	.1509	.168	.1829
Max	1.7368	1.8564	1.2346	2.4615	2.1136	1.9997	2.198
Min	.1307	.1886	.2378	.1698	.1509	.168	.1478
Avg	.3716	.5876	.5420	.8975	.7213	.7519	.7563

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 204 / 11 KV MINI MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1698	.1886	.1698	.0943	.1509	.1509
2	.1698	.1509	.1698	.1509	.0943	.1509	.132
3	.1509	.1509	.1698	.1509	.0943	.1509	.1509
4	.1509	.1509	.1698	.1494	.0943	.1698	.1509
5	.1509	.1698	.1698	.1886	.1132	.1698	.1698
6	.1509	.1509	.1698	.1886	.1132	.1886	.1886
7	.1698	.1509	.1698	.1886	.1132	.2263	.2075
8	.3961	.3961	.3961	.3921	.1132	.3395	.4338
9	.4338	.4338	.4715	.4527	.132	.4715	.4338
10	.4715	.4904	.4338	.4715	.1132	.4338	.4715
11	.3772	.4904	.4527	.415	.0943	.415	.4338
12	.3395	.3961	.3772	.3395	.132	.415	.3206
13	.3395	.3772	.3772	.3077	.0943	.3395	.3961
14	.4715	.4481	.415	.3961	.0943	.3772	.4715
15	.3961	.415	.3584	.3961	.0943	.3772	.415
16	.5093	.4668	.4338	.4527	.1132	.4527	.415
17	.3395	.3961	.3584	.3395	.1132	.3584	.3395
18	.3018	.3395	.3395	.3395	.132	.3395	.3018
19	.2075	.3018	.2829	.2641	.1509	.3174	.2452
20	.1886	.2452	.2614		.1886	.2614	.2263
21	.1698	.1698	.2263		.1886	.1886	.2075
22	.1698	.1886	.2075	.0377	.1886	.1886	.1886
23	.1698	.1886		.0943	.1886	.1698	.1886
24	.1886	.1698	.1886	.1698	.0943	.1509	.1509
Max	.5093	.4904	.4715	.4715	.1886	.4715	.4715
Min	.1509	.1509	.1698	.0377	.0943	.1509	.132
Avg	.2743	.2920	.2951	.2752	.1226	.2835	.2829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 205 / 11 KV MAHADA COLONY

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.0732	.0739	.0724	.0739	.0739	.0724
2	.0549	.0739	.0739	.0724	.0747	.0739	.0537
3	.0543	.0739	.0739	.0537	.0747	.0739	.0716
4	.0543	.0747	.0739	.0537	.0747	.0739	.0701
5	.0924	.0747	.0914	.0724	.0943	.1109	.0895
6	.1109	.1494	.128	.1254	.1307	.1478	.1254
7	.181	.1848	.1848	.1928	.1663	.1791	.1753
8	.2012	.1753	.2033	.1928	.197	.2126	.1715
9	.1928	.2103	.1791	.1753	.1402	.124	.1372
10	.156	.1715	.2058	.1357	.104	.1696	.1326
11	.156	.1402	.176	.1341	.0995	.0995	.1475
12	.1753	.1543	.1562	.1387	.081	.0762	.0914
13	.1433	.1372	.144	.0937	.0914	.0937	.108
14	.0995	.1402	.1296	.1054	.0686	.0617	.0983
15	.0995	.1578	.1505	.112	.0671	.1067	.0819
16	.1134	.12	.1543	.1107	.0503	.1067	.1107
17	.1372	.1052	.1718	.1296	.0693	.1524	.1107
18	.1578	.1715	.1886	.1753	.1254	.1715	.1696
19	.1928	.1791	.1753	.1791	.128	.1753	.1753
20	.1629	.1433	.1715	.1629	.1463	.1578	.1448
21	.1448	.1433	.1402	.128	.1463	.1715	.112
22	.1109	.1307	.1227	.1294	.1097	.1227	.0934
23	.0924	.0924		.0924	.0914	.0895	.0739
24	.0549	.0686	.0739	.0716	.0739	.0739	.0724
Max	.2012	.2103	.2058	.1928	.197	.2126	.1753
Min	.0543	.0686	.0739	.0537	.0503	.0617	.0537
Avg	.1247	.1311	.1410	.1212	.1033	.1208	.1121

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 206 / 11 KV M.I.D.C. JAWAHAR SHEDDABLE FEEDER HAVING WEEKLY
VIDYLAY Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6224	.7167	.6602	.6413	.679	.6224	.547
2	.6224	.6979	.6979	.6413	.6413	.6224	.547
3	.6413	.6979	.6979	.6602	.5281	.6224	.5281
4	.6602	.7167	.6979	.6036	.5281	.6224	.5281
5	.679	.6979	.6602	.5788	.547	.6413	.5041
6	.6979	.7733	.6602	.5788	.5847	.6413	.5281
7	.6979	.4904	.6602	.5544	.5847	.6224	.547
8	.6979	.7167	.679	.5975	.547	.6224	.6224
9	.7282	.7167	.7167	.5847	.5847	.6224	.6161
10	.7282	1.0562	.8299	.6224	.6602	.5281	.6979
11	.7282	.7733	.8488	.5847	.6602	1.1222	.6036
12	.6979	1.226	.5847	.4715	.6036	.9877	.7545
13	.679	1.2696	1.6221	1.1506	.6036	.6413	1.0751
14	.7545	1.6221	1.7541	.6979	.6413	1.2883	1.262
15	.7167	1.5089	1.531	1.4003	.6224	.6979	1.2936
16	.7545	1.4937	1.4712	.9242	.6224	1.2637	.7522
17	.7167	1.0562	1.773	.6413	.6224	.547	.5093
18	.7356	.6979	.9054	.7545	.6224	.5658	.7167
19	.7167	.6413	.6602	.7167	.6224	.547	.6413
20	.6979	.6036	.8676	.547	.6224	.5658	.679
21	.7167	.5847	.9431	.679	.6036	.5093	.6979
22	.6979	.679	.6602	.7356	.6224	.5228	.7356
23	.6979	.6602		.6413	.6224	.5415	.547
24	.6602	.7167	.6602	.6602	.7167	.6224	.5281
Max	.7545	1.6221	1.773	1.4003	.7167	1.2883	1.2936
Min	.6224	.4904	.5847	.4715	.5281	.5093	.5041
Avg	.6977	.8672	.9236	.6945	.6122	.6913	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 201 / 11KV ASAD

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5243	.7373	.7011	.0343	.0343	.0351	.0343
2	.4915	.6882	.7011	.0343	.0343	.0351	.0343
3	.4915	.6882	.6661	.0343	.0343	.0351	.0343
4	.4915	.6554	.631	.0343	.0343	.0351	.0343
5	.4915	.639	.631	.0343	.0343	.0351	.0343
6	.0343	.0343	.0351	.0343	.0343	.0351	.0343
7	.0343	.0343	.0351	.0343	.0514	.0351	.0514
8	.0343	.0343	.0343	.0343	.0514	.0351	.0514
9	.0343	.0343	.0343	.0343	.0514	.0351	.0514
10	.0514	.0514	.0343	.7045	.7716	.7865	.9012
11	.0343	.0514	.0343	1.0159	1.0288	.9995	.9774
12	.0343	.0343	.0343	1.2289	1.0924	1.0159	.9088
13	.0343	.0343	.0343	1.2289	1.0924	1.0159	1.0708
14	.0343	.0343	.0343	1.1797	.9492	1.0486	.8916
15	.0343	.0343	.0343	1.1633	.8954	.9339	.8916
16	.0343	.0343	.0343	1.0814	.8238	.9339	.852
17	.0343	.0343	.0343	.9503	.788	.7865	.7373
18	.0343	.0343	.0343	.0514	.0526	.0514	.0343
19	.0514		.0343	.0514	.0351	.0514	.0343
20	.0514	.0526	.0343	.0514	.0351	.0514	.0343
21	.0514	.0351	.0343	.0514	.0526	.0514	.0343
22	.8356	.7888	.0343	.0343	.0526	.0343	.5243
23	.8192	.7712	.0343	.0343	.0351	.0343	.4915
24	2.1628	.7865	.7362	.0343	.0343	.0351	.0343
Max	2.1628	.7888	.7362	1.2289	1.0924	1.0486	1.0708
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.2885	.2749	.1952	.3821	.3375	.3394	.3658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 202 / 11KV MOHITE VADGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0686	.0686	1.4091	1.5402	1.5074	1.491
2	.0686	.0686	.0686	1.3763	1.4419	1.3672	1.4255
3	.0686	.0686	.0686	1.3435	1.2944	1.2971	1.4091
4	.0686	.0857	.0686	1.278	1.1797	1.2269	1.3435
5	.0686	.0857	.0686	1.1469	1.1305	1.1218	1.278
6	.0686	.1029	.0857	.0686	.1029	.0876	.1029
7	.0686	.12	.1372	.0686	.12	.1052	.12
8	.0686	.1029	.1029	.1029	.1029	.0876	.1029
9	.0686	.1029	.0857	.0857	.1029	.0701	.0857
10	1.9662	2.1605	1.9662	.0686	.0857	.0686	.0857
11	2.1464	2.2634	2.4086	.1029	.0514	.0686	.0857
12	2.2775	2.4691	2.3102	.1029		.0857	.1029
13	2.3266	2.3834	2.1628	.0857		.0686	.1029
14	2.2611	2.1948	2.1628	.0857		.1029	.1029
15	2.1628	2.0748	1.9662	.0857		.1029	.1029
16	2.0645	1.9376	1.8023	.1029		.0857	.12
17	1.9662	1.6804	1.704	.0857	.0716	.12	.1029
18	.0857	.12	.0686	.1029	.1052	.12	.1029
19	.12	.12	.0686	.1029	.1052	.12	.1029
20	.12	.1029	.0686	.1029	.1402	.12	.1029
21	.1029	.0857	.0686	.1029	.1052	.1029	.1029
22	.0857	.0686	1.4091	1.704	1.858	1.7204	.1029
23	.0857	.0686	1.4091	1.6549	1.8229	1.6712	.0686
24	.0686	.0686	.0686	1.4091	1.6385	1.7528	1.6057
Max	2.3266	2.4691	2.4086	1.704	1.858	1.7528	1.6057
Min	.0686	.0686	.0686	.0686	.0514	.0686	.0686
Avg	.7691	.7752	.8500	.5325	.6842	.5492	.4314

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 203 / 11 KV 4TH SONSAL FEEDER NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0686	.0693	.0514	.0343	.0543	.0686
2	.0343	.0686	.0693	.0514	.0343	.0362	.0686
3	.0343	.0686	.0693	.0514	.0343	.0362	.0686
4	.0343	.0686	.0693	.0514	.0343	.0362	.0686
5	.0343	.0686	.0693	.0514	.0343	.0362	.0686
6	.0343	.0686	.052	.0686	.0686	.0543	.0686
7	.0343	.0686	.052	.0686	.0686	.0362	.0686
8	.0343	.0686	.0514	.0686	.0686	.0362	.0686
9	.0343	.0686	.0857	.0686	.0686	.0351	.0686
10	.0343	.0857	.0686	.0686	.1029	.0343	.0686
11	.0343	.0343	.0514	.0514	.1029	.0343	.0686
12	.0343	.0686	.0343	.0343	.0857	.0343	.0686
13	.0343	.0686	.0343	.0343	.0857	.0343	.0686
14	.0343	.0514	.0343	.0343	.0362	.0857	.0686
15	.0343	.0514	.0343	.0343	.0362	.0857	.0686
16	.0343	.0514	.0343	.0343	.0362	.0857	.0686
17	.0343		.0343	.0343	.0362	.0857	.0686
18	.0686	.1029	.0514	.0686	.0905	.0686	.0686
19	.0686	.0867	.0514	.0343	.0724	.0686	.0686
20	.0686	.0693	.0514	.0343	.0724	.0686	.0686
21	.0686	.0693	.0514	.0343	.0905	.0686	.0686
22	.0686	.0867	.0514	.0343	.0905	.0686	.0686
23	.0686	.0693	.0514		.0905	.0686	.0686
24	.0343	.0686	.0693	.0514	.0343	.0543	.0686
Max	.0686	.1029	.0857	.0686	.1029	.0857	.0686
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0686
Avg	.0429	.0688	.0538	.0485	.0629	.0545	.0686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 204 / 11KV MOHITE VADGAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2378	.2561	.2987	.2926	.2926	.2987	.2926
2	.2378	.2561	.2801	.2561	.2926	.2801	.2926
3	.2561	.2561	.3361	.2378	.2926	.2801	.2926
4	.2561	.2926	.3734	.2561	.3292	.3174	.2926
5	.3292	.3658	.5228	.3292	.4024	.5228	.3292
6	.3658	.5121	.5788	.3658	.5121	.5788	.439
7	.695	.695	.6908	.695	.695	.7468	.6584
8	.5487	.5487	.5853	.5487	.5487	.2614	.6219
9	.4024	.3658	.4572	.439	.4024	.3841	.4755
10	.3292	.3292	.3475	.3292	.3658	.3292	.4755
11	.3292	.3361	.3475	.2926	.2957	.2926	.2926
12	.2926	.2987	.2926	.2926	.2402	.4024	.2743
13	.2926	.2614	.2926	.2561	.2402	.3658	.2401
14	.2561	.2614	.2561	.2195	.2772	.2743	.2743
15	.2561	.2801	.2561	.2561	.2402	.2926	.3292
16	.2561	.2801	.3292	.2926	.3326	.2926	.3086
17	.3658	.3734	.3475	.3658	.2957	.3109	.2743
18	.5853	.5228	.4024	.5121	.5228	.439	.4024
19	.695	.5975	.5853	.6219	.5788	.5487	.5487
20	.5487	.6722	.6584	.6584	.6722	.6219	.6219
21	.439	.6535	.6401	.4755	.7095	.5121	.439
22	.3658	.4108	.3658	.3292	.3921	.4024	.3475
23	.3292	.3734	.3292	.3292	.3734	.3658	.3292
24	.2378	.2926	.3361	.3292	.2926	.3361	.3292
Max	.695	.695	.6908	.695	.7095	.7468	.6584
Min	.2378	.2561	.2561	.2195	.2402	.2614	.2401
Avg	.3711	.3955	.4129	.3742	.3999	.3940	.3826

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 205 / 11 KV RAMAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0514	.0686	1.4091	1.4746	1.5432	1.4582
2	.0686	.0514	.0686	1.3763	1.4255	1.4746	1.4091
3	.0686	.0514	.0686	1.1469	1.3435	1.4575	1.3435
4	.0686	.0686	.0686	1.1142	1.2125	1.3717	1.2452
5	.0686	.0686	.1029	1.0814	1.1142	1.0802	1.1305
6	.0686	.0686	.0686	.0686	.0686	.0514	.0686
7	.0686	.0857	.0857	.0686	.0857	.0686	.0686
8	.0686	.0686	.0671	.0686	.0686	.0514	.0686
9	.0686	.0686	.0503	.0686	.0686	.0671	.0686
10	2.0317	1.0059	2.13	.0686	.0686	.0686	.0686
11	2.2775	2.5549	2.3758	.0343	.0343	.0686	.0343
12	2.3758	2.572	2.2119	.0343	.0526	.0686	.0514
13	2.4413	2.4348	2.0317	.0343	.0526	.0686	.0514
14	2.5232	2.2977	1.9662	.0343	.0526	.0686	.0343
15	2.4413	2.2462	1.8023	.0343	.0701	.0686	.0686
16	2.13	2.1091	1.6385	.0343	.0526	.0343	.0686
17	1.9989	1.8861	1.6057	.0686	.0701	.0686	.0686
18	.0857	.0514	.0686	.0686	.0686	.0686	.0686
19	.0857	.0857	.0686	.0686	.0686	.0686	.0686
20	.0857	.0686	.0686	.0686	.0686	.0686	.0686
21	.0686	.0686	.0686	.0686	.0686	.0686	.0686
22	.0686	.0686	1.4091	1.6221	1.6804	1.6057	.0686
23	.0514	.0857	1.4091	1.5893	1.6461	1.5402	.0686
24	.0686	.0514	.0686		1.5565	1.6289	1.491
Max	2.5232	2.572	2.3758	1.6221	1.6804	1.6289	1.491
Min	.0514	.0514	.0503	.0343	.0343	.0343	.0343
Avg	.8063	.7571	.8155	.4448	.5197	.5304	.3837

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 206 / 11 KV CHINCHNI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9831	1.1142	.9431	.0857	.0686	.0686	.0686
2	.9831	1.0978	.8916	.0857	.0686	.0686	.0686
3	.9831	1.065	.8745	.0857	.0686	.0686	.0686
4	.9503	1.0486	.8573		.0686	.0686	.0686
5	.9175	.9831	.8745	.0857	.0686	.0686	.0686
6	.0686	.0857	.0686		.0686	.0686	.0686
7	.0686	.12	.0857	.0857	.0686	.1029	.0857
8	.0686	.1029	.0838	.0857	.0686	.1029	.1029
9	.0686	.1029	.0671	.0857	.0686	.0671	.1029
10	.0857	.0671	.0686	.9282	.8573	1.2003	1.3032
11	.0857	.0857	.0857	1.2483	1.4403	1.3763	1.4575
12	.0857	.0857	.1029	1.3123	1.5089	1.4419	1.3375
13	.0857	.0686	.1029	1.5074	1.5089	1.4922	1.5432
14	.0857	.0686	.0686	1.5074	1.4754	1.5089	1.4746
15	.0857	.0686	.0686	1.5074	1.4754	1.5089	1.4746
16	.0686	.0686	.0686	1.3927	1.3748	1.4419	1.3375
17	.0857	.1029	.1029	1.4746	1.2574	1.3435	1.2289
18	.1029	.0857	.1029	.0686	.0686	.0686	.0686
19	.1029	.0857	.1029	.0686		.0686	.0686
20	.1029	.0857	.1029	.0686	.0686	.0686	.0686
21	.1029	.0857	.1029	.0686	.0686	.0686	.0686
22	1.1797	1.1317	.0686	.0686	.0686	.0686	.8684
23	1.1469	1.0631	.1029	.0686	.0686	.0686	.8573
24	1.0322	1.1469	1.046	.0857	.0686	.0686	.0686
Max	1.1797	1.1469	1.046	1.5074	1.5089	1.5089	1.5432
Min	.0686	.0671	.0671	.0686	.0686	.0671	.0686
Avg	.3971	.4175	.2935	.5443	.5186	.5199	.5804

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 207 / 11 KV AMBAK AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8684	1.1142	1.1584	.0686	.0686		.0686
2	.8192	1.065	1.1222	.0686	.0686	.0716	.0686
3	.8192	1.0978	1.086	.0686	.0686	.0716	.0686
4	.8192	1.0814	1.2308	.0686	.1029	.0716	.0686
5	.8192	1.0486	1.0136	.0686	.1029	.0716	.1029
6	.1029	.1029	.0724	.0857	.1372	.0895	.12
7	.1029	.1372	.1448	.0857	.1715	.1254	.12
8	.1029	.12	.1052	.1029	.1372	.1254	.1372
9	.0686	.1029	.1227	.1029	.1372	.1029	.12
10	.0686	.0876	.1029	1.0442	1.2269	1.1603	1.4419
11	.0686	.0701	.0857	1.4754	1.6476	1.2431	1.4419
12	.0686	.1052	.1029	1.3717	1.4685	1.4918	1.4255
13	.1029	.0876	.1029	1.4575	1.4685	1.5089	1.1469
14	.1029	1.6126	.1029	1.4746	1.2517		1.3599
15	.1029	.0876	.1029	1.5089	1.286	1.2407	1.3108
16	.12	.1227	.1029	1.3375	1.2517	1.3565	1.3108
17	.12	.1052			1.1145	1.2887	.1029
18	.1029	.1433	.1029		.0895	.0686	.1372
19	.1029	.1267	.1029	.12	.0895	.1029	.1372
20	.1029	.1267	.1029	.12	.0716	.12	.1372
21	.0686	.1086	.1029	.1029	.0716	.12	.9012
22	1.2289	1.1946	.0686	.1029	.0716	.0686	.9012
23	1.1797	1.1946	.0686	.1029	.0716	.0686	
24	.8684	1.1469	1.1765	.0686	.0686	.0716	.0686
Max	1.2289	1.6126	1.2308	1.5089	1.6476	1.5089	1.4419
Min	.0686	.0701	.0686	.0686	.0686	.0686	.0686
Avg	.3721	.5079	.3689	.5003	.5102	.4836	.5521

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 201 / 11 KV Wine Park 1

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2641	.1006	.1395	.06	.2075	.0838
2		.2452	.1006	.1437	.0617	.2263	.0671
3		.2452	.1006	.1164	.0724	.2263	.0671
4		.2452	.1006	.1257	.0667	.2263	.061
5		.2452	.1132	.1288	.061	.2452	.0533
6		.2641	.1299	.2241	.0876	.2452	.1677
7		.3961	.208	.3988	.0953	.2452	.5975
8		.7356	.2401	.5975	.0953	.2452	.6535
9		.9997	.2561	1.6766	.0667	.9997	.8589
10	.7167	.6602	.6401	1.5089	.1886	.5041	1.531
11	.6979	.8299	.8676	1.6032	.1698	1.0082	1.5655
12	.4904	.9808	.7733	1.3203	.1698	1.1389	1.6004
13	.3018	.5658	1.3146	1.5089	.1698	1.4937	.6722
14	.5093	.8299	1.3908	1.4146	.1886	1.5684	1.0751
15	.5847	1.1317	.9526	1.8861		1.3443	1.5655
16	.6224	1.1694	1.2826	1.5089	.1886	1.2696	1.5655
17	.9054		.7316	1.1317	.2075	1.1203	1.1506
18	1.0374		.2896	1.1317	.2075	.7095	.2315
19	.5847	.1943	.176	.9431	.2075	.6535	.7167
20	.4904	.1532	.1543	.1677	.2075	.1677	.1989
21	.2452	.1659	.2	.0953	.2075	.1593	.1395
22	.2452	.144	.1677	.0876	.2075	.1509	.1069
23	.2452	.128	.1783	.0762	.2075	.1006	.1006
24	.905	.2641	.1189	.1395	.0667	.2075	.1174
Max	1.0374	1.1694	1.3908	1.8861	.2075	1.5684	1.6004
Min	.2452	.128	.1006	.0762	.06	.1006	.0533
Avg	.5721	.4935	.4412	.7531	.1418	.6026	.6228

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 202 / 11 KV Andhali Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1886	.2263	1.8564	1.3108	1.6385	1.6975
2		.2075	.2263	1.8351	1.3108	1.587	1.6032
3		.2075	.2263	1.8187	1.3108	1.5708	1.6032
4		.2075	.2263	1.8399	1.3108	1.5708	1.6032
5		.1886	.3206	1.6575	1.3108	1.5364	1.3927
6		.1886	.3584	.3961	.3206	.3772	.3932
7		.3584	.4338	.4338	.415	.3772	.3932
8		.3584	.4338	.3772	.3772	.3772	.3605
9		.1509	.415	.3772	.3206	.3018	.2622
10	2.6595	2.5606	2.5274	.3772	.3206	.2829	.1886
11	3.0664	3.3385	2.5029	.3584	.3584	.3018	.2075
12	3.2322	3.3762	2.5587	.3395	.3772	.3206	.2452
13	3.2653	3.3951	2.3967	.3584	.132	.3206	.2829
14	3.1903	3.4328	.4218	.3584	.132	.3206	.3961
15	3.2114	3.4517	1.7652	.2829	.1509	.3018	.3395
16	3.2114	1.5844	2.9492	.2829	.3772	.3018	.3584
17	2.9959	3.4705	2.8509	.3395	.3584	.3395	.3961
18	.132	.3772	.3395	.3584	.3206	.3772	.3772
19	.3206	.3772	.3961	.4338	.3395	.3395	.3584
20	.3206	.3772	.3395	.3206	.3206	.3395	.3584
21	.3206	.3584	.3395	.3395	.2829	.3206	.3206
22	.2641	.2641	1.9826	1.5074	.1886	2.2822	.3018
23	.2075		1.8947	1.3927	1.8296	2.2634	.2641
24	1.6766	.1886	.2263	1.8564	1.3108	1.5432	1.773
Max	3.2653	3.4705	2.9492	1.8564	1.8296	2.2822	1.773
Min	.132	.1509	.2263	.2829	.132	.2829	.1886
Avg	1.8716	1.2438	1.0982	.8124	.6161	.8038	.6449

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 203 / 11Kv Andhali Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1509	.1698	.1905	.168	.1509	.1886
2		.1509	.1698	.1905	.1494	.1698	.1886
3		.1509	.1698	.2096	.168	.1698	.1886
4		.1698	.1698	.2286	.1867	.1698	.2829
5		.1698	.3395	.2667	.2241	.1698	.3395
6		.2075	.4338	.4382	.4108	.3395	.4527
7		.5093	.547	.5716	.5093	.4904	.5658
8		.415	.5093	.3772	.415	.4338	.4527
9		.3018	.3018	.3174	.3206	.3018	.3772
10	.2402	.2641	.2263	.2263	.2195	.2452	.2829
11	.2075	.2641	.2378	.181	.2075	.1698	.1867
12	.1886	.2452	.1848	.1646	.1698	.1698	.1867
13	.1698	.2452	.1663	.1478	.1509	.1698	.1867
14	.1886	.2452	.1663	.1478	.1509	.1509	.1867
15	.2075	.2263	.1578	.1646	.1509	.1698	.168
16	.2263	.2263	.156	.1991	.1509	.1698	.2054
17	.3206	.3395	.2427	.181	.3206	.2263	.2427
18	.3961	.4904	.3584	.3734	.415	.3206	.3658
19	.4904	.5281	.415	.4527	.5093	.3772	.4338
20	.5093	.4715	.3439	.415	.4715	.4527	.415
21	.3395	.3584	.3429	.2987	.3584	.415	.3395
22	.2641	.2452	.2667	.2614	.1886	.3584	.2829
23	.1886	.1886	.2096	.1867	.1698	.2075	.1905
24	.1132	.1509	.1698	.1905	.168	.1509	.1886
Max	.5093	.5281	.547	.5716	.5093	.4904	.5658
Min	.1132	.1509	.156	.1478	.1494	.1509	.168
Avg	.2700	.2798	.2690	.2659	.2647	.2562	.2874

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 204 / 11KV BAMBAWADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8215	.8162	.128	.112	.112	.112
2		.7842	.8002	.128	.112	.128	.112
3		.7842	.8002	.128	.112	.144	.112
4		.7682	.8002	.128	.112	.144	.112
5		.7682	.8322	.144	.112	.144	.128
6		.144	.176	.192	.16	.16	.16
7		.144	.2561	.2401	.208	.176	.2401
8		.176	.2561	.176	.208	.192	.192
9		.176	.176	.192	.16	.128	.176
10	.144	.144	.16	.9282	.6401	.7042	.5921
11	.16	.16	.1326	1.1203	.9602	1.1843	1.0242
12	.144	.176	.128	1.4563	1.2323	1.2803	1.0883
13	.144	.176	.128	1.4403	1.1363	1.2483	1.2963
14	.144	.16	.128	1.4403	1.1203	1.2323	1.3923
15	.144	.144	.128	1.4723	1.0883	1.2163	
16	.144	.144	.144	1.1203	1.0562	1.2003	1.4403
17	.16	.16	.144	1.3283	.9922	1.2003	1.4083
18	.176	.192	.2241	.16	.16	.16	.144
19	.176	.208	.2241	.192	.176	.176	.176
20	.176	.176	.192	.16	.176	.176	.176
21	.16	.16	.176	.176	.176	.16	.176
22		.9122	.16	.128	.16	.16	.6241
23	.8002	.8162	.144	.128	.128	.128	.5761
24	.6401	.7842		.128	.112	.112	.112
Max	.8002	.9122	.8322	1.4723	1.2323	1.2803	1.4403
Min	.144	.144	.128	.128	.112	.112	.112
Avg	.2366	.3783	.3098	.5348	.4421	.4861	.5030

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 205 / 11 KV MORALE AG

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2323	1.3923	.048	.032	.048	
2		1.2003	1.3923	.048	.032	.048	.048
3		1.2003	1.3923	.048	.032	.048	.048
4		1.2163	1.3923	.048	.048	.048	.048
5		1.2003	1.4083	.048	.048	.064	.048
6		.08	.048	.064	.064	.064	.064
7			.08	.096	.08	.08	.08
8		.08	.08	.08	.08	.096	.064
9		.08	.08	.064	.08	.08	.08
10	.048	.064	.0829	1.5203	1.5203	1.3283	1.3603
11	.064	.048	.048	1.9204	1.6324	1.5043	1.6964
12	.048	.032	.064	1.9364	1.6964	1.6644	1.7444
13	.032	.032	.064	1.8404	1.6964	1.5546	1.7124
14	.032	.032	.048	1.8084	1.6804	1.5524	1.7284
15	.032	.048	.048	1.8404	1.5684	1.5684	
16	.048	.048	.048	1.8564	1.4883	1.5844	1.5844
17		.048	.064	1.7444	1.4083	1.4243	1.5844
18	.048	.064	.08	.064	.08	.048	.08
19	.048	.064	.064	.08	.064	.048	.08
20	.064	.064	.064	.064	.064	.048	.064
21	.064	.064	.064	.064	.064	.048	.064
22	1.2963	1.5524	.048	.048	.048	.048	1.0242
23	1.3283	1.4563	.048	.048	.048	.048	.9602
24	1.1043	1.2483		.048	.032	.048	.048
Max	1.3283	1.5524	1.4083	1.9364	1.6964	1.6644	1.7444
Min	.032	.032	.048	.048	.032	.048	.048
Avg	.3041	.4850	.3522	.6428	.5661	.5455	.6460

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 206 / 11KV LIS Feeder

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5281		.2012	.0063	.0063
2		.5281		.2012	.0063	
3		.547		.2012	.0063	.0063
4		.547		.2012	.0063	
5		.547		.2012	.0063	
6		.547		.2012	.0063	
7		.547		.5093	.0063	
8		.547		.5658	.0063	
9		.5281		.1698	.3961	
10	.5975	.5281	.5041	.0084	.547	.5601
11	.8501	.5281	.5041	.0084	.5658	.6979
12	.8501	.5281	.5041	.0084	.5658	.5281
13	.8589	.5281	.5093	.0084	.547	.5281
14	.8215	.5281	.5093	.0084	.547	.3772
15	.8215	.5281	.5093	.0084	.547	.5281
16	.5601	.547	.5093	.0084		.5281
Max	.8589	.547	.5093	.5658	.5658	.6979
Min	.5601	.5281	.5041	.0084	.0063	.0063
Avg	.7657	.5364	.5071	.1569	.2511	.4178

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 401 / 33 KV SOOTGIRANI

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.6804	1.4712	1.5844	1.5123	1.6975	1.5684
2		1.7924	1.4712	1.5844	1.5684	1.6975	1.5684
3		1.7924	1.4712	1.5844	1.5684	1.6804	1.5684
4		1.7924	1.4712	1.4712	1.5684	1.6804	1.5684
5		1.7924	1.5844	1.4712	1.5684	1.6804	1.5684
6		1.7924	1.5844	1.4712	1.5684	1.6804	1.5684
7		1.6804	1.5844	1.1317	1.5123	1.6804	1.5684
8		1.4563	1.5844	1.2449	1.5684	1.6975	1.5684
9		1.3443	1.5844	1.2449	1.5123	1.8107	1.5684
10		1.3443	1.5844	1.5278	1.5123	1.7924	1.5684
11	1.4563	1.2323	1.2449	1.5844	1.3443	1.5684	1.5844
12	1.5684	1.2323	1.1317	1.5278	1.3443	1.5684	1.4712
13	1.5684	1.2323	1.1317	1.4712	1.4563	1.5684	1.4712
14	1.6804	1.4563	1.1317	1.4146	1.4563	1.5684	1.4712
15	1.6804	1.4563	1.358	1.5844	1.5684	1.4403	1.4712
16	1.7924	1.4563	1.4712	1.5278	1.7924	1.5684	1.4712
17	1.6804	1.4563	1.4712	1.1317	1.7924	1.5684	1.2449
18	1.6804	1.4563	1.4712	1.3014	1.7924	1.5684	1.2449
19	1.6804	1.4563	1.358	1.3443	1.6804	1.5684	1.1317
20	1.6804	1.4563	1.4712	1.3443	1.6804	1.5684	1.4712
21	1.6804	1.4563	1.4712	1.2323	1.3443	1.5684	1.4712
22	1.6804	1.4712	1.4712	1.2883	1.4563	1.5684	1.4712
23	1.6804	1.4712	1.4712	1.4563	1.7924	1.4563	1.6975
24		1.7924	1.4712	1.1317	1.5123	1.6804	1.4563
Max	1.7924	1.7924	1.5844	1.5844	1.7924	1.8107	1.6975
Min	1.4563	1.2323	1.1317	1.1317	1.3443	1.4403	1.1317
Avg	1.6545	1.5229	1.4382	1.4024	1.5614	1.6220	1.4922

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244129 / 33/11 KV SHIRASGAON

Feeder No / Name : 201 / 11 KV PADLI AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	1.0802	.7926	.0305	.0267	.0259	.0305
2	.8535	1.0802	.7926	.0305	.0267	.0244	.0305
3	.8535	1.0802	.7926	.0305	.0286	.0244	.0305
4	.7926	1.0802	.7316	.0305	.0286	.0259	.0305
5	.7926	1.5432	.6706	.0305	.0286	.0259	.0305
6	.0271	.0282	.0305	.0305	.0286	.0259	.0305
7	.0293	.0282	.0305	.0305	.0301	.0244	.0305
8	.0278	.0282	.0305	.0305	.0267	.0255	.0305
9	.0278	.0305	.0305	.0229	.0305	.0255	
10	.0282	.0305	.0305	1.2803	1.3717	.5487	.0305
11	.0282	.0305	.0305	1.4723	1.4815	.6097	1.7604
12	.0282	.0305		1.6842	1.4815	1.2193	1.8515
13	.0282	.0305	.0305		1.4815	1.2193	1.917
14	.0282	.0305	.0305	1.9433	1.4815	1.2193	1.8564
15	.0282	.0305	.0305	1.9433		1.2803	1.6164
16	.029	.0305	.0305	2.0081		1.2803	1.4403
17	.029	.0305	.0305	1.8785		1.2803	1.3923
18		.0305	.0305	.0267		.0305	.032
19	.029	.0305	.0305	.0251	.029	.0305	.0305
20	.029	.0305	.0305			.0305	.0305
21	.0297	.0305	.0305			.0305	.0305
22	1.0802	.8535	.0305	.0259		.0305	.9602
23	1.0802	.9145	.0305	.0259	.0259	.0305	.9282
24	.9145	1.0802	.7926	.0305	.0267	.0259	.0305
Max	1.0802	1.5432	.7926	2.0081	1.4815	1.2803	1.917
Min	.0271	.0282	.0305	.0229	.0259	.0244	.0305
Avg	.3352	.3831	.2214	.6005	.4491	.3789	.6153

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244129 / 33/11 KV SHIRASGAON

Feeder No / Name : 202 / 11 SONSAL GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3258	.2896	.3658	.3395	.2926	.5068
2	.3018	.3258	.3258	.3292	.3395	.2926	.5068
3	.3018	.3258	.362	.3658	.3395	.2926	.5068
4	.3018	.3292	.4344	.3292	.3395	.2926	.5068
5	.3395	.3658	.4706	.3658	.3772	.3292	.5068
6	.5281	.6154	.6154	.7133	.6413	.5487	.6154
7	.7095	.6516	.724	.8048	.6722	.6154	.7602
8	.5914	.6154	.6154	.7865	.5914	.6878	.7602
9	.4755	.5792	.5068	.6447	.5121	.6154	.6154
10	.362	.5068	.4344	.5373	.439	.4706	.4344
11	.3258	.4706	.3982	.5316	.3658	.543	.3982
12	.2534	.4344	.3563	.5373		.4706	.4115
13	.2534	.4706	.3563	.5068		.4706	.4115
14	.2534	.3982	.362	.4706		.4706	.4344
15	.3258	.4344	.2896	.4706		.4344	.4344
16	.362	.3258	.3439	.4706		.4344	.4706
17	.4344	.3982	.2715	.4557		.6154	.4706
18		.4706	.5792	.6219		.6154	.4706
19	.6516	.5792	.7059	.7762	.4344	.6878	.7602
20	.724	.6154	.724			.6154	.6516
21	.6878	.543	.5973			.6154	.5611
22	.6154	.3982	.543			.5068	.4706
23	.362	.362	.4706	.3582	.2926	.5068	.4344
24	.3018	.3258	.2896	.3982	.3772	.2926	.5068
Max	.724	.6516	.724	.8048	.6722	.6878	.7602
Min	.2534	.3258	.2715	.3292	.2926	.2926	.3982
Avg	.4245	.4528	.4611	.5162	.4329	.4882	.5253

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244129 / 33/11 KV SHIRASGAON

Feeder No / Name : 203 / 11 KV SONKIRE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0419	.0579	.0648	1.1203	1.0883	1.0753	1.166
2	.0457	.0579	.0648	1.0883	1.0883	1.0753	1.1336
3	.0457	.0579	.0648	1.0883	1.0402	1.012	1.1336
4	.0457	.0579	.0648	1.0883	1.0402	1.012	1.1012
5	.0465	.0594	.0648	1.0402	1.0402	1.012	1.0688
6	.06	.0594	.0648	.064	.0457	.0594	.0648
7	.0579	.0579	.0648	.08	.0381	.0564	.0648
8	.0724	.0579	.0648	.0457	.0495	.0533	.0648
9	.061	.0648	.0486	.061	.048	.0533	.0457
10	1.5813	1.587	1.5223	.061	.0533	.0648	.061
11	1.866	1.9271	1.8461	.0762	.0533	.0648	.061
12	1.9766	1.9433	2.0891	.0762	.0667	.0648	.061
13	1.9766	1.9919	1.8461	.0762	.0667	.0648	.0457
14	1.9766	1.9919	1.8299	.0762	.0667		.061
15	1.9766	1.9919	1.749	.0762		.0648	.061
16	1.8976		1.749	.0762		.0648	.061
17	1.7394	1.8947	1.7166	.0724		.0648	.061
18		.0648	.0648	.0724		.0648	.061
19	.0762	.0648	.0724	.0648	.0446	.0648	.061
20	.0762	.0648	.061			.0648	.061
21	.0594	.0648	.0305			.0648	.061
22	.0594	.0648	1.2003	1.0974		1.166	.061
23	.0594	.0648	1.2003	1.1523	1.1069	1.166	.061
24	.0495	.0594	.0648	1.1523	1.1523	1.1069	1.166
Max	1.9766	1.9919	2.0891	1.1523	1.1523	1.166	1.166
Min	.0419	.0579	.0305	.0457	.0381	.0533	.0457
Avg	.6890	.6220	.7337	.4457	.4758	.4157	.327

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 201 / 11 KV DEORASHTRE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17
HR	Load (MW)
24	1.6766
Max	1.6766
Min	1.6766
Avg	1.6766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 202 / 11KV KUNDAL

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 203 / 11 KV PALUS

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17
HR	Load (MW)
24	1.6766
Max	1.6766
Min	1.6766
Avg	1.6766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 204 / 11 KV LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 205 / 11 KV TAKARI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 405 / 33 KV EBARA NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-DEC-17
HR	Load (MW)
24	2.8292
Max	2.8292
Min	2.8292
Avg	2.8292

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 407 / 33KV KRANTI CO-GENERATION NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-DEC-17
HR	Load (MW)
24	.5658
Max	.5658
Min	.5658
Avg	.5658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 408 / Kranti Co-Gen-II NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-DEC-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 259009 / 400KV KARAD STN.

Feeder No / Name : 807 / 220 KV KARAD KOP LINE 2 ND NON SHEDDABLE EHV INDUSTRIAL FEEDERS
CRT Feeder KV- 220 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-DEC-17
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 201 / KADEPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1069	1.4083	1.7924	.2195	.1829	.1829	.1494
2	1.1069	1.4083	1.7284	.1463	.1829	.1848	.1463
3		1.4083	1.6644	.1463	.1829	.1829	.1463
4		1.4083	1.6004	.1478	.1829	.181	.1494
5		1.4403	1.5546	.2218	.1829	.1829	.1494
6		.1829	.1448	.2957	.1867	.1829	.1867
7		.1829	.2195	.2957	.2054	.1829	.2241
8		.2195	.2926	.3696	.2054	.2534	.2241
9		.2534	.2957	.2957	.2218	.2896	.2587
10		.362	.3696	1.448	2.3703	2.3594	1.7814
11		.3658	.3658	2.0119	2.7368	2.5911	2.13
12	.2534	.3277	.3658	2.2447	2.7854	2.9835	2.2119
13	.2926	.3277	.4435	2.2119	2.8509	2.8826	2.2939
14	.3292	.362	.4435	2.2119		2.8826	2.2939
15	.2926	.4298	.4481	2.2119		2.7206	2.13
16	.2926	.4344	.4344	2.3758	.3277	2.753	2.13
17	.2743	.4344	.4344	2.2447	2.536	2.5911	2.13
18	.181	.2241	.3658	.1829	.1227	.1829	.1097
19	.2195	.2218	.2926	.1829	.2103	.1829	.128
20	.2195	.2218	.3696	.1829	.2149	.1848	.128
21	.1829	.2195	.2957	.1829	.2172	.1658	.128
22	1.4243	1.9662	.2957	.1829	.181	.1494	1.0936
23	1.4723	1.8785	.2218	.1829	.1791	.1494	1.0155
24	1.2018	1.4723	1.8785	.2218	.1829	.1829	.1494
Max	1.4723	1.9662	1.8785	2.3758	2.8509	2.9835	2.2939
Min	.181	.1829	.1448	.1463	.1227	.1494	.1097
Avg	.5900	.7150	.6799	.8508	.7568	1.0327	.8953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 203 / 11 KV Wangi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0305	.4512	.4687	.6401	.6706
2	.0343	.0343	.0309	.4001		.6401	.6706
3	.0343	.0335	.0312	.4001	.4687	.6401	.6097
4	.0343	.0663	.0316	.4001	.4374	.6478	.6173
5	.0343	.0663	.0633	.4633	.4374	.583	.6874
6	.0343	.0686	.0655	.0701	.0732	.0701	.0701
7	.0343	.0693	.0716	.0724	.0732	.0701	.0724
8	.0351	.0693	.0732	.0678	.0701	.0701	.0716
9	.0343	.0678	.0343	.0648	.0686	.0709	.0671
10	.9031	.9374	.9877	.0305	.0701	.0732	.0686
11	1.3123	1.2651	1.1248	.0343	.0655	.0724	.0701
12	1.3123	1.3443	1.2803	.0358	.0663	.0655	.0686
13	1.4548	1.4548	1.2803	.0358	.0663	.0701	
14	1.4548	1.4083	1.3443	.0351	.0663	.0693	.0686
15	1.4548	1.2803	1.3443	.0686	.0686	.0724	.0686
16	1.4548	1.2651	1.2651	.0686	.0693	.0709	.0686
17	1.2963	1.3123	1.1248	.0686	.0701	.0701	.0686
18	.0633	.0633	.061	.0686	.0701	.0686	.0686
19	.0648	.0633	.0648		.0716	.0686	.0686
20	.0648	.061	.0335	.0686	.0709	.0686	.0686
21	.0655	.0594	.0324	.0701	.0678	.0678	.0686
22	.0655	.0594	.535	.6584	.7682	.7407	.0686
23	.0655	.0297	.5281	.4999	.7362	.7407	.0686
24	.0343	.0343	.0301	.5144	.4999	.6401	.7407
Max	1.4548	1.4548	1.3443	.6584	.7682	.7407	.7407
Min	.0343	.0297	.0301	.0305	.0655	.0655	.0671
Avg	.4740	.4645	.4779	.2021	.2141	.2663	.2248

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 204 / 11 KV AMARAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1387	.1448	.1475		.1372	.1463
2		.1387	.1448	.1341		.1402	.1463
3		.1387	.1254	.12		.1433	.1463
4		.1387	.1448	.1387		.1433	.1629
5		.1753	.1646	.1595		.1791	.181
6		.2534	.2204	.2149		.2195	.2353
7		.3012	.3045	.2926		.2926	.3109
8		.2058	.2454	.2561		.2896	.2378
9		.1943	.1593	.1943		.2561	.1423
10		.1094	.192	.1928		.1578	.1402
11		.1	.1486	.1715		.1423	.1463
12	.1457	.0869	.1355	.128		.1389	.128
13	.128	.1067	.1189	.1372		.1337	.128
14	.1265	.125	.104	.1029	.0152	.1174	.128
15	.1265	.112	.1027	.1029	.016	.1	.0857
16	.1107	.0903	.1219	.12	.096	.1337	.12
17		.1372	.1593	.1543	.1989	.1353	.1715
18	.2713	.1943	.208	.2401	.1989	.208	.1886
19	.2947	.2713	.2561	.2629	.2401	.2427	.2229
20	.2774	.2515	.2561	.2572	.2601	.2601	.2229
21	.2543	.2347	.2279	.2572	.2427	.2401	.1715
22	.2103	.181	.1734	.1372	.1991	.197	.1029
23	.1907	.1829	.1677		.1526	.181	.1052
24		.1734	.1646	.1475		.1357	.1629
Max	.2947	.3012	.3045	.2926	.2601	.2926	.3109
Min	.1107	.0869	.1027	.1029	.0152	.1	.0857
Avg	.1942	.1684	.1746	.1769	.1620	.1802	.1639

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 205 / 11 KV Wangi Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1646	.1494	.124	.1753	.128	.1646
2	.1829	.1646	.1307	.1254	.1753	.1267	.1463
3	.1829	.1646	.1478	.1463	.1753	.1254	.1463
4	.1829	.1646	.1478	.1663	.1753	.124	.1829
5	.2012	.1829	.1663	.1867	.1928	.1848	.2012
6	.2561	.2743	.2561	.2743	.2561	.2263	.2772
7	.2743	.3109	.2926	.3142	.3109	.2772	.3292
8	.2926	.2686	.2534	.2957	.2743	.2804	.3292
9	.2743	.208	.2623	.285	.2279	.2915	.3315
10	.192	.213	.2006	.1677	.2103	.1492	.2572
11	.208	.2315	.1957	.2058	.1619	.1875	.2572
12	.16	.1562	.192	.1886	.1638	.216	.2012
13	.2187	.1852	.1739	.1802	.1578	.2031	.2401
14	.192	.1829	.1875	.2195	.1543	.2187	.2401
15	.176	.1875	.2031	.2195	.128	.2378	.2378
16	.1739	.1981	.1852	.1928	.1357	.1677	.2561
17	.1852	.192	.2187	.2279	.1907	.2054	.2561
18	.2303	.2229	.2229	.2401	.1478	.2155	.2629
19	.2896	.2629	.2353	.2572	.1829	.2715	.2926
20	.2686	.2427	.2353	.2401	.1867	.2686	.2561
21	.2303	.2401	.2172	.2229	.1867	.2481	.2561
22	.2054	.168	.1663	.1715	.1663	.2054	.2378
23	.1867	.1698	.1417	.1715	.1307	.1867	.2378
24	.1829	.1867	.1509	.1372	.1715	.1307	.1867
Max	.2926	.3109	.2926	.3142	.3109	.2915	.3315
Min	.16	.1562	.1307	.124	.128	.124	.1463
Avg	.2137	.2059	.1972	.2067	.1849	.2032	.2410

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 206 / 11 KV CHIKHALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3763	1.5729	1.2955	.0724	.0701	.0724	.0701
2	1.3763	1.5546	1.2955	.0366	.0701	.0716	.0709
3	1.3763	1.4899	1.2308	.0366	.0701	.0716	.0709
4	1.3763	1.4899	1.3108	.0739	.0701	.0732	.0701
5	1.3763	1.4899	.1029	.0924	.0701	.0732	.1052
6	.0693	.1448	.1029	.104	.0732	.0747	.1063
7	.0686		.1086	.112		.0739	.1417
8	.0686	.1433	.1063	.1075		.0732	.1387
9	.1029	.1372	.1052	.0995		.0724	.0983
10	.1311	.104	.1086	1.3748		1.6385	1.9433
11	.1463	.1063	.1017	2.2939	1.9845	2.2939	2.4006
12	.1086	.1052	.0926	2.6871	1.9845	2.4531	2.2939
13	.1075	.1075	.0983	2.6216	1.9433	2.4905	2.2939
14	.1097	.1086	.1017	2.7496	1.9662	2.2939	2.2939
15	.1097	.1052	.1063	2.6216	1.9006	2.2939	2.2939
16		.1109	.1063	2.8121	1.9662	2.1628	2.2939
17	.0983	.104	.0983	2.7435	1.989	1.7924	2.2939
18	.0995	.1075	.1086	.0686	.0625	.0655	.0914
19	.1387	.1097	.1109	.0701	.0701	.1029	.0876
20	.104	.1075	.1109	.0701	.0716	.1029	.0701
21	.104	.104	.1109	.0701	.0747	.1017	.0701
22	1.704	1.4419	.2957	.0716	.0716	.1052	1.2651
23	1.6385	1.3763	.1097	.0701	.0716	.1052	1.1717
24	1.4232	1.6385	1.3763	.1075	.0701	.0747	.0701
Max	1.704	1.6385	1.3763	2.8121	1.989	2.4905	2.4006
Min	.0686	.104	.0926	.0366	.0625	.0655	.0701
Avg	.5745	.5982	.3623	.8820	.7325	.7806	.9086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 207 / KADEPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3395	.3584	.3395	.2829	.1848	.3772
2	.3018	.3395	.3395	.3584	.2829	.1829	.3772
3	.3018	.3395	.3395	.3772	.2829	.1848	.3772
4	.3395	.3772	.3206	.3961	.2829	.2195	.415
5	.3772	.415	.3206	.415	.3395	.2896	.4338
6	.4527	.4904	.4527	.5281	.3772	.3361	.5281
7	.4715	.547	.5281	.5847	.415	.3696	.5847
8	.4904	.3395	.4715	.4715	.3395	.2957	.5281
9	.4527	.3772	.4338	.4904	.1886	.2614	.4338
10	.4338	.3961	.3961	.415	.1663	.2263	.3584
11	.415	.3961	.4338	.4338	.1867	.2378	.415
12	.4527	.415	.415	.4075	.1848	.2218	.3961
13	.3772	.415	.415	.415	.1867	.2641	.3961
14	.415	.3961	.3961	.3961	.1867	.2452	.3961
15	.415	.3961	.3961	.4294	.1848	.2829	.3772
16	.415	.3018	.3395	.2801	.1829	.3395	.3961
17	.3961	.415	.3772	.2641	.2218	.3395	.415
18	.4527	.415	.415	.3206	.2195	.3961	.4294
19	.4715	.3772	.5093	.3772	.2587	.415	.4481
20	.3961	.3961	.4904	.3395	.2561	.415	.4481
21	.415	.3961	.3961	.3018	.2507	.3961	.4481
22	.3772	.415	.415	.3206	.2149	.415	.3921
23	.3772	.3961	.3772	.3018	.1886	.415	.3734
24	.3395	.3772	.3772	.3395	.3018	.1867	
Max	.4904	.547	.5281	.5847	.415	.415	.5847
Min	.3018	.3018	.3206	.2641	.1663	.1829	.3584
Avg	.4016	.3945	.4047	.3876	.2493	.2967	.4237

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 401 / SAGARESHWAR SAHAKARI SOOT NON SHEDDABLE EXPRESS HV FEEDERS
 GIRA Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3765	2.3765	2.4897	2.4331	2.2634	1.1883	2.3765
2	2.3765	2.3765	2.6029	2.4331	2.2634	1.1317	2.3765
3	2.3765		2.6029	2.4897	2.2634	1.1317	2.3765
4	2.3765	2.3765	2.6595	2.4897	2.2634	1.1317	2.3765
5	2.3765	2.6029	2.7161	2.4897	2.3765	1.1317	2.3765
6	2.5463	2.6029	2.6029	2.4897	2.5463	1.1883	2.5463
7	2.5463	2.6595	2.6029	2.5463	2.5463	1.2449	2.5463
8	2.3765	2.4897	2.5463	2.5463	2.2634	1.1317	2.5463
9	2.4897	2.32	2.32	2.5463	1.2449	2.4331	2.3765
10	2.4331	2.4331	2.4897	2.32	1.1317	2.5463	2.3765
11	2.4897	2.4331	2.2634	2.6029	1.2449	2.5463	2.2068
12	2.4897	2.4897	2.6595	2.6595	1.2449	2.6595	2.5463
13	2.4897	2.4331	2.6029	2.7161	1.3014	2.6029	2.6595
14	2.3765	2.4897	2.6029	2.7161	1.2449	2.5463	2.7726
15	2.4897	2.6029	2.6029	2.6595	1.2449	2.6029	2.4897
16	2.4897	2.5463	2.4331	2.6029	1.2449	2.6029	2.6595
17	2.4331	2.32	2.32	2.6029	1.2449	2.5463	2.5463
18	2.32	2.4331	2.3765	2.3765	1.2449	2.4897	2.4897
19	2.32	2.4897	2.3765	2.32	1.2449	2.3765	2.32
20	2.3765	2.4331	2.2634	2.2634	1.2449	2.3765	2.2634
21	2.2634	2.32	2.32	2.2634	1.0751	2.1502	2.2634
22	2.3765	2.4897	2.3765	2.2634	1.3014	2.3765	2.3045
23	2.3765	2.4331	2.3765	2.2634	1.1883	2.3765	2.3765
24	2.2634	2.3765	2.4331	2.4331	2.2634	1.1317	2.3765
Max	2.5463	2.6595	2.7161	2.7161	2.5463	2.6595	2.7726
Min	2.2634	2.32	2.2634	2.2634	1.0751	1.1317	2.2068
Avg	2.4095	2.4577	2.4850	2.4803	1.6457	1.9852	2.4395

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 201 / Kadegaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6584	.4715	.5041	.5228	.6584	.6348	.547
2	.5544	.4251	.5093	.5041	.5914	.6348	.4805
3	.5487	.4251	.5093	.5093	.5487	.6722	.4805
4	.6516	.5228	.5658	.5658	.543	.7167	.5041
5	.7164	.6413	.6602	.679	.7316	.8299	.5788
6	1.0974	.8589	.9808	1.094	1.1088	1.0185	.9619
7	1.3491	1.419	1.4003	1.4712	1.5278	1.5684	1.475
8	1.134	1.4901	1.4003	1.3443	1.2437	1.3443	1.5278
9	1.0719	1.1949	1.2136	1.1949	1.1273	1.1088	1.3014
10	.9328	.9055	.961	.9774	1.0059	1.0242	.8962
11	.8779	.7602	.8326	.9145	.905	.9412	.8145
12	.7964	.7602	.7964	.8326	.788	.8048	.7164
13	.7522	.7164	.7964	.7164	.6556	.7522	.7087
14	.7522	.6697	.7783	.695	.6379	.7059	.6805
15	.7059	.6335	.7602	.6653	.6447	.6984	.6805
16	.6805	.6805	.7522	.7316	.6805	.6984	.7164
17	.7602	.7888	.7442	.7964	.724	.7164	.7087
18	.9313	.9145	1.0387	1.0387	1.0164	1.0242	1.0059
19	1.0829	1.2936	1.2803	1.1104	1.4563	1.1694	1.2012
20	1.1458	1.2567	1.0974	1.1706	1.307	1.1694	1.2136
21	1.0185	1.1088	1.0719	1.1088	1.0456	1.0082	1.0642
22	.8215	.924	.7468	1.0456	.7468	.9054	.8402
23	.679	.7468	.6161	.9054	.6722	.6838	.5975
24	.7762	.5093	.5228	.5601	.7392	.6535	.5975
Max	1.3491	1.4901	1.4003	1.4712	1.5278	1.5684	1.5278
Min	.5487	.4251	.5041	.5041	.543	.6348	.4805
Avg	.8540	.8382	.8558	.8814	.8794	.8952	.8458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 202 / MIDC No.1

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6461	1.5604	1.5089	1.4403	1.4746	1.4403	1.701
2	1.6263	1.595	1.5604	1.4575	1.3443	1.4403	1.6832
3	1.6057	1.5089	1.6301	1.4746	1.3927	1.4746	1.6834
4	1.5364	1.5261	1.6301	1.491	1.4746	1.491	1.6476
5	1.5074	1.5775	1.6301	1.5257	1.406	1.5257	1.7193
6	1.4746	1.5604	1.5604	1.5769	1.4373	1.5257	1.7193
7	1.6095	1.5432	1.595	1.5947	1.4403	1.5775	1.6476
8	1.576	1.5604	1.6126	1.6476	1.2003	1.6301	1.6476
9	1.6632	1.6476	1.6476	1.7013	1.1218	1.6655	1.6476
10	1.6126	1.6476	1.6476	1.7013	.7773	1.7193	1.7193
11	1.6476	1.829	1.7924	1.7375	.7773	1.7193	1.6834
12	1.6118	1.829	1.7924	1.7193	.6478	1.7924	1.6655
13	1.5089	1.6655	1.8107	1.7372	.6089	1.6126	1.491
14	1.6827	1.8099	1.7737	1.701	.6127	1.6655	1.4746
15	1.6476	1.8099	1.7737	1.7375	.6382	1.7551	1.7013
16	1.5089	1.7193		1.7741	.6539	1.7556	1.7558
17	1.5089	1.701	1.4403	1.7737	.6687	1.8107	1.829
18	1.5775	1.4563	1.6126	1.7558	.6401	1.885	1.6834
19	1.5775	1.6476	1.595	1.7013	.9145	1.7193	1.7375
20	1.595	1.5604	1.5947	1.7193	1.2574	1.7558	1.6476
21	1.5089	1.5947	1.6118	1.7002	1.6301	1.7375	1.7193
22	1.5089	1.4563	1.5424	1.6461	1.5424	1.7556	1.6301
23	1.3413	1.4563	1.4232	1.6263	1.4232	1.7556	1.6301
24	1.6651	1.4419	1.4403	1.4403	1.5729	1.4403	1.7741
Max	1.6827	1.829	1.8107	1.7741	1.6301	1.885	1.829
Min	1.3413	1.4419	1.4232	1.4403	.6089	1.4403	1.4746
Avg	1.5729	1.6127	1.6185	1.6409	1.1107	1.6521	1.6766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 203 / Shalgaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0924	.0549	.0543	.8278	.9922	.9374	1.0437
2	.0732	.0554	.0549	.8128	.9945	.9061	.9804
3	.0724	.056	.056	.8128	.9503	.8642	.9374
4	.0732	.0739	.056	.7827	.8962	.8333	.9172
5	.1109	.0739	.056	.7827	.8745	.7716	.9282
6	.1463	.132	.1132	.1132	.1097	.1132	.132
7	.1848	.1698	.1509	.1132	.1886	.112	.1886
8	.1463	.1886	.1494	.112	.1463	.112	.1663
9	.1294	.1478	.1109	.1109	.1294	.1097	.1109
10	1.6385	1.8023	1.8564	.12	.1829	.0732	.1097
11	2.3266	2.2939	1.821	.1052	.1075	.1109	.0709
12	2.6216	2.2939	1.8976	.0895	.0857		.0701
13	2.5232	2.1628	1.9044	.0724	.0819		.0686
14	2.3922	2.13	1.8564	.0732	.0838		.1052
15	2.2283	2.0243	1.8461	.0739	.0838		.0876
16	1.9498	2.0243	1.6324	.0914	.0848	.1097	.1075
17	1.8724	1.9766	1.4998	.0924	.0857	.1109	.1052
18	.0895	.104	.1017	.112	.1097	.1294	.1086
19	.0924	.1463	.1052	.1132	.1109	.1509	.1294
20	.112	.1267	.1097	.0934	.1109	.132	.1294
21	.1132	.1097	.1109	.0739	.112	.1132	.1109
22	.0747	.0747	.945	.6401	1.0753	1.1702	.1109
23	.0554	.0732	.888	.852	.9998	1.1561	.0724
24	.128	.0537	.0543	.8278	.9945	.9686	1.1069
Max	2.6216	2.2939	1.9044	.852	1.0753	1.1702	1.1069
Min	.0554	.0537	.0543	.0724	.0819	.0732	.0686
Avg	.8019	.7645	.7263	.3291	.3996	.4492	.3291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 204 / Kadegaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3592	1.5043	1.6004	.1326	.0905	.0857	.0732
2	1.3108	1.4723	1.5023	.1326	.0924	.0876	.0739
3	1.2483	1.4232	1.4232	.1311	.0732	.0876	.0739
4	1.2163	1.3916	1.4232	.1311	.0732	.0886	.0914
5	1.2186	1.3916	1.4232	.1296	.0924	.0895	.1097
6	.1097	.1663	.1086	.1341	.112	.0895	.1663
7	.1463	.2012	.1829	.1715	.1478	.1097	.2197
8	.1267	.2054	.2218	.1928	.0905	.128	.1848
9	.1646	.2218	.1829	.2126	.1829	.1463	.1886
10	.1663	.1791	.1772	1.7814	2.0328	1.6194	1.8023
11	.1646	.1867	.1433	2.5606	1.8185	2.0645	2.4863
12	.0686	.1478	.1433	2.9797	1.866	2.556	2.5857
13	.1463	.1494	.1433	2.9492	1.9292	2.3922	2.8509
14	.1254	.1494	.1646	2.8178	1.8976	2.2939	2.8178
15	.1463	.1494	.1646	2.5606	1.8185	2.1464	2.8178
16	.1848	.181	.1646	2.3266	1.7497	2.2939	2.5857
17	.1698	.1734	.181	2.2542	1.7029	2.2939	2.3868
18	.1791	.1734	.1715	.1097	.1134	.1254	.1417
19	.1646	.1791	.1715	.1267	.12	.128	.1848
20	.1848	.1448	.1696	.1463	.1052	.1254	.1463
21	.168	.1417	.1492	.1663	.1063	.1294	.1478
22	1.8564	1.8138	.1326	.1478	.0857	.1109	1.3763
23	1.7204	1.7814	.1326	.1307	.0848	.0895	1.3283
24	1.3763	1.6004	1.7284	.1326	.1097	.0857	.0895
Max	1.8564	1.8138	1.7284	2.9797	2.0328	2.556	2.8509
Min	.0686	.1417	.1086	.1097	.0732	.0857	.0732
Avg	.5718	.6304	.5002	.9399	.6873	.8070	1.0387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 206 / SHALGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587	.1663	.1848	.1848	.2587	.1848	.1886
2	.2195	.168	.1867	.1867	.1829	.1848	.168
3	.181	.1509	.1886	.1867	.181	.2241	.168
4	.2195	.1867	.1886	.2263	.2195	.2614	.1848
5	.2957	.2452	.2263	.2829	.2957	.3772	.2987
6	.4024	.3881	.4527	.4715	.4024	.4527	.3841
7	.5853	.6161	.6722	.6722	.6584	.6722	.6584
8	.5487	.5975	.5975	.5853	.5544	.5487	.5729
9	.4938	.5729	.4656	.4298	.3658	.4607	.5281
10	.4435	.4481	.3856	.373	.3696	.3814	.3856
11	.3761	.2774	.3155	.3429	.3292	.3441	.2401
12	.3045	.2774	.298	.3155	.2507	.3647	.2103
13	.218	.2743	.2804	.2865	.1753	.285	.2804
14	.2279	.2804	.2481	.2926	.1753	.3441	.2126
15	.2294	.2427	.2481	.2896	.1753	.3772	.2058
16	.3018	.3121	.2804	.3292	.208	.3521	.2401
17	.394	.3467	.3258	.3696	.2427	.3018	.2401
18	.4207	.4607	.4161	.4481	.4557	.5609	.3814
19	.462	.5373	.5373	.4904	.5731	.5121	.5544
20	.499	.4854	.4755	.5544	.5487	.5175	.4854
21	.3881	.4108	.3921	.4805	.3584	.3921	.4108
22	.2987	.2987	.3361	.439	.2614	.3361	.2987
23	.2033	.2241	.2033	.362	.1848	.2263	.2218
24	.2957	.1829	.1848	.1848	.2926	.1848	.2075
Max	.5853	.6161	.6722	.6722	.6584	.6722	.6584
Min	.181	.1509	.1848	.1848	.1753	.1848	.168
Avg	.3445	.3396	.3371	.3660	.3217	.3686	.3219

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 207 / 11 KV KHAMBALE-A AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.0924	.0747	1.1203	1.1523	1.2803	1.3283
2	.0554	.0747	.0754	1.0883	1.1336	1.2803	1.2967
3	.0554	.0943	.0754	1.0562	1.0814	1.2003	1.2018
4	.0732	.0739	.0754	1.012	1.0608	1.1203	1.1702
5	.0724	.0754	.0754	.9646	1.0155	1.0883	1.1523
6	.0914	.1294	.0943	.0943	.1097	.0754	.1132
7	.1097	.1509	.1478	.0943	.112	.0943	.1294
8	.1294	.1294	.1294	.112	.0914	.112	.1109
9	.1097	.112	.0914	.112	.0914	.112	.1132
10	1.7604	1.9989	2.0222	.1097	.0732	.1109	.0943
11	2.3922	2.5692	2.0153	.1109	.0732	.0554	.0739
12	2.556	2.1879	2.0481	.0914	.0724	.0747	.0724
13	.8642	2.5194	2.13		.0724	.0739	.0732
14	2.2542	2.5692	2.1879	.0732	.0732	.0554	.0724
15	2.5857	2.4863	2.2045	.0732	.0732	.0549	.0701
16	2.5029	2.3205	1.9662	.0739	.0739	.0554	.0716
17	2.2775	1.9433	1.7004	.0549	.0739	.0554	.0732
18	.1075	.0701	.0701	.0747	.0747	.0566	.0732
19	.1097	.132	.0716	.0914	.0747	.1132	.1132
20	.132	.1132	.0732	.1109	.0747	.0943	.0747
21	.1109	.1132	.0747	.112	.0747	.0754	.0747
22	.0943	.0943	1.2163	.9831	1.4899	1.5729	.0754
23	.0754	.0943	1.1843	1.0774	1.4413	1.5893	.0747
24	.0732	.0943	.0747	1.1523	1.1469	1.3603	1.4723
Max	2.5857	2.5692	2.2045	1.1523	1.4899	1.5893	1.4723
Min	.0549	.0701	.0701	.0549	.0724	.0549	.0701
Avg	.7770	.8433	.8283	.4280	.4504	.4901	.3823

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 208 / MIDC NO 3

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER MIDC EQUIVALENT

HAVING WEEKLY STAGGERING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9511	1.2323	1.134	1.086	.9145	.9709	1.2696
2	.924	1.2826	1.134	1.1222	.905	.9882	1.2071
3	.9877	1.251	1.1765	1.1584	.823	.9991	1.1949
4	1.0242	1.2197	1.1765		.8048	.9991	1.2449
5	1.0745	1.2449	1.1765	1.2308	.7373	1.0166	1.134
6	.9568	1.251	1.0288	1.1643	.6802	1.0166	1.1949
7	1.0208	1.2382	1.0745	1.1706	.68	1.0631	1.1694
8	1.0974	1.1088	.964	1.1706	.5868	1.0924	1.1949
9	1.3306	1.0642	1.0631	1.1946	.591	1.1222	1.3014
10	1.3535	1.5278	1.4146	1.5684	.5283	1.2567	1.8673
11	1.419	1.6032	1.4146	1.6975	.5083	1.6598	1.7918
12	1.4712	1.5089	1.5089	1.7002	.4995	1.5844	1.4003
13	1.3957	1.4937	1.6598	1.6827	.4887	1.39	1.307
14	1.2883	1.8861	1.6975	1.7372	.4694	1.6221	1.6032
15	1.4335	1.6975	1.7353	1.7741	.4694	1.475	1.7918
16	1.3957	1.8861	1.4937	1.7558	.4506	1.6221	1.6975
17	1.3443	1.7918	1.4045	1.6632	.4424	1.6221	1.5089
18	1.1104	1.4937	1.2752	1.4377	.4481	1.773	1.5089
19	1.2323	1.4003	1.2012	1.3676	.6135	1.7551	1.6032
20	1.2071	1.5089	1.134	1.2803	.7621	1.4335	1.5089
21	1.2637	1.0985	1.0974	1.358	.929	1.4712	1.6032
22	1.2323	1.1458	1.0791	1.1203	.9465	1.3443	1.307
23	1.2637	1.1458	1.0498	.9979	.9709	1.2071	1.2012
24	.9877	1.2071	1.134	1.086	.961	.9709	1.2637
Max	1.4712	1.8861	1.7353	1.7741	.9709	1.773	1.8673
Min	.924	1.0642	.964	.9979	.4424	.9709	1.134
Avg	1.1986	1.3870	1.2595	1.3706	.6754	1.3106	1.4115

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / BELAWADE S/STN

Feeder No / Name : 201 / 11 KV Tondoli

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	03-DEC-17	04-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1494	
2			.1494	
3			.1478	
4			.1494	
5			.1867	
6			.2534	
7			.3224	
8			.2926	
10		.1475		2.4006
11		.2957		3.2322
12		.2957		3.0476
13		.2172		3.0121
14		.2218		3.0996
15		.2614		3.083
16		.2263		2.9492
17		.2241		
18		.2561		.1629
19		.2561		.2926
20		.2587		.2743
21		.2218		.2957
22		.1848		1.3923
23		.1494		1.5089
24	2.1216		.1478	
Max	2.1216	.2957	.3224	3.2322
Min	2.1216	.1475	.1478	.1629
Avg	2.1216	.2298	.1999	1.9039

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082] BU 6254

Substation No/ Name :- 244079 / BELAWADE S/STN

Feeder No / Name : 202 / 11 KV Raigaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	03-DEC-17	04-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			2.1795	
2			2.0222	
3			1.9784	
4			1.8233	
5			1.6842	
6			.0895	
7			.1227	
8			.1848	
10		1.5238		.1715
11		2.8166		.1677
12		2.7846		.1433
13		2.9508		.1372
14		2.8502		.1829
15		2.9569		.2126
16		2.5194		.2427
17		2.3205		
18		.1829		.2218
19		.1052		.1734
20		.1254		.1417
21		.124		.1448
22		1.989		.1478
23		2.3472		.1448
24	.1509		2.2377	
Max	.1509	2.9569	2.2377	.2427
Min	.1509	.1052	.0895	.1372
Avg	.1509	1.8283	1.3691	.1717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082] BU 6254

Substation No/ Name :- 244079 / BELAWADE S/STN

Feeder No / Name : 203 / SOHOLI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	03-DEC-17	04-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4108	
2			.3734	
3			.3696	
4			.4108	
5			.4481	
6			.7392	
7			.8589	
8			.8215	
10		.5853		.543
11		.5175		.4252
12		.5121		.4908
13		.5175		.4607
14		.5175		.5121
15		.4805		.3982
16		.5014		.4961
17		.5121		
18		.6584		.6089
19		.8131		.8501
20		.7468		.8131
21		.6653		.6584
22		.5544		.5601
23		.4481		.4805
24	.439		.4435	
Max	.439	.8131	.8589	.8501
Min	.439	.4481	.3696	.3982
Avg	.439	.5736	.5418	.5613

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082] BU 6254

Substation No/ Name :- 244079 / BELAWADE S/STN

Feeder No / Name : 204 / 11 KV UPALE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	03-DEC-17	04-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0819	
2			.0819	
3			.0819	
4			.0983	
5			.1147	
6			.1638	
7			.1966	
8			.1638	
10		.1475		1.4255
11		.1311		1.6712
12		.1475		1.7204
13		.1311		1.7532
14		.1311		1.7859
15		.1638		1.5402
16		.1311		1.5238
17		.1638		
18		.1802		.0819
19		.1802		.1311
20		.1638		.1311
21		.1475		.1311
22		.1147		1.4746
23		.0819		1.6385
24	1.6712		.0819	
Max	1.6712	.1802	.1966	1.7859
Min	1.6712	.0819	.0819	.0819
Avg	1.6712	.1440	.1183	1.1545

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / BELAWADE S/STN

Feeder No / Name : 205 / 11 KV BOMBALEWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	03-DEC-17	04-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			2.13	
2			2.0317	
3			1.9662	
4			1.8023	
5			1.6549	
6			.1147	
7			.1966	
8			.1638	
10		2.5069		.0983
11		2.8346		.0983
12		2.8673		.1147
13		2.982		.1147
14		2.8509		.1311
15		2.4905		.1475
16		2.3922		.1638
17		2.6707		
18		.1311		.1638
19		2.3922		.1966
20		.1311		.1581
21		.1311		.1638
22		2.13		.1311
23		2.2447		.1311
24	.0943		2.1956	
Max	.0943	2.982	2.1956	.1966
Min	.0943	.1311	.1147	.0983
Avg	.0943	2.0540	1.3618	.1395

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / BELAWADE S/STN

Feeder No / Name : 206 / 11 KV LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	03-DEC-17	04-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2587	
2			.2957	
3			.3696	
4			.4066	
5			.4066	
6			.6653	
7			.924	
8			.6283	
10		.6838		.5729
11		.6283		.462
12		.7023		.961
13		.4805		.7023
14		.5544		.4435
15		.7023		.6468
16		.7392		.6283
24	.0038			
Max	.0038	.7392	.924	.961
Min	.0038	.4805	.2587	.4435
Avg	.0038	.6415	.4944	.6310

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 201 / 11 KV WANGI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3927	1.5708	1.587	.0867		.0848	.0905
2	1.3765	1.5384	1.5384	.0857		.0867	.0895
3	1.3765	1.5061	1.5546	.0857		.0867	.1097
4	1.3765	1.5384	1.5223	.0857		.104	.0914
5	1.3765	1.4899	1.4899	.1357		.1227	.1267
6	.1457	.1772	.1663	.2374		.2103	.197
7	.1457	.181	.2402	.2683		.2865	.2507
8	.1619	.2172	.2033	.2012		.2743	.2507
9	.1619	.1629	.1848	.1526		.1646	.1417
10	.1457	.1629	.1848	1.7593		1.9989	2.2028
11	.1612	.181	.1448	1.9444		.2303	2.1051
12	.1791	.181	.1448	2.1142		.2835	2.1548
13	.1433	.1629	.1448			.2507	2.0719
14	.1433	.1448	.1463	2.2455		.1949	1.989
15	.1612	.1448	.1097	2.2885	2.3758	.2303	1.9559
16	.1791	.1629	.1097	2.1538	2.3102	.2481	1.9062
17	.1791	.1629	.1646	2.0809	2.13	.2481	1.9227
18	.1612	.181	.181	.1311	.1357	.362	.1254
19	.1612	.181	.181	.1296	.1865	.1646	.1791
20	.1433	.1448	.1433	.1147	.1907	.1463	.1612
21	.1254	.1267	.124		.1526	.1267	.1254
22	1.6842	1.668	.1052		.1174	.1086	1.3927
23	1.6356	1.6356	.0867		.1174	.128	1.3763
24	1.587	1.6194	1.6194	.0867		.0848	.1254
Max	1.6842	1.668	1.6194	2.2885	2.3758	1.9989	2.2028
Min	.1254	.1267	.0867	.0857	.1174	.0848	.0895
Avg	.5960	.6351	.5032	.8194	.8574	.2594	.8809

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 202 / 11 KV TADSAR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2462	.1882	.1738	1.1797		1.0669	1.3123
2	.2462	.2027	.1593	1.1498		1.0002	1.2803
3	.2317	.1738	.1738	1.0822		.9335	1.2492
4	.2317	.1882	.1882	.9602		.9602	1.3108
5	.2622	.2172	.2172			1.0669	1.3395
6	.2896	.2751	.2606	.3041		.2401	.2606
7	.2896	.2896	.3475	.362		.3111	.3286
8	.3185	.333	.3765	.3814		.2841	.3475
9	.333	.333		.3814		.2976	.3475
10	1.3032	1.701	1.2521	.3374		.2934	.3144
11	1.2656	1.5356	1.8004	.3001		.2934	.3185
12	2.0723	1.7836	2.0538	.2743		.2841	.3475
13	1.9193	1.7364	2.1205	.2606		.2705	.362
14	1.9332	1.6655	2.0696	.2896		.257	.362
15	1.9332	1.8309	1.9885	.3185	.3155	.2976	.333
16	1.9054	1.7718	1.9616	.3475	.3111	.3246	.3185
17	1.9471	1.6655	1.893	.3269	.2841	.3111	.3475
18	.2751	.3041	.2787	.333	.3018	.1067	.3185
19	.2896	.2896	.2934	.3185	.2782	.2667	.3041
20	.2751	.2606	.2751	.3001	.2841	.2801	.2896
21	.2606	.2317	.2751		.257	.23	.2606
22	.2317	.2027	1.2071		1.2039	1.2955	.2172
23	.2172	.1882	1.2071		1.1633	1.3272	.1882
24	1.1022	.2172	.1882	1.1934		1.1633	1.3272
Max	2.0723	1.8309	2.1205	1.1934	1.2039	1.3272	1.3395
Min	.2172	.1738	.1593	.2606	.257	.1067	.1882
Avg	.8075	.7327	.9027	.5200	.4888	.5484	.5577

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 203 / 11 KV YERALA AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.0554	.0739	.4843		.5898	.6722
2	.0732	.0554	.0554	.463		.5182	.664
3	.0732	.0739	.0739	.4475		.5182	.6802
4	.0549	.0554		.4268		.4858	.6562
5	.0549	.0739	.0739	.4572		.6062	.664
6	.0732	.1109	.0924	.1174		.1052	.0886
7	.0732	.1478	.181	.1509		.197	.1791
8	.0914	.1848	.181	.1526		.197	.2149
9	.1097	.1109	.1629	.1029		.1463	.1433
10	1.0425	.8322	.8381	.1029		.1097	.1463
11	.9945	.8802	.8962	.0905		.1097	.0914
12	1.0322	.9442	.8962	.0905		.0905	.0914
13	1.0322	.9231	.8962	.0905		.0914	.0914
14	1.0159	.8642	.9069	.0895		.0905	.0914
15	1.0322	.8642	.8907	.1075	.1463	.0905	.1097
16	.8684	.8322	.8097	.128	.1463		.1097
17	.852	.8002	.7611	.1267	.1646		.1097
18	.1063	.1109	.1029	.128	.1463	.1463	.0914
19	.1086	.1109	.1372	.1254	.128	.1463	.128
20	.0905	.1109	.12	.1254	.1463	.1267	.128
21	.0905	.0924	.1029		.1075	.1086	.0914
22	.0724	.0739	.578		.7537	.7865	.0914
23	.0724	.0739	.5312		.6554	.7773	.0914
24	.0732	.0739	.0739	.4999		.6722	.7449
Max	1.0425	.9442	.9069	.4999	.7537	.7865	.7449
Min	.0549	.0554	.0554	.0895	.1075	.0905	.0886
Avg	.3817	.3523	.4102	.2146	.2660	.3050	.2571

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 204 / 11 KV AMBAK AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4858	.6167	.6167	.0678		.0655	.0328
2	.4858	.6325	.6009	.0678		.0492	.0328
3	.4696	.5535	.5535	.0678		.0492	.0492
4	.4372	.506	.506	.0678		.0486	.0492
5	.3887	.4586	.4744	.0671		.0655	.048
6	.0648	.0503	.0509	.1006		.0819	.0648
7	.081	.0671	.1017	.1341		.1475	.0983
8	.0972	.1006	.1017	.1187		.1147	.081
9	.0972	.0838	.0848	.1357		.1311	.0819
10	.0972	.1006	.1017	.8749		.8002	2.2996
11	.1015	.0838	.1029	.9172		.8259	.6167
12	.1006	.0838	.1029	.9646		.8259	.6642
13	.1174	.1017	.1214			.8192	.6325
14	.1006	.1017	.104	.8482		.7287	.5693
15	.1174	.1017	.1227		.9831	.7449	.5535
16	.1006	.1017	.1227		.9667	.5344	.5218
17	.1174	.1017	.1227	.8322	.7522	.5344	.4902
18		.1187	.1387	.081	.08	.1966	.0509
19	.1006	.1357	.1543	.0972	.112	.081	.0848
20	.1006	.1017	.12	.0983	.1147	.081	.0848
21	.0838	.0848	.1029		.08	.08	.0678
22	.759	.759	.0857		.081	.0486	.4111
23	.7116	.6958	.0857		.081	.0492	.3953
24	.4858	.6642	.6642	.0857		.0655	.0486
Max	.759	.759	.6642	.9646	.9831	.8259	2.2996
Min	.0648	.0503	.0509	.0671	.08	.0486	.0328
Avg	.2479	.2669	.2226	.3126	.3612	.2987	.3345

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 205 / 11 KV HINGANGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1781	.0848	.12	.5468		.7522	.8223
2	.1781	.0678	.1029	.5312		.7164	.7907
3	.1781	.0848	.12	.5247		.6984	.8065
4	.1619	.1017	.1372	.5247		.5761	.8322
5	.1296	.1017	.1372	.5944		.7202	.7907
6	.1802	.1696	.2058	.2012		.1966	.16
7	.1802	.1696	.2401	.2515		.213	.1966
8	.1638	.1696	.2229	.2204		.1966	.1943
9	.1638	.1357	.1886	.1886		.1475	.1619
10	1.1142	.9962	.9878	.1886		.1638	.1475
11	1.3763	1.1069	1.2793	.1715		.1457	.1802
12	1.4403	1.3125	1.3117	.1715		.1475	.1802
13	1.2963	1.2651	1.3603	.1341		.1619	.1802
14	1.3123	1.2334	1.3108	.1475		.1966	.1638
15	1.2803	1.2018	1.2289	.1457	.1966	.1802	.1638
16	1.2003	1.1069	1.1469	.1475	.213	.1966	.1638
17	1.0562	.9804	1.0978	.1296	.1966	.1638	.1966
18	.1187	.1543	.1357	.1475	.213	.1943	.1802
19	.1187	.1543	.1715	.1619	.1943	.213	.1802
20	.1357	.1715	.1715	.1802	.213	.1638	.1638
21	.1357	.1715	.1543		.1802	.1638	.1638
22	.1187	.12	.6405		.9012	1.0322	.1311
23	.1017	.12	.5937		.8848	1.004	.1311
24	.1619	.1017	.1372	.5624		.8192	.9602
Max	1.4403	1.3125	1.3603	.5944	.9012	1.0322	.9602
Min	.1017	.0678	.1029	.1296	.1802	.1457	.1311
Avg	.5200	.4701	.5501	.2796	.3547	.3818	.3351

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 206 / 11 KV WANGI GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2715	.1715	.1734	.1715		.1791	.1949
2	.2534	.1543	.1387	.1715		.1612	.1791
3	.2534	.1372	.1387	.1715		.1612	.1612
4	.2534	.1715	.1734	.2035			.1949
5	.2353	.2229	.2427	.2713		.2149	.2507
6	.3841	.3944	.3772	.4024		.394	.4477
7	.3841	.4801	.4973	.4862		.591	.5194
8	.4024	.4458	.4287	.4024		.5138	.4075
9	.4024	.3601	.3601	.3018		.3403	.394
10	.3475	.2743	.3086	.3222		.3403	.3403
11	.2915	.2254		.2804		.2303	.2865
12	.2915	.2427	.2601	.2507		.2835	.2507
13	.2058	.2254	.2629	.1949		.2507	.2328
14	.2229	.2427	.2103	.1595		.1949	.2865
15	.2401	.2427	.2658	.1791	.3224	.2303	.2507
16	.2572	.2601	.2835	.2507	.2865	.2481	.2328
17	.2915	.3121	.3224	.3366	.3403	.2481	.2865
18	.3944	.3814	.3403	.0394	.4477	.3761	.394
19	.4287	.4115	.4252	.4119	.4477	.3898	.4119
20	.3601	.3772	.3721	.4119	.4656	.3582	
21	.3429	.3429	.333		.3582	.3403	
22	.2572	.2572	.2454		.2686	.2507	.2686
23	.2401	.1907	.208		.2149	.2507	.2507
24	.2715	.2229	.1907	.1907		.2149	.2303
Max	.4287	.4801	.4973	.4862	.4656	.591	.5194
Min	.2058	.1372	.1387	.0394	.2149	.1612	.1612
Avg	.3035	.2811	.2852	.2671	.3502	.2940	.2942

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 201 / 11KV BHIKWADI-KH GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2033	.2195	.2303	.2075	.1867	.1829	.1781
2	.1867	.2195	.2481	.2054	.1829	.1829	.1638
3	.2033	.2195	.2658	.2263		.2012	.1658
4	.2054	.2195	.2658	.2987	.1829	.2195	.1966
5	.2241	.3292	.2658	.3734	.2587	.2195	.2561
6	.3696	.4572	.5544	.5658	.5121	.4024	.6268
7	.5601	.5487	.5914	.6602	.499	.5847	.6584
8	.6468		.6161	.5975	.5304	.5487	.6224
9	.6348	.567	.5228	.547	.4207	.5792	.5788
10	.6535	.4938	.4024	.5601	.3109	.5552	.5093
11	.5175	.4755	.3921	.6224	.3109	.5601	.4805
12	.5359	.5068	.3772	.5788	.2743	.5228	.5041
13	.4435	.4572	.3361	.3547	.2195	.3772	.4435
14	.3326	.3292	.3206	.2772	.2534	.4108	.3174
15	.2957	.3292	.2987	.2402	.3658	.3584	.3696
16	.439	.3658	.3206	.2378	.2896	.4108	.4108
17	.4755	.4805	.3921	.2743	.4755	.5281	.5228
18	.567	.6722	.4527	.4481	.5853	.4854	.6099
19	.8048	.5601	.5788	.4338	.7964	.8676	.5788
20	.4207	.5914	.5658	.462	.4572	.6348	.5359
21	.4938	.4755	.4481	.4525	.4163	.5281	.4854
22	.3658	.3052	.3395	.2241		.3605	.3361
23	.2743	.2374	.2614	.1867	.2195	.2401	.2402
24	.2033	.2195	.2103	.2263	.1848	.1829	.1966
Max	.8048	.6722	.6161	.6602	.7964	.8676	.6584
Min	.1867	.2195	.2103	.1867	.1829	.1829	.1638
Avg	.4190	.4035	.3857	.3859	.3606	.4227	.4162

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 202 / 11 KV NEWARI AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.267	1.3413	1.4918	.0934	.1509	.1086	.132
2	1.2437	1.326	1.326	.0943	.1132	.1086	.112
3	1.1765	1.2431	1.2431	.0934	.0747	.1097	.1132
4	1.134	1.1603	1.1934	.0934	.0754	.1097	.0934
5	1.086	1.1603	1.1797	.0934	.0747	.1097	.0943
6	.1254	.1294	.1478	.1509	.0754	.1097	.1494
7	.1433	.1646	.1463	.1886	.0747	.1448	.168
8	.1646	.1646	.1478	.1494	.1109	.1629	.1886
9	.1646	.128	.1463	.1509	.132		.168
10	.1848	.1646	.128	2.0317	1.9062	1.5729	1.8652
11	.1848	.1646	.1494	2.4006	2.1795	1.6164	2.7469
12	.1663	.1463	.168	2.6216		2.2996	2.7263
13	.1663	.0914	.168	2.4905		2.8182	2.7938
14	.1663	.112	.1509	2.3537		2.6406	2.332
15	.1463	.1109	.1494	2.4034		2.6216	2.3282
16	.1463	.0934	.1509	2.3205		2.3845	2.1033
17	.1463	.1109	.1307	2.13		2.2672	2.0774
18	.1646	.0934	.1886	.1052		.1867	.1612
19	.1646	.1478	.1494	.1132		.1509	.1612
20	.1646	.1307	.1509	.1307	.1463	.1494	.1629
21	.1646	.1478	.1307	.1307	.1646	.1307	.1629
22	1.643	1.9616	.1494	.1698	.128	.1494	1.4327
23	1.5089	1.7238	1.0562	.1698	.1097	.1509	1.2689
24	1.2894	1.4251	1.5746	.0943	.168	.1086	.1494
Max	1.643	1.9616	1.5746	2.6216	2.1795	2.8182	2.7938
Min	.1254	.0914	.128	.0934	.0747	.1086	.0934
Avg	.5380	.5601	.4841	.8656	.3553	.8788	.9871

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 203 / 11 KV DHANEWADI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1433	.1646	.1478	1.9334	1.8067	1.9281	2.0481
2	.1448	.1646	.1478	1.8404	1.7404	1.8861	1.9204
3	.128	.1629	.1478	1.8623	1.7072	1.8004	1.9109
4	.1254	.1629	.1478	1.8351	1.7238	1.8004	1.8023
5	.1267	.1991	.1478	1.8564	1.7072	1.7833	1.7695
6	.1829	.2378	.2195	.2614	.168	.1646	.2829
7	.2172	.2587	.2743	.3018	.1698	.2378	.2614
8	.3109	.2957	.2926	.2614	.1867	.2715	.2641
9	.2801	.2218	.2561	.2263	.2075	.1991	.168
10	2.4209	2.7721	2.5265	.168	.1867	.1629	.1698
11	3.5151	3.1161	3.4008	.168	.1646	.1886	.1663
12	3.3093	3.1623	3.5063	.1886	.1646	.1867	.1867
13	2.1325	3.2322	3.4656	.1867	.1829	.1886	.1663
14	2.3752	3.1824	3.5063	.1698	.1829	.1867	.168
15	2.2291	3.1131	3.4248	.1698	.1646	.1886	.1478
16	3.4122	3.1327	3.0407	.168	.1629	.1867	.168
17	3.2579	2.6686	2.7854	.1698	.1646	.1886	.1478
18	.1848	.1402	.1867	.1612	.181	.1867	.1829
19	.1848	.1478	.2263	.1509	.181	.2263	.2033
20	.1848	.168	.2054	.168	.1848	.2241	.2033
21	.1646	.168	.1509	.1698	.1829	.1886	.2054
22	.1646	.1494	1.9498	1.9281	2.3891	2.0165	.1629
23	.1646	.1494	1.9524	1.9989	2.0858	2.1628	.1448
24	.1433	.1646	.1494	1.9433	1.9559	1.9806	2.0805
Max	3.5151	3.2322	3.5063	1.9989	2.3891	2.1628	2.0805
Min	.1254	.1402	.1478	.1509	.1629	.1629	.1448
Avg	1.0626	1.1390	1.3441	.7620	.7480	.7723	.6221

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 204 / 11 KV YETGAON AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.081	.0934	1.1469	1.1401	1.286	1.1797
2	.0914	.081	.112	1.1271	1.065	1.2003	1.1336
3	.0895	.081	.0934	1.065	1.1437	1.2003	1.1142
4	.0905	.0829	.112	.9762	1.1469	1.2003	1.065
5	.0905	.0995	.112	1.1317	1.1469	1.166	.9922
6	.128	.1492	.1663	.1867	.2075	.1372	.2241
7	.1448	.1658	.1848	.2241	.2241	.1715	.2075
8	.197	.1658	.2218	.1867	.2263	.1715	.168
9	.1448	.1326	.1294	.132	.1494	.1029	.132
10	1.749	1.6409	1.7772	.0934	.112	.0663	.112
11	2.7435	2.6852	2.4577	.1132	.0732	.096	.1109
12	2.915	2.7854	2.6566	.112	.0914	.1147	.112
13	2.8807	2.8346	2.5888	.112	.0905	.112	.1109
14	3.0521	2.8675	2.5286	.132	.1086	.1132	.0934
15	2.9321	2.7183	2.1136	.1307	.0905	.0934	.0924
16	2.8121	2.7035	2.0645		.1086	.0943	.112
17	2.692	2.2211	1.8515	.1478	.1086	.0934	.128
18	.1214	.1326	.1307	.1886	.1629	.168	.1433
19	.1619	.1494	.1886	.1867	.1612	.2263	.1991
20	.1658	.1663	.168	.1698	.1619	.2054	.1829
21	.1492	.1663	.1509	.1867	.1457	.1698	.1629
22	.116	.1307	1.1248	1.326	1.4232	.168	.1075
23	.0972	.1307	1.2125	1.3108	1.3717	1.2483	.0905
24	.0895	.081	.0934	1.1498	1.291	1.3375	1.2289
Max	3.0521	2.8675	2.6566	1.326	1.4232	1.3375	1.2289
Min	.0895	.081	.0934	.0934	.0732	.0663	.0905
Avg	.9894	.9355	.9305	.5016	.4980	.4559	.3835

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 205 / 11 KV TUPEWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366	.0514	.037	.2984	.3605	.3239	.3768
2	.0362	.0514	.037	.3018	.3315	.2915	.3201
3	.0366	.0514	.037	.2622	.3185	.2429	.3239
4	.0362	.0514	.037	.2591	.285	.2429	.3113
5	.0358	.0514	.0554	.2622	.285	.2429	.2915
6	.0358	.0857	.0566	.0934	.132	.0486	.0934
7	.0543	.0857	.0829	.0943	.112	.0648	.112
8	.0895	.0857	.1132	.0747	.112	.0972	.0943
9	.0724	.0686	.112	.0566	.1132	.081	.112
10	.5792	.5487	.6274	.0934	.112	.0648	.0934
11	.9412	.7888	.7202	.0934	.0724	.0943	.0924
12	.9955	.7373	.8029	.0747		.1307	.1097
13	.6154	.7459	.6241	.0934	.0857	.132	.1086
14	.7545	.7701	.7125	.0934	.0848	.132	.1075
15	.8573	.7293	.7045	.1132	.0838	.112	.0905
16	.4458	.5571	.583	.0934	.0838	.1132	.0732
17	.5658	.5138	.5571	.112	.0671	.0934	.0724
18	.0686	.0663	.0377	.0934	.0648	.0934	.0724
19	.0905	.0754	.056	.056	.0829	.0943	.0537
20	.0724	.0732	.0566	.0566	.0648	.0747	.0543
21	.0686	.0747	.0747	.056	.0648	.0754	.0543
22	.0686	.0554	.3768	.4144	.4534	.4588	.0358
23	.0686	.056	.3681	.4424	.3887	.4481	.0362
24	.0362	.0514	.0373	.3277	.3932	.3401	.426
Max	.9955	.7888	.8029	.4424	.4534	.4588	.426
Min	.0358	.0514	.037	.056	.0648	.0486	.0358
Avg	.2776	.2678	.2878	.1632	.1805	.1705	.1465

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 206 / 11 KV YERALA AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.326	1.5432	1.4746	.0377	.0373	.0324	.0373
2	1.3435	1.5432	1.3763	.0377		.0324	.0373
3	1.3413	1.5261	1.3927	.0377	.0377	.0324	.0377
4	1.3226	1.4918	1.3927	.0377	.0377	.0324	.0377
5	1.3077	1.4746	1.4089	.0566	.0377	.0324	.0377
6	.0509	.0514	.0829	.056	.0747	.0324	
7	.0543	.0514	.0829	.056	.0754	.0324	.056
8	.0678	.0514	.0829	.0943	.0747	.0486	.1132
9	.0747	.0686	.1294	.0934	.0934	.0648	.0934
10	.0554	.0848	.1086	1.6385	1.6221	1.4746	1.9163
11	.0739	.0829	.0934	1.9364	1.757	1.9204	1.9757
12	.0914	.1526	.0943	1.9006	2.0119	2.13	1.9826
13	.0724	.1075	.112	1.4575	2.1262	2.13	2.1704
14	1.1584	.0716	.1132	2.13	1.9547	2.1464	1.7833
15	.0905	.0747	.0747	2.1628	1.9719	2.0325	1.95
16	.0686	.0739	.0943	2.0972	1.8176	2.0405	1.8778
17	.0686	.0924	.112	2.0056	1.8861	1.9989	1.8821
18	.0678	.0747	.112	.0747	.0514	.0373	.0543
19	.0686	.0747	.0566	.0747	.0343	.0566	.0732
20	.0686	.0924	.056	.0754	.0492	.056	.0549
21	.0686	.0924	.056	.0747	.0324	.0566	.0537
22	1.6289	1.5249	.0566	.056	.0324	1.8298	1.4232
23	1.6289	1.6221	.0373	.0566	.0324	.0373	1.4403
24	1.4255	1.5432	1.5729	.0373	.0377	.0324	.0377
Max	1.6289	1.6221	1.5729	2.1628	2.1262	2.1464	2.1704
Min	.0509	.0514	.0373	.0373	.0324	.0324	.0373
Avg	.5635	.5653	.4239	.6785	.6907	.7633	.8316

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244128 / 33/11 KV Shivani Substation

Feeder No / Name : 201 / 11 KV SHIVANI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0457	.0926	.0533	1.4403	1.5586	1.6164	1.5684
2	.0472	.0846	.0427	1.4403	1.5089	1.5813	1.4998
3	.0488	.0629	.0524	1.3125	1.4632	1.5623	1.4043
4	.0629	.0777	.0514	1.2346	1.448	1.5432	1.448
5	.0754	.0657	.0619	1.2651	1.4327	1.4969	1.4937
6	.0987	.1107	.0987	.0995	.108	.092	.104
7	.1311	.1326	.1204	.1326	.1423	.1067	.1147
8	.0937	.1235	.1067	.1326	.0947	.1082	.1158
9	.0705	.0892	.0777	.0667	.0854	.096	.0572
10	2.1445	2.4615	2.1285	.0619	.0591	.0697	.0674
11	2.6379	2.9635	.5053	.0594	.0907		.0674
12	2.672		2.5263	.0617	.0747	.0754	.0674
13	2.753	3.0769	2.5911	.093	.096	.076	.0469
14	2.8673	2.915	2.5911	.1006	.1257	.072	.0493
15		2.8178	2.6871	.0734	.0492	.0572	.0747
16		2.5749	2.4806	.0747	.0434	.1094	.064
17		2.3562	2.1715	.0141	.048	.0777	.0257
18	.1235	.1082	.08	.0137	.0747	.0732	.0166
19	.0907	.0945	.08	.0686	.08	.0686	.0754
20	.0934	.1029	.0987	.0674	.0707	.072	.056
21	.088	.0914	.0987	.0663	.0693	.064	.056
22	.061	.0697	1.5181	1.713	1.7869	1.7654	.056
23	.0581	.0709	1.5181	1.6975	1.8027	1.7341	.0572
24	.0553	.0591		1.5203	1.6512	1.7711	1.7394
Max	2.8673	3.0769	2.6871	1.713	1.8027	1.7711	1.7394
Min	.0457	.0591	.0427	.0137	.0434	.0572	.0166
Avg	.6818	.8957	.9452	.5337	.5818	.6213	.4302

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244128 / 33/11 KV Shivani Substation

Feeder No / Name : 202 / 11 KV HANMANTWADIYE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0467	1.4217	1.2955	.0655	.0497	.0503	.0693
2	1.0155	1.4754		.0492	.0678	.0497	.0876
3	.9998	1.3927	1.1873	.0509	.0686	.0497	.0867
4	.9998	1.4251	1.1574	.0716	.0686	.0503	.0686
5	1.0467	1.2651	1.2186	.064	.0686	.0514	.0686
6	.1052	.1029	.0857	.0876	.0895	.0905	.0709
7	.124	.1267	.1052	.0895	.1086	.0876	.1267
8	.1063	.1063	.1052	.1267	.1052	.0876	.0867
9	.1075	.0886	.0867	.0914	.0848	.0867	.0452
10	.1075	.0701	.0857	1.4403	1.6518	1.3283	1.5364
11	.1052	.0463	.0995	1.9044	1.8564	1.6129	1.7976
12	.0671	.0857	.0867		1.8084	1.6446	1.7924
13	.0867	.0867	.044		1.7654	1.5813	1.7711
14	.0876	.104	.064	2.0729	1.5895	1.5813	1.7078
15	.0819	.1052	.064	1.9685	1.6129	1.4217	1.6129
16	.1006	.1052	.064	1.8027	1.2809	1.4373	1.5154
17	.1174	.1017	.1029	1.7604	1.1589	1.3426	1.4232
18	.1017	.1017	.0914	.0743	.0781	.0678	.0829
19	.1357	.0995	.1063	.0876	.1006	.0876	.0857
20	.1214	.0995	.1006	.0857	.0972	.0857	.0857
21	.0995	.0995	.0838	.0678	.0781	.0655	.08
22	1.5043	1.4723	.064	.048	.0655	.08	.9686
23	1.4403	1.4737	.064	.0486	.0492	.0867	.9602
24	1.0753	1.4737		.064	.0492	.0497	.0686
Max	1.5043	1.4754	1.2955	2.0729	1.8564	1.6446	1.7976
Min	.0671	.0463	.044	.048	.0492	.0497	.0452
Avg	.4493	.5387	.2892	.5510	.5814	.5449	.6750

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244128 / 33/11 KV Shivani Substation

Feeder No / Name : 203 / 11 KV SHIVANI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3547	.4572	.3734	.3696	.3584	.3121	.462
2	.3547	.4477	.3547	.3696	.3395	.3292	.439
3	.3547	.4252	.3361	.3511	.3395	.2957	.4344
4	.3881	.4207	.3361	.3506	.3395	.2987	.4481
5	.4066	.3921	.4251	.3982	.3921	.4481	.4294
6	.6283	.6348	.6348	.5068	.6722	.6838	.6722
7	.7947	.7468	.7167	.5544	.7842	.6767	.7655
8	.7577	.6838	.7207	.663	.6468	.6878	.7392
9	.788	.7164	.6401	.5973	.543	.6335	.567
10	.6089	.6415	.543	.4656	.4784	.5552	.4835
11	.6485	.6001	.543	.5028	.4287	.5611	.4908
12	.4031	.5256	.5959	.4854	.4908	.567	.5258
13	.4239	.4784	.6584	.4733	.4458	.5014	.5784
14	.5434	.5258	.5731	.3506	.4163	.4252	.5138
15	.6602	.583	.5316	.443	.443	.4801	.4784
16	.5144	.5144	.567	.4298	.4508	.4973	.4578
17	.5434	.4908	.4607	.4557	.4239	.5533	.6283
18	.6201	.6661	.5375	.6089	.5731	.5784	.6344
19	.7343	.6733	.7087	.7682	.6697	.7421	.7602
20	.6838	.7059	.7164	.7316	.6401	.695	.6653
21	.5914	.6767	.6838	.695	.5792	.6283	.6468
22	.5228	.462	.5853	.4294	.499	.5175	.5359
23	.5041	.4435	.5853	.3734	.3658	.4938	.5175
24	.3921	.4755	.4435	.5487	.3921	.3439	.4755
Max	.7947	.7468	.7207	.7682	.7842	.7421	.7655
Min	.3547	.3921	.3361	.3506	.3395	.2957	.4294
Avg	.5509	.5578	.5530	.4968	.4880	.5211	.5562

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 248018 / 132/33 KV WANGI SUBSTATION

Feeder No / Name : 601 / SONHIRA S.S.K.LTD

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

Feeder KV- 132 / OUTGOING

(NON CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-DEC-17
HR	Load (MW)
24	.1052
Max	.1052
Min	.1052
Avg	.1052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA

Feeder No / Name : 201 / 11 KV VITA(U)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2449	1.2071	1.2826	1.2574	1.1431	.7545	1.094
2	1.2449	1.2449	1.2449	1.2193	1.1431	.7167	1.0562
3	1.2449	1.2071	1.1694	1.1431	1.105	.7167	1.0185
4	1.2071	1.1694	1.1317	1.105	1.0288	.7167	1.1317
5	1.3957	1.3203	1.2826	1.2197	1.105	.7922	1.2449
6	1.5089	1.5466	1.5089	1.5242	1.2574	1.1431	1.4335
7	1.7924		1.7924	1.7909	1.448	1.448	1.6598
8	1.9418	1.8671	1.8671	1.8671	1.6385	1.6975	1.8671
9	1.9959	1.8111	1.8656	1.7737	1.4098	1.6263	1.8111
10	1.9387	1.922	1.829	1.829	1.3203	1.6263	1.829
11	1.8461	1.8099	1.9022	1.829	1.3306	1.6289	1.8267
12	1.829	1.7558	1.7177	1.6632	.9979	1.4632	1.6461
13	1.6804	1.6057	1.3443	1.5893	.961	1.4415	1.4784
14	1.8656	1.7741	1.7002	1.7372	.9877	1.6095	1.6461
15	1.9022	1.9022	1.6827	1.7193		1.6651	1.7558
16	1.7924	1.8267	1.6461	1.7558	1.2193	1.6461	1.7193
17	1.8099	1.8461	1.829	1.4327	1.1431	1.6651	1.8099
18	2.0698	1.8099	1.829	2.0328	1.6221	2.0165	1.7558
19	2.3285	2.2177	2.037	2.2779	1.773	2.2032	2.1285
20	2.1437	2.0538	1.9791	2.1658	1.6598	2.0165	1.9993
21	1.8107	1.7353	1.7147	1.5242	1.4098	1.5844	1.6598
22	1.6221	1.6221	1.6004	1.3717	1.1694	1.3957	1.3717
23	1.4712	1.4712	1.4098	1.2574	1.0562	1.3203	1.1694
24	1.307	1.3203	1.358	1.2955	1.1812	.7922	1.1694
Max	2.3285	2.2177	2.037	2.2779	1.773	2.2032	2.1285
Min	1.2071	1.1694	1.1317	1.105	.961	.7167	1.0185
Avg	1.7081	1.6542	1.6135	1.5992	1.2657	1.4036	1.5534

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA

Feeder No / Name : 202 / 11 KV LENGARE (U)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0719	1.1203	1.134	1.2955	1.2955	.8002	1.094
2	1.1458	1.2071	1.2894	1.2193	1.2193	.8002	1.0185
3	1.2071	1.134	1.2803	1.1431	1.1431	.8002	.9526
4	1.0082	1.1203	1.2567	1.105	1.0288	.8002	1.0669
5	1.1088	1.2071	1.1949	1.2574	.9526	.8383	1.1317
6	1.2323	1.2323	1.1576	1.2936	1.0288	.9145	1.2323
7	1.307	1.3443	1.307	1.3676	1.0288	.9526	1.3817
8	1.4266	1.4998	1.4632	1.5524	.9526	1.2826	1.5927
9	1.6118	1.6301	1.5043	1.4255	.9145	1.448	1.6126
10	1.8378	1.7684	1.7337	1.7147	.8383	1.5604	1.749
11	1.7833	1.7101	1.749	1.6991	.8764	1.6461	.8505
12	1.2437	1.2936	1.1576	1.1827	.9145	1.1827	1.4266
13	1.1576	1.2936	1.3169	1.3169	.9145	1.2536	1.3394
14	1.595	1.7177	1.6297	1.6297	.3018	1.6278	1.7101
15	1.6118	1.829	1.6126	1.6297	.2683	1.6278	1.7635
16	1.491	1.5257	1.5402	1.4883	.8764	1.3466	1.4217
17	1.5775	1.5775	1.5074	1.4415	.9145	1.5775	1.6278
18	1.5592	1.576	1.4327	1.5402	.9145	1.5565	1.5074
19	1.7718	1.6476	1.5565	1.7193	.9526	1.576	1.7528
20	1.39	1.5043	1.4415	1.4998	.9145	1.4266	1.7193
21	1.105	1.0288	1.1431	1.0669	.9145	.9907	1.105
22	1.4266	1.3756	1.448	1.4842	.9145	1.2696	1.4118
23	1.4118	1.4327	1.4685	1.3969	.8764	1.3169	1.4529
24	1.105	1.1088	1.0829	1.2437	1.3676	.8002	1.0456
Max	1.8378	1.829	1.749	1.7193	1.3676	1.6461	1.7635
Min	1.0082	1.0288	1.0829	1.0669	.2683	.8002	.8505
Avg	1.3828	1.4119	1.3920	1.4047	.9301	1.2248	1.3736

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA

Feeder No / Name : 203 / 11 KV BHALWANI(U)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5967	.6706	.7042	.7164	.6935	.4481	.583
2	.6036	.6443	.6802	.6805	.7164	.4108	.5487
3	.6036	.6173	.6554	.6447	.7164	.4108	.5258
4	.583	.5959	.6299	.6089	.6805	.4066	.6089
5	.6173	.6661	.7042	.6653	.6588	.5175	.6219
6	.6935	.7712	.7377	.7522	.7282	.6722	.7167
7	.8505	.9568	.8322	.9313	.8326	.7468	.9054
8	1.0056	1.0852	1.0631	.9945	.7522	.8764	1.094
9	1.1827	1.1469	1.0688	.9686	.7628	.8745	1.0608
10	1.166	1.2929	1.0814	1.0242	.57	.8223	.9488
11	1.2163	1.1702	1.1797	1.0311	.6443	.9374	1.0185
12	1.0883	1.1069	1.0883	.8962	.6443	.9061	.9374
13	.9717	1.0688	1.0486	.8192	.5765	.8002	.8223
14	1.0688	1.1142	1.1469	.852	.583	.6958	.9282
15	1.0364	1.2346	1.1469	.9374	.6371	.9259	1.1069
16	1.1203	.7293	1.0883	.8749	.5765	.9374	1.1069
17	1.2018	1.0802	1.1203	.7537	.5765	1.1065	1.0936
18	1.0277	1.0277	.9831	.852	.5959	1.0395	.9804
19	1.073	1.1603	.9389	1.0288	.6878	1.0974	1.0059
20	.9614	1.0277	.9054	1.0056	.6878	1.0059	.9945
21	.8413	.8619	.8139	.9015	.6653	.7888	.8764
22	.8238	.823	.788	.7796	.6036	.6661	.8764
23	.7545	.7865	.7377	.7377	.5175	.6935	.78
24	.6802	.7377	.7449	.7282	.7282	.4805	.6104
Max	1.2163	1.2929	1.1797	1.0311	.8326	1.1065	1.1069
Min	.583	.5959	.6299	.6089	.5175	.4066	.5258
Avg	.907	.9323	.912	.8410	.6598	.7611	.8647

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA

Feeder No / Name : 204 / 11 KV PARE (U)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9774	1.0387	1.0056	1.1462	1.1096	.439	.9671
2	.9412	1.0631	1.0517	1.1462	1.0517	.4024	.9511
3	.9511	1.0387	1.0166	1.0745	.9114	.4066	.924
4	.8871	.9774	.9671	.9671	.8063	.4108	.8139
5	.9877	1.0974	1.0719	1.0056	.7975	.4805	.9114
6	1.134	1.1584	1.0974		.8322	.6805	.9389
7	1.3611	1.39	1.3394	1.4266	1.0136	1.0029	1.3394
8	1.4723	1.491	1.6126	1.5592	.9465	1.3394	1.4883
9	1.4746	1.4746	1.5424	1.4586	.8669	1.3032	1.4083
10	1.5089	1.5089	1.5912	1.4723	.6859	1.3748	1.5074
11	1.5729	1.5043	1.5581	1.4091	.4115	1.2643	.6401
12	1.2407	1.1469	1.1789	1.1191	.4108	1.2125	1.3077
13	1.1443	1.2003	1.1443	.6706	.4435	1.1191	1.1096
14	1.7002	1.4746	1.4586	1.3923	.5014	1.278	1.3279
15	1.5912	1.5364	1.5249	1.4419	.5373	1.4251	1.4255
16	1.4083	1.4899	1.406	1.278	.5373	1.3279	1.4091
17	1.4899	1.5546	1.5074	.9568	.5895	1.3603	1.5074
18	1.4582	1.6118	1.4586	1.3226	.7888	1.4217	1.3923
19	1.4563	1.5432	1.5257	1.6297	.788	1.4373	1.5089
20	1.3466	1.4217	1.3253	1.4883	.7522	1.3394	1.3321
21	1.1203	1.134	1.1706	1.2197	.6348	1.1088	1.1706
22	1.2178	1.2048	1.2178	1.3253	.6348	1.182	1.3321
23	1.2136	1.2003		1.1789	.5544	1.134	1.1789
24	1.0029	1.0867	1.0402	1.182	1.1789	.439	.9922
Max	1.7002	1.6118	1.6126	1.6297	1.1789	1.4373	1.5089
Min	.8871	.9774	.9671	.6706	.4108	.4024	.6401
Avg	1.2774	1.3062	1.2962	1.2552	.7410	1.0371	1.2035

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA

Feeder No / Name : 403 / 33KV NAGEVADI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5766	2.6292	2.9447	3.1207	3.5368	3.0521	4.1015
2	2.4451	2.6292	2.9447	3.1207	3.4328	2.3908	3.9963
3	2.392	2.524	2.8395	3.0167	3.4328	2.4417	3.8912
4	2.5789	2.8395	2.7343	3.0167	3.3288	2.8995	4.2067
5	2.9687	3.155	3.155	3.1207	3.1207	2.8487	4.417
6	1.1883	1.0517	1.1568	1.2894	1.0402	1.6461	1.262
7	1.6244	1.6827	1.5775	1.3969	1.2894	1.9044	1.6827
8	1.6632	1.6827	1.5775	1.9342	1.2894	1.6804	1.6827
9	1.5912	1.4723	1.7878	1.6118	1.2071	1.8804	1.6827
10	5.2675	6.7307	6.7616	3.6408	2.9127	3.546	3.3065
11	7.572	7.3617	7.3617	4.0124	3.035	4.1907	4.7188
12	8.8889	8.834	7.2817	4.369	2.9835	4.6205	4.768
13	9.425	7.8875	7.2817	4.161	2.9504	4.7279	4.8834
14	8.7597	8.6237	8.3219	5.2584	2.8995	4.417	4.4445
15	8.5597	9.465	8.2305	4.161	3.3385	4.6273	4.4353
16	8.1207	7.3617	7.2817	5.2012	2.7161	5.2584	4.4993
17	7.1331	7.572	5.2012	3.3653	3.0178	5.036	4.3347
18	1.7558	1.9982	3.1207	4.161	1.0317	1.893	2.3137
19	2.1948	1.9982	2.364	2.2885	1.5123	2.4188	2.0851
20	2.1948	2.3137	2.1491	1.4563	1.5364	2.3137	1.8656
21	1.4266	1.3672	1.5043	1.3672	1.4969	1.4723	1.5123
22	3.4019	3.155	3.8489	3.9758	4.1152	4.8377	2.5766
23	3.0087	3.2602	3.4979	3.6145	3.8152	4.7325	2.4446
24	2.6526	2.9447	3.2602	3.3288	3.6408	3.1184	4.417
Max	9.425	9.465	8.3219	5.2584	4.1152	5.2584	4.8834
Min	1.1883	1.0517	1.1568	1.2894	1.0317	1.4723	1.262
Avg	4.1413	4.1892	4.0910	3.1662	2.6117	3.2481	3.3137

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/S

Feeder No / Name : 201 / 11 KV ALSAND AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1147	1.8842	1.7814	1.406	.1357	.0812	.1187
2	.1147	1.7814	1.749	1.3279	.1357	.0812	.12
3	.1147	1.7814	1.6004	1.3123	.1326	.096	.12
4	.1147	1.6804	1.5684	1.2967	.1326	.0983	.12
5	.1174	1.6324	1.4563	1.3125	.1326	.096	.1214
6	.1753	.1505	.2172	.1928	.1753	.1772	.1543
7	.1753	.1772	.2172	.1907	.208	.181	.1791
8	.208	.2347	.2172	.1886	.1928	.1696	.181
9	.2303	.1949	.2454	.2126	.1696	.1696	.1543
10	.208	.2454	.2328	1.7924	2.0325	1.9271	1.7764
11	.1886	.2035	.2328	2.2447	2.2283	2.1862	1.9757
12	.1865	.1574	.1949	2.4577	2.2775	2.2611	2.0481
13	.2229	.0358	.1907	2.4577	2.0729	2.251	2.2939
14	.2254	.0358	.1526	2.4249		2.2348	2.3758
15	.2126	.0358	.1886	2.343	1.9524	2.17	2.4413
16	.0354	.0358	.2126	2.3594	1.7924	2.0165	2.4577
17	.2035	.0497	.1235	2.2024		1.8818	2.2024
18	.1734	.2058	.1753	.1692	.1235	.1189	.1276
19	.2058	.208	.1772	.2058	.1355	.1734	.1509
20	.1886	.208	.1928	.1886	.132	.1715	.1509
21	.1823	.1696	.1326	.1715	.1143	.156	.1341
22	2.0481	1.9433	1.6484	.1578	.108	.1417	.1357
23	2.0481	1.8785	1.5655	.1526	.0846	.12	.112
24	.144	1.9662	1.8623	1.4842	.1357	.0947	.1147
Max	2.0481	1.9662	1.8623	2.4577	2.2775	2.2611	2.4577
Min	.0354	.0358	.1235	.1526	.0846	.0812	.112
Avg	.3266	.7040	.6806	1.1772	.6638	.7940	.8236

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/S

Feeder No / Name : 202 / 11 KV BHALWANI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3279		.0693	.0343	1.6004	1.2498	1.3748
2	1.2498		.0693	.0351	1.4403	1.2029	1.2498
3	1.2029		.0693	.0351	1.2811	1.0802	1.1873
4	1.1873		.0716	.0351	1.1717	1.0494	1.1717
5	1.2018		.0716	.0354	1.0623	1.0494	1.1717
6	.0848	.0886	.1109	.0876	.0716	.112	.1063
7	.0914	.0934	.1109	.1063	.1267	.112	.1109
8	.1086	.1402	.1097	.112	.1086	.0739	.1086
9	.0914	.0905	.1029	.1052	.1086	.1075	.0886
10	1.6804	2.0805	2.0729	.104	.1029	.0838	.0926
11	2.3594	2.4006	2.4905	.0724	.0701	.0819	.064
12	2.3967	2.6235	2.6216	.1086	.0732	.08	.08
13	2.3644	2.6558	2.4615	.0914	.0895	.0695	.0857
14	2.3922	2.6882	2.3967		.088	.125	.064
15	2.5888	2.5301	2.2996	.0876	.0693	.0714	.064
16	2.4905	2.2455	2.2996	.0867	.0678	.0846	.064
17	2.2405	2.1822	2.1445	.104	.0556	.104	.0903
18	.0867	.0701	.1017	.104	.0693	.1063	.112
19	.1086	.1063	.1086	.0867	.0709	.0895	.12
20	.0905	.1063	.1254	.0895	.1063	.1075	.1029
21	.0886	.1075	.1075	.0709	.0716	.1075	.104
22	.0905	.0724	.0886	1.7814	.7682	1.6964	1.5497
23		.0693	.0335	1.6964	1.4232	1.6964	1.4864
24	1.4373		.0693	.0648	1.6804	1.2811	1.4685
Max	2.5888	2.6882	2.6216	1.7814	1.6804	1.6964	1.5497
Min	.0848	.0693	.0335	.0343	.0556	.0695	.064
Avg	1.1722	1.1306	.8420	.2232	.4907	.4926	.5049

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/S

Feeder No / Name : 203 / 11 KV KAMLAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5043	.1448	.1658	.1448	1.6804	1.7444	1.7652
2	1.4723	.1463	.1658	.1448	1.6004	1.6964	1.6518
3	1.4723	.1478	.1867	.1448	1.5364	1.6964	1.6518
4	1.4723	.1478	.1867	.1448	1.4403	1.6964	1.587
5	1.5061	.1478	.1867	.1772	1.3443	1.6964	1.587
6	.2353	.1829	.2957	.2328	.2172	.2957	.2561
7	.2987	.2801	.3326	.3142	.2957	.2987	.2772
8	.2957	.2865	.2987	.2772	.2865	.2218	.2241
9	.2402	.181	.2561	.2587	.2172	.1448	.2614
10	2.0317	2.13	2.4366	.2149	.2149	.2033	.1433
11	2.5194	2.7681	2.9172	.2772	.1658	.2058	.2218
12	2.5857	2.8673	2.652	.3326		.2149	.2587
13	2.7846	2.7854	2.7183	.3326	.1509	.218	.2218
14	2.7183	2.6355	2.652	.3326	.156	.1791	.2218
15	2.9172	2.5819	2.5194	.3696	.2149	.2218	.2957
16	3.0167	3.219	2.4249	.3326	.2012	.2374	.2987
17	2.4905	2.4577	2.2939	.3982	.1943	.2353	.3658
18	.1715	.2572	.2035	.3258	.2926	.2743	.2926
19	.2103	.2218	.2772	.2743	.1772	.2353	.2987
20	.1791	.2218	.2587	.2772	.1595	.2012	.2614
21	.1772	.2402	.2378	.2561	.1612	.2195	.2614
22	.1829	.1867	.2033	1.8138	.1966	2.2045	1.6842
23	.1448	.1658	.1646	1.7924	.1457	2.0317	1.6644
24	1.5364	.1448	.1658	.1629	1.7604	.144	1.8299
Max	3.0167	3.219	2.9172	1.8138	1.7604	2.2045	1.8299
Min	.1448	.1448	.1646	.1448	.1457	.144	.1433
Avg	1.3401	1.0228	1.0083	.3888	.5569	.6882	.7326

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/S

Feeder No / Name : 204 / BHALWANI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0633	.0943	.1132	.0914	.1029	.0655	.0943
2	.0633	.0934	.0754	.0914	.1029	.0655	.0943
3	.0633	.0934	.0747	.0914	.0886	.0686	.0857
4	.0655	.0934	.0747	.1097	.0886	.0701	.0934
5	.0655	.0934	.0747	.112	.0886	.0701	.112
6	.156	.1509	.1886	.1698	.1387	.1829	.1509
7	.1646	.1509	.2263	.2054	.3018	.1829	.1829
8	.1698	.181	.1886	.2075	.1734	.1448	.2033
9	.1663	.1646	.0716	.1595	.1543	.1235	.1463
10	.0983	.1029	.1492	.1311	.1353	.1429	.1406
11	.104	.1296	.1326	.1063	.0857	.1334	.1227
12		.1006	.1075	.1267	.0857	.1734	.1326
13	.0953	.0747		.1075	.0766	.0991	.1341
14		.0747	.0754	.0943	.088	.1097	.1341
15	.0819	.0602	.0895	.0943	.0777	.1334	.1029
16		.0903	.1265	.0953	.1257	.1067	.1265
17	.1326	.0903	.1187	.1214	.1067	.12	.1389
18	.1646	.1097	.1478	.1467	.1524	.0907	.1543
19	.2328	.2172	.1075	.2058	.1943	.1848	.1829
20	.1991	.2172	.2378	.208	.1943	.2218	.2054
21	.181	.181	.1848	.1907	.1943	.2218	.1848
22	.1524	.1132	.1509	.1433	.1357	.1509	.1509
23	.1132	.1132	.1294	.1029	.0995	.132	.1132
24	.0781	.1132	.1132	.1132	.1029	.0655	.0943
Max	.2328	.2172	.2378	.208	.3018	.2218	.2054
Min	.0633	.0602	.0716	.0914	.0766	.0655	.0857
Avg	.1243	.1210	.1286	.1344	.1289	.1275	.1367

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/S

Feeder No / Name : 205 / ALSAND / KAMALAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1981		.2804	.2328	.2715	.2149	.2353
2	.1981	.2683	.2454	.2353	.2715	.2195	.2353
3	.1981	.2683	.2454	.2353	.2801	.2195	.2353
4	.2515	.2713	.2263	.2561	.2801	.2587	.2743
5	.3086	.2713	.2263	.3547	.2987	.2987	.3734
6	.5014	.5014	.5228	.5601	.5601	.6908	.5658
7	.695	.695	.6908	.7095	.7282	.6908	.7282
8	.6089	.5609	.6348	.6283	.6584	.6653	.6838
9	.4334	.407	.4706	.4477	.4252	.5014	.5014
10	.3479	.3647	.3521	.3353	.3429	.3814	.3944
11	.3395	.3227	.2932	.3018	.2713	.3315	.3391
12	.301	.2934	.2984	.3315	.2883	.2753	.2743
13	.2143	.2934	.2429	.2515	.2012	.2984	.2515
14	.1894	.2641	.2622	.2321	.2012	.2785	.2683
15	.2439	.2641	.2622	.2294	.1989	.2785	.2683
16	.2641	.2503	.3041	.2458	.1989	.2785	.2652
17	.1707	.2782	.3113	.2591	.2622	.2949	.3149
18	.4359	.4458	.4382	.4161	.4252	.4557	.3506
19	.5144	.4801	.5304	.4508	.4344	.5853	.4557
20	.4854	.4805	.5175	.4755	.439	.5304	.4755
21	.4115	.4435	.4435	.439	.439	.439	.4066
22	.3391	.362	.4066	.3326	.2926	.3881	.3326
23	.2622	.3506	.2743	.2715	.2172	.2561	.2534
24	.2134	.2622	.2804	.2328	.2715	.2149	.2353
Max	.695	.695	.6908	.7095	.7282	.6908	.7282
Min	.1707	.2503	.2263	.2294	.1989	.2149	.2353
Avg	.3386	.3652	.3650	.3527	.3441	.3769	.3633

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/S

Feeder No / Name : 206 / 11 KV Umar Kanchan AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.104	2.1052	2.1538	1.5971	.0983	.1187	.12
2	.104	2.0243	2.0405	1.5181	.0983	.1187	.12
3	.104	1.9204	1.9757	1.4864	.1029	.12	.1214
4	.1067	1.9204	1.9109	1.4706	.1029	.128	.1227
5	.1227	1.8404	1.7604	1.4883		.128	.1267
6	.156	.128	.181	.1578	.1433	.2054	.1646
7	.1791	.1629	.181	.1646	.2126	.2054	.181
8	.156	.1286	.1646	.1448	.181	.2218	.1848
9	.1753	.124	.1844	.1311	.1543	.1595	.1417
10	.1372	.1357	.116	1.7869	2.0805	1.8299	2.0485
11	.1402	.1581	.1389	2.2672	2.1862	2.2447	2.4129
12	.1372		.1406	2.3805	2.3967	2.3365	2.6379
13	.1753		.0168	2.4615	2.3482	2.332	2.6235
14	.1595		.0259	2.4939		2.343	2.5587
15	.1578		.1715	2.3482	2.1052	2.3102	2.332
16	.1696	.2454	.1658	2.4741	1.9364	2.1052	2.2565
17	.1492	.2454	.1147	2.2085	1.8027	.8697	2.1925
18	.1696	.1214	.1463	.1174	.1457	.0137	.1189
19	.1907	.1715	.1753	.1387	.1509	.1526	.1619
20	.1715	.1715	.1677	.156	.144	.1658	.1638
21	.1509	.1658	.1696	.1543	.1492	.1696	.1341
22	2.1052	2.1464	1.7652	.1387	.1267	.1402	.1147
23	2.2283	2.1052	1.7284	.096	.1052	.1187	.1311
24	.1	2.1862	2.1052	1.6446	.096	.1187	.128
Max	2.2283	2.1862	2.1538	2.4939	2.3967	2.343	2.6379
Min	.1	.1214	.0168	.096	.096	.0137	.1147
Avg	.3146	.9103	.7375	1.2094	.7667	.7773	.8874

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/S

Feeder No / Name : 207 / VITA WATER SUPPLY,ALSAND NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2294	.1326	.1989	.213	.1311	.1989	.2294
2	.2294	.1326	.1989	.0377	.1966	.1989	.2294
3	.0377	.1326	.1989	.0377	.1966	.2012	.2294
4	.2155	.1326	.1326	.1341	.1966	.2012	.2294
5	.2294	.1326	.1326	.1341	.1326	.2012	.2321
6	.2321	.1989	.2012	.2155	.1989	.1875	.2321
7	.2321	.1989	.2012	.218	.1966	.2012	.2321
8	.2321	.1966	.2321	.218	.1989	.1989	.2321
9	.2347	.2347	.1966	.2321	.1989	.1989	.2321
10	.1989	.1989	.2321	.2294	.1989	.1989	.2294
11	.2321	.1943	.2294	.2294	.0995	.2155	.2155
12	.2294	.1943	.2321	.2321		.2155	.2321
13	.2294	.1989	.2294	.2321	.1989	.2294	.2321
14	.1966	.1989	.2155	.1326	.1989	.2321	.2321
15	.2012	.1989		.2321	.1989	.0377	.2321
16	.1989	.1966	.213	.2321	.1989	.0373	.2294
17	.1966	.1966	.213		.1966	.2294	.2294
18	.1989		.2347	.2294	.1966	.2321	.2321
19	.1029	.1966	.2294	.2294	.1966	.2321	.2294
20	.1966	.1966	.2155	.2294	.1943	.2321	.2294
21	.1943	.1966	.1966	.2294	.1943	.2321	.1966
22	.1989	.2012	.2155	.1966	.1989	.2321	.2294
23	.1989	.1989	.213	.213	.1989	.2321	.2294
24	.2321	.1989	.1989	.2353	.1966	.1989	.2294
Max	.2347	.2347	.2347	.2353	.1989	.2321	.2321
Min	.0377	.1326	.1326	.0377	.0995	.0373	.1966
Avg	.2033	.1851	.2070	.1966	.1875	.1990	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/S

Feeder No / Name : 201 / 11 KV GARDI FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0472	.9922	.6325	.6554	.9175
2				.9488	.6325	.7042	.9069
3				.8749	.6325	.7888	.8848
4			.0372	.8539	.6325	.7127	.8745
5				.8124	.6249	1.0595	.8421
7	.0754	.0579					
8	.064	.061					
9	.0655		.0791		.0503		
10	1.3763	1.4255	1.5089				
11	1.749	1.8896	1.8442		.0663		
12	2.0119	2.0056	1.9113				.0594
13	2.0119	2.0885	1.9062		.0594		.0564
14	2.079	2.2043	1.7604		.061		
15	2.1026	2.1195	1.861		.0648		
16	2.0119	1.9951	1.7368		.0829		
17	1.7436	1.8399	1.3603	.0328			.0533
18		.0518		.0457	.0549		
19	.0602	.0676	.061		.0753		.0663
20	.0617	.072	.0564	.0572	.0705	.0617	.0617
21	.0511	.0674	.0511		.0602	.0511	.0594
22		.0511	1.0159	.759	.6401	.9175	
23		.0434	.9804	.6958	.6874	.9503	
24			.0457	.9922	.6325	.7459	.9175
Max	2.1026	2.2043	1.9113	.9922	.6874	1.0595	.9175
Min	.0511	.0434	.0372	.0328	.0503	.0511	.0533
Avg	1.1046	1.0025	.9567	.6423	.3200	.6647	.4750

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/S

Feeder No / Name : 202 / 11kv prabhat steel

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0061	.0091	.1417	.0061	.0122	.0133	.0061
2	.0046	.0122	.0093	.0051		.0154	.0046
3	.0046	.0152	.0223	.0069	.0091	.0152	.0046
4	.0061	.0122	.0343	.0051	.0091	.0051	.0061
5	.0069	.0091	.0086	.0069	.0091	.032	.0122
6	.0061	.0366	.0351	.0061	.0091	.0446	.0154
7	.0061	.0335	.0305	.0061	.0091		.0051
8	.2614	.1219	.2172	.1478	.003	.1696	.5175
9	.1294	.2987	.2402	.3696	.0015	.2987	.2957
10	.3881	.7167	.2896	.7468	.0046	.2987	.1294
11	.3018	.3206	.5544	.0823	.0069	1.0269	.6036
12	.4527	.3921	.2957	.3772	.0034	.961	.6036
13	.2218	.3361	.1128	.3018	.0069	.3881	.2987
14	.3018	.8002	.3772	.7545	.0019	.4108	.0366
15	.2241	.9425	.3961	.3018	.0019	.3921	.3018
16	.2715	.8865	.3018	1.0562	.0019	.7577	.2241
17	.6036	1.2071	.4108	.961	.0076	.3395	.2263
18	.8299	.7842	.7207	.125	.0076	.7545	.3018
19	.4527	.7842	.5041	.6036	.0095	.2641	.7545
20	.7545	.048	1.0829	.0427	.0394	.7655	.0549
21	.0137	.0103	.0069	.0137	.0394	.0069	.0091
22	.0137	.0095	.0069	.0152	.0057	.0061	.0152
23	.0122	.1698	.0061	.0152	.0038	.0061	.0152
24	.0061	.0091	.1372	.0061	.0122	.0095	.0061
Max	.8299	1.2071	1.0829	1.0562	.0394	1.0269	.7545
Min	.0046	.0091	.0061	.0051	.0015	.0051	.0046
Avg	.2200	.3319	.2476	.2485	.0093	.3035	.1853

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/S

Feeder No / Name : 203 / 11 kv Yetgaon AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8233	1.7436	2.64	.1509	.1448	.1543	.1227
2	1.8442	1.7436	2.7351	.132	.1433	.1595	.1029
3	1.7772	1.7436	2.2862	.132	.1433	.1387	.104
4	1.7101	1.7436	2.4036	.1494	.1433		.12
5	1.6263	1.8313	1.933	.1867	.1417		.12
6	.1214	.1478		.1848	.1448	.181	.124
7	.2241	.3018	.2452	.3395	.2241	.2614	.2241
8	.2427	.3018	.2829	.2641	.2241	.2829	.2641
9	.3018	.3048	.3403	.2263	.1494	.2829	.2263
10	.2641	.3395	.415	1.8233	2.0119	1.8107	2.1691
11	.3018	.3018	.362	2.7496	2.5774	2.364	2.713
12	.3018	.2743	.2263	3.2556	2.3975	2.713	2.713
13	.3018	.2614	.2241	3.2861	2.5692	2.6825	3.12
14	.2263	.2641	.2641	3.2556	2.5987	2.649	2.9508
15	.3048	.3018	.2263	2.7496	2.7073	2.7496	2.9165
16	.2263	.362	.2263	2.8166	2.4034	3.0691	2.9843
17	.3018	.3048	.2263	2.4813	2.0553	2.7846	2.8487
18	.2263	.1478	.1886	.2263	.2172	.2263	.1509
19	.2829	.1109	.2054	.2263	.2641	.2263	.1478
20	.2263	.2012	.2263	.2241	.2772	.2241	.1478
21	.2241	.2012	.2241	.1478	.2534	.2054	.1463
22	2.0119	2.2043	.1494	.1463	.2054	.1433	1.3923
23	1.8778	2.3739	.1867	.1463	.1612	.1214	1.3923
24	1.8945	1.8107	2.4863	.1698	.1448	.1463	.1214
Max	2.0119	2.3739	2.7351	3.2861	2.7073	3.0691	3.12
Min	.1214	.1109	.1494	.132	.1417	.1214	.1029
Avg	.7768	.8051	.8132	1.0613	.9293	1.0717	1.1384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/S

Feeder No / Name : 204 / 11 KV SALSHINGE FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.1219	.1772	1.8107	1.4586	1.1431	2.0119
2	.1294	.1219	.1715	1.7436	1.4251	1.1401	2.0119
3	.1294	.1219	.1457	1.6766	1.4251	1.166	1.9113
4	.1294	.1204	.1509	1.6095	1.4251	1.1469	1.8442
5	.1478	.1189	.1715	1.5424	1.4251	1.2431	1.6933
6	.2402	.1806	.2829	.2218	.1174	.1886	.2402
7	.2957	.3048	.3961	.3142	.2858	.3395	.3326
8	.2772	.2408	.3439	.3326	.2439	.3547	.3511
9	.2402	.2408	.2614	.2957	.2256	.2829	.2218
10	1.7436	1.9281	1.8679	.2957	.1852	.2054	.1663
11	5.4992	2.9508	2.9843	.1509	.2614	.2614	.1478
12	6.438	3.1352	3.2526	.1235	.2427	.2427	.1532
13	3.152	3.4294	3.219	.1463	.2614		.1646
14	3.155	3.0681	3.152	.1623	.2054		.1158
15	3.3311	3.3364	1.5257	.1646	.2195	.2241	.1113
16	3.0476	2.934	3.0178	.16	.2033	.1478	.1829
17	2.8349	3.1184	1.8778	.1036	.2534	.1663	
18	.1852	.2195	.1294	.1395	.2561	.2218	.1669
19	.4161	.3584	.2218	.1669	.2241	.2957	.1783
20	.4024	.3206	.2218	.1578	.2054	.2587	.1783
21	.1692	.2641	.2218	.1189	.2054	.2218	.1646
22	.1219	.1886	1.6766	1.6766	1.5746	1.9784	.1113
23	.1219	.1886	1.873	1.576	1.5565	2.1125	.1128
24	.1478	.1219	.1886	1.8233	1.4918	1.4327	2.079
Max	6.438	3.4294	3.2526	1.8233	1.5746	2.1125	2.079
Min	.1219	.1189	.1294	.1036	.1174	.1478	.1113
Avg	1.3543	1.1306	1.1471	.6880	.6407	.6716	.6370

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/S

Feeder No / Name : 206 / 11 kv salshinge Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1578	.1772	.1886	.1753	.1772	.1715	.2103
2	.1578	.1595	.1734	.1753	.1772	.1417	.1753
3	.1753	.1595	.208	.1928	.1772	.1578	.1753
4	.1753	.1772	.2303	.2103	.1949	.1886	.2103
5	.2103	.2303	.2561	.2629	.2303	.2328	.2804
6	.4031	.3721	.1698	.3681	.3544	.1886	.4382
7	.5258	.567	.6283	.5609	.5847	.4877	.5609
8	.4557	.5316	.462	.5083	.4607	.4801	.4557
9	.4382	.4075	.3582	.4557	.3544	.4338	.3155
10	.333	.4287		.333	.3366	.3326	.333
11	.3898	.3544	.3155	.2481	.1372	.3155	.3366
12	.3366	.2915	.298	.3366	.1949	.2454	.2481
13	.2481	.2279	.333	.2303	.2402	.2629	.2658
14	.3012	.2686	.298	.3189	.2303	.2804	.2481
15	.3012	.2561	.2804	.3012	.2401	.2804	.2801
16	.3012	.3395	.298	.3012	.2427	.2629	.3189
17	.2658	.2743	.3681	.2835	.3258	.3155	.3012
18	.3721	.4338	.3681	.4075	.4607	.4207	.3898
19	.5493	.5201	.4733	.5487	.6099	.5083	.5493
20	.4607	.5175	.4207	.4607	.5014	.4733	.5316
21	.3898	.4075	.3681	.3898	.3944	.4207	.4075
22	.2835	.2507	.2804	.3012	.3395	.3155	.3189
23	.2481	.2507	.2279	.2658	.208	.2454	.2658
24	.1753	.2126	.2218	.2103	.2126	.1772	.2103
Max	.5493	.567	.6283	.5609	.6099	.5083	.5609
Min	.1578	.1595	.1698	.1753	.1372	.1417	.1753
Avg	.3190	.3257	.3142	.3269	.3077	.3058	.3261

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV STN LENGRE

Feeder No / Name : 201 / 11 KV Lengare Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.032	.0312	.0305	.5792	.5792	.5117	.0305
2	.0332	.0312	.0305	.571	.5792	.506	.0305
3	.0332	.032	.0305	.5601	.5487	.502	.0305
4	.0332	.032	.0305	.5312	.5556	.5218	.0305
5	.048	.032	.0457	.5247	.5247	.5093	.0305
6	.0753	.032	.0762	.064	.0469	.0781	.0305
7	.096	.0486	.0914	.0819	.0463	.0838	.0305
8	.0914	.0324	.0914	.0829	.0463	.0617	.0305
9	.0667	.0469	.0914	.0743	.0457	.0579	.0305
10	.9061	.6401	.7926	.064	.0457	.0316	.0305
11	.9686	1.829	1.6404	.0469	.0469	.0762	.0309
12	1.1523	2.1643	1.9204	.0469	.0753	.0762	.0309
13	1.2483	2.1948	2.1214	.0312	.1219	.0914	.0309
14	1.2163	2.2558	2.343	.0309	.0914	.0762	.0457
15	1.2163	2.1948	2.3758		.096	.0762	.0457
16	1.1523	2.0424	2.1052	.0469	.1094	.061	.0463
17	1.1561	1.829	1.7078	.0474	.1094	.0762	.0457
18	.048	.0914	.1029	.0469	.0743	.061	.0463
19	.0497	.0914	.104	.0463	.0914	.0762	.0305
20	.0492	.0762	.1006	.0469	.1107	.0762	.0305
21	.0497	.061	.0995	.048	.0983	.0762	.0463
22	.0469	.0305	.6097	.5944	.5864	.0762	.0309
23	.0312	.0305	.6249	.5944	.6878	.0457	.0309
24	.0312	.0312	.0305	.5944	.6401	.535	.0305
Max	1.2483	2.2558	2.3758	.5944	.6878	.535	.0463
Min	.0312	.0305	.0305	.0309	.0457	.0316	.0305
Avg	.4096	.6617	.7165	.2328	.2482	.1810	.0345

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV STN LENGRE

Feeder No / Name : 202 / 11 KV VEJEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3923	1.3123	1.6907	.104	.0857	.0924	.0663
2	1.3748	1.3123	1.6244	.0886	.0857	.0747	.0663
3	1.3413	1.3441	1.5746	.0905	.0857	.0747	.0663
4	1.3426	1.3763	1.4918	.0895	.1029	.0924	.0829
5	1.3765	1.3927	1.442	.1075	.0857	.0934	.1132
6	.1187	.08	.1326	.1063	.0857	.1109	.1326
7	.1402	.1265	.1326	.1227	.104	.1187	.1326
8	.1734	.1581	.1326	.1448		.12	.1326
9	.2229	.1423	.1326	.1612	.12	.1227	.116
10	.1478	.128	.116	1.3599	1.3592	1.2597	1.3426
11	.1663	.116	.116	2.1216	1.6095	2.0056	1.6244
12	.1867	.116	.124	3.1623	2.431	2.3868	
13	.1663	.116	.1086	3.315	2.4143	2.4531	2.2939
14	.1867	.1492	.1829	3.315	2.5434	2.4366	2.4086
15	.2054	.1492	.2218	2.7854	2.4926	2.3205	2.4086
16	.1387	.1326	.1646	2.8182	2.146	2.2874	2.5724
17	.1214	.1326	.124	2.6216	1.9725	2.1216	2.2939
18	.12	.1326	.1494	.12	.1187	.0829	.1475
19	.1029	.1326	.124	.1387	.1254	.116	.1311
20	.1214	.1326	.1417	.1214	.1075	.1326	.116
21	.1214	.116	.1227	.1227	.1075	.0995	.0829
22	1.491	1.7404	.1052		.0895	.0829	1.1843
23	1.4091	1.8067	.1029	.1029	.0732	.0829	1.2308
24	1.4091	1.4091	1.7238	.1029	.1029	.0895	.0829
Max	1.491	1.8067	1.7238	3.315	2.5434	2.4531	2.5724
Min	.1029	.08	.1029	.0886	.0732	.0747	.0663
Avg	.5657	.5731	.4992	1.0097	.8021	.7857	.8186

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV STN LENGRE

Feeder No / Name : 203 / 11 KV SALSHINGE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.128	.125	.1619	1.2193	1.2944	.9877	1.4251
2	.112	.0937	.1457	1.2498	1.2944	.953	1.3603
3	.1147	.096	.1457	1.3094	1.278	.953	1.3117
4	.1147	.112	.1457	1.2944	1.278	1.0082	1.2955
5	.1457	.112	.1619	1.3245	1.278	1.0753	1.2308
6	.1718	.112	.1943	.1658	.1357	.2035	.1619
7	.2321	.125	.2105	.2229	.1543	.197	.1562
8	.2229	.1423	.2105	.2454	.1543	.2126	.1781
9	.2103	.1423	.1943	.2267	.1734	.2035	.1619
10	1.3272	1.3272	1.5546	.218	.1457	.2035	.1619
11	1.9662	2.4615	2.3594	.1658	.1389	.1943	.1475
12	1.9989	3.0407	2.7349		.1614	.1457	.1475
13	2.0645	2.7854	2.6355	.1475	.1646	.1457	.128
14	1.9334	2.7206	2.652	.1475	.1829	.1619	.128
15	1.9662	2.4615	2.6825	.1372	.2031	.1619	.1406
16	1.9334	2.332	2.536	.1372	.2214	.1619	.1372
17	1.9006	2.17	2.4413	.1543	.1932	.1781	.1581
18	.144	.1943	.2328	.1543	.2439	.1943	.1581
19	.144	.1943	.2353	.1734	.2572	.1943	.16
20	.1475	.1943	.2279	.156	.2743	.1943	.176
21	.1886	.1943	.2229	.1658	.2347	.2105	.192
22	.1406	.1619	1.3757	1.3599	1.1843	1.4575	.1543
23	.128	.1619	1.3123	1.3272	1.0936	1.3927	.1372
24	.125	.125	.1457	1.2346	1.3108	.9633	1.3927
Max	2.0645	3.0407	2.7349	1.3599	1.3108	1.4575	1.4251
Min	.112	.0937	.1457	.1372	.1357	.1457	.128
Avg	.7317	.8994	1.0383	.5625	.5438	.4897	.4500

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV STN LENGRE

Feeder No / Name : 204 / 11 KV Lengare Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1509	.1629	.1524	.1524	.1334	.1629
2	.1334	.1307	.1629	.1334	.1334	.1143	.1629
3	.1334	.1307	.1448	.1334	.1334	.1143	.1629
4	.1334	.1509	.1448	.1334	.1509	.1334	.1448
5	.1715	.168	.1629	.1524	.1698	.1524	.181
6	.2452	.2452	.2172	.2614	.1372	.2829	.2353
7	.3292	.3772	.3258	.2957	.156	.3696	.3439
8	.2865	.3361	.3077	.2772	.156	.3258	.3258
9	.2658	.2987	.2896	.2378	.2454	.2534	.2534
10	.197	.2427	.2534	.2279	.1543	.1772	.2172
11	.2149	.1629	.2254	.1907	.1715	.181	.1715
12	.1772	.181	.208	.1734	.1886	.1629	.1715
13	.1772	.181	.2103	.1578	.1886	.1448	.1715
14	.1612	.1629	.197	.1578	.1595	.1629	.1387
15	.1612	.1448	.1791	.1734		.1448	.1543
16	.1791	.181	.1595	.1734		.1448	.1715
17	.1791	.2353	.2103	.1715	.1772	.1448	.1734
18	.2454	.2353	.2772	.1886	.2328	.2534	.1907
19	.2987	.3801	.3696	.3361	.3734	.3439	.3395
20	.3361	.362	.3547	.3772	.3772	.3439	.3772
21	.3772	.2896	.3018	.3361	.2829	.3077	.3258
22	.2103	.2172	.2263	.2477	.1886	.2172	.2058
23	.1698	.2172	.1698	.1524	.1524	.2172	.1734
24	.1509	.1509	.1991	.1509	.1524	.1334	.181
Max	.3772	.3801	.3696	.3772	.3772	.3696	.3772
Min	.1334	.1307	.1448	.1334	.1334	.1143	.1387
Avg	.2119	.2222	.2275	.208	.1925	.2066	.2140

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV STN LENGRE

Feeder No / Name : 205 / 11 KV SALSHINGE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2263	.2075	.1524	.1524	.1524	.1886
2	.1905	.2096	.2075	.1524	.1524	.1334	.1886
3	.1715	.1715	.1886	.1334	.1524	.1334	.1698
4	.1715	.1905	.1886	.1334	.1715	.1524	.1698
5	.1905	.1905	.2075	.1334	.1715	.1715	.1698
6	.2075	.1905	.2452	.1663	.1905	.1905	.2075
7	.2772	.2858	.2829	.2195	.2075	.2477	.2452
8	.2743	.2477	.2829	.2534	.2075	.2218	.2452
9	.2686	.2667	.2829	.2481	.2096	.2241	.2641
10	.1463	.2477	.2641	.1612	.1715	.2686	.2641
11	.2378	.2452	.2054	.1886	.1646	.2641	.2075
12	.2012	.2263	.2561	.2075	.132	.2263	.1886
13	.2195	.2641	.2686	.1886	.2012	.1886	.1698
14	.2033	.2263	.2126	.1698	.16	.1886	.1715
15	.1848	.2075	.1928	.1698	.1829	.1698	.1524
16	.2263	.2263	.208	.1698	.1478	.1698	.1524
17	.2452	.2452	.2303	.2286	.1867	.1698	.1905
18	.2075	.2641	.2477	.2477	.2378	.2641	.2096
19	.2075	.3395	.3048	.2667	.3142	.3395	.2286
20	.2263	.3395	.3048	.3239	.2686	.3206	.2667
21	.2263	.2829	.3206	.3018	.2241	.3206	.2858
22	.3018	.2641	.2286	.2452	.1698	.2641	.2286
23	.2263	.2641	.2096	.1715	.1715	.2452	.1905
24	.2263	.2263	.2263	.1715	.1715	.1524	.2263
Max	.3018	.3395	.3206	.3239	.3142	.3395	.2858
Min	.1463	.1715	.1886	.1334	.132	.1334	.1524
Avg	.2194	.2437	.2406	.2002	.1883	.2158	.2076

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV STN LENGRE

Feeder No / Name : 206 / 11 KV VEJEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0943	.1886	.1143	.0953	.1143	.1698
2	.0953	.1132	.1698	.0953	.0953	.1143	.1509
3	.0953	.1132	.1698	.0953	.0953	.1143	.132
4	.1143	.132	.1509	.1143	.1143	.1143	.132
5	.1334	.1509	.1698	.1524	.132	.1334	.1509
6	.1698	.1698	.2075	.1829	.1886	.1905	.2075
7	.2241	.2641	.2452	.1991	.1886	.2858	.2452
8	.2195	.2452	.2452	.2149	.1886	.3239	.2452
9	.2195	.2641	.2641	.2012	.1886	.362	.2641
10	.0924	.2075	.1886	.181	.1715	.3224	.3206
11	.2772	.2452	.2926	.1524	.1829	.1886	.2829
12	.1509	.2075	.3045	.1524	.2427	.1886	.2641
13	.132	.1509	.3109	.1715	.128	.132	.1132
14	.132	.2263	.2149	.1715	.1791	.2452	.0943
15	.1143	.2829	.2126	.1905	.1433	.2829	.1698
16	.2477	.2641	.2896	.2096	.0895	.2263	.1886
17	.2858	.2452	.2149	.2286	.1629	.1886	.2075
18	.2096	.1886	.2587	.2096	.3045	.2452	.2096
19	.2263	.2641	.2772	.2667	.3109	.3206	.2667
20	.2452	.2641	.2801	.2858	.2686	.3018	.2858
21	.2263	.2263	.2641	.2286	.2353	.2452	.2667
22	.1509	.1698	.1715	.1524	.168	.1698	.1905
23	.1132	.1698	.1334	.1334	.1143	.1698	.1715
24	.0943	.0943	.1509	.1143	.1143	.1143	.1509
Max	.2858	.2829	.3109	.2858	.3109	.362	.3206
Min	.0924	.0943	.1334	.0953	.0895	.1143	.0943
Avg	.1694	.1981	.2240	.1758	.1709	.2123	.2033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV STN LENGRE

Feeder No / Name : 207 / 11KV KANDESARWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.423	.4054	.5079	.0312	.0312	.0301	.0537
2	.4254	.3765	.503	.0324	.0312	.0301	.0362
3	.4214	.3961	.4687	.032	.0309	.0309	.0343
4	.4214	.4401	.4321	.0332	.0309	.032	.052
5	.4012	.4633	.4481	.0335	.0309	.0332	.0537
6	.0324	.0566	.0537	.0335	.0305	.0305	.0526
7	.0324	.0566	.0724	.0332	.0305	.0354	.052
8	.0324	.0377	.0716	.0343	.0463	.0347	.0514
9	.0324	.0324	.0709	.0316	.0463	.0509	.0486
10	.0316	.0324	.0351	.4904	.4401		.571
11	.0316	.0509	.0305	.5213	1.174		.6173
12	.0316	.0497	.0343	.5792	1.2346	1.012	.6173
13	.0316	.0328	.0343	.5357	1.2809	1.1248	.6097
14	.0566	.0503	.0332	.5502	1.2963	1.278	.6401
15	.0566	.0497	.0343	.5144	1.1888	1.2651	.6173
16	.0566	.0503	.0328	.4858	1.0364	1.1561	.6173
17	.0566	.0492	.0312	.4344	.9095	1.0883	.5093
18	.0566	.0633	.032	.0566	.0305	.0876	.0566
19	.0324	.0503	.0335	.0566	.0514	.0876	.0377
20	.0324	.0671	.0312	.0566	.048	.0701	.0358
21	.0486	.0678	.0332	.0566	.0434	.0716	.0537
22	.1882	.503	.0312	.0566	.0332	.0701	.4755
23	.3765	.4999	.0305	.0305	.0309	.0716	.4607
24	.4344	.4054	.5121	.0305	.0312	.0293	.0532
Max	.4344	.503	.5121	.5792	1.2963	1.278	.6401
Min	.0316	.0324	.0305	.0305	.0305	.0293	.0343
Avg	.1560	.1786	.1499	.1979	.3807	.3509	.2670

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244077 / 33/11 KV KARVE MIDC

Feeder No / Name : 201 / 11 KV TEXTILE PARK

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5801	.6962	.7625	.7625	.663	.4641	.5636
2	.5801	.6962	.663	.7459	.663	.4641	.5636
3	.5801	.6962	.6299	.7459	.6299	.4973	.5967
4	.5636	.663	.5636	.7625	.5636	.4973	.5967
5	.5636	.6962	.663	.7625	.5801		.5636
6	.5304	.663	.663	.7625	.6299	.5304	.4973
7	.5304	.663	.6962	.7459	.6299	.5636	.4973
8	.5636	.663	.663	.7293	.4973	.5801	.6413
9	.6464	.7625	.663	.7625	.2818	.6464	.6299
10	.663	.7625	.6796	.7625	.2486	.663	.6299
11	.663	.7625	.663	.6962	.2286	.663	.663
12	.6299	.8122	.663	.6464	.2984		.6796
13	.6299	.8453	.6962	.7127	.2652	.7956	.6962
14	.6299	.8288	.7625	.7293	.2652	.8288	.5801
15		.7625	.7625	.7293	.2486	.7625	.5487
16	.663	.7956	.7293	.7293	.1219	.7625	.6299
17	.7625	.7956	.7625	.7459		.7459	.6133
18	.7625	.7956	.7625	.5967	.116	.7459	.6133
19	.663	.7625	.6962	.5967	.116	.663	.6299
20	.663	.7459	.6962	.6464	.2652	.6299	.6299
21	.663	.7956	.7459	.663	.2984	.5636	.6133
22	.6962	.8122	.7459	.663	.4641	.5636	.6962
23	.663	.7956	.7459	.7293	.4641	1.442	.6962
24	.5801	.663	.7625	.7625	.7293	.4641	.5967
Max	.7625	.8453	.7625	.7625	.7293	1.442	.6962
Min	.5304	.663	.5636	.5967	.116	.4641	.4973
Avg	.6291	.7473	.7017	.7162	.4030	.6608	.6111

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244077 / 33/11 KV KARVE MIDC

Feeder No / Name : 202 / 11 KV PARE FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1006	1.531	1.7924	1.4746	.0686	.1075	.0701
2	.1052	1.5684	1.5684	1.4575	.0686	.1075	.0732
3	.1052	1.5203	1.4723	1.4403	.0693	.1086	.0732
4	.1052	1.3763	1.2651	1.4251	.1417	.1086	.0724
5	.1417	1.4575	1.2651	1.4251	.1417	.1463	.0709
6	.1772	.1402	.1448	.0701	.1448	.1848	.0876
7	.1772	.1463	.1448	.1075	.181	.2033	.0716
8	.1417	.1433	.1372	.1086	.1734	.2033	.0732
9	.1772	.1387	.1341	.1086	.096	.1463	.1086
10	.1658		.1417	1.2334	1.1888	.9842	1.2651
11		.1311	.1463	1.6644	2.0553		1.8884
12	.0709	.1734	.1052	1.8564	1.9334	1.3603	2.13
13	.0732	.1753	.1075	2.17	2.0153	2.0481	2.1879
14	.0709	.181	.0995	2.2348	2.0972	2.2024	1.7604
15	.0724	.181	.1097	2.2024	2.1125	2.0243	1.9757
16	.0716	.1753	.1075	2.0805			1.9685
17	.0732	.1311	.1063	2.0165	1.2654	1.7966	1.7284
18	.0724	.1448	.1097	.1219	.125	.096	.1299
19	.0724	.1448	.1052	.1387	.128		.1802
20	.1097	.1448	.1052	.1387	.1753	.1075	.1677
21	.0724	.1448	.1052	.1387	.1753	.1052	.1402
22	1.7185	1.9109	1.406	.1063	.1402	.1075	.1052
23	1.5623	1.9757	1.8842	.0995	.1075	.0701	.1052
24	.0983	1.6385	1.9433	1.5203	.1006	.1075	.0716
Max	1.7185	1.9757	1.9433	2.2348	2.1125	2.2024	2.1879
Min	.0709	.1311	.0995	.0701	.0686	.0701	.0701
Avg	.2407	.6641	.6044	1.0558	.6393	.5869	.6877

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244077 / 33/11 KV KARVE MIDC

Feeder No / Name : 203 / 11 KV WAZAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9724	.0754		.0754		1.073	1.5089
2	.9054	.0754		.0754		.9892	1.4419
3	.9221	.0754		.0754		.9724	1.4419
4	.8383	.0754		.0754		.9389	1.1736
5	.8383	.0754		.0754		.9221	1.1736
6	.1006	.0754		.1132		.1006	.0754
7	.1006	.0754		.1132		.1341	.0754
8	.1006	.0754		.1132		.1341	.0754
9	.1006	.0754		.0754		.1006	.0754
10	1.5089		1.5089		.0671	.0754	.0671
11	1.8442		2.0119		.0671	.0754	.0671
12	2.0119		2.0119		.0671	.0754	.0671
13	2.0957		2.0119		.0671	.0754	2.1879
14	2.5463		2.0119			.0663	.0671
15	2.6406		2.0957		.0671	.0754	.0671
16	2.3472		2.0119		.0671	.0754	.0671
17	2.1795		1.6766		.1006	.3395	.1006
18	.0754		.0754		.1006	.0754	.1341
19	.0754		.0754		.1341	.0754	.1341
20	.0754		.0754		.1341	.0754	.1341
21	.0754		.0754		.1341	.0754	.1006
22	.0754		.0754		1.3413	1.576	1.1736
23	.0754		.0754		1.3077	1.643	1.0898
24	.7716	.0754		.0754		1.2071	1.5089
Max	2.6406	.0754	2.0957	.1132	1.3413	1.643	2.1879
Min	.0754	.0754	.0754	.0754	.0671	.0663	.0671
Avg	.9699	.0754	1.1281	.0867	.2812	.4563	.5837

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244077 / 33/11 KV KARVE MIDC

Feeder No / Name : 204 / TEXTILE NO. 2

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.3395	.5281	.3395	.2263	.3018	.3395
2	.5658	.3206	.547	.3395	.1886	.3018	.3018
3	.5281	.3206	.4715	.3018	.2075	.3018	.3206
4	.5281	.3395	.4904	.3395	.1698	.3018	.3206
5	.4527	.3395	.4338	.3018	.2452	.3018	.3395
6	.4527	.3395	.4715	.3018	.1886	.3395	.3395
7	.415	.3395	.4904	.3395	.2263	.3395	.3395
8	.3772	.3206	.4715	.3395	.1886	.3395	.3772
9	.3395	.4715	.4338	.3584	.1698	.5093	.3772
10	.415	.4904	.5658	.3206		.5658	.3395
11	.4527	.5281	.5658	.4527	.1132	.6036	.4715
12	.3018	.4527	.5281	.3018	.1132		.4904
13	.3018	.5281	.4904	.2829	.1132	.5093	.4904
14	.3018	.5281	.5281	.3395		.5281	.5658
15	.2641	.5281	.5658	.3961		.5658	.5658
16	.2641	.5281	.4904	.3772	.0754	.5658	.4904
17	.2641	.5093	.4527	.3206		.4904	.4904
18	.3206	.5093	.3772	.3206		.415	.4904
19	.3018	.5281	.3772	.3584		.3395	.5281
20	.2641	.4715	.3395	.3772			.5658
21	.2075	.5281	.3395	.3395	.1509	.3772	.5281
22	.3018	.547	.3395	.2075	.1698	.3772	.5658
23	.3395	.5658	.3395	.1698	.1698	.3395	.5658
24	.5658	.3395	.5847	.3206	.2075	.1509	.3395
Max	.5658	.5658	.5847	.4527	.2452	.6036	.5658
Min	.2075	.3206	.3395	.1698	.0754	.1509	.3018
Avg	.3788	.4464	.4676	.3269	.1720	.4030	.4393

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244078 / 33/11 KV GARDI

Feeder No / Name : 201 / Yashodhan Garment

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2452	.2667	.2858	.2195	.2286	.2452
2	.2286	.2452	.2667	.2858	.2195	.2286	.2452
3	.2286	.2452	.2667	.2858	.2195	.2477	.2477
4	.2286	.2452	.2667	.2667	.2195	.2286	.2477
5	.2286	.2452	.2477	.2667	.2561	.2286	.2614
6	.2477	.2452	.2477	.2667	.2614	.2286	.2477
7	.2477	.2614	.2667	.2667	.2641	.2477	.2452
8	.2667	.2829	.2829	.3018	.0995	.2477	.3048
9	.362	.3239	.3239	.3429	.0572	.3239	.381
10	.362	.3429	.3429	.362	.0754	.3206	.381
11	.3395	.362	.3429	.3429		.3206	.381
12	.3395	.362	.3048	.3018	.1715	.3206	.381
13	.2829	.4001	.3395	.3239	.1524	.3206	.381
14	.3772	.3921	.3429	.3584	.2286	.3584	.381
15	.415	.415	.362	.3395	.2286	.362	.4001
16	.3584	.4001	.362	.3429	.2286	.4001	.4001
17	.3772	.2286	.3429	.362	.2286	.381	.362
18	.3961	.3772	.3429	.3239	.2286	.4001	.362
19	.362	.3239	.3429	.2829	.2286	.362	.3429
20	.2896	.3239	.2858	.2641	.2286	.3206	.3429
21	.2641	.2667	.2858	.2641	.2286	.2452	.3109
22	.2452	.2667	.2858	.2378	.2286	.2829	.2658
23	.2452	.2667	.2858	.2279	.2286	.2641	.2507
24	.2286	.2452	.2667	.2858	.2195	.2286	.2452
Max	.415	.415	.362	.362	.2641	.4001	.4001
Min	.2286	.2286	.2477	.2279	.0572	.2286	.2452
Avg	.2979	.3047	.3030	.2995	.2053	.2957	.3172

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244078 / 33/11 KV GARDI

Feeder No / Name : 202 / GHANWAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.4096	.4801	.5079	.4902
2				.4096	.4801	.5533	.4801
3				.426	.4801	.5121	.463
4	.0747		.0747	.4534	.4801	.5407	.4374
5	.0754		.0747	.4534	.4801	.6173	.4161
6	.0943	.0943		.0943	.1132	.1132	.0739
7	.1132	.0895	.1132	.0943	.1132	.0934	.1109
8	.0747	.0934	.0934	.112	.0754	.0943	.0924
9	.0739	.1052	.1086	.1307	.0905	.0732	.0924
10	.4161	.4111	.3292	.112	.1086		
11	1.065	.8482	.9175	.0934		.0754	.1509
12	1.065	1.1012	1.0978	.0943	.0739	.0924	.1698
13	1.2146	1.1498	1.0814	.112	.0747	.0754	.1509
14	1.2125	1.1142	1.1469	.112	.0934	.112	.132
15	1.2452	1.1336	1.0978	.1132	.0914	.0943	.1341
16	1.1174	1.0059	1.0688	.112		.0934	.1492
17	1.0722	1.0082	1.0526	.0934	.0934	.0934	.0857
18	.0876	.0739	.0914	.1097	.1132	.1307	.0905
19	.0934	.128	.1109	.0934	.112	.132	.1132
20	.0934	.1109	.1109	.112	.112	.1132	.0934
21	.0934	.0934	.0924	.0943	.1174	.0934	.0754
22	.0754	.0943	.4752	.5761	.5281	.664	
23			.4534	.5376	.5506	.5535	.0754
24				.426	.4744	.5365	.4843
Max	1.2452	1.1498	1.1469	.5761	.5506	.664	.4902
Min	.0739	.0739	.0747	.0934	.0739	.0732	.0739
Avg	.4925	.5091	.5048	.2239	.2425	.2593	.2073

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244078 / 33/11 KV GARDI

Feeder No / Name : 203 / GHANWAD GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.2865	.2686	.3109	.2561	.2987	
2	.3018	.2804	.2835	.2772	.2561	.3018	.2715
3	.2743	.2835	.2865	.2772	.2561	.2987	.2715
4	.3077	.3012	.3077	.3326	.2926	.3395	.2926
5	.4119	.3801	.3224	.4024	.3658	.5228	.4066
6	.5359	.5304	.4024	.5853	.6348	.5853	.5487
7	.6697	.6401	.6219	.695	.695	.7421	.695
8	.583	.6201	.6283	.6379	.6447	.6584	.6626
9	.5784	.5028	.583	.4973	.4854	.6613	.6443
10	.4862	.5201	.5197	.4801	.4557	.5506	.5735
11	.5571	.506	.503	.407	.4557	.4666	.5243
12	.5182	.5407	.4862	.3856	.3772	.4481	.4973
13	.4586	.4144	.4807	.3647		.4481	.4359
14	.4424	.4527	.4915	.3353	.2195	.4049	.39
15	.421	.4752	.4915	.2984	.3086	.4481	.426
16	.4752	.4917	.4973	.3113		.3563	.4801
17	.4641	.4321	.503	.3812	.4801	.4807	.5426
18	.6687	.5552	.6201	.4287	.5784	.7186	.6001
19	.6984	.7087	.6984	.6335	.6173	.7522	.6687
20	.6154	.5959	.6584	.6036	.6335	.6878	.6401
21	.5014	.5373	.5611	.499	.543	.5611	.5847
22	.3982	.5415	.462	.3696	.4024	.3881	.4207
23	.2865	.3077	.362	.3109	.3361	.3258	.439
24	.2926	.2865	.2801	.3109	.2561	.3206	.2865
Max	.6984	.7087	.6984	.695	.695	.7522	.695
Min	.2743	.2804	.2686	.2772	.2195	.2987	.2715
Avg	.4678	.4663	.4716	.4223	.4341	.4903	.4914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244102 / 33/11 KV pare sub-station

Feeder No / Name : 201 / 11 KV PARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2477	.2286	.2477	.2667	.2477	.2667
2	.2096	.2286	.2096	.2477	.2286	.2096	.2477
3	.2075	.2286	.2012	.2286	.2195	.2096	.2477
4	.2096	.2096	.2427	.2286	.2263	.2286	.2858
5	.2452	.2477	.2829	.2987	.3429	.3048	.3048
6	.2667	.3429	.3048	.4066	.381	.4066	.4001
7	.3429	.4001	.381	.499	.4572	.4755	.4191
8	.4191	.4572	.4763	.4435	.4763	.4525	.4954
9	.3239	.4001	.4191	.4251	.4001	.3898	.4191
10	.362	.4001	.4001	.3292	.2658	.362	.3048
11	.362	.2477	.381	.2715		.3258	.2303
12	.362	.3429	.381	.2303		.3258	.197
13	.3429	.362	.3429	.2328		.2896	.181
14	.3429			.1907		.2587	.1848
15	.3239	.3239		.1928	.2378	.2587	.1867
16	.3429	.3239			.2195	.2402	.1867
17	.381	.3239	.2858	.2218	.2328	.2402	.2172
18	.4191	.4382		.2477	.3045	.3429	.3239
19		.5144		.4572	.5544	.5359	.5144
20	.4805	.4954		.4382	.5228	.4805	.4763
21	.4481	.4572		.4191	.4954	.4251	.4572
22	.3734	.3121	.381	.381	.4001	.381	.3772
23	.3429	.2858	.3048	.3429		.2858	.3258
24	.2477	.2667	.2667	.2667	.2858	.2667	.2667
Max	.4805	.5144	.4763	.499	.5544	.5359	.5144
Min	.2075	.2096	.2012	.1907	.2195	.2096	.181
Avg	.3298	.3416	.3229	.3151	.3430	.3310	.3132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244102 / 33/11 KV pare sub-station

Feeder No / Name : 202 / 11 KV PARE AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5864	.8002	.7499	.0572	.0572	.0381	.0381
2	.5864	.7773	.703	.0572	.0572	.0381	.0381
3	.5624	.7773	.6944	.0572	.0381	.0381	.0381
4	.6167	.8162	.7621	.0572	.0381	.0381	.0381
5	.6718	.8482	.8333	.0762	.0572	.0381	.0572
6	.0572	.0762	.0762	.0762	.0762	.0381	.0572
7	.0762	.0953	.0762	.0762	.0953	.0381	.0572
8	.0762	.0953	.0762	.0953	.0762	.0572	.0381
9	.0762	.0953	.0762	.1143	.0572	.0572	.0572
10	.0572	.0572		.9568		.7682	.7907
11	.0572	.0762	.0572	1.3748		1.3279	
12	.0572	.0762	.0572	1.2654		1.3904	1.2811
13	.0572	.0762	.0572	1.2342		1.4506	1.3443
14	.0762	.0762		1.4198	1.1822	1.4661	1.4091
15	.0762	.0572		1.439	1.2803	1.4815	1.2763
16	.0953	.0572		1.3117	1.3279	1.4969	1.406
17	.0572	.0762	.0572	1.2186	1.2803	1.3279	1.3757
18	.0572	.0762		.0953	.0381	.0572	.0762
19		.0762		.0762	.0572	.0572	.0572
20	.0762	.0762		.0762	.0572	.0572	.0572
21	.0762	.0572		.0762	.0572	.0572	.0381
22	.9762	.8905	.0762	.0762	.0572	.0381	.6327
23	.8962	.8488	.0762	.0762	.0381	.0381	.5937
24	.6249	.8322	.7811	.0762	.0572	.0381	.0381
Max	.9762	.8905	.8333	1.439	1.3279	1.4969	1.4091
Min	.0572	.0572	.0572	.0572	.0381	.0381	.0381
Avg	.2848	.3246	.3256	.4767	.2993	.4764	.4694

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244102 / 33/11 KV pare sub-station

Feeder No / Name : 203 / 11 KV GHOTI (BK) AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.7125	.3906	.0762	.0953	.0762	.0762
2	.5401	.664	.3858	.0762	.0762	.0762	.0762
3	.5155	.664	.3704	.0762	.0953	.0762	.0762
4	.5155	.6401	.4938	.0953	.1143	.0953	.0953
5	.5556	.6882	.5937	.1334	.1334	.1334	.0953
6	.1334	.1334	.1715	.1905	.1524	.1524	.1334
7	.1334	.1905	.1715	.2286	.1524	.1905	.1524
8	.1334	.1715	.1524	.1715	.1524	.2096	.0953
9	.1905	.1143	.1715	.1524	.1334	.1334	.1524
10	.1334	.0762	.0953	.6483	.7099	.7362	.7907
11	.0953	.0953	.0762	.9568		1.0467	
12	.0762	.0381	.0762	.953		1.1405	
13	.0762	.0381	.0762	.9646		1.3123	
14	.0762	.0381		1.1717	1.0437	1.2342	1.2631
15	.0953	.0381		1.1728	1.2163	1.2654	1.0111
16	.0953	.0381		1.1069	1.186	1.1702	1.186
17	.1143	.0572	.0953	1.0155	.9842	1.0911	1.1092
18	.1334	.0572		.1334	.1715	.1334	.1334
19		.1715		.2477	.2096	.2096	.2286
20	.2096	.2286		.2096	.2096	.2096	.2096
21	.1715	.2096		.1905	.1905	.1905	.1905
22	.8962	.787	.1334	.1524	.1334	.1524	.7499
23	.8162	.7968	.1143	.1143	.0953	.1143	.6944
24	.6481	.7362	.4321	.0762	.0953	.0762	.0762
Max	.8962	.7968	.5937	1.1728	1.2163	1.3123	1.2631
Min	.0762	.0381	.0762	.0762	.0762	.0762	.0762
Avg	.3028	.3077	.2353	.4298	.3500	.4677	.4093

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244123 / 33/11 kv 5MVA VITA NEW S/STN

Feeder No / Name : 201 / 11 KV Harewadi URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4973	.4641	.4862	.4458	.4024	.4161	.4748
2	.4508	.4475	.4578	.4458	.3856	.3988	.4854
3	.4334	.4475	.4578	.4287	.373	.3988	.4334
4	.4382	.4527	.4801	.4334	.373	.3988	.4382
5	.4382	.4862	.4748	.3988	.373	.3944	.4557
6	.5144	.4862	.4694	.3988	.407	.3944	.4557
7	.5365	.5365	.5087	.5784	.4458	.4557	.5765
8	.6613	.639	.6299	.6036	.4475	.5487	.5868
9	.7545	.6093	.6882	.663	.4641	.5441	.5506
10	.8383	.7956	.7293	.7125	.5533	.5441	.5441
11	.8951	.8259	.7293	.7537	.4917	.664	.5851
12	.9282	.9012	.7293	.7625		.6964	.6325
13	.8951	.8421	.7459	.7611		.7045	.6882
14	.9175	.9175	.7956	.7865		.7611	.7045
15	.9614	.9012	.7956	.7209	.4527	.7701	.7125
16	.9831	.9012	.779	.7373	.4475	.8192	.7202
17	.9448	.8029	.7537	.7449	.4475	.7701	.7522
18	.7459	.7209	.663	.6802	.4801	.6962	.7682
19	.6706	.6706	.6371	.6203	.4801	.7202	.5087
20	.6783	.6036	.6274	.5636	.4862	.6443	.5144
21	.6203	.5868	.5935	.5138	.4578		.5144
22	.5868	.5935	.5765	.4801	.4508	.5721	.4801
23	.5138	.4862	.5087	.4748	.4334	.5144	.4681
24	.5144	.4752	.4973	.4424	.4191	.4161	.4862
Max	.9831	.9175	.7956	.7865	.5533	.8192	.7682
Min	.4334	.4475	.4578	.3988	.373	.3944	.4334
Avg	.6841	.6497	.6173	.5896	.4415	.5758	.5640

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244135 / 33/11 KV BHALAWANI S/STN.

Feeder No / Name : 201 / 11 KV Shelakbav Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2149	.2149	.2481	.1949		.2303	.1772
2	.2328	.2172	.2658	.1949		.2126	.1772
3	.2149	.2172	.2658	.2303		.2303	.2126
4	.197	.2353		.2481		.2481	.2303
5	.2149	.2561	.2835	.2481		.2658	.2658
6	.2507	.3475	.2835	.2881		.3012	.3224
7	.3224	.4163	.3012	.3761		.3366	.394
8	.3582	.3801	.3189	.3224		.3544	.3582
9	.3582	.3258	.3189	.3045		.3012	.3224
10	.2881	.2865	.3224	.3224		.2865	.2865
11	.2507	.2328	.2481	.2507		.2865	.2481
12	.2172	.2328	.1949	.2328		.2303	.2126
13	.197	.2328	.2126	.1949	.2658	.2126	.1791
14	.1791	.197	.1772	.1595		.2126	.1595
15	.197	.2149	.1772	.1772	.2658	.2126	.1595
16	.2328	.2658	.1595	.1772		.2658	.2126
17	.2126	.2126	.2126	.1595	.3012	.2303	.2303
18	.3012	.3189	.2835	.1772	.3898	.3544	.3366
19	.3224	.3012	.3544	.2126	.3721	.3544	.4075
20	.3403	.2835	.1094	.3189	.3366	.3544	.3898
21	.2658	.2658	.2835		.3012	.3012	.3012
22		.2303	.2303		.2126	.2481	.2507
23	.2328	.2303	.1595		.2303	.1949	.2303
24	.2328	.2328	.2481	.1949		.2481	.1772
Max	.3582	.4163	.3544	.3761	.3898	.3544	.4075
Min	.1791	.197	.1094	.1595	.2126	.1949	.1595
Avg	.2536	.2645	.2460	.2374	.2973	.2697	.2601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244135 / 33/11 KV BHALAWANI S/STN.

Feeder No / Name : 202 / 11 KV Dhawaleshawar AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0633	.8642	.8592	.8124		.0781	.0633
2	.0633	.7907	.8223	.703		.0937	.0633
3	.0474	.759	.7655	.6405		.0781	.0633
4	.0949	.7042	.7186	.578		.0625	.0633
5	.0474	.7042	.6718	.5247		.0781	.0633
6	.0474	.0949	.0937	.0926		.0937	.0791
7	.0633	.1265	.1094	.1389		.0781	.1265
8	.0791	.128	.125	.108		.0937	.0949
9	.0949	.112	.125	.1235		.1094	.0791
10	.0324	.125	.1235	.679		.9842	1.2651
11	.0343	.0937	.1389	1.25		1.531	1.5181
12	.0343	.1094	.0926	1.5123		1.7185	1.5623
13	.0343	.0781	.0926	1.6512	.9686	1.6091	1.5935
14	.0514	.0937	.0926	1.6248		1.5779	
15	.0514	.0937	.108	1.6248	1.3279	1.5813	
16	.0358	.125	.108	1.5935		1.5339	1.7869
17	.1372	.1406	1.6484	1.4373	1.1873	1.2967	1.7711
18	.1715	.125	.144	.0949	.1094	.0949	.1265
19	.1423	.1094	.176	.112	.0937	.0949	.1107
20	.1265	.125	.1094	.1107	.1094	.0949	.112
21	.1107	.1094	.1094		.0937	.0791	.096
22		1.0623	.7968		.0781	.0633	.08
23	.9922	.9842	.8124		.0781	.0633	.08
24	.0474	.9282		.8124		.0625	.0633
Max	.9922	1.0623	1.6484	1.6512	1.3279	1.7185	1.7869
Min	.0324	.0781	.0926	.0926	.0781	.0625	.0633
Avg	.1132	.3578	.3845	.7726	.4496	.5480	.4937

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244135 / 33/11 KV BHALAWANI S/STN.

Feeder No / Name : 203 / 11 KV Shelakbav AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4883	.1265	.144	.128		1.6804	1.5043
2	1.4563	.112	.128	.128		1.6164	1.5043
3		.112	.144	.128		1.5364	1.4403
4	1.3603	.128	.128	.128		1.4563	1.4083
5	.096	.1581	.144	.128		1.3923	1.3763
6	.128	.0316	.128	.176		.16	.192
7	.16	.2056	.128	.192		.192	.192
8	.176	.2056	.112	.2241		.2241	.2241
9	.16	.2056	.2241	.2401		.2241	.3041
10		1.7124	1.8884	.2241		.2241	.2321
11	1.9845	1.9204	2.1445	.16		.2241	.1423
12	2.0805	1.9685	2.1285	.176		.2241	.1265
13	2.0805	2.0325	2.1125	.176	.192	.2401	.1265
14	2.0965	1.9685	2.1445	.192		.2401	.1265
15	1.2003	2.0805	1.9845	.192	.2401	.2241	.112
16	1.1683	1.1843	1.8724	.176		.2401	.192
17	1.7924	1.2163		.16	.2881	.2241	.2721
18	.144	.176	.144	.1739	.2881	.2721	.2881
19	.144	.16		.1898	.2721	.2401	.208
20	.16	.176	.16	.1898	.2401	.2241	.1898
21	.16	.16	.16		.208	.192	.1739
22	.16	.128	.128		1.9204	1.6964	1.3599
23	.1265	.144	.128		1.8404	1.6484	1.2967
24	1.5203	.1265	.128	.128		1.7604	1.5364
Max	2.0965	2.0805	2.1445	.2401	1.9204	1.7604	1.5364
Min	.096	.0316	.112	.128	.192	.16	.112
Avg	.9019	.6850	.7456	.1719	.6099	.6815	.6054