

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 201 / 11 KV SIDHANATH AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-SEP-17
HR	Load (MW)
1	.3208
2	.3262
3	.3346
4	.3612
5	.4054
6	.5456
7	.2919
8	.4976
9	.6897
10	.7278
11	.7865
12	.7758
13	.788
14	.6424
15	.458
16	.144
17	.1257
18	.1547
19	.1981
20	.2119
21	.1829
22	.1776
23	.1585
24	.1578
Max	.788
Min	.1257
Avg	.3943

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 202 / 11 KV DARIKONUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-SEP-17
HR	Load (MW)
1	.1349
2	.1364
3	.1387
4	.1478
5	.1593
6	.2134
7	.2317
8	.202
9	.1349
10	.1006
11	.0754
12	.0168
13	.0267
14	.0221
15	.0724
16	.0831
17	.0488
18	.1067
19	.205
20	.2126
21	.1791
22	.1433
23	.1509
24	.141
Max	.2317
Min	.0168
Avg	.1285

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 203 / 11 KV SHEDYAL GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-SEP-17
HR	Load (MW)
1	.0434
2	.0408
3	.04
4	.04
5	.0499
6	.0876
7	.1063
8	.0964
9	.0751
10	.0575
11	.0438
12	.045
13	.0511
14	.0221
15	.0069
16	.0522
17	.0514
18	.0625
19	.1101
20	.1124
21	.1067
22	.0808
23	.0613
24	.0446
Max	.1124
Min	.0069
Avg	.0620

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 204 / 11 KV SHEDYAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-SEP-17
HR	Load (MW)
1	.1326
2	.1364
3	.1364
4	.1456
5	.1753
6	.2408
7	.2622
8	.2241
9	.1463
10	.1135
11	.08
12	.0137
13	.0472
15	.0023
17	.0008
18	.1135
19	.1867
20	.2065
21	.1997
22	.176
23	.317
24	.2873
Max	.317
Min	.0008
Avg	.1520

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 208 / 11 KV MUCHANDI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-SEP-17
HR	Load (MW)
1	.1524
2	.1578
3	.1616
4	.1997
5	.2393
6	.2904
7	.3277
8	.2926
9	.2187
10	.1616
11	.1334
12	.1212
13	.1326
14	.1067
15	.1029
16	.1181
17	.1067
18	.1357
19	.2393
20	.2591
21	.2301
22	.2225
23	.4816
24	.4115
Max	.4816
Min	.1029
Avg	.2085

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 202 / 11 KV GHOLESHWAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-SEP-17
HR	Load (MW)
1	.1692
2	.1699
3	.1821
4	.2058
5	.3102
6	.5091
7	.5921
8	.3452
9	.25
10	.1562
11	.1311
12	.1181
13	.1105
14	.1105
15	.1273
16	.1196
17	.1341
18	.1738
19	.3757
20	.4001
21	.3262
22	.266
23	.2995
24	.2728
Max	.5921
Min	.1105
Avg	.2440

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 201 / 11 KV KANKESHWAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	.2378	.1997	.1974			
2		.2301	.1623	.1875			
3	***	.2279	.1585	.1859			
4	***	.2263	.1608	.1936			
5		.2256	.1638	.1882			
6	***	.2675	.1707	.1905	.0023		
7	***	.2736	.1707	.2233	.0061	.0061	.0335
8	.0854	.0564	.013	.1951	.2111	.208	.1981
9	***	.0008		.2408	.2035	.2347	.2248
10	***			.2949	.2507	.3528	.2568
11			.0038	.2431	.3254	.3795	.2522
12	***			.3384	.3544	.3841	.2934
13	***			.4031		.4024	.3315
14				.362		.3681	.3475
15	***	.0579	.1311	.349		.2545	.349
16	***	.0838		.2759	.2439	.2286	.2591
17		.0023			.0023		.0008
18	***						
19			.0053		.0152	.0046	.0061
20	.0732	.0373	.0617	.0815	.0754	.0259	.0008
21	.0572	.0754	.0084	.0793	.0709	.0442	.0023
22	.0602	.0594		.0206	.0373	.0236	.0023
23	.2728	.0213	.208				
24	.2591	.1829	.1974				
Max	49.9429	.2736	.208	.4031	.3544	.4024	.349
Min	.0572	.0008	.0038	.0206	.0023	.0046	.0008
Avg	33.3402	.1333	.1210	.2237	.1383	.2084	.1705

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 203 / 11 KV MAHAVEER AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1082				.0983		
2	.1067				.0914		
3	.1097				.0907		
4	.1097				.0922		
5	.1105				.0922		
6	.1082				.0991		
7	.1021				.0991	.0541	.0335
8	.0671	.0541	.0732				
9	.0785	.0777	.1014				
10	.0793	.1067	.1029				
11	.0648	.1456	.1052				
12	.0663	.1555	.0892				
13	.0861	.109	.1105				
14	.0739	.1044	.1166				
15	.0594	.0998	.1219				
16	.0061	.0953	.1494				
23				.08	.061		.0724
24				.1014	.0815		.0831
Max	.1105	.1555	.1494	.1014	.0991	.0541	.0831
Min	.0061	.0541	.0732	.08	.061	.0541	.0335
Avg	.0835	.1053	.1078	.0907	.0895	.0541	.063



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 203 / 11 KV Subhashnagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2583	.266	.3033	.2766	.3368	.3185	.3643
2	.2492	.2599	.2942	.2713	.3208	.3033	.3445
3	.25	.2599	.2957	.2683	.3155	.298	.3269
4	.2492	.2644	.2987	.2743	.3132	.2972	.3201
5	.2766	.2774	.3155	.2964	.3368	.3178	.3544
6	.4207	.3932	.3795	.4024	.4527	.4252	.4679
7	.487	.4641	.4595	.5182	.5129	.4862	.5213
8	.474	.4755	.4832	.4862	.4999	.4588	.49
9	.4351	.4885	.471	.4603	.4679	.4641	.4862
10	.4527	.4351	.5266	.4412	.4214	.4519	.49
11	.4344	.3986	.5357	.4077	.4237	.5121	.5357
12	.4245	.4115	.4809	.4428	.3978	.4717	.5007
13	.4184	.4252	.4733	.4268	.3978	.4588	.4687
14	.3498	.3894	.3841	.426	.3635	.4733	.4138
15	.3178	.4077	.4245	.4207	.3551	.4832	.4245
16	.3406	.4153	.4512	.4306	.3467	.4862	.4146
17	.4085	.4496	.5594	.4451	.3513	.5335	.4458
18	.4618	.4969	.5944	.5624	.4161	.711	.6394
19	.644	.6965	.6478	.7514	.602	.7575	.5624
20	.6508	.6859	.615	.7202	.6059	.7148	.6219
21	.586	.6249	.5952	.6729	.6158	.6653	.6287
22	.535	.5556	.5251	.586	.5738	.5959	.5373
23	.4344	.4702	.4115	.5129	.4763	.5098	.4161
24	.314	.3399	.3056	.378	.3582	.4085	.3262
Max	.6508	.6965	.6478	.7514	.6158	.7575	.6394
Min	.2492	.2599	.2942	.2683	.3132	.2972	.3201
Avg	.4114	.4313	.4513	.4533	.4276	.4834	.4626

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076] BU 1244

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 207 / Malgaon Ag Spare-1  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4237	.1844	.1997	.192	.2065	.5464	.6028
2	.4138	.1806	.192	.1867	.2012	.5037	.5746
3	.4024	.1768	.192	.1829	.1974	.5037	.5655
4	.4191	.1882	.2027	.1943	.2065	.503	.5479
5	.4527	.208	.2126	.2073	.2164	.4999	.5708
6	.5228	.2743	.2827	.2827	.2721	.724	.7301
7	.6531	.3696	.333	.3483	.3467	.9846	1.054
8	.6264	.612	.6562	.6036	.3917	.3422	.3315
9	.9122	.9556	.8871	.7324	.3254	.3079	.2904
10	1.1835	1.2902	1.0898	.9755	.2919	.2873	.2538
11	1.2254	1.3329	1.1606	.9663	.2614	.2804	.2698
12	1.2323	1.2048	1.1218	.948	.2583	.2683	.2141
13	.8352	1.1751	.9275	.9206	.2294	.2431	.218
14	.9435	1.1706	.7979	.8627	.2324	.2522	.2141
15	.8939	1.0753	.7735	.9198	.2164	.2797	.2119
16	.8375	1.1347	.8139	.9183	.2172	.2751	.1943
17	.1692	.2119	.1951	.1799	.144	.2721	.16
18	.2073	.2385	.2294	.2187	.1654	.2583	.0953
19	.2492	.2698	.2568	.25	.2789	.3056	.2942
20	.3117	.3246	.2736	.3056	.3414	.314	.2393
21	.2957	.3155	.285	.2972	.3262	.2957	.2332
22	.2888	.2987	.2812	.2865	.3094	.3025	.2439
23	.2561	.2644	.25	.2599	.7674	.8124	.4344
24	.2012	.2187	.205	.2286	.6767	.7842	.3986
Max	1.2323	1.3329	1.1606	.9755	.7674	.9846	1.054
Min	.1692	.1768	.192	.1799	.144	.2431	.0953
Avg	.5815	.5698	.4925	.4778	.2950	.4228	.3726

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 201 / 11 KV PED AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5685	.1699	.16	.1425	.5563	.6142	.1014
2	.5525	.1699	.1578	.1433	.5754	.5723	.1021
3	.5342	.1692	.1547	.1471	.5784	.5617	.0983
4	.5312	.1722	.1578	.1478	.5792	.5418	.0953
5	.5479	.1997	.173	.1631	.6234	.5959	.1219
6	.7461	.3003	.2576	.2545	1.0151	1.3176	.2469
7	.4717	.4512	.4611	.397	.4268	.4618	.2743
8	.9717	1.2003	1.1065	.3567	.3612	.3544	.25
9	1.0799	1.4266	1.185	.2301	.2309	.2225	.1699
10	1.1187	1.5432	1.1957	.1433	.1524	.1501	.1143
11	1.1119	1.6331	1.2209	.1097		.1143	.109
12	.7842	1.6842	1.2894	.1181		.1105	.144
13	1.1195	1.6941	1.4053	.1181	.1288	.1059	.1501
14	1.4815	1.7177	1.5379	.1204	.1181	.1029	.1448
15	1.5417	1.7086	1.5348	.1128	.1303	.0975	.1257
16	.1242	.1372	.1425	.1189	.1204	.1021	.2042
17	.1425	.1364	.1395	.1349	.1181	.0854	1.0486
18	.1799	.1501	.1829	.1478	.1623	.1578	.9381
19	.2599	.2362	.2119	.2462	.2309	.2157	.2454
20	.2728	.2462	.2119	.253	.2347	.2256	.2416
21	.2591	.2294	.2164	.2301	.2241	.1936	.2362
22	.2309	.2065	.1974	.1981	.3361	.1745	.2103
23	.1882	.1638	.1562	.9221	1.0075	.1616	.5556
24	.1722	.1547	.1456	.6142	.6417	.1006	
Max	1.5417	1.7177	1.5379	.9221	1.0151	1.3176	1.0486
Min	.1242	.1364	.1395	.1097	.1181	.0854	.0953
Avg	.6246	.6625	.5667	.2321	.3887	.3058	.2577

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 202 / 11 KV HATNUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0793	.4725	.3978				.0069
2	.0785	.4786	.4031				.0008
3	.0815	.4694	.4062				
4	.0884	.4923	.4275				
5	.1044	.5175	.4603				
6	.1509	.5891	.5373				
7	.1989	.1837	.1783			.5716	
8	.1776	.1379	.157		.0465	.7811	
9	.1341	.1181	.125		.3429	.8352	
10	.1097	.1052	.1029		.6051	.8528	.061
11	.0953	.0953	.093	.1638		.8909	.4298
12	.0846	.1105	.0968	.1959		.8695	.7849
13	.0968	.1014	.0884	.3422	.8551	.8451	.7339
14	.0991	.0975	.096	.4047	1.0052	.9198	.6539
15	.0488	.0884	.1181	.333	.9976	.9084	.7057
16	.0221	.0846	.1044	.0899	.0998	.0861	.0975
17	.0099	.0777	.1044	.5586	.1387		.0998
18	.1196	.1128	.1242	.679	.1326		.128
19	.144	.1395		.1623	.1501	.1273	.1448
20	.1395	.1387		.1349	.1494	.1227	.1486
21	.1318	.1334		.1257		.1196	.1364
22	.4755	.4611		.1151		.1075	.1311
23	.5617	.5479		.0968		.0823	.0998
24	.487	.4291		.0892		.0015	.0922
Max	.5617	.5891	.5373	.679	1.0052	.9198	.7849
Min	.0099	.0777	.0884	.0892	.0465	.0015	.0008
Avg	.1550	.2576	.2234	.2494	.4112	.5076	.2621

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 206 / 11 KV PED GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0553	.0568	.0613	.0575	.0671	.0713	.0713
2	.0537	.056	.0613	.0575	.0663	.0693	.0693
3	.053	.056	.0617	.0594	.0663	.0663	.069
4	.0579	.0591	.0621	.0648	.0697	.0697	.0739
5	.0831	.0838	.0793	.0945	.1017	.1017	.1044
6	.1692	.1741	.1638	.1718	.1787	.1787	.1802
7	.1901	.1894	.1985	.197	.1924	.1924	.1974
8	.1467	.1532	.1749	.1437	.1738	.1738	.1638
9	.1135	.1071	.1219	.1158	.1105	.1105	.1196
10	.0808	.085	.1025	.1014	.0827	.0827	.0968
11	.0629	.0659	.0796	.0815			.0842
12	.0594	.0709	.0633	.0697			.0815
13	.0518	.0549	.0659	.0674	.0895	.0895	.0808
14	.0488	.0503	.0598	.0648	.0724	.0724	.0697
15	.0461	.0533	.0674	.0598	.0735	.0735	.0594
16	.0556	.0602	.0686	.064	.072	.072	.0598
17	.0709	.0873	.0834	.0754	.0804	.0804	.1132
18	.144	.1208	.1082	.1174	.1284	.1284	.1402
19	.1646	.1539	.1322	.1574	.1703	.1703	.1574
20	.1482	.1452	.1212	.1467	.1482	.1482	.1463
21	.1376	.117	.1116	.1296	.1235	.1235	.1311
22	.0998	.0941	.0922	.1155	.1116	.1116	.1075
23	.0713	.0735	.0678	.088	.0884	.0884	.0781
24	.0598	.0648	.0594	.0697	.0739	.0739	.0678
Max	.1901	.1894	.1985	.197	.1924	.1924	.1974
Min	.0461	.0503	.0594	.0575	.0663	.0663	.0594
Avg	.0927	.0930	.0945	.0988	.1064	.1068	.1051

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 201 / 11 KV PANMALEWADI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-SEP-17	23-SEP-17	24-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1212	.7689	.7979
2	.1181	.7606	.7834
3	.1174	.7499	.772
4	.1288	.7522	.7278
5	.1257	.7773	.7537
6	.173	.8451	.8589
7	.1898	.2073	.1989
8	.1677	.1768	.1875
9	.1623	.1776	.1669
10	.1578	.1859	.1677
11	.173	.1806	.192
12	.1981	.2042	.2073
13	.1966	.2103	.2088
14	.1783	.1875	.1898
15	.1547	.2004	.1692
16	.1753	.234	.1578
17	.1821	.189	.1478
18	.1882	.2195	.1509
19	.1837	.1859	.1433
20	.1837	.173	.1478
21	.1814	.1791	.1654
22	.3201	.3117	.2782
23	1.0745	1.0761	.7019
24	.8246	.8368	.6607
Max	1.0745	1.0761	.8589
Min	.1174	.173	.1433
Avg	.2365	.4079	.3723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 204 / 11 KV BORGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6051	.1235	.1532	.1395	.6554	.8863	.6348
2	.6028	.1242	.157	.1402	.6394	.8383	.6371
3	.602	.1273	.1555	.141	.6394	.8337	.6501
4	.5998	.1296	.1593	.1478	.6501	.8482	.647
5	.6485	.1699	.1844	.173	.6943	.9229	.7019
6	.695	.2385	.2309	.2538	.8368	1.0646	.9534
7	.4191	.4207	.3902	.2713	.2652	.3056	.5898
8	.823	1.2711	1.4982	.2492	.2271	.2362	.2416
9	1.0357	1.5867	1.4251	.2012	.1638	.1791	.157
10	1.2201	1.7673	1.4312	.173	.1349	.173	.1318
11	1.3291	1.8488	1.5089	.1425		.1646	.1318
12	1.3054	1.8877	1.5836	.157		.1684	.1181
13	1.2818	1.7817	1.5226	.1341	.1738	.1494	.1075
14	1.3847	1.8663	1.4304	.1235	.1715	.1578	.1181
15	1.3946	1.9265	1.3085	.1242	.1417	.157	.1006
16	.1166	.1425	.1212	.1379	.1417	.1471	.109
17	.1448	.1722	.1219	.1273	.1745	.144	.125
18	.1326	.2027	.1578	.1166	.1814	.16	.1532
19	.1768	.2202	.192	.1905	.2073	.1966	.1799
20	.2004	.205	.1875	.2035	.2187	.1844	.176
21	.1936	.192	.1791	.1821	.2042	.1745	.1699
22	.1707	.173	.1646	.3567	.2507	.2553	.2195
23	.1448	.157	.1555	1.0814	1.2483	.9328	.5258
24	.1296	.1509	.1417	.6958	.993	.6767	.4778
Max	1.3946	1.9265	1.5836	1.0814	1.2483	1.0646	.9534
Min	.1166	.1235	.1212	.1166	.1349	.144	.1006
Avg	.6399	.7036	.6067	.2360	.4097	.4149	.3357

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 206 / 11 KV PANMALEWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0579	.0587	.0709	.0629	.0747	.0766	.0754
2	.0575	.061	.0701	.0613	.0735	.0758	.0739
3	.0583	.0579	.0693	.0633	.0735	.0754	.0697
4	.0621	.0598	.0754	.0674	.0735	.0739	.0716
5	.0846	.0758	.0838	.0808	.0854	.0922	.0842
6	.1299	.1238	.1231	.1135	.1231	.1315	.1288
7	.1429	.1459	.1417	.1387	.1421	.1417	.1444
8	.1368	.1162	.1368	.1223	.133	.1254	.1227
9	.0941	.0743	.0953	.0861	.1029	.0914	.1143
10	.0854	.0629	.0876	.0644	.0892	.0815	.0884
11	.0705	.0617	.0697	.0591		.0774	.0815
12	.061	.0579	.072	.0248		.0659	.0888
13	.0636	.0598	.0766	.0781	.0937	.0674	.0789
14	.0648	.0629	.0796	.0713	.0914	.0697	.0812
15	.0697	.0667	.0785	.0785	.0834	.0701	.0789
16	.064	.0693	.0762	.0781	.0697	.0701	.0899
17	.0633	.08	.0724	.0709	.0739	.0876	.0713
18	.0831	.1033	.1299	.0876	.101	.1357	.1029
19	.1642	.1536	.141	.1802	.1627	.1928	.1936
20	.1692	.1654	.1421	.1825	.1703	.1779	.1886
21	.1467	.1417	.1261	.1665	.1482	.1555	.1658
22	.1208	.12	.1059	.1368	.1326	.1276	.1254
23	.0884	.0888	.0789	.1052	.1116	.1006	.0995
24	.0625	.0747	.0663	.0796	.0819	.0785	.0789
Max	.1692	.1654	.1421	.1825	.1703	.1928	.1936
Min	.0575	.0579	.0663	.0248	.0697	.0659	.0697
Avg	.0917	.0893	.0946	.0942	.1042	.1018	.1041



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077] BU 1261

Substation No/ Name :- 244108 / 33/11 KV Koulage

Feeder No / Name : 203 / 11KV ARAWADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-SEP-17	23-SEP-17
HR	Load (MW)	Load (MW)
1		.381
2		.381
3		.381
4	.0762	.381
5	.0762	.381
6	.1524	.4572
7	.1524	.1524
8	.1524	.1524
9	.0762	.1524
10	.0762	.0762
11	.0762	.0762
12	.0762	.0762
13	.0762	.0762
14		.0762
15		.0762
16		.0762
17		.0762
18	.0762	
19	.0762	
20	.0762	
21	.0762	
22	.2286	
23	.5335	
24	.4572	
Max	.5335	.4572
Min	.0762	.0762
Avg	.1479	.2017

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 208 / 11 KV MATKUNKI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4725	.503	.2972			
2		.4191	.503	.2972			
3		.381	.4954	.282			
4		.3734	.4877	.2743			
5		.3658	.4725	.282			
6		.4649	.6173	.2896			
7	.1677	.5106	.7392	.2667	.1753	.1677	.1753
8	.1753	.1981	.1905	.3887	.4496	.442	.4572
9	.1143	.1753	.1677	.4725	.5335	.503	.5716
10	.0152	.1067	.0533	.5258	.7011	.7468	.6859
11		.0229		.6173	.7697	.8612	.7545
12		.0229	.0457	.6401	.724	1.0136	.7697
13		.0533	.0762	.6173	.7164	1.0288	.8002
14			.0457	.602	.7316	1.0136	.823
15		.0229		.6173	.5335	1.0059	.9069
16	.0381			.6401	.3277	.8307	.8535
17	.1448	.0152			.0152		
18		.1448	.0229	.0229	.0305		.0152
19	.1829	.061	.16	.0381	.0305		.1296
20	.1829	.1524	.1677	.1753	.1524	.1219	.1677
21	.1677	.0533	.1677	.1677	.1219	.061	.1753
22	.1677	.0914	.16	.1677	.1372	.0686	.1677
23	.5944	.7011	.3506	.16	.0686		
24	.5716	.7011	.3277				
Max	.5944	.7011	.7392	.6401	.7697	1.0288	.9069
Min	.0152	.0152	.0229	.0229	.0152	.061	.0152
Avg	.2102	.2504	.2877	.3564	.3658	.6050	.4969

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078] BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 205 / 11 KV ANKALKHOP AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1151	.1349	.1006			
2		.1143	.1334	.1006			
3		.1097	.1311	.1014			
4		.1082	.1349	.1021			.0008
5		.1082	.1372	.1014			
6		.1151	.1501	.1036			
7		.1478	.1738	.1143	.0046	.0076	
8	.0579	.0282	.0389	.1128	.0671	.1318	.1052
9			.0114	.1585	.1501	.1989	.1943
10				.1738	.2088	.221	.1677
11				.2073	.2378	.2759	.1966
12				.2347	.2378	.3018	.1745
13				.1997	.2439	.3201	.2385
14				.1524	.2195	.2888	.2202
15				.1791	.208	.2599	.173
16				.1593	.2195	.2675	.1837
17						.0008	
18							.0015
20							.0053
21							.0038
22	.0008						.0008
23	.1532	.1364	.0693				
24	.1402	.1715	.0998				
Max	.1532	.1715	.1738	.2347	.2439	.3201	.2385
Min	.0008	.0282	.0114	.1006	.0046	.0008	.0008
Avg	.0880	.1155	.1104	.1439	.1797	.2067	.1190

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 201 / 11 KV YELAVI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1753	.144				
2		.1707	.1471				
3		.1684	.1501				
4		.1608	.1509				
5	.0671	.1974	.1783		.0396	.077	.0389
6	.1204	.2667	.2583		.1181	.1174	.109
7	.1524	.1402	.1288		.1593	.1448	.1486
8	.1341	.1196	.1311		.2515	.2393	.2446
9	.109	.1036	.0823		.3064	.285	.301
10	.0968	.1158	.0953		.3673	.3688	.3056
11	.0861	.1014	.1036	.0297	.3749	.3803	.3239
12	.0899	.0366	.1006	.3536	.3574	.3986	.3292
13	.0754	.0701	.0183	.3871	.3262	.3704	.3193
14	.0412	.093	.0099	.394	.3064	.3376	.3003
15	.08	.0953	.0091	.3323	.3064	.2911	.285
16	.0648	.0495			.0069		
17	.0236	.064	.0053	.0008	.003	.0008	
18	.0846	.0465	.0419	.0305	.0602	.013	.0267
19	.1014	.1014	.0846	.0892	.0975	.0884	.0914
20	.1021	.1021	.0876	.096	.1036	.0914	
21	.096	.0983	.0869	.096	.0998	.0876	
22	.1196	.1105	.0739	.0922	.093	.0823	
23	.2141	.2256		.0076	.0282		
24	.1753	.1699					
Max	.2141	.2667	.2583	.394	.3749	.3986	.3292
Min	.0236	.0366	.0053	.0008	.003	.0008	.0267
Avg	.1017	.1243	.0994	.1591	.1792	.1985	.2172

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 203 / 11 KV Yelavi Bu'wadi

GAOTHAN FEEDER

Gaonthan Feeder KV- 11 /  
OUTGOING

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3079	.314	.3506	.301	.3643	.3711	.3605
2	.2987	.3018	.3414	.3003	.3528	.3681	.3483
3	.2942	.3033	.3391	.2987	.3567	.3719	.3483
4	.3277	.3307	.362	.3109	.3803	.394	.3765
5	.4466	.4336	.4306	.4153	.4786	.4938	.5091
6	.6584	.6356	.6356	.6112	.6676	.6813	.6904
7	.7369	.7316	.7362	.6874	.7316	.7651	.7644
8	.6645	.6325	.6783	.6234	.5898	.6371	.6341
9	.4565	.426	.5068	.4344	.4207	.4329	.4565
10	.3384	.33	.3894	.349	.3368	.3528	.3765
11	.3201	.3025	.3269	.3353	.2644	.3025	.2995
12	.2843	.2919	.3163	.3368	.2957	.3071	.3079
13	.2713	.2934	.3254	.3071	.2949	.3079	.2942
14	.2454	.2995	.3117	.301	.3064	.2926	.298
15	.2256	.3071	.2995	.3109	.3003	.3102	.2949
16	.2393	.2957	.1806	.3125	.2812	.2964	.2942
17	.269	.2919	.3993	.3239	.3125	.3361	.3536
18	.3597	.3704	.522	.4496	.4626	.4298	.4054
19	.6066	.6539	.5601	.6943	.6584	.6462	.679
20	.6516	.7118	.567	.7331	.6683	.6661	.2583
21	.5807	.6028	.5396	.6478	.6341	.6081	
22	.5266	.5662	.503	.5822	.5898	.5556	.4771
23	.4291	.4603	.3879	.4733	.4862	.455	.4291
24	.3399	.3719	.3208	.3932	.4016	.3757	.0975
Max	.7369	.7316	.7362	.7331	.7316	.7651	.7644
Min	.2256	.2919	.1806	.2987	.2644	.2926	.0975
Avg	.4116	.4274	.4304	.4389	.4432	.4482	.4067

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 204 / 11 KV Burungwadi

Industrial Feeder KV- 11 /  
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3467	.3445	.3102	.2789	.314	.3605	.2728
2	.317	.3353	.2934	.2774	.3277	.3437	.2782
3	.301	.3155	.282	.2789	.3086	.3185	.2507
4	.349	.3163	.3338	.3064	.3498	.3155	.2583
5	.3658	.3498	.3102	.3361	.365	.3688	.2987
6	.3528	.3246	.282	.3346	.3414	.3338	.2804
7	.3879	.3666	.3269	.3467	.378	.3666	.3185
8	.4199	.3795	.3856	.3887	.3948	.4367	.3307
9	.4946	.4862	.5799	.5403	.3818	.8116	.2774
10	.5914	.5517	.6485	.4748	.3879	.849	.3285
11	.5777	.5647	.6516	.458	.3757	.8665	.3574
12	.5693	.6196	.6501	.4199	.3765	.7461	.4923
13	.5472	.5898	.6005	.3826	.3635	.7209	.2553
14	.6394	.8878	.644	.4283	.3521	.8375	.6874
15	.6653	.836	.788	.458	.3513	.8756	.8436
16	.6645	.631	.5716	.4481	.3711	.8665	.8352
17	.586	.583	.3414	.4527	.3704	.455	.9084
18	.5388	.5517	.2942	.4428	.4153	.439	.6074
19	.5639	.5601	.3262	.5083	.4367	.2873	.2065
20	.4047	.4275	.3285	.4839	.407	.3772	
21	.4146	.442	.2926	.426	.4092	.3887	.0953
22	.4245	.4245	.2911	.4199	.4138	.4047	.2058
23	.3102	.3719	.3071	.3521	.3788	.3025	.2583
24	.3239	.3117	.2766	.3239	.3582	.2858	.2759
Max	.6653	.8878	.788	.5403	.4367	.8756	.9084
Min	.301	.3117	.2766	.2774	.3086	.2858	.0953
Avg	.4648	.4821	.4215	.3986	.3720	.5149	.3880

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 205 / 11Kv Express Feeder

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4944	1.5737	1.592	1.4579	1.5181	1.5524	1.4076
2	1.4761	1.563	1.5661	1.4144	1.4944	1.5745	1.3626
3	1.4457	1.5097	1.4952	1.3847	1.4068	1.5623	1.3336
4	1.4685	1.499	1.4243	1.3306	1.3672	1.4487	1.3535
5	1.4739	1.5013	1.3717	1.3649	1.4098	1.3954	1.342
6	1.5699	1.5943	1.4495	1.4937	1.5592	1.6057	1.4815
7	1.5935	1.5325	1.5249	1.4624	1.72	1.6354	1.3984
8	1.6758	1.6979	1.6042	1.5524	1.8656	1.7353	1.5889
9	1.7116	1.6621	1.6408	1.5638	1.8107	1.8618	1.608
10	1.3382	1.2841	1.1378	1.1972	1.2711	1.4464	1.0387
11	1.1622	1.358	1.4586	1.3832	1.3481	1.422	1.4015
12	1.2955	1.4502	1.4922	1.5097	1.5059	1.5379	1.4266
13	1.5981	1.8663	1.454	1.6751	1.6042	1.8496	1.4822
14	1.4853	1.8976	1.6735	1.7314	1.7528	1.8526	1.7543
15	1.7894	2.0157	1.8976	1.9517	1.832	1.9364	1.816
16	1.7665	1.9646	1.7604	1.8671	1.6842	1.733	1.8488
17	1.7993	1.9791	1.7398	1.8084	1.7444	1.6354	1.8679
18	1.7909	1.9532	1.7322	1.7947	1.7307	.8093	1.8564
19	1.2506	1.371	.5952	1.4731	1.496	1.294	1.5379
20	1.1378	1.2993	1.044	1.3542	1.4373	1.3474	.9473
21	.9945	1.2833	1.1584	1.2582	1.3314	1.278	.1014
22	1.0288	1.3283	1.2247	1.3992	1.342	1.2879	.1097
23	1.5966	1.7497	1.2765	1.7596	1.627	1.5264	.6219
24	1.5409	1.6347	1.3535	1.6339	1.5143	1.4251	.9183
Max	1.7993	2.0157	1.8976	1.9517	1.8656	1.9364	1.8679
Min	.9945	1.2833	.5952	1.1972	1.2711	.8093	.1014
Avg	1.4785	1.6070	1.4445	1.5342	1.5572	1.5314	1.3169

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 206 / Yelavi Ag -2

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.157	.381	.3231	.2759	.173	.1814	.1806
2	.1547	.3666	.3064	.2782	.1692	.1776	.1791
3	.1555	.3696	.3003	.282	.1745	.176	.173
4	.1631	.3818	.317	.2957	.1783	.1837	.1799
5	.1997	.4367	.3551	.3216	.2088	.2119	.2241
6	.2919	.7217	.6005	.4504	.2972	.2995	.2987
7	.3757	.397	.3856	.3795	.3978	.3711	.3902
8	.3544	.3437	.3612	.5464	.5022	.5007	.4885
9	.2477	.2492	.2614	.5426	.5434	.6302	.5441
10	.202	.234	.2317	.6272	.599	.6645	.5609
11	.1456	.1829	.1532	.724	.5982	.679	.5304
12	.1471	.1776	.1638	.5784	.5022	.6562	.5677
13	.1372	.1707	.144	.5799	.5335	.6843	.6188
14	.1326	.1646	.1471	.5464	.5266	.7064	.6569
15	.1349	.1699	.1273	.5159	.4915	.6706	.5815
16	.1334	.1753	.1425	.1699	.1486	.1402	.1669
17	.1524	.1677	.1867	.1616	.1623	.1486	.1684
18	.218	.1859	.2241	.205	.1997	.1959	.1928
19	.269	.282	.2606	.2683	.2561	.2591	.2736
20	.3025	.2873	.2751	.2942	.282	.2812	.1196
21	.2713	.2721	.2599	.2576	.2652	.2713	.0008
22	.2599	.2545	.2332	.2492	.2454	.2507	
23	.6859	.5975	.3658	.2119	.2088	.2149	
24	.4291	.3643	.2881	.1829	.1814	.1875	
Max	.6859	.7217	.6005	.724	.599	.7064	.6569
Min	.1326	.1646	.1273	.1616	.1486	.1402	.0008
Avg	.2384	.3056	.2672	.3727	.3269	.3643	.3379



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 201 / 11 KV VASAGADE GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0884	.096	.1135	.0983	.1135	.1189	.1097
2	.0876	.093	.1113	.0983	.1105	.1151	.1105
3	.0884	.0922	.1105	.0998	.109	.1143	
4	.0869	.0937	.1151	.0991	.109	.1158	.1395
5	.1166	.1174	.1196	.1227	.1486	.1326	.1326
6	.1768	.1623	.173	.1555	.1783	.1707	.1707
7	.1768	.1654	.1692	.1578	.1669	.1593	.1593
8	.144	.1318	.157	.1318	.1402	.1509	.1509
9	.1273	.1174	.141	.1128	.1166	.1166	.1166
10	.096	.0846	.1174	.0968	.1196	.1166	.1166
11	.0991	.1082	.1166	.096		.1273	.1273
12	.1006	.1135	.1181	.096		.1341	.1341
13	.1257	.1189	.1044	.0998	.1638	.1372	.1372
14	.1052	.1082	.109	.0975	.1532	.1395	.1395
15	.0914	.1036	.1059	.0983	.1593	.1364	.1364
16	.0907	.1128	.109	.1097	.1555	.1265	.1265
17	.1235	.1334	.1517	.1311	.1631	.1288	.1288
18	.1494	.1692	.1555	.1882	.1974	.1799	.1799
19	.1837	.2233	.1989	.2225	.2347	.2035	.2035
20	.1943	.2111	.1806	.2271	.2202	.2103	.2103
21	.1905	.1974	.176	.2157	.192	.1829	.1829
22	.1638	.1722	.1539	.1966	.1753	.1707	.1707
23	.1219	.157	.1189	.1631	.1486	.1395	.1395
24	.1029	.1265	.1052	.128	.1296	.1174	.1174
Max	.1943	.2233	.1989	.2271	.2347	.2103	.2103
Min	.0869	.0846	.1044	.096	.109	.1143	.1097
Avg	.1263	.1337	.1346	.1351	.1548	.1435	.1452

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 201 / 11 KV Tasgaon I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.6401	.7316	.7011	.7621	.7926	.7926
2	.6097	.6097	.7011	.6401	.7316	.7621	.7316
3	.6097	.5792	.6706	.6401	.7011	.7316	.7011
4	.6097	.5792	.6706	.6401	.7316	.7621	.7011
5	.6097	.6097	.7011	.6401	.7316	.7621	.7011
6	.7316	.7011	.7621	.7316	.8535	.8535	.823
7	.8535	.884	.9145	.884	1.0059	1.0059	.945
8	.8535	.823	.823	.8535	.945	.9145	.945
9	.8535	.7621	.8535	.8535	.8535	.7926	.8535
10	.7926	.7926	.884	.884	.823	.823	.823
11	.884	.8535	.9145	.945	.823	.945	.945
12	.884	.945	.9145	.9755	.823	1.0364	.945
13	.9145	.945	.8535	.945	.884	1.0059	.9755
14	.884	1.0059	.823	.884	.9145	.9755	.9145
15	.823	.9145	.823	.9145	.884		.945
16	.945	.9755	.884	1.0364	.945	.7011	1.0364
17	.884	.9755	.884	1.0059	.884	1.1584	1.0059
18	.9755	.9755	1.0059	1.0669	.945	.884	1.0974
19	1.1584	1.2193	1.1584	1.3108	1.1584	1.4022	1.3108
20	1.1888	1.2498	1.0364	1.3413	1.1888	1.3413	1.2803
21	1.0974	1.1584	1.0669	1.2803	1.1888	1.2193	1.1584
22	1.0059	1.0669	1.0364	1.0974	1.1279	1.2193	1.1279
23	.9145	1.0059	.945	1.0364	1.0669	1.0669	1.0364
24	.7621	.823	.823	.9145	.9145	.9145	.884
Max	1.1888	1.2498	1.1584	1.3413	1.1888	1.4022	1.3108
Min	.6097	.5792	.6706	.6401	.7011	.7011	.7011
Avg	.8535	.8789	.8700	.9259	.9119	.9596	.9450

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 202 / 11 KV Tasgaon II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-SEP-17	23-SEP-17
HR	Load (MW)	Load (MW)
1	.7011	.7011
2	.6706	.6706
3	.6706	.6706
4	.6706	.6706
5	.7011	.7011
6	.7926	.7926
7	1.0059	.9755
8	.9145	.884
9	.7926	.7926
10	.7316	.4877
11	.7621	.5182
12	.7316	.2743
13	.7011	.1829
14	.7011	
15	.7011	
16	.7011	
17	.7011	
18	.8535	
19	1.1584	
20	1.2498	
21	1.1279	
22	1.0059	
23	.9145	
24	.7926	
Max	1.2498	.9755
Min	.6706	.1829
Avg	.8230	.6401

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 203 / 11 KV WATER SUPPLY

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND

UTILITY

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2743	.2743	.4268	.3353	.6401	.6401
2	.2743	.2743	.2743	.4268	.3353	.6401	.6097
3	.3048	.3048	.3048	.4877	.3353	.6401	.6097
4	.3048	.3048	.3048	.4877	.3353	.6401	.5792
5	.3048	.3048	.3048	.4877	.3658	.6401	.6401
6	.3658	.3658	.3353	.5487	.3963	.7316	.6706
7	.3658	.3963	.3658	.5487	.3658	.7316	.7011
8	.4572	.4572	.4572	.5792	.3963	.7926	.7621
9	.4572	.4572	.4572	.5792	.4877	.7926	.7926
10	.3963	.4268	.3963	.5792	.4572	.7316	.7316
11	.3658	.3963	.3658	.6401	.3658	.7011	.7011
12	.2743	.2743	.1829	.6097	.2743	.6097	.5792
13	.1829	.1829	.1524	.6097	.1829	.4268	.5487
14	.2134	.2439	.1829	.5182	.1829	.2743	.4572
15	.3353	.3658	.2743	.3658	.3353	.2743	.6097
16	.3353	.4268	.4268		.3353	.4268	.6706
17	.4268	.3963	.4268		.3048	.4572	.6706
18	.4268	.3963	.4268		.3658	.4268	.6706
19	.3048	.3048	.2439		.4268	.3963	.5487
20	.2134	.2134		.3353	.2743	.4268	.3963
21	.2743	.3048		.4268	.3658	.3353	.3048
22	.3048	.3963		.4268	.5487	.3353	.6401
23	.3048	.3963	.3353	.4268	.5792	.2743	.6401
24	.2439	.2743	.4268	.3658	.5792	.5792	.6706
Max	.4572	.4572	.4572	.6401	.5792	.7926	.7926
Min	.1829	.1829	.1524	.3353	.1829	.2743	.3048
Avg	.3213	.3391	.3295	.4938	.3721	.5385	.6185

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 204 / 11KV NEW TASGAON

INDUSTRIAL FE Feeder KV- 11 /  
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219	.1067	.1029	.0876	.1029		.0914
2	.1181	.1029	.0953	.0876	.1029		.0876
3	.1181	.1029	.0953	.0914	.0991		.0876
4	.1181	.1029	.0953	.0876	.0991		.0838
5	.1219	.1029	.0876	.0876	.0953		.0838
6	.1219	.1029	.0838	.0876	.0991		.0457
7	.1181	.1067	.0838	.0876	.0991		.0381
8	.1219	.1105	.08	.0914	.0953		.08
9	.141	.1143	.1029	.0991	.1181	.0991	.1105
10	.1638	.1181	.1372	.1067	.1181	.0953	.1257
11	.1981	.1143	.2058	.1181	.1029	.141	.16
12	.1981	.1448	.2096	.1448	.1219	.1867	.2172
13	.1867	.1677	.2172	.1943	.1296	.221	.2324
14	.16	.1296	.1677	.1867	.1257	.1829	.202
15	.1791	.141	.1791	.221	.0991	.1943	.1981
16	.1867	.16	.1715	.2477	.1029	.1981	.2286
17	.202	.1372	.1829	.2248	.0991	.2058	.1562
18	.1981	.1524	.1677	.2362	.1029	.2172	.202
19	.1486	.16	.1219	.1524	.1105	.16	.1181
20	.1715	.1524	.1257	.1334	.0914	.1334	.1296
21	.1143	.1334	.1143	.1296	.0762	.1524	.1067
22	.1029	.1257	.1181	.141	.0724	.1067	.1029
23	.1067	.0914	.1029	.1334	.0229	.0914	.0838
24	.1105	.0953	.0914	.1334		.0953	.0838
Max	.202	.1677	.2172	.2477	.1296	.221	.2324
Min	.1029	.0914	.08	.0876	.0229	.0914	.0381
Avg	.1470	.124	.1308	.1380	.0994	.1550	.1273

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 202 / 11 KV KAVALAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0495	.0937	.1166	.0667	.1052	.0911	.1075
2	.0472	.0914	.1025	.0633	.0975	.0854	.0911
3	.0652	.0907	.1014	.0644	.0979	.0842	.0911
4	.0484	.0907	.0979	.0648	.0972	.072	.0819
5	.0476	.0892	.101	.0644	.0953	.0728	.0549
6	.0514	.1147		.0762	.1071	.0823	.0568
7	.0979	.1551		.12	.133	.1322	.096
8	.1029	.1456		.1257	.1475	.1456	.0934
9	.0793	.1246		.1227	.1334	.1181	.0888
10	.0629	.1063		.1052	.0846	.109	.0777
11	.0892	.0995	.1604	.0827	.0812	.0907	.085
12	.0876	.08		.0998	.0709	.1006	.1033
13	.0777	.0663		.0762	.0697	.1135	.1071
14	.0568	.0545	.1341	.0705	.0865	.1227	.077
15	.0465	.0568	.0918	.0682	.0865	.0743	.0968
16	.0461	.0728	.0758	.069	.0751	.0629	.0777
17	.0697	.0743	.0937	.069	.0732	.0522	.072
18	.0732	.0781	.1063	.0636	.08	.0869	.1014
19	.176	.1162	.1063	.1147	.1223	.1444	.1273
20	.1795	.1989	.1303	.1654	.165	.173	.125
21	.1631	.1734	.1208	.1551	.1696	.1688	.1246
22	.157	.1718	.1174	.1589	.1635	.1456	.1227
23	.1364	.152	.1063	.1513	.1402	.133	.1067
24	.1227	.1395	.0781	.1181	.1257	.1223	.0785
Max	.1795	.1989	.1604	.1654	.1696	.173	.1273
Min	.0461	.0545	.0758	.0633	.0697	.0522	.0549
Avg	.0889	.1098	.1083	.0973	.1087	.1077	.0935

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 205 / 11 KV Kavalapur Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.3487	.4519	.2557	.0956	.1566	.1532
2	.1482	.3266	.4401	.2522	.096	.1566	.1574
3	.1478	.3166	.4195	.2587	.0956	.165	.1536
4	.1471	.3266	.4241	.2595	.0953	.1745	.1425
5	.1612	.3555	.4325	.2698	.1105	.1612	.1478
6	.2039	.5818	.4191	.2999	.1368	.205	.2046
7	.2305	.2248	.2069	.2153	.181	.2694	.2492
8	.2294	.1993	.165	.3875	.2656	.4729	.3601
9	.1665	.1398	.1368	.474	.4782	.612	.4287
10	.1284	.1581	.1242	.4938	.5887	.6501	.4992
11	.1558	.1208	.1124	.5597	.6154	.719	.5548
12	.1482	.0617	.1036	.535	.5636	.6752	.5479
13	.1303	.1417	.1052	.5517	.5224	.6828	.5681
14	.0998	.1334	.1204	.5697	.5114	.7099	.5777
15	.1177	.1238	.0911	.4919	.5834	.7145	.6112
16	.1151	.1265	.0964	.0983	.1871	.112	.0926
17	.1086	.1097	.1402	.0873	.1501	.1075	.0983
18	.1284	.1212	.1387	.0922	.1505	.1139	.1189
19	.2	.205	.1627	.1753		.1848	.1673
20	.2008	.1863	.1677	.1863	.2229	.1966	.1658
21	.1939	.1833	.1597	.1486	.2134	.1837	.1707
22	.2218	.3418	.1844	.1189	.1981	.1783	.1619
23	.4797	.7506	.2728	.1113	.176	.1722	.1425
24	.3662	.4915	.2553	.0964	.16	.1562	.1421
Max	.4797	.7506	.4519	.5697	.6154	.719	.6112
Min	.0998	.0617	.0911	.0873	.0953	.1075	.0926
Avg	.1824	.2531	.2221	.2912	.2782	.3304	.2757

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 203 / 11 kv PWW Bramhnal

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1992	.1986	.2014	.1998	.1987	.1993	.2002
2	.199	.198	.1998	.1998	.1981	.199	.1997
3	.199	.1984	.1998	.1997	.1981	.1985	.1992
4	.1991	.1983	.1998	.1991	.1978	.199	
5	.1992	.1985	.1992	.1992	.1979	.1991	
6	.1994	.1984	.1999	.1993	.198	.1994	
7	.1998	.1995	.2006	.1999	.1997	.2004	
8	.1994	.2006	.2012	.2009	.2001	.1983	
9	.0187	.202	.2026	.2017	.2009	.1995	.2003
10		.2009	.0973	.1993		.1995	.1992
11		.1987	.0963	.201		.1985	.1969
12		.1005	.0979	.0358		.1746	.1969
13		.0436	.0975				.1951
14			.0014				.0043
15							.076
16						.0056	.1976
17							.1983
18			.038	.0472			.1993
19			.2019	.2			.156
20			.2011	.202			.2018
21	.202	.2029	.2002	.2005	.1506	.0938	
22	.1997	.2006	.1992	.1997	.2013	.2019	
23	.1994	.202	.2004	.2003	.1987	.2004	
24	.1999	.2029	.2004	.1999	.2	.2014	
Max	.202	.2029	.2026	.202	.2013	.2019	.2018
Min	.0187	.0436	.0014	.0358	.1506	.0056	.0043
Avg	.1857	.1850	.1636	.1834	.1954	.1805	.1747



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 201 / 11 kv Dudhgaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-SEP-17	23-SEP-17	24-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2						.0198
3						.0015
4						.0015
5						.0015
6						.0015
7				.016	.0008	.0023
8		.0008	.0526			.0114
9		.0282	.1082			
10	.0747	.0808	.1585			
11	.0953	.0861	.1417			
12	.1014	.141	.1951			.0168
13	.1021	.1433	.1974			.0053
14	.1014	.1417	.1623			.0023
15	.0998	.1456	.0892			
16	.1036	.1509	.0762			
17						.0099
18					.0099	.0023
19					.0008	.0015
21						.0069
22						.0084
23					.0015	
24					.0259	
Max	.1036	.1509	.1974	.016	.0259	.0198
Min	.0747	.0008	.0526	.016	.0008	.0015
Avg	.0969	.1020	.1312	.016	.0078	.0062

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 203 / 11 KV Kavathe Piran Ag      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0023	
7					.0412	
8			.109			
9		.0975	.1166			
10		.1097	.1143			
11	.061	.0983	.1265			
12	.1196	.1151	.1273			
13	.0587	.1052	.1257			
14		.1265	.1181			
15	.0008	.1227	.0975			
16		.1212	.0869			
23				.096	.0152	
24					.0434	.0282
Max	.1196	.1265	.1273	.096	.0434	.0282
Min	.0008	.0975	.0869	.096	.0023	.0282
Avg	.0600	.1120	.1135	.096	.0255	.0282

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 246001 / 110/33/11 KV VISHRAMBAG S/SN

Feeder No / Name : 404 / 33 KV MADHAVNAGAR(EHV)

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	17.1811	23.5598	16.2209	23.1481	9.0878	18.3814	16.3237
2	16.1866	22.0508	15.7407	22.4623	8.1276	17.9355	15.8093
3	15.8436	21.6392	15.5693	21.8451	7.8532	17.6269	15.4664
4	15.6722	21.6392	15.3293	20.8162	7.5789	17.5583	13.9232
5	16.0151	22.2565	15.7065	21.1249	7.2702	18.0042	15.3635
6	17.1811	24.2456	16.6324	23.1825	7.5789	19.6502	17.0782
7	18.5185	25.7888	17.0096	25.9603	7.476	22.9424	18.2785
8	19.3759	26.4061	17.5927	26.9547	7.5446	26.1317	18.7243
9	21.6392	***	18.8957	***	7.2702	29.664	18.2099
10	23.6969	***	20.5076	***	5.2469	***	18.5186
11	26.4403	***	21.022	***	5.144	***	19.3759
12	25.8917	***	20.4047	***	4.9726	***	19.2387
13	24.4856	***	18.0727	***	5.0069	***	18.3128
14	23.9712	***	17.5583	***	5.2126	***	17.8326
15	24.8629	***	18.1756	***	5.2126	***	17.9356
16	24.177	***	17.5583	***	4.1495	***	17.524
17	24.2798	***	17.3869	***	5.0755	***	17.3526
18	24.1427	***	18.8614	***	5.1097	***	17.9355
19	25.7202	***	19.6502	***	6.7558	***	20.9877
20	24.2113	***	19.5817	***	7.7846	***	19.4788
21	22.0165	***	18.2442	***	7.7846	***	19.8903
22	20.9534	***	18.7929	***	7.3731	***	19.5816
23	20.3361	29.1153	17.6613	29.9726	7.476	28.3266	16.6324
24	19.1015	26.749	15.7408	27.6063	7.2017	26.5776	15.1235
Max	26.4403	37.5172	21.022	36.4198	9.0878	37.2771	20.9877
Min	15.6722	21.6392	15.3293	20.8162	4.1495	17.5583	13.9232
Avg	21.3292	29.8140	17.8298	30.0769	6.6372	28.7695	17.7041

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 246001 / 110/33/11 KV VISHRAMBAG S/SN

Feeder No / Name : 405 / 33KV SANGLI CITY -NEW

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	28.9438	***	28.5323	***	28.5323	***	5.2126
2	27.8121	28.1207	26.4061	28.2579	26.6118	***	4.8354
3	26.9891	27.2292	25.583	27.8121	26.0631	***	4.6639
4	26.5776	26.8519	25.5144	27.7092	25.7202	29.2182	4.5953
5	27.2635	27.2977	25.5144	27.9836	25.7202	***	4.6296
6	***	***	27.1605	***	28.3951	***	5.0069
7	***	***	26.9548	***	29.2867	***	5.7956
8	***	***	27.7778	***	29.5611	***	6.7215
9	***	***	28.8752	***	29.4925	***	6.3786
10	***	***	***	***	29.081	***	5.8985
11	***	***	***	***	***	***	5.7956
12	***	***	***	***	***	***	5.7613
13	***	***	***	***	***	***	5.5899
14	***	***	29.0124	***	***	***	5.5899
15	***	***	29.5611	***	***	***	5.0755
16	***	***	28.4637	***	29.8354	***	5.0755
17	***	***	29.3553	***	28.3265	***	5.144
18	***	***	***	***	***	***	5.5556
19	***	***	***	***	***	***	7.4417
20	***	***	***	***	***	***	7.9561
21	***	***	***	***	***	***	7.4074
22	***	***	***	***	***	***	7.1331
23	***	***	***	***	***	***	6.5158
24	***	***	28.1893	***	***	***	5.5213
Max	52.4006	54.7669	40.1921	55.007	44.1702	54.4582	7.9561
Min	26.5776	26.8519	25.5144	27.7092	25.7202	29.2182	4.5953
Avg	36.4313	37.4186	30.5470	38.2174	31.5244	39.4319	5.8042

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 203 / 11 KV MALBANGLA WATER  
SUPPLY Feeder KV- 11 /  
OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4016	.4016	.3993	.3986	.3879	.4633	.5235
2	.4009	.4009	.3978	.394	.3871	.5243	.522
3	.3993	.3567	.3559	.362	.3528	.5251	.5205
4	.3559	.3567	.3559	.3605	.3513	.5251	.5197
5	.3559	.3574	.3544	.3605	.3506	.4832	.4207
6	.3574	.3582	.3589	.3635	.3559	.3719	.3643
7	.3551	.3597	.3567	.3643	.3559	.3666	.3628
8	.3986	.4031	.3963	.4054	.3948	.3917	.3978
9	.4054	.4054	.4054	.4062	.394	.3955	.4031
10	.4039	.4024	.4123	.4001		.5053	.5235
11	.4047	.4169	.4009	.4024		.5266	.5274
12	.4451	.4161	.4009	.3925		.41	.519
13	.4031	.4054	.3879	.3849		.4191	.4351
14	.4207	.3871	.3978	.3978	.1562	.4062	.503
15	.4001	.394	.4016	.3978	.1547	.4169	.5053
16	.3925	.3948	.3925	.3849	.157	.5228	.4733
17	.4222	.4001	.3902	.3849	.16	.4313	.3932
18	.4199	.4016	.3902	.3932	.0739	.4077	.4092
19	.4062	.4077	.3948	.3932	.1699	.5357	.4077
20	.4092	.4153	.3955	.3955	.2401	.4092	.4062
21	.4047	.407	.394	.3894	.49	.3917	.4092
22	.4062	.4039	.4077	.3864	.4054	.5167	.5312
23	.4085	.4077	.4077	.3871	.407	.4557	.503
24	.4062	.4016	.3993	.3902	.4793	.5266	.4123
Max	.4451	.4169	.4123	.4062	.49	.5357	.5312
Min	.3551	.3567	.3544	.3605	.0739	.3666	.3628
Avg	.3993	.3942	.3897	.3873	.3112	.4553	.4580

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 204 / OLD BUDHGAON ROAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0831	.0838	.0328	.0945	.0914	.0876	.0922
2	.0541	.0884	.0343	.0907	.093	.0846	.0678
3	.0404	.0869	.045	.0518	.0633	.0739	.0854
4	.0808	.0861	.0991	.1105	.08	.1135	.1166
5	.1166	.1174	.125	.1135	.1067	.1425	.1235
6	.1303	.1257	.1357	.1273	.1151	.1501	.1128
7	.1166	.1273	.1212	.1265	.1158	.1387	.1036
8	.1082	.1174	.1105	.1113	.1181	.128	.1021
9	.0983	.1067	.096	.1029	.109	.1097	.0404
10	.0602	.0945	.0754	.0914	.0937	.0899	.0366
11		.0884	.0061	.0846	.0869	.0823	
12		.0838		.0808	.0808	.0793	
13		.0793		.0511	.0793	.0686	
14		.0808	.0373	.0274	.0793	.0274	
15		.0815	.0145	.0549	.0838	.0648	
16		.0869	.0335	.0564	.0678	.048	
17	.0015		.0404	.0015	.0053	.0023	.0267
18	.0053	.0145	.0358	.0389	.003	.016	.0122
19	.0145	.0351	.0533	.0488	.0069	.0488	.0305
20	.0587	.0823	.0884	.0511	.0572	.0785	.0823
21	.0351	.0968	.0937	.0785	.0709	.0991	.0815
22	.0564	.0671	.096	.0854	.0823	.0953	.0922
23	.0876	.08	.1044	.0899	.0869	.0884	.0823
24	.0793	.0328	.1006	.0884	.0716	.0854	.0724
Max	.1303	.1273	.1357	.1273	.1181	.1501	.1235
Min	.0015	.0145	.0061	.0015	.003	.0023	.0122
Avg	.0682	.0845	.0718	.0774	.0770	.0834	.0756

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 205 / SANGLI COLLEGE CORNER  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7689	.7468	.8368	.7522	.8375	.8398	.8634
2	.7171	.6965	.7827	.7141	.7857	.7819	.8002
3	.7118	.6859	.7682	.6798	.7697	.7689	.7834
4	.6943	.6737	.7453	.6744	.7651	.7529	.7514
5	.7164	.7072	.7453	.6904	.7743	.7758	.7758
6	.8208	.8002	.8291	.8086	.8413	.8878	.8657
7	.9313	.9183	.8154	.9092	.9137	.9374	.9343
8	.964	.8901	.8398	.9191	.9625	.9305	.9366
9	.9648	.8802	.8764	.948	.948	.8993	.9084
10	.9595	.9282	.945	.9503	.8566	.9541	.9168
11	.9511	.9214	.9625	.9671	.8459	.9831	.9564
12	.9069	.9092	.9198	.9602	.7971	.9648	.9816
13	.865	.916	.8779	.9023	.7987	.9435	1.0128
14	.7667	.823	.7278	.8375	.7705	.8802	.8474
15	.7895	.8253	.7659	.8612	.7415	.9183	.8284
16	.804	.8535	.7903	.9511	.7758	1.0021	.9175
17	.7895	.8779	.849	.9183	.7705	.948	.9267
18	.8733	.9496	.9709	1.0105	.8307	.9762	.9983
19	1.1637	1.1774	1.134	1.2521	1.0928	1.2521	1.2673
20	1.2201	1.2369	1.1248	1.3512	1.1782	1.2971	1.243
21	1.1058	1.1645	1.0532	1.246	1.1363	1.1835	1.0486
22	1.0593	1.0814	.9755	1.1462	1.089	1.1195	1.025
23	.9823	1.0501	.9183	1.0852	1.0387	1.0341	.9183
24	.8459	.9473	.8345	.945	.9496	.9404	.8261
Max	1.2201	1.2369	1.134	1.3512	1.1782	1.2971	1.2673
Min	.6943	.6737	.7278	.6744	.7415	.7529	.7514
Avg	.8905	.9025	.8787	.9367	.8862	.9571	.9306

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244080 / 33/11KV RISALA ROAD

Feeder No / Name : 201 / 11KV GYMKHANA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5563	.5563	.6165	.5662	.6379	.6196	.6295
2	.5175	.519	.5746	.5418	.6097	.5746	.5845
3	.5053	.5083	.5609	.5312	.5967	.5624	.567
4	.5037	.4984	.5609	.5312	.5769	.5601	.5533
5	.5205	.5182	.5716	.5472	.5799	.5754	.5639
6	.6203	.6013	.6142	.6478	.663	.6737	.6562
7	.6843	.647	.6188	.6904	.6935	.7049	.7042
8	.711	.692	.692	.7362	.7827	.7392	.7514
9	.7171	.7263	.7179	.7019	.7514	.74	.7331
10	.7202	.7499	.7476	.7712	.7545	.7484	.772
11	.7628	.8147	.8017	.9069	.8368	.9137	.8474
12	.7613	.9	.8284	.8977	.8482	.929	.9313
13	.7484	.9023	.7994	.8497	.8147	.9008	.929
14	.7415	.8436	.7034	.8154	.7994	.8566	.8337
15	.7377	.8314	.6889	.8208	.7606	.8612	.7461
16	.7293	.8154	.6965	.8169	.7583	.8756	.7781
17	.7278	.8436	.7255	.8185	.7842	.8139	.8284
18	.8429	.8977	.8688	.9915	.9343	1.0098	.9983
19	1.198	1.2323	1.1035	1.2772	1.1797	1.2696	1.2422
20	1.2239	1.2635	1.1325	1.291	1.2018	1.2498	1.1713
21	1.1805	1.2087	1.0448	1.2399	1.1667	1.1507	1.0898
22	1.0707	1.0707	.9534	1.0883	1.0418	1.0357	.9747
23	.8391	.8665	.8223	.9381	.8779	.8733	.8269
24	.66	.7209	.6493	.7651	.7171	.727	.6699
Max	1.2239	1.2635	1.1325	1.291	1.2018	1.2696	1.2422
Min	.5037	.4984	.5609	.5312	.5769	.5601	.5533
Avg	.7617	.8012	.7539	.8243	.8070	.8319	.8076



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244080 / 33/11KV RISALA ROAD

Feeder No / Name : 202 / 11KV RAJWADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.618	.6828	.631	.5708	.5418	.5441
2	.4451	.5891	.6485	.6005	.5296	.5037	.5075
3	.4405	.5769	.6455	.4664	.5175	.4976	.4885
4	.4382	.5754	.6348	.4702	.5144	.4938	.4877
5	.4466	.5731	.6462	.4702	.5213	.4931	.4915
6	.4809	.5891	.6821	.5106	.5449	.5289	.5342
7	.4839	.5975	.6607	.5129	.5472	.5998	.5296
8	.5152	.6318	.6737	.5495	.5274	.6889	.5251
9	.5685	.5761	.6973	.5723	.5403	.6897	.5464
10	.7034	.6554	.6744	.5944	.5647	.7263	.618
11	.8284	.74	.7125	.6859	.6622	.8322	.6325
12	.8154	.7834	.6866	.7324	.6546	.8764	.7461
13	.8002	.7743	.6904	.7354	.679	.9595	.7926
14	.7964	.7613	.5449	.7125	.6699	.8772	.7346
15	.7377	.7316	.5967	.6714	.7095	.8459	.6127
16	.7644	.7354	.5914	.6767	.7064	.849	.663
17	.7377	.7095	.6485	.6363	.6828	.8436	.6668
18	.7705	.7209	.6889	.3018	.7004	.6996	.6843
19	.9709	.961	.849	1.0913	.8581	.9145	.9656
20	1.0631	1.0593	.9031	1.1149	.9008	.9701	.9732
21	.9762	1.0227	.8535	.9899	.8703	.9107	.836
22	.8726	.9214	.807	.8512	.7773	.7628	.7339
23	.7903	.8429	.7613	.7415	.7064	.6836	.6577
24	.6988	.7682	.6912	.6432	.6203	.6013	.5647
Max	1.0631	1.0593	.9031	1.1149	.9008	.9701	.9732
Min	.4382	.5731	.5449	.3018	.5144	.4931	.4877
Avg	.6926	.7298	.6946	.6651	.6490	.7246	.6473

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244080 / 33/11KV RISALA ROAD

Feeder No / Name : 203 / 11KV VAKHARBAG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5624	.5677	.628	.5967	.6089	.6127	.6142
2	.5121	.5136	.5456	.5228	.5479	.5594	.551
3	.5098	.506	.5266	.5068	.5411	.5418	.5396
4	.5075	.49	.5251	.4999	.5449	.5235	.5266
5	.5007	.49	.5175	.4976	.5335	.519	.5182
6	.5083	.5175	.5312	.5114	.5563	.5434	.5502
7	.5746	.551	.5289	.5853	.602	.6241	.5914
8	.5921	.5799	.5479	.6165	.6104	.6287	.6188
9	.6432	.6127	.6165	.6081	.6455	.6485	.6379
10	.7064	.6508	.6783	.6783	.7103	.6904	.7064
11	.8337	.7659	.8169	.8718	.8352	.932	.8528
12	1.0357	.9808	.9823	1.0288	.8871	1.0433	1.0288
13	1.0197	1.0029	1.0105	1.0296	.5975	1.0067	1.0966
14	.9785	.9777	.9023	.9983	.9503	.9678	1.1233
15	.9396	.9556	.8939	.9473	.8871	1.0326	.98
16	.9374	.9823	.8154	.9686	.9739	1.0258	.9732
17	.8162	.9945	.8436	.9503	1.0098	.977	.961
18	.9137	.993	.9877	1.0273	.9991	1.0227	1.0189
19	1.0418	1.1256	1.0692	1.1591	1.1401	1.1576	1.1515
20	1.1683	1.2521	1.0105	1.1942	1.1774	1.2071	1.1683
21	1.1957	1.2109	.9244	1.2201	1.2041	1.1446	1.0761
22	1.0212	1.025	.8772	1.0341	1.0951	1.0799	.9922
23	.8337	.8665	.6478	.8993	.9031	.8657	.8406
24	.743	.7499	.4367	.7385	.7636	.7331	.6958
Max	1.1957	1.2521	1.0692	1.2201	1.2041	1.2071	1.1683
Min	.5007	.49	.4367	.4976	.5335	.519	.5182
Avg	.7956	.8067	.7443	.8204	.8052	.8370	.8256

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 201 / 11 KV OM COLD

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.3272	3.2952	3.3532	3.216	3.4065	1.7574	2.9706
2	3.1946	3.2404	3.2327	3.3303	3.2419	1.7589	2.8121
3	3.094	3.2007	3.309	3.3669	3.1916	1.7741	2.7999
4	3.0239	3.1306	3.2419	3.2648	3.1657	1.7665	2.7648
5	3.1763	3.28	3.187	3.187	3.1093	1.7848	2.6932
6	3.1931	3.2739	3.3272	3.2495	2.9538	1.7756	2.7084
7	3.2297	3.3455	3.4034	3.4385	2.9645	1.9814	2.7237
8	3.2998	3.2053	3.2968	3.3532	2.7054	1.9814	2.8898
9	3.7235	3.6214	3.5879	3.4827	1.9387	2.8365	3.4919
10	4.2006	4.2783	4.068	4.0756	1.7497	3.6412	4.0162
11	4.4887	4.382	4.2737	4.5481	1.6964	3.8881	4.385
12	4.321	4.417	4.3286	4.5771	1.6979	3.914	4.6609
13	4.2189	4.4338	4.324	4.4612	1.669	3.7982	4.5618
14	4.1213	4.0634	4.0954	4.0787	1.5988	3.5985	4.2295
15	4.3134	4.7295	4.4978	4.446	1.6232	3.9079	4.7889
16	4.1777	4.5115	4.4765	4.5024	1.5577	4.0466	4.702
17	4.324	4.3103	4.3789	4.4445	1.4998	3.9674	4.7249
18	4.1991	4.289	4.1701	4.3606	1.5226	3.8195	4.4826
19	4.2097	4.0665	3.914	3.9369	1.6324	3.722	4.0787
20	3.8058	3.7235	3.5909	3.7235	1.6994	3.5269	3.69
21	3.2053	3.3547	3.4903	3.4004	1.7452	3.091	3.3272
22	3.28	3.3364	3.2526	3.4675	1.7482	2.9828	3.251
23	3.3821	3.4507	3.2678	3.4187	1.7497	3.0331	3.2282
24	3.3714	3.4263	3.3196	3.5056	1.7619	3.0239	3.3318
Max	4.4887	4.7295	4.4978	4.5771	3.4065	4.0466	4.7889
Min	3.0239	3.1306	3.187	3.187	1.4998	1.7574	2.6932
Avg	3.7034	3.7652	3.7245	3.7848	2.1512	2.9741	3.6380

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 203 / 11 KV DIAMOND

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4098	1.4548	1.4662	***	***	***	***
2	1.3298	1.3664	1.3245	1.3161	1.3611	.7956	1.3451
3	1.3481	1.3268	1.3047	***	***	***	***
4	1.3862	1.4617	1.3207	***	***	***	***
5	1.3314	1.3695	1.3695	.8109	1.2285	.7644	1.4274
6	1.4205	1.4098	1.3756	***	***	***	***
7	1.464	1.4007	1.3634	***	***	***	***
8	1.4281	1.4952	1.5242	1.4708	1.3763	.7842	1.5242
9	1.3413	1.4022	1.4129	***	***	***	***
10	1.531	1.5851	***	***	***	***	***
11	1.6728	1.6903	1.6568	1.5394	.4047	1.0357	1.6126
12	1.6636	1.7109	***	***	***	***	***
13	1.5242	1.6049	***	***	***	***	***
14	1.1012	1.4297	1.6857	1.4861	.3056	.9221	1.4754
15	1.0799	1.5562	***	***	***	***	1.5531
16	1.0463	1.6872	***	***	***	***	1.5775
17	1.4937	1.6423	1.6621	1.6225	.2378	.9617	1.6187
18	1.4662	1.6309	***	***	***	***	.9313
19	1.6164	1.6507	***	***	***	***	1.3108
20	1.6629	1.5874	1.5036	1.4967	.3925	1.4662	1.4502
21	1.4708	1.4419	***	***	***	***	1.2727
22	1.3611	1.3992	***	***	***	***	1.5287
23	1.5028	1.4533	1.31	1.3542	1.31	1.4144	1.4403
24	1.3359	1.4426	***	***	***	***	1.422
Max	1.6728	1.7109	49.9429	49.9429	49.9429	49.9429	49.9429
Min	1.0463	1.3268	1.3047	.8109	.2378	.7644	.9313
Avg	1.4162	1.5083	21.6545	33.7576	33.5710	33.6346	19.6240

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 204 / 11KV NATRAJ

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2462	.2103	.2629	.2035	.2096	.176	.234
2	.2416	.2103	.2591	.1951	.2119	.176	.2233
3	.2385	.2073	.2431	.1951	.2088	.1745	.2134
4	.2378	.2058	.2401	.1989	.202	.1753	.1905
5	.2522	.2103	.2553	.1997	.2004	.1768	.1966
6	.2431	.2256	.2507	.2126	.192	.1783	.1981
7	.2393	.2119	.285	.2058	.1959	.1799	.2271
8	.3041	.2088	.2995	.2111	.1875	.1715	.2362
9	.4915	.4954	.3406	.282	.1913	.2248	.3033
10	.5251	.5449	.3932	.4009	.1837	.3734	.3757
11	.647	.6584	.4359	.4169	.1806	.5517	.4626
12	.9191	.6821	.4237	.4108	.1738	.5838	.7903
13	.8139	.5792	.3826	.4001	.1745	.583	.7682
14	.5251	.5144	.3506	.3772	.1677	.4999	.5258
15	.7125	.7446	.4222	.442	.1562	.5129	.6851
16	.7377	.7514	.5296	.5014	.1684	.5647	.6356
17	.7278	.8093	.522	.4816	.1738	.4976	.4618
18	.647	.7659	.4672	.5479	.1776	.5975	.4626
19	.756	.6714	.4618	.4009	.1791	.4908	.4443
20	.5449	.6379	.2362	.2858	.1753	.3292	.2606
21	.4047	.4611	.2355	.2454	.1768	.2545	.2103
22	.2195	.2774	.218	.2233	.1738	.2462	.1974
23	.221	.2721	.2286	.2301	.1753	.2538	.2111
24	.2195	.2736	.2256	.2309	.176	.2423	.2484
Max	.9191	.8093	.5296	.5479	.2119	.5975	.7903
Min	.2195	.2058	.218	.1951	.1562	.1715	.1905
Avg	.4631	.4512	.3320	.3125	.1838	.3423	.3651

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 205 / 11 KV OMKAR

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9517	1.736	1.7574	1.528	1.7993	.8063	1.7048
2	1.7436	1.9403	1.9052	1.8427	1.7688	.8177	1.8138
3	1.97	1.7909	1.2551	1.5303	1.832	.8733	1.4975
4	1.4975	1.6781	1.8343	1.7718	1.2582	.9343	1.7048
5	2.0218	2.0431	1.7474	1.5485	1.8846	.961	1.829
6	1.6088	1.3946	1.701	1.7604	1.5493	.9511	1.7375
7	1.8038	1.6941	1.7002	1.3542	1.8404	.8779	1.9113
8	1.5379	1.6065	1.1126	1.576	.7369	1.5905	1.4822
9	1.2323	1.8359	1.8328	1.7253	.7888	1.6027	1.8785
10	1.7444	1.8389	1.8061	1.3748	.7849	1.6095	1.5706
11	1.6072	2.0599	1.9502	2.1193	.4298	1.97	1.8077
12	1.97	2.2382	1.7939	1.9143	.4123	1.9913	2.1361
13	1.877	2.0477	1.9273	1.6926	.7575	1.8861	1.8138
14	2.1376	2.2009	1.5859	1.7711	.7606	2.0111	2.5057
15	2.1018	2.508	2.0683	1.7322	.7636	2.1186	1.9669
16	2.2116	1.8907	2.268	2.0706	.7667	2.303	1.9723
17	2.0447	2.3213	1.7101	2.2542	.7804	1.9776	2.095
18	1.6964	1.7086	1.8122	1.5432	.8086	1.6286	1.4411
19	2.1712	1.7673	1.6972	1.5585	.807	1.6476	1.5554
20	1.6438	1.5927	1.6758	1.9342	.7743	1.579	1.5646
21	1.0486	1.6194	1.7124	1.4144	.7324	1.685	1.4457
22	1.1896	1.1393	1.0715	1.9906	.7735	1.6042	1.3771
23	1.5066	1.8724	1.5318	1.5813	.7948	1.893	1.6979
24	2.0302	1.9303	1.5821	1.8762	.8093	1.8892	1.7116
Max	2.2116	2.508	2.268	2.2542	1.8846	2.303	2.5057
Min	1.0486	1.1393	1.0715	1.3542	.4123	.8063	1.3771
Avg	1.7645	1.8523	1.7100	1.7277	1.0173	1.5504	1.7592

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 207 / 11 kv mandhana

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2178	1.1934	1.2422	1.1774	1.1911	.7293	1.2765
2	1.1568	1.1675	1.2521	1.1347	1.2445	.7583	1.2734
3	1.2148	1.0814	1.2026	1.1195	1.0715	.7651	1.2216
4	1.1767	1.1279	1.1827	1.1591	1.1614	.7819	1.1431
5	1.1759	1.1416	1.166	1.1949	1.0966	.7895	1.2186
6	1.1637	1.2018	1.1744	1.1774	1.1637	.7933	1.233
7	1.2544	1.1881	1.1088	1.1835	1.1446	.7804	1.2239
8	1.2178	1.3016	1.2132	1.1317	.9198	.868	1.2178
9	1.6324	1.5394	1.5943	1.5767	.7842	1.3832	1.6316
10	1.9486	2.002	1.8625	1.7695	.7811	1.7406	1.9829
11	1.9883	1.9692	1.8679	1.9784	.7446	1.8206	1.9235
12	1.97	1.9776	1.8755	1.9662	.775	1.9875	2.1079
13	1.7429	1.8854	1.8938	1.9875	.7849	1.813	1.9761
14	1.5996	1.7711	1.8008	1.6674	.7842	1.752	1.7276
15	1.7208	1.9303	2.0927	1.8229	.7758	1.8572	1.8526
16	1.6735	1.9601	1.7551	1.9006	.7987	1.8854	1.8679
17	1.6423	1.893	1.8877	1.7353	.7689	1.7977	1.848
18	1.7444	1.8138	1.9753	1.8	.7865	1.8648	1.7749
19	1.72	1.6141	1.7406	1.7497	.7773	1.8176	1.7109
20	1.6728	1.5912	1.6583	1.4571	.7514	1.6263	1.5127
21	1.6339	1.5905	1.4982	1.4022	.7278	1.6613	1.499
22	1.4929	1.5043	1.4144	1.5082	.7362	1.5729	1.262
23	1.5333	1.4746	1.4007	1.515	.7407	1.39	1.1995
24	1.2948	1.2833	1.1553	1.2833	.7468	1.2262	1.2757
Max	1.9883	2.002	2.0927	1.9875	1.2445	1.9875	2.1079
Min	1.1568	1.0814	1.1088	1.1195	.7278	.7293	1.1431
Avg	1.5245	1.5501	1.5423	1.5166	.8857	1.3943	1.5400

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 208 / 11 KV Devika

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1745	.2042	.1738	.1783	.1837	.1943	.189
2	.1799	.2134	.1738	.1722	.1844	.1951	.1898
3	.1898	.2218	.1905	.173	.189	.1959	.1875
4	.192	.2225	.2035	.1722	.1913	.1943	.1936
5	.1837	.2126	.2027	.1882	.192	.1867	.208
6	.1707	.1905	.1981	.1844	.1814	.1852	.205
7	.1867	.2035	.2042	.1776	.2012	.1959	.2225
8	.1898	.2286	.2187	.1844	.1966	.1966	.2423
9	.237	.25	.2294	.2103	.2141	.2157	.2469
10	.2469	.2591	.2439	.2545	.221	.2126	.285
11	.2766	.2964	.3071	.2881	.2378	.2484	.2995
12	.3193	.2987	.2865	.3018	.2301	.2515	.2827
13	.2888	.2728	.2873	.2827	.2332	.2423	.2545
14	.2705	.2652	.2743	.2469	.2157	.2667	.2926
15	.282	.3033	.2957	.2896	.2103	.2522	.2911
16	.301	.3041	.2972	.2454	.2126	.2385	.266
17	.2995	.2949	.3178	.2416	.2157	.2629	.2843
18	.2568	.2553	.2667	.2522	.2172	.2629	.2622
19	.2233	.2317	.2195	.2218	.2187	.2439	.2378
20	.2065	.2149	.208	.2027	.2088	.2408	.2256
21	.1936	.1951	.1859	.1753	.1936	.1951	.1905
22	.1943	.1837	.1867	.1821	.1966	.1837	.1959
23	.1959	.1753	.1799	.1806	.1943	.1829	.189
24	.2004	.1715	.1753	.1814	.1959	.1791	.1951
Max	.3193	.3041	.3178	.3018	.2378	.2667	.2995
Min	.1707	.1715	.1738	.1722	.1814	.1791	.1875
Avg	.2275	.2362	.2303	.2161	.2056	.2176	.2349



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 402 / 33 KV Shah Presicast Unit NON SHEDDABLE EXPRESS HV FEEDERS  
 III Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.6859	.6516	.7545	.7202	.7888	.6859
2	.3086	.6173	.6859	.7202	.7545	.823	.6859
3	.3086	.7202	.6859	.7545	.7545	.8573	.7202
4	.6516	.7545	.7545	.7545	.7888	.8573	.7545
5	.583	.583	.7202	.6859	.7545	.8573	.7545
6	.4458	.6516	.7202	.7202	.7888	.8916	.7545
7	.7202	.7202	.583		.7202	.9259	.6859
8	.7202	1.406	.6173		.7202	.9259	.7545
9	.2401	2.8464	.6516	.4801	.7545	.9945	3.2922
10	.0686	3.3265	.4115	.2058	.5144	1.0288	3.738
11	1.0974	3.9095	.5144	.2058	.6516	1.6118	3.7037
12	3.4637	3.2579	.7545	.3429	.6173	2.4691	3.7723
13	2.8807	2.5034	2.8464	.2058	.7545	1.6118	3.7037
14	3.6351	3.8752	3.6008	.5487	.7545	3.2579	3.4637
15	2.7778	3.8066	3.6008	.2401	.7202	2.1605	3.5322
16	.2058	3.4637	3.2236	.4115	.823	3.0521	3.6008
17	.1372	.1715	3.3265	.4115	.823	2.6063	.1372
18	.2743	.1372	2.332	.4115	.823	.1029	.1029
19	.3086	.1715	.6516	.4458	.7888	.4458	.5487
20	.5487	.4458	.4458	.6173	.823	.6859	.6173
21	.6859	.7202	.6516	.7545	.823	.7545	.7545
22	.7545	.7202	.7888	.7545	.823	.7545	.6859
23	.7202	.7202	.6859	.6516	.7888	.6516	.6516
24	.7202	.6516	.7202	.7545	.7888	.7545	.7202
Max	3.6351	3.9095	3.6008	.7545	.823	3.2579	3.7723
Min	.0686	.1372	.4115	.2058	.5144	.1029	.1029
Avg	.9417	1.5361	1.2760	.5378	.7530	1.2446	1.6175

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244043 / 33/11 KV CHAKAN

Feeder No / Name : 401 / 33 KV Parvati Agro Plast      NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / OUTGOING      (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	1.1488			.4287	.463	.4287
2	.2572	1.1317	.1372		.4287	.463	.4287
3	.3601	1.1317	.2058		.4287	.463	.4287
4	.3944	.6687	.0686		.4287	.463	.4287
5	.4801	.1715			.4287	.463	.4287
6	.4973				.4287	.463	.4287
7	.4973	.3429	.1886		.4287	.463	.4287
8	.4973	.3429	.3258		.4458	.463	.4115
9	.463	.3429	.0343		.463	.4458	.4287
10	.5144	.3772	.0857		.4458	.4115	.4287
11	.4973	.3429	.0686		.4458	.4115	.4115
12	.4801	.3944	.0686	.0857	.4458	.4287	.4115
13	1.0117	.6173	.1886	.4115	.4458	.4287	.4115
14	.6859	.4801	.1029	.4287	.463	.4287	.4287
15	.2915	.4973		.4287	.4458	.4287	.4287
16	.7716	.4801		.4287	.463	.4287	.4287
17	.8402	.463		.4287	.463	.4287	.4287
18	1.0802	.463		.4287	.463	.4115	.4287
19	1.046	.4458	.0171	.4115	.463	.4287	.4287
20	1.1145	.463		.4287	.463	.4287	.4287
21	1.0974	.4801		.4458	.463	.4287	.4287
22	1.166	.2915		.4287	.463	.4287	.4287
23	1.166	.1029		.4287	.463	.4287	.4287
24	1.1488			.4287	.463	.4115	.4287
Max	1.166	1.1488	.3258	.4458	.463	.463	.4287
Min	.2572	.1029	.0171	.0857	.4287	.4115	.4115
Avg	.6937	.5082	.1243	.4010	.4487	.4380	.4258

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244043 / 33/11 KV CHAKAN

Feeder No / Name : 404 / 33KV BASHKO

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9547	3.5665	3.5665		2.1434	
2	1.8004	3.8409	2.8121		2.2462	
3	3.2579	3.4294	2.332		2.5377	
4	3.8409	3.6523	3.5837		3.7894	
5	3.618	3.7894	3.5151		3.5322	
6	2.0576	3.6351	3.6523		3.5151	
7	3.8237	2.452	3.9266	.7373	3.0693	
8	3.6351	2.2805	3.9266	2.4177	3.738	
9	2.0233	2.0233	2.2462	3.0864	3.8923	.7373
10	2.3491	2.1776	1.9547	2.4006	.3258	2.2462
11	3.4808	1.8519	2.0576	1.9033	.3944	3.5665
12	3.8066	.583	1.6975	3.7894	.3601	2.7949
13	3.6008	1.5261	1.8347	3.738	.463	2.2634
14	3.1893	1.7661	1.6804	2.0576	.1372	3.3265
15	3.275	1.9033	2.0576	3.5322		3.5151
16	2.5377	1.8004	2.1948	3.9095		3.8066
17	3.8066	1.8176	2.0576	3.4294	.0686	3.8923
18	3.5322	1.7833	1.9376	3.4294	.0171	4.0124
19	3.5494	.3601	2.0405	3.8752		3.7894
20	3.5837	.5144	2.3491	2.2462		3.8752
21	2.0233	.4287	3.3265	2.3491		2.2291
22	2.1262	.4287		2.0576		2.3491
23	3.3779	2.2977		2.2119		3.738
24	4.0809	2.0576		2.1948		3.6523
Max	4.0809	3.8409	3.9266	3.9095	3.8923	4.0124
Min	1.8004	.3601	1.6804	.7373	.0171	.7373
Avg	3.0971	2.0819	2.6071	2.7425	1.8894	3.1121

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 201 / 11 KV Ankur

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1667	1.1622	1.0997	1.1683	1.3253	.916	1.0334
2	1.0037	1.0021	1.0959	1.1538	1.1606	.8901	1.0593
3	.9488	.9838	1.0715	1.1645	1.1614	.913	1.0181
4	.9717	.9884	1.0433	.9335	1.0578	.9	1.0105
5	.9465	1.0006	1.0189	.9473	.9915	1.044	1.0159
6	1.0128	.9998	1.0623	.9541	.9838	1.0098	1.0883
7	1.0425	.9572	1.073	.945	.8939	1.0783	1.1385
8	1.0867	.9686	1.1096	.9442	.8459	1.0791	1.1065
9	1.4236	1.4266	1.2917	1.262	.8215	1.5074	1.4982
10	1.4868	1.704	1.6842	1.5333	.6112	1.5364	1.7833
11	1.7436	1.9174	1.7276	1.7414	.6394	1.6667	1.9098
12	1.6461	1.8717	1.5836	1.7589	.5799	1.659	1.9349
13	1.3557	1.653	1.3961	1.4914	.5716	1.5485	1.6461
14	1.5905	1.829	1.6842	1.5775	.5548	1.5623	1.6446
15	1.5737	1.8038	1.733	1.6049	.551	1.752	1.7627
16	1.5447	1.8206	1.6575	1.7711	.5876	1.3336	1.6766
17	1.6423	1.6941	1.672	1.7612	.6531	1.5082	1.5333
18	1.6903	1.5844	1.7025	1.6507	.692	1.5203	1.5646
19	1.4342	1.3489	1.5318	1.5394	.9137	1.3679	1.48
20	1.3054	1.2902	1.2384	1.5082	.996	1.2521	1.2955
21	1.2894	1.1492	1.243	1.2849	1.0059	1.3695	.9442
22	1.262	1.1629	1.291	1.5318	.9092	1.3573	1.1431
23	1.2872	1.166	1.2574	1.4556	.9099	1.1241	1.1157
24	1.2757	1.1629	1.1736	1.4358	.9252	1.1454	1.0715
Max	1.7436	1.9174	1.733	1.7711	1.3253	1.752	1.9349
Min	.9465	.9572	1.0189	.9335	.551	.8901	.9442
Avg	1.3221	1.3603	1.3517	1.3800	.8476	1.2934	1.3531

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 202 / 11 KV LOKMAT

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5114	.5449	.551	.5449	.4915	.4428	.4969
2	.5068	.5106	.5243	.5136	.455	.4306	.4885
3	.4877	.4824	.4862	.4915	.4245	.4359	.4976
4	.4893	.4694	.4885	.4992	.4268	.4344	.5045
5	.4961	.4664	.487	.4771	.4268	.426	.5053
6	.5152	.49	.4931	.4748	.4245	.4298	.503
7	.5274	.5182	.4885	.503	.4481	.4519	.5388
8	.5525	.5708	.538	.5335	.471	.4649	.535
9	.7247	.7529	.7232	.7164	.4641	.759	.7796
10	.9503	1.0372	.9252	.9549	.4931	1.0303	.9419
11	1.2544	1.2727	1.0067	1.0197	.4771	1.2308	1.07
12	1.2056	1.3138	1.0921	1.0402	.5037	1.2742	1.1446
13	1.0982	1.1782	.9793	.9282	.5167	1.0319	1.0471
14	1.0943	1.1302		.9747	.5213	1.0067	1.0059
15	1.1721	1.2574	1.0067	.9846	.5114	1.07	1.0288
16	1.1408	1.134	1.102	.9976	.1517	1.134	1.1401
17	1.1111	1.0761	1.0021	.9907	.4847	1.0844	1.1637
18	1.0265	1.012	.9915	.9305	.4763	.9069	1.0722
19	.9473	.8512	.8787	.8154	.4473	.8055	.8528
20	.8436	.7933	.7255	.7186	.4344	.7026	.724
21	.7628	.7179	.6836	.647	.4367	.5388	.5777
22	.618	.6508	.618	.5769	.4466	.4976	.5296
23	.6767	.6859	.647	.5937	.4519	.5106	.5213
24	.6554	.6645	.6424	.5982	.4443	.5098	.5014
Max	1.2544	1.3138	1.102	1.0402	.5213	1.2742	1.1637
Min	.4877	.4664	.4862	.4748	.1517	.426	.4885
Avg	.8070	.8159	.7426	.7302	.4512	.7337	.7571

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 246001 / 110/33/11 KV VISHRAMBAG S/SN

Feeder No / Name : 204 / 11 KV Karnal

SHEDDABLE URBAN

(Yashwantnagar) Feeder KV- 11  
/ OUTGOING

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2117	1.2536	1.4518	1.2651	1.4594	1.4556	1.4784
2	1.1431	1.1736	1.3641	1.2041	1.3679	1.3489	1.3794
3	1.1279	1.1507	1.2765	1.1812	1.3298	1.3184	1.3527
4	1.1203	1.1393	1.2803	1.1812	1.3222	1.3336	1.3336
5	1.1355	1.1469	1.2993	1.1927	1.3146	1.326	1.3413
6	1.2536	1.2574	1.3756	1.3032	1.4137	1.4175	1.3794
7	1.3451	1.3527	1.406	1.3908	1.4556	1.4861	1.467
8	1.4441	1.3336	1.3565	1.4518	1.467	1.4708	1.467
9	1.307	1.2003	1.3108	1.3298	1.3298	1.2689	1.2727
10	1.1355	1.0631	1.2384	1.166	1.3032	1.1507	1.1012
11	1.0288	1.0136	1.1126	1.0326	.9907	1.0288	1.0364
12	.9678	1.0021	1.086	.9983	.8154	1.0059	1.0212
13	.8954	1.0402	1.0822	1.0059	.8383	1.0098	.9983
14	.8573	1.0326	.9983	.9831	.8726	1.0174	.9831
15	.8154	1.0212	.9488	.9717	.9869	1.0669	.8916
16	.7888	1.0212	1.0174	.9831	.9755	1.0669	.9069
17	.8116	.9983	1.0059	.9755	.9678	1.0517	.9602
18	.8954	1.0364	1.2041	1.0212	1.0136	1.0707	1.0898
19	1.3032	1.3413	1.5356	1.4784	1.406	1.5775	1.6499
20	1.9852	2.0652	1.9357	2.1643	2.0424	2.1224	1.9433
21	1.9776	2.0767	1.9014	2.1605	2.0195	2.0957	1.909
22	1.89	1.9814	1.8557	2.0614	2.0157	2.0043	1.9014
23	1.8061	1.9014	1.7756	1.9776	1.9243	1.9204	1.7947
24	1.5242	1.7032	1.467	1.7109	1.6728	1.7223	1.4746
Max	1.9852	2.0767	1.9357	2.1643	2.0424	2.1224	1.9433
Min	.7888	.9983	.9488	.9717	.8154	1.0059	.8916
Avg	1.2404	1.3044	1.3452	1.3413	1.3460	1.3891	1.3389

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 201 / 11 KV MIRAJ CITY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9389	1.0151	1.1004	.9998	1.1088	1.1416	1.1614
2	.8893	.9579	1.0418	.9503	1.0486	1.0883	1.102
3	.8733	.9267	1.0204	.9374	1.0219	1.0578	1.1012
4	.8749	.9259	1.0159	.9244	1.0425	1.0585	1.0997
5	.929	.9595	1.0578	.9671	1.0547	1.0692	1.134
6	1.1225	1.1507	1.1599	1.1622	1.2346	1.2376	1.2902
7	1.3062	1.2628	1.2315	1.3062	1.3054	1.3062	1.3527
8	1.323	1.3001	1.2872	1.31	1.3275	1.3199	1.3603
9	1.3047	1.2346	1.3176	1.2849	1.3352	1.3001	1.2414
10	1.233	1.185	1.2902	1.1241	1.1652	1.1728	1.2353
11	1.1446	1.1439	1.2582	1.041	1.1203	1.1485	1.2308
12	1.0006	1.1172	1.2338	1.0684	1.0707	1.1698	1.2254
13	.9808	1.1073	1.1096	1.0357	1.0402	1.1302	1.1538
14	.9198	1.0715	.8551	1.0311	.9396	1.0044	1.0822
15	.8337	.996	.9465	.9838	.5411	.9816	.9823
16	.7956	.9595	1.0067	.945	1.1233	1.0052	.8718
17	.8291	1.0136	1.0486	.9168	1.0151	.9511	.9259
18	1.0501	1.102	1.1706	1.0822	1.1393	1.1523	1.2102
19	1.5882	1.6232	1.5722	1.672	1.653	1.7276	1.4609
20	1.6865	1.7353	1.5943	1.7551	1.704	1.7932	1.5524
21	1.6453	1.685	1.6042	1.7071	1.7002	1.7238	1.5752
22	1.5531	1.6324	1.5714	1.5836	1.6423	1.6758	1.5424
23	1.3885	1.4632	1.3542	1.5028	1.5082	1.5356	1.3527
24	1.15	1.2323	1.1218	1.2628	1.2925	1.3131	1.1469
Max	1.6865	1.7353	1.6042	1.7551	1.704	1.7932	1.5752
Min	.7956	.9259	.8551	.9168	.5411	.9511	.8718
Avg	1.1400	1.2000	1.2071	1.1897	1.2139	1.2527	1.2246

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 205 / 11KV Dairy Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6485	.6386	.7179	.6737	.7324	.7583	.7506
2	.5921	.6051	.6653	.6264	.6767	.7026	.7125
3	.5898	.5914	.6432	.6173	.6569	.6821	.6805
4	.5792	.5815	.6333	.6074	.6508	.6775	.6722
5	.583	.586	.6432	.6188	.6462	.6706	.6699
6	.6501	.6554	.6897	.6981	.7331	.7446	.7293
7	.7659	.7316	.6775	.7659	.8093	.7979	.7956
8	.7522	.7316	.7194	.7697	.7819	.7644	.7994
9	.8398	.7682	.7926	.8238	.8375	.8543	.82
10	.8505	.8086	.7781	.8642	.8406	.8749	.8642
11	.8993	.8337	.7948	.9366	.8909	.9297	.9229
12	.9145	.8703	.7918	.9191	.9381	.9755	.961
13	.8764	.865	.7407	1.1485	.9084	.9564	.9694
14	.8497	.8688	.7019	1.0014	.9259	.9747	.8749
15	.7674	.7933	.7042	.9259	.8733	.9069	.7857
16	.7369	.7918	.6638	.8878	.8871	.9145	.7948
17	.7453	.8269	.6501	.865	.8512	.8627	.8246
18	.7491	.8002	.7697	.8863	.8535	.8665	.8459
19	.9526	.9838	.9305	1.121	1.0646	1.1126	1.0669
20	1.0761	1.1187	.9976	1.1873	1.1081	1.1797	1.0014
21	1.0212	1.0768	.9991	1.118	1.0517	1.1157	.9938
22	.9587	.9892	.945	1.0418	1.0296	1.0372	.9457
23	.929	.9739	.9236	1.0037	.9808	.993	.8726
24	.7636	.8246	.7827	.8512	.8573	.8665	.7819
Max	1.0761	1.1187	.9991	1.1873	1.1081	1.1797	1.0669
Min	.5792	.5815	.6333	.6074	.6462	.6706	.6699
Avg	.7955	.8048	.7648	.8733	.8577	.8841	.8390



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 206 / Vidya nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3376	.3498	.4169	.3681	.4115	.4291	.4382
2	.3125	.3254	.3803	.3315	.3833	.3986	.4077
3	.301	.317	.365	.3323	.3704	.3887	.3948
4	.298	.3117	.3628	.3231	.365	.3841	.3864
5	.3163	.3231	.3688	.333	.3772	.3879	.3963
6	.3696	.3719	.3948	.3963	.4374	.4412	.442
7	.4748	.4832	.4572	.4992	.5175	.5251	.5487
8	.4702	.4565	.4954	.4923	.5083	.5175	.5022
9	.4565	.4306	.4702	.4656	.4733	.4489	.4588
10	.4085	.3864	.4435	.4146	.4252	.4054	.4138
11	.3917	.3406	.3986	.3719	.397	.3719	.3856
12	.3567	.3803	.3818	.3894	.3612	.3749	.3696
13	.3399	.3803	.3795	.349	.3574	.3734	.3765
14	.3155	.3559	.3658	.3422	.381	.3871	.3452
15	.2957	.3338	.333	.3353	.3757	.3749	.3406
16	.282	.3346	.3216	.333	.3597	.365	.3414
17	.2614	.3193	.3376	.3551	.3567	.3513	.2629
18	.3147	.3064	.4313	.362	.3978	.3993	.3932
19	.4877	.5159	.5426	.5464	.5517	.5601	.5464
20	.6066	.6165	.567	.6333	.6112	.6523	.5693
21	.5898	.615	.5777	.6363	.6188	.6295	.5929
22	.5731	.5944	.5517	.5998	.6089	.6036	.5708
23	.519	.5495	.5258	.5685	.5677	.5792	.5342
24	.4359	.4824	.4298	.4877	.4992	.5167	.4451
Max	.6066	.6165	.5777	.6363	.6188	.6523	.5929
Min	.2614	.3064	.3216	.3231	.3567	.3513	.2629
Avg	.3964	.4117	.4291	.4277	.4464	.4527	.4359

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 203 / 11 KV Krishna Ghat

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1318	.176	.1486	.1806	.192	.1707
2	.1288	.1273	.1517	.144	.1532	.1555	.1623
3	.1273	.1257	.1478	.1395	.1501	.1532	.1593
4	.1616	.1578	.1821	.1677	.1821	.1829	.1867
5	.1753	.173	.2004	.1951	.1783	.2881	.1913
6	.2957	.2774	.2881	.2911	.1829	.2919	.2904
7	.2782	.2804	.2766	.2957	.1974	.2743	.2743
8	.2926	.2865	.2827	.2934	.1859	.2873	.2721
9	.2644	.2759	.2789	.2675	.1608	.2683	.2652
10	.2637	.2652	.2462	.2591	.16	.2378	.2675
11	.2576	.2568	.2576	.2462	.1669	.2599	.2858
12	.2515	.2355	.2622	.2568	.1715	.285	.2469
13	.2347	.1783	.1547	.2713	.1722	.2561	.2553
14	.1433	.1562	.1372	.2545	.1509	.2637	.2423
15	.1463	.1776	.141	.2538	.1623	.2202	.2027
16	.1151	.1509	.1318	.2195	.1212	.144	.2004
17	.1387	.1768	.1707	.2385	.141	.1669	.2309
18	.1357	.1547	.1783	.1616	.1471	.2522	.1799
19	.202	.2058	.2934	.2241	.1981	.3102	.1928
20	.2187	.2286	.2865	.2256	.2248	.3079	.1235
21	.2469	.2439	.3193	.2492	.2454	.3445	.2355
22	.2408	.2446	.3102	.2515	.2454	.3269	.2355
23	.1799	.2004	.1806	.2058	.2012	.2065	.189
24	.1745	.1943	.1882	.202	.1981	.208	.1799
Max	.2957	.2865	.3193	.2957	.2454	.3445	.2904
Min	.1151	.1257	.1318	.1395	.1212	.144	.1235
Avg	.2003	.2044	.2184	.2276	.1782	.2451	.2183

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 205 / 11 KV JACKWELL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2061	.2073	.21	.2	.2088	.2023	.205
2	.2061	.2065	.2077	.2004	.2073	.202	.2042
3	.2058	.2069	.2073	.3155	.2073	.33	.2709
4	.3757	.3734	.3692	.3681	.3746	.373	.37
5	.3761	.3738	.3734	.3677	.3746	.3734	.3704
6	.3765	.3734	.3749	.3673	.3746	.3761	.3692
7	.3772	.3776	.3768	.37	.3734	.3784	.3723
8	.378	.3795	.3742	.3711	.3749	.3685	.3685
9	.3814	.3829	.3753	.3734	.3788	.3711	.37
10	.3841	.3765	.3807	.3776	.3818	.3746	.3746
11	.381	.3749	.3746	.3818	.3772	.3746	.3704
12	.3822	.3768	.3772	.3753	.3711	.3711	.3711
13	.3822	.3746	.3681	.3719	.3715	.3704	.3662
14	.3776	.3688	.3738	.3753	.3715	.365	.3673
15	.3799	.37	.378	.3776	.3719	.3727	.3688
16	.381	.3719	.378	.3772	.3704	.3715	.3688
17	.378	.3765	.3696	.3749	.3685	.3681	.3727
18	.3791	.3765	.3692	.3765	.3719	.3696	.3746
19	.3803	.3742	.3715	.3788	.3765	.3768	.3788
20	.3837	.381	.3723	.3807	.3772	.3784	.3814
21	.3765	.3605	.3704	.3776	.3749	.3681	
22	.205	.2077	.1997	.3768	.3334	.3624	.2073
23	.2	.2073	.2004	.2107	.2027	.3307	.2092
24	.2084	.2115	.2	.21	.2023	.2065	.2084
Max	.3841	.3829	.3807	.3818	.3818	.3784	.3814
Min	.2	.2065	.1997	.2	.2023	.202	.2042
Avg	.3359	.3329	.3313	.3440	.3374	.3473	.3313

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244070 / 33/11 KV KRIPAMAI

Feeder No / Name : 201 / 11 KV KRIPAMAYEE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5883	.0421	.6645	.672	.7236	.6646	.7703
2	.5475	.0419	.6127	.6294	.6914	.6222	.7202
3	.5334	.0398	.6078	.6184	.679	.6157	.7059
4	.5285	.0389	.602	.6049	.6687	.611	.6891
5	.5243	.032	.5948	.6272	.6619	.6213	.6586
6	.5736	.0467	.6234	.6876	.719	.664	.7358
7	.772	.061	.6504	.7668	.8065	.7657	.8188
8	.7703	.0516	.7125	.8156	.7918	.7799	.8297
9	.7751	.0648	.7449	.7708	.7245	.7577	.7707
10	.9	.0983	.8082	.8928	.7434	.8384	.8402
11	.9852	.1012	.8284	.8583	.7303	.8954	.9294
12	.964	.1103	.8779	.8528	.7687	.9913	.9726
13	.8772	.1069	.759	.8745	.7865	.9326	.9227
14	.7264	.08	.628	.9412	.7068	.7722	.6788
15	.7495	.1015	.6344	.8438	.7469	.4209	.7674
16	.7153	.1107	.6386	.7752	.7053	.0373	.7592
17	.6828	.0962	.6611	.7179	.612	.5802	.696
18	.7059	.1063	.7518	.7785	.6238	.7705	.7009
19	.8848	.0993	.8612	.9497	.8532	.9562	.993
20	.9774	.0623	.945	1.0029	.9537	1.0612	.9164
21	.9233	.0653	.9046	1.0322	.9511	1.039	.9775
22	.8988	.0619	.8592	1.0048	.9372	1.0168	.9522
23	.8467	.0562	.828	.9541	.8909	.9467	.8696
24	.7251	.0617	.7129	.8557	.7738	.8932	.7379
Max	.9852	.1107	.945	1.0322	.9537	1.0612	.993
Min	.5243	.032	.5948	.6049	.612	.0373	.6586
Avg	.7573	.0724	.7296	.8136	.7604	.7606	.8089

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244070 / 33/11 KV KRIPAMAI

Feeder No / Name : 202 / 11 KV GMIE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6424	.7217	.74	.6767	.6127
2	.6203	.7232	.7651	.7072	.6066
3	.5952	.7263	.7331	.7194	.6219
4	.5944	.7133	.6767	.679	.6173
5	.6501	.6843	.6386	.7072	.631
6	.6234	.6386	.6333	.6638	.586
7	.6127	.6211	.6142	.6615	.5563
8	.5563	.5563	.6325	.679	.5525
9	.6562	.5898	.6462	.5723	.5426
10	.7461	.7522	.7392	.5815	.5548
11	.8002	.7926	.7735	.6767	.57
12	.8558	.8512	.7727	.6554	.4999
13	.7308	.7575	.7667	.5708	.4473
14	.679	.807	.8246	.5685	.3422
15	.7011	.8154	.8444	.6249	.3376
16	.7331	.8749	.868	.628	.3285
17	.7987	.8825	.836	.6341	.3239
18	.8109	.788	.5784	.5815	.3246
19	.7781	.6371	.5548	.628	.3323
20	.7186	.612	.4961	.6127	.33
21	.5456	.442	.4344	.5578	.3368
22	.4313	.3864	.5586	.4854	.4481
23	.5959	.647	.679	.6158	.4367
24	.6767	.7225	.6821	.6409	.4245
Max	.8558	.8825	.868	.7194	.631
Min	.4313	.3864	.4344	.4854	.3239
Avg	.6730	.6976	.6870	.6303	.4735

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244070 / 33/11 KV KRIPAMAI

Feeder No / Name : 203 / 11 KV INDIAN OIL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6135	.6257	.6661	.6081	.7217	.7034	.7164
2	.57	.5921	.615	.5929	.6493	.6417	.6539
3	.5578	.5571	.5898	.5838	.6356	.6211	.6409
4	.5525	.5434	.5746	.5799	.6241	.6112	.6203
5	.5617	.5571	.5761	.5807	.6295	.618	.6226
6	.6203	.6211	.628	.6417	.6897	.6523	.6973
7	.6813	.6668	.6356	.7217	.7308	.7026	.7118
8	.7705	.7423	.6943	.8253	.8543	.7644	.8246
9	.9191	.8383	.7331	.9793	1.0814	.8924	.9054
10	1.0044	.9122	.743	1.028	1.1424	1.0044	.9518
11	.9998	.9396	.7148	1.1355	1.1332	.9968	1.0578
12	.9915	.9785	.7171		1.1462	1.0677	1.0966
13	.9823	1.0021	.7194	1.1645	1.0837	1.0943	1.0799
14	.8932	.8993	.7072	1.1728	1.0623	1.0524	.9663
15	.8939	.9153	.6722	1.0639	1.0707	1.0189	.9229
16	.8794	.8741	.618	1.0677	1.0235	1.0014	.932
17	.8391	.8665	.6516	.98	.9877	.9236	.9038
18	.8505	.852	.7331	.9678	.9793	.9823	.9534
19	1.009	1.0418	.8954	1.1904	1.1667	1.1919	1.0875
20	1.0593	1.0974	.9107	1.2224	1.1568	1.1561	
21	.9701	1.0059	.9221	1.1477	1.1027	1.1043	.8413
22	.8886	.932	.8893	.9808	1.0372	.9899	1.0029
23	.8009	.8429	.8139	.9214	.8954	.8977	.8695
24	.7004	.7407	.7179	.7796	.7857	.7926	.7263
Max	1.0593	1.0974	.9221	1.2224	1.1667	1.1919	1.0966
Min	.5525	.5434	.5746	.5799	.6241	.6112	.6203
Avg	.8170	.8185	.7141	.9103	.9329	.8951	.8602

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244070 / 33/11 KV KRIPAMAI

Feeder No / Name : 204 / 11KV WATER FILTER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2096	.2271	.2134	.2172	.2187	.2202
2	.2134	.2088	.2225	.2149	.2149	.2187	.218
3	.3033	.2751	.3041	.2942	.2911	.2926	.2942
4	.2926	.2942	.3064	.2942	.2911	.2949	.2957
5	.2904	.2919	.3003	.2942	.2911	.2949	.2919
6	.2934	.2926	.301	.2896	.2934	.2964	.2873
7	.2873	.301	.3018	.2926	.1669	.298	.2881
8	.2637	.2759	.2606	.266	.2576	.2721	.2622
9	.2675	.2797	.2599	.269	.2683	.2751	.2622
10	.2858	.2904	.2606	.2904	.269	.2858	.2804
11	.3041	.2972	.3147	.2873	.2782	.2865	.2972
12	.3102	.298	.3216	.2896	.3224	.2881	.3117
13	.33	.3163	.3361		.333	.3224	.3262
14	.3178	.314	.3429	.3041	.3315	.3208	.3208
15	.3033	.314	.3361	.3048	.3262	.3193	.3231
16	.3224	.3079	.3125	.3086	.3216	.314	.3361
17	.2995	.3231	.2896	.3163	.33	.3155	.3224
18	.285	.3742	.2896	.3307	.3346	.3201	.3254
19	.2896	.3498	.2942	.317	.3307	.3246	.3239
20	.3185	.3742	.314	.3064	.317	.317	.3338
21	.2942	.3422	.2827	.2865	.2934	.3056	
22	.2538	.2911	.2545	.2614	.2622	.2606	.2058
23	.2538	.2751	.2538	.2614	.2629	.266	.2119
24	.2309	.2187	.2119	.2279	.2393	.2789	.176
Max	.33	.3742	.3429	.3307	.3346	.3246	.3361
Min	.2058	.2088	.2119	.2134	.1669	.2187	.176
Avg	.2840	.2965	.2874	.2835	.2852	.2911	.2832

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244070 / 33/11 KV KRIPAMAI

Feeder No / Name : 205 / 11KV SIDHIVINAYAK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	***		***	
2	***		***		***
3	***		***		***
4	***		***		***
5	***				***
6	***				
12	***				
16	***				
Max	152.416	152.416	152.416	152.416	152.416
Min	152.416	152.416	152.416	152.416	152.416
Avg	152.416	152.416	152.416	152.416	152.416



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244070 / 33/11 KV KRIPAMAI

Feeder No / Name : 206 / 11KV GULMOHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1357	.1433	.1463	.1387	.1471	.1539	.1532
2	.1349	.1379	.1456	.1311	.1509	.1494	.1517
3	.1334	.1387	.144	.1326	.1433	.1478	.1486
4	.1357	.1364	.1501	.1288	.1478	.1501	.1532
5	.1433	.1463	.1494	.1395	.1456	.1555	.1562
6	.1753	.1768	.1661	.1623	.1844	.1829	.1799
7	.208	.1943	.1867	.2096	.1898	.2058	.1997
8	.208	.1867	.176	.2004	.1852	.1959	.1989
9	.282	.2507	.2225	.2416	.1951	.2561	.2423
10	.2423	.2218	.2103	.2042	.1745	.2263	.1974
11	.2271	.2393	.202	.1837	.1509	.2126	.2126
12	.2218	.2225	.1814	.1776	.1532	.218	.2149
13	.1638	.192	.1623	.1684	.1661	.2058	.1844
14	.2157	.2134	.1372	.1837	.1478	.2119	.1875
15	.2157	.2088	.1417	.1715	.1494	.218	.1859
16	.1974	.1943	.1456	.1593	.1425	.208	.1829
17	.1738	.1997	.1387	.1539	.1501	.1829	.1631
18	.1669	.1776	.1692	.1776	.1631	.1974	.1837
19	.2599	.2614	.2141	.2492	.2332	.2782	.2378
20	.2462	.2644	.218	.2462	.237	.2622	
21	.2263	.2164	.2073	.2271	.2195	.2248	.2469
22	.2096	.2172	.2065	.2073	.2096	.2065	.2111
23	.1829	.1875	.1661	.1898	.1936	.1882	.1791
24	.1501	.1631	.1448	.1631	.1654	.1677	.1616
Max	.282	.2644	.2225	.2492	.237	.2782	.2469
Min	.1334	.1364	.1372	.1288	.1425	.1478	.1486
Avg	.1940	.1954	.1722	.1811	.1727	.2002	.1884

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 201 / 11KV Jagdish IRON

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7246	1.8031	2.1773	2.2558	2.367	1.0136	1.848
2	2.1887	2.0683	2.2398	2.0797	2.3403	1.0745	1.7406
3	2.1788	2.2908	2.3609	2.3068	2.399	1.028	1.7901
4	2.2817	2.2268	2.3045	2.3594	2.3419	1.0463	1.7185
5	2.1895	2.2977	2.3403	2.3198	2.3518	.9991	1.5958
6	2.1887	2.1498	2.3967	2.2184	2.4021	1.0395	1.784
7	2.3007	2.2497	2.2519	1.9022	2.4592	.9709	1.7078
8	2.146	2.2344	2.2786	1.9768	2.3099	1.0197	1.5059
9	2.0508	1.528	2.1895	1.1767	.9175	.8848	1.1515
10	2.4082	2.1689	2.2588	2.0485	.5822	1.9372	2.2931
11	2.2954	2.0729	2.2725	2.271	.5716	2.4219	2.3983
12	2.5164	2.4737	2.3655	2.4257	.612	2.4821	1.9959
13	2.1155	2.2344	2.2108	2.3022	.6097	2.3327	2.3548
14	1.7284	1.8359	1.5386	1.6606	.57	1.8762	1.5188
15	2.2855	2.4501	2.223	1.5988	.5533	2.2657	2.6185
16	1.7695	2.5591	2.3906	1.5638	.5403	2.4089	2.4745
17	2.3205	2.351	2.0843	1.8107	.5403	2.2413	2.1704
18	2.4318	2.2794	2.2131	2.4211	.5738	1.7802	2.3838
19	2.4013	2.4097	2.3343	2.3845	.6272	1.7718	1.8915
20	2.4425	2.3304	2.3998	2.0873	.6059	1.8	2.3655
21	1.4609	2.3624	1.041	1.8549	.6516	.7583	1.1157
22	2.1605	2.3312	2.0363	2.335	.9656	1.8496	1.8526
23	2.3396	2.2695	2.3449	2.3975	1.0174	2.0088	1.9829
24	1.8122	2.303	2.2817	2.4044	1.0631	1.8496	2.3449
Max	2.5164	2.5591	2.3998	2.4257	2.4592	2.4821	2.6185
Min	1.4609	1.528	1.041	1.1767	.5403	.7583	1.1157
Avg	2.1557	2.2200	2.1889	2.0901	1.2489	1.6192	1.9418

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 202 / 11 KV Mahabal

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3756	1.3695	1.4182	1.4365	1.3146	1.2795	1.4853
2	1.2734	1.2902	1.2628	1.2361	1.2483	1.2399	1.5203
3	1.2864	1.2856	1.3474	1.3847	1.1972	.7537	1.4472
4	1.3222	1.3169	1.2917	1.2734	1.1919	.9015	1.4678
5	1.2376	1.2231	1.3085	1.3123	1.2285	1.0753	1.2932
6	1.294	1.3336	1.2833	1.3154	1.2102	1.2193	1.4319
7	1.3458	1.3748	1.2521	1.3999	1.1744	1.0837	1.3824
8	1.2757	1.3748	1.3054	1.4487	1.0189	1.3938	1.4121
9	1.4876	1.6827	1.1408	1.6187	.4649	1.2811	1.6042
10	1.6811	1.7764	1.7261	1.2887	.4687	1.1759	1.781
11	1.6049	1.9067	1.5706	1.5737	.4748	1.4632	1.8724
12	1.3717	1.861	1.6926	1.7314	.4801	1.5318	1.8808
13	1.5287	1.6438	1.5165	1.5722	.4748	1.4792	1.5318
14	1.2391	1.6095	1.4007	1.2986	.4816	1.1309	1.4746
15	1.6293	1.8549	1.6446	1.752	.4885	1.5082	1.7208
16	1.6834	1.7932	1.6369	1.294	.4915	1.752	1.9281
17	1.6651	1.8549	1.8038	1.31	.4847	1.9692	1.9753
18	1.611	1.592	1.8328	1.8107	.458	1.8419	2.0492
19	1.5798	1.5859	1.5181	1.4784	.618	1.6126	1.653
20	1.4533	1.4845	1.5615	1.3999	.7392	1.4457	1.512
21	1.4906	1.4487	1.4335	1.4548	1.2742	1.3557	1.5112
22	1.3923	1.403	1.3496	1.3573	1.2574	1.2856	1.4723
23	1.3946	1.2239	1.2399	1.2719	1.1523	1.4373	1.3268
24	1.3283	1.3626	1.3359	1.355	1.2369	1.4327	1.4601
Max	1.6834	1.9067	1.8328	1.8107	1.3146	1.9692	2.0492
Min	1.2376	1.2231	1.1408	1.2361	.458	.7537	1.2932
Avg	1.4396	1.5272	1.4531	1.4323	.8596	1.3604	1.5914

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 203 / 11KV Shreeji

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3948	.3757	.4039	.3734	.3765	.2256	.4047
2	.381	.3719	.3841	.365	.3719	.2309	.4031
3	.3788	.3628	.3742	.3559	.3612	.2286	.3841
4	.4115	.3521	.4077	.346	.3909	.2279	.3841
5	.3993	.3605	.3986	.3528	.3917	.2271	.3605
6	.3917	.3681	.4062	.3536	.3833	.237	.3521
7	.3772	.3483	.3864	.3483	.346	.2271	.3498
8	.3711	.3521	.3742	.3437	.3285	.2378	.3422
9	.7164	.7651	.6859	.6996	.2294	.6958	.7194
10	.7773	.8109	.7522	.772	.2164	.7857	.8253
11	.8322	.833	.8147	.7857	.2042	.8779	.8627
12	.8223	.8619	.8055	.7644	.2004	.8909	.8573
13	.6958	.7369	.6996	.7346	.2157	.8772	.711
14	.8261	.7796	.7514	.7842	.2103	.8962	.82
15	.8276	.8017	.7827	.823	.2119	.8794	.8589
16	.7385	.8238	.772	.8086	.2103	.8474	.8048
17	.7514	.7842	.7171	.7415	.0968	.8109	.8009
18	.7697	.8269	.711	.7019	.0541	.7788	.823
19	.7339	.7407	.6851	.6851	.2301	.74	.7491
20	.6485	.6691	.5815	.5891	.2309	.615	.6401
21	.3772	.3932	.4161	.3688	.2256	.4512	.4092
22	.3803	.3803	.3681	.3742	.2294	.3506	.362
23	.3589	.3887	.3437	.3696	.2324	.3307	.3292
24	.4153	.4062	.3795	.3818	.2241	.3932	.3909
Max	.8322	.8619	.8147	.823	.3917	.8962	.8627
Min	.3589	.3483	.3437	.3437	.0541	.2256	.3292
Avg	.5740	.5789	.5584	.5510	.2572	.5443	.5810

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 204 / 11KV JK ICE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9846	.9579	1.0646	1.0463	1.2064	1.0334	1.2361
2	.9907	.9694	1.0669	1.0669	1.1256	1.0319	1.121
3	1.0021	.9717	1.0768	1.0517	1.0288	1.0319	1.134
4	1.0067	.9625	1.0745	1.0372	1.0448	.9983	1.0951
5	.9229	.8916	1.0639	1.0608	1.0456	.9366	.9938
6	.9587	.9023	1.0661	1.0509	1.0463	.964	1.0059
7	.9777	.8863	1.0936	1.0745	1.0433	.9998	.9938
8	.9595	.9739	1.1873	1.342	1.025	.9755	1.0364
9	1.2559	1.3984	1.4876	1.5684	1.0037	1.0966	1.2468
10	1.6987	2.0218	1.7032	2.0729	.9008	1.4472	1.9265
11	1.8884	2.127	1.6712	2.239	.9175	1.6438	1.9029
12	1.9113	2.1757	1.3664	2.2565	.9343	1.9151	1.8801
13	1.6994	1.922	1.166	2.1331	1.0319	1.701	1.6369
14	1.8084	1.6385	1.1675	2.1247	1.0181	1.6712	1.858
15	2.0904	1.7795	1.4213	2.2192	1.0174	1.8404	2.0149
16	2.1209	2.0774	1.7139	2.0904	.9899	2.1346	2.0287
17	2.0157	2.0469	1.7581	1.9479		1.9761	2.0195
18	1.624	1.8747	1.4868	1.9303	.823	2.0439	1.6598
19	1.1096	1.2125	.9038	1.438	1.0189	1.3146	1.5996
20	.9214	1.0722	.8977	1.1172	.9617	1.0844	1.0479
21	.8406	.9221	.8756	.9976	.9191	1.1104	1.0532
22	.868	.9945	.9823	1.0067	.9663	1.1393	1.0303
23	.9854	1.0783	1.041	1.2262	1.0181	1.2369	1.2483
24	.9229	1.0806	1.0402	1.1988	1.0311	1.2452	1.1805
Max	2.1209	2.1757	1.7581	2.2565	1.2064	2.1346	2.0287
Min	.8406	.8863	.8756	.9976	.823	.9366	.9938
Avg	1.3152	1.3724	1.2240	1.5124	1.0051	1.3572	1.4146

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 205 / 11KV Shakti

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0898	.977	1.0997	1.0113	1.5638	.6356	.8772
2	1.1172	.9602	1.169	1.0044	.9221	.6356	.8802
3	1.0494	.9709	1.1233	.9518	.9595	.6356	.7948
4	1.1035	.9694	1.1164	.9983	.9389	.6379	.8596
5	1.0601	1.0037	1.1942	.9617	.9183	.6386	.7857
6	1.0166	.9595	1.2109	.9617	.8909	.6432	.8558
7	1.1591	.964	1.182	.9427	.8916	.6302	.8619
8	1.1507	.9351	1.2361	.9396	.5777	.727	.9625
9	1.4502	1.1279	1.6773	1.0219	.6394	.9899	1.1553
10	1.6278	1.1759	1.6758	1.3763	.6219	1.2117	1.3001
11	1.8435	1.4106	1.6674	1.7177	.5304	1.7269	1.8663
12	2.0477	1.7543	2.0005	1.8061	.535	2.082	1.9768
13	1.4022	1.6347	1.7642	1.816	.5792	1.938	1.9037
14	1.7276	1.7459	1.6789	1.5813	.5708	1.6331	1.6369
15	1.8176	1.8374	2.0393	1.9311	.4588	1.9479	1.7444
16	1.7032	1.8625	1.8999	1.5249	.3422	1.8206	1.7779
17	1.7551	1.8823	1.7718	1.845	.5517	1.909	1.2628
18	1.768	1.3687	1.688	1.9585	.6127	1.8656	1.2018
19	1.3146	1.3756	1.1698	1.7764	.6401	1.3352	1.3923
20	1.2551	1.2986	1.1332	1.9243	.647	1.2841	1.0463
21	1.2841	1.0921	.996	1.6331	.6516	1.073	.945
22	1.1706	1.0075	1.0273	1.5935	.6462	.9191	1.0151
23	1.1881	1.0288	.993	1.8793	.6516	.9579	.9054
24	.9983	1.0463	.9442	1.5051	.6455	.8665	.7735
Max	2.0477	1.8823	2.0393	1.9585	1.5638	2.082	1.9768
Min	.9983	.9351	.9442	.9396	.3422	.6302	.7735
Avg	1.3792	1.2662	1.3941	1.4443	.7078	1.1977	1.1992

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 206 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.643	1.4586	1.4213	1.4121	1.3009	1.1622	1.6148
2	1.627	1.6248	1.4495	1.6636	1.2727	1.1248	1.5813
3	1.448	1.4807	1.4152	1.3435	1.2978	1.2239	1.6453
4	1.4922	1.4342	1.4525	1.3298	1.1469	1.1134	1.5676
5	1.4693	1.6065	1.1911	1.3314	1.1043	1.118	1.4723
6	1.4769	1.4533	1.1416	1.3123	1.0578	1.1591	1.31
7	1.5066	1.5798	1.1218	1.342	1.044	1.2186	1.4358
8	1.5364	1.6209	1.2132	1.2041	1.1294	1.2513	1.3847
9	1.7535	1.7353	1.2452	1.5005	.9206	1.6042	1.6331
10	2.1361	1.9997	1.4022	1.4952	.599	1.8221	1.9311
11	2.2116	2.2009	1.701	1.8381	.5853	1.9311	1.9906
12	2.3579	1.9646	1.8077	1.9829	.612	2.1422	1.9761
13	2.069	1.8442	1.832	1.7833	.615	2.1597	1.9433
14	2.0751	2.0607	1.7741	1.7977	.6173	1.9974	1.8701
15	2.3884	2.2611	2.0447	2.1635	.6059	2.1887	1.9654
16	2.4097	2.1353	2.0073	2.0652	.618	2.3091	2.0683
17	2.3518	1.8755	1.9281	1.8999	.663	2.2809	2.0416
18	2.3061	2.0401	2.0195	1.7147	.6744	2.2428	1.9273
19	1.9875	1.5821	1.8145	1.3961	.8505	1.8747	1.6316
20	2.1361	1.5287	1.7756	1.5287	.7316	1.6941	1.7962
21	1.6796	1.4617	1.6758	1.2711	.8733	1.6309	1.704
22	1.6705	1.4845	1.6758	1.4098	.9343	1.5828	1.8275
23	1.5508	1.5303	1.5745	1.3855	.9313	1.6918	1.5348
24	1.5485	1.4594	1.5394	1.4495	1.0814	1.6225	1.6705
Max	2.4097	2.2611	2.0447	2.1635	1.3009	2.3091	2.0683
Min	1.448	1.4342	1.1218	1.2041	.5853	1.1134	1.31
Avg	1.8680	1.7260	1.5927	1.5675	.8861	1.6728	1.7301

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 207 / 11 KV Priyanka

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-SEP-17	23-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1014	.1036	.0533		.109
2	.1006	.1036	.0526		.1082
3	.1059	.1029	.0404		.1082
4	.1067	.1036	.0457		.1075
5	.1067	.1029	.0419		.1075
6	.1067	.1105	.032		.1075
7	.1052	.1257			
8		.1364			
9		.1273			
10	.0396	.1311		.0358	.0251
11	.0442	.1288	.0038	.0876	.0678
12	.1471	.1417	.0671	.1082	.1456
13	.1562	.1494		.1303	.1456
14	.1379	.1501		.1379	.1456
15	.0572	.1395		.1433	.1768
16	.0633	.1349		.1448	.1783
17	.0221	.1303		.1372	.1585
18	.0213	.1326		.1097	.1219
19		.029		.0655	.0008
20		.0023		.0023	
22	.0297			.0785	
23	.112			.1158	.1021
24	.1036			.1128	.1143
Max	.1562	.1501	.0671	.1448	.1783
Min	.0213	.0023	.0038	.0023	.0008
Avg	.0878	.1143	.0421	.1007	.1128



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 401 / 33KV Super Craft Foundry      NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / OUTGOING      (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	5.4527	5.4012	5.1269	5.0926	1.4746	5.0926
2	1.4403	4.9554	5.6756	5.5384	4.9211	1.4918	5.4698
3	4.784	5.3498	5.0412	5.3327	4.8011	1.4918	5.3327
4	4.8697	5.3327	5.2469	5.4012	5.1097	1.4918	5.4698
5	5.487	5.4527	5.4012	5.4698	5.3841	1.3032	5.3669
6	5.2469	5.0926	5.3327	5.4698	4.9211	1.3203	5.3498
7	5.4012	5.2812	5.4184	5.4355	4.9726	1.3032	5.6756
8	5.2298	5.3669	5.4184	5.727	4.3381	1.4575	5.487
9	5.0755	5.727	5.7956	5.4355	3.275	1.4918	5.7442
10	5.4527	5.6242	5.6413	5.5899	3.738	1.6461	5.727
11	5.2812	5.487	5.5899	5.1097	1.2689	2.2805	5.2469
12	5.5384	5.6584	5.8985	5.607	1.2689	4.0638	5.8299
13	5.4184	5.6756	5.8814	5.5727	1.2346	1.3717	5.6242
14	5.3327	5.6584	5.4355	5.6242	1.2346	1.3717	5.3498
15	5.2812	5.2984	5.5041	5.4527	1.2517	1.7833	5.3327
16	5.2641	5.8985	5.7613	5.2812	1.4403	2.1776	4.784
17	5.5899	5.4012	5.5727	5.5213	1.3717	2.0919	5.9156
18	5.4012	5.7099	5.6756	5.5384	1.2346	3.4808	5.5041
19	5.8814	5.5384	5.5213	5.6242	1.2346	2.8292	5.7613
20	5.6413	5.6413	5.5213	5.3498	1.2517	4.5439	5.1269
21	5.6927	5.6927	5.727	5.7785	1.2689	4.6468	5.607
22	5.4355	5.7099	5.144	5.6584	1.286	4.7668	5.2812
23	5.1097	5.3669	4.9383	5.0069	1.286	5.2298	5.1097
24	5.4184	5.6242	5.1783	4.9897	1.4575	5.6413	4.5953
Max	5.8814	5.8985	5.8985	5.7785	5.3841	5.6413	5.9156
Min	.7716	4.9554	4.9383	4.9897	1.2346	1.3032	4.5953
Avg	5.0019	5.4998	5.4884	5.4434	2.6935	2.5313	5.4077

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 248004 / 220 KV MIRAJ

Feeder No / Name : 401 / 33 KV SAHYADRI STARCH  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-SEP-17	23-SEP-17	24-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)
1			2.7435
2			1.8861
10		.3772	
11		1.2003	
12		1.2346	
13		1.1317	
14		.9945	
15		.9945	
16		.9602	
17		.9259	
18		.9602	
19	.7545	.7888	
20	2.2291	.7888	
21	.6173	.7888	
22		.7888	
23		1.6461	
24		1.989	
Max	2.2291	1.989	2.7435
Min	.6173	.3772	1.8861
Avg	1.2003	1.0380	2.3148

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 248004 / 220 KV MIRAJ

Feeder No / Name : 403 / 33 KV MIRAJ

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-SEP-17	23-SEP-17	25-SEP-17	26-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	17.3526	16.2552	15.8436	18.6557	20.096
2	16.6667	15.4321	15.0206	17.8327	18.8615
3	16.4609	15.0892	14.952	17.4897	18.2442
4	16.7353	15.0892	15.0206	17.5583	17.3526
5	17.5583	15.9808	15.5693	18.5185	18.2442
6	21.9479	21.1249	18.5871	24.9657	24.6228
7	18.9301	19.5474	18.3128	22.2908	23.6626
8	25.2401	24.3485	23.2511	22.2223	20.7133
9	26.8862	26.749	25.926	24.3485	21.9479
10	29.081	***	28.1208	26.4747	22.428
11	28.738	29.9726	27.2291	26.8176	22.9081
12	28.4637	29.6297	27.1605	26.3375	29.4925
13	28.5323	***	25.6516	23.594	29.6297
14	23.594	28.3951	24.8286	22.0165	27.5035
15	22.771	28.6009	24.0741	21.0563	27.3663
16	15.5007	19.4788	17.1468	17.3526	17.284
17	12.0028	13.786	13.5117	13.1002	13.3059
18	13.8546	14.6091	14.4719	14.129	16.3923
19	18.3814	18.8615	20.096	19.5474	18.7929
20	21.262	21.605	22.2908	21.262	18.3128
21	20.6447	21.0563	21.7421	21.0563	19.6159
22	19.5474	19.8217	19.6159	20.5076	18.9987
23	22.9767	27.7778	25.3773	27.6406	20.1646
24	19.3416	23.594	21.8107	23.6626	18.7243
Max	29.081	30.5899	28.1208	27.6406	29.6297
Min	12.0028	13.786	13.5117	13.1002	13.3059
Avg	20.9363	21.9965	20.6505	21.1849	21.0277

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 248004 / 220 KV MIRAJ

Feeder No / Name : 404 / 33 KV Madhavnagar

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	10.7682	13.3059	12.3457	8.9163	13.1002	7.8189	11.7284
2	11.0425	13.3059	10.6996	9.3279	11.3855	7.6818	11.7284
3	11.1797	12.6886	13.1687	8.642	12.2085	7.6132	13.1687
4	12.963	12.6886	12.8944	9.1221	12.1399	8.1619	12.963
5	11.6598	12.62	12.7572	9.465	12.4829	8.1619	12.7572
6	12.0028	12.4829	13.4431	10.0137	12.4829	7.8875	13.1687
7	12.8258	11.9342	13.9232	12.963	12.0713	8.1619	11.4541
8	12.2085	12.4829	14.3347	12.1399	11.6598	8.5734	11.6598
9	12.963	13.0316	13.4431	13.0316	7.9561	12.62	13.0316
10	16.8039	16.2552	19.1358	15.9122	7.8875	18.2442	17.9013
11	19.4788	17.0096	19.4102	18.8615	7.2017	17.9698	18.7929
12	19.2044	17.2154	19.4788	19.3416	7.8189	16.8725	18.9301
13	17.8327	17.0782	16.941	15.0206	7.8189	16.2552	16.3923
14	16.4609	17.4897	15.6379	15.9122	7.8189	15.6379	15.7751
15	15.0892	19.5474	16.2552	17.9698	8.2991	17.7641	18.5185
16	18.5185	19.4102	17.9698	17.8327	7.8189	18.3814	18.0384
17	19.1358	19.3416	18.6557	17.0096	7.5446	18.107	17.7641
18	18.3128	17.2154	17.4897	16.6667	6.9959	18.6557	17.9698
19	17.284	15.0892	15.8436	15.7065	7.8189	17.9698	16.3923
20	16.118	15.0892	15.5007	13.3059	7.9561	16.5295	14.1976
21	14.1976	12.7572	7.2017	12.963	7.8189	12.4143	12.4143
22	13.9232	13.3745	9.3279	12.8258	8.0933	13.1687	11.1797
23	13.9232	13.2373	9.2593	13.3745	8.3676	13.5117	11.5912
24	13.5117	13.3745	9.465	13.1002	8.0933	13.0316	11.3169
Max	19.4788	19.5474	19.4788	19.3416	13.1002	18.6557	18.9301
Min	10.7682	11.9342	7.2017	8.642	6.9959	7.6132	11.1797
Avg	14.892	14.9177	14.3576	13.7260	9.2850	13.3831	14.5348

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 248004 / 220 KV MIRAJ

Feeder No / Name : 406 / 33KV KRIPAMAAI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	13.8546	7.3045	16.3238	7.4074	15.6721	7.0645	16.9067
2	13.4774	7.1331	15.7064	7.4074	14.8491	7.3045	16.118
3	13.4773	7.2359	15.7064	7.5446	15.2264	7.5103	16.3238
4	13.4774	7.1331	15.3636	7.4417	15.0206	7.4074	15.8779
5	13.6831	7.0988	15.0206	7.6475	15.0549	7.3045	16.0151
6	14.8148	7.6475	15.5007	7.9904	15.3636	7.8875	17.0096
7	16.2552	8.2305	16.0494	8.882	16.941	8.5734	17.8669
8	16.6667	7.8875	16.4267	9.1564	17.2154	8.6763	18.2785
9	19.2387	8.882	17.5926	9.4993	17.7641	9.3622	19.5817
10	20.3018	9.6365	18.8957	9.808	18.4843	9.808	20.4733
11	20.8848	10.1509	19.1701	10.2195	18.107	9.4993	20.9534
12	20.7134	10.1509	18.93	3.3265	18.0041	10.2195	21.5364
13	19.5817	9.7737	17.764	8.5734	17.5241	9.808	20.6448
14	18.1413	9.6022	17.4898	9.808	16.4267	9.7394	19.7189
15	18.6558	9.7737	17.4212	9.5679	16.4267	8.7792	19.6846
16	17.9012	9.4993	16.7352	9.3964	15.8093	7.7161	19.2044
17	17.4212	9.4993	16.7009	9.0192	14.7119	9.2593	18.3814
18	17.6612	9.2936	17.0782	9.3279	15.0549	9.808	18.9301
19	21.022	10.5624	19.2044	10.9397	18.9643	11.0082	21.0563
20	21.3992	10.9397	18.6901	11.0425	19.0672	11.0082	
21	18.8614	9.7051	18.1756	10.4938	18.45	10.5967	18.0041
22	17.5927	9.0535	17.8669	9.4993	18.0727	9.7394	19.2044
23	17.0439	9.1564	18.2785	9.6022	17.9698	9.6708	17.2497
24	15.8779	8.6763	16.3924	8.5048	15.4665	9.1907	16.2552
Max	21.3992	10.9397	19.2044	11.0425	19.0672	11.0082	21.5364
Min	13.4773	7.0988	15.0206	3.3265	14.7119	7.0645	15.8779
Avg	17.4169	8.9178	17.1868	8.8377	16.7353	9.0392	18.4902

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 248004 / 220 KV MIRAJ

Feeder No / Name : 407 / 33KV MIDC MIRAJ

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	27.7778	***	***	***	16.3238	29.5611
2	***	28.8752	***	***	28.4637	16.7353	29.3553
3	***	28.8066	***	***	27.3663	15.3635	28.8066
4	***	29.4925	***	***	28.2579	15.2949	26.8176
5	***	28.3265	***	***	27.2291	15.8436	26.749
6	***	28.4637	***	***	26.2689	16.0494	25.5144
7	***	28.9438	***	***	26.8862	16.3238	25.926
8	***	28.6694	***	***	23.5254	17.0096	25.1715
9	***	***	***	***	17.3526	22.5652	28.3265
10	***	***	***	***	12.4143	***	***
11	***	***	***	***	12.1399	***	***
12	***	***	***	***	12.2085	***	***
13	***	***	***	***	12.4143	***	***
14	***	***	***	***	12.5515	25.6516	***
15	***	***	***	***	12.62	***	***
16	***	***	***	***	11.7284	***	***
17	***	***	***	***	11.1111	***	***
18	***	***	***	***	8.9163	***	***
19	***	***	***	***	13.2373	***	***
20	***	***	***	***	13.6489	28.8066	***
21	***	28.8066	***	***	14.6091	25.1029	29.3553
22	***	29.081	***	***	14.8148	26.5432	28.3951
23	***	29.4925	***	***	15.8436	28.8066	28.4637
24	***	***	***	***	16.1866	29.1496	***
Max	56.5616	42.1811	52.7892	55.3498	31.6187	38.7518	41.7696
Min	32.0531	27.7778	34.6366	34.2936	8.9163	15.2949	25.1715
Avg	44.3150	33.4906	43.1309	43.2919	17.9756	26.5633	32.7704

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 248004 / 220 KV MIRAJ

Feeder No / Name : 408 / 33 KV Sunrise

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	22-SEP-17
HR	Load (MW)
12	.9145
13	.9145
14	.9145
15	.9145
Max	.9145
Min	.9145
Avg	.9145

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 201 / 11KV JACKWELL LIS

Feeder KV- 11 / OUTGOING

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8337	.8253	.7705	.8238	.7727	.8612	.7819
2	.8314	.8284	.7697	.8261	.7895	.8589	.7781
3	.8391	.8299	.7712	.8261	.7872	.8581	.7705
4	.8406	.8291	.7697	.8269	.7888	.849	.6234
5	.8467	.7545	.7727	.823	.7895	.8436	.7796
6	.8467	.8314	.7804	.8284	.7994	.849	.788
7	.8368	.8261	.7446	.8269	.772	.836	.7743
8	.8391	.836	.7781	.8314	.7727	.8436	.775
9	.8505	.8352	.7758	.823	.7766	.8558	.7933
10	.8337	.8627	.7895	.8307	.3864	.8604	.7933
11	.6386	.8612	.8314	.7285	.3772	.7019	.8177
12	.6356	.8391	.8185	.8444	.378	.8512	.8413
13	.631	.8314	.7888	.8314	.3368	.8169	.8398
14	.7895	.8322	.8398	.8512	.234	.8223	.849
15	.7903	.8421	.8276	.8558	.1555	.8246	.7682
16	.7682	.6958	.8139	.8497	.1539	.7232	.7072
17	.7811	.5799	.6752	.8474	.378	.8139	.7202
18	.7743	.7049	.6813	.8505	.3826	.8208	.8711
19	.7537	.8467	.6805	.7179	.5373	.8078	.8543
20	.631	.708	.535	.6988	.5266	.6783	.7057
21	.6234	.6798	.6828	.6821	.7004	.6683	.6889
22	.6645	.6584	.6622	.6485	.6988	.6356	.6615
23	.8246	.7811	.8299	.7499	.7034	.7834	.8109
24	.8223	.7781	.8284	.7788	.8436	.7834	.8025
Max	.8505	.8627	.8398	.8558	.8436	.8612	.8711
Min	.6234	.5799	.535	.6485	.1539	.6356	.6234
Avg	.7719	.7874	.7591	.8001	.5767	.8020	.7748



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 202 / 11KV GANPATI MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.743	.7567	.8192	.743	.8284	.8101	.8474
2	.6958	.6767	.7766	.7049	.7567	.7499	.7918
3	.6828	.6622	.7407	.6889	.7346	.7232	.7583
4	.695	.6714	.7583	.6828	.7346	.7148	.756
5	.6912	.6661	.7697	.6988	.7476	.7293	.7506
6	.7644	.7712	.7926	.7933	.8269	.8131	.8223
7	.775	.7849	.7682	.8139	.8535	.8444	.8208
8	.8497	.8169	.8291	.8558	.8505	.8391	.8672
9	.8505	.8909	.8535	.8718	.8833	.8863	.8855
10	.8589	.8848	.8817	.8421	.8772	.9015	.8993
11	1.0113	.9793	1.0463	.9587	1.057	1.1218	1.089
12	.756	1.0806	1.105	.9755	1.0639	1.1576	1.2003
13	1.4426	1.0776	1.1149	1.0021	1.0844	1.1988	1.2109
14	1.182	1.0974	1.0059	.9412	1.1104	1.1546	1.134
15	1.0143	1.0128	.9511	.916	1.1043	1.0997	1.0113
16	.9572	1.0227	.9351	.8977	1.0715	1.0928	1.0174
17	.9701	1.028	1.0105	.9244	1.0372	1.0966	1.0532
18	1.041	1.1111	1.217	1.0319	1.262	1.2231	1.201
19	1.5988	1.6148	1.563	1.5127	1.672	1.7734	1.7261
20	1.6385	1.7444	1.5508	1.544	1.7055	1.7779	1.701
21	1.5554	1.6621	1.4632	1.4975	1.608	1.6232	1.5386
22	1.2399	1.2795	1.1485	1.2719	1.2917	1.3138	1.2346
23	1.0623	1.1279	1.0387	1.1157	1.1256	1.1546	1.0768
24	.8794	.9526	.8444	.9511	.932	.9739	.8703
Max	1.6385	1.7444	1.563	1.544	1.7055	1.7779	1.7261
Min	.6828	.6622	.7407	.6828	.7346	.7148	.7506
Avg	.9981	1.0155	.9993	.9682	1.0508	1.0739	1.0527

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 203 / 11KV SANGLI WADI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4923	.5175	.6135	.5091	.6066	.5738	.6043
2	.4786	.4862	.583	.4923	.5708	.5396	.57
3	.4702	.4763	.5723	.4839	.5624	.5274	.5578
4	.4755	.4771	.57	.4862	.5609	.5281	.5517
5	.5068	.506	.5944	.5266	.586	.5517	.5754
6	.7308	.7087	.759	.7415	.7484	.7522	.7651
7	.8002	.7758	.7758	.8063	.788	.8253	.8032
8	.7484	.7377	.7689	.7766	.7682	.7621	.7781
9	.6874	.6691	.7293	.6691	.6325	.6683	.6668
10	.644	.6409	.6965	.6135	.5921	.6417	.6219
11	.612	.6478	.6501	.6234	.5533	.6584	.6325
12	.5799	.6638	.6379	.6036	.4466	.6165	.6424
13	.5617	.6783	.6013	.5784	.5014	.5914	.6188
14	.5357	.6348	.5571	.5647	.5289	.6005	.5464
15	.4824	.5235	.4329	.5235	.5281	.5716	.4862
16	.4862	.5876	.5075	.5312	.4999	.5716	.4755
17	.5136	.5876	.5959	.5517	.4778	.5479	.5159
18	.586	.6287	.6882	.6226	.5914	.6371	.6264
19	.9275	.9648	.8398	.9808	.8993	.9496	.9526
20	.9465	.993	.9054	.9938	.9396	.9648	.9046
21	.916	.9595	.8345	.929	.9122	.9366	.8451
22	.8642	.9137	.8154	.9122	.8825	.9038	.8406
23	.7659	.8276	.7255	.8413	.7468	.8093	.7506
24	.6188	.6904	.5777	.6973	.6622	.679	.586
Max	.9465	.993	.9054	.9938	.9396	.9648	.9526
Min	.4702	.4763	.4329	.4839	.4466	.5274	.4755
Avg	.6429	.6790	.6680	.6691	.6494	.6837	.6632

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244080 / 33/11KV RISALA ROAD

Feeder No / Name : 204 / 11 KV SHIVAJI MANDAI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3315	.3406	.3727	.3429	.3795	.3666	.3681
2	.3109	.3109	.3361	.3147	.3521	.3338	.3437
3	.3079	.3048	.3384	.3079	.3399	.33	.333
4	.3163	.3048	.3315	.3109	.3399	.333	.33
5	.3185	.3117	.3376	.314	.3445	.3315	.3292
6	.3399	.3254	.3422	.3361	.3643	.3551	.346
7	.362	.3704	.3688	.3711	.3986	.381	.3765
8	.4001	.3879	.3887	.4016	.4283	.4298	.4153
9	.426	.4161	.4108	.4336	.455	.4428	.4351
10	.4824	.4862	.458	.4824	.4694	.5068	.5266
11	.5799	.5533	.5403	.5959	.5655	.618	.6158
12	.6043	.5914	.5708	.6219	.5967	.6584	.6226
13	.5929	.5891	.5838	.6455	.631	.6653	.7019
14	.586	.5662	.5205	.6013	.6165	.644	.6645
15	.5396	.5418	.4694	.5685	.5807	.6089	.5784
16	.5388	.5251	.4649	.5647	.5716	.5937	.5792
17	.5411	.5418	.5114	.5746	.5693	.5838	.567
18	.5647	.5868	.5594	.5761	.6318	.628	.6264
19	.7865	.7979	.7346	.8253	.7895	.8093	.8345
20	.8352	.8756	.7331	.8893	.82	.8787	.8482
21	.7727	.8444	.7301	.8558	.7773	.8299	.7209
22	.6302	.692	.5799	.7019	.6203	.6569	.5792
23	.4938	.5403	.4786	.5281	.5075	.5075	.4862
24	.4031	.4374	.3856	.4382	.4237	.426	.4016
Max	.8352	.8756	.7346	.8893	.82	.8787	.8482
Min	.3079	.3048	.3315	.3079	.3399	.33	.3292
Avg	.5027	.5101	.4811	.5251	.5239	.5383	.5262

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 202 / 11KV SHAMRAO NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7179	.724	.8337	.6874	.8505	.8345	.8291
2	.6341	.644	.7354	.6257	.7567	.7308	.7537
3	.6043	.6066	.6866	.602	.7171	.7019	.7042
4	.5959	.6158	.676	.5998	.7049	.6843	.6973
5	.6005	.6196	.6584	.6051	.7087	.6828	.6996
6	.6622	.6562	.6752	.6424	.7308	.7171	.7499
7	.7263	.7461	.7141	.7369	.804	.7948	.8048
8	.7301	.7476	.7324	.7727	.82	.807	.7948
9	.7758	.7811	.7895	.791	.82	.7781	.7796
10	.7865	.7628	.8253	.7872	.8009	.7956	.7628
11	.791	.7933	.8124	.7727	.7933	.7819	.791
12	.8124	.8109	.8261	.8162	.756	.8269	.8116
13	.7903	.8497	.852	.823	.7255	.8383	.8017
14	.7659	.8253	.7095	.7872	.7125	.8276	.7865
15	.6767	.7941	.7209	.7918	.7072	.8261	.4633
16	.6668	.8078	.692	.7705	.6988	.8002	.7628
17	.6485	.7941	.6645	.7499	.6775	.7758	.724
18	.6912	.7827	.7598	.7956	.6897	.74	.7697
19	.9221	.9739	.9496	1.0395	.9366	1.0692	1.0883
20	1.1355	1.2201	1.0395	1.2734	1.1172	1.1949	.8794
21	1.1187	1.2018	1.0364	1.2536	1.118	1.1637	.868
22	1.0608	1.1256	.9732	1.1645	1.0951	1.1058	.9427
23	.98	1.0616	.9541	1.0966	1.0692	1.089	.98
24	.8893	.9541	.8269	.9991	.9717	.9854	.8162
Max	1.1355	1.2201	1.0395	1.2734	1.118	1.1949	1.0883
Min	.5959	.6066	.6584	.5998	.6775	.6828	.4633
Avg	.7826	.8291	.7976	.8327	.8242	.8563	.7942

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 204 / 11KV CIVIL HOSPITAL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0476	.6142	.6753	.6344	.6695	.6386	.6424
2	.0469	.5795	.6398	.6043	.6421	.5792	.6409
3	.0472	.5952	.6348	.6047	.6394	.5906	.602
4	.0453	.5461	.6321	.6161	.652	.5868	.599
5	.0488	.5994	.6306	.6161	.6558	.5929	.6066
6	.0469	.6238	.6462	.6394	.687	.6226	.6074
7	.0461	.6089	.6684	.6192	.6554	.6653	.644
8	.045	.623	.6363	.6264	.6935	.6432	.6508
9		.6653	.6935	.6611	.7004	.5586	.6203
10	.0526	.7446	.6474	.7403	.6284	.66	.6592
11	.0678	.7556	.674	.7571	.6097	.7202	.7095
12	.0541	.6695	.6543	.6775	.6112	.7004	.7194
13		.5735	.5918	.6383	.5159	.5639	.6104
14	.0004	.6283	.6363	.6615	.5525	.6081	.6196
15		.6509	.6215	.6611	.567	.66	.6127
16		.6409	.589	.6032	.3795	.6478	.6348
17	.0488	.652	.6062	.5815	.3567	.5876	.4763
18	.048	.6078	.5906	.6375	.3437	.5914	.6341
19	.0373	.676	.6756	.7023	.618	.6531	.6714
20		.7552	.6962	.6866	.6539	.7186	.6569
21		.727	.618	.7164	.6706	.6973	.6676
22		.7179	.612	.7552	.6996	.7171	.6874
23		.676	.5357	.7423	.5746	.6112	.583
24		.6588	.6393	.6287	.679	.6371	.5799
Max	.0678	.7556	.6962	.7571	.7004	.7202	.7194
Min	.0004	.5461	.5357	.5815	.3437	.5586	.4763
Avg	.0455	.6496	.6352	.6588	.6023	.6355	.6307

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 205 / Hanuman Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4268	.439	.5235	.4374	.5548	.5281	.5548
2	.4123	.4176	.4954	.4237	.5167	.503	.5243
3	.4009	.4108	.4877	.4153	.506	.4946	.5068
4	.4054	.407	.4915	.4184	.5022	.4931	.4954
5	.4329	.4291	.5136	.4443	.5167	.503	.5266
6	.5068	.5152	.5449	.5357	.6074	.5761	.6005
7	.5479	.5533	.5357	.5746	.6142	.5944	.5716
8	.5677	.5304	.5456	.5601	.5792	.5761	.5746
9	.5235	.5014	.5312	.5144	.5068	.519	.4923
10	.4519	.4557	.4931	.4466	.4313	.455	.4397
11	.4009	.4001	.4611	.4161	.3894	.423	.4176
12	.3757	.3986	.4512	.3925	.3612	.4146	.3955
13	.3567	.4176	.4024	.3963	.3963	.426	.3871
14	.346	.4191	.3978	.4245	.4153	.4451	.3506
15	.3422	.4207	.3955	.4207	.4199	.4451	.3574
16	.3315	.4146	.3833	.4024	.4047	.4336	.3597
17	.3384	.3993	.4374	.3879	.3734	.3826	.378
18	.4466	.4572	.5838	.5281	.4854	.5525	.5075
19	.7644	.7727	.7491	.8124	.7019	.8192	.772
20	.7918	.804	.7301	.8406	.7705	.8406	.7118
21	.7423	.7926	.676	.8307	.7705	.8101	.7423
22	.7255	.7766	.692	.8048	.7651	.7827	.7293
23	.6394	.7148	.6089	.7476	.7057	.7141	.6333
24	.5152	.6074	.4877	.6257	.6059	.631	.5129
Max	.7918	.804	.7491	.8406	.7705	.8406	.772
Min	.3315	.3986	.3833	.3879	.3612	.3826	.3506
Avg	.4914	.5190	.5258	.5334	.5375	.5568	.5226

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 206 / 11KV TRIMURTI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5868	.5639	.631	.5967	.6645	.6531	.692
2	.5594	.535	.5868	.5738	.6226	.6211	.6501
3	.5373	.4832	.5799	.5738	.6173	.6043	.6295
4	.5327	.4961	.5868	.5891	.6127	.618	.6295
5	.5296	.5037	.5975	.586	.6165	.6272	.6493
6	.5921	.567	.6219	.6257	.6767	.6706	.7019
7	.6821	.6577	.6104	.7026	.7308	.7651	.7499
8	.7278	.7057	.6577	.775	.7811	.7461	.7461
9	.7842	.7484	.7011	.7644	.7781	.7811	.7651
10	.8467	.7567	.7461	.8131	.8368	.8444	.8459
11	.964	.8878	.8345	1.0014	.9518	1.041	1.0151
12	.9587	.8893	.9038	1.0387	1.044	1.0837	1.0456
13	.9678	.9275	.8543	1.0166	1.0555	1.0921	1.0357
14	.9046	.9175	.7926	1.0014	1.0524	1.105	.9861
15	.8657	.9198	.7987	.9915	1.0425	1.0928	.9092
16	.8749	.9275	.759	.9633	1.0296	1.0456	.9351
17	.8749	.9328	.7788	.9633	1.0235	1.0113	.9747
18	.9137	.9198	.8817	1.0159	1.057	1.0883	1.0059
19	1.1104	1.1858	1.1164	1.2711	1.2887	1.2856	1.2437
20	1.1652	1.2315	1.1187	1.2849	1.2833	1.2772	1.1911
21	1.1347	1.1767	1.0578	1.2254	1.1873	1.2056	1.1164
22	1.0227	1.0753	.9762	1.0982	1.0997	1.0898	1.0197
23	.8299	.8764	.8505	.9198	.9145	.9084	.8253
24	.6531	.7293	.6798	.7598	.7697	.7682	.6828
Max	1.1652	1.2315	1.1187	1.2849	1.2887	1.2856	1.2437
Min	.5296	.4832	.5799	.5738	.6127	.6043	.6295
Avg	.8175	.8173	.7801	.8813	.9057	.9177	.8769

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 403 / 33 KV RISALA ROAD

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.9328	6.31	6.9616	13.1688	13.786	13.203	6.5844
2	5.5213	5.8985	6.4815	12.2086	12.62	12.0714	6.1386
3	5.4184	5.7956	6.3786	11.214	12.1743	11.7284	5.9671
4	5.4184	5.7613	6.3443	11.0426	12.14	11.5912	5.8642
5	5.4527	5.7956	6.3786	11.0769	11.8999	11.4883	5.8985
6	6.0357	6.1728	6.653	11.8313	12.5857	12.2771	6.3443
7	6.3786	6.6187	6.6187	12.8601	13.2717	13.9575	6.7558
8	6.653	6.8244	6.9273	13.8203	14.0261	14.9177	7.0302
9	7.1331	6.9273	7.3731	14.0947	14.3348	15.3979	7.2017
10	8.1276	7.7846	7.8532	15.1578	14.8148	16.3237	8.2305
11	9.2593	9.0192	8.7792	18.1071	17.1468	20.2332	9.1564
12	9.8766	9.9109	9.2593	19.9589	18.2099	21.5707	10.5624
13	9.6365	9.9794	9.3964	20.0274	16.3238	21.7079	11.0768
14	9.3279	9.7394	7.9904	19.4445	18.0384	20.6447	10.5624
15	8.9849	9.2936	7.8189	18.2442	17.4212	19.9588	8.8477
16	9.1907	9.3279	7.7161	18.6558	17.9698	20.439	9.0535
17	8.6763	9.3622	8.3333	18.2099	18.107	19.4788	9.1907
18	9.3279	9.5336	9.2593	17.3869	19.0673	19.4444	10.1166
19	12.2771	12.6543	11.3855	25.0686	22.9082	24.417	12.7229
20	12.9287	13.5803	11.1454	26.9891	24.6914	25.7545	12.5515
21	12.62	12.9287	10.7339	26.2689	24.417	24.6571	11.1797
22	11.0425	11.4198	9.6365	22.9424	21.7764	21.7764	9.9794
23	9.1221	9.5679	7.9561	19.6159	18.5871	18.347	8.4705
24	7.6475	8.2648	6.5158	16.2894	15.6036	15.6036	7.0645
Max	12.9287	13.5803	11.3855	26.9891	24.6914	25.7545	12.7229
Min	5.4184	5.7613	6.3443	11.0426	11.8999	11.4883	5.8642
Avg	8.4162	8.6863	8.079	17.2368	16.7467	17.7912	8.6063



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 404 / 33KV KOLHAPUR ROAD

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	9.8766	10.9054	11.6598	10.6996	11.5226	11.2483	12.0028
2	10.0137	10.1509	10.7682	9.7394	11.1797	10.9054	10.8368
3	9.8766	9.8766	10.5624	10.0137	10.974	10.7682	10.9054
4	9.5336	9.8766	10.5624	10.0137	10.8368	10.2881	10.5624
5	10.0137	9.7394	10.4253	10.2195	10.9054	10.9054	10.7682
6	11.5912	11.5912	11.5226	11.8656	12.2085	12.3457	11.9342
7	11.5912	11.7284	11.1797	11.8656	12.4829	12.0028	12.0713
8	12.3457	11.9342	11.4541	12.4829	12.0713	12.4143	12.2085
9	12.2771	12.2771	12.0028	12.5515	12.0028	12.4829	12.3457
10	12.4143	13.0316	12.7572	12.2771	11.3169	12.7572	12.8944
11	12.62	13.4431	13.2373	12.963	11.3855	13.9918	13.3745
12	12.0028	13.7174	13.5803	13.5117	11.5912	14.5405	14.1976
13	12.8944	14.129	12.2085	13.4431	11.5912	14.4033	14.1976
14	12.3457	13.3745	12.2085	13.0316	11.1111	13.5803	13.6489
15	12.2771	13.1002	12.3457	13.1002	11.2483	14.129	12.0028
16	12.3457	12.5515	12.0028	12.5515	10.9054	13.7174	12.5515
17	12.2085	11.9342	12.5515	13.4431	9.465	13.6489	12.963
18	12.8944	12.8258	13.0316	14.0604	11.7284	14.5405	13.9918
19	16.3238	17.0096	14.952	16.941	16.7353	18.45	18.45
20	17.2154	18.3128	15.7065	17.8327	17.284	17.9013	17.5583
21	16.4609	17.0096	15.5693	17.0782	16.3238	17.1468	15.7065
22	15.2264	15.6379	13.7174	15.5693	15.7751	15.9808	15.0892
23	13.9918	14.1976	12.62	15.0206	14.4719	14.5405	14.0604
24	12.1399	13.0316	11.8656	13.6489	12.8258	13.5803	11.6598
Max	17.2154	18.3128	15.7065	17.8327	17.284	18.45	18.45
Min	9.5336	9.7394	10.4253	9.7394	9.465	10.2881	10.5624
Avg	12.5200	12.9744	12.4371	13.0802	12.4143	13.5946	13.1659

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244092 / 33 / 11 KV KOLHAPUR ROAD

Feeder No / Name : 202 / 11 KV FRUIT MARKET

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.0008					.003	.0004
10	.0084		.0027	.0008	.0019	.0015	.0004
11	.0111	.0004	.0168	.0069	.0225	.0004	.0011
12	.0164	.0011	.0072	.008	.005	.0267	.0061
13	.0343	.0141	.0465	.0114	.0088	.0301	.0514
14	.0244	.0149	.021	.0065	.037	.003	.0564
15	.0179	.0099	.0396	.0152	.005	.032	.0297
16	.0392	.0107	.0423	.0278	.0564	.061	.0484
17	.0373	.0274	.0469	.0446	.0549	.0606	.0629
18	.0442	.0594	.0446	.0583	.0674	.0549	.0594
19	.0164	.0526		.0415	.0533	.0217	.0503
20		.0297		.003	.0004	.0057	.0126
21							.0004
Max	.0442	.0594	.0469	.0583	.0674	.061	.0629
Min	.0008	.0004	.0027	.0008	.0004	.0004	.0004
Avg	.0228	.0220	.0297	.0204	.0284	.0251	.0292

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244094 / 33\11 KV VIJAYANAGAR

Feeder No / Name : 402 / 33 KV KUPWAD CITY FEEDER NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.7215	6.9959	7.9561	7.2017	8.0933	8.0247	8.0247
2	6.4472	6.653	7.6132	6.9273	7.6818	7.6132	7.6818
3	6.3786	6.5158	7.5446	6.7901	7.5446	7.4074	7.4074
4	6.2414	6.4472	7.4074	6.653	7.476	7.3388	4.5268
5	6.5844	6.653	7.6132	6.7901	7.6818	7.2702	7.8189
6	7.8189	7.6132	8.2305	8.0933	8.7792	8.3676	8.7106
7	8.8477	8.9163	8.2305	9.3279	9.3964	9.6708	9.6022
8	9.0535	8.4362	8.7106	9.3964	9.6708	9.1221	9.5336
9	8.2305	7.9561	8.642	8.4362	8.642	8.1619	8.7792
10	7.6132	7.5446	8.1619	7.6818	7.5446	7.7504	7.7504
11	7.0645	6.9959	7.7504	6.9959	6.8587	7.1331	6.9273
12	6.31	6.5844	7.2017	6.8587	6.653	6.7901	6.7215
13	6.2414	6.5844	5.4184	6.5158	6.3786	6.7215	6.653
14	5.8985	6.5158	6.5844	6.1728	6.2414	6.8587	6.31
15	5.6927	6.653	6.31	6.1728	6.5844	6.7215	5.9671
16	5.6242	6.7901	6.1043	6.3786	6.3786	6.2414	5.9671
17	5.4184	6.3786	6.7215	6.5158	6.0357	6.5158	6.1728
18	6.3786	6.7215	7.8875	7.2017	6.653	7.5446	7.2702
19	9.3279	9.3964	8.7106	9.8766	9.3279	10.4253	8.7792
20	10.6996	11.1111	7.8875	11.3855	10.8368	11.4541	7.476
21	10.4253	11.1111	7.8189	11.1797	10.974	11.1797	10.3567
22	9.8766	10.631	9.808	10.4253	10.7682	10.7682	10.3567
23	8.9849	9.808	9.2593	9.8766	10.0137	10.1509	6.7901
24	7.9561	8.9849	8.0247	8.9163	8.9163	9.1221	6.7215
Max	10.6996	11.1111	9.808	11.3855	10.974	11.4541	10.3567
Min	5.4184	6.3786	5.4184	6.1728	6.0357	6.2414	4.5268
Avg	7.4932	7.8332	7.7332	7.9904	8.1305	8.2648	7.5960

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 246001 / 110/33/11 KV VISHRAMBAG S/SN

Feeder No / Name : 201 / 11 KV WALCHAND

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.4687	.4001	.4992	.522	.522	.4954
2	.4611	.4382	.3925	.4801	.5068	.4915	.4801
3	.4191	.423	.4534	.4496	.4687	.4725	.2705
4	.4039	.4077	.4344	.442	.4611	.4458	.2858
5	.4001	.4077	.423	.423	.4687	.4687	.3772
6	.4992	.4649	.4534	.4687	.5296	.5182	.3925
7	.5868	.5677	.5182	.5906	.6325	.602	.4687
8	.6897	.6821	.522	.6706	.7354	.6859	.6516
9	.7202	.7392	.4954	.724	.7964	.7697	.8383
10	.8764	.8421	.5449	.804	.8954	.8688	.9374
11	.8993	.8345	.5525	.8878	.9831	.9602	.964
12	.8497	.8154	.5754	.8954	.7773	1.0136	.964
13	.8535	.8002	.5373	.7697	.8993	.9297	.9412
14	.7964	.6897	.5716	.8078	.8497	.8688	.884
15	.823	.7087	.583	.8497	.9259	.884	.8497
16	.8154	.7049	.5258	.8269	.9602	.8993	.8573
17	.7583	.6821	.5601	.8078	.8345	.8612	.804
18	.6668	.6097	.602	.7545	.7392	.7278	.6821
19	.6592	.6478	.6744	.6363	.7506	.7506	.6897
20	.6821	.6592	.6249	.6897	.7773	.7545	.6668
21	.6401	.6249	.5982	.7545	.7278	.6744	.644
22	.5944	.6097	.6211	.7049	.6859	.663	.6287
23	.5373	.5487	.5944	.6592	.6363	.5944	.6135
24	.5068	.4534	.5639	.5754	.5639	.5449	.5716
Max	.8993	.8421	.6744	.8954	.9831	1.0136	.964
Min	.4001	.4077	.3925	.423	.4611	.4458	.2705
Avg	.6508	.6179	.5342	.6738	.7137	.7071	.6649

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 246001 / 110/33/11 KV VISHRAMBAG S/SN

Feeder No / Name : 207 / 11 KV DOORDARSHAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4877	.4992	.5525	.5258	.5868	.5754	.602
2	.4611	.4725	.522	.4915	.5487	.5563	.5487
3	.4649	.4496	.4992	.4839	.5296	.5335	.5335
4	.4611	.4496	.4992	.4877	.522	.5182	.5258
5	.4649	.4572	.503	.4877	.5182	.5258	.5335
6	.5525	.5601	.5601	.5868	.6173	.6173	.6211
7	.823	.7849	.6821	.8535	.884	.8078	.8497
8	.8573	.7811	.724	.8764	.8688	.823	.8383
9	.7926	.7545	.743	.7926	.8954	.7888	.7926
10	.7621	.7125	.7354	.7926	.7392	.7202	.7354
11	.6668	.6821	.7087	.7164	.6935	.724	.7011
12	.644	.6135	.6973	.6554	.6287	.6592	.6363
13	.5944	.6059	.6516	.6135	.583	.6173	.6173
14	.5182	.6059	.5716	.5563	.5754	.583	.583
15	.5068	.5411	.522	.522	.5373	.583	.522
16	.5106	.5373	.5373	.5296	.5258	.5525	.5373
17	.4992	.5563	.5944	.5525	.5335	.5754	.583
18	.6135	.663	.7087	.6859	.6516	.6821	.7125
19	.8688	.8688	.865	.9145	.8459	.9221	.8954
20	.8916	.9259	.8688	.9678	.8993	.9717	.8612
21	.8573	.8954	.8535	.9526	.8993	.9221	.8612
22	.8535	.865	.8078	.884	.8688	.8726	.8192
23	.7392	.8002	.7506	.8421	.804	.8116	.7468
24	.5944	.6363	.5944	.6668	.6821	.7011	.5944
Max	.8916	.9259	.8688	.9678	.8993	.9717	.8954
Min	.4611	.4496	.4992	.4839	.5182	.5182	.522
Avg	.6452	.6549	.6563	.6849	.6849	.6935	.6771

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-SEP-17 and 28-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 246001 / 110/33/11 KV VISHRAMBAG S/SN

Feeder No / Name : 209 / 11 KV INDUSTRIAL SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-SEP-17	23-SEP-17	24-SEP-17	25-SEP-17	26-SEP-17	27-SEP-17	28-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1888	1.2117	1.2498	1.2117	1.3489	1.3489	1.3717
2	1.1431	1.1584	1.2269	1.1431	1.2727	1.2727	1.3032
3	1.1355	1.1355	1.1888	1.1355	1.2574	1.2574	1.2803
4	1.1279	1.1279	1.1812	1.1279	1.2422	1.2422	1.2651
5	1.1431	1.1584	1.2193	1.166	1.2574	1.2498	1.2879
6	1.2955	1.2955	1.2727	1.3032	1.3717	1.3794	1.3946
7	1.4403	1.3565	1.2574	1.4098	1.4251	1.4937	1.4556
8	1.448	1.3641	1.326	1.4784	1.4784	1.4327	1.4556
9	1.387	1.2879	1.3184	1.3565	1.5699	1.3413	1.3489
10	1.3641	1.2803	1.2955	1.326	1.3794	1.3413	1.3336
11	1.3794	1.3032	1.2651	1.3717	1.3717	1.4251	1.4251
12	1.3413	1.3108	1.2422	1.3946	1.3717	1.4327	1.4632
13	1.2955	1.3108	1.2269	1.3946	1.387	1.448	1.4708
14	1.2422	1.2879	1.1203	1.4022	1.3717	1.4403	1.4556
15	1.1584	1.2498	1.0669	1.3641	1.3565	1.3946	1.2346
16	1.1736	1.2498	1.0745	1.3641	1.3565	1.4251	1.2803
17	1.2117	1.2574	1.1812	1.326	1.3184	1.3717	1.3032
18	1.2955	1.3413	1.3641	1.4784	1.4403	1.5165	1.4937
19	1.8823	1.9662	1.768	2.0652	1.9738	2.0652	2.1033
20	2.05	2.0881	1.829	2.1948	2.0424	2.111	1.989
21	1.9281	1.9966	1.768	2.0424	1.9738	1.9814	1.8976
22	1.7833	1.8442	1.7071	1.8671	1.8671	1.8747	1.7833
23	1.6385	1.669	1.5394	1.7071	1.7071	1.7375	1.5851
24	1.3641	1.4556	1.326	1.5013	1.4937	1.5165	1.3641
Max	2.05	2.0881	1.829	2.1948	2.0424	2.111	2.1033
Min	1.1279	1.1279	1.0669	1.1279	1.2422	1.2422	1.2346
Avg	1.3924	1.4045	1.3339	1.4638	1.4848	1.5042	1.4727