

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 201 / 11 Kv Hutatma

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4338	.6535	.6468	.6224	.5847	.567	.6348
2	.4338	.6535	.6535	.6224	.5658	.5487	.5788
3	.4338	.6535	.6535	.6224	.5601	.543	.5788
4	.4338	.7095	.6838	.6224	.5975	.543	.5601
5	.5281	.7842	.8589	.6602	.7282	.6154	.6535
6	.7545	.8589	.9511	.8676	.8962	.7362	.9055
7	.8676	1.0082	.9694	.8865	.961	.8589	.9896
8	.7095	.8775		.7682	.8048	.7865	.8131
9	.6219	.6722	.8048	.6154	.6089	.7059	.6219
10	.5487		.7095	.567	.6535	.5731	.6161
11	.5121	.6036	.6348	.5121	.6535	.5434	.5601
12	.5121	.5973	.6535	.499	.6154	.5959	.5041
13	.462		.6535	.5359	.5601	.5609	.5792
14	.4435		.6535	.5729	.5601	.5792	.6535
15	.4251		.6535	.5975	.5601	.6335	.5973
16	.4108		.6535	.5548	.5975	.6024	.5973
17	.6036		.7095	.4854	.5973		
18	.7095			.6379	.7602	.823	.8048
19	.8962			.8779	.8507	.9694	.9877
20	.9149	1.0745	.9877	.961	.961	.9145	.9795
21	.8048	1.0719	.8775	.9055	.9055	.8048	.961
22	.7468	.9511	.8215	.7316	.8316	.7842	.8501
23	.6535	.8589	.7468	.6468	.6722	.7282	.6908
24	.4715	.6535	.6838	.6413	.5847	.567	.6348
Max	.9149	1.0745	.9877	.961	.961	.9694	.9896
Min	.4108	.5973	.6348	.4854	.5601	.543	.5041
Avg	.5972	.7926	.7457	.6673	.6946	.6776	.7110

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 202 / 11 Kv Walwa Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5927	1.2003	1.2266	1.2574	.2218	.2263	.2241
2	1.5927	1.2003	1.1797	1.2574	.2033	.2263	.2241
3	1.5927	1.2003	1.1797	1.2574	.2033	.2075	.2241
4	1.5927	1.2003	1.278	1.2574	.1991	.2075	.2054
5	1.5927	1.2003	1.4586	1.2574	.2172	.2172	.2075
6	1.7635	1.2346	1.5912	1.3889	.2629	.2715	.2829
7	2.2382	1.7833	1.6575	1.543	.3439	.3326	.3361
8	.3292	.2987	.3012	.2715	.2427	.3086	.2772
9	.2561	.2587	.2172	2.1195	2.6791	2.7639	.2534
10	.2378		.2241	2.2466	2.915	3.086	.181
11	.2195	.1402	.1867	2.3137	3.0807	3.2217	.1991
12	.2195	.1526	.1867	2.3472	2.8807	3.2386	.1991
13		.1357	.1867	2.3807	2.7435	3.1878	.181
14		.1402	.1867	2.4143	2.7435	2.9843	.1896
15		.1578	.1867	2.4143	2.7435	3.1539	.1867
16	.1326	.1658	.1867	2.3739	2.6063	3.0521	.2172
17		.1658	.1867	.1966	.2801	.2155	.2172
18	.2321	.1823	.1677	.2229	.2829	.2715	.2561
19	.2896	.1989	.218	.2926	.3077	.3142	.2587
20	.3077	.2347	.2957	.3142	.3326	.2801	.2772
21	.2926	.2515	.2772	.2926	.2926	.2801	.2987
22	1.3717	1.1984	1.3748	.2614	.2772	.2427	2.8193
23	1.286	1.3108	1.3245	.2241	.2452	.2218	2.3712
24	1.6766	1.2003	1.2266	1.2742	.2218	.2263	.2241
Max	2.2382	1.7833	1.6575	2.4143	3.0807	3.2386	2.8193
Min	.1326	.1357	.1677	.1966	.1991	.2075	.181
Avg	.9408	.6614	.6877	1.2991	1.1053	1.1974	.4296

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 203 / 11 Kv.Bawachi LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.307	1.9022	2.1948	2.0119	2.0119	2.0485
2		1.9753	2.3777	2.0119	2.0119	2.0485
3		2.1216		2.0485	2.0485	2.1033
4		2.3045	2.3777	2.1948	2.1948	2.1948
5		2.524	2.3777	2.4143	2.3594	2.4691
6		2.6703	2.7252	2.5423	2.7069	2.7252
7		2.7069	2.8715	2.7435	2.7618	2.8349
8		2.7801	2.9447	2.8715	2.963	3.091
9		2.7949	3.1093	2.9813	3.0361	3.091
10		3.0247	3.0178	3.1181	2.963	3.0434
11	2.4691	3.0247	2.9264	3.1181	2.9813	3.0556
12	2.7618	3.1181	2.8715	3.0434	3.0178	3.0247
13	2.6703	3.0744	2.8898	2.9874	3.0178	2.9874
14	2.8349	3.0434	2.9264	2.95	3.0361	2.8567
15	2.8349	3.0434	2.9264	2.8006	3.0178	2.8006
16	.8413	1.6804	.9694	1.1576	1.4449	1.0642
Max	2.8349	3.1181	3.1093	3.1181	3.0361	3.091
Min	.8413	1.6804	.9694	1.1576	1.4449	1.0642
Avg	2.2456	2.6118	2.6338	2.5622	2.5983	2.5899

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 204 / 11 KV Padawalwadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.168	.1543	.1478	1.587	1.2793	1.2146
2	.1829	.168	.1543	.1478	1.587	1.2793	1.2146
3	.1829	.168	.1578	.1494	1.6194	1.2955	1.2146
4	.1829	.1886	.1753	.1478	1.7814	1.3279	1.2146
5	.2378	.2195	.2149	.1848	1.8138	1.3765	1.3603
6	.3292	.2926	.2507	.2801	1.9271	1.587	1.4413
7	.3841	.3734	.2507	.2926	1.9595	1.8299	1.4899
8	.2743	.2987	.2218	.2561	.2263	.2263	.2641
9	2.1052	2.1948	2.0995	.2012	.2263	.2263	2.3482
10	2.2211	2.5972	2.0576	.1829	.1886	.1829	
11	2.2542	2.2186	2.2291	.1829	.168	.1829	2.9492
12	2.2119		2.4863	.1646	.1867	.1829	2.915
13	2.13	2.0485	2.4863	.1463	.168	.1829	2.753
14	1.9334	2.0645	2.6595	.1463	.168	.168	2.753
15	1.7238	2.0165	2.4006	.1478	.168		2.4291
16	1.6221	1.8404	2.0576	.1867	.1867	.1097	2.3967
17	.1663	.1311	.2241	.2054	.1867		.168
18	.168	.1475	.1578	.2263	.2263	.2263	.197
19	.2896	.1989	.2534	.2829	.2829	.2829	.2328
20	.2987	.1989	.2402	.2641	.2829	.2452	.2715
21	.2378	.218	.2402	.2452	.2641	.2641	.2534
22	.2241	.2012	.2218	1.7814	1.3441	1.1012	.2218
23	.2241	.1677	.1848	1.668	1.3441	1.2308	.1991
24	.1829	.168	.1696	.2056	1.587	1.2793	1.2146
Max	2.2542	2.5972	2.6595	1.7814	1.9595	1.8299	2.9492
Min	.1663	.1311	.1543	.1463	.168	.1097	.168
Avg	.8313	.7952	.9062	.3268	.8117	.7303	1.3355

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 205 / 11 KV Hutatma Dudh Sangh NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.2241	.2614	.2054	.2195	.2195	.2743
2	.2054	.2241	.2614		.2195	.2195	.2195
3	.2054	.2241	.2241		.2195	.2195	.2195
4	.2054	.2241	.2241		.1829	.2195	.2195
5	.2054	.2427	.2427		.1829	.1829	.2743
6	.2987	.2801	.2427	.2614	.2195	.1829	.2926
7	.2801	.2987	.2614	.2614	.2195	.2195	.3109
8	.2614	.2427	.2614	.2427	.2195	.2195	.2926
9	.2987	.3361	.2987	.4481	.2195	.2743	.3109
10	.3361	.3547	.4108	.4108	.3174	.2614	.3734
11	.3734	.3734	.3734	.3734	.2987	.2427	.4108
12	.4108	.3734	.4108	.3361	.3174	.2987	.3921
13	.3361	.3547	.3734	.3361	.2241	.2614	.3734
14	.3174	.2801	.2801	.2987	.2054	.2054	.3734
15	.2801	.2614	.3174	.2987	.2241	.2054	.3361
16	.2614	.2241	.3174	.439	.2241	.1867	.3174
17	.2587	.2427	.2801	.2378	.2427	.2427	.3174
18	.2987	.2614	.2241	.2195	.2743	.2195	.3734
19	.3174	.2614	.2801	.2743	.2926	.2743	.3734
20	.3174	.2987	.2987	.3475	.2561	.2195	.4108
21	.2378	.3174	.2987	.2561	.2561	.2378	.4294
22	.2614	.3174	.2427	.2195	.2926	.2743	.3361
23	.2614	.3174	.2614	.2195	.2195	.3109	.2987
24	.2195	.2241	.2987	.2241	.2195	.2195	.2743
Max	.4108	.3734	.4108	.4481	.3174	.3109	.4294
Min	.2054	.2241	.2241	.2054	.1829	.1829	.2195
Avg	.2772	.2816	.2894	.2955	.2403	.2341	.3252

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 206 / 11KV Ahirwadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2241	.2561	.2641	.2801	.2263	.2241
2	.2241	.2241	.2218	.2641	.2801	.2075	.2241
3	.2241	.2241	.2218	.2641	.2241	.2054	.2241
4	.2241	.2134	.2614	.2641	.2241	.2054	.2054
5	.3361	.4108	.3361	.3395	.2801	.2241	.1991
6	.5093	.4481	.415	.4527	.3511	.3511	.3801
7	.4904	.4108	.4715	.4338	.4668	.4527	.5041
8	.4527	.3734	.4338	.3584	.3961	.4108	.3921
9	.4294	.3734	.3584	.2987	.3584	.4108	.3109
10	.3734	.3109	.3361	.2614	.2614	.2452	.2241
11	.3326	.2743	.3174	.2263	.2241	.2641	.2241
12	.2772	.2402	.2801	.2075	.1524	.2263	.2241
13	.2402	.2195	.2241	.2075	.1867	.2263	.2241
14	.2218	.1867	.1867	.1886	.168	.2263	.2241
15	.2218	.2075	.1867	.1886	.168	.2054	.2263
16	.2561	.2172	.1867	.2218	.1867	.1886	.2427
17	.3326	.2686	.2241	.2218	.1867	.2452	.2427
18	.3174	.3045	.2507	.2427	.3961	.3961	.2957
19	.4481	.3881	.4481	.4108	.4715	.5093	.3696
20	.4481	.4251	.4854	.5041	.4668	.5041	.439
21	.4572	.4108	.4854	.4481	.4294	.5041	.4207
22	.3734	.3696	.3547	.3734	.3921	.3921	.3326
23	.2987	.2957	.2801	.3361	.2801	.3174	.2957
24	.2241	.2374	.2926	.2641	.2801	.2241	.2427
Max	.5093	.4481	.4854	.5041	.4715	.5093	.5041
Min	.2218	.1867	.1867	.1886	.1524	.1886	.1991
Avg	.3307	.3024	.3131	.3018	.2963	.3070	.2872

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 207 / 11KV Nagthane AG

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.2429	.3086	.3239	.0754	.0566	.0566
2	.3239	.2429	.3086	.3239	.0566	.0566	.0566
3	.3239	.2572	.2713	.3239	.0566	.0566	.0566
4	.3239	.2572	.2713	.3239	.0566	.0566	.0566
5	.3239	.2743	.373		.0566	.0566	.0566
6	.3887	.2743	.407	.3725	.0566	.0754	.0566
7	.4715	.3429	.4409	.3887	.0566	.0566	.0566
8	.0566	.0566	.0566	.0566	.0566	.0566	.0754
9	.0566	.0566	.0566	.6802	.8745	.8259	.0566
10	.0566	.0566	.0549	.7125	.9774	.8583	.0566
11	.0566	.0566	.0566	.7362	.9431	.9069	.0549
12	.0566	.0566	.0566	.7362	.9431	.9393	.0566
13	.0566	.0566	.0566	.7682	.9431	.8907	.0566
14	.0566	.0566	.0566	.7682	.9945	.9393	.0566
15	.0566	.0566	.0566	.7682	.9945	.9069	.0566
16	.0566	.0566	.0566	.8309	.9709	.8583	.0566
17	.0566		.0566	.0566	.0566	.0566	.0566
18	.0566		.0566	.0566	.0566	.0566	.0566
19	.0566		.0566	.0566	.0754	.0566	.0566
20	.0566	.0566	.0754	.0754	.0754	.0566	.0566
21	.0549	.0566	.0754	.0566	.0754	.0754	.0566
22	.2743		.3563	.0566	.0754	.0566	.5144
23	.2743	.3403	.3401	.0566	.0566	.0566	.463
24	.3563	.2572	.3086	.3401	.0754	.0566	.0754
Max	.4715	.3429	.4409	.8309	.9945	.9393	.5144
Min	.0549	.0566	.0549	.0566	.0566	.0566	.0549
Avg	.1740	.1556	.1756	.3856	.3608	.3362	.0941

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 208 / 11KV Kisan No 3 LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.0183	.0185	.0181	.1086	.1086
2	.0549	.0183	.0185	.0181	.1086	.1086
3	.0549	.0183	.0185	.0181	.1086	.1086
4	.0549	.0183	.0185	.0181	.1086	.1086
5	.0549	.0183	.0185	.0181	.1086	.1086
6	.128	.0183	.0185	.0543	.2172	.2353
7	.1829	.0183	.0185	.0724	.2172	.2353
8	.0183	.0183	.0185	.1086	.2353	.2353
9	.0181	.0183	.0185	.1267	.2353	.2353
10	.0183	.0189	.0185	.1097	.2378	.2427
11	.0183	.0183	.0183	.1097	.2195	.2378
12	.0183	.0183	.0185	.0686	.2195	.2378
13	.0183	.0187	.0185	1.5729	.2195	.2353
14	.0183	.0183	.0185	.1097	.2195	.2378
15	.0183	.0187	.0185	.1086	.2195	.4294
16	.0183	.0187	.0183	.1086	.2195	.2378
Max	.1829	.0189	.0185	1.5729	.2378	.4294
Min	.0181	.0183	.0183	.0181	.1086	.1086
Avg	.0469	.0184	.0185	.1650	.1877	.2089

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244021 / 33/11 KV WALWA S/S

Feeder No / Name : 401 / 33KV Walwa LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8107	1.3169	1.4266	1.1523	1.1523	.9877
2	1.8107	1.3169	1.4266	1.1523	1.1523	1.1523
3	1.8107	1.3169	1.4266	1.1523	1.1523	1.1523
4	1.8107	1.3169	1.4266	1.2071	1.2071	1.2071
5	1.8107	1.262	1.4266	1.3717	1.3717	1.3717
6	1.8107	1.262	1.4815	1.4815	1.4815	1.4815
7	1.8107	1.262	1.4815	1.4815	1.4815	1.6461
8	1.8107	1.262	1.4266	1.4815	1.5912	1.5912
9	1.8107	1.262	1.4266	1.4815	1.6461	1.5912
10	1.8107	1.8107	1.4266	1.4815	1.6461	1.5912
11	1.8107	1.8107	1.4266	1.4815	1.6461	1.4815
12	1.3169	1.8107	1.4266	1.5912	1.6461	.7133
13	1.262	1.8107	1.4266	1.5912	1.6461	.7133
14	1.262	1.8107	1.4266	1.5912	1.5912	.7133
15	1.3169	1.8107	1.4266	1.6461	1.5912	.9522
16	1.262	1.3717	.8779	.9328	.9328	.9328
Max	1.8107	1.8107	1.4815	1.6461	1.6461	1.6461
Min	1.262	1.262	.8779	.9328	.9328	.7133
Avg	1.6461	1.4883	1.3992	1.3923	1.4335	1.2049

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 201 / 11 Kv. Shigaon AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6371		.5868	.4793	.0309	.0297	.0389
2	.6371		.602	.4858	.0309	.0314	.0406
3	.6371		.6401	.4858	.0297	.0337	.0423
4	.6371		.6093	.4858	.0446	.036	.04
5	.6748		.6249	.4793	.0452	.0372	.0423
6	.823		.6706	.5213	.0452	.0383	.0434
7	.8749		.7042	.5647	.044	.0394	.0412
8	.04		.0434	.0372	.0686	.0406	.0332
9	.0191	.044	.0434	.945	1.1888	1.5023	
10	.0183	.0423	.0372	1.1126	1.4529	1.6204	.028
11	.0191	.0406	.0354	1.2146	1.4352	1.6049	.0366
12	.0198	.0383	.0354	1.2041	1.4175	1.6358	.036
13	.021	.0274	.0244	1.1888	1.387	1.6512	.0343
14	.0213	.0343	.0251	1.1888	1.3717	1.6156	.0349
15	.0149	.036	.0251	1.1888	1.3123	1.5586	.0372
16	.0152	.0303	.0229	1.1888	1.3123	1.475	.0377
17		.5216	.0229	.0514	.0269	.0343	.0383
18	.0251	.04	.0343	.0514	.0373	.0465	.0389
19	.0541	.0389	.0372	.0514	.0419	.036	.0518
20	.0533	.04	.0248	.0514	.045	.0337	.0526
21	.5411	.0406	.0251	.0514	.0472	.0343	.04
22	.5944	.6622	.5144	.0412	.0232	.0354	1.0802
23	.5647	.6161	.5502	.0457	.0286	.0354	1.0364
24	.6748	.5281	.5937	.5075	.0457	.028	.0332
Max	.8749	.6622	.7042	1.2146	1.4529	1.6512	1.0802
Min	.0149	.0274	.0229	.0372	.0232	.028	.028
Avg	.3312	.1738	.2722	.5676	.4797	.5514	.1277

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 202 / 11 Kv. Bhadkambe LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0147	.3801	.3734	.3734	.3881
2	.0189	.0143	.3841	.3734	.3734	.3801
3	.0189	.0137	.3841	.3734	.3696	.3761
4	.0189	.0149	.3841	.3841	.3881	.3801
5	.0189	.0143	.3841	.3841	.3881	.3721
6	.3206	.0869	.3881	.3841	.3881	.3801
7	.3881	.3881	.3881	.3841	.3881	.3841
8	.3881	.3881	.3841	.3658	.3881	.3841
9	.3881	.3881	.3881	.3658	.3881	
10	.3881	.3841	.3658	.4024	.3881	.0023
11	.3881	.3841	.3658	.4066	.3841	.3881
12	.3881	.3841	.3658	.3982	.3841	.3881
13	.3841	.3658	.3658	.3801	.3841	.3841
14	.3841	.3658	.3658	.3801	.3881	.3841
15	.3881	.3658	.3658	.3841	.3841	.3841
16	.2218	.2103	.2195	.2378	.2402	.2378
17	.2218					
Max	.3881	.3881	.3881	.4066	.3881	.3881
Min	.0189	.0137	.2195	.2378	.2402	.0023
Avg	.2555	.2364	.3675	.3736	.3749	.3476

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 203 / 11 Kv.Pokharni Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724	.0549	.0747	.0543		.0549	.0724
2	.0716	.0732	.0754	.0549		.0549	.0739
3	.0716	.0732	.0747	.0549		.0554	.0716
4	.0716	.0739	.0747	.0549		.0554	.0724
5	.0724	.0739	.0914	.0549		.0739	.0732
6	.0905	.0924	.1109	.0905		.0739	.0905
7	.1086	.1267	.1063	.1086	.1052	.0914	.1075
8	.0895	.1097	.0895	.0686	.0857	.0924	.1086
9	.0526	.0693	.0686	.0686	.0701	.0532	
10	.0526	.0686	.12	.1052	.0716	.0716	.0914
11	.0526	.0509	.0762	.0876	.0543	.0914	.1029
12	.0532	.0701	.061	.0701	.0686	.0895	.0693
13	.0537	.0686	.0678	.0686	.104	.0848	.0905
14	.0532	.1086	.0686	.0857	.1052	.0686	.0732
15	.0362	.0693	.0686	.1052	.0686	.0701	.0686
16	.0351	.0671	.0671	.1052	.0701	.0838	.0701
17	.0905	.0693	.061	.1075	.0716	.0857	.0895
18	.0716	.0895	.061	.112	.0732	.104	.0914
19	.1254	.1267	.0924	.1494	.1075	.1227	.104
20	.1086	.128	.0934	.1494	.1267	.1267	.124
21	.0924	.1307	.0934		.1086	.1097	.0895
22	.1109	.112	.0732	.1097	.0934	.0934	.0747
23	.0905	.0934	.0732	.0747	.0739	.0739	.0732
24	.0724	.1086	.0747	.0543	.056	.0549	.0732
Max	.1254	.1307	.12	.1494	.1267	.1267	.124
Min	.0351	.0509	.061	.0543	.0543	.0532	.0686
Avg	.0750	.0879	.0799	.0867	.0841	.0807	.0850

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 204 / 11 Kv Shigaon Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2263	.2829	.2263	.2075	.2075	.2263
2	.1886	.2263	.2829	.2263	.2075	.2075	.2263
3	.1886	.2263	.2829	.2263	.2054	.2075	.2263
4	.1886	.2452	.2829	.2263	.3142	.2263	.2427
5	.2263	.2829	.3395	.2263	.3326	.2641	.2801
6	.4108	.3772	.3961	.3361	.3734	.3395	.3361
7	.4294	.4294	.4294	.4108	.3361	.4108	.4251
8	.3658	.3142	.3292	.4024	.3292	.3696	.3475
9	.3258	.3258	.2926	.2865	.2896	.2926	
10	.2507	.3077	.3224	.2303	.2715	.2896	.2149
11	.2328	.2743	.2481	.2149	.2172	.2328	.2507
12	.1949	.2328	.2481	.2149	.2328	.2353	.2353
13	.1772	.2534	.2507	.2012	.2149	.2195	.2172
14	.1928	.2012	.2534	.2075	.2328	.2149	.2172
15	.1949	.2378	.2561	.1991	.2218	.2012	.2561
16	.197	.1928	.2534	.1991	.2012	.2172	.2534
17	.2353	.2328	.2507	.2195	.2402	.2328	.2715
18	.2926	.3109	.2658	.2926	.2957	.2427	.2715
19	.4066	.4108	.3326	.3841	.3439	.3982	.3801
20	.4481	.4294	.3734	.4207	.4207	.462	.4251
21	.415	.4108	.3734		.3801	.3961	.3921
22	.3961	.415	.3395	.3658	.3584	.3395	.3772
23	.3395	.3772	.3018	.2829	.3018	.2829	.3018
24	.1886	.2452	.2829	.2263		.2263	.2452
Max	.4481	.4294	.4294	.4207	.4207	.462	.4251
Min	.1772	.1928	.2481	.1991	.2012	.2012	.2149
Avg	.2781	.2994	.3029	.2707	.2838	.2799	.2878

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 205 / 11 Kv Pokharni Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061	.0457	.0343	.0434	.4572	.4858	.4144
2	.061	.0486	.0362	.0434	.463	.4858	.4287
3	.0602	.0497	.0366	.044	.4515	.4923	.4401
4	.0602	.0514	.0358	.044	.5268	.5068	.4633
5	.061	.052	.0366	.044	.5647	.5281	.4512
6	.0724	.0701	.0554	.0716	.5944	.5428	.4934
7	.0732	.0732	.0663	.0724		.8215	.5357
8	.0648	.0716	.052	.0671	.743	.0469	.0514
9	.8322	.7133	.5721	.0469	.04	.0312	
10	.8802	.6516	.9682	.0625	.0655	.0305	1.2041
11	.9482	.6984	1.0402	.064	.0474	.0297	1.4685
12	.9297	.6984	1.0402	.064	.0446	.0293	1.5203
13		.6895	.8802	.0514	.0602	.0297	1.4937
14	.6226	.6308	.8802	.0514	.061	.0301	1.4815
15	.5898	.6472	.8802	.0514	.0497	.0328	1.4175
16	.6133	.5944	.8177	.0686	.0503	.0251	1.247
17	.0457	.0372	.0503	.0686	.0514	.0267	.0663
18	.0463	.0509	.0503	.0343	.0526	.0429	.0686
19	.0633	.0514	.0655	.0343	.0625	.0486	.0474
20	.0625	.052	.0655	.0343	.064	.0492	.064
21	.0617	.052	.0663		.0497	.0503	.0648
22	.0686	.0532	.0446	.5702	.5647	.463	.0526
23	.0532	.0514	.0446	.5801	.5144	.4144	.0486
24	.032	.0452	.0328	.04	.4973	.4793	.4089
Max	.9482	.7133	1.0402	.5801	.743	.8215	1.5203
Min	.032	.0372	.0328	.0343	.04	.0251	.0474
Avg	.2767	.2575	.3272	.0979	.2642	.2385	.6057

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 206 / Hutatma Sureshkumar LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0189	.0191	.0191
2	.0191	.0191	.0191	.0189	.0191	.0191
3	.0191	.0191	.0191	.0189	.0191	.0191
4	.0191	.0191	.0191	.0189	.0191	.0191
5	.0191	.0191	.0191	.0189	.0191	.0191
6	.0191	.0191	.0191	.0189	.0191	.0191
7	.0191	.0191	.0191	.2561	.0191	.2926
8	.2801	.0191	.2801	.2926	.0191	.2957
9	.2772	.2957	.2801	.2926	.0191	
10	.2957	.2772	.2743	.2926	.0191	.2772
11	.2987	.2772	.2926	.2957	.0191	.2772
12	.2987	.2772	.2926	.2957	.0191	.2957
13	.0191	.2743	.2926	.2957	.0191	.2957
14	.0191	.2743	.2926	.2957	.0191	.2957
15	.2987	.2743	.2926	.2772	.0191	.2772
16	.2987	.2772	.2743	.2772	.0191	.2743
Max	.2987	.2957	.2926	.2957	.0191	.2957
Min	.0191	.0191	.0191	.0189	.0191	.0191
Avg	.1387	.1488	.1691	.1865	.0191	.1797

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 207 / 11KV Bahadurwadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2675	.176	.2526	.2	.0189	.0185	.0189
2	.2572	.176	.2559	.2	.0189	.0187	.0183
3	.2572	.1783	.2347	.2027	.0189	.0187	.0189
4	.2572	.1783	.2439	.2027	.0189	.0187	.0183
5	.2896	.1957	.2559	.2027	.0189	.0189	.0185
6	.3269	.2107	.2591	.2286	.0189	.0189	.0366
7	.3658	.2439	.2751	.2656	.0189	.0187	.0543
8	.0183	.0151	.0183	.0185	.0189	.0185	.0183
9	.0185	.0189	.0191	.3963	.6097	.4877	
10	.0187	.0189	.0171	.4904	.6706	.7164	.0181
11	.0185	.0177	.0156	.5053	.6636	.7074	.0183
12	.0181	.0181	.0156	.5268	.602	.7011	.0181
13	.0183	.0191	.0156	.5335	.6097	.6773	.0179
14	.0181	.0191	.0158	.5182	.6249	.6706	.0177
15	.0164	.0179	.0158	.4967	.6944	.6472	.0162
16	.0166	.0173	.0183	.4967	.6554	.6401	.0166
17	.0168	.0133	.0171	.0152	.0175	.0126	.0171
18	.0171	.0187	.0171	.0173	.0181	.0217	.0177
19	.0185	.0187	.0183	.0173	.0139	.0143	.0179
20	.0183	.0152	.0183	.0173	.0143	.0164	.0181
21	.0181	.0156	.0185		.0147	.0168	.0179
22	.208	.2559	.1907	.0189	.0189	.0171	.4877
23	.1907	.2526	.208	.0185	.0187	.0189	.4666
24	.2972	.1738	.2494	.2027	.0185	.0185	.0189
Max	.3658	.2559	.2751	.5335	.6944	.7164	.4877
Min	.0164	.0133	.0156	.0152	.0139	.0126	.0162
Avg	.1237	.0952	.1111	.2518	.2257	.2306	.0603

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244025 / 33/11 KV NAGAON

Feeder No / Name : 401 / 33KV LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6224	.679	.679	.6224	.9054	.679
2	.679	.679	.679	.6224	.9054	.679
3	.679	.679	.679	.6224	.9054	.679
4	.679	.7356	.679	.679	.9054	.679
5	.679	.7356	.679	.7356	.9054	.679
6	.679	.7356	.679	.7356	.9054	.679
7	.679	.7922	.679	.8488	.9054	.679
8	.9619	.9619	.8962	.9619	.9054	.679
9	.9619	.9619	.9054	.9619	.9619	
10		.9054	.9054	.9619	.9619	.2263
11	.9619	.9054	.9054	.9619	.9619	.7356
12	.9054	.9054	.9054	.9619	.9619	.679
13	.9054	.9054	.9054	.9619	.9619	.679
14	.9054	.9054	.9054	.9619	.9619	.679
15	.9619	.9054	.9054	.9619	.9619	.679
16	.7922	.7922	.7922	.8488	.8488	.5716
Max	.9619	.9619	.9054	.9619	.9619	.7356
Min	.6224	.679	.679	.6224	.8488	.2263
Avg	.8035	.8240	.7987	.8381	.9266	.6454

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 201 / 11 KV Krishnamai AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.2561	.2652	.2294			
2	.4534	.2561	.2683	.2321			
3	.4534	.2561	.2652	.2294			
4	.4534	.2561	.2652	.2294			
5	.4481	.2561	.2683	.2486			
6	.4481	.2591	.2683	.2515			
7	.4049	.2591	.2818	.2683			
9				.3978	.583	.503	
10				.4973	.7468	.6371	
11				.4973	.8413	.6706	
12				.4973	.924	.7377	
13				.5365	.6299	.7377	
14				.5365	.6371	.7042	
15				.5304	.5967	.6539	
16				.5304	.5182	.6203	
22	.253	.2622	.192				.5735
23	.253	.2818	.2429				.5735
24	.4641	.253	.2785	.2267			
Max	.4641	.2818	.2818	.5365	.924	.7377	.5735
Min	.253	.253	.192	.2267	.5182	.503	.5735
Avg	.4080	.2596	.2596	.3712	.6846	.6581	.5735

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 202 / 11KV Mahalaxmi LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.267	1.2803	1.267	1.267	1.2803	1.2803
2	1.267	1.2803	1.2851	1.267	1.267	1.2803
3	1.267	1.267	1.2851	1.0002	1.267	1.2752
4	1.267	1.2803	1.2851	1.267	1.267	1.262
5	1.267	1.262	1.2851	1.267	1.267	1.2803
6	1.267	1.267	1.2851	1.267	1.267	1.2986
7	1.267	1.2803	1.3032	1.267	1.2803	1.2715
8	1.3169	1.3169	1.3213	1.267	1.3169	1.3032
9	1.3169	1.3169	1.3213	1.2894	1.3394	1.3169
10	1.3169	1.3073	1.2894	1.2894	1.3394	1.3535
11	1.3032	1.2894	1.2894	1.3169	1.3535	1.3169
12	1.3169	1.2795	1.2894	1.3169	1.3394	1.3169
13	1.3169	1.2795	1.2894	1.3169	1.3394	1.3169
14	.0549	1.3073	1.2894	1.3032	1.3535	1.3169
15	1.3169	1.3112	1.3253	1.3032	1.3535	1.3169
16	1.2851	1.2656	1.2894	1.267	1.2403	1.3169
Max	1.3169	1.3169	1.3253	1.3169	1.3535	1.3535
Min	.0549	1.262	1.267	1.0002	1.2403	1.262
Avg	1.2134	1.2869	1.2938	1.2670	1.3044	1.3015

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 203 / 11KV Yashwant AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.583	.407	.4641			
2		.5144	.373	.4694			
3		.5144	.3772	.4694			
4		.5144	.373	.4862			
5		.5144	.373	.4917			
6		.5144	.3814	.5087			
7		.5487	.39	.5256			
9				.9496	1.1869	1.3565	
10				1.1869	1.2548	1.3904	
11				1.1869	1.2209	1.4582	
12				1.2209	1.326	1.4922	
13				1.2071	1.326	1.4582	
14				1.1736	1.3565	1.4243	
15				1.1065	1.3565	1.3413	
16				1.073	1.3077	1.1271	
22	.5935	.4191	.4862				.7712
23	.5765	.4024	.4862				.7712
24		.5765	.4024	.4641			
Max	.5935	.583	.4862	1.2209	1.3565	1.4922	.7712
Min	.5765	.4024	.373	.4641	1.1869	1.1271	.7712
Avg	.585	.5102	.4049	.8115	1.2919	1.3810	.7712

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 204 / 11 KV Ashta PWW

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0633	.0716	.0709	.0709	.0716	.0724	.0709
2	.0625	.0716	.0709	.0701	.0716	.0724	.0716
3	.0625	.0716	.0716	.0701	.0716	.0724	.0716
4	.0617	.0716	.0716	.0701	.0716	.0724	.0709
5	.0617	.0716	.0716	.0701	.0716	.0724	.0716
6	.0625	.0716	.0716	.0716	.0716	.0724	.0716
7	.0625	.0716	.0716	.0716	.0716	.0701	.0716
8	.0625	.0716	.0716	.0716	.0716	.0709	.0716
9	.0625	.0716	.0716	.0716	.0716	.0709	.0716
10	.0625	.0716	.0709	.0709	.0716	.0724	.0716
11	.0625	.0716	.0709	.0709	.0716	.0716	.0716
12	.0625	.0716	.0693	.0709	.0709	.0716	.0716
13	.0625	.0716	.0701	.0709	.0709	.0716	.0716
14	.0625	.0716	.0709	.0716	.0724	.0716	.0716
15	.0076	.0716	.0701	.0716	.0724	.0716	.0716
16	.0076	.0716	.0701	.0716	.0724	.0716	.0716
17	.0076	.0716	.0701	.0701	.0701	.0716	
18	.0701	.0716	.0693	.0701	.0693	.0716	.0617
19	.0709	.0716	.0693	.0701	.0701	.0709	.0617
20	.0709	.0716	.0701	.0701	.0701	.0709	.0617
21	.0709	.0716	.0701	.0701	.0709	.0724	.0617
22	.0709	.0716	.0701	.0709	.0709	.0709	.0617
23	.0709	.0716	.0701	.0693	.0701	.0709	.0617
24	.0617	.0709	.0709	.0701	.0693	.0701	.0709
Max	.0709	.0716	.0716	.0716	.0724	.0724	.0716
Min	.0076	.0709	.0693	.0693	.0693	.0701	.0617
Avg	.0576	.0716	.0706	.0707	.0711	.0716	.0689

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 205 / 11KV Tryambkeshwar LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.005	.0063	.005	.0983	.0057	.0055
2	.005	.0055	.0048	.0983	.0057	.0059
3	.005	.0055	.0051	.0983	.0057	.0061
4	.005	.0053	.0051	.0983	.0057	.0061
5	.005	.0057	.005	.0983	.0059	.0065
6	.005	.0059	.0053	.0983	.0059	.0067
7	.005	.005	.0055	.0983	.0059	.0059
8	.1448	.197	.2149	.1802	.197	.197
9	.1267	.197	.2149		.2058	.197
10	.0914	.2149	.2149	.197	.2172	.2353
11	.0739	.2328	.2149	.1949	.2195	.2149
12	.2378	.2303	.2149	.1949	.197	.2149
13	.2353	.2328	.2149	.1949	.197	.2149
14	.128	.2328	.2149	.1928	.197	.2149
15	.2378	.2328	.2149	.1928	.197	.2126
16	.2353	.2303	.2149	.1928	.197	.2126
Max	.2378	.2328	.2149	.197	.2195	.2353
Min	.005	.005	.0048	.0983	.0057	.0055
Avg	.0966	.1275	.1231	.1486	.1166	.1223

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244048 / 33/11 KV MARDWADI S/S

Feeder No / Name : 206 / 11KV Dhadak LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5571	.2818	.6478	.7449	.503	.426
2	.3277	.3018	.664	.7449	.503	.426
3	.5571	.3018	.664	.7449	.503	.4372
4	.5571	.0373	.6802	.7449	.5365	.4372
5	.5571	.0373	.6882	.7449	.5365	.4588
6	.5571	.0377	.6802	.7449	.5365	.4534
7	.4588	.0373	.6882	.7449	.5365	.664
8	.4973	.0373	.5182	.7449	.5304	.4862
9	.7042	.2591	.5197	.8288	.5426	.503
10	.7956	.421	.5365	.8192	.5765	.5765
11	.8453	.2721		.8192	.5304	.5765
12	.8192	.2688	.6036	.8192	.3277	.3353
13	.8192	.3041	.8139	.852	.5304	.3353
14	.1989	.8356	.78	.852	.5636	.3353
15		.8259	.8478	.8421	.5636	.7956
16		.6722	.6104	.4161	.5407	.7293
Max	.8453	.8356	.8478	.852	.5765	.7956
Min	.1989	.0373	.5182	.4161	.3277	.3353
Avg	.5894	.3082	.6628	.7630	.5226	.4985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 201 / 11KV Bagni AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0716	.0914	.064	.061	.6219	.6562	.8131
2	.0655	.0739	.064	.0625	.5609	.6481	.8215
3	.0625	.0739	.064	.0633	.503	.679	.7842
4	.064	.0914	.0655	.0625	.4915	.6874	.8131
5	.0781	.0924	.0819	.064	.5243	.7042	.8589
6	.0892	.0914	.0819	.0819	.5121	.7499	.9149
7	.0914	.1097	.0819	.1017	.8223	.7716	.9896
8		.1109	.1029	.0876	.0886	.0625	.0838
9	2.0328	1.7002	1.2986	.0655	.0895	.0633	1.7013
10	1.8839	1.8111	1.4969	.0655	.0905	.0791	1.829
11	2.0485	1.7372	1.4815	.0655	.0914	.0633	2.1132
12	2.0814	1.6632	1.2986	.0663	.0739	.0625	2.1491
13	2.0328	1.6057	1.46	.061	.0732	.048	2.2624
14	1.6644	1.4937	1.4045	.0457	.0739	.0492	2.2744
15	1.6632	1.2071	1.3535	.061	.0739	.0655	2.2744
16	1.4969	1.1317	1.0974	.061	.0732	.0655	2.1849
17	.0732	.0655	.064	.0617	.0739	.0655	.0549
18	.0924	.0663	.0655	.061	.0732	.064	.0747
19	.0924	.0633	.0876	.1052	.0739	.08	.0739
20	.1097	.0838	.0857	.1029	.0693	.096	.112
21	.128	.0838	.0829	.0857	.0857	.0949	.1307
22	.1294	.0819	.081		.6249	.8962	.0924
23	.1109	.08	.061	.679	.6173	.8775	.0914
24	.0934	.0924	.064	.0556	.6722	.6401	.8488
Max	2.0814	1.8111	1.4969	.679	.8223	.8962	2.2744
Min	.0625	.0633	.061	.0457	.0693	.048	.0549
Avg	.7068	.5709	.5037	.0968	.2939	.3446	1.0144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 202 / 11KV Ashta Chadoli Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0457	.0457	.0617	.048	.5155	.5792	.4816
2	.0463	.0463	.0617	.0486	.506	.5864	.4687
3	.0452	.0457	.061	.0497	.4784	.6249	.4586
4	.0452	.0457	.061	.0492	.4744	.6173	.4801
5	.061	.0602	.0762	.0497	.4902	.6097	.4801
6	.0772	.0743	.0903	.0655	.5155	.6173	.5121
7	.0914	.0892	.0892	.096	.5624	.6173	.5937
8		.0762	.0903	.0648	.0633	.0625	.0469
9	.823	.7926	.4062	.0486	.048	.0633	.6722
10	.7876	.7926	.3795	.0474	.0486	.0469	.7537
11		.7827	.6241	.048	.0497	.0469	.7842
12	.8078	.7526	.6802	.064	.0457	.0463	.9328
13	.743	.7716	.7209	.0633	.0617	.0469	.7459
14	.7095	.8436	.7127	.032	.0625	.0633	.7202
15	.6984	.679	.6882	.0469	.0781	.0633	.7125
16	.6706	.6874	.7209	.0463	.0772	.0633	.6401
17	.0309	.0469	.048	.061	.0781	.0625	.0474
18	.0457	.0633	.0492	.0762	.0772	.0617	.0469
19	.0617	.0791	.0829	.0663	.0983	.0762	.0633
20	.0781	.0791	.0829	.0937	.0937	.0903	.08
21	.0791	.0791	.0838	.0937	.096	.0937	.081
22	.0625	.0926	.0663	.6405	.5937	.5921	.0655
23	.0463	.0772	.0492	.6325	.5864	.5535	.048
24	.0594	.0457	.0617	.2789	.6081	.5792	.5182
Max	.823	.8436	.7209	.6405	.6081	.6249	.9328
Min	.0309	.0457	.048	.032	.0457	.0463	.0469
Avg	.2780	.2979	.2520	.1171	.2629	.286	.4347

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 203 / 11KV SHIGAON RIVER AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0185	.8501	.679	.5853	.037	.037	.037
2	.9808	.8413	.679	.5914	.0373	.0366	.0366
3	.924	.8048	.6722	.5914	.0373	.037	.0373
4	.924	.8131	.6722	.5853	.0377	.037	.0377
5	.9335	.8501	.7095	.6219	.0377	.0366	.0373
6	.9997	.8501	.7392	.6584	.0377	.037	.0377
7	1.0751	.8413	.7922	.6838	.0373	.037	.0373
8		.037	.0377	.037	.056	.037	.0373
9	.0366	.0377	.0366	.9431	1.1203	1.307	.037
10	.037	.0377	.037	.9054	1.1088	1.4937	.0366
11	.0366	.037	.037	.056	1.1576	1.5154	.037
12	.037	.037	.0366	.9997	1.3676	1.5154	.037
13	.0366	.0377	.037	.9896	1.39	1.5684	.037
14	.037	.0377	.037	.9431	1.5154	1.5339	.0366
15	.0554	.0373	.037	1.0374	1.4415	1.5154	.0362
16	.0549	.0373	.0366	.8299	1.3535	1.46	.0358
17		.0373	.037	.0373	.0373	.037	.0358
18			.0328	.0373	.037	.0373	.0366
19		.0377	.0362	.037	.037	.0554	.037
20		.037	.037	.037	.0366	.0549	.037
21	.037	.0373	.0366	.0373	.0554	.0554	.0366
22	.924	.8299	.6219	.037	.037	.0366	
23	.8501	.7922	.5853	.0377	.0366	.0934	1.2071
24	1.0642	.8413	.679	.5914	.0373	.037	.0377
Max	1.0751	.8501	.7922	1.0374	1.5154	1.5684	1.2071
Min	.0366	.037	.0328	.037	.0366	.0366	.0358
Avg	.5296	.3826	.3059	.4963	.4620	.5255	.0878

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244084 / 33/11KV Falkewadi

Feeder No / Name : 205 / 11KV BAGNI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.2957	.2641	.2561	.2378	.2926	.2715
2	.2534	.2561	.2641	.2534	.2195	.2926	.2561
3	.2353	.2561	.2641	.2561	.2172	.2587	.2561
4	.2378	.2587	.2641	.2587	.2353	.2587	.2561
5	.2561	.2957	.2641	.2561	.2561	.2926	.2896
6	.2957	.3326	.3206	.2957	.3326	.2957	.3326
7	.2926	.2957	.3584	.3326	.3511	.3142	.3292
8		.2957	.2801	.2587	.3511	.2614	.3109
9	.2957	.2987	.2772	.2743	.2743	.2772	.3292
10	.2587	.2587	.2743	.2743	.2957	.2772	.3326
11	.2561	.2561	.2587	.2743	.3109	.2743	.2957
12	.2587	.2587	.2772	.2772	.2957	.2957	.3326
13	.2561	.2743	.2772	.2772	.2926	.2957	.2957
14	.2402	.2772	.2587	.2715	.2772	.3292	.2957
15	.2561	.2402	.2561	.2743	.2957	.3292	.2926
16	.2587	.2587	.2772	.2743	.2743	.3292	.3142
17	.2957	.2378	.2772	.2957	.2957	.3326	.2926
18	.3109	.2507	.2218	.3326	.3174	.3511	.3511
19	.3326	.4066	.3511	.3658	.4108	.3658	.4066
20	.3658	.4668	.4294	.4435	.4435	.4024	.4251
21	.4435	.4715	.4066	.439	.4108	.4024	
22	.4066	.4338	.3881	.3475	.3696	.3696	
23	.2957	.3772	.2957	.2957	.3292	.3326	.2743
24	.3109	.2926	.2641	.2587	.2587	.2957	.2957
Max	.4435	.4715	.4294	.4435	.4435	.4024	.4251
Min	.2353	.2378	.2218	.2534	.2172	.2587	.2561
Avg	.2900	.3061	.2946	.2976	.3064	.3136	.3107

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 201 / 11 Kv Ashta Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.1494	.168	.1132	1.2041	1.4198	1.0004
2	.1867	.1307	.168	.1132	1.2193	1.4327	.9156
3	.1867	.1509	.1867	.112	1.2037	1.4506	.9835
4	.1867	.132	.1867	.132	1.1883	1.4998	1.0852
5	.2241	.1698	.2054	.132	1.3123	1.4998	1.2378
6	.2241	.2263	.2054	.1698	1.406	1.5684	1.5261
7	.2427	.2452	.2054	.2096	1.4937	1.5394	1.6108
8	.2241	.1886	.2054	.1886	.1509	.1715	.2427
9	1.7465	1.7711	1.5893	.1886	.1886	.1715	
10	1.933	1.781	1.8842	.1509	.1698	.1715	2.1026
11	1.8903	1.6091	1.6707	.1509	.1698		2.1605
12	1.8747	1.7029	1.6461	.1132	.1509		2.2138
13	1.821	1.6091	1.6461	.132	.1509		2.2613
14	1.7071	1.5154	1.7071	.1494	.1417		2.3403
15	1.4937	1.5779	1.768	.132	.1509		2.3087
16	1.4784	1.656	1.7223	.132	.1509		2.2929
17	.132	.2241	.1219	.132	.1509		.1509
18	.1494	.2241	.168	.1494	.1886		
19	.1886	.1867	.1829	.168	.1905		.1715
20	.1886	.1867	.2033	.1698	.1905		.1715
21	.1886	.1867	.1886	.1698	.1905		.1715
22	.168	.1867	.1715	1.2809	1.3279		.1524
23	.1509	.1867	.1334	1.25	1.406		.1334
24	.2241	.1509	.1867	.132	1.2037	1.3889	1.0682
Max	1.933	1.781	1.8842	1.2809	1.4937	1.5684	2.3403
Min	.132	.1307	.1219	.112	.1417	.1715	.1334
Avg	.7098	.6728	.6884	.2405	.6375	1.1194	1.1955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 202 / 11KV PATOLE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6722	.4481	.7842	.3814	.0791	.0972	.1147
2	.6401	.4481	.7362	.3864	.0633	.0972	.0972
3	.6241	.4321	.6882	.3715	.0633	.0972	.0972
4	.7362	.4161	.6562	.3864	.0474	.0972	.1457
5	.7842	.4801	.7042	.4012	.0633	.0972	.1619
6	.8162	.5601	.6882	.4214	.0949	.0972	.1619
7	.6401	.6722	.6401	.5182	.0949	.0972	.1781
8	.128	.08	.7042	.0762	.0791	.1296	.1781
9	.144	.064	.16	.7621	1.0279	.9998	.1457
10	.144	.064	.144	.6859	1.1069	1.0202	.1296
11	.048	.064	.0791		1.0753		.1457
12	.048	.096	.0633		1.1523		.1296
13	.048	.096	.0474		1.1843		.1296
14	.048	.096	.0474		1.1523		.1296
15	.048	.048	.0474	.953	1.1683		.112
16	.048	.048	.0633	.9686	1.1984		.1134
17	.048	.048	.0633	.8905	.0648		.1296
18	.064	.08	.0633	.0633	.081		.1296
19	.08	.08	.0633	.0791	.081		.1457
20	.08	.064	.0633	.0791	.0648		.1619
21	.08	.064	.0633	.0791	.0648		.1457
22	.4801	.9602	.4744	.0633	.0486		.7773
23	.4481	.8642	.4586	.0633	.0486		.7611
24	.6882	.4641	.8482	.3961	.0633	.0972	.1134
Max	.8162	.9602	.8482	.9686	1.1984	1.0202	.7773
Min	.048	.048	.0474	.0633	.0474	.0972	.0972
Avg	.3161	.2807	.3480	.4013	.4237	.2661	.1889

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 203 / 11 KV Ashta Gaohan 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7796	.5316	.7265	.5493	.6379	.6089	.7343
2	.7619	.5138	.7087	.5493	.6201	.6268	.7701
3	.7442	.4961	.7442	.543	.591	.6447	.7522
4	.815	.4784	.691	.5487	.5731	.6626	.7701
5	.5761	.5493	.815	.567	.6805	.6626	.8417
6	.9036	.6556	.8682	.7207	.6984	.6805	.8954
7	.905	.7973	.8682	.7947	.8059	.8059	.9313
8	.8682	.815	.8505	.8316	.8238	.8596	.9134
9	.8328	.7087	.815	.7762	.788	.8596	.8775
10	.7796	.7973	.8328	.8501	.7343	.8775	.8417
11	.7265	.815	.8505	.7964	.8238		.8505
12	.7265	.8682	.7619	.7164	.7522		.7973
13	.6024	.815	.7619	.7701	.7164		.7796
14	.6379	.8505	.7087	.7087	.6733		.7796
15	.6201	.7442	.691	.691	.6379		.7796
16	.6201	.7087	.7442	.6379	.6733		.7796
17	.691	.7619	.8682	.691	.7087		.8505
18	.7796	.7796	.6379	.691	.9214		.9036
19	.9214	.9214	.9036	.8505	.9745		1.0454
20	.9391	1.0099	.9568	1.0099	.9568		1.134
21	.9036	.9391	.8682	.9214	.8859		1.0099
22	.7973	.9036	.7796	.8328	.8505		.8859
23	.6733	.5881	.691	.7265	.6626		.7973
24	.8682	.5316	.7619	.5493	.6379	.591	.788
Max	.9391	1.0099	.9568	1.0099	.9745	.8775	1.134
Min	.5761	.4784	.6379	.543	.5731	.591	.7343
Avg	.7697	.7325	.7877	.7218	.7428	.7163	.8545

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 204 / 11KV BAWACHI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.2054	.2218	.2033	.1886	.2263	.1829
2	.2054	.1867	.2218	.2033	.1886	.2641	.1829
3	.2241	.1698	.2402	.2241	.1698	.2614	.2012
4	.2427	.1509	.2033	.2218	.1867	.2801	.1829
5	.2614	.1886	.2957	.2033	.2614	.2987	.2378
6	.2987	.2241	.3326	.2772	.2801	.3361	.2743
7	.3174	.2614	.3511	.3142	.3361	.3077	.3109
8	.2987	.2427	.3326	.2926	.2772	.3012	.2926
9	.2614	.2587	.2587	.2378	.2427	.2378	.2195
10	.2427	.2218	.2033	.2561	.2614	.2195	.1463
11	.1097	.2218	.181	.1646	.1494		.1402
12	.1663	.2218	.1612	.1448	.1254		.1052
13	.1307	.2402	.1433	.1463	.1254		.1052
14	.1307	.2218	.1254	.1463	.1433		.1052
15	.0924	.1109	.0895	.1478	.1417		.1052
16	.1494	.1109	.0716	.1294	.1578		.1052
17	.1886	.1109	.1612	.1294	.156		.1578
18	.2263	.1294	.1372	.168	.2172		.1949
19	.2641	.2218	.2195	.2241	.2896		.2715
20	.2801	.2957	.2801	.2829	.2587		.3142
21	.2614	.2587	.2614	.2452	.2427		.2614
22	.2427	.2587	.2427	.2054	.2263		.2241
23	.2263	.2218	.2054	.1886	.1886		.2054
24	.2054	.2075	.2218	.2241	.2075	.2263	.1829
Max	.3174	.2957	.3511	.3142	.3361	.3361	.3142
Min	.0924	.1109	.0716	.1294	.1254	.2195	.1052
Avg	.218	.2059	.2151	.2075	.2093	.2690	.1962

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 205 / 11 KV Bawachi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1494	.1867	.1663	1.1111	1.1279	1.0852
2	.1867	.1307	.1867	.168	1.0957	1.1439	1.0343
3	.1867	.132	.2054	.1848	1.0517	1.174	1.0004
4	.168	.1132	.2054	.1867	1.0517	1.2041	.9156
5	.1867	.132	.2241	.2033	1.1279	1.2346	.9665
6	.2241	.1698	.2054	.2241	1.1584	1.2346	1.0682
7	.2241	.1886	.2054	.2427	1.2955	1.2809	1.2209
8	.2241	.168	.2054	.2195	.168	.2054	.2241
9	1.4074	1.406	1.3923	.1629	.1663	.168	1.7465
10	1.5402	1.4661	1.5083	.1448	.1494	.1494	1.9669
11	1.4661	1.4352	1.5242	.1463	.168		1.6918
12	1.4969	1.3735	1.4901	.1448	.1463		1.7528
13	1.3413	1.3426	1.4327	.128	.1448		1.7071
14	1.3117	1.25	1.4022		.1612		1.6766
15	1.1589	1.2963	1.387	.1463	.1612		1.6156
16	1.1736	1.4198	1.2955	.1663	.1612		1.5546
17	.1307	.1867	.1227	.1478	.1612		.1629
18	.1494	.2054	.1612	.168	.1829		.1663
19	.168	.2054	.2012	.1867	.2033		.2241
20	.1867	.2054	.2033	.2263	.1829		.2427
21	.1886	.2054	.2218	.2263	.2054		.2427
22	.168	.2054	.2054	1.1126	1.1248		.2241
23	.1494	.2054	.1848	1.0957	1.1574		.1848
24	.1867	.132	.1867	.1663	1.0669	1.0974	1.1869
Max	1.5402	1.4661	1.5242	1.1126	1.2955	1.2809	1.9669
Min	.1307	.1132	.1227	.128	.1448	.1494	.1629
Avg	.5754	.5718	.6060	.2593	.5668	.9109	.9942

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244116 / 33/11KV ASHTA

Feeder No / Name : 206 / 11KV Ashta Pump House

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7865	.6584	.7682	.6036	.6767	.6584	.7682
2	.7499	.6401	.7865	.6099	.6584	.6584	.7865
3	.7316	.6219	.7499	.6099	.6036	.695	.8048
4	.7682	.5853	.7316	.5914	.5853	.695	.7865
5	.7865	.6584	.7682	.6161	.6401	.6767	.8413
6	.8413	.7316	.8048	.6908	.6767	.6767	.8048
7	.8596	.8779	.8413	.8402	.7865	.7865	.8048
8	.8962	.8048	.8779	.7468	.8048	.7316	.8779
9	.8048	.7133	.7682	.6401	.7133	.695	.7682
10	.6767	.6767	.6584	.6767	.695	.6401	.695
11	.1097	.7133	.7316	.7316	.7133		.6401
12		.695	.8048	.7499	.6584		.7682
13		.7133	.695	.6401	.5853		.6767
14		.7316	.6584	.5853	.5853		.6401
15	.6584	.6584	.6401	.6584	.6219		.6767
16	.6219	.5487	.567	.5853	.6036		.7133
17	.5853	.6219	.567	.5853	.567		.6584
18	.7499	.7133	.6219	.6584	.8779		.7316
19	.8962	.8596	.823	.8596	.9511		.9694
20	.9328	.9694	1.0059	1.0608	.9877		1.134
21	.9694	.9328	.9694	1.0059	.9511		1.0791
22	.8962	.8596	.9328	.9145	.9145		.9694
23	.7499	.8413	.7682	.8048	.7865		.7865
24	.8596	.6584	.7865	.6219	.7133	.6401	.7865
Max	.9694	.9694	1.0059	1.0608	.9877	.7865	1.134
Min	.1097	.5487	.567	.5853	.567	.6401	.6401
Avg	.7586	.7285	.7636	.7120	.7232	.6867	.7987

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244124 / 33/11KV KOREGAON SUBSTATION

Feeder No / Name : 201 / 11KV KOREGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.2801	.3772	.2829	.2957	.3018	.3018
2	.3206		.3395	.2829	.2829	.2987	.3018
3	.3142		.3395	.2829	.2801	.2987	.3018
4	.3326		.3395	.2829	.2987	.3361	.3018
5	.3734		.3961	.3206	.3395	.3772	.3395
6	.4668		.4854	.4715	.4338	.4715	.5281
7	.5658		.5975	.5415	.5228	.5175	.5914
8	.4294		.499	.462	.4435	.4525	.5304
9	.3696		.4163	.4024	.3761	.4525	.4477
10	.362		.4075	.3155	.4207	.4075	.3898
11	.3366		.3856	.333	.3544	.3898	.3761
12	.2865	.2835	.3582	.3366	.3012	.3258	.3582
13	.2686	.3077	.3224	.298	.3012	.3077	.3224
14	.2715	.3077	.3077	.2865	.2865	.3292	.3224
15	.2033	.2715	.3045	.2896	.2865	.3258	.3258
16	.2012	.3045	.3403	.3045	.2896	.3439	.3292
17	.3258	.4161	.3403	.3155	.3582	.3582	.3439
18	.3224	.4075	.3366	.3641	.4031	.3681	.3544
19	.4435	.5601	.5175	.5068	.4706	.4755	.5249
20	.5788	.6283	.5975	.5975	.5914	.3696	.5914
21	.5853	.6161	.5788	.5415	.5975	.5788	.5788
22	.547	.547	.5281	.5093	.5415	.5093	.4715
23	.3961	.4904	.3772	.3734	.3961	.3772	.3584
24	.3395	.3206	.4527	.3018	.3018	.3395	.3206
Max	.5853	.6283	.5975	.5975	.5975	.5788	.5914
Min	.2012	.2715	.3045	.2829	.2801	.2987	.3018
Avg	.3742	.4101	.4144	.3751	.3822	.3880	.4005

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244124 / 33/11KV KOREGAON SUBSTATION

Feeder No / Name : 202 / 11KV Bhadurwadi AG
(Koregaon) Feeder KV- 11 /
OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6882	.3704	.4321	.3121	.0739	.0867	.0924
2	.6882		.4321	.2934	.0747	.0876	.0914
3	.6802		.4115	.2934	.0754	.0876	.0924
4	.6882		.4115	.2972	.0739	.0886	.0914
5	.7701		.442	.2972	.0739	.0895	.0914
6	.8097		.4816	.3201	.0943	.0905	.112
7	.8482		.5117	.4062	.0943	.128	.1494
8	.1132		.1109	.1075	.0914	.1097	.1267
9	.1097		.1097	.6405	1.0279	1.1544	.1097
10	.0857		.1214	.7773	1.1544	1.3125	.112
11	.0848		.0983	.9374	1.1561	1.4232	.1294
12	.0663	.0857	.1006	.9877	1.1717	1.3757	.112
13	.0716	.1063	.0848	1.0031	1.1873	1.3757	.1075
14	.0724	.1052	.0848	1.0031	1.1883	1.3757	.1086
15	.0716	.0867	.0867	.9877	1.2037	1.3599	.1097
16	.1017	.1029	.0914	.7253	1.2191	1.3125	.1086
17	.0886	.4607	.1097	.0819	.0857	.0838	.1075
18	.0876	.4967	.0914	.0829	.0886	.1029	.1433
19	.1029	.0857	.1307	.104	.0886	.1086	.1086
20	.0914	.0886	.1097	.1097	.1063	.1075	.1086
21	.0914	.0867	.1097	.0732	.1075	.1086	.1109
22	.4428	.4191	.3311	.0739	.0895	.1097	.9842
23	.3906	.4268	.3121	.0724	.0867	.0924	.953
24	.6882	.381	.4321	.3121	.0716	.0867	.0924
Max	.8482	.4967	.5117	1.0031	1.2191	1.4232	.9842
Min	.0663	.0857	.0848	.0724	.0716	.0838	.0914
Avg	.3306	.2359	.2349	.4291	.4452	.5108	.1814

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 244124 / 33/11KV KOREGAON SUBSTATION

Feeder No / Name : 203 / 11KV Koregaon AG

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0309	.0286	.048	.0271	.535	.535	.9488
2	.0324		.0324	.0274	.5335	.535	.933
3	.0328		.0328	.0274	.5117	.5569	.933
4	.0335		.0332	.0274	.5053	.5569	.9217
5	.0514		.0339	.0274	.5117	.5498	.9061
6	.052		.0514	.0526	.5335	.5719	.9762
7	.0549		.052	.0537	.6249	.6321	1.0623
8	.0509		.052	.0309	.048	.0457	.0457
9	1.4403		.9259	.0301	.0221	.0429	1.7924
10	1.3916		.9957	.0383	.0366	.0389	1.8623
11	1.4232		1.0105	.0343	.0343		1.8976
12	1.3916	.8907	.9934	.021	.0332		2.0557
13	1.3283	.8488	1.0059	.0236	.0332		2.1032
14	1.3279	.8993	.9568	.021	.0332		2.1664
15	.9568	.8993	.9214	.0251	.032		2.1765
16	.9145	.873	.9105	.0225	.0309	.0248	2.1605
17	.0229	.0314		.0303	.0366	.0259	.0349
18	.0349	.0225	.0236	.0343	.0389	.0343	.032
19	.0474	.0263	.0469	.0434	.0412	.0463	.044
20	.0486	.0452	.0305	.0434	.0429	.0457	.0297
21	.0429	.0429	.0474	.0423	.0446	.0324	.0305
22	.0492	.0486	.0457	.5868	.5428	.9686	.0335
23	.0312	.0469	.0274	.5502	.5281	.953	.0335
24	.0305	.0282	.048	.0267	.5144	.5201	.9488
Max	1.4403	.8993	1.0105	.5868	.6249	.9686	2.1765
Min	.0229	.0225	.0236	.021	.0221	.0248	.0297
Avg	.4509	.3380	.3620	.0770	.2437	.3535	1.0053

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 201 / 11KV MARDWADI 1PH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	.0886
Max	.0886
Min	.0886
Avg	.0886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 202 / 11KV KARANDWADI 1PH SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	.3256
Max	.3256
Min	.3256
Avg	.3256

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 204 / 11 KV FALKEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	.3827
Max	.3827
Min	.3827
Avg	.3827

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 401 / 33 KV MARDWADI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	.8596
Max	.8596
Min	.8596
Avg	.8596

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 403 / 33 KV Ashta

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	2.0199
Max	2.0199
Min	2.0199
Avg	2.0199

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 404 / 33KV Kasbe Digraj
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	1.9136
Max	1.9136
Min	1.9136
Avg	1.9136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 405 / 33 KV Nagaon

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	1.2757
Max	1.2757
Min	1.2757
Avg	1.2757

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 406 / 33 KV Koregaon

PURELY LIS FEEDERS

Feeder KV- 33 / INCOMING

DATE	01-SEP-17
HR	Load (MW)
24	.8505
Max	.8505
Min	.8505
Avg	.8505

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ASTHA[074]

BU 6246

Substation No/ Name :- 246003 / 110/33/11 KV ASHTA S/S

Feeder No / Name : 407 / 33 KV Kasturi

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	4.768
Max	4.768
Min	4.768
Avg	4.768

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 201 / 11 KV ISLAMPUR-I FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2437	1.1088	1.2696	1.1203	1.2197	1.1706	1.2197
2	1.1706	1.0719	1.2696	1.1203	1.2197	1.1827	1.1827
3	1.0974	1.0829	1.2696	1.0719	1.2197	1.1458	1.1827
4	1.0974	1.0829	1.2696	1.0719	1.2567	1.1458	1.1827
5	1.134	1.1203	1.3203	1.1576	1.4045	1.0974	1.1827
6	1.3169	1.307	1.3203	1.2567	1.307	1.1706	1.0719
7	1.6461	1.5844	1.5684	1.4784	1.5844	1.4632	1.531
8	1.6827	1.6598	1.6263	1.5893	1.643	1.4118	1.5893
9	1.643	1.5684	1.419	1.531	1.4998	1.4415	1.4563
10	1.829	1.8298	1.6461	1.7924	1.643	1.6827	1.7193
11	1.4045	1.3817	1.4415	1.4415	1.3676	1.4266	1.4998
12	1.3306	1.5154	1.4632	1.4632	1.2803	1.4784	1.5524
13	1.2936	1.4415	1.3394	1.3306	1.2197	1.4045	1.5154
14	1.2197	1.3676	1.3306	1.3676	1.1458	1.3306	1.4415
15	1.1203	1.3676	1.3306	1.2197	1.2197	1.3169	1.4045
16	1.0829	1.3306	1.4045	1.2936	1.2197	1.3306	1.4045
17	1.1203	1.2437	1.39	1.39	1.2437	1.3306	1.39
18	1.1576	1.4632	1.4632	1.3535	1.4632	1.3676	1.4266
19	1.8111	2.1068	1.9791	1.922	1.8656	2.0538	2.0851
20	1.922	1.9589	2.0165	2.0165	1.848	1.9791	2.0119
21	1.7741	1.8671	1.8111	1.8111	1.7193	1.8298	1.829
22	1.6804	1.7924	1.6632	1.7372	1.6461	1.8298	1.7013
23	1.419	1.5893	1.4045	1.5154	1.4266	1.5524	1.5729
24	1.3169	1.1458	1.3306	1.2071	1.2197	1.2437	1.3306
Max	1.922	2.1068	2.0165	2.0165	1.8656	2.0538	2.0851
Min	1.0829	1.0719	1.2696	1.0719	1.1458	1.0974	1.0719
Avg	1.3964	1.4578	1.4728	1.4275	1.4118	1.4328	1.4785

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 202 / 11 KV Peth Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8048	.7545	.7468	.7095	.7095	.7682	.8215
2	.7316	.7095	.7468	.7095	.7095	.7762	.8215
3	.7316	.6722	.7468	.6653	.7095	.7392	.8215
4	.7392	.6653	.7468	.6653	.7095	.7316	.8215
5	.8131	.7023	.7922	.7023	.7095	.7316	.8962
6	.9671	1.1203	.7922	1.2567	1.0829	.9774	1.0829
7	1.2567	1.307	1.307	1.2323	1.2449	.9511	1.2826
8	1.267	1.2567	1.1576	1.2323	1.1203	1.0719	1.1576
9	1.0456	1.1827	.9709	1.0082	1.0349	1.0608	.961
10	1.0242	1.0242	1.0059	.9877	.961	.9412	.9774
11	.9511	.9145	.8507	.8596	.8688		.9412
12	.8238	.8596	.7964		.7682	.6805	.8596
13	.788	.788	.7682	.7602	.7602	.543	.7964
14	.7762	.788	.7316	.7964	.8048	.6584	.7783
15	.7023	.8596	.8048	.8413	.8779	.7602	.823
16	.7762	.7522	.8326	.5544	.7602	.8779	.7964
17	.8413	.788	.8326	.8048	.8413	.8413	.8413
18	.9877	.9774	.8326	.8048	.8779	.9511	.9511
19	1.3676	1.3817	1.3443	1.2696	1.1706	1.3306	1.2936
20	1.5154	1.4937	1.4937	1.4937	1.39	1.419	1.39
21	1.419	1.4563	1.3676	1.3817	1.4415	1.3443	1.3169
22	1.3443	1.3817	1.2567	1.2323	1.2071	1.2696	1.2803
23	1.0082	1.1203	.9979	1.0082	.9877	1.0829	1.0498
24	.8779	.7922	.9335	.7842	.7842	.7682	.8589
Max	1.5154	1.4937	1.4937	1.4937	1.4415	1.419	1.39
Min	.7023	.6653	.7316	.5544	.7095	.543	.7783
Avg	.9817	.9895	.9523	.9461	.9388	.9251	.9842

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 203 / 11 KV LIS FEEDER

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5228	.7922	.9335	.8962	.7164	.8589
2	.5975	.7922	1.0164	1.0456	.7164	.8589
3	.7468	.7922	1.0164	1.0456	.7602	.8589
4	.7922	.7922	1.0829	1.0456	.7964	.8589
5	.7922	.8002	1.1949	1.2936	.7442	.8589
6	.8299	.8002	1.2936	1.3443	.7522	.8962
7	.8676	1.3203	1.2567	.0688	1.2536	.8589
8	1.1949	1.3203	1.2696	.0583	1.2048	1.307
9	.8676	1.3306	1.2936	.394	1.2936	1.2936
10	.8299	1.3121	1.2936	.9808	1.3676	1.2567
11	.9054	1.3306	1.2936	.9054	1.3676	1.2567
12	.8676	1.3306	1.2936	1.2936	1.3306	1.2567
13	.8299	1.2567	1.2936	1.3306	1.3306	1.2567
14	.9054	1.2567	1.2936	1.3306	1.3306	1.2936
15	.9054	1.2936	1.2936	1.3121	1.2936	1.2936
16	.3429	.4961	.3395	.1928	.2553	.2218
Max	1.1949	1.3306	1.2936	1.3443	1.3676	1.307
Min	.3429	.4961	.3395	.0583	.2553	.2218
Avg	.7999	1.0636	1.1537	.9086	1.0321	1.0304

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 204 / 11 KV ISLAMPUR-II FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1109	.1109	.132	.112	.1307	.1086	.1307
2	.1109	.1109	.132	.112	.1307	.1086	.1307
3	.1097	.112	.132	.1109	.1307	.1097	.1307
4	.1097	.112	.132	.1109	.1307	.1097	.1307
5	.1097	.112	.132	.112	.1307	.1109	.1307
6	.1478	.1867	.1509	.1478	.1307	.1448	.168
7	.2172	.1848	.1886	.1848	.1698	.1463	.2075
8	.181	.1848	.2241	.1478	.1848	.1829	.1698
9	.1848	.1848	.1478	.128	.1433	.1463	.1494
10	.1448	.1463	.1075	.1086	.1097	.1448	.128
11	.1448	.0914	.1075	.1052	.1086	.1267	.1063
12	.1075	.1075	.1086		.1109	.1086	.1075
13	.1075	.124	.1086	.1372	.0905	.1075	.0905
14	.1097	.1063	.0914	.1086	.0732	.1075	.104
15	.1109	.124	.0732	.1086	.0924	.1075	.1109
16	.1109	.124	.0905	.1097	.0914	.0924	.0747
17	.112	.1417	.1086	.124	.1097	.1267	.112
18	.112	.1097	.2195	.124	.1097	.1267	.112
19		.1867	.1867	.2012	.1848	.2012	.1848
20	.2241	.2054	.2241	.2241	.1848	.2033	.2195
21	.2241	.1867	.1867	.1867	.1848	.2241	.2241
22	.1867	.1867	.1867	.1867	.1848	.2054	.2218
23	.1494	.168	.1494	.1494	.1463	.1307	.1829
24	.1109	.1109	.1494	.112	.1307	.1097	.1307
Max	.2241	.2054	.2241	.2241	.1848	.2241	.2241
Min	.1075	.0914	.0732	.1052	.0732	.0924	.0747
Avg	.1407	.1424	.1446	.1371	.1331	.1371	.1441

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 205 / 11 KV ISLAMPUR AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0175	.0187	.0189	.1128	.1505	.208	.0189
2	.0175	.0189	.0189	.1128	.1505	.2103	.0189
3	.0177	.0189	.0189	.1128	.1505	.2103	.0189
4	.0177	.0187	.0189	.1128	.1505	.208	.0189
5	.0175	.0187	.0189	.1143	.1677	.208	.0189
6	.0175	.0189	.0377	.2	.1829	.2454	.0377
7	.0351	.0377	.0566	.2027	.253	.2804	.0377
8	.0351	.0377	.0566	.0709	.112	.0351	.037
9	.3311	.2972	.301	.0739	.0373	.0373	.3479
10	.3353	.301	.3241	.0747	.0739	.0566	.4111
11	.3353	.2675	.3395	.0739	.0747	.0377	.3549
12	.3353	.2526	.3048	.0739	.0747	.0373	.3704
13	.2972	.2526	.3353	.0747	.0924	.0377	.3311
14	.2675	.2526	.2709	.0373	.0747	.0377	.3353
15	.2378	.2347	.2709	.0373	.0747	.0377	.3241
16	.2317	.2201	.2606	.0747	.0732	.0377	.3121
17	.0351	.0187	.0532	.0549	.0366	.0373	.0173
18	.0358	.0189	.0543	.0549	.0366	.0373	.0351
19	.037	.0377	.0747	.056	.0362	.0373	.0532
20	.0373	.0377	.0754	.0747	.0358	.0377	.0351
21	.0373	.0377	.0754	.0747	.0358	.0377	.0347
22	.0377	.0377	.1715	.2031	.2774	.0189	.0343
23	.0189	.0189	.141	.1852	.2401	.0189	.0173
24	.0351	.0187	.0189	.1128	.1677	.2103	.0189
Max	.3353	.301	.3395	.2031	.2774	.2804	.4111
Min	.0175	.0187	.0189	.0373	.0358	.0189	.0173
Avg	.1175	.1039	.1382	.0990	.1150	.0984	.1350

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244005 / 33/11KV ISLAMPUR

Feeder No / Name : 401 / 33KV Ganesh Nagar

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1148	1.6575	2.0576	2.0302	2.1148	2.2291	1.829
2	1.9433	1.5432	1.9433	1.9204	2.0005	2.0576	1.7718
3	1.8861	1.5432	1.829	1.8107	1.8861	2.0005	1.7718
4	1.8861	1.6004	1.829	1.8107	1.829	2.0576	1.829
5	2.0576	1.9433	1.9433	2.0302	1.9433	2.2291	2.0576
6	2.572	2.4006	2.2862	2.5789	2.6863	2.5149	2.4006
7	2.1148	2.572	2.572	2.963	3.2579	2.915	2.6292
8	2.8578	2.6863	2.572	2.5789	2.2291	2.4577	2.572
9	3.3722	3.0293	2.8532	2.3434	2.3434	2.1148	2.8578
10	3.315	3.1436	3.1276	2.3434	2.4006	2.1148	3.4294
11	3.0864	3.0293	2.7984	2.0576	2.0576	2.0576	2.9721
12	2.9721	2.9721	2.8532	1.9433	1.9433	2.0576	2.915
13	2.9721	2.5149	2.7435	1.9433	1.8861	1.9433	2.9721
14		2.8006	2.4691	1.9433	1.829	1.9433	3.0864
15	1.0288	2.6292	2.5789	1.7718	1.829	1.9433	2.9721
16	2.6863	2.8006	2.5789	2.0576	1.829	2.0005	2.6292
17	2.1148	2.0005	1.8107	1.9433	1.8861	2.1148	2.8006
18	2.2291	2.1719	1.9753	2.2862	2.1719	2.1148	3.0293
19	3.1436	3.2007	2.9081	2.915	3.0293	3.1436	3.2007
20	3.2007	3.2007	3.1824	3.315	2.9721	3.1436	3.3722
21	3.0293	2.9721	2.9081	2.915	2.8006	2.915	3.1436
22	2.8578	2.8578	2.963	2.9721	2.6292	2.8006	2.8578
23	2.1719	2.4006	2.4691	2.4577	2.6292	2.2862	2.4577
24	2.2862	1.7718	2.0576	2.0302	2.2291	2.2862	1.9433
Max	3.3722	3.2007	3.1824	3.315	3.2579	3.1436	3.4294
Min	1.0288	1.5432	1.8107	1.7718	1.829	1.9433	1.7718
Avg	2.5173	2.4768	2.4712	2.2901	2.2672	2.3101	2.6458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 201 / 11 KV MIDC FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2826	.6036	1.094	.9997	1.094	1.0562	1.0562
2	1.2826	.6036	1.094	.9997	1.094	1.0562	1.0562
3	1.2826	.6036	1.094	.9997	1.094	1.0562	1.0562
4	1.2826	.6036	1.094	.9997	1.094	1.0562	1.0562
5	1.2826	.6036	1.094	.9431	1.0751	1.1506	1.0562
6	.8676	.7545	.9808	1.094	1.0185	1.0562	1.1128
7	.8865	.7733	1.094	1.1694	1.0185	1.0185	1.1317
8	.6036	.8299	.9054	.9431	.9808	.9808	1.1694
9	.6036	1.1317	1.2071	.7316	1.1317	1.1317	1.3769
10	.6413	1.4523	1.5466	1.6975	1.3957	1.4712	1.5089
11	.6413	1.4712	1.7164	1.6975	1.5089	1.5089	1.4712
12	.6413	1.3203	1.5278	1.6975	1.4712	1.5844	1.5466
13	.6413	1.4712	1.3392	1.3957	1.2826	1.5089	1.4335
14	.6413	1.5089	1.4712	1.5278	1.2826	1.3957	1.3957
15		1.5844	1.4901		1.2826	1.5089	1.6032
16	.6036	1.5089	1.4901	1.6032	1.4335	1.5089	1.6032
17	.6036	1.3957	1.3392	1.6032	1.2826	1.3957	1.4335
18	.6036	1.2637	1.1317	1.358	1.0185	1.0185	1.226
19	.6036	1.2449	1.2071	1.1694	1.0185	1.0185	1.2449
20	.6036	1.094	1.0185	.9997	1.0562	1.086	1.1317
21	.6036	1.2003	1.0185		1.0562	1.1431	1.0562
22	.6036	1.2637	1.1128	1.0374	1.0562	1.0562	1.1883
23	.6036	1.2449	1.2071	1.0374	1.1317	.9997	1.2071
24	1.2826	.6036	1.0751	.7545	1.094	1.094	1.0751
Max	1.2826	1.5844	1.7164	1.6975	1.5089	1.5844	1.6032
Min	.6036	.6036	.9054	.7316	.9808	.9808	1.0562
Avg	.8127	1.0890	1.2229	1.2027	1.1655	1.2026	1.2582

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 202 / 11 KV SAKHRALE GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.0914	.1509	.1509	.1463	.0914	.1132
2	.1463	.0914	.1509	.1509	.1463	.0914	.1132
3	.1463	.0914	.1509	.1509	.1463	.0914	.1132
4	.1463	.0914	.1509	.1509	.1463	.1463	.1132
5	.1463	.1463	.1509	.1509	.1463	.1829	.1132
6	.2195	.1829	.2263	.2263	.2195	.2012	.2263
7	.2195	.2195	.2829	.3018	.2561	.2561	.2829
8	.1463	.1829	.1867	.2012	.2561	.2012	.1886
9	.1463	.1463	.1494	.2054	.1463	.2012	.1478
10	.1463	.1494	.1307	.1463	.1463	.1463	.1646
11	.1097	.1294	.1448	.1463	.1463	.1478	.1463
12	.1097	.128	.1267	.1097	.1097	.1478	.1463
13	.1097	.1448	.1267	.1097	.1097	.1109	.1448
14	.0914	.1267	.0924	.1097	.1097	.1109	.1448
15	.0914	.1086	.1097	.0189	.0171	.112	.1448
16	.1097	.1294	.128	.0189	.128	.112	.1254
17	.1097	.1294	.1448	.1463	.128	.1478	.124
18	.1463	.1463	.1448	.1829	.1463	.1478	.1417
19	.2195	.2218	.2561	.2195	.1829	.2012	.2218
20	.2195	.2641	.2987	.2195	.1829	.2614	.2801
21	.2195	.2641	.2241	.1463	.1829	.2263	.2241
22	.1829	.2263	.2241	.1463	.1829	.1886	.2241
23	.1463	.1886	.1886	.1463	.1097	.1509	.1886
24	.1463	.0914	.1509	.1509	.1463	.0914	.132
Max	.2195	.2641	.2987	.3018	.2561	.2614	.2829
Min	.0914	.0914	.0924	.0189	.0171	.0914	.1132
Avg	.1509	.1538	.1705	.1544	.1516	.1569	.1652

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 203 / 11 KV BAHE AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.5937	.535	.0189		.0171	.7316
2	.6097	.5937	.535	.0189	.0189	.0171	.7316
3	.6097	.5937	.535	.0189	.0189	.0171	.7316
4	.6097	.5937	.535	.0189	.0189	.0171	.7316
5	.6097	.5937	.535	.0189	.0189	.0171	.7316
6	.823	.6562	.535	.0189	.0189	.0171	.7407
7	.9145	.7499	.7011	.0189	.0189	.0171	.8905
8	.0189	.0171	.0189	.0189	.0189	.0171	.0189
9	.0189	.0171	.0189	1.0059	1.2334	1.3443	.0189
10	.0171	.0179	.0189	1.1248	1.5364	1.3283	.0189
11	.0171	.0185	.0189	1.1248	1.5684	1.3283	.0189
12	.0171	.0177	.0189	1.2186	1.5364	1.3283	.0189
13	.0171	.0179	.0189	1.2186	1.5043	1.3283	.0189
14	.0171	.0181	.0189	1.2186	1.4083	1.3123	.0189
15	.0171	.0183	.0189	1.2186	1.4083	1.3283	.0189
16	.0171	.0187	.0189	1.1248	1.3443	1.3443	.0189
17	.0171	.0183	.0189	.0189	.0171	.0189	.0189
18	.0171	.0181	.0189	.0189	.0171	.0189	.0189
19	.0171	.0189	.0189	.0189	.0171	.0189	.0187
20	.0171	.0189	.0189	.0189	.0171	.0189	.0189
21	.0171	.0189	.0189		.0171	.0189	.0189
22	.5624	.5213	.0189	.0189	.0171	.7316	.933
23	.6249	.5213	.0189	.0189	.0171	.7316	.9488
24	.6097	.6249	.5213	.0189	.0189	.0171	.7316
Max	.9145	.7499	.7011	1.2186	1.5684	1.3443	.9488
Min	.0171	.0171	.0189	.0189	.0171	.0171	.0187
Avg	.2844	.2624	.1973	.4147	.5135	.5148	.3403

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 204 / 11 KV DUDH SANGH FEEDER

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3395	.2641	.5281	.3772	.4338	.3206
2	.3772	.3395	.2641	.5281	.3772	.4338	.3206
3	.3772	.3395	.2641	.5281	.3772	.4338	.415
4	.3772	.3395	.2641	.5281	.3772	.4338	.415
5	.3772	.3772	.2641	.3584	.4338	.415	.415
6	.2829	.3018	.2641	.3395	.4527	.2829	.3018
7	.2452	.2263	.2829	.2829	.3772	.2641	.2829
8	.3206	.2452	.2452	.2829	.2641	.2829	.2641
9	.3206	.3584	.2641	.3395	.3206	.4527	.3584
10	.3772	.4527	.3584	.4338	.415	.3961	.4715
11	.4904	.4527	.4904	.4338	.4904	.3772	.5281
12	.4904	.4527	.5093	.4715	.4715	.3584	.5281
13	.3772	.415	.4715	.4715	.4715	.4527	.5281
14	.3772	.3584	.4338	.3772	.4338	.4715	.5281
15	.415	.3018	.4715	.3772	.4338	.4904	.5281
16	.3772	.3018	.3772	.5093	.4527	.4904	.4715
17	.3395	.3395	.4338	.5093	.4527	.5281	.4715
18	.3395	.3395	.4904	.5093	.4904	.547	.4715
19	.3395	.3961	.415	.5093	.4338	.4904	.547
20	.3772	.3395	.4338	.4715	.4338	.4338	.5093
21	.415	.3584	.4527		.4338	.4904	.5281
22	.3772	.3206	.547	.3772	.4527	.4527	.4527
23	.3395	.3395	.5281	.3772	.4527	.4338	.4527
24	.3772	.3395	.2641	.4715	.3772	.4338	.415
Max	.4904	.4527	.547	.5281	.4904	.547	.547
Min	.2452	.2263	.2452	.2829	.2641	.2641	.2641
Avg	.3694	.3489	.3772	.4354	.4189	.4283	.4385

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 205 / 11 KV NAGARPALIKA PWW
FEEDER Feeder KV- 11 /
OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3772	.3772	.3584	.415	.415	.3772
2	.3395	.3772	.3772	.3584	.415	.415	.3772
3	.3395	.3772	.3772	.3584	.415	.415	.3772
4	.3395	.3772	.3772	.3584	.415	.3772	.3772
5	.3395	.3395	.3772	.3018	.415	.3395	.3772
6	.415	.4338	.3772	.3961	.4904	.4527	.2452
7	.4527	.4527	.4527	.4527	.4527	.4715	.3018
8	.4527	.4527	.4904	.439	.4527	.4715	.3206
9	.4527	.4715	.4715	.4527	.4904	.4715	.3018
10	.4338	.5335	.4904	.415	.4527	.415	.3395
11	.3772	.4904	.5093	.415	.4527	.4338	.3395
12	.2641	.4527	.5093	.4527	.5093	.5281	.2641
13		.4527	.415	.4527	.4904	.4904	.2641
14		.4904	.4715	.4904	.4904	.4904	.3018
15		.4904	.4715	.4904	.4904	.4904	.3018
16		.4715	.4715	.4527	.4715	.4904	.415
17		.4715	.4715	.4527	.4715	.4527	.3395
18		.4715	.4527	.415	.4715	.415	.3206
19	.2263	.3584	.3772	.415	.415	.3584	.3395
20	.2263	.3395	.3018	.3018	.3395	.3395	.3206
21	.2641	.2534	.3018	.2263	.2263	.1505	.1698
22	.2641	.1486	.2035	.2263	.2263	.2035	.1886
23	.2641	.2058	.2126	.2263	.3395	.2987	.3772
24	.3395	.3772	.3772	.2658	.415	.3961	.3772
Max	.4527	.5335	.5093	.4904	.5093	.5281	.415
Min	.2263	.1486	.2035	.2263	.2263	.1505	.1698
Avg	.3406	.4028	.4048	.3823	.4260	.4076	.3214

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 206 / 11 KV Kapuskhed Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.1097	.132	.132	.1097	.1097	.132
2	.1097	.1097	.132	.132	.1097	.1097	.132
3	.1097	.1097	.132	.132	.1097	.1097	.132
4	.1097	.1097	.132	.132	.1097	.1097	.132
5	.1097	.1829	.132	.1509	.1463	.1829	.132
6	.1829	.2561	.2263	.1829	.2195	.2195	.2075
7	.2641	.2743	.2452	.2263	.2195	.2743	.2263
8	.1829	.2195	.2054	.1867	.2195	.1829	.1886
9	.1463	.1463	.112	.1307	.1463	.1463	.1463
10	.1097	.1109	.0934	.1097	.1097	.1052	.0914
11	.1097	.1075	.1052	.1097	.1097	.0886	.1052
12	.0914	.1029	.12	.0732	.128	.0716	.104
13	.0914	.1063	.1029	.0732	.0914	.1075	.1052
14	.0914	.0876	.1029	.0732	.0914	.1063	.1029
15	.0886	.1052	.1052	.1097	.0914	.1075	.1029
16	.0914	.0934	.1227	.1097	.1097	.1254	.1402
17	.1097	.1097	.1029	.1097	.1097	.1097	.1402
18	.128	.1267	.1029	.1463	.1463	.0924	.1402
19	.2195	.1848	.1646	.1829	.1829	.1663	.1848
20	.2195	.2263	.2075	.2195	.2378	.2241	.2241
21	.2195	.1886	.2054	.2195	.2012	.2075	.2054
22	.1829	.1886	.1867	.1829	.1829	.1886	.1867
23	.1463	.1509	.1698	.1463	.1463	.132	.1698
24	.1097	.1097	.132	.132	.1097	.128	.132
Max	.2641	.2743	.2452	.2263	.2378	.2743	.2263
Min	.0886	.0876	.0934	.0732	.0914	.0716	.0914
Avg	.1389	.1465	.1447	.1418	.1433	.1419	.1485

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 207 / 11 KV SAKHRALE Ag FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0171	.0183	.3086	.3795	.2561	.0183
2	.0189	.0171	.0183	.3086	.3795	.2561	.0183
3	.0189	.0171	.0183	.3086	.3795	.2561	.0183
4	.0189	.0171	.0183	.3048	.3795	.2561	.0183
5	.0189	.0171	.0183	.3048	.3795	.2561	.0183
6	.0189	.0171	.0183	.3241	.3749	.2881	.0185
7	.0189	.0171	.0171	.381	.3795	.3201	.0179
8	.7545	.0164	.0171	.0139	.0189	.0171	.0173
9	.6325	.5243	.506	.0143	.0189	.0171	.8421
10	.7274	.5376	.5535	.0189	.0171	.0149	.9069
11	.7274	.5376	.6009	.0189	.0171	.0149	.9393
12	.7274	.5376	.6009	.0189	.0171	.0149	.9282
13	.6958	.5312	.6325	.0189	.0171	.0145	.8962
14	.6642	.5312	.5624	.0189	.0171	.0133	.8962
15	.6642	.506	.5468	.0189	.0171	.0141	.9282
16	.6325	.4877	.5401	.0189	.0171	.0143	.7682
17	.0171	.0156	.0133	.0189	.0171	.0145	.0131
18	.0171	.0164	.0133	.0189	.0171	.0147	.0131
19	.0171	.0179	.0187	.0189	.0171	.0177	.0152
20	.0171	.0185	.0175	.0189	.0171	.0175	.0175
21	.0171	.0183	.0189	.0171	.0171	.0175	.0175
22	.0171	.0168	.3437	.3795	.2743	.0175	.0177
23	.0171	.0183	.3395	.3795	.2561	.0177	.0175
24	.0189	.0171	.0183	.3395	.3795		.0175
Max	.7545	.5376	.6325	.381	.3795	.3201	.9393
Min	.0171	.0156	.0133	.0139	.0171	.0133	.0131
Avg	.2707	.1862	.2279	.1497	.1585	.0931	.3075

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 209 / 11 KV Siddhanath LIS
feeder Feeder KV- 11 /
OUTGOING

PURELY LIS FEEDERS

DATE	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.016	.2652	.2561	.3315	.2881	.3481
2	.016	.2652	.2561	.3315	.2881	.3481
3	.016	.2652	.2561	.3315	.2881	.3481
4	.016	.2652	.2561	.3315	.2881	.3812
5	.016	.2652	.2561	.3315	.3041	.3812
6	.016	.2652	.2561	.3315	.3041	.3812
7	.016	.2652	.2721	.3315	.3041	.3812
8	.1898	.2652	.3077	.3315	.3041	.3647
9	.2622	.2652	.3041	.3481	.3681	.3812
10	.2818	.2652	.3149	.3681	.3681	.3812
11	.2818	.2984	.3149	.3681	.3812	.3812
12	.2818	.2818	.3149	.3681	.3812	.3812
13	.2652	.3277	.3149	.3681	.3812	.3812
14	.2652	.3113	.3315	.3681	.3812	.3812
15	.2652	.3647	.3315	.3681	.3812	.3812
16	.2652		.3315	.3521	.3812	.3812
Max	.2818	.3647	.3315	.3681	.3812	.3812
Min	.016	.2652	.2561	.3315	.2881	.3481
Avg	.1544	.2824	.2922	.3476	.3370	.3740

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244033 / 33/11 KV MIDC

Feeder No / Name : 401 / 33 KV EXPRESS FEEDER

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.358	1.1431	1.4861	1.4712	1.2449	1.2003	1.829
2	1.358	1.1431	1.4861	1.4712	1.2449	1.2003	1.829
3	1.358	1.1431	1.4861	1.3014	1.2449	1.2003	1.829
4	1.358	1.1431	1.4861	1.3014	1.2449	1.2003	1.829
5	1.358	1.1431	1.4861	1.2449	1.2449	1.1431	1.829
6	1.358	1.3146	1.4861	1.4146	1.2449	1.2003	1.8861
7	1.358	1.2574	1.4861	1.358	1.2449	1.2574	1.829
8	1.2449	1.1431	1.4861	1.2449	1.358	1.2003	1.829
9	1.1317	1.1431	1.6004	1.3014	1.358	1.2003	2.0576
10	1.1431	1.6004	1.6409	1.358	1.3717	1.6004	1.9239
11	1.1431	1.6004	1.5844	1.358	1.3146	1.6004	2.0936
12	1.1431	1.4861	1.3014	1.358	.8573	1.7147	1.9239
13	1.1431	1.4861	1.4146	1.358	.6859	1.7718	1.9805
14	1.1431	1.4289	1.4712	1.4712	.6859	1.829	1.9239
15	1.1431	1.4861	1.4712	1.4712	.6859	1.829	1.358
16	1.2574	1.2574	1.5844	1.358	.6859	1.829	1.3014
17	1.2574	1.2574	1.5278	1.358	.6859	1.829	1.2449
18	1.1431	1.4861	1.5278	1.2449	.6859	1.7147	1.1883
19	1.1431	1.4289	1.4712	1.2449	.6859	1.829	1.6409
20	1.1431	1.5432	1.4712	1.1317	1.0288	1.829	1.8107
21	1.2003	1.3717	1.5278	1.358	1.1431	1.829	1.6975
22	1.2003	1.4861	1.4146	1.358	1.1431	1.829	1.7541
23	1.2003	1.4861	1.4712	1.358	1.1431	1.829	1.9239
24	1.4712	1.2003	1.4861	1.4712	1.2449	1.1431	1.829
Max	1.4712	1.6004	1.6409	1.4712	1.3717	1.829	2.0936
Min	1.1317	1.1431	1.3014	1.1317	.6859	1.1431	1.1883
Avg	1.2399	1.3408	1.4940	1.3486	1.0616	1.5337	1.7642

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244053 / 33/11 KV RETHRE HARNAX STN

Feeder No / Name : 201 / 11 KV RHX & TAKARI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.415	.415	.4338	.4338	.4338	.4527
2	.3772	.3961	.415	.415	.4338	.4294	.4527
3	.4715	.3961	.3772	.415	.4338	.439	.4668
4	.5601	.4527	.5415	.4527	.4527	.5228	.5415
5	.6161	.5658	.7167	.4904	.4904	.6413	.6535
6	.6535	.7545	.7733	.679	.5544	.6979	.7167
7	.8775	.8215	.7842	.7468	.7947	.8048	.7577
8	.8779	.7095	.7577	.7392	.7421	.7059	.7499
9	.6283	.6036	.5731	.6516	.631	.6268	.6154
10	.5415	.5316	.5611	.567	.5847	.5721	.5847
11	.5611	.5611	.5194	.5373	.567	.5792	.5975
12	.5258	.4681	.5373	.5083	.567	.3761	.6099
13	.4435	.5068	.4477	.5194	.5068	.3547	.5729
14	.4835	.5194	.462	.5014	.499	.3224	.5788
15	.4344	.4887	.4887	.5316	.4938	.5975	.567
16	.5121	.5249	.4835	.5434	.4755	.6283	.6161
17	.5014	.4887	.5611	.5487	.5201	.6161	.5658
18	.6201	.5194		.6001	.6173	.6584	.6836
19	.9511	.8779	.8779	.8688	.8869	.8688	.9511
20	.8962	.9522	.8686	.8779	.8688	.8962	.961
21	.8316	.7783	.8402	.8316	.7947	.8871	.8775
22	.7167	.7655	.7545	.7095	.7023	.7392	.7842
23	.5281	.547	.5281	.5658	.5041	.5975	.6722
24	.415	.4527	.4715	.4527	.4527	.4904	.5093
Max	.9511	.9522	.8779	.8779	.8869	.8962	.961
Min	.3772	.3961	.3772	.415	.4338	.3224	.4527
Avg	.6001	.5874	.5981	.5911	.5836	.6036	.6474

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244053 / 33/11 KV RETHRE HARNAX STN

Feeder No / Name : 202 / 11 KV TAKARI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0566	.056	.2656	.3437	.3395	.0739
2	.056	.0566	.056	.2469	.3281	.3437	.0732
3	.0566	.0566	.056	.2469	.3241	.3749	.0732
4	.0566	.0566	.0554	.25	.3437	.4641	.0905
5	.0754	.056	.056	.2721	.3906	.5506	.0905
6	.0754	.0739	.0754	.3605	.4586	.583	.0905
7	.0754	.0754	.0914	.5668	.6167	.6554	.1097
8	.1132	.0554	.0934	.0934	.0754	.0943	.1097
9	.5281	.4858	.5761	.0943	.1132	.0924	1.3923
10	.6226	.5376	.6325	.0754	.0934	.0914	1.1934
11	.6241	.5898	.7202	.0754	.0739	.1132	1.2125
12	.506		.7362	.0754	.0914	.0924	1.3426
13	.5079	.4858	.6882	.0754	.0747	.0934	1.2616
14	.4687	.5735	.6299	.0566	.0754	.1109	1.2289
15	.4374	.5761	.663	.0754	.0924	.0943	1.1961
16	.426	.6062	.639	.0754	.112	.0934	1.1603
17	.0747	.0754	.0754	.0754	.0754	.1132	.0943
18	.0754	.0943		.0943	.0754	.0943	.0943
19	.0754	.0914	.0566	.0754	.0934	.0934	.112
20	.0747	.0934	.0924	.0934	.0943	.0934	
21	.0747	.0905	.0739	.0739	.0754	.0905	.0747
22	.056	.0739	.3201	.3749	.427	.0905	.0739
23	.0566	.056	.2846	.3593	.4481	.0732	.056
24	.0754	.0566	.056	.2812	.3353	.3549	.0739
Max	.6241	.6062	.7362	.5668	.6167	.6554	1.3923
Min	.056	.0554	.0554	.0566	.0739	.0732	.056
Avg	.2195	.2162	.2949	.1806	.2180	.2163	.4903

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244053 / 33/11 KV RETHRE HARNAX STN

Feeder No / Name : 203 / 11 KV RETHRE HARNAX AG SEPARATED AG FEEDERS HAVING SPECIAL
FEEDER Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5898	.4572	.4938	.0537	.0526	.056	.7682
2	.583	.4268	.463	.0543	.0526	.056	.7773
3	.6316	.4572	.4687	.0543	.0709	.0566	.8097
4	.6706	.463	.4999	.0549	.0709	.0754	.8002
5	.6952	.463	.4999	.0549	.0701	.0747	.8002
6	.7202	.5312	.4999	.056	.0886	.0554	.8002
7	.6802	.679	.6722	.0886	.0876	.0943	.8855
8		.0554	.056	.052	.0857	.0754	.0566
9	.0566	.0497	.0566	1.0311	1.2651	1.4746	.0549
10	.056	.0509	.0554	1.2334	1.4737	1.6907	.0747
11	.0554	.0663	.0373	1.3763	1.6549	1.7532	.0754
12	.0362	.0655	.0377	1.4899	1.6032	1.7901	.0747
13	.0377	.0497	.0373	1.4883	1.6057	1.4582	.0754
14	.0373	.0492	.037	1.4737	1.4586	1.442	.0747
15	.0373	.0492	.0366	1.4089	1.4419	1.4255	.0754
16	.0554	.0497	.0373	1.2803	1.3757	1.3592	.0934
17	.0566	.0492	.0486	.0497	.0566	.0655	.0754
18	.056	.0648		.0486	.0509	.0671	.0701
19	.0549	.056	.0526	.052	.0754	.0554	.0724
20	.056	.0554	.0543	.0716	.0739	.056	.0554
21	.0554	.056	.0549	.0716	.0739	.0739	.0549
22	.5312	.5182	.0549	.0532	.0739	.8322	.8802
23	.5247	.5247	.0537	.0526	.0747	.8421	.8802
24	.6081	.5182	.4877	.0537	.0514	.056	.8002
Max	.7202	.679	.6722	1.4899	1.6549	1.7901	.8855
Min	.0362	.0492	.0366	.0486	.0509	.0554	.0549
Avg	.2994	.2419	.2085	.4877	.5412	.6244	.3827

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244053 / 33/11 KV RETHRE HARNAX STN

Feeder No / Name : 204 / 11KV Bhavaninagar LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4858	.4687	.0091	.4588	.4374	.0069
2	.4801	.4999	.0095	.5506	.4999	.0069
3	.5182	.5121	.0091	.5506	.5121	.0069
4	.5571	.5571	.0095	.0088	.5121	.0072
5	.5636	.57	.0095	.0084	.5182	.0072
6	.5636	.5868	.0099	.0084	.5243	.0072
7	.5571	.5571	.0095		.5121	.008
8	.547	.5304	.5407	.0076	.4938	.0084
9	.5407	.5243	.5735	.0095	.5868	.008
10	.5243	.5304	.5735	.5868	.5571	.5407
11	.5182	.5182	.5571	.5571	.5441	.5121
12	.5182	.5243	.5571	.5506	.5571	.5079
13	.5243	.5304	.5571	.5441	.5636	.4961
14	.5121	.5243	.5571	.5571	.5121	.5079
15	.5182	.5243	.5571	.5506	.5441	.502
16	.5121	.5182	.5506	.5121	.5243	.506
Max	.5636	.5868	.5735	.5868	.5868	.5407
Min	.4801	.4687	.0091	.0076	.4374	.0069
Avg	.5275	.5298	.3181	.3641	.5249	.2275

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244112 / 33/11 KV BAHE SUB-STATION

Feeder No / Name : 201 / 11 KV BAHE GOVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1494	.168	.1448	.1698	.1494	.1848
2	.1494	.1478	.168	.1463	.1698	.1478	.1848
3	.1509	.1494	.168	.1478	.1698	.1494	.1791
4	.2195	.1494	.2241	.1494	.2075	.1509	.2743
5	.2772	.2587	.3142	.2743	.3018	.2987	.3142
6	.3326	.3511	.3921	.3696	.3881	.3881	.3881
7	.3142	.3292	.2715	.3258	.3109	.2865	.3439
8	.2378	.2507	.2507	.2303	.2715	.2454	.2328
9	.2149	.2303	.208	.1526	.2126	.2058	.2035
10	.197	.2058	.1907	.1296	.1526	.1823	.1619
11	.1357	.1696	.1753	.1457	.1357	.1823	.16
12	.1492	.1844	.1372	.1311	.1509	.1823	.1638
13	.1311	.1844	.1696		.1677	.1823	
14	.1326	.1526	.1886	.1543	.1187	.1865	.1457
15	.1311	.1543	.1886	.1372	.1526	.2058	.1886
16	.1475	.1543	.1865	.1372	.1372	.156	.1715
17	.1402		.1658	.1677	.1638	.1658	.1844
18	.218	.1715	.1966	.1844	.1823	.1715	.1658
19	.298	.2402	.2658	.3189	.2481	.2715	.2172
20	.3403	.2614	.2561	.2743	.2378	.2587	.2957
21	.2772	.2801	.2561		.2218	.2614	.2772
22	.2427	.2801	.2241		.2427	.2561	.2402
23	.1867	.2241	.1867	.2033	.1848	.1848	.1867
24	.1478	.1509	.168	.1494	.1698	.1509	.1829
Max	.3403	.3511	.3921	.3696	.3881	.3881	.3881
Min	.1311	.1478	.1372	.1296	.1187	.1478	.1457
Avg	.2051	.2100	.2133	.194	.2028	.2092	.2194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244112 / 33/11 KV BAHE SUB-STATION

Feeder No / Name : 202 / 11 KV KHARATWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0297	.061	.0617	
2				.029	.061	.061	
3				.0286	.061	.0625	
4				.029	.0762	.0617	
5				.0594	.0762	.061	
6	.0377			.0587	.0903	.0772	
7	.0189			.088	.144	.1235	
9	.25	.16	.1781				.3163
10	.25	.1739	.1943				.3321
11	.2623	.2187	.2056				.3637
12	.2408	.2006	.1875				.3593
13	.2439	.1543	.2031				.3361
14	.2286	.1543	.1898				.3637
15	.2286	.176	.1852				.3681
16	.2134	.1781	.1562				.3725
18	.0183						
22			.029		.064		
23			.0282	.2715	.0633		
24				.0417	.0724	.0625	
Max	.2623	.2187	.2056	.2715	.144	.1235	.3725
Min	.0183	.1543	.0282	.0286	.061	.061	.3163
Avg	.1811	.1770	.1557	.0706	.0769	.0714	.3515

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244112 / 33/11 KV BAHE SUB-STATION

Feeder No / Name : 203 / 11 KV HUBALWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5218	.2155	.1551	.037	.0377	.0185	.6009
2	.5218	.2155	.1551	.0373	.0377	.0187	.6081
3	.5281	.2155	.1551	.037	.0377	.0189	.6081
4	.5218	.2294	.1551	.0377	.0377	.0185	.6009
5	.5218	.2321	.1692	.0373	.0566	.0373	.6009
6	.5281	.2818	.2054	.0566	.0754	.037	.6081
7	.5441	.3149	.2538	.0373	.0566	.056	.6882
8	.0526	.037	.0347	.0377	.0377	.0377	.0373
9	.0532	.037	.0362	.5535	.9014	1.0082	.0549
10	.0532	.0351	.0366	.7253	1.0688	1.1043	.0373
11	.0537	.0351	.0181	.7655	1.0722	1.0722	.037
12	.1075	.0335	.0183	.8124	1.1012	1.1523	.0171
13	.0537	.0324	.0181		1.1203	1.2163	.0173
14	.0537	.0339	.0185	.8223	1.0722	1.2323	.0347
15	.0549	.0358	.0366	.8223	1.0364	1.2003	.0181
16	.0554	.0358	.0362	.8065	.9762	1.1523	.0354
17		.0358	.0366	.0362	.0366	.0543	.0358
18		.0366	.037	.0366	.037	.0373	.0354
19	.0554	.0543	.0362	.0566	.037	.056	.0362
20	.0554	.056	.037	.0566	.0566	.0377	.0366
21	.0914	.037	.0362		.037	.0566	.0362
22	.2372	.1833	.0362		.0362	.6722	.5535
23	.208	.1898	.0366	.0377	.037	.6401	.5247
24	.5601	.2155	.1739	.037	.0377	.0187	.6325
Max	.5601	.3149	.2538	.8223	1.1203	1.2323	.6882
Min	.0526	.0324	.0181	.0362	.0362	.0185	.0171
Avg	.2470	.1179	.0805	.2803	.3767	.4564	.2706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244113 / 33/11 KV YEDEMACHHINDRA

Feeder No / Name : 201 / 11 KV MANCHHINDRANAT

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /
OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	.7545
Max	.7545
Min	.7545
Avg	.7545

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244113 / 33/11 KV YEDEMACHHINDRA

Feeder No / Name : 202 / 11KV KRISHNA LIS

PURELY LIS FEEDERS

YEDEMACHHINDR Feeder KV- 11 /
OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	1.1317
Max	1.1317
Min	1.1317
Avg	1.1317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 244113 / 33/11 KV YEDEMACHHINDRA

Feeder No / Name : 203 / 11KV Kilemachindragad Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	1.3203
Max	1.3203
Min	1.3203
Avg	1.3203

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244113 / 33/11 KV YEDEMACHHINDRA

Feeder No / Name : 204 / 11KV Shirte Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3795	.3479	.3321	.0474	.0474	.064	.8162
2	.3795	.3005	.3321	.0514	.0474	.064	.8162
3	.3795	.3005	.3321	.0543	.0474	.064	.8162
4	.3795	.3163	.3321	.0543	.0474	.064	.8162
5	.3795	.3479	.3479	.0543	.064	.064	.8322
6	.4111	.3953	.3637	.0732	.08	.08	1.0242
7	.427	.6483	.5851	.0924	.096	.08	1.1203
8	.0633	.0633	.0791	.0905	.08	.08	.08
9	.0474	.0633	.0633	.9831	1.3443	1.6164	.048
10	.0474	.0633	.0474	1.2308	1.5043	1.7124	.048
11	.0474	.0474	.0474	.9602	1.5364	1.8404	.064
12		.0474	.0474	1.2323	1.6964	1.8244	.064
13			.0474	1.2803	1.5684	1.7764	.048
14			.0474	1.2963	1.5203	1.7444	.064
15			.0474	1.2803	1.4883	1.6804	.064
16	.0633	.0474	.0474	1.2323	1.4083	1.6164	.08
17	.0791	.0633	.0474	.08	.064	.08	.08
18	.0633	.0633	.0633	.0633	.064	.08	.064
19	.0791	.0949	.0633	.0791	.096	.08	.08
20	.0949	.0949	.0791	.0949	.096	.096	.112
21	.0791	.0949	.0791	.0949	.096	.096	.096
22	.4111	.3953	.0791	.0791	.08	.8802	.9602
23	.3795	.3637	.0633	.0633	.064	.8802	.9282
24	.3795	.3637	.3479	.0474	.0633	.064	.8322
Max	.427	.6483	.5851	1.2963	1.6964	1.8404	1.1203
Min	.0474	.0474	.0474	.0474	.0474	.064	.048
Avg	.2285	.2154	.1634	.4423	.5500	.6928	.4148

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244120 / 33/11 KV Ganeshnager

Islampur

Feeder No / Name : 201 / 11 KV RAJARAM NAGER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1524	.1905	.1829	.1905	.1905	.1715
2	.1524	.1334	.1524	.1646	.1715	.1524	.1715
3	.1524	.1334	.1524	.1463	.1524	.1524	.1715
4	.1905	.1524	.1524	.1463	.1524	.1524	.1715
5	.1715	.1905	.1905	.1646	.1715	.1524	.1905
6	.2286	.2096	.2286	.1829	.2286	.1905	.2096
7	.2667	.2477	.2286	.2195	.2096	.2286	.2477
8	.3048	.2858	.3048	.2561	.2286	.2667	.3048
9	.2858	.2667	.2561	.2667	.2477	.2286	.2667
10	.2477	.2286	.2195	.1905	.2286	.2096	.2667
11	.2477	.2286	.1829	.1905	.2286	.2286	.2286
12	.2286	.2286	.2012	.1905	.2286	.1905	.2286
13		.1905	.1829	.2286	.2286	.2096	.2286
14		.1905	.1646	.2286	.1905	.1905	.2286
15	.1715	.1905	.1646	.1905	.2096	.1905	.1905
16	.1715	.1905	.1829	.2286	.1715	.2286	.2286
17	.1905	.1905	.1829	.1905	.1905	.2477	.2667
18	.2286	.2286	.1829	.2096	.1905	.1524	.2477
19	.3048	.2667	.2743	.2286	.3048	.2858	.2858
20	.3048	.3048	.2743	.3048	.3048	.2477	.2858
21	.2858	.3048	.2561	.2667	.2667	.2667	.2667
22	.2858	.2667	.2743	.2477	.2286	.2667	.2477
23	.2286	.2286	.2195	.2286	.2286	.2286	.2096
24	.1715	.1715	.1905	.1829	.1905	.1905	.1905
Max	.3048	.3048	.3048	.3048	.3048	.2858	.3048
Min	.1524	.1334	.1524	.1463	.1524	.1524	.1715
Avg	.2269	.2159	.2087	.2099	.2143	.2104	.2294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244120 / 33/11 KV Ganeshnager

Islampur

Feeder No / Name : 202 / 11 KV Uran-Islampur

GAOTHAN FEEDER

Gaothan. Feeder KV- 11 /

OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.7049	.8764	.7316	.8764	.7621	.7621
2	.8954	.6668	.8383	.695	.8002	.724	.724
3	.9526	.6668	.8002	.6584	.6859	.724	.724
4	1.0288	.6668	.8002	.6584	.724	.7621	.7811
5	1.0288	.8954	.8383	.7316	.8192	.8383	.8954
6	1.1241	1.105	1.0669	1.0059	1.0479	.9526	1.0669
7	1.105	1.0479	1.105	1.0242	.9335	.9526	1.086
8	1.086	1.0479	.9526	.8779	.8383	.8764	.9145
9	.9526	.9907	.8413	.8764	.8764	.8002	.8002
10	.9717	1.0288	.9511	.8764	.8573	.743	.8764
11	.8573	.9907	.8596	.8002	.7621	.743	.724
12	.8383	.9526	.8779	.8002	.7621	.724	.7621
13		.5335	.8413	.7621	.7811	.743	.724
14		.8383	.695	.6859	.724	.7811	.724
15		.8383	.7682	.6478	.6859	.8002	.724
16	.8954	.9907	.8962	.8764	.8002	.8192	.7621
17	.9145	.8764	.7316	.8002	.7811	.8383	1.0669
18	.9526	.8383	.7499	1.105	.8764	.8573	1.1622
19	1.2955	1.2955	1.1157	1.1622	1.2193	1.2384	1.2574
20	1.3336	1.2955	1.2437	1.2955	1.2193	1.2384	1.2003
21	1.2955	1.2574	1.1706	1.2193	1.1812	1.2003	1.2003
22	1.2003	1.2193	1.0791	1.105	1.105	1.1431	1.2003
23	.9145	1.0288	.8779	.9717	.9526	.9145	1.105
24	.9335	.743	.8764	.7499	.9145	.8002	.8002
Max	1.3336	1.2955	1.2437	1.2955	1.2193	1.2384	1.2574
Min	.8383	.5335	.695	.6478	.6859	.724	.724
Avg	1.0197	.9383	.9106	.8799	.8843	.8740	.9185

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244120 / 33/11 KV Ganeshnager

Islampur

Feeder No / Name : 203 / 11KV Mahadev Nagar Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	.7049	.9145	.7682	.9145	.8383	.8002
2	.9335	.6478	.8764	.7316	.8192	.8002	.7621
3	.8383	.6478	.8383	.695	.9335	.8002	.7621
4	1.0479	.6859	.8383	.695	.8954	.8383	.8192
5	1.105	.8002	.8764	.7682	1.0098	.8764	.8954
6	1.1622	1.0098	.9526	1.0242	1.086	.9145	1.0098
7	1.467	1.1812	1.1431	1.1888	1.2003	1.1431	1.1812
8	1.5242	1.2955	1.2574	1.3169	1.105	1.2193	1.2384
9	1.2003	.9907	.9511	1.1431	1.1431	.9907	.9907
10	1.1812	1.0669	1.0974	1.2193	1.2193	.9526	1.2193
11	.9717	.9526	.8779	.9907	.9526	.9145	1.0288
12	.8954	.9145	.9145	.8764	.8383	.9145	.9526
13		.9526	.8779	.8764	.8192	.8764	.8764
14		.9907	.8048	.9526	.8383	.9145	1.0288
15	.8383	.8383	.8048	.8764	.8573	.9145	.9526
16	.9145	.8764	.823	.8764	.7621	.8192	.9145
17	.9335	.8383	.8413	.9145	.8383	.9335	.9717
18	.9526	1.0288	.9511	1.3527	1.0288	1.0288	1.5051
19	1.4861	1.6004	1.4449	1.5242	1.448	1.5432	1.6194
20	1.4861	1.5242	1.5729	1.6956	1.3717	1.5432	1.5813
21	1.3527	1.3717	1.39	1.448	1.2955	1.3717	1.3527
22	1.2955	1.2955	1.2803	1.3336	1.2193	1.2955	1.3146
23	.9335	1.105	1.0242	1.2003	1.0288	1.0669	1.2003
24	1.0098	.7621	.9526	.8413	.9717	.8764	.8954
Max	1.5242	1.6004	1.5729	1.6956	1.448	1.5432	1.6194
Min	.8383	.6478	.8048	.695	.7621	.8002	.7621
Avg	1.1145	1.0034	1.0127	1.0546	1.0248	1.0161	1.0780

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 244120 / 33/11 KV Ganeshnager

Islampur

Feeder No / Name : 204 / 11KV Urun Ag Feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0655	.2949	.362	.3605	.0762
2	.0762	.0762	.0655	.2949	.381	.3277	.0762
3	.0762	.0762	.0655	.2949	.4191	.2949	.0762
4	.0762	.0762	.0655	.2949	.381	.2949	.0762
5	.0762	.0762	.0655	.3113	.4382	.3277	.0762
6	.0762	.0762	.0655	.3277	.4763	.3932	.1143
7	.0762	.0762	.0983	.4588	.5906	.5243	.0953
8	.0762	.0762	.0655	.0983	.0762	.0983	.0953
9	.9145	.6882	.7209	.0655	.0762	.1143	.7209
10	.9145	.7209	.7701	.0655	.0762	.0762	.9503
11	.9907	.7537	.8029	.0655	.1143	.0762	.852
12	.9907	.7865	.7865	.0655	.1143	.0953	.852
13		.7209	.7537	.0655	.0762	.0762	.9831
14		.6882	.7209	.0655	.0762	.0762	.9831
15		.6882	.6882	.0655	.0762	.0762	.9831
16	.6859	.6554	.6226	.0655	.0762	.0953	.6554
17	.0762	.0983	.0655	.0655	.0762	.0953	.0762
18	.0762	.0655	.0655	.0762	.0655	.0953	.0953
19	.0762	.0655	.0655	.0762	.0655	.0953	.0953
20	.0762	.0655	.0655	.0762	.0655	.0953	.0762
21	.0762	.0655	.0655	.0762	.0655	.0953	.0762
22	.0762	.0655	.3113	.381	.3932	.0762	.0762
23	.0762	.0655	.2949	.362	.3932	.0762	.0762
24	.0762	.0762	.0655	.2949	.3429	.3932	.0762
Max	.9907	.7865	.8029	.4588	.5906	.5243	.9831
Min	.0762	.0655	.0655	.0655	.0655	.0762	.0762
Avg	.2722	.2866	.3092	.1795	.2199	.1804	.3464

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 201 / 11 KV BORGAON GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	1.0288
Max	1.0288
Min	1.0288
Avg	1.0288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 202 / 11 KV KHED GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 203 / 11 KV WALWA FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 204 / 11 KV LIS BOR FEEDER

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	1.0288
Max	1.0288
Min	1.0288
Avg	1.0288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072] BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 205 / 11 KV KHED AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	1.0288
Max	1.0288
Min	1.0288
Avg	1.0288

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 206 / 11 KV BORGON AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (I)[072]

BU 6211

Substation No/ Name :- 246002 / 110/33/11 KV BORGAON

Feeder No / Name : 701 / Rajaram Bpau SSK Sakharale NON SHEDDABLE EHV INDUSTRIAL FEEDERS

Feeder KV- 132 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING

DATE	01-SEP-17
HR	Load (MW)
24	.0229
Max	.0229
Min	.0229
Avg	.0229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 201 / 11 KV Kasegaon Gaothan-

GAOTHAN FEEDER

Village Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3326		.4024			.3921	.3582
2	.2772		.3734			.3772	.3326
3	.2743		.3734			.3658	.3326
4	.3475		.4344			.3292	.4481
5	.4854		.5068			.4481	.5041
6	.5788		.5914			.5041	.567
7	.6767		.6722			.6099	.6468
8	.6219		.5729		.4755	.5853	.6036
9	.5175				.4755	.5121	
10	.4344				.3439	.4706	
11	.4024				.4163	.4298	
12	.3292				.3841	.394	
13	.2926				.3292	.362	
14	.3258				.3439	.3506	
15	.3258				.2534	.333	
16	.4024				.3982	.4115	
17		.3696			.4854	.4477	.4755
18		.4207	.5487		.5041	.462	.4755
19		.6468	.6584		.6468	.5914	.5487
20		.5853	.6219		.6283	.5853	.6219
21		.5487	.5487		.5359	.5544	.5487
22		.462	.4755		.4163	.5121	.5175
23		.439	.415		.439	.4024	.3772
24	.3361		.4024	.3395		.3921	.3582
Max	.6767	.6468	.6722	.3395	.6468	.6099	.6468
Min	.2743	.3696	.3734	.3395	.2534	.3292	.3326
Avg	.4094	.4960	.5065	.3395	.4422	.4509	.4823

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 202 / 11 KV Nerle Gaothan feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.499		.4527			.4715	.4527
2	.415		.415			.4108	.4527
3	.415		.4024			.4108	.4024
4	.3658		.439			.4344	.4024
5	.439		.5228			.4887	.5041
6	.5228		.5601			.5601	.5788
7	.5975		.6036			.6224	.6602
8	.5093		.5415		.5487	.547	.5359
9	.5281				.4755	.4805	
10	.4344				.4706	.4805	
11	.4207				.4755	.5121	
12	.4207				.5014	.4755	
13	.3982				.4252	.499	
14	.3982				.3982	.5249	
15	.4024				.443	.5249	
16	.3658				.4207	.4733	
17		.4854			.5041	.5175	
18		.4904			.547	.5228	
19		.6979			.7095	.7356	
20		.9335			.8676	.8589	
21		.6413			.7392	.7167	
22		.5601			.6535	.6036	
23		.4481			.547	.5658	
24	.499		.4435	.4904		.4668	.499
Max	.5975	.9335	.6036	.4904	.8676	.8589	.6602
Min	.3658	.4481	.4024	.4904	.3982	.4108	.4024
Avg	.4489	.6081	.4867	.4904	.5454	.5377	.4987

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 203 / 11 KV Tambave Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3326		.3544			.3734	.3696
2	.2772		.3189			.3142	.362
3	.2715		.3292			.3142	.3077
4	.3439		.2926			.3403	.3109
5	.3841		.3511			.394	.4024
6	.4938		.4435			.4344	.4668
7	.5729		.4887			.4887	.5249
8	.4755		.4207		.4755	.4435	.4755
9	.4024				.4024	.4207	
10	.3292				.3982	.4163	
11	.3077				.362	.3982	
12	.362				.3582	.4024	
13	.2507				.3224	.4251	
14	.2507				.3547	.4207	
15	.2481				.2865	.3292	
16					.3189	.3258	
17		.2772			.2896	.3582	
18		.2743			.2926	.394	
19		.4024			.3292	.4887	
20		.4066			.4024	.5121	
21		.4066			.362	.4706	
22		.4163			.4024	.4294	
23		.4163			.4024	.4207	
24	.3292		.3544	.3772		.3734	.4066
Max	.5729	.4163	.4887	.3772	.4755	.5121	.5249
Min	.2481	.2743	.2926	.3772	.2865	.3142	.3077
Avg	.3520	.3714	.3726	.3772	.3600	.4037	.4029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 204 / 11 KV Wategaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2172		.2328			.2149	.2353
2	.1829		.1848			.1848	.181
3	.1829		.1848			.1848	.1867
4	.1612		.2149			.2126	.2614
5	.3224		.2865			.2126	.2534
6	.3696		.3326			.2587	.3077
7	.4066		.3658			.3109	.3841
8	.3511		.3326		.3658	.3077	.3511
9	.3292				.3292	.3012	
10	.2926				.2715	.3224	
11	.3077				.2715	.2865	
12	.1991				.2303	.2715	
13	.2012				.2481	.2715	
14	.181				.2279	.2658	
15	.181				.2279	.2481	
16	.181				.2658	.2804	
17		.2378	.1829		.3292	.3258	.2926
18		.2534	.3292		.3326	.3326	.3292
19		.3982	.4024		.3982	.4298	.4024
20		.4024	.439		.439	.439	.439
21		.3982	.3658		.362	.4435	.4066
22		.3696	.3658		.3292	.362	.3696
23		.2896	.2641		.2507	.2772	.3018
24	.2172		.2328	.2263		.2149	.2353
Max	.4066	.4024	.439	.2263	.439	.4435	.439
Min	.1612	.2378	.1829	.2263	.2279	.1848	.181
Avg	.2520	.3356	.2948	.2263	.3049	.2900	.3086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 205 / 11 KV KASEGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	1.5775
Max	1.5775
Min	1.5775
Avg	1.5775

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 206 / 11 KV NERLE AG. FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1136		1.2003		.0762	1.8023
2	2.3777		1.2643		.0762	1.8724
3	2.13		1.2944		.061	1.8724
4	2.0485		1.3599		.0625	2.0081
5	2.0485		1.3125		.061	2.0405
6	2.0485		1.3125		.0781	2.13
7	2.0481		1.3763		.0762	2.13
8	.0762		.0762	.0914	.0762	.0762
9	.0762			3.2648	2.5453	
10	.125			3.2065	2.5606	
11	.1107			3.0769	2.5911	
12	.0949			3.0182	2.6871	
13	.1219			2.9508	2.7183	
14	.125			2.4981	2.6871	
15	.125			2.3807	2.6558	
16	.125			2.34	2.484	
17	.1219	.0762		.0762	.0457	
18		.0838		.0762	.0457	
19		.061		.0762	.061	
20		.061		.0762	.061	
21		.061		.0762	.061	
22		1.1142		.061	1.6549	
23		1.1633		.0762	1.7532	
24	2.1136		1.2289		.0762	1.8023
Max	2.3777	1.1633	1.3763	3.2648	2.7183	2.13
Min	.0762	.061	.0762	.061	.0457	.0762
Avg	1.0017	.3744	1.1584	1.4591	1.0523	1.7482

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 207 / 11 KV Wategaon Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762		.0914			1.4582	.0762
2	.0762		.0762			1.5893	.061
3	.0762		.0762			1.5524	.0625
4			.0762			1.8724	.0937
5			.1067			1.781	.0914
6			.1067			1.7185	.0914
7			.1406			1.6964	.1219
8			.1562		.1219	.125	.1219
9	2.2283				.1219	.108	
10	2.4985				.1067	.108	
11	2.7854				.1219	.128	
12	2.7183				.1235	.125	
13	2.6246				.108	.1265	
14	2.1091				.1235	.1265	
15	1.5546				.125	.1265	
16	1.4937				.125	.1107	
17		.1219			.1562	.1875	
18		.1219			.1875	.1875	
19		.1524			.1219	.1219	
20		.1524			.1219	.1372	
21		.1219			.1219	.1219	
22		.1219	1.1843		1.3108	.0914	
23		.1219	1.1523		1.3763	.0914	
24	.0762		.0914	1.1523		1.4582	.0762
Max	2.7854	.1524	1.1843	1.1523	1.3763	1.8724	.1219
Min	.0762	.1219	.0762	1.1523	.1067	.0914	.061
Avg	1.5264	.1306	.2962	1.1523	.2796	.6312	.0885

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 208 / 11 KV Tambave Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9831		.6241		.061	1.7204
2	1.0486		.6241		.0762	1.7604
3	1.0242		.7045		.0781	1.7604
4	.9922		.7045		.0469	1.7394
5	.9922		.8539		.0457	1.692
6	.933		.8539		.061	1.6876
7	.9442		.7865		.0762	1.6549
8	.0762		.061	2.4326	.061	.061
9	.0457			2.6073	2.4846	
10	.1067			2.6397	2.5309	
11	.1219			2.5911	2.5934	
12	.0937				2.6246	
13	.1094			2.4684	2.6402	
14	.125			2.4036	2.6246	
15	.1219			2.3878	2.3746	
16	.1094			2.2138	2.2965	
17		.061		.1067	.1067	
18		.061		.1067	.1067	
19		.061		.061	.0762	
20		.061		.061	.061	
21		.061		.061	.061	
22		.4915		.061	1.5729	
23		.5407		.061	1.6385	
24	.9831		.6241		.061	1.7204
Max	1.0486	.5407	.8539	2.6397	2.6402	1.7604
Min	.0457	.061	.061	.061	.0457	.061
Avg	.5183	.1910	.6485	1.3508	1.0150	1.5329

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 209 / 11 KV Someshwar

PURELY LIS FEEDERS

Bhairavnath LI Feeder KV- 11 /
OUTGOING

DATE	31-AUG-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.543		.5144	.3077
2	.5487		.5601	.3077
3	.5853		.6348	.3547
4	.5914		.6219	.3547
5	.7282		.6767	.499
6	.7282		.5914	.7023
7	.6335		.7207	.7421
8	.9055	.6984	.6036	.8962
9	1.7013	.7343	.8322	
10	1.7013	.8939	.7975	
11	.8962	.9231	.7888	
12	.9145	.8573	.8573	
13	.9145	.7888	.8573	
14	.9231	.7888	.8573	
15	.9231	.8573	.8402	
16	.9134	.8402	.8573	
Max	1.7013	.9231	.8573	.8962
Min	.543	.6984	.5144	.3077
Avg	.8845	.8202	.7257	.5206

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244017 / 33/11 KV KASEGAON

Feeder No / Name : 210 / 11 KV Krishna LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	31-AUG-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001		.6687	.583
2	.6001		.6687	.583
3	.6859		.7373	.6687
4	.7373		.8059	.8322
5	.9774		.8916	1.0923
6	1.2517		1.1831	1.3375
7	1.6289		1.5089	1.5432
8	1.6118	1.2826	1.4746	1.4918
9		1.543	1.4091	
10		1.3375	1.4089	
11		1.3375	1.4754	
12		1.4746	1.4918	
13		1.5257	1.4918	
14		1.4918	1.4918	
15		1.5089	1.4918	
16		1.2071	1.1904	
Max	1.6289	1.543	1.5089	1.5432
Min	.6001	1.2071	.6687	.583
Avg	1.0117	1.4121	1.2119	1.0165

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 203 / 11 KV Aitwadi Kh -Gaothan-

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2452		.3206	.2452	.2926	.2641	.3018
2	.2263	.3658	.3206	.2452	.2926	.2452	.2641
3	.2263	.362	.3018	.2263	.3361	.2263	.2641
4	.2614	.4252	.3018	.2427	.4066	.2829	.3018
5	.3547	.4344	.3772	.2987	.4344	.3395	.3584
6	.4481	.4805	.415	.3361	.4344	.415	.415
7	.5121	.5175	.4668	.4435	.4435	.4854	.4668
8		.4938	.4066	.4066	.3982	.4024	.4251
9	.4887	.1867	.3475	.3292	.3982	.3582	.3658
10	.3506	.3142	.3155	.2743	.3506	.3506	.3155
11	.3155	.2926	.2804	.2454	.3155	.3155	.3018
12	.3155	.3258	.2454	.2454	.3155	.3018	.2454
13	.2804	.2507	.2454	.2454	.2804	.3086	.2454
14	.2572	.2328	.2294	.2454	.298	.333	.2454
15	.2454	.2561	.2012	.2561	.2454	.2743	.2103
16		.2743	.2058	.2804	.2454	.2347	.2103
17	.2321	.2534	.2058	.2804	.2454	.2401	.2103
18	.407	.3841	.3582		.3582	.3403	.3582
19	.5068	.4805	.4163	.5068	.4024	.4572	.4572
20	.543	.5041	.462	.5121	.4435	.5041	.5041
21	.112	.5093	.4435	.4656	.4668	.4904	.4715
22	.7392	.4904	.4108	.4344	.4481	.4338	.4338
23	.6878	.415	.3018	.3361	.2987	.3584	.3395
24	.2452	.3155	.3395	.2641	.2641	.2641	.3018
Max	.7392	.5175	.4668	.5121	.4668	.5041	.5041
Min	.112	.1867	.2012	.2263	.2454	.2263	.2103
Avg	.3637	.3724	.3300	.3202	.3506	.3427	.3339

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 204 / 11 KV WASHI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.3506	.2829	.1886	.2195	.1886	.2075
2	.1698	.3155	.2641	.1698	.2149	.1886	.1886
3	.1698	.3292	.2452	.1698	.2534	.1698	.1698
4	.1886	.3224	.2452	.1867	.2926	.1867	.1698
5	.2829	.3326		.2427	.3326	.2614	.2263
6	.3772	.3734	.3772	.2987	.3696	.3361	.3584
7	.5228	.4481	.4481	.3734	.439	.4066	.4108
8	.4716	.4706	.3881	.362	.3898	.3841	.4435
9	.362	.394	.3292	.2865	.4298	.3506	.4572
10	.3506	.362	.2454	.2454	.2804	.3506	.3506
11	.2804	.3258	.2103	.2103	.2454	.3506	.2804
12	.1753	.2926	.2454	.2103	.2454	.3086	.2103
13	.1715	.181	.2401	.2103	.2454	.2683	.2103
14	.1715	.1829	.2012	.2058	.298	.2294	.2103
15	.1402	.2195		.2058	.2507	.2454	
16	.2683	.2195	.1966	.2103	.2454	.2401	
17	.2835	.2835	.2012	.2454	.2454	.2804	.2103
18	.3189	.362	.362	.394	.3258	.3582	.3403
19	.4706	.4755	.4572	.439	.362	.4207	.4207
20	.3658	.5041	.4805		.4805	.4668	.4668
21	.4706	.4715	.4481	.4435	.4435	.4527	.4527
22	.3544	.3961	.3361	.362	.3326	.3772	.3584
23	.4344	.3018	.2263	.2614	.3395	.2452	.3018
24	.1886	.394	.2829	.1886	.2241	.1886	.2075
Max	.5228	.5041	.4805	.4435	.4805	.4668	.4668
Min	.1402	.181	.1966	.1698	.2149	.1698	.1698
Avg	.2991	.3462	.3052	.2657	.3127	.3023	.3024

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 205 / 11 KV Aitwade Kh Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9602	.6878	.427	.0377	.0747	.0377	
2	.9282	.3292	.3906	.0377	.0732	.0377	
3	.8907	.3224	.3906	.0377	.1075	.0377	
4	.8962	.2926	.427	.0377	.1086	.0377	
5	.9282	.2865	.4902	.0566	.1097	.0754	
6	.9602	.2846	.5921	.0754	.1132	.0754	
7	1.0526	.4111	.6882	.1132	.0754	.1132	
8		.0754	.0566	.1132	.0943	.0754	
9	.0754	.0747	.0566	.8951	1.3565	1.4918	
10	.0754	.056	.0526	.9816	1.3413	1.5775	
11	.0754	.0377	.0526	.9816	1.3717	1.5074	
12	.0701	.0377	.0526	.9114	1.4022	1.5432	
13	.0377	.0377	.0526	.8764	1.4373	1.6766	
14		.0377	.0526	.9465	1.4723	1.749	
15	.0351	.0377	.0566	1.0242	1.4373	1.7528	
16		.0377	.0526	1.2003	1.4022	1.7177	
17		.0377	.0526	.0343	.0351	.0351	
18		.0566	.0754	.0648	.0373	.0549	
19	.1132	.0754	.0754	.064	.056	.0754	
20		.0943	.0754	.0754	.0754	.0754	
21		.0943	.0754	.0754	.0754	.0754	
22		.502	.0754	.0739	.0754	1.0852	1.1869
23		.4858	.0566	.0754	.0754	1.0852	
24	.9602	.6379	.4481	.0377	.0754	.0377	
Max	1.0526	.6878	.6882	1.2003	1.4723	1.7528	1.1869
Min	.0351	.0377	.0526	.0343	.0351	.0351	1.1869
Avg	.5373	.2096	.2011	.3678	.5201	.6679	1.1869

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 207 / 11 KV WASHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0732	.0566	.6249	.8848	.7842	
2	.0373	.0732	.0377	.6154	.9496	.7773	
3	.0373	.0716	.0377	.5851	.9945	.7773	
4	.0373	.0709	.0377	.6081	1.0517	.7611	
5	.037	.0724	.0566	.6241	1.1641	.8002	
6	.0739	.0732	.0754	.6722	.9503	.8642	
7	.0739	.0739	.0943	.9069	1.1012	1.1105	
8	.0732	.0754	.0943	.0754	.1132	.0754	
9	1.3435	1.3108	1.4251	.0377	.0747	.0377	
10	1.4022	1.3108	1.5424	.0377	.0351	.0377	
11	1.4022	1.2793	1.6827	.0377	.0351	.0351	
12	1.4022	1.2631	1.7177	.0351	.0343	.0377	
13	1.2071	1.3108	1.5775	.0351	.0351	.0377	
14	1.166	1.2944	1.4746	.0351	.0543	.0377	
15	1.1919	1.278	1.3413	.0351	.0351	.0377	
16	1.166	1.0526	1.278	.0351	.0351	.0351	
17	.0754	.056	.0351	.0701	.0351	.0351	
18	.1132	.0754	.037	.1075	.0362	.0732	
19	.0732	.0943	.0739	.1075	.0732	.0943	
20	.0732	.0943	.0747	.0747	.0747	.0943	
21		.0943	.0754	.0754	.0754	.0943	
22	.0724	.0754	.7202	.7468	.8848	.0754	.0754
23	.0732	.0566	.6642	.8962	.8745	.0566	
24	.0377	.0724	.0514	.6249		.8002	
Max	1.4022	1.3108	1.7177	.9069	1.1641	1.1105	.0754
Min	.037	.056	.0351	.0351	.0343	.0351	.0754
Avg	.4873	.4709	.5942	.3210	.4175	.3154	.0754

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 208 / 11 KV YELUR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0754	.0943	.8855	1.1271	1.1984	.0754
2		.0739	.0754	.8855	1.1317	1.166	.0754
3			.0754	.8802	1.1233	1.166	.0754
4		.0732	.0754	.8962	1.1568	1.1683	.0754
5		.0724	.0754	.9393	1.2536	1.1843	.0943
6		.0943	.0943	.9555	1.247	1.2003	.1132
7		.1132	.0943	1.2944	1.6221	1.6907	.1132
8		.1886	.0943	.0754	.0732	.0724	.1132
9		1.9062	2.1534	.0754	.0514	.0943	2.6825
10		1.9826	2.0576	.0754	.0526	.0754	2.6292
11	2.3137	1.9109	2.1735	.0701	.0526	.0701	2.8045
12	2.3487	1.9433	2.2611	.0701	.0526	.0701	3.0693
13	2.3838	1.6712	1.9281	.0701	.0526	.0754	3.155
14	2.226	1.6549	1.9631	.0701	.0526	.0754	2.9797
15	1.9806	1.6385	1.9204	.0716	.0526	.0754	3.155
16	1.8404	1.6409	1.9113	.0686	.0526	.0754	3.8211
17	1.4403	.0732	.0335	.0701	.0514	.0754	.0701
18	.1109	.0943	.0724		.0747	.1097	.0914
19	.1132	.132	.0747	.1097	.112	.132	.132
20	.0983	.132	.1132	.1132	.1132	.132	.132
21	.1143	.132	.0754	.112	.132	.132	.132
22	.0762	.1132	.9922	1.4937	1.326	.1132	.1132
23		.0943	.9945	1.1069	1.2616	.0943	.0943
24		.0747	.0876	.9172	1.1069	1.2289	.0943
Max	2.3838	1.9826	2.2611	1.4937	1.6221	1.6907	3.8211
Min	.0762	.0724	.0335	.0686	.0514	.0701	.0701
Avg	1.2539	.6907	.8121	.4916	.5555	.4781	1.0788

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244024 / 33/11 KV KURLAP

Feeder No / Name : 209 / 11 KV Kundalwadi Ag feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6802	1.0277	.8383	.0377		.0377	1.3904
2	.6478	1.0277	.7956	.0377		.0377	1.3748
3	.6154	1.0867	.7625	.0377		.0377	1.358
4	.6554	1.1104	.7537	.0377		.0377	1.3565
5	.6554	1.1706	.8002	.0377		.0377	1.4243
6		1.0059	.8421	.0377		.0377	1.5775
7		1.1361	.8745	.0747		.0754	1.7318
8	.0554	.0543	.0566	.0373		.0754	.0566
9	.0362	.0335	.0377	1.5089	.9835	2.1365	.0566
10	.0362	.0343	.0351	1.5775	2.0119	2.1033	.0377
11	.0351		.0351	1.7528	2.0645	2.1033	.0351
12	.0351	.037	.0362	1.7528	2.1033	2.2436	.0351
13	.0377	.0373	.0377	1.7528	2.1033	2.2291	.0351
14	.0351	.0362	.0339	1.7528	2.1033	2.2291	.0351
15	.0351	.0354	.0335	1.7177	2.1033	2.3137	.0351
16	.0351	.0351	.0343	1.7878	2.1033	2.3137	.0351
17	.0549	.0351	.0351	.0351	.0343	2.3487	.0351
18	.0362	.0537	.0537	.0724	.0358	.0549	.0543
19	.0678	.0566	.0716	.0693	.0554	.0754	.0754
20	.0686	.0566	.0732		.0747	.0754	.0754
21	.0701	.0566	.0373	.0732	.0747	.0754	
22	1.1462	.9835	.0373		.0373	1.5947	1.5947
23	1.0985	.9156	.0377		.0377	1.5261	1.5775
24	.7042	1.086	.8551	.0377		.0377	1.4575
Max	1.1462	1.1706	.8745	1.7878	2.1033	2.3487	1.7318
Min	.0351	.0335	.0335	.0351	.0343	.0377	.0351
Avg	.3110	.4831	.3003	.6776	1.0618	.9932	.6715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244067 / 33/11 KV YEDENIPANI STN

Feeder No / Name : 202 / 11 KV ITKARE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	.884	1.073	.1097	.0934	.0943	1.406
2	1.2193	.8535	1.0059	.1097	.0934	.0943	1.3916
3	1.2193	.8535	1.0059	.1097	.0934	.0943	1.3283
4	1.2193	.8535	1.0059	.1097	.0934	.0943	1.2967
5	1.2193	.9181	1.1218	.112	.1307	.1132	1.4232
6	1.2193	.9934	1.2071	.1494	.1494	.1509	1.5278
7	1.6766	1.4232	1.6095	.1867	.1848	.1886	1.8244
8	.1829	.1663	.1886	.1829	.1829	.1886	.1663
9	.181	.1463	.1509	2.0165	2.5972	2.6337	.181
10	.181	.1463	.1463	2.3411	3.1824	3.0769	.1848
11	.1646	.1629	.1463	2.3777	3.3653	3.1131	.1478
12	.1646	.1629	.128	2.5701	3.219	3.2217	.1478
13		.1433	.1307	2.4874	2.9729	3.2217	.1463
14	.1086	.1433	.1307	2.4508	2.7343	2.9321	.128
15	.1086	.1433	.1307	2.2546	2.6703	2.8166	.1294
16	.1402	.1433	.1494	2.1437	2.524	2.4874	.1294
17	.1402	.1402	.1494	.1402	.132	.1402	.1307
18	.1543	.0579	.1494	.1372	.1509	.1402	.1494
19	.181	.1886	.1848	.181	.1886	.1791	.1848
20	.181	.1886	.2195	.2195	.1886	.2033	.1848
21	.1848	.1886	.1867	.1848	.1886	.1698	.1848
22	1.0974	1.3535	.1494	.1663	.1509	1.7497	1.6766
23	.9907	1.3169	.1494	.1494	.132	1.6872	1.5851
24	1.3413	.9145	1.2437	.1086	.112	.1132	1.4373
Max	1.6766	1.4232	1.6095	2.5701	3.3653	3.2217	1.8244
Min	.1086	.0579	.128	.1086	.0934	.0943	.128
Avg	.6302	.5202	.4901	.8749	1.0638	1.2044	.7122

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244067 / 33/11 KV YEDENIPANI STN

Feeder No / Name : 204 / 11 KV ITKARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2195	.2195	.1867	.1646	.1829	.1829
2	.2241	.2195	.2195	.1867	.1646	.1829	.1829
3	.2241	.2195	.2195	.1867	.1646	.1829	.1829
4	.2241	.2195	.2195	.1867	.1646	.1829	.1829
5	.2614	.2926	.2561	.2241	.2195	.2195	.2378
6	.3734	.3658	.2926	.2987	.2743	.2926	.3292
7	.4294	.4572	.439	.3921	.3109	.3292	.3292
8	.4294	.4024	.3658	.3361	.3109	.3658	.3292
9	.4294	.3658	.3658	.3174	.3109	.3189	.3475
10	.4294	.3658	.3547	.3174	.2926	.2896	.2987
11	.3511	.3077	.3174	.3142	.2195	.2896	.3174
12	.2926	.3077	.2801	.1991	.2561	.1753	.3174
13	.2561	.3077	.2801	.181	.2561	.1753	.2801
14	.2561	.1928	.2801	.2561	.2195	.2328	.2801
15	.2561	.1928	.2614	.1991	.2195	.2328	.2801
16	.2561	.2303	.2614	.1791	.2195	.1753	.2801
17	.2743	.2103	.2801	.1991	.2561	.197	.2614
18	.2957	.2103	.2801	.2561	.2926	.2172	.2987
19	.3841	.3658	.3326	.3658	.4024	.3982	.3881
20	.4207	.4938	.4251	.4207	.439	.439	.4066
21	.3658	.3658	.3547	.3658	.3658	.3475	.3696
22	.3475	.3292	.3174	.3109	.2926	.2926	.2587
23	.3109	.2926	.2427	.2195	.2195	.2378	.2614
24	.2614	.2561	.2561	.1867	.1829	.1829	.2012
Max	.4294	.4938	.439	.4207	.439	.439	.4066
Min	.2241	.1928	.2195	.1791	.1646	.1753	.1829
Avg	.3157	.2996	.2967	.2619	.2591	.2559	.2835

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244067 / 33/11 KV YEDENIPANI STN

Feeder No / Name : 205 / Shivtirtha Express Feeder NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.008	.0111	.0126	.0103	.008	.0126	.0084
2	.008	.008	.0126	.0095	.0095	.0126	.0088
3	.0076	.0076	.0126	.0076	.0072	.0126	.008
4	.0076	.0076	.0137	.0076	.0065	.0126	.0084
5	.0076	.0088	.0137	.0076	.0065	.0099	.0095
6	.0076	.0091	.0107	.0069	.0061	.0099	.008
7	.0076	.0091	.0084	.0069	.005	.0069	.0072
8	.0076	.0069	.0084	.0072	.0053	.0084	.0065
9	.0069	.0069	.0084	.0069	.0046	.0084	.0072
10	.0069	.0069	.0069	.0069	.0084	.008	.0069
11	.0076	.0076	.0072	.0069	.0099	.008	.008
12	.0076	.0076	.008	.0076	.0168	.0076	.008
13	.0084	.0076	.0088	.008	.0084	.0076	.0084
14	.0084	.008	.0088	.008	.0072	.0076	.0076
15	.0091	.0084	.0088	.008	.0099	.0076	.0076
16	.0091	.0084	.0076	.008	.0099	.0084	.0088
17	.0095	.0084	.0091	.008	.0107	.0084	.008
18	.0076	.0069	.0084	.0069	.0084	.0091	.0095
19	.008	.0076	.0076	.0072	.0099	.008	.0103
20	.0095	.0084	.0091	.008	.0084	.0095	.0133
21	.0118	.0084	.0103	.0137	.0149	.013	.0118
22	.0114	.0084	.013	.0118	.0099	.0133	.0103
23	.0118	.0099	.0118	.0111	.0126	.0126	.0091
24	.0095	.0111	.0084	.0118	.0111	.0126	.0122
Max	.0118	.0111	.0137	.0137	.0168	.0133	.0133
Min	.0069	.0069	.0069	.0069	.0046	.0069	.0065
Avg	.0085	.0083	.0098	.0084	.0090	.0098	.0088

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244111 / 33/11 KV Karanjawade S/S

Feeder No / Name : 201 / 11 KV Karanjawade Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2126	.2507		.2481	.2587	.2481	.2481
2	.2126	.2507	.3142	.2126	.2587	.2481	.2481
3	.2126	.2507	.3142	.2126	.2587	.2481	.2481
4	.2481	.2865	.3142	.2835	.2587	.2481	.2481
5	.3189	.3224	.3142	.3189	.2587	.2835	.2865
6	.3544	.3582	.4024	.3189	.3696	.3189	.3761
7	.3898	.394	.4207	.3544	.4024	.3189	.3761
8	.3898	.394	.362	.3658	.3982	.3544	.3189
9	.3189	.3582	.333	.3224	.333	.3189	.3189
10	.3189	.3258	.3189	.3086	.2804	.3721	.2915
11	.2835	.3086	.2835	.3018	.2804	.3189	.2622
12	.3224	.2883	.2658	.2818	.2804	.2481	.2254
13	.3224	.2774	.2126	.2486	.2454	.2481	.2254
14	.2507	.2481	.2126	.2155	.2103	.2481	.2279
15	.2149	.2279	.2126	.2012	.2454	.2481	.2103
16	.2507	.2279	.2126	.2713	.2454	.2481	.218
17	.2865	.2572	.2481	.2683	.2454	.2481	.2865
18	.3224	.2915	.2835	.2652	.2454	.2865	.3582
19	.5014	.4477	.4252	.4096	.4961	.4298	.4298
20	.5373	.5544	.5316	.4858	.5316	.5194	.4656
21	.5373	.4938	.4961	.5304	.4607	.5014	.4477
22	.4111	.4668	.3898	.4668	.3544	.394	.3224
23	.2865	.3189	.2835	.3142	.2835	.2865	.2507
24	.2126	.2507	.3142	.2481	.2587	.2481	.2481
Max	.5373	.5544	.5316	.5304	.5316	.5194	.4656
Min	.2126	.2279	.2126	.2012	.2103	.2481	.2103
Avg	.3215	.3271	.3246	.3106	.3108	.3097	.2974

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244111 / 33/11 KV Karanjawade S/S

Feeder No / Name : 202 / 11 KV Devarde AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0373		.463	.6554	.6642	.056
2	.0373	.0373	.056	.4321	.6554	.6009	.056
3	.0373	.0373	.056	.4321	.6554	.6009	.056
4	.0566	.0373	.056	.4572	.6554	.6325	.056
5	.0754	.056	.0747	.4877	.6554	.6642	.056
6	.0754	.0747	.0747	.5792	.7468	.7274	.0747
7	.0943	.0934	.0934	.8535	1.1584	1.2651	.0934
8	.0943	.0747	.0934	.0934	.0934	.0747	.112
9	1.4506	1.1561	1.0669	.056	.0747	.056	1.9204
10	1.4373	1.2342	1.1279	.056	.0747	.056	2.3434
11	1.531	1.2186	1.2193	.056	.0747	.056	2.2862
12	1.5623	1.2029	1.2193	.0373	.056	.056	2.3015
13	1.406	1.1888	1.2346	.0373	.056	.056	2.5911
14	1.2811	1.2193	1.2037	.0373	.0747	.056	2.5301
15	1.2498	1.1888	1.1728	.0373	.056	.056	2.5758
16	1.1248	1.1126	.2126	.0373	.056	.056	2.4234
17	.056	.0934	.0747	.0373	.0747	.0747	.0934
18	.0747	.112	.0747	.0373	.056	.0934	.0934
19	.0934	.0934	.0747	.0934	.0747	.0934	.112
20	.0934	.0747	.0747	.0934	.0747	.0934	.112
21	.0747	.0747	.0747	.0747	.0739	.0934	.112
22	.0747	.0747	.4938	.8029	.6562	.0747	.112
23	.056	.0747	.4938	.8029	.6562	.0747	.0934
24	.056	.056	.056	.463	.8029	.6642	.056
Max	1.5623	1.2342	1.2346	.8535	1.1584	1.2651	2.5911
Min	.0373	.0373	.056	.0373	.056	.056	.056
Avg	.5062	.4426	.4512	.2732	.3445	.2892	.8465

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 244111 / 33/11 KV Karanjawade S/S

Feeder No / Name : 203 / KARVE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2812	.2846		.0566	.0732	.0474	.506
2	.2812	.2846	.3243	.0566	.0732	.0474	.506
3	.253	.2846	.3243	.0566	.0732	.0474	.506
4	.2846	.2846	.3243	.0747	.0732	.0474	.506
5	.3125	.3163	.3243	.0934	.0914	.0474	.5441
6	.3749	.3163	.3475	.112	.1086	.0633	.6401
7	.6562	.6009	.6308	.112	.1235	.0949	.8162
8	.0781	.0949	.0886	.112	.1402	.08	.0949
9	.0625	.0474	.0732	1.0242	1.3603	.7682	.0949
10	.0781	.0732	.0633	1.1203	1.4575	.9922	.0838
11	.0469	.0724	.0633	1.2163	1.3927	1.1843	.0701
12	.0312	.0709	.0633	1.3443	1.4899	1.3923	.0724
13	.0312	.0693	.0633	.6019	1.6194	1.3763	.0905
14	.0312	.0514	.0633	1.2003	1.5546	1.3603	.0905
15	.0312	.0686	.0633	1.2651	1.4403	1.3443	.0905
16	.0469	.0678	.0633	1.2651	1.0883	1.2803	.1063
17	.0625	.0693	.0633	.0724	.0316	.0633	.1063
18	.0625	.0709	.0633	.0724	.0474	.0791	.0949
19	.0791	.0905	.0633	.0914	.0633	.0949	.0949
20	.0791	.0934	.0791	.112	.0791	.0949	.0949
21	.0791	.0934	.0791	.112	.0633	.096	.0949
22	.3163	.3185	.0633	.0934	.0474	.5376	.6874
23	.3163	.3384	.0474	.0747	.0474	.5376	.6874
24	.2812	.3163	.3243	.0566	.0732	.0474	.5121
Max	.6562	.6009	.6308	1.3443	1.6194	1.3923	.8162
Min	.0312	.0474	.0474	.0566	.0316	.0474	.0701
Avg	.1732	.1824	.1593	.4332	.5255	.4885	.2996

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073]

BU 6220

Substation No/ Name :- 244111 / 33/11 KV Karanjawade S/S

Feeder No / Name : 204 / Ganesh Chikurde LIS Feeder

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0181		.0181	.0181	.181	.1086
2	.0181	.0181	.0181	.0181	.181	.1086
3	.0181	.0181	.0181	.0181	.181	.1086
4	.0181	.0181	.0181	.0181	.181	.1086
5	.0181	.0181	.0181	.0181	.181	.1086
6	.1086	.0181	.0181	.1086	.1991	.1086
7	.2353	.0181	.0181	.2353	.2172	.1086
8	.2172	.0181	.0181	.2353	.2172	.1086
9	.2172	.0181	.0181	.2353	.2172	.0905
10	.2172	.0181	.0181	.2172	.2172	.0905
11	.2172	.0181	.0181	.2172	.2353	.1448
12	.2172	.0181	.0181	.1267	.2353	.2353
13	.1267	.0181	.0181	.1267	.2353	.2353
14	.1267	.0181	.0905	.1267	.2353	.2353
15	.1267	.0181	.0905	.1267	.2353	.2353
16	.0181	.0181	.2172	.2353	.2353	.2353
Max	.2353	.0181	.2172	.2353	.2353	.2353
Min	.0181	.0181	.0181	.0181	.181	.0905
Avg	.1199	.0181	.0396	.1301	.2115	.1482

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 403 / (Kurloop)Shirala

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	6.2443
Max	6.2443
Min	6.2443
Avg	6.2443

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 405 / 33 KV Dindayal Sut Girani NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	1.885
Max	1.885
Min	1.885
Avg	1.885

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 406 / 33 KV Echo Board

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	3.4928
Max	3.4928
Min	3.4928
Avg	3.4928

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 407 / 33 KV Kasegaon Feeder NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	4.269
Max	4.269
Min	4.269
Avg	4.269

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

ISLAMPUR (II)[073] BU 6220

Substation No/ Name :- 248008 / 220 KV PETH SUBSTATION

Feeder No / Name : 702 / 132 KV Peth Wategaon NON SHEDDABLE EHV INDUSTRIAL FEEDERS
Feeder Feeder KV- 132 / (CONTINUOUS PROCESS)(NO STAGGERING
OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	.6173
Max	.6173
Min	.6173
Avg	.6173

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 201 / 11 KV BIUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0457	.0648	.0648	.1457	.1524	.1638	.0457
2	.0457	.0486	.0648	.144	.1524	.1638	.0457
3	.0457	.0648	.0648	.1619	.1524	.1638	.0457
4	.0457	.064	.0648	.1638	.1524	.1943	.0457
5	.0457	.0648	.064	.192	.1524	.1943	.061
6	.0762	.0648	.0648	.192	.1524	.2267	.061
7	.0762	.0648	.08	.3239	.3048	.426	.0762
8	.0762	.0648	.0648	.0972	.061	.0648	.0914
9	.5335	.2561	.2591	.0762	.0762	.0594	.6249
10	.4755	.1966	.208	.061	.0579	.0594	.7926
11	.4161	.1638	.208	.061	.0594	.0594	.6836
12		.1966	.2	.061		.0446	.7727
13	.2972	.1966	.2229	.061	.0594	.0446	.7133
14	.2972	.2267	.2378	.061	.0594	.0594	.4877
15	.2972	.2622	.2378	.0762	.0579	.0594	.5182
16	.2675	.2984	.2027	.061	.0594	.0892	.743
17	.0446	.0819	.081	.061	.0648	.061	.0594
18	.0648	.081	.0648	.0914	.0648	.061	.0633
19	.0648	.0648	.0648	.061	.0648	.061	.0633
20	.0648	.0819	.0648	.0648	.0655	.061	.0633
21	.0648	.0819	.0648	.0633	.0655	.061	.064
22	.0648	.0648	.1943	.2214	.1638	.061	.0633
23	.0648	.0648	.1619	.1898	.1638	.061	.0633
24	.061	.0648	.0648	.1619	.1898	.1638	.0457
Max	.5335	.2984	.2591	.3239	.3048	.426	.7926
Min	.0446	.0486	.064	.061	.0579	.0446	.0457
Avg	.1537	.1202	.1279	.1189	.1110	.1110	.2623

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 202 / 11 KV SHIRALA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.0324	.0362	.0486	.061	.081	.0305
2	.0305	.0324	.0324	.081	.061	.081	.0305
3	.0305	.0324	.0324	.064	.061	.0819	.0305
4	.0305	.032	.0324	.08	.061	.0983	.0305
5	.0305	.032	.0324	.08	.061	.0972	.0305
6	.0305	.032	.0324	.064	.0914	.1296	.0305
7	.0305	.0324	.0324	.128	.1829	.1619	.0305
8	.0305	.0324	.0324	.0324	.0305	.0324	.0305
9	.1524	.1296	.0594	.0305	.0305	.029	.2134
10	.1189	.1296	.0594	.0305	.0297		.1932
11	.1783	.1619	.0892	.0305	.0297		.2429
12	.1635	.1619	.1448	.0305	.0297	.0286	.2526
13	.0743	.1638	.0857	.0305	.0286	.029	.2526
14	.0714	.1966	.0572	.0305	.0286	.0297	.2439
15		.1943	.0429	.0305	.029	.029	.2675
16	.1429	.1638	.1014		.0297	.0286	.2675
17	.0286	.0328	.0328	.0305	.0366	.0305	.0297
18	.0324	.0328	.0362	.0305	.0366	.0305	.0316
19	.032	.0324	.0324	.0305	.0328	.0305	.0316
20	.0324	.0328	.0324	.0312	.0328	.0305	.0316
21	.0324	.0324	.032	.0316	.0328	.0305	.0316
22	.0324	.0324	.0648	.0312	.0648	.0305	.0312
23	.0324	.0324	.0972	.032	.0983	.0305	.0316
24	.0305	.0324	.0324	.0648	.0312	.081	.0305
Max	.1783	.1966	.1448	.128	.1829	.1619	.2675
Min	.0286	.032	.032	.0305	.0286	.0286	.0297
Avg	.0608	.0758	.0526	.0467	.0505	.0560	.1011

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 203 / 11 KV NATH AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.16	.1619	.048	.0305	.0328	.4062
2	.1524	.16	.1619	.032	.0305	.0328	.4161
3	.1524	.1943	.1619	.048	.0305	.0324	.4161
4	.1524	.192	.1619	.032	.0305	.0328	.4062
5	.1524	.1943	.1943	.064	.0305	.0328	.4062
6	.1981	.2241	.1966	.064	.0305	.0655	.4641
7	.2439	.2915	.2267	.064	.0305	.0648	.4725
8	.0762	.0648	.0648	.0648	.061	.0648	.0762
9	.061	.0648	.0648	.3353	.4725	.5647	.0762
10	.0594	.0324	.0446	.381	.535	.5944	.0446
11	.0572	.0328	.0297	.3963	.535	.6321	.0594
12	.0594	.0324	.0297	.3963	.535	.7133	.0594
13	.0594	.0324	.0297	.4115	.535	.7133	.0446
14	.0594	.0492	.0301	.4115	.5053	.7133	.0457
15	.0594	.048		.4268		.743	.0446
16	.0446	.0486		.3963		.7621	.0446
17	.0286	.0655	.0486	.0457	.0324	.061	.0446
18	.048	.0492	.0648	.061	.0328	.061	.0625
19	.0663	.0655	.0648	.061	.0819	.061	.0625
20	.0648	.0655	.0648	.0633	.0819	.061	.0633
21	.0648	.0648	.064	.0633	.0648	.061	.0633
22	.2267	.1619	.0648	.0316	.0648	.4115	.4161
23	.1943	.1619	.064	.0316	.0486	.4268	.3749
24	.1829	.1943	.1619	.048	.032	.0324	.4115
Max	.2439	.2915	.2267	.4268	.535	.7621	.4725
Min	.0286	.0324	.0297	.0316	.0305	.0324	.0446
Avg	.1103	.1104	.0980	.1657	.1742	.2904	.2076

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 204 / 11 KV KAPARI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.0324	.029	.048
2	.0305	.0324	.0297	.08
3	.0305	.0324	.0297	.064
4	.0305	.0324	.0297	.081
5	.0305	.0324	.0297	.081
6	.0305	.0324	.0297	.064
7	.0305	.0324	.0297	.1296
8	.0305	.0324	.0297	.0324
9	.1524	.1296	.0594	
10	.1189	.1189	.0594	
11	.1783	.1486	.0892	
12	.1635	.1486	.1486	
13	.0743	.1486	.0869	
14	.0714	.1783	.0594	
15		.1783	.0434	
16	.1429	.1448	.1014	
17	.0286	.0286	.0324	
18	.032	.0297	.0324	
19	.0324	.0297	.0324	
20	.0324	.0286	.0324	
21	.0324	.029	.0324	
22	.0324	.0297	.0648	
23	.0324	.029	.0972	
24	.0305	.0324	.0297	.064
Max	.1783	.1783	.1486	.1296
Min	.0286	.0286	.029	.0324
Avg	.0608	.0705	.0516	.0716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 206 / 11 KV BIUR GAOTAHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.1829	.2195	.1646	.1463	.1848	.2195
2	.2195	.1829	.2195	.1829	.1463	.1848	.2218
3	.2195	.1629	.2195	.2195	.1478	.1848	.2195
4	.2218	.181	.2561	.2561	.1829	.2218	.2378
5	.2743	.1829	.2926	.2896	.2561	.2587	.2743
6	.3109	.3292	.3258	.3292	.2926	.4755	.3109
7	.4294	.439	.3658	.4024	.3696	.3658	.3841
8	.4755	.439	.3258	.4024	.3772	.3658	.439
9	.3658	.3658	.3361	.3292	.3658	.3292	.4066
10	.2957	.3258	.3326	.3292	.2987	.3292	.2926
11	.2587	.2534	.2957	.3109	.1848	.3326	.2561
12	.2957	.2195	.2561	.2561	.2587	.2926	.2926
13	.2241	.2195	.2561	.2587	.2218	.2218	.2561
14		.2896	.2218	.2195	.2957	.2561	.2587
15	.2926	.2534	.2195	.1829	.2561	.2195	.2957
16	.2561	.2534	.1829	.1829	.3077	.2957	.1848
17	.2561	.2926	.2896	.3475	.3258	.3475	.2561
18	.3658	.362	.2896	.3658	.3658	.3658	.181
19	.5121	.4344	.4755	.2195	.4024	.439	.4344
20	.5487	.4344	.5068	.4024	.439	.4024	.4706
21	.439	.3658	.439	.3982	.439	.439	.3982
22	.3658	.3258	.362	.2957	.3658	.4024	.3258
23	.2896	.2896	.2172	.2534	.2926	.3109	.2534
24	.2378	.2195	.2561	.1829	.1478	.2195	.2378
Max	.5487	.439	.5068	.4024	.439	.4755	.4706
Min	.2195	.1629	.1829	.1646	.1463	.1848	.181
Avg	.3206	.2918	.2984	.2826	.2869	.3102	.2961

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 207 / 11 KV NATH GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366	.0366	.0366	.0366	.0366	.0366	.037
2	.0366	.0366	.0366	.0549	.037	.0366	.0366
3	.0366	.0366	.0366	.0366	.037	.0366	.0366
4	.037	.0362	.0366	.0549	.0366	.0366	.0366
5	.0366	.0549	.0366	.0732	.037	.0543	.0366
6	.0549	.0732	.0724	.0366	.037	.0724	.0549
7	.0739	.0543	.0724	.0549	.0366	.0732	.0549
8	.0739	.0373	.0724	.0362	.0549	.0724	.0732
9	.0739	.0362	.0549	.0554	.037	.0701	.0549
10	.0366	.0543	.0366	.0549	.0549	.0549	.0549
11	.0366	.0543	.0366	.037	.0358	.0366	.0732
12	.0366	.0362	.0358	.0366	.0366	.0366	.0549
13	.0366	.0362	.0366	.037	.0358	.0366	.0366
14		.0362	.1463	.0366	.0366	.0358	.0358
15	.0366	.0362	.0343	.0366		.0366	.037
16	.0366	.0362	.0366	.0549		.0343	.0343
17	.0366	.0366	.0362	.0549	.0362	.0554	.0366
18	.0362	.0366	.0362	.0739	.0549	.0549	.0366
19	.0724	.0366	.0724	.0716	.0724	.0914	.0362
20	.0747	.0724	.0747	.0732	.0724	.0732	.0366
21	.0724	.0732	.0549	.0373	.0724	.0549	.0366
22	.0373	.0549	.0362	.0358	.0549	.0554	.0366
23	.0366	.0366	.0362	.0362	.0362	.0366	.0362
24	.0366	.0362	.0362	.0362	.0366	.0362	.0366
Max	.0747	.0732	.1463	.0739	.0724	.0914	.0732
Min	.0362	.0362	.0343	.0358	.0358	.0343	.0343
Avg	.0471	.0448	.0500	.048	.0448	.0508	.0433

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 208 / 11 KV SHIRALA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5304	.4572	.5175	.4755	.439	.4435	.4435
2	.5359	.4572	.5175	.4572	.4481	.439	.439
3	.5359	.439	.5175	.5487	.4755	.4435	.439
4	.5359	.439	.5853	.5853	.5175	.5853	.4755
5	.7023	.4481	.6584	.6219	.5487	.6584	.5853
6	.7682	.5853	.7316	.6584	.5853	.7316	.6584
7	.8962	.7964	.7964	.8779	.8048	.8048	.8779
8	.8596	.724	.724	.8048	.7316	.7316	.8501
9		.8215	.7392	.7392	.7316	.6584	.7468
10	.7316	.724	.7468	.7316	.6653	.6653	.7468
11	.6653	.6584	.6653	.6653	.6653	.6722	.6584
12	.6283	.5792	.6653	.6535	.5914	.6653	.6653
13	.5914	.5792	.6653	.6099	.5914	.5914	.6653
14		.5853	.5853	.6283	.5914	.5914	.6653
15	.6584	.5853	.5914	.6219	.5914	.5975	.5975
16	.7392	.5853	.5853	.5853	.5175	.5914	.5975
17	.6653	.6584	.5068	.6219	.5853	.6584	.5914
18	.6722	.724	.5121	.5914	.5853	.7392	.6447
19	.8962	.8688	.724	.8962	.8048	.8413	.8779
20	.8962	.9511	.8215	.8131	.8779	.8779	.8962
21	.8402	.7316	.7964	.7316	.8048	.8048	.7316
22	.7468	.6516	.724	.6653	.6516		.7316
23	.5792	.5792	.5792	.5731	.5068	.6401	.5853
24	.5359	.5068	.5853	.5068	.4344	.5121	.4805
Max	.8962	.9511	.8215	.8962	.8779	.8779	.8962
Min	.5304	.439	.5068	.4572	.4344	.439	.439
Avg	.6914	.6307	.6476	.6527	.6144	.6498	.6521

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 209 / 11 KV KAPARI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.2172	.1829	.1646	.1463	.1829	.2926
2	.1478	.1829	.1829	.1829	.1478	.1829	.2957
3	.1646	.1646	.1829	.1829	.1478	.1848	.2926
4	.1646	.1463	.1829	.2012	.1463	.2218	.2957
5	.1829	.181	.2172	.2195	.1478	.2195	.2926
6	.2587	.2241	.2172	.2195	.1848	.2561	.3142
7	.2957	.2896	.2561	.2561	.2561	.2561	.3326
8	.2772	.2172	.2534	.2561	.2587	.2561	.3326
9	.7682	.2195	.2587	.2926	.2218	.2218	.2926
10	.2561	.2926	.2561	.3511	.2957	.2957	.3696
11	.2561	.3292	.3292	.3696	.3326	.4435	.2926
12		.2896	.3326	.3292	.4755	.2926	.4066
13	.2218	.2195	.2957	.2926	.3696	.2587	.4024
14		.1829	.2587	.3174	.3696	.3734	.3658
15	.1829	.1829	.1829	.3658	.4024	.5121	.3658
16	.2218	.2172	.2561	.2378	.4755	.4435	.4755
17	.2241	.2561	.2614	.2195	.2926	.4572	.4024
18	.2534	.2534	.2534	.2218	.2172	.2561	.181
19	.3258	.2896	.2534	.2195	.2195	.3292	.2534
20	.362	.3658	.2896	.2561	.2561	.3109	.2561
21	.3258	.2926	.2534	.2561	.2561	.3109	.2561
22	.2896	.2534	.2172	.2195	.2195		.2534
23	.2534	.2172	.181	.1448	.181	.3109	.181
24	.1829	.2534	.2195	.181	.1463	.1848	.2957
Max	.7682	.3658	.3326	.3696	.4755	.5121	.4755
Min	.1463	.1463	.181	.1448	.1463	.1829	.181
Avg	.2619	.2391	.2406	.2482	.2569	.2940	.3124

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244004 / 33/11 KV SHIRALA

Feeder No / Name : 401 / 33 KV GLUCOSE EXPRESS

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.144	.0972	.1052	.1457	.096	.1063	.096
2	.144	.0972	.1052	.0972	.096	.1052	.0972
3	.144	.144	.1063	.1457	.0972	.1029	.0972
4	.144	.0972	.1029	.096	.096	.1029	.0972
5	.1457	.144	.1029	.096	.096	.1029	.096
6	.144	.096	.1029	.096	.0972	.1543	.1457
7	.144	.096	.1029	.0972	.0972	.1543	.144
8	.1943	.096	.1052	.0937	.0972	.1543	.1457
9	.1943	.0972	.1966	.0972	.0972		.1457
10	.1646	.1029	.096	.1109	.0983	.096	.0937
11	.096	.1029	.0937	.0972	.0937	.1406	.0937
12	.096	.1052	.0857	.0972	.0937	.0937	.0983
13	.096	.1543	.0937	.0972	.0937	.0892	.0937
14	.0972	.1543	.1097	.0972	.0914	.0937	.0937
15	.0937	.1063	.096	.0972	.0892	.0937	.0914
16	.1337	.1029	.0983	.0972	.0937	.0892	.0914
17	.0983	.1052	.0972	.0972	.1097	.0983	.0914
18	.0972	.1543	.0972	.096	.1097	.096	.0949
19	.0972	.1543	.096	.0983	.1029	.0972	.0949
20	.096	.1543	.0972	.1006	.1052	.1475	.0949
21	.0983	.1029	.0972	.0937	.1052	.096	.0949
22	.0983	.1006	.0972	.0937	.1029	.0972	.0949
23	.0972	.1029	.096	.0949	.1029	.0972	.0949
24	.1457	.1406	.1029	.2915	.0949	.1029	.0972
Max	.1943	.1543	.1966	.2915	.1097	.1543	.1457
Min	.0937	.096	.0857	.0937	.0892	.0892	.0914
Avg	.1252	.1170	.1035	.1094	.0982	.1092	.1033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 202 / 11 KV MANDOOR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2229	.2401	.2229	.2229	.2229	.2229
2	.2058	.2058	.2229	.2058	.2058	.2058	.2058
3	.1886	.2058	.2229	.2058	.1715	.1886	.2058
4	.1715	.2058	.2229	.2058	.1715	.1886	.2058
5	.1886	.2229	.2401	.2229	.2572	.2401	.2401
6	.2743	.2743	.2915	.2743	.2743	.2743	.2915
7	.3772	.4458	.4458	.463	.4115	.4287	.3772
8	.5316	.5144	.463	.4458	.4458	.4801	.4115
9	.4973	.4801	.4973	.463	.4287	.4115	.3601
10	.4458	.4287	.4287	.3772	.3258	.4115	.2915
11	.3944	.4115	.3772	.3429	.3086	.3258	.3086
12	.3086	.3429	.3601	.2743	.2058	.3086	.1029
13	.2743	.2401	.3429	.2229	.2743	.2743	.2915
14	.2915	.2915	.2915	.2058	.12	.2401	.1029
15	.3086	.2572	.2915	.2229	.3086	.2401	.3086
16	.3429	.2743	.3086	.2572	.3086	.4115	.3086
17	.3429	.3086	.2743	.3429	.4287	.3944	.3429
18	.463	.463	.2915	.4801	.4801	.4973	.4458
19	.5316	.6001	.5144	.5658	.5144	.6001	.463
20	.6173	.6001	.6173	.6173	.6001	.6173	.6173
21	.583	.6001	.583	.5658	.5487	.5487	.5316
22	.5144	.5144	.463	.4287	.4801	.463	.4287
23	.3601	.3429	.3086	.3086	.3429	.3258	.3429
24	.2229	.2743	.2915	.2401	.2572	.2743	.2743
Max	.6173	.6001	.6173	.6173	.6001	.6173	.6173
Min	.1715	.2058	.2229	.2058	.12	.1886	.1029
Avg	.3601	.3636	.3579	.3401	.3372	.3572	.3201

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 203 / 11 KV CHARAN GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2229	.2401	.2058	.2229	.2229	.2229
2	.2058	.2058	.2058	.2058	.2401	.2058	.2058
3	.2229	.2058	.2058	.2058	.2058	.2058	.2058
4	.2058	.2058	.1886	.2058	.2229	.2058	.2058
5	.2058	.2229	.1886	.2229	.2401	.2401	.2058
6	.3258	.2743	.2572	.2743	.2401	.2743	.2915
7		.4458	.4115	.463	.4458	.4115	.4287
8	.6344	.5658		.5316	.5144	.5144	.4973
9	.5658	.4801	.1715	.4973	.4801	.4458	.4115
10	.463	.4287	.1886	.4115	.4115	.3772	.4458
11	.4801	.3944		.3772	.4115	.3601	.3772
12	.463	.4458		.4115	.3601	.3772	.3944
13	.4115	.4287	.1715	.3601	.3601	.3601	.3086
14	.3772	.3086	.4973	.3429	.3258	.3429	.3258
15	.3429	.2401	.4458	.2572	.2743	.2915	.2915
16	.3086	.2915	.3944	.2743	.2572	.3086	.2915
17	.3772	.3772	.3258	.3086	.2915	.3086	.2915
18		.463	.3258	.3772	.3944	.3772	.3086
19		.583	.463	.5487	.4973	.5316	.463
20	.6516	.6001	.6516	.6173	.583	.4801	.5658
21	.583	.583	.583		.5144	.4801	.4973
22	.5144	.5144	.4801	.463	.4458	.4287	.4287
23	.3601	.3601	.3258	.3258	.3429	.3429	.3429
24	.2229	.2572	.3086	.2401	.2401	.2401	.2572
Max	.6516	.6001	.6516	.6173	.583	.5316	.5658
Min	.2058	.2058	.1715	.2058	.2058	.2058	.2058
Avg	.3878	.3794	.3348	.3534	.3551	.3472	.3444

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 204 / 11 KV MANDOOR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0171	.0171	.0171	
2				.0171	.0171	.0171	
3				.0171	.0171	.0171	
4				.0171	.0171	.0171	
5				.0171	.0171	.0171	
6				.0171	.0171	.0171	
7				.0171	.0171	.0171	
9		.0171	.0171				.0514
10		.0171					.0514
11		.0171	.0171				.0514
12	.0171	.0171	.0171				.0514
13	.0171	.0171	.0171				.0171
14	.0171	.0171	.0171				.0171
15	.0171	.0171	.0171				.0171
16	.0171	.0171	.0171				.0171
22			.0171	.0171	.0171		
23			.0171	.0171	.0171		
24				.0342	.0171	.0171	
Max	.0171	.0171	.0171	.0342	.0171	.0171	.0514
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.0171	.0171	.0171	.0188	.0171	.0171	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244018 / 33/11 KV PANUMBRE S/S.

Feeder No / Name : 401 / 33 KV WARNAWATI

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 33 / OUTGOING

UTILITY

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0669	.0669	.0669	.072	.072	.0669	.0669
2	.0669	.0617	.0669	.072	.0669	.0617	.0669
3	.072	.0617	.0669	.072	.0669	.0617	.0669
4	.0669	.0617	.0669	.072	.0617	.0617	.0669
5	.072	.0617	.0669	.072	.0566	.0669	.072
6	.072	.0669	.0669	.0772	.0669	.0669	.0823
7	.0926	.072	.072	.0617	.0772	.072	.0823
8	.072	.072	.072	.072	.072	.072	.072
9	.072	.0669	.0669	.0669	.072	.0772	.072
10	.072	.0669	.072	.0617	.0617	.0823	.0566
11	.072	.072	.0566	.0514	.036	.072	.0566
12	.0772	.072	.0617	.0617	.0412	.072	.0669
13	.072	.0617	.0617	.0514	.0617	.072	.0669
14	.0669	.0617	.0669	.0669	.0669	.0669	.0669
15	.0772	.0772	.0669	.0566	.0669	.0669	.0772
16	.0514	.0617	.072	.0566	.0669	.0617	.0772
17	.0669	.0514	.072	.0617	.0514	.0617	.0772
18	.0566	.0514	.0669	.0617	.0566	.0617	.072
19	.0566	.0669	.0772	.072	.0617	.0617	.0514
20	.0617	.0669	.0874	.0823	.072	.072	.072
21	.0617	.0669	.0823	.072	.0772	.072	.072
22	.072	.072	.0772	.072	.072	.072	.072
23	.0669	.0669	.0772	.072	.072	.0669	.072
24	.072	.0669	.0669	.072	.072	.072	.072
Max	.0926	.0772	.0874	.0823	.0772	.0823	.0823
Min	.0514	.0514	.0566	.0514	.036	.0617	.0514
Avg	.0690	.0656	.0699	.0671	.0645	.0684	.0699

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11KV CHIKHALI SUB

STATION

Feeder No / Name : 201 / 11 KV KANDE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362	.0236	.0343	.1467	.192	.2267	
2	.0362	.0236	.0343	.1467	.1947	.2267	.0343
3	.0362	.0236	.0343	.1467	.1947	.2267	.0343
4	.0362	.024	.0343	.1467	.2115	.2267	.0343
5	.0362	.024	.0343	.16	.2256	.2267	.0343
6	.0362	.0244	.0343	.1734	.2572	.2591	.0343
7	.0362	.0343	.0343	.2134	.4161	.3658	.0343
8		.0343	.0343	.0343	.029	.0362	.0343
9	.0362	.0343	.0343	.0305	.0036	.0343	.0343
10	.029	.0339	.0343	.0305	.0362	.0343	.0305
11	.0293	.0343	.0343	.0301	.0362	.0343	.0343
12	.4877	.3772	.2715	.0316	.0362	.0343	.823
13	.4515	.3772	.2858	.0274	.0362	.0343	.8535
14	.4214	.3222	.3048	.029	.0362	.0343	.9755
15	.3765	.3086	.3048	.0271	.0362	.0343	1.0212
16	.3668	.3086	.4268	.0251	.0362	.0343	1.0669
17	.3715	.2915	.4268	.0251	.0362	.0343	1.0669
18	.3384	.2743	.4268	.0251	.0362	.0343	1.2254
19	.3102	.2915	.3353	.0301	.0362	.0343	.9602
20	.0271	.0343	.0305	.029	.0362	.0343	.0343
21	.0263	.0343	.0305	.029	.0362	.0343	.0343
22	.0251	.0343	.2134	.2115	.2591	.0343	.0343
23	.0236	.0343	.1677	.192	.2591	.0343	.0343
24	.0362	.0236	.0343	.1467	.192	.2267	.0343
Max	.4877	.3772	.4268	.2134	.4161	.3658	1.2254
Min	.0236	.0236	.0305	.0251	.0036	.0343	.0305
Avg	.1570	.1261	.1515	.0870	.1195	.1057	.3697

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11KV CHIKHALI SUB

STATION

Feeder No / Name : 202 / 11 KV NATOLI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.032	.0332	.1334	.192	.1829	.0343
2	.0305	.032	.0343	.1334	.192	.1829	.0332
3	.0305	.032	.0332	.1334	.1947	.1829	.0343
4	.0305	.032	.0332	.1334	.1947	.1829	.0343
5	.0305	.0335	.0332	.1334	.2086	.1829	.0339
6	.0305	.032	.0332	.1334	.2364	.2134	.0343
7	.0305	.0343	.0332	.2	.362	.3658	.0332
8	.0305	.0332	.0343	.0343	.0339	.0305	.0332
9	.3887	.3315	.3018	.0347		.0343	.7316
10	.3319	.2818	.2896	.0347	.0305	.0343	.8078
11	.3368	.2818	.2896	.0366	.0305	.0332	.884
12	.2675	.2652	.2801	.0347	.0305	.0332	.9145
13	.2103	.2652	.2934	.032	.0305	.0343	.884
14	.2	.2486	.3353	.0324	.0305	.0332	.8535
15	.1814	.2743	.3201	.0347	.0305	.0343	.8535
16	.1972	.2984	.3201	.0332	.0305	.0332	.8078
17	.0324	.0332	.0343	.0328	.0305	.0343	.0343
18	.0328	.0332	.0343	.0339	.0305	.0332	.0343
19	.0335	.0343	.0343	.0328	.0305	.0343	.0343
20	.0332	.0343	.0343	.0312	.0305	.0332	.0343
21	.0324	.0332	.0343	.0312	.0305	.0332	.0343
22	.0335	.0332	.1334	.2029	.2439	.0343	.0343
23	.0312	.0332	.1334	.192	.2439	.0343	.0343
24	.0305	.0312	.0335	.1143	.192	.2134	.0332
Max	.3887	.3315	.3353	.2029	.362	.3658	.9145
Min	.0305	.0312	.0332	.0312	.0305	.0305	.0332
Avg	.1091	.1156	.1321	.0825	.1157	.0935	.3034

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11KV CHIKHALI SUB

STATION

Feeder No / Name : 204 / 11 KV KANDE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1494	.1715	.2614	.2241	.1848	.1715
2	.1829	.1494	.1715	.2614	.2241	.1478	.1372
3	.1829	.1494	.1715	.2614	.2241	.1478	.1372
4	.1829	.1494	.1715	.2614	.2241	.1478	.1372
5	.1829	.1478	.1715	.2614	.2241	.1848	.1715
6	.2195	.2241	.1715	.3174	.2587	.2218	.1715
7	.2561	.1715	.1715	.3174	.2896	.2561	.2058
8	.2195	.1715	.1715	.2987	.3258	.2195	.2058
9	.2195	.1715	.2241	.2835	.2926	.1715	.1829
10	.1463	.1715	.2241	.2804	.2561	.2058	.1646
11	.1433	.2058	.1867	.2507	.181	.1715	.1463
12	.1734	.1715	.3366	.2126	.1463	.1715	.168
13	.1402	.1715	.2614	.1791	.1463	.1715	.1829
14	.104	.1715	.2561	.2149	.1448	.1715	.1829
15	.0983	.1715	.2926	.2172	.1829	.1372	.128
16	.1357	.1715	.2926	.2774	.2378	.1372	.1646
17	.1696	.1715	.2561	.2804	.2561	.1715	.1829
18	.2058	.1715	.1829	.1658	.3292	.1715	.2195
19	.2172	.2058	.2561	.2126	.2561	.2058	.2561
20	.2587	.2401	.2987	.2172	.2561	.2058	.2801
21	.2218	.2401	.3361	.2926	.2926	.2058	.3361
22	.2218	.2401	.2987	.2926	.2195	.2058	.3174
23	.1478	.1715	.2614	.2587	.2195	.1715	.2801
24	.1829	.1478	.2401	.2561	.2241	.1791	.1715
Max	.2587	.2401	.3366	.3174	.3292	.2561	.3361
Min	.0983	.1478	.1715	.1658	.1448	.1372	.128
Avg	.1832	.1795	.2323	.2555	.2348	.1819	.1959

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11KV CHIKHALI SUB

STATION

Feeder No / Name : 205 / 11 KV NATOLI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724	.0366	.1372	.0732	.0747	.0716	.1372
2	.0724	.0366	.1372	.0747	.0747	.0716	.1029
3	.0724	.037	.1372	.0747	.0747	.0716	.1029
4	.0724	.037	.1372	.0747	.0739	.0716	.1029
5	.0362	.0739	.1029	.0747	.0739	.0716	.1029
6	.1086	.1109	.1029	.1463	.1109	.1075	.1029
7	.1629	.1029	.1029	.1463	.1448	.1463	.1372
8	.1433	.1372	.1029	.12	.1075	.128	.1029
9	.1254	.1372	.1097	.1341	.1075	.1029	.1052
10	.1417	.1372	.1629	.1341	.1086	.1029	.1372
11	.0693	.1372	.128	.1326	.0895	.1029	.1463
12	.0686	.1029	.1029	.0686	.0905	.1029	.1949
13	.0693	.1029	.124	.0686	.0895	.1029	.1753
14	.0972	.1017	.1029	.0663	.0895	.1029	.1417
15	.0617	.1029	.1227	.0686	.0895	.1029	.1772
16	.0671	.1372	.1052	.0686	.0895	.1029	.1753
17	.1341	.1372	.1052	.125	.1075	.1029	.1753
18	.1029	.1029	.1463	.0995	.1433	.1029	.1578
19	.1791	.1029	.1772	.1734	.1791	.1372	.2103
20	.2172	.1372	.2054	.1448	.1791	.1372	.2378
21	.1478	.1372	.1867	.1478	.1433	.1372	.2172
22	.1478	.1372	.1494	.1109	.1254	.1715	.1829
23	.1097	.1372	.1307	.0747	.1075	.1372	.112
24	.1075	.0732	.1372	.0924	.0747	.0716	.1372
Max	.2172	.1372	.2054	.1734	.1791	.1715	.2378
Min	.0362	.0366	.1029	.0663	.0739	.0716	.1029
Avg	.1078	.1040	.1315	.1039	.1062	.1067	.1490

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244027 / 33/11KV CHIKHALI SUB

STATION

Feeder No / Name : 401 / 33 KV JYOTIRLING LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1109				
8					.2058
9					.5144
10			.2012		.5144
11		.2572	.503		.4973
12		.5144	.4915	.5144	.5144
13		.5144	.4858	.5144	.4973
14		.5144	.4915	.5144	.4973
15		.5144	.4915	.5144	.5144
16		.5144	.4915	.5144	.4973
Max	.1109	.5144	.503	.5144	.5144
Min	.1109	.2572	.2012	.5144	.2058
Avg	.1109	.4715	.4509	.5144	.4725

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 201 / 11 KV WAKURDE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2172	.0676	.0465	.0305	.0324	.0305	.1829
2	.192	.0676	.0457	.0312	.0305	.0305	.1677
3	.1989	.0686	.0457	.0312	.0324	.0312	.1174
4	.2587	.0676	.0465	.0305	.0343	.0312	.1174
5	.2614	.0619	.064	.0312	.0309	.0305	.1174
6	.2241	.0591	.06	.0312	.0324	.0297	.1524
7	.3201	.1429	.2286	.061	.0617	.0305	.253
8	.0633	.0191	.061	.0762	.0633	.0305	.0316
9	.064	.0198	.0572	.1614	.3749	.2027	.0286
10	.0366	.0305	.0572	.2469	.427	.3086	.032
11	.0366	.0251	.029	.2743	.4111	.3963	.0316
12	.0335		.029	.2743	.3906	.3963	.0324
13	.0335		.029	.1981	.381	.2934	.0351
14	.0328		.029	.216	.3715	.2934	
15	.0328	.0229	.029	.1829	.3658	.3658	.0332
16	.0358	.0442	.029	.1981	.39	.3612	.0324
17	.0351	.0472	.029	.0602	.0305	.016	.032
18	.0373	.0533	.029	.0633	.0305	.0564	.0625
19	.0541	.0594	.0714	.061	.0305	.0762	.0648
20	.0541	.0937	.0762	.061	.0305	.061	.0625
21	.0267	.064	.0762	.061	.0305	.061	.0625
22	.0541	.08	.0309	.064	.0312	.2372	.1875
23	.0676		.0305	.0678	.0312	.2187	.1989
24	.2241	.0676	.0465	.0305	.0316	.0305	.216
Max	.3201	.1429	.2286	.2743	.427	.3963	.253
Min	.0267	.0191	.029	.0305	.0305	.016	.0286
Avg	.1081	.0581	.0532	.1060	.1532	.1508	.0979

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 202 / 11 KV TAKAVE AG

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0848	.0633	.6718	.9231	.703	.0686
2	.0648	.0848	.0625	.6562	.8954	.703	.0686
3	.064	.0934	.0625	.6562	.9511	.6874	.0693
4	.0655	.081	.0625	.6562	.9774	.703	.0693
5	.0663	.0781	.0625	.6802	.9602	.7186	.0693
6	.0655	.0781	.0857	.7116	.9282	.7811	.0716
7	.1029	.0693	.0905	.8907	1.1869	.9717	.0905
8	.0648	.0903	.0829	.0693	.0781	.0886	.1052
9	1.3592	.9717	1.0978	.0867	.0972	.0709	
10	1.3435	.9878	1.2266	.0686	.0905	.0716	1.1984
11	1.3435	.9442	1.2763	.0895	.0716	.0701	1.5775
12	1.3108	.9878	1.3923	.0701	.0905	.0701	1.8652
13	1.3108	.9172	1.3923	.0781	.0867	.0876	2.6244
14		.933	.9717	.0791	.1029	.0876	2.4966
15		1.0202	1.1984	.0648	.0895	.0693	2.6787
16		1.0402	.9762	.1006	.0857	.0867	2.6993
17		.0695	.081	.0972	.1187	.064	.1006
18	.0903	.0724	.081	.096	.12	.0838	.12
19	.1029	.0867	.0876	.0937	.0905	.0867	.0791
20	.1029	.0886	.0895	.0949	.0914	.0886	.0724
21	.0838	.0886	.0905	.0693	.0914	.0886	.1029
22	.1017	.0867	.7116	.7907	.759	.0709	.0663
23	.0848		.703	.9231	.7432	.0701	.0693
24	.0625	.0848	.0633	.6874	.8916	.703	.0678
Max	1.3592	1.0402	1.3923	.9231	1.1869	.9717	2.6993
Min	.0625	.0693	.0625	.0648	.0716	.064	.0663
Avg	.3930	.3930	.5005	.3534	.4384	.3011	.7144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 203 / 11 KV PADALI AG.

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.1296	.092	.0297	.032	.0297	.1391
2	.1429	.1296	.088	.0297	.0343	.0297	.141
3	.1505	.1296	.088	.0297	.0293	.0286	.141
4	.208	.1296	.088	.0301	.0286	.0286	.141
5	.2172	.1276	.1036	.0305	.0335	.0286	.1448
6	.1829	.1276	.1387	.0305	.0309	.0286	.1852
7	.2439	.192	.2347	.0594	.0625	.0286	.2439
8	.0312	.0229	.0312	.0594	.0663	.0286	.0305
9	.0305	.024	.0316	.1882	.3163	.3704	.0263
10	.0343	.0305	.0312	.2374	.3321	.4062	.0282
11	.0343	.0305	.0305	.253	.3479	.0762	.0312
12	.016	.0305	.0305	.2652	.3858	.0762	.0309
13	.0343	.029	.0305	.2469	.381	.0602	.0332
14	.0343	.0293	.0305	.2778	.3763	.0602	.0347
15	.0343	.0305	.0305	.3086	.3395	.3311	.0347
16	.0343	.0301	.0305	.3801	.3567	.3227	.0354
17	.0343	.0301	.0305		.0305	.0343	.032
18	.0343	.0602	.0305	.032	.0305	.0526	.0625
19	.0396	.0312	.061	.0309	.0305	.0594	.0678
20	.0396	.0633	.061	.0309	.0305	.0286	.0701
21	.0343	.064	.061	.0309	.0305	.0282	.061
22	.1296	.1097	.0297	.0312	.0286	.1448	.2486
23	.1296		.0286	.0305	.0286	.1391	.213
24	.1867	.1296	.0907	.0286	.0324	.0297	.1372
Max	.2439	.192	.2347	.3801	.3858	.4062	.2486
Min	.016	.0229	.0286	.0286	.0286	.0282	.0263
Avg	.0932	.0744	.0626	.1161	.1415	.1021	.0964

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 204 / 11 KV PADALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1134	.1848	.1075	.1097	.1029	.1097	.1097
2	.0914	.1848	.1063	.1097	.1086	.1109	.1097
3	.0693	.1848	.1063	.1097	.1029	.1109	.1097
4	.0701	.1848	.1063	.1086	.1134	.1109	.1086
5	.0663	.1848	.1052	.1267	.1235	.1294	.1086
6	.1254	.1791	.1595	.1448	.144	.1663	.1646
7	.2033	.208	.2172	.181	.1928	.2149	.2149
8	.1886	.208	.2103	.2103	.2149	.208	.1949
9	.1753	.1696	.1595	.1734	.1753	.1578	.1715
10	.1174	.1772	.1433	.1357	.1214	.1341	.2149
11	.1174	.104	.12	.1006	.0876	.1865	.0867
12	.0995	.1214	.1017	.0838	.0876	.1865	.0895
13	.0995	.1147	.0724	.0693	.0716	.0678	.0781
14	.1029	.0983	.104	.0663	.0701	.0678	.0876
15	.1029	.0838	.0693	.0686	.0709	.0886	.0716
16	.0857	.104	.0709	.0693	.0709	.0876	.0829
17	.1109	.12	.0686	.0829	.1006	.0867	.0857
18	.1802	.1526	.1509	.1646	.1417	.1509	.1067
19	.1966	.2172	.1791	.197	.2012	.181	.2012
20	.2218	.2218	.2054	.2033	.1867	.2054	.2054
21	.2218	.2241	.2241	.1886	.1886	.1867	.1886
22	.2033	.2033	.1848	.1663	.168	.1867	.168
23	.1848		.128	.1214	.1307	.1294	.1448
24	.1387	.1848	.1254	.1086	.1086	.1097	.1097
Max	.2218	.2241	.2241	.2103	.2149	.2149	.2149
Min	.0663	.0838	.0686	.0663	.0701	.0678	.0716
Avg	.1369	.1659	.1344	.1292	.1285	.1406	.1339

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 205 / 11 KV WAKURDE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.2149	.1494	.1463	.1448	.1463	.1829
2	.1387	.2149	.1307	.1463	.1029	.1463	.1829
3	.1134	.2149	.1307	.1463	.1052	.1448	.1829
4	.1067	.2149	.1307	.1463	.1086	.1463	.1829
5	.2012	.2195	.1307	.1646	.1402	.1478	.1646
6	.2075	.2378	.1698	.1829	.1886	.1848	.2241
7	.3018	.3012	.2402	.2957	.2686	.2561	.3292
8	.3206	.298	.2402	.3077	.2614	.2896	.3258
9	.1848	.2454	.2353	.2686	.2218	.2481	.2629
10	.2058	.2507	.2328	.1772	.2126	.208	.2587
11	.2058	.2149	.1928	.2103	.1949	.1753	.2229
12	.1966	.1227	.1949	.2378	.1715	.1753	.2058
13	.16	.0995	.1772	.1734	.1543	.1823	.1802
14	.16	.1372	.1886	.1734	.1357	.1823	.1949
15	.16	.1949	.1781	.1753	.1372	.2012	.1907
16	.208	.197	.1595	.1966	.1844	.1772	.2126
17	.2486	.1949	.1907	.2105	.1989	.253	.1907
18	.2753	.208	.2103	.2454	.2401	.2683	.2058
19	.3239	.3696	.3109	.3696	.3439	.362	.3696
20	.3582	.4294	.3734	.3921	.3881	.4066	.3772
21	.394	.3641	.3734	.3881	.3185	.3734	.3361
22	.2686	.3206	.2987	.2829	.2801	.3174	.2641
23	.2686		.1848	.1753	.2012	.2195	.2263
24	.1867	.2149	.168	.1463	.1509	.1478	.1829
Max	.394	.4294	.3734	.3921	.3881	.4066	.3772
Min	.1067	.0995	.1307	.1463	.1029	.1448	.1646
Avg	.2226	.2383	.2080	.2233	.2023	.2233	.2357

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244057 / 33/11 KV SHIRASHI S/S

Feeder No / Name : 206 / 11 KV TAKAVE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.2012	.132	.1494	.0972	.1097	.1132
2	.1829	.2012	.132	.1494	.0995	.1097	.1132
3	.1734	.2012	.132	.1307	.0926	.1109	.1132
4	.1402	.2012	.132	.1307	.0937	.1109	.1132
5	.2058	.2195	.132	.1494	.1387	.1294	.1132
6	.2987	.2218	.1886	.1848	.1753	.1829	.1867
7	.2957	.2896	.3174	.3155	.2743	.2715	.3326
8	.2926	.3258	.3109	.2865	.3018	.2896	.3258
9	.2753	.3121	.2896	.2303	.2772	.2715	.298
10	.2347	.3294	.2629	.2103	.2658	.2103	.2743
11	.2347	.2303	.2303	.2321	.2303	.2103	.1966
12	.2012	.1949	.2172	.1865	.1677	.2103	.1658
13	.16	.156	.12	.1075	.1227	.1402	.1543
14	.16	.1448	.1543	.1086	.112	.1402	.1402
15	.1638	.1433	.1715	.0686	.1341	.1433	.1265
16	.1696	.1254	.1886	.112	.1341	.2012	.1543
17	.208	.1254	.1543	.1372	.1372	.1677	.1734
18	.2149	.1629	.1734	.1949	.2229	.2279	.1989
19	.3326	.3077	.2534	.2587	.3658	.2926	.2427
20	.3326	.4108	.3841	.3511	.3292	.3547	.3258
21	.2218	.3734	.3475	.4024	.3292	.2987	.2957
22	.2587	.3018	.2614	.2279	.2561	.3326	.2987
23	.2218		.1886	.16	.1829	.1509	.2172
24	.181	.2012	.1509	.1478	.1029	.1294	.1132
Max	.3326	.4108	.3841	.4024	.3658	.3547	.3326
Min	.1402	.1254	.12	.0686	.0926	.1097	.1132
Avg	.2228	.2340	.2094	.1930	.1935	.1999	.1994

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 202 / 11 KV DEWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0166	.0166	.0166	.1486	.2134	.4687	.0316
2	.0166	.0166	.0166	.1783	.2134	.4531	.0316
3	.0332	.0166	.0166	.1486	.2134	.4531	.0316
4	.0332	.0166	.0166	.1486	.2134	.4687	.0316
5	.0332	.0166	.0166	.1783	.2286	.4687	.0316
6	.0332	.0166	.0332	.1783	.2896	.5312	.0316
7	.0332	.0166	.0332	.3269	.3353	.6874	.0316
8		.0166	.0332	.0301	.0152	.0156	.0316
9		.6299		.0149	.0152	.0156	1.2967
10		.663		.0151	.0152	.0156	1.4883
11		.663		.0151	.0152	.0312	1.4403
12		.6133		.0151	.0152	.0312	1.5364
13	.6133	.4973	.2984	.0151	.0152	.0156	1.3603
14	.4973	.4641	.4144	.0151	.0152	.0156	1.3927
15	.5304	.4475	.4144	.0151	.0152	.0156	1.4737
16	.547	.4144	.3978	.0151	.0152	.0312	
17	.0166	.0166	.0332	.0151	.0152	.0312	1.4737
18	.0166	.0166	.0166		.0152	.0312	.0324
19	.0166	.0166	.0166	.0151	.0152	.0312	.0162
20	.0332	.0166	.0166	.0151		.0312	.0162
21	.0332	.0166	.0166	.0151	.0152	.0316	.0162
22	.0166	.0166	.2155	.2134	.4938	.0316	.0324
23	.0166	.0166	.1989	.2134	.4938	.0316	.081
24	.0332	.0166	.0166	.1989	.2134	.463	.0316
Max	.6133	.663	.4144	.3269	.4938	.6874	1.5364
Min	.0166	.0166	.0166	.0149	.0152	.0156	.0162
Avg	.1353	.1941	.1119	.0932	.1350	.1834	.5192

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 203 / 11 KV MANGLE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.016	.016	.016	.208	.2134	.2134	.0152
2	.016	.016	.016	.208	.2134	.2134	.0152
3	.016	.016	.016	.1783	.2134	.2134	.0152
4	.016	.016	.016	.1783	.2134	.2134	.0152
5	.016	.016	.016	.1932	.2134	.2134	.0152
6	.016	.016	.016	.2229	.2439	.2439	.0152
7	.016	.016	.016	.2526	.3048	.2743	.0152
8	.016	.016	.016	.0149	.0152	.0152	.0152
9	.5441	.2561		.0149	.0152	.0152	.5182
10	.4801	.2881		.0149	.0152	.0152	.5792
11	.4161	.2812		.0149	.0152	.0152	.5556
12		.2778		.0149	.0152	.0152	.5937
13	.3479	.2469	.2881	.0149	.0152	.0152	.6249
14	.3521	.2315	.2721	.0149	.0152	.0152	.6401
15	.3521	.2315	.2881	.0149	.0152	.0152	.6401
16	.3521	.2439	.2881	.0149	.0152	.0152	.7449
17	.016	.016	.016	.0149	.0152	.0152	.0162
18	.016	.016	.016	.0149	.0152	.0152	.0162
19	.016	.016	.016	.0149	.0152		.0162
20	.016	.016	.016	.0149	.0152	.0152	.0162
21	.016	.016	.016	.0149	.0152	.0152	.0162
22	.016		.192	.2107	.2134	.0152	.0162
23	.016	.016	.192	.2134	.2134	.0152	.0162
24	.016	.016	.016	.192	.2134	.2134	.0152
Max	.5441	.2881	.2881	.2526	.3048	.2743	.7449
Min	.016	.016	.016	.0149	.0152	.0152	.0152
Avg	.1348	.0999	.0872	.0944	.1029	.0881	.2145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 204 / 11 KV CHIKHALWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6009	.253	.2372	.0316	.064	.032	1.0159
2	.5851	.253	.2214	.0335	.064	.032	.9831
3	.6009	.2214	.253		.064	.032	.9717
4	.5851	.2214	.2846	.0339	.064	.032	.9667
5	.5693	.2214	.3163	.0678	.064	.032	.9393
6	.6009	.3163	.5693	.0678	.064	.032	1.1012
7	.8223	.5693	.6325	.0686	.032	.064	1.1984
8	.0633	.0316	.0316	.0693	.032	.0633	.0648
9	.0316	.0316	.0633	.7773	1.4403	1.6004	.0648
10	.0316	.0316	.0633	.9488	1.5043	1.8404	.0324
11		.0316	.0633	1.0437	1.5203	1.9109	.0324
12		.0316	.0633	1.1069	1.5364	1.9757	.0648
13	.0316	.0316	.0633	1.1843	1.4563	2.0729	.0648
14	.0316	.0316	.0633	1.1843	1.3763	1.6842	.0324
15	.0316	.0316	.0633	1.2163	1.4723	1.749	.0324
16	.0316	.0316	.0633	1.1843	1.5043	1.7328	.0648
17	.0316	.0316	.0633	.064	.064	.0648	.0648
18	.0316	.0316	.0633	.7522	.064	.0648	.0648
19	.0316	.0316	.0316	.064	.032	.0648	.0972
20	.0316	.0633	.0633	.064	.032	.0648	.0972
21	.0316	.0633	.0316	.064	.032	.0648	.0972
22	.3163	.3163	.0316	.064	.032	1.0688	1.166
23	.3163	.2846	.0316	.064	.032	1.1012	1.166
24	.6167	.3163	.253	.0316	.064	.032	1.0526
Max	.8223	.5693	.6325	1.2163	1.5364	2.0729	1.1984
Min	.0316	.0316	.0316	.0316	.032	.032	.0324
Avg	.2739	.1450	.1509	.4429	.5254	.7255	.4765

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 206 / 11 KV DHANTAKE WARANA

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.0497	.0503		.0537	.0537	.0537
3	.0497	.0503	.0572	.0537	.0537	.0537
4	.0497	.0503	.0572	.0537	.0537	.0537
5	.0503	.0503	.0572	.0537	.0537	.0537
6	.0503	.0503	.0572	.1254	.0537	.0537
7	.0503	.0503	.0572	.1254	.0537	.1254
8	.0503	.1006	.1294	.1254	.0537	.1254
9	.0503	.1174	.1254	.1254	.0537	.1254
10	.0503	.1174	.1254	.1433	.0514	.1254
11	.0838	.1174	.1267	.1433		.1791
12	.1174	.1174	.1267	.1433	.0537	.1791
13	.1174	.1174	.1267	.1433	.0537	.0537
14	.0503	.1174	.1267	.1254	.0537	
15	.1174	.1174	.1267	.1254	.0537	.0537
16	.1174	.1174	.1254	.1254	.0537	.1791
17	.1174	.1174	.1254	.1254	.0537	.1791
18	.1174	.1174	.1254	.1433	.0537	.1772
Max	.1174	.1174	.1294	.1433	.0537	.1791
Min	.0497	.0503	.0572	.0537	.0514	.0537
Avg	.0758	.0927	.1047	.1138	.0536	.1107

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244061 / 33/11 KV MANGLE S/S

Feeder No / Name : 401 / 33KV INGRUL KAPARI LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0572	.4973	.0572	.1475
2	.0572	.0572	.0572	.5967	.0572	.3887
3	.0572	.0572	.0572	.5967	.0572	.4024
4	.0572	.0572	.0572	.6036	.0572	.4973
5	.0572	.0572	.0572	.6036	.0572	.6036
6	.0572	.156	.631	.6036	.503	.6036
7	.5784	.4784	.631	.6036	.6104	.6104
8	.5784	.5784	.631	.6036	.6036	.6036
9	.5784	.5847	.631	.6104	.6173	.6104
10	.5847	.5316	.6379	.6539	.6687	.6104
11	.5847	.5847	.6379	.6613	.6687	.6687
12	.591	.6379	.6379		.6687	.6687
13	.591	.631	.6379		.6687	.6687
14		.631	.112		.6687	.6687
15		.6379			.6687	.6687
16		.6687		.0572	.2058	.0572
Max	.591	.6687	.6379	.6613	.6687	.6687
Min	.0572	.0572	.0572	.0572	.0572	.0572
Avg	.3408	.4004	.3910	.5576	.4274	.5299

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244098 / 33/11 KV KANDUR S/STN.

Feeder No / Name : 201 / 11 KV KANDUR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0434	.0316	.0293	.061	.0869	.0974	.0293
2	.0434	.0316	.0301	.0648	.0857	.0705	.0293
3	.044	.0316	.0293	.0648	.0846	.0705	.0278
4	.0429	.0305	.029	.0667	.088	.0846	.0278
5	.0423	.0305	.0282	.0812	.1014	.1113	.0278
6	.0412	.0267	.0278	.08	.1189	.1235	.029
7	.2172	.0474	.0412	.2027	.2286	.2143	.0434
8	.0434	.0301	.04		.029	.0316	.0423
9	.3281	.1562	.1947	.0312	.0297	.0301	.4321
10	.286	.1581	.1882	.0305	.0305	.0305	.4938
11	.2709	.16	.1858	.0312	.0267	.029	.5401
12		.16	.0714	.0293	.0263	.0293	.5401
13	.2229	.1562	.0724	.0282	.0263	.029	.4877
14	.2258	.1524	.1488	.029	.0286	.0293	.4877
15	.2258	.1423	.2143	.0282	.0305	.0434	.5247
16	.2258		.3227	.0282	.0446	.044	.503
17	.0297	.0417	.0434		.0429	.0417	.0229
18	.0286		.0434	.04	.029	.0423	.0267
19	.0316	.0434	.0316	.0457	.032	.0417	.0259
20		.044	.0312	.0429	.0316	.044	.0274
21	.0316	.0423	.0312	.0446	.0312	.0366	.0274
22	.032	.044	.1067	.1219	.1	.0293	.0332
23	.0305	.0293	.1027	.1189	.0947	.029	.0324
24	.0446	.0305	.029	.0709	.0892	.096	.0293
Max	.3281	.16	.3227	.2027	.2286	.2143	.5401
Min	.0286	.0267	.0278	.0282	.0263	.029	.0229
Avg	.1151	.0737	.0864	.0610	.0632	.0595	.1871

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244098 / 33/11 KV KANDUR S/STN.

Feeder No / Name : 202 / 11 KV PUNVAT GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.0924	.1307	.112	.112	.1132	.112
2	.112	.0924	.1307	.112	.112	.112	.112
3	.112	.0924	.1307	.112	.112	.112	.112
4	.112	.1109	.1307	.112	.112	.1307	.1494
5	.128	.1109	.1463	.1307	.1307	.1509	.1829
6	.181	.1848	.1791	.1867	.1848	.168	.181
7	.2686	.2218	.2149	.2402	.2218	.1848	.2172
8	.2328	.2172	.2149		.2328	.2012	.2149
9	.2172	.1991	.1791	.1829	.2149	.197	.1772
10	.1949	.181	.181	.181	.181	.1791	.1791
11	.1772	.181	.1791	.1715	.1543	.1417	.156
12		.1612	.1254	.1006	.1341	.1029	.1387
13	.1187	.1595	.1227	.0829	.0829	.1029	.104
14	.1187	.1612	.1402	.0829	.1147	.1214	.1214
15	.1509	.1595	.1543	.1492	.1296	.1402	.116
16	.1715	.1629	.1509	.1526	.1475	.1402	.192
17	.1753	.1629	.1543	.1907	.1802	.1753	.2031
18	.1949		.1402	.1677	.2328	.1949	.1781
19	.3045	.2195	.2172	.2378	.2561	.2658	.2507
20	.3292	.2743	.2772	.2926	.2772	.2926	.2561
21	.1848	.2561	.2427	.2378	.2427	.2353	.2587
22	.2587	.2195	.1867	.2033	.1867	.2218	.2033
23	.1848	.1867	.1478	.1663	.1509	.1867	.1848
24	.1294	.1478	.1494	.1109	.1307	.132	.1307
Max	.3292	.2743	.2772	.2926	.2772	.2926	.2587
Min	.112	.0924	.1227	.0829	.0829	.1029	.104
Avg	.1813	.1720	.1678	.1616	.1681	.1668	.1721

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244098 / 33/11 KV KANDUR S/STN.

Feeder No / Name : 203 / 11 KV SAGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0934	.1307	.1132	.112	.1132	.112
2	.0943	.0934	.1307	.1132	.1132	.1132	.112
3	.0943	.0934	.1307	.1132	.1132	.1132	.112
4	.0943	.112	.1494	.132	.1132	.112	.1494
5	.1132	.1307	.1829	.1494	.1132	.1509	.181
6	.1219	.1886	.2012	.1867	.1867	.1698	.1991
7	.2587	.2427	.2172	.2402	.2241	.2218	.2149
8	.2534	.2218	.2149		.1829	.2033	.2149
9	.2172	.2012	.1991	.1829	.1949	.197	.1991
10	.1791	.181	.1949	.1646	.1907	.1791	.1543
11	.1578	.181	.1753	.1734	.1715	.1646	.1658
12	.1753	.181	.1753	.1543	.1715	.1578	.1696
13	.1578	.181	.1595	.1543	.1543	.1543	.1526
14	.1578	.1612	.128	.1341	.1509	.1402	.1543
15	.1402	.1612	.124	.1509	.16	.1372	.1526
16	.1753	.181		.1543	.1475	.1578	.176
17	.1433	.0732	.1543	.1595	.1457	.1595	.1638
18	.1772	.0549	.1578	.1966	.1734	.1772	.1823
19	.2561	.2926	.2507	.2865	.2507	.2686	.2507
20	.2772	.2957	.2896	.2896	.2896	.2896	.2743
21	.2772	.2772	.2772	.2561	.2772	.2378	.2402
22	.2587	.2402	.2054	.2054	.2427	.2033	.2241
23	.1848	.1867	.168	.1478	.1509	.1867	.1867
24	.112	.1307	.1307	.1132	.112	.132	.1307
Max	.2772	.2957	.2896	.2896	.2896	.2896	.2743
Min	.0943	.0549	.124	.1132	.112	.112	.112
Avg	.1738	.1732	.1803	.1727	.1726	.1725	.1780

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244110 / 33/11 MIDC SHIRALA

Feeder No / Name : 201 / 11 KV KARMALA AG

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1075	.1433	.132	.2256	.3353	.3353	.0754
2	.1097	.1097	.132	.2378	.3395	.3086	.0754
3	.1109	.1086	.132	.2408	.3437	.3048	.0754
4	.1494	.1097	.132	.2709	.3749	.3048	.1132
5	.1886	.0991	.132	.301	.4687	.3506	.1509
6	.1886	.1829	.1698	.381	.6325	.463	.2075
7	.2572	.2561	.3018	.4877	.8065	.7926	.2641
8	.2772	.2561	.2263	.2241	.2427	.2561	.2195
9	.9488		.3749	.168	.1867	.1646	1.3283
10	.9907	.6554	.7499	.1494	.168	.1646	1.5546
11	1.034	.6554	.7811	.1463	.128	.1463	1.5223
12	1.0059	.6554	.7811	.1463	.1478	.1463	1.587
13	.6097	.6554	.7186	.1448	.1463	.1097	1.5524
14	.4321	.6554	.5864	.1433	.1463	.0924	1.4883
15	.4268	.6554	.6173	.1433	.1646	.1463	1.5684
16	.5792	.4588	.6097	.124	.1478	.1646	1.4723
17	.1829	.1886	.1829	.1463	.0732	.168	.181
18	.2149	.2263	.2263	.1867	.1848	.168	.1791
19	.2481	.3018	.2829	.2801	.2195	.2241	.2801
20	.2629	.3018	.2829	.2801	.2772	.2801	.2957
21	.2658	.2641	.2801	.2801	.2561	.2614	.2641
22	.2149	.2263	.2709	.4374	.3864	.2263	.2263
23	.1463	.1886	.2462	.3963	.3612	.1509	.168
24	.1086	.1448	.1509	.2225	.3658	.3658	.1132
Max	1.034	.6554	.7811	.4877	.8065	.7926	1.587
Min	.1075	.0991	.132	.124	.0732	.0924	.0754
Avg	.3775	.3260	.3542	.2402	.2876	.2540	.6234

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244110 / 33/11 MIDC SHIRALA

Feeder No / Name : 202 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	03-SEP-17
HR	Load (MW)
8	.061
Max	.061
Min	.061
Avg	.061

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244110 / 33/11 MIDC SHIRALA

Feeder No / Name : 203 / 11 KV PADALIWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0159	.4062	.3048	.061	.0452	.0463	.6249
2	1.0059	.4111	.3048	.0594	.0452	.0463	.5937
3	.9175	.4062	.3048	.0594	.0452	.0457	.5624
4	.8745	.4111	.3048	.0579	.0452	.0457	.5556
5	.852	.4111	.4268	.0714	.0602	.0457	.5864
6	.7907	.4111	.3353	.0714	.0602	.061	.6173
7	.8539	.5218	.4843	.0724	.0903	.0914	.7099
8	.0791	.0633	.0686	.0594	.0753		.0617
9	.0791	.0412	.0667	.5117	.7676	.7926	.0772
10	.0625	.04	.0469	.5639	.8535	.8535	.0463
11	.0474	.04	.0469	.5487	.8535	.8951	.0463
12	.0469	.04	.0469	.5335	.7099	.8951	.0463
13	.0474	.04	.0469	.5487	.7468	.9374	.0617
14	.0457	.04	.0469	.5792	.7621	.9374	
15	.061	.04	.0625	.5719	.6554	.9374	.0463
16	.061	.04	.0625	.5719	.7621	.9686	.0463
17	.0914	.0533	.0625	.0602	.0617	.0617	.0617
18	.0791	.0533	.0625	.0602	.061	.0772	.0772
19	.0625	.0533	.0625	.0753	.0625	.0772	.0617
20	.0791	.0533	.0625	.0753	.061	.0772	.0617
21	.0633	.0533	.0625	.0602	.061	.0781	.0617
22	.4161	.3201	.0625	.0602	.0463	.6874	.6636
23	.4111	.3521	.0469	.0452	.0457	.6562	.679
24	1.0608	.4111	.3201	.0625	.0452	.0457	.6249
Max	1.0608	.5218	.4843	.5792	.8535	.9686	.7099
Min	.0457	.04	.0469	.0452	.0452	.0457	.0463
Avg	.3793	.1964	.1543	.2267	.2926	.4070	.3032

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244110 / 33/11 MIDC SHIRALA

Feeder No / Name : 204 / 11 KV MIDC NEW

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.5281	.3961	.4715	.415	.415	.5658
2	.3772	.5281	.3961	.4527	.415	.415	.5658
3	.3395	.5658	.3961	.3772	.4527	.3206	.5281
4	.3395	.5658	.3961	.3018	.3772	.2641	.3772
5	.3395	.5847	.3961	.3018	.3395	.2641	.3395
6	.3395	.6036	.415	.3206	.3584	.2829	.3206
7	.3772	.6413	.3772	.3206	.3206	.3018	.3395
8	.2829	.3206	.415	.3206	.3395	.2829	.3395
9	.3018	.8676	.5281	.4715	.547	.415	.4527
10	.3961	.8676	.9054	.8676	1.0185	.9054	1.0669
11	.5093	.8676	1.1694	1.2449	1.3392	1.2449	1.2765
12	.5281	.8676	1.1694	1.2637	1.3392	1.2449	.9717
13	.5658	.9808	1.1317	1.1694	1.2826	1.0387	1.2003
14	.6224	.9808	.8676	.9619	1.0751	.9619	.9717
15	.5281	.9808	.9054	1.3203	1.0185	1.0562	.9717
16	.6036	1.3392	.9808	1.3392	1.1506	1.094	1.2193
17	.5093	1.1317	1.0562	1.2826	1.0185	.9054	1.1431
18	.415	1.1317	.9808	1.2071	.9431	.4904	.4001
19	.3961	.8676	.8676	.9431	.8299	.4904	.9335
20	.3772	.4527	.7167	.7167	.415	.5281	.7621
21	.4715	.5658	.5281	.5093	.5658	.547	.4763
22	.4527	.4904	.4904	.4904	.547	.5281	.4382
23	.4527	.4527	.3772	.4527	.547	.5658	.4001
24	.415	.5281	.415	.4715	.415	.547	.5658
Max	.6224	1.3392	1.1694	1.3392	1.3392	1.2449	1.2765
Min	.2829	.3206	.3772	.3018	.3206	.2641	.3206
Avg	.4299	.7379	.6782	.7324	.7112	.6296	.6928

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244121 / 33/11 KV BILASHI

Feeder No / Name : 201 / 11 KV MANGRUL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0301	.0297	.0297	.0149	.0152	.0152	.0149
2	.0301	.0297	.0297	.0149	.0152	.0152	.0149
3	.0301	.0297	.0297	.0149	.0152	.0152	.0149
4	.0301	.0297	.0297	.0149	.0152	.0152	.0149
5	.0301	.0297	.0297	.0149	.0154	.0152	.0149
6	.0452	.0297	.0297	.0149	.0154	.0149	.0152
7	.0602	.0594	.0297	.0168	.0154	.0149	.0149
8	.0151	.0149	.0152	.0152	.0154	.0149	.0152
9	.0149	.0149	.0149	.0305	.0457	.0446	.0152
10	.0149	.0149	.0297	.0305	.0305	.0149	.0152
11	.0149	.0149	.0149	.0305	.0152	.0149	.0152
12	.0149	.0149	.0149	.0309	.0152	.0446	.0152
13	.0149	.0149	.0149	.0305	.0152	.0297	.0152
14	.0149	.0149	.0149	.0152	.0305	.0297	.0152
15	.0149	.0149	.0149	.0305	.0305	.0297	.0152
16	.0149	.0149	.0149	.0305	.0305	.0446	.0152
17	.0149	.0149	.0149	.0151	.0152	.0149	.0152
18	.0149	.0149	.0149	.0151	.0152	.0149	.0152
19	.0149	.0149	.0149	.0152	.0152	.0149	.0152
20	.0149	.0149	.0149	.0151	.0152	.0156	.0152
21	.0149	.0149	.0149	.0152	.0152	.0156	.0152
22	.0149	.0149	.0149	.0152	.0152	.0312	.0305
23	.0297	.0297	.0149	.0152	.0152	.0305	.0305
24	.0301	.0297	.0297	.0149	.0152	.0152	.0297
Max	.0602	.0594	.0297	.0309	.0457	.0446	.0305
Min	.0149	.0149	.0149	.0149	.0152	.0149	.0149
Avg	.0225	.0217	.0205	.0196	.0191	.0219	.0170

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244121 / 33/11 KV BILASHI

Feeder No / Name : 202 / 11 KV KOKARUD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0086	.0086	.0086	.0086	.004	.0046	.0048
2	.0086	.0086	.0086	.0086	.004	.0046	.0048
3	.0086	.0086	.0086	.0086	.004	.0046	.0048
4	.0086	.0086	.0086	.0086	.004	.0046	.0048
5	.0086	.0086	.0086	.0086	.004	.0046	.0048
6	.0086	.0088	.0086	.0086	.0042	.0046	.0048
7	.0086	.0086	.0086	.0086	.0042	.0046	.0048
8	.0086	.0086	.0086	.004	.0042	.0046	.0067
9	.0175	.0086	.0086	.004	.0086	.0046	.0067
10	.0088	.0086	.0086	.004	.0086	.0046	.0133
11	.0088	.0086	.0076	.004	.0086	.0046	.0133
12	.0088	.0086	.0177	.004	.0086	.0046	.0133
13	.0088	.0086	.0086	.004	.0086	.0046	.0133
14	.0088	.0086	.0086	.004	.0086	.0046	.0133
15	.0088	.0086	.0086	.004	.0086	.0046	.0133
16	.0088	.0086	.0086	.004	.0086	.0046	.0133
17	.0088	.0086	.0086	.0042	.0086	.0046	.0067
18	.0088	.0086	.0086	.0042	.0086	.0046	.0067
19	.0088	.0086	.0086	.0042	.0086	.0046	.0067
20	.0088	.0086	.0086	.0042	.0086	.0046	.0067
21	.0088	.0086	.0086	.0046	.0057	.0046	.0067
22	.0086	.0086	.0086	.0048	.0057	.0046	.0067
23	.0086	.0086	.0086	.0044	.0057	.0048	.0067
24	.0086	.0086	.0086	.0086	.004	.0057	.0048
Max	.0175	.0088	.0177	.0086	.0086	.0057	.0133
Min	.0086	.0086	.0076	.004	.004	.0046	.0048
Avg	.0091	.0086	.0089	.0056	.0065	.0047	.0080

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

ISLAMPUR DIVISION[521]

SHIRALA[075]

BU 6238

Substation No/ Name :- 244121 / 33/11 KV BILASHI

Feeder No / Name : 203 / 11 KV KOKARUD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2481	.2481	.2835	.2126	.2481	.2658	.2658
2	.2481	.2481	.2658	.2126	.2481	.2481	.2481
3	.2303	.2481	.2658	.2126	.2303	.2481	.2481
4	.2481	.2303	.2481	.2126	.2481	.2481	.2481
5	.3366	.3189	.3012	.2658	.3189	.3366	.3544
6	.4075	.4607	.4252	.3544	.3898	.4252	.4252
7	.567	.4961	.4961	.5068	.567	.5138	.5493
8	.6201	.567	.567	.5249	.567	.5316	.5493
9	.5493	.4784	.5316	.4163	.4961	.4961	.5138
10	.4607	.4607	.4961	.4344	.4075	.443	.5138
11	.4252	.3898	.4607	.4163	.4252	.4252	.443
12	.443	.3544	.443	.362	.3898	.3898	.4252
13	.4075	.3366	.4252	.3801	.3544	.3544	.3544
14	.3544	.3012	.3898	.3224	.3544	.3721	.3544
15	.3189	.3898	.3544	.3403	.3544	.3544	.3189
16	.3898	.3189	.3721	.3582	.3366	.3544	.3898
17	.3898	.4607	.3544	.4252	.3898	.4252	.4961
18	.4784	.4607	.4252	.4784	.5316	.5138	.4607
19	.6379	.6379	.6024	.6733	.6556	.691	.6733
20	.6556	.6733	.6733	.7087	.6733	.6379	.6733
21	.6379	.6379	.6024	.5847	.6024	.6024	.6201
22	.5493	.5493	.5316	.5138	.4961	.5316	.443
23	.4607	.443	.3544	.3721	.3898	.3721	.3721
24	.2481	.2835	.3012	.2481	.2481	.2658	.2658
Max	.6556	.6733	.6733	.7087	.6733	.691	.6733
Min	.2303	.2303	.2481	.2126	.2303	.2481	.2481
Avg	.4297	.4164	.4238	.3974	.4134	.4186	.4253

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 201 / 11 KV Dafalapur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.462	.4917	.6401	.4915	.2801	.3018	.2987
2	.4572	.4239	.6401	.4973	.2801	.3018	.2987
3	.4572	.4239	.6401	.4915	.2801	.3018	.2987
4	.4525	.5041	.823	.4915	.3174	.3961	.3547
5	.6154	.5087	.9511	.5735	.4108	.4904	.4481
6	.8775	.8886	1.2071	.7773	.6722	.6413	.6722
7	1.4706	1.5249	1.6095	.9945	.7577	.7167	.7095
8	.5853	.5975	.5847	.4534	.5415	.5281	.5415
9	.3841		.5093	.8356	1.073	1.262	.3361
10	.3174	.3206	.2915	.8684	1.1523	1.2071	.2801
11	.2987	.2641	.2458	.8215	1.134	1.073	.1966
12	.2427	.2263	.213	.7545	.9877	1.0227	.1943
13	.2614	.2452	.1781	.6203	.8962	.9724	.1989
14	.2241	.2641	.213	.6706	.9877	.8886	.1638
15	.2054	.2641	.2458	.7377	1.0242	.9556	.213
16	.2614	.2452	.2294	.7712	.9145	.9556	.213
17	.2614	.2829	.2294	.3361	.3395	.2801	.3277
18	.3547	.3584	.2458	.3734	.3961	.3361	.3113
19	.5415	.4338		.5415	.4527	.5415	.4096
20	.5041	.4715		.5415	.5281	.5601	.4801
21	.4294	.4527	.426	.4668	.4904	.4854	.3932
22	.6443	.8596	.4096	.3547	.3772	.3921	.8356
23	.5426	.823	.5079	.2987	.3395	.2987	.6062
24	.439	.4917	.7316	.4752	.2801	.3395	.2987
Max	1.4706	1.5249	1.6095	.9945	1.1523	1.262	.8356
Min	.2054	.2263	.1781	.2987	.2801	.2801	.1638
Avg	.4704	.4942	.5351	.5933	.6214	.6354	.3783

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 202 / 11 KV Baj AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6767	.7122	.7316	.6554	.2614	.2263	.2801
2	.6767	.7122	.7316	.6478	.2614	.2263	.2801
3	.6767	.7122	.7316	.6554	.2614	.2263	.2801
4	.6697	.7461	.9145	.6783	.2987	.3018	.3174
5	.985	.78	1.0974	.7865	.3734	.3961	.3734
6	1.5415	1.1233	1.3169	.9339	.5601	.547	.5415
7	1.9669	2.0719	2.1399	1.4243	.5601	.5658	.5975
8	.439	.4481	.3584	.3401	.4481	.4338	.4481
9	.2587		.2263	1.1012	1.4083	1.5546	.3547
10	.2427	.1698	.1966	1.2289	1.5546	1.4449	.2801
11	.1867	.1886	.2035	1.2742	1.5181	1.5089	.213
12	.2054	.2075	.1966	1.1736	1.3169	1.5089	.213
13	.1494	.2641	.1802	1.1736	1.2803	1.4754	.4424
14	.168	.2075	.1802	1.2071	1.3169	1.4586	.213
15	.168	.1698	.2155	1.3748	1.4815	1.6263	.2105
16	.1867	.1886	.1966	1.3748	1.4449	1.6598	.213
17	.2241	.1886	.1943	.2801	.3018	.2241	.4144
18	.2987	.3018	.2458	.2801	.3395	.2987	.3277
19	.4294	.3961		.3921	.3961	.4294	.426
20	.3734	.4338		.3921	.4338	.4668	.3887
21	.3734	.3772	.3441	.3921	.3395	.3734	.3077
22	.8139	.9511	.7373	.2987	.3018	.3361	1.2125
23	.763	.9145	.7045	.2801	.2452	.2987	.8684
24	.6584	.7122	.823	.6226	.2614	.2452	.2801
Max	1.9669	2.0719	2.1399	1.4243	1.5546	1.6598	1.2125
Min	.1494	.1698	.1802	.2801	.2452	.2241	.2105
Avg	.5472	.5642	.5757	.7903	.7069	.7431	.3951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 203 / 11KV Mirwad AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1494	.1509	.1638	.8718	.823	.8551
2	.1848	.1494	.1509	.1619	.8718	.823	.8551
3	.1848	.1494	.1509	.1638	.8718	.823	.8551
4	.1867	.168	.1886	.1966	.9221	.9145	.8886
5	.2587	.2054	.2263	.2486	1.0395	1.1888	.9221
6	.3326	.3361	.3206	.2721	1.5089	1.4998	1.3245
7	.4066	.3921	.3961	.3401	2.0388	2.268	1.6244
8	.3326	.3547	.3206	.2785	.3361	.3206	.3361
9	1.2795		1.4632	.1823	.2241	.2263	1.7101
10	1.3245	1.4632	1.4251	.1311	.1698	.1886	1.643
11	1.2071	1.4266	1.491	.112	.1698	.168	1.491
12	1.2574	1.4083	1.4575	.1307	.1509	.168	1.3426
13	1.0898	1.4083	1.3923	.112	.1509	.1494	1.4737
14	.8718	1.3535	1.3426	.112	.1509	.1494	1.3927
15	1.0059	1.4632	1.4413	.1494	.1509	.1307	1.4089
16	1.1065	1.4449	1.3927	.1307	.1698	.1494	.852
17	.112	.2263	.1475	.1494	.1698	.1494	.1638
18	.1867	.2263	.1638	.1867	.2075	.1867	.2054
19	.3174	.2263		.2614	.2829	.3547	.3441
20	.2987	.2641		.2987	.3206	.3361	.3391
21	.2614	.2452	.2785	.2614	.2641	.2801	.213
22	.1867	.2075		1.0898	1.2071	1.073	.213
23	.168	.1886	.2458	1.0395	1.0974	.9389	.1638
24	.168	.168	.1698	.1638	.9054	.9145	.8886
Max	1.3245	1.4632	1.491	1.0898	2.0388	2.268	1.7101
Min	.112	.1494	.1475	.112	.1509	.1307	.1638
Avg	.5381	.5924	.6817	.2640	.5939	.5927	.8961

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 204 / 11 Kv Baj Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0934	.1132	.1132	.0934	.0943	.0934
2	.0943	.0934	.1132	.1097	.0934	.0943	.0934
3	.0934	.0934	.1132	.1097	.0934	.0943	.0934
4	.0934	.0934	.132	.112	.0934	.1132	.0934
5	.1307	.112	.1698	.112	.1307	.1509	.112
6	.1848	.168	.2075	.1307	.2054	.1698	.2054
7	.2402	.2241	.2452	.168	.2241	.2263	.2427
8	.2033	.1867	.1886	.1294	.168	.1886	.168
9	.112		.132	.112	.1494	.1509	.1307
10	.1307	.1132	.1132	.112	.0943	.132	.1307
11	.0934	.0943	.0934	.0747	.0943	.112	.132
12	.112	.0754	.0819		.0754	.112	.1097
13	.0934	.0754	.132	.112	.0754	.112	.1097
14	.0747	.0943	.0934	.112	.0754	.0747	.0983
15	.056	.0943	.1509	.0934	.0754	.0747	.1147
16	.112	.0754	.1134	.0934	.0943	.0934	.1147
17	.1494	.1132	.112	.1307	.1132	.112	.132
18	.1867	.1509	.0983	.168	.1509	.168	.132
19	.2241	.2263		.2241	.1886	.2241	.1698
20	.1867	.2452		.2241	.2452	.2614	.1848
21	.168	.1886	.1698	.1867	.1698	.1867	.2075
22	.112	.1509	.1311	.112	.132	.1307	.1698
23	.0934	.132	.132	.0934	.1132	.0934	.1509
24	.0943	.0934	.132	.1132	.0934	.1132	.0934
Max	.2402	.2452	.2452	.2241	.2452	.2614	.2427
Min	.056	.0754	.0819	.0747	.0754	.0747	.0934
Avg	.1306	.1299	.1349	.1281	.1268	.1368	.1368

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 205 / 11 KV Dafalapur GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0934	.1132	.1132	.112	.1132	.112
2	.0943	.0934	.1132	.112	.112	.1132	.112
3	.0943	.0934	.1132	.1097	.112	.1132	.112
4	.0943	.0934	.132	.112	.112	.132	.112
5	.112	.112	.132	.0983	.1307	.1509	.112
6	.1307	.1307	.132	.1294	.1494	.1698	.1494
7	.1307	.168	.1509	.1848	.1307	.1698	.1307
8	.112	.1494	.132	.128	.0934	.132	.1307
9	.0943		.1132	.112	.112	.1132	.0934
10	.112	.1509	.1006	.1132	.132	.1132	.112
11	.112	.1509	.0943	.112	.132	.1307	.132
12	.112	.1509	.0943	.1494	.1132	.112	.1132
13	.0934	.1698		.168	.1132	.112	.112
14	.0934	.1132	.0819	.1494	.1132	.1307	.1132
15	.0934	.0943	.1509	.1307	.1132	.1307	.132
16	.112	.1132	.132	.1494	.1509	.1494	.132
17	.112	.132	.1097	.1494	.1509	.1494	.1307
18	.1494	.1509	.1097	.1494	.1509	.1494	.1307
19	.168	.1698		.2054	.1509	.2427	.1698
20	.1867	.2075		.2241	.2452	.2054	.2075
21	.1867	.1509	.1698	.1867	.1886	.2054	.2075
22	.168	.1886	.1509	.1867	.1886	.1867	.1698
23	.1494	.1509	.1509	.1494	.1698	.1494	.1463
24	.0943	.0934	.132	.1132	.1307	.1509	.112
Max	.1867	.2075	.1698	.2241	.2452	.2427	.2075
Min	.0934	.0934	.0819	.0983	.0934	.112	.0934
Avg	.1208	.1357	.1242	.1432	.1378	.1469	.1327

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244022 / 33/11 KV DAFALAPUR

Feeder No / Name : 206 / 11 KV ANKALE DORLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587	.2427	.2452	.2429	.9724	.823	.8718
2	.2614	.2427	.2452	.2458	.9724	.823	.8718
3	.2587	.2427	.2452	.2458	.9724	.8413	.8718
4	.2614	.2427	.3584	.2458	1.0227	.9145	.8886
5	.3841	.2801	.415	.3239	1.1568	1.2437	.9054
6	.4938	.4481	.5847	.4049	1.6095	1.7741	1.3077
7	.6401	.6722	.679	.502	2.1714	2.5606	1.5912
8	.5121	.5415	.415	.4475	.4668	.5281	.5228
9	1.0631		1.3169	.3353	.4481	.5093	1.9393
10	1.291	1.4998	1.5238	.2949	.3772	.3961	1.9227
11	1.4419	1.4632	1.6876	.2801	.3395	.3734	1.6907
12	1.1736	1.4815	1.6221	.2427	.3395	.3361	1.9433
13	1.1736	1.6827		.2614	.3395	.3361	1.5565
14	1.291	1.6095	1.7204	.2614	.3395	.2987	1.8187
15	1.3916	1.5364	1.7814	.2241	.3395	.3547	1.9989
16	1.1401	1.0608	1.5223	.2241	.3584	.3361	1.6549
17	.2427	.2452	.2458	.2801	.3772	.3361	.4144
18	.2987	.3584	.2785	.3921	.415	.3921	.373
19	.4481	.4527		.5041	.4904	.5601	.4096
20	.3734	.4904		.5228	.5093	.5788	.4144
21	.3734	.3961	.3563	.4481	.4338	.4668	.3812
22	.2801	.3018	.3277	1.2239	1.2803	1.2071	.2713
23	.2427	.2829	.213	1.073	1.0974	1.0059	.2591
24	.2402	.2427	.2641	.213	.9724	.9145	.9389
Max	1.4419	1.6827	1.7814	1.2239	2.1714	2.5606	1.9989
Min	.2402	.2427	.213	.213	.3395	.2987	.2591
Avg	.6473	.6964	.7642	.3933	.7417	.7463	1.0758

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 201 / 11 KV Billur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1357	.1357	.0709			
2		.1187	.1357	.0867			
3		.1187	.1357	.0701			
4		.1357	.1357	.0876			
5		.1696	.1696	.0876			
6		.2543	.2543	.0701			
7		.3052	.2883	.333			
8		.2543	.2543	.2279			
9	1.0288	1.1603	1.1603	.1772		.1524	1.3375
10	1.0288	1.1603	1.1603	.1734			1.1603
11	.9945	1.0774	.9945	.156		.1658	1.1603
12	.4973	.9945	.9717	.1734	.061		1.1603
13	.7459	.9945	1.1145	.1753			1.1603
14	.8288	.9116	1.0774	.12		.125	1.1603
15	.9116	.8288	1.166	.1387	.061		.9945
16	.8288	.9945	.9831	.0886	.061	.125	.9945
17	.1357	.1696	.0876	.1063			.1658
18	.1696	.3052	.1402	.1772	.061		.1989
19	.2035	.3052	.2303	.2629		.1524	.2486
20	.2543	.3052	.1928	.3429			.2486
21	.2543	.2543	.1734	.2572	.1524	.2286	.2035
22	.2035	.2035	.1063	1.1603	1.0974	1.0288	.2035
23	.1696	.1696	.0876	1.1437			.1696
24	.1524	.1696	.1696	.0876		1.166	1.166
Max	1.0288	1.1603	1.166	1.1603	1.0974	1.166	1.3375
Min	.1357	.1187	.0876	.0701	.061	.125	.1658
Avg	.5255	.4790	.4719	.2406	.2490	.393	.7333

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 202 / 11kv salmalgewadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8288	1.1603	1.3146			
2		.8288	1.21	1.3226			
3		.9116	1.1603	1.3717			
4		1.1105	1.2431	1.6575			
5		1.326	1.326	1.8004			
6		1.4918	1.8233	1.8233			
7		2.4863	2.652	2.1548			
8		.4239	.4239	.1715			
9	1.0059	1.1603	1.326	1.9071			1.4243
10	1.0288	1.1603	1.326	1.989			1.4918
11	.9945	1.1603	1.2431	1.8861		2.2291	1.4089
12	.663	1.1603	1.2431	1.8861	2.4006		1.4089
13	.8288	1.1603	1.3717	1.8652			1.326
14	.9116	.9945	1.3717	1.5261		2.2291	1.326
15	.8288	.9945	1.4575	1.8233	2.4006		1.1603
16	.8288	1.1603	1.5432	1.989	2.4006	2.4006	1.2431
17	.2035	.2035	.1772	.2629			.2204
18	.2543	.2543	.2454	.2629	.2683		.3052
19	.3391	.4239	.3544	.3544		.3353	.407
20	.3696	.4239	.3681	.4382			.4239
21	.3052	.3391	.3506	.3506	.3353	.2286	.3391
22	1.0774	1.4089	1.3717	1.0288	1.166	1.0974	1.6575
23	.9945	1.326	1.3523	1.0288			1.5912
24	.7545	.9116	1.326	1.2887		1.0288	1.0288
Max	1.0774	2.4863	2.652	2.1548	2.4006	2.4006	1.6575
Min	.2035	.2035	.1772	.1715	.2683	.2286	.2204
Avg	.7118	.9854	1.1428	1.3127	1.4952	1.3641	1.0477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 203 / 11 KV Wajrawad ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8288	.7459	.8745			
2		.7459	.663	.8987			
3		.7459	.663	.9116			
4		.8288	.7459	.9831			
5		.9945	.9945	1.278			
6		1.326	1.2431	1.3426			
7		1.989	1.8233	1.2163			
8		.3391	.3391	.0876			
9	.3048	.2543	.2543	1.2378		.6516	.2372
10	.1677	.1696	.1696	1.2174			.1696
11	.1357	.1357	.1227	1.0277		.5487	.1357
12	.1357	.1187	.0876	.8573	.5487		.1187
13	.1187	.1017	.1052	.9465			.1187
14	.1187	.1017	.1052	.9448		1.166	.1187
15	.1187	.1017	.0876	1.0774	1.166		.1187
16	.1187	.1187	.0701	.9842	1.0288	1.3032	.1187
17	.1357	.1696	.0701	.1753			.1696
18	.1696	.2374	.1753	.1949	.1524		.2035
19	.2543	.3391	.3681	.2629		.3429	.2543
20	.3391	.3391	.333	.4207			.3391
21	.3391	.3391	.2629	.298	.3086	.2572	.3052
22	.9945	.9945	.9431	.2572	.2743	.2572	.9116
23	.9116	.9116	.8916	.2454			.8288
24		.8288	.8288	.8573		.2058	.2515
Max	.9945	1.989	1.8233	1.3426	1.166	1.3032	.9116
Min	.1187	.1017	.0701	.0876	.1524	.2058	.1187
Avg	.2908	.5441	.5039	.7749	.5798	.5916	.2750

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 204 / 11 Kv Billur Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0924	.0924	.0526			
2		.0739	.0739	.052			
3		.0739	.0739	.052			
4		.0924	.0739	.0709			
5		.1294	.1109	.0876			
6		.1663	.1478	.1063			
7		.1848	.1848	.1227			
8		.1478	.1478	.0886			
9	.0886	.1109	.1109	.0693		.0914	.0716
10	.0716	.1109	.1109	.0709			.0739
11	.0739	.0924	.0867	.0526		.0857	.0739
12	.0739	.0924	.0701	.0347	.0876		.0739
13	.0739	.0739	.0709	.0532			.0739
14	.0739	.0739	.0701	.0543		.0709	.0739
15	.0739	.0739	.0693	.0532	.0686		.0739
16	.0739	.0829	.0526	.0905	.0701	.0709	.0739
17	.0924	.1109	.0709	.0886			.0924
18	.1109	.1478	.1063	.1063	.0895		.1478
19	.1478	.1848	.124	.1227		.1463	.1663
20	.1848	.1848	.1052	.124			.1848
21	.1848	.1848	.0886	.0867	.1267	.1372	.1848
22	.1294	.1478	.0526	.0693	.1267	.1463	.1294
23	.1109	.1109	.0701	.0693			.1109
24	.0895	.1109	.1109	.0514		.0905	.0876
Max	.1848	.1848	.1848	.124	.1267	.1463	.1848
Min	.0716	.0739	.0526	.0347	.0686	.0709	.0716
Avg	.1034	.1190	.0948	.0762	.0949	.1049	.1058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 205 / 11 kv Wajrwad Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1478	.1478	.1052			
2		.1294	.1294	.124			
3		.1294	.1294	.1227			
4		.1294	.1294	.1417			
5		.1848	.1848	.1734			
6		.2402	.2218	.2058			
7		.2772	.2772	.2454			
8		.2218	.2218	.1715			
9	.2058	.1848	.1848	.1372		.2149	.2401
10	.1772	.1848	.1848	.1372			.1848
11	.1294	.1478	.1772	.1063		.2058	.1478
12	.1294	.1478	.1402	.0886	.1562		.1478
13	.1294	.2151	.1227	.1052			.1478
14	.1294	.1294	.1402	.104		.1254	.1294
15	.1294	.1294	.1402	.104	.1791		.1294
16	.1294	.1326	.1227	.1772	.1772	.12	.1294
17	.1478	.1848	.1417	.1772			.1848
18	.1848	.2218	.2103	.2103	.2058		.2218
19	.2402	.2772	.2454	.2279		.1989	.3326
20	.2772	.2772	.2103	.2658			.2772
21	.2772	.2772	.1753	.1734	.1772	.3506	.2587
22	.2218	.2218	.1052	.1387	.1715	.3048	.1848
23	.1848	.1848	.1227	.1417			.1848
24	.1402	.1848	.1848	.1909		.1402	.1715
Max	.2772	.2772	.2772	.2658	.2058	.3506	.3326
Min	.1294	.1294	.1052	.0886	.1562	.12	.1294
Avg	.1771	.1901	.1688	.1573	.1778	.2076	.1920

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244031 / 33/11 KV BILLUR S/STN

Feeder No / Name : 206 / 11 kv Gugwad AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0339	.0339	.0351			
2		.017	.0339	.0351			
3		.0339	.0339	.0354			
4		.0034	.0339	.0358			
5		.0339	.0339	.0358			
6		.0339	.0339	.0354			
7		.0509	.0509	.0354			
8		.0339	.0339	.0347			
9	.1638	.2486	.2543	.0351		.0305	.3429
10	.2601	.2035	.2035	.0354			.3391
11	.1696	.1696	.1753	.0354		.0305	.3052
12	.1696	.2486	.1753	.0354	.0343		.2543
13	.1357	.1696	.1578	.0354			.2035
14	.0848	.2035	.1646	.0354		.0305	.2035
15	.1696	.2035	.1402	.0351	.0305		.1696
16	.1696	.1696	.1227	.0358	.0305	.0343	.2543
17	.0339	.0339	.0351	.0354			.0339
18	.0339	.0339	.0351	.0351	.0305		.0339
19	.0339	.0339	.0351	.0354		.0457	.0339
20	.0509	.0509	.0351	.0351			.0509
21	.0509	.0339	.0351	.0351	.0305	.0457	.0339
22	.0339	.0339	.0354	.1715	.2058	.0514	.0339
23	.0339	.0339	.0351	.1715			.0339
24	.0305	.0339	.0339	.0343		.1524	.1524
Max	.2601	.2486	.2543	.1715	.2058	.1524	.3429
Min	.0305	.0034	.0339	.0343	.0305	.0305	.0339
Avg	.1015	.0894	.0817	.0466	.0604	.0526	.1549

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 201 / 11 KV SHEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1311	.1638	.1509	.1475	.3563	.4858	.4656
2	.1311	.1638	.1509	.1475	.3239	.4696	.4656
3	.1475	.1311	.1677	.1638	.3239	.4696	.4525
4	.1475	.1311	.1677	.1638	.3239	.4858	.4938
5	.3277	.1638	.3521	.3277	.4534	.7935	.5658
6	.4534	.3932	.4049	.3768	1.0364	.9231	.9808
7	.4696	.4144	.4534	.426	1.2955	1.3923	1.1283
8	.3401	.2984	.3077	.2622	.2984	.3018	.2801
9	.431	.4858	.502	.1943	.2012	.2105	1.2431
10	.3978	.4858	.5992	.1781	.1677	.2105	
11	.2949	.4858	.6316	.1326	.1677	.2218	1.1469
12	.3239	.4858	.5992	.1658	.1677	.2241	1.1797
13	.3563	.4696	.5992	.1509	.1492	.1886	1.1469
14	.3239	.4534	.5668	.1341	.1341	.2075	1.1336
15	.3277	.4858	.6478	.1341	.1326	.2075	1.2003
16	.3725	.4696	.6401	.1341	.1326	.2075	1.0883
17	.1326	.1638	.1802	.1326	.1619	.2263	.1886
18	.1658	.1638	.1475	.1658	.2458	.2452	.2263
19	.2622	.2652	.2622	.2622	.2949	.3658	.3206
20	.2818	.3185	.2785	.3113	.2915	.4024	.3772
21	.2652	.2818	.2591	.2949	.2915	.3841	.3206
22	.2012	.2347	.2105	.4534	.5506	.4917	.2454
23	.1677	.1658	.1619	.3887	.5182	.4578	.2126
24	.1475	.1638	.1677	.1638	.3563	.4858	.4578
Max	.4696	.4858	.6478	.4534	1.2955	1.3923	1.2431
Min	.1311	.1311	.1475	.1326	.1326	.1886	.1886
Avg	.275	.3099	.3587	.2255	.3490	.4191	.6661

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 202 / 11 KV kashilingwadi AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0332	.0671	.0663	.0492	.2429	.2949	.4115
2	.0332	.0503	.0663	.0492	.1943	.2785	.3944
3	.0497	.0503	.0829	.0655	.1943	.2785	.3944
4	.0497	.0503	.0829	.0655	.1943	.2949	.4115
5	.0829	.0671	.0995	.0655	.2915	.3277	.4458
6	.116	.1006	.1326	.0819	.4049	.4424	.5658
7	.116	.1326	.1326	.1147	.4915	.5506	.583
8	.0995	.1006	.0995	.0819	.1006	.081	.0732
9	.2155	.2429	.2818	.0995	.1509	.1341	.6554
10	.2652	.3077	.3149	.0995	.1341	.0995	
11	.2949	.3563	.431	.116	.1677	.128	.5735
12	.3401	.3563	.3605	.116	.1174	.128	.6226
13	.3563	.3563	.3768	.1326	.116	.0914	.5898
14	.3239	.3401	.426	.1341	.1492	.128	.6882
15	.3277	.3725	.3768	.1326	.1341	.1463	.7209
16	.3563	.3401	.3768	.1658	.1509	.128	.639
17	.1492	.1341	.1006	.1326	.1174	.2033	.1227
18	.1326	.1174	.1006	.116	.0995	.2772	.1227
19	.0983	.0995	.0838	.1147	.116	.2218	.1227
20	.0838	.1006	.1006	.0983	.0983	.1663	.1402
21	.0838	.0838	.0819	.0983	.1147	.1478	.0876
22	.0671	.0829	.0819	.3077	.2984	.4359	.0701
23	.0671	.0838	.0819	.2591	.2949	.4024	.0701
24	.0497	.0671	.0829	.0655	.2429	.2949	.4024
Max	.3563	.3725	.431	.3077	.4915	.5506	.7209
Min	.0332	.0503	.0663	.0492	.0983	.081	.0701
Avg	.1580	.1692	.1842	.1151	.1924	.2367	.3873

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 203 / 11 KV AWANDI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4144	.5243	.4807	.4641	.1966	.1823	.1907
2	.4144	.4915	.4641	.4641	.1638	.1658	.1928
3	.431	.4915	.4641	.4807	.1638	.1658	.1928
4	.431	.4915	.4807	.4807	.1638	.1823	.2279
5	.7293	.4915	.9448	.663	.2622	.4144	.3681
6	.8288	.852	1.1437	.8453	.3932	.4807	.4908
7	1.326	1.4899	1.5581	1.0442	.3978	.3978	.4207
8	.3481	.3018	.2818	.2652	.2652	.2984	.3012
9	.2321	.1943	.2012	1.1105	1.2955	1.5083	.2126
10	.1989	.1823	.1341	1.2597	1.4723	1.6244	
11	.1658	.1326	.1341	1.166	1.4723	1.6078	.1753
12	.1658	.1326	.1326	1.0486	1.3763	1.6741	.1928
13	.1326	.116	.0995	1.1012	1.2963	1.0159	.1578
14	.1658	.116	.0995	1.0486	1.5123	1.3108	.1578
15	.1341	.1326	.1326	1.0486	1.2803	1.3108	.1928
16	.1638	.1326	.1326	1.0486	1.2803	1.3599	.1928
17	.1638	.1658	.1823	.1326	.1781	.1928	.2279
18	.1943	.1823	.1989	.2347	.2429	.298	.2804
19	.2652	.2984	.2984	.2652	.3149	.3506	.3506
20	.3239	.3149	.3315	.3647	.3647	.3856	.3506
21	.2591	.2818	.2652	.3018	.2818	.3155	.3155
22	.583	.5636	.5636	.1989	.1989	.2401	.9175
23	.5243	.4807	.5138	.1966	.1823	.2229	.852
24	.431	.5243	.4807	.4807	.1989	.1823	.2058
Max	1.326	1.4899	1.5581	1.2597	1.5123	1.6741	.9175
Min	.1326	.116	.0995	.1326	.1638	.1658	.1578
Avg	.3761	.3785	.4049	.6548	.6231	.6620	.3116

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 204 / 11 Kv Walekhindi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0185	.0187	.0187	.0187	.0373	.0187	.0377
2	.0185	.0187	.0187	.0187	.0187	.0187	.0377
3	.0185	.0187	.0187	.0187	.0187	.0187	.0377
4	.0185	.0187	.0187	.0187	.0187	.0187	.0377
5	.037	.0373	.0373	.0373	.0373	.0373	.0377
6	.0377	.0747	.056	.056	.056	.056	.0566
7	.0377	.0554	.056	.056	.037	.056	.0377
8	.0373	.037	.0377	.0373	.0189	.0373	.0377
9	.0373	.0189	.0373	.0373	.0377	.0373	.0377
10	.0187	.0377	.0373	.0373	.0189	.0373	
11	.0373	.0377	.0187	.0373	.0373	.0373	.0189
12	.0187	.0189	.0187	.0189	.0187	.0373	.0189
13	.0187	.0377	.0187	.0189	.0373	.0187	.0189
14	.0189	.0189	.0187	.0189	.0187	.0187	.0189
15	.0189	.0189	.0187	.0189	.0187	.0187	.0189
16	.0189	.0189	.0187	.0189	.0187	.0187	.0189
17	.0189	.0189	.0187	.0189	.0189	.0187	.0189
18	.037	.0189	.0187	.0373	.0187	.0187	.0377
19	.0549	.056	.056	.0549	.056	.056	.0566
20	.0549	.056	.056	.0549	.056	.056	.0566
21	.0366	.0373	.0373	.0366	.056	.0566	.0377
22	.0373	.0373	.0373	.0366	.0373	.0377	.0377
23	.0373	.0373	.0373	.037	.0373	.0377	.0377
24	.0187	.0189	.0187	.0373	.0187	.0373	.0377
Max	.0549	.0747	.056	.056	.056	.0566	.0566
Min	.0185	.0187	.0187	.0187	.0187	.0187	.0189
Avg	.0294	.0320	.0304	.0326	.0311	.0335	.0344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244036 / 33/11 KV SHEGAON

Feeder No / Name : 205 / 11 KV SHEGAON GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905	.112	.0934	.0934	.1109	.1307	.1132
2	.0905	.0934	.0934	.0934	.0924	.112	.1132
3	.0905	.0934	.112	.112	.0924	.1132	.1132
4	.0905	.0934	.112	.1494	.0924	.132	.1132
5	.1448	.112	.1494	.1494	.1478	.1509	.132
6	.1867	.1848	.1867	.2054	.1848	.1867	.2075
7	.2241	.2218	.2427	.168	.2172	.2427	.2263
8	.1646	.1848	.1886	.1867	.1478	.2452	.2263
9	.2378	.2195	.1867	.2054	.2195	.2641	.2829
10	.2743	.1463	.168	.2241	.1829	.2641	
11	.2378	.1829	.1307	.1294	.1463	.2263	.2075
12	.0914	.128	.1307	.1478	.1097	.1886	.2075
13	.128	.1463	.112	.1109	.1663	.2075	.1886
14	.0924	.1463	.168	.0914	.1307	.1698	.2075
15	.128	.1097	.112	.1463	.1478	.132	.1886
16	.1463	.1097	.112	.1097	.1848	.1886	.2263
17	.1294	.1494	.168	.1463	.168	.1886	.2263
18	.1629	.168	.2054	.181	.2054	.2263	.2641
19	.2353	.2987	.2614	.2534	.2801	.3206	.3206
20	.2353	.2614	.3174	.2896	.2614	.3018	.2263
21	.181	.2054	.2054	.2195	.2054	.2075	.2263
22	.1448	.1494	.1494	.1663	.1494	.1509	.1698
23	.1267	.112	.1307	.1097	.1494	.132	.1509
24	.1086	.1109	.112	.112	.1109	.1307	.1132
Max	.2743	.2987	.3174	.2896	.2801	.3206	.3206
Min	.0905	.0934	.0934	.0914	.0924	.112	.1132
Avg	.1559	.1558	.1603	.1584	.1627	.1922	.1935

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244058 / 33/11 KV UMRANI

Feeder No / Name : 201 / 11 KV Umrani AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097		.1463	.1463		
2	.1097		.1463	.1463		
3	.1097		.1463	.1646		
4	.12		.1829	.1646		
5	.1663		.2195	.1829		
6	.2402		.2743	.1829		
7	.2378		.2743	.2195		
8	.168		.2195	.1829		
9	.1715		.9724	.0914		
10			1.0059	.0914		
11		.9221	1.1736			
12		.9221	1.2803		.1097	
13		.8383	1.1401		.1097	
14		.9221	1.1401		.1097	.0732
15		.9069	1.1401		.1097	.0732
16		.9389	1.1736		.0739	.0732
17		.1463	.1006		.112	.0732
18		.1463	.1097		.2195	
19		.1829	.1463		.2033	
20		.1829	.1829		.1867	
21		.1829	.1829		.168	.1463
22		.1463	.1829		.9646	.7316
23		.1463	.1463		.933	.7316
24	.1097		.1296	.1463		
Max	.2402	.9389	1.2803	.2195	.9646	.7316
Min	.1097	.1463	.1006	.0914	.0739	.0732
Avg	.1543	.5065	.4924	.1563	.2750	.2718

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244058 / 33/11 KV UMRANI

Feeder No / Name : 202 / 11KV Khojanwadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829		.1646	.1829		
2	.1829		.1646	.1829		
3	.1646		.1646	.1829		
4	.1646		.1829	.1829		
5	.2195		.1829	.2195		
6	.2772		.2561	.2561		
7	.3361		.3292	.3292		
8	.3174		.2195	.2926		
9			1.6872	.2195		
10			1.7185	.2195		
11		1.6404	1.6872			.2195
12		1.656	1.6872		.2378	.1646
13		1.6404	1.7185		.2195	.1646
14		1.6404	1.7185		.1829	.1829
15		1.656	1.7966		.1848	.1829
16		1.6872	1.8435		.1646	.1829
17		.1406	.1463		.1867	.2195
18		.1646	.1463		.2195	.1829
19		.1829	.1829		.2218	.2195
20		.2195	.2561		.2195	.2195
21		.2195	.2561		.2195	.2195
22		.2195	.2561		1.7553	1.6461
23		.2195	.2195		1.7814	1.6461
24	.1829		.1646	.1829		
Max	.3361	1.6872	1.8435	.3292	1.7814	1.6461
Min	.1646	.1406	.1463	.1829	.1646	.1646
Avg	.2253	.8682	.7146	.2228	.4661	.4193

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244058 / 33/11 KV UMRANI

Feeder No / Name : 203 / 11 KV SINDUR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716		1.2574	.9221		
2	.7526		1.2574	.9221		
3	.7316		1.3413	.9221		
4	.7811		1.3748	1.0059		
5	.8684		1.3748	1.4251		
6	1.1797		1.6766	1.5089		
7	1.7901		1.9281	1.6766		
8	.4572		.3292	.2926		
9	.3109		.2926	1.6095		
10			.2926	1.5927		
11		.2926	.1463			1.8107
12		.3292	.1463		1.0279	1.8107
13		.1829	.1463		.7748	1.8107
14		.1646	.1463		1.2651	1.8107
15		.1646	.1463		1.4899	1.8442
16		.1829	.1463		1.5074	1.8138
17		.1829	.1829		.1463	.2561
18		.1829	.2012		.3109	.2561
19		.3292	.2743		.3696	.2926
20		.3475	.3292		.3734	.2926
21		.3658	.3292		.3174	.2926
22		1.1736	1.1401		.2218	.3292
23		1.2574	.8886		.2195	.3292
24	.7773		1.2574	.8886		
Max	1.7901	1.2574	1.9281	1.6766	1.5074	1.8442
Min	.3109	.1646	.1463	.2926	.1463	.2561
Avg	.8421	.3966	.6919	1.1606	.6687	.9961

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244058 / 33/11 KV UMRANI

Feeder No / Name : 204 / 11 Kv Umrani Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0324		.0324	.0324		
2	.0324		.0324	.0324		
3	.0324		.0324	.0486		
4	.0486		.0486	.0486		
5	.0486		.0486	.0486		
6	.0972		.0648	.0648		
7	.0972		.0972	.0972		
8	.0648		.0648	.0648		
9	.0648		.0648	.0648		
10			.0486	.0486		
11		.0486	.0486			
12		.0324	.0486		.0486	.0648
13		.0324	.0486		.0324	.0486
14		.0324	.0486		.0324	.0486
15		.0324	.0486		.0486	.0486
16		.0324	.0486		.0486	.0486
17		.0648	.0648		.0648	.0486
18		.0648	.0648		.0972	.0486
19		.0972	.0972		.1134	.0972
20		.1147	.1134		.1134	.1134
21		.0972	.0972		.0972	.0972
22		.0648	.0648		.0648	.0648
23		.0486	.0486		.0648	.0486
24	.0486		.0324	.0324		
Max	.0972	.1147	.1134	.0972	.1134	.1134
Min	.0324	.0324	.0324	.0324	.0324	.0486
Avg	.0567	.0587	.0587	.0530	.0689	.0648

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 201 / 11 KV DEVANAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9488	1.186	1.4074	1.5181	.2846	.2846	.2372
2	.9488	1.186	1.4074	1.5181	.2846	.2846	.2372
3	.9488	1.186	1.4232	1.5181	.2846	.2846	.2372
4	.9488	1.186	1.4232	1.5181	.2846	.2846	.2372
5	1.0279	1.2018	1.4232	1.6604	.3005	.2214	.2846
6	1.3441	1.4706	1.6446	1.8027	.3479	.253	.3321
7	1.6446	2.0873	2.198	1.8027	.3321	.3321	.3479
8	.253	.253	.2688	.2214	.3321	.3321	.3163
9	.1898	.2214	.2372	1.8976	2.2929	2.1348	.2846
10	.1739	.2214	.2372	1.9134	2.3562	2.3403	.253
11	.1739	.1581	.1581	2.1822		2.4036	.2688
12	.1739	.1581	.1739	2.0241	.4744	2.4669	.2214
13	.1739	.1581	.1739	1.5813	2.2929	2.372	.2214
14		.1581	.1739	1.5813	2.451	2.372	.1581
15	.1265	.1898	.1581	1.9766	2.3878	2.3403	.1581
16	.1265	.1898	.1581		2.3562	2.372	.1423
17	.1265	.1581	.1581	.1898	.2372	.2372	.1898
18	.1581	.1898	.1581	.2214	.2372	.2372	.1898
19	.253	.253	.1898	.2846	.2846	.2846	.3163
20	.2846	.2846	.1898	.2846	.3163	.3005	.3479
21	.2846	.253	.253	.2846	.3163	.3005	.2846
22	1.2651		1.5023	.2846	.2846	.2846	1.8185
23	1.186	1.4548	1.5023	.2846	.2846	.253	1.7394
24	.9488	1.186	1.4232	1.5181	.2846	.2846	.2372
Max	1.6446	2.0873	2.198	2.1822	2.451	2.4669	1.8185
Min	.1265	.1581	.1581	.1898	.2372	.2214	.1423
Avg	.5961	.6518	.7518	1.2204	.8395	.9692	.3775

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 202 / 11 KV PACCHPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1448	.2317	.1738	.2172	.0579	.0579	.0434
2	.1448	.2317	.1738	.2172	.0579	.0579	.0434
3	.1448	.2317	.2027	.2172	.0579	.0579	.0434
4	.1448	.2317	.2317	.2172	.0579	.0579	.0434
5	.1593	.2462	.2462	.2606	.0579	.0579	.0434
6	.1882	.3041	.3475	.2896	.0724	.0579	.0579
7	.4199	.5213	.695	.3475	.0724	.0724	.0579
8	.0579	.0579	.0579	.0579	.0724	.0724	.0434
9	.0434	.0579	.0434	.3475	.5792	.4633	.0579
10	.0434	.0579	.0434	.3475	.5792	.5068	.0579
11	.0434	.0579	.0434	.4923	.7964	.695	.0579
12	.0434	.0579	.0434	.4489	.724	.6371	.0579
13	.0434	.0579	.0434	.2896	.724	.6371	.0579
14	.0434	.0579	.0434	.3475	.5792	.6371	.0579
15	.0434	.0579	.0434	.4199	.5792	.6081	.0579
16	.0434	.0579	.0434		.5068	.5937	.0579
17	.0434	.0579	.0434	.0579	.0434	.0579	.0579
18	.0434	.0579	.0434	.0579	.0434	.0579	.0579
19	.0724	.0579	.0579	.0724	.0579	.0579	.0579
20	.0724	.0579	.0579	.0724	.0724	.0579	.0579
21	.0579	.0579	.0579	.0579	.0724	.0579	.0579
22	.2606	.2027	.2172	.0579	.0579	.0579	.2027
23	.2606	.1882	.2172	.0579	.0579	.0579	.2027
24	.1448	.2317	.1738	.2172	.0579	.0724	.0434
Max	.4199	.5213	.695	.4923	.7964	.695	.2027
Min	.0434	.0579	.0434	.0579	.0434	.0579	.0434
Avg	.1128	.1430	.1394	.2247	.2516	.2395	.0657

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 203 / 11 KV Rawalgundwadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2753	.2429	.1943	.2105	1.7004	1.5384	1.7004
2	.2753	.2429	.1943	.2105	1.7004	1.5384	1.7004
3	.2753	.2429	.1943	.2105	1.7004	1.5384	1.7004
4	.2753	.2429	.2267	.2105	1.7004	1.587	1.7004
5	.2915	.2753	.2753	.2753	1.7004	.6478	1.9109
6	.3239	.3077	.3239	.2915	1.8947	1.2146	1.9757
7	.3401	.3077	.3077	.3239	1.0526	2.3967	2.0243
8	.3725	.2915	.2753	.2915	.2429	.2591	.2267
9	1.3765	1.749	1.6518	.2753	.2915	.2591	1.9757
10	1.6194	1.7004	1.6194	.2429	.2591	.2591	2.0243
11	1.7166	1.7328	1.7004	.2267	.2429	.2591	2.2348
12	1.7166	1.7814	1.8623	.2105	.2429	.2591	
13	.9717	1.8138	1.8138	.1457	.1781	.2429	1.2955
14	1.2955	1.8785	1.8785	.1457	.1619	.2429	1.3279
15	1.2955	1.9919	1.8785	.1781	.1619	.2591	1.4575
16	1.3117	1.8947	1.9109		.2105	.2429	1.4575
17	.2591	.2591	.1943	.2267	.2429	.2591	.1619
18	.2591	.2591	.2267	.2591	.2429	.2591	.1943
19	.2753	.2591	.2267	.3077	.2753	.2591	.2591
20	.3077	.3239	.1943	.3077	.3321	.2915	.3239
21	.3077	.2591	.1943	.3077	.3239	.2591	.2591
22	.2753	.2267	.1781	1.8623	1.7004	1.7328	.2267
23	.2591	.1943	.2105	1.8623	1.5384	1.8623	.2267
24	.2753	.2591	.1943	.2105	1.7004	1.5384	1.7004
Max	1.7166	1.9919	1.9109	1.8623	1.8947	2.3967	2.2348
Min	.2591	.1943	.1781	.1457	.1619	.2429	.1619
Avg	.6646	.7807	.7469	.3823	.8249	.8003	1.2202

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 204 / 11 kv Rawalgundwadi Gav

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724	.0724	.0724	.0537	.0724	.0724	.0537
2	.0724	.0724	.0724	.0537	.0724	.0724	.0537
3	.0724	.0724	.0724	.0537	.0724	.0724	.0537
4	.0724	.0724	.0724	.0537	.0724	.0724	.0537
5	.0724	.0905	.0905	.0716	.0724	.0905	.1254
6	.1448	.1267	.1448	.1433	.1448	.1629	.1433
7	.1448	.1448	.1267	.1254	.1448	.1629	.1433
8	.1267	.0905	.1086	.1254	.1086	.1267	.1075
9	.0905	.0905	.0716	.0905	.1086	.0716	.0905
10	.0905	.0724	.0537	.0724	.0724	.0716	.0724
11	.0724	.0724	.0537	.0543	.0724	.0895	.0724
12	.0543	.0543	.0537	.0543	.0724	.0716	.0724
13	.0543	.0543	.0537	.0724	.0724	.0537	.0724
14	.0543	.0543	.0537	.0724	.0724		.0724
15	.0543	.0362	.0537	.0543	.0724		.0724
16	.0543	.0543	.0537		.0905	.0537	.0724
17	.0905	.0543	.0716	.0905	.0905	.0716	.0724
18	.0905	.0724	.0716	.1086	.1086	.1075	.0724
19	.181	.1448	.0895	.1629	.1448	.1254	.1448
20	.1991	.181	.1433	.1991	.1991	.1612	.181
21	.1448	.1448	.1791	.1629	.1629	.1254	.1086
22	.0905	.1086	.1075	.0905	.0905	.1254	.0905
23	.0724	.0724	.0716	.0724	.0724	.0716	.0905
24	.0724	.0724	.0724	.1573	.0724	.0724	.0716
Max	.1991	.181	.1791	.1991	.1991	.1629	.181
Min	.0543	.0362	.0537	.0537	.0724	.0537	.0537
Avg	.0935	.0867	.0839	.0954	.0973	.0957	.0901

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244072 / 33/11 KV PACHAPUR

Feeder No / Name : 205 / 11 kv Pachhapur Amrutwadi GAOTHAN FEEDER
gav Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0181	.0181	.0181	.0185	.0181	.0181	.0185
2	.0181	.0181	.0181	.0185	.0181	.0181	.0185
3	.0181	.0181	.0181	.0185	.0181	.0181	.0185
4	.0181	.0181	.0181	.0185	.0181	.0181	.0185
5	.0181	.0181	.0181	.0185	.0181	.0181	.0185
6	.0181	.0362	.0724	.0185	.0543	.0181	.037
7	.1086	.0724	.0543	.037	.0724	.0543	.0185
8	.0543	.0362	.0543	.0554	.0724	.0543	.037
9	.0181	.0362	.0185	.0181	.0543	.037	.0362
10	.0181	.0181	.0185	.0181	.0181	.0185	.0181
11	.0181	.0181	.0185	.0181	.0181	.0185	.0181
12	.0181	.0181	.0185	.0181	.0181	.0185	.0181
13	.0181	.0181	.0185	.0181	.0181	.0185	.0181
14	.0181	.0181	.0185	.0181	.0181	.0185	.0181
15	.0181	.0181	.0185	.0181	.0181	.0185	.0181
16	.0181	.0181	.0185		.0181	.0185	.0181
17	.0181	.0181	.0185	.0181	.0181	.0185	.0181
18	.0181	.0181	.0185	.0362	.0181	.0185	.0181
19	.0543	.0362	.0554	.0543	.0543	.037	.0181
20	.0905	.0724	.037	.0905	.0905	.037	.0543
21	.0362	.0362	.0185	.0724	.0543	.037	.0362
22	.0181	.0181	.037	.0181	.0362	.0554	.0181
23	.0181	.0181	.0185	.0181	.0181	.0185	.0181
24	.0181	.0181	.0181	.0185	.0181	.0181	.0185
Max	.1086	.0724	.0724	.0905	.0905	.0554	.0543
Min	.0181	.0181	.0181	.0181	.0181	.0181	.0181
Avg	.0287	.0264	.0267	.0285	.0324	.0260	.0228

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 201 / 11 KV Kosari AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.2229	.823	.3429	.12	.1543	.1715
2	.1372	.2229	.7716	.3429	.12	.1543	.1372
3	.1543	.2229	.6859	.3429	.12	.1715	.1715
4	.1715	.2229	.6859	.4287	.12	.1543	.2058
5	.1886	.2401	.6859	.5144	.1543	.1715	.2058
6	.2229	.4115	.7202	.5487	.2058	.2572	.2572
7	.583	.7373	.7716	.6001	.2229	.2572	.2915
8	.1543	.1543	.1886	.1543	.2058	.2058	.2401
9	.1543	.12	.1715	.7373	.8916	.9774	.2058
10	.1543	.12	.1372	.7202	1.0117	1.1488	.1886
11	.1029	.12	.1029	.8573	1.0802	.2229	.2058
12	.12	.12	.1029		1.1317	.2229	.2058
13	.12	.12	.12	.8402	1.1145	.2229	.2229
14	.12	.12	.12	.8402	1.0288	.2401	.1886
15	.12	.12	.1029	.8745	1.0974	.2401	.1886
16	.0857	.12	.1029	.7716	1.0631	.2401	.1715
17	.12	.1372	.1372	.1372	.1372	.1715	.1524
18	.1372	.1372	.1715	.1715	.1886	.2058	.1715
19	.1715	.1715	.1715	.2058	.2401	.2058	.1886
20	.1715	.1715	.1715	.2229	.2401	.2058	.1715
21	.1372	.1715	.1886	.1543	.1886	.2229	.1715
22	.2401	.4287	.3429	.1372	.1715	.2058	.6344
23	.2229	.5144	.3429	.12	.1543	.1715	.583
24	.1543	.2229	.5144	.3601	.12	.1543	.1715
Max	.583	.7373	.823	.8745	1.1317	1.1488	.6344
Min	.0857	.12	.1029	.12	.12	.1543	.1372
Avg	.1708	.2229	.3472	.4533	.4637	.2744	.2293

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 202 / 11 KV Kumbharwadi AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.1715	.2058	.1372	.9431	.9088	.6859
2	.0514	.1715	.1715	.1372	.9431	.8916	.8573
3	.0514	.1715	.1715	.1372	.9088	.9088	.8573
4	.0514	.1715	.2572	.1715	.9088	.8916	1.0288
5	.2915	.2229	.3429	.2572	.9088	.9088	1.2003
6	.3258	.3429	.3429	.3429	1.3546	1.5089	1.3717
7	.4287	.3601	.3944	.3772	1.0631	1.8347	1.4403
8	.3258	.2915	.2572	.2401	.2401	.3086	.3601
9	.9774	.8745	1.6289	.1543	.2058	.2743	1.5775
10	1.0802	.8916	1.6118	.2229	.1543	.2401	1.7147
11	1.2517	1.0288	1.5947	.2229	.1543		1.8004
12	.9259	.9774	1.3717		.1886		1.8176
13	.7202	1.0631	1.2517	.1886	.2401		1.7833
14	.8573	1.0288	1.2003	.2058	.2229		1.4575
15	.8573	1.0288	1.0288	.2058	.2058		1.5089
16	.7716	.8573	.9431	.1543	.2229		1.3546
17	.12	.2058	.1715	.1886	.2058	.2058	.1677
18	.1715	.2401	.2058	.2229	.3086	.1715	.2401
19	.2401	.2743	.2058	.3429	.3258	.2058	.3258
20	.2915	.2915	.2401	.3429	.3429	.2572	.2915
21	.2572	.2915	.2743	.2915	.2915	.3086	.2743
22	.2058	.2572	.2572	1.0631	1.0631	.1715	.2229
23	.1715	.2572	.1715	1.046	1.046	.1372	.2058
24	.0514	.1715	.2229	1.3717	1.0117	.9088	.9945
Max	1.2517	1.0631	1.6289	1.3717	1.3546	1.8347	1.8176
Min	.0514	.1715	.1715	.1372	.1543	.1372	.1677
Avg	.4387	.4851	.6051	.3489	.5609	.6135	.9808

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 203 / 11 KV Birnal GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.1029	.1372	.12	.12	.1029	.1029
2	.0857	.1029	.12	.1029	.12	.1029	.0857
3	.1029	.1029	.12	.1029	.12	.0857	.0857
4	.0857	.1029	.1715	.1715	.12	.1029	.0857
5	.1029	.12	.1715	.1715	.1543	.1029	.12
6	.1372	.12	.1715	.2058	.1886	.1543	.1715
7	.1886	.1543	.1886	.2058	.1715	.2058	.2058
8	.1715	.1543	.1543	.1543	.1715	.1543	.1886
9	.1372	.12	.1715	.1372	.1886	.1715	.1715
10	.1372	.1372		.1886	.1543	.1372	.2229
11	.1372	.1029	.1715	.1543	.1543	.1372	.1372
12	.1372	.1372	.1372		.1715	.1372	.1372
13	.0857	.0857	.1029	.12	.1543	.1372	.1029
14	.1029	.0857	.1029	.1029	.1543	.1372	.1372
15	.0857	.12	.1029	.1372	.1543	.1715	.1372
16	.1029	.1372	.12	.1543	.1372	.1715	.12
17	.12	.1543	.1372	.1886	.1543	.1715	.1524
18	.1886	.1543	.1543	.1886	.1715	.1715	.1715
19	.2058	.1715	.1543	.2229	.2058	.2058	.2915
20	.1886	.1715	.1543	.2401	.2229	.2058	.2572
21	.1715	.1886	.1543	.1886	.1886	.2401	.2058
22	.12	.1715	.1372	.1715	.1543	.1715	.1372
23	.1029	.1715	.1372	.1372	.1372	.1372	.12
24	.0857	.1029	.1372	.12	.12	.1029	.12
Max	.2058	.1886	.1886	.2401	.2229	.2401	.2915
Min	.0857	.0857	.1029	.1029	.12	.0857	.0857
Avg	.1279	.1322	.1439	.1603	.1579	.1508	.1528

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 204 / 11 KV Dhawadwadi GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0514	.0343	.0343	.0343	.0514
2	.0343	.0343	.0514	.0343	.0343	.0343	.0514
3	.0343	.0343	.0514	.0343	.0343	.0343	.0686
4	.0514	.0343	.0686	.0514	.0514	.0343	.0686
5	.0514	.0514	.0857	.0857	.0514	.0514	.0686
6	.0686	.0857	.0857	.0857	.0857	.0857	.0686
7	.0857	.0686	.1029	.0857	.0514	.0857	.0686
8	.0686	.0686	.0343	.0686	.0857	.0857	.0686
9	.0343	.0514	.0343	.0686	.0343	.0343	.0514
10		.0343	.0343	.0514	.0343	.0343	.0343
11	.0171	.0343	.0343	.0343	.0514	.0514	.0343
12	.0171	.0343	.0343		.0343	.0514	.0343
13	.0171	.0343	.0171	.0171	.0343	.0514	.0514
14	.0171	.0343	.0343	.0171	.0343	.0343	.0343
15	.0171	.0343	.0343	.0343	.0343	.0343	.0343
16	.0343	.0343	.0514	.0343	.0343	.0343	.0343
17	.0343	.0514	.0857	.0514	.0514	.0514	.0514
18	.0514	.0686	.0857	.0686	.0686	.0857	.0514
19	.0686	.0686	.0857	.0857	.0857	.0857	.12
20	.0857	.0686	.0686	.1029	.0857	.0857	.1029
21	.0686	.0686	.0686	.0686	.0686	.0686	.0857
22	.0514	.0514	.0686	.0686	.0514	.0686	.0514
23	.0343	.0514	.0514	.0343	.0514	.0686	.0514
24	.0343	.0343	.0514	.0343	.0343	.0343	.0514
Max	.0857	.0857	.1029	.1029	.0857	.0857	.12
Min	.0171	.0343	.0171	.0171	.0343	.0343	.0343
Avg	.0440	.0486	.0571	.0544	.0507	.055	.0579

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 205 / 11 KV Hivare AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1543	.1715	.1372	1.0288	1.0631	1.0288
2	.12	.1543	.1372	.1372	1.0288	1.046	1.0288
3	.1372	.1372	.1372	.12	1.0288	1.0117	.9431
4	.1372	.1372	.1715	.12	.9945	1.0117	.9431
5	.1543	.1372	.1715	.1715	.9945	1.0117	1.0288
6	.1886	.2229	.2572	.2572	1.3032	1.3375	1.2003
7	.2743	.2743	.3258	.3086	1.5432	1.7661	1.3546
8	.2572	.1886	.2401	.2572	.1886	.2401	.2572
9	.8402	.9774	1.0288	.2058	.1715	.1886	1.6289
10	1.0288	1.2003	1.2003	.2058	.1543	.1543	1.749
11	1.046	1.1145	1.3717	.1886	.1715	.2229	1.7833
12	1.0288	.1372	1.406		.12	.2229	1.749
13	.9431	1.3203	1.5089	.1715	.1372	.2229	1.7147
14	.9774	1.286	1.3717	.1715	.1543	.2229	1.7318
15	1.0117	1.2003	1.3717	.1715	.1543	.2229	1.869
16	.9431	1.166	1.2003	.2058	.1886	.2229	1.6804
17	.1372	.1715	.1715	.2058	.2229	.2058	.2134
18	.1543	.1715	.1715	.2401	.2058	.1715	.2572
19	.2229	.2058	.1715	.2915	.2572	.2058	.2743
20	.2229	.2058	.1715	.2572	.2401	.2058	.2572
21	.2229	.2401	.2058	.2401	.2229	.2401	.2229
22	.1886	.2058	.1715	1.1831	1.3032	1.0288	.1886
23	.1715	.1715	.1715	1.1831	1.286	1.0288	.1715
24	.12	.1715	.1715	.1543	1.0802	1.0974	1.1145
Max	1.046	1.3203	1.5089	1.1831	1.5432	1.7661	1.869
Min	.12	.1372	.1372	.12	.12	.1543	.1715
Avg	.4437	.4730	.5616	.2863	.5909	.5980	1.0163

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244105 / 33/11 KV Dhawadwadi

Feeder No / Name : 206 / 11 KV Pratapur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.3944	.823	.583	.0686	.0514	.0514
2	.3086	.3944	.7716	.5487	.0686	.0514	.0514
3	.2915	.3944	.6859		.0686	.0514	.0514
4	.3086	.3944		.5144	.0686	.0514	.0686
5	.3258	.3944		.6516	.0857	.0514	.0857
6	.3601	.5487	.8573	.6859	.1029	.1029	.0857
7	.7545	.823	1.0117	.7716	.12	.12	.12
8	.0857	.0686	.0686	.0514	.0686	.0857	.0686
9	.0514	.0514	.0343	.8059	1.046	1.046	.0514
10	.0514	.0343	.0343	.9602	1.1145	1.2174	.0514
11	.0343	.0343	.0343	1.046	1.2003	1.1145	.0514
12	.0343	.0343	.0343		1.286	1.1145	.0343
13	.0171	.0514	.0514	.9602	1.1488	1.1145	.0343
14	.0343	.0514	.0343	1.046	1.2346	1.1145	.0514
15	.0171	.0686	.0343	1.0117	1.2174	1.1317	.0686
16	.0514	.0686	.0343	1.0117	1.0802	1.1488	.0686
17	.0514	.0686	.0514	.0514	.0343	.0857	.0457
18	.0514	.0514	.0857	.0686	.0514	.0514	.0686
19	.0857	.0514	.0857	.0857	.0686	.0514	.0857
20	.0857	.0686	.0857	.1029	.0686	.0686	.0686
21	.0857	.0857	.0857	.0857	.0857	.0857	.0857
22	.4287	.6859	.4801	.0686	.0686	.0857	.7888
23	.3944	.8573	.5144	.0686	.0686	.0857	.7202
24	.2915	.3944	.8573	.6173	.0686	.0514	.0514
Max	.7545	.8573	1.0117	1.046	1.286	1.2174	.7888
Min	.0171	.0343	.0343	.0514	.0343	.0514	.0343
Avg	.1872	.2529	.3071	.5362	.4372	.4222	.1212

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244114 / 33/11KV JIRGYAL

Feeder No / Name : 201 / 11 KV JIRGYAL AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.7202	.8785	.7375	.1905	.1524	.1524
2	.6478	.7202	.8785	.7375	.1905	.1524	.1524
3	.6478	.7202	.8785	.7468	.1905	.1524	.1524
4	.6478	.7459	.8951	.7468	.1905	.1524	.1715
5	.6478	.9116	.9012	.7468	.1905	.2096	.1905
6	.6964	1.326	1.3599	1.0526	.3239	.381	.3429
7	1.7814	2.0553	2.1376	1.4746	.4763	.362	.4191
8	.3429	.3048	.2858	.2477	.2858	.2858	.2667
9	.2096	.1905	.2286	1.3765	1.4937	1.8138	.2096
10	.1143	.1524	.1524	1.4575	1.5394	1.7328	.1524
11	.0953	.1143	.1334	1.1336	1.5394	1.668	.0953
12	.0762	.1143	.1524	1.3441	1.4175	1.587	.0953
13	.0953	.1143	.1143	1.3765	1.5203	1.5893	.1143
14	.0953	.1334	.0953	1.3765	1.5043	1.5238	.1143
15	.0953	.1143	.0953	1.4575	1.5203	1.7652	.1143
16	.0953	.1334	.0953	1.4575	1.5684	1.668	.1143
17	.1334	.1524	.1334	.0953	.1715	.0953	.1334
18	.1905	.1524	.1524	.0953	.1905	.1334	.1334
19	.2477	.2286	.2286	.2477	.2477	.2286	.2286
20	.2477	.2477	.2477	.2477	.2858	.2858	.2858
21	.1905	.2096	.2286	.1905	.2096	.1905	.1905
22	.8482	1.0322	.8697	.1905	.1715	.1715	1.186
23	.7842	.9831	.7716	.1905	.1524	.1524	1.0936
24	.6478	.7522	.9282	.7716	.1905	.1524	.1524
Max	1.7814	2.0553	2.1376	1.4746	1.5684	1.8138	1.186
Min	.0762	.1143	.0953	.0953	.1524	.0953	.0953
Avg	.4261	.5137	.5351	.8125	.6567	.6919	.2609

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244114 / 33/11KV JIRGYAL

Feeder No / Name : 202 / 11 KV SHINGANAPUR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.2096	.2096	.4049	.4062	.3932
2	.1905	.1905	.2096	.2096	.4049	.4062	.3932
3	.1905	.1905	.2096	.2096	.4049	.4062	.3932
4	.1905	.1905	.2286	.2096	.4049	.4915	.4096
5	.1905	.2286	.2667	.2477	.4858	.5735	.4096
6	.2477	.3048	.3239	.362	.7125	.7373	.5506
7	.381	.3239	.3239	.3429	.6478	.7865	.6478
8	.2858	.2667	.3048	.2858	.2286	.2477	.2286
9	.5426	.6226	.788	.2096	.1905	.2096	.6802
10	.5087	.6226	.7125	.1905	.1524	.1715	.6802
11	.5426	.5571	.6478	.1715	.1715	.2096	.583
12	.5087	.3605	.6722	.3048	.1524	.1143	.6081
13	.4475	.5407	.6009		.1524	.1143	.5921
14	.5093	.5243	.583	.0953	.1524	.0953	.5535
15	.5093	.5243	.6226	.0953	.1524	.1143	.5693
16	.4784	.583	.6203	.0953	.0953	.1143	.5243
17	.1143	.1334	.1334		.1715	.1143	.1334
18	.1524	.1143	.1334		.1715	.1334	.1715
19	.2477	.2096	.2667	.1905	.2667	.2286	.2286
20	.2858	.2858	.3429	.2477	.3048	.2858	.3048
21	.2667	.2858	.3239	.2477	.2667	.2667	.2858
22	.2096	.2477	.2667	.4858	.4687	.4372	.2286
23	.2096	.2286	.2096	.4858	.4218	.4534	.2096
24	.1905	.1905	.2096	.2096	.4858	.4062	.426
Max	.5426	.6226	.788	.4858	.7125	.7865	.6802
Min	.1143	.1143	.1334	.0953	.0953	.0953	.1334
Avg	.3163	.3299	.3838	.2432	.3113	.3135	.4252

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080]

BU 1287

Substation No/ Name :- 244114 / 33/11KV JIRGYAL

Feeder No / Name : 203 / 11 KV JIRGYAL GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0762	.0953	.0762	.0762	.0953
2	.0953	.0953	.0762	.0953	.0762	.0762	.0953
3	.0953	.0953	.0762	.0953	.0762	.0762	.0953
4	.0953	.0953	.0953	.0953	.0762	.0953	.0953
5	.0953	.1143	.0953	.0953	.0762	.1143	.0953
6	.1143	.1334	.1334	.1905	.1334	.1334	.1524
7	.1905	.1715	.1524	.1905	.1524	.1334	.1715
8	.1524	.1143	.1334	.1334	.1334	.1143	.1143
9	.0953	.0953	.0953	.0953	.0762	.0953	.0953
10	.0953	.0762	.0762	.0572	.0572	.0953	.0572
11	.0572	.0762	.0953	.0572	.0762	.0762	.0762
12	.0762	.0762	.0762	.0762	.0381	.0953	.0762
13	.0762	.0762	.0572	.0572	.0762	.1143	.1143
14	.0191	.0191	.0381	.0572	.0953	.0762	.0572
15	.0381	.0381	.0381	.0572	.0381	.0762	.0572
16	.0381	.0572	.0572	.0572	.0381	.0762	.0381
17	.0381	.0762	.0381	.0572	.0381	.0762	.0762
18	.1334	.0953	.0572	.1143	.0762	.0953	.1334
19	.1143	.1524	.1334	.1905	.1334	.1524	.1905
20	.1715	.1715	.1524	.1905	.1524	.2286	.1905
21	.1334	.1524	.1334	.1334	.1334	.1715	.1524
22	.1334	.1334	.1143	.0953	.0953	.1334	.1143
23	.0953	.1143	.0953	.0953	.0762	.1143	.0953
24	.0953	.0953	.0953	.0953	.0762	.0762	.0953
Max	.1905	.1715	.1524	.1905	.1524	.2286	.1905
Min	.0191	.0191	.0381	.0572	.0381	.0762	.0381
Avg	.0977	.1008	.0913	.1032	.0865	.1072	.1056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244114 / 33/11KV JIRGYAL

Feeder No / Name : 204 / 11 KV EKUNDI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2667	.2286	.2477	.4144	.3768	.3768
2	.1905	.2667	.2286	.2477	.4144	.3768	.3768
3	.1905	.2667	.2286	.2477	.4144	.3768	.3932
4	.1905	.2667	.2667	.2858	.4144	.381	.3932
5	.1905	.3429	.3429	.362	.4144	.4115	.4096
6	.362	.4382	.4572	.4572	.5967	.503	.5506
7	.4382	.5144	.4572	.4763	.8288	.7316	.6154
8	.4191	.5144	.4001	.4001	.381	.3429	.362
9	.5376	.4752	.6962	.3429	.3048	.2667	.5801
10	.4428	.5243	.5668	.1905	.2286	.1715	.4321
11	.4428	.4096	.5344	.1143	.1524	.1715	.5506
12	.4111	.3768	.5506	.1143	.1334	.1715	.5312
13	.4144	.3647	.4687	.0953	.1334	.1334	.4064
14	.3978	.4588	.5182	.0953	.1334	.1524	.3241
15	.4641	.426	.5992	.1143	.1524	.1715	.5468
16	.5304	.4858	.6133	.1334	.1524	.1715	.5735
17	.1905	.1334	.1524	.1334	.1905	.1715	.1715
18	.2477	.1524	.2096	.1905	.1524	.1334	.2286
19	.3429	.3048	.2667	.381	.3429	.3429	.3429
20	.362	.4001	.3239	.381	.381	.4001	.3048
21	.3048	.3048	.2667	.2858	.2667	.3048	.2667
22	.2858	.2858	.2477	.5801	.4096	.4858	.2286
23	.2667	.2477	.2477	.4144	.3768	.421	.2286
24	.1905	.2667	.2286	.2477	.4144	.3768	.3932
Max	.5376	.5243	.6962	.5801	.8288	.7316	.6154
Min	.1905	.1334	.1524	.0953	.1334	.1334	.1715
Avg	.3335	.3539	.3792	.2724	.3252	.3144	.3995

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244131 / 33/11 KV WALEKHINDI

Feeder No / Name : 201 / 11KV WALEKHINDI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-SEP-17
HR	Load (MW)
1	1.7204
24	1.3717
Max	1.7204
Min	1.3717
Avg	1.5461

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244131 / 33/11 KV WALEKHINDI

Feeder No / Name : 202 / 11KV BEVNOOR AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-SEP-17
HR	Load (MW)
1	.1524
2	.1524
3	.1524
4	.1524
5	.1829
6	.2469
7	.2315
8	.1372
9	1.3832
10	1.4803
11	1.8278
12	1.8679
13	1.917
14	2.2885
24	1.3717
Max	2.2885
Min	.1372
Avg	.9030

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244132 / 33/11 KV BASARGI

Feeder No / Name : 201 / Basargi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	1.1336
Max	1.1336
Min	1.1336
Avg	1.1336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 244132 / 33/11 KV BASARGI

Feeder No / Name : 202 / Basargi Gavtaon

Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-SEP-17
HR	Load (MW)
24	.1372
Max	.1372
Min	.1372
Avg	.1372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 201 / 11 KV TIPPEHALLI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 202 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-SEP-17
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 203 / 11 KV MALLAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 204 / 11 KV Jath

Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-SEP-17
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 205 / 11 KV Rampur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	1.5089
Max	1.5089
Min	1.5089
Avg	1.5089

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 206 / 11 KV Achakanhalli AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 207 / 11 KV SUGAR FACTORY

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-SEP-17
HR	Load (MW)
24	.0857
Max	.0857
Min	.0857
Avg	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

JATH[080] BU 1287

Substation No/ Name :- 246006 / 110/33/11 KV JAT

Feeder No / Name : 208 / 11 kv Achakanhallii Gav
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-SEP-17
HR	Load (MW)
24	.1372
Max	.1372
Min	.1372
Avg	.1372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 201 / 11kv k mahankal

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7865	.8413	.7499	.7499	.7316	.7682	.823
2	.7865	.8048	.7499	.7316	.7316	.7499	.8048
3	.7865	.8048	.7316	.7133	.695	.7499	.7865
4	.7682	.8413	.7133	.8048	.7682	.8048	.8048
5	.8048	.8596	.7682	.8779	.8779	.823	.8596
6	.9145	.9145	.8962	.8779	.9877	.8596	.9145
7	1.134	1.0791	1.134	1.0425	1.0974	1.0425	1.1523
8	1.0974	1.0974	1.0608	1.0242	.9511	1.0791	1.0974
9	.9694	.9145	.9511	.9694	.9511	.8779	.9328
10	.8596	.9694	1.0242	.9145	.9511	.9145	1.1157
11	.8779	.9877	.9511	.9511	.9145	.9145	1.0974
12	.8596	.9694	.9694	.9145	.9511	.9145	1.134
13	.823	.9328	.8779	.823	.9145	.8962	1.0608
14	.823	.9145	.9145	.8596	.9145	.8413	1.0425
15	.7499	.8962	.8596	.8596	.8962	.823	1.0059
16	.7499	.8962	.8962	.9145	.8779	.8413	
17	.823	.823	.8413	.9145	.9145	.9694	1.1706
18	.8048	.8779	.8962	1.0608	.9328	.9694	1.134
19	1.2986	1.3169	1.1523	1.1888	1.134	1.2254	1.3717
20	1.0974	1.4266	1.1706	1.2803	1.1888	1.2803	1.2803
21	1.134	1.134	1.1157	1.0791	1.1706	1.134	1.1706
22	1.0059	1.0242	1.0059	1.0059	1.0242	1.0608	1.0425
23	.9694	.9145	.8413	.8779	.9511	.9511	.8779
24	.823	.9145	.7682	.7682	.7682	.7865	.8413
Max	1.2986	1.4266	1.1706	1.2803	1.1888	1.2803	1.3717
Min	.7499	.8048	.7133	.7133	.695	.7499	.7865
Avg	.9061	.9648	.9183	.9252	.9290	.9282	1.0226

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 202 / 11KV KUCHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1888	1.2437	1.2437	1.1888	.1463	.1463	.128
2	1.1706	1.2254	1.2254	1.1523	.1463	.1463	.1097
3	1.1706	1.2071	1.2254	1.2437	.1463	.1646	.1097
4	1.134	1.2254	1.1888	1.3169	.1646	.1646	.128
5	1.1523	1.262	1.2803	1.3717	.1646	.1463	.1463
6	1.1523	1.4083	1.3717	1.4266	.1829	.1646	.1646
7	1.7375	1.7741	2.1216	1.5364	.2012	.1829	.2195
8	.1646	.2378	.1646	.2012	.1646	.2012	.2012
9	.128	.1829	.128	1.7741	2.3228	2.6337	.2012
10	.0914	.1097	.128	1.9936	2.6886	2.8898	.1646
11	.128	.1097	.1097	2.1399	2.7435	2.7984	.1829
12	.128	.128	.128	2.1399	2.4874	2.7618	.1829
13	.128	.128	.1646	1.829	2.3228	2.7069	.1829
14	.1097	.1463	.128	1.9753	2.3045	2.652	.1646
15	.128	.1463	.1097	2.0851	2.3045	2.5606	.1646
16	.1463	.1463	.128	2.0119	2.1216	2.3777	.1463
17	.1646	.1829	.1463	.1646	.2561	.1463	.1646
18		.1829	.1646	.1829	.2195	.1829	.1829
19	.2378	.1646	.1829	.2012	.2012	.2378	.2378
20	.2012	.1829	.2012	.2195	.2012	.2561	.2195
21	.1646	.1646	.2012	.2012	.2012	.2195	.2012
22	1.4083	1.3969	1.2803	.1646	.1463	.1463	1.5181
23	1.3717	1.3535	1.262	.1646	.1463	.1463	1.4632
24	1.2071	1.2803	1.262	1.2071	.1646	.1463	.128
Max	1.7375	1.7741	2.1216	2.1399	2.7435	2.8898	1.5181
Min	.0914	.1097	.1097	.1646	.1463	.1463	.1097
Avg	.6354	.6496	.6478	1.1622	.9229	1.0075	.2797

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 203 / 11 KV HINGANGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024	.3841	.4207	.4024	1.9589	2.1437	1.8088
2	.3841	.3841	.4024	.3841	1.9404	2.1253	1.7909
3	.3841	.3658	.4024	.3841	1.9404	2.1253	1.7909
4	.3841	.4024	.3841	.4207	2.0144	2.1068	1.8088
5	.4207	.439	.4207	.4572	2.3101	2.1437	1.8267
6	.4755	.4938	.4572	.4938	2.9199	2.1253	1.8625
7	.4755	.5121	.4755	.4755	2.4025	2.6242	2.0237
8	.4572	.4572	.4024	.4572	.4251	.4251	.4119
9	1.9753	1.9204	2.5057	.4572	.4066	.4298	2.6326
10	1.8473	2.1765	2.5972	.4572	.4251	.4119	2.5789
11	1.9753	2.1033	2.7435	.439	.4066	.4119	2.2028
12	1.9936	2.0485	2.4691	.4207	.3881	.4298	2.0595
13	2.0119	2.0668	2.4508	.439	.4066	.4298	2.2923
14	1.4449	2.0851	2.3594	.4024	.4435	.4298	2.3102
15	1.5546	2.1216	2.4874	.4024	.4435	.4298	2.5072
16	1.5546	2.1582		.4572	.4251	.4298	1.8983
17	.3841	.3841	.3841	.4207	.4066	.4119	.3582
18	.4024	.3841	.4024	.439	.4251	.4298	.3761
19	.439	.4024	.439	.4755	.4435	.5014	.5014
20	.4572	.4755	.4572	.4755	.462	.5373	.4656
21	.439	.4572	.439	.4755	.4435	.5014	.4656
22	.439	.4572	.439	.4755	2.1992	1.8804	.4656
23	.4024	.439	.4024	2.0119	2.1807	1.8446	.4298
24	.4024	.4024	.4207	.4207	1.9774	2.1622	1.8267
Max	2.0119	2.1765	2.7435	2.0119	2.9199	2.6242	2.6326
Min	.3841	.3658	.3841	.3841	.3881	.4119	.3582
Avg	.8794	.9800	1.0592	.5060	1.1581	1.1455	1.5290

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 204 / 11KV Ranjani Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9313	1.1283	1.1462	1.0745	.1612	.1612	.2149
2	.9313	1.0924	1.1283	1.0387	.1612	.1612	.197
3	.9671	1.0924	1.1283	1.1462	.1433	.1791	.197
4	.9671	1.1104	1.1641	1.2536	.197	.1791	.2328
5	1.0566	1.1999	1.2894	1.3969	.2507	.2328	.2686
6	1.2178	1.3969	1.5223	1.5223	.3582	.3403	.3582
7	2.0774	2.1491	2.0416	1.6118	.3761	.4298	.3403
8	.3403	.3224	.2865	.3045	.2507	.2686	.2865
9	.2328	.2328	.197	1.8088	2.0953	2.0774	.2328
10	.197	.2328	.197	1.9342	2.1312	2.3461	.3045
11	.1791	.2149	.1612	2.0237	2.1491	2.2207	.1612
12	.1612	.2328	.1791	2.0953	2.0416	2.1491	.1791
13	.1254	.2149	.1791	1.8267	1.9521	2.0595	.1612
14	.1075	.197	.1433	1.7013	1.9163	1.97	.1612
15	.1433	.1791	.1791	1.8267	1.8625	1.6297	.1612
16	.1433	.197	.2149	1.6476	1.7193	1.7372	.1612
17	.1791	.2149	.2149	.1791	.2865	.197	.1791
18	.2507	.2507	.2149	.2686	.2507	.2328	.2507
19	.3045	.3224	.2686	.3045	.2865	.3224	.3403
20	.3224	.3582	.3403	.3403	.3475	.3582	.3224
21	.2865	.3224	.3045	.3224	.3224	.3224	.3045
22	1.2536	1.3969	1.182	.2328	.2328	.2328	1.3432
23	1.2178	1.2536	1.1641	.197	.197	.2328	1.1641
24	.9492	1.1641	1.1641	1.1104	.1791	.1612	.2149
Max	2.0774	2.1491	2.0416	2.0953	2.1491	2.3461	1.3432
Min	.1075	.1791	.1433	.1791	.1433	.1612	.1612
Avg	.6059	.6865	.6671	1.1320	.8278	.8417	.3224

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 205 / 11KV Langerpeth Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012	.1463	.2378	.2012	2.5606	2.8532	2.9447
2	.1829	.1463	.2195	.1829	2.524	2.8532	2.9264
3	.1829	.128	.2012	.2378	2.652	2.8166	2.8898
4	.2195	.1463	.2378	.2743	2.7618	2.8166	2.8532
5	.2012	.2012	.2743	.3292	3.0727	2.963	2.8349
6	.2743	.3109	.4024	.3658	3.4385	3.0544	2.8166
7	.3841	.4207	.4207	.439	3.4202	3.4385	3.0727
8	.3292	.3292	.3109	.3841	.3475	.3109	.2926
9	2.5057	2.6337	2.7435	.3109	.3109	.2012	3.2922
10	2.8166	2.9813	2.7435	.2743	.2561	.1829	3.3836
11	2.8532	2.7435	3.1093	.2012	.2012	.1829	3.3471
12	2.8715	2.7069	2.7801	.1829	.1829	.1646	3.3653
13	2.5606	2.652	2.9264	.1463	.1463	.1646	3.2007
14	2.1765	2.6155	3.0178	.2012	.1646	.1646	3.1093
15	2.6886	2.5606	2.9264	.2195	.2012	.2012	2.963
16	2.5972	2.4508	2.652	.1646	.1829		2.652
17	.1646	.2012	.1646	.2195	.2378	.2195	.1646
18	.2195	.2378	.1829	.2743	.2743	.2561	.2012
19	.2743	.3475	.3109	.3109	.2926	.3841	.3475
20	.2743	.3658	.3292	.3475	.3292	.4207	.2926
21	.2561	.3292	.2561	.3109	.3292	.2926	.2926
22	.2012	.2743	.2561		2.9447	3.0361	.2561
23	.1829	.2743	.2378	2.7069	2.8898	2.9995	.2195
24	.2012	.1646	.2561	.2195	2.5972	2.8715	2.963
Max	2.8715	2.9813	3.1093	2.7069	3.4385	3.4385	3.3836
Min	.1646	.128	.1646	.1463	.1463	.1646	.1646
Avg	1.0341	1.0570	1.1332	.3698	1.3466	1.4282	2.1117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 206 / 11KV S.Factory Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3169	1.4083	.7499	1.5912	.2561	.2378	.2561
2	1.3352	1.39	.7499	1.5546	.2378	.2378	.2561
3	1.2986	1.39	.7316	1.5364	.2378	.2195	.2378
4	1.2986	1.4266	.823	1.6095	.2926	.2195	.2926
5	1.3535	1.4815	.9511	1.6461	.3292	.3109	.3658
6	1.4449	1.6827	1.2254	1.6827	.439	.439	.4572
7	2.1399	2.0668	1.7924	1.7558	.4755	.4755	.4938
8	.3475	.3658	.2743	.3292	.439	.4024	.4572
9	.3292	.3292	.2012		3.4568	2.8349	.4755
10	.2926	.3658	.2743		3.4934	3.3653	.439
11	.2561	.2926	.2378		3.3836	3.3288	.3658
12	.2743	.2012	.3109	2.652	3.3653	3.0544	.3109
13	.2012	.2012	.3292	2.8166	3.2922	3.1093	.3475
14	.1646	.2012	.3475		3.1459	3.1276	.3292
15	.2561	.1829	.3292	2.8532	2.9264	3.1459	.3841
16	.2926	.2012	.3475	3.091	3.0178	2.9813	.3292
17	.3292		1.0242	.3475	.3109	.2743	.3292
18	.3292		.3292	.3658	.2743	.3658	.3109
19	.3475		.3292	.3841	.4024	.4755	.3292
20	.3658		.3475	.4207	.4938	.5121	.3475
21	.3109	.2012	.3109	.3841	.4755	.4755	.3292
22	1.5912		1.6827	.3292	.3475	.3475	1.957
23	1.4998		1.6827	.2926	.3109	.2926	1.8839
24	1.2803	1.4266	.7682	1.6095	.2743	.2561	.2743
Max	2.1399	2.0668	1.7924	3.091	3.4934	3.3653	1.957
Min	.1646	.1829	.2012	.2926	.2378	.2195	.2378
Avg	.7773	.8230	.6729	1.3626	1.3199	1.2704	.4816

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 207 / 11 KV Express MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0532	.0183	.0549	.0549	.0732	.0549	.0549
2	.0354	.0183	.0549	.0366	.0549	.0549	.0549
3	.0354	.0183	.0549	.0366	.0549	.0366	.0366
4	.0177	.0183		.0366	.0549	.0366	.0366
5	.0177	.0183		.0366	.0549	.0366	.0366
6	.0177	.0183		.0366	.0549	.0366	.0366
7	.0354	.0183		.0366	.0549	.0366	.0366
8	.0177	.0549		.0366	.0732	.0549	.0732
9	.0914	.0732		.0366	.0732	.0549	.0732
10	.0732	.1097	.0914	.0366	.1097	.1097	.128
11	.0732	.128	.128	.1463	.1463	.128	.128
12	.0549	.1646	.1463	.1829	.1463	.1829	.1646
13	.0343	.1463	.1097	.1463	.1646	.1463	.128
14	.0366	.1646	.128	.1463	.1463	.128	.1097
15	.0366	.1097	.0914	.1097	.128	.1097	.0914
16	.0366	.0732	.0732	.0914	.1097	.1097	.0914
17	.0183	.128	.0732	.1097	.0914	.0914	.1097
18	.0183	.0732	.0549	.0914	.0732	.1097	.1097
19	.0366	.0914	.0549	.0914	.0732	.0732	.0732
20	.0549	.0914	.0914	.0914	.0732	.0914	.0732
21	.0366	.0732	.128	.0914	.0732	.128	.0716
22	.0732	.1097	.0914	.1097	.0914	.1097	.1097
23	.0549	.0914	.0914	.0914	.0732	.0914	.1097
24	.0532	.0366	.0732	.0732	.0732	.0732	.0732
Max	.0914	.1646	.1463	.1829	.1646	.1829	.1646
Min	.0177	.0183	.0549	.0366	.0549	.0366	.0366
Avg	.0422	.0770	.0884	.0815	.0884	.0869	.0838

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244007 / 33/11KV K.MAHANKAL

Feeder No / Name : 208 / 11KV Langerpeth Gao

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2279	.2454	.2279	.2103	.2279	.2629	.2279
2	.2103	.2279	.2103	.1753	.2103	.2279	.2279
3	.2103	.2103	.1928	.2279	.2103	.2279	.2103
4	.2103	.2454	.1753	.2629	.2629	.2279	.1928
5	.2454	.2804	.2629	.333	.3155	.298	.2279
6	.333	.333	.3856	.3681	.3506	.4207	.333
7	.4207	.4382	.4207	.4557	.4207	.4908	.4557
8	.298	.333	.3506	.3506	.333	.3856	.4207
9	.2804	.3506	.298	.333	.2804	.3856	.3681
10	.2804	.333	.2629	.2629	.298	.3681	.3155
11	.2454	.298	.2454	.2804	.333	.3506	.2629
12	.2279	.2804	.2454	.2454	.2804	.2804	.2804
13	.1928	.2279	.2279	.2454	.2279	.2454	.2454
14	.1402	.1928	.1578	.1928	.2103	.2103	.2279
15	.1052	.1928	.1402	.1578	.1928	.1753	.1753
16	.1578	.1753	.1928	.1753	.1928	.2629	.2279
17	.1928	.2103	.2279	.1928	.298	.2454	.298
18	.333	.2629	.2804	.3506	.3856	.2629	.3681
19	.4207	.4031	.4031	.3856	.4382	.4557	.4908
20	.4207	.4557	.3681	.4382	.5083	.5083	.4382
21	.3856	.4207	.3506	.4382	.4733	.3506	.4382
22	.3506	.3681	.3681	.3658	.4207	.3506	.4031
23	.3155	.298	.2629	.298	.3155	.2804	.2804
24	.2279	.2629	.2279	.2454	.2454	.2629	.2454
Max	.4207	.4557	.4207	.4557	.5083	.5083	.4908
Min	.1052	.1753	.1402	.1578	.1928	.1753	.1753
Avg	.2680	.2936	.2702	.2913	.3097	.3140	.3067

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 202 / 11KV Shirdhon Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0983	.0983	.1174	.1433	1.2136	1.2136	1.5083
2	.0995	.1006	.1174	.1448	1.1616	1.1919	1.491
3	.1029	.0838	.1017	.1267	1.0974	1.1218	1.4563
4	.1029	.0867	.1029	.1267	1.2346	1.2094	1.4217
5	.1029	.104	.12	.1448	1.2346	1.283	1.4217
6	.12	.1402	.156	.1509	1.3226	1.3032	1.3176
7	.2427	.197	.197	.2534	1.7772	1.8004	1.7804
8	.1907	.208	.1772	.2561	.208	.2126	.2075
9	1.5091	1.5432	1.6804	.2402	.1753	.1844	2.5377
10	1.4083	1.5939	2.079	.2774	.1509	.1991	2.5549
11	1.5261	1.5261	1.9113	.1943	.1734	.1629	2.5774
12	1.5939	1.4419	1.7772		.2012	.1772	1.8313
13	1.56	1.4083	1.8945	.1696	.2058	.1823	2.4478
14	1.4575	1.4754	1.9839	.1658	.2058	.1696	2.4981
15	1.3443	1.4419	1.8945	.1772	.1311	.1715	2.3807
16	1.1873	1.4586	1.8896	.1772	.1753	.181	1.9669
17	.128	.1463	.1006	.1772	.2279	.2149	.1448
18	.128	.1829	.1526	.1772	.2534	.1296	.1448
19	.16	.2218	.2172	.2126		.181	.1791
20	.1966	.2452	.2195	.2587	.2743	.2195	.2149
21	.1638	.2263	.1829	.2378	.2561	.2012	.2218
22	.1311	.1802	.1848		1.283	1.5261	.1478
23	.0983	.1658	.1448	1.2136	1.2269	1.4575	.1463
24	.0983	.0983	.1326	.1433	1.262	1.2483	1.4575
Max	1.5939	1.5939	2.079	1.2136	1.7772	1.8004	2.5774
Min	.0983	.0838	.1006	.1267	.1311	.1296	.1448
Avg	.5729	.5989	.7306	.2349	.6718	.6643	1.3357

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 203 / 11KV Borgaon Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1132	.132	.1132	.1509	.1509	.1509
2	.0934	.0943	.1132	.0943	.132	.132	.132
3	.0934	.0943	.1132	.0943	.132	.1132	.112
4	.0943	.1132	.132	.0943	.1509	.1132	.0934
5	.1132	.1132	.1509	.1132	.1698	.1509	.0943
6	.132	.1509	.1886	.132	.1886	.1698	.0943
7	.1698	.2263	.2075	.1663	.2054	.1886	.1663
8	.1698	.1698	.2012	.168	.1509	.2054	.1698
9	.132	.1886	.1886	.1307	.2263	.1867	.1294
10	.1294	.168	.168	.1417	.1307	.168	.1848
11		.168	.1448	.1829	.2054	.112	.1848
12	.128	.1478	.1267	.1646	.1848	.132	.1478
13	.1307	.1478	.1132	.132	.3734	.0943	.112
14	.1307	.1294	.0943	.1109	.1132	.0943	.0953
15	.1132	.1307	.0914	.1307	.1478	.0943	.0943
16	.1143	.1494	.1109	.1109	.1307	.1086	.0566
17	.1509	.1494	.1109	.128	.1086	.1086	.1132
18	.1509	.1886	.1109	.1612	.1448	.1267	.1509
19	.1698	.2241	.2263	.2587	.2402	.181	.2075
20	.2075	.2452	.2075	.2263	.2263	.2241	.2263
21	.1886	.2263	.2075	.2263	.2075	.2075	.2075
22	.1509	.1886	.1698	.1886	.1886	.1886	.1698
23	.1509	.1509	.132	.1698	.1698	.1698	.1509
24	.112	.1132	.132	.1132	.1698	.1698	.1698
Max	.2075	.2452	.2263	.2587	.3734	.2241	.2263
Min	.0934	.0943	.0914	.0943	.1086	.0943	.0566
Avg	.1364	.1580	.1489	.1480	.1770	.1496	.1422

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 204 / 11KV Borgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.1509	.1886	.2075	1.6356	1.7166	1.7976
2	.2012	.1509	.2075	.1886	1.587	1.6842	1.8299
3	.1886	.1509	.2263	.1886	1.5364	1.6164	1.7814
4	.1886	.1886	.2263	.2075	1.5524	1.6964	1.5844
5	.2075	.2075	.2641	.2263	1.5844	1.7284	1.5844
6	.2829	.2829	.2987	.2829	1.6129	1.7604	1.5524
7	.415	.3395	.3881	.3584	2.2138	2.3967	1.8947
8	.3206	.2801	.2957	.3018	.2987	.3361	.2801
9	1.692	1.7284	1.8138	.3395	.3547	.3734	2.769
10	1.7029	1.8027	1.8976	.2801	.4108	.415	2.9504
11	1.6204	1.7029	1.8185	.3734	.3921	.3772	2.9797
12	1.5741	1.7185	1.8827	.3361	.3734	.3734	3.2065
13	1.5432	1.6821	1.9372	.3206		.3734	3.1367
14	1.5432	1.5432	1.692	.2641	.3361	.3547	2.5126
15		1.4529	1.9766	.3018	.3772	.3734	2.5926
16	1.2654	1.3435	1.8364	.3018	.3772	.4294	2.7692
17	.1433	.1509	.2402	.2987	.3547	.4294	.1829
18		.2452	.2561	.2987	.3511	.4066	.2054
19		.3547	.3206	.3547	.3547	.4108	.2801
20	.1509	.3326	.3206	.3395	.3361	.3772	.3395
21	.1509	.2957	.3018	.2957	.2987	.3206	.2829
22	.132	.2614	.2641	1.6762	1.8884	1.8564	.2452
23	.1132	.2241	.2452	1.5971	1.7166	1.7711	.1886
24	.2263	.1132	.1886	.2075	1.6644	1.8023	1.7924
Max	1.7029	1.8027	1.9766	1.6762	2.2138	2.3967	3.2065
Min	.1132	.1132	.1886	.1886	.2987	.3206	.1829
Avg	.6614	.6960	.7953	.3978	.9395	.9741	1.6141

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 205 / 11KV Shivganga Gao

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1417	.1075	.1307	.1387	.1791	.1663	.1663
2	.1433	.1086	.1132	.1214	.1612	.1463	.1646
3	.128	.1086	.1132	.1214	.1417	.128	.1612
4	.128	.0905	.1132	.1214	.1402	.1267	.1772
5	.1463	.112	.132	.1387	.1578	.1448	.1772
6	.1646	.112	.132	.1387	.1772	.1612	.1772
7	.132	.132	.132	.132	.1698	.1509	.128
8	.1109	.132	.0791	.1086	.1417	.0972	.0934
9	.0934	.112	.0886	.1214	.1132	.1132	.0876
10	.1132	.1109	.124	.1494	.0943	.1698	.1063
11	.132	.0924	.1509	.1595	.1457	.1509	.1448
12	.132	.0914	.1187	.1696	.2054	.2241	.1478
13	.0943	.0905	.1463	.132	.1509	.0943	.1402
14	.0943	.1109	.0747	.2012	.1772	.1629	.1134
15	.0739	.1307	.0943	.1387	.2263	.1663	.1475
16	.0543	.1698	.0701	.1402	.1448	.1663	.1475
17	.0934	.1509	.0943	.096	.176	.1478	.1638
18	.1132	.1307	.0716	.1357	.1132	.1509	.1928
19	.1509	.1307	.1109	.1509	.1494	.1509	.181
20	.1886	.1448	.1646	.1991	.2054	.2075	.1463
21	.1509	.181	.181	.1791	.181	.1867	.1463
22	.1448	.1478	.1612		.1629	.1829	.1433
23	.1267	.1494	.1387	.1629	.1646	.1867	.1254
24	.1417	.1254	.1307	.8145	.2012	.1646	.1867
Max	.1886	.181	.181	.8145	.2263	.2241	.1928
Min	.0543	.0905	.0701	.096	.0943	.0943	.0876
Avg	.1247	.1239	.1194	.1727	.1617	.1561	.1486

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 206 / 11KV Shirdhon Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.1494	.1509	.1509	.2241	.2054	.168
2	.112	.132	.1509	.1509	.1867	.1886	.168
3	.112	.132	.132	.1509	.1886	.1698	.168
4	.1307	.1509	.1307	.1698	.1698	.1698	.1494
5	.1494	.1698	.1494	.1698	.1886	.2075	.1494
6	.1867	.2054	.2218	.1886	.1886	.1886	.2054
7	.2587	.2587	.2587	.2561	.2218	.2218	.2402
8	.2715	.2172	.2378	.2402	.2303	.2149	.2012
9	.197	.181	.1829	.181	.1772	.2401	.1829
10	.1132	.197	.1886	.1677	.2035	.208	.1595
11	.1509	.1949	.1715	.1423	.2012	.218	.1578
12	.1886	.2126	.1543	.1509	.1844	.2012	.1886
13	.1791	.2103	.1612	.213	.2035	.2035	.1791
14	.1433	.1772	.1595	.1402	.1734	.1417	.1791
15	.1448		.1734		.1543	.124	.1612
16	.1387	.1433	.1772	.156	.1578	.1612	.1612
17	.1907	.1629	.1734	.1543	.1265	.1753	.1829
18	.208	.2012	.1865	.1865	.1734	.2254	.2561
19	.2507	.2743	.2743	.2743	.3142	.2715	.2587
20	.2926	.3174	.3258	.2957	.2801	.3142	.2987
21	.2378	.2801	.2801	.2957	.2587	.2987	.2801
22	.2012	.2452	.2427	.2614	.2241	.2801	.2452
23	.168	.2263	.1867	.2241	.2033	.2054	.2075
24	.1307	.1494	.1886	.1509	.2427	.2241	.1867
Max	.2926	.3174	.3258	.2957	.3142	.3142	.2987
Min	.112	.132	.1307	.1402	.1265	.124	.1494
Avg	.1786	.1995	.1941	.1944	.2032	.2108	.1973

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 207 / 11KV Alkud Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.4961	.4534	.5441	.1698	.1698	.1698
2	.2401	.4961	.4049	.5121	.1698	.1509	.1698
3	.2401	.4641	.4049	.4961	.1509	.1509	.1698
4	.2561	.5121	.4428	.5121	.1509	.1698	.1886
5	.2721	.6154	.506	.5571	.2075	.1886	.1886
6	.2721	1.0364	.6401	.6062	.2641	.2641	.2641
7	.5344	1.166	.8962	.9231	.1698	.2829	.3018
8	.132	.2263	.2263	.2263	.2452	.2241	.2218
9	.1132	.1698	.1578	1.0322	1.4737	1.3927	.2075
10	.0943	.1494	.1109	1.2186	1.6712	1.6876	
11	.112	.1307	.1307	1.3283	1.6842	1.6518	.168
12	.1307	.1294	.0934	1.1248	1.6032	1.7814	.168
13	.1307	.1097	.1307	1.1873	1.5684	1.5339	.1663
14	.1307	.0924	.132	1.2003	1.5524	1.6804	.1294
15	.1307	.0934	.1494	1.3599	1.668	1.7124	.1463
16	.1307	.1132	.1307	1.3599	1.6549	1.873	.1463
17	.1494		.1294	.1086	.1402	.2241	.1848
18	.168	.1867	.112	.1294	.1562	.1867	.1867
19	.1867	.2378	.1886	.2241	.2587	.2427	.2241
20	.1886	.2641	.2263	.2263	.2801	.2641	.2829
21	.1509	.2075	.2075	.2263	.2641	.2263	.2452
22	.6241	.5693	.6226	.1886	.1886	.2075	.9503
23	.5761	.5441	.5601		.1698	.1886	.9012
24	.2561	.5441	.4801	.5441	.1886	.1886	.1886
Max	.6241	1.166	.8962	1.3599	1.6842	1.873	.9503
Min	.0943	.0924	.0934	.1086	.1402	.1509	.1294
Avg	.2282	.3719	.3140	.6885	.6688	.6935	.2596

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244035 / 33/11KV Borgaon

Feeder No / Name : 401 / 33 KV JOLLY BOARD
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER MIDC EQUIVALENT
HAVING WEEKLY STAGGERING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.679	.1029	.679	.5093	.463	.5658	.9054
2	.7356	.1029	.5658	.5658	.463	.5144	.7922
3	.8488	.1029	.5658	.5658	.5144	.5658	.7356
4	.7356	.1029	.5093	.7356	.5658	.5658	.9054
5	.5658	.1029	.6224	.7356	.463		.8488
6	.5093	.1543	.5658	.7922	.823	.6173	.9054
7	.3395	.1543	.5658	.5093	.7202	.7202	.5093
8	.3395	.1029	.5093	.7356	.4115	.463	.6224
9	.2829	.1543	.7922	.463	.7716	.7922	.9054
10	.2058	.2263	.9619	.7202	.823	.7922	.823
11	.2058	.2829	.9054	.5658	.8745	.7356	1.0288
12	.2058	.3395	.6224	.7716	.7716	.8488	1.1317
13	.1029	.4527	.5093	.2572	.463	.7356	1.0288
14	.1029	.4527	.5658	.463	.9259	.9054	.8745
15	.1029	.9054	.6224	.463	.6173	.5658	.7716
16	.1029	.6224	.2829	.5144	.5144	.3961	.7202
17	.1029	.7922	.3395	.5658	.7716	.7922	.6173
18	.1029	.9054	.8488	.6687	.7202	.7922	.6173
19	.1029	.5658	.7356	.5658	.5144	.7922	.5658
20	.1029	.5658	.7356	.5144	.7202	.5658	.5658
21	.1029	.5658	.5658	.5144	.463	.5658	.7202
22	.1029	.679	.7922	.823	.5487	.8488	1.0288
23	.1029	.6224	.5093	.7202	.5658	.5658	.8745
24	.7356	.1029	.6224	.5093	.5658	.6173	.679
Max	.8488	.9054	.9619	.823	.9259	.9054	1.1317
Min	.1029	.1029	.2829	.2572	.4115	.3961	.5093
Avg	.3134	.3817	.6248	.5937	.6273	.6663	.7991

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 201 / 11Kv Dudhebhavi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.763	.8573		.1886	.1865	.1677
2	.763	.8383	.9835		.1867	.1696	.1696
3	.6706	.6783	.8573		.1715	.1696	.1844
4		.7545	1.0059		.1715	.1844	.1865
5		.9326	1.3565		.2401	.2012	.2035
6		1.1736	1.5261		.2401	.218	.2012
7	.5935	1.1869	1.6956		.2572	.218	.2012
8	.1696	.1677	.2012	1.0631	.2743	.2012	.1677
9	.1677	.1696	.1509	1.046	1.166	1.0898	.1844
10	.1509	.1715	.1677	1.0631		1.0898	.1677
11	.1509	.1543	.1865	1.046		1.1736	.1677
12	.1543	.1543	.1677	1.0288		1.1736	.1509
13	.1509	.1357	.1844	1.0288		1.0395	.1509
14	.1677	.1372	.1677	.8573		1.0059	.1509
15		.1372		.8916		1.0059	.1526
16		.1543		.8402		1.0059	
17	.1865		.1677	.1928		.1865	.1844
18	.1696		.1526	.2601		.2035	.2035
19	.1677		.1677	.2743		.218	.1844
20	.1865		.2035	.2743	.2347	.218	.2035
21	.1677			.2572	.2347	.2012	.1844
22	.503			.2229	.218	.2012	.8383
23	.5935			.1886	.2012	.2035	.8478
24	.5087	.6706	.8383	.7287	.2054	.1844	.1865
Max	.763	1.1869	1.6956	1.0631	1.166	1.1736	.8478
Min	.1509	.1357	.1509	.1886	.1715	.1696	.1509
Avg	.3356	.4929	.5810	.6626	.285	.4895	.2365

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 202 / 11KV Nagaj
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3561	.3052	.4694	.3353	1.2136	.8383	1.0898
2	.3353	.3353	.4748	.3222	1.2323	.8383	1.0395
3	.3052	.3222	.4641	.3353	1.251	.8048	1.0898
4	.3018	.3353	.4641	.373	1.1145	.8383	1.1736
5	.3391	.373	.5426	.4527	2.1472	1.2071	1.2071
6	.4024	.4024	.5533	.4409	1.9719	1.5089	1.3413
7	.4409	.407	.547	.4527	2.0062	1.7604	1.6095
8	.4191	.4239	.503	.3944	.5316	.5365	.3688
9	1.2574	.8383	1.0174	.3944	.463	.5365	1.6766
10	1.0562	.8059	1.0227	.3772		.5365	1.7604
11	1.0174	.8745	1.0513	.3772		.5087	1.8652
12	.8383	.8059	1.0682	.3944		.5087	1.6766
13	.6706	.8059	1.0174	.3772		.5365	1.6108
14	.7461	.823	.8817	.4031		.5533	1.5769
15		.8745		.3944		.57	1.5261
16		.9259		.4115		.57	
17	.3391		.3052	.5144		.5868	.4748
18	.3018		.3185	.7716	.6371	.6036	.4191
19	.3391		.3353	.8402	.6371	.6036	.5087
20	.3018		.3391	.8745	.6706	.6443	.5365
21	.3391		.3018	.8916	.5868	.6443	.6036
22	.3018		.3222	1.1488	.8718	1.1736	.4527
23	.3391			1.1488	.9221	1.1736	.5087
24	.3353	.3185	.4748	.3052	1.1488	.8718	1.0898
Max	1.2574	.9259	1.0682	1.1488	2.1472	1.7604	1.8652
Min	.3018	.3052	.3018	.3052	.463	.5087	.3688
Avg	.5038	.5869	.5940	.5305	1.0879	.7898	1.0959

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 203 / 11KV Chorochi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	.9012
Max	.9012
Min	.9012
Avg	.9012

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 204 / 11KV Dhalewadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8478	.763	1.0288	.6706	.3944	.3185	.3856
2	.6783	.8383	1.0288	.5935	.3944	.3018	.3856
3	.8383	.763	1.0288	.6706	.3772	.3052	.3856
4	.6783	.8383	1.3717	.763	.4294	.3018	.4024
5	.7545	1.1869	1.5261	.8383	.4668	.3353	.4359
6	1.0174	1.3413	2.2291	1.1869	.4458	.4359	.503
7	.8383	1.5089	2.1365	1.3413	.463	.503	.4359
8	.1677	.2035	.1844	1.5947	.4801	.4359	.503
9	.1844	.1844	.1865	1.5432	2.0748	2.3807	.2204
10	.1865	.298	.1844	1.5775		2.4034	.2204
11	.1696	.2915	.1844	1.5604		2.4813	.2204
12	.1677	.2915	.1844	1.6289		2.5484	.2204
13	.1658	.2743	.2515	1.5947		2.431	.218
14	.1677	.2743	.2035	1.7147		2.1795	.2204
15		.2743		1.7661		2.2634	.218
16		.2743		1.8004		2.2634	
17	.1341		.052	.4287	.2543	.3688	.2347
18	.1526		.0686	.4458	.2883	.4239	.2374
19	.1677		.0693	.463	.3688	.5365	.2713
20	.1696		.0857	.4908	.4694	.503	.2683
21	.1844		.1029	.4801	.2683	.4694	.2515
22	.763		.6001	.4115	.3052	.4359	1.0174
23	.7545			.4115	.3222	.4024	1.0059
24	.8383	.6706	1.0288	.8573	.4207	.3222	.4024
Max	1.0174	1.5089	2.2291	1.8004	2.0748	2.5484	1.0174
Min	.1341	.1844	.052	.4115	.2543	.3018	.218
Avg	.4558	.6045	.6541	1.0347	.4837	1.0563	.3767

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 205 / 11KV Chorochi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.104	.1214	.1886	.1387	.1543	.1387	.1715
2	.1214	.1029	.1886	.1372	.1372	.1214	.1734
3	.104	.104	.2229	.1214	.1372	.1214	.1734
4	.1029	.12	.2401	.1214	.1372	.1372	.1907
5	.104	.156	.2743	.104	.1543	.1734	.208
6	.1543	.1372	.2743	.12	.1886	.2401	.2229
7	.1543	.156	.2915	.156	.2058	.2743	.2058
8	.1715	.1387	.1886	.1543	.2058	.2254	.208
9	.1715	.1372	.1715	.1372	.168	.1886	.3086
10	.1543	.12	.1865	.1372		.1886	.3086
11	.156	.12	.1696	.1402		.156	.3258
12	.1543	.12	.2058	.1387		.156	.1543
13	.1372	.12	.1715	.1387		.1372	.1372
14	.1372	.12	.0514	.1214		.1372	.1372
15		.12		.1372		.1387	.1372
16		.1372		.12		.1387	
17			.1715	.1734	.1387	.1734	.156
18			.1886	.1886	.1734	.1907	.1372
19			.2229	.2058	.208	.2229	.156
20			.208	.2058	.2229	.208	.1715
21			.1886	.2058	.1734	.1907	.1886
22			.1734	.1543	.1715	.1907	.1715
23				.1543	.1543	.1734	.1734
24	.1543	.1387	.1886	.1543	.168	.1372	.1715
Max	.1715	.156	.2915	.2058	.2229	.2743	.3258
Min	.1029	.1029	.0514	.104	.1372	.1214	.1372
Avg	.1387	.1276	.1984	.1486	.1705	.1733	.1908

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244040 / 33/11KV DHALGAON

Feeder No / Name : 206 / 11 KV Dudhebhavi Gao

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.208	.2229	.1886	.2572	.2427	.2743
2		.2058	.2229	.1734	.2401	.2427	.2601
3		.1907	.2229	.1734	.2401	.2401	.2601
4	.1372	.2058	.2401	.1907	.2401	.2427	.2774
5	.1387	.2254	.2743	.1715	.2572	.2774	.3086
6	.1543	.2401	.2915	.2401	.2743	.3086	
7	.208	.3121	.2915	.3258	.2915	.3467	.3086
8	.2401	.3294	.3086	.2915	.2915	.3086	.2915
9	.2229	.2743	.2915	.2915	.3258	.2572	.2572
10	.2058	.1907	.2915	.2743		.2229	.2229
11	.2058	.1886		.2743		.1907	.2229
12	.2058	.2058	.1886	.2572		.1907	.2058
13	.2058	.2058	.1715	.2401		.1715	.2229
14	.2058	.2229	.1715	.2572		.1715	.2401
15		.2058	.2401	.2401		.1907	.2401
16		.2229		.2804		.1907	
17	.2601			.3258	.2427	.2427	.2427
18	.2401		.208	.3772	.2915	.3258	.2774
19	.3258		.2401	.3944	.3772	.4287	.2743
20	.3467		.3258	.3944	.3944	.3988	.3121
21	.3258			.3944	.3429	.3641	.3429
22	.3121		.2774	.3734	.3121	.3121	.2915
23	.2743			.2801	.2774	.2947	.3258
24	.2401	.2427	.2229	.2229	.2572	.2572	.2743
Max	.3467	.3294	.3258	.3944	.3944	.4287	.3429
Min	.1372	.1886	.1715	.1715	.2401	.1715	.2058
Avg	.2331	.2280	.2476	.2764	.2890	.2675	.2697

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 201 / 11KV Shelkewadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5121		.7907	.9172	.2452	.1886	.2195
2	.5182	.7045	.7907	.9488	.2452	.1886	.2172
3	.5243	.6554	.8907	1.0526	.2641	.1886	.2149
4	.6401	.6554	.9393	1.1336	.3018	.2075	.3258
5	.852	.8551	1.0978	1.2125	.415	.3584	.394
6	.9717	1.3077	1.3413	1.3413	.5658	.6036	.5373
7	1.7695	2.0454	2.1216	1.5927	.6036	.6036	.6401
8	.4298	.4527	.3921	.3921	.4108	.3921	.4344
9	.2686	.3772	.2801	1.6032	.3856	1.7695	.2926
10	.197	.2801	.2427	1.704	1.6575	1.8842	.2715
11	.1991	.2402	.2033	1.6712	1.8564	1.9725	.2772
12	.1753	.2195	.2033	1.6221	1.8842	2.0222	.2218
13	.132	.2195	.181	1.4255	1.8623	1.8023	.181
14	.2172	.2303	.1848	1.5581	1.8351	1.8564	.2103
15	.1753	.2012	.1848	1.5912	1.7695	2.3868	.2172
16	.1494	.2012	.2378	1.4251	1.757	2.1382	.2033
17		.2427	.2801	.0191	.2534	.3109	.2452
18	.2402	.3174	.3174	.2987	.3142	.362	.3206
19	.3734	.3734	.3547	.3961	.4108	.439	.3961
20	.3772	.3961	.3961	.4527	.4294	.4298	.415
21	.3395	.3584	.3961	.3961	.3921	.2172	.3584
22	.8139	1.0082	1.1633	.3206	.3206	.3224	1.0688
23	.7499	.933	.9762	.2829	.2641	.3077	.9762
24	.5761	.7449	.7907	.9172	.2641	.2263	.2865
Max	1.7695	2.0454	2.1216	1.704	1.8842	2.3868	1.0688
Min	.132	.2012	.181	.0191	.2452	.1886	.181
Avg	.4870	.5661	.6149	1.0114	.7795	.8824	.3719

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 202 / 11 KV GATHNANDRE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0895	.0924	.0924	.0934	.4062	.3612	.4049
2	.0914	.0739	.0924	.0934	.4012	.3506	.4001
3	.0886	.0754	.0934	.0934	.4012	.3048	.4096
4	.128	.0754	.1307	.1307	.4218	.3048	.4641
5	.1646	.1132	.1698	.1698	.4374	.4321	.5182
6	.2012	.2075	.2075	.1886	.7209	.6401	.6226
7	.2149	.3018	.2641	.2452	1.085	1.1498	.7042
8	.2149	.2263	.1867	.1886	.1886	.168	.1417
9	.3932	.5218	.5937	.1494	.1509	.1509	.7209
10	.3841	.5218	.6405	.0924	.1109	.0566	.7682
11	.4858	.4967	.6554	.0537	.0934	.1075	.6622
12	.4515	.4515	.6481	.0924	.1086	.0716	.6706
13	.4572	.5117	.679	.0747	.0895	.0686	.5721
14	.4778	.5719	.6874	.0732	.0905	.0709	.5428
15	.4816	.587	.6718	.0532	.0905	.0876	.5213
16	.2751	.5093	.6093	.1097	.0724	.0848	.5182
17	.1052	.0934	.112	.1075	.1052	.0867	.1132
18	.1478	.1307	.1307	.128	.1097	.1097	.132
19	.1867	.1494	.168	.1698	.168	.1433	.1698
20	.1698	.1698	.1886	.1886	.1867	.1463	.1698
21	.1509	.1307	.1509	.1509	.1698	.1448	.1509
22	.0747	.112	.1132	.5898	.5937	.5441	.1132
23	.1109	.0914	.112	.5182	.4365	.4801	.1109
24	.1063	.0924	.0924	.0934	.4218	.3913	.4481
Max	.4858	.587	.6874	.5898	1.085	1.1498	.7682
Min	.0747	.0739	.0924	.0532	.0724	.0566	.1109
Avg	.2355	.2628	.3121	.1603	.2942	.2690	.4187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 203 / 11KV Raiwadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0543	.0377	.0566	.0381	.2572	.2934	.2294
2	.0537	.0189	.0566	.0381	.2606	.2787	.2241
3	.0537	.0189	.0566	.0381	.2751	.2526	.2241
4	.0543	.0377	.0943	.0762	.2934	.2378	.3041
5	.0732	.0747	.132	.1143	.3311	.2286	.3605
6	.128	.132	.1715	.1334	.5761	.5312	.4161
7	.1254	.1509	.1698	.132	.6093	.7125	.4481
8	.0914	.132	.1132	.0943	.1132	.1132	.1109
9	.2881	.3185	.4572	.0754	.0943	.056	.5898
10	.3841	.3521	.4725	.0747	.0934	.0566	.5121
11	.3841	.3814	.4199	.0566	.0566	.056	.4967
12	.362	.3525	.4054		.0566	.0566	.4666
13	.362	.3286	.362	.0366	.0747	.056	.4666
14	.3765	.2858	.4214	.0381	.0747	.0566	.4161
15	.2143	.3668	.4572	.0549	.0747	.0754	.3961
16	1.0669	.4054	.4254	.0554	.056	.0566	.4401
17	.056	.0566	.0754	.056	.0532	.056	.0566
18	.0566	.0754	.0762	.056	.0747	.0914	.0754
19	.0943	.0943	.0953	.1132	.1132	.1063	.0943
20	.0943	.1132	.0943	.1132	.0943	.1075	.0943
21	.0943	.0953	.0953	.1132	.0943	.1075	.0943
22	.1494	.0754	.0754	.4374	.3715	.3437	.0762
23	.0566	.0754	.0572	.3506	.3227	.3201	.0566
24	.0532	.0377	.0754	.0572	.2715	.2934	.2622
Max	1.0669	.4054	.4725	.4374	.6093	.7125	.5898
Min	.0532	.0189	.0566	.0366	.0532	.056	.0566
Avg	.1969	.1674	.2048	.1023	.1955	.1893	.2880

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 204 / 11 KV Shelkewadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1433	.132	.1509	.1509	.1715	.1698	.1791
2	.1448	.132	.1509	.1509	.1715	.1509	.1829
3	.1433	.112	.1509	.1509	.1715	.1509	.181
4	.181	.112	.2263	.2263	.1905	.1886	.2195
5	.2561	.168	.3206	.2858	.2286	.2452	.2534
6	.362	.3395	.3961	.3429	.3772	.3206	.3696
7	.439	.3395	.4108	.4338	.3429	.3395	.3475
8	.3045	.2829	.2614	.3326	.2427	.2987	.2896
9	.2328	.2427	.2378	.1991	.2452	.2378	.2561
10	.2353	.2075	.168	.1949	.2075	.197	.181
11	.2012	.1867	.168	.1448	.2075	.1867	.1463
12	.1867	.1612	.168	.1307	.1829	.1867	.1478
13	.1478	.1791	.1494	.1663	.2054	.1886	.1663
14	.1478	.1646	.1494	.1334	.168	.1886	.1478
15	.1294	.168	.112	.1334	.1307	.1886	.1478
16	.1267	.1646	.1478	.1509	.1132	.1698	.1448
17		.2033	.1478	.2263	.1848	.2033	.181
18	.2012	.2614	.2218	.2378	.2378	.2896	.2561
19	.3584	.3361	.3142	.3395	.3547	.3658	.3696
20	.3584	.3734	.3734	.3429	.3584	.3658	.3361
21	.3206	.3395	.3395	.3239	.3018	.3439	.3174
22	.2263	.2829	.2641	.2477	.2641	.2686	.2614
23	.1698	.2075	.2075	.2096	.1886	.2328	.1886
24	.1417	.1509	.1698	.1886	.1715	.1698	.2012
Max	.439	.3734	.4108	.4338	.3772	.3658	.3696
Min	.1267	.112	.112	.1307	.1132	.1509	.1448
Avg	.2243	.2186	.2253	.2268	.2258	.2353	.2280

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 205 / 11 KV GHATNANDRE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724	.0747	.0762	.0762	.0943	.0754	.0924
2	.0716	.056	.0762	.0762	.0943	.0754	.0914
3	.0724	.056	.0762	.0762	.0943	.0754	.0905
4	.1463	.0566	.1494	.1143	.0943	.0943	.1646
5	.181	.0943	.1867	.1698	.132	.132	.2012
6	.2149	.2263	.2263	.2263	.2286	.2075	.2353
7	.2303	.2641	.2987	.2452	.2641	.2263	.2715
8	.1829	.2075	.168	.1886	.1698	.1698	.1829
9	.181	.1698		.1294	.1698	.132	.1109
10	.0914	.0943	.1494	.0924	.1334	.112	.0914
11	.1097	.0934	.1109	.0747	.0566	.0934	.1109
12	.0754	.0943	.0924	.0943	.0924	.056	.0914
13	.0362	.0924	.0739	.0943	.0905	.0934	.0754
14	.0543	.1307	.112	.1132	.0724	.0747	.0914
15	.0739	.0924	.0747	.0373	.056	.0747	.0739
16	.1463	.0934	.0934	.0924	.1109	.0747	.0924
17	.112	.112	.1494	.0943	.1109	.0934	.132
18	.1448	.1494	.1848	.1494	.181	.1646	.1698
19	.2402	.1867	.2033	.1886	.2218	.2012	.2075
20	.2241	.1886	.2075	.2263	.2054	.1791	.2241
21	.1698	.1886	.1886	.2075	.1867	.181	.2075
22	.132	.1509	.1509	.1524	.132	.1595	.132
23	.0943	.1143	.0953	.1132	.0943	.0895	.0953
24	.0724	.0754	.0762	.0762	.0943	.0754	.1132
Max	.2402	.2641	.2987	.2452	.2641	.2263	.2715
Min	.0362	.056	.0739	.0373	.056	.056	.0739
Avg	.1304	.1276	.1400	.1295	.1325	.1213	.1395

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 206 / 11KV Raiwadi Gao

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0537	.0373	.0377	.0181	.0189	.0377	.0358
2	.0543	.0377	.0377	.0181	.0189	.0189	.0362
3	.0549	.0189	.0377	.0181	.0189	.0189	.0366
4	.0543	.0189	.0566	.037	.0189	.0377	.0362
5	.0537	.0377	.0566	.056	.0189	.0566	.0554
6	.0543	.0566	.0754	.0762	.0762	.0566	.0724
7	.0895	.0754	.0754	.0943	.0953	.0754	.2896
8	.0914	.1132	.0739	.0754	.0943	.0377	.0732
9	.0537	.0566	.0549	.0554	.0191	.0377	.0543
10	.0537	.056	.0549	.0537	.0566	.0373	.0537
11	.0724	.0543	.0509	.0566	.0554	.0373	.0532
12	.0554	.0526	.0358	.0537	.0358	.0362	.0503
13	.056	.0354	.0358	.0716	.0526	.0351	.0514
14	.056	.0362	.0537	.0543	.0543	.0358	.0339
15	.0377	.0537	.0362	.0532	.0549	.0724	.0354
16	.0362	.0537	.0351	.052	.0373	.0532	.0351
17	.056	.0732	.0351	.0549	.0537	.0537	.0543
18	.0543	.0747	.0747	.056	.056	.0732	.0739
19	.0739	.0754	.0747	.0754	.0754	.0905	.0934
20	.0566	.0934	.0924	.0754	.0754	.0895	.0754
21	.0566	.0739	.0747	.0943	.0566	.0914	.0762
22	.0377	.0549	.0566	.0754	.0377	.0732	.0377
23	.0373	.0354	.037	.0377	.0373	.0732	.037
24	.0532	.0373	.0377	.0362	.0189	.0377	.0543
Max	.0914	.1132	.0924	.0943	.0953	.0914	.2896
Min	.0362	.0189	.0351	.0181	.0189	.0189	.0339
Avg	.0564	.0547	.0538	.0562	.0474	.0528	.0627

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 207 / 11KV Jakhapur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.08	.1227	.1341	.1006	.0381	.0373	.0358
2	.081	.1086	.1341	.1006	.0381	.0373	.0362
3	.08	.1086	.1341	.1341	.0381	.0187	.0366
4	.1107	.1086	.1989	.1509	.0572	.0187	.0716
5	.1638	.1753	.2486	.1823	.0943	.0373	.0905
6	.1898	.3086	.2949	.1989	.1509	.0754	.1097
7	.4641	.5243	.3277	.2622	.1509	.0943	.1097
8	.0914	.1307	.112	.0905	.1509	.112	.0914
9	.0543	.0747	.0934	.2949	.4475	.3768	.0543
10	.0358	.1227	.0747	.3113	.3812	.426	.0732
11	.0362	.0934	.0377	.3113	.3315	.3441	.0377
12	.0724	.0754	.0566	.3441	.2984	.3185	.0189
13	.0747	.0377	.0747	.2949	.3149	.3185	.0377
14	.056	.0566	.0747	.3315	.2984	.3521	.0566
15	.0566	.0747	.0747	.3647	.3149	.4424	.0566
16	.0566	.0934	.112	.3113	.2984	.4096	.0754
17	.0934	.0747	.0934	.0943	.112	.056	.0754
18	.0934	.0754	.0747	.0943	.112	.0914	.0747
19	.0747	.0566	.0566	.132	.0934	.128	.0747
20	.0747	.0754	.0747	.0943	.0747	.1086	.0747
21	.056	.0754	.0566	.0943	.0747	.0724	.0747
22	.2058	.218	.1677	.0572	.056	.0543	.1006
23	.1402	.1844	.1174	.0381	.056	.0537	.0838
24	.0791	.1227	.1509	.1006	.0381	.0373	.0366
Max	.4641	.5243	.3277	.3647	.4475	.4424	.1097
Min	.0358	.0377	.0377	.0381	.0381	.0187	.0189
Avg	.1050	.1291	.1240	.1871	.1675	.1675	.0661

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244064 / 33/11KV KUNDLAPUR

Feeder No / Name : 208 / 11 KV AGALGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.112	.1132	.1132	.6722	.5868	.6802
2	.0895	.0934	.1132	.1132	.6722	.5365	.6722
3	.0905	.0943	.1132	.1132	.6882	.5087	.6802
4	.1612	.0943	.1698	.1509	.7125	.5087	.7362
5	.2195	.128	.2427	.2614	.7373	.6464	.7773
6	.3292	.2896	.3174	.3361	1.1191	.9069	.8356
7	.3403	.3582	.3734	.3921	1.2407	1.2803	.7449
8	.2743	.2353	.2801	.2801	.2452	.2378	.2195
9	.8322	.852	.9122	.1698	.2075	.1867	1.0082
10	.7701	.7865	.9282	.1132	.132	.1494	.852
11	.663	.8848	.9282	.112	.1132	.1307	.9831
12	.8192	.7373	.8802	.0943	.1132	.1307	.852
13	.7045	.7373	.8962	.0943	.1132	.112	.852
14	.7373	.7045	.9122	.112	.0943	.112	.6718
15	.7865	.8482	1.1092	.0943	.0943	.1307	.7209
16	.4588	.7842	.8962	.0934	.1132	.112	.7209
17	.1307	.132	.132	.1509	.1463	.1463	.132
18	.1829	.1698	.1698	.1509	.1646	.1791	.1509
19	.2172	.2241	.2054	.2263	.2172	.2149	.1867
20	.2561	.4294	.2614	.2829	.2534	.2195	.2241
21	.2195	.2054	.2241	.2452	.2172	.2353	.2054
22	.1663	.1698	.1698	1.0111	.8453	.8539	.1509
23	.1307	.1509	.1509	.9069	.7042	.8002	.132
24	.124	.112	.132	.1509	.6882	.6371	.7522
Max	.8322	.8848	1.1092	1.0111	1.2407	1.2803	1.0082
Min	.0895	.0934	.1132	.0934	.0943	.112	.132
Avg	.3665	.3889	.4430	.2404	.4294	.3984	.5809

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 201 / 11 KV LONARWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5735			.8383		.415
2	.57			.8192		.3772
3	.6299			.8785		.3772
4				.9724		.3772
5				.9945		.415
6				1.1022		.5281
7		1.6461		1.576		.5041
8				.5041		.4435
9				1.8023		
10			.2743		1.7126	
11			.2614	1.8004		
12			.2614			
13			.2587			
14			.2641			
15			.2801			
16			.2957	1.3256		.2402
17			.3361			
18			.4527			
19			.5175			
20			.5788			
21			.5281			
22			1.3748			.823
23			1.0322			
24	.6554	1.4217		.8785		.415
Max	.6554	1.6461	1.3748	1.8023	1.7126	.823
Min	.57	1.4217	.2587	.5041	1.7126	.2402
Avg	.6072	1.5339	.4797	1.1243	1.7126	.4469

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 202 / 11KV Kokle Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168			.1867		
2	.1478			.1867		
3	.1698			.1848		
4	.1715			.2241		
5	.2218			.2587		
6	.2829			.2829		
7	.2829			.3772		
8	.2641			.2829		
9	.1698			.2667		
10			.6796		.2402	
11			.6962	.2263		
12			.7377			
13			.6718			
14			.663			
15			.6554			
16			.6464	.168		
17			.1829			
18			.2218			
19			.2561			
20			.3018			
21			.2858			
22			.2286			.2427
23			.2263			
24	.1698	.2427		.2054		
Max	.2829	.2427	.7377	.3772	.2402	.2427
Min	.1478	.2427	.1829	.168	.2402	.2427
Avg	.2048	.2427	.4610	.2375	.2402	.2427

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 203 / 11 KV IRALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509			.2263		
2	.1294			.1848		
3	.1307			.1886		
4	.1478			.2218		
5	.1886			.2241		
6	.2241			.2614		
7	.2241	.181		.3696		
8	.2801			.3174		
9				.2614		
10			.9724		.2378	
11			.9448	.2427		
12			.9945			
13			.9175			
14			.8718			
15			.8288			
16			.8192	.2241		
17			.1848			
18			.2241			
19			.2587			
20			.2587			
21			.2614			
22			.2452			.2218
23			.2218			
24	.168	.2353		.2241		
Max	.2801	.2353	.9945	.3696	.2378	.2218
Min	.1294	.181	.1848	.1848	.2378	.2218
Avg	.1826	.2082	.5717	.2455	.2378	.2218

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 204 / 11 KV LONARWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132			.1494		
2	.0934			.1267		
3	.0924			.1307		
4	.0924			.1646		
5	.1307			.1848		
6	.1509			.1886		
7	.2263	.1829		.1886		
8	.1848			.1848		
9				.1463		
10			.1294		.1494	
11			.1307	.1848		
12			.1267			
13			.128			
14			.1294			
15			.1307			
16			.1294	.1494		
17			.1307			
18			.1494			
19			.1848			
20			.2263			
21			.1867			
22			.1848			.1886
23			.168			
24	.1109	.1663		.1509		
Max	.2263	.1829	.2263	.1886	.1494	.1886
Min	.0924	.1663	.1267	.1267	.1494	.1886
Avg	.1328	.1746	.1525	.1625	.1494	.1886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 205 / 11 KV KOKLE GAO

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732			.112		
2	.0554			.0924		
3	.056			.0914		
4	.0732			.0924		
5	.0739			.112		
6	.1132			.1132		
7	.0114	.1109		.1143		
8	.0953			.1143		
9				.0754		
10			.0934		.0943	
11			.0943	.0943		
12			.0762			
13			.0943			
14			.0934			
15			.0934			
16			.0943	.0754		
17			.0934			
18			.0739			
19			.0924			
20			.112			
21			.1132			
22			.1143			.112
23			.1143			
24	.0754	.0924		.1109		
Max	.1132	.1109	.1143	.1143	.0943	.112
Min	.0114	.0924	.0739	.0754	.0943	.112
Avg	.0697	.1017	.0966	.0998	.0943	.112

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244076 / 33/11 KV RANJANI

Feeder No / Name : 206 / 11 KV IRALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0924			.0747		
2	.056			.0754		
3	.056			.0754		
4	.0554			.0924		
5	.0934			.112		
6	.1132			.1132		
7	.132	.0747		.1848		
8	.1132	.0934		.1307		
9				.1132		
10			.1132		.0747	
11			.0739	.0924	.0747	
12			.056		.0747	
13			.0554		.0747	
14			.0566		.0701	
15			.0549		.052	
16			.0554	.0754	.0526	
17			.0747		.0739	
18			.1097		.0739	
19			.1109		.112	
20			.112		.1132	
21			.1132		.1132	
22			.1143		.1132	.112
23			.0943		.1132	
24	.0754			.0924		
Max	.132	.0934	.1143	.1848	.1132	.112
Min	.0554	.0747	.0549	.0747	.052	.112
Avg	.0874	.0841	.0853	.1027	.0847	.112

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244099 / 33/11 kv KAROLI

Feeder No / Name : 201 / 11 KV Shindewadi (H) Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867		.3292	.2195	1.989		1.9725
2	.2427		.3109	.2012	2.0222		1.9393
3	.2801		.2926	.2378	2.0056		1.989
4	.2801		.3292	.2195	1.9725		2.0388
5	.3547		.3658	.2743	2.1548		2.2377
6	.4481		.4755	.2378	2.3703		2.304
7	.3921		.567	.2378			2.3205
8	.2427			.2195			.4066
9	1.8896			.2378			2.5692
10	1.7901		2.556	.2195			2.4366
11	.2427	2.4249	2.4905	.2378		.3109	2.3205
12		2.5232	2.4577	.2195		.2743	2.1879
13	1.7901	2.4905	2.2939	.2561		.2561	2.0885
14		2.556	2.2119	.2378		.2378	1.989
15	1.7901	2.4577	2.3594	.2926		.2195	1.9393
16	1.6907	2.0317	2.3594	.2378		.2195	1.8233
17	.2054	.3292	2.343	.2743		.2378	.2614
18	2.1216	.3109	.1646	.2743		.2195	.3361
19		.4024	.2743	.2926		.2743	.3734
20		.3292	.3109	.3292		.3475	.5041
21		.2378	.4024	.3841		.4024	.4481
22		.2561	.3475	2.1548		2.1548	.3734
23		.3475	.3658	2.0553		2.0485	.2987
24	.2075		.3292	.9717	2.0222		1.989
Max	2.1216	2.556	2.556	2.1548	2.3703	2.1548	2.5692
Min	.1867	.2378	.1646	.2012	1.9725	.2195	.2614
Avg	.8326	1.2844	1.0880	.4384	2.0767	.5541	1.5478

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244099 / 33/11 kv KAROLI

Feeder No / Name : 202 / 11 KV Kuktoli Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307		.1829	.2033	2.0222		1.8351
2	.112		.2012	.1848	1.989		1.8842
3	.168		.2195	.1663	1.989		1.9498
4	.2241		.2378	.1848	2.0056		2.0481
5	.2614		.2926	.1848	2.0222		2.13
6	.2987		.3658	.2772	2.1216		1.8023
7	.2241		.3841	.3511			1.6712
8	.1867			.2587			.1646
9	2.0553			.2402			2.4577
10	1.9725		2.2939	.2218			2.3594
11	1.9227	2.4508	2.2119	.2218		.2218	2.2939
12	1.7072	2.4326	1.917	.2033		.2402	2.1714
13	1.6741	2.524	2.0645	.2402		.2033	1.989
14		2.4874	2.13	.2218		.1791	1.8896
15	1.6244	2.524	1.9989	.1848		.2033	1.989
16	1.5912	1.829	1.9006	.1848		.2033	1.9227
17	.1326	.2561	.1848	.2402		.2218	.168
18		.2378	.2033	.3326		.2402	.2241
19		.2561	.2218	.4805		.2772	.2801
20		.2378	.2587	.4435		.2587	.3361
21		.2378	.2458	.462		.2402	.2614
22		.2195	.2957	2.1879		1.6385	.2241
23		.2012	.3142	2.0885		1.7368	.1867
24	.1494		.2012	.2218	2.0553		1.8023
Max	2.0553	2.524	2.2939	2.1879	2.1216	1.7368	2.4577
Min	.112	.2012	.1829	.1663	1.989	.1791	.1646
Avg	.8491	1.2226	.8330	.4161	2.0293	.4511	1.4184

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244099 / 33/11 kv KAROLI

Feeder No / Name : 203 / 11 KV Kongnoli Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3094		1.5249	1.6575	.2801		.3142
2	1.4586		1.5581	1.989	.2801		.2772
3	1.5581		1.5415	2.0719	.2987		.3326
4	1.7736		1.5912	2.1548	.2801		.3511
5	1.9725		1.6078	2.1879	.2987		.4066
6	2.1879		2.304	2.2377	.4668		.462
7	2.0719		2.3205	2.1051			.5544
8	.2987			.3881			.462
9	.3174			2.4863			.4066
10	.2801		.3696	2.5692			.4251
11	.2427	.3361	.3511	2.5194		2.8178	.3142
12	.2427	.3174	.3881	2.5526		2.7349	.2772
13	.2427	.2987	.2033	2.5526		2.7018	.2587
14		.2614	.2218	2.4863		2.4863	.1848
15	.2561	.2427	.2402	2.5029		2.5194	.2402
16	.2561	.2427	.2957	1.6244		2.304	.3142
17	.2926	.2614	.3142	.3361		.2772	.3696
18		.2987	.3511	.3361		.3142	.4435
19		.4108	.3696	.4481		.3511	.4805
20		.3734	.4435	.4854		.4066	.5729
21		.3921	.4805	.3944		.4805	.5359
22		1.6244	1.5746	.3547		.4066	1.9559
23		1.5581	1.7072	.3361		.3511	1.8233
24	1.3592		1.5415	1.5581	.2987		.3326
Max	2.1879	1.6244	2.3205	2.5692	.4668	2.8178	1.9559
Min	.2427	.2427	.2033	.3361	.2801	.2772	.1848
Avg	.9483	.5091	.9682	1.5973	.3147	1.3963	.5040

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244099 / 33/11 kv KAROLI

Feeder No / Name : 204 / 11 KV Karoli Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829		.2926	.2195	.2378		.3109
2	.2378		.3109	.2743	.2195		.3475
3	.2743		.3292	.2561	.2378		.3292
4	.3109		.3658	.3292	.2561		.3658
5	.3475		.4024	.3658	.3292		.4024
6			.5853	.4024	.567		.4207
7			.439	.3475			.3658
8	.3841			.3658			.4207
9	.3475			.3109			.3658
10	.3109		.3109	.2743			.2926
11	.2743	.2926	.2926	.2926		.2378	
12		.2561	.2743	.3109		.2743	
13		.3292	.2561	.3292		.2561	
14		.2926		.2195		.2561	
15	.4207	.3109	.2378	.2378		.2378	
16	.3658	.3109	.2743	.2378		.2378	
17	.2012	.3292	.3475	.2561		.3109	
18		.4024	.3109	.3292		.3475	
19		.5853	.3658	.5853		.4024	
20		.5121	.4024	.5487		.4572	
21		.4938	.439	.4572		.4938	
22		.3292	.3475	.439		.3658	
23		.3292	.2926	.3109		.3109	
24	.2195		.2926	.2378	.2561		.3292
Max	.4207	.5853	.5853	.5853	.567	.4938	.4207
Min	.1829	.2561	.2378	.2195	.2195	.2378	.2926
Avg	.2983	.3672	.3414	.3307	.3005	.3222	.3591

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244099 / 33/11 kv KAROLI

Feeder No / Name : 205 / 11 KV Sarati Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.7459	.6706	.0924		.0747
2			.7293	.7042	.0739		.0934
3			.7625	.7545	.0554		.1307
4			.7956	.8048	.0739		.1307
5			.8288	.8215	.0924		.168
6			1.1437	.8886			.168
7			1.1934	.9221	.1848		.1867
8				.1494	.0739		.168
9				.8383			.0934
10			.0747	.9389			.0934
11	.0995	.1867	.0747	.8718		1.0059	
12	.0995	.0747	.0747	.9054		.9724	
13	.0829	.0934	.0747	.9724		.9221	
14		.112	.0934	.9389		.9221	
15	.0829	.0747	.0934	.9054		.9556	
16	.0663	.056	.0934	.8551		.9556	
17	.0829	.1494	.112	.0739		1.0059	
18		.112	.112	.0924		.0934	
19		.1494	.1307	.1478		.0934	
20		.1494	.1307	.1294		.1307	
21		.112	.112	.1109		.112	
22		.8288	.5868	.0924		.0934	
23		.7625	.6706	.0739		.0747	
24			.7625	.6371	.0739		.0747
Max	.0995	.8288	1.1934	.9724	.1848	1.0059	.1867
Min	.0663	.056	.0747	.0739	.0554	.0747	.0747
Avg	.0857	.2201	.4271	.5958	.0901	.5644	.1256

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 201 / 11 KV Deshing GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	30-AUG-17	31-AUG-17	01-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2347		.1677
2	.2515		.1677
3	.2515		.1677
4	.2683		.1677
5	.3018		.2515
6	.3353		.3185
7	.3688		.3185
8	.3353		.2347
9	.218		.2012
10	.218		.1844
11	.2012		.1677
12	.2012		.1677
13	.1677		.1677
14	.1677		.1677
15	.1509		.1677
16	.1509		.1844
17	.1509		.1677
18	.2012		.2683
19	.3018		.3353
20	.3353		.3353
21	.3353		.3521
22	.3185		.2683
23	.2347		.218
24	.2347	.2012	.2515
Max	.3688	.2012	.3521
Min	.1509	.2012	.1677
Avg	.2473	.2012	.2250

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 202 / 11 KV BANEWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	.8907
Max	.8907
Min	.8907
Avg	.8907

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 203 / 11 KV MORGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	30-AUG-17	31-AUG-17	01-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.8718		.7712
2	.9221		.788
3	1.0059		.788
4	1.0395		.788
5	1.1065		.8048
6	1.1401		.8383
7	1.1736		.8551
8	.1006		.1509
9	.1174		1.073
10	.0838		1.2071
11	.0838		1.2407
12	.1006		1.2407
13	.1174		1.2742
14	.1174		1.2742
15	.1174		1.2407
16	.1174		1.2071
17	.1174		.1174
18	.1174		.1174
19	.1509		.1174
20	.1509		.1174
21	.1174		.1341
22	1.0059		.1174
23	.9054		.1006
24	.8383	.8383	1.1145
Max	1.1736	.8383	1.2742
Min	.0838	.8383	.1006
Avg	.4841	.8383	.7283

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079]

BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 204 / 11 KV KHARSHING AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	30-AUG-17	31-AUG-17	01-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1006		.0838
2	.1174		.0838
3	.1174		.0838
4	.1341		.0838
5	.1341		.0838
6	.1509		.1006
7	.1509		.1174
8	.1509		.0671
9	1.0227		.0671
10	1.0227		.0838
11	1.0227		.0486
12	1.1065		.0503
13	1.1401		.0503
14	1.1401		.0503
15	1.1568		.0503
16	1.1568		.0671
17	.1006		.0838
18	.1006		.0838
19	.1006		.0838
20	.1006		.0838
21	.1006		.0838
22	.0838		.9389
23	.0838		.9221
24	.1006	.0671	.0838
Max	1.1568	.0671	.9389
Min	.0838	.0671	.0486
Avg	.4415	.0671	.1473

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 205 / 11 KV SONI LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-AUG-17	01-SEP-17
HR	Load (MW)	Load (MW)
1		.0671
2		.0671
3	.0168	.0671
4	.0168	.0648
5	.0168	.0671
6	.0168	.0671
7	.0168	.0671
8	.0503	.0671
9	.0671	.0503
10	.0655	.0503
11	.0671	.0503
12	.0671	.0503
13	.0671	.0671
14	.0671	.0671
15	.0671	.0671
16	.0671	.0671
Max	.0671	.0671
Min	.0168	.0503
Avg	.0478	.0628

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

K.MAHANKAL[079] BU 1295

Substation No/ Name :- 244103 / 33/11 KV Haroli(Deshing)

Feeder No / Name : 206 / 11 KV HAROLI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	30-AUG-17	31-AUG-17	01-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0983		.0655
2	.1147		.0655
3	.1147		.0655
4	.1311		.0655
5	.1311		.0819
6	.1311		.1147
7	.1475		.1147
8	.1311		.0983
9			.0655
10	1.1469		.0655
11	1.1469		.0671
12	1.1469		.0655
13	1.065		.0671
14	1.0159		.0655
15	.9831		
16	.9831		.0819
17	.0655		.0655
18	.0819		.0819
19	.0983		.0983
20	.0983		.1147
21	.0983		.1147
22	.0983		.9831
23	.0655		.9831
24	.0983	.0655	.0655
Max	1.1469	.0655	.9831
Min	.0655	.0655	.0655
Avg	.3996	.0655	.1590

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 201 / KHANDERAJURI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6133	.6371	1.0526	.8697	.2096	.2096	.2477
2	.6133	.6371	1.0526	.8223	.2096	.2096	.2477
3	.5898	.6371	1.0526	.7811	.2096	.2096	.2667
4	.639	.6554	1.0526	.7499	.2096	.2096	.2667
5	.6554	.8192	1.0402	.8482	.2096	.2477	.2858
6	.7125	1.2146	1.1203	1.0159	.2858	.3429	.4191
7	1.6194	1.8187	2.1605	1.3927	.4191	.4382	.4572
8	.4001	.3429	.3239	.3429	.2858	.3048	.3429
9	.2477	.2858	.2477	1.6842	2.2996	2.0972	.2667
10	.1905	.2286	.2667	2.0325	2.5888		.2096
11	.1905	.1905	.1715	2.1285	2.769	2.4806	.2096
12	.1715	.1905	.1905	2.1862	2.556	2.4806	.2667
13	.1715	.1905	.1524	2.2405	2.5888	2.4646	.2096
14	.1715	.1905	.1524	2.3205	1.4746	2.5446	.1715
15	.1524	.1905	.1715	2.3158	2.13	2.5911	.1715
16	.1524	.1905	.2096	2.2672	2.0317	2.6408	.1715
17	.1905	.2286	.2096	.2286	.2096	.2477	.1905
18	.2096	.2858	.2286	.2286	.2477	.2667	.2667
19	.3239	.3239	.2858	.2858		.3429	.362
20	.2858	.3239	.2858	.3048	.3048	.362	.362
21	.2858	.2858	.2667	.2858	.2858	.3239	.3048
22	.7888	1.1203	1.0202	.2477	.2477	.2858	1.5074
23	.6706	1.085	.9602	.2096	.2286	.2477	1.3763
24	.6226	.6371	1.0526	1.6903	.2096	.2096	.2477
Max	1.6194	1.8187	2.1605	2.3205	2.769	2.6408	1.5074
Min	.1524	.1905	.1524	.2096	.2096	.2096	.1715
Avg	.4445	.5296	.6136	1.1450	.9657	.9460	.3678

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 202 / 11 KV Khatav

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 203 / 11 KV Mallewadi Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1334	.1334	.1715	.852	.9156	.7459
2	.1334	.1334	.1334	.1715	.852	.9054	.7459
3	.1334	.1334	.1334	.1715	.852	.9054	.7293
4	.1524	.1334	.1334	.1715	.852	.9054	.7701
5	.1715	.1524	.1334	.2096	.852	.9831	.8684
6	.2096	.1905	.1905	.2477	.9717	1.2289	.9231
7	.2286	.2477	.2858	.2667	1.3603	1.491	1.085
8	.2096	.2096	.2477	.2477	.2286	.2096	.1905
9	.8745	1.2944	1.1797	.1905	.1905	.2096	1.3927
10	.8097	1.3435	1.1523	.1715	.1715	.1715	1.6518
11	.9831	1.3763	1.2803	.1524	.1524	.1524	1.7166
12	1.065	1.2631	1.3283	.1524	.1715	.1524	1.6004
13	1.0486	1.2146	1.2803	.1715	.1524	.1524	1.4074
14	1.0159	1.1523	1.2323	.1715	.1334	.1524	1.3435
15	.9175	1.1203	1.3603	.1715	.1334	.1524	1.3435
16	.8684	1.0526	1.2803	.1524		.1715	1.2963
17	.1334	.1334	.1524	.1524	.1524	.1715	.1143
18	.1524	.1524	.1905	.1715	.1905	.1905	.1524
19	.2477	.2096	.2096	.2477	.2286	.2477	.2286
20	.2096	.2096	.2667	.2477	.2477	.2477	.2286
21	.1905	.2096	.2477	.2286	.2286	.2477	.2096
22	.1715	.1905	.2096	1.004	1.0898	.9231	.1905
23	.1524	.1715	.1905	.8684	.9892	.852	.1715
24	.1334	.1334	.1334	.1715	.852	.9326	.7701
Max	1.065	1.3763	1.3603	1.004	1.3603	1.491	1.7166
Min	.1334	.1334	.1334	.1524	.1334	.1524	.1143
Avg	.4311	.5234	.5452	.2535	.5176	.5280	.8282

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 204 / 11 kv shivganga

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0762	.0762	.0762	.0762	.0572	.0572
2		.0762	.0762	.0572	.0762	.0572	.0572
3		.0572	.0762	.0572	.0762	.0572	.0572
4		.0572	.0762	.0572	.0762	.0572	.0572
5		.0572	.0762	.0572	.0762	.0572	.0572
6		.0572	.0762	.0762	.0762	.0572	.0762
7		.0572	.0762	.0953	.0762	.0762	.0762
8	.0762	.0572	.0572	.0572	.0762	.0572	.0762
9	.0381	.0762	.0953	.0572	.0762	.1905	.0762
10	.2858	.0953	.0953	.0381	.0762	.3239	.2477
11	.1905	.1143	.0762	.0572	.0572	.2858	.1143
12	.0953	.0572	.0762	.3239	.0572	.3048	.2667
13	.1143	.0953	.0762	.1905	.0762	.2667	.1334
14	.1334	.0381	.0762	.0762	.0762		.0762
15	.0762	.0953	.0381	.2286	.0762	.2477	.2667
16	.0762	.0572	.0762	.2858	.0953	.2096	.3048
17	.0572	.0953	.0762	.2667	.0762	.2858	.2477
18	.0191	.1143	.0762	.3048	.0572	.2477	.3239
19	.0572	.0953	.0381	.0572	.0572	.1905	.0762
20	.0572	.1143	.0572	.0762	.0762	.1715	.0762
21	.0572	.0762	.0762	.0762	.0572	.1905	.0762
22	.0572	.0953	.0762	.0572	.0572	.0572	.0381
23	.0572	.0953	.0762	.0762	.0572	.0572	.0953
24		.0572	.0762	.0762	.0762	.0762	.0572
Max	.2858	.1143	.0953	.3239	.0953	.3239	.3239
Min	.0191	.0381	.0381	.0381	.0572	.0572	.0381
Avg	.0905	.0778	.0730	.1159	.0715	.1557	.1246

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 205 / 11KV Salgare

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1357	.3239	.2623	.0953	.0572	.0762
2	.1387	.1357	.3239	.2623	.0953	.0572	.0762
3	.1387	1.4232	.3239	.2439	.0953	.0572	.0762
4	.1865	.1543	.3239	.2286	.0953	.0572	.0953
5	.2204	.1715	.3239	.2561	.0953	.0762	.0953
6	.2652	.2543	.3814	.3521	.1143	.0953	.1524
7	.5801	.407	.7202	.4807	.1524	.0762	.1334
8	.0953	.0762	.0953	.0953	.1143	.0762	.0953
9	.0762	.0572	.0762	.6554	.7459	.0572	.1143
10	.0762	.0953	.0762	.7842	.8453		.0762
11	.0762	.0953	.0762	.8802	.7865	.9892	.0953
12	.0572	.0953	.0381	.852	.8848	.9945	.1143
13	.0572	.0953	.0572	.8192	.9012	.9116	.1143
14	.0762	.0953		.8029	.8192	.8987	.0953
15	.0572	.0953		.7865	.8421	.7537	.0953
16	.0762	.0953		.7773	.8192	.8097	.0953
17	.0572	.1143	.0762	.0762	.0572	.0953	.1143
18	.0762	.1334	.0762	.0762	.0762	.1143	.1143
19	.0953	.0953	.0953	.1143	.0953	.1334	.1143
20	.0953	.1143	.0953	.1143	.0953	.1334	.1143
21	.0953	.1143	.0953	.1143	.0953	.0953	.1143
22	.2286	.3048	.3401	.0953	.0762	.0953	.6706
23	.1715	.3239	.3041	.0953	.0762	.0762	.5967
24	.1357	.1357	.3239	1.0467	.0953	.0572	.0762
Max	.5801	1.4232	.7202	1.0467	.9012	.9945	.6706
Min	.0572	.0572	.0381	.0762	.0572	.0572	.0762
Avg	.1362	.2008	.2165	.4280	.3404	.2942	.1465

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244009 / 33/11 KV BELANKI

Feeder No / Name : 206 / BELANKI gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.1334	.1334	.1334	.1334	.1334
2	.0953	.0953	.1334	.1334	.1334	.1334	.1334
3	.1143	.0953	.1334	.1334	.1334	.1334	.1334
4	.1524	.1143	.1334	.1334	.1334	.1334	.1524
5	.1715	.1524	.1524	.2096	.1524	.1524	.1905
6	.2477	.1905	.2286	.2667	.2715	.2286	.2715
7	.2896	.2667	.3239	.3048	.3841	.3048	.3582
8	.2896	.2286	.2477	.2477	.2858	.2858	.2477
9	.2667	.2096	.2096	.2507	.2286	.3239	.2286
10	.3048	.2286	.2204	.2149	.1905		.2858
11	.2667	.3429	.2401	.1715	.2096	.2096	.2683
12	.2286	.3048	.218	.2286	.1905	.1905	.2572
13	.2096	.2858	.1928	.2096	.1905	.1905	.1989
14	.2096	.2667	.2347	.1905	.1715	.1905	.2515
15	.2667	.2667	.2149	.2286	.1905	.2096	.2347
16		.2667	.1791	.2858	.1715	.2096	.2401
17	.1905	.2477	.1334	.2667	.2477	.2096	.2328
18	.1905	.2096	.1905	.2477	.2667	.2477	.2149
19	.2477	.2096	.2477	.3048	.2858	.2858	.2858
20	.1905	.2667	.2858	.2667	.2286	.3048	.2858
21	.1905	.2667	.2477	.2667	.2096	.2286	.2477
22	.1334	.2286	.1905	.1905	.1715	.1905	.1905
23	.1143	.1334	.1524	.1334	.1524	.1524	.1524
24	.1143	.0953	.1334	.1334	.1334	.1334	.1334
Max	.3048	.3429	.3239	.3048	.3841	.3239	.3582
Min	.0953	.0953	.1334	.1334	.1334	.1334	.1334
Avg	.1991	.2112	.1991	.2147	.2028	.2079	.2220

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 201 / 11 Kv Arag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-SEP-17	02-SEP-17
HR	Load (MW)	Load (MW)
19	.2667	
24	1.1203	.1524
Max	1.1203	.1524
Min	.2667	.1524
Avg	.6935	.1524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 202 / 11 KV Bedag gav

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17	02-SEP-17
HR	Load (MW)	Load (MW)
19	.4572	
24	.2667	.2667
Max	.4572	.2667
Min	.2667	.2667
Avg	.3620	.2667

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 203 / 11 KV Vijaynagar
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-SEP-17	02-SEP-17
HR	Load (MW)	Load (MW)
19	.2477	
24	1.6583	.1524
Max	1.6583	.1524
Min	.2477	.1524
Avg	.953	.1524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 204 / 11 KV Bedag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-SEP-17	02-SEP-17
HR	Load (MW)	Load (MW)
19	.2477	
24	1.1822	.1905
Max	1.1822	.1905
Min	.2477	.1905
Avg	.7150	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 205 / 11 KV rade ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-SEP-17	02-SEP-17
HR	Load (MW)	Load (MW)
19	.4191	
24	.3048	1.7394
Max	.4191	1.7394
Min	.3048	1.7394
Avg	.3620	1.7394

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244010 / 33/11 kv Bedag

Feeder No / Name : 206 / 11 Kv Bolwad Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244052 / 33/11 KV MALLEWADI

Feeder No / Name : 201 / 11 kv Erandoli Gav.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	1.045
Max	1.045
Min	1.045
Avg	1.045

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244052 / 33/11 KV MALLEWADI

Feeder No / Name : 203 / 11 KV Takali

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	1.3657
Max	1.3657
Min	1.3657
Avg	1.3657

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244052 / 33/11 KV MALLEWADI

Feeder No / Name : 204 / 11 kv Erandoli

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	.1886
Max	.1886
Min	.1886
Avg	.1886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244052 / 33/11 KV MALLEWADI

Feeder No / Name : 206 / 11 KV VanKochiwadi feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	.2096
Max	.2096
Min	.2096
Avg	.2096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 201 / 11 KV Lingnoor Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.104	.1524	.1097	.1494	.1698	.1463	.1417
2	.104	.1524	.1052	.1267	.1698	.1294	.1387
3	.1052	.1524	.1097	.132	.1698	.1307	.1387
4	.1052	.132	.1109	.132	.1509	.132	.104
5	.1052	.112	.0995	.132	.1509	.132	.1052
6	.1509	.112	.1017	.1698	.1509	.1509	.1448
7	.0934	.1132	.0781	.1663	.132	.1132	.1294
8	.0716	.0754	.1109	.1478	.1143	.1334	.0716
9	.1109	.0914	.0924	.1063	.132	.1294	.104
10	.1294	.1132	.132	.1097	.168	.1509	.1524
11	.1307	.132	.132	.112	.1524	.1509	.1132
12	.1132	.132		.1334	.1334	.1509	.1143
13	.1132	.0876	.1132	.112	.1524	.1267	.0934
14	.0716	.0693	.0924	.0905	.1097	.1267	.0905
15	.0732	.0857	.0739	.1075	.1132	.1086	.0895
16	.0747	.0648	.0924	.0886	.112	.0895	.0905
17	.0934	.0693	.0953	.0549	.1086	.1109	.0709
18	.0914	.0895		.056	.1294	.168	.1132
19	.2054	.1867	.128	.1886	.1886	.1905	.1715
20	.2427	.2477	.2286	.2452	.2641	.2452	.2263
21	.2241	.2075	.1905	.2263	.2263	.2829	.2641
22	.1905	.1886	.1848	.1886	.2075	.2075	.2075
23	.1905	.1294		.1886	.1698	.1886	.168
24		.1715	.1478		.1886	.1463	.1886
Max	.2427	.2477	.2286	.2452	.2641	.2829	.2641
Min	.0716	.0648	.0739	.0549	.1086	.0895	.0709
Avg	.1258	.1278	.1204	.1376	.1569	.1517	.1347

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 202 / 11 KV Shindewadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1267	.1509	.1097	.1478	1.1561	.8916	1.0648
2	.1267	.132	.1075	.1463	1.0669	.8619	.9511
3	.1267	.1307	.1086	.1463	.9633	.873	.9214
4	.1267	.1307	.1075	.1463	.9482	.8429	.8802
5	.1267	.1307	.124	.1463	.9332	.8429	1.0517
6	.1698	.1698	.1307	.1646	1.3283	1.1523	1.1265
7	.1646	.2075	.1524	.1886	1.6518	1.6385	1.2334
8	.197	.1949	.1753	.1886	.1966	.1629	.1791
9	1.1248	1.5203	1.7004	.1494	.1494	.1132	1.7695
10	1.1717	1.5708	1.6484	.1494	.1698	.1509	1.704
11	1.1873	1.3443	.1712	.132	.168	.1509	1.7368
12	1.2346	1.2803	1.5971	.0732	.2241	.1494	1.4883
13	1.1888	1.2498	1.4232	.0732	.1494	.1463	1.3603
14	1.2186	1.2346	1.4074	.1109	.1307	.1463	1.3916
15	1.2498	1.2651	1.3599	.128	.1509	.1463	1.5203
16	1.2346	1.2346	1.5364	.1463	.1307	.1463	1.2346
17	.1865	.1326	.1526	.1526	.1696	.156	.144
18	.2035	.1526	.1886	.1781	.1715	.1772	
19	.2279	.1595	.1612	.1991	.1772	.2172	.2103
20	.2172	.1448	.181	.1991	.1791	.181	.2126
21	.2195	.1433	.181	.1772	.1829	.1829	.1791
22	.1886	.112	.1698	1.4413	1.2308	1.3443	.1886
23	.1698	.1097		1.5546	1.0936	1.3763	.132
24		.1698	.1478		1.3123	.9214	1.1843
Max	1.2498	1.5708	1.7004	1.5546	1.6518	1.6385	1.7695
Min	.1267	.1097	.1075	.0732	.1307	.1132	.132
Avg	.5299	.5446	.5670	.2669	.5848	.5405	.9506

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 203 / 11 KV Landgewadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0572	.0572	.0381	.8124	.8322	.8745
2	.0381	.0572	.0572	.0381	.7074	.8002	.7811
3	.0381	.0572	.0572	.0381	.6773	.7682	.7099
4	.0381	.0381	.0572	.0381	.6321	.7611	.6859
5	.0381	.0381	.0572	.0381	.587	.7611	.8179
6	.0572	.0572	.0762	.0572	.7811	.9069	.8333
7	.0572	.0572	.0572	.0762	.9762	1.065	.9014
8	.0381	.0381	.0381	.0572	.0381	.0762	.0572
9	.7042	.7842	.9667	.0381	.0572	.0381	1.0159
10	.7099	.8583	.9831	.0381	.0381	.0381	1.065
11	.7164	.8745	.8848	.0381	.0381	.0381	.9175
12	.6773	.5468	.9012	.0381	.0572	.0572	.9231
13	.6554	.8223	.8684	.0381	.0381	.0572	.8802
14	.6173	.7907	.8097	.0381	.0381	.0572	.8065
15	.6173	.8421	.9122	.0381	.0762	.0572	.9496
16	.6097	.7842	.8482	.0381	.0572	.0572	.8745
17	.0572	.0572	.0572	.0381	.0762	.0572	.0572
18	.0572	.0572	.0381	.0381	.0762	.0762	.0762
19	.0953	.0572	.0572	.0762	.0762	.0953	.0953
20	.0762	.0762	.0762	.0762	.0953	.0762	.0953
21	.0572	.0762	.0572	.0762	.0953	.0762	.0953
22	.0572	.0762	.0572	.9602	1.1142	.9393	.0762
23	.0572	.0572		1.1984	1.004	1.0364	.0762
24		.0572	.0554		1.1012	.8482	.9717
Max	.7164	.8745	.9831	1.1984	1.1142	1.065	1.065
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0572
Avg	.2656	.3008	.3491	.1369	.3854	.3990	.6099

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244074 / 33/11 KV LINGNOOR

Feeder No / Name : 204 / 11 KV Lingnoor Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.695	.9511	.9457	.8741	.1905	.2075	.2075
2	.5335	.8916	.9587	.86	.1905	.2075	.1886
3	.5468	.9488	.9457	.9214	.1886	.2263	.1886
4	.6661	.9503	.9328	.9214	.1886	.2263	.1886
5	.8109	.9614	.9069	.9214	.2075	.2263	.2286
6	.8688	1.2654	1.1736	1.0105	.2452	.2477	.2477
7	1.5497	1.8827	1.7654	.9282	.2829	.3048	.2858
8	.2957	.2587	.2172	.2481	.2195	.2561	.2561
9	.2427	.2241	.2452	1.5074	1.9433	2.1052	.2096
10	.2054	.1886	.2263	1.5364	1.9109	2.1376	.1886
11	.1867	.2263	.2054	1.6461	1.8785	1.9784	.1886
12	.2075	.1886	.1848	1.6461	1.8122	1.7444	.1698
13	.1886	.1886	.1886	1.5741	1.6461	1.7604	.1867
14	.1307	.168	.1698	1.5586	1.4861	1.6446	.1698
15	.1294	.1494	.1886	1.5699	1.7284	1.6446	.1509
16	.1294	.1867	.1494		1.5546	1.9608	.1448
17	.1867	.1417	.1991	.2149	.1907	.156	.2507
18	.2172	.1991	.2126	.2328	.208	.2172	.2534
19	.2561	.2801	.2587	.2686	.2772	.2801	.2587
20	.2561	.2829	.2987	.3206	.2987	.2987	.2614
21	.2772	.2829	.2987	.2987	.2987	.2987	.2641
22	1.1145	1.2323	1.1589	.2286	.2477	.2667	2.2611
23	1.0536	1.057		.1905	.2263	.2263	1.8564
24		1.0235	.9412		.1905	.2075	.2263
Max	1.5497	1.8827	1.7654	1.6461	1.9433	2.1376	2.2611
Min	.1294	.1417	.1494	.1905	.1886	.156	.1448
Avg	.4673	.5887	.5553	.8854	.7338	.7846	.3680

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 201 / 11 KV Arag gav

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2452	.2743	.2641	.2641	.2829	.2772
2	.2641	.2452	.2743	.2641	.2641	.2641	.2772
3	.2641	.2452	.2743	.2641	.2641	.2641	.2772
4	.2641	.2452	.2561	.2641	.2641	.2641	.2801
5	.2641	.2452	.2561	.2641	.2641	.2641	.2987
6	.3206	.3018	.3142	.3018	.3018	1.1506	.3326
7	.3772	.3475	.3658	.3772	.3881	.3206	.3511
8	.415	.3258	.3403	.3584	.3658	.3696	.3439
9	.3439	.2658	.3224	.3696	.3258	.3258	.3801
10	.362	.3506	.3224	.3506	.3439	.3258	.3077
11	.3467	.3224	.3403	.3467	.3366	.3475	.3258
12	.333	.3403	.3224	.3294	.3366	.3439	.3222
13	.2601	.3189	.3294	.3121	.3366	.3224	.3641
14	.2601	.3012	.2774	.2629	.3366	.3403	.3294
15	.2601	.3403	.2947	.298	.3544	.3403	.2601
16	.2507	.2835	.3045	.3121	.3366	.3582	.2774
17	.2572	.2835	.2896	.2915	.3721	.3403	.3506
18	.3155	.3439	.4887	.362	.4075	.4344	.4075
19	.4298	.5175	.4251	.4572	.4344	.5068	.4681
20	.439	.499	.4715	.439	.4805	.5304	.5201
21	.4024	.4251	.415	.4435	.462	.439	.4287
22	.3696	.4024	.3772	.3696	.3772	.3881	
23	.3206	.3475	.3206	.3018	.3206	.3326	
24	.2641	.2829	.3109	.2829	.2641	.2829	.2957
Max	.439	.5175	.4887	.4572	.4805	1.1506	.5201
Min	.2507	.2452	.2561	.2629	.2641	.2641	.2601
Avg	.3187	.3261	.3320	.3286	.3417	.3808	.3398

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 202 / Arag mix Laxmiwadi
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3206	.3395	.2829	.2641	1.3916	1.3765	1.4746
2	.3206	.3395	.2829	.2641	1.2809	1.4089	1.4746
3	.3206	.3206	.2829	.2641	1.2654	1.3757	1.3765
4	.3206	.3206	.3018	.2829	1.2346	1.3592	1.3765
5	.3206	.3395	.3018	.2829	1.25	1.3592	1.5238
6	.3206	.3961	.3395	.3395	1.8842	1.587	1.7404
7	.3772	.4527	.3395	.3395	2.1051	2.0567	1.7072
8	.3395	.3018	.3206	.2829	.2452	.2829	.2263
9	1.2631	1.6221	1.8679	.2452	.2452	.2829	1.8023
10	1.3765	1.6804	1.8947	.2641	.2452	.2263	1.9662
11	1.2654	1.8623	1.749	.2075	.2452	.2829	1.8515
12	1.2492	1.5402	1.749	.2075	.2075	.2452	1.7204
13	1.2029	1.4746	1.6842	.1886	.1886	.2263	1.6712
14	1.1717	1.3927	1.4413	.2075	.2452	.2829	1.6385
15	1.1523	1.3765	1.587	.2263	.2075	.3018	1.8351
16	1.0987	1.3765	1.6356	.1886	.1886	.3584	1.9826
17	.3018	.2263	.1886	.2075	.2263	.3206	.2829
18	.3395	.2641	.2452	.2075	.2641	.3395	.3018
19	.4527	.3961	.3395	.3395	.3395	.4338	.3584
20	.4527	.4904	.415	.3395	.415	.4715	.4338
21	.4527	.4527	.2263	.3395	.3772	.3961	.415
22	.415	.3772	.3395	1.704	1.8724	1.7072	
23	.3395	.3584	.2829	1.6644	1.5708	1.6057	
24	.3206	.3395	.3395	.2641	1.5043	1.4251	1.4746
Max	1.3765	1.8623	1.8947	1.704	2.1051	2.0567	1.9826
Min	.3018	.2263	.1886	.1886	.1886	.2263	.2263
Avg	.6456	.7517	.7682	.3801	.7917	.8213	1.3016

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 203 / 11 KvAshoknagar

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.9014	.9717	1.0774	.1509	.1698	.132
2	.8048	.8697	.9717	1.0442	.1509	.1698	.132
3	.7712	.8539	.9717	1.0442	.1509	.1698	.132
4	.7712	.8539	1.0526	1.0442	.1509	.1886	.132
5	.7712	.8539	1.6385	1.0442	.1509	.1886	.1886
6	.9282	1.166	1.8564	1.1174	.1698	.1886	.2263
7	1.4899	1.5708	1.9062	1.3927	.1698	.2075	.2075
8	.2075	.132	.1886	.1698	.1509	.1698	.1886
9	.1698	.1886	.1698	1.4899	1.9662	1.866	.2075
10	.132	.1509	.1509	1.5708	2.0481	1.9766	.1698
11	.132	.1509	.1698	1.5203	1.9989	1.9433	.1698
12	.132	.132	.1698	1.3748	1.7695	1.8623	.1698
13	.0943	.132	.1509	1.4403	1.6549	1.7204	.132
14	.0943	.132	.1509	1.4899	1.6876	1.8351	.132
15	.0943	.1132	.132	1.5384	1.6712	1.7695	.1509
16	.132	.1132	.1509	1.4217	1.7204	1.5729	.1698
17	.1294	.1132	.132	.132	.132	.132	.1698
18	.1307	.132	.1509	.1509	.132	.1509	.1698
19	.1867	.1886	.1698	.2075	.1886	.1886	.1886
20	.1886	.1886	.1886	.2263	.2075	.2075	.2263
21	.1886	.1886	.2075	.2075	.2075	.1886	.2075
22	1.1336	1.5083	1.3094	.1698	.2075	.1698	
23	1.1336	1.3765	1.2597	.1509	.1886	.132	
24	.8383	.9646	1.1336	1.1437	.1509	.1698	.132
Max	1.4899	1.5708	1.9062	1.5708	2.0481	1.9766	.2263
Min	.0943	.1132	.132	.132	.132	.132	.132
Avg	.4789	.5406	.6397	.9237	.7157	.7224	.1698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 204 / railway station Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.57	.6642	.7287	.6962	.0943	.132	.1132
2	.5533	.6642	.6401	.6796	.0943	.132	.1132
3	.5533	.6483	.6401	.6796	.0943	.132	.1132
4	.5533	.6483	.6401	.6962	.0943	.132	.1132
5	.5533	.6483	.7287	.6962	.0943	.132	.1132
6	.6133	.7682	.8097	.7293	.132	.1509	.132
7	.8122	.9172	.9831	.7956	.1509	.1509	.1509
8	.132	.132	.132	.132	.1132	.1509	.132
9	.0943	.1132	.0754	1.0111	1.1012	1.1363	.132
10	.0943	.1132	.0943	1.0111	1.1523	1.0242	.132
11	.0943	.1132	.1132	1.0595	1.1363	1.3765	.132
12	.0943	.0943	.0943	1.0623	1.1523	1.3763	.132
13	.0943	.1132	.0943	1.085	1.1363	1.4255	.132
14	.132	.1132	.0754	1.1012	.9762		.132
15	.1132	.1132	.0943	1.085	1.0883	1.3927	.132
16	.0566	.1132	.1132		1.1043	1.3435	.1509
17	.0943	.1132	.132		.132	.1132	.1509
18	.1132	.0943	.1509	.1132	.132	.132	.1509
19	.132	.1886	.1132	.132	.1509	.1698	.1509
20	.1509	.1698	.1509	.1509	.1509	.1698	.1698
21	.132	.132	.132	.132	.1509	.1509	.1698
22	.6722	.7865	.7459	.1132	.132	.132	
23	.7042	.7287	.7293	.0943	.132	.1132	
24	.57	.68	.7287	.6962	.0943	.132	.1132
Max	.8122	.9172	.9831	1.1012	1.1523	1.4255	.1698
Min	.0566	.0943	.0754	.0943	.0943	.1132	.1132
Avg	.3201	.3696	.3725	.6342	.4496	.4913	.1346

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244082 / 33/11 kv Arag

Feeder No / Name : 205 / Malwadi Ag feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.1132	.1509	.132	1.668	1.7814	1.7204
2	.0943	.1132	.132	.1132	1.6004	1.7004	1.7204
3	.0943	.1132	.132	.1132	1.5684	1.7004	1.6057
4	.0943	.1132	.132	.132	1.5684	1.7814	1.5402
5	.0943	.132	.1698	.132	1.5844	1.7814	1.704
6	.1132	.1698	.1886	.1509	1.9725	1.9919	1.989
7	.1698	.2452	.2075	.1886	2.3205	2.2834	2.2377
8	.1698	.1698	.1886	.1698	.2075	.1886	.1886
9	1.2308	1.7368	2.2119	.1509	.2263	.1509	2.5692
10	1.4413	1.8679	2.2672	.1886	.2263	.1698	2.7018
11	1.5708	1.9662	2.2996	.1698	.2452	.2452	2.5396
12	1.5223	1.8842	2.0243	.1886	.2263	.2452	2.4086
13	1.6518	1.8842	2.0405	.2263	.2075	.2075	2.3594
14	1.5708	1.8023	1.8623	.2075	.2641	.2452	2.3266
15	1.3123	1.7204	2.0243	.2075	.2452	.2263	2.3758
16	.873	1.7204	2.0729	.1886	.2452	.2263	2.4413
17	.1132	.1509	.132	.1886	.2263	.2075	.1886
18	.1698	.1509	.1509	.1886	.2263	.2263	.2075
19	.1698	.1698	.1886	.2075	.2452	.2641	.2075
20	.1886	.1886	.1886	.2263	.2263	.2829	.2075
21	.1698	.1886	.1886	.1886	.2263	.2641	.1886
22	.1509	.1698	.1698	1.9393	1.9919	1.8351	
23	.132	.1698	.1509	1.8187	1.8785	1.7368	
24	.0943	.132	.1509	.132	1.7004	1.7814	1.704
Max	1.6518	1.9662	2.2996	1.9393	2.3205	2.2834	2.7018
Min	.0943	.1132	.132	.1132	.2075	.1509	.1886
Avg	.5536	.7114	.8094	.3145	.8791	.8968	1.5969

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244136 / 33/11kV SALGARE

Feeder No / Name : 201 / Salgare Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244136 / 33/11kV SALGARE

Feeder No / Name : 202 / Chabukswarwadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

MIRAJ RURAL-II S/DN.[788] BU 4788

Substation No/ Name :- 244136 / 33/11kV SALGARE

Feeder No / Name : 203 / Janraowadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 202 / 11 KV BHIVARGI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	.2286
Max	.2286
Min	.2286
Avg	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 203 / 11 KV ANKALGI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	.1905
Max	.1905
Min	.1905
Avg	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 204 / 11 KV SANKH GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	.1905
Max	.1905
Min	.1905
Avg	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 205 / 11 KV ANKALGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	.6962
Max	.6962
Min	.6962
Avg	.6962

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 206 / 11 KV ASANGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	.663
Max	.663
Min	.663
Avg	.663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244015 / 110/33/11 KV SANKH

Feeder No / Name : 207 / 11 KV SANKH AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	.2858
Max	.2858
Min	.2858
Avg	.2858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 201 / 11 KV AKKALWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1658	.2984	.2984	.2881	.0953	.1143	.1143
2	.1989	.2515	.3353	.2915	.0953	.1334	.1143
3	.2012	.2949	.4527	.3113	.1143	.1334	.1334
4	.3185	.3353	.4917	.3441	.1334	.1715	.1334
5	.3391	.4239	.503	.3856	.1524	.2096	.1524
6	.3772	.6068	.5596	.463	.1715	.2096	.1905
7	.9156	1.1022	1.0227	.7716	.1905	.2286	.1905
8	.1143	.1524	.1524	.1334	.1524	.2286	.1715
9	.0762	.0953	.0953	.5668	.7682	.9282	.1905
10	.0953	.1143	.0953	.6325	.7748	1.0402	.1524
11	.1143	.1143	.0953	.7042	.9922	1.0526	.1143
12	.0953	.0953	.0953	.5468	.8796	1.1336	.1143
13	.0762		.0762	.5851	.9259	1.2003	.1143
14	.0572	.0953	.0762	.759	.8179	1.2308	.1143
15	.0762	.0572	.0572	.8223	.8905	1.2955	.1143
16	.0762	.0762	.0762	.8223	.7773	1.2651	.1143
17	.0762	.0762	.0762	.0762	.1143	.0762	.1143
18	.0953	.0953	.1143	.0953	.0953	.1143	.1143
19	.0953	.1334	.1143	.1524	.1334	.1143	.1143
20	.1334	.1524	.1524	.1524	.1715	.1715	.1715
21	.0953	.1524	.1524	.0953	.1715	.1905	.1524
22	.3353	.3077	.3277	.0762	.1334	.1524	.8139
23	.3277	.3018	.3201	.1143	.1143	.1334	.7865
24	.1638	.3315	.3018	.3201	.0953	.1143	.1334
Max	.9156	1.1022	1.0227	.8223	.9922	1.2955	.8139
Min	.0572	.0572	.0572	.0762	.0953	.0762	.1143
Avg	.1925	.2463	.2518	.3962	.3734	.4851	.1929

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 202 / 11 KV BORGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1334	.1143	.1334	.2883	.4744	.4973
2	.0953	.1524	.1143	.1334	.3185	.5182	.5079
3	.1334	.1524	.1334	.1524	.2984	.5801	.5243
4	.1715	.1715	.1905	.1524	.3391	.5868	.5801
5	.1905	.1905	.1905	.1905	.3814	.7545	.6371
6	.1905	.2667	.2858	.2667	.7186	.8478	.9326
7	.1905	.3048	.2858	.3048	1.1361	1.6956	1.3032
8	.2096	.2667	.2477	.1715	.1905	.2477	.2477
9	.2753	.4475	.6081	.1715	.1715	.2096	1.467
10	.2785	.5487	.6882	.1334		.1334	1.1431
11	.4111	.2812	.6859	.1143		.1334	1.3757
12	.3593	.442	.7926	.1143		.1143	1.4198
13	.4268	.5792	.7468	.1143		.1524	1.4217
14	.3353	.5093	.7316	.1143	.1524	.1715	1.4998
15	.2439	.503	.6249	.1334	.1905	.1715	1.358
16	.2469	.571		.1143	.1905	.1524	1.2955
17	.1715	.1143		.0953	.1715	.1905	.1524
18	.2096	.1334		.1524	.2286	.1715	.1524
19	.2667	.2096	.2096	.2096	.0953	.2477	.2477
20	.2286	.2286	.2667	.1905	.2858	.2667	.2477
21	.2096	.1905	.2096	.1524	.2286	.2286	.2286
22	.1524	.1334	.1524	.3353	.6154	.6371	.1524
23	.1334	.1334	.1334	.3113	.506	.5304	.1524
24	.0953	.1334	.1143	.1334	.2984	.4938	.5079
Max	.4268	.5792	.7926	.3353	1.1361	1.6956	1.4998
Min	.0953	.1143	.1143	.0953	.0953	.1143	.1524
Avg	.2217	.2832	.3584	.1706	.3403	.4046	.7522

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 203 / 11 KV BALGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2486	.3647		.6081	.1334	.1524	.1334
2	.2984	.3441		.6478	.1715	.1715	.1334
3	.3353	.3768		.6882	.1715	.2096	.1524
4	.4191	.4191		.7373	.2096	.3048	.1715
5	.5426	.5935		.9054	.2667	.381	.2477
6	.6173	.9536		1.1488	.381	.4001	.362
7	1.2378	1.4413		1.5089	.3048	.3239	.3429
8	.2286	.2477		.2286	.2096	.2477	.1905
9	.1524	.1524		.9231	1.1683	1.2803	.1524
10	.1334	.1334	.1715	1.012	.759	1.2003	.1143
11	.0953	.0762	.2096	1.0402	1.0722	1.4575	.1524
12	.1524	.3429	.1334	1.0467	1.0802	1.4413	.1524
13	.1143	.2286	.1334	.8539	1.142	1.6004	.1524
14	.1143	.2286	.1334	.8223	.8951	1.6194	.1715
15	.2286	.0953	.2667	1.0279	1.2811	1.7004	.1524
16	.1715	.2096	.2858	1.0437	1.1736	1.5971	.1524
17	.0953	.1715	.1334	.1143	.1524	.1905	.1715
18	.1334	.1334	.1715	.1524	.1715	.2096	.2477
19	.2477	.2286	.1905	.2286	.2286	.2667	
20	.2667	.2096	.2477	.2477	.2477	.2667	.2667
21	.1905	.1715	.1905	.2096	.1905	.2096	.2286
22	.4191		.6062	.1524	.1524	.1715	1.17
23	.3768		.5761	.1334	.1524	.1334	1.0322
24	.2458	.3481		.5921	.1334	.1524	.1524
Max	1.2378	1.4413	.6062	1.5089	1.2811	1.7004	1.17
Min	.0953	.0762	.1334	.1143	.1334	.1334	.1143
Avg	.2944	.3396	.2464	.6697	.4937	.6537	.2697

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGI

Feeder No / Name : 204 / 11 KV AKKALWADI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0572	.0572	.0762	.0572	.0572
2	.0572	.0762	.0572	.0572	.0572	.0572	.0762
3	.0762	.0762	.0572	.0572	.0572	.0762	.0762
4	.0762	.0953	.0762	.0762	.0762	.0953	.0953
5	.0953	.1143	.0953	.0953	.0762	.1143	.0953
6	.1143	.1334	.0953	.1334	.0953	.1143	.1334
7	.0953	.1334	.0953	.1524	.1143	.0953	.1334
8	.0953	.0953	.0762	.1334	.0953	.0953	.0953
9	.0762	.0953	.0762	.0762	.0953	.0762	.0953
10	.0762	.0762	.0572	.0762	.0572	.0572	.1524
11	.0762	.0762	.0572	.0953	.0572	.0572	.0953
12	.0762	.0572	.0572	.0953	.0762	.0572	.0762
13	.0953		.0572	.0762	.0572	.0572	.0953
14	.0762	.0572	.0572	.0762	.0572	.0572	.0953
15	.0953	.1143	.0572	.8223	.0762	.0572	.0762
16	.0953	.0762	.0572	.0953	.0762	.0572	.0762
17	.0953	.0762	.0762	.0762	.0762	.0572	.0953
18	.1143	.1143	.0953	.0762	.1143	.0762	.0953
19	.1334	.1143	.1143	.0953	.1143	.1143	.1143
20	.1524	.1524	.1524	.0953	.1334	.1715	.0953
21	.1143	.0953	.1334	.0953	.0953	.1524	.0953
22	.0953	.0762	.0953	.0762	.0953	.1143	.1143
23	.0762	.0762	.0572	.0762	.0762	.0762	.1143
24	.0572	.0572	.0572	.0572	.0572	.0762	.0572
Max	.1524	.1524	.1524	.8223	.1334	.1715	.1524
Min	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Avg	.0905	.0911	.0778	.1176	.0818	.0842	.0961

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244029 / 33/11 KV BORGHI

Feeder No / Name : 205 / 11 KV BORGHI BALGAON
GAVTHAN Feeder KV- 11 /
OUTGOING

GAOTHAN FEEDER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953	.0953	.0953	.0953	.0762
2	.0953	.0953	.0953	.0953	.0762	.0953	.0762
3	.1143	.1143	.1334	.1143	.0953	.1143	.0953
4	.1715	.1524	.1905	.1334	.1143	.1905	.1143
5	.2096	.1905	.2096	.1715	.1524	.2096	.1524
6	.2477	.2667	.2477	.2477	.2286	.2477	.2096
7	.2286	.2096	.1715	.2096	.2096	.1905	.1905
8	.1334	.1524	.1334	.1334	.1334	.1524	.1334
9	.1143	.1143	.0953	.1143	.0762	.1143	.0953
10	.0762	.0953	.1143	.0953	.0572	.0953	.0762
11	.0762	.0953	.0572	.0762	.0762	.1143	.0762
12	.0953	.0762	.0953	.0762	.0953	.0953	.0762
13	.0762	.0762	.1143	.0572	.1143	.0953	.0572
14	.0762	.0762	.0953	.0572	.0762	.0953	.0762
15	.0762	.0762	.0953	.0762	.0953	.1143	.0762
16	.0762	.0762	.1143	.0953	.1143	.1143	.0381
17	.1143	.1143	.1334	.1143	.1715	.1334	.1143
18	.1524	.0953	.1715	.1905	.1715	.1334	.1715
19	.2096	.1905	.2096	.1143	.2286	.2286	.2286
20	.2096	.2477	.2286	.1905	.2286	.2286	.1715
21	.1715	.2096	.1715	.1524	.1715	.2096	.1334
22	.1334	.1334	.1524	.1334	.1334	.1715	.1334
23	.1143	.0953	.0953	.0953	.1143	.0953	.1143
24	.0953	.0953	.0953	.0953	.0953	.1143	.0953
Max	.2477	.2667	.2477	.2477	.2286	.2477	.2286
Min	.0762	.0762	.0572	.0572	.0572	.0953	.0381
Avg	.1318	.1310	.1382	.1223	.1302	.1437	.1159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 201 / 11 KV SUSLAD AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.1886	.2587	.2801	1.848	1.1717	1.2003
2	.2987	.2012	.2012	.2987	1.9044	1.1561	1.2003
3	.3018	.2402	.1658	.2987	1.6975	1.1843	1.0883
4	.3206	.2829	.2772	.2801	1.4003	1.1683	1.2955
5	.3326	.3174	.2957	.3174	1.3769	1.1984	1.3765
6	.2987	.3018	.3584	.4108	1.8671	2.1052	1.442
7	.3395	.3361	.3395	.3547	2.0182	1.9433	1.9062
8	.2987	.2829	.2427	.3547	.2987	.2801	.2743
9	.7545	1.0898	1.8671		.3174	.2054	
10		1.0936	1.7193		.1949	.2054	
11		1.1138	1.7394		.1595	.2054	
12	.8402	1.174	1.6766		.1595	.2987	
13	1.2936	1.2616	1.6766		.1829	.2614	
14	1.1584	1.2308	1.9879		.2012	.2614	
15	1.0719	1.2803	1.97		.2126		
16	1.0269	1.3117	1.9951		.1772		
17	.1886	.1848	.2507		.2507		
18	.2218	.2218	.3584		.2865		
19	.2561	.2614	.3018		.2865		
20	.2957	.2801			.3511	.2801	
21	.2172	.2801	.3206		.3511	.2614	
22	.1829	.2957	.2614		1.2342	1.2003	
23	.1848	.3174	.3206		1.2811	1.1488	
24	.3174	.2054	.2987	.2801	1.8673	1.2029	1.1488
Max	1.2936	1.3117	1.9951	.4108	2.0182	2.1052	1.9062
Min	.1829	.1848	.1658	.2801	.1595	.2054	.2743
Avg	.4791	.5731	.8210	.3195	.8302	.8283	1.2147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 202 / 11 KV UMADI GAVTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.1698	.2452	.1867	.1509	.2241	.2054
2	.1886	.1886	.1886	.1663	.1698	.197	.1886
3	.2075	.2033	.2241	.1698	.1867	.2241	.1886
4	.2241	.2427	.2402	.181	.2218	.2507	.1698
5	.1886	.2218	.2743	.2561	.2402	.2987	.2561
6	.2801	.2641	.3475	.3582	.2801	.3734	.3206
7	.2957	.2926	.3841	.3224	.2926	.3658	.3361
8	.3045	.2715	.3012	.2865	.2686	.2926	.2614
9	.2715	.2507	.1715		.2804	.2218	
10	.2103	.2254	.197		.208	.2587	
11		.2058	.2149		.2401	.2218	
12	.1823	.1772	.1791		.2058	.2218	
13	.2012	.1781	.1791		.1734	.2218	
14	.1823	.2012	.1612		.1734	.2218	
15	.1898	.1753	.1646		.208	.2033	
16	.2006	.1928	.2561		.1715	.2218	
17	.2214	.2035	.2614		.2401	.3018	
18	.2683	.2347	.2865		.2401	.3326	
19	.3258	.298	.3582		.3258	.2957	
20	.3544	.2835	.3395		.3467	.2957	
21	.2896	.2926	.3018		.2957	.2987	
22	.2743	.2561	.2195		.2587	.2614	
23	.1867	.2957	.2195		.2218	.2195	
24	.2641	.1867	.2801	.2054	.1886	.2241	.2241
Max	.3544	.298	.3841	.3582	.3467	.3734	.3361
Min	.1823	.1698	.1612	.1663	.1509	.197	.1698
Avg	.2407	.2297	.2498	.2369	.2329	.2604	.2390

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 203 / 11 KV SONALGI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7449	.6081	.9282	.7225	.16	.2587	.2534
2	.6722	.5441	.8551	.8029	.144	.2241	.2534
3	.6081	.583	.9945	.7562	.1296	.2263	.2926
4	.6316	.6478	.9945	.8381	.1457	.2641	.3292
5	.5898	.6722	.9393	.9602	.1619	.3018	.3921
6	.5636	.9393	.9842	.9922	.2267	.415	.4108
7	1.1469	1.5384	1.6518	1.2003	.2267	.4066	
8	.2378	1.4575	.2743	.3113	.1943	.2987	.3734
9	.1848	.197	.2561		1.2125	1.4998	
10	.1781	.1267	.1848		1.4089	1.4632	
11		.2012	.1848		1.4752	1.531	
12	.1619	.1848	.1848		1.326		
13	.1943	.1772	.1848		1.3927	1.4746	
14	.1781	.2149	.1848		1.3927	1.3108	
15	.1619	.2218	.1867		1.4089	1.3927	
16		.2534	.1867		1.326	1.3435	
17	.1781	.2195	.1867		.3149	.3315	
18	.192	.2353	.2641		.3149	.3605	
19	.2241	.2587	.3018		.3315	.3113	
20	.2591	.2829	.3772		.3113	.2622	
21	.2429	.2801	.2987		.2987	.3149	
22	.4858	.7977	.7926		.2957	.2652	
23	.6478	.9116	.8122		.2587	.2713	
24	.8619	.6802	.9054	.7526	.1781	.2587	.2427
Max	1.1469	1.5384	1.6518	1.2003	1.4752	1.531	.4108
Min	.1619	.1267	.1848	.3113	.1296	.2241	.2427
Avg	.4248	.5097	.5464	.8151	.6098	.6429	.3185

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 204 / 11 KV UMADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	.1905
Max	.1905
Min	.1905
Avg	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244044 / 33/11 KV UMADI

Feeder No / Name : 205 / 11 KV SUSLAD GAVTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	.056	.0566	.0185	.0537	.0191
2	.0566	.0554	.056	.0381	.0189	.0358	.0191
3	.0373	.0739	.0377	.0191	.0373	.0362	.0381
4	.0566	.0914	.0373	.0566	.0554	.0747	.0754
5	.0747	.0554	.0754	.0905	.0747	.0895	.0934
6	.1132	.0747	.1132	.1097	.0943	.1307	.1494
7	.1143	.0924	.1307	.1097	.0566	.1402	.1307
8	.0934	.056	.1086	.0914	.0566	.0934	.0914
9	.0943	.056	.0537		.056	.0934	
10	.0747	.056	.0549		.0693	.056	
11	.0377	.0373	.0362		.052	.0537	
12	.0373	.0549	.0358		.052	.0537	
13	.0373	.0373	.0358		.0347	.0358	
14	.0189	.0373	.0179			.0358	
15	.0377	.0549	.0358		.0532	.0358	
16	.0362	.037	.0537		.052	.0537	
17	.0739	.0526	.0695		.0526	.0914	
18	.0934	.0937	.1075		.0351	.1433	
19	.1132	.1187	.1433		.1417	.1254	
20	.1187	.1052	.124		.124	.1109	
21	.0914	.0934	.1132		.0876	.128	
22	.0739	.0754	.0747		.0686	.0377	
23	.037	.056	.0747		.0514	.0366	
24	.0373	.0373	.0739	.0566	.0373	.0514	.0377
Max	.1187	.1187	.1433	.1097	.1417	.1433	.1494
Min	.0189	.037	.0179	.0191	.0185	.0358	.0191
Avg	.0665	.0642	.0716	.0698	.0600	.0749	.0727

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 201 / 11 KV MADGYAL AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1753	.1753	.1753	.4633	.4877	.6478
2	.1829	.1753	.1753	.1753	.4633	.4877	.6554
3	.1829	.1753	.1753	.1753	.4633	.4877	.6706
4	.2149	.2103	.2103	.1928	.4755	.5335	.8478
5	.2454	.2804	.2629	.2804	.5792	.6097	1.0631
6	.3224	.3506	.298	.3506	1.4842	1.1717	1.5043
7	.3155	.3155	.3155	.3155	1.5623	1.9662	1.6476
8	.2804	.2804	.2804	.2629	.2454	.2454	.394
9	.5201	.6859	.6859	.1753	.2103	.1753	1.4918
10	.5201	.6859		.1402	.1578	.1402	1.3916
11	.4877	.6097	.5335	.1402	.1578	.1448	1.4403
12	.5335	.5792	.6097	.1402	.1433	.1791	1.5203
13	.5335	.5647	.6097	.1294	.1402	.2195	1.4575
14	.6097	.5075	.8383	.1294	.1402	.2172	1.4575
15	.6401	.6687	.9145	.1227	.1402	.2033	1.4403
16	.5335	.743	.8173	.1227	.1402	.2195	1.4403
17	.1578	.1402	.1753	.1578	.1578	.2454	.2987
18	.1753	.1402	.1753	.1753	.1753	.3224	.2829
19	.298	.2804	.2454	.2629	.2454	.4207	.2829
20	.2804	.298	.2629	.2804	.2804	.4344	.3258
21	.1562	.2454	.2454	.2629	.2279	.4066	.362
22	.1753	.1753	.1753	.6687	.5335	.9614	.2829
23	.1753	.1753	.1753		.4877	.8097	.3018
24	.1829	.1753	.1753	.1753	.4633	.4877	.6478
Max	.6401	.743	.9145	.6687	1.5623	1.9662	1.6476
Min	.1562	.1402	.1753	.1227	.1402	.1402	.2829
Avg	.3294	.3599	.3710	.2179	.3974	.4824	.9106

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 202 / 11 KV SONYAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.16	.1562	.1898	.1581	.724	.724	.7811
2	.16	.1562	.1898	.16	.724	.743	.7907
3	.16	.1562	.1898	.16	.724	.743	.8002
4	.192	.1898	.208	.192	.743	.743	.9602
5	.2429	.2591	.2915	.3018	.9145	1.0155	1.2146
6	.3239	.4161	.3239	.421	1.6575	1.5565	1.704
7	.3563	.426	.421	.426	1.6194	2.3758	1.9989
8	.4534	.5121	.3201	.3521	.3239	.3563	.5761
9	.8916	1.1717	1.3889	.2881	.2721	.2753	1.8461
10	.9659	1.2193	1.3889	.16	.2401	.2401	1.9204
11	.7145	1.1888	1.2955	.16		.2343	1.7185
12	.743	1.086	1.2498	.1581	.2401	.2561	1.5432
13	.743	1.0715	1.2193	.16	.2401	.2846	1.6404
14	1.0059	1.0402	1.3117	.16	.2214	.2846	1.6604
15	.9907	.743	1.3117	.1898	.2214	.3041	1.7966
16	.724	.3734	1.1584	.2241	.25	.3239	1.8747
17	.1389	.1524	.2286	.25	.25	.3521	.3437
18	.1543	.1524	.2439	.2778	.2469	.4111	.3858
19	.2656	.3125	.3749	.3125	.2812	.5441	.3906
20	.2721	.3521	.4428	.3479	.3163	.506	.3906
21	.2401	.253	.2656	.2812	.25	.4428	.4801
22	.1562	.2214	.2372	1.0669	.8173	1.1138	.3239
23	.1562	.1898	.1898		.724	.9259	.3239
24	.16	.1562	.1898	.1562	.724	.724	.7811
Max	1.0059	1.2193	1.3889	1.0669	1.6575	2.3758	1.9989
Min	.1389	.1524	.1898	.1562	.2214	.2343	.3239
Avg	.4321	.4981	.6096	.2767	.5533	.6450	1.0936

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 203 / 11 KV UTAGI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.4801	.4938	.4801	.1265	.1235	.125
2	.2667	.4801	.4938	.4801	.1265	.1235	.1265
3	.2667	.4801	.4938	.4801	.1265	.1235	.128
4	.2667	.4801	.4938	.4934	.1265	.1235	.1619
5	.2934	.5487	.5487	.5068	.1265	.125	.2429
6	.4572	.8383	1.0402	.8488	.2949	.2785	.4915
7	.9907	1.3717	1.448	1.1431	.2881	.2753	.4534
8	.1562	.2241	.2187	.2372	.1898	.2187	.2846
9	.1372	1.406	.1581	.6081	1.2193	1.2308	.2267
10	.0892	.096	.096	.7859	1.2193	1.2631	.1581
11	.1067	.0914	.0617	.8288	1.2193	1.2631	.1143
12	.061	.0762	.061	.8573	1.0974	1.2631	.1097
13	.0594	.0743	.061	.6173	1.1584	1.2616	.1097
14	.061	.0724	.0617	.4668	1.1888	1.3375	.1143
15	.0762	.0743	.0617	.4668	1.2631	1.5051	.1113
16	.0743	.0686	.061	.5601	1.166	1.4299	.1113
17	.0892	.08	.1067	.096	.096	.2286	.141
18	.1189	.1067	.12	.1372	.1235	.2812	.1692
19	.1829	.2846	.1932	.2286	.2286	.3437	.1715
20	.1829	.2372	.216	.25	.2315	.3048	.2258
21	.1524	.1486	.1486	.25	.1486	.2709	.2258
22	.5487	.5487	.5068	.1265	.1235	.1698	.8173
23	.5213	.5213	.4934		.1235	.1406	.9536
24	.2667	.4801	.4938	.4668	.1265	.1235	.125
Max	.9907	1.406	1.448	1.1431	1.2631	1.5051	.9536
Min	.0594	.0686	.061	.096	.096	.1235	.1097
Avg	.2372	.3862	.3388	.4963	.5058	.5754	.2458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 204 / 11 KV SONYAL GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1132	.1132	.0943	.0943	.0943	.0934
2	.112	.1132	.1132	.0943	.0943	.0943	.0934
3		.1132	.1132	.0943	.0943	.0943	.0934
4	.0934	.1509	.1509	.132	.1132	.132	.1086
5		.2263	.2075	.2075	.2075	.2075	.1612
6		.3584	.3395	.3206	.3395	.3206	.3292
7		.3772	.3395	.3395	.3395	.3361	.3734
8		.3109	.2614	.2957	.2641	.2957	.2926
9		.1848	.1867	.1867	.2241	.2241	.1663
10		.1494	.112	.1509	.1663	.1494	.1463
11	.1463	.128	.1075	.112	.1109	.1097	.0914
12	.1402	.1097	.0934	.0739	.0934	.0924	.0732
13	.1526	.1097	.0934	.0924	.0943	.0914	.0914
14	.1402	.0914	.0895	.0943	.0934	.0905	.0914
15	.1267	.0914	.0886	.0934	.0934	.0914	.0905
16	.1267	.1063	.1052	.1294	.0876	.0914	.0905
17	.1578	.1372	.1341	.1677	.1433	.1086	.1463
18	.2058	.176	.1658	.2241	.1791	.1463	.1829
19	.2926	.2454	.2279	.3155	.2353	.3109	.1829
20	.2926	.2772	.2402	.3224	.2378	.2715	.2012
21	.2033	.2054	.2033	.1829	.1848	.2012	.2012
22	.1509	.1509	.1307	.1509	.132	.128	.1494
23	.132	.132	.112		.1132	.1097	.1132
24	.112	.1132	.1132	.0094	.0943	.0943	.0934
Max	.2926	.3772	.3395	.3395	.3395	.3361	.3734
Min	.0934	.0914	.0886	.0094	.0876	.0905	.0732
Avg	.1587	.1738	.1601	.1689	.1596	.1619	.1524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 205 / 11 KV UTAGI VHASPETH

GAOTHAN FEEDER

GAVTHAN Feeder KV- 11 /

OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0739	.0554	.0566	.0739	.0739	.0754
2	.056	.0739	.0554	.0566	.0739	.0739	.0754
3	.056	.0739	.0554	.0566	.0739	.0739	.0747
4	.056	.0739	.0554	.0754	.0739	.0739	.0914
5	.056	.0924	.0554	.0943	.0739	.0739	.1097
6	.112	.1307	.0924	.132	.1109	.0924	.132
7	.1307	.0924	.1097	.0924	.1109	.1109	.1132
8	.0934	.0554	.0739	.0747	.0554	.0924	.1227
9	.1109	.112	.1109	.0739	.0739	.0924	.1075
10	.128	.1307	.1109	.1075	.0739	.0924	.128
11	.1097	.1294	.1294	.1075	.0924	.0914	.0914
12	.1109	.1294	.0924	.1052	.0924	.0924	.0914
13	.112	.1109	.0739	.1097	.0924	.112	.1075
14	.1478	.0739	.1109	.1109	.0924	.0934	.1075
15	.1663	.0732	.1294	.0914	.0739	.0943	.1086
16	.168	.0924	.112	.1097	.0549	.1097	.1086
17	.1494	.0924	.1109	.1097	.0554	.1086	.0857
18	.1307	.0924	.1097	.0914	.0739	.1097	.0848
19	.1307	.128	.128	.1294	.1294	.1214	.0848
20	.1294	.128	.1463	.1478	.1478	.128	.1132
21	.1109	.0924	.1097	.1097	.1109	.132	.1132
22	.0924	.0924	.0914	.0914	.0924	.112	.0943
23	.0739	.0739	.0739		.0739	.0934	.0754
24	.056	.0739	.0739	.0566	.0732	.0739	.0754
Max	.168	.1307	.1463	.1478	.1478	.132	.132
Min	.056	.0554	.0554	.0566	.0549	.0739	.0747
Avg	.1060	.0955	.0944	.0952	.0854	.0968	.0988

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244047 / 33/11 KV SONYAL

Feeder No / Name : 206 / 11 KV LAMANTANDA AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2957	.2452	.2452	.0537	.0886	.0914
2		.2957	.2452	.2452		.0895	.0914
3		.3326	.2452	.2452	.0537	.0895	.0934
4		.2957	.2641	.2452	.0537	.0895	.112
5		.2957	.2829	.2452	.0537	.1097	.1494
6		.4904	.5975	.4527	.0754	.1494	.1829
7		.6908	.8029	.679	.0754	.1494	.1991
8		.081	.12	.1187	.0566	.0678	.1578
9		.0895	.1052	.5228	.3395	.7373	.1991
10		.0895	.1109	.5281	.3395	.7287	.2012
11		.0857	.1294	.6036	.4024	.7888	.1578
12		.1006	.1052	.7167	.695	.905	.1578
13		.0838	.0857	.6706	.7964	1.0242	.1753
14	.1254	.0671	.1086	.7762	.8238	.9955	.2279
15	.124	.0781	.1267	.8488	.8596	1.0317	.2629
16	.124	.0509	.1227	.7922	.5093	.9877	.298
17	.1029	.0937	.112	.0549	.0983	.1086	.298
18	.0791	.0949	.1094	.0312	.0972	.1463	.298
19	.0983	.124	.1006		.1052	.1791	.298
20	.1006	.124	.1017	.0709	.1433	.181	.2629
21	.0791	.12	.0829	.0686	.1187	.1829	.1928
22	.2957	.2452	.2452	.0543	.0895	.1097	.4382
23	.2957	.2452	.2452		.0886	.0914	.5609
24		.2957	.2452	.2452	.0537	.0886	.0914
Max	.2957	.6908	.8029	.8488	.8596	1.0317	.5609
Min	.0791	.0509	.0829	.0312	.0537	.0678	.0914
Avg	.1425	.1986	.2058	.3846	.2601	.3800	.2166

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 201 / 11 KV SIDHANATH AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4096	.4915	.4915	.5735	.1638	.1638	.1638
2	.4096	.4915	.4915	.5735	.1638	.1638	.1638
3	.4096	.4915	.4915	.5735	.1638	.1638	.1638
4	.4096	.6554	.4915	.5735	.1638	.1638	.1638
5	.6554	.9831	.8192	.6554	.1638	.1638	.1638
6	.8192	1.1469	1.2289	.8192	.1638	.1638	.1638
7	.9012	1.1469	1.2289	.9012	.1638	.1638	.1638
8	.1638	.1638	.1638	.1638	.1638	.1638	.1638
9	.0819	.1638	.0819	.9831	1.1469	1.6385	.1638
10	.0819	.1638	.0819	1.1469	1.3108	1.6385	.1638
11		.1638	.0819	1.1469	1.3108	1.6385	.1638
12		.1638	.0819	1.3203	1.4746	1.4746	.1638
13	.0819	.1638	.0819	1.1469	1.4746	1.6385	.1638
14	.0819	.1638	.0819	1.1469	1.4746	1.6385	.1638
15	.0819	.1638	.0819	1.1469	1.4746	1.6385	.1638
16	.0819	.1638	.0819	1.1469	1.3927	1.6385	.1638
17	.0819	.1638	.0819	.1638	.1638	.1638	.1638
18	.0819	.1638	.0819	.1638	.1638	.1638	.1638
19	.1638	.1638	.1638	.1638	.1638	.1638	.0819
20	.1638	.1638	.1638	.1638	.1638	.1638	.1638
21	.1638	.1638	.1638	.1638	.1638	.1638	.1638
22	.4915	.4915	.4915	.1638	.1638	.1638	1.1469
23	.4915	.5658	.5735	.1638	.1638	.1638	1.1469
24	.4096	.4915	.4915	.5735	.1638	.1638	.1638
Max	.9012	1.1469	1.2289	1.3203	1.4746	1.6385	1.1469
Min	.0819	.1638	.0819	.1638	.1638	.1638	.0819
Avg	.3053	.3854	.3447	.6558	.5700	.6485	.2423

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 202 / 11 KV DARIKONUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.081	.081	.0819	.081	.2429	.2458	.3239
2	.081	.081	.0819	.081	.2429	.2458	.3239
3	.081	.081	.0819	.081	.2429	.2458	.3239
4	.081	.081	.0819	.081	.2429	.2458	.3239
5	.081	.081	.0819	.081	.3239	.4915	.4858
6	.081	.081	.0819	.081	.6478	.8192	.4858
7	.081	.1619	.1638	.1619	.6478	.8192	.4858
8	.081	.1619	.1638	.081	.081	.1638	.081
9	.2429	.3239	.3277	.081	.081	.0819	.8097
10	.2429	.3239	.4915	.081	.081	.0819	.9717
11			.4915	.081	.081	.0819	.9717
12			.4915	.081	.081	.0819	.9717
13	.2429	.3277	.4858	.081	.0819	.081	.8097
14		.3277	.4858	.081	.081	.081	.8097
15		.3277	.4858	.081	.081	.081	.8097
16		.3277	.4858	.081	.0819	.081	.8097
17	.081	.0819	.081	.081	.0819	.081	.081
18	.081	.0819	.081	.081	.1638	.081	.081
19	.1619	.1638	.1619	.1619	.1638	.1619	.1619
20	.1619	.1638	.1619	.1619	.1638	.1619	.1619
21	.1619	.1638	.1619	.1619	.1638	.081	.081
22	.1619	.0819	.1619	.2429	.2458	.3239	.081
23	.081	.0819	.081	.2429	.2458	.3239	.081
24	.081	.081	.0819	.081	.2429	.2458	.3239
Max	.2429	.3277	.4915	.2429	.6478	.8192	.9717
Min	.081	.081	.081	.081	.081	.081	.081
Avg	.1236	.1667	.2307	.1080	.1997	.2245	.4521

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 203 / 11 KV SHEDYAL GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0566	.0566	.0566	.0566	.0566
2	.0566	.0566	.0566	.0566	.0566	.0566	.0566
3	.0566	.0566	.0566	.0566	.0566	.0566	.0566
4	.0566	.0566	.0566	.0566	.0566	.0566	.0566
5	.0566	.0566	.0566	.0566	.0566	.0566	.0566
6	.0754	.0566	.0566	.0566	.0566	.0566	.0754
7	.0754	.0566	.0754	.0566	.0566	.0566	.0754
8	.0566	.0566	.0754	.0566	.0566	.0566	.0566
9	.0566	.0566	.0566	.0566	.0566	.0566	.0566
10	.0566	.0566	.0566	.0566	.0566	.0566	.0566
11		.0566	.0566	.0566	.0566	.0566	.0566
12		.0566	.0566	.0566	.0566	.0566	.0566
13	.0566	.0566	.0566	.0566	.0566	.0566	.0566
14	.0566	.0566	.0566	.0566	.0566	.0377	.0377
15	.0566	.0492	.0566	.0566	.0566	.0377	.0566
16	.0566	.0566	.0566	.0566	.0566	.0566	.0566
17	.0566	.0566	.0566	.0566	.0819	.0566	.0566
18	.0566	.0566	.0566	.0943	.1132	.0754	.0754
19	.0943	.0943	.0943	.0943	.1132	.0943	.0943
20	.0943	.0943	.0943	.0943		.0943	.0943
21	.0943	.0943	.0934	.0943	.1132	.0943	.0943
22	.0943	.0566	.056	.0943	.0566	.0754	.0754
23	.0566	.0566	.056	.0566	.0566	.0566	.0566
24	.0566	.0566	.0566	.056	.0566	.0566	.0566
Max	.0943	.0943	.0943	.0943	.1132	.0943	.0943
Min	.0566	.0492	.056	.056	.0566	.0377	.0377
Avg	.0652	.0610	.0628	.0644	.0651	.0613	.0637

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 204 / 11 KV SHEDYAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0848	.0848	.0819	.0848	.4239	.4096	.6783
2	.0848	.0848	.0819	.0848	.4239	.4096	.6783
3	.0848	.0848	.0819	.0848	.4239	.4096	.6783
4	.0848	.0848	.0819	.0848	.5087	.4096	.6783
5	.0848	.0848	.0819	.0848	.8478	.6554	.8478
6	.0848	.0848	.0819	.0848	1.0174	.9831	.8478
7	.0848	.1696	.1638	.1696	1.0174	.9831	.9326
8	.0848	.1696	.1638	.0848	.1696	.1638	.0848
9	.2543	.4239	.3277	.0848	.0848	.0629	1.0174
10	.2543	.4239	.4915	.0848	.0848	.0819	1.1869
11		.4239	.4915	.0848	.0848	.0819	1.1869
12		.2543	.4915	.0848	.0848	.0819	1.1869
13	.2543	.3605	.5087	.0848	.0819	.0848	1.1869
14	.2543	.3605	.5087	.0848	.0819	.0848	1.3056
15	.2543	.3605	.5087	.0848	.0819	.0848	1.1869
16	.2543	.3605	.5087	.0848	.0819	.0848	1.1869
17	.0848	.0819	.0848	.0848	.0819	.0848	.0848
18	.0848	.0819	.0848	.0848	.1638	.0848	.0848
19	.1696	.1638	.1696	.1696	.1638	.1696	.1696
20	.1696	.1638	.1696	.1696	.1638	.1696	.1696
21	.1696	.1638	.1696	.1696	.1638	.1696	.0848
22	.1696	.0819	.1696	.4239	.4096	.6783	.0848
23	.0848	.0819	.0848	.4239	.4096	.6783	.0848
24	.0848	.0848	.0819	.0848	.4239	.4096	.6783
Max	.2543	.4239	.5087	.4239	1.0174	.9831	1.3056
Min	.0848	.0819	.0819	.0848	.0819	.0629	.0848
Avg	.1464	.1967	.2363	.1272	.3117	.3132	.6797

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 205 / 11 KV DARIKONUR GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0566	.0566	.056	.056	.0566	.0566
2	.0377	.0566	.0566	.056	.056	.0566	.0566
3	.0377	.0566	.0566	.056	.056	.0566	.0566
4	.0566	.0566	.0566	.056	.056	.0566	.0566
5	.0566	.0566	.0566	.056	.056	.0566	.0566
6	.0566	.0566	.0566	.056	.056	.0566	.0566
7	.0566	.0566	.0754	.056	.056	.0566	.0566
8	.0566	.0566	.0754	.056	.056	.0566	.0566
9	.0566	.0566	.0566	.056	.056	.0566	.0566
10	.0566	.0566	.0566	.056	.056	.0566	.0566
11		.0566	.0566	.056	.056	.0566	.0566
12		.0566	.0566	.056	.056	.0566	.0566
13	.0566	.0566	.0377	.056	.0566	.0566	.0377
14	.0566	.0566	.0377	.056	.0566	.0377	.0377
15	.0566	.0566	.0566	.056	.0566	.0377	.0377
16	.0566	.0566	.0566	.056	.0566	.0566	.0566
17	.0566	.0566	.0566	.056	.0943	.0566	.0566
18	.0566	.0566	.0566	.0934	.0983	.0754	.0754
19	.0943	.0943	.0943	.0934	.1132	.0943	.0943
20	.0943	.0943	.0943	.0934	.1132	.1132	.0943
21	.0943	.0943	.0943	.0934	.1132	.1132	.0943
22	.0943	.0566	.0566	.0934	.0566	.0754	.0566
23	.0566	.0566	.0566	.056	.0566	.0566	.0566
24	.0566	.0566	.0566	.0566	.056	.0566	.0566
Max	.0943	.0943	.0943	.0934	.1132	.1132	.0943
Min	.0377	.0566	.0377	.056	.056	.0377	.0377
Avg	.0609	.0613	.0613	.0638	.0667	.0629	.0597

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 206 / 11 KV SIDDHANATH GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.0754	.0754	.0754	.0754	.0754
2	.0754	.0754	.0754	.0754	.0754	.0754	.0754
3	.0754	.0754	.0754	.0754	.0754	.0754	.0754
4	.0754	.0754	.0754	.0754	.0754	.0754	.0754
5	.0754	.0754	.0754	.0754	.0754	.0754	.0754
6	.0943	.0754	.0754	.0754	.0754	.0754	.0754
7	.0943	.0754	.0943	.0754	.0754	.0754	.0754
8	.0754	.0754	.0943	.0754	.0754	.0754	.0754
9	.0754	.0754	.0754	.0754	.0754	.0754	.0754
10	.0754	.0754	.0754	.0754	.0754	.0754	.0754
11		.0754	.0754	.0754	.0754	.0754	.0754
12		.0754	.0754	.0754	.0566	.0754	.0754
13	.0754	.0754	.0754	.0754	.0566	.0754	.0566
14	.0754	.0754	.0754	.0754	.0566	.0754	.0566
15	.0754	.0754	.0754	.0754	.0566	.0754	.0566
16	.0754	.0754	.0754	.0754	.0566	.0754	.0566
17	.0754	.0754	.0754	.0754	.1132	.0754	.0754
18	.0943	.0754	.0943	.132	.132	.0754	.0943
19	.132	.132	.132	.132	.132	.1132	.1132
20	.132	.132	.132	.1509	.132	.132	.132
21	.132	.132	.132	.1509	.132	.132	.132
22	.0943	.0754	.132	.1509	.0754	.1132	.132
23	.0754	.0754	.0754	.0754	.0754	.0754	.1132
24	.0754	.0754	.0754	.0754	.0754	.0754	.0754
Max	.132	.132	.132	.1509	.132	.132	.132
Min	.0754	.0754	.0754	.0754	.0566	.0754	.0566
Avg	.0866	.0825	.0872	.0896	.0825	.0833	.0833

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 207 / 11 KV DARIBADCHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4096	.6554	.6554	.5735	.1638	.2458	.2458
2	.4096	.6554	.6554	.5735	.1638	.2458	.2458
3	.4096	.6554	.6554	.5735	.1638	.2458	.2458
4	.4915	.6554	.6554	.5735	.1638	.2458	.2458
5	.4915	.8192	.8192	.6554	.1638	.2458	.2458
6	.6554	1.1469	1.1469	.9831	.1638	.2458	.3277
7	.8192	1.3108	1.1469	1.1469	.2458	.3277	.3277
8	.2458	.3277	.2458	.2458	.2458	.3277	.3277
9	.1638	.2458	.1638	.9831		1.7204	.3277
10	.1638	.2458	.1638	1.3108	1.4746	1.7204	.3277
11		.1638	.1638	1.3108	1.4746	1.6385	.2458
12		.1638	.1638	1.3108	1.8023	1.8023	.2458
13	.1638	.1638	.1638	1.3108	1.6385	1.8023	.2458
14	.1638	.1638	.1638	1.3108	1.6385	1.8023	.2458
15	.1638	.1638	.1638	1.3108	1.7204	1.8023	.2949
16	.1638	.1638	.1638	1.3108	1.6385	1.8023	.2458
17	.2458	.1638	.1638	.1638	.2458	.2458	.2458
18	.2458	.1638	.1638	.3277	.3277	.2458	.3277
19	.3277	.3277	.3277	.3277	.3277	.3277	.3277
20	.3277	.3277	.3277	.3277	.3277	.3277	.3277
21	.3277	.3277	.3277	.3277	.3277	.3277	.3277
22	.5735	.5735	.4915	.2458	.2458	.3277	1.1469
23	.6554	.6554	.5735	.1638	.2458	.2458	1.1469
24	.4096	.6554	.6554	.5735	.1638	.2458	.2458
Max	.8192	1.3108	1.1469	1.3108	1.8023	1.8023	1.1469
Min	.1638	.1638	.1638	.1638	.1638	.2458	.2458
Avg	.3649	.4540	.4301	.7476	.6554	.7715	.3537

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244049 / 33/11 KV DARIKONUR

Feeder No / Name : 208 / 11 KV MUCHANDI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0819	.1638	.0819	.1638	.8192	.8192	.8192
2	.0819	.1638	.0819	.1638	.8192	.8192	.8192
3	.0819	.1638	.0819	.1638	.8192	.8192	.8192
4	.1638	.1638	.0819	.1638	.8192	.8192	.8192
5	.1638	.1638	.0819	.1638	1.1469	1.1469	1.1469
6	.1638	.1638	.0819	.1638	1.4746	1.6385	1.3108
7	.1638	.1638	.1638	.1638	1.4746	1.7204	1.3927
8	.1638	.1638	.1638	.1638	.1638	.1638	.1638
9	.4915	.6554	.8192	.1638	.1638	.1638	1.1469
10	.6554	.8192	1.1469	.1638	.1638	.1638	1.3108
11		.8192	1.1469	.1638	.1638	.1638	1.4746
12		.9831	1.065	.1638	.1638	.1638	1.5565
13	.6554	.9012	1.065	.1638	.1638	.0762	1.4746
14	.6554	.9831	1.065	.1638	.1638	.0819	1.4746
15	.7373	.9831	1.1469	.1638	.1638	.0819	1.4746
16	.7373	.9831	1.1469	.1638	.1638	.0819	1.4746
17	.0819	.1638	.0819	.1638	.1638	.1638	.1638
18	.0819	.1638	.0819	.1638	.1638	.1638	.1638
19	.1638	.1638	.1638	.1638	.1638	.1638	.1638
20	.1638	.1638	.1638	.1638	.1638	.1638	.1638
21	.1638	.1638	.1638	.1638	.1638	.1638	.1638
22	.1638	.1638	.1638	.8192	.8192	.8192	.1638
23	.1638	.1638	.1638	.8192	.8192	.8192	.1638
24	.1638	.1638	.1638	.1638	.8192	.8192	.8192
Max	.7373	.9831	1.1469	.8192	1.4746	1.7204	1.5565
Min	.0819	.1638	.0819	.1638	.1638	.0762	.1638
Avg	.2793	.4062	.4403	.2184	.5052	.5083	.8602

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 201 / 11 KV TIKONDI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0497	.0655	.0663	.0648	.2683	1.1012	.8192
2	.0497	.0655	.0655	.0648	.2486	1.0774	.8097
3	.0492	.0648	.0655	.0648	.2374	1.065	.8421
4	.0655	.0648	.0655	.0655	.2713	1.1305	.8421
5	.0655	1.3603	.0655	.0655	.3018	1.1984	.9175
6	.0655	1.3765	.0983	.1147	.3605	1.4737	1.5074
7	.0983	.0983	.0972	.1311	.5182	1.7284	1.6385
8	.0995	.0819	.0838	.1147	.0838	.3353	.2915
9	.3277	.3113	.3563	.081	.0829	.2984	1.2955
10	.3605	.2915	.4049	.081		.2984	1.8138
11	.3605	.3239	.3887	.081		.2652	1.8404
12	.3563	.3401	.3887	.0663		.2652	1.9204
13	.3401	.2915	.421	.0663		.2458	1.8244
14	.3239	.3563	.4321	.0671		.2591	1.7284
15	.3239	.3401	.4161	.0671		.2753	1.7924
16	.3239	.3239	.4001	.0671		.2753	1.749
17	.0655	.0739	.064	.0739		.2267	.1867
18	.0655	.0732	.08	.0934	.0739	.2401	.2801
19	.0819	.1109	.096	.1307	.3361	.2881	.3696
20	.0819	.0924	.0972	.1494	.3696	.2915	.4108
21	.0655	.0924	.081	.112	.3326	.2753	.3361
22	.0655	.0678	.081	.2652	1.1271	.7773	.2652
23	.0655	.0678	.0648	.2683	1.1822	.8192	.2652
24	.0497	.0655	.0663	.0648	.2683	1.1336	.8192
Max	.3605	1.3765	.4321	.2683	1.1822	1.7284	1.9204
Min	.0492	.0648	.064	.0648	.0739	.2267	.1867
Avg	.1584	.2667	.1852	.1009	.3789	.6394	1.0236

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 202 / 11 KV KONTEBOBLAD AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0829	.1296	.1326	.1475	
2	.0829	.1296	.1326	.1311	
3	.0829	.1296	.1326	.1134	
4	.1147	.1296	.1311	.1134	
5	.1311	.1638	.1475	.1296	
6	.1802	.1966	.1638	.1638	
7	.1943	.2294	.213	.1966	
8	.2012	.2267	.1677	.213	.2374
9	.6554	.7449	.9069	.1802	.2486
10	.6554	.8907	.9878	.1619	
11	.6478	.9122	1.1012	.1296	
12	.664	.9282	1.1336	.1326	
13	.6802	.8421	1.0402	.1341	
14	.6401	.7773	.9922	.1174	
15	.7682	.7773	1.0082	.116	
16	.8002	.6478	1.004	.1341	
17	.1134	.1109	.081	.1867	
18	.1296	.1848	.0972	.2218	.1494
19	.1457	.2012	.1619	.2587	
20	.1475	.1829	.1638	.2587	
21	.1475	.1829	.1475	.2241	
22	.1311	.1341	.1475		
23	.1311	.1509	.1475		
24	.0838	.1311	.1492	.1638	
Max	.8002	.9282	1.1336	.2587	.2486
Min	.0829	.1109	.081	.1134	.1494
Avg	.3171	.3806	.4371	.1649	.2118

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 203 / 11 KV PANDOZARI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3441	.4973	.4807	.5898	.2683	.218	.3277
2	.3277	.4641	.4807	.5735	.2543	.1865	.3239
3	.3277	.4588	.4973	.5801	.2543	.1844	.3077
4	.3605	.4915	.5243	.5801	.285	.2818	.3077
5	.3887	.5243	.5898	.6299	.431	.3481	.3441
6	.5506	1.0608	1.004	1.4582	.5138	.4915	.5407
7	1.5223		1.7328	1.5893	.4973	.6226	.5735
8	.4475	.0332	.3521	.3605	.4578	.4527	.5407
9	.2785	.0328	.2984	1.4746	1.6842	1.7652	.4915
10	.213	.2622	.2458	1.4899	1.9109	2.0805	.4049
11	.1619	.2591	.1802	1.4737	1.9134	2.1605	.3887
12	.2105	.2429	.1966	1.3927	1.9685	2.1765	.3887
13	.2105	.2105	.1943	1.4251	1.9685	2.1376	.3978
14	.176	.2267	.1781	1.4737	1.9433	2.1052	.4191
15	.192	.2429	.1781	1.587	1.9433	2.0405	.3856
16	.208	.2591	.2753	1.5384	1.8947	2.0081	.3481
17	.2241	.3511	.2429	.2402	.3174	.2721	.4435
18	.2591	.3326	.2753	.3174	.3511	.3041	.5228
19	.2812	.4024	.3768	.4251	.3658	.3239	.6099
20	.2753	.4572	.3277	.4435	.3658	.3725	.567
21	.2591	.3841	.2622	.3734	.3547	.3725	.4805
22	.5735	.5138	.7373	.3174	.3185	.3441	1.2793
23	.5243	.5138	.6718	.285	.2321	.3277	1.3441
24	.3481	.4973	.4973	.5898	.2713	.218	.3277
Max	1.5223	1.0608	1.7328	1.5893	1.9685	2.1765	1.3441
Min	.1619	.0328	.1781	.2402	.2321	.1844	.3077
Avg	.3610	.3791	.4500	.8837	.8652	.9081	.5027

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 204 / 11 KV TIKONDI GAVTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.056	.056	.0739	.0934	.0934	.1109
2	.056	.056	.056	.0739	.0739	.0754	.0924
3	.0554	.0554	.0566	.0739	.0747	.0934	.0924
4	.0739	.0739	.0754	.0747	.0934	.1307	.0924
5	.0924	.0924	.0934	.112	.1294	.2033	.112
6	.1494	.1307	.1494	.1478	.2033	.1848	.168
7	.1867	.1494	.1867	.1663	.2241	.2012	.2241
8	.168	.1494	.1109	.1494	.1848	.1867	.1494
9	.1494	.1294	.1109	.112	.128	.1478	.1494
10	.1307	.0924	.1109	.1109		.1109	.1663
11	.0924	.0914	.1097	.0924	.1478	.1478	.1478
12	.0739	.0914	.0914	.0924	.1109	.1294	.1663
13	.0732	.0914	.0905	.0934	.0934	.1463	.1663
14	.0732	.0732	.0905	.0924	.0934	.1463	.1829
15	.0732	.0732	.0905	.0924		.1448	.0934
16	.0732	.0914	.0724	.128		.1448	.1109
17	.0905	.1109	.0914	.1307		.1629	.112
18	.1267	.1109	.1097	.1494	.1494	.1629	.1478
19	.1463	.1478	.1463	.1848	.2402	.1829	.1867
20	.1463	.1867	.1478	.2054	.2218	.1829	.2218
21	.1097	.1867	.1294	.1663	.1867	.1663	.2054
22	.0924	.1307	.1109	.1307	.1663	.1478	.1663
23	.0739	.0934	.0924	.112	.1307	.1109	.1294
24	.0747	.0747	.0747	.0739	.0934	.0934	.1109
Max	.1867	.1867	.1867	.2054	.2402	.2033	.2241
Min	.0554	.0554	.056	.0739	.0739	.0754	.0924
Avg	.1023	.1058	.1022	.1183	.1420	.1457	.1461

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 205 / 11 KV PANDOZARI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0572	.0572	.0572	.0572	.0381	.0572
2		.0572	.0572	.0572	.0381	.0381	.0572
3		.0572	.0572	.0572	.0381	.0572	.0572
4	.0057	.0572	.0762	.0572	.0572	.0762	.0572
5	.0095	.0762	.0953	.0572	.0953	.1143	.0762
6	.0152	.1143	.0953	.1143	.1334	.1334	.1334
7	.0191	.1334	.1143	.1524	.1524	.1334	.1524
8	.0191	.1143	.0953	.1143	.1143	.0953	.1143
9	.0191	.0762	.0762	.0762	.0572	.0762	.0953
10		.0572	.0572		.0572	.0381	.0572
11		.0572	.0381	.0381	.0191	.0381	.0572
12		.0572	.0191	.0381	.0381	.0381	.0381
13		.0381	.0381	.0381	.0381	.0381	.0381
14	.0572	.0381	.0381	.0381	.0381	.0381	.0191
15	.0572	.0381	.0381	.0381	.0381	.0381	.0381
16	.0572	.0191	.0381	.0381	.0381	.0381	.0381
17	.0572	.0381	.0381	.0381	.0381	.0381	.0381
18	.0762	.0572	.0572	.0572	.0381	.0572	.0762
19	.1334	.0953	.0762	.0762	.1143	.0953	.1143
20	.1334	.1143	.1143	.1143	.1143	.1334	.1334
21	.1143	.0762	.1143	.0953	.0953	.1143	.1143
22	.0762	.0572	.0762	.0762	.0762	.0762	.0762
23	.0572	.0572	.0572	.0572	.0572	.0762	.0572
24		.0572	.0572	.0572	.0572	.0572	.0572
Max	.1334	.1334	.1143	.1524	.1524	.1334	.1524
Min	.0057	.0191	.0191	.0381	.0191	.0381	.0191
Avg	.0567	.0667	.0659	.0671	.0667	.0699	.0731

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 206 / 11 KV KAGNARI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2204	.3391	.373	.4917	.1865	.1696	.2374
2	.2035	.3222	.373	.4748	.1509	.1715	.2035
3	.2035	.3391	.39	.4694	.1658	.1865	.2035
4	.218	.373	.407	.4696	.2012	.2204	.2035
5	.2347	.503	.4359	.503	.2155	.2683	.2543
6	.3353	.9221	.6203	.8309	.2984	.3353	.407
7	.8648	1.0059	1.3413		.3688	.4475	.503
8		.3185	.3222		.285	.407	.5868
9		.285	.2713		1.1984	1.4737	.6036
10		.2012	.2204		1.4883	1.8947	.3391
11		.2035	.1844	1.0059	1.4737	1.9524	.3561
12		.1696	.218	1.4089	1.7166	2.0485	.5087
13		.1677	.218	1.4251	1.7284	2.1052	.503
14	.1677	.1341	.2347	1.4089	1.6032	1.6518	.5197
15	.2012	.1844	.218	1.4251	1.6549	1.7004	.3561
16	.218	.1187	.2012	1.4089	1.5249	1.6842	.2713
17	.218	.1848	.1677	.2033	.2801	.3978	.4066
18	.2347	.2195	.1865	.2427	.3142	.3978	.3511
19	.285	.2561	.2035	.3109	.2743	.4001	.2427
20	.2713	.2378	.2374	.2957	.2926	.3401	.2801
21	.2374	.2033	.2204	.2427	.2772	.3353	.2614
22	.5087	.407	.6036	.218	.218	.285	1.2631
23	.4239	.4409	.5365	.218	.2012	.2515	1.3117
24	.2204	.3561	.3856	.4862	.1865	.1865	.2347
Max	.8648	1.0059	1.3413	1.4251	1.7284	2.1052	1.3117
Min	.1677	.1187	.1677	.2033	.1509	.1696	.2035
Avg	.2926	.3289	.3571	.6770	.6794	.8046	.4337

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721]

BU 4721

Substation No/ Name :- 244055 / 33/11KV TIKONDI

Feeder No / Name : 207 / 11 KV KAREWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0497	.0648	.0492	.0648	.4144	.3521	.5182
2	.0497	.0648	.0492	.0648	.3856	.3315	.5182
3	.0503	.0648	.0492	.0648	.3647	.3647	.502
4	.0503	.081	.0648	.064	.4144	.4475	.5182
5	.0663	.081	.0972	.096	.4534	.5138	.6401
6	.1147	.144	.1296	.144	.5992	.6554	.9602
7	.1475	.16	.1619	.1457	.8097	1.004	.8802
8	.0995	.112	.1509	.1134	.1341	.1341	.144
9	.2429	.3361	.4858	.0972	.0995	.1174	1.0402
10	.3201	.3041	.5182	.081	.1006	.0995	.7773
11	.2881	.4049	.583	.081	.0829	.0829	1.0364
12	.3521	.421	.5992	.0829	.0829	.0995	1.0526
13	.3201	.4858	.5601	.0829	.0829	.0819	1.0722
14	.3201	.4372	.5761	.0503	.0671	.0819	1.0562
15	.3401	.4858	.5601	.0503	.0829	.0972	.5182
16	.3563	.1943	.5765	.0848	.0663	.081	.502
17	.081	.0739	.0648	.0924	.112	.096	.0747
18	.096	.0554	.0648	.0934	.112	.096	.0739
19	.096	.1097	.0972	.1109	.1294	.128	.0747
20	.1134	.1097	.1134	.1307	.1294	.128	.1478
21	.0972	.0924	.0972	.1109	.1109	.1134	.1307
22	.081	.0671	.08	.4694	.4359	.5668	.1006
23	.0648	.0663	.064	.4807	.4475	.5344	.0995
24	.0503	.0648	.0492	.064	.4144	.3812	.5182
Max	.3563	.4858	.5992	.4807	.8097	1.004	1.0722
Min	.0497	.0554	.0492	.0503	.0663	.081	.0739
Avg	.1603	.1867	.2434	.1217	.2555	.2745	.5398

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 201 / 11 KV SANMADI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953	.0953	.0953	.0953	.0953
2	.0953	.0953	.0953	.0953	.0953	.0953	.0953
3	.0953	.0953	.0953	.0953	.0953	.0953	.0953
4	.0953	.0953	.0953	.0953	.0953	.0953	.0953
5	.0953	.0953	.1905	.0953	.0953	.0953	.0953
6	.0953	.0953	.1905	.0953	.1905	.0953	.0953
7	.1905	.1905	.1905	.0953	.1905	.1905	.1905
8	.1905	.1905	.1905	.0953	.1905	.0953	.0953
9	.0953	.0953	.1905	.0953	.1905	.0953	.0953
10		.0953	.0953	.0953	.0953	.1905	.0953
11	.0953	.0953	.0953	.0953	.0953	.0953	.0953
12	.0953	.0953	.0953	.0953	.0953	.0953	.0953
13	.0953	.0953	.0953	.0953	.0953	.0953	.0953
14	.0953	.0953	.0953	.0953	.0953	.0953	.0953
15	.0953	.0953	.0953	.0953	.0953	.0953	.0953
16	.0953	.0953	.0953	.0953	.0953	.0953	.0953
17	.0953	.0953	.0953	.0953	.0953	.0953	.0953
18	.0953	.0953	.0953	.1905	.1905	.0953	.1905
19	.0953	.1905	.0953	.1905	.1905	.1905	.1905
20	.0953	.1905	.0953	.1905	.1905	.0953	.0953
21	.1905	.1905	.0953	.1905	.1905	.1905	.0953
22	.0953	.0953	.0953	.0953	.0953	.0953	.0953
23	.0953	.0953	.0953	.0953	.0953	.0953	.0953
24	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Max	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Min	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Avg	.1077	.1151	.1151	.1112	.1270	.1112	.1072

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 202 / 11 KV GHOLESHWAR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.1867	.3429	.2614	.5658	.4854	.3681
2	.2075	.2452	.3429	.2774	.5375	.5258	.3772
3	.1867	.298	.381	.2353	.5487	.5375	.3988
4	.2865	.3511	.4954	.2218	.5316	.5144	.3772
5	.2629	.3961	.5716	.2865	.5548	.5487	.7716
6	.2263	.5847	.5906	.3547	1.0974	1.0117	.8413
7	.1791	.3429	.3772	.3772	1.387	1.3889	1.1145
8	.1543	.3361	.3395	.132	.3121	.2507	.2926
9	.4755	.3311	.5079	.1524	.2241	.2622	1.0682
10	.4172	.2743	.4961	.1905	.1886	.3086	1.3226
11	.3018	.2378	.426	.2218	.1509	.1886	1.3413
12	.2572	.3418	.3201	.0934	.1543	.1132	1.3757
13	.2896	.3913	.3768	.0857	.1494	.1109	1.358
14	.3121	.4167	.5376	.1478	.1509	.1307	1.2742
15	.3144	.381	.426	.1612	.112	.1294	1.1363
16	.2858	.3353	.4167	.132	.0934	.1307	.9762
17	.2949	.1981	.3429	.1886	.1448	.1372	.2452
18	.2683	.2401	.2658	.3206	.2218	.208	.3584
19	.2543	.2883	.2172	.3395	.3174	.2715	.3961
20	.3584	.3258	.2587	.3772	.3734	.3109	.3734
21	.2896	.3018	.3018	.3395	.3584	.3018	.2926
22	.3292	.3018	.2926	.6068	.5316	.4287	.1867
23	.2987	.2801	.2614	.5895	.5721	.4207	.2641
24	.181	.3045	.3239	.1905	.5721	.547	.3467
Max	.4755	.5847	.5906	.6068	1.387	1.3889	1.3757
Min	.1543	.1867	.2172	.0857	.0934	.1109	.1867
Avg	.2796	.3204	.3839	.2618	.4104	.3860	.7024

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 203 / 11 KV KONIKUNUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1753	.0857	.1829	.2401	.2652	.2458
2	.1509	.208	.0867	.2033	.2267	.2486	.2591
3	.104	.124	.0943	.1698	.213	.2458	.2429
4	.2481	.1478	.1132	.1494	.2321	.2294	.2622
5	.1848	.1494	.1494	.2263	.2321	.2321	.3401
6	.1509	.1698	.1698	.2957	.5735	.5735	.426
7	.132	.1509	.1372	.112	.7773	.6478	.6478
8	.0934	.1187	.1029	.1509	.0857	.1372	.128
9	.2667	.3668	.3906	.1478	.0867	.1829	.852
10	.2743	.3185	.4784	.1715	.0876	.0905	.9556
11	.2115	.2606	.5182	.0953	.0876	.0934	.9282
12	.192	.3812	.3437	1.0679	.0905	.0934	.9282
13	.2229	.421	.4096	.0857	.0914	.0905	.8684
14	.2172	.427	.4744	.124	.0924	.0886	.8192
15	.2317	.3953	.3201	.1646	.0924	.0934	.7655
16	.2172	.2743	.2778	.0886	.0905	.0934	.7655
17	.2926	.0762	.1463	.0895	.0905	.0876	.0934
18	.3361	.08	.2614	.1097	.0886	.104	.0924
19	.3582	.1029	.2103	.1294	.1086	.104	.1109
20	.1463	.1267	.1772	.1478	.112	.12	.1478
21	.1509	.1294	.112	.128	.1307	.1307	.1307
22	.128	.12	.1387	.2279	.2818	.285	.1463
23	.1254	.104	.1086	.2229	.2984	.2683	.1075
24	.2075	.1463	.0857	.2054	.1943	.2785	.2543
Max	.3582	.427	.5182	1.0679	.7773	.6478	.9556
Min	.0934	.0762	.0857	.0857	.0857	.0876	.0924
Avg	.2011	.2073	.2247	.1957	.1919	.1993	.4382

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 204 / 11 KV SANAMADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0657	.0648	.0648	.0629	.06	.06	.0667
2	.0657	.0648	.0648	.0572	.06	.06	.0667
3	.0657	.0648	.0648	.0553	.06	.06	.0667
4	.0657	.0648	.0648	.0553	.06	.06	.0667
5	.0657	.0648	.0648	.0553	.06	.06	.0667
6	.0657	.0648	.0648	.0553	.06	.06	.0667
7	.0657	.1036	.0648	.0553	.06	.06	.0667
8	.0657	.0648	.0648	.0553	.06	.0667	.0667
9	.0667	.0648	.0648	.0581	.096	.1067	.0676
10	.0667	.0648	.0648	.0581	.084	.0934	.0676
11	.0667	.0648	.0648	.0581	.072	.0869	.0676
12	.0667	.0648	.0648	.0581	.072	.1158	.0676
13	.0667	.0648	.0648	.0945	.084	.1067	.0676
14	.0667	.0648	.0648	.0591	.072	.1067	.0676
15	.0667	.0648	.0648	.0591	.108	.0934	.0676
16	.0667	.0648	.0648	.06	.096	.1067	.0676
17	.0657	.0648	.0648	.06	.06	.0667	.0676
18	.0657	.0648	.0648	.06	.06	.0667	.0676
19	.0657	.0648	.0648	.06	.06	.0667	.0676
20	.0657	.0648	.0648	.06	.06	.0667	.0676
21	.0657	.0648	.0648	.06	.06	.0667	.0676
22	.0657	.0648	.0648	.06	.06	.0667	.0676
23	.0657	.0648	.0629	.06	.06	.0667	.0676
24	.0667	.0657	.0648	.0754	.06	.06	.0667
Max	.0667	.1036	.0648	.0945	.108	.1158	.0676
Min	.0657	.0648	.0629	.0553	.06	.06	.0667
Avg	.0661	.0665	.0647	.0605	.0685	.0762	.0673

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 205 / 11 KV GHOLESHWAR GAVTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0867	.0876	.0943	.0953	.0943	.0953
2		.0943	.0867	.0934	.0953	.0934	.0953
3		.0934	.0867	.0924	.0953	.0943	.0953
4			.0895	.0905	.0953	.0943	.0953
5			.0905	.0934	.0953	.0934	.0953
6		.1886	.1829	.1829	.1905	.181	.0953
7		.1848	.1715	.1886	.1905	.1886	.1905
8		.0924	.0867	.0867	.0943	.0924	.0924
9		.0867	.0905	.0895	.0934	.0905	.0905
10		.0857	.0876	.0934	.0943	.0934	.0934
11		.0876	.0895	.0867	.0943	.0886	.0934
12	.0838	.0867	.0924	.1086	.0943	.0905	.0934
13	.0838	.0924	.0914	.0934	.0934	.0857	.0943
14	.0857	.0934	.0934	.0895	.0934	.0867	.0943
15	.0857	.0943	.0905	.0905	.0857	.0857	.0943
16	.0848	.0867	.0867	.112		.0867	.0943
17	.1581	.0857	.1829	.0886		.0905	.0886
18	.2401	.0876	.1791	.1734		.0914	.0905
19	.2572	.1734	.0876	.2601	.1791	.181	.2686
20	.2629	.1734	.0934	.2629	.2715	.1829	.2865
21	.1829	.0857	.0934	.1791	.1829	.1867	.1867
22	.0934	.0867	.0934	.1886	.0905	.0943	.0914
23	.0914	.0876	.0914	.0934	.0914	.0943	.0934
24		.0886	.0857	.0943	.0953	.0934	.0953
Max	.2629	.1886	.1829	.2629	.2715	.1886	.2865
Min	.0838	.0857	.0857	.0867	.0857	.0857	.0886
Avg	.1425	.1056	.1046	.1261	.1196	.1106	.1168

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244071 / 33/11 KV SANAMADI

Feeder No / Name : 206 / 11 KV NIGADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.2149	.1334	.1791	.3429	.3086	.3361
2	.1075	.2614	.1509	.2103	.3121	.2896	.3401
3	.1402	.2263	.1698	.2481	.3366	.3048	.3563
4	.1848	.2481	.168	.208	.4525	.3277	.3361
5	.2241	.2534	.2829	.1991	.5144	.3401	.5668
6	.2926	.3361	.3326	.2427	.7209	.9448	.6226
7	.1629	.2829	.2715	.3018	.9602	1.0059	.8619
8	.156	.2286	.2229	.2149	.2263	.1433	.2149
9	.6516	.6093	.4915	.2804	.2427	.1097	1.0159
10		.5792	.5693	.3326	.1698	.1294	1.1401
11	.5144	.5247	.639	.2715	.1494	.1075	1.0437
12	.4607	.5155	.7362	.1254	.0983	.128	1.0883
13	.3864	.4572	.7682	.1612	.116	.1254	1.0159
14	.3858	.4321	.7522	.1267	.0972	.1227	1.0442
15	.3807	.3963	.7045	.1494	.1147	.1214	1.0159
16	.3616	.4784	.7682	.1052	.1307	.12	.9878
17	.1463	.1829	.1867	.1543	.168	.1372	.1907
18	.168	.1629	.1612	.1734		.1698	.2195
19	.2103	.2172	.208	.208	.2172	.2054	.2957
20	.2561	.2561	.2835	.2658	.2534	.2452	.2195
21	.2507	.2402	.2561	.2534	.2378	.2402	.2427
22	.2058	.2012	.2507	.3258	.3812	.3932	.2241
23	.2587	.168	.1886	.3658	.3563	.3725	.1886
24	.3292	.2774	.132	.1663	.3801	.3361	.3768
Max	.6516	.6093	.7682	.3658	.9602	1.0059	1.1401
Min	.1075	.1629	.132	.1052	.0972	.1075	.1886
Avg	.2792	.3229	.3678	.2196	.3034	.2804	.5810

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244109 / 33/11 KV LAVANGA

Feeder No / Name : 201 / 11 KV KONTEBOBLAD MIX
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
1	.3315
2	.4144
3	.4641
4	.4973
5	.5967
6	.6299
7	.1143
8	.1524
9	.1715
24	.3315
Max	.6299
Min	.1143
Avg	.3704

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244109 / 33/11 KV LAVANGA

Feeder No / Name : 202 / 11 KV JALYAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244109 / 33/11 KV LAVANGA

Feeder No / Name : 203 / 11 KV GIRGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	.1658
Max	.1658
Min	.1658
Avg	.1658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

KAVATHEMAHANKAL DIVISION[525]

SANKH S/DN.[721] BU 4721

Substation No/ Name :- 244109 / 33/11 KV LAVANGA

Feeder No / Name : 204 / 11 KV MORBAGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
10	.1823
Max	.1823
Min	.1823
Avg	.1823

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 201 / 11 KV KANKESHWAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.064	.048	.048	.064	1.1797	1.1203	1.1227
2	.064	.048	.048	.064	1.1305	1.1203	1.1069
3	.064	.048	.048	.064	.9831	1.1069	1.1069
4	.064	.048	.048	.064	.9667	1.1069	1.1469
5	.064	.064	.048	.064	.9667	1.1069	1.1069
6	.08	.08	.064	.064	1.065	1.1385	1.1069
7	.064	.048	.064	.064	1.1961	1.3283	1.2018
8	.064	.064	.048	.048	.0655	.048	.0474
9	1.4243	1.3123	1.3923	.048	.048	.048	1.5813
10	1.3923	1.4403	1.4883	.048	.048	.048	1.8185
11	1.4243	1.4243	1.2323	.048	.048	.048	1.8027
12	1.3603	1.4563	1.5364	.048	.048	.048	1.8564
13	1.3443	1.4723	1.5524	.048	.064	.048	1.7284
14	1.2963	1.4083	1.3603	.048	.048	.048	1.6876
15	1.3443	1.4083	1.3123	.048	.048	.064	1.7695
16	1.3603	1.3443	1.2163	.048	.048	.048	1.692
17	.048	.048	.048	.048	.048	.064	.0474
18	.048	.048	.064	.032	.048	.064	.0474
19	.064	.048	.08	.064	.08	.08	.0633
20	.064	.064	.08	.0724	.064	.064	.0633
21	.064	.064	.08	.0724	.08	.08	.0633
22	.064	.064	.064	1.1361	1.2003	1.1843	.0633
23	.048	.064	.064	1.2209	1.1843	1.2003	.0474
24	.064	.048	.048	.064	1.2289	1.1363	1.1363
Max	1.4243	1.4723	1.5524	1.2209	1.2289	1.3283	1.8564
Min	.048	.048	.048	.032	.048	.048	.0474
Avg	.4974	.5068	.5014	.1496	.4953	.5145	.9756

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 202 / 11 KV MHAISHAL GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3881	.4805	.5914	.4763	.4251	.499	.462
2	.3881	.4435	.5544	.4191	.4066	.4805	.462
3	.3696	.4435	.5544	.4191	.4066	.4805	.462
4	.3696	.4805	.5544	.4191	.4066	.4805	.462
5	.462	.5175	.5544	.4763	.4066	.5175	.499
6	.5359	.5544	.5914	.5525	.499	.5914	.5729
7	.6468	.6283	.6653	.5525	.6283	.6099	.5914
8	.6653	.6099	.5359	.5525	.5914	.5175	.5729
9	.5359	.5729	.5175	.4954	.4251	.4435	.499
10	.5359	.5175	.5914	.5144	.3881	.4066	.4435
11	.5175	.462	.7023	.499	.4066	.462	.4251
12	.4066	.462	.5914	.3881		.4251	.4525
13	.5175	.462	.3142	.462	.5175	.4066	.4525
14	.4251	.5914	.5544	.4251	.4435	.3881	.4525
15	.5359	.6099	.5914	.4251	.4251	.4251	.4525
16	.499	.5914	.499	.4066	.4805	.3881	.4525
17	.6099	.5729	.5544	.4435	.5175	.4251	.5175
18	.6283	.5729	.7577	.5729	.5544	.5175	.5544
19	.924	.8871	.8316	.7762	.7207	.7207	.6653
20	.9425	.8501	.8131	.7947	.7947	.7947	.8131
21	.8316	.8501	.7577	.6838	.7207	.7762	.7577
22	.7577	.7577	.6838	.6283	.6468	.6468	.7023
23	.5914	.5914	.5914	.5175	.6099	.5175	.5544
24	.4251	.499	.5544	.5335	.4435	.5175	.462
Max	.9425	.8871	.8316	.7947	.7947	.7947	.8131
Min	.3696	.4435	.3142	.3881	.3881	.3881	.4251
Avg	.5629	.5837	.6045	.5181	.5159	.5182	.5309

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 203 / 11 KV MAHAVEER AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1934	1.1437	1.0111	.9014			
2	1.1934	1.1437	1.0111	.8855			
3	1.1934	1.1271	1.0111	.8855			
4	1.1934	1.1271	1.0111	.8855			
5	1.1934	1.1271	1.0111	.8855			
6	1.2266	1.1271	.9945	.8855			
7	1.2431	1.1523	1.1934	.9014			
9				1.1385	1.3927	1.5912	
10				1.2176	1.4746	1.6575	
11				1.2809	1.491	1.7072	
12				1.2809	1.3763	1.757	
13				1.3125	1.4582	1.6575	
14				1.3441	1.6078	1.6741	
15				1.3125	1.6078	1.6409	
16				1.3283	1.6057	1.6409	
17					1.6057		
22	1.1437	1.1271	1.1105				1.442
23	1.1271	.9448	.9282				.5544
24	1.2266	1.1437	1.0111	.9014			
Max	1.2431	1.1523	1.1934	1.3441	1.6078	1.757	1.442
Min	1.1271	.9448	.9282	.8855	1.3763	1.5912	.5544
Avg	1.1934	1.1164	1.0293	1.0842	1.5133	1.6658	.9982

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 204 / 11 KV NARWAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0617	.0617	.0617	.0617	.7537	.679	.6562
2	.0617	.0617	.0617	.0617	.7045	.6481	.6562
3	.0617	.0617	.0617	.0617	.7045	.6481	.6562
4	.0617	.0617	.0463	.0617	.6718	.6481	.6562
5	.0617	.0617	.0617	.0617	.6226	.6481	.6562
6	.0772	.0772	.0926	.0772	.8684	.7253	.6944
7	.0772	.0772	.0926	.0772	1.0814	1.034	.9259
8	.0926	.0926	.0926	.0926	.0819	.108	.0926
9	.8333	.8802	1.1111	.0772	.0625	.0772	1.1574
10	.9568	.9282	1.1883	.0772	.0625	.0772	1.3117
11	.9259	.9442	1.1574	.0772	.0625	.0772	1.1265
12	.9105		1.0494	.0926	.0781	.0463	
13	.8488	.8642	.9105	.0772	.0625	.0617	1.034
14	.7716		.7716	.0617	.0625	.0617	.9568
15	.7099	.8962	.8025	.0617	.0469	.0617	.9831
16	.7407	.8802	.8179	.0617	.0781	.0772	1.0031
17	.0617	.064	.0772	.0617	.0625	.0772	.0617
18	.0617	.08	.0772	.0772	.0791	.0926	.0617
19	.0926	.108	.0772	.108		.0937	.0926
20	.108	.1235	.0926	.1463	.0949	.1094	.108
21	.108	.108	.0983	.1463	.0949	.0937	.0926
22	.0926	.108	.0772	.9602	.9014	.7655	.0772
23	.0772	.0617	.0772	.9088	.7748	.7655	.0617
24	.0617	.0617	.0617	.0617	.8192	.6874	.703
Max	.9568	.9442	1.1883	.9602	1.0814	1.034	1.3117
Min	.0617	.0617	.0463	.0617	.0469	.0463	.0617
Avg	.3299	.3029	.3758	.1505	.3840	.3485	.6011

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 205 / 11 KV MHAISHAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6964	1.5364	1.5684	1.2651	.0633	.064	.0648
2	1.6484	1.5203	1.5364	1.2651	.0633	.064	.0648
3	1.6004	1.5043	1.5364	1.2803	.0633	.064	.0648
4	1.5524	1.5043	1.5364	1.2803	.0633	.064	.0648
5	1.5524	1.5203	1.5364	1.2955	.0633	.064	.0648
6	1.5844	1.5203	1.5684	1.326	.0949	.08	.081
7	1.7764	1.7444	1.8084	1.4327	.0791	.064	.0972
8	.08	.064	.096	.061	.0949	.064	.081
9	.08	.096	.096	1.7985	2.0399	2.2725	.081
10	.048	.08	.112	1.9814	2.5143	2.4486	.0648
11	.064	.096		1.9509	2.5766	2.4646	.0648
12	.064	.096		1.9966		2.6566	.0655
13	.064	.096		2.1033	2.1765	2.5606	.0655
14	.048	.096	.064	2.0729	2.3525	2.5286	.0655
15	.064	.08	.064	2.1033	2.5446	2.4326	.081
16	.064	.096	.08	1.9357	2.5126	2.3525	.081
17	.064	.112	.064		.064	.08	.0648
18	.064	.096	.064	.061	.064	.08	.0486
19	.08	.112	.064	.0791	.064	.081	
20	.08	.112	.064	.0949	.08	.0972	.0648
21	.08	.096	.08	.0791	.08	.081	.0648
22	1.5364	1.7284	1.4083	.0791	.08	.081	2.0243
23	1.5524	1.4563	1.3763	.0633	.064	.081	2.1052
24	1.7124	1.5524	1.5364	1.2651	.0791	.064	.081
Max	1.7764	1.7444	1.8084	2.1033	2.5766	2.6566	2.1052
Min	.048	.064	.064	.061	.0633	.064	.0486
Avg	.7148	.7048	.7743	1.1683	.7773	.8704	.2437

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 206 / 11 KV NARWAD GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366	.0366	.0366	.0191	.0366	.0366	.0362
2	.0366	.0366	.0366	.0191	.0366	.0366	.0362
3	.0366	.0366	.0366	.0191	.0366	.0366	.0362
4	.0366	.0366	.0366		.0366	.0366	.0362
5	.0366	.0366	.0366		.0366	.0366	.0362
6	.0366	.0366	.0366		.0366	.0366	.0366
7	.0366	.0366	.0366		.0366	.0362	.0549
8	.0366	.0366	.0366		.0366	.0362	.0549
9	.0366	.0366	.0366		.0366	.0362	.0366
10	.0366	.0183	.0366	.0191	.0366	.0366	.0366
11	.0366	.0183	.0366	.0381	.0366	.0366	.0366
12	.0366	.0549	.0366	.0381	.0366	.0366	.0181
13	.0366	.0183	.0366	.0381	.0181	.0366	.0181
14	.0366	.0183	.0366	.0381	.0183	.0183	.0362
15	.0366	.0183	.0183	.0381	.0183	.0366	.0181
16	.0366	.0183	.0183	.0381	.0183	.0366	.0362
17	.0366	.0549	.0366	.0191	.0366	.0366	.0183
18	.0366	.0366	.0366	.0381	.0366	.0366	.0366
19	.0366	.0366	.0366	.0381	.0183	.0362	.0366
20	.0366	.0366	.0366	.037	.0366	.0362	.0366
21	.0183	.0366	.0366	.037	.0366	.0362	.0366
22	.0366	.0549	.0366	.037	.0366	.0362	.0366
23	.0366	.0366	.0183	.037	.0366	.0362	.0366
24	.0366	.0366	.0366	.0191	.0373	.0366	.0362
Max	.0366	.0549	.0366	.0381	.0373	.0366	.0549
Min	.0183	.0183	.0183	.0191	.0181	.0183	.0181
Avg	.0358	.0343	.0343	.0315	.0328	.0357	.0349

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244001 / 33/11 KV MHAISHAL

Feeder No / Name : 207 / 11 KV WATER WORKS

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 11 / OUTGOING

UTILITY

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0829	.052	.08	.0347	.0351	.0819	.0819
2	.0829	.052	.08	.0347	.0351	.0819	.0492
3	.0819	.052	.081	.0347	.0351	.0819	.0532
4	.0819	.052	.081	.0347	.0351	.0819	.0532
5	.0819	.052	.081	.0347	.0351	.0819	.0532
6	.0819	.052	.081	.0347	.0351	.0829	.0532
7	.0819	.052	.08	.052	.0351	.0972	.0532
8	.0819	.052	1.2643	.052	.0351	.052	.0532
9	.0819	.052	.0633	.052	.0526	.0526	.0532
10	.0829	.052	.0995	.0819	.0526	.052	.0526
11	.0983	.052	.0995	.0819	.0532	.0693	.0526
12	.0983	.0514	.0995	.0819	.0526	.0693	.0351
13	.0995	.0514	.0829	.0819	.0526	.0693	.0351
14	.0983	.0514	.0829	.0819	.0332	.0693	.0351
15	.0532	.0514	.0829	.0819	.0332	.0693	.0351
16	.0532	.0514	.0829	.0492	.0316	.0693	.0351
17	.0526	.0514	.0332	.0492	.0316	.052	.0351
18	.052	.0509	.0497	.0492	.0324	.052	.0876
19	.052	.0343	.0332	.0328	.0324	.0526	.0876
20	.052	.0343	.0332	.0347	.061	.081	.0876
21	.052	.0343	.0332	.0347	.0633	.0829	.0876
22	.052	.0343	.0332	.0347	.0829	.0819	.0876
23	.052	.0819	.0332	.0347	.0829	.0819	.0876
24	.0829	.052	.08	.0347	.0351	.0819	.0819
Max	.0995	.0819	1.2643	.0819	.0829	.0972	.0876
Min	.052	.0343	.0332	.0328	.0316	.052	.0351
Avg	.0738	.0501	.1188	.0504	.0443	.0720	.0595

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 201 / 11 KV Dhavali Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191	1.2209	1.3032	1.4575
2	.0191	.0191	.0191	.0191	1.1191	1.3032	1.4575
3	.0191	.0191	.0191	.0191	1.1191	1.3032	1.4575
4	.0191	.0191	.0191	.0191	1.1191	1.3032	1.4575
5	.0191	.0191	.0191	.0191	1.1191	1.3032	1.4575
6	.0191	.0191	.0191	.0191	1.1317	1.3523	1.4575
7	.0191	.0191	.0191	.0191	1.2003	1.3717	1.4746
8	.0191	.0191	.0191	.0191	.0191	.0191	.0191
9	2.2539	1.749	1.7833	.0191	.0191	.0191	2.0233
10	2.3405	1.749	1.8519	.0191	.0191	.0191	2.1434
11	2.3405	1.7147	1.9071	.0191	.0191	.0191	2.2291
12	2.3752	1.7147		.0191	.0191	.0191	2.1152
13	2.3232	1.7318		.0191	.0191	.0191	2.1434
14	2.2885	1.7318	1.7147	.0191	.0191	.0191	2.1672
15	2.0748	1.7318	1.8378	.0191	.0191	.0191	2.2192
16	1.8031	1.7318	1.3717	.0191	.0191	.0191	2.2539
17	.0191	.0191	.0191	.0191	.0191	.0191	.0191
18	.0191	.0191	.0191	.0191	.0191	.0191	.0191
19	.0191	.0191	.0191	.0191	.0191	.0191	.0191
20	.0191	.0191	.0191	.0191	.0191	.0191	.0191
21	.0191	.0191	.0191	.0191	.0191	.0191	.0191
22	.0191	.0191	.0191	1.3226	1.2346	1.4563	.0191
23	.0191	.0191	.0191	1.3226	1.3375	1.5089	.0191
24	.0191	.0191	.0191	.0191	1.3226	1.2887	1.5089
Max	2.3752	1.749	1.9071	1.3226	1.3375	1.5089	2.2539
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.7544	.5900	.4896	.1277	.5080	.5734	1.2157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 202 / 11 KV Nilaji Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5636	.4161	.3605	.5801	.0191	.0191	.0191
2	.547	.4001	.3605	.547	.0191	.0191	.0191
3	.547	.4001	.3605	.5304	.0191	.0191	.0191
4	.547	.4001	.3605	.5365	.0191	.0191	.0191
5	.547	.4049	.3605	.5365	.0191	.0191	.0191
6	.547	.4424	.3605	.5365	.0191	.0191	.0191
7	.6299	.4534	.4096	.5571	.0191	.0191	.0191
8	.0191	.0191	.0191	.0191	.0191	.0191	
9	.0191	.0191	.0191	.8886	1.0395	1.4243	.0191
10	.0191	.0191	.0191	.6718	1.2071	1.6289	.0191
11	.0191	.0191	.0191	.9831	1.3904	1.7187	.0191
12	.0191	.0191	.0191	1.0978	1.4746	1.6632	.0191
13	.0191	.0191		1.073	1.3904	1.6078	.0191
14	.0191	.0191	.0191	1.073	1.4243	1.6078	.0191
15	.0191	.0191	.0191	1.0562	1.4243	1.5708	.0191
16	.0191	.0191	.0191	1.0513	1.4403	1.5497	.0191
17	.0191	.0191	.0191	.0191	.0191	.0191	.0191
18	.0191	.0191	.0191	.0191	.0191	.0191	.0191
19	.0191	.0191	.0191	.0191	.0191	.0191	.0191
20	.0191	.0191	.0191	.0191	.0191	.0191	.0191
21	.0191	.0191	.0191	.0191	.0191	.0191	.0191
22	.4588	.0655	.6036	.0191	.0191	.0191	1.3375
23	.4588		.5967	.0191	.0191	.0191	1.3032
24	.5636	.4588	.3725	.5967	.0191	.0191	.0191
Max	.6299	.4588	.6036	1.0978	1.4746	1.7187	1.3375
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.2365	.1613	.1910	.5195	.4624	.5449	.1323

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 203 / 11 KV Krishna Ghat

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587	.1698	.2012	.2241	.2241	.2378	.2241
2	.2587	.1663	.2012	.2241	.2241	.2378	.2241
3	.2587	.1663	.2012	.2241	.2241	.2378	.2241
4	.2587	.1663	.2012	.2241	.2241	.2378	.2561
5	.2587	.2561	.2715	.2772	.2427	.2378	.3224
6	.2743	.2926	.3366	.3077	.3045	.2896	.3224
7	.2743	.2926	.3366	.3403	.333	.2926	.3224
8	.2743	.3224	.3721	.3366	.3544	.3544	.4031
9	.2686	.3155	.3681	.3772	.3814	.3988	.4458
10	.298	.3601	.4031	.3641	.4115	.4161	.5721
11	.3641	.3258	.4115	.3601	.4115	.4161	.6001
12	.3294	.3561	.4239	.3561	.3988	.4287	.5596
13	.3121	.3561		.407	.407	.4578	.5256
14	.2481	.3086	.3052	.373	.3772	.4748	.5256
15	.197	.3429		.3601	.3294	.4748	.4801
16	.2865	.3467	.2543	.3856	.3772	.4801	.4801
17	.2303	.3772	.3772	.4115	.407	.4748	.4748
18	.1646	.3121	.415	.2774	.3222	.0191	.4527
19	.2241	.3544	.3961	.3045	.333	.3045	.4748
20	.2801	.2896	.3439	.2926	.2715	.3224	.3856
21	.2772	.2896	.3761	.2926	.2715	.3258	.3721
22	.2263	.2587	.2614	.2772	.2241	.2427	.3109
23	.2241	.2561	.2241	.2641	.2378	.2241	.2772
24	.2587	.2241	.2012	.4142	.2241	.2378	.2241
Max	.3641	.3772	.4239	.4142	.4115	.4801	.6001
Min	.1646	.1663	.2012	.2241	.2241	.0191	.2241
Avg	.2627	.2878	.3129	.3198	.3132	.326	.3942

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 204 / 11 KV Takali Bolwad Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1132	.132	.132	1.0688	1.2289	1.166
2	.1132	.1132	.132	.132	1.0688	1.2289	1.166
3	.1132	.1132	.132	.132	1.0688	1.2289	1.166
4	.1132	.1132	.132	.132	1.0688	1.2289	1.166
5	.1132	.1509	.132	.1698	1.0688	1.2289	1.166
6	.1509	.1509	.1509	.1698	1.2125	1.3108	1.2308
7	.1698	.1698	.1509	.1698	1.4563	1.5074	1.2963
8	.1509	.1509	.1509	.1509	.1698	.132	.128
9	1.4251	1.4899	1.5729	.1132	.132	.112	1.5402
10	1.5223	1.6194	1.917	.1307	.0943	.112	1.9393
11	1.6549	1.6032	1.7859	.1307	.0754	.0934	1.989
12	1.587	1.6518	1.668	.1307	.132	.1109	1.8351
13	1.5708	1.668		.112	.0895	.1097	1.8842
14		1.5384	1.4746	.112	.0739	.1109	1.8515
15	1.3763	1.5061	1.5074	.1097	.0914	.1109	1.8515
16	1.4413	1.4575	.9998	.0895	.1132	.1307	1.7532
17	.0914	.1109	.0934	.0886	1.8296	.128	.1307
18	.1109	.1132	.132	.1448	.128	.1307	.1494
19	.1509	.1509	.1509	.168	.1509	.1698	.1698
20	.2263	.1698	.1886	.1698	.1698	.1698	.1886
21	.2054	.1698	.1698	.1698	.1698	.1886	.2075
22	.1509	.1509	.1509	1.166	1.2616	1.2452	.1509
23	.132	.132	.132	1.1012	1.3108	1.1984	.1509
24	.1132	.1132	.132	.132	1.0688	1.247	1.1984
Max	1.6549	1.668	1.917	1.166	1.8296	1.5074	1.989
Min	.0914	.1109	.0934	.0886	.0739	.0934	.128
Avg	.5564	.6133	.5734	.2190	.6281	.6026	1.0615

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244038 / 33/11 KV KRISHNA GHAT

Feeder No / Name : 206 / 11 KV Dhavali Gaohan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075	.1886	.2075	.2263	.2452	.2263	.2263
2	.1886	.1886	.2075	.2263	.2452	.2263	.2263
3	.1886	.1886	.2075	.2263	.2452	.2263	.2263
4	.1886	.1886	.2263	.2263	.2452	.2263	.2263
5	.2075	.2641	.2641	.2641	.2452	.2263	.2452
6	.3018	.2829	.2829	.2641	.3018	.2641	.2641
7	.2829	.2829	.2829	.2641	.2829	.2829	.3018
8	.2829	.2829	.2452	.2263	.2641	.2829	.2641
9	.2452	.2641	.2452	.2075	.2452	.2829	.2641
10	.2075	.2829	.2641	.2263	.2263	.2641	.2641
11	.2075	.2452	.2263	.2263	.2452	.2452	.2263
12	.2075	.2641	.2641	.2263	.2452	.2452	.2452
13	.132	.2263		.2075	.2263	.2452	.2263
14	.132	.2263	.2075	.1698	.2075	.2452	.2263
15	.1509	.2075	.1886	.1698	.2263	.2452	.2452
16	.1698	.2075	.2075	.2075	.2263	.2452	.2452
17	.1886	.2263	.2075	.2263	.2452	.2452	.2452
18	.2075	.2452	.2829	.2641	.2452	.2452	.2452
19	.2641	.3395	.3206	.3206	.2829	.3584	.3395
20	.2829	.3018	.3018	.3206	.2641	.3395	.3206
21	.2054	.3018	.3018	.3018	.2641	.3206	.2829
22	.2452	.2452	.2829	.3018	.2452	.3018	.2452
23	.2263	.2075	.2641	.2641	.2263	.2452	.2263
24	.2075	.2075	.2075	.2263	.2452	.2263	.2263
Max	.3018	.3395	.3206	.3206	.3018	.3584	.3395
Min	.132	.1886	.1886	.1698	.2075	.2263	.2263
Avg	.2137	.2444	.2477	.2413	.2476	.2609	.2523

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 201 / Soni Gavathan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1867	.1886	.1886	.2075	.1886	.1886
2	.1886	.1867	.1886	.1886	.1886	.1886	.1886
3	.1886	.1867	.1886	.1886	.1886	.1886	.1886
4	.1886	.1867	.1886	.1886	.1886	.1886	.1886
5	.2241	.2241	.2075	.1886	.2075	.2075	.2263
6	.2801	.2987	.2641	.2614	.2801	.2614	.2829
7	.2987	.2614	.2801	.2614	.3018	.2614	.2987
8	.2614	.2427	.1848	.2054	.2241	.2054	.2054
9	.2241	.1867	.2012	.168	.168	.168	.1663
10	.2033	.168	.1867	.1867	.1494	.1478	.1494
11	.1646	.168	.168	.1867	.1663	.1478	.112
12	.1463	.168	.168	.1867	.1463	.1294	.1867
13	.1478	.1494	.168	.168	.1663	.1463	.1307
14	.1663	.1494	.168	.1494	.1463	.1478	.168
15	.1463	.168	.1494	.1494	.1494	.1867	.1867
16	.1478	.1307	.1494	.1494	.1646	.1494	.1867
17	.1663	.168	.1494	.168	.1478	.1791	.1867
18	.2427	.2033	.2054	.2054	.2241	.2126	.2241
19	.3547	.3734	.3361	.3361	.3547	.3258	.3921
20	.3734	.3772	.3734	.3361	.3547	.3658	.3921
21	.3547	.3584	.3361	.3361	.2987	.3511	.3174
22	.2987	.2641	.2987	.2987	.2801	.2829	.2801
23	.2241	.2452	.2054	.2614	.2241	.2263	.2427
24	.2075	.2054	.2075	.4626	.2263	.2075	.2075
Max	.3734	.3772	.3734	.4626	.3547	.3658	.3921
Min	.1463	.1307	.1494	.1494	.1463	.1294	.112
Avg	.2245	.2190	.2151	.2258	.2147	.2110	.2207

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 202 / 11 KV Bhose Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075	.2054	.1886	.2075	.2054	.1509	.1509
2	.2075	.2054	.1698	.1886	.1867	.1509	.1509
3	.2075	.2054	.1509	.1886	.1867	.1509	.1509
4	.2075	.2054	.1509	.1886	.1867	.1509	.1509
5	.2427	.2427	.1509	.1886	.2427	.1886	.1886
6	.3174	.2987	.2263	.3174	.3174	.2241	.2641
7	.3361	.3547	.2427	.3361	.3547	.2801	.2263
8	.2054	.1867	.1867	.2054	.2241	.2241	.2427
9	.2241	.2427	.2801	.2801	.2987	.1867	.1867
10	.2054	.3174	.3734	.168	.168	.1867	.1867
11	.1494	.3292	.3174	.2054	.3511	.2987	.2614
12	.4108	.3658	.3734	.1867	.3734	.2987	.168
13	.3734	.2241	.3174	.168	.4481	.168	.3174
14	.2801	.3326	.3547	.168	.415	.3734	.2427
15	.3174	.4207	.3734	.3734		.1886	.3734
16	.4481	.4706	.5601	.3174	.3174	.3206	.4481
17	.3547	.4572	.5601	.3174	.3921	.4108	.2987
18	.2427	.2054	.2987	.3174	.2987	.3547	.112
19	.2241	.2427	.2427	.2614	.2427	.2427	.1867
20	.2427	.2641	.2241	.2614	.2614	.2641	.2241
21	.2054	.2263	.2241	.2241	.2241	.1949	.2241
22	.2054	.2452	.2241	.2987	.2054	.2075	.2241
23	.2614	.2641	.2614	.2801	.168	.1886	.2054
24	.2263	.2241	.2263	.2452	.2427	.1509	.1698
Max	.4481	.4706	.5601	.3734	.4481	.4108	.4481
Min	.1494	.1867	.1509	.168	.168	.1509	.112
Avg	.2626	.2807	.2783	.2456	.2744	.2315	.2231

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 203 / 11 KV Siddhewadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0747	.0754	.0566	.3239	.3239	.3563
2	.0754	.0747	.0754	.0566	.3239	.3239	.3239
3	.0754	.0747	.0754	.0566	.3239	.3239	.3201
4	.0754	.0747	.0754	.0566	.3239	.3401	.3201
5	.0934	.0934	.0754	.0754	.3401	.3887	.3401
6	.112	.112	.0943	.0934	.421	.5601	.3887
7	.112	.112	.112	.112	.7773	.9122	.4858
8	.112	.0747	.0934	.0934	.0934	.0747	.0934
9	.4534	.502	.5668	.0747	.0747	.1307	.6478
10	.502	.5992	.6964	.0934	.0747	.0934	.8745
11	.4858	.583	.6478	.0747	.0934	.0747	.8097
12	.4858	.4696	.6478	.0747	.0747	.0934	.8259
13	.4696	.502	.5182	.0747	.0934	.0934	.7125
14	.4534	.5344	.5668	.0747	.0747	.056	.6964
15	.3725	.5668	.6154	.0747	.0934	.0747	.7287
16	.421	.583	.664	.0747	.0747	.0747	.7449
17	.0747	.112	.0943	.0747	.0747	.0934	.112
18	.0747	.0934	.0566	.0747	.112	.112	.112
19	.1307	.1307	.1132	.1307	.1307	.0934	.112
20	.1307	.1307	.0943	.112	.1307	.132	.1307
21	.112	.1132	.0943	.112	.1307	.1132	.112
22	.0747		.0943	.4372	.4359	.4534	.112
23	.0747	.0943	.0754	.3725	.3768	.421	.0934
24	.0754	.0747	.0754	.0566	.3563	.3401	.3887
Max	.502	.5992	.6964	.4372	.7773	.9122	.8745
Min	.0747	.0747	.0566	.0566	.0747	.056	.0934
Avg	.2134	.2513	.2624	.1078	.2220	.2374	.4101

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 204 / Soni AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0747	.0754	.0754	.3887	.3563	.3725
2	.0754	.112	.0754	.0754	.3681	.3563	.3521
3	.0754	.0747	.0754	.0754	.3681	.3563	.3521
4	.0754	.0934	.0754	.0754	.3841	.3887	.3841
5	.0934	.112	.0943	.0943	.4049	.4372	.421
6	.112	.1494	.132	.1494	.4696	.5121	.5182
7	.1307	.1494	.1307	.1307	.7773	.8642	.6478
8	.0934	.0747	.0934	.112	.112	.0934	.0934
9	.4424	.502	.6154	.0934	.112	.1494	.8421
10	.5506	.5668	.664	.0747	.0934	.1307	.9393
11	.5668	.583	.6964	.0747	.0934	.0747	.7935
12	.5992	.5668	.6802	.0747	.056	.0747	.7287
13	.5182	.5506	.7287	.0747	.0934	.056	.6478
14	.4858	.583	.6802	.0934	.0934	.056	.7935
15	.4049	.6154	.7449	.0934	.0747	.0747	.8097
16	.4534	.8002	.7935	.112	.056	.1307	.8259
17	.0934	.0934	.0566	.112	.0747	.1307	.0747
18	.112	.0747	.0754	.112	.0934	.1494	.1494
19	.0934	.1307	.132	.1307	.1307	.1307	.1494
20	.112	.132	.132	.1494	.1307	.132	1.8298
21	.112	.1132	.1132	.1494	.112	.132	.1307
22	.0934	.0943	.0943	.4534	.5868	.4696	.112
23	.0747	.0754	.0754	.4049	.4588	.421	.0934
24	.0754	.0747	.0754	.3326	.3887	.3887	.3887
Max	.5992	.8002	.7935	.4534	.7773	.8642	1.8298
Min	.0747	.0747	.0566	.0747	.056	.056	.0747
Avg	.2299	.2665	.2962	.1385	.2467	.2527	.5187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 206 / 11kv Karoli AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.112	.132	.132	.3563	.3563	.3563
2	.132	.112	.132	.132	.3563	.3401	.3521
3	.132	.112	.132	.132	.3563	.3401	.3521
4	.132	.1307	.1509	.1509	.3725	.3563	.3521
5	.168	.168	.1886	.2241	.421	.4161	.4049
6	.2614	.2801	.3018	.2987	.5506	.5921	.5668
7	.3361	.3361	.3174	.3174	.9878	1.1203	.7773
8	.2801	.2801	.2241	.1867	.2054	.1494	.2801
9	.5344	.502	.502	.1867	.1494	.1494	.8583
10	.5506	.5344	.5182	.1494	.0934	.112	.9717
11	.6316	.6154	.583	.1478	.1307	.1494	.9878
12	.6154	.6154	.583		.112	.1307	.8907
13	.5182	.5344	.6316	.1307	.112	.1307	.8907
14	.4858	.5506	.583	.1307	.112	.1307	.8583
15	.3563	.583	.6478	.112	.112	.1494	.8583
16	.4372	.5668	.7125	.112	.112	.1494	.8745
17	.0934	1.8298	.1132	.1307	.1307	.1867	.1494
18	.1307	.1307	.132	.1307	.1867	.2241	.1867
19	.2241	.2241	.2075	.2241	.2614	.2987	.2241
20	.2241	.2641	.2263	.2054	.2614	.2829	.2427
21	.2054	.2452	.2075	.2054	.2241	.2452	.1867
22	.168	.1698	.1886	.4858	.4973	.421	.168
23	.112	.1509	.1509	.4049	.3932	.4049	.1494
24	.132	.112	.132	.132	.3725	.3563	.3725
Max	.6316	1.8298	.7125	.4858	.9878	1.1203	.9878
Min	.0934	.112	.1132	.112	.0934	.112	.1494
Avg	.2914	.3817	.3207	.1940	.2861	.2997	.5130

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244059 / 33/11 KV SONI

Feeder No / Name : 207 / 11KV Bhose AG Spare
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7611	.7773	.9231	.8421	.0934	.0943	.0943
2	.7611	.7773	.8642	.8097	.0934	.0943	.0943
3	.7449	.7773		.8097	.0934	.0943	.0943
4	.7449	.6478		.8097	.0934	.0943	.0943
5	.7682	.8421	.5344	.8259	.0905	.1132	.1132
6	.8642	.9878	.583	.9282	.112	.1307	.132
7	1.2803	1.4413	.9231	1.0722	.1307	.1307	.1509
8	.0934	.1307	.0747	.168	.1132	.1494	.1307
9	.112	.1307	.056	1.5364	1.9433	2.0805	.112
10	.112	.112	.056	1.9364	2.2996	2.3967	.1494
11	.112	.112	.056	1.4243	2.3158	1.8461	.1307
12	.0747	.0934	.056	1.6356	2.2996	2.1376	.1494
13	.0747	.112	.1307	1.7004	2.1214	2.251	.1494
14	.0747	.112	.0747	1.8299	2.1214	2.2996	.1307
15	.0747	.0934	.0747	1.9595	2.3482	2.3967	.1307
16	.112	.112		1.9595	2.2672	2.4939	.112
17	.0934	.112		.0943	.112	.1307	.112
18	.112	.112	.112	.1307	.112	.1307	.112
19	.1494	.1494	.1307	.168	.1494	.1494	.1307
20	.1494	.1307	.112	.1494	.1494	.1509	.1307
21	.1494	.1307	.112	.1494	.1307	.1509	.112
22	.9393	1.085	.9393	.112	.112	.132	1.2803
23	.8745	1.0526	.9393	.112	.112	.1132	1.2323
24	.8259	.8097	.9717	.8745	.0934	.0943	.0943
Max	1.2803	1.4413	.9717	1.9595	2.3482	2.4939	1.2803
Min	.0747	.0934	.056	.0943	.0905	.0943	.0943
Avg	.4191	.4517	.3862	.9182	.8128	.8273	.2155

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 201 / 11 KV Savali Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.5487	.5544	.5281	.1402	.1478	.168
2	.5601	.5487	.5601	.4854	.1372	.1478	.1698
3	.6535	.5601	.5658	.5093	.1543	.1463	.1867
4	.7545	.5544	.6283	.5041	.1509	.1463	.1886
5	.8488	.6283	.7392	.5415	.1658	.1848	.1867
6	.8962	.695	.9808	.6036	.1638	.1848	.1867
7	.9335	1.1088	1.2012	.7922	.1966	.2033	.2241
8	.132	.1848	.1494	.9054	.2347	.2218	.1886
9	.1494	.1829	.1886	.9709	.7011		.2241
10	.1132	.1478	.1867	1.094	1.0745	1.307	.1867
11	.128	.1494	.1494	1.0829	1.1157	1.2696	.1867
12	.1294	.1509	.1494	1.0642	1.1088	1.1694	.1867
13	.1307	.132	.1494	1.0562	1.0679	1.2826	.1494
14	.128	.112	.112	1.0829	1.0903	1.2826	.1494
15	.1294	.112	.132	1.1203	1.1157	1.307	.1478
16	.1478	.0943	.1509	1.1088	1.1088	1.2449	.1294
17	.1478	.132	.1509		.1848	.1886	.1494
18	.1867	.1698	.1509		.1848	.1886	.1867
19	.2218	.1886	.2054		.2218	.2054	.2427
20	.2218	.2241	.2012		.2241	.2641	.2614
21	.1867	.3018	.2054		.2218	.2241	.2452
22	.5853	.7023	.5601	.1867	.1867	.2075	.8676
23	.5487	.6219	.5281	.1663	.1646	.1867	.7842
24	.4854	.5487	.5975	.5041	.1463	.168	.1886
Max	.9335	1.1088	1.2012	1.1203	1.1157	1.307	.8676
Min	.1132	.0943	.112	.1663	.1372	.1463	.1294
Avg	.3696	.3666	.3832	.7530	.4692	.5165	.2411

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 202 / 11 KV SAIPRASAD

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.3142	.5281	.4668	.4557	.499	.5093
2	.4481	.3292	.5415	.5093	.463	.4854	.5093
3	.4481	.3326	.5658	.4854	.4458	.4805	.5228
4	.415	.3361	.499	.5093	.4359	.4805	.4904
5	.3772	.3292	.5228	.4715	.4144	.462	.5228
6	.3734	.3326	.4904	.4294	.4096	.439	.5093
7	.4108	.3174	.5041	.4668	.3932	.4572	.5281
8	.3696	.3658	.5281	.4481	.4144	.4024	.4108
9	.3658	.3881	.5228	.5975	.5609		.6161
10	.4668	.5175	.6224	.7356	.724	.5788	.7282
11	.4435	.7545	.8215	.7468	.924	.7922	.8215
12	.4481	.7095	.8589	.7468	.9511	.9242	.8215
13	.4251	.7545	.9149	.7762	.9425	.8676	.6838
14	.3696	.7282	1.0456	.8215	.8871	.8589	.7392
15	.3696	.8676	.9619	.8589	.8589	.7922	.9335
16	.4066	.8775	.7733	.8871	.7577	.7842	.8775
17	.3881	.9054	.6602	.7468	.7023	.7655	.8029
18	.4108	.9709	.5658	.5975	.6722	.679	.7095
19	.4024	.823	.5658	.5175	.5853	.5601	.5975
20	.4066	.5041	.4163	.4572	.5175	.5281	.4108
21	.3841	.5093	.4294	.4805	.439	.5228	.4668
22	.3658	.5175	.415	.4854	.5228	.4904	.4668
23	.3109	.5601	.415		.5175	.3734	.4854
24	.4668	.3174	.5788	.4481	.4668	.5228	.5041
Max	.4668	.9709	1.0456	.8871	.9511	.9242	.9335
Min	.3109	.3142	.415	.4294	.3932	.3734	.4108
Avg	.4052	.5568	.6145	.5952	.6026	.5977	.6112

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 203 / 11 KV Savali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.1494	.1886	.1698	.1147	.1478	.1509
2	.1463	.1478	.1478	.168	.1341	.1463	.1494
3	.1646	.1463	.1494	.168	.1526	.1478	.1509
4	.1646	.1463	.1478	.1698	.1526	.1463	.1663
5	.1848	.1663	.1886	.1698	.1715	.1494	.168
6	.2241	.2195	.2075	.1886	.1715	.1829	.2263
7	.2641	.2378	.2614	.2075	.1844	.1867	.2054
8	.2241	.2195	.2241	.1867	.1865	.2033	.1886
9	.2241	.2033	.1886	.168	.1715		.1494
10	.1509	.2012	.168	.1509	.1578	.1848	.1867
11	.1663	.1867	.168	.1494	.1646	.1867	.1494
12	.1663	.1886	.1494		.1848	.2075	.1867
13	.1663	.168	.1494	.1663	.1646	.168	.168
14	.1478	.1698	.112	.1494	.1478	.2075	.168
15	.1478	.1307	.1494	.1494	.168	.1867	.168
16	.1294	.132	.1494	.1698	.1463	.2075	.168
17	.1663	.1494	.1494	.1663	.2587	.1848	.168
18	.2241	.1886	.1867	.1829	.2743	.1867	.2054
19	.3475	.2218	.2427	.1791	.2926	.2263	.2987
20	.3326	.2987	.2241	.2743	.2743	.2427	.2801
21	.2561	.2829	.2054	.2347	.2561	.2829	.2614
22	.2614	.2614	.2241	.2058	.2218	.2614	.2427
23	.2195	.2075	.1867		.1867	.2263	.2241
24	.1494	.1848	.2054	.1698	.1296	.1772	.168
Max	.3475	.2987	.2614	.2743	.2926	.2829	.2987
Min	.1294	.1307	.112	.1494	.1147	.1463	.1494
Avg	.1990	.1920	.1822	.1793	.1861	.1934	.1916

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 204 / BOTHRA FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5544	.112	.3772	.6602	.6516	.4805	.5658
2	.5121	.112	.3734	.6348	.6706	.4108	.5601
3	.4755	.1294	.2957	.679	.6371	.4108	.5175
4	.4435	.1294	.2987	.6722	.6516	.3696	.4854
5	.3696	.1478	.2641	.6535	.6104	.3326	.4904
6	.3361	.1463	.2241	.6413	.6036	.2195	.4108
7	.2241	.1478	.2641	.679	.6001	.3658	.4527
8	.1848	.1478	.1867	.6224	.583	.3696	.6036
9	.1829	.1494	.1886	.6283	.6089	.6036	.4668
10	.168	.2772	.5975	.8589	.6219	.4435	.8402
11	.1494	.3361	.6161	.8215	.7392	.679	1.0456
12	.1478	.3395	.5601	.7762	.7865	.6348	.8962
13	.1463	.3395	.5041	.7468	.7499	.695	.7392
14	.1478	.2987	.5228	.9054	.7392	.6722	.7468
15	.1294	.3395	.6161	.8962	.7499	.6036	.924
16	.1109	.3734	.6161	.9335	.7762	.6348	.8501
17	.112	.3772	.7167	.8316	.7095	.7095	.9055
18	.1478	.3734	.6036		.6653	.679	.6535
19	.1829	.2263	.3734		.5487	.4854	.5228
20	.1848	.2241	.2743		.4755	.415	.5175
21	.1829	.1698	.2218	.4801	.3734	.3734	.4435
22	.1848	.2241	.4481		.4066	.4108	.6838
23	.1463	.3395	.5788		.6283	.4527	.7095
24	.5975	.1478	.3734	.6979	.6706	.6036	.5601
Max	.5975	.3772	.7167	.9335	.7865	.7095	1.0456
Min	.1109	.112	.1867	.4801	.3734	.2195	.4108
Avg	.2509	.2337	.4206	.7273	.6357	.5023	.6496

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 205 / 11 KV REX

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5544	.6535	.6283	.6161	.3772	.5729	.5847
2	.5601	.6468	.5788	.6602	.3688	.567	.5487
3	.5228	.6401	.6036	.6413	.3978	.5544	.5975
4	.5544	.6468	.5544	.6535	.4359	.5544	.5847
5	.5175	.6401	.5788	.6535	.4748	.5975	.5601
6	.5121	.6468	.6036	.679	.4641	.6036	.5847
7	.4887	.6468	.6413	.4715	.5144	.499	.5601
8	.5487	.5853	.5847	.415	.5144	.5175	.6036
9	.5853	.5914	.5601	.4294	.5609		.547
10	.6908	.6401	.6224	.4904	.6516	.567	.7655
11	.5914	.6161	.5847	.4854	.5914	.5601	.6348
12	.5544	.5601	.5788	.4668	.567	.547	.6161
13	.5175	.5281	.5975	.462	.5544	.5228	.6653
14	.3142	.5601	.6161	.4481	.5601	.547	.5601
15	.2957	.5281	.547	.4527	.5729	.5228	.4805
16	.2957	.5601			.5601	.6413	.4108
17	.4435	.547	.4338	.4668	.5544	.6161	.4294
18	.4668	.5788	.547	.462	.5487	.5847	.4854
19	.4572	.5658	.679		.5544	.5601	.4108
20	.462	.5975	.6335		.5601	.5281	.6161
21	.4755	.6602	.5975	.462	.5729	.5788	.6535
22	.5601	.6348	.5093	.4481	.6535	.5601	.5975
23	.6401	.6224	.547		.6099	.547	.6348
24	.5121	.6468	.6535	.5788	.3506	.5853	.5601
Max	.6908	.6602	.679	.679	.6535	.6413	.7655
Min	.2957	.5281	.4338	.415	.3506	.499	.4108
Avg	.5050	.6060	.5861	.5221	.5238	.5624	.5705

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244093 / 33/11 KV Savali Kanadwadi

Feeder No / Name : 208 / 11KV KANADWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1294	.1109	.1509	.1174	.128	.132
2	.112	.128	.112	.1494	.1372	.1294	.112
3	.1109	.1109	.132	.1494	.1372	.1294	.1109
4	.1294	.1097	.1294	.1509	.1174	.128	.0934
5	.1307	.1294	.1509	.1494	.1147	.1294	.112
6	.1494	.1478	.1494	.1494	.1326	.128	.132
7	.1509	.128	.1294	.1307	.1174	.1463	.132
8	.1307	.1294	.1494	.1307	.12	.1494	.1132
9	.1294	.1294	.1698	.1494	.1433		.168
10	.1494	.1663	.2241	.1494	.1463	.1478	.168
11	.1494	.1509	.2054	.1509	.1663	.168	.168
12	.1478	.1307	.1867	.168	.1463	.1698	.1663
13	.1478	.1307	.1867	.168	.1663	.1509	.1848
14	.112	.1509	.1494	.1509	.1478	.1494	.1848
15	.1109	.1307	.168	.1494	.168	.1509	.1663
16	.1109	.1509		.1494	.1646	.1698	.2054
17	.1109	.1494	.168	.1663	.1646	.1478	.168
18	.112	.1698	.1307	.1433	.2033	.1294	.1867
19	.1463	.168	.2054	.1578	.2012	.1509	.2054
20	.1848	.1886	.1848	.1543	.1848	.1494	.2241
21	.1867	.1886	.1698	.1372	.1646	.1509	.168
22	.1463	.1478	.1509	.1341	.1478	.132	.1886
23	.1294	.1494	.1494		.1463	.1494	.1886
24	.1294	.128	.1509	.1509	.1311	.1478	.1509
Max	.1867	.1886	.2241	.168	.2033	.1698	.2241
Min	.1109	.1097	.1109	.1307	.1147	.128	.0934
Avg	.1346	.1434	.1593	.1496	.1494	.1449	.1596

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244107 / 33/11KV Malgaon

Feeder No / Name : 201 / 11 KV malgaon Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.4763	.4572	.4191	.5121	.4805	.4382
2	.362	.4763	.4251	.4191	.4572	.4668	.4191
3	.362	.4191	.4251	.4001	.4024	.4854	.4191
4	.362	.4191	.4207	.4001	.3658	.4854	.4191
5	.4191	.4191	.4755	.4572	.3658	.4854	.4763
6	.5144	.4763	.5544	.5716	.3658	.5041	.5335
7	.6097	.5601	.567	.5716	.6401	.5228	.5975
8	.5544	.5359	.5304	.5228	.5304	.5359	.543
9	.4755	.5083	.5121	.4207	.4572	.4656	.4525
10	.4938	.5028	.4572	.4572	.4024	.3841	.4835
11	.4755	.4835	.4572	.4344	.439	.4854	.4835
12		.5014	.439	.4207	.3841	.4656	.4835
13	.2987	.4252	.439	.439	.3841	.4854	.443
14	.3109	.4298	.3658	.4207	.4024	.4805	.4075
15	.3475	.4207	.362	.4207	.4207	.462	.4163
16	.3658	.439	.3898	.4024	.4572	.4435	.3582
17	.3898	.462	.4298	.3658	.5121	.4298	.5068
18	.3366	.5544	.5028	.3658	.6036	.4681	.5895
19	.6268	.7499	.6767	.439	.7392	.7164	.7265
20	.724	.8048	.7468	.5121	.7023	.7865	.7087
21	.7059	.7577	.7095	.6401	.6468	.7282	.7207
22	.6099	.6401	.6348	.6036	.5729	.6287	.6348
23	.5041	.6401	.4954	.5121	.5175	.4954	.5335
24	.381	.4763	.4938	.4382	.5121	.4805	.4382
Max	.724	.8048	.7468	.6401	.7392	.7865	.7265
Min	.2987	.4191	.362	.3658	.3658	.3841	.3582
Avg	.4613	.5241	.4986	.4606	.4914	.5155	.5097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244107 / 33/11KV Malgaon

Feeder No / Name : 202 / 11 KV Cannal AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5937	.6249	.6455	.7164	.2286	.2286	.2667
2	.578	.5937	.639	.7099	.2286	.2286	.2667
3	.578	.6009	.639	.7099	.2286	.2286	.2667
4	.578	.6173	.6539	.7099	.2286	.2286	.2667
5	.6249	.703	.8036	.7499	.2286	.3048	.3048
6	.7811	.9374	1.1717	.8592	.2667	.4001	.4001
7	1.4232	1.4074	1.4198	1.078	.2667	.4191	.4382
8	.362	.362	.3429	.381	.2667	.381	.381
9	.3429	.362	.3292	1.3272	1.4575	1.4043	.2667
10	.2667	.3048	.2858	1.448	1.5384	1.5935	.2667
11	.2858	.2667	.2667	1.4661	1.4899	1.4352	.2667
12		.2286	.2286	1.3904	1.4899	1.4327	.2096
13	.2477	.2286	.2286	1.2811	1.4575	1.3565	.1905
14	.2096	.2477	.2286	1.3123	1.4575	1.326	.1905
15	.2096	.2096	.2286	1.2963	1.4089	1.46	.2096
16	.2096	.2477	.2477	1.3592	1.4089	1.5352	.2286
17	.2667	.2667	.2858	.2667	.2477	.3048	.2667
18	.2858	.3239	.3239	.2667	.2858	.3429	.3239
19	.381	.362	.381	.2858	.362	.381	.4572
20	.3429	.381	.4001	.3048	.3429	.4191	.4191
21	.3429	.362	.381	.3048	.3239	.381	.381
22	.8539	.8741	.9014	.3429	.2858	.3239	1.0155
23	.7253	.7819	.7526	.2858	.2477	.2858	.8905
24	.5864	.6249	.695	.7316	.2667	.2286	.2667
Max	1.4232	1.4074	1.4198	1.4661	1.5384	1.5935	1.0155
Min	.2096	.2096	.2286	.2667	.2286	.2286	.1905
Avg	.4816	.4966	.52	.8160	.6673	.6929	.3517

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244134 / 33/11KV Sidhewadi

Feeder No / Name : 201 / 11 KV Sidhewadi AG

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1109	.1307	.1132	.3858	.5312	.4801
2	.132	.1109	.1294	.1132	.3637	.5864	.4586
3	.132	.1075	.132	.1132	.3321	.6562	.4801
4	.132	.1097	.1509	.1132	.3637	.759	.4062
5	.1509	.1109	.1829	.132	.3681	.8642	.4428
6	.1698	.1646	.1848	.1698	.6062	.9831	.5668
7	.2452	.2012	.2075	.1698	.9555	1.0402	.7773
8	.1886	.2033	.1509	.132	.132	.132	.168
9	.4961	.6468	.7116	.132	.0934	.1307	.7655
10	.5079	.6173	.8065	.0554	.0934	.0924	.9014
11	.5487	.6019	.8592	.0543	.0934	.1109	.8381
12		.7099	.7562	.0543	.0747	.0914	.8592
13	.442	.7461	.7621	.0543	.0347	.0732	.8436
14	.7045	.6443	.7164	.056	.0739	.0732	.8223
15	.7045	.6636	.8124	.0747	.0732	.056	.9014
16	.6554	.6687	.602	.0747	.0724	.0747	.8429
17	.0655	.0373	.0554	.0732	.0724	.0739	.0754
18	.0655	.0943	.0747	.0739	.112	.0747	.0739
19	.1526	.1698	.1509	.1509	.1886	.1509	.1886
20	.1526	.2075	.1886	.1698	.1886	.1886	.2075
21	.1677	.1886	.2075	.1698	.1698	.1886	.1698
22	.1646	.1715	.1698	.6154	.6562	.5506	.1509
23	.128	.1509	.1509	.4696	.5937	.4801	.132
24	.132	.1097	.132	.132	.3795	.4902	.4801
Max	.7045	.7461	.8592	.6154	.9555	1.0402	.9014
Min	.0655	.0373	.0554	.0543	.0347	.056	.0739
Avg	.2770	.3145	.3511	.1444	.2699	.3522	.5014

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244134 / 33/11KV Sidhewadi

Feeder No / Name : 202 / 11KV Kalambi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.1109	.1109	.1132	.0934	.0914	.0924
2	.0943	.1109	.112	.1132	.0747	.0924	.1109
3	.0943	.1097	.112	.1132	.0924	.0934	.0934
4	.0943	.1097	.1132	.1132	.0934	.0943	.1294
5	.1132	.1097	.128	.132	.0934	.1109	.112
6	.1509	.128	.1478	.1509	.1307	.1097	.1307
7	.1509	.1646	.1509	.1509	.1132	.1132	.1698
8	.1132	.128	.1294	.1494	.128	.0943	.1543
9	.2033	.3149	.2543	.1943	.1463	.1448	.1075
10	.2033	.2572	.3772	.2486	.2035	.1448	.2652
11	.2033	.2401	.2543	.3561	.218	.2804	.2458
12		.1658	.1865	.373	.1638	.1402	
13	.1097	.1433	.1715	.2347	.156	.1715	.2543
14	.1848	.1075	.0943	.2401	.0914	.2587	.3018
15	.1848	.1578	.1886	.2543	.1109	.1595	.2818
16	.1663	.2652	.128	.2155	.128	.2035	.216
17	.1478	.2515	.1063	.3441	.1646	.2374	.3018
18	.1478	.2561	.2543	.2241	.2149	.3149	.2035
19	.1478	.2241	.2054	.1509	.1886	.1867	.1886
20	.1478	.1886	.2075	.1886	.1698	.1886	.2075
21	.1663	.1698	.1698	.1698	.1509	.1698	.1886
22	.1663	.1698	.1509	.1698	.1307	.1509	.1698
23	.1478	.1463	.132	.112	.1132	.1109	.1509
24	.0943	.1109	.1109	.1132	.112	.0914	.1109
Max	.2033	.3149	.3772	.373	.218	.3149	.3018
Min	.0943	.1075	.0943	.112	.0747	.0914	.0924
Avg	.1446	.1725	.1665	.1927	.1367	.1564	.1820

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244134 / 33/11KV Sidhewadi

Feeder No / Name : 203 / 11 KV Kalambi Ag

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.16	.2454	.2134	.2164	.0739	.0732	.0739
2	.16	.2401	.192	.2164	.0934	.0739	.0554
3	.16	.2454	.1947	.2164	.0732	.0747	.0739
4	.16	.2401	.2743	.2164	.0732	.0914	.0554
5	.16	.2804	.3666	.2164	.0924	.0924	.0739
6	.2317	.5144	.4172	.282	.112	.0914	.0934
7	.4089	.5487	.5213	.4033	.1109	.0905	.0934
8	.0739	.0343	.0838	.0876	.0914	.0886	.0876
9	.0905	.0686	.0648	.4572	.423	.5068	.0701
10	.0905	.0739	.0716	.3978	.439	.4311	.0895
11	.052	.0532	.0716	.4172	.4371	.4633	.0895
12		.0492	.0716	.4033	.3704	.4033	.0671
13	.0716	.0503	.0886	.3681	.4214	.3923	.0671
14	.0716	.0497	.0509	.3155	.3567	.3894	.0514
15	.0537	.052	.0716	.3788	.3788	.4033	.0701
16	.0537	.0686	.0886	.4572	.4001	.4858	.104
17	.0549	.0693	.0914	.0701	.0886	.0701	.0905
18	.0914	.1075	.0876	.0895	.1086	.0886	.1612
19	.0914	.128	.0914	.128	.1254	.0895	.128
20	.0914	.0924	.1109	.1097	.1097	.0924	.0924
21	.0914	.0924	.1109	.1109	.1109	.0934	.112
22	.3658	.3206	.257	.0924	.0876	.0747	.2961
23	.3258	.2256	.23	.0739	.0709	.0739	.2503
24	.1623	.3258	.2103	.2	.0739	.0724	.0739
Max	.4089	.5487	.5213	.4572	.439	.5068	.2961
Min	.052	.0343	.0509	.0701	.0709	.0701	.0514
Avg	.1423	.1740	.1680	.2469	.1968	.2003	.1008

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244137 / 33/11KV NARWAD

Feeder No / Name : 201 / 11 KV NARWAD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0747	.0754	.0566	.056	.0754	.0566
2	.0747	.0754	.0747	.0566	.056	.056	.0566
3	.0747	.056	.0747	.056	.056	.056	.0566
4	.0754	.0566	.0566	.0566		.0754	.0754
5	.0934	.056	.0747	.0566	.0747	.0754	.0754
6	.1132	.0747	.0943	.0754	.056	.0754	.0754
7	.1509	.0934	.1132	.0934	.0943	.0754	.0754
8	.132	.0943	.1132	.0943	.0943	.0754	.0754
9	.132	.0934	.1132	.0934	.0754	.0943	.0754
10	.132	.0754	.0747	.0566	.0754	.0943	
11	.112	.0754	.0943	.0754	.0754	.0754	.2054
12	.0943	.0754	.0934	.0754	.0754	.1698	.0754
13	.0934	.056	.1132	.0754	.0566	.1698	.0747
14	.0566	.056	.0934	.0943	.0566	.0943	.0566
15	.056	.0566	.0943	.0754	.0747	.0754	.056
16	.0566	.0566	.0943	.0566	.0754	.1886	.0566
17	.0747	.0566	.0934	.0943	.0754	.2075	.0566
18	.0747	.0934	.0943	.0943	.0943	.0754	.0934
19	.0943	.112	.0934	.1132	.1132	.0943	.132
20	.1307	.132	.0934	.1307	.1307	.0943	.1698
21	.132	.1132	.0943	.0934	.1132	.1132	.168
22	.112	.1132	.0934	.0934	.0943	.2263	.132
23	.0754	.0943	.0754	.0747	.0754	.0943	.0934
24	.0943	.0747	.0943	.056	.056	.0754	.0754
Max	.1509	.132	.1132	.1307	.1307	.2263	.2054
Min	.056	.056	.0566	.056	.056	.056	.056
Avg	.0971	.0798	.0908	.0791	.0785	.1045	.0899

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244137 / 33/11KV NARWAD

Feeder No / Name : 202 / 11 KV GAYRANWADI AG

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.0747	.0754	.9602	1.2631	.9717
2	.0747	.0754	.0754	.0747	.8907	1.2146	.9602
3	.056	.056	.0566	.0566	.9602	1.1203	.8802
4	.056	.0566	.056	.056		1.0883	.9393
5	.0754	.0566	.056	.056	.7499	1.0526	.9717
6	.0943	.0754	.1132	.0754	.9998	1.2003	1.2793
7	.1307	.0747	.1132	.0934	1.2963	1.4243	1.4413
8	.0934	.0754	.0934	.0934	.081	.1132	.0747
9	1.0562	1.1523	1.2003	.0943	.1132	.1307	1.6876
10	1.2483	1.3443	1.3443	.112	.132	.112	
11	.8539	1.5223	1.4083	.0934	.1132	.112	1.8515
12	1.0437	1.4243	1.4723	.0747	.112	.0934	1.8299
13	1.1069	1.3923		.0934	.112	.0934	1.8299
14	1.1069	1.186		.0747	.1132	.112	1.7604
15	1.0753	1.3283		.0747	.1132	.1307	1.3441
16	1.1069	1.2967	1.4251	.0934	.112		1.2955
17	.0747	.0934		.0934	.1132		.112
18	.0747	.112	.1494	.0934	.1307		.1132
19	.0934	.132	.1509	.1307	.1509		.1307
20	.1132	.132	.1494	.1307	.1494	.1307	.1509
21	.1132	.1307	.132	.112	.1307	.112	.1307
22	.0934	.112	.112	1.2163	1.3603	1.2643	.132
23	.0754	.112	.0943	1.3603	1.3765	1.3123	.112
24	.0943	.0754	.0934	.0934	1.1336	1.3279	1.1336
Max	1.2483	1.5223	1.4723	1.3603	1.3765	1.4243	1.8515
Min	.056	.056	.056	.056	.081	.0934	.0747
Avg	.4161	.5038	.4185	.1884	.4958	.6704	.9188

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

MIRAJ RURAL[076]

BU 1244

Substation No/ Name :- 244137 / 33/11KV NARWAD

Feeder No / Name : 203 / 11 KV BHAVANI AG

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0781	.0937	.0781	.0937	1.1145	1.3283	1.0402
2	.0781	.0937	.0625	.0781	.9602	1.3123	.9602
3	.0617	.0937	.0625	.0781	.8802	1.2803	.8802
4	.0772	.0937	.0625	.0781		1.2323	.8802
5	.0781	.0937	.0781	.0781	1.3603	1.1843	1.0402
6	.125	.125	.1094	.0937	1.1203	1.4083	1.2803
7	.1406	.125	.125	.1094	1.2803	1.6804	1.3283
8	.1406	.125	.1094	.1094	.112	.128	.112
9	1.1405	1.3435	1.406	.1094	.112	.128	1.6644
10	1.3904	1.4842	1.4842	.0937	.112	.112	
11	.9686	1.4373	1.6248	.0937	.128	.112	1.668
12	1.2186	1.4842	1.656	.0937	.112	.096	1.7004
13	1.3123	1.4685	1.6248	.125	.112	.096	1.7652
14	1.2334	1.4217	1.6248	.125	.144	.112	1.6518
15	.9061	1.4685	1.6091	.125	.128	.128	1.2003
16	1.1717	1.531	1.5623	.1094	.128	.128	1.1523
17	.1094	.0937	.125	.0937	.128	.112	.1423
18	.1094	.1094	.1406	.1463	.112	.144	.1581
19	.125	.125	.1406	.1646	.128	.176	.1581
20	.1406	.1406	.1406	.1646	.144	.176	.1739
21	.1406	.125	.125	.1463	.144	.16	.1581
22	.125	.1094	.125	1.406	1.4864	1.3603	.1265
23	.1094	.0937	.0937	1.4232	1.4548	1.3283	.112
24	.0937	.0937	.0937	.0937	1.2003	1.4232	1.1523
Max	1.3904	1.531	1.656	1.4232	1.4864	1.6804	1.7652
Min	.0617	.0937	.0625	.0781	.112	.096	.112
Avg	.4614	.5572	.5943	.2180	.5479	.6394	.8915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 201 / 11 KV Anjani AG

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0457	.0474	.0457	.0446	.1833	.2	.2225
2	.0474	.0474	.0469	.0457	.1882	.2	.2
3	.0469	.0469	.0469	.0457	.1882	.2172	.2134
4	.0781	.0463	.064	.0781	.208	.2675	.2534
5	.1094	.0625	.1134	.1094	.2201	.3048	.2934
6	.1296	.1147	.1475	.1475	.3121	.4321	.3111
7	.1619	.1492	.1638	.1781	.6773	.759	.4729
8	.1094	.1296	.125		.0781	.1389	.112
9	.301	.3858	.5053	.0772	.064	.0791	.5944
10	.3418	.3913	.4199	.0587	.0781	.0602	.6642
11	.3814	.3185	.4108	.044	.0625	.061	.5401
12	.362	.362	.4666	.04	.0434	.061	.4458
13	.2921	.3292	.4172	.0406	.0587	.0734	.5201
14	.2858	.3477	.4001	.0412	.04	.0602	.5729
15	.2881	.3475	.4694	.0434	.0417	.0541	.4904
16	.2801	.4287	.4816	.0423	.0526	.0579	.5487
17	.0564	.0541		.0587	.0676	.0541	.0511
18	.0594	.0572	.0549	.0602	.0676	.0541	.0549
19	.0791	.0781	.0762	.0594	.0762	.0602	.0781
20	.0791	.0791	.0949	.0781	.0762	.0949	.0949
21	.0602	.0625	.0926	.0772	.0762	.0937	.0791
22	.0469	.0625	.0762	.3549	.3567	.4012	.0625
23	.0463	.061	.0602	.2408	.2503	.282	.0617
24	.0446	.0469	.061	.0429	.2	.2364	.2397
Max	.3814	.4287	.5053	.3549	.6773	.759	.6642
Min	.0446	.0463	.0457	.04	.04	.0541	.0511
Avg	.1555	.1690	.2104	.0873	.1528	.1793	.2991

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 202 / 11 KV Bastavade Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677	.2458	.2606	.208	.0924	.1132	.0754
2	.1677	.2429	.2606	.2134	.0914	.1132	.0943
3	.1677	.2401	.3041	.2134	.0905	.1132	.0754
4	.2286	.2949	.3418	.2591	.1063	.1509	.0943
5	.2812	.3163	.4268	.3048	.1254	.1886	.1886
6	.3593	.4801	.5312	.3506	.181	.2452	.2075
7	.8278	.7907	1.034	.503	.2686	.2641	.2987
8	.2263	.2481	.2614		.1991	.2427	.1867
9	.181	.1629	.1509	.4904	.5921	.6472	.1698
10	.1097	.132	.1109	.5441	.535	.639	.112
11	.0924	.0914	.0934	.5535	.381	.5428	.1109
12	.0747	.0747	.0739	.4755	.5053	.4161	.0934
13	.0747	.0732	.0678	.4666	.5287	.5647	.0924
14	.0747	.1109	.0549	.5556	.4664	.5216	.112
15	.0747	.0924	.0709	.5761	.6485	.6516	.0934
16	.0739	.0724	.0924	.6481	.6661	.7385	.1109
17	.0716	.0732		.1075	.0914	.0914	.1433
18	.128	.1086	.0905	.1097	.1463	.128	.1646
19	.168	.1663	.1307	.1848	.168	.1867	.2241
20	.2012	.1886	.2075	.1867	.2263	.1867	.2075
21	.1848	.1698	.1698	.1829	.1886	.1886	.1867
22	.3658	.3567	.3201	.1448	.1509	.1509	.5053
23	.2401	.3185	.2572	.1075	.1132	.1132	.4001
24	.1783	.2401	.2921	.2115	.0914	.1132	.0943
Max	.8278	.7907	1.034	.6481	.6661	.7385	.5053
Min	.0716	.0724	.0549	.1075	.0905	.0914	.0754
Avg	.1967	.2204	.2436	.3303	.2772	.3046	.1684

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 203 / 11 KV Dongarsoni AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4531	.4801	.5647	.4572	.197	.2241	.1867
2	.4531	.4858	.5575	.4531	.2012	.2241	.2075
3	.4531	.4915	.6097	.4531	.1886	.2263	.2075
4	.5468	.5182	.8749	.5468	.2683	.415	.2075
5	.7202	.6562	1.1469	.7888	.3481	.5658	.3206
6	.8987	.8745	1.4582	1.0442	.5735	.679	.679
7	1.7072	1.8244	2.1548	1.3279	.5668	.6979	.6348
8	.5093	.4144	.4854		.3544	.4481	.4294
9	.3174	.333	.2614	.9217	1.2963	1.3443	.2987
10	.1802	.2801	.2054	.9105	1.3125	1.2803	.1848
11	.1326	.2378	.1433	.8592	1.3599	1.3592	.124
12	.1509	.2218	.1387	.8179	1.1265	1.0155	.1417
13	.1311	.181	.1402	.0406	1.1561	1.0059	.1791
14	.1326	.1753	.1417	.0705	1.0517	1.1265	.1463
15	.1475	.1612	.1433	.9568	1.2809	1.5181	.1478
16	.1492		.1478	1.2346	1.2651	1.5779	.2033
17	.1509	.2012		.1791	.2149	.2715	.2033
18	.3045	.197	.2561	.2896	.2715	.2772	.2957
19	.3982	.3547	.3734	.3841	.4108	.4108	.3696
20	.4298	.415	.4715	.394	.4481	.4481	.3696
21	.3721	.415	.415	.3801	.3734	.3734	.3174
22	.6874	.8381	.884	.2686	.2829	.2801	.5864
23	.5761	.6097	.503	.197	.2241	.2054	.4725
24	.4572	.4744	.5721	.4607	.1991	.2241	.2054
Max	1.7072	1.8244	2.1548	1.3279	1.3599	1.5779	.679
Min	.1311	.1612	.1387	.0406	.1886	.2054	.124
Avg	.4358	.4713	.5500	.5842	.6238	.6749	.2966

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 204 / 11 KV Jarandi AG

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1718	.1943	.1252	.208	.0829	.0791	.0819
2	.176	.1875	.1252	.2134	.081	.0791	.0819
3	.176	.1829	.1337	.2134	.081	.0937	.0819
4	.2241	.2317	.1852	.2743	.128	.128	.081
5	.2881	.2968	.2241	.3437	.1638	.1619	.1311
6	.3887	.3725	.2753	.4372	.2294	.2294	.2294
7	.8025	.9122	.4725	.7621	.2458	.2458	.2785
8	.1781	.1781	.1296		.1781	.2105	.176
9	.112	.1296	.08	.4967	.7562	.828	.1296
10	.096	.0791	.0602	.4967	.7186	.7253	.08
11	.0617	.0743	.0937	.3666	.6636	.5792	.096
12	.0772	.064	.0972	.4172	.6327	.6097	.112
13	.0781	.1219	.064	.3948	.5944	.5719	.0474
14	.0791	.0949	.0949	.4841	.5944	.587	.112
15	.0556	.0781	.08	.5647	.639	.7074	.112
16	.0705	.1067	.0949	.5357	.6687	.7727	.128
17	.096	.0617		.0791	.08	.128	.1067
18	.108	.0791	.112	.0937	.112	.16	.112
19	.176	.08	.16	.144	.1619	.208	.1457
20	.1781	.08	.1509	.1619	.1781	.1619	.144
21	.1296	.08	.1134	.1457	.1619	.1619	.1296
22	.2932	.208	.4696	.0972	.0983	.1311	.2591
23	.2241	.176	.3077	.0819	.0819	.081	.2258
24	.1875	.2241	.1286	.2172	.0819	.081	.081
Max	.8025	.9122	.4725	.7621	.7562	.828	.2785
Min	.0556	.0617	.0602	.0791	.08	.0791	.0474
Avg	.1845	.1789	.1643	.3143	.3089	.3217	.1318

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 205 / 11 KV Savalaj Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2218	.2452	.2263	.2427	.2452	.2641
2	.2075	.2172	.2452	.2075	.2427	.2452	.2641
3	.2075	.2149	.2641	.2075	.2402	.2641	.2641
4	.2641	.2378	.3018	.2829	.2743	.2829	.2452
5	.3395	.2896	.3772	.3584	.3109	.3584	.3584
6	.4338		.4904	.4904	.4477	.4715	.5093
7	.547	.5258	.5281	.5093	.5258	.5281	.5601
8	.4854	.4508	.5228		.3721	.4294	.4481
9	.3772	.3506	.3361	.2987	.2804	.3326	.3326
10	.2987	.3361	.3361	.2835	.2614	.2772	.3326
11	.2772	.3142	.2614	.2865	.3326	.2772	.2957
12	.2614	.2957	.2195	.1991	.3142	.2801	.3142
13	.2587		.2743	.2507	.2427	.2772	.2957
14	.2561	.3109	.2561	.2715	.2801	.2772	.2957
15	.2353	.2772	.2614	.2507	.2801	.2801	.2957
16	.2378	.2743	.2452	.2534	.3109	.2801	.2587
17	.3258	.2772		.3224	.3109	.2957	.2772
18	.3841	.3475	.3395	.3077	.3658	.3142	.2987
19	.5068	.5228	.5041	.4477	.5487	.5175	.3961
20	.5194	.547	.5228	.543	.5228	.5788	.4338
21	.4344	.4715	.4715	.4938	.4904	.4854	.4338
22	.3439	.3772	.3961	.362	.415	.4338	.415
23	.2378	.3018	.2829	.3361	.3206	.3395	.3395
24	.2452	.2378	.2452	.2452	.2587	.2641	.3018
Max	.547	.547	.5281	.543	.5487	.5788	.5601
Min	.2075	.2149	.2195	.1991	.2402	.2452	.2452
Avg	.3296	.3364	.3447	.3232	.3413	.3473	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 207 / 11 KV Savlaj Water Supply NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0133	.0143	.0114	.0133	.0145	.0133	.0122
2	.0152	.0139	.0114	.0143	.0147	.0149	.0133
3	.0152	.0141	.0149	.0152	.0147	.0152	.0137
4	.0152	.0145	.0152	.0152	.0145	.016	.0151
5	.0152	.0143	.016	.0152	.0143	.0156	.0152
6	.0152	.0139	.0164	.0152	.0141	.0166	.0152
7	.0152	.0143	.016	.0158	.0145	.017	.0154
8	.0151	.0145	.0072		.0145	.008	.0105
9	.008	.0143	.0122	.0141	.0143	.0147	.0114
10	.0143	.0084	.009	.0145	.0162	.0152	.013
11	.0145	.0084		.0141	.0162	.0149	.0154
12	.0141	.0084	.009	.0143	.0135	.0114	.0152
13	.0143	.0072	.009	.0143	.0116	.0114	.0154
14	.0141	.0151	.0158	.0145	.0154	.0114	.0156
15	.0141	.0156	.0128	.0145	.0139	.0114	.016
16	.0143	.0131	.0156	.0141	.0158	.0114	.0152
17	.0141	.0139		.0145	.0141	.0154	.0149
18	.0143	.0154	.0099	.0143	.0141	.0151	.0152
19	.0141	.008	.0084	.0143	.0111	.0151	.013
20	.0143	.0105	.0093	.0145	.0084	.0152	.0133
21	.0145	.0093	.0111	.0143	.0088	.0151	.009
22	.0143	.012	.0114	.0143	.0135	.0135	.013
23	.0141	.0111	.013	.0141	.0122	.0133	.0114
24	.013	.0141	.0103	.013	.0143	.0116	.0122
Max	.0152	.0156	.0164	.0158	.0162	.017	.016
Min	.008	.0072	.0072	.013	.0084	.008	.009
Avg	.0142	.0124	.0121	.0144	.0137	.0139	.0137

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244016 / 33/11 KV Savlaj Substation

Feeder No / Name : 209 / 11 KV Savlaj Ag

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.2195	.2054	.2054	.5376	.4725	.3353
2	.168	.2172	.2054	.1886	.5441	.4572	.3353
3	.1698	.2149	.2075	.1886	.5506	.503	.3353
4	.2452	.2896	.2641	.2263	.6325	.5535	.3506
5	.3206	.3109	.3772	.3395	.7186	.8259	.427
6	.4481	.4252	.5093	.4294	.9602	1.0442	.5182
7	.4854	.4557	.4715	.462	1.406	1.6221	.7956
8	.3921	.362	.3547		.3315	.3547	.3174
9	.7186	.8436	.8488	.2241	.2507	.2427	.8855
10	.7682	.823	.953	.1478	.1867	.1829	.9374
11	.7125	.7579	.7522	.1463	.1463	.1663	.9998
12	.7042	.743	.7842	.1478	.1646	.1267	1.0402
13	.6478	.7282	.8322	.1494	.1254	.1227	.9442
14	.6401	.724	.8907	.1478	.1267	.1254	.8482
15	.583	.7876	.9282	.1463	.1612	.1267	.9442
16	.5761	.8509	1.0311	.1448	.1357	.1448	1.0082
17	.1638	.1715	.2241	.1829	.208	.197	.2054
18	.2561	.1829	.2427	.2587	.2172	.2534	.2614
19	.362	.3142	.2614	.3361	.3547	.3174	.3361
20	.3658	.3174	.3174	.3361	.3734	.3547	.3921
21	.3326	.3142	.2801	.3326	.3174	.2987	.3174
22	.2534	.2641	.2614	.8002	.7449	.5182	.2801
23	.2561	.2241	.2427	.5761	.578	.4374	.2427
24	.2054	.2218	.2054	.2241	.5506	.5155	.3749
Max	.7682	.8509	1.0311	.8002	1.406	1.6221	1.0402
Min	.1638	.1715	.2054	.1448	.1254	.1227	.2054
Avg	.4151	.4485	.4854	.2757	.4301	.4152	.5597

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 201 / 11 KV Manerajuri Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8421	.8436	.8421	.8048	.3658	.2743	.3155
2	.8642	.9442	.8223	.7537	.3696	.2772	.3077
3		1.004	.8642	.7712	.3258	.2801	.3224
4	.8697	.9374	.9488	.9175	.3841	.3395	.3366
5	.9602	1.166	1.0364	1.094	.462	.4477	.4382
6	1.3279	1.4243	1.1336	1.1904	.5792	.547	.5201
7	1.5844	1.668	1.7604	1.4091	.6805	.6268	.5792
8	.543	.5068	.3887	.3772	.5068	.3961	.4557
9	.567	.4031	.3481	1.4586	1.0883	1.4815	.4252
10	.5359	.3189	.3696	1.4582	1.5223	1.5927	.362
11	.2279	.2804	.2772		1.3108	1.4083	.2835
12	.2149	.2658	.2772	1.2803	1.2929	1.4548	.2534
13	.2254	.2865	.2801	1.166	1.2125	1.4089	.2481
14	.2353	.2454	.2772	1.2483	1.3413	1.4419	.2534
15	.2103	.2658	.2829	1.3283	1.3763	1.5061	.2865
16	.2303	.3506	.3018	1.3927	1.5238	1.5364	.2835
17	.3155	.362	.3018	.3224	.3395	.3155	.3155
18	.3121	.3403	.3772	.362	.3696	.394	.4477
19	.4119	.3856	.4251	.4024	.4251	.4733	.4607
20	.4525	.4755	.4435	.4435	.4066	.4344	.5014
21	.3898	.3898	.3696	.4572	.3658	.462	.4163
22	.9282	.9602	1.0059	.4435	.3511	.394	.8322
23	.7432	.8907	.9503	.4108	.3361	.3155	.7773
24	.8192	.8097	.8951	.8192	.3982	.3018	.3012
Max	1.5844	1.668	1.7604	1.4586	1.5238	1.5927	.8322
Min	.2103	.2454	.2772	.3224	.3258	.2743	.2481
Avg	.6005	.6469	.6241	.8831	.7223	.7546	.4051

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 202 / 11 KV Yogewadi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2534	.2601	.1791	.1663	.852	.6371	.6722
2	.2743	.3077	.181	.1663	.9116	.6226	.6642
3		.2507	.1772	.1494	.9393	.6299	.679
4	.2686	.3155	.1829	.2452	.9602	.7537	.703
5	.2835	.3403	.2149	.2686	1.004	.9069	.7701
6	.3258	.3641	.2896	.3772	1.3927	1.0486	.7842
7	.3403	.4525	.3544	.3292	1.6032	1.5089	1.1174
8	.2743	.3366	.3155	.2772	.3258	.3206	.3366
9	.7287	.9717	1.0242	.2772	.3045	.2829	1.0722
10	.8322	.9962	1.0814	.2587	.3292	.2641	1.1092
11	.7773	.9602	1.1142	.2561	.2587	.2715	1.0437
12	.5937	.8951	1.1065	.2686	.2402	.2328	.9922
13	.5761	.7907	1.0486	.2715	.2218	.2534	1.0202
14	.5535	.6154	.9831	.2561	.2587	.3109	.9686
15	.5441	.6722	1.0486	.2772	.2772	.2835	1.0279
16	.5344	.8749	1.0978	.2743	.2402	.197	1.0562
17	.1433	.1696	.1848	.2534	.2587	.1991	.2103
18	.1991	.2328	.2218	.2561	.2614	.2629	.2686
19	.2126	.2303	.2587	.2402	.2641	.3086	.2835
20	.2279	.2715	.2378	.2378	.2686	.3109	.2865
21	.208	.2481	.2241	.2149	.2534	.2835	.2481
22	.1991	.2149	.2075	.8421	.8097	.8905	.2149
23	.1612	.2103	.1848	.7907	.7287	.7202	.1753
24	.2328	.2126	.1772	.1698	.8002	.6718	.6327
Max	.8322	.9962	1.1142	.8421	1.6032	1.5089	1.1174
Min	.1433	.1696	.1772	.1494	.2218	.197	.1753
Avg	.3802	.4664	.5040	.2968	.5735	.5072	.6807

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 203 / 11 KV Bhosalenagar Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1791	.1734	.1267	.132	.7202	.5571	.5556
2	.181	.1612	.1254	.1294	.759	.5376	.5281
3		.1402	.1227	.1267	.8097	.5281	.506
4	.2012	.1387	.124	.1448	.852	.5344	.5556
5	.2218	.1928	.1402	.1646	.8802	.5735	.5668
6	.2378	.2149	.1949	.197	.9393	.6226	.6226
7	.2353	.2172	.2149	.1991	1.0242	1.0227	.7655
8	.2195	.2149	.1753	.1848	.1791	.2195	.1928
9	.6722	.7186	.8288	.1848	.1991	.1848	.8907
10	.7773	.7099	.9012	.1848	.197	.1848	.8642
11	.5218	.6882	.8871		.1848	.1928	.7907
12	.5992	.7373	.779	.181	.1848	.197	.7362
13	.5937	.7116	.7537	.1646	.1848	.1448	.7459
14	.5601	.7449	.7537	.1629	.1663	.1791	.7202
15	.5281	.7362	.8551	.1612	.1595	.1772	.7611
16	.4999	.8745	.9012	.1646	.1848	.2103	.8855
17	.1296	.1433	.1848	.1791	.1848	.2454	.1772
18	.1448	.1753	.2218	.1848	.2012	.2715	.2686
19	.1417	.2172	.2402	.2012	.2012	.2507	.2658
20	.1612	.1772	.2614	.2218	.2126	.2378	.2172
21	.156	.1791	.2218	.2195	.1949	.2126	.1791
22	.1267	.1417	.1663	.7202	.8505	.6562	.1402
23	.1254	.1402	.1494	.7209	.7164	.5937	.1063
24	.1646	.1417	.1433	.128	.6802	.5668	.5668
Max	.7773	.8745	.9012	.7209	1.0242	1.0227	.8907
Min	.1254	.1387	.1227	.1267	.1595	.1448	.1063
Avg	.3208	.3621	.3947	.2199	.4528	.3792	.5254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 204 / 11 KV Manerajuri Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3258	.2957	.2587	.3772	.2507	.2534
2	.2896	.3658	.2926	.2587	.362	.2534	.2686
3		.415	.3174	.2561	.3326	.2561	.2926
4	.3292	.3881	.2987	.2561	.3395	.2957	.2801
5	.3734	.4108	.3395	.2865	.2957	.3174	.3142
6	.4435	.3982	.3734	.3582	.3174	.3086	.3658
7	.4904	.4298	.3772	.4066	.3326	.3467	.3658
8	.4668	.415	.2987	.4066	.3961	.4066	.3258
9	.4572	.3326	.5658	.4066	.3841	.3326	.2987
10	.4527	.3292	.5544	.3696	.4715	.3326	.3018
11	.4435	.2957	.2957	.3475	.462	.415	.3326
12	.3658	.2743	.2987	.3395	.4607	.439	.3734
13	.3361	.2987	.2957	.3174	.4066	.3395	.3326
14	.2172	.2957	.2957	.3361	.4066	.2957	.4108
15	.2641	.2614	.2587	.3772	.4435	.5121	.4904
16	.3696	.2218	.3326	.4435	.4607	.5068	.4481
17	.4527	.2865	.3696	.4525	.5093	.4527	.4527
18	.6154	.3258	.462	.4904	.5175	.439	.3696
19	.6653	.4024	.5544	.4854	.5487	.4854	.4904
20	.724	.5228	.6733	.4887	.6099	.4706	.6348
21	.5121	.415	.631	.5121	.5544	.5281	.4854
22	.5658	.3696	.5609	.4525	.5228	.4435	.415
23	.3326	.3361	.5068	.4527	.3395	.3734	.3734
24	.3734	.3734	.3174	.2481	.4066	.2587	.2561
Max	.724	.5228	.6733	.5121	.6099	.5281	.6348
Min	.2172	.2218	.2587	.2481	.2957	.2507	.2534
Avg	.4296	.3537	.3986	.3753	.4274	.3775	.3722

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 205 / 11 KV AG LIS Feeder

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0716		.0362	.0543	.0377	.0366
2	.0732	.0716	.0701	.0716	.0739	.0373
3	.0739	.0709	.0709	.0732	.0924	.0754
4	.0724	.0876	.0716	.0924	.0924	.0739
5	.0716	.0895	.0724	.0905	.0934	.0905
6	.0732	.0886	.0754	.0895	.0943	.0924
7	.0905	.0876	.0886	.0914	.0924	.0943
8	.0924	.0895	.0924	.0905	.0924	.0934
9	.0914	.0905	.0924	.0914	.0886	.0914
10	.0934	.0905	.0924	.0924	.0886	.0905
11	.0895	.0924	.0914	.0924	.0905	.0895
12	.0886	.0924	.0905	.0924	.0895	.0905
13	.0876	.0934	.0924	.0924	.0914	.0895
14	.0886	.0924	.0914	.0924	.0924	.0876
15	.0886	.0924	.0934	.0924	.0895	.0886
16	.0895	.0924	.0905	.0943	.0905	.0351
Max	.0934	.0934	.0934	.0943	.0943	.0943
Min	.0716	.0709	.0362	.0543	.0377	.0351
Avg	.0835	.0881	.082	.0871	.0869	.0785

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244054 / 33/11 KV MANERAJURI

Feeder No / Name : 206 / 11 kv Yogewadi Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.2033	.128	.2033	.128	.1478	.1463
2	.1646	.2263	.1307	.2033	.132	.132	.1494
3		.1646	.1294	.1848	.1494	.132	.128
4	.168	.1448	.1494	.1867	.1663	.1294	.1294
5	.1848	.168	.1867	.2075	.181	.1646	.1629
6	.181	.2195	.2829	.2481	.1886	.1949	.2263
7	.2218	.2534	.2241	.2587	.2195	.1928	.1848
8	.2075	.2218	.1509	.2957	.2587	.1848	.128
9	.1829	.2534	.4854	.4066	.3395	.3326	.3982
10	.1867	.2054	.462	.3582	.4481	.2957	.3326
11	.3475	.2452	.443		.3696	.3841	.3772
12	.3696	.1307	.3696	.1663	.3511	.3881	.3921
13	.3841	.112	.2218	.0934	.1848	.362	.1448
14	.3772	.1097	.2218	.1132	.2772	.1132	.128
15	.4024	.0924	.2033	.1463	.3696	.4251	.1867
16	.4163	.0905	.4251	.1478	.3696	.3547	.1478
17	.4024	.0905	.3696	.128	.3206	.3881	.1494
18	.4298	.1075	.4066	.132	.3582	.2534	.2641
19	.2263	.1254	.4252	.1494	.4344	.3206	.3395
20	.4024	.2195	.3506	.1698	.3658	.2561	.2957
21	.2402	.1886	.2658	.1663	.3326	.1848	.1867
22	.2241	.1478	.2328	.1698	.2829	.1698	.1478
23	.2172	.1307	.2172	.1463	.1829	.168	.1494
24	.1463	.2378	.1294	.2195	.1448	.1478	.1698
Max	.4298	.2534	.4854	.4066	.4481	.4251	.3982
Min	.1463	.0905	.128	.0934	.128	.1132	.128
Avg	.2710	.1704	.2755	.1957	.2731	.2426	.2110

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244089 / 33/11 KV WAIFALE

Feeder No / Name : 201 / 11 KV Waifale Gaonthan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.0953	.0953	.0762	.0762	.0762	.0953
2	.1715	.0953	.0953	.0762	.0762	.0762	.0953
3	.1524	.0953	.0953	.0762	.0762	.0762	.0953
4	.1524	.0953	.0953	.0762	.0762	.0762	.0953
5	.1715	.1143	.0953	.1143	.0953	.1143	.1143
6	.1905	.1334	.1524	.1524	.1334	.1715	.1715
7	.1905	.2096	.2096	.2096	.1715	.1524	.2096
8	.1905	.1524	.1715	.1334	.1143	.1143	.1524
9	.1334	.0953	.0762	.0762	.0762	.0953	.1143
10	.1334	.1143	.0762	.0762	.0762	.0953	.0953
11	.1143	.1143	.0762	.0572	.0762	.0953	.0953
12	.0953	.1143	.0572	.0572	.0762	.0762	.0953
13	.0953	.1143	.0572	.0572	.0762	.0762	.0762
14	.0953	.0572	.0572	.0572	.0572	.0762	.0572
15	.0762	.0572	.0572	.0572	.0762	.0762	.0572
16	.0572	.0572	.0572	.0572	.0762	.0762	.0572
17	.0762	.0762		.0572	.0762	.0762	.0953
18	.0953	.0762	.0572	.0953	.1143	.0953	.1143
19	.1334	.1143	.1143	.1524	.1524	.1524	.1334
20	.1334	.1143	.1905	.1715	.1715	.1524	.1334
21	.1334	.1143	.1524	.1334	.1334	.1334	.1524
22	.0953	.0953	.1143	.1143	.1143	.1143	.1524
23	.0953	.0953	.0953	.0953	.0953	.0953	.1524
24	.1524	.0953	.0953	.0762	.0762	.0762	.0953
Max	.1905	.2096	.2096	.2096	.1715	.1715	.2096
Min	.0572	.0572	.0572	.0572	.0572	.0762	.0572
Avg	.1286	.1040	.1019	.0961	.0976	.1008	.1127

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244089 / 33/11 KV WAIFALE

Feeder No / Name : 202 / 11 KV Waifale Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6535	.4382	.463	.3881	.0953	.1143	.1143
2	.6535	.4382	.463	.3881	.0953	.1143	.1143
3	.6401	.4382	.4733	.3881	.0953	.1143	.1143
4	.6401	.4382	.4578	.3881	.0953	.1143	.1143
5	.6935	.4908	.57	.5175	.1524	.1905	.1905
6	.7802	.583	.7545	.7133	.3429	.362	.3511
7	1.0288	.9945	.964	.8238	.381	.381	.3511
8	1.0288	.3048	.2477	.2096	.2477	.2286	.2096
9	.1524	.1524	.1334	.6626	.7421	.6859	.1524
10	.0953	.1143	.1143	.7059	.7783	.6516	.1143
11	.1143	.1143	.0953	.724	.7964	.6001	.0953
12	.1143	.1143	.0953	.8326	.7783	.5935	.0953
13	.1143	.1143	.0953	.7964	.7602	.6706	.0953
14	.0953	.0953	.1143	.7783	.724	.6706	.0953
15	.0953	.0953	.1143	.7602	.7602	.663	.0953
16	.1143	.0762	.1143	.7522	.8059	.7293	.1143
17	.1334	.1334	.1143	.1334	.1334	.1524	
18	.1524	.1334	.1524	.1715	.1524	.1905	
19	.2096	.1524	.1715	.1905	.2286	.2667	
20	.2096	.1905	.2286	.2096	.2096	.2667	
21	.1905	.2096	.1905	.1715	.1715	.1905	.3429
22	.4801	.5144	.567	.1334	.1524	.1715	.4115
23	.4382	.5144	.5121	.1143	.1334	.1334	.4161
24	.6001	.4382	.463	.3841	.0953	.1143	.1143
Max	1.0288	.9945	.964	.8326	.8059	.7293	.4161
Min	.0953	.0762	.0953	.1143	.0953	.1143	.0953
Avg	.3928	.3037	.3196	.4724	.3720	.3487	.1851

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244089 / 33/11 KV WAIFALE

Feeder No / Name : 203 / 11 KV Biranwadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1524	.1905	.1524	1.1765	1.0136	1.0059
2	.1905	.1524	.1905	.1524	1.1765	1.0136	1.0059
3	.1905	.1524	.1905	.1524	1.1765	1.0136	1.0059
4	.1905	.1524	.1905	.1524	1.2536	1.0136	.9945
5	.2286	.1905	.1905	.2667	1.3672	1.2346	1.1603
6	.3048	.3429	.2667	.4191	1.5261	1.6385	1.326
7	.4954	.4572	.4572	.4572	1.7736	1.7976	1.4403
8	.381	.3239	.3239	.3048	.3429	.3239	.362
9	.9328	1.1401	1.3717	.1715	.2667	.2286	1.4251
10	.9328	1.1888	1.3169	.1715	.2286	.1905	1.3117
11	.8648	1.2136	1.2986	.1524	.1524	.1715	1.6057
12	.8817	1.1523	1.3717	.1524	.1524	.1715	1.0059
13	.8383	1.0802	1.3535	.1524	.1334	.1715	1.0059
14	.8383	1.0974	1.3352	.1905	.1334	.1524	1.2003
15	.8322	1.1269	1.3535	.2096	.1334	.1524	1.6278
16	.9282	1.2883	1.3169	.1524	.1334	.1524	1.5604
17	.1905	.1715	.1715	.1334	.1715	.1524	.1905
18	.2286	.1715	.2096	.1715	.1905	.1905	.2286
19	.2858	.1905	.2477	.2096	.3048	.3429	.2667
20	.2858	.1905	.3239	.2667	.3429	.3239	.3048
21	.2477	.2477	.2667	.2667	.2477	.2477	.2286
22	.1715	.1905	.1905	1.2536	1.1283	1.0898	.2286
23	.1524	.1905	.1715	1.267	1.086	1.0059	.2667
24	.1905	.1524	.1905	.1524	1.1765	1.0136	1.0059
Max	.9328	1.2883	1.3717	1.267	1.7736	1.7976	1.6278
Min	.1524	.1524	.1715	.1334	.1334	.1524	.1905
Avg	.4572	.5299	.6038	.2971	.6573	.6169	.9068

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244089 / 33/11 KV WAIFALE

Feeder No / Name : 204 / 11 KV Agrani agro express NON SHEDDABLE EXPRESS HV FEEDERS
fdr Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	02-SEP-17
HR	Load (MW)
22	.0019
Max	.0019
Min	.0019
Avg	.0019

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244108 / 33/11 KV Koulage

Feeder No / Name : 201 / 11 KV Savarde Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1646	.3521	.2643	.2	.1132	.1509	.1509
2	.1646	.3563	.2643	.1867	.1132	.1478	.1698
3		.3563	.2503	.1867	.1132	.1494	.1509
4	.2256	.3681	.2503	.2134	.132	.2075	.1509
5	.2972	.3749	.2503	.2469	.1698	.2427	.1698
6	.3437	.3858	.3864	.3549	.2641	.2829	.2641
7	.6562	.7282	.7385	.4548	.3018	.3206	.3142
8	.2427	.2614	.2054	.2075	.2054	.2587	.2614
9	.1867	.1848	.2054	.4287	.6015	.6081	.2054
10	.1494	.1294	.2033	.4512	.5216	.6081	.2054
11	.1294	.1478	.1663	.3788	.5201	.6081	.2054
12	.1086	.1433	.1646	.3018	.3978	.5716	.2054
13	.128	.1448	.2033	.3155	.4527	.5216	.1867
14	.1109	.1448	.1646	.3755	.4464	.5075	.2054
15	.0924	.1097	.1646	.3948	.4934	.6081	.2054
16	.1097	.1448	.1646	.5075	.5357	.6802	.2241
17	.1307	.1478	.1448	.2033	.1991	.1867	.2427
18	.1494	.2054	.1646	.2218	.2172	.2614	.2801
19	.1848	.2054	.2587	.2614	.2614	.2427	.2614
20	.2218	.2241	.2427	.2263	.1886	.2241	.2427
21	.2054	.2054	.2054	.1867	.1886	.1886	.2054
22	.2961	.4001	.3125	.1698	.168	.1698	.3475
23	.3144	.3199	.2812	.132	.1494	.1509	.3185
24	.1974	.3725	.2782	.2134	.1132	.1509	.1509
Max	.6562	.7282	.7385	.5075	.6015	.6802	.3475
Min	.0924	.1097	.1448	.132	.1132	.1478	.1509
Avg	.2091	.2672	.2473	.2841	.2861	.3354	.2219

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244108 / 33/11 KV Koulage

Feeder No / Name : 202 / 11 KV Khujgaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	31-AUG-17	01-SEP-17	02-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.3201	.1254
2		.2934	.1075
3		.2934	.1075
4		.3246	.1254
5		.3567	.1448
6		.4607	.2033
7		.6602	.2614
8		.2241	.2378
9		.643	.8253
10		.3517	
11		.6222	
12	.116	.6763	
13	.1326	.6089	
14	.1417	.5601	
15	.1448	.6722	
16	.1478	.7335	
17	.1254	.1017	
18	.1595	.1254	
19	.2012	.2012	
20	.2218	.1848	
21	.2195	.1848	
22	.4652	.168	
23	.3978	.1478	
24		.3517	.1254
Max	.4652	.7335	.8253
Min	.116	.1017	.1075
Avg	.2061	.3861	.2264

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244125 / 33/11 KV ANJANI (NAGEWADI)

Feeder No / Name : 201 / 11 kv Vadgaon Ag

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0572	.0762	.0943	.3201	.2812	.4801
2	.0566	.0572	.0762	.0943	.3201	.25	.4801
3	.0566	.0572	.0762	.0943	.3048	.2561	.4801
4	.0566	.0953	.0762	.1132	.3395	.2881	.506
5	.0943	.1524	.1905	.1509	.4744	.3887	.5535
6	.2263	.2286	.3395	.2263	.6802	.663	.6167
7	.3206	.2477	.3109	.3206	.5304	1.2631	.8745
8	.2263	.1905	.2075	.2263	.1886	.2075	.2263
9	.3658	.4428	.6097	.132	.1132	.1509	.8488
10	.3913	.4321	.602	.1509	.112	.1698	.9804
11	.3668	.421	.5721	.1132	.0747	.1509	.8688
12	.3475	.4588	.4755	.0953	.0924	.1132	.8535
13	.3227	.4534	.602	.0943	.0914	.0754	.5418
14	.1806	.4752	.5556	.0943	.0934	.0747	.7526
15	.2572	.4687	.7011	.0754	.112	.112	.7011
16	.2378	.4012	.5868	.0943	.112	.1132	.5647
17	.0934	.1097	.0732	.112	.1663	.1132	.0934
18	.132	.0924	.1109	.1509	.1867	.1867	.1132
19	.1698	.1307	.1886	.1886	.1698	.1886	.1698
20	.1509	.1886	.1698	.1886	.1886	.2263	.1698
21	.1143	.1509	.1509	.1698	.1509	.1886	.1524
22	.0953	.1132	.132	.4999	.4999	.5312	.132
23	.0762	.0953	.1132	.3906	.3549	.506	.1132
24	.0566	.0572	.0762	.0943	.3549	.3048	.4744
Max	.3913	.4752	.7011	.4999	.6802	1.2631	.9804
Min	.0566	.0572	.0732	.0754	.0747	.0747	.0934
Avg	.1855	.2324	.2947	.1652	.2513	.2835	.4895

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244125 / 33/11 KV ANJANI (NAGEWADI)

Feeder No / Name : 202 / 11KV Anjani Vadgaon

GAOTHAN FEEDER

Gaothan Feeder KV- 11 /
OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1905	.1698	.1886	.1886	.1698	.2075
2	.1509	.1905	.1509	.1886	.1886	.1698	.1886
3	.1509	.1905	.1509	.1886	.1886	.1698	.1886
4	.1509	.2286	.1509	.2263	.2075	.1698	.2263
5	.2263	.3429	.3206	.3018	.3206	.2263	.3395
6	.4527	.4763	.4904	.4715	.4715	.4527	.4904
7	.5093	.4904	.4527	.415	.3239	.4338	.4527
8	.3584	.3018	.3174	.2829	.2096	.2987	.3018
9	.2241	.2587	.2033	.2218	.0572	.2587	.3109
10	.1509	.1646	.1478	.1478	.168	.2054	.132
11	.1612	.1478	.1463	.1463	.181	.2012	.1663
12	.1646	.1463	.1478	.1646	.2033	.1848	.1646
13	.1663	.1448	.1494	.1646	.1848	.132	.1509
14	.1646	.1646	.168	.1848	.1848	.1509	.1848
15	.1463	.1867	.1867	.1663	.168	.1509	.2054
16	.1629	.1848	.1867	.181	.1829	.1848	.2172
17	.1848	.2054	.1886	.168	.2012	.2218	.2218
18	.1886	.2241	.2033	.2033	.2195	.2507	.2743
19	.3921	.2241	.3174	.3584	.4024	.3881	.3881
20	.4338	.4668	.3772	.4481	.4481	.3961	.4108
21	.3961	.3772	.3395	.3961	.3961	.3772	.3772
22	.2641	.2263	.3018	.3018	.3206	.3206	.3395
23	.2096	.1886	.2263	.2452	.2452	.2641	.2641
24	.1886	.1905	.1886	.1886	.2075	.2096	.2263
Max	.5093	.4904	.4904	.4715	.4715	.4527	.4904
Min	.1463	.1448	.1463	.1463	.0572	.132	.132
Avg	.2395	.2464	.2368	.2479	.2446	.2495	.2679

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244125 / 33/11 KV ANJANI (NAGEWADI)

Feeder No / Name : 203 / 11 KV Gavan Ag

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4214	.3612	.4191	.6009	.0754	.0754	.0943
2	.3913	.3612	.4191	.6009	.0754	.0754	.0943
3	.381	.3612	.4191	.6154	.0754	.0754	.0943
4	.3963	.3963	.4144	.6478	.0943	.0754	.132
5	.4687	.506	.6554	.6882	.1509	.1132	.1698
6	.6802	.7701	.9831	.7701	.2263	.2263	.2452
7	1.1797	1.2146	1.2944	.9717	.2263	.2452	.2641
8	.1867	.1509	.1698	.112	.1494	.2075	.2241
9	.1294	.128	.1086	.9804	1.1174	1.7976	.2033
10	.1097	.1294	.0905	1.2809	1.5384	1.9006	.2054
11	.1294	.128	.0693	1.1717	1.4575	1.6164	.1867
12	.1097	.128	.0724	1.1265	1.3923	1.4403	
13	.1109	.1478	.0724	1.1092	1.4706	1.2803	.1075
14	.0924	.128	.0732	1.1248	1.4074	1.6032	.168
15	.0701	.0914	.0739	1.2018	1.3125	1.7444	.1848
16	.1227	.1097	.0747	1.1265	1.2967	1.7814	.1494
17	.0905	.1075		.1294	.0924	.2012	.1494
18	.1267	.1075	.1267	.1097	.1307	.1478	.1698
19	.1848	.1097	.1307	.132	.1494	.1478	.2054
20	.1494	.2218	.168	.1509	.1698	.1886	.132
21	.132	.1494	.132	.1509	.1509	.1698	.112
22	.5401	.5868	.7842	.112	.132	.132	.953
23	.4515	.5868	.7186	.0934	.0943	.1132	.8749
24	.4458	.3913	.503	.6249	.0754	.0934	.0943
Max	1.1797	1.2146	1.2944	1.2809	1.5384	1.9006	.953
Min	.0701	.0914	.0693	.0934	.0754	.0754	.0943
Avg	.2959	.3072	.3466	.6513	.5442	.6438	.2267

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244133 / 33/11 KV Manjarde Stn

Feeder No / Name : 201 / 11 KV DATTANAGAR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.0754	.0943	.1932	.2054	.2429
2	.0754	.0754	.0754	.0943	.1858	.1783	.2195
3	.0754	.0754	.0754	.0943	.2201	.1829	.2195
4	.0754	.1132	.0943	.0943	.2709	.2187	.2462
5	.1132	.1886	.132	.0943	.3241	.3841	.2896
6	.1509		.1698	.2075	.3858	.5121	.4321
7	.2075	.1886	.2427	.2452	.6321	.7316	.5281
8	.2075	.1886	.168	.1509	.1698	.1663	.168
9		.4064	.3961	.0934	.132	.1132	.4778
10		.3185	.3477	.0747	.0724	.0924	.423
11	.0377	.2397	.3807	.056	.0566	.0739	.423
12	.1463	.2679	.3477	.0554	.0554	.056	.4287
13	.2858	.2705	.3201	.0549	.0549	.056	.4451
14	.2439	.3111	.3384	.0549	.0549	.0554	.459
15	.286	.2921	.3384	.056	.0549	.0554	.4311
16	.2896	.3018	.3368	.056	.0739	.0549	.4212
17	.0732	.0724	.0549		.0739	.0554	.0732
18	.1097	.0732	.0747	.0924	.1132	.0747	
19	.1646	.1307	.1132	.1494	.1509	.1509	.1307
20	.1463	.1334	.1698	.1886	.1698	.1509	.1509
21	.1463	.1334	.1509	.1509	.1698	.1509	.1509
22	.1132	.1143	.132	.3704	.3593	.3506	.1132
23	.1132	.0943	.0943	.2709	.3125	.2934	.1132
24	.0754	.0716	.0754	.0943	.2054	.2054	.2934
Max	.2896	.4064	.3961	.3704	.6321	.7316	.5281
Min	.0377	.0716	.0549	.0549	.0549	.0549	.0732
Avg	.1460	.1798	.1960	.1258	.1872	.1904	.2991

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244133 / 33/11 KV Manjarde Stn

Feeder No / Name : 202 / 11 KV GOURGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1585	.2	.176	.2008	.0716	.0739	.0549
2	.176	.1867	.176	.1943	.0732	.0554	.0543
3	.168	.168	.176	.1976	.0732	.056	.0543
4	.1734	.1635	.2042	.1772	.0914	.0934	.0549
5	.1915	.2378	.2073	.2353	.1267	.1132	.0739
6	.1943	.286	.2435	.2761	.1294	.1509	.112
7	.3894	.3612	.4401	.3829	.1478	.1509	.1629
8	.1478	.1307	.0905	.0934	.128	.1294	.1307
9	.0867	.0934	.0895	.4033	.4172	.4172	.0724
10	.0701	.0739	.0716	.3734	.4329	.4287	.1109
11	.0739	.0709	.1086	.3681	.4252	.4729	.0905
12	.0739	.0701	.0886	.3944	.4075	.4801	.0724
13	.0739	.0693	.0648	.3887	.3734	.4534	.0857
14	.0429	.0678	.0693	.439	.3734	.4793	.1097
15	.0714	.0526	.0532	.459	.3788	.5201	.0895
16	.0714	.0648	.08	.4193	.3652	.5182	.0995
17	.1086	.0709	.0686	.0678	.0486	.0503	.0743
18	.1086	.0709	.0701	.0693	.064	.0701	.0633
19	.1086	.1109	.1109	.1109	.1109	.1109	.1097
20	.128	.1132	.1294	.128	.1109	.112	.1294
21	.1463	.112	.1097	.1109	.112	.112	.112
22	.2572	.2364	.2934	.0934	.0943	.0934	.2858
23	.2572	.2134	.2389	.0732	.0943	.0739	.2538
24	.1858	.2286	.2012	.2298	.0716	.0739	.0739
Max	.3894	.3612	.4401	.459	.4329	.5201	.2858
Min	.0429	.0526	.0532	.0678	.0486	.0503	.0543
Avg	.1443	.1439	.1484	.2453	.1967	.2204	.1054

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244133 / 33/11 KV Manjarde Stn

Feeder No / Name : 203 / 11 KV MANJARDE VILLAGE

Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0566	.0754	.0572
2		.0566	.0566	.0572
3		.0754	.0566	.0572
4		.0943	.0754	.0572
5		.0943	.0943	.0943
6		.132	.132	.1509
7		.1509	.1494	.1509
8		.112	.1132	.0566
9		.0549	.0924	.0351
10		.037	.0554	.0537
11		.0554	.0543	.0543
12		.0554	.0183	.0543
13		.056	.0366	.0549
14		.056	.0543	.0554
15		.056	.056	.056
16		.0554	.0554	.0549
17	.0867	.0543	.0709	.0549
18	.0895	.0739	.0724	.0905
19	.1494	.1132	.1294	.1478
20	.1663	.1509	.1494	.1478
21	.132	.132	.1494	.132
22	.1132	.1132	.1132	.1132
23	.0754	.0943	.0762	.0953
24		.0566	.0754	.0762
Max	.1663	.1509	.1494	.1509
Min	.0754	.037	.0183	.0351
Avg	.1161	.0828	.0838	.0816

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244139 / 33/11KV Jarandi

Feeder No / Name : 201 / 11 KV Jarandi Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.1097	.1075	.1097	.128	.1509	.132
2	.1097	.1086	.1075	.1097	.1294	.1509	.1509
3	.1097	.1109	.1086	.1097	.1294	.1509	.112
4	.1109	.1097	.1086	.1097	.1294	.1509	.1509
5	.1307	.1463	.1595	.1494	.1294	.1698	.1698
6	.168	.2452	.2075	.2452	.2452	.2263	.2075
7	.3018	.3395	.3395	.3206	.3206	.3018	.3206
8	.2829	.2829	.2641	.2641	.2641	.2641	.1886
9	.1886	.1886	.2263	.1886	.1886	.2263	.168
10	.1886	.1886	.1698	.1867	.2075	.132	.1886
11	.1663	.1886	.132	.1509	.1132	.1132	.1509
12	.1829	.1698	.1132	.168	.112	.0943	.132
13	.1829	.1132	.1132	.1509	.1509	.0754	.132
14	.181	.1494	.1132	.168	.1494	.0943	.1132
15	.2149	.1494	.1132	.1867	.1698	.0566	.1509
16	.2172	.132	.1132	.1663	.1509	.1132	.1494
17	.2172	.1494	.1132	.1991	.1494	.128	.1494
18	.2195	.132	.132	.1848	.168	.1478	.168
19	.2263	.1886	.1698	.2241	.2263	.168	.1886
20	.2075	.1698	.1886	.2452	.2641	.2452	.2075
21	.1886	.1698	.1698	.1886	.2075	.2263	.2075
22	.1478	.1478	.1494	.1698	.1886	.2054	.1698
23	.1097	.1307	.1086	.1494	.1698	.1848	.1698
24	.1097	.1097	.1075	.1097	.128	.1509	.168
Max	.3018	.3395	.3395	.3206	.3206	.3018	.3206
Min	.1097	.1086	.1075	.1097	.112	.0566	.112
Avg	.1780	.1638	.1515	.1773	.1758	.1636	.1686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244139 / 33/11KV Jarandi

Feeder No / Name : 202 / 11 KV Jarandi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1947	.282	.2782	.0716	.0754	.0943	.0934
2	.1947	.2896	.2782	.0701	.0754	.0943	.1132
3	.1947	.2896	.2782	.0701	.0754	.0943	.132
4	.1974	.282	.2782	.0701	.0754	.0943	.1494
5	.2378	.282	.3429	.1433	.1132	.1698	.1698
6	.3163	.3321	.506	.1848	.1886	.1886	.1698
7	.6009	.6478	.8539	.2686	.2452	.2452	.2075
8	.1867	.1886	.1698	.1097	.1509	.1698	.132
9	.1227	.1132	.1132	.6173	.6249	.6171	.112
10	.0895	.1132	.0754	.5639	.6539	.5944	.0754
11	.0732	.0943	.0554	.4108	.5868	.6249	.0747
12	.0914	.1387	.0554	.4572	.5287	.6327	.0739
13	.0554	.1052	.0554	.5216	.5007	.7122	.0537
14	.0554	.0554	.0747	.4793	.3616	.7373	.0549
15	.0354	.0739	.056	.5502	.5216	.7716	.0366
16	.0543	.0714	.056	.578	.5702	.7164	.0537
17	.0747	.1461	.0754	.056	.1294	.1132	.0549
18	.112	.0934	.1097	.0739	.132	.132	.0747
19	.1886	.1509	.1698	.1509	.1509	.1509	.1509
20	.1886	.1509	.1509	.1698	.1698	.168	.132
21	.1509	.132	.132	.1509	.132	.132	.1132
22	.3658	.4268	.1075	.0943	.1132	.0943	.2408
23	.3001	.3086	.0709	.0754	.1132	.0943	.2286
24	.1947	.282	.2782	.1052	.0754	.0943	.0747
Max	.6009	.6478	.8539	.6173	.6539	.7716	.2408
Min	.0354	.0554	.0554	.056	.0754	.0943	.0366
Avg	.1782	.2104	.1926	.2518	.2652	.3140	.1155

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

SAVLAJ S/DN.[789]

BU 4789

Substation No/ Name :- 244139 / 33/11KV Jarandi

Feeder No / Name : 203 / 11 KV Dahiwadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0739		.0747	.0566	.2641	.2143	.2721
2	.0739		.0747	.0566	.2641	.2143	.2846
3	.0739		.0747	.0566	.2641	.2143	.2896
4	.0739		.0747	.0754	.2641	.2143	.3395
5	.132		.1132	.1132	.2824	.282	.3749
6	.1698		.1886	.1698	.3913	.4696	.3163
7	.2075		.1886	.2075	.6097	.7042	.4475
8	.1294		.1867	.1509	.1494	.1478	.1494
9	.2526		.3506	.0934	.0943	.0747	.2401
10	.2641		.3567	.0549	.112	.056	.3506
11	.2606		.2429	.0905	.0914	.0373	.381
12	.2503	.3121	.3185	.0739	.0549	.0566	.4115
13	.2538	.4054	.362	.0724	.0895	.0739	.3269
14	.282	.282	.3814	.0566	.0543	.0934	.3668
15	.2858	.3384	.4214	.0732	.0716	.0566	.4515
16	.2364	.3477	.4012	.0905	.0724	.0724	.4115
17	.0537	.1	.0716	.0867	.0709	.0934	.0716
18	.0739	.0724	.0549	.0747	.1097	.112	.1097
19	.1109	.1132	.0934	.1307	.1307	.1307	.112
20	.1097	.132	.1132	.132	.1109	.132	.1132
21	.1132	.1075	.0943	.0943	.1132	.0934	.0934
22	.0943	.0943	.0754	.286	.3593	.2058	.0747
23	.0732	.0747	.0566	.2824	.3506	.2347	.0747
24	.0739	.0732	.0747	.0566	.2641	.2143	.2591
Max	.2858	.4054	.4214	.286	.6097	.7042	.4515
Min	.0537	.0724	.0549	.0549	.0543	.0373	.0716
Avg	.1551	.1887	.1852	.1098	.1933	.1749	.2634

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 201 / 11 KV KUMTHE NAGAON

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /

OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2033	.3239	.1886	.2075	.2075	.3048
2	.1886	.2054	.3048	.1867	.2054	.2075	.3048
3	.1886	.2075	.3048	.1886	.2033	.2263	.2858
4	.1886	.2075	.3239	.1905	.2054	.2263	.2858
5	.2452	.2452	.3239	.1886	.2263	.2452	.2667
6	.3395	.2801	.3429	.2195	.2641	.2641	.2667
7	.2987	.3048	.3429	.2587	.2987	.2641	.2667
8	.2858	.2667	.3048	.2378	.2772	.2286	.2477
9	.2263	.1905	.2126	.2054	.2075	.2477	.1905
10	.1829	.1928	.1715	.1509	.1715	.1886	.132
11	.1663	.1905	.1715	.132	.1715	.1463	.1463
12	.112	.1524	.0762	.156	.1715	.1267	.1478
13	.1132	.1524	.1334	.1402	.1524	.1463	.1698
14	.1097	.1524	.1143	.1214	.1524	.1629	.1663
15	.1267	.1334	.1334	.132	.1524	.1663	.1646
16	.1307	.1334	.1524	.1509	.1017	.1646	.1698
17	.1848	.1715	.1509	.1509	.1698	.2286	.132
18	.1949	.1905	.1867	.1867	.2096	.2286	.2534
19	.3292	.2286	.2587	.2587	.2667	.2667	.3292
20	.3511	.3048	.2801	.2896	.3429	.3239	.3658
21	.3018	.3429	.2561	.2987	.2858	.3429	.3292
22	.2353	.3429	.2587	.2587	.2641	.3429	.2865
23	.2012	.3239	.2241	.2452	.2263	.3239	.2477
24	.1886	.2012	.3239	.1886	.2054	.2075	.3239
Max	.3511	.3429	.3429	.2987	.3429	.3429	.3658
Min	.1097	.1334	.0762	.1214	.1017	.1267	.132
Avg	.2116	.2219	.2365	.1969	.2141	.2285	.2410

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 204 / 11 KV Kumthe Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4858	.5312	.7499	.3814	.1886	.1715	.2667
2	.4915	.4902	.8749	.3612	.1848	.1524	.2477
3	.4858	.4961	.8642	.3567	.1848	.1524	.2477
4	.4801	.4843	.9259	.3475	.1886	.1524	.2477
5	.5864	.4784	.9602	.3429	.2241	.1886	.2667
6	.6859	.5719	.9907	.5796	.2452	.2263	.2667
7	.8025	1.1336	1.0722	.6773	.2587	.2452	.2667
8	.2286	.2286	.2286	.2241	.2829	.2286	.2667
9	.2096	.1905	.2286	.8802	1.0145	1.1443	.2286
10	.1848	.1524	.1715	.8579	1.2003	1.0717	.1509
11	.1494	.1524	.1524	.1142	1.1385	.9991	.1463
12	.132	.1524	.1524	1.0212	1.1888	.8859	.1663
13	.1307	.1524	.1334	1.0059	1.1498	1.0136	.1698
14	.1294	.1524	.1334	1.1431	1.1405	1.0987	.168
15	.132	.1524	.1524	1.0212	1.0802	1.0848	.1698
16	.132	.1524	.1524	1.0402	1.0837	1.1003	.168
17	.1494	.1715	.1698	.1334	.1715	.1494	.1829
18	.1905	.1715	.1867	.168	.1524	.1905	.1905
19	.2477	.2096	.2452	.2033	.2096	.2096	.2667
20	.2477	.2286	.2587	.2378	.2477	.2477	.2667
21	.2096	.2286	.2829	.2353	.2477	.2667	.2477
22	.6636	.6009	.4755	.2195	.2286	.2667	.9633
23	.5792	.6944	.4666	.2075	.1715	.2667	.7926
24	.4801	.5556	.7682	.4365	.1867	.1715	.2667
Max	.8025	1.1336	1.0722	1.1431	1.2003	1.1443	.9633
Min	.1294	.1524	.1334	.1142	.1524	.1494	.1463
Avg	.3423	.3555	.4499	.5082	.5154	.4869	.2759

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 206 / 11 KV Upalavi Matkunki Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.112	.1524	.1143	.6097	.7042	.7343
2	.1132	.1132	.1715	.1132	.6097	.6802	.7116
3	.1132	.1132	.1715	.1132	.6249	.6882	.7011
4	.132	.1132	.1905	.1143	.6173	.7202	.6718
5	.1698	.1509	.1905	.1509	.6472	.7748	.7407
6	.2075	.1886	.2096	.1886	.8109	.8592	.7621
7	.2452	.2075	.2096	.2614	1.2289	1.0648	.8688
8	.1886	.1698	.1886	.1663	.1698	.1494	.2054
9	.7316	.6859	.6241	.1478	.1509	.197	1.0957
10	.8429	.7922	.7407	.128	.1886		
11	.8322	.8905	.945	.1478	.1848	.1848	1.2193
12	.8977	.953	1.0822	.128	.168	.181	1.1736
13	.9031	.9374	1.0136	.128	.1629	.1663	1.1717
14	.8916	.953	.9783	.1097	.1417	.1463	1.2323
15	.7621	.9842	1.0686	.1097	.1478	.1509	1.278
16	.6805	.4843	.9633	.1478	.128	.1829	1.2029
17	.0943	.0937	.1132	.1494	.1294	.1509	.132
18	.1063	.0937	.112	.1663	.1254	.1698	.2054
19	.168	.0937	.1509	.2033	.1698	.1663	.2075
20	.1867	.1094	.1509	.1848	.1509	.1829	.2075
21	.1509	.1094	.1509	.1646	.1334	.1886	.1509
22	.132	.1334	.1307	.6895	.8436	.6562	.1698
23	.112	.1524	.1132	.6923	.7907	.6718	.132
24	.1132	.1132	.1524	.1132	.6539	.7362	.7522
Max	.9031	.9842	1.0822	.6923	1.2289	1.0648	1.278
Min	.0943	.0937	.112	.1097	.1254	.1463	.132
Avg	.3703	.3645	.4156	.1930	.3995	.4249	.6838

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 207 / Nagaon Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.2801	.3506	.2641	.2957	.2926	.3696
2	.2378	.2614	.3155	.2801	.2772	.2743	.3155
3	.2402	.2641	.3121	.2641	.2801	.2587	.3155
4	.2587	.2641	.2774	.2587	.2772	.2614	.2947
5	.2957	.2801	.2743	.2801	.2926	.2801	.2947
6	.3547	.2957	.3429	.3109	.3174	.2957	.3258
7	.3511	.3326	.3544	.3326	.3772	.2957	.3326
8	.2957	.2957	.3174	.2561	.2614	.2218	.2957
9	.2402	.2587	.2743	.2587	.2378	.2218	.2378
10	.2263	.2587	.2402	.2614	.2715	.1829	.2075
11	.2195	.2218	.2402	.2218	.2629	.181	.1829
12	.1867	.2218	.2033	.2587	.2454	.1646	.1629
13	.1886	.2218	.2033	.2587	.2481	.1848	.1663
14	.1867	.2218	.2033	.2402	.2303	.2012	.1646
15	.2195	.2402	.2033	.2402	.2353	.2218	.1991
16	.2263	.2587	.2402	.2561	.2454	.2561	.1867
17	.2075	.2957	.2801	.2743	.2561	.2402	.2772
18	.2926	.3326	.3475	.3734	.2561	.3012	.3326
19	.4024	.3696	.3881	.4805	.4207	.3511	.4572
20	.4251	.4066	.439	.4755	.439	.4024	.4755
21	.3841	.462	.4066	.4755	.3511	.4668	.4251
22	.3475	.4298	.3734	.4066	.3475	.4294	.3881
23	.2772	.4024	.3395	.3658	.3109	.3696	.2782
24	.2561	.2772	.3544	.2801	.3258	.3109	.3696
Max	.4251	.462	.439	.4805	.439	.4668	.4755
Min	.1867	.2218	.2033	.2218	.2303	.1646	.1629
Avg	.2740	.2981	.3034	.3073	.2943	.2778	.2940

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244020 / 33/11 KV KUMTHE

Feeder No / Name : 208 / Nagaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4344	.2435	.3765	.3429	.0566	.0537	.0857
2	.4108	.2364	.4054	.3567	.056	.0543	.0848
3	.4108	.2286	.4001	.3612	.0566	.0543	.1017
4	.431	.2201	.4287	.3658	.056	.0554	.0995
5	.4841	.2286	.4401	.3763	.0554	.0554	.0995
6	.5357	.2267	.4548	.4725	.0754	.0549	.0949
7	.5792	.4694	.4489	.578	.1132	.0532	.0914
8	.0617	.0537	.0526	.0943	.1132	.0537	.0848
9	.0625	.0351	.0452	.7074	.8655	.6344	.0857
10	.0566	.0554	.0693	.8025	1.0185	.7335	.1132
11	.056	.044	.0543	.873	.9804	.8688	.1109
12	.0554	.0587	.0486	.7529	.9145	1.0059	.1097
13	.0566	.044	.0423	.7775	.9105	.9412	.1097
14	.0554	.044	.0339	.8322		.9288	.1109
15	.056	.044	.0509	.8322	.8398	.9808	.0924
16	.0566	.044	.0343	.8128	.7727	.9976	.1307
17	.056	.044	.0566	.0474	.0602	.0754	.0924
18	.0316	.044	.056	.056	.0663	.0701	.0848
19	.0532	.0587	.0747	.0739	.0503	.0739	.0905
20	.0532	.0587	.0747	.0754	.0532	.0709	.0905
21	.0509	.0587	.0754	.056	.0537	.0724	.0724
22	.3199	.2503	.3814	.056	.0537	.0709	.3243
23	.2629	.2606	.3763	.0566	.0537	.0701	.3163
24	.4287	.2705	.2976	.362	.0572	.0537	.0857
Max	.5792	.4694	.4548	.873	1.0185	1.0059	.3243
Min	.0316	.0351	.0339	.0474	.0503	.0532	.0724
Avg	.2108	.1384	.1991	.4217	.3188	.3368	.1151

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 201 / 11 KV PED AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.9282						
10							.1029
11			.0905				.0857
12			.0983				.0857
13			.1132				
14					1.3413		
15					1.387		
18					.128		
19							.1029
20					.1448		.12
21							.12
22					.1307		1.2041
23							1.1288
24	.6299	.6401	.6805	.6287		.112	.1132
Max	.9282	.6401	.6805	.6287	1.387	.112	1.2041
Min	.6299	.6401	.0905	.6287	.128	.112	.0857
Avg	.7791	.6401	.2456	.6287	.6264	.112	.3404

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 202 / 11 KV HATNUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10							.5944
11			.6661				.7133
12			.6516				
14			.6371				
15					.0724		
18					.112		
19							.1204
20					.1494		.1355
21							.0903
22					.6249		.0903
23							.0903
24	.0762	.112	.0857	.0754	.3864	.4401	.3858
Max	.0762	.112	.6661	.0754	.6249	.4401	.7133
Min	.0762	.112	.0857	.0754	.0724	.4401	.0903
Avg	.0762	.112	.5101	.0754	.2690	.4401	.2775

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 204 / 11KV HATNUR GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.2241						
10							.0934
11			.1267				.1494
12			.1267				
13			.1267				
14					.1294		
15					.0924		
18					.1448		
19							.3361
20					.3511		.3547
21							.3174
22					.2452		.2614
23							.2241
24	.1867	.1715	.1698	.1698	.1698	.1715	.1698
Max	.2241	.1715	.1698	.1698	.3511	.1715	.3547
Min	.1867	.1715	.1267	.1698	.0924	.1715	.0934
Avg	.2054	.1715	.1375	.1698	.1888	.1715	.2383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 206 / 11 KV PED GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0566		
8	.1478						
10							.0549
11			.037				.0549
12			.037				.0549
13			.037				
14					.056		
15					.0566		
18					.0701		
19							.1463
20					.0732		.128
21							.0732
22					.0943		.0732
23							.0549
24	.0739	.0572	.0377	.1892		.0377	.0762
Max	.1478	.0572	.0377	.1892	.0943	.0377	.1463
Min	.0739	.0572	.037	.1892	.056	.0377	.0549
Avg	.1109	.0572	.0372	.1892	.0678	.0377	.0796

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 208 / VIJAYNAGAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.0924	
2						.0934	
3						.0914	
4						.1307	
8	.2408						
10							.104
11			.081				.0686
12			.0648				.1029
13			.0686				
14					.8436		
15					.8905		
18					.1267		
19							.1656
20					.2614		.2258
21							.1806
22					.1867		.4816
23							.4515
24	.1957	.3887	.3437	.3506	.132	.112	.132
Max	.2408	.3887	.3437	.3506	.8905	.1307	.4816
Min	.1957	.3887	.0648	.3506	.1267	.0914	.0686
Avg	.2183	.3887	.1395	.3506	.4068	.1040	.2125

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244046 / 33/11 KV HATNUR

Feeder No / Name : 209 / 11 KV HONAI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.0183	
2						.0187	
3						.0183	
4						.0187	
8	.0332						
10							.0332
11			.0171				.0343
12			.0152				.0343
13			.0171				
14					.2462		
15					.2397		
18					.0183		
19							.0343
20					.037		.0343
21							.0343
22					.0183		.2317
23							.2172
24	.1658	.16	.1334	.1021	.0189	.0183	.0189
Max	.1658	.16	.1334	.1021	.2462	.0187	.2317
Min	.0332	.16	.0152	.1021	.0183	.0183	.0189
Avg	.0995	.16	.0457	.1021	.0964	.0185	.0747

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 201 / 11 KV PANMALEWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1132	.1494	.1132	1.2803	1.1336	.9282
2	.1143	.0934	.132	.1132	1.2944	1.085	.8802
3	.0953	.0943	.1132	.112	1.1843	1.0526	.8002
4	.1132	.0953	.112	.112	1.1469	1.0883	.7773
5	.1494	.132	.1294	.1132	1.0883	1.1203	.8421
6	.1829	.1698	.1698	.1698	1.1523	1.1523	.8907
7	.1753	.1867	.168	.1848	1.6057	1.5238	1.0159
8	.156	.1478	.1663	.1646	.181	.1991	.1848
9	1.3108	1.4091	1.4723	.1629	.1663	.2054	1.8233
10	1.3279	1.3441	1.6842	.1463	.1867	.2195	1.704
11	1.4575	1.0883	1.7814	.181	.2075	.2378	.7773
12	1.5565	1.3123	1.6194	.2507	.1886	.2534	.9069
13	1.5893	1.2803	1.5708	.2195	.2241	.2353	2.0481
14	1.4746	1.3279	1.6842	.2534	.2241	.2402	2.2348
15	1.3279	1.4255	1.704	.2378	.2218	.2241	2.0317
16	1.2146	1.3927	1.587	.2218	.2012	.2427	1.9006
17	.1267	.1463	.1595	.1829	.1867	.2452	.1595
18	.1463	.1791	.0732	.0895	.1478	.2218	.2172
19	.1663	.168	.0747	.1463	.1829	.2218	.1848
20	.1478	.1698	.1478	.2033	.2012	.2033	.1848
21	.1494	.168	.1463	.1829	.2218	1.1012	.2054
22	.1433	.1509	.1294	1.5729	1.4251	1.0883	.1698
23	.1307	.1494	.112	1.3763	1.2323	1.0364	.1509
24	.132	.112	.1494	.1132	1.3763	1.1843	.9717
Max	1.5893	1.4255	1.7814	1.5729	1.6057	1.5238	2.2348
Min	.0953	.0934	.0732	.0895	.1478	.1991	.1509
Avg	.5626	.5357	.6348	.2760	.6470	.6465	.9163

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 202 / 11 KV BORGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1334	.1524	.1509	.132	.1307	.1715
2	.1143	.1143	.132	.132	.1143	.1307	.1698
3	.1143	.0943	.1132	.1509	.1334	.132	.168
4	.1509	.0943	.1143	.1509	.1698	.1698	.1886
5	.1867	.1509	.1494	.1509	.1867	.1867	.2075
6	.2218	.2263	.2377	.2263	.2012	.2263	.2452
7	.2561	.2452	.2241	.2263	.2402	.2241	.2427
8	.2172	.2033	.1698	.1867	.1791	.2033	.2378
9	.1646	.168	.1307	.1478	.1463	.1663	.1829
10	.1478	.1663	.1663	.1097	.1478	.1478	.1791
11	.1478	.1478	.0924	.1254	.1294	.1307	.1663
12	.1294	.1294	.0739	.1448	.112	.1463	.1417
13	.1109	.1294	.0747	.1097	.0549	.1294	.1478
14	.112	.1307	.0924	.0905	.0924	.1294	.1478
15	.0934	.0943	.0747	.1097	.1109	.1307	.1478
16	.0934	.0934	.0739	.1478	.0934	.1478	.1294
17	.1109	.0934	.0739	.128	.1109	.1646	.0905
18	.128	.128	.1433	.1448	.1463	.1848	.1629
19	.2241	.2054	.2218	.1791	.2218	.2378	.2402
20	.2452	.2452	.2427	.2507	.2614	.2427	.2801
21	.2241	.2241	.2452	.2378	.2263	.2241	.2641
22	.2075	.2263	.2075	.2218	.2096	.2263	.2263
23	.168	.1886	.1698	.1646	.1698	.2075	.1886
24	.1509	.1334	.1524	.1509	.1478	.1509	.1905
Max	.2561	.2452	.2452	.2507	.2614	.2427	.2801
Min	.0934	.0934	.0739	.0905	.0549	.1294	.0905
Avg	.1605	.1569	.1470	.1599	.1557	.1738	.1882

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 203 / 11 KV SHIRGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.2286	.2286	.2477	.2477	.2667	.2286
2	.1905	.1905	.1905	.2286	.2286	.2667	.2286
3	.1715	.1905	.1905	.2477	.2096	.2667	.2477
4	.1905	.1905	.1715	.2477	.2667	.3048	.2477
5	.2286	.2858	.2477	.2667	.3048	.3429	.2858
6	.3048	.4001	.3429	.362	.3429	.381	.3429
7	.362	.4763	.4191	.381	.362	.4001	.362
8	.3429	.3239	.3048	.3429	.3239	.381	.3429
9	.2858	.2858	.2477	.2667	.2667	.2667	.2477
10	.2096	.2096	.2328	.2096	.2667	.2667	.2328
11	.2286	.2286	.1715	.2286	.2477	.2477	.1829
12	.2477	.2667	.1905	.2096	.2096	.2286	.197
13	.1905	.1715	.1524	.1715	.1638	.2096	.2096
14	.1715	.1715	.1463	.1715	.2286	.1905	.2667
15	.2096	.2096	.1905	.1905	.2477	.1905	.2286
16	.2096	.2286	.1905	.2286	.1334	.1905	.2195
17	.2667	.2286	.1928	.2667	.2286	.2096	.1612
18	.3048	.2477	.2353	.3048	.2858	.2667	.2218
19	.381	.381	.3475	.381	.3906	.4001	.4001
20	.4763	.4191	.3881	.4382	.4382	.4572	.4572
21	.381	.381	.381	.4001	.381	.4001	.4001
22	.3048	.3239	.3239	.362	.3429	.381	.362
23	.2858	.2858	.2477	.2858	.3239	.2858	.2858
24	.2286	.2286	.2572	.2477	.2667	.2858	.2477
Max	.4763	.4763	.4191	.4382	.4382	.4572	.4572
Min	.1715	.1715	.1463	.1715	.1334	.1905	.1612
Avg	.2659	.2731	.2496	.2786	.2795	.2953	.2753

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 204 / 11 KV BORGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	1.0322	.9922	.8482	.1905	.1905	.168
2	1.2452	.9442	.9488	.8322	.1715	.1886	.1886
3	1.1843	.9717	.9602	.8583	.1715	.1886	.1886
4	1.1305	.9339	.9555	.8421	.1886	.2263	.2286
5	1.1363	.9717	.9393	.8322	.2241	.2452	.2667
6	1.1961	1.0364	.9878	.9069	.2561	.2829	.3018
7	1.4403	1.326	1.2003	1.0364	.2865	.3018	.3206
8			.2054	.2218	.2614	.2614	.2641
9		.2614	.168	1.3763	1.7924	1.8515	.2241
10		.2218	.1867	1.5524	1.8623	1.8842	.2054
11		.1494	.1494	1.5565	1.917	1.8785	.1848
12	.1663	.168	.168	1.5364	1.8623	1.8299	.168
13	.1294	.2561	.1494	1.5074	1.7695	1.8842	.1494
14	.128	.2591	.168	1.5364	1.7736	1.7604	.168
15	.1448	.2591	.1494	1.5402	1.7695	1.8138	.1494
16	.1848	.2591	.1478	1.4723	1.7004	1.8084	.181
17	.1646	.2721	.1829	.1829	.1463		
18	.1463	.2865	.2012	.1663	.1867	.1478	.1848
19	.2054	.2591	.2054	.1829	.2263	.2427	.2033
20	.2241	.3018	.2263	.2149	.1132	.2263	.2241
21	.2263	.2054	.2263	.2378	.1698	.2263	.2452
22	1.3117	1.1984	1.0277	.2218	.2263	.2452	2.0645
23	1.2125	1.1174	.9717	.2241	.2075	.2075	1.8351
24	1.3763	1.0437	1.012	.9122	.2075	.1698	.1886
Max	1.4403	1.326	1.2003	1.5565	1.917	1.8842	2.0645
Min	.128	.1494	.1478	.1663	.1132	.1478	.1494
Avg	.7117	.5972	.5221	.8666	.7367	.7853	.3610

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 205 / 11 KV SHIRGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.1307	.128	.1307	1.3763	1.2483	1.1843
2	.0762	.1132	.1109	.112	1.3435	1.1843	1.1336
3	.0762	.1097	.1109	.1109	1.2483	1.1363	1.0722
4	.1524	.0934	.1307	.1307	1.2163	1.1405	1.0402
5	.1867	.1478	.1494	.1294	1.2003	1.1717	1.0911
6	.1829	.2054	.2241	.2218	1.3108	1.2176	1.1843
7	.2172	.2054	.2378	.2427	1.6385	1.5729	1.2631
8	.1829	.2195	.2033	.2218	.197	.1949	.1612
9	1.5364	1.7004	1.6644	.181	.1867	.1463	2.0891
10	1.8084	1.7124	1.8404	.1463	.168	.1254	2.3594
11	1.7814	1.7976	1.9044	.1612	.1433	.1463	2.2611
12	1.8138	1.7284	1.8884	.1448	.1463	.156	2.3644
13	1.6324	1.6964	1.8947	.1463	.1332	.1463	2.2283
14	1.5684	1.6518	1.5684	.181	.1097	.1417	2.3815
15	1.3916	1.7004	1.4706	.1646	.0876	.1307	2.2186
16	1.4563	1.6194	1.5061	.1612	.1063	.1227	1.9433
17	.1214	.1267	.1448	.1646	.128	.1097	
18	.1387	.116	.1463	.181	.1494	.0934	.1578
19	.1829	.1629	.2012	.2012	.2195	.2172	.1829
20	.1867	.2033	.2033	.1848	.2218	.2195	.1886
21	.168	.1867	.2033	.1494	.2054	.1848	.2075
22	.1494	.1646	.2033	1.4582	1.4899	1.3123	.168
23	.132	.168	.1307	1.4083	1.3765	1.2643	.1509
24	.0934	.128	.1463	.1294	1.3927	1.3279	1.2323
Max	1.8138	1.7976	1.9044	1.4582	1.6385	1.5729	2.3815
Min	.0754	.0934	.1109	.1109	.0876	.0934	.1509
Avg	.6380	.6703	.6838	.2693	.6581	.6130	1.2289

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 206 / 11 KV PANMALEWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0747	.0747	.0754	.0762	.0943	.0934
2	.0572	.0566	.0566	.0754	.0572	.0754	.0924
3	.0572	.0572	.056	.0754	.0566	.0754	.0924
4	.0762	.0762	.0549	.0754	.0747	.0934	.112
5	.0754	.0934	.0934	.0943	.0924	.112	.132
6	.1097	.112	.1132	.1132	.128	.132	.132
7	.1448	.1307	.1307	.1307	.1478	.1307	.1478
8	.1267	.0924	.1097	.0905	.1227	.1063	.124
9	.0914	.0934	.1086	.0914	.1646	.0895	.1086
10	.0732	.0905	.0895	.1075	.112	.0739	.0709
11	.0732	.0895	.0732	.0914	.0924	.0732	.0724
12	.0732	.0924	.0732	.0724	.0934	.0709	.0886
13	.0732	.0747	.0716	.0732	.0905	.0724	.0747
14	.0732	.0747	.0549	.0724	.0914	.0732	.0724
15	.0732	.0943	.0566	.0549	.0716	.0739	.0732
16	.0732	.0747	.0566	.0537	.0693	.0886	.0716
17	.0739	.0732	.0543	.0549	.0732	.0732	.0732
18	.0747	.0716	.0543	.0716	.0924	.0747	.0716
19	.1463	.1097	.1109	.128	.1433	.1086	.112
20	.181	.1663	.1478	.1612	.1478	.1698	.1494
21	.1463	.1132	.1698	.1448	.1307	.132	.132
22	.1132	.1132	.1307	.1097	.132	.1132	.132
23	.0943	.0934	.0943	.112	.0943		.0943
24	.0754	.0754	.0754	.0754	.0754	.0934	.112
Max	.181	.1663	.1698	.1612	.1646	.1698	.1494
Min	.0572	.0566	.0543	.0537	.0566	.0709	.0709
Avg	.0930	.0914	.0880	.0919	.1012	.0957	.1015

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 207 / 11 Kv Nimbalk Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3763	.9922	1.1797	1.1469	.1334	.1307	.1494
2	1.3272	.9488	1.1469	1.0688	.1334	.132	.1478
3	1.2163	.9172	1.1012	1.0202	.1143	.132	.1478
4	1.1469	.9393	1.0883	1.0082	.132	.168	.168
5	1.1142	.9762	1.166	.9804	.1494	.1698	.1886
6	1.1363	1.0722	1.2146	1.0722	.1663	.1886	.2075
7	1.4582	1.4255	1.4089	1.1822	.1646	.1698	.2263
8	.1646		.1578	.1663	.1448	.1663	.2263
9	.1829	.1719	.1478	1.8244	2.5396	2.4034	.2241
10	.1663	.1494	.1494	2.1136	2.6189	2.3205	.1867
11	.1463	.1867	.168	2.1445	2.6686	2.343	.2054
12	.1448	.1867	.181	2.3685	2.5724	2.3537	.2033
13	.1294	.2054	.128	2.1792	2.3205	2.343	.0373
14	.1307	.1509	.1494	2.1445	2.2119	2.3266	.2054
15	.1307	.1698	.1494	2.0972	1.8896	2.1628	.2054
16	.132	.168	.1867	1.9989	1.7124	2.0729	.2054
17	.1307	.1848	.1646	.1629	.1307	.1646	.1867
18	.1478	.1494	.1848	.1629	.1494	.1867	.2054
19	.168	.1494	.2075	.1848	.1848	.2241	.2263
20	.1886	.1698	.1848	.2012	.1867	.2054	.2075
21	.1509	.168	.1867	.181	.1867	.1867	.168
22	1.2793	1.4089	1.4091	.1646	.1698		2.1051
23	1.1683	1.2955	1.2955	.168	.1509	.1886	1.9062
24	1.4419	1.0595	1.1843	1.2146	.1509	.1494	.168
Max	1.4582	1.4255	1.4091	2.3685	2.6686	2.4034	2.1051
Min	.1294	.1494	.128	.1629	.1143	.1307	.0373
Avg	.6158	.5759	.6059	1.1232	.8743	.9082	.3378

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (I)[077]

BU 1261

Substation No/ Name :- 244056 / 33/11 KV BORGAON

Feeder No / Name : 208 / 11kv VISAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0934	.1132	.1132	.8029	.6173	.6944
2	.0191	.0754	.0934	.1132	.7362	.5937	.6718
3	.0191	.0754	.0953	.1132	.7209	.5864	.6249
4	.0191	.0934	.0953	.1132	.7202	.6562	.6401
5	.0191	.1132	.1132	.1132	.7537	.679	.6562
6	.0191	.1433	.132	.132	.7865	.6859	.6718
7	.1829	.168	.1478	.1867	.8802	1.1012	.8223
8	.1629	.1829	.1267	.1294	.1463	.2012	.1663
9	.8192	.787	.8749	.1254	.1109	.1509	1.1092
10	.8025	.8333	.9061	.1086	.112	.0943	1.1385
11	.787	.8025	.8905	.0905	.1109	.1109	1.2186
12	.7716	.8592	.884	.0914	.112	.1463	1.2191
13	.8749	.8905	1.0494	.0924	.1294	.1478	1.1561
14	.8592	.9442	1.034	.128	.1307	.1294	1.1069
15	.828	.8802	.953	.1478	.1294	.1307	1.2334
16	.823	.8322	.933	.1307	.1307	.112	1.2483
17	.1063	.0934	.0709	.128	.112	.0943	.1267
18	.1267	.1086	.1187	.1448	.1097	.0934	.1109
19	.1494	.1307	.1294	.1463	.1307	.1494	.1494
20	.1494	.132	.1307	.1629	.1494	.1509	.1509
21	.1494	.1307	.1494	.1646	.132	.1509	.1509
22	.132	.1132	.1132	.8642	.8905	.8592	.132
23	.112	.112	.1132	.9012	.7164	.787	.132
24	.0754	.0934	.112	.1132	.8322	.6636	.7407
Max	.8749	.9442	1.0494	.9012	.8905	1.1012	1.2483
Min	.0191	.0754	.0709	.0905	.1097	.0934	.1109
Avg	.3344	.3620	.3908	.1898	.3994	.3788	.6696

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 201 / 11 KV ANKALKHOP GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1029	.1372	.1029	.1029	.1372	.1372
2	.1029	.1029	.1372	.1029	.1029	.1372	.1372
3	.1029	.1029	.1372	.1029	.1029	.1372	.1029
4	.1029	.1029	.1372	.1029	.1029	.1715	.1029
5	.1715	.1372	.1715	.1715	.1715	.1715	.1715
6	.2058	.1715	.2058	.2058	.2058	.2401	.2401
7	.2743	.2401	.2058	.2743	.2743	.2058	.2743
8	.1715		.1715	.2058	.2058	.2058	.1715
9	.1372	.1715	.1715	.1372	.1715	.1372	.2058
10	.1372	.1372	.1029	.1029	.1372	.1372	.1715
11	.1029	.1372	.1029	.1372	.1372	.1715	.1029
12	.1029	.1715	.1372	.1715	.1372	.1372	.1715
13	.1029	.1372	.1029	.1715	.1372	.1372	.1715
14	.1029	.1372	.1372	.1715	.1372	.1715	.1372
15	.1029	.1372		.1715	.1029		.1372
16	.1372	.1372	.1372		.1372		.2058
17	.1372	.1372	.1715	.1715	.1372	.1715	.2058
18	.1372		.1715	.1715	.1715	.1715	.2401
19	.1372	.3086	.2058	.2743		.2401	.2743
20	.1372	.3086	.2401	.2743	.2743	.3086	.2743
21	.1715	.2743	.2401	.2743	.2058	.2401	.2401
22	.1372	.2401	.1715	.2401	.1715	.2401	.2058
23	.1372	.1715	.1715	.1715	.1372	.1715	.1715
24	.2058	.1372	.1715	.1372	.1372	.1372	.1372
Max	.2743	.3086	.2401	.2743	.2743	.3086	.2743
Min	.1029	.1029	.1029	.1029	.1029	.1372	.1029
Avg	.1415	.1684	.1626	.1760	.1566	.1809	.1829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 202 / 11 KV AUDUMBER GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1715	.1372	.1372	.0857	1.3032	1.6975
2	.0838	.1372	.1372	.1372	.1029	1.2689	1.6975
3	.1372	.1543	.1372	.12	.1029	1.2003	1.6804
4	.1715	.1543	.1372	.12	.0857	1.1317	1.7833
5	.2401	.1543	.2058	.1715	.12	1.2003	1.8861
6	.2229	.2058	.2743	.2058	.1715	1.3032	2.0062
7	.2229	.2401	.2743	.2401	.1372	1.4403	2.0233
8	.1715		.2058	.2058	.12	1.3717	.2572
9	.12	2.2462	2.3148	.1543	.12	.1715	2.7949
10	.0857	2.4006	2.4348	.12	.1029	.1372	3.1207
11	2.4006	2.5892	2.4006	.12		.1372	3.2922
12	2.4691	2.5377	2.4006			.12	3.2579
13	2.5206	2.3834	2.2462			.1543	3.1893
14	.1543	2.2805	.1543			.1543	.3086
15	.1715	2.2291	.1029	.1543		.1543	.3086
16	.1715	.12	.1372			.1543	.3086
17	.1886	.12	.1543	.1543	.0343	.1543	.3086
18	.1886		.1715	.1543	.2401	.2572	.3086
19	.2058	.2915	.1715	.2401		.2743	.3086
20	.2229	.2915	.2058	.2229	.2743	.2915	.3086
21	.2229	.2572	.2401	.2229	.2401	.3086	.3086
22	.2058	.2401	.2058	.1886	.2401	1.8519	.3086
23	.1886	.1886	.1715	.0857	.1715	1.8347	.3086
24	.1715	.1715	.1715	.1715	.0857	1.2346	1.6632
Max	2.5206	2.5892	2.4348	.2401	.2743	1.8519	3.2922
Min	.0838	.12	.1029	.0857	.0343	.12	.2572
Avg	.4607	.8893	.6330	.1663	.1432	.7337	1.3932

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 203 / 11 KV BHILAWADI GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.3429	.3772	.3772	.3772	.3772	.3772
2	.3429	.3429	.3429	.3772	.3772	.3772	.3772
3	.3429	.3086	.3429	.3429	.3772	.3772	.3772
4	.3429	.3086	.3429	.3429	.3772	.3772	.4115
5	.4458	.4801	.3429	.4801	.4115	.4801	.4115
6	.6344	.5487	.6859	.4801	.6516	.5487	.6516
7	.703	.6859	.6859	.6001	.7202	.6516	.6859
8	.5658		.5144	.4973	.583	.5144	.4458
9	.4458	.4973	.3772	.3772	.4287	.3772	.4458
10	.3429	.4287	.3429	.3944	.3601	.3772	.3772
11	.2743	.3601	.3086	.3429	.3429	.3429	.3772
12	.2743	.3429	.3429	.3429	.3429	.3429	.3772
13	.3086	.3429	.3258	.3772	.3772	.3772	.3772
14	.3086	.3086	.3258	.3772	.3429	.3772	.4115
15	.3086	.3429	.3601	.3772	.3772	.4458	.3772
16	.3258	.3086	.3772		.3772		.3944
17	.3601	.3772	.4115		.3772		.4458
18	.4115		.4458	.583	.4801	.5144	.5487
19	.4801	.7545	.4973	.7202		.6516	.6516
20	.5144	.7545	.583	.6859	.6516	.7202	.7202
21	.5487	.6859	.6344	.6344	.6173	.583	.6516
22	.4801	.6173	.5144	.583	.583	.5487	.6173
23	.4115	.4801	.4801	.5144		.4458	.5144
24	.4801	.3772	.4115	.3944	.4115	.4115	.3772
Max	.703	.7545	.6859	.7202	.7202	.7202	.7202
Min	.2743	.3086	.3086	.3429	.3429	.3429	.3772
Avg	.4194	.4544	.4322	.4637	.4520	.4645	.4751

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 204 / 11 KV NAGATHANE GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2058	.2401		.2058	.2058	.2058
2	.2401	.2058	.2401		.2058	.2058	.2058
3	.2401	.1715	.2058	.2058	.2058	.2058	.1715
4	.2743	.1715	.2401	.2058	.2572	.2401	.2401
5	.3086	.2401	.3086	.3086	.3429	.2743	.3772
6	.3429	.3086	.4458	.3429	.4115	.3772	.4115
7	.3772	.4115	.4458	.4801	.3429	.3086	.4458
8	.3772		.3429	.4115	.3772	.3429	.2743
9	.3429	.3086	.3086	.3086	.2058	.2743	.3429
10	.3086	.2058	.2058	.2058	.2058	.2401	.2401
11	.2401	.2058	.2058	.2058	.2058	.2058	.1715
12	.2401	.1715	.2743	.2401	.2058	.2401	.2058
13	.2401	.1372	.1715	.2401	.2401	.1715	.1715
14	.2401	.2401	.2058	.2641	.2058	.2058	
15	.2058	.2401	.1715	.1715	.1372		.1372
16	.2058	.2058	.2058	.1715	.1372	.2401	.2058
17	.2401	.2058	.2401	.2058	.1715		.2401
18	.2401		.2058	.2058	.2058	.2743	.3086
19	.3429	.4115	.2058	.3086		.3429	.3429
20	.4458	.4458	.3429	.3429	.3086	.4458	.4115
21	.4115	.4458	.3772	.3429	.3772	.4458	.4115
22	.2743	.3772	.2743	.2401	.3086	.3772	.2401
23	.2401	.2743	.2401	.3086	.2058	.2743	.2743
24	.2401		.2743	.2401	.2401	.2401	.2401
Max	.4458	.4458	.4458	.4801	.4115	.4458	.4458
Min	.2058	.1372	.1715	.1715	.1372	.1715	.1372
Avg	.2858	.2662	.2658	.2708	.2483	.2790	.2729

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 205 / 11 KV ANKALKHOP AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	.0343	.6516	.6516	.6173
2	.0343	.0343	.0343	.0343	.6516	.6173	.6173
3	.0343	.0343	.0343	.0343	.6344	.583	.6173
4	.0343	.0343	.0343	.0343	.6344	.5487	.6173
5	.0343	.0343	.0343	.0343	.6173	.6173	.6516
6	.0343	.0343	.0343	.0343	.6859	.6516	.7202
7	.0343	.0343	.0343	.0343	.823	.6859	.8573
8	.0343		.0343	.0343	.0343	.0343	.8916
9	.0343	.0343	.0343	.0343	.0343	.0343	
10	.0343	.0343	.9945	.0343	.0343	.0343	
11	.0343	.0343	.0343	.0343	.0343	.0343	.0343
12	.0343	.0343	.0343	.0343	.0343	.0343	.0343
13	.0343	1.0288	.0343	.0343	.0343	.0343	.0343
14		1.0288	1.0631	.0343	.0343	.0343	1.5432
15	.9945	1.2689		.0343	.0343		1.6118
16	1.0631	1.2003	1.2003		.0343		1.6804
17	1.3375	1.166	1.1317		.0343		1.4403
18	1.2003		.9945		.0343	.0343	1.3375
19	.0343	.0343	.0343	.0343		.0343	.0343
20	.0343	.0343	.0343		.0343	.0343	.0343
21	.0343	.0343	.0343		.0343	.0343	.0343
22	.0343	.0343	.0343	.7888	.7202	.0343	.0343
23	.0343	.0343	.0343	.7202	.6173	.6859	.0343
24	.0343	.0343	.0343	.0343	.6859	.6859	.6516
Max	1.3375	1.2689	1.2003	.7888	.823	.6859	1.6804
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.2281	.2853	.2609	.1101	.3116	.2923	.6422

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 206 / 11KV AUDUMBER AG

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0335	.0335	.0343	.0343	1.1736	1.1317	1.5775
2	.0343	.0335	.0343	.0335	1.1401	1.0974	1.5775
3	.0343	.0335	.0343	.0335	1.166	1.0288	1.5775
4	.0343	.0335	.0343	.0335	1.2003	1.0288	1.5775
5	.0343	.0335	.0343	.0335	1.1736	1.0288	1.6289
6	.0343	.0335	.0343	.0335	1.3916	1.2003	1.749
7	.0343	.0335	.0343	.0335	1.4754	1.2689	1.8519
8	.0343		.0343	.0335	1.2071	1.2003	.0343
9	2.0576	2.0287	2.1605	.0335	.0335	.0343	2.6578
10	2.1795	2.2291	2.3148	.0335	.0335	.0343	3.0007
11	2.2466	2.4177	2.1795			.0343	3.1893
12	2.2466	2.4006	1.9448				3.155
13	2.2969	2.2634	2.0287				3.0864
14	.0335	2.1434	.0335				.0343
15	.0335	2.0919	.0335				.0343
16	.0335		.0343				.0343
17	.0335	.0343	.0343		.0343		.0343
18	.0343		.0343		.0343	.0857	.0343
19	.0343	.0343	.0335	.0343		.0343	.0343
20	.0343	.0343	.0335	.0335	.0343	.0343	.0343
21	.0343	.0343	.0335	.0335	.0343	.0343	.0343
22	.0335	.0343	.0343	.0335	.0343	1.6461	.0343
23	.0335	.0343	.0343	1.3413	.0343	1.6975	.0343
24	.0343	.0335	.0343	.0335	1.1736	1.0631	1.5432
Max	2.2969	2.4177	2.3148	1.3413	1.4754	1.6975	3.1893
Min	.0335	.0335	.0335	.0335	.0335	.0343	.0343
Avg	.4864	.7642	.4698	.1153	.6691	.7602	1.1896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 207 / 11 KV BHILAWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3032	1.0974	.9602	.0343	.0343	.0343	.0343
2	1.2346	1.0288	.8916	.0343	.0343	.0343	.0343
3	.0343	.0343	.8916	.9945	.0343	.0343	.0343
4	.0343	.0343	.8916	1.0288	.0343	.0343	.0343
5	.0343	.0343	.823	1.0974	.0343	.0343	.0343
6	.0343	.0343	.8916	1.0974	.0343	.0343	.0343
7	.0343	.0343	.0686	1.166	.0343	.0343	.0343
8	.0343		.0343	.0343	.0343	.0343	.0343
9	.0343	.0343	.0343	1.8519	2.6063	2.9492	.0343
10	.0343	.0343	.0343	2.0576	2.5034	3.0864	.0343
11	.0343	.0343	.0343	2.2291	2.6063	3.155	.0343
12	.0343	.0343	.0343	2.332	.0686	3.0864	.0343
13	.0343	.0343	.0343	2.3663	.0686	3.155	.0343
14	.0343	.0343	.0343	.0343	.0343		.0343
15	.0343	.0686	.0343	.0343	.0343		.0343
16	.0343	.0686	.0343		.0343		.0343
17	.0343	.0343	.0343		.0343		.0343
18	.0343		.0343	.0343	.0343	.0343	.0343
19	.0343	.0343	.0343	.0343		.0686	.0343
20	.0343	.0343	.0343	.0343	.0343	.0686	.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	.0343
22	.823	1.166	.0343	.0343	.0343	.0343	2.2634
23	.9259	1.0974	.0343	.0343	.0343	.0343	2.4006
24	1.4746	1.0288	1.0288	.0343	.0343	.0343	.0343
Max	1.4746	1.166	1.0288	2.3663	2.6063	3.155	2.4006
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.2672	.2759	.2915	.7560	.3683	.8008	.2258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244013 / 33/11 KV ANKALHKOP

Feeder No / Name : 208 / 11 KV NAGTHANE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1372	.0686	1.2517	.1029	.0686	.0686
2	.1029	.1372	1.1145	1.0974	.1029	.0686	.0686
3	1.5089	.1372	1.1145	1.3717	.1029	.0686	.0686
4	1.5775	.1372	1.2346	1.4403	.1029	.0686	.0686
5	1.8176	.1372	1.166	1.5432	.1372	.0686	.1372
6	1.9204	.1372	1.3032	1.4918	.1372	.1372	.2058
7	1.989	.1372	1.5775	1.4403	.1372	.1372	.1372
8	.1372	.1372	1.5089	.1372	.1372	.1372	
9	.1372	.1372	.0686	.1372	.1372	.1372	.1372
10	.1372	.1372	.0686	.1372	.1372	.1372	.1372
11	.1372	.1372	.0686	.1372	.1372	.2058	
12	.1372	.0686	.1372	.1372	.1372	.1372	.1372
13	.1372	.0686	.1372	.1372	.1372	.0686	.1372
14	.1372	.1372	.1341	3.2922	3.6008	3.6866	.1372
15	.1372	.0686	.1372	2.8807	3.8409	3.9781	
16	.1372	.0686	.1372	2.915	3.4294	3.9781	.1372
17	.1372	.0686	.1372	3.2236	3.0864	3.9438	.1372
18	.1372		.1372	2.9492	3.155	.1372	.1372
19	.1372	.1372	.1372	.1372		.1372	.1372
20	.1372	.1372	1.2517	.1372	.1372	.1372	.1372
21	.1372	.0686	1.2517	.1372	.1372	.1372	.1372
22	.1372	.1372	1.2517	.1372	.1372	.1372	.1372
23	.1372	.0686	1.1126	.1029	.1372	.1372	.1372
24	.1029	.1372	.0686	1.2517	.1029	.0686	.1372
Max	1.989	.1372	1.5775	3.2922	3.8409	3.9781	.2058
Min	.1029	.0686	.0686	.1029	.1029	.0686	.0686
Avg	.4716	.1163	.6385	1.1510	.8439	.7466	.1274

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 201 / 11 KV YELAVI AG

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1132	.132	.1132	.5937	.571	.703
2	.1132	.1132	.1132	.0943	.5693	.5624	.7202
3	.1132	.1132	.132	.0943	.5556	.571	.6958
4	.132	.1132	.132	.1132	.6009	.578	.7773
5	.1698	.1509	.1698	.132	.6325	.6009	.759
6	.2452	.2263	.2075	.1698	.6882	.6882	.8322
7	.2452	.2641	.2452	.2075	1.078	1.0526	.9012
8	.2263	.2263	.2075	.168	.1494	.1867	.1509
9		.8381	.8697	.1698	.2263	.1867	1.1523
10	.8002	.9602	1.1203	.168	.2033	.1848	1.1843
11	.9745	.9602	1.1523	.168	.2241	.2263	
12		1.0883	1.1069	.1698	.2218	.1886	1.2176
13	.5556	1.0623	.8124	.1867	.1886	.2263	
14	.7748	.9374	.7748	.168	.1698	.2452	1.2803
15	.7562	.9259	.8802	.1463	.1698	.2263	1.2963
16	.8124	.8802	.9014	.1509	.1848	.2075	1.2334
17	.112		.1307	.1494	.1867	.2075	.1698
18		.168	.1307	.1307	.1494	.1886	.1886
19	.1509	.1698	.1698	.1494	.1886	.2075	.2075
20	.1509	.1698	.1698	.1886	.1886	.2263	.1886
21	.132	.1698	.1698	.1886	.1886	.2263	.1886
22	.1509	.1698	.1509	.6958	.7287	.7522	.1509
23	.1132	.1698	.1132	.2263	.6722	.8002	.132
24	.132	.0943	.1509	.1132	.6167	.5693	.7186
Max	.9745	1.0883	1.1523	.6958	1.078	1.0526	1.2963
Min	.112	.0943	.1132	.0943	.1494	.1848	.132
Avg	.3330	.4384	.4226	.1776	.3907	.4034	.6749

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 202 / 11 KV Laxmi LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0559	1.4632	.9259	.7716	.5376	1.6632
2	2.0748	1.5497	.9259	.8505	.5668	1.7551
3	2.0936	1.6598	.9088	.8596	.5556	1.7177
4	2.0748	1.6975	.9431	1.0269	.6001	1.8861
5	2.0559	1.8107	.9816	1.1203	.6836	2.0182
6	2.0936	1.8861	1.0631	1.307	1.1763	2.1313
7	2.1691	1.9239	.8573	1.251	1.3014	2.2445
8	2.3577	2.1313	1.1088	1.3392	1.7918	2.32
9	2.5463	2.3765	1.5089	1.3769	2.32	2.7349
10	2.5652	2.4897	1.4901	1.2449	.2256	3.0744
11	2.6595	2.4897	1.5089	1.5466	2.6029	2.5086
12	2.8292	2.4709	1.5655	1.4712	2.6406	2.9613
13	2.7726	2.32	1.5844	1.4523	2.8292	2.9047
14	2.7726	2.4143	1.6032	1.4146	2.9235	2.9047
15	2.6406	2.3954	1.5089	1.4335	2.8669	2.9801
16	1.9805	1.9427	1.4901	1.3957	2.0748	2.1879
17			1.4901			
Max	2.8292	2.4897	1.6032	1.5466	2.9235	3.0744
Min	1.9805	1.4632	.8573	.7716	.2256	1.6632
Avg	2.3589	2.0638	1.2626	1.2414	1.6060	2.3745

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 203 / 11 KV Yelavi Bu'wadi

GAOTHAN FEEDER

Gaonthan Feeder KV- 11 /

OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3395	.3772	.3584	.3772	.3584	.3772
2	.2829	.3395	.3584	.3395	.3395	.3584	.3772
3	.2829	.3584	.3584	.3395	.3584	.3547	.3584
4	.3206	.3584	.415	.3961	.3772	.3772	.3961
5	.3961	.4338	.4904	.4904	.4715	.4527	.4527
6	.7167	.7545	.6979	.6979	.679	.6602	.6979
7	.7356	.7545	.7356	.6908	.7545	.679	.5658
8	.5601	.5601	.547	.4805	.4805	.5175	.4024
9	.4755	.4435	.4066	.4163	.4207	.4207	.3224
10	.3658	.362	.3045	.3155	.362	.4207	.3045
11	.3045		.2686	.3155	.3224	.3898	.2454
12	.2686	.3292	.2686	.333	.2865	.3403	.4075
13	.2328	.2743	.2715	.3012	.2835	.3077	.3681
14	.2534	.2686	.2715	.2126	.2865	.3475	.3429
15	.2686	.2126	.2926	.3045	.3045	.3475	.3258
16	.2686	.2561	.2715	.3012	.3045	.3326	.3077
17	.3439	.2686	.3224	.3155	.3366	.3403	.3142
18		.3258	.3544	.3681	.394	.3506	.3696
19	.6099	.4805	.5853	.5792	.4572	.6036	.6219
20	.6535	.6161	.6653	.6468	.6161	.6535	.6722
21	.6224	.5658	.6161	.6348	.5788	.6161	.6348
22	.5281	.547	.547	.5658	.5281	.5658	.5281
23	.415	.4715	.4338	.4715	.4338	.4527	.4715
24	.3206	.3584	.415	.3772	.4338	.3772	.415
Max	.7356	.7545	.7356	.6979	.7545	.679	.6979
Min	.2328	.2126	.2686	.2126	.2835	.3077	.2454
Avg	.4143	.4208	.4281	.4272	.4245	.4427	.4283

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 204 / 11 KV Burungwadi

Industrial Feeder KV- 11 /
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2591	.2561	.1886	.2372	.1467	.2286	.2
2	.216	.2315	.2012	.2372	.1296	.1894	.1646
3	.1858	.2164	.1829	.2134	.1383	.184	.1907
4	.2054	.2143	.1781	.2027	.1372	.2058	.2006
5	.2115	.2195	.192	.2029	.132	.208	.2134
6	.2107	.1652	.1989	.2107	.1659	.2086	.2713
7	.3086	.3121	.3224	.3086	.3544	.2804	.3018
8	.3258	.2949	.3841	.2035	.3222	.3395	.3294
9	.3841	.3761	.4904	.2865	.3982	.4656	.4344
10	.362	.5093	.7167	.2987	.3544	.5083	.6036
11	.3772	.5093	.7356	.3734	.394	.7167	.547
12	.4338	.4715	.8299	.4338	.3224	.7356	.6161
13	.4108	.4527	.7545	.2263	.4668	.439	.7545
14	.3881	.4527	.6036	.5093	.4207	.5847	.7733
15	.4435	.5281	.8488	.4904	.4338	.6979	.7545
16	.4251	.5847	.547	.3801	.4294	.6413	.7922
17	.4066	.679	.8299	.415	.3881	.4024	.7545
18	.3921	.811	.5281	.3961	.3511	.3841	.5658
19	.5228	.4527	.5658	.4163	.4668	.3475	.4904
20	.5228	.5658	.5281	.4207	.3982	.3012	.462
21	.4344	.5281	.4668	.4024	.4031	.2591	.439
22	.4163	.547	.5093	.3479	.4031	.2286	.4163
23	.2932	.362	.3109	.3681	.2561	.2286	.3163
24	.3086	.2656	.2804	.2743	.2429	.2429	.216
Max	.5228	.811	.8488	.5093	.4668	.7356	.7922
Min	.1858	.1652	.1781	.2027	.1296	.184	.1646
Avg	.3518	.4169	.4748	.3273	.3190	.3762	.4503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 205 / 11Kv Express Feeder

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4146	1.4146	1.3769	1.3769	1.4712	1.4146	1.6032
2	1.4523	1.4335	1.358	1.4146	1.4523	1.5278	1.5089
3	1.3957	1.358	1.3769	1.4146	1.4335	1.5089	1.4901
4	1.4335	1.4901	1.4146	1.4335	1.4712	1.5466	1.4712
5	1.4146	1.6032	1.3957	1.5089	1.5466	1.5844	1.4901
6	1.4523	1.6221	1.4146	1.5466	1.6409	1.6409	1.5278
7	1.4146	1.5844	1.4523	1.5089	1.6598	1.7353	1.6598
8	1.5466	1.5466	1.6598	1.6598	1.6975	1.6598	1.7353
9	.9808	1.1317	1.1317	1.3769	1.1883	1.094	1.226
10	1.0751	1.0751	1.1694	1.3014	1.226	1.3203	1.2826
11	1.1694	1.4523	1.3203	1.5089	1.358	1.3392	1.4335
12	1.3957	1.4335	1.094	1.5089	1.358	1.3957	1.4523
13	1.7353	1.773	1.7353	1.9427	1.6598	1.773	1.773
14	1.6975	1.8861	1.7918	1.9616	1.6975	1.7164	1.6787
15	.547	1.7918	1.6032	2.037	1.5844	1.6221	1.6221
16		1.6787	1.6409	1.6598	1.6409	1.8296	1.7353
17	1.8107	1.5089	1.6975	1.7918	1.6409	1.6975	1.7353
18	1.6598	1.5655	1.226	1.3203	1.6598	1.5655	1.5089
19	1.1694	1.0562	1.1883	1.1694	1.226	1.2449	1.358
20	1.1317	1.0374	1.094	1.2826	1.1128	1.1506	1.4146
21	1.1694	.9997	1.094	1.1506	1.0374	1.1883	1.1694
22	1.226	.9431	1.2071	1.2826	1.1694	1.3203	1.6032
23	1.3203	1.2826	1.4712	1.5466	1.4335	1.4901	1.3957
24	1.358	1.358	1.4146	1.2826	1.4335	1.4146	1.5278
Max	1.8107	1.8861	1.7918	2.037	1.6975	1.8296	1.773
Min	.547	.9431	1.094	1.1506	1.0374	1.094	1.1694
Avg	1.3465	1.4178	1.3887	1.4995	1.4500	1.4909	1.5168

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244026 / 33/11 KV BURUNGAWADI

Feeder No / Name : 206 / Yelavi Ag -2

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0137	.0154	.0305	.0267	.9116	.0297	1.1603
2	.0093	.0168	.0253	.0286	.9389	.0272	1.1012
3	.0133	.0107	.0229	.0286	.9448	.0274	1.0562
4	.0137	.0154	.0173	.0272	.9326	.0272	1.0279
5	.0152	.021	.0229	.0223	.9831	.0267	1.0311
6	.024	.0206	.0457	.0206	1.0526	.064	1.0883
7	.036	.0419	.0713	.052	.503	.0777	1.2803
8	.0617	.0514	.061	.0518	.0429	.0583	.0713
9	.0617	1.2266	1.2239	.048	.0572	.0671	2.0729
10	1.2597	1.3077	1.4586	.0669	.0503	.0553	2.13
11	1.3077	1.2742	1.2574	.064	.0667	.0421	1.8275
12	1.3592	1.3592	1.5249	.0709	.0669	.0533	1.9784
13	1.2039	1.2742	1.2407	.0476	.0566	.052	1.95
14	.7545	1.3077	1.1568	.0514	.0608	.0419	1.8652
15	.9602	1.2574	1.2407	.0692	.0545	.04	1.8482
16	1.0288	1.1401	1.2763	.064	.0389	.0347	1.6263
17	.0326	.0419	.0514	.0743	.057	.0545	.0693
18		.0419	.0457	.0644	.0587	.048	.061
19	.0486	.0572	.04	.0732	.0514	.0488	.048
20	.0229	.0453	.0486	.0421	.0398	.0377	.029
21	.016	.0457	.0274	.0488	.0377	.0396	.0194
22	.0137	.0488	.0293	1.0277	.0396	1.3603	.0257
23	.021	.052	.0274	1.0059	.0251	1.166	.0229
24	.0152	.0154	.0572	.0293	.9945	.0293	1.1469
Max	1.3592	1.3592	1.5249	1.0277	1.0526	1.3603	2.13
Min	.0093	.0107	.0173	.0206	.0251	.0267	.0194
Avg	.3605	.4454	.4585	.1294	.3361	.1462	1.0224

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 201 / 11 KV VASAGADE GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1109	.1267	.1109	.1086	.1097	.1097
2		.1097	.1075	.1109	.0914	.0914	.1086
3		.1097	.112	.1097	.0914	.0924	.1097
4		.1109	.1097	.1097	.1086	.1097	.1086
5		.1294	.1448	.1294	.1097	.128	.1097
6		.1848	.1791	.2587	.1267	.2218	.1097
7		.128	.2149	.2195	.128	.1848	.1086
8		.1109	.1629	.1478	.1086	.128	.128
9		.1097	.128	.1097	.128	.1478	.1097
10		.1097	.1086	.1097	.1097	.1097	.1086
11	.1109	.1086		.1086	.0924	.1097	.112
12	.1097	.1097		.1097	.1097	.1086	.1097
13	.1097	.1086	.0914	.1086	.1109	.1097	.1017
14	.1109	.1075	.1294	.1097	.081	.1086	.1052
15	.1097	.1086	.1463	.1086	.081	.1097	.1075
16	.0924	.1097	.1097	.1097	.0995	.1086	.1075
17		.1097	.1109	.0905	.128	.1097	.1086
18	.1097	.1433	.1294	.0914	.1478	.1086	.1254
19	.2195	.1595	.1829	.1448	.1829	.0732	.1612
20	.1829	.2149	.2218		.2587	.1463	.2172
21	.1478		.2012	.2172	.2033	.1829	.2149
22	.128	.181	.1478	.2195	.1463	.1267	.1991
23	.128	.1646	.128	.1086	.1109	.128	.1829
24		.1109	.1463	.128	.1097	.1109	.1086
Max	.2195	.2149	.2218	.2587	.2587	.2218	.2172
Min	.0924	.1075	.0914	.0905	.081	.0732	.1017
Avg	.1299	.1283	.1427	.1335	.1239	.1235	.1280

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 202 / 11KV KHATAV GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.128	.128	.1109	.1097	.1109	.1267
2	.1097	.1478	.1109	.1109	.0905	.1109	.128
3	.1086	.1109	.1109	.1097	.0914	.1097	.1086
4	.0914	.1097	.1086	.1097	.1086	.1829	.1097
5	.1086	.128	.1463	.128	.2172	.2218	.128
6	.128	.2218	.1991	.2218	.2195	.2402	.1267
7	.2534	.2195	.2149	.2033	.2172	.1829	.2195
8	.2561	.1829	.181	.1829	.1829	.1663	.2195
9	.1448	.1478	.1433	.1478	.1109	.1463	.1267
10	.1463	.128	.1267	.1097	.1097	.2561	.128
11	.1294	.1086		.1086	.1097	.2172	.1075
12		.1097		.1097	.1109	.1086	.1086
13		.1086		.1097	.1097	.1097	.1097
14		.1075		.1086	.1294	.1086	.1086
15		.1075	.0924	.0914	.0914	.1097	.1075
16		.1075	.1097	.1086	.1109	.1086	.1075
17		.1075	.1109	.0914	.128	.1097	.1086
18	.2561	.1448	.1109	.128	.1109	.1086	.1433
19	.2561	.1791	.1829	.2172	.1829	.1097	
20	.2402	.2126	.2378	.2195	.2195	.2378	.2328
21	.2378	.2328	.2218	.2534	.1848	.2353	.2103
22	.2195	.1991	.1829	.1097		.2195	.197
23	.1848	.1629	.1097	.1086	.1463	.1448	.1463
24	.1097	.1478	.1463	.1097		.1097	.1463
Max	.2561	.2328	.2378	.2534	.2195	.2561	.2328
Min	.0914	.1075	.0924	.0914	.0905	.1086	.1075
Avg	.1717	.1484	.1488	.1379	.1405	.1569	.1415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 203 / 11 KV SUKHWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5636	.2195	.3052	.3481	.0181	.0183	.0181
2	.57	.2218	.285	.3481	.0183	.0183	.0183
3		.2218	.2883	.3401	.0181	.0181	.0181
4		.2195	.2713	.3401	.0183	.0181	.0183
5		.2957	.2652	.3441	.0181	.0185	.0181
6		.3326	.2949	.3441	.0183	.0185	.0183
7		.4207	.0177	.3401	.0183	.0183	.0181
8		.1097	.0175	.0166	.0183	.0185	
9		.0185	.0177	.7293	1.1088	1.2803	.0181
10		.0183	.0181	.9282	1.2437	1.448	.0183
11		.0181		.9389	1.5154	1.4632	.0181
12		.0179		.9282	1.3676	1.4118	.0181
13		.0181		.9724	1.3169	1.4266	.0181
14		.0179		.9614	1.2936	1.3394	.0179
15		.0177		.9282	1.1888	1.3169	.0179
16		.0179	.0162	.9389	1.1827	1.267	.0177
17		.0179	.0166	.0179	.0181		.0179
18		.0181	.0164	.0181	.0183		.0181
19	.0185	.0177	.0166	.0181	.0166	.0175	.0179
20	.0183	.0179	.0164		.0166		.0181
21	.0183	.0177	.0166		.0164	.0177	.0179
22	.3887	.3315	.3401	.0018	.0162	.0179	.8356
23	.3277	.3018	.3441	.0018	.0183	.0181	.8288
24	.5967	.3315	.2984	.3441	.0183	.0185	.0183
Max	.5967	.4207	.3441	.9724	1.5154	1.4632	.8356
Min	.0183	.0177	.0162	.0018	.0162	.0175	.0177
Avg	.3127	.1350	.1506	.4613	.4376	.5328	.0889

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 204 / 11 KV VASAGADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.1326	.1086	.1296	1.4586	1.1603	.9614
2	.1267	.1311	.1097	.1311	1.4251	1.1603	.9724
3	.128	.1311	.1097	.1326	1.4255	1.1469	.8951
4	.1448	.1296	.1086	.1638	1.4419	1.1469	.8383
5	.1829	.1638	.1433	.1638	1.4255	1.1336	.9282
6	.181	.1638	.1772	.1943	1.4419	1.2125	.9389
7	.2012	.1823	.1949	.1989	1.4918	1.3426	1.0774
8	.2195	.1326	.197	.1802	.2534	.1966	.1829
9	1.5927	1.2616	.2458	.1943	.2012	.2195	1.8564
10	1.6289	1.3757	.2984	.2294	.2012	.1989	1.9113
11	1.7924	1.4419	1.5893	.2321		.218	1.9662
12	1.7741	1.7166	1.873	.2347	.2218	.2321	1.9559
13	1.7924	1.7901		.2652	.2172	.2347	1.989
14	1.7372	1.7368		.2515	.2195	.1844	2.2939
15	1.4632	1.6575	1.8187	.2486	.2402	.218	2.332
16	1.4415	1.6385	1.8564	.2683	.2378	.2155	2.3537
17	.1294	.1696	.1311	.2486	.2561		.2149
18	.128	.1612	.1781	.2543	.2587		.2303
19	.1478	.1595	.1802	.2401	.2561		.2686
20	.1829	.1402	.1989		.2587		.2481
21	.1478	.1433	.1966	.2229	.2561	.2401	.181
22	.1311	.124	.1989	1.5089	1.2929		.181
23	.1296	.1086	.1658	1.5089		.9614	.1829
24	.1463	.1311	.1075	.1658	1.4586	1.2071	.9724
Max	1.7924	1.7901	1.873	1.5089	1.4918	1.3426	2.3537
Min	.1267	.1086	.1075	.1296	.2012	.1844	.181
Avg	.6540	.6218	.4631	.3203	.7245	.6647	1.0805

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244063 / 33/11KV KHATAV

Feeder No / Name : 205 / 11 KV PARSHWNATH LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.431	.4973	.4641	.4641
2			.4694	.503	.4694	.4694
3			.4973	.4973	.4858	.4694
4			.503	.503	.4915	.4973
5			.4641	.4641	.4973	.4694
6			.503	.4694	.503	.4641
7						.431
8	.431		.4694	.5544	.503	
9	.503		.4973	.503	.4973	.4973
10	.4973		.503	.4973	.503	.503
11	.4801		.4973	.4973	.4973	.4641
12	.4915		.503	.503	.503	.4588
13	.4973		.4973	.4973	.4973	.4641
14	.4915	.431	.503	.503	.4694	.4641
15	.4973	.503	.503	.4973	.4641	.4588
16	.4534	.426	.4641	.4641	.4694	.4641
Max	.503	.503	.503	.5544	.503	.503
Min	.431	.426	.431	.4641	.4641	.431
Avg	.4825	.4533	.4870	.4967	.4877	.4693

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 201 / 11 KV Tasgaon I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6722				.6722
2			.6413			.6602	.679
3			.6413				.6468
4			.6413				.7545
5		.7468	.679				.7842
6		.7922	.7356				.7922
7	.8402	.8029	.8589	.7655	.7783	.7356	.7762
8	.823	.7468	.7577		.7842	.7421	.7207
9		.7655	.7762				.7421
10		.8326		.6379	.7701		.7682
11		.7316	.7421	.8417	.7499		.8596
12		.7964		.8775	.7783		.7783
13		.788	.8145				.8688
14		.5914			.7602		.8779
15		.8507	.8145	.823	.7783		.8413
16		.9036	1.0059	.6283	.9036		1.0059
17		.9391		.7087			.9214
18		.9492	.8779				.9568
19		1.1273		1.1584			1.2178
20		1.0719	1.0269	1.1273			1.1458
21		.9979	1.0534		.924		1.1273
22		.9522					1.0751
23	.7922	.8215	.8676			.8299	.9242
24	.7356	.7167	.7468	.7167	.7282	.6979	.7167
Max	.8402	1.1273	1.0534	1.1584	.924	.8299	1.2178
Min	.7356	.5914	.6413	.6283	.7282	.6602	.6468
Avg	.7978	.8462	.7974	.8285	.7955	.7331	.8605

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 202 / 11 KV Tasgaon II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6401				.7125
2			.6171			.6171	.6962
3			.6015				.6962
4			.6093				.6859
5		.7628	.6636				.7628
6		.8505	.823				.8495
7	.9492	.9313	.9492	.8954	.8596	.8954	.8505
8	.8063	.8063	.8505		.8322	.7796	.7712
9		.7282	.7265				.7373
10		.7455		.6687	.7537		.7619
11		.788	.7619	.7442	.7108		.788
12		.7442		.7701	.7186		.7537
13		.7108	.7282				.7712
14		.7537			.6062		.815
15		.7202	.7628	.7537	.639		.8328
16		.703	.7888	.7202	.6783		.8417
17		.8059		.7964			.8507
18		.9425	.8779				.9709
19		1.2136		1.1506			1.4335
20		1.2696	1.2136	1.2136			1.3392
21		1.1458	1.1273		1.0608		1.1763
22		1.0029					1.086
23	.7625	.8402	.8139			.7545	.9465
24	.68	.6874	.7287	.6718	.7293	.7287	.7116
Max	.9492	1.2696	1.2136	1.2136	1.0608	.8954	1.4335
Min	.68	.6874	.6015	.6687	.6062	.6171	.6859
Avg	.7995	.8576	.7936	.8385	.7589	.7551	.8684

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 203 / 11 KV WATER SUPPLY

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND

UTILITY

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2715				.2896
2			.2743			.2743	.2957
3			.2743				.3734
4			.2743				.3696
5		.362	.3077				.4066
6		.3696	.3801				.3982
7	.2263	.3258	.2801	.3801	.3582	.3801	.362
8	.2263	.4251	.4163		.4119	.3841	.3982
9		.362	.3801				.3801
10		.362		.2587	.2587		.3439
11		.3258	.3292	.2926	.2402		.2772
12		.3258		.2218	.1334		.1698
13		.3403	.2587				.1698
14		.3544			.2195		.2743
15		.3582	.2263	.3582	.3582		.3109
16		.2743	.3801	.3439	.3544		.2743
17		.3582		.2587			.2896
18		.3258	.3439				.3077
19		.3292		.2587			.0297
20		.3258	.3109	.2241			.3077
21		.1698	.1715		.2561		.1886
22		.1086					.1698
23	.2452	.1886	.1905			.4527	.2743
24	.2743	.3258	.2686	.2858	.2715	.2743	.2957
Max	.2743	.4251	.4163	.3801	.4119	.4527	.4066
Min	.2263	.1086	.1715	.2218	.1334	.2743	.0297
Avg	.2430	.3159	.2966	.2883	.2862	.3531	.2899

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 204 / 11KV NEW TASGAON

INDUSTRIAL FE Feeder KV- 11 /
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0663				.0381
2			.0648			.1494	.0381
3			.0648				.0381
4			.0648				.0381
5		.0381	.0633				.0381
6		.0762	.0633				.0762
7	.016	.0762	.0625	.0663	.0236	.0724	.0754
8	.0579	.1143	.0686		.0183	.0724	.0747
9		.112	.0686				.1063
10		.1075		.1086	.0206		.1509
11		.1448	.0686	.2263	.0221		.1132
12		.1509		.2241	.0934		.1478
13		.112	.0762				.1075
14		.1132			.0934		.2218
15		.1886	.0781	.1494	.0934		.1848
16		.1848	.125	.1524	.112		.1086
17		.1509		.1886			.1867
18		.1509	.1372				.112
19		.112		.1132			.0732
20		.0732	.0914	.0541			.064
21		.0541	.0914		.1494		.064
22		.0267					.0301
23	.0747	.0434	.0754			.0381	.0495
24	.0366	.0953	.0686	.0754	.0126	.1494	.0381
Max	.0747	.1886	.1372	.2263	.1494	.1494	.2218
Min	.016	.0267	.0625	.0541	.0126	.0381	.0301
Avg	.0463	.1063	.0777	.1358	.0639	.0963	.0906

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244086 / 33 / 11 KV TASGAON

Feeder No / Name : 205 / 11 KV NIMANI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1509				.2263
2			.1509				.2614
3			.1509				.2263
4			.1509				.3018
5		.1509	.2263				.3048
6		.1886	.3772				.381
7	.4338	.4481	.3772	.3734	.3429		.3772
8		.3734	.2987		.2263		.3018
9		.2241	.2987				
10		.1463		.1478	.2641		
11		.1478	.3174	.1463	.2829		
12		.1478		.1463	.3206		
13		.1478	.3511				
14		.0739			.3584		.2218
15		.1494	.362	.1478	.362		.2218
16		.1448	.3439	.0747	.2172		.1463
17				.0739			.2149
18		.1494	.3077				.2149
19		.2987		.3326			.3696
20		.3734	.2896	.4108			.4481
21		.3772	.2715		.2829		.3772
22		.3018					.3018
23	.2241	.2263	.2378			.2286	
24		.2286	.2263	.2195	.2286	.2263	.2263
Max	.4338	.4481	.3772	.4108	.362	.2286	.4481
Min	.2241	.0739	.1509	.0739	.2172	.2263	.1463
Avg	.3290	.2262	.2716	.2073	.2886	.2275	.2846

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244087 / 33/11 KV TURACHI

Feeder No / Name : 201 / 11 KV NIMANI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.1334	.0953	1.1401	1.0437	1.0802
2	.0953	.0953	.1143	.0953	1.1401	1.0155	1.0936
3	.0953	.0953	.1143	.0953	1.1142	1.0402	1.0155
4	.0953	.1143	.1334	.0953	1.0883	1.0595	1.0031
5	.1143	.1334	.1524	.1143	1.1336	1.0883	1.0623
6	.1524	.1715	.1715	.1524	1.2125	1.1405	1.0936
7	.1715	.2096	.1715	.2096	1.6263	1.4548	1.2186
8	.1524	.1524	.1524	.1715	.1715	.1524	.1715
9	1.2809	1.406	1.5813	.1715	.1715	.1143	1.9134
10	1.3441	1.439	1.6644	.1715	.1715	.1715	1.9997
11	1.406	1.5023	1.6872	.1905	.1524	.1905	2.0485
12	1.4074	1.4217	1.6918	.1905	.1905	.1715	2.0153
13	1.3592	1.4083	1.7223	.1905	.1905	.1905	1.9271
14	1.1092	1.3441	1.1126	.1715	.1905	.1905	1.8187
15	1.1227	1.3603	1.3904	.1905	.1905	.1905	1.7976
16	1.1405	1.2029	.6249	.2096	.1905	.1905	1.8138
17	.1143	.1524	.0762	.1905	.1905	.1905	.1524
18	.1334	.1524	.1715	.1715	.1715	.1905	.1715
19	.1334	.1524	.1715	.1905	.1715	.1905	.1905
20	.1524	.1905	.1715	.2096	.1715	.1905	.1905
21	.1524	.1905	.1715	.1905	.1715	.1715	.1905
22	.1334	.1715	.1334	1.4083	1.1717	1.1873	.1524
23	.1143	.1334	.1334	1.2944	1.1227	1.1702	.1334
24	.0953	.0953	.1334	.1143	1.166	1.0437	1.1523
Max	1.4074	1.5023	1.7223	1.4083	1.6263	1.4548	2.0485
Min	.0953	.0953	.0762	.0953	.1524	.1143	.1334
Avg	.5071	.5579	.5742	.2619	.6005	.5725	1.0586

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244087 / 33/11 KV TURACHI

Feeder No / Name : 202 / 11 KV TURACHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4793	.5535	.5864	.4172	.0762	.0762	.0953
2	.4527	.4999	.5556	.3894	.0762	.0762	.0762
3	.459	.506	.5624	.3841	.0762	.0762	.0762
4	.4729	.5218	.5468	.3894	.0762	.0762	.0762
5	.4938	.4999	.5624	.4172	.0762	.0953	.0953
6	.5487	.6173	.6249	.4512	.0953	.1143	.0953
7	.7573	.8592	.8697	.578	.1143	.1143	.1143
8	.1143	.1143	.1143	.0762	.0953	.1143	.0953
9	.0953	.0953	.0953	.7819	1.085	1.0595	.0953
10	.0953	.0762	.0953	.8145	1.0688	1.0623	.0953
11	.0762	.0762	.0953	.7819	1.012	1.0623	.0953
12	.0762	.0762	.0762	.7727	.953	1.012	.0953
13	.0762	.0762	.0762	.8124	.9172	.9568	.0953
14	.0762	.0953	.0953	.8642	.8749	.9998	.0953
15	.0762	.0953	.0762	.8745	.8592	.9998	.0953
16	.0953	.0953	.0762	.8583	.9646	.9488	.0953
17	.0953	.0953	.0572	.0953	.0953	.0953	.0953
18	.0953	.0953	.0762	.0953	.1143	.0953	.0953
19	.1143	.1143	.0762	.1143	.1143	.1143	.1143
20	.1334	.1334	.0762	.1143	.1334	.1334	.1143
21	.1143	.1334	.0762	.1143	.1143	.1143	.1143
22	.6483	.7099	.5357	.0953	.1143	.0953	.8642
23	.6167	.6874	.4252	.0762	.0953	.0953	.7935
24	.5144	.5624	.6325	.439	.0762	.0953	.0953
Max	.7573	.8592	.8697	.8745	1.085	1.0623	.8642
Min	.0762	.0762	.0572	.0762	.0762	.0762	.0762
Avg	.2824	.3079	.2943	.4503	.3866	.4035	.1572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244087 / 33/11 KV TURACHI

Feeder No / Name : 203 / 11 KV Dhavali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2858	.3395	.3018	.3018	.2858	.3395
2		.2858	.3206	.2829	.3018	.2858	.3361
3		.2858	.3239	.2829	.3018	.2858	.3174
4		.3048	.3429	.2829	.3018	.2987	.3206
5		.3429	.415	.3018	.3584	.3395	.3511
6		.3881	.5281	.4904	.4755	.4251	.4481
7	.6535	.4755	.6283	.5415	.5973	.5121	.6099
8	.5544	.462	.4805	.4024	.4805	.4024	.4706
9	.3761	.3174	.3403	.3403	.3841	.4075	.3506
10	.3155	.2561	.2804	.3506	.3258	.3077	.3155
11	.3012	.2481	.2915	.2804	.3189	.3467	.2915
12	.2629	.2572	.2572	.2715	.3109	.3294	.2507
13	.2629	.2543	.2374	.2686	.3155	.2743	.2715
14	.2126	.2743		.2328	.3366	.298	.3077
15	.2103	.2804	.2454	.2454	.3155	.3155	.3292
16	.2149	.2743	.3045	.2715	.3189	.3429	.3696
17	.2658	.2804	.3086	.2622	.3258	.3506	.3734
18	.4207	.3086	.2896	.3292	.3403	.3641	.3841
19	.5359	.4706	.4805	.4887	.4755	.6224	.5304
20	.5914	.5359	.5359	.5487	.5544	.6722	.5914
21	.5121	.499	.4854	.4938	.5121	.5788	.5359
22	.4481	.4294	.4294	.4435	.4207	.5041	.4854
23	.3734	.3921	.3584	.3475	.3547	.3696	.4338
24		.2987	.3361	.5111	.3142	.3206	.3511
Max	.6535	.5359	.6283	.5487	.5973	.6722	.6099
Min	.2103	.2481	.2374	.2328	.3018	.2743	.2507
Avg	.3830	.3420	.3721	.3572	.3768	.3850	.3902

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244087 / 33/11 KV TURACHI

Feeder No / Name : 204 / 11 kv RAJAPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6836	.7907	.703	.5287	.0953	.0762	.0762
2	.6516	.7316	.703	.5144	.0953	.0762	.0762
3	.6226	.7186	.68	.5001	.0953	.0572	.0762
4	.6308	.7407	.6722	.5213	.0953	.0762	.0953
5	.6539	.7468	.6401	.5428	.0953	.0953	.1143
6	.6602	.828	.6642	.602	.1143	.1143	.1524
7	1.0242	1.0494	.9602	.7164	.1334	.1524	.1715
8	.0953	.1143	.1524	.1334	.1334	.1524	.1524
9	.0762	.0953	.1143	.9659	1.5424	1.4842	.1143
10	.0762	.0953	.0953	1.1145	1.4899	1.5181	.1334
11	.0572	.0762	.0762	1.0364	1.4232	1.4232	.1143
12	.0572	.0953	.0572	1.0364	1.3435	1.3592	.1143
13	.0572	.0953	.0572	1.0623	1.3123	1.2037	.1143
14	.0381	.0953	.0572	1.1203	1.2651	1.3748	.1143
15	.0381	.0953	.0572	1.1203	1.3435	1.3889	.1143
16	.0762	.0953	.0762	1.1012	1.3441	1.2967	.1524
17	.0953	.0953	.0953	.1905	.0953	.1143	.1524
18	.1334	.0953	.0762	.2286	.0953	.1334	.1524
19	.1143	.0953	.1334	.1334	.0953	.1334	.2286
20	.0953	.1143	.1143	.1143	.1143	.1143	.2477
21	.1143	.1143	.1143	.0953	.1334	.0953	.1905
22	.9686	.8802	.7579	.0953	.0953	.0953	1.3603
23	.9488	.8381	.6516	.0953	.0762	.0953	1.2742
24	.7335	.8592	.759	.5498	.0953	.0762	.0762
Max	1.0242	1.0494	.9602	1.1203	1.5424	1.5181	1.3603
Min	.0381	.0762	.0572	.0953	.0762	.0572	.0762
Avg	.3626	.3981	.3528	.5883	.5301	.5294	.2320

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244091 / 33/11 KV Bhilwadi (Malwadi

)

Feeder No / Name : 201 / 11 KV MALWADI INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY

Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0457	.132	.0259	.0667	.132	.0734	.044
2	.0381	.132	.0457	.06	.132	.0734	.0572
3	.0381	.132	.0457	.06	.1132	.06	.0652
4	.0457	.132	.0457	.06	.1132	.0514	.0457
5	.0412	.132	.0381	.0734	.1132	.0377	.0377
6	.0503	.1698	.0503	.0734	.132	.0377	.0507
7	.0381	.1698	.0429	.084	.132	.0434	.0377
8	.0566	.132	.0429	.044	.132	.0251	.072
9	.0943	.1886	.0943	.0434	.1509	.084	.0894
10	.1509	.1886	.1334	.132	.1094	.1372	.1
11	.1886	.0838	.181	.1886	.104	.2096	.1357
12	.1886	.1467	.1928	.1886	.1949	.1928	.1928
13	.1886	.1315	.1457	.1509	.1696	.2103	.1372
14	.1509	.1467	.1219	.1698	.1406	.1372	.1526
15	.1509	.1928	.1543	.1509	.1753	.1753	.1021
16	.1509	.0789	.1562	.2263	.1067	.0854	.1734
17	.1698	.0943	.1406	.2263	.1219	.1265	.0587
18	.1886	.0617	.0838	.1886	.1219	.1	.0854
19	.1886	.0943	.0587	.1509	.0747	.0894	.0587
20	.1886	.0762	.0734	.132	.0854	.0747	.0667
21	.1886	.0503	.084	.132	.1021	.0747	.0572
22	.132	.0943	.0914	.132	.0894	.1189	.1
23	.132	.0838	.1143	.132	.0894	.044	.0857
24	.0503	.132		.0667	.132	.08	.044
Max	.1886	.1928	.1928	.2263	.1949	.2103	.1928
Min	.0381	.0503	.0259	.0434	.0747	.0251	.0377
Avg	.119	.1240	.0940	.1222	.1237	.0976	.0854

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 244091 / 33/11 KV Bhilwadi (Malwadi

)

Feeder No / Name : 203 / 11 KV MALWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6249	.5658	.6249	.535	.132	.0953	.0953
2	.5428	.5658	.5312	.5117	.132	.0953	.0762
3	.5498	.5658	.503	.5117	.1132	.0953	.0762
4	.5281	.5658	.4694	.5487	.1132	.1143	.0762
5	.4904	.5658	.4904	.5792	.1132	.1524	.1143
6	.5864	.5847	.5401	.6019	.1509	.1715	.1524
7	.7526	.8488	.743	.6405	.1509	.1715	.1715
8	.0953	.132	.1143	.1334	.132	.1334	.1143
9	.0762	.0943	.0762	1.1111	1.7164	1.3904	.0953
10	.0754	.0943	.0762	1.6221	1.5844	1.5524	.0953
11	.0754	.0762	.0953	1.7541	1.7004	1.6032	.0953
12	.0754	.0572	.0953	1.7541	1.5844	1.7166	.0953
13	.0754	.0762	.0953	1.7541	1.6324	1.7284	.0953
14	.0754	.0381	.0953	1.6787	1.6842	1.6324	.1334
15	.0754	.0762	.0953	1.6787	1.5043	1.5203	.1143
16	.1132	.0762	.0953	1.5089	1.3748	1.3279	.1143
17	.132	.0762	.0953	.0943	.0953	.1143	.1143
18	.132	.0762	.1143	.132	.1143	.0953	.1334
19	.132	.1143	.1334	.132	.1334	.1524	.1334
20	.132	.1334	.1334	.132	.1334	.1334	.1334
21	.132	.1143	.1334	.132	.1143	.1334	.1143
22	.7545	.7186	.5864	.132	.1143	.1334	.9962
23	.7545	.7099	.5498	.132	.0953	.0953	.9061
24	.6706	.5658	.6481	.535	.132	.0953	.0953
Max	.7545	.8488	.743	1.7541	1.7164	1.7284	.9962
Min	.0754	.0381	.0762	.0943	.0953	.0953	.0762
Avg	.3188	.3122	.2973	.7644	.6146	.6022	.1809

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 201 / 11 KV ARWADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.7625				.1734
2			.7293			.1638	.1677
3			.7293				.1357
4			.7625				.1387
5		.3887	.7956				.1715
6		.4374	.8619				.2149
7	.081	.7537	1.1603	.9496	.1943	.116	.2058
8	.081	.1658	.1638	.1638	.1638	.1492	.2035
9		.0983	.1638				.1326
10		.1311			1.4918		.1326
11		.2294	.1311	1.643	1.6244		.1326
12		.2652		1.576	1.5238		.1311
13		.2984	.0995				.0983
14		.2652			1.5893		.1311
15		.0983	.1341	1.4089	1.5565		.1326
16		.0983	.1341	1.5089	1.5729		.1326
17		.1638		.176			.1658
18		.1658	.1341				.1658
19		.1989		.2267			.1966
20		.1989	.2204	.2429			.1966
21		.1966	.2204		.16		.1966
22		.8848					1.2929
23	.3605	.8288	.8619			.1734	1.1271
24	.1943	.3932	.8288	.8619	.16	.176	.3467
Max	.3605	.8848	1.1603	1.643	1.6244	.176	1.2929
Min	.081	.0983	.0995	.1638	.16	.116	.0983
Avg	.1792	.3130	.4941	.8758	1.0037	.1557	.2551

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 204 / 11 KV DHAVLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0168				1.0277
2			.024			.9995	.9175
3			.0251				.9282
4			.0251				.9717
5		.1524	.0229				.9831
6		.1905	.0168				1.1469
7	.0251	.1905	.0259	.0983	1.2289	1.326	1.278
8	.0309	.1143	.0396		.0564	.0686	1.4403
9		1.0105	1.0105				1.8244
10		1.1279			.0564		2.1376
11		1.1888	1.3969	.0238	.0564		2.1125
12		1.2346		.0381	.1296		1.9845
13		1.07	1.2717				2.0241
14		1.0562			.1296		1.9292
15		1.07	1.3375	.0347	.1311		1.8976
16		1.0288	1.3375	.0366	.1311		1.2803
17		.0629		.0737			.0583
18		.0492	.1189				.0686
19		.0518		.0629			.0777
20		.0335	.1204	.0419			.0495
21		.0335	.1204		.1475		.0438
22		.0259					.0259
23	.0953	.0217	.0972			1.1012	.0206
24	.02	.1143	.0263	.0972	.9682	1.065	1.0159
Max	.0953	1.2346	1.3969	.0983	1.2289	1.326	2.1376
Min	.02	.0217	.0168	.0238	.0564	.0686	.0206
Avg	.0428	.4914	.3908	.0564	.3035	.9121	1.0518

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 212 / 11 KV NIMANI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.8916				.104
2			.8509			.0972	.0886
3			.8109				.0886
4			.8322				.1086
5		.9393	.8619				.1063
6		.9061	.9031				.1357
7	1.0536	1.0159	1.0974	1.3032	.1052	.0972	.1448
8	.1052	.1311	.1029	.1029	.104	.0972	.1109
9		.1086	.1029				.1109
10		.1109			1.335		.112
11		.1097	.1029	1.6004	1.3523		.1075
12		.1109		1.4548	1.2651		.1097
13		.1097	.1052				
14		.1097			1.3283		.1109
15		.0739	.1052	1.7924	1.3441		.0747
16		.0716	.1052	1.6324	1.3441		.1063
17		.1006		.1006			.0983
18		.1029	.1227				.1296
19		.1075		.1417			.1433
20		.1478	.1094	.1417			.1478
21		.1478	.1094		.096		.1463
22		1.0669					1.2654
23	.8848	1.0235	.8855			.104	1.2193
24	.9332	.852	.9511	1.0279	.0686	.096	.1097
Max	1.0536	1.0669	1.0974	1.7924	1.3523	.104	1.2654
Min	.1052	.0716	.1029	.1006	.0686	.096	.0747
Avg	.7442	.3673	.5028	.9298	.8343	.0983	.2121

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 401 / 33KV Hatnoor

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			2.3765				2.6886
2			2.2634			1.9044	2.4394
3			2.2634				2.6886
4			2.2634				2.7161
5		2.8578	2.6029				2.7161
6		3.0247	2.9424				3.0556
7	2.9424	2.9127	3.0556	2.9938	2.7435	2.2405	2.6886
8	2.6029	2.9424	2.9424		2.8578	1.9044	2.6292
9		2.6029	2.9424				2.4897
10		2.6029		2.3765	2.5149		2.6029
11		2.9424		2.9424	2.6063		2.8292
12		3.0556		3.0247	2.8235		2.8292
13		3.0247	2.8292				2.7161
14		2.7161			2.7721		3.2487
15		3.1687	2.7149	3.0247	2.7721		3.3608
16		3.0247	2.9321	2.8292	2.8829		3.3951
17		3.1367		2.9127			3.2156
18		3.2487	2.7435				3.3608
19		3.8477		3.6969			3.6214
20		3.9609	3.5117	3.6214			3.7346
21		3.5082	3.2922		3.1367		3.3951
22		3.0556					3.2819
23	2.4646	5.0023	2.524			2.8292	3.0556
24	2.1502	2.3525	2.7161	2.4143	2.6029	2.4646	2.6029
Max	2.9424	5.0023	3.5117	3.6969	3.1367	2.8292	3.7346
Min	2.1502	2.3525	2.2634	2.3765	2.5149	1.9044	2.4394
Avg	2.5400	3.1494	2.7598	2.9837	2.7713	2.2686	2.9734

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

TASGAON (II)[078]

BU 1279

Substation No/ Name :- 246005 / 110/33/11 KV TASGAON

Feeder No / Name : 406 / 33 KV Sut Girani

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	1.2731
Max	1.2731
Min	1.2731
Avg	1.2731

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 201 / 11 KV Kasabe Digraj

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5093	.3584	.5093	.3841	.3395	.3395	.3395
2	.5093	.3584	.5093	.3841	.3395	.3395	.3395
3	.547	.3772	.5281	.3841	.3772	.3395	.3395
4	.547	.3772	.5658	.3841	.3772	.3395	.3961
5	.547	.415	.5658	.3841	.3772	.3584	.415
6	.7167	.4715	.547	.4024	.3961	.415	.4338
7	.679	.4527	.6979	.4706	.415	.3961	.3961
8	.6602	.415	.5544	.5731	.3772	.3961	.3584
9	.3961	.3584	.3584	.6089	.6224	.6036	.3584
10	.3292	.4715	.3511	.5544	.5544	.6535	.3961
11	.2561	.6036	.3142	.3142	.5544	.6535	.3395
12	.3696	.5658	.5228		.5729	.5788	.3772
13	.2772	.5658	.3361	.3142	.5544	.5415	.3772
14	.2587	.4715	.5415	.3696	.6099	.5975	.3772
15	.2587	.3584	.5788	.3511	.5228	.5975	.4715
16	.2427	.3584	.5415	.3511	.5914	.5975	.3584
17	.2801	.3772	.3584	.3696	.5041	.5041	.3772
18	.2801	.547	.4805	.2987	.5041	.6036	.6413
19	.547	.7167	.6219	.7282	.6535	.7922	.6979
20	.5847	.811	.5487	.6161	.6722	.7922	.7356
21	.5281	.7167	.6154	.6908	.5601	.679	.5658
22	.4904	.6036	.6335	.5281	.6602	.6413	.6979
23	.3961	.679	.5792	.6036	.4715	.6036	.6413
24	.547	.3584	.3961	.5792	.4338	.3395	.3584
Max	.7167	.811	.6979	.7282	.6722	.7922	.7356
Min	.2427	.3584	.3142	.2987	.3395	.3395	.3395
Avg	.4482	.4912	.5107	.4628	.5017	.5293	.4495

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 202 / 11 KV NANDRE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0754	.0377	.0377	.1417	.1109	.1543
2	.0566	.0754	.0377	.0377	.1417	.1109	.1543
3	.0566	.0754	.0377	.0377	.1417	.1109	.1543
4	.0566	.0754	.0377	.0377	.1417	.1109	.1715
5	.0566	.0754	.0377	.0377	.1417	.1109	.9945
6	.0566	.0754	.0377	.0377	.1595	.1109	.1715
7	.0566	.0566	.0377	.0377	.1772	.1294	.2058
8	.0566	.0754	.0377	.0377	.0566	.0566	.0566
9	.3121	.3113	.3086	.0377	.0566	.0566	.4681
10	.2949	.3113	.3258	.0377	.0747	.0566	.6661
11	.2949	.3113	.3467	.0377	.056	.0566	.6661
12	.2652	.3018	.3467	.0377	.056	.0566	.6836
13	.2818	.3018	.3395	.0377	.056	.0566	.7011
14	.2652	.2915	.3018	.0377	.056	.0566	.7011
15	.2652	.2753	.1509	.0377	.056	.0566	.6836
16	.2652	.2591	.3018	.0377	.056	.0566	.6485
17	.0754	.0377	.0377	.0377	.056	.0566	.0566
18	.0566	.0377	.0377	.0377	.056	.0566	.0566
19	.0754	.0377	.0377	.0377	.056	.0566	.0566
20	.0754	.0377	.0377	.0377	.056	.0566	.0566
21	.0566	.0377	.0377	.0377	.0566	.0566	.0566
22	.0566	.0377	.0377	.1595	.1109	.1543	.0566
23	.0566	.0377	.0377	.1543	.1109	.1543	.0566
24	.0566	.0566	.0377	.9194	.1543	.1109	.1543
Max	.3121	.3113	.3467	.9194	.1772	.1543	.9945
Min	.0566	.0377	.0377	.0377	.056	.0566	.0566
Avg	.1336	.1362	.1260	.0844	.0927	.0836	.3263

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 203 / 11 KV TUNG VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.132	.1509	.1494	.132	.1509	.1509
2	.132	.132	.1509	.1494	.132	.1509	.1509
3	.132	.132	.1509	.1494	.132	.1509	.1509
4	.132	.132	.1509	.1494	.132	.1509	.1698
5	.1509	.1509	.2829	.1494	.1509	.1698	.2829
6	.3018	.3018	.3206	.2987	.2829	.3206	.3206
7	.2829	.3395	.3206	.2957	.3018	.3018	.3018
8	.2452	.3206	.2641	.2378	.2452	.3018	.2829
9	.2075	.2263	.2263	.2378	.2263	.2452	.2452
10	.1848	.2075	.2452	.2263	.2957	.2452	.2263
11	.1848	.2452	.2263	.2075	.2587	.2452	.2263
12	.1848	.1698	.2075	.1886	.2054	.2263	.2075
13	.1663	.2075	.1886	.1886	.2054	.2075	.1698
14	.1848	.1886	.1698	.1509	.1867	.2075	.1698
15	.1478	.1509	.1886	.132	.1494	.1886	.1509
16	.112	.1132	.1698	.0943	.168	.2075	.132
17	.2054	.1886	.1698	.1886	.2241	.2075	.2452
18	.2263	.2452	.1848	.2263	.2241	.2452	.1886
19	.3395	.3206	.2926	.2829	.3206	.3206	.3395
20	.3395	.3206	.3292	.3018	.2829	.3018	.3206
21	.3206	.3206	.3109	.3018	.3018	.2829	.2829
22	.3018	.3018	.2743	.2829	.2829	.2829	.2641
23	.2452	.2452	.2402	.2263	.1886	.2452	.2452
24	.1509	.1509	.1698	.1494	.1509	.1698	.1698
Max	.3395	.3395	.3292	.3018	.3206	.3206	.3395
Min	.112	.1132	.1509	.0943	.132	.1509	.132
Avg	.2088	.2185	.2244	.2069	.2158	.2303	.2248

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 205 / 11 KV TUNG AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377		.0377	.0566	.6167	.6081	.6062
2	.0377		.0377	.0566	.6167	.6081	.6226
3	.0377		.0377	.0566	.6167	.6081	.6226
4	.0377		.0377	.0566	.6167	.6081	.6062
5	.0377		.0377	.0566	.6167	.6081	.6062
6	.0377		.0377	.0566		.6009	.6133
7	.0377		.0377	.0566		.6882	.7127
8	.0377	.0377	.0377	.0566		.0566	.0566
9	1.2616	.4161	1.2548	.0566		.0566	1.6278
10	1.2803	.4641	1.3916	.0566	.0373	.0566	1.8652
11	1.3603	.8482	1.2742	.0566	.0747	.0566	1.95
12	1.3279	1.0814	1.358		.0747	.0566	2.0178
13	1.0562	1.1305	1.1105	.0566	.0747	.0566	1.8778
14	1.0364	.9831	.7956	.0566	.0747	.0566	1.8442
15	.9878	1.0159	.7459	.0566	.0747	.0566	1.7604
16	.9717	.9831	1.0442	.0566	.0747	.0566	1.8107
17	.0566	.0377	.0566	.0754	.0747	.0566	.0566
18	.0566	.0566	.0566	.0754	.0754	.0566	.0754
19	.0377	.0566	.0566	.0754	.0566	.0754	.0754
20	.0377	.0566	.0566	.0754	.0566	.0754	.0754
21	.0566	.0566	.0566	.0566	.0566	.0754	.0754
22	.0566	.0566	.0377		.6882	.6226	.0566
23	.0377	.0377	.0566	.6401	.6401	.6554	.0566
24	.0377	.0566	.0377	.0566	.6167	.6081	.6226
Max	1.3603	1.1305	1.3916	.6401	.6882	.6882	2.0178
Min	.0377	.0377	.0377	.0566	.0373	.0566	.0566
Avg	.4150	.4338	.4038	.0865	.2917	.2944	.8456

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244011 / 33/11 KV KASABE DIGRAJ

Feeder No / Name : 206 / 11 KV Vasant LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0724	.0566	.0754	.0943
2	.0566	.0566	.0724	.0566	.0754	.0943
3	.0566	.0566	.0724	.0566	.0754	.0943
4	.0566	.0566	.0724	.0566	.0754	.0943
5	.0566	.0566	.0724	.1132	.0754	.0943
6	.0566	.0566	.0724	.1509	.0754	.1509
7	.0943	.1886	.1433	.2829	.3018	.2829
8	.132	.2452	.4607	.3584	.2452	.3584
9	.1509	.2452	.3898	.5658	.6036	.5847
10	.1509	.3018	.4715	.5487	.6036	.5658
11	.1509	.2452	.4715	.5487	.6036	.5658
12	.1132	.2452		.5304	.5847	.5658
13	.1132	.0566	.4338	.5304	.547	.5281
14	.1132	.2452	.4527	.5304	.547	.5281
15	.1132	.2452	.4715	.5304	.5281	.5281
16	.1132	.1509	.4715	.5487	.3772	.5658
Max	.1509	.3018	.4715	.5658	.6036	.5847
Min	.0566	.0566	.0724	.0566	.0754	.0943
Avg	.0990	.1568	.2800	.3416	.3371	.3560

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 201 / 11 KV Mouje Digraj

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0019	.0191	.0191	.0191	.0156	.0149	.0154
2	.0019	.0191	.0191	.0191	.0156	.0149	.0151
3	.0019	.0191	.0191	.0191	.0156	.0158	.0151
4	.0019	.0191	.0191	.0191	.0019	.0158	.0151
5	.0019	.0191	.0191	.0191	.0156	.0158	.0151
6	.0019	.0191	.0191	.0191	.0156	.0158	.0151
7	.0019	.0191	.0191	.0191	.0156	.0158	.0151
8	.0019	.0191	.0191	.0191	.0019	.0191	.0191
9	.0312	.029	.0168	.0191	.0019	.0191	.0154
10	.0625	.0343	.0149	.0019	.0191	.0191	.0156
11	.0312	.0347	.0145	.0019	.0191	.0191	.0156
12	.0312	.0339	.0147	.0019	.0191	.0191	.0156
13	.0312	.0343	.0139	.0019	.0191	.0191	.0312
14	.0316	.0351	.0135	.0002	.0191	.0191	
15	.0316	.0351	.0137	.0019	.0191	.0191	.0312
16	.0316	.0354	.0135	.0019	.0191	.0191	.0312
17	.0191	.0191	.0019	.0019	.0191	.0191	.0191
18	.0191	.0191	.0019	.0019	.0191	.0191	.0191
19	.0191	.0191	.0191	.0019	.0191	.0191	.0191
20	.0191	.0191	.0191	.0019	.0191	.0191	.0191
21	.0191	.0191	.0191	.0019	.0191	.0191	.0191
22	.0191	.0191	.0191	.0156	.0149	.0154	.0191
23	.0191	.0191	.0191	.0166	.0149	.0154	.0191
24	.0019	.0191	.0191		.0166	.0149	.0191
Max	.0625	.0354	.0191	.0191	.0191	.0191	.0312
Min	.0019	.0191	.0019	.0002	.0019	.0149	.0151
Avg	.0180	.0241	.0161	.0094	.0156	.0176	.0189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 203 / 11 kv PWV Bramhnal

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 11 / OUTGOING

UTILITY

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1907	.1715	.0021	.1829	.1949	.2149	.032
2	.1907	.1715	.0023	.1829	.1949	.2149	.1307
3	.1907	.2601	.0554	.2353	.1949	.3366	.1307
4	.1907	.2601	.0554	.2353	.1949	.3366	.1307
5	.1907	.2601	.0554	.2427	.1949	.3366	.1307
6	.2427	.2601	.0934	.2427	.1949	.3366	.1307
7	.2427	.2947	.0934	.2572	.2835	.3366	.1307
8	.2481	.2947	.128	.3155	.2835	.0381	.1478
9	.2481	.298	.128	.3366	.2896	.1307	.1478
10	.0754	.2835	.1494	.3584	.1132	.3189	.1463
11	.0754	.2835	.1494	.3584	.1294	.3366	.1463
12	.0943	.2835	.1494	.2454	.1294	.3366	.1463
13	.0943	.2835	.0377	.2454	.0732	.3366	.0747
14	.0747	.2149	.0566	.2427	.0732	.3366	.1494
15	.0747	.2149	.0566	.2427	.0739	.3366	.0747
16	.0747	.2149	.0566	.0747	.0739	.3366	.0747
17	.0017	.056	.0754	.2204	.2427	.0354	.0747
18	.0015	.056	.0754	.1865	.2427	.0354	.0747
19	.0015	.056	.1494	.1865	.2427	.0354	.0019
20	.0015	.0747	.1494	.1865	.2149	.0328	.0019
21	.0015	.0747	.168	.1865	.2149	.0328	.0019
22	.1715	.0023	.1829	.1928	.2149	.032	.0019
23	.1715	.0023	.1829	.1886	.2149	.032	.0019
24	.1907	.0023	.1829		.1886	.2149	.0019
Max	.2481	.298	.1829	.3584	.2896	.3366	.1494
Min	.0015	.0023	.0021	.0747	.0732	.032	.0019
Avg	.1267	.1822	.1015	.2325	.1862	.2113	.0869

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 204 / 11 KV Express LIS Feeder

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0002	.004	.0038	.0943	.2452	.2263
2	.0002	.004	.0038	.0943	.2452	.2263
3	.0002	.004	.0038	.0943	.2452	.2263
4	.0002	.004	.0038	.0943	.2452	.2263
5	.0002	.004	.0042	.0943	.2452	.2263
6	.0002	.004	.0042	.0943	.2452	.2263
7	.0695	.2347	.0042	.2263	.2452	.2263
8	.0695	.2347	.0549	.2263	.0006	.2957
9	.0667	.2012	.1829	.2263	.0011	.2957
10	.1372	.0743	.2263	.2957	.3142	.2987
11	.1387	.0724	.2263	.2957	.3142	.3174
12	.1357	.0734	.2263	.2957	.3142	.2987
13	.1372	.013	.2263	.2926	.3174	.2987
14	.0351	.0676	.2263	.2926	.3174	.2987
15	.0354	.0686	.2263	.2926	.3174	.2987
16	.0358	.0676	.2263	.2926	.2987	.2987
Max	.1387	.2347	.2263	.2957	.3174	.3174
Min	.0002	.004	.0038	.0943	.0006	.2263
Avg	.0539	.0707	.1156	.2064	.2445	.2678

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 205 / 11 KV Yeshwant Express

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3544	.5316	.815	.8505	.8859	1.0631
2	.3544	.5316	.815	.8505	.8859	1.0631
3	.3544	.567	.815	.8505	.8859	1.0631
4	.3544	.567	.8859	.8505	.8859	1.0631
5	.6379	.6024	.8682	.8505	1.2403	1.0631
6	.6379	.8859	.8682	.8505	1.2403	1.0631
7	.7796	.8859	.7265	.8505	1.2403	1.2757
8	.8859	.9922	1.0099	1.0277	1.382	1.4883
9	1.0277	.9922	.9922	1.134	.9568	1.5238
10	1.0745	1.0985	.9922	.8505	1.5223	1.5238
11	1.0745	1.1694	.815	1.2757	1.5043	1.5238
12	1.0745		.815	1.2757	1.5402	1.4883
13	1.086	.9214	.815	1.3466	1.5402	1.4883
14	1.0974	1.134	.7619	1.3466	1.5402	1.4883
15	1.0974		.8505	1.3466	1.5402	1.5238
16	1.0974	.6024	.6733		1.2757	1.0277
Max	1.0974	1.1694	1.0099	1.3466	1.5402	1.5238
Min	.3544	.5316	.6733	.8505	.8859	1.0277
Avg	.8118	.8201	.8449	1.0371	1.2542	1.2957

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244032 / 33/11 KV BRAMHNAL

Feeder No / Name : 206 / 11 KV NAWARASWADI

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1991	.1753	.2629	.2835	.4961	.2715
2	.1991	.1753	.2629	.2835	.4961	.2715
3	.1991		.2629	.2835	.4961	.2715
4	.1991		.2658	.2835	.4961	.2715
5	.1991		.2658	.2835	.4961	.2715
6	.1991		.3012	.2865	.4961	.2715
7	.2534		.3012	.2865	.4961	.2715
8	.1991		.3045	.3582	.3544	.2715
9	.1991		.3403	.3582	.2303	.2534
10	.2172		.2328	.0191	.1928	.2507
11	.2172		.2328	.2241	.1928	.2507
12	.2172		.2328	.2241	.3366	.2481
13	.2195	.1791	.0019	.2241	.3366	.2507
14	.0549	.3982	.3544	.2241	.3544	.2507
15	.0549	.2149	.2865	.2241	.3544	.2507
16	.0549	.2172	.2149	.2241	.2507	.0019
Max	.2534	.3982	.3544	.3582	.4961	.2715
Min	.0549	.1753	.0019	.0191	.1928	.0019
Avg	.1801	.2267	.2577	.2544	.3797	.2456

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244037 / 33/11 KV PRAKASH AGRO

Feeder No / Name : 201 / 11 KV Haripur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.3658	.3269	.3353	.0179	.0189	.0189
2	.5556	.3658	.3269	.3201	.0181	.0189	.0187
3	.571	.3658	.3081	.3161	.0181	.0189	.0187
4	.5639	.3506	.3041	.3311	.0181	.0189	.0187
5	.5487	.3353	.3081	.3161	.0181	.0189	.0191
6	.5693	.3506	.3311	.3241	.0185	.0189	.0191
7	.5506	.3749	.3749	.3549	.0156	.0189	.0189
8	.0189	.0175	.0154	.0189	.0168	.0189	.0189
9	.0189	.0162	.0152	.5921	.8745	.9717	.0187
10	.0181	.0168		.5937	.8907	1.0814	.0189
11	.0181	.0171	.0189	.68	1.0202	1.094	.0189
12	.0183	.0168	.0189	.6327	1.0526	1.094	.0189
13	.0183	.0152	.0189	.7655	1.0402	1.1142	.0189
14	.0185	.0156	.0189	.7748	1.0688	1.0688	.0189
15	.0156	.0168	.0189	.7682	1.0364	1.0526	.0189
16	.0183	.0152	.0189	.7449	.9922	.9922	.0189
17	.0164	.016	.0189	.0149	.0189	.0164	.0189
18	.0131	.0162	.0189	.0259	.0189	.0152	.0189
19	.0185	.0179	.0189	.0162	.0189	.0181	.0189
20	.0171	.0177	.0189	.0158	.0189	.0181	.0189
21	.017	.0171	.0189	.017	.0189	.0181	.0189
22	.4012	.3704	.3506	.0175	.0189	.0189	.7125
23	.381	.3658	.3311	.0181	.0189	.0187	.6718
24	.571	.3658	.3658	.3353	.0179	.0189	.0189
Max	.571	.3749	.3749	.7748	1.0688	1.1142	.7125
Min	.0131	.0152	.0152	.0149	.0156	.0152	.0187
Avg	.2294	.1601	.1550	.3471	.3445	.3651	.0750

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 201 / 11 kv Dudhgaon AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3637	.2572	.2743	.2785	.0171	.0173	.0173
2	.3437	.2538	.2429	.2785	.0171	.0175	.0175
3	.3281	.2538	.2494	.2785	.0175	.0171	.0177
4	.3437	.2606	.2378	.2785	.0173	.0175	.0175
5	.3281	.0145	.2408	.2785	.0171	.0179	.0177
6	.3361	.2408	.2286	.2622	.0183	.0179	.0175
7	.3277	.2439	.2397	.2785	.0171	.0179	.0177
8	.0177	.0173	.0183	.0133	.0168	.0171	.0175
9	.0158	.0173	.0173	.4752	.6009	.6722	.0175
10	.017	.0171	.0133	.6722	.6562	.6722	.0133
11	.0171	.016	.0133	.6722	.6964	.7125	.0133
12	.0171	.0158	.0133	.6722	.7362	.7042	.0133
13	.0175	.0156	.0133	.6722	.7362	.6642	.0133
14	.0171	.0145	.0133	.6802	.7373	.6401	.0133
15	.0152	.0143	.0133	.6154	.7287	.6009	.0133
16	.0152	.0143	.0133	.6154	.6882	.5851	.0133
17	.016	.0151	.0133	.0162	.016	.0171	.0133
18	.0171	.0162	.0133	.016	.016	.0175	.0133
19	.0168	.0177	.0133	.017	.0171	.0179	.0133
20	.0173	.0175	.0133	.017	.0179	.0183	.0133
21	.0171	.0175	.0133	.0173	.0183	.0185	.0133
22	.3479	.2968	.2622	.0171	.0181	.0175	.4424
23	.3311	.2968	.2785	.0171	.0175	.0171	.426
24	.3725	.2972	.286	.2785	.0173	.0175	.0171
Max	.3725	.2972	.286	.6802	.7373	.7125	.4424
Min	.0152	.0143	.0133	.0133	.016	.0171	.0133
Avg	.1524	.1101	.1140	.3091	.2440	.2305	.0501

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 202 / 11 KV Kavathe Piran
Village Feeder KV- 11 /
OUTGOING

GAOTHAN FEEDER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.2614	.2641	.2801	.2829	.2858	.2801
2	.2641	.2641	.2614	.2801	.2801	.2641	.2614
3	.2641	.2641	.2614	.2801	.2829	.2667	.2641
4	.2829	.2641	.2641	.2801	.2829	.2829	.2614
5	.3239	.3018	.3361	.2801	.2987	.3048	.3772
6	.4382	.415	.5093	.4668	.4108	.3772	.4715
7	.4904	.4527	.4904	.4668	.415	.4527	.4527
8	.4715	.3361	.415	.3734	.3734	.415	.415
9	.3206	.2987	.3018	.2987	.2641	.3018	.3174
10	.2587	.2926	.2801	.2641	.2743	.2772	.2987
11	.2263	.2957	.2801	.2641	.2402	.2801	.2801
12	.2241	.2772	.2801	.2263	.2587	.2587	.2641
13	.1494	.2772	.2801	.2614	.2241	.2614	.2452
14	.1867	.2614	.2801	.2241	.2801	.2614	.2452
15	.1867	.2402	.2241	.2263	.2427	.2772	.2452
16	.2241	.2241	.1867	.2263	.2452	.2957	.2452
17	.2263	.2829	.2241	.2614	.2801	.3361	.2801
18	.2641	.3547	.3361	.2614	.2896	.3547	.3361
19	.4108	.4904	.4108	.415	.4294	.3547	.4668
20	.4481	.4854	.5228	.4527	.4668	.4715	.4668
21	.4481	.4715	.5041	.4904	.4338	.4715	.4294
22	.415	.4715	.4108	.4108	.415	.3734	.4108
23	.3361	.3961	.3547	.3361	.3206	.3395	.3361
24	.2829	.2614	.3395	.2801	.2987	.3018	.3018
Max	.4904	.4904	.5228	.4904	.4668	.4715	.4715
Min	.1494	.2241	.1867	.2241	.2241	.2587	.2452
Avg	.3094	.3308	.3341	.3169	.3163	.3277	.3314

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 203 / 11 KV Kavathe Piran Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516		.4915	.5658	.0091	.012	.012
2	.6687		.4915	.5658	.0093	.012	.0122
3	.6516		.4973	.5658	.0091	.012	.0124
4	.6344		.4752	.5658	.0095	.0122	.0126
5	.6516		.4807	.5658	.0095	.0124	.0122
6	.6344		.4807	.6173	.0105	.0124	.0118
7	.6344		.3932	.6173	.0097	.012	.0126
8	.0095		.0091	.0114	.0095	.0114	.0126
9	.0095		.009	.9431	.9835	1.0513	.0116
10	.0088	.009	.0114	.9945	1.0343	1.0513	.0114
11	.0095	.0091	.0114	1.0513	1.0513	1.0631	.0114
12	.0097	.0093	.0114	1.0174	1.0513	1.0513	.0114
13	.0095	.0093	.0114	.9945	1.0174	1.0288	.0114
14	.0095	.0091	.0114	.9054	1.0288	1.0402	.0114
15	.0095	.009	.0114	.9945	.9835	1.0229	.0114
16	.0091	.009	.0114	.9945	.9602	1.0056	.0114
17	.0095	.0093	.0114	.0095	.0114	.0114	.0114
18	.0095	.0091	.0114	.0099	.0118	.0116	.0114
19	.0097	.0091	.0114	.0097	.0118	.0118	.0114
20	.0095	.0093	.0114	.0095	.0118	.012	.0114
21	.0095	.0095	.0114	.0095	.0118	.012	.0114
22	.583	.5765	.6001	.0097	.0118	.0122	.6859
23		.5935	.583	.0095	.0116	.0124	.6516
24	.6687		.547	.5658	.0091	.012	.0114
Max	.6687	.5935	.6001	1.0513	1.0513	1.0631	.6859
Min	.0088	.009	.009	.0095	.0091	.0114	.0114
Avg	.2570	.0914	.2165	.5251	.3449	.3544	.0665

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 204 / 11 KV samdoli Village

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.16	.1658	.156	.2054	.1844	.1844	.1734
2	.144	.1492	.156	.2054	.1696	.2035	.1734
3	.144	.1509	.156	.2054	.1677	.1844	.1753
4	.1619	.1658	.1715	.2054	.1677	.1638	.1753
5	.176	.1844	.1715	.2054	.1865	.1781	.1772
6	.2486	.1928	.2401	.2427	.2254	.1886	.2103
7	.2481	.1772	.2058	.2241	.2172	.2195	.2328
8	.2149	.1448	.2172	.1867	.181	.181	.181
9	.1772	.1848	.2012	.168	.1646	.1829	.1867
10	.1433	.1867	.1867	.128	.1663	.1848	.1867
11	.168	.1886	.1867	.1867	.2033	.1867	.1867
12	.1867	.1886	.1867	.2054	.181	.168	.1867
13	.1494	.1886	.1867	.168	.1791	.1663	.1867
14	.1494	.1848	.1867	.1494	.156	.168	.1867
15	.168	.1867	.1867	.1463	.1595	.1698	.1867
16	.1663	.1848	.1867	.168	.1791	.1867	.1867
17	.1646	.2507	.2054	.1867	.2012	.2195	.2241
18	.1829	.3012	.2614	.1886	.2241	.2772	.2427
19	.2896	.3189	.3361	.2987	.2896	.3045	.3174
20	.3361	.3366	.3547	.3361	.3045	.3012	.3361
21	.3361	.333	.3547	.3361	.3012	.298	.3361
22	.2629	.3155	.2987	.3012	.2804	.2743	.2987
23	.2229	.2743	.2427	.2427	.2401	.2347	.2801
24	.16	.1844	.1715	.2054	.2058	.2035	.2058
Max	.3361	.3366	.3547	.3361	.3045	.3045	.3361
Min	.1433	.1448	.156	.128	.156	.1638	.1734
Avg	.1984	.2141	.2170	.2123	.2056	.2096	.2181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 205 / 11 KV Samdoli Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0189	.0189	.0189	.3772	.4668	.5281
2	.0191	.0189	.0189	.0189	.3772	.4481	.5281
3	.0191	.0189	.0189	.0189	.3772	.4294	.5281
4	.0191	.0189	.0189	.0189	.3772	.415	.5281
5	.0191	.0189	.0189	.0189	.3772	.4338	.5281
6	.0191	.0189	.0189	.0189	.3772	.4715	.5281
7	.0191	.0189	.0189	.0189	.415	.5093	.5658
8	.0191	.0189	.0171	.0189	.0189	.0191	.0189
9	1.0374	1.1203	1.0751	.0189	.0189	.0191	1.2826
10	1.0562	1.1883	1.0751	.0189	.0191	.0189	1.4712
11	1.094	1.226	1.0751	.0189	.0191	.0189	1.5089
12	1.1317	1.1317	.9808	.0189	.0191	.0189	1.4712
13	1.1317	1.0562	.9431	.0189	.0191	.0189	1.4335
14	1.0562	1.0185	.8488	.0189	.0191	.0189	1.4146
15	.9808	.9997	.6979	.0189	.0191	.0189	1.3957
16	.9054	.9808	.7167	.0189	.0191	.0189	1.3769
17	.0189	.0189	.0189	.0189	.0191	.0189	.0189
18	.0189	.0189	.0189	.0189	.0191	.0189	.0189
19	.0189	.0189	.0189	.0189	.0191	.0189	.0189
20	.0189	.0189	.0189	.0189	.0191	.0189	.0189
21	.0189	.0189	.0189	.0189	.0191	.0189	.0189
22	.0189	.0189	.0189	.415	.4715	.547	.0189
23	.0189	.0189	.0189	.415	.4854	.5281	.0189
24	.0191	.0189	.0189	.0189	.3772	.4854	.5281
Max	1.1317	1.226	1.0751	.415	.4854	.547	1.5089
Min	.0189	.0189	.0171	.0189	.0189	.0189	.0189
Avg	.3624	.3760	.3214	.0519	.1783	.2083	.6570

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 206 / 11 KV Shaurya Industries NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0171	.0171	.0343	.0343	.0514	.0171
2	.0686	.0343	.0171	.0343	.0343	.0514	.0171
3	.0191	.0343	.0171	.0343	.0343	.0686	.0171
4	.0686	.0343	.0171	.0343	.0343	.0686	.0171
5	.0686	.0343	.0171	.0343	.0724	.0686	.0171
6	.0686	.0343	.0171	.0343	.0724	.0686	.0171
7	.0686	.0343	.0171	.0514	.0724	.0686	.0171
8	.0686	.0343	.0171	.0686	.0724	.0686	.0171
9	.0686	.0724	.0171	.0686	.0724	.0686	.0171
10	.0716	.0686	.0514	.0716	.0686	.0686	.0514
11	.0724	.0686	.0514	.0905	.0686	.0686	.0514
12	.0724	.0686	.0514	.0905	.0686	.0857	.0514
13	.0724	.0857	.0514	.0905	.0686	.0686	.0686
14	.0724	.0857	.0514	.0914	.0686	.0686	.0514
15	.0343	.0686	.0686	.0934	.0686	.0686	.0514
16	.0343	.0514	.0686	.0934	.0686	.0686	.0514
17	.0171	.0686	.0686	.0343	.0686	.0343	.0514
18	.0343	.0686	.0686	.0343	.0686	.0343	.0514
19	.0724	.0686	.0686	.0343	.0686	.0343	.0514
20	.0747	.0171	.0686	.0724	.0686	.0171	.0514
21	.0747	.0171	.0686	.0343	.0686	.0171	.0514
22	.0739	.0171	.0686	.0343	.0686	.0171	.0686
23	.0343	.0171	.0686	.0343	.0686	.0171	.0686
24	.0686	.0171	.0171	.0686	.0343	.0686	.0171
Max	.0747	.0857	.0686	.0934	.0724	.0857	.0686
Min	.0171	.0171	.0171	.0343	.0343	.0171	.0171
Avg	.0603	.0466	.0436	.0568	.0622	.0550	.0393

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244065 / 33/11 KV KAVATHE PIRAN

Feeder No / Name : 207 / 11 kv warana kath ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.4024	.2214	.2785			
2	.5144	.3688	.2187	.2785			
3	.5144	.373	.216	.2785			
4	.4458	.3429	.2187	.2785			
5	.3772	.3391	.2006	.2785			
6	.3429	.2984	.1698	.2458			
7	.5144	.2984	.1635	.2622			
9				.4915	.5365	.7373	
10				.57	.6687	.7373	
11				.5967	.6859	.7125	
12				.6173	.7373	.7461	
13				.6036	.7716	.6554	
14				.6371	.7888	.6316	
15				.6516	.7373	.639	
16				.6036	.6859	.6154	
22	.4359	.2915	.2984				.4372
23	.4359	.2561	.2818				.421
24	.5144	.3978	.25	.2818			
Max	.5144	.4024	.2984	.6516	.7888	.7461	.4372
Min	.3429	.2561	.1635	.2458	.5365	.6154	.421
Avg	.4610	.3368	.2239	.4346	.7015	.6843	.4291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 201 / 11 KV Budhgaon Village

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6584	.6001	.5571	.6783	.7164
2	.663		.6697	.6001	.5344	.6783	.6878
3			.6878	.5144	.5182	.6783	.6878
4	.5801		.695	.5144	.5243	.5935	.6068
5		.4096	.6838	.5144	.5304	.5935	.6401
6		.5138	.6838	.4287	.5571	.5087	.6878
7	.5801	.5898	.6878	.4287	.6062	.5087	.7468
8		.5571	.6089		.5898	.4287	.5668
9	.4973	.6154		.4668	.6133	.4144	.7468
10	.4096	.6722	.5138	.5898	.5967	.5144	
11	.4096		.4973	.6154	1.5912	.6935	.639
12	.3481	.5914	.4641	.5571	.5967	.7468	
13	.3277		.4801	.4424	.4641	.6661	.4752
14	.3441			.4534	.4973	.6241	
15	.3149			.4588	.5304	.631	
16	.3277	.6001	.4115	.5898	.4641	.6001	.6133
17	.3113		.5144	.6154	.4641	.6762	
18	.4144	.6001	.5144	.6554	.4973	.7888	
19	.639	.7202	.7202	.7611	.6962	.8059	
20	.6718		.7202	.8029	.7956	.8413	
21	.6796	.7682	.6859			.823	
23	.5243		.7459	.6882	.7956		
24	.7293	.4475	.695	.6859	.5735	.8048	.7164
Max	.7293	.7682	.7459	.8029	1.5912	.8413	.7468
Min	.3113	.4096	.4115	.4287	.4641	.4144	.4752
Avg	.4873	.5905	.6169	.5706	.6179	.6499	.6562

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 202 / 11 KV Kaleran (Kavalpur) SEPARATED AG FEEDERS HAVING SPECIAL
AG Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0549	.0497	.426	.3315	.4801
2	.0663		.0554		.4049		1.1523
3			.0549	.0497	.4096	.3315	.5182
4	.0663		.0701		.4049		.5182
5		.0492	.0543	.0497	.4049	.4144	.5506
6		.0648	.0701		.4696	.4144	.5441
7	.0663	.0972	.0686	.0497	.5668	.4144	.6173
8		.0655			.0492	.0497	.0732
9	.663	.583	.0686	.0497	.0492	.0497	1.0802
10	.5571	.7499	.6554	.0492		.0549	
11	.5506		.663	.0648	.0497	.0554	1.0608
12	.583	.6962	.7293	.0648	.0497	.056	
13	.5898		.7293	.0648	.0492	.037	1.0159
14	.5571			.0655	.0497	.056	
15	.5506			.0648		.0566	
16	.583	.6554	.663	.0648	.0497	.056	1.0608
17	.0328		.0497	.0819	.0497	.0857	
18	.0486	.0373	.0497	.0648	.0663	.0686	
19	.0648			.0819	.0497	.0537	
20	.0655			.0648	.0497	.0724	
21	.0648	.0373	.0497			.0934	
22	.0648						
23	.0492		.0497	.4534	.5801		
24	.0663	.0486	.0554	.056	.4534	.3315	.4801
Max	.663	.7499	.7293	.4534	.5801	.4144	1.1523
Min	.0328	.0373	.0497	.0492	.0492	.037	.0732
Avg	.2784	.2804	.2328	.0828	.2341	.1541	.7040

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 203 / 11 KV Bisur village

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1463	.2058	.1494	.2572	.2149
2	.2743		.1463	.2058	.1307	.2572	.2172
3			.1646	.1867	.1307	.2572	.2172
4	.2195		.1629	.1867	.1494	.1715	.2126
5		.168	.1829	.1715	.168	.1715	.2149
6		.2241	.2172	.1867	.2054	.1715	.2126
7	.2195	.2241	.2195	.1715	.2241	.1715	.2353
8		.2241	.2195		.2054	.1715	.208
9	.1829	.168		.2241	.1494	.1867	.112
10	.1307	.1463	.1494	.112	.1494	.1867	
11	.0934		.1463	.1494	.1478	.1132	.132
12	.0934	.1109	.1494	.0934	.1478	.112	
13	.0934		.1494	.0934	.1494	.1109	.1132
14	.0934			.0934	.1867	.0934	
15	.0934			.0934	.1867	.0732	
16	.0934	.0914	.1867	.0934	.1848	.056	.132
17	.112		.1867	.0934	.1867	.1097	
18	.1307	.112		.112	.1867	.1663	
19	.2427	.168		.2241	.2241	.2241	
20	.2614			.2614	.2801	.2195	
21	.2614	.2172	.1867			.2172	
22	.2427						
23	.1867		.2058	.168	.2801		
24	.2743	.1494	.1463	.2058	.1494	.2572	.2172
Max	.2743	.2241	.2195	.2614	.2801	.2572	.2353
Min	.0934	.0914	.1463	.0934	.1307	.056	.112
Avg	.1736	.1670	.1745	.1587	.1806	.1707	.1876

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 204 / 11 KV Budhgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1852	.2543	.0486	.0497	.0543
2	.1326		.1875	.2801	.0486	.0497	.0543
3			.2006	.2543	.0492		.0543
4	.1326		.2031	.2035	.0486	.0497	.0543
5		.1296	.2031	.1867	.0486		.0543
6		.1457	.2429	.1867	.0486		.0549
7	.1326	.2267	.2294	.1867	.0492	.0497	.0747
8		.0492			.0486	.0497	.056
9	.0497	.0486	.0514	.2984	.4372	.3429	.056
10	.0486	.0543	.056	.4372	.4049	.463	
11	.0328		.0514	.4696	.4144	.5312	.0486
12	.0486	.0549	.0514	.4424	.4049	.5093	
13	.0486		.056	.4534	.4049	.4999	.0486
14	.0328	.0543		.421	.3563		
15	.0328			.4372	.3563	.4801	
16	.0324	.0543	.0497	.4424		.4696	.0492
17	.0486		.0554	.0486	.0663	.0543	
18	.0492	.0362	.0497	.0486	.0663	.0543	
19	.0486	.0554	.0509	.0486	.0663	.0543	
20	.0486		.0497	.0486	.0663	.0747	
21	.0648	.056	.0663			.0537	
22	.1475						
23	.1781		.2486	.0486	.0663		
24	.1326	.1619	.1562	.2486	.0492	.0663	.0543
Max	.1781	.2267	.2486	.4696	.4372	.5312	.0747
Min	.0324	.0362	.0497	.0486	.0486	.0497	.0486
Avg	.0759	.0867	.1222	.2593	.1690	.2168	.0549

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 205 / 11 KV Express college
feeder Feeder KV- 11 /
OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0876	.112	.1509	.0686	.0895
2	.112		.0895	.112	.1509	.0686	.0934
3			.0905	.112	.1509	.0686	.0716
4	.112		.0732	.112	.1509	.0686	.0716
5		.1509	.0732	.1029	.1509	.1029	.0724
6		.1509	.0724	.1029	.1509	.1029	.0724
7	.1494	.0754	.0732	.1029	.1509	.1029	.0724
8		.0754	.0732		.1509	.0857	.112
9	.112	.1886			.1698	.0857	
10	.2075	.1886	.112	.2263	.1494	.0857	
11	.1132		.1494	.2263	.0924	.0857	.168
12	.1132	.1086	.1494	.132	.0934	.1097	
13	.132		.1494	.2263	.0924	.1478	.168
14	.1132	.1134		.2263	.0934	.1478	
15	.1132			.2263	.0924	.0747	
16	.0943	.12	.112	.2075	.0934	.1494	.168
17	.0943		.112	.0943	.0924	.1109	
18	.0943	.0739		.0754	.0924	.0934	
19	.0754	.0739		.1698	.0924	.0686	
20	.0754			.1698	.0924	.0724	
21	.0754	.0747	.1029			.0716	
22	.0754						
23	.1509		.0103	.1509	.0857		
24	.112	.1509	.0867	.1029	.1509	.0857	.0895
Max	.2075	.1886	.1494	.2263	.1698	.1494	.168
Min	.0754	.0739	.0103	.0754	.0857	.0686	.0716
Avg	.1118	.1189	.0951	.1495	.1223	.0935	.1041

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 207 / 11 KV Jyptirling LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0895	.0686	.1886	.1372	.2058
2		.0905	.0686	.1886	.1372	.2172
3		.0716	.0857	.1886	.1372	.2801
4		.0716	.0857	.1886	.1372	.2601
5	.1132	.0886	.0934	.2263	.4287	.2572
6	.0754	.0943		.2263	.1372	.2572
7	.0754	.0857	.0934	.1509	.1372	.2572
8	.0754	.1075		.2263	.1372	.0137
9	.0754	.1075	.0934	.2829	.1494	.2401
10	.128		.2075	.1867		
11		.1326	.2075	.1867	.2195	.2829
12	.1463		.1509	.1867	.2715	
13		.1494	.2075	.1494	.2601	.2829
14	.1612		.132	.1509	.2829	
15			.2829	.1509	.2743	
16	.1543	.112	.2829	.0995	.2926	.3018
Max	.1612	.1494	.2829	.2829	.4287	.3018
Min	.0754	.0716	.0686	.0995	.1372	.0137
Avg	.1116	.1001	.1471	.1861	.2093	.2380

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 208 / 11 KV Bisur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0549	.0497	.4344	.3763	.6535
2	.0497		.0554	.0497	.3909	.3763	.5182
3			.0747	.0497	.3668	.462	.5668
4	.0497		.0739	.0497	.362	.301	.5468
5		.0579	.0747		.362	.301	.5401
6		.0714	.0747		.4108	.301	.5468
7	.0497	.0579	.0747	.0497	.4633	.2972	.5668
8		.0579	.0739		.0434	.0452	
9	.6299	.6081		.0497	.044	.0497	.6874
10	.5647	.7773	.6554	.044	.0446	.0857	
11	.5135		.7842	.0434	.044	.0943	.8916
12	.5068	.6944	.6962	.0434	.044	.0549	
13	.5068		.6882	.044	.0492	.0554	1.0105
14		.6964		.0434	.0492	.056	
15				.0434	.0492	.0549	
16		.7287	.663	.0434	.0492	.0549	.8509
17			.0497	.0293	.0446	.0732	
18	.0587	.0351		.0869		.0747	
19	.0579	.0732		.0579	.0434	.0934	
20	.0579			.0579	.0434	.0924	
21	.0587	.0747	.0497			.0934	
22	.0587						
23	.0434		.0497	.4778	.4458		
24	.0497	.0434	.0554	.0497	.4694	.4144	.5247
Max	.6299	.7773	.7842	.4778	.4694	.462	1.0105
Min	.0434	.0351	.0497	.0293	.0434	.0452	.5182
Avg	.2171	.3059	.2499	.0717	.2026	.1731	.6587

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244068 / 33/11 KV BUDHGAON

Feeder No / Name : 401 / 33 kv sherinala

Feeder KV- 33 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0366	.0448	.0444		.0366
2			.0366		.0439	.0448	.0366
3			.0366		.0444		.0366
4			.0366	.0336	.0439	.0504	.0366
5		.0444	.0366		.0439		.0366
6		.0444	.0366		.0444	.0504	.0366
7	.0504	.0439	.0366	.0448	.0439	.0504	.0366
8		.0494	.0412		.0439		.0366
9	.0509	.0439		.0448	.0439	.005	.0366
10	.0439	.0366		.0444			
11	.0444			.0439		.0412	
12	.0439	.0384	.0448	.0439		.0463	
13	.0444		.0448	.0439		.0463	
14		.0366		.0439		.0412	
15	.0439			.0439		.0463	
16	.0444	.0366	.0448	.0439		.0366	
17	.0444			.0439			
18	.0499	.0366		.0439		.0366	
19	.0494	.0366		.0439		.0384	
20	.0494			.0444	.0448	.0366	
21	.0494	.0366	.0412			.0389	
22	.0439		.0416				
23	.0439			.0444	.0448		
24	.0448	.0494	.0366	.0504	.0444	.0504	.0412
Max	.0509	.0494	.0448	.0504	.0448	.0504	.0412
Min	.0439	.0366	.0366	.0336	.0439	.005	.0366
Avg	.0463	.0410	.0394	.0439	.0442	.0412	.0371

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 201 / 11 kV Dudhgaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2427	.2427	.2801	.2614	.2667	.2477	.2801
2	.2427	.2427	.2801	.2427	.2667	.2286	.2801
3	.2427	.2427	.2801	.2427	.2477	.2286	.2801
4	.2427	.2427	.2801	.2427	.2667	.2286	.2801
5	.2801	.2614	.2801	.2801	.3429	.3048	.2987
6	.3547	.3921	.3174	.3547	.3921	.4001	.3734
7	.4108	.4108	.3734	.3547	.3696	.381	.3921
8	.3734	.3921	.3361	.3361	.3361	.362	.3361
9	.3239	.4024	.2987	.2801	.2987	.3439	.3429
10	.3048	.4207	.3361	.2614	.2987	.3174	.2477
11	.3048	.2858	.2427	.2614	.2715	.2987	.2858
12	.3048	.3048	.2241	.2801		.3361	.2858
13	.2858	.3048	.2614	.2801	.2987	.3361	.3048
14	.2477	.3239	.2614	.2614	.2614	.2801	.3239
15	.2667	.3048	.2614	.2427	.2801	.2987	.3429
16	.2858	.2667	.2801	.2801	.3174	.3174	.362
17	.2987	.2801	.2987	.2801	.2987	.2987	.362
18	.3361	.2987	.3174	.2801	.3361	.3174	.3429
19	.4668	.4668	.4854	.4668	.4668	.4668	.5121
20	.5601	.5041	.5228	.5228	.499	.5228	.5487
21	.5041	.4668	.4854		.4805	.4481	.499
22	.4668	.4294	.4668	.3961	.3734	.4294	.462
23	.3361	.3547	.3361	.3429	.3395	.3547	.3429
24	.2427	.2801	.2987	.2801	.2858	.2667	
Max	.5601	.5041	.5228	.5228	.499	.5228	.5487
Min	.2427	.2427	.2241	.2427	.2477	.2286	.2477
Avg	.3302	.3384	.3252	.3057	.3302	.3339	.3516

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 202 / 11 kV Sawalwadi Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191	.0743	.0714	.1372
2	.0191	.0191	.0191	.0191	.0743	.0714	.1372
3	.0191	.0191	.0191	.0191	.08	.0724	.1372
4	.0191	.0191	.0191	.0191	.08	.0734	.1372
5	.0191	.0191	.0191	.0191	.1	.0892	.1372
6	.0381	.0381	.0191	.0191	.1	.1067	.1372
7	.0381	.0381	.0381	.0381	.1337	.1265	.1981
8	.0381	.0191	.0191	.0381	.0191	.0191	.0381
9	.4687	.3437	.2623	.0381	.0191	.0191	.4877
10	.4218	.3593	.2778	.0191	.0191	.0191	.6405
11	.4218	.3281	.2932	.0191	.0191	.0191	.7748
12	.4062	.3437	.2932	.0191		.0191	.7907
13	.3906	.2656	.2932	.0191		.0191	.7907
14		.2656	.2469	.0191		.0191	.7907
15		.2688	.2469	.0191		.0191	.7748
16		.2846	.2315	.0191		.0191	.7432
17	.0191	.0191	.0191	.0191	.0191	.0191	.0191
18	.0191	.0191	.0381	.0191	.0191	.0191	.0191
19	.0381	.0381	.0381	.0191	.0191	.0191	.0191
20	.0381	.0191	.0381	.0191	.0191	.0191	.0191
21	.0381	.0191	.0381	.0191	.0191	.0191	.0191
22	.0191	.0191	.0191		.1	.1829	.0191
23	.0191	.0191	.0191	.06	.1	.1677	.0191
24	.0191	.0191	.0191	.0191	.072	.1	
Max	.4687	.3593	.2932	.06	.1337	.1829	.7907
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.1204	.1176	.1061	.0234	.0572	.0554	.3037

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 203 / 11 kV Dharan Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024	.1844	.1844	.1578			
2	.4024	.1844	.1886	.1753			
3	.4024	.1844	.1886	.1753			
4	.3353	.1844	.1715	.1753			
5	.3018	.1844	.1715	.1753			
6	.2683	.2012	.1357	.2279			
7	.2515	.2347	.12	.2804			
9				.5258	.78	.7461	
10				.5992	.9221	.8383	
11				.6882	.9389	.788	
12				.6554		.8215	
13				.6226	.9054	.788	
14				.639	.9221	.7545	
15				.6554	.8383	.7045	
16				.639	.788	.7042	
22	.2515	.1677	.1578				.503
23	.2347	.2012	.1753				.4694
24	.4024	.218	.2012	.1578			
Max	.4024	.2347	.2012	.6882	.9389	.8383	.503
Min	.2347	.1677	.12	.1578	.78	.7042	.4694
Avg	.3253	.1945	.1695	.4094	.8707	.7681	.4862

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 204 / 11 kV Bagani road Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191	.1829	.1829	.2012
2	.0191	.0191	.0191	.0191	.1656	.1656	.2012
3	.0191	.0191	.0191	.0191	.1656	.1656	.2012
4	.0191	.0191	.0191	.0191	.1829	.1806	.2012
5	.0191	.0191	.0191	.0191	.2006	.1829	.2012
6	.0381	.0381	.0191	.0191	.2214	.1852	.2012
7	.0381	.0381	.0381	.0381	.2591	.2753	.2515
8	.0381	.0191	.0381	.0191	.0191	.0191	.0381
9	.4586	.4111	.4218	.0191	.0191	.0191	.502
10	.4744	.4111	.4218	.0191	.0191	.0191	.5182
11	.4744	.4902	.4062	.0191	.0191	.0191	.5344
12	.4586	.506	.3906	.0191		.0191	.3953
13	.4428	.427	.3593	.0191	.0191	.0191	.583
14	.3479	.427	.3281	.0191	.0191	.0191	.5281
15	.3637	.427	.3281	.0191	.0191	.0191	.5121
16	.3637	.3953	.3125	.0191	.0191		.4961
17	.0191	.0191	.0381	.0191	.0191		.0381
18	.0191	.0191	.0191	.0381	.0191	.0381	.0381
19	.0381	.0381	.0381	.0381	.0191	.0381	.0381
20	.0381	.0381	.0381	.0381	.0381	.0381	.0381
21	.0381	.0381	.0381	.0381	.0381	.0381	.0381
22	.0381	.0381	.0381	.2187	.1928	.2347	.0381
23	.0191	.0381	.0191	.2214	.2103	.2683	.0191
24	.0191	.0191	.0191	.0191	.1829	.1829	
Max	.4744	.506	.4218	.2214	.2591	.2753	.583
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.1593	.1639	.1420	.0398	.0978	.1059	.2528

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244088 / 33/11 kV Dudhgaon S/Stn

Feeder No / Name : 205 / 11 KV A1 PPS Express

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.2801	.2241	.2263	.0943	.3206
2	.3395	.2801	.2241	.2263	.0943	.3206
3	.3395	.2801	.2241	.2263	.0943	.3206
4	.3395	.2801	.2241	.2452	.0943	.3206
5	.3395	.2801	.2427	.2477	.1132	.3206
6	.3772	.3174	.2427	.2477	.1509	.3206
7	.3772	.2987	.2801	.2452	.1254	.3584
8	.4715	.3547	.3547	.2263	.1509	.3772
9	.4904	.3174	.2614	.2452	.3018	.4338
10	.4904	.3174	.2801	.3174	.3547	.4338
11	.4715	.2987	.2801	.2715	.3921	.4715
12	.4715	.2987	.2801		.4108	.547
13	.4527	.2987	.2801	.2614	.4294	.5658
14	.4338	.2987	.2614	.2614	.4294	.5658
15	.3206	.2987	.2614	.2614	.3921	.547
16	.3395	.2801	.2614	.2614	.4108	.5281
Max	.4904	.3547	.3547	.3174	.4294	.5658
Min	.3206	.2801	.2241	.2263	.0943	.3206
Avg	.3996	.2987	.2614	.2514	.2524	.422

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244090 / 33/11KV Nandre S/Stn

Feeder No / Name : 201 / 11 KV Nandre Village

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7733	.6602	.7545	.679	.6979	.6979	.7545
2	.7356	.6602	.7356	.6413	.6602	.679	.7356
3	.7356		.7356	.6413	.6602	.6602	.7356
4	.7356	.7392	.7356	.6413	.6602	.6602	.7356
5	.8865	.8871	.8779	.7167	.8029	.7545	.811
6	.9145	.9425	.9425	.9431	.924	.8962	.9795
7	.9145	.8779	.9795	.8871	.9055	.8316	.8596
8	.7964	.8048	.7865	.7947	.7865	.7499	.7499
9	.7602	.8048	.7602	.8145	.7499	.7577	.7059
10	.6268	.7059	.6516	.724	.6878	.7316	.6697
11	.6447	.6335	.6401	.5973	.7421	.6767	.6697
12	.5611	.6268	.5792	.6516	.6447	.724	.6401
13	.5853	.6268	.591		.6089	.6154	
14	.5175	.6154	.5249	.6401	.6154	.591	.6401
15	.4668	.5973	.5973	.5853	.5792	.591	.6283
16	.6401		.5373	.5175	.6584	.5973	.5729
17	.499	.567	.543	.5729	.5611	.5792	.5729
18	.5544	.567	.6584	.695	.6697	.6767	.6036
19	.961	.924	.924	.9694	.924	1.0059	.9328
20	1.0791	1.1643	1.1203	1.1016	1.0829	1.0719	1.0425
21	1.0242	1.0829	1.0751	1.0719	1.0829	1.0269	1.0608
22	.9328	1.0082	1.0374	1.0082	.9431	1.0269	1.0269
23	.7421	.8676	.8488	.8299	.811	.8488	.8962
24	.8299		.7733	.7167	.7356	.7356	.7922
Max	1.0791	1.1643	1.1203	1.1016	1.0829	1.0719	1.0608
Min	.4668	.567	.5249	.5175	.5611	.5792	.5729
Avg	.7465	.7792	.7671	.7583	.7581	.7578	.7746

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244090 / 33/11KV Nandre S/Stn

Feeder No / Name : 202 / 11 kV Nandre Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)
9			.0943
14	.415		
18		.0566	
Max	.415	.0566	.0943
Min	.415	.0566	.0943
Avg	.415	.0566	.0943

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244090 / 33/11KV Nandre S/Stn

Feeder No / Name : 203 / 11 KV Malbhag Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2452	.1886	.1698	.1509	.0377	.0377	.0377
2	.2263	.1698	.1698	.1509	.0377	.0377	.0377
3	.2263	.1509	.1698	.132	.0377	.0377	.0377
4	.2263	.1509	.1698	.132	.0377	.0377	.0377
5	.2263	.1698	.1698	.132	.0377	.0377	.0377
6	.2263	.1698	.1698	.132	.0566	.0377	.0377
7	.2075	.1886	.1698	.1509	.0566	.0377	.0377
8	.0754	.0566	.0377	.0754	.0377		.0754
9	.0754	.0943	.0754	.2641	.3961	.3961	
10	.0943	.0943	.0943	.3206	.4338	.4527	.0943
11	.1132	.132	.0943	.3206	.4527	.4715	.1132
12	.0943	.1132	.1132	.3584	.4904	.4338	.0943
13	.132	.1132	.0754	.6401	.4527	.415	
14	.132	.1132	.0754	.3584	.4527	.415	.0754
15	.1132	.1132	.0754	.3206	.3772	.3772	.0754
16	.1132	.1132	.0943	.3206	.3772	.3772	.0943
17	.0943	.1132	.0754	.0566	.0754	.0566	.0754
18		.0754	.0566	.0943	.0566	.0566	.0566
19	.0566	.0566	.0566	.0566	.0566	.0566	.0566
20	.0566	.0566	.0566	.0377	.0566	.0566	.0566
21	.0566	.0566	.0566	.0377	.0377	.0377	.0566
22	.2075	.2075	.1698	.0377	.0377	.0377	.2829
23	.1886	.1886	.1698	.0377	.0377	.0377	.2829
24	.2641	.1886	.1886	.1698	.0377	.0377	.0377
Max	.2641	.2075	.1886	.6401	.4904	.4715	.2829
Min	.0566	.0566	.0377	.0377	.0377	.0377	.0377
Avg	.1501	.1281	.1148	.1870	.1737	.1730	.0814

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244126 / 33/11 KV KAVALAPUR

Feeder No / Name : 201 / 11 KV KAVALAPUR VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3547	.3584	.3734	.3658	.3961	.3961	.3961
2	.3395	.3772	.3772	.3658	.3772	.3772	.3772
3	.3395	.3584	.3584	.3658	.3772	.3772	.3772
4	.3547	.3584	.3547	.3658	.3584	.3772	.3772
5	.4066	.3961	.3547	.439	.415	.3961	.415
6	.462	.4715	.462	.5228	.4527	.4338	.4715
7	.5853	.5228	.5359	.4854	.5415	.5093	.5041
8	.4938	.4481	.4572	.4481	.4755	.462	.4755
9	.4755	.439	.4207	.4298	.4344	.4207	.3761
10	.362	.3841	.3366	.3366	.4024	.3761	.3439
11	.3292	.3696	.3224	.3366	.3841	.3544	.2926
12	.2926	.2915	.2865	.3189	.3475	.3761	.2743
13	.2743	.3511	.2865	.3582	.3475	.3077	.3142
14	.2743	.3109		.3142	.3292	.3439	.3292
15	.2561	.3326		.2957	.3142	.3439	.2812
16	.2743	.3292	.4119	.3258	.3109	.3582	.3292
17	.2587	.3511	.4119	.3224	.3109	.3582	.3326
18	.3475	.4024	.4908	.3641	.4252	.4298	.4207
19	.5544	.6036	.5609	.5792	.5304	.543	.6335
20	.5601	.6036	.5784	.5729	.5729	.6099	.6401
21	.5601	.5544	.5721	.5415	.5788	.5658	.5788
22	.5415	.5249	.5316	.5281	.5281	.5093	.5658
23	.415	.462	.4115	.4715	.4338	.4338	.4904
24	.3547	.3584	.4108	.3921	.3961	.415	.3961
Max	.5853	.6036	.5784	.5792	.5788	.6099	.6401
Min	.2561	.2915	.2865	.2957	.3109	.3077	.2743
Avg	.3944	.4150	.4230	.4103	.4183	.4198	.4164

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244126 / 33/11 KV KAVALAPUR

Feeder No / Name : 202 / 11 kv tukai ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0509	.0543	.0686	.0739	.442	.3864	.4064
2	.0514	.0549	.0686	.0739	.442	.3763	.3963
3	.0514	.0554	.0678	.0739	.4572	.3763	.4167
4	.0686	.0554	.0686	.0732	.4475	.3864	.4167
5	.0686	.0739	.0671	.0732	.442	.4012	.4268
6	.0848	.0934	.1006	.0914	.463	.5093	.4572
7	.1029	.1109	.0995	.0924	.679	.6481	.4999
8	.1029	.0924	.0838	.0905	.0934	.0914	.0701
9	.4586	.4784	.5624	.0724	.1086	.1109	.7655
10	.4843	.5468	.703	.0686	.0686	.0716	.8223
11	.4572	.5468	.6562	.0701	.0857	.0537	.8124
12	.4877	.5335	.5944	.0886	.0857	.0526	.8697
13	.4572	.5639	.587	.0701	.0686	.052	.7343
14	.4572	.5792		.0709	.0686	.0532	.759
15	.3048	.5312		.0732	.0686	.0709	.7811
16	.3269	.5535	.5376	.0537	.0857	.0716	.7432
17	.0509	.0509	.0905	.0701	.0678	.0724	.0492
18	.0671	.0709	.0876	.0693	.0876	.0709	.0739
19	.0747	.1006	.104	.1097	.1109	.1294	.0924
20	.0924	.0995	.1109	.1109	.112	.1109	.0934
21	.0924	.1006	.1097	.1109	.112	.1109	.0934
22	.0747	.0838	.0914	.5601	.4999	.4938	.0934
23	.0747	.0848	.0739	.4843	.4115	.4572	.0747
24	.0671	.0537	.0848	.0732	.442	.3864	.431
Max	.4877	.5792	.703	.5601	.679	.6481	.8697
Min	.0509	.0509	.0671	.0537	.0678	.052	.0492
Avg	.1921	.2320	.2281	.1166	.2479	.2310	.4325

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 244126 / 33/11 KV KAVALAPUR

Feeder No / Name : 203 / 11 KV KONDAKA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3795	.3286	.4161	.3048	.112	.1307	.1494
2	.3681	.3429	.4161	.3086	.0934	.112	.1494
3	.3681	.3567	.427	.3048	.0943	.1132	.1307
4	.3841	.3567	.4111	.3353	.0943	.132	.1494
5	.3795	.381	.4062	.3858	.112	.1494	.1494
6	.3953	.4167	.4218	.463	.1698	.1698	.168
7	.6874	.639	.6562	.4725	.1848	.2054	.2054
8	.1509	.1478	.1715	.1187	.1663	.1867	.1663
9	.1174	.1463	.1341	.6554	.8579	.8688	.1448
10	.0995	.1294	.1109	.7188	.9568	.8993	.1052
11	.1006	.6401	.1109	.6984	.9374	.9181	.1063
12	.0857	.0876	.1097	.6539	.8905	.8916	.1214
13	.0857	.0914	.1109	.6836	.8436	.8619	.12
14	.0686	.0924		.7074	.8223	.8362	.1214
15	.0514	.0914		.7468	.8162	.8471	.1029
16	.0732	.1294	.1267	.5418	.8223	.884	.1387
17	.0739	.128	.1478	.1052	.1174	.128	.1372
18	.1433	.128	.1478	.124	.1463	.128	.1663
19	.1867	.1543	.1646	.1663	.168	.1848	.2033
20	.1663	.1543	.1848	.1663	.1867	.1867	.2054
21	.1478	.1372	.1646	.1478	.168	.168	.1867
22	.4515	.6009	.442	.132	.1494	.168	.7773
23	.3765	.5281	.3658	.1132	.1307	.168	.6401
24	.3795	.3243	.4961	.3353	.1109	.1294	.1663
Max	.6874	.6401	.6562	.7468	.9568	.9181	.7773
Min	.0514	.0876	.1097	.1052	.0934	.112	.1029
Avg	.2384	.2722	.2792	.3912	.3813	.3945	.1963

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI RURAL DIVISION[522]

VISHRAMBAG[081]

BU 1252

Substation No/ Name :- 246001 / 110/33/11 KV VISHRAMBAG S/SN

Feeder No / Name : 210 / 11 KV Dhamni

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	02-SEP-17
HR	Load (MW)
1	.8686
2	.8686
3	.8686
4	.8596
5	.8962
6	.9694
7	1.0608
8	1.2012
9	1.2536
10	1.2894
12	1.2971
13	.3125
14	.6783
15	.6962
16	1.3523
17	1.2757
18	1.2757
19	1.1616
20	1.3289
21	1.3112
22	1.2894
23	1.1104
24	.8686
Max	1.3523
Min	.3125
Avg	1.0476

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244080 / 33/11KV RISALA ROAD

Feeder No / Name : 201 / 11KV GYMKHANA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5792	.543	.6089	.6401	.6154	.5792	.6154
2	.5792	.543	.6154	.5853	.5853	.543	.5853
3	.543	.5611	.6154	.5853	.5853	.5611	.5853
4	.543	.543	.6154	.5487	.543	.5792	.5544
5	.543	.543	.5792	.5487	.5487	.5611	.5544
6	.543	.6154	.5853	.5853	.5914	.5792	.5975
7	.6653	.6335	.5853	.6283	.6219	.543	.6584
8	.7023	.6516	.695	.6767	.5175	.6516	.6653
9	.8048	.6767	.6584	.6335	.7392	.6584	.543
10	.724	.6878	.695	.7602	.7762	.7316	.7602
11	.7602	.7316	.6878	.7964	.8145	.7316	.8688
12	.724	.7522	.724	.8507	.724	.7316	.8507
13	.724	.7087	.788	.8688	.7522	.724	.7964
14	.5792	.6697	.7316	.724	.724	.6516	.7964
15	.6154	.6401	.7392	.7602	.6335	.6335	.7602
16	.6089	.6401	.7316	.7602	.724	.6335	.6878
17	.6697	.724	.7602	.7421	.6697	.7164	.8596
18	.7421	.9214	.7522	.8145	.7602	.7164	.8688
19	1.086	1.134	.9745	1.1222	1.0498	.9922	1.1641
20	1.086	1.1462	1.0631	.9671	1.0317	.9922	1.1694
21	1.0136	1.0029	.985	.905	.9593	.9313	1.0566
22	.8688	.8505	.8417	.7964	.8326	.8596	.8145
23	.724	.7522	.724	.7164	.7421	.6516	.724
24	.543	.6516	.6447	.6401	.6154	.6154	.6154
Max	1.086	1.1462	1.0631	1.1222	1.0498	.9922	1.1694
Min	.543	.543	.5792	.5487	.5175	.543	.543
Avg	.7072	.7218	.7250	.7357	.7149	.6903	.7563

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244080 / 33/11KV RISALA ROAD

Feeder No / Name : 202 / 11KV RAJWADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.695	.4344	.7164	.6335	.6379	.6697	.695
2	.5853	.4344	.724	.6154	.6089	.6516	.6584
3	.5853	.4344	.6516	.6401	.6089	.6516	.6584
4	.5544	.4525	.6516	.6401	.5792	.6335	.6283
5	.5175	.4344	.6516	.6401	.5792	.6516	.6283
6	.462	.4344	.6219	.6838	.6584	.6697	.6653
7	.4668	.4163	.6219	.6335	.695	.6516	.6447
8	.4668	.4344	.6379	.6379	.4904	.6516	.6379
9	.5121	.5014	.6805	.724	.5487	.6135	.724
10	.543	.6805	.6733	.6516	.5914	.6268	.7602
11		.964	.7087	.9774	.7164	.6447	.8507
12		.9114	.7442	1.2731	.7973	.7164	.7783
13	.6516	.8669	.7011	.9412	.7442	.7087	.8688
14	.6089	.8413	.7164	.724	.7619	.6379	.8145
15	.6154	.8145	.7316	.8507	.7087	.6805	.8688
16	.6219	.8059	.724	.8507	.7442	.6805	.8688
17	.4525	.8238	.7973	.8326	.7602	.6379	.7973
18	.4887	.6516	.7442	.8688	.7602	.6661	.8238
19	.7602	1.0631	.8859	1.0317	.9774	.9114	.9671
20	.724	1.0277	.8954	.8954	.9593	.8505	1.0029
21	.6697	.9313	.8145	.8954	.905	.8326	.8596
22	.6335	.8326	.724	.8326	.8507	.7964	.7762
23	.5792	.788	.6767	.724	.7783	.724	.7316
24	.6335	.5068	.7522	.6154		.724	.6878
Max	.7602	1.0631	.8954	1.2731	.9774	.9114	1.0029
Min	.4525	.4163	.6219	.6154	.4904	.6135	.6283
Avg	.5831	.6869	.7186	.7839	.7157	.6951	.7665

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244080 / 33/11KV RISALA ROAD

Feeder No / Name : 203 / 11KV VAKHARBAG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.543	.6154	.5853	.6516	.543	.6283
2	.5121	.543	.6154	.5544	.6219	.543	.5914
3	.5121	.5249	.6219	.5544	.5853	.5249	.5914
4	.499	.5249	.6219	.5175	.5544	.5249	.5601
5	.499	.5068	.5853	.5175	.5544	.5068	.5601
6	.499	.5068	.5914	.5228	.5975	.5068	.5601
7	.6401	.543	.5975	.5544	.7023	.543	.5914
8	.5853	.5973	.5731	.5914	.6722	.543	.5975
9	.6653	.6219	.6653	.6335	.6161	.5914	.6878
10	.6584	.6468	.7682	.6878	.7095	.6535	.724
11		.9145	.9145	.9412	.9055	.9795	.9231
12		.9145	.9774	1.086	.924	1.0164	.8869
13	1.0136	.9709	1.0136	1.086	.961	.9412	.9231
14	.8238	.8859	.8871	.9774	.8688	.8688	.9412
15	.8238	.8326	.7842	1.0136	.8869	.905	.9593
16	.8688	1.0029	.7392	.9774	.9145	.905	1.0136
17	.7964	.905	.8871	.9774	.8507	.8779	.9955
18	.8688	.9145	.823	.9955	.9774	.8954	.905
19	1.086	1.0974	1.0498	1.1462	1.1403	1.0745	1.1765
20	1.1041	1.1222	1.0498	1.086	1.1222	1.086	1.1946
21	.9593	1.0029	.9511	.9313	1.1041	1.0242	1.086
22	.7964	.788	.823	.8688	.8688	.7964	.924
23	.7602	.7164	.6584	.7964	.724	7.3891	.823
24	.5487	.6335	.6447	.5853	.6516	.6335	.6219
Max	1.1041	1.1222	1.0498	1.1462	1.1403	7.3891	1.1946
Min	.499	.5068	.5731	.5175	.5544	.5068	.5601
Avg	.7304	.7608	.7691	.7995	.7985	1.0364	.8111

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244122 / 33/11 KV BALAJI MANDIR

Feeder No / Name : 201 / 11 KV Balaji Mill Road

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.4321	.503	.4696	.5087	.4534
2	.3567	.3658	.4111	.4694	.4534	.4588	.427
3	.3567	.3612	.4372	.421	.421	.4111	.4111
4	.3567	.3521	.427	.3963	.4111	.4062	.4111
5	.3525	.362	.4374	.4115	.427	.4115	.4115
6	.3666	.3666	.4374	.4012	.4475	.3858	.4572
7	.502	.427	.4801	.427	.4862	.4687	.4531
8	.4218	.3963	.4534	.4481	.4752	.4744	.4111
9	.4374	.4694	.6089	.4534	.5256	.502	.4534
10	.427	.4527	.7023	.5487	.5316	.5365	.5144
11	.3475	.4862	.7023	.5973	.6024	.6173	.6401
12	.3841	.463	.7468	.6283	.5493	.6516	.6154
13	.4374	.4908	.6036	.5258	.5792	.591	.6379
14	.427	.4733	.6219	.591	.5973	.5847	.6379
15	.3374	.567	.5375	.6653	.5493	.5847	.6697
16	.3506	.5194	.4973	.7023	.5658	.6001	.6268
17	.3658	.4887	.4973	.6401	.5658	.6626	.6089
18	.3384		.4862	.5373	.5487	.591	.5434
19	.4527	.5493	.4973	.5258	.5847	.5548	.6556
20	.5201	.567	.5316	.5552	.5731	.5258	.6335
21	.5201	.6201	.591	.6447	.6335	.6135	.6268
22	.5087	.567	.6089	.6379	.6335	.5895	.6878
23	.4321	.5144	.5609	.5721	.6089	.5548	.5784
24	.381	.4012	.4424	.5256	.4902	.583	.4858
Max	.5201	.6201	.7468	.7023	.6335	.6626	.6878
Min	.3374	.3521	.4111	.3963	.4111	.3858	.4111
Avg	.4067	.4627	.5313	.5345	.5304	.5362	.5438

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

CENTRAL ZONE,SANGLI[068] BU 4068

Substation No/ Name :- 244122 / 33/11 KV BALAJI MANDIR

Feeder No / Name : 202 / 11 KV Circuit House

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.132	.1886	.1698	.1494	.1509	.1698
2	.1132	.132	.1698	.1494	.1307	.132	.1509
3	.1132	.1132	.132	.1494	.1307	.1132	.132
4	.1132	.1132	.132	.1307	.132	.1132	.132
5	.132	.132	.1509	.128	.1509	.1132	.1509
6	.1886	.1698	.1509	.1646	.1698	.132	.1698
7	.2263	.2075	.2263	.2263	.1698	.1509	.1886
8	.2075	.2075	.2263	.2075	.2075	.1698	.1886
9	.2263	.2263	.2075	.2263	.2452	.2075	.2263
10	.2075	.2075	.1886	.2075	.1886	.1886	.2075
11	.1886	.1698	.1698	.2452	.1886	.2075	.1698
12	.1698	.1698	.1698	.2241	.2641	.2263	.1886
13	.1698	.2075	.1886	.2263	.1886	.2263	.2263
14	.1698	.1886	.1698	.2075	.1698	.2263	.2263
15	.1698	.1698	.1698	.1886	.1698	.2452	.2263
16	.1509	.1698	.1698	.1698	.1698	.2075	.2263
17	.1509	.1886	.1698	.2263	.1698	.2263	.2263
18	.1698		.1698	.1886	.2263	.1698	.2263
19	.2641	.2641	.2263	.2075	.2263	.2263	.3206
20	.2452	.2452	.2263	.2829	.2263	.2829	.2987
21	.2263	.2263	.2263	.2452	.2263	.2452	.2452
22	.2263	.2452	.2263	.2452	.2263	.2452	.2452
23	.2075	.394	.2263	.1886	.2263	.2452	.2263
24	.132	.1509	.1886	.1698	.1886	.1886	.2075
Max	.2641	.394	.2263	.2829	.2641	.2829	.3206
Min	.1132	.1132	.132	.128	.1307	.1132	.132
Avg	.1792	.1926	.1863	.1990	.1892	.1933	.2073

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244019 / 33/11 KV MADHAVNAGAR

Feeder No / Name : 201 / 11 KV MADHAVNAGAR FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4715	.415	.4715	.4904	.5658	.5601	.5658
2	.4904	.3961	.4715	.4904	.5658	.5601	.5658
3	.4904	.3772	.4904	.5093	.5658	.5228	.547
4	.5093	.3772	.4904	.5281	.5658	.5041	.5281
5	.5093	.415	.5093	.5658	.5658	.5415	.5281
6	.5093	.4527	.5281	.5658	.5847	.5788	.547
7	.4904	.4715	.547	.5658	.5975	.6161	.5658
8	.4715	.4715	.547	.4715	.6161	.5788	.5281
9	.4527	.547	.6979	.6413	.679	.679	.5658
10	.415	.6036	.7545	.8676	.7167	.679	.6602
11	.3961	.6602	.8865	.811	.7356	.7167	.6602
12	.3584	.6036	.6979	.7356	.6602	.5658	.6602
13	.3206		.5658	.6413	.6224	.4527	.7356
14	.3206	.6036	.7545	.7356	.6413	.5658	.7133
15	.3206	.6413	.811	.8299	.679	.7167	.7922
16	.3395	.6979	.811	.8865	.7545	.7356	.9054
17	.3961	.8299	.679	.9054	.7655	.7545	.8488
18	.4904	.8299	.679	.9431	.8676	.811	.811
19	.6602	.8865	.679	1.0751	.9335	.9431	.7733
20	.6602	.7733	.679	1.0374	.9149	.9054	.7545
21	.5847	.7167	.6413	.9431	.8402	.7922	.7545
22	.547	.6602	.5847	.7922	.7468	.679	.6979
23	.4904	.5847	.5658	.679	.6535	.6224	.679
24	.4715	.4527	.5281	.5093	.6036	.5975	.547
Max	.6602	.8865	.8865	1.0751	.9335	.9431	.9054
Min	.3206	.3772	.4715	.4715	.5658	.4527	.5281
Avg	.4653	.5855	.6279	.7175	.6851	.6533	.6639

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244019 / 33/11 KV MADHAVNAGAR

Feeder No / Name : 203 / 11 KV INDOTEX

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5093	.4904	.4715	.4904	.5093	.5093	.4715
2	.5093	.4904	.4715	.4904	.4904	.5093	.4527
3	.4904	.4715	.4715	.4904	.4904	.4904	.4527
4	.4904	.4904	.4715	.5093	.4904	.4904	.4527
5	.4904	.5093	.4715	.5281	.4904	.5093	.4715
6	.4715	.5093	.4715	.5281	.4904	.5281	.4715
7	.4715	.547	.4715	.4904	.5093	.5281	.4715
8	.4715	.6036	.4527	.4904	.5093	.3681	.5093
9	.4904	.6036	.6036	.5658	.5658	.4904	.6036
10	.5281	.6036	.6602	.6413	.6036	.547	.6979
11	.5281	.6224	.6413	.679	.6348	.6413	.679
12	.5658	.6161	.6413	.6036	.6348	.6413	.679
13	.6036	.6413	.5847	.6036	.6224	.6413	.679
14	.6036	.6224	.6224	.6224	.6602	.6602	.6979
15	.6036	.6413	.6413	.6602	.6979	.6979	.6979
16	.5658	.6224	.6224	.6602	.6602	.7167	.7167
17	.6224	.6224	.5847	.6413	.679	.679	.7356
18	.6036	.6413	.5847	.6413	.6602	.6413	.7545
19	.6036	.6413	.5658	.6602	.679	.6224	.7167
20	.6224	.4904	.5658		.6413	.5658	.5658
21	.5847		.5658		.6036	.5281	.4904
22	.547	.4904	.5281		.5658	.4904	.5093
23	.5093	.4715	.4904		.547	.4904	.5281
24	.5093	.5093	.4904	.4904	.4715	.4904	.5281
Max	.6224	.6413	.6602	.679	.6979	.7167	.7545
Min	.4715	.4715	.4527	.4904	.4715	.3681	.4527
Avg	.5415	.5631	.5478	.5743	.5795	.5615	.5847

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244019 / 33/11 KV MADHAVNAGAR

Feeder No / Name : 205 / 11 KV COTTON MILL FEEDER SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6979	.5658	.7356	.7356	.679	.7356	.679
2	.679	.5658	.7356	.7356	.679	.7356	.679
3	.679	.547	.7167	.7167	.6036	.7167	.6602
4	.679	.547	.6979	.7356	.5853	.7356	.6602
5	.6602	.5847	.6979	.6979	.5853	.7356	.7167
6	.6602	.5658	.679	.6602	.5658	.7545	.7167
7	.6224	.6602	.679	.6224	.6602	.7545	.7167
8	.5658	.7545	.679	.7356	.7545	.7356	.7545
9	.5658	.8865	1.0562	.8299	.9431	1.0374	.6602
10	.5658	1.0185	1.2637	1.0374	1.0185	.9808	.6413
11	.547	1.1694	1.3392	1.0562	1.1128	.9431	.7545
12	.5658	1.1317	1.1317	1.1506	1.0562	.9619	.9431
13	.5658	1.0374	1.1128	1.0562	.9997	.9997	1.0374
14	.5658	1.0751	1.0374	1.1128	1.0562	1.1128	.9808
15	.547	1.094	.9997	1.1506	1.1128	1.1883	.9054
16	.5658	1.1317	1.1317	1.0751	1.094	1.0562	.9431
17	.5658	1.094	1.0562	1.0374	1.1128	1.094	.9997
18	.5658	1.0185	.7545	1.0185	.9619	.9431	1.0751
19	.5658	.9619	.7356	.9997	.7545	.7545	.9054
20	.5658	.8676	.679	.9808	.7167	.7167	.8488
21	.5658	.7356	.6979	.9431	.7356	.7356	.7167
22	.5658	.7167	.7167	1.0562	.7167	.6979	.7167
23	.5658	.6979	.7167	.9054	.6979	.6979	.7167
24	.6979	.5658	.7167	.7167	.7167	.7167	.7167
Max	.6979	1.1694	1.3392	1.1506	1.1128	1.1883	1.0751
Min	.547	.547	.679	.6224	.5658	.6979	.6413
Avg	.5996	.8330	.8653	.9069	.8300	.8558	.7977

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244019 / 33/11 KV MADHAVNAGAR

Feeder No / Name : 208 / 11 KV SIE Ag FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.1132	.0943	.1132	.1132	.1132	.1132
2	.0943	.0943	.0943	.1132	.1132	.1132	.1132
3	.1132	.0943	.1132	.1132	.1132	.1132	.1132
4	.0943	.0943	.1132	.1132	.1132	.1132	.1132
5	.132	.0943	.1132	.1132	.1132	.1132	.1132
6	.132	.132	.132	.1132	.1132	.1132	.132
7	.1132	.132	.132	.1509	.1132	.1509	.128
8	.1132	.132	.1132	.1132	.1132	.1509	.0943
9	.3018	.4527	.3961	.3658	.5281	.4268	.5658
10	.3772	.4755	.4904	.4725	.5847	.4725	.6602
11	.3961	.547	.4725	.2591	.6602	.5182	.6036
12	.3395		.4725	.442	.6413	.503	.5658
13	.0377	.3772	.4268	.4268	.6036	.4877	.5281
14	.0377	.3772	.381	.442	.5658	.4268	.5093
15	.0566	.3772	.4268	.4115	.4904	.3963	
16		.3961	.381	.4115	.4904	.3506	
17	.0943	.1132	.0943	.1698	.1132	.1132	
18	.0943	.1132	.1132	.1698	.132	.1132	.132
19		.132	.1132	.1509	.1509	.132	.132
20	.132	.1509	.1509		.1698	.132	.132
21	.1132	.1509	.132		.1698	.132	.1509
22	.1132	.1132	.1132		.1509	.1509	.132
23	.1132	.1132	.1132		.1509	.1509	.132
24	.0943	.1132	.0943	.132	.132	.132	.1132
Max	.3961	.547	.4904	.4725	.6602	.5182	.6602
Min	.0377	.0943	.0943	.1132	.1132	.1132	.0943
Avg	.1449	.2126	.2199	.2399	.2767	.2341	.2513

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 201 / 11 KV OM COLD

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0178	2.3577	3.0178	2.9721	3.1876	2.8858	3.0178
2	2.999	2.2822	2.9424	2.9721	3.1876	2.8858	2.9801
3	2.999	2.2068	2.9235	2.8959	3.1687	2.9235	2.9424
4	2.9801	2.1125	2.9235	2.8578	3.1687	2.9613	2.9801
5	2.9047	2.1691	2.8669	2.915	3.1499	2.9613	3.0556
6	2.8292	2.1502	2.999	2.9531	3.1499	3.0178	3.1687
7	2.7161	2.5086	2.9424	2.8959	2.8669	2.9613	3.1687
8	2.2257	2.5274		2.9912	3.3573	3.2253	3.0933
9	2.1125	3.658	3.3951	3.5648	3.4328	3.6961	3.7912
10	2.1125	4.039	3.4705	4.0552	3.6214	4.2486	4.3193
11	2.037	4.4702	4.1118	4.4136	3.8477	4.3759	4.3759
12	2.0182	4.6588	3.942	4.3381	3.9043	4.2816	4.4136
13	1.9805	4.1914	3.7912	3.7346	3.8289	3.7723	3.9609
14		4.1684	3.81	3.7912	3.7534	4.2438	3.8666
15	1.5089	4.3193	4.1684	3.9043	3.7346	4.3381	4.3759
16	1.8673	4.1684	3.7912	4.0552	3.6969	4.2816	3.9609
17		4.2627	3.7151	3.81	3.6025	3.7723	4.2676
18		3.8855	3.3913	3.5837	3.5271		
19		3.4705	3.2388	3.6591	3.2253		3.4675
20	1.9993	3.3951	3.0293	3.3951	3.0178	3.1121	3.296
21	1.9805	3.2253	2.8006	3.0933	2.8669		
22	1.9427	3.3196	2.8578	2.8669	2.9801		3.1817
23	2.3388	3.3573	2.915	3.3951	2.9424		3.4675
24	3.0556	2.3954	3.1687	2.8959	3.2065	2.8669	3.0933
Max	3.0556	4.6588	4.1684	4.4136	3.9043	4.3759	4.4136
Min	1.5089	2.1125	2.8006	2.8578	2.8669	2.8669	2.9424
Avg	2.3813	3.3041	3.3136	3.4171	3.3511	3.5164	3.5566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 202 / 11 KV KVC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1128	.8865	1.0185	1.0669	1.2637	1.226	1.2071
2	1.1128	.9242	1.0185	1.0288	1.2637	1.1883	1.1694
3	1.1128	.9242	1.0185	.9907	1.2637	1.2071	1.1317
4	1.1128	.9431	.9808	.9907	1.2449	1.2449	1.1317
5	.5281	.9808	1.0562	1.0288	1.2071	1.226	1.1694
6	.547	1.0374	1.1317	1.086	1.1694	1.1883	1.2071
7	.5658	.9808	1.1694	1.105	1.2071	1.4901	1.226
8	.5093	1.1317	1.1883	1.2574	1.3392	1.5089	1.4335
9	.6224	1.5623	1.4712	1.4901	1.5089	1.7528	1.6221
10	.5847	1.9624	1.6032	1.9805	1.5844	1.9052	1.7353
11	.5847	2.0559	1.6787	1.7353	1.7164	1.8484	1.773
12	.5847	2.0748	1.5655	1.8673	1.7353	1.9805	1.9805
13	.547	1.4098	1.4335	1.5278	1.8484	1.4523	1.6221
14		1.4901	1.3769	1.6787	1.8296	1.6032	1.6787
15	.6224	2.452	1.8861	1.7353	1.8107	1.7918	2.0748
16	.8676	2.2634	1.5655	1.9616	1.8296	1.9239	1.9805
17		1.8107	1.2955	1.8861	1.8673	1.773	2.1148
18		1.8673	1.2574	1.6032	1.8861		
19		1.4335	1.1812	1.6032	1.6787		1.5051
20	.8488	1.4335	1.1431	1.1694	1.4901	1.3203	1.2955
21	.8488	1.4146	1.0669	1.2826	1.2637		
22	.8676	1.3203	1.0669	1.2449	1.3392		1.1812
23	.8299	1.1883	1.105	1.3203	1.226		1.3908
24	1.1317	.8488	1.0185	1.0669	1.2826	1.2637	1.2449
Max	1.1317	2.452	1.8861	1.9805	1.8861	1.9805	2.1148
Min	.5093	.8488	.9808	.9907	1.1694	1.1883	1.1317
Avg	.7771	1.4332	1.2624	1.4045	1.4940	1.5208	1.4943

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 203 / 11 KV DIAMOND

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3203	.7733	1.3392	1.3717	1.1694	1.4335	1.226
2	1.3203	.9808	1.3392	1.3336	1.1506	1.4146	1.4335
3	1.3203	1.0374	1.3392	1.2955	1.1506	1.3769	1.4146
4	1.3203	1.226	1.3392	1.2193	1.1506	1.3957	1.4335
5	1.3203	1.3014	1.358	1.3146	1.1317	1.4523	1.3957
6	1.3392	1.3203	1.3769	1.4861	.9054	1.4146	1.4335
7	1.358	1.3392	1.3957	1.448	1.3957	1.3769	1.3769
8	1.3769	1.3203	1.3957	1.3717	1.3769	1.3957	.811
9	.4904	1.4098	1.6598	1.3203	1.5089	1.448	1.4523
10	.3018	1.5051	1.6598	1.1128	1.6221	1.5242	1.7353
11	.3018	1.6221	1.6221	1.6032	1.6598	1.6221	1.5844
12	.1886	1.0374	1.5844	1.5278	1.6598	1.0562	1.7541
13	.1698	1.086	1.6032	1.3014	1.4712	1.5844	.9997
14		1.1128	1.6787	1.3203	1.5844	1.5089	1.6032
15	.2263	1.4712	.5281	1.4146	1.5466	1.3957	1.6975
16	.1509	.9619	1.5844	1.4335	1.4335	1.0374	1.5466
17		1.5278	1.5242	.9242	1.5278	1.5466	1.6956
18		1.5089	1.5051	1.4712	1.5089		
19		1.5089	1.448	1.4335	1.3769		1.5432
20	.3206	1.4712	1.3717	1.094	1.2637	.1886	.8383
21	.3206	1.3769	1.448	1.5089	.811		
22	.2829	1.4335	1.4289	1.4901	1.5089		.8954
23	.6979	1.4712	1.2955	1.4901	1.4146		1.1812
24	1.1317	.7356	1.358	1.467	1.2449	1.4146	1.1128
Max	1.3769	1.6221	1.6787	1.6032	1.6598	1.6221	1.7541
Min	.1509	.7356	.5281	.9242	.811	.1886	.811
Avg	.7629	1.2725	1.4243	1.3647	1.3572	1.3467	1.3711

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 204 / 11KV NATRAJ

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.1698	.2075	.2286	.1886	.3395	.3772
2	.2263	.1698	.2075	.2096	.1886	.3206	.3395
3	.2263	.1698	.2075	.1905	.2075	.3206	.2641
4	.2263	.1698	.2075	.1905	.2263	.3018	.2641
5	.2263	.1698	.2075	.2096	.2452	.2263	.2263
6	.2263	.1886	.2075	.2477	.2452	.1886	.2263
7	.2075	.1698	.2075	.2286	.2263	.2075	.2263
8	.2075	.1509		.2286	.2263	.2075	.2452
9	.2075	.2286	.3395	.3018	.2263	.3048	.3584
10	.2452	.3239	.415	.5093	.2641	.381	.4715
11	.2452	.3018	.415	.5658	.3395	.3961	.5093
12	.2263	.3395	.3772	.4715	.3584	.4904	.5093
13	.2263	.3429	.3206	.3961	.415	.3772	.415
14		.3772	.2829	.415	.3961	.3584	.3961
15	.1698	.547	.4527	.4527	.3961	.3395	.4338
16	.1698	.4715	.4715	.4715	.415	.3772	.3961
17		.5847	.381	.7167	.3584	.3961	.4572
18		.7167	.2858	.5093	.2829		
19		.3395	.2286	.4715	.2452		.2667
20	.1886	.3206	.2477	.3395	.1886	.2452	.381
21	.1886	.3018	.2286	.1886	.1886		
22	.1698	.3018	.1905	.2075	.1698		.2858
23	.1698	.3206	.1905	.1886	.2829		.4001
24	.2075	.1698	.2263	.1905	.1886	.3584	.3772
Max	.2452	.7167	.4715	.7167	.415	.4904	.5093
Min	.1698	.1509	.1905	.1886	.1698	.1886	.2263
Avg	.2094	.3061	.2829	.3387	.2696	.3230	.3558

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 205 / 11 KV OMKAR

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5844	.7356	1.358	1.9052	1.6598	1.1317	1.094
2	1.5844	.7167	1.3203	1.7528	1.6598	1.3014	1.4712
3	1.6032	.7356	1.3203	1.7147	1.6409	1.3203	1.5466
4	1.6032	.7733	1.3203	1.6385	1.6409	1.358	1.5844
5	1.6598	.7545	1.3203	1.6956	1.6221	1.6975	1.5844
6	1.6221	.7733	1.2826	1.9052	1.1694	1.8107	1.3203
7	1.5466	.7356	1.2637	1.3146	1.3014	.7167	.9808
8	.679	1.4335		1.1431	.7167	1.8484	1.7918
9	.679	1.5623	1.6409	1.1317	1.1694	1.7909	1.5466
10	.7167	1.9052	.8299	1.094	1.4712	1.7718	1.3769
11	.7356	1.3203	1.7541	1.8861	1.8484	1.773	1.5466
12	.6979	1.4901	1.4335	1.7164	2.0748	1.773	1.3392
13	.7545	2.0767	1.4901	2.037	1.7353	1.5655	1.4712
14		1.8861	1.5278	2.0559	1.4712	1.7164	1.358
15	.7733	1.8107	1.7918	2.1313	1.6975	1.7353	1.3392
16	.7356	1.8484	2.037	2.1691	.9619	1.8861	1.773
17		1.094	1.0098	1.3392	1.358	1.1128	1.9814
18		1.0374	.8192	1.094	1.773		
19		1.0185	1.0288	1.5844	1.6787		1.6194
20	.6979	1.0562	.9145	1.358	1.2071	1.6598	.9335
21	.7167	1.0751	.8383	.9054	1.3203		
22	.7356	1.3203	1.1431	1.2449	1.0185		1.3717
23	.7167	1.6032	1.5623	1.773	1.1317		1.9433
24	1.5844	.7356	1.4335	1.9052	1.6975	1.1694	1.0751
Max	1.6598	2.0767	2.037	2.1691	2.0748	1.8861	1.9814
Min	.679	.7167	.8192	.9054	.7167	.7167	.9335
Avg	1.0713	1.2291	1.3235	1.6040	1.4594	1.5336	1.4568

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 206 / 11 kv Adimaya

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9808	.7922	.9619	1.105	1.0751	.9054	1.0185
2	.9808	.7922	.9431	1.0669	1.0751	.9242	.9808
3	.9808	.8488	.9431	1.0288	1.0751	.8865	.9431
4	.9808	.8299	.9431	.9907	1.094	.9054	.9431
5	.9997	.8676	.9431	1.0669	1.094	.9054	1.0185
6	.9431	.8865	1.0185	1.1241	1.1128	.9431	1.0562
7	.9054	.9619	1.1694	1.1812	1.0374	1.226	1.0562
8	.7922	.9619	1.1317	1.1812	1.0751	1.1128	.9619
9	.7922	1.448	1.2637	1.5466	1.2071	1.3146	1.5278
10	.6036	1.6766	1.358	1.7353	1.3203	1.5242	1.773
11	.7167	1.5844	1.5278	1.8296	1.5089	1.6598	1.4901
12	.6979	1.4523	1.7164	1.5278	1.6032	1.4335	1.8861
13	.7733	1.5051	1.6221	1.4146	1.3392	1.2826	1.5278
14		1.5655	1.5655	1.5089	1.3957	1.3769	1.5655
15	.7545	1.6221	1.6409	1.6032	1.4335	1.4523	1.5844
16	.7545	1.5278	1.2826	1.6598	1.4712	1.6409	1.6787
17		1.4146	1.1812	1.6975	1.4523	1.5466	1.3336
18		1.358	1.1241	1.5089	1.3392		
19		1.5089	1.1431	1.1317	1.1506		1.2955
20	.7167	1.3203	1.1241	1.094	1.0751	1.1317	1.2384
21	.7545	1.2071	1.086	1.0562	.9619		
22	.7545	1.2449	1.1431	1.0374	1.0562		1.105
23	.7545	1.2637	1.105	1.1506	.9619		1.1241
24	.9997	.7733	.9808	1.0669	1.094	.8865	1.0185
Max	.9997	1.6766	1.7164	1.8296	1.6032	1.6598	1.8861
Min	.6036	.7733	.9431	.9907	.9619	.8865	.9431
Avg	.8318	1.2256	1.2049	1.3047	1.2087	1.2136	1.2785

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 207 / 11 kv mandhana

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	.7922	1.0374	1.105	.9054	.9242	1.226
2	1.094	.7922	1.0374	1.0669	.9054	.9242	1.1317
3	1.094	.8299	1.0185	1.0288	.9242	.8488	1.094
4	1.094	.811	1.0185	.9907	.9431	.8865	1.0751
5	.9431	.8299	1.0185	1.0669	.9808	.811	1.0751
6	.9054	.8488	1.0562	1.1431	1.094	.8299	1.094
7	.8676	.9242	1.094	1.1812	1.094	1.0374	1.094
8	.8676	.9997	1.2071	1.2193	1.0751	1.0751	1.6409
9	.8676	1.3146	1.4712	1.4523	1.1694	1.4098	1.8296
10	.7922	1.5813	1.9805	1.7353	1.358	1.7147	2.0182
11	.7545	1.6032	1.7918	1.7353	1.5466	1.905	1.5089
12	.3395	1.6787	1.9239	1.8861	1.5655	1.8673	1.6975
13	.811	1.2955	1.6787	1.4712	1.3203	1.3769	1.4523
14		1.8861	1.6409	1.5466	1.4712	1.6032	1.6032
15	.7545	1.9239	1.5278	1.6787	1.4335	1.8861	1.7541
16	.7733	1.8296	1.5844	1.8296	1.4146	1.905	1.7164
17		1.6598	1.5813	1.773	1.3203	1.6032	1.6766
18		1.6787	1.4861	1.6221	1.2449		
19		1.4335	1.448	1.5655	1.3392		1.6766
20	.7733	1.3203	1.4289	1.3957	1.1128	1.3957	1.5432
21	.7545	1.3014	1.4098	1.358	1.0751		
22	.7733	1.2826	1.3336	1.3203	1.1883		1.4098
23	.7733	1.1883	1.2574	.9808	1.0751		1.448
24	1.2449	.7733	1.0562	.9907	.9054	.9431	1.1694
Max	1.2449	1.9239	1.9805	1.8861	1.5655	1.905	2.0182
Min	.3395	.7733	1.0185	.9808	.9054	.811	1.0751
Avg	.8705	1.2741	1.3787	1.3810	1.1859	1.3130	1.4516

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 208 / 11 KV Devika

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1509	.1698	.1905	.1698	.1698	.1698
2	.1698	.1509	.1698	.1715	.1698	.1698	.1698
3	.1698	.1509	.1698	.1715	.1698	.1698	.1698
4	.1698	.1509	.1698	.1524	.1698	.1698	.1698
5	.1886	.1509	.1698	.1715	.1698	.1698	.1698
6	.1886	.1698	.1698	.1715	.1886	.1698	.1886
7	.1886	.1698	.1698	.1715	.1886	.2075	.2075
8	.1886	.1886	.1698	.1905	.2075	.2075	.2263
9	.1698	.1905	.1698	.2263	.2263	.2096	.2641
10	.1698	.1905	.2263	.2641	.2452	.2286	.2829
11	.1698	.2075	.2452	.2829	.2452	.2075	.2452
12	.1698	.2452	.3018	.2641	.2263	.2452	.2452
13	.1698	.1905	.2641	.2263	.2263	.1886	.2452
14		.2452	.2263	.2641	.2452	.2263	.2829
15	.1698	.2829	.2641	.2641	.2641	.2263	.3018
16	.1698	.2075	.2452	.3018	.2641	.1886	.2263
17		.2263	.2096	.3395	.2263	.2452	.2858
18		.2075	.2286	.2452	.1698		
19		.1698	.2096	.2075	.1509		.1905
20	.1698	.1698	.2096	.1886	.1698	.1886	.1905
21	.1698	.1698	.1905	.1698	.1698		
22	.1698	.1698	.1715	.1698	.1698		.1715
23	.1509	.1698	.1715	.1698	.1698		.1715
24	.1698	.1509	.1698	.1905	.1698	.1698	.1698
Max	.1886	.2829	.3018	.3395	.2641	.2452	.3018
Min	.1509	.1509	.1698	.1524	.1509	.1698	.1698
Avg	.1726	.1865	.2026	.2152	.1989	.1978	.2157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244030 / 33/11 KV KUPWAD MIDC

Feeder No / Name : 402 / 33 KV Shah Presicast Unit NON SHEDDABLE EXPRESS HV FEEDERS
III Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2999	.2263	.2572	.2263	.2263	.2263
2	.2263	.2999	.2263	.2743	.2263	.2263	.2263
3	.2263	.2886	.2263	.2286	.2263	.2263	.2263
4	.2263	.2829	.2263	.2286	.2263	.2263	.2263
5	.2263	.2659	.2263	.2458	.2263	.2263	.2263
6	.2263	.2546	.2263	.2343	2.7161	.2263	.2263
7	.2433	.2263	.2263	.2286	.2377	.2263	.2263
8	.2886	.2263	.249	.2286	.2263	.2263	.2263
9	.2829	.2286	.2263	.2263		.2286	.2263
10	.2829	.2286	.2263	.2263	.8035	.2286	.2263
11	.2829	.2263	.2263	.2263	1.1317	.2263	.2263
12	.2603	.232	.249	.2433	1.2788	.2263	.5941
13	.2659	1.2003	.2263	.2433	1.1939	.2377	1.1373
14		1.0412	.2263	.2263	1.1373	.232	1.1373
15	.2886	1.0412	.2263	.2263	.3961	1.1939	1.2562
16	.2999	.232	.8544	.2263	.2263	1.0808	.8884
17		.232	1.3203	.2263	.8714	.4979	.2286
18		.2942	.2286	.249	1.2505		
19		.2263	.2286	.249	1.2335		.2286
20	.2829	.2377	.2401	.249	.2263	.2263	.2286
21	.2829	.2659	.2572	.2716	.2433		
22	.2829	.249	.2286	.2773	.2263		.2286
23	.2999	.2546	.2286	.2659	.2263		.2286
24	.2999	.2999	.2263	.2286	.2263	.2263	.2263
Max	.2999	1.2003	1.3203	.2773	2.7161	1.1939	1.2562
Min	.2263	.2263	.2263	.2263	.2263	.2263	.2263
Avg	.2651	.3598	.3022	.2411	.6514	.3376	.4033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 201 / 11 KV Ankur

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7926	.0572	.7545	.7865	.8962	.9145	.9979
2	.7133	.0629	.7545	.7537	.8871	.8688	.9709
3	.6737	.0629	.7293	.7362	.8871	.8688	.9335
4	.5335	.0572	.7125	.6874	.8589	.8596	.924
5	.5639	.0572	.7449	.6706	.7202	.8954	.924
6	.3948	.0854	.8855	.6097	.4633	.9282	.924
7	.4054	.5127	.9496	.4451	.4054	.7628	.9979
8	.1646	.8718	.5716	1.0517	.9114	.4534	1.086
9	.1646	1.086	1.39	1.1317	1.086	1.358	1.5684
10	.189	1.4632	1.4632	1.6598	1.1706	1.5089	1.8861
11	.0072	1.3443	1.5524	1.4335	1.7177	1.5089	1.9616
12	.0152	1.4632	1.3756	1.358	1.643	1.5089	1.7353
13	.0076	1.39	1.643	1.3443	1.4937	1.5844	1.4045
14	.0914	1.7002	1.6598	1.7177	1.1949	1.5844	1.6598
15	.1036	.7964	1.086	1.4335	1.5089	1.4784	1.8107
16	.128	1.643	1.4937	1.4784	1.7353	1.5844	1.7353
17	.1097	1.3611	1.1827	1.419	1.5844	1.3443	1.358
18	.0488	1.3756	.7011	1.2071	1.3306	1.2071	1.358
19	.0686	1.2757	1.1462	1.2071	1.1706	1.0288	1.1317
20	.0671	.8871	1.0631	1.0974		.9015	1.0349
21	.0671	.9709	.4694	1.0242	1.0136	1.0456	.6584
22	.0671	.9709	.7796	.9709	1.086	.9114	1.0349
23	.0572	1.0242	.9145	.9145	.961	1.0829	.924
24	.8916	.0572	.6127	.8048	.8596	.924	1.0349
Max	.8916	1.7002	1.6598	1.7177	1.7353	1.5844	1.9616
Min	.0072	.0572	.4694	.4451	.4054	.4534	.6584
Avg	.2636	.8573	1.0265	1.0810	1.1124	1.1297	1.2523

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 202 / 11 KV LOKMAT

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.1966	.4268	.4588	.3788	.4054	.4374
2	.3544	.2012	.4268	.4534	.3841	.3666	.3658
3	.4271	.2012	.4161	.4428	.3841	.3467	.3567
4	.2987	.2012	.4161	.3948	.3894	.3368	.3475
5	.2721	.218	.4054	.4161	.3894	.317	.3715
6	.2454	.2229	.3948	.4054	.3948	.3121	.3894
7	.2187	.1783	.3841	.3567	.3018	.3269	.3418
8	.1646	.2389	.463	.4161	.2286	.3307	.5182
9	.1635	.5792	.7461	.6554	.7011	.7796	.8688
10	.1677	.6478	.8596	.9412	.8596	1.0242	1.1949
11	.2469	1.0456	.9709	1.1317	.961	.961	1.358
12	.2058	.8505	.8505	.9511	.8505	.8413	1.2826
13	.141	.823	.8048	.8322	.9015	.8916	1.1706
14	.2058	.9511	.961	1.1949	.8779	1.0456	1.2071
15	.1829	1.1317	.9511	1.1203	1.0456	.9511	1.2826
16	.2195	.961	.9511	1.0456	.9709	.961	1.1317
17	.1783	.8322	.679	.9214	.8596	.8505	1.0456
18	.1372	.7712	.7293	.8688	.7377	.7377	.788
19	.1463	.5693	.6325	.6859	.6554	.7125	.788
20	.2195	.4999	.6104	.5365		.6325	.663
21	.1829	.4999	.4801	.583	.4534	.4054	.3864
22	.2012	.5761	.4321	.6653	.4938	.4012	.506
23	.2012	.5182	.4481	.5144	.4161	.4588	.4877
24	.4207	.1966	.4534	.4588	.4108	.4161	.4481
Max	.4271	1.1317	.9709	1.1949	1.0456	1.0456	1.358
Min	.1372	.1783	.3841	.3567	.2286	.3121	.3418
Avg	.2320	.5463	.6205	.6854	.6107	.6172	.7391

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 206 / 11 KV MIDC Water Supply

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377		.0377	.0377	.0377	.0377
2	.0377	.0377	.0377	.0377	.0377	.0377	.0377
3	.0377	.0377	.0377	.0377	.0377	.0377	.0377
4	.0377	.0377	.0377	.0377	.0377	.0377	.0377
5	.0377	.0377	.0377	.0377	.0377	.0377	.0377
6	.0377	.0377	.0377	.0377	.0377	.0377	.0377
7	.0377	.0377	.0377	.0377	.0377	.0377	.0377
8	.0377	.0377	.0377	.0377	.0377	.0377	.0377
9	.0377	.0377	.0377	.0377	.0377	.0377	.0377
10	.0377	.0377	.0377	.0377	.0377	.0377	.0377
11	.0377	.0377	.0377	.0377	.0377	.0377	.0377
12	.0377	.0377	.0377	.0377		.0377	.0377
13	.0377	.0377	.0377	.0377	.0377	.0377	.0377
14	.0377	.0377	.0377	.0377	.0377	.0377	.0377
15	.0377	.0377	.0377	.0377	.0377	.0377	.0377
16	.0377	.0377	.0377	.0377	.0377	.0377	.0377
17	.0377	.0377	.0377	.0377	.0377	.0377	.0377
18	.0377	.0377	.0377	.0377	.0377	.0377	.0377
19	.0377	.0377	.0377	.0377	.0377	.0377	.0377
20	.0377	.0377	.0377	.0377		.0377	.037
21	.0377	.0377	.0377	.0377	.0377	.0377	.037
22	.0377	.0377	.0377	.0377	.0377	.0377	.037
23	.0377	.0377	.0377	.0377	.0377	.0377	.0377
24	.0377	.0377	.0377	.0377	.0377	.0377	.0377
Max	.0377	.0377	.0377	.0377	.0377	.0377	.0377
Min	.0377	.0377	.0377	.0377	.0377	.0377	.037
Avg	.0377	.0377	.0377	.0377	.0377	.0377	.0376

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244066 / 33/11 KV SIE

Feeder No / Name : 207 / 11 KV Bharat Steel

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0122	.0122	.0091	.0091	.0061	.0107	.0107
2	.0122	.0122	.0122	.0091	.0122	.0091	.0122
3	.0122	.0152	.0122	.0122	.0122	.0091	.0152
4	.0122	.0244	.0137	.0122	.0122	.0061	.0213
5	.0122	.0305	.0259	.0122	.0122	.0061	.0305
6	.0122	.0625	.0213	.0122	.032	.0351	.0381
7	.0122	.0625	.0259	.029	.0274	.029	.1029
8	.0122	.1738	.2439	.2865	.9054	.3086	1.1317
9	.0107	.8718	1.5089	1.5089	.8299	1.643	.7316
10	.0122	.7042	.6722	1.5089	.3315	1.0349	.9808
11	.0091	.7545	1.4335	.8299	.7461	.8962	1.0562
12	.0091	.679	1.0242	1.1949		1.4335	.7545
13	.0008	1.0242	1.1203	.9808	.9313	1.5364	1.2826
14	.0091	1.1317	.7545	.1372	.7011	.2743	1.6598
15	.0133	.8299	1.2071	.3239	1.4883	.7545	1.0456
16	.0213	.8048	.8131	1.3443	1.1218	1.4937	.8048
17	.0213	.7468	1.1317	1.0349	1.1088	1.1088	.8299
18	.0716	.7545	.7545	1.3443	.0061	.724	.8299
19	.0133	1.5089	.0061	.7316	.0107	.0091	.0122
20	.0152	.0122	.0061	.0122		.0091	.0061
21	.0133	.0122	.0061	.0122	.0107	.0229	.0046
22	.0133	.0122	.0213	.0122	.0061	.0168	
23	.0133	.0122	.0091	.0152	.0061	.0061	.0122
24	.0122	.0152	.0091	.0091	.0152	.0107	.0107
Max	.0716	1.5089	1.5089	1.5089	1.4883	1.643	1.6598
Min	.0008	.0122	.0061	.0091	.0061	.0061	.0046
Avg	.0149	.4278	.4518	.4743	.3788	.4745	.4950

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MADHAVNAGAR[070]

BU 1236

Substation No/ Name :- 244095 / 33/11 KV KUPWAD CITY

Feeder No / Name : 207 / 11 KV Kupwad City

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
12	.0754
Max	.0754
Min	.0754
Avg	.0754

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 201 / 11 KV MIRAJ CITY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0903	1.2012	1.2127	1.0117	1.1643	1.1827	1.2567
2	1.0534	1.1643	1.2012	.9945	1.0719	1.1088	1.2012
3	1.0534	1.0974	1.1949	.9945	1.0719	1.1088	1.1145
4	1.0534	1.0608	1.2012	.9945	.9945	1.1088	1.1145
5	1.1458	1.086	1.1765	1.0631	1.0288	1.1273	1.2346
6	1.2003	1.3032	1.2382	1.166	1.0974	1.0631	1.2689
7	1.2689	1.267	1.3817	1.2346	1.3032	1.2174	1.3375
8	1.3889	1.3466	1.4415	1.3676	1.386	1.3032	1.4299
9	1.386	1.2689	1.4563	1.3756	1.3032	1.3375	1.4506
10	1.1949	1.1919	1.2752	1.4083	1.2517	1.3575	1.3756
11	1.1458	1.2308	1.2715	1.3535	1.3672	1.2894	1.4299
12	1.1576	1.1488	1.2174	1.262	1.3611	1.4661	1.4118
13	1.0164	1.1488	1.046	1.2254	1.3253	1.3394	1.3432
14	.9896	1.0566	1.0136	1.1888	1.0745	1.2803	1.2178
15	.9055	1.0498	.9709	1.1157	1.0679	1.2803	1.2308
16	1.0534	1.086	1.0631	1.0924	1.1946	1.3169	1.2308
17	1.1203	1.1145	1.1403	1.1641	1.2308	1.262	1.3213
18	1.2197	1.262	1.0745	1.2445	1.2178	1.4373	1.382
19	1.6832	1.5939	1.4842	1.7372	1.6297	1.7147	1.773
20	1.7556	1.8298	1.7741	1.7556	1.6651	1.8461	1.8642
21	1.6827	1.7372	1.6644	1.6461	1.5089	1.7013	1.828
22	1.6095	1.6617	1.5364	1.6078	1.4403	1.7187	1.7556
23	1.386	1.46	1.3676	.5959	1.286	1.4969	1.5708
24	1.1273	1.2197	1.2883	.2572	1.2197	1.2752	1.3306
Max	1.7556	1.8298	1.7741	1.7556	1.6651	1.8461	1.8642
Min	.9055	1.0498	.9709	.2572	.9945	1.0631	1.1145
Avg	1.2370	1.2745	1.2788	1.2024	1.2609	1.3475	1.3947

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 204 / 11 KV MEDICAL COLLEGE
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
13	.0189
24	.0189
Max	.0189
Min	.0189
Avg	.0189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 205 / 11KV Dairy Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6099	.6838	.7095	.6401	.6283	.6653	.7468
2	.5729	.6535	.6838	.5973	.5975	.6161	.6348
3	.5729	.6468	.6335	.5973	.5975	.6161	.6348
4	.5729	.6722	.6268	.5973	.5975	.6161	.6348
5	.6283	.7095	.6089	.5973	.5975	.6283	.6535
6	.6348	.8029	.6348	.6219	.6722	.6348	.6722
7	.7842	.7655	.7023	.7282	.7947	.6348	.7095
8	.7762	.8131	.7095	.7282	.7655	.6468	.8029
9	.8589	.8501	.7392	.8488	.7922	.6767	.8488
10	.8131	.8501	.8589	.8676	.811	.695	.9242
11	.8029	.8686	.8686	.9522	.7733	.7468	.924
12	.7964	.8316	.7392	.8402	.8215	.7577	.9593
13	.7655	.8413	.8131	.8589	.7842	.7783	.9709
14	.7468	.7762	.7762	.8402	.7468	.7468	.924
15	.6838	.8029	.8215	.8215	.7282	.7133	.8501
16	.7095	.7842	.8131	.7655	.7282	.7095	.9522
17	.6653	.8048	.8131	.8048	.7133	.724	.9511
18	.7023	.7577	.823	.8507	.7316	.7602	.9145
19	1.0059	1.0269	.9694	1.0534	.9593	.9955	1.0791
20	1.0136	1.0349	1.0425	1.0387	.9412	1.0242	1.134
21	.9694	.9709	.9694	.9412	.9145	.9425	1.0608
22	.8596	.9425	.9619	.9425	.9145	.961	1.0349
23	.7762	.8215	.8589	.8131	.8131	.8686	.961
24	.6468	.7095	.7207	.7207	.7207	.7392	
Max	1.0136	1.0349	1.0425	1.0534	.9593	1.0242	1.134
Min	.5729	.6468	.6089	.5973	.5975	.6161	.6348
Avg	.7487	.8092	.7874	.7945	.7560	.7457	.8686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 206 / Vidya nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3511	.3841	.3921	.4024	.3881	.3881	.4108
2	.3326	.3696	.3696	.3801	.3734	.3734	.3921
3	.3326	.3696	.362	.3801	.3734	.3734	.3921
4	.3326	.3547	.3582	.3801	.3734	.3734	.3921
5	.3511	.3547	.3761	.3982	.3734	.3696	.4294
6	.4668	.4108	.4668	.439	.4108	.3921	.4854
7	.4481	.4108	.4066	.4294	.4066	.4108	.4481
8	.4251	.4066	.4294	.4294	.4108	.4066	.4108
9	.3734	.3881	.3881	.415	.4527	.3961	.3961
10	.3696	.3511	.3921	.3772	.3772	.3801	.3772
11	.3174	.3511	.3142	.3547	.3361	.3658	.3361
12	.2896	.3326	.3142	.3547	.3547	.3734	.3475
13	.2957	.3292	.2957	.3174	.3361	.3841	.3475
14	.2801	.3142	.2957	.3174	.3174	.3734	.362
15	.2772	.2987	.3174	.3361	.3361	.3921	.3658
16	.2614	.2801	.3326	.3174	.3547	.4108	.3658
17	.2772	.2926	.3326	.3292	.3292	.362	.3475
18	.3475	.3326	.3475	.3439	.3475	.4344	.4024
19	.5304	.4854	.3658	.5544	.4887	.5249	.5487
20	.567	.5544	.5853	.5731	.5249	.5853	.6036
21	.5487	.5601	.567	.5249	.5121	.5729	.6036
22	.5121	.5544	.5658	.5544	.5121	.5544	.5914
23	.4805	.5041	.5228	.4805	.462	.4805	.5544
24	.3696	.4108	.4066	.4435	.4251	.4251	.4294
Max	.567	.5601	.5853	.5731	.5249	.5853	.6036
Min	.2614	.2801	.2957	.3174	.3174	.362	.3361
Avg	.3807	.3917	.3960	.4097	.3990	.4209	.4308

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244008 / 33/11 KV MIRAJ

Feeder No / Name : 401 / 33 KV Bedag outgoing(
Crossove Feeder KV- 33 /
INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.2593	6.31	6.7215	6.7873	6.2049	7.0988	6.6873
2	4.2593	6.4615	1.3306		5.8642	6.8416	6.4301
3	4.2593	6.5158	6.1614		5.8642	6.8416	6.4301
4	4.9954	6.6084	5.9877		5.9945	6.8416	6.4301
5	5.1532	8.6877	5.5813		6.1214	7.0988	6.9959
6	6.4152	10.2081	9.0369		8.5185	8.7449	7.5617
7	9.6228	11.0677	10.8665	9.3936	11.3169	10.391	9.4559
8	2.5206	2.4446	2.6612	2.552	2.1605	2.6235	2.8235
9	7.8189	6.6358	9.6342	10.2058	10.4424	11.7827	11.4569
10	8.906	7.3091	9.0535	10.5779	11.5512	11.8736	9.0678
11	5.7659	9.4125	8.8992	10.4184	11.5512	11.8736	6.4615
12	6.2734	9.6194	7.8704	10.2081	11.2289	11.5655	10.751
13	8.2053	9.1564	10.0309	10.4801	10.0995	11.0677	11.0225
14	7.5617	6.3272	6.9959	10.2624	10.3652	10.7991	11.0677
15	6.8747	9.0021	9.6108	10.3167	10.4716	11.5512	10.9499
16	7.3183	8.3219	9.828	10.423	9.5022	11.0563	11.0677
17	1.9605	1.9547	1.9004	2.2028	2.3148	2.2085	1.9547
18	1.9136		2.2262	2.3663	2.4188	2.4714	2.7401
19	2.8086	2.2611	2.6863	2.7263	2.7778	2.8292	3.2922
20	2.9447	3.1367	3.1824	2.9835	2.8807	2.9321	3.5665
21	2.7938	2.9938	3.0727	2.7869	2.572	2.8292	2.7938
22	7.7824	9.3542	8.3951	8.2305	9.0021	8.4362	7.7618
23	6.9502	8.1499	7.6818	7.1502	7.9733	7.5103	6.6941
24	4.2593	6.2934	7.5057	7.2074	6.4815	7.4074	6.9959
Max	9.6228	11.0677	10.8665	10.5779	11.5512	11.8736	11.4569
Min	1.9136	1.9547	1.3306	2.2028	2.1605	2.2085	1.9547
Avg	5.4843	6.8797	6.5384	7.2252	7.2366	7.6948	7.1024

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244070 / 33/11 KV KRIPAMAI

Feeder No / Name : 201 / 11 KV KRIPAMAYEE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	.0199
Max	.0199
Min	.0199
Avg	.0199

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 201 / 11KV Jagdish IRON

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8107	.1492	.743	.7579	1.5466	1.773	1.7718
2	1.9616	.192	.6802	.7526	1.6975	1.7147	1.829
3	1.8673	.2187	.6447	.6767		1.7147	1.8673
4	1.8107	.2134	.5449	.7579	1.9616	1.6598	1.9239
5	2.0182	.2109	.4344	.743	2.1148	1.6598	2.2634
6	1.7541	.2241	.2263	.695	2.2672	1.5844	2.4897
7	2.3765	.2928	.7145	.724	2.3434	1.3203	2.3954
8	1.829	.0953	.4548	.6859	2.4006	1.3203	2.2257
9	.2606	.1429	.4572	.1823	1.3908	1.1431	.9568
10	.2724	.4904	.5335	.8025	1.1317	1.8861	1.9239
11	.262	.9997	.5573	.3086	1.5089	1.8673	2.5086
12	.1753	.9335	.6447	.6584	1.6221	1.5432	2.3011
13	.2721	1.1128	.6805	.8478	1.5844	1.8296	2.4897
14	.2818	.9808	.8097	.9362	1.5844	1.905	1.9774
15	.1437	1.0374	.9231	.9156	1.5466	1.6598	2.4958
16	.1595	.7716	.9808	.8817	1.5089	1.8861	2.5274
17	.1174	.8745	.8223	.787	1.3336	1.8296	1.8673
18	.08	.787	.2743	.8482	1.6004	2.1719	1.6956
19	.1315	.8078	.787	.9116	1.5242	2.5149	1.922
20	.1122	.7968	.2172	.8697	1.2193	2.2862	2.2822
21	.1029	.8421	.695	.7074	1.5242	2.1691	2.1529
22	.12	.7977	.8078	.9526	1.7147	2.1338	2.553
23	.1174	.8124	.7827	2.32	1.7353	2.3815	1.1506
24	1.7164	.1235	.743	.724	1.5466	1.773	1.7718
Max	2.3765	1.1128	.9808	2.32	2.4006	2.5149	2.553
Min	.08	.0953	.2172	.1823	1.1317	1.1431	.9568
Avg	.8231	.5795	.6316	.8103	1.6699	1.8220	2.0559

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 202 / 11 KV Mahabal

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4335	.1492	1.3014	1.3392	.8413	1.358	1.5089
2	1.2696	.1713	1.2449	1.2696	.8413	1.3957	1.3676
3	1.3392	.1547	1.1389	1.358	.924	1.3957	1.2489
4	1.3957	.1492	1.1763	1.1949	1.0562	1.448	1.134
5	1.1643	.1879	1.2197	1.1203	1.1694	1.448	1.0719
6	1.4335	.3201	1.2696	1.3769	1.2826	1.4861	.8779
7	.1646	.4489	.8962	1.1949	1.3256	1.4861	1.4146
8	.1635	.7602	1.1506	1.1694	1.358	1.448	1.6575
9	.2229	1.4098	1.105	1.6194	1.6385	1.829	1.9243
10	.2315	1.9427	1.3957	1.7528	1.2826	1.5051	1.3717
11	.2229	2.0748	1.6409	1.7541	1.5242	2.1125	.5281
12	.1372	1.4523	.8488	1.6598	1.6004	1.773	1.0374
13	.1955	1.9993	.9896	1.5813	1.5623	.9619	1.1317
14	.1086	1.094	1.2449	1.5089	1.5623	1.3817	1.3957
15	.1943	1.5844	1.1431	1.773	1.5623	1.773	1.9427
16	.181	1.7164	1.1241	1.1128	1.4861	1.9427	1.8673
17	.1572	1.8673	1.9993	1.6598	1.4098	1.358	1.7353
18	.0874	1.5432	.8048	1.0642	.9709	1.6385	1.6575
19	.1132	1.0642	1.4523	1.6385	.9709	.961	1.1763
20	.1389	1.1317	.8145	.8865	.924	1.0562	1.6194
21	.0572	1.226	1.5466	1.4901	.9335	1.0974	1.0374
22	.0854	.961	.8596	1.4901	.9709	.9431	1.5813
23	.1029	1.2323	1.4146	.7011	1.1317	1.4901	1.4523
24	.7186	.1387	1.3014	.788	1.5466	1.358	1.5089
Max	1.4335	2.0748	1.9993	1.773	1.6385	2.1125	1.9427
Min	.0572	.1387	.8048	.7011	.8413	.9431	.5281
Avg	.4716	1.0325	1.2118	1.3543	1.2448	1.4436	1.3854

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 203 / 11KV Shreeji

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3467	.0781	.3077	.415	.3584	.2865	.3921
2	.3761	.0796	.3475	.3881	.3772	.3658	.3395
3	.3294	.0686	.3696	.3475	.415	.3658	.3077
4	.3681	.0964	.415	.3696	.4527	.4066	.2926
5	.3582	.1006	.3734	.4024	.4066	.4066	.3174
6	.3582	.1086	.3326	.3439	.3841	.439	.3511
7	.3366	.2214	.5093	.5716	.5041	.4755	.4715
8	.0686	.3982	.4668	.5228	.4835	.4755	.5228
9	.0838	.5658	.7356	.7733	.6099	.7545	.6979
10	.0975	.7356	.7545	.8299	.7621	.7733	.7095
11	.0974	.7545	.7922	.7356	.7545	.7545	
12	.1006	.6602	1.6409	.7545	.7545	.7733	.7167
13	.1217	.6413	.6413	.5093	.7621	.6413	.8002
14	.12	.743	.7468	.7545	.7621	.7167	.8299
15	.0669	.7468	.8002	.7545	.7356	.7811	.7545
16	.0634	.679	.7356	.7545	.7356	.7356	.7167
17	.0532	.6413	.6413	.6979	.7167	.6979	.7356
18	.0857	.5975	.6099	.6224	.6413	.6468	.6653
19	.0762	.6036	.6099	.6161	.5544	.6099	.6283
20	.065	.6602	.3982	.4207	.3224	.679	.4108
21	.0667	.6173	.3292	.3582	.3086	.6979	.3511
22	.0545	.1698	.218	.2315	.25	.2372	.2343
23	.0419	.2896	.3961	.4801	.2743	.3547	.3439
24	.4557	.0817	.3077	.4338	.3584	.2865	.3921
Max	.4557	.7545	1.6409	.8299	.7621	.7811	.8299
Min	.0419	.0686	.218	.2315	.25	.2372	.2343
Avg	.1747	.4308	.5616	.5453	.5285	.5567	.5209

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 204 / 11KV JK ICE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3567	.8436	.8848	.9945	.9172	.743
2		.3239	.7926	.8848	.9116	.8642	.743
3		.3567	.7335	.8162	.8421	.8642	.6722
4		.3231	.6815	.8684	.7621	.7811	.6401
5		.3012	.6179	.6908	.7375	.7811	.5959
6		.2675	.5784	.385	.6859	.7499	.5462
7		.4209	.6882	.5281	.8383	.6706	.4401
8		.5761	.7042	.6135	.7282	.6706	.6661
9		.8421	.9465	.8842	1.0903	1.5844	1.5623
10		1.8484	1.0185	1.4901	1.2193	1.4377	1.773
11		1.358	1.1317	1.6221	1.5242	1.6032	
12		1.1506	1.1128	1.3203	1.6766	1.3957	1.7541
13		1.7353		1.0269	1.5466	1.1883	1.6598
14	.2804	1.5844	1.2449	1.2071	1.4563	1.6409	1.7164
15	.3048	1.8107	1.3957	1.3392	1.5089		1.7541
16	.3109	1.9433	1.0751	1.7541	1.5844	1.0374	1.358
17	.3206	1.7164	.9362	1.7164	1.6766	1.6032	1.6975
18	.3595	.9568	.703	1.0608	1.5242	1.5844	.9362
19	.2429	.8886	.6539	.9955	1.3443	.6636	.9877
20	.2423	.9945	.6859	.763	.6958	.8097	.6984
21	.208	1.0631	.6687	.6859	.6958	.8916	.7225
22	.3189	.8954	.7074	.6226	.7362	.6371	.852
23	.3807	.9122	.9496	.9665	.8002	1.4413	.9069
24		.3837	.8436	1.0056	.9945	.9172	.743
Max	.3807	1.9433	1.3957	1.7541	1.6766	1.6409	1.773
Min	.208	.2675	.5784	.385	.6859	.6371	.4401
Avg	.2969	.9587	.8571	1.0055	1.1073	1.0754	1.0508

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 205 / 11KV Shakti

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9313	.1486	.578	.571	.4214	.5898	.5571
2	.815	.1713	.6081	.6226	.3961	.6299	.5344
3	.7421	.1543	.5735	.5601	.3572	.6299	.5121
4	.8954	.1713	.5735	.6613	.3894	.6706	.4687
5	.8505	.1536	.5636	.5571	.3429	.6706	.506
6	.7362	.1372	.6062	.4961	.3601	.6516	.5344
7	.6415	.2115	.6539	.583	.3487	.7164	.4877
8	.2229	.5075	.788	.5053	.3978	.7164	.9795
9	.1707	.9593	1.0751	.788	.6783	1.2955	1.094
10	.192	1.1241	1.2449	.9425	1.0185	1.1317	1.2637
11	.1547	1.2071	1.1431	1.0751	1.1431	.9808	1.1812
12	.2191	2.0559	1.2826	1.2449	1.1812	1.3203	1.2826
13	.2058	1.7353	.8495	.7167	1.3336	1.2826	1.358
14	.1658	1.5466	1.1317	.7167	1.448	1.2071	1.5089
15	.5281	1.4098	1.2637	1.2574	1.4861	1.2449	1.5655
16	.1492	1.5123	1.7353	1.5051	1.5242	.1425	1.8107
17	.1069	1.8484	1.5278	1.4969	1.6385	1.7164	1.1883
18	.1105	1.358	1.5844	1.2826	.8779	1.1506	.9619
19	.16	.9979	.9955	1.358	.8779	.9511	1.2826
20	.1658	1.1317	.9979	.4858	.924	.9979	1.0269
21	.2126	1.226	.9877	.4475	.8779	1.0751	.9709
22	.2012	1.0745	.823	.3944	.8326	.7087	.8962
23	.1372	.9313	.8859	.431	.6859	.961	1.0374
24	.8413	.1372	.578	.6952	.4214	.5898	.5571
Max	.9313	2.0559	1.7353	1.5051	1.6385	1.7164	1.8107
Min	.1069	.1372	.5636	.3944	.3429	.1425	.4687
Avg	.3982	.9129	.9605	.8081	.8318	.9180	.9819

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 206 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6617	.9694	1.8296	1.475	1.0924	1.3957	1.5655
2	1.5684	.9134	1.7918	1.419	1.2489	1.5089	1.5089
3	1.2382	1.0136	1.5089	1.2567	1.3443	1.5089	1.4415
4	1.5181	.929	1.6409	1.3306	1.3717	1.5432	1.419
5	1.262	.8954	1.5497	1.2254	1.4299	1.5432	1.3535
6	1.1041	1.134	1.2936	1.1888	1.5524	1.5466	1.386
7	.9259	1.2323	1.1706	1.5123	.8987	1.5466	1.4003
8	.4801	1.1827	1.8484	1.0631	1.4815	1.4937	1.2308
9	.6241	1.4523	1.9052	1.226	1.5844	1.448	1.3957
10	.9694	1.5466	1.8296	2.1338	1.7147	1.6766	1.2071
11	.4633	1.9993	1.9993	1.467	1.6004	1.6032	
12	.6935	1.9616	1.4335	1.3957	1.3717	1.4523	2.1313
13	.5093	1.8296	1.6956	1.7541	1.4098	1.7164	1.358
14	.6135	1.7147	2.0748	1.9239	1.448	1.8107	1.9239
15	.112	1.773	2.3243	1.9052	1.3717	2.0767	2.0936
16	.1278	1.9052	2.2257	1.9243	1.3336	2.037	1.9993
17	.6371	1.6409	1.5089	1.7353	.8962	2.0182	1.7353
18	.9231	1.467	1.5655	1.7541	1.5089	1.5844	1.9243
19	1.0082	1.1389	1.6057	1.5497	1.4937	1.6032	1.7353
20	1.0349	1.2449	1.2437	1.2254	1.4937	1.6221	1.3769
21	1.1706	1.3203	1.6598		1.4712	1.6409	1.6032
22	.9391	1.0498	1.2936	1.1584	1.4712	1.1949	1.1827
23	.664	.9231	1.4003	.7362	1.4335	1.6787	1.1403
24	1.5466	.905	1.8296	1.0985	1.0924	1.3957	1.5655
Max	1.6617	1.9993	2.3243	2.1338	1.7147	2.0767	2.1313
Min	.112	.8954	1.1706	.7362	.8962	1.1949	1.1403
Avg	.9081	1.3393	1.6762	1.4547	1.3798	1.6102	1.5512

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 207 / 11 KV Priyanka

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-SEP-17
HR	Load (MW)
24	.0189
Max	.0189
Min	.0189
Avg	.0189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 210 / 11KV Saptrang

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9522	.3048	.961	.4218	1.0642	.8501	.7964
2	.8413	.3281	.9145	.5426	1.0903	.7682	.7762
3	.9145	.3361	.8238	.7108	1.0136	.7682	.8215
4	.6984	.3281	.7291	.6173	.9492	.7164	.8316
5	.7888	.301	.5898	.5079	.8589	.7164	.8596
6	.3384	.3437	.3479	.3763	.7164	.6173	.8413
7	.924	.3765	.3567	.4534	.7343	.3429	.8779
8	.3395	.3666	.431	.381	.5304	.2667	.7522
9	.0945	1.0374	.3582	.9619	.9997	.9907	.9997
10	.0774	1.0562	.7316	1.2449	1.4098	1.0056	1.2071
11	.0884	1.3203	.8299	.9431	1.4098	1.4335	1.5089
12	.0972	1.3957	1.2071	1.1317	1.4098	1.358	1.5466
13	.0937		.7922	1.4335	1.3336	1.4335	1.3203
14	.0995	1.3203	1.0562	1.358	1.2574	.9431	1.358
15	.0347	1.358	.9808	1.6598	1.2193	.8299	1.0562
16	.0453	1.4335	1.1317	1.5089	1.3336	.7922	1.3203
17	.0533	1.2449	1.0562	1.5466	1.3336	1.1317	1.358
18	.0372	1.1128	.5426	1.2826	.9808	.8676	.5853
19	.0486	1.0562	.5138	.8779	.9335	.6722	.2824
20	.0486	1.1317	.3795	.7602	.4534	.7545	.4641
21	.2332	1.0751	.3437	.7682	.421	.7922	.4641
22	.3121	.924	.8413		.421	.8413	.7682
23	.2896	.924	.7522	.7964	.6859	.8048	.7682
24	1.0082	.3281	.961	.8413	1.0642	.8501	.7964
Max	1.0082	1.4335	1.2071	1.6598	1.4098	1.4335	1.5466
Min	.0347	.301	.3437	.3763	.421	.2667	.2824
Avg	.3524	.8436	.7347	.9185	.9843	.8561	.9317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 244085 / 33/11KV MIDC MIRAJ

Feeder No / Name : 401 / 33KV Super Craft Foundry NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4712	.0274	1.3014	1.829	1.6575	1.829	1.7718
2	1.358	.032	1.358	1.358	1.7147	1.8861	1.7147
3	1.358	.024	1.4146	1.3014	1.7147	1.8861	1.6004
4	1.3014	.0274	1.5844	1.4146	1.6004	1.829	1.4712
5	1.358	.02	1.4712	1.3014	1.5432	1.829	1.358
6	1.3014	.0229	1.3014	1.3443	1.7147	1.7718	1.3014
7	1.7147	.0229	1.7718	1.8861	1.6575	1.7718	1.7147
8	.0777	.032	1.2323	1.6575	1.7147	1.7147	1.2883
9	.088	.4344	1.7147	1.358	1.7718	1.4712	1.7147
10	.16	1.6975	1.7541	1.6975	1.8861	1.7718	1.8861
11	.1006	.4681	1.7541		1.829	1.7541	1.7541
12	.08	1.8673	1.4712	1.5278	1.6004	1.7718	1.7147
13	.04	1.7147	1.7541	1.7718	1.7147	1.3014	1.7541
14	.0412	1.5844	1.358	1.4712	1.829	1.6004	1.7541
15	.0366	1.7541	1.7147	1.7147	1.829	1.9239	1.7541
16	.0549	1.3014	1.6575	1.6409	1.7718	1.5278	1.358
17	.0549	1.7541	1.6975	1.3014	1.7718	1.6575	1.7541
18	.0229	1.6004	1.6975	1.6004	1.7718	1.5278	1.7147
19	.0274	1.829	1.4146	1.3014	1.6975	1.1963	1.6409
20	.0274	1.7147	1.5432	1.5844	1.6409	1.2346	1.6975
21	.024	1.6004	1.5844	1.6575	1.5844	1.4415	1.9433
22	.0274	1.4289	1.4146	1.6575	1.4712	1.3014	1.829
23	.024	1.3014	1.829	1.358	1.7147	1.7147	1.2003
24	1.7718	.032	1.3014	1.8861	1.6575	1.829	1.7718
Max	1.7718	1.8673	1.829	1.8861	1.8861	1.9239	1.9433
Min	.0229	.02	1.2323	1.3014	1.4712	1.1963	1.2003
Avg	.5217	.9288	1.5457	1.5487	1.7025	1.6476	1.6443

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

MIRAJ urban[071]

BU 1228

Substation No/ Name :- 248004 / 220 KV MIRAJ

Feeder No / Name : 402 / 33KV SONI

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	2.5892
Max	2.5892
Min	2.5892
Avg	2.5892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 201 / 11KV JACKWELL LIS

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6653	.5731	.6401	.6535	.6535	.6036	.6653
2	.6653	.5788	.6653	.6468	.6535	.6219	.7207
3	.6516	.6722	.6767	.6653	.6535	.6283	.7468
4	.6584	.7095	.6838	.6535	.6535	.6468	.7468
5	.7947	.7282	.6767	.6653	.7577	.6584	.7655
6	.7947	.7762	.7392	.6653	.7947	.7316	.7865
7	.5281	.5093	.6161	.6535	.6099	.6036	.7762
8	.6602	.6602	.6036	.679	.6401	.5788	.6535
9	.6535	.6348	.6036	.6602	.6468	.6722	.6602
10	.5847	.6348	.6161	.6036	.6602	.6348	.6224
11	.5788	.6468	.6602	.5975	.6602	.6413	.6224
12	.6036	.7762	.7783	.6036	.6413	.6602	.7655
13	.7392	.7842	.7133	.7468	.7947	.7577	.7392
14		.7842	.6722		.7947	.7762	.7392
15	.7133	.6468	.6602	.7392	.7947	.7762	.7392
16	.695	.6767	.6413	.6413	.6535	.6602	.7577
17	.4338	.6468	.2641	.5788	.6722	.6602	.7207
18	.4527	.5121	.6348	.5729	.6908	.6602	.7207
19	.4527	.5093	.7762	.5975	.5975	.6535	.7133
20	.5914	.5281	.6468	.5729	.5914	.6535	.5552
21	.5601	.5281	.6468	.5729	.6468	.5281	.3696
22	.5228	.5281	.5281	.4887	.4763	.5658	.5175
23	.5093	.5975	.6722	.6535	.6348	.6722	.6584
24	.6653	.5895	.5914	.6535	.6535	.5975	.6535
Max	.7947	.7842	.7783	.7468	.7947	.7762	.7865
Min	.4338	.5093	.2641	.4887	.4763	.5281	.3696
Avg	.6163	.6346	.6420	.6333	.6677	.6518	.684

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 202 / 11KV GANPATI MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7087	.8131	.815	.8238	.8238	.7619	.7796
2	.6878		.8328	.7973	.7802	.788	.788
3	.6878	.6584	.7888	.7796	.7802	.7619	.7783
4	.695	.6653	.7796	.7362	.6984	.7362	.7783
5	.7164	.6584	.7888	.7164	.6984	.7087	.7522
6	.7343	.695	.7796	.6984	.6984	.6733	.7499
7	.788	.724	.7316	.7421	.7796	.7133	.7796
8	.8417	.8145	.8145	.7421	.7602	.7265	.8238
9	.8326	.7888	.7783	.7522	.8145	.7783	.8063
10	.8238	.8413	.8954	.8238	.8775	.8682	.8688
11	.9568	.9536	.9745	.9492	1.0317	1.0631	.8954
12	.9745	.985	.9745	.9922	.9745	1.0277	.8682
13	.9568	1.0136	.9671	1.0534	.9922	.9991	.8589
14		.9511	.9412		.9391	.9745	.8328
15	.8505	.8779	.9328	.9313	.9134	.9134	.8596
16	.8063	.8869	.9391	.905	.9134	.8962	.8954
17	.9391	.9593		.9568	.9492	.9955	.8682
18	1.1694	1.3253	.9568	1.0517	1.0745	1.1641	.9114
19	1.5074	1.6126	1.56	1.6124	1.576	1.4899	1.4043
20	1.4022	1.5415	1.4899	1.5769	1.4723	1.5074	1.4022
21	1.2136	1.2934	1.2656	1.3575	1.1096	1.262	1.262
22	1.1443	1.1163	1.1043	1.1222	1.0277	1.1443	1.0923
23	.964	.9922	.9816	.9492	.8859	.9568	.9709
24	.7087	.8686	.8505	.8238	.8238	.8505	.8238
Max	1.5074	1.6126	1.56	1.6124	1.576	1.5074	1.4043
Min	.6878	.6584	.7316	.6984	.6984	.6733	.7499
Avg	.9178	.9581	.9540	.9519	.9331	.9484	.9104

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 203 / 11KV SANGLI WADI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.543	.5373	.591	.6161	.6516	.5914	.6653
2	.5249	.4805	.6154	.6348	.6154	.6099	.6584
3	.5359	.5601	.6268	.6653	.6154	.6219	.6584
4	.5359	.5544	.6516	.7095	.6283	.6099	.7095
5	.6413	.6653	.6584	.7545	.6722	.6219	.7282
6	.7733	.7733	.679	.7545	.7095	.6283	.7733
7	.823	.7842	.7468	.7655	.8501	.7282	.8048
8	.7421	.7842	.6838	.7577	.8326	.695	.8326
9	.7316	.7701	.7682	.7964	.8775	.7392	.9036
10	.6154	.7701	.7682	.7783	.8954	.7973	.9816
11	.5373	.7421	.7602	.7964	.8328	.8328	.9114
12	.543	.7059	.7522	.7442	.8413	.8059	.8413
13	.5792	.7265	.7522	.7442	.7701	.7796	.7796
14		.6241	.7602		.7522	.7682	.8688
15	.4525	.6762	.7499	.6516	.7421	.8326	.8596
16	.4706	.6762	.6626	.6516	.724	.8326	.8775
17	.5731	.6379	.724	.6805	.724	.8417	.8505
18	.7316	.6268	.7059	.7888	.6697	.985	.8859
19	.8869	.9231	1.0317	.9816	.905	1.0924	1.1043
20	.9511	.9145	.9877	1.0679	.8869	1.0679	1.1403
21	.8413	.8686	.9511	.9745	.7964	1.0425	1.0425
22	.7499	.8501	.8686	.8589	.7392	.9145	.9134
23	.7207	.695	.7468	.7362	.6468	.8048	.8048
24	.5552	.591	.5731	.6161	.6584	.5729	.7023
Max	.9511	.9231	1.0317	1.0679	.905	1.0924	1.1403
Min	.4525	.4805	.5731	.6161	.6154	.5729	.6584
Avg	.6547	.7057	.7423	.7620	.7515	.7840	.8457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 403 / 33 KV- BALAJIMANDIR

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6379	.591	.743		.7442	.9145	.6984
2	.6379	.5973	.743		.7602	.743	.6984
3	.6516	.6036	.743		.7602	.743	.691
4	.6516	.6036	.8002		.6984	.743	.7059
5	.6984	.6584	.8002		.7059	.743	.7133
6	.7059	.7207	.8002		.7059	.743	.7682
7	.7602	.7207	.8002		.691	.743	.7522
8	.7059	.7133	.743	.7059	.7059	.743	.6379
9	.743	.7442	.7842	.7059	.8145	.8002	.6836
10	.743	.7442	.8059	.9145	.8059	.7973	.7522
11	.6859	.6836	.9036	.9717	.8596	.8505	.7973
12	.6859	.6762	.9036	.9717	.8505	.8505	.7888
13	.6859	.6613	.8059	.8002	.8505	.8413	.7973
14		.6836	.8059		.7442	.8059	.8505
15	.6287	.7522	.7682	.9145	.7522	.8059	.9036
16	.6161	.7442	.7522	.9145	.7442	.8688	.8505
17	.5784	.743	.7522	.8316	.8573	.9134	.7802
18	.6241	.8002	.7522	.7202	.8002	.7973	.7802
19	.7362	.8573	.7282	.7122	.8002	.7522	.823
20	.7442	.8573	.7282	.7716	.8573	.8322	.8745
21	.7522	.9145	.7802	.823	.9145	.8413	.8842
22	.7682	.8573	.8505	.9036	.9145	.8505	.9036
23	.7059	.8573	.8059	.8505	.9145	.8596	.8596
24	.6379	.6447	.743	.7522	.7442	.9145	.7442
Max	.7682	.9145	.9036	.9717	.9145	.9145	.9036
Min	.5784	.591	.7282	.7059	.691	.743	.6379
Avg	.6863	.7262	.7851	.8290	.7915	.8124	.7808

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SANGLIWADI WEST ZONE[067] BU 4067

Substation No/ Name :- 244073 / 33/11 KV SHERINALA

Feeder No / Name : 404 / 33 KV -MJP SHERINALA STAGE NON SHEDDABLE EXPRESS HV FEEDERS
NO- Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1595	.1612	.1715	.3224	.3189	.1715	.1612
2	.1595	.1629	.1715	.3258	.3258	.1715	.1612
3	.1629	.1646	.1715	.1629	.3258	.1715	.1595
4	.1629	.1646	.1715	.1646	.3224	.1715	.3258
5	.1612	.3292	.1715	.1646	.3258	.1715	.1646
6	.1629	.1663	.1715	.1646	.3258	.1715	.3292
7	.1629	.3326	.3429	.3292	.1595	.3429	.1612
8	.3258	.1646	.1715	.1629	.1629	.1715	.1595
9	.1715	.1595	.168	.1629	.3258	.3429	.1578
10	.1715	.1595	.1612	.1715	.1612	.1595	.1612
11	.1715	.1578	.1595	.1715	.1612	.1595	.1595
12	.3429	.156	.1595	.1715	.1595	.3189	.3155
13	.1715	.1526	.1612	.3429	.1595	.1578	.1595
14		.1578	.3258		.1595	.1612	.1595
15	.3429	.1612	.3292	.3429	.3224	.3224	.3189
16	.1715	.1595	.1612	.1715	.1595	.1629	.1595
17	.1578	.3429	.1612	.1663	.1715	.1612	.156
18	.156	.1715	.1612	.3086	.3429	.3189	.3121
19	.1578	.1715	.156	.1526	.1715	.156	.1543
20	.1595	.1715	.156	.1543	.1715	.156	.1543
21	.1612	.1715	.3121	.3086	.1715	.1578	.3121
22	.1646	.1715	.1595	.1595	.1715	.1595	.1595
23	.1629	.1715	.1612	.1595	.1715	.1612	.3224
24	.1595	.1075	.1715	.3224	.3189	.1715	.1595
Max	.3429	.3429	.3429	.3429	.3429	.3429	.3292
Min	.156	.1075	.156	.1526	.1595	.156	.1543
Avg	.1861	.1829	.1920	.2202	.2319	.1988	.2060

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 201 / 11KV RAMMANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8954	.8145	.9526	.8954	.8299	.8764	.8326
2	.8764	.7602	.9145	.8573	.8299	.8192	.788
3	.8573	.7602	.8383	.8192	.7922	.8002	.788
4	.8383	.724	.8192	.8002	.7545	.7621	.7701
5	.8383	.7602	.8192	.8002	.7545	.8002	.8145
6	.8383	.7964	.8764	.8573	.7922	.8192	.8326
7		.8145	.8764	.8764	.7922	.8192	.8507
8	.9335	.8688	.8573	.9145	.8488	.8383	.8145
9	.9145	.8326	.8764	.9145	.8299	.8573	.8507
10	.9526	.8764	.8954	.8954	.7964	.8764	.8869
11	.8954	.9717	.9808	.9335	.8688	.8764	.8775
12	.8002	.9335	.8676	.9526	.905	.8002	.8688
13	.7811	.8573	.8299	.9717	.8596	.8573	.8869
14		.8573	.8299	.9526	.7602	.8192	.9412
15	.7577	.8383	.8299	.9335	.7783	.8383	.905
16	.7621	.8764	.8383	.8192	.7964	.8002	.9526
17	.8002	.8383	.8383	.8954	.7964	.7783	.9526
18	.9335	1.0669	.9145	.9526	.9335	.8326	1.0288
19	1.086	1.3527	1.2384	1.3014	1.3146	1.0317	1.3717
20	1.2489	1.3908		1.358	1.3146	1.2308	1.4289
21	1.1946	1.2955	1.2003	1.2071	1.2193	1.1584	1.3527
22		1.2384	1.1622	1.1317	1.1431	1.1041	1.2384
23		1.105	1.086	1.0185	1.0479		1.1431
24	.9145	.8507	.9907	.9145	.8676	.9145	.9231
Max	1.2489	1.3908	1.2384	1.358	1.3146	1.2308	1.4289
Min	.7577	.724	.8192	.8002	.7545	.7621	.7701
Avg	.9059	.9367	.9275	.9572	.9011	.8831	.9625

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 202 / 11KV SHAMRAO NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.6584	.8954	.8002	.7545	.8002	.7762
2	.7049	.6468	.8383	.7811	.7545	.7621	.7023
3	.7049	.6401	.8192	.7621	.7167	.724	.6584
4	.6859	.6468	.7811	.724	.679	.6859	.6584
5	.6668	.6219	.7049	.6859	.679	.6668	.7023
6	.6859	.6401	.7811	.7621	.679	.6859	.7762
7	.7621	.6838	.7621	.724	.679	.724	.7392
8	.7811	.7316	.7811	.724	.7167	.7621	.7577
9	.7811	.7392	.7621	.7621	.7545	.7621	.7316
10	.7621	.7621	.7621	.7621	.695	.7811	.7133
11	.724	.743	.7167	.7049	.7207	.7621	.7207
12	.7049	.7621	.7545	.743	.7133	.724	.7682
13	.7049	.724	.679	.7811	.6584	.724	.7762
14		.7049	.679	.743	.6838	.724	.7499
15	.6097	.6859	.6413	.6859	.6767	.724	.7865
16	.6283	.6859	.6478	.6668	.695	.743	.8002
17	.6097	.6668	.6478	.6478	.6036	.6584	.7621
18	.6478	.743	.6478	.724	.6859	.6401	.7811
19	.8962	1.0669	.9717	.9808	1.0098	.9328	1.0669
20	.9979	1.086		1.0562	1.0098	1.0425	1.1812
21	.9694	1.0479	1.0288	1.0185	1.0288	.9877	1.1431
22		1.0288	.9907	1.0185	1.0098	.9877	1.0669
23		.9526	.9145	.9054	.9335		1.0288
24	.724	.7316	.9526	.8002	.7922	.8383	.823
Max	.9979	1.086	1.0288	1.0562	1.0288	1.0425	1.1812
Min	.6097	.6219	.6413	.6478	.6036	.6401	.6584
Avg	.7369	.7667	.7895	.7902	.7637	.7758	.8196

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 204 / 11KV CIVIL HOSPITAL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5601	.5716	.6478	.5281	.5716	.5975
2		.5788	.5335	.6478	.5281	.5335	.5975
3	.5525	.5228	.5525	.6287	.5281	.4763	.5228
4	.5716	.5228	.5525	.6287	.5281	.4572	.5601
5	.5906	.5601	.5525	.6287	.5658	.6097	.5975
6	.6097	.5788	.6097	.6668	.6036	.6478	.6348
7	.6097	.5975	.6287	.6478	.5658	.6668	.6348
8	.6097	.6535	.6097	.6287	.4904	.4954	.6722
9	.6859	.6722	.7621	.6859	.4527	.5525	.6722
10	.6478	.6478	.5906	.7049	.5975	.6097	.7282
11	.6478	.6859	.6036	.6478	.6348	.5144	.5975
12	.4572	.5525	.5658	.6097	.5601	.5144	.5601
13	.381	.5525	.547	.5716	.5041	.5906	.5415
14		.6287	.5658	.6097	.5788	.6097	.6535
15	.5144	.5525	.5658	.6097	.5975	.6287	.6348
16	.5906	.5906	.5716	.4191	.4294	.4763	.6287
17	.381	.4001	.5335	.5906	.5601	.5415	.4954
18	.6097	.5525	.5335	.6287	.5716	.5975	.6287
19	.6348	.7049	.6668	.6036	.6478	.6722	.7621
20	.6348	.724		.679	.6859	.5041	.724
21	.6535	.724	.5525	.7167	.7049	.6908	.7049
22		.5716	.5906	.7167	.6668	.5601	.724
23		.6287	.6478	.5281	.6097		.7049
24	.4954	.5788	.5716	.6478	.679	.6097	.5601
Max	.6859	.724	.7621	.7167	.7049	.6908	.7621
Min	.381	.4001	.5335	.4191	.4294	.4572	.4954
Avg	.5696	.5976	.5861	.6289	.5758	.5709	.6307

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 205 / Hanuman Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5121	.6097	.6097	.5281	.6097	.5487
2	.5335	.4755	.5716	.5906	.4904	.5716	.5175
3	.5335	.4805	.5525	.5716	.4904	.4954	.5121
4	.5144	.4805	.5335	.5525	.4904	.5144	.5175
5	.5335	.5175	.5335	.5335	.5281	.5335	.5544
6	.5525	.5544	.5716	.5716	.5281	.5144	.5853
7	.6097	.5487	.5525	.5335	.4904	.4763	.5487
8	.5716	.5487	.5335	.5144	.4904	.5144	.4938
9	.4954	.4938	.4763	.4954	.4527	.4763	.462
10	.4191	.4572	.4763	.4191	.439	.4572	.439
11	.4001	.4572	.415	.4191	.3658	.4572	.4251
12	.381	.4382	.415	.4191	.4024	.2096	.4024
13	.381	.4001	.415	.4191	.4024	.5525	.4066
14		.4001	.415	.4191	.3841	.4954	.4435
15	.362	.381	.415	.4191	.3881	.381	.439
16	.3429	.381	.4191	.381	.4024	.4763	.4572
17	.3239	.362	.381	.3429	.4207	.439	.4191
18	.381	.4763	.4191	.4191	.4572	.4755	.4763
19	.6283	.7621	.6668	.679	.6478	.7392	.7049
20	.7207	.8002		.7167	.6668	.7865	.8573
21	.7392	.7811	.724	.7167	.8002	.7682	.8192
22		.7621	.743	.7167	.724	.7499	.8192
23		.7049	.6859	.6413	.6668		.743
24	.5716	.5121	.6478	.6097	.5658	.6287	.567
Max	.7392	.8002	.743	.7167	.8002	.7865	.8573
Min	.3239	.362	.381	.3429	.3658	.2096	.4024
Avg	.5032	.5286	.5292	.5296	.5093	.5357	.5483

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 206 / 11KV TRIMURTI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6668	.5975	.6859	.6478	.6413	.6859	.6535
2	.6478	.5975	.6668	.6478	.6413	.6478	.5975
3	.6287	.5601	.6287	.6287	.6413	.6097	.5975
4	.6097	.5601	.6097	.5906	.679	.5906	.5601
5	.5906	.5601	.6097	.5906	.7167	.5906	.5975
6	.5716	.6161	.6287	.6668	.679	.5906	.6348
7	.6859	.6535	.6859	.6668	.679	.6287	.6722
8	.7049	.7282	.6859	.6478	.6036	.6668	.6908
9	.7621	.7655	.724	.6478	.6413	.8383	.7282
10	.9717	.8764	.8192	.9717	.8589	.8002	1.0269
11	.9907	1.0098	.9808	1.0479	.9149	.8383	1.0456
12	.9335	1.0288	.9431	1.0288	.8775	.8764	1.0642
13	.8954	.9526	.8676	1.0098	.9149	.8383	1.1576
14		.9145	.8676	.9717	.8215	.8192	1.0829
15	.8383	.9335	.9054	.9335	.8402	.743	1.0082
16	.8383	.9526	.9145	.9717	.8402	.8192	1.105
17	.8954	.9717	.9526	1.0288	.8215	.8029	1.1241
18	.9145	.9907	.9145	.9717	.8764	.8775	1.105
19	1.0829	1.1812	1.1241	1.1694	1.1241	1.0456	1.2574
20	1.1016	1.1431		1.1694	1.1431	1.1389	1.2765
21	1.0642	1.0669	1.086	1.094	1.0479	1.0456	1.1622
22		.8954	.9145	.8676	.9335	.9149	.8573
23		.8002	.8192	.7167	.7811		.8383
24	.7049	.6161	.724	.6668	.6413	.724	.6722
Max	1.1016	1.1812	1.1241	1.1694	1.1431	1.1389	1.2765
Min	.5716	.5601	.6097	.5906	.6036	.5906	.5601
Avg	.8143	.8322	.8156	.8481	.8066	.7884	.8965

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244039 / 33/11 KV SANGLI CITY

Feeder No / Name : 403 / 33 KV RISALA ROAD

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4577	2.0416	2.7435	2.3434	2.3765	2.572	2.2565
2	2.2862	1.9342	2.4577	2.2862	2.2634	2.572	2.1491
3	2.2291	1.9342	2.2291	2.2862	2.1502	2.3434	2.0953
4	2.1148	1.8804	2.1148	2.1148	2.1502	2.2291	2.0416
5	2.0005	1.8267	2.1719	2.0005	2.1502	2.1148	2.0416
6	2.0576	1.8267	2.2862	2.2291	2.037	2.1148	2.0953
7	2.1719	1.9879	2.2862	2.3434	2.037	2.1719	2.1491
8	2.2291	2.0416	2.572	2.4577	2.037	2.4006	2.2565
9	2.5149	2.2028	2.6292	2.3434	2.4331	2.5149	2.364
10	2.572	2.572	2.8006	2.8006	2.4714	2.6292	2.6326
11	1.3717	2.8578	3.3951	3.4865	3.0087	2.9721	3.2236
12	1.3717	2.915	3.5082	3.7151	3.0087	3.0864	3.1161
13	3.2579	3.6008	3.1687	3.658	3.0087	3.0864	3.2236
14	2.5149	3.2007	3.0556	3.4294	2.7938	2.8578	3.1161
15	2.6863	2.915	3.0556	3.315	2.7938	2.7435	3.1699
16	2.6863	2.6292	3.2007	3.2007	2.7938	2.8578	3.3722
17	2.6292	2.572	3.315	3.3722	2.915	2.6326	3.6008
18	2.6863	3.5437	3.0864	3.3722	3.2007	2.7938	3.3722
19	3.3311	4.4582	3.658	4.0741	4.0581	3.4922	4.2867
20	3.5997	4.4582	4.0581	4.3004	4.0009	3.7609	4.401
21	3.3311	3.658	3.3722	3.6214	3.7151	3.546	3.9438
22		3.3722	3.0293	3.2819	3.2007	3.0087	3.315
23			2.7435	2.9424	2.8006		2.915
24	2.6292	2.0953	2.8578	2.4006	2.4897	2.6863	2.2565
Max	3.5997	4.4582	4.0581	4.3004	4.0581	3.7609	4.401
Min	1.3717	1.8267	2.1148	2.0005	2.037	2.1148	2.0416
Avg	2.4877	2.7184	2.9081	2.9740	2.7456	2.7473	2.8914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244092 / 33 / 11 KV KOLHAPUR ROAD

Feeder No / Name : 201 / 11 KV SHASTRI CHOWK SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7167	.6979	.7356			.6979	.703
2	.679	.6979	.6979			.6602	.703
3	.679	.6979	.6979			.6602	.703
4		.6979	.6979			.6602	.703
5	.9619	.7167	.7356			.6979	.703
6	.811	.7922	.7922			.7167	.7202
7	.811	.8299	.8676			.7545	.7888
8	.8299	.8299	.8676			.811	.7545
9	.8488	.8488	.8676			.7733	.8299
10	.8676	.9808	.9808			.7733	.9431
11	.8865	1.0374	1.0185			.8299	.9808
12	.8676	.9997	1.0185		.8573	.8676	.9431
13	.8488	.9054	.8865		.7888	.8299	.9997
14	.7922	.8676	.8488		.7373	.7922	.9619
15	.7733	.8865	.8676		.6859	.7922	.9619
16	.7545	.8865	.3772		.7373	.7545	.9619
17	.7922	.9054	.9431		.8299	.7545	1.0374
18	.8676	.9808	.9054		.9054	.7888	1.0374
19	1.2637	1.2826	1.2826		1.226	.9774	1.2826
20	1.226	1.3014	1.2637		1.1883	1.0288	1.3014
21	1.1694	1.1506	1.1317		1.094	1.0288	1.1883
22	1.094	1.1128	1.0562		1.0185	.9431	1.1506
23	.9808	.9997	.9431		.9054	.8573	.9808
24	.7545	.7922	.811	.811		.7733	.7545
Max	1.2637	1.3014	1.2826	.811	1.226	1.0288	1.3014
Min	.679	.6979	.3772	.811	.6859	.6602	.703
Avg	.8816	.9124	.8873	.811	.9145	.8010	.9206

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244092 / 33 / 11 KV KOLHAPUR ROAD

Feeder No / Name : 202 / 11 KV FRUIT MARKET SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.1132	.1132			.0943	.0857
2	.0943	.1132	.1132			.0943	.0857
3	.0943	.0943	.0943			.0943	.0857
4		.0943	.0943			.0943	.0857
5	.1132	.0943	.0943			.0943	.0857
6	.0943	.0943	.0943			.0943	.0857
7	.0943	.0754	.0943			.0943	.0686
8	.0754	.0943	.0754			.0754	.0686
9	.0754	.1132	.0943		.1029	.0754	.0943
10	.0943	.0943	.1132		.0857	.0566	.132
11	.0943	.1132	.1509		.0686	.132	.1698
12	.1132	.1132	.132		.12	.1132	.1509
13	.0943	.0754	.1698		.0857	.0943	.1132
14	.0754	.132	.0943		.1029	.0754	.132
15	.0943	.1132	.1132		.1029	.0754	.132
16	.1132	.132	.132		.12	.132	.0943
17	.0943	.1132	.132		.1509	.0857	.132
18	.1132	.1132	.1132		.0943	.1029	.0943
19	.1509	.1509	.1509		.132	.12	.1509
20	.1509	.132	.1509		.132	.12	.132
21	.1509	.132	.264		.132	.12	.132
22	.132	.1132	.132		.1132	.12	.132
23	.1132	.1132	.1132		.1132	.1029	.1132
24	.0943	.1132	.1132	.0943		.0943	.1029
Max	.1509	.1509	.264	.0943	.1509	.132	.1698
Min	.0754	.0754	.0754	.0943	.0686	.0566	.0686
Avg	.1050	.1100	.1226	.0943	.1104	.0982	.1108

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

SOUTH ZONE,SANGLI[069] BU 4069

Substation No/ Name :- 244092 / 33 / 11 KV KOLHAPUR ROAD

Feeder No / Name : 402 / 33KV SHERINALA

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6029	2.6595	2.5463	3.0556	2.8292	2.9424	2.7263
2	2.4897	2.6595	2.3765	2.9424	2.7161	2.7161	2.6749
3	2.4897	2.6595	2.3765	2.8858	2.7161	2.7161	2.6749
4	2.6029	2.7161	2.3765	2.8858	2.7161	2.7161	2.6749
5	2.999	2.7726	2.5463	2.8858	2.8292	2.9424	2.7778
6	3.0556	2.999	2.8292	2.9424	2.9424	3.0556	3.1379
7	3.0556	3.0556	3.1687	3.2253	3.1121	3.1687	3.0864
8	3.0556	3.1687	3.0556	2.999	3.1687	2.999	2.8807
9	3.1121	3.1121	3.2819	2.8807	3.2407	3.3951	3.5082
10	2.999	3.3951	3.5082	3.2407	3.1379	3.2819	3.4517
11	2.9424	3.2819	3.5082	3.1893	3.2922	3.6214	3.5648
12	2.4897	3.3951	3.678	3.1893	3.6523	3.8477	3.9043
13	3.1121	3.3951	3.5082	3.2407	3.3951	3.678	3.5648
14	2.999	3.2819	3.4517	3.1379	3.1893	3.5082	3.5082
15	3.0556	3.1687	3.4517	3.3436	3.2922	3.7346	3.8477
16	2.7161	3.2253	3.3385	3.035	2.9321	3.3951	3.5082
17	2.6029	3.3951	2.8858	3.4517	3.2819		3.5082
18	2.8858		3.3385	3.6214	3.7912		3.7912
19	3.8477	4.357	4.4702	4.2438	4.2438		4.357
20	4.0741	4.3004	4.1307	4.4136	4.2438	3.9609	4.357
21	3.9043	4.0741	3.9609	4.1872	3.8477	3.7551	4.357
22	3.5082	3.5648	3.5648	3.6214	3.4517	3.4465	3.7912
23	3.0556	3.3385	3.3951	3.3951	3.3385	3.1893	3.7912
24	2.7161	3.1121	2.7161	3.2253	3.0556	3.1121	2.8807
Max	4.0741	4.357	4.4702	4.4136	4.2438	3.9609	4.357
Min	2.4897	2.6595	2.3765	2.8807	2.7161	2.7161	2.6749
Avg	3.0155	3.2647	3.2277	3.3016	3.2673	3.2944	3.4302

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244094 / 33\11 KV VIJAYANAGAR

Feeder No / Name : 201 / 11 KV Government Colony SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4066	.4108	.4805			.4481	.5228
2	.4066	.3961	.4854			.4481	.5228
3	.4108	.3961	.4904			.4481	.5281
4	.4108	.3961	.4904			.4481	.5093
5	.4715	.4481	.5041			.4481	.5041
6	.5093	.499	.5281			.462	.5281
7	.5658	.567	.5658		.5658	.499	.5847
8	.5658	.499	.5228		.5601	.499	.5041
9	.5415	.4805	.4668		.4854	.462	.4668
10	.4294	.4207	.3921		.4294	.4435	.4294
11	.3511	.3475	.3696		.4251	.4251	.3881
12	.3361	.3658	.3696		.4066	.4294	.3696
13	.3018	.3292	.3658		.3881	.4294	.3921
14	.3174	.3109	.3475		.3841	.4108	.4066
15	.3206	.3109	.3475		.3511	.3921	.3696
16	.3174	.3475			.3734	.4066	.4294
17	.3326	.3658			.3658	.4294	.4163
18	.3696	.3658	.3326		.3841	.439	.5853
19	.6447	.6626	.6089		.6089	.6626	.695
20	.6447	.6878	.6516		.6516	.7164	.7133
21	.6335	.6767	.6335		.6584	.7164	.695
22	.6154	.6584	.6219		.6219	.7059	.695
23	.5487	.4973	.5175		.5853	.6036	.5729
24	.4251	.4435	.4805	.4854		.499	.5228
Max	.6447	.6878	.6516	.4854	.6584	.7164	.7133
Min	.3018	.3109	.3326	.4854	.3511	.3921	.3696
Avg	.4532	.4535	.4806	.4854	.4850	.4947	.5146

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244094 / 33\11 KV VIJAYANAGAR

Feeder No / Name : 205 / 11 KV CENTRAL BUILDING

FEEDER Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8					.0019		
9			.0191	.0191			
10	.0019			.0191	.0019	.0019	.0019
11	.0019	.0191	.0381	.0191	.0019	.0019	.0019
12	.0019	.0191	.056	.0191	.0019	.0019	.0373
13	.0019	.0191	.0572	.0191	.0019	.0019	
14	.0019	.0191	.056	.0191	.0019	.0019	.0373
15	.0019	.056	.056	.0191	.0019	.0019	.0373
16	.0019	.056		.0191	.0019	.0019	.0373
17	.0019	.0572		.0191	.0019	.0019	.0373
18	.0191	.0366	.0191	.0381	.0191	.0381	.0191
19				.0191			.0191
Max	.0191	.0572	.0572	.0381	.0191	.0381	.0373
Min	.0019	.0191	.0191	.0191	.0019	.0019	.0019
Avg	.0038	.0353	.0431	.0208	.0036	.0059	.0254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

SANGLI URBAN DIVISION[121]

VISHRAMBAG NORTH ZN.[066] BU 4066

Substation No/ Name :- 244094 / 33\11 KV VIJAYANAGAR

Feeder No / Name : 402 / 33 KV KUPWAD CITY FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.2323	1.1883	1.4003
2	1.2323	1.1317	1.4146
3	1.2323	1.1317	1.3443
4	1.2323	1.1317	1.3443
5	1.2449	1.1317	1.3443
6	1.3014	1.3443	1.4146
7	1.3014	1.5278	1.5278
8	1.4146	1.4712	1.4003
9	1.3443	1.4003	1.2883
10	1.1203	1.2323	1.1763
11	1.0642	1.1088	1.0751
12	1.0185	1.0534	1.1643
13	.8488	1.0425	1.0534
14	.8488	.9877	1.0974
15	.8402	.9774	1.0974
16	.8488	.9877	
17	.8402	.9877	
18	.9425	.9979	
19	1.6461	1.5912	
20	1.701	1.7558	
21	1.6461	1.7558	
22	1.6078	1.6632	
23	1.386	1.6244	
24	1.2323	1.2323	1.4563
Max	1.701	1.7558	1.5278
Min	.8402	.9774	1.0534
Avg	1.2136	1.2690	1.2874

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 201 / 11 KV Madgule AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.182	1.1403	1.7924	1.4118	.4344	.2896	.3658
2	1.448	1.0136	1.7558	1.4118	.439	.2896	.3801
3	1.2894	1.0136	1.829	1.3756	.4525	.2534	.3658
4	1.2536	1.0317	1.8099	1.4083	.4938	.2507	.362
5	1.4118	1.1946	1.9909	1.4998	.4887	.3582	.3841
6	1.6461	1.7013	2.0271	1.8099	.4572	.4656	.3982
7	1.5927	2.4364	2.8959	2.1719	.5973	.4298	.4163
8	.5304	.439	.4252	.362	.567	.394	.3841
9	.362	.394	.394	2.8959	2.5339	3.0769	.3801
10	.3258	.3582	.3258	2.1948	2.5606	3.1131	.362
11	.3077	.3582	.3292		2.524	3.0178	.3439
12	.2896	.3544	.3109	2.6063	2.4874	3.1674	.3189
13	.2686	.3582	.2896	2.3777		3.1855	.3012
14	.2534	.3582	.2896	2.1719		3.3303	.3045
15	.2353	.362	.2896	2.2923		3.4751	.2865
16	.2172	.3582	.2896	2.4072	2.0814	3.1674	.2865
17	.2896	.3506	.2896	.4656	1.9366	.3258	.3258
18	.3258	.3544		.3898	1.9728	.3475	
19	.3982	.394			.3292	.362	.3982
20	.4298	.4298	.4024	.4784	.4024	.3475	.4344
21	.4298	.4298	.4024	.5014	.439	.3439	.4344
22	1.2536	2.1719	.181		.3982	.3258	2.1948
23	1.2308	1.829	1.8099	.4887	.362	.3658	2.1033
24	.905	1.1946	1.7924	1.5432	.4755	.3258	.3439
Max	1.6461	2.4364	2.8959	2.8959	2.5606	3.4751	2.1948
Min	.2172	.3506	.181	.362	.3292	.2507	.2865
Avg	.7448	.8344	.9965	1.5364	1.0682	1.2920	.5163

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 202 / 11 KV Atpadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8688	.8048	.9145	.788	.7602	.9412	1.0791
2	.9877	.7682	.9145	.7522	.7522	.8954	1.0608
3	1.0136	.7682	.905	.7522	.724	.8596	1.1041
4	1.0608	.8501	.9412	.7964	.7343	.8596	1.1222
5	1.086	.961	.9313	.8326	.724	.9313	1.1523
6	1.1523	1.0349	1.0387	.9774	.8413	1.0136	1.1888
7	1.1946	1.1088	1.182	1.086	1.1222	1.0974	1.262
8	1.134	1.1458	1.0985	1.1584	1.2178	1.134	1.2437
9	1.0136	1.1462	1.0745	1.3032	1.3394	1.1157	1.2803
10	.9774	1.182	1.1104	1.0242		1.1041	1.2803
11	.9511	1.182	1.086			1.1765	1.2803
12	.9511	1.1946	1.086	1.1584		1.134	1.2803
13	.9412	1.1462	.9774	1.2071		1.1403	1.2437
14	.9145	1.1462	.8688	1.1946	1.3535	1.1403	1.2437
15	.9511	1.1462	.905	1.1641		1.1765	1.267
16	.9511	1.1462	.9774	1.1584	1.2308	1.1946	1.3032
17	.9877	1.1694	1.0608	1.2071	1.2308	1.2127	1.3535
18	1.0719	1.2403	1.1888	1.2308	1.3394	1.2437	1.39
19	1.0719	1.3253	1.3169	1.2437	1.3535	1.2489	1.4784
20	1.1458	1.3611	1.2803	1.1946	1.3169	1.2803	
21	1.1088	1.2178	1.2437	1.1462	1.3169	1.1946	1.4784
22	.9877	1.086	1.134		1.1765	1.2071	1.4045
23	.8779	.9511	.9511	.905	1.0136	1.1765	1.2012
24	.8048	.8413	.9145	.8048	.8779	.9774	1.1888
Max	1.1946	1.3611	1.3169	1.3032	1.3535	1.2803	1.4784
Min	.8048	.7682	.8688	.7522	.724	.8596	1.0608
Avg	1.0086	1.0802	1.0459	1.0493	1.0750	1.1023	1.2559

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 203 / 11 KV Pujarwadi AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0543	.0358	.0732	.0905	.2195	.2172	.2172
2	.0537	.0358	.0732	.0362	.1991	.2172	.2195
3	.0532	.0358	.0732	.0362	.2195	.2561	.2534
4	.0716	.0362	.0724	.0366	.2534	.2926	.2561
5	.0724	.0543	.0905	.0549	.2686	.3658	.2715
6	.1097	.0724	.1075	.0724	.362	.5249	.2926
7	.1086	.0905	.0895	.1086	.0716	.4706	.2896
8	.0914	.0905	.1063	.0724	.0724	.0724	.1097
9	.181	.362	.3077	.0543	.0716	.0905	.3292
10	.181	.362	.2896	.0549		.0914	.3475
11	.181	.3439	.3658			.0905	.3658
12	.1629	.3258	.3841	.0724		1.134	.543
13	.1629	.3258	.3658	.0549		.1086	.3801
14	.1629	.2926	.3658	.0543	.0543	.1097	.3439
15	.1448	.2926	.3292	.0366	.0543	.1086	.3439
16	.1267	.2561	.2743	.0543	.0549	.1086	.3439
17	.0537	.0351	.0549	.0549	.1448	.1086	.0543
18	.0537	.0532	.0732	.0543	.0724	.1097	.0724
19	.0716	.0716	.0732	.0537	.0905	.1086	.0724
20	.0716	.0895	.0732	.0362	.0905	.128	.0724
21	.0716	.0895	.0732	.0549	1.2308	.1254	.0732
22	.6984	.0724	.0724		.3258	.1448	.0724
23	.0543	.0732	.0543	.1829	.3077	.1646	.0543
24	.0549	.0358	.0732	.0543	.2172	.2534	.181
Max	.6984	.362	.3841	.1829	1.2308	1.134	.543
Min	.0532	.0351	.0543	.0362	.0543	.0724	.0543
Avg	.1270	.1472	.1632	.0628	.2190	.2251	.2316

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 204 / 11 KV Pujarwadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0716	.1097	.0732	.1433	.0716	.1463	.1463
2	.0724	.1097	.0732	.1254	.0543	.128	.1448
3	.0914	.0914	.0732	.1075	.0549	.1086	.1463
4	.1086	.0905	.1086	.1086	.0905	.1086	.1629
5	.128	.1267	.1086	.1267	.128	.1097	.1646
6	.1267	.1463	.1433	.1267	.1448	.1463	.181
7	.1463	.1463	.1791	.1448	.1463	.1646	.181
8	.1448	.1448	.1417	.1463	.1267	.1646	.1829
9	.128	.1433	.1433	.1463	.128	.1629	.181
10	.128	.1075	.1433	.181		.1646	.181
11	.1267	.1086	.1433			.181	.181
12	.1267	.1075	.1433	.1097		.7316	.1646
13	.1086	.0716	.1433	.1086		.181	.1463
14	.1086	.0716	.1254	.0914	.1463	.181	.1463
15	.1086	.0724	.1075	.1086	.1463	.181	.1097
16	.1267	.0905	.1433	.1097	.1448	.181	.1463
17	.1267	.0886	.1433	.1267	.1448	.181	.1463
18	.1433	.1063	.1433	.1433	.1646	.2012	.1646
19	.1612	.1433	.1433	.1267	.1629	.1991	.1829
20	.1612	.1433	.1791	.1254	.1629	.1829	.181
21	.1612	.1433	.1791	.1448	.1448	.181	.181
22	.1433	.1086	.181		.1463	.1629	.1646
23	.1267	.1097	.1448	.1097	.1463	.1646	.1463
24	.0724	.1267	.1097	.1463	.0724	.1463	.1629
Max	.1612	.1463	.181	.181	.1646	.7316	.1829
Min	.0716	.0716	.0732	.0914	.0543	.1086	.1097
Avg	.1228	.1128	.1341	.1276	.1264	.1858	.1623

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 205 / 11 KV Madgule Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1829	.1829	.2172	.1829	.2195	.2378
2	.2172	.1829	.1829	.181	.2172	.1829	.2378
3	.2561	.1829	.1829	.1829	.2149	.1829	.2353
4	.2715	.2195	.181	.1829	.2353	.2218	.2534
5	.3292	.2561	.2172	.1848	.2378	.2772	.2534
6	.3439	.3658	.3982	.3326	.2896	.3696	.2715
7	.3582	.362	.4344	.4066	.3582	.3326	.2896
8	.2715	.362	.3898	.4024	.2896	.3292	.3109
9	.2561	.3582	.3582	.3658	.2195	.3077	.2896
10	.2172	.2865	.2865	.181	.2172	.3077	.2534
11	.2172	.2865	.2534		.2172	.2896	.2353
12	.2172	.2149	.2534	.1829	.2172	.2743	.2195
13	.1829	.1791	.2195	.1448		.2715	.2012
14	.181	.1791	.2195	.1463		.2743	.2012
15	.181	.1791	.1829	.181		.2534	.2149
16	.1991	.1791	.1829	.1791	.2926	.2715	.2149
17	.2172	.2103	.2172	.2172	.2896	.2534	.2507
18	.2507	.2481		.2149	.3258	.2561	.3224
19	.3224	.3582		.2172	.3582	.2353	.362
20	.3582	.394	.3982	.2561	.3582	.2561	.362
21	.3582	.3582	.3982	.2896	.3582	.2715	.362
22	.3258	.2534	.362		.3224	.2353	.2926
23	.2534	.2195	.2896	.2353	.2865	.2378	.2378
24	.1448	.2172	.1829		.1791	.2534	.2353
Max	.3582	.394	.4344	.4066	.3582	.3696	.362
Min	.1448	.1791	.181	.1448	.1791	.1829	.2012
Avg	.2547	.2598	.2715	.2334	.2699	.2652	.2644

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 206 / 11 KV Atpadi AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1448	.1463	.1463	.1791	.8954	.8326
2	.181	.1448	.1463	.1463	.2658	.8238	.8596
3	.1433	.1448	.1463	.1463	.394	.788	.8869
4	.1417	.1463	.1448	.1463	.543	.8238	.9328
5	.1791	.1829	.181	.1448	.6767	.9412	1.0498
6	.2172	.2195	.2172	.1629	.8869	1.086	1.0791
7	.2149	.2195	.2149	.181	.2195	1.2308	1.086
8	.181	.2195	.2126	.2195	.2534	.2172	.1829
9	.7682	1.0136	1.1584	.2195	.1829	.181	1.9909
10	.8688	1.0136	1.2071	.181		.1829	2.3891
11	.8413	.9412	1.4118			.1629	2.3529
12	.8048	.9412	1.5384	.1463		.1646	2.3411
13	.7602	.905	1.448	.181		.1629	2.2862
14	.695	.9145	1.448	.1829	.2172	.1646	2.0119
15	.695	.9145	1.39	.1448	.2172	.1629	1.7918
16	.6584	.8779	1.3535	.1463	.2172	.1629	1.7194
17	.1829	.1753	.181	.181	.543	.1629	.1829
18	.1829	.1772	.2172	.197	.543	.1829	.2195
19	.2195	.2149	.2172	.2126	.1791	.181	.2195
20	.2172	.2507	.2172	.2507	.2149	.1829	.2195
21	.2172	.2149	.1991	.2715	.2149	.1991	.2172
22	.2172	.181	.2012		1.0387	.1991	.2195
23	.181	.1463	.1463	.2195	1.0136	.7316	.1829
24	.1448	.181	.1463	.1463	.181	.9412	.8145
Max	.8688	1.0136	1.5384	.2715	1.0387	1.2308	2.3891
Min	.1417	.1448	.1448	.1448	.1791	.1629	.1829
Avg	.3790	.4369	.5788	.1806	.4091	.4555	1.0862

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244002 / 33/11 KV SUB-STATION, ATPADI

Feeder No / Name : 401 / 33 KV Soot Girani

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4434	.439	2.8235	2.364	2.3891	2.1948	2.524
2	2.5789	.3292	2.8532	2.364	2.4143	2.5789	2.4434
3	2.6063	.3292	2.7435	2.2565	2.3348	2.524	2.524
4	2.7435	.3361	2.7149	2.3045	2.2565	2.4394	2.4434
5	2.8235	.2801	2.7938	2.524	2.2805	2.5503	2.3045
6	2.9081		2.6863	2.6337	2.3594	2.5503	2.4977
7	2.9321	.3361	2.9012	2.7938	2.6063	2.6612	2.4977
8	1.6461	.3361	2.6578	2.5789	2.524	2.6337	1.7558
9	.8145	2.4714	2.9012	2.4714	2.552	2.7149	1.6461
10	.8145	2.5789	2.8532	2.552	2.3891	2.7984	.3292
11	.823	2.9321	2.7692	2.6337	2.1719	2.8235	.2743
12	.8145	2.8235	2.7149	2.7149	1.8461	2.9081	.3292
13	2.4977	2.7149	2.6606	2.6337	1.9753	2.8235	.439
14	.543	2.6863	2.6063	2.6063	2.0851	2.8532	.5487
15	.543	2.6863	2.2805	2.524	2.3045	2.7692	.7682
16	.2715	2.7938	1.8461	2.4434	2.4977	2.8235	.823
17	.2195	2.8704	1.9342	2.0851	.2743	2.7149	.5373
18	.2195	2.8704	2.2565	1.9004	.2743	2.6886	.3224
19	.3292	2.3102	2.364		.3258	2.6063	.3224
20	.3258	2.1262	2.4714	2.009	.3258	2.5789	.3258
21	.3258	2.1491	2.4714	2.0851	.3258	2.4977	
22	.3841	2.7149	2.364		.3292	2.4977	.3801
23	.439	2.6337	2.364	2.2262	.2743	2.4691	.3801
24	2.4691	.439	2.7149	2.364	2.4691	.2743	2.4434
Max	2.9321	2.9321	2.9012	2.7938	2.6063	2.9081	2.524
Min	.2195	.2801	1.8461	1.9004	.2743	.2743	.2743
Avg	1.3548	1.8342	2.5728	2.4122	1.7327	2.5406	1.2548

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 201 / 11 KV Nelkaranji AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3544		1.6834	
2				.3544		1.6651	
3				.3544		1.6297	
4				.3721		1.6124	
5				.3721		1.8073	
6				.3898		2.0237	
7				.3898		2.2325	
8				.4075		.3801	
9				.3721		.3801	
10				.3544		.3961	
11				.3544		.3395	
12				.3544		.2829	
13				.3544		.2641	
14		1.8427					
15				.3189		.3772	
16						.3772	
17				.3189		.3961	
18				.3898		.3961	
19		.415					
24	.2715		.3982	.3721	1.5947	1.7375	1.7918
Max	.2715	1.8427	.3982	.4075	1.5947	2.2325	1.7918
Min	.2715	.415	.3982	.3189	1.5947	.2641	1.7918
Avg	.2715	1.1289	.3982	.3638	1.5947	.9989	1.7918

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 202 / 11 KV Zare AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.543		.0543	
2				.5249		.0543	
3				.5249		.0543	
4				.5068		.0724	
5				.5249			
6				.6154		.0724	
7				.6697			
8				.0905			
9				1.0679		1.3213	
10				1.1765		1.6126	
11				1.086		1.5203	
12				1.086		1.6289	
13				1.086		1.6289	
14		.0543		.9955		1.6289	
15				.9955		1.5384	
16				1.0679		1.3032	
17				.0543		.0724	
18				.0724		.0724	
19		.0905					
24	.6335		.5792	.543	.0905	.0543	.0724
Max	.6335	.0905	.5792	1.1765	.0905	1.6289	.0724
Min	.6335	.0543	.5792	.0543	.0905	.0543	.0724
Avg	.6335	.0724	.5792	.6964	.0905	.7931	.0724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 203 / 11 KV Zare Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2896		.2534	
2				.2534		.2353	
3				.2534		.2534	
4						.2534	
5				.2896		.3077	
6				.362		.3982	
7				.3982			
8				.362		.4887	
9				.3439		.4706	
10				.3258		.3982	
11				.3258		.362	
12				.3258		.3439	
13				.3258		.3439	
14		.2534		.3258		.362	
15				.3077		.362	
16				.2715		.362	
17				.3258		.362	
18				.362		.3801	
19		.4525					
24	.362		.2896	.3258	.3258	.2534	.3258
Max	.362	.4525	.2896	.3982	.3258	.4887	.3258
Min	.362	.2534	.2896	.2534	.3258	.2353	.3258
Avg	.362	.3530	.2896	.3208	.3258	.3439	.3258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 204 / 11 KV Nelkaranji Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0905		.0905	
2				.0905		.1086	
3				.0905		.0905	
4				.1086		.1086	
5				.1629		.181	
6				.2172		.2353	
7				.2353		.2172	
8				.181		.1448	
9				.1448		.1267	
10				.1267		.1448	
11				.1267		.1448	
12				.1267		.1086	
13				.1267		.0905	
14		.1448		.0905		.0905	
15				.0905		.0905	
16				.0905		.1267	
17				.0905		.1086	
18				.1086		.1086	
19		.181					
24	.0905		.1267	.0905	.0905	.0905	.1086
Max	.0905	.181	.1267	.2353	.0905	.2353	.1086
Min	.0905	.1448	.1267	.0905	.0905	.0905	.1086
Avg	.0905	.1629	.1267	.1257	.0905	.1267	.1086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 205 / 11 KV Mitaki AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0762		.6401	
2				.0762		.6249	
3				.0762		.6097	
4				.0762		.6097	
5				.0762		.6859	
6				.0762		.7926	
7				.0914		1.0212	
8				.0762		.0762	
9				.0762		.061	
10				.0762		.0457	
11				.0762		.061	
12				.0762		.061	
13						.0762	
14		.945		.0762		.0762	
15				.0762		.0762	
16				.1829		.061	
17				.0762		.0762	
18				.0762		.0762	
19		.0914				.0914	
20						.0914	
24	.0762		.061	.0762	.9907		.7621
Max	.0762	.945	.061	.1829	.9907	1.0212	.7621
Min	.0762	.0914	.061	.0762	.9907	.0457	.7621
Avg	.0762	.5182	.061	.0830	.9907	.2957	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244023 / 33/11 KV SUBSTATION,

KHARSUNDI

Feeder No / Name : 206 / 11 KV Walvan AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.381		.061	
2				.381		.061	
3				.3658		.061	
4				.381			
5				.3963		.0762	
6				.4268		.0762	
7				.4572		.1067	
8				.0762		.1067	
9			.4268	.9297		1.1888	
10				1.1584		1.3108	
11				1.1584		1.3717	
12				1.1584		1.387	
13				1.1431		1.3413	
14		.0762		1.0974		1.3413	
15				1.0974		1.326	
16				1.0974		1.0364	
17				.0762		.0914	
18				.0914		.0914	
19				.1372		.1219	
20						.1219	
24	.4572			.3963	.0914	.061	.0914
Max	.4572	.0762	.4268	1.1584	.0914	1.387	.0914
Min	.4572	.0762	.4268	.0762	.0914	.061	.0914
Avg	.4572	.0762	.4268	.6203	.0914	.5670	.0914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244041 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 201 / 11 KV Zare (Zare) AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2896	.2378	.3113	.1463	.124	.1448
2		.2743	.2317	.2915	.1448	.1254	.1433
3		.2743	.2317	.3149	.1267	.1063	.124
4		.2743	.2378	.2915	.1254	.1063	.1227
5		.3125	.3353	.3201	.1848	.1227	.1402
6		.5761	.5155	.4001	.2614	.1753	.1734
7	.4687	.8749	.7773	.5535	.2801	.1402	.1928
8	.2149	.2033	.2195	.1844	.1612	.1417	
9	.1753	.1387	.181	.7526	1.0059	.884	.1715
10	.156	.1543	.1595	.9031	1.0898	.8278	.1372
11	.1147	.1387	.1063	.8429	1.0898	.9214	.1357
12	.1326	.1357	.1006	.9976	1.0059	.888	.1174
13	.1134	.1029	.1006	1.0254	.9326	.8025	.1134
14	.0937	.0678	.1174	.9783	1.0059	.8322	.112
15	.1235	.1772	.1357	.9332	1.0898	.9602	.1134
16	.1187	.1578	.0995	.8069	1.0059	.8333	.0995
17	.1311	.128	.1187	.1158	.1715	.1715	.1341
18	.1326	.1543	.1526	.1303	.1433	.1734	.1696
19	.2303	.2149	.2058	.1417	.1417	.2126	.2058
20	.2561	.2402	.1844	.2896	.1417	.1949	.208
21	.2427	.2561	.1865	.2561	.1433	.1949	.1886
22	.3086	.3161	.426	.2033	.1402	.1791	.1715
23	.3437	.286	.3978	.1646	.1227	.1448	.4144
24	.4801	.3086	.2675	.3222	.1463	.1227	.1448
Max	.4801	.8749	.7773	1.0254	1.0898	.9602	.4144
Min	.0937	.0678	.0995	.1158	.1227	.1063	.0995
Avg	.2132	.2524	.2386	.4805	.4503	.3911	.1599

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244041 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 202 / Vibhutwadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0701	.0724	.0905	.0914	.0905	.1254	.0914
2	.0709	.0724	.0905	.0905	.0905	.1063	.0905
3	.0716	.0724	.0905	.0724	.0716	.1063	.1086
4	.0716	.0724	.1097	.0914	.0914	.1075	.0905
5	.0867	.1109	.1294	.0905	.1109	.1433	.128
6	.1372	.1698	.1867	.1448	.1698	.1772	.1753
7	.1715	.1867	.2054	.197	.1886	.1753	.2195
8	.1478	.1478	.1267	.1267	.1294	.1417	.1829
9	.1075	.1254	.1254	.128	.1433	.1417	.1097
10	.0886	.1311	.1063	.0905	.1267	.1075	.0924
11	.1006	.0995	.0716	.1267	.1433	.1254	.0732
12	.0848	.0829	.0724	.0732	.1448	.1086	.0724
13	.0848	.0983	.0716	.0857	.1254	.1075	.0732
14	.0924	.0838	.1086	.0867	.1254	.1086	.0905
15	.0747		.1097	.0876	.1267	.128	.0914
16	.0655	.1017	.1448	.0857	.1448	.1463	.1086
17	.1898	.0838	.128	.1052	.1254	.1097	.128
18	.181	.1029	.1097	.1052	.1433	.1097	.1646
19	.1791	.181	.181	.1463	.1791	.1829	.2012
20	.1829	.1829	.1433	.168	.181	.1848	.1829
21	.1494	.1829	.1267	.128	.181	.1478	.1478
22	.1294	.1629	.1097	.1097	.1612	.128	.1294
23	.112	.128	.1097	.0905	.1433	.1109	.1097
24	.0686	.0914	.1097	.1086	.0905	.1448	.0914
Max	.1898	.1867	.2054	.197	.1886	.1848	.2195
Min	.0655	.0724	.0716	.0724	.0716	.1063	.0724
Avg	.1133	.1193	.1191	.1096	.1345	.1323	.1230

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244041 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 203 / 11 KV PIMPARI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0762	.0953	.8381	.503	.6882
2	.0762	.0762	.0762	.0953	.7811	.5087	.6802
3	.0762	.0762	.0762	.0953	.7811	.5087	.6722
4	.0953	.0762	.0953	.1143	.8223	.503	.6478
5	.1143	.0953	.0953	.0953	.8482	.8383	.6241
6	.1334	.1334	.1143	.1524	1.1984	1.0898	.6009
7	.1524	.1524	.1524	.1715	1.3927	1.8442	.8162
8	.1334	.1334	.1905	.1524	.1524	.1524	.1905
9	.8065	.8539	1.1043	.0953	.1524	.1143	1.0364
10	.8223	.9998	1.1702	.0762	.1334	.1143	1.3916
11	.9217	.9259	1.2643	.0762	.1524	.1143	1.4548
12	.9602	1.0311	1.2651	.0762	.1905	.0953	1.4243
13	.9762	.9922	1.2967	.0762	.1334	.0953	1.4575
14	.9488	.8259	1.2963	.0762	.1334	.1143	1.4563
15	.7186	1.0517	1.3441	.0762	.1524	.1143	1.587
16	.759	1.0437	1.2483	.0762	.1905	.1143	1.4883
17	.0953	.0714	.1334	.0762	.1524	.1334	.1524
18	.1143	.1143	.1524	.0762	.1524	.1334	.1524
19	.1524	.1524	.1524	.1524	.1905	.1524	.1715
20	.1524	.1524	.1334	.1524	.2286	.1334	.1524
21	.1334	.1524	.1334	.1524	.2286	.1334	.1334
22	.1143	.0953	.1143	.8855	.503	.759	.1334
23	.0953	.0953	.1143	.8962	.5087	.7362	.1143
24	.0762	.0762	.0953	.1143	.8802	.503	.7287
Max	.9762	1.0517	1.3441	.8962	1.3927	1.8442	1.587
Min	.0762	.0714	.0762	.0762	.1334	.0953	.1143
Avg	.3627	.3939	.4956	.1711	.4540	.3962	.7481

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 201 / 11 KV Hivtad AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1063	.124	.1227	.1267		1.5684	1.4723
2	.124	.1227	.124	.128		1.5497	1.4899
3	.1254	.12	.1254			1.531	1.4899
4	.1463	.1387	.1387	.128		1.5432	1.5565
5	.1829	.1612	.2172	.1663		1.4632	1.6057
6	.2218	.181	.2561	.2263		1.8519	1.6575
7	.2957	.2241	.2353	.2427		2.1445	1.704
8	.2103	.1829	.2149			.1581	.1638
9	.9831	1.8804	1.9433	.1387		.1581	
10	1.1203	1.704	2.1136		.144	.144	2.42
11		1.7532	2.13		.1219	.1457	2.3537
12	1.3283	1.7166	2.0481		.1189	.1311	2.2119
13	1.2186	1.6324	1.9433		.1014	.1296	2.0891
14	1.2346	1.5813	1.8842		.1067	.128	2.0243
15	1.2654	1.7833	1.7394		.1235	.1107	1.9662
16	1.2193	1.6604	1.8138		.108	.1219	1.6762
17	.1387	.2241	.1		.128	.1475	.088
18	.1715		.1543		.1638	.1886	.1715
19	.2254	.2865	.1734	.1753	.2229	.2279	.2534
20	.2303	.2279	.2481	.2126	.2229	.2454	.2172
21		.1791	.2195	.2328	.1753	.2254	.2743
22	.1612		.1663		1.7204	1.4746	
23	.1448			.9145	1.6004	1.5546	.1663
24	.1052	.1254	.124	.1267		1.5684	1.4723
Max	1.3283	1.8804	2.13	.9145	1.7204	2.1445	2.42
Min	.1052	.12	.1	.1267	.1014	.1107	.088
Avg	.4982	.7623	.7929	.2349	.3613	.7713	1.2965

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 202 / 11 KV Shetphale AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.4161	.6316	.5243		.1646	.1867
2	.3102	.4054		.5243		.1629	.1848
3	.2896		.6316	.5243		.1612	.1848
4	.2896	.4001	.6325	.5735		.1417	.2054
5	.4458	.4344	1.0242	.5967		.208	.2452
6	.703	.5487	1.1469	.6478		.2561	.2715
7	.8381	.8322	1.2803	.9717		.3547	.3206
8	.2835	.1134	.128			.3174	.2328
9		.128	.1417	1.0526		1.3352	
10		.1311	.1578		1.1218	1.4327	.1417
11	.2195	.1227	.124		1.2003	1.3375	.1075
12	.1433	.1448	.12		1.4403	1.2308	.0905
13	.124	.1433	.1187		1.2346	1.1523	.0914
14	.1267	.1646	.124		1.142	1.1702	.1063
15	.1134	.1848	.1214		.9907	1.2037	.1372
16	.1357		.12		.9145	1.2018	.1543
17	.2058	.16	.208		.208	.1543	.1619
18	.2507		.2294		.2481	.1791	.2195
19	.3077		.2374	.2058	.3045	.1734	.362
20	.3292	.2949	.6249	.2279	.3258		.3109
21	.2743	.2486	.2743	.2507	.2743	.1734	.2772
22	.4001				.2402	.1612	.8356
23	.4344			.3077	.1867	.1734	
24	.2934	.4054	.639	.5243		.1646	.1867
Max	.8381	.8322	1.2803	1.0526	1.4403	1.4327	.8356
Min	.1134	.1134	.1187	.2058	.1867	.1417	.0905
Avg	.3100	.2933	.4150	.5332	.7023	.5657	.2279

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 203 / 11 KV Banpuri AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3269	.3201	.3909	.2591		.1097	.1478
2	.2896	.3239	.3807	.2753		.1086	.1463
3	.2896	.3277	.3858	.2785		.1086	.1463
4	.2934	.3932	.4923	.2785		.1254	.1663
5	.3567	.4858	.6836	.2785		.1417	.1886
6	.4877	.5898	.8025	.4096		.208	.2614
7	.6325	.852	.7225	.5182		.2614	.2987
8	.2149	.1492	.1067	.6325		.2218	.0886
9	.1402	.1372	.1094	1.0155		1.262	
10	.0914	.1595	.1067		1.046	1.448	.104
11	.0753	.12	.0914		1.0753	1.2689	.0886
12	.0762	.064	.096		1.0669	1.1523	.0905
13	.0937	.064	.0791		.9633	1.1069	.0914
14	.1107	.0791	.0914		.8402	1.0242	.081
15	.0869	.096	.0714		.9297	1.0802	.0772
16	.0892	.125	.0714		.9031	.9846	.088
17	.1448	.144	.088		.1357	.1907	.1898
18	.1734	.1715	.124		.1715	.2126	.2587
19	.2401	.1848	.2058	.1543	.2481	.2328	.2926
20	.2328	.2378	.2195	.1753	.2328	.2534	.2172
21	.181	.181	.1663	.2149	.181	.2149	.1867
22	.3277		.4321		.1433	.1991	
23	.3048			.2126	.128	.1829	
24	.3269	.3201		.2591		.1086	.1478
Max	.6325	.852	.8025	1.0155	1.0753	1.448	.2987
Min	.0753	.064	.0714	.1543	.128	.1086	.0772
Avg	.2328	.2512	.2690	.3544	.5761	.5086	.1599

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 204 / 11 KV Hivtad Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.112	.1254	.1097		.1075	.112
2	.1109	.1109	.1267	.1097		.1063	.1097
3	.1294	.1097	.1267	.1097		.104	.1109
4	.1463	.128	.1646	.1086		.1254	.1307
5	.181	.1448	.181	.1448		.1463	.1646
6	.2195	.1612	.2195	.1595		.1417	.1867
7	.2353	.2241	.2149	.2012		.1254	.1886
8	.1753	.1829	.1791			.1063	.1494
9	.1791	.1132	.1433	.1417		.1075	
10	.12		1.6478		.1387	.1063	.0886
11	.0791	.2481	.0876		.1254	.0867	.0886
12	.08	.2774	.0895		.128	.0857	.0886
13	.0648		.0886		.0892	.0914	.0886
14	.0819	.1772	.0895		.1219	.1075	.0905
15	.0678	.1052	.0886		.108	.0867	.0914
16	.0848	.0876	.0914		.0926	.0937	.124
17	.1372	.1063	.1097		.1372		.1086
18	.1753				.1791		.1595
19	.2172	.197		.2658	.2172		.2149
20	.1829	.1772		.208	.1829		.1772
21	.1478	.1433		.2401	.1478		
22	.1478				.1267		.1294
23	.1132			.2601	.1109	.1265	.1772
24	.1086	.112	.1254	.1097		.1097	.112
Max	.2353	.2774	1.6478	.2658	.2172	.1463	.2149
Min	.0648	.0876	.0876	.1086	.0892	.0857	.0886
Avg	.1373	.1536	.2166	.1668	.1361	.1091	.1314

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 205 / 11 KV Shetphale Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2402	.2587	.2896	.1698		.2534	.2801
2	.2241	.2561	.2896	.1698		.2561	.2772
3	.2241	.2534	.2896	.1698		.2534	.2743
4	.2614	.2896	.3292	.1698		.2896	.3077
5	.3772	.3224	.3734	.2263		.3475	.3511
6	.4904	.3544	.4527	.2829		.4108	.4294
7	.5281		.4904	.2829		.5093	.4527
8	.4805		.4481			.4481	.3547
9	.3696		.3544	.1867		.3734	
10	.2772	.2804	.2427		.3403	.3018	.2427
11	.2378	.2896	.2427		.3077	.2218	.2218
12	.2195	.2772	.2126		.2715	.1886	.1772
13	.2172	.2561	.2054		.2353	.1867	.2058
14	.2012	.2402	.2126		.2378	.2012	.1791
15	.1848	.2172	.2402		.2172	.1791	.2378
16	.181	.2033	.2195		.2218	.2054	.2507
17	.2507	.2218	.2686		.2507		.2427
18	.3544		.3109		.3429		.3326
19	.3658			.5258	.5316		.5121
20	.4656	.4755	.1829	.6201	.4656		.4755
21	.4024	.3982		.7392	.4024		
22			.2054		.3582		
23	.3206			.6805	.3395		
24	.2402	.2614	.2865	.1698		.2561	.2801
Max	.5281	.4755	.4904	.7392	.5316	.5093	.5121
Min	.181	.2033	.1829	.1698	.2172	.1791	.1772
Avg	.3093	.2856	.2927	.3380	.3230	.2872	.3043

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 206 / 11 KV Banpuri Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.1433	.1086	.1097		.1448	.128
2	.1097	.1417	.1075	.1097		.1463	.1267
3	.1294	.1387	.1063	.1097		.1463	.1254
4	.1478	.1612	.1254	.1097		.1629	.1417
5	.1867	.181	.1463	.1478		.1791	.156
6	.2218	.2195	.1848	.2054		.2195	.2012
7	.2561	.2402	.0514	.2195		.2427	.2218
8	.2149	.2012	.0514			.2218	.1612
9	.1928	.181	.1147	.1448		.2195	
10	.1638	.1543	.1457		.1612	.2507	.1326
11	.1372	.1543	.128		.1734	.2058	.1619
12	.1423	.1475	.1619		.168	.1638	.1311
13	.1235	.1543	.1638		1.4586	.1829	.0972
14	.112	.1311	.1619		.128	.176	.0857
15	.112	.1423	.16		.1423	.1981	.0934
16	.1029	.128	.1562		.1509	.208	.116
17	.1387	.144	.1372		.1387		.1886
18	.1791	.16	.1715		.1772		.2172
19	.2195	.1949	.1829	.2126	.2149		.2195
20	.2172	.2149	.2195	.1753	.2172		.181
21	.1829	.1734		.1612	.1829		
22	.1612		.1463		.1629		.1509
23	.1629			.2149	.1646		
24	.1109	.1448	.1075	.1097		.1463	.1267
Max	.2561	.2402	.2195	.2195	1.4586	.2507	.2218
Min	.1029	.128	.0514	.1097	.128	.1448	.0857
Avg	.1598	.1660	.1381	.1562	.2601	.1891	.1507

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244045 / 33/11 KV KARGANI

Feeder No / Name : 207 / 11 KV GOMEWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0267	.04	.0457	.0549		.5281	.4681
2	.0274	.0406	.048	.0549		.5218	.463
3	.0423	.0412	.0492	.0554		.5344	.4578
4	.0564	.0533	.0648	.056		.5601	.4862
5	.0714	.0518	.0791	.0732		.663	.503
6	.0869	.0629	.0937	.124		.8596	.5801
7	.1014	.0619	.0541	.0732		.9492	.7701
8	.1014	.061	.0705			.0543	.0511
9	.4458	.6036	.8002	.0532		.0358	.7621
10	.5268	.8288	1.1012		.048	.0532	1.2431
11	.5487	.8916	.9831		.0366	.0537	1.3757
12	.5401	.8048	.9012		.0343	.0537	1.1469
13	.5281	.7461	.8421		.0314	.0492	1.0526
14	.4902	.7042	.7449		.0309	.0423	.9831
15	.4572	.6783	.6554		.0291	.04	1.0526
16	.426	.6274	.6478		.0286	.0309	.7125
17	.064	.1067	.0709			.0564	.0532
18	.0762	.1067	.0709			.0667	.0716
19	.0892	.0709	.0819	.0701		.088	.1063
20	.0869	.0777	.0914	.0886		.0892	.0914
21	.0714	.0667				.0714	.0914
22	.0579		.6055			.5335	.0514
23	.0457			.6135		.5441	
24	.0389	.0412		1.5432		.5218	.463
Max	.5487	.8916	1.1012	1.5432	.048	.9492	1.3757
Min	.0267	.04	.0457	.0532	.0286	.0309	.0511
Avg	.2086	.3076	.3858	.2384	.0341	.2917	.5668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244081 / 33/11 KV Lingiware

Feeder No / Name : 201 / 11 KV Palaskhel

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5083	.5087	.6001	.5959	.0953	.0953	.1143
2	.5028	.5197	.6068	.5847	.0953	.0953	.1143
3	.4578	.5197	.631	.5721	.0762	.0953	.1143
4	.4475	.5426	.631	.5596	.0762	.0762	.1143
5	.4801	.547	.6173	.5487	.0762	.0762	.1143
6	.4973	.6226	.6415	.6201	.0953	.0953	.1334
7	.7186	.6802	.8589	.7087	.0953	.0953	.1334
8	.1334	.1524	.1715	.1334	.1143	.1143	.1524
9	.1143	.1143	.0953		1.3443	1.3146	.1143
10	.0762	.0762	.0572	1.1088	1.4415	1.1584	.0953
11	.0572	.0762	.0762	1.1999	1.5384	1.1096	.0953
12	.0572	.0762	.0762	1.1218	1.475	1.258	.0762
13	.0572	.0572	.0572	1.251	1.2536	1.3176	.0762
14	.0572	.0572	.0762	1.2178	1.2795	1.6118	.0762
15	.0572	.0381	.0762	1.267	1.2003	1.6476	.0762
16	.0572	.0572	.0762	1.2094	1.262	1.382	.0762
17	.0572	.0762	.0762	.0953	.0953	.0572	.0572
18	.0572	.0762	.0762	.0953	.0762	.0381	.0572
19	.1143	.1143	.0953	.0762	.0762	.1143	.0953
20	.1143	.1143	.1334	.0762	.0953	.1524	.1143
21	.1143	.1143	.1143	.0953	.0953	.1334	.1143
22	.4748	.6556	.5316	.0762	.0953	.1334	.9774
23	.5144	.6485	.5784	.0762	.0762	.1334	.964
24	.4973	.5375	.6241	.9602	.0762	.0762	.1334
Max	.7186	.6802	.8589	1.267	1.5384	1.6476	.9774
Min	.0572	.0381	.0572	.0762	.0762	.0381	.0572
Avg	.2593	.2909	.3158	.6196	.5085	.5159	.1746

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244081 / 33/11 KV Lingiware

Feeder No / Name : 202 / 11 KV Rajewadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.0762	.1524	.1143	.8642	.8962	.5921
2	.1143	.0762	.1334	.1143	.8886	.9556	.5506
3	.1143	.0762	.1334	.1143	.9012	.8697	.5535
4	.1143	.0762	.1334	.1334	.9217	.8535	.6036
5	.1334	.0953	.1524	.1334	.933	1.0031	.583
6	.1524	.1143	.1524	.1524	1.0227	1.0082	.7045
7	.1524	.1143	.1524	.1905	1.1869	1.1227	.7045
8	.1143	.0953	.1143	.1524	.0953	.1334	.1143
9	.5506	.664	.9448	.0953	.0762	.1334	1.0566
10	.7373	.7811	.9995	.1334	.0762	.1143	1.1145
11	.8785	.6874	1.0513	.1524	.0762	.0953	1.2971
12	.8886	.6642	1.2308	.1524	.1524	.0572	1.0808
13	.788	.8025	1.2071	.1143	.1143		.9774
14	.7701	.9686	1.2178	.1143	.1524	.0762	1.0745
15	.7127	.9172	1.1789	.1143	.1334	.0762	1.0517
16	.7209	.7926	1.2048	.1143	.1334	.1143	.9536
17	.0762	.0953	.1143	.1143	.1143	.1524	.0762
18	.0762	.0953	.0953	.1334	.1524	.1524	.0953
19	.0953	.1524	.1334	.1524	.1334	.1715	.1334
20	.0953	.1524	.1524	.1524	.1334	.1524	.1524
21	.1143	.1715	.1524	.1143	.0953	.0953	.1334
22	.1143	.1715	.1143	.9221	.8848	.4915	.1524
23	.0953	.1334	.1143	.8817	.9221	.5281	.1524
24	.1143	.0953	.1334	.1143	.8381	.9779	.5571
Max	.8886	.9686	1.2308	.9221	1.1869	1.1227	1.2971
Min	.0762	.0762	.0953	.0953	.0762	.0572	.0762
Avg	.3266	.3362	.4654	.1950	.4584	.4448	.6027

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244081 / 33/11 KV Lingiware

Feeder No / Name : 203 / 11 KV Dhole Mala,
Dighanchi Feeder KV- 11 /
OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3052	.3856	.4755	.4115	.0762	.0953	.0572
2	.3086	.3982	.499	.3688	.0953	.0762	.0572
3	.3012	.3982	.4163	.4119	.0762	.0762	.0572
4	.2947	.4252	.4706	.3814	.0762	.0762	.0572
5	.3018	.4382	.5121	.3429	.0762	.0572	.0572
6	.3086	.5316	.5175	.3856	.0762	.0762	.0762
7	.5487	.5959	.7468	.5249	.0762	.0953	.0953
8	.0953	.0762	.1143	.0953	.0953	.0953	.1143
9	.0953	.0762	.0953	.7362	1.1104	1.1222	.0953
10	.0572	.0572	.0572	.9896	1.262	.9816	.0953
11	.0572	.0572	.0572	.9362	1.3769	.9259	.0953
12	.0381	.0381	.0572	.9774	1.2883	1.0808	.0762
13	.0381	.0381	.0572	.9568	1.1694	1.1789	.0953
14	.0381	.0381	.0572	.9816	1.1949	1.3546	.0953
15	.0381	.0381	.0572	.9189	1.1458	1.382	.0953
16	.0381	.0381	.0572	.9991	1.0566	1.2483	.0762
17	.0381	.0381	.0572	.0762	.0953	.0572	.0762
18	.0381	.0572	.0572	.0762	.0762	.0572	.0762
19	.0762	.0762	.0762	.0572	.0762	.0762	.0953
20	.0762	.0762	.0953	.0762	.0953	.1143	.1334
21	.0762	.0762	.0953	.0953	.0953	.0762	.1143
22	.3467	.5304	.4119	.0953	.0762	.0762	.7186
23	.4031	.5544	.4161	.0953	.0762	.0762	.7619
24	.3121	.4119	.5249	.4207	.0762	.0762	.0762
Max	.5487	.5959	.7468	.9991	1.3769	1.382	.7619
Min	.0381	.0381	.0572	.0572	.0762	.0572	.0572
Avg	.1763	.2271	.2492	.4754	.4550	.4388	.1395

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244081 / 33/11 KV Lingiware

Feeder No / Name : 204 / 11 KV Rajewadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0716	.1187	.1109	.0867	.1075	.1075	.0876
2	.0678	.104	.1097	.0914	.112	.112	.0895
3	.0693	.1075	.1097	.6859	.1109	.0876	.0693
4	.0724	.1097	.1109	.0671	.0895	.0867	.0486
5	.0701	.1086	.112	.0693	.0876	.1109	.0514
6	.0934	.1294	.1494	.1254	.0867	.1086	.0876
7	.1463	.1448	.1463	.1494	.0934	.1075	.1463
8	.156	.1417	.1433	.1267	.1052	.1143	.1372
9	.1086	.1612	.1372	.0867	.1097	.104	.0895
10	.0848	.104	.0829	.1052	.0924	.0526	.1052
11	.0655	.1052	.0509	.1063	.112	.0549	.052
12	.0663	.1063	.0526	.1052	.1086	.0497	.0549
13	.0867	.1063	.0537	.0934	.1063	.0486	.0514
14	.0857	.0886	.0514	.0924	.0876	.052	.0526
15	.1006	.0693	.0554	.1075	.0895	.0537	.0543
16	.0838	.1063	.0503	.112	.112	.0526	
17	.0995	.0857	.0492	.1227	.1267	.0732	.052
18	.1017	.0995	.0716	.0867	.104	.0686	.0537
19	.12	.1311	.0934	.1097	.1227	.1307	.0497
20	.156	.1478	.1629	.1254	.1494	.2149	.2033
21	.1646	.1646		.128	.1478	.1387	.1867
22	.1663	.168	.1294	.0876	.1097	.181	.1478
23	.1311	.1307	.104	.0867	.1075	.124	.1086
24	.0724	.116	.112	.1075	.0886	.0876	.1086
Max	.1663	.168	.1629	.6859	.1494	.2149	.2033
Min	.0655	.0693	.0492	.0671	.0867	.0486	.0486
Avg	.1017	.1190	.0978	.1277	.1070	.0967	.0908

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244106 / 33/11 KV Pujarwadi

Feeder No / Name : 201 / 11 KV Kauthuly

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5609	.6783	.5194	.1417	.1402	.1829
2		.5258	.6706	.4887	.1402	.1402	.3292
3	.2149	.5316	.6516	.4344	.1433	.1402	.1886
4	.2686	.567		.5316	.1612	.1402	.1791
5	.3721	.6447	.6962	.6485		.1402	.181
6	.5258	.8596	.8848	.8238	.2103	.2126	.2218
7	1.2003	1.5775	1.2574	1.0288	.2058	.2103	.2561
8	.1886	.2172	.2058	.1715	.2401	.1448	.1715
9	.1387	.1387	.2149	1.6095	2.0348	2.4143	.2012
10	.1372	.1791	.1753	1.6956	2.6139	2.2891	.1417
11	.1372	.1612	.1372	1.8482	2.4897	2.146	.1387
12	.1372	.1463		1.95	2.1376	1.9204	.1372
13	.1187	.1829		1.9204	1.9616	2.2043	.1187
14	.1029	.1612		1.8519	1.9993	2.2466	.1174
15	.1029	.1448	.1357	1.8652	2.037	2.1296	.1326
16	.1017	.1612	.1357	1.8991	2.1879	2.3472	.1677
17	.1341	.1829	.1372	.1372	.1402	.1791	.1372
18	.1341	.1791	.156	.208	.1402	.1772	.1734
19	.2195	.2172	.2454	.2454	.2149	.2035	.2103
20	.2195	.2507	.2481	.2481	.2195	.2507	.1949
21	.2195	.2561	.2149		.2218	.2378	.1791
22	.6104	.6379	.8238	.2149	.1402	.3224	1.9281
23	.5426	.6089		.1772	.1402	.2012	1.6301
24	.4607	.5487	.6173	.567	.1417	.1402	.181
Max	1.2003	1.5775	1.2574	1.95	2.6139	2.4143	1.9281
Min	.1017	.1387	.1357	.1372	.1402	.1402	.1174
Avg	.2858	.4017	.4361	.9167	.8723	.8616	.3125

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244106 / 33/11 KV Pujarwadi

Feeder No / Name : 202 / 11 KV Nimbawade

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1372		.1267		.5609	.5426
2		.1372		.128	.5014	.5609	.5487
3	.1267	.1402	.1791	.1294		.5959	.583
4	.128	.1402	.1646	.1663	.8505	.631	.5087
5	.128	.1417	.1612	.1991		.7011	.6036
6	.1629	.1791	.1629	.2303	1.286	.815	.57
7	.1772	.2058	.1829	.208	1.3904	1.4723	.7461
8	.124	.2172	.1612	.1886	.1715	.1753	1.6095
9	.5487	.7628	1.1584	.1526	.1372	.1509	1.6095
10	.6173	.9214	1.1393	.1526	.112	.1433	1.6575
11	.6516	.9259	1.1488		.1132	.1097	1.6712
12	.6859	.8764		.1372	.0972	.1075	1.6385
13	.6783	.823			.1132	.1402	1.5912
14	.6173	.8764		.1372	.1132	.1063	1.5249
15	.5144	.8322	1.1736		.1132	.1433	1.5089
16	.4409	.8596	1.1233	.1357	.1132	.1097	1.3413
17	.1341	.1791	.1029		.1052	.1463	.1029
18	.1341	.1829	.1214		.1402	.1433	.1214
19	.2195	.1478	.1753	.1928	.1791	.1829	.1578
20	.2195	.2012	.1949		.1829	.1612	.1595
21	.1829	.197	.1791	.2149	.1848	.1595	.1578
22	.1357	.1417	.1612		.8063	.5487	.1595
23	.1357	.1867		.5068	.6661	.6104	.1612
24	.1267	.1372	.181	.1448	.4706	.5959	.57
Max	.6859	.9259	1.1736	.5068	1.3904	1.4723	1.6712
Min	.124	.1372	.1029	.1267	.0972	.1063	.1029
Avg	.3132	.3979	.4373	.1854	.3737	.3780	.8269

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244106 / 33/11 KV Pujarwadi

Feeder No / Name : 203 / 11 KV Kauthuly Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.0876	.1715	.0924	.1097	.1052	.1063
2	.0732	.0876	.156	.0739		.1052	.132
3	.0924	.0886	.1772	.0747	.1448	.1052	.1029
4	.0924	.124	.1075	.0924		.1227	.104
5	.1267	.1433	.1387	.1086	.1791	.1227	.1254
6	.1417	.1791	.1543	.1417		.1417	.1595
7	.1734	.1715	.1949	.2103	.2229	.2103	.2303
8	.12	.1629	.1463	.1402	.2229	.181	.1791
9	.0857	.1387	.2507	.1187	.2572	.1886	.1417
10	.0857	.1075	.2103	.12	.2801	.197	.1214
11	.1029	.0867	.2401		.1509	.1543	.0857
12	.0857	.0709		.12	.1134	.2126	.0848
13	.0848	.0549			.1132	.197	.0671
14	.0857	.0716		.12	.0943	.1772	.0838
15	.0857	.0709	.0848		.0943	.2012	.1017
16	.0848	.0716	.0678	.12	.0943	.2328	.12
17	.0838	.1646	.1029		.0876	.1829	.1372
18	.0838	.197	.1214	.12	.1402	.197	.156
19	.1463	.2195	.1753		.2149	.1829	.2103
20	.2195	.2507	.1417	.1772	.1829	.2149	.3189
21	.1829	.2303	.1433		.1663	.156	.3366
22	.1187	.181	.1254		.1402	.124	.1791
23	.0848	.1907		.1267	.1227	.1075	.1629
24	.0724	.0857	.2058	.0914	.1097	.1052	.0867
Max	.2195	.2507	.2507	.2103	.2801	.2328	.3366
Min	.0724	.0549	.0678	.0739	.0876	.1052	.0671
Avg	.1078	.1349	.1558	.1205	.1544	.1635	.1472

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 244106 / 33/11 KV Pujarwadi

Feeder No / Name : 204 / Nimbawade Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1052	.1791	.2561		.1227	.2561
2		.1052	.1928	.2402	.2353	.1227	.2328
3			.1829	.2218		.1227	1.6118
4		.124	.2149	.2172	.2172	.1402	.2926
5		.1433	.2401	.2686		.1402	.2481
6		.1791	.2254	.333	.3403	.1595	.2804
7	.1734	.1715	.2103	.3814	.3982	.2103	.2507
8	.1543	.181	.1734	.2915		.181	.2561
9	.1372	.1387	.2012	.2543	.3189	.1886	.2328
10	.1029	.2126	.1772	.2374	.2987	.2263	.2103
11	.1029	.2454	.1907		.1509	.2328	.1886
12	.1029	.1753		.1696	.1134	.1829	.1696
13	.1017	.197			.132	.2149	.1509
14	.1029	.2126		.2058	.1132	.1949	.1326
15	.1029	.1734	.1526		.1132	.2149	.1326
16	.1017	.1578	.1526	.2035	.1132	.2481	.1509
17	.1006	.2195	.1543		.1052	.2507	.12
18	.1006	.2328	.1734	.208	.1402	.2743	.156
19	.1463	.2481	.2103		.2149	.2926	.1928
20	.2195	.2804	.3012	.3012	.1829	.2865	.2658
21	.1829	.2601	.3403		.1848	.2835	.3045
22	.1357	.2103	.3801	.362	.1753	.2926	.2686
23	.1187	.2401		.3109	.1578	.3045	.2715
24	.2715	.1029	.208	.2534	.2715	.1227	.2835
Max	.2715	.2804	.3801	.3814	.3982	.3045	1.6118
Min	.1006	.1029	.1526	.1696	.1052	.1227	.12
Avg	.1366	.1877	.2130	.2620	.1989	.2088	.2775

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 201 / 11 KV Vithalapur

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	1.5432
Max	1.5432
Min	1.5432
Avg	1.5432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 202 / 11 KV Dighanchi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
23	1.5432
24	1.5432
Max	1.5432
Min	1.5432
Avg	1.5432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 203 / 11 KV Rajewadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
12	.0293
Max	.0293
Min	.0293
Avg	.0293

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 204 / 11 KV Rajewadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
12	.0067
Max	.0067
Min	.0067
Avg	.0067

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 205 / 11 KV Dighanchi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
12	.0137
Max	.0137
Min	.0137
Avg	.0137

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

ATPADI S/DN.[084]

BU 6289

Substation No/ Name :- 246012 / 110/33/11 KV DIGHANCHI

Feeder No / Name : 406 / 110 KV SADGURU SUGAR

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

FACTORY C Feeder KV- 132 /

(CONTINUOUS PROCESS)(NO STAGGERING

OUTGOING

DATE	01-SEP-17
HR	Load (MW)
13	.3658
24	7.2017
Max	7.2017
Min	.3658
Avg	3.7838

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 201 / 11 KV Gorewadi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.017	.0857	.0724	.0681	.5087	.3688	.4694
2		.0867	.0724	.0686	.503	.3688	.4694
3		.0867	.0724	.0697	.5087	.3315	.4527
4	.0168	.0867	.0905	.0693	.5868	.3315	.4862
5	.017	.0857	.1075		.6783	.3812	.5304
6	.0168	.1543	.1075	.1526	1.0174	.7956	.6464
7	.017	.2058	.1791	.1187	1.6108	1.704	.9831
8	.0168	.1886	.1772	.1509	.1526	.1715	.1865
9	.0509	.503	.7045	.1017	.12	.12	1.2944
10	.0838	.4475	.6203	.0857	.0857	.1029	1.0898
11	.6706	.4424	.7545	.0678	.0857	.0848	1.0852
12	.663	.5571	.8478	.0509	.0857	.0838	1.0174
13	.5304	.5138	.8551	.0343	.0857	.0848	1.0513
14	.426	.3605	.7377	.0857	.0857	.0848	1.0174
15	.426	.4915	.8718	.0857	.0857	.0857	.9602
16	.431	.5407	.9724		.0857	.1029	1.0174
17	.1227	.0848	.0666		.0876	.0867	.12
18	.1227	.0876	.0848		.1227	.0876	.1174
19	.1928	.1612	.1341	.1543	.1402	.1753	.1696
20	.1928	.1791	.1696		.1753	.197	.1715
21	.1907	.1612	.1753		.1753	.1791	.1715
22	.1372	.1254	.1029		.7712	.7712	.12
23	.1029	.0895	.0678		.4359	.6036	.0857
24	.017	.0857	.0716	.0671	.5144	.3688	.503
Max	.6706	.5571	.9724	.1543	1.6108	1.704	1.2944
Min	.0168	.0848	.0666	.0343	.0857	.0838	.0857
Avg	.2028	.2421	.3382	.0894	.3629	.3197	.5923

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 202 / 11 KV Bhivghat AG

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2347	.2713	.3052	.0671	.0686	.0724
2		.2347	.2713	.2743	.0678	.0686	.0724
3		.2347	.2713	.2572	.0671	.0686	.0724
4		.2652	.2713	.2883	.0678	.0857	.0716
5		.2652	.3018	.3185	.0838	.0857	.0716
6		.3441	.4024	.3688	.1017	.1029	.1075
7	.6371	.6882	.663	.4475	.1187	.1017	.1227
8	.1341	.12	.1187		.1017	.1372	.0857
9	.0663	.0678	.0678	.5087	.78	.7461	.0678
10	.0829	.0509	.0671	.5087	.7042	.7459	.0678
11	.0693	.0509	.0671	.5765	.4115	.7625	.0509
12	.0693	.0671	.0678	.5256	.4115	.7701	.0678
13	.0693	.0678	.0503	.5658	.4801	.7625	.0678
14	.0693	.0503	.0503	.6783	.6859	.7701	.0509
15	.0693	.0514	.0671	.6783	.7888	.8583	.0509
16	.0693	.0686	.0663		.7888	.9012	.0509
17	.0076	.0686	.0819		.1029	.0678	.0509
18	.0693	.0686	.0671		.1029	.0857	.0848
19	.1214	.1052	.0995	.0848	.1029	.1052	.0848
20	.1387	.1063	.1006		.12	.1052	.1017
21	.1387	.1063	.1017		.1029	.1063	.1017
22	.3429	.4024	.4024		.0857	.0895	.503
23	.285	.3185	.3353		.0857	.0716	.3561
24		.2347	.2683	.3222	.0678	.0857	.0716
Max	.6371	.6882	.663	.6783	.7888	.9012	.503
Min	.0076	.0503	.0503	.0848	.0671	.0678	.0509
Avg	.1435	.1780	.1888	.4193	.2707	.3230	.1044

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 203 / 11 KV Khanapur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3353	.4359	.4578	.0509	.0857	.0716
2		.3353	.0339	.4191	.0503	.0693	.0716
3		.3688	.0339	.4527	.0678	.0693	.0716
4		.3978	.0339	.5087	.0671	.0686	.0716
5		.3978	.0339	.5426	.0678	.0686	.0716
6	.5197	.4475	.0509	.5533	.0671	.0857	.0886
7	.5197	.8951	.1017	.7291	.1174	.1187	.1402
8	.5197	.12	.0171	.1006	.0848	.12	.1029
9	.5087	.0686		.7291	.9326	.9054	.0678
10	.1029	.0678		.8383	.6783	.9175	.0671
11	.0686	.0678	.0663	.8648	.7122	.9175	.0838
12	.0514	.0686	.0838	.3391	.8139	1.0202	.0671
13	.0857	.1187	.0497	.763	.8139	1.0159	
14	.0514	.0503	.0503	.763	.8139	1.065	
15	.0514	.0514	.0514	.8309	.9259	1.0814	
16	.0514	.0678	.0671		.9602	1.1142	.0848
17	.0686		.0829		.0867	.0678	.0838
18	.0857	.12	.0848		.0701	.0857	.0838
19	.0857	.0876	.1017	.1017	.1052	.1052	.0848
20	.0857	.1063	.1006		.1052	.1063	.1006
21	.0857	.0886	.0995		.1052	.1075	.0838
22	.4458	.5365	.5765		.0686	.0895	.5765
23	.4024	.4694	.503		.0686	.0716	.4862
24		.3688	.4527	.4694	.0503	.0857	.0716
Max	.5197	.8951	.5765	.8648	.9602	1.1142	.5765
Min	.0514	.0503	.0171	.1006	.0503	.0678	.0671
Avg	.2106	.2450	.1414	.5567	.3285	.3934	.1253

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 204 / 11 KV Khanapur Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.1734	.181	.1543	.1677	.1715	.1791
2	.2204	.1753	.181	.1357	.1696	.1715	.1791
3	.2427	.1928	.181	.1734	.1677	.1715	.1791
4	.3294	.1928	.1791	.1907	.1865	.1886	.1791
5	.3294	.2103	.197	.2229	.2012	.2058	.2149
6	.2743	.2804	.2865	.2947	.2543	.2401	.2865
7	.3988	.4031	.443	.3944	.373	.373	.4075
8	.3772	.333	.3681	.3561	.3688	.3086	.3506
9	.3294	.2804	.2743	.2774	.2713	.2401	.3086
10	.2427	.2743	.2254	.2572	.2035	.2374	.2543
11	.208	.2204	.2743	.2543	.2374	.2204	.2035
12	.1734	.2035	.2012	.2347	.1526	.2058	.2035
13	.208	.1715	.2204	.2204	.2058	.2058	
14	.208	.1886	.2182	.2204	.2058	.2035	
15	.1734	.1865	.1715	.2035	.2058	.2058	
16	.208	.1865	.1734		.2229	.2401	.3052
17	.2454	.1543	.2572		.2229	.2401	.3391
18	.298		.2743		.2743	.1715	.3561
19	.3856	.333	.3429	.3052	.3086	.333	.3688
20	.3856	.3721	.3641		.4115	.3721	.407
21	.333	.3403	.3262		.3429	.3403	.407
22	.2804	.2865	.2774		.2713	.3224	.3052
23	.2254	.2328	.2229		.2035	.2149	.2229
24	.1907	.1734	.197	.1734	.1696	.1715	.197
Max	.3988	.4031	.443	.3944	.4115	.373	.4075
Min	.1734	.1543	.1715	.1357	.1526	.1715	.1791
Avg	.2704	.2420	.2516	.2393	.2416	.2398	.2788

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 205 / 11 KV Bhivghat Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.104	.12	.1075	.104	.0857	.1029	.1267
2	.0881	.104	.1086	.1029	.1052	.1029	.1267
3	.1063	.104	.1086	.0867	.1052	.104	.1086
4	.124	.12	.1086	.1063	.1017	.104	.1267
5	.1417	.12	.1254	.1254	.1174	.12	.1254
6	.1543		.1791	.1578	.1341	.1543	.1612
7	.1865		.2303	.1886	.1526	.1526	.1949
8	.1734		.2103	.1734	.1677	.1715	.1753
9	.0876		.1734	.12	.1372	.1543	.1543
10	.1578	.2543	.1372	.1006	.1372	.1526	.1357
11	.1402	.1526	.1214	.0838	.1029	.1715	.1357
12	.1227	.12	.1227	.0848	.1372	.1526	.1357
13	.1227	.1187	.1223	.0857	.1372	.1543	.1187
14	.0876	.1187	.12	.0857	.12	.12	.1017
15	.1052	.1052	.12	.0848	.1029	.1174	.1017
16	.1052	.104	.1214		.12	.1187	.1006
17	.1227	.1052	.12		.1052	.1372	.1174
18	.1402	.1227	.12		.1227	.1372	.1509
19	.1928	.1772	.1678	.1865	.1753	.1753	.1677
20	.2103	.197	.1865		.1753	.2126	.1886
21	.2427	.197	.2083		.2279	.197	.1715
22	.2058	.1791	.1928		.1886	.1791	.1526
23	.1372	.1254	.1417		.12	.1433	.12
24	.1017	.12	.1075	.1227	.1029	.12	.1254
Max	.2427	.2543	.2303	.1886	.2279	.2126	.1949
Min	.0876	.104	.1075	.0838	.0857	.1029	.1006
Avg	.1400	.1383	.1442	.1176	.1326	.1440	.1385

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 206 / 11 KV Balawadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.12	.1433	.1341	.8383	.8383	.8048
2	.1526	.12	.1267	.1357	.8478	.7956	.788
3	.1677	.12	.1267	.1543	.9326	.7625	.788
4	.1865	.1372	.1267	.1734	.9221	.7625	.8048
5	.2229	.1543	.1612	.1865	1.0174	.7956	.8619
6	.2014	.2035	.2328	.2155	1.3245	1.1271	1.0774
7	.2486	.2374	.2481	.2347	1.8442	1.7924	1.278
8	.2014	.1715	.1753	.1658	.1696	.1715	.1696
9	.8551	.9054	1.2597	.0838	.12	.1372	1.4091
10	.8048	.6962	1.3077	.0857	.0857	.1017	1.5091
11	.8785	.6718	1.3565	.0678	.1029	.0848	1.4586
12	.8192	.8356	1.1065	.0848	.0857	.0838	1.4413
13	.852	.8951	1.2039	.1029	.1029	.1017	
14	.5243	.9339	1.1904	.0857	.1372	.0857	
15	.6226	.8951	1.1233	.0857	.1029	.0848	1.2548
16	.7209	1.0486	1.2407		.1029	.1029	1.1831
17	.0857	.1017	.0995		.1029	.1029	.1372
18	.1029	.12	.1187		.12	.0876	.1372
19	.208	.1949	.1989	.1886	.1734	.2103	.1753
20	.208	.2328	.218		.1734	.2149	.2058
21	.1886	.2149	.2204		.1734	.2149	.1844
22	.1543	.1791	.1677		1.1065	1.0227	.1543
23	.12	.1433	.1509		.9054	.8886	.1174
24	.1357	.12	.1433	.1341	.8573	.8383	.8383
Max	.8785	1.0486	1.3565	.2347	1.8442	1.7924	1.5091
Min	.0857	.1017	.0995	.0678	.0857	.0838	.1174
Avg	.3672	.3938	.5186	.1364	.5145	.4753	.7627

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244014 / 33/11 KV KHANAPUR

Feeder No / Name : 207 / 11 KV GOREWADI gaovthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0526	.0347	.0179	.0173	.017	.0343	.0358
2	.0532	.0351	.0179	.0171	.0168	.0347	.0358
3	.0532	.0351	.0179	.0514	.017	.0347	.0179
4	.0701	.0351	.0179	.0514	.0335	.0347	.0358
5	.104	.0351	.0358	.0716	.0339	.0343	.0358
6	.0693	.0701	.0532	.0709	.0678	.0514	.0709
7	.1029	.0876		.12	.0848	.1017	.1063
8	.1214	.0724	.1052	.0867	.0848	.12	.0876
9	.0686	.0526	.052	.0895	.0503	.0686	.0526
10	.0526	.0343	.052	.0678	.0686	.0514	.0339
11	.0351	.0343	.0514	.0509	.0514	.0509	.0339
12	.0351	.0509		.0339	.0343	.0343	.0339
13	.0351	.0343	.0173		.0343	.0509	
14	.0351	.0339	.0343	.0339	.0514	.0339	.0335
15	.0351	.0343	.0173	.0339	.0343	.0343	.0339
16	.0351	.0343	.0347		.0343	.0514	.0335
17	.0701	.0347	.0351		.0351	.0347	.0509
18	.0526	.0351	.0343		.0701	.0347	.0678
19	.0876	.0709	.0686	.1017	.0876	.0886	.0838
20	.0876	.0716	.0867		.1052	.0886	.0848
21	.0701	.0716	.0689		.0876	.0716	.0848
22	.052	.0537	.052		.0514	.0537	.0503
23	.0347	.0358	.0343		.0343	.0358	.0339
24	.052	.0347	.0358	.0175	.0339	.0343	.0358
Max	.1214	.0876	.1052	.12	.1052	.12	.1063
Min	.0347	.0339	.0173	.0171	.0168	.0339	.0179
Avg	.0611	.0468	.0428	.0572	.0508	.0526	.0510

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244117 / 33/11 KV Hiware Substation

Feeder No / Name : 201 / PALASHI AG

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1334	.1494	.1147	.4961	.4858	.427
2		.1334	.1294	.116	.4801	.4534	.427
3		.1334	.128	.1174	.4374	.4481	.427
4		.1334	.1494	.1341	.4374	.4481	.427
5		.1715	.1663	.1526	.4428	.4586	.4374
6		.2858	.3109	.2572	.9496	.7935	.6401
7		.3475	.3511	.3239	1.2431	1.1888	.8642
8		.2858	.2614	.2058	.2126	.2279	.2126
9	.4115	.8002	.6874	.1865	.1928	.2096	.9393
10	.3353	.8002	.7274	.1509	.1372	.1715	.8749
11	.2753	.7562	.759	.0995	.1387	.1478	.8381
12		.6944	.7935	.1174	.1387	.124	.8223
13	.3481	.679	.8002	.1174	.1334	.1715	.4696
14	.2374	.6554	.7935	.1174	.1524	.1267	.7116
15	.2347	.6706	.852	.1372	.1294	.1254	.8002
16	.2915	.8179	.9779	.1543	.1294	.1254	.8421
17		.1433	.1372	.1928	.1905	.1715	.1715
18	.2058	.168	.1402	.1753	.2286	.1905	.1928
19	.3189	.2801	.2507	.2865	.2835	.3048	.2328
20	.3239	.2801		.3109	.3048	.3239	.2926
21	.3048	.2614	.2454	.2926	.2667	.2858	.2534
22	.2286	.1829	.1886	.8059	.7209	.7045	.1772
23	.1715	.1478	.1357	.6539	.5761	.5376	.1402
24	.1402	.1334	.1463	.116	.5898	.5093	.4858
Max	.4115	.8179	.9779	.8059	1.2431	1.1888	.9393
Min	.1402	.1334	.128	.0995	.1294	.124	.1402
Avg	.2734	.3790	.4035	.2223	.3755	.3639	.5044

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244117 / 33/11 KV Hiware Substation

Feeder No / Name : 202 / 11 KV HIVARE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.3005	.2343	.2486	.1578	.1905	.1905
2	.2286	.2881	.2401	.2458	.1578	.1715	.1905
3	.2439	.2881	.2401	.2486	.1578	.1715	.1905
4	.2286	.2881	.2372	.2683	.1578	.1905	.1905
5	.25	.2591	.253	.2915	.1753	.1905	.2286
6	.4161	.4374	.5468	.5087	.2865	.2926	.3258
7	.945	.9962	1.0212	.7811	.3841	.4024	.4144
8	.3582	.3696	.3734	.3258	.2865	.3012	.2477
9	.2279	.2477	.2402	.7545	.9431	.8078	.1907
10	.1886	.181	.1829	.663	.7127	.6642	.1907
11	.1886	.1928	.1753	.5735	.7287	.6882	.1928
12	.1772	.197	.2035	.547	.5898	.6481	.1928
13	.1753	.197	.1677	.5407	.4843	.6483	.2303
14	.2012	.1991	.1638	.5921	.583	.6706	.1928
15	.2058	.197	.1619	.6642	.7522	.8124	.2126
16	.1865	.2353	.1989	.7316	.7655	.8259	.1928
17	.2035	.2328	.2103	.2401	.2229	.1928	.2126
18	.2629	.2801	.2103	.2229	.2229	.2858	.3077
19	.3761	.3547	.3077	.362	.3429	.362	.3696
20	.4001	.3547	.3475	.3841	.4001	.4191	.3921
21	.3429	.3361	.3045	.3475	.3429	.381	.3511
22	.4144	.4111	.4409	.2507	.2667	.2987	.4973
23	.3201	.2812	.3113	.1949	.2096	.2286	.3353
24	.2881	.3005	.2469	.2652	.1753	.1905	.2096
Max	.945	.9962	1.0212	.7811	.9431	.8259	.4973
Min	.1753	.181	.1619	.1949	.1578	.1715	.1905
Avg	.2941	.3094	.2925	.4272	.3961	.4181	.2604

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244117 / 33/11 KV Hiware Substation

Feeder No / Name : 203 / 11 KV HIVARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0358	.0362	.0354	.0362	.0358	.0358	.0358
2	.0358	.0362	.0351	.0362	.0358	.0358	.0358
3	.0358	.0362	.0358	.0358	.0358	.0358	.0351
4	.0358	.0358	.0362	.0358	.0358	.0362	.0358
5	.0358	.0358	.0351	.0358	.0358	.0362	.0358
6	.0543	.0526	.0537	.0351	.0543	.0701	.052
7	.0543	.0701	.0543	.0509	.0924	.1052	.0838
8	.0549	.0678	.0724	.0701	.0543	.0686	.0663
9	.0358	.0678	.0358	.0343	.0532	.0709	.0514
10	.0354	.0351	.0362	.0848	.0343	.0709	.0693
11	.0351	.0678	.0358	.0686	.0343	.0343	.0526
12	.0351	.0686	.0362	.0876	.0181	.0503	.0354
13	.017	.052	.0358	.0343	.0351	.0173	.0354
14	.017	.0343	.0351	.0671	.0354	.0655	.0514
15	.0497	.0514	.0537	.0678	.0351	.0648	.0701
16	.0686	.0343	.0895	.0503	.0497	.0175	.0701
17	.0328	.0693	.0701	.0343	.0686	.0175	.0351
18	.0497	.0716	.0724	.0514	.0693	.0335	.0732
19	.0686	.0724	.056	.0724	.0537	.0514	.0739
20	.0686	.0716	.0572	.0732	.0537	.0709	.0934
21	.0526	.0543	.056	.0543	.0693	.052	.0549
22	.0532	.0526	.0362	.0537	.0532	.052	.0358
23	.0362	.0358	.0358	.0358	.0351	.0354	.0358
24	.0358	.0362	.0351	.0358	.0358	.0351	.0358
Max	.0686	.0724	.0895	.0876	.0924	.1052	.0934
Min	.017	.0343	.0351	.0343	.0181	.0173	.0351
Avg	.0431	.0519	.0473	.0517	.0464	.0485	.0523

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244127 / 33/11 KV RENA VI SUBSTATION

Feeder No / Name : 201 / 11 KV RENA VI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.1898	.2778	.2364	.0509	.0509	.0463
2	.3086	.1966	.2778	.2332	.0509	.0514	.0463
3	.3086	.1989	.2778	.2332	.0514	.052	.0463
4	.3241	.1966	.2778	.23	.0514	.0514	.0463
5	.3241	.2105	.2778	.2364	.052	.0526	.0463
6	.3395	.3149	.3241	.2641	.0509	.0686	.0617
7	.4321	.4807	.4784	.3269	.0857	.0693	.0772
8		.0678	.0617	.0469	.0848	.0686	.0617
9	.0617	.0343	.0463	.3864	.6036	.5281	.0463
10	.0678	.0617	.0497	.4999	.6562	.6636	.0463
11	.0514	.0463	.0492	.5693	.6167	.7099	.0463
12	.052	.0463	.0497	.427	.7042	.8179	.0617
13	.0514	.0463	.0503	.6562	.7116	.8642	.0463
14	.0514	.0309	.0509	.6325	.6241	.8951	.0463
15	.0509	.0309	.0526	.7202	.6167	.9722	.0463
16	.0514	.0463	.064	.6009	.7362	1.034	.0463
17	.0678	.0463	.061	.0509	.0509	.0617	.0617
18	.0686	.0617	.0857	.0686	.0686	.0772	.0743
19	.0678	.0617	.0848	.0848	.0678	.0617	.0886
20	.0857	.0617	.0867	.0857	.0857	.0617	.0886
21	.0848	.0617	.0857	.0867	.0848	.0617	.0876
22	.2881	.3086	.2751	.0701	.0686	.0617	.4515
23	.1898	.2778	.2538	.0693	.0509	.0617	.4268
24	.3395	.1875	.2778	.23	.0514	.0514	.0463
Max	.4321	.4807	.4784	.7202	.7362	1.034	.4515
Min	.0509	.0309	.0463	.0469	.0509	.0509	.0463
Avg	.1729	.1361	.1615	.2936	.2615	.3104	.0893

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KHANAPUR[836]

BU 4836

Substation No/ Name :- 244127 / 33/11 KV RENA VI SUBSTATION

Feeder No / Name : 202 / 11 KV RENA VI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.0716	.0732	.0747	.0724	.0724	.0732
2	.0732	.0724	.0732	.0754	.0716	.0716	.0732
3	.0914	.0724	.0732	.0747	.0716	.0724	.0732
4	.0914	.0732	.0732	.0747	.0724	.0724	.0732
5	.1097	.0905	.0732	.0739	.0724	.0716	.0732
6	.1097	.1097	.1097	.112	.1075	.1086	.1097
7	.1463	.1448	.1829	.1494	.181	.197	.1646
8		.1254	.1829	.128	.1254	.1595	.128
9	.1097	.1075	.1097	.1075	.1063	.1097	.128
10	.0905	.0914	.0732	.0905	.0895	.0732	.1097
11	.0532	.0732	.0724	.0537	.0709	.0732	.0732
12	.0537	.0732	.0724	.0532	.0716	.0732	.0732
13	.0543	.0732	.0732	.0537	.0543	.0732	.0732
14	.0716	.0732	.0732	.0543	.0716	.0732	.0732
15	.0532	.0732	.0724	.0716	.0543	.0732	.0732
16	.0895	.0732	.0886	.0543	.0532	.0732	.0732
17	.0905	.0732	.104	.0724	.0895	.0732	.0732
18	.1075	.0732	.1075	.0716	.1086	.1097	.1075
19	.1448	.1463	.1294	.1595	.1612	.1463	.1663
20	.1646	.1646	.1494	.1433	.1646	.1646	.1663
21	.1448	.1463	.1494	.1267	.1433	.1463	.132
22	.128	.1097	.132	.1075	.1086	.128	.132
23	.0895	.0732	.0934	.0905	.0895	.0914	.0943
24	.0732	.0724	.0732	.0754	.0716	.0716	.0732
Max	.1646	.1646	.1829	.1595	.181	.197	.1663
Min	.0532	.0716	.0724	.0532	.0532	.0716	.0732
Avg	.0962	.0940	.1006	.0895	.0951	.0991	.0996

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 201 / 11 KV BURLI FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0564	.0549	.0526	.0488	.535	.6481	.759
2	.0572	.0556	.0526	.0472	.535	.6722	.7499
3	.0572	.0572	.0518	.0465	.5418	.6642	.703
4	.0705	.0579	.0518	.0503	.5418	.6481	.7287
5	.0714	.0892	.08	.0518	.5556	.6562	.759
6	.0869	.0903	.0914	.0556	.6562	.6642	.7773
7	.0846	.0892	.0903	.0892	.7316	.7407	.8642
8	.0823	.0857	.0594	.0834	.0564	.0406	.0705
9	1.3763		.9488	.0743	.0533	.0383	1.9113
10		1.2631	1.2483	.0488	.04	.0389	2.0885
11		1.2483	1.3763	.0457	.0389	.0354	2.1879
12		1.2334	1.3443	.0457	.0638	.0406	2.1628
13	1.4746	1.1111	1.2186	.0343	.0518	.0564	2.2874
14	1.278	1.0185	1.2186	.0354	.0383	.0564	2.1628
15	1.278	1.0185	1.1385	.0372	.0533	.0572	2.0645
16	1.2631	.9682	1.0311	.0377	.048	.0657	2.2131
17		.0389	.0434	.0472	.0442	.0754	.0465
18	.0495	.0619	.0404	.0465	.0495		.0619
19	.088	.0734	.0743	.0549	.0572	.0846	.0869
20	.0869	.0892	.0823	.0705	.0892	.0869	.0892
21	.0869	.0743	.08	.0695	.0857	.0846	.0753
22	.044	.088	.0648	.6321	.759	.759	.0762
23	.0572	.0734	.06	.6321	.6642	.8002	.0594
24	.0579	.0564	.0657	.4752	.6321	.6562	.759
Max	1.4746	1.2631	1.3763	.6321	.759	.8002	2.2874
Min	.044	.0389	.0404	.0343	.0383	.0354	.0465
Avg	.3853	.3912	.4402	.1192	.2884	.3335	.9893

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 202 / 11 KV RAMANANDNAGAR 1

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.2641	.3018	.3018	.3018	.3395	.3018
2	.3018	.2641	.3018	.3018	.3018	.3018	.3018
3	.3018	.2614	.2641	.3018	.3018	.3018	.2641
4	.3395	.2614	.2641	.3361	.3018	.3018	.2641
5	.3772	.3018	.2641	.3734	.3395	.3395	.3018
6	.4527	.3772	.3772	.4527	.3395	.3772	.3772
7	.5228	.5175	.4527	.4527	.4904	.4527	.4527
8	.5228	.4435	.4527	.4481	.3772	.4481	.4527
9	.439	.4961	.4527	.5548	.5068	.5068	.4481
10		.5258	.4961	.4854	.5014	.5487	.5609
11		.5014	.439	.5365	.5609	.5068	.567
12		.4409	.4435	.362	.4435	.439	.3658
13		.4024	.3772	.3696	.3696	.4066	.4527
14	.3582	.4557	.4252	.4607	.4298	.439	.4607
15	.3326	.394	.4344	.4908	.4755	.4706	.4298
16	.3189	.4359	.4298	.4908	.5014	.5258	
17	.362	.3898	.5014	.4344	.4435	.4961	.5201
18	.3582	.3658	.3544	.4252	.439		.5014
19	.5121	.3734	.5853	.4805	.5175	.5853	.5544
20	.4435	.4527	.5914	.4854	.5228	.5544	.5281
21	.4481	.4527	.5228	.5228	.4481	.4481	.4904
22	.3772	.4527	.4527	.4527	.4527	.4527	.4527
23	.3395	.3772	.3772	.3772	.3772	.3772	.3772
24	.3395	.3018	.3395	.3018	.415	.3772	.3395
Max	.5228	.5258	.5914	.5548	.5609	.5853	.567
Min	.3018	.2614	.2641	.3018	.3018	.3018	.2641
Avg	.3893	.3962	.4125	.4250	.4233	.4346	.4246

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 203 / 11 KV SAWANTPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0753	.0714	.0705	.0686	.9259	.9374	1.0402
2	.0762	.0579	.0695	.0676	.9145	.9488	1.0774
3	.0734	.0587	.0686	.0676	.9145	.9259	1.0174
4	.0762	.0556	.0714	.0705	.9145	.9145	1.0059
5	.0772	.0602	.0734	.0753	1.0155	.9374	1.1022
6	.0937	.0772	.1094	.0903	1.1069	1.0279	1.0402
7	.0892	.104	.088	.0903	1.2498	1.1431	1.0155
8	.1014	.0705	.0857	.0734	.0903	.088	.0762
9	1.6004	1.2955		.0648	.0629	.0714	2.2377
10	1.7604	1.5565	1.4403	.0667	.0676	.0705	2.4291
11	1.8404	1.4842	1.7004	.0619	.0695	.0857	2.4291
12		1.6204	1.7814	.061	.0686	.0705	2.4291
13		1.5432	1.7604	.0648	.0667	.0676	2.5396
14	1.3441	1.5023	1.7004	.0667	.0812	.0657	2.3482
15	1.4575	1.5203	1.5623	.0657	.1052	.06	2.3482
16	1.4403	1.5623	1.6194	.0629	.0743	.0564	2.1605
17	.0667	.0747	.06	.0743	.088	.0766	.0657
18	.0686	.061	.0619	.072	.0766		.0812
19	.0734	.0846	.088		.0857	.0869	.108
20	.0743	.0892	.0762	.0892	.0857	.1054	.0914
21	.0753	.088	.0753	.0753	.0869	.0903	.0791
22	.0753	.104	.0753	1.0936	1.0936	1.0279	.0753
23	.0762	.0743	.0705	1.0155	.9374	1.1203	.0762
24	.0781	.0743	.0724	.0686	1.0031	.9259	1.0279
Max	1.8404	1.6204	1.7814	1.0936	1.2498	1.1431	2.5396
Min	.0667	.0556	.06	.061	.0629	.0564	.0657
Avg	.4861	.5538	.5557	.1568	.4660	.4741	1.1626

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 204 / 11 KV RAMANANDNAGAR 2

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.4066	.4527	.4527	.4527	.4108	.4527
2	.3772	.4108	.4527	.3734	.415	.4108	.4527
3	.3772	.3734	.415	.4527	.415	.415	.415
4	.4904	.3734	.4527	.5281	.415	.4108	.415
5	.5281	.4161	.4904	.6036	.5281	.4527	.4904
6	.6036	.5548	.679	.6036	.679	.6036	.679
7	.679	.4252	.7545	.679	.7545	.6722	.7545
8	.6722	.4961	.6722	.4527	.6413	.5975	.679
9	.5228		.679	.6584	.6348	.5853	.679
10	.3856	.6653	.5175	.5792	.5975	.5853	.6219
11		.5853	.5792	.5487	.5975	.5544	.5914
12		.5175	.4481	.4481	.4854	.5228	.4527
13	.439	.4904	.4481	.4527	.5228	.5175	.5544
14	.3734	.5914	.5175	.4527	.5228	.5487	.6219
15	.3696	.5121	.4527	.4527	.4904	.5228	.5853
16	.3582	.5487	.5121	.5175	.3772	.4607	.5544
17		.5068	.5121	.439	.4527	.4854	.439
18	.4961	.5601	.4908	.4854	.5731		.5544
19	.6653	.7468	.6653	.6036	.7392	.7316	.7392
20	.7095	.7545	.6722	.7167	.6722	.7762	.7545
21	.679	.6653	.679	.6413	.6036	.679	.679
22	.6036	.679	.6036	.6036	.6036	.679	.6413
23	.5281	.6036	.5281	.5281	.4904	.5281	.5658
24	.4527	.4527	.5281	.4527	.4527	.4527	.4904
Max	.7095	.7545	.7545	.7167	.7545	.7762	.7545
Min	.3582	.3734	.415	.3734	.3772	.4108	.415
Avg	.5125	.5363	.5501	.5303	.5465	.5480	.5776

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244003 / 33/11 KV K'WADI S/S

Feeder No / Name : 401 / 33 KV KBL

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
23	.5316
Max	.5316
Min	.5316
Avg	.5316

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 201 / 11 KV Dudhondi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0625	.0625	.0781	.1875	.1932	.2743	.0762
2	.0625	.0633	.0625	.1875	.1932	.2743	.061
3	.0625	.0625	.0625	.1875	.208	.2743	.061
4	.0625	.0937	.0781	.2031	.1932	.3048	.0762
5	.0781	.0937	.0937	.2187	.208	.3353	.0914
6	.0781	.0937	.0937	.2343	.2675	.3353	.0914
7	.0937	.0625	.0781	.4218	.4755	.4572	.0762
8	.0937	.0625	.0781	.0781	.0892	.0762	.0762
9	.6562	.3749	.4999	.0625	.0743	.0762	.9259
10	.7186	.3749	.5312	.0625	.0594	.061	1.0623
11	.6874	.4374	.5624	.0587	.061	.061	1.1092
12	.6562	.4687	.5624	.0587	.061	.061	1.1405
13	.6249	.4999	.5937	.0587	.061	.061	1.1248
14	.5624	.4687	.3125	.0587	.061	.061	1.0936
15	.4999	.4687	.4062	.0587	.061	.0762	1.078
16	.4687	.4374	.4374	.044	.061	.0762	.9842
17	.0625	.0625	.0625	.0594	.061	.0762	.0937
18	.0625	.0781	.0655	.0743	.061	.0762	.0937
19	.0625	.0937	.0781	.0743	.061	.0914	.0937
20	.0949	.0937	.0781	.0594	.0762	.0914	.0781
21	.0781	.0937	.0781	.0594	.0914	.0914	.0625
22	.0625	.0781	.1875	.2229	.3048	.0762	.0781
23	.0625	.0781	.1875	.2107	.2439	.0762	.0781
24	.0625	.0781		.1875	.1783	.0762	
Max	.7186	.4999	.5937	.4218	.4755	.4572	1.1405
Min	.0625	.0625	.0625	.044	.0594	.061	.061
Avg	.2507	.1992	.2290	.1304	.1419	.1467	.422

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 202 / 11 KV Nagrale Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3768	.1966	.1966	.0663	.0633	.0648	.6478
2	.3605	.2294	.2294	.0663	.0633	.0648	.6154
3	.3605	.1966	.1966	.0663	.0474	.0648	.583
4	.3768	.2294	.2294	.0671	.0633	.081	.6154
5	.3932	.2294	.2622	.0838	.0791	.081	.6478
6	.4096	.2294	.2949	.1006	.0633	.081	.6802
7	.5571	.3932	.5243	.1006	.0633	.081	.8097
8	.0655	.0655	.0655	.0995	.0633	.0648	.0648
9	.0983	.0655	.0655	.6562	1.1069	1.2308	.0648
10	.0983	.0655	.0655	.7811	1.186	1.2631	.0648
11	.0655	.0655	.0655	.8223	1.1797	1.2955	.0648
12	.0655	.0655	.0655	.8539	1.2125	1.3279	.0648
13	.0655	.0655	.0655	.9014	1.166	1.2955	.0648
14	.0655	.0655	.0655	.8539	1.1469	1.2631	.0648
15	.0655	.0655	.0655	.8223	1.1336	1.1336	.0648
16	.0655	.0655	.0655	.8855	1.1336	1.0688	.081
17	.0655	.0655	.0655	.0633	.0648	.0648	.0648
18	.0655	.0819		.0791	.0648	.081	.0648
19	.0819	.0819	.0819	.0791	.0648	.081	.0648
20	.0819	.0983	.0819	.0791	.0648	.0972	.0648
21	.0655	.0819	.0819	.0633	.081	.081	.081
22	.2622	.2622	.0819	.0633	.081	.6802	.7287
23	.2622	.2622	.0819	.0633	.081	.6802	.7287
24	.3932	.2294		.0655	.0633	.6478	
Max	.5571	.3932	.5243	.9014	1.2125	1.3279	.8097
Min	.0655	.0655	.0655	.0633	.0474	.0648	.0648
Avg	.1986	.1440	.1363	.3243	.4307	.5364	.3042

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 203 / 11 KV Takari Exps

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 11 / OUTGOING

UTILITY

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4961	.5609	.567	.5258	.5895	.5784	.5609
2	.5014	.5373	.5959	.567	.5721	.5731	.5201
3	.4706	.5609	.5609	.5731	.5487	.6154	.5201
4	.4706	.583	.5201	.5373	.5487	.5609	.5609
5	.439	.5731	.5609	.567	.5658	.6089	.5784
6	.439	.5895	.5959	.5258	.5895	.5895	.5959
7	.4207	.5487	.6379	.5609	.5959	.5487	.6201
8	.5487	.6024	.6805	.6201	.724	.6024	.6805
9	.5258	.7522	.7164	.6805	.7964	.5731	.724
10	.5258	.6878	.6447	.567	.6984	.5731	.6516
11	.5487	.6447	.6201	.6024	.6154	.6089	.6626
12	.543	.6024	.6089	.6379	.6447	.5731	.6805
13	.5792	.6268	.5792	.631	.6154	.5316	.6584
14	.5731	.6516	.6584	.6485	.6805	.5609	.6335
15	.5853	.567	.724	.6588	.6154	.6024	.6024
16	.6154	.5959	.5121	.6661	.5914	.5609	.6268
17	.5258	.6733	.6335	.6485	.5914	.5959	.6089
18	.2591	.631	.6089	.6241	.6283	.5548	.6024
19	.2214	.5959	.5959	.6661	.7087	.5959	.6878
20	.7602	.6733	.567	.7087	.6024	.631	.6089
21	.6588	.6447	.6024	.6516	.6588	.6024	.5959
22	.6173	.6024	.5258	.631	.5895	.5609	.631
23	.5609	.631	.567	.6415	.7282	.5959	.6733
24	.5609	.5959		.5201	.6241	.5609	
Max	.7602	.7522	.724	.7087	.7964	.631	.724
Min	.2214	.5373	.5121	.5201	.5487	.5316	.5201
Avg	.5186	.6138	.6036	.6109	.6301	.5816	.6211

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 204 / 11 KV Nagrale Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5544	.7023	.7023	.5914	.7095	.7392	.7023
2	.5544	.6653	.6653	.5914	.7282	.7023	.6653
3	.5914	.6283	.6653	.6283	.7282	.6653	.6653
4	.7023	.7762	.7762	.7023	.7468	.7023	.7392
5	.924	.9979	.924	.8501	.7655	.7762	.924
6	1.1088	1.1088	1.0719	.9979	1.0456	.961	1.0719
7	1.2567	1.1458	1.1458	1.0719	1.0082	1.1088	1.1088
8	.9979	.924	.924	.8686	.8962	.924	.8501
9	.7762	.7392	.7392	.3696	.5788	.7392	.7023
10	.7023	.6283	.6653	.5914	.5975	.7023	.6283
11	.5914	.6283	.5544	.5788	.6653	.6653	.5914
12	.5544	.5914	.6283	.5788	.7392	.5914	.5729
13	.5544	.5914	.5544	.5601	.7023	.5914	.5544
14	.5544	.5544	.5544	.5601	.6653		.5544
15	.5544	.5544	.5544	.5601	.6283	.5914	.5729
16	.5175	.5544	.3696	.5601	.6283	.5914	.5544
17	.5544	.5914	.5914	.5788	.7023	.6283	.5729
18	.5914	.6283	.5544	.5788	.7392	.6653	.5914
19	.924	.924	.8131	.7842	.961	.924	.9425
20	.9979	.9979	.9795	1.0829	.9979	.9979	1.0164
21	1.0719	1.0349	.924	.9896	.961	.961	.9979
22	.924	.924	.9055	.9522	.924	.924	.8871
23	.7392	.8131	.7392	.8029	.7392	.7392	.7577
24	.5914	.7392		.7998	.7468	.7023	
Max	1.2567	1.1458	1.1458	1.0829	1.0456	1.1088	1.1088
Min	.5175	.5544	.3696	.3696	.5788	.5914	.5544
Avg	.7454	.7685	.7392	.7179	.7752	.7649	.7489

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244050 / 33/11 KV NAGRALE S/S

Feeder No / Name : 205 / Satteshwar LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3921	.1509	.1886	.2263	.1867	.2263
2	.4338	.1509	.1886	.2263	.2241	.2263
3	.4108	.1886	.2263	.2452	.2427	.2641
4	.3961	.1886	.2263	.2452	.2241	.3018
5	.3921	.2263	.2075	.2263	.2427	.3395
6	.3961	.2263	.2263	.2263	.2452	.3395
7	.3961	.2263	.2075	.3395	.2452	.3395
8	.5281	.1886	.3206	.3395	.2641	.3584
9	.547	.3206	.3395	.3395	.2427	.3395
10	.5415	.3206	.3206	.3395	.2263	.3395
11	.547	.3206	.3206	.3584	.1132	.3584
12	.5093	.1886	.2452	.3584	.1132	.3584
13	.5093	.3206	.2452	.3584	.0943	.3584
14	.5281	.3206	.2452	.3395	.0943	.3584
15	.4904	.3206	.2452	.3395	.1132	.2263
16	.3772	.3395	.2452	.3395	.1132	.1886
Max	.547	.3395	.3395	.3584	.2641	.3584
Min	.3772	.1509	.1886	.2263	.0943	.1886
Avg	.4622	.2499	.2499	.3030	.1866	.3077

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 201 / 11 KV PALUS CITY FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9619	.9808	1.0349	.9808	.9054	.8676	.8596
2	.8865	.9054	.9979	.9431	.8865	.8676	.8145
3	.9054	.9054	1.0242	.9054	.8676	.8676	.8145
4	.9054	.9054	1.0791	.8676	.8676	.9054	.8962
5	1.094	1.1694	1.3032	1.2071	.9431	.9619	1.2382
6	1.5844	1.419	1.5746	1.3769	1.3014	1.307	1.531
7	1.6975	1.643	1.6461	1.6057	1.4335	1.5655	1.643
8	1.5684	1.6057	1.4045	1.386	1.2883	1.419	1.3535
9	1.2696	1.3352	1.267	1.3352	1.2012	1.386	1.267
10	1.0242	1.2567	1.1584	1.2803	1.0829	1.3169	1.262
11	.9593	1.2449	1.1946	1.1946	1.1458	1.1523	1.2851
12	.9774	1.134	1.0791	1.0974		1.2071	1.1706
13	.9877	1.1584	1.0791	1.1104	1.2254	1.1706	1.2489
14		1.1523	.9694	1.0745	1.1584	1.1706	1.2071
15	1.1765	1.1273	1.0425	.9231	1.1104	1.1888	1.1827
16	1.0974	1.1883	1.0791	1.0136	1.0566	1.1946	1.2437
17	1.0924	1.2071	1.1222	1.1641	1.1888	1.2357	1.3112
18	1.1222	1.251	1.0679	1.1641	1.3032	1.1584	1.4842
19	1.6632	1.7558	1.5339	1.6078	1.5524	1.6297	1.5729
20	1.7924	1.6289	1.6057	1.6057	1.6078	1.6461	1.6817
21	1.531	1.5912	1.4563	1.4523	1.5089	1.5524	1.5684
22	1.3203	1.3756	1.3957	1.3203	1.2826	1.4632	1.4712
23	1.226	1.1523	1.1317	1.0751	1.1694	1.2254	1.2071
24	1.0751	1.1317	1.0791	.9808	.9054	.9431	.9979
Max	1.7924	1.7558	1.6461	1.6078	1.6078	1.6461	1.6817
Min	.8865	.9054	.9694	.8676	.8676	.8676	.8145
Avg	1.2138	1.2594	1.2219	1.1947	1.1736	1.2251	1.2630

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 202 / 11 KV MIDC PALUS FEEDER SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5093	.5281	.5041	.4904	.547	.5281	.5415
2	.4904	.5281	.5041	.4904	.5281	.5281	.5359
3	.4904	.5281	.5175	.4904	.5281	.5281	.5175
4	.4904	.5281	.5175	.5093	.547	.5281	.5175
5	.4904	.5658	.5304	.5093	.547	.547	.5487
6	.4904	.5658	.5359	.5093	.5658	.547	.5601
7	.547	.5658	.5228	.5093	.5093	.5658	.6908
8	.547	.6036	.6348	.5847	.679	.679	.7733
9	.6413	.9335	.9808	.7011	.823	.9694	1.1694
10	.547	1.4003	1.1949	.8413	.9593	1.2308	1.386
11	.547	1.1694	1.7164	1.0185	1.3817	1.5089	1.8296
12	.5281	1.0751	.9242	.9619	1.6057	.8488	1.1393
13	.5281	.8676	1.7926	.7545	1.6032	1.094	1.9774
14	.547	1.1694	1.905	.9054	2.0182	1.3121	1.8296
15	.6979	1.3121	1.9418	.9242	1.7924	1.3256	2.1125
16	.547	1.6598	1.7541	1.3769	1.6057	1.5466	1.5708
17	.5281		1.2803	1.1157	1.3203	.8596	1.5339
18	.6036	.7316	.9997	.5281	.6602	.7095	.9808
19	.547	.6348	.5281	.5847	.6224	.5847	.8676
20	.547	.5281	.4527	.547	.5658	.5281	.5658
21	.5281	.5281	.4527	.5093	.5281	.5847	.547
22	.5281	.5093	.4527	.5281	.5281	.5658	.5847
23	.5281	.5093	.4715	.5281	.5281	.5658	.5658
24	.547	.5281	.547	.4904	.547	.5281	.5658
Max	.6979	1.6598	1.9418	1.3769	2.0182	1.5466	2.1125
Min	.4904	.5093	.4527	.4904	.5093	.5281	.5175
Avg	.5415	.7813	.9026	.6837	.8975	.8006	.9963

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 203 / 11 KV GONDILWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2614	.3361	.2241	.7926	.7499	.8288
2	.0943	.2614	.3361	.2241	.7773	.7186	.7537
3	.0943	.2427	.3206	.2263	.7676	.7186	.7449
4	.0943	.2427	.3395	.2641	.7827	.7362	.7611
5	.0943	.3547	.3361	.2957	.8383	.8322	1.1523
6	.0943	.3734	.3361	.3547	1.0311	1.0883	1.1984
7	.1132	.3734	.3881	.3696	1.5466	1.8084	1.2125
8	.0943	.3361	.3326	.3109	.2801	.3658	.3547
9	.578	1.2163	1.5604	.2481	.2926	.2926	2.2405
10	1.0631	1.3763	1.6872	.2561	.3174	.2743	2.5749
11	1.7833	1.4089	1.7497	.2402	.3361	.2772	2.769
12	1.6964	1.4083	1.6049	.2926		.2641	2.4806
13	1.5581	1.3272	1.448	.2561	.2614	.2926	2.4486
14	1.5089	1.3123	1.2793	.2561	.2402	.2715	2.2245
15	1.4251	1.3123	1.3565	.2829	.2772	.2743	2.3685
16	1.3272	1.3765	1.3279	.2587	.2987	.2715	2.2996
17	.2195	.2195	.2155	.2743	.2641	.3045	.2629
18	.2743	.2378	.2195	.2926	.3109	.2987	.3109
19	.3174	.3258	.2772	.3511	.3326	.3395	.3142
20	.2987	.3475	.3109	.3696	.3696	.3584	.3511
21	.2987	.3547	.3142	.3361	.3511	.3361	.3109
22	.2614	.3361	.3142	.953	.9998	1.0974	.3174
23	.2614	.3395	.2561	.8642	.9686	1.0277	.2614
24	.2641	.2614	.3206	.2402	.7926	.8436	.9831
Max	1.7833	1.4089	1.7497	.953	1.5466	1.8084	2.769
Min	.0943	.2195	.2155	.2241	.2402	.2641	.2614
Avg	.5850	.6503	.7070	.3351	.5752	.5768	1.2302

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 204 / 11 KV MINI MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1509	.132	.2241	.1509	.1509	.1698
2	.1509	.1509	.132	.2263	.1509	.1509	.1494
3	.1509	.1509	.1494	.1886	.1509	.1509	.1494
4	.1698	.1509	.1494	.1886	.1509	.1509	.132
5	.1698	.1509	.1494	.1886	.1509	.1509	.1509
6	.1698	.1698	.1698	.1698	.1509	.1698	.1494
7	.1509	.3018	.1509	.1509	.1509	.1886	.1509
8	.1886	.3395	.3395	.3584	.3395	.3395	.3734
9	.1886	.3772	.3961	.3961	.3772	.415	.4294
10	.1867	.3584	.3961	.3961	.4338	.3395	.4338
11	.1867	.415	.415	.3961	.3961	.4338	.4715
12	.1698	.3395	.3018	.2829	.3174	.3584	.2829
13	.1698	.3584	.3395	.2641	.2829	.3018	.3584
14	.1867	.415	.3772	.3018	.2829	.3961	.3961
15	.1867	.3584	.3395	.3395	.3547	.3395	.3772
16	.1886	.4338	.3772	.415	.3395	.3961	.415
17	.1698	.3206	.3018	.3395	.3395	.3772	.3584
18	.1886	.2427	.1886	.2829	.3018	.3547	.3395
19	.1698	.2075	.1509	.2829	.3018	.3018	.3018
20	.1698	.1886	.1509	.2263	.2452	.2641	.2452
21	.1509	.1886	.1698	.1886	.1886	.2427	.2075
22	.1509	.1509	.1509	.1886	.1886	.1886	.2075
23	.1698	.1509	.1509	.1698	.1886	.1886	.1886
24	.1698	.1509	.1509	.1698	.1509	.1886	.1886
Max	.1886	.4338	.415	.415	.4338	.4338	.4715
Min	.1509	.1509	.132	.1509	.1509	.1509	.132
Avg	.1718	.2593	.2387	.2640	.2536	.2725	.2761

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 205 / 11 KV MAHADA COLONY

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0943	.0905	.0943	.0943	.0943	.0724
2	.0754	.0943	.0716	.0943	.0943	.0943	.0724
3	.0754	.0943	.0716	.0943	.0943	.0943	.0914
4	.0754	.0943	.0905	.0943	.0943	.0943	.1097
5	.0943	.1109	.1075	.1132	.1132	.112	.1075
6	.1509	.1109	.1578	.1494	.1698	.1307	.1578
7	.2033	.1646	.1753	.1829	.1629	.2195	.1928
8	.2218	.1829	.1886	.181	.2218	.1463	.1928
9	.1829	.1578	.1402	.1463	.1663	.1629	.1543
10	.1402	.1214	.1357	.1341	.1612	.1612	.1311
11	.12	.1387	.1677	.1341	.1578	.1698	.1372
12	.0857	.124	.12	.1448	.1402	.1698	.1357
13	.1006	.104	.104	.1052	.12	.1387	.1372
14	.0838	.1075	.1029	.1052	.1174	.1254	.1387
15	.0857	.1214	.116	.1029	.1341	.1612	.12
16	.0876	.124	.104	.1187	.1372	.1698	.1457
17	.1052	.1433	.1526	.1174	.1753	.1698	.1696
18	.1214	.1646	.104	.1526	.1174	.1829	.1696
19	.1646	.181	.1433	.1646	.1433	.1433	.1646
20	.1463	.1753	.1663	.1663	.1646	.181	.1663
21	.1307	.1372	.128	.1494	.1494	.1629	.1663
22	.1307	.1402	.1509	.168	.1509	.1402	.168
23	.1132	.1254	.1132	.112	.1509	.1227	.132
24	.0943	.0943	.0905	.0943	.0943	.1132	.0895
Max	.2218	.1829	.1886	.1829	.2218	.2195	.1928
Min	.0754	.0943	.0716	.0943	.0943	.0943	.0724
Avg	.1202	.1294	.1247	.1300	.1386	.1442	.1384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244051 / 33/11 KV PALUS SUB-STATION

Feeder No / Name : 206 / 11 KV M.I.D.C. JAWAHAR SHEDDABLE FEEDER HAVING WEEKLY
VIDYLAY Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6224	.7356	.7167	.7167	.7922	.7545	.7545
2	.6224	.7167	.6979	.679	.7922	.7545	.7545
3	.6224	.7167	.6722	.679	.7545	.7167	.7282
4	.6036	.7167	.6722	.679	.7545	.7167	.7095
5	.7356	.7167	.7545	.7167	.7733		.7167
6	.7356	.7545	.7545	.7356	.7545		.7356
7	.7545	.7356	.7545	.679	.7356	.7356	.7095
8	.7733	.7356	.7545	.6979	.7733	.7545	.7167
9	.7356	.6413	.6348	.6979	.9896	.7167	.6224
10	.7167	.3772	.6036	.6979	.9896	.9709	.6602
11	.7167	.5658	.7095	.6036	.6224	2.1125	.6908
12	.7095	.7167	1.2445	.7167	.6413	.9997	.8299
13	.7095	.7712	1.2449	.7167	.9149	1.7164	1.0185
14	.7545	1.1317	1.0867	.6413	1.1506	1.4415	.9425
15	.7282	.6036	1.2826	.6413	1.0562	1.1403	1.2826
16	.7733	.9997	1.2637	.7167	.6161	1.094	.7619
17	.7468	1.0829	.7167	.7167	.9808	1.358	.811
18	.7545	.6036	.7356	.6413	.679	.679	.7922
19	.6979	.6413	.6602	.6413	.679	.6908	.7545
20	.6979	.6535	.679	.6602	.7167	.7167	.6413
21	.6979	.6722	.7167	.7545	.7167	.7167	.6602
22	.7167	.679	.6979	.7922	.7545	.7095	.679
23	.7356	.7167	.679	.7922	.7922	.7095	.7356
24	.7922	.7356	.7167	.7356	.811	.7922	.7356
Max	.7922	1.1317	1.2826	.7922	1.1506	2.1125	1.2826
Min	.6036	.3772	.6036	.6036	.6161	.679	.6224
Avg	.7147	.7258	.8104	.6979	.8017	.9544	.7685

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 201 / 11KV ASAD

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0351	.5243	.3605	.503	.0351
2	.0343	.0343	.0351	.4915	.3605	.5144	.0351
3	.0343	.0343	.0351	.4915	.3605	.5144	.0351
4	.0343	.0343	.0351	.5407	.3605	.5144	.0351
5	.0343	.0343	.0351	.5735	.5735	.5144	.0351
6	.0343	.0343	.0351	.6226	.6554	.5144	.0343
7	.0343	.0343	.0343	.6554	.7045	.6706	.0335
8	.0343	.0343	.0335	.0343	.0328	.0343	.0335
9	.7045	.6718	.7545	.0343	.0343	.0343	1.0059
10	.6882	.6371	.8029	.0343	.0343	.0335	1.1142
11	.7045	.6371	.8848	.0343	.0343	.0335	1.2125
12	.7865	.7042	.9667	.0343	.0343	.0335	1.2452
13	.852	.6874	.9339	.0343	.0343	.0335	1.2289
14	.8192	.6706	.9175	.0343	.0343	.0335	1.1797
15	.8029	.7209	.8848	.0343		.0335	1.2125
16	.7701	.7209	.852	.0343	.0343	.0335	1.1961
17	.0343	.0335	.0343	.0343	.0343	.0335	.0343
18	.0343	.0351	.0343	.0343	.0343	.052	.0343
19	.0343	.0351	.0343	.0343	.0229	.052	.0343
20	.0343	.0351	.0343	.0343	.0514	.052	.0343
21	.0343	.0351	.0343	.0343	.6706	.052	.0343
22	.0343	.0351	.5735	.3605	.6706	.052	.0343
23	.0343	.0351	.5407	.3605	.6859	.0351	.0343
24	.0343	.0343	.0351	.953	.3605	.503	.0351
Max	.852	.7209	.9667	.953	.7045	.6706	1.2452
Min	.0343	.0335	.0335	.0343	.0229	.0335	.0335
Avg	.2782	.2501	.3582	.2522	.2686	.2033	.4145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 202 / 11KV MOHITE VADGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8192	1.3108	1.3032	.0686	.0686		1.7833
2	.8192	1.278	1.286	.0686	.0686	.0857	1.749
3	.8192	1.2452	1.2689	.0686	.0686	.0857	1.7147
4	.8192	1.2616	1.2689	.0686	.0686	.0857	1.6804
5	.9831	1.2944	1.286	.0857	.0686	.0857	1.6804
6	1.3108	1.3108	1.3413	.1029	.0686	.0857	1.6461
7	1.4746	1.3599	1.4251	.1029	.0686	.0857	1.7604
8	.0655	.12	.1174	.1029	.0686	.0857	.0838
9	.0857	.0686	.0671	1.9662	2.3102	2.2939	.0671
10	.0857	.0686	.0686	2.1956	2.6052	2.3807	.0686
11	.0857	.0857	.0686	2.2611	2.4577	2.3472	.0857
12	.0857	.0857	.0686	2.4577	2.4577	2.2801	.0857
13	.0857	.1029	.0686	2.4249	2.2939	2.2634	.0857
14	.0857	.1029	.0686	2.2939	2.13	2.2466	.1029
15	.0857	.0857	.0686	2.2611	2.4577		.1029
16	.1029	.1029	.0686	2.2611	2.3205	2.2298	.12
17	.0857	.1029	.0686	.0686	.0857	.1006	.12
18	.0857	.1029	.0857	.0686		.1029	.12
19	.0857	.1029	.1029	.0686	.0857	.1029	.12
20	.0857	.0857	.1029	.0686	.0857	.1029	.12
21	.0857	.1029	.1029	.0686	.0857	.1029	.1029
22	1.4255	1.5089	.1029	.0686	.0857	1.9376	1.8351
23	1.4091	1.3889	.0857	.0686	.0857	1.9719	1.8023
24	.8192	1.3763	1.3717	.0857	.0686	.0857	1.989
Max	1.4746	1.5089	1.4251	2.4577	2.6052	2.3807	1.989
Min	.0655	.0686	.0671	.0686	.0686	.0857	.0671
Avg	.4957	.6106	.4945	.8065	.8767	.9613	.7928

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 203 / 11 KV 4TH SONSAL FEEDER NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.4115	.3856	.3772	.3944	.3944	.3467
2	.4115	.4287	.3856	.3944	.3944	.2629	.3467
3	.4115	.4115	.3856	.3944	.3944	.2629	.3467
4	.4115	.4287	.3856	.3944	.3772	.3944	.3641
5	.4115	.4115	.3856	.4115	.3772	.3944	.3641
6	.4115	.4115	.3944	.3944	.3772	.4287	.3814
7	.4115	.4287	.4115	.3944	.4115	.2858	.3944
8	.4115	.4458	.3772	.3944	.4115	.4287	.3772
9	.4115	.4115	.1715	.3944	.4115	.3944	.3772
10	.4115	.4207	.3944	.4115	.4115	.3772	.3944
11	.4287	.4207	.4115	.4115	.4287	.3772	.4115
12	.4115	.4031	.4115	.4115	.4287	.3772	.4115
13	.4115	.4031	.3944	.4115	.4287	.3601	.4115
14	.4287	.3856	.4115	.4115	.3944	.3601	.4115
15	.4115	.4207	.4115	.4115	.4287	.3429	.4115
16	.4115	.4031	.3944	.4115	.4287	.3429	.4287
17	.4115	.4207	.3944	.4115	.4572	.3601	.4115
18	.4115	.4031	.3944	.4115	.3944	.3601	.4115
19	.4287	.3856	.3944	.4115	.3429	.3814	.4115
20	.4115	.3856	.3944	.4115	.4287	.3641	.4115
21	.4115	.3856	.3944	.4115	.3944		.4287
22	.4115	.3856	.3944	.4115	.3944	.3467	.4115
23	.4115	.3856	.3944	.4115	.3944	.3467	.4115
24	.4115	.4115	.3856	.3944	.4115	.3944	.3467
Max	.4287	.4458	.4115	.4115	.4572	.4287	.4287
Min	.4115	.3856	.1715	.3772	.3429	.2629	.3467
Avg	.4137	.4087	.3858	.4044	.4049	.3625	.3926

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 204 / 11KV MOHITE VADGAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.3658	.3361	.2926	.2926	.3429	.3921
2	.3292	.3292	.3361	.2926	.2926	.2572	.3921
3	.3292	.3292	.3547	.2926	.2926	.2572	.4294
4	.3292	.3658	.3734	.3292	.3292	.2572	.4481
5	.439	.4755	.4854	.4024	.4024	.3429	.5228
6	.4755	.5487	.5914	.5487	.5487	.5144	.6161
7	.4024	.695	.7023	.695	.8048	.6859	.7842
8	.3292	.5853	.5914	.5487	.6219	.6001	.5121
9	.4755	.4755	.4066	.4024	.4024	.5144	.3658
10	.4024	.3658	.3658	.4024	.4024	.3658	.3292
11	.3658	.3475	.3292	.4024	.3429	.3292	.3292
12	.3658	.3475	.2926	.695	.3429	.2926	.3292
13	.3292	.3658	.2926	.439	.2572	.2926	.3292
14	.3292	.3326	.2926	.3292	.2572	.2743	.3292
15	.3292	.2587	.2926	.3292	.2572	.2926	.3292
16	.3292	.2957	.2926	.3475	.2572	.3292	.3292
17	.3658	.3881	.3292	.3658	.3429	.3475	.3292
18	.5121	.5788	.439	.4024	.3429	.4755	.4755
19	.6584	.7095	.5487	.5487	.5144	.5544	.6219
20	.5853	.6535	.6584	.695	.6001	.7095	.6584
21	.5121	.5788	.6219	.6584	.5144	.6535	.5853
22	.5121	.3734	.5121	.5121	.5144	.5601	.5121
23	.4755	.3734	.4024	.4024	.3429	.5601	.4024
24	.4024	.4024	.3547	.2926	.3292	.3429	.4294
Max	.6584	.7095	.7023	.695	.8048	.7095	.7842
Min	.3292	.2587	.2926	.2926	.2572	.2572	.3292
Avg	.4146	.4392	.4251	.4428	.4002	.423	.4492

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 205 / 11 KV RAMAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6554	1.3923	1.4083	.0686	.0686	.0857	1.7772
2		1.3603	1.3748	.0686	.0686	.0514	1.7436
3		1.3443	1.3413	.0686	.0686	.0514	1.6766
4		1.3763	1.358	.0686	.0686	.0514	1.6095
5		1.4403	1.3413	.0686	.0686	.0857	1.5424
6		1.5043	1.278	.0857	.0686	.0857	1.4754
7		1.5524	1.278	.1372	.0686	.0857	1.6057
8		.0686	.0819	.1029	.0686	.0857	.0819
9		.0686	.0655	1.9524	2.4741	2.13	.0328
10		.0492	.0686	2.1628	2.7199	2.5396	.0343
11		.0655	.0686	2.2611	2.5396	2.4905	.0343
12		.0492	.0686	2.3266	2.5396	2.4577	.0343
13	.1029	.0492	.0686	2.3663	2.4577	2.3102	.0343
14	.1029	.0492	.0686	2.13	2.2939	2.2611	.0343
15	.1029	.0655	.0686	2.0972	2.2939	2.1628	.0343
16		.0655	.0686	2.0645	2.0719	2.0972	.0686
17	.0686	.0655	.0686	.0686	.0914	.0655	.0686
18	.0857	.0671	.0686	.0686	.0857	.0671	.0857
19	.0857	.0671	.0857	.0686	.0857	.0671	.1029
20	.0857	.0671	.1029	.0686	.0857	.0671	.1029
21	.0857	.0838	.1029	.0686	.0857	.0671	.0857
22	1.4723	1.5424	.0857	.0686	.0857	1.7604	1.5524
23	1.4403	1.5592	.0686	.0686	.0857	1.7436	1.5043
24	.6554	1.4243	1.5089	.0686	.0686	.0857	1.861
Max	1.4723	1.5592	1.5089	2.3663	2.7199	2.5396	1.861
Min	.0686	.0492	.0655	.0686	.0686	.0514	.0328
Avg	.4120	.6407	.5041	.7741	.8589	.9565	.7160

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 206 / 11 KV CHINCHNI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0514	.0503	.6401	.6554	.6859	.0503
2	.0686	.0514	.0503	.6401	.6554	.5144	.0503
3	.0686	.0514	.0503	.6401	.6554	.5144	.0503
4	.0686	.0514	.0503	.6722	.7209	.5144	.0503
5	.0686	.0514	.0503	.6722	.6882	.6859	.0503
6	.0686	.0686	.0492	.7202	.7373	.6706	.0671
7	.0686	.0686	.0655	.7362	.8192	.8383	.0838
8	.0686	.0686	.0655	.0686	.0686	.0857	.0655
9	1.0814	.8029	1.0159	.0514	.0686	.0857	1.2125
10	1.0883	.7865	1.1843	.0686	.0686	.0492	1.2483
11	1.1043	.8356	1.2643	.0686	.0857	.0492	1.3443
12	1.1043	.852	1.3123	.0686	.0857	.0492	1.3123
13	1.0883	.852	1.2803	.0686	.0857	.0492	1.3123
14	1.0722	.8192	1.2483	.0686	.0857	.0655	1.2803
15	1.0242	.852	1.1843	.0686	.0857	.0492	1.2803
16	.9922	.7373	1.0402	.0686	.0857	.0492	1.2803
17	.0686	.0328	.0686	.0686	.0857	.0655	.0514
18	.0686	.0503	.0686	.0686	.0857	.0503	.0514
19	.0686	.056	.0686	.0686	.0857	.0503	.0514
20	.0686	.0503	.0686	.0686	.0857	.0503	.0514
21	.0686	.0503	.0686	.0686	.6706	.0503	.0514
22	.0514	.0503	.7522	.7701	.6706	.0503	.0514
23	.0514	.0503	.7042	.7701	.6706	.0503	.0514
24	.0686	.0514	.0503	.6722	.7701	.6706	.0503
Max	1.1043	.852	1.3123	.7701	.8192	.8383	1.3443
Min	.0514	.0328	.0492	.0514	.0686	.0492	.0503
Avg	.4008	.308	.4921	.3282	.3657	.2497	.4645

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244062 / 33/11 KV M WADGAON

Feeder No / Name : 207 / 11 KV AMBAK AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1029	.112	1.1603	1.3763	1.1603	.1478
2	.1029	.1029	.112	1.1437	1.3435	1.0059	.1109
3	.1029	.1029	.112	1.1437	1.3108	1.0288	.1109
4	.1029	.1029	.112	1.1603	1.3108	1.0059	.1109
5	.1029	.12	.1307	1.2266	1.3763	1.0898	.1109
6	.1029	.1372	.1478	1.3094	1.6385	1.1603	.1663
7	.1029	.1715	.2218	1.3592	2.13	1.2289	.2195
8	.1029	.12	.1478	.12	.1029	.1372	.1829
9	1.7695	1.3763	1.4415	.1029	.1372	.1372	1.7924
10	1.6712	1.3108	1.4746	.1715	.1372	.1097	1.9753
11	1.5729	1.3272	1.5432	.1543	.12	.1097	2.0485
12	1.5729	1.1469	1.5775	.1543	.1372	.1097	2.1399
13	1.5402	1.4998	1.5604	.1543	.12	.128	2.1033
14	1.491	1.4632	1.5432	.1543	.0857	.128	2.0851
15	1.4419	1.5729	1.5432	.1543	.0857	.1463	1.9204
16	1.4091	1.4998	1.5089	.1543	.12	.1463	1.7924
17	.1029	.0732	.1029	.1886	.12	.1646	.1097
18	.1029	.0914	.1029	.1715	.128	.1663	.1097
19	.12	.1097	.1029	.1886	.1372	.1848	.1097
20	.12	.0924	.1029	.1886	.1372	.1663	.1097
21	.12	.1663	.1029	.2058	1.3108	.1663	.1097
22	.1029	.1494	1.3094	1.3763	1.3108	.1663	.1097
23	.1029	.112	1.2597	1.3763	1.1469	.1494	.1097
24	.1029	.1029	.112	1.1934	1.3763	1.1469	.1478
Max	1.7695	1.5729	1.5775	1.3763	2.13	1.2289	2.1399
Min	.1029	.0732	.1029	.1029	.0857	.1097	.1097
Avg	.5903	.5439	.6868	.6130	.7166	.4643	.7472

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 201 / 11 KV Wine Park 1

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0617			.1128		.0796
2		.0608			.1158		.0796
3		.064			.0884		.0914
4		.0724			.1		.1189
5		.0762			.128		.1326
6		.0819			.1029		.1257
7		.5304			.6283		.679
8		.3561			.2439		.7733
9		1.0669			1.3908		1.3769
10	.0335	1.2826	1.3203	.6413		1.094	1.3203
11	.064	.8299	1.4146	.724		1.7353	1.1317
12		.3772	1.5089	.547		.4954	.7545
13		.5847	1.3203	.811		.7811	.679
14		1.2826	1.3203	.7545		1.5466	1.1317
15		1.0185	1.5089	.9431		1.6221	1.1317
16		.7733	1.1317	.8488		.8676	.7545
17		.7733	.9431	1.0751		1.2826	1.1317
18	.0526	.7545	.9431	.5281		1.3392	.5281
19	.0686	.7356	.2462	.1463		.7356	.1286
20	.0617	.3206	.1858	.1402		.1486	.0819
21	.0709	.2263	.1486	.1257		.109	.0754
22	.064	.2452	.1143	.128		.1166	.08
23	.064	.0718	.104	.1158		.0914	.0754
24	.2452	.064		.08	.1128		.0914
Max	.2452	1.2826	1.5089	1.0751	1.3908	1.7353	1.3769
Min	.0335	.0608	.104	.08	.0884	.0914	.0754
Avg	.0805	.4879	.8722	.5073	.3024	.8547	.5230

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 202 / 11 KV Andhali Ag

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.4548		.1886	.2452	.2801	1.7736
2		1.4217		.1886	.2452	.2801	1.757
3		1.4403		.1886	.2641	.2801	1.7901
4		1.4548		.2075	.2829	.2801	1.8564
5		1.4706		.2452	.3206	.3734	1.9062
6		1.4685		.3395	.3584	.4338	1.9559
7		1.7236		.3395	.4338	.5041	2.0553
8		.415		.3395	.3772	.4294	.4338
9		.3395		2.4577	2.7349	3.2861	.4527
10		.3018	.3395	2.7854		2.9007	.3772
11		.3018	.2829	2.8664		2.9172	.0943
12		.2829	.2641	2.0729		2.8841	.4338
13		.3018	.2829	2.6355		2.8178	.5281
14	.3584	.3206	.2452	2.652		2.9504	.3395
15	.2829	.3395	.2452	2.5692		2.8178	.1886
16	.3018	.3772	.3018	2.5396		2.7362	.5601
17	.3018	.3772	.3395	.2641		.4954	.5093
18	.2641	.3584	.3395	.3584		.4715	.5658
19	.3772	.3584	.3584	.3395		.5658	.5281
20	.3961	.3584	.3018	.3772		.5093	.5093
21	.3772	.3584	.3018	.3772		.4904	.4904
22	1.6907	1.6385	.3018	.3395		1.989	1.7394
23	1.6617	1.6518	.2263	.3395		1.8564	1.6446
24		1.4864		.2075	.2641	.2801	1.8233
Max	1.6907	1.7236	.3584	2.8664	2.7349	3.2861	2.0553
Min	.2641	.2829	.2263	.1886	.2452	.2801	.0943
Avg	.6012	.8334	.2951	1.0508	.5526	1.3679	1.0130

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 203 / 11Kv Andhali Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2829			.2477	.2641	.2641
2		.2829			.2477	.2452	.2641
3		.3018			.2477	.2452	.2829
4		.3772			.2858	.2452	.3206
5		.415			.3429	.3395	.415
6		.4904			.4763	.5093	.4904
7		.5525			.4904	.5415	.5093
8		.4938			.3206	.4481	.4904
9		.3582			.2452	.4108	.3292
10	.2481	.2865	.3361	.2915		.3292	.2743
11	.1848	.2865	.2926	.2401		.2507	.2241
12		.2829	.2715	.2204		.1865	.2126
13		.3018	.2303	.218		.2427	.1949
14		.2896	.2303	.218		.2507	.2126
15		.3018	.1991	.2481		.2658	.2279
16		.3018	.2172	.2713		.2572	.2353
17		.3395	.2241	.218		.2401	.2481
18	.3641	.3961	.2614	.2572		.3086	.3506
19	.5544	.4715	.4481	.5121		.567	.443
20	.5359	.5281	.5093	.547		.5093	.5041
21	.4527	.4715	.415	.4715		.4338	.4108
22	.3961	.3961	.3361	.362		.3772	.3734
23	.3018	.3018	.2614	.2286		.3018	.2801
24	.2263	.3018		.2263	.2477	.2641	.2829
Max	.5544	.5525	.5093	.547	.4904	.567	.5093
Min	.1848	.2829	.1991	.218	.2452	.1865	.1949
Avg	.3627	.3672	.3023	.3020	.3152	.3347	.3267

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 204 / 11KV BAMBWADE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.128		.3361	.4001	.5441	.128
2		.1326		.3361	.4001	.5441	.128
3		.128		.3201	.4161	.5441	.128
4		.128		.4801	.4801	.5441	.144
5		.144		.4801	.6081	.8642	.16
6		.16		.8002	.8962	1.0722	.192
7		.208		.8002	1.2643	1.2811	.2401
8		.176		.112	.128	.16	.144
9		1.0883		.096	.096	.096	1.6004
10	.8642	1.0242	1.5684	.08		.096	1.5203
11	.9122	1.0402	1.2803	.08		.112	1.4403
12	.8482	1.0562	1.2803	.096		.112	.8642
13	.8962	1.0562	1.2163	.096		.08	1.3123
14	.7362	1.0562	.9282	.096		.08	1.4723
15	.6562	.7842	1.0402	.096		.112	1.4563
16	.6401	.7042	.8962	.096		.112	1.3763
17	.2881	.128	.08	.112		.112	.096
18	.112	.144	.112	.112		.16	.112
19	.16	.16	.144	.16		.192	.128
20	.16	.16	.16	.176		.176	.16
21	.16	.16	.16	.16		.176	.144
22	.16	.16	.4001	.5761		.176	.128
23	.144	.144	.3361	.4801		.144	.128
24	.128	.144		.3361	.4321	.5441	.144
Max	.9122	1.0883	1.5684	.8002	1.2643	1.2811	1.6004
Min	.112	.128	.08	.08	.096	.08	.096
Avg	.4577	.4256	.6859	.2714	.5121	.3348	.5561

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 205 / 11 KV MORALE AG

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.048		.7202	.8002	1.0402	.064
2		.048		.7202	.8002	1.0402	.064
3		.048		.7202	.7842	1.0402	.064
4		.048		.7362	.7682	1.0402	.064
5		.048		.7362	.7682	1.0562	.064
6		.064		.7522	.7522	1.0722	.064
7		.096		.8482	1.0082	1.2003	.096
8		.112		.064	.08	.096	.064
9		.2241		.064	.048	.064	1.8724
10	1.3603	1.3763	1.5684	.064		.048	1.8404
11	1.3443	1.4083	1.5203	.08		.032	1.7924
12		1.5043	1.4723			.08	1.5364
13		1.4723	1.4403	.048		.096	1.6644
14		1.4563	1.3763	.048		.08	1.7284
15		1.4403	1.2963	.064		.064	1.7924
16		1.3283	1.1683	.064		.08	1.5844
17		.08	.048	.08		.08	.064
18	.08	.08	.048	.08		.08	.08
19	.08	.08	.096	.08		.08	.08
20	.064	.08	.096	.064		.064	.064
21	.064	.096	.064	.064		.064	.064
22	.064	.096	.8162	.9122		.064	.064
23	.048	.064	.7682	.8322		.064	.048
24	.048	.048		.7042	.8162	1.0402	.064
Max	1.3603	1.5043	1.5684	.9122	1.0082	1.2003	1.8724
Min	.048	.048	.048	.048	.048	.032	.048
Avg	.3503	.4728	.8413	.3716	.6626	.4027	.6201

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 206 / 11KV LIS Feeder

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075		.0084	.2075	.0126	.924
2	.2075		.0084	.2075	.0126	.924
3	.2075		.0084	.2075	.0126	.924
4	.2075		.0084	.2075	.0105	.924
5	.2075		.0084	.2075	.0105	.924
6	.2075		.0084	.2075	.0105	.924
7	.4075		.208	.2075	.0147	.7392
8	.6224		.5658	.2075	.0267	.8686
9	.8686		.5658	.2075	.9149	.9055
10	.8871	.5415	.5658	.0189	.9055	.8775
11	.8962	.547	.5525	.0189	.9055	.8962
12	.8962	.5658	.547	.0183	.9055	.8589
13	.8775	.5658	.5658	.0183	.8686	.8589
14	.9054	.5658	.5658	.0084	.8686	.8676
15	.8676	.547	.5658	.0084	.8871	.8676
16	.8676	.5658	.5658	.0084	.8871	.8676
18						.8676
19						.8676
24	.2075					
Max	.9054	.5658	.5658	.2075	.9149	.924
Min	.2075	.5415	.0084	.0084	.0105	.7392
Avg	.5617	.5570	.3324	.1229	.4533	.8826

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244075 / 33/11 KV SANDAGEWADI

Feeder No / Name : 401 / 33 KV SOOTGIRANI

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.4712	1.5844	1.5844
2				1.5844	1.4712	1.5844
3				1.5844	1.4712	1.4712
4				1.4712	1.4712	1.5684
5				1.4712	1.4712	1.4712
6				1.5844	1.4712	1.5844
7				1.5844	1.4712	1.5844
8				1.4712	1.5844	1.6975
9				1.5844	1.358	1.4712
10	.679	1.5684	.679	1.4712	1.5844	1.4146
11	1.1317	1.5123	1.2449	1.358	1.6975	1.4712
12	1.2323	1.5684	1.2449	1.358	1.5844	1.4146
13	1.5684	1.4563	1.358	1.358	1.5844	1.5844
14	1.6804	1.4003	1.2449	1.2449	1.358	1.5844
15	1.6804	1.5123	1.2449	1.2449	1.358	1.6975
16	1.6804	1.4563	1.358	1.2449	1.358	1.5844
17	1.6975	1.4563	1.5844	1.358	1.358	1.5844
18	1.8107	1.5123	1.358	1.358	1.4712	1.6975
19	1.7924	1.5684	1.4712	1.358	1.4712	1.4712
20	1.6804	1.5684	1.4712	1.4712	1.4712	1.4563
21	1.6804	1.4563	1.358	1.4712	1.4712	1.5123
22	1.6804	1.5123	1.4712	1.5844	1.4712	1.5684
23	1.6804	1.4563	1.4712	1.5844	1.4712	1.6244
24			1.4563	1.4712	1.5844	1.4712
Max	1.8107	1.5684	1.5844	1.5844	1.6975	1.6975
Min	.679	1.4003	.679	1.2449	1.358	1.4146
Avg	1.5482	1.5003	1.3344	1.4476	1.4853	1.5481

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244129 / 33/11 KV SHIRASGAON

Feeder No / Name : 201 / 11 KV PADLI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0274	.0305	.0297	.3567	.4268	.3704	.0617
2	.0267	.0309	.0278	.3567	.4268	.3704	.0617
3	.0255	.0309		.3567	.4268	.3704	.0617
4	.0255	.0309	.0278	.4161	.4268	.3749	.0617
5	.0255	.0309	.0278	.4161	.4268	.3749	.0617
6	.0305	.0309	.0278	.4161	.4268	.3704	.0617
7	.0305	.0309		.4161	.4877	.4268	.0617
8	.0236	.0305		.0594	.0255	.0305	.0617
9	.3749	.3658	.4001	.0286	.0305	.0617	1.0722
10	.6173	.4572	.4755	.0286	.0309	.0617	1.3283
11	.6173	.4588	.4755	.0282	.0309	.0617	1.4563
12	.6173	.4588	.4755	.0282	.0309	.0617	1.5844
13	.6097	.4915	.4755	.0274	.0309	.0617	1.6409
14	.6097	.4588	.535	.0271	.0309	.0617	1.5844
15	.6097	.4752	.535	.0274	.0309	.0617	1.6741
16	.5487	.4752	.535	.0286	.0309	.0617	1.6741
17	.0309	.0328	.0594	.0259	.0309	.0617	.0332
18	.0309	.0328	.0594	.0236	.0309	.0625	.0332
19	.0309	.0328	.0594	.0259	.0305	.0617	.0332
20	.0309	.0305	.0594	.0248	.0305	.0617	.0305
21	.0309	.0305	.0594	.0263	.0305	.0617	.0305
22	.0305	.0305	.3567	.4268	.4012	.0617	.0274
23	.0305	.0305	.3567	.4268	.4012		.0274
24	.029	.0305	.0297	.3567	.4268	.3704	.0617
Max	.6173	.4915	.535	.4268	.4877	.4268	1.6741
Min	.0236	.0305	.0278	.0236	.0255	.0305	.0274
Avg	.2110	.1724	.2423	.1815	.1960	.1706	.5327

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244129 / 33/11 KV SHIRASGAON

Feeder No / Name : 202 / 11 SONSAL GAOTHAN FEEDER GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3258	.4344	.5487	.3772	.3658	.4344
2	.3395	.2896	.4344	.6219	.3772	.3658	.4344
3	.3395	.2896	.4344	.6219	.3772	.3658	.4344
4	.3395	.2896	.4344	.6219	.3772	.3658	.4344
5	.3772	.362	.6154	.7316	.3772	.4024	.4344
6	.6348	.6154	.724	.7316	.5658	.6154	.4344
7		.6878	.8048	.7316	.7023	.724	.4344
8	.7023	.7059	.6154	.695	.5175	.6516	.4344
9	.5792	.5068	.5068	.543	.4755	.6154	.5914
10	.4344	.4344	.4706	.3898	.4706	.6154	.5175
11	.362	.4344	.4344	.3582	.4706	.5792	.4805
12	.3258	.3982		.3224	.4706	.543	.4435
13	.3258	.362	.4344	.3224	.362	.5068	.4435
14	.2896	.362		.3224	.362	.5068	.4435
15	.2896	.3361		.3258	.362	.5068	.3982
16	.2896	.3361	.439	.3292	.2896	.4344	.3982
17	.2896	.3326	.4024	.3224	.4344	.4344	.3841
18	.5068	.567	.4755	.3544	.5068	.4344	.439
19	.5792	.7087	.5853	.5853	.6878	.5068	.5853
20	.6154	.6379	.5914	.7023	.6878	.5068	.6219
21	.5068	.6516	.5853	.6348	.6516	.5068	.567
22	.4344	.6219	.5487	.5658	.5792	.6878	.4668
23	.362	.5121	.5544	.4904	.5068		.3734
24	.3772	.362	.5121	.439	.415	.439	.5121
Max	.7023	.7087	.8048	.7316	.7023	.724	.6219
Min	.2896	.2896	.4024	.3224	.2896	.3658	.3734
Avg	.4191	.4637	.5256	.5130	.4752	.5078	.4642

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 244129 / 33/11 KV SHIRASGAON

Feeder No / Name : 203 / 11 KV SONKIRE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9804	.6009	.4481	.0463	.0381	.0463	1.0883
2	.9488	.6009	.4481	.0463	.0381	.0474	1.0883
3	.9488	.6009	.4481	.0463	.0381	.0474	1.0883
4	.933	.6009	.4481	.0463	.0381	.0474	1.0883
5	.933	.6009	.4481	.0463	.0381	.0469	1.0883
6	.933	.6009	.4961	.0463	.0412	.0469	1.0883
7	.9442	.6249	.5921	.0463	.0518	.0474	1.0242
8	.0381	.0446		.0463	.0419	.0474	.0648
9	.0381	.0446	.0463	1.166	1.5746	1.5497	.0486
10	.0474	.0412	.0463	1.2955	1.7394	1.4864	.0457
11	.0474	.0278	.0463	1.4091	1.7394	1.4864	.0457
12	.0474	.0556		1.5083	1.692	1.4548	.0429
13	.0469	.0556	.0463	1.5581	1.692	1.4548	.0429
14	.0469	.0429		1.5402	1.5813	1.4232	.0429
15	.0469			1.5074	1.5813	1.4232	.0429
16	.0474	.0572	.0463	1.491	1.4706	1.3916	.0429
17	.0469	.0572	.0463	.0495	.0316	.064	.0286
18	.0625	.0556	.0463	.0381	.0633	.064	.0572
19	.0625	.0533	.0463	.0381	.0625	.064	.0572
20	.0633	.0572	.0463	.0381	.0625	.064	.0446
21	.0633	.0572	.0463	.0381	.0625	.064	.0446
22	.6325	.4687	.0463	.0381	.061	1.0883	.9945
23	.6325	.4687	.0463	.0381	.061		.9945
24	.9922	.6325	.4687	.0463	.0381	.061	1.0242
Max	.9922	.6325	.5921	1.5581	1.7394	1.5497	1.0883
Min	.0381	.0278	.0463	.0381	.0316	.0463	.0286
Avg	.3993	.2804	.2177	.5071	.5766	.5877	.4674

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 201 / 11 KV DEORASHTRE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	2.4006
Max	2.4006
Min	2.4006
Avg	2.4006

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 202 / 11KV KUNDAL

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	.503
Max	.503
Min	.503
Avg	.503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 203 / 11 KV PALUS

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	.1307
Max	.1307
Min	.1307
Avg	.1307

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 204 / 11 KV LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	2.1795
Max	2.1795
Min	2.1795
Avg	2.1795

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSKARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 205 / 11 KV TAKARI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	.8002
Max	.8002
Min	.8002
Avg	.8002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 405 / 33 KV EBARA

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	.2195
Max	.2195
Min	.2195
Avg	.2195

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSARWADI S/DN.[085] BU 6271

Substation No/ Name :- 246007 / 110/33/11 KV KUNDAL S/ST

Feeder No / Name : 408 / Kranti Co-Gen-II NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	.1509
Max	.1509
Min	.1509
Avg	.1509

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

KIRLOSARWADI S/DN.[085] BU 6271

Substation No/ Name :- 259009 / 400KV KARAD STN.

Feeder No / Name : 807 / 220 KV KARAD KOP LINE 2 ND NON SHEDDABLE EHV INDUSTRIAL FEEDERS
CRT Feeder KV- 220 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING

DATE	01-SEP-17
HR	Load (MW)
24	8.5734
Max	8.5734
Min	8.5734
Avg	8.5734

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 201 / KADEPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.1109	.1509	1.5813	1.6194	1.6194	.2195
2	.1463	.1097	.1509	1.5497	1.6194	1.6194	.2195
3	.1463	.1086		1.5497	1.6194	1.5546	.2195
4	.1463	.1075		1.5497	1.5364	1.7284	.2614
5	.1463	.1791		1.6004	1.5364	1.7924	.2614
6	.1494	.2263		1.6004	1.5546	1.9433	.3361
7		.2241		1.749	1.6194	2.0317	.3734
8	.2195	.2218		.3658	.2957	.3696	.3696
9	2.0972	2.1765		.3658	.2957	.3696	2.8182
10	2.13	2.3594	.9717	.3658	.3696	.3658	3.0803
11	2.3205	2.4905	1.0364	.3696	.3696	.4066	2.9492
12	2.3205	2.2672	.9717	.2957	.2926	.439	2.9492
13	2.3205	1.9845	1.3108	.2987	.2926	.4435	3.3425
14	2.1548	2.2672	1.4746	.2957	.2926	.4024	.2926
15	2.0317	2.1376	1.5729	.2957	.2957	.4066	
16		1.9372	1.3108	.2957	.2926	.4066	.3658
17	.1147	.2957		.2957	.2957	.3658	.439
18	.116	.2926		.3696	.2926	.3696	.3658
19	.116	.2218	.2926	.2957	.2241	.3326	.3658
20	.1715	.2241	.2926	.2587	.2241	.3292	.3658
21	.1734	.2241	.2926	.2241	.2241	.2987	.3734
22	.1734	.2241	1.6446	1.749	1.749	.2987	.3734
23	.112	.1494	1.6446	1.6842	1.6644	.2614	.3734
24	.1463	.112	.1494	1.7147	1.6842	1.6644	.2614
Max	2.3205	2.4905	1.6446	1.749	1.749	2.0317	3.3425
Min	.112	.1075	.1494	.2241	.2241	.2614	.2195
Avg	.8000	.8605	.8845	.8634	.8442	.8258	.9120

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 203 / 11 KV Wangi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8002	.7133	.0366	.0724	.0686	.9488
2		.8002	1.379	.0366	.0716	.0686	.9488
3		.7907	.6371	.0351	.0716	.0678	.9374
4		.7907	.695	.0351	.0709	.0678	.9998
5		.8322	.7042	.0343	.0709	.0671	.9998
6		.8124	.7628	.0351	.0716	.0709	1.1111
7		.1029	.9633	.0351	.0724	.0724	1.1728
8		.1029	.061	.0351	.0709	.0678	.061
9		.1029	.0693	1.4419	1.4899	1.4723	.0693
10		.0716	.0351	1.4403	1.5546	1.5364	.0701
11		.0716	.0366	1.6004	1.5546	1.6004	.0701
12		.0671	.0366	1.5813	1.5546	1.6004	.0732
13		.0655	.0366	1.4373	1.6004	1.5181	.0732
14		.0663	.0366	1.4548	1.6004	1.5813	.0732
15		.0701	.0366	1.4548	1.3916	1.5623	.0732
16		.0671	.0366	1.3748	1.3916	1.4198	.0732
17		.0655	.0351	.0602	.0594	.0671	.0366
18	.1753	.0655		.0648	.064	.0655	.0366
19	.12	.0663	.0366	.0686	.0663	.0655	.0366
20	.1227	.0655	.0343	.0686	.0655	.0678	.0366
21	.0995	.0655	.0343	.0686	.0655	.0678	.0366
22	.9488	.7827	.0366	.0739	.0701	1.0242	1.1111
23	.8322	.7727	.0366	.0709	.0693	1.0242	1.0936
24		.8322	.7133	1.8861	.0724	.0693	1.0242
Max	.9488	.8322	1.379	1.8861	1.6004	1.6004	1.1728
Min	.0995	.0655	.0343	.0343	.0594	.0655	.0366
Avg	.3831	.3471	.3116	.6013	.5518	.6372	.4653

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 204 / 11 KV AMARAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1417	.12	.1463	.1029	.156	.156
2	.1829	.1402	.1214	.1463	.1017	.1372	.156
3	.1829	.1433	.1402	.1463	.1017	.1174	.156
4	.1829	.1433	.1417	.1463	.1174	.116	.1578
5	.1991	.2172	.1612	.1829	.1372	.1341	.1928
6	.2058	.2587		.2378	.2103	.197	.2303
7	.2058	.2561	.1907	.2743	.2715	.2896	.3012
8	.2058	.2103	.2241	.2195	.2035	.2204	.1989
9	.1829	.1886	.2012	.2012	.112	.218	.2012
10	.1848	.1214	.2195	.1829	.1638	.1943	.2012
11	.128	.1357	.2195	.1406	.16	.16	.2058
12	.12	.112	.2012	.132	.1406	.1524	.1886
13	.1029	.108	.1829	.1269	.1543	.1448	.1928
14	.1029	.08	.1463	.132	.1524	.1286	.2012
15	.1029	.0995	.1463	.1174	.0974	.1082	.2195
16		.0914	.1829	.1334	.0947	.1353	.2012
17	.1753	.125	.2012	.1303	.1391	.1448	.2012
18	.1791	.1423	.1463	.1614	.1593	.1614	.2195
19	.1886	.2429	.2195	.1658	.2429	.2347	.2195
20	.1928	.2204	.2743	.2012	.2321	.2743	.2378
21	.1928	.2204	.2561	.2347	.2347	.2515	.2561
22	.1753	.1734	.2195	.2149	.1949	.2401	.2561
23	.1417	.1526	.1646	.1595	.1753	.1715	.2378
24	.2195	.1402	.1357	.1646	.1214	.1753	.1715
Max	.2195	.2587	.2743	.2743	.2715	.2896	.3012
Min	.1029	.08	.12	.1174	.0947	.1082	.156
Avg	.1712	.1610	.1833	.1708	.1592	.1776	.2067

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 205 / 11 KV Wangi Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1402	.1478	.1494	.1494	.1509	.168	.1646
2	.1402	.1463	.1509	.1494	.132	.1494	.1629
3	.1402	.1448	.1509	.1494	.132	.1494	.1578
4	.1433	.1433	.1886	.1463	.1698	.1698	.1629
5	.1463	.2172	.2263	.1829	.2075	.1886	.2195
6	.2054	.2195	.2641	.2743	.2427	.2452	.2801
7	.2561	.2614	.3511	.3292	.3174	.3361	.3696
8	.3109	.2218	.2427	.2561	.2427	.2772	.2614
9	.1867	.2328	.2195	.2279	.2241	.2303	.2926
10	.1848	.181	.2012	.2012	.208	.2058	.2454
11	.1867	.1949		.1734	.1907	.2058	.2804
12	.1867	.1294	.1715	.156	.1715	.1802	.2454
13	.1494	.1463	.1715	.1677	.1526	.1844	.2279
14	.1402	.1578	.2012	.1509	.1509	.1638	
15	.1433	.1387	.2012	.1326	.1715	.1658	.2103
16		.144	.2195	.1562	.1581	.1823	.2195
17	.1578	.1526	.2195	.1526	.1658	.181	.1829
18	.1791	.1492	.2195	.1886	.1989	.1646	.2378
19	.2075	.2402	.2195	.2328	.0732	.2743	.2378
20	.2126	.2772	.2378	.2195	.2561	.2561	.2561
21	.2241	.2743	.2561	.2587	.2561	.2427	.2241
22	.1753	.2427	.2195	.2263	.2263	.1829	.2195
23	.1494	.1867	.1829	.1886	.2075	.1829	.2195
24	.1578	.1494	.168	.1494	.1698	.1886	.1829
Max	.3109	.2772	.3511	.3292	.3174	.3361	.3696
Min	.1402	.1294	.1494	.1326	.0732	.1494	.1578
Avg	.1793	.1875	.2101	.1925	.1907	.2031	.2287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 206 / 11 KV CHIKHALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.0876	.1075	1.2803	1.4251	1.5546	.1463
2	.1372	.0895	.0724	1.2803	1.3603	1.4899	.1463
3	.1402	.0905	.0724	1.2803	1.3603	1.4083	.1463
4	.1402	.0914	.1086	1.2803	1.3603	1.4083	.1463
5	.1433	.1109	.1463	1.3123	1.4419	1.4899	.1463
6	.1494	.1109	.1463	1.3603	1.5729	1.6385	.1829
7	.1463	.1109	.1848	1.4746	1.6575	1.7238	.1829
8	.1463	.1433	.1753	.1402	.1478	.1433	.2172
9	1.6385	.7727	2.1216	.1433	.1463	.1478	2.4531
10	1.6575	2.1879	2.0317	.1433	.1448	.1829	2.9492
11	1.7238	2.1879	1.9433	.1086	.1463	.1829	2.6216
12	1.848	1.989	2.0081	.104	.1097	.1829	
13	1.4723	2.0317	2.0081	.1402	.1097	.1829	
14	1.4403	1.9662	1.9433	.104	.1097	.1829	
15	1.3123	1.8351	1.7695	.0995	.1448	.1829	2.6871
16		1.5813	1.6385	.1006	.096	.181	2.5396
17	.1052	.1341	.0876	.104	.1402	.1829	.1063
18	.1075	.1417	.1463	.1029	.1075	.2195	.1417
19	.1029	.2865	.1402	.1017	.0995	.1448	.1463
20	.1052	.1063	.1463	.1017	.0995	.1448	.1097
21	.1052	.1063	.1463	.1017	.0995	.1448	.1463
22	.0943	.1075	1.3763	1.5729	1.704	.1448	.1646
23	.0895	.1075	1.3435	1.5074	1.6842	.1448	.1097
24	.1372	.0886	.1075	1.7147	1.4251	1.6385	.1311
Max	1.848	2.1879	2.1216	1.7147	1.704	1.7238	2.9492
Min	.0895	.0876	.0724	.0995	.096	.1433	.1063
Avg	.5687	.6861	.8322	.6525	.6955	.6270	.7438

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 207 / KADEPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2427	.1867	.2263	.1867	.1698	.3584	.3018
2	.2427	.1848	.2075	.1867	.1509	.3361	.2829
3	.2427	.1829	.2641	.1867	.1509	.2957	.2829
4	.2427	.181	.3018	.2241	.1494	.3142	.2829
5	.2614	.2587	.3395	.2614	.2641	.3292	.3395
6	.3584	.1867	.3961	.3361	.3395	.4668	.3961
7	.3584	.3174	.415	.4294	.415	.4904	.3961
8	.3584	.3361	.2829	.2987	.3395	.3584	.3018
9	.2263	.2801	.2452	.2641	.3206	.3206	.2452
10	.2218	.1886	.2641	.2241	.2263	.3395	.2075
11	.2241	.1886	.2427	.2263	.2263	.3584	.1867
12	.2263	.2075	.2614	.2641	.2641	.3395	.2241
13	.1494	.2241	.2427	.2534	.3018	.3395	.2241
14	.1646	.2452	.2614	.2263	.3018	.3395	.2614
15	.1663	.2587	.2012	.2033	.2829	.3395	.2241
16		.2263	.1829	.1886	.2829	.3018	.1867
17	.1867	.2263	.2054	.2075	.3206	.3206	.2241
18	.2218	.2075	.2614	.2452	.3018	.3395	.2054
19	.2614	.2452	.2801	.3018	.3961	.3961	.2614
20	.2587	.2452	.2801	.3018	.3772	.415	.2987
21	.2587	.2641	.2801	.2641	.3772	.415	.2614
22	.2241	.2641	.2561	.2452	.3772	.3772	.2987
23	.1886	.2452	.2241	.2263	.3772	.3395	.2987
24	.2427	.1886	.2263	1.8861	.1698	.3772	.3395
Max	.3584	.3361	.415	1.8861	.415	.4904	.3961
Min	.1494	.181	.1829	.1867	.1494	.2957	.1867
Avg	.2404	.2308	.2645	.3183	.2868	.3587	.2722

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244012 / 33/11 KV KADEPUR

Feeder No / Name : 401 / SAGARESHWAR SAHAKARI SOOT NON SHEDDABLE EXPRESS HV FEEDERS
GIRA Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1502	2.1502	2.2634	2.2634	2.4331	2.2634	2.2634
2	2.037	2.1502	2.2068	2.2634	2.4331	2.2634	2.32
3	1.9805	2.1502	2.1502	2.2634	2.4331	2.32	2.3765
4	1.9805	2.1502	2.1502	2.2634	2.4331	2.3765	2.3765
5	1.9805	2.1502	2.2068	2.2634	2.4897	2.4897	2.3765
6	1.9805	2.2068	2.2068	2.2068	2.4897	2.4897	2.4897
7	1.9805	2.2068	2.3765	2.2634	2.4897	2.6029	2.5463
8	1.9239	2.1502	2.3765	2.1502	2.2068	2.2634	2.3765
9	2.4897	2.5463	2.4897	2.3765	2.2068	2.4897	2.7161
10	2.4331	2.2634	2.4331	2.1502	2.32	2.4331	2.4331
11	2.3765	2.1502	2.1502	2.32	2.0936	2.4897	2.4331
12	2.4331	2.32	2.4331	2.4331	2.2068	2.4897	1.6975
13	2.4897	2.5463	2.4331	2.5463	2.32	2.4331	2.2634
14	2.32	1.8673	2.5463	2.4331	2.4331	2.4331	2.4331
15	2.32	2.4897	2.3765	2.2634	2.4331	2.32	2.4331
16		2.4331	2.3765	2.4331	2.4331	2.3765	2.4331
17	1.9805	2.3765	2.2068	2.1502	2.037	2.2634	2.1502
18	1.9805	2.2634	1.8107	2.1502	2.2634	2.1502	2.2634
19	1.9805	2.1502	2.0936	2.2068	2.037	2.2068	
20	1.9805	2.32	2.1502	2.1502	2.1502	2.1502	
21	2.0936	2.2068	2.32	2.1502	2.1502	2.0936	2.2634
22	2.2068	2.2634	2.3765	2.4331	2.3765	2.2634	2.2068
23	2.1502	2.2634	2.32	2.32	2.3765	2.32	2.2634
24	2.2634	2.1502	2.2634	1.7147	2.4897	2.32	2.32
Max	2.4897	2.5463	2.5463	2.5463	2.4897	2.6029	2.7161
Min	1.9239	1.8673	1.8107	1.7147	2.037	2.0936	1.6975
Avg	2.1527	2.2469	2.2799	2.2570	2.3223	2.3459	2.3380

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 201 / Kadegaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6348	.6516	.679	.6413	.7964	.7545
2		.5914	.6219	.6413	.5914	.7316	.7356
3		.5544	.6099	.6413	.5914	.6653	.7167
4		.5975	.7316	.679	.6348	.7316	.7167
5		.6908	.905	.7167	.679	.8131	.7922
6		1.0562	1.134	.9054	1.0082	1.1203	1.0562
7		1.419	1.3756	1.3957	1.4335	1.2803	1.475
8	1.1576	1.3014	1.134	1.1949	1.3957	1.2696	1.2696
9	.961	1.0829	1.0242	.9709	.9877	1.1088	1.0974
10	.823	.9511	.924	.7964	.8779	.9709	.905
11	.905	.8779	.8413	.8962	.8413	.8962	.8688
12	.7602	.8131	.8048	.788	.7964	.8048	.8145
13	.7964	.7316	.6878	.724	.7682	.7682	.7602
14	.6154	.543	.695	.7133	.724	.7316	.7602
15	.6219	.6219	.6584	.7682	.6584	.7316	.7682
16	.7059	.7023	.7207	.7059	.6805	.7316	.7682
17	.7522	.8048	.7316	.7059	.7682	.8779	.7602
18	1.0029	.8871	.8779	.8596	.9979	1.0349	.823
19	1.2197	1.0242	1.1458	1.094	1.0791	1.1458	1.1088
20	1.2883	1.2197	.924	1.251		1.1458	1.2136
21	1.1458	1.134	.8215	1.1458		1.1458	1.1203
22	1.0456	.9671	.7842	1.0719		1.0829	1.2136
23	.7922	.7964	.7392	.8215		.9054	.8488
24		.679	.7316	1.829	.6535	.9145	.7545
Max	1.2883	1.419	1.3756	1.829	1.4335	1.2803	1.475
Min	.6154	.543	.6099	.6413	.5914	.6653	.7167
Avg	.9121	.8617	.8448	.9165	.8404	.9335	.9209

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 202 / MIDC No.1

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7737	1.5775	1.7193	1.6301	1.595	1.7193	1.5927
2	1.7551	1.5074	1.7002	1.595	1.595	1.7013	1.576
3	1.6651	1.4746	1.6461	1.595	1.6118	1.7013	1.576
4	1.6827	1.5089	1.5927	1.6301	1.6126	1.7013	1.5746
5	1.6461	1.5261	1.5912	1.6301	1.5775	1.7375	1.5746
6	1.5769	1.5432	1.5927	1.6297	1.5775	1.7002	1.5912
7	1.56	1.5775	1.5074	1.6832	1.6124	1.6827	1.5927
8	1.3927	1.5257	1.5364	1.5604	1.5775	1.7002	1.4083
9	.9859	1.5424	1.7193	1.6827	1.6476	1.6461	1.3763
10	.9465	1.6827	1.7741	1.7372	1.6476	1.7002	1.4754
11	1.0145	1.7187	1.7013	1.7193	1.7193	1.7193	1.4419
12	.7756	1.7909	1.6118	1.773	1.7193	1.6827	1.3923
13	.7034	1.8656	1.5261	1.7558	1.7741	1.6118	1.3443
14	.6802	1.7375	1.5775	1.8473	1.7924	1.5424	1.3763
15	.7034	1.7741	1.5775	1.8656	1.7375	1.576	1.4083
16	.6899	1.7558	1.6301	1.9753	1.829	1.5939	1.5424
17	.9334	1.7013	1.6301	1.8656	1.848	1.5939	1.5257
18	.631	1.7375	1.6126	1.8088	1.7558	1.6108	1.5257
19	.6767	1.7193	1.6301	1.8656	1.6827	1.6108	1.5775
20	.7095	1.7556	1.6126	1.7924		1.5939	1.5604
21	1.3443	1.6827	1.6301	1.7193		1.5424	1.4723
22	1.4419	1.7193	1.6632	1.6476		1.576	1.4217
23	1.4419	1.7375	1.6461	1.6301		1.6108	1.4563
24	1.8484	1.5604	1.7372	1.3717	1.6476	1.6651	1.5927
Max	1.8484	1.8656	1.7741	1.9753	1.848	1.7375	1.5927
Min	.631	1.4746	1.5074	1.3717	1.5775	1.5424	1.3443
Avg	1.1908	1.6551	1.6319	1.7088	1.6780	1.6467	1.4990

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 203 / Shalgaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0753	.7907	.8322	.0747	.0739	.0914	1.8244
2	1.0279	.7842	.8192	.0747	.056	.0739	1.8244
3	1.0279	.759	.7956	.0747	.0566	.0732	1.8138
4	.9998	.7499	.7209	.1132	.0739	.0543	1.8299
5	.9842	.7499	.7125	.1132	.0943	.0732	1.8461
6	.9686		.7865	.132	.132	.1097	1.8785
7	1.2803			.1494	.1886	.1663	2.0972
8	.168	.1886		.1478	.1478	.1646	.1478
9	.132	.1509	.0732	2.2542	2.7526	2.5606	.1307
10	.0747	.132	.0724	2.2611	2.7854	2.7199	.0924
11	.0554	.112	.0724	2.5232	2.6406	2.6543	.0754
12	.0732	.1097	.0732	2.3594	2.6216	2.5888	.0747
13	.0747	.0924	.0732	2.3922	2.5857	2.6216	.0754
14	.0739	.0914	.0739	2.3922	2.5857	2.6543	.0754
15	.0739	.0724	.0747	2.3922	2.6216	2.4905	.112
16	.0732	.0732	.0934	2.4249	2.6189	2.3922	.112
17	.0732		.0914	.0739	.0914	.1612	.1267
18	.1109		.0914	.0895	.1109	.1448	.112
19	.128		.1109	.1132	.1097	.1448	.1294
20	.132		.1307	.132		.1463	.132
21	.1294		.112	.1294		.1478	.112
22	.8642		.0739	.112		1.9757	1.2955
23	.8539		.0739	.0895		1.9271	1.1336
24	1.1544	.8322	.8745	2.0576	.0754	.0914	1.8564
Max	1.2803	.8322	.8745	2.5232	2.7854	2.7199	2.0972
Min	.0554	.0724	.0724	.0739	.056	.0543	.0747
Avg	.4837	.3792	.3105	.9448	1.1211	1.0928	.7878

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 204 / Kadegaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0895	.0716	.0924	.5937	.7526	.8642	.1075
2	.0716	.0716	.0732	.5868	.7282	.852	.1086
3	.0905	.0549	.0724	.5868	.7133	.7621	.1086
4	.0905	.0732	.0914	.6015	.7133	.8124	.1097
5	.0905	.0876	.1478	.6622	.7133	.8124	.128
6	.0905	.128	.1829	.7074	.8535	1.1203	.1307
7	.1294	.1646	.2218	1.0467	1.3763	1.278	.1848
8	.128	.1478	.2195	.1372	.1663	.1463	.1829
9	1.0254	1.0936	1.1797	.1402	.1254	.1097	2.1052
10	1.1728	1.1111	1.2483	.1402	.1294	.1109	2.3594
11	1.2342	1.1843	1.2803	.0838	.1254	.1227	2.5194
12	1.25	1.278	1.3916	.1254	.1097	.1629	2.5857
13	1.2654	1.326	1.2654	.1109	.1109	.1402	2.556
14	1.1439	1.2125	1.2654	.1097	.1086	.1387	2.556
15	1.0837	1.1523	1.2346	.1254	.0924	.1227	2.3922
16	1.0536	1.0364	1.2037	.1075	.1097	.124	1.6842
17	.0983		.1254	.1307	.1267	.1254	.1372
18	.1254		.1254		.1254	.1448	.1753
19	.1463		.1417	.1433	.1463	.1448	.1753
20	.1227		.1417	.1463		.1448	.1448
21	.1109		.1227	.1294		.1448	.1254
22	.0895		1.5565	.8796		.1267	.1227
23	.0732		.6455	.7926		.1075	.1227
24	.0895	.0732	.0914	2.915	.7676	.9175	.1075
Max	1.2654	1.326	1.5565	2.915	1.3763	1.278	2.5857
Min	.0716	.0549	.0724	.0838	.0924	.1075	.1075
Avg	.4527	.6039	.5884	.4784	.4047	.3973	.8721

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 205 / MIDC No.2

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6733	.7108	.6062	.6878	.7712
2		.6805	.7108	.6415	.6767	.7537
3		.6516	.6859	.6173	.6653	.7455
4		.6584	.6859	.6588	.7133	.7455
5		.7316	.6935	.6661	.724	.7545
6		.7499	.703	.6687	.7682	.7373
7		.7392	.7186	.6859	.7392	.7796
8		.7316	.6539	.6661	.7392	.703
9		.8048	1.094	.8413	.8954	.9055
10		1.0136	1.4335	1.0719	.9511	1.1576
11		.9774	1.3957	1.0349	.9877	1.0456
12		.9313	1.094	1.0082	1.1016	1.1317
13		.9134	1.0349	.9511	1.0456	1.0349
14		.9511	1.4901	.9214	1.0269	1.1317
15		1.0242	1.5278	.9671	1.0829	1.1203
16		1.3203	1.1317	1.0242	1.1506	.7537
17		1.2437	1.0456	.9412	1.1203	1.0456
18	.7316	1.134		.9145	1.1203	1.1203
19	.7682	1.0498	.9709	.8871	1.0791	.9511
20	.8131	.8688	.9522		.8954	.9511
21	.8413	.8962	.7164		.7802	.663
22	.7964	.7682	.6344		.7716	.5944
23	.7762	.7133	.7164		.7377	.6097
24		.7011	2.1434	.6371	.695	.7712
Max	.8413	1.3203	2.1434	1.0719	1.1506	1.1576
Min	.7316	.6516	.6344	.6062	.6653	.5944
Avg	.7878	.8720	.9975	.8205	.8815	.8741

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 206 / SHALGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075	.1867	.2587	.2075	.2075	.2896	.2452
2	.2075	.1698	.2218	.1886	.1848	.2195	.2263
3	.1886	.168	.1829	.1886	.1848	.181	.2263
4	.2263	.1848	.2195	.2263	.2054	.2195	.2452
5	.2641	.2641	.2587	.3018	.2263	.2957	.3018
6	.4338	.4854	.439	.415	.4527	.3658	.4527
7	.6161	.6348	.5068	.5415	.6161	.5792	.6161
8	.5359	.5185	.439	.439	.5729	.5121	.5175
9	.4207	.4024	.2865	.3563	.5041	.4344	.4334
10	.3768	.3761	.2534	.2534	.3224	.3582	.373
11	.3041	.3292	.2454	.2401	.3292	.3856	.2683
12	.2454	.2587	.2572	.2149	.2896	.3944	.2713
13	.2328	.2241	.2486	.1791	.2926	.3429	.2321
14	.2195	.1829	.2374	.1802	.2561	.2915	.181
15	.2949	.181	.2229	.218	.2172	.3086	.2743
16	.2507	.2195	.2401	.2012	.2507	.407	.2126
17	.2469		.2804	.3224	.2926	.4115	.3018
18	.2865		.4298		.3696	.4477	.2601
19	.4481		.5373	.4656	.439	.4572	.4435
20	.4854		.4668	.5175		.439	.4854
21	.3921		.4481	.4854		.4481	.4527
22	.3361		.4854	.3961		.3734	.415
23	.2452		.2427	.2641		.3018	.3395
24	.2263	.2075	.2957	1.829	.2263	.3292	.2452
Max	.6161	.6348	.5373	1.829	.6161	.5792	.6161
Min	.1886	.168	.1829	.1791	.1848	.181	.181
Avg	.3205	.2937	.3210	.3753	.3220	.3664	.3342

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 207 / 11 KV KHAMBALE-A AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203	.852	.8322	.0739	.0924	.0709	1.6842
2	1.0883	.8223	.8192	.056	.0747	.0716	1.6518
3	1.0753	.8065	.7956	.056	.1698	.0537	1.6194
4	1.0279	.8016	.8192	.056	.0739	.0537	1.6194
5	1.1069	.8223	.8619	.1132	.0754	.0732	1.6194
6	1.1069	.8322	.8192	.132	.1132	.1109	1.6356
7	1.2803	1.0242	1.1523	.1698	.1509	.1478	1.7204
8	.1307	.132	.1097	.112	.1294	.128	.1294
9	.0924	.1132	.0732	2.1714	2.5724	2.4531	.1109
10	.0924	.112	.0732	2.2708	2.5857	2.5396	.1109
11	.0739	.112	.0732	2.3472	2.5888	2.5232	.1109
12	.0739		.0543	2.3537	2.4006	2.5194	.1109
13	.0914		.0543	2.3594	2.3482	2.5232	.0739
14	.0924		.0543	2.3266	2.3266	2.5724	.0739
15	.0895		.0543	2.3266	2.1765	2.5396	.0934
16	.0732		.0543	2.3266	2.1956	2.4905	.0732
17	.0914		.0724	.0537	.0732	.1494	.0905
18	.1109		.0165	.0716	.0905	.1494	.0914
19	.112		.1097	.112	.1097	.1494	.128
20	.1494		.1307	.132		.1494	.1509
21	.1294		.112	.1294		.1509	.1109
22	1.0159		.1109	.0934		1.7814	1.6575
23	.9282		.0739	.0934		1.7652	1.6078
24	1.1523	.8539	.9054	2.0576	.0943	.0739	1.7166
Max	1.2803	1.0242	1.1523	2.3594	2.5888	2.5724	1.7204
Min	.0732	.112	.0165	.0537	.0732	.0537	.0732
Avg	.5127	.6070	.3430	.9164	1.0221	1.0517	.7496

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244060 / 33/11 KV KADEGAON

Feeder No / Name : 208 / MIDC NO 3

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER MIDC EQUIVALENT
HAVING WEEKLY STAGGERING

DATE	29-AUG-17	30-AUG-17	01-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.7186	.6401	
2	.703	.6249	
3	.6859	.6562	
4	.6859	.6722	
5	.6836	.7042	
6	.6602	.7042	
7	.5079	.7537	
8	.503	.7377	
9	.3018	.8962	
10	.3605		
11	.3837		
12	.3353		
13	.3864		
14	.5617		
15	.5275		
16	.4755		
17	.5498		
18	.4344		
19	.4512		
20	.5213		
21	.6173		
22	.6722		
23	.6722		
24	.7274	.6722	1.5242
Max	.7274	.8962	1.5242
Min	.3018	.6249	1.5242
Avg	.5469	.7062	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / BELAWADE S/STN

Feeder No / Name : 201 / 11 KV Tondoli

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829			1.2616		2.0165	.2033
2	.1848			1.278		2.0119	.1829
3	.1646			1.2597		2.0058	.1848
4	.1646			1.2289		1.8679	.2012
5	.2012			1.2289		1.9334	2.3102
6	.2378			1.4255		1.9662	.3326
7	.3658			1.6221		2.0957	.4066
8	.2561			.2378	.3206	.3222	.2957
9				.2195	.2012		.1326
10		1.8023	2.4086	.2263	.2195	.2785	3.0849
11			2.3594	.2149	.2378	.2458	3.4808
12			2.6216		.2743	.2785	3.3813
13			2.3102	.2195	.2402	.213	3.5208
14			2.4577	.2507	.2587	.2195	3.6885
15			2.3594	.2772	.2772	.2378	3.5208
16			2.0809		.2957	.2926	3.1855
17			.2402	.2926	.3142	.2957	.2801
18			.2561	.3395	.3326	.3109	
19			.2926		.2987	.3292	
20			.3109		.3174		
21			.2957		.3361	.3292	
22			1.4419		2.2218	.2743	
23			1.3927		2.2592	.2561	.181
24	.1829			1.3435	1.8652	1.9978	.2195
Max	.3658	1.8023	2.6216	1.6221	2.2592	2.0957	3.6885
Min	.1646	1.8023	.2402	.2149	.2012	.213	.1326
Avg	.2156	1.8023	1.4877	.7604	.6041	.8990	1.5154

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / BELAWADE S/STN

Feeder No / Name : 202 / 11 KV Raigaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.491			.0914			2.556
2	1.4746			.0739			2.4741
3	1.491			.0732			2.4086
4	1.491			.0724			2.3594
5	1.4746						2.3102
6	1.4746						2.4741
7	1.4582						2.4577
8	.1147				.1478		.1463
9				2.4577	3.2388		.128
10		.1509	.1097	3.3532	2.6052		.1494
11			.0914	3.2556	2.4577		.1478
12			.0732		2.5888		.1646
13			.0549	3.2388			.1463
14			.0732	3.2217	3.1352	.7865	
15			.0914	2.9797	3.2047	3.8176	.1417
16			.1097		2.8147	3.3916	.2149
17			.0914	.1509		.1109	.2195
18			.1109	.1463		.128	
19			.1097			.1463	
20			.0914			.1463	
21			.1097			.1478	
22			.0914			3.1184	
23			.0914			2.8182	2.2131
24	1.4746			.0732	.1463		2.6216
Max	1.491	.1509	.1109	3.3532	3.2388	3.8176	2.6216
Min	.1147	.1509	.0549	.0724	.1463	.1109	.128
Avg	1.3271	.1509	.0928	1.476	2.2599	1.4612	1.2963

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / BELAWADE S/STN

Feeder No / Name : 203 / SOHOLI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658			.4572		.5228	.499
2	.3881			.4755			.4755
3	.3658			.462		.5487	.462
4	.3841			.462		.5853	.4572
5	.3475			.4938		.6219	.4805
6	.6767			.5853		.6219	.7392
7	.823			.7499		.8413	.7392
8	.7682			.695	.7316	.5487	.6653
9				.567	.4805		.5175
10		.5175	.4755	.5658	.4066	.6401	.5228
11			.5304	.5487	.4251	.439	.543
12			.5121		.4805	.4755	.5975
13			.4572	.3734	.4294	.4024	.5175
14			.4938	.4108	.5788	.4755	.5914
15			.439	.439	.4481	.4572	.5853
16			.439		.5041	.5729	.5601
17			.4024	.5281	.5228	.5853	.5487
18			.4207	.5853	.5415	.5914	
19			.6584		.591	.7316	
20			.823		.5853	.7762	
21			.7316		.6099	.7133	
22			.6584		.6535	.7682	
23			.5121		.5415	.5853	.6036
24	.3841			.439	.4572	.4481	.5121
Max	.823	.5175	.823	.7499	.7316	.8413	.7392
Min	.3475	.5175	.4024	.3734	.4066	.4024	.4572
Avg	.5004	.5175	.5395	.5199	.5287	.5888	.5588

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / BELWADE S/STN

Feeder No / Name : 204 / 11 KV UPALE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0983			1.3108		1.9791	.0983
2	.0983			1.3108		2.0119	.0983
3	.0983			1.278		2.0119	.0819
4	.0819			1.278		2.0058	.0983
5	.0983			1.3272		1.9982	.1147
6	.0819			1.5238		1.9982	.1638
7	.0819			1.7204		.2149	.213
8	.1311			.1802	1.9909	.1433	.1966
9				.1475	.1829		2.343
10		1.8138	2.0153	.1357	.1646	.1475	3.0803
11			2.343	.1341	.1463	.1638	2.7854
12			2.2119		.1463	.1638	3.0803
13			2.0481	.1457	.1294	.1475	3.0803
14			2.1792	.1509	.1294	.1638	3.2769
15			2.1956	.1492	.1294	.1802	3.0312
16			1.9989		.0924	.1475	2.8673
17			.1147	.1578	.168	.1638	.1311
18			.1311	.1646	.168	.1638	
19			.1638		.1867	.213	
20			.1475		.1867	.1802	
21			.1311		.1867	.1802	
22			1.491		2.0165	.1475	
23			1.4091		1.9605	.1147	.1147
24	.0819		2.3472	1.3763		1.9791	.1147
Max	.1311	1.8138	2.3472	1.7204	2.0165	2.0119	3.2769
Min	.0819	1.8138	.1147	.1341	.0924	.1147	.0819
Avg	.0947	1.8138	1.3952	.7348	.4990	.7226	1.3142

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / BELWADE S/STN

Feeder No / Name : 205 / 11 KV BOMBALEWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9831			.0655		.0701	1.4582
2	.9339			.0655		.0701	1.4255
3	.9175			.0492		.0895	1.3927
4	.9175			.0655		.0895	1.3927
5	.9339			.0819		.1097	1.3763
6	.9503			.1147		.1075	1.4582
7	1.0486			.1475		.1646	1.6221
8	.0983			.0983	.1227	.128	.0983
9				1.7859	2.4709		.0819
10		.0537	.0732	2.2213	2.7349	2.5724	.0655
11			.0732		2.4539	2.7035	.0819
12			.0492		2.7694	2.4741	.0983
13			.0655	2.0805	2.8654	2.5069	.0983
14			.0819	2.2043	2.9264	2.5069	.1147
15			.0655	2.13	2.652	2.556	.0983
16			.0819		2.4326	2.343	.1147
17			.0819		.0924	.0983	.0819
18			.0983	.128	.1294	.1147	
19			.1311		.1478	.1311	
20			.1147		.1478	.1147	
21			.0983		.1294	.0983	
22			.0819		.0934	1.6876	
23			.0819		.0747	1.6057	1.5402
24	1.0814			.0655		.0747	1.4746
Max	1.0814	.0537	.1311	2.2213	2.9264	2.7035	1.6221
Min	.0983	.0537	.0492	.0492	.0747	.0701	.0655
Avg	.8738	.0537	.0842	.7536	1.3902	.9746	.7408

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244079 / BELAWADE S/STN

Feeder No / Name : 206 / 11 KV LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848		.1848		.1638	.1848
2	.1848		.1848		.2622	.2033
3	.1848		.1848		.3277	.2033
4	.1848		.1848		.4096	.1848
5	.1848		.1848		.5243	.2033
6	.1848		.2033		.6371	.499
7	.1848		.1848		.7011	.3511
8	.1848		.1848	.6161	.6447	.3511
9			.1848	.4119		.2957
10		.1848	.2452	.4572	.6653	.3696
11		.2033	.2452	.5487	.7023	.3696
12		.2033		.7682	.4435	.3881
13		.1848	.7167	.7316	.4805	.3881
14		.1848	.695	.7499	.7207	.3696
15		.2033	.7023	1.6095	.7023	.2402
16		.1848		.1646	.2033	.2402
24			.3429			
Max	.1848	.2033	.7167	1.6095	.7207	.499
Min	.1848	.1848	.1848	.1646	.1638	.1848
Avg	.1848	.1927	.3086	.6731	.5059	.3026

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 201 / 11 KV WANGI AG

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.1006	.1006	1.2186	1.3108	1.4091	.124
2	.112	.1006	.1052	1.1873	1.2452	1.3441	.124
3	.1494	.0838	.1402	1.1574	1.2125	1.3441	.1052
4	.112	.0829	.1402	1.1111	1.2944	1.3441	.1052
5	.1646	.0995	.1715	1.1431	1.247	1.3927	.1734
6	.2195	.1658	.1886	1.2193	1.3923	1.3927	.2601
7	.2378	.2321	.2427	1.2803	1.5565	1.7652	.2427
8	.2054	.1658	.1543	.1844	.197	.1463	.2427
9	1.8656	1.5089	1.6484	.1341	.1433	.1463	1.89
10	1.5684	1.4352	1.7124	.1187	.1463	.1463	2.1559
11	1.5546	1.4899	1.6964	.1433	.1494	.1646	2.0399
12	1.5223	1.3763	1.8623		.1829		2.1125
13		1.4089	1.8299	.1311	.1646	.1829	2.1605
14	1.4251	1.4083	1.8138	.1433	.1494	.1829	2.2297
15	1.3927	1.3763	1.7004		.1646	.1829	2.1822
16	.502	1.4548	1.6194	.1612	.1829	.1829	1.9134
17	.1017	.112	.1372	.1646	.1463		.16
18	.1187	.1187	.1715	.1928	.1646	.1991	.1619
19	.1526	.1357	.1543	.1753	.1791	.1991	.1802
20	.1526	.1372	.1372	.1865	.1612	.1791	.1619
21	.1341	.1372	.1357	.1696	.1417	.1791	.1457
22	.1341	.1187	1.3279	1.3603	1.7924	.1612	.128
23	.1006	.1187	1.2029	1.3123	1.6827	.1417	.128
24	.0895	.1006	.1187	2.7435	1.3443	1.4575	.124
Max	1.8656	1.5089	1.8623	2.7435	1.7924	1.7652	2.2297
Min	.0895	.0829	.1006	.1187	.1417	.1417	.1052
Avg	.5272	.5612	.7713	.7108	.6813	.6293	.8021

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 202 / 11 KV TADSAR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0031	.8535	.8916	.1858	.1734	.1738	.9469
2	.9722	.8535	.8269	.1858	.1734	.1593	.9469
3	.8977	.8282	.8002	.1715	.1467	.1635	.9334
4	.9214	.815	.8387	.1715	.1353	.1783	.9202
5	.9362	.8162	.8792	.2143	.1488	.2027	.9469
6	.9362	.9069	.9602	.2572	.2332	.2172	1.2136
7	1.086	1.0883	1.1603	.3001	.2934	.3041	1.3203
8	.2606	.1858	.2332	.3185	.257	.2378	.3041
9	.2229	.2172	.2195	1.467	1.6671	1.6362	.2606
10	.2229	.2201	.2267	1.5556	1.5015	1.5912	.2896
11	.2229	.2195	.2143	1.587	1.5089	1.701	.2494
12	.2229	.2195	.2462	1.6404	1.6638		.2606
13		.2195	.2606	1.6368	1.781	1.7802	.2858
14	.1783	.2534	.2641	1.6004	1.8427	1.7385	.333
15	.208	.2195	.2787		1.8099	1.669	.2896
16	.2347	.2134	.2787	1.4537	1.5638	1.5508	.2526
17	.2347	.2164	.3081	.2534	.2462		.3041
18	.2347	.192	.2787	.1894		.2824	.2751
19	.2787	.2195	.3185	.2705	.2606	.2972	.2606
20	.2462	.192	.2896	.2667	.2378	.2934	.2675
21	.2317	.1734	.2606	.2164	.2378	.2641	.2378
22	.8935	.8935	.2317	.2058	.2027	1.0562	1.1728
23	.8802	.9465	.2027	.2058	.1882	1.0288	1.1294
24	.9846	.8669	.8779	2.21	.1734	.1715	.9604
Max	1.086	1.0883	1.1603	2.21	1.8427	1.7802	1.3203
Min	.1783	.1734	.2027	.1715	.1353	.1593	.2378
Avg	.5439	.4929	.4728	.7202	.7151	.7590	.5984

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 203 / 11 KV YERALA AG

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.639	.5468	.5601	.0848	.1254	.0905	
2	.6154	.5247	.5407	.0678	.1075	.0914	
3	.6554	.4938	.4915	.0671	.128	.0914	
4	.5898	.4938	.5243	.0671	.128	.1097	
5	.5506	.503	.5243	.116	.1086	.1086	
6	.5506	.5639	.5898	.1326	.1612	.1097	
7	.639	.6401	.6882	.1492	.2378	.2195	
8	.1829	.1658	.1696	.1677	.2195	.2012	
9	.1097	.1326	.1433	.7316	1.0322		
10	.1097	.1006	.1463	.679	1.0242		
11	.0905	.0934	.1097	.7186	1.0202		.0678
12	.0905	.0934	.128	.9172	1.065		.0905
13		.0934	.128	.9442	1.0159	.6722	.0914
14	.0905	.0914	.128	.9122	.9878	.7042	.1227
15	.0905	.0914	.128		.9878	.7611	.1227
16	.1086	.1307	.128	.8848	.9831	.7611	.124
17	.1086	.1097	.1448	.0983	.128		.1254
18	.1075	.1307	.1075	.1372	.128	.1029	.1646
19	.1433	.1494	.1417	.1402	.1433	.1372	.1791
20	.1254	.1646	.1417	.1578	.1448	.1372	.1646
21	.1052	.1357	.1227	.1543	.1433	.1372	.1254
22	.5937	.6226	.104	.1402	.1063		.7537
23	.578	.6062	.0857	.1433	.0905		.8029
24	.6154	.5624	.5601	2.2253	.1254	.0905	
Max	.6554	.6401	.6882	2.2253	1.065	.7611	.8029
Min	.0905	.0914	.0857	.0671	.0905	.0905	.0678
Avg	.3256	.3017	.2723	.4277	.4309	.2662	.2258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 204 / 11 KV AMBAK AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0983	.0848	.0655	.8333	.9995	.9069	.0509
2	.0983	.0671	.0492	.8179	.9012	.9175	.0509
3	.081	.0671	.0492	.8025	.852	.9503	.0509
4	.0819	.0671	.0819	.7621	.9175	.9393	.0503
5	.0983	.0663	.0983	.7773	.9175	.9503	.0838
6	.0983	.0829	.096	.823	1.0595	.9503	.1006
7	.0983	.0995	.0819	.884	1.1142	.9717	.0829
8	.0983	.0829	.0819	.0838	.0983	.0791	.0995
9	.9831	.884	1.1984	.0838	.0983	.0791	1.0822
10	1.085	.9259	1.3108	.1017	.0983	.0838	1.1728
11	1.1498	1.0562	1.2146	.08	.1134	.1187	1.2498
12	1.1336	1.0242	1.1822	.096	.1134	.1187	1.2498
13		1.1523	1.1984	.096	.0819	.12	1.2334
14	.9393	1.2289	1.1822	.112	.0949	.104	1.2803
15	1.0526	1.1797	1.166		.0972	.104	1.186
16	1.0202	1.1633	1.1174	.1147	.1147	.1227	1.2003
17	.1029	.0983	.1017	.1311	.0983	.1227	.081
18	.1029	.0983	.0848		.0819	.1052	.081
19	.1029	.0819	.1017	.1147	.0791	.104	.0983
20	.1017	.0819	.1017	.0983	.0791	.0857	.081
21	.1017	.0819	.0838	.0983	.0625	.0857	.081
22	.0848	.081	.8749	1.1043	.9804	.0686	.0655
23	.0848	.0655	.8749	1.1142	.9717	.0678	.0655
24	.0819	.0848	.0655	2.5911	1.065	.9503	.0509
Max	1.1498	1.2289	1.3108	2.5911	1.1142	.9717	1.2803
Min	.081	.0655	.0492	.08	.0625	.0678	.0503
Avg	.3861	.4127	.5193	.5327	.4621	.3794	.4512

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 205 / 11 KV HINGANGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0883	.9061	1.0082	.1509	.1475	.1423	1.0467
2	1.0279	.8642	1.0486	.1341	.1475	.1581	1.0467
3	1.0562	.8488	1.0159	.1326	.1311	.16	1.0185
4	1.012	.8488	.9831	.1326	.1311	.1423	1.0031
5	1.0279	.8383	1.0322	.1492	.1475	.1739	1.0212
6	1.0722	.9145	1.1633	.1989	.1966	.1581	1.1126
7	1.2146	1.1126	1.3435	.2486	.2458	.2056	1.2193
8	.1943	.1823	.1475	.1844	.1802	1.6324	.1823
9	.1638	.1823	.1475	1.5123	1.5203	1.6324	.1823
10	.1658	.1677	.1311	1.6248	1.6804	1.6004	.1677
11	.1844	.16	.1844	1.6804	1.6876	1.5061	.1696
12	.1677	.1638	.1696	1.6356	1.6518	1.6194	.1526
13		.144	.1372	1.6712	1.4899	1.7532	.1526
14	.1341	.1475	.1372	1.6004	1.5238	1.7695	.1526
15	.1357	.1475	.156		1.5402	1.7204	.1677
16	.1372	.1311	.1734	1.4883	1.491	1.5238	.1865
17	.1372	.1296	.1734	.1475	.1638	.1543	.1543
18	.1543	.1475	.1543	.1475	.128	.1715	.1715
19	.1886	.1475	.1886	.1638	.1638	.2058	.208
20	.1886	.1638	.2058	.1966	.1781	.2229	.1715
21	.1696	.1802	.2058	.1802	.1619	.2229	.1543
22	1.0513	1.1305	.1865	.1638	.1802	1.1561	1.1822
23	.9374	1.1043	.1509	.1802	.1638	1.1092	1.1336
24	1.1069	.9374	1.065	3.0864	.1638	.144	1.078
Max	1.2146	1.1305	1.3435	3.0864	1.6876	1.7695	1.2193
Min	.1341	.1296	.1311	.1326	.128	.1423	.1526
Avg	.5529	.4875	.4712	.7309	.6340	.8035	.5515

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244083 / 33/11 KV WANGI SUB-STATION

Feeder No / Name : 206 / 11 KV WANGI GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2835	.3189	.2865	.3012	.2865	.3403	.2481
2	.2507	.3155	.2507	.2804	.2865	.3403	.2454
3	.2507	.298	.2686	.2804	.2507	.2846	.2279
4	.197	.2947	.2686	.2804	.3012	.3366	.2254
5	.2481	.3814	.2865	.3467	.3761	.3898	.3467
6	.5493	.5487	.5014	.5028	.5014	.4656	.4854
7	.6268		.6447	.5721	.5552	.5194	.5316
8	.5194	.4287	.5194	.5258	.4656	.5014	.4334
9	.3582	.3429	.3544	.3681	.3506	.3582	.3506
10	.2865	.3294	.3045	.2835	.3403	.3224	.3189
11	.3403	.3403	.2865	.2507	.3224	.2896	.2865
12	.3403	.3403	.2715	.2507	.2865	.3077	.2686
13		.3045	.2896	.2686	.2865	.3109	.2481
14	.2686	.3045	.2896	.2507	.2865	.3109	.2507
15	.2715	.3012	.3077		.2686	.3109	.2865
16	.3077	.3045	.3109	.2686	.2865	.3292	.3045
17	.3258	.3224	.3292	.3045	.3224	.3258	.2835
18	.3801	.3582	.3982	.3224	.3761	.3258	.3898
19	.5068	.4656	.5068	.5014	.4656	.5068	.5373
20	.5014	.5194	.5194	.5194	.4382	.4477	.4477
21	.4835	.4477	.4656	.4477	.4477	.4298	.4656
22	.4298	.3761	.4252	.4119	.4477	.3761	.3761
23	.3544	.3403	.3366	.3582	.394	.2865	.3224
24	.3189	.3366	.2865	2.0576	.3544	.3544	.2481
Max	.6268	.5487	.6447	2.0576	.5552	.5194	.5373
Min	.197	.2947	.2507	.2507	.2507	.2846	.2254
Avg	.3652	.3617	.3629	.4328	.3624	.3654	.3387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 201 / 11KV BHIKWADI-KH GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.3361	.2402	.2801	.2987	.2587	.3174
2	.2241	.3174	.2218	.2641	.2801	.2427	.3206
3	.2075	.3174	.2149	.2561	.2801	.2402	.3018
4	.2054	.3174	.2614	.2427	.2772	.2957	.3018
5	.2743	.3174	.3547	.2452	.2801	.3734	.3206
6	.4668	.4668	.4251	.5228	.4294	.462	.5281
7	.6036	.6348	.6653	.5975	.5788	.6348	.6348
8	.5228	.5228	.5304	.5601	.5228	.5359	.5847
9	.3772	.3601	.462	.4715	.4668	.5068	.5228
10	.3734	.3511	.4481	.4668	.4066	.4294	.4572
11	.3547	.2054	.3584	.4668	.499	.4024	.4207
12	.2987	.2033	.3547	.4854	.4163	.3921	.4024
13	.2614	.2218	.2829	.4251	.3511	.415	.4435
14	.2054	.2033	.3734	.3696	.3326	.4108	.3881
15	.2957	.2218	.4572	.3696	.4066	.4338	.3881
16	.2743	.2614	.4294	.3696	.4294	.3921	.4066
17	.3292	.2957	.3584	.3696	.3326	.4294	.4066
18	.4066	.3734	.4338	.5175	.3696	.4904	.3511
19	.6099	.5729	.679	.7392	.5175	.6348	.5975
20	.6099	.5914	.6161	.7316	.5914	.6224	.4854
21	.5359	.4668	.547	.567	.5359	.5228	.4854
22	.4108	.4435	.4527	.4668	.4251	.4904	.4435
23	.3734	.3326	.3292	.3734	.3696	.3734	.3696
24	.2241	.3734	.2957	.2829	.2987	.3142	.3395
Max	.6099	.6348	.679	.7392	.5914	.6348	.6348
Min	.2054	.2033	.2149	.2427	.2772	.2402	.3018
Avg	.3613	.3628	.4080	.4350	.404	.4293	.4257

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 202 / 11 KV NEWARI AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.1267	.1109	.7537	.9448	1.406	.0943
2	.0747	.1267	.1097	.7202	.9614	1.3413	.0943
3	.0934	.1267	.1097	.7287	2.6189	1.3672	.0747
4	.0943	.1267	.1267	.7701	.9614	1.4022	.0754
5	.1097	.1267	.128	.7682	.9614	1.406	.0943
6	.1294	.1267	.1448	.8421	.9945	1.4403	.112
7	.1494	.1267	.1646	.9503	1.004	1.4918	.1307
8	.1509	.1267	.1478	.1494	.1629	.1612	.1509
9	1.2944	.9614	1.46	.1494	.181	.1629	2.5724
10	1.3603	1.1603	.1494	.1509	.1629	.1463	2.8346
11	1.2289	1.2574	1.8107	.1478	.1663	.1494	2.7854
12	1.1961	1.2003	1.4746	.1646	.1867	.1509	2.6543
13	1.1797	1.1361	1.166	.1646	.1663	.1494	2.4777
14		1.0288	1.1469	.1663	.1663	.1494	2.4453
15		1.0117	1.166	.1663	.1848	.1509	2.4086
16	.8097	.9816	1.1797	.1478	.2241	.1494	2.17
17	.1457	.1663	.1494	.1663	.1848	.1494	.181
18	.1457	.168	.1509	.1646	.1663	.1886	.181
19	.1457	.1294	.1509	.1646	.1629	.1509	.1646
20	.181	.168	.1494	.1829	.1848	.1867	.1829
21	.1478	.1478	.1509		.1663	.1494	.1829
22	.1463	.1267	.9175	1.0978	1.6289	.1132	.1829
23	.1463	.1478	.8322	1.0442	1.5261	.112	.181
24	.0754	.1463	.1478	.7773	.9231	1.4575	.0943
Max	1.3603	1.2574	1.8107	1.0978	2.6189	1.4918	2.8346
Min	.0747	.1267	.1097	.1478	.1629	.112	.0747
Avg	.4127	.4563	.5519	.4582	.6246	.5722	.9386

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 203 / 11 KV DHANEWADI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5668	.8097	1.2003	.0934	.1448	.1433	1.6518
2	.5668	.7611	1.1317	.0943	.1448	.1448	1.6549
3	.5735	.7611	1.1218	.0943	.1448	.1612	1.6575
4	.5967	.7611	1.1269	.1097	.1829	.1612	1.6766
5	.6371	.7611	1.2269	.1307	.1829	.1578	1.668
6	.6478	.9221	1.262	.2263	.2195	.2033	1.9006
7	.9995	1.0562	1.6448	.2987	.2743	.2587	2.0317
8	.2241	.1886	.2033	.2263	.1829	.2241	.2241
9	.1509	.1629	.1629	2.1765	2.2672	2.6621	.1886
10	.112	.1463	.1494	2.2996	1.7404	2.5263	.1867
11	.1294	.1663	.132	2.4646	.1267	2.5888	.1829
12	.1294	.1663	.1494	2.4863	2.6749	2.4615	.1646
13	.1294	.168	.1132	2.4366	2.9502	2.3758	.1829
14	.1109	.1663	.1463	2.2939	2.9908	2.4615	.1663
15	.1294	.1629	.132	2.1464	2.6406	2.4249	.1629
16	.1294	.1646	.1494	1.9559	2.2977	2.3644	.1448
17	.1663	.1848	.1509	.1448	.1663	.1619	.1646
18	.1663	.168	.1509	.1267	.1663	.2263	.1829
19	.1663	.1663	.1867	.1629	.1867	.2263	.1848
20	.181	.1791	.2241	.181	.1848	.2241	.181
21	.1629	.1629	.1867	.181	.1663	.1886	.181
22	.9774	1.5154	.1494	.1629	.1629	2.2405	2.0388
23		1.3375	.132	.1448	.1612	1.8351	2.0222
24	.583	.905	1.262	.0914	.1448	.1448	1.6842
Max	.9995	1.5154	1.6448	2.4863	2.9908	2.6621	2.0388
Min	.1109	.1463	.1132	.0914	.1267	.1433	.1448
Avg	.3581	.4977	.5206	.8637	.8544	1.1070	.8535

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 204 / 11 KV YETGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4915	.583	.8573	.0943	.0972	.1109	1.0526
2	.0267	.5506	.8413	.0943	.0972	.0895	1.0159
3	.4588	.5506	.8238	.0934	.0972	.0905	.9831
4	.5138	.5506	.8063	.112	.0972	.1086	.9831
5	.4858	.5506		.112	.1296	.1448	1.166
6	.5668	.6154			.1296	.1629	1.3927
7	.7865	.9393	1.2012		.1619	.197	1.5074
8	.1867	.1619	.2172		.1475	.1267	.168
9	.132	.1134	.1294	1.7764	2.0972	1.9547	.1494
10	.112	.081	.0934	2.1052	2.3594	1.8138	.112
11	.0655	.1017	.0943	2.2672	2.1026	1.8187	.081
12	.0819	.0857	.0934	2.1214	1.9719	1.9919	.0819
13	.0819	.0857	.0943	2.0243	2.2291	2.0153	.0648
14	.0819	.0857	.112	1.9433	2.1948	2.0405	.0972
15	.081	.1029	.0943	1.9433	2.0576	1.9334	.1134
16	.081	.0924	.112	1.9757	1.9909	1.8461	.0972
17	.081	.112	.1509	.081	.0924	.0983	.0972
18	.1134	.1109	.132	.0972	.0924	.1132	.0972
19	.1619	.168	.1886	.1457	.1448	.1886	.1296
20	.1619	.1612	.168	.1457	.1848	.1886	.1296
21	.1619	.181	.1698	.1457	.1663	.168	.1457
22	.6478	1.086	.1494	.1475	.1267	1.278	1.3927
23	.6316	.9774	.1132	.1134	.1267	1.1498	1.3765
24	.4858	.583	.9431	.0934	.0972	.1086	1.1142
Max	.7865	1.086	1.2012	2.2672	2.3594	2.0405	1.5074
Min	.0267	.081	.0934	.081	.0924	.0895	.0648
Avg	.2783	.3596	.3448	.8396	.7913	.8224	.5645

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 205 / 11 KV TUPEWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0819	.0972	.1433	.0377	.0324	.037	.4534
2	.081	.0972	.1254	.0377	.0324	.037	.426
3	.0819	.1134	.1267	.0373	.0324	.0373	.4161
4	.0819	.1134	.1433	.0549	.0324	.0362	.4372
5	.081	.1134	.1612	.0554	.0324	.0543	.4481
6	.0848	.1134	.1848	.0747	.0486	.0537	.4696
7	.0972	.0486	.2172	.0747	.0486	.0724	.4915
8	.0373	.0486	.0739	.0373	.0486	.0358	.0747
9	.0377	.0324	.0373	.4424	.5992	.7373	.0566
10	.0373	.0324	.0373	.5121	.6802	.8962	.0747
11	.0373	.0339	.0377	.5182	.6687	.8192	.0934
12	.0373	.0343	.056	.583	.5552	.8288	.0934
13	.0373	.0343	.0566	.583	.5487	.8029	.1097
14	.0373	.0343	.0754	.6154	.5544	.7125	.0724
15	.0373	.0343	.0754	.5801	.6697	.6226	.1086
16	.0373	.0351	.0747	.5506	.591	.5992	.1267
17	.0373	.0554	.0754	.0324	.0537	.056	.1267
18	.0373	.0373	.0754	.0486	.0543	.0566	.0724
19	.056	.0554	.0754	.0486	.0543	.0747	.0648
20	.056	.0537	.0754	.0486	.0543	.0747	.0543
21	.0486	.0543	.0754	.0486	.0554	.0747	
22	.1966	.2229	.056	.0324	.037	.547	.4752
23		.1753	.0373	.0324	.037	.5601	.4588
24	.0983	.0972	.1663	.0377	.0324	.037	.4588
Max	.1966	.2229	.2172	.6154	.6802	.8962	.4915
Min	.0373	.0324	.0373	.0324	.0324	.0358	.0543
Avg	.0633	.0737	.0943	.2135	.2314	.3276	.2462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244115 / 33/11 KV BHIKWADI-KH SUB

STATI

Feeder No / Name : 206 / 11 KV YERALA AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0324	.037	.6554	1.2146	1.3748	.0934
2	.0343	.0324	.0373	.6478	1.1984	1.326	.0943
3	.0377	.0324	.0373	.6226	1.1984	1.3748	.0943
4	.0373	.0324	.037	.6226	1.1984	1.4232	.0943
5	.0566	.0324	.0373	.6401	1.0688	1.4737	.0943
6	.056	.0324	.037	.7287	1.1305	1.5424	.0943
7	.056	.0324	.037	.8192	1.2616	1.595	.0934
8	.056	.0486	.037	.0747	.0655	.0724	.0943
9	.9602	.9393	1.0719	.0747	.081	.0724	2.1136
10	.9717	.9555	1.0486	.0943	.081	.0934	1.749
11	.9717	.9779	1.0688	.0492	.0509	.0914	2.2672
12	.9231	.9945	1.065	.0486	.0857	.0934	2.2024
13	.9665	.9835	1.0526	.0486	.0905	.0754	2.3758
14	.9069	.8916	1.0814	.0486	.0895	.0747	.2267
15	.8259	.823	1.0526	.0486	.0905	.0943	
16	.7125	.8063	.9339	.0486	.1109	.0934	1.9989
17	.0324	.0362	.0377	.0486	.0924	.0934	.0486
18	.0324	.0366	.0754	.0486	.0924	.0943	.0486
19	.0486	.0543	.0934	.0486	.1086	.0754	.0972
20	.0324	.0549	.0754	.0486	.1109	.0934	.1134
21	.0324	.037	.0747	.0486	.0924	.0943	.081
22	.0324	.037	.78	1.2955	1.5947	.0943	.0648
23	.0324	.037	.7209	1.2955	1.5432	.0934	.0648
24	.0377	.0324	.037	.664	1.2308	1.4575	.0934
Max	.9717	.9945	1.0814	1.2955	1.5947	1.595	2.3758
Min	.0324	.0324	.037	.0486	.0509	.0724	.0486
Avg	.3288	.3322	.4403	.3654	.5784	.5403	.6217

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244128 / 33/11 KV Shivani Substation

Feeder No / Name : 201 / 11 KV SHIVANI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2342	1.0957	1.1431	.0495	.0572	.0892	1.5623
2	1.1888	1.0936	1.1279	.0503	.0709	.0838	1.531
3	1.1888	1.1203	1.1279	.0541	.0709	.0772	1.5123
4	1.174	1.0974	1.1279	.0541	.0709	.0781	1.5123
5	1.1443	1.1279	1.1279	.0734	.0827	.08	1.5123
6	1.174	1.1126	1.1888	.0972	.1147	.0937	1.6404
7	1.4784	1.3592	1.439	.1147	.1341	.1187	1.7924
8	.0914	.1054	.0812	.0949	.128	.0914	.0987
9	.0846	.0846	.0629	2.0399	2.372	2.4453	.0581
10	.0697	.0705	.0638	2.2138	2.2405	2.4352	.0697
11	.0674	.061	.0572	2.3045	2.372	2.5926	.0743
12		.0543	.0581	2.5286	2.4806	2.5926	.0686
13	.0709	.0812	.0638	2.4646	2.4486	2.5286	.0629
14	.0663	.0947	.0638	2.4646	2.4006	2.5286	.0629
15	.0754	.0789	.0511	2.234	2.4006	2.4486	.0476
16	.0766	.0903	.0638	2.2725	2.2725	2.4291	.0533
17	.0867	.0823	.0732	.0686	.0766	.072	.0572
18	.06	.0676	.0709	.0652	.0754	.0777	.0648
19	.08	.0753	.088	.0657	.0619	.0857	.0657
20	.0667	.0734	.0705		.0648	.0812	.0753
21	.0823	.0714	.0734	.0676	.0705	.0714	.0789
22	1.1728	1.1888	.0638	.0619	.0724	1.6872	1.8778
23	1.1265	1.1888	.0895	.061	.0667	1.6804	1.8778
24	1.2955	1.0974	1.1736	2.4006	.0572	.0676	1.6484
Max	1.4784	1.3592	1.439	2.5286	2.4806	2.5926	1.8778
Min	.06	.0543	.0511	.0495	.0572	.0676	.0476
Avg	.5720	.5239	.4396	.9522	.8443	1.0223	.7252

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244128 / 33/11 KV Shivani Substation

Feeder No / Name : 202 / 11 KV HANMANTWADIYE AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0924	.1086	1.2651	1.4998	1.828	.0655
2	.0686	.0549	.0914	1.2029	1.4998	1.829	.0671
3	.0693	.0924	.0914		1.4998	1.848	.0838
4	.0693	.0924	.0914	1.142	1.4998	3.7155	.0848
5	.0848	.112	.1097	1.1405	1.5203	1.8298	.0848
6	.1097	.1063	.1294	1.1561	1.5023	1.5684	.104
7	.1294	.1448	.1294	1.2492	1.5813	1.7328	.1086
8	.1075	.124	.1063	.1107	.104	.1267	.1029
9	1.8244	1.7764	1.8724	.0848	.08	.1254	2.17
10	1.8884	1.9433	1.9109	.0838	.0791	.1063	2.3922
11	1.9204	1.8244	1.9919	.0781	.0848	.0838	2.3845
12	1.8564	1.8244	1.9595	.0625	.0848	.0848	2.4291
13	1.8442	1.8084	1.8724	.064	.1075	.1006	2.5749
14	1.7833	1.692	1.8623	.064	.1086	.0848	2.5587
15	1.6762	1.6484	1.8461	.0781	.1097	.0867	2.4806
16	1.5813	1.6842	1.6804	.0819	.1086	.104	2.4086
17	.0903	.0819	.1052	.1029	.1097	.1017	.1227
18	.0949	.0983	.124	.1029	.124	.1052	.1227
19	.104	.1267	.1387	.1294	.124	.0914	.1227
20	.104	.124	.1254	.1109	.1227	.1063	.124
21	.1017	.128	.1254	.1109	.1227	.1063	.1227
22	.0838	.1086	1.3599	1.4685	1.6004	.0829	.0838
23	.0663	.1075	1.2811	1.5623	1.6644	.0655	.0886
24	.0848	.0671	.1086	1.5089	.0937	1.8625	.0648
Max	1.9204	1.9433	1.9919	1.5623	1.6644	3.7155	2.5749
Min	.0663	.0549	.0914	.0625	.0791	.0655	.0648
Avg	.6595	.6610	.8009	.5635	.6430	.7407	.8730

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 244128 / 33/11 KV Shivani Substation

Feeder No / Name : 203 / 11 KV SHIVANI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.4435	.4481	.4481	.4108	.4294	.415
2	.415	.4207	.4527	.4294	.4108	.4066	.415
3	.415	.4024	.4527		.4108	.3921	.415
4	.4527	.4435	.4527	.4108	.4108	.4108	.4527
5	.4715	.4854	.4904	.4435	.5228	.4805	.5093
6	.6722	.6413	.7167	.6602	.5415	.6535	.7167
7	.8962	.8402	.7842	.6468	.7207	.7762	.7282
8	.7095	.6535	.6535	.4435	.695	.695	.6516
9	.5601	.5487	.567	.4477		.6878	.591
10	.499	.6036	.5731	.4298	.6068	.5548	.5609
11	.3801	.5258	.5316	.439	.6344	.6241	.4961
12	.4024	.4207	.5493	.3921	.4784	.5028	.5014
13	.4066	.4938	.567	.4108	.5434	.5434	.499
14	.499	.5068	.543	.4108	.5028	.4835	.4938
15	.4477	.5014	.4344	.4733	.4733	.567	.4755
16	.4805	.5304	.5493	.4805	.4681	.5014	.5194
17	.462	.4572	.6268	.4805	.5548	.4656	.5373
18	.5175	.5487	.567	.4887	.5658	.4908	.6805
19	.7392	.7282	.7964	.6984	.7087	.7499	.7701
20	.7392	.7468	.7133	.695	.7522	.7499	
21	.7468	.7468	.7207	.695	.7316	.7577	
22	.5788	.5975	.5359	.5544	.5544	.6161	.7095
23	.4715	.5041	.4252	.4251	.4294	.4904	.7095
24	.4481	.4668	.4668	1.9052	.3921	.4108	.4527
Max	.8962	.8402	.7964	1.9052	.7522	.7762	.7701
Min	.3801	.4024	.4252	.3921	.3921	.3921	.415
Avg	.5344	.5524	.5674	.5612	.5443	.5600	.5591

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA I S/DN.[082]

BU 6254

Substation No/ Name :- 248018 / 132/33 KV WANGI SUBSTATION

Feeder No / Name : 601 / SONHIRA S.S.K.LTD

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

Feeder KV- 132 / OUTGOING

(NON CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	4.5725
Max	4.5725
Min	4.5725
Avg	4.5725

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA

Feeder No / Name : 201 / 11 KV VITA(U)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	.9526	.9907	1.1431	1.0456	1.105	1.2955
2	.9145	.9526	.9526	1.0288	1.105	1.0669	1.2193
3	.8764	.8764	.9145	.9526	1.0669	1.0288	1.1431
4	.9907	.8383	1.0288	.9145	1.105	1.105	1.0669
5	1.094	.9145	1.1431	1.0669	1.3336	1.1812	1.2193
6	1.1203	1.105	1.2574	1.2574	1.3336	1.2574	1.4098
7	1.448	1.448	1.419	1.5242	1.5623	1.4098	1.5623
8	1.5623	1.6004	1.5623	1.5242	1.5623	1.5242	1.6004
9	1.2955	1.448	1.3717	1.4861	1.5466	1.5844	1.6004
10	1.2193	1.4861	1.448	1.5844	1.6221	1.6385	1.6975
11	1.2193	1.4712	1.6004	1.5844	1.5242	1.5655	1.7551
12	1.1431	1.3014	1.4098	1.4098	1.4098	1.4712	1.6975
13	1.1812	1.3392	1.3717	.724	1.2955	1.4861	1.5844
14	1.1431	1.3908	1.5242	1.448	1.5089	1.6004	1.7353
15	1.1812	1.448	1.5623	1.5466	1.5466	1.6004	1.6975
16	1.1812	1.3527	1.5242	1.448	1.4335	1.5623	1.6598
17	1.1812	1.4901	1.5623	1.5466	1.4712	1.6004	1.6804
18	1.2574	1.448	1.5242	1.5466	1.4335	1.5623	1.6221
19	1.7909	1.7528	1.8671	1.9239	1.8107	1.9052	1.9993
20	1.7528	1.829	1.6766	1.8861	1.8107	1.829	1.9814
21	1.448	1.5242	1.6385	1.5623	1.4335	1.6004	1.6385
22	1.3336	1.4098	1.448	1.448	1.4098	1.4861	1.5623
23	1.1431	1.2574	1.2955	1.3717	1.358	1.4098	1.4098
24	1.0288	.9907	1.105	1.1431	1.1431	1.1812	1.2955
Max	1.7909	1.829	1.8671	1.9239	1.8107	1.9052	1.9993
Min	.8764	.8383	.9145	.724	1.0456	1.0288	1.0669
Avg	1.2274	1.3178	1.3832	1.3780	1.4113	1.4484	1.5472

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA

Feeder No / Name : 202 / 11 KV LENGARE (U)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2894	.7621	.8764	.9526	1.0562	1.1576	1.3336
2	1.2803	.7621	.8383	.9526	1.1203	1.1317	1.2955
3	1.2308	.724	.8002	.8764	1.094	1.105	1.2193
4	1.1431	.724	.8383	.8383	1.0669	1.105	1.1431
5	1.0669	.7621	.8764	.9145	1.105	1.1317	1.2193
6	1.0288	.8764	.9145	.9526	1.105	1.1317	1.2955
7	.9907	.9907	.9907	1.1812	1.2449	1.4563	1.419
8	1.0288	1.2955	.9907	1.448	1.4632	1.5927	1.5565
9	.9145	1.1949	1.4098	1.4998	1.6655	1.6655	1.6655
10	.8764	1.5402	1.39	1.5402	1.8378	1.7337	1.8031
11	.8383	1.6644	1.4685	1.5402	1.848	1.5249	1.8313
12	.8764	1.1949	.9907	1.0288	1.1458	1.3957	1.4632
13	.2667	1.1128	1.0288	1.094	1.2936	1.39	1.4883
14	.2561	1.4506	1.4685	1.5592	1.8313	1.7295	1.8313
15	.2587	1.4175		1.6126	1.6956	1.7337	1.7974
16	.2865	1.4706	1.2125	1.4685	1.4723	1.491	1.5238
17	.9145	1.4022	1.2197	1.5604	1.6617	1.6297	1.5257
18	.8383	1.3169	1.0288	1.3112	1.4175	1.4327	1.448
19	.9145	1.4045	1.1812	1.4998	1.5947	1.5203	1.5927
20	.9145	1.2826	1.0288	1.3676	1.4266	1.1431	1.419
21	.9145	1.1317	.9907	1.0669	1.0562	1.0288	1.1812
22	.8764	1.0669	1.1431	1.2936	1.4266	1.448	1.5203
23	.8002	.9907	1.105	1.2567	1.4118	1.448	1.4784
24	1.2308	.7621	.8764	1.0288	1.0456	1.1949	1.4098
Max	1.2894	1.6644	1.4685	1.6126	1.848	1.7337	1.8313
Min	.2561	.724	.8002	.8383	1.0456	1.0288	1.1431
Avg	.8765	1.1375	1.0725	1.2435	1.3786	1.3884	1.4775

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA

Feeder No / Name : 203 / 11 KV BHALWANI(U)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.5335	.6733	.7164	.7282	.7545	.8596
2	.6661	.4954		.7164	.7545	.7202	.8596
3	.6516	.4954	.6154	.6805	.7282	.7316	.8238
4	.6447	.4572	.695	.6447	.7796	.6805	.788
5	.6805	.5335	.7316	.6805	.788	.7621	.8596
6	.7164	.6097	.7316	.7164	.7964	.7621	.8954
7	.7762	.8002	.7545	.8596	.9145	.8299	.9671
8	.7682	.7682	.815	.9313	.8669	1.0185	.8669
9	.5792	.8322	1.0029	.8718	1.073	1.1317	.9945
10	.4854	.7712	.9175	.9717	1.094	1.094	1.0364
11	.5201	.7373	.8642	.8855	1.1012	1.0688	1.0437
12	.4854	.663	.8192	.8322	.9831	1.0311	.9922
13	.5373	.5895	.7042	.5765	.8288	.8383	.8097
14	.4508	.7099	.8192	.8002	1.0159	.9614	.9602
15	.4656	.7186	.8322	.9069	1.0562	.9614	.6642
16	.4854	.8482	.8002	.9172	.9998	1.073	.8855
17	.4854	.8002	.8962	.9998	1.0623	1.0562	.9061
18	.5014	.7045	.7865	.8539	1.0277	.9831	.7865
19	.695	.823	.9945	.9175	1.0277	1.3077	.9945
20	.695	.9362	.9362	.9724	1.0395	.9389	.9709
21	.6653	.8859	.9015	.9362	.8596	.8238	.8326
22	.6653	.8688	.8954	.9214	.9114	1.0029	.8326
23	.5853	.7796	.7975	.9015	.8573	.9671	.7628
24	.7202	.5121	.7087	.7282	.7975	.7888	.8954
Max	.7762	.9362	1.0029	.9998	1.1012	1.3077	1.0437
Min	.4508	.4572	.6154	.5765	.7282	.6805	.6642
Avg	.6088	.7031	.8127	.8308	.9205	.9287	.8870

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA

Feeder No / Name : 204 / 11 KV PARE (U)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9054	.5716	.8048	1.105	.8951	.9389	1.1431
2	.9054	.5716	.8676	.9877	1.0242	.8848	1.105
3	.8764	.5716	.8383	.8669	.9979	.8619	1.0288
4		.5335	.8413	.8322	.9511	.9259	.924
5	.8779	.6097	.8871	.8669	.9412	.9465	.9979
6	.8916	.6859	.8669	.9709	.9362	1.0242	1.0608
7	.9511	.924	1.1812	1.2136	1.1919	1.2197	1.3523
8	.9877	1.1096	1.2696	1.3253	1.4255	1.3535	1.3443
9	.8688	1.1431	1.3717	1.3306	1.3603	1.39	1.3443
10	.7164	1.1576	1.3169	1.3969	1.4232	1.4685	1.4373
11	.6089	1.2197	1.2894	1.382	1.3927	1.3336	1.4327
12	.6478	.8573	.8002	.9709	.9282	1.1203	.9877
13	.6478	.7701	.9907	.8676	.9069	1.0288	.8642
14	.4191	1.0402	1.1706	1.3279	1.2654	1.3969	1.2498
15	.4572	1.1088	1.2803	1.3413	1.3108	1.3611	1.5947
16	.4191	1.0164	1.1462	1.3108	1.4243	1.2536	1.2437
17	.4954	1.1041	.8413	1.2742	1.3077	1.3253	1.3466
18	.4954	.9997	1.1069	1.2041	1.1584	1.2197	1.2197
19	.9145	1.1694	1.3108	1.3763	1.4403	1.2197	1.3443
20	.8501	1.1812		1.326	1.4091	1.1812	1.2826
21	.7468	1.105	1.0517	1.0631	1.0985	.9907	1.0669
22	.8002	.9907	1.2003	1.153	1.166	1.1812	1.2193
23	.724	.9907	1.0608	1.1469	1.2452	1.2955	1.1431
24	1.0082	.5716	.8383	1.0277	.9945	1.0486	1.1431
Max	1.0082	1.2197	1.3717	1.3969	1.4403	1.4685	1.5947
Min	.4191	.5335	.8002	.8322	.8951	.8619	.8642
Avg	.7485	.9168	1.0580	1.1528	1.1748	1.1654	1.2032

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244006 / 33/11 KV VITA

Feeder No / Name : 403 / 33KV NAGEVADI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6827	1.8267	1.9547	2.0416	2.2085	2.1033	2.8704
2	1.6827	1.7193	1.893	2.0416	1.9982	1.9982	2.7938
3	1.5775	1.6118	1.893	1.8267		1.893	2.6863
4	1.9982	1.6118	2.1033	1.8267	2.1033	1.7878	2.4966
5	2.3137	1.8267	2.3137	2.0416	2.4188	1.9982	2.9127
6	2.6292	2.1948	2.4188	2.364	2.6292	2.524	3.4328
7	1.6827	2.6863	3.0498	2.6863	3.3653	3.0498	3.9335
8	1.4723	1.8267	1.0517	4.1907	1.6827	1.4723	1.7684
9	2.3137	3.1207	3.1207	4.6296	5.7842	5.9945	5.2012
10	2.2885	3.2247	3.1207	5.0412	7.0462	5.9294	3.9232
11	2.0805	3.2247	3.1207	4.8354	7.2817	5.7842	4.0741
12	1.9765	3.3048	2.6578	4.8354	6.6095	5.4092	4.0278
13	2.5789	2.9127	1.8267	5.8894	5.9374		3.4899
14	2.2565	3.0556	3.7609	5.7842	5.487	5.2012	4.225
15	2.1491	2.9424	3.7609	5.7842	5.7133	5.5281	3.4899
16		3.3048	3.5368	5.8894	6.0471	5.6173	2.2028
17	1.0974	2.1091	1.6118	1.7878	1.7878	3.6808	1.1963
18	1.2894	1.6221	1.6644	1.893	2.2085	1.8724	1.2483
19	1.6118	2.3594	2.3388	2.524	1.893	2.1845	2.4977
20	1.6118	2.5857	1.9342	1.7878	2.8395	2.1033	2.1176
21	1.4266	2.4577	1.8461	1.5775	2.6292	1.7684	1.7187
22	1.6118	2.3594	1.7684	2.524	2.4188	2.9127	3.2247
23	1.8267	2.1125	1.9765	2.3137	2.524	3.1207	3.035
24	1.7878	1.8267	2.0119	1.9765	2.2085	2.3137	2.8086
Max	2.6292	3.3048	3.7609	5.8894	7.2817	5.9945	5.2012
Min	1.0974	1.6118	1.0517	1.5775	1.6827	1.4723	1.1963
Avg	1.8672	2.4095	2.3640	3.2538	3.6879	3.3151	2.9740

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/S

Feeder No / Name : 201 / 11 KV ALSAND AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1387	.128	.1265	.1492	1.7814	1.6964	1.2803
2	.1326	.128	.1094	.1492	1.749	1.6644	1.2163
3	.1187	.128	.1094	.1492	1.7004	1.6004	1.2003
4	.1296	.128	.1147	.1492	1.5813	1.5466	1.2003
5	.1296	.1581	.1341	.1658	1.5497	1.531	1.2483
6	.1406	.1581	.1734	.1734	1.5181	1.6091	1.2483
7	.1949	.2172	.1949	.2172	1.7328	1.7166	1.2803
8	.1619	.2058	.1638	.2149	.2303	.2126	.2629
9	2.0243	1.9757		.181	.2149	.0579	1.7695
10	2.0243	2.0972	2.1214	.1791	.2149	.0572	2.5526
11	2.0405	2.2939	2.1376	.1772	.2103	.0503	2.3102
12	2.0081	2.2119	2.1052	.1753	.2454	.0442	2.556
13	1.9433	2.1052	2.1052	.1865	.2481	.0389	2.5888
14	1.9109	2.0485	2.1052	.1865	.2481	.1524	2.5396
15	1.7004	1.9204	2.0891	.2058	.2481	.1898	2.6189
16	1.5844	1.8404	1.9919	.1677	.2658	.2683	2.4741
17	.1658	.1372	.2229		.2835	.2713	.0244
18	.1658	.1402	.2279	.1966	.2774	.2743	.0286
19	.1638	.1578	.2103	.2155	.2454	.2804	.2601
20	.1638	.1696	.2279	.1989	.2103	.2629	.2481
21	.1638	.1696	.1886	.1943	.2103	.2629	.2481
22	.1638	.1526	.1734	1.8084	1.7924	1.3763	.2328
23	.1311	.128	.1543	1.8785	1.7604	1.3123	.2149
24	.1387	2.2939	.128	.1492	1.8623	1.7284	1.3123
Max	2.0405	2.2939	2.1376	1.8785	1.8623	1.7284	2.6189
Min	.1187	.128	.1094	.1492	.2103	.0389	.0244
Avg	.7350	.8789	.7528	.3247	.8492	.7585	1.2882

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/S

Feeder No / Name : 202 / 11 KV BHALWANI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2018	1.0364	1.1248	.7621	.0739	.0724	
2	1.1248	1.0059	1.0936	.6984	.0739	.0724	
3	1.1248	.9755	1.0623	.6539	.0724	.0716	
4	1.0669	.823	1.012	.6308	.0724	.0716	
5	1.0364	.7145	1.012	.6226	.0724	.0716	.0754
6	.9332	.9568	1.0155	.6622	.0724	.0716	.0747
7	1.0623	1.0494	1.0494	.7499	.112	.0754	.0924
8	.1063	.0716	.1886	.0905	.1097	.0732	.0895
9	.0716	.0724	.0895	1.4251	1.9433	1.8244	.0857
10	.0716	.0709	.0905	1.587	1.9109	2.0243	.0895
11	.0709	.0886	.0895	1.7604	1.8785	1.9433	.064
12		.0886	.0895	1.9204	1.8461	1.7924	.0663
13		.0876	.0179	1.8027	1.7924	1.656	.116
14			.0158	1.8343	1.8884	1.5741	.1254
15	.0671		.0171	1.7394	1.6004	1.4632	.1075
16	.0671		.017	1.4842	1.4548	1.3413	.1052
17	.0671		.0156	.0572	.1017	.0781	.1017
18	.0671	.1075	.0678	.0602	.1017	.0983	.1006
19	.0716	.1075	.0876	.1029	.0701	.1052	.1063
20	.0716	.1063	.1097	.1063	.0724	.1075	.0732
21	.0716	.1063	.1086	.1052	.0724	.0905	.0895
22	1.142	.0633	1.0031	.1097	.0739	.0914	1.6057
23	1.1111	1.2498	.9878	.0739	.0739		1.4899
24	1.2651	1.0669	1.1873	.8025	.0739	.0724	
Max	1.2651	1.2498	1.1873	1.9204	1.9433	2.0243	1.6057
Min	.0671	.0633	.0156	.0572	.0701	.0716	.064
Avg	.5653	.4924	.4814	.8267	.6506	.6453	.2452

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/S

Feeder No / Name : 203 / 11 KV KAMLAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7004	1.4548	1.6095	1.3441	.1448	.1791	.1715
2	1.6004	1.406	1.576	1.2967	.1448	.1791	.1734
3	1.5364	1.3748	1.576	1.2651	.1448	.1791	.1734
4	1.3889	1.2643	1.5257	1.2342	.1478	.181	.1753
5	1.358	1.2041	1.5424	1.2342	.1478	.181	.2035
6	1.2963	1.4737	1.6095	1.3123	.1848	.2587	.2347
7	1.6842	1.6518	1.7101	1.4089	.2587	.2957	.3018
8	.2149	.2149	.1677	.2012	.2172	.2126	.3018
9	.181	.181	.1677	1.9826	2.9835	2.7681	.3688
10	.2534	.1677	.1844	2.1628	2.967	2.8502	.3511
11	.2225	.1341	.1991	2.3868	2.8841	3.0178	.3658
12	.2126	.1677	.1991	2.3594	2.8178	3.0514	.3658
13	.1898	.1677	.2587	2.4905	2.7349	2.9447	.3696
14	.1898	.1677	.2353	2.4905	2.5692	3.0514	.3475
15	.2103	.1677	.2321	2.556	2.5692	3.0514	.3511
16	.2103	.1677	.2957	2.2939	2.5526	3.0178	.3881
17	.2103	.1677	.2957	.1543	.2058		.4024
18	.2103	.2012	.2957	.1581	.2058		.3475
19	.2103	.2012	.2587	.2035	.2507	.2347	.2772
20	.2103	.2012	.2587	.2149	.2507	.2347	.2772
21	.2241	.1677	.2587	.2149	.2149	.2347	.2587
22	1.5497	1.7772	1.5203	.1829	.2172	.1677	2.1879
23	1.4998	1.7101	1.5769	.1791	.1791	.1677	2.1548
24	1.7814	1.4842	1.6766	1.3916	.1791	.1791	.1677
Max	1.7814	1.7772	1.7101	2.556	2.9835	3.0514	2.1879
Min	.181	.1341	.1677	.1543	.1448	.1677	.1677
Avg	.7644	.7198	.8013	1.2799	1.0488	1.2108	.4465

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/S

Feeder No / Name : 204 / BHALWANI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1086	.1311	.1147	.128	.104	.1063	.1254
2	.1086	.1311	.116	.1052	.104	.1052	.1267
3	.1086	.1311	.1147	.1029	.1075	.1052	.1294
4	.1075	.1311	.1147	.1029	.1075	.1052	.1109
5	.1075	.1296	.1341	.1187	.1097	.1052	.1097
6	.1433	.1296	.1715	.1448	.1097	.1494	.1463
7	.1848	.1829	.197	.168	.1478	.1494	.1848
8	.1696	.1753	.1886	.1865	.1402	.104	.1715
9	.1063	.1311		.1372	.1619	.1265	.116
10	.0709	.112	.1353	.1219		.1147	.112
11	.0602	.1067	.1029	.0937	.1204	.108	.1054
12	.0602	.1189	.1082	.1036	.0903	.0914	.0753
13	.0602	.1189	.0676	.0695	.0701	.0892	.0753
14		.1014	.096	.0617	.0701	.0846	.0791
15	.0633	.0892	.0753	.0846	.1052	.096	.0829
16	.0633	.0892	.1006	.1353	.1174	.0947	.0791
17	.1174	.125	.1257	.0975	.1113	.3018	.0743
18	.1467	.1341	.1334	.1238	.1113	.1698	.0937
19	.2058	.1715	.1989	.1486	.1715	.208	.1791
20	.2058	.2012	.2204	.1966	.1715	.192	.2328
21	.1715	.1943	.1696	.1898	.1715	.1543	.1433
22	.1402	.1357	.1423	.1433	.1417	.1865	.168
23	.1402	.1147	.1387	.1387	.1417	.124	.1307
24	.1086	.1311	.1147	.128	.1619	.1052	.124
Max	.2058	.2012	.2204	.1966	.1715	.3018	.2328
Min	.0602	.0892	.0676	.0617	.0701	.0846	.0743
Avg	.1200	.1340	.1340	.1263	.1238	.1324	.1240

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/S

Feeder No / Name : 205 / ALSAND / KAMALAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2263	.2427	.2641	.2987	.2641	.2614
2	.2641	.2263	.2427	.2641	.2801	.2641	.2614
3	.2641	.2263	.2427	.2641	.2801	.2614	.2614
4	.2641	.2641	.2926	.2829	.2829	.2957	.2614
5	.2641	.3395	.362	.3584	.2829	.3326	.2926
6	.3772	.4481	.5611	.5281	.415	.4435	.5068
7	.5281	.6722	.6379	.6348	.6722	.6348	.6516
8	.4481	.5359	.543	.5601	.5544	.4805	.543
9	.3696	.4066	.362	.3841	.4024	.4527	.3258
10	.2957	.2896	.2835	.3506	.3658	.3258	.2572
11	.2172	.2896	.2743	.3189	.3544	.3258	.3155
12	.2896	.2534	.2534	.2774	.2957	.3258	.3155
13	.2774	.2561	.2743	.2427	.2957	.3258	.3224
14	.2774	.2561	.2126	.2629	.2957	.3258	.2896
15	.2774	.181	.104	.2427	.2835	.2896	.3189
16	.2481	.1086	.1029	.2401	.2835	.2896	.3189
17		.3258	.3475		.3544	.362	.3641
18	.4024	.362	.3696	.4115	.3898	.4706	.4252
19	.439	.4706	.5121	.4607	.3898	.543	.5121
20	.462	.4706	.5175	.4854	.4435	.5068	.4854
21	.4435	.3982	.4481	.4435	.4066	.4706	.4854
22	.4108	.362	.3772	.3734	.3696	.3982	.415
23	.3018	.2743	.3018	.2987	.2587	.3258	.3395
24	.2641	.2263	.2427	.2641	.2987	.2641	.2614
Max	.5281	.6722	.6379	.6348	.6722	.6348	.6516
Min	.2172	.1086	.1029	.2401	.2587	.2614	.2572
Avg	.3326	.3279	.3378	.3571	.3564	.3741	.3663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/S

Feeder No / Name : 206 / 11 KV Umar Kanchan AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1214	.1067	.1107	.112	2.2348	1.8884	1.6804
2	.1214	.1067	.112	.112	2.2348	1.8564	1.6518
3	.1214	.1067	.0972	.112	2.1605	1.7924	1.6194
4	.12	.1027	.0972	.112	2.1605	1.7394	1.6194
5	.12	.1174	.1296	.112	2.1125	1.692	1.7004
6	.1543	.1848	.1372	.1387	2.1125	1.7236	1.7814
7	.1848	.1848	.1753	.1791	2.1792	1.8023	1.8138
8	.16	.128	.128	.1526	.1886	.1677	.125
9	2.1538	2.1628	2.4453	.1595	.1772	.1475	2.3967
10	2.2672	2.3158	2.4777	.156	.1772	.1235	2.6246
11	2.2672	2.3158	2.5101	.1387	.1402	.128	1.8515
12		2.3967	2.4291	.1543	.1402	.1311	2.3967
13	2.1376	2.2725	2.4453	.1524	.1341	.1341	2.4741
14	2.0729	2.2405	2.2834	.1562	.1341	.1524	2.3158
15	1.9433	2.2138	2.3967	.1562	.1341	.1783	2.3482
16	1.8785	2.1822	2.2834	.16	.1341	.1623	2.3482
17	.2267	.1326	.1204	.1677	.1341	.1783	.1052
18	.2027	.1341	.1526	.1739	.144	.176	.1143
19	.1448	.1372	.1475	.192	.16	.1844	.1509
20	.1423	.1509	.1619	.1739	.1802	.1844	.3258
21	.1265	.1457	.1619	.1524	.1638	.1844	.1696
22	.1311	.1311	.1357	2.3158	1.9524	1.7328	.1417
23	.1311	.1235	.1134	2.2996	1.9204	1.7604	.1254
24	.1214	.1067	.1067	.1134	2.2672	1.9204	1.7124
Max	2.2672	2.3967	2.5101	2.3158	2.2672	1.9204	2.6246
Min	.12	.1027	.0972	.112	.1341	.1235	.1052
Avg	.7413	.8417	.8899	.3272	.9782	.8392	1.3997

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244028 / 33/11 KV ALSAND S/S

Feeder No / Name : 207 / VITA WATER SUPPLY,ALSAND NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1966	.2294	.213	.2321	.1989	.1989	.218
2	.1966	.1966	.213	.2321	.1989	.1989	.218
3	.1966	.1966	.213	.2321	.1989	.1989	.2155
4	.1966	.1966	.213		.1989	.1989	.1989
5	.1966	.128	.213		.1989	.2294	.1989
6	.1966	.128	.213	.2321	.1989	.2347	.2155
7	.2321	.1989	.213	.2321	.2347	.2347	.218
8	.1966	.1966	.213	.2321	.1989	.1989	.2155
9	.2321	.2321	.213	.2321	.2347	.1989	.2155
10	.2321	.2155	.1989	.2347	.2347	.2155	.2347
11	.1989	.2155	.1147	.2267	.2012	.2155	.2321
12	.2321	.2321	.116	.2321	.2012	.2155	
13	.2321	.2294		.2321	.2012	.2155	.2321
14	.2321	.2294	.2321	.2321	.2012	.213	.2321
15	.1989	.2105	.2321	.2321	.2012	.213	.2321
16	.2012	.2105		.2321	.2012	.2105	.2321
17	.1966	.213	.2321	.2294	.1989	.213	.2155
18	.1966	.213	.2321	.2294	.1989	.2155	.2155
19	.1966	.2294	.1311	.1989	.2321	.2321	.2155
20		.2294	.2321	.2294	.2294	.213	.2155
21	.1966	.213	.2321	.1966	.1966	.213	.2155
22	.1966	.213	.2321	.1989	.1989	.213	.2155
23	.2294	.213	.2321	.1989	.1989	.2155	.2321
24		.2294	.213	.2321	.1989	.1989	.2155
Max	.2321	.2321	.2321	.2347	.2347	.2347	.2347
Min	.1966	.128	.1147	.1966	.1966	.1989	.1989
Avg	.2082	.2083	.2067	.2255	.2065	.2127	.2195

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/S

Feeder No / Name : 201 / 11 KV GARDI FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.4374	.4816				.8535
2	.5792	.4218	.4816				.9122
3	.5792	.4218	.4816				.8535
4	.5556	.4641	.4816				.9774
5	.578	.4801	.5182				1.0454
6	.6249	.5121	.5426				.9448
7	.6722	.5601	.5624				1.0111
9				1.1174	1.4089	1.1797	
10				1.2963	1.4255	1.2944	
11				1.3123	1.4419	1.3435	
12				1.3441	1.3763	1.2803	.064
13				1.3603	1.2803	1.3927	.0572
14				1.4091	1.2163	1.2346	.061
15				1.3272	1.2308	1.2631	.061
16				1.2498	1.1012	1.1385	
21		.0434					
22	.506	.4816				.8322	.8421
23	.4744	.4694				.823	.8421
24	.6173	.4531	.4694				.9282
Max	.6722	.5601	.5624	1.4091	1.4419	1.3927	1.0454
Min	.4744	.0434	.4694	1.1174	1.1012	.823	.0572
Avg	.5797	.4314	.5024	1.3021	1.3102	1.1782	.6753

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/S

Feeder No / Name : 202 / 11kv prabhat steel

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0095	.0061	.0061	.0152	.0046	.0091	.0343
2	.0076	.0046	.0061	.0107	.0061	.0091	.0326
3	.0057	.003	.0091	.0076	.0046	.0091	.036
4	.0191	.0046	.0152	.0061	.0046	.0122	.0351
5	.0286	.003	.0229	.0091	.0046	.0152	.0381
6	.0457	.003	.0381	.0103	.0061	.0335	.0351
7	.0095	.003	.0366	.0366	.0061	.0366	.0191
8	.0038	.0023	.0305	.0381	.5228	.0335	.0627
9	.0019	.0686	.2241	.2402	.6413	.6036	.2075
10	.0038	.6348	.8962	.811	.2263	.3395	.2218
11		.3772	.6224	.3961	1.2071	.4294	.2641
12	.0076	.1433	.6413	.3772	.4527	.3467	.2187
13	.0057	.6036		.2263	.3018	.2303	
14	.0076	.2218	1.094	.5658	.1509	.3048	.1886
15	.0076	.7545	.6722	.2263	.3018	.2667	.112
16	.0076	.3018	.3018	.3772	.1448	.2126	.2667
17	.0076	.5281	.8002	.6653	.3018	.0537	.3206
18	.0076	.3018	.2452	.2452	.3734		.2075
19	.0076	.6722	.4338	.3772	.3018	.1294	.3429
20	.0076	.202	.2263	.0076	.961	.4382	.7545
21	.0076	.029	.0114	.0152	.0168	.3563	.1524
22	.0061	.0137	.0114	.0069	.0122	.012	.0198
23	.0061	.0107	.0137	.0069	.0152	.0086	.0152
24	.0114	.0061	.0076	.0198	.0069	.0152	.0057
Max	.0457	.7545	1.094	.811	1.2071	.6036	.7545
Min	.0019	.0023	.0061	.0061	.0046	.0086	.0057
Avg	.0101	.2041	.2768	.1957	.2490	.1698	.1561

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/S

Feeder No / Name : 203 / 11 kv Yetgaon AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1143	.1143	.7716	1.1065	.9602	.1509
2	.0943	.1143	.1143	.7407	1.065	.9602	.156
3	.0943	.1143	.1143	.7186	1.0774	.9488	.1734
4	.1132	.1334	.1143	.7655	1.094	.9488	.1848
5		.1509	.1334	.8381	1.1633	1.0883	.2452
6	.1132	.1886	.1524	1.0562	1.2452	1.1523	.2829
7	.2667	.2641	.2865	1.442	1.5581	1.4419	.3206
8	.2667	.2641	.1509	.2075	.2896	.1524	.3174
9	1.5074	1.4251	1.5912	.1372	.2835	.2286	2.6113
10	1.6385	1.4586	1.5074	.1886	.2286	.2641	2.4813
11	1.6712	1.5912	1.6385	.1494	.1524	.3018	2.649
12	1.6712	1.5729	1.6194	.1886	.1524	.2353	2.3137
13	1.4746	1.4899		.1715	.2263	.2641	2.2211
14	1.4089	1.4586	1.757	.1886	.2263	.2641	2.2377
15	1.2793	1.4586	1.7072	.1905	.2263	.2641	2.2045
16	1.2163	1.3603	1.6194	.2096	.1524	.2452	1.9725
17	.1905	.1524	.1886	.2286	.2263	.2987	
18	.1905	.1494	.2263	.1905	.2263		.2427
19	.2286	.1509	.2477	.2263	.2263	.3018	.3206
20	.2075	.1509	.2263	.2263	.2286	.3018	.3018
21	.1905	.1509	.2263	.2263	.2286	.3018	.3018
22	.1509	.1509	.9014	1.2125	1.0883	.2865	.2641
23	.1509	.112	.9014	1.1069	1.012	.2452	.2263
24	.1132	.132	.1143	.8124	1.1401	1.0242	.1848
Max	1.6712	1.5912	1.757	1.442	1.5581	1.4419	2.649
Min	.0943	.112	.1143	.1372	.1524	.1524	.1509
Avg	.6240	.5962	.6806	.5081	.6093	.5426	.9724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/S

Feeder No / Name : 204 / 11 KV SALSHINGE FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4062	.4572	.1294	.1478	1.1934	1.1506
2		.3795	.4572	.1109	.1294	.0823	1.1694
3		.3795	.4572	.112	.1478	.0823	1.0802
4		.4001	.4001	.1494	.1478	.0823	1.1523
5		.4481	.5144	.1886	.1848	.1143	.9907
6	.5441	.5281	.5548	.2263	.2218	.176	1.1934
7	.9667	.9012	1.0402	.2829	.2587	.1783	1.5257
8	.181	.2321	.1692	.2427	.2218	.1646	.2587
9	.1448	.2218	.1113	1.4582	2.1807	1.704	
10	.1086	.1478	.1006	1.5729	2.1628	1.8442	.1698
11	.1109	.0754	.1829	1.5238	2.079	1.8564	.1629
12	.1109	.0404	.1991	1.5249	1.89	1.7833	.1772
13		.0606	.181	1.7436	2.1879	1.9498	
14		.1128	.2218	1.8442		1.989	.1886
15		.1113	.2054	1.8442	2.0119	2.0553	.1991
16		.1067	.1867	1.7772	1.8991	1.8564	.1629
17	.1109	.0975		.1663	.093	.1791	.1772
18		.0945	.1595	.1848	.0869		.1928
19	.2172	.1623	.2218	.2218	.1646	.3077	.2561
20	.2587	.1646	.2427	.2218	.16	.2195	.2427
21	.2218	.1532	.2033	.2218	.1463	.2195	.2195
22	.4374	.5182	.1867	.1848	.1113	.9555	.8642
23	.4218	.4633	.1494	.1478	.1036	1.0288	.8802
24		.4062	.4572	1.5384	.1478	.1067	1.0924
Max	.9667	.9012	1.0402	1.8442	2.1879	2.0553	1.5257
Min	.1086	.0404	.1006	.1109	.0869	.0823	.1629
Avg	.2950	.2755	.3069	.7341	.7341	.8752	.6139

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/S

Feeder No / Name : 206 / 11 kv salshinge Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1402	.1417	.132	.1402	.1595	.1677
2	.1132	.1402	.1417	.1132	.1402	.1417	.1677
3	.1132	.1402	.1417	.1132	.1402	.1417	.2126
4	.1886	.1578	.1417	.1509	.1578	.1417	.2587
5	.2452	.2103	.1772	.2263	.2103	.1772	.298
6	.3018	.333	.3544	.3206	.333	.2835	.3961
7	.5093	.4557	.4607	.462	.4207	.4252	.4115
8	.3761	.333	.3366	.3189	.3506	.3012	.3395
9	.2658	.298	.2481	.2835		.2658	.2534
10	.2401	.2279	.2481	.2401	.298	.2401	.2126
11	.1753	.2126	.1886	.2103	.2303	.1886	.2058
12	.1928	.2303	.1886	.1753	.2126	.2218	.2155
13	.1772	.1949	.1509	.1578	.1949	.1949	.1886
14	.1402	.2126	.1543	.1753	.2303	.1715	.1886
15	.1402	.1595	.1865	.1578	.1949	.2328	.1886
16		.1595	.116	.1753	.2126	.2263	.2058
17		.2126	.1886	.1753	.2303	.1734	
18	.2454	.1949	.2126	.2629	.2481		.2481
19	.4031	.3366	.3921	.3681	.4075	.3258	.3547
20	.3506	.3366	.415	.3506	.3544	.3961	.3921
21	.298	.3012	.3547	.333	.3189	.3258	.3361
22	.2454	.2658	.2987	.2629	.2658	.3109	.3018
23	.2103	.1772	.2075	.2103	.1772	.2772	.2452
24	.1509	.1753	.1772	.1698	.1753	.1772	.2452
Max	.5093	.4557	.4607	.462	.4207	.4252	.4115
Min	.1132	.1402	.116	.1132	.1402	.1417	.1677
Avg	.2370	.2336	.2343	.2311	.2454	.2391	.2623

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244042 / 33/11 KV NAGEWADI S/S

Feeder No / Name : 207 / 11 kv yetgaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.0739
2							.0739
4							.0686
5				.0739			.1097
6	.0739	.0754	.0739	.0739		.0739	.0924
7	.1109	.1109	.0732	.1075	.1267		.0934
8	.1052	.0895	.0701	.0867	.1063	.0739	.0886
9	.0857	.0709	.0693	.0686	.0701	.0701	.0686
10	.0678	.0848		.0625	.0663	.0686	.0655
11		.0709				.0678	
12						.0686	
13						.0678	
15	.0655		.0663			.0671	
16	.0678					.0663	
17		.0678		.0663	.0663		
18		.0655	.0686	.0678	.0655		.0686
19	.0934	.0724	.0724		.0709	.104	.0905
20	.0747	.0724	.0924	.0732	.1086	.0716	.0924
21	.0754	.0739	.0732	.0739	.0724	.0924	.1097
22				.0739	.0732		.0747
23						.0754	
Max	.1109	.1109	.0924	.1075	.1267	.104	.1097
Min	.0655	.0655	.0663	.0625	.0655	.0663	.0655
Avg	.0820	.0777	.0733	.0753	.0826	.0744	.0836

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV STN LENGRE

Feeder No / Name : 201 / 11 KV Lengare Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.285		.3961	.0762		.0667	.6321
2	.3319		.3763	.0903		.0648	.7407
3	.4001		.3704	.096		.0667	.8436
4	.4512		.3704	.0926		.0743	.9282
5	.5068		.3913	.0743		.0743	.945
6	.4988		.4694	.0937		.0876	.9877
7	.4199		.743	.0914		.0886	1.0155
8	.0781		.0772	.0781		.0892	.096
9		.0457	.0572	.8962		.945	.0633
10	.0442	.061	.0594	.8539	.9922	1.0059	.064
11	.061	.0518		.7968	1.2186	1.1248	.0734
12	.061	.0652		1.0185	1.2803	1.2191	.0983
13	.0617	.061		1.2498	1.3603	1.2811	.1107
14	.061	.0743		1.3283	1.4089	1.2809	.1134
15	.061	.0686		1.2498	.759	1.2809	.0995
16	.0617	.076			.6241	1.1736	.0743
17	.0617	.064		.0791	.0553	.0743	.0789
18	.0625	.0834		.0772	.0533	.064	.0892
19	.0625	.0937		.061	.0823	.0983	.096
20	.0617	.1054		.061	.0823	.0914	.1006
21	.0781	.0949			.0834	.0926	.1017
22	.3788	.4054			.0846	.5247	.5851
23		.4199			.0695	.5418	.5312
24	.3064		.0625	.0625		.0714	.5575
Max	.5068	.4199	.743	1.3283	1.4089	1.2811	1.0155
Min	.0442	.0457	.0572	.061	.0533	.064	.0633
Avg	.1998	.1180	.3067	.4213	.5824	.4784	.3761

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV STN LENGRE

Feeder No / Name : 202 / 11 KV VEJEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549		.0762	.4687		.6173	.0747
2	.0554		.0572	.4877		.6481	.0739
3	.056		.0572	.5441		.7202	.0914
4	.056		.0572	.5247		.9686	.0943
5	.0732		.0762	.5624		.8592	.112
6	.0732		.0943	.6081		.9488	.112
7	.0724		.1463	.6154		.9393	.1132
8	.0914		.1433	.0953		.0924	.1629
9	.6562	.8124	.7499	.0943		.0914	1.491
10	.7164	.6882	.8796	.0747	.061	.0924	1.5684
11	1.065	.6958		.0943	.0617	.1132	1.7939
12	1.0082	.7562		.0762	.0905	.0934	1.6244
13	1.0311	.828		.0926	.0905	.1109	1.5729
14	.8436	.8962		.08	.0914	.0914	1.6575
15	.7716	.8592		.0762	.0739	.0943	1.6244
16	.828	.8333		.1067	.0732	.0934	1.5402
17	.0934	.1017		.0937	.0732	.1109	.104
18	.0924	.1052		.0772	.0739	.0943	.1402
19	.112	.1109		.0983	.0934	.1097	.1097
20	.112	.1054		.0983	.0924	.1109	.0934
21	.112	.128			.0924	.0754	.0934
22	.0914	.112			.6562	.0924	.1132
23		.1109			.6706	.0934	.1132
24	.0554		.4641	1.3765		.6249	.0943
Max	1.065	.8962	.8796	1.3765	.6706	.9686	1.7939
Min	.0549	.1017	.0572	.0747	.061	.0754	.0739
Avg	.3531	.4762	.2547	.3022	.1639	.3286	.6070

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV STN LENGRE

Feeder No / Name : 203 / 11 KV SALSHINGE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487		.602	.1326		.1475	.8124
2	.543		.5556	.1187		.1475	.9282
3	.6241		.5556	.12		.1526	1.0159
4	.7316		.5864	.1341		.1543	1.0242
5	.8535		.6249	.1311		.1772	1.0623
6	.9061		.6622	.144		.1772	1.0802
7	.953		.8333	.1638		.181	1.1363
8	.1475		.16	.1389		.1829	.1402
9	.1204	.1235	.1252	1.2452		1.3123	.1448
10	.1113	.1296	.0869	1.2483	1.4091	1.4251	.1612
11		.1149		1.3279	1.4255	1.3763	.1214
12	.1269	.112		1.2498	1.4575	1.3603	.1337
13	.1303	.1276		1.2963	1.5074	1.3748	.1174
14	.1303	.1372		.128	1.5074	1.3108	.0732
15	.1486	.1412		1.2803	1.4251	1.3443	.0766
16	.1486	.0991		.9602	1.3603	1.2651	.0974
17	.1635	.1278		.144	.1372	.144	
18	.1486	.1488		.1715	.1486	.1696	
19	.1486	.1823		.1907	.1619	.1886	.1402
20	.1656	.1844		.1715	.1802	.2035	.1753
21	.1505	.1865			.1966	.2035	.1753
22	.5716	.6093			.1966	.6859	.7682
23		.5944			.1619	.6874	.7116
24	.5563		.112	.112		.16	.7011
Max	.953	.6093	.8333	1.3279	1.5074	1.4251	1.1363
Min	.1113	.0991	.0869	.112	.1372	.144	.0732
Avg	.3695	.2012	.4458	.5052	.8054	.6055	.4908

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV STN LENGRE

Feeder No / Name : 204 / 11 KV Lengare Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987		.1886	.1753		.1646	.2378
2	.1886		.1715	.2172		.1663	.2218
3	.2218		.1715	.2507		.1715	.2534
4	.2561		.1905	.2743		.2454	.2865
5	.3258		.2263	.3109		.2804	.3155
6	.3696		.3361	.3584		.3224	.3258
7	.3658		.3658	.3801		.3475	.3841
8	.3582		.3045	.3224		.3258	.3155
9	.3121	.2926		.2835		.2835	.2629
10	.285	.2103	.2374	.2149	.2507	.2774	.2454
11	.2058	.2058		.1753	.2534	.2149	.4382
12	.2058	.1696		.1753	.2149	.1753	.2254
13	.2058	.1715		.1753	.2012	.2149	.197
14	.2427	.1612		.1791	.2172	.1886	.181
15	.2058	.1791		.1715	.1991	.1991	.181
16	.2427	.1753		.1715	.1791	.1949	.197
17	.2254	.1715		.208	.1949	.2534	.1949
18	.2058	.2454		.2103	.1928	.2804	.2328
19	.3292	.4066		.3361	.3109	.3361	.2926
20	.3921	.4066		.3772	.362	.3881	.4108
21	.3772	.3921			.3658	.3547	.4108
22	.3292	.3206			.2715	.3018	.3206
23		.2452			.2587	.2534	.2452
24	.3361		.2054	.2054		.2241	.2263
Max	.3921	.4066	.3658	.3801	.3658	.3881	.4382
Min	.1886	.1612	.1715	.1715	.1791	.1646	.181
Avg	.2820	.2502	.2398	.2463	.2480	.2569	.2751

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV STN LENGRE

Feeder No / Name : 205 / 11 KV SALSHINGE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509		.1524			.1509	.1905
2	.1509		.1334			.1509	.2096
3	.1509		.1334			.1509	.2286
4	.1886		.1334			.1509	.2286
5	.2241		.1715			.1698	.2477
6	.2427		.1905			.1867	.2667
7	.2452		.2667			.1867	.2667
8	.2054		.2286			.168	.2667
9	.1509	.1715				.1494	.1905
10	.1132	.1905	.1307	.1905	.1905	.0566	.2096
11	.1715	.168		.2096	.1509	.168	
12	.1715	.132		.1524	.1132	.1698	.168
13	.1905	.1294		.1334	.1132	.168	.1867
14	.1715	.1478			.1132	.132	.1494
15	.1334	.1478		.1524	.1132	.1509	.1494
16	.1334	.1307		.1143	.1132	.132	.1494
17	.2096	.1294		.1524	.132	.1494	.0934
18	.2096	.1663		.1905	.1494	.1905	.168
19	.2286	.2641		.2286	.2241	.2477	.2987
20	.2667	.3174		.2858	.2614	.2829	.2801
21	.2667	.2614			.2801	.3239	.2987
22	.2477	.2452			.2263	.2667	.2641
23		.1698			.1886	.2286	.1698
24	.1494		.1715			.1698	.2096
Max	.2667	.3174	.2667	.2858	.2801	.3239	.2987
Min	.1132	.1294	.1307	.1143	.1132	.0566	.0934
Avg	.1901	.1848	.1712	.1810	.1692	.1792	.2126

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV STN LENGRE

Feeder No / Name : 206 / 11 KV VEJEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698		.1524			.1698	.2667
2	.1698		.1334			.1698	.2667
3	.1698		.1334			.1698	.2858
4	.1867		.1334			.1886	.3048
5	.2241		.1715			.2241	.3048
6	.2614		1.0288			.2614	.3048
7	.2614		.3429			.2801	.3239
8	.2829		.2667			.2614	.2858
9	.2452	.1494				.2241	.2096
10	.2075	.1698	.2934	.2858	.1524	.2241	.1905
11	.2829	.2241		.2667	.1886	.3018	.1334
12	.3395	.2614		.1905	.1867	.3361	.1307
13	.1886	.2241		.1524	.0566	.3206	.1494
14	.1698	.1867		.1524	.2614	.3048	.1494
15	.1886	.168		.1524	.2614	.3429	.1494
16	.2075	.2427		.1524	.2987	.362	.168
17	.2263	.2402		.2286	.2614	.3206	.1867
18	.2263	.2452		.3048	.2054	.3361	.2427
19	.2641	.2477		.3048	.2427	.3584	.3547
20	.2641	.3174		.3239	.2801	.381	.3547
21	.3048	.2829			.2801	.3772	.3326
22	.2477	.2263			.2641	.3048	.2858
23		.1886			.2075	.2667	.2286
24	.1698		.1905			.1698	.2286
Max	.3395	.3174	1.0288	.3239	.2987	.381	.3547
Min	.1698	.1494	.1334	.1524	.0566	.1698	.1307
Avg	.2286	.2250	.2846	.2286	.2248	.2773	.2433

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244069 / 33/11 KV STN LENGRE

Feeder No / Name : 207 / 11KV KANDESARWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566		.0259			.1334	.0566
2	.0566		.0271			.1334	.0566
3	.0566		.0271			.1646	.0566
4	.0566		.0278			.1646	.0566
5	.0566		.0263			.2503	.0566
6	.0566		.0754			.2256	.0566
7	.056		.0693			.2286	.0566
8	.0566		.0316			.0566	.0566
9	.2667	.3111				.0566	.4287
10	.2332	.2195	.2841	.0566	.0566	.0566	.5418
11	.257	.2881		.0566	.0566	.0566	.4365
12	.2705	.3616		.0566	.0566	.0566	.5868
13	.2782	.3666		.0566	.0566	.0566	.5937
14	.2503	.3475		.0566	.0566	.0566	.5144
15	.2435	.3018		.0566	.0566	.0566	.4858
16	.2364	.3338		.0566	.0566	.0566	.4572
17	.0566	.06		.0566	.0566	.0566	.0278
18	.0566	.0657		.0566	.0566	.0566	.0332
19	.0566	.0857		.0566	.0566	.0566	.0671
20	.0566	.0772		.0566	.0566	.0566	.0526
21	.0566	.0772			.0566	.0566	.0532
22	.0566	.0251			.3269	.0566	.0537
23		.0251			.2469	.0566	.0537
24	.0566		.1238		.1238		.0566
Max	.2782	.3666	.2841	.0566	.3269	.2503	.5937
Min	.056	.0251	.0259	.0566	.0566	.0566	.0278
Avg	.1254	.1964	.0718	.0566	.0918	.0959	.2040

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244077 / 33/11 KV KARVE MIDC

Feeder No / Name : 201 / 11 KV TEXTILE PARK

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7625	.3812	.6299	.5636	.5636	.663	.7625
2	.7625	.3481	.5967	.5304	.5636	.6962	.7293
3	.7459	.3315	.5967	.4973	.5967	.7293	.6796
4	.7625	.2984	.5801	.431	.5967	.7293	.6796
5	.6962	.3149	.5801	.4807	.5636	.6962	.7127
6	.6962	.2818	.5801	.5636	.5636	.6962	.663
7	.663	.2818	.5801	.5801	.5967	.7459	.663
8	.663	.3812	.5801	.5967	.5967	.779	.6962
9	.2155	.6796	.6464	.6796	.663	.7127	.6464
10	.2321	.6796	.663	.663	.663	.7127	.663
11	.2486	.6796	.7293	.6962	.663	.7459	.6796
12	.2486	.6796	.6962	.6962	.6464	.6796	.6796
13	.2652	.663	.6464	.7293	.5967	.7127	
14	.1989	.663	.6299	.7293	.5636	.7459	.663
15	.1492	.7127	.6299	.6299	.5801	.7625	.6464
16	.3149	.6962	.6299	.663	.5636	.7956	.663
17	.2818	.663	.6133	.6299	.5967	.7956	.6464
18	.2984	.6962	.6133	.6299	.5636	.7956	.5967
19	.3149	.6464	.6133	.663	.5967	.7459	.5801
20	.3149	.6299	.6133	.6299	.6299	.6962	.5967
21	.3149	.6962	.6299	.5801	.663	.6796	.4973
22	.3647	.663	.6299	.5801	.663	.7459	.5304
23	.4144	.6299	.6299	.6299	.6962	.779	.4973
24	.7293	.3812	.6299	.5636	.6299	.6796	.779
Max	.7625	.7127	.7293	.7293	.6962	.7956	.779
Min	.1492	.2818	.5801	.431	.5636	.663	.4973
Avg	.4441	.5449	.6237	.6098	.6092	.7300	.6500

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244077 / 33/11 KV KARVE MIDC

Feeder No / Name : 202 / 11 KV PARE FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1052	.0762	.0701	.0709	1.0608	.8848	.8025
2	.1086	.0762	.0701	.0716	.9145	.9116	.7727
3	.0995	.0762	.0716	.0716	.884	.9389	.7526
4	.0829	.1143	.0895	.1075	.8592	.8642	.6622
5	.0829	.1132	.0943	.1463	.8802	.8905	.7011
6	.0857	.1132	.1132	.1463	.9831	.9175	.6687
7	.1063	.0754	.1132	.1463	1.0155	.8951	.6836
8	.1052	.0762	.1132	.1063	.0686	.1227	.1372
9	.2027	.5121	.4572	.1402	.0983	.0972	1.1873
10	.2378	.5624		.1052	.116	.0926	1.2811
11	.2968	.5624		.1063	.1147	.088	1.0802
12	.3125	.6173		.1075	.1326	.1372	1.0974
13		.703		.1075	.12	.1341	
14	.192	.7499	.7099		.0995	.1311	1.0957
15	.1718	.884	1.4403	.1029	.1227	.1311	.9682
16	.1562	.8383	1.2811	.1052	.1372	.1296	.8459
17			.096	.1086	.1478	.1341	.0701
18		.0686	.0972	.1075	.1402	.1753	.1029
19		.1132	.1387	.104	.168	.1772	.1433
20		.1509	.1433	.1052	.1646	.1772	.1448
21		.1463	.1417	.1029	.1612	.1387	.1448
22	.0762	.1075	.1433	1.0852	.9259	.7621	.1052
23	.0762	.0876	.1086	.9145	.9339	.8025	.0857
24	.1063	.0762	.0701	.1063	.9831	.9282	.8025
Max	.3125	.884	1.4403	1.0852	1.0608	.9389	1.2811
Min	.0762	.0686	.0701	.0709	.0686	.088	.0701
Avg	.1447	.3000	.2781	.1859	.4680	.4442	.6233

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244077 / 33/11 KV KARVE MIDC

Feeder No / Name : 203 / 11 KV WAZAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5927		1.0059		.0754	.1006	
2	1.5927		.9724		.0754	.0838	
3	1.4251		.8718		.0754	.0838	
4	1.4251		.8383		.0754	.0838	
5	1.4251		.8383		.0754	.0838	
6	1.3077		1.0395		.0754	.1006	
7	1.5089		1.2239		.0754	.1174	
8	.0754		.0671		.0754	.1006	
9	.0671		.0671		1.8442	1.9784	
10	.0838		.0671	1.576	2.1795		
11	.0671			1.6766	2.1795		.0671
12	.0838	.0671	.0754	1.7604	2.1628		.0671
13	.0671	.0671		1.6766	2.1125		
14	.0671	.0671		1.6766	1.8778		.0671
15	.0671	.0671		1.6766	1.8107		.0671
16		.0671		1.6766	1.643		.0671
17		.0838		.0754	.0838		.0671
18		.0671		.0754	.1006		
19				.0754	.1006		.1341
20		.1341		.0754	.1006		.1341
21		.1341		.0754	.1174		.1341
22		1.1736		.0754	.1006		2.0119
23		1.1401		.0754	.1006		1.9784
24	1.6766		1.0898		.0754	.1006	
Max	1.6766	1.1736	1.2239	1.7604	2.1795	1.9784	2.0119
Min	.0671	.0671	.0671	.0754	.0754	.0838	.0671
Avg	.7833	.2789	.6797	.8748	.7164	.2833	.4359

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244077 / 33/11 KV KARVE MIDC

Feeder No / Name : 204 / TEXTILE NO. 2

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132		.0943	.3584	.0943	.2641	.1698
2	.1132		.0754	.3018	.0943	.3018	.1698
3	.0943		.0754	.3206	.0754	.3206	.1698
4			.0754	.2829	.1132	.3206	
5	.0943		.0943	.3018	.0943	.3395	.1886
6	.1132		.1132	.2452	.0943	.3206	
7	.1132		.1132	.1509	.1509	.3018	
8	.0943		.1132		.1509	.3395	
9	.0943		.1509		.1886	.2641	
10	.0943		.1509	.1132	.1886	.3206	
11	.0754		.2829	.1132	.2075	.3018	.1698
12		.1132	.2263	.1132	.2829	.3395	.1509
13	.0943	.1132	.3395	.1132	.2829	.3584	
14	.0943	.1132	.3584	.1132	.2641	.1886	.1509
15	.1132	.1509	.3584	.1509	.3018	.2075	.1698
16		.1886	.3961	.1509	.2829		.1886
17		.1509	.3206	.1509	.3018	.1132	.1509
18		.1509	.2641	.1132	.3395	.1509	.1132
19		.1132	.3018	.1509	.3206	.1509	.1132
20		.1132	.3206	.1132	.3395	.1509	.1132
21		.1132	.3584	.1132	.2829	.1509	.1509
22		.0943	.3018	.1132	.3018	.2075	.1509
23		.0943	.2641	.1132	.3018	.1886	.1132
24	.0943		.0943	.3772	.1132	.2829	.1886
Max	.1132	.1886	.3961	.3772	.3395	.3584	.1886
Min	.0754	.0943	.0754	.1132	.0754	.1132	.1132
Avg	.0997	.1258	.2185	.1852	.2153	.2559	.1542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244078 / 33/11 KV GARDI

Feeder No / Name : 201 / Yashodhan Garment
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3048	.2829	.3361	.3734	.3206	.3429
2	.3018	.3048	.2829	.3395	.3547	.3239	.3429
3	.3018	.3048	.2829	.3142	.3584	.3239	.3429
4	.3018	.3048	.2829	.3174	.3395	.3048	.3429
5	.3018	.3048	.2829	.3109	.3395	.2858	.3429
6	.3395	.3048	.2829	.3395	.3206	.3048	.3584
7	.2829	.3048	.3018	.3206	.3206	.3048	.3584
8	.2452	.2858	.2829	.3361	.3429	.3239	.3584
9	.2263	.3395	.3395	.3584	.3772	.3772	.3584
10	.2263	.3395	.3547	.3584	.3921	.3734	.3395
11	.2263	.3361	.3395	.3734	.3696	.3734	.3547
12	.061	.3584	.3361	.3734	.3734	.3734	.3547
13	.0686	.3174	.3361	.3734	.3395	.3584	.3018
14	.0713	.3361	.3361	.3734	.3395	.3584	.3395
15	.0608	.3361	.3584	.3734	.3772	.3584	.3395
16	.065	.3361	.3395	.3734	.3395	.3584	.3361
17	.0545	.3395	.3174	.3734	.3772	.3584	.3206
18	.0524	.3361	.3395	.3734	.3361	.3429	.3547
19	.0594	.3511	.3395	.3734	.3584	.3206	.3696
20	.2614	.3395	.3547	.3734	.3395	.3206	.3584
21	.2772	.3174	.3395	.3734	.3395	.3395	.3584
22	.2858	.3174	.3395	.3734	.3395	.3395	.3018
23	.2858	.2987	.3174	.3734	.3584	.3429	.2801
24	.3018	.3048	.3018	.3395	.3734	.3395	.3429
Max	.3395	.3584	.3584	.3734	.3921	.3772	.3696
Min	.0524	.2858	.2829	.3109	.3206	.2858	.2801
Avg	.2067	.3218	.3196	.3552	.3533	.3386	.3417

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244078 / 33/11 KV GARDI

Feeder No / Name : 202 / GHANWAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2107	.1486	.1614				.253
2	.2027	.1486	.1614				.2241
3	.2054	.1486	.1614				.2241
4	.208	.1486	.1806				.3239
5	.2027	.1783	.1981				.3887
6	.2812	.3125	.2031		.0754		.5243
7	.3281	.3437	.3887	.0943	.0943		.5407
8		.0724		.0754	.0739	.0625	.0747
9				.421	.4641	.5601	
10				.4641	.5601	.6722	
11				.4902	.6081	.68	
12				.5312	.6009	.6874	
13				.5312	.5401	.7042	.0732
14				.5535	.6093	.7042	.0914
15				.5535	.5937	.7116	.0914
16				.4902	.5556	.6249	.0739
17				.0747			
18				.0934	.0686		
19		.0867	.0739	.0934	.0739		.0716
20	.0739	.0724	.0943	.0934		.0739	.0747
21	.0739	.0716	.0732	.0754			.0747
22	.2006	.1505				.3361	.3734
23	.2035	.1783				.2812	.2846
24	.2134	.1486	.1783				.253
Max	.3281	.3437	.3887	.5535	.6093	.7116	.5407
Min	.0739	.0716	.0732	.0747	.0686	.0625	.0716
Avg	.2003	.1578	.1704	.3090	.3783	.5082	.2231

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244078 / 33/11 KV GARDI

Feeder No / Name : 203 / GHANWAD GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3403	.3224	.4024	.3696	.3658	.3696
2	.3475	.3403	.3224	.362	.3361	.3582	.3734
3	.3439	.3403	.3258	.3881	.3361	.3582	.3361
4	.3366	.3403	.3292	.4108	.3326	.3801	.4066
5	.394	.394	.3982	.4835	.4066	.3982	.499
6	.5487	.543	.5729	.5373	.5121	.499	.5853
7	.6767	.7059	.6767	.6584	.6335	.6219	.6767
8	.6268	.631	.6201	.5611	.567	.5959	.6379
9	.5138	.5201	.4681	.5895	.5201	.6173	.5548
10	.4854	.5087	.4049	.5487	.5316	.547	.4239
11	.463	.4961	.4527	.4641	.503	.502	.4144
12	.3688	.4641	.3768	.3953	.421	.4641	.4424
13	.3681	.1619	.4359	.3887	.4586	.4694	.4024
14	.3521	.4287	.4334	.4024	.4481	.4748	.4239
15	.3391	.4784	.463	.3772	.427	.4694	.4239
16	.3481	.3856	.4409	.407	.4096	.4694	.4191
17	.3561	.3932	.463	.4681	.431	.4917	.4096
18	.4239	.3978	.4359	.567	.3856	.5375	
19	.6379	.5493	.5316	.6447	.591	.567	.6024
20	.6697	.6335	.6516	.6878	.6878	.6805	.724
21	.6335	.5792	.5304	.6401	.5853	.6154	.6878
22	.4755	.5068	.4938	.5304	.4854	.5304	.499
23	.3801	.4024	.4668	.3881	.4066	.4251	.4066
24	.3881	.3403	.3258	.4715	.3696	.3511	.3881
Max	.6767	.7059	.6767	.6878	.6878	.6805	.724
Min	.3366	.1619	.3224	.362	.3326	.3511	.3361
Avg	.4521	.4534	.4559	.4906	.4648	.4912	.4829

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244102 / 33/11 KV pare sub-station

Feeder No / Name : 201 / 11 KV PARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	1.2146
Max	1.2146
Min	1.2146
Avg	1.2146

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244102 / 33/11 KV pare sub-station

Feeder No / Name : 202 / 11 KV PARE AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0572	.0191	.2778	.4218	.3953	.0762
2	.0191	.0572	.0191	.2623	.4161	.3704	.0762
3	.0191	.0572	.0191	.2778	.4111	.3704	.0572
4	.0191	.0953	.0191	.3005	.4218	.4012	.0572
5	.0381	.1143	.0381	.3281	.463	.506	.0762
6	.0381	.1143	.0381	.3549	.5792	.6944	.0953
7	.0381	.1143	.0381	.5693	.8488	.8436	.1143
8	.0381	.1143	.0572	.0381	.0381	.0953	.1143
9	.4531	.4687	.7316	.0381	.0381	.0762	.8768
10	.463	.463	.703	.0381	.0381	.0762	.7468
11	.4725	.463	.6481	.0381	.0381		.9145
12	.5155	.5093	.7499	.0381	.0381	.0953	.8796
13	.5093	.5093	.8025	.0381	.0381	.0953	.8383
14	.4062		.7716	.0381	.0381	.0953	.7316
15	.4475	.6097	.7499	.0381	.0381	.0762	.7316
16	.3906		.7407	.0381	.0572	.0762	.7253
17	.0381	.0381	.0762	.0381	.0953	.0762	.0381
18	.0381	.0191	.0953	.0381	.1143	.1143	.0381
19	.0381	.0191	.1143	.0381	.1143	.1143	.0381
20	.0381	.0381	.1143	.0381	.1334	.1143	.0381
21	.0381	.0381	.0953		.1143	.1143	.0381
22	.0381	.0191	.3593	.4687	.5312	.0953	.0381
23	.0381	.0191	.3086	.463	.5093	.0953	.0381
24	.0191	.0381	.0191	.3086	.4428	.4687	.0762
Max	.5155	.6097	.8025	.5693	.8488	.8436	.9145
Min	.0191	.0191	.0191	.0381	.0381	.0762	.0381
Avg	.1738	.1807	.3053	.1785	.2491	.2374	.3106

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244102 / 33/11 KV pare sub-station

Feeder No / Name : 203 / 11 KV GHOTI (BK) AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0762	.2031	.3239	.2812	.0953
2	.0953	.0762	.0762	.2006	.3041	.2778	.0953
3	.0953	.0762	.0762	.2031	.2968	.2968	.0953
4	.0953	.0953	.0953	.2187	.3321	.3281	.1143
5	.1143	.1143	.1143	.2778	.3593	.463	.1143
6	.1334	.1524	.1524	.3321	.4321	.5468	.1334
7	.1905	.1715	.1905	.4531	.6718	.6642	.1715
8	.2477	.1905	.2096	.2096	.1905	.1715	.1715
9	.3953	.4687	.5312	.1334	.1334	.1334	.7407
10	.3125	.3858	.4938	.0953	.1143	.1143	.578
11	.3353	.4012	.4961	.0762	.0953		.5851
12	.3125	.4167	.4999	.0953	.0953	.0191	.5851
13	.4062	.5144	.5093	.0762	.0762	.0191	.6019
14	.3479		.5155	.0762	.0953	.0191	.6019
15	.4012	.4475	.506	.0762	.0953	.0191	.5944
16	.4111	.4321	.4843	.0953	.0953	.0381	.6249
17	.1334	.1143	.0953	.0953	.0953	.1143	.1143
18	.1143	.1524	.1143	.0953	.1143	.1334	.1334
19	.1905	.1905	.1905	.1715	.1715	.2096	.1905
20	.2286	.1905	.2096	.1905	.2096	.2096	.2096
21	.2096	.1905	.1905		.1905	.1905	.2096
22	.1524	.1334	.2932	.4531	.4843	.1524	.1905
23	.1143	.1143	.2372	.3593	.4763	.1334	.1524
24	.0953	.0953	.0762	.2187	.3321	.3281	.1143
Max	.4111	.5144	.5312	.4531	.6718	.6642	.7407
Min	.0953	.0762	.0762	.0762	.0762	.0191	.0953
Avg	.2178	.2269	.2681	.1916	.2410	.2114	.3007

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244123 / 33/11 kv 5MVA VITA NEW S/STN

Feeder No / Name : 201 / 11 KV Harewadi URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3155	.3077	.3467	.3601	.3688	.3978	.4334
2	.298	.3077	.3149	.3506	.3521	.407	.4031
3	.298	.3077	.3294	.3366	.3561	.4031	.4075
4	.2804	.2896	.3155	.3506	.3391	.3772	.3898
5	.2804	.2896	.298	.3467	.3086	.3814	.4031
6	.2629	.3077	.3045	.3467	.2947	.3988	.4334
7	.2865	.3856	.3353	.39	.3772	.4748	.4973
8	.3391	.3605	.3401	.4144	.4049	.5182	.5344
9	.3561	.4024	.3812	.4424	.5344	.583	.5921
10	.3149	.503	.4534	.4915	.6718	.7045	.639
11	.3944	.547	.4801	.5407	.7459	.7545	.6554
12	.373	.5571	.5121	.6062	.6964	.8288	.6964
13	.4115	.6464	.5218	.5601	.7373	.8619	.7293
14	.4239	.6299	.6081	.6464	.7773	.8192	.7127
15	.4239	.6173	.6401	.7459	.8356	.8029	.7293
16	.4334	.4115	.6802	.7377	.8322	.7935	.6962
17	.4161	.4287	.6316	.7042	.759	.6882	.6299
18	.3812	.4508	.5601	.6325	.6882	.6154	.5967
19	.39	.4801	.5218	.5407	.6316	.5668	.5735
20	.4161	.4961	.4973	.5256	.6464	.5243	.4915
21	.3988	.4681	.4424	.5144	.5426	.4752	.463
22	.3898	.3856	.4144	.4191	.4748	.4801	.4287
23	.3366	.3768	.3978	.4239	.4475	.4917	.3944
24	.3155	.3294	.3521	.3725	.3647	.4359	.4578
Max	.4334	.6464	.6802	.7459	.8356	.8619	.7293
Min	.2629	.2896	.298	.3366	.2947	.3772	.3898
Avg	.3557	.4286	.4450	.4916	.5495	.5743	.5412

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244135 / 33/11 KV BHALAWANI S/STN.

Feeder No / Name : 201 / 11 KV Shelakbav Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2328	.2686	.2149	.197	.2163	.1991	.3403
2	.2149	.2686	.197	.2149	.1985	.1991	.3403
3	.2149	.2507	.197	.2507	.1985	.2172	.3224
4	.2149	.2328	.2149	.2507	.2174	.1991	.3258
5	.2507	.2328	.2328	.2686	.2539	.181	.3439
6	.3045	.3224	.3224	.3224	.3801	.2715	.362
7	.3403	.3761	.394	.3761	.4163	.3801	.3801
8	.3045	.3045	.3761	.3224	.3761	.3439	.3077
9	.2507	.2686	.3045	.3045	.3045	.3077	.2715
10	.2328	.2328	.2686	.3064	.3045	.2896	.2686
11	.2328	.197	.2507	.2884	.2353	.2534	.2686
12	.2149	.2149	.2507	.2695	.2715	.2353	.2507
13	.2149	.197	.2507	.2433	.2715	.2353	.2328
14	.1791	.197	.197	.2331	.2896	.2534	.197
15	.2328	.2149	.2149		.2896	.2715	.197
16	.2328	.2507	.2149	.1985	.2353	.2896	.3142
17	.2149	.2587	.2328	.2165	.2149	.3077	.2686
18	.2686	.2743	.2686	.2698	.2507	.3077	.3761
19	.2865	.3475	.3582	.2875		.3258	.3761
20	.2865	.3696	.3582	.3589	.3403	.3258	.3582
21	.3045	.3224	.197	.3406	.2896	.3258	.3224
22	.2686	.2686	.2686	.323	.2715	.3045	.3045
23	.2686	.2149	.2507	.2333	.2172	.3045	.2686
24	.2328	.2507	.2149	.1791	.2333	.181	.3224
Max	.3403	.3761	.394	.3761	.4163	.3801	.3801
Min	.1791	.197	.197	.1791	.1985	.181	.197
Avg	.2500	.2640	.2604	.2720	.2729	.2712	.3050

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244135 / 33/11 KV BHALAWANI S/STN.

Feeder No / Name : 202 / 11 KV Dhawaleshawar AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0926	.0926	.1088	.0926	.583	.4515	.4666
2	.0926	.0926	.093	.0926	.5087	.4458	.4816
3	.0926	.0926	.093	.108	.4801	.5201	.4816
4	.108	.0926	.1086	.0926	.4801	.602	.4755
5	.108	.108	.1245	.0926	.4801	.6321	.4755
6	.108	.1235	.1549	.1235	.5135	.6321	.4755
7	.108	.1543	.1706	.1389	.6097	.6321	.4755
8	.1389	.0926		.1235	.1235	.1054	.1635
9	.679	.787	.787	.1389	.1189	.0892	.9808
10	1.0031	.8179	.787	.1399	.0892	.104	1.0402
11	1.0185	.7407	.8488	.1401	.0892	.1189	1.0997
12	.9414	.787	.9259	.1396	.0892	.1337	.9957
13	.8333	.787	.9414	.1245	.0892	.1337	.9957
14	.6327	.7562	.9259	.1088	.0892	.1337	.888
15	.5864	.6481	.8796		.1054	.1337	.873
16	.5093	.5401	.6173	.1063	.1204	.1189	.7827
17	.108	.108	.0772	.1063	.0903	.1486	.1054
18	.0926	.109	.0926	.1433	.0903	.1486	.1204
19	.0926	.1245	.108	.1417	.1054	.1337	.1204
20	.108	.1244	.108	.1402	.1204	.1337	.1054
21	.108	.1245	.108	.1402	.1054	.1486	.1054
22	.0926	.1238	.0926	.7362	.6472	.4515	.1054
23	.0926	.1088	.0926	.6219	.5719	.4515	.0903
24	.0926	.0926	.109	.0772	.6415	.3913	.4666
Max	1.0185	.8179	.9414	.7362	.6472	.6321	1.0997
Min	.0926	.0926	.0772	.0772	.0892	.0892	.0903
Avg	.3266	.3179	.3632	.1682	.2892	.2914	.5154

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 244135 / 33/11 KV BHALAWANI S/STN.

Feeder No / Name : 203 / 11 KV Shelakbav AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0517	.9934	.9808	.0518	.0467	.04
2		1.0235	.8916	.8802	.048	.0293	.04
3		1.0254	.9031	.9031	.0493	.0467	.0461
4		.9568	.8916	.9214	.048	.0377	.0461
5		1.0364	.9214	.9934	.0533	.0667	.044
6		1.0715	.9808	1.0402	.0583	.0524	.048
7	.9332	1.0717	1.1589	1.0402	.0842	.0545	.048
8	.0419	.0648	.0427	.0705	.0648	.048	.0793
9	.0524	.0724	.0634	1.5278	1.5741	1.9766	.0686
10		.0669	.0547	1.7985	1.8278	1.9925	.0629
11	.0505	.0625	.0583	1.8212	2.0557	2.0083	.0608
12	.0549	.0579	.0838	1.813	1.9292	2.0241	.0608
13	.0486	.0533	.0713	1.7751	1.8747	1.8519	.0686
14	.056	.04	.0629	1.813	.2968	1.8122	.0617
15	.0857	.0507	.0366		1.8435	1.8364	.0587
16	.1067	.0423	.024	1.5604	1.6872	1.7158	.0671
17	.0686	.0493	.0372	.0396	.0634	.262	.0594
18	.0652	.0533	.0937	.0652	.0591	.1286	.0629
19	.0497	.0549	.0777	.0686	.0572	.061	.0549
20	.0472	.0061	.0671	.0652	.0476	.0572	.048
21	.0457	.0518	.0572	.048	.0446	.0566	.0457
22	1.1728	.7179	1.1888	.048	.0457	.0533	1.5813
23	1.0974	1.0151	1.1888	.0427	.04	.0514	1.5546
24		1.0536	1.0402	1.1888	.0427	.0467	.04
Max	1.1728	1.0717	1.1888	1.8212	2.0557	2.0241	1.5813
Min	.0419	.0061	.024	.0396	.04	.0293	.04
Avg	.2485	.4479	.4579	.8915	.5811	.6799	.1811

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

KOLHAPUR ZONE[050]

SANGLI CIRCLE[520]

VITA DIVISION[523]

VITA II S/DN.[083]

BU 6262

Substation No/ Name :- 248001 / 220/33 Vita Karve

Feeder No / Name : 208 / EHV CONSUMER TEMBHU

SHEDDABLE EHV(AGRICULTURE)

Feeder KV- 220 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	42.867
Max	42.867
Min	42.867
Avg	42.867