

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274035 / 33/11 KV AKLUJ S/STN.

Feeder No / Name : 201 / 11KV MARKET YARD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.4572	.4287	.4572	.4287	.4572	.4287
2	.4287	.4572	.4287	.4572	.4287	.4572	.4287
3	.4287	.4572	.4287	.4572	.5144	.4572	.4287
4	.5144	.4572	.5144	.4572	.6001	.4572	.5144
5	.7716	.6097	.6859	.6097	.8573	.6097	.7716
6	.9431	.7621	.8573	.7621	.9431	.7621	.9431
7	.4287						
8	.4287						
9	.381	.7621	.5144	.6097		.6097	.8573
10	.4572	.6859	.4572	.3429		.4287	.6097
11	.4572	.4287	.6097	.3086		.4287	.4572
12	.4572	.4287	.6097	.3086		.4287	.4572
13	.4572	.4287	.4572	.3086		.4287	.4572
14	.4572	.4287	.4572	.3429		.4287	.4572
15	.4572	.4287	.4572	.2572		.4287	.4572
16	.4572	.4287	.4572	.3429		.4287	.4572
17	.4572	.4287	.4572	.3429		.4287	.4572
18	.4572	.4287	.6097	.3429	.381	.4287	.4572
19	.6097	.5144	.7621	.6859	.7621	.6001	.6097
20	.7621	.8573	.7621	.9431	.7621	.8573	.7621
21	.7621	.8573	.7621	***	.7621	.8573	.7621
22	.7621	.8573	.7621		.6859	.8573	.6859
23	.5335	.4287	.4572	.5144	.6097	.5144	.6097
24	.4287	.4572	.4287	.4572	.4287	.4572	.4287
Max	.9431	.8573	.8573	85.734	.9431	.8573	.9431
Min	.381	.4287	.4287	.2572	.381	.4287	.4287
Avg	.5303	.5477	.5620	4.5258	.6280	.5369	.5681

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274035 / 33/11 KV AKLUJ S/STN.

Feeder No / Name : 202 / 11KV AKLUJ URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.7621	.8573	.7621	.8573	.7621	.8573
2	.8573	.7621	.8573	.7621	.8573	.7621	.8573
3	.7716	.7621	.7716	.7621	.7716	.7621	.7716
4	.8573	.7621	.8573	.7621	.8573	.7621	.8573
5	1.0288	.7621	.9431	.9145	.9431	.8383	.9431
6	1.1145	.9145	1.0288	.9907	1.1145	.9145	
7	.6859						
8	.5144						
9	.7621	.9907	1.0288	.9145	1.1145	.9145	1.1145
10	.7621	1.0288	.9145	.9431		.9431	.9145
11	.7621	.9431	.8383	.9088		1.0288	.8383
12	.7621	1.0288	.8383	.8916		1.0288	.8383
13	.7621	.9431	.8383	.9431		1.0288	.8383
14	.7621	.9431	.8383	.9088		.9431	.8383
15	.7621	.9431	.8383	.8573		.9431	.8383
16	.7621	.9431	.8383	.8916		.8573	.8383
17	.7621	.9431	.8383	.9431		.8573	.8383
18	.7621	1.0288	.9145	1.0288	.9145	.9431	.8383
19	.9145	1.2003	1.0669	1.1145	1.1431	1.0288	.9907
20	.9907	1.2003	1.0669	1.286	1.1431	1.1145	1.0669
21	.9907	1.1145	1.0669	1.2003	1.0669	1.1145	1.0669
22	.9145	1.1145	1.0669		.9145	1.1145	.9145
23	.8383	.9431	.8383	1.0288	.8383	.9431	.8383
24	.9431	.7621	.8573	.7621	.8916	.7621	.8573
Max	1.1145	1.2003	1.0669	1.286	1.1431	1.1145	1.1145
Min	.5144	.7621	.7716	.7621	.7716	.7621	.7716
Avg	.8292	.9453	.9093	.9322	.9591	.9258	.8932

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274035 / 33/11 KV AKLUJ S/STN.

Feeder No / Name : 203 / 11KV DIVISION

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.4572	.5144	.4572	.5144	.4572	.5144
2	.5144	.4572	.5144	.4572	.4287	.4572	.5144
3	.5144	.4572	.5144	.4572	.4287	.4572	.6001
4	.6859	.4572	.6859	.4572	.7716	.4572	.6859
5	.7716	.6097	***	.6097	.8573	.6097	.7716
6	.8573	.7621	.8573	.7621	***	.7621	.8573
7	.4287						
8	.4287						
9	.381		.8573	.7621	.8573	.7621	.8573
10	.4572	.8573	.7621	.8573		.8573	.7621
11	.6097	.9431	.7621	.8573		.9431	.7621
12	.6097	.8916	.7621	.8573		.8573	.7621
13	.6097	.8573	.7621	.8573		.8573	.7621
14	.6097	.8573	.7621	.8573		.8573	.7621
15	.6097	.8573	.7621	.8573		.7716	.7621
16	.6097		.7621	***		.8573	.7621
17	.6097	1.0288	.7621	.8573		.8573	.7621
18	.6097		.8383	.8573	.7621	.8573	.7621
19	.7621	1.0631	.9145	.9431	.9145	.9431	.9145
20	.7621	1.1145	.9145	1.0288	.9145	.9774	.9145
21	.7621	1.0288	.9145	.9431	.9145	.8573	.9145
22	.7621	.8573	.9145		.7621	.8573	.7621
23	.6097	.8573	.6097	.6859	.6097	.8573	.6097
24	.6001	.5335	.5144	.4572	.5144	.4572	.5144
Max	.8573	1.1145	85.734	85.734	85.734	.9774	.9145
Min	.381	.4572	.5144	.4572	.4287	.4572	.5144
Avg	.6121	.7867	4.6089	4.7911	6.7846	.7558	.7404

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274035 / 33/11 KV AKLUJ S/STN.

Feeder No / Name : 204 / 11KV BAGEWADI PURE AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.9907
Max	.9907
Min	.9907
Avg	.9907

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274035 / 33/11 KV AKLUJ S/STN.

Feeder No / Name : 205 / 11KV ANANDNAGAR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.1219
Max	.1219
Min	.1219
Avg	.1219

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274035 / 33/11 KV AKLUJ S/STN.

Feeder No / Name : 206 / 11 KV MIDC

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.1524	.2401	.1524		.1524	.1715
2	.2058	.1524	.2401	.1524		.1524	.1715
3	.1715	.1524	.2058	.1524		.1524	.2058
4	.1715	.1524	.2058	.1524		.1524	.2401
5	.2058	.1524	.2401	.1524		.1524	.2401
6	.2401	.1524	.2401	.1524		.1524	.3429
7	.2058						
8	.2058						
9	.2134	.2134	.2058	.1524	.1715	.1524	.1715
10	.2286	.2058	.2286	.2401		.5487	.2286
11	.2286	.2058	.2286	.2401		.5487	.2286
12	.3048	.2058	.2286	.2401		.4115	.2286
13	.3048	.2058	.2286	.2743		.5487	.3048
14	.3048	.2058	.2286	.2401		.5487	.3048
15	.3048	.2058	.2286	.2401		.5487	.3048
16	.2286	.2058	.2743	.2401		.5487	.3048
17	.3048	.1715	.2286	.2058		.5487	.3048
18	.3048	.3429	.2286	.2058	.1219	.1715	.3048
19	.3048	.3429	.1524	.3429	.1524	.3429	
20	.2286	.3429	.1524	.3429	.1524	.3429	.3048
21	.2286	***	.1524	.1715	.1524	.3429	.3048
22	.1524	.1715	.1524		.1524	.1715	.2286
23	.1524	.2058	.1524	.2058	.1524	***	.2286
24	.3944	.1524	.2401	.1524	.2058	.1524	.1715
Max	.3944	17.1468	.2743	.3429	.2058	17.1468	.3429
Min	.1524	.1524	.1524	.1524	.1219	.1524	.1715
Avg	.2417	.9748	.2129	.2099	.1577	1.0905	.2522

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274035 / 33/11 KV AKLUJ S/STN.

Feeder No / Name : 207 / DR INAMDAR NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0335	.0394	.0335	.0377	.0335	.0377
2	.036	.0305	.0377	.0335	.036	.0305	.036
3	.0343	.0305	.036	.0305	.036	.0305	.0343
4	.0326	.0305	.0326	.0305	.0343	.0305	.0326
5	.0309	.0305	.0309	.0305	.0326	.0305	.0309
6	.0291	.0335	.0326	.0305	.0291	.0305	.0257
7	.0394	.0305	.0326	.0305	.0377	.0274	.0412
8	.0326	.0305	.0394	.0305	.036	.0274	.0394
9	.0198	.0305	.0617	.0274	.0291	.0274	.0377
10	.0457	.0703	.0488	.0463		.036	.0533
11	.0457	.0737	.0457	.0429		.0394	.0686
12	.064	.0669	.0457	.048		.0514	.0686
13	.0686	.0532	.0579	.0669		.048	.0686
14	.0701	.0737	.0533	.0412		.048	.0732
15	.0701	.0703	.061	.048		.036	.0732
16	.0732	.0634	.064	.0652		.0532	.0686
17	.061	.072	.0579	.0532		.0549	.0686
18	.061	.0652	.0549	.0583	.0427	.0652	.061
19	.0549	.0652	.0457	.0532	.0427	.06	.0579
20	.0488	.0566	.0457	.0549	.0427	.0377	.0549
21	.0488	.0514	.0457	.0429	.0396	.0514	.0549
22	.0396	.0412	.0457	.0497	.0396	.0429	.0457
23	.0381	.048	.0396	.0394	.0396	.0497	.0457
24	.0343	.0335	.0412	.0335	.0377	.0366	.0377
Max	.0732	.0737	.064	.0669	.0427	.0652	.0732
Min	.0198	.0305	.0309	.0274	.0291	.0274	.0257
Avg	.0465	.0494	.0457	.0425	.0371	.0408	.0507

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274037 / 33/11 KV LAWANG S/STN

Feeder No / Name : 201 / 11 KV WAGHOLI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1265		1.4232	1.6289	1.5813	.1638	.1372
2	.1265		1.4232	1.6289	1.5813	.1638	.1372
3	.1265		1.4232	1.6289	1.6604	.1311	.1372
4	.1581		1.5023	1.6289	1.6604	.1311	.1372
5	.1581		1.5813	1.6289	1.7185	.1638	.1372
6	.1898		1.6604	1.8004	1.7185	.1966	.2058
7	.1581		1.8976	1.8861	1.8747	.1966	.1715
8	.1581		1.9766	1.9719	1.8747	.1311	.1715
9	2.2138		.1265	.1372	.125	2.2929	1.9719
10	2.4006	.1052	.1402	.1311	.1402	2.2653	2.451
11	2.5606	.1402	.1402		.1402	2.3434	2.5301
12	2.5606	.1402	.1402	.1147	.1372	2.2653	2.5301
13	2.4806	.1448	.1402	.1311	.1402	2.2653	2.372
14	2.4006	.1402	.1402	.1311	.1402	2.1872	2.372
15	2.4006	.1402	.1578	.1147	.1402	2.3434	2.372
16	2.4006	.1402		.1311	.1402	2.3434	2.2929
17	.16	.1402		.1326			.1357
18	.1581	.1326	.1753		.1326		.1581
19	.1265	.1658	.2103	.1581	.1326	.1715	.1581
20		.1638	.2103	.1581	.1658	.1753	.1581
21		.1311	.2103	.1581	.1658	.1753	.1581
22		.1311	.1753	.1581	.1326	.1753	.1581
23		1.4232	1.6289	1.5813	.1658	.1433	.1562
24	.1265		1.4232	1.6289	1.5813	.1989	.1372
Max	2.5606	1.4232	1.9766	1.9719	1.8747	2.3434	2.5301
Min	.1265	.1052	.1265	.1147	.125	.1311	.1357
Avg	1.0595	.2313	.8139	.8486	.7500	.9374	.8894



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274037 / 33/11 KV LAWANG S/STN

Feeder No / Name : 202 / 11KV SANGAM-Lawang- FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1619	1.5623	1.5813	1.6289	1.8023	.1989	.2172
2	.1619	1.6194	1.5813	1.6289	1.7204	.1989	.2172
3	.1619	1.7004	1.6604	1.6289	1.7204	.1989	.2172
4	.1943	1.7004	1.6604	1.6289	1.6385	.1989	.181
5	.2267	1.7814	1.6604	1.6289	1.7004	.2321	.2172
6	.2267	1.7814	1.7394	1.7147	1.6194	.2321	.2534
7	.1943	1.9433	1.8185	1.9719	2.0481	.1989	.2534
8	.1943	1.9433	1.9766	1.9719	2.1862	.1989	.2172
9	2.672	.1296	.1638	.1402	.1296	2.2138	2.3148
10	2.6882	.1402	.1638	.1326	.2103	2.5911	2.5301
11	2.6882	.1052	.1581		.2103	2.5911	2.6882
12	2.6882	.1052	.1638	.1326	.2103	2.5911	2.6882
13	2.6092	.1052	.1638	.1326	.2103	2.4291	2.6882
14	2.5301	.1052	.1638	.1326	.2103	2.4291	2.6882
15	2.372	.1402	.1966	.1658	.2103	2.5101	2.5301
16	2.2138	.1402		.1658	.2103	2.5911	2.451
17	.1581	.1402		.1989			.1696
18	.1658	.1658	.1753		.1989		.1677
19	.1658	.1658	.1753	.1966	.1989	.2279	.1677
20	.1989	.1658	.2103	.2507	.2486	.2454	.2012
21	.1989	.1326	.2103	.2294	.2486	.2454	.2012
22	.1658	.1326	.2103	.1966	.2486	.2454	.1677
23	1.5746	1.6804	1.6289	1.7814	.1989	.2103	.1658
24	.1619	1.6194	1.5813	1.6289	1.8023	.1989	.2172
Max	2.6882	1.9433	1.9766	1.9719	2.1862	2.5911	2.6882
Min	.1581	.1052	.1581	.1326	.1296	.1989	.1658
Avg	1.0322	.8002	.8656	.8767	.8340	1.0444	.9921

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274037 / 33/11 KV LAWANG S/STN

Feeder No / Name : 203 / 11 KV LAWANG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0243	.1006	.116			1.6604	
2	2.0243	.1006	.116			1.6604	
3	2.0243	.1006	.1326			1.6604	
4	2.1052	.1677	.1326			1.7394	
5	2.1052	.1677	.1326			1.7394	
6	2.1052	.2012	.1658			1.8185	
7	2.4291	.1677	.1658			1.8976	
8	2.4291	.1677	.1492			1.9766	
9	.1619	2.1795	1.7394			.0995	
10	.1326	2.1795	2.1338	1.7711			.1658
11	.116	2.0957	2.431	1.8185			.1658
12	.116	2.0119	2.3472	1.8185			.1658
13	.1326	1.9281	2.2634	1.8185			.1492
14	.1326	1.8442	2.1795	1.8976			.1492
15	.1326	1.9281		1.9766			.1492
16	.1326	1.9281		1.8976			.1658
17	.1492			.1326			.1658
18	.1715	.1326	.1006		.1658		
19	.1677	.1492	.1677		.1658		
20	.1677	.1492	.2012		.1658		
21	.1677	.1492	.2012		.1326		
22	.1677	.1492	.1677		.116		
23	.1006	.116	.1341		1.6604		
24	.5182	.1006	.116			1.6604	
Max	2.4291	2.1795	2.431	1.9766	1.6604	1.9766	.1658
Min	.1006	.1006	.1006	.1326	.116	.0995	.1492
Avg	.8297	.7920	.7283	1.6414	.4011	1.5913	.1596

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274037 / 33/11 KV LAWANG S/STN

Feeder No / Name : 204 / GAOTHAN (LAWANG)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4207	.4298	.4458	.4477	.4207	.3772	.394
2	.4207	.4298	.4458	.4477	.4207	.3772	.394
3	.4382	.4298	.463	.4477	.4557	.3944	.394
4	.4908	.5014	.4801	.4477	.4908	.4287	.394
5	.5959	.6089	.583	.5014	.5548	.5487	.4656
6	.631	.6805	.5487	.6805	.5895	.5487	.5959
7	.4908	.5731	.5487	.5731	.4908	.5487	.5731
8	.4557	.5258	.4801	.4656	.4557	.4801	.4835
9	.3988	.3856	.4115	.394	.4207	.3772	.3582
10	.3429	.394	.3506	.3429	.3761	.3467	.3429
11	.3086	.394	.3155		.3582	.3467	.3429
12	.2915	.3582	.333	.2743	.3155	.3467	.3086
13	.2915	.2865	.3155	.2743	.3224	.3467	.3086
14	.2743	.2686	.3506	.2743	.2865	.3467	.2915
15	.2743	.2804	.3506	.2743	.2865	.3506	.2915
16	.2915	.3224		.3086	.2865	.3155	.3086
17	.3429			.3772			.2743
18		.4801	.4656		.3772		.3292
19	.5194	.5144	.6447	.5373	.4801	.4835	.439
20	.5731	.5144	.6805	.5731	.5144	.5014	.4755
21	.5373	.4801	.6089	.5731	.5144	.5014	.439
22	.5014	.463	.4477	.4656	.463	.4656	.4024
23	.4656	.4458	.4477	.4382	.4115	.4298	.4298
24	.4207	.4298	.4458	.4477	.4207	.3772	.394
Max	.631	.6805	.6805	.6805	.5895	.5487	.5959
Min	.2743	.2686	.3155	.2743	.2865	.3155	.2743
Avg	.4251	.4433	.4620	.4348	.4223	.4200	.3929

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274037 / 33/11 KV LAWANG S/STN

Feeder No / Name : 205 / J K SANGAM

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0119	.1006	.0983	.1402	.1326	1.7029	1.9719
2	2.0622	.1006	.0983	.1402	.1326	1.7029	1.9719
3	2.0287	.0972	.0983	.1402	.1326	1.6872	1.9719
4	2.079	.1341	.0983	.1402	.1492	1.7711	1.8861
5	2.1293	.1677	.1147	.1402	.1492	1.8818	1.8861
6	2.0405	.1677	.1638	.2103	.1658	2.0083	2.1434
7	2.2119	.1677	.1311	.1753	.1326	2.1032	2.3148
8	2.3266	.1341	.1311	.1753	.1326	2.0557	2.3663
9	.0983	2.0454	2.0005	1.8861	2.2045	.0983	.1753
10	.0983	2.2291	2.2634	1.7711	2.5415	.0995	.1311
11	.0819	2.2291	2.3807	1.9528	2.4863	.0995	.0983
12	.0819	2.2291	2.4646	1.906	2.4863	.0995	.0983
13	.0819	2.0576	2.5819	1.7966	2.4348	.116	.0983
14	.0819	1.8861	2.364	1.7966	2.4006	.116	.0983
15	.0819	2.0233	2.146	1.9528	2.4006	.116	.0819
16	.0819	2.0576		1.8903	2.4539	.116	.0983
17	.0983	.1402		.1658			.1017
18	.0995	.1326	.1402	.1326	.1326		.1341
19	.1006	.1326	.1402	.1658	.1326	.1753	.1509
20	.1341	.1326	.1753	.1658	.1658	.1753	.1677
21	.1341	.116	.1753	.1658	.1658	.1753	.1677
22	.1341	.116	.1402	.1326	.1326	.1753	.1341
23	.1006	.0995	.1402	.1326	1.6604	1.9376	1.5927
24	2.0119	.1006	.0983	.1402	.1326	1.6872	1.9719
Max	2.3266	2.2291	2.5819	1.9528	2.5415	2.1032	2.3663
Min	.0819	.0972	.0983	.1326	.1326	.0983	.0819
Avg	.8496	.7832	.8248	.7256	1.0025	.9136	.9089

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274037 / 33/11 KV LAWANG S/STN

Feeder No / Name : 206 / Vajrai

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2809		.1147	.1296	.1235	2.0005	1.6518
2	2.2809		.1147	.1296	.1235	1.9204	1.6518
3	2.3278		.0983	.1296	.1235	1.8884	1.668
4	2.4059		.1147	.1296	.1389	1.8724	1.7166
5	2.5465		.1311	.1457	.1389	1.9044	1.7814
6	2.5934		.1311	.1619	.1235	1.9204	1.8623
7	2.5152		.1311	.1296	.108	1.9524	2.0567
8	2.4215		.1311	.1296	.108		2.0243
9	.1094		1.4883	1.6194	1.8982		.081
10	.0819	1.5708	1.7328	1.6716	2.2996		.1147
11	.0819	1.749	1.7976	1.7236	2.4863		
12	.0983	1.7976	1.8623	1.5339	2.5892		.0819
13	.0983	1.7652	1.8947	1.5023	2.6235		.0819
14	.0819	1.7772	1.8138	1.5023	2.5263		.0819
15	.0819	1.6518	1.7976	1.5813	2.5425	.0772	.0983
16	.0819	1.6194		1.6604	2.4939	.0617	.0983
17	.1147			.116			.1357
18		.1311	.0972	.108	.1326		.1543
19		.1311	.1134	.1235	.1492	.1134	.1543
20		.1475	.1457	.1235	.1492	.1296	.1543
21		.1475	.1457	.1235	.1492	.1296	.1543
22		.1475	.1296	.1389	.1492	.1296	.1389
23		.1147	.1296	.1389	1.9524	1.6194	1.7284
24	2.2965		.1147	.1296	.1235	2.0005	1.6842
Max	2.5934	1.7976	1.8947	1.7236	2.6235	2.0005	2.0567
Min	.0819	.1147	.0972	.108	.108	.0617	.081
Avg	1.2499	.9808	.6468	.6201	1.0110	1.1813	.8415

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274037 / 33/11 KV LAWANG S/STN

Feeder No / Name : 207 / 11 KV CANAL AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	1.8004	1.6324	1.8861	1.9719	.4915	.5144
2	.5144	1.8176	1.6324	1.9033	1.989	.4915	.5144
3	.5316	1.8861	1.6804	1.9033	2.0576	.4915	.5144
4	.5316	1.9033	1.6804	1.9204	2.0517	.4915	.5144
5	.5487	1.9719	1.7604	1.9547	2.1365	.5243	.5316
6	.583	1.989	1.8244	2.1262	2.1704	.5243	.5316
7	.5144	2.0576	1.9524	2.332	2.2891	.5243	.5316
8	.4748	2.0748	1.9524	2.2977	2.34	.4915	.5144
9	2.2891	.4458	.4588	.4801	.4748	2.3045	2.7092
10	2.4326	.4458	.4458	.4424	.4458	2.73	2.6724
11	2.7686	.4458	.4458		.4458	2.7978	2.7357
12	2.6726	.4458	.4458	.426	.4458	2.713	2.7357
13	2.5766	.4458	.4458	.426	.4458	2.8317	2.7199
14	2.4806	.463	.4458	.426	.4458	2.8487	2.7041
15	2.4166	.463	.4458	.426	.4287	2.8656	2.6408
16	2.2725	.463		.426	.4287	2.7639	2.625
17	.4424	.4801		.4475			.4578
18	.4917	.4752	.4801		.4641		.4917
19	.4917	.4915	.4801	.4973	.4807	.5144	.4917
20	.4917	.4915	.5144	.5144	.4973	.5144	.5087
21	.5256	.4915	.5144	.5144	.4973	.5144	.4917
22	.5256	.4915	.5144	.5144	.4973	.5144	.4917
23	1.7635	1.7284	1.9376	1.9547	.4915	.5144	.4917
24	.5144	1.8004	1.6164	1.9033	1.989	.4915	.5144
Max	2.7686	2.0748	1.9524	2.332	2.34	2.8656	2.7357
Min	.4424	.4458	.4458	.426	.4287	.4915	.4578
Avg	1.2237	1.0654	1.0594	1.1692	1.1080	1.3159	1.2354

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274047 / 33/11 KV VIZORI S/STN.

Feeder No / Name : 202 / VIZORI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4746	1.4289	1.3927	1.3441	1.6575	1.4752	.2915
2	1.4563	1.4289	1.5238	1.3426	1.6194	1.4089	.2915
3	1.2963	1.5242	1.704	1.3123	1.7147	1.3763	.3077
4	1.3735	1.6194	1.8515	1.2803	1.829	1.3904	.2753
5	1.4327	1.7147	1.917	1.3375	1.8671	1.4661	.3113
6	1.5699	1.7528	1.9595	1.4045	1.9624	1.5779	.3113
7	1.813	2.0386	2.1195	1.6575	2.2291	1.709	.3113
8	1.8099	2.2291	1.9757	1.7751	2.2862	1.729	.2785
9	.1612	.1715	.1781	.2149	.2012	.2149	1.5466
10	.1086	.1097	.1463	.1463	.128	.128	1.709
11	.081	.1097	.1097	.1097	.1097	.128	1.8884
12	.0972	.0732	.1097	.1097	.1097	.1463	1.6766
13	.0983		.1097	.1097	.1097	.1097	1.7387
14	.0983	.1097	.1097	.1097	.1097	.1097	1.8362
15	.1334	.0914	.0914	.1097	.128	.128	1.6861
16	.1524	.1097	.1097	.1463	.1463	.128	1.7901
17	.1334	.1097	.1097	.128	.1463	.1463	.0895
18	.1715	.1966	.1578	.2096	.1928	.1475	.1463
19	.2667	.2374	.2103	.2477	.2835	.0655	.2012
20	.3239	.3052	.2896	.362	.3224	.2785	.2561
21	.381	.3222	.3439	.3429	.2785	.2622	.3292
22	.362	.2753	.3506	.3429	.3045	.2949	.3292
23	1.467	1.3435	1.3426	1.6004	1.3108	.3077	.3109
24	1.3413	1.4289	1.3599	1.3599	1.6575	1.4419	.2785
Max	1.813	2.2291	2.1195	1.7751	2.2862	1.729	1.8884
Min	.081	.0732	.0914	.1097	.1097	.0655	.0895
Avg	.7335	.8144	.8155	.7126	.8627	.6737	.7580

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274047 / 33/11 KV VIZORI S/STN.

Feeder No / Name : 205 / EXPRESS FEEDER WATER SUPPLY Feeder KV- 11 / OUTGOING NON SHEDDABLE WATER SUPPLY AND UTILITY

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2486	.5716	.5182	.4372	.5716	.5967	.639
2	.2321	.5716	.5087	.431	.5716	.5735	.6154
3	.218	.5906	.5087	.4049	.5716	.5636	.5992
4	.3561	.6097	.5344	.4801	.5906	.5668	.6478
5	.3932	.6097	.5935	.4999	.5906	.5992	.6882
6	.421	.6097	.5801	.4725	.5906	.6081	.6718
7	.4001	.5906	.6062	.6944	.6668	.6093	.6964
8	.4218	.6478	.6952	.6241	.6668	.6483	.6554
9	.5281	.724	.6783	.5937	.6718	.7407	.5182
10	.5761	.5243	.664	.426	.7537	.3605	.6093
11	.5506	.4915	.6802	.3932	.5571	.5735	.6154
12	.5735	.3441	.7125	.4752	.7209	.6718	.5937
13	.6226	.4915	.6964	.5571	.639	.426	.5937
14	.5182	.5079	.664	.5243	.6226	.5407	.5556
15	.6287	.4752	.664	.5243	.6718	.6062	.5487
16	.7621	.5243	.6478	.5735	.7045	.6062	.5624
17	.7049	.6062	.6478	.5571	.6226	.6062	.5407
18	.6097	.6062	.5571	.6097	.6554	.5898	.4096
19	.5525	.407	.5407	.5716	.5624	.5407	.3768
20	.5335	.5426	.5121	.6478	.5967	.5571	.4588
21	.5525	.6104	.5121	.6478	.5601	.5898	.6226
22	.5525	.5407	.502	.5716	.6009	.5898	.5898
23	.5906	.5407	.4687	.5525	.5937	.5898	.5898
24	.2652	.5906	.5182	.4588	.5716	.6036	.5571
Max	.7621	.724	.7125	.6944	.7537	.7407	.6964
Min	.218	.3441	.4687	.3932	.5571	.3605	.3768
Avg	.4922	.5554	.5921	.5303	.6219	.5816	.5815



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274115 / 33/11 KV SANGAM

Feeder No / Name : 201 / JAMBUDBET

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.1524
Max	.1524
Min	.1524
Avg	.1524

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274115 / 33/11 KV SANGAM

Feeder No / Name : 202 / BABHULGAON SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1823	.2241	.2241	.1658	1.3717
2	.1829	.1823	.2241	.2427	.1658	1.3352
3	.2195	.1658	.2241	.2241	.1658	1.39
4	.2378	.1658	.2427	.2427	.1989	1.4632
5	.2743	.1989	.2614	.2614	.1989	1.4632
6	.2926	.2321	.3174	.2614	.2321	1.5546
7	.2926	.2321	.2614	.2614	.2321	1.6095
8	.2926	.1989	.2427	.2801	.1989	1.6461
9	1.3575		1.3441	1.5546	1.5089	.1867
10	1.326	1.3603	1.5546	1.4918	1.8107	.2241
11	1.326	1.3765	1.5384	1.4918	1.8473	.1867
12	1.326	1.4251	1.5708	1.5249	1.9022	.168
13	1.2929	1.4737	1.5384	1.4918	1.8473	.168
14	1.2431	1.4575	1.4899	1.4918	1.829	.168
15	1.2431	1.4419	1.5912	1.5746	1.701	.1867
16	1.2431	.1494	1.4998	1.4089	1.6827	.1867
17	.1989		.2614	.1989		.1867
18	.1989	.2241	.2987	.1989		.2241
19	.2321	.2614	.3361	.2321		.2427
20	.2321	.2614	.3734	.2321		.2614
21	.2155	.2427	.3921	.2155		.2801
22	.2155	.2427	.2801	.1989		.2801
23	.1989		.2427	.1989		1.0269
24	.1829	.1989	.2241	.2241	.1989	1.3352
Max	1.3575	1.4737	1.5912	1.5746	1.9022	1.6461
Min	.1829	.1494	.2241	.1989	.1658	.168
Avg	.5837	.5559	.6889	.6553	.9345	.7144

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274115 / 33/11 KV SANGAM

Feeder No / Name : 203 / SANGAM

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-AUG-17
HR	Load (MW)
24	.5182
Max	.5182
Min	.5182
Avg	.5182

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274117 / 33/11KV YASHWANTNAGAR S/STN.

Feeder No / Name : 201 / 11KV YESHWANTNAGAR SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2279	.2629	.2058	.16	.2454	.2572
2	.2401	.2229	.2629	.2743	.2572	.2454	.2572
3	.2401	.2279	.2629	.2915	.2572	.2454	.2572
4	.2572	.2572	.2629	.3086	.2743	.2629	.2743
5	.2743	.2804	.2629	.3086	.2915	.2804	.3086
6	.3086	.3086	.3155	.3086	.2915	.3155	.3086
9	.2835	.3155	.3155	.2401	.333	.3155	.2058
10	.2835	.2915	.3086	.2658	.3506	.3258	.2401
11	.3544	.3086	.3258	.3366	.3681	.3429	.2058
12	.3898	.3258	.3429	.3366	.3856	.3601	.2229
13	.4075	.3258	.3086	.3012	.4031	.3601	.2401
14	.4252	.3429	.2915	.333	.3506	.3429	.2572
15	.3898	.3601	.3086	.3544	.333	.3772	.2743
16	.3544	.3429	.3258	.3898	.3544	.3772	.2743
17	.3189	.3258	.3086	.3429	.3506	.3086	.2401
18	.3506	.333	.2572	.3086	.3506	.3429	.3155
19	.3506	.333	.2743	.2915	.3506	.3429	.3506
20	.3506	.3155	.2743	.3258	.3506	.3429	.3506
21	.3155	.298	.3086	.2572	.333	.3429	.3506
22	.2804	.298	.2743	.2401	.3155	.3086	.3155
23	.2629	.2804	.2743	1.9433	.2629	.2743	.298
24	.2572	.2454	.2572	.2058		.2629	.2743
Max	.4252	.3601	.3429	1.9433	.4031	.3772	.3506
Min	.2401	.2229	.2572	.2058	.16	.2454	.2058
Avg	.3160	.2985	.2903	.3714	.3202	.3147	.2763

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274117 / 33/11KV YASHWANTNAGAR S/STN.

Feeder No / Name : 202 / 11KV GRAMIN

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2743	.3155	.2743	.2743		2.3148
2	.2743	.2743	.3155	.2743	.3086		2.3148
3	.2743	.2572	.3155	.3086	.3086		2.4006
4	.3086	.2572	.3155	.3086	.3258		2.4006
5	.3086	.2572	.3155	.3086	.3429		2.4863
6	.3429	.3086	.3506	.3429	.3429		
7	.3429	.3429	.3506	.3429	.3772		2.7435
8	.3429	.3429	.3681	.3429	.3921		2.8292
9	2.5911	2.572	2.6292	2.1052	2.0576		.3086
10	2.5777	2.7435	2.6578	2.6715	2.734	2.572	.3429
11	2.5777	2.8292	2.7435	2.4996	2.9839	2.6578	
12	2.6882		2.915	2.5934	2.9683	2.7435	.3258
13	2.7673	2.8292	2.572	2.5777	3.0152	2.9864	.3258
14	2.7027	2.915	2.4006	2.5621	3.062	2.8292	.3086
15	2.734	3.0007	2.2291	2.5465	3.0464	1.9433	.3086
16	2.7199	2.915	2.2291	2.5465	2.8746	2.915	.1715
17	.1875	.3429	.3429	.3429	.2454	.2915	.3086
18	.3429	.3944	.3601	.3258	.3506	.3086	.3506
19	.3772	.4287	.3429	.3601	.3856	.3429	.3856
20	.3944	.4458	.3429	.3772	.4031	.3429	.4031
21	.3944	.4115	.3086	.3258	.4382	.3429	.4031
22	.3772	.3944	.2743	.3086	.3856	.3086	.4207
23	.3429	.3772	.2743	.2915	.3506	2.1052	2.3663
24	.2743	.3086	.3506	.2743	.2743		2.3148
Max	2.7673	3.0007	2.915	2.6715	3.062	2.9864	2.8292
Min	.1875	.2572	.2743	.2743	.2454	.2915	.1715
Avg	1.1049	1.0966	1.0675	1.0505	1.1770	1.6207	1.2061

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274117 / 33/11KV YASHWANTNAGAR S/STN.

Feeder No / Name : 203 / 11 KV CHOUDESHWARWADI FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9433	2.191	2.191	2.1052	2.0243		.1715
2	2.0243	2.191	2.191	2.1862	2.1052		.1715
3	2.0243	2.1434	2.191	2.1862	2.1052		.1715
4	2.1862	2.2786	2.191	2.2672	2.1862		.1715
5	2.2672	2.4539	2.2786	2.2672	2.1862		.1886
6	2.3482	2.6292		2.3482	2.1862		.1886
7	2.3482	2.8045	2.6292	2.5101	2.2672		.2058
8	2.4291	2.9797	2.8045	2.5101	2.3482		.2058
9	.1581		.1753	.1715	.2915		2.1862
10	.1581	.1619	.1619	.1581	.1581	.16	2.2672
11	.1581	.1619	.1619	.1562	.1562	.1619	2.3482
12	.16	.1619	.1619	.1619	.1619	.1619	2.4291
13	.1562	.1619	.1619	.1638	.1562	.1619	2.4291
14	.16	.1619	.1619	.1562	.1562	.1619	2.2672
15	.1581	.1619	.1619	.1562	.1562	.1619	2.2672
16	.1619	.2915	.1619	.1562	.1562	.1619	2.1862
17	.1581	.1619	.1619	.1619	.1753	.1619	.1619
18	.1886	.1715	.1619	.1619	.1753	.1715	.2103
19	.2058	.1715	.1886	.1619	.1753	.1715	.2103
20	.2058	.1715	.1715	.1619	.1753	.1715	.2103
21	.1886	.1715	.1715	.1619	.1753	.1715	
22	.1715		.1715	.1619	.1715	.1715	.1928
23	2.1033	2.191	2.0243	1.9433	2.2786	.1715	.1753
24	1.9433	2.191	2.191	2.1052	2.0243		.1715
Max	2.4291	2.9797	2.8045	2.5101	2.3482	.1715	2.4291
Min	.1562	.1619	.1619	.1562	.1562	.16	.1619
Avg	1.0003	1.1893	1.0012	1.0284	1.0063	.1659	.9212

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274117 / 33/11KV YASHWANTNAGAR S/STN.

Feeder No / Name : 204 / GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2058	.2229	.2058	.2229		.2058
2	.2058	.2103	.2229	.2058	.2401		.2058
3	.2229	.2103	.2229	.2229	.2572		.2401
4	.2229	.2279	.3086	.2229	.2915		.2401
5	.2401	.2454	.2743	.2401	.2915		.2743
6	.2401	.2629	.2804	.2401	.3086		.3086
7	.2572	.2804	.298	.2743	.3258		.3086
8	.2572	.2804	.2804	.2743	.2572		.2743
9	.2279		.2629	.2229	.2401		.2229
10	.2303	.2401	.2229	.2454	.2303	.2572	.2058
11	.2507	.2572	.2229	.2454	.2303	.2401	.1886
12	.2658	.2743	.2058	.2103	.2481	.2743	.2229
13	.2481	.2572	.1886	.1753	.2561	.2229	.1886
14	.2534	.2401	.2058	.2454	.2629	.2401	.1943
15	.2303	.2058	.2229	.2629	.2629	.1886	.1943
16	.2103	.2572	.2401	.2454	.2629	.2058	.2229
17	.1949	.2401	.1886	.2572	.2629	.1886	.2058
18	.2743	.2915	.2058	.2401	.2804	.2229	
19	.2915	.298	.2058	.2572	.2804	.2401	.2804
20	.3086	.2804	.2401	.2915	.2804	.2401	.298
21	.2743	.2572	.2401	.1886	.2804	.2229	.2629
22	.2454	.2401	.2401	.2229	.2629	.2058	.2454
23	.2229	.2229	.2229	.2058	.2454	.2058	.2279
24	.2058	.2279	.2279	.2058	.2229		.2058
Max	.3086	.298	.3086	.2915	.3258	.2743	.3086
Min	.1949	.2058	.1886	.1753	.2229	.1886	.1886
Avg	.2411	.2484	.2356	.2337	.2627	.2254	.2358

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274117 / 33/11KV YASHWANTNAGAR S/STN.

Feeder No / Name : 205 / GIRZANI FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274117 / 33/11KV YASHWANTNAGAR S/STN.

Feeder No / Name : 206 / 11 kV MAHARSHINAGAR SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.8764	.8764	.9431	.9431	.8764	.8573
2	.9431	.8764	.8764	.9431	.9431	.8764	.8573
3	.9431	.8764	.8764	1.0288	.9431	.8764	.9431
4	.9431	1.0517	1.0517	1.0288	1.0288	.964	.9431
5	1.0288	1.0517	1.1393	1.0288	1.0288	1.0517	1.0288
6	1.0288	1.1393	1.1393	1.1145	1.1145	1.1393	1.0288
7			1.1393				
9	1.0631	1.1393	1.1393	.9431	1.0288	1.1393	.9431
10	1.0631	1.1145	1.1145	1.0517	1.0517	1.1145	1.0288
11	1.0454	1.1145	1.0288	1.0631	1.0517	1.0288	1.1145
12	1.0099	1.0288	1.0288	1.0517	1.0631	1.0288	1.1145
13	.9745	1.1145	.9431	.8764	1.0631	1.1145	1.0288
14	1.0029	.9431	.8573	1.0517	1.1517	1.1145	1.0288
15	1.0454	1.0288	.8573	1.0631	1.1517	.9431	1.1145
16	1.0631	.9431	.8573	1.0517	1.134	.9431	1.1145
17	1.0745	.9431	.9431		1.1393	.9431	.9431
18	1.1393	1.1393	.8573		1.1393	.8573	1.1393
19	1.2269	1.1393	.9431		1.2269	.9431	1.1393
20	1.2269	1.1393	1.0288		1.2269	.9431	1.2269
21	1.1393	1.1393	1.0288		1.2269	.9431	1.2269
22	1.1393	1.0517	1.0288		1.1393	.8573	1.1393
23	1.0517	.964	.9431	.8573	1.0517	.8573	1.0517
24	.8573	.964	.8764	.9431	.8573	.964	.8573
Max	1.2269	1.1393	1.1393	1.1145	1.2269	1.1393	1.2269
Min	.8573	.8764	.8573	.8573	.8573	.8573	.8573
Avg	1.0394	1.0354	.9815	1.0025	1.0775	.9781	1.0395

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274117 / 33/11KV YASHWANTNAGAR S/STN.

Feeder No / Name : 207 / Deshmukh Mala FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7287	.8764	.8764	.7287	.8097		.0857
2	.7287	.8764	.8764	.7287	.8907		.1029
3	.8097	.8573	.8764	.8097	.9717		.1029
4	.8097	.8764	.8764	.8097	1.0526		.12
5	.8907	1.0517	.8764	.8907	1.1336		.1372
6	.9717	1.1393	1.0517	.8907	1.2146		.1372
7	1.0526	1.2269	1.2269	1.0526	1.2146		.1543
8	1.2146	1.2795	1.3146	1.1336	1.1336		.1372
9	.1134	.12	.1227	.1029	.1134		.8907
10	.0972	.1134	.0972	.0781	.0781	.0972	.8907
11	.0949	.0972	.081	.0781	.0781	.081	.8907
12	.0949	.0972	.081	.0781	.0625	.081	.9717
13	.0819	.0972	.0648	.0781	.0625	.081	.9717
14	.0949	.081	.081	.0781	.0625	.0972	1.0526
15	.081	.081	.0972	.0781		.0857	1.0526
16	.081	.0972	.0972	.0781	.0625	.1029	1.1336
17	.0655	.0972	.081	.0972	.0876	.0972	.0972
18	.1372	.1543	.0972	.1134	.1402	.1029	.1402
19	.1543	.1886	.12	.1296	.1578	.12	
20	.1715	.2058	.1372	.1619	.1715	.12	.1578
21	.1886	.1886	.1372	.1457	.1928	.1372	.1928
22	.1715	.1715	.1372	.1457	.1886	.12	.1753
23	.7716	.8764	.6478	.6478	.7888	.1029	.1402
24	.7287	.8764	.8764	.7287	.7287		.0857
Max	1.2146	1.2795	1.3146	1.1336	1.2146	.1372	1.1336
Min	.0655	.081	.0648	.0781	.0625	.081	.0857
Avg	.4306	.4886	.4555	.411	.4955	.1019	.4270

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274143 / 33/11 kV ANANDNAGAR

Feeder No / Name : 201 / 11 KV CHAKORE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2498	.9755	1.3413	1.3717	1.5546	1.5394	.442
2	1.2498	.9907	1.3413	1.3717	1.6004	1.6004	.4268
3	1.2651	1.0212	1.3565	1.448	1.6613	1.6004	.442
4	1.326	1.1279	1.4937	1.5242	1.6766	1.6766	.4572
5	1.4632	1.2193	1.7528	1.6766	1.7985	1.8138	.4877
6	1.7223	1.4022	1.8595	1.829	2.0119	2.1338	.4572
7	1.8138	1.6156	1.9509	1.9509	2.2253	2.3624	.442
8	1.7375	1.6461	1.9662	2.0119	2.1643	2.2862	.3506
9	.2286	.2743	.2743	.3353	.3353	.3048	2.1948
10	.2286	.2286	.2439	.2591	.2743	.2743	2.332
11	.2134	.2134	.2286	.2134	.3048	.2743	2.2862
12	.2134	.2134	.1981	.2134	.3353	.3048	2.3167
13	.2286	.1981	.1677	.2134	.2591	.2743	2.4082
14	.2134	.1829		.2134	.2134	.2743	2.2862
15	.2134	.1829	.1677		.2134	.2439	2.1948
16	.1677	.1981	.2134		.2439	.3048	2.1033
17	.1829	.2896	.2591	.2743	.2134	.2743	.2134
18	.2439	.3353	.2896	.3353	.2743	.3048	.2743
19	.2743	.3658	.3201	.3658	.3658	.3963	.3048
20	.3963	.3963	.3658	.4268	.3963	.381	.3353
21	.3658	.381	.3963	.3963	.4115	.3658	.3506
22	.3658	.4115	.4268	.4268	.4115	.4268	.381
23	.945	1.3413	1.2955	1.4937	1.4632	.442	.4115
24	.503	.9602	1.326	1.4022	1.5242	1.5242	.442
Max	1.8138	1.6461	1.9662	2.0119	2.2253	2.3624	2.4082
Min	.1677	.1829	.1677	.2134	.2134	.2439	.2134
Avg	.7005	.6738	.8363	.8979	.9139	.8910	1.0142

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274143 / 33/11 kV ANANDNAGAR

Feeder No / Name : 202 / 11 KV KONDBAVI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.381	.3963	.3048	.381	.3201	1.3413
2	.3506	.381	.3963	.3048	.3658	.3201	1.326
3	.3658	.3658	.381	.3048	.3963	.3353	1.3413
4	.4115	.3963	.4115	.3353	.3963	.381	1.4784
5	.4268	.3963	.4572	.3353	.3658	.4572	1.7528
6	.4572	.3963	.442	.3353	.3963	.4877	1.8595
7	.3658	.4268	.4115	.3353	.4268	.4268	1.9357
8	.2896	.3963	.3201	.3353	.3658	.3658	1.89
9	1.7223	1.5242	1.5089	1.4632	1.7375	1.7528	.2591
10	1.7375	1.5394	1.6613	1.4784	1.8138	1.7375	.2286
11	1.6461	1.448	1.6766	1.5242	1.7375	1.768	.1829
12	1.5851	1.4327	1.5851	1.5394	1.6766	1.768	.1829
13	1.5089	1.387	1.5851	1.5546	1.6461	1.6766	.1829
14	1.4022	1.3717	1.6156	1.5699	1.6309		.1981
15	1.3717	1.326	1.6004	1.6004	1.6004	1.8176	.2134
16	1.3565	1.3108	1.5546	1.6156	1.5851	1.6766	.1829
17	.1372	.2134	.2134	.2439	.1829	.1829	.2134
18	.2134	.2591	.2439	.2743	.2439	.2743	.2134
19	.2743	.2896	.2743	.3048	.3353	.3048	.2591
20	.3353	.3201	.2896	.3658	.3658	.3201	.2896
21	.3201	.3048	.3201	.3353	.3658	.3048	.3201
22	.3353	.3353	.3048	.3658	.3353	.3353	.3353
23	.3658	.3658	.3048	.3963	.3353	1.3413	1.0669
24	.3506	.3658	.381	.3201	.3963	.3201	1.3565
Max	1.7375	1.5394	1.6766	1.6156	1.8138	1.8176	1.9357
Min	.1372	.2134	.2134	.2439	.1829	.1829	.1829
Avg	.7373	.7056	.7640	.7310	.7951	.8119	.7754

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274143 / 33/11 kV ANANDNAGAR

Feeder No / Name : 203 / 11 KV VATHPHALI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0762	.0762	.0762	.0762	.3963
2	.0762	.061	.0762	.0762	.0762	.0762	.381
3	.0762	.061	.0914	.0762	.0914	.0762	.3963
4	.0914	.0762	.1067	.0914	.0762	.1067	.4572
5	.1067	.0762	.1067	.0914	.0914	.1067	.5335
6	.1219	.0914	.1219	.0914	.0914	.1219	.6401
7	.0914	.0914	.0914	.0914	.1219	.1067	.7164
8	.0914	.0914	.0914	.0914	.0914	.0914	.7011
9	.7468	.7926	.4725	.6001	.6859	.5792	
10	.7621	.7468	.6401	.5792	.7164	.6097	.061
11	.7621	.7316	.6249	.5639	.6401	.6554	.061
12	.7316	.6706	.5944	.5487	.5792	.6097	.061
13	.6859	.6554	.5792	.5792	.5335	.503	.061
14	.7011	.6401	.5639	.6097	.5944		.0762
15	.7011	.6401	.5487	.6097	.6097	.5944	.0762
16	.6859	.6097	.5639	.6249	.6401	.6401	.061
17	.0305	.061	.061	.061	.0305	.061	.0914
18	.061	.0457	.0457	.0457	.0457	.0762	.0762
19	.0762	.0762	.0762	.0762	.0762	.1067	.061
20	.0914	.1067	.061	.0914	.0914	.1067	.0457
21	.0762	.0914	.0762	.0762	.1067	.1219	.0762
22	.0914	.0762	.0762	.0762	.0914	.1067	.1067
23	.0762	.0762	.0762	.0914	.0914	.381	.3963
24	.0762	.0762	.0762	.0762	.0914	.0762	.3963
Max	.7621	.7926	.6401	.6249	.7164	.6554	.7164
Min	.0305	.0457	.0457	.0457	.0305	.061	.0457
Avg	.2953	.2801	.2458	.2498	.2642	.2604	.2578

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274143 / 33/11 kV ANANDNAGAR

Feeder No / Name : 204 / vaibhav agrotech ht consumer Feeder KV- 11 / OUTGOING  
 NON SHEDDABLE EXPRESS HV FEEDERS  
 (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0017	.0017	.0017	.0017	.0017	.0017	.0017
2	.0017	.0017	.0017	.0017	.0017	.0017	.0017
3	.0017	.0017	.0017	.0017	.0017	.0017	.0017
4	.0017	.0017	.0017	.0017	.0017	.0017	.0017
5	.0017	.0017	.0017	.0017	.0017	.0017	.0017
6	.0017	.0017	.0017	.0017	.0017	.0017	.0017
7	.0017	.0017	.0017	.0017	.0017	.0017	.0017
8	.0017	.0017	.0017	.0017	.0017	.0017	.0017
9	.0015	.0017	.0017	.0017	.0017	.0015	
10	.0017	.0017	.0017	.0017	.0017	.0017	.0017
11	.0017	.0017	.0017	.0017	.0017	.0017	.0017
12	.0017	.0017	.0017	.0017	.0017	.0017	.0017
13	.0017	.0017	.0017	.0017	.0017	.0017	.0017
14	.0017	.0017	.0017	.0017	.0017	.0017	.0017
15	.0017	.0017	.0017	.0017	.0017	.0017	.0017
16	.0017	.0017	.0017	.0017	.0017	.0017	.0017
17	.0017	.0017	.0017	.0017	.0017	.0017	.0017
18	.0017	.0017	.0017	.0017	.0017	.0015	.0017
19	.0017	.0017	.0017	.0017	.0017	.0017	.0017
20	.0017	.0017	.0017	.0017	.0017	.0017	.0017
21	.0017	.0017	.0017	.0017	.0017	.0017	.0017
22	.0017	.0017	.0017	.0017	.0017	.0017	.0017
23	.0017	.0015	.0017	.0017	.0017	.0015	.0017
24	.0017	.0017	.0017	.0017	.0017	.0015	.0017
Max	.0017	.0017	.0017	.0017	.0017	.0017	.0017
Min	.0015	.0015	.0017	.0017	.0017	.0015	.0017
Avg	.0017	.0017	.0017	.0017	.0017	.0017	.0017

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274196 / 33/11KV KHANDALI SUB STATION

Feeder No / Name : 201 / 11KV KHANDALI NAGTHANA SINGLE PHASING

FEEDER Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.286	.3189	.3944	.3772	.2481	.2915	.3944
2	.4287	.2835	.4115	.3944	.2126	.3086	.3772
3	.4801	.2658	.4287	.4115	.1949	.3086	.3944
4	.5144	.2126	.3944	.4458	.1772	.2915	.4115
5	.5487	.2126	.4801	.5144	.1772	.4287	.5144
6	.5658	.3189	.5144	.7202	.4252	.5144	.6001
7	.6001	.4252	.6173	.6516	.5493	.583	.583
8	.463	.5316	.583	.5658	.6024	.463	.4287
9	.8745	.8573	.8745	.7619	.9568	.4784	.9568
10	.9602	.8573	.8859	.8859	.9745		.9214
11	.9945	.8573	.8859	.8859	.9745		.9745
12	.9431	.8573	.9745	.8859	.7973	.7973	.9745
13	.9259	.7716	.8859	.8859	.9745	1.0631	
14	.9088	.7716	.8859	.8859	.7973	1.0631	.7973
15	.8916	.7716	.8859	.7973	1.0631	1.0288	
16	.8573	.8402	.7973	.8859	.7716	1.0288	.6201
17	.2303	.2743	.2572	.2658	.2572		.3429
18	.3898	.3086	.3601	.3898	.4287		.3772
19	.4784	.4973	.5144	.5316	.5144	.4973	.4458
20	.443	.4801	.583	.4784	.583	.4973	.4287
21	.443	.463	.5144	.443	.4973	.4973	.3944
22	.4607	.4458	.4115	.443	.4287	.4287	.3601
23	.443	.3944	.3944	.3898	.3944	.3944	.3429
24	.4115	.3898	.3772	.3944	.3189	.3086	.3944
Max	1.286	.8573	.9745	.8859	1.0631	1.0631	.9745
Min	.2303	.2126	.2572	.2658	.1772	.2915	.3429
Avg	.6476	.5169	.5963	.5955	.5550	.5636	.5470

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274196 / 33/11KV KHANDALI SUB STATION

Feeder No / Name : 202 / 11KV DATTANAGAR FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	1.6289	1.7147	1.4232	1.448	1.749	.5144
2	1.8004	1.5384	1.8004	1.4232	1.448	1.7147	.5316
3	1.8347	1.5384	1.8347	1.406	1.5023	1.6289	.5316
4	1.8519	1.5746	1.8861	1.4403	1.5384	1.749	.5487
5	1.8861	1.6651	1.9719	1.4746	1.5384	1.8519	.5487
6	1.8861	1.8461	1.8861	1.7318	1.6651	1.8861	.6001
7	1.9719	2.0633	2.0576	2.1091	2.0271	2.0576	.6001
8	2.1091	2.1176	2.0062	1.7147	1.9909	2.1605	.5487
9	.5144	.463	.4973	.5373	.5552	.5373	2.0774
10	.4801	.4115	.5373	.5373	.5373	.5373	2.2386
11	.463	.4115	.5373		.5373	.5014	2.3282
12	.4458	.3944	.5373	.5373	.5373	.5373	2.4177
13	.4458	.3772	.5373	.5373	.5373	.5373	2.3282
14	.4458	.4115	.4477	.5373	.5373	.5373	2.1491
15	.4458	.4287	.4477	.5373	.5373	.5144	2.4177
16	.463	.4458	.4477	.5373	.5373	.5144	2.2386
17	.5249		.5144	.5373	.5144	.4973	.5144
18	.5249	.4801	.4973	.543	.5144	.5316	.5144
19	.543	.5487	.5658	.5611	.5487	.5658	.5316
20	.543	.5144	.5658	.543	.5658	.5658	.5316
21	.5611	.5144	.5487	.5611	.5658	.5658	.5487
22	.5611	.5316	.5316	.5792	.5316	.5487	.5316
23	1.6289	1.4918	1.406	1.5203	1.5775	.5316	.5144
24	1.6289	1.6651	1.6804	1.406	1.4842	1.7147	.5316
Max	2.1091	2.1176	2.0576	2.1091	2.0271	2.1605	2.4177
Min	.4458	.3772	.4477	.5373	.5144	.4973	.5144
Avg	1.0531	1.0027	1.0607	.9885	.9907	1.0223	1.1182



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274196 / 33/11KV KHANDALI SUB STATION

Feeder No / Name : 203 / 11KV BHOSALE WASTI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.1898	.2915	.2896	.1898	.3086	1.6004
2	.3048	.1898	.2915	.2743	.1898	.2915	1.6004
3	.3353	.1739	.3429	.2896	.1739	.2743	1.5851
4	.3658	.1739	.3429	.3048	.1739	.3086	1.6156
5	.3353	.2458	.3258	.3201	.2214	.3429	1.6461
6	.3353	.2846	.3086	.3658	.2214	.3772	1.7375
7	.3506	.3163	.3429	.3506	.2372	.3772	1.9814
8	.2743	.3321	.3086	.3353	.2372	.3944	1.8595
9	2.0881	2.1091	2.0233	2.0005	2.0165	1.8724	.2241
10	2.1491	2.3148	1.9204	2.0805	2.2405	1.8404	.2401
11	2.1643	2.2119	1.9204	2.1605	2.4177		.2401
12	2.0576	2.1948	1.7604	2.3205	2.0805	2.2405	.2401
13	1.9662	2.1948	2.0805	2.2405	2.1605	2.0805	.2401
14	1.829	2.1605	2.0805	2.2405	2.1605	2.0005	.2401
15	1.9052	2.1434	2.0005	2.2405	2.2405	1.829	.2401
16	1.9052	.4801	2.0805	2.2405	2.1605	1.9814	.2401
17	.2056	.2572	.2286	.2401	.1715	.1981	.2572
18	.2372	.2743	.2743	.2688	.2572	.2743	.2743
19	.2846	.3258	.3353	.3005	.3086	.2896	.3086
20	.2688	.2915	.3506	.3163	.3601	.2896	.3086
21	.2688	.3429	.3201	.2846	.3429	.2743	.3086
22	.2846	.3429	.3258	.2846	.3601	.2743	.3258
23	.2372	.3086	.2896	.253	.3772	1.5851	1.7147
24	.3048	.2214	.3086	.2896	.2214	.3429	1.6004
Max	2.1643	2.3148	2.0805	2.3205	2.4177	2.2405	1.9814
Min	.2056	.1739	.2286	.2401	.1715	.1981	.2241
Avg	.8651	.8367	.8689	.9288	.8967	.8716	.8595

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274196 / 33/11KV KHANDALI SUB STATION

Feeder No / Name : 204 / 11KV ITI KHADALI FEEDER NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	04-AUG-17	05-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		.0148	.0103		
8		.0148			
10				.0148	
11					.0111
13					.0129
15					.0129
16					.0111
22	.0111				
23				.0103	
Max	.0111	.0148	.0103	.0148	.0129
Min	.0111	.0148	.0103	.0103	.0111
Avg	.0111	.0148	.0103	.0126	.012

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274198 / 33/11 kv BABULGOAN SUB

STATI

Feeder No / Name : 201 / BABULGOAN FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3163	.3125	.2753	.3163	.8592	.823
2	.3121	.3321	.2743	.2526	.3321	.8697	.9069
3	.2743	.3163	.3201	.1783	.3321	.8855	.8916
4	.2778	.3321	.3201	.2778	.3479	.8592	.9877
5	.2972	.3479	.2972	.2778	.3637	.8951	1.0467
6	.2824	.3637	.2984	.3086	.3479	1.0311	.9907
7	.2968	.3479	.2896	.3395	.3321	1.034	1.085
8	.2372	.253	.2286	.2743	.253	1.0494	1.0031
9	1.3272	.6327	.6249	.6478	.8792	.2286	.1981
10	.8288	.5944	.7316	.7682	1.034	.1932	.1932
11	.8551	.7282	.7468	.8886	1.0031	.1829	.125
12	.7935	.6481	.8688	.8886	.9722	.1677	.1486
13	.7842	.6539	.7716	.8848	1.0105	.1562	.1698
14	.7865	.6573	.8951	.8583	1.078	.1389	.1677
15	.7865	.7011	.8025	.8684	1.0364	.1372	.1524
16	.7449	.6173	.8488	.8745	1.0517	.1677	.1562
17	.253	.2229	.1543	.1739	.1829	.1932	.1562
18	.3005	.1543	.2623	.253	.1981	.1858	.1875
19	.3321	.2778	.2229	.2846	.2932	.2591	.2526
20	.3637	.2824	.216	.3321	.3395	.3418	.3125
21	.3479	.3048	.3241	.3479	.2972	.301	.2972
22	.3321	.3281	.2623	.3637	.3281	.3121	.3315
23	.3321	.3125	.1852	.3479	.8697	.7773	.7133
24	.3353	.3321	.3241	.2286	.3321	.8436	.8124
<b>Max</b>	<b>1.3272</b>	<b>.7282</b>	<b>.8951</b>	<b>.8886</b>	<b>1.078</b>	<b>1.0494</b>	<b>1.085</b>
<b>Min</b>	<b>.2372</b>	<b>.1543</b>	<b>.1543</b>	<b>.1739</b>	<b>.1829</b>	<b>.1372</b>	<b>.125</b>
<b>Avg</b>	<b>.4911</b>	<b>.4191</b>	<b>.4409</b>	<b>.4665</b>	<b>.5638</b>	<b>.5029</b>	<b>.5045</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274198 / 33/11 kv BABULGOAN SUB

STATI

Feeder No / Name : 202 / WAFEGAON FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0031	.8192	.5944	.8002	1.0227	.2056	.1486
2	.9907	.8453	.6802	1.034	.9995	.1875	.1486
3	1.0802	.8383	.7164	1.034	.9995	.0316	.1635
4	1.0802	.8421	.7164	1.142	1.073	.1875	.1829
5	1.1111	.9326	.7468	1.1431	1.1736	.2214	.2134
6	1.142	.9448	.8993	1.2498	1.3395	.2812	.2056
7	1.1279	.9555	.9297	1.2811	1.3426	.2688	.2187
8	1.1961	.9922	1.0059	1.326	1.2631		.1829
9	.1423	.1389	.108	.1423	.1783		1.5158
10	.1107	.1524	.1189	.1265	.1783	1.5123	1.6644
11	.0949	.1219	.108	.1265	.1235	1.5009	.1783
12	.1107	.1067	.0914	.1107	.1219	1.7654	1.5586
13	.0949	.1067	.1067	.1265	.1219	1.7497	1.5394
14	.1107	.0762	.0743	.1265	.061	1.7029	1.6872
15	.1265	.0743	.0914	.1423	.1337	1.6507	1.278
16	.1423	.0892	.0914	.1107	.1372	1.7497	1.5581
17	.1581	.1505	.0594	.1265	.1524	.1524	.1562
18	.1898	.1635	.0762	.1423	.2378	.1635	.1406
19	.1898	.2134	.0743	.1581	.2439	.2187	.2031
20	.2056	.2286	.1067	.2214	.2229	.2286	.2006
21	.2372	.2134	.1543	.2056	.208	.2439	.1852
22	.2214	.1829	.2134	.2214	.208	.2187	.2187
23	.7773	.6859	.7282	.9717		.2006	.1783
24	.9259	.8122	.6944	.7968	1.0111	.2056	.1738
<b>Max</b>	<b>1.1961</b>	<b>.9922</b>	<b>1.0059</b>	<b>1.326</b>	<b>1.3426</b>	<b>1.7654</b>	<b>1.6872</b>
<b>Min</b>	<b>.0949</b>	<b>.0743</b>	<b>.0594</b>	<b>.1107</b>	<b>.061</b>	<b>.0316</b>	<b>.1406</b>
<b>Avg</b>	<b>.5237</b>	<b>.4453</b>	<b>.3828</b>	<b>.5361</b>	<b>.5458</b>	<b>.6658</b>	<b>.5792</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 278008 / 220/132/33/11 KV MALINAGAR

Feeder No / Name : 202 / 11KV VELAPUR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 278008 / 220/132/33/11 KV MALINAGAR

Feeder No / Name : 203 / SANGAM

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.7011
Max	.7011
Min	.7011
Avg	.7011

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 278008 / 220/132/33/11 KV MALINAGAR

Feeder No / Name : 204 / YASHWANTNAGAR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 278008 / 220/132/33/11 KV MALINAGAR

Feeder No / Name : 205 / 11KV GANESH NAGAR  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-AUG-17
HR	Load (MW)
24	.0857
Max	.0857
Min	.0857
Avg	.0857



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 278008 / 220/132/33/11 KV MALINAGAR

Feeder No / Name : 206 / 11 Kv Harinagar (M S  
Karkhana Feeder KV- 11 /  
OUTGOING

GAOTHAN FEEDER

DATE	01-AUG-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 278008 / 220/132/33/11 KV MALINAGAR

Feeder No / Name : 207 / MAHALUNG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 278008 / 220/132/33/11 KV MALINAGAR

Feeder No / Name : 208 / GAOTHAN (MALINAGAR)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 278008 / 220/132/33/11 KV MALINAGAR

Feeder No / Name : 704 / 132 KV SMS SL Cogen

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 132 / OUTGOING

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	.5487
Max	.5487
Min	.5487
Avg	.5487

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 000494 / 132/33KV VELAPUR EHV S/S

Feeder No / Name : 430 / 33KV VIZORI FEEDER

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	.5487
Max	.5487
Min	.5487
Avg	.5487

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274040 / 33/11KV NEWARE S/SN.

Feeder No / Name : 201 / 11KV JAMBHUD

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3101		2.1719	2.1253			2.2624
2	2.3101		2.1719	2.1253			2.2624
3	2.2177		2.1719	2.1253			2.2624
4	2.2177		2.0814	2.2177			2.2624
5	2.3101		2.1719	2.2177			2.2624
6	2.3101		2.2624	2.2177			2.3529
7	2.4949		2.3529				2.5339
8	2.4949		2.4434				2.7149
13	.2801	.2772			.3734		
14	.3696	.3696			.4572	.3696	
15	.3734	.462			.5121	.462	
16	.3734	.462			.4572	.462	
19		.462	.3696			.5487	.4525
20		.4668	.462			.5487	.543
21		.4668	.462			.4572	.543
22		.4668	.462			.4572	.543
23		2.0814	2.1253			2.1948	.5792
24	.3506		2.1719	2.1253			2.2862
Max	2.4949	2.0814	2.4434	2.2177	.5121	2.1948	2.7149
Min	.2801	.2772	.3696	2.1253	.3734	.3696	.4525
Avg	1.5702	.6127	1.7058	2.1649	.4500	.6875	1.7043

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274040 / 33/11KV NEWARE S/SN.

Feeder No / Name : 202 / 11KV KONDARPATTA FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	1.7004	1.7004	1.6194	1.7814	
10	2.0243	1.9433	2.0243	2.0243	
11	2.0243	1.9433	2.0243	2.0243	
12	2.1052	1.9433	2.0567		
13	2.1052	1.9433	2.0243		
14	2.1052	1.8623	2.0243	1.7004	
15	1.7814	1.7814	1.7004	1.9433	
16	1.7814	1.4575	1.8623	2.0243	
23					1.4419
24	.3506				
<b>Max</b>	<b>2.1052</b>	<b>1.9433</b>	<b>2.0567</b>	<b>2.0243</b>	<b>1.4419</b>
<b>Min</b>	<b>.3506</b>	<b>1.4575</b>	<b>1.6194</b>	<b>1.7004</b>	<b>1.4419</b>
<b>Avg</b>	<b>1.7753</b>	<b>1.8219</b>	<b>1.917</b>	<b>1.9163</b>	<b>1.4419</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274040 / 33/11KV NEWARE S/SN.

Feeder No / Name : 203 / NEWARE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6385		1.8023	1.6385		2.0814
2	1.6385		1.8023	1.6385		1.8842
3	1.7204		1.7204	1.6385		1.8842
4	1.6385		1.7204	1.5565		1.8842
5	1.6385		1.7204	1.5565		1.8842
6	1.7204		1.8023	1.7204		1.8842
7	1.8842		1.9662			2.0481
8	2.0481		1.9662			2.13
23		1.8023	1.7204		1.9662	
24	.3506		1.8023	1.6385		1.9662
<b>Max</b>	<b>2.0481</b>	<b>1.8023</b>	<b>1.9662</b>	<b>1.7204</b>	<b>1.9662</b>	<b>2.13</b>
<b>Min</b>	<b>.3506</b>	<b>1.8023</b>	<b>1.7204</b>	<b>1.5565</b>	<b>1.9662</b>	<b>1.8842</b>
<b>Avg</b>	<b>1.5864</b>	<b>1.8023</b>	<b>1.8023</b>	<b>1.6268</b>	<b>1.9662</b>	<b>1.9607</b>



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274040 / 33/11KV NEWARE S/SN.

Feeder No / Name : 204 / 11KV NADURE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	1.1469	1.278	1.6385	1.7814	
10	1.3108	1.3108	2.0481	1.9433	
11	1.4746	1.3108	2.0481	1.9433	
12	1.4746	1.3108	2.3411		
13	1.4746	1.2289	1.7695		
14	1.4419	1.2289	1.8023	1.7004	
15	1.3435	1.2289	1.8515	1.7004	
16	1.4255	1.2289	1.8842	1.7004	
23					1.5238
24	.4877				
Max	1.4746	1.3108	2.3411	1.9433	1.5238
Min	.4877	1.2289	1.6385	1.7004	1.5238
Avg	1.2867	1.2658	1.9229	1.7949	1.5238

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274040 / 33/11KV NEWARE S/SN.

Feeder No / Name : 205 / NEWARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468		.7468	.6535			.7316
2	.7468		.7468	.7468			.7316
3	.7468		.8402	.7468			.823
4	.8402		.9335	.9335			.9145
5	1.0269		1.0269	1.0269			1.0059
6	.9335		1.0829	1.0269			1.0059
10	.5121	.4668			.5487	.6535	
11	.4572	.4668			.4572	.5601	
12	.3734	.3734			.4572		
13	.3734	.3734			.3658		
14	.2801	.3734			.3658	.4668	
15	.4108	.3734			.3292	.5601	
16	.3734	.3734			.3658	.4668	
19		.7468	.7468			.7316	.6535
20		.7468	.7468			.823	.8402
21		.8402	.8402			.823	.724
22		.7468	.8402			.7316	.7468
23		.6535	.6535			.7316	.7468
24	.8078		.7468	.6535			.7316
Max	1.0269	.8402	1.0829	1.0269	.5487	.823	1.0059
Min	.2801	.3734	.6535	.6535	.3292	.4668	.6535
Avg	.6164	.5446	.8293	.8268	.4128	.6548	.8046

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 201 / 11KV SHRI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	1.2955	1.2955	1.448	1.6766	.1524	.1524
2	.1524	1.2955	1.2955	1.3717	1.5242	.1524	.1524
3	.1524	.1524	.1524	.1524	.1524	1.2193	1.5242
4	.1524	.1524	.1524	.1524	.1524	1.3717	1.6766
5	.1524	.1524	.1524	.1524	.1524	1.3717	1.6766
6						1.5242	1.7528
7						1.6766	1.7528
8						1.6766	1.7528
9						1.6766	.9145
10						1.6766	1.6766
19		1.3717	1.448	1.6766	.1524	.1524	.1524
20		1.5242	1.5242	1.6766	.1524	.1524	.1524
21		1.6766	1.6004	1.7528	.1524	.1524	.1524
22		1.6766	1.6004	1.7528	.1524	.1524	.1524
23		1.5242	1.5242	1.6766	.1524	.1524	.1524
24	.1829	1.2955	1.2955	1.5242	1.6766	.1524	.1524
Max	.1829	1.6766	1.6004	1.7528	1.6766	1.6766	1.7528
Min	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Avg	.1575	1.1015	1.0946	1.2124	.5542	.8383	.8716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 202 / 11 KV NARALACHIWADI  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1524	.1524	.1524	.6859	.9907
2	.1524	.1524	.1524	.1524	.1524	.6859	.9602
3	.9907	.1524	.1524	.1524	.1524	.1524	.1524
4	.9907	.1524	.1524	.1524	.1524	.1524	.1524
5	1.0669	.1677	.1524	.1524	.1524	.1524	.1524
6	1.0669						
7	1.1279						
8	1.1584						
9	1.2651						
10	1.2193						
11		1.0669	1.1431				
12		1.0669	1.1431				
13		1.1431	1.2193	1.0669			
14		1.2193	1.2193	1.1431	1.3717		
15		1.2193	1.1431	1.1431	1.2193		
16		1.2955	1.1431	1.2041	1.1431		
17		1.2193	1.1431	1.1888	1.1431		
18		1.2193	1.0669	1.1736	1.1431		
19	.1524	.1524	.1524	.1524	1.1431	.9145	.9145
20	.1524	.0152	.1524	.1524	.9145	1.0212	1.0364
21	.1524	.1524	.1524	.1524	.9145	1.0669	1.0669
22	.1524	.1524	.1524	.1524	.9145	1.0822	1.1126
23	.1524	.1524	.1524	.1524	.7621	1.0822	.9907
24	.1829	.1524	.1524	.1524	.1524	.7621	1.0669
Max	1.2651	1.2955	1.2193	1.2041	1.3717	1.0822	1.1126
Min	.1524	.0152	.1524	.1524	.1524	.1524	.1524
Avg	.6335	.5792	.5735	.5056	.7240	.7053	.7815

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 203 / 11KV NIMGAON VILLAGE  
AG/SDT Feeder KV- 11 /  
OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1524	.1524	.1524	.5335	.6859
2	.1524	.1524	.1524	.1524	.1524	.5335	.6859
3	.6859	.1524	.1524	.1524	.1524	.1524	.1524
4	.6859	.1524	.1524	.1524	.1524	.1524	.1524
5	.7621	.1524	.1524	.1524	.1524	.1524	.1524
6	.7621						
7	.7621						
8	.9145						
9	.9145						
10	.9145	.9907					
11		.7621	.6859				
12		.7621	.7621				
13		.7621	.7621	.6859			
14		.8383	.7621	.7621	.7621		
15		.8383	.6859	.7621	.7621		
16		.7621	.6859	.7621	.6859		
17		.6859	.6859	.6859	.6859		
18		.6859	.6097	.6859	.2743		
19	.1524	.1524	.1524	.1524	.2896	.6859	.6859
20	.1524	.1524	.1524	.1524	.6097	.7621	.7621
21	.1524	.0152	.1524	.1524	.6097	.7621	.8383
22	.1524	.1524	.1524	.1524	.5335	.7621	.8383
23	.1524	.1524	.1524	.1524	.5335	.7621	.7621
24		.1524	.3506	.1524	.1524	.5335	.6859
Max	.9145	.9907	.7621	.7621	.7621	.7621	.8383
Min	.1524	.0152	.1524	.1524	.1524	.1524	.1524
Avg	.4979	.4313	.3955	.3541	.4163	.5265	.5820

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 204 / NIMGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061	.0762	.0762	.061	.061	.061	.0762
2	.0762	.0762	.0762	.0762	.061	.061	.061
3	.0762	.0762	.0762	.0762	.061	.061	.061
4	.0914	.0762	.0762	.0914	.0762	.0762	.061
5	.0914	.0914	.0914	.0914	.0762	.0914	.0914
6	.1067	.1067	.1067	.1067	.0914	.0914	.0914
7	.1067	.0762	.0762	.0762	.0914	.0914	.061
8	.1067	.0762		.0762	.0762	.0762	.061
9	.0762	.061	.0762		.0762	.0762	.061
10	.0762	.061	.0762		.061	.0762	.061
11	.061	.061	.061			.061	.061
12	.061	.061	.061			.061	.0457
13	.061	.0762	.0457	.061		.0457	.0457
14	.0457	.0762	.061	.061	.061	.0457	.0457
15	.0457	.0762	.0457	.061	.061	.061	.0457
16	.061	.0762	.0457	.0762	.061	.061	.061
17	.0762		.0457	.0762	.0762	.061	.0762
18	.0914	.0762	.0762	.0762	.0762	.0762	.0914
19	.0914	.0762	.061	.1067	.0762	.1067	.0914
20	.1067	.0914	.061	.1067	.0762	.1067	.1067
21	.1067	.1067	.0457	.0914	.0762	.0914	.1067
22	.0914	.1067	.0457	.0914	.0762	.0914	.0914
23	.0914	.0914	.0457	.0762	.0762	.0762	.0762
24	.1829	.0762	.0762	.061	.061	.0762	.0762
Max	.1829	.1067	.1067	.1067	.0914	.1067	.1067
Min	.0457	.061	.0457	.061	.061	.0457	.0457
Avg	.0851	.0795	.0656	.0800	.0719	.0743	.0711

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 205 / naganemala

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.1524	.1524	.1524	.1524	.1524	.1524
2	.7621	.1524	.1524	.1524	.1524	.1524	.1524
3	.1524	.8535	.7621	.6859	.7926	.1524	.1524
4	.1524	.9145	.7621	.7621	.8383	.1524	.1524
5	.1829	.9297	.8383	.7621	.8383	.1524	.1524
6		.9602	.8383	.7621	.8078		
7		.9145	.8535	.7621	.9145		
8		.884	.8383	.6859	.9297		
9		.823	.8383	.6859	.9907		
10		.7011	.8383		.9297		
11						.6859	.8535
12				1.0364		.7621	.9297
13						.8383	.9907
14						.8383	.9145
15						.8383	.884
16						.7621	.823
17						.6859	.823
18						.6859	.8078
19	.1524	.1524	.1524	.1524	.1524	.1524	.1524
20	.1524	.0152	.1524	.1524	.0152	.1524	.1524
21	.1524	.1524	.1524	.1524	.1524	.1524	.1524
22	.1524	.1524	.1524	.1524	.1524	.1524	.1524
23	.1524	.1524	.1524	.1524	.1524	.1524	.1524
24		.1524	.1524	.1524	.1524	.1524	.1524
Max	.7621	.9602	.8535	1.0364	.9907	.8383	.9907
Min	.1524	.0152	.1524	.1524	.0152	.1524	.1524
Avg	.2774	.5039	.4868	.4601	.5077	.4091	.4580

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 206 / jay khanderaya

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219	.1219	.1219	.1219	.1219	.6859	.8383
2	.1219	.1219	.1219	.1219	.1219	.6859	.8078
3	.6859	.1219	.1219	.1219	.1219	.1219	.1219
4	.8383	.1219	.1219	.1219	.1219	.1219	.1219
5	.8383	.1219	.1219	.1219	.1219	.1219	.1219
6	.8383						
7	.9297						
8	.9602						
9	.945						
10	.9145						
11		.7621	.9907				
12		.8383	1.0669				
13		.8383	1.0669				
14		.9145	.2134	.9145	1.1431		
15		.9145		1.0517	1.1431		
16		.9145		1.0364	1.1431		
17		.9145		.9907	1.1431		
18		.9145		.9907	1.0669		
19	.1219	.1219		.1219	.9145	.9145	.8383
20	.1219	.1219		.1219	.9145	.9755	.9145
21	.1219	.1219	.1219	.1219	.9145	.9755	.9145
22	.1219	.1219	.1219	.1219	.8383	.9602	.8383
23	.1219	.1219	.1219	.1219	.8383	.9145	.7621
24	.1981	.1219	.1219	.1219	.1219	.7621	.8383
Max	.9602	.9145	1.0669	1.0517	1.1431	.9755	.9145
Min	.1219	.1219	.1219	.1219	.1219	.1219	.1219
Avg	.5001	.4396	.3412	.3953	.6744	.6582	.6471



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 207 / MAULI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	.1524	.1524	.1524	.1524		.1524
2	.9907	.1524	.1524	.1524	.1524	.1524	.1524
3	.1524	.9145	.9145	.9145	.9145	.1524	.1524
4	.1524	.9907	.9907	.9907	.9145	.1524	.1524
5	.1524	.9907	1.0669	1.0669	.9907	.1524	.1524
6		.9907	1.0669	1.0669	.9907		
7		1.0669	1.0669	.9907	1.0669		
8		1.0669	1.0669	.9907	1.0669		
9		1.0669	1.0669	.9907	1.0669		
10			1.0669		1.0669		
11						.8383	.9145
12						.9145	1.0669
13						1.0669	1.0669
14						1.0669	1.0669
15						1.1431	.9907
16						1.1431	.9907
17						1.0669	.9907
18						1.0669	.9907
19	.1524	.0152	.1524	.1524	.1524	.1524	.1524
20	.1524	.1524	.1524	.1524	.1524	.1524	
21	.1524	.1524		.1524	.1524	.1524	.1524
22	.1524	.1524		.1524	.1524	.1524	.1524
23	.1524	.1524	.1524	.1524	.1524	.1524	.1524
24	.2896	.1524	.1524	.1524	.1524	.1524	.1524
Max	.9907	1.0669	1.0669	1.0669	1.0669	1.1431	1.0669
Min	.1524	.0152	.1524	.1524	.1524	.1524	.1524
Avg	.3173	.5446	.6586	.5487	.5811	.5461	.5334

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 208 / KESHAVNAGAR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.1219	.1219	.1219	.1219	.1219	.1219
2	.381	.1219	.1219	.1219	.1219	.1219	.1219
3	.1219	.4877	.4572	.381	.4877	.1219	.1219
4	.1219	.5182	.4877	.381	.4877	.1219	.1219
5	.1219	.5335	.4877	.4572	.4877		.1219
6		.5335	.5335	.4572	.503		
7		.5792	.5335	.4877	.5944		
8		.5944	.4877	.4877	.6401		
9		.5792	.4572	.4877	.6401		
10		.4877	.4572		.6401		
11						.5335	.5335
12						.5792	.6097
13						.6097	.6097
14						.5335	.6097
15						.5335	.6097
16						.4572	.6097
17						.4572	.5335
18						.4268	.4572
19	.1219	.1219	.1219	.1219	.1219	.1219	.1219
20	.1219	.1219	.1219	.1219	.1219	.1219	.1219
21	.1219	.1219	.1219	.1219	.1219	.1219	
22	.1219	.1219	.1219	.1219	.1219	.1219	.1219
23	.1219	.1219	.1219	.1219	.1219	.1219	.1219
24	.3506	.1219	.1219	.1219	.1219	.1219	.1219
Max	.4572	.5944	.5335	.4877	.6401	.6097	.6097
Min	.1219	.1219	.1219	.1219	.1219	.1219	.1219
Avg	.1967	.3305	.3048	.2743	.341	.2972	.3218

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 209 / BALIRAJA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.6859	.6859	.6859	.7926	.1219	.0914
2	.0914	.6401	.6859	.6859	.7621	.0914	.0914
3	.0914	.0914	.0914	.0914	.0914	.6859	.8383
4	.0914	.0914	.0914	.0914	.0914	.7621	.884
5	.0914	.0914	.0914	.0914	.0914	.7621	.9145
6						.8383	.9145
7						.9145	.9297
8						.9145	.9297
9							.9145
10						.945	.884
11	.8383						
12	.884						
13	.9297						
14	.9297						
15	.9145						
16	.9145						
17	.884						
18	.8993						
19	.8535	.7621		.0838	.0914	.0914	.0914
20	.8383	.7621		.8383	.0914	.0914	.0914
21	.7621	.7621	.7621	.8383	.0914	.0914	.0914
22	.7316	.7621	.8383	.7621		.0914	.0914
23	.6859	.7621	.7621	.7621	.0914	.0914	.0914
24	.3506	.6859	.6859	.7621	.7926	.1219	.0914
Max	.9297	.7621	.8383	.8383	.7926	.945	.9297
Min	.0914	.0914	.0914	.0838	.0914	.0914	.0914
Avg	.6249	.5542	.5216	.5175	.2987	.4410	.4963

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274042 / PILIV

Feeder No / Name : 201 / BACHERI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5		.4572				
6		.5639				
9		2.7435				
23	.5335		.503	.4458	.4115	.463
24	1.8595		.4572	.5335	.4287	.4287
Max	1.8595	2.7435	.503	.5335	.4287	.463
Min	.5335	.4572	.4572	.4458	.4115	.4287
Avg	1.1965	1.2549	.4801	.4897	.4201	.4459

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274042 / PILIV

Feeder No / Name : 202 / PILIV SECTION GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.9945				
7				1.3032		
8		.6516				
9		.5658				
23	.6859		.9431	1.1145	.8573	1.2003
24	.6001	.7716	.9259	.9431	1.0288	.8573
<b>Max</b>	<b>.6859</b>	<b>.9945</b>	<b>.9431</b>	<b>1.3032</b>	<b>1.0288</b>	<b>1.2003</b>
<b>Min</b>	<b>.6001</b>	<b>.5658</b>	<b>.9259</b>	<b>.9431</b>	<b>.8573</b>	<b>.8573</b>
<b>Avg</b>	<b>.643</b>	<b>.7459</b>	<b>.9345</b>	<b>1.1203</b>	<b>.9431</b>	<b>1.0288</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274042 / PILIV

Feeder No / Name : 203 / CHANDAPURI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.9145				
7				1.5242		
8		1.2193				
23	.8383		.6859	.8573	.9431	.1886
24	.1981	.9145	.7926	.7621	.9431	1.2003
Max	.8383	1.2193	.7926	1.5242	.9431	1.2003
Min	.1981	.9145	.6859	.7621	.9431	.1886
Avg	.5182	1.0161	.7393	1.0479	.9431	.6945

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274042 / PILIV

Feeder No / Name : 204 / KUSMODE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.3506
Max	.3506
Min	.3506
Avg	.3506

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274042 / PILIV

Feeder No / Name : 205 / SULEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.3506
Max	.3506
Min	.3506
Avg	.3506



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274042 / PILIV

Feeder No / Name : 206 / Garwad

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.0015
Max	.0015
Min	.0015
Avg	.0015

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274042 / PILIV

Feeder No / Name : 207 / Sheri

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					1.5432	
2					1.6975	
6		1.5242				
7				1.9814		
8		1.6766				
23	.6859		.9907		1.2003	1.286
24	.1829	.9145	1.3717		1.6204	1.5432
Max	.6859	1.6766	1.3717	1.9814	1.6975	1.5432
Min	.1829	.9145	.9907	1.9814	1.2003	1.286
Avg	.4344	1.3718	1.1812	1.9814	1.5154	1.4146

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274042 / PILIV

Feeder No / Name : 208 / PILIV (URBAN) GAOTHAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.3963				
7				.3201		
9		.3201				
23	.2591		.3963	.4458	.3772	.4287
24	.381	.3048	.3506	.381	.4115	.3944
Max	.381	.3963	.3963	.4458	.4115	.4287
Min	.2591	.3048	.3506	.3201	.3772	.3944
Avg	.3201	.3404	.3735	.3823	.3944	.4116

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274043 / SALMUKH

Feeder No / Name : 201 / 11KV KALAMWADI.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.1715	1.9528	1.2193	1.9814	1.9052	.1715
2	.2058	.1886	1.8747	1.448	2.0576	1.9814	.1524
3	.2229	.2058	1.7185	1.6766	2.1338	2.1338	.1886
4	.2279	.2229	1.7966	1.9052	2.2862	2.21	.2058
5	.2454	.2401	1.7528	2.5149	2.4387	2.2862	.2229
6	.2572	.2572	1.9052	2.5911	2.5149	2.4387	.2134
7			2.1091	2.6673	2.5911		
8			2.2862	2.8902	2.5911		
9							3.1245
10							3.2579
11							2.8197
12							2.6673
13						2.6673	2.5911
14							2.5149
15							2.4387
16							2.3624
17	3.2579	2.9683					
18	2.8121	2.8121					
19	2.6558	2.6558	.1886	.2572	.1886	.2591	.2229
20	2.4996	2.4996	.1886	.2401	.2058	.2743	.2229
21	2.4291	2.4215	.2058	.2229	.1677	.2572	.1829
22	2.1872	2.4291	.1886	.1886	.1715	.2229	.2058
23	2.0309	2.1872	.1886	.1715	.1886	.2058	.1886
24	.3506	2.0309	2.1052	.1886	.1715	.1715	.1715
Max	3.2579	2.9683	2.2862	2.8902	2.5911	2.6673	3.2579
Min	.2058	.1715	.1886	.1715	.1677	.1715	.1524
Avg	1.3992	1.5208	1.3187	1.2987	1.4063	1.3087	1.2063

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274043 / SALMUKH

Feeder No / Name : 202 / 11KV TANDULWADI FEEDER. SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.6859	.1524	.1829	.1524	.1981	.1524
2	.6097	.7621	.1677	.1677	.1677	.1829	.1677
3	.6859	.7621	.1829	.1829	.1829	.1981	.1829
4	.7621	.8383	.1981	.1981	.2134	.1981	.1981
5	.8383	.9145	.2286	.2134	.2286	.2134	.2286
6	.9145	.9907	.2743	.2286	.2591	.2286	.2743
7	1.0669	1.0669					
8	1.1431	1.0669					
9			.9907		1.0669	.7621	
10			.9145	1.1431	.9907	.6859	
11			.8383	.9145	.9145	.7621	
12			.8383	.7621	.8383	.8383	
13			.9145	.6097	.8383	.7621	
14			.9145	.6097	.7621	.6859	
15			.7621	.5335	.6859	.6859	
16			.7621	.5335	.6097	.6097	
17							1.448
18							1.3717
19	.2134	.1829	.1372	.2591	.1981	.2286	1.2955
20	.1981	.1829	.1524	.2286	.1829	.2134	1.2193
21	.1829	.1677	.1829	.2134	.1677	.1829	1.1431
22		.1524	.1829	.1829	.1677	.1524	1.0669
23	.1677	.1372	.1677	.1829	.1981	.1524	.9907
24	.1372	.1524	.1372	.1524	.1981	.2134	.1372
Max	1.1431	1.0669	.9907	1.1431	1.0669	.8383	1.448
Min	.1372	.1372	.1372	.1524	.1524	.1524	.1372
Avg	.5733	.5759	.4550	.3947	.4512	.4077	.7055

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274043 / SALMUKH

Feeder No / Name : 203 / SALMUKH GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5182	.4268	.4572	.503	.4877	.5792	.4877
2	.5792	.4877	.5182	.6097	.5335	.6097	.5182
3	.6249	.5335	.5639	.6859	.5792	.6401	.5335
4	.6554	.6097	.6097	.7621	.5944	.7011	.6097
5	.7011	.6401	.7164	.7164	.6859	.7316	.6859
6	.7621	.6859	.7926	.6097	.7621	.7621	.8573
7	.6249	.4877	.7011	.5335	.5792	.703	.6249
8	.503	.4268	.4572	.5487	.5487	.442	.5335
9	.4268	.3963	.4572	.4877	.5144	.3506	.3658
10	.442	.4268	.4268	.4572	.442	.3963	.381
11	.4115	.4115	.4115	.4268	.4268	.381	.4268
12	.381	.3201	.3506	.381	.3506	.381	.442
13		.381	.3201	.3429	.3353	.3658	.4115
14	.3201	.3963	.1829		.3353	.3506	.381
15	.3506	.4268	.1981		.3201	.3353	.3506
16	.4268	.4572	.1829	.3506	.3506	.381	.3353
17	.4268	.442	.4572	.4268	.3963	.4115	.3506
18	.442	.3963	.3963	.4572	.4268	.4572	.4115
19	.5639	.5335	.5639	.5792	.6097	.5335	.5182
20	.5182	.6097	.5639	.6097	.6554	.5792	.5487
21	.5792	.5639	.5335	.5639	.6249	.6097	.5639
22	.4725	.4877	.5335	.5335	.5639	.5182	.5335
23	.4268	.4572	.4877	.4725	.5335	.4572	.5182
24	.4877	.381	.4268	.4877	.4572	.5182	.4572
Max	.7621	.6859	.7926	.7621	.7621	.7621	.8573
Min	.3201	.3201	.1829	.3429	.3201	.3353	.3353
Avg	.5063	.4744	.4712	.5248	.5047	.5081	.4936

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274043 / SALMUKH

Feeder No / Name : 204 / Shendechinch  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1406	.1372	.1543	.1543	.1715	.2058	1.5432
2	.1718	.1372	.1715	.1715	.1715	.1886	1.2955
3	.1781	.1543	.1886	.2058	.1677	.1715	1.2193
4	.1875	.6859	.2058	.2401	.1829	.2058	1.1431
5	.1943	.1886	.2229	.2401	.1981	.2229	1.2193
6	.2187	.2058	.2401	.2572	.2401	.2743	1.448
7							1.6004
8		2.3434					1.7528
9	2.0309	2.2653					
10	2.1872						
11	2.1091	2.1872					
12	2.0309	2.1091					
13		2.1872					
14	1.8747	2.1091					
15	1.7185	2.1338					
16	1.6404	2.21					
17			2.7435	2.7435	2.21	2.5911	
18			2.4387	2.5911	2.3624	2.4387	
19	.2031	.2229	2.2862	2.7435	1.9814	2.2862	.2058
20	.2035	.2058	2.21	2.572	1.829	1.9814	.2229
21	.1865	.1886		2.1338	1.6766	1.9052	.2058
22	.1718	.1715	2.2862	1.9814	1.5242	1.6766	.1886
23	.1715	.1543	2.1338	1.8004	1.3717	1.5242	.1886
24	.3506	.1372	.1372	2.2291	1.3717	1.2193	1.448
Max	2.1872	2.3434	2.7435	2.7435	2.3624	2.5911	1.7528
Min	.1406	.1372	.1372	.1543	.1677	.1715	.1886
Avg	.8405	1.0067	1.1861	1.4331	1.1042	1.2065	.9772

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274043 / SALMUKH

Feeder No / Name : 205 / FALAWANI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.1067	.0914	.1524	.1067	.0914	.3048
2	.1067	.1219	.1067	.1829	.1219	.1067	.381
3	.1219	.1219	.1219	.1981	.1372	.1067	.4572
4	.1372	.1372	.1372	.2134	.1524	.1372	.5335
5	.1372	.1372	.1524	.1829	.1829	.1372	.6097
6	.1524	.1524	.1829	.1677	.1524	.1524	.6097
7							.6859
8							.7621
9	.9907	.9145					
10	.9907	.8383					
11	1.0669	.8383					
12	.9907	.6859					
13		.6859					
14	.9145	.6097					
15	.8383	.6859					
16	.8383	.7621					
17			1.2955	1.2193	1.2193	1.2193	
18			1.1431	1.1431	1.1431	1.1431	
19	.1067	.1067	1.0669	.9145	.9145	.9145	.1372
20	.1067	.1219	.9907	.8383	.7621	.6859	.1372
21	.0914	.1219	.9145	.7621	.6859	.5335	.1219
22	.0914	.1067		.6097	.6097	.4572	.1219
23	.0762	.1067	.6859	.5335	.5335	.4572	.1067
24	.0914	.0762	.0914	.5335	.5335	.4572	.3048
Max	1.0669	.9145	1.2955	1.2193	1.2193	1.2193	.7621
Min	.0762	.0762	.0914	.1524	.1067	.0914	.1067
Avg	.4179	.3719	.5370	.5465	.5182	.4714	.3767



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274043 / SALMUKH

Feeder No / Name : 207 / maloli

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669	.8592	.1543	.1372	.1372	.1677	.1372
2	1.1888	.9145	.1715	.1524	.1524	.1886	.1524
3	1.2193	1.0669	.1886	.1677	.1524	.1829	.1677
4	1.2955	1.2193	.2058	.1829	.1829	.1829	.1829
5	1.2955	1.3717	.2229	.1981	.1981	.1981	.2134
6	1.3717	1.448	.2572	.2286	.2286	.1829	.1981
7	1.448	1.5242					
8	1.5242	1.6404					
9			1.9052		1.3717	1.6766	
10			1.9052		1.5242	1.6004	
11			1.829		1.6766	1.5242	
12			1.6766		1.7528	1.3717	
13			1.7528		1.5242		
14			1.6004		1.448		
15			1.448		1.2955		
16			1.2955	2.1434	1.3717	1.2955	
17							1.9814
18							1.7528
19	.2743	.1715	.1715	.2439	.1981	.1981	1.5242
20	.2572	.1886	.1886	.2134	.3353	.1829	1.3717
21		.2058	.2058	.1829	.1829	.1677	1.2955
22	.1886	.1886	.1715	.1524	.1677	.1524	1.2193
23	.1715	.1715	.1715	.1372	.1677	.1524	1.1431
24	.1372	.1372	.1543	.1219	.1219	.1524	.1372
Max	1.5242	1.6404	1.9052	2.1434	1.7528	1.6766	1.9814
Min	.1372	.1372	.1543	.1219	.1219	.1524	.1372
Avg	.8799	.7934	.7838	.3278	.7095	.5634	.8198

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274046 / 33/11KV VELAPUR

Feeder No / Name : 201 / BONDLE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.829	.1524	1.6766	.3048	.3048	.3429	1.9052
2	1.829	1.6766	1.6766	.3048	.3048	.3429	1.9052
3	1.9814	1.829	1.829	.3048	.3048	.3429	1.9814
4	1.9814	1.9814	1.829	.3048	.3048	.3429	2.1338
5	2.1338	2.1338	1.9814	.3048	.3048	.3429	2.21
6	2.1338	2.2862	2.21	.3048	.3048	.3429	2.2862
7	2.2862	2.4387	2.7435				2.8959
8	2.4387	2.4387	2.8197				2.4387
9				1.829	2.4387	2.8959	
10				2.3624	2.5911	2.8959	
11				2.4387		2.9721	
12				2.4387		2.5911	
13				2.2862		2.4387	
14				2.4387		2.4387	
15				2.4387		2.4387	
16				2.4387		2.4387	
19	.3429	.3048	.3048	.3048		.3429	.3048
20	.3429	.3048	.3048	.3048		.3429	.3048
21	.3429	.3048	.3048	.3048		.3429	.3048
22	.3429	.3048	.3048	.3048		.2572	.3048
23	1.6766	1.6766	.3048	.3048		1.829	1.829
24	1.6766	1.6766	1.6766	.3048	.3048	.3429	1.9052
Max	2.4387	2.4387	2.8197	2.4387	2.5911	2.9721	2.8959
Min	.3429	.1524	.3048	.3048	.3048	.2572	.3048
Avg	1.5242	1.3935	1.4262	1.1164	.7959	1.3313	1.6221

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274046 / 33/11KV VELAPUR

Feeder No / Name : 202 / VELAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6097	.6097	.6097	.6859	.6859
2	.6859	.6097	.6097	.6097	.6859	.6859
3	.7716	.6859	.6097	.6097	.6859	.6097
4	.8573	.6859	.6859	.7621	.8573	.7621
5	.9431	.7621	.9145	.9145	1.0288	.8383
6	1.0288	.9145	1.0669	1.0669	1.286	.9145
7	.8573	1.0669	1.0669	.9145	1.286	1.0669
8	.8573	.9145	.9145	.9145	1.2003	.9145
9	.8573	.9145	.7621	.8383	1.0288	.7621
10	.8573	.9145	.7621	.7621		
11	.8573	.7621	.7621	.7621	.9431	.7621
12	.8573	.7621	.7621	.6097	.8573	.7621
13	.8573	.6859	.7621	.6097	.8573	.7621
14	.8573	.6859	.7621	.6097	.8573	.7621
15	.8573	.6097	.7621	.7621	.8573	.7621
16	.7716	.6097	.7621	.7621	.8573	.7621
17	.8573	.6859	.8383	.7621	1.1145	.9145
18	.9431	.7621	.9145	.7621	1.286	.9907
19	1.2003	.8383	.8383	.9145	1.2003	.9907
20	1.1145	1.0669	.7621	1.0669	1.1145	.9145
21	.9431	.9907	.7621	.9907	.8573	.7621
22	.8573	.9145	.6859	.9145	.7716	.6859
23	.7716	.7621	.6097	.7621	.7716	.6097
24	.6859	.6097	.6097	.6097	.8573	.6859
Max	1.2003	1.0669	1.0669	1.0669	1.286	1.0669
Min	.6859	.6097	.6097	.6097	.6859	.6097
Avg	.8680	.7843	.7748	.7875	.9542	.7985

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274046 / 33/11KV VELAPUR

Feeder No / Name : 203 / 11 KV NEVARE  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1524	.1524	1.2193	1.0669	.1524
2	.1715	.1524	.1524	1.2193	1.0669	.1524
3	.1715	.1524	.1524	1.2193	1.2193	.1524
4	.1715	.1524	.1524	1.2193	1.448	.1524
5	.1715	.1524	.1524	1.2193		.1524
6	.1715	.1524	.1524	1.2193	1.9052	.1524
7				1.5242	1.829	
8				1.6004		
9	1.6004	1.5242	1.5242			1.6766
10		1.6766	1.6766			
11	1.7528	1.6766	1.6766			1.5242
12	1.6766	1.5242	1.5242			1.5242
13	.9145	1.448	1.5242			1.448
14	.9145	1.3717	1.448			1.448
15	.6859	1.2193	1.3717			1.448
16	.4572	1.2193	1.3717			1.5242
19	1.7147	.1524	.1524	.1524	.1715	.1524
20	.1715	.1524	.1524	.1524	.1715	.1524
21	.1715	.1524	.1524	.1524	.1715	.1524
22	.1715	.1524	.1524	.1524	.1715	.1524
23	.1715	.1524	1.2193	.9145	.1715	.1524
24	.1715	.1524	.1524	1.0669	1.0669	.1524
Max	1.7528	1.6766	1.6766	1.6004	1.9052	1.6766
Min	.1715	.1524	.1524	.1524	.1715	.1524
Avg	.6107	.6744	.7506	.9308	.8716	.6538

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274046 / 33/11KV VELAPUR

Feeder No / Name : 204 / 11KV NIMGAON  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	1.448	1.5242	.1524	.1715	1.3717
2	.6097	1.448	1.5242	.1524	.1715	1.3717
3	.6097	1.5242	1.5242	.1524	.1715	1.448
4	.6097	1.6004	1.6004	.1524	.1715	1.5242
5	.6097	1.829	1.6766	.1524	.1715	1.829
6	.6097	2.1338	1.829	.1524	.1715	2.1338
7	.4572	2.3624	2.2862	.1524		2.3624
8	.6097	2.2862	2.21			2.2862
9				1.9814	2.4387	
10				2.1338		
11				2.2862	2.3624	
12				2.2862	2.5149	
13				2.1338	2.0576	
14				2.1338	2.3624	
15				2.1338	2.0576	
16				2.1338	2.4387	
17	1.5242					
19	.1715	.1524	.1524	.1543	.1715	.1524
20	.1715	.1524	.1524	.1524	.1715	.1524
21	.1715	.1524	.1524	.1524	.1715	.1524
22	.1715	.1524	.1524	.1524	.1715	.1524
23	1.3717	1.5242	.1524	.1524	1.3717	1.5242
24	.6097	1.448	1.5242	.1524	.1715	1.3717
Max	1.5242	2.3624	2.2862	2.2862	2.5149	2.3624
Min	.1715	.1524	.1524	.1524	.1715	.1524
Avg	.5995	1.3010	1.1758	.9146	1.0258	1.2738

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274046 / 33/11KV VELAPUR

Feeder No / Name : 205 / TANDULWADI  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2146	1.0669	.9145	.1524	.1715	1.0669
2	1.2955	1.0669	.9145	.1524	.1715	1.0669
3	1.2955	1.1431	1.0669	.1524	.1715	1.2193
4	1.3765	1.2193	1.2193	.1524	.1715	1.3717
5	1.3765	1.3717	1.3717	.1524	.1715	1.3717
6	1.4575	1.5242	1.448	.1524	.1715	1.5242
7		1.5242	1.829			1.9814
8		1.5242	1.829			1.829
9				1.6004	1.9814	
10				1.829	1.6766	
11				1.6766	1.829	
12				1.6766	1.6766	
13				1.6766	1.5242	
14	1.6194			1.6766	1.3717	
15				1.6766	1.5242	
16				1.5242	1.5242	
19	.1715	.1524	.1524	.1524	.1715	.1524
20	.1715	.1524	.1524	.1524	.1715	.1524
21	.1715	.1524	.1524	.1524	.1715	.1524
22	.1715	.1524	.1524	.1524	.1715	.1524
23	1.0669	.9145	.1524	.1524	1.0669	1.0669
24	1.0669	1.0669	.9145	.1524	.1715	1.0669
Max	1.6194	1.5242	1.829	1.829	1.9814	1.9814
Min	.1715	.1524	.1524	.1524	.1715	.1524
Avg	.9581	.9308	.8764	.7583	.8031	1.0125

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274046 / 33/11KV VELAPUR

Feeder No / Name : 206 / BHAKAREWADI  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1524	.1524	1.0669	1.0669	.1524
2	.1715	.1524	.1524	1.0669	1.0669	.1524
3	.1715	.1524	.1524	1.2193	1.2193	.1524
4	.1715	.1524	.1524	1.2193	1.2193	.1524
5	.1715	.1524	.1524	1.3717	1.2955	.1524
6	.1715	.1524	.1524	1.3717	1.3717	.1524
7				1.6766	1.5242	
8				1.7528	1.829	
9	1.6194	1.5242	1.6004			1.6004
10	1.5242	1.6766	1.6766			
11	1.6004	1.5242	1.6766			1.7528
12	1.5242	1.5242	1.5242			1.6766
13	1.5242	1.3717	1.5242			1.6004
14	1.3717	1.2193	1.448			1.5242
15	1.3717	1.2193	1.448			1.5242
16	1.448	1.2955	1.3717			1.6004
19	.1715	.1524	.1524	.1524	.1715	.1524
20	.1715	.1524	.1524	.1524	.1715	.1524
21	.1715	.1524	.1524	.1524	.1715	.1524
22	.1715		.1524	.1524	.1715	.1524
23	.1715	.1524	.8383	.9907	.1715	.1524
24	.1715	.1524	.1524	.9145	1.0669	.1524
Max	1.6194	1.6766	1.6766	1.7528	1.829	1.7528
Min	.1715	.1524	.1524	.1524	.1715	.1524
Avg	.7021	.6859	.7392	.9471	.8941	.6899

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274046 / 33/11KV VELAPUR

Feeder No / Name : 207 / UGHDEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1524	.1524	.6859	.6097	.6097	.1524
2		.1524	.1524	.6097	.6097	.6097	.1524
3		.1524	.1524	.7621	.6097	.6097	.1524
4		.1524	.1524	.7621	.6097	.6859	.1524
5		.1524	.1524	.7621	.6097	.7621	.1524
6		.1524	.1524	.7621	.7621	.9145	.1524
7				.9907	1.0669	1.0669	
8				1.0669	1.0669	1.2193	
9		1.2193	.7621				.9145
10		1.2955	1.1431				
11	1.0669	1.2193	1.1431				.9145
12	1.1336	1.1431	.9907				.9907
13	1.0669	1.0669	.8383				.9145
14	.9145	1.0669	.7621				.8383
15	.9145	1.0669	.7621				1.6766
16	.9145	.9907	.6859				1.6766
19	.1715	.1524	.1524	.1524	.1524	.1715	.1524
20	.1715	.1524	.1524	.1524	.1524	.1715	.1524
21	.1715	.1524	.1524	.1524	.1524	.1715	.1524
22	.1715	.1524	.1524	.1524	.1524	.1715	.1524
23	.1715	.1524	.6097	.4572	.6097	.1715	.1524
24		.1524	.1524	.6097	.6097	.6097	.1524
Max	1.1336	1.2955	1.1431	1.0669	1.0669	1.2193	1.6766
Min	.1715	.1524	.1524	.1524	.1524	.1715	.1524
Avg	.6244	.5449	.4687	.5770	.5552	.5675	.5134



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274046 / 33/11KV VELAPUR

Feeder No / Name : 208 / NAGTHANA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1524	.1524	1.3717	1.2955	.1524
2	.1715	.1524	.1524	1.3717	1.2955	.1524
3	.1715	.0152	.1524	1.5242	1.2955	.1524
4	.1715	.1524	.1524	1.5242	1.3717	.1524
5	.1715	.1524	.1524	1.6004	1.3717	.1524
6	.1715	.1524	.1524	1.6766	1.3717	.1524
7				2.2862	1.6766	
8				1.829	1.829	
9	1.829	1.829	1.829			1.829
10		1.7528	1.9814			
11	1.9814	1.6766	1.9814			1.6766
12	1.9814	1.6004	1.829			1.829
13	1.9814		1.7528			1.7528
14	1.829	1.5242	1.6766			1.6766
15	1.829	1.3717	1.5242			
16	1.829	1.3717	1.448			
19	.1715	.1524	.1524		.1715	.1524
20	.1715	.1524	.1524		.1715	.1524
21	.1715	.1524	.1524		.1715	.1524
22	.1715	.3048	.1524		.1715	.1524
23	.1715	.1524	1.2193		.1715	.1524
24	.381	.1524	.1524	1.3717	1.2955	.1524
Max	1.9814	1.829	1.9814	2.2862	1.829	1.829
Min	.1715	.0152	.1524	1.3717	.1715	.1524
Avg	.8172	.6827	.8459	1.6173	.9757	.6231

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274088 / SHRIPUR

Feeder No / Name : 201 / SHRIPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2572	.3506			.3506	.362
2	.5144	.4287	.3506			.3506	.3658
3	.5144	.5144	.5258			.5258	.4525
4	.5144	.5144	.7011			.7011	.543
5	.5144	.6001	.7011			.7011	.7316
9	.3429						
10	.362	.2572		.3506	.3506	.3429	.7011
11	.2743	.2572		.2629		.2572	.2629
12	.2715	.2572		.2629			.2629
13	.2743	.3429		.2629			.2629
14	.2715	.3429		.2629		.1715	.2629
15	.2772	.3429		.2629		.1715	.2629
16	.2572	.2572		.2629		.181	.2629
20	.5144	.7011	.2572		.7011	.7316	.2572
21	.5144	.7011	.2572		.5258	.5544	.2572
22	.4287	.5258	.2572		.4382	.4572	.3429
23	.3429	.3506			.3506	.3658	.2572
24	.3429	.2572	.3506			.3506	.362
Max	.5144	.7011	.7011	.3506	.7011	.7316	.7316
Min	.2572	.2572	.2572	.2629	.3506	.1715	.2572
Avg	.3819	.4064	.4168	.2754	.4733	.4142	.3653

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274088 / SHRIPUR

Feeder No / Name : 202 / MAHALUNG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	2.13			.0876	.0876
2	.0857	.0857	2.0481			.0876	.0876
3	.0857	.0857	2.0481			.0876	.0876
4	.0857	.0857	2.0481			.0876	.0876
5	.0857	.0857	2.0481			.0876	.0876
6			2.13				
7			2.2939				
8			2.5396				
9		2.4387				2.8673	
10	3.0045	2.5911				2.8959	
11	2.8464	2.4387				3.0483	3.0312
12	2.8807	2.4387					2.9492
13	2.8464	2.4387		.0876			2.9492
14	2.8464	2.4387		.0876		2.5911	2.9492
15	2.8464	2.4387		.0876		2.8959	2.9492
16	2.7435	2.5149		.0876		3.0045	2.9492
20	.0857	.0876	.0857		.0876	.0876	.0857
21	.0857	.0876	.0857		.0876	.0876	.0857
22	.0857	.0876	.0857		.0876	.0876	.0857
23	.0857	2.13			.0876	.0876	.0857
24	.3506	.0857	2.13			.0876	.0876
Max	3.0045	2.5911	2.5396	.0876	.0876	3.0483	3.0312
Min	.0857	.0857	.0857	.0876	.0876	.0876	.0857
Avg	1.2433	1.2581	1.6394	.0876	.0876	1.1362	1.1654

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274088 / SHRIPUR

Feeder No / Name : 203 / UMBARE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6097	.0876			.6554	.6401
2	.6859	.6097	.0876			.6554	.6478
3	.6859	.6097	.0876			.6554	.6325
4	.6859	.6097	.0876			.6554	.6478
5	.6097	.6097	.0876			.6554	.6325
6	.9145	.6859				.7373	.6401
7	.9145	.7621				.9012	.8697
8	.9145	.7621				.9012	.8002
9			.8192				
10				.7373			
11				.7373			
12				.7373			
13	.0876	.0857		.7373			.0876
14	.0876	.0857		.7373		.0857	.0876
15	.0876	.0857		.7373		.0857	.0876
16	.0857	.0857		.7373		.0876	.0876
20	.0857	.0876	.0857		.0876	.0876	.0857
21	.0857	.0876	.0857		.0876	.0876	.0857
22	.0857	.0876	.0857		.0876	.0876	.0857
23	.6097	.0876			.6554	.6325	.5335
24	.6097	.6097	.0876			.6554	.6401
Max	.9145	.7621	.8192	.7373	.6554	.9012	.8697
Min	.0857	.0857	.0857	.7373	.0876	.0857	.0857
Avg	.4615	.3860	.1602	.7373	.2296	.4767	.4289

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274088 / SHRIPUR

Feeder No / Name : 204 / CHAUKI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	1.6004	.1753			1.4746	1.4403
2	1.448	1.6004	.1753			1.4746	1.4575
3	1.448	1.6004	.2629			1.4746	1.4575
4	1.448	1.6004	.2629			1.4746	1.4232
5	1.448	1.6004	.2629			1.4746	1.4403
6	1.6766	1.6004				1.4746	1.4403
7	1.829	1.829				1.8023	1.5813
8	1.6766	1.829				1.8842	1.5813
9			1.9662				
10				1.9662			
11				1.9662			
12				1.9662			
13	.1227	.1715		1.8842			.0876
14	.1753	.1715		1.8842			.1753
15	.1227	.1715		1.9662		.1372	.1753
16	.1029	.1715		1.9662		.1227	.1753
20	.1372	.1753	.1715		.1753	.1753	.1715
21	.1715	.1753	.1715		.1753	.1753	.1715
22	.1715	.1753	.1715		.1753	.1402	.1715
23	1.6004	.1753			1.5565	1.4403	1.5242
24	1.5242	1.6004	.1753			1.4746	1.5023
Max	1.829	1.829	1.9662	1.9662	1.5565	1.8842	1.5813
Min	.1029	.1715	.1715	1.8842	.1753	.1227	.0876
Avg	.9780	.9558	.3795	1.9428	.5206	1.0800	.9398

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274088 / SHRIPUR

Feeder No / Name : 205 / MALEWADI AG/SDT

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.0857	1.4746			.0876	.0876
2	.1715	.1029	1.3927			.0876	.0876
3	.1715	.1029	1.3927			.1753	.1227
4	.1715	.1372	1.3927			.1753	.1402
5	.1715	.1715	1.3927			.1753	.1578
6			1.3927				
7			1.8023				
8			1.6385				
9	1.829	1.829				1.8842	1.8976
10	1.6804	1.829				1.829	2.13
11	1.7394	1.7528				1.829	2.0481
12	1.6604	1.7528					1.9662
13	1.6604	1.6766		.0876			1.7204
14	1.6804	1.6766		.0876		1.6766	
15	1.6604	1.6766		.0876		1.829	1.6385
16	1.6766	1.6004		.0876		2.0005	1.8023
20	.12	.1753	.0857		.0876	.1227	.0857
21	.12	.1753	.0857		.0876	.1227	.0857
22	.0857	.0876	.0857		.0876	.1227	.0857
23	.0857	1.6385			.0876	.1063	.0857
24	.0857	.0857	1.4746			.0876	.0876
Max	1.829	1.829	1.8023	.0876	.0876	2.0005	2.13
Min	.0857	.0857	.0857	.0876	.0876	.0876	.0857
Avg	.8301	.9198	1.1342	.0876	.0876	.7695	.8370

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274088 / SHRIPUR

Feeder No / Name : 206 / Borgaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	.9431	.964			.964	1.0164
2	1.3717	1.286	.964			.964	1.0059
3	1.5432	1.4575	1.2269			1.2269	1.2136
4	1.6289	1.6289	1.4022			1.4022	1.3717
5	1.6289	1.7147	1.6651			1.5775	1.5708
9	1.0288						
10	.823	1.1145		1.0517		1.1145	1.0517
11	.8316	1.0288		.964		1.0288	.8764
12	.7392			.8764			.7888
13	.7316	.7716		.7011			.7888
14	.7316	.6001				.9431	.7011
15	.6401	.6859		.8764		.8573	.7011
16	.6859	.7716		.8764		.9145	.7011
20	1.4575	1.5775	1.3717	1.4575	1.5775	1.4937	1.3717
21	1.3717	1.4022	1.3717		1.4022	1.2936	1.286
22	1.286	1.2269	1.286		1.2269	1.2012	1.1145
23	1.0288	1.0517			1.0517	1.1088	1.0288
24	1.0288	.9431	.964			.964	1.0059
Max	1.6289	1.7147	1.6651	1.4575	1.5775	1.5775	1.5708
Min	.6401	.6001	.964	.7011	1.0517	.8573	.7011
Avg	1.1072	1.1378	1.2462	.9719	1.3146	1.1369	1.0350

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274088 / SHRIPUR

Feeder No / Name : 207 / Mundafane Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.6859				.9012	.8697
2	.7621	.6859				.8192	.8907
3	.8383	.6859				.8192	.8802
4	.8383	.6859				.8192	.8697
5	.7621	.6859				.9012	.8907
6	.8383	.6859				.9012	.9488
7	.8383	.7621				1.065	.8802
8	.8383	.7621				1.065	.9488
9			.9012				
10				.8192			
11				.9831			
12				.9831			
13				.9831			
15				.9831			
16				.9831			
23	.8383				.8192	.8002	.9145
24	.7621	.7621				.9012	.8802
Max	.8383	.7621	.9012	.9831	.8192	1.065	.9488
Min	.7621	.6859	.9012	.8192	.8192	.8002	.8697
Avg	.8078	.7113	.9012	.9558	.8192	.8993	.8974



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274102 / KHALAVE

Feeder No / Name : 201 / 11 KV TAMKHEDA AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2346		.0914		.0914	
2		1.2041		.0914		.0914	
3		1.1736		.0914		.0914	
4		1.2955		.0914		.1219	
5		1.3565		.1067		.1524	
6		1.448		.1524		.1829	
7		1.5242		.1829		.1524	
8		1.5851		.1677		.1829	
9		.1524		1.5699		1.5699	
10	.1067			1.6156	1.1431		.1219
11	.0914			1.5242	1.5394		.1067
12	.1067				1.5699		.1067
13	.1219				1.6004		.1067
14	.1372				1.6004		.1067
15	.1067				1.5546		.1067
16	.1067				1.5089		.0914
17	.0914		.1067		.0914		.0914
18	.0914		.1219		.1067		.1067
19	.1219		.1372		.1219		.1372
20	.1372		.1524		.1372		.1219
21	.1524		.1219		.1219		.1219
22	.1219		.1219		.1219		.1067
23	1.2041		.1067		.1067		1.4022
24	.2286	1.2651		.0914		.0914	
Max	1.2041	1.5851	.1524	1.6156	1.6004	1.5699	1.4022
Min	.0914	.1524	.1067	.0914	.0914	.0914	.0914
Avg	.1951	1.2239	.1241	.4814	.8089	.2728	.2025

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274102 / KHALAVE

Feeder No / Name : 202 / 11 KV TONDLE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.7223		.1524		.1524	
2		1.6918		.1372		.1372	
3		1.6156		.1219		.1219	
4		1.7223		.1067		.1524	
5		1.9052		.1524		.1829	
6		2.0576		.1981		.2134	
7		2.2558		.2439		.2591	
8		2.2405		.3048		.2743	
9		.1981		2.1491		2.5301	
10				2.4844	2.5606		.2286
11	.1219			2.5453	2.5453		.2134
12	.1372				2.5758		.1981
13	.1067				2.6063		.1981
14	.1372				2.6673		.1829
15	.1219				2.6978		.1829
16	.1219				2.6825		.1981
17	.1372		.1829		.1524		.1981
18	.1829		.1981		.1829		.2134
19	.2134		.2134		.2591		.2286
20	.2439		.2439		.2896		.2286
21	.1981		.2286		.2591		.2439
22	.1829		.1981		.2286		.2134
23	1.6918		.1829		.1829		2.0271
24	.3506	1.7528		.1677		.1677	
Max	1.6918	2.2558	.2439	2.5453	2.6978	2.5301	2.0271
Min	.1067	.1981	.1829	.1067	.1524	.1219	.1829
Avg	.2820	1.7162	.2068	.7303	1.4207	.4191	.3397

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274102 / KHALAVE

Feeder No / Name : 203 / 11 KV KHALAVE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0152		.0457		.0914	
2		.0152		.0457		.0914	
3		.0152		.0457		.0914	
4		.0152		.061		.0914	
5		.0152		.0762		.0914	
6		.0152		.0914		.0914	
7		.0152		.1067		.1219	
8		.0152		.1067		.1372	
9		.0762		.0152		.0152	
10	.0762			.0152	.0152		.1219
11	.0914			.0152	.0152		.1372
12	.0914				.0152		.1219
13	.0457				.0152		.1067
14	.0762				.0152		.1067
15	.0762				.0152		.0914
16	.0762				.0152		.1067
17	.0152		.0152		.0152		.0152
18	.0152		.0152		.0152		.0152
19	.0152		.0152		.0152		.0152
20	.0152		.0152		.0152		.0152
21	.0152		.0152		.0152		.0152
22	.0152		.0152		.0152		.0152
23	.0152		.0305		.0762		.0152
24	.3506	.0152		.0457		.0914	
Max	.3506	.0762	.0305	.1067	.0762	.1372	.1372
Min	.0152	.0152	.0152	.0152	.0152	.0152	.0152
Avg	.0660	.0213	.0174	.0559	.0196	.0914	.0642

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274102 / KHALAVE

Feeder No / Name : 204 / 11 KV SHERI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0914		1.6004		1.7985	
2		.0914		1.5242		1.7528	
3		.0914		1.448		1.7223	
4		.1067		1.4175		1.7833	
5		.1219		1.6613		1.829	
6		.1372		1.9052		1.8595	
7		.1524		2.0119		2.0424	
8		.1219		1.9204		2.1948	
9		1.9814		.0914		.0914	
10	1.9204			.0914	.0914		2.3167
11	1.829			.0762	.061		2.2558
12					.061		2.3777
13	1.89				.061		2.3472
14	2.0119				.061		2.3624
15	1.9814				.061		2.3777
16	1.9509				.061		2.3929
17	.0305		.0914		.061		.0914
18	.0305		.1067		.0762		.1067
19	.0914		.1219		.0914		.1067
20	.1219		.1372		.1219		.1219
21	.1372		.0914		.0914		.1219
22	.0914		.0914		.0914		.1067
23	.0914		1.5242		1.7375		.0914
24	.3506	.0914		1.6766		1.829	
Max	2.0119	1.9814	1.5242	2.0119	1.7375	2.1948	2.3929
Min	.0305	.0914	.0914	.0762	.061	.0914	.0914
Avg	.8949	.2987	.3092	1.2854	.1949	1.6903	1.2269

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274102 / KHALAVE

Feeder No / Name : 205 / 11 KV BONDALÉ GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1677		.1829		.1981	
2		.1524		.1677		.1829	
3		.1372		.1524		.1524	
4		.1524		.1524		.2286	
5		.1981		.1981		.2743	
6		.2286		.2743		.3353	
7		.2439		.3201		.3201	
8		.2134		.2743		.3353	
9		.1829		.3048		.2439	
10	.3963			.3353	.3353		.2743
11	.381			.2286	.2439		.3201
12	.1677				.2134		.1829
13	.1219				.1677		.1677
14	.1067				.1524		.1524
15	.0914				.1372		.1372
16	.1219				.1219		.1372
17	.1677		.1981		.1524		.1219
18	.1677		.2134		.1981		.1524
19	.2134		.2286		.2439		.1981
20	.3048		.2591		.2743		.2591
21	.3506		.2439		.3201		.3048
22	.4115		.3963		.4115		.3658
23	.1981		.2134		.2286		.2286
24	.3963	.1829		.1981		.2134	
Max	.4115	.2439	.3963	.3353	.4115	.3353	.3658
Min	.0914	.1372	.1981	.1524	.1219	.1524	.1219
Avg	.2398	.1860	.2504	.2324	.2286	.2484	.2145

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274127 / UMBARE(VELAPUR)

Feeder No / Name : 201 / HANUMAN MANDIR GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-AUG-17
HR	Load (MW)
24	.1829
Max	.1829
Min	.1829
Avg	.1829

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274127 / UMBARE(VELAPUR)

Feeder No / Name : 202 / UMBARE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0949		.0983	
2	.1107		.0819	
3	.1147		.0949	
4	.1326		.1147	
5	.1326		.1147	
9				2.0005
10				2.0485
11				2.1125
12				2.2085
13				2.1605
14				2.1605
15				2.2725
16				2.0005
20		.0819		
21		.0983		
22		.0819		
23		.0819		
24	.0937		.0983	
Max	.1326	.0983	.1147	2.2725
Min	.0937	.0819	.0819	2.0005
Avg	.1132	.086	.1005	2.1205

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274127 / UMBARE(VELAPUR)

Feeder No / Name : 203 / MIRE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2929		1.6385	
2	1.3565		1.8023	
3	1.3592		1.9662	
4	1.3603		1.9662	
5	1.4089		2.0481	
6	1.4586		2.0481	
7	1.4918		2.13	
8	1.5249		2.2119	
13				.1311
14				.1311
15				.1475
16				.1802
20		.1134		
21		.1296		
22		.1457		
23		1.6194		
24	1.1717		1.6004	
Max	1.5249	1.6194	2.2119	.1802
Min	1.1717	.1134	1.6004	.1311
Avg	1.3805	.5020	1.9346	.1475



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274127 / UMBARE(VELAPUR)

Feeder No / Name : 204 / 11KV ANUSEWASTI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8233		1.5813	
2	1.5604		1.7394	
3	1.7004		1.8185	
4	1.7238		1.8185	
5	1.6194		1.8976	
6	1.7814		1.8976	
7	1.8461		1.8976	
8	2.2218		1.9766	
13				.0633
14				.0633
15				.0633
16				.0949
20		.0791		
21		.0791		
22		.0633		
23		1.5023		
24	1.8233		1.5813	
Max	2.2218	1.5023	1.9766	.0949
Min	1.5604	.0633	1.5813	.0633
Avg	1.7889	.4310	1.8009	.0712

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274127 / UMBARE(VELAPUR)

Feeder No / Name : 205 / 11KV THITWASTI FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	07-AUG-17
HR	Load (MW)
9	1.6872
10	1.7185
11	1.7966
12	1.7966
13	1.7966
14	1.781
15	1.7185
16	1.7341
<b>Max</b>	<b>1.7966</b>
<b>Min</b>	<b>1.6872</b>
<b>Avg</b>	<b>1.7536</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274153 / Vitthalwadi

Feeder No / Name : 201 / MALKHAMBI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.2058	1.448	1.6004	1.6766	1.5242	.2058
2	.1334	.1715	1.6004	1.6004	1.6004	1.5242	.1715
3	.1524	.1715	1.6766	1.7528	1.6766	1.5242	.2572
4	.1524	.2058	1.7528	1.7528	1.7528	1.7071	.2058
5	.1524	.3429	1.6766	1.7528	1.829	1.5242	.2229
6	.2286	.2058	1.7528	1.829	1.7528	1.7071	.2601
7	.1524	.1715	1.7528	1.829	1.5394	1.7223	
8	.1524	.3429	1.7985	1.829	1.829	1.7528	.2058
9	2.2291	1.9357	.1715	.1715	.2229	.1715	1.8519
10	1.9814	1.4022	.1715	.1715	.0857	.1715	2.0576
11	1.5242	1.6004	.1715		.0857	.1715	1.8861
12	1.829	1.7528	.1715	.1715	.1715	.2058	2.0748
13	1.9052	1.7528	.1715	.1715	.1372	.2058	2.0748
14	1.829	1.829	.1715	.1715	.1372	.2058	1.9033
15	1.9052	1.9052		.1715	.0857	.2058	1.9204
16	1.9052	1.9052	.1715	.1715	.1715	.1715	1.869
17	.1715		.1715	.1715	.2058	.1715	.1677
18	.1715	.1372	.2058	.2572	.2743	.2572	.2286
19	.2058	.1372	.2572	.2058	.2401	.2572	.2439
20	.2058	.1372	.2058	.1715	.1886	.2572	.2286
21	.1715	.1715	.2572	.1715	.1886	.2572	.1981
22	.1715	.1715	.2058	.1715	.1715	.2401	.1829
23	.2058	1.5242	1.5242	1.6004	1.5242	.2229	.1829
24	.1334	.1715	1.5242	1.5242	1.6004	1.5242	.2058
Max	2.2291	1.9357	1.7985	1.829	1.829	1.7528	2.0748
Min	.1334	.1372	.1715	.1715	.0857	.1715	.1677
Avg	.7426	.7979	.8266	.8444	.7978	.7368	.8176

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274153 / Vitthalwadi

Feeder No / Name : 202 / GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0667	.1715	.1372		.0857	.0857	.1372
2	.0667	.1372	.1372	.0857	.1372	.0857	.1543
3	.0667	.0857	.1372	.0857	.0857	.1372	.1372
4	.0667	.0857	.0857	.0857	.0857	.1372	.1543
5	.1524	.1372	.0857	.1715	.0857	.0857	.1715
6	.1334	.1372	.0857	.1715	.0857	.1372	.1715
7	.1524	.1715	.1372	.1372	.1715	.1715	.1715
8	.1524	.0857	.1372	.1372	.0857	.1372	.1715
9	.0762	.0857	.0857	.1372		.1372	.12
10	.0857	.0857	.0857	.1372	.0857	.1372	.1029
11	.0857	.0857	.1372		.0857	.1372	.0857
12	.0857	.1372	.0857	.1372	.0857	.1372	.0857
13	.1372	.0857	.0857	.1372	.0857	.1372	.0857
14	.1372	.0857	.0857	.1372	.0857	.1372	.1372
15	.0857	.0857		.1372	.1372	.1372	.0857
16	.1372	.0857	.0857	.0857	.1372	.1372	.0857
17	.0857	.0857	.0343	.0857	.1372	.0857	.0857
18	.1372	.0857	.1372	.0857	.1372	.0857	.0857
19	.1372	.0857	.1372	.0857	.0857	.1372	.1372
20	.1715	.0857	.0857	.1715	.0857	.1715	.1372
21	.1715	.0857	.0857	.1715	.12	.12	.0857
22	.1372	.0857	.0857	.0857	.12	.0857	.0857
23	.1372	.0857	.0857	.1372	.12	.1372	.0857
24	.0667	.1372	.0857	.0857	.1372	.1372	.1372
Max	.1715	.1715	.1372	.1715	.1715	.1715	.1715
Min	.0667	.0857	.0343	.0857	.0857	.0857	.0857
Avg	.1138	.1036	.1014	.1224	.1073	.1265	.1207

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274153 / Vitthalwadi

Feeder No / Name : 203 / MALEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9719	1.9052	.3086	.3429	.3429	.3429	1.9719
2	1.8861	1.829	.3772	.3429	.3772	.4287	1.9719
3	1.6766	2.21	.3429	.3772	.4115	.4287	1.829
4	1.8861	2.1338	.5487	.4287	.3429	.5144	1.6766
5	1.9719	2.21	.5144	.3772	.3772	.4287	1.8861
6	2.0576	2.21	.5487	.4801	.4287	.5144	1.6766
7	2.21	2.2862	.5487	.5144	.5144	.5144	1.6766
8	2.6578	2.2862	1.5432	.5487	.4287	.5144	2.2862
9	.2286	.3086	2.0576	2.0576	1.9814	2.2862	.2286
10	.2572	.2058	2.21	2.21	2.2862	2.4387	.3048
11	.2058	.2058	2.3624	2.21	2.6673	2.21	.2286
12	.2572	.2058	1.5242	2.3624	2.7435	2.3624	.1524
13	.2058	.1715	2.4387	2.2862	2.2862	2.2405	.1524
14	.2058	.1715	2.1033	2.21	2.2405	2.1643	.1981
15	.1715	.2572	2.1643	2.21	2.3472	2.3015	.2286
16		.2572		2.1338	2.3777	2.3167	.2134
17	.2572		.3429	.2572	.3086	.1715	.2286
18	.3429	.2058	.3772	.2572	.3772	.3429	.3201
19		.2058	.4458	.3944	.4115	.4287	.1981
20	.4287	.1715	.4287	.4287	.5316	.4287	.381
21	.4115	.2058	.4287	.3429	.4287	.3944	.4572
22	.3429	.3601	.3429	.3772	.3429	.2915	.2743
23	1.829	.3429	.2572	.2572	.3772	1.7528	1.8595
24	1.7528	1.829	.2572	.2572	.2572	.3429	1.9719
Max	2.6578	2.2862	2.4387	2.3624	2.7435	2.4387	2.2862
Min	.1715	.1715	.2572	.2572	.2572	.1715	.1524
Avg	1.0552	.9641	.9771	.9860	1.0495	1.0900	.9322

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274153 / Vitthalwadi

Feeder No / Name : 204 / KAWADE FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.5394	.0857	.0857	.0857	.0857	1.5604
2	1.2193	1.5242	.1372	.0857	.0857	.0857	1.5947
3	1.2193	1.3717	.0857	.0857	.0857	.0857	1.5432
4	1.2955	1.448	.0857	.0857	.0857	.12	1.5432
5	1.3717	1.6766	.0857	.0857	.0857	.0857	1.6975
6	1.5242	1.7528	.1372	.0857	.0857	.0857	1.6766
7	1.8861	1.7528	.1372	.1372	.0857	.0857	1.9719
8	1.9719	1.7528	.0857	.1372	.0857	.0857	2.0576
9	.0762	.1372	1.7528	1.6461	1.7528	1.829	.1524
10	.0857	.1372	1.6766	1.7528	1.7071	1.829	.1829
11	.0857	.0857	1.7528	1.829	1.9052	1.6766	.1524
12	.0857	.1372	1.7528	1.829	1.9357	1.7528	.1219
13	.1372	.0857	1.7528	1.829	1.9814	1.9814	.0762
14	.0857	.0857	1.6766	1.7528	1.829	1.768	.0762
15	.1372	.1372	1.3717	1.7528	1.829	1.6156	.0762
16	.0857	.1372	1.4175	1.829	1.7985	1.8442	.0762
17	.1372	.0857	.0857	.1372	.0857	.1543	.0762
18	.1372	.0857	.0857	.0857	.1372	.1372	.0667
19	.0857	.0857	.1372	.0857	.1372	.1543	.0762
20	.1715	.1372	.0857	.0857	.1372	.1543	.1219
21	.1372	.0857	.1372	.1372	.1372	.1543	.1219
22	.1372	.0857	.1372	.0857	.0857	.1372	.1372
23	1.2955	.0857	.1372	.0857	.0857	1.3717	1.6289
24	1.3717	1.2955	.0857	.1372	.1372	.0857	1.5432
Max	1.9719	1.7528	1.7528	1.829	1.9814	1.9814	2.0576
Min	.0762	.0857	.0857	.0857	.0857	.0857	.0667
Avg	.6713	.6545	.6202	.6604	.6820	.7236	.7638

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274153 / Vitthalwadi

Feeder No / Name : 205 / VITTHALWADI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3429	1.6004	1.6766	1.829	1.6004	.4877
2	.3048	.3772	1.7528	1.7528	1.9052	1.6004	.4725
3	.3048	.3429	1.829	1.829	1.9052	1.6004	.4877
4	.381	.2572	1.7528	1.9052	1.9052	1.6766	.4877
5	.381	.4287	1.9052	1.829	1.829	1.6004	.5792
6	.381	.3429	1.7528	1.7528	1.829	1.6766	.5792
7	.381	.4287	1.829	1.9052	1.9814	1.9052	.6097
8	.381	.3429	1.9814	1.829	1.9814	1.829	.4572
9	2.3148	1.9814	.1715	.2058	.2743	.2572	2.2291
10	2.2862	2.2862	.2058	.2058	.4115	.3429	2.3663
11	2.21	2.21	.2572	.1715	.4458	.2743	2.7263
12	2.21	2.21	.3429	.1715	.4801	.5144	2.7435
13	2.2862	2.1338	.3429	.1715	.5316	.2229	2.7435
14	2.1338	2.1338	.3429	.1715	.5487	.5487	2.572
15	2.21	2.21		.3429	.6001	.583	2.6578
16	2.21	2.1338		.3429	.6859	.6173	2.6578
17	.4287	.2058		.3429	.6859	.6859	.2439
18	.4287	.1715		.4287	.6859	.6344	.3258
19	.4801	.1715	.2058	.5144	.6173	.6859	.1677
20	.4287	.2058	.1715	.5316	.5487	.6687	.2286
21	.5144	.2229	.2058	.2401	.463	.6344	.1524
22	.5144	.2058	.2572	.4115	.3429	.583	.3048
23	.3429	1.5242	1.6004	1.6766	1.5242	.5487	.3353
24	.3048	.2572	1.6004	1.6004	1.6766	1.6004	.5487
Max	2.3148	2.2862	1.9814	1.9052	1.9814	1.9052	2.7435
Min	.3048	.1715	.1715	.1715	.2743	.2229	.1524
Avg	1.0051	.9636	1.0054	.9171	1.0703	.9538	1.1319

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274160 / Kolegaon

Feeder No / Name : 201 / KOLEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.1886	.1886	.1886	.1886	.9602	.1886
2	.1886	.1886	.1715	.1886	.1715	.9945	.1886
3	.2058	.2058	.1715	.1715	.2058	1.0288	.2058
4	.2401	.2229	.2058	.2058	.2572	1.2003	.2401
5	.2915	.2743	.2743	.2743	.2915	1.5432	.3086
6	.3601	.3601	.3429	.3429	.3601	1.8004	.3601
7	.2401	.2743	.2572	.2572	.2401	2.572	.2743
8						2.1434	
9	.2058	.2058	.2229		.2058		.2229
10	.1886	.2401	.1715		.1886		.2378
11	.1715	.2058	.1886	.2378	.2229		.1829
12	.1715	.1715	.1372	.2241	.1715		.2218
13		.1715	.12	.2054	.1543	.1886	.2054
14	.1715	.1372	.1029	.1867	.1372	.1543	.1867
15	.1715	.1372	.12	.1698	.1372	.1543	.168
16	.1543	.1372	.1372	.1509	.1372	.1886	.1509
17	.1543	.1715	.12	.1509	.1543	.2058	.1698
18	.1886	.1886	.2058	.1509	.1886	.2058	.1886
19	.2401	.2229	.2401	.2263	.2743	.2229	.2241
20	.3258	.3086	.3086		.2915	.2572	.2614
21	.2915	.2572	.2743		.2572	.2572	.2427
22	.2229	.2401	.2229		.2401	.2401	.2263
23	.2229	.2229	.2058		.2058	.2058	.2263
24	.3506	.2058	.1886	.2058	.1886	.9431	.2058
Max	.3601	.3601	.3429	.3429	.3601	2.572	.3601
Min	.1543	.1372	.1029	.1509	.1372	.1543	.1509
Avg	.2256	.2147	.1991	.2081	.2117	.7733	.2212



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274160 / Kolegaon

Feeder No / Name : 202 / Kolegaon Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8861	.2058	.2058	.2058	.1715	.1886
2	1.869	.1886	.1715	.1886	.1886	.1886
3	1.9376	.1886	.1886	.2058	.1886	.2058
4	2.0405	.2572	.2229	.2229	.2058	.2401
5	2.332	.2743	.2915	.2743	.2743	.3258
6	2.5892	.3772	.3772	.4287	.3086	.3772
7	3.035					
8	2.9835					
9		2.7435		2.915	2.6578	2.5892
10		3.1893		2.7435	3.035	
11		3.2579	2.1091	3.0521	3.0007	2.7183
12		3.1207	2.9371	2.6063	2.8292	2.4215
13		3.0178		2.7435	2.7949	2.3562
14	.12	2.8464		2.7435	2.692	2.2455
15	.1543	2.6578		2.6578	2.452	2.2611
16	.1715	2.4006		2.572	2.2634	2.1822
17	.1543	.12		.1372		.1543
18	.1886	.2058		.1886	.1543	.1715
19	.2401	.2743		.2572	.2401	.2103
20	.2572	.3258		.2572	.2401	.2572
21	.2572	.2743		.2401	.2229	.2204
22	.2058	.2229		.2229	.2058	.2058
23	1.8347	.2229		.2058	.1886	.2058
24	.3963	.2058	.2229	.2058	.1715	.2058
Max	3.035	3.2579	2.9371	3.0521	3.035	2.7183
Min	.12	.12	.1715	.1372	.1543	.1543
Avg	1.1923	1.2081	.7474	1.1488	1.1660	.9491

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274160 / Kolegaon

Feeder No / Name : 203 / Phalawni Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2229	.7716	1.0117	.8402	.9602	.9602
2	.2572	.2279	.8573	1.046	.8402	.9945	1.0117
3	.2401	.2572	1.0288	1.0288	1.0117	1.0288	1.0631
4	.2743	.3086	1.286	1.1317	1.1488	1.2003	1.0802
5	.3258	.373	1.3717	1.2689	1.4232	1.5432	1.2174
6	.4115	.4359	1.749	1.6461	1.6632	1.8004	1.6289
7			2.2805	2.3491	2.5206	2.572	1.989
8			1.9719	1.749	2.5377	2.1434	1.8519
9	1.6289	1.7078					
10	1.7147	1.8623					
11	1.749	1.6004					
12	1.6461	1.5546					
13		1.5729	.1543	.1417	.1543	.1886	.1715
14	1.4403	1.3927	.1543	.1417	.1543	.1543	.2058
15	1.5432	1.2955	.1372	.1433	.1372	.1543	.2058
16	1.6118	1.3599	.1372	.1595	.1372	.1886	.2229
17	.2743	.2279	.1886	.1595	.2401	.2058	.2401
18	.2229	.2454	.2058	.1753	.2572	.2401	.2572
19	.2572	.2804	.2743	.2454	.2915	.2915	.2743
20	.3429	.3294	.3086		.3429	.3258	.3052
21	.3258	.3429	.3429		.3258	.3086	.2713
22	.2915	.3086	.2915		.3258	.3086	.2543
23	.2572	.7459	.9259		.9602	.9431	1.004
24	.381	.2229	.7373	.9602	.9431	.9431	.9774
Max	1.749	1.8623	2.2805	2.3491	2.5377	2.572	1.989
Min	.2229	.2229	.1372	.1417	.1372	.1543	.1715
Avg	.7359	.7670	.7587	.8349	.8128	.8248	.7596

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274175 / KHUDUS

Feeder No / Name : 201 / DOMBALWADI  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.213	.2294	1.4255	1.6385	1.5565	1.5249	1.5249
2	.1966	.213	1.4255	1.6385	1.5565	1.5249	1.5746
3	.1966	.213	1.5729	1.6385	1.6057	1.7238	1.6409
4	.2294	.213	1.5729	1.7368	1.6057	1.7238	1.6575
5	.2622	.2458	1.7695	1.7368	1.7204	1.7901	1.7404
6	.2622	.2949	1.917	1.9006	1.9989	1.8564	2.0222
7			2.4577	2.0481	2.1628	1.989	2.4863
8			2.2119	2.2283	2.2283	2.0388	2.4366
9	1.8842	1.9334					
10	2.1628	2.1628					
11	2.13	2.1956					
12	2.2611	2.13					
13	2.13						
14	2.0317	1.9006					
15	1.9662	2.5724					
16	1.9662	1.917					
19	.213	.2622	.2622	.2294	.2622	.218	.2515
20	.2622	.2949	.2785	.2622	.2785	.3018	.285
21	.2458	.2949	.2785	.2294	.2785	.3018	.3185
22	.2294	.2949	.2785	.2458	.2785	.2515	.3353
23	.213	1.9334	1.5729	1.4746	1.5074	1.442	1.3094
24	.3506	.2294	1.3927	1.5729	1.5565	1.5249	1.5249
Max	2.2611	2.5724	2.4577	2.2283	2.2283	2.0388	2.4863
Min	.1966	.213	.2622	.2294	.2622	.218	.2515
Avg	.9703	1.0279	1.3154	1.3272	1.3283	1.3008	1.3649

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274175 / KHUDUS

Feeder No / Name : 202 / AMBEMALA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3927	1.6712	.2949	.3277	.2458	.2683	.3353
2	1.3927	1.6712	.2949	.3277	.2458	.2683	.3353
3	1.3927	1.6712	.2949	.3277	.2949	.2683	.3353
4	1.4746	1.7204	.2949	.3277	.2949	.2683	.3353
5	1.5565	1.8023	.2949	.3277	.2949	.3018	.3688
6	1.8023	1.8842	.2949	.2458	.2785	.3018	.3018
7	2.0972	2.13					
8	1.9989	2.0481					
9				1.9662	2.2611	2.2874	2.2542
10		.0492	2.0481	2.1956	2.3922	2.5069	2.4366
11	.0655	.0655	2.5396	2.0481		2.7035	2.6355
12	.0655	.0655		2.3594		2.3537	2.6852
13	.0655	.0655	2.2611	2.3266		2.3537	2.4863
14	.0655	.0655	2.4905	2.3758	2.6216	2.2874	2.3371
15	.0655	.0492	2.1956	2.4086	2.4741	2.1879	2.3868
16	.0655		2.2611	2.1628	2.5724	2.1714	2.3868
17	.0328			.0492	.0492		
19	.2785	.3277	.3277	.2458	.2785	.285	
20	.2785	.3441	.3605	.2622	.3113	.285	.218
21	.2949	.3441	.3605	.2294	.3113	.3185	.3353
22	.2785	.3441	.3605	.2294	.3113	.3185	.3688
23	1.5729	.3277	.3277	.2294	.2622	.3688	.3353
24	1.3927	1.6712	.3277	.3277	.2458	.2683	.3353
Max	2.0972	2.13	2.5396	2.4086	2.6216	2.7035	2.6852
Min	.0328	.0492	.2949	.0492	.0492	.2683	.218
Avg	.8395	.9159	.9794	1.0143	.8748	1.1186	1.2217

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274175 / KHUDUS

Feeder No / Name : 203 / KHUDUS

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2458	.2458	1.5729	1.6712	1.5565	1.6244	1.6575
2	.2458	.2458	1.5729	1.6712	1.5565	1.6409	1.6409
3	.2458	.2458	1.5729	1.6712	1.5565	1.7404	1.6409
4	.2458	.2458	1.6712	1.6712	1.5565	1.989	1.6409
5	.2622	.2458	1.917	1.7695	1.7204	2.2377	1.7404
6	.2294	.2622	2.0645	1.7204	1.8023	2.4863	1.9062
7			2.2939	2.2611	2.4577	2.6023	2.3205
8			2.2611	2.1792	2.3758	2.6355	2.3371
9	1.9662	2.2119					
10	2.13	2.3758					
11	2.13	2.2447					
12	2.13	2.2119					
13	1.9989						
14	1.9989	2.13					
15	2.0317	2.13					
16	2.0153	2.0645					
19	.1966	.2294	.2294	.2294	.2294	.218	.2683
20	.2294	.2622	.2622	.2785	.2622	.2683	.3018
21	.2458	.2622	.2622	.2622	.2622	.2683	.3353
22	.2622	.2622	.2622	.2622	.2622	.2515	.3353
23	.2458	1.5729	1.6712	1.6057	1.6057	1.6575	1.442
24	.2458	.2458	1.5729	1.6712	1.5565	1.5746	1.7072
Max	2.13	2.3758	2.2939	2.2611	2.4577	2.6355	2.3371
Min	.1966	.2294	.2294	.2294	.2294	.218	.2683
Avg	.9651	1.0366	1.3705	1.3517	1.3400	1.5139	1.3767

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274175 / KHUDUS

Feeder No / Name : 204 / ZANJEWADI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9831	.9831	.1311	.1311	.1311	.1341	.1341
2	.9831	.9831	.1311	.1311	.1311	.1341	.1341
3	.9831	.9831	.1311	.1311	.1475	.1341	.1341
4	.9831	1.0486	.1311	.1311	.1475	.1341	.1341
5	1.065	1.0814	.1311	.1311	.1475	.1341	.1509
6	1.1961	1.278	.1311	.1475	.1475	.1341	.1341
7	1.3927	1.3599					
8	1.4255	1.3435					
9				1.0322	1.3108	1.6741	1.3923
10			1.2289	1.3599	1.3599	1.7238	1.7901
11			1.1633	1.3599		1.7736	1.7901
12			1.4582	1.4255		1.6409	1.7901
13			1.4419	1.5074		1.6244	1.6907
14			1.5238	1.5565	1.4419	1.2929	1.5912
15			1.1633	1.4746	1.5893	1.2763	1.5912
16			1.2289	1.4419	1.6057	1.326	1.442
19	.0983	.1147	.1147	.0655	.0819	.1006	.0838
20	.0983	.1311	.1311	.0983	.1311	.1174	.1509
21	.0983	.1311	.1311	.0983	.1311	.1341	.1677
22	.1311	.1311	.1311	.1311	.1311	.1509	.1677
23	.9503	.1311	.1311	.1311	.1311	.1341	.1341
24	.442	.9831	.1311	.1311	.1311	.1341	.1341
Max	1.4255	1.3599	1.5238	1.5565	1.6057	1.7736	1.7901
Min	.0983	.1147	.1147	.0655	.0819	.1006	.0838
Avg	.7736	.7631	.5666	.6308	.5234	.6954	.7369

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274213 / GARWAD SUBSTATION

Feeder No / Name : 201 / GARWAD

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.448	1.0974	.2	.2058	.2801	.2743	.2667
2	1.4937	1.166	.2	.2058	.2667	.2667	.2801
3	1.6404	1.2346	.2	.2134	.3429	.2667	.2934
4	1.7528	1.3032	.2058	.2134	.3201	.2534	.2534
5	1.8964	1.5337	.2058	.2401	.3334	.2401	.2801
6	2.0309	1.8576	.2058	.2401	.2667	.2401	.2667
7	2.1872	2.0062					
8	2.1548	1.989					
9			.9335	1.3375	1.6671	.9335	1.4403
10			1.3375	1.448	1.7833	1.2186	1.6671
11			1.467	1.2936	1.8061	1.3375	1.9616
12			1.7238	1.6671	1.8576	1.4563	1.8576
13	.1334	.1334	1.8362	1.9319	1.8576	1.5954	1.7833
14		.1334	1.9022	1.8814	1.8576	1.7833	1.768
15	.1646	.1334	1.9052	1.7535	1.829		
16	.1467	.1334	2.0119	1.2631	1.7833	2.0062	
17	.1467	.1646	.12	.16	.16	.12	.1067
18	.16	.1646	.16	.16		.1334	.1334
19	.192	.1783	.192	.208	.192	.16	.16
20	.2058	.1734	.2401	.2	.2058	.1867	.2058
21	.2743	.192	.2743	.2675		.2058	.2469
22	.2743	.1867	.3269	.2606	.2134	.2401	.2934
23	.9602	.1867	.3567	.2667	.2134	.2896	.2881
24	1.3375	1.0288	.1867	.2934	.2801	.2134	.2667
Max	2.1872	2.0062	2.0119	1.9319	1.8576	2.0062	1.9616
Min	.1334	.1334	.12	.16	.16	.12	.1067
Avg	.9789	.7498	.7360	.7141	.8758	.6391	.6910

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274213 / GARWAD SUBSTATION

Feeder No / Name : 202 / CHANDAPURI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2	.3292	1.7833	1.2346	1.3375	1.6347	1.166
2	.1867	.2743	1.7833	1.262	1.2041	1.7833	1.3375
3	.2058	.3018	1.8061	1.3443	1.2631	1.7833	1.4118
4	.2469	.2743	1.9319	1.4403	1.3546	1.7833	1.4861
5	.2743	.2606	1.9319	1.5364	1.4118	1.8576	1.709
6	.3429	.2743	2.0805	1.8061	1.6347	1.9319	1.8576
7			2.0805	1.8724	1.8576	1.9319	1.9319
8			2.0805	1.8724	1.6644	1.9319	1.8814
9	2.1548	1.3375					
10	2.2291	1.5089					
11		1.8061					
12	1.9319	1.9566					
13	2.0805	2.0805		.12	.16	.1334	.1097
14	2.1548	2.0805		.12	.2267	.1334	.1097
15		2.0805	.12		.2134		.1235
16	2.0805	1.8576	.1334	.1067	.2667		.1334
17		.2667	.16	.12	.2934	.1372	.1334
18	.1334	.2606	.2	.1334		.1334	.16
19	.1467	.2606	.2134	.16	.3067	.1646	.2
20	.2058	.3018	.2401	.2058	.3292	.192	.2401
21	.2743	.3201	.2743	.2058		.192	.2743
22	.3715	.3201	.2881	.2195	.3467	.2058	.2881
23	.3567	1.2346	1.1888	1.166	1.4861	1.1888	1.1888
24	.2469	.3334	1.4861	1.2631	1.3226	1.5901	1.166
Max	2.2291	2.0805	2.0805	1.8724	1.8576	1.9319	1.9319
Min	.1334	.2606	.12	.1067	.16	.1334	.1097
Avg	.8328	.8964	1.0990	.8520	.9266	1.0394	.8454



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274214 / DASUR

Feeder No / Name : 201 / DASUR PATI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.703	.9145	.0914	.1372	.1829	.1143	1.4232
2	.7202	.9145	.08	.1372	.1829	.1143	1.4232
3	.7202	.9297	.08	.1543	.1829	.1372	1.4403
4	.7202	.945	.1029	.1715	.1981	.1486	1.4746
5	.7373	.945	.1143	.2058	.2286	.1486	1.4918
6	.8573	.9755	.1486	.2058	.2439	.16	1.6118
7	1.0631	1.2193	.1372	.2229	.2439	.16	1.6804
8	1.0974	1.1888	.1029	.1886	.2286	.1486	1.7661
9	.0857	.0762	.8002	1.3032	1.2041	.9602	.1029
10	.0914	.0457	1.5089	1.2651	.9374	1.6461	.1219
11	.061	.0457	1.5261	1.2803	1.0745	1.6804	.1219
12	.1067	.0572		1.2955	1.1317	1.7318	.1219
13	.061	.0457	1.5089	1.326	1.0745	1.7661	.1219
14		.0457	1.4918	1.326	1.0745	1.7318	.1219
15	.061	.0457	1.4746	1.3413	1.0517	1.5947	.1219
16	.1067	.0457	1.4403	1.3413	1.0517	1.6118	.1219
17	.0914	.1029	.0686	.0762	.0686	.0857	.1219
18	.0914	.1372	.0857	.1524	.2058	.1029	.1219
19	.1067	.1543	.1029	.1829	.2401	.1372	.1219
20	.1372	.2058	.2058	.2286	.2229	.1715	.1829
21	.1067	.1715	.1886	.2439	.2012	.1543	.1829
22	.1067	.1715	.1543	.1829	.2058	.1372	.1372
23	.9297	.1029	.1372	.1829	.16	1.4232	1.1736
24	.7202	.9297	.0914	.1372	.1829	.1143	1.4403
Max	1.0974	1.2193	1.5261	1.3413	1.2041	1.7661	1.7661
Min	.061	.0457	.0686	.0762	.0686	.0857	.1029
Avg	.4123	.4340	.5062	.5537	.4908	.6742	.6979

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274214 / DASUR

Feeder No / Name : 202 / 11 KV NANAWARE WASTI

FEEDER SEPERATION/PURE AG

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1677	.3429	.5316	.4877	.4115	.1715
2	.1543	.1677	.3201	.5316	.4877	.4115	.1715
3	.1715	.2286	.2972	.5487	.4877	.4572	.1886
4	.2401	.2286	.3201	.583	.5182	.4572	.2229
5	.2915	.2591	.4115	.6173	.5792	.4915	.2743
6	.3429	.2896	.503	.7888	.7011	.5716	.3258
7	.2915	.2591	.663	.9259	.9297	.6744	.3086
8	.2572	.2134	.6973	.9431	.8535	.7087	.2572
9	.6097	.7468	.1372	.1543	.1981	.1143	.9774
10	.7164	.6401	.1372	.1219	.1372	.1543	.9297
11	.7011	.5944	.1372	.1219	.1372	.1543	.9297
12	.7011	.5487	.1372	.1219	.1372	.1715	.945
13	.6859	.5487	.1372	.1219	.1486	.1886	.9602
14	.7011	.5601	.1372	.1219	.1486	.1543	.9602
15	.7011	.5601	.1372	.1219	.1257	.1543	.945
16	.7468	.5487	.1372	.1372	.1143	.1715	.945
17	.1067	.1029	.1715	.1524	.2058	.1886	.1219
18	.1219	.1715	.1886	.1677		.2229	.1677
19	.2286	.2401	.3086	.2743	.3258	.2572	.1829
20	.2743	.2572	.2915	.2439	.2915	.2915	.2439
21	.1829	.1715	.2572	.1524	.2012	.2572	.1829
22	.1677	.1715	.2058	.1524	.1715	.2229	.1524
23	.1524	.3429	.5487	.4725	.5068	.1715	.1677
24	.1543	.1677	.3429	.5487	.4725	.4344	.1715
Max	.7468	.7468	.6973	.9431	.9297	.7087	.9774
Min	.1067	.1029	.1372	.1219	.1143	.1143	.1219
Avg	.3690	.3411	.2903	.3607	.3638	.3122	.4543

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274214 / DASUR

Feeder No / Name : 203 / 11 KV BHIMA NADI FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5316	.4877					.7716
2	.5316	.4877					.7716
3	.5487	.4877					.7888
4	.5487	.503					.8059
5	.5487	.5182					.823
6	.6001	.5487					.8916
7	.703	.6249					.9602
8	.7373	.6097					1.0117
9			.4115	.8059	.7926	.663	
10			.7545	.7926	.663	1.1145	
11			.7545	.8535	.7316	1.166	
12			.7373	.9755	.7316	1.0974	
13			.8402	.9755	.7659	1.0631	
14			.9259	.9755	.7888	1.0974	
15			.8916	.9602	.7888	1.1317	
16			.823	.9602	.8116	1.2003	
23	.4572					.7716	.6706
24	.5316	.4877					.7888
Max	.7373	.6249	.9259	.9755	.8116	1.2003	1.0117
Min	.4572	.4877	.4115	.7926	.663	.663	.6706
Avg	.5739	.5284	.7673	.9124	.7592	1.0339	.8284

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 201 / 11KV JADHAVWADI AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.2458			
8	.2622	.2622		1.9662
10	.1638			
15	.0983			
16		.1638		
17	.0983			
22	1.1142			
23	1.0486	.2294	.2458	.2458
24	1.153	.9995		.2458
<b>Max</b>	<b>1.153</b>	<b>.9995</b>	<b>.2458</b>	<b>1.9662</b>
<b>Min</b>	<b>.0983</b>	<b>.1638</b>	<b>.2458</b>	<b>.2458</b>
<b>Avg</b>	<b>.5230</b>	<b>.4137</b>	<b>.2458</b>	<b>.8193</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 202 / 11KV CHAUR WASTI AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.3605			
7	.3605			
8	.3277	.3277		.3239
10	2.9165			
15	2.7526			
16		.2949		
17	2.13			
20	.3277			
23	.3277	1.9662	2.4249	1.3108
24	.3048	.3277		2.2996
<b>Max</b>	<b>2.9165</b>	<b>1.9662</b>	<b>2.4249</b>	<b>2.2996</b>
<b>Min</b>	<b>.3048</b>	<b>.2949</b>	<b>2.4249</b>	<b>.3239</b>
<b>Avg</b>	<b>1.0898</b>	<b>.7291</b>	<b>2.4249</b>	<b>1.3114</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 203 / 11KV SIDACHIWADI AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9559	1.6617		
2	1.9062	1.6108		
3	.1658			
4	.1658			
5	.1658			
6	.1658			
7	.1658			
8	.1658			2.5069
9	.1658			
10	.1492			
11	.1326			
12	.1326			
13	.1326			
14	.1326			
15	.1326			
16	.116			.1475
17	.116			
18	.116			
19	2.0719			
20	2.1548			
21	2.0719			
22	1.9062			
23	1.8233		.1943	.1638
24	2.0348	1.7126		.1966
Max	2.1548	1.7126	.1943	2.5069
Min	.116	1.6108	.1943	.1475
Avg	.7602	1.6617	.1943	.7537

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 204 / 11KV DEV AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1658		
2	.1658		
3	1.0608		
4	1.2431		
5	1.326		
6	1.3592		
7	1.6575		
8	1.6907		.1475
9	1.6244		
10	1.5581		
11	.116		
12	.0995		
13	.0995		
14	.0995		
15	.0995		
16	.0995		1.6057
17	.0995		
18	.116		
19	.1326		
20	.1492		
21	.1492		
22	.1658		
23	.1658	.1475	.1475
24	.1696		.1475
Max	1.6907	.1475	1.6057
Min	.0995	.1475	.1475
Avg	.5672	.1475	.5121

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 205 / 11KV MALSHIRAS URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0277	1.0277		
2	.9779	.9614		
3	1.0111			
4	1.0774			
5	1.1603			
6	1.2929			
7	1.1603			
8	1.0111	.9779	1.0486	1.1469
9	.9945	.9282		
10	.9779			
11	.9116			
12	.8288			
13	.7956			
14	.7127			
15	.7293			
16	.7956		.852	.8356
17	.8785			
18	1.0111			
19	1.1271			
20	1.1437			
21	1.1934			
22	1.21	1.1768		
23	1.1603	1.0608	1.1797	1.0814
24	1.0608	1.0608	1.0814	1.1469
Max	1.2929	1.1768	1.1797	1.1469
Min	.7127	.9282	.852	.8356
Avg	1.0104	1.0277	1.0404	1.0527



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 206 / 11KV Medad AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3222		
2	.3222		
3	.3222		
4	.3391		
5	.3391		
6	.373		
7	.3391		
8	.3222		.2458
9	.2374		
10	.2204		
11	1.8652		
12	1.7126		
13	1.6617		
14	1.56		
15	1.5261		
16	1.4752		.1802
17	1.3565		
18	1.2717		
19	.2374		
20	.2543		
21	.3222		
22	.3222		
23	.3222	1.2955	1.0486
24	.3391		1.2452
Max	1.8652	1.2955	1.2452
Min	.2204	1.2955	.1802
Avg	.7235	1.2955	.6800

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 207 / 11KV TARANGFAL AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9614	1.2378		
2	.9282	1.3565		
3	.9665			
4	1.0174			
5	1.0852			
6	1.153			
7	1.3056			
8	1.1869	2.2891	2.0645	2.343
9	.3391	.3052		
11	1.1869			
12	1.3226			
13	1.8652			
14	2.1365			
15	2.0348			
16	1.95		1.5729	1.6549
17	1.8821			
18	1.6787			
19	.1696			
20	.1357			
21	.1357			
22	.3222	.1357		
23	1.0682	1.0513	1.9826	1.5074
24	1.0174	1.17	1.9334	1.9334
Max	2.1365	2.2891	2.0645	2.343
Min	.1357	.1357	1.5729	1.5074
Avg	1.1239	1.0779	1.8884	1.8597

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 208 / 11 KV TARANGFAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3812	.3978		
2	.3812	.3978		
3	.3812			
4	.4144			
5	.4239			
6	.4578			
7	.3391			
8	.3812	.3647	.3605	.3605
9	.3315	.2984		
10	.2321			
11	.2155			
12	.1823			
13	.1989			
14	.1989			
15	.2155			
16	.2155		.2622	.2294
17	.2321			
18	.2818			
19	.3812			
20	.4641			
21	.4144			
22	.4475	.4144		
23	.3978	.3978	.4588	.4096
24	.3978	.3978	.4588	.4588
Max	.4641	.4144	.4588	.4588
Min	.1823	.2984	.2622	.2294
Avg	.3320	.3812	.3851	.3646

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 209 / 11KV KALE-PANDARE AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2035			
2	.2035			
3	1.1022			
4	1.153			
5	1.2209			
6	1.2887			
7	1.7126			
8	1.6617	1.3927		.2294
9	1.5261			
10	1.4413			
11	.1187			
12	.1017			
13	.1187			
14	.1187			
15	.1187			
16	.1357	.1311		1.4091
17	.1357			
18	.1526			
19	.1865			
20	.2035			
21	.2035			
22	.2204			
23	.2204	.2294	.218	.213
24	.2035	.213		.1966
Max	1.7126	1.3927	.218	1.4091
Min	.1017	.1311	.218	.1966
Avg	.5730	.4916	.218	.5120

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 210 / COURT-(GOVT) EXPRESS NON SHEDDABLE WATER SUPPLY AND  
 FEEDER Feeder KV- 11 / UTILITY  
 OUTGOING

DATE	01-AUG-17	02-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.0819			
5	.0819			
6	.0819			
8	.0819	.081		.0819
12	.0819			
16	.0819	.0819		.0819
17	.0819			
20	.0819			
21	.0819			
23	.0819	.0819	.0819	.0819
24	.0819	.0819		.0819
Max	.0819	.0819	.0819	.0819
Min	.0819	.081	.0819	.0819
Avg	.0819	.0817	.0819	.0819

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274105 / 33/11KV ISLAMPUR S/Stn

Feeder No / Name : 201 / 11KV KANHER AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1718	.1802	1.587	1.2452	1.6604	1.7652	1.7814
2	.1718	.1802	1.7004	1.3435	1.7394	1.7652	1.8299
3	.1875	.1802	1.7004	1.4582	1.7394	1.7814	1.8461
4	.1875	.1966	1.7328	1.6712	1.7924	1.7814	1.8461
5	.1875	.1966	1.7328	1.8842	1.8027	1.7814	1.9271
6	.2031	.1802	1.7328	2.1956	1.8818	1.9433	1.9757
7	.1718	.1802	2.0405	2.0153	2.1285	2.1052	2.2024
8	.1875	.1475	2.1052	2.1792	2.2138	2.1862	2.251
9	1.9372	1.8623	.1134		.1094	.1296	.1341
10	2.2348	2.2186	.1296	.1094	.1147	.1296	.1134
11	2.1862	2.2186	.1134	.1094	.1311	.1457	.1296
12	2.2348	2.2024	.1134	.1094		.1296	.1296
13	2.2672	2.0729	.1134	.125		.1457	.1134
14	2.2024	2.0243	.1296	.1094	.1311	.1619	.1296
15	1.8623	2.0243	.1296	.1094	.1475	.1457	.1296
16	1.8138	1.9919	.1296	.1094	.1475	.1311	.1296
17	.1311	.1457	.1457	.1562	.1638	.1457	.1457
18	.1311	.1296	.1457	.1718		.1457	.1619
19	.1311	.1296	.1619	.2031	.1802	.1457	.1619
20	.1475	.1457	.1781	.2031	.1966	.1457	.1781
21	.1638	.1457	.1619	.1875	.213	.1457	.1943
22	.1638	.1619	.1781	.1875	.213	.1619	.1943
23	.1802	.1619	1.2125	1.6004	1.8299	1.587	1.5074
24	.1781	.1802	.1619	1.2452	1.6804	1.749	1.7328
Max	2.2672	2.2186	2.1052	2.1956	2.2138	2.1862	2.251
Min	.1311	.1296	.1134	.1094	.1094	.1296	.1134
Avg	.8097	.8024	.7354	.8143	.9627	.8523	.8727

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274105 / 33/11KV ISLAMPUR S/Stn

Feeder No / Name : 202 / 11KV ISLAMPUR AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6194	1.6194	.1781	.1296	.1562	.1638	.1781
2	1.6004	1.6194	.1781	.1134	.1718	.1638	.1781
3	1.6004	1.6194	.1943	.1457	.1718	.1638	.1943
4	1.6324	1.6842	.2105	.1619	.1875	.1638	.2105
5	1.6324	1.7328	.2105	.1781	.2031	.1802	.2105
6	1.8404	1.8623	.2267	.1781	.2343	.2458	.2105
7	2.0485	2.0567	.2105	.1943	.2187	.2294	.2105
8	2.1605	2.1052	.1296	.1619	.1875	.1966	.1619
9	.1094	.0983	1.7859		2.1445	2.2672	2.0317
10	.1147	.0972	2.5069	2.2405	2.5101	2.4129	2.0972
11	.0983	.0972	2.4905	2.2885	2.5101	2.5587	
12	.0983	.0972	2.4741	2.4166	2.6073	2.5101	
13	.0983	.0972	2.4249	2.332	2.5101	2.4453	
14	.1147	.0972	2.2939	2.3967	2.3482	2.2672	2.13
15	.0983	.081	2.2611	2.3205	2.3158	2.1538	2.343
16	.0983	.081	2.0645	2.17	2.1862	2.0891	2.13
17	.1147	.1134	.0972	.0937	.0983	.0972	.1134
18	.1372	.1296	.1296	.1094		.1134	.1296
19	.1802	.1296	.1296	.1718	.1966	.1296	.1457
20	.1966	.1296	.1619	.1718	.1966	.1457	.1619
21	.1802	.1296	.1781	.1562	.1966	.1781	.1781
22	.1638	.1457	.1619	.1562	.1802	.1781	.1296
23	1.5384	.1457	.1296	.1718	.1638	.1619	.1296
24	1.5708	1.587	.1619	.1296	.1562	.1638	.1619
Max	2.1605	2.1052	2.5069	2.4166	2.6073	2.5587	2.343
Min	.0983	.081	.0972	.0937	.0983	.0972	.1134
Avg	.7936	.7315	.8746	.8082	.9501	.8908	.6398

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274105 / 33/11KV ISLAMPUR S/Stn

Feeder No / Name : 203 / 11KV MANAKI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3281	.3441	.7287	.7537	.7682	.6802	.7773
2	.3281	.3277	.7935	.7537	.7773	.6964	.7773
3	.3281	.3441	.8097	.7865	.8097	.6802	.7935
4	.3437	.3605	.8097	.7373	.8097	.6802	.8259
5	.3593	.3605	.8097	.7537	.8259	.7287	.9555
6	.3906	.3441	.8421	1.5238	1.2963	1.1498	.9717
7	.3437	.3113	1.3927	1.1469	1.7814	1.6194	1.5546
8	.3125	.213	1.1336	1.4255	1.5043	1.2955	1.3927
9	.9922	1.3279	.2267		.2187	.1781	.1781
10	1.1012	1.166	.1781	.1406	.213	.1619	.1619
11	1.2146	1.166	.1619	.1406	.1802	.1296	.1457
12	1.1822	1.1498		.1562	.1802	.1457	.1457
13	1.1336	1.0526		.1562	.1802	.1296	.1619
14	1.1012	.8421		.125	.1638	.1296	.1457
15	.9231	.8421	.1134	.1562	.1802	.1296	.1619
16	.9393	.8421	.1457	.1094	.2458		.1781
17	.1311	.1457	.1457	.1406		.1457	.1781
18	.213	.1619	.1619	.1562		.1619	.1943
19	.2949	.1619	.2105	.1718	.2622	.1943	.1781
20	.2785	.1781	.2429	.3281	.3605	.2105	.2105
21	.2949	.213	.2591	.3125	.3277	.2267	.2267
22	.2949	.2429	.2591	.3125	.2785	.2429	.2267
23	.3113	.2429	.6882	.7287	.7449	.6154	.6226
24	.3401	.3277	.2753	.7373	.7522	.6964	.7287
Max	1.2146	1.3279	1.3927	1.5238	1.7814	1.6194	1.5546
Min	.1311	.1457	.1134	.1094	.1638	.1296	.1457
Avg	.5617	.5278	.4947	.511	.5846	.4795	.4956



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274105 / 33/11KV ISLAMPUR S/Stn

Feeder No / Name : 204 / ISLAMPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.086		1.1984	1.1765	1.086	1.0099	1.166
2	1.1765	1.134	1.1984	1.086	1.1765	1.0631	1.166
3	1.2489	1.2048	1.2631	1.1584	1.1946	1.0985	1.1822
4	1.3575	1.2934	1.2955	1.2489	1.267	1.134	1.2308
5	1.4661	1.5238	1.2955	1.3394	1.3394	1.2048	1.2631
6	1.5384	1.3289	1.2955	1.2851	1.5203	1.382	1.2631
7	1.086	1.0277	.502	1.1765	1.086	1.0808	1.0202
9	.8869	.8859	.8869		.8688	.9231	.8507
10	.691	.6478	.7421	.6516	.7087	.8097	.7602
11	.6024	.5079	.4525	.5792	.5316	.5668	.6878
12	.5316	.4858		.5068	.5138	.5506	.5792
13	.4961	.4534		.4887	.4961	.502	.543
14	.4961	.421		.4887	.4961	.4372	.5249
15	.4961	.421	.4344	.5068	.5138	.4372	.543
16	.4961	.4049	.6154	.4706	.5493	.4534	.5973
17	.5316	.5079	.7421	.5792		.5344	.6878
18	.8859	.6478	.7783	.8326		.6802	.7602
19	1.134	.6188	1.2308	.9774	1.1163	.8097	.8688
20	1.3289	1.1174	1.3575	1.3756	1.3289	.9069	1.2308
21	1.2048	1.166	1.3394	1.267	1.2048	.9717	1.2489
22	1.1517	1.1984	1.3032	1.2308	1.0631	1.1012	1.086
23	1.0985	1.2146	1.1222	1.086	1.0454	1.1012	1.1041
24	.9878	1.0631	1.1822	1.1222	1.086	.9745	1.085
Max	1.5384	1.5238	1.3575	1.3756	1.5203	1.382	1.2631
Min	.4961	.4049	.4344	.4706	.4961	.4372	.5249
Avg	.9556	.8761	1.0118	.9379	.9615	.8580	.9326

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274105 / 33/11KV ISLAMPUR S/Stn

Feeder No / Name : 205 / GORADWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1862	2.4615	.4372	.4049	.4062	.4096	.4858
2	2.1605	2.4939	.4696	.4049	.4062	.426	.5079
3	2.2405	2.5911	.4858	.4534	.4374	.4424	.502
4	2.2405	2.7044	.4858	.4696	.4531	.4752	.4858
5	2.3205	2.8016	.4858	.4696	.4999	.5243	.5182
6	2.7206	2.9959	.4858	.4858	.4687		.5182
7		2.915					
8		2.672					
9			2.4741		2.4006	2.9959	.2458
10			3.2769	1.8244	2.834	3.0607	.2622
11			3.2606	1.8623	2.834	.4049	
12			2.8509	1.7764	2.9312	.2267	2.9656
13			3.2769	2.7368	2.915	3.1579	3.0967
14			2.9165	2.8166	2.9473	3.3198	2.6707
15			2.8837	3.1207	2.8502	3.0931	2.7526
16			2.7854	2.4129	2.5911	2.8664	2.6871
17		.2591	.1781	.2812	.2622	.2591	.2591
18		.2915	.2267	.2968		.3077	.2591
19		.3077	.2915	.3593	.3768	.3563	.3077
20	.426	.3401	.3441	.3906	.4752	.4049	.3725
21	.4096	.3401	.3768	.3593	.4752	.4372	.3887
22	.3605	.3725	.3725	.3593	.4752	.4534	.421
23	2.3805	.3725	.4096	.3906	.4752	.4534	.421
24	2.1376	2.4291	.4049	.4049	.3906	.4096	.4696
Max	2.7206	2.9959	3.2769	3.1207	2.9473	3.3198	3.0967
Min	.3605	.2591	.1781	.2812	.2622	.2267	.2458
Avg	1.7803	1.6468	1.3263	1.0514	1.3288	1.1659	.9808

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274105 / 33/11KV ISLAMPUR S/Stn

Feeder No / Name : 206 / SARGARWADI AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2372	.2949	1.0526	1.0486	1.0526	1.1984	1.1336
2	.2343	.2949	1.1498	1.1142	1.1012	1.2146	1.1336
3	.2343	.2949	1.1336	1.1469	1.1336	1.247	1.2631
4	.2656	.3113	1.1336	1.1797	1.2003	1.2793	1.3117
5	.2968	.3277	1.2308	1.2616	1.2955	1.3441	1.4089
6	.2968	.3113	1.4251	1.6712	1.6004		1.4575
7	.2656	.2294	1.9524	1.8351	2.0081	1.8623	1.7814
8	.2187		1.8244	1.8842	1.8947	1.9433	1.6842
9	1.5061	1.5384	.1457		.2031	.1781	.1781
10	1.7166	1.7004	.1134	.1406	.1966	.1296	.1457
11	1.7004	1.7328	.1134	.1406	.1475	.1296	.1296
12	1.6518	1.7166	.1296	.1406	.1475	.1296	.1296
13	1.587	1.4899	.1296	.1562	.1475	.1296	.1134
14	1.5384	1.3279	.1457	.125	.1311	.1296	.1296
15	1.4575	1.3272	.1457	.1406	.1311	.1296	.1296
16	1.4251	1.2955	.1296	.1562	.1475	.1134	.1134
17	.0983	.0972	.1296	.1406	.1802	.1457	.1296
18	.1638	.1134	.1457	.1406		.1457	.1619
19	.2785	.1457	.1619	.2187	.2622	.1619	.1619
20	.2622	.1943	.1943	.2343	.2622	.213	.1943
21	.2785	.1943	.2267	.2343	.3277	.2429	.2105
22	.2949	.2267	.2429	.2343	.3113	.2591	.2267
23	.2429	.2267	.9667	.9393	1.1984	.8259	.7865
24	.2343	.2785	.2591	1.0159	.9717	1.1822	1.1012
Max	1.7166	1.7328	1.9524	1.8842	2.0081	1.9433	1.7814
Min	.0983	.0972	.1134	.125	.1311	.1134	.1134
Avg	.6869	.6813	.5951	.6652	.6979	.6232	.6340

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274132 / 33KV KACHREWADI S/STN

Feeder No / Name : 201 / DESHMUKH PATTA AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.1524	1.1431	.823	1.0059	1.1431	1.0212
2	.1829	.1524	.9907	.823	1.0669	1.2193	1.0364
3	.1524	.1524	1.0669	.8535	1.1279	1.2193	1.0822
4	.1524	.1524	1.0974	.884	1.1584	1.2955	1.1279
5	.1372	.1677	1.2193	.9297	1.2193	1.3717	1.2346
6	.1829	.1829	1.2955	.9907	1.3717	1.448	1.2955
7	.2286	.1524	1.2955	1.2955	1.5242	1.6766	1.7071
8	.2286	.1524	1.2193	1.2498	1.3717	1.448	1.6004
9	1.2346	1.2193	.1829	.1524	.1524	.1524	.1524
10	1.2803	1.2498	.1829			.1372	.1524
11	1.387		.1524	.1524			.1524
12	1.3717		.1524	.1524		.1524	.1524
13	1.2193		.1524	.1524		.1524	.1524
14	1.1888		.1524	.1524		.1524	.1524
15	1.1279		.1677	.1524		.1677	.1524
16	1.0669		.1829	.1524		.1829	.1524
17	.1524		.1829	.1524		.1829	
18	.1524		.1829	.1524		.1829	.1524
19	.1829		.1829	.1829		.2134	.1829
20	.1981		.1829	.1829		.2591	.1829
21	.1981		.1829	.1829		.2439	.1829
22	.2134		.1524	.1829		.2286	.1829
23	.1981		.7926	.9145		.9907	.7621
24	.1829	.1829	1.1431	.8078	.945	.9907	1.0059
Max	1.387	1.2498	1.2955	1.2955	1.5242	1.6766	1.7071
Min	.1372	.1524	.1524	.1524	.1524	.1372	.1524
Avg	.5354	.3561	.5690	.5076	1.0943	.6614	.6077

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274132 / 33KV KACHREWADI S/STN

Feeder No / Name : 202 / 11KV UMBARE DAHIGAON AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.945	.884	.2439	.3048	.3353	.2896	.3658
2	1.0212	.884	.2439	.3048	.3353	.2896	.3658
3	1.1584	.9145	.2439	.3048	.3353	.2896	.381
4	1.2803	.9755	.1981	.3048	.3201	.2591	.381
5	1.4022	1.0822	.1829	.3201	.3048	.2439	.3658
6	1.4784	1.1279	.2134	.3353	.381	.2591	.3658
7	1.5242	1.6766	.1829	.3048	.3048	.2591	.381
8	1.3717	1.5242	.1829	.2743	.2134	.1981	.2286
9	.1524	.2286	1.6613	1.4632	1.829	1.829	1.829
10	.1372	.1524	1.7223			1.89	2.1033
11	.1372		1.6918	1.7985		1.9814	2.1643
12	.1219		1.6766	1.89		2.0119	2.1338
13	.1524		1.8519	1.829		2.0271	2.1338
14	.1524		1.6004	1.7985		2.0119	2.0576
15	.1524		1.5394	1.7528		1.9662	1.829
16			1.2803	1.7528		1.9052	1.5242
17	.1829		.1829	.1219		.1524	.1829
18	.2134		.2439	.1524		.2286	.2439
19	.2591		.2591	.2134		.2591	.2743
20	.3048		.2743	.2439		.3048	.2896
21	.3201		.3048	.2743		.3201	.3048
22	.3353		.3048	.2743		.3506	.3048
23	.8535		.3201	.3048		.3658	.3201
24	.8688	.8688	.2134	.3048	.3201	.3201	.3658
Max	1.5242	1.6766	1.8519	1.89	1.829	2.0271	2.1643
Min	.1219	.1524	.1829	.1219	.2134	.1524	.1829
Avg	.6315	.9381	.7008	.7230	.4679	.8338	.8707

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274132 / 33KV KACHREWADI S/STN

Feeder No / Name : 203 / KHANDOBA WASTI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.6401	.1981	.1524	.1981	.2591	.1524
2	.945	.6706	.2134	.1677	.1829	.2286	.1677
3	1.1584	.6859	.1829	.1677	.1829	.2286	.1829
4	1.2498	.7773	.1829	.2134	.1829	.2286	.1829
5	1.4632	.8688	.1677	.2439	.1829	.2134	.1981
6	1.5394	.9145	.1372	.2591	.2591	.1829	.1981
7	1.5699	1.2041	.1372	.2134	.1829	.1981	.1981
8	1.3717	1.2803	.1372	.1829	.1219	.1829	.1524
9	.1524	.1219	.945	.9602	1.0669	1.2346	1.2498
10	.1219	.1372	1.2651	1.0974		1.2498	1.3717
11	.1067		1.1888	1.0669		1.2651	1.3108
12	.0762		1.1736	1.0364		1.2346	1.2193
13	.0762		1.0822	.9907		1.1888	1.1431
14	.0762		.7316	.9602		1.0669	1.0669
15	.0914		.9297	.9145		1.0364	
16	.1067		.8688	.8993		1.0059	.9907
17	.1219		.0914	.061		.0914	.1372
18	.1219		.1219	.0914		.1219	.1372
19	.1372		.1677	.1219		.1524	.1372
20	.1524		.1524	.1677		.1677	.1524
21	.1524		.1372	.1829		.1524	.1524
22	.1524			.1829		.1524	.1677
23	.6249		.1372	.1829		.1524	.1829
24	.7468	.6401	.1524	.1524	.1981	.2439	.1524
Max	1.5699	1.2803	1.2651	1.0974	1.0669	1.2651	1.3717
Min	.0762	.1219	.0914	.061	.1219	.0914	.1372
Avg	.5474	.7219	.4566	.4446	.2759	.5100	.4784

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274132 / 33KV KACHREWADI S/STN

Feeder No / Name : 204 / 11KV KACHAREWADI GAOTHAN GAOTHAN FEEDER  
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2439	.2439	.2439	.1981	.1082	.2439	.2286
2	.2591	.2286	.1829	.2134	.1097	.2439	1.448
3	.2743	.2286	.1829	.2134	.1128	.2134	.2439
4	.2439	.2439	.1829	.2286	.1143	.2439	.2591
5	.2286	.2591	.1829	.2439	.1174	.2134	.2743
6	.1981	.2743	.1219	.2591	.1311	.1829	.2743
7	.1524	.1829	.1829	.2134	.1158	.1219	.2286
8	.1524	.1981	.1524	.1677	.1082	.1524	.2134
9	.1524	.1677	.1219	.1524	.093	.1829	.1829
10	.1524	.1524	.1372	.0625		.2134	.1219
11	.1372		.1219	.064		.1829	.0655
12	.1219		.0914	.064		.1372	.064
13	.1219		.1067	.0625		.1219	.064
14	.1067		.1219	.061		.1219	.0625
15	.1067		.1067	.061		.1219	.061
16	.1067		.0762	.061		.1219	
17	.1067		.0762	.064		.1219	.0777
18	.1219		.1524	.0777		.1829	.0808
19	.1829		.1677	.0854		.1981	.0838
20	.2286		.1829	.0869		.2134	.0869
21	.2286		.2134	.1006		.2134	.1021
22	.2286		.2134	.1021		.2286	.1021
23	.2286		.1981	.1036		.2286	.1036
24	.8688	.2286	.2134	.2134	.1067	.2743	.2286
Max	.8688	.2743	.2439	.2591	.1311	.2743	1.448
Min	.1067	.1524	.0762	.061	.093	.1219	.061
Avg	.2064	.2189	.1556	.1317	.1117	.1867	.2025

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274132 / 33KV KACHREWADI S/STN

Feeder No / Name : 205 / KAMALMALA AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2591	.2896	2.2405	1.448		2.0881	.5639
2	.2286	.2896	2.4691	1.4937		2.3472	.5792
3	.2591	.3048	2.4234	1.5394		2.1643	.5792
4	.2439	.3048	2.271	1.6461		2.2558	.5944
5	.2439	.3201	2.2253	1.89		2.0119	.6249
6	.2591	.3353	2.0881	2.0119		2.1948	.6554
7	.2896	.2896	2.1186	2.332		.6401	.6706
8	.2286	.3048	2.1491	2.3015	2.3929	.5944	.6706
9	1.829	1.9814	.1372	.2439	.2743	.2286	.2286
10	2.0424	1.89	.1524	.1829		.1524	.2134
11	1.9966		.1524	.1829		.1524	.1981
12	2.1491		.1372	.1524		.1524	.1981
13	2.1033			.1524		.1677	
14	1.9966			.1524		.1829	
15	1.9509			.1219		.1829	
16	1.829			.1219		.1981	
17	.1524					.1524	
18	.1677		.1981	.1829		.2134	.2439
19	.2286		.2286	.2134		.2896	.2743
20	.2591		.2591	.2743		.3353	.2896
21	.2591		.2896	.2743		.3201	.2896
22	.2743		.2896	.4268		.3048	.3048
23	.2743		1.4022			.5182	1.5851
24	.2896	.2896	2.3167	1.4175		2.2253	.5487
Max	2.1491	1.9814	2.4691	2.332	2.3929	2.3472	1.5851
Min	.1524	.2896	.1372	.1219	.2743	.1524	.1981
Avg	.8256	.6000	1.2394	.8528	1.3336	.8364	.4901



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274132 / 33KV KACHREWADI S/STN

Feeder No / Name : 206 / TIRWANDI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.6097	.1829	.2743	.2743	.2134	.0122
2	.8688	.6097	.1677	.2743	.2896	.1981	.2743
3	1.0059	.5792	.1219	.2896	.2896	.1677	.2896
4	1.1736	.5792	.1372	.2896	.2591	.1524	.2896
5	1.3108	.5335	.1829	.3048	.2591	.1829	.2743
6	1.3413	.5182	.1829	.3048	.3353	.2134	.2743
7	1.0669	.7468	.1524	.2591	.2591	.2286	.2439
8	.823	.7011	.1677	.1981	.1981	.2134	.2134
9	.1372	.1372	.4877	.5792	.6706	.8078	.7773
10	.1372	.1372	.7011	.7926		.9602	.9755
11	.1219		.7011	.823		.9297	.9145
12	.1219		.7164	.884		.8993	.884
13	.1067		.6859	.8383		.884	.8535
14	.1067		.6706	.7926		.8688	.823
15	.0914		.6249	.7316		.823	.7621
16	.0914		.5487	.6554		.7621	.6859
17	.1067		.0762	.0457		.1067	.1067
18	.1219		.1219	.0914		.1524	.1219
19	.1677		.1524	.1219		.1829	.1372
20	.2134		.2134	.1524		.2134	.1829
21	.2286		.2591	.1829		.2286	.2134
22	.2286		.2591	.2134		.2439	.2286
23	.6097		.2743	.2591		.2743	.2591
24	.5335	.6249	.1372	.2743	.2743	.2134	.2743
Max	1.3413	.7468	.7164	.884	.6706	.9602	.9755
Min	.0914	.1372	.0762	.0457	.1981	.1067	.0122
Avg	.4731	.5252	.3302	.4014	.3109	.4217	.4196

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274177 / 33/11KV MANDAVE S/S

Feeder No / Name : 201 / 11KV LAXMINAGAR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3725	.4266	1.4918	1.7598	1.5708	1.7166	1.6032
2	.3725	.4266	1.4918	1.7598	1.7004	1.7166	1.6032
3	.3887	.4417	1.5089	1.7598	1.8623	1.749	1.6032
4	.421	.4444	1.6289	1.7598	2.0891	1.7814	1.6032
5	.4534	.4622	1.869	1.8131	2.1862	1.8138	1.749
6	.4858	.4977	2.0748	1.902	2.2672	1.9109	2.0081
7	.4049	.4444	2.1434	2.1153	2.2834	2.2996	2.5425
8	.3563	.3555	2.0576	2.4175	2.2672	2.332	2.4291
9	1.9204	2.4708	.2058	.1778	.2753	.1943	.2439
10	2.1643	2.3108	.1886	.1778	.1943	.2229	.2439
11	2.1948	2.1508	.2058	.16	.1943	.2229	.2134
12	1.9966	2.1153	.2229	.16	.2267	.2229	.2134
13	1.8747	2.0442	.2058	.1955	.2267	.2229	.1829
14		1.9731	.2058	.1955	.2429	.2229	.1829
15		1.9553	.1886	.1778	.2429	.2229	.1981
16		1.8842	.1886	.1955	.2429	.2229	.2286
17	.1829	.1244	.2229	.1778	.2429	.2572	.2134
18	.2134	.1778	.2572	.2133	.2591	.2915	.2286
19	.2439	.2311	.3429	.2489	.3239	.3258	.2743
20	.3506	.3377	.3429	.2844	.421	.3429	.2743
21	.3506	.3377	.3086	.3022	.3887	.3601	.2591
22	.3506	.32	.2915	.32	.3239	.3429	.2591
23	.3658	1.5287	1.6632	1.6353	1.668	1.6289	1.3413
24	.3437	.4266	1.5089	1.7598	1.5384	1.749	1.6032
Max	2.1948	2.4708	2.1434	2.4175	2.2834	2.332	2.5425
Min	.1829	.1244	.1886	.16	.1943	.1943	.1829
Avg	.7527	.9953	.8673	.9029	.9683	.9322	.8876

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274177 / 33/11KV MANDAVE S/S

Feeder No / Name : 202 / 11KV GIRVI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6461	1.4058	.2915	.4414	.4287	.4287	.4115
2	1.6461	1.3731	.2915	.4414	.3944	.4287	.4115
3	1.6118	1.3731	.2743	.4414	.3772	.4458	.4115
4	1.6461	1.3895	.2743	.4414	.3772	.463	.4115
5	1.749	1.4548	.3086	.4741	.4287	.4801	.4801
6	1.9719	1.8308	.3258	.4904	.463	.4973	.4801
7	2.2977	1.9779	.2743	.5231	.4458	.3944	.3772
8	1.9376	1.8472	.2401	.2779	.4115	.3086	.2743
9	.2743	.2125	1.4403	1.7491	1.8004	1.6289	1.6289
10	.1715	.1798	1.6975	1.7818	2.0576	1.989	1.8347
11	.1543	.1471	1.7661	1.7818	1.989	1.9376	1.7661
12	.1372	.1144	1.8347	1.7981	2.0576	1.8861	1.7318
13	.1372	.1144	1.9719	1.7981	1.5432	1.7833	1.7318
14		.1144	1.9719	1.6674	1.8176	1.749	1.749
15		.1144	1.869	1.6347	1.7661	1.6118	1.4575
16		.1308	1.7833	1.5366	1.6975	1.3717	1.4232
17	.1543	.1308	.1543	.1798	.2229	.1715	.2058
18	.2229	.1962	.2058	.2452	.2401	.2058	.2058
19	.2572	.2452	.3429	.3106	.3772	.2572	.3086
20	.3944	.2942	.463	.3596	.4458	.4287	.4287
21	.3772	.3106	.4458	.3923	.4458	.3944	.4458
22	.3772	.3269	.4287	.425	.463	.4115	.4458
23	1.5261	.3106	.4458	.4087	.4458	.4115	.4287
24	1.5581	1.4058	.3086	.4414	.4458	.4458	.4115
Max	2.2977	1.9779	1.9719	1.7981	2.0576	1.989	1.8347
Min	.1372	.1144	.1543	.1798	.2229	.1715	.2058
Avg	.9642	.7083	.8088	.8351	.8809	.8388	.8109

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274177 / 33/11KV MANDAVE S/S

Feeder No / Name : 203 / 11KV MANDAVE GAOTHAN GAOTHAN FEEDER  
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8059	.8385	.7888	.8757	.8059	.823	.8573
2	.8059	.8385	.7888	.8757	.7888	.823	.8573
3	.8059	.8385	.7716	.8757	.7888	.823	.8573
4	.8573	.8757	.8402	.913	.8402	.8916	.8573
5	.9259	.9689	.9774	1.0248	.8916	.9774	.9602
6	1.1488	1.1925	1.0974	1.0993	.9774	1.1317	1.046
7	1.0631	1.0807	1.0802	1.1552	.9431	1.046	1.0288
8	.823	.8385	.8573	.8944	.8402	.8916	.8916
9	.7888	.8757	.7545	.8571	.6859	.823	.7373
10	.6859	.7826	.6687	.8385	.6687	.7545	.7545
11	.6687	.7453	.6173	.8198	.6516	.7716	.6687
12	.5487	.6708	.583	.7453	.6173	.7716	.6516
13	.5487	.6894	.5316	.6521	.5658	.7716	.6173
14		.708	.5144	.6335	.5316	.6859	.583
15		.6894	.4973	.5963	.5316	.583	.6173
16		.6708	.4801	.559	.5487	.583	.6516
17	.7716	.7267	.5487	.708	.6173	.6344	.703
18	.8916	.8385	.7202	.7826	.6516	.7373	.7202
19	.9431	.913	.823	.9689	.8573	.8059	.7716
20	.9774	1.0434	.9602	1.0807	1.0117	1.0117	.9602
21	.9431	.9875	.9088	1.0434	.9945	.9088	.9259
22	.9431	.9689	.8573	1.0062	.9259	.8573	.8916
23	.8573	.8571	.8059	.9316	.8745	.8573	.8573
24	.8149	.8385	.7716	.8757	.823	.823	.8573
Max	1.1488	1.1925	1.0974	1.1552	1.0117	1.1317	1.046
Min	.5487	.6708	.4801	.559	.5316	.583	.583
Avg	.8390	.8532	.7602	.8672	.7680	.8245	.8052

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274177 / 33/11KV MANDAVE S/S

Feeder No / Name : 204 / 11KV AHILYANAGAR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5525	.5335	1.3717	1.8099	1.7337	1.9052	1.9814
2	.5525	.5335	1.3717	1.8099	1.7147	1.8671	1.9814
3	.5525	.5335	1.4575	1.8099	1.8099	2.0005	1.9814
4	.5716	.5335	1.4575	1.829	2.2481	2.21	1.9814
5	.6097	.5335	1.7147	1.7909	2.572	2.3243	2.1529
6	.6478	.5906	2.2119	2.0767	2.8387	2.4387	2.6863
7	.5906	.5335	2.4348	2.4577	2.9531	3.0674	3.2769
8	.4763	.4382	2.4177	2.8387	3.0483	3.0674	3.0483
9	2.6292	2.8769	.3429	.4001	.3048	.362	.3239
10	2.7244	2.572	.3258	.381	.3048	.3086	.3239
11	2.6863	2.3624	.2915	.362	.3429	.2915	.3048
12	2.553	2.2481	.2915	.3429	.3429	.2915	.3048
13	2.4387	2.0957	.3086	.3239	.3429	.2915	.3048
14		1.9814	.3086	.3048	.3429	.2743	.3048
15		1.9052	.2572	.3048	.3048	.2743	.3239
16		1.8671	.2229	.2858	.3048	.2743	.362
17	.2667	.1905	.2572	.2858	.3429	.2915	.3048
18	.2858	.2667	.3429	.362	.3429	.2915	.3239
19	.3048	.3429	.4115	.4001	.4572	.2743	.3429
20	.5335	.4191	.4801	.4382	.5335	.4458	.5144
21	.5335	.4763	.4801	.4954	.5335	.4115	.5144
22	.5335	.4954	.4973	.5144	.5335	.4115	.5144
23	.5716	1.5623	1.5775	1.6194	1.8671	1.749	1.7718
24	.5525	.5525	1.3889	1.8099	1.7528	1.9052	1.9814
Max	2.7244	2.8769	2.4348	2.8387	3.0483	3.0674	3.2769
Min	.2667	.1905	.2229	.2858	.3048	.2743	.3048
Avg	1.0080	1.1018	.9259	1.0439	1.1614	1.1262	1.1630

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274177 / 33/11KV MANDAVE S/S

Feeder No / Name : 205 / 11KV PURANDAWADE AG FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.105	.9907	.1886	.2477	.1905	.2286	.2477
2	1.105	.9907	.2058	.2477	.1905	.2286	.2477
3	1.1431	.9907	.2229	.2477	.2096	.2667	.2477
4	1.2193	1.0098	.2915	.2667	.2096	.3048	.2477
5	1.2955	1.086	.3258	.3239	.2286	.362	.3048
6	1.4861	1.5242	.3601	.362	.2667	.4191	.4001
7	1.7528	1.6385	.3258	.3048	.2858	.362	.362
8	1.7718	1.5813	.2915	.2667	.2858	.362	.3239
9	.2286	.1905	1.046	1.1241	1.3336	1.6004	.3048
10	.1905	.1715	1.286	1.2384	1.6956	1.5432	1.7147
11	.1715	.1715	1.286	1.4098	1.6766	1.5432	1.6766
12	.1715	.1524	1.286	1.448	1.5813	1.5261	1.6004
13	.1715	.1524	1.286	1.4861	1.6956	1.5089	1.5242
14		.1334	1.286	1.5051	1.7147	1.4575	1.5051
15		.1334	1.2174	1.5051	1.7909	1.4575	1.4861
16		.1334	1.2003	1.5242	1.6575	1.4232	1.4861
17	.1905	.1524	.12	.1905	.1524	.1372	.1905
18	.2096	.1905	.1715	.1905	.1905	.1715	.1905
19	.2477	.2286	.1886	.2096	.2667	.2058	.2286
20	.2286	.2477	.2229	.2286	.3239	.2401	.2858
21	.2286	.2286	.2229	.2286	.3239	.2229	.2667
22	.2096	.2286	.2058	.2096	.2858	.2229	.2667
23	1.0288	.2286	.2229	.1905	.2667	.2229	.2286
24	1.086	.9907	.1886	.2477	.2096	.2286	.2477
Max	1.7718	1.6385	1.286	1.5242	1.7909	1.6004	1.7147
Min	.1715	.1334	.12	.1905	.1524	.1372	.1905
Avg	.7258	.5644	.5687	.6335	.7097	.6769	.6494

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103] BU 6360

Substation No/ Name :- 274036 / 33/11 KV DAHIGAON SUBSTATION

Feeder No / Name : 201 / 11KV DAHIGAON AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.5144	.9745	.8916	1.286	1.0631	.4458
2	.4287	.5144	.9745	.9945	1.286	1.0974	.4458
3	.4287	.5144	.9745	1.0288	1.286	1.0517	.4458
4	.4287	.5144	1.0974	1.1145	1.286	1.1517	.4458
5	.4287	.5144	1.1517	1.4575	1.4575	1.267	.5144
6	.4458	.5316	1.4998	1.5775	1.749	1.6832	.5487
7			2.1262	2.1434	2.2634	2.1616	
8			2.0119	1.6632	2.2291	1.9004	
9	1.8519	1.6804	.2915	.2915	.2715	.3012	1.7833
10	1.7147	1.7318	.2401	.2743	.2658		1.8519
11	1.6632	1.5947	.2229	.2572	.2353		1.8004
12	1.5432	1.5384	.2229	.2572	.2303	.2058	1.4918
13	1.406	1.5384	.2229	.2058	.2303	.2058	1.3717
14	1.3717	1.3289	.2229	.1886	2.8045	.2229	1.2003
15	1.2689	1.1517	.2229	.2229	.2378	.2401	1.2346
16	1.1145	1.1523	.2401	.2229	.2561	.2572	1.1317
17	.2401	.2195	.2915	.3086	.2926		.2743
18	.4115	.3658	.3429	.3429	.3582		.3429
19	.4801	.4252	.463	.3944	.4557	.4458	.3772
20	.5144	.4607	.463	.5144	.5138	.5144	.4287
21	.5144	.4784	.4458	.5144	.5014	.5144	.4458
22	.5144	.4938	.4458	.5144	.4887	.5144	.4458
23	.5144	.9214	.8573	.9945	1.0631	.4458	.4287
24	.4458	.5144	.9745	.8745	1.0288	1.0631	.4458
Max	1.8519	1.7318	2.1262	2.1434	2.8045	2.1616	1.8519
Min	.2401	.2195	.2229	.1886	.2303	.2058	.2743
Avg	.8262	.8500	.7075	.7187	.9199	.8154	.8137

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274036 / 33/11 KV DAHIGAON SUBSTATION

Feeder No / Name : 202 / 11KV KALAMBOLI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	1.6804	.4607	.4287	.4115	.4607	1.8861
2	1.6289	1.6804	.4755	.4287	.4115	.4607	1.8861
3	1.6289	1.6804	.4607	.4287	.4115	.4755	1.8861
4	1.7147	1.6804	.4784	.4458	.4115	.4706	1.8861
5	1.8861	1.8861	.4961	.4458	.4115	.4938	2.1434
6	2.6578	2.2291	.4961	.4801	.4801	.4961	2.572
7	3.0864	2.7435			.3772		2.9835
8	2.7435	2.6578					2.9492
9	.2743	.3086	2.572	2.4348	2.8349	3.1093	.2743
10	.2401	.3086	2.915	3.0864	3.1007	3.2579	.2401
11	.2401	.2481	3.2579	3.035	3.2007	2.915	.2401
12	.2401	.2126	3.1207	3.155	3.1674	2.9492	.2229
13	.2401	.2126	3.0007	3.0864	3.1093	2.8292	.2058
14	.2401	.2172	2.6063	2.4863	2.8045	2.572	.2058
15	.2401	.2149	2.4348	2.4863	2.9264	2.6063	.2058
16	.2401	.2195	2.3148	2.4863	3.0121	2.6578	.2401
17	.2401	.2481	.3429	.3086	.2804	.3429	.3429
18	.3086	.3012	.3601		.3544	.4115	.3601
19	.4115	.3898	.4458	.3772	.4298	.5144	.4287
20	.4115	.4961	.4458	.5144	.4961	.5144	.4287
21	.4115	.4961	.4801	.5144	.4908	.5144	.4458
22	.4115	.4784	.4801	.4801	.4733	.5144	.4115
23	1.5432	.4938	.4458	.4115	.4733	1.8861	1.8004
24	1.5432	1.5432	.4607	.4115	.4115	.4784	
Max	3.0864	2.7435	3.2579	3.155	3.2007	3.2579	2.9835
Min	.2401	.2126	.3429	.3086	.2804	.3429	.2058
Avg	1.0052	.9428	1.2978	1.3301	1.3252	1.4059	1.0542



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274036 / 33/11 KV DAHIGAON SUBSTATION

Feeder No / Name : 203 / 11KV SHINDEWADI

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	1.4575	.3292	.3601	.3772	.3155	1.3717
2	1.5432	1.4575	.3258	.3601	.3772	.3189	1.3717
3	1.6289	1.4575	.3189	.4115	.3772	.3189	1.3717
4	1.6289	1.4575	.3544	.4115	.3772	.3721	1.3717
5	1.8861	1.6289	.439	.4458	.3772	.4252	1.5432
6	2.4863	.1886	.4784	.463	.463	.4706	1.8861
7	2.6235	2.2291			.2743		2.0576
8	2.4348	2.1434					2.0576
9	.2572	.2058	2.0576	2.1776	2.1262	2.4434	.2229
10	.2058	.2058	2.2291	2.1434	2.3034	2.5339	.2058
11	.2058	.1829	2.2291	2.0576	2.1262	2.4006	.1715
12	.1543	.1772	2.0576	1.8861	2.1033	2.0748	.1886
13	.1543		1.8004	1.8861	1.9281	1.9204	.1715
14	.1543	.1595	2.0576	1.8861	2.1948	2.0576	.1715
15		.1612	2.1434	1.8861	2.1262	2.0233	.1715
16	.1715	.1595	1.9719	1.8861	2.1719	1.8861	.2229
17	.1715		.2915	.3086	.2629	.2572	.3258
18	.2572	.3109	.3086	.3086	.3189	.3429	.3772
19	.2743	.3841	.3944	.4115	.4024	.3772	.4115
20	.4115	.439	.3944	.4115	.4298	.4115	.4287
21	.4115	.4075	.4115	.4115	.3856	.3772	.4115
22	.4115	.4024	.3772	.3772	.3721	.3772	.4115
23	1.3717	.3544	.3429	.3772	.3582	1.3717	1.3889
24	1.4232	1.3717	.3292	.3429	.3772	.3544	1.3717
Max	2.6235	2.2291	2.2291	2.1776	2.3034	2.5339	2.0576
Min	.1543	.1595	.2915	.3086	.2629	.2572	.1715
Avg	.9483	.7701	.9837	.9641	.9831	1.0650	.8202

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274036 / 33/11 KV DAHIGAON SUBSTATION

Feeder No / Name : 204 / 11KV SHERIWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.4458	1.2536	1.286	1.4575	1.5061	.4115
2	.4458	.4458	1.267	1.286	1.4575	1.5061	.4115
3	.4287	.4458	1.2403	1.3717	1.4575	1.5061	.4115
4	.4287	.4458	1.3289	1.4575	1.4575	1.6289	.4115
5	.4801	.4458	1.4175	1.5432	1.5432	1.6832	.4115
6	.4287	.5316	1.6832	1.7661	1.8176	1.949	.5487
7			2.1262	2.0062	2.2634	2.4806	
8			2.1262	2.1091	2.1605	2.3565	
9	1.989	1.8861	.3258	.2915	.1829	.3475	2.2291
10	2.0233	2.2291	.2401	.2401	.1991		2.4348
11	2.1262	2.1262	.2229	.2058			2.4006
12	1.989	2.0119	.2229	.1715			2.4006
13	1.8861	1.949	.2058	.1886	.2279	.1886	2.2634
14	1.7833	1.7528	.2058	.1715	.2279	.1886	2.2291
15	1.6804	1.5947	.2401	.2058	.2507	.2401	2.1776
16	1.4575	1.6832	.2401	.2229	.2534	.2229	2.0919
17	.3086	.2835	.3601	.2229	.3189	.3429	.2915
18	.3086	.3292	.3944	.2229	.4252	.4115	.3429
19	.4287	.4207	.463	.2572	.5258	.5144	.4287
20	.4801	.5853	.4801	.5144	.5731	.5144	.4287
21	.4801	.5316	.463	.5316	.5258	.5144	.4458
22	.4801	.4938	.463	.5144	.4733	.5144	.4458
23	.4801	1.2803	1.2003	1.286	1.5249	.4115	.4287
24	1.286	.4458	1.2403	1.2346	1.3717	1.5415	.4115
Max	2.1262	2.2291	2.1262	2.1091	2.2634	2.4806	2.4348
Min	.3086	.2835	.2058	.1715	.1829	.1886	.2915
Avg	.9930	1.0165	.8088	.8045	.9407	.9795	1.0935

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274036 / 33/11 KV DAHIGAON SUBSTATION

Feeder No / Name : 205 / 11KV DAHIGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.8573	.8596	.9335	.8573	.8145	.8573
2	.8573	.8573	.7973	.9335	.8573	.8145	.8573
3	.8573	.8573	.7973	1.0269	.8573	.823	.8573
4	.9431	.8573	.9145	1.0269	.8573	.905	.8573
5	.9431	.8573	1.0631	1.0829	.8573	1.086	.8573
6	1.1145	1.2003	1.3575	1.307	1.2003	1.2803	1.2003
7			.9745		.8573	1.0059	.8573
8			.8507	.9335	.6859	.905	.8573
9	.8573	.5144	.7468	.9335	.543	.724	.5144
10	.6001	.5144	.6535	.6859	.543	.6697	.5601
11	.6001	.543	.6535	.6001	.5316	.3429	.5601
12	.5144	.5316	.5601	.5144	.543	.3429	.5601
13	.4287	.5316	.5601	.4287	.5068	.3429	.4668
14	.4801	.5068	.4668	.4287	.4887	.3429	.5601
15	.4287	.4525	.4668	.4287	.4733	.3429	.4668
16	.4287	.4525	.5601	.4287	.4887	.3429	.5601
17	.5144	.4887	.5601	.5144	.543	.5144	.6535
18	.6859	.5792	.6535		.6335	.5144	.7468
19	.8573	.8145	1.0269	.8573	.6201	1.0288	.9431
20	1.2003	1.1517	1.2136	1.2003	1.2048	1.2003	1.2136
21		1.1403	1.1203	1.2003	1.1765	1.2003	1.2136
22	1.0288	1.0631	1.1203	1.0288	1.086	1.0288	1.1203
23	.8573	.905	.9335	.8573	.905	.8573	.9335
24	.8573	.8573	.8859	.9335	.8573	.905	.8573
Max	1.2003	1.2003	1.3575	1.307	1.2048	1.2803	1.2136
Min	.4287	.4525	.4668	.4287	.4733	.3429	.4668
Avg	.7577	.7515	.8248	.8311	.7573	.7639	.7972

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274036 / 33/11 KV DAHIGAON SUBSTATION

Feeder No / Name : 206 / 11KV EXPRESS SHIVPRASAD NON SHEDDABLE EXPRESS HV FEEDERS  
MILK Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.12	.124	.0514	.1029	.0526	.0343
2	.0343	.12	.0886	.0514	.1029	.0526	.0343
3	.0343	.12	.0895	.0514	.1029	.0526	.0343
4	.0514	.12	.0876	.0514	.1029	.0351	.0343
5	.0514	.12	.0886	.0343	.1029	.0351	.0343
6	.0514	.12	.1063	.1029	.1029	.0354	.0343
7	.1029	.12	.128	.1029	.0343	.0351	.0343
8	.12	.12	.1417	.12	.0343	.0354	.0343
9	.1372	.1372	.1494	.1372	.1463	.0914	.0343
10	.1715	.1886	.168	.1372		.1417	.0747
11	.2058	.1829	.1867	.2058	.1772	.1715	.1494
12	.1543	.1417	.1867	.2572	.056	.0343	.168
13	.1543	.1448	.1494	.2572	.2103	.0343	.1867
14	.1543	.2195	.2241	.2058	.2172	.0343	.1867
15	.1029	.2126	.2614	.2058	.2481	.0343	.168
16	.1372	.1949	.2241	.12	.2534	.0343	.1494
17	.2229	.2195	.2241	.2572	.2172	.0343	.1867
18	.1715	.2303	.2427	.2572	.2126	.0343	.2241
19	.2058	.2378	.2427	.2572	.2172	.0343	.2241
20	.3086	.2303	.1867	.2572	.2303	.0343	.2427
21	.3086	.2126	.1867	.2572	.2303	.0343	.2427
22	.3086	.2126	.168	.2572	.1753	.0343	.2241
23	.2401	.2195	.168	.2572	.1417	.0343	.2054
24	.1494	.2401	.1629	.1307	.2572	.124	.0343
Max	.3086	.2401	.2614	.2572	.2572	.1715	.2427
Min	.0343	.12	.0876	.0343	.0343	.0343	.0343
Avg	.1520	.1744	.1661	.1676	.1598	.0531	.1240

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274036 / 33/11 KV DAHIGAON SUBSTATION

Feeder No / Name : 207 / 11 KV PIRALE AG

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2401	.3544	.5144	.6859	.5316	.2229
2	.2229	.2401	.3544	.6001	.6859	.5316	.2229
3	.2229	.2401	.3544	.6001	.6859	.5487	.2229
4	.2229	.2401	.4572	.6001	.6859	.6201	.2229
5	.2229		.5316	.7202	.7716	.7087	.2229
6	.2229	.2915	.7442	.9602	.9945	.9145	.2743
7			1.3289	1.2174	1.2003	1.2757	
8			1.2048	.8573	.9945	1.2403	
9	1.0117	1.0288	.1543	.12	.1417	.1448	1.0288
10	1.0631	1.1145	.12	.1029	.1052		1.0288
11	1.1145	1.1523	.1029	.1029	.1063		1.1145
12	1.1145	1.0974	.0686	.1029	.1052	.1029	1.166
13	.9774	1.0631	.0857	.0857	.1052	.1029	1.1145
14	.8916	1.0059	.0686	.0857	.1063	.08	.9774
15	.8745	.8859	.0686	.1029	.0905	.12	.9431
16	.823	.7087	.0857	.12	.0914	.1029	.8573
17	.1372	.128	.1029	.1372	.1254	.1543	.1372
18	.1715	.1646	.1372	.1372	.1578	.1886	.1543
19	.2058	.2561	.2058	.2058	.2103	.2401	.2058
20	.2743	.2561	.2229	.2401	.2481	.2572	.2058
21	.2572	.2481	.2229	.2572	.2481	.2572	.2229
22	.2572	.2481	.2058	.2401	.2303	.2572	.2229
23	.2401	.3658	.5144	.6001	.5373	.2229	.2229
24	.2401	.2401	.3658	.5144	.6001	.5316	.2229
Max	1.1145	1.1523	1.3289	1.2174	1.2003	1.2757	1.166
Min	.1372	.128	.0686	.0857	.0905	.08	.1372
Avg	.5004	.5341	.3359	.3844	.4131	.4152	.5097

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103] BU 6360

Substation No/ Name :- 274039 / 33/11 KV NATEPUTE SUB-STATION

Feeder No / Name : 201 / 11KV DHARMPURI AG SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER  
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.5316	1.2955	1.7833	1.7814	1.9204	.4801
2	.5144	.5487	1.3279	1.8861	1.8299	1.9547	.4801
3	.5487	.5658	1.4089	1.989	1.8623	2.0062	.5144
4	.6001	.583	1.5061	2.1091	1.9595	2.0576	.5144
5	.6001	.6001	1.7814	2.2291	2.0243	2.1091	.5144
6	.6344	.6173	2.0891	2.3491	2.0081	2.1605	.583
7	.5658	.5144	2.251	2.3148	2.753	2.2805	.5316
8	.4801	.4287	2.1052	2.2805	2.6235	2.4177	.463
9	2.9664	2.6235	.3944	.3772	.3944	.3086	2.2805
10	3.155	2.9835	.3601	.3258	.3086	.3086	2.5034
11	.5144	2.8292	.2572	.2401	.3086	.2915	2.452
12	1.9033		.2401	.2572	.2915	.3601	2.7092
13	3.0693	1.9204	.2229	.2915	.2401	.3429	2.5892
14		2.0405	.2401	.2743	.2058	.3429	2.6578
15	2.8635	2.2119		.2058	.2058	.3258	2.4006
16	2.572	2.0405	.2743	.2229	.2915	.3601	2.1948
17	.1886	.2401	.3086	.3258	.3429	.3772	.3086
18	.3772		.4115	.4458	.3601	.3944	.3772
19	.4287	.3944	.4973	.4973	.3944	.4287	.4973
20	.6173	.4287	.4973	.463	.4458	.5316	.6173
21	.5144	.4973	.5144	.463	.5144	.5316	.5316
22	.4973	.4801	.4801	.4801	.4973	.5144	.4458
23	.5316	.7287	1.6975	1.6356	1.8176	.5144	.4801
24	.4801	.5144	1.166	1.6804	1.7004	1.8861	.5316
<b>Max</b>	<b>3.155</b>	<b>2.9835</b>	<b>2.251</b>	<b>2.3491</b>	<b>2.753</b>	<b>2.4177</b>	<b>2.7092</b>
<b>Min</b>	<b>.1886</b>	<b>.2401</b>	<b>.2229</b>	<b>.2058</b>	<b>.2058</b>	<b>.2915</b>	<b>.3086</b>
<b>Avg</b>	<b>1.0914</b>	<b>1.1056</b>	<b>.9273</b>	<b>1.0470</b>	<b>1.0484</b>	<b>1.0302</b>	<b>1.1524</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274039 / 33/11 KV NATEPUTE SUB-  
STATION

Feeder No / Name : 202 / 11KV NATEPUTE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7888	.8916	1.2174	.8916	.8745	.9259	.8402
2	.8402	.9602	1.166	.9774	.8059	.9945	.8745
3	.8916	1.0288	1.1145	1.0631	1.0288	1.0631	.9259
4	.9774	1.1145	1.2003	1.1488	1.166	1.1317	.9774
5	1.0288	1.2003	1.2174	1.2346	1.166	1.2003	1.046
6	1.166	1.286	1.2689	1.3375	1.2517	1.2689	1.3203
7	1.0802	1.2003	1.2346	1.2517	1.166	1.2003	1.2517
8	1.0288	1.1145	1.0288	1.166	.9945	1.1145	1.1317
9	.9259	1.046	.9259	1.0117	.9774	1.0288	.9774
10	1.0288	.9431	.8916	.9259	.9774	1.0631	.9774
11	1.0117	.9088	.8573	1.0117	1.0288	1.0974	.9945
12	.9945	.8573	.8402	.9945	1.0631	1.3546	.9431
13	.9602	.8573	.8745	1.0117	.9774	1.3546	.9602
14	.9088	.8745	.9259	.9945	1.0288	1.0117	.9945
15	.8745	.8916	1.046	1.0117	.9774	1.0288	.9259
16	1.2517	.8402	1.0117	.9945	1.046	1.0631	.8745
17	1.0117	.9602	.8745	1.0974	1.0117	1.046	.8916
18	.9774	.9602	.9945	1.0802	1.0631	1.0117	.9259
19	1.1488	1.0802	1.1317	1.046	1.1317	1.0974	1.0288
20	1.3032	1.0974	1.1145	1.166	1.1145	1.1488	1.1488
21	1.2003	1.1145	1.0974	1.1488	1.0974	1.0631	1.1145
22	1.1145	1.1145	1.0117	1.0117	1.0631	1.0117	1.0631
23	.9774	1.2003	.8916	.9602	.9602	.9431	.9259
24	.8059	.823	1.2003	.8059	.8402	.8573	.9088
<b>Max</b>	<b>1.3032</b>	<b>1.286</b>	<b>1.2689</b>	<b>1.3375</b>	<b>1.2517</b>	<b>1.3546</b>	<b>1.3203</b>
<b>Min</b>	<b>.7888</b>	<b>.823</b>	<b>.8402</b>	<b>.8059</b>	<b>.8059</b>	<b>.8573</b>	<b>.8402</b>
<b>Avg</b>	<b>1.0124</b>	<b>1.0152</b>	<b>1.0474</b>	<b>1.0560</b>	<b>1.0338</b>	<b>1.0867</b>	<b>1.0009</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274039 / 33/11 KV NATEPUTE SUB-  
STATIONFeeder No / Name : 203 / 11KV MANDAVE AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.3772	.703	.9602	.9088	.8402	.3772
2	.3429	.3944	.7716	1.046	.8573	.8745	.3772
3	.3258	.4115	.9945	1.1317	.9602	.9088	.3772
4	.3601	.4287	1.0802	1.2174	1.0631	.9431	.4115
5	.4115	.4458	1.0288	1.3032	1.1145	.9774	.4287
6	.4458	.463	1.0631	1.3717	1.1831	1.0288	.463
7	.3944	.4287	1.4403	1.4575	1.6194	1.3375	.4801
8	.4115	.3944	1.406	1.5604	1.6804	1.6461	.4287
9	1.3889	.5658	.3258	.2743	.3429	.2743	1.0802
10	1.4575		.2572	.2401	.2572	.2572	1.3717
11	1.5775		.2058	.1886	.2058	.1886	1.4403
12	1.4918	.9088	.1715	.1715	.1886	.2058	1.286
13	1.4403	1.3032	.1543	.1715	.1372	.1886	1.3032
14	1.3375	1.166	.1543	.1543	.1543	.1886	1.2174
15	1.2346	.8916	.1543	.1715	.1372	.1715	1.2346
16	1.1488	.1543	.1715	.1715	.1886	.1886	1.166
17	.12	.1543	.1372	.2058	.2229	.2229	.2229
18	.2401	.2572		.3086	.2915	.2401	.2401
19	.3086	.3429	.3429	.3086	.3772	.2743	.3086
20	.3944	.3258	.3429	.3772	.3772	.3429	.3772
21	.3601	.3429	.3601	.4458	.3944	.3601	.3601
22	.3601	.6173	.3429	.4115	.3772	.3429	.3772
23	.3601	.6001	.8573	.9431	.8402	.3429	.3601
24	.3429	.3601	.6001	.8916	.9088	.8059	.3601
<b>Max</b>	<b>1.5775</b>	<b>1.3032</b>	<b>1.4403</b>	<b>1.5604</b>	<b>1.6804</b>	<b>1.6461</b>	<b>1.4403</b>
<b>Min</b>	<b>.12</b>	<b>.1543</b>	<b>.1372</b>	<b>.1543</b>	<b>.1372</b>	<b>.1715</b>	<b>.2229</b>
<b>Avg</b>	<b>.6923</b>	<b>.5152</b>	<b>.5681</b>	<b>.6452</b>	<b>.6162</b>	<b>.5480</b>	<b>.6687</b>



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274039 / 33/11 KV NATEPUTE SUB-

STATION

Feeder No / Name : 204 / 11KV LONAND AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5892	1.8004	.9717	1.3032	1.6289	1.4918	1.6289
2	2.7435	1.7833	1.004	1.3546	1.5223	1.5261	1.6632
3	2.9492	1.7661	.9717	1.406	1.587	1.5604	1.749
4	3.1036	1.749	1.085	1.4575	1.587	1.6118	1.869
5	3.0864	1.7318	1.286	1.5089	1.6356	1.6632	1.9547
6	3.3779	1.7147	1.2793	1.5775	1.7652	1.7147	2.0405
7		1.7833	1.7652	1.5089	1.8299	1.6632	2.2977
8	2.4006	1.8347		1.4232	1.7661	1.6289	2.0405
9	1.5604	1.7661		1.5546	1.9033	1.6289	1.4575
10	1.3375	1.7833	2.0233		2.2634	1.9547	1.5775
11	.4115	1.5604	2.1605	1.8299	2.2805	2.0233	1.5089
12	.3601			2.0891	2.2634	2.1434	1.4918
13	.3429	1.3717	2.0405	1.9271	2.0748	2.0576	1.406
14	.3258	1.4918		1.9919	2.0919	1.7652	1.3717
15	.3429			1.8623	2.1091	1.749	1.2517
16	.3601	.4458	2.0576	1.8138	2.0233	1.7652	1.2689
17	.4287	.4458	1.9719	.5182		.4458	
18	.3944	.5144	.6001	.6173	.6001	.5144	.463
19	.6001	.6344	.5658	.6001	.6687	.6344	.6173
20	.8573	.7202	.6001	.703	.7373	.7888	.7888
21	.8402	.7888	.6344	.8402	.8059	.7716	.7716
22	.8573	.9774	.6001	.8059	.7716	.7202	.7888
23	1.6975	.9774	1.2174	1.4251	1.5432	1.4403	1.6804
24	1.4575	1.8347	.9259	1.2517	1.5223	1.4575	1.5604
<b>Max</b>	<b>3.3779</b>	<b>1.8347</b>	<b>2.1605</b>	<b>2.0891</b>	<b>2.2805</b>	<b>2.1434</b>	<b>2.2977</b>
<b>Min</b>	<b>.3258</b>	<b>.4458</b>	<b>.5658</b>	<b>.5182</b>	<b>.6001</b>	<b>.4458</b>	<b>.463</b>
<b>Avg</b>	<b>1.4098</b>	<b>1.3398</b>	<b>1.2506</b>	<b>1.3639</b>	<b>1.6079</b>	<b>1.4467</b>	<b>1.4456</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274039 / 33/11 KV NATEPUTE SUB-

STATION

Feeder No / Name : 205 / 11KV PHADATARI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.0686	.2401	.2401	.2401	.2572	.2401
2	.2058	.0686	.2572	.2572	.2915	.2743	.2572
3	.2915	.0857	.2915	.2572	.3258	.2915	.2572
4	.3258	.0857	.3258	.2743	.3601	.3086	.2915
5	.3601	.0686	.3601	.2915	.3429	.3258	.3429
6	.3429		.3772	.3086	.3772	.3429	.3772
7	.2401		.2915	.2743	.2572	.2915	.2572
8	.2229		.2401	.2401	.2058	.2401	.2058
9	.1715		.2058	.2058	.2229	.1886	.1372
10	.1372		.1715	.1543	.1715	.1886	.12
11	.1372		.1372	.12	.12	.1715	.1029
12	.12		.12	.1029	.1543	.1372	.0857
13	.1372	.0514	.12	.1372	.1029	.1029	.0857
14	.1543		.1543	.1029	.12	.0857	.1029
15	.12		.1372	.12	.12	.12	.0857
16		.1715	.12	.12	.1543	.12	.1029
17	.0514	.1715	.1372	.1715		.1372	
18	.0686	.1886	.1886	.2058	.1886	.1543	.1372
19	.0686	.2058	.2401	.2058	.2229	.2058	.1886
20	.0857	.2401	.2743	.2915	.2572	.2915	.2572
21	.0686	.3086	.2915	.3258	.2915	.2743	.2401
22	.0686	.3086	.2572	.2743	.2743	.2401	.2401
23	.0857	.2572	.2572	.2229	.2572	.2401	.2401
24	.2229	.0686	.2572	.2401	.2229	.2401	.2401
<b>Max</b>	<b>.3601</b>	<b>.3086</b>	<b>.3772</b>	<b>.3258</b>	<b>.3772</b>	<b>.3429</b>	<b>.3772</b>
<b>Min</b>	<b>.0514</b>	<b>.0514</b>	<b>.12</b>	<b>.1029</b>	<b>.1029</b>	<b>.0857</b>	<b>.0857</b>
<b>Avg</b>	<b>.1700</b>	<b>.1566</b>	<b>.2272</b>	<b>.2143</b>	<b>.2296</b>	<b>.2179</b>	<b>.1998</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN

Feeder No / Name : 201 / 11KV WATER SUPPLY

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6766	1.6289	.3353	.3086	.407	.3521	1.4575
2	1.8442	1.7147	.3185	.3086	.407	.3185	1.5432
3	2.0957	1.7147	.2753	.2915	.3647	.285	1.5074
4	2.1795	1.8861	.2591	.3258	.39	.3018	1.5384
5	2.3472	1.9719	.3018	.3429	.407	.3856	1.6385
6	2.431	2.0576	.3353	.3475	.4144	.4694	1.7814
7	2.2672	2.4006	.3018	.3292	.373	.3688	2.3739
8	2.1795	2.1434	.2683	.2572	.2949	.3185	2.1628
9		.2429	1.7814	1.7328	1.9719	2.0576	.2429
10		.2458	2.1052	1.8623	2.0576	2.2291	.2429
11		.2458	2.1052	1.7814	2.1434	2.3148	.2915
12		.2105	1.9757	1.8138			.2915
13		.2267	1.8623	1.7814		2.0576	.2429
14		.2543		1.8138	1.9719	1.8004	.2429
15		.2374	1.8138	1.8138	1.9719	2.0119	.3018
16	.1943	.2321	1.3765	1.8461	1.8861	1.8004	.2429
17	.2427	.4024	.2401	.2294	.2683	.1966	.2012
18	.2801	.3856	.2572	.2949	.3239	.2458	.2267
19	.3174	.3856	.3086	.3391	.3353	.2949	.2683
20	.3506	.3401	.3601	.4144	.3521	.426	.3018
21	.3921	.3725	.3601	.4049	.3856	.4049	.3077
22	.3801	.3856	.3391	.4144	.4024	.4049	.3725
23	1.4937	.3688	.3222	.426	.3856		1.4251
24	1.4083	1.4575	.3353	.3222	.4144	.3688	1.4251
Max	2.431	2.4006	2.1052	1.8623	2.1434	2.3148	2.3739
Min	.1943	.2105	.2401	.2294	.2683	.1966	.2012
Avg	1.2988	.8963	.7799	.8251	.8149	.8824	.8596

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN

Feeder No / Name : 202 / 11KV FONDSHIRAS AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	07-AUG-17
HR	Load (MW)
23	.0134
Max	.0134
Min	.0134
Avg	.0134

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN

Feeder No / Name : 203 / 11KV PALASMANDAL

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.503	.4801	1.6194	2.0119	1.9524	2.0119	.4858
2	.4862	.4801	1.6766	1.9719	2.1548	2.1795	.4641
3	.4694	.463	2.0957	2.0576	2.2891	2.431	.4424
4	.4359	.4287	2.1795	2.2291	2.3868	2.5987	.4475
5	.4862	.4115	2.3472	2.652	2.5434		.4694
6	.503	.3772	2.431	2.4863	2.713	2.6825	.5087
7	.503	.3429	2.6825	2.7435	2.8178	2.7664	.4748
8	.3688	.2743	2.7664	2.8292	2.9165	2.8502	.4096
9		2.5911	.3077	.2429	.3086	.3258	2.5911
10		2.8826	.1943	.2429	.2743	.2743	2.915
11	2.5425	2.7978	.1943	.1943	.2572	.2401	1.1174
12	2.4615	2.5888	.1943	.1943			1.1498
13	2.4453	2.5396		.1943		.2229	1.1336
14	2.4129	2.4863	.1943	.1943	.2401	.2012	2.9959
15	2.2348	2.3205	.1943	.1943	.2572	.1886	3.2922
16	2.753	2.3205		.1619	.2058	.2058	1.917
17	.2801	.4024	.2572	.1677		.2321	.2267
18	.2987	.3856	.3086	.3277		.3018	.3018
19	.3361	.3856	.3429	.3932		.3353	.4359
20	.3658	.503	.4287	.4858	.4862	.4807	.503
21	.4031	.5197	.4458	.4973	.4694	.4973	.5197
22	.4668	.5197	.5121	.4588	.4694	.4641	.5365
23	.4287	1.4251	1.8004	1.8233	.503		.4694
24	.5197	.4801	1.4575	1.8861	1.8842	1.9281	.4973
Max	2.753	2.8826	2.7664	2.8292	2.9165	2.8502	3.2922
Min	.2801	.2743	.1943	.1619	.2058	.1886	.2267
Avg	.9866	1.1836	1.1196	1.1100	1.3226	1.1152	1.0127

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN

Feeder No / Name : 204 / 11KV FONDSHIRAS GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5944	.631	.6874	.6516	.6796	.7042	.7042
2	.6874	.6516	.6964	.6687	.6554	.7712	.6718
3	.7209	.7202	.8383	.8059	.6802	.8383	.7461
4	.7712	.7202	.9221	.9877	.7716	.8718	.763
5	.8383	.7716	1.0059	1.0791	.8288	.9389	
6	.8551	.9945	1.0562	1.1888	.9282	.9892	.9724
7	.788	.8573	.8383	.8745	.8453	.8383	.9326
8	.7042	.6516	.7545		.7537	.8048	.7459
9		.5571	.6154	.5668	.6344	.7373	.583
10		.4915	.5506	.421	.6535	.6859	.5668
11	.4372	.4641	.3401	.3749	.5487	.5658	.5506
12	.4049	.4424		.3401			.5182
13	.3563	.4096		.3887		.4801	
14		.3978	.4049	.4049	.4287	.3429	.4372
15	.4534	.4144	.4049	.3725	.4108	.3772	.5068
16	.3887	.3978	.4049	.4534	.4287	.3944	.373
17	.4294	.3725	.4481	.4641	.4862	.4748	.3856
18	.6348	.5365	.4973	.6226	.5365	.5801	.503
19	.703	.7042	.7316	.7373	.5992	.6952	.6203
20	.8402	.7209	.8402	.9069	.8215	.8192	.6316
21	.8573	.8383	.8745	.8619	.8383	.8029	.6874
22	.8962	.7545	.8048	.779	.8048	.763	.7125
23	.7373	.7377	.6613	.7293	.7377		.7209
24	.6371	.6516	.6706	.6001	.6962	.6874	.6882
Max	.8962	.9945	1.0562	1.1888	.9282	.9892	.9724
Min	.3563	.3725	.3401	.3401	.4108	.3429	.373
Avg	.6541	.6204	.6840	.6643	.6713	.6892	.6373

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN

Feeder No / Name : 205 / 11KV TAMSHIDWADI

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3185	.4801	1.3413	1.5123	1.7368	1.6766	.3932
2	.3018	.4973	1.4419	1.4918		1.8442	.3725
3	.285	.4973	1.6766	1.5775	1.9757	1.9281	.3725
4	.2683	.5068	1.6933	1.6289	2.1548	2.0454	.3887
5	.8048	.4801	1.8107	1.7318	2.2874	2.146	.4049
6	.3185	.4115	1.8275	1.8004	2.3739	2.1795	.421
7	.3185	.3429	2.0119	2.4348	2.4587	2.3472	.3812
8	.3353	.2743	2.0287	2.3148	2.4531	2.2996	.3481
9		2.2708	.2105	.2753	.2915	.2743	2.1376
10		2.3758	.1781	.2429	.2743	.2629	2.332
11	2.3805	2.13	.1457	.1619	.1886	.2279	2.3482
12	2.4291	1.989		.1134			2.0891
13	2.1052	1.9062		.1781		.1715	2.17
14		1.8652	.1296	.1457	.1543	.1543	2.0891
15	1.8299	1.8023	.1457	.1457	.1886	.1543	2.3348
16	1.749	1.6409	.1781	.1943	.1372	.1886	
17	.1448	.1844	.1543	.1802	.2105	.1802	
18	.2058	.2591	.2401	.2429	.2915	.2486	
19	.2743	.3018	.3086	.3391	.3353	.2984	.3018
20	.3361	.3353	.3658	.407	.3563	.4144	.3353
21	.3547	.3521	.3429	.3932	.3856	.3932	.3688
22	.4108	.3688	.3601	.39	.3725	.3812	.4024
23	.4481	1.1736	1.286	1.5546	1.587		.4024
24	.3353	.4287	1.2308	1.4563	1.6617	1.6598	.3887
Max	2.4291	2.3758	2.0287	2.4348	2.4587	2.3472	2.3482
Min	.1448	.1844	.1296	.1134	.1372	.1543	.3018
Avg	.7597	.9531	.8686	.8714	1.0417	.9762	.9896

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN

Feeder No / Name : 206 / 11KV KADAMWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6194	1.9231	.4527	.6344	.5801	.4694	1.9433
2	1.8442	2.1472		.6516	.5801	.4527	2.1628
3	2.1795	2.2592	.4191	.6805	.5182	.4359	2.2939
4	2.431	2.3348	.4024	.6979	.5243	.4862	2.5434
5	2.6825	2.4646	.4359	.6173	.5735	.5365	2.6282
6	2.8502	3.0807	.5533	.6001	.6104	.6036	2.713
7	2.8502	3.3836	.503	.5144	.5304	.503	3.4537
8	3.0011	3.0864	.4191	.4115	.2321	.421	3.3196
9		.2652	2.5101	2.5749	3.0864	3.275	.25
10		.2652	3.1741	2.4291	3.4385	3.3779	.2591
11	.2591	.2818	3.0607	2.7206	3.3608	3.4637	.2105
12	.2267	.2883	2.9312	2.9797			.2429
13	.2753	.2984		2.7044		3.3436	.3239
14	.2753	.2984	2.9312	2.8178	3.155	2.9321	.2591
15	.2267	.2785	2.4291	2.7368	2.8635	2.8978	
16	.2105	.2818	2.251	2.7206	2.5943	3.1855	.2683
17		.2683	.2058	.2818	.1677	.2458	.2105
18	.2058	.3353	.3429	.3481	.3353	.3222	.2683
19	.3086	.4359	.4854	.4049	.4359	.3812	.3077
20	.4801	.4694	.4801	.5801	.4694	.503	.3521
21	.5415	.503	.5316	.5735	.503	.4915	.4359
22	.4801	.503	.5868	.5243	.5365	.5426	.503
23	1.6278	.503	.6173	.6133	.503		1.9281
24	1.4632	1.6118	.4694	.5868	.5898	.503	1.8623
Max	3.0011	3.3836	3.1741	2.9797	3.4385	3.4637	3.4537
Min	.2058	.2652	.2058	.2818	.1677	.2458	.2105
Avg	1.2399	1.1486	1.1906	1.2669	1.1904	1.3351	1.2495



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN

Feeder No / Name : 208 / 11 KV ISHWAR PIND AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6539	.7373	.1457	.2229	.1526	.1341	1.1603
2	.7042	.7716	.1341	.218	.1326	.1174	1.1797
3	.7712	.8402	.1174	.2401	.1219	.1341	1.3395
4	.8551	.9259	.1509	.2401	.1357	.1509	1.4089
5	1.0059	.9602	.1677	.2614	.1475	.1677	1.5089
6	1.2071	1.1317	.2012	.2641	.1865	.1677	1.6078
7	1.291	1.3032	.1677	.2058	.1658	.1509	1.6907
8	1.0898	1.2689	.1619	.2195	.1311	.1341	
9		.1147	1.3603	1.166	1.5775	1.6975	
10		.0995	1.587	1.2793	1.8519	1.7661	
11	.081	.0819	1.7004	1.4899	2.0919	1.8176	
12	.081	.0995	1.8623	1.5708			
13	.081	.0819		1.5708		2.0919	
14	.0972	.0983	1.5061	1.6194		2.0576	
15	.0972	.0829	1.4089	1.5223		1.989	
16	.081	.0995	1.3603		1.6632	2.0538	
17	.112	.0671	.1029		.1174	.0983	
18	.1372	.1006	.1543	.1357	.1296	.1187	.1341
19	.1867	.1174	.2195	.1526	.1296	.1492	.1509
20	.1772	.1509	.2058	.1619	.1341	.1311	.1509
21	.1715	.1677	.2058	.1696	.1457	.1475	.1457
22	.1753	.1677	.218	.1526	.1341	.1658	.1457
23	.695	.1781	.2126	.1526	.1509		1.073
24	.6154	.7373	.1619	.2204	.1475	.1509	1.065
Max	1.291	1.3032	1.8623	1.6194	2.0919	2.0919	1.6907
Min	.081	.0671	.1029	.1357	.1174	.0983	.1341
Avg	.4712	.4327	.5875	.6016	.4724	.7087	.9115

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN

Feeder No / Name : 209 / 11 KV MARKADWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1029	.4527	.3601	.5087	.3856	.1509
2	.1341	.1029	.4694	.3601	.5243	.3688	.1296
3	.1006	.12	.503	.4115	.6443	.3856	.1187
4	.1341	.1214	.503	.4239	.6783	.4694	.1311
5	.1457	.12	.502	.5249	.663	.503	.1475
6	.1509	.1052	.5365	.5487	.7209	.503	.1311
7	.1509	.1029	.5365	.7865	.7042	.6036	.1341
8	.1006	.0857	.1677	.6173	.664	.6539	.0995
9		.5365	.0648	.0486	.1029	.0686	.4858
10		.547	.0648	.081	.0686	.0686	.5992
11	.4858	.4915	.0324	.0486	.0514	.0724	.5365
12	.4049	.5138	.0324	.0486			.502
13	.3887	.4915	.0486	.0648		.0514	.4372
14		.4144	.0486	.0486	.0343	.0514	.4372
15	.4696	.3521	.081	.0486	.0351	.0549	
16	.3887	.3277	.0486	.081	.0343	.0343	.3563
17	.056	.0503	.0514	.0492	.0671	.0671	.0671
18	.056	.0671	.0549	.0655	.1006	.0678	.0671
19	.056	.1006	.0686	.0848	.1174	.0819	.0671
20	.0934	.1174	.0857	.1357	.1341	.1311	.1006
21	.0857	.1341	.1029	.1492	.1509	.1341	.1174
22	.0934	.1341	.1029	.1492	.1677	.1296	.1341
23	.0886	.4191	.2915	.2949	.3688		.1509
24	.1677	.12	.4694	.3086	.3932	.4024	.1492
Max	.4858	.547	.5365	.7865	.7209	.6539	.5992
Min	.056	.0503	.0324	.0486	.0343	.0343	.0671
Avg	.1858	.2366	.2216	.2392	.3152	.2404	.2283

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274130 / 33/11 KV DHARMPURI

Feeder No / Name : 201 / 11KV KOTHALE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.8004	1.5242	.2572
2	1.8861	1.6004	.2572
3	1.9204	1.6461	.2743
4	2.0233	1.6766	.2743
5	2.0919	1.6918	.3086
6	2.1262	1.7223	.3258
7	2.1605	1.7985	.2915
8	2.332	1.9204	.2915
9	.2229	.1981	1.8519
10	.2229	.1829	2.0748
11	.2058	.1829	2.2291
12	.2058		2.1776
13	.1886	.1219	2.1776
14	.1543	.1372	2.1776
15	.1715	.1677	2.0919
16	.1886	.1524	2.1262
17	.2401	.1981	.2229
18	.2572	.2591	.2229
19	.2743	.2591	.2915
20	.2915	.3048	.2915
21	.2915	.2896	.2915
22	.3086	.2896	.2915
23	1.5947	.2134	.2915
24	1.5604	1.4175	.2401
Max	2.332	1.9204	2.2291
Min	.1543	.1219	.2229
Avg	.9466	.7806	.8888

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274130 / 33/11 KV DHARMPURI

Feeder No / Name : 202 / 11KV GURSALE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2134	.9088
2	.2743	.2134	.9088
3	.3086	.2286	.9088
4	.3086	.2743	.9259
5	.2401	.2591	.6401
6	.2401	.2591	1.0974
7	.2229	.2439	1.2517
8	.2401	.2439	1.2517
9	1.0288	1.0822	.2058
10	1.1145	1.2041	.1715
11	1.2003	1.2041	.1543
12	1.2517	1.2041	.1886
13	1.2517	1.0517	.1543
14	1.2517	1.0517	.1372
15	1.2517	1.0517	.1543
16	1.2346	1.0059	.1715
17	.1886	.1829	.1715
18	.2229	.1829	.2229
19	.2401	.2286	.2572
20	.2572	.2439	.2572
21	.2572	.2591	.2743
22	.2743	.2743	.2915
23	.2743	.7773	.8573
24	.2743	.2134	.9088
Max	1.2517	1.2041	1.2517
Min	.1886	.1829	.1372
Avg	.5701	.5481	.5196

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274130 / 33/11 KV DHARMPURI

Feeder No / Name : 203 / 11KV SHINDEWADI FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0069	.0061	.0069
2	.0069	.0061	.0069
3	.0069	.0061	.0069
4	.0069	.0061	.0069
5	.0069	.0061	.0069
6	.0069	.0061	.0069
7	.0069	.0061	.0017
8	.0069	.0061	.0069
9	.0069	.0061	.0206
10	.0069	.0183	.0206
11	.0069	.0183	.0137
12	.0069	.0183	.0137
13	.0069	.0122	.0137
14	.0069	.0183	.0137
15	.0069	.0183	.0137
16	.0069	.0183	.0206
17	.0069	.0183	.0206
18	.0069	.0183	.0206
19	.0069	.0183	.0206
20	.0069	.0183	.0206
21	.0069	.0061	.0069
22	.0069	.0061	.0069
23	.0069	.0061	.0069
24	.0069	.0061	.0069
Max	.0069	.0183	.0206
Min	.0069	.0061	.0017
Avg	.0069	.0114	.0121

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274130 / 33/11 KV DHARMPURI

Feeder No / Name : 204 / 11KV DHARMPURI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.583	.4725	.463
2	.6173	.4877	.463
3	.583	.5335	.5144
4	.5487	.5335	.6001
5	.5316	.5639	.6687
6	.5316	.5792	.823
7	.5316	.442	.6344
8	.5144	.4268	.4973
9	.5144	.3353	.4115
10	.5144	.3048	.3258
11	.5144	.2896	.2915
12	.4287	.2743	.2572
13	.2572	.2591	.2572
14	.2743	.3048	.2743
15	.2915	.2915	.2915
16	.2915	.2591	.2915
17	.2915	.2439	.3086
18	.3429	.3658	.3601
19	.4458	.5182	.4115
20	.4801	.6554	.4287
21	.5144	.6097	.4287
22	.5487	.5182	.4458
23	.5316	.4725	.463
24	.7716	.4572	.4458
Max	.7716	.6554	.823
Min	.2572	.2439	.2572
Avg	.4773	.4249	.4315

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274130 / 33/11 KV DHARMPURI

Feeder No / Name : 205 / 11 KV MASUGADE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.823	.6859	.2229
2	1.0288	.7316	.2229
3	1.3717	.7621	.2229
4	1.4403	.7926	.2572
5	1.5089	.8383	.2915
6	1.5432	.9145	.3734
7	1.4403	1.1126	.3601
8	1.2689	1.2498	.3086
9	.1372	.1829	1.1831
10	.1715	.1524	1.2689
11	.1543	.1372	1.406
12	.1372		1.286
13	.1372	.1219	1.2689
14	.1372	.1067	1.2174
15	.1543	.1524	1.1831
16	.1715	.1829	1.046
17	.1886	.1677	.12
18	.1886	.2134	.1715
19	.1886	.1981	.2401
20	.1886	.2743	.2401
21	.2058	.2743	.2401
22	.2058	.2286	.2401
23	.703	.2134	.2401
24	.8745	.6249	.2401
Max	1.5432	1.2498	1.406
Min	.1372	.1067	.12
Avg	.5987	.4486	.5771

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274130 / 33/11 KV DHARMPURI

Feeder No / Name : 206 / 11 KV KARUNDE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.2003	1.0974	.3258
2	1.2689	1.1279	.3258
3	1.3032	1.1888	.3258
4	1.3717	1.2193	.3429
5	1.3717	1.2498	.3601
6	1.3889	1.2803	.463
7	1.3717	1.3717	.3944
8	1.3717	1.1279	.3086
9	.3086	.1677	1.2174
10	.2058	.1829	1.5432
11	.1715	.1524	1.4746
12	.1372	.1372	1.6289
13	.1372	.1524	1.5432
14	.1543	.1372	1.3717
15	.1715	.1372	1.3717
16	.1715	.1372	1.166
17	.1543	.1524	.1543
18	.1715	.2134	.2058
19	.2058	.2439	.2572
20	.2401	.3353	.2743
21	.3086	.3048	.2743
22	.3429	.2896	.2915
23	1.1317	.2743	.3086
24	1.0288	1.0669	.3086
Max	1.3889	1.3717	1.6289
Min	.1372	.1372	.1543
Avg	.6537	.5728	.6766



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274130 / 33/11 KV DHARMPURI

Feeder No / Name : 207 / 11 KV MOROCHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.1981	.6859
2		.2134	.6859
3		.2134	.6859
4		.2134	.7373
5		.2286	.7888
6		.2572	.9774
7		.1981	1.1831
8		.1829	1.1317
9		1.0517	.1372
10		1.0669	.1372
11		.945	.1372
12		.884	.12
13		.9755	.12
14		.945	.12
15		.884	.12
16		.7926	.12
17		.1067	.1372
18		.12	.1543
19		.1677	.1715
20		.1981	.1886
21		.1981	.1886
22		.1981	.2058
23		.5792	
24	.4287	.1981	.6859
Max	.4287	1.0669	1.1831
Min	.4287	.1067	.12
Avg	.4287	.4590	.4182

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274001 / 33/11 KV BORGAON S/STN.

Feeder No / Name : 201 / 11 KV Barshi feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8							1.4251
16	1.9784	2.0454	1.0227	1.0227	1.4083		
24	.1006	.1006	.0838	.0838	.1006	.5365	1.0059
Max	1.9784	2.0454	1.0227	1.0227	1.4083	.5365	1.4251
Min	.1006	.1006	.0838	.0838	.1006	.5365	1.0059
Avg	1.0395	1.073	.5533	.5533	.7545	.5365	1.2155

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274001 / 33/11 KV BORGAON S/STN.

Feeder No / Name : 202 / 11 KV Kategoan feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.5424	1.643	.8718	.7209	.9389		
16						1.8778	1.7101
24	.9724	.7545	.57	.3185	.3688	.0671	.0671
Max	1.5424	1.643	.8718	.7209	.9389	1.8778	1.7101
Min	.9724	.7545	.57	.3185	.3688	.0671	.0671
Avg	1.2574	1.1988	.7209	.5197	.6539	.9725	.8886

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274001 / 33/11 KV BORGAON S/STN.

Feeder No / Name : 204 / 11KV BORGAON AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8							.4024
16	.5868	.4694	.3856	.3521	.4694		
24	.0335	.0335	.0335	.0335	.0335	.218	.3688
Max	.5868	.4694	.3856	.3521	.4694	.218	.4024
Min	.0335	.0335	.0335	.0335	.0335	.218	.3688
Avg	.3102	.2515	.2096	.1928	.2515	.218	.3856

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274001 / 33/11 KV BORGAON S/STN.

Feeder No / Name : 205 / BABHULGAON Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8							1.3245
16	1.9784	2.1125	1.4754	1.2239	1.5257		
24						1.1736	1.2574
Max	1.9784	2.1125	1.4754	1.2239	1.5257	1.1736	1.3245
Min	1.9784	2.1125	1.4754	1.2239	1.5257	1.1736	1.2574
Avg	1.9784	2.1125	1.4754	1.2239	1.5257	1.1736	1.2910

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274002 / 33/11 KV CHIKHARDE S/S

Feeder No / Name : 203 / YELAMB FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
23	.4858
Max	.4858
Min	.4858
Avg	.4858

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274002 / 33/11 KV CHIKHARDE S/S

Feeder No / Name : 204 / forest Feeder

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)
13		.2343
24	1.4575	
Max	1.4575	.2343
Min	1.4575	.2343
Avg	1.4575	.2343

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274002 / 33/11 KV CHIKHARDE S/S

Feeder No / Name : 207 / MAHAGAON AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)
13		2.372
24	1.3765	
<b>Max</b>	<b>1.3765</b>	<b>2.372</b>
<b>Min</b>	<b>1.3765</b>	<b>2.372</b>
<b>Avg</b>	<b>1.3765</b>	<b>2.372</b>



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274004 / 33/11 KV PANGAON S/S

Feeder No / Name : 201 / 11 KV PANGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0857	.1509	.0476	.0943	.0943	.0943
2	.0762	.0943	.1509	.0476	.0943	.0914	.0943
3		.0943	.1509	.0476	.0943	.0914	.0943
4		.0943	.1509	.0476	.0943	.0943	.0914
5		.0857	.1509	.0476	.0943	.0943	.0943
6		.0943	.1509	.0476	.0943	.0914	.0943
7		.0943	.0943	.0476	.0943	.0943	.0943
8		.0943	.0943	.0476	.0943	.0943	.0943
9	1.9052	.0943	.0943	.0476	.0943	.0943	.0943
10	2.1338	.0943		.0476	.0943	.0914	.0943
11	2.0576						
12	2.2862						
13	2.21						
14	1.1431			.0476			
15	1.829			.0476			
16	1.829			.0476			
17	.0762	2.7435	2.2634	.503	1.5089	2.21	2.2634
18	.0762	2.431		.503	1.5927	2.21	2.0576
19	.0762	2.1795	.8573	1.5927	1.4251	1.6766	1.829
20	.0762	1.9448	.7545	1.5089	1.3413	1.5242	1.5242
21	.0762	1.9281	.6706	1.3413	1.2574	1.2193	1.448
22	.0762	1.5089	.6706	1.2574	1.1736	1.2498	1.2955
23	.0762	1.4251	.5868	1.1736	1.1736	1.2651	1.2955
24	.0762	.0943	1.4251	.503	1.2003	1.1736	1.4083
Max	2.2862	2.7435	2.2634	1.5927	1.5927	2.21	2.2634
Min	.0762	.0857	.0943	.0476	.0943	.0914	.0914
Avg	.8976	.8434	.5260	.4287	.6453	.7478	.7812

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274004 / 33/11 KV PANGAON S/S

Feeder No / Name : 202 / 11 KV SAKAT AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.3353	.1677	.2515	.1715	.2572	.1677
2	.0762	.3353	.2347	.2515	.1677	.3353	.2012
3	.0762	.3353	.3018	.2515	.1677	.3772	.218
4	.0762	.3353	.3688	.2515	.1677	.3429	.2401
5	.0762	.3353	.503	.2012	.2515	.3353	.2286
6	.0762	.3353	.5868	.2515	.4191	.6706	.2683
7	.0762	.6706	.6706	.2515	.4191	1.0059	.2515
8	.0762	.8383	.7042	.2515	.503	.8383	.2515
9	.0762						.0943
10	.0762						
15		.0943	.0943	.0476	.0943	.0943	
16		.0943	.0943	.0476	.0943	.0943	.0762
17	.7621	.0943	.0943	.0476	.0857	.0762	.0762
18	.7621	.0943	.0943	.0476	.0943	.0762	.0762
19	.7621	.0943	.0943	.0476	.0762	.0762	.0762
20	.7621	.0943	.0943	.0476	.0762	.0762	.0762
21	.7621	.0943	.0943		.0762	.0762	.0762
22	.6097		.0943		.0762	.0762	.0762
23	.4572	.6706	.0943	.0476	.0943	.0762	.0762
24	.5335	.4191	.0943	.0476	.0943	.0943	.0914
Max	.7621	.8383	.7042	.2515	.503	1.0059	.2683
Min	.0762	.0943	.0943	.0476	.0762	.0762	.0762
Avg	.3429	.3100	.2489	.1464	.1739	.2766	.1457

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274004 / 33/11 KV PANGAON S/S

Feeder No / Name : 203 / 11 KV KALEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669	.0943	.0943	.0476	.0943	.0943	.0943
2	1.3717	.0943	.0943	.0476	.0943	.0914	.0943
3	1.3717						
4	1.3717						
5	1.5242						
6	2.21						
7	2.4387						
8	2.0576						
9		2.1795	2.0119		2.0957	2.0119	2.0119
10		2.3472	2.0119		2.1795	2.1795	2.0119
11		2.6825	2.3472		2.1795	2.3472	2.0957
12		2.5987	2.5149		2.431	2.3807	2.1795
13		2.6825	2.3472	1.3413	2.5149	2.3472	2.3472
14		2.1795	2.5149	2.0957	2.431	2.3807	2.3472
15	.0762	2.431	2.2634	2.2634	2.5149	2.431	2.2634
16	.0762	2.1795	2.0119	2.1795	2.431	2.2634	2.0119
17	.0762	.0943	.0943	.0476	.0943	.0762	.0943
18	.0762	.0943	.0943	.0476	.0914	.0762	.0762
19	.0762	.0943	.0943	.0476	.0914	.0762	.0762
20	.0762	.0943	.0943	.0476	.0914	.0762	.0762
21	.0762	.0943	.0943	.0476	.0943	.0762	.0762
22	.0762	.0943	.0943	.0476	.0943	.0762	.0762
23	.0762	.0943	.0943	.0476	.0377	.0762	.0762
24	.0762	.0943	.0943	.0838	.0943	.0943	.0943
Max	2.4387	2.6825	2.5149	2.2634	2.5149	2.431	2.3472
Min	.0762	.0943	.0943	.0476	.0377	.0762	.0762
Avg	.7875	1.1235	1.0537	.5994	1.0920	1.0642	1.0057

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274004 / 33/11 KV PANGAON S/S

Feeder No / Name : 204 / 11 KV OLD GAONTHAN FEEDER GAONTHAN FEEDER  
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.1886	.3395	.2743	.1886	.2829	.7922
2	.3429	.1886	.3772	.2829	.1886	.2829	.6219
3	.3429	.2829	.4715	.3772	.2743	.3772	.5658
4	.4287	.4715	.6413	.4715	.4715	.4715	.3772
5	.5144	.6602	.7922	.6602	.5658	.5658	.6036
9	.5144	.6602	.5658	.5658	.6602	.5658	.4715
10	.3429	.7545	.4715	.3772	.4715	.4715	.3772
11	.2572	.5658	.3772	.2829	.2829	.3772	.2829
12					.2829		
13					.2829		
15	.1715	.2572	.1715	.1886		.3018	.1886
16	.1715	.2829	.2829	.1886		.3395	.2572
17	.1715	.3206	.2829				
19				.5658	.5487	.6859	.5144
20	.6001	.6602	.6602	.6602	.6401	.7716	.5144
21	.5144	.7167	.4715	.5658	.4715	.5144	.4287
22	.4287	.5658	.3772	.4715	.4572	.6001	.4287
23	.3429	.3772	.2829	.2829	.3772	.5487	.2829
24	.3429	.2829	.3395	.2829	.1829	.3772	.3772
Max	.6001	.7545	.7922	.6602	.6602	.7716	.7922
Min	.1715	.1886	.1715	.1886	.1829	.2829	.1886
Avg	.3644	.4522	.4316	.4061	.3967	.4709	.4428

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274004 / 33/11 KV PANGAON S/S

Feeder No / Name : 205 / 11 KV NEW PANGAON GAOTHAN SEPARATED GAOTHAN FEEDERS  
FEED Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1886	.2561	.1886	.1886	.1886	.3961
2	.1715	.1886	.2829	.1886	.1829	.1886	.3584
3	.2572	.2452	.3018	.2263	.2452	.2829	.3772
4	.3429	.3395	.3206	.2829	.2829	.3772	.3772
5	.4115	.4338	.3658	.3772	.3772	.415	.415
10	.3429	.3658	.3772	.3772	.3772	.3772	.3772
11	.3944	.3395	.2829	.4338	.3395	.3018	.3395
12	.3429	.415	.2263	.3395	.2743	.3772	.1886
13	.2229	.2829	.2263	.2012	.3395	.3395	.1886
18	.3429	.3658	.415	.3772	.3772	.3086	.3429
19	.3944	.4715	.4527	.3772	.4527	.3429	.3944
20	.3429	.4904	.5281	.4715	.4715	.3601	.4287
21	.3086	.4715	.3772	.3772	.3395	.3429	.3086
22	.2572	.3772	.2829	.2829	.2829	.2572	.2229
23	.2229	.4904	.2263	.2452	.2263	.2058	.1886
24	.1886	.1886	.3772	.2263	.1886	.2263	.415
Max	.4115	.4904	.5281	.4715	.4715	.415	.4287
Min	.1715	.1886	.2263	.1886	.1829	.1886	.1886
Avg	.2947	.3534	.3312	.3108	.3091	.3057	.3324

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274005 / 33/11 KV PANGARI S/S

Feeder No / Name : 203 / UKKADGAON FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.829			.6706		
2		1.7528			.6859		
3		1.829			.6859		
4					.7926		
5		1.9052			.9907		
6		1.9814			1.2193		
7					1.2955		
8				.7487	1.4232		1.0849
10							2.0933
11							2.292
12							2.3072
13							2.2965
15							2.2308
17			.8404				
18			.8709				
19	1.0955						
20		.1073	.0153				.0153
21	1.9052		.0611				.0153
22	1.9052						
23	1.829		.6265	.6401	.0898	.019	.0153
24		1.8595		.7334	.6859	1.1083	
Max	1.9052	1.9814	.8709	.7487	1.4232	1.1083	2.3072
Min	1.0955	.1073	.0153	.6401	.0898	.019	.0153
Avg	1.6837	1.6092	.4828	.7074	.8539	.5637	1.3723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274005 / 33/11 KV PANGARI S/S

Feeder No / Name : 204 / UKKADGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1986	.2241	.0764		.1677		.2052
2	.1681	.2054	.0764		.1524		.1867
3	.1834	.2241	.0917		.1677		.1865
4	.2139	.3174	.1222		.1829		.2614
5	.275	.3734	.1834		.2591		.3734
6	.489	.5596	.2598		.442		.5223
7	.4584		.2445		.4268		.5036
8		.5223	.2139	.3514	.381	.5596	.5228
9	.3362	.4476		.2903	.3353	.4663	.3362
10		.3171	.2445	.1829		.3171	.2445
11		.2425		.1372		.2052	.1986
12	.1524	.2052	.1528			.2052	.1528
13		.1865	.1222	.9145			.1528
14	.1524	.1679	.1681	.1372			
15	.1524	.1867	.1681	.1372		.1679	.1375
16	.1372		.1834	.1524	.1865	.1865	.1528
17	.1677	.2238	.1834	.1677		.2238	.1681
18	.1981	.2798	.2445	.1829		.2984	.2139
19	.181		.3056	.2134		.4103	.3362
20	.3963	.1865	.275	.442		.5596	.3056
21	.3201	.2052	.3209	.3201		.4476	.2903
22	.2896	.1679	.0306	.2743		.373	
23	.2286	.1306	.2139	.2134	.2798	.2798	.2445
24	.2292	.2238	.0917	.1681	.1143	.2238	.2425
Max	.489	.5596	.3209	.9145	.442	.5596	.5228
Min	.1372	.1306	.0306	.1372	.1143	.1679	.1375
Avg	.2464	.2665	.1806	.2678	.2580	.3283	.2699

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274005 / 33/11 KV PANGARI S/S

Feeder No / Name : 205 / BARSHI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5959	.577	.4278		.442		.6143
2	.4737	.5956	.382		.442		.5584
3	.5806	.6515	.4431		.442		.6329
4	.9626	.7446	.5653		.6859		.8376
5	1.2835	.9307	.7487		.7621		.9493
6		1.0796	1.0237		.9907		1.2285
7	1.2682	1.2471	1.0696		1.0059		1.2471
8	1.1001	1.061	.8862	1.0085	.9145	1.1168	1.1354
9	1.0237	.9307	.7793		.7773	.9307	.8098
10		.6887	.5501	.6097		.6701	.6265
11		.4653	.3973	.381		.5212	.5806
12	.503	.4095	.3209	.3048		.4467	.4278
13		.3723	.3056	.3201		.4653	.4126
14	.3353	.4095	.3056	.2896		.4467	.3667
15	.3506	.4281		.3201		.4467	.3667
16	.381	.4467	.3056	.3201	.4653	.484	.3514
17	.3963		.3667			.5398	
18	.442	.7632	.5806				
19	.7164	.9307					
20	.945	1.0982	.8709			1.1541	.8404
21	.6706	.8562	.6723			1.0424	.7334
22	.6097	.6887	.6723			.819	
23	.5639	.5956	.489	.4725	.7446	.7073	.5195
24	.6723	.6143	.4584	.4431	.4572	.5584	.6515
Max	1.2835	1.2471	1.0696	1.0085	1.0059	1.1541	1.2471
Min	.3353	.3723	.3056	.2896	.442	.4467	.3514
Avg	.6937	.7211	.5737	.4470	.6775	.6899	.6945



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274005 / 33/11 KV PANGARI S/S

Feeder No / Name : 206 / Shirale Ag Fdr

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0305	.0153		.0152		.3646
2		.0305	.0153		.0152		.3659
3		.0305			.0152		.3504
4		.0305	.0153		.0152		.3836
5		.0305	.0153		.0152		.4006
6		.0305	.0153		.0152		.4481
7		.0152	.0153		.0152		.5269
8		.0152				.4344	
9		2.0881	1.7266		2.4387	.5024	
10		2.2896	2.292	1.1736		.5038	
11		2.7834	2.8267	1.2803		.4275	
12		2.8009	2.8267	1.5851		.4406	
13		2.8384	2.7045	1.829		.5066	
14	2.1033	3.4403	2.6892	2.0271		.5679	
15	2.332	3.1227		2.0881		.5402	
16	2.3015	3.1544	2.7317	2.6825	2.862	2.9393	.0611
17	2.2253			.3658		2.9387	2.8726
18	2.2862			.4877			3.0712
19				.6249		2.9393	2.842
20		.0379	.0458	.8535		2.2579	2.3989
21	.0305	.038	.0306	.7468		2.3065	2.4142
22	.0305	.019	.0306	.5792		2.359	
23	.0305	.019	.0306	.4725	2.3748	2.2122	2.3378
24		.0305	.0153		.0152	.038	
Max	2.332	3.4403	2.8267	2.6825	2.862	2.9393	3.0712
Min	.0305	.0152	.0153	.3658	.0152	.038	.0611
Avg	1.4175	1.0893	1.0023	1.1997	.7088	1.3696	1.3456

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274005 / 33/11 KV PANGARI S/S

Feeder No / Name : 207 / Pangri Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1867	.1375		.1524		.1867
2		.1867	.1375		.1524		.168
3		.2241	.1528		.1524		.1867
4			.1834		.1677		.2241
5		.3357	.2445		.1677		.3357
6		.373	.2903		.2286		.3917
7		.2798	.3209		.2286		.4103
8		.2425	.2598	.1834	.2286	.4103	.373
9		.2238	.2292	.2292	.1829	.2984	.2598
10		.2611	.1528	.1829		.2425	.1986
11		.2052	.1986	.1524		.1865	.1986
12		.1865	.1834	.1524		.1865	.1681
13		.1494	.1986	.1524		.1492	.1528
14	.1372	.1679	.1528	.1524		.1492	.1831
15	.1524	.1865		.1524		.1865	.1528
16	.1372	.1865	.1986	.1524	.1865	.2052	.1528
17	.1524	.2052	.1986	.1677		.2425	.1986
18	.1829	.2425	.1986	.1829		.2798	.1834
19	.1829	.2425		.1829		.373	.2445
20	.2286	.3357	.3056	.2743		.4476	.1528
21	.2743	.2798	.3362	.2591		.373	.2292
22	.2286	.2425	.3362	.2286		.3171	
23	.1981	.2052	.1528	.1829	.2798	.2425	.2139
24		.2052	.1528	.1375	.1677	.1865	.2052
Max	.2743	.373	.3362	.2743	.2798	.4476	.4103
Min	.1372	.1494	.1375	.1375	.1524	.1492	.1528
Avg	.1875	.2328	.2146	.1839	.1913	.2633	.2248

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274006 / 33/11 KV UPALE (D)

Feeder No / Name : 201 / JAMGAON FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	04-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)
1	.0514	.0514
2	.0514	.0514
3	.0514	.0514
4	.0514	.0514
5	.0514	.0514
9	1.2003	1.4403
10	1.166	1.7147
11	1.2346	
12	1.406	1.7833
13	1.4746	1.6804
14		2.572
15	1.9204	3.0521
16	2.4006	2.6063
17	2.572	2.4691
18	2.4691	2.4348
19	2.332	2.332
20	2.2977	2.332
21	2.3663	2.4006
22	.0514	.0514
23	.0514	.0514
24	.0514	.0514
Max	2.572	3.0521
Min	.0514	.0514
Avg	1.1625	1.3614

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274006 / 33/11 KV UPALE (D)

Feeder No / Name : 203 / HALDUGE FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	02-AUG-17	04-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
1	2.0119		
2	1.9814		
3	1.89		
4	1.7223		
6	2.0119	1.989	2.4691
7		2.2291	
9			2.915
10		1.989	2.9835
12		2.2119	
13	2.2862	2.1948	2.4863
24	2.0271		
Max	2.2862	2.2291	2.9835
Min	1.7223	1.989	2.4691
Avg	1.9901	2.1228	2.7135

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274006 / 33/11 KV UPALE (D)

Feeder No / Name : 204 / Jamgaon GAONTHAN FEEDER  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	02-AUG-17	04-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2058	.2058
2	.2229	.2058	.2058
3	.2229	.2058	.2058
4	.2572	.2401	.2743
5	.3086	.3086	
6		.4801	
7		.4801	
8		.4115	
9		.3086	.3258
10		.2058	.2572
11		.1543	
12		.12	.1715
13	.2229	.1372	.1543
14			.1372
15	.2058	.2058	.1543
16	.2401	.1715	.1372
17	.2572	.12	
18		.2058	.2743
19		.2743	.3258
20		.4115	.3772
21		.3258	.2915
22		.2572	.2743
23		.2401	.2401
24	.2229	.2058	.2058
Max	.3086	.4801	.3772
Min	.2058	.12	.1372
Avg	.2383	.2557	.2343

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274006 / 33/11 KV UPALE (D)

Feeder No / Name : 205 / Bhatambre Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	02-AUG-17	04-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2915	.2401	.3086
2	.2915	.2401	.3086
3	.2915	.2401	.3086
4	.3429	.3086	.3601
5	.4458	.4801	.463
6	.6344	.6859	.6859
7		.6859	
8		.6001	
9		.4115	.5316
10		.2915	.3772
12		.2229	
13	.2915	.2058	.2743
14	.3258	.2058	.2915
15	.3429	.2401	.3086
16	.3429	.2401	.2743
17	.2915	.2915	.2915
18		.3944	.3258
19		.5487	.4458
20		.5658	.4458
21		.4115	.4115
22		.3086	.3772
23		.2915	.3429
24	.2915	.2401	.3086
Max	.6344	.6859	.6859
Min	.2915	.2058	.2743
Avg	.3486	.3631	.3721

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274006 / 33/11 KV UPALE (D)

Feeder No / Name : 206 / Malegaon AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	02-AUG-17	04-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
1	2.6673	.0514	1.5775
2	2.6216	.0514	1.5432
3	2.915	.0514	1.4575
4	2.5301	.0514	1.406
5	2.4691	.0514	.9945
6	2.3663	2.8121	
7		2.2977	
8		1.7147	
9		1.9204	3.3608
10		1.8347	3.0864
11		2.0748	
12		2.452	3.155
13	2.6673	2.5549	
14	1.1317		1.5089
15	1.8176	1.5775	1.6461
16	1.6309	1.869	1.5775
17	1.5242	1.4575	1.5089
18		1.4746	1.3375
19		1.3889	1.2346
20		1.0974	1.0631
21		1.0288	.9602
22		1.406	1.5775
23		1.3889	1.5432
24	3.0521	.0514	1.6118
Max	3.0521	2.8121	3.3608
Min	1.1317	.0514	.9602
Avg	2.2828	1.3330	1.6921

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274006 / 33/11 KV UPALE (D)

Feeder No / Name : 207 / Upale(D) Gaothan feeder  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	02-AUG-17	04-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715
2	.1715	.1715	.1715
3	.1715	.1715	.1715
4	.1715	.1715	.1886
5	.1886	.1715	.2058
6	.2058	.2401	.2401
8		.2058	
9		.1715	.1715
10		.12	.1029
12		.12	.12
13	.1543		.12
14	.1372	.12	.1029
15		.1029	.1029
16	.1029	.12	.12
17		.1372	.1372
18		.1886	.2058
19		.1886	.2401
20		.2572	.2743
21		.2743	.1715
22		.1886	.1715
23		.1715	.1715
24	.1715	.1715	.1715
Max	.2058	.2743	.2743
Min	.1029	.1029	.1029
Avg	.1646	.1731	.1682



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274006 / 33/11 KV UPALE (D)

Feeder No / Name : 208 / 11 kv Zaregaon Ag Feeder  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	04-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)
1	1.0974	.0514
2	1.0631	1.8861
3	1.0631	1.8519
4	1.0631	1.7833
5	1.0631	1.7147
20	.0514	.0514
21	.0514	.0514
22	1.5775	1.5432
23	1.5775	1.5432
24	1.0974	1.989
<b>Max</b>	<b>1.5775</b>	<b>1.989</b>
<b>Min</b>	<b>.0514</b>	<b>.0514</b>
<b>Avg</b>	<b>.9705</b>	<b>1.2466</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274007 / 33/11 KV VAIRAG SUB STATION

Feeder No / Name : 202 / 11 KV PANGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)
11		.0152
23	.0171	
24	.0152	
Max	.0171	.0152
Min	.0152	.0152
Avg	.0162	.0152

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274007 / 33/11 KV VAIRAG SUB STATION

Feeder No / Name : 205 / 11 KV IRLE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
23	.9431
Max	.9431
Min	.9431
Avg	.9431

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274085 / 33/11 KV JAVALGAON S/STN

Feeder No / Name : 201 / 11 KV JAVALGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	2.2862
Max	2.2862
Min	2.2862
Avg	2.2862

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274085 / 33/11 KV JAVALGAON S/STN

Feeder No / Name : 202 / 11 KV SAROLE SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)
11		1.3717
23	1.3717	
24	1.4575	
Max	1.4575	1.3717
Min	1.3717	1.3717
Avg	1.4146	1.3717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274085 / 33/11 KV JAVALGAON S/STN

Feeder No / Name : 204 / Rui SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	2.1338
Max	2.1338
Min	2.1338
Avg	2.1338

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274085 / 33/11 KV JAVALGAON S/STN

Feeder No / Name : 205 / Kasari SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.583	2.4006	2.4006	2.1434			
9	.4458	2.4863	2.572	2.0919			
10	.1543	2.4348	2.572				
11	.1372	2.4006	2.6578	1.5089			
12	.1372	2.5377	2.5206	1.6289			
13	.1372	2.5377	2.5892	1.6289			
14	.12	.1372	.1715	.12			
15	.12	.1372	.1372	.12			
16	.1372	.1372	.1715	.1543		.1543	.1886
17						.1543	.2229
18					.3429	.2229	.2743
19					.4458	.3601	.3601
20					.5487	.5316	.4115
21					.3944	.3772	.3429
22					.3258	.3429	.3086
23					.3086	.3086	.2572
24	1.5432						
Max	1.5432	2.5377	2.6578	2.1434	.5487	.5316	.4115
Min	.12	.1372	.1372	.12	.3086	.1543	.1886
Avg	.3515	1.6899	1.7547	1.1745	.3944	.3065	.2958

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274123 / 33/11 KV SURDI S/S

Feeder No / Name : 201 / 11 KV MALWANDI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.1219	.1372	.1067	.1372	.1067	.1219
2	.7926	.1219	.1372	.1067	.0137	.0914	.1219
3	.823						
4	.9145						
5	1.1279						
6	1.2193						
7	1.4327						
8	1.448						
9		1.1888	1.2193	.8383	.1334	1.2193	1.0669
10		1.1431	1.2955	.9907	1.2651	1.1888	1.4022
11		1.6766	1.448	.945	1.0364	1.326	1.5242
12		1.829	1.448	.9145	1.5242	1.448	1.5851
13		1.6004	1.3717	.9145	1.6766	1.448	1.5242
14		1.9052	1.6766	.9907	1.3413	1.6004	1.3108
15		1.8595	1.2193	1.3413	1.4937	1.6766	1.3717
16	.0572	1.9814	1.0669	1.2955	1.3108	1.2346	1.3717
17	.0914	.1219	.0762	.0572		.1143	.0914
18	.0914	.1219	.0914	.0686		.1143	.1219
19	.0914	.1219	.1219	.1143	.1524	.1143	.1524
20	.1143	.1829	.1524	.1257	.1524	.1143	.1524
21	.1257	.1524	.1372	.1143	.1524	.1143	.1029
22	.1257	.1372	.1219	.0914	.1219	.1143	.1029
23	.1029		.1067	.0914	.1219	.1029	.1029
24	.7621	.1372		.1067	.1219	.1219	.1219
Max	1.448	1.9814	1.6766	1.3413	1.6766	1.6766	1.5851
Min	.0572	.1219	.0762	.0572	.0137	.0914	.0914
Avg	.5931	.8472	.6957	.5119	.6722	.6806	.6861



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274123 / 33/11 KV SURDI S/S

Feeder No / Name : 202 / 11 KV GULPOLI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.08	.3048	.381	.3048	.3048	.381	.381
2	.08	.3048	.381	.3048	.3048	.381	.381
3		.3048	.381	.3048	.3048	.4572	.4572
4		.3048	.4877	.3048	.3048	.6097	.4572
5		.3048	.6401	.3048	.4268	.7621	.6097
6		.381	.8383	.3048	.823	.9145	.9145
7		.7011	1.1431	.3048	1.0669	1.2003	1.2193
8		.9907	1.1888	.7926	1.2955	1.2955	.9145
9	.8383						
10	.9145						
11	1.0669						
12	1.2193						
13	1.2803						
14	.9145						
15	.9145	.0914	.0762	.0095		.0572	.0762
16	.9907	.0914	.0762	.0572	.0762	.0572	.0762
17	.0572	.0914	.0762	.0457	.0762	.0572	.0914
18	.0572	.0914	.0762	.0686	.1067	.0686	.0914
19	.0572	.1219	.1067	.1143	.1067	.08	.1372
20	.0914	.1219	.1067	.1143	.1067	.0914	.1372
21	.0914	.1219	.1372	.1143	.0914	.0914	.0914
22	.0914	.1067	.1372	.1029		.0914	.0914
23	.2286		.3048	.2286	.3048	.3048	.5335
24	.1867	.2286	.381	.3048	.3048	.381	.381
Max	1.2803	.9907	1.1888	.7926	1.2955	1.2955	1.2193
Min	.0572	.0914	.0762	.0095	.0762	.0572	.0762
Avg	.5089	.2743	.3844	.2270	.3753	.4045	.3912

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274123 / 33/11 KV SURDI S/S

Feeder No / Name : 203 / 11 KV SURDI FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	1.0669	.7621	.6097		.6097
2	.1143	1.0364	.7773	.6249		.6097
3	.1143	.9145	.7926	.6401		.7621
4	.1143	.9145	.8383	.7011		1.0669
5	.1372	1.2193	.9145	.7468		1.2193
6	.1715	1.2803	1.5242	1.0974		1.6766
7	.1943	2.0729	2.0576			2.1338
8	.1715	1.8747	1.89	1.2803		2.1338
9	.1143					
10	.08					
15		.0914	.0914	.0762	.0686	.0914
16		.1067	.0914	.08	.0914	.0914
17	2.1338	.0914	.1067	.08	.1143	.1067
18	2.3624	.1219	.1372	.1143	.1143	.1372
19	2.2253	.1677	.1829	.1829	.1372	.1829
20	1.7375	.1829	.2134	.1715	.1715	.1829
21	1.5242	.1829	.1677	.1372	.1715	.1257
22	1.2955	.1524	.1372	.1143	.1486	.1143
23	1.2193		.1219	.08	.1372	.0914
24	1.0822	1.1584	.1372	.1219		.1524
Max	2.3624	2.0729	2.0576	1.2803	.1715	2.1338
Min	.08	.0914	.0914	.0762	.0686	.0914
Avg	.8269	.7432	.6080	.4034	.1283	.6382

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274123 / 33/11 KV SURDI S/S

Feeder No / Name : 204 / 11 kV Surdi Gaonthan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.3086	.2915	.2915	.2915	.2743	.2572
2	.2915	.3086	.2915	.2915	.2915	.2572	.2572
3	.3086	.3429	.2915	.2915	.2915	.2572	.2572
4	.3429	.3601	.3086	.4344	.3258	.3429	.2572
5	.4115	.4115	.3772		.3429	.4287	.4287
6	.5249	.5068	.4287		.5249	.5068	.4801
7	.4344	.4344	.4287		.4525	.4525	.4287
8	.3801	.3506	.3601		.3772	.3772	.3772
9	.3429	.3429	.3772	.3429	.3429	.3429	.2743
10	.3429	.2572	.2229	.2572	.3086	.2743	.2915
11	.2743	.2743	.1715	.2572	.2743	.2572	.2401
12	.2058	.2058	.1715	.2572	.1715	.2572	.2058
13	.1715	.1715	.1715	.2572	.1372	.2058	.2743
14	.1715	.1715	.1715	.2572	.1372	.1372	.2743
15	.1715	.1372	.1715	.2572	.1715	.1715	.2401
16	.2058	.1372	.2058	.2058	.2058	.2058	.2058
17	.2401	.2401	.2058	.2058	.2743	.2572	.2915
18	.3429	.3086	.2915	.3429	.3429	.3086	.2915
19	.3772	.4163	.3601	.4115	.4525	.3772	.3772
20	.4973	.5249	.4287	.543	.4525	.4287	.4525
21	.4458	.4706	.4887	.4287	.4525	.4287	.3601
22	.4115	.3772	.3801	.3429	.3772	.3772	.2915
23	.3429	.3086	.2743	.2915	.3429	.3429	.2915
24	.2915	.3086	.2915	.2915	.2915	.3086	.3086
Max	.5249	.5249	.4887	.543	.5249	.5068	.4801
Min	.1715	.1372	.1715	.2058	.1372	.1372	.2058
Avg	.3259	.3198	.2984	.3129	.3180	.3157	.3089

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274123 / 33/11 KV SURDI S/S

Feeder No / Name : 205 / 11 kV Yawali Ag feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3413	.1219	.1219	.1524	.0914		.1524
2	1.3717	.0914	.1219	.1524	.0914		.1524
3	1.387						
4	1.5851						
5	1.9204						
6	2.1338						
7	2.4539						
8	2.2558						
9		2.1338	2.0729	1.6156	2.2862		2.3624
10		1.9052	2.3015	1.9376	2.2253		2.4539
11		2.3624	2.5149	2.0119	2.5911		2.4996
12		2.3624	2.5149	2.21	2.8959		2.5911
13		2.4082		2.1338	2.9721		2.8045
14		2.3624		2.1643	2.4387	2.7435	2.8959
15	.16	2.3472	1.5242	2.1186	2.713	2.5911	2.7435
16	.1829	2.3015	2.2862	2.2862	2.4234	2.3624	2.2558
17	.1486	.1372	.1372	.0686	.1524	.1143	.1219
18	.1715	.1524	.1372	.1143	.1524	.1143	.1372
19	.1372	.1677	.1524	.1257	.1829	.1143	.1372
20	.16	.1981	.1829	.1372	.1829	.1143	.1372
21	.1829	.1677		.1143	.1829	.1143	.1143
22	.1372	.1981	.1829	.1143	.1524	.1143	.1029
23	.0914		.1677	.0914	.1524	.1143	.0914
24	.0777	.1219	.1219	.1677	.0914		.1524
Max	2.4539	2.4082	2.5149	2.2862	2.9721	2.7435	2.8959
Min	.0777	.0914	.1219	.0686	.0914	.1143	.0914
Avg	.8832	1.1494	.9694	.9842	1.2210	.8497	1.217

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274123 / 33/11 KV SURDI S/S

Feeder No / Name : 206 / 11 kV Turk-Pimpari AG

FEEDER SEPERATION/PURE AG

Feeder Feeder KV- 11 /

OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0914	.0914	.0762		.0762
2	.0686	.0914	.0914	.0762		.0762
3		.0914	.0914	.0914		.0762
4		.0914	.1067	.0914		.0762
5		.1067	.1067	.0914		.0914
6		.1219	.1219	.0914		.1067
7		.1219	.1372	.0914		.1219
8		.1219		.1219		.1219
9	.6859	.0914		.0762		.0914
10	.8383	.0914				.0914
11	.8383					
12	.7621					
13	.7621					
14	.6859					
15	.9145		.6097			
16	.9907					
17	.0686	1.1888	1.1431	.9145	.9145	1.1584
18	.08	1.2193	1.0669	1.0364	.9145	1.0059
19	.0914	1.0212	.7926	.9145	.9145	.9602
20	.0914	.9145	.5944	.7621	.9145	.9297
21	.0914	.7621	.503	.5487	.7621	.823
22	.0686	.7316	.5335	.4572	.7621	.7621
23	.0686		.4877	.4572	.6097	.7621
24	.0686	.0914	.6097	.442		.6097
Max	.9907	1.2193	1.1431	1.0364	.9145	1.1584
Min	.0686	.0914	.0914	.0762	.6097	.0762
Avg	.4024	.4088	.4430	.3729	.8274	.4411

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274125 / 33/11 KV KASARWADI S/S

Feeder No / Name : 201 / 11 KV SOUNDARE FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0305	.0514		.0305	.0514	.0343
2	.0343	.0305	.0514		.0305	.0514	.0343
3	.0343	.0305	.0343		.0305	.0514	.0343
4	.0343	.0305	.0343		.0305	.0343	.0343
9	1.5432						
10	1.4327						
11	1.4175						
12	1.5242						
13	1.6004						
14	1.1584						
15	1.5242						
16	1.5394						
17		1.7318		1.3717	1.6804	1.8861	1.5242
18		1.5947		1.4022	1.7318	1.6118	1.5851
19	.0305	1.4918		1.3717	1.406	1.3889	1.4175
20	.0305	1.3717		1.2803	1.3032	1.2174	1.0669
21	.0305	1.3375		.9602	1.3546	1.2174	1.0059
22	.0305	1.2346		.945	1.3032	1.166	.9145
23	.0305	1.2003		.9297	1.2689	1.1317	.8993
24	.0343	.0305	1.1145		.9145	1.2003	1.1317
Max	1.6004	1.7318	1.1145	1.4022	1.7318	1.8861	1.5851
Min	.0305	.0305	.0343	.9297	.0305	.0343	.0343
Avg	.6702	.8429	.2572	1.1801	.9237	.9173	.8069

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274125 / 33/11 KV KASARWADI S/S

Feeder No / Name : 202 / 11 KV KORFALE FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4575	.0762	.0686	.0762	.1372	.0857	.061
2	1.4575	.0762	.0686	.0762	.1372	.0857	.061
3	1.4232	.061	.0686	.0762	.1372	.0857	.0762
4	1.4232	.061	.0686	.0762	.1372	.0857	.0762
5	1.749						
6	2.0233						
7	2.2291						
8	2.1434						
9		2.0919	2.2862	.884	1.7147	2.0748	1.4937
10		2.0405	2.271	.9602	1.8347	1.9662	1.7528
11		2.8807	2.3167	.4268	1.8347	1.9357	1.8747
12			2.3777		2.1262	1.4632	1.9052
13		2.6749	2.6368	1.0059	2.2462	2.0424	2.0729
14		3.1722	2.3777	1.387	2.3148	2.0271	2.0424
15		3.0864	2.0424	1.5851	2.3148	2.1338	2.0424
16		2.7949	2.3015	1.6156	2.2977	1.6918	2.0271
19		.0857	.1067	.1372	.1029	.061	.0914
20		.0857	.1219	.1372	.12	.0762	
21		.0857	.1067	.1372	.0857	.0914	.0914
22		.0857	.1067	.1372	.0857	.0762	.0914
23		.0857	.0762	.1067	.0857	.0762	.0914
24	.0857	.0914	.0686	.0762	.1067	.0857	.061
Max	2.2291	3.1722	2.6368	1.6156	2.3148	2.1338	2.0729
Min	.0857	.061	.0686	.0762	.0857	.061	.061
Avg	1.5547	1.1492	1.0817	.5236	.9900	.8969	.9360

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274125 / 33/11 KV KASARWADI S/S

Feeder No / Name : 203 / 11 KV KASARWADI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1888	1.0288	1.1145	.884	1.1145	1.4575
2		1.1736	1.1145	1.046	.9145	1.0288	1.4232
3		1.1736	1.1145	.9774	.9602	1.0974	1.3889
4		1.1431	1.166	.9431	.9602	1.1488	1.3546
5		1.1584	1.286	.9602	.9602	1.5432	2.0233
6		1.2498	1.8861	.9259	1.1888	1.8861	2.0748
7		1.4327	2.0405	.9088	1.2803	2.0748	2.1091
8		1.4022	1.9719	1.0974	1.3108	2.0576	1.3889
17	1.9052						
18	1.8595						
19	1.7985						
20	1.5242						
21	1.3717						
22	1.2955						
23	1.2346						
24	1.3889	1.1888					
Max	1.9052	1.4327	2.0405	1.1145	1.3108	2.0748	2.1091
Min	1.2346	1.1431	1.0288	.9088	.884	1.0288	1.3546
Avg	1.5473	1.2346	1.4510	.9967	1.0574	1.4939	1.6525



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274125 / 33/11 KV KASARWADI S/S

Feeder No / Name : 204 / KASARWADI GAONTHAN FEEDER GAONTHAN FEEDER  
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.4801	.3429	.0857	.3772	.3601	.2058
2	.2915	.4287	.3429	.0857	.3772	.3601	.1372
3	.2572	.4287	.3429	.0857	.3772	.3601	.12
4	.2572	.4115	.3944	.0857	.3601	.4115	.1029
5	.4287	.4458	.4458	.1372	.463	.4801	.2743
6	.5144	.4801	.5144	.1029	.6001	.4801	.2915
7	.5144	.4801	.4801	.0171	.6173	.5144	.2915
8	.5144	.4458	.4287		.583		.2572
9	.3429	.4287	.3944	.0343	.5144	.463	.4115
10	.1715	.2229	.3429	.0343	.4801	.3772	.2915
11	.2572	.2401	.1886	.1715	.3429	.2058	.3258
12	.2401	.2058	.0343		.2743	.12	.3258
13	.2401	.1543	.1715	.1886	.2401		.2743
14	.2401	.1715	.12	.3772	.2743	.1372	.2572
15	.3772	.1715	.12	.3772	.3086	.0857	.2572
16	.4115	.2058	.2229	.3258	.3429	.2743	.2401
17	.4458	.2401	.2401	.4115	.3258	.2058	.5144
18	.4458	.3772	.2915	.5316	.463	.2743	.6001
19	.6173	.4458	.1543	.6173	.5487	.3944	.5487
20	.6173	.4801	.0343	.6001	.7202	.4287	.4287
21	.6687	.4287	.12	.583	.1715	.2401	.3772
22	.6516	.4115	.0857	.4287	.6001	.2572	.3086
23	.5144	.3772	.0686	.4801	.5144	.12	.3772
24	.4115	.4973	.3772	.0857	.3944	.3944	.1715
Max	.6687	.4973	.5144	.6173	.7202	.5144	.6001
Min	.1715	.1543	.0343	.0171	.1715	.0857	.1029
Avg	.4072	.3608	.2608	.2658	.4280	.3157	.3079

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274125 / 33/11 KV KASARWADI S/S

Feeder No / Name : 205 / 11 KV Maruti Technofab NON SHEDDABLE EXPRESS HV FEEDERS  
Express Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2401	.1029	.2572	.2743	.2401	.12
2	.2572	.2401	.1029	.2401	.2915	.2572	.1372
3	.2572	.2572	.1029	.2572	.2743	.2572	.12
4	.2572	.2572	.0857	.2572	.2743	.2572	.12
5	.2743	.2572	.0857	.2401	.2743	.2572	.1886
6	.2915	.2743	.12	.2572	.2915	.2572	.1715
7	.3086	.2572	.12	.2401	.3086	.2572	.1886
8	.2572	.1886	.12	.2401	.3429	.2401	.1543
9	.2743	.1886	.1372	.2915	.3429	.2572	.12
10	.3258	.0686	.1715	.1715	.3429	.3086	.1677
11	.2915	.0857	.1715	.0857	.3944	.3258	.1886
12	.2915	.0857	.1886	.1543	.3429	.2915	.1886
13	.2743	.0857	.1715	.2572	.3601	.3086	.1886
14	.2915	.0686	.1886	.3086	.3772	.2915	.1886
15	.2915	.0857	.2058	.3258	.3429	.3429	.1886
16	.2915	.0857	.2058	.3429	.3772	.3429	.1886
17	.2915	.1029	.2058	.3086	.3772	.3086	.1715
18	.2572	.0686	.2058	.3086	.3772	.3258	.1715
19	.2058	.0857	.1886	.2915	.2915	.2915	.1715
20	.2058	.0857	.2229	.2915	.2915	.3086	.1543
21	.2058	.0686	.2229	.2915	.2743	.2743	.1543
22	.2058	.0857	.2572	.2572	.2915	.2401	.1543
23	.2229	.1029	.2743	.2572	.2572	.2915	.1372
24	.2743	.2229	.1029	.2743	.2572	.12	.1372
Max	.3258	.2743	.2743	.3429	.3944	.3429	.1886
Min	.2058	.0686	.0857	.0857	.2572	.12	.12
Avg	.2651	.1479	.1650	.2586	.3179	.2772	.1613

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274157 / Jamgaon

Feeder No / Name : 201 / Industrial Feeder  
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9687	1.086	.5526	.9619	.679	1.086	1.0288
2	.8573	1.0288	.5382	.9619	.6224		1.0288
3	.9145	.9145	.5275	.9054	.6224	1.0288	.8573
4	.8539	.8573	.5476	.9054	.679	1.0288	.8573
5	.7914	.8573	.6049	.8488	.7356	1.1431	.9145
6	.8999	.9145	.7682	.7922	.8488	1.2003	.9717
7	1.1431	1.0288	.961	.9619	1.1763	1.2574	1.086
8	1.1248	1.1431	1.0288	.9619	1.1203	1.3146	.9717
9	1.3443	1.2003	1.0185	1.0751	1.1763	1.6975	1.1317
10	1.6409	1.1152	2.0513	1.4146	1.9404	2.037	1.3846
11	2.037	1.44	2.9321	1.6804	2.2731	2.2451	1.8364
12	2.7726	1.5792	2.8235	1.8296	2.4646	2.4897	1.5912
13	2.2068	1.6992	2.0851	1.7741	2.6057	2.037	1.6991
14	2.0936	.1617	1.6461	1.6632	1.885	1.6632	1.3895
15	2.32	1.2008	2.3285	2.0851	2.1948	2.2731	2.0664
16	2.3765	.7705	2.6886	2.4143	2.6337	2.6326	1.8284
17	2.6595	1.2739	2.5206	2.1068	2.2405	2.6886	2.009
18	1.9805		1.9805	1.6804	1.9605	2.1285	.8573
19	1.0751		1.0751	1.0082	1.5278	1.7364	.8548
20	1.2449	.7722	.9619		.9054	1.2883	1.1979
21	1.3146	.6653	.8488	.743		1.1763	1.1835
22	1.1431	.6749	.7922	1.0751	1.1317	1.2003	1.1847
23	1.4861	.62	1.0751	.7922	1.2449	1.2574	1.1294
24	1.134	1.6004	.5602	1.0185	.7356	1.1431	1.2003
Max	2.7726	1.6992	2.9321	2.4143	2.6337	2.6886	2.0664
Min	.7914	.1617	.5275	.743	.6224	1.0288	.8548
Avg	1.5160	1.0275	1.3715	1.2896	1.4523	1.6414	1.2608

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274157 / Jamgaon

Feeder No / Name : 202 / Gaothan Fdr

GAOTHAN FEEDER

Feeder KV- 33 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2386	1.3512	1.2962	1.2449	1.3014	1.2883	1.4003
2	1.1835	1.3443	1.3539	1.1883	1.2449	1.2323	1.4003
3	1.2411	1.4563	1.4118	1.2449	1.4146	1.3443	1.4563
4	1.4667	1.4563	1.5262	1.5278	1.6409	1.5684	1.6277
5	2.035	1.9044	1.9219	1.9605	2.0165	1.9605	1.9044
6	2.6595	2.3525	2.6055	2.3525	2.5206	2.2405	2.4646
7	2.5976	2.5766	2.6968	2.7446	2.6326	2.4646	2.6326
8	2.2918	2.1285	2.2428	2.3525	2.3525	2.3525	1.9605
9	1.5684	1.5524	1.5524	1.9605	1.8484	1.7924	1.6244
10	1.2323	.9928	1.0974	1.2883	1.3306	1.5524	1.3306
11	1.1203	.9046	.823	.9979	1.1088	1.3443	1.2059
12	.8402	.8871	.7682	.5544	.9979	.9979	1.0219
13	.8402	.7586		.5487	.9877	.9425	1.1235
14	.8962	.7973	.7682	.5487	.9979	.9877	1.0654
15	.8402	.7948	.9328	.6516	.9877	.9979	1.0208
16	.8402	.8578	.9979	.8145	1.0425	1.0534	1.046
17	.8402	.8959	1.1088	1.0974	1.1203	1.1763	1.1858
18	1.2323		1.4003	1.386	1.4003	1.2323	1.388
19	1.7364		1.7924	1.7924	1.9605	1.8484	1.6598
20	1.8484	2.3237	2.2405	2.0165	2.3525	2.0725	1.9918
21	1.7924	2.1511	1.9605	2.0165	2.2405	1.7924	1.7778
22	1.6376	1.6177	1.7364	1.7364	1.7924	1.6804	1.5154
23	1.4003	1.4075	1.4003	1.4563	1.5684	1.5123	1.3512
24	1.2949	1.3512	1.3525	1.358	1.4003	1.4003	1.4003
Max	2.6595	2.5766	2.6968	2.7446	2.6326	2.4646	2.6326
Min	.8402	.7586	.7682	.5487	.9877	.9425	1.0208
Avg	1.4448	1.4483	1.5212	1.4517	1.5942	1.5348	1.5231

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274157 / Jamgaon

Feeder No / Name : 203 / Ag Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 33 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							2.1296
2							2.1296
3							2.3045
4							2.4074
5							2.5926
6							3.6111
7							4.0741
8							2.963
9	2.7041	2.5412	2.5777	1.4449	2.0165	2.6092	
10	2.8938	3.618	3.6488	2.0833	3.9369	3.6054	
11	3.2259	3.912	3.9838	2.5777	4.1295	4.317	
12	3.4156	3.6914	4.1295	3.0727	3.8866	4.3644	
13	3.9375	4.2551	4.0809	3.1687	3.7449	4.4593	
14	4.317	3.3885	4.2753	3.2648	4.561	4.537	
15	5.076	4.4158	3.9849	3.1784	4.7125	3.3333	
16	5.2658	4.0761	3.9369	3.0836	4.6153	3.4259	
23						1.8982	1.8153
24							2.1296
Max	5.2658	4.4158	4.2753	3.2648	4.7125	4.537	4.0741
Min	2.7041	2.5412	2.5777	1.4449	2.0165	1.8982	1.8153
Avg	3.8545	3.7373	3.8272	2.7343	3.9504	3.6166	2.6157

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274157 / Jamgaon

Feeder No / Name : 204 / Shelgaon(m)Ag.

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0449	.0594	.0454	.0762	.061	.0463	.9414
2	.0449	.0594	.0454	.0762	.061	.0463	.9414
3	.0449	.0594	.0454	.0762	.061	.0463	.9568
4	.0449	.0594	.0454	.061	.061	.0463	1.0031
5							1.142
6							1.4815
7							1.6358
8							1.2963
9	1.0848	1.4166	1.4148	.8488	1.4998	1.5123	
10	1.2186	1.6879	1.8827	.9877	1.6091	1.6667	
11	1.5752	1.6728	1.9997	1.1574	1.9766	1.9753	
12	1.6049	1.7805	2.2184	1.2809	1.9841	2.037	
13	1.6792	1.7828		1.3889	2.0873	2.1296	
14	1.6941	1.8734	1.8903	1.4198	2.1348		
15	1.7535	1.9968	1.8747	1.3889	2.1822	1.6667	
16	1.7684	1.8176	1.9528	1.4198	2.1348	1.5895	
19	.0594		.061	.0772	.061	.0617	.0479
20	.0594	.0757	.0762	.0617	.0914	.0463	.0478
21	.0594	.0606	.0762	.0617	.0772	.0463	.0478
22	.0594	.0606	.0762	.061	.0617	.0463	.0319
23	.0594	.0454	.0762	.061	.0463	.8796	.9875
24	.0449	.0594	.0454	.0762	.061	.0463	.9259
Max	1.7684	1.9968	2.2184	1.4198	2.1822	2.1296	1.6358
Min	.0449	.0454	.0454	.061	.0463	.0463	.0319
Avg	.7167	.8569	.8133	.5878	.9029	.8170	.8205

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274157 / Jamgaon

Feeder No / Name : 205 / DEVGAON Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0467	1.0802	.4385	.8124	.8025	.8333	
2	1.0623	1.0402	.4385	.828	.8025	.8025	
3	1.078	1.0957	.4385	.8592	.8488	.8488	
4	1.1873	1.5123	.4542	.8592	.9105	.9259	
5	1.4217	2.284	.5005	1.0467	1.4529	1.4661	
6	2.1403	2.6235	.7821	1.4685	2.2965	2.284	
7		1.2346	1.1262	1.7185	2.6402	.1852	
8		1.6204	.6882	1.6716	2.4996	.1543	
9							2.7932
12							2.7497
13							3.5017
14							3.1093
15							2.0453
16							3.5753
23	1.0185	.4072	.7621	.8488	.9259		
24	1.0467	1.0802	.4542	.828	.8333	.8488	
Max	2.1403	2.6235	1.1262	1.7185	2.6402	2.284	3.5753
Min	1.0185	.4072	.4385	.8124	.8025	.1543	2.0453
Avg	1.2502	1.3978	.6083	1.0941	1.4013	.9277	2.9624

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274158 / 33/11 KV Shendri S/Stn

Feeder No / Name : 201 / Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2614	.2801	.2614	.2614	.2614	.3361
2	.2241	.2614	.2801	.2614	.2614	.2614	.3361
3	.2241	.2614	.2801	.2614	.2614	.2614	.3361
4	.2587	.2987	.3174	.2987	.2614	.2614	.3734
5	.3326	.3361	.3921	.3734	.3734	.3734	.4668
6	.4066	.5175	.5601	.5228	.5228	.4108	.6348
7	.4435	.4805	.5041	.4854	.4854	.4481	.5041
8	.3696	.4435	.3696	.3734	.2987		.4668
9	.4066	.2957	.3658	.2926	.3361	.3696	.3696
10		.2172	.2561	.2926	.2614	.3109	.3326
11	.2149	.1629	.1829	.2126	.1867	.2743	.2926
12	.1417	.1267	.1463	.1791	.1494	.1829	.2561
13	.1417	.1267	.1097	.1791	.1494	.1829	.2561
14	.128	.1267			.1494	.1829	.2195
15	.1402	.1267	.1478	.1478	.1494	.1829	.2195
16	.1402	.181	.1478	.1463	.1867	.2378	.2195
17	.2126	.181	.1478		.1867	.2195	.2149
18	.2481	.2715	.2218	.208	.2241	.2561	.2865
19	.3582	.362	.3326	.394	.3734	.4344	.3696
20	.4706	.462	.4435	.439	.4854	.4755	.4108
21	.439	.4066	.3734	.4066	.4668	.439	.3696
22	.3696	.3361	.2957	.3734	.3734	.4024	.3734
23	.2987	.2801	.2614	.2614	.2987	.3361	.2987
24	.2241	.2614	.2801	.2614	.2614	.2614	.3361
Max	.4706	.5175	.5601	.5228	.5228	.4755	.6348
Min	.128	.1267	.1097	.1463	.1494	.1829	.2149
Avg	.2790	.2827	.2911	.3014	.2902	.3055	.3450



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274158 / 33/11 KV Shendri S/Stn

Feeder No / Name : 202 / Shripat-Pimpri Feeder AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1867	.1867	.1867	.1867		1.0688
2	.1829	.1867	.1867	.1867	.1867		1.0688
3	.1829	.1867	.1494	.1867	.1867		1.0688
4							1.1012
5							1.3927
6							1.8679
7							2.6852
8							1.7166
9	1.9662	2.0885	2.0972	1.1873	1.829	2.1879	
10	2.4249		2.2939	1.2346	2.1338	2.5857	
11	2.6216	2.4863	2.13	1.6324	2.4387	2.652	
12	2.7854	2.2211	2.4577	1.9433	2.0062	2.5857	
13	2.7526	2.6189	1.4746	2.0645	2.4371		
14		2.4531		1.6248	2.3148	2.1548	
15	2.1125	2.4531	2.5911	1.9662	2.1605	2.42	
16	2.2996	2.5692	2.5911	2.1879	2.1338	2.42	
20	.2614	.2987	.2614	.2614	.2241		
21	.2218	.2614	.1867	.1867	.2218		
22	.1848	.1867	.1867	.1867	.2218		
23	.1867	.1867		.1867		1.1012	1.3916
24	.1848	.1867	.1867	.1867	.1867		1.0688
Max	2.7854	2.6189	2.5911	2.1879	2.4387	2.652	2.6852
Min	.1829	.1867	.1494	.1867	.1867	1.1012	1.0688
Avg	1.2367	1.2380	1.2129	.9631	1.2579	2.2634	1.4430

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274158 / 33/11 KV Shendri S/Stn

Feeder No / Name : 203 / Shendri Feeder AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7735	.8688	1.086	.8573	.8116	.8116	.1429
2	1.0669	.8688	1.086	.8573	.8573	.8116	.1296
3	1.2003	1.1888	1.0997	.8573	.9145	.8792	.1425
4	1.4098	1.3413	1.1561	.8459	1.2574	.9469	
5	1.4289	1.9925	1.4563	1.4098	1.656	1.3717	
6	1.7147	2.3403	1.9022	1.4098	1.9528	1.6204	
7	2.2862	2.5617	2.5934	1.5299	2.2809	2.2862	
8	2.1434	2.372	2.2558	1.5089	2.1559		
9							1.419
10							1.9444
11							2.3087
12							2.5263
13							2.372
14							2.372
15							2.3403
16							2.1994
20	.1787	.1858	.1715	.168	.144	.2027	.1829
21	.16	.1734	.1429	.1734	.1463	.2027	.1555
22	.1257	.161	.1429	.1734	.1463	.161	.12
23	.8398	1.0002	.7145	.7846	.7034	.1448	.1334
24	.8002	.8688	1.0002	.8573	.8116	.8116	.1429
Max	2.2862	2.5617	2.5934	1.5299	2.2809	2.2862	2.5263
Min	.1257	.161	.1429	.168	.144	.1448	.12
Avg	1.0868	1.2249	1.1390	.8795	1.0645	.8542	1.1645

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274158 / 33/11 KV Shendri S/Stn

Feeder No / Name : 204 / PWW Express Feeder NON SHEDDABLE WATER SUPPLY AND  
Feeder KV- 11 / OUTGOING UTILITY

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2641	.2641	.2641	.2641	.2641	.2641
2	.2641	.2641	.2641	.2641	.2641	.2641	.2641
3	.2641	.2641	.2641	.2641	.2641	.2641	.2641
4	.2641	.2641	.2641	.2641	.2641	.2641	.2641
5	.2641	.2641	.2641	.2641	.2641	.2641	.2641
6	.2641	.2641	.2641	.2641	.2641	.2641	.2641
7	.2641	.2641	.2641	.2641	.2641	.2641	.2641
8	.2641	.2641	.2641	.2641	.2641		.2641
9	.2641	.2641	.2641	.2641	.2641	.2641	.2641
10	.2641	.2641	.2641	.2641	.2641	.2641	.2641
11	.2641	.2641	.2641	.2641	.2641	.2641	.2641
12	.2641	.2641	.2641	.2641	.2641	.2641	.2641
13	.2641	.2641	.2641	.2641	.2641	.2641	.2641
14	.2641		.2561	.2641	.2641	.2641	.2641
15	.2641		.2641	.2641	.2641	.2641	.2641
16	.2641		.2641	.2641	.2641	.2641	.2641
17			.2641	.2641	.2641	.2641	.2641
19	.2641						
20	.2641	.2641	.2641	.2641		.2641	.2641
21	.2641		.2641	.2641	.2641	.2641	.2641
22	.2641		.2641	.2641	.2641	.2641	.2641
23	.2641		.2641	.2641	.2641	.2641	.2641
24	.2641	.2641	.2641	.2641	.2641	.2641	.2641
Max	.2641	.2641	.2641	.2641	.2641	.2641	.2641
Min	.2641	.2641	.2561	.2641	.2641	.2641	.2641
Avg	.2641	.2641	.2637	.2641	.2641	.2641	.2641

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274192 / Gaudgaon Sub station

Feeder No / Name : 201 / 11 KV Gaudgaon feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4575	.4115	.5144	.4115	.3963	.5144	.4801
2	1.4575	.4115	.5144	.4115	.3963	.4801	.4801
3	1.4575	.4115	.5144	.4572	.3963	.4801	.5658
4	1.5432	.4877	.6173	.4877	.5182	.5144	.6859
5	1.5432	.7316	.7202	.6859	.7164	.6859	.6859
6	1.7147	.9145	.9602	.9145	.884	.9259	1.0288
7	1.8861		.823	.9145	.7926	.8916	
8			.6859	.7926	.6859	.7202	
9	.503		1.3413	.5335	.5144		.6859
10	.3506		1.5242	.4268			.5487
11	.3048		1.7528	.381	.4115	.3772	
12	.3048		1.829	.381	.3429	.3772	.5144
13	.3048	1.6118	1.829	.381	.3429	.4287	
14		1.4746	1.829	1.2955	2.0919	1.8861	2.1262
15		1.989	1.6766	1.2193	2.1948	1.8861	
16		2.0576	1.6004	1.2193	1.8519	1.8861	2.1605
17		.4115	.381	1.2193		1.7661	2.0233
18	.5335	.583	.381	1.2498		1.8004	2.0919
19	.6859	.8573	.7316	1.2803	1.8176	1.8004	1.6804
20	.7621	.9602	.6401	1.2803	1.8861	1.8004	1.8861
21	.6554	.7888	.5639	1.2498	1.7147	1.7147	1.6804
22	.5487	.6516	.503	.5182	.6516	.6001	.6173
23	.4572	.5487	.4572	.4572	.5487	.5487	.5487
24	1.4575	.4115	.5487	.4268	.3963	.5144	.4801
Max	1.8861	2.0576	1.829	1.2955	2.1948	1.8861	2.1605
Min	.3048	.4115	.381	.381	.3429	.3772	.4801
Avg	.9436	.8730	.9558	.7748	.9310	1.0272	1.1037

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274192 / Gaudgaon Sub station

Feeder No / Name : 202 / 11 KV Raulgaon Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.2439	.3429	.5335	1.0669	1.2003	1.406
2	.6859	.2439	.3086	.5335	1.0669	1.166	1.3717
3	.6859	.2439	.3086	.5639	.9145	1.166	1.286
4	.7716	.2743	.3772	.5792	.9145	1.1317	1.2346
5	.823	.3658	.5144	.6097	.9602	1.1317	1.2003
6	.9431	.4572	.7202	.5792	.4572	.7202	.6516
7	1.0288		.6859	.5335	.5182	.5144	.5487
8			.6173	.4877	.5792	.6173	
9	.4115		.823	.3353	.5144	.4801	.4458
10	.2743		.1829	.1829	.2743	.2401	.4115
11	.1524		.1524		.1715	.1715	
12	.1524		.1524		.1715	.1715	.2743
13	.1524	.823	.1524	.1524	.1715	.1715	.2401
14		.7545	.1524	.1524	.1715	.2058	.2058
15		1.4746	.1829	.1524	.1715	.2572	.2058
16		1.406	.1829	.1524	.1715	.2572	.2058
17		.2401	.1829	.1524		.2229	.2058
18	.3048	.2743	.2591	.2286		.4287	.2743
19	.503	.4801	.4877	.3353	.5487	.5658	.4458
20	.5944	.583	.4572	.5335	.6516	.6001	.4458
21	.4877	.4458	.3658	.3963	.4458	.4287	.4115
22	.3658	.3772	.7621	1.1431	1.4746	1.5432	1.4403
23	.3048	.3429	.7621	1.1431	1.5089	1.5432	1.4403
24	.6859	.2439	.3429	.7621	1.1431	1.2003	1.5432
Max	1.0288	1.4746	.823	1.1431	1.5089	1.5432	1.5432
Min	.1524	.2401	.1524	.1524	.1715	.1715	.2058
Avg	.5270	.5152	.3948	.4656	.6395	.6723	.7225

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274192 / Gaudgaon Sub station

Feeder No / Name : 203 / 11 KV Bhalgaon Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.9907	1.2346	.3048	.2591	.2915	.2915
2	.2915	.9907	1.2003	.3048	.2591	.2915	.2915
3	.3086	.9907	1.166	.3353	.2591	.2915	.3429
4	.3429	1.0669	1.166	.3658	.3048	.3086	.3772
5	.4115	1.2193	1.166	.4115	.3658	.3772	.3944
6	.6001	1.4022	1.406	.3658	.9145	1.406	1.8861
7	.5487		1.7833	.3048	.945	1.4403	1.8861
8			1.5432	.2591	1.0364	1.9204	
9	1.4022		.2743	.4572	1.1317	1.6804	
10	1.5089		.1524	.4572	1.0288	1.8861	1.8176
11	1.5394		.1524	.7621	1.3375	1.8861	
12	1.5394		.1524	.8383	1.4746		1.6804
13	1.5394		.1524	.8383	1.4746	1.5432	1.6804
14			.1524	.1677	.1715	.2229	.2058
15			.1524	.1677	.1715	.2229	.2058
16			.1829	.1677	.1715	.2229	.2058
17		.2743		.1677	.2743	.1715	.1886
18	.2286	.3429		.2743	.3429	.4287	.2401
19	.4115	.4458		.381	.4801	.4801	.3772
20	.4572	.5487		.4572	.5144	.5487	.4458
21	.4115	.4801	.4115	.3658	.4458	.4287	.4115
22	.3353	.3772	.3353	.3048	.3429	.3772	.3772
23	.945	1.2003	.3353	.2591	.3086	.3086	.3086
24	.2915	.9907	1.2346	.3048	.2591	.3086	.2915
Max	1.5394	1.4022	1.7833	.8383	1.4746	1.9204	1.8861
Min	.2286	.2743	.1524	.1677	.1715	.1715	.1886
Avg	.7055	.8086	.7177	.3760	.5947	.7410	.6622

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274208 / 33/11 KV Pathari Sub station

Feeder No / Name : 201 / 11 Kv pathari Gaothan  
feeder Feeder KV- 11 /  
OUTGOING GAOTHAN FEEDER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1372	.1372	.1494	.1494	.1372	.1372
2	.12	.1543	.1372	.1494	.1307	.12	.1543
3	.1543	.1715	.1543	.1867	.1867	.1372	.1715
4	.1886	.2058	.3086	.2241	.2241	.2401	.1715
5	.2572	.2401	.3772	.2987	.2987	.3258	.2401
6	.4115	.3429	.4287	.4668	.3361	.3944	.2743
7	.3086	.2743	.3601	.4481	.2241	.3772	.3429
8	.2401		.2743	.3174	.1715	.3086	.2743
9	.2058	.1715		.2427	.1543	.2572	.2058
10	.1543	.1372	.1372	.1494	.1372	.1715	.1715
11	.1029	.12		.112	.0686	.1029	.12
12	.0857	.0857	.112	.0747	.0686	.1029	.1029
13	.0857	.0857	.112	.0754	.0514	.1029	.0857
14	.0857	.0857	.0934	.0747	.0514	.1029	.1029
15	.0686	.0686	.0934	.0747	.0857	.1029	.0857
16	.0857	.0857	.0934	.112	.0857	.1029	.12
17	.0857	.1029	.112	.1867	.1029	.1029	.12
18	.12	.1029	.168	.2614	.1372	.1372	.12
19	.2401	.2401	.2427	.2801	.2572	.2058	.1715
20	.2743	.2915		.3734	.2915	.2743	.2401
21	.2058	.2229		.2614	.2058	.2058	.2058
22	.1372	.1715	.1867	.1867	.1715	.1715	.1715
23	.1372	.1543	.1494	.1494	.1543	.1372	.1372
24	.1372	.1372	.1543	.1494	.1494	.1372	.1372
Max	.4115	.3429	.4287	.4668	.3361	.3944	.3429
Min	.0686	.0686	.0934	.0747	.0514	.1029	.0857
Avg	.1679	.1648	.1916	.2085	.1623	.1858	.1693

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274208 / 33/11 KV Pathari Sub station

Feeder No / Name : 202 / 11 Kv Dhanore Ag feeder FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							1.166
2							1.2003
3							1.2346
4							1.2346
5							1.2517
6							1.2689
7							1.3375
8							1.0802
9	1.5947	1.7318			1.1145	1.2003	
10	1.7833	1.869	1.0802	.9962	1.2346	1.4403	
11	1.8004	1.9376		1.0279	1.3203	1.4232	
12	2.0576	1.989	1.186	1.0753	1.3032	1.3717	
13	2.0748	1.9719	1.2651	1.0437	1.3032	1.406	
14	1.8861	1.9719	1.3441	1.0437	1.3032	1.4575	
15	1.8004	1.9547		1.0753	1.3889	1.4232	
16	1.8519	1.5432	1.1702	1.1385	1.4575	1.406	
23						1.0117	1.0288
24							1.0974
Max	2.0748	1.989	1.3441	1.1385	1.4575	1.4575	1.3375
Min	1.5947	1.5432	1.0802	.9962	1.1145	1.0117	1.0288
Avg	1.8562	1.8711	1.2091	1.0572	1.3032	1.3489	1.19



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274208 / 33/11 KV Pathari Sub station

Feeder No / Name : 203 / 11 KV Pimpalwadi Ag FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.9259	.4973	.3281	.3125	.463	
2	.9945	.8916	.4801	.3125	.3125	.4801	
3	.9259	.9259	.4801	.3125	.3281	.4801	
4	.9602	.9431	.5144	.3281	.3437	.5144	
5	.9602	.9602	.5316	.3437	.3593	.5487	
6	1.0631	.9945	.5144	.3125	.3749	.5316	
7	1.1317	.9431	.5144	.3593	.4687	.6859	
8	1.0288	1.0288	.4973	.3281	.5144	.703	
9							.7202
10							.8059
11							.9259
13							1.0288
14							1.0288
15							.9088
16							1.0974
23	.8916	.463	.3281	.3125	.4458		
24	.9945	.9259	.4973	.3281	.3125	.463	
Max	1.1317	1.0288	.5316	.3593	.5144	.703	1.0974
Min	.8916	.463	.3281	.3125	.3125	.463	.7202
Avg	.9979	.9002	.4855	.3265	.3772	.5411	.9308

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274221 / 33/11KV BAVI SUB STATION

Feeder No / Name : 201 / 11 KV DAM FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	05-AUG-17	06-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.3048	1.0669	.8383	1.1888
2	.3658	.2896	1.0822	.884	1.1888
3		.2896	1.0517	.9145	1.2651
4		.3353	1.0822	1.0364	1.3717
5		.4268	1.1279	1.1584	1.4632
6		.6097	1.1736	1.326	1.768
7		.4877	1.2193	1.5851	1.7833
8		.442		1.5851	1.5699
12	1.4632				
13	1.5394				
14	1.6156				
15	1.5546	.2134	.1829	.2134	
16	1.5851	.1372	.2134	.2439	
17	.2134	.1219	.2743	.3048	.2439
18	.2743	.4268	.3658	.3353	.3048
19	.381	.4877	.3963	.3658	.4725
20	.4268	.4725	.4268	.3658	.4572
21	.442	.4877	.4268	.3658	.4572
22	.4268	.8535	.4268	.3963	.4268
23	.381	.9145	.7926	1.1431	1.4327
24	.3353	.3353	1.0059	.8078	1.2651
Max	1.6156	.9145	1.2193	1.5851	1.7833
Min	.2134	.1219	.1829	.2134	.2439
Avg	.7560	.4242	.7244	.7705	1.0412

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274221 / 33/11KV BAVI SUB STATION

Feeder No / Name : 202 / 11 KV TANDULWADI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	05-AUG-17	06-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2439	.0914	.0914	.1067
2	.2439	.2439	.0762	.0762	.1067
3	.2743	.2591			
4	.2743	.3201			
5	.3658	.3506			
6	.3658	.3506			
7	.3201	.381			
8	.3201	.3963			
9		.4268	.4877	.381	.4572
10		.5182	.4572	.3963	.5792
11		.5792	.4572	.4572	.5944
12		.6097	.4877	.4877	.6097
13		.5335	.5182	.5335	.6097
14		.5335	.5487	.5182	.6859
15	.061	.5487	.5182	.5487	.6706
16	.061	.061	.5182	.5792	.6554
17	.0457	.0457	.0457	.0914	.061
18	.0762	.1067	.061	.0914	.0762
19	.0762	.1219	.1067	.0914	.1219
20	.1219	.1219	.1524	.0914	.1372
21	.0914	.1067	.1219	.0914	.1372
22	.0914	.1067	.1067	.1067	.1219
23	.2286	.1067	.0914	.1067	.0914
24	.2591	.2286	.0914	.0914	.1067
Max	.3658	.6097	.5487	.5792	.6859
Min	.0457	.0457	.0457	.0762	.061
Avg	.1973	.3042	.2743	.2684	.3294

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274222 / 33/11 KV HINGANI.P SUB

STATION

Feeder No / Name : 201 / 11KV HINGANI.P AG FEEDER FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		2.1879				
9		2.0885	.9945	1.0974	1.6461	1.5775
16			1.2346	1.6956	2.0348	1.8482
23				1.6956		
24	1.0174	1.2929				
Max	1.0174	2.1879	1.2346	1.6956	2.0348	1.8482
Min	1.0174	1.2929	.9945	1.0974	1.6461	1.5775
Avg	1.0174	1.8564	1.1146	1.4962	1.8405	1.7129

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274222 / 33/11 KV HINGANI.P SUB

STATION

Feeder No / Name : 202 / 11KV NANDANI AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	2.3205				
24		1.166	1.6956	1.7295	1.8821
Max	2.3205	1.166	1.6956	1.7295	1.8821
Min	2.3205	1.166	1.6956	1.7295	1.8821
Avg	2.3205	1.166	1.6956	1.7295	1.8821

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274222 / 33/11 KV HINGANI.P SUB

STATION

Feeder No / Name : 203 / 11KV GAVTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9		.1865	.2035	.1357	.1696	.1865
16	.2321		.1696	.1357	.2035	.2229
24	.1696		.2035	.1715	.1715	.1696
Max	.2321	.1865	.2035	.1715	.2035	.2229
Min	.1696	.1865	.1696	.1357	.1696	.1696
Avg	.2009	.1865	.1922	.1476	.1815	.193

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274235 / 33/11 KV RATANJAN SUB

STATION

Feeder No / Name : 201 / 11 KV GAVTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.1372	.2743	.2401	.2401	.3258	.2229
2	.2229	.1372	.2915	.2572	.1715	.3258	.2401
3	.2058	.1372	.2915	.3086	.2058	.3086	.2401
4	.2743	.1543	.2915	.2743	.2401	.3086	.2743
5	.3086	.2743	.3086	.3086	.3086	.3258	.2915
6	.3429	.3429	.3086	.3258	.3429	.3258	.3601
7	.3086	.3429	.3086	.3086	.3429	.3429	.3258
8	.2743	.3429	.2743	.2743	.2743	.2743	.2743
9	.2915	.2401	.2401	.1715	.2058	.3086	.2915
10	.1543	.1372	.2401	.1715	.1715	.2572	.2058
11	.1543	.1029	.1715	.1372	.12	.2229	.2229
12	.1715	.0857	.1543	.1715	.12	.1372	.1715
13	.1715	.1029	.1543	.1543	.1715	.1715	.1715
14	.1543	.1029	.1372	.1715	.1543	.1886	.1715
15	.1543	.1029	.1372	.1715	.12	.2058	.1543
16	.1372	.1029	.1372	.1715	.1372	.1372	.1372
17		.12	.1886	.1715	.1372	.1543	.1543
18	.1543	.1372	.1543	.2229	.1372	.2058	.1886
19	.2401	.2401	.1886	.2401	.2058	.2743	.2229
20	.3429	.3429	.3258	.3429	.3429	.3601	.3086
21	.3086	.2401	.2401	.3086	.4287	.3086	.2915
22	.3086	.2401	.2229	.3429	.3772	.2572	.2572
23	.2058	.2572	.2401	.2401	.3601	.2229	.2743
24	.2058	.1715	.2743	.2058	.2401	.3429	.2229
<b>Max</b>	<b>.3429</b>	<b>.3429</b>	<b>.3258</b>	<b>.3429</b>	<b>.4287</b>	<b>.3601</b>	<b>.3601</b>
<b>Min</b>	<b>.1372</b>	<b>.0857</b>	<b>.1372</b>	<b>.1372</b>	<b>.12</b>	<b>.1372</b>	<b>.1372</b>
<b>Avg</b>	<b>.2318</b>	<b>.1915</b>	<b>.2315</b>	<b>.2372</b>	<b>.2315</b>	<b>.2622</b>	<b>.2365</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274236 / 33/11 KV DHAMANGAON SUB

STATIO

Feeder No / Name : 201 / 11 KV RALERAS FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.439	.3772	.7202	.7362	.6859	.6001	1.0288
2	.5068	.4287	.7202	.7716	.7234	.6859	1.0402
3	.543	.4191	.8573	.8573	.7209	.8383	1.1145
4	.6584	.503	.9054	.8573	.7545	.7545	1.2003
5	.6878	.6036	.9054	.9259	.9614	.8288	1.406
6	.724	.663	1.1934	1.0974	.9831	1.065	1.1736
7	.724	.6299	1.3763	1.2407	1.2944	.8383	1.1736
8	.7865	.663	1.0852	1.2071	1.5061	1.0128	1.4083
9	1.3413	.4252	.543	.5847	.6154	.4163	.5792
10	1.3108	.362	.181	.4163	.1463	.4207	.5853
11	1.166	.2012	.1612	.3258	.1448	.2353	.5373
12	1.094	.181	.181	.3077	.1267	.3258	.4525
13	.8383	.2172	.181	.2743	.128	.2561	.4572
14	.6371	.2012	.2012	.2926	.0914	.2534	.3982
15	1.2431	.2172	.2126	.2353	.1267	.2561	.3658
16	.7545	.2534	.3658	.2896	.1267	.2378	.3982
17	.2172	.2534	.2686	.3475	.181	.2896	.3292
18	.2195	.3982	.4755	.4887	.2743	.3628	.3258
19	.2561	.5487	.4525	.4706	.2715	.5068	.4572
20	.2534	.5792	.4525	.4706	.2353	.724	.0543
21	.2172	.4525		.4163	.2353	.543	.3658
22	.2195	.4525	.4344		.2378	.4706	.4344
23	.3429	.5853	.6965	.4908	.362	.7628	.7011
24	.3772	.3429	.6173	.6661	.6173	.4287	.8573
<b>Max</b>	<b>1.3413</b>	<b>.663</b>	<b>1.3763</b>	<b>1.2407</b>	<b>1.5061</b>	<b>1.065</b>	<b>1.4083</b>
<b>Min</b>	<b>.2172</b>	<b>.181</b>	<b>.1612</b>	<b>.2353</b>	<b>.0914</b>	<b>.2353</b>	<b>.0543</b>
<b>Avg</b>	<b>.6482</b>	<b>.4149</b>	<b>.5734</b>	<b>.5987</b>	<b>.4813</b>	<b>.5464</b>	<b>.7018</b>



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 274197 / 33/11 Kv Barshi Town Sub  
stati

Feeder No / Name : 201 / 11KV TOWN FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.905	.9328	.9193	.9526	.8688	.8779	.9193
2	.8688	.9145	.9376	.9526	.8326	.8779	.8825
3	.8326	.8688	.956	.9145	.8326	.8413	.9193
4	.8688	.8779	.9376	.9145	.8688	.8413	.9376
5	.8688	.9511	.9744	.9526	.905	.9145	.9744
6	.905	1.0059	.956	1.0479	.9412	.9877	.9193
7	.9774	1.2071	.9193	1.0479	1.0136	1.0059	.9928
8	.9593	1.0059	.9744	1.1431	.9774	1.0059	1.048
9	.8869	.9145	.9193	.905	.905	.9145	.9744
10	1.0059	1.0112	1.0288	.905	1.0059	.956	
11	1.0608	1.1031	1.086	1.0498	1.0608	1.0112	
12	1.0608	1.1767	1.1431	.9412	1.0974	1.0296	
13	1.0974	1.1583	1.2003	1.086	1.0608	1.048	
14	1.0974	1.195	1.2384	1.1222	1.0974	1.0296	
15	1.1157	1.2134	1.2384	1.086	1.0608	1.0112	
16	1.1157	1.2134	1.2384	1.1222	1.134	.9744	
17	1.1706	1.195	1.2384	1.086	1.0974	1.0112	
18	1.1523		1.3336	1.1765	1.1888	1.1031	
19	1.3535	1.6179	1.2765	1.2851	1.3169	1.1399	
20	1.2986	1.5995	1.2384	1.448	1.39	1.287	
21	1.2803	1.4708	1.2003	1.3032	1.4632	1.3421	
22	1.2071	1.2686	1.1622	1.1584	1.1888	1.3605	
23	1.0059	1.1031	1.0479	1.1222	1.0059	1.1031	
24	.9412	.9694	.956	.9526	.905	.9145	.9376
<b>Max</b>	<b>1.3535</b>	<b>1.6179</b>	<b>1.3336</b>	<b>1.448</b>	<b>1.4632</b>	<b>1.3605</b>	<b>1.048</b>
<b>Min</b>	<b>.8326</b>	<b>.8688</b>	<b>.9193</b>	<b>.905</b>	<b>.8326</b>	<b>.8413</b>	<b>.8825</b>
<b>Avg</b>	<b>1.0432</b>	<b>1.1293</b>	<b>1.0884</b>	<b>1.0698</b>	<b>1.0508</b>	<b>1.0245</b>	<b>.9505</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 274197 / 33/11 Kv Barshi Town Sub  
statiFeeder No / Name : 202 / 11 KV INDUSTRIAL ESTATE SHEDDABLE FEEDER HAVING WEEKLY  
NO.02 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.4338	.2646	.3429	.5068	.4338	.4158
2	.3258	.3772	.2835	.3429	.4706	.3961	.378
3	.3258	.3395	.3024	.3429	.4706	.3772	.3969
4	.2715	.3395	.2646	.2858	.3982	.3395	.3402
5	.2172	.415	.3024	.2858	.3801	.3584	.378
6	.2353	.4715	.3402	.2858	.3982	.3584	.3591
7	.4887	.547	.4158	.3429	.4344	.3772	.3402
8	.4525	.4527	.4536	.4191	.4887	.415	.3213
9	.6154	.3772	.5292	.5792	.5611	.5658	.4914
10	.6979	.3591	.5716	.6878	.7356	.6048	
11	.8488	.378	.6097	.7602	.8299	.6615	
12	.9054	.3969	.5716	.8145	.9054	.6993	
13	.6036	.3591	.5525	.6154	.8488	.6804	
14	.5658	.3213	.5335	.724	.811	.7182	
15	.7733	.3024	.4763	.8869	.7545	.6804	
16	.8488	.2835	.4763	.8507	.811	.7182	
17	.7922	.2268	.5716	.6516	.8865	.6048	
18	.7545		.6668	.5792	.7922	.567	
19	.7167	.1512	.6097	.5973	.7356	.5103	
20	.6602	.189	.5716	.5249	.6413	.4914	
21	.6036	.2268	.5144	.5068	.5658	.4536	
22	.547	.2457	.4763	.543	.5658	.4725	
23	.5093	.2646	.4763	.543	.5093	.4536	
24	.3982	.4715	.2835	.381	.5068	.4715	.4347
<b>Max</b>	<b>.9054</b>	<b>.547</b>	<b>.6668</b>	<b>.8869</b>	<b>.9054</b>	<b>.7182</b>	<b>.4914</b>
<b>Min</b>	<b>.2172</b>	<b>.1512</b>	<b>.2646</b>	<b>.2858</b>	<b>.3801</b>	<b>.3395</b>	<b>.3213</b>
<b>Avg</b>	<b>.5633</b>	<b>.3448</b>	<b>.4633</b>	<b>.5372</b>	<b>.6253</b>	<b>.5170</b>	<b>.3856</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 274197 / 33/11 Kv Barshi Town Sub  
statiFeeder No / Name : 203 / 11 KV BHAGAWANT FEEDER  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3077	.2378	.2951	.3429	.3077	.2561	.3135
2	.2804	.2195	.3135	.3239	.3077	.2195	.332
3	.2896	.2195	.2766	.3239	.3258	.2012	.3504
4	.3077	.2012	.2766	.2858	.362	.1829	.3504
5	.362	.3109	.3135	.381	.4163	.2743	.332
6	.4344	.3658	.2951	.381	.4344	.3658	.3135
7	.362	.4572	.2766	.381	.4706	.3292	.3504
8	.3258	.3109	.2951	.381	.3982	.3658	.3504
9	.3077	.2743	.2766	.2715	.2896	.2743	.332
10	.2743	.2398	.2858	.2353	.2012	.2582	
11	.2195	.2213	.2858	.2172	.2012	.2766	
12	.2378	.2213	.2858	.1991	.2195	.2951	
13	.2561	.2398	.2858	.2172	.2195	.2951	
14	.2561	.2213	.2858	.2353	.2378	.2766	
15	.2561	.2582	.2858	.2353	.2561	.2582	
16	.2378	.2766	.381	.2353	.2926	.2766	
17	.2378	.2951	.381	.2534	.2743	.2951	
18	.2561		.381	.2534	.2743	.332	
19	.3292	.3504	.381	.2534	.2926	.332	
20	.3292	.3688	.381	.3801	.4024	.3688	
21	.3658	.4057	.381	.3982	.3658	.3504	
22	.3658	.4242	.381	.3982	.3658	.3873	
23	.3109	.3688	.381	.3982	.2926	.4057	
24	.3258	.2743	.3135	.3429	.3077	.2561	.332
Max	.4344	.4572	.381	.3982	.4706	.4057	.3504
Min	.2195	.2012	.2766	.1991	.2012	.1829	.3135
Avg	.3015	.2940	.3206	.3052	.3132	.2972	.3357

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 203 / 11KV CANCER FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203	1.3203	1.1317			1.307	1.2003
2	1.1203	1.3203	1.1203			1.1203	1.2003
3	1.1203	1.3203	1.1317			1.1203	1.2003
4	.9335	1.1317	1.1317			1.1088	1.2003
5		1.1317	1.1317			1.307	1.0288
6		1.1317	1.1317			1.307	.8573
7	.9335	1.1317	1.1317			1.307	.8573
8	.8573	1.1317	1.1317			1.1203	.6859
9	.9145	1.1317	1.3203		.9335	1.3203	.6859
10	1.4632	1.1088	1.5242	1.0974	1.6804		1.5089
11	1.6461	.9431	1.7147	1.0974	1.4937	1.4632	1.5089
12	1.6461	1.1203	1.7147	1.2803	1.4937	1.2803	1.6975
13	1.6632	.9431	1.3336	1.2803	1.307	1.2803	1.307
14	1.6632		1.3336	1.2803	1.6804	1.2803	1.3203
15	1.6632		1.5242	1.6461	1.4937	1.2803	1.3203
16	1.848	1.1317	1.7147	1.6461	1.4632	1.2803	1.3203
17	1.829	1.1317	1.5242	1.2003	1.4632	1.2803	1.3203
18	1.6632	1.1203	1.3336	1.307	1.6461	1.2803	1.1203
19	1.307	1.1203	1.1431	1.0288	1.2803	1.0974	1.1203
20	1.2803	1.1317	1.1431	1.307	1.2803	1.0974	.924
21	1.2803	.9335	1.3336	1.307	1.307	1.2803	1.1317
22	1.2803	.924	1.3336		1.307	1.2803	1.1317
23	1.3203	1.1203	1.3336		1.307	1.2003	1.3203
24	1.307	1.3203	1.1317			1.2803	1.2003
Max	1.848	1.3203	1.7147	1.6461	1.6804	1.4632	1.6975
Min	.8573	.924	1.1203	1.0288	.9335	1.0974	.6859
Avg	1.3573	1.1273	1.3124	1.2898	1.4091	1.2469	1.1737

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 204 / 11KV I.T.I. FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.5544	.5316			.5487	.5144
2		.5544	.5258			.5544	.5144
3		.5544	.5144			.5487	.5144
4	.5601	.5544	.5258			.5544	.5144
5		.5544	.7164			.5601	.5144
6		.5544	.724			.5544	.5144
7	.5144	.5544	.724			.5601	.5144
8	.7468	.7392	.724			.7468	.5144
9	.7164	.7392	.5316		.7468	.5544	.5144
10	.5373	.5316	.5716	.7316	.5487	.5487	.724
11	.7164	.7316	.5716	.7316	.5487	.5144	.724
12	.7087	.724	.7621	.7316	.543	.5316	.7316
13	.7087	.724	.7621	.7316	.543	.5487	.7164
14	.7087	.724	.7621	.5487	.724	.5487	.5258
15	.7087	.5258	.7621	.5487	.724	.5144	.543
16	.7164	.724	.5716	.5487	.724	.5487	.543
17	.724	.724	.5716	.5601	.6935	.5144	.543
18	.724		.5716	.6859	.6859	.5144	.5487
19	.543	.724	.7621		.7011	.7316	.7316
20	.9145	.7316	.7621	.7468	.7087	.6859	.7316
21	.724	.7316	.7621	.7468	.7087	.6859	.724
22	.7164	.724	.7621		.7087	.5144	.7316
23	.5544	.5258	.7621		.5487	.5487	.543
24	.5601	.5544	.5258			.5487	.5144
Max	.9145	.7392	.7621	.7468	.7468	.7468	.7316
Min	.5144	.5258	.5144	.5487	.543	.5144	.5144
Avg	.6682	.6417	.6567	.6647	.6572	.5701	.5919

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 206 / 11KV MILL FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0026	1.4937	1.4784			1.4937	2.7434
2	2.9721	1.4937	1.4937			1.4937	2.8654
3	2.9873	1.4937	1.2936			1.4937	2.7434
4	1.4784	1.4937	1.2803			1.4937	2.7434
5	1.6804	1.4937	1.4784			1.6804	2.7434
6	3.1721	1.4937	1.4784			1.6804	2.4006
7	3.3436	1.6804	1.6804			1.8671	2.4006
8	3.3436	1.6804	1.6632		1.6975	1.4937	2.7434
9	1.6632	1.307	1.4937		3.3779	1.6804	1.3717
10	1.2936	1.5089	1.7147	1.5432	1.6975	1.7147	1.6804
11	2.0328	1.5089	2.0957	1.6289	1.8861	1.5432	2.0538
12	2.2177	1.307	2.0957	2.0576	1.8861	1.5432	2.0538
13	1.848	1.307	2.0957	1.8861	1.8861	1.5432	2.0538
14	1.6461	1.307	2.0957	1.8861	1.6975	1.7147	1.4784
15	1.6632	1.2936	2.0957	2.0576	1.8861	1.8861	1.8671
16	2.0538	1.4937	2.0957	2.0576	2.0748	1.8861	2.0748
17	2.0328	1.4937	2.0957		1.848	2.0576	1.8671
18	1.848	1.2936	2.0957		2.0328	2.0576	1.8671
19	1.6804	1.4937	1.9052	1.8671	1.6632	1.5432	1.8671
20	1.6804	3.3779	1.7147		1.8671	1.5432	1.6804
21	1.6632	1.6804	1.7147	1.6804	1.6632	1.3717	1.4937
22	1.6632	1.6804	1.7147		1.6632	1.3717	1.6804
23	1.6613	1.4937	1.5242	1.8671	1.6804	1.3717	1.6804
24	1.6556	1.4937	1.4784		1.5089	1.4937	2.7434
Max	3.3436	3.3779	2.0957	2.0576	3.3779	2.0576	2.8654
Min	1.2936	1.2936	1.2803	1.5432	1.5089	1.3717	1.3717
Avg	2.0951	1.5568	1.7447	1.8532	1.8833	1.6258	2.1207

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 207 / 11KV JAIN MANDIR FEEDER SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6804	1.4937	1.6632			1.4784	1.3717
2	1.6804	1.4937	1.4632			1.4784	1.3717
3	1.6804	1.4937	1.4632			1.4784	1.3717
4		1.4937	1.6632			1.4784	1.3717
5	1.6804	1.6804	1.6632			1.6632	1.5432
6	1.4937	1.8671	1.8671			1.6804	1.7147
7	1.8671	2.0538	2.0538			1.8671	1.7147
8	1.6804	1.8671	1.6632			1.8671	1.7147
9	1.6461	1.6632	1.4784		1.8671	1.6632	1.7147
10	1.2803	1.4632	1.5242	.6859	1.267	1.6461	1.2936
11	1.267	1.267	1.1431	1.2003	1.267	1.5432	1.2803
12	1.2936	1.2803	1.3336	1.3717	1.267	1.2003	1.2803
13	1.2803	1.267	1.3336	1.3717	1.2803	1.2003	1.267
14	1.2803	1.2536	1.3336	1.2003	1.2803	1.2803	1.4632
15	1.2936	1.267	1.3336	1.2003	1.267	1.2003	1.2803
16	1.2936	1.2803	1.3336	1.2803	1.267	1.3717	1.2936
17	1.2936	1.2803	1.3336	1.6804	1.2136	1.3717	1.2936
18	1.4784	1.4784	1.5242	1.6804	1.387	1.5432	1.4784
19	1.5947	1.848	1.7147	1.8671	1.8099	1.7147	1.848
20	2.1948	2.2405	2.2862	1.8671	1.848	1.7147	2.0538
21	2.1948	2.2405	2.2862	2.0538	2.0328	1.3717	2.0538
22	2.0119	2.0328	2.0957		2.0328	1.3717	1.8671
23	1.6804	1.6461	1.9052		1.6632	1.3717	1.6632
24	1.6804	1.4937	1.6461			1.4784	1.3717
Max	2.1948	2.2405	2.2862	2.0538	2.0328	1.8671	2.0538
Min	1.267	1.2536	1.1431	.6859	1.2136	1.2003	1.267
Avg	1.5881	1.6019	1.6294	1.4549	1.5167	1.5014	1.5282

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 208 / 11KV BHAVANI PETH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.4784	1.4784			1.4784	1.2003
2	1.4937	1.4784	1.4784			1.4784	1.2003
3	1.4937	1.4784	1.2803			1.4937	1.2003
4	1.6804	1.4784	1.4784			1.2936	1.2003
5	1.6804	1.4784	1.4784			1.4937	1.3717
6	1.6804	1.4784	1.6804			1.4784	1.2003
7		1.6632	1.6632			1.6632	1.2003
8	1.5432	1.6632	1.6804			1.4784	1.3717
9	1.6632	1.6632	1.4784		1.5089	1.448	1.3717
10	1.6632	1.4632	1.5242	1.6461	1.4632		1.4937
11	1.6632	1.4784	1.7147	1.5432	1.6461	1.2803	1.4632
12	1.6461	1.4632	1.7147	1.3717	1.6461	1.3717	1.4784
13	1.6632	1.4632	1.7147	1.5432	1.6461	1.3717	1.4632
14	1.6632	1.4632	1.7147	1.5432	1.6461	1.3717	1.4632
15	1.6632	1.6804	1.7147	1.5432	1.4632	1.3717	1.4937
16	1.6632	1.6804	1.7147	1.5432	1.4632	1.3717	1.4784
17	1.6461	1.6632	1.5242	1.6804	1.4327	1.3717	1.4784
18	1.6461	1.6804	1.7147	1.6804	1.4327	1.3717	1.6804
19	1.848	1.8671	1.9052	1.8671	1.829	1.5432	1.848
20	2.0328	2.2634	2.0957		1.848	1.7147	1.8671
21	2.0328	2.0538	2.0957	1.8671	1.848	1.5432	1.8671
22	1.848	1.848	1.9052		1.848	1.5432	1.8671
23	1.6804	1.6632	1.7147		1.4784	1.3717	1.4784
24	1.4937	1.4784	1.4784			1.4632	1.3717
Max	2.0328	2.2634	2.0957	1.8671	1.848	1.7147	1.8671
Min	1.3717	1.4632	1.2803	1.3717	1.4327	1.2803	1.2003
Avg	1.6722	1.6279	1.6643	1.6208	1.6133	1.4507	1.4629



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 213 / 11KV BARSHI TEXTILE MILL NON SHEDDABLE EXPRESS HV FEEDERS  
EXPRES Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9335	.9431	.0137			.9431	.8573
2	.9335	.9431	.0057			.9431	.8573
3		.9431	.0103			.9431	.8573
4	.9335	.9431	.0097			.9431	.8573
5		.9431	.0126			.9431	.8573
6		.9431	.0097			1.1317	.8573
7	.9335	.9431	.4287			.9431	.8573
8	1.1203	.5658	1.1317			1.1317	.8573
9	.9431	.5658	1.1317		.9335	1.1317	.8573
10	1.1317	.4401	1.1431	.8573	1.1317	.8573	1.1317
11	1.1317	.4287	1.1431	.8573	1.1317	.8573	1.1317
12	1.1317	.4458	1.1431	.8573	1.1317	.8573	1.1317
13	1.1317	.4401	.9526	.8573	1.1317	.8573	1.1317
14	1.1317	.4172	.9526	1.0288	1.1317	.8573	1.1317
15	1.1317	.4344	1.1431	1.0288	1.1317	.8573	.9335
16	1.1317	.0533	1.1431	1.0288	1.1317	.8573	.9335
17	1.1317	.0533	.9526	.9335	1.1317	.8573	.9335
18	.9431	.0553	.9526	.9335	.9431	.8573	.9335
19	.9431	.0572	.9526	.8573	.9431	.8573	1.1317
20	.9431	.0343	.9526		.9431	.8573	.9335
21	.9431	.0514	.9526	.9335	.9431	.8573	.9335
22	.9431	.0572	.9526		.9431	.8573	.9335
23	.9431	.0533	.9526		.9431	.8573	.9335
24	.8383	.9431	.0137			.9431	.8573
Max	1.1317	.9431	1.1431	1.0288	1.1317	1.1317	1.1317
Min	.8383	.0343	.0057	.8573	.9335	.8573	.8573
Avg	1.0166	.4874	.7107	.9249	1.0430	.9166	.9513

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 402 / Paranda

Feeder KV- 33 / INCOMING

DATE	01-AUG-17
HR	Load (MW)
24	2.4291
Max	2.4291
Min	2.4291
Avg	2.4291

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 403 / Agalgaon

Feeder KV- 33 / INCOMING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4815	1.5746	1.3649	1.5432	1.5364	1.5364	1.6492
2	1.3717	1.4661	1.308	1.4861	1.5364	1.4815	1.5924
3	1.3717	1.4118	1.2511	1.4861	1.4266	1.3717	1.7061
4	1.3717	1.3575	1.3649	1.4861	1.4266	1.3032	1.6492
5	1.4266	1.6832	1.308	1.6004	1.4266	1.5203	1.6492
6	1.4815	1.8461	1.4218	1.6575	1.7558	1.6289	1.5924
7	1.8107	2.1719	1.5924	1.7147	1.9204	1.6461	1.6492
8	1.8107	2.0633	1.6492	1.8861	1.7558	1.7918	1.5924
9	1.7558	1.4661	1.8198	1.8107	1.701	1.7918	1.7061
10	1.9547	1.5924	1.829	1.8656	2.009	1.9905	
11	2.0633	1.701	1.8861	2.0302	2.0633	1.9336	
12	2.1948	1.8198	1.8861	1.9753	2.2497	2.1611	
13	1.9004	1.763	1.9433	1.9204	1.9547	2.1042	
14	1.8461	1.8767	1.9433	2.0851	1.9547	1.9905	
15	2.1176	1.8198	2.1719	2.1948	1.8461	2.0473	
16	2.1719	1.8767	2.1719	2.1399	2.2262	2.0473	
17	2.1719	1.763	2.1719	1.9753	2.2805	1.9336	
18	2.0633		2.2862	1.9753	2.1176	2.0473	
19	2.2262	2.0473	2.0576	2.0851	2.2805	1.9905	
20	2.3045	2.1042	2.0576	2.2497	2.4143	2.1042	
21	2.0302	1.8767	2.0005	2.0851	2.3348	2.0473	
22	1.9204	1.8198	1.9433	1.9547	1.9004	1.8767	
23	1.701	1.5924	1.829	1.701	1.7375	1.7061	
24	1.5364	1.6832	1.308	1.6004	1.5912	1.6289	1.5924
Max	2.3045	2.1719	2.2862	2.2497	2.4143	2.1611	1.7061
Min	1.3717	1.3575	1.2511	1.4861	1.4266	1.3032	1.5924
Avg	1.8369	1.7555	1.7736	1.8545	1.8936	1.8200	1.6379

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 404 / Pangari

Feeder KV- 33 / INCOMING

DATE	01-AUG-17
HR	Load (MW)
24	4.8583
Max	4.8583
Min	4.8583
Avg	4.8583

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 407 / 33KV Atlanta Feeder (T/F

1) Feeder KV- 33 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	10.0823	3.3265	3.3608			3.3265	1.0082
2		3.3265	3.2922			3.1927	9.2593
3		3.3265	3.2922			3.1927	9.2593
4	10.0823	3.1602	3.2922			3.1927	9.2593
5	10.0823	3.3265	3.3265			3.5288	
6	9.5222	3.4928	3.8809			3.5648	9.2593
7		3.7146	3.8809			3.7146	9.2593
8	10.0823	3.7146	3.3608			3.7146	8.7449
9	3.2579	3.5288	3.3265		10.6424	3.4928	8.7449
10	3.2579	3.2236	3.6008	7.8418	3.4568		3.2922
11	3.638	2.7721	3.4294		3.2922		3.2922
12	3.638	3.2922	3.8866		3.2922		3.8809
13	3.638	2.6863	3.4294		3.1276		3.2922
14	3.638	2.1719	3.4294		3.6763		3.2922
15	3.638	1.6461	3.5437		3.4568		3.2922
16	3.8009	3.3265			3.4568		3.3265
17	3.8409	3.3265	3.4294		3.4568		3.3265
18	3.8409	2.7435	3.4294	10.0995	3.8409		3.2922
19	3.4568	3.8809	3.6008		3.8409		3.8409
20	4.3896	3.8809	4.1152	11.7627	3.8409		3.8809
21	4.225	3.8809	4.2867	12.3228	4.0472		3.8409
22	4.0055	3.8809	4.1152		4.0472		3.9209
23	3.4568	3.2922	4.0009		3.4928		3.3265
24	10.6424	3.3608	3.3265			3.3265	10.0823
Max	10.6424	3.8809	4.2867	12.3228	10.6424	3.7146	10.0823
Min	3.2579	1.6461	3.2922	7.8418	3.1276	3.1927	1.0082
Avg	5.5341	3.2618	3.5929	10.5067	4.0645	3.4247	5.3902

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 408 / 33KV Atlanta Feeder (T/F

2) Feeder KV- 33 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.6965	5.0926	3.3608			5.0926	12.8601
2	14.0032	4.9228	3.3608			4.9228	12.8601
3	14.0032	4.9228	3.2922			4.9228	12.3457
4		4.9228	3.3265			4.6965	12.3457
5	15.1235	4.5268	3.3265			5.0926	12.3457
6		4.5268	3.9209			5.2624	11.3169
7	15.2469	4.9228	4.5268			5.4887	11.3169
8	10.0823	4.5268	5.0926			5.2624	12.3457
9	4.9897	4.1307	5.0926		14.712	5.6584	12.3457
10	5.3778	3.8409	5.7156		5.4332		5.0412
11	6.2649	4.481	6.7444		5.9934		5.6013
12	6.4866	3.8809	6.7444		5.9934		5.6013
13	5.7105	3.9209	5.9442		5.9322		5.5441
14	5.5441	3.8809	5.9442		5.7105		4.9897
15	5.5441	3.9209	6.1728		5.7693		5.6013
16	6.2649	3.9609	6.4015		6.1614		5.6013
17	5.9934	3.9209	6.2872		5.7105		5.6013
18	5.6013	3.9209	6.2872		5.6013		5.5441
19	5.6013	3.9609	6.1157		5.6013		5.5441
20	5.6013	4.5268	5.7156		5.8282		5.0412
21	5.7693	4.5268	5.7156		5.6584		5.0926
22	5.6013	4.5268	5.487		5.6584		5.6584
23	5.2092	3.9209	5.144	16.2437	5.2624		5.0926
24	4.9228	5.0926	3.3608			5.0926	13.3745
Max	15.2469	5.0926	6.7444	16.2437	14.712	5.6584	13.3745
Min	4.6965	3.8409	3.2922	16.2437	5.2624	4.6965	4.9897
Avg	7.4381	4.3657	5.1283	16.2437	6.3351	5.1492	8.2921

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274010 / 33/11 KV SUBSTATION JEUR (SO

J

Feeder No / Name : 201 / 11 KV JEUR URBAN GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.3506	.6135	.4382	.6135	.443	.5258	.5316
Max	.3506	.6135	.4382	.6135	.443	.5258	.5316
Min	.3506	.6135	.4382	.6135	.443	.5258	.5316
Avg	.3506	.6135	.4382	.6135	.443	.5258	.5316

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274010 / 33/11 KV SUBSTATION JEUR (SO

J

Feeder No / Name : 202 / 11 KV PANGARE GAONTHAN

GAONTHAN FEEDER

(WANGI Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.9145
Max	.9145
Min	.9145
Avg	.9145



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274010 / 33/11 KV SUBSTATION JEUR (SO

J

Feeder No / Name : 203 / 11 KV DAHIGAON-SHETFAL AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.1581	.1581	.1581	.1581	.1581	.1585	.1581
Max	.1581	.1581	.1581	.1581	.1581	.1585	.1581
Min	.1581	.1581	.1581	.1581	.1581	.1585	.1581
Avg	.1581	.1581	.1581	.1581	.1581	.1585	.1581

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274010 / 33/11 KV SUBSTATION JEUR (SO

J

Feeder No / Name : 204 / 11 KV DAHIGAON W/S NON SHEDDABLE WATER SUPPLY AND  
 EXPRESS Feeder KV- 11 / UTILITY  
 OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	2.7435	.1753	.0876	.1753	.1753	.3506	.1753
Max	2.7435	.1753	.0876	.1753	.1753	.3506	.1753
Min	2.7435	.1753	.0876	.1753	.1753	.3506	.1753
Avg	2.7435	.1753	.0876	.1753	.1753	.3506	.1753

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274010 / 33/11 KV SUBSTATION JEUR (SO

J

Feeder No / Name : 205 / 11 KV PANGARE AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	2.5911
Max	2.5911
Min	2.5911
Avg	2.5911

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274010 / 33/11 KV SUBSTATION JEUR (SO

J

Feeder No / Name : 206 / 11 KV WANGI NO-2 AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	2.5911
Max	2.5911
Min	2.5911
Avg	2.5911

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274010 / 33/11 KV SUBSTATION JEUR (SO

J

Feeder No / Name : 207 / 11 KV JEUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	2.5911
Max	2.5911
Min	2.5911
Avg	2.5911

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274011 / 33/11 KV SUBSTATION KANDAR

(S

Feeder No / Name : 201 / 11 KV KANDAR GAONTHAN

GAONTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
23	.9145
24	1.0288
Max	1.0288
Min	.9145
Avg	.9717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274011 / 33/11 KV SUBSTATION KANDAR

(S

Feeder No / Name : 202 / 11 KV BARSHI W/S EXPRESS NON SHEDDABLE WATER SUPPLY AND  
Feeder KV- 11 / OUTGOING UTILITY

DATE	01-AUG-17
HR	Load (MW)
24	1.0288
Max	1.0288
Min	1.0288
Avg	1.0288

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274011 / 33/11 KV SUBSTATION KANDAR

(S

Feeder No / Name : 203 / 11 KV BITERGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	2.4387
Max	2.4387
Min	2.4387
Avg	2.4387



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274011 / 33/11 KV SUBSTATION KANDAR

(S

Feeder No / Name : 204 / 11 KV KAVITGAON AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.2439					
3		.2439					
4		.2439					
5		.2286					
6		.2286					
7		.2439					
8	.2286		.2439	1.9052	2.2862	1.829	1.829
9	.2439		.2439	.2439	.2439	.2439	.2286
10	1.9814		1.829	.2439	.2439	.2439	.2439
11	1.829		.2439	.2439	.2439	.2439	.2439
12	1.9814		.2743	.2439	.2439	.2439	.2439
13	1.829		.2439	.2439	.2439	.2439	.1829
14	1.9814		.2439	.2439	.2439	.2439	.2439
Max	1.9814	.2439	1.829	1.9052	2.2862	1.829	1.829
Min	.2286	.2286	.2439	.2439	.2439	.2439	.1829
Avg	1.4392	.2388	.4747	.4812	.5357	.4703	.4594

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274011 / 33/11 KV SUBSTATION KANDAR

(S

Feeder No / Name : 205 / 11 KV WADSHIWANE-SATOLI SEPARATED AG FEEDERS HAVING SPECIAL  
AG Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		1.829				
3		1.6766				
4		1.7528				
5		1.9052				
6		1.829				
7		1.9052				
8	.1829		.2743	.2439	.2439	.1981
9	.2743		.2439	.2439	1.829	1.829
10	.2439		1.829	1.829	1.9052	1.829
11	.2439		1.829	1.829	1.829	1.829
12	.2439		1.9052	1.9052	1.829	1.7528
13	.2439		1.9052	1.9052	1.829	1.9509
14	.2439		1.9814	1.9052	1.9052	1.829
23	1.9814					
24	2.4387					
Max	2.4387	1.9052	1.9814	1.9052	1.9052	1.9509
Min	.1829	1.6766	.2439	.2439	.2439	.1981
Avg	.6774	1.8163	1.424	1.4088	1.6243	1.6025

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274011 / 33/11 KV SUBSTATION KANDAR

(S

Feeder No / Name : 206 / 11 KV KANDAR VILLAGE AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.2439					
3		.2439					
4		1.829					
5		.2439					
6		.2439					
7		.2439					
8	.2134		1.829	1.829	1.9052	1.829	1.829
9	.2439		.2439	.1829	.2439	.2439	.2439
10	1.829		.2439	.2439	.2439	.2439	.2439
11	1.9052		.2439	.2439	.2439	.2439	.2439
12	1.9052		.2439	.2439	.2439	.2439	.2134
13	1.829		.2439	.2134	.2439	.2439	.2439
14	1.9528		.2439	.2134	.2439	.2439	.2439
24	2.4387						
Max	2.4387	1.829	1.829	1.829	1.9052	1.829	1.829
Min	.2134	.2439	.2439	.1829	.2439	.2439	.2134
Avg	1.5397	.5081	.4703	.4529	.4812	.4703	.4660

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEJUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274011 / 33/11 KV SUBSTATION KANDAR

(S

Feeder No / Name : 207 / 11 KV HARITKRANTI AG

PURELY LIS FEEDERS

EXPRESS F Feeder KV- 11 /  
OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.0762					
3		.0762					
4		.1219					
5		.1219					
6		.0762					
7		.1219					
8	.1219		.1524	.1219	.1219	.0762	.0762
9	.0762		.0762	.1219	.0762	.1524	.1524
10	.0762		.0762	.1219	.0762	.0762	.0762
11	.1219		.0762	.0762	.0762	.1219	.0762
12	.1219		.1219	.0762	.0762	.0762	.0762
13	.1219		.1219	.1219	.1219	.1219	.0762
14			.1219	.1219	.1219	.1219	.0762
24	.6097						
Max	.6097	.1219	.1524	.1219	.1219	.1524	.1524
Min	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Avg	.1785	.0991	.1067	.1088	.0958	.1067	.0871

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274011 / 33/11 KV SUBSTATION KANDAR

(S

Feeder No / Name : 208 / 11 KV KANDAR BACKWATER AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.2439					
3		.2439					
4		.2439					
5		.2439					
6		.2439					
7		.2439					
8	.2439		.2286	1.829	1.829	1.829	1.829
9	.2743		.2439	.2439	.2439	.2439	.2439
10	1.829		.2439	.2286	.2439	.2439	.2439
11	1.9814		.2439	.2439	.2439	.2439	.2134
12	1.9814		.2743	.2439	.2439	.2439	.2134
13	1.829		.2439	.2439	.2439	.2286	.2439
14	1.829		.2439	.2439	.2439	.2439	.1829
23							1.829
24	2.4387						
Max	2.4387	.2439	.2743	1.829	1.829	1.829	1.829
Min	.2439	.2439	.2286	.2286	.2439	.2286	.1829
Avg	1.5508	.2439	.2461	.4682	.4703	.4682	.6249

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274013 / 33/11 KV SUBSTATION KEM (SO  
KA

Feeder No / Name : 201 / 11 KV KEM GAONTHAN

GAONTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018		.415	.3206	.3395	.3395	
2	.3018		.3772	.3206	.3584	.3395	
3	.3018		.3584	.3772	.3772	.3772	
4	.3772		.3961	.4715	.3772	.3772	
5	.4715		.3961	.6036	.3961	.4715	
6	.547		.5281	.6413	.4527	.5847	
7	.4715		.6224	.4904	.5093	.5847	
9		.3584	.4338		.3426	.4527	
10		.3395	.4338		.3939	.415	
11		.3961	.415		.4111	.3961	
12		.415	.4715		.3597	.3772	
13		.3772	.4904		.3768	.3961	
14		.3961	.3772		.3597	.415	
15		.3961	.3584			.4715	
16		.3772	.3584			.5281	.4527
17		.3961	.4904		.5658		
18		.415	.4715		.547		
19		.3772	.5281		.4527		
20		.3961	.4715		.5281		
21		.415	.4338		.4715		
22		.3961	.3772		.3772		
23		.3772	.3772		.3772		
24	2.4387		.3961	.3206	.3584	.3206	
Max	2.4387	.415	.6224	.6413	.5658	.5847	.4527
Min	.3018	.3395	.3584	.3206	.3395	.3206	.4527
Avg	.6514	.3886	.4338	.4432	.4158	.4279	.4527

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEJUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274013 / 33/11 KV SUBSTATION KEM (SO

KA

Feeder No / Name : 202 / 11 KV WADSHIVANE AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7833		.4614	.4887	.3946	.439	
2	1.7833		.4614	.4938	.4433	.439	
3	2.0576		.4433	.5304	.396	.5487	
4	2.0576		.3946	.6001	.4275	.5601	
5	2.3148		.4944	.7011	.4604	.5975	
6	2.4177		.5274	.7545	.4275	.5658	
7	2.8635		.6592	.6516	.4768	.5658	
8	2.7263		.4933		.3288	.5228	
9		.3617	1.7147		1.6692	2.2742	
10		.3573	2.0576		1.7756	2.3237	
11		.3296	2.452		1.9547	2.505	
12		.3461	2.572		2.5292	2.6368	
13		.3626			2.6226	2.6698	
14		.3296			2.7366	2.7027	
15		.3473				2.7522	
16		.3617	.6859			2.6459	2.7435
17		.3461	.3801		.4163		
18		.3617	.4163		.5249		
19		.3288	.5249		.5611		
20		.4609	.5144		.6154		
21		.4933	.543		.6135		
22		.4604	.4973		.5658		
23		.4438	.463		.543		
24	2.4387		.4285	.4887	.3946	.4481	
Max	2.8635	.4933	2.572	.7545	2.7366	2.7522	2.7435
Min	1.7833	.3288	.3801	.4887	.3288	.439	2.7435
Avg	2.2714	.3794	.8183	.5886	.9490	1.4822	2.7435

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEJUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274013 / 33/11 KV SUBSTATION KEM (SO  
KAFeeder No / Name : 203 / 11 KV MALAWADI AG SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4887		1.5491	1.3717	1.5491	1.5432	
2	.4887		1.6645	1.3717	1.5656	1.5432	
3	.4938		1.9611	1.3717	1.7139	1.5432	
4	.5487		1.9401		1.7922	2.0576	
5	.7316		2.0435		2.0388	2.572	
6	.7716		2.0717		2.535	2.6406	
7	.703		1.9776		2.7686	2.572	
8	.6154		2.0388		2.6307	2.9492	
9		2.0106	.3658		.324	.3941	
10		2.0765	.3841		.341	.3613	
11		2.1046	.2926		.3581	.3449	
12		2.0717	.2743		.3751	.3285	
13		2.1777			.3751	.3449	
14		2.2167	.4024		.4263	.3613	
15		2.1754	.439			.3285	
16		2.0765				.427	.4163
17		.4944			.583		
18		.5109			.5658		
19		.4614			.5316		
20		.4779			.6001		
21		.5109			.583		
22		.4961			.5144		
23		1.4173			1.3717		
24	2.4387		1.4173	1.2174	1.2854	1.4575	
Max	2.4387	2.2167	2.0717	1.3717	2.7686	2.9492	.4163
Min	.4887	.4614	.2743	1.2174	.324	.3285	.4163
Avg	.8089	1.4186	1.2548	1.3331	1.1286	1.2805	.4163



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274013 / 33/11 KV SUBSTATION KEM (SO

KA

Feeder No / Name : 205 / 11 KV UPALWATE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288		.3288	.3429	.3296	.3429	
2	1.0288		.3288	.3429	.3296	.3429	
3	1.286		.3288	.3429	.3307	.3429	
4	1.286		.3288	.3429	.3296	.3429	
5	1.5432		.3288	.4287	.3296	.3429	
6	1.8004		.3288	.4287	.3296	.4287	
7	2.0576		.3296	.4287	.3307	.4287	
8	2.0576		.3288		.3296	.3429	
9		.3296	.3258			.3296	
10		.3296	.3239				
11		.3296	.3239				
12		.3296	.3239				
13		.3296	.4049				
14		.3296	.4049				
15		.3307	.4049				
16		.3296					.3429
17		.3296			2.0576		
18		.3296			2.0576		
19					2.1605		
20					1.8004		
21		.3307			1.8004		
22		.3296			1.8004		
23		.3296			1.8004		
24	2.4387		.3288	1.5432	***	1.5432	
Max	2.4387	.3307	.4049	1.5432	16.3152	1.5432	.3429
Min	1.0288	.3296	.3239	.3429	.3296	.3296	.3429
Avg	1.6141	.3298	.3420	.5251	2.0270	.4788	.3429

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEJUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274013 / 33/11 KV SUBSTATION KEM (SO

KA

Feeder No / Name : 206 / 11 KV KEM VILLAGE AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9			2.6878	2.472	
10			2.672	2.472	
11			2.672	2.7282	
12			2.672	2.472	
13			2.4291	2.472	
14			2.4291	2.472	
15			2.4291	2.472	2.9321
16				2.472	
17		1.4832		2.472	
18		1.4832			
19		1.648			
20		1.648			
21		1.9776			
22		1.9776			
23		1.9776			
24	2.4387		2.3019		
<b>Max</b>	<b>2.4387</b>	<b>1.9776</b>	<b>2.6878</b>	<b>2.7282</b>	<b>2.9321</b>
<b>Min</b>	<b>2.4387</b>	<b>1.4832</b>	<b>2.3019</b>	<b>2.472</b>	<b>2.9321</b>
<b>Avg</b>	<b>2.4387</b>	<b>1.7422</b>	<b>2.5366</b>	<b>2.5005</b>	<b>2.9321</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274017 / 33/11 KV SUBSTATION SALSE  
(SOFeeder No / Name : 201 / 11 KV SALSE GAONTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-AUG-17
HR	Load (MW)
24	.9145
Max	.9145
Min	.9145
Avg	.9145

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274017 / 33/11 KV SUBSTATION SALSE

(SO

Feeder No / Name : 202 / 11 KV SALASE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	03-AUG-17
HR	Load (MW)	Load (MW)
19		2.4387
24	2.7435	
<b>Max</b>	<b>2.7435</b>	<b>2.4387</b>
<b>Min</b>	<b>2.7435</b>	<b>2.4387</b>
<b>Avg</b>	<b>2.7435</b>	<b>2.4387</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274017 / 33/11 KV SUBSTATION SALSE

(SO

Feeder No / Name : 203 / 11KV ALSUNDE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	2.4387
Max	2.4387
Min	2.4387
Avg	2.4387

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274044 / 33/11 KV SUBSTATION

CHIKHALTHA

Feeder No / Name : 201 / 11KV CHIKHALTHAN GAONTHAN

GAONTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
23	1.0288						.362
24		.3429	.362	.362	.3658	.3658	
Max	1.0288	.3429	.362	.362	.3658	.3658	.362
Min	1.0288	.3429	.362	.362	.3658	.3658	.362
Avg	1.0288	.3429	.362	.362	.3658	.3658	.362

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274044 / 33/11 KV SUBSTATION

CHIKHALTHA

Feeder No / Name : 203 / 11 KV KEDGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
23		1.8861					
24	2.5911		2.1434	2.4006	2.4006	2.572	2.572
Max	2.5911	1.8861	2.1434	2.4006	2.4006	2.572	2.572
Min	2.5911	1.8861	2.1434	2.4006	2.4006	2.572	2.572
Avg	2.5911	1.8861	2.1434	2.4006	2.4006	2.572	2.572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274044 / 33/11 KV SUBSTATION

CHIKHALTHA

Feeder No / Name : 204 / 11 KV KOTLING DEVASTHAN AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	2.5911	.0905	.0905	.0905	.0905	.0914	.0914
Max	2.5911	.0905	.0905	.0905	.0905	.0914	.0914
Min	2.5911	.0905	.0905	.0905	.0905	.0914	.0914
Avg	2.5911	.0905	.0905	.0905	.0905	.0914	.0914



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274044 / 33/11 KV SUBSTATION

CHIKHALTHA

Feeder No / Name : 205 / 11 KV SHETFAL(NAGOBACHE) SEPARATED AG FEEDERS HAVING SPECIAL  
AG Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	2.5911
Max	2.5911
Min	2.5911
Avg	2.5911

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274044 / 33/11 KV SUBSTATION

CHIKHALTHA

Feeder No / Name : 206 / 11 KV KUGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	2.4387
Max	2.4387
Min	2.4387
Avg	2.4387

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274090 / 33/11 KV SUBSTATION WANGI

NO-1

Feeder No / Name : 201 / 11 KV WANGI GAONTHAN

GAONTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.9145
Max	.9145
Min	.9145
Avg	.9145

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274090 / 33/11 KV SUBSTATION WANGI

NO-1

Feeder No / Name : 202 / 11 KV DHOKARI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
23	2.7435
Max	2.7435
Min	2.7435
Avg	2.7435

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274090 / 33/11 KV SUBSTATION WANGI

NO-1

Feeder No / Name : 203 / 11 KV WANGI 4 AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	2.4387
Max	2.4387
Min	2.4387
Avg	2.4387

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274090 / 33/11 KV SUBSTATION WANGI

NO-1

Feeder No / Name : 204 / 11 KV PANGARE AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	2.4387
Max	2.4387
Min	2.4387
Avg	2.4387

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274090 / 33/11 KV SUBSTATION WANGI

NO-1

Feeder No / Name : 205 / 11 KV WANGI-3 AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	2.4387
Max	2.4387
Min	2.4387
Avg	2.4387

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274090 / 33/11 KV SUBSTATION WANGI

NO-1

Feeder No / Name : 206 / 11 KV NAGANATH AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	2.4387
Max	2.4387
Min	2.4387
Avg	2.4387



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274106 / 33/11 KV SUBSTATION SADE (SO

S

Feeder No / Name : 202 / 11 KV SADE NEW AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	2.4387
Max	2.4387
Min	2.4387
Avg	2.4387

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274106 / 33/11 KV SUBSTATION SADE (SO

S

Feeder No / Name : 203 / 11 KV GHOTI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	2.4387
Max	2.4387
Min	2.4387
Avg	2.4387

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274106 / 33/11 KV SUBSTATION SADE (SO

S

Feeder No / Name : 204 / 11 KV SOUNDE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	2.4387
Max	2.4387
Min	2.4387
Avg	2.4387

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274106 / 33/11 KV SUBSTATION SADE (SO

S

Feeder No / Name : 205 / 11 KV SADE OLD AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	2.4387
Max	2.4387
Min	2.4387
Avg	2.4387

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274106 / 33/11 KV SUBSTATION SADE (SO

S

Feeder No / Name : 206 / 11 KV PATHURDI AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	2.4387
Max	2.4387
Min	2.4387
Avg	2.4387

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274106 / 33/11 KV SUBSTATION SADE (SO

S

Feeder No / Name : 207 / 11 KV WARKATANE AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	2.4387
Max	2.4387
Min	2.4387
Avg	2.4387

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274145 / 33/11 KV SUBSTATION UMRAD

(SO

Feeder No / Name : 201 / 11 KV UMRAD-KUMBHEJ

GAOTHAN FEEDER

GAONTHAN Feeder KV- 11 /  
OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.0288	.4694	.4694	.463	.463	.463	.4801
Max	1.0288	.4694	.4694	.463	.463	.463	.4801
Min	1.0288	.4694	.4694	.463	.463	.463	.4801
Avg	1.0288	.4694	.4694	.463	.463	.463	.4801

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274145 / 33/11 KV SUBSTATION UMRAD

(SO

Feeder No / Name : 202 / 11 KV SOGAON-(E) AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
23		1.0395					
24	2.1338		.0838	.0838	.0838	.0838	.0838
Max	2.1338	1.0395	.0838	.0838	.0838	.0838	.0838
Min	2.1338	1.0395	.0838	.0838	.0838	.0838	.0838
Avg	2.1338	1.0395	.0838	.0838	.0838	.0838	.0838



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274145 / 33/11 KV SUBSTATION UMRAD

(SO

Feeder No / Name : 203 / 11 KV BHAIKAVNATH AG SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	2.4387	.0838	.0838	.0838	.0838	.0838	.0838
Max	2.4387	.0838	.0838	.0838	.0838	.0838	.0838
Min	2.4387	.0838	.0838	.0838	.0838	.0838	.0838
Avg	2.4387	.0838	.0838	.0838	.0838	.0838	.0838

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274145 / 33/11 KV SUBSTATION UMRAD

(SO

Feeder No / Name : 204 / 11 KV UMRAD AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
23		.0838					
24	2.4387		1.1736	1.0059	1.4251	1.6766	1.6766
Max	2.4387	.0838	1.1736	1.0059	1.4251	1.6766	1.6766
Min	2.4387	.0838	1.1736	1.0059	1.4251	1.6766	1.6766
Avg	2.4387	.0838	1.1736	1.0059	1.4251	1.6766	1.6766

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274145 / 33/11 KV SUBSTATION UMRAD

(SO

Feeder No / Name : 205 / 11 KV BHAIKAVNATH NEW AG FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	2.4387	.0503	.0503	.0503	.0503	.0503
Max	2.4387	.0503	.0503	.0503	.0503	.0503
Min	2.4387	.0503	.0503	.0503	.0503	.0503
Avg	2.4387	.0503	.0503	.0503	.0503	.0503

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274145 / 33/11 KV SUBSTATION UMRAD

(SO

Feeder No / Name : 206 / 11 KV SOGAON NEW AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	03-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
23		.0503			
24	2.4387		.0503	.0503	.0503
Max	2.4387	.0503	.0503	.0503	.0503
Min	2.4387	.0503	.0503	.0503	.0503
Avg	2.4387	.0503	.0503	.0503	.0503

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274145 / 33/11 KV SUBSTATION UMRAD

(SO

Feeder No / Name : 207 / 11 KV POPHALAJ-KUMBHEJ AG FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	2.4387	.0503	1.1736	1.0059	.9221	1.0059	.9221
Max	2.4387	.0503	1.1736	1.0059	.9221	1.0059	.9221
Min	2.4387	.0503	1.1736	1.0059	.9221	1.0059	.9221
Avg	2.4387	.0503	1.1736	1.0059	.9221	1.0059	.9221

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274159 / 33/11 KV SUBSTATION

KOLEGAON

Feeder No / Name : 201 / 11 KV KOLEGAON GAONTHAN

GAONTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	1.0174
Max	1.0174
Min	1.0174
Avg	1.0174

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274159 / 33/11 KV SUBSTATION

KOLEGAON

Feeder No / Name : 202 / 11 KV NIMGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	2.4387
Max	2.4387
Min	2.4387
Avg	2.4387

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274159 / 33/11 KV SUBSTATION

KOLEGAON

Feeder No / Name : 203 / 11 KV KOLEGAON AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	2.4387
Max	2.4387
Min	2.4387
Avg	2.4387



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274163 / 33/11 KV SUSTATION DAHIGAON

(S

Feeder No / Name : 202 / 11 KV Dahigaon AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Max	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Min	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Avg	.0857	.0857	.0857	.0857	.0857	.0857	.0857

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274163 / 33/11 KV SUSTATION DAHIGAON

(S

Feeder No / Name : 203 / 11 KV SHETPHAL AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.6289	.0857	.0857	.0857	.0857	.1372	.0857
Max	1.6289	.0857	.0857	.0857	.0857	.1372	.0857
Min	1.6289	.0857	.0857	.0857	.0857	.1372	.0857
Avg	1.6289	.0857	.0857	.0857	.0857	.1372	.0857

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274163 / 33/11 KV SUSTATION DAHIGAON

(S

Feeder No / Name : 204 / 11 KV WANGI-2 AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0857	2.7435	2.4006	2.2291	1.8861	2.572	2.1434
Max	.0857	2.7435	2.4006	2.2291	1.8861	2.572	2.1434
Min	.0857	2.7435	2.4006	2.2291	1.8861	2.572	2.1434
Avg	.0857	2.7435	2.4006	2.2291	1.8861	2.572	2.1434

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274179 / 33/11 KV SUBSTATION

KAVITGAON

Feeder No / Name : 202 / 11 KV YASHOBA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.3121		.3412		.0772		
7							.2058
12	2.8807	.1235	.1903		.0274	.132	.1355
23	.2555	.2418	.192	.1337	.0566	.2572	.2092
24	2.4387	.2589	.2418	.1955	.1389	.0566	.2572
Max	2.8807	.2589	.3412	.1955	.1389	.2572	.2572
Min	.2555	.1235	.1903	.1337	.0274	.0566	.1355
Avg	1.4718	.2081	.2413	.1646	.0750	.1486	.2019

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274179 / 33/11 KV SUBSTATION

KAVITGAON

Feeder No / Name : 203 / 11 KV KOLDHARA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.0549		1.9547		2.0062		
7							.048
12	.024	.0206	.0223		.0257	.0257	.0274
23	.048	1.8861	1.869	1.9719	2.0576	1.9204	1.749
24	2.4387	.048	1.8861	1.8861	1.9719	2.0405	1.9376
Max	2.4387	1.8861	1.9547	1.9719	2.0576	2.0405	1.9376
Min	.024	.0206	.0223	1.8861	.0257	.0257	.0274
Avg	.6414	.6516	1.4330	1.929	1.5154	1.3289	.9405

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274179 / 33/11 KV SUBSTATION

KAVITGAON

Feeder No / Name : 204 / 11 KV SANGAVI NO.2 AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	1.7833		.0377		.0394		
7							2.4348
12	.0274	2.0576	2.5034			2.5549	2.8464
23	1.8861	.0412	.0446	.0394	.0257	.0429	.036
24	2.4387	1.9204	.0394	.0446	.0377	.0257	.0412
Max	2.4387	2.0576	2.5034	.0446	.0394	2.5549	2.8464
Min	.0274	.0412	.0377	.0394	.0257	.0257	.036
Avg	1.5339	1.3397	.6563	.042	.0343	.8745	1.3396

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 278014 / 220KV JEUR

Feeder No / Name : 402 / 33 KV JEUR

Feeder KV- 33 / INCOMING

DATE	01-AUG-17
HR	Load (MW)
24	6.8587
Max	6.8587
Min	6.8587
Avg	6.8587

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 278014 / 220KV JEUR

Feeder No / Name : 403 / 33 KV CHIKALTHAN

Feeder KV- 33 / INCOMING

DATE	01-AUG-17
HR	Load (MW)
24	6.8587
Max	6.8587
Min	6.8587
Avg	6.8587



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 278014 / 220KV JEUR

Feeder No / Name : 404 / 33 KV WANGI

Feeder KV- 33 / INCOMING

DATE	01-AUG-17
HR	Load (MW)
24	6.8587
Max	6.8587
Min	6.8587
Avg	6.8587

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 278014 / 220KV JEUR

Feeder No / Name : 405 / 33 KV KANDHAR

Feeder KV- 33 / INCOMING

DATE	01-AUG-17
HR	Load (MW)
24	7.316
Max	7.316
Min	7.316
Avg	7.316

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 278014 / 220KV JEUR

Feeder No / Name : 407 / 33 KV UMRAD

Feeder KV- 33 / INCOMING

DATE	01-AUG-17
HR	Load (MW)
24	7.316
Max	7.316
Min	7.316
Avg	7.316

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 215 / DEVICHA MAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.4572	.4572	.4572	.381	.4572	.4572
2	.381	.4572	.4572	.4572	.381	.4572	.381
3	.4572	.5335	.4572	.4572	.381	.4572	.381
4	.4572	.5335	.4572	.4572	.5335	.5335	.4572
5	.5335	.5335	.5335	.4572	.6097	.5335	.5335
6	.6097	.6097	.5335	.5335	.7621	.5335	.6097
7	.6859	.6859	.6097	.5335	.6097	.5335	.6097
8	.6859	.4877	.6859	.5335	.8383	.5335	.6097
24	.3506	.5335	.4572	.4572	.381	.5335	.4572
Max	.6859	.6859	.6859	.5335	.8383	.5335	.6097
Min	.3048	.4572	.4572	.4572	.381	.4572	.381
Avg	.4962	.5369	.5165	.4826	.5419	.5081	.4996

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 216 / Bhavani Naka

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.7621	.7621	.9145	.3048	.3048	.3048
2	.6859	.7621	.7621	.9145	.3048	.3048	.3048
3	.6097	.8383	.6097	.9145	.3048	.3048	.2286
4	.6859	.8383	.6097	.9145	.381	.3048	.2286
5	.7621	.8078	.6859	.9145	.381	.2286	.3048
6	.7773	.6859	.7621	.9907	.2591	.2591	.2591
7	.9907	.9907	.9907	.9907	.3048	.3048	.3048
8	.9907	.9145	.9907	.884	.3048	.4572	.3506
24	.7621	.8383	.7621	.9145	.381	.3048	.3048
Max	.9907	.9907	.9907	.9907	.381	.4572	.3506
Min	.6097	.6859	.6097	.884	.2591	.2286	.2286
Avg	.7723	.8264	.7706	.9280	.3251	.3082	.2879

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 217 / Karmala Urban

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3048	.3048	.381
2			.3048	.3048	.381
3			.2591	.3048	.381
4			.2591	.3048	.381
5			.3048	.3048	.381
6			.5487	.381	.3963
7			.4572	.4572	.4572
8			.4725	.5335	.503
11		.3048			
23		.4572			
24	.7716		.4572	.381	.4572
Max	.7716	.4572	.5487	.5335	.503
Min	.7716	.3048	.2591	.3048	.381
Avg	.7716	.381	.3742	.3641	.4132

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 218 / 11 KV JEUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	1.4575
Max	1.4575
Min	1.4575
Avg	1.4575

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 220 / 11KV VEET AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.0762
Max	.0762
Min	.0762
Avg	.0762



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 221 / 11KV PANDE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.9431
Max	.9431
Min	.9431
Avg	.9431

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 222 / 11 KV SANGOBA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.7716
Max	.7716
Min	.7716
Avg	.7716

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 223 / 11 KV KARMALA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	1.5432
Max	1.5432
Min	1.5432
Avg	1.5432

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 224 / 11 KV MIDC KARMALA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0762	.0762	.0762	.0762	.0762
2	.0762	.0762	.0762	.0762	.0762	.0762	.0762
3	.0762	.0762	.0762	.0762	.0762	.0762	.0762
4	.0762	.0762	.0762	.0762	.0762	.0762	.0762
5	.0762	.0762	.0762	.0762	.0762	.0762	.0762
6	.0762	.0762	.0762	.0762	.0762	.0762	.0762
7	.0762	.0762	.0762	.0762	.0762	.0762	.0762
8	.0762	.0762	.0762	.0762	.0762	.0762	.0762
11						.0762	
23					.0762		
24	.7716	.0762	.0762	.0762	.0762	.0762	.0762
Max	.7716	.0762	.0762	.0762	.0762	.0762	.0762
Min	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Avg	.1535	.0762	.0762	.0762	.0762	.0762	.0762

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 225 / VITTHAL SUGAR FEEDER

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0762	.0762	.0762		.0762
2	.0762	.0762	.0762	.0762	.0762		.0762
3	.0762	.0762	.0762	.0762	.0762		.0762
4	.0762	.0762	.0762	.0762	.0762		.0762
5	.0762	.0762	.0762	.0762	.0762		.0762
6	.0762	.0762	.0762	.0762	.0762		.0762
7	.0762	.0762	.0762	.0762	.0762		.0762
8	.0762	.0762	.0762	.0762	.0762		.0762
24	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Max	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Min	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Avg	.0762	.0762	.0762	.0762	.0762	.0762	.0762

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274014 / 33/11 KV MANGI S/S

Feeder No / Name : 229 / 11 WADGAON/BOSE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.9526	.9335	.8573	1.0288	1.1431	1.0269
2	.0953	.9907	.9526	.8764	1.0669	1.2193	.9709
3	.0953	1.0288	.9907	.9145	1.105	1.2574	1.0082
4	.1143	1.0669	1.0479	.9526	1.1431	1.3336	1.0642
5	.1143	1.1431	1.1431	.9907	1.1812	1.4289	1.2136
6	.1143	1.1812	1.2384	1.0479	1.2384	1.5242	1.3817
7	.1334	1.3717	1.3336	1.1431	1.3908	1.6004	1.4563
8	.1143	1.3336	1.2955	1.2574	1.2765	1.5813	1.5684
9	1.467	.0934	.0953	.0953		.1143	.0934
10	1.6057	.0934	.0747	.0762		.1132	.0934
11	1.7177	.0934	.0754	.0762		.0943	.0934
12	1.6617	.0747	.0566	.0572		.0943	.0934
13	1.5684	.0747	.0572	.0762		.0943	.0747
14	1.4937	.0747	.0762	.0572		.0754	.0747
15	1.4937	.0747	.0572	.0572	.0762	.0934	.0934
16	1.251	.0747	.0572	.0572	.0762	.0747	.0934
17	.0934	.0747	.0762	.0762	.0762	.0747	.0934
18	.0747	.0934	.0762	.0943	.0953	.0934	.0747
19	.0934	.0934	.1143	.1132	.1143	.1307	.112
20	.0934	.1307	.1334	.132	.1334	.1307	.112
21	.1307	.112	.1334	.1334	.1334	.1307	.112
22	.1143	.0934	.1143	.1143	.1143	.112	.112
23	.8954	.8402	.8002	.9526	1.0479	1.0269	1.0642
24	.0953	.9145	.8962	.8383	.9907	1.086	1.0829
Max	1.7177	1.3717	1.3336	1.2574	1.3908	1.6004	1.5684
Min	.0747	.0747	.0566	.0572	.0762	.0747	.0747
Avg	.6136	.5031	.4929	.4603	.6827	.6095	.5485

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274014 / 33/11 KV MANGI S/S

Feeder No / Name : 230 / 11 KV MANGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.2401	1.4575	1.406	1.8861	2.2291	2.2291
2	.6859	.2572	1.7147	1.3717	2.0576	2.4863	2.0576
3	.6859	.3086	2.1434	1.4575	2.3148	2.6578	2.1434
4	.7716	.3429	2.4863	1.5432	2.6578	2.915	2.8292
5	.9431	.3772	2.7435	2.0576	2.8292	3.2579	2.915
6	1.1145	.4287	3.0007	2.3148	3.1722	3.6008	3.2065
7	1.2346	2.4348	3.2579	2.572	3.6351	3.9095	3.8237
8	1.0802	2.2634	3.2065	2.8464	.4287	3.6694	3.6694
9	3.0864	.463	.703	.6516	.6001	.9088	.8402
10	3.6523	.583	.823	.7202	.6859	1.0802	.9945
11	3.7209		.7545	.7545	.7716	1.0288	.9431
12	3.7551	.6344	.8059	.7545	.8059	1.0117	.9945
13		.8059	.7373	.7373	.8745	1.166	1.0631
14	2.9664	.7716	.7888	.7888	.9088	1.0974	1.0974
15	3.3951	.7545	.703	.8745	.8745	.9774	1.0802
16	3.6351	.823	.5144	.703	.9945	1.1145	1.1317
17	.1543	.1715	.0686	.2058	.1886	.2572	.2572
18	.2229	.1886	.1372	.2058	.2229	.2743	.2401
19	.2572	.2058	.2058	.2743	.3772	.3258	.2915
20	.2572	.2401	.3772	.2572	1.5089	.4115	.3086
21	.3429	.3086	.3429	.2915	.3601	.3721	.3086
22	.2743	.2915	.2743	.2915	.2915	.3601	.3086
23	.2572	1.286	1.3032	1.5775	1.9033	1.9719	1.6632
24	.6859	.2401	1.3717	1.3717	1.7147	2.0576	2.2977
Max	3.7551	2.4348	3.2579	2.8464	3.6351	3.9095	3.8237
Min	.1543	.1715	.0686	.2058	.1886	.2572	.2401
Avg	1.4724	.6270	1.2467	1.0845	1.3360	1.6309	1.5289

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274014 / 33/11 KV MANGI S/S

Feeder No / Name : 241 / 11KV GFSS Mangi

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.443	.5316	.2658	.3544	.3544	.443	.4961
2	.3544	.443	.3012	.3898	.3544	.443	.4252
3	.3544	.443	.3544	.443	.3898	.4784	.3721
4	.443	.5316	.443	.5316	.443	.5316	.4961
5	.5316	.6379	.5316	.5316	.4784	.5316	.6201
6	.6379	.6379	.6379	.6379	.5316	.6379	.8505
7	.6379	.7087	.7087	.7087	.6379	.7087	.7087
8	.5316	.5316	.6379		.5316	.6379	.6379
9	.3544	.5373	.6379		.6379	.7087	.7442
10	.2241	.5731		.6201	.7087	.7619	.7087
11	.1075		.6201	.4252	.6379	.6201	.7619
12	.2149	.4298	.5716	.3721	.6024	.5847	.691
13		.2328	.6024	.4252	.5316	.6379	.7087
14	.4294	.4477	.4075	.3189	.4252	.7087	.6733
15	.3761	.5373	.4961	.3189	.4075	.6447	.7619
16		.5014		.3721	.4961		.7973
17		.5014	.443	.443	.567	.8505	.8505
18		.6268	.5138	.4607	.6201	.8859	.567
19	.6268	.5014	.567	.691	.6379	.9391	.6733
20	.4477	.7164	.691	.7619	.7973	.9922	.7087
21	.8596	.6447	.6201	.7087	.8505	.9568	.5316
22	.7087	.4298	.5316	.6379	.7087	.7973	.4252
23	.5316	.2686	.443	.443	.5316	.7087	.3721
24	.443	.5316	.2686	.3544	.443	.5316	.567
Max	.8596	.7164	.7087	.7619	.8505	.9922	.8505
Min	.1075	.2328	.2658	.3189	.3544	.443	.3721
Avg	.4629	.5194	.5134	.4977	.5552	.6844	.6312



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274015 / 33/11 KV MANJARGAON S/S

Feeder No / Name : 232 / 11 KV MAJARGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.7716
Max	.7716
Min	.7716
Avg	.7716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274015 / 33/11 KV MANJARGAON S/S

Feeder No / Name : 233 / 11 KV UMRAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.7716
Max	.7716
Min	.7716
Avg	.7716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274015 / 33/11 KV MANJARGAON S/S

Feeder No / Name : 234 / 11 KV SANT DYNESHWAR AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.9431
Max	.9431
Min	.9431
Avg	.9431

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274015 / 33/11 KV MANJARGAON S/S

Feeder No / Name : 235 / 11KV MANJARGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.7716
Max	.7716
Min	.7716
Avg	.7716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093] BU 1376

Substation No/ Name :- 274016 / 33/11 KV PAREWADI S/S

Feeder No / Name : 235 / 11 KV KETTUR/PAREWADI POOL SEPARATED AG FEEDERS HAVING SPECIAL  
AG Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.7716
Max	.7716
Min	.7716
Avg	.7716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274016 / 33/11 KV PAREWADI S/S

Feeder No / Name : 237 / 11 KV RAJURI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.7716
Max	.7716
Min	.7716
Avg	.7716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274016 / 33/11 KV PAREWADI S/S

Feeder No / Name : 238 / 11 KV GFSS PAREWADI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.7716
Max	.7716
Min	.7716
Avg	.7716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274016 / 33/11 KV PAREWADI S/S

Feeder No / Name : 239 / 11 KV WASHIMBE /PAREWADI SEPARATED AG FEEDERS HAVING SPECIAL  
AG Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.9431
Max	.9431
Min	.9431
Avg	.9431



Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274016 / 33/11 KV PAREWADI S/S

Feeder No / Name : 240 / 11KV POMALWADI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.7716
Max	.7716
Min	.7716
Avg	.7716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274018 / 33/11 KV VEET S/S

Feeder No / Name : 244 / 11 KV KORTI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
23	.7716
Max	.7716
Min	.7716
Avg	.7716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274018 / 33/11 KV VEET S/S

Feeder No / Name : 245 / 11 KV VEET AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.7716
Max	.7716
Min	.7716
Avg	.7716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274018 / 33/11 KV VEET S/S

Feeder No / Name : 246 / 11 KV GFSS VEET

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.7716
Max	.7716
Min	.7716
Avg	.7716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274087 / 33/11 KV JINTI S/S

Feeder No / Name : 253 / 11 KV JINTI AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.5335	.4572	.5335	.6097	.4572	.4572
2	.6859	.6859	.4572	.6859	.6097	.4572	.4572
3	.8383	.8383	.6097	.7621	.6859	.6859	.6097
4	.9145	.9907	.8383	.8383	.8383	.7621	.7621
5	.9907	1.0669	.9145	.9907	.9907	.8383	.8383
6	1.0669	1.0669	1.0669	1.0669	1.0669	.9145	.9145
7	1.9814	.9907	.9145	.9145	.9907	.9907	.9907
8	2.21	.8383	.8383	.8383	.7621	.7621	.8383
9	2.2862	.6097	.8383		.5335	.5335	.6097
10	1.9814		.6097		.3048	.4572	.6097
11	1.9814		.3048				.3048
12	1.9814		.1524	.1524		.3048	.1524
13	1.9052		.1524	.1524		.3048	.1524
14	1.3717		.1524	.1524		.3048	.1524
15	.3048					2.0576	2.0576
16						2.1338	2.2862
17	.3048			1.0669		2.4387	2.4387
18	.4572	1.6766		1.1431		2.2862	2.5149
19	.5335	1.5242	1.5242	1.448		2.2862	2.3624
20	.6859	1.5242	1.448	1.3717	1.829	2.1338	1.9052
21	.6097	1.829	1.2955	1.2193	2.0576	1.829	1.5242
22	.5335	.8383	1.0669	1.1431	1.6766	1.3717	1.3717
23	.4572	.7621	.6859	.6097	.5335	.6097	.5335
24	.4572	.4572	.6097	.4572	.5335	.5335	.5335
Max	2.2862	1.829	1.5242	1.448	2.0576	2.4387	2.5149
Min	.3048	.4572	.1524	.1524	.3048	.3048	.1524
Avg	1.0901	1.0145	.7468	.8182	.9348	1.1067	1.0574

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274087 / 33/11 KV JINTI S/S

Feeder No / Name : 254 / 11 KV KATRAJ AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.9431
Max	.9431
Min	.9431
Avg	.9431

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274087 / 33/11 KV JINTI S/S

Feeder No / Name : 256 / 11 KV TAKALI AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.3048	.0762	.0762	.0762	.0762	.0762
2	.3048	.3048	.0762	.0762	.0762	.0762	.0762
3	.3048	.3048	.0762	.0762	.0762	.0762	.0762
4	.3048	.3048	.0762	.0762	.0762	.0762	.0762
5	.3048	.3048	.0762	.0762	.0762	.0762	.0762
6	.3048	.3048	.0762	.0762	.0762	.0762	.0762
7	.0762	.3048	.3048	.381	.3048	.381	.381
8	.0762	.3048	.381	.4572	.381	.381	.381
9	.0762	.3048	.381	.4572	.3048	.381	.4572
10	.0762		.381	.381	.3048	.381	.381
11	.0762	.3048	.381	.381			.5335
12			.4572	.3048		.4572	.5335
13	.0762		.4572	.3048		.4572	.5335
14	.0762		.4572	.3048		.381	.5335
15	.0762		.0762			.0762	
16	.0762		.0762	.0762		.0762	
17			.0762	.0762		.0762	.0762
18		.0762	.0762	.0762		.0762	.0762
19	.0762	.0762	.0762	.0762		.0762	.0762
20	.0762	.0762	.0762	.0762	.0762	.0762	.0762
21	.0762	.0762	.0762	.0762	.0762	.0762	.0762
22	.0762	.0762	.0762	.0762	.0762	.0762	.0762
23	.3048	.0762	.0762	.0762	.0762	.0762	.0762
24	.381	.3048	.0762	.0762	.0762	.0762	.0762
Max	.381	.3048	.4572	.4572	.381	.4572	.5335
Min	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Avg	.1705	.2241	.1842	.1789	.1422	.1756	.2182

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274087 / 33/11 KV JINTI S/S

Feeder No / Name : 257 / 11KV RAMWADI AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.9431
Max	.9431
Min	.9431
Avg	.9431



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274087 / 33/11 KV JINTI S/S

Feeder No / Name : 258 / 11KV NEMATWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.9431
Max	.9431
Min	.9431
Avg	.9431

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093] BU 1376

Substation No/ Name :- 274124 / 33/11 KV POTEGAON S/S

Feeder No / Name : 201 / 11 KV POTEGAON/TARATGAON SEPARATED AG FEEDERS HAVING SPECIAL  
AG Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.2193	.1524	.1524	.1524	.1524	.1524	.1524
16		1.2193	1.2193	1.2193	1.5242		1.5242
23	.1524	.1524	.1524	.1524	.1524	.1524	
24	.9431	.1524	.1524	.1524	.1524	.1524	.1524
Max	1.2193	1.2193	1.2193	1.2193	1.5242	.1524	1.5242
Min	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Avg	.7716	.4191	.4191	.4191	.4954	.1524	.6097

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274124 / 33/11 KV POTEGAON S/S

Feeder No / Name : 202 / 11KV Borgaon AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.1524	1.829	1.9814	1.829		2.2862	2.2862
23	.6097	.6097	.6097		.6097	.6097	.6097
24	.1524	.7621	.7621	.7621		1.0669	1.0669
Max	.6097	1.829	1.9814	1.829	.6097	2.2862	2.2862
Min	.1524	.6097	.6097	.7621	.6097	.6097	.6097
Avg	.3048	1.0669	1.1177	1.2956	.6097	1.3209	1.3209

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274124 / 33/11 KV POTEGAON S/S

Feeder No / Name : 203 / 11KV Ghargaon/ Padali AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.1524	1.0669	1.3717	1.2193	1.3717	1.2193	1.2193
16	1.3717	.1524					
23	.6097	.6097	.6097	.6097	.6097	.6097	.4572
24	.1524	.6097	.6097	.6097	.7621	.6097	.6097
Max	1.3717	1.0669	1.3717	1.2193	1.3717	1.2193	1.2193
Min	.1524	.1524	.6097	.6097	.6097	.6097	.4572
Avg	.5716	.6097	.8637	.8129	.9145	.8129	.7621

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274124 / 33/11 KV POTEGAON S/S

Feeder No / Name : 242 / 11KV GFSS Potegaon

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.9431
Max	.9431
Min	.9431
Avg	.9431

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274171 / 33/11 KV WASHIMBE S/S

Feeder No / Name : 201 / 11KV WASHIMBE/BHAIRVNATH SEPARATED AG FEEDERS HAVING SPECIAL  
AG Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1219	.1219	.1524	.2134	.1829	.3048
2	.1524	.1219	.1219		.1829	.1829	.3048
3	.1524	.1219	.1219	.1524	.1829	.2743	.3048
4	.1524	.1219	.1219		.1829	.2134	.3048
5	.1524	.1219	.1219	.1829	.1829	.2134	.2743
6	.8383	.1524	.1372	.1981	.1829	.1829	.3048
7	.9297						
8	.9602						
9	.945						
10	.9145						
11	.9145						
12	.884						
13			1.0669	.8535	.8535	.884	.8383
14			.8535	.9145	1.0669	.9145	.884
15			.9145	1.1431	1.0974	.9145	.884
16			.9145	1.1584	1.0974	.945	.884
17			.945	1.0974	.8535	.945	.884
18		.7621	.9907	1.0974	.8535	.945	.8535
19		.7316	.945	1.0669	.9145	.9145	.8383
20	.1219	.1372	.1372	.1219	.1524	.2743	.3048
21	.1219	.1372	.1524	.1524	.1829	.3048	.3048
22	.1219	.1219	.1677	.1524	.2134	.3048	.3048
23	.1067	.1219	.1829	.1829	.2134	.3048	.2743
24	.1524	.1067	.1219	.1829	.2134	.2134	.3048
Max	.9602	.7621	1.0669	1.1584	1.0974	.945	.884
Min	.1067	.1067	.1219	.1219	.1524	.1829	.2743
Avg	.4572	.2216	.4522	.5506	.4911	.5064	.5199

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274171 / 33/11 KV WASHIMBE S/S

Feeder No / Name : 202 / 11KV Goyegaon AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.1829	.1524	.2286	.2743		.2286
2	.2896	.1829	.1524		.2439		.2286
3	.2743	.1524	.1524	.2134			.2286
4	.2743	.1524	.1524	.2134	.2439		.2439
5	.2743	.1524	.1829	.2286	.2134		.2743
6	.3048	2.1338	2.0424	2.1338	2.1338		2.7435
7		2.1643	2.1186	1.829	2.1948		2.8197
8		2.2862	2.1643	2.2405		2.5149	3.0483
9		2.21		2.332		2.8807	3.0331
10		2.1491	2.1033	2.3777		3.0178	3.0178
11		2.1186		2.3777		3.155	2.9111
12			2.332	2.3777		3.1398	2.8654
14	2.5453						
15	2.5911						
16	2.4996						
17	2.332						
18	2.2558						
19	2.1795						
20	.1829	.1829	.1524			.2439	.2439
21	.1829	.1829	.2134			.2439	.2743
22	.1829	.1524	.2134			.2286	.2743
23	.1829	.1524	.2286			.2286	.2439
24	.7716	.1829	.1524	.2286	.2743		.2286
Max	2.5911	2.2862	2.332	2.3777	2.1948	3.155	3.0483
Min	.1829	.1524	.1524	.2134	.2134	.2286	.2286
Avg	1.0370	.9212	.8342	1.3984	.7969	1.7392	1.3475

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274171 / 33/11 KV WASHIMBE S/S

Feeder No / Name : 203 / 11KV WASHIMBE /NANGI AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.7716
Max	.7716
Min	.7716
Avg	.7716



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274171 / 33/11 KV WASHIMBE S/S

Feeder No / Name : 204 / 11kv Jyotiba Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1219	.1829	.1829	.2286	.2286
2		.1219	.1829	.2134	.2439	.1829
3		.1219	.1829	.1829	.2743	.1524
4		.1219	.1981	.1829	.2743	.1524
5		.1524	.2134	.1829	.2743	.1524
6		.1524			.2743	.1524
7			.2439			
13		2.0424	2.1338	1.89	2.0881	2.21
14		2.3624	2.1643	2.1338	2.1033	2.2558
15		2.1338	2.1338	2.1643	2.1338	2.2405
16		2.1643	2.1491	2.1643	2.21	2.2558
17		2.1948	2.1491	2.0119	2.21	2.21
18		2.1338	2.1643	2.0119	2.21	2.1643
19			1.9814	2.0424	2.1643	2.1643
20		.1219		.1524	.1829	.2743
21		.1372		.2439	.2439	.3048
22		.1372		.2439	.2439	.3048
23		.1524		.2286	.2439	.2743
24	.1372	.1219	.1677	.1829	.2286	.2286
Max	.1372	2.3624	2.1643	2.1643	2.21	2.2558
Min	.1372	.1219	.1677	.1524	.1829	.1524
Avg	.1372	.8526	1.1605	.9656	.9907	.9949

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274171 / 33/11 KV WASHIMBE S/S

Feeder No / Name : 205 / 11kv Washimbe gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1219	.1677	.2134	.1829	.1067
2		.1219	.1829	.2134	.1981	.0914
3		.1219	.1829	.2439	.2134	.0914
4		.1524		.2743	.2439	.0914
5		.2286	.2134	.2743	.2743	.1219
6		.2286	.2439	.2743	.2743	.1524
7		.2134	.2743	.2743	.2743	.1524
8		.1677	.2439	.2134	.2743	.0914
9		.1524	.2439	.2134	.2439	.1067
10		.1524	.2439	.2134	.2439	.1067
11		.1524	.2134	.1829	.1219	.0914
12		.1372	.2134	.1829	.0914	.061
13		.1372	.2134	.1372	.0762	.0914
14		.1372	.1829	.1372	.0762	.0914
15		.1219	.2134	.1524	.0762	.0914
16		.1219		.1829	.0762	.1067
17		.1372	.2134	.1524	.0762	.1372
18		.1219	.2439	.1372	.0914	.2743
19		.1829	.2134	.1677	.1219	.2134
20		.2134	.2134	.1829	.1219	.2439
21		.1981	.2439	.2134	.1219	.2286
22		.1829	.2439	.2134	.1219	.1829
23		.1677	.2134	.1829	.1067	.1677
24	.1219	.1219	.1524	.2134	.1829	.1067
Max	.1219	.2286	.2743	.2743	.2743	.2743
Min	.1219	.1219	.1524	.1372	.0762	.061
Avg	.1219	.1581	.2169	.2020	.1619	.1334

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274195 / 33/11KV PANDE S/STN

Feeder No / Name : 201 / 11KV PANDE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.061	.5487	.381
2	.061	.5335	.3658
3	.061	.5335	.3658
4	.0762	.5792	.442
5	.0914	.7011	.4725
6	.1219	.6401	.7468
7	.0914	1.2041	1.0974
8	.061	1.0974	1.1126
9	.7773	.1067	.0914
10	.884	.0914	.0762
11	.7926	.0914	.061
12		.0762	.0762
13	1.326	.0914	.0762
14	1.387	.0762	.061
15	1.5089	.0457	.061
16	1.6309	.0914	
17	.0914	.0914	.0762
18	.1067	.1219	.1067
19	.1372	.1524	.1372
20	.1524	.1677	.1677
21	.1372	.1677	.1372
22	.1219	.1372	.1219
23	.5335	.3658	.442
24	.7716	.5792	.3963
Max	1.6309	1.2041	1.1126
Min	.061	.0457	.061
Avg	.4775	.3455	.3075

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274210 / 33/11 KV JATEGAON SUB

STATION

Feeder No / Name : 201 / JATEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
1	.1054
24	.1204
Max	.1204
Min	.1054
Avg	.1129

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274210 / 33/11 KV JATEGAON SUB

STATION

Feeder No / Name : 202 / WADGAON AG FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL

DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
1	1.386
24	1.3321
<b>Max</b>	<b>1.386</b>
<b>Min</b>	<b>1.3321</b>
<b>Avg</b>	<b>1.3591</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274210 / 33/11 KV JATEGAON SUB

STATION

Feeder No / Name : 203 / KHADAKI AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
1	.1027
24	.1189
<b>Max</b>	<b>.1189</b>
<b>Min</b>	<b>.1027</b>
<b>Avg</b>	<b>.1108</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274211 / HINGANI SUB STATION

Feeder No / Name : 201 / 11KV GULMOHARWADI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2256	.1768	.0046	.003	.0061	.0076	.0061
2	.2088	.1753	.003	.0061	.0061	.0076	.0061
3	.2012	.1738	.003	.0061	.0061	.0076	.0061
4	.1981	.1722	.003	.0061	.0061	.0091	.0061
5	.1951	.1707	.003	.0061	.0076	.0091	.0076
6	.0076	.0107	.003	.0061	.0076	.0107	.0122
7	.0091	.0122	.0046	.0061	.0076	.0122	.0122
8	.0137	.0091	.0046	.0046	.0076	.0122	
9	.0122	.0091	.003	.0046	.0076	.0122	.0061
10	.0137	.0091	.003	.003		.0091	.0061
11	.0122	.0091	.003			.0076	.0061
12	.0152		.003	.0061	.0091	.0076	.0061
13	.0137		.003	.0061	.0061	.0091	.0061
14	.0152		.003	.0061	.0076	.0091	.0076
15	.0168		.003	.0061	.0076	.0091	.0061
16	.0046		.1433	.2241	.2591	.2591	.2347
17	.0061		.1494	.2317	.2591	.2561	.2362
18	.0076				.2591	.253	.2378
19	.0122	.1433	.1616	.2393	.2561	.2515	.2378
20	.0137	.1433	.1646	.2301	.2408	.2362	.2317
21	.1814	.1402	.1616	.2286	.2134	.2286	.2134
22	.0091	.1402	.1616	.2256	.2195	.221	.2073
23	.1814	.003	.003	.0061	.0076	.0061	.0091
24	.7716	.1783	.0046	.003	.0061	.0076	.0061
Max	.7716	.1783	.1646	.2393	.2591	.2591	.2378
Min	.0046	.003	.003	.003	.0061	.0061	.0061
Avg	.0977	.0986	.0435	.0666	.0824	.0775	.0746

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274211 / HINGANI SUB STATION

Feeder No / Name : 202 / 11 KV MAKAI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1494	.1661	.1692	.1951	.1981
2			.1524	.1646	.1707	.192	.1981
3			.1524	.1646	.16	.189	.1905
4			.1463	.1585	.1646	.189	.192
5			.1433	.1585	.1616	.1829	.1905
6	.2256						
7	.2317						
8	.2393						
9	.2469						
10	.2439						
11	.2545						
12	.2378						
23		.1372	.1646	.1753	.192	.2134	.189
24	.7716		.1433	.1646	.1722	.192	.2119
Max	.7716	.1372	.1646	.1753	.192	.2134	.2119
Min	.2256	.1372	.1433	.1585	.16	.1829	.189
Avg	.3064	.1372	.1502	.1646	.1700	.1933	.1957



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274211 / HINGANI SUB STATION

Feeder No / Name : 203 / 11 KV HINGANI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0046	.0046	.0046	.0046	.0046	.0046
2		.0046	.003	.0061	.0046	.0046	.0046
3		.0046	.003	.0061	.0046	.0046	.0046
4		.0061	.003	.0061	.0046	.0061	.0046
5		.0061	.003	.0061	.0061	.0061	.0061
6		.1494	.1494	.1524	.1448	.1799	.2073
7		.1524	.1524	.1524	.1631	.189	.2256
8		.1539	.1799	.1677	.1829	.1951	
9		.1494	.1829	.1677	.192	.2012	.2042
10		.1494	.1829	.1677	.1859	.2012	.2012
11		.1494	.1738	.1524	.1799	.2012	.2042
12			.1738	.1524	.1799	.1981	.1981
13	.003		.0046	.003	.0046	.0046	.0076
14	.003		.003	.003	.0046		.0046
15	.0046		.003	.003	.0046		.0046
16	.1829		.0046	.003	.0046		.0046
17	.1753		.0046	.003	.0046	.0046	.0046
18	.1646	.0046	.003	.0046	.0046	.0061	.0046
19	.1585	.0046	.0061	.003	.0061	.0061	.0061
20	.1509	.0046	.0046	.003	.0061	.0061	.0061
21	.1433	.0061	.0061	.003	.0046	.0061	.0061
22	.1372	.0061	.0061	.003	.0061	.0061	.0061
23	.0046	.0061	.0061	.003	.0046	.0046	.0061
24	.7716	.0046	.0061	.0046	.0046	.0046	.0061
Max	.7716	.1539	.1829	.1677	.192	.2012	.2256
Min	.003	.0046	.003	.003	.0046	.0046	.0046
Avg	.1583	.0537	.0529	.0492	.0547	.0686	.0579

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274212 / 33/11Kv Korti Substation

Feeder No / Name : 201 / 11 KV RAJURI AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.9393	.2591	.3222	.3391	.2267	.2591	.3239
8	1.3441	.3077	.3222	.373	.3239	.3401	.3725
12	.1457		.7727		1.0364	1.166	
16	.1296		.6097	.7935	.8907	1.0526	.7773
18		.2058					
19			.2401				
20	.3239	.3222		.2591	.3239	.2429	.3563
22			.2058				
23	.2267			.1781	.1943	.2267	.2267
24	.5937	.1943	.1772	.1886	.1619	.1943	.2267
<b>Max</b>	<b>1.3441</b>	<b>.3222</b>	<b>.7727</b>	<b>.7935</b>	<b>1.0364</b>	<b>1.166</b>	<b>.7773</b>
<b>Min</b>	<b>.1296</b>	<b>.1943</b>	<b>.1772</b>	<b>.1781</b>	<b>.1619</b>	<b>.1943</b>	<b>.2267</b>
<b>Avg</b>	<b>.529</b>	<b>.2578</b>	<b>.3786</b>	<b>.3552</b>	<b>.4511</b>	<b>.4974</b>	<b>.3806</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274212 / 33/11kv Korti Substation

Feeder No / Name : 202 / 11KV KORTI GAOTHAN

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.1017	.0895	.1254	.0983	.081	.1134
8	.0972	.1017	.1075	.1075	.1187	.1296	.1296
12			.0895		.0648	.0848	
16	.1017		.0895	.0972	.081	.081	.0972
18		.124					
20		.1402	.1753	.081	.1296	.1134	.1296
23	.0848			.1017	.081	.0972	.081
24	.0895	.0848	.0895	.0716	.0848	.081	.0972
Max	.1017	.1402	.1753	.1254	.1296	.1296	.1296
Min	.0848	.0848	.0895	.0716	.0648	.081	.081
Avg	.0933	.1105	.1068	.0974	.0940	.0954	.108

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274212 / 33/11kv Korti Substation

Feeder No / Name : 203 / 11 KV GOREWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.1943	.4534	.8768	.7316	1.0688	.8745	1.1822
8	.2915	.4858	.9659	1.0856	1.0202	.8745	1.4575
12			.1075		.0972	.1296	
14	1.4251						
16	1.1012		.0716	.1134	.1457	.1619	.1619
20	.1619		.1578	.1457	.1943	.1619	.2267
23	.3563			.4858	.5182	.6964	.6154
24	.1734	.3563	.3906	.4374	.5506	.583	.7773
Max	1.4251	.4858	.9659	1.0856	1.0688	.8745	1.4575
Min	.1619	.3563	.0716	.1134	.0972	.1296	.1619
Avg	.5291	.4318	.4284	.4999	.5136	.4974	.7368

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274218 / 33/11 KV KATRAJ SUBSTATION

Feeder No / Name : 201 / 11KV KATRAJ SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.7716
Max	.7716
Min	.7716
Avg	.7716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274218 / 33/11 KV KATRAJ SUBSTATION

Feeder No / Name : 202 / 11 KV TAKALI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.7716
Max	.7716
Min	.7716
Avg	.7716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274218 / 33/11 KV KATRAJ SUBSTATION

Feeder No / Name : 203 / 11 KV KHATGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.7716
Max	.7716
Min	.7716
Avg	.7716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274220 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 201 / 11KV ZARE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3982	.4252	.4252	.4031	.3988	.407	.4294
2	.4298	.4115	.4031	.4252	.4115	.4119	.4251
3	.4075	.4024	.3944	.4119	.3988	.4344	.4481
4	.4207	.3658	.4024	.3982	.4115	.4207	.4435
5	.39	.3246	.3887	.4207	.4252	.4435	.4527
6	.4161	.3841	.3932	.4435	.4298	.4338	.4668
7	.3944	.3978	.3978	.3944	.4031	.4481	.462
8	.5895	.3978	.3932		.4161	.4251	.4525
9	.4382	.373	.3812	.4161	.3647	.4938	.5975
10	.3384	.3637	.4024	.4161	.3856	.5975	.7947
11	.3418		.3768	.4207	.407	.7207	.8413
12	.3227		.3978	.4115	.4031	.7655	.8686
13	.3567	.3361		.373	.4252	.8215	.8589
14	.3521	.4115		.4287	.4119	.7023	.924
15	.3286	.3988	.3856	.4207	.4075	.8029	.9149
16		.443	.407		.4207	.8131	.8596
17			.3944	.415	.3988	.4163	.439
18	.3479		.3814	.4294	.3856	.4251	.4163
19	.3521	.4298	.4031	.4435	.4075	.4435	.4298
20	.4481	.4252	.4252	.439	.4298	.4527	
21	.4435	.4298	.3944	.4481	.4163	.4251	.4525
22	.4481	.4163	.4207	.4207	.439	.4207	.439
23	.4435	.4207	.4075	.4344	.4435	.4435	.4207
24	.7716	.4344	.4298	.4161	.4207	.3944	.4251
Max	.7716	.443	.4298	.4481	.4435	.8215	.924
Min	.3227	.3246	.3768	.373	.3647	.3944	.4163
Avg	.4173	.3996	.4002	.4195	.4109	.5235	.5766



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274220 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 202 / 11 KV KHADKEWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.443	1.8233	.7011	2.1735	.8145	2.5415	2.8349
2	.4908	1.6766	.7888	2.2148	.8596	2.8349	2.8395
3	.5028	1.8138	.8328	2.3282	.905	2.6244	2.6791
4	.5144	1.8884	.8238	2.3148	.9511	2.9569	2.6871
5	.6104	1.9608	.823	2.3838	.8871	2.9874	2.7206
6	.6203	2.4006	.8962	2.4806	1.0269	3.3951	2.9504
7	.6588	2.9165	.8413	2.7694	2.7759	2.9504	.8139
8	.5609	2.915	.7023		3.2579	2.4863	.5197
9	1.4175	.3772	.3658	.4252	.4108	.4887	.4904
10	.4338	.2629	.3326	.2629	.4251	.4527	.4435
11				.2401	.4024	.3584	.4207
12	2.3758			.2279	.4344	.4527	.3982
13		.2204		.2195	2.652	.4527	.4119
14		.2401		.2801	.3326	.4527	.3982
15		.208	1.4937	.2561	.3547	.3772	.3921
16		.2204	1.3203	.2561	.3582	.3921	.3772
17			.3429	.2481	.3601	.3326	.4066
18	.2267		.3681	.3982	.3856	.3982	.4525
19	.415	.3898	.3544	.439	.4075	.4938	.5304
20	.5415	.4887	.3801	.4344	.4477	.5601	
21	.4481	.4525	.4207	.4755	.3801	.462	.462
22	.3881	.439	.4805	.543	.3658	.4572	.4525
23	1.6832	.7762	.5601	.6335	.3696	2.8959	3.0178
24	.7716	1.6956	.823	2.1325	.7682	2.4863	2.8833
Max	2.3758	2.9165	1.4937	2.7694	3.2579	3.3951	3.0178
Min	.2267	.208	.3326	.2195	.3326	.3326	.3772
Avg	.7279	1.1583	.6826	1.0494	.8472	1.4288	1.2862

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274220 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 203 / 11KV ZARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1578	.124	.1417	.1417	.1417	.1326	.1433
2	.1357	.1402	.12	.1372	.1372	.1147	.1417
3	.1663	.1492	.1509	.1526	.116	.1134	.1543
4	.1646	.1619	.1865	.1341	.1696	.128	.1543
5	.1629	.1524	.1966	.1595	.208	.1372	.1509
6	.1433	.1718	.1989	.1227	.2481	.1402	.1696
7	.1629	.144	.1696	.1387	.2172	.1595	.1326
8	.1791	.1457	.1402		.1867	.1433	.1311
9	.1629	.1326	.12	.1227	.1848	.1448	.1448
10	.1372	.1174	.104	.1372	.168	.128	.1254
11	.112		.1357	.156	.1698	.1663	.1063
12	.0924		.1174		.1663	.168	.0895
13	.0566	.1543			.1494	.1646	.0886
14	.0716	.1254			.1478	.1663	.1086
15	.0983	.1448	.1372		.1595	.168	.1463
16		.1097	.1214		.1433	.1478	.181
17				.2103	.12	.1494	.1829
18			.1578	.2126	.1357	.1478	.181
19		.181	.1417	.2534	.1543	.1478	
20	.2126	.2149	.1629	.2743	.1402	.1595	.2303
21	.1753	.1991	.128	.2561	.1267	.1791	.2303
22	.1595	.2195	.1478	.2172	.1463	.1629	.181
23	.1402	.1848	.168	.1829	.1478	.1663	.1646
24	.7716	.1478	.1646	.1629	.1629	.1509	.1448
Max	.7716	.2195	.1989	.2743	.2481	.1791	.2303
Min	.0566	.1097	.104	.1227	.116	.1134	.0886
Avg	.1731	.1560	.1481	.1762	.1603	.1494	.1514

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 277019 / 132KV PAREWADI

Feeder No / Name : 401 / 33KV MAKAI

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
23	2.3148
Max	2.3148
Min	2.3148
Avg	2.3148

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274024 / MAHISGAON S/STN

Feeder No / Name : 201 / RIDHORE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5359	.7655		.2801	.5847		.5914
2	.5487	.7655	.6908	.2587	.5601		.5601
3	.5975	.7922	.7167	.2926	.6161	.5601	.4805
4	.5729	.811	.7167	.2715	.5729	.1188	.5041
5	.6161	.7922	.8402	.3109	.6161	.1188	.5415
6	.6468	.8488	.9522	.3326	.6036	.1358	.5788
7	.6722			.3109	.5415	.1698	.6722
8	.5914	.8402	.8775	.3511	.6348	.1698	
9	.5729	.9709	1.2826	.3511	.9242	.9709	
10	.6348	1.226	1.2883	.4481	.9808	.8215	
11		1.251	1.475	.4668	.8775	.6241	
12	.6653	.7023	1.5339	.165	.8215	.5729	
13	.7842	1.0456	1.0082	.1155	.8962	.5975	
14	.7842	1.1016	1.0719	.165	.7947	.4755	
15	.7577	.9896	.6089	.443	.3658	.5175	
16	2.5396	3.0996		1.8842	1.9227	2.0972	.5914
17	2.4741	3.3482		1.9433	1.8623	2.0885	.9149
18		2.8012	1.3763	1.9498	2.1792	1.7444	.9896
19	3.0498	.4477	1.8298	2.0481	1.8233	1.9334	1.0269
20	.5973	.9242		1.8896	1.989	2.0056	1.0269
21	.7655	.9709		1.6842	1.9559	1.8842	.9054
22	.8029	1.0829	1.5181	1.6644	1.8623		.5373
23	.7655		.2614	.5658	.7167		1.6032
24	.5415	.7842		.2587	.5847	.1698	.679
Max	3.0498	3.3482	1.8298	2.0481	2.1792	2.0972	1.6032
Min	.5359	.4477	.2614	.1155	.3658	.1188	.4805
Avg	.9326	1.1982	1.0617	.7688	1.0536	.8888	.7627

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274024 / MAHISGAON S/STN

Feeder No / Name : 202 / GFSS MAISGOAN  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4477	.4887	.4344	.4207	.4525	.4706	.5175
2	.543	.499	.4344	.4525	.4938	.4706	.5249
3	.6767	.5544	.4477	.5175	.6219	.4706	.5487
4	.7023	.6036	.4938	.6036	.7282	.5121	.5729
5	.7207	.6908	.6468	.6722	.7947	.7316	.7865
6	.924	.9335	.8962	.6722	.9335	.9425	.9795
7	.924	.8501	.924	.8402	.924	.961	.924
8	.7865	.7133	.695	.6535	.823	.7682	.6584
9	.5973	.591	.6556	.5487	.7164	.7783	.6283
10	.4681	.5083	.567	.4706	.5847	.6268	.567
11		.4578	.5028	.216	.5144	.3326	.6516
12	.4239	.4024	.5426	.333	.4748	.3429	.5552
13	.3521	.4359	.5138	.3681	.4694	.3561	.5258
14	.407	.4191	.4372	.3391	.4424	.285	.5316
15	.4641	.4458	.4694	.3121	.4458	.373	.5083
16	.4239	.4115		.3856	.4973	.3601	.4527
17	.4334		.3544		.4458	.4119	.4681
18			.4119	.4784	.5028	.3721	.4908
19	.6697	.724	.5487	.6626	.7059	.5792	.6154
20	.8326	.8779	.6468	.8596	.8962	.7682	.7421
21	.6984	.6516	.5415	.7133	.6697	.6584	.5973
22	.5552	.5373	.4525	.5487	.5611		.4835
23	.4887	.5121	.4207	.4572	.4887		.4525
24	.4656	.4706	.4344	.3982	.4344	.4525	.5249
Max	.924	.9335	.924	.8596	.9335	.961	.9795
Min	.3521	.4024	.3544	.216	.4344	.285	.4525
Avg	.5911	.5809	.5422	.5184	.6092	.5466	.5961

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274024 / MAHISGAON S/STN

Feeder No / Name : 203 / MAHISGAON AG SEPERATED SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1822	2.8012	2.7161	.434	2.4531	2.7831	2.5526
2	2.2245	2.8166	2.6189	.4534	2.4413	2.8502	2.364
3	2.2348	2.8166	2.6155	.4733	2.4697	2.8502	2.3975
4	2.2119	2.8012	2.536	.4851	2.536	2.8334	2.4143
5	2.2283	2.1382	2.5316	.5182	2.5819	2.5758	2.4366
6	2.0729	2.5194	2.4981	.5361	2.6322	2.8166	2.5692
7	2.3102	2.6355	2.5484	.5325	2.4905	2.7999	2.6825
8	1.4022	1.5497	1.3117	.9976	1.5699	1.4901	2.5857
9	1.4901	1.713	1.7071	1.0997	1.6975	1.7497	2.8166
10	1.5202	1.7747	1.8244	1.0235	1.6766	1.8056	2.7664
11	1.5895	1.821	1.8278	1.0517	1.713	1.4998	2.8166
12	1.6049	1.4632	1.8827	1.0974	1.5546	1.6461	2.9508
13	1.6004	1.5503	1.8663	1.5546	1.7158	1.7008	2.8178
14	1.448	1.5009	1.8278	1.5804	1.6651	1.5813	2.6686
15	1.4784	1.5741	1.6406	1.5741	1.5455	1.7284	2.5316
16	.4601		1.6406	.5761	.7287	.5365	1.1294
17	.4338		.415		.7093	.6358	1.4969
18	.5182		.4868	.5898	.7472	.3048	1.5202
19		.4329	.4934	.6268	.6716	.3887	1.5653
20	.5053	.4938	.5005	.6455	.6895	.5498	1.448
21	.4527	.4134	.4668	.6144	.6287	.5213	1.3672
22	.3963	.2789	.4016	.5075	.598	.5411	1.2163
23	2.4697	2.7808	.3944	1.9006	2.6993	2.3045	.5498
24	2.2283	2.8012	2.7328	.4146	2.4366	2.7664	2.5652
Max	2.4697	2.8166	2.7328	1.9006	2.6993	2.8502	2.9508
Min	.3963	.2789	.3944	.4146	.598	.3048	.5498
Avg	1.5245	1.8417	1.6452	.8386	1.6938	1.7192	2.1762

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274024 / MAHISGAON S/STN

Feeder No / Name : 403 / Vitthal Corporation  
(Textile & Feeder KV- 33 /  
OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6818	2.7343	2.9321	2.3137	2.9447	3.1276	2.7343
2	2.7641	2.8172	2.8475	2.4177	2.9973	3.2156	2.5252
3	2.6863	2.7641	3.0178	2.4983	3.0298	3.1276	2.524
4	2.7109	2.7343	2.9321	2.6863	2.9767	3.2156	2.6046
5	2.9447	2.7109	3.0178	2.6526	2.9447	3.1276	3.2236
6	2.8086	2.8172	2.9321	2.8395	3.1161	3.1276	2.7109
7	2.8395	2.6292	2.6006	2.6578	2.955	2.6006	2.8395
8	2.7641	2.7869	3.0407	2.7401	2.8704	2.8475	2.7109
9	2.524	2.9767	2.9321	2.7109	2.4451	3.3265	2.955
10	2.4983	2.7869	2.7938	2.8475	2.6006	2.5789	2.7869
11	2.9012	2.7046	2.8395	2.9012	2.7641	3.0298	2.524
12	2.7869	2.7046	2.7109	2.6526	2.8475	2.8921	2.8704
13	2.9767	2.8704	2.7343	2.7869	2.2634	2.7109	2.7109
14	2.8395	2.7869	2.8607	2.6818	2.6006	2.2028	2.7343
15	2.8395	2.5206	2.5766	2.8172	2.6006	2.8172	2.7343
16	2.9447	2.3663	2.7109	2.8921	3.1276	2.6292	2.7938
17	2.9767	3.0727	2.6818	2.7869	2.7641	2.6578	2.8475
18	2.7641	2.4691	2.9235	2.6578	2.8475	2.7343	2.9235
19	2.8395	2.7046	2.7869	2.9767	3.1276	2.8172	2.9235
20	2.6818	2.7046		3.0498	2.8475	2.8921	2.9973
21	2.7938	3.0624	2.7343	2.7343	2.9321	2.8704	2.6818
22	2.7938	2.8704	2.9235	2.9235	2.9321	2.9321	2.8475
23	2.9767	3.1276	2.2611	2.8704	3.0178	3.0298	2.7938
24	2.8475	2.7869	2.9321	2.4966	3.0624	3.0727	2.8172
Max	2.9767	3.1276	3.0407	3.0498	3.1276	3.3265	3.2236
Min	2.4983	2.3663	2.2611	2.3137	2.2634	2.2028	2.524
Avg	2.7994	2.7712	2.8140	2.7330	2.8590	2.8993	2.7839

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274101 / KAVE

Feeder No / Name : 201 / ROPALE AG FDR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.1715	.1457	.1886	.1619
2		.1715	.1715	.1457	.2058	.1619
3		.1715	.1715	.1457	.2229	.1781
4		.1715	.2572	.1619	.2401	.1943
5		.2229	.2915	.1781	.2572	.2105
6		.3258	.3086	.2105	.2915	.2915
7		.2915		.2915	.3086	.3239
8		.2401		.2591	.2058	.3077
9			.1543	.1943	.0857	.2429
10		.1715	.1543	.1457	.1372	.1943
11		.1715	.12	.1296	.1029	.1619
12		.1715	.12	.0972	.12	.1781
13		.1715	.12	.1134	.1715	.1619
14		.1715	.1372	.0972	.0857	.1781
15		2.3015	2.21	2.572		2.8464
16		2.4539	2.4539	2.572		3.0007
17		1.9357	2.4691	2.6578	2.652	
18		1.8595		2.5892	2.3624	2.1776
19		1.9357	2.21	2.6063	2.6063	2.4006
20		1.5699	1.8747	2.572	2.271	2.2634
21		1.4632	1.7071	2.1091	2.1948	2.0919
22			1.5851	1.7833	2.0576	1.7318
23			.1543	.2105	.1886	.2429
24	1.0364	.1829	.1715	.1619	.1886	.1619
Max	1.0364	2.4539	2.4691	2.6578	2.652	3.0007
Min	1.0364	.1715	.12	.0972	.0857	.1619
Avg	1.0364	.7774	.8102	.9229	.7793	.8637



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274101 / KAVE

Feeder No / Name : 202 / BITERGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	1.0059
Max	1.0059
Min	1.0059
Avg	1.0059

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274101 / KAVE

Feeder No / Name : 203 / NADI AG FDR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	1.0059
Max	1.0059
Min	1.0059
Avg	1.0059

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274101 / KAVE

Feeder No / Name : 204 / CANAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	03-AUG-17	04-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.7435	3.4122	3.2007	3.3951
2		2.7435	3.3265	3.2007	3.3436
3		2.7435	3.3265	3.2769	3.3608
4		2.774	3.2407	3.2007	3.3436
5		2.8045	3.3608	3.2007	3.4122
6		2.8045	3.2236	2.6673	3.2579
7			.2105	.1886	.1781
8			.1619	.2058	.1943
9		.1372	.1781	.1372	.2267
10			.1296	.1372	.1619
11		.0857	.1134	.1029	.1134
12		.0857		.0857	.1457
13		.0686	.1296	.12	.1457
14			.1296	.1372	.1619
15			.1134		.1619
16		.0857	.1134		
17		.0686	.1134	.1372	.1457
18		.1372	.1296	.1543	.1943
19		.1886	.1296	.1886	.1619
20		.1715	.1296	.1886	.1781
21		.1372	.1296	.1715	.1619
22		.1543	.1457	.1372	.1457
23		2.8807	3.3951	3.0483	3.2579
24	.7621	2.7435	3.4294	3.2007	3.4808
Max	.7621	2.8807	3.4294	3.2769	3.4808
Min	.7621	.0686	.1134	.0857	.1134
Avg	.7621	1.2399	1.2509	1.2313	1.2752

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274101 / KAVE

Feeder No / Name : 205 / 11 KV MUNGASHI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.945	.3429	.3239		.4115	.3077
2		.945	.3429	.3239		.463	.2915
3		.884	.3429	.3077		.4973	.2915
4		.8383	.4973	.3401		.5658	.3077
5		.9145	.6859	.4696		.703	.4696
6		1.3108	.823	.6802		.823	.7287
7		1.2955				1.2193	1.3889
8		1.2193				1.1279	1.3889
9		1.1584	.5487			1.0974	1.3375
10		.9602		.9431		1.0669	1.2517
11		.823	.884	.9602		.9907	1.2003
12		.945	.945	1.1145		.9907	1.0631
13		.9145	.9602	1.0802		1.0059	1.0288
14		.945	.9145	.2753		.945	1.046
15		.2286	.2572	.2753		.2743	.3077
16		.2439	.2743	.2591			.3239
17		.3048	.3429	.2591		.3772	.3239
18			.3772	.5506		.4801	.3887
19		.5792	.6173	.5668		.6001	.502
20		.6401	.6001	.502		.703	.5506
21		.4572	.583	.5182		.6516	.502
22				.4049		.4801	.3725
23			.3772	.4534		.3944	.3725
24	.8383	.9145	.3429	.3401	.4572	.4115	.3239
Max	.8383	1.3108	.9602	1.1145	.4572	1.2193	1.3889
Min	.8383	.2286	.2572	.2591	.4572	.2743	.2915
Avg	.8383	.8318	.5530	.5213	.4572	.7078	.6696

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274101 / KAVE

Feeder No / Name : 206 / BARDI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	1.0059
Max	1.0059
Min	1.0059
Avg	1.0059

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274155 / Chobe Pimpri

Feeder No / Name : 201 / Chobe Pimpri Bogda

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0564	.8962	.8962	.9602	1.0911	1.0883	1.0883
2	.0564	.9282	.933	.9602	1.0595	1.0883	1.1043
3	.0564	.9602	.9488	.9922	1.0753	1.1043	1.1203
4	.0564	.9602	.9488	1.0402	1.0911	1.1683	1.1203
5	.0705	1.0082	.9804	1.1203	1.1069	1.2003	1.1203
6	.0705	1.0402	.9646	1.1523	1.1069	1.1683	1.1363
7	1.1279	1.6004	1.4074	1.4243	1.5655	1.6804	1.7284
8	1.1984	1.6484	1.5655	1.5203	1.6446	1.6964	1.7444
9	1.1561	1.6324	1.5971	1.5524	1.6762	1.7604	1.7284
10	1.1561	1.6644	1.6446		1.6964	1.7444	1.7924
11	1.1702	1.6484	1.6804	1.5043	1.7284	1.8244	1.8724
12	1.142	1.6484	1.6324	1.4883	1.7284	1.6804	1.8564
13	1.1702	1.6484	1.6644	1.5203	1.7124	1.8244	1.8724
14	1.142	1.6644	1.6484	1.5684	1.7124	1.7604	1.8564
15	1.4098	.112	.08	.08	.048	.128	.048
16	1.4521	.144	.08	.0791	.048	.128	.096
17	1.438	.096	.08	.0791	.048	.128	.096
18	1.4803	.064	.08	.1107	.048		.08
19	1.5085	.064	.096	.1107	.064	.144	
20	1.5085	.08	.096	.1107	.144	.128	.08
21	1.7284	.08	.112	.1265	.144	.128	.08
22	1.7124	.08	.112	.1107	.176	.16	.112
23	.096	.8642	.8962	1.0595	1.0082	1.0402	1.0722
24	.0846	.096	.9282	.9282	1.1069	1.0082	1.0883
Max	1.7284	1.6644	1.6804	1.5684	1.7284	1.8244	1.8724
Min	.0564	.064	.08	.0791	.048	.128	.048
Avg	.9187	.8595	.8780	.8521	.9513	1.0340	1.0388

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274155 / Chobe Pimpri

Feeder No / Name : 202 / 11KV Bogewadi AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.945	.0594	.0602	.061	.061	.0762	.1372
2	.884	.0594	.0753	.061	.061	.0762	.1372
3	1.0364	.0594	.0903	.061	.0762	.0914	.1372
4	1.0669	.0743	.1054	.0762	.0914	.1067	.1524
5	1.1736	.0892	.1204	.0914	.1067	.0914	.1829
6	1.1888	.1189	.0753	.1067	.1219	.1677	.1981
7	.0914	.1189	.1054	.0914	.1372	.2286	.2134
8	.1067	.1189	.1054	.1067	.1067	.1981	.1677
9	.0914	.104	.0753	.1067	.0914	.1524	.1372
10	.0762	.104	.0602		.0762	.1677	.1219
11	.061	.1204	.0457	.061	.0762	.1372	.1067
12	.061	.1204	.061	.0762	.0762		.1372
13	.061	.1204	.0762	.0762	.0914	.1372	.1829
14	.0762	.1355	.0762	.9907	.0762	.1372	.1219
15	.0762	1.5352	1.3565	1.2651	1.3413	1.5851	1.9966
16	.061	1.6255	1.3717	1.3717	1.6461	1.4327	2.1186
17	.061	1.5954	1.3108	1.5242	1.6461	2.3472	2.1643
18	.0762	1.5051	1.2803	1.5089	1.8138		2.0576
19	.1219	1.3546	1.2041	1.3565	1.7375	1.9662	2.332
20	.1219	1.2944	1.0974	1.1584	1.4937	1.8138	1.7071
21	.104	1.2041	1.0364	1.1279	1.5394	1.7985	1.6613
22	.0892	1.0536	.9755	1.0822	1.4632	1.7528	1.5546
23	.8916	.0903	.0914	.0762	.1372	.1372	.1067
24	.9145	.9065	.0753	.0762	.0762	.1219	.1219
<b>Max</b>	<b>1.1888</b>	<b>1.6255</b>	<b>1.3717</b>	<b>1.5242</b>	<b>1.8138</b>	<b>2.3472</b>	<b>2.332</b>
<b>Min</b>	<b>.061</b>	<b>.0594</b>	<b>.0457</b>	<b>.061</b>	<b>.061</b>	<b>.0762</b>	<b>.1067</b>
<b>Avg</b>	<b>.3932</b>	<b>.5653</b>	<b>.4555</b>	<b>.5441</b>	<b>.5893</b>	<b>.6692</b>	<b>.7481</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274155 / Chobe Pimpri

Feeder No / Name : 203 / GFSS chobepimpri  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362	.0362	.0362	.0366	.0362		.0362
2	.0362	.0362	.0362	.0366	.0362	.0362	.0362
3	.0362	.0362	.0362	.0366	.0362	.0362	.0362
4	.0362	.0543	.0543	.0366	.0543	.0362	.0543
5	.0724	.0724	.0724	.0549	.0543	.0724	.0543
6	.0724	.0905	.0724	.0914	.0724	.0724	.0724
7	.0543	.0724	.0543	.0732	.0724	.0724	.0543
8	.0543	.0543	.0543	.0914	.0543	.0543	.0543
9	.0362	.0362	.0362	.0549	.0362	.0543	.0362
10	.0362	.0362	.0362		.0362	.0362	.0362
11	.0362	.0362	.0181	.0366	.0362	.0181	.0362
12	.0362	.0362	.0181	.0366	.0362	.0181	.0362
13	.0362	.0362	.0183	.0366	.0362	.0181	.0362
14	.0362	.0362	.0183	.0366	.0362	.0181	.0362
15	.0362	.0362	.0183	.0183	.0362	.0181	.0362
16	.0362	.0362	.0366	.0183	.0362	.0181	.0362
17	.0543	.0362	.0366	.0183	.0362	.0181	.0351
18	.0543	.0362	.0366	.0366	.0362		.0362
19	.0724	.0543	.0549	.0549	.0543	.0543	.0543
20	.0724	.0724	.0732	.0732	.0724	.0905	.0724
21	.0543	.0724	.0732	.0732	.0724	.0724	.0905
22	.0543	.0543	.0549	.0543	.0543	.0543	.0543
23	.0362	.0543	.0549	.0362	.0362	.0543	.0362
24	.0362	.0362	.0362	.0366	.0362	.0362	.0362
Max	.0724	.0905	.0732	.0914	.0724	.0905	.0905
Min	.0362	.0362	.0181	.0183	.0362	.0181	.0351
Avg	.0468	.0483	.0432	.0469	.0460	.0436	.0460



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274167 / 33/11K V PADSALI S/STn.

Feeder No / Name : 201 / PADSALI AG.(Old Butashte) SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2358	.2498	.2302	.2358	.1975	.1973
2	.2371	.2526	.2664	.2466	.2358	.1975	.2137
3	.2826	.8253	1.049	1.003	.2526	.2142	.2466
4	.3392	.9768	1.1823	1.1509	.2863	.2469	.3124
5	.4899	1.1789	1.6318	1.4798	.4716	.3461	.3617
6	.6783	1.7684	1.9482	1.7922	.6063	.5438	.5261
7	.6972	2.3916	2.2979	1.7428	.5558	.5274	.4933
8	.5841	2.7116	1.5486	1.71	.4884	.4779	.4439
9	.4334	2.4926	2.4644	.9043			.3617
10	.2826	2.1558	2.198	1.2989	.3032	.379	.2795
11	.1696	.1516	.1665	1.5291	1.8695	1.8458	.2631
12	.1696	.1347	.1332	1.7757	2.1558	2.1754	.2302
13	.1696	.1516	.1332	1.7922	2.2058	1.9776	
14	.1696	.1684	.1332	1.6606	2.0247	1.9282	.2795
15	.1696	.1516	.1332	1.8744	1.465		
16	.1507	.179	.1499	1.973	1.6626	2.0905	.1973
17		.1302		1.973	1.8436	1.9753	.1644
18		.179	.2331	1.003	1.0547		.2302
19	.5464	.3537	.4496	.3453	.379	.1975	.3453
20	.5464	.4884	.333	.4768		.3951	.3288
21	.3768	.32	.2831	.3453	.2966	.2798	.2631
22	.2826	.2526	.2664	.2466	.2307	.214	.2466
23	.2826	.2358	.2498	.2302	.2142	.214	.2137
24	.2638	.2358	.2331	.2302	.2189	.214	.2137
Max	.6972	2.7116	2.4644	1.973	2.2058	2.1754	.5261
Min	.1507	.1302	.1332	.2302	.2142	.1975	.1644
Avg	.3487	.7551	.7710	1.1256	.8662	.7923	.2915

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274167 / 33/11K V PADSALI S/STn.

Feeder No / Name : 202 / DHORE WASTI AG FEEDER(OLD SEPARATED AG FEEDERS HAVING SPECIAL  
LAUL Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1303	.1139	.1144	.115	.1302	.1147	.115
2	.1303	.1302	.1308	.1314	.1302	.1147	.1314
3	.6842	.1302	.1308	.1478	.8623	.9831	.9197
4	.7493	.1627	.1471	.1971	1.0088	1.0814	.9854
5	1.2054	.2278	.2452	.2463	1.2203	1.3272	1.3467
6	1.352	.3254	.376	.3941	1.4643	1.6221	1.6259
7	1.6778	.3742	.3106	.3613	2.1477	1.8351	1.6423
8	1.6778	.3417	.2779	.3285	1.6596	1.4091	1.6587
9	1.6452	.2603	.2125	.2299	1.9362	1.7368	1.7901
10	1.5149	.1627	.1308	.0985	1.562	1.704	1.7737
11	1.7267	1.5294	1.5693	.0821	.1139	.1147	1.708
12	1.2543	1.8386	1.8308	.1314	.0651	.1311	1.4124
13	1.5149	1.8711	1.5856	.0985	.099	.1147	1.6751
14	1.4986	1.6921	1.3568	.1314	.099	.0983	1.7572
15	1.7104	1.7735	1.7164	.1314	.1155		1.7244
16	1.6452	1.7572	1.7327	.1314	.132	.1475	1.5766
17	1.5312	1.6433		.1314	.1485	.1311	1.4945
18	.3421	1.4643	.7193	.1478	.1485	.1147	1.3959
19	.2118	.1627	.2125	.1642	.1815	.1966	.1642
20	.3095	.2441	.1962	.2792	.2805	.2458	.1971
21	.1955	.179	.1798	.2299	.198	.1966	.1971
22	.1466	.1302	.1635	.1478	.1485	.1475	.1642
23	.114	.1302	.1471		.132	.1311	.1314
24	.1303	.1139	.1308	.1314	.1302	.1311	.1314
Max	1.7267	1.8711	1.8308	.3941	2.1477	1.8351	1.7901
Min	.114	.1139	.1144	.0821	.0651	.0983	.115
Avg	.9624	.6983	.5920	.1821	.5881	.6013	1.0716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274167 / 33/11K V PADSALI S/STn.

Feeder No / Name : 203 / GFSS Padsali

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.128	.1272	.1274	.1274	.1272	.1092	.1274
2	.128	.1272	.1274	.1456	.1272	.1274	.1274
3	.128	.1091	.1456	.1819	.1272	.1274	.1456
4	.1463	.0909	.1456	.2183	.1272	.1274	.1819
5	.2012	.1636	.2001	.2365	.1999	.1819	.2183
6	.2743	.1818	.2547	.2729	.2545	.2365	.2547
7	.2195	.2181	.2729	.2547	.1999	.2729	.2729
8	.2378	.1999	.2365	.2365	.1636	.2001	.2183
9	.2378	.1999	.2365	.1638	.1999	.2183	.2183
10	.2012	.2363	.2001	.1819	.1818		.2001
11	.1646	.1818	.1456	.1456	.1818	.2001	.1819
12	.1463	.1272	.1456	.1092		.1819	.1456
13	.1097	.1272	.1092	.1456	.1092	.1456	.1274
14	.1097	.1272	.091	.1092	.1092	.1456	.1092
15	.128	.1272	.091	.1092	.1274		.1274
16		.1272	.091	.1092	.1638	.1638	.1456
17	.1463	.1454		.1456	.1638	.1456	.1456
18	.128	.1636	.1456	.1274	.1819	.1456	.1274
19	.2012	.1636	.1819	.1638	.1819	.2001	.1819
20	.2378	.2363	.2001	.2365	.2365	.2547	.2001
21	.1829	.1999	.2183	.2183	.1819	.2183	.1819
22	.1463	.1818	.2001	.2001	.1638	.2001	.1638
23	.128	.1454	.1819	.1456	.1456	.1638	.1456
24	.128	.1272	.1274	.1456	.1454	.1274	.1274
Max	.2743	.2363	.2729	.2729	.2545	.2729	.2729
Min	.1097	.0909	.091	.1092	.1092	.1092	.1092
Avg	.1678	.1598	.1685	.1721	.1652	.1770	.1698

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274167 / 33/11K V PADSALI S/STn.

Feeder No / Name : 204 / New BUTashte AG Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.0964	.1123	.112	.0964	.112	.112
2	.9382	.0964	.0963	.112	.0964	.1318	.112
3	.1294	.53	.7219	.7042	.0964	.1318	.128
4	.1132	.6103	.8502	.8482	.1124	.1318	.144
5	.1779	.7388	1.0427	1.0562	.1767	.1813	.192
6	.2265	.9637	1.2352	1.2803	.2249	.2307	.2401
7	.275	1.333	1.2673	1.2963	.2088	.1978	.2241
8	.2426	1.2849	1.2833	1.3283	.1767	.1978	.208
9	.1618	1.2849	1.3475	.8962	.1606	.1813	.176
10	.0971	1.3009	1.2192	.8962	.0803		.144
11	.0647	.0803	.0802	1.0082	1.1403	1.3678	.096
12	.0647		.0481	1.1683	1.3009	1.3514	
13	.0324		.0642	1.2163	1.4243	1.4883	
14		.0482	.0481	1.2803	1.5684	1.4563	
15	.0485	.0642	.0481	1.1523	1.3763		
16	.0809	.0642	.0802	1.2483	1.4083	1.6324	
17	.0971	.0964		1.3443	1.4083	1.2803	
18	.1132	.1285		.7202	1.2323	1.0402	
19	.1456	.1445	.1765		.176	.128	1.4723
20	.2265	.2249	.1604	.192	.208	.176	1.4083
21	.1779	.1927	.1444	.16	.16	.16	1.4083
22	.1294	.1445	.1283	.144	.16	.144	1.3923
23	.0971	.1285	.1283	.096	.144	.128	1.3603
24	1.0514	.0964	.1283	.112	.0964	.128	.128
Max	1.0514	1.333	1.3475	1.3443	1.5684	1.6324	1.4723
Min	.0324	.0482	.0481	.096	.0803	.112	.096
Avg	.2412	.4388	.4732	.7988	.5514	.5444	.5262

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274167 / 33/11K V PADSALI S/STn.

Feeder No / Name : 205 / UJANI (M) AG FEEDER FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1907	.2932	.2625	.2634	2.2968	2.5379	2.6337
2	.1907	.2932	.2953	.3128	2.2642	2.4061	2.5185
3	.6991	.3421	.3281	.3292	.2769	.2472	.2469
4	.7786	.3584	.3445	.3621	.2769	.2802	.2798
5	1.0805	.3909	.4101	.4115	.3909	.3626	.3621
6	1.2076	.6353	.5085	.5432	.4887	.4944	.5432
7	1.4459	.505	.5741	.4938	.5213	.5438	.4938
8	1.5254	.4724	.4593	.4444	.4561	.4614	.4774
9	1.6684	.4072	.3937	.3457	.4235	.4285	.4444
10	1.5254	.3095	.3609	.2963	.3584	.445	.4115
11	1.3983	2.476	2.0177	.2634	.3421	.3461	.2963
12	2.4152	2.9158	3.1495		.3258	.3131	.2963
13	2.733	3.2416	.3773		.3955	.379	.3621
14	2.733	2.6389	.2132	.2469	.3955	.3461	.3457
15		2.6226		.2963	.3626		.3128
16	2.3198	3.1439	1.9192		.412	.3131	.3457
17	2.7806	2.7692		.428	.4285	.3441	.3621
18	1.4618	1.4009	1.9192	.2798	.4887	.3768	.3621
19	.3813	.3421	.3773	1.9753	2.9484	2.6203	.5103
20	.4608	.4561	.3937	3.0617	3.0461	2.9994	.4115
21	.4131	.3747	.4101	3.1111	2.6715	3.0158	.3951
22	.3337	.3095	.3609	2.963	2.9484	3.0323	.3786
23	.286	.2932	.3281	2.7325	2.8344	2.9664	.3128
24	.1907	.2932	.2789	.2469	2.4597	2.7357	2.7161
Max	2.7806	3.2416	3.1495	3.1111	3.0461	3.0323	2.7161
Min	.1907	.2932	.2132	.2469	.2769	.2472	.2469
Avg	1.2269	1.1369	.7128	.9242	1.1589	1.2172	.6591

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274167 / 33/11K V PADSALI S/STn.

Feeder No / Name : 206 / NEW LAUL AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2472	2.3794	2.332	2.3122	.2586	.2232	.2398
2	.2662	2.3104	2.2462	2.2609	.2931	.2232	.2569
3	.3042	.2414	.2572	.2569	1.8277	2.0256	1.747
4	.3803	.2759	.2743	.274	1.9656	2.1457	1.8841
5	.5324	.3448	.3772	.3768	2.2415	2.3346	2.2266
6	.7035	.6035	.5487	.5995	2.6553	2.5234	2.7062
7	.7225	.6552	.583	.5995	2.5346	3.1414	2.8432
8	.5894	.6207	.583	.5995	2.8967	2.9697	2.9117
9	.5324	.569	.5658	.4624	2.9928	2.6092	2.8432
10	.4373	.4138	.3944	.3597	2.2415	2.3861	
11	.3993	.1897	.3944	.274	.3448		2.3465
12	.3423	.2586	.3258	.2569	.2931	.2575	2.2266
13	.3423	.3104	.2572	.2569	.3262	.2918	2.3294
14	.3613	.2931	.3258	.3083	.3262	.3262	2.5863
15	.3803	.2931	.3258	.274	.3262		3.0316
16	.2852	.2069	.1886	.3254	.2403	.3948	2.7062
17	.3042	.2931		.3254	.2918	.3776	2.7404
18	.4563	.3966	.3258	.2398	.412	.3605	2.5863
19		1.8794	2.915	.3768	.3776	.4291	.531
20	3.0422	2.5863	2.8978	.5823	.515	.4978	.5138
21	3.0422	2.7415	2.8635	.4453	.3948	.4291	.4967
22	3.1943	2.6725	2.8292	.3597	.309	.3948	.4796
23	2.9281	2.5518	2.7435	.274	.2575	.3433	.3597
24	.2472	2.4829	2.4177	2.3808	.2586	.2403	.2398
Max	3.1943	2.7415	2.915	2.3808	2.9928	3.1414	3.0316
Min	.2472	.1897	.1886	.2398	.2403	.2232	.2398
Avg	.8713	1.0654	1.1727	.6159	1.0242	1.1330	1.7753

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274188 / 33/11 KV KURDU SUBSTATION

Feeder No / Name : 201 / 11 KV PIMPALKHUNTE AG FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7194	1.286	.5487	.5068	.5068	.5487	.4525
2	1.7194	.4706	.5487	.5068	.543	.5068	.4525
3	1.7558	.5249	.5487	.5792	.6335	.5792	.4572
4	2.0995	.5792	.6401	.7059	.724	.6516	.6335
5	2.5606	.724	.7316	.8145	.7316	.724	.543
6	2.9995			.823			
7	3.7647						
8	3.8371						
9		3.8775		2.2862	3.219	3.7647	3.1674
10		3.8409		2.9447	3.8552	3.7647	3.2217
11		3.8914		3.5117	3.8009	3.8009	4.0724
12		3.9819	4.1152	3.9506	3.1855	3.8009	4.1267
13		3.8914	4.1086	3.6742	3.8371	3.8409	3.276
14		3.9323	5.8711	3.6561	3.1255	3.6199	3.9819
15		3.6199		3.819	3.786	3.6199	4.0181
16		3.4389	3.914	3.5113	3.8914	3.6199	3.4027
17	.4525			.4344	.4706		
18	.543		.4344	.4887			
19	.5068	.6401	.6219	.6335	.6335	.543	.6219
20	.4572		.6584	.6697	.7602	.7316	.6697
21	.5068	.724	.6219	.6584	.724	.724	.6516
22	.543	.6335	.5973	.543	.6335	.6335	.6154
23	.567	.6401	.5487	.4908	.6036	.543	.6154
24	1.7375	1.448	.5853	.5121	.5121	.5853	.543
Max	3.8371	3.9819	5.8711	3.9506	3.8914	3.8409	4.1267
Min	.4525	.4706	.4344	.4344	.4706	.5068	.4525
Avg	1.6106	2.1191	1.5684	1.6237	1.8089	1.9264	1.8696

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274188 / 33/11 KV KURDU SUBSTATION

Feeder No / Name : 202 / 11 KV AMBAD

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	1.1431	1.6108	2.4587	2.536	3.152	2.9673
2	.3429	1.0974	1.6651	2.4587	2.713	3.2217	2.9797
3	.3601	1.0974	1.8404	2.431	2.7978	3.2556	2.915
4	.5144	1.7939	2.5434	2.5484	3.0521	3.2556	3.0521
5	.6097	2.0348	2.8502	3.0521	3.0521	.7362	3.0521
6	.7716	2.1026	3.6626	3.4476	3.6286	.7888	3.3065
7		2.6452	3.3532	3.315		.9114	
8		2.9165	3.3303	3.3699	.6661	.9114	2.8045
9	2.3339						
10	2.934						
11	3.014						
12	3.1093						
13	3.2312						
14	2.8673						
16	2.3167						
17	.2058	.3467	.2804	.2804	.2743	.3772	.3086
18	.2743	.4287	.3224	.3155	.4207	.4207	.333
19	.5249	.4961	.4252	.4607	.567	.5258	.4557
20	.6219	.4961	.4557	.4908	.333	.5609	.5493
21	.5487	.4908	.4607	.4908	.3856	.5258	.4557
22	.362	.4382	.4252	.4382	.4557	.5316	.4557
23	1.4118	1.6956	2.3739	2.2891	3.1878	3.0178	2.7808
24	.3429	1.3717	1.7528	2.4587	2.431	3.0352	2.9835
Max	3.2312	2.9165	3.6626	3.4476	3.6286	3.2556	3.3065
Min	.2058	.3467	.2804	.2804	.2743	.3772	.3086
Avg	1.2876	1.2872	1.7095	1.8941	1.7667	1.5767	1.9600



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274188 / 33/11 KV KURDU SUBSTATION

Feeder No / Name : 203 / GFSS KURDU GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3944	.3944	.4973	.4801	.4801	.463
2	.3772	.3944	.3944	.4973	.5144	.4458	.463
3	.3772	.4287	.4287	.4973	.5487	.463	.4801
4	.5144	.5144	.6001	.5487	.583	.5144	.6001
5	.6001	.6173	.703	.5487	.583	.6516	.6859
6	.7202	.703	.7202	.703	.583	.703	.6859
9	.5487	.6516		.5658	.6001	.6344	.5487
10	.5487	.5144		.5658	.5487	.5316	.5316
11	.5316	.4115		.4801	.5144	.4801	.5144
12	.4458	.3772	.3772	.4458	.4458		
13	.3601	.3429	.5144	.3258	.3601	.4287	.3429
14	.3429	.3429	.3944	.3601	.3601	.4458	.3772
15	.3601	.3258		.3258	.3944	.4458	.3944
16	.3601	.3258	.3258	.3601	.3772	.463	.4458
17	.3944	.3772	.4458	.3772	.3258	.463	.3772
18	.4458	.4115	.463	.4458	.4973	.4801	.3601
19	.5487	.6516	.5487	.5144	.4973	.6516	.4973
20	.6516	.6859	.583	.6173	.6687	.6859	.6001
21	.5487	.6859	.583	.6001	.6173	.6859	.4115
22	.4973	.6001	.5487	.5487	.583	.6001	.5144
23	.4287	.5144	.5144	.5144	.5487	.5144	.4115
24	.3982	.4115	.4458	.4973	.4801	.5144	.5144
Max	.7202	.703	.7202	.703	.6687	.703	.6859
Min	.3429	.3258	.3258	.3258	.3258	.4287	.3429
Avg	.4717	.4856	.4992	.4926	.5051	.5373	.4866

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274223 / DHAVALAS S/STN

Feeder No / Name : 202 / Dhavlas Bogda Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	1.8843					
4	1.9012					
5	2.0031					
6	1.8673					
7	2.037					
8	1.9522					
9	2.088					
10	2.054					
11		2.0201	1.8164	2.0031	2.2068	2.1898
12		2.0201		2.071	2.2407	2.2068
13		2.037		2.037	2.1898	2.1559
14		2.1049		2.0031	1.9691	2.2068
15		2.088		2.1049	2.1728	2.2407
16		2.037		2.037		2.2407
17		2.1049		2.0031	2.2238	2.2407
18		2.1728		2.0031	1.5617	2.1728
Max	2.088	2.1728	1.8164	2.1049	2.2407	2.2407
Min	1.8673	2.0201	1.8164	2.0031	1.5617	2.1559
Avg	1.9734	2.0731	1.8164	2.0328	2.0807	2.2068

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274223 / DHAVALAS S/STN

Feeder No / Name : 203 / jhakale-Bhogewadi Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1485		.1155	.1155	.1155	.132
2	.1485		.132	.1155	.132	.1155
3	.165		1.1219	.9899	1.1549	.8579
4	.165	1.1879	1.0229	1.1879	1.3199	1.2374
5	.198	1.3364	1.1219	1.7159	1.5674	1.5674
6	.1485	1.4849		.099	1.9964	2.0789
7	.099	1.8314	.363	2.1779	2.4089	2.8378
8	.1815	2.1614	.264	2.3594	2.4749	2.6233
9	.165	2.1779	1.3199	2.2934	1.9469	2.5903
10	.132				1.9964	2.4419
11	1.9799	.099	.1155	.132	.1155	.165
12	2.3264	.132		.1485	.1485	.132
13	2.4419	.1155		.165	.132	
14	2.4914	.132		.231	.132	.132
15	2.5079	.1155		.132	.132	.132
16		.132	.0098	.1155		.132
17		.1155	.132	.165	.132	.132
18		.099			.1485	.132
19		.165	.165	.1485		.198
20		.132	.198	.2145	.2145	.2145
21		.165	.165	.198	.1815	.1485
22		.165	.1485	.198	.165	.165
23		.132	.1155	.1155	.132	.132
24	.1485		.099	.1155	.1155	.1485
Max	2.5079	2.1779	1.3199	2.3594	2.4749	2.8378
Min	.099	.099	.0098	.099	.1155	.1155
Avg	.8404	.6252	.3888	.5970	.7665	.8020

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274224 / BARLONI S/STN

Feeder No / Name : 201 / GFSS Barloni

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2439	.0762	.1524	.0762	.0762
2			.2743	.0762	.1677	.0762	.0762
3	.0914		.2591	.0762	.1372	.0762	.0914
4	.1219		.2439		.1677	.0762	.1219
5	.0914		.2286		.1524	.0914	.1524
6	.1829		.2134		.1829		
7	1.5851		.061		.1677		
8	1.7833		.061	.1067	.1219		
9	1.8595			.1067	.0914	.1372	.0762
10	1.9052			.1067	.0914	.1067	.0762
11	1.89		.061		.0914	.0914	.0762
12	1.9052		.061	.061	.0914	.0914	.0762
13	1.89		.061	.061	.0914	.0762	.0914
14	1.89		.1372		.0762	.0914	.0762
15	.061		1.6309		1.8138	2.0119	
16	.061		1.829	1.9204	2.1033		2.1033
17	.061			2.0576	2.0576	1.9204	2.1491
18	.061		2.0576	1.9814	2.1338	1.8595	2.0271
19	.061	.1219	2.1186	1.9509	2.2558	1.9204	2.1338
20	.0914	1.9052	2.0881	2.0271	2.3015	1.9509	2.0119
21	.0914	1.9052	2.0576	1.9814	2.1948	2.0424	2.0271
22	.061	1.7833	1.9814	1.9357	2.1338	1.9814	1.9052
23	.061	.1067	.061	.2134	.1372	.0914	.0762
24	.061	.061	.1067	.061	.2286	.0914	.0762
Max	1.9052	1.9052	2.1186	2.0576	2.3015	2.0424	2.1491
Min	.061	.061	.061	.061	.0762	.0762	.0762
Avg	.7212	.9806	.7541	.8706	.7976	.7430	.7750

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274224 / BARLONI S/STN

Feeder No / Name : 202 / Barloni Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1948	2.4387	.3353	.1829	.2439	.2591	.1524
2	2.4539	2.1338	.3658	.1524	.1524	.2591	.1524
3		2.1338	.3658	.1524	.2896	.2591	.1524
4	.1219	2.4387	.381		.1829	.2286	.1677
5	.1524	2.5149	.381	.1524	.2743	.2439	.1677
6	.1981	2.7435	.3963	.1524	.3658	.3048	.1677
7	.442	2.8959	.4877	1.9814	2.8654	2.9264	2.8654
8	.2743	3.0026	.3506	2.0119	3.1703	3.2312	3.0788
9	.2134	2.9721		2.1643	3.2312	3.0178	3.2007
10	.1981	2.9874		2.5606	3.216	3.2922	3.3989
11	.1829		2.9874		3.2007	3.2007	3.3379
12	.1524		3.0483	2.9264	2.8349	3.0483	3.216
13	.1524		3.1855	2.8197	3.0331	3.1855	3.1855
14	.1524		3.094	2.9721	3.0026	3.0026	2.3167
15	2.9264		.1981	.1219	.1219		
16	2.9569		.2591	.1677	.1219		.1372
17	2.9721		.1524	.1677	.1981	.1524	.1524
18	2.9569		.1981	.2439	.1981	.1829	.1829
19	2.9721		.2743	.2286	.2591	.1829	.2439
20	2.8959	.3048	.2591	.2591	.2591	.2134	.2439
21	.2439	.2439	.2591	.2743	.2439	.2286	.2743
22	.2286	.1829	.2134	.2591	.2591	.2286	.1829
23	.2134	.1677	.1829	.2591	.2591	.1981	.1829
24	2.5606	.1829	.3506	.1829	.2286	.2591	.1829
Max	2.9721	3.0026	3.1855	2.9721	3.2312	3.2922	3.3989
Min	.1219	.1677	.1524	.1219	.1219	.1524	.1372
Avg	1.2094	1.8229	.8057	.9270	1.1755	1.2775	1.1888

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274224 / BARLONI S/STN

Feeder No / Name : 203 / Bandhara Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.061	1.0669	2.3167	2.4234	2.8197	2.7435
2		.061		2.3472	2.3472	2.8197	2.713
3		.061		2.0881	2.4844	2.6063	2.5911
4		.061			2.4539	2.4691	2.5911
5		.061			2.271	2.4539	2.5911
6		.061			2.4691	2.4539	2.6216
7		.061			.9145		.061
8		.061				.061	.061
9		.061			.061		.061
10		.061			.061		.061
11		.061			.061		.061
12		.061			.061		.061
13					.061	.0762	
14					.061	.1372	
15					.061	.061	
16					.061		
17					.0914	.0762	
18					.0914	.0762	
19					.0914	.0762	
20			.1067		.0914	.061	
21	1.7528		.061		.061	.061	
22	1.8747		.061		.061	.061	
23	1.829	1.0669	2.332	2.4387	2.8959	2.8349	1.9814
24		1.8138	1.1431	2.2862	2.4844	2.774	2.8349
Max	1.8747	1.8138	2.332	2.4387	2.8959	2.8349	2.8349
Min	1.7528	.061	.061	2.0881	.061	.061	.061
Avg	1.8188	.2581	.7951	2.2954	.9443	1.2210	1.5024

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 277004 / 132/110/33/11 KV EHV

KURDUWADI

Feeder No / Name : 201 / 11 KV M.TEKADI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 277004 / 132/110/33/11 KV EHV

KURDUWADI

Feeder No / Name : 202 / 11 KV UJANI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	1.5089
Max	1.5089
Min	1.5089
Avg	1.5089



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 277004 / 132/110/33/11 KV EHV

KURDUWADI

Feeder No / Name : 203 / Kurduwadi

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
22	1.6766
Max	1.6766
Min	1.6766
Avg	1.6766

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 277004 / 132/110/33/11 KV EHV

KURDUWADI

Feeder No / Name : 204 / 11 KV TANDULWADI (OLD

SHEDDABLE RURAL

MODLIMB Feeder KV- 11 /

OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	1.5089
Max	1.5089
Min	1.5089
Avg	1.5089

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 277004 / 132/110/33/11 KV EHV

KURDUWADI

Feeder No / Name : 205 / 11 KV AKULGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	1.5546
Max	1.5546
Min	1.5546
Avg	1.5546

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 277004 / 132/110/33/11 KV EHV

KURDUWADI

Feeder No / Name : 206 / 11 KV MADHA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	1.3565
Max	1.3565
Min	1.3565
Avg	1.3565

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 277004 / 132/110/33/11 KV EHV

KURDUWADI

Feeder No / Name : 207 / 11 KV KURDUWADI W/W  
EXPRESS Feeder KV- 11 /  
OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-AUG-17
HR	Load (MW)
24	1.5089
Max	1.5089
Min	1.5089
Avg	1.5089

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 277004 / 132/110/33/11 KV EHV

KURDUWADI

Feeder No / Name : 400 / Station T/F

Feeder KV- 33 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	3.9323
Max	3.9323
Min	3.9323
Avg	3.9323

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 277004 / 132/110/33/11 KV EHV

KURDUWADI

Feeder No / Name : 405 / Madha

Feeder KV- 33 / INCOMING

DATE	01-AUG-17
HR	Load (MW)
23	5.5784
24	5.5784
Max	5.5784
Min	5.5784
Avg	5.5784

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 277004 / 132/110/33/11 KV EHV

KURDUWADI

Feeder No / Name : 406 / Mahisgaon (Karmala)

Feeder KV- 33 / INCOMING

DATE	01-AUG-17
HR	Load (MW)
24	5.0297
Max	5.0297
Min	5.0297
Avg	5.0297



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 277004 / 132/110/33/11 KV EHV

KURDUWADI

Feeder No / Name : 407 / Jeur

Feeder KV- 33 / INCOMING

DATE	01-AUG-17
HR	Load (MW)
24	5.0297
Max	5.0297
Min	5.0297
Avg	5.0297

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 277004 / 132/110/33/11 KV EHV

KURDUWADI

Feeder No / Name : 409 / Kurdu

Feeder KV- 33 / INCOMING

DATE	01-AUG-17
HR	Load (MW)
22	5.0297
24	5.0297
Max	5.0297
Min	5.0297
Avg	5.0297

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 277004 / 132/110/33/11 KV EHV

KURDUWADI

Feeder No / Name : 410 / Vithal Corporation Sugar

Feeder KV- 33 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	4.5268
Max	4.5268
Min	4.5268
Avg	4.5268

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 277004 / 132/110/33/11 KV EHV

KURDUWADI

Feeder No / Name : 702 / 132 kv indian suger

Feeder KV- 132 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	21.9479
Max	21.9479
Min	21.9479
Avg	21.9479

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274022 / 33/11KV MADHA SUBSTATION

Feeder No / Name : 201 / Nimgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.4877	.7316	.9145	.6401	.6859	.6401
2	.1372	.4572	.7316	.884	.6401	.6401	.6859
3	.1524	.4877	.7621	.8993	.6249	.6401	.6401
4	.1524	.5335	.7468	.9145	.6706	.6859	.6859
5	.1677	.6097	.7773	.9907	.7316	.7621	.7164
6	.1981	.6401	.823	1.0974	.7926	.8078	.7468
7	.1677	.7316	1.0364	1.2955	1.0974	.9145	1.0059
8	.1219	.7773	1.1126	1.2955	1.0974	.9602	1.0364
9	.1543	.9431	1.2346	1.1145	1.2517	1.166	1.166
10	.1372	.9774	1.166	1.5947	1.166	1.1488	1.0974
11	1.2689	.1372	.1029	.3772	.1372	.1372	.12
12	1.2346	.1543	.1372	.5144	.1715	.1372	.12
13	1.2517	.1372	.1029	.4973	.1715	.1372	.1357
14	1.0974	.1341	.1357	.3772	.1715	.1715	.1677
15	1.0802	.1341	.1187	.4115	.1543	.1715	
16	1.1317	.1372	.1174	.3772	.1372	.1543	.1677
17	1.1317	.1543		.4725	.1543	.1543	.1219
18	.9145	.12	.1543	.4268	.1543	.12	.1067
19	.1715	.1372			.2058	.1886	.1677
20	.2229	.1543		.2134	.2401	.2229	.1829
21	.3429	.1677	.4973	.1981	.2401	.2229	.1829
22	.2058	.1524	.463	.1829	.2374	.2058	.1829
23	.1715	.1372	.4287	.1524	.1886	.1886	.1677
24	3.0864	.1543	.1372	.4287	.1524	.1715	.1715
Max	3.0864	.9774	1.2346	1.5947	1.2517	1.166	1.166
Min	.1219	.12	.1029	.1524	.1372	.12	.1067
Avg	.6182	.3607	.5484	.6796	.4679	.4498	.4529

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274022 / 33/11KV MADHA SUBSTATION

Feeder No / Name : 202 / MADHA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.4458	.4287	.3944	.4115	.3944	.4115
2	.4115	.4287	.3944	.3944	.3772	.3772	.3944
3	.3944	.4287	.3944	.3772	.3772	.3772	.3944
4	.4287	.463	.4115	.4287	.4115	.3944	.4115
5	.463	.5144	.4801	.463	.4801	.4287	.463
6	.5144	.583	.583	.5316	.5658	.5144	.5144
7	.5316	.5316	.583	.5658	.5487	.5658	.5658
8	.4801	.5487	.5144	.5487	.4458	.4973	.5316
9	.0514	.4801	.463	.4458	.4287	.5316	.5144
10	.4801	.5658	.4458	.463	.5144	.5316	.5316
11	.4973	.4973	.4287	.4287	.4458	.6001	.5144
12		.5316	.4973	.5144	.5487	.5487	.463
13	.4973	.5144	.5144	.5658	.6024	.583	.4801
14	.5487	.4973	.5144	.4801	.5487	.5144	.4973
15	.5316	.4801	.5144	.4973	.4801	.4458	
16	.463	.4973	.4801	.5144	.5487	.463	.4572
17	.0686	.5316		.5144	.6001	.4973	.5144
18	.5144	.5316	.6859	.6001	.6001	.5316	.5316
19	.6516	1.166	.7202	.6859	.6687	.6516	.6001
20	.7716	.6859	.7888	.6859	.6859	.7202	.6516
21	.6344	.6344	.6516	.6516	.6173	.6859	.583
22	.6001	.6001	.583	.583	.5658	.5658	.5487
23	.5144	.5144	.4801	.4801	.4801	.4973	.4801
24	.4458	.463	.463	.4115	.4287	.4115	.4458
Max	.7716	1.166	.7888	.6859	.6859	.7202	.6516
Min	.0514	.4287	.3944	.3772	.3772	.3772	.3944
Avg	.4749	.5473	.5226	.5094	.5159	.5137	.5000

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274022 / 33/11KV MADHA SUBSTATION

Feeder No / Name : 203 / JADHAVWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.2229	.1829	.2401	.1677	.2058	.2401
2	.945	.2058	.1829	.2229	.1677	.1886	.2229
3	.945	.2229	.2286	.2229	.1829	.1886	.2401
4	1.0669	.2572	.2743	.2572	.2591	.2058	.2572
5	1.2498	.3429	.3048	.3429	.3353	.2743	.3429
6	1.6613	.4801	.4115	.4801	.4572	.4458	.463
7	2.3777	.4287	.3963	.463	.3963	.463	.4287
8	2.3624	.3772	.3353	.3772	.2743	.3772	.3429
9	2.4691	.2743	.2743	.3086	.3086	.2915	.2683
10	2.1605	.5658	.2229	.2229	.2058	.2572	.2515
11	.1619	2.692	2.1776	2.3491	2.3663	2.572	2.1628
12		2.5034	2.8807	2.7263	3.0521	2.692	2.6322
13	.2058		2.5892	2.6578	2.9492	3.0864	2.6686
14	.2058	2.3807	2.5987	2.692	2.8292	3.0007	2.7681
15	.1886	2.1125	2.5987	2.6578	2.8292	2.6673	
16	.1886	2.6063	2.4813	2.7092	2.7949	2.5911	2.4234
17	.2058	2.7778		2.4387	2.6825	2.4691	2.4691
18	.1886	2.6063	1.448	1.6613	2.5484	2.0576	.2591
19	.2743	.2915	.3258	.2743	.3018	.2743	.2591
20	.3944	.3086	.3601	.3201	.3521	.3772	.3048
21	.3258	.2439	.2743	.2743	.3353	.3429	.2286
22	.2743	.2439	.2572	.2439	.3018	.2915	.2134
23	.2401	.1981	.2229	.1981	.2229	.2572	.1981
24	2.915	.2229	.1981	.2401	.1829	.2058	.2401
Max	2.915	2.7778	2.8807	2.7263	3.0521	3.0864	2.7681
Min	.1619	.1981	.1829	.1981	.1677	.1886	.1981
Avg	.9531	.9811	.9229	1.0242	1.1043	1.0743	.8646

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274022 / 33/11KV MADHA SUBSTATION

Feeder No / Name : 204 / chincholi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6766	.2401	.2229	.2401	.1886	.2058	.2058
2	1.6766	.2572	.2229	.2229	.1886	.1886	.1886
3	1.7071	.2401	.2401	.2401	.2401	.1886	.1886
4	1.829	.3429	.3086	.3429	.3086	.2058	.2572
5	1.9357	.4287	.463	.4287	.6173	.2572	.3429
6	2.2862	.5658	.6001	.5316	.5487	.4287	.463
7	2.2405	.5182	.5658	.583	.5316	.4801	.4973
8	2.4387	2.6063	.463	.583	.4287	.4287	.3944
9	.2743	2.9321	2.9664	1.4575	2.8807	3.0864	2.9007
10	.2058	2.8121	3.2065	2.2291	2.8635	3.5151	3.0333
11	.1543	2.8121	3.1379	2.332	2.3663	3.0864	2.7515
12	.1715	2.9664	3.2236	2.5206	2.6578	3.0864	2.0287
13	.1543	2.8635	2.8121	2.7435	2.6235	.7888	2.6852
14	.12		2.8675	2.8292	2.8121	.8059	2.6189
15	.12	2.7161	2.3537	2.915	2.9492	2.5301	
16	.12	2.7092	2.4863	3.0007	3.0864	2.5911	1.9662
17	.1715	.1372		.12	.1658	.1543	.12
18	.1886	.1886	.1886	.1543	.1823	.1715	.1886
19	.3429	.2743	.3086	.2401	.3018	.2572	.2229
20	.4458	.463	.4801	.3601	.3688	.3772	.3258
21	.4115	.3429	.3429	.2915	.3018	.3086	.2915
22	.3429	.3086	.2915	.2915	.2515	.2572	.2743
23	.2743	.2743	.2401	.2058	.2229	.2229	.2229
24	1.6461	.2401	.2134	.2401	.2058	.2058	.2058
Max	2.4387	2.9664	3.2236	3.0007	3.0864	3.5151	3.0333
Min	.12	.1372	.1886	.12	.1658	.1543	.12
Avg	.8723	1.1843	1.2263	1.0460	1.1372	.9929	.9728



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274023 / 33/11KV MANEGAON SUB STATION

Feeder No / Name : 201 / WAKAV SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715		1.2269	2.6063			3.155
2	.1715	.6859	1.2269	2.6063	2.4863		3.155
3	.1715	.6859	1.2269	2.6063	2.4863		3.155
4	.1715	.6859	.1753	2.6063	2.6406		3.155
5	.1715	.6859	.1753	2.6063	2.8464		4.1152
6	.2572	.9431	.1753	2.6235	1.7147		4.1152
7	.2572	1.4575	.1753	3.2579			
8	.2572		.1753	3.1207		3.3303	
9	.1715		.1753	.1715		.1753	
10	.1715		.1715	.1715		.1753	
11	.1753	.181	.1715	.1753	.1753	.1715	
12	.1753	1.6476	.1715	.1753	.1753	.1715	.1753
13	.1753		.1715	.1753	.1753	.1715	.1772
14	.1753		.1715			.1715	
15	.1753		.1715			.1715	.1753
16	.1753		.1715				.1753
17			.1753	.1753		.1715	
18			.1715	.1753		.1715	
19			.2058			.2058	
20		.1715	.2572			.2572	.1753
21			.2572			.2572	.1753
22			.2572			.2058	
23			.2058			.2058	
24	1.8861		.0876	2.6063			.2058
Max	1.8861	1.6476	1.2269	3.2579	2.8464	3.3303	4.1152
Min	.1715	.1715	.0876	.1715	.1753	.1715	.1753
Avg	.2888	.7938	.3146	1.6162	1.5875	.4009	1.7008

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274023 / 33/11KV MANEGAON SUB STATION

Feeder No / Name : 202 / MANEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1091			.3429			.3429
2	2.1091		.1753	.3429			.3429
3	2.1091		.1753	.3429			.3429
4	2.1091		.1753	.3429			.3429
5	2.1091		.1753	.3429			.3429
6	2.2291	.3086	.1753	.4287	.2572		.5144
7	2.6235	.3086	.1753	.4287			.5144
8	2.3663		.1753	.3429		.3856	.4287
9	.2572		1.4899	1.9204		2.9797	3.0178
10	.2572		.9945	2.0919		3.2952	3.1722
11	.2629	2.2443	2.452		2.6993	3.5322	
12	.2629	.2629	3.3265		2.9096	3.1722	2.9622
13	.2629		3.0178	.1753	2.6467	2.9492	3.3829
14	2.7168		3.2579			2.8978	
15	.2629		3.1722			3.1036	2.8045
16	.2572		2.4006				2.6993
17				.3506		.2572	
18				.3506		.2572	
19			.3429			.3429	
20		.3429	.4287			.4287	.3155
21		.3429	.4287			.4287	.3155
22			.4287			.3429	.2572
23			.3429			.3429	
24	2.2291		.1753	.3429			.3429
Max	2.7168	2.2443	3.3265	2.0919	2.9096	3.5322	3.3829
Min	.2572	.2629	.1753	.1753	.2572	.2572	.2572
Avg	1.4431	.6350	1.1184	.5819	2.1282	1.6477	1.2468

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274023 / 33/11KV MANEGAON SUB STATION

Feeder No / Name : 203 / ANGENGAON(U) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	1.6289	2.2786	2.4348	1.6289		2.5549
2	.1715	1.4746	2.2786	2.4348	1.6289		2.5549
3	.1715	1.4746	2.2786	2.4348	1.6289		2.5549
4	.1715		2.2786	2.4348	1.6289		2.5549
5	.1715	1.4746	2.2786	2.4348	1.8861		2.5549
6	.2572	1.4746	2.8045	2.572	2.4006		2.7949
7	.2572	2.6578	2.8045	2.692			3.0864
8	.2572		2.8045	2.4177			2.452
9	.1715		.1753	.2058			.1715
10	.1715		.1715	.1715			.1715
11	.1753	.1753			.1753		
12	.1753	.1753		.1753	.1753		.1753
13	.1753				.1753	.1715	.1753
14	.1753		.1715			.1715	
15	.1753		.1715			.1715	.1753
16	.1715		.1715				.1753
17			.1753	.1753		1.9719	
18			.1715	.1753		.1715	
19			.2058			.2058	
20		.2058	.2572			.2572	.1753
21		.1715	.2572			.2572	.1753
22			.2572			.2058	.1715
23			.2058			.2058	
24	1.5432		.1753	.2058			.2058
Max	1.5432	2.6578	2.8045	2.692	2.4006	1.9719	3.0864
Min	.1715	.1715	.1715	.1715	.1753	.1715	.1715
Avg	.2684	1.0913	1.0654	1.4975	1.2587	.3790	1.2711

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274023 / 33/11KV MANEGAON SUB STATION

Feeder No / Name : 204 / KHAIRAO SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3032		.1753	.2058			.2058
2	1.3032		.1753	.2058			.2058
3	1.3032		.1753	.2058			.2058
4	1.3032		.1753	.2058			.2058
5	1.3032		.1753	.2058			.2058
6	1.5604	.1715	.1753	.2572	.1715		
7	1.7661	.1715	.1753	.2572			
8	1.6632		.1753	.2572		.1753	.1715
9	.1715		1.8054	2.4348		3.3303	3.2065
10	.1715		2.1262	2.5892		3.4004	3.7723
11	.1753	1.858	2.6406	2.1735	2.5941	3.5322	
12	.1753	1.6476	2.6406	2.1735	2.3838	3.4294	3.4355
13	.1753		2.6406	2.1209	3.276	3.4294	3.1539
14	.1753		2.332			3.1036	
15	.1753		2.5892			3.3265	3.2251
16	.1753		2.0233				3.2251
17			.1753	.1753		3.2922	
18			.1715	.1753		.1715	
19			.2058			.2058	
20		.1715	.2572			.2572	.1753
21		.1715	.2572			.2572	.1753
22			.2572			.2058	
23			.2058			.2058	
24	1.5432		.1402	.2058			.2058
Max	1.7661	1.858	2.6406	2.5892	3.276	3.5322	3.7723
Min	.1715	.1715	.1402	.1753	.1715	.1715	.1715
Avg	.8496	.6986	.9113	.8656	2.1064	1.8882	1.4517

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274023 / 33/11KV MANEGAON SUB STATION

Feeder No / Name : 205 / KAPASEWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715		.1753				.2058
2	.1715		.1753				.2058
3	.1715		.1753				.2058
4	.1715		.1753				.2058
5	.1715		.1753				.2058
6	.2572		.1753		.1715		.3429
7	.3429	.1715	.1753	.2572			.3429
8	.3429		.1753	.2572		.2103	.3429
9	1.869		.1753	.1715		.1753	.1715
10	2.0405		.1715	.1715		.1753	.1715
11	1.6651	.1753	.1715		.1753	.1715	
12	1.6651	.1753	.1715		.1753	.1715	.1753
13	1.7703		.1715		.1753	.1715	.1753
14	.1753		.1715			.1715	
15	1.7703		.1715			.1715	.1753
16	1.6289		.1715				.1753
17			2.2786	2.0508		.1715	
18			2.1948	2.0508		2.452	
19			2.0405			2.452	
20		2.1776	2.0062			2.4348	2.2961
21		2.0576	1.8519			2.2805	2.2961
22			1.7147			2.2805	2.1948
23			1.7833			2.2805	
24	1.9719		1.9105	1.7833			2.1776
Max	2.0405	2.1776	2.2786	2.0508	.1753	2.452	2.2961
Min	.1715	.1715	.1715	.1715	.1715	.1715	.1715
Avg	.9622	.9515	.7733	.9632	.1744	1.0513	.6704

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274023 / 33/11KV MANEGAON SUB STATION

Feeder No / Name : 206 / kumbhej SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715		.1753	.1715			.2058
2	.1715		.1753	.1715			.2058
3	.1715			.1715			.2058
4	.1715		.1753	.1715			.2058
5	.1715		.1753	.1715			.2058
6	.2572	.1715	.1753	.2572	.1715		
7	.2572	.1715	.1753	.2572			
8	.1715		.1753	.1715		.1753	.1715
9	.6344		.1753	.1715		.1753	.1372
10	.5316		.1715	.1715		.1753	.1372
11	.3506	.1753	.1372	.1753	.1753	.1715	
12	.3506	.1753	.1372	.1753	.1715	.1715	.1753
13	.3506		.1372	.1753	.1753	.1715	.1753
14	.3506		.1372			.1715	
15	.3506		.1372			.1715	.1753
16	.3506		.1372				.1753
17			1.6476	2.0683		.1715	
18			1.7661	2.2786		2.8121	
19			1.9204			3.0007	
20		.1715	1.9204			3.0178	2.6467
21		.2229	1.8176			2.7949	2.6467
22			1.7147			2.8978	2.5377
23			1.7833			3.0007	
24	1.6289		.1928	1.7833			2.4348
Max	1.6289	.2229	1.9204	2.2786	.1753	3.0178	2.6467
Min	.1715	.1715	.1372	.1715	.1715	.1715	.1372
Avg	.3789	.1813	.6591	.5339	.1734	1.2719	.7776

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION

Feeder No / Name : 201 / Uplai(BK)

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.3429	.2572	.2572	.2572	.2572	.2572
2	.0686	.2572	.2572	.2572	.2058	.2572	.1715
3	.0686	.2572	.3429	.2572	.2058	.2572	.1715
4	.0686	.2572	.3429	.2572	.2058	.2572	.2572
5	.0857	.4287	.3429	.3429	.2572	.2572	.2572
6	.12	.6859	.3429	.4287	.2572	.3429	.3429
7	.12	.6001	.4287	.4287	.4287	.4287	.4287
8	.0857	.4287	.5144	.4287	.4287	.4287	.4287
9	.2572	.0514	.0686	.0686	.0857	.0857	.0514
10	.3944	.0514	.0514	.0343	.0514		.0343
11	.3429	.0343	.0514	.0343	.0514	.0686	.0343
12	.3429		.0343	.0343	.0514	.0343	.0171
13	.3429		.0343	.0343	.0514	.0343	.0343
14	.3429	.0343	.0343	.0343	.0343	.0343	.0343
15	.3429	.0343	.0343	.0343	.0343		.0171
16	.5144	.0514	.0343	.0171	.0343		.0343
17	.0514	.0171	.0343	.0343	.0343	.0686	.0343
18	.0686	.0343	.0343	.0514	.0514	.0857	.0514
19	.0857	.0857	.0514	.0857	.0514	.0857	.0857
20	.0857	.0686	.0686	.0857	.1029	.1029	.1029
21	.1029	.0686	.0686	.0857	.1029	.12	.0857
22	.0857	.0686	.0686	.0686	.0857	.12	.0857
23	.2572	.2572	.2572	.1715	.2572	.2572	.2572
24	.0686	.3429	.2572	.2572	.2572	.2572	.2572
Max	.5144	.6859	.5144	.4287	.4287	.4287	.4287
Min	.0514	.0171	.0343	.0171	.0343	.0343	.0171
Avg	.1822	.2026	.1672	.1579	.1493	.1829	.1472

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION

Feeder No / Name : 202 / Rophale(KH)

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.1715	.1715	.1715	.1715	.1715	.1715
2	.8573	.1715	.1715	.1715	.1715	.1715	.1715
3	.9431	.1715	.1715	.1715	.1715	.1715	.1715
4	1.0288	.1715	.2572	.1715	.2058	.2572	.1715
5	1.2003	.2572	.2572	.1715	.2572	.2572	.1715
6	1.8861	.3429	.3429	.2572	.3429	.3429	.1715
7	2.1434	.3086	.4287	.3429	.4287	.3429	.2572
8	1.8861	.3429	.3429	.3429	.3429	.3086	.2572
9	.1715	1.9719	1.3717	1.3717	1.8861	2.4006	2.2291
10	.1715	2.2291	2.4006	1.7147	2.1434		2.572
11	.1372	2.4863	2.3148	2.0576	2.1434	2.4863	2.572
12	.1372		2.4006	2.1434	2.2291	2.4863	2.2291
13	.1372		2.2291	2.0576	2.1434	.8573	2.4006
14	.12	1.5432	2.2291	2.2291	2.2291	2.4006	2.572
15	.12	2.4006	2.2291	2.3148	1.9719		2.572
16	.1372	2.0576	2.3148	2.2291	2.0576		2.4006
17	.1543	.1715	.1715	.1715	.1715	.1715	.1715
18	.1715	.1715	.1715	.2058	.1715	.1715	.2401
19	.2229	.2572	.1715	.3086	.1715	.2572	.3086
20	.3086	.3086	.2572	.3944	.3258	.2572	.2572
21	.3944	.3086	.2572	.3772	.3429	.2572	.2401
22	.4115	.2743	.1715	.3086	.3086	.2572	.2058
23	.2401	.2572	.1715	.2572	.2572	.1715	.2229
24	.9431	.1715	.2572	.1715	.2401	.2572	.1715
Max	2.1434	2.4863	2.4006	2.3148	2.2291	2.4863	2.572
Min	.12	.1715	.1715	.1715	.1715	.1715	.1715
Avg	.6159	.7521	.8859	.8381	.8702	.6883	.9545



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION

Feeder No / Name : 204 / GAONTHAN

GAONTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2572	.1715	.3086	.2572	.2572	.3086
2	.2572	.1715	.1715	.3086	.2572	.2572	.3086
3	.2572	.1715	.1715	.3086	.2572	.2572	.3086
4	.2572	.1715	.2572	.3086	.2572	.2572	.3086
5	.2572	.2572	.2572	.3086	.2572	.2572	.3086
6	.2572	.3429	.3086	.3086	.2572	.3086	.3086
7	.3429	.4287	.3429	.3086	.4287	.3429	.3086
8	.2572	.3429	.3086	.3429	.4287	.3086	.3086
9	.3429	.2572	.2572	.3429	.3429	.3086	.3429
10	.3086	.2572	.2572	.3086	.2572		.1715
11	.2572	.2572	.2572	.3086	.2572	.2572	.3086
12	.2572		.2572	.1715	.2572	.2572	.3086
13	.1715		.2572	.1715	.2572	.1715	.1715
14	.1715	.2572	.2572	.1715	.1715	.1715	.1715
15	.2572	.2572	.1715	.1715	.1715		.2572
16	.1715	.1715	.1715	.1715	.1715		.1715
17	.2572	.2058	.2572	.1715	.1715	.2572	.1715
18	.2572	.2572	.2572	.2572	.2572	.2572	.2572
19	.3429	.3086	.2572	.3429	.2572	.3086	.3772
20	.3429	.3429	.3429	.3772	.3429	.3086	.3429
21	.4287	.3429	.3429	.4287	.3429	.2572	.3429
22	.4287	.3086	.2572	.3772	.3086	.2572	.3086
23	.3772	.2572	.3086	.2572	.2572	.3086	.3086
24	.2572	.3429	.2572	.3086	.2572	.2572	.3086
Max	.4287	.4287	.3429	.4287	.4287	.3429	.3772
Min	.1715	.1715	.1715	.1715	.1715	.1715	.1715
Avg	.2822	.2712	.2565	.2851	.2701	.2678	.2829

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION

Feeder No / Name : 205 / Kumbhej

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.1715	.1715	.2058	.1715	.1715	.2572
2	.6859	.1715	.1715	.2058	.1715	.1715	.2572
3	.7716	.1715	.1715	.2058	.1715	.1715	.2572
4	.8573	.1715	.1715	.2058	.1715	.1715	.2572
5	.8573	.1715	.1715	.2058	.2058	.1715	.2572
6	.8573	.2572	.2572	.1715	.2572	.2572	.2572
7	1.0288	.2572	.2572	.2572	.2572	.2572	.2572
8	1.1145	.2572	.2572	.2572	.2572	.2058	.1715
9	.1715	.8573	1.286	1.046	1.1145	.3429	.6859
10	.12	1.2003	1.286	1.166	1.2003		1.4575
11	.0857	1.2003	1.286	1.2689	1.286	.8573	1.286
12	.0857		1.286	1.3375	1.286	.8573	1.3546
13	.0857		1.286	1.406	1.2003	.5144	1.2517
14	.0857	.9431	1.286	1.4232	1.2003	.6859	1.4232
15	.0857	1.0288	1.2003	1.4232	1.286		1.4403
16	.0857	1.286	1.2517	1.4403	1.286		1.166
17	.0857	.1715	.1715	.1715	.1372	.0857	.1715
18	.0857	.1715	.1715	.1715	.1715	.1715	.1715
19	.12	.2058	.1715	.1715	.1715	.1715	.2058
20	.2058	.2572	.1715	.2058	.2572	.2058	.1715
21	.2572	.2572	.1715	.2572	.2572	.2058	.1715
22	.2058	.1715	.1715	.2058	.2058	.2058	.1715
23	.1715	.1715	.1715	.1715	.1715	.1715	.1715
24	.6859	.1715	.1715	.1715	.1715	.1715	.1715
Max	1.1145	1.286	1.286	1.4403	1.286	.8573	1.4575
Min	.0857	.1715	.1715	.1715	.1372	.0857	.1715
Avg	.3951	.4419	.5487	.5730	.5444	.2964	.5601

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION

Feeder No / Name : 206 / UPLAI(KH)

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	1.4575	1.1145	1.4575	1.6289	1.2003	1.4575
2	.1715	1.4575	1.3717	1.4575	1.6289	1.4575	1.4575
3	.1715	1.5432	1.4575	1.5432	1.7147	1.7147	1.5432
4	.2572	1.8004	1.5432	1.5432	1.8004	1.8861	1.5432
5	.3429	1.9719	1.6289	1.6632	1.8861	2.0576	1.7147
6	.3429	2.4006	2.452	2.0233	1.9376	2.2291	2.2291
7	.4287	2.572	2.572	2.6578	2.5549	2.572	2.572
8	.3429	2.5892	2.6063	2.2805	2.452	2.2634	.4287
9	2.0748	.2915	.2572	.2915	.2743	.3429	.3086
10	2.452	.1886	.1715	.2572	.1715		.2743
11	2.572	.1715	.1715	.12	.1886	.2058	.2572
12	2.4691		.1715	.12	.1886	.2058	.2572
13	2.2291		.1715	.1372	.1715	.1715	.2915
14	2.2634	.1372	.2229	.1372	.1715	.1715	.2572
15	2.2805	.1886	.2058	.1372	.2401		.2401
16	2.1091	.1886	.2229	.1715	.2401		.2229
17	.1886	.0343	.2572	.1715	.2401	.1886	.2401
18	.2401		.2572	.1886	.2572	.2572	.3086
19	.3429	.3258	.3429	.3086	.2915	.3429	.3944
20	.3944	.3944	.4287	.3772	.3772	.4287	.3429
21	.3772	.4115	.4287	.2743	.3258	.4287	.3086
22	.3429	.4115	.3429	.2401	.2915	.3429	.2572
23	1.166	.7716	1.3717	1.3717	.8573	1.3717	1.6289
24	.1715	1.3717	.8573	1.3717	1.6289	.9431	1.3717
Max	2.572	2.5892	2.6063	2.6578	2.5549	2.572	2.572
Min	.1715	.0343	.1715	.12	.1715	.1715	.2229
Avg	.9959	.9847	.8595	.8459	.8966	.9896	.8295

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION

Feeder No / Name : 207 / vittalwadi

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.6859	.4287	.6859	.7373	.6001	.6859
2	.0514	.6859	.5144	.5144	.7545	.6859	.6859
3	.0514	.6859	.6001	.5144	.7716	.6859	.6859
4	.0686	.7716	.6859	.5144	.8059	.6859	.7716
5	.0686	.8573	.7716	.5316	.8402	.7716	.7888
6	.1029	1.0288	1.0117	.8059	.8916	.9431	.9431
7	.0857	1.0288	1.2003	.9431	.9945	1.0288	.9431
8	.0686	.9602	.9431	.8745	1.0802	.8745	.3429
9	.9259	.0686	.0857	.0686	.0514	.0514	.0686
10	1.1831	.0514	.0514	.0514	.0686		.0686
11	1.0802	.0343	.0514	.0343	.0514	.0514	.0514
12	.9945		.0514	.0343	.0343	.0343	.0343
13	1.1145		.0343	.0514	.0343	.0343	.0514
14	1.1145	.0514	.0343	.0343	.0343	.0343	.0343
15	1.1317	.0343	.0343	.0343	.0343		.0343
16	1.1145	.0514	.0343	.0514	.0343		.0514
17	.0343	.0514	.0343	.0343	.0343	.0514	.0514
18	.0514		.0343	.0514	.0343	.0686	.0686
19	.0857	.0857	.0686	.0857	.0686	.0857	.0857
20	.0857	.0857	.0857	.0857	.0857	.0857	.0686
21	.0857	.0857	.0857	.0857	.0686	.0686	.0686
22	.0686	.0857	.0857	.0686	.0857	.0686	.0686
23	.6001	.3429	.6859	.6173	.4287	.7716	.7716
24	.0514	.7202	.4287	.7716	.7202	.5144	.7716
Max	1.1831	1.0288	1.2003	.9431	1.0802	1.0288	.9431
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.4279	.4025	.3351	.3144	.3644	.3903	.3415

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION

Feeder No / Name : 208 / londewadi

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.2058	.2572	.2572	.2229	.2572	.2572
2	1.5432	.2058	.2572	.2572	.2401	.2572	.2572
3	1.5432	.2058	.2572	.3086	.3086	.2572	.2572
4	1.6289	.2572	.3429	.3086	.3772	.3429	.3086
5	1.8861	.3429	.3772	.3944	.4287	.4287	.4115
6	2.4006	.463	.463	.5144	.5144	.4458	.4458
7	2.7435	.4287					
8	2.4348						
9	.2743	2.2291	2.6235	1.9033	2.3663	2.4863	2.7263
10	.1886	2.7778	2.8292	2.3491	1.0288		2.8978
11	.1715	2.7606	2.8292	2.5034	2.8292	2.452	2.6063
12	.1372		2.7435	2.4006	2.5377	2.4863	2.9835
13	.12		2.8292	2.1776	2.572	1.9719	2.5892
14	.12	2.0919	2.8292	2.3148	2.572	2.4863	2.7435
15	.12	2.7949	2.572	2.4348	2.5892		2.7778
16	.1029	2.6235	2.2291	2.4863	2.4006		2.3491
17	.1543	.1886	.1715	.1886	.1715	.1886	.1886
18	.1715		.2572	.2058	.2572	.2572	.2572
19	.3086	.3258	.2572	.3258	.3086	.2572	.3944
20	.4115	.4287	.3429	.4115	.3086	.3429	.3601
21	.3601	.4115	.4287	.3772	.3601	.3429	.3429
22	.3772	.4287	.3429	.3601	.4973	.3086	.3086
23	.2401	.3429	.2572	.2058	.2572	.2572	.2401
24	1.7147	.2229	.3086	.2572	.2058	.2572	.2572
Max	2.7435	2.7949	2.8292	2.5034	2.8292	2.4863	2.9835
Min	.1029	.1886	.1715	.1886	.1715	.1886	.1886
Avg	.8230	.9868	1.1730	1.0428	1.0615	.8465	1.1800

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274162 / Darphal(sina) s/s

Feeder No / Name : 201 / Darphal

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.3734	2.1872	2.5926	2.5934	2.7035	2.834
2	.2614	.3395	2.119	2.359	2.5621	2.6707	2.7526
3	.2641	.3326	2.1125	2.3403	2.4371	2.6216	2.6408
4	.3206	.3921	2.1052	2.2297	2.3045	2.6543	2.6566
5	.3772	.4481	2.1052	2.2348	2.2085	2.652	2.8487
6	.5658	.5601	.5256	.5847	.6722	.5093	.6468
7	.5041	.5847	.6348	.5847	.7468	.6722	.6908
8	.4338	.5228	.6908	.5658	.7095	.7468	
9	.9061	.4715	.6535		.6413	.7282	
10	.9998		.5658		.5658	.6535	.5975
11	1.0311	.3921	.567	.2987	.5788	.5601	.6535
12	1.0623	.3881	.6036	.4108	.5788	.5788	.6722
13	1.0802	.462	.5975	.4108	.5788	.6099	.6908
14	1.1248	.4805	.6099	.4481	.6161	.6348	.6348
15	1.1873	.4755	.6413	.4481	.6283	.6468	.5601
16			.6653	.4668	.6468	.6099	.6348
17	.2987			.4668	.6468	.6348	.6348
18	.2801				.6535	.7095	.6535
19	.4854	.6722	.7356	.7095	.7733	.7655	.6535
20	.5041	.6161	.7468	.7842	.6979	.6535	.5601
21	.5041	.5041	.5975	.6036	.6224	.5093	.5041
22	.4108	2.2405	2.6543	2.7206	2.753	2.7366	
23					2.7368	2.9329	
24	.3018	.3734	2.234	2.6092	2.6558	2.769	2.967
Max	1.1873	2.2405	2.6543	2.7206	2.753	2.9329	2.967
Min	.2614	.3326	.5256	.2987	.5658	.5093	.5041
Avg	.5993	.5594	1.1596	1.1934	1.2753	1.3318	1.2744

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274162 / Darphal(sina) s/s

Feeder No / Name : 202 / kevad

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8179	.8436	.2641	.3174	.2987	.3395	.3174
2	.8124	.7926	.2641	.3018	.2772	.3395	.3174
3	.8025	.7526	.3018	.2987	.3395	.3772	.3018
4	.8592	.8429	.3395	.3584	.3361	.415	.3361
5	.9297	1.0059	.3961	.4338	.3734	.3772	.3772
6	1.3272	1.3108	1.6667	2.0216	2.2725	2.4291	3.2065
7	1.5466	1.8747	2.1872	2.3903	2.4326	2.5587	2.8675
8	1.5741	1.8747	2.4985	2.3245	2.5286	2.6558	2.6397
9	.4481		2.2455	2.1872	2.5606	2.6882	2.8509
10	.4108		2.3205	2.1872	2.3045	2.5749	2.6543
11	.2614	.2027	2.0934	2.0729	2.6216	2.4615	2.753
12		1.2967	2.1091	2.1247	2.6871	2.5606	2.5926
13	.1886	1.2498	2.1247	2.3746	2.6882	2.6408	2.6235
14	.1867	.2743	.2772		.2134	.3361	.2172
15	.2241	.2561	.2801	.2614	.3109	.3142	.2033
16		.3142	.2587	.2614	.3658	.2926	.2957
17	.2987	.3326		.2987		.3658	.2587
18	.3361	.3511	.3841	.3361	.3881	.4251	.2987
19	.4435	.4805	.4715	.4854	.5601	.5175	.3696
20	.5544	.5041	.5228	.4854	.6161	.5228	.4435
21	.5228	.5041	.4668	.3734	.5228	.5415	.4481
22	.4481	.3174	.3584	.3361	.3921	.4251	
23					.3547	.3696	
24	.8436	.8436	.2641	.3174	.2987	.3395	.3326
Max	1.5741	1.8747	2.4985	2.3903	2.6882	2.6882	3.2065
Min	.1867	.2027	.2587	.2614	.2134	.2926	.2033
Avg	.6589	.7726	1.0043	1.0249	1.1193	1.1195	1.2139

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274162 / Darphal(sina) s/s

Feeder No / Name : 203 / Undergoan SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6718	.4877	.6097	.3725	.4481	.4527	.5228
2	.6642	.4687	.5937	.3353	.4904	.4527	.5041
3	.6722	.5761	.5937	.3395	.5415	.4904	.5093
4	.7116	.5761	.6167	.4239	.679	.5281	.5975
5	.8905	.5937	.6325	.5182	.679	.6413	.679
6	.8905	.8124	.5506	.6173	.7095	.7545	.7468
7	.8642	1.0242	.4784	.602	.7545	.7356	.8299
8	.8436	1.0623	.4268	.4725	.7545	.7167	.3772
9	.3734	1.2186		.4515	.6036	.6413	.6413
10	.3734		.3561	.4481	.4668	.5658	.5847
11	.2987		.3315	.3734	.4108	.5228	.5601
12	.2241	.1619	.3521	.2987	.2987	.547	.5228
13	.2241	.1875	.2035	.1509	.2241	.2987	
14	.1867	.4428	2.3148	1.9662	3.3364		2.5194
15	.1494	.5851	2.5772	2.8121	3.3867	3.4494	2.2672
16		.8322	2.713	2.8746	3.3813	3.417	2.5857
17	.2241	.9145		2.8433	3.4808	3.4808	2.8121
18	.2241	1.0364	2.2653	2.8121		.2561	2.6558
19	.4481	1.3413	2.7831	2.8121	3.315	3.5711	2.7206
20	.5228	1.5089	2.9127	2.8807	3.2526	3.3846	2.6558
21	.5228	1.5089	3.0178	2.7206	3.1184	3.5099	2.4059
22	.5041	.5556	.4733	.5281	.5281	.5847	
23					.4904	.5658	
24	.679	.4877	.6321	.4252	.4435	.4527	.547
Max	.8905	1.5089	3.0178	2.8807	3.4808	3.5711	2.8121
Min	.1494	.1619	.2035	.1509	.2241	.2561	.3772
Avg	.5074	.7801	1.2112	1.2208	1.3823	1.3052	1.345



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274162 / Darphal(sina) s/s

Feeder No / Name : 204 / Darfal Water Supply

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0145	.0145	.0145	.0145	.0145	.0145	.0145
2	.0145	.0145	.0145	.0145	.0145	.0145	.0145
3	.0145	.0145	.0145	.0145	.0145	.0145	
4	.0145	.0145	.0145	.0145	.0145		
5	.0145	.0145	.0145	.0145	.0145	.0145	
6	.029	.0145	.2606	.1014	.1882	.0869	.1448
7	.0145	.0145	.2172	.1014	.2027	.1303	.1738
8	.0145	.0145	.1882	.1014	.2606	.1738	.2027
9	.2317	.1014	.2027	.1158	.2606	.2027	.1882
10	.2027		.2172	.1882	.2317	.2317	.2317
11	.2027	.2462	.2172	.1882	.2462	.2606	.2896
12	.2751	.2896	.1882	.2317	.2317	.2606	.2751
13	.2317	.2751	.1738		.2172	.2606	.2896
14	.2317	.2606	.029	.0145	.0145	.0145	.029
15	.2317	.2606	.029	.0145	.0145	.0145	
16		.2751	.0145	.0145	.0145		.029
17	.029	.029		.0145	.029	.029	.0145
18	.0145	.029				.029	.0145
19	.029	.029	.029	.0145	.029	.029	.0145
20	.0145	.029	.029	.0145	.0145	.0145	.0145
21	.0145	.029	.029	.0145	.0145	.0145	.0145
22	.0145	.0145	.0145	.0145	.0145	.029	
23					.0145	.0145	
24	.0145	.0145	.0145	.0145	.0145	.0145	.0145
Max	.2751	.2896	.2606	.2317	.2606	.2606	.2896
Min	.0145	.0145	.0145	.0145	.0145	.0145	.0145
Avg	.0849	.0908	.0917	.0586	.0907	.0960	.1094

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274020 / ADHEGAON

Feeder No / Name : 201 / WADOLI FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274020 / ADHEGAON

Feeder No / Name : 202 / TAKALI FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274020 / ADHEGAON

Feeder No / Name : 204 / NAGORLI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274020 / ADHEGAON

Feeder No / Name : 205 / BHIMANAGAR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274020 / ADHEGAON

Feeder No / Name : 206 / Alegaon 10 km  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274020 / ADHEGAON

Feeder No / Name : 207 / Ranjani 6 km  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274020 / ADHEGAON

Feeder No / Name : 208 / Adhegaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274020 / ADHEGAON

Feeder No / Name : 209 / OSMANABAD WW  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-AUG-17
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274021 / BEMBALE

Feeder No / Name : 201 / Humbe Wasti AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.0914	.1219
2		.0914	.1067
3		.1067	.1067
4		.1067	.1067
5		.1524	.1067
6		.1524	.0914
7		.1524	.0914
8		.1524	.0914
9		.1562	.0914
10		.1562	.0762
17		1.4842	1.7185
18		1.406	1.8747
19		1.406	1.906
20		1.406	1.906
21		1.406	1.906
22		1.3279	1.8747
23		1.2498	1.8747
24	1.3717	1.2498	1.1717
<b>Max</b>	<b>1.3717</b>	<b>1.4842</b>	<b>1.906</b>
<b>Min</b>	<b>1.3717</b>	<b>.0914</b>	<b>.0762</b>
<b>Avg</b>	<b>1.3717</b>	<b>.6808</b>	<b>.8457</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274021 / BEMBALE

Feeder No / Name : 202 / Bemble AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.9145
Max	.9145
Min	.9145
Avg	.9145

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274021 / BEMBALE

Feeder No / Name : 203 / Ghoti AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274021 / BEMBALE

Feeder No / Name : 204 / BHOSALE WASTI  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274021 / BEMBALE

Feeder No / Name : 205 / Goathan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274021 / BEMBALE

Feeder No / Name : 206 / ChavanWadi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274025 / 33/11KV PIMPLNEAR SUBSTATION

Feeder No / Name : 201 / WIRELESS

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6385	1.8023	.1829	.1989	.1966	.1989	.1829
2	1.6575	1.7695	.2134	.1989	.2294	.1823	.2134
3	1.6385	1.704	.2439	.1966	.2294	.1823	.2286
4	1.8023	1.6385	.2591	.2622	.2622	.2321	.2439
5	2.0719	1.5074	.2743	.2622	.2622	.2818	.2591
6	2.0972	1.6385	.2896	.3315	.2294	.2984	.2591
7	2.4577	1.9662					
8	2.4905	2.0972					
9		2.2939	2.9492	2.271	2.5301	2.8509	
10		2.5526	2.4249	2.3929	2.652	2.7183	
11		2.556	2.4905	2.3472	2.713	2.7183	
12			2.4577	2.4844	2.5301	2.652	
13		2.1792	2.4577	2.5149	2.4082	2.713	
14		2.1879	2.6216	2.4082	2.5301	2.652	
15		2.1795	2.1792	2.332	2.3472	2.5434	
16		2.0972	2.2939	2.2862	2.0729	2.3205	
20	.2622	.2134	.2622	.1966	.2652	.2286	
21	.2294	.1981	.2622	.1966	.2155	.1829	
22	.2294	.1829	.1966	.1966	.1989	.1829	
23	.2294	.1829	.1966	.1966	.1989	.1677	
24	1.5683	.1966	.1829	.1966	.1966	.1989	.1677
Max	2.4905	2.556	2.9492	2.5149	2.713	2.8509	.2591
Min	.2294	.1829	.1829	.1966	.1966	.1677	.1677
Avg	1.4133	1.5572	1.1810	1.1300	1.1720	1.2371	.2221



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274025 / 33/11KV PIMPLNEAR SUBSTATION

Feeder No / Name : 202 / PIMPALNER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2622	.2294	.3048	.2294	.2321	.2652	.2134
2	.2622	.2267	.3353	.2294	.2321	.2652	.2439
3	.2652	.2267	.3506	.2622	.2321	.2652	.2591
4	.2949	.2591	.3658	.2652	.2652	.2818	.2743
5	.3277	.3239	.381	.3018	.2652	.2818	.2896
6	.3932	.3239	.3963	.3315	.2321	.2984	.3353
9	2.5911						
10	2.652						
11	2.5911						
12	2.8349						
13	2.652						
14	2.3929						
15	1.9204						
16	1.8595						
17		3.0483	2.9835	2.9835	3.2156	2.713	
18		2.8349		3.0664	3.1493	2.6978	
19		2.652	3.0498	3.315	2.8178	2.4691	
20	.3277	2.4387	2.7526	2.3205	2.6189	2.4082	
21	.2294	2.2558	2.4863	2.1216	2.304	2.1033	
22	.2294	2.0729	2.3472	1.989	2.2211	1.9509	
23	.2622	1.9204		1.8896	2.1548	1.89	
24	.2622	.1966	1.8595	2.0972	1.7901	2.0885	1.829
Max	2.8349	3.0483	3.0498	3.315	3.2156	2.713	1.829
Min	.2294	.1966	.3048	.2294	.2321	.2652	.2134
Avg	1.1900	1.3578	1.4677	1.5287	1.5522	1.4270	.4921

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274025 / 33/11KV PIMPLNEAR SUBSTATION

Feeder No / Name : 203 / NIMGAON (T) SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2267	.2294	2.2862	2.5396	2.3266	2.4697	2.4996
2	.2294	.2294	2.3167	2.5396	2.5396	2.4863	2.5301
3	.2294	.2294	2.3167	2.6216	2.6216	2.5194	2.5606
4	.2294	.2294	2.3472	2.7035	2.6871	2.5029	2.5911
5	.2652	.2622	2.3624	2.7854	2.4249	2.5857	2.6216
6	.2622	.2622	2.3777	2.8182	2.3266	2.8178	2.8807
7			1.9814	2.4387	2.7526	2.7183	.4877
8				2.2558	2.6216	2.9172	2.0424
17	3.0476						
18	2.9492						
19	2.8509						
20	2.4249	.2591	.2622	.2591	.2818	.2439	
21	2.13	.2286	.2652	.2591	.2652	.2134	
22	1.9662	.2134	.1989	.1943	.2652	.1981	
23	1.9006	.1981		.1943	.0829	.1829	
24	2.0081	1.8351	.1829	.1966	.1943	.2321	.1829
Max	3.0476	1.8351	2.3777	2.8182	2.7526	2.9172	2.8807
Min	.2267	.1981	.1829	.1943	.0829	.1829	.1829
Avg	1.4800	.3797	1.5361	1.6774	1.6454	1.6991	2.0441

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274025 / 33/11KV PIMPLNEAR SUBSTATION

Feeder No / Name : 204 / PIMPALNER GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3944	.3772	.463	.4382		.463	.4801
2	.4161	.4115	.4801	.5258		.463	.4973
3	.4207	.4458	.5144	.5487		.4458	.5144
4	.5258	.4801	.5487	.6001		.4973	.5487
5	.5784	.6001	.6001	.6485		.583	.583
9	.5658	.5609	.6173	.6001	.5316	.6135	
10	.5316	.443	.8745		.4973	.5316	
11	.4973	.4733	.463	.4287	.4115	.4908	
12	.463		.4115	.4115	.4115	.4382	
13	.4458		.3772	.3772	.4115	.3814	
14	.4287		.4115	.3772	.3944		
15	.3772		.3772	.4287	.4115		
17		.4287					
18		.4458					
20	.6516	.6859	.6661		.7373	.6687	
21	.5144	.6173	.6135	.57	.6344	.583	
22	.5316	.5658	.567	.5144	.5144	.5316	
23	.463	.4973	.5258	.463	.4801	.4973	
24	.463	.4287	.4973	.4733		.4801	.463
Max	.6516	.6859	.8745	.6485	.7373	.6687	.583
Min	.3772	.3772	.3772	.3772	.3944	.3814	.463
Avg	.4864	.4974	.5299	.4937	.4941	.5112	.5144

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274025 / 33/11KV PIMPLNEAR SUBSTATION

Feeder No / Name : 205 / Dahiwali

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0497	.1524	2.6825	2.6658	2.6189	2.6063
2		.0497	.1524	2.652	2.649	2.6189	2.6406
3		.0497	.1677	2.652	2.6155	2.6355	2.6578
4		.0497	.1677	2.6825	2.5149	2.652	2.6749
5		.0497	.1677	2.8178	2.5484	2.7018	2.692
6		.0663	.1677	2.9673	2.5819	2.9007	2.7606
7			2.4844	2.7435	2.7328	2.652	2.9321
8				2.7435	2.3975		2.4006
17	2.7183			3.0178			
18	2.3205						
19	2.5526						
20	2.1548	.1219	.0509	.0503	.1326	.12	
21	2.0553	.1219	.0509	.0503	.1326	.0914	
22	1.9559	.1219	.0509		.116	.0914	
23	1.8896	.1067	.0509	.0503	.0829	.0914	
24	1.9814	1.873	.1067	.0497	.0503	.0829	.0857
Max	2.7183	1.873	2.4844	3.0178	2.7328	2.9007	2.9321
Min	1.8896	.0497	.0509	.0497	.0503	.0829	.0857
Avg	2.2036	.2418	.3142	1.9353	1.6323	1.6047	2.3834

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274025 / 33/11KV PIMPLNEAR SUBSTATION

Feeder No / Name : 206 / TAMBAVE AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.13	1.9227	.3353	.2652	.3429	.3601	.2743
2	2.2377	1.8896	.3353	.2652	.2743	.3429	.2915
3	2.2377	1.7901	.3506	.2652	.3429	.3429	.3086
4	2.3758	1.757	.3658	.2984	.3429	.3429	.3429
5	2.4863	1.7238	.3658	.2818	.3391	.3772	.3772
6	2.3205	1.989	.3658	.3315	.3391	.3944	.4115
7	2.2939	2.5194					
8	2.2542	2.652					
9	1.9052	2.652	3.1161	2.2862	3.1207	3.0864	
10	2.2253		3.152	2.1948	3.155	2.5377	
11	2.3167	2.4531	2.9835	2.5034	3.1207	3.0178	
12	2.3777		3.0001	2.5549	3.0864		
13	2.0424	2.5194	3.0498	2.6749	3.0521	2.9473	
14	1.89	2.5194	2.7846	2.572	2.9835	2.7978	
15	1.7375	2.5194	2.652	2.572	3.0864	2.8607	
16	1.6766	2.5194	2.5194	2.452	2.8464	2.6452	
17		2.3777	2.4863	2.6063	2.9492	2.4691	
18		2.4539	2.3371	2.7435	2.8121	2.7778	
19		2.1338	2.3371	2.4006	2.5377	2.572	
20	.3315	2.0119	2.1216	2.2977	2.2977	2.332	
21	.2652	1.829	1.989	2.1262	2.1605	2.3834	
22	.2652	1.7071	1.8564	1.7147	2.1091	1.768	
23	.2652	1.5242	1.8233	1.6118	1.8176	1.6766	
24	1.3717	.2652	1.4937	1.5912	1.5089	1.7833	1.7833
Max	2.4863	2.652	3.152	2.7435	3.155	3.0864	1.7833
Min	.2652	.2652	.3353	.2652	.2743	.3429	.2743
Avg	1.7622	2.0786	1.9009	1.7550	2.0284	1.8960	.5413

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274026 / TEMBHURNI

Feeder No / Name : 201 / AKOLE AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
22	.2743
24	1.3717
Max	1.3717
Min	.2743
Avg	.823

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274026 / TEMBHURNI

Feeder No / Name : 202 / MALEGAO AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274026 / TEMBHURNI

Feeder No / Name : 204 / UJANI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
1	1.8519
2	1.7661
3	1.8004
4	1.9204
5	2.0233
6	2.1091
7	1.4861
8	2.4691
24	1.8519
<b>Max</b>	<b>2.4691</b>
<b>Min</b>	<b>1.4861</b>
<b>Avg</b>	<b>1.9198</b>



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274026 / TEMBHURNI

Feeder No / Name : 205 / SHEWARE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274026 / TEMBHURNI

Feeder No / Name : 206 / Footjawalgaon  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274026 / TEMBHURNI

Feeder No / Name : 207 / GOATHAN TEMBHURNI  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-AUG-17	03-AUG-17
HR	Load (MW)	Load (MW)
1		1.8107
2		1.8298
3		1.7375
4		1.8298
5		1.9004
6		2.0119
7		1.828
8		1.4632
9		1.3575
10		1.2883
11		1.1946
12		1.086
13		1.0498
14		1.1403
15		1.086
16		1.0498
17		.9955
18		.9955
19		1.1765
20		1.3575
21		1.267
24	1.6975	1.848
<b>Max</b>	<b>1.6975</b>	<b>2.0119</b>
<b>Min</b>	<b>1.6975</b>	<b>.9955</b>
<b>Avg</b>	<b>1.6975</b>	<b>1.4229</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274026 / TEMBHURNI

Feeder No / Name : 208 / AKOLE BHAGIRATH

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	03-AUG-17
HR	Load (MW)	Load (MW)
1		.362
2		.362
3		.439
4		.439
5		.439
6		.5068
7		.5121
8		.3658
9		.3658
10		.3841
11		.3292
12		.2926
13		.2896
14		.2561
15		.2172
16		.2561
17		.2715
18		.2896
19		.4024
20		.439
21		.4572
24	.3429	.362
<b>Max</b>	<b>.3429</b>	<b>.5121</b>
<b>Min</b>	<b>.3429</b>	<b>.2172</b>
<b>Avg</b>	<b>.3429</b>	<b>.3654</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274026 / TEMBHURNI

Feeder No / Name : 209 / SURLI BHAGIRATH

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
1	.1543
24	.1543
Max	.1543
Min	.1543
Avg	.1543

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274026 / TEMBHURNI

Feeder No / Name : 210 / SHEVARE PANIPURAWATHA  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-AUG-17
HR	Load (MW)
24	.2743
Max	.2743
Min	.2743
Avg	.2743

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274027 / WARWADE

Feeder No / Name : 201 / Bhend Ag

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-AUG-17
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274027 / WARWADE

Feeder No / Name : 202 / PARITE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	1.1904	.4287	.3932	.4096	.4359	.426
2	1.3717	1.1904	.4458	.426	.3932	.4191	.4752
3	1.3717	1.2071	.4801	.4588	.3768	.4694	.5079
4	1.3565	1.3245	.6173	.5243	.4752	.5365	.5407
5	1.829	2.0119	.6687	.6062	.5898	.6371	.5735
6	2.1643	2.1628	.7202	.7865	.7373	.7712	.6554
7		2.4813	1.8176	1.8275	1.7772		2.2131
8		2.0957		1.7772	2.1963		2.1125
9		2.2801		1.7101	2.079		1.6095
10		2.0119		1.7604	2.0919		1.9448
11		1.7939		1.6766	2.0576		1.8107
12		1.7772	2.2634	1.8778	2.1091		1.6263
13		1.7604	2.3491	1.9448	2.0748		1.8107
14		1.4419	2.4348	1.9448	1.9204		***
19	.6226	.5243	.5144	.5079	.5487		.3932
20	9.9619	.5735	.6516	.6718	.4973		.4752
21	.5571	.4915	.6344	.6062	.503		.4424
22	.4862	.4588	.4801	.4915	.503		.3932
23	1.4419	.426	.426	.4424	.503		.3932
24	1.3717	1.2574	.4287	.4096	.4096	.4694	.4096
Max	9.9619	2.4813	2.4348	1.9448	2.1963	.7712	24.9977
Min	.4862	.426	.426	.3932	.3768	.4191	.3932
Avg	2.0049	1.4231	.9601	1.0422	1.1126	.5341	2.1905



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274027 / WARWADE

Feeder No / Name : 203 / Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3688	.4458	.4527	.4527	.4801	.5868
2	.3772	.3688	.5144	.4191	.4527	.4458	.6371
3	.4115	.4024	.5658	.4359	.4191	.6173	.6706
4	.4287	.426	.6173	.5365	.503	.6859	.7042
5	.5487	.5365	.583	.6203	.6371	.6516	.7545
9	.6371	.6036			.6706		.6706
10	.5365	.503			.6173		.5868
11	.5365	.503		.4527	.5658		.5868
15	.3688	.4359		.4359	.4287		.4024
16	.4359	.4694	.583	.4862	.3772		.503
17	.4527	.503			.4458		.5868
18	.4527	.5365	.5316		.4973		.5243
19	.6036	.7042	.6516	.6874	.6687		.5533
20	.7042	.6036	.7202	.788	.6344		.6539
21	.5197		.7202	.6874	.583		.6539
22	.4862	.4862	.6516	.6036	.5487		.5868
23	.4024	.4191	.5365	.4862	.5144		.5365
24	1.3717	.4024	.4287	.4694	.4862	.4973	.57
Max	1.3717	.7042	.7202	.788	.6706	.6859	.7545
Min	.3688	.3688	.4287	.4191	.3772	.4458	.4024
Avg	.5362	.4866	.5807	.5401	.5279	.563	.5982

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274027 / WARWADE

Feeder No / Name : 204 / AKOLE BK

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	1.2944	1.749	2.1795	1.9281	1.9719	1.9113
2	.2743	1.2944	1.7661	2.146	1.9113	1.9033	1.8945
3	.2743	1.3435	1.7318	2.0454	1.9113	1.9376	1.9616
4	.2743	1.4091	1.7833	2.079	1.6598	2.0062	1.9951
5	.2743	1.4255	1.8347	2.1293	1.6933	2.1605	2.0119
6	.2743	1.4746	1.9719	2.1125	1.7772	2.2291	.9221
7	3.0178						
8	3.3532						
9	2.9172						
10	2.8334						
11	2.5819						
12	2.6322						
13	2.6993						
14	2.5819						
15	2.2634	2.8502		2.649	2.8978		2.7161
16	2.2298	2.9005	1.5947	2.6322	3.0693		2.7161
17	2.1963	3.0011			3.1893		2.7831
18	2.2466	3.1017	2.4177		2.8292		2.7664
19	2.3472	2.5149	2.5377	2.7831	3.0693		2.6993
20	2.2131	2.0287	2.7435	2.7161	3.0007		2.6658
21	1.9784	1.8442	2.7435	2.5149	2.7435		2.6155
22	1.9784	1.6263	2.5034	2.3472	2.4863		2.1963
23	1.3748	1.6766	2.3472	1.9113	2.1605		1.8275
24	1.3717	1.3108	1.8004	2.3137	1.9951	2.0576	1.9281
Max	3.3532	3.1017	2.7435	2.7831	3.1893	2.2291	2.7831
Min	.2743	1.2944	1.5947	1.9113	1.6598	1.9033	.9221
Avg	1.8526	1.9435	2.1089	2.3257	2.3951	2.0380	2.2257

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274027 / WARWADE

Feeder No / Name : 205 / Palwan ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.4096	2.2634	1.6263	1.4083	1.8004	2.3472
2	.4801	.3605	2.2291	1.6095	1.4083	1.7147	2.364
3	.4801	.5735	2.2462	1.576	1.3916	1.8176	2.3975
4	.6173	.6226	2.2634	1.6263	1.4754	1.8861	2.431
5	.6859	.7373	2.2977	1.643	1.5592	1.989	2.4813
6	.823	.9012	2.7778	2.2969	2.0622	2.0576	2.7496
7	2.0957						
8	2.2634						
9	2.0287						
10	1.8778						
11	1.7436						
12	1.6766						
13	1.7269						
14	1.6598						
15	2.7161	2.0287		1.9448	2.0405		2.0957
16	2.6322	2.1795	1.8519	2.1795	2.1605		2.1628
17	2.6658	2.3472			2.2291		2.079
18	2.6825	2.2634	2.1948		1.9376		2.079
19	2.6379	2.0957	2.0919	2.4478	2.0405		1.8945
20	2.5652	1.6598	2.0405	2.2298	1.9204		1.8945
21	2.364	1.4091	2.0576	2.0287	1.7318		1.8442
22	.7545	1.3413	1.6632	1.9784	1.9376		1.7269
23	.4588	2.3472	1.5592	1.4083	1.9719		2.0957
24	1.3717	.4096	2.5377	1.5927	1.4586	1.8861	2.3807
Max	2.7161	2.3472	2.7778	2.4478	2.2291	2.0576	2.7496
Min	.4588	.3605	1.5592	1.4083	1.3916	1.7147	1.7269
Avg	1.6453	1.3554	2.1482	1.8706	1.7958	1.8788	2.1890

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274027 / WARWADE

Feeder No / Name : 206 / Hole Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274134 / 33/11 KV ALEGAON S/S

Feeder No / Name : 201 / Gaonthan

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524					
2	.1524	.1524					
3	.2286	.2286					
4	.3048	.381					
5	.381	.4572					
6	.4572	.4572					
7	.381	.381					
8	.3048	.3048	.3048	.3048	.3048	.3353	
9	.3048	.3048					
10	.2286	.1524					
11	.1524	.1524					
12	.1524	.1524					
14	.1524						
15	.1524						
16	.1524		.1219	.1524	.2286	.1524	.1524
17	.1524						
18	.2286	.1524					
19	.2286	.3048					
20	.3048	.3048					
21	.3048	.2286					
22	.3048	.2286					
23	2.3167	.1524	.1524	.1524	.3353	.2286	.2286
24	1.3717	.1524	.1524	.1524	.1524	.3048	.1829
Max	2.3167	.4572	.3048	.3048	.3353	.3353	.2286
Min	.1524	.1524	.1219	.1524	.1524	.1524	.1524
Avg	.3857	.2527	.1829	.1905	.2553	.2553	.1880

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274134 / 33/11 KV ALEGAON S/S

Feeder No / Name : 202 / Alegaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524					
2	.1524	.1524					
3	.1524	.1524					
4	.1524	.1524					
5	.1524	.1524					
6	.1524	.1524					
7	1.3717	2.2862					
8	1.5242	2.2862	2.1338	2.4387	1.829	2.1338	2.21
9	1.6766	2.4387					
10	1.6766	2.4387					
11	1.829	2.4387					
12	1.829						
13	1.829						
14	1.829						
19	.1524	.1524					
20	.1524	.1524					
21	.1524	.1524					
22	.1524	.1524					
23	.1524	.1524	.1524	.1524	.1524	.1524	.1524
24	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Max	1.829	2.4387	2.1338	2.4387	1.829	2.1338	2.21
Min	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Avg	.7697	.8069	.8129	.9145	.7113	.8129	.8383

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274134 / 33/11 KV ALEGAON S/S

Feeder No / Name : 203 / Garakole

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524					
2	.1524	.1524					
3	.1524	.1524					
4	.1524	.1524					
5	.1524	.1524					
6	.1524	.1524					
15	1.5242						
16	1.5242		1.448	1.829	1.829	2.1338	1.829
17	1.829						
18	1.829	1.5242					
19	1.5242	1.5242					
20	1.5242	1.5242					
21	1.5242	1.3717					
22	1.5242	1.3717					
23	.1524	.1524	.1524	.1524	.1524	.1524	.1524
24	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Max	1.829	1.5242	1.448	1.829	1.829	2.1338	1.829
Min	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Avg	.8764	.6566	.5843	.7113	.7113	.8129	.7113

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274134 / 33/11 KV ALEGAON S/S

Feeder No / Name : 204 / TAKALI BANDHARA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274134 / 33/11 KV ALEGAON S/S

Feeder No / Name : 205 / CHANDAJ

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762					
2	.0762	.0762					
3	.0762	.0762					
4	.0762	.0762					
5	.0762	.0762					
6	.0762	.0762					
7	.2286	.7621					
8	.3048	.7621	.4268	.6097	.4572	.5335	.4572
9	.381	.4572					
10	.381	.4572					
11	.381	.3048					
12	.4572						
13	.3048						
14	.3048						
16				.3048	.4572		
19	.0762	.0762					
20	.0762	.0762					
21	.0762	.0762					
22	.0762	.0762					
23	.0762	.0762	.0762	.0762	.0762	.0762	.0762
24	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Max	.4572	.7621	.4268	.6097	.4572	.5335	.4572
Min	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Avg	.1829	.2152	.1931	.2667	.2667	.2286	.2032

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274134 / 33/11 KV ALEGAON S/S

Feeder No / Name : 206 / 11 KV RUI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219	.1067					
2	.1219	.12					
3	.1219	.1219					
4	.1524	.1219					
5	.1524	.1524					
6	.1524	.1524					
8				.1524			
15	1.6766						
16	1.6766		1.7528	1.829	2.1033	2.1948	1.9814
17	1.6004						
18	1.6004	1.5242					
19	1.6004	1.6766					
20	1.5242	1.6766					
21	1.3717	1.5242					
22	1.2955	1.5242					
23	.1067	.1067	.1524	.0762	.0762	.0762	.0762
24	.1067	.1067	.1524	.1524	.0762	.0762	.0762
Max	1.6766	1.6766	1.7528	1.829	2.1033	2.1948	1.9814
Min	.1067	.1067	.1524	.0762	.0762	.0762	.0762
Avg	.8364	.6857	.6859	.5525	.7519	.7824	.7113

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274149 / 33/11 KV ARAN S/S

Feeder No / Name : 201 / ARAN

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.9145		.7621
2			.9907		.7621
3			1.0669		.8383
4			1.3717		.9145
5			1.6766		1.0669
6			2.1338		2.21
7			2.1338		3.0483
8			2.21		2.4387
19		.2286		.1524	
20		.2286		.2286	
21		.2439		.2286	
22		.2134		.1829	
23		.1829		.1829	
24	1.3717		.1524		.1829
Max	1.3717	.2439	2.21	.2286	3.0483
Min	1.3717	.1829	.1524	.1524	.1829
Avg	1.3717	.2195	1.4056	.1951	1.3582

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274149 / 33/11 KV ARAN S/S

Feeder No / Name : 202 / JADHAVWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1829		.1829
2			.2286		.1981
3			.2286		.1981
4			.3048		.2286
5			.3048		.3048
6			.3353		
16		2.0576			
17		2.0576		2.2862	
18		2.0271		2.2862	
19		1.9052		1.9052	
20		1.6766		1.5242	
21		1.3717		1.448	
22		1.0669		1.2955	
23		1.0669		1.2193	.3353
24	1.5241		1.0669		.9907
Max	1.5241	2.0576	1.0669	2.2862	.9907
Min	1.5241	1.0669	.1829	1.2193	.1829
Avg	1.5241	1.6537	.3788	1.7092	.3484

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274149 / 33/11 KV ARAN S/S

Feeder No / Name : 203 / TULSHI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3048		.3048
2			.3048		.3048
3			.3048		.3353
4			.381		.381
5			.4268		.4115
6			.4572		.4572
9		2.2862		2.8959	
10		2.4387		2.7435	
11		2.5911		2.5911	
12		2.5149		2.6368	
13		2.4844		2.4844	
14		2.4387		2.4387	
15		2.4691		2.3929	
16		2.6825		2.3777	
19		.381		.3048	
20		.4572		.381	
21		.4572		.381	
22		.4572		.3353	
23		.381		.3048	
24	1.3717		.3048		.3048
Max	1.3717	2.6825	.4572	2.8959	.4572
Min	1.3717	.381	.3048	.3048	.3048
Avg	1.3717	1.6953	.3549	1.7129	.3571

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274176 / 33/11kV SURLI

Feeder No / Name : 201 / AKOLE(KH) AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.3717	.4725	.6443	.3963	.2572	.6001	.3544
Max	1.3717	.4725	.6443	.3963	.2572	.6001	.3544
Min	1.3717	.4725	.6443	.3963	.2572	.6001	.3544
Avg	1.3717	.4725	.6443	.3963	.2572	.6001	.3544

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274176 / 33/11kV SURLI

Feeder No / Name : 202 / SHIRAL (T) AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274176 / 33/11kV SURLI

Feeder No / Name : 203 / SURLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.3717	.2134	.2454	.1829	.1219	.1677	.1715
Max	1.3717	.2134	.2454	.1829	.1219	.1677	.1715
Min	1.3717	.2134	.2454	.1829	.1219	.1677	.1715
Avg	1.3717	.2134	.2454	.1829	.1219	.1677	.1715



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274176 / 33/11kV SURLI

Feeder No / Name : 204 / SHIRAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.2614	.2427	.2279		.2801	.3174	.2804
16	.2241	.104		.1867	.112	.1187	.1307
24	.1867	.2054	.1734	.1715	.2054	.2054	.197
Max	.2614	.2427	.2279	.1867	.2801	.3174	.2804
Min	.1867	.104	.1734	.1715	.112	.1187	.1307
Avg	.2241	.1840	.2007	.1791	.1992	.2138	.2027

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274186 / Parite

Feeder No / Name : 201 / KALWEL WASTI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2862	.1524	.061	.0457	.0469	.0474	.061
2	2.271	.1524	.061	.061	.0469	.0474	.061
3	2.2558	.1524	.061	.061	.0474	.0474	.061
4	2.2558	.1677	.061	.061	.0469	.0633	.061
5	2.271	.1829	.0762	.0762	.0781	.0633	.0762
6	2.271	.1829	.0914	.0914	.0937	.0791	.0762
7			2.0309	1.89	2.0241	1.829	1.8976
8			2.0622	1.9357	2.0557	1.829	1.8976
9			2.0934		2.0873	1.7985	1.8976
10		1.829	2.0934		2.0557	1.7985	2.0557
11		1.9814	2.0934		2.0083	1.829	2.0557
12		1.9509	2.0153	1.9814	2.0873	1.7985	2.0557
13		1.9814	2.0309	1.9509	2.0557	1.7985	2.0399
14		1.9966	1.9841	1.9052	1.9766	1.7985	1.9925
19	.1677	.061	.0469	.0469	.0633	.0762	.0474
20	.1524	.061	.0625	.0469	.0633	.0762	.0457
21	.1524	.061	.0457	.0469	.0474	.0762	.0457
22	.1524	.061	.0457	.0469	.0474	.061	.0457
23	.1524	.061	.0457	.0469	.0474	.061	.061
24	1.3717	.1524	.061	.0457	.0469	.0474	.061
Max	2.2862	1.9966	2.0934	1.9814	2.0873	1.829	2.0557
Min	.1524	.061	.0457	.0457	.0469	.0474	.0457
Avg	1.3133	.6581	.8561	.6082	.8513	.7613	.8298

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274186 / Parite

Feeder No / Name : 202 / KADAM WASTI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219	.1219	.1219	.0457	.0648	.0305	.0457
2	.1219	.1219	.1219		.0648	.0305	.0457
3	.1219	.1219	.1219	.0457	.0648	.0305	.0457
4	.1219	.1372	.1372	.0457	.081	.0305	.061
5	.1219	.1524	.1524	.061	.081	.0457	.061
6	.1219	.1524	.1524	.061	.081	.0457	.061
7	1.5242						
8	1.4327						
9	1.387						
10	1.6004						
11	1.829						
12	1.829						
13	1.829						
14	1.829	1.829					
15		1.829	2.0081	1.9433	1.8595	1.6004	
16		1.8442	1.9757	2.0243	1.9357	1.6004	1.8785
17		1.7528	1.9757	2.0081	1.7071	1.6766	1.9109
18		2.1948	1.9595	1.9595	1.6918	1.829	1.9271
19	.1219	1.7375	1.9433	1.9433	1.7223	1.7528	1.9109
20	.1219	1.7375	1.9433	1.9662	1.7071	1.448	1.6766
21	.1219	1.7375	1.6766	1.0688	1.6918	1.448	1.6766
22	.1219	1.7375	1.6766	1.4575	1.7223	1.448	1.6766
23	.1219	.1067	.061	.0648	.0305	.0457	.0762
24	.1219	.1219	.1067	.0457	.0648	.0305	.0457
Max	1.829	2.1948	2.0081	2.0243	1.9357	1.829	1.9271
Min	.1219	.1067	.061	.0457	.0305	.0305	.0457
Avg	.7362	1.0257	1.0084	.9827	.9106	.8183	.8733

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274186 / Parite

Feeder No / Name : 203 / PARITE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.192	1.0279	2.2138	1.6446	2.2455	2.2613	2.1338
2	.2241	1.0279	2.2138	1.6288	2.2455	2.3087	2.1338
3	.2241	1.0279	2.2613	1.7236	2.2929	2.3562	2.1338
4	.2881	1.0279	2.372	1.866	2.3878	2.451	2.1795
5	.3201	1.1069	2.451	2.2771	2.5301	2.5459	2.3167
6	.3361	1.1702	2.5143	2.5459	2.5775	2.6408	2.4234
15	1.5813						
16	1.5813						
17	1.5813						
18	1.6604						
19	1.5181	.3163	.3125	.3321	.2372	.3048	.253
20	1.4548	.3005	.2968	.3163	.2846	.3048	.2688
21	1.1385	.2846	.2846	.2846	.3321	.3048	.2688
22	1.0595	.2688	.253	.253	.2688	.2743	.253
23	1.0279	2.1822	1.5181	2.2929	2.2613	2.1338	1.9134
24	.192	1.0279	2.2138	1.7236	2.2771	2.2613	2.1338
Max	1.6604	2.1822	2.5143	2.5459	2.5775	2.6408	2.4234
Min	.192	.2688	.253	.253	.2372	.2743	.253
Avg	.8987	.8974	1.5754	1.4074	1.6617	1.6790	1.5343

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274187 / Dahiwali

Feeder No / Name : 201 / UPALWATE BOGADA AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.9145
Max	.9145
Min	.9145
Avg	.9145

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274187 / Dahiwali

Feeder No / Name : 202 / DAHIWALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2134	.2134	.1829	.1829	.2134	.1829	.2134
2	.2134	.2134	.1829	.1829	.2134	.1829	.2134
3	.2134	.2134	.1829	.1829	.2134	.1829	.2134
4	.2134	.2134	.1829	.1829	.2439	.1829	.2134
5	.2134	.2134	.1829	.1981	.2439	.1981	.2134
6	.2134	.2134	.1981	.2134	.2439	.1981	.2134
9	2.5606						
10	2.9264						
11	2.9721						
12	2.774						
13	2.4996						
14	2.3624						
15	2.3472						
16	2.3472						
17		3.0026	2.5606	2.8959	3.0483		3.1093
18		3.0788	2.6825	2.9264	3.1855		3.1398
19		2.9416	2.713	2.8959	2.8959		3.0483
20	.1829	2.6978	2.3777	2.8959	2.652		2.6978
21	.1981	2.5606	2.2862	2.7435	2.5301		2.4691
22	.2134	2.3929	2.1643	2.7435	2.4539		2.3015
23	.2134	2.2558	2.0119	2.7435	2.3472		2.271
24	.2134	.2134	2.1948	1.9814	2.7435	2.2253	2.2862
Max	2.9721	3.0788	2.713	2.9264	3.1855	2.2253	3.1398
Min	.1829	.2134	.1829	.1829	.2134	.1829	.2134
Avg	1.2153	1.4589	1.4360	1.6407	1.6592	.4790	1.6145

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274187 / Dahiwali

Feeder No / Name : 203 / DAHIWALI BOGADA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	2.3167	2.2862	2.2558	2.1338	2.4387	2.1338
2	.1524	2.3777	2.3167	2.2862	2.1338	2.4691	2.1338
3	.1524	2.3777	2.3624	2.3167	2.1338	2.4691	2.2862
4	.1524	2.4996	2.4082	2.3472	2.3472	2.4844	2.3777
5	.1677	2.4996	2.4691	2.4082	2.3472	2.5911	2.4387
6	.1829	2.5149	2.5911	2.4387	2.4387		2.4387
7		2.6673	2.6368	2.6216	2.4996	2.6216	2.4387
8		2.652	2.3929	2.3472	2.4996	2.4387	2.2862
17	2.713						
18	2.713						
19	2.7435						
20	2.5911	.381	.2439	.1829	.2439	.2743	.2591
21	2.3472	.381	.2439	.1829	.2439	.2743	.2591
22	2.3472	.3201	.2439	.1829	.2439	.2743	.2439
23	2.3777	.2896	.2439	.1829	.2286	.2439	.2401
24	2.2862	2.3167	.2591	.2134	.1829	2.4387	.2439
Max	2.7435	2.6673	2.6368	2.6216	2.4996	2.6216	2.4387
Min	.1524	.2896	.2439	.1829	.1829	.2439	.2401
Avg	1.5057	1.8149	1.5922	1.5359	1.5136	1.7515	1.5215

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274193 / MIDC TEMBHURNI

Feeder No / Name : 201 / MIDC TEMBHURNI  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.4801	.3429	.3772	.3944	.3944	.3086
2	.4458	.4458	.3429	.3601	.3601	.3601	.3086
3	.3963	.4458	.3429	.3601	.3258	.3258	.3086
4	.463	.463	.3429	.3601	.3086	.3086	.3086
5	.4801	.4801	.3429	.3429	.2743	.2743	.3258
6	.463	.4115	.3086	.2743	.2229	.2229	.2743
7	.4115	.3429	.3086	.2743	.3086	.2743	.2743
8	.463	.2572	.3086	.3258	.3429	.3086	.3429
9	.5144	.3429	.4287	.4115	.6516	.4115	.4287
10	.5316	.5316	.583	.5144	.6859	.5487	.4287
11	.6344	.6173	.6344	.6687	.7202	.6516	.5144
12	.6344	.5144	.6516	.7202	1.0631	.583	.5144
13	.5316		.5144	.6173	.6344	.5487	.4287
14	.5658	.6859	.5316	.6173	.6687	.5487	.4287
15	.7202		.703	.6344	.9259	.5658	.463
16	.6173		.5658	.583	.8402	.6001	.463
17	.5658	.463	.5658	.6001	.6516	.4801	.5144
18	.6687	.463	.5316	.6001	.6173	.5144	.4287
19	.5658	.3429	.5487	.5658	.6859	.5316	.4287
20	.5144	.3772	.4801	.5144	.6516	.4801	.5144
21	.5658	.3772	.4801	.5144	.6173	.4801	.5144
22	.583	.3772	.5144	.4801	.4801	.463	.5144
23	.5144	.3429	.4115	.4287	.4973	.4115	.4287
24	.4801	.4801	.3429	.3772	.3944	.4287	.4115
Max	.7202	.6859	.703	.7202	1.0631	.6516	.5144
Min	.3963	.2572	.3086	.2743	.2229	.2229	.2743
Avg	.5338	.4401	.4637	.4801	.5551	.4465	.4115



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274193 / MIDC TEMBHURNI

Feeder No / Name : 202 / KANHERGAON AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2896	.2896	.3429	.3086	.2896	.2896	1.749
2	.2896	.2896	.3429	.3086	.3258	.2896	1.8004
3	.2743	.2743	.3429	.3086	.3048	.3048	1.8861
4	.3048	.3048	.3429	.3086	.3048	.3048	2.0233
5	.3201	.3201	.3429	.3086	.3353	.3353	2.0919
6	.3353	.3353	.3429	.3258	.3353	.3048	2.1091
7							2.5377
8							2.6749
9	2.5911	2.6578	2.4006	1.749	2.2862	2.8807	
10	2.6825	2.6406	2.5892	1.9662	2.6578	3.2236	
11	2.8045	2.8464	2.5892	2.21	1.6156	3.1722	
12	2.8959	2.6749	2.6749	2.2253	2.2558	3.1036	
13	2.7892	2.7092	2.7092	2.3015	2.6063	3.0178	
14	2.6216	2.2291	2.5549	2.2862	2.3777	2.915	
15	2.5758	2.3663	2.4177	2.1948	2.332	2.9835	
16	2.5149	2.4006	2.4177	2.1795	2.4082	2.7435	
20	.2896	.3429	.3258	.2591	.3048	.2401	.2229
21	.2591	.3429	.3258	.2896	.2743	.2401	.2229
22	.2743	.3429	.3086	.2896	.2896	.2229	.2229
23	.2896	.3429	.3086	.3048	.2896	1.5947	1.7147
24	.2743	.2743	.3429	.3086	.3258	.2896	1.6804
Max	2.8959	2.8464	2.7092	2.3015	2.6578	3.2236	2.6749
Min	.2591	.2743	.3086	.2591	.2743	.2229	.2229
Avg	1.2987	1.2623	1.2643	1.0754	1.1536	1.4977	1.6105

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274193 / MIDC TEMBHURNI

Feeder No / Name : 203 / VENEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1584	1.1584	2.0576	1.6289	1.7223	1.7223	.4458
2	1.1888	1.1888	2.0576	1.8004	1.7833	1.7833	.4458
3	1.2803	1.2803	2.0576	2.0233	1.829	1.829	.4458
4	1.4784	1.4784	2.2291	2.4006	1.89	1.89	.4801
5	1.7223	1.7223	2.4006	2.5377	2.0881	2.0881	.4801
6	2.4387	.7621	2.6578	2.5892	2.3472	2.3472	.4801
7	2.5453	.7773	3.2579	2.8292	2.6825	2.4234	
8	2.3777	2.2405	2.915		2.4082	2.4691	
9							2.572
10							2.915
11							3.0007
12							2.7435
13							2.572
14							2.572
15							2.572
16							2.572
20	.3048	.3944	.4973	.3963		.4458	.3772
21	.3506	.3944	.4801	.3658	.2743	.4458	.3772
22	.381	.3944	.4801	.3658	.2896	.4287	.3772
23	1.1584	1.5432	1.4575	1.7071	1.6461	.4287	.3772
24	1.2193	1.2193	1.5432	1.5089	1.6613	1.6309	.4287
Max	2.5453	2.2405	3.2579	2.8292	2.6825	2.4691	3.0007
Min	.3048	.3944	.4801	.3658	.2743	.4287	.3772
Avg	1.3542	1.1195	1.8532	1.6794	1.7185	1.5333	1.3808

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274209 / 33/11 KV BHEND SUB STATION

Feeder No / Name : 201 / 11 KV BHEND AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.448	1.6156	.2743	.2591	.2591	.2743	.3048
2	1.448	1.6766	.3353	.2439	.2743	.3048	.3353
3	1.4784	1.7375	.3658	.381	.2896	.3048	.3658
4	1.4784	1.829	.3963	.3963	.3201	.3353	.3963
5	1.6766	1.8747	.4268	.3506	.3506	.381	.4268
6	2.1643	1.9509	.4268	.3658	.3506	.4268	.4572
7	2.4082						
8	.7621						
9		2.1948	2.4996		2.3624	2.4234	2.3777
10		2.2862	2.1948		2.0576	2.3777	1.7071
11		1.0974			1.89	2.0424	2.1338
12		2.1948	2.3167	1.5699	1.9814	2.4996	2.21
13		1.7985	2.1491	1.9052	2.0881	2.1338	1.4784
14		1.7375	2.1795	1.9814	2.1795	2.1643	2.0424
15		1.8595	1.4784		2.2558	2.1338	2.1491
16		1.9509	1.9052		2.3167	2.0729	2.1643
19	.2286	.2439	.2591		.2743	.2439	.2743
20	.2439	.3353	.1524	.2743	.2591	.2439	.2286
21	.2743		.2439	.2591	.2743	.2439	.3201
22	.2439	.2439	.3201	.2286	.2439	.2743	.2743
23	1.5546	.2439	.1981	.2286	.2591	.2743	.3658
24	1.448	1.5851	.2439	.2591	.2286	.2286	.3048
Max	2.4082	2.2862	2.4996	1.9814	2.3624	2.4996	2.3777
Min	.2286	.2439	.1524	.2286	.2286	.2286	.2286
Avg	1.2041	1.4977	.9666	.6216	1.0258	1.0692	1.0158

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274231 / TAKALI (T) S/S

Feeder No / Name : 203 / MAHALAXMI TAKALI  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
1	1.3717
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274232 / MITKALWADI S/S

Feeder No / Name : 201 / MITKALWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6409	1.6156	1.1203	1.3123	1.4243	1.4737	.0572
2	1.6221	1.6461	1.1363	1.3283	1.4243	1.4723	.0667
3	1.5074	1.5394	1.1363	1.3283	1.4403	1.4723	
4	1.5524	1.5699	1.1363	1.3279	1.4403	1.4723	
5	1.6324	1.347	1.1523	1.2163	1.4746	1.5203	
6	1.6876	1.347	1.2146	1.2643	1.4723	1.6032	
7	1.6964	1.2936	1.4243	1.4529	1.6804	1.7124	
8	1.7532	1.2803	1.5203	1.4661	1.6644	1.7328	
10							2.0805
11							1.9997
12							2.1605
13							2.1451
14							2.1605
15	.0857	.0914	.1578	.1054	.0914	.0762	2.2405
16	.0857	.1677	.208	.1054	.0937	.0762	2.2558
17	.0762	.1372	.1402	.1054		.0381	.1402
18	.0857	.1067	.1402	.04		.0762	.1227
19	.0857	.0762	.1402	.052		.0762	.1227
20	.0762	.1067	.156	.0669	.0937	.0762	.1402
21	.0762	.1219	.156	.0617	.1067	.0667	.1227
22	.0857	.1067	.1753	.1355	.1219	.0476	.1227
23	1.6156	1.085	1.1633	1.3923	1.4083	.0572	.1402
24	1.6385	1.6004	1.1069	1.2631	1.4083	1.4723	.0572
Max	1.7532	1.6461	1.5203	1.4661	1.6804	1.7328	2.2558
Min	.0762	.0762	.1402	.04	.0914	.0381	.0572
Avg	.9446	.8466	.7436	.7791	1.0230	.8068	.9491

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274232 / MITKALWADI S/S

Feeder No / Name : 202 / MALEGAON CANAL AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.3601	.2812	.4115	.3311		2.0881
2	.1257	.3429	.2968	.4115	.3612		2.1338
3							2.1186
4							2.2348
5							2.2672
6							2.332
7							2.332
8							2.2497
9	2.7526	2.6558	2.4905	2.1559	2.4646	2.5617	
10	2.8589		2.7282	2.7035	2.8673	2.915	
11	2.8589	2.834	2.7092	2.7854	2.5888	2.9312	
12	2.7587	2.9165	2.6558	2.6543	2.8841	2.734	
13	2.5758	2.7854	2.7652	2.5621	2.8012	2.7496	
14	2.5606	2.6397	2.6406	2.5621	2.7515	2.4387	
15	2.5758	2.4806	2.6086	2.4528	2.4366	2.4684	.1753
16	2.4539	2.5286	2.4615	2.5286	2.6023	2.3903	.2454
17	.3429	.2214	.1734	.1656	.2846	.2134	
18	.3429	.2056	.2454	.2107	.2846		
19	.3601	.2656	.3814	.3311	.2401		
20	.3429	.3593	.4287	.3612	.3841		
21	.3086	.3593	.4287	.3311			
22	.3429	.253	.4287	.3311			
23	.3772	.2031	.4115	.3462		1.9814	1.8842
24	.3161	.3429	.2778	.4115	.3462		2.0119
Max	2.8589	2.9165	2.7652	2.7854	2.8841	2.9312	2.332
Min	.1143	.2031	.1734	.1656	.2401	.2134	.1753
Avg	1.3538	1.2796	1.3563	1.3176	1.5752	2.3384	1.8394

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278022 / 220/33 kV TEMBHURNI EHV

Feeder No / Name : 401 / 33 KV Tembhorni

Feeder KV- 33 / INCOMING

DATE	01-AUG-17
HR	Load (MW)
24	4.6296
Max	4.6296
Min	4.6296
Avg	4.6296

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278022 / 220/33 kV TEMBHURNI EHV

Feeder No / Name : 402 / 33 KV Bhend

Feeder KV- 33 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	4.1152
Max	4.1152
Min	4.1152
Avg	4.1152



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278022 / 220/33 kV TERMBHURNI EHV

Feeder No / Name : 403 / 33 KV Pimpalner

Feeder KV- 33 / INCOMING

DATE	01-AUG-17
HR	Load (MW)
24	4.1152
Max	4.1152
Min	4.1152
Avg	4.1152

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278022 / 220/33 kV TEMBHURNI EHV

Feeder No / Name : 404 / 33 KV Bemble

Feeder KV- 33 / INCOMING

DATE	01-AUG-17
HR	Load (MW)
24	4.6296
Max	4.6296
Min	4.6296
Avg	4.6296

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278022 / 220/33 kV TEMBHURNI EHV

Feeder No / Name : 405 / 33 KV Adhegaon

Feeder KV- 33 / INCOMING

DATE	01-AUG-17
HR	Load (MW)
24	4.1152
Max	4.1152
Min	4.1152
Avg	4.1152

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278022 / 220/33 kV TERMBHURNI EHV

Feeder No / Name : 406 / 33 KV Kandhar (Surli)

Feeder KV- 33 / INCOMING

DATE	01-AUG-17
HR	Load (MW)
24	4.1152
Max	4.1152
Min	4.1152
Avg	4.1152

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278022 / 220/33 kV TERMBHURNI EHV

Feeder No / Name : 407 / 33 KV MIDC

Feeder KV- 33 / INCOMING

DATE	01-AUG-17
HR	Load (MW)
24	4.1152
Max	4.1152
Min	4.1152
Avg	4.1152

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278022 / 220/33 kV TERMBHURNI EHV

Feeder No / Name : 408 / JINDAL EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.463	.6173	.4115		.3601	.7202	.1029
2	.4115	.6173	.4115		.3086	.7202	.1029
3	.4115	.6173	.4115		.3086	.7202	.1029
4	.3601	.6173	.4115		.2572	.7202	.1029
5	.3601	.6173	.4115		.2572	.7202	.1029
6	.3086	.6173	.4115		.2058	.7202	.1029
7	.3086	.6173	.4115		.2058	.7202	.1029
8	.2572	.6173	.4115	.2058	.2058	.7202	.1029
9	.463	.6173	.6173		.6687	.3086	.5144
10	.6173	.6173	.6173		.6687	.3086	.5144
11	.6173	.6173	.7202		.7202	.3086	.5144
12	.6687	.6173	.7202		.7202	.3086	.5144
13	.6687	.6173	.7202		.823	.3086	.5144
14	.5144	.6173	.7202		.823	.3086	.5144
15	.5144	.6173	.7202		.823	.3086	.5144
16	.5144	.6173	.7202	.8745	.8745	.4115	.5144
17		.5144		.6173	.9259	.1029	
18	.7716	.5144		.6173	1.0288	.1029	
19	.7716	.5144		.5144	1.0288	.1029	
20	.7716	.5144		.5144	1.0288	.1029	
21	.7716	.5144		.5658	1.0288	.1029	
22	.7716	.5144		.5658	1.0288	.1029	
23	.7716	.5144		.5144	1.0288	.1029	
24	.5658	.7716	.5144	.5144	.5144	1.0288	.1029
Max	.7716	.7716	.7202	.8745	1.0288	1.0288	.5144
Min	.2572	.5144	.4115	.2058	.2058	.1029	.1029
Avg	.5502	.5937	.5507	.5504	.6601	.4201	.2965

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278022 / 220/33 kV TERMBHURNI EHV

Feeder No / Name : 409 / MILLENIUM EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	1.1317	1.2346		1.1831	1.2346	1.0288
2	1.1831	1.1317	1.2346		1.1831	1.2346	1.0288
3	1.1831	1.1317	1.2346		1.2346	1.1831	1.0288
4	1.1831	1.1317	1.2346		1.2346	1.1831	1.0288
5	1.1317	1.1317	1.2346		1.1831	1.1831	1.0288
6	1.1317	1.1317	1.2346		1.1317	1.1831	1.0288
7	1.1317	1.1317	1.2346		1.1317	1.1831	1.0288
8	1.0802	1.1317	1.2346	1.0802	1.0802	1.1831	1.0288
9	1.1831	1.1317	1.3889		1.0288	.2572	1.0288
10	1.1831	1.1317	1.3889		.9774	.2572	1.0288
11	1.1831	1.1317	1.3889		.9774	.2572	1.0288
12	1.2346	1.1317	1.3889		.9259	.2572	1.0288
13	1.2346	1.1317	1.3889		.9259	.2572	1.0288
14	1.286	1.1317	1.3889		.8745	.2572	1.0288
15	1.286	1.1317	1.3889		.8745	.2572	1.0288
16	1.286	1.1317	1.3889	.823	.823	.2572	1.0288
17	1.1317	1.2346		1.3375	1.286	1.0288	
18	1.1317	1.2346		1.3375	1.286	1.0288	
19	1.1317	1.2346		1.2346	1.286	1.0288	
20	1.1317	1.286		1.1831	1.286	1.0288	
21	1.1317	1.286		1.1831	1.286	1.0288	
22	1.1317	1.286		1.2346	1.286	1.0288	
23	1.1317	1.286		1.286	1.286	1.0288	
24	1.1317	1.1317	1.286	1.286	1.286	1.286	1.0288
Max	1.286	1.286	1.3889	1.3375	1.286	1.286	1.0288
Min	1.0802	1.1317	1.2346	.823	.823	.2572	1.0288
Avg	1.1703	1.1703	1.3102	1.1986	1.1274	.8380	1.0288

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278022 / 220/33 kV TEMBHURNI EHV

Feeder No / Name : 410 / STATION T/F

Feeder KV- 33 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	4.1152
Max	4.1152
Min	4.1152
Avg	4.1152



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278022 / 220/33 kV TEMBHURNI EHV

Feeder No / Name : 411 / Deveer Decor Express NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	4.6296
Max	4.6296
Min	4.6296
Avg	4.6296

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278022 / 220/33 kV TERMBHURNI EHV

Feeder No / Name : 801 / 220 KV EHV VSSSKL (CO GEN)

FE Feeder KV- 220 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	27.4349
Max	27.4349
Min	27.4349
Avg	27.4349

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278023 / 220/33 kV INDAPUR EHV

Feeder No / Name : 401 / 33kV SMC UJANI

Feeder KV- 33 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-AUG-17
HR	Load (MW)
24	4.6296
Max	4.6296
Min	4.6296
Avg	4.6296

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278023 / 220/33 kV INDAPUR EHV

Feeder No / Name : 402 / 132 KV EHV SEENA MADHA

(LIS AG Feeder KV- 132 /  
OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	16.4609
Max	16.4609
Min	16.4609
Avg	16.4609

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278023 / 220/33 kV INDAPUR EHV

Feeder No / Name : 403 / 132 KV SHIVRATNA (CO GEN)

ALEG Feeder KV- 132 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	16.4609
Max	16.4609
Min	16.4609
Avg	16.4609

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278023 / 220/33 kV INDAPUR EHV

Feeder No / Name : 404 / 132 KV EHV HYDRO

GENERATION (U Feeder KV- 132 /  
OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	16.4609
Max	16.4609
Min	16.4609
Avg	16.4609

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274028 / 33/11 KV ANDHALGAON

SUBSTATION

Feeder No / Name : 201 / 11 KV KHUPSANGI FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.6706	.6097			.9907	1.0669
2	.1829	.6706	.5487			.9907	1.0669
3	.2134	.9145	.5487			1.0364	1.0669
4	.3048	1.0059	.5792			1.0974	1.1888
5	.3658	1.3717	1.2193			1.0974	1.2193
6	.3658	1.4327	1.3717			1.2193	1.2498
7	.3048	1.4937	1.1736			1.2193	1.3413
8	.3048	1.3717	1.2955	1.4022		1.1431	1.1888
9	.945	.1524	.2286	.1829			
10	1.4752	.1524	.1677	.1677			
11	1.2955	.1524	.1219	.1219			
12	1.2955	.0762	.1067	.1219			
13	1.2498	.0762	.1067	.1219			
14	1.448	.1067	.1067	.1219			
15	1.4022	.1067	.1067				
16	.8688	.1067	.1219	.1219	1.0364	.1219	
17	.0914	.1067			.1829	.1067	
18	.2134	.1524			.2134	.2134	
19	.2439	.2134			.2591	.2591	
20	.2286	.1433			.2743	.3048	
21	.2591	.2743			.3201	.2896	
22	.2134	.2286			.2286	.1829	
23	.6859				.9907	1.0364	
24	.1524	.6706	1.1431			.9907	1.0669
Max	1.4752	1.4937	1.3717	1.4022	1.0364	1.2193	1.3413
Min	.0914	.0762	.1067	.1219	.1829	.1067	1.0669
Avg	.5943	.5065	.5621	.2953	.4382	.7235	1.1617

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274028 / 33/11 KV ANDHALGAON

SUBSTATION

Feeder No / Name : 202 / 11KV ANDHALGAON FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.6706	.4572			1.2955	1.3717
2		.6706	.4572			1.2955	1.3717
3		.884	.5487			1.2955	1.4022
4	.2591	.9145	.5792			1.4022	1.448
5	.3048	1.0059	.7621			1.5242	1.5546
6	.3048	1.0669	1.0669			1.7528	1.829
7	.3353	1.0669	1.1431			.381	1.4784
8	.3048	1.0364	1.1888	1.2193		.3353	1.9814
9	.884	.1829	.1524	.1829			
10	1.4022	.1524	.2286	.1829			
11	1.3717	.1524	.1829	.2286			
12	1.3413	.1524	.1829	.1524			
13	1.2498	.1524	.1524	.1524			
14	1.4937	.1829	.1524	.1524			
15	1.448	.1524	.1524	.1905			
16		.1524	.1524	.1524	.1524	.1524	
17		.1524			.1524	.1524	
18		.1829			.1524	.1829	
19		.1829			.1829	.2134	
20		.2134			.1829	.2134	
21		.1829			.1829	.2134	
22		.1829			.1524	.1524	
23		.5335			.823	1.3717	
24	.1524	.6706				.8383	1.3717
Max	1.4937	1.0669	1.1888	1.2193	.823	1.7528	1.9814
Min	.1524	.1524	.1524	.1524	.1524	.1524	1.3717
Avg	.7860	.4541	.4725	.2904	.2477	.7513	1.5343



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274028 / 33/11 KV ANDHALGAON

SUBSTATION

Feeder No / Name : 203 / 11 KV LAXMI DAHIWADI

SEPARATED AG FEEDERS HAVING SPECIAL

FEEDER Feeder KV- 11 /

DESIGN TRANSFORMER

OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.1905		.1905		.1905	.1905
2		.1905		.1905		.1905	.1905
3	.9259	.1905		.1905		.2286	.1905
4	1.1317	.2286		.1905		.2858	.2858
5	1.2346	.2286		.2286		.3429	.3429
6	1.4575	.2667		.2667		.4191	.4763
7	1.4403	.2667		.2667		.4572	.4763
8	1.3717	.2286	.2667	.2286		.381	.381
9	.1905	1.3717	.7716	1.5775			
10	.2858	1.4575	1.5604	1.6461			
11	.2858	1.406	1.5775	1.6975			
12	.2286	1.5432	1.6632	1.6289			
13	.1905	2.1605	1.5432				
14	.1905	1.5432	1.4575	1.5432			
15	.1905	.9431		1.3717			
16	.1905	1.3032	.703		1.0288	1.0288	
17	.1905	.1905			.1905	.1905	
18	.2286	.2096			.2286	.2286	
19	.2286	.2096			.2667	.2286	
20	.2667	.2286			.2667	.2477	
21	.2667	.2096			.2477	.2477	
22	.2477	.2286			.1905	.1905	
23	.1905	.2286			.1905	.1905	
24	.6859	.1905				.1905	.1905
Max	1.4575	2.1605	1.6632	1.6975	1.0288	1.0288	.4763
Min	.1905	.1905	.2667	.1905	.1905	.1905	.1905
Avg	.5350	.6339	1.1929	.8013	.3263	.3082	.3027

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274028 / 33/11 KV ANDHALGAON

SUBSTATION

Feeder No / Name : 204 / Gaothan Andhalgaon

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587	.2587	.2402			.0381	.2772
2	.2587	.2587	.2218			.2286	.2772
3	.3142	.2587	.2218			.2286	.2772
4	.3511	.3142	.2587			.3429	.3326
5	.4435	.3142	.3696			.4763	.462
6	.6283	.6653	.5175			.5716	.5914
7	.4435	.5729	.6283			.6287	.5729
8	.3326	.4525	.499	.4805		.5175	.499
9	.3326	.4066	.3696	.3048			
10	.2957	.3696	.3511	.2587			
11	.2957	.3696	.2772	.2402			
12	.2587	.2402	.2033	.2402			
13	.2402	.1848	.2033	.2402			
14	.2218	.2033	.1848	.2218			
15	.2218	.2033		.2218			
16	.1848	.2957	.2772	.2218	.2587	.2587	
17	.3142	.2957			.3696	.3326	
18	.4066	.3881			.3696	.4435	
19	.5175	.499			.4805	.5175	
20	.4805	.499			.4805	.5729	
21	.462	.4435			.5359	.5544	
22	.3142	.3142			.4066	.3696	
23	.2587	.2587			.2587	.2772	
24	.2587	.2667	.2587			.2218	.2772
Max	.6283	.6653	.6283	.4805	.5359	.6287	.5914
Min	.1848	.1848	.1848	.2218	.2587	.0381	.2772
Avg	.3373	.3472	.3176	.27	.3950	.3871	.3963

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274028 / 33/11 KV ANDHALGAON

SUBSTATION

Feeder No / Name : 205 / 11 Kv Kacharewadi feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.663			1.2431	1.326
2			.8288			1.2431	1.326
3			.7459			1.1603	1.326
4			.7459			1.1603	1.326
5			1.0774			1.1603	1.3592
6			1.326			1.1437	1.4089
7			1.1603			1.326	1.4918
8	.381		1.2431	1.2431		1.1934	1.5415
9	.7956		.2096	.1524			
10	1.1271	1.0277	.2286	.1524			
11	1.1437	.0953	.2096	.1905			
12	1.0608	.1334	.2096	.1905			
13	1.094	.1524	.1905	.1905			
14	1.1105	.1524	.1905	.1905			
15	1.0774	.1524	.1905	.1326			
16	.5801	.1524	.2286	.2477	.2667	.3048	
17	.5801	.1715			.2477	.2858	
18	.1905	.1905			.3048	.2858	
19	.2286	.2286			.3429	.362	
20	.2286	.2667			.3429	.381	
21	.2477	.3048			.381	.381	
22	.2477	.2286			.2286	.3429	
23		.5716			1.3908	1.326	
24	.1524		.9945			1.2431	1.326
Max	1.1437	1.0277	1.326	1.2431	1.3908	1.326	1.5415
Min	.1524	.0953	.1905	.1326	.2286	.2858	1.326
Avg	.6404	.2735	.6143	.2989	.4382	.8554	1.3813

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274028 / 33/11 KV ANDHALGAON

SUBSTATION

Feeder No / Name : 206 / 11 KV MAHAMADABAD(S)

SEPARATED AG FEEDERS HAVING SPECIAL

FEEDER Feeder KV- 11 /

DESIGN TRANSFORMER

OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2172		.362	.362
2			.1991		.362	.362
3			.2172		.362	.362
4			.2172		.5068	.4344
5			.2534		.6878	.5792
6			.3982		.7602	.8145
7			.4706			
8	.3077	.362	.4344	.4344	.3258	
9	.3077	1.0679	1.6289	1.8099		
10		1.1765	2.0633	1.7737		
11	.2715	1.267	1.6108	1.086		
12	.2715	1.448	1.3937	1.6651		
13	.2715	1.2489	1.3032			
14	.2534	1.2308	1.267	1.6832		
15	.2534		1.267	1.4299		
16	.2715		1.448	1.448	1.448	
17	.2715	.181			.2534	
18	.2715	.3258			.3077	
19		.3801			.4344	
20		.3982			.4706	
21		.3077			.4706	
22		.2534			.362	
23		.2534	.2172		.362	
24	1.2955		.2172		.362	.362
<b>Max</b>	<b>1.2955</b>	<b>1.448</b>	<b>2.0633</b>	<b>1.8099</b>	<b>1.448</b>	<b>.8145</b>
<b>Min</b>	<b>.2534</b>	<b>.181</b>	<b>.1991</b>	<b>.4344</b>	<b>.2534</b>	<b>.362</b>
<b>Avg</b>	<b>.3679</b>	<b>.7072</b>	<b>.8235</b>	<b>1.4163</b>	<b>.4898</b>	<b>.4680</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274029 / 33KV BATHAN S/S

Feeder No / Name : 201 / 11KV UCHETHAN FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	2.1643
Max	2.1643
Min	2.1643
Avg	2.1643

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274029 / 33KV BATHAN S/S

Feeder No / Name : 202 / 11KV SARKOLI FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7204	.3403	.3012	.2218	.2031	.2629
2	1.8023	.3224	.2865		.2458	.3189
3	1.7604	.2804	.2715	.2427	.2846	.3189
4	1.7924	.2507	.2629	.2561	.3125	.3366
5	1.8185	.2126	.3403	.2896	.3801	.3506
6	1.9433	.1753	.3856	.2629		.3544
7	2.1262	.197	.3721	.2804		.3898
8	2.0317	.1629	.333	.3189		.3544
9	.2865	1.7695	1.7859	1.8442		1.8442
10	.2149	1.8404	1.7814	1.873		2.1548
11	.1646	1.7604		1.8442		2.1795
12	.1791	1.8785	1.7004	1.8233		2.0719
13	.2149	1.7814		1.989		2.0287
14	.2686	1.7924	1.6385	1.9062		1.95
15	.2149	1.7966		1.8842		2.0119
16	.1791	1.9204	1.6194	1.989		1.8842
17	.1629	.1928		.2401		.2743
18	.3189	.3155				.3086
19	.3582	.394		.2058		.3856
20	.3801	.4163		.2254		.3155
21	.362	.3801		.1928		.2804
22	.3506	.3544		.1753		.3155
23	.3439	.3155		.2103		.2926
24	1.6766	.362	.3155	.2378	.1898	.2804
Max	2.1262	1.9204	1.7859	1.989	.3801	2.1795
Min	.1629	.1629	.2629	.1753	.1898	.2629
Avg	.8613	.8005	.8139	.8415	.2693	.8860

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274029 / 33KV BATHAN S/S

Feeder No / Name : 203 / 11KV BATHAN FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	2.0119	1.8442	1.8442	2.0557	2.2939
2	.298	2.0517	1.9033	1.8351	2.3304	2.4577
3	.2629	2.2043	1.8991	1.95	2.4863	2.4806
4	.2835	2.4078	1.9719	1.9662	2.6216	2.672
5	.3012	2.4587	2.0233	2.0287	3.0178	2.8178
6	.2686	2.5434	2.0576	2.0153	3.0312	2.8006
7	.2686	2.5029	2.0687	2.0957	3.0887	3.2769
8	.2865	2.5604	2.1795	2.0719	3.2442	3.4008
9	2.9673	.1928	.2126	.1715	.2543	.2229
10	2.7978	.1578		.1734	.2058	.1372
11	2.696	.124		.1753	.1865	.12
12	2.5434	.1063		.1734	.1543	.1372
13	2.5987	.1254		.1753	.1387	.1387
14	2.3739	.1417		.2103	.1578	.1227
15	2.4078	.1595		.1928	.1753	.1387
16	2.3908	.1612		.1928	.1578	.1543
17	.2572	.2103		.2279	.1772	.156
18	.208	.3045		.2126	.2481	.2229
19	.2454	.3582		.2629	.2683	.2401
20	.2804	.3224		.3544	.3086	.1753
21	.2303	.2804		.443	.2947	.1578
22	.1753	.2804		.4298	.2835	.1715
23	1.9281	1.6766		1.9662	2.1052	2.934
24	2.1338	1.8778	1.7804	1.8442	2.0005	2.2634
Max	2.9673	2.5604	2.1795	2.0957	3.2442	3.4008
Min	.1753	.1063	.2126	.1715	.1387	.12
Avg	1.1866	1.0509	1.7941	.9589	1.2080	1.2372

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274029 / 33KV BATHAN S/S

Feeder No / Name : 204 / Bathan Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1086	.128	.1086	.0724	.124	.124
2	.0914	.1433	.1097	.1075	.1417	.1075
3	.1075	.1612	.1267	.0895	.124	.1075
4	.1267	.1254	.1448	.0716	.1075	.1448
5	.1448	.1494	.1595	.1086	.1433	.1433
6	.1629	.1075	.181	.1612	.1612	.1595
7	.1433	.0914	.1387	.2012	.1629	.1417
8	.1629	.1086	.1448	.3189	.1267	.1417
9	.1075	.1075	.1029	.3761	.1433	.124
10	.1086	.0886		.4298	.0905	.1433
11	.1254	.0905		.4163	.0905	.1254
12	.1267	.0716		.3582	.0724	.124
13	.1612	.0905		.394	.0895	.1086
14	.1448	.0895		.4075	.0716	.1267
15	.1612	.0876		.4344	.0895	.124
16	.181	.0709		.3898	.0886	.1402
17	.1267	.0914		.4252	.1086	.1433
18	.1075	.128		.362	.1075	.128
19	.1075	.1463		.1433	.1052	.1254
20	.0905	.1448		.181	.1254	.1433
21	.1254	.1086		.1791	.1433	.124
22	.1086	.0905		.1612	.1433	.1417
23	.0905	.0905		.1267	.124	.124
24	.0905	.1086	.0905	.1086	.1595	.1227
Max	.181	.1612	.181	.4344	.1629	.1595
Min	.0905	.0709	.0905	.0716	.0716	.1075
Avg	.1255	.1092	.1307	.2510	.1185	.1308



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274030 / 33/11KV BORALE S/S

Feeder No / Name : 201 / 11 KV TAMDARDI FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	1.8747
Max	1.8747
Min	1.8747
Avg	1.8747

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274030 / 33/11KV BORALE S/S

Feeder No / Name : 202 / 11 KV ARALI FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	1.9509
Max	1.9509
Min	1.9509
Avg	1.9509

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274030 / 33/11KV BORALE S/S

Feeder No / Name : 203 / 11 KV DONAJ FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	04-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.2058	.2347	.1372
2		.1715	.2058	.2401	.1372
3		.1715	.2058	.2743	.1372
4		.2058	.2743	.3429	.1715
5		.2743	.3086	.4115	.2743
6		.4115	.4115	.4458	.3601
7		.3429	.4115	.4458	.3772
8		.2743	.3601	.3429	.2743
9		1.2631			1.5708
10		1.4899	1.4251	2.3482	2.1214
11		1.8138	1.8785	2.3644	2.2672
12		2.1376	1.6356	2.2996	2.1538
13		2.1862	1.7166	2.332	2.1862
14			2.1628	2.0567	.8745
15			2.2024	2.0729	1.6356
16			1.6842	1.8299	1.9109
17			.2401	.2401	.2743
18			.2915	.2572	.3086
19			.3429	.3429	.3258
20			.3772	.2401	.3429
21			.3429	.3772	.3086
22			.3258	.2743	.2743
23			.2401	.2401	.2572
24	1.829	.1715	.2058	.2347	.1543
Max	1.829	2.1862	2.2024	2.3644	2.2672
Min	1.829	.1715	.2058	.2347	.1372
Avg	1.829	.7918	.7589	.8804	.7848

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274030 / 33/11KV BORALE S/S

Feeder No / Name : 204 / 11 KV SIDDHAPUR FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	04-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.4575	1.2955	1.3279	1.9784
2		1.4575	1.2955	1.3279	1.9757
3		1.4575	1.2955	1.3279	1.9757
4		1.4575	1.2955	1.3603	2.0405
5		1.4575	1.2955	1.4575	2.1052
6		1.4575	1.3603	1.587	
7		1.6194	1.4575	1.9109	2.0081
8		1.6842		2.3482	2.2348
9		.0168		.0168	.0168
10		.0168		.0168	.0168
11		.0168	.0168	.0168	.0168
12		.0168	.0168	.0168	.0168
13		.0168	.0168		.0168
14			.0168		.0168
15			.0168		.0168
16			.0168		.0168
17			.0168	.0168	.0168
18			.0671	.0168	.0168
19			.0168	.0168	.0168
20			.0168	.0168	.0168
21			.0168	.0168	.0168
22			.0168	.0168	.0168
23			1.3765	.0168	.0168
24	1.9814	1.4575	1.3279	.0168	.0168
Max	1.9814	1.6842	1.4575	2.3482	2.2348
Min	1.9814	.0168	.0168	.0168	.0168
Avg	1.9814	.9707	.5834	.6425	.6342

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274030 / 33/11KV BORALE S/S

Feeder No / Name : 205 / 11 KV TANDUR FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	04-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0168	.0168	.0168	.0168
2		.0168	.0168	.0168	.0168
3		.0168	.0168	.0168	.0168
4		.0168	.0168	.0168	.0168
5		.0168	.0168	.0168	.0168
6		.0168	.0168	.0168	.0168
7		.0168	.0168	.0168	.0168
8		.0168	.0168	.0168	.0168
9		.6478	.4858	.0168	.0168
10		.6478	.9717	.0168	.0168
11		.6802	1.1736		.0168
12		.6478	.7287		.0168
13		.6964	.7287		.0168
14			.9717		.0168
15			1.0526		
16			.4858		
17			.0168	1.2146	1.6518
18			.0168	1.3927	1.8623
19			.0168	1.4251	1.8138
20			.0168	1.2955	1.7814
21			.0168	1.3927	1.7814
22			.0168	1.3927	1.7814
23			.0162	1.2955	1.7814
24	1.4937	.0168	.0168	.0168	1.2308
Max	1.4937	.6964	1.1736	1.4251	1.8623
Min	1.4937	.0168	.0162	.0168	.0168
Avg	1.4937	.2479	.2861	.5330	.6327

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274030 / 33/11KV BORALE S/S

Feeder No / Name : 206 / 11 KV BORALE FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	04-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4575	.0503	.0503		.0671
2	1.4575	.0503	.0503		.0671
3	1.4575	.0503	.0503		.0671
4	1.4899	.0503	.0503		.0838
5	1.6518	.0671	.0503		.0838
6	1.6518	.1006	.0671		.0838
7	1.5384	.0838	.0838		.0671
8	1.5384	.0671	.0671		.0503
9		1.0526	1.1336		1.3117
10		1.1336	1.5546		1.5223
11		1.4575	1.4413		1.4899
12		1.4737	1.5061	1.7166	1.587
13		1.4899	1.5223	1.6518	1.4899
14			1.3927	1.7166	1.4737
15			1.4737	1.4089	1.4413
16			1.5223	1.4413	1.4575
17			.0648	.0503	.0335
18			.0838	.0648	.0671
19			.1006	.0838	.0838
20			.1006	.1006	.0671
21			.0838	.0671	.0671
22			.0838	.0671	.0503
23			.0671	.0671	.0503
24	1.4413	.0503	.0503		.0671
Max	1.6518	1.4899	1.5546	1.7166	1.587
Min	1.4413	.0503	.0503	.0503	.0335
Avg	1.5205	.5127	.5271	.703	.5346

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274030 / 33/11KV BORALE S/S

Feeder No / Name : 207 / Gaothan Borale

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	04-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4887	.5068	.4706	.5068
2		.4887	.5068	.4706	.5068
3		.5249	.543	.6154	.543
4		.7059	.7059	.6154	.6335
5		1.0136	.9412	.7602	.8869
6		1.2127	1.1584	1.0136	
7		.9412		1.2127	.8688
8		.6516	.8326	1.086	.6878
9		.543	.543	.8326	.5068
10		.3801	.4706	.543	.4344
11		.362	.3982	.4163	.3982
12		.3258	.3258	.4525	.5249
13		.3258	.4163	.4525	.5068
14			.3258	.3982	.3801
15			.3439	.4163	.3982
16			.3982		.4887
17			.4706	.4887	.4706
18			.6516	.5792	.5792
19			.7602	.7602	.8326
20			1.086	1.0136	.9955
21			.8869	.8688	.9231
22			.6516	.6516	.7059
23			.543	.543	.5973
24	.6001	.4887	.5068	.4706	.5249
Max	.6001	1.2127	1.1584	1.2127	.9955
Min	.6001	.3258	.3258	.3982	.3801
Avg	.6001	.6038	.6075	.6579	.6044

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274030 / 33/11KV BORALE S/S

Feeder No / Name : 208 / 11 Kv Nandur Feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0972	.1006	.1448
2		.0972	.1006	.1448
3		.0972	.1174	.1448
4		.1134	.1509	.1341
5		.1341	.1509	.1509
6		.1341	.1677	.1677
7		.1341	.1844	.1509
8		.1174	.1509	.1341
9		1.4575	1.7814	1.5223
10		1.5223	2.0243	2.0729
11		2.1862	2.4615	2.3967
12		2.2672	2.4129	2.4939
13		2.3158	2.4615	2.2672
14			2.0891	2.332
15			2.4129	2.2348
16			2.2348	2.3482
17			.1174	.1174
18			.1174	.1174
19			.1677	.1509
20			.1619	.1677
21			.1677	.1509
22			.1296	.1134
23			.1341	.1006
24	1.4937	.0972	.1006	.1341
Max	1.4937	2.3158	2.4615	2.4939
Min	1.4937	.0972	.1006	.1006
Avg	1.4937	.7694	.8374	.8289



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274030 / 33/11KV BORALE S/S

Feeder No / Name : 209 / 11 Kv Mahasiddha Feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	1.9814
Max	1.9814
Min	1.9814
Avg	1.9814

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274030 / 33/11KV BORALE S/S

Feeder No / Name : 210 / Matoli

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	2.0576
Max	2.0576
Min	2.0576
Avg	2.0576

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274031 / 33KV S/S HULJANTI

Feeder No / Name : 201 / 11KV HULJANTI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2071	.1802	.1638	.1492	.1823	.2652	.2818
2	1.2071	.1802	.1638	.1492	.1823	.2486	.2652
3	1.2239	.1638	.1966	.1658	.1989	.2486	.2652
4	1.2574	.1638	.2294	.2155	.1989	.2818	.2984
5	1.3916	.2622	.2458	.2155	.2155	.3113	.3315
6	1.861	.3277	.2622	.2984	.2652	.426	.3315
7	2.0119	.2785	.3277	.3315	.2818	.4424	.3441
8	2.0454	.2294	.2785	.2155	.2321	.2818	.3441
9	.1326	1.7695	1.8107	1.6907	1.8564	1.9393	1.5912
10	.0995	2.1051	1.0774	1.989	2.0388	1.5402	2.0719
11	.1475	1.7901	2.2298	1.989	1.9725	1.8564	1.9062
12	.1475	2.1216	2.079		1.9559	1.9559	1.8564
13			1.9448	1.8564	2.0222	1.873	2.0965
14		.9231	2.079	1.9062	2.0553	1.6575	1.7736
15	.1638	2.0567	2.1125	1.9227	1.989		1.4586
16	.1638	2.1714	1.2742	1.7736	2.0388	1.5912	1.6575
17	.213	.1989	.1296		.2652	.2458	.2429
18	.1823	.2321	.1619	.1326	.3149	.2622	.2591
19	.2622	.2486	.2591	.3149	.3647	.3315	.2915
20	.2949	.2652	.2915	.2984	.4144	.4144	.3401
21	.2458	.2622	.2591	.2486	.3647	.3978	.3239
22	.2622	.2294	.2267	.2155	.3315	.3647	.2915
23	.1966	.1638	.1619	.1989	.2321	.2818	.1781
24	1.1603	.1966	.1638	.1658	.1823	.2652	.2785
Max	2.0454	2.1714	2.2298	1.989	2.0553	1.9559	2.0965
Min	.0995	.1638	.1296	.1326	.1823	.2458	.1781
Avg	.7217	.7183	.7554	.7474	.8398	.7601	.7950

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274031 / 33KV S/S HULJANTI

Feeder No / Name : 202 / 11 KV SODDI FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0829	.759	.9326	.8122	.8951	.7907	.8951
2	.0829	.7907	.9835	.8122	.9116	.8539	.8951
3	.0829	.8381	1.0174	.9282	.9116	.9488	.9614
4	.0829	.933	1.0774	.9945	.9448	.9646	1.0774
5	.0995	1.1069	1.1603	1.0608	1.0277	1.0437	1.1603
6	.1326	1.5497	1.3094	1.278	1.4918	1.4548	1.4255
7			1.6741	1.6221	1.757	1.5813	1.6907
8			1.1437	1.491	1.4918	1.2018	1.4752
9	1.2929		.112	.1147	.116	.0819	.0829
10	1.3125	.08	.064		.0791	.0328	.1017
11	1.4255	.0663	.0648	.0328	.0633	.0339	.08
12	1.1702	.0663	.048		.0633	.0678	.0048
13	1.1961	.0678	.0648	.0819	.0633	.0678	
14	.6554	.0678	.081	.0819	.0949	.0678	.08
15	1.2125	.0678	.0648	.0829	.0949		.096
16	1.1544	.0663	.0648	.0663	.0791	.0678	.08
17	.0633	.0829	.0972	.0829	.0791	.1017	.096
18	.0655		.128	.1147	.1107	.1357	.112
19	.1107	.116	.1296	.1326	.1423	.1357	.1311
20	.1265		.1457	.1326	.1581	.1526	.1638
21	.1265	.1326	.1296	.1326	.1423	.1357	.1475
22	.1107	.116	.1134	.116	.1423	.1187	.1147
23	.6642	.7625	.7127	.8288	.7432	.8619	.7293
24	.0838	.7116	.8987	.8288	.8619	.7432	.8785
Max	1.4255	1.5497	1.6741	1.6221	1.757	1.5813	1.6907
Min	.0633	.0663	.048	.0328	.0633	.0328	.0048
Avg	.5152	.4411	.5091	.5377	.5194	.5063	.5426

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274031 / 33KV S/S HULJANTI

Feeder No / Name : 203 / 11 KV MARAWADE FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2616	.3163	.3647	.2881	.3681	.4534	.6062
2	1.278	.3163	.3647	.2881	.3841	.4372	.5898
3	1.278	.3005	.3481	.3521	.3841	.4372	.5898
4	1.326	.3041	.4144	.3841	.3841	.4534	.6226
5	1.4089	.3953	.4973	.4321	.4321	.4696	.6226
6	1.873	.5535	.5636	.4321	.4321	.583	.639
7	2.5857	.4586	.4973	.4161		.583	.6554
8	2.4531	.3953	.4807	.4001	.4161	.4801	.5735
9	.2126	2.1032	2.1548	1.5497	2.0056	2.2085	1.5074
10	.2303	2.6578	2.4646	1.7394	2.2672	2.6886	2.2085
11	.208	2.4531	2.5692	2.0557	2.372	2.8178	2.1125
12	.213	2.4531	2.42		2.1348	2.8178	2.0553
13	.2214	2.4577	2.2874	1.8404	2.5425	2.3868	1.9725
14	.2372	2.5396	2.0885	2.1605	1.9595	2.3205	2.0325
15		2.6052	2.5194	2.1925			2.1605
16	.1265	2.6246		2.3365	2.3644	2.0553	2.0805
17	.253	.3315		.3841	.4534	.6299	.3277
18	.3479	.3978		.4641	.5506	.7127	
19	.3953	.4973	.4641	.4588	.6478	.7459	.3605
20	.4641	.5636	.4973	.4641	.6154	.7956	.3768
21	.3795	.4973	.4973	.4001	.5992	.7459	.4588
22	.3795	.3647	.4475	.4001	.5668	.6133	.2949
23	.3321	.3812	.3978	.4001	.4534	.6299	.2949
24	1.2146	.3321	.3812	.3005	.4001	.4534	.6062
Max	2.5857	2.6578	2.5692	2.3365	2.5425	2.8178	2.2085
Min	.1265	.3005	.3481	.2881	.3681	.4372	.2949
Avg	.8121	1.0958	1.0819	.8756	1.0333	1.1530	1.0325

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274031 / 33KV S/S HULJANTI

Feeder No / Name : 204 / Gaothan Huljanti

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4887	.547	.4024	.5068	.5304	.5975
2	.4572	.4706	.5281	.439	.5068	.4938	.5601
3	.4755	.4163	.4904	.4755	.5249	.4572	.5601
4	.5121	.3681	.6535	.5487	.5792	.5121	.7468
5	.6584	.6335	.9149	.7316	.724	.7682	.9335
6	1.0242	1.0498	1.1203	.7964	.9955	1.1706	1.0829
7	.9511	.9593	.961	.8688	.985	.8962	.9709
8	.7316	.8326	.9425	.9328	.8688	.8779	.8962
9	.5853	.6516	.6516	.6878	.7964	.9145	.6722
10	.5249	.6653	.6516	.6584	.6697	.7133	.6348
11	.4525	.5914	.6154	.6219	.6335	.7468	.5373
12	.5792	.5975	.6036		.5792	.7095	.3582
13	.5249	.6878	.5853	.6219	.5973	.7095	
14	.4887	.5853		.6036	.7316	.7282	.5731
15		.5121	.5853	.6219	.7316		.5373
16	.3982	.5914	.5487	.5853	.7865	.7468	.6447
17	.6154	.7762	.695	.7316	.7865	.9335	.6805
18	.7421	.8131		.8779	.8962	.9335	.7522
19	.8507	.924	.9511	.9511	1.0425	.9709	.9054
20	.9465	.9877	.9694	1.0242	1.0791	1.0456	1.0185
21	.8507	.9055	.8413	.8596	.9145	.9709	.8299
22	.7059	.8131	.7316	.7164	.8413	.8962	.7167
23	.543	.5914	.6878	.6584	.5487	.7095	.5373
24	.4572	.5249	.5658	.439	.543	.5487	.6348
Max	1.0242	1.0498	1.1203	1.0242	1.0791	1.1706	1.0829
Min	.3982	.3681	.4904	.4024	.5068	.4572	.3582
Avg	.6318	.6849	.7201	.6893	.7445	.7819	.7122

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274031 / 33KV S/S HULJANTI

Feeder No / Name : 205 / 11 Kv Yedrav Feeder

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1189	.9962	1.4373	.9393	1.6032	1.4899	1.7284
2	.1189	1.0279	1.4685	.9717	1.6032	1.5223	1.7444
3	.1337	1.1069	1.531	1.1012	1.6356	1.587	1.7604
4	.1337	1.3441	1.6129	1.1984	1.7166	1.7004	1.8404
5	.1635	1.439	1.7394	1.3279	1.8623	1.7976	1.8976
6	.1932	1.8343	1.9925	1.7695	2.0405	2.0243	1.9845
7	.1783	1.6129	1.085	2.3482	1.5384	2.0891	2.2043
8	.1635	2.0399	2.0405	2.2348	2.3644	2.1376	2.251
9	1.3969	.1265	.16		.1457	.1265	.1457
10	1.8027	.1417	.128		.1457	.1265	.1457
11	1.8501	.0972	.112	.0648	.1619	.1457	.1265
12	1.6288	.1134	.112	.0655	.1457	.1134	.112
13	1.6604	.1296	.1296	.1134	.0972	.1619	.1107
14	1.692	.0972	.1296	.1296	.1296	.1296	.0972
15	1.692	.0819	.1457	.1311	.1457		.096
16	1.6604	.1457	.1296	.1638	.1296	.1296	.08
17	.1265	.1134	.1457	.1638	.1619	.1619	.1189
18	.1107	.1296		.1802	.1619	.1619	.1486
19	.1423	.1619	.1781	.1943	.2267	.1781	.1635
20	.1898	.2105	.1943	.213	.2105	.2105	.1932
21	.1581	.1943	.1619	.1781	.1943	.1943	.192
22	.1423	.1619	.1457	.1791	.1619	.1943	.192
23	.933	1.2146	1.1498	1.4575	1.3603	1.4899	1.3117
24	1.4937	.9488	1.4403	1.4089	1.5708	1.4413	1.7004
Max	1.8501	2.0399	2.0405	2.3482	2.3644	2.1376	2.251
Min	.1107	.0819	.112	.0648	.0972	.1134	.08
Avg	.7451	.6446	.7552	.7516	.8131	.8397	.8477

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274032 / 33/11KV HUNNUR S/S

Feeder No / Name : 201 / 11 kv Hunnur Feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1457	.5182	.6478	.5182	.6154	.583	.6316
2	.1457	.5182	.6478	.5668	.6478	.583	.7202
3	.1457	.5344	.7287	.5992	.6802	.6316	.8402
4	.1619	.5506	.7773	.6154	.7287	.6316	.8573
5	.1619	.8745	.8421	.6478	.8907	.6964	.9088
6	.2267	1.0364	1.0202	.7773	.9878	.9231	.9717
7	.2591	1.1984	1.2631	1.0526	1.247	1.0202	1.0688
8	.2429	1.1336	1.2793	1.2955	1.1984	.9878	1.0288
9	.9717	.1457	.1619	.1619	.1781	.2105	.1543
10	.9555	.0972	.1619	.1134	.0972	.1134	.1296
11	.8259	.0648	.1296	.081	.081	.0972	.1134
12	.7935	.081	.1296	.081	.081		.0972
13	.8421	.081	.1296	.0972	.081		.1134
14	.6802	.0648	.1134	.081	.0972		.0972
15	.7125	.081	.1134	.0972	.0972	.0972	.0972
16	.8421	.1134	.1134	.1134	.1134	.1296	.1296
17	.1296	.1296	.1457	.1134	.1134	.1457	.1457
18	.1457	.1457	.1619	.1134	.2267	.1781	.1781
19	.2105	.2105	.1943	.2105	.2105	.2105	.1943
20	.2591	.3077	.2267	.2915	.2591	.2429	.2267
21	.2429	.2753	.2591	.2591	.2105	.2267	.2105
22	.1781	.1943	.2591	.2105	.1619	.2105	.1781
23	.3563	.6802	.4049	.4858	.5668	.5344	.6154
24	.1457	.4858	.6964	.4858	.5668	.583	.583
Max	.9717	1.1984	1.2793	1.2955	1.247	1.0202	1.0688
Min	.1296	.0648	.1134	.081	.081	.0972	.0972
Avg	.4075	.3968	.4420	.3779	.4224	.4303	.4288



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274032 / 33/11KV HUNNUR S/S

Feeder No / Name : 202 / 11 kv Bhose Feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	2.1338
Max	2.1338
Min	2.1338
Avg	2.1338

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274032 / 33/11KV HUNNUR S/S

Feeder No / Name : 203 / 11 Kv Mahamdabad Feeder      SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0152	.0914	.0914	.061	.0914	.0762	.0686
2	.0152	.1067	.0914	.061	.0914	.0762	.0857
3	.0152	.1219	.1067	.0762	.1067	.0914	.0762
4	.0152	.1524	.1219	.0914	.1372	.1067	.12
5	.0152	.2743	.1372	.1067	.2286	.1219	.1543
6	.0152	.3353	.1829	.1219	.3201	.1829	.1981
7	.0152	.4115	.3048	.1524	.3658	.1981	.2401
8	.1372	.2896	.2439	.1981	.3048	.1677	.1829
9	.1372	.0152	.0152	.0152	.0152	.0152	.0152
10	.1981	.0152	.0152	.0152	.0152	.0152	.0152
11	.1677	.0152	.0152	.0152	.0152	.0152	.0152
12	.1981	.0152	.0152	.0152	.0152	.0152	.0152
13	.1524	.0152	.0152	.0152	.0152	.0162	.0152
14	.1524	.0152	.0152	.0152	.0152	.0162	.0152
15	.1219	.0152	.0152	.0152	.0152	.0152	.0152
16	.1067	.0152	.0152	.0152	.0305	.0152	.0152
17	.0152	.0152	.0152	.0152	.0152	.0152	.0152
18	.0152	.0152	.0152	.0152	.0152	.0171	.0152
19	.0152	.0152	.0152	.0152	.0305	.0343	.0457
20	.0152	.0305	.0152	.0152	.0152	.0343	.0457
21	.0152	.0305	.0152	.0152	.0152	.0171	.0152
22	.0152	.0305	.0152	.0152	.0152	.0171	.0152
23	.0762	.0914	.061	.061	.061	.0514	.0762
24	.0152	.0914	.0762	.061	.061	.0686	.0686
Max	.1981	.4115	.3048	.1981	.3658	.1981	.2401
Min	.0152	.0152	.0152	.0152	.0152	.0152	.0152
Avg	.0692	.0927	.0679	.0501	.0838	.0583	.0644

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274032 / 33/11KV HUNNUR S/S

Feeder No / Name : 204 / Gaothan Hunnur

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	06-AUG-17
HR	Load (MW)	Load (MW)
15		.0972
24	.5335	
Max	.5335	.0972
Min	.5335	.0972
Avg	.5335	.0972

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274032 / 33/11KV HUNNUR S/S

Feeder No / Name : 205 / MANEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.5144	.5487	.5658	.5487	.4287	.5658
2	.1886	.5144	.5487	.6001	.5658	.4287	.6344
3	.2058	.5487	.5658	.6859	.6001	.463	.6687
4	.2229	.5658	.5658	.7202	.6516	.5144	.7202
5	.2229	.6859	.7202	.6859	.6859	.5658	.7716
6	.2401	.8059	.8916	.8573	.7545	.823	.8402
7	.2572	1.1145	1.166	.9945	.9602	1.1317	.9259
8	.2058	.9431	1.1145	1.0802	.945	1.0117	.8573
9	.6859	.1029	.1029	.0857	.0857	.1029	.8573
10	.7545	.0686	.1029	.0857	.0686	.1543	.0857
11	.9259	.0686	.1029		.0686		.1029
12	.8402	.0686	.1029		.0514		.1029
13	.7888	.0514	.1029		.0514	.0686	.0686
14	.7545	.0514	.1029	.0514	.0514	.0514	.0686
15	.8059	.0514	.1029	.0514	.0514	.0857	.0686
16		.0514	.0857	.0514	.0686	.1029	.0686
17	.0686	.0686	.0857	.0686	.0686	.1372	.0686
18	.12	.0857	.12	.0857	.0686	.1543	.0857
19	.12	.12	.1715	.1029	.12	.1886	.12
20	.1886	.1715	.1715	.1715	.1372	.2229	.1543
21	.1372	.1543	.1715	.1372	.12	.1715	.1372
22	.1372	.12	.1543	.12	.12	.1543	.1372
23	.4287	.4801	.4287	.4287	.3601	.4115	.4287
24	.1886	.4458	.5144	.5144	.5144	.5144	.5144
Max	.9259	1.1145	1.166	1.0802	.9602	1.1317	.9259
Min	.0686	.0514	.0857	.0514	.0514	.0514	.0686
Avg	.3772	.3272	.3644	.3878	.3216	.3585	.3772

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274032 / 33/11KV HUNNUR S/S

Feeder No / Name : 206 / Lonar

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.2229	.2058	.1715	.2058	.2058	.1543
2	.5144	.2229	.2229	.1715	.2229	.2058	.1543
3	.5144	.2229	.2229	.2058	.2401	.2229	.1372
4	.6001	.2401	.2572	.2229	.2572	.2572	.1372
5	.6859	.3086	.2915	.2401	.3086	.2915	.12
6	.823	.3944	.3601	.2743	.3772	.3429	.1886
7	1.0631	.2915	.3601	.2743	.3086	.3601	.2572
8	1.0288	.1886	.3429	.2058	.2229	.2572	.2229
9	.1372	.9431	.823	1.406	1.0117	.9774	.8573
10	.12	.8402	.7716	1.0974	1.0117	.9431	.9259
11	.12	.9602	.7888	.9259	.9774	.7545	.8745
12	.12	.9259	.8059	.9259	.9259	.6001	.7373
13	.12	.823	.823	.7716	.8916	.7888	.7888
14	.12	.8573	.8402	.703	.823	.8059	.7373
15	.12	.8573	.8573	.8745	.8402	.5144	.823
16		.9259	.7716	.9602	.9259	.7545	.9602
17		.1372	.1029	.1372	.1372	.1543	.1543
18	.1543	.1543	.12	.1543	.1715	.1715	.2058
19	.2058	.1886	.1543	.2401	.2229	.2058	.2401
20	.2743	.2915	.2401	.3258	.2572	.2229	.2915
21	.2915	.3086	.2401	.2743	.2915	.1886	.2915
22	.2743	.2743	.2572	.2572	.2743	.1715	.2743
23	.2401	.2229	.2743	.2229	.2401	.1543	.2401
24	.3429	.2229	.2058	.2572	.2229	.1543	.1543
Max	1.0631	.9602	.8573	1.406	1.0117	.9774	.9602
Min	.12	.1372	.1029	.1372	.1372	.1543	.12
Avg	.3811	.4594	.4308	.4708	.4737	.4044	.4137

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274033 / 33/11 KV MANGALWEDHA S/S

Feeder No / Name : 201 / 11 KV MANGALWEDHA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	1.406
Max	1.406
Min	1.406
Avg	1.406

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274033 / 33/11 KV MANGALWEDHA S/S

Feeder No / Name : 202 / 11 KV GFSS MGL

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	1.1145
Max	1.1145
Min	1.1145
Avg	1.1145

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274033 / 33/11 KV MANGALWEDHA S/S

Feeder No / Name : 203 / 11 KV BORALE FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	2.5149
Max	2.5149
Min	2.5149
Avg	2.5149



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274033 / 33/11 KV MANGALWEDHA S/S

Feeder No / Name : 204 / 11 KV MALLEWADI FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	1.9814
Max	1.9814
Min	1.9814
Avg	1.9814

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274033 / 33/11 KV MANGALWEDHA S/S

Feeder No / Name : 205 / 11KV UCHETHAN FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	1.3413
Max	1.3413
Min	1.3413
Avg	1.3413

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274034 / 33/11 KV NIMBONI S/S

Feeder No / Name : 201 / 11KV JALIHAI FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.6004	.2229	.1886	.2743	.1991	.1886	.1886
16	.1029	1.2193	1.2193	1.2193	.6401	.7468	.8078
22					.1448		
23	.12	.12	.12	.12	.12	.12	.1372
24	.6401	.12	.12	.12	.1372	.12	.12
Max	1.6004	1.2193	1.2193	1.2193	.6401	.7468	.8078
Min	.1029	.12	.12	.12	.12	.12	.12
Avg	.6159	.4206	.4120	.4334	.2482	.2939	.3134

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274034 / 33/11 KV NIMBONI S/S

Feeder No / Name : 202 / 11KV NANDESHWAR FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.2229	1.4327	1.4327	1.4784	1.4784	1.5242	1.2803
16	1.0974	.0857	.1029	.1029	.0857		.12
22					.1991		
23	.6706	.6554	.9145	.884	.9755	.7611	.664
24	.1715	.7011	.7164	.884	.8688	.9755	.7287
Max	1.0974	1.4327	1.4327	1.4784	1.4784	1.5242	1.2803
Min	.1715	.0857	.1029	.1029	.0857	.7611	.12
Avg	.5406	.7187	.7916	.8373	.7215	1.0869	.6983

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274034 / 33/11 KV NIMBONI S/S

Feeder No / Name : 203 / 11KV JITTI FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.7985	.3086	.3086	.3429	.2572	.3258	.2915
15			1.326				
16	.1029	1.4632		1.3565	.7316	1.2651	1.2955
22					.2172		
23	.1372	.1372	.1372	.12	.1543	.1372	.1543
24	1.2803	.1372	.1372	.1372	.1372	.1372	.1372
Max	1.7985	1.4632	1.326	1.3565	.7316	1.2651	1.2955
Min	.1029	.1372	.1372	.12	.1372	.1372	.1372
Avg	.8297	.5116	.4773	.4892	.2995	.4663	.4696

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274034 / 33/11 KV NIMBONI S/S

Feeder No / Name : 205 / Gaothan Nimboni

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.664	.6478	.6802	.6964	.7716	.6859	.7202
16	.3944	.3772	.3086	.3429	.3772	.4287	.3772
22					.6173		
23	.4115	.463	.3944	.3944	.463	.4801	.5144
24	.3944	.3772	.4287	.3772	.3772	.3944	.3772
Max	.664	.6478	.6802	.6964	.7716	.6859	.7202
Min	.3944	.3772	.3086	.3429	.3772	.3944	.3772
Avg	.4661	.4663	.4530	.4527	.5213	.4973	.4973

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274034 / 33/11 KV NIMBONI S/S

Feeder No / Name : 206 / 11 KV Chikkalgi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.3086	1.89	1.89	2.0424	1.9204	1.9357	2.0729
16	1.5699	.1715	.2572	.2058	.12		.2915
22					.3086		
23	.9907	1.1126	1.1736	1.1736	1.2498	1.1888	1.1584
24	2.0576	1.0059	1.2193	1.1736	1.1888	1.2651	1.2041
Max	2.0576	1.89	1.89	2.0424	1.9204	1.9357	2.0729
Min	.3086	.1715	.2572	.2058	.12	1.1888	.2915
Avg	1.2317	1.045	1.1350	1.1489	.9575	1.4632	1.1817

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274111 / SALGAR BK

Feeder No / Name : 201 / SALGAR BK

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	1.2498
Max	1.2498
Min	1.2498
Avg	1.2498



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274111 / SALGAR BK

Feeder No / Name : 202 / MAROLI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	1.4937
Max	1.4937
Min	1.4937
Avg	1.4937

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274111 / SALGAR BK

Feeder No / Name : 203 / LAWANGI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	2.0576
Max	2.0576
Min	2.0576
Avg	2.0576

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274111 / SALGAR BK

Feeder No / Name : 204 / SALGAR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.5316
Max	.5316
Min	.5316
Avg	.5316

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274111 / SALGAR BK

Feeder No / Name : 205 / 11 kv jangalgi ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.945
Max	.945
Min	.945
Avg	.945

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274111 / SALGAR BK

Feeder No / Name : 403 / Huljanti

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
 (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	.0051
Max	.0051
Min	.0051
Avg	.0051

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274121 / 33/11KV MARAPUR

Feeder No / Name : 201 / 11KV MARAPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3749	1.0623	1.4232	1.3435	1.4723	1.5043
2	.3795	1.1069	1.2811	1.3763	1.3279	1.2803
3	.3795	1.1069	1.1888	1.3927	1.3123	1.2041
4	.4534	1.1603	1.2346	1.3927	1.3279	1.2193
5	.5121	1.1561	1.25	1.3443	1.5203	1.3123
6	.8962	1.8244	1.781	2.0972	2.0317	1.5813
7	1.004	2.1247	2.372	2.7206	2.8502	2.7328
8	1.0242	2.2405		2.4966	2.7183	2.4863
9		.5864	.6748			
10		.9114	.7225			
11		.6874	.7074			
12		.4988	.6748			
13		.6733	.6455			
14		.6019	.6081			
15		.6241	.5647			
16		.6167	.2643			
17				1.531	.1974	.2949
18					.2606	.3294
19					.3864	.3641
20					.3658	.3856
21		1.0494			.3086	.3239
22					.2968	.253
23					1.6078	1.5655
24	.3841	1.0494	1.4864	1.531	1.6057	1.5546
Max	1.0242	2.2405	2.372	2.7206	2.8502	2.7328
Min	.3749	.4988	.2643	1.3435	.1974	.253
Avg	.6009	1.0601	1.0550	1.7226	1.2244	1.1495

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274121 / 33/11KV MARAPUR

Feeder No / Name : 204 / 11 KV GFSS MARAPUR

Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	05-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0213	.0305	.0244	.0259
2	.0213	.0274	.0229	.0259
3	.0213	.0244	.0229	.0314
4	.0274	.0244	.032	.0444
5	.0366	.0457	.0366	.0517
6	.0518	.0366	.0503	.0554
7	.0472	.0305	.0457	.0573
8	.0427	.0305		.0517
9		.037	.0314	
10		.0333	.0277	
11		.0333	.0277	
12		.0333	.0259	
13		.0314	.0259	
14		.0277	.0259	
15		.0277	.0259	
16		.0314	.0277	
24	.1829	.0381	.0274	.0333
Max	.1829	.0457	.0503	.0573
Min	.0213	.0244	.0229	.0259
Avg	.0503	.0320	.0300	.0419

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274121 / 33/11KV MARAPUR

Feeder No / Name : 205 / ITI COLLAGE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1147	.5218	.506	.5506	.5761	.5624
2	.1147	.5218	.506	.5312	.5624	.5487
3	.1134	.5247	.5155	.4999	.6081	.5335
4	.1619	.5401	.5601	.6154	.6478	.5792
5	.213	.5624	.6081	.7042	.7209	.6562
6	.2683	.7968	.8436	.9717	.9175	.7907
7	.213	1.0082	1.1092	1.2452	1.2431	1.1305
8	.1943	1.0364		1.1336	1.1336	1.0437
9		.1094	.181			
10		.1052	.081			
11		.0886	.081			
12		.1214	.08			
13		.1417				
14		.1387	.081			
15		.1791	.1296			
16		.1578	.1417			
17					.1402	.2328
18					.2012	.2303
19					.2743	.2587
20					.2957	.2561
21					.2957	.2353
22					.2534	.2149
23					.5668	.5851
24	.1174	.5121	.5155	.5376	.5898	.5761
Max	.2683	1.0364	1.1092	1.2452	1.2431	1.1305
Min	.1134	.0886	.08	.4999	.1402	.2149
Avg	.1679	.4157	.3960	.7544	.5642	.5271



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274121 / 33/11KV MARAPUR

Feeder No / Name : 206 / GUNJEGAON FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0082	.1991	.2378	.2195	.2195	.2172
2	.9962	.2012	.2378	.2126	.2195	.2149
3	.9804	.197	.2561	.2561	.2218	.2534
4	1.0688	.2103	.2772	.2534	.2587	.2926
5	1.1305	.2254	.2957	.2686	.2957	.3326
6	1.5844	.2835	.3326	.3109	.3361	.3734
7	1.9433	.2658	.3292	.2987	.3547	.3547
8	1.7924	.2126		.2801	.3174	.3174
9		1.2967	1.9662			
10		1.9109	1.7695			
11		1.7532	1.749			
12		1.5623	1.7004			
13		1.5524				
14		1.4548	1.6194			
15		1.5546	1.7004			
16		1.6004	1.7328			
18					.2103	.1696
19					.2896	.2353
20					.3326	.2561
21					.3292	.2328
22					.3077	.2149
23					.2033	.181
24	1.1012	.1734	.2195	.2172	.2218	.1991
Max	1.9433	1.9109	1.9662	.3109	.3547	.3734
Min	.9804	.1734	.2195	.2126	.2033	.1696
Avg	1.2895	.8620	.9616	.2575	.2745	.2563

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274140 / 33/11KV Bramhapuri S/S

Feeder No / Name : 201 / 11 Kv Machnur new

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.5138	.4268	.4877	.2439	1.3108	1.8187
2	.0514	.547	.4268	.4268	.2439	1.3435	1.8351
3	.0514	.5636	.4572	.4725	.2439	1.3435	1.8515
4	.0514	.6299	.4572	.3658	.2439	1.3927	1.8679
5	.0514	.6299	.4572	.381	.2743	1.3927	1.8515
6	.0514	.6299	.4572	.4268	.2743	1.4255	1.8679
7	.0514	.6133	.4725	.4268	.2896	1.5729	1.8842
8	.0514	.5967	.503	.3658	.3353	1.5729	1.9334
9	.7537	.0549	.0549	.0514	.0686	.0549	.0549
10	.7701	.0549	.0549	.0514	.0686	.0514	.0686
11	.7373	.0549	.0549	.0514	.0686		.0686
12	.7373	.0549	.0549	.0514	.0686		
13	.6882	.0549		.0514	.0686		
14	.6226	.0549	.0549		.0686		
15	.5898	.0549	.0549	.0514	.0686		
16	.5735	.0549	.0549		.0686		
17	.0549		.0514	.0514	.0686		.0549
18	.0549	.0514	.0514	.0686		.0549	.0549
19	.0549	.0514	.0514	.0686		.0549	.0549
20	.0549	.0514	.0514	.0686	.0732	.0549	.0549
21	.0549	.0514	.0514	.0686	.0732	.0549	.0549
22	.0549	.0514	.0514	.0686	.0732	.0549	.0549
23	.0549	.3658	.5182	.2743	1.278	1.6057	1.8842
24	.0514	.4641	.4268	.5335	.2743	1.3108	1.8351
Max	.7701	.6299	.5182	.5335	1.278	1.6057	1.9334
Min	.0514	.0514	.0514	.0514	.0686	.0514	.0549
Avg	.2633	.2717	.2302	.2211	.2063	.8619	1.0079

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274140 / 33/11KV Bramhapuri S/S

Feeder No / Name : 202 / 11 Kv Bramhpuri Feeder      SEPARATED AG FEEDERS HAVING SPECIAL  
River      Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2134	.0732	.0686	.0686	.0686	.0732	.0732
2	.2134	.0732	.0686	.0686	.0686	.0732	.0732
3	.2286	.0732	.0686	.0686	.0686	.0732	.0732
4	.2286	.0732	.0686	.0686	.0686	.0732	.0732
5	.2591	.0732	.0686	.0686	.0686	.0732	.0732
6	.2591	.0732	.0686	.0686	.0686	.0732	.0732
7	.2949	.0732	.0686	.0686	.0686	.0732	.0732
8	.2785	.0732	.0686	.0686	.0686	.0732	
9	.0732	.3978	.3978	.2286	.1829	1.0159	1.278
10	.0732	.4144	.431	.1829	.1829	1.1279	1.2803
11	.0732	.2984	.3315	.2134	.1829	1.1431	
12	.0732	.2984	.2984	.1524	.1524	1.326	1.2193
13	.0732	.2818	.2984	.2134	.1524	1.326	1.3108
14	.0732	.2818	.2172	.2134	.3658	1.3413	1.3413
15	.0732	.2652	.2715	.1524		1.3413	1.2041
16	.0732	.2652	.181	.1524	.6859	1.326	1.2289
17	.0732	.0732	.0686	.0686	.0686	.0732	.0732
18	.0732	.0686	.0686	.0686	.0686		.0732
19	.0732	.0686	.0686	.0686	.0732		.0732
20	.0732	.0686	.0686	.0686	.0732	.0732	.0732
21	.0732	.0686	.0686	.0686	.0732	.0732	.0732
22	.0732	.0686	.0686	.0686	.0732	.0732	.0732
23	.0732	.0686	.0686	.0686	.0732	.0732	.0732
24	.2134	.0732	.0686	.0686	.0686	.0732	.0732
Max	.2949	.4144	.431	.2286	.6859	1.3413	1.3413
Min	.0732	.0686	.0686	.0686	.0686	.0732	.0732
Avg	.1370	.1519	.1469	.1086	.1316	.4987	.4528

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274140 / 33/11KV Bramhapuri S/S

Feeder No / Name : 203 / 11kv GFSS Bramhapuri

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.181	.1543	.1372	.1715	.2172	.2172
2	.1543	.2172	.1543	.1372	.1715	.1991	.2172
3	.1543	.2534	.1715	.1715	.1715	.1991	.2353
4	.1715	.3077	.1715	.1886	.2058	.2534	.2715
5	.1886	.2896	.2058	.2229	.2058	.3077	.2896
6	.1886	.2896	.2229	.2572	.2572	.3439	.3439
7	.2058	.2353	.2572	.2058	.2572	.3077	.3258
8	.2401	.2172	.2058	.2058	.1715	.2715	.2896
9	.1991	.1991	.1448	.1886	.1543	.1991	.2353
10	.1991	.1629	.181	.1543	.1543	.1715	.2058
11	.181	.1629	.1991	.1715	.1543	.1886	.2229
12	.181	.1629	.1629	.1543	.1219	.1886	.1715
13	.181	.1086	.181	.1543	.1543	.1715	.1886
14	.1991	.1448	.1629	.1543	.1543	.1886	.1715
15	.1991	.1267		.1543	.1886	.1886	.1886
16	.1629	.1086	.1448	.12	.1886	.1715	.1629
17	.1629	.1267	.1372	.1543	.1886		.181
18	.181	.1715	.1715	.1715	.1886	.2172	.1991
19	.1991	.1886	.2058	.2058	.2534	.2715	.2353
20	.2353	.2229	.2229	.2401	.2715	.3077	.2534
21	.2534	.2229	.2058	.2401	.2715	.3077	.2534
22	.2534	.2058	.1886	.1886	.2896	.2896	.2534
23	.2172	.1715	.1715	.1715	.2353	.2353	.2353
24	.1715	.1991	.1543	.1715	.1715	.2172	.2353
Max	.2534	.3077	.2572	.2572	.2896	.3439	.3439
Min	.1543	.1086	.1372	.12	.1219	.1715	.1629
Avg	.1931	.1949	.1816	.1801	.1980	.2354	.2326

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274140 / 33/11KV Bramhapuri S/S

Feeder No / Name : 204 / 11 KV BRAHAMPURI BORE SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.387	.0732	.0686	.0686	.0686	.0732	.0724
2	1.3108	.0732	.0686	.0686	.0686	.0732	.0724
3	1.3108	.0732	.0686	.0686	.0686	.0732	.0732
4	1.3717	.0732	.0686	.0686	.0686	.0732	.0732
5	1.4022	.0724	.0686	.0686	.0686	.0732	.0732
6	1.4327	.0732	.0686	.0686	.0686	.0732	.0732
7	1.5546	.0732	.0686	.0686	.0686	.0732	.0732
8	1.6156	.0732	.0686	.0686	.0686	.0732	.0732
9	.0732	1.6876	1.7859	1.6461	1.4784	1.6057	1.3927
10	.0732	1.8351	2.0645	1.6309	1.4937	1.6461	1.8138
11	.0732	1.8351	1.9498	1.6613	1.6156	1.5242	1.7528
12	.0732	1.8842	2.0645	1.6918	1.6766	1.5546	1.7833
13	.0732	1.9006	1.9662	1.6613	1.7071	1.5394	1.7223
14	.0732	2.0317	2.0317	1.5699	1.6309	1.5089	1.8347
15	.0732	1.9498	1.6549	1.6461	1.6613	1.6156	1.6766
16	.0732	1.917	1.7204	1.6766	1.7223	1.5851	1.6385
17	.0732	.0732	.0686	.0686	.0686		.0732
18	.0732	.0686	.0686	.0686	.0686	.0732	.0732
19	.0732	.0686	.0686	.0686	.0732	.0732	.0732
20	.0732	.0686	.0686	.0686	.0732	.0732	.0732
21	.0732	.0686	.0686	.0686	.0732	.0732	.0732
22	.0732	.0686	.0686	.0686	.0732	.0732	.0732
23	.0732	.0686	.0686	.0686	.0732	.0732	.0732
24	1.387	.0732	.0686	.0686	.0686	.0732	.0732
Max	1.6156	2.0317	2.0645	1.6918	1.7223	1.6461	1.8347
Min	.0732	.0686	.0686	.0686	.0686	.0732	.0724
Avg	.5779	.6743	.6806	.5951	.5878	.5947	.6160

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274140 / 33/11KV Bramhapuri S/S

Feeder No / Name : 205 / Machnur AG-2

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	1.1797	1.1584	1.2193	1.2193	1.3108	1.3435
2	.0686	1.1469	1.1279	1.2041	1.2193	1.2289	1.2944
3	.0686	1.1961	1.1584	1.1888	1.2193	1.1797	1.3108
4	.0686		1.2193	1.2041	1.2498	1.1797	1.278
5	.0686		1.2803	1.2498	1.2498	1.1797	1.2944
6	.0686		1.326	1.2955	1.2803	1.2452	1.3435
7	.0686		1.3717	1.4937	1.4175	1.4746	1.4746
8	.0686		1.3717	1.4937	1.4937	1.4746	1.5402
9	1.6385		.0732	.0514	.0686	.0549	.0549
10	1.6712		.0549	.0514	.0686	.0514	.0514
11	1.6057		.0549	.0514	.0686	.0514	.0514
12	1.7375	.0549	.0549	.0514	.0686	.0514	.0514
13	1.5729	.0549		.0514	.0686	.0514	.0514
14	1.5893	.0549	.0549		.0686	.0514	.0514
15	1.6221	.0549	.0549		.0686	.0514	.0514
16	1.5565	.0549	.0549		.0686	.0514	
17	.0549	1.3108	.0514	.0686	.0686	.0549	.0549
18	.0549	.0514	.0514	.0686	.0686	.0549	.0549
19	.0549	.0549	.0514	.0686	.0732	.0549	.0549
20	.0549	.0514	.0514	.0686	.0732	.0549	.0732
21	.0549	.0514	.0514	.0686	.0732	.0549	.0732
22	.0549	.0514	.0514	.0686	.0732	.0549	.0732
23	1.3108	1.2193	.4877	1.2193	1.3927	1.3108	1.3763
24	.0686	1.278	1.1888	1.2346	1.2193	1.3599	1.3599
Max	1.7375	1.3108	1.3717	1.4937	1.4937	1.4746	1.5402
Min	.0549	.0514	.0514	.0514	.0686	.0514	.0514
Avg	.6355	.4916	.5392	.6415	.5808	.5703	.6245

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274147 / 33/11 Kv Khupsangi

Substation

Feeder No / Name : 201 / 11 Kv Shirshi Feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	1.9052
Max	1.9052
Min	1.9052
Avg	1.9052

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274147 / 33/11 Kv Khupsangi

Substation

Feeder No / Name : 202 / 11 Kv Khadki Feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	1.829
Max	1.829
Min	1.829
Avg	1.829



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274147 / 33/11 Kv Khupsangi

Substation

Feeder No / Name : 203 / 11 Kv Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.4115
Max	.4115
Min	.4115
Avg	.4115

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274147 / 33/11 Kv Khupsangi

Substation

Feeder No / Name : 204 / 11 KV GONEWADI AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	1.4327
Max	1.4327
Min	1.4327
Avg	1.4327

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274185 / 33/11 KV KHOMNAL SUBSTATION

Feeder No / Name : 201 / 11 KV KHOMNAL AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	1.989						
8		.2401	.3429	.3258	.3086	.2401	.3222
16		1.8233	1.8313	2.1091	1.989	1.9227	1.757
24	.7888	.1715	.2035	.2058	.2058	.2058	.2035
Max	1.989	1.8233	1.8313	2.1091	1.989	1.9227	1.757
Min	.7888	.1715	.2035	.2058	.2058	.2058	.2035
Avg	1.3889	.7450	.7926	.8802	.8345	.7895	.7609

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274185 / 33/11 KV KHOMNAL SUBSTATION

Feeder No / Name : 202 / 11 KV DONGARGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.2743	1.8347	1.9113	1.9204	2.0388	2.0687	1.8067
16	1.4922	.1526	.1696	.2915	.3018	.2035	.181
24	.1715	.8139	1.0513	1.0802	1.2003	1.2174	1.2445
Max	1.4922	1.8347	1.9113	1.9204	2.0388	2.0687	1.8067
Min	.1715	.1526	.1696	.2915	.3018	.2035	.181
Avg	.646	.9337	1.0441	1.0974	1.1803	1.1632	1.0774

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274185 / 33/11 KV KHOMNAL SUBSTATION

Feeder No / Name : 203 / 11 KV KHOMNAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.056	.056	.0747	.0747	.0747	.0747	.0747
16	.0373	.0187	.0373	.0373	.0187	.0373	.0373
24	.0373	.0373	.0373	.0373	.0373	.0373	.0373
Max	.056	.056	.0747	.0747	.0747	.0747	.0747
Min	.0373	.0187	.0373	.0373	.0187	.0373	.0373
Avg	.0435	.0373	.0498	.0498	.0436	.0498	.0498

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274189 / 33/11 KV NANDESHWAR

SUBSTATION

Feeder No / Name : 201 / 11 KV MAULI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL

DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	1.9052
Max	1.9052
Min	1.9052
Avg	1.9052

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274189 / 33/11 KV NANDESHWAR

SUBSTATION

Feeder No / Name : 202 / 11 KV NANDESHWAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL

DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	2.4082
Max	2.4082
Min	2.4082
Avg	2.4082

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274189 / 33/11 KV NANDESHWAR

SUBSTATION

Feeder No / Name : 203 / 11 KV NANDESHWAR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.5487
Max	.5487
Min	.5487
Avg	.5487



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274116 / 33/11 KV PADHARPUR (U)

Feeder No / Name : 201 / DARSHAN MANDAP SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3944	.4115	.4287	.4115	.4115	.3944
2	.3429	.3944	.4458	.4287	.3772	.3772	.3772
3	.3772	.463	.4458	.4458	.3772	.3772	.3772
4	.4115	.4801	.4458	.4458	.4801	.3772	.3772
5	.4801	.4801	.4458	.5144	.5316	.4115	.4115
6	.5316	.5144	.583	.5658	.5316	.5316	.5144
7	.4801	.4973	.5144	.5487	.4973	.4973	.4973
8	.4287	.4458	.4801	.4287	.4287	.463	.4801
9	.4801	.5144	.463	.4973	.4904	.5658	.5281
10	.5658	.6001	.583	.583	.5658	.6224	.6036
11	.6859	.6859	.6516	.703	.6979	.679	.7545
12	.6687		.6859	.6859	.6602	.7545	.6979
13	.6859	.7202	.7373	.6859	.7167	.7167	.6602
14	.6687	.7202	.5658	.703	.7545	.7356	.6979
15	.6687	.7373	.6859	.6859	.7545	.7545	.679
16	.6516	.7545	.6859	.6859	.7167	.7167	.7167
17	.703	.7202	.6859	.703	.6687	.4973	.6173
18	.7716	.7545	.7888	.8059	.7373	.583	.6687
19	.9259	.9088	.9259	.8916	.9602	.7202	.9088
20	.9259	.8916	.703	.9431	.8745	.7716	.8402
21	.7545	.7716	.7545	.7373	.7373	.6859	.6687
22	.5658	.6001	.6173	.6173	.6001	.583	.5487
23	.4973	.4973	.4973	.463	.4801	.4801	.4458
24	.3772	.4287	.4458	.4458	.4115	.4287	.4287
Max	.9259	.9088	.9259	.9431	.9602	.7716	.9088
Min	.3429	.3944	.4115	.4287	.3772	.3772	.3772
Avg	.5830	.6076	.5937	.6101	.6026	.5726	.5789

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274116 / 33/11 KV PADHARPUR (U)

Feeder No / Name : 202 / 11KV GANESHNAGAR SHEDDABLE URBAN  
 PANDHARPUR Feeder KV- 11 /  
 OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.6859	.6859	.6516	.6687	.6859	.6859
2	.6516	.6859	.6687	.6516	.6687	.6516	.6516
3	.6859	.7716	.6516	.6859	.6516	.6516	.6516
4	.7202	.8059	.6516	.7545	.6859	.6516	.6516
5	.7545	.823	.6516	.7716	.7202	.6516	.6859
6	.7545	.823	.7888	.8059	.7545	.7716	.7716
7	.8402	.823	.9259	.8916	.8916	.7716	.8402
8	.7545	.7716	.823	.8402	.8573	.823	.7545
9	.7373	.6516	.7716	.7202	.7922	.8488	.811
10	.703	.6859	.7202	.7202	.7356	.7922	.7545
11	.6859	.6687	.6516	.703	.7167	.7545	.7545
12	.7545	.6516	.7545	.7373	.7545	.7545	.7167
13	.703	.6516	.6687	.7716	.7545	.7545	.6602
14	.6516	.6516	.6516	.7202	.7545	.7733	.6224
15		.6516	.6344	.6687	.7545	.7545	.6036
16		.703	.6344	.6687	.7167	.7167	.6036
17		.6516	.6516	.6516	.6859	.6516	.6173
18		.6687	.6344	.703	.6687	.6516	.6344
19		.7716	.6687	.823	.7716	.7888	.7545
20		.9602	.6859	.9431	.9431	.9431	.9088
21		.9088	.9259	.9431	.9088	.9259	.9088
22		.8916	.7888	.9259	.9259	.9088	.8745
23		.823	.7888	.823	.8059	.823	.7888
24	.6859	.703	.6859	.6516	.703	.7202	.7202
Max	.8402	.9602	.9259	.9431	.9431	.9431	.9088
Min	.6516	.6516	.6344	.6516	.6516	.6516	.6036
Avg	.7156	.7452	.7152	.7595	.7621	.7592	.7261

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274116 / 33/11 KV PADHARPUR (U)

Feeder No / Name : 203 / CABLE EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0343	.0343	.0343	.0343		.0343
2	.0171	.0343	.0343	.0343	.0343		.0343
3	.0171	.0343	.0343	.0343	.0343	.0343	.0343
4	.0171	.0343	.0343	.0514	.0343	.0343	.0343
5	.0343	.0343	.0343	.0514	.0514	.0343	.0343
6	.0343	.0343	.0343	.0514	.0343	.0343	.0343
7	.0171	.0343	.0343	.0343	.0514	.0343	.0343
8	.0171	.0343	.0343	.0343	.0343	.0343	.0343
9	.0343	.0343	.0343	.0514	.0377	.0377	.0377
10	.0343	.0343	.0343	.0343	.0377	.0377	.0377
11	.0343	.0343	.0343	.0343	.0377	.0377	.0377
12	.0343	.0343	.0343	.0343	.0377	.0377	.0377
13	.0343	.0343	.0514	.0343	.0377	.0377	.0377
14	.0343	.0343	.0343	.0343	.0377	.0377	.0377
15	.0343	.0343	.0514	.0343	.0377	.0377	.0377
16	.0343	.0343	.0343	.0343	.0377	.0377	.0377
17	.0343	.0514	.0343	.0343	.0343	.0343	.0343
18	.0343	.0514	.0686	.0343	.0343	.0343	.0343
19	.0343	.0514	.0686	.0343	.0514	.0343	.0343
20	.0343	.0514	.0514	.0343	.0514	.0343	.0343
21	.0343	.0514	.0514	.0343	.0343	.0343	.0343
22	.0343	.0343	.0514	.0343	.0343	.0343	.0343
23	.0343	.0343	.0514	.0343	.0343	.0343	.0343
24	.0171	.0343	.0343	.0514	.0343	.0343	.0343
Max	.0343	.0514	.0686	.0514	.0514	.0377	.0377
Min	.0171	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.0293	.0379	.0414	.0379	.0383	.0355	.0354

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274116 / 33/11 KV PADHARPUR (U)

Feeder No / Name : 204 / 11 KV AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.1715					
2	.2058	.1715					
3	.2058	.1715					
4	.2058	.1715					
5	.2058	.1715					
6	.2229	.1715					
7	.2229	.1715					
8	.2058	.2401					
9			.2401	.2915	.3772		.3395
10				.3429	.3395		.415
11			.2743	.3429	.3395		.3772
12			.3429	.3601	.3584		.3395
13			.3429	.3772		.3961	.0943
14			.3772	.3772		.3584	.0943
15			.3944	.3772		.3395	.3772
16			.3944	.3772		.415	.3395
22	.1715						
23	.1715						
24	.2058	.1715					
Max	.2229	.2401	.3944	.3772	.3772	.415	.415
Min	.1715	.1715	.2401	.2915	.3395	.3395	.0943
Avg	.2027	.1791	.3380	.3558	.3537	.3773	.2971

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274116 / 33/11 KV PADHARPUR (U)

Feeder No / Name : 205 / 11 KV SARGAM SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.4115	.4801	.4287	.4115	.4287	.4287
2	.3429	.4115	.4458	.4287	.4115	.4115	.4115
3	.3429	.4287	.4801	.4458	.4115	.4115	.4115
4	.3944	.4458	.4458	.463	.4458	.4115	.4287
5	.4287	.4801	.4458	.5144	.5487	.4287	.4458
6	.5144	.5144	.5144	.5487	.5487	.5144	.4458
7	.4801	.5487	.4801	.5487	.5144	.5144	.4801
8	.4458	.4115	.4115	.4801	.4801	.463	.4458
9	.4801	.5144	.4801	.5144	.6036	.5847	.4904
10	.6001	.5487	.5144	.583	.6224	.6413	.5658
11	.6859	.6001	.6001	.583	.6224	.679	.6036
12	.6516	.6516	.6516	.6173	.6602	.6036	.6224
13	.6859	.6516	.6859	.6344	.6224	.5658	.6036
14	.6859	.6344	.6001	.6516	.679	.5658	.6036
15	.6859	.6859	.6516	.6687	.7167	.6036	.6036
16	.6687	.703	.6516	.6687	.7545	.5658	.6413
17	.6516	.583	.6173	.6516	.6516	.4458	.6173
18	.6173	.6516	.6173	.6516	.6173	.4801	.5487
19	.6516	.6859	.7202	.6516	.6859	.5487	.6516
20	.6859	.6859	.6859	.7202	.6516	.583	.6516
21	.6173	.6173	.6173	.6516	.583	.5487	.583
22	.583	.5487	.5487	.5487	.5487	.5144	.583
23	.4801	.4801	.5144	.5487	.5144	.5144	.4801
24	.4115	.4458	.4801	.4458	.4458	.4458	.4458
Max	.6859	.703	.7202	.7202	.7545	.679	.6516
Min	.3429	.4115	.4115	.4287	.4115	.4115	.4115
Avg	.5487	.5558	.5558	.5687	.5730	.5198	.5331

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274116 / 33/11 KV PADHARPUR (U)

Feeder No / Name : 206 / 11 KV AMBIKA SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.8573	.8916	.8916	.9259	.9088	.9088
2	.8573	.8573	.8573	.8916	.8916	.8916	.9088
3	.9431	.9431	.9431	.8916	.9088	.8916	.9088
4	1.0288	1.1145	.9945	.9945	.9774	.9431	.9431
5	1.286	1.286	1.0288	1.0631	1.286	1.0117	.9945
6	1.3717	1.406	1.406	1.4746	1.4232	1.3203	1.3717
7	1.166	1.166	1.286	1.2689	1.2689	1.2003	1.2003
8	.8916	.9259	.9602	.9945	.9602	.9945	.9945
9	.8573	.8573	.8745	.9088	.9997	1.0562	1.0562
10	.8916	.9088	.9088	.9088	.9431	1.094	1.094
11	.9431		.9431	.9602	1.0562	1.0374	1.0751
12	.9088		.9602	.9259	1.094	1.0562	1.094
13	.9259	1.0802	.9774	.8916	1.1128	1.0185	1.0751
14	.9431	1.0117	.9602	.9088	1.1506	1.0562	1.0562
15	.9602	.9945	.9602	.9259	1.0562	1.094	1.094
16	.9431	.9602	.9431	.9259	1.094	.9808	1.0562
17	.9602	1.0117	.9774	.9602	.9774	.8573	.8745
18	1.0802	1.0802	1.046	1.046	1.0288	.8745	.9602
19	1.286	1.2689	1.2346	1.286	1.286	1.1317	1.1831
20	1.286	1.3203	1.3203	1.286	1.286	1.2003	1.2689
21	1.2003	1.2174	1.2003	1.2003	1.2346	1.166	1.2003
22	1.1317	1.1488	1.166	1.1488	1.166	1.1145	1.0974
23	1.0288	1.0288	1.0288	1.0288	1.0288	1.0288	.9945
24	.8916	.8916	.9259	.9431	.9259	.9259	.9259
Max	1.3717	1.406	1.406	1.4746	1.4232	1.3203	1.3717
Min	.8573	.8573	.8573	.8916	.8916	.8573	.8745
Avg	1.0267	1.0608	1.0331	1.0302	1.0868	1.0356	1.0557

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274144 / 33/11 KV LINK ROAD

Feeder No / Name : 201 / 11 KV Manisha Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5068	.5144	.5316	.4973	.4973	.4801	.5144
2	.4887	.4973	.5316	.4801	.4801	.463	.4973
3	.4887	.4973	.5658	.4801	.4801	.4458	.4973
4	.5068	.4973	.6001	.4801	.4801	.4458	.5144
5	.543	.5487	.6001	.5487	.5144	.4973	.5487
6	.6154	.583	.6173	.6344	.5487	.5487	.5316
7	.6516	.6173	.6859	.703	.583	.5487	.6173
8	.6335	.6516	.7373	.7716	.6001	.6687	.6859
9	.5658	.6516	.6344	.7202	.6468	.6516	.5175
10	.4973	.4801	.4458	.4801	.5544	.4973	.5175
11	.4115	.4287	.4287	.4801	.4805	.4801	.499
12	.4458	.4458	.4287	.4973	.4805	.547	.462
13	.4801	.463	.4458	.4801	.4805	.463	.4805
14	.4801	.4801	.463	.4287	.4805	.4458	.499
15	.4973	.4115	.4115	.4458	.4805	.4801	.4458
16	.4973	.463	.3944	.4287	.499	.4973	.4287
17	.5359	.4973	.4458	.4287	.463	.4115	.4287
18	.5544	.5316	.4973	.4973	.4973	.4287	.463
19	.6838	.6516	.6516	.583	.6173	.5144	.6001
20	.7373	.7373	.6859	.703	.703	.6516	.6859
21	.7202	.6859	.7202	.7545	.7202	.6516	.6687
22	.6859	.6516	.7392	.6859	.6687	.6173	.6859
23	.6001	.583	.6468	.6001	.5658	.5658	.583
24	.543	.5144	.4973	.5729	.5316	.4973	.5144
Max	.7373	.7373	.7392	.7716	.7202	.6687	.6859
Min	.4115	.4115	.3944	.4287	.463	.4115	.4287
Avg	.5571	.5451	.5586	.5576	.5439	.5208	.5369

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274144 / 33/11 KV LINK ROAD

Feeder No / Name : 202 / 11KV PANI PURWATHA EXP. NON SHEDDABLE WATER SUPPLY AND  
Feeder KV- 11 / OUTGOING UTILITY

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8962	.583	.8573	.6001	.703	.5144	.8573
2	.9896	.6173	1.0631	.6001	.6344	.6173	.8916
3	1.0829	.6687	1.1145	.7545	.7373	.6173	.9259
4	1.2136	.7373	1.166	.9431	.7545	.6344	.9945
5	1.3443	.9259	1.2346	.9602	.9259	.6859	1.0802
6	1.4563	1.0117	1.3032	.9774	1.3375	.6859	1.3203
7	1.1016	1.0288	1.286	.9602	1.3375	.6859	1.3375
8	1.0829	1.0117	1.286	.9602	1.1145	.9774	1.3203
9	.9945	1.286	1.3032	.9259	1.4045	.9431	1.2689
10	.9774	1.3032	1.2689	.9259	1.1643	.9259	1.4045
11	1.286	1.2689	1.1145	.9602	1.0719	.9602	1.4045
12	1.3032	.9259	1.1317	.9602	1.1088	.9945	1.386
13	1.2517	1.2174	1.1488	1.166	1.0719	.9602	1.3121
14	1.2346	1.2346	1.1488	1.2517	1.0349	.9088	1.2567
15	.9088	.4115	1.1317	1.046	.9055	1.0974	1.0117
16	.961	.7888		.8916	.6653	1.2003	.8745
17	.9425	.6859	.6173	.8916	1.046	1.1831	.8745
18	.8686	.583	.5487	.8745	.5144	.7545	.5658
19	.3881	.5144	.5144	.6516	.1886	.5144	.2401
20	.2058	.1886	.2572	.4801	.1886	.1715	.2229
21	.4458	.6001	.2218	.1715	.1715	.4801	.2229
22	.5144	.6859	.7023	.1886	.1715	.6859	.6516
23	.5658	.7545	.6653	.7716	.4458	.7373	.6173
24	.8402	.6001	.823	.6468	.7545	.2058	.7716
Max	1.4563	1.3032	1.3032	1.2517	1.4045	1.2003	1.4045
Min	.2058	.1886	.2218	.1715	.1715	.1715	.2229
Avg	.9523	.8181	.9525	.8150	.8105	.7559	.9506



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274144 / 33/11 KV LINK ROAD

Feeder No / Name : 203 / 11 KV ISBAWI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8131	.8916	.8573	.7888	.7545	.823	.8573
2	.8131	.8573	.8745	.7373	.7545	.7888	.8573
3	.7947	.9259	.8916	.7202	.7888	.7545	.8916
4	.7947	.9259	.9602	.703	.7716	.7202	.8916
5	1.0164	.9602	.9602	.7716	.8745	.7888	.9088
6	1.1088	.9945	1.0117	.9945	.9602	.8573	.9259
7	1.1458	.9431	.9774	.9602	1.0974	1.0288	.9259
8	.9979	.8745	.9774	.9431	.9602	.9945	.9259
9	.8402	.7545	.8059	.8916	.9425	.9088	.8059
10	.7888	.7373	.7888	.7202	.8686	.7888	.8316
11	.6859	.7545	.823	.6859	.7947	.7545	.8131
12	.6687	.7373	.7373	.6859	.8686	.7202	.7577
13	.703	.7202	.7545	.6516	.8501	.6859	.8316
14	.6687	.703	.7373	.6516	.8316	.6687	.8316
15	.6859	.7202	.703	.6173	.7577	.6173	.7888
16	.6838	.7545	.6516	.6173	.7023	.6516	.7888
17	.1848	.7373	.7373	.7545	.7202	.7373	.7545
18	.2033	.7373	.823	.7202	.7545	.7373	.703
19	1.2567	.9945	1.0288	.9088	.8916	.8059	.823
20	1.1831	1.0288	1.0631	1.0117	1.0288	.9945	.9774
21	1.1317	1.0288	1.1488	1.0802	1.0117	1.0117	.9945
22	1.1145	1.046	1.2012	.9774	1.0802	1.046	1.0631
23	1.0631	.9259	.9979	.9088	.9431	.9259	.823
24	.8316	.8916	.8402	.9055	.8059	.8573	.823
Max	1.2567	1.046	1.2012	1.0802	1.0974	1.046	1.0631
Min	.1848	.703	.6516	.6173	.7023	.6173	.703
Avg	.8408	.8602	.8897	.8086	.8672	.8195	.8581

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274144 / 33/11 KV LINK ROAD

Feeder No / Name : 402 / 33KV Bandishegaon

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	8.3162	9.0021	7.2017	6.8416	7.9218	7.8704	7.7161
2	8.039	9.1564	7.4074	6.7901	7.9218	8.5391	8.0247
3	8.2053	9.2593	7.6132	6.4301	7.8704	8.4362	8.642
4	8.3716	9.5679	7.8704	6.1214	7.6646	8.3848	8.7449
5	8.9815	9.6708	8.0247	7.4074	8.3333	8.3333	9.3622
6	9.2587	10.0823	8.3333	8.8992	9.3107	8.4362	10.1338
7	8.7043	9.0535	8.4877	8.7449	9.8251	8.5905	10.751
8	8.4825	8.8992	7.8704	8.5905	9.6194	8.2305	10.1338
9	5.4527	8.0247	6.0185	8.8477	9.9794	10.2366	7.8704
10	7.2531	7.9733	9.465	8.642	11.4209	8.5905	11.1991
11	7.0473	7.4074	9.6708	8.5905	10.7002	11.4712	10.3155
12	7.2017	6.07	9.6194	9.2593	10.5339	11.1626	11.3655
13	7.1502	7.0988	9.465	8.8477	8.8152	10.4424	10.6379
14	5.607	7.6132	9.4136	8.8477	11.1437	10.5453	10.9774
15	8.2305	7.8189	9.8766	9.465	12.0862	10.5453	10.9568
16	8.7597	8.0761	9.0021	8.5905	12.1971	10.5967	10.751
17	4.9897	1.0288	3.5494	3.9095	3.7037	4.2181	4.0124
18	5.5441	4.8868	4.2696	3.8066	4.3724	4.6811	3.9609
19	5.7105	5.4527	4.7325	4.5268	4.784	4.8868	4.2181
20	5.8128	5.8642	4.8868	4.8868	1.6975	4.9897	4.5268
21	4.9897	5.2469	4.5268	4.5268	4.8868	4.784	4.1152
22	4.7325	4.8354	4.6016	4.1667	4.2181	4.4753	3.858
23	8.9506	6.9959	7.4846	9.465	7.6132	7.6646	6.893
24	8.538	8.8992	6.9445	7.54	7.3045	7.6646	7.5617
Max	9.2587	10.0823	9.8766	9.465	12.1971	11.4712	11.3655
Min	4.7325	1.0288	3.5494	3.8066	1.6975	4.2181	3.858
Avg	7.2637	7.4160	7.3473	7.2393	8.0802	8.0740	8.1970

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 276001 / 110/11 KV PANDHARPUR

Feeder No / Name : 203 / 11 KV VITHAL MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.1088	1.2012	1.2012	1.2936	1.2136	1.2012	1.1269
Max	1.1088	1.2012	1.2012	1.2936	1.2136	1.2012	1.1269
Min	1.1088	1.2012	1.2012	1.2936	1.2136	1.2012	1.1269
Avg	1.1088	1.2012	1.2012	1.2936	1.2136	1.2012	1.1269

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 276001 / 110/11 KV PANDHARPUR

Feeder No / Name : 207 / 11 KV WATER WORKS SHEDDABLE URBAN  
 PANDHARPUR Feeder KV- 11 /  
 OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.5935	.5935	.6706	.5935	.6001	.5935	.6201
Max	.5935	.5935	.6706	.5935	.6001	.5935	.6201
Min	.5935	.5935	.6706	.5935	.6001	.5935	.6201
Avg	.5935	.5935	.6706	.5935	.6001	.5935	.6201

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274048 / 33/11 KV BHALWANI SUBSTATION

Feeder No / Name : 201 / 11KV Bhalwani

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2172	.2126	.9955	1.0631	1.4175	1.3413	1.3426
2	.2172	.2126	.9955	1.0631	1.4175	1.3413	1.3426
3	.2534	.2126	1.086	1.2403	1.4175	1.3413	1.3426
4	.2896	.2126	1.267	1.3717	1.5238	1.3592	1.3757
5	.3258	.2835	1.448	1.7718	1.6832	1.3757	1.3923
6	.362	.3366	1.7194	2.073	2.1616	2.0222	1.8896
7			1.828	2.2148	2.4451	1.3916	2.304
8			2.2443	2.3211	2.3034	1.2407	.9282
9	1.949	1.9667					
10	1.9313						
11	1.9845						
12	1.8781						
13	1.8781						
14	1.8959						
15	1.8959			.1646	.1629		.2033
16	1.9313			.1829	.181	.2353	.2218
17	.1595			.2012	.181	.2353	.2218
18	.2303			.3012	.2218	.2353	.2126
19	.2658			.3189	.2587	.2353	.2303
20	.2303			.3189	.3142	.362	.2658
21	.2303			.2835	.2772		.2481
22	.2126			.2126	.2402		.2481
23	.2126			1.4529	1.3426	1.4842	1.2403
24	.2172	.2126	.9955	.9745	1.4175	1.3748	1.5023
Max	1.9845	1.9667	2.2443	2.3211	2.4451	2.0222	2.304
Min	.1595	.2126	.9955	.1646	.1629	.2353	.2033
Avg	.8531	.4562	1.3977	.9739	1.0537	1.0384	.9173

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274048 / 33/11 KV BHALWANI SUBSTATION

Feeder No / Name : 202 / 11KV Jainwadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1393	.9745		.5487	.5121		.5175
2	1.1393	.9745		.5487	.4961		.5175
3	1.2269	.9745		.567	.4961		.5175
4	1.4022	.9922		.6024	.5316		.5544
5	1.6651	1.4175		.6379	.5847		.5914
6	1.858	1.7187		.6733	.6379		.6283
7	1.9909	2.4097					
8	2.0814	2.073	.5068				
9				2.0908	1.8099		1.9281
10				2.1085	1.9909		1.9938
11				1.949	1.8461		1.9938
12				1.7718	1.6289		1.9938
13				1.7718	1.6289		2.0111
14				1.4883	1.5565		1.595
15	.4252			1.5592	1.6832		1.7337
16	.443			1.701	1.7013	.4525	1.7164
17	.5316			.4572	.4706		.4435
18	.5493			.4961	.462		.462
19	.567			.5316	.5359		.5487
20	.5493			.5847	.5914		.567
21	.5316			.567	.5544		.5316
22	.5316			.5316	.5175		.5316
23	1.1163			.5121	.5175	.5068	.5316
24	1.1393	1.0631	.5068	.5316	.5121	.5175	.5175
Max	2.0814	2.4097	.5068	2.1085	1.9909	.5175	2.0111
Min	.4252	.9745	.5068	.4572	.462	.4525	.4435
Avg	1.0493	1.3997	.5068	1.0105	.9666	.4923	1.0194

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274048 / 33/11 KV BHALWANI SUBSTATION

Feeder No / Name : 203 / 11 KV KESKARWADI AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1765	1.4175		.2126	.1595		.1478
2	1.1765	1.4175		.2126	.1595		.1478
3	1.267	1.4883		.2303	.1595		.1663
4	1.3575	1.6832		.2481	.2126		.1663
5	1.448	1.7718		.2481	.2481		.2218
6	1.6289	1.8781		.2835	.2835		.2587
7	1.8099	2.1616					
8	1.9366	2.0553					
9				1.949	1.448		2.2045
10				.7087	1.448		1.989
11				1.949	.6335		1.989
12				2.1262	2.2805		1.989
13				2.3211	2.2624		1.989
14				2.1262	2.1176		1.9062
15	.124			2.2325	2.3348		1.8399
16	.0532			1.701	.1448	.181	.1478
17	.1417			.1949	.1448		.1478
18	.1595			.1772	.2402		.2033
19	.1595			.1772	.2402		.1949
20	.1417			.1772	.1848		.2126
21	.124			.1595	.1848		.1772
22	.1029			.1417	.1294		.1772
23	1.4529			.1595	.1109	.1629	.1595
24	.3429	1.4175	.2172	.2126	.1595	.1109	.1663
Max	1.9366	2.1616	.2172	2.3211	2.3348	.181	2.2045
Min	.0532	1.4175	.2172	.1417	.1109	.1109	.1478
Avg	.8113	1.6990	.2172	.8159	.6949	.1516	.7546

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274048 / 33/11 KV BHALWANI SUBSTATION

Feeder No / Name : 204 / 11 KV BHALWANIN GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3841		.4268	.4115		
2	.3734	.3734		.4268	.4784		
3	.4001	.3944		.4572	.4115		
4	.4268	.4146		.4877	.4572		
5	.4534	.5449		.5487	.5792		
6	.7068	.5716		.7316	.7316		
7	.5068	.503		.6401	.6706		
8	.4534	.5487	.4934	.5335	.4961		
9	.3572	.4572		.3201	.4001		.4706
10	.2317			.2896	.4268		.3382
11	.2896			.3544	.4668		.3517
12	.2915			.2743	.4668		.3382
13	.2675			.2743	.2667		.3429
14	.2896			.2134	.2534		.3111
15	.2896			.3012	.2667		.2705
16	.2667			.3048	.2667	.3067	.2705
17	.3894			.306	.3067		.3246
18	.4572			.442	.3704		.3517
19	.514			.5487	.5335		.503
20	.5182			.6706	.5601		.6401
21	.4793			.6097	.5068		.6733
22	.4001			.4743	.4268		.567
23	.3734			.4054	.3841	.5068	.4001
24	.3734	.3894	.5068	.4268	.4115	.3841	.3734
Max	.7068	.5716	.5068	.7316	.7316	.5068	.6733
Min	.2317	.3734	.4934	.2134	.2534	.3067	.2705
Avg	.3951	.4581	.5001	.4362	.4396	.3992	.4079



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274048 / 33/11 KV BHALWANI SUBSTATION

Feeder No / Name : 205 / 11 KV CHOUGHULEWADI SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1417		.9745	1.2757	1.1401	
2	.1372	.1417		.9745	1.2757	1.0898	
3	.1543	.1417		1.0631	1.2757	1.0898	
4	.1715	.1772		1.0631	1.382	1.073	
5	.1715	.2126		1.2403	1.4529	1.073	
6	.1886	.2303		1.5947	1.6832	1.4754	
7				1.7718	2.2148	1.9951	
8			1.9185	2.0022	2.0022	1.8896	
9	2.0199	1.9667	.9955				
10	1.7718						
11	1.5947						
12	1.0631						
13	1.2403						
14	1.4175						
15	1.4175			.0886	.0905		.0739
16	1.5947			.0886	.0905	.1267	.1294
17	.0886			.0886	.1267		.1109
18	.124			.1417	.1663		.1294
19	.1595			.1595	.1848		.124
20	.1772			.1417	.1848		.1595
21	.1595			.124	.1663		.1595
22	.1417			.124	.1294		.1417
23	.1417			1.286	1.2574	1.267	1.1517
24	.1372	.1417	.9955	.9745	1.2757	1.2071	1.267
Max	2.0199	1.9667	1.9185	2.0022	2.2148	1.9951	1.267
Min	.0886	.1417	.9955	.0886	.0905	.1267	.0739
Avg	.6459	.3942	1.3032	.7723	.9019	1.2206	.3447

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274048 / 33/11 KV BHALWANI SUBSTATION

Feeder No / Name : 206 / 11 KV GARDI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274048 / 33/11 KV BHALWANI SUBSTATION

Feeder No / Name : 207 / 11 KV SATPUTEWADI SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.4287
Max	.4287
Min	.4287
Avg	.4287

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274049 / 33/11 KV BHANDHSHEGAON

Feeder No / Name : 201 / 11 KV SHELAVE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2634	2.4863	.4287	.2401	.3086	.3772	.3944
2	2.2291	2.4863	.4115	.2401	.2743	.3772	.3772
3	2.1776	2.6578					
4	2.1776	2.7778					
5	2.332	2.9321					
6	2.4348	3.0178					
7	2.6235	3.1379					
8	2.7606	3.2236					
9			2.8121	2.7778	2.7435	3.4808	3.4465
10			3.2579	2.915	3.4465	3.6866	3.6008
11			3.4465	3.0521	3.3265	3.7723	3.2579
12			3.4294	3.1379	3.3608	3.8923	3.4294
13			3.3951	3.0007	3.4465	3.6008	3.5322
14			3.3608	2.9492	3.5322	3.7209	3.6008
15	.3601	.2401	3.4637	2.8807	3.6008	3.2922	3.6866
16	.3944	.3429	2.7606	3.0864	3.5665	3.2579	3.2579
17	.3601		.2229	.3086	.3258	.3772	.3772
18	.3429	.4287	.2915	.2915	.3429	.4115	.3601
19	.463	.463	.3258	.3086	.3944	.463	.3944
20	.4801	.4973	.3772	.3601	.4287	.4287	.3601
21	.3429	.4973	.3429	.3429	.4287	.3944	.3429
22	.3429	.4801	.2915	.3772	.4458	.4115	
23	2.3834	.463	.2915	.3429	.4458	.3944	.3086
24	2.5377	2.4348	.4287	.2743	.3429	.4287	.3944
Max	2.7606	3.2236	3.4637	3.1379	3.6008	3.8923	3.6866
Min	.3429	.2401	.2229	.2401	.2743	.3772	.3086
Avg	1.5003	1.6804	1.6299	1.4937	1.7090	1.8204	1.8307

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274049 / 33/11 KV BHANDHSHEGAON

Feeder No / Name : 202 / 11 KV BHALAWANI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	1.1145	.9431	1.166	1.0802	1.2346
2	.1715	.1715	1.1145	.9945	1.1145	1.0802	1.286
3			1.2003	1.046	1.2003	1.166	1.3717
4			1.3717	1.0802	1.4575	1.2689	1.6289
5			1.6289	1.0974	1.7147	1.4746	1.8004
6			1.8861	1.3203	2.0576	1.6632	2.0576
7			2.3148	1.5261	2.3148		2.4006
8			2.0576	1.749	2.1434		2.1948
9	1.8861	1.8861					
10	1.8861	2.0576					
11	1.8861	2.0576					
12	1.8861	2.0576					
13	1.8861	1.7147					
14	1.8861	1.5432					2.1434
15	1.8861	1.7147		.1543			
16	1.7147	1.7147		.1543			
17	.1543	.1715		.1715	.1543	.1715	
18	.1715	.1715		.1715	.1715	.1715	.1715
19	.2229	.1715	.1886	.2058	.1715	.1715	.2229
20	.2229	.1886	.1715	.2401	.1886	.2572	.2229
21	.1715	.2058	.1715	.2058	.1886	.2058	.1886
22	.1715	.1886	.1715	.1886	.1886	.1715	.1715
23	.1715	1.286	1.166	1.0288	1.0802	1.2346	1.5432
24	.1715	.1715	1.2003	.9945	1.166	1.1317	1.2003
Max	1.8861	2.0576	2.3148	1.749	2.3148	1.6632	2.4006
Min	.1543	.1715	.1715	.1543	.1543	.1715	.1715
Avg	.9288	.9802	1.1256	.7373	1.0299	.8035	1.2399

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274049 / 33/11 KV BHANDHSHEGAON

Feeder No / Name : 203 / 11 KV PALASHI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	1.8861	2.0233	2.1434	2.0576	2.1434
2	.1715	.1543	1.9719	2.0748	2.1434	2.0576	2.2291
3			2.0576	2.1262	2.2291	2.1605	2.3148
4			2.2291	2.1605	2.3148	2.2805	2.4006
5			2.4863	2.2119	2.4006	2.4863	2.572
6			2.6578	2.4863	2.4863	2.692	2.8292
7			2.915	2.7606	3.2579	2.7435	3.2579
8			2.6578	2.9664	3.0864	3.2236	3.0007
9	.1715	2.572					
10	2.4006	2.6578					
11	2.4006	2.572					
12	2.4006	2.6578					
13	2.3148	2.6578					
14	2.2634	2.572					
15	2.4006	2.572	.12	.1543	.12		.1543
16	2.3148	2.4863	.1372	.1715	.1543		.2058
17	.1543	.1715	.1543	.2058	.1543	.2058	.2058
18	.1715	.1886	.1886	.2401	.1715	.2401	.2229
19	.2229	.2572	.2058	.2572	.2229	.3086	.2572
20	.2743	.3086	.2401	.2915	.2572	.3429	.2572
21	.1715	.2401	.2229	.2572	.2401	.2743	.2572
22	.1715	.2058	.2058	.2058	.2058	.2229	.2058
23	.1715	1.8861	1.9547	2.2291	2.0576	2.2291	2.0919
24	.1715	.1715	1.8861	2.0233	2.2291	2.0919	2.1434
Max	2.4006	2.6578	2.915	2.9664	3.2579	3.2236	3.2579
Min	.1543	.1543	.12	.1543	.12	.2058	.1543
Avg	1.0288	1.3613	1.3432	1.3803	1.4375	1.6011	1.4861

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274049 / 33/11 KV BHANDHSHEGAON

Feeder No / Name : 204 / 11 KV PIRACHI KUROLI SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2119	2.3834	.2058		.2401		.2229
2	2.2119	2.4006	.2058		.2058		.2058
3	2.2634	2.4348					
4	2.2634	2.4863					
5	2.2805	2.4863					
6	2.2805	2.5377					
7	2.4006	2.6063					
8	2.4863	2.6578					
9			2.7778	2.915	2.8292	2.8292	3.0007
10			3.0007	2.7778	2.9492	3.0521	3.0864
11			3.0178	2.4348	3.1207	3.1722	3.0864
12			3.0007	2.8292	3.155	3.2579	3.0864
13			2.9835	2.8635	3.1379	3.1722	3.0521
14			2.9492	2.8464	3.0521	3.1722	3.0521
15			2.7778	2.6749	2.915	3.2407	3.035
16			2.6406	3.0178	3.0007	3.0864	2.8807
17	.2401						
18	.2572						.1543
19	.2572	.1715		.2915			.1543
20	.2572	.2572		.3086		.2572	.1543
21	.2743	.2572		.2743		.2572	.1372
22		.2401		.2572		.2401	.1372
23	2.5377	.2401		.2572		.2401	.1543
24	2.4348	2.6235	.2229		.2572		.2229
Max	2.5377	2.6578	3.0178	3.0178	3.155	3.2579	3.0864
Min	.2401	.1715	.2058	.2572	.2058	.2401	.1372
Avg	1.6438	1.6988	2.1621	1.8268	2.2603	2.1648	1.519

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274049 / 33/11 KV BHANDHSHEGAON

Feeder No / Name : 205 / 11 KV BHANDISHEGAON

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /  
OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5658	.5487	.583	.5144	.5144	.5144
2	.5144	.6516	.5658	.6516	.5144	.5658	.5316
3	.583	.7373	.6516	.7202	.6001	.6687	.5487
4	.6687	.8402	.7716	.7716	.6859	.7373	.6859
5	.823	.9259	.8573	.8059	.8059	.8402	.7716
6	1.0117	1.0288	1.0288	1.0117	.9945	.9088	.9088
9	.7716	.6516	.6173	.6344	.6859	.6344	.6173
10	.6344	.6173	.6173	.5658	.6173	.4973	
11		.4458	.4458	.5316	.463	.463	.5316
12	.5144		.4287	.5144	.4287	.4287	.5144
13	.463	.4287	.4287	.463	.4287	.4287	.4801
14	.4458	.4287	.4115	.4287	.4458	.4115	.4458
15	.463	.463	.4287	.463	.463	.4115	.4801
16	.4458	.463	.4115	.463	.4287	.4458	.4801
17	.4801		.4458	.4973	.463	.4801	.4973
18	.6173	.6173	.4973	.5144	.5316	.5487	.6687
19	.7545	.7716	.6001	.6859	.6001	.6859	.7716
20	.9088	.9259	.7373	.823	.7202	.8573	.7202
21	.6687	.823	.6516	.6859	.6687	.7716	.6859
22	.583	.6344	.583	.6173	.6001	.583	.6344
23	.5487	.6001	.5487	.5487	.5658	.583	.6173
24	.5658	.5144	.5487	.5487	.5144	.5316	.5487
Max	1.0117	1.0288	1.0288	1.0117	.9945	.9088	.9088
Min	.4458	.4287	.4115	.4287	.4287	.4115	.4458
Avg	.6181	.6567	.5830	.6150	.5791	.5908	.6026



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274049 / 33/11 KV BHANDHSHEGAON

Feeder No / Name : 206 / 11 Kv Supali

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0514	.6859	.6001	.823	.7545	.7202
2	.0514	.0514	.6001	.6001	.7716	.7545	.7545
3			.6859	.6344	.7716	.7888	.7202
4			.6859	.6516	.8573	.823	.7373
5			.7716	.6516	.8916	.8916	.7545
6			.8573	.8059	.9431	.8916	.7716
7			.9431	.9945	.9774	.9431	1.0288
8			.9431	1.0631	.9431	.9088	.9431
9	.8059	.8573					
10	.7716	.9602					
11	.8573	.9431					
12	.823	.8573					
13	.823	.8573					
14	.7888	.8573					
15	.7716	.8573	.0171	.0514	.0343		.0514
16	.6859	.7716	.0343	.0343	.0343		.0514
17	.0514	.0343	.0343	.0343	.0343	.0343	.0343
18	.0686	.0514	.0514	.0343	.0343	.0343	.0514
19	.0514	.0686	.0514	.0514	.0514	.0514	.0857
20	.0686	.0686	.0686	.0514	.0686	.0514	.0514
21	.0686	.0686	.0686	.0514	.0686	.0514	.0514
22	.0686	.0686	.0686	.0686	.0686	.0514	.0514
23	.0686	.6859	.6687	.8573	.7202	.8573	.8745
24	.4287	.0514	.6859	.7202	.8573	.7716	.7716
Max	.8573	.9602	.9431	1.0631	.9774	.9431	1.0288
Min	.0514	.0343	.0171	.0343	.0343	.0343	.0343
Avg	.4058	.4534	.4401	.4420	.4973	.5412	.4725

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274049 / 33/11 KV BHANDHSHEGAON

Feeder No / Name : 207 / TEJUS AGRO EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3944	.2058		.0686		.2401	.2058
2	.4287	.2058				.2401	.2058
3	.4287	.2229				.2743	.2401
4	.4115	.2401				.2915	.2572
5	.4115	.2572		.0686		.3086	.2915
6	.3772	.2572		.0686		.3086	.2915
7	.4115		.0686			.2743	.1715
8	.4287		.0686			.1543	
9	.4458			.0514		.3429	
10	.3601		.0686			.2401	
11	.3429		.0857	.0514	.1372	.2572	
12	.4287		.0857	.0514	.2229	.3086	
13	.4458		.0857	.0686	.2572	.2229	
14	.3944		.1029	.0857	.1715	.2229	
15	.4115		.3258		.2229	.2229	
16	.4287		.1372	.0686	.2058	.2743	
17	.463		.12	.0686	.2401	.2915	
18	.3429		.2401	.1029	.2401	.2401	
19	.3429		.2743	.1029	.2229	.2058	
20	.3258		.2743	.0857	.2058	.2058	
21	.3429		.2572	.0857	.2058	.1715	
22	.2743		.2401	.0686	.2572	.1715	
23	.2743		.2401	.0686	.2572	.2572	
24	.3944	.2572		.1886		.2229	.2229
Max	.463	.2572	.3258	.1886	.2572	.3429	.2915
Min	.2743	.2058	.0686	.0514	.1372	.1543	.1715
Avg	.3879	.2352	.1672	.0797	.2190	.2479	.2358

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274050 / 33/11 CHALE S/STN

Feeder No / Name : 201 / 11 KV KALERAN

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	2.1338	2.1338	1.0669	1.829	2.4387	2.4387
2	.3048	2.1338	2.1338	1.0669	1.829	2.4387	2.4387
3		2.4387	2.1338	1.5242	1.829	2.4387	2.4387
4		2.4387	2.1338	1.5242	2.2862	2.5911	2.5911
5		2.4387	2.1338	1.5242	2.2862	2.5911	2.5911
6		2.4387	2.1338	1.9814	2.2862	2.7435	2.7435
7		2.4387	1.9814	1.9814	2.2862	2.7435	2.7435
8		2.4387	2.1338	1.9814	2.2862	2.7435	2.6673
9	2.7435						
10	2.7435						
11	2.7435						
12	2.5911						
13	2.5911						
14	2.5911						
15	2.5911						
16	2.5911						
17	.1524	.1524	.1524	.1524	.1524	.1524	.1524
18	.1524	.1524	.1524	.1524	.1524		.1524
19	.1524	.1524	.1524	.1524	.1524	.1524	.1524
20	.1524	.1524	.1524	.1524	.1524	.1524	.1524
21	.1524	.1524	.1524	.1524	.1524	.1524	.1524
22	.1524	.1524	.1524	.1524	.1524	.1524	.1524
23	1.9814	1.9814	1.0669	1.7528	.1524	.1524	.1524
24	.4287	1.9814	1.9814	1.0669	1.829	.1524	.1524
Max	2.7435	2.4387	2.1338	1.9814	2.2862	2.7435	2.7435
Min	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Avg	1.3956	1.4861	1.3050	1.0240	1.2384	1.4530	1.3670

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274050 / 33/11 CHALE S/STN

Feeder No / Name : 202 / 11 KV AMBE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9814	.1524	.1524	.2286	.3048	.1524	.1524
2	1.9814	.1524	.1524	.2286	.3048	.1524	.1524
3	2.2862						
4	2.2862						
5	2.2862						
6	2.2862						
7	2.2862						
8	2.2862						
9		2.1338	2.5911	2.1338	2.5911	3.2007	2.8197
10			2.5911	2.1338	2.5911	3.2007	2.8197
11			2.5911	2.1338	2.5911	3.0483	2.8197
12			2.5911	2.1338	2.5911	2.5911	3.0483
13			2.5911	2.1338	2.5911	2.5911	3.0483
14			2.5911	1.829	2.5911	2.5911	2.8959
15			2.3624	1.829	2.5911	2.5911	2.8959
16			2.3624	1.829	2.5911	2.5911	2.8959
17	.1524		.1524	.1524	.1524	.1524	.1524
18	.1524	2.1338	.1524	.1524	.1524	.1524	.1524
19	.1524	.1524	.1524	.1524	.1524	.1524	.1524
20	.1524	.1524	.1524	.1524	.1524	.1524	.1524
21	.1524	.1524	.1524	.1524	.1524	.1524	.1524
22	.1524	.1524	.1524	.1524	.1524	.1524	.1524
23	.1524	.1524	.1524	.1524	.1524	.1524	.1524
24	.3772	.1524	.1524	.2286	.3048	.1524	.1524
Max	2.2862	2.1338	2.5911	2.1338	2.5911	3.2007	3.0483
Min	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Avg	1.1953	.5487	1.2109	.9949	1.2617	1.3294	1.3760

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274050 / 33/11 CHALE S/STN

Feeder No / Name : 203 / 11 Kv Ranzani

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	1.3717	1.3717	.9145	2.1338		2.2862
2	.1524	1.3717	1.3717	.9145	2.1338	2.2862	2.2862
3		1.829	1.829	.9145	2.2862	2.2862	2.2862
4		1.829	1.829	.9145	2.2862	2.7435	2.7435
5		2.2862	1.829	1.1431	2.2862	2.7435	2.7435
6		2.2862	1.829	1.5242	2.7435	2.7435	2.7435
7		2.2862	2.2862	2.2862	2.7435	2.7435	2.7435
8		2.2862	2.2862	2.2862	2.7435	2.7435	2.7435
9	2.2862						
10	2.2862						
11	2.2862						
12	2.2862						
13	2.2862						
14	1.829						
15	1.829						
16	1.829						
17	.1524	.1524	.1524	.1524	.1524	.1524	.1524
18	.1524	.1524	.1524	.1524	.1524	.1524	.1524
19	.1524	.1524	.1524	.1524	.1524	.1524	.1524
20	.1524	.1524	.1524	.1524	.1524	.1524	.1524
21	.1524	.1524	.1524	.1524	.1524	.1524	.1524
22	.1524	.1524	.1524	.1524	.1524	.1524	.1524
23	1.3717	1.3717	1.3717	1.6766	.1524	.1524	.1524
24	.4287	1.3717	1.3717	.9145	1.6766	.1524	.1524
Max	2.2862	2.2862	2.2862	2.2862	2.7435	2.7435	2.7435
Min	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Avg	1.1076	1.2003	1.1431	.9002	1.3813	1.3006	1.3622

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274050 / 33/11 CHALE S/STN

Feeder No / Name : 204 / 11 KV CHALE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.6097	.6097	.6097	.6097	.4572	.4572
2	.7621	.6097	.6097	.6097	.6097	.6097	.6097
3	.7621	.6097	.6097	.6097	.7621	.6097	.6097
4	.9145	.7621	.7621	.7621	.7621	.7621	.7621
5	.9145	.9145	.9145	.9145	.7621	.9145	.9145
6	.9145	.9145	.9145	.9145	.7621	.9145	.9145
7	.7621	.7621	.7621	.7621	.7621	.7621	.7621
8	.7621	.6097	.6097	.7621	.7621	.7621	.7621
9	.7621	.4572	.6097	.6097	.6097	.6097	.6097
10	.6097		.6097	.6097	.6097	.6097	.6097
11	.6097		.6097	.6097	.6097	.6097	.6097
12	.4572		.4572	.6097	.6097	.6097	.6097
13	.4572		.4572	.6097	.4572	.6097	.6097
14	.4572	.4572	.4572	.6097	.4572	.6097	.6097
15	.4572			.6097	.4572	.6097	.6097
16	.4572	.4572	.381	.6097	.4572	.6097	.6097
17	.4572	.6097	.4572	.6097	.4572	.6097	.6097
18	.4572	.6097	.6097	.6097	.4572		.6097
19	.4572	.6097	.7621	.6097	.4572	.6097	.6097
20	.6097	.6097	.9145	.6097	.6097	.6097	.9145
21	.6097	.6097	.9145	.6097	.6097	.6097	.9145
22	.6097	.6097	.9145	.6097	.6097	.6097	.9145
23	.6097	.6097	.7621	.6097	.4572	.4572	.7621
24	.7621	.6097	.6097	.6097	.6097	.4572	.4572
Max	.9145	.9145	.9145	.9145	.7621	.9145	.9145
Min	.4572	.4572	.381	.6097	.4572	.4572	.4572
Avg	.6414	.6337	.666	.6542	.5970	.6362	.6859

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274050 / 33/11 CHALE S/STN

Feeder No / Name : 205 / 11 Kv Chale

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669	.1524	.1524	.1524	.3048	.1524	.1524
2	1.0669	.1524	.1524	.1524	.3048	.1524	.1524
3	1.0669						
4	1.0669						
5	1.0669						
6	1.0669						
7	1.0669						
8	1.0669						
9		1.6766	1.5242	1.3717	2.2862	2.2862	1.829
10			1.5242	1.3717	2.2862	2.2862	1.829
11			1.5242	1.2193	2.2862	1.829	1.829
12			1.5242	1.2193	2.2862	1.829	1.829
13		2.4387	1.5242	1.2193	2.2862	1.829	1.829
14		2.4387	1.5242	1.2193	2.2862	1.829	1.829
15			1.5242	1.2193	2.2862	1.829	2.2862
16		2.4387	1.5242	1.2193	1.829	1.829	2.2862
17	.1524	.1524	.1524	.1524	.1524	.1524	.1524
18	.1524	.1524	.1524	.1524	.1524	.1524	.1524
19	.1524	.1524	.1524	.1524	.1524	.1524	.1524
20	.1524	.1524	.1524	.1524	.1524	.1524	.1524
21	.1524	.1524	.1524	.1524	.1524	.1524	.1524
22	.1524	.1524	.1524	.1524	.1524	.1524	.1524
23	.1524	.1524	.1524	.1524	.1524	.1524	.1524
24	.4287	.1524	.1524	.1524	.3048	.1524	.1524
Max	1.0669	2.4387	1.5242	1.3717	2.2862	2.2862	2.2862
Min	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Avg	.6269	.7512	.7621	.6435	1.1008	.9484	.9484

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274050 / 33/11 CHALE S/STN

Feeder No / Name : 206 / 11 KV DARLING

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669	.1524	.1524	.1524	.3048	.1524	.1524
2	1.0669	.1524	.1524	.1524	.3048	.1524	.1524
3	1.2193						
4	1.2193						
5	1.2193						
6	1.2193						
7	1.2193						
8	1.2193						
9		1.0669	1.2193	1.0669	1.6766		
10			1.2193	1.0669	1.6766		
11			1.2193	1.0669			
12			1.2193	1.0669			
13			1.2193	1.0669			
14			1.2193	1.0669			
15			1.2193	1.0669			
16			1.2193	1.0669			
17	.1524		.1524	.1524	2.1338	2.2862	1.9814
18	.1524	.9145	.1524	.1524	2.1338	2.2862	2.2862
19	.1524	.1524	.1524	.1524	2.1338	2.2862	2.2862
20	.1524	.1524	.1524	.1524	1.9814	2.1338	2.2862
21	.1524	.1524	.1524	.1524	1.9814	2.1338	2.2862
22	.1524	.1524	.1524	.1524	1.9814	1.9814	2.2862
23	.1524	.1524	.1524	.1524	1.9814	1.9814	2.1338
24	.4287	.1524	.1524	.1524	.3048	1.9814	1.9814
Max	1.2193	1.0669	1.2193	1.0669	2.1338	2.2862	2.2862
Min	.1524	.1524	.1524	.1524	.3048	.1524	.1524
Avg	.6841	.3201	.6266	.5588	1.5496	1.7375	1.7832



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274053 / 33/11 KV KHARDI

Feeder No / Name : 201 / 11 KV KHARDI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	.4115	.3086	.3429	.3429	.3429	.3429
2	1.5432	.3772	.3086	.3429	.3429	.3601	.3429
3	1.6461						
4	1.6804						
5	1.7147						
6	1.9814						
7	2.7282						
8	2.4387						
9		2.3805	2.5263	2.2558	2.0405	1.2193	
10		2.6558	2.4453	2.271	2.1376	2.1033	2.21
11		2.5263	2.1052	2.1643	1.9109	2.3167	2.1338
12		2.4291	2.332	2.1795	1.8461	2.1033	2.0729
13		2.4615	2.2672	1.8595	1.9109	1.5546	2.0119
14		2.3644	2.3482	1.9052	2.1052	1.7375	2.0119
15		2.3967	2.1376	1.8747	2.1052	1.5546	1.9814
16	.2915	2.2862	2.2024	1.9685		1.6461	1.9814
17	.3772	.3086	.2572	.2572	.2155	.2229	.3086
18	.3772	.3429	.3772	.3258	.2818	.3429	.3429
19	.3258	.4801	.4115	.4458	.3481	.3772	.3772
20	.4115	.5144	.4458	.4458	.3315	.4115	.4458
21	.4458	.4801	.4115	.4458	.3315	.4115	.4287
22	.4458	.4115	.3944	.4115	.3149	.3772	.9602
23	.4458	.3086	.3772	.3429	.3258	.3601	.4115
24	1.6289	.4115	.3086	.3601	.3429	.3429	.3429
Max	2.7282	2.6558	2.5263	2.271	2.1376	2.3167	2.21
Min	.2915	.3086	.2572	.2572	.2155	.2229	.3086
Avg	1.1780	1.3082	1.2203	1.1222	1.0138	.9880	1.1004

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274053 / 33/11 KV KHARDI

Feeder No / Name : 202 / 11 KV BOHALI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	1.166	1.2955	1.3717	1.2146	1.2955	1.3717
2	.4115	1.0288	1.2631	1.3717	1.1336	1.2308	1.3717
3		1.0288	1.2146	1.3032	1.1336	1.3279	1.2346
4		1.4403	1.2146	1.286	1.1336	1.4251	1.3717
5		1.6804	1.406	1.5775	1.3927	1.4685	1.7147
6		1.9814	2.1559	2.0119	1.9216	2.1872	2.1643
7		2.5149	2.6825	2.6063	2.6368	2.4387	2.5911
8		1.0669	2.7587	2.5606	2.5149	2.8959	2.5911
9	2.4082						
10	2.4387						
11	2.4691						
12	2.0424						
13	1.9814						
14	1.9814						
15	1.9814	.1326					
16	2.2862						
17	.2229	.3086	.2915	.2401	.2321	.2229	.2743
18	.2572	.3429	.2915	.3086	.3315	.3086	.3086
19	.3086	.3429	.3429	.3429	.3647	.3772	.3429
20	.3772	.3429	.4115	.3429	.4144	.4115	.4115
21	.3429	.3429	.3429	.3429	.3647	.3772	.4115
22	.3086	.3258	.2915	.3258	.3315	.3429	.3772
23	1.2346	1.4251	1.5261	1.2955	1.4575	1.4232	1.2631
24	.4115	1.2003	1.2955	1.4575	1.2955	1.3927	1.4575
Max	2.4691	2.5149	2.7587	2.6063	2.6368	2.8959	2.5911
Min	.2229	.1326	.2915	.2401	.2321	.2229	.2743
Avg	1.2153	.9807	1.1740	1.1716	1.1171	1.1954	1.2036

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274053 / 33/11 KV KHARDI

Feeder No / Name : 203 / 11 KV T SHETPHAL  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	.4801	.4458	.4801	.4801	.4801	.5487
2	1.6194		.4458	.4458	.4801	.4801	.4801
3	1.749						
4	1.7375						
5	1.829						
6	2.0729						
7	2.6825						
8	2.3777						
9		2.3967	2.5911	2.1338	2.4615	.7773	2.3967
10		2.5263	2.4615	2.1948	2.4615	1.9372	2.4387
11		2.332	2.0729	2.1338	2.332	2.1948	2.1338
12		2.0081	1.6842	2.0119	2.0729	2.0119	2.2024
13		1.8785	2.0081	1.9509	2.1052	2.0729	1.9509
14		1.9433	1.8138	1.829	2.1376	1.9509	1.9509
15	.3429	2.0081	1.9433	1.9509	2.2024	1.9509	1.9509
16	.4115	2.1338	1.9433	2.0729	2.2672	1.9509	1.9509
17	.4115	.3772	.4115	.4115	.3315	.2286	.3429
18	.4801	.4115	.4115	.4115		.4115	.3772
19		.4801	.4801	.4458		.5487	.4115
20	.4801	.4801	.5487	.4801	.5304	.5487	.4801
21	.4801	.4801	.5144	.4801	.5304	.5487	.4801
22	.4801	.4801	.4801	.4801	.5304	.5487	.4801
23	.5487	.4801	.4801	.4801	.5487	.5487	.4115
24	1.7147	.4801	.4801	.4801	.4801	.5487	.5487
Max	2.6825	2.5263	2.5911	2.1948	2.4615	2.1948	2.4387
Min	.3429	.3772	.4115	.4115	.3315	.2286	.3429
Avg	1.2319	1.2574	1.1787	1.1596	1.372	1.0966	1.1965

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274053 / 33/11 KV KHARDI

Feeder No / Name : 204 / 11 KV KHARDI GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3086	.2915			.3086	.3086
2	.2915		.2915	.2915	.3086	.3429	.3086
3	.3429	.3086	.2915	.2915	.3086	.3944	.3086
4		.3429	.3258	.1829	.3086	.4287	.3772
5	.4458	.3772	.4458		.4458	.4801	.4458
6	.5144	.5144	.583	.5487	.583	.6001	.5658
7	.5487	.583	.5487	.5316	.583	.6001	.5658
8	.3944	.3772	.3944	.4973	.4458	.463	.4115
9	.3258	.3601	.3429	.3772	.3772	.3601	
10	.2743	.2572	.3086	.2743	.3086	.3086	.3086
11	.2401	.2401	.2743	.2401	.3086	.2572	.3086
12	.2572	.2058	.2058	.2229	.2915	.2743	.2915
13	.2401	.2401	.1886	.2401	.2743	.2743	.2915
14	.2572	.2229	.2401	.2401	.2743	.2915	.2915
15	.2743	.2401	.2401	.2229	.2743	.2915	.2915
16	.2401	.2401	.2572	.2743	.2743	.2915	.2743
17	.3086	.3601	.3429	.3086	.2743	.3429	.3429
18	.3429	.4115	.3429	.3429	.3601	.3772	.3772
19	.4115	.4973	.4458	.3944	.5144	.4458	.4287
20		.5658	.5144	.4801	.5144	.4115	.4801
21		.4801	.4801	.4458	.4287	.3772	.4458
22		.3601	.3772	.3772	.3772		.3944
23	.2915	.3086	.3086	.3429	.3429	.3772	.3429
24	.3086	.2915	.2915	.3086	.3086	.3086	.3429
Max	.5487	.583	.583	.5487	.583	.6001	.5658
Min	.2401	.2058	.1886	.1829	.2743	.2572	.2743
Avg	.3309	.3519	.3472	.3380	.3690	.3742	.3698

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274053 / 33/11 KV KHARDI

Feeder No / Name : 205 / 11KV Umbargaon  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	1.406	1.3927	1.5432	1.7814	1.749	1.5242
2		1.3717	1.3765	1.5432	1.6842	1.7166	1.7147
3		1.3717	1.3765	1.5089	1.6194	1.8138	1.7985
4		1.5775	1.4251	1.5089	1.6194	1.9433	1.9204
5		1.6194	1.9109	1.768	1.8747	2.0729	1.9814
6		2.6825	2.5606	2.2558	2.2558	2.652	2.6825
7		3.0788	3.1245		.7888	2.774	3.0483
8		2.5301	.2572	2.1338	3.0483	2.8349	2.8654
9	1.829						
10	1.7985						
11	1.829						
12	2.4387						
13	2.4082						
14	2.3167						
15	2.2862						
16		.3429					
17		.3429	.3086	.2743	.2984	.3429	.3086
18	.3429	.3772	.3772	.3086	.431	.3772	.3772
19	.4115	.4115	.4115	.4115	.4641	.4458	.4115
20	.4115	.4115	.4458	.4115	.431	.4115	.4115
21	.3772	.4115	.4458	.4115	.3978	.3772	.4458
22	.3772	.3429	.4115	.3772	.3978	.3429	.3772
23	1.5432	1.749	1.6194	1.8785	1.8461	1.749	1.749
24	.4458	1.5432	1.3927	1.6518	1.8785	1.7814	1.6766
Max	2.4387	3.0788	3.1245	2.2558	3.0483	2.8349	3.0483
Min	.3429	.3429	.2572	.2743	.2984	.3429	.3086
Avg	1.2841	1.2688	1.1773	1.1991	1.3010	1.4615	1.4558

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274053 / 33/11 KV KHARDI

Feeder No / Name : 206 / 11KV Kasegaon (BEND WASTI) SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9814	1.0288	.7716	1.0288	.8573	.9945	1.0288
2	1.9509	1.0288	.7716	1.0288	.7545	.9945	1.0288
3	1.829						
4	2.21						
5	2.5911						
6	2.8654						
7	3.1703						
8	2.9874						
9		3.336	3.4979	3.1093	3.3036	3.3532	
10		3.2388	3.4332	3.2312	3.4979	3.3836	
11		3.3036	3.3036	3.4141	3.3684	3.3532	3.0483
12		2.915	3.1417	2.8045	3.3036	3.2922	3.0788
13		3.336	3.336	2.9874	3.2388		3.0788
14		3.3036	3.3036	2.9874	.4534	2.8959	3.0788
15	.5144	3.3036	3.2712	3.3227	.4534	2.8045	3.0483
16	.583	3.1703	3.1417	3.0483		2.774	3.0178
17	.4344	.7545	.6859	.7202	.5967	.5144	.4115
18	.6859	.8573	.7545	.8573	.8951	.7202	.6173
19	.7888	1.0974	1.0288	.9602	1.094	.9945	.9259
20	1.0288	1.0974	1.0974	.9602	1.1271	1.1317	1.0288
21	1.0288	1.166	1.1317	1.0631	1.1271	1.0974	1.166
22	1.1317	1.166	1.1317	1.1317	.9614	1.0631	1.166
23	1.1145	1.1317	1.0631	1.073	1.0288	1.0631	1.0974
24	2.1643	1.1145	.823		1.0288	1.0288	1.0288
Max	3.1703	3.336	3.4979	3.4141	3.4979	3.3836	3.0788
Min	.4344	.7545	.6859	.7202	.4534	.5144	.4115
Avg	1.6145	2.0194	1.9827	1.9840	1.5935	1.8505	1.7406

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274053 / 33/11 KV KHARDI

Feeder No / Name : 401 / Sitaram Mah SSK  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)
18		1.8519
19		2.7778
20		3.0864
21		3.4979
22		3.4979
24	1.2346	
<b>Max</b>	<b>1.2346</b>	<b>3.4979</b>
<b>Min</b>	<b>1.2346</b>	<b>1.8519</b>
<b>Avg</b>	<b>1.2346</b>	<b>2.9424</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274056 / 33/11 SONAKE

Feeder No / Name : 201 / Tisangi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.4287
Max	.4287
Min	.4287
Avg	.4287



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274056 / 33/11 SONAKE

Feeder No / Name : 202 / 11 KV SONAKE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.3429
Max	.3429
Min	.3429
Avg	.3429

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274056 / 33/11 SONAKE

Feeder No / Name : 203 / 11 KV KORTI  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.3772
Max	.3772
Min	.3772
Avg	.3772

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274056 / 33/11 SONAKE

Feeder No / Name : 204 / GADEGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3472	2.3205	2.7435	2.9264	2.9264	2.9264	2.9264
2	2.3472	2.3472	2.7435	2.9264	2.9264	2.9264	2.9264
3	2.1548	2.3472	2.8349	2.7435	2.9264	2.9264	2.8349
4	2.2377	2.3472	2.9264	2.9264	3.1093	3.1093	3.0178
5	2.5149	2.5149	3.0178	3.1093	3.2922	3.2922	3.2922
6	2.8502	2.6825	3.1093	3.2922	3.658	3.8043	3.658
7	2.9835	2.6825			3.4751	3.658	.5487
8	2.652	2.6825			3.3836	2.9264	.6535
9	2.3472	3.1493	2.8349		2.7435	2.3777	2.5606
10		3.0178	3.3836		3.2922	2.9264	3.2922
11	3.1855	3.3532	3.2922		3.2922	3.2007	3.2922
12	2.8502	2.9835	3.2922	2.5606	3.2922	3.1093	3.2007
13	2.8178	2.3205	3.2922	3.2922	3.1093	2.9264	3.2007
14	2.8178	2.5692	2.9264	3.2922	2.9264	2.5606	2.9264
15	3.1493	2.3472	2.8349	3.2922	3.1093	2.7435	2.9264
16	2.9007	2.5149	2.652	3.1093	3.1093	2.8349	3.1093
17	.2801	.2801		.3734	.3734	.5544	.5601
18		.3734	.2801	.3734	.3734	.6535	.5601
19	.2801	.4668	.6535	.3734	.3734	.7468	.7468
20	.3734	.5601	.7468	.4668	.4668	.7468	.7468
21	.3734	.5601	.7468	.4668	.4668	.7468	.7468
22	.3734	.5601	.7468	.4668	.3734	.7468	.7468
23	1.6766	2.4034	2.5606	2.1948	2.0119	2.5606	2.9264
24	2.2377	2.3472	2.7435	2.7435	2.9264	2.9264	2.9264
Max	3.1855	3.3532	3.3836	3.2922	3.658	3.8043	3.658
Min	.2801	.2801	.2801	.3734	.3734	.5544	.5487
Avg	2.0796	2.0721	2.3982	2.1542	2.4141	2.4138	2.2636

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274056 / 33/11 SONAKE

Feeder No / Name : 205 / Gaothan No.1 Takali-  
Gadegaon Feeder KV- 11 /  
OUTGOING

GAOTHAN FEEDER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1867	.1867	.1867	.1867	.0934
2	.1905	.1905	.1867	.1867	.1867	.1867	.0934
3	.1905	.1905	.1867	.1867	.1867	.1867	.0934
4	.1905	.1905	.2801	.1867	.1867	.1867	.0934
5	.1905	.1905	.2801	.1867	.2801	.2801	.0934
6	.2858	.2858	.3734	.2801	.2801	.2801	.1867
7	1.0059	.1905	.1867		.2801	.2801	.1867
8	.8478	.1905	.1867		.1867	.1867	.1867
9	.6783	.1905	.1867		.1867	.1867	.0934
10	.5935	.1905	.1867		.1867	.1867	.0934
11	.6535	.1905	.1867		.1867	.1867	.0934
12	.6535	.2858	.1867	.1867	.2801	.1867	.0914
13	.6535	.1905	.1867	.1867	.1867	.1867	.0943
14	.7468	.1905	.1867	.2801	.1867	.1867	.0934
15	.6535	.2858	.1867	.2801	.1867	.1867	.0934
16	.6535	.2801	.1867	.1867	.1867	.0934	.0934
17	.2801	.2801	.1867	.1867	.1867	.0934	.1494
18	.1867	.2801	.1867	.2801	.1867	.0934	.0934
19	.2801	.2801	.1867	.3734	.2801	.1867	.1886
20	.2801	.3734	.3353	.3734	.2801	.2801	.2801
21	.2801	.3734	.4668	.3734	.2801	.1867	.1867
22	.2801	.2801	.4668	.1867	.1867	.1867	.1867
23	.1867	.1867	.2801	.1867	.1867	.0934	.0934
24	.1905	.1905	.1867	.1867	.1867	.1867	.0934
Max	1.0059	.3734	.4668	.3734	.2801	.2801	.2801
Min	.1867	.1867	.1867	.1867	.1867	.0934	.0914
Avg	.4309	.2362	.2357	.2358	.2139	.1867	.1269

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274056 / 33/11 SONAKE

Feeder No / Name : 206 / 11KV Navale College  
Express Feeder KV- 11 /  
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0934	.0934	.0934	.0934	.0934
2	.0953	.0953	.0934	.0934	.0934	.0934	.0934
3	.0953	.0953	.0934	.0934	.0934	.0934	.0934
4	.0953	.0953	.0934	.0934	.0934	.0934	.0934
5	.0953	.0953	.0934	.0934	.0934	.0934	.0934
6	.0953	.0953	.0934	.0934	.0934	.0934	.0934
7	.0953	.0953	.0934		.0934	.0934	.0934
8	.0953	.0953	.0934		.0934	.0934	.0934
9	.0953	.0953	.0934		.0934	.0934	.0934
10	.0953	.0953	.0934		.0934	.0934	.0934
11	.0953	.0953	.0934		.0934	.0934	.0934
12	.0953	.0953	.0934	.0934	.0934	.0934	.0934
13	.0953	.0953	.0934	.0934	.0934	.0934	.0934
14	.0953	.0953	.0934	.0934	.0934	.0934	.0934
15	.0953	.0953	.0934	.0934	.0934	.0934	.0934
16	.0953	.0953	.0934	.0934	.0934	.0934	.0838
17	.0953	.0953	.1494	.0934	.0934	.0934	.0934
18	.0953	.0953	.0934	.0934	.0934	.0934	.0934
19	.0953	.0953	.0934	.0934	.0934	.0934	.0934
20	.0953	.0953	.0934	.0934	.0934	.0934	.0934
21	.0953	.0953	.1494	.0934	.0934	.0934	.0934
22	.0953	.0953	.0934	.0934	.0934	.0934	.0934
23	.0953	.0953	.0934	.0934	.0934	.0934	.0934
24	.1715	.0953	.0934	.0934	.0934	.0934	.0934
Max	.1715	.0953	.1494	.0934	.0934	.0934	.0934
Min	.0953	.0953	.0934	.0934	.0934	.0934	.0838
Avg	.0985	.0953	.0981	.0934	.0934	.0934	.093

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274056 / 33/11 SONAKE

Feeder No / Name : 207 / Gaothan No.2 Sonke-Tisangi  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-AUG-17
HR	Load (MW)
24	.4287
Max	.4287
Min	.4287
Avg	.4287

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274114 / 33/11 KV ANAWALI

Feeder No / Name : 201 / 11 KV ANAWALI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.12	.12	.1372	.12	.12	.1372
2	.1372	.12	.12	.1372	.12	.12	.1372
3	.1372	.1372	.12	.1372	.1372	.1372	.1372
4	.1372	.1372	.12	.1715	.1372	.1372	.8573
5	.1372	.1715	.1372	.1715	.1715	.1543	.8573
6	.1715	.2058	.1543	.1715	.1715	.1715	1.0288
7	.1715	.1543	.1715	.1886	.2058	.1715	1.3717
8	.1543	.1543	.1715	.1715	.1715	.1543	1.5432
9	1.3717	1.3717	1.0288	1.2003	1.3717	1.5432	.1715
10	1.4575	1.3717	1.2003	1.286	1.286	1.5432	.1715
11	1.5432	1.286	1.286	1.2003	1.286	1.5432	.1372
12	1.5432	1.2003	1.2003	1.1145	1.2003	1.5432	.1372
13	1.3717	1.2003	1.2003	1.1145	1.2003	1.5432	.1372
14	1.3717	1.2003	1.2003	1.2003	1.3717	1.5432	.1372
15	1.5432	1.1145	1.1145	1.2003	1.3717	1.2003	.1372
16	1.3717	1.286	1.1145	1.286	1.3717	1.2003	.1372
17	.1372	.1372	.1372	.1372	.1372	.1372	.1543
18	.1715	.1372	.1543	.1372	.1543	.1543	.1543
19	.2401	.1372	.1715	.1715	.2058	.1543	.1715
20	.3086	.1372	.1715	.1543	.1715	.1715	.1886
21	.2401	.1372	.1543	.1372	.1543	.1715	.1715
22	.2058	.1372	.1372	.1372	.1543	.1715	.1372
23	.1715	.1372	.1372	.12	.1372	.1543	.6859
24	.3772	.1372	.1372	.1372	.12	.12	.1543
Max	1.5432	1.3717	1.286	1.286	1.3717	1.5432	1.5432
Min	.1372	.12	.12	.12	.12	.12	.1372
Avg	.6087	.5137	.4858	.5008	.5387	.5859	.3772

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274114 / 33/11 KV ANAWALI

Feeder No / Name : 202 / 11 KV TAWASHI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	1.7147	1.7147	1.3717	1.7147	1.7147	1.3717
2	1.7337	1.7147	1.7147	1.7147	1.7147	1.7147	1.7147
3	1.8004	1.8861	1.8861	1.7147	2.0576	1.7147	1.7147
4	1.8861	2.0576	2.0576	1.7147	2.0576	1.8004	.1543
5	1.8861	2.2291	2.2291	1.8861	2.0576	1.8861	.1715
6	2.4006	2.4006	2.4006	2.4006	2.4006	2.2291	.2058
7	2.7435	2.7435	2.8292	2.4006	2.4006	2.572	.2743
8	2.915	2.915	2.915	2.572	2.7435	2.7435	.1715
9	.1715	.1715	.1372	.1715	.1715	.1715	2.7435
10	.1715	.1715	.1372	.1715	.1715	.1886	2.7435
11	.1715	.1543	.1715	.1715	.1715	.12	2.7435
12	.1372	.1543	.1543	.1543	.1372	.12	2.7435
13	.12	.1543	.1543	.1543	.1543	.12	2.572
14	.12	.1543	.1543	.1543	.1543	.12	2.4006
15	.12	.1543	.1543	.1543	.1543	.1543	2.4006
16	.1372	.1543	.1543	.1543	.1543	.1543	2.3148
17	.1372	.1715	.1715	.2058	.1543	.1543	.1543
18	.1543	.2058	.2058	.2229	.1543	.1543	.1715
19	.2058	.2401	.2401	.2229	.1886	.1715	.2058
20	.2058	.2743	.2058	.2058	.1886	.1715	.2401
21		.2401	.1886	.1715	.2058	.2058	.2401
22	.1543	.2058	.1715	.1715	.1886	.1715	.2058
23	1.5432	1.0288	1.0288	1.3717	1.2003	1.3717	.1543
24	1.6289	1.7147	1.3717	1.3717	1.3717	1.3717	1.3717
Max	2.915	2.915	2.915	2.572	2.7435	2.7435	2.7435
Min	.12	.1543	.1372	.1543	.1372	.12	.1543
Avg	.9678	.9588	.9395	.8752	.9195	.8873	1.2160



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274114 / 33/11 KV ANAWALI

Feeder No / Name : 203 / 11 KV ANAWALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.8573	.8573	.8573	.8573	.8573	.8573
2	.0686	.7716	.8573	.8573	.8573	.8573	.8573
3	.6859	.8573	.8573	.9431	.8573	.8573	.6859
4	.8573	.9431	.9431	1.0288	1.0288	.9431	.8573
5	.8573	1.0288	.9431	1.1145	1.0288	.9431	.8573
6	1.0288	1.2003	1.0288	1.1145	1.0288	1.0288	1.0288
7	1.0288	1.0288	1.0288	.8573	.8573	1.0288	1.0288
8	1.0288	.9431	1.0288	.8573	.8573	.9431	.8573
9	.8573	.8573	.8573	.7716	.7716	.9431	.8573
10	.7716	.6859	.8573	.6859	.7716	.7716	.8573
11	.6859	.6859	.8573	.5144	.7716	.7716	.7716
12	.6859	.6859	.7716	.6001	.6859	.7716	.6859
13	.703	.6859	.6859	.6859	.6859	.6859	.6859
14	.6859	.6001	.6859	.6859	.6859	.6859	.5144
15	.6859	.6001	.6859	.6859	.6859		.5144
16	.7716	.5144	.6001	.6859	.6859	.6859	.6001
17	.7716	.6859	.5144	.6859	.7716	.4287	.6859
18	.8573		.5144	.8573	.8573	.4287	.7716
19	1.2003	1.1145	.9431	.9431	.9431	.6859	.8573
20	1.1145	1.0288	1.0288	1.0288	1.0288	.8573	1.0288
21	1.0288	.9431	.8573	.9431	.9431	1.0288	1.0288
22		.8573	.8573	.8573	.8573	.9431	.8573
23	.8573	.8573	.8573	.8573	.8573	.8573	.8573
24	.8573	.8573	.8573	.8573	.8573	.8573	.8573
Max	1.2003	1.2003	1.0288	1.1145	1.0288	1.0288	1.0288
Min	.0686	.5144	.5144	.5144	.6859	.4287	.5144
Avg	.8163	.8387	.8323	.8323	.8430	.8201	.8109

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274114 / 33/11 KV ANAWALI

Feeder No / Name : 204 / Shirgaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.2058	.2058	.2058	.2401	.2058
2	.1715	.2058	.1715	.2401	.2401	.2401	.2058
3	.1715	.2058	.1715	.3086	.2743	.2401	.2229
4	.2401	.2401	.2743	.3429	.2743	.2743	.5144
5	.2743	.2743	.3429	.3429	.3086	.2743	.5144
6	.2743	.3429	.3772	.3429	.3429	.3086	.5144
7	.3086	.3086	.3772	.3772	.3772	.3429	.6859
8	.2743	.2058	.3086	.3772	.3086	.2743	.6859
9	.6859	.6859	.4287	.6859	.6859	.8573	.2229
10	.6001	.6859	.5144	.5144	.6001	.8573	.2229
11	.6001	.6001	.5144	.4287	.5144	.6859	.2058
12	.5144	.5144	.4287	.4287	.5144	.5144	.1886
13	.4287	.5144	.4287	.4287	.5144	.5144	.2058
14	.4287	.5144	.4287	.4287	.4287	.5144	.2058
15	.4287	.5144	.4287	.4287	.4287	.3429	.2058
16	.4287	.5144	.4287	.4287		.3429	.2058
17	.0857	.3086	.2743	.2572	.1715	.2058	.2401
18	.1029	.3086	.3086	.3429	.2743	.2401	.2743
19	.1372	.3086	.3086	.3944	.3429	.2743	.3086
20	.1715	.3429	.2743	.3772	.2401	.3086	.3086
21	.2058	.3086	.2743	.3429	.3429	.3429	.3429
22	.1715	.2743	.2401	.3086	.3429	.3086	.3086
23	.1715	.2743	.2401	.2743	.3086	.2401	.5144
24	.2058	.1715	.2401	.2058	.2401	.2743	.2401
Max	.6859	.6859	.5144	.6859	.6859	.8573	.6859
Min	.0857	.1715	.1715	.2058	.1715	.2058	.1886
Avg	.3022	.3665	.3329	.3672	.3601	.3758	.3229

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274114 / 33/11 KV ANAWALI

Feeder No / Name : 205 / VITHURAYA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	1.7147	1.3717	1.3717	1.3717	1.2003	1.0288
2	1.7147	1.7147	1.3717	1.3717	1.3717	1.2003	1.0288
3	1.7147	1.7147	1.5432	1.3717	1.7147	1.286	1.0288
4	1.7147	1.749	1.5432	1.3717	1.7147	1.286	.1029
5	1.8861	1.7833	1.7147	1.5432	1.8861	1.3717	.1029
6	1.8861	1.8176	1.7147	1.5432	2.0576	1.5089	.1029
7	1.8861	1.8861	1.8004	1.8861	2.0576	1.7147	.1543
8	2.0576	2.0576	1.8861	2.0576	2.1434	1.9719	.1372
9	.1029	.1029	.0857	.1029	.1029	.1372	1.7147
10	.1029	.1029	.0857	.1029	.1029	.1372	1.7147
11	.0857	.1029	.1029	.1029	.1029	.0857	1.7147
12	.0857	.1029	.1029	.1029	.1029	.0857	1.6289
13	.0857	.1029	.1029	.1029	.1029	.12	1.5432
14	.0857	.1029	.1029	.1029	.1029	.12	1.4575
15	.0857	.1029	.1029	.1029	.1029		1.5432
16	.1029	.1029	.1029	.1543	.1029	.12	1.6289
17	.12	.2058	.12	.1372	.12	.1372	.1029
18	.1372	.2572	.12	.1372	.1372	.1372	.1372
19	.1715	.2743	.1715	.1543	.1543	.1715	.1715
20	.2058	.2058	.1715	.1715	.1715	.2058	.1543
21	.2401	.1715	.1715	.1715	.1715	.2058	.1543
22	.2058	.1715	.1715	.1543	.1715	.2058	.1372
23	1.3717	.8573	1.0288	1.0288	1.0288	1.0288	.1372
24	1.3717	1.5432	1.2003	1.0288	1.3717	1.2003	1.0288
Max	2.0576	2.0576	1.8861	2.0576	2.1434	1.9719	1.7147
Min	.0857	.1029	.0857	.1029	.1029	.0857	.1029
Avg	.7973	.7895	.7037	.6823	.7695	.6799	.7773

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274114 / 33/11 KV ANAWALI

Feeder No / Name : 206 / SIDDHANATH  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1543	.12	.1543	.1543	.1543	.1715
2	.2058	.1543	.1029	.1543	.1372	.1715	.1715
3	.2058	.1715	.1372	.1372	.1715	.1715	.1715
4	.2401	.1715	.1715	.1715	.1715	.2058	.6859
5	.2743	.2401	.2058	.1543	.2058	.2401	.8573
6	.2401	.2743	.2058	.2058	.2058	.2743	1.0288
7	.2401	.2401	.2229	.2401	.1715	.2401	1.2003
8	.2058	.1715	.1715	.2229	.1715	.2058	1.2003
9	1.1145	1.2003	.6859	.9431	1.0288	1.5432	1.2003
10	1.3717	1.3717	.8573	1.0288	1.1145	1.5432	.1886
11	1.5432	1.2003	1.0288	.9431	1.1145	1.5432	.1886
12	1.5432	1.2003	.9431	.8573	1.2003	1.5432	.2229
13	1.3717	1.2003	.9431	1.0288	1.1145	1.5432	.2229
14	1.3717	1.2003	.8573	1.1145	1.286	1.3717	.2229
15	1.3717	1.2003	1.0288	1.1145	1.3717	1.0288	.2229
16	1.2003	1.2003	1.0288	1.2003	1.5432	.6859	.2229
17	.1372	.2401	.1715	.1715	.1543	.1372	.2229
18	.1543	.2058	.2058	.2058	.2229	.1543	.2743
19	.2401	.2058	.2743	.2058	.3086	.1715	.2743
20	.2572	.1886	.2743	.2058	.3086	.2401	.3258
21	.2743	.1715	.1886	.2058	.2743	.3086	.3086
22	.1715	.1715	.1715	.1715	.2743	.2743	.2401
23	.1715	.1715	.1715	.1715	.2058	.2401	.5144
24	.1715	.1715	.1543	.1715	.1543	.1715	.2229
Max	1.5432	1.3717	1.0288	1.2003	1.5432	1.5432	1.2003
Min	.1372	.1543	.1029	.1372	.1372	.1372	.1715
Avg	.5937	.5366	.4301	.4658	.5444	.5901	.4401

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274114 / 33/11 KV ANAWALI

Feeder No / Name : 207 / MAN

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1372	.1715	.1715	.1543	.1543	.2058
2	.1372	.1372	.2058	.1715	.1372	.1372	.1715
3	.1715	.1715	.2058	.1715	.1372	.1372	.1715
4	.1715	.2229	.2058	.1886	.1715	.1543	1.0288
5	.2058	.2572	.2401	.2058	.2401	.1715	1.3717
6	.2401	.2915	.2401	.3086	.2401	.2058	1.3717
7	.2401	.2401	.2743	.3086	.2058	.2058	1.5432
8	.2401	.2058	.2401	.2743	.1715	.1715	1.8004
9	1.3717	1.5432	1.0288	1.5432	1.5432	1.8861	.1543
10	1.5432	1.7147	1.3717	1.6289	1.5432	.3429	.1543
11	1.7147	1.7147	1.6289	1.3717	1.6289	1.5432	.1372
12	1.5432	1.5432	1.3717	1.2003	1.7147	1.6289	.1715
13	1.3717	1.5432	1.286	1.2003	1.5432	1.5432	.1715
14	1.3717	1.3717	1.2003	1.2003	1.5432	1.5432	.1715
15	1.5432	1.3717	1.2003	1.286	1.5432		.1715
16	1.5432	1.5432	1.3717	1.3717			.1372
17	.12	.2743	.1715	.2401	.1715		.1543
18	.1543	.2743	.2229	.2743	.2401	.1543	.1715
19	.2058	.2743	.2572	.3086		.2401	.2058
20	.2401	.3086	.2572	.2743	.3086	.2743	.2401
21	.2572	.2743	.2229	.2743	.3086	.2401	.3086
22		.2401	.2058	.2401	.2743		.2401
23	.1715	.2058	.2058	.2058	.1886	.2401	.8573
24	.1543	.1715	.1715	.1715	.1715	.1715	.2058
Max	1.7147	1.7147	1.6289	1.6289	1.7147	1.8861	1.8004
Min	.12	.1372	.1715	.1715	.1372	.1372	.1372
Avg	.6456	.6680	.5816	.6080	.6446	.5573	.4715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274131 / 33/11KV WAKHARI

Feeder No / Name : 201 / WAKHARI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.1715	.2058	.1989	.1372	.1715	.2058
2	.1463	.1715	.2058	.2058	.1715	.1715	.2058
3	.1829	.1715	.2058	.2058	.1715	.1715	.2058
4	.1829	.1715	.2058	.2058	.2058	.1715	.2058
5	.2218	.2058	.2058	.2058	.2058	.2058	.2058
6		.2401	.2058	.2058	.2058	.2058	.2401
7		1.3413	1.6156	1.7147	1.6156	1.7071	2.0233
8		1.4022	1.5851	1.6766	1.6156	1.9662	2.0919
9		1.3717	1.3413	1.6766	1.6766	1.6194	1.829
10		1.3717	1.4937	1.7833		1.9433	1.768
11		1.3413	1.5546	1.6804		1.9433	1.7375
12		1.4327	1.6156	1.6804		1.9109	1.768
13		1.4022	1.5851	1.6156		2.0405	1.7375
14		1.4022	1.5851	1.757	1.768	2.0081	1.7375
15	1.6766						
16	1.6766						
17	1.6766						
18	1.7071						
19	1.5242	.2058	.1715	.1715		.1715	.1372
20	1.4327	.1829	.2058	.2058	.2058	.1715	
21	1.3717	.1829	.2401	.3429	.2058	.2058	.3086
22	1.2803	.1829	.2058	.3429	.2058	.2401	
23	.1829	.1829	.2058	.1715	.1715	.2058	.3315
24		.2058	.2058	.2058	.1372	.1715	.2058
Max	1.7071	1.4327	1.6156	1.7833	1.768	2.0405	2.0919
Min	.1463	.1715	.1715	.1715	.1372	.1715	.1372
Avg	.9578	.6670	.7423	.8126	.5800	.8701	.9414

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274131 / 33/11KV WAKHARI

Feeder No / Name : 202 / KHED BHALWANI  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0343	.1029	.0332	.0343	.0857	.0171
2		.0343	.1029	.0332	.0343	.0857	.0171
3		.0343	.1029	.0332	.0343	.0857	.0171
4		.0343	.1029	.0332	.0343	.0857	.0171
5		.0343	.1029	.0332	.0343	.0857	.0171
6		.0343	.1029	.0332	.0343	.0857	.0171
7		2.4996	2.7435	3.1161	2.1338	3.5361	.1029
8		2.7435	2.7435	3.2819	2.2558	3.5665	.1372
9		2.9264	2.4387	3.6466	3.1398	3.8218	
10		3.0788	3.3608	3.4808		3.5803	
11		2.9264	3.1093	1.6244		3.6134	3.5056
12		2.5606	3.0445	2.9172			3.719
13		2.652	2.9797	3.0498			3.5056
14		2.652	2.8826	2.9835	2.9264		3.3532
15	3.0178						
17	3.2312						
18	3.2617						
19	3.0483		.0343	.0343	.0857		.0686
20	2.8654	.1029	.0343	.0343	.0857		
21	2.9264	.1029	.0343	.0343	.1372		.0686
22	2.9874	.1029	.0343	.0343	.1372		.0686
23	.0343	.1029	.0343	.0343	.1372		.0663
24	.4287	.0343	.1029	.0343	.0343	.1372	
Max	3.2617	3.0788	3.3608	3.6466	3.1398	3.8218	3.719
Min	.0343	.0343	.0343	.0332	.0343	.0857	.0171
Avg	2.4224	1.1943	1.2097	1.2253	.7049	1.5641	.9186

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274131 / 33/11KV WAKHARI

Feeder No / Name : 203 / KOUTHALI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	.0343	.0343	.0343	.0343
2	.0343	.0343	.0343	.0343	.0343	.0343	.0343
3	.0343	.2058	.0343	.0343	.0343	.0343	.0343
4	.0343	.2058	.0343	.0343	.0343	.0343	.0343
5	.0343	.0343	.0343	.0343	.0343	.0343	.0343
6		.0343	.0343	.0343	.0343	.0343	.0343
11	2.6825						
12	2.7435						
13	2.5606						
14	2.8045						
15		3.4751	3.3684	3.4145	2.9264	3.6466	3.5665
16		3.4751	3.1703	3.5803	3.0483	3.6466	3.1703
17		3.1703	3.1093	3.1703	3.1703	3.3532	3.0483
18		3.0483	3.1093	3.1703	2.8654	3.3532	2.9264
19	.0514	3.0483	2.8654	3.1703	2.9264	3.1703	3.1093
20	.0686	2.7435	2.7435	2.8045	2.8959	3.1093	
21	.0686	2.6673	2.6825	2.8045	2.8349	2.6825	2.6216
22	.0686	2.6216	2.5606	2.8045	2.7435	2.6825	2.6216
23	.0686	.0343	.0343	.0686	.0343	.0514	.0332
24	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Max	2.8045	3.4751	3.3684	3.5803	3.1703	3.6466	3.5665
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0332
Avg	.7548	1.5542	1.4927	1.5767	1.4803	1.6210	1.4225



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274131 / 33/11KV WAKHARI

Feeder No / Name : 204 / SHIRDHONE  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11	3.2922						
12	3.2922						
13	3.6351						
14	3.1703						
15		3.0483	3.5665	3.0483	3.1703	3.4476	2.8045
16		3.0483	3.1703	3.2312	2.8654	3.3813	3.4294
17		3.0483	3.1093	3.3532	3.3532	3.2312	3.4294
18		3.0483	3.1093	2.9874	2.9874	3.2922	3.4979
19		3.1703	3.1093	2.8045	3.1703	3.2922	3.4294
20		3.1398	3.0483	2.6825	3.1703	3.2922	
21		3.0788	2.9874	2.6825	3.1398	2.9264	3.155
22			2.8045	2.6825	3.1093	3.0483	2.8045
24	.3772						
Max	3.6351	3.1703	3.5665	3.3532	3.3532	3.4476	3.4979
Min	.3772	3.0483	2.8045	2.6825	2.8654	2.9264	2.8045
Avg	2.7534	3.0832	3.1131	2.9340	3.1208	3.2389	3.2214

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274131 / 33/11KV WAKHARI

Feeder No / Name : 205 / WAKHARI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.3239	.3086	.2572	.3086	.3086
2	.3772	.3258	.3563	.3258	.2572	.3086	.3258
3	.3944	.3429	.3563	.3429	.2572	.3429	.3429
4	.3944	.4115	.3887	.3772	.2572	.4115	.3944
5	.3944	.4287	.4049	.4287	.2743	.4458	.4287
6			.3887				
9		.2572	.2429	.2743	.2229	.2743	.2401
10		.1886	.1781	.2058		.1715	.2058
11	.1543	.1372	.1457	.12		.1886	.2058
15	.1715	.1543	.0972	.1097	.1543	.1372	.1829
16	.1715	.12	.1372	.1097	.3086	.1543	.1829
17	.2058	.1715	.1715	.1372	.2058	.1715	.1829
18	.2572	.2229	.2058	.2229	.1886	.2058	.1677
19	.3429	.2743	.2401	.2229	.2572		.2134
20	.4115	.3086	.3429	.2401	.2572	.3944	
21	.4115	.3429	.3429	.3086	.2743	.2915	.2896
22	.3944	.3429	.3086	.3086	.3086	.3258	.2896
23	.3772	.3429	.3086	.2401	.3086	.3086	
24	.3086	.3429	.3429	.3086	.2401	.3086	.3086
Max	.4115	.4287	.4049	.4287	.3086	.4458	.4287
Min	.1543	.12	.0972	.1097	.1543	.1372	.1677
Avg	.3194	.281	.2781	.2551	.2518	.2794	.2669

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274131 / 33/11KV WAKHARI

Feeder No / Name : 206 / 11 KV Mauli Gavthan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.4024	.4572	.3887	.2591	.4755	.3772
2	.3734	.4024	.4572	.3563		.439	.3944
3	.3361	.3658	.4572	.3563	.2591	.439	.3944
4	.3361	.4024	.439	.3725	.2591	.439	.4115
5	.3361	.439	.439	.3887	.2591	.4115	.4115
6		.5121	.439		.3725	.439	.3944
7		.5487	.4572	.421	.3725	.5121	.463
8		.4207	.2743	.4534	.3239	.4572	.4287
9		.3841	.2743	.4115	.3563	.3185	.3772
10		.4755	.1991			.4527	.4115
11	.5415	.4755	.4344	.3563		.4024	.3944
12	.4668	.4207	.4163	.3887		.4359	.4287
13	.3921	.3658	.3801	.3725		.4024	.3429
14	.3547	.3109	.3439	.3887	.5121	.4024	.3086
15	.3734	.2378	.3647	.3239	.4755	.4024	.3048
16	.4108	.2378	.3944	.3239	.3658	.3481	.3353
17	.4481	.2743	.3772	.3292	.4572	.3429	.2743
18	.4854	.3658	.4115	.3658	.3292	.2743	
19	.4854	.3841	.4115	.3658	.4024	.3601	.2896
20	.4854	.439	.463	.3658	.3772	.4115	
21	.5041	.4572	.463	.4024	.439	.4287	.3201
22	.5041	.4572	.4458	.439	.4458	.3944	
23	.4572	.4572	.4115	.3658	.4458	.3772	.3658
24	.3658	.439	.4572		.2915	.4755	.3772
Max	.5415	.5487	.463	.4534	.5121	.5121	.463
Min	.3361	.2378	.1991	.3239	.2591	.2743	.2743
Avg	.4226	.4031	.4028	.3779	.3686	.4101	.3717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274138 / 33/11 KV KASEGAON

Feeder No / Name : 201 / 11 KV SIDDHESHWAR  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.5335	.4458	.5144		.4287	.9431
2	.4458	.5335	.4287	.4954		.4458	1.0229
3							1.0229
4							1.6991
5							1.9938
6							2.2192
7							2.4619
8							2.6006
9	2.4792	2.5659	2.2539	2.2712		2.4863	
10	2.8607	2.6526	2.4272	2.0631		2.6235	
11	2.6526	2.3926	2.3579	2.1152		2.4177	
12	2.5659	2.2712	2.1498	2.1152		2.4177	
13	2.3926	1.6644	2.0978	2.1325		2.2291	
14	2.2539	2.1152	2.0631	2.0458		2.2291	
15	2.2712	2.2365	2.2192	2.2018			
16	2.2539	2.3579	2.1325	2.2365		1.6804	
17	.3048	.2229	.1886	.2058	.2229	.2058	.381
18	.3429	.3258	.2743	.2743	.3944	.3772	.4191
19	.4191	.4458	.4115	.3772	.4115	.3944	.4191
20	.5144	.5144	.4801	.463	.5316	.4287	.4191
21	.4954	.463	.4458	.4115	.463	.4115	.4191
22	.4763	.4287	.4458	.4287	.4287	.4115	.4001
23	.4954	.4287	.4458	.4458	.4287	.3772	1.2517
24	.4287	.5335	.4458	.5144		.4287	.3944
Max	2.8607	2.6526	2.4272	2.2712	.5316	2.6235	2.6006
Min	.3048	.2229	.1886	.2058	.2229	.2058	.381
Avg	1.3379	1.2603	1.2063	1.1840	.4115	1.1761	1.1292

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274138 / 33/11 KV KASEGAON

Feeder No / Name : 202 / 11 KV SATWAI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.3239	.2743	.2667		.2743	.6516
2	.2915	.3239	.2743	.2477		.2743	.6516
3							.6516
4							1.1789
5							1.3696
6							1.491
7							1.6124
8							1.6817
9	2.0978	1.8204	1.6817	1.6297		1.6804	
10	2.5139	2.0111	1.8898	1.8031		1.9719	
11	2.3926	2.2365	1.7164	1.8551		2.1605	
12	2.0805	2.2885	1.6817	1.7857		2.1262	
13	2.1152	2.2192	1.6297	1.7164		2.1262	
14	2.0111	2.3752	1.6991	1.6991		2.1262	
15	1.8204	2.2885	1.6124	1.595			
16	1.9938	2.2712	1.6124	1.7164		1.5261	
17	.1715	.2401	.1715	.1886	.2572	.1543	.2096
18	.2286	.2572	.2572	.2058	.2915	.2572	.2286
19	.3048	.2915	.3086	.3258	.3601	.3429	.3239
20	.381	.3772	.3258	.4287	.4115	.3086	.3429
21	.381	.3429	.2915	.3944	.3429	.3429	.3429
22	.362	.2915	.2743	.2915	.3086	.3086	.2858
23	.3239		.2743	.2572	.2743	.2572	1.086
24	.2915	.3239	.2743	.2667		.2743	.2058
Max	2.5139	2.3752	1.8898	1.8551	.4115	2.1605	1.6817
Min	.1715	.2401	.1715	.1886	.2572	.1543	.2058
Avg	1.1140	1.1931	.9027	.9263	.3209	.9713	.7696

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274138 / 33/11 KV KASEGAON

Feeder No / Name : 203 / 11 KV DESHMUKH NAGAR  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.8176	1.7661	1.5775		1.8724	.3086
2	1.3717	1.8176	1.7661	1.6804		1.8724	.3086
3	1.406	1.8176	1.7661	1.749		1.8724	
4	1.406	1.869	1.749	1.7661		1.9938	
5	1.5775	1.989	1.989	2.0233		2.1845	
6	2.0233	2.5034	2.1091	2.5034		2.3059	
7	2.2634	2.6063	2.5549	2.5549		2.4446	
8	2.2634	2.8464	2.5549	2.5377		2.8086	
15	.2058	.2058	.1886	.1886			
16	.2058	.1886	.1886	.1886		.1715	
17	.2477	.2058	.2572	.2401	.2743	.12	.1905
18	.2858	.2229	.2572	.2915	.2915	.2915	.2286
19	.3239	.2572	.3258	.3601	.2915	.3086	.2286
20	.4001	.3258	.3772	.4287	.3258	.3086	.3429
21	.362	.2915	.3258	.3944	.2743	.2915	.362
22	.3239	.2915	.2915	.3429	.2572	.3086	.362
23	1.6975	1.6289	1.4043	2.5034	1.6804	1.2656	.381
24	1.3546	1.8004	1.8176	1.4232	1.8724	1.8724	1.2483
Max	2.2634	2.8464	2.5549	2.5549	1.8724	2.8086	1.2483
Min	.2058	.1886	.1886	.1886	.2572	.12	.1905
Avg	1.0606	1.2603	1.2049	1.2641	.6584	1.3113	.3961

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274138 / 33/11 KV KASEGAON

Feeder No / Name : 204 / 11 KV GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	05-AUG-17	06-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601		.2743		
2	.2915		.2743		
3	.3086		.2915		
4	.3086		.2915		
5	.3258		.3258		
6	.4801		.3601		
7	.463		.4287		
8	.4115		.3601		
9					.3601
10					.3429
11					.3429
12					.3944
13					.4115
14					.4115
16					.3429
17		.3601		.3086	
18		.2743		.4458	
19		.2915		.3944	
20		.3944		.3772	
21		.3601		.3429	
22		.3086		.3258	
23		.2915		.2915	
24	.3429		.2915		
Max	.4801	.3944	.4287	.4458	.4115
Min	.2915	.2743	.2743	.2915	.3429
Avg	.3658	.3258	.3220	.3552	.3723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274138 / 33/11 KV KASEGAON

Feeder No / Name : 205 / Nagin

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274138 / 33/11 KV KASEGAON

Feeder No / Name : 206 / Dongare Shala

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1831	1.2384	.9945	1.105		1.1443	.4458
2	1.1831	1.2384	.9774	1.1431		1.1269	.4458
3	1.2003	1.3146	.9945	1.1431		1.1443	
4	1.2346	1.3717	.9945	1.1431		1.1963	
5	1.406	1.4861	1.1831	1.6575		1.3696	
6	2.1605	2.5149	2.2462	2.0195		2.0111	
7	3.1893	2.934	2.7435	3.0483		2.4966	
8	3.1036	3.658	2.8464	3.1626		3.086	
15	.2229	.2229	.3944	.2743			
16	.2572	.2915	.3944	.3601		.3601	
17	.4191	.4115	.3429	.4287	.4973	.3944	.5144
18	.5335	.4973	.5658	.4801	.6001	.6001	.6097
19	.7621	.5658	.6859	.6001	.823	.7888	.724
20	.7621	.7202	.7716	.7716	.8573	.7202	.7811
21	.6287	.6516	.7373	.4973	.7373	.6001	.7621
22	.5335	.5144	.5144	.5316	.583	.5487	.7811
23	1.3146	1.0288	.9536	1.0056	1.1616	.703	.5906
24	1.166	1.2574	.9774	1.086		1.1789	.6687
<b>Max</b>	<b>3.1893</b>	<b>3.658</b>	<b>2.8464</b>	<b>3.1626</b>	<b>1.1616</b>	<b>3.086</b>	<b>.7811</b>
<b>Min</b>	<b>.2229</b>	<b>.2229</b>	<b>.3429</b>	<b>.2743</b>	<b>.4973</b>	<b>.3601</b>	<b>.4458</b>
<b>Avg</b>	<b>1.1811</b>	<b>1.2176</b>	<b>1.0732</b>	<b>1.1365</b>	<b>.7514</b>	<b>1.1453</b>	<b>.6323</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274142 / 33/11 KV SARKOLI

Feeder No / Name : 201 / 11 KV SARKOLI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.703	1.9204	1.7147	1.6632	2.0576	1.7661
2	.6859	.6859	1.8861	1.7833	1.6632	2.0919	1.8519
3			1.8861	1.8004	1.6632	2.0919	1.8861
4			1.8861	1.8347	1.6632	2.1262	1.8861
5			1.8004	1.8861	1.6804	2.1262	1.9376
6			1.8347	1.9204	1.7147	2.1605	1.9719
7			2.1776	2.2291	1.989	2.2291	2.3663
8			2.3491	2.3148	2.1262	.2743	2.332
9	2.4006	2.6749					
10	2.452	2.8464					
11	2.692	2.7778					
12	2.7092	2.7092					
13	2.5377	2.7435					
14	2.6578	2.6578					
15	2.7092	2.6235	.4115	.3601	.4287	.6173	.6859
16	2.692	2.5377	.4115	.4801	.5316	.7545	.7202
17	.3772	.3772	.4458	.583	.5316	.7888	.7202
18	.6344	.4973	.4801	.583	.5144	.7888	.7545
19	.7202	.463	.4973	.4801	.5144	.7888	.6001
20	.7888	.4115	.5144	.4458	.6173	.8402	.6344
21	.6859	.3772	.4801	.4287	.5487	.8573	.5144
22	.6859	.2915	.4287	.3944	.5144	.5658	.4801
23	.6859	1.9376	1.7147	1.6461	2.0405	1.7661	2.0405
24	.6859	.6859	1.9376	1.7147	1.6461	2.0576	1.7661
Max	2.7092	2.8464	2.3491	2.3148	2.1262	2.2291	2.3663
Min	.3772	.2915	.4115	.3601	.4287	.2743	.4801
Avg	1.5270	1.5556	1.2812	1.2555	1.2250	1.3879	1.3841

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274142 / 33/11 KV SARKOLI

Feeder No / Name : 202 / 11 KV OZEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3032	1.2689	.1543	.1543	.1715	.1715	.1886
2	1.3032	1.2517	.1543	.1543	.1715	.1715	.1886
3	1.3717	1.2517					
4	1.6289	1.3375					
5	1.6632	1.5261					
6	1.8004	1.7318					
7	1.8347						
8	1.869	1.7833					
9			1.7318	1.3717	1.6975	1.8004	1.4918
10			1.7147	1.5432	2.0062	2.0919	1.6804
11			1.7147	1.5089	1.9376	2.0233	1.6804
12			1.7147	1.6975	1.9547	1.9547	1.7318
13			1.6289	1.7147	1.7833	2.0062	1.7147
14			1.3717	1.749	1.8176	1.8519	1.6804
15	.12	.1029	1.3717	1.5775	1.6804	1.7661	1.6289
16	.12		1.3375		1.8347	1.5947	1.6289
17	.1543	.1372	.1543		.12	.2058	.1715
18	.1372	.1543	.1715	.2058	.12	.2229	.1715
19	.1543	.1543	.2058	.1886	.1715	.2401	.1543
20	.1543		.2229	.2229	.2229	.2401	.1543
21	.12	.1886	.2058	.2401	.2058	.1886	.1886
22	.12	.2058	.1715	.2401	.2058	.2401	.1886
23	1.0288	.1543	.1543	.1715	.1886	.1886	.1886
24	.3772	1.3032	.1543	.1543	.1715	.1886	.1715
Max	1.869	1.7833	1.7318	1.749	2.0062	2.0919	1.7318
Min	.12	.1029	.1543	.1543	.12	.1715	.1543
Avg	.8478	.8368	.7964	.8059	.9145	.9526	.8335

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274142 / 33/11 KV SARKOLI

Feeder No / Name : 203 / 11 KV KHATAKALI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.7545	.463	.3429	.1715	.3944	.5144
2	1.0288	.7545	.463	.3429	.1715	.3944	.5144
3	1.046	.7545					
4	1.0802	.7716					
5	1.1145	.823					
6	1.1488	.9431					
7	1.1145	1.0802					
8	1.0974	1.0117					
9			1.1317	1.0288	1.3032	1.2689	1.5604
10			1.2174	1.0288	1.749	1.6289	1.869
11			1.2346		1.7833	1.5775	1.9376
12			1.2517		1.5775	1.6289	1.9033
13			1.0288		1.6289	.6344	1.8861
14			.823		1.6804	1.8176	1.9204
15	.6344	.4287	.8573		1.6289	1.8347	1.7661
16	.6516	.6173	.9602		1.6289	1.6461	1.8004
17	.6516	.6173	.4115		.4801	.5316	.6859
18	.6687	.6516	.4115		.463	.6687	.7545
19	.5658	.6687	.4115		.463	.8059	.7202
20	.6687	.6687	.4115		.4801	.7373	.7202
21	.5144	.6516	.4115		.4801	.7373	.7202
22	.463	.5658	.3772		.4801	.7202	.7373
23	.6859	.4801	.3772		.3944	.9431	.703
24	.3772	.7716	.4801	.3429	.1715	.3944	.5487
Max	1.1488	1.0802	1.2517	1.0288	1.7833	1.8347	1.9376
Min	.3772	.4287	.3772	.3429	.1715	.3944	.5144
Avg	.8078	.7230	.7068	.6173	.9297	1.0202	1.1812

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274142 / 33/11 KV SARKOLI

Feeder No / Name : 204 / 11 KV AMBIKA NAGAR  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1372	1.0802	1.0288	1.0117	1.0974	1.0802
2	.1372	.1372	1.1145	1.2003	1.0288	1.0974	1.0974
3			1.1145	1.2003	1.0802	1.166	1.1317
4			1.166	1.3717	1.2003	1.2346	1.2003
5			1.286	1.5432	1.286	1.3717	.0154
6			1.4403	1.7147	1.4918	1.6804	1.4918
7			1.7661	1.7147	1.7147	1.749	1.6975
8			1.3717	1.5432	1.6461	1.8004	1.7318
9	2.0233	1.8861					
10	2.1605	2.0233					
11	2.0576	2.0576					
12	2.0919	1.9204					
13	1.8861	.2229					
14	1.869	1.8176					
15	1.7147	1.6804	.1543	.1029	.12	.1543	.1372
16	1.8004	1.6289	.1715	.1372	.1543	.1372	.1372
17	.1372	.12	.1715	.1372	.1715	.1372	.0686
18	.1715	.1715	.1715	.1715	.1715	.1715	.0686
19	.1886	.2058	.1715	.2058	.2058	.1715	.0857
20	.2058	.2058	.1715	.2229	.2229	.2058	.0857
21	.1715	.2058	.1715	.2229	.1715	.1886	.0686
22	.1715	.1886	.1715	.1886	.1715	.1715	.0686
23	.3772	1.0288	.1715	.9945	1.0974	1.0631	1.0631
24	.3772	.1543	1.0802	1.0288	1.0117	1.0974	1.046
Max	2.1605	2.0576	1.7661	1.7147	1.7147	1.8004	1.7318
Min	.1372	.12	.1543	.1029	.12	.1372	.0154
Avg	.9831	.8773	.7192	.8183	.7754	.8164	.6820

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274142 / 33/11 KV SARKOLI

Feeder No / Name : 205 / SHIVAJI NAGAR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.583	.1715	.1715	.1715	.1543	.1543
2	.7716	.5658	.1715	.1715	.1715	.1543	.1543
3	.7545	.5658					
4	.7545	.583					
5	.7716	.583					
6	.7545	.6001					
7	.9259	.7888					
8	1.0288	.8573					
9			.703	.8573	.9259	.9431	.9774
10			.8573	.8573	.9774	1.0802	1.0802
11			.8573	.6001	1.0288	.9088	1.0974
12			.8916	.6859	1.0631	.9259	1.1317
13			.823	.7716	1.0631	.8916	1.1317
14			.7545	.823	1.0631	.9602	1.1488
15	.1886	.3429	.8573	.7545	1.0288	1.1145	1.166
16	.2058	.3772	.8916	.6859	1.046	1.1831	1.1488
17	.1715	.3429	.12	.2743	.2572	.1372	.1372
18	.2058		.1372	.2572	.2572	.1543	.1372
19	.2058	.2572	.1715	.2229	.2229	.1715	.1715
20	.2229	.2572	.1715	.2229	.2401	.2229	.1715
21	.2058	.2401	.1715	.2058	.1715	.2058	.1543
22	.2058	.2058	.1715	.2058	.1715	.1715	.1543
23	.583	.2058	.1715	.2058	.1543	.1543	.1543
24	.7716	.6173	.1715	.1715	.1715	.1543	.1543
Max	1.0288	.8573	.8916	.8573	1.0631	1.1831	1.166
Min	.1715	.2058	.12	.1715	.1543	.1372	.1372
Avg	.5278	.4690	.4592	.4525	.5659	.5382	.5792

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274142 / 33/11 KV SARKOLI

Feeder No / Name : 206 / SARKOLI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2058	.2058	.1715	.1715	.2058	.2401
2	.2058	.2058	.2058	.1715	.1715	.2401	.2229
3	.2401	.1715	.2058	.2058	.1715	.2743	.2229
4	.2743	.2401	.2058	.2229	.2058	.2915	.2572
5	.3258	.2572	.2401	.2401	.2229	.3086	.3086
6	.3772	.3429	.2743	.2572	.2572	.3258	.3601
7	.2743	.3429	.3086	.3429	.3086	.2743	.3258
8						.2058	
9	.2229	.2401	.2058	.2058	.2058	.2058	.2401
10	.2058	.2229	.2058	.1715	.2058	.2058	.2229
11	.2058	.2229	.1715	.1543	.1715	.2058	.2229
12	.1886	.2058	.1372	.1543	.1715	.2058	.1715
13	.1715	.2058	.1372	.1372	.1715	.1715	.1715
14	.1715	.1715	.1372	.1372	.2058	.1715	.2058
15	.1886	.1715	.1543	.12	.2058	.2058	.2058
16	.2401	.1543	.1715	.1372	.2229	.2229	.2229
17	.2229	.1715	.1886	.1372	.2572	.2401	.2401
18	.2572	.1543	.2058	.1543	.3086	.2915	.2401
19	.2572	.2058	.2401	.1715	.3086	.3258	.3086
20	.2915	.2229	.2572	.2058	.2229	.3429	.3086
21	.2572		.2401	.2058	.2229	.3258	.2401
22	.2401		.2058	.2058	.2229	.2572	.2401
23	.2401	.2058	.1715	.1886	.2058	.2572	.2229
24	.3772	.2401	.2058	.1715	.1715	.2058	.2401
Max	.3772	.3429	.3086	.3429	.3086	.3429	.3601
Min	.1715	.1543	.1372	.12	.1715	.1715	.1715
Avg	.2453	.2172	.2035	.1856	.2170	.2486	.2453

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274161 / 33/11 KV PIRACHI KUROLI

Feeder No / Name : 201 / 11 KV DHONDEWADI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8097	1.1336	.181	.0905	.0905	.0905	.181
2	.8097	1.1336	.181	.0905	.0905	.0905	.181
3	.9717	1.1336					
4	.9717	1.1336					
5	1.1336	1.2955					
6	1.1336	1.4575					
7	1.2955	1.4575					
8	1.2955	1.4575					
9			1.4575	1.4575	1.2498	1.7814	1.6194
10			1.4575	1.4575	1.6194	1.7814	1.7814
11			1.4575	1.4575	1.6194	1.9433	1.7814
12			1.4575	1.2955	1.2955	1.9433	1.7814
13			1.4575	1.4575	1.4575	1.7814	1.7814
14			1.6194	1.6194	1.6194	1.6194	1.7814
15	.0905	.0905	1.4575	1.4575	1.6194	1.6194	1.6194
16	.0905	.0905	1.6194	1.2955	1.6194	1.6194	1.4575
17	.0905		.0905	.0905	.0905	.0905	.0905
18	.0905	.0905	.0905	.0905	.0905	.0905	.0905
19	.0905	.0905	.0905	.0905	.0905	.181	.0905
20	.0905	.181	.0905	.181	1.3756	.181	.0905
21	.0905	.181	.0905	.181	.0905	.181	.0905
22	.0905	.181	.0905	.181	.0905	.181	.181
23	.0905	.181	.0905	.181	.0905	.181	.181
24	.1715	.0905	.181	.0905	.0905	.0905	.181
Max	1.2955	1.4575	1.6194	1.6194	1.6194	1.9433	1.7814
Min	.0905	.0905	.0905	.0905	.0905	.0905	.0905
Avg	.5226	.6693	.7311	.7092	.7939	.8581	.8312



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274161 / 33/11 KV PIRACHI KUROLI

Feeder No / Name : 202 / 11 KV PIRACHI KUROLI SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.181	1.7814	1.6194	1.6194	2.2672	2.4291
2	.181	.181	1.7814	1.6194	1.6194	2.2672	2.4291
3	.181	.181	1.6194	1.6194	1.6194	2.2672	2.4291
4	.181	.181	1.6194	1.7814	1.7814	2.4291	2.4291
5	.181	.181	1.6194	1.7814		2.7149	2.5911
6	.181	.181	1.6194	1.9433	2.5911	2.8959	2.753
7	.181	.181	1.9433	2.1052	2.753	3.0769	2.915
8	.181	.181	1.9433	2.1052	2.753	3.0769	2.915
15	.181	.181	.181		.181	.362	.362
16	.181	.181	.181		.181	.362	.362
17	2.5911		.181		.362	.543	.362
18	2.5911	2.4291	.181	.181	.181	.543	.362
19	2.5911	2.4291	.181	.181	.362	.543	.362
20	2.5911	2.4291	.181	.362		.543	.362
21	2.4291	2.2672	.181	.362	.362	.543	.362
22	2.2672	2.1052	.181	.362	.362	.543	.362
23	2.1052	1.9433	.181	.362	.362	.543	.362
24	2.1052	2.1052	1.7814	.181	.362	.362	.362
Max	2.5911	2.4291	1.9433	2.1052	2.753	3.0769	2.915
Min	.181	.181	.181	.181	.181	.362	.362
Avg	1.1712	1.0305	.9632	1.1044	1.0907	1.4379	1.3617

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274161 / 33/11 KV PIRACHI KUROLI

Feeder No / Name : 203 / 11 KV CHANDRABHAGA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	03-AUG-17	04-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
13			.1296	
18			.1448	
24	.1715	.1448		.1448
Max	.1715	.1448	.1448	.1448
Min	.1715	.1448	.1296	.1448
Avg	.1715	.1448	.1372	.1448

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274161 / 33/11 KV PIRACHI KUROLI

Feeder No / Name : 204 / 11 KV GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4887	.4525	.5068	.4163	.4525	.5068	.4706
2	.5249	.4887	.5068	.4163	.4525	.5068	
3	.5611	.5249	.5068	.4163	.4344	.4887	.543
4	.5973	.6154	.543	.4887	.4706	.4887	.543
5	.6335	.6516	.6516	.6154	.5068	.5792	.6516
6	.6335	.6878	.7602	.6878	.5611	.6335	.7602
7	.6154	.724	.6516	.6697	.6878	.6335	.6516
8	.5611	.5973	.543	.5068	.6335	.6335	.5973
9	.4706	.543	.4344	.4525	.4525	.4525	.4163
10	.3258	.2896	.3258		.362	.4163	
11	.2534		.2172	.2353	.2353	.2896	.362
12	.2534	.2534	.2172	.2353	.2715	.2353	.3077
13	.2353	.2353	.2172	.2172	.2534	.2353	.2896
14	.2353	.2172	.2172	.2353	.2353	.2353	.2804
15	.2172	.2172	.1991	.2534	.2534	.2534	.3077
16	.2534	.2353	.2172	.2534	.2715	.3077	.3077
17	.3077		.362	.3077	.3258	.3258	.3439
18	.4163	.3982	.3982	.6335		.4163	.4163
19	.5068	.543	.5068	.6516	.6335	.543	.4706
20	.6516	.6878	.7059	.6335		.6516	.5068
21	.5973	.6154	.6335	.6335	.6154	.5973	.543
22	.543	.5068	.543	.6154	.543	.543	.543
23	.4706	.543	.4163	.5792	.5068	.5068	.5068
24	.4887	.4525	.543	.4163	.543	.5068	.4706
Max	.6516	.724	.7602	.6878	.6878	.6516	.7602
Min	.2172	.2172	.1991	.2172	.2353	.2353	.2804
Avg	.4517	.4764	.4510	.4596	.4410	.4578	.4677

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274161 / 33/11 KV PIRACHI KUROLI

Feeder No / Name : 205 / NEW DHONDEWADI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2172	.2896	.3258	.3077	.2715	.2715	.362
2	.2172	.2896	.3258	.3077	.2715	.3258	.362
3			.3258	.3077	.2715	.3258	.362
4			.3258	.3258	.3258	.3077	.362
5			.3439	.362	.362	.3258	.362
6			.362	.3982	.3801	.3258	.3982
7			.362	.4344	.4163	.5068	.3982
8			.362	.3801	.362	.3982	.3801
9	1.4251	1.6842					
10	1.4899	1.9433					
11	1.6842	1.9109					
12	1.6194	1.8785					
13	1.6518	1.7814					
14	1.6356	1.6842					
15	1.6032	1.7004	.2715	.1991	.2353	.2172	.1991
16	1.6356	1.7166	.2896	.1991	.2715	.2534	.2353
17	.2172		1.8138	2.0729	2.1376	2.1862	2.1862
18	.2172	.2172	2.1376	2.1052	2.3482	2.2672	2.2348
19	.3077	.2715	2.1376	2.2348	2.2672	2.1052	2.2672
20	.362	.3258	1.9271	2.1862		1.9757	2.0729
21	.3077	.3258	1.7976	1.9433	1.9919	1.9109	1.8623
22	.3077	.3258	1.749	1.9109	2.1357	1.8299	1.7166
23	.1715	.3258	1.7004	1.8623	1.9728	1.749	1.7004
24	.2353	.2896	.3439	1.6518	1.6356	1.7652	1.6518
Max	1.6842	1.9433	2.1376	2.2348	2.3482	2.2672	2.2672
Min	.1715	.2172	.2715	.1991	.2353	.2172	.1991
Avg	.8503	.9977	.9390	1.0661	1.0386	1.0582	1.0618

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274165 / 33/11KV PALASHI

Feeder No / Name : 201 / UJANI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3549	.3086	1.358	1.5123	1.6667	1.5432	1.4198
2	.3241	.3201	1.358	1.4352	1.6821	1.6204	1.4506
3			1.3426	1.3889	1.6512	1.5123	1.5123
4			1.3889	1.5432	1.6204	1.6204	1.5432
5			1.6667	1.7438	1.6667	1.6975	1.6049
6			1.7284	1.821	1.6512	1.8673	1.6204
7			1.9136	2.0062	1.6975	2.0988	1.7901
8			1.9136	1.929	1.9444	2.0062	1.9907
9	1.3889	1.5851					
10	1.6049	1.6204					
11	1.5432	1.6512					
12	1.4661	1.7284					
13	1.4661	1.6358					
14	1.4815	1.5741					
15	1.5586	1.6049	.3086	.1698	.216	.2778	.2623
16	1.6358	1.6821	.3395	.2623	.2688	.3086	.3086
17	.2408		.1543	.2709	.3163	.1543	.3395
18	.2559		.3086		.3479	.1852	.3549
19	.3121	.2778	.3086	.3201	.3479	.1852	.3241
20	.286	.3086	.3395	.2743	.3637	.216	.2932
21				.2743	.3163	.2623	.2932
22	.3311	.3395	.3086	.2559	.3163	.2932	.2778
23		1.3889	1.4661	1.5804	.1423	1.358	1.4661
24	.3395	.3241	1.3889	1.5123	1.6556	1.4661	1.3889
Max	1.6358	1.7284	1.9136	2.0062	1.9444	2.0988	1.9907
Min	.2408	.2778	.1543	.1698	.1423	.1543	.2623
Avg	.9118	1.0900	1.0349	1.0765	.9929	1.0374	1.0134

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274165 / 33/11KV PALASHI

Feeder No / Name : 202 / RAMESHWAR  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3612	.4268	.0903	.1204	.1505	.1204	.0903
2	.3161	.442	.0903	.1204	.1355	.1054	.0903
3	.3311	.4515					
4	.3763	.5268					
5	.6171	.5569					
6	.888	.7316					
7	.9332						
8	.9934	.7773					
9			.9181	.8278	.8278	.7074	.7074
10			1.0084	.9181	.8429	.7526	.7827
11			.9031	.9181	.8579	.7977	.7526
12			.8429	.9031	.7827	.7526	.7526
13			.7676	.8278	.7375	.6472	.7526
14			.7074	.7977	.7225	.6773	.7526
15	.0753	.0753	.6923	.7074	.7074	.6687	.6472
16	.1355	.1054	.6923	.7282	.6773	.6472	.7225
17	.1656	.0903	.1204	.0743	.0903	.0753	.0753
18	.1806	.1204	.1204	.0892	.1054	.0753	.1054
19	.2107	.1806	.1204	.1204	.1204	.0753	.1204
20	.1957	.2408	.1355	.1505	.1505	.0903	.1355
21	.1505	.2408	.1355	.1505	.1204	.0903	.1355
22	.1355	.1806	.1204	.1505	.1204	.1054	.1355
23	.3462	.1204	.1204	.1505	.1204	.1054	.1355
24	.3772	.4572	.1204	.1204	.1505	.1204	.0753
Max	.9934	.7773	1.0084	.9181	.8579	.7977	.7827
Min	.0753	.0753	.0903	.0743	.0903	.0753	.0753
Avg	.3772	.3367	.4281	.4375	.4122	.3675	.3872

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274165 / 33/11KV PALASHI

Feeder No / Name : 203 / 11Kv palashi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1702	1.7833	.2214	.253	.3795	.253	.2688
2	1.2809	1.8061	.2214	.2214	.212	.253	.2688
3	1.4074	1.8362			.3163		
4	1.5971	1.8212					
5	1.8976	1.9052					
6	2.0873	2.1072					
7	2.1664						
8	2.2297	2.2125					
9			2.372	2.5617		2.451	2.1451
10			2.6408	2.7515	2.6092	2.5301	2.6882
11			2.6566	2.7199	2.5775	2.6092	2.7199
12			2.6882	2.7041	2.6566	2.6566	2.2138
13			2.5934	2.6408	2.6566	2.6408	1.8501
14			2.4827	2.6092	2.6408	2.5301	2.2138
15	.253	.2214	2.4827	2.5143	2.625	2.5301	2.4827
16	.253	.3163	2.4669	2.4387	2.6724	2.3878	2.4036
17	.2439		.2372	.2408	.1898	.3163	.1898
18	.3353		.2688	.2896	.3163	.3479	.3479
19	.3395	.3163	.2846	.3048	.3163	.3163	.3479
20	.0293	.3479	.3163	.2743	.3479	.3321	.3637
21	.3658	.3953	.2846	.3311	.3795	.3479	.3637
22	.2286	.3795	.2846	.3612	.3795	.3321	.3479
23	1.8595	.253	.2846	.3462	.3479	.3163	.3479
24	1.0279	1.9509	.253	.253	.3612	.3163	.3321
Max	2.2297	2.2125	2.6882	2.7515	2.6724	2.6566	2.7199
Min	.0293	.2214	.2214	.2214	.1898	.253	.1898
Avg	1.0429	1.1768	1.2800	1.3231	1.2214	1.3037	1.2164

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274165 / 33/11KV PALASHI

Feeder No / Name : 204 / Palashi Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.3439	.3403	.3403	.3155	.3224	.2715
2	.3077	.3224	.3224	.3403	.2715	.2865	.2715
3	.2715	.3582	.3224	.3224	.2715	.2865	.3077
4	.4344	.3982	.3582	.4119	.3258	.3582	.362
5	.4887	.4525	.5014	.4477	.362	.394	.4887
6	.5611	.543	.5731	.5552	.5792	.5552	.543
7	.4163	.5249	.4656	.4656	.5611	.5373	.4887
8	.362	.3801	.4119	.4119	.4344	.4656	.4887
9	.3439	.3077	.3761	.394	.3439	.4344	.3801
10	.3403	.2896	.3224	.3439	.362	.3982	.362
11	.3224	.2534	.394	.3258	.3801	.362	.3801
12	.3224	.2353	.5014	.3258	.3258	.3258	.2534
13	.3045	.2172	.3403	.2715	.1991	.1991	.3258
14		.181	.2507	.2172	.1991	.1991	.2534
15		.1581	.2507	.2534	.1991	.2172	.2353
16	.2865	.1991	.2865	.2715	.2534	.2534	.3045
17	.3077		.2507	.197	.3258	.2715	.2686
18	.4525		.3045	.3403	.4525	.3258	.3582
19	.4525	.4477	.4477	.4477	.5249	.3439	.3582
20	.5792	.5194	.5731	.4119	.543	.3439	.394
21	.4163	.5373	.5373	.4477	.4163	.3258	.4119
22	.362	.4119	.4477	.4477	.362	.3439	.3582
23	.4163	.3403	.4119	.3224	.3439	.3258	.3582
24	.362	.4163	.3403	.3582	.3224	.3224	.3258
Max	.5792	.543	.5731	.5552	.5792	.5552	.543
Min	.2715	.1581	.2507	.197	.1991	.1991	.2353
Avg	.3835	.3563	.3888	.3613	.3614	.3416	.3562



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274225 / 33/11 KV GADEGAON

Feeder No / Name : 201 / 11 KV LAXAMAN DAS

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.406	1.8861	1.6804	1.7318	2.4272	2.0538	1.7551
2	1.5261	1.8519	1.6804	1.7661	2.4272	2.0538	1.6804
3	1.5947	1.7833	1.7661	1.8004	2.4272	2.1658	1.587
4	1.989	1.8861	1.8861	1.8004	2.5019	2.2592	.4294
5	2.332	2.0233	1.989	1.9719	2.4832	2.4086	.4668
6		2.2805	2.0233	2.3663	2.5206	2.4832	.5415
7		2.2291	2.2119	2.7435	2.7633	2.8753	.4668
8		2.1262	2.1091	2.6749	2.8567	2.9687	.4108
9		.2743	.2915	.2743	.3174	.3921	2.2965
10		.2915	.2572	.2915		.3921	2.3339
11	.3944	.3086	.2743	.2915		.3921	2.4086
12	.2229	.3086	.2572	.3086		.4108	2.3339
13	.3258	.3258	.2401	.3258		.4108	2.1472
14	.3429	.3086	.2915	.3429	.2801	.3734	1.8298
15	.3601	.3086	.3086	.3086	.3361	.3361	2.0351
16	.2229	.3258	.3429	.3086	.3921	.3361	2.2965
17	.2915	.3086	.3772	.1372	.4108	.4108	.3361
18	.3944	.3429	.4115	.2915	.4294	.4481	.3734
19	.4115	.3944	.4458	.3601	.4481	.4481	.4481
20	.4115	.4458	.4801	.3601	.4108	.4481	
21	.4287	.3772	.4115	.3944	.3734	.4481	.4481
22	.3944	.3429	.4287	.3772	.3361	.4294	.4108
23	1.9547	1.4403	1.6804	2.0576	1.6057	1.7737	.4108
24	1.406	1.9719	1.5947	2.3899		1.7924	1.8298
Max	2.332	2.2805	2.2119	2.7435	2.8567	2.9687	2.4086
Min	.2229	.2743	.2401	.1372	.2801	.3361	.3361
Avg	.8637	1.0059	.9766	1.0698	1.3551	1.1879	1.2729

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274225 / 33/11 KV GADEGAON

Feeder No / Name : 202 / GADEGAON-WAKHARI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1543	.1372	.1372	.1867	.1494	.1494
2	.1372	.1543	.1372	.1372	.1867	.1494	.1494
3	.1543	.1372	.1372	.1372	.1867	.1494	.1867
4	.1715	.1372	.1372	.1372	.1867	.168	.7842
5	.1715	.1715	.1543	.1543	.2054	.168	.8589
6		.2058	.1715	.1886	.2054	.168	.9335
7		.2058	.1715	.2058	.2054	.2054	1.1389
8		.1886	.1715	.1715	.2054	.2054	1.1203
9		1.0288	.823	1.0288	1.0082	1.1576	.1494
10		1.0974	.9259	1.0631		1.307	.1494
11		1.1145	.9602	1.0288		1.307	.1494
12	1.2003	1.0631	1.0631	1.0117		1.2136	.1494
13	1.1831	1.0117	1.0974	.9945		1.1389	.112
14	1.1145	.9602	.9431	1.0288	1.2323	1.0829	.112
15	1.046	.8916	.8916	.9945	1.3817	.9896	.112
16	.7373	.9088	.6687	.9259	1.0642	.9149	.112
17	.1372	.1029	.1372	.1372	.1494	.112	.1494
18	.1543	.12	.1543	.1372	.168	.168	.168
19	.1543	.1372	.1543	.1886	.168	.168	.168
20	.1543	.1886	.1543	.1715	.1867	.168	
21	.1029	.1715	.1372	.1715	.1867	.1867	.2241
22	.1543	.1543	.1372	.1715	.1494	.1867	.2427
23	.1543	.1543	.1372	.1715	.1494	.1867	.7468
24	.1372	.1543	.1543	.1372		.1494	.1494
Max	1.2003	1.1145	1.0974	1.0631	1.3817	1.307	1.1389
Min	.1029	.1029	.1372	.1372	.1494	.112	.112
Avg	.4001	.4422	.4065	.4430	.3901	.4917	.3572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274225 / 33/11 KV GADEGAON

Feeder No / Name : 203 / GADEGAON GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.6859	.5144	.6859	.7468	.5601	.6722
2	.5144	.6516	.5144	.6859	.7468	.5601	.5975
3	.583	.6173	.5144	.6516	.7468	.5601	.5601
4	.6173	.583	.5487	.6516	.7468	.6722	.6348
5	.6859	.6516	.6173	.7202	.8215	.7842	.7842
6		.8573	.7888	.8573	.8962	.8215	.9335
7		.7202	.7545	.7202	.8589	.9709	.7468
8		.7545	.6859	.6859	.8215	.9335	.7842
9		.6173	.6173	.6344	.7842	.7842	.7468
10		.5487	.583	.5144		.8589	.7095
11	.1715	.5487	.6173	.6516		.8402	.6348
12	.1543	.5487	.583	.6516		.8215	.6348
13	.1029	.5144	.5487	.6344		.8215	.6348
14	.1372	.5487	.5144	.6173	.3361	.7095	.5975
15	.1372	.5487	.5487	.583	.2987	.5601	.6722
16	.1372	.583	.5487	.5487	.2614	.6722	.7095
17	.5487	.583	.6173	.583	.2987	.6722	.6348
18	.6859	.583	.6859	.6859	.6722	.7468	.5601
19	.7545	.6687	.823	.7545	.7842	.7842	.8962
20	.8573	.8916	.8573	.7716	.9335	.8962	
21	.8573	.7888	.823	.7888	.8962	.9335	.9335
22	.7888	.7545	.8059	.7545	.8215	.8215	.8215
23	.7202	.7202	.7545	.7202	.7095	.7842	.7842
24	.5487	.6859	.6516	.7202		.6722	.7468
Max	.8573	.8916	.8573	.8573	.9335	.9709	.9335
Min	.1029	.5144	.5144	.5144	.2614	.5601	.5601
Avg	.5009	.6523	.6466	.6780	.6938	.7601	.7144

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 278032 / 220 KV BHALAWANI

Feeder No / Name : 401 / 220 KV CHANDRABHAGA S.S.  
KARK Feeder KV- 220 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	6.8587
Max	6.8587
Min	6.8587
Avg	6.8587

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274051 / 33/11 KV GURSALE

Feeder No / Name : 201 / 11 KV GURUSALE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	2.1948	2.7435	2.7435	2.332	2.572	2.4691
2	.0686	2.3167	2.8807	2.7435	2.332	2.572	2.4691
3	.0686	2.3167	2.8807	2.8654	2.332	2.572	2.4691
4	.0686	2.3167	2.8807	2.8959	2.5377	2.6749	2.7435
5	.0686	2.4082	2.8807	3.0483	2.6063	2.8121	2.9492
6	.0686	2.5606	3.2236	3.2312	2.7435	3.0178	3.0178
7		2.6216	3.155	3.1703	3.0864		3.2236
8		3.0178	3.3608	3.3608	3.2236	3.2922	3.2236
9	3.0864						
10	3.2922						
11	3.3608						
12	3.4979						
13	3.4294						
14	3.3608						
15	3.3608						
16	2.8045						
17		.0686		.0686	.0686	.0686	.0686
18	.0686	.0686	.061	.0686	.0686	.0686	
19	.061	.0686	.061	.0686	.0686	.0686	.0686
20	.061	.0686	.061	.0686	.0686	.0686	.0686
21	.061	.0686	.061	.0686	.0686	.0686	.0686
22	.061	.0686	.061	.0686	.0686	.0686	.0686
23	2.4691	.0686	.061	.0686	.0686	.0686	.0686
24	.0686	2.1948	.0686	.061	.0686	.0686	.0686
Max	3.4979	3.0178	3.3608	3.3608	3.2236	3.2922	3.2236
Min	.061	.0686	.061	.061	.0686	.0686	.0686
Avg	1.4026	1.4018	1.6294	1.5375	1.3589	1.3375	1.5363

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274051 / 33/11 KV GURSALE

Feeder No / Name : 202 / 11 KV HOLE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	1.7071	2.0576	1.6461	2.1262	1.7147	2.1948
2	.4801	1.829	2.0576	1.6461	2.1262	2.0576	2.1948
3	.4801	1.829	2.0576	1.6461	2.1262	2.0576	2.1948
4	.4801	1.9509	2.0576	1.6461	2.1262	2.0576	2.332
5	.4801	2.0119	2.1262	1.6461	2.1262	2.1262	2.4691
6	.4801	2.1338	2.1948	1.6461	2.2634	2.4006	2.4691
7		2.1338	2.4006	1.89	2.4691	2.4006	2.7435
8		2.4006	2.4006	2.1948	2.4006	2.5377	2.7435
9	2.5377						
10	2.6749						
11	2.6063						
12	2.5377						
13	2.332						
14	2.332						
15	2.332						
16	2.1338						
17	.2439		.3048	.3429	.4115	.4801	.3048
18	.1829	.4115	.3048	.4115	.5487	.4801	.4877
19	.1829	.4115	.3048	.4801	.5487	.4801	
20	.2439	.4115	.3048	.4801	.4801	.5487	.4268
21	.2439	.4115		.4115	.4801	.4801	.0152
22	.2439	.4115	.3048	.4115	.4801	.4801	.4268
23	1.5242	2.1262	1.6461	.4115	.4801	.4115	.4268
24	.4801	1.6461	2.0576	1.6461	.4115	.4801	.4115
Max	2.6749	2.4006	2.4006	2.1948	2.4691	2.5377	2.7435
Min	.1829	.4115	.3048	.3429	.4115	.4115	.0152
Avg	1.1688	1.4551	1.5054	1.1598	1.3503	1.3246	1.4561

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274051 / 33/11 KV GURSALE

Feeder No / Name : 203 / 11 KV CHILAIWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6461	.2743	.4115	.2743	.4115	.4115	.4115
2	1.6461	.2743	.4115	.2743	.4115	.4115	.4115
3	1.7833	.2743	.4115	.2743	.4115	.4115	.4115
4	1.7833	.2743	.4115	.4115	.4115	.4115	.4115
5	2.0576	.4115	.4115	.4115	.4115	.4115	.4115
6	2.332	.4115	.4115	.4115	.4115	.4115	.4115
7	2.8807		.4115	.4115		.4115	.4115
8	2.7435		.4115			.4115	
9		3.155	2.7435	2.332	3.4294	3.5665	
10		3.4294	3.7037	2.6063	3.8409	3.7037	2.7435
11		2.7435	3.8409	3.0178	3.7037	3.0178	3.0178
12		3.155	3.5665	2.8807	3.2922	3.5665	2.8807
13		3.0178	3.5665	3.0178	3.2922	3.5665	3.0178
14		3.0178	3.155	2.8807	3.5665	2.8807	2.8807
15		3.155	3.155	2.7435	2.7435	3.2922	2.8807
16		3.155	3.2922	2.332	3.7037	3.7037	2.7435
17	.2743		.2743	.2743	.2743		.1372
18	.2743	.2743		.2743	.4115	.2743	.1372
19	.2743	.4115	.4115	.4115	.4115	.4115	.1372
20	.4115	.4115	.4115	.4115	.4115	.4115	.2743
21	.4115	.4115	.4115	.4115	.4115	.4115	.4115
22	.4115	.4115	.4115	.4115	.4115	.4115	.4115
23	.2743	.4115	.2743	.4115	.4115	.4115	.4115
24	1.6461	.2743	.4115	.2743	.4115	.4115	.4115
Max	2.8807	3.4294	3.8409	3.0178	3.8409	3.7037	3.0178
Min	.2743	.2743	.2743	.2743	.2743	.2743	.1372
Avg	1.3032	1.3978	1.4314	1.1809	1.5089	1.4493	1.1535

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274051 / 33/11 KV GURSALE

Feeder No / Name : 204 / 11 KV GURSALE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.583	.583	.583	.6173	.4801	.6173	.4458
2	.583	.6516	.583	.6859	.4801	.6173	.4458
3	.6173	.6859	.6516	.823	.4801	.6687	.4458
4	.8916	.823	.7202	.8573	.6516	.7888	.5487
5	.9945	.8916	.9602	.9259	.7888	.9259	.6516
9	.6516	.6516	.5144	.6173		.4458	.5487
10	.583	.6173	.5144	.4801		.4458	.5487
11	.5487	.583	.4458	.4115		.3429	.6173
12	.5144	.5144	.5144	.5487		.4115	.583
13	.4458	.5144	.4801	.5144			.4801
14	.4458	.4458		.4458	.4458	.5144	.5144
15	.4458	.4458	.3772	.4115	.3048	.4801	.5487
16	.5144	.4801	.4801	.4458	.3429	.5144	.583
17	.4801		.5144	.3772	.5487	.5144	.5144
18	.583	.6516		.5487	.5144	.5487	.583
19	.6516	.7545	.7202	.6516	.6516	.4115	
20	.6859	.9259	.7202	.8573	.6516	.6859	.823
21	.7202	.823	.7545	.6859	.9259	.6173	.823
22	.7202	.7202	.6516	.6173	.7545	.5487	.5144
23	.583	.6173	.583	.5144	.6516	.5144	.5144
24	.583	.5487	.583	.583	.4458	.6516	.4458
Max	.9945	.9259	.9602	.9259	.9259	.9259	.823
Min	.4458	.4458	.3772	.3772	.3048	.3429	.4458
Avg	.6108	.6464	.5974	.6009	.5699	.5633	.5590



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274051 / 33/11 KV GURSALE

Feeder No / Name : 205 / 11 KV AMR BIOTECH

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0038	.0076	.0038	.0076	.0171	.0038	.0171
2	.0038	.0076	.0038	.0076	.0171	.0038	.0171
3	.0038	.0076	.0038	.0076	.0171	.0038	.0171
4	.0038	.0076	.0038	.0076	.0171	.0038	.0171
5	.0038	.0076	.0038	.0076	.0171	.0038	.0171
6	.0038	.0076	.0038	.0076	.0171	.0038	.0171
7	.0038	.0076	.0171	.0076	.0171	.0038	.0171
8	.0038	.0171	.0171	.0038	.0171	.0076	.0171
9	.0171	.0171	.0171	.0038	.0076	.0076	.0171
10	.0171	.0171	.0171	.0038	.0076	.0076	.0076
11	.0171	.0171	.0171	.0038	.0076	.0076	.0076
12	.0171	.0171	.0171	.0038	.0076	.0076	.0076
13	.0171	.0038	.0171	.0038	.0076	.0076	.0076
14	.0171	.0038	.0171	.0038	.0076	.0076	.0076
15	.0171	.0038	.0171	.0038	.0038	.0171	.0038
16	.0076	.0038	.0076	.0171	.0038	.0171	.0038
17	.0076	.0038	.0076	.0171	.0038	.0171	.0038
18	.0076	.0038	.0076	.0171	.0038	.0171	.0038
19	.0076	.0038	.0076	.0171	.0038	.0171	.0171
20	.0076	.0038	.0076	.0171	.0038	.0171	.0038
21	.0076	.0038	.0076	.0171	.0038	.0171	.0038
22	.0076	.0038	.0076	.0171	.0038	.0171	.0038
23	.0076	.0038	.0076	.0171	.0038	.0171	.0038
24	.0038	.0076	.0038	.0076	.0171	.0038	.0171
Max	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Min	.0038	.0038	.0038	.0038	.0038	.0038	.0038
Avg	.0089	.0078	.0101	.0095	.0097	.0099	.0107

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274051 / 33/11 KV GURSALE

Feeder No / Name : 206 / 11 KV KARKHANA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9797	.2058	.1943	.2058	.1943	.1943	.1943
2	3.0849	.2058	.1943	.2058	.1943	.1943	.1943
3	3.0769	.2058	.1943	.2058	.1943	.1943	.1943
4	3.3608	.2058	.2012	.2058	.1943	.1943	.1943
5	3.3036	.2058	.1943	.2058	.1943	.1943	.1943
6		.2058	.1943	.2058		.2105	.1943
7						.2429	.1943
8	3.2065						
9		3.2388					
10		4.1295					
16					3.6599		
17		3.3684	3.6008	3.9514		4.0486	3.7247
18	.2058	3.7723	3.6008	4.0486	4.1152	3.8056	4.0971
19	.2058	3.5627	3.4294	4.0486	3.4818	3.5627	3.8056
20	.2058	3.4008	3.3951	3.9514		3.4656	3.7247
21	.2058	3.3198	3.3951	3.8866	3.4818	3.4656	3.3198
22	.2058	3.1579	3.3951	3.8866	3.4008	2.5911	3.3198
23	.2058	2.8826	2.8807	2.672	3.4294	3.3198	2.9312
24	.4917	.2058	2.834	2.8807	2.672	3.2388	3.3198
Max	3.3608	4.1295	3.6008	4.0486	4.1152	4.0486	4.0971
Min	.2058	.2058	.1943	.2058	.1943	.1943	.1943
Avg	1.5953	2.0171	1.9788	2.1829	2.1010	1.9282	1.9735

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274051 / 33/11 KV GURSALE

Feeder No / Name : 207 / 11 KV JACKWELL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173						
2	.6173						
3	.6687						
4	.6687						
5	.6859						
6	.703						
7	.6859						
9		.6859	.7202	.703	.7545	.7888	.7373
10			.7545	.7202	.8059	.8059	.7373
11		.703	.703	.7373	.8059	.8573	.7716
12		.7545	.703	.7202	.8059	.8573	.7888
13		.7202	.703	.7716	.8059	.7716	.7545
14		.7373	.703	.7373	.8059	.7716	.7545
15		.7545	.7202		.8059	.7716	.7202
16			.6859	.7373	.8059	.7716	
24	.6173						
Max	.703	.7545	.7545	.7716	.8059	.8573	.7888
Min	.6173	.6859	.6859	.703	.7545	.7716	.7202
Avg	.6580	.7259	.7116	.7324	.7995	.7995	.7520

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274052 / 33/11 KV KARKAMB

Feeder No / Name : 201 / 11 KV UMBARE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
23	.6443
Max	.6443
Min	.6443
Avg	.6443

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274052 / 33/11 KV KARKAMB

Feeder No / Name : 202 / 11 KV SANGAVI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2949		.5144		.6478	.6478	.4696
2	.3563		.4954		.6554	.6668	.4858
3	.3605		.4954		.6783	.6859	.4858
4	.373		.5335		.6478	.6859	.4696
17		.4191					
19		.4382		.3887	.6097	.5144	.5716
20		.4954		.6554	.6668	.5041	.6097
21		.5144		.6554	.6859	.6535	.6668
22		.5144		.6613	.6859	.6602	.6668
23		.5144		.6613	.6478	.543	.6668
24	2.8826		.5144		.6316	.6097	.4696
Max	2.8826	.5144	.5335	.6613	.6859	.6859	.6668
Min	.2949	.4191	.4954	.3887	.6097	.5041	.4696
Avg	.8535	.4827	.5106	.6044	.6557	.6171	.5562

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274052 / 33/11 KV KARKAMB

Feeder No / Name : 203 / 11 KV RANMALA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3567		1.0669		.9012	.9907	.7225
2	.3612		1.105		.873	1.0288	.8907
3	.3715		1.1431		.9717	1.0669	.9717
4	.3906		1.1812		1.3279	1.1431	1.3279
5			1.2193		1.2793	1.2193	1.4449
6			1.5242		1.3998	1.5242	1.7166
7			2.0005		1.5061	1.7147	1.8023
8			1.9052		1.4746	1.7528	1.8138
19		.4382		.3567	.4954	.421	.4954
20		.4572		.4588	.5335	.4049	.4954
21		.4572		.4588	.4954	.4049	.4954
22		.4763		.4409	.5335	.421	.5144
23		.5335		.4409	.4954	.4424	.5144
24	.4064		.4954		.426	.4954	.4012
Max	.4064	.5335	2.0005	.4588	1.5061	1.7528	1.8138
Min	.3567	.4382	.4954	.3567	.426	.4049	.4012
Avg	.3773	.4725	1.2934	.4312	.9081	.9307	.9719

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274052 / 33/11 KV KARKAMB

Feeder No / Name : 204 / 11 KV JADHAVWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0953		.0714	.0953	.0714
2				.081	.0953	.081
3				.081	.0953	.081
4		.0953		.0848	.0953	.081
5				.081	.0953	.081
6				.0848	.0953	.0714
17			2.2672	2.4768	2.0005	2.2862
18	2.4768		2.2672	2.4768	2.2672	2.2862
19	2.6673		2.1052	2.6673	2.1052	2.2862
20	2.6673		2.0805	2.4768	1.9204	2.2862
21			2.13	2.2862	1.9662	2.2862
22			1.9204	2.0957	1.9662	2.2862
23			1.7814	2.0957	1.7814	2.0957
24				1.6347	1.9052	1.5718
Max	2.6673	.0953	2.2672	2.6673	2.2672	2.2862
Min	2.4768	.0953	1.7814	.0714	.0953	.0714
Avg	2.6038	.0953	2.0788	1.3353	1.1774	1.2751

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274052 / 33/11 KV KARKAMB

Feeder No / Name : 205 / 11 KV BARDI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.381		1.9052	
2			.381		2.0957	
3			.4191		2.2862	
4			.4572		2.8578	
5					2.9531	
6					3.0483	
7					3.4294	
8					3.2388	
19		.5716		.5144		.5335
20		.5716		.5716		.5716
21				.5335		.4763
22				.4572		.4191
23				1.7147		1.5242
24	1.0004				1.7147	
Max	1.0004	.5716	.4572	1.7147	3.4294	1.5242
Min	1.0004	.5716	.381	.4572	1.7147	.4191
Avg	1.0004	.5716	.4096	.7583	2.6144	.7049



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274052 / 33/11 KV KARKAMB

Feeder No / Name : 206 / 11 KV Karkamb Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.543		.5716		.543	.5716	.543
2	.5487		.5716		.5487	.5716	.5487
3	.3511		.5716		.5544	.5716	.5487
4	.5487		.5716		.7316	.5716	.7316
5	.7392		.7621		.7316	.7621	.7316
6	.724		.7621		.7392	.7621	.7316
10							.5716
12							.5716
14							.5716
16							.5716
17		.5716		.543	.5716	.5373	.5716
18		.5716		.7164	.5716	.724	.5716
19		.5716		.7164	.5716	.7316	.7621
20		.7621		.7316	.7621	.5487	.7621
21		.7621		.5487	.7621	.543	.7621
22		.7621		.5487	.5716	.5601	.5716
23		.5716		.5544	.5716	.5544	.5716
24	.543		.5716		.543	.5716	.543
Max	.7392	.7621	.7621	.7316	.7621	.7621	.7621
Min	.3511	.5716	.5716	.543	.543	.5373	.543
Avg	.5711	.6532	.6260	.6227	.6267	.6130	.6243

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274052 / 33/11 KV KARKAMB

Feeder No / Name : 207 / 11 KV Diwan Mala

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17
HR	Load (MW)	Load (MW)
19		.0191
24	.763	
Max	.763	.0191
Min	.763	.0191
Avg	.763	.0191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274052 / 33/11 KV KARKAMB

Feeder No / Name : 208 / 11 KV DESHMUKH PATTA  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	03-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
7		.0191	
12			3.4294
14			3.6199
16			3.2388
24	.6443		
<b>Max</b>	<b>.6443</b>	<b>.0191</b>	<b>3.6199</b>
<b>Min</b>	<b>.6443</b>	<b>.0191</b>	<b>3.2388</b>
<b>Avg</b>	<b>.6443</b>	<b>.0191</b>	<b>3.4294</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274052 / 33/11 KV KARKAMB

Feeder No / Name : 209 / 11 KV GULAME FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
11			3.0483
13			2.8578
15			2.8578
16			2.8578
21		.0191	
23			3.0483
24	.6443		
Max	.6443	.0191	3.0483
Min	.6443	.0191	2.8578
Avg	.6443	.0191	2.934

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274054 / 33/11 KV MENDHAPUR

Feeder No / Name : 201 / 11 KV MENDHAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	03-AUG-17	04-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
1			1.4413
2			1.4413
3			1.5384
4			1.5384
5			1.749
6			2.0243
7			.2641
8			.2452
9		.1509	.0754
10		.132	.0754
11		.0754	
12		.0943	
13		.0754	
14		.0566	
15		.0566	
16		.0754	
17		.0754	
18		.0943	
19		.2075	
20		.2452	
21		.1886	
22		.1132	
23		1.4575	
24	.4917		1.4899
Max	.4917	1.4575	2.0243
Min	.4917	.0566	.0754
Avg	.4917	.2066	1.0802

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274054 / 33/11 KV MENDHAPUR

Feeder No / Name : 202 / 11 KV KHARATWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3158	.8097	.583	.502	.7287	.7611	.6478
2	2.3482	.8259	.583	.502	.7287	.5992	.6802
3	2.5425	.8421	.6154	.583	.7287	.6316	.7125
4	2.6235	.8907	.6478	.5992	.8097	.6964	.8097
5	2.915	1.247	.7125	.6802	.8907	.9717	.8907
6	3.1255	1.166	.9393	1.1498	.8907	1.166	.9231
7	3.1903	2.8016	2.7206		2.5911	2.4291	2.5911
8	3.0607	3.2388	2.8178	2.5587	3.1093	2.8988	2.753
9	3.6761	2.1052	3.1093	2.753	3.1741	2.8664	3.1093
10	3.8542	2.1376	3.0931	2.7854	2.3805	2.6882	3.0769
11	3.7247	2.5749	3.1093	2.5911	2.1538	2.672	
12	3.4494	2.753	3.0607	2.2024	2.2834	2.6073	
13	2.9959	2.9635	3.0769	2.2024	2.0567	2.6073	
14	2.8664		3.1093	2.2024	2.7044	2.6558	
15	.2591	3.4008	3.1417	3.2388	2.8988	3.0121	
16	.2915	3.7732	3.255	3.4332	3.4818	3.4979	
17	.421	3.417	3.3684	3.4818	3.5141	3.7247	
18	.6802	3.336	3.5789	3.4008	3.255	3.4494	
19	.8097		3.3846	3.4008	3.3846	3.3846	2.0567
20	1.2631	3.3846	3.3522	3.3198	2.9959	3.2065	3.2874
21	1.085	3.2065	3.3036	3.0769	2.8502	3.0445	3.417
22	.9231	3.0445	3.2065	2.9959	2.9312	2.8178	3.3846
23	.6478	.5506	.664	.8097	1.1336	.6478	.6316
24	.5765	.4858	.5506	.583	.8097	.6478	.6478
Max	3.8542	3.7732	3.5789	3.4818	3.5141	3.7247	3.417
Min	.2591	.4858	.5506	.502	.7287	.5992	.6316
Avg	2.0686	2.2252	2.3326	2.1327	2.1869	2.2368	1.8512

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274054 / 33/11 KV MENDHAPUR

Feeder No / Name : 203 / 11 KV PANDHAREWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	1.6549	1.4419		1.4575	1.4419	1.7166
2	.1132	1.7166	1.4419		1.5384	1.5565	1.7166
3	.132	1.7652	1.4746		1.5384	1.6057	1.6842
4	.1698	1.7814	1.5546		1.6194	1.6712	1.749
5	.2263	1.6356	1.6194		1.7004	1.9662	1.8138
6	.3206	1.7814	1.9109		1.7814	2.0567	2.0405
7	.3206	.3772	.3772		.2641	.3206	.3395
8	.3018	.2829	.3018		.2641	.2452	.2263
9	.2075	.2641			.0943	.2452	.1886
10	.132	.1886			.0943	.1132	.1698
11	.0754	.0943		.0377	.0754	.0943	
12	.0754	.0943		.0377	.0754	.0754	
13	.0754	.0943		.0377	.0566	.0754	
14	.0754	.0943		.0377	.0566	.0566	
15	2.0559	.0943		.0377	.0566	.0754	
16	1.6518	.1132		.0377	.0566	.132	
17	2.0405	.0943		.0377	.2452	.1132	
18	1.9109	.1886		.0566	.1698	.1886	
19	1.9433	.2641		.1886	.1886	.2641	.132
20	1.668	.2641		.2641	.2075	.2263	.1698
21	1.6842	.1509		.2263	.1132	.1886	.2263
22	1.7814	.1132		.1132	.132	.1132	.1886
23	1.8623	1.3927		1.3765	1.2631	1.6518	1.4091
24	.1132	1.9662	1.4419		1.3765	1.4746	1.6842
Max	2.0559	1.9662	1.9109	1.3765	1.7814	2.0567	2.0405
Min	.0754	.0943	.3018	.0377	.0566	.0566	.132
Avg	.7938	.6861	1.2849	.1915	.6011	.6647	.9659

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274054 / 33/11 KV MENDHAPUR

Feeder No / Name : 204 / 11 KV Jadhavwadi Feeder SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9757	.2075	.1886	.1698	.1886	.1509	.1886
2	1.9757	.2075	.1886	.1698	.1886	.1698	.1886
3	2.0243	.2263	.1886	.2075	.1886	.1698	.2263
4	2.1538	.1886	.2263	.2452	.1886	.2263	.2263
5	2.2834	.2641	.2263	.2452	.2263	.2641	.2641
6	2.5101	.2452	.2452	.2641	.2263	.2641	.3018
7	.8907	.2829	.2641	.2452	.2641	.2452	.2452
8	2.1376	.2641	.2452	.2075	.2452	.2641	.2263
9	.1132	2.7854	2.9959	2.2672	2.6882	3.0967	2.9492
10	.0754	2.5911	3.0931	2.4939	.4372	3.2388	.9339
11	.0754	3.2388	3.1417	2.672	2.8664	3.336	
12	.0754	3.1579	3.2065	3.0769	3.1579	3.0769	
13	.1132	3.2388	3.1579	3.0769	3.0769	3.1093	
14	.132		2.9959	3.1579	.1781	3.1093	
15	.132	2.8502	2.915	3.1579	.0983	2.4939	
16	.0754	2.8178	2.7692	3.255	2.7044	2.9797	
17	.0754	.0943	.1296	.1509	2.915	.1132	
18	.1509	.1886	.1886	.1132	.1886	.1509	.132
19	.1886	.2263	.1886	.1886	.2075	.1886	.132
20	.1886	.2641	.2452	.2641	.1943	.1886	.1698
21	.2075	.2263	.2829	.1715	.1509	.1886	.1698
22	.2263	.2263	.2075	.1698	.1698	.1886	.1509
23	.2641	.1698	.1698	.1698	.1509	.1886	.132
24	1.9433	.2452	.1886	.1698	.1698	.1509	.1886
Max	2.5101	3.2388	3.2065	3.255	3.1579	3.336	2.9492
Min	.0754	.0943	.1296	.1132	.0983	.1132	.132
Avg	.8328	1.0525	1.1520	1.0962	.8779	1.1480	.4015



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274054 / 33/11 KV MENDHAPUR

Feeder No / Name : 205 / 11 KV Ropale Feeder SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	1.9109	1.9757	.1886	1.6194	1.8023	2.2672
2	.1886	1.9662	1.9757	.1886	1.7814	1.8842	2.2672
3	.1886	1.9989	2.0081	.1865	1.7814	1.8623	2.2996
4	.2075	2.0481	2.0729	.1865	1.9433	2.0729	2.332
5	.2263	2.2119	2.1052	.2075	1.9433	2.1862	2.3967
6	.2263	2.1538	2.2672	.1886	2.0891	2.4291	2.5587
7	.2452	2.5749	2.6235		2.7854	2.753	2.834
8	.2452	2.6882	2.7692	2.5749	2.5911	2.834	2.4291
9	2.2186						
10	2.5587		.0754				
11	2.7692		.0754	.0754		.0754	
12	2.8178	.0754	.0566	.0754	.0943	.0754	
13	2.834	.132	.0566	.0943	.1132	.0943	
14	2.8502	.132	.0754	.1132	.132	.1132	
15	2.7368	.0943	.0754	.1132	.132	.0943	
16	2.7044	.0943	.0943	.1132	.1132	.132	
17		.1132	.1132	.132	.132	.132	
18		.1509	.1509	.1509	.1698	.1509	.132
19	.132	.1886	.1509	.1886	.1886	.1886	.132
20	.1698	.1886	.1509	.2452	.2263	.1886	.1698
21	.1886	.1886	.1509	.1886	.2075	.1698	.1698
22	.2075	.1698	.1509	.1886	.1698	.1698	.1509
23	1.668	2.0153	.1886	1.4575	1.085	2.2672	2.251
24	.1886	1.9271	2.0317	.1886	1.4575	1.3108	2.2996
Max	2.8502	2.6882	2.7692	2.5749	2.7854	2.834	2.834
Min	.132	.0754	.0566	.0754	.0943	.0754	.132
Avg	1.1709	1.0963	.9302	.3355	.9884	1.0448	1.6460

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274055 / 33/11 KV PAT KUROLI

Feeder No / Name : 201 / 11 KV DEWADE FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.4409	1.5432	1.4918	1.3717	1.5604	1.4746
2	.4287	.4572	1.5432	1.5604	1.4403	1.6975	1.6108
3		1.4413	1.6289	1.6804	1.4746	1.7833	1.6194
4		1.6356	1.8004	1.7318	1.5432	1.869	1.8023
5		1.7652	2.1434	1.7661	1.5775	1.9033	1.8842
6		1.8785	2.1434	1.7833	1.6461	1.989	1.9662
7		1.9595	2.1605	1.8347	1.8861	2.1091	1.9334
8		2.0567	2.0062		2.0405	2.2119	1.9662
9	1.7147	2.1376					
10	1.869	2.0891					
11	1.989	2.0891					
12	2.1262						
13	2.0919						
14	2.1605						
15	2.1091						
16	2.0748						
17	.2229		.2058	.2915	.2058	.2743	.2294
18		.2743	.2401	.3772	.2572	.3086	.3109
19	.4801	.3429	.2572	.4115	.3086	.4458	.3801
20	.5144	.4287	.2915	.4115	.3601	.4801	.4207
21	.3601	.4287	.3601	.4115	.3772	.4458	.4207
22	.4287	.4115	.4115	.4115	.4115	.4115	.4207
23	.4287	.9717	1.3203	1.3717	1.3203	1.3717	1.2955
24	.4287	.4525	1.4575	1.406	1.406	1.4403	1.3435
Max	2.1605	2.1376	2.1605	1.8347	2.0405	2.2119	1.9662
Min	.2229	.2743	.2058	.2915	.2058	.2743	.2294
Avg	1.1690	1.1812	1.2196	1.1294	1.1017	1.2689	1.1924

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274055 / 33/11 KV PAT KUROLI

Feeder No / Name : 202 / 11 KV WATER SUPPLY FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.5765
Max	.5765
Min	.5765
Avg	.5765

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274055 / 33/11 KV PAT KUROLI

Feeder No / Name : 203 / 11 KV PAT KURUL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.6443
Max	.6443
Min	.6443
Avg	.6443

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274055 / 33/11 KV PAT KUROLI

Feeder No / Name : 204 / 11 KV SHEVATE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.6478	.1029	.0857	.0857	.0857	.0857
2	.4801	.664	.1029	.0857	.0857	.0857	.0857
3	.5144						
4	.5144						
5	.5144						
6	.5144		.1029				
7	.6859						
8	.7716						
9			.7202	.463	.6859	.5658	.6859
10			.7716	.5144	.7545	.8059	.7449
11			.7716	.6001	.8059	.8573	.6478
12		.5506		.6001	.8402	.8573	.6154
13		.5992		.6001	.823	.7716	.6478
14		.6478	.6859	.6516	.823	.7716	.7125
15		.6802	.7716	.7202	.823	.7716	.7287
16		.7287	.6859	.7545	.8059	.7716	.7449
17	.0514	.0848	.0857	.0857	.0514	.0857	.0486
18	.0686	.0857	.0857	.0857	.0514	.0857	.0686
19	.0857	.0914	.0857	.0857	.0514	.0857	.0686
20	.0686	.0857	.0857	.0857	.0514	.0857	.0686
21	.1372	.0857	.0857	.0857	.0514	.0857	.0686
22	.1372	.0857	.0857	.0857	.0514	.0857	.0686
23	.5316	.1029	.0857	.0857	.0857	.0857	.0857
24	.4458	.6154	.1029	.0857	.0857	.0857	.0857
Max	.7716	.7287	.7716	.7545	.8402	.8573	.7449
Min	.0514	.0848	.0857	.0857	.0514	.0857	.0486
Avg	.3729	.3837	.3187	.3201	.3896	.3905	.3479

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274055 / 33/11 KV PAT KUROLI

Feeder No / Name : 205 / 11 KV OLD NANDURE FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.8478
Max	.8478
Min	.8478
Avg	.8478

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274055 / 33/11 KV PAT KUROLI

Feeder No / Name : 206 / 11 KV PAT.KUROLI GAOTHAN GAOTHAN FEEDER  
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3658	.3429	.3429	.3429	.3429	.3429
2	.3429	.3658	.3429	.3429	.3429	.3429	.3429
3	.3429	.3658	.3429	.3429		.3429	.3429
4	.3429	.3658	.3429	.3429	.3429	.3429	.3429
5	.3429	.5121	.3429	.3429	.3429	.3429	.3429
6	.3429	.3658	.3429	.3429	.3429	.3429	.3429
7	.3429	.3658	.3429	.3429	.3429	.3429	.3429
8	.3429	.3658	.3429	.3429	.3429	.3429	.3429
9	.3429	.1829	.3429	.1715	.1715	.1715	.1715
10	.1715	.1829	.1715	.1715	.3429	.1715	.1715
11	.1715	.1829	.1715	.1715	.1715	.1715	.1715
12	.1715	.1829	.1715	.1715	.1715	.1715	.1715
13	.1715	.1829	.1715	.1715	.1715	.1715	.1715
14	.1715	.1829		.1715	.1715	.1715	.1715
15	.1715	.1829		.1715	.1715	.1715	.1715
16	.1715	.1829	.1715	.1715	.1715	.1715	.1829
17	.1715	.1829	.1715	.1715	.1715	.1715	.1829
18	.3429	.5121	.1715	.1715	.1715	.1715	.1829
19	.3429	.3658	.1715	.3429	.3429	.3429	.1829
20	.3429	.3658	.3429	.3429	.3429	.3429	.3658
21	.3429	.3658	.3429	.3429	.3429	.3429	.3658
22	.3429	.3658	.3429	.3429	.3429	.3429	.3658
23	.3429	.3658	.3429	.3429	.3429	.3429	.3658
24	.1715	.3658	.3429	.3429	.1715	.3429	.1715
Max	.3429	.5121	.3429	.3429	.3429	.3429	.3658
Min	.1715	.1829	.1715	.1715	.1715	.1715	.1715
Avg	.2786	.3094	.2806	.2715	.2684	.2715	.2629

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274055 / 33/11 KV PAT KUROLI

Feeder No / Name : 207 / New Nandure

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.4917
Max	.4917
Min	.4917
Avg	.4917



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274055 / 33/11 KV PAT KUROLI

Feeder No / Name : 208 / taratgaon  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.4917
Max	.4917
Min	.4917
Avg	.4917

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274055 / 33/11 KV PAT KUROLI

Feeder No / Name : 209 / 11 Kv khed Bhose

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.5765
Max	.5765
Min	.5765
Avg	.5765

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274057 / 33/11 KV TUNGAT

Feeder No / Name : 201 / 11 KV TUNGAT

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.6443
Max	.6443
Min	.6443
Avg	.6443

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274057 / 33/11 KV TUNGAT

Feeder No / Name : 202 / 11 KV SUSTE  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7375	1.0059	.9297	1.0059	1.0517	1.0059	1.0517
2	1.7375	.9755	.9145	.9907	1.0669	.9907	1.0669
3	1.768	1.0364	.9755	1.0364	1.0517	.9755	1.0822
4	1.4632	.945	1.0364	1.0059	1.0669	1.0517	1.1736
5	1.5242	1.0059	1.0517	1.0212	1.0517	1.1126	1.1888
6	1.7985	.9755	1.1126	1.0364	1.0669	1.2193	1.2346
7	2.1338	1.1584	1.1736	1.1584	1.1126	1.2803	1.2498
8	2.0729	1.2193	1.2803	1.1584	1.2193	1.2193	1.2346
9	1.2498	2.0729	2.0119	1.9509	2.1948	2.1643	2.2558
10	1.4175	2.3472	2.2862			2.5911	2.5606
11	1.3413	2.4082	2.5606	1.5851		2.5911	2.4996
12	1.4022	2.4539	2.4691	2.1338		2.5606	2.2558
13	1.2803	2.4539	2.5911	2.4691	2.1948	2.3472	2.1948
14	1.2193	2.4844		2.4387	2.3777	2.5606	2.4387
15	1.2193	2.2558	1.7375	2.1948	2.4387	2.3015	2.1338
16	1.1584	2.0881	1.829	2.3777	2.774	2.5911	2.3167
17	.1372	.0686	.1372	.1372	.1372	.1372	.0343
18	.1372	.1715	.1715	.1715	.1677	.1715	.0343
19	.1372	.1715	.2058	.1715	.1715	.1715	.0343
20	.1372	.1715	.2058	.1886	.2058	.1715	.1886
21	.1372	.1715	.2058	.1715	.2058	.1886	.1715
22	.1372	.1543	.1715	.1543	.2058	.1715	.1715
23	.9755	.9755	.9755	1.0364	1.0364	1.0974	1.0974
24	1.7375	.945	.9145	1.1126	1.0364	1.0364	1.0669
Max	2.1338	2.4844	2.5911	2.4691	2.774	2.5911	2.5606
Min	.1372	.0686	.1372	.1372	.1372	.1372	.0343
Avg	1.1692	1.2382	1.1716	1.1612	1.1350	1.3212	1.2807

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274057 / 33/11 KV TUNGAT

Feeder No / Name : 203 / 11 KV ROPALE  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4632	.0171	.0343	.0171	.0171	.0171	.0171
2	1.4327	.0171	.0171	.0171	.0171	.0168	.0171
3	1.4327						
4	1.6118						
5	1.4022						
6	1.4632						
7	1.7375						
8	1.6766						
9		1.829	1.9509	2.0729	2.21	2.1033	2.21
10		1.9966	2.3777	2.1948	2.1643	2.2558	2.3167
11		2.4387	2.4082	2.1643	2.2253	2.4539	2.4387
12		2.4082	2.1643	2.3472	2.5606	2.4387	2.3777
13		2.1338	2.2862	2.1948	2.1033	2.1795	2.1338
14		2.1643	2.2253	2.271	2.4082	2.2558	2.3167
15	.0171	2.4082	2.0424	2.2558	2.2558	2.3167	2.3777
16	.0171	2.0881	2.2558	2.4082	2.4691	2.2558	2.2253
17	.0171	.0171	.0168	.0171	.0171	.0171	.0171
18	.0171	.0171	.0171	.0171	.0171	.0171	.0343
19	.0171	.0171	.0171	.0343	.0171	.0171	.0362
20	.0171	.0171	.0171	.0171	.0171	.0171	.0343
21	.0171	.0343	.0171	.0343	.0171	.0171	.0171
22	.0171	.0343	.0171	.0343	.0168	.0171	.0171
23	.0171	.0343	.0171	.0171	.0171	.0171	.0171
24	1.4632	.0171	.0343	.0171	.0171	.0171	.0171
Max	1.7375	2.4387	2.4082	2.4082	2.5606	2.4539	2.4387
Min	.0171	.0171	.0168	.0171	.0168	.0168	.0171
Avg	.7687	.9828	.9953	1.0073	1.0315	1.0239	1.0345

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274057 / 33/11 KV TUNGAT

Feeder No / Name : 204 / 11 KV NARANCHOLI  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	1.6613	1.9052	1.7071	1.7071	1.7985	1.7985
2	.1029	1.7375	2.1033	1.7375	1.7223	1.829	1.8138
3		1.8442	2.1338	1.7985	1.7375	1.8747	1.9814
4		2.1186	2.3777	1.829	1.768	2.1948	2.4387
5		2.2405	2.4082	2.1033	1.829	2.6368	2.4996
6		2.4387	2.4996	2.4387	2.1338	2.8654	2.5301
7		2.6368	2.7435	2.5453	2.6216	2.8045	2.8502
8		2.5911	2.5911	2.5301	2.6063	2.774	2.8045
9	2.6216						
10	2.8959						
11	2.8959						
12	2.7282						
13	2.7587						
14	2.6216						
15	2.652	.0857	.0686	.0857	.1029	.12	.1029
16	2.6368	.0857	.12	.0857	.1029	.12	.1543
17	.12	.12	.1372	.12	.12		.1543
18	.1372	.1543	.1372	.1372	.1677	.1543	.1715
19	.1543	.1677	.1509	.1715	.1886	.1886	.1886
20	.1543	.1543	.1715	.1677	.1715	.1715	.1543
21	.1543	.1543	.1372	.1715	.1372	.1715	.1372
22	.1715	.1543	.1543	.1543	.1543	.1543	.1372
23	1.5546	1.7375	1.6918	1.6766	1.7528	1.7833	1.7375
24	.1029	1.5851	1.768	1.6766	1.6766	1.768	1.8138
Max	2.8959	2.6368	2.7435	2.5453	2.6216	2.8654	2.8502
Min	.1029	.0857	.0686	.0857	.1029	.12	.1029
Avg	1.3648	1.2038	1.2944	1.1742	1.1500	1.3770	1.3038

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274057 / 33/11 KV TUNGAT

Feeder No / Name : 205 / 11 KV TUNGAT GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.4344	.3801	.3801	.3258	.3258	.463
2	.3772	.4525	.362	.362	.3429	.3429	.4801
3	.3772	.4887	.3801	.3801	.3429	.3601	.4973
4	.4115	.543	.4706	.4163	.3258	.4115	.4973
5	.4973	.5792	.5068	.5249	.3772	.4458	.4801
6	.6001	.5973	.5792	.543	.4801	.5487	.4973
7	.4973	1.4299	.5068	.4344	.4115	.5316	.5144
8	.3429	.3982	.362	.3982	.3258	.4458	.4115
9	.3086	.3439	.3258	.3439	.2572	.4287	.3772
10	.2743	.362	.362	.362	.3429	.3944	.3772
11	.2401	.3439	.4163	.3258	.3429	.3601	.3944
12	.2229	.3077	.3982	.2715	.2743	.3429	.2915
13	.2743	.2715	.2715	.2401	.2743	.3258	.2915
14	.3258	.2715	.2534	.2229	.2401	.3086	.3086
15	.3077	.2896	.2715	.2229	.2743		.2915
16	.2896	.362	.2534	.2229	.2743	.12	.3086
17	.3258	.3801	.3258	.2915	.2743	.2401	.3772
18	.362	.5068	.3982	.3429	.3944		.4344
19	.3982	.543	.4706	.4801	.4458	.3601	.4887
20	.4706	.5792	.5068	.5144	.5487	.583	.543
21	.5249	.5249	.543	.4973	.5487	.5144	.543
22	.5068	.5249	.5068	.463	.4973	.5487	.5068
23	.4163	.3801	.3982	.3601	.3772	.4115	.4706
24	.362	.3801		.362	.3429	.3429	.4287
Max	.6001	1.4299	.5792	.543	.5487	.583	.543
Min	.2229	.2715	.2534	.2229	.2401	.12	.2915
Avg	.3773	.4706	.4021	.3734	.3601	.3952	.4281

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274058 / 33/11 KV UMBRE

Feeder No / Name : 201 / 11 KV KANHAPURI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.1989	.1989	.2321	.2458	.2155	.1989
2	.1772	.1989	.2486	.2321	.213	.2155	.2155
3	.2126	.2321	.2652	.1989	.2458	.2321	.2155
4	.2303	.2155	.2486	.1989	.2949	.2486	.2155
5	.1772	.2155					
6	.1949						
7	.1772						
8	.2303						
9		2.4531	2.652	2.4863	2.8346	2.8178	2.6852
10		2.4863	2.7183	2.5029	2.9656	2.8841	2.7183
11			2.7846	2.5692	2.9172	2.8178	2.7515
12			2.8012	2.6216	2.8178	2.7846	2.7515
13			2.7349	2.7349	2.8344	2.7681	2.7515
14			2.7183	2.6216	2.8509	2.7681	2.7515
15			2.6189	2.6023	2.9504	2.7183	2.7349
16			2.4863	2.6686	3.0167	2.6686	2.7018
17	2.7846						
18	2.6023						
19	2.5526	.2321	.2321	.2294	.1823	.1989	.1658
20	2.5194	.2486	.2155	.1802	.1989	.1989	.1823
21	2.4531	.2321	.2402	.2294	.2321	.2321	.2155
22	2.5526	.2984	.2486	.2294	.2486	.3315	.2155
23	2.5526	.2984	.2486	.2458	.2486	.2984	.2321
24	2.6023	2.7515	.3315	.2486	.2785	.2515	.3315
Max	2.7846	2.7515	2.8012	2.7349	3.0167	2.8841	2.7515
Min	.1772	.1989	.1989	.1802	.1823	.1989	.1658
Avg	1.3901	.7740	1.3329	1.2796	1.4209	1.3695	1.3352



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274058 / 33/11 KV UMBRE

Feeder No / Name : 202 / 11 KV KAROLE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.176	.1898	.1029	.1063	.1467	.132	.1334
2	.1572	.1898	.144	.1181	.1915	.1659	.1334
3	.2029	.1898	.1511	.1181	.161	.16	.1334
4	.1833	.1898	.1372	.1219	.1658	.1758	.1334
5	.2201						
6	.1867						
7	.1738						
8	.168						
9		2.2405	2.0018	1.8747	2.451	2.6886	2.5911
10		2.2565	2.1186	1.9052	2.7206	2.7686	2.6368
11		2.2565	2.21	2.1214	2.7206	2.7206	2.9492
12			2.2405	2.1186	2.7206	2.6246	2.9635
13			2.21	2.332	2.7206	2.5286	2.9312
14			2.1795	2.1186	2.7206	2.5617	2.915
15			2.2405	2.1643	2.7366	2.5934	2.8807
16			2.0576	2.2809	2.7526	2.6724	2.8967
17	2.4326						
18	2.5126						
19	2.4006	.1425	.128	.1467	.1656	.192	.1698
20	2.3045	.1532	.128	.1429	.1299	.16	.1677
21	2.1445	.1684	.128	.1734	.1739	.1734	.1718
22	2.0805	.161	.1174	.1669	.132	.192	.1677
23	2.0805	.1372	.1067	.1448	.1362	.192	.1867
24	1.9814	2.0241	.2454	.0854	.153	.1463	.1467
Max	2.5126	2.2565	2.2405	2.332	2.7526	2.7686	2.9635
Min	.1572	.1372	.1029	.0854	.1299	.132	.1334
Avg	1.2128	.7922	1.0360	1.0133	1.2833	1.2693	1.3505

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274058 / 33/11 KV UMBRE

Feeder No / Name : 203 / 11 KV UMBRE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5971	.064		.064	.0633	.0633	.064
2	1.7394	.064	.061	.064	.0474	.0633	.064
3	1.6762	.064	.061	.064	.0633	.0633	.064
4	1.8343	.064	.061	.064	.0474	.0633	.064
5	1.7394	.064	.061	.064	.0625	.0633	.064
6	1.8027	.064	.061	.064	.0625	.0633	.064
7	1.9608	.064	.061	.064	.0469	.0633	.064
8	2.119	.064	.061	.064	.0625	.0633	.064
17			2.1765	2.4996	2.8464	3.1367	3.0045
18			2.1765	2.4059		3.1367	2.9729
19	.064	1.2803	2.1125	2.3434	2.9729	3.0407	3.0045
20	.064	1.3443	2.1125	2.2497	2.6566	3.0045	2.8464
21	.064	1.4723	2.0485	2.3434	2.5301	2.9096	2.7831
22	.064	1.4723	2.0485	2.1872	2.5934	2.8807	2.7831
23	.064	1.1203	2.0485	2.2497	2.5934	2.8807	2.8147
24	.0633	.064	1.0669	2.0485	2.1872	2.5617	2.8807
Max	2.119	1.4723	2.1765	2.4996	2.9729	3.1367	3.0045
Min	.0633	.064	.061	.064	.0469	.0633	.064
Avg	1.0609	.5190	1.0812	1.1775	1.2557	1.5036	1.4751

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274058 / 33/11 KV UMBRE

Feeder No / Name : 204 / 11 KV UMBRE GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024	.4344	.5601	.4298	.4435	.4527	.4525
2	.4435	.4344	.5544	.4477	.439	.4527	.4525
3	.4435	.4525	.6036	.4298	.4706	.4854	.4344
4	.5281	.4706	.6036	.4656	.4706	.4904	.4344
9	.3696	.3982	.3506	.362	.3544	.3658	.2172
10	.3292	.3982	.3467	.3224	.2835	.3224	.2172
11	.2896		.3982	.3086	.2865	.3224	.2534
12	.2896		.3982	.2865		.3403	.2561
13	.3258		.362	.2641	.2149	.2865	.2587
14			.3439	.2587	.1791	.2534	.2587
15	.2534		.362	.2896	.181	.2534	.2427
16	.2353		.362	.2743	.2149	.2534	.2743
17	.2896		.362	.2743	.2534	.3258	.2835
18	.3801	.4252	.362	.2835		.3258	.3258
19	.394	.5316	.4163	.3658	.4435	.362	.3696
20	.3982	.5853	.4119	.4706	.4481	.4163	.4481
21	.4344	.6154	.4656	.4435	.4805	.4706	.4527
22	.4706	.5853	.4477	.4435	.4527	.4706	.4527
23	.4706	.5544	.4298	.3982	.4527	.4525	.4527
24	.4527	.4344	.4854	.4298	.3326	.4527	.4344
Max	.5281	.6154	.6036	.4706	.4805	.4904	.4527
Min	.2353	.3982	.3439	.2587	.1791	.2534	.2172
Avg	.3790	.4861	.4313	.3624	.3556	.3778	.3486

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274058 / 33/11 KV UMBRE

Feeder No / Name : 205 / 11KV Kanal Fata Feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.21	.2035	.2374	.2058	.2229	.1844	.2713
2	2.3148	.2035	.2743	.2058	.2715	.208	.2713
3	2.3805	.2374	.2743	.2743	.2572	.2058	.3052
4	2.536	.2374	.2713	.2401	.3189	.2374	.3052
5	2.4228	.2035	.2543	.2401	.2715	.1696	.3391
6	2.5143	.2374	.2515	.2401	.2743	.1907	.3391
7	2.6155	.2374	.2401	.2743	.2743	.1928	.3391
8	2.5446	.2204	.2572	.3048	.2427	.1791	.3222
17			3.12	2.9264	3.0681	3.0407	3.2023
18		2.7978	3.1369	3.0283		3.2556	3.2047
19	.1696	2.7949	3.1207	3.1036	3.1131	3.2217	3.199
20	.1696	2.774	3.1207	2.9338	3.0996	3.1539	3.2156
21	.1696	2.6235	3.0693	2.8006	3.0691	3.103	3.083
22	.2035	2.6578	3.0007	3.152	2.8837	3.0521	3.0178
23	.2035	2.5206	2.9664	2.9165	2.8502	2.9843	2.9504
24	.1698	.2204	2.5139	2.9492	2.7349	2.8317	2.9673
Max	2.6155	2.7978	3.1369	3.152	3.1131	3.2556	3.2156
Min	.1696	.2035	.2374	.2058	.2229	.1696	.2713
Avg	1.4732	1.2113	1.6318	1.6122	1.5301	1.6382	1.7083

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274058 / 33/11 KV UMBRE

Feeder No / Name : 206 / 11 KV SANGAVI FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2138	.2458	.1781	.2622	.2429	.1638	.1966
2	2.2455	.2294	.1943	.2622	.2105	.1638	.1966
3	2.3245	.2294	.2105	.2785	.2429	.1966	.1802
4	2.2297	.2622	.1943	.2622	.2267	.1966	.1966
5	2.372	.2622	.2591	.2458	.2429	.2294	.213
6	2.451	.2949	.2915	.2622	.2591	.2785	.213
7	2.7846	.2949	.3239	.2949	.2949	.3113	.213
8	2.5606	.2622	.3239	.3113	.2294	.2949	.0983
10					.2294		
17			3.0639	3.4008	3.1131	3.3425	3.1786
18		2.5232	3.0803	3.336		3.408	3.1459
19	.2294	2.769	3.0148	3.2388	3.2278	3.3261	3.0312
20	.2652	2.7526	2.982		3.1131	3.2769	2.982
21	.2622	2.7362	2.8837	3.0769	3.0639	3.0476	3.0148
22	.2294	2.6379	2.7854	2.9797	2.9492	.208	3.0476
23	.2294	2.5396	2.6726	2.8664	2.8837	2.9165	2.8018
24	.1966	.213	2.4291	2.7035	2.7854	2.8018	2.8837
Max	2.7846	2.769	3.0803	3.4008	3.2278	3.408	3.1786
Min	.1966	.213	.1781	.2458	.2105	.1638	.0983
Avg	1.4710	1.2168	1.5555	1.5854	1.4572	1.5101	1.5996

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274058 / 33/11 KV UMBRE

Feeder No / Name : 207 / 11 KV JALOLI FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	2.3045	2.4394	2.3045		2.6254	1.7044
2	.156	2.2805	2.4272	2.3285		2.6873	1.8244
3	.144	2.3765	2.4148	2.3765		2.6625	1.8004
4	.132	2.3765	2.4272	2.4366		2.613	1.8004
5		2.3765	2.5139	2.4966		.743	1.8484
6		2.5206	2.6006	2.6406		.743	1.8484
7		2.5806	2.6625	.7682			1.8484
8		2.7126	2.5634	.6722	.5325		1.8244
9	2.934						
11							.0074
13	2.9407						
14	2.8206						
15	2.7246						
16	2.8447						
19	.168	.096	.108	.108	.0991	.084	.084
20	.2294	.1115	.096	.132	.0991	.084	.084
21	.2294	.1115	.096	.108	.1115	.072	.12
22	.156	.1115	.096	.0975	.1115	.072	.0692
23	.156	.1115	.096	.1341	.1115	.072	.132
24	.168	.156	.1115	.096		.0991	.06
Max	2.9407	2.7126	2.6625	2.6406	.5325	2.6873	1.8484
Min	.12	.096	.096	.096	.0991	.072	.0074
Avg	1.0616	1.4447	1.4752	1.1928	.1775	1.0464	1.0037

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274058 / 33/11 KV UMBRE

Feeder No / Name : 208 / 11 KV KALANANI FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2103	2.0873	1.9867	1.6827	2.6406	1.9749	2.5926
2	.1658	2.0873	2.0525	1.7314	.3601	2.1222	2.5606
3	.1989	2.119	2.0424	1.7314	.4201	2.1914	2.6246
4	.1989	2.1506	2.0525	1.8046	.4561	2.4129	2.6886
5		2.2455	2.1605	1.7924	.4801	2.5425	2.7526
6		2.3878	2.21	1.829	.4921	2.7035	2.7526
7		2.4194	2.2439	1.8534	.5161	2.8182	2.7686
8		2.4669	2.2253	1.9753	2.5857	2.9504	2.9127
9	3.0498						
10	3.0996						
11	2.9767						
15	2.8166						
16	2.8647						
19	.1658	.1635	.1219	.1524	.1802	.16	.1423
20	.1658	.1505	.1463	.1943	.1698	.192	.16
21	.1658	.1656	.1463	.1543	.1718	.192	.16
22	.1638	.16	.1341	.1739	.1718	.16	.16
23	.16	.1486	.1219	.1981	.153	.16	.1898
24	.2229	.1562	.1536	.1219	.12	.16	.16
Max	3.0996	2.4669	2.2439	1.9753	2.6406	2.9504	2.9127
Min	.16	.1486	.1219	.1219	.12	.16	.1423
Avg	1.1084	1.3506	1.2713	1.0997	.6370	1.4814	1.6161

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274058 / 33/11 KV UMBRE

Feeder No / Name : 209 / 11 KV SUTAR MALA  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.1886	.2667	.1886	.2286	.1524	.1886
2	.2667	.1886	.2667	.1886	.2286	.1524	.1886
3	.2286	.1886	.2667	.1886	.2667	.1524	.1886
4	.2667	.1886	.2667	.1886	.2667	.1905	.7545
5	.3048						
6	.2667						
7	.2286						
8	.2286						
9		3.546	3.7342	3.0933	3.6199	3.5056	3.3951
10		3.5837	3.8104	3.0933	3.5437	3.5818	3.2819
11			3.7346	3.2065	3.5437	3.5056	3.4294
12			3.7346	3.3951	3.5056	3.5056	3.5818
13			3.6969	3.2819	3.5056	3.4294	3.546
14			3.6214	3.2065	3.5056	3.4705	3.5082
15			3.5837	3.2065	3.6199	3.4705	3.6214
16			3.5082	3.0933	3.6961	3.5082	3.6969
17	3.5837						
18	3.6969						
19	3.5837	.2286	.1509	.2667	.1524	.2263	.1905
20	3.5082	.2286	.1509	.2286	.1524	.2263	.1905
21	3.2065	.2286	.1509	.2667	.1905	.2263	.1905
22	3.1687	.2667	.1509	.2667	.1905	.2263	.1905
23	3.1687	.2667	.1886	.2286	.1905	.2641	.2667
24	3.315	3.131	.2667	.1886	.2667	.1905	.2641
Max	3.6969	3.5837	3.8104	3.3951	3.6961	3.5818	3.6969
Min	.2286	.1886	.1509	.1886	.1524	.1524	.1886
Avg	1.8282	1.0195	1.7528	1.5432	1.7041	1.6658	1.7041



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274104 / 33/11 KV TARAPUR

Feeder No / Name : 201 / 11 KV TARAPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.9907	1.0669	1.0822	1.6358	1.5242	2.0576
2	.1334	1.0155	1.0669	1.0974	1.6461	1.448	2.0576
3		1.0623	1.0686	1.1138	1.6556	1.448	2.0576
4		1.0669	1.1126	1.1279	1.7284	1.5242	2.0576
5		1.2955	1.1431	1.1431	1.7375	1.6766	2.1033
6		1.3717	1.2193	1.1883	1.7901	1.829	2.1338
7		1.3717	1.4043	1.3748	1.9997	2.1491	2.0576
8		1.2803	1.3889	1.3108	2.0309	2.0424	2.1491
9	1.4784						
10	1.448						
11	1.5242						
12	1.5546						
13	1.5242						
14	1.5242						
15	1.5242		.1143	.0762	.0762	.0572	.0762
16	1.5089	.0953	.1143	.0953	.0953	.1905	.0953
17	.0953	.0953	.1143	.1905	.0953	.1905	.1524
18	.1143	.1334	.1143	.1905	.1143	.1905	.1524
19	.1143	.0953	.1143	.1905	.1143	.2286	.2477
20	.1143	.0953	.1143	.1905	.1143	.2858	.2667
21	.0953	.0953	.1143	.1905	.0953	.2667	.2477
22	.0953	.0953	.0953	.1905	.0953	.2477	.2477
23	.4917	1.0669	1.0669	1.5394	1.5851	2.0576	1.7985
24	.0953	1.0936	1.0402	1.0669	1.6004	1.6004	2.0881
Max	1.5546	1.3717	1.4043	1.5394	2.0309	2.1491	2.1491
Min	.0953	.0953	.0953	.0762	.0762	.0572	.0762
Avg	.7528	.7247	.6930	.7422	1.0117	1.0532	1.2248

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274104 / 33/11 KV TARAPUR

Feeder No / Name : 202 / 11 KV KHARSOLI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1338	.1334	.1905	.1905	.1905	.1905	.2858
2	2.0576	.1524	.1905	.1905	.1905	.1905	.2858
3	1.9814						
4	2.1338						
5	2.3624						
6	2.3624						
8	2.4387						
9		2.1338	1.8747	1.5242	2.0119	2.1338	2.5149
10		2.3167	2.1948	1.6004	2.2862	2.5911	2.5149
11		2.21	2.21	1.5242	2.4387	2.8959	1.5242
12		2.1338	2.2862	1.6004	2.21	3.0178	2.5911
13		2.21	2.2558	1.6004	2.4387	2.7435	2.6673
14		2.2862	2.2558	1.5546	2.5149	2.713	2.9721
15	.1334		2.0576	1.6004	2.5149	2.8502	2.9721
16	.1334	2.572	2.1338	1.6004	2.5149	2.3472	2.8959
17	.1334	.1143	.1905	.0953	.0953	.1334	.0953
18	.1905	.1143	.1905	.1905	.1905	.1905	.1905
19	.1905	.1905	.1905	.1905	.1905	.2858	.2858
20	.1905	.1524	.1905	.1905	.1905	.2858	.2858
21	.1524	.1524	.1905	.1905	.1905	.2858	.2858
22	.1524	.1905	.1905	.1905	.1905	.2858	.2858
23	.1524	.1905	.1905	.1905	.1905	.2858	.2858
24	.6443	.1524	.1905	.1905	.1905	.1905	.2858
Max	2.4387	2.572	2.2862	1.6004	2.5149	3.0178	2.9721
Min	.1334	.1143	.1905	.0953	.0953	.1334	.0953
Avg	1.0320	1.0239	1.0652	.8008	1.1522	1.3121	1.2903

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274104 / 33/11 KV TARAPUR

Feeder No / Name : 203 / 11 KV MAGARWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	1.2193	1.6766	1.5546	1.6766	1.7528	1.7528
2	.0953	1.2193	1.6766	1.5851	1.7528	1.7528	1.7528
3		1.2193	1.7223	1.6156	1.829	1.829	1.829
4		1.2193	1.7528	1.6766	1.9052	1.9814	1.829
5		1.2955	1.829	1.7528	1.9814	1.9814	1.9052
6		1.3717		1.9509	2.0576	2.0576	1.9814
7		1.5242	2.1643	2.0881	2.0881	2.1338	1.9814
8		1.829	2.2253	2.1338	2.21	2.1338	1.9814
9	1.9814						
10	2.21						
11	2.21						
12	2.2862						
13	2.1338						
14	2.1338						
15	2.1338		.0953	.0953	.0953	.0953	.0953
16	2.0576	.0953	.0953	.0953	.0953	.0953	.0953
17	.0953	.0953	.0953	.0953	.0953	.0953	.0953
18	.0953	.0953	.0953	.0953	.0953	.0953	.0953
19	.0953	.0953	.0953	.0953	.0953	.0953	.0953
20	.0953	.0953	.0953	.0953	.0953	.0953	.0953
21	.0953	.0953	.0953	.0953	.0953	.0953	.0953
22	.0953	.0953	.0953	.0953	.0953	.0953	.0953
23	1.2955	1.6766		1.6461	1.6766	1.6766	1.6766
24	.4917	1.2955	1.6766	1.5242	1.6766	1.7528	1.7528
Max	2.2862	1.829	2.2253	2.1338	2.21	2.1338	1.9814
Min	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Avg	1.0942	.8551	.9679	1.0161	1.0898	1.1008	1.0669

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274104 / 33/11 KV TARAPUR

Feeder No / Name : 204 / Tarapur Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2286	.2286	.2286	.2286	.2286	.2439
2	.2591	.3048	.2591	.2286	.2591	.2591	.2439
3	.3201	.3353	.2896	.2591	.2896	.2743	.2743
4	.3201	.3353	.3201	.2896	.3353	.3506	.3048
5	.3506	.3506	.3658	.381	.381	.3506	.381
6	.4268	.4268	.3963	.4268	.4268	.4268	.4268
7	.381	.3048	.4115	.381	.381	.381	.3658
8		.2591	.3048	.3048	.3048	.3048	.3048
9	.2591	.2286	.2286	.2286	.2286	.2286	.2743
10	.2286	.1829	.1829	.1981	.1981	.2286	.2286
11	.1677	.1677	.1677	.1677	.1677	.1981	.1981
12	.1677	.1677	.1677	.1677	.1677		.1829
13	.1524	.1524	.1524	.1677	.1524	.1524	.1677
14	.1677	.1524	.1524	.1524	2.5149	.1829	.1524
15	.1677		.1677	.1677	.1677	.1981	.1677
16	.1829	.1981	.1829	.1981	.1981	.2286	.1981
17	.2591	.2286	.2286	.2286	.2286	.2286	.2286
18	.3048	.2743	.3048	.2591	.2286	.2591	.2591
19	.381	.381	.381	.381	.3506	.3048	.3201
20	.4268	.4115	.4268	.4268	.381	.3963	.4115
21	.3506	.381	.381	.381	.3353	.3658	.381
22	.3048	.3048	.3048	.3048	.3048	.3048	.3048
23	.2591	.2286	.2286	.2286	.2286	.2743	.2743
24	.6613	.2286	.2286	.2286	.2286	.2286	.2591
Max	.6613	.4268	.4268	.4268	2.5149	.4268	.4268
Min	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Avg	.2925	.2710	.2693	.2661	.3620	.2763	.2731

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274104 / 33/11 KV TARAPUR

Feeder No / Name : 206 / 11 KV SUSTE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.1739	.2896	.1829	.2286	.2439	
2	.0381	.1562	.2623	.1829	.2439	.2439	
3		.1406	.2378	.1783	.2469	.2286	
4		.1406	.2559	.1829	.2286	.2286	
5		.1562	.2591	.1829	.2286	.2591	
6		.1829	.2591	.216	.2315	.2743	
7		.2591	.2778	.2656	.2656	.3201	
8		.3125	.2932	.3241	.2932	.3201	
9	.2896						
10	.3239						.2439
11	.3077						
12	.3239						
13	.3201						
14	.2896						
15	.2896		.0381	.0191	.0191	.0191	.0191
16	.2812	.0572	.0381	.0191	.0191	.0191	.0191
17	.0381	.0572	.0572	.0191	.0191	.0191	.0191
18	.0572	.0572	.0572	.0191	.0191	.0381	.0191
19	.0572	.0572	.0572	.0381	.0191	.0381	.0191
20	.0572	.0381	.0572	.0191	.0191	.0381	.0191
21	.0381	.0381	.0381	.0191	.0191	.0381	.0191
22	.0381	.0381	.0381	.0191	.0191	.0381	.0191
23	.1406	.2896	.1829	.2286	.2743		.2743
24	.0381	.1718	.3048	.1829	.2286	.2591	
Max	.3239	.3125	.3048	.3241	.2932	.3201	.2743
Min	.0381	.0381	.0381	.0191	.0191	.0191	.0191
Avg	.1648	.1369	.1669	.1277	.1457	.1544	.0671

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274104 / 33/11 KV TARAPUR

Feeder No / Name : 207 / 11 KV GANESH

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.5792	.6097	.6097	.6859	.6859	.6097
2	.0572	.5792	.6097	.6097	.6859	.6859	.6097
3		.5335	.6097	.6097	.6859	.6859	.6097
4		.5335	.6097	.6097	.6859	.7316	.6097
5		.6097	.6097	.6401	.6859	.7316	.6859
6		.6097		.6859	.7316	.7621	.6859
7		.6859	.8383	.7926	.7621	.7621	.6859
8		.7621	.7926	.8383	.7926	.7621	.6859
9	.7621						
10	.7621						
11	.7621						
12	.8383					.1524	
13	.7621						
14	.6859						
15	.6859		.0572	.0572	.0572	.0572	.0572
16	.6859	.0572	.0572	.0572	.0572	.0572	.0572
17	.0572	.0572	.0572	.0572	.0572	.0572	.0572
18	.0572	.0572	.0572	.0572	.0572	.0572	.0572
19	.0572	.0572	.0572	.0572	.0572	.0572	.0572
20	.0572	.0572	.0572	.0572	.0572	.0572	.0572
21	.0572	.0572	.0572	.0572	.0572	.0572	.0572
22	.0572	.0572	.0572	.0572	.0572	.0572	.0572
23	.6554	.6097	.6097	.6859	.6859	.6097	.6097
24	.4917	.6554	.6097	.6097	.6859	.6859	.6097
Max	.8383	.7621	.8383	.8383	.7926	.7621	.6859
Min	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Avg	.4194	.3858	.3739	.3972	.4192	.4059	.3811

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274119 / 33/11 KV DEGAON

Feeder No / Name : 201 / 11 KV DEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7068	.8402	.6097	.9431	.8535	.9116	.8688
2	.7068	.8573	.6859	.9602	.8535	.9282	.8688
3	.7468	.8916	.9431	.9602	.884	.9614	.8993
4	.8269	.9774	1.0631	.9945	.945	1.0288	.945
5	.9736	1.0117	1.1831	1.046	1.0669	1.0749	1.0212
6	1.0802	1.2346	1.286	1.3203	1.2498	1.2309	1.2003
7	1.0002	1.4232	1.387	1.5939	1.3413	1.406	1.387
8	.8535	1.2193	1.3717	1.6095	1.3413	1.5091	1.2803
9	1.1126	.5601	.6135	.6268	.639	.7335	.6001
10	1.1888	.5335	.4001	.4268	.4108	.7335	.4841
11	1.2193	.4134	.3734	.4268	.4199	.4268	.5281
12	1.1584	.2934	.3734	.3734	.4161	.3601	.4755
13	1.1584	.3734	.3467	.3601	.4199	.3734	.4548
14	1.0822	.3734		.3334	.4108	.3868	.5053
15	1.3108	.3601	.3467	.3734	.3909	.4134	.4755
16	.823	.4401	.3734	.3868	.4923	.4534	.5424
17	.4001	.4934	.3067	.4534	.5075	.5201	.5573
18	.5735	.064	.5647	.5735	.3567	.6135	.5573
19	.7735	.7602		.7735	.8109	.7602	.6805
20	.9469	.9202	1.0084	.9335	.9934	.9069	.9362
21	.8935	.8135	.9934	.8935	.9783	.8269	.8768
22	.7868	.7735	.8655	.7735	.8768	.7735	.8429
23	.8402	.9259	.9602	.8535	.8951	.8688	.9326
24	.7068	.8402	.8383	.9431	.8535	.9116	.8688
Max	1.3108	1.4232	1.387	1.6095	1.3413	1.5091	1.387
Min	.4001	.064	.3067	.3334	.3567	.3601	.4548
Avg	.9112	.7247	.7679	.7889	.7670	.7964	.7829

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274119 / 33/11 KV DEGAON

Feeder No / Name : 202 / 11 KV ADHIV

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0364	.4115	.4572	.4031	.3944	.407	.463
2	1.0364	.4287	.3658	.4207	.3944	.407	.463
3	1.0364	.4287	.3658	.4557	.4287	.4239	.4801
4	1.0974	.4458	.4115	.4973	.4801	.4748	.5144
5	1.1431	.442	.4572	.5144	.5487	.5316	.5487
6	1.4632	.703	.6859	.6687	.6516	.6613	.6859
7	1.768	.6687	.7202	.6344	.6859	.7455	.6687
8	1.5394	.5487	.5658	.5243	.4801	.6068	.5144
9	.4115	1.6004	1.4937	1.5242	1.5779	1.6613	1.5844
10	.3086	1.6461	1.5546	1.5546	1.4022	1.7528	1.8884
11	.3086	1.9204	1.6918	1.5851	1.692	1.8747	1.8244
12	.3086	1.6766	1.6004	1.4937	1.6004	1.6613	1.8623
13	.3086	1.7985	1.5699	1.5394	1.6091	1.6613	1.7375
14	.2915	1.829	1.4022	1.5242	1.6716	1.8747	1.7497
15	.2915	1.8595	1.3565	1.5699	1.7604	1.6766	1.7394
16	.2572	1.6004	1.448	1.6004	1.7814	1.7528	1.448
17	.3258	.823	.2915	.3086	.362	.3429	.3224
18	.3601	.6516	.362		.3761	.3772	.2896
19	.5487	.5144	.5138	.583	.5201	.5144	.4252
20	.6687	.6859	.6135	.6859	.6344	.5487	.6068
21	.6516	.6173	.5959	.6173	.5784	.5487	.5548
22	.6001	.5316	.5083	.4801	.4961	.5658	.5258
23	.4287	.381	.4031	.3944	.4239	.463	.407
24	1.0364	.4115	.3658	.4031	.3944	.407	.463
Max	1.768	1.9204	1.6918	1.6004	1.7814	1.8747	1.8884
Min	.2572	.381	.2915	.3086	.362	.3429	.2896
Avg	.7178	.9427	.8250	.8688	.8727	.9142	.9070



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274119 / 33/11 KV DEGAON

Feeder No / Name : 203 / 11 KV AJANSOND

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	1.0059	1.2651	1.1633	1.0669	1.21	1.2193
2	.0191	1.0059	1.2651	1.1797	1.0669	1.2266	1.2193
3	.0191	.823	1.2651	1.1797	1.0669	1.2431	1.2498
4	.0191	.8535	1.2651	1.2266	1.2498	1.2597	1.2803
5	.0191	.8688	1.2955	1.2597	1.5242	1.3094	1.3413
6	.0191	1.2498	1.5546	1.5927	1.7071	1.6766	1.5851
7	.0191	1.3717	1.8747	1.9448	1.8442	1.8442	1.8747
8	.0191	1.3413	1.8747	1.8945	1.8747	1.8896	1.5851
9	1.5089	.0191	.0191	.0191	.0191	.0191	.0191
10	1.5089	.0191	.0191	.0191	.0191	.0191	.0191
11	1.6766	.0191	.0191	.0191	.0191	.0191	.0191
12	1.7375	.0191	.0191	.0191	.0191	.0191	.0191
13	1.5546	.0191	.0191	.0191	.0191	.0191	.0191
14	1.5089	.0191	.0191	.0191	.0191	.0191	.0191
15	1.5775	.0191	.0191	.0191	.0191	.0191	.0191
16	1.1431	.0191	.0191	.0191	.0191	.0191	.0191
17	.0191	.0191	.0191	.0191	.0191	.0191	.0191
18	.0191	.0191	.0191	.0191	.0191	.0191	.0191
19	.0191	.0191		.0191	.0191	.0191	.0191
20	.0191	.0191	.0191	.0191	.0191	.0191	.0191
21	.0191	.0191	.0191	.0191	.0191	.0191	.0191
22	.0191	.0191	.0191	.0191	.0191	.0191	.0191
23	1.0364	1.1584	1.1469	1.0669	1.278	1.2041	1.1305
24	.0191	1.0212	1.2346	1.1633	1.0669	1.21	1.2193
Max	1.7375	1.3717	1.8747	1.9448	1.8747	1.8896	1.8747
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.5641	.4570	.6213	.5808	.5839	.5975	.5822

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274119 / 33/11 KV DEGAON

Feeder No / Name : 204 / 11 KV S.Dumala

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.4973	.583	.5373	.5144	.5493	.5658
2	.5487	.4973	.583	.5552	.5144	.567	.5658
3	.5792	.5316	.6516	.591	.5487	.567	.6001
4	.6097	.6001	.6859	.6556	.583	.631	.6344
5	.6706	.6516	.7202	.7108	.6173	.6935	.6859
6	.7468	.7202	.823	.7455	.6859	.7373	.7202
7	.8535	.703	.7202	.631	.7545	.6415	.6516
8	.7926	.5658	.5316	.567	.5487	.5895	.5487
9	.4115	.6859	.823	.6173	.6935	.7545	.8048
10	.3772	.7202	.823		.7108	.823	.8886
11	.3086	.9774	.9088	.6859	.7802	.823	.8551
12	.3944	.8573	.8916	.7545	.8495	.8745	.9054
13	.3944	.6687	.9259	.8059	.8495	.3429	.9054
14	.3944	.7888	.8916	.7373	.7975	.8573	.8718
15	.3772	.823	.8745	.7202	.8322	.9088	.8886
16	.4287	.7202		.6554	.8669	.9259	.8718
17	.4115	.3772		.3429	.3761	.3772	.4298
18	.4801		.4477	.4115	.4298	.3944	.4298
19	.6001	.5144	.6201	.5487	.6201	.5658	.5316
20	.7716		.6733	.6516	.7186	.583	.7108
21	.7373	.7202	.6024	.583	.6661	.583	.6762
22	.6516	.703	.5552	.5487	.5847	.583	.5959
23	.5487	.583	.5552	.5144	.5847	.5658	.5784
24	.5487	.5144	.583	.5373	.5144	.5493	.5658
Max	.8535	.9774	.9259	.8059	.8669	.9259	.9054
Min	.3086	.3772	.4477	.3429	.3761	.3429	.4298
Avg	.5494	.6555	.7034	.6134	.6517	.6453	.6868

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274119 / 33/11 KV DEGAON

Feeder No / Name : 205 / 65 ACRE GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2229	.2229	.2686	.2572	.2629	.3258
2	.2401	.2401	.2229	.2686	.2572	.2629	.3258
3	.2572	.2915	.2572	.3012	.2572	.2804	.3258
4	.2915	.3086	.2572	.3189	.2743	.2947	.3429
5	.3258	.3086	.2743	.3366	.3086	.3121	.3429
9	.2667	.1715	.2058	.1886	.2629	.2915	.2534
10	.3429	.2058	.2229	.2058	.2804	.2229	.1991
11	.3086		.2572	.2572	.2804	.2572	.2172
12	.2743	.12	.3258	.2229	.2454	.2229	.1991
13	.2401	.2229	.2743	.2229	.2629	.2743	.2172
14	.2229	.2401	.2572	.2058	.298	.2743	.2534
15	.2058	.2572	.2743	.1715	.2103	.2401	.2172
16	.2058	.2058		.1715	.2279	.2058	.181
17	.2229	.1886	.2715	.2229	.2454	.2743	.181
18	.2229	.1886	.2507	.2401	.2454	.2229	.181
19	.1715	.2058	.3012	.2572	.2454	.2743	.1991
20	.3086		.3189	.2743	.2947	.3258	.2804
21	.2743	.2915	.3012	.2915	.2774	.3258	.2629
22	.2572	.3086	.3012	.2743	.2774	.3429	.2629
23	.2401	.2572	.2686	.2743	.2629	.3258	.2629
24	.2401	.1886	.2229	.2686	.2572	.2629	.3258
Max	.3429	.3086	.3258	.3366	.3086	.3429	.3429
Min	.1715	.12	.2058	.1715	.2103	.2058	.181
Avg	.2552	.2328	.2644	.2497	.2633	.2741	.2551

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274120 / 33/11 KV BHOSE

Feeder No / Name : 201 / 11 KV PEHE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0152	.3429	.4801	.3353		.3429	.3048
2	.0152	.3429	.4287	.3353		.3429	.3353
3	.0152	.3601	.463	.3658		.3772	.3353
4	.0152	.4115	.463	.3658		.4287	.3506
5		.4115	.4973	.4268		.4287	.4268
6		.463	.4973	.4572		.4458	.4725
7		.463	.5144	.503		.583	.5487
8		.463	.4973	.503		.5487	.5182
9	.463						
10	.463						
11	.5144						
12	.5144						
13	.5144						
14	.5487						
15	.5487	.0343	.0305	.0343		.0305	.0343
16	.4287	.0343		.0343	.0171	.0305	.0343
17		.0171	.0305	.0343	.0171	.0305	.0343
18		.0171	.0305	.0343	.0171	.0305	.0343
19	.0171	.0343	.0305	.0343	.0171	.0305	.0343
20	.0171	.0343	.0457	.0514	.0171	.0305	.0343
21	.0171	.0343	.0457	.0514	.0171	.0305	.0343
22	.0171	.0343	.0305	.0343	.0171	.0152	.0171
23	.0171	.0343	.0305	.0343	.0171	.0152	.0343
24	.0152	.0171	.0171	.0305		.0171	.0305
Max	.5487	.463	.5144	.503	.0171	.583	.5487
Min	.0152	.0171	.0171	.0305	.0171	.0152	.0171
Avg	.2309	.1972	.2431	.2036	.0171	.2088	.2008

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274120 / 33/11 KV BHOSE

Feeder No / Name : 202 / 11 KV SUGAON BHOSE  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	1.7147	2.8292	2.0119		2.6406	1.9814
2	.3048	2.0576	2.7778	2.0119		2.5549	1.9814
3	.3201	2.4006	1.829	2.0424		2.572	2.0424
4	.3201	2.4006	2.7435	2.0424		2.6063	2.0424
5		2.572	2.8292	2.3624		2.7435	2.4006
6		2.7435	2.8464	2.5149		2.8121	2.5206
7		2.8292	3.3608	2.9492		2.915	2.5911
8		2.8464	3.0864	2.7435		2.7435	2.8635
9	3.1379	2.8464					
10	3.155						
11	2.9321						
12	2.9321						
13	2.9835						
14	2.9492						
15	2.915	.2572	.1219	.1543	.1715	.1524	.1715
16	2.8121	.2915	.1524	.1715	.2058	.1677	.1715
17		.2572	.1524	.2058	.2058	.1372	.2058
18		.2572	.1829	.2058	.3429	.1677	.2743
19	.3772	.3772	.3048	.3429	.3601	.3048	.3429
20	.3944	.3429	.3506	.3944	.3429	.3506	.4115
21	.3944	.3086	.3658		.3258	.3353	.3772
22	.3258	.3258	.3048		.2915	.2896	.3429
23	.3086	.2915	.2286	.4115	.2572	.2591	.3258
24	.2896	.3258	.2915	.2439		.2572	.2439
Max	3.155	2.8464	3.3608	2.9492	.3601	2.915	2.8635
Min	.2896	.2572	.1219	.1543	.1715	.1372	.1715
Avg	1.5087	1.3393	1.3754	1.3005	.2782	1.3339	1.1828

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274120 / 33/11 KV BHOSE

Feeder No / Name : 203 / 11 KV BHOSE GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.3086	.3258	.2743		.3258	.3048
2	.3048	.3258	.3258	.2743		.3258	.3429
3	.3048	.3429	.3429	.3048		.3429	.3353
4	.3506		.4287	.3353		.4287	.3353
5	.4268		.4801	.3963		.4801	.3658
6	.442	.4801	.5487	.4572		.5316	.4801
7	.4572	.4458	.4973	.3963		.4458	.4268
8	.3506	.4115	.3944	.3048		.3772	.3086
9	.2743	.3429	.3048	.3086	.2743	.3048	.3086
10	.2401	.2915	.2896	.2401	.2401	.2286	.2572
11	.2058	.2572	.1981	.2058	.2229	.1677	.2401
12		.2229	.1524	.1715	.1715	.1829	.2229
13	.2058	.2229	.1524	.1372	.1715	.1829	.2058
14	.2058	.2058	.1372	.1372	.1372	.1524	
15	.1715	.2058	.1524	.1715	.1543	.1524	.1715
16	.2401	.2229	.1524	.1715	.1715	.2134	.2229
17	.2915	.3086	.2439	.2743	.2572	.2134	
18	.3086	.3772	.2896	.3258	.4115	.2743	
19	.3429	.4458	.2439	.2743	.4801	.4268	.4801
20	.4287	.4115	.3658	.4115	.4287	.4725	.5487
21	.4801	.3601	.4268	.4115	.3429	.4572	.5144
22	.3258	.3429	.3048	.3429	.3258	.3658	.4287
23	.3086	.3086	.2439	.3086	.3086	.2743	.3086
24	.2743	.3086	.3086	.2439		.2572	.2743
Max	.4801	.4801	.5487	.4572	.4801	.5316	.5487
Min	.1715	.2058	.1372	.1372	.1372	.1524	.1715
Avg	.3137	.3250	.3046	.2866	.2732	.3160	.3373

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274120 / 33/11 KV BHOSE

Feeder No / Name : 204 / 11 KV Sol Patti Feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9052		.2229	.1829	.2229	.2058	.2058
2	1.9052		.2058	.1829	.2229	.2229	.1829
3	1.9357		.2058	.2134	.2572	.2058	.2286
4	1.9509		.2401	.2134	.2572	.2058	.2286
5	2.4082		.2572	.2134	.2401	.2572	.2743
6	2.4691		.2743	.2134	.2401	.2915	.3048
7	2.6673						
8	2.8197						
13					.1372	.1219	.2058
14		.2058			.1372	.1829	.2572
15	.1715	.2572	.1524	.1715	.1715	.1829	.2401
16	.1886	.3086	.1524	.1886	.2058	.2134	.2401
17	.2058	3.3265	3.0483	3.4637	3.5322	2.5911	3.0864
18	.2743	3.6008	2.8197	3.4637	3.5494	3.3836	3.7723
19		3.7551	2.652	3.2579	3.5665	2.9721	3.3951
20		3.7209	2.652	3.2236	3.3951	2.7892	3.155
21		3.5322	2.5911	3.0864	3.155	2.7435	3.1036
22		3.155	2.4387	2.7435	3.0178	2.5911	2.915
23		2.8978	2.3624	2.6578	2.6749	2.4539	2.7778
24			2.7949	2.3015	2.6578	2.5892	2.3777
Max	2.8197	3.7551	3.0483	3.4637	3.5665	3.3836	3.7723
Min	.1715	.2058	.1524	.1715	.1372	.1219	.1829
Avg	1.5751	2.4760	1.4419	1.6111	1.5356	1.3447	1.4973

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274120 / 33/11 KV BHOSE

Feeder No / Name : 205 / 11 KV Nematwadi Feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1715	.2058	.1524		.1886	.1524
2	.1524	.1715	.1886	.1715		.2058	.1524
3	.1524	.1715	.2058	.1372		.1886	.1715
4	.1524		.2058	.1372		.1886	.1715
5	.1677						
6	.1677						
9		2.0576	1.829	1.6461	1.8519	1.9052	2.1605
10		1.9719	1.8595	1.6461	1.8004	1.9509	2.2119
11		1.8861	1.8595	1.8861	1.7661	1.829	2.0576
12		1.7661	1.7985	1.8861	1.7833	1.829	2.0748
13	.1543	1.7833	1.7528	1.749	1.7661	1.9052	2.0576
14	.1372	1.7661	1.4784	1.7318	1.8004	1.7375	2.0576
15	.1543	1.6975	1.5546	1.7661	1.8176	1.7528	2.0576
16	.1715	1.6461	1.5851	1.7833	1.8347	1.768	2.0748
17	1.9719						
18	1.8004						
19	1.8861	.1886	.1829		.1543	.1524	.1715
20	1.8861	.2058	.1829		.1715	.1677	.1886
21	1.8861	.1886	.1829		.1715	.1677	.1886
22	1.8347	.1715	.1524		.1543	.1524	.1715
23	1.8004	.1715	.1372		.1715	.1524	.1715
24	1.4632	1.6804	.1886	.1524		.1886	.1677
Max	1.9719	2.0576	1.8595	1.8861	1.8519	1.9509	2.2119
Min	.1372	.1715	.1372	.1372	.1543	.1524	.1524
Avg	.8940	1.0409	.8639	1.1419	1.1726	.9128	1.0255



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274139 / 33/ 11 Kv Shankargaon

Feeder No / Name : 201 / 11 Kv NALI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.17	.1905	.2858	.2286	.2286		
2	1.17	.1905	.2858	.2286	.2286		
3	1.4752						
4	1.5261						
5	1.5261						
6	1.5769						
7	1.6787						
8	1.5261						
9		1.6278	1.7804	1.4861		1.7101	2.6155
10		1.5769	1.8821	1.3413	1.3923		2.5987
11		1.5261	1.5769	1.4752			2.5232
12		1.5261	1.5769	1.5238			2.536
13		1.5261	1.5261	1.5415			2.5987
14		1.5261	1.5261	1.5592			2.5526
15	.1524	1.543	1.5261	1.5415			2.556
16	.1334	1.3735	1.5261	1.5424			2.1795
17	.1715	.2286	.2286	.1905			.2667
18	.1905	.2667		.2286			.3429
19	.2096	.2667	.1905	.2858			.381
20	.2667	.2667	.3048	.2858			.381
21	.2286	.2096	.2667	.3048			.381
22	.2286	.2286	.2667	.3048		.1905	.381
23	.2096	.1905	.2667	.2286	.1905	.2096	.381
24	1.1361	.1905	.2286	.2286	.2286	.1905	.2096
Max	1.6787	1.6278	1.8821	1.5592	1.3923	1.7101	2.6155
Min	.1334	.1905	.1905	.1905	.1905	.1905	.2096
Avg	.8098	.8030	.8968	.8070	.4537	.5752	1.4303

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274139 / 33/ 11 Kv Shankargaon

Feeder No / Name : 202 / 11 Kv AMBE CHINCHOLI SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8139	1.8652	1.4918	1.8143	1.1568		
2	.823	1.8143	1.5415	1.8143	1.1437		
3		1.8313	1.5415	1.6787	1.1469		
4		1.8482	1.4918	1.7804	1.2266		
5		1.8652	1.6244	1.8652	1.2452		
6		1.933	1.6409	1.933	1.3923		
7		2.1874		1.933	1.4091		
8		2.2891	1.989	1.9669	1.643	2.1879	2.649
9	2.2891						
10	2.2721						
11	2.3908						
12	2.3569						
13	2.2721						
14	2.2721						
15	2.4874	.5525	.6287	.4572			1.0288
16	2.1874		.8002	.4763			1.105
17	.5487	.6859		.4382			1.0669
18	.5731	.7865		.4001			1.0669
19	.6154	.8413	.6401	.381			1.0479
20	.6697	.7682	.8048	.3429			1.0288
21	.5784	.7316	.7316	.3239			1.0098
22	1.8652	.6287	.7316	.3239		1.0479	1.0479
23	1.8652	1.4586	1.7126	1.1568	1.1934	1.5089	2.3205
24	.8596	1.8821	1.4752	1.7804	1.1437	1.4918	1.6095
Max	2.4874	2.2891	1.989	1.9669	1.643	2.1879	2.649
Min	.5487	.5525	.6287	.3239	1.1437	1.0479	1.0098
Avg	1.5411	1.4099	1.2564	1.1593	1.2701	1.5591	1.3619

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274139 / 33/ 11 Kv Shankargaon

Feeder No / Name : 203 / 11 Kv JACKWELL  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.8145
Max	.8145
Min	.8145
Avg	.8145

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274148 / 33/11 Kv Puluji

Feeder No / Name : 201 / 11 Kv Kalamal

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.2883
Max	.2883
Min	.2883
Avg	.2883

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274148 / 33/11 Kv Puluoj

Feeder No / Name : 202 / 11 Kv Fulchincholi  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.3077
Max	.3077
Min	.3077
Avg	.3077

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274148 / 33/11 Kv Puluji

Feeder No / Name : 203 / 11 Kv Puluji Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-AUG-17
HR	Load (MW)
24	.805
Max	.805
Min	.805
Avg	.805

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274148 / 33/11 Kv PuluJ

Feeder No / Name : 204 / 11 kv PULUJ  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.6093
Max	.6093
Min	.6093
Avg	.6093

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274148 / 33/11 Kv Puluji

Feeder No / Name : 205 / 11 KV VITE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.4917
Max	.4917
Min	.4917
Avg	.4917



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274164 / 33/11 KV Nandure

Feeder No / Name : 201 / 11 kv Nanure Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1867	.2054	.2054	.2054	.1867	.2241
2	.1867	.1867	.2241	.2054	.2054	.1867	.2241
3	.1867	.2241	.2614	.2054	.2054	.2054	.2427
4	.2054	.2614	.2614	.2054	.2987	.2054	.2801
5	.2241	.2987	.2987	.2427	.2987	.2241	.3361
6	.2614	.3174	.3361	.2614	.3361	.2241	.3547
7	.2987	.3174	.3361	.2801	.3361	.2987	.3174
8	.2987	.2054	.3361	.2801	.2614	.2987	.2801
9	.2987	.2801	.2801	.2427	.2801	.2241	.2427
10		.2427	.2241	.2054	.3174	.1867	.2241
11	.2054	.1494	.168	.2054	.1494	.1307	.2054
12	.1867	.1494	.1494	.1867	.1494	.1494	.168
13	.1494	.1307	.1307	.168	.112	.1307	.168
14	.1494	.1307	.112	.168	.112		.168
15	.168	.1307	.112	.168	.112	.1307	.168
16		.1494		.168	.1307	.1494	.1867
17		.2054	.1494	.168	.2054	.168	.1848
18	.2427	.2614	.2054	.168	.2614	.1867	.2033
19	.2987	.2987	.2801	.2054	.3174		.2402
20	.3174	.3547	.2801	.2241	.3174	.3361	.2587
21	.2987	.2987	.2241	.2427	.2987	.2987	.2772
22	.2427	.2427		.2427	.2241	.2427	.2402
23	.2241	.2054	.2054	.2427	.1867	.2054	.2033
24	.4973	.1867	.2054	.2054	.2054	.1867	.2054
Max	.4973	.3547	.3361	.2801	.3361	.3361	.3547
Min	.1494	.1307	.112	.168	.112	.1307	.168
Avg	.2442	.2256	.2266	.2124	.2303	.2071	.2335

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274164 / 33/11 KV Nandure

Feeder No / Name : 202 / 11 KV Pehe

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9662	1.8023	.213	.1966	.1966	.1989	.213
2	1.9662	1.7859	.213	.1966	.1802	.1823	.213
3	1.9662	1.8023					
4	1.9662						
5	1.9662						
6	1.9662						
7	1.9989						
8	1.9989						
9			1.5893	2.4577	2.7035	2.7846	2.7199
10			1.7859	2.556	3.2606	3.1824	2.9165
11			2.2119	2.5888	2.8509	2.9835	2.9001
12			2.2447	2.6216	2.8673	2.967	2.8346
13		2.0481	2.3102	2.6216	2.8673	2.9007	2.8018
14		2.13	2.4249	2.6543	2.9656	2.9172	2.8018
15		2.13	2.4741	2.6543	2.9492	2.9172	2.6052
16		2.0809	2.5232	2.6871	2.9492	2.9172	2.5888
17		.0983	.0983		.1638		.1147
18		.1638	.1311		.1638		.1326
19	.0655	.1966	.1638	.1638	.1802		.1823
20	.0819	.2458	.1966	.1966	.213	.1966	.1989
21	.0819	.213	.2294	.1966	.1966	.213	.2155
22	.0819	.213	.2294	.1966	.2294	.213	.2155
23	1.7368	.213	.213	.1966	.2294	.1966	.2155
24	.3222	1.8023	.213	.213	.1966	.1989	.2294
Max	1.9989	2.13	2.5232	2.6871	3.2606	3.1824	2.9165
Min	.0655	.0983	.0983	.1638	.1638	.1823	.1147
Avg	1.2975	1.1284	1.0814	1.3999	1.4091	1.6646	1.3388

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274164 / 33/11 KV Nandure

Feeder No / Name : 203 / 11 KV Ave

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1739	.1265	1.9204	1.9766	1.9134	1.9292	2.0715
2	.1739	.1265	1.9204	1.9766	1.9134	1.9292	2.0557
3			1.9044	1.9766	1.9134	1.9766	2.0241
4		2.5301	1.8884	1.9766	1.9134	2.0557	2.0241
5		2.5301	1.8884	2.0083	1.9134	2.2455	2.0873
6		2.5301	1.9204	2.0083	1.9766	2.3245	2.3403
7		2.5775	2.0805	2.0557	2.0557	2.3087	2.4827
8		2.7357	2.1125	2.0557	2.119		2.4669
9	2.4036	2.6566					.1107
10	2.4985	2.625					
11	2.5301	2.5617					
12		2.4806					
13	2.5301						
14	2.7673						
15	2.7831		.1107	.0949	.2214		.1107
16			.1107	.0949	.0633		.1107
17			.1423	.0949	.0791		.1265
18	.1265		.1423		.1107		.1423
19	.1423	.064	.1581	.0949	.1739		.1581
20	.1581	.192	.1581	.1423	.1739	.1423	.1581
21	.1739	.176	.1739	.1423	.1107		.1581
22	.1739	.112	.1739	.1423	.1107	.1265	.1581
23	.1423	1.8564	1.866	1.9608	1.9766	1.9292	1.9608
24	.1739	.1423	1.9364	1.9134	1.9134	1.9766	2.0715
Max	2.7831	2.7357	2.1125	2.0557	2.119	2.3245	2.4827
Min	.1265	.064	.1107	.0949	.0633	.1265	.1107
Avg	1.1301	1.5308	1.1449	1.2185	1.1473	1.7222	1.2010

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274174 / 33/11 KV Shevate Sub Station

Feeder No / Name : 201 / 11 KV Shevate Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0953	.0914	.0686	.0686	.0514	.0686
2		.0572	.0914	.0686	.0857	.0686	.0686
3	.0686	.0762	.1067	.0686	.0857	.0857	.0686
4	.061	.0572	.0914	.0857	.0857	.0686	.0686
5	.0762	.0953	.0914	.1029	.0857	.0514	.0857
6	.0914	.0762	.1067	.1029	.12	.0686	.12
7	.0914	.0953	.1219	.1372	.1372	.1029	.1543
8	.1219	.1524	.1524	.1372	.1067	.0857	.1543
9	.1143	.1524	.1219	.1543	.1715	.0857	.1029
10	.2858	.1829	.2401	.2591	.4001	.1715	.2058
11	.3239	.2134	.2572	.2915	.362	.2058	.3086
12	.3048	.1829	.3086	.2439	.381	.2572	.2743
13	.2667	.2134	.2743	.2915	.4191	.2572	
14	.2477	.2134	.1029	.2896	.2858	.2058	.1372
15	.3239	.2439	.12	.3258	.4191	.1543	.1715
16	.2286	.2743	.3258	.2743	.2096	.12	.2058
17	.1715	.2439	.3086	.2286	.3048	.0686	.1715
18	.1334	.1981	.2743	.2229	.2667	.0686	.1886
19	.1524	.1829	.1372	.1524	.2286	.0686	.1886
20	.1905	.1829	.1029	.1372	.1905	.1029	.1715
21	.1715	.1524	.0857	.1219	.1143	.1029	.1372
22	.0953	.1524	.0857	.061	.0762	.0857	.12
23	.0762	.1219	.0686	.0686	.0857	.0857	.12
24	.0514	.0572	.1067	.0686	.0686	.0686	.0857
Max	.3239	.2743	.3258	.3258	.4191	.2572	.3086
Min	.0514	.0572	.0686	.061	.0686	.0514	.0686
Avg	.1609	.1531	.1572	.1651	.1983	.1122	.1469

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274174 / 33/11 KV Shevate Sub Station

Feeder No / Name : 202 / 11 KV Shevate AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3944	.3429	1.7604	2.2024	2.7092	2.7206	3.1579
2	.3944	.381	1.7871	2.2024	2.4387	2.753	3.1579
3		2.7625	1.7604	2.2024	2.4996	2.834	3.1579
4		2.8959	1.8404	2.2996	2.5453	2.9797	3.1579
5		2.8197	1.8404	2.3967	2.915	2.915	3.2065
6		3.0102	1.8138		2.9264	3.2065	3.2712
7		2.8769	1.8938			3.2388	3.1579
8		2.9531	2.1605			3.1417	3.2388
9	2.9912	2.8006					
10	3.1817	2.0005					
11	3.2388	2.0271					
12	3.1817						
13	3.1436						
14	3.0864						
15	2.9531		.1715			.1029	.2401
16	2.934		.1715			.1715	.2401
17	.3048		.1886			.2401	.2058
18	.3239	.1067	.2229			.3086	.2401
19	.3429	.1334	.2743		.1905	.3772	.2401
20	.362	.1867	.2743	.1829	.2667	.3772	.2058
21	.381	.1867	.2572	.2134	.2096	.3601	.2401
22	.381	.1867	.2572	.2286	.2286	.3086	.2401
23	.3239	1.6804	2.1052	2.3624	2.9959	2.9959	2.6558
24	.3429	.362	1.7337	2.2024	2.7092	3.0445	3.1093
Max	3.2388	3.0102	2.1605	2.3967	2.9959	3.2388	3.2712
Min	.3048	.1067	.1715	.1829	.1905	.1029	.2058
Avg	1.5701	1.5396	1.1396	1.6493	1.8862	1.7820	1.8402

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274174 / 33/11 KV Shevate Sub Station

Feeder No / Name : 203 / Ulabhagat Mala

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0631	1.3146	.16	.2572		.2229	.2572
2	.945	1.467	.16	.2572	.2591	.2572	.2572
3	1.1145						
4	1.0212						
5	1.0669						
6	1.7528						
7	2.1338						
8	2.0881						
9		.2477	1.6004	1.5061	2.4387	2.0567	2.0081
10		.1334	2.3967	1.5699	2.7054	2.2996	1.9757
11		.1334	2.4291		2.8387	2.2834	1.9433
12			2.4615	1.9509	2.6292	2.2996	2.0405
13		1.507	2.4291	1.9662	2.5149	2.2996	
14		1.5737	2.4129	1.9814	2.7054	2.2996	1.7166
15	.1905	1.6537	2.2996	2.2291	2.8197	2.332	2.0081
16	.2286	1.6004	2.2186	1.9052	2.0957	2.2996	2.1376
17	.2667	.1334		.12	.1905	.12	.1715
18	.2477	.16	.1543		.2477	.1543	.1886
19	.3429	.16	.2229		.2667	.2229	.2058
20	.2858	.1334	.2572	.2439	.362	.2572	.2058
21	.3048	.1334	.2572	.2286	.3239	.2572	.2229
22	.2858	.16	.2401	.2286	.3048	.2572	.2401
23	1.1431	.1467	.2572	.2134	.2572	.2572	.2401
24	.9145	1.2765	.1467	.2572	.2401	.2058	.2572
Max	2.1338	1.6537	2.4615	2.2291	2.8387	2.332	2.1376
Min	.1905	.1334	.1467	.12	.1905	.12	.1715
Avg	.8553	.7020	1.1826	.9943	1.3647	1.1323	.9457

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274174 / 33/11 KV Shevate Sub Station

Feeder No / Name : 204 / CHOUFULA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3167	3.0483	.1067	.2058	.2401	.12	.1715
2	2.3015		.1067	.2058	.1981	.1543	.1715
3	2.3472						
4	2.332						
5	2.3167						
6	2.5911						
7	2.774						
8	2.6673						
9		.1715	2.1338	2.2672	3.3341	2.8178	2.834
10		.08	2.9312	2.5149	.9907	2.9959	2.7206
11		.0934	2.9959	2.6063	1.0288	3.0445	2.6558
12		2.1338	3.0445	3.0864	.9526	3.2388	2.7206
13		2.2672	3.0445	3.0007	3.2388	3.1417	2.753
14		2.2405	3.0283	2.6216	3.5437	3.1417	2.9473
15	.1334	2.3472	2.915	2.5911	3.677	3.0931	2.8502
16	.1715	2.3739	2.8502	2.7435	3.4294	3.0121	2.834
17	.1524	.1067	.1372	.2915	.1334	.12	.12
18	.1334	.1067	.1543		.1524	.1372	.12
19	.1715	.1067	.1715		.1715	.1543	.1715
20	.2096	.0934	.2058	.2439	.2286	.1715	.1715
21	.1905	.0934	.2058	.2439	.1524	.1715	.1372
22	.1905	.1067	.2058	.2286	.1905	.1715	.1372
23	2.8578	.1067	.2058	.2743	.1543	.2058	.1543
24	2.6063	3.0102	.0934	.2058	.2439	.1372	.2058
Max	2.8578	3.0483	3.0445	3.0864	3.677	3.2388	2.9473
Min	.1334	.08	.0934	.2058	.1334	.12	.12
Avg	1.4702	1.0874	1.3631	1.4582	1.2256	1.4461	1.3264

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274181 / 33/11 KV BABHULGAON

SUBSTATION

Feeder No / Name : 201 / 11 KV BABHULGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.362	.3258	.3439	.362	.3801	.362
2	.3982	.3982	.3982	.362	.3801	.3982	.3801
3	.4706	.4525	.4706	.3982	.4163	.4344	.4344
4	.543	.5249	.5068	.4887	.5249	.543	.5249
5	.5973	.6154	.543	.5973	.5973	.5792	.5792
9	.3801	.4344	.4344	.4344	.362	.4163	.3439
10	.3439	.4344	.3801	.4344	.3801	.4344	.4163
11	.2534	.3258	.3077	.3077	.3077	.362	.3801
12	.2353	.2534	.2715	.2353	.2715	.2896	.3439
13	.2172	.2534	.1991	.181	.2534	.1991	.2715
14	.2534	.1991	.181	.1991	.2353	.1991	.2353
15	.2534	.1991	.2172	.1991	.2715	.1991	.2353
16	.2715	.2353	.1991		.2715	.2172	.2172
17	.2896	.2715	.2353		.3077	.2172	.2534
18	.3258	.3077	.3077	.3982	.4163	.2715	.2715
19	.4525	.3982	.3982	.4344	.4525	.4163	.3801
20	.5249	.5249	.5973	.5611	.543	.5068	.4887
21	.5792	.5611	.543	.543	.5249	.4887	.5249
22	.5249	.4887	.4706	.4525	.4344	.4706	.4706
23	.3982	.3801	.3801	.4163	.3801	.4344	.3801
24	.3801	.3801	.362	.3439	.362	.362	.3982
Max	.5973	.6154	.5973	.5973	.5973	.5792	.5792
Min	.2172	.1991	.181	.181	.2353	.1991	.2172
Avg	.3818	.3810	.3680	.3858	.3835	.3723	.3758



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274181 / 33/11 KV BABHULGAON

SUBSTATION

Feeder No / Name : 202 / BABHULGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669	1.1126	.1524	.1372	.1524	.1718	.1562
2	1.1126	1.0974	.1677	.1372	.1677	.1562	.1562
3	1.1888	1.1126	.1981	.1677	.1677	.1875	.1875
4	1.2346	1.1279	.2134	.2353	.1981	.2031	.2031
5	1.4022	.1829	.2286	.2134	.2134	.2031	.2187
6	1.5394	.2286	.2591	.2591	.2591	.2343	.25
7	1.6461	.3048	.2743	.2591	.2591	.2656	.2968
8	1.768	.2591	.1372	.2286	.2591	.2656	.2343
9	.1829	1.4937	1.829	1.4175	1.3717	1.5154	1.3748
10	.1677	2.0119	2.0119	1.6156	1.5851	1.6091	1.7341
11	.2439	1.9662	1.8138	1.4175	1.8442	1.7185	1.8278
12	.2591	2.0271	1.9662	1.7375	1.829	1.7497	1.7966
13	.1524	.1524	1.8138	1.9052	1.7985	1.7497	
14	.1981	.1524	1.89	1.7528	1.7375		1.4529
15	.2286	.1981	1.7985	1.7375	1.7375	1.5935	1.7341
16	.2591	.2134	1.7985	1.7223	1.768	1.6613	1.781
17	.2743	.2591	.1372	.1677	.0914	.1718	.1406
18	.2439	.1981	.1981	.2134	.1524	.2187	.1562
19	.1829	.1677	.2439	.2286	.1981	.2656	.1718
20	.2439	.1524	.0244	.2439	.2134	.2812	.2343
21	.2134	.1524	.1829	.2134	.2286	.25	.2187
22	.1981	.1677	.1981	.1829	.1829	.2031	.2031
23	1.1126	.1524	.1829	.1677	.1677	.1875	.2031
24	1.0517	1.1279	.1372	.1524	.1524	.1718	.1718
Max	1.768	2.0271	2.0119	1.9052	1.8442	1.7497	1.8278
Min	.1524	.1524	.0244	.1372	.0914	.1562	.1406
Avg	.6738	.6675	.7441	.6881	.6973	.6537	.6480

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274181 / 33/11 KV BABHULGAON

SUBSTATION

Feeder No / Name : 203 / 11 KV ROPALE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.064	.064	1.9204	1.9044	1.9204	2.1125	2.0485
2	.08	.08	2.0165	1.9044	1.9845	2.0485	1.9845
3	.08	.08	2.0805	1.9204	1.9845	2.1125	2.0485
4	.064	.08	2.1445	1.9204	1.9204	2.1125	2.1125
5	.064	1.4083	2.2405	1.9204	1.9845	2.1765	2.1765
6	.064	2.2405	2.3045	1.9204	2.3045	2.3365	2.3045
7	.064	2.4326	2.4326	2.3045	2.6886	2.6886	2.6886
8	.064	2.5606	2.6246	2.6886	2.5606	2.6246	2.6886
9	2.5606	.064	.064	.064	.064	.064	.064
10	2.8166	.064	.064	.064	.064	.064	.064
11	2.8166	.064	.064	.064	.064	.064	.064
12	2.7526	.064	.064	.064	.064	.064	.064
13	2.8807	2.4966	.064	.064	.064	.064	.064
14	2.8807	2.4966	.064	.064	.064	.064	.0625
15	2.9447	2.5606	.064	.064	.064	.064	.064
16	2.8166	2.7526	.064	.064	.064	.064	.08
17	.064	.064	.064		.064	.064	.08
18	.08	.064	.064	.064	.064	.08	.08
19	.096	.064	.064	.064	.08	.08	.096
20	.096	.08	.064	.08	.08	.08	.096
21	.08	.08	.064	.08	.096	.08	.08
22	.08	.08	.08	.08	.08	.08	.08
23	.08	1.9204	1.9204	1.9845	2.1125	2.0485	2.1125
24	.064	.064	1.9845	1.9204	1.9204	2.0485	2.0485
Max	2.9447	2.7526	2.6246	2.6886	2.6886	2.6886	2.6886
Min	.064	.064	.064	.064	.064	.064	.0625
Avg	.9855	.9135	.9409	.9247	.9315	.9702	.9688

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274182 / 33/11 KV SUSTE SUBSTATION

Feeder No / Name : 201 / 11KV SHINGARE/CHAWAN SEPARATED AG FEEDERS HAVING SPECIAL  
 WASTI FE Feeder KV- 11 / DESIGN TRANSFORMER  
 OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.8642	1.1111	.9877	1.2498	1.406	
2	.1543	.8642	1.1574	.9877	1.1405	1.406	
3		.8642	1.1111	1.0031	1.1405	1.4842	
4		.9259	1.1574	.9722	1.1248	1.4842	
5		1.0031	1.2346	.9877	1.1248	1.531	
6		1.0957	1.3117	1.3426	1.3435	1.6404	
7		1.3735	1.5432	1.5741	1.4998	1.9528	1.7071
8		1.4661	1.4969	1.5432	1.8122	2.1559	1.7223
9	1.5741						
10	1.6821						
11	1.7438						
12	1.6667						
13	1.6204						
14	1.5278						
15	1.4969	.0926	.1235	.0926			.1562
16	1.5123	.1235	.1235	.108	.1562	.1543	.1718
17	.1543	.1543	.1235	.1543			.1718
18	.1543	.216	.1698	.1852	.1875		
19		.216	.216		.2343		.1852
20	.1698	.2315	.2315	.216	.25		.2315
21	.1852	.2315	.216	.1852	.2812		.2006
22	.1852	.2006	.2006	.1543	.2343		.1852
23	.8333	1.0494	1.0031	1.2346	1.3435	1.3565	1.4198
24	.1543	.8642	1.1111	.9877	1.2654	1.406	1.3565
Max	1.7438	1.4661	1.5432	1.5741	1.8122	2.1559	1.7223
Min	.1543	.0926	.1235	.0926	.1562	.1543	.1562
Avg	.8805	.6576	.7579	.7480	.8993	1.4525	.6825

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274182 / 33/11 KV SUSTE SUBSTATION

Feeder No / Name : 202 / 11KV WATAR WAT FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7773	.2378	.208	.1932	.1635	.1783	
2	.7468	.2378	.208	.1932	.1635	.1783	
7	1.1126						
8	1.1584						.8619
9		1.0997	1.0254	.9362	.8619	.9602	1.07
10		1.0254	1.0997	.9214	1.07		1.07
11		1.07	1.1145	.8949	1.1145		1.0402
12		1.1145	1.1145	.9095	1.1145		1.0402
13		1.1145	1.1294	.9095	1.07		1.0402
14		1.0254	1.1294	.8802	1.0254		.8322
15	.0892	1.0402	1.0105	.8802	.9214		.8916
16	.1783	1.0402	.9957	.8509	.9214	.945	.9214
17	.1932	.104		.132	.1189		.104
18	.208	.1189	.1337	.1467	.1337		
19		.1783	.1932	.1907	.1486		.1337
20	.2378	.1932	.208	.2054	.1635		.1486
21	.2378	.1932	.208	.1614	.1635		.1783
22	.2229	.1783	.208	.1486	.1783		.1932
23	.2378	.208	.208	.1635	.1783	.2058	.208
24	.6706	.2378	.208	.208	.1635	.1783	.2058
Max	1.1584	1.1145	1.1294	.9362	1.1145	.9602	1.07
Min	.0892	.104	.1337	.132	.1189	.1783	.104
Avg	.4670	.5787	.6119	.4959	.5375	.4410	.6212

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274182 / 33/11 KV SUSTE SUBSTATION

Feeder No / Name : 203 / 11KV SUSTE RIVER SIDE SEPARATED AG FEEDERS HAVING SPECIAL  
 FEEDER Feeder KV- 11 / DESIGN TRANSFORMER  
 OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	1.3603	1.1843	1.012	1.0402	1.3443	
2	.0343	1.3603	1.1843	1.0155	1.0402	1.3443	
3		1.3603	1.1843	.9842	1.0402	1.3603	
4		1.3603	1.1843	.9804	1.0242	1.3603	
5		1.3603	1.2483	.9962	1.0402	1.3443	
6		1.3603	1.2803	1.012	1.1523	1.4403	
7		1.3603	1.3603	1.1069	1.2003	1.4723	1.5546
8		1.3443	1.2803	1.012	1.2163	1.4723	1.4327
9	1.4723						
10	1.6004						
11	1.6644						
12	1.6644						
13	1.6644						
14	1.6164						
15	1.6644	.032	.0316	.0316	.032		.064
16	1.6324	.032	.0316	.0469	.032	.0514	.064
17	.032	.032	.0316	.0316	.032		.064
18	.048	.032	.0316	.0312	.032		
19		.032	.0474	.0316	.032		.0474
20	.048	.032	.0474	.0316	.032		.0474
21	.048	.032	.0474	.0316	.032		.0474
22	.048	.032	.0316	.0474	.032		.0474
23	1.3603	1.1203	1.0279	1.078	1.2963	1.2803	1.3599
24	.0343	1.3603	1.1843	1.012	1.1043	1.3443	1.2955
Max	1.6644	1.3603	1.3603	1.1069	1.2963	1.4723	1.5546
Min	.032	.032	.0316	.0312	.032	.0514	.0474
Avg	.8637	.7557	.6899	.5829	.6339	1.2559	.5477

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 276006 / 110/33/11 KV PULUJ

Feeder No / Name : 205 / 11 KV KARKHANA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.4917
Max	.4917
Min	.4917
Avg	.4917

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 276006 / 110/33/11 KV PULUJ

Feeder No / Name : 207 / 11 KV BEGUMPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.763
Max	.763
Min	.763
Avg	.763

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 278021 / 220/33kv Karkamb

Feeder No / Name : 406 / 33kv Co-Gen

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	1.4752
Max	1.4752
Min	1.4752
Avg	1.4752



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274059 / 33/11 KV ACHAKDANI

SUBSTATION

Feeder No / Name : 241 / 11 KV IAKSHMINAGAR FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	04-AUG-17
HR	Load (MW)	Load (MW)
1		.1524
2		.2286
3		.1524
4		.2286
5		.2286
6		.3048
7		.7621
8		.381
24	.7926	.381
Max	.7926	.7621
Min	.7926	.1524
Avg	.7926	.3133

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274059 / 33/11 KV ACHAKDANI  
SUBSTATIONFeeder No / Name : 242 / 11 KV Thombarewadi feeder      SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274059 / 33/11 KV ACHAKDANI

SUBSTATION

Feeder No / Name : 243 / 11 KV ACHAKDANI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274059 / 33/11 KV ACHAKDANI

SUBSTATION

Feeder No / Name : 244 / 11 KV Khavaspur feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.6249
Max	.6249
Min	.6249
Avg	.6249

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274059 / 33/11 KV ACHAKDANI  
SUBSTATIONFeeder No / Name : 245 / 11 KV Gaonthan Feeder  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-AUG-17
HR	Load (MW)
24	.3658
Max	.3658
Min	.3658
Avg	.3658

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274060 / 33/11 KV Jawala

Feeder No / Name : 241 / 11 KV Jawala feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274060 / 33/11 KV Jawala

Feeder No / Name : 242 / 11 KV Sonand

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274060 / 33/11 KV Jawala

Feeder No / Name : 243 / 11 KV Tarangewadi feeder      SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING    DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.6249
Max	.6249
Min	.6249
Avg	.6249



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274060 / 33/11 KV Jawala

Feeder No / Name : 244 / 11 KV Gaothan feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274060 / 33/11 KV Jawala

Feeder No / Name : 245 / Kashidwadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.7773
Max	.7773
Min	.7773
Avg	.7773

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274060 / 33/11 KV Jawala

Feeder No / Name : 246 / 11kv lonvire Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.7926
Max	.7926
Min	.7926
Avg	.7926

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274060 / 33/11 KV Jawala

Feeder No / Name : 247 / 11kv bhopsewadi Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.6249
Max	.6249
Min	.6249
Avg	.6249

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274061 / 33/11 KV Geradi

Feeder No / Name : 241 / 11 KV Gherdi feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1524	.503	.5335	.5335	.1829	.4268
2	.1829	.1829	.503	.5182	.5792	.1829	.3963
3			.7164	.5335	.6401		
4			.7773	.6097	.8688		
5			.9755	.8383	.9755		
6			1.2193	.9602	1.2193		
7			1.326	1.2193	1.2498		
8			1.2803	1.2651	1.0212		
9	1.2193	1.2193				1.2193	.6097
10	1.0822	1.2498				1.3413	.6859
11	1.1431	1.1279				1.0669	.7773
12		1.0517				.9907	.6401
13	1.0974	.9297				.9145	.7316
14	1.0669	.8078				.8078	.6859
15	.9145		.0914	.1067	.1067	.7621	.7316
16	.823		.1067	.1067	.1067		.7926
17	.1372	.1372	.1067	.1677	.1067	.1829	
18	.1524	.1677	.1067	.1524	.1372	.1524	
19		.2134	.1829	.1829	.1981	.1677	.1829
20	.2134	.2439	.1829	.2134	.2286	.1981	.1524
21	.2439	.2286	.2286	.2439	.1067	.2134	.1524
22	.1829	.2134	.2286	.1981		.1829	.1524
23	.1829		.381	.3963		.3201	.2743
24	.1829	.1829	.442	.4572	.4572	.1981	.442
Max	1.2193	1.2498	1.326	1.2651	1.2498	1.3413	.7926
Min	.1372	.1372	.0914	.1067	.1067	.1524	.1524
Avg	.5630	.5406	.5199	.4835	.5335	.5344	.4896

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274061 / 33/11 KV Geradi

Feeder No / Name : 242 / 11 KV Pare

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.4572	.1067	.1524	.1524	.3506	.1677
2	.4572	.442	.1067	.1524	.1524	.3658	.1524
3	.5335	.5792				.381	.7621
4	.5944	.5639				.4572	.7621
5	.6249	.5792				.5182	.7926
6	.7164	.6097				.7468	.8078
7	.8383	.6401				.7773	.9145
8	.7468	.7773				.7164	.9602
9			.9145	.6249	.7164		
10			.7011		.7773		
11			.6097		.823		
12			.5792	.6859	.6706		
13			.5487	.6401	.503		
14			.5335	.5944	.442		
15	.1829		.5335	.5182	.4572	.1829	.0914
16	.1524		.5487	.5487	.5182	.1981	.0914
17	.1372	.0914	.0914	.0762	.0914	.1981	.0914
18	.1219	.1067	.0914	.0762	.0914		.0914
19	.1372	.1524	.1067	.0762	.1219		.1219
20	.1524	.1677	.1524	.1524	.1372	.2134	
21	.1677	.1372	.1524	.1524		.2286	
22	.1372	.1372	.1524	.1524		.2286	
23	.4115		.1524	.1524		.1829	
24	.4268	.442	.1067	.1524	.1524	.2896	.1524
Max	.8383	.7773	.9145	.6859	.823	.7773	.9602
Min	.1219	.0914	.0914	.0762	.0914	.1829	.0914
Avg	.3844	.3922	.3438	.3067	.3871	.3772	.4257

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274061 / 33/11 KV Geradi

Feeder No / Name : 243 / 11 KV Hangirge feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1981	.1829	.7468	.6097	.6097	.1981	.1829
2	.1981	.1829	.7316	.7011	.6859	.1981	.1981
3			.884	.6859	.6859		
4			1.0364	.7621	.7621		
5			1.0822	.9907	1.0059		
6			1.2651	1.326	1.3413		
7			1.4784	1.2803	1.448		
8			1.4175	1.326	1.4022		
9	1.2193	1.0212					1.1888
10	1.2346	1.0974					1.3108
11	1.2193	1.0822				.823	1.1736
12	.9145	1.0974				.7621	1.0974
13	.7621	1.1431				.7316	1.0517
14	.6097	.823				.7164	.9602
15	.7926		.1067	.1067	.1067	.6859	.9755
16	.7926		.116	.1219	.1067	.7468	1.0669
17	.1219	.1067	.1067	.1219	.1067	.2591	.1219
18	.1067	.1677	.1524	.1524	.1372	.2439	.1372
19	.1829	.2439	.1677	.1829	.1829	.2286	.1829
20	.1981	.2591	.1981	.1981	.2439	.2439	.2439
21	.2286	.2439	.1829	.1829		.2439	.2286
22	.1981	.2134	.2743	.2439		.1981	.2134
23	.1829		.4572	.4572		.1829	.1981
24	.1981	.1677	.5487	.4572	.4572	.1981	.1677
Max	1.2346	1.1431	1.4784	1.326	1.448	.823	1.3108
Min	.1067	.1067	.1067	.1067	.1067	.1829	.1219
Avg	.5199	.5355	.6085	.5504	.6188	.4163	.5944

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274061 / 33/11 KV Geradi

Feeder No / Name : 244 / Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2134	.2286	.2134	.2286	.2286	.2439	.2439
2	.2134	.2134	.2134	.2286	.2286	.2439	.2743
3	.2439		.2439	.2286	.2286	.2439	.3048
4	.2743	.2591	.2743	.2439	.2591	.2743	.381
5	.3048	.3658	.3353	.3048	.3048	.3048	.4115
6	.3353	.4115	.4268	.4572	.4572	.3658	.4268
7	.3963	.442	.4572	.4268	.3658	.4268	
8	.3353	.4877	.2439	.3353	.3048	.3048	.4268
9	.3048	.3048	.2439	.3048	.2439	.3048	.3048
10	.2439	.2134	.2439		.2439	.3353	.2439
11	.2286	.2286	.2286	.2896	.2134	.2743	
12	.1981	.2134	.2286	.1524	.2134	.2134	.1524
13	.1829	.2134	.1829	.1829	.1829	.1981	.1524
14	.1829	.2134	.1829	.1981	.1829	.1829	.1829
15	.1829		.2134	.2134	.1829	.1677	.1829
16	.2134		.2286	.2134	.1829	.1677	.1829
17	.2591	.2439	.2286	.2439	.2743	.1524	.2134
18	.3048	.3353	.2743	.3048	.3353	.2134	.2743
19	.2591	.4268	.4572	.3658	.4268	.2743	.3048
20	.3506	.4877	.4572	.4572	.4268	.3048	.4877
21	.3963	.3658	.4268	.3963		.2743	.4268
22	.3048	.3353	.3048	.3048		.2591	.3963
23	.2743		.2286	.2286		.2439	.3048
24	.2134	.2134	.2439	.2286	.2286	.2439	.2134
Max	.3963	.4877	.4572	.4572	.4572	.4268	.4877
Min	.1829	.2134	.1829	.1524	.1829	.1524	.1524
Avg	.2674	.3102	.2826	.2843	.2722	.2591	.2951



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274063 / 33/11 KV KOLA SUBSTATION

Feeder No / Name : 241 / 11 KV Kola feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0972	.0972	.2753	.3563	.3725	.3077	.3239
2	.0972	.0972	.2915	.3887	.4049	.3077	.3239
3	.0648	.0972	.3077	.421	.4372	.2753	.4049
4	.1134	.0972	.3401	.4858	.4858	.2915	.4049
5	.1619	.1134	.3725	.502	.6154	.3563	.5668
6	.1457	.1781	.4049	.5344	.7287	.5506	.5668
7	.1134	.1134	.5668	.7935	.7935	.7611	.7449
8	.1134	.081	.6154	.7611	.7773	.7773	.7287
9	.4858	.5992	.0486	.0486	.0486	.1134	.081
10	.5668	.6478	.0648	.0648	.0648	.081	.0324
11	.6802	.5506	.0486	.0486	.0972	.0972	.081
12	.583	.6478	.0324	.0324	.0486	.0972	.0469
13	.4696	.583	.0486	.0324	.0972	.0972	.0469
14	.4858	.6478	.0486	.0486	.081	.081	.0469
15	.5182	.7287	.0486	.0648	.0486	.0972	.0469
16	.4858	.5506	.0648	.0486	.0648	.0972	.0469
17	.0648	.0648	.0486	.0324	.0486	.081	.0625
18	.081	.0972	.0648	.0648	.0648	.081	.0781
19	.1134	.1134	.0486	.0648	.081	.1134	.0781
20	.1457	.1296	.0486	.1296	.1134	.1296	.1094
21	.1457	.1296	.1134	.1134	.1134	.1134	.125
22	.1457	.1296	.1134	.1134	.1134	.1134	.1406
23	.1134	.2753	.3563	.3725	.2753	.2915	.3437
24	.081	.1134	.2753	.3563	.3725	.2915	.3239
Max	.6802	.7287	.6154	.7935	.7935	.7773	.7449
Min	.0648	.0648	.0324	.0324	.0486	.081	.0324
Avg	.2530	.2868	.1937	.2450	.2645	.2335	.2398

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274063 / 33/11 KV KOLA SUBSTATION

Feeder No / Name : 242 / 11 KV Gaudwadi feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.421	.2429	.081	.081	.081	.0972	.0972
2	.3725	.2429	.081	.081	.081	.0972	.081
3	.4372	.2591	.081	.0972	.0972	.0972	.081
4	.4696	.2915	.081	.0972	.0972	.0972	.081
5	.6154	.3401	.0972	.1134	.1134	.0972	.0972
6	.9393	.6154	.0972	.1296	.1134	.1296	.0972
7	1.1174	.8583	.1296	.1134	.081	.1296	.0972
8	1.085	.8907	.081	.0972	.0648	.1296	.081
9	.0486	.0486	.5992	.5506	.7125	.8421	.7611
10	.0324	.0324	.7935	.6316	.8421	.9555	.8259
11	.0324	.0486	.7449	.7449	.8745	.6964	.8745
12	.0324	.0324	.6154	.664	.8421	.7611	.8436
13	.0486	.0162	.5992	.6478	.7773	.7773	.7811
14	.0486	.0324	.6964	.7449	.8583	.8097	.7499
15	.0324	.0324	.7287	.6154	.6478	.7449	.6249
16	.0324	.0324	.8421	.6478	.6964	.6964	.5312
17	.0486	.0486	.0486	.081	.0648	.0648	.0625
18	.0648	.081	.0648	.0648	.0486	.081	.0781
19	.081	.0972	.0486	.0486		.1134	.0781
20	.081	.1134	.0486	.081	.0972	.1134	.0781
21	.081	.1134	.0972	.0972	.1134	.1134	.0781
22	.081	.0972	.0972	.0972	.0972	.1134	.0781
23	.2429	.0972	.0972	.0972	.0972	.0972	.0781
24	.3887	.2591	.0972	.081	.081	.0972	.0972
Max	1.1174	.8907	.8421	.7449	.8745	.9555	.8745
Min	.0324	.0162	.0486	.0486	.0486	.0648	.0625
Avg	.2848	.2051	.2895	.2794	.3295	.3313	.3056

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274063 / 33/11 KV KOLA SUBSTATION

Feeder No / Name : 243 / 11 KV Junoni feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4372	.3563	.1781	.1781	.1619	.1943	.0972
2	.4858	.3563	.1781	.1781	.1619	.1781	.0972
3	.5506	.3887	.1943	.1781	.1619	.1781	.0972
4	.6478	.4049	.2105	.1943	.1619	.1943	.0972
5	.7449	.4534	.2267	.2429	.1943	.2267	.1296
6	.8745	.6964	.2591	.2753	.2429	.3077	.1619
7	1.2146	1.1498	.2429	.2267	.2267	.1457	.2105
8	.9878	.9393	.1619	.1619	.2105	.1457	.1457
9	.2105		.6316	.583	.7611	.7935	.6562
10	.1134	.0486	.7611	.5182	.7449	.7935	.7935
11	.081	.0486	.7773	.6478	.7449	.7773	.5992
12	.0648	.0648	.8421	.9069	.6154	.6802	.5937
13	.081	.0486	1.085	.8097	.664	.6316	.5468
14	.081	.0648	.8907	.9069	.6316	.5506	.5937
15	.0972	.0324	.6478	.7449	.5668	.5182	.6249
16	.0972	.0162	.8097	.8097	.5992	.6316	.5312
17	.0972	.0162	.0972	.1619	.081	.1457	.125
18	.1134	.1457	.0648	.1781	.0972	.1134	.125
19	.1619	.1943	.081	.1619	.1619	.2105	.1406
20	.2591	.2591	.2105	.2915	.2591	.2267	.1875
21	.2591	.2429	.2429	.2753	.2429	.2429	.2031
22	.2753	.2105	.2105	.2753	.2591	.2591	.2187
23	.3563	.1781	.1943	.2429	.2267	.2267	.2031
24	.4858	.3725	.1781	.1781	.1943	.1943	.0972
Max	1.2146	1.1498	1.085	.9069	.7611	.7935	.7935
Min	.0648	.0162	.0648	.1619	.081	.1134	.0972
Avg	.3657	.2908	.3907	.3886	.3488	.3569	.3032

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274063 / 33/11 KV KOLA SUBSTATION

Feeder No / Name : 244 / 11 KV Pachegaon feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1619	.1457	.3239	.4858	.4858	.4858	.5668
2	.1619	.1457	.3239	.4858	.4858	.4858	.5668
3	.1457	.1457	.3239	.4858	.4858	.4858	.7287
4	.1619	.1457	.4858	.8097	.6478	.4858	.7287
5	.1781	.1457	.4858	.8097	.6478	.4858	.8097
6	.1781	.1619	.4858	.6478	.6478	.8097	.8907
7	.1619	.1781	.8097	.8097	.8097	1.1336	.8907
8	.1943	.1619	.6478	.9717	.8097	.9717	.8907
9	.8097	.9717	.0972	.1134	.0972	.1457	.1457
10	.8097	.9717	.0972	.1134	.1296	.1457	.1296
11	.6478	1.0526	.1134	.0972	.1296	.1457	.1296
12	.6478	.8097	.1134	.1134	.1296	.1457	.0972
13	.6478	.8907	.1296	.1296	.1296	.1457	.0972
14	.6478	.9717	.1296	.1296	.1296	.1457	.0972
15	.6478	1.0526	.1457	.1457	.1296	.1457	.0972
16	.6478	.6478	.1457	.1296	.1296	.1457	.0972
17	.1619	.0972	.1457	.1457	.1457	.1457	.1296
18	.1619	.1457	.1296	.1296	.1457	.1457	.1296
19	.1619	.1619	.1296	.1457	.1619	.1619	.1296
20	.1619	.1619	.1296	.1619	.1619	.1619	.1457
21	.1619	.1619	.1619	.1619	.1619	.1457	.1457
22	.1619	.1619	.1619	.1619	.1619	.1457	.1457
23	.1619	.3239	.4858	.4858	.4858	.5668	.7287
24	.7773	.1619	.3239	.4858	.4858	.4858	.5668
Max	.8097	1.0526	.8097	.9717	.8097	1.1336	.8907
Min	.1457	.0972	.0972	.0972	.0972	.1457	.0972
Avg	.3650	.4156	.2719	.3482	.3306	.3529	.3785

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274063 / 33/11 KV KOLA SUBSTATION

Feeder No / Name : 245 / KOLA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5182	.583	.583	.583	.583	.5506	.5182
2	.4858	.583	.583	.583	.583	.5506	.5182
3	.4858	.583	.6478	.6154	.6478	.5506	.5506
4	.583	.6154	.7449	.7449	.7449	.583	.6154
5	.7449	.6802	.7449	.9393	.9069	.6154	.6154
6	1.004	1.1336	1.0688	1.1012	1.1012	1.0364	1.004
7	.8745	.8745	.9393	.8745	1.004	.9069	.9393
8	.6154	.5182	.6478	.6478	.6154	.6154	.6154
9	.4534	.4534	.4858	.583	.4858	.5182	.4858
10	.421	.3887	.4534	.4858	.4858	.421	.4858
11	.3887	.3887	.3887	.3563	.3887	.3563	.4858
12	.3563	.3887	.3887	.3563	.3563	.3239	.4062
13	.3563	.3563	.3563	.3887	.421	.3563	.4062
14	.3887	.3563	.3563	.3563	.3887	.3239	.4062
15	.4534	.3887	.3563	.3563	.4534	.3563	.3749
16	.421	.3887	.3887	.3887	.4858	.4858	.3749
17	.4858	.421	.5506	.4534	.5182	.4858	.4374
18	.6154	.5506	.5506	.4858	.6154	.5182	.5312
19	.7773	.7773	.6802	.6802	.6802	.8097	.6249
20	.9069	.9393	.9393	.9717	.7773	.9393	.9061
21	.8097	.8745	.8745	.9393	.9393	.8421	.8124
22	.7449	.7773	.7449	.7773	.7449	.8097	.7499
23	.6478	.6478	.6478	.6478	.5506	.5506	.5312
24	.5182	.583	.583	.583	.583	.5506	.5182
Max	1.004	1.1336	1.0688	1.1012	1.1012	1.0364	1.004
Min	.3563	.3563	.3563	.3563	.3563	.3239	.3749
Avg	.5857	.5938	.6127	.6208	.6275	.5857	.5797

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274063 / 33/11 KV KOLA SUBSTATION

Feeder No / Name : 246 / 11 KV KOMBADWADI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1619	.1781	.4858	.6478	.6478	.6478	.7287
2	.1781	.1619	.4858	.6478	.6478	.6478	.7287
3	.1943	.1619	.4858	.6478	.6478	.6478	.8097
4	.1619	.1619	.6478	.8097	.8097	.6478	.8097
5	.1781	.1619	.6478	.8097	.8097	.6478	.9717
6	.1457	.1943	.6478	.8097	.8097	.6478	.9717
7	.1781	.1943	.9717	.9717	.9717	1.2955	.9717
8	.1781	.1781	.8097	1.0526	.9717	1.1336	.9717
9	1.1336	1.1336	.1296	.0972	.1134	.1619	.1619
10	.9717	1.2146	.1134	.0972	.1457	.1619	.1619
11	.8097	1.1336	.0972	.1134	.1457	.1619	.1619
12		1.0526	.1134	.1134	.1457	.1619	.1296
13	.8097	.9717	.1134	.1296	.1457	.1619	.1296
14	.8097	.9717	.1296	.0972	.1457	.1619	.1296
15	.8097	.9717	.1134	.1134	.1296	.1619	.1296
16	.8097	.8097	.1296	.1457	.1296	.1619	.1296
17	.1781	.1296	.1296	.1296	.1134	.1619	.1457
18	.1781	.1457	.1296	.1457	.1134	.1619	.1457
19	.1781	.1619	.1457	.1457	.1296	.1943	.1457
20	.1781	.1943	.1619	.1943	.1781	.1943	.1619
21	.1781	.1943	.1943	.1943	.1781	.1619	.1619
22	.1781	.1943	.1943	.1943	.1781	.1619	.1619
23	.1781	.4858	.6478	.6478	.6478	.7287	.8097
24	.6859	.1781	.4858	.6478	.6478	.6478	.7287
Max	1.1336	1.2146	.9717	1.0526	.9717	1.2955	.9717
Min	.1457	.1296	.0972	.0972	.1134	.1619	.1296
Avg	.4114	.4723	.3421	.4001	.4001	.4177	.4399

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274063 / 33/11 KV KOLA SUBSTATION

Feeder No / Name : 247 / 11 KV BUDDIHAL FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5992	1.166	.1781	.1619	.1619	.1781	.1562
2	.5992	1.1822	.1781	.1619	.1619	.1943	.1619
3	.6478	1.1984	.1781	.1619	.1619	.1943	.1619
4	.7449	1.1822	.1943	.1619	.1619	.1619	.1619
5	1.2793	1.4413	.2105	.1943	.1943	.1619	.1943
6	1.8623	1.8623	.2267	.2105	.1781	.2105	.1943
7	1.8299	2.3805	.1781	.1781	.1457	.1943	.1943
8	1.749	1.7814	.1296	.1943	.1134	.1457	.1134
9	.081	.1296	1.8461	1.5223	1.749	2.0729	1.9433
10	.081	.1134	2.2348	1.6842	2.4939	2.2672	2.2834
11	.081	.1457	2.251	2.0891	2.2862	2.2348	2.0891
12	.081	.1781	2.0729	2.2348	2.4615	2.2672	1.9372
13	.0972	.1296	2.2024	1.9433	2.332	2.332	2.0309
14	.0972	.1457	2.1052	2.1862	2.2348	2.2348	2.0622
15	.0972	.1134	2.2186	2.0891	1.9433	2.2348	1.9528
16	.0972	.1134	2.2348	1.9595	2.0567	2.2834	1.781
17	.0972	.1296	.1457	.1619	.1619	.1457	.1562
18	.1134	.1619	.1943	.2267	.1457	.1619	.1562
19	.1457	.1781	.1619	.1781	.1457	.1943	.1562
20	.2267	.2105	.1781	.2267	.2105	.1943	.1562
21	.2267	.2105	.1943	.2105	.1943	.1943	.1875
22	.2267	.1943	.1943	.2105	.2105	.1943	.1875
23	1.166	.1781	.1781	.1943	.1943	.1943	.1562
24	.5668	1.1336	.1781	.1619	.1781	.1943	.1943
Max	1.8623	2.3805	2.251	2.2348	2.4939	2.332	2.2834
Min	.081	.1134	.1296	.1619	.1134	.1457	.1134
Avg	.5331	.6525	.8360	.7793	.8449	.8684	.7820

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274064 / 33/11 KV MAHUD S/STN.

Feeder No / Name : 241 / 11 KV Kolegaon feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.181		1.1336
2				.181		1.1336
3						1.2146
4						1.2146
5						1.4089
6						1.8947
7						2.6235
8	2.753	3.1093				2.7854
12				1.4575		
13				2.4291		
14				2.5101		
15				2.4291	.181	.181
16		.181	1.8138	2.2672	.181	.181
17				.2172	.181	.181
18				.2353	.181	.181
19				.2534	.181	.181
20				.2534	.2172	.2172
21					.2172	.2172
22					.181	.181
23	1.4575	.181	.181	.2172	1.0526	1.247
24	.6249	1.5384	.181	.181		1.166
Max	2.753	3.1093	1.8138	2.5101	1.0526	2.7854
Min	.6249	.181	.181	.181	.181	.181
Avg	1.6118	1.2524	.7253	.9856	.2859	.9635



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274064 / 33/11 KV MAHUD S/STN.

Feeder No / Name : 242 / 11 KV Mahud feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				2.1862		.181
2				2.1862		.181
3				2.2186		
4				2.2672		
5				2.4129		
6				2.672		
7				2.834		
8			2.8016			
9						2.5101
10					2.7854	2.2996
11					3.0769	2.2996
12					3.1255	2.5339
13					2.915	2.1862
14					2.7044	2.1052
15				.181	2.4777	1.9433
16	2.4291	2.3482	.181	.181	2.6397	1.9433
17				.181	.1448	.1448
18				.181	.181	.181
19				.2172	.181	.181
20				.2172	.2172	.2172
21				.2172	.181	.181
22				.181	.181	.181
23	.181	1.7814	2.0567	1.9433	.181	.181
24	.5468	.181	1.8138	2.1862		.181
Max	2.4291	2.3482	2.8016	2.834	3.1255	2.5339
Min	.181	.181	.181	.181	.1448	.1448
Avg	1.0523	1.4369	1.7133	1.3214	1.4994	1.0906

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274064 / 33/11 KV MAHUD S/STN.

Feeder No / Name : 243 / 11 KV Itaki feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				2.0243		.181
2				2.1376		.181
3				2.1376		
4				2.0243		
5				2.1376		
6				2.1862		
7				2.5101		
8			2.7854			
9						2.3482
10					3.0283	2.6235
11					2.9959	2.8664
12					2.7044	2.915
13					2.7854	2.7854
14					2.7044	2.5101
15				.1619	2.5425	3.0769
16	2.915	2.672	.181	.181	1.8623	3.3198
17					.181	.181
18				.181	.2172	.2172
19				.2172	.2172	.2172
20				.2172	.2715	.2715
21				.2353	.2353	.2353
22				.2172	.2172	.2172
23	.181	1.7328	1.9433	1.6194	.181	.181
24		.181	1.8623	2.0243		.181
Max	2.915	2.672	2.7854	2.5101	3.0283	3.3198
Min	.181	.181	.181	.1619	.181	.181
Avg	1.548	1.5286	1.693	1.2633	1.4388	1.3616

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274064 / 33/11 KV MAHUD S/STN.

Feeder No / Name : 244 / 11 KV Mahim feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.181		1.4575
2				.181		1.4575
3						1.3765
4						1.4575
5						1.5384
6						1.6518
7						2.3967
8						2.0243
12				2.1052		
13				2.4615		
14				2.3482		
15				2.0243	.1267	.1629
16	.2172	.2715	1.3117	1.8623	.181	.181
17				.2353	.181	.181
18				.2534	.2172	.2172
19				.2715	.2172	.2172
20				.2715	.2715	.2715
21				.2534	.2172	.2172
22				.2353	.2172	.2172
23	1.3765	.181	.181	.2172	1.4575	1.4575
24	1.7737	1.4575	.181	.181		1.4899
Max	1.7737	1.4575	1.3117	2.4615	1.4575	2.3967
Min	.2172	.181	.181	.181	.1267	.1629
Avg	1.1225	.6367	.5579	.8721	.3429	.9985

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274064 / 33/11 KV MAHUD S/STN.

Feeder No / Name : 245 / 11 KV Gaothan feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.724		.8145
2				.724		.8145
3				.7059		.8145
4				.7059		.8145
5				.9593		1.0317
6				1.1765		1.448
7				1.267		1.267
8	.8145	.905	.6335			1.1222
9						.8507
10					.8145	.8145
11					.8145	.724
12				.905	.6697	.724
13				.724	.6697	.724
14				.724	.724	.724
15				.6335	.724	.724
16	.8688	.6697	.6335	.6335	.7602	.6335
17				.724	.7602	.724
18				.8145	.724	.7602
19				.905	.8145	.8145
20				1.1765	1.1765	1.1765
21				1.086	1.1403	1.1403
22				.905	.9955	.9955
23	.8507	.8507	.7783	.8145	.905	.905
24	.724	.724	.8145	.724		.8145
Max	.8688	.905	.8145	1.267	1.1765	1.448
Min	.724	.6697	.6335	.6335	.6697	.6335
Avg	.8145	.7874	.7150	.8516	.8352	.8907

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274065 / 33/11KV SHIRBHAVI S/STN.

Feeder No / Name : 241 / 11 KV Shirbhavi feeder      SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.2012	.285	2.1538	2.3158	2.5819	2.3137	1.7604
16	1.6263	1.2407	.1457	.1509	.1509	.1509	.1844
23	.2347	.8907	1.0202	1.1065	1.073	1.1401	.9724
24	.1781	.2347	.8907	1.004	1.1736	1.0395	1.1568
Max	1.6263	1.2407	2.1538	2.3158	2.5819	2.3137	1.7604
Min	.1781	.2347	.1457	.1509	.1509	.1509	.1844
Avg	.5601	.6628	1.0526	1.1443	1.2449	1.1611	1.0185

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274065 / 33/11KV SHIRBHAVI S/STN.

Feeder No / Name : 242 / 11KV Dhyati Feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.1677	.3018	2.1862	2.1052	2.3472	1.5089	1.4922
16	1.7101	.7545	.2591		.1341	.1341	.1509
23	.2683	.8097	.9175	1.0059	.9221	.9054	.7377
24	2.6073	.2347	.8097	.9393	1.0898	1.0059	.9724
Max	2.6073	.8097	2.1862	2.1052	2.3472	1.5089	1.4922
Min	.1677	.2347	.2591	.9393	.1341	.1341	.1509
Avg	1.1884	.5252	1.0431	1.3501	1.1233	.8886	.8383

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274065 / 33/11KV SHIRBHAVI S/STN.

Feeder No / Name : 243 / 11 KV Haldahiwadi feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.4813	2.2131	.2915	.2915	.3353	.3353	.3018
16	.2347	.1677	1.4899	1.6766	1.8442	1.8107	1.576
23	.7042	.1619	.2267	.2683	.2683	.2683	.2347
24	.6859	.7377	.1619	.1943	.2347	.2347	.2683
Max	2.4813	2.2131	1.4899	1.6766	1.8442	1.8107	1.576
Min	.2347	.1619	.1619	.1943	.2347	.2347	.2347
Avg	1.0265	.8201	.5425	.6077	.6706	.6623	.5952

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274065 / 33/11KV SHIRBHAVI S/STN.

Feeder No / Name : 244 / Gaothan feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.3018	.3353	.2753	.2915	.2683	.3018	.218
16	.0671	.1341	.0972		.1677	.1509	.1509
23	.3018	.1943	.2622	.2347	.3018	.3185	.3018
24	.1619	.2683	.1943	.2267	.2012	.2683	.285
Max	.3018	.3353	.2753	.2915	.3018	.3185	.3018
Min	.0671	.1341	.0972	.2267	.1677	.1509	.1509
Avg	.2082	.233	.2073	.2510	.2348	.2599	.2389



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274065 / 33/11KV SHIRBHAVI S/STN.

Feeder No / Name : 245 / Devkatewadi feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.3472	2.1795	.2591	.2683	.3353	.3353
16	.1341	.1341	2.079	1.9448	1.1401	1.5089
23	.6706	.1943	.2347	.2347	.2683	.2683
24	1.0364	.7545	.1943	.2347	.2012	.2591
Max	2.3472	2.1795	2.079	1.9448	1.1401	1.5089
Min	.1341	.1341	.1943	.2347	.2012	.2591
Avg	1.0471	.8156	.6918	.6706	.4862	.5929

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274065 / 33/11KV SHIRBHAVI S/STN.

Feeder No / Name : 246 / 11KV WATER SUPPLY

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 11 / OUTGOING

UTILITY

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.3688	.4694	.2915	.3887	.3688	.0335	.4694
16	.2683	.0335	.1619	.3018	.1006	.2683	.1677
22		.3353					
23	.3018		.2267	.0335	.1341	.0335	.2683
24	.3887	.3353	.2591	.2591	.4359	.1006	.3688
Max	.3887	.4694	.2915	.3887	.4359	.2683	.4694
Min	.2683	.0335	.1619	.0335	.1006	.0335	.1677
Avg	.3319	.2934	.2348	.2458	.2599	.1090	.3186

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274066 / 33/11 KV UDANWADI SUB-  
STATIONFeeder No / Name : 241 / 11 KV Nazara feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.6249
Max	.6249
Min	.6249
Avg	.6249

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274066 / 33/11 KV UDANWADI SUB-  
STATIONFeeder No / Name : 242 / 11 KV Rajuri feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
23	.381
24	.7773
Max	.7773
Min	.381
Avg	.5792

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274066 / 33/11 KV UDANWADI SUB-  
STATIONFeeder No / Name : 243 / 11 KV Chopadi feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.823
Max	.823
Min	.823
Avg	.823

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274066 / 33/11 KV UDANWADI SUB-  
STATIONFeeder No / Name : 244 / 11 KV Karandewadi feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.6249
Max	.6249
Min	.6249
Avg	.6249

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274066 / 33/11 KV UDANWADI SUB-  
STATION

Feeder No / Name : 245 / Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.3201
Max	.3201
Min	.3201
Avg	.3201

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274066 / 33/11 KV UDANWADI SUB-  
STATIONFeeder No / Name : 246 / 11 KV Rajuri Gaonthan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-AUG-17
HR	Load (MW)
24	.1829
Max	.1829
Min	.1829
Avg	.1829



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274069 / 33/11 KV MANJARI S/S

Feeder No / Name : 241 / 11 KV Manjari feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0671	.2683	.1943	
2	.0678	.3018	.2294	
3	.0671	.3018	.2294	
4	.0671	.3353	.426	
5	.2012	.3688	.3605	
6	.4409	.3688	.4049	
7	.426	.4024	.3563	
8	.4024	.3688	.421	.4024
9	.0343	.0671	.0655	
10	.0343	.0335	.2294	
11	.0335	.0335	.0324	
12	.0343	.0335	.0328	
13	.0339	.0335	.0328	
14	.0343	.0335	.0328	
15	.0343			
16	.0343		.0324	.0328
17	.0343	.0335	.0328	.0655
18	.0343	.0671	.0324	.0655
19	.0678	.0671	.0671	.0655
20	.0686	.0671	.0648	.0655
21	.0686	.0671	.0648	.0648
22	.0686	.1006	.0648	.0655
23	.2058	.1341	.2012	.2347
24	.061	.3018	.1966	.1989
Max	.4409	.4024	.426	.4024
Min	.0335	.0335	.0324	.0328
Avg	.1092	.1722	.1654	.1261

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274069 / 33/11 KV MANJARI S/S

Feeder No / Name : 242 / 11 KV Bamni feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0671	.2347	.2267	.0648
2	.0678	.2683	.2591	.0648
3	.0671	.2683	.2591	
4	.0678	.2743	.2591	
5	.2012	.3018	.2915	
6	.3391	.3018	.2267	
7	.3353	.3353	.3277	
8	.3052	.3353	.3277	.3563
9	.0164	.0168	.0328	
10	.0171	.0162	.0324	
11	.0171	.0168	.0162	
12	.0168	.0168	.0164	
13	.017	.0168	.0164	
14	.017	.0168	.0164	
15	.0171		.0328	
16	.0171		.0324	.0168
17	.0168	.0335	.0324	.0162
18	.0343	.0335	.0324	.0328
19	.0343	.0335	.0328	.0328
20	.0678	.0335	.029	.0328
21	.0678	.0335	.0328	.0324
22	.0343	.0335	.0328	.0162
23	.1715	.0335	.0655	.1619
24	.0914	.2294	.2267	.0648
Max	.3391	.3353	.3277	.3563
Min	.0164	.0162	.0162	.0162
Avg	.0877	.1311	.1191	.0744

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274069 / 33/11 KV MANJARI S/S

Feeder No / Name : 243 / 11 KV Sangewadi Feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1844	.2012	.3018		.1677
2	.1802	.2012	.2949		
3	.1638	.2012	.3353		
4	.1619	.2012	.3688		
5	.3018	.2012	.3018		
6	.1677	.2347	.3277		
7	.1677	.2347	.2347		
8	.2012	.2058	.2012	.1619	.1619
9	1.5424	1.4754	.9667		1.2631
10	1.5089	1.5775	.8192		1.4754
11	1.3077	1.6766	1.1736		1.5089
12	1.1401	1.7436	1.2452		1.5424
13	1.3077	1.6766	1.1469		1.4922
14	1.3413		.7865		1.4419
15	1.4083		1.065		1.5089
16	1.3413		1.1797	.1296	1.5384
17	.1341	.2012	.1311	.1296	.1357
18	.1341	.2012	.1311	.1638	.1677
19	.2035	.2374	.1638	.1943	.2012
20	.2374	.2347	.1638	.1943	.2012
21	.2347	.2683	.1638	.2294	.2035
22	.2374	.3018	.1966	.2267	.4858
23	.2374	.2683	.1638	.2267	.4694
24	.2012	.2058	.2949	.1619	.2012
Max	1.5424	1.7436	1.2452	.2294	1.5424
Min	.1341	.2012	.1311	.1296	.1357
Avg	.5853	.5595	.5066	.1818	.7870

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274069 / 33/11 KV MANJARI S/S

Feeder No / Name : 244 / 11 KV Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5182	.4694	.4915	.4915
2	.503	.4694	.4915	
3	.503	.4588	.5365	
4	.57	.503	.4915	
5	.7621	.4915	.4752	
6	.5487	.5898	.4534	
7	.6036	.6371	.4752	
8	.5365	.5765	.4534	.503
9	.4024	.5087	.3932	
10	.3391	.2713	.3887	
11	.3353	.2683	.3239	
12	.3018	.3391	.2347	
13	.3018	.3688	.2347	
14	.3353	.3353	.2294	
15	.3018		.3239	
16	.3018		.3277	.3688
17	.3353	.3353	.4534	.3605
18	.3688	.3605	.4858	.4024
19	.4024	.4359	.5571	.4024
20	.4904	.5365	.5243	.4359
21	.5144	.503	.4915	.4694
22	.503	.5868	.4588	.5087
23	.4359	.5243	.3239	.503
24	.5335	.4694	.6371	.3353
Max	.7621	.6371	.6371	.5087
Min	.3018	.2683	.2294	.3353
Avg	.4478	.4563	.4273	.4346

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274069 / 33/11 KV MANJARI S/S

Feeder No / Name : 245 / 11 KV DEVALE AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2374	.2012	.3239	.2012
2	.2204	.1677	.3688	.2294
3	.218	.1677	.3688	.2347
4	.2294	.1677	.1677	.2515
5	.3018	.2012	.1677	.2515
6	.1677	.2012	.2012	.2683
7	.1677	.1966	.1677	.2012
8	.2012	.1638	.1696	.1677
9	1.1736	.8383	.9389	.8421
10	1.2071	1.1797	1.0395	.9389
11	1.2407	1.1736	1.0059	.6706
12	.9054	1.2574	.8048	.7042
13	.9054	1.1736	.7712	.8139
14	.6706	1.2289	.7377	.9054
15	.8048		.7773	.9724
16	.8383		.8718	.8718
17	.1341	.1341	.1677	.1341
18	.1341	.1638	.1677	.1341
19	.1677	.1844	.1943	.2012
20	.2012	.2012	.2012	.2347
21	.2012	.2347	.1966	.2347
22	.2347	.2347	.2012	.2374
23	.2012	.3018	.2012	.2347
24	.9602	.2012	.3353	.1966
Max	1.2407	1.2574	1.0395	.9724
Min	.1341	.1341	.1677	.1341
Avg	.4885	.4534	.4395	.4222

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274069 / 33/11 KV MANJARI S/S

Feeder No / Name : 246 / 11 KV SAVE Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.3353	.4588	
2	.439	.3277	.4915	
3	.439	.3353	.5243	
4	.4359	.3688	.5243	
5	.4572	.3605	.503	
6	.3521	.4588	.4359	
7	.3201	.6036	.4359	
8	.2743	.3688	.4191	.2591
9	.2829	.3353	.3353	
10	.2743	.285	.285	
11	.2572	.285	.2683	
12	.2683	.3353	.2543	
13	.2713	.3353	.2012	
14	.2515		.1677	
15	.3185		.1638	
16	.3185		.1638	.3353
17	.3353	.1341	.1966	.3401
18	.3521	.1638	.2458	.3401
19	.3688	.2949	.3277	.3401
20	.4024	.3353	.3277	.3269
21	.4024	.4024	.3052	.407
22	.3688	.3353	.3018	.4024
23	.3353	.4096	.3018	.3563
24	.4572	.1638	.4917	.3018
Max	.4572	.6036	.5243	.407
Min	.2515	.1341	.1638	.2591
Avg	.3517	.3321	.3388	.3409

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274069 / 33/11 KV MANJARI S/S

Feeder No / Name : 247 / 11 KV Save AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5502	.8383	.5792	.8421
2	.5647	.8718	.8356	
3	.6783	.9221	1.0059	
4	.7969	1.291	1.2289	
5	1.1736	1.0059	1.3395	
6	1.3077	1.5729	1.3565	
7	1.3077	1.6221	1.5261	
8	1.291	1.6263	1.5893	1.3927
9	.0972	.1174	.1509	
10	.0914	.1006	.1006	
11	.1134	.1006	.1006	
12	.1174	.1006	.0972	
13	.1174	.1174	.0869	
14	.1006	.1509	.1006	
15	.1174		.1006	
16	.1174		.0869	.1619
17	.1341	.1677	.0972	.1677
18	.1509	.1966	.0857	.1619
19	.1865	.1844	.0983	.1677
20	.1802	.218	.1341	.1844
21	.1829	.213	.1677	.1781
22	.1829	.2458	.1677	.1943
23	.9724	.3353	.7385	.8421
24	.5502	1.0059	.503	.8097
Max	1.3077	1.6263	1.5893	1.3927
Min	.0914	.1006	.0857	.1619
Avg	.4618	.5911	.5116	.4639

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274110 / 33/11 KV ALEGAON S/S

Feeder No / Name : 241 / 11 KV Waki Gheradi Feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1296	.081	.2286		.3048	.3048	.3048
2	.1296	.081	.1524	.1524	.3048	.3048	.3048
3			.2286		.3048	.3048	.381
4			.2286		.3048	.3048	.4572
5			.4572		.3048	.381	.5335
6			.6097		.381	.6097	.6097
7			.7621		.4572	.7621	.7621
8			.8383	.1524	.5335	.8383	.7621
9	.2429	.6859					
10	.2429	.4572					
11	.3239	.381					
12	.3239						
13	.3048						
14	.3048						
15	.3048		.1134	.081	.081	.0972	.0972
16	.3048	.2286	.1134	.081	.081	.0972	.0972
17	.081	.2286	.1134			.0972	.1134
18	.081	.0972	.1134	.081	.081		.1134
19	.081	.1134	.1296	.081	.1134		.1296
20	.081		.1296	.081	.0972	.1134	.1296
21	.081	.1134	.1296	.0762	.081	.1134	.1296
22	.081	.0972	.1296	.0762	.081	.1296	.1296
23		.4572	.4572	.0762	.4572	.381	.4115
24	.1296	.081	.381	.381	.3048	.3048	.381
Max	.3239	.6859	.8383	.381	.5335	.8383	.7621
Min	.081	.081	.1134	.0762	.081	.0972	.0972
Avg	.1899	.2387	.2953	.1199	.2514	.3215	.3249



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274110 / 33/11 KV ALEGAON S/S

Feeder No / Name : 242 / 11 KV Alegaon Feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.6097	.1296	.1134	.1134	.1134	.1134
2	.6401	.6859	.1296	.1134	.1134	.1134	.1134
3	.6097	.9145					
4	.6097	.9907					
5	1.0669	1.2955					
6	1.9052	1.2955					
7	2.2862	1.5242					
8	1.6004	1.6766					
9			1.6766	.6097	1.829	1.6766	1.5242
10			1.7528	.8383	1.9814	1.5242	1.6004
11			1.5242	.9907	1.6766	.9907	1.2193
12			.9907	1.2193	1.5242	.9145	.9145
13				1.1431	1.3717	.8383	.945
14			1.2955	1.1431	1.3717	.7621	.945
15	.081		1.5242	1.2955	1.2193	.7621	1.2193
16	.081	.1619	1.9052	1.3717	1.829	.9907	1.5242
17	.081	.1619	.1134	.081			.1134
18	.081	.1619	.1134	.081	.1134	.1134	.1134
19	.1134	.1619	.1134	.1134		.1134	.1296
20	.1134	.1619	.1296	.1134	.1296	.1134	.1296
21	.1134	.1619	.1296	.1134	.1134	.1296	.1457
22	.1134	.0162	.1296	.1134	.1134	.1296	.1296
23		.1296	.1457	.1134	.1134	.1296	.1296
24	.6859	.6097	.1296	.1296	.1134	.1134	.1296
Max	2.2862	1.6766	1.9052	1.3717	1.9814	1.6766	1.6004
Min	.081	.0162	.1134	.081	.1134	.1134	.1134
Avg	.6366	.6306	.7019	.5387	.8579	.5605	.6188

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274110 / 33/11 KV ALEGAON S/S

Feeder No / Name : 243 / 11 KV Medshingi Feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.6249
Max	.6249
Min	.6249
Avg	.6249

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274110 / 33/11 KV ALEGAON S/S

Feeder No / Name : 244 / Alegaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3086	.2058	.2286	.3086	.2401	.2401
2	.2743	.3601	.2229	.2439	.3258	.2229	.2401
3	.2743	.4115	.2572	.2439	.3772	.2229	.2743
4	.2286	.4458	.3258	.2591	.4115	.2401	.3429
5	.2572	.4801	.3772	.3048	.463	.2572	.3772
6	.2915	.5144	.463	.381	.4973	.2915	.4115
7	.4973	.4458	.4801	.442	.4458	.3258	.4458
8	.2572	.3772	.4458	.3048	.3772	.3258	.3429
9	.2401	.2572	.2743	.2743	.2229		.2743
10	.2058	.2229	.2572	.2134	.2058	.2572	.2572
11	.1886	.2058	.1886	.1677	.1886	.1715	.2401
12	.1715		.1886	.1524	.2058	.2572	.2229
13	.1886			.1372	.2058		.2058
14	.1886		.2058	.1372	.2229	.2572	.1886
15	.2058		.2229	.1219	.1715		.1715
16	.2401	.1715	.2058	.1219	.2229		.1715
17	.2743	.1715	.2401	.1524			.2229
18		.2915	.2743	.1829	.2915		.3086
19	.2743	.3772	.3086	.2439	.3772		.3258
20	.3048	.3944	.3601	.2743		.4801	.4287
21	.2896	.3429	.3429	.2896	.2743	.3772	.4287
22	.2896	.2915	.2572	.2743	.2572	.3086	.4115
23		.2229	.2743	.2286	.2229	.2743	.3429
24	.3258	.2743	.2229	.2134	.2743	.2229	.2572
Max	.4973	.5144	.4801	.442	.4973	.4801	.4458
Min	.1715	.1715	.1886	.1219	.1715	.1715	.1715
Avg	.2626	.3284	.2870	.2331	.2977	.2784	.2972

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274110 / 33/11 KV ALEGAON S/S

Feeder No / Name : 245 / Wanichanchale AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2429	.1619	.9145	1.0669	1.3717	.9145	.5335
2	.2105	.1619	.6097	.7621	1.3717	1.0669	.6097
3			.6097	.6097	1.3717	1.2193	.823
4			.7621	.9145	1.5242	1.2193	.945
5			1.2193	1.1584	1.5242	1.3717	.9907
6			1.6766	1.5242	1.6766	1.3717	1.0669
7			2.0576	1.8747	1.6766	1.5242	1.2498
8			1.829	1.89	1.829	1.7528	1.326
9	.9717	1.5242					
10	1.0526	1.6004					
11	1.2146	1.5242					
12	1.3765						
13	.9907						
14	.6859						
15	.5335		.1296	.1619	.1134		.1296
16	.3048	1.448	.1134	.1619	.1457	.1619	.1296
17	.1619	1.3717	.1457	.1619		.1296	.1543
18	.1619	.1943	.1619	.1619	.2105		.2429
19	.1619	.2267	.1943	.1619	.2753		.2429
20	.1619	.2429	.2753	.1619	.2429	.2267	.2915
21	.1619	.1943	.2591	.1619	.2105	.1943	.2915
22	.1619	.1943	.2429	.1619	.1943	.2429	.2591
23		1.6004	1.3717	1.2193	1.3717	.6097	.9145
24	.2591	.1619	1.3717	1.3717	1.3717	1.0669	.4572
Max	1.3765	1.6004	2.0576	1.89	1.829	1.7528	1.326
Min	.1619	.1619	.1134	.1619	.1134	.1296	.1296
Avg	.5185	.7577	.7747	.7604	.9695	.8715	.5921

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274118 / 33/11 KV Y.MANGEWADI S/S

Feeder No / Name : 241 / 11 KV Watambare Feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.6249
Max	.6249
Min	.6249
Avg	.6249

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274118 / 33/11 KV Y.MANGEWADI S/S

Feeder No / Name : 242 / 11 KV Y.Mangewadi Feeder      SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.6249
Max	.6249
Min	.6249
Avg	.6249

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274118 / 33/11 KV Y.MANGEWADI S/S

Feeder No / Name : 243 / 11 KV Balwadi Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.7926
Max	.7926
Min	.7926
Avg	.7926

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274118 / 33/11 KV Y.MANGEWADI S/S

Feeder No / Name : 244 / 11 KV Ajnale Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.6249
Max	.6249
Min	.6249
Avg	.6249



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274118 / 33/11 KV Y.MANGEWADI S/S

Feeder No / Name : 245 / Ligadewadi feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.6249
Max	.6249
Min	.6249
Avg	.6249

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274118 / 33/11 KV Y.MANGEWADI S/S

Feeder No / Name : 246 / Kamlapur feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274137 / 33/11 kv Gaigavan sub  
stationFeeder No / Name : 241 / 11 KV Gaigavan Feeder  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-AUG-17
HR	Load (MW)
24	.7926
Max	.7926
Min	.7926
Avg	.7926

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274137 / 33/11 kv Gaigavan sub

station

Feeder No / Name : 242 / 11 KV Khilarwadi Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.9757	2.3805			.3801
16	.2534	.2172	1.7004		.2172
23	.583	.362	.3258		.4858
24	.7287	.664	.3439	.3258	1.004
Max	1.9757	2.3805	1.7004	.3258	1.004
Min	.2534	.2172	.3258	.3258	.2172
Avg	.8852	.9059	.7900	.3258	.5218

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274137 / 33/11 kv Gaigavan sub  
stationFeeder No / Name : 243 / 11 KV Dhalewadi Feeder  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6				1.5708		
8			1.6356			
16	1.2955	1.4737	.1086			
23	.2715	.4372	.4372			.2896
24	.381	.2353	.4858	.5182	.5182	
Max	1.2955	1.4737	1.6356	1.5708	.5182	.2896
Min	.2715	.2353	.1086	.5182	.5182	.2896
Avg	.6493	.7154	.6668	1.0445	.5182	.2896

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274137 / 33/11 kv Gaigavan sub  
stationFeeder No / Name : 244 / 11kv gaighavan gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6				2.0576		
8	.1334	.1372	.16			.1219
16	.1219	.0457	.0572		.061	.0762
23	.141	.0876	.0914		.0876	.0876
24	.381	.1562	.0838	.0914		.08
Max	.381	.1562	.16	2.0576	.0876	.1219
Min	.1219	.0457	.0572	.0914	.061	.0762
Avg	.1943	.1067	.0981	1.0745	.0743	.0914

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274154 / 33/11 KV Junoni S/Stn

Feeder No / Name : 241 / 11 KV Jujarpur Feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1296	.1595	.4915	.5407	.5243	.6226	.5898
2	.1296	.1402	.4915	.5426	.5735	.6062	.6226
3	.1296	.1595	.5079	.4588	.6062	.639	.6882
4	.1296	.1595	.6226	.7701	.6718	.6554	.7865
5	.1619	.2126	.7373	.9175	.8192	.7865	.9175
6	.2429	.2658	1.0159	1.1305	1.1961	1.1797	1.2616
7	.1781	.1928	1.2289	1.3108	1.4746	1.1142	1.278
8	.1457	.1227	1.278	1.1633	1.3435	1.3435	1.3435
9	1.0322	.9831	.124	.0972	.0886	.124	.1063
10	1.1797	1.2452	.1341	.081	.0914	.0886	.0838
11	1.2452	1.1797	.1341		.0914	.0876	.0838
12	1.278	1.1961	.1341		.0914	.0655	.0848
13	1.1961	1.1469	.1341		.0914	.0709	.0678
14	1.2289	1.0978	.1174		.0732	.0732	.0678
15	1.065	1.0814	.1174	.0648	.0732	.0732	.0678
16	1.0159	1.1961	.1341	.0648	.0732	.0709	.0678
17	.1463	.0709	.0838	.0648	.0886	.0709	.0671
18	.1063	.1063	.0838	.0972	.1063	.0709	.1006
19	.1417	.1417	.1341	.1457	.1417	.124	.1341
20	.1928	.1949	.1844	.1943	.1949		.2012
21	.1753	.1949	.1677	.1943	.1949	.1949	.1844
22	.1772	.1772	.1509	.1619	.1646	.1928	.1509
23	.1595	.3953	.4752	.4049	.6554	.5735	.5304
24	.1296	.1595	.4588	.4915	.4915	.6226	.6226
Max	1.278	1.2452	1.278	1.3108	1.4746	1.3435	1.3435
Min	.1063	.0709	.0838	.0648	.0732	.0655	.0671
Avg	.4882	.4992	.3809	.4448	.4134	.4109	.4212

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274154 / 33/11 KV Junoni S/Stn

Feeder No / Name : 242 / 11 KV Junoni Feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0162	.0183	.1311	.1296	.0819	.1311	.1311
2	.0162	.0366	.1147	.1296	.0819	.0983	.0983
3	.0162	.0183	.1311	.1134	.0819	.1147	.1311
4	.0162	.0366	.1311	.1619	.1147	.1638	.1638
5	.0162	.0366	.1311	.2105	.1802	.1966	.1638
6	.0324	.0366	.1638	.2915	.213	.2294	.1966
7	.0324	.0366	.2294	.3239	.2785	.2785	.2458
8		.0183	.1966	.2915	.2458	.3277	.2949
9	.2214	.2458	.0183	.0324	.0183	.0183	.0183
10	.2622	.213	.0162	.0162	.0183	.0183	.0162
11	.1966	.2214	.0162	.0162	.0183	.0177	.0162
12	.2458	.2622	.0162	.0162	.0183	.0183	.0162
13	.2458	.2372	.0162	.0162		.0183	.0162
14	.2294	.2294	.0162	.0162	.0183	.0183	.0162
15	.2785	.2622	.0162	.0162	.0183	.0366	.0162
16	.2294	.2458	.0324	.0162	.0177	.0366	.0162
17	.0183	.0183	.0162	.0162	.0183	.0183	.0162
18	.0366	.0177	.0324	.0162	.0183	.0177	.0162
19	.0366	.0549	.0324	.0324	.0366	.0183	.0324
20	.0549	.0709	.0324	.0324	.0549		.0324
21	.0366	.0549	.0324	.0324	.0549	.0366	.0324
22	.0366	.0366	.0324	.0324	.0549	.0354	.0162
23	.0366	.1147	.0972	.0486	.1147	.1311	.0972
24	.6249	.0366	.1311	.1134	.0791	.0983	.1311
Max	.6249	.2622	.2294	.3239	.2785	.3277	.2949
Min	.0162	.0177	.0162	.0162	.0177	.0177	.0162
Avg	.1277	.1066	.0743	.0884	.0799	.0904	.0805



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274154 / 33/11 KV Junoni S/Stn

Feeder No / Name : 243 / 11 KV H.Mangewadi feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8421	.6554	.1949	.218	.2303	.1772	.2103
2	.8907	.6554	.1949	.2204	.2126	.1772	.2103
3	.9231	.6882	.2126	.1865	.2103	.1949	.1949
4	.9878	.7209	.2481	.2347	.2126	.2126	.2103
5	1.085	.9175	.2629	.2515	.2481	.2481	.2401
6	1.4251	1.4255	.3429	.3018	.3086	.3155	.2915
7	1.6194	1.7204	.2629	.2683	.2572	.2658	.2454
8	1.4737	1.3435	.2303	.2012	.1928	.2126	.1772
9	.124	.1595	1.2289	1.5546	1.3435	1.3599	.1966
10	.124	.124	.6226	1.4575	1.4746	1.6221	.1006
11	.1063	.124	.6226	1.4575	1.4746	1.0814	1.5565
12	.124	.124	.6478	1.4575	.8192	1.4582	1.5729
13	.124	.1063	.6154	1.4575		1.5074	1.5238
14	.124	.124	.6554	1.4575	1.5402	1.4582	1.5402
15	.124	.1063	.6882	1.4575	1.4746	1.3927	1.5565
16	.124	.124	1.1797	1.4575	1.4419	1.5238	1.3272
17	.1417	.124	.1509	.1134	.1417	.1417	.1006
18	.124	.1063	.1677	.1619	.1595	.124	.1357
19	.2103	.1949	.218	.1981	.2126	.1595	.1696
20	.2835	.2835	.3018	.2429	.2743		.2683
21	.2658	.2658	.2683	.2429	.2743	.2481	.2515
22	.2454	.2303	.2515	.2429	.2401	.2481	.2347
23	.7373	.2103	.2515	.2105	.2103	.2126	.2012
24	.8421	.6882	.1949	.2347	.2303	.1949	.2126
Max	1.6194	1.7204	1.2289	1.5546	1.5402	1.6221	1.5729
Min	.1063	.1063	.1509	.1134	.1417	.124	.1006
Avg	.5446	.4676	.4173	.6370	.5732	.6320	.5304

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274154 / 33/11 KV Junoni S/Stn

Feeder No / Name : 244 / 11 KV JUNONI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1772	.1753	.1526	.1772	.1772	.1928
2	.1543	.1772	.1772	.1526	.1772	.1772	.1928
3	.1543	.1949	.1928	.1509	.1753	.2103	.2103
4	.1543	.2126	.2126	.1865	.2126	.2454	.2058
5	.1886	.2481	.2254	.2204	.2658	.2743	.2229
6	.2572	.2835	.2743	.3185	.2915	.3086	.3086
7	.2915	.2103	.2743	.2347	.2572	.2427	.2915
8	.2105	.1753	.1949	.2012	.2229	.2058	.2103
9	.1886	.1753	.1417	.2058	.2126	.2279	.1417
10	.1772	.1595	.1696	.1715	.2058	.1886	.2543
11	.1772	.1753	.1509	.1715	.1886	.1886	.2035
12	.1753	.1772	.1509	.1715	.1753	.2058	.1865
13	.1753		.1341	.1715	.1949	.2481	.1677
14	.1772		.1341	.1715	.1753	.2303	.1509
15	.1772		.1187	.1715	.1772	.2279	.1677
16	.1772		.1357		.1949	.2303	.1677
17	.2303	.2279	.1187		.2303	.2103	.1677
18	.2279	.2126	.1357		.2481	.2103	.1844
19	.2743	.298	.2515	.2915	.2835	.2229	.218
20	.3258	.3506	.3353	.3086	.3258		.2984
21	.2804	.2915	.2713	.3086	.2835	.3189	.2683
22	.2454	.2658	.2374	.2058	.2454	.2572	.2515
23	.1928	.2126	.1865	.1715	.2126	.2229	.2204
24	.1715	.1949	.1949	.1696	.1772	.1949	.2126
Max	.3258	.3506	.3353	.3185	.3258	.3189	.3086
Min	.1543	.1595	.1187	.1509	.1753	.1772	.1417
Avg	.2065	.2210	.1914	.2051	.2213	.2272	.2123

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274166 / 33/11 KV Chopadi Sub-Station

Feeder No / Name : 241 / Chopadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1543	.1543	.1619	.1543	.1543	.1543
2	.1715	.1715	.1715	.1943	.1715	.1715	.1715
3	.1886	.2058	.1886	.2267	.2058	.2058	.1886
4	.2229	.2572	.2401	.2429	.2401	.2229	.2229
5	.2572	.2915	.2572	.2753	.2572	.2572	.2572
6	.3086	.3258	.2915	.3258	.3086	.2915	.2915
7	.2915	.2915	.2915	.3429	.3086	.2743	.2743
8	.2229	.2401	.2229	.2401	.2572	.2572	.2229
9	.2743	.1886	.2743	.2743	.2572	.2572	.2572
10	.2743	.2429	.2229	.2915	.2401	.2743	.2401
11	.2229	.2105	.2229	.2743	.2229	.2401	.2743
12	.2058	.1781	.1886	.2058	.1029	.2058	.2401
13	.1715	.1619	.1715	.1715	.1715	.1715	.1886
14	.1715	.1457	.1715	.1886	.1543	.1543	.1715
15	.1886	.1457	.2058	.1715	.1715	.1543	.1715
16	.2058	.1457	.2058	.1715	.2058	.1715	.2229
17	.2572	.2058	.2058	.2743	.1886	.2743	.2229
18	.2743	.2572	.2401	.2058	.2743	.2401	.2572
19	.2915	.2572	.2401	.3086	.2743	.2743	.3258
20	.3601	.3258	.3601	.3258	.3601	.3772	.3601
21	.3429	.2743	.2572	.2743	.2743	.3258	.2401
22	.3429	.2743	.2572	.2572	.2401	.2572	.2743
23	.1886	.1886	.1715	.2058	.1715	.2058	.1886
24	.1715	.1715	.1715	.1715	.1715	.1715	.1715
Max	.3601	.3258	.3601	.3429	.3601	.3772	.3601
Min	.1543	.1457	.1543	.1619	.1029	.1543	.1543
Avg	.2401	.2213	.2244	.2409	.2243	.2329	.2329

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274166 / 33/11 KV Chopadi Sub-Station

Feeder No / Name : 242 / balwadi feeder

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.421	.3887	1.2146	1.2631	1.2146	1.2955	.3725
2	.4696	.4858	1.3603	1.4251	1.2955	1.3765	.4049
3	.5182	.5182	1.4251	1.5223	1.3765	1.4575	.4372
4	.5506	.5668	1.5384	1.6194	1.6032	1.6194	.4696
5	.5668	.6154	1.6194	1.8623	1.7814	1.8623	.5182
6	.5992	.6802	1.7652	1.9757	1.9109	1.9919	.5992
7	.5992	.5668	2.2672	2.4777	2.5425	2.3805	.5506
8	.4858	.4696	2.4129	2.4453	2.1862	2.4129	.4858
9	2.3482	2.1052	.3563	.3239	.3401	.3563	2.2186
10	2.3482	2.3644	.2915	.3077	.3077	.3077	2.1214
11	2.1052	1.9433	.2753	.2915	.3239	.2915	1.6842
12	2.0081	1.9271	.3401	.2915	.3239	.3077	1.8947
13	1.9919	1.9757	.3563	.3239	.2267	.2591	1.5384
14	2.0729	1.7814	.3077	.3077	.3239	.2753	1.7004
15	1.9271	2.0729	.2915	.3077	.3077	.2591	1.8138
16	2.0243	2.251	.3239	.2753	.2753	.2429	1.9271
17	.3239	.3563	.3887	.3239	.3239	.3239	.3077
18	.4049	.4534	.4049	.421	.3563	.421	.3563
19	.4858	.4696	.4534	.4372	.4049	.4696	.4372
20	.5668	.5344	.5344	.5344	.5506	.5668	.583
21	.5344	.502	.502	.502	.5344	.5506	.5182
22	.4858	.4372	.4696	.4696	.4858	.502	.502
23	.3887	1.4575	1.4737	1.6518	1.6194	.3887	.3887
24	.3725	.4049	1.247	1.2793	1.2631	1.3279	.3563
Max	2.3482	2.3644	2.4129	2.4777	2.5425	2.4129	2.2186
Min	.3239	.3563	.2753	.2753	.2267	.2429	.3077
Avg	1.0250	1.0553	.9008	.9433	.9116	.8853	.9244

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274166 / 33/11 KV Chopadi Sub-Station

Feeder No / Name : 243 / BANDGARWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5992	.6478	.1296	.1457	.1134	.0972	.4696
2	.6478	.7287	.1619	.1619	.1457	.1134	.5344
3	.7287	.7611	.1943	.1781	.1619	.1619	.5668
4	.7935	.8097	.2267	.2105	.1943	.1943	.6316
5	.8421	.8421	.2429	.2267	.2267	.2267	.6802
6	.8583	.8907	.2915	.2591	.2591	.2591	.7287
7	.9069	1.0526	.2429	.2429	.2429	.2267	.9555
8	.7773	.9555	.1619	.1781	.1781	.1619	.9555
9	.1134	.1134	.8259	.8421	.7287	.7773	.081
10	.081	.0648	.8745	.8097	.8745	.7287	.081
11	.0648	.0486	.7611	.7935	.7935	.6964	.0648
12	.081	.0486	.7611	.7287	.6802	.6478	.0486
13	.0972	.0648	.7449	.7287	.7287	.664	.0648
14	.0648	.0486	.5506	.664	.6802	.6802	.0972
15	.0648	.0648	.7449	.6964	.6316	.6478	.0648
16	.081	.081	.8259	.7125	.7935	.7611	.0972
17	.081	.0486	.0648	.081	.0486	.081	.0648
18	.1134	.0648	.0972	.1134	.1134	.081	.1296
19	.1457	.1457	.1296	.1296	.1619		.1457
20	.1781	.1781	.1619	.1619	.1943		.1781
21	.1457	.1296	.1296	.1134	.1457		.1296
22	.1619	.1134	.1134	.1134	.1134		.1134
23	.5992	.0972	.0972	.0972	.0972	.4534	.5506
24	.5182	.4858	.1457	.1296	.1296	.0972	.502
Max	.9069	1.0526	.8745	.8421	.8745	.7773	.9555
Min	.0648	.0486	.0648	.081	.0486	.081	.0486
Avg	.3644	.3536	.3617	.3549	.3515	.3879	.3306

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274166 / 33/11 KV Chopadi Sub-Station

Feeder No / Name : 244 / chopadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7611	.7125	.1619	.1781	.1619	.1457	.7287
2	.7773	.7611	.1943	.2105	.1781	.1781	.7449
3	.8097	.8097	.2429	.2429	.2105	.2105	.8745
4	.8583	.8421	.2915	.2915	.2915	.2429	.9231
5	.8907	.9231	.3239	.3239	.3239	.3239	1.004
6	.9717	1.0364	.4049	.3725	.4049	.3887	1.0688
7	1.4899	1.3603	.3563	.4049	.4049	.3887	1.2955
8	1.247	1.2955	.2753	.2591	.2429	.2753	1.2146
9	.1296	.1619	1.247	1.0364	1.2146	1.1822	.0972
10	.081	.0972	1.4737	1.1984	1.3279	1.2631	.1134
11	.0648	.081	1.2955	1.2631	1.2955	1.2955	.081
12	.0486	.081	1.3441	1.1984	1.3279	1.2793	.1296
13	.0972	.0972	1.3279	1.1822	1.1984	1.1984	.0972
14	.0972	.0972	.8745	1.1822	1.2146	1.1822	.0972
15	.0972	.1134	1.0688	1.1984	1.2308	1.166	.081
16	.1457	.1296	1.085	1.2631	1.2631	1.0526	.1296
17	.0972	.1296	.0972	.1134	.1296	.1296	.1619
18	.1619	.1619	.1619	.1619	.1457	.1619	.1619
19	.2753	.1943	.2429	.2429	.2429	.2267	.2591
20	.2915	.3077	.3077	.3239	.2915	.2915	.2753
21	.2429	.2429	.2429	.2591	.2267	.2591	.2105
22	.2267	.1781	.1943	.1943	.1943	.2267	.1943
23	.8745	.1619	.1619	.1781	.1619	.7773	.7611
24	.7125	.7287	.1943	.1619	.1619	.1619	.7611
Max	1.4899	1.3603	1.4737	1.2631	1.3279	1.2955	1.2955
Min	.0486	.081	.0972	.1134	.1296	.1296	.081
Avg	.4771	.4460	.5654	.5600	.5769	.5837	.4777

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274169 / 33/11 KV Wadegaon Sub-  
Station

Feeder No / Name : 241 / Wadegaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1372	.1372	.0972	.0914	.1029	.0914
2	.1372	.1372	.1372	.0972	.0914	.1029	.0914
3	.1372	.1372	.1372	.1296	.0914	.1029	.0914
4	.1372	.1372	.1372	.1619	.1219	.1543	.1219
5	.2058	.2058	.2229	.2267	.1524	.2058	.1524
6	.3086	.2915	.3086	.2915	.2743	.3258	.2743
7	.2915	.2572	.2401	.2429	.2286	.2743	.2286
8	.1715	.1543	.1886	.1619	.1524	.2058	.1677
9	.1067	.1219	.12	.12	.1372		.1457
10	.0914	.0914	.12	.12	.12	.1296	.1296
11	.0762	.0457	.1029	.0857	.1029	.0972	.1134
12	.0762	.0762	.0857	.12	.1029	.0972	.081
13	.0762	.0762	.0857	.0857	.1029	.081	.0972
14	.0762		.0857	.0857	.1029	.081	.1296
15	.0914		.0857	.0686	.1029	.0476	.1134
16	.0914	.0914	.0857	.12	.1029	.081	.1134
17	.0972	.0972	.1134	.1296	.1029	.0857	.12
18	.0972	.1457	.1619	.1457	.1372	.12	.12
19	.1781	.1943	.2105	.1781	.1715	.2058	.1715
20	.2429	.2267	.2267	.2105	.2401	.2401	.2229
21	.1886	.1781	.1619	.1943	.2058	.2058	.1886
22	.1372	.1715	.1619	.1619	.1715	.1715	.1457
23	.1372	.1372	.1372	.1219	.1543	.1372	.1219
24	.1372	.1372	.1372	.0972	.0914	.1029	.0914
Max	.3086	.2915	.3086	.2915	.2743	.3258	.2743
Min	.0762	.0457	.0857	.0686	.0914	.0476	.081
Avg	.1428	.1477	.1496	.1439	.1397	.1460	.1385

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274169 / 33/11 KV Wadegaon Sub-  
StationFeeder No / Name : 243 / DIGHEMALA FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.3086	.6401	.8002	.9335	.9069	.8669
2	.2743	.3086	.6401	.8002	.9335	.9335	.8669
3			.6401	.9602	.9335	.9869	.8669
4			.6706	1.0669	1.0669	1.0669	.9335
5			.9145	1.1336	1.2269	1.0669	1.0402
6			1.448	1.2003	1.3336	1.1336	1.2003
7			1.9052	1.5337	1.7337	1.6671	1.6671
8			1.6461	1.6671	1.6671	1.7337	1.7337
9	1.4003	1.467					
10	1.347	1.4137					
11	1.267	1.0002					
12	1.2136	1.2403					
13	1.2269	1.1736					
14	1.0669						
15			.2401	.2401	.2572	.2267	.2591
16	1.1336	1.0936	.2915	.2915	.2743	.2591	.2753
17	.2267	.2591	.3077	.3077	.3086	.3086	.3429
18	.2915	.3239	.3401	.3563	.3772	.3944	.3429
19	.3563	.421	.421	.3887	.4801	.463	.4287
20	.4534	.4858	.4534	.4534	.4458	.4458	.4287
21	.4115	.3887	.421	.3401	.3601	.4115	.3944
22	.3086	.3258	.3077	.3239	.3239	.3944	.3401
23	.3086	.6859	.884	.8802	.8669	.8002	.8002
24	.2743	.3086	.4001	.8002	.9335	.9069	.8669
Max	1.4003	1.467	1.9052	1.6671	1.7337	1.7337	1.7337
Min	.2267	.2591	.2401	.2401	.2572	.2267	.2591
Avg	.6962	.7003	.6984	.7525	.8031	.7837	.7586



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274169 / 33/11 KV Wadegaon Sub-  
StationFeeder No / Name : 244 / BURLEWADI FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2572	.2058	.1943	.1829
2			.2572	.2058	.1943	.1829
9			.8993	.7773	.7468	.8097
10			.7773	.823	.7468	.7611
11			.7316	.7011	.6706	.7611
12			.6401	.6097	.4877	.7287
13			.5792	.5792	.5639	.6478
14			.5792	.5944	.5639	.6478
15			.6097	.5487	.5792	.583
16			.7316	.7773	.7773	.7287
17		.2429	.1715	.1715	.1715	.1372
18		.2753	.1886	.1981	.2058	.2058
19		.3077	.3258	.2743	.3086	.2572
20		.3401	.3601	.3429	.2915	.2743
21			.3258	.3086	.2915	.2572
22			.2572	.2915	.2429	.2401
23			.2572	.2572	.2267	.2105
24	1.2498		.2572	.2058	.1943	.1829
Max	1.2498	.3401	.8993	.823	.7773	.8097
Min	1.2498	.2429	.1715	.1715	.1715	.1372
Avg	1.2498	.2915	.4559	.4373	.4143	.4333

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274170 / 33/11 KV Akola Sub-Station

Feeder No / Name : 241 / Akola SSTn Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.3429	.3601	.3429	.3601	.3772	.3429	.3429
8	.4458	.463	.5144	.5658	.3772	.4973	.5144
12	.2743	.3429	.2915	.3086	.3086	.2915	.3086
16	.3601	.3429	.3258	.3086	.3429	.2743	.3258
20	.5144	.583	.5658	.5487	.6344	.5316	.5316
24	.3429	.3429	.3429	.3258	.3086	.3086	.3086
Max	.5144	.583	.5658	.5658	.6344	.5316	.5316
Min	.2743	.3429	.2915	.3086	.3086	.2743	.3086
Avg	.3801	.4058	.3972	.4029	.3915	.3744	.3887

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274170 / 33/11 KV Akola Sub-Station

Feeder No / Name : 246 / DATT MANDIR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.2058	.2058	1.0117	.8745	.9602	.1543	.1543
8	.2058	.2058	1.7318	1.7147	1.5775	.2572	.2401
12	.8573	1.166	.0857	.12	.1029	1.2003	1.0631
16	1.0974	1.0117	.0857	.12	.12	1.5089	1.1831
20	.2401	.2401	.2229	.2743	.2401	.2229	.2229
23					.12		
24	.1715	.1715	.9431	.9431	.9259	.1029	.1029
Max	1.0974	1.166	1.7318	1.7147	1.5775	1.5089	1.1831
Min	.1715	.1715	.0857	.12	.1029	.1029	.1029
Avg	.4630	.5002	.6802	.6744	.5781	.5744	.4944

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274170 / 33/11 KV Akola Sub-Station

Feeder No / Name : 247 / SOMNATH MANDIR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.6173	.6173	.1715	.1715	.2229	.463	.463
8	1.3032	1.4575	.2058	.2229	.2743	1.2689	1.3032
12	.1372	.12	.8059	.8402	.583	.12	.1029
16	.1029	.12	1.1145	.9774	.9602	.1029	.12
20	.2401	.2229	.2401	.2401	.2401	.1886	.1886
24	.6859	.6516	.1715	.1715	.1715	.4801	.463
Max	1.3032	1.4575	1.1145	.9774	.9602	1.2689	1.3032
Min	.1029	.12	.1715	.1715	.1715	.1029	.1029
Avg	.5144	.5316	.4516	.4373	.4087	.4373	.4401

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274170 / 33/11 KV Akola Sub-Station

Feeder No / Name : 248 / AKOLA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.7202	.6859	.2058	.1372	.2229	.5658	.6516
8	1.0802	1.3203	.2401	.2915	.2743	1.2346	1.3203
12	.12	.12	.823	.9945	.8573	.1029	.1372
16	.12	.1543	1.1317	1.1145	1.0974	.1372	.1372
20	.2572	.2915	.2743	.3086	.3086	.2743	.2743
24	.8573	.8573	.2058	.1886	.1715	.6859	.6173
Max	1.0802	1.3203	1.1317	1.1145	1.0974	1.2346	1.3203
Min	.12	.12	.2058	.1372	.1715	.1029	.1372
Avg	.5258	.5716	.4801	.5058	.4887	.5001	.5230

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274172 / 33/11 kv KATAFAL SUBSTATION

Feeder No / Name : 201 / 11 KV KATAFAL

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1802	.1802	2.2939	2.9843	3.4705	.2012	.2012
2	.1638	.1638	2.4086	2.9508	3.2693	.1844	.1677
3	.1638	.1966	2.4741	2.934	3.2693	.1844	.1844
4	.1966	.2294	2.7035		3.0011	.2012	.285
5	.2622	.2785	2.8182		3.0178	.2515	.3521
6	.3277	.4096	3.0639		3.0849	.3521	.3856
7	.2949	.3932			3.3699	.3688	.3353
8	.2622	.3113			3.0849	.3185	.2515
9	3.4899			.1844	.2012	3.1017	3.3699
10	3.2278			.1509	.1341	3.6046	3.5376
11	3.7029	2.6871	.1966	.1174			
12	3.6702		.1802	.1006			3.7891
13		3.7521	.1802	.1006	.1509		
14		3.5883	.1311	.1174	.1341	3.8394	2.6993
15	.1802	3.6374	.1475		.1677	2.934	2.8334
16	.1475	3.1786	.1638	.1174	.1475	3.1017	2.5987
17	.1638	.1475	.1638	.1341	.1844	.1509	.1509
18	.1966		.2012	.1677	.2012	.1677	.1677
19	.2949		.2515	.1677	.2286		.1844
20	.3441	.2949	.285	.2683	.285	.3018	.1844
21	.2785	.2294	.2515	.2347	.2347	.2683	.1677
22	.2622	.1966	.2012	.218	.2347	.2347	.1509
23	.2294	2.1628	2.9675	3.0849	.2012	.218	.1341
24	.1802	.213	2.2611	2.9675	3.5208	.1844	.218
Max	3.7029	3.7521	3.0639	3.0849	3.5208	3.8394	3.7891
Min	.1475	.1475	.1311	.1006	.1341	.1509	.1341
Avg	.8282	1.1711	1.1672	.9445	1.4361	1.0085	1.0159

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274172 / 33/11 kv KATAFAL SUBSTATION

Feeder No / Name : 202 / 11 KV ITAKI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4374	.4218	.0625	.064	.048	.4801	.4001
2	.4374	.4531	.0469	.048	.048	.5121	.3201
3	.4531	.4687	.0469	.064	.064	.5601	.3841
4	.4687	.5155	.0781		.08	.6081	.4961
5	.5624	.6093	.0781	.096	.096	.6401	.6081
6	.6874	.6718	.0937	.112	.112	.7202	.7842
7	.828	.7655		.128	.096	.7522	.8482
8	.703	.7186			.032	.7682	.6401
9	.1406	.0625		.5601	.3041	.064	.048
10	.0469	.0469		.7842	.4481	.064	.064
11	.0312	.0469	.7499	.7042		.032	.032
12	.0312	.0312	.6405	.6241		.048	.032
13	.0312	.0312	.5937	.6562	.8002	.032	.048
14	.0312	.0312	.7499	.6722	.8322	.032	.032
15	.0312	.0312	.5155		.8162	.037	.032
16	.0312	.0312	.4843	.6241	.6562	.032	.032
17	.0312	.0312	.0469	.032	.048	.032	.032
18	.125		.0633	.048	.048	.048	.048
19	.1562		.0791	.08	.096	.064	.08
20	.1094	.1094	.128	.112	.128	.096	.08
21	.0781	.0781	.096	.08	.096	.08	.08
22	.0781	.0781	.064	.064	.08	.08	.08
23	.4218	.0625	.064	.064	.4961	.4641	.3681
24	.4218	.3906	.0625	.064	.048	.3841	.4961
Max	.828	.7655	.7499	.7842	.8322	.7682	.8482
Min	.0312	.0312	.0469	.032	.032	.032	.032
Avg	.2656	.2585	.2372	.2705	.2488	.2763	.2527

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274172 / 33/11 kv KATAFAL SUBSTATION

Feeder No / Name : 203 / KATAFAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1294	.1109	.1294	.1294	.1109	.1109	.1294
2	.1109	.0924	.1109	.1109	.1294	.1109	.1109
3	.1109	.0739	.1478	.1294	.0924	.1109	.1109
4	.1294	.0924	.1663		.1294	.1294	.1478
5	.1848	.1478	.1848	.1294	.1663	.1663	.1848
6	.2402	.2402	.2218	.2218	.2033	.2218	.2033
7	.1848	.2587		.2587	.2218	.2402	.2218
8	.1663	.2033			.1478	.1848	.1663
9	.1478	.1663		.1663	.1478	.1663	.1294
10	.1109	.0739		.1294	.0924	.1478	.1109
11		.0924	.1478	.1663		.1478	.1109
12	.0554	.1109	.1109	.1109		.1294	.1109
13	.0924	.0739	.1109	.0924	.1478	.1294	.0924
14	.1109	.0554	.1109	.1294	.1294	.1294	.0739
15	.1109	.0924	.0924		.1294	.0924	.0739
16	.1109	.0924	.1109	.0924	.1294	.0739	.0554
17	.1109	.0739	.1478	.0924	.1663	.0739	.0924
18	.1478		.1663	.1478	.1663	.0924	.1294
19	.1848		.1294	.1848	.2033	.1663	.1478
20	.1663	.1848	.2402	.2033	.2402	.2033	.1478
21	.2033	.2218	.2033	.1848	.2033	.1848	.1294
22	.1663	.1478	.1663	.1478	.1663	.1663	.1109
23	.1478	.1294	.1294	.1294	.1294	.1478	.0924
24	.1294	.1109	.1109	.1294	.1109	.1109	.1478
Max	.2402	.2587	.2402	.2587	.2402	.2402	.2218
Min	.0554	.0554	.0924	.0924	.0924	.0739	.0554
Avg	.1414	.1294	.1469	.1470	.1529	.1432	.1263



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274173 / NIJAMPUR(MANEGAON)

Feeder No / Name : 244 / MANEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274173 / NIJAMPUR(MANEGAON)

Feeder No / Name : 249 / NIJAMPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.6401
Max	.6401
Min	.6401
Avg	.6401

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274173 / NIJAMPUR(MANEGAON)

Feeder No / Name : 251 / DONGARGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
23	.6401
Max	.6401
Min	.6401
Avg	.6401

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274178 / SHIVANE

Feeder No / Name : 241 / SHIVANE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288						
2	1.0288						
3	1.0288						
4	1.1488	1.0974	.3086	.3429	.4458	.4287	.4115
5	1.3203						
6	1.8519						
7	2.0233						
8	1.8004	1.8861		.4458			
12	.12	.2572	1.6461		1.6804	1.3717	1.5261
16	.2401	.2229	1.2003	1.6289	1.6118	1.4575	1.5432
20	.463	.4458	.4801	.5316	.5144	.4115	.4115
23	.9945	.3429	.3429	.3601	.3772	.4115	.3601
24	1.0288	1.046	.3429	.3429	.3601	.4115	.3944
Max	2.0233	1.8861	1.6461	1.6289	1.6804	1.4575	1.5432
Min	.12	.2229	.3086	.3429	.3601	.4115	.3601
Avg	1.0829	.7569	.7202	.6087	.8316	.7487	.7745

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274178 / SHIVANE

Feeder No / Name : 242 / WAKI SHIVANE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3593						
2	.3437						
3	.3437						
4	.3593	.3906	.8745	.3239	1.004	1.1336	1.5546
5	.3906						
6	.5468						
7	.578						
8	.4687	.4062		1.6356	1.7166	1.8785	1.587
12	1.4529	1.3904	.3239	.2429	.2915	.2429	.3239
16		1.3123	.3563	.2591	.3258	.3401	.3401
20	.5155	.4062	.4858	.421	.5182	.4696	.4858
23	.3906	.8124	.8421	.9231	.9717	1.5384	1.5708
24	.3749	.3749	.8421	.8907	.9069	1.0526	1.5384
Max	1.4529	1.3904	.8745	1.6356	1.7166	1.8785	1.587
Min	.3437	.3749	.3239	.2429	.2915	.2429	.3239
Avg	.5103	.7276	.6208	.6709	.8192	.9508	1.0572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274178 / SHIVANE

Feeder No / Name : 243 / GALVEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1107						
2	.1107						
3	.1265						
4	.1423	.1265	.8916	.3429	1.0802	1.0288	.9259
5	.1581						
6	.2056						
7	.1739						
8	.1423	.1898		1.3032	1.3032	1.5261	1.2003
12	1.186	1.1544	.1029	.0686	.1029	.0857	.0857
16	.4111	.9962	.12	.0857	.1029	.0857	.1029
20	.1581	.1581	.1543	.1715	.1715	.12	.1372
23	.1107	.6167	.4458	.9259	.9259		.823
24	.0949	.1107	.6859	.5144	1.0288	.9602	.9259
Max	1.186	1.1544	.8916	1.3032	1.3032	1.5261	1.2003
Min	.0949	.1107	.1029	.0686	.1029	.0857	.0857
Avg	.2408	.4789	.4001	.4875	.6736	.6344	.6001

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274190 / 33/11 kV Diksal

Feeder No / Name : 202 / 11 kV Pare Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3077	.3563	.0486	.0486	.0486	.2267	.2267
2	.3401	.3239	.0486	.0486	.0486	.2105	.2267
3	.2429	.2429				.2267	.2105
4	.3239	.2429				.3239	.3239
5	.4858	.1943				.3563	.3563
6	.6802	.1943				.3725	.3887
7	.4372	.2429				.5182	.4858
8	.4858	.1943				.502	.4696
9			.4372		.583		
10			.5182		.5344		
11			.3887		.4858		
12			.3563		.4372		
13			.3401		.4372		
14			.3401		.421		
15	.0162	.0162	.3401	.421	.4372	.0162	.0162
16	.0162	.0324	.3887	.4534	.5182	.0324	.0324
17	.0324	.0486	.0324	.0324	.0324	.0324	.0324
18	.0486	.0469	.0486	.0486	.0486	.0486	.0486
19	.0648	.0648	.0648	.0648	.0648	.0648	.0648
20	.081	.081	.081	.081	.081	.081	.081
21	.0648	.0648	.0648	.0648	.0648	.081	.0648
22	.0486	.0648	.0648	.0486	.0486	.0648	.0486
23	.3887	.0486	.0486	.0486	.2429	.2429	.2267
24	.6249	.4372	.0486	.0486	.0486	.2429	.2267
Max	.6802	.4372	.5182	.4534	.583	.5182	.4858
Min	.0162	.0162	.0324	.0324	.0324	.0162	.0162
Avg	.2605	.1610	.2033	.1174	.2546	.2024	.1961

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274216 / Sangola Urban

Feeder No / Name : 212 / 11 KV Sangola Pandharpur  
Road Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-AUG-17
HR	Load (MW)
24	.6401
Max	.6401
Min	.6401
Avg	.6401



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 276009 / 132/33/11 KV SANGOLA S/S

Feeder No / Name : 271 / 11 KV SANGOLA U

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.3506	.3048	.3048		.3944	.4115
2	.3506	.3353	.3048	.2286		.3772	.3944
3	.3048	.3201	.2286	.2286		.3601	.3772
4	.2896	.3201	.3048	.2286		.3429	.3429
5	.3048	.3506	.3048	.3048		.3429	
6	.3353	.381	.381	.381		.3601	.3772
7	.3506	.4115	.381	.4572		.3772	.3944
8	.3506	.381	.381	.3353		.4115	.3944
9	.4115	.3506	.3201	.381		.3429	.3429
10		.3658	.3353	.3048		.3944	.4287
11	.381		.3506	.381		.3601	.3429
12	.3963		.3658	.3048		.4287	.3429
13	.3353		.3506	.381		.3944	.3601
14	.3048		.3201	.3048		.4287	.2572
15	.3506		.3048	.381		.3944	.2572
16	.2896		.2743	.3353		.3772	.2743
17	.3353	.3353	.2896	.3048		.3086	.2915
18	.2743	.3353	.3048	.3048		.3429	.3429
19	.3048	.3658	.3353	.381		.3258	.3429
20	.3658	.381	.3506	.381		.3258	.4287
21	.3506	.4268	.3658	.381		.3772	.4287
22	.3201	.3963	.3658	.381		.3601	.4287
23	.3353	.3506	.3506	.3506		.3601	.4115
24	.381	.3506	.3353	.3201	.3201	.3944	.4115
Max	.4115	.4268	.381	.4572	.3201	.4287	.4287
Min	.2743	.3201	.2286	.2286	.3201	.3086	.2572
Avg	.3386	.3616	.3296	.3353	.3201	.3701	.3645

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 276009 / 132/33/11 KV SANGOLA S/S

Feeder No / Name : 272 / 11 KV Gherdi Feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0364	1.0669	.3048	.2743		.4115	.9145
2	1.0364	1.0364	.3048	.3048		.3944	.884
3	.9907	.9907	.3048	.3048		.3772	.8383
4	1.0669	.9755	.3201	.381		.3601	.8383
5	1.2803	.9145	.4572	.4572		.3429	.9145
6	1.3717	.9602	.5335			.3601	1.1431
7	1.5699	.9755				.3772	1.0059
8	1.6156	.9755				.3944	.0914
9	.2743	.2743				.6097	.1029
10	.3353	.3048				.8078	.0857
11	.2896					.9145	.2572
12	.3658		.8383			.9907	.3429
13	.3201		.9907	1.5242		1.1888	.3429
14	.4115		1.0669	1.6004		1.2193	.3429
15	.3506		1.2193	1.6004		1.2651	.3429
16	.2743		1.1888	1.6309		1.2346	.3258
17	.3048	.3048	.2134	.4572		.3429	.4287
18	.3201	.2743	.2286	.4572		.3086	.4287
19	.3201	.4572	.2439	.4572		.3429	.4287
20	.2743	.5335	.2743	.5335		.3772	.5144
21	.3353	.5182	.3048	.4572		.3601	.5144
22	.3048	.4572	.3353	.381		.3429	.463
23	.9755	.3506	.3353	.3201		.823	.9297
24	.9907	1.0669	.3048	.3048	.3048	.4115	.9145
Max	1.6156	1.0669	1.2193	1.6309	.3048	1.2651	1.1431
Min	.2743	.2743	.2134	.2743	.3048	.3086	.0857
Avg	.6840	.6909	.5142	.6733	.3048	.6066	.5581

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 276009 / 132/33/11 KV SANGOLA S/S

Feeder No / Name : 274 / 11 KV Chincholi Feeder      SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1981	.2439	.5335	.4725		.6401	.2572
2	.1524	.2286	.5335	.5335		.6249	.2401
3	.1524	.2134	.5335	.6097		.5792	.2401
4		.1981	.5335	.6859		.5944	.2229
5	.2286	.1829	.6097	.7621		.7011	.2058
6	.2743	.1829	.6859	.8383		1.0974	.2229
7	.3353	.2134	.3048	1.3717		1.2193	.2229
8	.3048	.2286	.5335	1.448		1.2803	.2229
9	.4572	.5335	.2134	.1524		.2229	1.1431
10	.5487	.6097	.2134	.1524		.2401	1.3717
11	.6249		.1981	.1524		.2058	1.3717
12	.7164			.1524		.2401	1.2193
13	.8078		.1524	.2286		.1886	1.1431
14	.9145		.1677	.1524		.2229	.9907
15	.9907		.1829	.0762		.1715	.9907
16	1.0364			.1219		.1886	1.0059
17	.2134	.2134	.1067	.1524		.2401	.1715
18	.2591	.2286	.1219	.1524		.2058	.2572
19	.2286	.2439	.1524	.2286		.2572	.2286
20	.1981	.3048	.2134	.3048		.2229	.2572
21	.2286	.2896	.2439	.3048		.1886	.2572
22	.1981	.2743	.2439	.2286		.2229	.2229
23	.2134	.5335	.503	.6401		.2401	.2229
24	.1981	.2439	.6097	.4877	.6859	.6554	.2572
Max	1.0364	.6097	.6859	1.448	.6859	1.2803	1.3717
Min	.1524	.1829	.1067	.0762	.6859	.1715	.1715
Avg	.4122	.2871	.3450	.4337	.6859	.4438	.5394

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 276009 / 132/33/11 KV SANGOLA S/S

Feeder No / Name : 275 / 11 KV Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2591	.3048	.2286	.2286			.3258
2	.2439	.2743	.2286	.2286			.3258
3	.2439	.2591	.2286	.2439			.3086
4	.2286	.2286	.3048	.2591			.2915
5	.2743	.2591	.381	.3048		.2572	.2572
6	.3506	.4268	.6097	.4572			.2572
7	.381	.442	.5335	.6097			.3429
8	.4268	.442	.381	.3506			.4287
9	.381	.381	.3658	.3048			.3429
10	.3353	.3506	.381	.2286			
11	.3506		.381	.2286			
12	.3048		.3048	.2286			.2572
13	.2896		.3048	.2439			.3429
14	.2591		.2286	.2439		.2534	.3429
15	.2286		.2286	.2591			.2572
16	.1981		.2286	.3048			.2572
17	.2286	.3353	.2286	.2286			.2572
18	.2743	.3658	.2743	.381			.3429
19	.3048	.381	.3048	.381			.4287
20	.2743	.4268	.381	.4572			.5144
21	.2439	.4725	.381	.381			.4287
22	.2591	.381	.3506				.3944
23	.2743	.3048	.2896	.2743			.3258
24	.2591	.3048	.2896	.2743	.2896		.3429
Max	.4268	.4725	.6097	.6097	.2896	.2572	.5144
Min	.1981	.2286	.2286	.2286	.2896	.2534	.2572
Avg	.2864	.3522	.3258	.3088	.2896	.2553	.3351

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 276009 / 132/33/11 KV SANGOLA S/S

Feeder No / Name : 276 / 11 KV Mahud Feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669	.9145	.2286	.2134	
2	1.0059	.884	.2286	.2286	
3	1.0059	.8383	.1524	.2286	
4	1.0669	.9145	.2286	.3048	
5	1.3413	1.1888	.3048	.381	
6	1.6766	1.3565	.4572	.5335	
7	2.1033	1.7985	.381		
8	2.2253	1.89	.3048		
9	.2134	.2286	1.448	1.7528	
10	.2591	.2743	1.7528	2.0576	
11	.3048		1.7985	1.7528	
12	.2439			1.9814	
13	.2896				
14	.2591				
15	.1981				
16	.2134		1.5546		
17	.2591	.2743	.1067	.3048	
18	.3048	.3048	.1372	.381	
19	.2743	.3201	.1677	.381	
20	.2439	.3353	.2134	.381	
21	.2896	.3353	.2286	.3201	
22	.3048	.3048	.2439	.3048	
23	.8078		.2439	.2591	
24	1.0364	.9145	.2286	.2286	.2439
Max	2.2253	1.89	1.7985	2.0576	.2439
Min	.1981	.2286	.1067	.2134	.2439
Avg	.7081	.7692	.5205	.6664	.2439

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 276009 / 132/33/11 KV SANGOLA S/S

Feeder No / Name : 277 / 11 KV Chandolwadi

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3658	1.5242	1.6766	
2	.3201	.3506	1.5242	1.5242	
3	.2896	.3048	1.448	1.448	
4	.2743	.3048	1.6004	1.5242	
5	.3048	.3506	1.7528	1.7528	
6	.381	.381	1.5242	1.9052	
7	.4268	.4268			
8	.4115	.442			
9	.7621	.2439	.4268	.4572	
10	.8993	.2591	.4268	.381	
11	1.0059	.2743	.4268	.3048	
12	1.2193		.4115	.3048	
13	1.3413		.3963	.2286	
14	1.448		.3353	.3048	
15	1.5394		.3048	.3048	
16	1.6004			.3506	
17	.3048	.3048	.3048	.381	
18	.2896	.3353	.3048	.4572	
19	.3506	.3658	.3658	.5335	
20	.381	.4268		.5335	
21	.3658	.4725		.4572	
22	.381	.4268		.4572	
23	.3353	1.5242		2.1338	
24	.3048	.3658	1.6004	1.6766	2.1643
Max	1.6004	1.5242	1.7528	2.1338	2.1643
Min	.2743	.2439	.3048	.2286	2.1643
Avg	.6351	.4171	.8634	.8681	2.1643

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 276009 / 132/33/11 KV SANGOLA S/S

Feeder No / Name : 278 / 11 KV super feeder

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2134	.2591	.1524	.2134		.2743	.3258
2	.2286	.2286	.1524	.1981		.2572	.3086
3	.2134	.1981	.1524	.1524		.2401	.2915
4	.1981	.1981	.1524	.1524		.3258	.2743
5	.1981	.1524	.1677	.1524		.2058	.2572
6	.1829	.1219	.1524	.1677		.1715	.2058
7	.1677	.0914	.1524	.1524		.1372	.1372
8	.1524	.0914	.1524	.1219		.1372	.1029
9	.2134	.1219	.2439	.1524		.1715	
10	.2439	.1524	.2591	.3048		.2058	.4287
11	.1829	.1524	.2743	.3048		.1372	.2572
12	.2743		.2591	.381		.1715	.3429
13	.3048		.2439	.3048		.2058	.0857
14	.3658		.2286	.1524		.2401	.0857
15	.3048		.2134	.3048		.2058	
16	.3353		.1829	.2439		.1715	
17	.3658	.2134	.1981	.2286		.2058	.1715
18	.3353	.2134	.2134	.2286		.1715	.1715
19	.3048	.2134	.2286	.2439		.2401	.1715
20	.3048	.2439	.2439	.2439		.2743	.1886
21	.3048	.2743	.2743	.2439		.3086	.1886
22	.2439	.2743	.2743	.3048		.3429	.3772
23	.2134	.2134	.2439	.2439		.3258	.2401
24	.2134	.2743	.2134	.2134	.2439	.2743	.3429
Max	.3658	.2743	.2743	.381	.2439	.3429	.4287
Min	.1524	.0914	.1524	.1219	.2439	.1372	.0857
Avg	.2528	.1941	.2096	.2254	.2439	.2251	.2360

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 276009 / 132/33/11 KV SANGOLA S/S

Feeder No / Name : 402 / 33 KV Old Soot Mill

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
23	.2572
24	2.5606
Max	2.5606
Min	.2572
Avg	1.4089



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 276009 / 132/33/11 KV SANGOLA S/S

Feeder No / Name : 409 / 33 KV Fabtech (Sangola II) NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	2.6749
Max	2.6749
Min	2.6749
Avg	2.6749

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 276009 / 132/33/11 KV SANGOLA S/S

Feeder No / Name : 410 / 33 KV RYB Solar Power

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	.1029
Max	.1029
Min	.1029
Avg	.1029

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274067 / 33/ 11 KV HANNUR S/S

Feeder No / Name : 201 / 11 KV CHUNGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	04-AUG-17	06-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1248	1.3916	1.5074
2		1.2967	1.3889	1.4403
3		1.3916		1.4373
4		1.4403	1.4661	1.5043
5		1.4685	1.5741	1.6575
6		1.4842	1.5586	1.6575
7		1.7185	1.757	1.8233
8		1.8747	1.7747	1.989
18		.0914	.0762	.0895
19		.0905	.0926	.0895
20		.0905	.0926	.0914
21		.0905	.081	.0914
22		.0914	.081	.0914
23	.8436	.5121	1.4232	1.4403
24	.0876	.4973	1.3441	1.4243
Max	.8436	1.8747	1.7747	1.989
Min	.0876	.0905	.0762	.0895
Avg	.4656	.8842	1.0073	1.0890

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274067 / 33/ 11 KV HANNUR S/S

Feeder No / Name : 202 / 11 KV BOREGAON AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	04-AUG-17	06-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9717	1.6204	2.2611
2		1.0526	1.8519	2.1091
3		1.1336	2.2377	2.2939
4		1.166	2.3457	2.332
5		1.2803	2.5463	2.3685
6		1.2811	2.7006	2.4006
7		1.6404	3.0864	3.2007
8		1.9524	2.5772	3.1367
18		.1402	.1143	.1715
19		.1791	.1036	.2103
20		.1753	.1036	.2629
21		.2103	.1334	.2629
22		.2149	.1391	.2629
23	.8097	1.7528	1.6232	2.0805
24	.1715	.8097	1.5432	2.0833
Max	.8097	1.9524	3.0864	3.2007
Min	.1715	.1402	.1036	.1715
Avg	.4906	.9307	1.5151	1.6958

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274067 / 33/ 11 KV HANNUR S/S

Feeder No / Name : 203 / 11 KV HANNUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	04-AUG-17	06-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4062	.3286	.3658
2		.4801	.4172	.3163
3		.5243	.5068	.3437
4			.5792	.5898
5		.6009	.6226	.5944
6		.6249	.6371	.5792
7		.5418	.5792	.5792
8		.4572	.5001	.5624
9		.381	.4515	.4801
10		.3201	.301	.4572
11		.3201	.3048	.381
12		.3201	.3086	.3715
13		.2458	.3125	.282
14		.2458	.3953	.282
15		.3048	.2429	.2058
16		.3048	.2429	.2115
17		.3715	.3277	.2743
18		.4115	.3163	.362
19		.4115	.4801	.3944
20		.4001	.6325	.4534
21		.4001	.5868	.4001
22		.3429	.5087	.4001
23	.3018	.3334	.4287	.3334
24	.3429	.282	.2629	.4049
Max	.3429	.6249	.6371	.5944
Min	.3018	.2458	.2429	.2058
Avg	.3224	.3926	.4281	.4010

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274067 / 33/ 11 KV HANNUR S/S

Feeder No / Name : 204 / 11 KV NANHEGAON GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-AUG-17	02-AUG-17	04-AUG-17	06-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3361	.3361	.2195
2		.3734	.3734	.1848
3		.4024	.3696	.1867
4		.4755	.462	.4024
5		.5487	.4938	.4481
6		.5487	.5175	.4706
7		.3658	.462	.439
8		.2957	.4435	.4066
9		.3734	.3696	.2957
10		.3734	.2772	.2801
11		.3772	.3658	.1867
12		.2801	.362	.1867
13		.1867	.362	.1867
14		.1867	.3582	.1867
15		.1867	.2686	.1886
16		.1886	.2715	.1886
17		.2829	.2686	.3734
18		.5601	.3544	.4668
19		.4668	.3429	.4668
20		.4715	.3467	.462
21		.4715	.3506	.462
22		.3734	.2658	.3734
23	.2614	.3772	.2629	.3696
24	.2801	.2614	.1867	.2587
Max	.2801	.5601	.5175	.4706
Min	.2614	.1867	.1867	.1848
Avg	.2708	.3652	.3530	.3204

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274067 / 33/ 11 KV HANNUR S/S

Feeder No / Name : 205 / 11 KV SULTANPUR AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	04-AUG-17	06-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8				.5624
9		.4915	.506	
10		.5735	.5335	.6249
11		.5601	.5335	.6249
12		.5601		.6401
13		.4915	.463	.6401
14		.4001	.5468	.6401
15		.4801	.6478	.6562
16			.6478	.6718
17			.0648	
18			.0655	
19			.0648	
21			.0655	
22			.0486	
23			.0486	
24	.0747			
Max	.0747	.5735	.6478	.6718
Min	.0747	.4001	.0486	.5624
Avg	.0747	.5081	.3259	.6326

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274067 / 33/ 11 KV HANNUR S/S

Feeder No / Name : 206 / 11 KV BAWKARWADI AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	04-AUG-17	06-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1619	.064	.0937
2		.1619	.064	.0937
9		2.2405	1.9599	2.1559
10		2.2405	2.1338	2.2653
11		2.2725	2.1605	2.4996
12		2.2405		2.6566
13		2.0805	1.2003	2.5606
14		1.9766	1.3413	2.2405
15		2.0805	1.2193	2.2939
16		2.0805	1.2346	2.4577
18		.128	.1029	.1006
19		.16	.104	.1341
20		.16	.104	.1341
21		.1638	.1052	.1372
22		.1638	.1227	.1372
23	.1943	.1638	.0532	.1402
24	1.7833	.1619	.048	.0781
<b>Max</b>	<b>1.7833</b>	<b>2.2725</b>	<b>2.1605</b>	<b>2.6566</b>
<b>Min</b>	<b>.1943</b>	<b>.128</b>	<b>.048</b>	<b>.0781</b>
<b>Avg</b>	<b>.9888</b>	<b>1.0963</b>	<b>.7511</b>	<b>1.187</b>



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274067 / 33/ 11 KV HANNUR S/S

Feeder No / Name : 207 / 11 KV ANV Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	04-AUG-17	06-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
4			.1296
8		.0633	
9		.0949	
10		.0943	.0324
11		.1132	.0328
12		.0943	.0328
13		.0943	
14		.0943	.0335
15		.0943	
16		.0943	.0335
17		.0943	.0175
18		.0566	.0175
19		.056	.0171
20		.0377	.0171
21		.0189	.0351
22		.0189	.0351
23		.0189	.0351
24	.0189		.016
<b>Max</b>	<b>.0189</b>	<b>.1132</b>	<b>.1296</b>
<b>Min</b>	<b>.0189</b>	<b>.0189</b>	<b>.016</b>
<b>Avg</b>	<b>.0189</b>	<b>.0712</b>	<b>.0347</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274070 / 33/11 KV NAGANSUR S/STN

Feeder No / Name : 201 / 11 KV NAVADAGI AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.181	.6097	.9955	.8145	1.086
2	.181	.181	.6097	1.086	.9955	1.2803
3			.6859	1.086	1.086	1.267
4			.8383	1.1765	1.267	1.448
5			.9907	1.3575	1.448	1.6461
6			1.448	1.6289	1.7194	1.829
7			2.1338	2.3529	2.2624	2.3777
8			1.9814	2.4434	2.3529	2.5339
9	2.0814	1.8099				
10	2.3529	2.0814				
11	2.3529	2.1719				
12	2.1719	2.1719				
13	1.9909	1.9004				
14	1.9909	1.3575				
15	1.9909	1.6289				
16	2.0814	1.8099				
19	.181	.181	.1905	.181	.181	.0905
20	.181	.181	.1905	.181	.181	.1829
21	.181	.181	.1905	.181	.181	.1829
22	.181		.1905	.181	.181	.181
23	.181	.362	.7621	.181	.8145	.9955
24	.181	.181	.6097	.9955	.724	.905
Max	2.3529	2.1719	2.1338	2.4434	2.3529	2.5339
Min	.181	.181	.1905	.181	.181	.0905
Avg	1.2187	1.0920	.8165	1.0019	1.0149	1.1433

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274070 / 33/11 KV NAGANSUR S/STN

Feeder No / Name : 202 / 11 KV HAIDRA AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	04-AUG-17	05-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4289	1.2803	.1905		.1905
2	1.4289	1.8671	.1905		.1905
3	1.4289	2.1719			
4	2.0957	2.3529			
5	2.2862	2.6139			
6	2.572	2.7149			
7	3.2388	3.1741			
8	2.9531	2.9874			
9			1.829		2.2862
10			2.1338		2.0957
11			2.1338		2.191
12			1.9814		2.2862
13			1.9052		2.3815
14					2.4768
15			1.7528		2.4768
16			1.9052		2.572
18			.1905		
19	.1905	.1867	.1905		.1905
20	.1905	.181	.1905		.1905
21	.1905	.1867	.1905		.1905
22	.1905	.181	.1905		.1905
23	.9526	.181	.1905	.1905	.1905
24	1.4289	1.086	.1905		.1905
Max	3.2388	3.1741	2.1338	.1905	2.572
Min	.1905	.181	.1905	.1905	.1905
Avg	1.4697	1.5118	.9597	.1905	1.2681

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274070 / 33/11 KV NAGANSUR S/STN

Feeder No / Name : 203 / 11 KV Nagansur GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.543	.543	.6001	.6335	.4525	.543
2	.6335	.543	.6001	.6335	.543	.6335
3	.7316	.8145	.823	.724	.724	.724
4	1.0059	1.086	.9431	.905	.8145	.724
5	1.0974	1.1765	1.1145	1.086	.905	1.0974
6	1.3717	1.3575	1.286	1.267	1.1765	1.3575
7		1.3575				
8	1.0974	1.086	1.1145	.9955	.964	1.0059
9	.823	.905	.7716	.8145	.8145	.7316
10	.6401	.6335	.6001	.6335	.724	.6335
11	.4572	.4525	.4287	.543	.543	.543
12	.4572	.4525	.4287	.4525	.543	.4525
13	.4572	.362	.4287	.4525	.4525	.4525
14	.4572			.362	.4525	.4525
15	.4572	.4525	.4287	.362	.4525	.362
16	.4572	.4525	.4287	.4525	.4525	.362
17		.543	.4287	.543	.543	.543
18	.6335	.6335	.5144	.6335	.6335	.6335
19	.724	.6335	.6001	.724	.8145	.724
20	.8145	.9955	1.0288	.8145	1.1765	.9955
21	.905	1.086	.8573	.905	.9955	.8145
22	.8145	.9955	.7716	.8145	.8145	.724
23	.724	.543	.5144	.6335	.724	.6335
24	.6401	.6335	.5487	.543	.4525	.543
Max	1.3717	1.3575	1.286	1.267	1.1765	1.3575
Min	.4572	.362	.4287	.362	.4525	.362
Avg	.7247	.7712	.6937	.6925	.7030	.6820

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274070 / 33/11 KV NAGANSUR S/STN

Feeder No / Name : 204 / 11kv Rly Station Gaothan GAOTHAN FEEDER  
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4525	.4525	.3429	.362		.4525
2	.4525	.4525	.3429	.362		.543
3	.4525	.543	.3429	.4525		.543
4	.543	.6335	.5144	.543		.6335
5	.6335	.724	.6859	.724		.724
6	.8145	.8145	.8573	.905		.905
7	.724	.724	.6859	.8145		.724
8	.543	.543	.5144	.543		.543
9	.4525	.4525	.4287	.4525		.543
10	.4525	.4525	.4287	.4525		.4525
11	.4525	.362	.4287	.362		.362
12	.362	.362	.3429	.362		.362
13	.4525	.362	.3429	.362		.362
14	.362	.362	.2572	.4525		.362
15	.362	.362		.4525		.362
16	.362	.362	.3429	.4525		.362
17	.4525	.4525	.4287	.4525		.4572
18	.4525	.543	.5144	.4525		.4572
19	.543	.724	.5144	.543		.5487
20	.6335	.724	.6859	.6335		.724
21	.724	.724	.6859	.6335		.6335
22	.6335	.543	.5144	.543		.543
23	.543	.4525	.4287	.4525		.4525
24	.4525	.4525	.3429	.362	.4525	.4525
Max	.8145	.8145	.8573	.905	.4525	.905
Min	.362	.362	.2572	.362	.4525	.362
Avg	.5128	.5241	.4771	.5053	.4525	.5210

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274070 / 33/11 KV NAGANSUR S/STN

Feeder No / Name : 205 / 11 KV Gaudgaon Bk Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0781	.0905	.2286	.2715	.362	.4525
2	.0781	.0905	.2286	.2715	.4525	.3906
3			.2286	.362	.4525	.3906
4			.3048	.362	.4525	.4687
5			.3048	.362	.4525	.4687
6			.381	.4525	.543	.4687
7			.6859	.724	.6335	.5468
8			.6859	.6335	.6335	.703
9	.5668	.4525				
10	.5668	.6335				
11	.5668	.543				
12	.5468	.543				
13	.4858	.543				
14	.4687	.4525				
15	.0469	.543				
16	.4858	.4525				
19	.0781	.0905	.0953	.0905	.0905	.0781
20	.0781	.0905	.0953	.0905	.0905	.0781
21	.0781	.0905	.0953	.0905	.0905	.0791
22	.0781	.0905	.0953	.0905	.0905	.0791
23	.0781	.2715	.4525	.362	.362	.2372
24	.081	.0905	.2286	.2715	.362	.362
Max	.5668	.6335	.6859	.724	.6335	.703
Min	.0469	.0905	.0953	.0905	.0905	.0781
Avg	.2726	.3168	.2936	.3168	.362	.3431

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274071 / 33/11 KV SHIRWAL S/S

Feeder No / Name : 201 / 11 KV MOTYAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953					.4525	
2	.0953					.4525	
3	.0953					.4525	
4	.0953					.543	
5	.0953					.724	
6	.2858					.8145	
7	.381					.724	
8	.2858					.6335	
9		.1905	.2858	.1905	.1905	.4525	.2858
10		.1905	.2858	.2858	.1905	.4525	.2858
11		.2858	.2858	.2858	.2858	.4525	.2858
12		.381	.381	.2858	.1905	.4525	.2858
13		.381	.2858	.2858	.381	.362	.2858
14		.1905	.2858	.2858	.2858	.362	.381
15		.2858	.381	.2858	.2858	.4525	.381
16		.2858	.381	.381	.2858	.4525	.2858
17						.543	
18						.6335	
19						.724	
20						.724	
21						.6335	
22						.5258	
23						.4525	
24	.0953					.4525	
Max	.381	.381	.381	.381	.381	.8145	.381
Min	.0953	.1905	.2858	.1905	.1905	.362	.2858
Avg	.1694	.2739	.3215	.2858	.2620	.5385	.3096

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274071 / 33/11 KV SHIRWAL S/S

Feeder No / Name : 202 / 11 KV WAGADARI AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	1.5242	2.0957	1.9052	2.0005	2.2862	2.572
2	.0953	1.5242	2.0957	1.9052	2.0005	2.2862	2.572
3	.0953	1.5242	2.0957	2.0005	2.0005	2.2862	2.572
4	.0953	1.5242	2.0957	2.0005	2.0005	2.4768	2.572
5	.0953	1.7147	3.0483	2.0957	2.0005	2.6673	2.572
6	.0953	2.3815	3.1436	2.3815	2.7625	3.0483	2.7625
7		2.6673	3.4294	3.2388	3.3341	3.4294	3.6199
8		2.7625	3.2388	3.0483	3.3341	2.2862	2.9531
9	3.1436						
10	3.8104						
11	3.4294						
12	3.7151						
14	3.5246						
15	3.8104						
16	3.5246						
19	.0953	.0953	.0953		.0953		.0953
20	.0953	.0953	.0953		.0953	.0953	.0953
21	.0953	.0953	.0953	.0953	.0953	.0953	.0953
22	.0953	.0953	.0953	.0953	.0953	.0953	.0953
23	1.5242	2.0957	1.8099	1.7147	2.0957	2.4768	2.3815
24	.0953	1.5242	2.0957	1.9052	2.0005	2.2862	2.572
Max	3.8104	2.7625	3.4294	3.2388	3.3341	3.4294	3.6199
Min	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Avg	1.4490	1.4017	1.8236	1.8655	1.7079	1.9858	1.9664



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274071 / 33/11 KV SHIRWAL S/S

Feeder No / Name : 203 / 11 KV SANGAVI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	1.7147	1.8099	2.0005	2.0957	2.0957	1.9052
2	.0953	1.7147	1.8099	2.0005	2.0957	2.0957	1.9052
3	.0953	1.7147	1.8099	2.0005	2.0957	2.0957	1.9052
4	.0953	1.7147	1.8099	2.0005	2.0957	2.0957	1.9052
5	.0953	1.8099	2.0005	2.0005	2.0957	2.0957	2.2862
6	.0953	2.0005	2.4768	2.4768	2.572	2.3815	2.4768
7		2.2862	2.4768	2.572	2.572	2.6673	2.9531
8		2.2862	2.3815	2.8578	2.6673	2.8578	3.0483
9	2.3815						
10	2.3815						
11	2.8578						
12	2.6673						
13	2.3815						
14	2.4768						
15	2.572						
16	2.0005						
19	.0953	.0953	.0953	.0953	.0953		.0953
20	.0953	.0953	.0953	.0953	.0953	.0953	.0953
21	.0953	.0953	.0953	.0953	.0953	.0953	.0953
22	.0953	.0953	.0953	.0953	.0953	.0953	.0953
23	1.6194	1.8099	1.8099	2.0957	1.8099	1.9052	1.7147
24	.0953	1.7147	1.8099	1.9052	2.191	1.9052	2.0005
Max	2.8578	2.2862	2.4768	2.8578	2.6673	2.8578	3.0483
Min	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Avg	1.1193	1.3677	1.4697	1.5922	1.6194	1.7293	1.6058

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274071 / 33/11 KV SHIRWAL S/S

Feeder No / Name : 204 / 11 KV Shirwal Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.4763	.4763	.4763	.5716	.5716	.4763
2	.4763	.4763	.4763	.4763	.5716	.5716	.4763
3	.5716	.4763	.4763	.5716	.5716	.5716	.4763
4	.6668	.5716	.5716	.6668	.6668	.6668	.6668
5	.7621	.7621	.7621	.8573	.8573	.7621	.7621
6	.9526	.9526	.9526	1.0479	1.0479	.8573	1.1431
7	.8573	.8573	.8573	1.0479	.7621	.9526	.9526
8	.6668	.7621	.6668	.8573	.6668	.6668	.7621
9	.4763	.5716	.6668	.6668	.4763	.7621	.6668
10	.4763	.5716	.5716	.4763	.381	.6668	.5716
11	.381	.4763	.4763	.381	.381	.5716	.4763
12	.381	.4763	.381	.381	.4763	.4763	.4763
13	.381	.4763	.381	.381	.381	.4763	.4763
14	.381	.381	.381	.381	.381	.4763	.4763
15	.381	.381	.381	.2858	.4763	.4763	.4763
16	.381	.381	.381	.381	.4763	.4763	.4763
17		.4763	.4763	.381	.4763	.4763	.4763
18	.6668	.4763	.5716	.4763	.4763	.5716	.4763
19	.6668	.6668	.7621	.6668	.7621	.7621	.7621
20	.8573	.8573	.7621	.8573	.8573	.9526	.8573
21	.6668	.7621	.6668	.7621	.7621	.7621	.7621
22	.5716	.6668	.5716	.6668	.6668	.6668	.6668
23	.4763	.5716	.4763	.5716	.5716	.5716	.5716
24	.4763	.4763	.4763	.4763	.5716	.5716	.5716
Max	.9526	.9526	.9526	1.0479	1.0479	.9526	1.1431
Min	.381	.381	.381	.2858	.381	.4763	.4763
Avg	.5674	.5835	.5676	.5914	.5954	.6390	.6232

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274071 / 33/11 KV SHIRWAL S/S

Feeder No / Name : 205 / 11kv Wagdari Goathan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.381	.381	.381	.381	.381
2	.381	.381	.381	.381	.381	.381	.381
3	.381	.381	.381	.381	.381	.381	.381
4	.5716	.4763	.381	.4763	.381	.381	.4763
5	.6668	.5716	.5716	.5716	.4763	.4763	.5716
6	.8573	.7621	.7621	.6668	.6668	.5716	.6668
7	.7621	.6668	.6668	.8573	.6668	.6668	.7621
8	.5716	.4763	.5716	.4763	.5716	.5716	.5716
9	.4763	.4763	.4763	.381	.4763	.4763	.4763
10	.381	.381	.381	.2858	.381	.4763	.381
11	.2858	.2858	.2858	.2858	.381	.381	.381
12	.2858	.2858	.2858	.2858	.2858	.381	.381
13	.2858	.2858	.2858	.2858	.381	.381	.1905
14	.2858	.2858	.2858	.2858	.381	.381	
15		.2858	.2858	.2858	.2858	.381	.381
16	.2858	.2858	.2858	.2858	.2858	.381	.2858
17	.381	.2858	.2858	.2858	.381	.381	.2858
18	.4763	.381	.381	.381	.381	.4763	.381
19	.5716	.5716	.4763	.5716	.5716	.5716	.5716
20	.6668	.6668	.6668		.5716	.7621	.6668
21	.6668	.6668	.6668	.5716	.5716	.4763	.6668
22	.4763	.5716	.4763	.4763	.4763	.5716	.5716
23	.381	.381	.381	.381	.381	.381	.381
24	.381	.381	.381	.381	.381	.381	.381
Max	.8573	.7621	.7621	.8573	.6668	.7621	.7621
Min	.2858	.2858	.2858	.2858	.2858	.381	.1905
Avg	.4722	.4406	.4326	.4183	.4366	.4604	.4597

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274071 / 33/11 KV SHIRWAL S/S

Feeder No / Name : 206 / 11kv Borgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.7151	.0953	.0953	.0953	.0953	.0953	.0953
2	3.7151	.0953	.0953	.0953	.0953	.0953	.0953
3	3.7151	.0953	.0953	.0953	.0953	.0953	.0953
4	3.8104	.0953	.0953	.0953	.0953	.0953	.0953
5		.0953	.0953	.0953	.0953	.0953	.0953
6	1.9052	.0953	.0953	.0953	.0953	.0953	.0953
7	3.8104						
8	3.6199						
9		2.0957	3.3341	2.0957	2.7625	2.6673	3.0483
10		2.0957	3.6199	3.0483	3.6199	3.0483	3.8104
11		3.0483	4.0009	3.1436	3.9057	3.3341	3.8104
12		3.2388	4.0009	3.4294	3.9057	3.7151	3.3341
13		3.2388	4.0009	3.0483	3.8104	3.4294	3.0483
14		3.1436	3.8104	2.2862	3.2388	3.2388	2.4768
15		3.6199	3.7151	3.2388	3.6199	2.6673	2.6673
16		3.3341	3.1436	2.0957	3.6199	2.4768	2.7625
19	.0953	.0953	.0953	.0953		.0953	.0953
20	.0953	.0953	.0953	.0953	.0953	.0953	.0953
21	.0953	.0953	.0953	.0953	.0953	.0953	.0953
22	.0953	.0953	.0953	.0953	.0953	.0953	.0953
23	.0953	.0953	.0953	.0953	.0953	.0953	.0953
24	3.7151	.0953	.0953	.0953	.0953	.0953	.0953
Max	3.8104	3.6199	4.0009	3.4294	3.9057	3.7151	3.8104
Min	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Avg	2.1910	1.2479	1.5385	1.1765	1.5543	1.2860	1.3051

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274072 / 33/11 KV TADWAL SUBSTATION

Feeder No / Name : 201 / 11 KV TADWAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3969	.0892	.0743	.0743	.104	.0892	.0892
2	1.46	.0892	.0743	.0743	.104	.0892	.104
3	1.5503	.104	.0892	.0892	.104	.104	.104
4	1.6049	.1189	.1189	.104	.1189	.1189	.104
5	1.7008	.1486	.1486	.1189	.1189	.1337	.1189
6	1.7833	.1486	.1189	.1337	.1189	.1486	.1189
7	2.0576						
8	1.9765						
9		1.8576	1.8724	1.9319	1.9022	1.8724	1.8427
10		2.1102	1.8724	1.9467	2.0508	1.9616	1.5752
11			2.0062	1.9467	1.9765	1.9913	1.8964
12				1.9913	1.9616	1.9319	1.9319
13				1.4861	1.9319	1.9319	1.9319
14			1.9319	1.7833	1.8278	1.9022	1.8724
15			1.9616	1.6347	1.7981	1.813	1.9022
16			1.9913	1.8427	1.7981	1.813	
19	.0892	.0892	.104	.0892	.0892	.104	
20	.1189	.1189	.1337	.1189	.1189	.104	.0602
21	.1189	.1337	.1337	.1337	.104	.104	.0594
22	.104	.0892	.1189	.1189	.104	.104	.0743
23	.0892	.0892	.0892	.104	.0892	.0892	.0602
24	1.4118	.0892	.0743	.0743	.104	.0892	.0743
Max	2.0576	2.1102	2.0062	1.9913	2.0508	1.9913	1.9319
Min	.0892	.0892	.0743	.0743	.0892	.0892	.0594
Avg	1.1045	.3768	.7174	.7898	.8263	.8248	.7733

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274072 / 33/11 KV TADWAL SUBSTATION

Feeder No / Name : 202 / 11 KV KHANAPUR AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0537	1.5089	1.5089	1.2651	1.5466	1.4335	1.2955
2	.0537	1.5466	1.4901	1.2803	1.5844	1.4146	1.2955
3	.0537	1.5844	1.4901	1.2955	1.5844	1.4712	1.3108
4	.0732	1.6221	1.5089	1.2955	1.6975	1.5278	1.3413
5	.0754	1.6598	1.5089	1.3108	1.7353	1.6032	1.3413
6	.0724	1.7541	1.5466	1.3413	1.7353	1.6975	1.3565
7		1.9239		1.4327	1.8861	1.8861	1.4632
8		2.037	1.7541	1.3717	1.9616	1.8484	1.5546
9	1.7718						
10	1.97						
11	1.9993						
12	1.9805						
13	1.773						
14	1.8107						
15	1.8861						
16	1.9427						
19	.0943	.0943	.0914	.0943	.0943	.0914	.0895
20	.1132		.0914	.0943	.0943	.0914	.0886
21	.1132		.0914	.1132	.0943	.0914	.0895
22	.0943	.1132	.0914	.1132	.0943	.0762	.0895
23	1.4901	1.4712	1.2498	1.4712	1.4146	1.2498	1.3643
24	.0543	1.5089	1.5089	1.2651	1.5089	1.4146	1.2803
Max	1.9993	2.037	1.7541	1.4712	1.9616	1.8861	1.5546
Min	.0537	.0943	.0914	.0943	.0943	.0762	.0886
Avg	.8738	1.4020	1.0717	.9817	1.2166	1.1355	.9972

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274072 / 33/11 KV TADWAL SUBSTATION

Feeder No / Name : 203 / 11 KV MHAISALGI AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0457	.9568	1.034	1.1574	1.0802	1.1574	1.2191
2	.0457	.9877	1.0185	1.2037	1.0802	1.142	1.25
3	.0457	1.0185	1.0185	1.2037	1.1111	1.1728	1.2809
4	.0617	1.0802	1.034	1.2346	1.142	1.2346	1.2809
5	.0617	1.1111	1.034	1.25	1.2346	1.2963	1.3117
6	.0617	1.2654	1.1728	1.358	1.358	1.4352	1.3272
7		1.4815		1.4043	1.4506	1.5123	1.4661
8		1.5123	1.7541	1.4043	1.5123	1.5432	1.4969
9	1.5123						
10	1.6004						
11	1.5741						
12	1.5586						
13	1.5432						
14	1.5123						
15	1.5586						
16	1.5432						
19	.0926	.108	.108	.0926	.0772	.108	.1235
20	.108	.1235	.108	.0926	.0926	.108	.1219
21	.0926	.1235	.108	.108	.0926	.108	.1067
22	.0772	.1235	.108	.108	.108	.108	.108
23	.9105	.9877	1.1111	.9877	1.1574	1.1574	1.1265
24	.0457	.9414	1.0648	1.1574	1.0648	1.1574	1.2037
Max	1.6004	1.5123	1.7541	1.4043	1.5123	1.5432	1.4969
Min	.0457	.108	.108	.0926	.0772	.108	.1067
Avg	.7026	.8444	.8211	.9116	.8973	.9458	.9588

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274072 / 33/11 KV TADWAL SUBSTATION

Feeder No / Name : 204 / 11 KV MANGRUL AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3279	.112	.112	.128	.1698	.128	.128
2	1.3592	.112	.128	.128	.144	.112	.128
3	1.4373	.128	.144	.144	.144	.112	.128
4	1.4969	.144	.16	.16	.16	.144	.128
5	1.6512	.16	.192	.16	.16	.176	.144
6	1.8122	.1543	.16	.176	.16	.16	.144
7	2.2809						
8	2.0778						
9		1.8244	1.9685	1.9204	1.8564	1.7284	1.8564
10		1.9364	2.0165	2.0805	2.0485	1.5684	1.9204
11			2.0165	1.9845	1.8564	1.7924	1.8435
12			1.9685	1.7284	1.9845	1.8564	1.8278
13			1.9524	1.7764	1.9845	1.8884	1.7654
14			1.9364	1.8244	1.9204	1.8884	1.7394
15			1.9204	1.8884	1.8404	1.9364	1.8122
16			1.9524	1.9364	1.9845	1.9685	1.866
19	.128	.144	.176	.144	.16	.144	.128
20	.16	.176	.176	.144	.16	.144	.1619
21	.144	.176	.16	.16	.16	.1389	.1457
22	.128	.16	.16	.16	.16	.144	.1457
23	.128	.112	.128	.144	.128	.112	.112
24	1.3272	.112	.128	.128	.144	.128	.128
Max	2.2809	1.9364	2.0165	2.0805	2.0485	1.9685	1.9204
Min	.128	.112	.112	.128	.128	.112	.112
Avg	1.1042	.3894	.8778	.8458	.8663	.8135	.8126



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274072 / 33/11 KV TADWAL SUBSTATION

Feeder No / Name : 205 / 11KV TADWAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4755	.5121	.2012	.4572	.4938	.4938	.4938
2	.4938	.5121	.2012	.4938	.4572	.5121	.5487
3	.5853	.5853	.2378	.5853	.5487	.567	.6036
4	.7023	.7682	.2926	.6697	.695	.6584	.6767
5	.7392	.8779	.3658	.7682	.8413	.7316	.7682
6	.8316	.7499	.3292	.8596	.8962	.823	.8413
9	.4755	.4755	.2012	.4755	.4755	.4207	.4207
10	.4572	.4207	.1829	.4207	.4572	.5121	.4572
11	.4207		.1463	.4024	.439	.3841	.4024
12	.4024		.1646	.4024	.4207	.4207	.3658
13	.3658		.3109	.3658	.439	.4024	.3658
14	.3658		.4755	.4024	.4207	.3841	.3658
15	.439		.4161	.4207	.4207	.4207	.3658
16	.439		.3109	.3841	.439	.3841	.4024
17			.3841				.4024
18			.5853				.4572
19	.5853	.6401	.695	.6219	.6767	.6401	.5487
20	.8596		.7499	.7865	.8048	.7133	.7392
21	.7865	.2743	.6767	.7133	.7316	.6767	.6653
22	.6767	.2926	.6036	.6401	.5853	.5853	.6219
23	.5487	.2195	.4938	.5487	.5121	.4938	.5487
24	.4938	.5121	.2012	.4572	.5121	.4938	.4572
Max	.8596	.8779	.7499	.8596	.8962	.823	.8413
Min	.3658	.2195	.1463	.3658	.4207	.3841	.3658
Avg	.5572	.5262	.3739	.5438	.5633	.5359	.5236

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274072 / 33/11 KV TADWAL SUBSTATION

Feeder No / Name : 206 / 11 kv Gokul Mauli NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0347	.0354	.0347	.0347	.0354	.052	.0347
2	.0347	.0354	.0347	.0347	.0354	.052	.0343
3	.0514	.0354	.0347	.0347	.0354	.052	.0347
4	.052	.0354	.0347	.0347	.0354	.052	.0347
5	.0514	.0354	.0173	.0347	.0183	.0347	.0347
6	.052	.0354		.0347	.0177		
7	.0343	.0177			.0177	.0173	.0347
8	.0335	.0354		.0347	.0177		.052
9	.0848	.0532	.0867	.0347	.0532	.0693	.104
10	.0867	.0693	.0867	.0347	.0709	.104	.104
11	.0173		.052	.0532	.0693	.0347	.0526
12	.0354		.052	.0532	.0347	.0347	.0701
13	.0532		.052	.0532	.052	.0358	.052
14	.0532		.052	.052	.052	.0358	.0701
15	.0532		.0693	.0532	.0347	.0347	.052
16	.0532		.052	.0549	.052		.0701
17	.0532		.0693	.0532	.052		.0701
18	.0693	.0867	.0867	.0532	.0693	.0173	.052
19	.0532	.0693	.0867	.0886	.104	.0347	.0693
20	.0354	.052	.0693	.0709	.104	.0347	.0876
21	.0532	.0347	.0693	.0709	.0693	.0347	.104
22	.0532	.0347	.0867	.0709	.0693	.0347	.0867
23	.0354	.0347	.052	.0354	.0693	.0347	.0857
24	.0343	.0354	.0347	.0347	.0354	.052	.0347
Max	.0867	.0867	.0867	.0886	.104	.104	.104
Min	.0173	.0177	.0173	.0347	.0177	.0173	.0343
Avg	.0487	.0433	.0578	.0483	.0502	.0426	.0619

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274072 / 33/11 KV TADWAL SUBSTATION

Feeder No / Name : 207 / 11 KV Mangrul Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 /

OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1254	.1448	.1433	.1612	.1267	.1433	.1433
2	.1433	.1629	.1433	.1791	.1267	.1433	.1612
3	.1791	.181	.1791	.1791	.1629	.1612	.1791
4	.2172	.2534	.2686	.2149	.2534	.2149	.2149
5	.2328	.2715	.3224	.2507	.2896	.2686	.2686
6	.2715	.2896	.2865	.2865	.3258	.2328	.3045
9	.1433	.181	.1433	.1612	.1433	.1433	.156
10	.1433	.1612	.1433	.1433	.1448	.1612	.1254
11	.1267		.1075	.1448	.1254	.1433	.1254
12	.1267		.1075	.1254	.1254	.1254	.1075
13	.1086		.1075	.1086	.1254	.1254	.0895
14	.1086		.1075	.1086	.1075	.1254	.0895
15	.1086		.1075	.1086	.1075	.1254	.1075
16	.1086		.1075	.1097	.0895	.1254	.0895
17							.1075
18							.1075
19	.181	.2328	.2149	.1991	.2149	.2328	.1629
20	.2353	.2686	.2507	.2534	.2328	.2507	.2353
21	.2534	.2507	.2149	.2534	.2149	.2149	.2328
22	.181	.197	.197	.1991	.197	.1791	.1612
23	.1448	.1433	.1612	.1448	.1433	.1433	.1433
24	.1433	.1448	.1433	.1612	.1267	.1433	.1433
Max	.2715	.2896	.3224	.2865	.3258	.2686	.3045
Min	.1086	.1433	.1075	.1086	.0895	.1254	.0895
Avg	.1641	.2059	.1728	.1746	.1692	.1702	.1571

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274079 / 33/11 KV MAINDARGI S/STN

Feeder No / Name : 201 / 11 KV DUDHANI AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5089	.0829	.0829	.0829	.0829	.0848	.0848
2	1.6289	.0829	.0829	.0838	.0829	.0848	.0848
3	1.5927	.0829	.0829	.0838	.0829	.0819	.0848
4	1.7147	.0829	.0829	.0838	.0829	.0848	.0848
5	1.7604	.0829	.0829	.0848	.0829	.0848	.0848
6	1.8861	.0829	.0829	.0838	.0829	.0848	.0848
7	1.95						
8	2.0576						
9		1.0774	1.6004	1.1022	1.8233	1.5261	1.6108
10		1.989	1.9062	1.0059	1.989	2.0348	1.95
11		1.989	1.8233	1.5927	2.1548	2.0348	2.0348
12		1.989	1.8233		2.0719	2.2043	2.1195
13		1.8233		1.5089	2.0719	2.2043	1.95
14		1.5746	1.8233	1.6766	2.0719	1.95	1.8652
15		1.9062	1.6575	2.0119	1.989	1.7804	1.95
16		1.989	1.7404	2.0119	2.0719	1.7804	2.0348
19	.081						
20	.0772		.0829	.0838	.0829	.0848	.0848
21	.0781	.0829	.0829	.0848	.0829	.0848	.0848
22	.0848	.0829	.0829	.0848	.0829	.0848	.0848
23	.0848	.0829	.0829	.0838	.0829	.0848	.0848
24	1.4918	.0829	.0829	.0838	.0829	.0819	.0848
Max	2.0576	1.989	1.9062	2.0119	2.1548	2.2043	2.1195
Min	.0772	.0829	.0829	.0829	.0829	.0819	.0848
Avg	1.1426	.8426	.7381	.6574	.9029	.8654	.8657

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274079 / 33/11 KV MAINDARGI S/STN

Feeder No / Name : 202 / 11 KV MAINDARGI PURE AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.503	.0829		.0829	.0848	.0819	.0848
2	.5087	.0829		.0829	.0819	.0848	.0848
3	.5087	.0829		.0829	.0791	.0848	.0848
4	.503	.0829		.0829	.0848	.0848	.0848
5	.5935	.0829		.0829	.0819	.0848	.0819
6	.6706	.0829		.0829	.0819	.0848	.0819
7	.8478						
8	1.0059						
9		.663	.5935	.5801	.8192	.5087	.9326
10		.9116	.7716	.7459	.9326	.8478	.9326
11			.7716	.5801	.9326	.8478	.9326
12		.663	.6706	.2486	.763	.9326	.9326
13		.663	.6706		.763	.8478	.8526
14		.663			.8478	.8478	.8478
15		.5801	.6001	.4973	.8192	.8478	.6783
16		.7459	.6783	.663	.8478	.763	.5935
19					.0848		
20			.0848	.0829	.0819	.0848	.0848
21			.0857	.0829	.0848	.0848	.0848
22			.0857	.08	.0848	.0848	.0848
23			.0857	.0829	.6443	.0848	.0819
24	.5087	.0829	.7545	.0829	.0819	.0848	.0848
Max	1.0059	.9116	.7716	.7459	.9326	.9326	.9326
Min	.503	.0829	.0848	.08	.0791	.0819	.0819
Avg	.6278	.3907	.4877	.2485	.4141	.3881	.4014

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274079 / 33/11 KV MAINDARGI S/STN

Feeder No / Name : 203 / 11 KV SALAGAR AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0838	1.8233		1.7147	1.5746	1.3108	1.95
2	.0838	1.989		1.6766	1.6575	1.5261	1.95
3	.0838	2.1548		1.7804	1.989	1.8652	1.95
4	.0848	2.3205		1.7604	2.3205	2.0348	1.95
5	.0838	2.4863		1.95	2.3205	2.3739	1.95
6	.0838	2.8178		2.3739	2.4863	2.6216	2.713
7		2.8178		2.4587	2.3205	2.4577	2.8826
8		1.989		2.5987	2.2377	2.9673	2.9673
9						2.0833	
10						2.4691	
11						2.7778	
12						3.0556	
13						1.8023	
14						2.0309	
15						3.0769	
16						2.9683	
17					.0829		
18					.0829		
19		.0829			.0829	.0791	
20			.0829	.0838	.0829	.0848	.0848
21			.0829	.0838	.0829	.0848	.0848
22			1.5746	.0848	.0829	.0848	.0848
23			1.5746	1.7804	1.1603	1.95	1.6385
24	.0838	.0829		1.6766	1.4918	1.3108	1.95
Max	.0848	2.8178	1.5746	2.5987	2.4863	3.0769	2.9673
Min	.0838	.0829	.0829	.0838	.0829	.0791	.0848
Avg	.0839	1.8564	.8288	1.5402	1.2535	1.8644	1.7043

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274079 / 33/11 KV MAINDARGI S/STN

Feeder No / Name : 204 / 11 KV BOROTI AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	1.8233	1.3565	1.1736	1.5261	1.3565	1.6956
2	1.3717	1.8233	1.3717	1.1869	1.5261	1.3565	1.6956
3	1.2003	1.989	1.3717	1.286	1.5261	1.3565	1.6956
4	1.1736	1.8233	1.3717	1.2574	1.5261	1.3927	1.6956
5	1.0898	1.8233	1.2003	1.326	1.5261	1.4575	1.6956
6	1.0059	1.6575	1.0402	1.6766	1.6108	1.5384	1.6956
7	1.3413	1.1603	1.5432	1.7604	1.6956	1.9433	
8	1.8861	1.6004	1.8861	1.7604	1.7147	2.0243	
9	2.1195	1.6575	1.7337	1.5089	1.7804	1.7004	1.6975
10	2.13	2.1548	1.8861	1.5261	1.6956	1.7004	2.0348
11	2.1195	2.0719	1.95	1.5089	2.0348	1.7394	2.1195
12	1.6956	1.989	1.9719	1.5089	1.95	1.9433	2.2043
13	1.7804	1.8233	1.9719	1.6766	1.8652	1.8747	2.1195
14	1.7804	1.7404	1.8861	1.9605	1.8652	1.9433	2.0348
15	1.8652	1.8233	1.9071	1.7604	1.8652	1.8747	1.95
16	1.8652	1.8233	1.9071	1.8233	1.8652	1.8976	1.8023
19	.0848	.1658			.0848		
20	.1696	.1658	.1696	.1696	.0848	.0848	.0848
21	.1696	.1658	.1715	.1677	.0848	.0848	.1696
22	.1696	.1658	.1715	.1677	.0848	.0848	.1696
23	.1696	1.2431	1.1145	1.3927	1.3565	1.6108	1.3565
24		1.6575	1.3413	1.1736	1.3765	1.3687	1.6956
Max	2.13	2.1548	1.9719	1.9605	2.0348	2.0243	2.2043
Min	.0848	.1658	.1696	.1677	.0848	.0848	.0848
Avg	1.2729	1.4704	1.3964	1.3225	1.3930	1.4444	1.5585

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274079 / 33/11 KV MAINDARGI S/STN

Feeder No / Name : 205 / 11 KV UMARGA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
23	.2486
Max	.2486
Min	.2486
Avg	.2486



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274079 / 33/11 KV MAINDARGI S/STN

Feeder No / Name : 206 / 11 KV DUDHANI/BOROTI

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /  
OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.503	.8288	.6859	.503	.4572	.381	.4572
2	.5087	.8288	.6783	.4572	.4572	.381	.4572
3	.503	.8288	.6783	.4572	.4572	.381	.4572
4	.5868	.8288	.6706	.4572	.4572	.4572	.4572
5	.6783	.8002	.8478	.4572	.6859	.6859	.4572
6	.9431	.8002	.9326	.8383	.9145	.8383	.7621
7	.8383	.7459	.8383	.6097	.7621	.7621	.6859
8	.763	.663	.6783	.6097	.6097	.6097	.6097
9	.4687	.5601	.503	.5335	.4572	.5335	.5335
10	.4744	.4973	.4191	.4572	.4572	.4572	.4572
11	.3906	.4144	.4191	.381	.381	.4572	.381
12	.3906	.3315	.4191		.381	.381	
13	.3953	.3201	.4287	.381	.3048	.381	
14	.3906	.3239		.381	.3048	.3048	
15	.3391	.3315	.3391	.381	.3048	.381	
16	.3125	.3315	.4239	.381	.3048	.381	
17	.3906	.4144	.5087	.381	.381	.381	
18	.4801	.4973	.5087	.4572	.4572	.381	
19	.6249		.6859	.6097	.6097	.6097	
20	.7811	.7459	.8383	.6859	.6859	.7621	
21	.6554	.663	.7287	.4572	.6097	.6097	
22	.7373	.5801	.5668	.4572	.5335	.5335	
23	.763	.5801	.4858	.4572	.4572	.4572	
24	.503	.8288	.6706	.4858	.4572	.381	.4572
Max	.9431	.8288	.9326	.8383	.9145	.8383	.7621
Min	.3125	.3201	.3391	.381	.3048	.3048	.381
Avg	.5592	.5976	.6068	.4903	.4953	.4953	.5144

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274079 / 33/11 KV MAINDARGI S/STN

Feeder No / Name : 207 / 11KV UAMRGE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	07-AUG-17
HR	Load (MW)
12	.381
13	.381
14	.381
15	.381
16	.381
17	.381
18	.4572
19	.5335
20	.4572
21	.4572
22	.4572
23	.4572
Max	.5335
Min	.381
Avg	.4255

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274079 / 33/11 KV MAINDARGI S/STN

Feeder No / Name : 208 / 11KV MAINDARGI SEMI URBAN GAOTHAN FEEDER  
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.503	.663	.5935	.4973	.5935	.5087	.5935
2	.5087	.663	.5868	.4973	.5935	.5087	.5935
3	.503	.663	.5935	.4973	.5935	.5087	.5935
4	.5087	.663	.5935	.5801	.5935	.5087	.5935
5	.5935	.663	.6001	.663	.5735	.5935	.5935
6	.6783	.663	.6706	.7459	.6783	.6783	.763
9	.4687	.4973	.4191	.4973	.4915	.5087	.5087
10	.4915	.4144	.4191	.4144	.4239	.4572	.5087
11	.3086	.4144	.3277	.4144	.4239	.4239	.4239
12	.463	.4144	.4191	.4144	.4239	.5087	.4239
13	.3906	.4144	.4239	.4144	.4239	.5087	.4239
14	.3906	.4144	.4191	.4973	.4239	.4239	.4239
15	.3858	.4144	.4239	.4144	.4239	.4239	.4239
16	.4687	.4144	.4191	.4144	.4239	.4249	.4239
17	.4744	.4973	.4191	.4144	.3391	.4239	.4096
18	.3953	.4973	.5087	.4973	.4239	.4239	.5087
19	.4687	.7459	.5868	.663	.6783	.6783	.5935
20	.703	.7459	.7545	.7459	.763	.763	.5935
21	.703	.7459	.7716	.663	.6783	.6783	.5935
22	.6249	.663	.6783	.6401	.6783	.6783	.5935
23	.6325	.4801	.5935	.5801	.5935	.5935	.5087
24	.5087	.663	.5868	.4973	.5735	.5087	.5935
Max	.703	.7459	.7716	.7459	.763	.763	.763
Min	.3086	.4144	.3277	.4144	.3391	.4239	.4096
Avg	.5079	.5643	.5367	.5301	.5369	.5334	.5312

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274079 / 33/11 KV MAINDARGI S/STN

Feeder No / Name : 209 / 11KV SALAGAR/UMERGE

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /

OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3391	.4973	.4144	.3315	.3315	.3391	.4239
2	.3391	.4973	.4144	.3315	.3315	.3391	.4239
3	.3353	.4973	.4144	.4144	.3315	.3391	.4239
4	.3391	.4973	.4144	.4144	.3315	.4915	.4239
5	.5144	.4973	.4973	.4973	.4973	.5935	.5087
6	.5935	.4973	.5801	.5801	.5801	.5468	.6783
9	.3277	.4144	.3315	.3315	.4973	.3391	.4239
10	.2458	.2486	.3315	.2486	.4973	.3391	.3391
11	.2543	.2486	.1658	.1658	.3315	.3391	.3391
12	.1638	.2486	.2486	.1658	.2486	.2543	.3391
13	.1638	.2486	.2486	.1658	.2486	.1696	.3391
14	.1638	.1658	.2486	.1658	.1658	.2543	.2543
15	.1696	.2486	.2486	.1658	.2486	.1696	.2543
16	.1638	.2486	.2486	.1658	.2486	.2543	.2543
17	.2543	.2486	.2486	.2486	.2486	.2543	.2543
18	.2543	.2486	.2486	.3315	.2486	.3391	.3391
19	.3277	.4973	.4144	.4144	.4144	.4239	.3391
20	.5935	.4973	.4973	.5801	.4973	.5087	.3391
21	.4858	.4973	.4144	.4973	.4144	.4239	.3391
22	.5087	.4144	.3315	.4144	.3315	.3391	.3391
23		.3315	.3315	.3315	.3315	.3391	.3391
24	.3353	.4973	.4144	.3315	.3315	.3239	.4239
Max	.5935	.4973	.5801	.5801	.5801	.5935	.6783
Min	.1638	.1658	.1658	.1658	.1658	.1696	.2543
Avg	.3273	.3767	.3503	.3315	.3503	.3509	.3699

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274086 / 33/11 KV KARAJGI

Feeder No / Name : 201 / 11 KV HILLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.583	.0343	.0343	.0343	.0343	.0572	.0343
2	.583	.0343	.0343	.0343	.0343	.0572	.0343
3	.6516						
4	.6859						
5	.7888						
6	.9431						
7	1.3375						
8	1.3203						
9		1.1145	1.1488	.9431	1.0288	1.1145	1.0288
10		1.1831	1.2003	1.0974	1.1488	1.1145	1.1145
11			1.2346	1.166	1.166	1.1831	1.2003
12			1.1831	1.2003	1.1831	1.166	1.166
13			1.2437	1.166	1.2346	1.1831	1.166
14			1.2003	1.0631	1.166	1.1145	1.1145
15	.0171		1.1831	1.1488	1.0631	1.166	1.2003
16	.0171		1.2003	1.2346	1.0117	1.286	1.2346
17	.0171	.0343	.0343	.0171	.0381	.0171	.0171
18	.0343	.0343	.0343	.0171	.0381	.0171	.0171
19	.0343	.0343	.0343	.0171	.0381	.0343	.0171
20	.0343	.0343	.0343	.0343	.0572	.0343	.0343
21	.0343	.0343	.0343	.0343	.0572	.0343	.0343
22	.0343	.0343	.0343	.0343	.0572	.0343	.0343
23	.0343	.0343	.0343	.0343	.0381	.0343	
24	.1715	.0343	.0343	.0343	.0343	.0381	.0343
Max	1.3375	1.1831	1.2437	1.2346	1.2346	1.286	1.2346
Min	.0171	.0343	.0343	.0171	.0343	.0171	.0171
Avg	.4068	.2201	.5521	.5173	.5238	.5381	.5578

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274086 / 33/11 KV KARAJGI

Feeder No / Name : 202 / 11 KV HANDRAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	1.7147	1.7318			1.7147
2	.12	1.7661	1.749			1.9033
3		1.8004	1.7833			1.9033
4		1.8861	1.8861			1.8861
5		1.9376	1.9204			2.0576
6		1.9719	2.0748			2.1434
7		2.0576				2.2291
8		2.1091	3.8752			2.1434
9	1.5432					
10	1.6289					
11	1.7147					
12	1.8861					
13	1.9719					
14	2.0576					
15	1.9719		.12		.0857	
16	1.8861		.12		.0857	
17	.0857	.0857			.1029	
18	.0857	.1029			.12	
19	.1029	.12			.1372	
20	.12	.1372			.1543	
21	.1372	.1372			.1543	
22	.1543	.1543			.1543	
23	1.4575	1.5432			1.4575	
24	.12	1.5432	1.5775	.0171		1.6975
Max	2.0576	2.1091	3.8752	.0171	1.4575	2.2291
Min	.0857	.0857	.12	.0171	.0857	1.6975
Avg	.9535	1.1917	1.6838	.0171	.2724	1.9643

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274086 / 33/11 KV KARAJGI

Feeder No / Name : 204 / 11KV KARJAGI GAOTHAN GAOTHAN FEEDER  
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1886	.1886		.1715
2	.1543	.2058	.2058		.1543
3	.1543	.2058	.2058		.1543
4	.2058	.2229	.2229		.2058
5	.3086	.2572	.2572		.2229
6	.2743	.2743	.2743		.2572
8	.2058	.2572	.2572		.2401
9	.1715	.2058	.2915	.1715	
10	.1886	.1886	.2572	.1715	
11	.1886		.2401	.1715	
12	.2058		.2058	.1543	
13	.2058		.1715	.1543	
14	.2058		.1715	.1543	
15	.2058		.1886	.1543	
16	.2058		.1715	.1715	
17	.2229	.1715		.2058	
18	.2401	.1715		.2229	
19	.2572	.1715		.2401	
20	.2401	.1715		.3086	
21	.2401	.1715		.2572	
22	.2401	.1543		.1886	
23	.2058	.1543		.1886	
24	.1715	.1715	.1715		.1715
Max	.3086	.2743	.2915	.3086	.2572
Min	.1543	.1543	.1715	.1543	.1543
Avg	.2110	.1967	.2176	.1943	.1972

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274086 / 33/11 KV KARAJGI

Feeder No / Name : 205 / 11 KV HILLI GAONTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1886	.1886	.1715	.1715	.2572	.1715
2	.1372	.2058	.2572	.1715	.1715	.2058	.1886
3	.1543	.2572	.2572	.1886		.2401	.1886
4	.2743	.3086	.2572	.2401	.3086	.2572	.2572
5	.3086	.3429	.2915	.3086		.3086	.3429
6	.4115	.3601	.3601	.3772	.3429	.3258	.4801
7	.4115	.3944		.4115	.3258	.3429	.3944
8	.3429	.3086	.2743	.2572	.3772	.3258	.3086
9	.2915	.3086	.2572	.2743	.2572	.2572	.3429
10	.2915	.2572	.2572		.2229	.2229	.1715
11	.2915		.2058	.2401	.2058	.2058	.2058
12	.2058		.2401		.1886	.2058	.2401
13	.1886		.1886	.1715	.2058	.1715	.2058
14	.1715		.2058	.1715	.2058	.1886	.1886
15	.1715		.1715	.1886	.2058	.1886	.1715
16	.1715		.2058	.2229	.1886	.2229	.1886
17	.2058	.2229	.2058	2.4348	.1886	.2229	.2058
18	.2229	.2572	.2058	.2743	.2058	.2572	.2401
19	.2572	.4287	.2401	.3086	.2572	.3429	.2743
20	.2915	.3086	.2743	.3772	.3086	.4801	.3086
21	.3086	.2572	.3772	.4115	.2572	.3601	.3601
22	.2743	.2572	.2572	.2743	.2743	.2915	.2572
23	.2572	.2401	.2058	.2229	.2572	.2572	
24	.1715	.1886	.1886	.1715	.1715	.2401	.2058
Max	.4115	.4287	.3772	2.4348	.3772	.4801	.4801
Min	.1372	.1886	.1715	.1715	.1715	.1715	.1715
Avg	.2486	.2829	.2423	.3577	.2408	.2658	.2565



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274086 / 33/11 KV KARAJGI

Feeder No / Name : 206 / 11 KV JEUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	.0857	.0857	.0953	.0857
2	.0857	.0857	.0857	.0857	.0953	.0857
9	1.166	.9431	.6859	1.0288	1.3375	1.1145
10	1.3032	1.0288	.8573	1.1145	1.3203	1.166
11		1.2003	.8573	1.0802	1.2003	1.5432
12		1.2003		1.0288	1.2003	1.1145
13		1.2003	.8573	1.0802	1.1317	.8573
14		1.1831	.9431	1.0631	1.1145	.8573
15		1.0974	.8573	1.046	1.1145	.8573
16		1.0974	.8573	1.0288	1.1145	1.0288
17	.0857	.0686	.0857	.0953	.0857	.0857
18	.0857	.0857	.0857	.0953	.0857	.0857
19	.0857	.0857	.0857	.0953	.0857	.0857
20	.0857	.0857	.0857	.0953	.0857	.0857
21	.0857	.0857		.0953	.0857	.0857
22	.0857	.0857	.0857	.0953	.0857	.0857
23	.0857	.0857	.0857		.0857	.0857
24	.0857	.0857	.0857	.0857	.0953	.0857
Max	1.3032	1.2003	.9431	1.1145	1.3375	1.5432
Min	.0857	.0686	.0857	.0857	.0857	.0857
Avg	.2772	.5439	.4179	.5470	.5789	.5220

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274086 / 33/11 KV KARAJGI

Feeder No / Name : 207 / 11 KV HANDRAL GOATHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	04-AUG-17	05-AUG-17
HR	Load (MW)	Load (MW)
4	.2401	
5	.3086	
6	.3772	
7	.4115	
24		.0857
<b>Max</b>	<b>.4115</b>	<b>.0857</b>
<b>Min</b>	<b>.2401</b>	<b>.0857</b>
<b>Avg</b>	<b>.3344</b>	<b>.0857</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274103 / 33/11 KV KORSEGAON S/S

Feeder No / Name : 201 / 11 KV SHEGAON MIX AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	1.0517		1.0974	1.0174	1.0402	1.0288
2	1.5623	1.0402		1.0974	1.0174	1.0402	1.0288
3	1.6404	1.0402		1.0974	1.0174	1.0402	1.0288
4	1.6404	.9536		1.0974	1.0174	1.0402	1.0288
5	1.6404	.9536		1.0974	1.0174	1.0402	1.0288
6	1.7966						
7	1.9528						
8	1.7966						
9		1.6975	1.2803	2.0243	1.8842	1.8747	1.9204
10		2.0243	1.989	2.1052	2.0833	2.13	2.0309
11		2.1605	2.2377	2.13	2.0062	2.0481	2.0062
12		2.2405	2.1548	2.0481	1.8747	1.9662	2.0062
13		2.2138	2.0481	2.0481	1.8747	1.9662	1.8747
14	.6935	2.0805	1.9662	1.9662	1.8519	1.9662	1.8976
15	.6935	2.0557	1.9662	1.8842	1.7966	1.9662	1.8747
16		1.9766	2.0481	1.8842	1.929	1.8842	1.6975
19	1.0402		1.0974	.9431	1.0402	.9431	1.0402
20	1.0517		1.1888	.9431	1.0402	1.0288	1.0402
21	.9536		1.1888	.9431	1.2136	1.0288	1.0402
22	.8669		1.1888	.9431	1.2269	1.0288	1.0402
23	1.0402		1.0974	1.0174	1.0402	1.0288	1.0402
24	1.6004	1.0402		1.0974	1.0174	1.0402	1.0288
Max	1.9528	2.2405	2.2377	2.13	2.0833	2.13	2.0309
Min	.6935	.9536	1.0974	.9431	1.0174	.9431	1.0288
Avg	1.3445	1.6092	1.6501	1.4455	1.4193	1.4264	1.4043

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274103 / 33/11 KV KORSEGAON S/S

Feeder No / Name : 202 / 11 KV S.JAWALAGE MIX AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.1734	.2572	.2743	.2715	.2572	.2686
2	.7716	.1734	.2572	.2743	.2715	.2601	.2686
3	.7811	.1734	.2572	.2743	.2715	.2601	.2686
4	.7811	.1734	.2572	.2743	.2715	.2601	.2686
5	.7716	.1734	.2572	.2743	.2715	.2601	.2686
6	1.2498						
7	2.2138						
8	1.8747						
9		1.3889	.9602	1.0174	1.1869	.9259	1.3565
10		1.3108	1.3108	1.1869	1.0802	1.0288	1.2346
11		1.2955	1.1469	1.1869	.9374	1.5432	1.2498
12		1.2803	1.3108	1.0174	.9374	1.286	.9259
13		1.2955	1.3108	1.0174	.9259	1.2003	.9259
14	.1734	1.2003	1.3108	1.1869	.7716	1.1869	.9374
15	.1734	1.3108	1.1336	1.1869	.7716	1.1869	.9145
16		1.2003	1.3927	1.3413	.9259	1.3565	.9374
19	.1734	.2601	.2743	.2743	.2601	.2686	.1734
20	.1753		.2743	.2743	.2601	.2686	.1734
21	.1734		.2743	.2743	.2572	.2686	.1753
22	.1734		.2743	.2743	.2601	.2686	.1734
23	.1734	.2601	.2743	.2715	.2601	.2686	.2601
24	.7716	.1734	.2572	.2743	.2715	.2601	.2686
Max	2.2138	1.3889	1.3927	1.3413	1.1869	1.5432	1.3565
Min	.1734	.1734	.2572	.2715	.2572	.2572	.1734
Avg	.7002	.7402	.6732	.6398	.5507	.6640	.5815

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274103 / 33/11 KV KORSEGAON S/S

Feeder No / Name : 203 / 11 KV KORSEGAON MIX AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3467	1.4661		.8097	1.4403	1.3889	1.4746
2	.3467	1.4661		.9717	1.4403	1.3889	1.4746
3	.3467	1.4661		1.2955	1.4403	1.4661	1.4746
4	.3467	1.406		1.2955	1.4403	1.4842	1.4746
5	.3506	1.3889		1.4575	1.4403	1.5623	1.4746
6	.3506	1.406		1.4575	1.5203	1.5432	1.4746
7	.2601	1.5623		1.6194	1.6804	1.6404	1.5565
8	.2601	1.4842		1.6194	1.6004	1.5432	1.6385
9	1.4661						
10	1.6404						
11	1.5432						
12	1.5432						
13	1.5623						
14	1.4661	.1715		.1772	.1543	.2686	.1734
15	1.4661	.1715		.1772	.2601	.2686	.1753
16	1.4842		1.2717				
19	.2601		.2743	.3582	.2601	.3544	.2601
20	.2601		.2743	.3582	.2601	.3544	.3506
21	.3467		.2743	.3582	.3467	.3544	1.3889
22	.3467		.2743	.3582	.3467	.3544	1.3889
23	1.3889		.7907	1.4403	1.3889	1.4746	1.3889
24	.3429	1.3889		.8097	1.4403	1.3889	1.4746
Max	1.6404	1.5623	1.2717	1.6194	1.6804	1.6404	1.6385
Min	.2601	.1715	.2743	.1772	.1543	.2686	.1734
Avg	.8057	1.2161	.5266	.9102	1.0287	1.0522	1.1652

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274103 / 33/11 KV KORSEGAON S/S

Feeder No / Name : 204 / 11 KV KUMTHA MIX FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0087	.1543	.2458	.1562	.181	.2315	.1772
2	.0087	.1543	.2401	.1562	.181	.2315	.1772
3	.0087	.1562	.2401	.1562	.181	.2286	.1772
4	.0087	.1543	.2458	.2343	.181	.2286	.1772
5	.0088	.1543	.2401	.2343	.181	.2286	.1772
6		.1543	.3201	.2343	.2715	.2286	.2658
7		.2343	.3201	.2343	.3582	.2315	.3506
8		.2315	.3277	.2343	.3506	.2315	.3506
9	.2315						
10	.2315						
11	.2343						
12	.2343						
13	.2315						
14	.2315	.0867	.0914	.0905	.0087	.0905	.0087
15	.2315	.0857	.0914	.0905	.0087	.0905	.0087
16	.2343						
19	.0087	.0857	.0914	.0914	.0087	.0905	.0087
20	.0087	.0857	.0914	.0914	.0088	.0905	.0087
21	.0088	.0857	.0914	.0914	.0087	.0905	.0087
22	.0087	.0857	.0914	.0914	.0087	.0905	.0087
23	.1543	.2429	.1562	.181	.2315	.1772	.1543
24	.0087	.1543	.2401	.1562	.181	.2315	.1772
Max	.2343	.2429	.3277	.2343	.3582	.2315	.3506
Min	.0087	.0857	.0914	.0905	.0087	.0905	.0087
Avg	.1106	.1441	.1953	.1577	.1469	.1745	.1398

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274103 / 33/11 KV KORSEGAON S/S

Feeder No / Name : 205 / 11 KV KALKARJAL MIX FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0087	.3086	.3277	.2343	.3544	.3858	.3506
2	.0088	.3086	.3277	.2343	.3506	.3858	.3506
3	.0087	.3906	.3239	.2343	.3506	.3906	.3506
4	.0088	.3906	.3201	.2343	.3506	.4687	.3506
5	.0087	.3906	.3201	.2343	.3506	.4687	.3506
6		.3858	.4001	.3906	.4287	.463	.5201
7		.5401	.4801	.5668	.6001	.6173	.6935
8		.5401	.4801	.5668	.6001	.4687	.6068
9	.3858						
10	.463						
12	.3858						
13	.3906						
14	.3858	.0867	.0914	.0905	.0087	.0905	.0088
15	.3125	.0857	.0914	.0905	.0087	.0905	.0087
16	.3086						
19	.0087	.0857	.0914	.0914	.0087	.0905	.0087
20	.0087	.0857	.0914	.0914	.0086	.0905	.0088
21	.0087	.0857		.0914	.0087	.0905	.0088
22	.0087	.0857	.0914	.0914	.0087	.0905	.0087
23	.3086	.3201	.2343	.3544	.3858	.3506	.3086
24	.0087	.3086	.3239	.2343	.3544	.3858	.3506
Max	.463	.5401	.4801	.5668	.6001	.6173	.6935
Min	.0087	.0857	.0914	.0905	.0086	.0905	.0087
Avg	.1682	.2749	.2663	.2394	.2611	.308	.2678

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274107 / 33/11 KV DUDHANI S/STN

Feeder No / Name : 201 / 11 KV RUDDAWADI AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.848	1.531	.0373	.056	.0377	.0373	.037
2	1.848	1.885	.0373	.056	.037	.0373	.0373
3	2.0328	1.9589					
4	2.1948	2.0328					
5	2.1719	2.0485					
6	2.5072	2.1216					
7	2.364	2.1719					
8	1.7909	2.1849					
9			1.4003	1.4784	1.1088	1.7556	1.848
10			2.1253	1.6461	1.3306	2.0119	1.9204
11			2.1948	2.0119	1.6095	2.3777	2.1033
12			2.1033	1.267	2.0119	2.2624	2.2624
13			1.9909	1.086	2.1719	2.1491	2.3282
14			1.9909	1.2536	2.364	2.2386	2.5072
15			2.2386	1.4327	2.1849	2.2386	2.5968
16			1.8804	1.6118	1.97	1.9879	2.6863
20	.0373		.056	.0373	.0373	.0373	.0373
21	.037	.0373	.056	.037	.0377	.0373	.0377
22	.037	.0373	.056	.0373	.0377	.0377	.0373
23	1.0974	.0373	.0554	.037	.0377	.0377	.0373
24	1.1458	1.1949	.0377	.0566	.0373	.0373	.037
Max	2.5072	2.1849	2.2386	2.0119	2.364	2.3777	2.6863
Min	.037	.0373	.0373	.037	.037	.0373	.037
Avg	1.4702	1.4368	1.0840	.8070	1.0009	1.1522	1.2342



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274107 / 33/11 KV DUDHANI S/STN

Feeder No / Name : 202 / 11 KV BOROTI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.2321
Max	.2321
Min	.2321
Avg	.2321

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274107 / 33/11 KV DUDHANI S/STN

Feeder No / Name : 203 / 11 KV DUDHANI AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.4854	.0377	.0377	.037	.0377	.0377
2	.4668	.5544	.0373	.0373	.037	.0377	.0377
3	.4668	.5544					
4	.5544	.5853					
5	.5487	.6584					
6	.905	.6878					
7	.9412	.6516					
8	.985	.5731					
9			.4108	.4668	.4066	.3881	.2801
10			.462	.5544	.4755	.4668	.3696
11			.5121	.6401	.5487	.5487	.4572
12			.543	.724	.5792	.4706	.543
13			.4525	.8145	.5792	.4525	.6335
14			.4525	.8954	.5014	.4477	.8954
15			.5068	1.0745	.5121	.4477	.8059
16			.543	1.0745		.2865	.7164
20	.0373		.0373	.0373	.0373	.0373	.0377
21	.037	.0373	.0373	.0373	.0373	.0377	.0377
22	.0373	.0377	.0373	.0373	.037	.0377	.0377
23	.4066	.0377	.0373	.0373	.0373	.0377	.0373
24	.3734	.4481	.0373	.0377	.0373	.0373	.0377
Max	.985	.6878	.543	1.0745	.5792	.5487	.8954
Min	.037	.0373	.0373	.0373	.037	.0373	.0373
Avg	.4718	.4426	.2763	.4337	.2759	.2514	.3310

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274107 / 33/11 KV DUDHANI S/STN

Feeder No / Name : 205 / Kallappawadi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0377	.8131	.5544	.4481	1.1458	1.1088
2	.0373	.0377	.8215	.5121	.4854	1.3443	1.2936
3			.9335	.4805	.4805	1.3817	1.386
4			.8316	.4854	.5175	1.4784	1.4937
5			.7316	.5544	.5487	1.3535	1.3306
6			.6878	.924	.9955	1.4266	1.086
7			1.0208	1.3169	1.0745	1.448	1.2536
8			1.0208	1.086	1.1641	1.0387	1.2715
9	.924	.7468					
10	1.2012	.9522					
11	1.134	1.3491					
12	1.0974	1.3352					
13	1.0498	1.0974					
14	1.0136	.788					
15	.9671	.985					
16	.7522	1.0208					
20	.0373		.0377	.0373	.0373	.0373	.0373
21	.0373	.0373	.0377	.0373	.056	.0377	.0373
22	.037	.056	.0362	.0373	.056	.0377	.0373
23	.0373	.5544	.462	.3734	.4481	.5601	.3696
24	.0373	.0377	.6468	.5544	.4435	.5601	.6161
Max	1.2012	1.3491	1.0208	1.3169	1.1641	1.4784	1.4937
Min	.037	.0373	.0362	.0373	.0373	.0373	.0373
Avg	.5600	.6454	.6216	.5349	.5196	.9115	.8709

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274107 / 33/11 KV DUDHANI S/STN

Feeder No / Name : 206 / 11KV DUDHANI GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-AUG-17
HR	Load (MW)
24	.2486
Max	.2486
Min	.2486
Avg	.2486

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274107 / 33/11 KV DUDHANI S/STN

Feeder No / Name : 207 / Sinnur Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
23	.1658
Max	.1658
Min	.1658
Avg	.1658

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274146 / 33/11kv Guddewadi Sub/Stn

Feeder No / Name : 201 / ALAGI MIX AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.8907	.9488	.8697	.9488	.8697	.6401
2	.1715	.8907	.9602	.8697	1.0279	1.0279	.6401
3	.1715	.9831	.9602	.8802	1.2003	1.0402	.6401
4	.1715	.9831	.9602	.8697	1.2003	1.1203	.6401
5	.1905	1.065	1.0402	1.004	1.2955	1.2289	.6401
6		1.1736	1.1203	1.2125	1.3927	1.2146	.9393
7		1.2289	1.1717	1.2289	1.3927	1.2289	1.004
8		1.2289	1.2803	1.2289	1.1336	1.2289	1.004
9	1.5089						
10	1.5927						
11	1.6108						
12	1.326						
13	1.326						
14	1.2431						
15	1.2574						
16	1.2574						
19	.0953	.1905	.1905	.1524	.1524	.2286	.1905
20	.0953	.1905	.1905	.1524	.1524	.2286	.2286
21	.0953	.1905	.1905	.1905	.1905	.2286	.2286
22	.0953	.1905	.1905	.1905	.1905	.2286	.1524
23	.8907	.8697	.8697	.8697	.8697	.5601	.8848
24	.1905	.8907	.8697	.8697	.9488	.8697	.6401
Max	1.6108	1.2289	1.2803	1.2289	1.3927	1.2289	1.004
Min	.0953	.1905	.1905	.1524	.1524	.2286	.1524
Avg	.7085	.7833	.7817	.7563	.8640	.8074	.6052

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274146 / 33/11kv Guddewadi Sub/Stn

Feeder No / Name : 202 / GUDDewADI AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	1.2003	1.0155	1.0279	1.1203	1.0402	1.0402
2	.0762	1.2003	1.0279	1.0279	1.1203	1.2003	1.0402
3	.0762	1.2146	1.0279	1.0279	1.2146	1.2003	1.0402
4	.0762	1.2146	1.0279	1.0279	1.2955	1.3765	1.0402
5	.0762	1.2146	1.1069	1.166	1.2955	1.3765	1.0402
6		1.326	1.186	1.3923	1.4746	1.4746	1.2452
7		1.3765	1.2346	1.094	1.4746	1.3765	1.3108
8		1.2146	1.2651	1.4255	1.4746	1.2955	1.3435
9	1.5746						
10	1.6575						
11	1.6766						
12	1.6385						
13	1.6385						
14	1.5565						
15	1.5746						
16	1.5746						
19	.0953	.0953	.0762	.0953	.0953	.0762	.0762
20	.0953	.0953	.0762	.0953	.0953	.0762	.0762
21	.0953	.0953	.0762		.0953	.0762	.0762
22	.0953	.0953	.0762	.0953	.0953	.0762	.0762
23	1.2003	1.0155	1.0279	1.0402	1.0402	.9922	1.0059
24	.0762	1.2003	1.0155	1.0279	1.0402	1.0402	1.0402
Max	1.6766	1.3765	1.2651	1.4255	1.4746	1.4746	1.3435
Min	.0762	.0953	.0762	.0953	.0953	.0762	.0762
Avg	.7858	.8970	.8029	.8880	.9237	.9055	.8180

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274146 / 33/11kv Guddewadi Sub/Stn

Feeder No / Name : 203 / GUDDWADI GAOTHAN FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3734	.3734	.3361	.4481	.4108	.3361
2	.3734	.3734	.3734	.3361	.4668	.4108	.3361
3	.3734	.3734	.3734	.3361	.4668	.4854	.3361
4	.4854	.3734	.3734	.3734	.5601	.4854	.3734
5	.5601	.5601	.4668	.5228	.5601	.5601	.4481
9	.1867	.2801	.1867	.2241	.1867	.2241	.2241
10	.1867	.2801	.168	.1867	.1867	.1867	.1867
11	.1867	.1867	.1494	.1867	.1867	.1494	.1886
12	.0934	.1867	.1494	.1867	.1867	.1494	.1886
13	.1867	.1867	.1494	.1867	.1867	.1494	.1886
14	.1867	.1867	.1494	.1867	.1867	.1494	.2263
15	.1867	.1867	.1494	.1867	.1867	.1867	.2241
16	.1867	.1867	.1494	.1867	.1867	.2241	.2241
17	.1867	.1867	.1867	.1867	.1867	.2241	.1867
19	.3734	.4668	.4481	.2801	.2801	.4481	.3361
20	.5601	.4668	.5601	.2801	.2801	.5601	.3361
21	.4668	.4668	.4854	.3734	.3734	.4481	.3734
22	.4668	.3734	.4481	.4481	.4481	.4108	.3734
23	.3734	.3734	.4108	.4481	.4481	.3361	.3734
24	.3734	.3734	.3734	.3734	.4481	.4108	.3361
Max	.5601	.5601	.5601	.5228	.5601	.5601	.4481
Min	.0934	.1867	.1494	.1867	.1867	.1494	.1867
Avg	.3183	.3221	.3062	.2913	.3230	.3305	.2898



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274146 / 33/11kv Guddewadi Sub/Stn

Feeder No / Name : 204 / 11KV ANKALGI PURE AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2939	.0953	.0953	.0953	.0953	.0953	.1905
2	2.3266	.0953	.0953	.0953	.0934	.0953	.1905
3	2.3758	.0953	.0953	.0953	.0953	.0953	.1905
4	2.3758	.0953	.0953	.0953	.0953	.0953	.1905
5	2.4249	.0953	.0953	.0953	.0953	.0953	.1905
6	2.5194						
7	2.4531						
8	2.42						
9		2.3205	2.1051	2.536	2.4194		2.2939
10		2.3482	2.4863	2.536	2.5301	2.4863	2.3266
11		2.5606	2.4863	2.6216	2.5606	2.5526	2.4143
12		2.4863	2.4863	1.0059	2.6406	2.5194	2.4813
13		2.5987	2.4863	2.5692	2.915	2.5029	2.5377
14		2.5692	2.4531	2.4577	2.915	2.4697	2.572
15		2.4034	2.4531	2.4577	2.4577	2.4531	2.4478
16		2.4034	2.3868	2.3482	2.3205	2.4531	2.3472
19	.0953	.0953	.0953	.0953	.0953	.0953	.0953
20	.0953	.0953	.0953	.0953	.0953	.0953	.0953
21	.0953	.0953	.0953	.0953	.0953	.0953	.0953
22	.0953	.0953	.0953	.0953	.0953	.0953	.0953
23	.0953	.0953	.0953		.0953	.1905	.0953
24	2.2119	.0953	.0953	.0953	.0953		.1905
Max	2.5194	2.5987	2.4863	2.6216	2.915	2.5526	2.572
Min	.0953	.0953	.0953	.0953	.0934	.0953	.0953
Avg	1.5627	1.0915	1.0732	1.0825	1.1476	1.0874	1.1074

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274151 / 33/11KV KUDAL SUB/STN

Feeder No / Name : 201 / ANDEWADI AG SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.6859		.381	.823		.6401
2	.056	.6859		.381	.823		.695
3		.7716		.381	.8573		.905
4		.8573		.381	.8573		.905
5		.8573		.5716	.8916		.9955
6		.8573		.7621	.8916		.9955
7		.8573		1.1431	.9431		1.0745
8		.8573		1.2384	.9431		1.0745
9	.7716						
10	.7716						
11	.8573						
12	.8573						
13	.8573						
14	.8573						
15	.823	.056	.0572	.056	.056	.056	.0373
16	.823	.056	.0572	.056	.056	.056	
17	.0934	.056	.0572	.056	.056	.056	.056
18	.0934	.056	.0572	.056	.056	.056	.056
19	.0934	.056	.0572	.056	.056	.056	.056
20	.0747	.056	.0572	.056	.0747	.056	.056
21	.0747	.056	.0572	.056	.056	.056	.056
22	.0747	.056	.0572	.8402	.056	.056	.056
23	.5765		.3429	.7716	.7716	.056	.6401
24	.056	.6001		.381	.7888		.5487
Max	.8573	.8573	.3429	1.2384	.9431	.056	1.0745
Min	.056	.056	.0572	.056	.056	.056	.0373
Avg	.4371	.4399	.0889	.4236	.5032	.056	.5204

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274151 / 33/11KV KUDAL SUB/STN

Feeder No / Name : 202 / SANGMESHVAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.0747	.056	.0381	.0747		.056
2	.6516	.0747	.056	.0381	.0747		.056
3	.6859						
4	.6859						
5	.7202						
6	.7373						
7	.7716						
8	.7716						
9		.8573	.9526	.8573	.6001	.8145	.8145
10		.9955	1.0479	.8916		.905	.905
11			1.0479	1.0288		.9955	.905
12			.9526	1.166	.6173	.9955	.8145
13			.8192	1.3546	.6516	.905	.724
14			.7621	1.5432	.6173	.905	.6401
15	.056		.7621	1.6289	.6859	.724	.6401
16	.056		.7621	1.6289	.6859	.6401	.6401
17	.056	.056	.0381	.056	.056	.056	.0373
18	.056	.056	.0381	.056	.0514	.056	.0373
19	.056	.056	.0381	.056	.056	.056	.0373
20	.056	.056	.0381	.0747	.056	.056	.0373
21	.0747	.056	.0381	.0747	.056	.056	.0373
22	.0747	.056	.0381	.0686	.056	.056	.0373
23	.0747	.056	.0381	.0747	.056	.056	.0373
24	.6001	.0747	.056	.0381	.0747		.056
Max	.7716	.9955	1.0479	1.6289	.6859	.9955	.905
Min	.056	.056	.0381	.0381	.0514	.056	.0373
Avg	.3798	.2057	.4190	.5930	.2794	.4851	.3618

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274151 / 33/11KV KUDAL SUB/STN

Feeder No / Name : 203 / DEVIKAWATHA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.2458
Max	.2458
Min	.2458
Avg	.2458

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274156 / 33/11KV MOTYAL SUB/STN

Feeder No / Name : 201 / 11KV KURNUR (MIX AG) SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	1.3575	1.9528	1.7654	1.7747	2.0309	2.1538
2	.0762	1.386	2.0243	1.8185	1.8435	1.9997	2.1862
3	.0762	1.5158	1.9845	1.8185	1.8818	2.0557	2.2024
4	.0762	1.7008	2.0325	1.9204	1.9204	2.1032	2.2348
5	.0762	1.7833	2.0729	1.9757	1.8903	2.1348	2.3205
6		2.0466	2.2348	2.2611	2.0873	2.2531	2.649
7		2.3403	2.5232	2.4939	2.284	2.4059	2.649
8		2.0934	2.5263	2.4006	2.3611	2.4371	2.652
9	2.4129						
10	2.5425						
11	2.4413						
12	2.5396						
13	2.5425						
14	2.5126						
15	2.3758						
16	2.4086						
20	.1143	.0953	.1143	.1143	.1143	.1334	.1143
21	.0953	.0762	.1143	.1143	.1143	.1143	.1334
22	.0953	.0953	.1143	.1143	.0953	.1143	.1143
23	1.5718	1.9364	1.7185	1.8084	1.9766	2.1862	2.0081
24	.0762	1.3336	1.9685	1.7654	1.8185	2.0241	2.1538
Max	2.5425	2.3403	2.5263	2.4939	2.3611	2.4371	2.652
Min	.0762	.0762	.1143	.1143	.0953	.1143	.1143
Avg	1.2283	1.3662	1.6447	1.5670	1.5509	1.6917	1.8132

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274156 / 33/11KV MOTYAL SUB/STN

Feeder No / Name : 202 / 11kv KURNUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.1905	.2286	.2286	.2286	.2286	.2286
2	.2286	.2096	.2286	.2477	.2858	.2286	.2286
3	.2667	.2286	.2858	.2858	.362	.2477	.2667
4	.3239	.2286	.3239	.3429	.4108	.2667	.3239
5	.4001	.4572		.4763	.5249	.362	.381
6	.5552	.4572	.5906	.5611	.567	.567	.5716
7	.4954	.442	.4954	.5792		.5611	.5525
8	.4763	.4954	.4382	.4656	.4854	.5041	.4572
9	.3048	.3239	.3239	.394	.4001	.4191	.4001
10	.1715	.2096	.2286	.2667	.2477	.2858	.3239
11	.1334	.2096	.1715	.2667	.1715	.2096	.2858
12	.1334	.1334	.1143	.1715	.1143	.1524	.2667
13	.1334	.1334	.1334	.1524	.1334	.1334	.1905
14	.1143	.1334	.1143	.1143	.0953	.1334	.1334
15	.1143	.1143	.1143	.1143	.1334	.1334	.1524
16		.1334		.1334	.1334	.1905	.1715
17	.1715	.1905		.1715	.1715	.1715	.1715
18	.3239	.2286		.2096	.3239	.2477	.1905
19	.362	.3429	.298	.3292	.381	.4382	.2477
20	.4572	.4954	.4763	.4656	.2858	.4572	.333
21	.3239	.362	.3429	.362	.3239	.3429	.2667
22	.2477		.2667	.2858	.2477	.2858	.2477
23	.2096	.2286	.2286	.2096	.2286	.2286	.2096
24	.2096	.1905	.2096	.2096	.2096	.2096	.2096
Max	.5552	.4954	.5906	.5792	.567	.567	.5716
Min	.1143	.1143	.1143	.1143	.0953	.1334	.1334
Avg	.2768	.2669	.2807	.2935	.2811	.2919	.2838

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274156 / 33/11KV MOTYAL SUB/STN

Feeder No / Name : 203 / 11 KV Badole Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7499	.0572	.0572	.0286	.0286	.0572	.0381
2	.7499	.0572	.0381	.0286	.0572	.0381	.0381
3	.7655	.0572	.0381	.0381	.0381	.0381	.0381
4	.7811	.0572	.0381	.0381	.0381	.0381	.0381
5	.787	.0572	.0381	.0381	.0381	.0381	.0381
6	1.1363				.0381		
7	1.2963						
8	1.1227						
9		.8025	.9488	.8128	.7579	.8592	.8749
10		.9602	1.0911	.8993	.9922	1.0437	1.0562
11		1.0911	1.1523	.9297	1.078	1.1523	1.0082
12		.8905	1.186	.8768	1.1702	1.1523	1.1683
13		.8539	1.0936	.9259	1.078	1.1363	1.0936
14		1.0242	1.0623	.8509	1.0936	1.0311	1.0031
15		1.1092	1.0753	.8509	1.034	.9998	1.0279
16		1.078	1.0185	1.0059	1.0494	1.0623	.9907
20	.1143	.0762	.0194	.0229	.0953	.0572	.0286
21	.1143	.0762	.0187	.0229	.0953	.0572	.0229
22	.0953	.0572	.0227	.0381	1.0098	.0572	.0229
23	.0572	.0572	.0191	.0286	.0572	.0381	.0381
24	.7907	.0572	.0572	.0286	.0286	.0572	.0381
Max	1.2963	1.1092	1.186	1.0059	1.1702	1.1523	1.1683
Min	.0572	.0572	.0187	.0229	.0286	.0381	.0229
Avg	.6585	.4678	.4986	.4147	.5146	.4952	.4758

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274180 / AKKALKOT TOWN SUB-STATION

Feeder No / Name : 201 / 11 KV AKKALKOT URBAN SHEDDABLE URBAN

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.267	1.3443	1.2803	1.2803	1.3306	1.3169	1.4266
2	1.2489	1.2986	1.2803	1.262	1.2936	1.2803	1.39
3	1.2489	1.2803	1.262	1.262	1.2936	1.2803	1.39
4	1.267	1.2803	1.2803	1.2803	1.3306	1.2803	1.4266
5	1.3032	1.3169	1.3535	1.3169	1.3306	1.3169	1.4266
6	1.4045	1.3535	1.4449	1.4266	1.386	1.39	1.4632
7	1.386	1.3169	1.4449	1.4632	1.4415	1.4632	1.4998
8	1.3491	1.2986	1.2986	1.3535	1.4045	1.4083	1.4083
9	1.2197	1.2803		1.2437	1.2803	1.3352	1.3535
10	1.2936	1.307		1.2986	1.3535	1.39	1.3717
11	1.386	1.3169		1.3535	1.4449	1.3535	1.3352
12	1.386	1.3169		1.3352	1.4083	1.3717	1.3676
13	1.4415	1.3717		1.3535	1.4815	1.3717	1.423
14	1.423	1.3535		1.3676	1.4632	1.39	1.39
15	1.4045	1.3169		1.3491	1.3535	1.4266	1.4045
16		1.2803		1.3491	1.4632	1.4632	1.386
17		1.2071		1.3676	1.4083	1.4266	1.3676
18		1.2437		1.3306		1.3535	1.386
19		1.2803		1.6632		1.7558	1.6461
20		1.262		1.9035		1.9022	1.6827
21		1.7375		1.8111		1.7924	1.6827
22		1.6095		1.6632		1.701	1.5729
23		1.4266		1.5154		1.5546	1.4266
24	1.3213	1.3817	1.2986	1.3352	1.386	1.39	1.4632
Max	1.4415	1.7375	1.4449	1.9035	1.4815	1.9022	1.6827
Min	1.2197	1.2071	1.262	1.2437	1.2803	1.2803	1.3352
Avg	1.3344	1.3409	1.3270	1.4119	1.3808	1.4464	1.4454



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274180 / AKKALKOT TOWN SUB-STATION

Feeder No / Name : 202 / 11 KV SAMARTH NAGAR FEEDER SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5359	.5415	.5415	.5228	.5975	.5975	.6535
2	.6036	.5228	.5228	.5228	.5601	.5601	.6348
3	.6036	.5281	.5228	.5228	.5601	.5601	.5975
4	.6036	.5601	.5415	.5601	.5975	.5975	.5975
5	.6161	.5975	.5601	.5975	.6161	.5975	.6348
6	.6722	.6348	.6161	.6535	.6535	.6535	.6722
7	.7545	.6535	.7095	.7468	.6908	.7655	.7842
8	.679	.6722	.6908	.6722	.6535	.7468	.7468
9	.6413	.7468		.6722	.5601	.7095	.7095
10	.6413	.6908		.4481	.7023	.6535	.7468
11	.5975	.4294		.5975	.6099	.5601	.9335
12	.6161	.5041		.5788	.7023	.6535	.5975
13	.6161	.5788		.5601	.7392	.6908	.6161
14	.5601	.5041		.4481	.7023	.6535	.5788
15	.5415	.5041		.4854	.499	.6535	.5041
16	.5601	.5041		.5415	.5544	.5975	.5601
17	.5788	.7655		.5601	.7023	.6161	.5228
18	.6535	.5415		.6161		.6722	.4854
19	.5788	.5601		.5041		.6722	.5601
20	.5601	.5975		.6348		.6722	.6908
21	.7095	.7468		.7468		.7655	.7468
22	.8215	.6908		.7842		.7842	.7282
23	.6535	.6722		.7095		.7095	.7095
24	.5359	.5415	.5487	.4527	.6348	.6348	.6722
Max	.8215	.7655	.7095	.7842	.7392	.7842	.9335
Min	.5359	.4294	.5228	.4481	.499	.5601	.4854
Avg	.6223	.5954	.5838	.5891	.6298	.6574	.6535

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274180 / AKKALKOT TOWN SUB-STATION

Feeder No / Name : 203 / 11 KV Swami Vihar FEEDER SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0274	.0255	.0251	.0251	.0251	.0263	.0263
2	.0274	.0255	.0251	.0251	.0251	.0263	.0255
3	.0274	.0255	.0251	.0251	.0251	.0263	.0255
4	.0274	.0255	.0255	.0255	.0251	.0263	.0255
5	.0274	.0255	.0255	.0255	.0251	.0263	.0255
6	.0286	.0255	.0255	.0255	.0251	.0263	.0394
7	.0286	.0255	.0259	.0251	.0251	.0263	.0394
8	.0274	.0255	.0251	.0251	.0251	.0263	.0394
9	.0267	.0255		.0377	.0251	.0131	.0263
10		.0383		.0377	.0251	.0394	.0263
11		.0255		.0503	.0377	.0394	.0394
12		.0255		.0503	.0251	.0263	.0263
13		.0383		.0377	.0251	.0263	.0263
14		.0383		.0251	.0251	.0394	.0263
15		.0383		.0251	.0362	.0263	.0263
16		.0383		.0251	.0251	.0263	.0263
17		.0383		.0377	.0251	.0263	.0394
18		.0383		.0251		.0263	.0394
19		.0383		.0251		.0259	.0255
20		.0383		.0251		.0255	.0255
21		.0255		.0251		.0255	.0255
22		.0255		.0251		.0259	.0255
23		.0255		.0251		.0394	.0128
24	.0286	.0255	.0251	.0251	.0251	.0263	.0263
Max	.0286	.0383	.0259	.0503	.0377	.0394	.0394
Min	.0267	.0255	.0251	.0251	.0251	.0131	.0128
Avg	.0277	.0303	.0253	.0294	.0264	.0278	.0287

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274206 / 33/11 KV KINI SUBSTATION

Feeder No / Name : 201 / 11 KV GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.2801	.2429	.2614	.2614	.2614	.2957
2	.2987	.2801	.2801	.2614	.2614	.2614	.2957
3	.2987	.3174	.3361	.2801	.3361	.3361	.3326
4	.4481	.4668		.3361	.3734	.4108	.3326
5	.5228	.5601	.6535	.4481	.4854	.5228	.4066
6	.5975	.6348	.7468	.7095	.6653	.7095	.4668
7	.5228	.5601	.6161	.5975	.5914	.6653	.5228
8	.4668	.4108	.3921	.4108	.4854	.5601	.5601
9	.3361	.3361	.3361	.2614	.3547	.3734	.3734
10	.2614	.2427	.2241	.2614	.2427	.2614	.3361
11	.2241	.1867	.1494	.1867	.1867	.2241	.2987
12	.1494	.2054	.1494	.1494	.1867	.1494	.2801
13	.1867	.1867	.0934	.1494	.1494	.1494	.2427
14	.1867	.1494	.1494	.1494	.1867	.1867	.1867
15	.1867	.1494	.1494	.1494	.1867	.1494	.1867
16	.2241	.1494	.1494	.1867	.1867	.1867	.2241
17	.2614	.2427	.1867	.2241	.2241	.1867	.2241
18	.2801	.3361	.2987	.2801	.2241	.2801	.2987
19	.3734	.4668	.3734	.4108	.4108	.3361	.3734
20	.4854	.5601	.4854	.5228	.5228	.5228	.4668
21	.3734	.4668	.5228		.4108	.3734	.4294
22	.2987	.3734	.2987	.4108	.3361	.3361	.3734
23	.2801	.3174	.2614	.2614	.2614	.2801	.2987
24	.2987	.2801	.2801	.2614	.2614	.2614	.2614
Max	.5975	.6348	.7468	.7095	.6653	.7095	.5601
Min	.1494	.1494	.0934	.1494	.1494	.1494	.1867
Avg	.3275	.3400	.3207	.3117	.3247	.3327	.3361

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274206 / 33/11 KV KINI SUBSTATION

Feeder No / Name : 202 / 11 KV KINI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3441						
2	1.3441						
3	1.3441						
4	1.3441						
5	1.4403						
6	1.8671						
7	1.8564						
8	1.7924						
9		1.5813	1.7711	1.4723	1.4723	1.6129	1.6004
10		1.7394	1.9292	1.8404	1.7284	1.7924	1.7924
11		1.8976	2.0165	1.8404	1.7604	1.9524	1.7604
12		1.8976	1.9845	1.7604	1.8884	1.9204	1.7604
13		1.6129	1.8404	1.7924	1.7284	1.8244	1.7604
14		1.7394	1.8564	1.7604	1.8564	1.7924	1.2803
15		1.7394	1.8884	1.8404	1.8244	1.6964	1.7604
16		1.2651	1.7924	1.8564	1.9204	1.8244	1.6964
24	1.3599						
Max	1.8671	1.8976	2.0165	1.8564	1.9204	1.9524	1.7924
Min	1.3441	1.2651	1.7711	1.4723	1.4723	1.6129	1.2803
Avg	1.5214	1.6841	1.8849	1.7704	1.7724	1.8020	1.6764

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274206 / 33/11 KV KINI SUBSTATION

Feeder No / Name : 203 / 11 KV KAZIKANBUS AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8002	.8907	.9259	.9877	1.0031	1.0311
2		.8002	.9393	.9259	1.0031	1.0031	1.0623
3		.8322	.9717	.9259	1.0031	.9877	1.1248
4		.8802	1.004		1.0031	.9877	1.1561
5		.9602	1.0526	.9568	1.0936	.9877	1.1561
6		1.0242	1.1336	.9804	1.2018	1.1111	1.2186
7		1.2003	1.247	1.2018	1.3599	1.2963	1.2186
8		1.1683	.9717	1.186	1.4403	1.358	1.2811
9	.9214						
10	1.1111						
11	1.2346						
12	1.2963						
13	1.2346						
14	1.2346						
15	1.2037						
16	1.2037						
23	.7042	.8421	.9069	.8128	.9259	1.0311	1.0562
24		.8002	.8907	.9259	.9877	.9877	1.0311
Max	1.2963	1.2003	1.247	1.2018	1.4403	1.358	1.2811
Min	.7042	.8002	.8907	.8128	.9259	.9877	1.0311
Avg	1.1271	.9308	1.0008	.9824	1.1006	1.0754	1.1336

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274228 / 33/11 KV Mirajgi Sub-station

Feeder No / Name : 201 / 11 KV Hattikanbas Ag FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.8223	1.0031	.7716	1.0031	1.0155	1.0936
2	.0857	.8223	1.0031	.7716	1.0031	1.0155	1.0936
3	.0876	.8223	1.0031	.7716	1.0279	1.0155	1.0936
4	.0905	.8223	1.0031	.7811	1.0279	1.0155	1.1717
5	.1463	.9488	1.3117	.9217	1.186	1.0936	1.4232
6	.1848	1.0562	1.3889	1.0467	1.2346	1.186	1.6324
7		1.5181	1.3889	1.5844	1.531	1.7814	1.6964
8		1.5497	1.3117	1.5278	1.7284	1.7814	1.6762
9	1.4784						
10	1.5935						
11	1.7078						
12	1.7029						
13	1.6404						
14	1.656						
15	1.6248						
16	1.5741						
19	.1387	.0633	.0983	.0648	.12	.0762	.1029
20	.1387	.0781		.0663	.1187	.0762	.08
21	.12	.0781		.1006	.1187	.0762	.0791
22	.0949	.0781	.0914	.0791	.0937	.0762	.08
23	.6093	.9259	.6321	.9374	.9259	1.0031	1.1336
24	.0838	.8223	1.0031	.7621	1.0031	1.0155	1.0802
Max	1.7078	1.5497	1.3889	1.5844	1.7284	1.7814	1.6964
Min	.0838	.0633	.0914	.0648	.0937	.0762	.0791
Avg	.7422	.7434	.9365	.7276	.8659	.8734	.9598

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274228 / 33/11 KV Mirajgi Sub-station

Feeder No / Name : 202 / 11 KV Basalegaon Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9722	.0762	.0772	.0772	.0617	.0625	.0781
2	.9722	.0762	.0772	.0772	.0625	.0633	.0781
3	.9722	.0762	.0772	.0772	.0625	.0633	.0791
4	.9722	.0762	.0772	.0772		.0633	.0791
5	1.1574	.061	.0772	.0772	.0617	.0655	.0791
6	1.2654	.0457	.0772	.0772	.0625	.0655	.0648
7	1.4043						
8	1.3889						
9		1.1111	.8488	1.0185	1.2955	1.2323	1.0802
10		1.3117	.9259	.4784	1.5203	1.4403	1.387
11		1.3889	1.0185	.4938	1.6194	1.5384	1.5432
12		1.3117	1.1728	.4938	1.6518	1.6356	1.4661
13		1.3117	1.358	.6636	1.5384	1.4899	1.4937
14		1.2346	1.4043	.7407	1.3923	1.4403	1.3889
15		1.3889	1.4198	.6944	1.4403	1.4403	1.3117
16		1.3117	1.4043	.5864	1.4723	1.4883	1.2955
19	.108	.0772		.0309	.061	.0762	.0617
20	.1387	.0772		.0457	.0781	.0772	.061
21	.0617	.0772		.061	.0781	.0772	.0762
22	.0772	.0772	.0617	.0617	.0781	.0762	.0772
23	.0772	.0772	.0772	.0617	.0625	.0772	.0762
24	.9722	.0762	.0762	.0772	.0617	.0625	.0781
Max	1.4043	1.3889	1.4198	1.0185	1.6518	1.6356	1.5432
Min	.0617	.0457	.0617	.0309	.061	.0625	.061
Avg	.7528	.5622	.6018	.2986	.6664	.6268	.5928

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274228 / 33/11 KV Mirajgi Sub-station

Feeder No / Name : 203 / 11 KV Mirajgi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2402	.2587	.2772	.2772	.2241	.1867	.1867
2	.2402	.2587	.2772	.2772	.2241	.1867	.1867
3	.2402	.2587	.2772	.2772	.2241	.1867	.1867
4	.2402	.2587	.2772	.2772	.2218	.2241	.1867
5	.3326	.3696	.2957	.3142	.3326	.3326	.3547
6	.3881	.4066	.3326	.3696	.4435	.4066	.3881
7	.2587	.2218	.2402	.2957	.2772	.2402	.2218
8	.2218	.1663	.2218	.2402	.1848	.2427	.1848
9	.1663	.1848	.1848	.1848	.1478	.1867	.1848
10	.1478	.1478	.1478	.1478	.112	.1494	.1478
11	.1294	.1478	.1478	.1478	.0934	.1109	.1478
12	.1294	.1294	.1663	.1294	.112	.1109	.1478
13	.1294	.1294	.1478	.1848	.112	.1294	.1494
14	.1294	.1294	.1109	.1109	.112	.1294	.1494
15	.1294	.1109	.1663	.1294	.1307	.1294	.1848
16	.1478	.1478	.1478	.1478	.1307	.1478	.1848
17	.1294	.1663		.1478	.168	.1478	.1848
18		.2218		.1478	.2054	.1478	.2218
19	.2587	.1109		.1848	.2772	.2218	.2772
20	.3326	.2957		.2772	.3142	.2772	.2772
21	.2957	.2957		.2772	.3142	.3142	.2587
22	.2587	.2402	.2772	.2218	.2402	.2402	.2587
23	.2218	.2587	.2218	.2218	.1867	.2218	.2218
24	.2402	.2587	.2772	.2772	.2241	.1867	.1867
Max	.3881	.4066	.3326	.3696	.4435	.4066	.3881
Min	.1294	.1109	.1109	.1109	.0934	.1109	.1478
Avg	.2177	.2156	.2208	.2195	.2089	.2024	.2117



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 277007 / 132KV/33/11KV AKKALKOT S/S

Feeder No / Name : 202 / 11 KV CHAPALGAON MIX AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.2486
Max	.2486
Min	.2486
Avg	.2486

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 277007 / 132KV/33/11KV AKKALKOT S/S

Feeder No / Name : 203 / 11 KV RLY-STATION AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.2915
Max	.2915
Min	.2915
Avg	.2915

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 277007 / 132KV/33/11KV AKKALKOT S/S

Feeder No / Name : 204 / 11 KV WATER WORKS AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.2458
Max	.2458
Min	.2458
Avg	.2458

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 277007 / 132KV/33/11KV AKKALKOT S/S

Feeder No / Name : 205 / 11 KV KARJAL AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.2486
Max	.2486
Min	.2486
Avg	.2486

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 277007 / 132KV/33/11KV AKKALKOT S/S

Feeder No / Name : 206 / SUGAR FACTORY EX. FEEDER SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17
HR	Load (MW)
24	.2458
Max	.2458
Min	.2458
Avg	.2458

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 277007 / 132KV/33/11KV AKKALKOT S/S

Feeder No / Name : 207 / 11 KV KARJAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.2486
Max	.2486
Min	.2486
Avg	.2486

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 277007 / 132KV/33/11KV AKKALKOT S/S

Feeder No / Name : 407 / Matoshri-I co gen.

Feeder KV- 33 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.2458
Max	.2458
Min	.2458
Avg	.2458

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 277029 / 132/33KV KARAJGI EHV SUB  
STATAFeeder No / Name : 404 / 33KV ENRICH FEEDER NO 1  
Feeder KV- 33 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.2486
Max	.2486
Min	.2486
Avg	.2486



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 277029 / 132/33KV KARAJGI EHV SUB  
STATAFeeder No / Name : 408 / 33KV ENRICH FEEDER NO 2  
Feeder KV- 33 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.7459
Max	.7459
Min	.7459
Avg	.7459

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274073 / 33/11 KV ANAGAR

Feeder No / Name : 201 / 11 KV ANAGAR AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17
HR	Load (MW)	Load (MW)
8		1.7204
24	.2896	
Max	.2896	1.7204
Min	.2896	1.7204
Avg	.2896	1.7204

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274073 / 33/11 KV ANAGAR

Feeder No / Name : 202 / 11 KV KOMBADWADI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.3048
Max	.3048
Min	.3048
Avg	.3048

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274073 / 33/11 KV ANAGAR

Feeder No / Name : 203 / 11 KV KHANDOBACHIWADI AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.3048
Max	.3048
Min	.3048
Avg	.3048

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274073 / 33/11 KV ANAGAR

Feeder No / Name : 204 / 11 KV PASALEWADI MIX AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.7202	.081	.0857	.0819
2			.7202	.081	.0857	.0829
3			.7202	.08	.0857	.081
4			.7373	.0819	.0857	.08
5			.7373	.08	.0857	.0819
9			.7888	.9717	1.4899	1.0402
10		.3944	.9175	1.2146		
11		.3429	.9555	1.5604	1.3435	1.2174
12		.3429	.9831	1.5432	1.2289	1.3203
13		.3429	1.1603	1.5432		1.4548
14		.3086	1.2616	1.5775	1.1336	1.6289
15		.3086	1.3927	1.5424		1.5604
16		.3944	1.2289	.9431		
17		.463		.9945		
18		.5316				
19		.6859				
20		.6935			.081	.0857
21		.7202			.0819	.0857
22		.7202	.081	.1029	.032	.0857
23		.7373	.0819	.1029	.08	.0857
24	.3048		.7455	.08	.0857	.081
Max	.3048	.7373	1.3927	1.5775	1.4899	1.6289
Min	.3048	.3086	.081	.08	.032	.08
Avg	.3048	.4990	.827	.7400	.4275	.5658

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274073 / 33/11 KV ANAGAR

Feeder No / Name : 205 / 11 KV ANAGAR GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5144		.5144	.4915	.5144	.4858
2	.5144	.5144		.5144		.5144	.4801
3	.6001	.5144		.6001	.4858	.5144	.4915
4	.7716	.6001		.6859	.5801	.6001	.6554
5	.9431	.9431		.9431	.8907	.9431	1.0322
6	1.1145						.9717
7	1.2003	.7716		.8573	.7701	.7716	.7373
8	1.0288	.7716		.6859	.5668	.7716	.7865
9	.6859	.5144		.5144			.5506
10			.5144	.4534	.4287		.4915
11	.6001		.5201	.4001		.4915	.5144
12	.6001		.5144			.4858	.5144
13	.6001		.5144	.4973	.6859		.5144
14	.5144		.5144	.4915	.6859	.8192	.5144
15	.5144		.5316	.5735	.6001		.5144
16	.5144		.6001	.6554	.6859		.6001
17	.6859		.6859	.7287	.7716	.7773	.6001
18	.6859			.7045	.7716	.8002	.7011
19	.8573			.7865	.8573	1.0159	.7888
20	1.0288		1.0288	1.1469	1.2003	1.0774	.9431
21	.7716		.9431	.9012	.9431	.9012	.7716
22	.6859		.7716	.7202	.7716	.7373	.6859
23	.6001		.6001	.5735	.6001	.5735	.6001
24	.5144	.5144		.5144	.4801	.5144	.5735
Max	1.2003	.9431	1.0288	1.1469	1.2003	1.0774	1.0322
Min	.5144	.5144	.5144	.4001	.4287	.4858	.4801
Avg	.7194	.6287	.6449	.6574	.6983	.7124	.6466

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274074 / 33/11 KV BEGAMPUR

Feeder No / Name : 201 / 11 KV ARDHANARI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.4049	.0171	.0162	.0171	.0171	.0171
2	.3048	.3239	.0171	.0162	.0171	.0171	.0152
3	.2286	.3239					
4	.2286	.2429					
5	.3048	.2429					
6	.2286	.4049		.0162			
7	.2286	.3725					
8	.2286	.4049					
9			.2286	.381	.2572	1.6194	2.1338
10				.4572	.2286	1.749	1.5242
11			.3429	.4572	.2286	1.7814	1.9357
12			.3429	.381	.2286	1.7204	2.0576
13			.3429	.381	.2286	1.7814	2.1033
14			.3429	.381	.2286	1.7924	2.1338
15			.3429	.3048	.2286	1.6842	1.9814
16			.3429	.3048	1.1431	1.7004	1.9814
17	.0154	.0171	.0162	.0171	.0152	.0171	
18	.0156	.0171	.0162	.0171	.0171	.0171	.0152
19	.0156	.0171	.0162	.0171	.0171	.0171	.0152
20	.0156	.0171	.0162	.0171	.0171	.0171	.0152
21	.0158	.0171	.0162	.0171	.0171	.0171	.0152
22	.0162	.0171	.0162	.0171	.0171	.0171	.0152
23	.4858	.0171	.0162	.0171	.0171	.0171	.0152
24	.4268	.4049	.0171	.0162	.0171	.0171	.0171
Max	.4858	.4049	.3429	.4572	1.1431	1.7924	2.1338
Min	.0154	.0171	.0162	.0162	.0152	.0171	.0152
Avg	.1963	.2028	.1442	.1701	.1634	.7778	.9407

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274074 / 33/11 KV BEGAMPUR

Feeder No / Name : 202 / 11 KV ARBALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1296	1.2803	1.278	1.5089	2.5606	3.5151
2	.1372	.1296	1.3108	1.2163	1.4746	2.5606	3.5665
3			1.2955	1.2163	1.4746	2.5606	3.5151
4			1.2955	1.2452	1.4403	2.5758	3.4294
5			1.3108	1.2887	1.5432	2.5758	2.9874
6			1.4327	1.4266		2.652	3.0483
7			1.6004	1.8364		2.8045	3.1093
8			1.7223	1.5697	1.7833	3.1093	3.155
9	1.9509	2.037					
10	2.1948	2.0729					
11	2.1338	1.9966					
12	2.1033	2.0424					
13	1.768	1.89					
14	1.829	1.5851					
15	1.89	1.6461					
16	1.7071	1.6156					
17	.0975	.0514	.096	.0514	.1219	.1543	
18	.1166	.1715		.0514	.2229	.1715	.12
19	.1189	.1543	.1395	.0514	.2401	.1715	.1036
20	.1486	.1543	.1505	.0514	.2058	.1715	.1052
21	.1372	.1543	.1204	.0514	.1715	.1715	.1238
22	.1562	.1715	.1204	.0514	.1715	.1543	.0991
23	.125	1.2651	1.4937	1.5775	2.3167	2.5339	3.2156
24	.1543	.1296	1.3717	1.3717	1.5432	2.6216	2.9416
Max	2.1948	2.0729	1.7223	1.8364	2.3167	3.1093	3.5665
Min	.0975	.0514	.096	.0514	.1219	.1543	.0991
Avg	.9392	.9665	.9827	.8959	1.0156	1.7218	2.2023



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274074 / 33/11 KV BEGAMPUR

Feeder No / Name : 203 / 11 KV BEGAMPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8078	1.004	.0514	.056	.0514	.0514	.0514
2	.7621	1.004	.0514	.056	.0514	.0514	.0514
3	.7621	1.0202					
4	.8993	1.0526					
5	.9755	1.0031					
6	1.6004	1.2654					
7	1.7833	1.7814					
8	1.6613	1.5497					
9			1.4937	1.2193	1.7147	1.6057	1.5699
10			1.8176	1.4632	1.6918	1.8564	1.5851
11			1.5432	1.4632	1.387	1.8896	1.5699
12			1.4403	1.448	1.6613	1.8351	1.6004
13			1.5775	1.3717	1.6766	1.7604	1.5242
14			1.4403	1.2803	1.4937	1.7078	1.4937
15			1.5089	1.1584	1.448	1.6964	1.4175
16				1.2193	1.4175	1.5844	1.2193
17	.0566	.0514	.056	.0514	.0514	.0514	
18	.056	.0514	.056	.0514	.0514	.0514	.0543
19	.056	.0514	.056	.0514	.0514	.0514	
20	.056	.0514	.056	.0514	.0514	.0514	.0543
21	.056	.0514	.056	.0514	.0514	.0514	.0549
22	.056	.0514	.056	.0514	.1715	.0514	.056
23	1.0155	.0514	.056	.0514	.0514	.0457	.056
24	.823	1.0202	.0514	.056	.0514	.0514	.0514
Max	1.7833	1.7814	1.8176	1.4632	1.7147	1.8896	1.6004
Min	.056	.0514	.0514	.0514	.0514	.0457	.0514
Avg	.7142	.6913	.6687	.6195	.7292	.8025	.7756

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274074 / 33/11 KV BEGAMPUR

Feeder No / Name : 204 / 11 KV BEGAMPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.3326	.3086	.3547	.2743	.3086	.2915
2	.2743	.3142	.3086	.3734	.2743	.3086	.3086
3	.2915	.3142	.2915	.3921	.3086	.3429	.3258
4	.4458	.462	.3944	.4668	.3429	.4115	.4115
5	.5144	.5729	.4973	.5601	.5144	.583	.4973
9	.3772	.5249	.3601	.463	.3772	.5304	.3944
10	.2915	.3429	.3601	.3429	.3944	.4382	.3944
11	.2743	.3429	.3429		.3944	.3582	.3429
12	.3086	.3429	.3429	.3086	.2572	.3224	.3772
13	.2743	.2743	.3086	.3086	.2743	.2865	.3429
14	.3086	.2743	.3086	.2743	.3086	.3366	.3086
15	.2743	.2915	.3086	.3086	.2743	.2686	.2743
16	.3086	.2743		.2743	.2572	.3045	.3086
17	.333	.3429	.3511	.2743	.3429	.3086	
18	.3641	.4973	.4334		.4458	.3429	.3155
19	.4298	.583	.5373	.5144	.4973	.4801	.4525
20	.5973	.5487	.5792	.583	.6516	.5487	.5068
21	.5487	.4801	.4525	.4458	.5144	.4801	.4525
22	.439	.3601	.4066	.3772	.4801	.4287	.4024
23	.3696	.3258	.3734	.2743	.3429	.3258	.3475
24	.2915	.3511	.3086	.3361	.2743	.3429	.3086
Max	.5973	.583	.5792	.583	.6516	.583	.5068
Min	.2743	.2743	.2915	.2743	.2572	.2686	.2743
Avg	.3615	.3882	.3787	.3807	.3715	.3837	.3682

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274074 / 33/11 KV BEGAMPUR

Feeder No / Name : 205 / 11KV YENKI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.061	.5792	.8907	.9602	.9755	.9145
2	.0686	.061	.5487	.8421	.9259	.9755	.8688
3			.503	.823	.9259	.884	.8688
4			.5335	.8535	.9945	.884	.884
5			.6097	.8535	1.0288	.9145	.884
6			.6706	.945	1.0631	1.0364	.9145
7			.8383	1.2967	1.1317	1.1888	.9145
8			.8688	1.2811	1.2003	1.2041	1.1431
9	1.2346	1.2186					
10	1.2498	1.2498					
11	1.2193	1.2651					
12	1.2346	1.2346					
13	1.1888	1.1888					
14	1.2193	1.0517					
15	1.1584	1.0364					
16	1.0364	1.0974					
17	.0309	.0514	.0305	.0686	.0457	.0514	
18	.0309	.0343	.0762	.0514	.0514	.0514	.0486
19	.0309	.0514	.061	.0514	.0686	.0686	.0486
20	.0772	.0686	.061	.0514	.0686	.0857	.0486
21	.0617	.0686	.061	.0514	.0686	.0857	.0486
22	.0617	.0686	.0457	.0514	.0514	.0514	.0486
23	.0469	.6401	.9393	1.0288	.9907	.9755	1.0212
24	.0514	.061	.6097	.9555	.9945	.9907	.9907
Max	1.2498	1.2651	.9393	1.2967	1.2003	1.2041	1.1431
Min	.0309	.0343	.0305	.0514	.0457	.0514	.0486
Avg	.5585	.5838	.4398	.6310	.6606	.6515	.6431

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274074 / 33/11 KV BEGAMPUR

Feeder No / Name : 206 / 11 KV KOTHALE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	1.1336	.0457	.0648	.0686		.1715
2	1.0059	1.004	.0514	.0648	.0686		.1372
3	1.0059	1.004					
4	1.0059	.9717					
5	1.0364	.9717					
6		1.166					
7	1.0364	1.1203		.0648			
8	1.2651	1.1012					
9			1.2651	1.3413	1.166	1.8861	1.5699
10				1.3717	.945	1.8785	1.4327
11			1.406	1.2193	.7621	1.8138	1.6766
12			1.3717	1.326	1.0364	1.7368	1.768
13			1.3032	1.1584	1.0669	1.7695	1.829
14			1.2003	1.0974	1.2193	1.7695	1.829
15			1.2003	1.1888	1.1431	1.7652	1.7985
16			1.2003	1.1888	1.1584	1.4419	1.7071
17	.0648	.0857		.0686		.1372	
18	.0648	.0857		.0857		.1372	.0937
19	.1296	.0686	.0648	.0857	.1372	.1715	.0937
20	.0972	.0686	.0648	.0857	.1715	.1886	.0937
21	.0972	.0686	.0972	.0686	.1715	.1715	.0972
22	.0972	.0686	.0972	.0686	.1715	.2058	.081
23	1.2308	.0514	.0972	.0686		.1829	.0972
24	1.1431	1.1822	.0514	.0648	.0686		.2058
Max	1.2651	1.1822	1.406	1.3717	1.2193	1.8861	1.829
Min	.0648	.0514	.0457	.0648	.0686	.1372	.081
Avg	.6918	.6345	.6344	.5622	.6236	1.0171	.8636

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274074 / 33/11 KV BEGAMPUR

Feeder No / Name : 401 / M/S JAKARAYA SUGAR LTD

Feeder KV- 33 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.2858
Max	.2858
Min	.2858
Avg	.2858

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274076 / 33/11 KV KAMTI

Feeder No / Name : 201 / 11 KV SHINGOLI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.3658	2.2862	2.21	2.2253	2.21	2.2558
2	.2439	.3658	2.2558	2.21	2.2862	2.21	2.2558
3			2.2558	2.4387	2.3777	2.2862	2.3167
4			2.3624	2.7664	2.3624	2.3624	2.3624
5			2.5149	2.5149	2.5911	2.3624	2.4387
6			2.652	2.652	2.6673	2.7892	2.5149
7			.4268	3.2769	2.7435	3.2312	3.0178
8			.4268	3.0483	2.7435	2.9721	3.094
9	2.8197	3.3573					
10	2.9721						
11	3.1245						
12	2.5453						
13	2.5911						
14	2.5301						
15	2.4691						
16	2.6063						
17	.3353	.4409	.2743			.3658	.3048
18	.3963		.381	.3353		.3048	.3963
19	.3963		.381	.381		.4268	.4268
20	.4268	.4748	.3963	.4268	.4268	.4268	.4572
21	.4268	.4748	.3963	.3963	.4268	.3963	.4268
22	.4268	.407	.381	.3963	.4268	.3658	.3963
23	.3658	2.5434	2.21	2.1338	2.21	2.21	2.1338
24	.3048	.3658	2.2862	2.21	2.1643	2.21	2.2558
Max	3.1245	3.3573	2.652	3.2769	2.7435	3.2312	3.094
Min	.2439	.3658	.2743	.3353	.4268	.3048	.3048
Avg	1.4031	.9773	1.3679	1.8264	1.9732	1.6956	1.6909

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274076 / 33/11 KV KAMTI

Feeder No / Name : 202 / 11 KV ICHAGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2498	.9145	.1067	.1067	.1219	.1219	.1067
2	1.2955	.9602	.1067	.1067	.1372	.1219	
3	1.3717	.9602	.1067				.1067
4	1.5242	1.0669					
5	1.6766	1.3717					
6	1.7375	1.8138					
7	2.271	2.21					
8	1.6766	1.7528					
9			1.4937	1.9052		1.6766	1.1888
10			1.9052	1.7528	1.7833	2.1033	1.6766
11			1.768	1.4327	1.6766	2.1338	1.5394
12			1.6766	1.4632	1.5546	1.5394	1.3717
13			1.5546	1.4937	1.2955	1.387	1.3717
14			1.4937	1.3108	1.3565	1.3108	1.2498
15			1.4632	1.3413	1.326	1.2803	1.0822
16		1.4937	1.4175	1.4327	1.448	1.4175	1.1431
17	.0914	.0914	.0762	.0914	.0914	.0914	.0762
18		.0914	.0914	.0914	.1067	.0914	.0914
19		.1067	.1067	.1067		.1067	.1067
20		.1372	.1067	.1372	.1219	.1372	.1219
21	.1524	.1372	.1219	.1372	.1372	.1219	.1372
22	.1067	.1067	.1219	.1219	.1372	.1067	.1219
23	.9145	.1067	.1067	.1067	.1219	.1067	.1067
24	.3048	.9145	.1067	.1067	.1067	.1219	.1067
Max	2.271	2.21	1.9052	1.9052	1.7833	2.1338	1.6766
Min	.0914	.0914	.0762	.0914	.0914	.0914	.0762
Avg	1.1056	.8374	.7332	.7358	.7202	.7765	.6503

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274076 / 33/11 KV KAMTI

Feeder No / Name : 203 / 11 KV WATWATE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.4572
Max	.4572
Min	.4572
Avg	.4572



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274076 / 33/11 KV KAMTI

Feeder No / Name : 204 / 11 KV WIRWADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.4572
Max	.4572
Min	.4572
Avg	.4572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274076 / 33/11 KV KAMTI

Feeder No / Name : 205 / 11 KV KAMATI BK. GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.5144	.4115	.381	.5426	.5087	.4115
2	.4954	.5144	.3658	.381	.5426	.5087	.4115
3	.5335	.5144	.3963	.381	.5426	.5765	.4115
4	.6097	.6668	.4268	.5335	.5765	.6443	.5144
5	.6478	.7621	.5182	.6097	.6952	.6783	.6001
6	.7621	.8764	.6097	.7011	.8139	.78	.6001
7	.6859	.8764	.6097	.6859	.763	.763	.4115
8	.6859	.6668	.5182	.6859	.6104	.6274	.5487
9	.5716	.5716	.4572	.6516	.5426	.5256	.4801
10	.5144		.3963	.5487	.4239	.4748	.4458
11	.4572		.442	.4287	.373	.4409	.4973
12	.381		.1524	.3429		.407	.3429
13	.4954		.3506	.4115	.4239	.373	.3601
14	.4191		.3353	.3772		.4239	.3429
15	.4572		.3658	.4115	.4239	.407	.3429
16	.4954	.5335	.3658	.4115	.407	.407	.3772
17	.5335	.6097	.3963	.4458	.5596	.4409	.4458
18	.6478	.7621	.4725	.463		.5087	.583
19	.7811	.8383	.6249	.4801	.6104	.6783	.6859
20	.9526	.8573	.6706	.7202	.7122	.7291	.6859
21	.8573	.7621	.6097	.6173	.6443	.6104	.583
22	.6668	.6478	.4725	.5487	.5765	.5087	.5144
23	.5144	.4763	.381	.4801	.5087	.4409	.4801
24	.4954	.5144	.3658	.381	.5087	.5087	.4115
Max	.9526	.8764	.6706	.7202	.8139	.78	.6859
Min	.381	.4763	.1524	.3429	.373	.373	.3429
Avg	.5898	.6647	.4465	.5033	.5620	.5405	.4787

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274076 / 33/11 KV KAMTI

Feeder No / Name : 206 / 11 KV HARALWADI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8099	1.7528	.2591	.2591	.2374	.2374	.2401
2	1.8099	1.7528	.2591	.2591	.2035	.2374	.2134
3	1.8671	1.848					
4	1.8671	1.848					
5	1.8671	1.8861					
6	1.8671	1.9052					
7	2.1719	1.9814					
8	2.1148	2.0386					
9			1.829	1.6766	1.8652	1.8991	1.4937
10			1.768	1.6004	1.8991	2.1704	1.6766
11			1.6309	1.5394	1.8313	2.2382	1.6156
12			1.5546	1.6004	1.7635	1.7635	1.4784
13			1.6004	1.6004	1.7465	1.6787	1.4632
14			1.5851	1.448	1.6617	1.6787	1.5432
15			1.5851	1.3717	1.6617	1.56	1.3413
16		1.9052	1.6004	1.3108	1.7126	.1865	1.3413
17	.3429	.2477	.1677	.1981	.1865	.1696	.1524
18	.3048	.3048	.1981	.2134	.2035	.2374	.1829
19	.362	.3239	.2286	.2439	.1696	.2713	.1981
20	.381	.3429	.2591	.3048	.2713	.2713	.2134
21	.381	.3429	.2591	.2743	.2713	.2374	.2286
22	.3239	.362	.2439	.2743	.2374	.2374	.2134
23	1.7528	.362	.2591	.2591	.2374	.2374	.2134
24	1.7909	1.7528	.2591	.2591	.2713	.2374	.2134
Max	2.1719	2.0386	1.829	1.6766	1.8991	2.2382	1.6766
Min	.3048	.2477	.1677	.1981	.1696	.1696	.1524
Avg	1.3134	1.2328	.8637	.8163	.9128	.8638	.7790

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274076 / 33/11 KV KAMTI

Feeder No / Name : 207 / 11 KV DADPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2096	1.2193	1.1584	1.2548	1.2548	1.0669
2	.2286	.1905	1.2193	1.2742	1.2717	1.2548	1.0669
3			1.2498	1.2955	1.3565	1.2887	1.0669
4			1.3413	1.3717	1.3565	1.2887	1.1431
5			1.5242	1.448	1.4413	1.3565	1.2803
6			1.7071	1.6766	1.5939	1.6956	1.387
7			2.0729	1.9509	1.95	2.0348	1.6004
8			2.1338	1.8595	1.8652	1.933	1.8595
9	2.0576	2.2862					
10	2.2862						
11	2.3243						
12	2.0005						
13	1.8671						
14	1.7909						
15	1.6385						
16	1.6004						
17	.2286	.1905	.0914			.2035	.0762
18	.3239	.2286	.1524	.1372	.2035	.2204	.1219
19	.2858	.3048	.2134	.1524	.2374	.2204	.1524
20		.3048	.2286	.2134	.2204	.2374	.1677
21		.3048	.2134	.1981	.2204	.2204	.1677
22	.2096	.2667	.1981	.1829	.2204	.2204	.1829
23	.2096	1.5242	1.1584	1.0974	1.2209	1.1361	.1981
24	.2286	.2096	1.2193	1.1584	1.2209	1.2548	1.0669
Max	2.3243	2.2862	2.1338	1.9509	1.95	2.0348	1.8595
Min	.2096	.1905	.0914	.1372	.2035	.2035	.0762
Avg	1.0943	.5473	.9964	1.0116	1.0423	.9888	.7878

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274077 / 33/11 KV LAMBOTI

Feeder No / Name : 201 / 11 KV LAMBOTI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	04-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			2.1994	
16			2.0805	2.4139
24	.3658	.5335		
Max	.3658	.5335	2.1994	2.4139
Min	.3658	.5335	2.0805	2.4139
Avg	.3658	.5335	2.1400	2.4139

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274077 / 33/11 KV LAMBOTI

Feeder No / Name : 202 / 11 KV SHIRAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.3048
Max	.3048
Min	.3048
Avg	.3048

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274077 / 33/11 KV LAMBOTI

Feeder No / Name : 203 / 11 KV SAWALESHWAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	04-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		1.9357	2.0953	
16			.5647	.4801
24	.2286	1.0802		
Max	.2286	1.9357	2.0953	.4801
Min	.2286	1.0802	.5647	.4801
Avg	.2286	1.5080	1.33	.4801

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274077 / 33/11 KV LAMBOTI

Feeder No / Name : 205 / 11 KV ARJUNSOND FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.1829
Max	.1829
Min	.1829
Avg	.1829



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274077 / 33/11 KV LAMBOTI

Feeder No / Name : 206 / 11 KV PANCHRATNA

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	.3048
Max	.3048
Min	.3048
Avg	.3048

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274077 / 33/11 KV LAMBOTI

Feeder No / Name : 207 / 11KV TOLL PLAZA

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	04-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.0173	.0163	
16			.0208	.0173
24	.3429	.0457		
Max	.3429	.0457	.0208	.0173
Min	.3429	.0173	.0163	.0173
Avg	.3429	.0315	.0186	.0173

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274077 / 33/11 KV LAMBOTI

Feeder No / Name : 401 / UPSA SINCHAN SHIRAPUR

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	.1543
Max	.1543
Min	.1543
Avg	.1543

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274078 / 33/11 KV MOHOL

Feeder No / Name : 201 / 11 KV ANAGAR.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.9145
Max	.9145
Min	.9145
Avg	.9145

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274078 / 33/11 KV MOHOL

Feeder No / Name : 202 / 11 KV NARKHED

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.1524
Max	.1524
Min	.1524
Avg	.1524

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274078 / 33/11 KV MOHOL

Feeder No / Name : 203 / 11 KV WADWAL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.1524
Max	.1524
Min	.1524
Avg	.1524

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274078 / 33/11 KV MOHOL

Feeder No / Name : 204 / 11 KV D.BABHULGAON  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274078 / 33/11 KV MOHOL

Feeder No / Name : 205 / 11 KV MOHOL

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.8097
Max	.8097
Min	.8097
Avg	.8097



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274080 / 33/11 KV PAPRI

Feeder No / Name : 201 / 11 KV PAPRI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.3048
Max	.3048
Min	.3048
Avg	.3048

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274080 / 33/11 KV PAPRI

Feeder No / Name : 202 / 11 KV ASHTI LAKE AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.3048
Max	.3048
Min	.3048
Avg	.3048

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274080 / 33/11 KV PAPRI

Feeder No / Name : 203 / 11 KV KHANDALI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.2286
Max	.2286
Min	.2286
Avg	.2286

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274080 / 33/11 KV PAPRI

Feeder No / Name : 204 / 11 KV TALE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.2286
Max	.2286
Min	.2286
Avg	.2286

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274080 / 33/11 KV PAPRI

Feeder No / Name : 205 / 11 KV PAPRI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.2286
Max	.2286
Min	.2286
Avg	.2286

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274080 / 33/11 KV PAPRI

Feeder No / Name : 206 / 11 KV DINAKAR KACHARE

Feeder KV- 11 / OUTGOING

PURELY LIS FEEDERS

DATE	01-AUG-17
HR	Load (MW)
24	.0857
Max	.0857
Min	.0857
Avg	.0857

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274080 / 33/11 KV PAPRI

Feeder No / Name : 207 / 11 KV YEWATI NALA  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.3048
Max	.3048
Min	.3048
Avg	.3048

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274080 / 33/11 KV PAPRI

Feeder No / Name : 209 / 11 KV DONGARE

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-AUG-17
HR	Load (MW)
24	.0486
Max	.0486
Min	.0486
Avg	.0486



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274080 / 33/11 KV PAPRI

Feeder No / Name : 210 / 11 KV HARITKRANTI

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	.0686
Max	.0686
Min	.0686
Avg	.0686

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274081 / 33/11 KV PENUR

Feeder No / Name : 201 / 11 KV KONHARI PAPRI  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	2.2291	2.572	2.1091	2.572	2.2291	2.572
2	.5144	2.2291	2.572	2.0919	2.572	2.2291	2.572
3		2.2291	2.572	2.1434	2.572	2.2291	3.4294
4		2.2291	2.572	2.2291	2.572	2.2291	3.4294
5		2.2291	2.572	2.2634	2.572	2.2291	3.4294
6		2.2291	3.4294	2.3148	2.572	2.2291	3.4294
7		2.2291	3.4294	2.3663		2.2291	3.4294
8		2.2291	3.4294	2.3834		2.2291	3.4294
9	2.4006						
10	2.7435						
12	2.572						
13	2.572						
14	2.0576						
15	2.0576						
16	2.0576						
17	2.0576	3.4294	2.4006	2.2862	2.2291	2.572	2.4006
18	2.0576	3.4294	2.4006	2.2862	2.2291	2.572	2.3663
19	2.0576	3.4294	2.3834	2.572	2.2291	2.572	2.572
20	2.0576	3.4294	2.3663	2.572	2.2291	2.572	2.5377
21	2.0576	3.4294	2.3148	2.572	2.2291	2.572	2.4691
22	2.0576	3.4294	2.332	2.572	2.2291	2.572	2.5034
23	2.2291	3.4294	2.2977	2.572	2.2291	2.572	2.5206
24	.3658	2.0576	2.572	2.0919	2.572	2.2291	2.572
Max	2.7435	3.4294	3.4294	2.572	2.572	2.572	3.4294
Min	.3658	2.0576	2.2977	2.0919	2.2291	2.2291	2.3663
Avg	1.9077	2.7435	2.6385	2.3391	2.4006	2.3791	2.8539

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274081 / 33/11 KV PENUR

Feeder No / Name : 202 / 11 KV PATKUL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8292	.5144	.5144	.5144	.5144	.5144	.5144
2	2.7435	.5144	.5144	.5144	.5144	.5144	.5144
3	2.915						
4	2.915						
5	3.0864						
6	3.0864						
7	3.3779						
8	3.6008						
9		3.0864	3.2579	2.8635	3.2579	3.2579	2.8292
10		3.2579	2.915	3.3779	3.4294	3.4294	3.0864
11		3.2579	3.0007		3.4294	1.7147	3.0521
12		3.2579	3.0864		3.6008	2.4006	3.0693
13		3.2579	3.0864	3.0483	3.4294	2.7435	3.2579
14		3.2579	3.3093	3.4294	3.6008		3.4122
15			3.4122	2.8959	3.2579	3.4294	3.3951
16			3.2922	3.2579	3.0864	3.4294	3.6008
17	.5144	.5144	.5144	.4572	.5144	.5144	.5144
18	.5144		.5144	.4572	.5144	.5144	.5144
19	.5144	.5144	.5144	.5144	.5144	.5144	.5144
20	.5144	.5144	.5144	.5144	.5144	.5144	.5144
21	.5144	.5144	.5144	.5144	.5144	.5144	.5144
22	.5144	.5144	.5144	.5144	.5144	.5144	.5144
23	.5144	.5144	.5144	.5144	.5144	.5144	.5144
24	.2286	.5144	.5144	.5144	.5144	.5144	.5144
Max	3.6008	3.2579	3.4122	3.4294	3.6008	3.4294	3.6008
Min	.2286	.5144	.5144	.4572	.5144	.5144	.5144
Avg	1.7740	1.6004	1.6947	1.4939	1.7909	1.5029	1.7137

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274081 / 33/11 KV PENUR

Feeder No / Name : 203 / 11 KV PENUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0007	.5144	.5144	.5144	.5144	.5144	.5144
2	3.2579	.5144	.5144	.5144	.5144	.5144	.5144
3	3.3436						
4	3.1722						
5	3.3779						
6	3.6008						
7	3.6008						
9		3.2579	3.4294	3.2065	3.4294	1.0288	3.7723
10		3.4294	3.2065	3.2579	3.6008	3.7723	3.6008
11		3.6008	3.3951		3.9438	3.7723	3.7209
12		3.2579	3.3951		3.9438	3.6008	3.6694
13		3.4294	3.5665	3.2007	3.9438	3.6008	3.6008
14		3.4294	3.6008	3.2007	3.7723		3.7551
15			3.5837	3.3532		3.9438	3.738
16			3.6008	3.7723	3.2579	3.9438	3.8066
17	.5144	.5144	.5144	.4572	.5144	.5144	.5144
18	.5144	.5144	.5144	.4572		.5144	.5144
19	.5144	.5144	.5144	.4572	.5144	.5144	.5144
20	.5144	.5144	.5144	.5144	.5144	.5144	.5144
21	.5144	.5144	.5144	.5144	.5144	.5144	.5144
22	.5144	.5144	.5144	.5144	.5144	.5144	.5144
23	.5144	.5144	.5144	.5144	.5144	.5144	.5144
24	.442	.5144	.5144	.5144	.5144		.5144
Max	3.6008	3.6008	3.6008	3.7723	3.9438	3.9438	3.8066
Min	.442	.5144	.5144	.4572	.5144	.5144	.5144
Avg	1.8264	1.5968	1.8290	1.5602	1.9076	1.7683	1.9338

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274081 / 33/11 KV PENUR

Feeder No / Name : 205 / 11 KV YEWATI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	3.2579	3.4294	2.692	3.4294	3.2579	3.4294
2	.5144	3.2579	3.4294	2.8292	3.4294	3.2579	3.4294
3		3.2579	2.572	2.7092	3.4294	3.2579	3.4294
4		3.2579	2.572	2.8121	3.4294	3.2579	3.4294
5		3.2579	3.4294	2.915	3.4294	3.2579	3.4294
6		3.2579	3.4294	2.8807	3.4294	3.2579	3.4294
7		3.2579	3.4294	2.9492	3.4294	3.2579	3.4294
8		3.2579	3.4294	2.9835	3.4294	3.2579	3.4294
9	2.7435						
10	2.7435						
12	3.4294						
13	3.4294						
14	3.2579						
15	3.2579						
16	3.2579						
17	.5144	.5144	.5144	.4572	.5144	.5144	.5144
18	3.2579	.5144	.5144	.5144	.5144	.5144	.5144
19	.5144	.5144	.5144	.5144	.5144	.5144	.5144
20	.5144	.5144	.5144	.5144	.5144	.5144	.5144
21	.5144	.5144	.5144	.5144	.5144	.5144	.5144
22	.5144	.5144	.5144	.5144	.5144	.5144	.5144
23	3.2579	3.4294	2.6235	3.4294	3.2579	3.4294	2.7435
24	.442	3.2579	3.4294	2.8292	3.4294	3.2579	3.4294
Max	3.4294	3.4294	3.4294	3.4294	3.4294	3.4294	3.4294
Min	.442	.5144	.5144	.4572	.5144	.5144	.5144
Avg	1.9222	2.2398	2.1787	2.0037	2.3256	2.2398	2.2934

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274081 / 33/11 KV PENUR

Feeder No / Name : 206 / 11 KV PENUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6859	.6859	.6859	.6859	.6859	.6859
2	.6859	.6859	.6859	.6859	.6859	.6859	.6859
3	.6859	.6859	.6859	.6859	.6859	.6859	.6859
4	.6859	.6859	.6859	.6859	.6859	.6859	.6859
5	.6859	.6859	.6859	.6859	.6859	.6859	.6859
6	.6859	.6859	.6859	.6859	.6859	.6859	.6859
10	.6859	.6859	.6859	.6859	.6859	.6859	.6859
11		.6859	.6859		.6859	.6859	.6859
12	.6859	.6859	.6859		.6859	.6859	.6859
13	.6859	.6859	.6859	.6097	.6859	.6859	.6859
14	.6859	.6859	.6859	.6097	.6859		.6859
15	.6859		.6859	.6859	.6859	.6859	.6859
17						.6859	
18						.6859	
19	.6859	.6859	.6859	.6859	.6859	.6859	.6859
20	.6859	.6859	.6859	.6859	.6859	.6859	.6859
21	.6859	.6859	.6859	.6859	.6859	.6859	.6859
22	.6859	.6859	.6859	.6859	.6859	.6859	.6859
23	.6859	.6859	.6859	.6859	.6859	.6859	.6859
24	.442	.6859	.6859	.6859	.6859	.6859	.6859
Max	.6859	.6859	.6859	.6859	.6859	.6859	.6859
Min	.442	.6859	.6859	.6097	.6859	.6859	.6859
Avg	.6716	.6859	.6859	.6764	.6859	.6859	.6859

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274082 / 33/11 KV SHETPHAL

Feeder No / Name : 201 / 11 KV ASHTI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.1715	.2058	.2058
2		.1715	.1715	.2058	.2058
3		.1715	.1715	.2058	.2572
4		.2229	.1715	.2229	.2058
5		.2572	.1715	.2572	.2401
16		3.2769	2.9264	2.9721	3.2769
17		3.2312	2.7892	3.2007	3.597
18		3.0788	2.774	3.0026	3.2617
19		2.7435	2.7892		3.2922
20		2.6673	2.7435		2.6673
21		2.3624	2.4996		2.713
22		2.332	2.4387		2.713
23			2.2862		2.713
24	.4572	.1715	.1715	.2058	.2058
Max	.4572	3.2769	2.9264	3.2007	3.597
Min	.4572	.1715	.1715	.2058	.2058
Avg	.4572	1.6045	1.5911	1.1643	1.8253

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274082 / 33/11 KV SHETPHAL

Feeder No / Name : 202 / 11 KV SHETFAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2498	.1715	.1715	.1715
2		1.2498	.1715	.1715	.1715
3		1.2498	.1715		.1715
4		1.6004	.1715		.1715
5		1.829	.1715		.1715
6		2.6673			
7		2.7435			
8		2.8959			
9			2.4387		2.1338
10			3.0483		
11			3.0483		2.7435
12			2.9721		2.1338
13			2.7435		1.829
14			3.0483		2.21
15			2.8959		2.2862
16			3.0483		2.4387
19		.1715	.1715		.1715
20		.1715	.1715		.1715
21		.1715	.1715		.1715
22		.1715	.1715		.1715
23			.1715		.1715
24	.4572	1.2193	.1715	.1715	.1715
Max	.4572	2.8959	3.0483	.1715	2.7435
Min	.4572	.1715	.1715	.1715	.1715
Avg	.4572	1.3378	1.3226	.1715	.9812



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274082 / 33/11 KV SHETPHAL

Feeder No / Name : 204 / 11 KV BAIRAGWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3717	1.3717	1.2193	1.5699
2		1.3717	1.3717	1.2193	1.6004
3		1.5242	1.3717	1.2193	1.6004
4		1.6461	1.8861	1.3717	1.6004
5		1.7833	1.6766	1.5242	1.7223
6		2.21	1.9814	1.829	2.0881
7		2.5301	2.0576	2.1338	2.2558
8		2.3015	1.9357	2.1338	2.332
9		2.4387	2.2862	2.1033	1.7528
10		2.3472	2.5149	1.5242	2.3777
11		2.1338	2.4996	1.9814	2.0729
12		2.21	2.2405	2.1338	
13		2.2405	2.21	2.2253	2.3167
14			2.1338	2.2862	2.2253
15		2.1948	2.0729	2.1338	2.2405
19		.4801	.4115		
20		.6001	.5658		.463
21		.5316	.4973		.4287
22		.463	.4801		.4287
23			.4458		.3944
24	.3201	1.6156	1.5432	1.2193	1.6766
Max	.3201	2.5301	2.5149	2.2862	2.3777
Min	.3201	.463	.4115	1.2193	.3944
Avg	.3201	1.6839	1.5978	1.7661	1.6393

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274082 / 33/11 KV SHETPHAL

Feeder No / Name : 205 / 11 KV SHETFAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.3429	.3429
2		.3429	.3429
3		.3429	.3429
4		.3772	.4287
5		.5144	.4801
12		.3429	.3429
13		.3429	.2915
14		.3429	.2915
15		.3086	.2572
16		.3086	.2572
17		.3429	.3258
19		.4458	.4287
20		.5316	.5144
21		.4287	.5144
22		.381	.4287
23			.3429
24	.3353	.3086	.3429
Max	.3353	.5316	.5144
Min	.3353	.3086	.2572
Avg	.3353	.3753	.3692

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274082 / 33/11 KV SHETPHAL

Feeder No / Name : 209 / 11 KV TELANGWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2041	.1372	.1372
2		1.3717	.1372	.1372
3		1.3717	.1372	.1372
4		1.3717	.1372	.1715
5		1.6004	.1886	.1886
6		2.2862		
7		2.4387		
8		2.0881		
9			1.7528	1.286
10			2.3777	2.2862
11			2.2862	2.1643
12			2.1338	2.0576
13			1.9814	
14			1.9966	
15			1.5242	1.7985
16			1.7528	1.9204
19		.1886	.1886	.2229
20		.1886	.2229	.2401
21		.1372	.2229	.2401
22		.1372	.2229	.1886
23			.1715	.2229
24	.3048	1.0364	.1372	.1372
Max	.3048	2.4387	2.3777	2.2862
Min	.3048	.1372	.1372	.1372
Avg	.3048	1.1862	.9320	.7963

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274084 / 33/11 KV NARKHED

Feeder No / Name : 201 / 11 KV DIKSAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.8478	.7392	.9945	.6706
2			1.0174	.8402	.9945	.6706
3			1.3565	1.086	1.326	1.0059
4			1.3413	1.1765	1.326	1.3565
5			1.6766	1.5061	1.4918	1.7147
6			1.8442	1.949	2.1548	2.6006
7			2.1548	2.1719	2.4863	2.774
8			1.8233	2.5606	2.3205	2.8607
9		1.2955				
10		1.5242				
11		1.829				
12		1.829				
15			.2543	.1867		.3315
16			.2543	.4239		.4191
17		.1524	.3391	.5087		.503
18		.2572	.4239	.6335		.6706
19			.9326			.8383
20			.8478	.6401		.9221
21			.8478			.8383
22		.7716	.5935	.4525		.6706
23		.9431	1.0059	.8402		.8383
24	.3391	.6001	.8478	.7468	.9116	.6706
Max	.3391	1.829	2.1548	2.5606	2.4863	2.8607
Min	.3391	.1524	.2543	.1867	.9116	.3315
Avg	.3391	1.0225	1.0227	1.0289	1.5562	1.1309

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274084 / 33/11 KV NARKHED

Feeder No / Name : 202 / 11 KV NARKHED

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.3048
Max	.3048
Min	.3048
Avg	.3048

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274084 / 33/11 KV NARKHED

Feeder No / Name : 203 / 11 KV EKURKE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.3048
Max	.3048
Min	.3048
Avg	.3048

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274084 / 33/11 KV NARKHED

Feeder No / Name : 204 / 11 KV WALUJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	05-AUG-17	06-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.1869	.763	1.326
2		.1524	1.1736	.8192	1.326
3			1.1869	1.0774	1.6575
4			1.3413	1.1869	1.6575
5			1.3413	1.3565	1.8233
6			1.6766	2.0538	2.4863
7			2.0119	1.829	2.8178
8			2.0119	2.6139	3.0664
11		2.2291			
12		2.572			
15			.1696	.2286	
16			.1696	.181	
17		.2572	.3052	.2543	
18		.3429	.1696	.2715	
19			.1696		
20		.4287	.3391	.362	
21			.2543	.4525	
22			.2543	.3734	
23		1.286		.9335	
24	.3391	.1524	1.2717	.7468	.9945
Max	.3391	2.572	2.0119	2.6139	3.0664
Min	.3391	.1524	.1696	.181	.9945
Avg	.3391	.9276	.8843	.9120	1.9061

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274084 / 33/11 KV NARKHED

Feeder No / Name : 205 / 11 KV BHOPALE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	05-AUG-17	06-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9945	1.2003	.2543	.3658	.2486
2	.9945	1.3717	.2543	.3696	.2486
3	1.1603				
4	1.1603				
5	1.326	1.3717			
6	1.4918	1.8004			
7	1.989	2.2291			
8	2.1548	1.8861			
9			2.0119	2.1262	2.4863
10			2.4863	2.5339	2.8178
11			2.1548	2.5434	
12			2.0957	2.4291	
13			2.1795	2.4863	
14			2.0719	2.4577	
15			2.0119	2.5911	
16			1.8442		
17		.1715	.1696		
18		.2572	.3052	.2801	
19			.3391		
20		.3429	.4748	.4334	
21			.4748	.4572	
22			.2543	.3582	
23		.2572	.1696	.3582	
24	.3658	1.286	.2543	.362	.2486
Max	2.1548	2.2291	2.4863	2.5911	2.8178
Min	.3658	.1715	.1696	.2801	.2486
Avg	1.293	1.1067	1.1004	1.3435	1.2100



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274084 / 33/11 KV NARKHED

Feeder No / Name : 206 / 11 KV HINGANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	05-AUG-17	06-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9145	.2543	.3048	.2486
2		.8383	.2543	.3696	.2486
3		.8383			
4		.9145			
5		.9907			
6		1.1431			
7		1.4575			
8		1.0669			
9			1.3413	2.0538	2.4863
10			1.5089	2.5206	2.7349
11			1.4251	2.3482	
12			1.5089	2.7435	
13			1.4089	2.6139	
14			1.326	2.8006	
15			1.3413	2.3739	
16			1.2574	2.8006	
17		.1524	.1696	.1867	
18		.2572	.1696	.2801	
19			.3391		
20			.2543	.362	
21		.2572	.2543	.5373	
22			.1696	.2629	
23		.2572	.1696	.3277	
24	.1524	1.0669	.2543	.3582	.2486
Max	.1524	1.4575	1.5089	2.8006	2.7349
Min	.1524	.1524	.1696	.1867	.2486
Avg	.1524	.7811	.7448	1.3673	1.1934

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274112 / 33/11 KV KURUL

Feeder No / Name : 201 / 11 KV OLD KURUL AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.442
Max	.442
Min	.442
Avg	.442

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274112 / 33/11 KV KURUL

Feeder No / Name : 202 / 11 KV KATEWADI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.6097
Max	.6097
Min	.6097
Avg	.6097

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274112 / 33/11 KV KURUL

Feeder No / Name : 203 / 11 KV ANKOLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1619		1.2955	2.2138	1.6004	2.2653	2.2405
2	.1619	1.406		2.2672	1.9204	2.1872	2.4006
3			1.4575	2.1033	1.9204		2.4326
4			1.3717	2.1338	1.7604		2.4006
5		1.4842	1.6194	2.2184	1.6804	2.1872	2.2405
6			1.9433	2.6558	2.2405	2.4215	2.8464
7		2.1872	2.4291	2.6871	2.5606	2.6558	2.9607
8		2.3434	2.5101		2.6406	2.4996	2.8807
11	1.829						
13	1.6766						
15		.1715	.1718	.1875	.945	.2401	
16	1.829	.1943	.1898	.2286		.2401	
17			.2343	.2343		.096	
18		.2753	.3125	.25	.216	.3521	
19	.2134	.2915	.2688	.2267	.2778	.3521	
20		.2915	.2656	.2214		.3201	
21		.2743	.2343	.2286		.3041	
22		.2743				.2881	
23		1.1336	1.9134	.2187	2.3148	2.0805	
24	.1619	1.5623	1.1336	2.0576	.2241	2.4996	2.1348
Max	1.829	2.3434	2.5101	2.6871	2.6406	2.6558	2.9607
Min	.1619	.1715	.1718	.1875	.216	.096	2.1348
Avg	.8620	.9146	1.0844	1.2583	1.5616	1.3118	2.5042

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274112 / 33/11 KV KURUL

Feeder No / Name : 204 / 11 KV KURUL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353		.3725	.3841	.4161	.3801	.4161
2	.3429	.4435	.3563	.4161	.4001	.4024	
3	.381		.3887	.4161	.3521		.3521
4	.4858		.4049	.4161	.4801		.5281
5	.5668	.6283	.5182	.4481	.5121	.5914	.5601
10		.3239					
11	.5258	.4748	.3841	.4161		.4481	
12			.4374	.4321	.583	.4641	
13			.4531	.4641		.4641	
14		.3725	.4843	.4641		.3201	
15		.4115	.3479	.4801	.4801	.4321	
16	.3601	.4287	.4428	.5281		.4481	
17			.4531	.5601		.4801	
18		.6001	.506	.5601	.5487	.4961	
19	.5487	.6344	.4999	.5441	.6661	.5121	
20		.6344	.5468	.5121		.5121	
21		.6516		.4961		.4961	
22			.5468	.4961		.5121	
23		.5144	.4999	.4641	.4207	.4801	
24	.2286	.4163		.3201	.4481	.4477	.4481
Max	.5668	.6516	.5468	.5601	.6661	.5914	.5601
Min	.2286	.3239	.3479	.3201	.3521	.3201	.3521
Avg	.4194	.5026	.4496	.4641	.4825	.4639	.4609

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274112 / 33/11 KV KURUL

Feeder No / Name : 205 / 11 KV NEW KURUL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478			.08	.128	.1219	.128
2	.6478	.1372		.08	.128	.1219	.128
3	.7287						
4	.7287						.128
5	.8097						.128
6	1.0526						
7	1.2193						
8	1.2193						
9		1.1431	1.7814	.8002	1.0883	1.0669	.9922
10		1.3765		.8002		1.1523	1.0883
11		1.3765	1.406	.8002		1.0402	
12		1.1336	1.0623	.8002	.9907	.9922	
13		1.1336	1.078	.9602		.9602	
14		.9145	.9686	.8322		.9602	
15		.9717	.8749	.8002	.945	.9602	
16	.0914	.9717	.8642	.8002	.945	.8802	
17			.1898	.128		.128	
18		.1619	.1898	.128	.1524	.128	
19	.1829	.1943	.1562	.128	.1829	.16	
20		.1943	.1562	.16		.16	
21		.1943	.16	.16		.144	
22		.1943	.1524	.16		.128	
23		.1619	.1543	.128	.1067	.128	
24	.6478	.1372	.1619	.0781	.128	.1219	.128
Max	1.2193	1.3765	1.7814	.9602	1.0883	1.1523	1.0883
Min	.0914	.1372	.1524	.0781	.1067	.1219	.128
Avg	.7251	.6498	.6237	.4347	.4795	.5197	.3886

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274112 / 33/11 KV KURUL

Feeder No / Name : 206 / 11 KV SHEJBABHULGAON  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915		1.9433	2.3205	2.3205	2.2577	2.8006
2	.3052	1.6556	2.1052	2.3205		2.1824	2.7206
3			2.1052	2.4006	2.2405		2.6726
4			2.1052	2.4966	2.4006		2.7206
5		1.8061	2.1862	2.5606	2.8807	2.3329	2.7526
6			2.3482	2.5606	3.1207	2.5587	3.1207
7		2.7092	2.5911	3.2007	3.2648	2.2577	3.2808
8		2.6339	3.2388	3.0887	2.8807	3.236	3.2808
11	2.5911						
13	2.4387						
15		.2401	.3637	.2401		.2401	
16	2.2577	.3086	.3125	.2881		.3841	
17			.4687	.2881			
18		.4115	.4999	.2881	.301	.4321	
19	.3048	.4049	.5668	.3201	.3311	.4321	
20		.4049	.5468	.3841		.4161	
21		.4049	.6249	.4001		.4001	
22		.4049	.5535	.4481		.4001	
23		1.9433	2.2929	1.9204	2.2577	2.7206	
24	.2915	2.1072	1.9433	2.2565	2.3365	2.4834	2.8807
Max	2.5911	2.7092	3.2388	3.2007	3.2648	3.236	3.2808
Min	.2915	.2401	.3125	.2401	.301	.2401	2.6726
Avg	1.2115	1.1873	1.4887	1.5435	2.2123	1.5156	2.9144

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274112 / 33/11 KV KURUL

Feeder No / Name : 207 / 11 KV S.WARWADE AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1862		.2429	.2881	.2561	.1852	.2241
2	2.1862	.2932	.2267	.2561	.2241	.1852	.2241
3	2.1338			.2561			
4	2.1338						
5	2.4291						
6	2.9959						
7	3.1245						
8	2.672						
9		2.5911	2.5101		2.6406	2.4691	2.5926
10		2.915	2.4006	2.7206		2.4806	2.8006
11		2.915	2.4806	2.7206		2.4006	
12		3.1722	2.4806	2.8006	2.4691	2.5606	
13			2.6406	2.8006		2.7366	
14		2.834	2.2085	2.7686		2.7206	
15		2.834	1.8884	2.7526	2.4387	2.5606	
16		2.5149	2.5766	2.8006		2.4806	
17			.3041	.2401		.2401	
18		.3086	.3041	.2881	.2469	.2881	
19	.2778	.3429	.3041	.3201	.2469	.2881	
20		.3239	.3041	.3201		.2881	
21		.3239	.3041	.3041		.2881	
22		.3429		.3201		.2561	
23		.2591	.2187	.3201	.216	.2401	
24	.4572	.2932	.2429	.2561	.2881	.2006	.2372
Max	3.1245	3.1722	2.6406	2.8006	2.6406	2.7366	2.8006
Min	.2778	.2591	.2187	.2401	.216	.1852	.2241
Avg	2.0597	1.4843	1.2728	1.2519	1.0029	1.2705	1.2157



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274126 / 33/11 KV CHANDRAMOULI

Feeder No / Name : 201 / 11 KV CHANDRAMOULI ESTATE SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	05-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401		.4239	.6554	.6478
2	.6478		.4748		.5735
3	.5735	.3277	.4973		.5735
4	.4915		.503		.4049
5	.5243		.4641		.4144
6	.5243		.4973		.4096
7	.5735		.4973	.4915	.4858
8	.583	.1638	.4191	.4096	.4915
9	.6554	.1638	.3315	.5801	
10	.7287	.2543	.7545	.663	
11		.2515		.9189	
12				.9015	.8192
13				.8478	
14				.5868	
15				.7459	.7373
16				.7545	
17				.7545	
18		.3391		.7459	
19		.3772		.7042	.6554
20		.3814		.6962	
21		.3772		.6706	
22		.4287		.7042	
23		.3467		.7042	
24	.6554	.5735	.3353	.8097	.7373
Max	.7287	.5735	.7545	.9189	.8192
Min	.4915	.1638	.3315	.4096	.4049
Avg	.5998	.3321	.4726	.7023	.5792

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274126 / 33/11 KV CHANDRAMOULI

Feeder No / Name : 202 / 11 KV GOTEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	05-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8322		.1457	.1638	.1457
2	.8802		.1457	.1802	.128
3	1.0883	1.4582			
4	1.0911				
5	1.3125				
6	1.3904				
7	1.5844	1.6385			
8	1.5364	1.7204			
9			1.5844	1.587	1.4255
10				1.6644	
11				1.6129	
12				1.6129	1.6221
13				1.6004	
14				1.3603	
15				1.4575	.1311
16				1.3923	
17				.1457	
18		.2105		.1781	.1475
19		.2429		.2401	
20		.192		.1966	
21		.1943		.1802	
22		.1781		.1638	
23		.1781		.1638	
24	.7968	1.2651	.1619	.1966	.144
Max	1.5844	1.7204	1.5844	1.6644	1.6221
Min	.7968	.1781	.1457	.1457	.128
Avg	1.1680	.7278	.5094	.7831	.5348

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274126 / 33/11 KV CHANDRAMOULI

Feeder No / Name : 203 / 11 KV WADWAL GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	05-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3932		.4908		.3605
2	.3768		.4557		.3441
3	.5571	.3441	.4508		.3978
4	.5761		.4908		.4424
5	.6062		.5731		.5138
6	.6554	.5079	.6379	.5243	.5735
7	.6299	.5079	.724	.5243	.6062
8	.4424		.7133	.5243	.4915
9	.3932	.426	.6584	.4607	
10	.3605	.3721		.4607	
11		.4207		.4607	
12				.4908	.426
13				.4908	
14				.4207	
15				.4961	.426
16				.4961	
17				.591	
18		.6878		.695	
19		.7947		.7392	.426
20		.7602		.695	
21		.6447		.567	
22		.567		.5258	
23		.5258		.4908	
24	.3978	.421	.4908	.3605	.3812
Max	.6554	.7947	.724	.7392	.6062
Min	.3605	.3441	.4508	.3605	.3441
Avg	.4899	.5369	.5686	.5270	.4491

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274126 / 33/11 KV CHANDRAMOULI

Feeder No / Name : 204 / 11 KV VARDHMAN EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS  
FEEDER Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	05-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0509		.0572		.0509
2	.0509		.0572		.0503
3	.0503	.0572	.0572		.0503
4	.0503		.0572		.0503
5	.0503		.0572		.0503
6	.0497	.0572	.0572	.0572	.0509
7	.0503	.0572	.0572	.0572	.0503
8	.0497		.0572	.0572	.0509
9	.0503	.0572	.0572	.0572	
10	.0497	.0572		.0572	
11		.0572		.0572	
12				.0572	.0057
13				.0572	
14				.0572	
15				.0572	
16				.0572	.0057
17				.0572	
18		.0572		.0572	
19		.0572		.0572	.0057
20		.0572		.0572	
21		.0572		.0572	
22		.0572		.0572	
23		.0572		.0572	.0057
24	.0503	.0572	.0572	.0572	.0509
Max	.0509	.0572	.0572	.0572	.0509
Min	.0497	.0572	.0572	.0572	.0057
Avg	.0502	.0572	.0572	.0572	.0368

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274128 / 33/11 KV BITALE

Feeder No / Name : 201 / 11 KV BITALE BHAGIRATH

Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-AUG-17	02-AUG-17
HR	Load (MW)	Load (MW)
1	.2587	.1886
2		.1886
3	.3658	.2587
4	.4656	
5	.4656	.4024
6	.4298	
7	.4024	
8	.3696	
9	.3326	
10	.3696	
11	.4066	
12	.3584	
13	.2641	
14	.2402	
15	.2402	
16	.2263	
17	.2587	
18	.3045	
19	.3475	
20	.4435	
21	.4251	
22	.3041	.3511
23	.2641	.2587
24	.7621	.2075
Max	.7621	.4024
Min	.2263	.1886
Avg	.3611	.2651

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274128 / 33/11 KV BITALE

Feeder No / Name : 202 / 11 KV CHIKHALI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.4572
Max	.4572
Min	.4572
Avg	.4572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274128 / 33/11 KV BITALE

Feeder No / Name : 203 / 11 KV BITALE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
24	.2286
Max	.2286
Min	.2286
Avg	.2286

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274128 / 33/11 KV BITALE

Feeder No / Name : 204 / 11 KV GHATANE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
1	.112
2	.1174
9	1.3927
10	1.56
11	1.6575
12	.192
13	1.3927
14	1.4243
15	1.3443
16	1.3426
17	.1006
18	.1658
19	.1638
20	.1966
21	.1844
22	.1658
23	.8322
24	.116
<b>Max</b>	<b>1.6575</b>
<b>Min</b>	<b>.1006</b>
<b>Avg</b>	<b>.6923</b>



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274128 / 33/11 KV BITALE

Feeder No / Name : 205 / 11 KV BANDHARA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
1	.6226
2	.6081
3	.663
4	.6722
5	.6401
6	.7042
7	.6722
15	.0497
16	.0648
17	.0663
18	.064
19	.0819
20	.08
21	.081
22	.064
23	.0497
24	.6081
<b>Max</b>	<b>.7042</b>
<b>Min</b>	<b>.0497</b>
<b>Avg</b>	<b>.3407</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274128 / 33/11 KV BITALE

Feeder No / Name : 206 / 11 KV MALIKPETH

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17
HR	Load (MW)	Load (MW)
1	.0838	
2	.0829	
9	1.004	
10	1.0883	
11	1.4575	
12	1.2963	
13	.9922	
14	1.2483	
15	1.3923	
16	1.3123	
17	.0848	
18	.0829	
19	.0995	
20	.1341	
21	.1311	
22	.116	.116
23	.5344	
24	.0848	
Max	1.4575	.116
Min	.0829	.116
Avg	.6236	.116

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274152 / 33/11 TAKALI SIKANDAR

Feeder No / Name : 201 / 11 KV SOUNDANE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	04-AUG-17	05-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.4287	.5258
2		.4287	.5258
9		2.9264	.0762
10		.2058	3.0483
11			3.3532
12		3.2769	3.3532
13		3.2007	3.3532
14		3.2007	3.2922
15		3.1245	3.0483
16		3.0483	
17		.3772	
18		.4287	.7011
19		.5144	.7011
20		.5144	.7362
21		.5144	.5609
22		.5144	.5609
23		.5144	.5959
24	.3125	.4458	.5258
Max	.3125	3.2769	3.3532
Min	.3125	.2058	.0762
Avg	.3125	1.3920	1.5599

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274152 / 33/11 TAKALI SIKANDAR

Feeder No / Name : 202 / 11 KV TAMBOLE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	04-AUG-17	05-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
1		2.5911	2.9721
2		2.5911	3.0483
3		2.5911	3.0483
4		2.7435	3.0483
5		2.8959	3.0483
6		.2401	3.3532
7		.2743	3.4294
8		.2743	3.2007
15			.5258
17		.5144	
18		.6001	.7011
19		.6859	.929
20		.6001	.9465
21		.6001	.8063
22		.6001	.8063
23		2.8959	2.9492
24	.3887	2.5911	2.8959
Max	.3887	2.8959	3.4294
Min	.3887	.2401	.5258
Avg	.3887	1.4556	2.2318

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274152 / 33/11 TAKALI SIKANDAR

Feeder No / Name : 203 / 11kv PATKUL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	04-AUG-17	05-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
1	2.3624	.3429	.3506
2	2.4387	.3429	.3506
3	2.5149		
4	2.7435		
5	3.0483		
6	3.2007		
7	3.3532		
8	3.2007		
9		3.4294	3.4294
10		3.3532	3.658
11		3.4294	3.658
12		3.4294	3.4446
13		3.4294	3.4446
14		3.4294	3.4141
15		3.2007	
16		3.0483	
17		.2572	.3506
18		.3429	.3506
19		.3429	
20		.4287	
21		.4287	
22		.4287	
23		.3429	
24	.3239	.4115	.3506
Max	3.3532	3.4294	3.658
Min	.3239	.2572	.3506
Avg	2.5763	1.6899	2.0729

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274152 / 33/11 TAKALI SIKANDAR

Feeder No / Name : 204 / 11 KV TAKALI SIKANDAR  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	04-AUG-17	05-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
1		1.7528	1.7528
2		1.7528	1.829
3		1.7528	1.829
4		1.829	1.9052
5		1.829	1.9814
6		1.9509	2.1338
7		2.0729	2.21
8		2.1338	2.0576
15		.2572	.2804
16		.3429	
17		.3429	.3506
18		.4287	.3506
19		.4287	.4557
20		.4287	.4557
21		.4287	.4207
22		.4287	.4031
23		1.7528	1.8515
24	.3506	1.7528	1.7528
Max	.3506	2.1338	2.21
Min	.3506	.2572	.2804
Avg	.3506	1.2037	1.2953

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274152 / 33/11 TAKALI SIKANDAR

Feeder No / Name : 205 / 11 KV TAKALI(S) GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.4862
Max	.4862
Min	.4862
Avg	.4862

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274194 / 33/11 KV BHAMBEWADI

Feeder No / Name : 201 / 11 KV BHAMBHEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.3048
Max	.3048
Min	.3048
Avg	.3048



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274194 / 33/11 KV BHAMBEWADI

Feeder No / Name : 202 / 11kv Ashte

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.3048
Max	.3048
Min	.3048
Avg	.3048

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274194 / 33/11 KV BHAMBEWADI

Feeder No / Name : 203 / 11 KV HINGANI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.1829
Max	.1829
Min	.1829
Avg	.1829

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274201 / 33/11 KV KURANWADI(ASHTI)

Feeder No / Name : 201 / 11 KV KURANWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0579	.0486	.3475	.3239	.4534	.3765	.3715
2	.061	.0486	.3185	.3315	.5182	.362	.4161
3	.0762	.0486	.3765	.3239	.6154	.4054	.4755
4	.0762	.0486	.4054	.583	.6802	.4344	.5647
5	.0914	.081	.5068	.7287	.7287	.5068	.6687
6	.1067	.1134	.5792	1.0688	.8259	.7095	.7727
7			.9556	1.166	1.1012	.8688	.9659
8			.9556	1.166	1.0202	.9556	.9659
9	.7011	.7287					
10	.9145	.703					
11	.9145	.8097					
12	.9145	.8421					
13	.8383	.8745					
14	.8383	.9393					
15	.8383	.9717					
16	.8383	.9717					
19	.0762	.0648	.0724	.081	.0648		.0446
20	.0762	.0648	.0724	.081	.0648		.0594
21	.0762	.0648	.0724	.0648	.0648		.0446
22	.0762	.0648	.0434	.0648	.0486		.0446
23	.0457	.3239	.2896	.3563	.3239		.2972
24	.061	.0486	.3185	.3239	.4049	.3185	.3269
Max	.9145	.9717	.9556	1.166	1.1012	.9556	.9659
Min	.0457	.0486	.0434	.0648	.0486	.3185	.0446
Avg	.3839	.3931	.3796	.4760	.4939	.5486	.4299

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274201 / 33/11 KV KURANWADI(ASHTI)

Feeder No / Name : 202 / 11 KV ASHTI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.1848	.2561	.2772	.2218	.2195	.2218
2	.2218	.1848	.2561	.2772	.2218	.2195	.2218
3	.2587	.1848	.2561	.2772	.2587	.2561	.2587
4	.3326	.1848	.2926	.2772	.3326	.2926	.3326
5	.4066	.2772	.3292	.3696	.3326	.3292	.3696
6	.4805	.4805	.4755	.4805	.4805	.439	.4435
9	.3326						
10	.2957						
11	.2218	.2587	.2743	.2957	.2587	.3292	.2957
12	.2218	.2957	.2743	.2587	.2218	.2561	.2772
13	.2218	.2587	.2743	.2218	.2218	.2195	.2402
14	.2218	.2218	.2743	.2218	.1848	.2195	.2587
15	.2218	.1478	.2743	.1848	.1478		.2218
16	.2218	.1848	.2743	.1848	.1848		.1848
19	.3696	.5175	.2743	.4435	.4435		.4435
20	.3696	.4805	.3658	.3696	.4066		.4435
21	.3696	.3696	.3658	.3326	.3326		.3326
22	.3696	.2957	.2743	.2957	.3326		.2957
23	.1848	.2587	.2743	.2587	.2587		.2587
24	.2587	.1848	.2561	.2772	.2218	.2561	.2218
Max	.4805	.5175	.4755	.4805	.4805	.439	.4435
Min	.1848	.1478	.2561	.1848	.1478	.2195	.1848
Avg	.2902	.2762	.2957	.2947	.2813	.2760	.2957

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274201 / 33/11 KV KURANWADI(ASHTI)

Feeder No / Name : 203 / 11 KV MASOBA AG

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6194	1.7004	.2622	.1658	.3315	.3277	.3563
2	1.6518	1.7004	.2622	.1658	.3315	.3277	.3563
3	1.7004	1.7004	.2622	.1658	.3315	.3277	.3563
4	1.749	1.7004	.2622	.1658	.3315	.3605	.3725
5	1.7814	1.7004	.2949	1.6575	.3647	.3605	.3887
6	1.7814	1.9433	.3277	.2486	.3647	.3932	.3887
7	1.8623	2.2672					
8	1.9433	2.2672					
9				2.4863	2.7183	2.6543	2.5911
10				2.5692	2.9835	2.6871	2.6397
11			1.9662	2.652	2.7515	2.7854	2.6397
12			1.9662	2.7349	2.7183	2.6871	2.672
13			2.2939	2.7846	2.6852	2.6216	2.6882
14			2.2939	2.7515	2.7349	2.4577	2.6235
15			2.2939	2.7183	2.7515		2.5587
16			2.2939	2.6852	2.6852		2.5263
19	.1619	.2439	.1638	.3315	.3315		.3563
20	.1619	.2439	.2458	.3315	.3315		.3725
21	.1619	.2439	.2458	.3647	.3315		.3725
22	.1619	.2439	.1638	.3647	.3481		.3725
23	1.4575	.2439	.1638	.3647	.3315		.3725
24	1.587	1.7004	.2622	.1658	.3315	.3277	.3563
<b>Max</b>	<b>1.9433</b>	<b>2.2672</b>	<b>2.2939</b>	<b>2.7846</b>	<b>2.9835</b>	<b>2.7854</b>	<b>2.6882</b>
<b>Min</b>	<b>.1619</b>	<b>.2439</b>	<b>.1638</b>	<b>.1658</b>	<b>.3315</b>	<b>.3277</b>	<b>.3563</b>
<b>Avg</b>	<b>1.2701</b>	<b>1.2785</b>	<b>.8903</b>	<b>1.2937</b>	<b>1.3045</b>	<b>1.4091</b>	<b>1.2680</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274205 / 33/11 KV DEWADI

Feeder No / Name : 202 / 11 KV DEWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	.9774	.2401	.1715	.2058	.2229	.1715
2	1.2346	1.2689	.2229	.1715	.2058	.2229	.1715
3	1.3032	1.3717					
4	1.406	1.5089					
5	1.5089	1.749					
6	2.2634	2.4691					
7	3.1207	2.7263					
8	2.4006	2.8807					
9	2.4006		2.0576	1.7147	1.7147	2.0576	
10			2.4691	2.1434	2.2977	2.8464	2.7435
11			2.6578	2.3663	2.4348	2.7092	2.7778
12				2.4691	2.5377	2.6406	2.6749
13			2.4348	2.4348	2.6063	2.6063	2.6406
14			2.2634	2.4006	2.6749	2.6578	2.7092
15				2.3663	2.7435	2.692	2.7435
16			2.0919	2.332	2.9492	2.7435	2.8121
17	.2743	.2743	.1715	.1372	.2229	.2743	.1715
18	.3258	.3086	.2058	.2743	.2401	.3086	.2401
19	.3601	.3429	.2743	.3086	.2572	.3772	.3086
20	.3772	.3429	.2743	.3772	.2743	.3429	.3772
21	.3601	.3258	.2743	.3429	.2915	.3429	.3772
22	.3429	.3429	.2743	.2743	.2743	.3086	.2743
23	.6173	.2915	.2572	.2401	.2572	.2743	.2058
24	1.166	.6516	.2401	.2058	.2401	.2401	.1715
Max	3.1207	2.8807	2.6578	2.4691	2.9492	2.8464	2.8121
Min	.2743	.2743	.1715	.1372	.2058	.2229	.1715
Avg	1.2154	1.1145	1.0256	1.1517	1.246	1.3260	1.2689

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274205 / 33/11 KV DEWADI

Feeder No / Name : 203 / 11 KV WAFALE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.4115	1.2346	1.2003	1.3032	1.2517	1.749
2	.4115	.4115	1.286	1.1145	1.3717	1.4403	1.749
3			1.286	1.2003	1.4232	1.6461	1.8004
4			1.3375	1.286	1.4918	1.9204	1.8519
5			1.3717	1.8861	1.6804	2.4006	1.8861
6			1.8861	2.3148	2.6406	2.5892	2.332
7			2.4348	2.6063	2.915	2.7435	2.9321
8			2.4006	1.286	2.7092	2.9492	3.0864
9	2.6749	2.9492					
10	2.6063	2.7606					
11	2.5377	2.4006					
12	2.5034	1.9204					
13	2.5377	2.2634					
14	2.6063	2.3663					
15	2.7092	2.4348					
16	2.7435	2.4006					
17	.3258	.3086	.3944	.3772	.3429	.3944	.4115
18	.3772	.4287	.4287	.4458	.4115	.4801	.4458
19	.4115	.4801	.5144	.4801	.4115	.6173	.4801
20	.4801	.4287	.4287	.5487	.3772	.5487	.5144
21	.463	.4115	.3772	.4115	.3429	.5144	.5144
22	.4458	.3772	.3429	.3429	.3258	.4458	.4458
23	.4287	1.0974	1.2003	1.2003	.583	1.3375	1.5089
24	.4458	.4115	1.2003	1.286	1.2346	.6173	1.7147
Max	2.7435	2.9492	2.4348	2.6063	2.915	2.9492	3.0864
Min	.3258	.3086	.3429	.3429	.3258	.3944	.4115
Avg	1.3965	1.3479	1.1328	1.1242	1.2228	1.3685	1.4639

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274205 / 33/11 KV DEWADI

Feeder No / Name : 205 / 11 KV DEWADI - WAFALE

GAOTHAN FEEDER

GAONTHAN Feeder KV- 11 /

OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3429	.3086	.3086	.3086	.3086	.3086
2	.2743	.3429	.3086	.3086	.3086	.3086	.3086
3	.2743	.3429	.3429	.2743	.2743	.3429	.3429
4	.3429	.3772	.3601	.2572	.3086	.3601	.3601
5	.3772	.4115	.3772	.3429	.3772	.3772	.3429
13	.2401	.1372	.1715	.1372	.3086	.1372	.1372
14	.2401	.1543	.1372	.1372	.2915	.1543	.1715
15	.2229	.1543		.1372	.2743	.1543	.2058
16	.2229	.1715	.1715	.1372	.2401	.1715	.1715
17	.3086	.2058	.2401	.2058	.2915	.2058	.1715
18	.4115	.2743	.2743	.2743	.3601	.2572	.2743
19	.4287	.3086	.3429	.3772	.3772	.3258	.3086
20	.4458	.3429	.3772	.4458	.4115	.3429	.3772
21	.4115	.3772	.3772	.3772	.3772	.3429	.3772
22	.3944	.4115	.3772	.3772	.3429	.3429	.3429
23	.3601	.3429	.3429	.3429	.3258	.3086	.2743
24	.3086	.3429	.2743	.3429	.3429	.3086	.2743
Max	.4458	.4115	.3772	.4458	.4115	.3772	.3772
Min	.2229	.1372	.1372	.1372	.2401	.1372	.1372
Avg	.3278	.2965	.2990	.2814	.3248	.2794	.2794



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274217 / 33/11 KV GOTEWADI S/S

Feeder No / Name : 201 / 11 KV NANDGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							1.3123
2							1.4089
3							1.4575
4							1.5061
5							1.5684
6							1.6644
7							2.0325
8							1.9134
15							.1086
16							.1086
23	.9717	.9602	1.3283	.9717	1.3603	1.1523	1.3441
24	.6097						1.1523
Max	.9717	.9602	1.3283	.9717	1.3603	1.1523	2.0325
Min	.6097	.9602	1.3283	.9717	1.3603	1.1523	.1086
Avg	.7907	.9602	1.3283	.9717	1.3603	1.1523	1.2981

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274217 / 33/11 KV GOTEWADI S/S

Feeder No / Name : 202 / 11 KV GOTEWADI AG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.1448
2							.1086
9							.6241
10							.6241
11							.5601
12							.421
16	.1075						.4858
18							.0724
23	.1791	.1448	.1448	.1478	.1463	.1433	.1448
24	.3048						.1448
<b>Max</b>	<b>.3048</b>	<b>.1448</b>	<b>.1448</b>	<b>.1478</b>	<b>.1463</b>	<b>.1433</b>	<b>.6241</b>
<b>Min</b>	<b>.1075</b>	<b>.1448</b>	<b>.1448</b>	<b>.1478</b>	<b>.1463</b>	<b>.1433</b>	<b>.0724</b>
<b>Avg</b>	<b>.1971</b>	<b>.1448</b>	<b>.1448</b>	<b>.1478</b>	<b>.1463</b>	<b>.1433</b>	<b>.3331</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274217 / 33/11 KV GOTEWADI S/S

Feeder No / Name : 203 / 11 KV D.BABHULGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)
13		1.3441
14		2.2085
15		1.5524
16		2.1445
17		1.7604
18		1.9524
19		2.3045
20		1.9364
23		.2149
24	.4572	
<b>Max</b>	<b>.4572</b>	<b>2.3045</b>
<b>Min</b>	<b>.4572</b>	<b>.2149</b>
<b>Avg</b>	<b>.4572</b>	<b>1.7131</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274229 / 33/11 KV WAD-DEGAON S/S

Feeder No / Name : 201 / 11 KV NEW KOTHALE AG (WAD- SEPARATED AG FEEDERS HAVING SPECIAL  
DEGA Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17
HR	Load (MW)
1	.0857
2	.1029
9	1.1736
11	1.4746
12	1.2041
13	1.1736
14	1.1279
15	1.2041
16	1.2041
17	.0857
18	.1543
19	.1715
20	.1886
21	.2229
22	.2058
23	1.2346
24	.0857
<b>Max</b>	<b>1.4746</b>
<b>Min</b>	<b>.0857</b>
<b>Avg</b>	<b>.6529</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274229 / 33/11 KV WAD-DEGAON S/S

Feeder No / Name : 202 / 11 KV WAD-DEGOAN AG (WAD- SEPARATED AG FEEDERS HAVING SPECIAL  
DEGAV Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17
HR	Load (MW)	Load (MW)
1	.0857	
2	.0857	
9	1.6766	
10	1.7833	
11	1.6918	
12	1.3413	
13	1.3413	
14	1.3108	1.0974
15	1.3108	1.1888
16	1.5546	1.4632
17	.0762	.0686
18	.1029	.0686
19	.12	.12
20	.1372	.1372
21	.1543	.1029
22	.12	.1029
23	.7773	.0857
24	.1029	
<b>Max</b>	<b>1.7833</b>	<b>1.4632</b>
<b>Min</b>	<b>.0762</b>	<b>.0686</b>
<b>Avg</b>	<b>.7652</b>	<b>.4435</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274229 / 33/11 KV WAD-DEGAON S/S

Feeder No / Name : 203 / 11 KV AUNDHI AG (WAD-DEGAV SEPARATED AG FEEDERS HAVING SPECIAL  
S.S Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17
HR	Load (MW)	Load (MW)
1	.9755	
2	1.0364	
3	1.0212	
4	1.0974	
5	1.4327	
6	1.5851	
7	1.829	
8	1.7071	
17	.12	.1715
18	.1715	.2058
19	.2401	.2058
20	.2572	.2401
21	.2058	.2058
22	.1886	.2058
23	.1886	.9755
24	.2286	
Max	1.829	.9755
Min	.12	.1715
Avg	.7678	.3158

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274230 / 33/11 KV JAMGAON S/S

Feeder No / Name : 201 / 11 KV JAMGAON AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-AUG-17
HR	Load (MW)
24	.2286
Max	.2286
Min	.2286
Avg	.2286

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274230 / 33/11 KV JAMGAON S/S

Feeder No / Name : 202 / 11 KV KORAWALI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-AUG-17
HR	Load (MW)
24	.3048
Max	.3048
Min	.3048
Avg	.3048



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274230 / 33/11 KV JAMGAON S/S

Feeder No / Name : 203 / 11 KV JAMGAON GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.2134
Max	.2134
Min	.2134
Avg	.2134

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274233 / 33/11 KV MIRI S/S

Feeder No / Name : 201 / 11 KV MIRI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2641	.2641	.2641	.2829	.2641	.2641
2	.2665	.2641	.2641	.2641	.2829	.2641	.2641
3	.2641	.2641	.2641	.2641	.2829	.2641	.2641
4	.2641	.2641	.2641	.2641	.2829	.2641	.2641
5	.2641	.2641	.2641	.2641	.3772	.2641	.2641
9	.2641	.2641	.2641	.2641	.3395	.2641	.2641
10	.2641	.2641	.2641	.2641	.2641	.2641	.2641
11	.2641	.2641	.2641	.2641	.2641	.2641	.2641
12	.2641	.2641	.2641	.2641	.2641	.2641	.2641
13	.2641	.2641	.2641	.2641	.2641	.2641	.2641
14	.2641	.2641	.2641	.2829	.2641	.2641	.2641
15	.2641	.2641	.2641	.2829	.2641	.2641	.2641
16	.2641	.2641	.2641	.2829	.2641	.2641	.2641
17	.2641	.2641	.2641	.2829	.2641	.2641	.2641
18	.2641	.2641	.2641	.2829	.2641	.2641	.2641
19	.2641	.2641	.2641	.2829	.2641	.2641	.2641
20	.2641	.2641	.2641	.3772	.2641	.2641	.2641
21	.2641	.2641	.2641	.3772	.2641	.2641	.2641
22	.2641	.2641	.2641	.3772	.2641	.2641	.2641
23	.2641	.2641	.2641	.2829	.2641	.2641	.2641
24	.2641	.2641	.2641	.2641	.2829	.2641	.2641
Max	.2665	.2641	.2641	.3772	.3772	.2641	.2641
Min	.2641	.2641	.2641	.2641	.2641	.2641	.2641
Avg	.2642	.2641	.2641	.2865	.2776	.2641	.2641

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274233 / 33/11 KV MIRI S/S

Feeder No / Name : 202 / 11 KV MIRI AG (MIRI S.ST,) SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.4715	.0377	.0377	.0377	.0377	.0377
2	.5658	.4715	.0377	.0377	.0377	.0377	.0377
3	.5658	.4715					
4	.5658	.4715					
5	.5658	.4715					
6	.5658	.4715					
7	.5658	.4715					
8	.5658	.4715					
9			.5658	.5658	.3772	2.452	2.6406
10			.5658	.5658	.3772	2.5463	2.7349
11			.4715	.5658	.415	2.5463	2.6406
12			.4715	.5658	.4338	2.5463	2.6406
13			.4715	.5658	.4527	2.5463	2.6406
14			.4715	.5658	.4715	2.5463	2.6406
15			.4715	.5658	.3772	2.5463	2.6406
16			.4715	.5658	.3772	2.5463	2.6406
17	.0377	.0377	.0377	.0377	.0377	.0377	.0377
18	.0377	.0377	.0377	.0377	.0377	.0377	.0377
19	.0377	.0377	.0377	.0377	.0377	.0377	.0377
20	.0377	.0377	.0377	.0377	.0377	.0377	.0377
21	.0377	.0377	.0377	.0377	.0377	.0377	.0377
22	.0377	.0377	.0377	.0377	.0377	.0377	.0377
23	.4715	.0377	.0377	.0377	.0377	.0377	.0377
24	.5658	.4715	.0377	.0377	.0377	.0377	.0377
Max	.5658	.4715	.5658	.5658	.4715	2.5463	2.7349
Min	.0377	.0377	.0377	.0377	.0377	.0377	.0377
Avg	.3619	.2817	.2410	.2724	.2033	1.1474	1.1998

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274233 / 33/11 KV MIRI S/S

Feeder No / Name : 203 / 11 KV NEW YENAKI AG(MIRI S.ST. Feeder KV- 11 / OUTGOING SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	1.5089	1.6975	1.8861	1.5089	1.5089
2	.0377	.0377	1.6975	1.6975	2.1691	1.6975	1.5089
3			1.8861	1.6975	2.1691	1.8861	1.6032
4			2.0748	1.6975	2.2634	1.8861	1.8861
5			2.2634	1.6975	2.2634	1.8861	1.8861
6			2.2634	1.6975	2.452	2.0748	1.8861
7			2.452	1.6975	2.6406	2.2634	1.9805
8			2.452	1.6975	2.6406	2.452	1.9805
9	1.9805	1.1317					
10	2.1691	1.5089					
11	2.1691	1.6975					
12	2.1691	1.8861					
13	2.0748	2.2634					
14	2.0748	2.452					
15	2.0748	2.6406					
16	2.0748	2.6406					
17	.0377	.0377	.0377	.0377	.0377	.0377	.0377
18	.0377		.0377	.0377	.0377	.0377	.0377
19	.0377		.0377	.0377	.0377	.0377	.0377
20	.0377		.0377	.0377	.0377	.0377	.0377
21	.0377		.0377	.0377	.0377	.0377	.0377
22	.0377	.0377	.0377	.0377	.0377	.0377	.0377
23	.0377	1.1317	1.6975	1.6975	1.5466	1.5089	2.7349
24	.0377	.0377	1.3203	1.6975	1.6975	1.5466	1.5089
Max	2.1691	2.6406	2.452	1.6975	2.6406	2.452	2.7349
Min	.0377	.0377	.0377	.0377	.0377	.0377	.0377
Avg	.9536	1.2529	1.2401	1.0751	1.3722	1.1835	1.1694

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 277015 / 132 EHV MOHOL

Feeder No / Name : 405 / Begumpur Wagholi Mill

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	.679
Max	.679
Min	.679
Avg	.679

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 277015 / 132 EHV MOHOL

Feeder No / Name : 408 / Kothari Agritec

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	.8488
Max	.8488
Min	.8488
Avg	.8488

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 277015 / 132 EHV MOHOL

Feeder No / Name : 409 / 33 KV SOLAR VISHWAJ ENERGY  
PVT Feeder KV- 33 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.5716
Max	.5716
Min	.5716
Avg	.5716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 277015 / 132 EHV MOHOL

Feeder No / Name : 704 / 132 KV Loknete SF Cogen

Feeder KV- 132 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(NON CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 201 / 11KV Sakal

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5304					.6344	.6859
2	.4784					.583	.6516
3	.5851					.6001	.6516
4	.5268					.6001	.583
5	.4868					.6173	.583
6	.5441	.3913				.6173	.5316
7	.4999	.3864				.6001	.5487
8	.6935	.2366				.583	.6001
9	.7282		.6348	.8865	.9335	.7468	
10	.8322		.8962	.811	.9709	.9522	
11	.8916		.8962	.9526	.9522	1.0562	
12			.9896	.9335	1.0456	1.0751	
13	.8916		1.0164	.9907	1.0269	.9979	
14	.9431		1.0349	.9997	.9335		
15	1.0402		.9979	.9717	.8402	1.1506	
16	1.0923		.9709	1.0288	.8962		
17	.6859	.4115	.8573	.7373	.9896	1.0631	.9335
18	.7202	.4287	.6516	.6859	.9335	.8573	.8215
19	.7545	.4801	.7202	.6516	.7095	.7716	.7468
20	.7202	.4287	.7373	.6001	.6908	.7545	.6535
21	.6859	.4115	.703	.6001	.5975	.7202	.6535
22	.6859	.4801	.6516	.583		.6859	.6535
23	.5721	.4801	.6344	.583		.6859	
24	.6104					.6516	.703
Max	1.0923	.4801	1.0349	1.0288	1.0456	1.1506	.9335
Min	.4784	.2366	.6344	.583	.5975	.583	.5316
Avg	.7043	.4135	.8262	.8010	.8861	.7729	.6667

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 202 / 11KV VENKY SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2452					.2572	.3086
2	.2263					.2401	.2572
3	.2641					.2401	.2572
4	.2075					.2058	.2401
5	.2452					.2058	.2401
6	.2829	.2452				.1886	.2229
7	.2641	.2075				.2058	.2058
8	.2263	.1698				.2229	.2058
9	.3734		.2987	.3395	.4108	.3018	
10	.4207		.3547	.4904	.4668	.3206	
11	.5601		.3734	.5093	.4854	.3772	
12	.5228		.4294	.9431	.4854	.3961	
13	.4294		.3734	.4338	.5041	.2452	
14	.4668		.3174	.4527	.4668		
15	.4854			.4338	.4294	.3961	
16	.5041			.4715			
17	.4287	.2058	.3772	.3944	.5041	.3772	.3734
18	.4115	.2058	.3601	.3772		.3429	.2054
19	.3944	.2058	.3429	.3429	.3734	.3601	.2452
20	.3429	.2058	.3086	.3086	.3734	.3429	.2614
21	.2743	.1886	.2743	.2058	.3174	.3086	.2829
22	.2572	.1886	.2743	.2058		.2572	.2829
23	1.094	.2058	.2743	.2229			
24	.4287					.2915	.2572
Max	1.094	.2452	.4294	.9431	.5041	.3961	.3734
Min	.2075	.1698	.2743	.2058	.3174	.1886	.2054
Avg	.3898	.2029	.3353	.4088	.4379	.2897	.2564

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 203 / 11 KV Smruti Express NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder Feeder KV- 11 / (CONTINUOUS PROCESS)(NO STAGGERING)  
 OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3961					.4115	.4115
2	.4527					.3772	.3772
3	.4527					.3772	.3772
4	.4527					.3429	.3944
5	.4527					.3429	.3944
6	.4527	.4715				.3944	.3944
7	.4338	.4904				.3772	.3772
8	.4338	.4527				.3601	.3601
9	.4715		.4108	.4715	.4481	.4338	
10	.5093				.4668	.4338	
11	.5041		.4481	.4527	.7095	.4338	
12	.5041		.4481	.4527	.5041	.4527	
13	.4854		.4481	.4527	.5415	.4904	
14	.5041		.4294	.4527	.4854		
15	.5041			.4338	.4481	.5093	
16	.5093			.4715	.4481		
17	.463	.4287	.3944	.4115	.4668	.463	
18	.4801	.4287	.3944	.4115	.462	.4458	.4108
19	.5144	.4458	.4115	.4115	.4481	.4458	.415
20	.5144	.4287	.4801	.4287	.4481	.4458	.415
21	.4973	.4287	.4973	.4287	.4668	.4287	.3961
22	.4801	.4115	.4801	.4115		.4287	.415
23	.4715	.4115	.463	.4115		.4287	
24	.4715					.4287	.4287
Max	.5144	.4904	.4973	.4715	.7095	.5093	.4287
Min	.3961	.4115	.3944	.4115	.4481	.3429	.3601
Avg	.4755	.4398	.4421	.4359	.4880	.4206	.3976

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 204 / 11KV BANG DATA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7733					.7545	.7202
2	.8192					.7202	.6859
3	.7545					.7202	.703
4	.724					.6859	.6859
5	.7049					.6859	.7202
6	.8002	.8299				.7545	.7716
7	.8764	.7922				.7202	.5144
8	.8192	.6979				.6859	.3429
9	.8573		.7762	.9145	.6413	.9054	
10	.9145		.9335	.8488	.7167	.9054	
11	.9145		.8962	.8954	.8215	.9431	
12	.8676		.8962	.9526	.8589	.9896	
13	.8299		.9335	.8954		.9149	
14	.8402		1.0082	.9526	.7468		
15	.8962			.9145	.6535	.9709	
16	.9808			.9145	.7468		
17	.9259	.7545	.8573	.8745	.8215	.7202	.8589
18	.8573	.7202	.8573	.8573	.8589	.7202	.8589
19	.7716	.6859	.8059	.8402	.8962	.7373	.8402
20	.7716	.6859	.7716	.8059	.8215	.7202	.8299
21	.8402	.6687	.8059	.8059	.8402	.7202	.7545
22	.823	.6516	.8059	.7716		.7545	.7167
23	.9145	.6516	.8059	.7888		.7545	
24	.8383					.7888	.7373
Max	.9808	.8299	1.0082	.9526	.8962	.9896	.8589
Min	.7049	.6516	.7716	.7716	.6413	.6859	.3429
Avg	.8381	.7138	.8580	.8688	.7853	.7851	.7160

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 205 / 11KV BPL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1883					1.3717	1.5432
2	1.2071					1.3375	1.5261
3	1.094					1.3375	1.5089
4	1.1128					1.286	1.4575
5	1.0751					1.2003	1.3717
6	1.1128	1.094				1.1317	1.3203
7	1.094	.9808				1.1145	1.3717
8	1.3957	.811				1.0802	1.5432
9	1.4937		1.3443	1.4523	1.6804	1.1694	
10	1.7737		1.4563	1.6409	1.8671	1.3392	
11			1.4563	1.6598	1.8298	1.5278	
12	1.9044		1.3817	1.3203	1.7551	1.4712	
13	1.8671		1.363	1.6598	1.8298	1.5844	
14	1.8671		1.3817	1.6409	1.6804		
15	1.8484			1.6221	1.8858	1.4901	
16	1.8298			1.5844	1.9978		
17	1.5604	.823	1.4575	1.4403	2.1658	1.4746	1.9044
18	1.4575	.823	1.5947	1.5432	2.0351	1.3717	1.8671
19	1.406	.8059	1.3889	1.5432	1.9791	1.2346	1.8298
20	1.3717	.8059	1.3717	1.3717	1.8671	1.2689	1.7918
21	1.3203	.8059	1.3203	1.0802	1.531	1.286	
22	1.286	.823	1.286	1.0288		1.3032	1.8484
23	1.094	.823	1.2003	1.0802		1.3717	
24	1.3375					1.4403	1.5947
Max	1.9044	1.094	1.5947	1.6598	2.1658	1.5844	1.9044
Min	1.0751	.8059	1.2003	1.0288	1.531	1.0802	1.3203
Avg	1.4216	.8596	1.3848	1.4445	1.8542	1.3269	1.6056

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 206 / 11KV INDIAN OIL

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0642					.9945	.9945
2	.9774					1.0288	.9945
3	.9036					1.0631	1.046
4	.9189					1.0974	1.0631
5	1.046					1.166	1.0631
6		1.4003				1.2346	1.0974
7	1.3203	1.4377				1.2346	1.0631
8	1.1949	.0934				1.2003	.9774
9	1.1763		1.1203	.9709	1.1203	1.1827	
10	1.1949		1.2323	1.0719	1.2323	1.1104	
11	1.1203		1.251	1.0242	1.1949	.985	
12	1.1203		1.2323	.924	.6348	.8326	
13	1.1203		1.0269			.7087	
14	1.1576		.9335	1.0164	.9335		
15	1.1949			1.1763	.7842	.7865	
16	1.2323		1.1576	1.2197	.7125		
17	.9088	1.1317	1.0288	1.0974	1.1203	.7716	1.0269
18	1.1145	1.1145	.9945	1.1145	1.307	.8573	1.0082
19	1.1488	1.0974	.8573	1.1317		1.046	.8402
20	1.2003	1.2346	1.2003	1.2003	1.2696	1.0631	1.1088
21	1.3203	1.3375	1.2689	1.2689	1.2883	1.1145	1.2136
22	1.286	1.286	1.2346	1.2003		1.1317	1.2323
23	1.226	1.2346	1.0631	1.1831		1.0288	
24	1.1626					.9774	.9774
Max	1.3203	1.4377	1.2689	1.2689	1.307	1.2346	1.2323
Min	.9036	.0934	.8573	.924	.6348	.7087	.8402
Avg	1.1352	1.1368	1.1144	1.1143	1.0543	1.0280	1.0471

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 207 / 11KV AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5441					1.8004	1.4918
2	.6133					1.8004	1.5089
3	.6481					1.8176	1.5261
4	.6952					1.8004	1.5432
5	.7773					1.8176	1.5432
6	.9667	1.5971				1.8347	1.6118
7	1.153	1.7901				1.8861	1.7147
8	1.0595	1.8185				1.9204	1.8347
9	1.587		1.1949	.9014	1.1763	.8855	
10	1.6385		1.2696	.9779	1.2136	.9069	
11	1.5089		1.3443	.6952	1.251	1.0648	
12	1.643		1.307	.9172	1.251	1.1363	
13	1.6766			1.0608		1.1271	
14	1.587			1.0031	1.1203		
15	1.7772			.9646	.9709	1.0185	
16	1.7166			1.0082	1.1576		
19	.3944	.3601	.4458	.3944	.5121	.4115	.4108
20	.4287	.3429	.4287	.4287	.4435	.4115	.4854
21	.4458	.2743	.4287	.463	.5601	.4115	.4481
22	.4287	.3429	.4115	.4287		.3772	.4294
23	1.3443	1.286	1.4575	1.4746		1.2003	
24	.3953					1.7833	1.4232
Max	1.7772	1.8185	1.4575	1.4746	1.251	1.9204	1.8347
Min	.3944	.2743	.4115	.3944	.4435	.3772	.4108
Avg	1.0468	.9765	.9209	.8244	.9656	1.2706	1.2286

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 208 / 11kv volant

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17
HR	Load (MW)
24	.703
Max	.703
Min	.703
Avg	.703



Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 209 / 11kv Vidhyapith Exp. NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	.5316
Max	.5316
Min	.5316
Avg	.5316

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 210 / 11kv ASHOK POLYMERS Exp. NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0124					.0857	.0857
2	.0162					.0857	.0857
3	.0181					.0857	.0857
4	.02					.0857	.0857
5	.0152					.0857	.0857
6	.0143	.0124				.0857	.0857
7	.0162	.0133				.0857	.0857
8	.0124	.0133				.0857	.0857
9	.0133			.0143	.0762	.0124	
10	.0133			.0171	.0772	.0181	
11			.0934	.0181		.0143	
12	.0133		.0934	.0143	.0762	.0105	
13	.0133		.0934	.0124	.0762	.0143	
14	.0133		.0934	.0124	.0772		
15				.0162	.0762	.0124	
16	.0133		.0934	.0143	.0762		
17	.1029	.1029	.1029	.1029	.0762	.0857	
18	.1029	.0857	.1029	.1029	.0762	.0857	
19	.1029	.0857	.1029	.1029	.0762	.0857	
20	.0857	.0857	.1029	.0857	.0762	.0857	
21	.0857	.1029	.1029	.0857	.0762	.0857	
22	.0857	.1029	.1029	.0857		.0857	
23	.0124	.0857	.1029	.0857		.0857	
24	.0133					.0857	.0857
Max	.1029	.1029	.1029	.1029	.0772	.0857	.0857
Min	.0124	.0124	.0934	.0124	.0762	.0105	.0857
Avg	.0362	.0691	.0989	.0514	.0764	.0661	.0857

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274083 / 33/11 KV AKOLEKATI

Feeder No / Name : 201 / 11KV KARAMBA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.5506	.6706	.6249	.7373	.8097	.6401
2	.1905	.5243	.6097	.5864	.703	.7773	.5944
3		.5601	.5792	.6249	.6097	.7701	.5647
4		.7042	.6706	.8421	.6173	.7537	.6539
5		.852	.8078	.9414	.8642	.8619	.8535
6		.9503	1.0279	1.0279	.9717	1.1065	1.0623
7		1.2163	1.1984	1.1174	1.2963	1.3279	1.2955
8		1.1069	1.0936	1.0623	1.2651	1.2803	1.2803
9	.8436						
10	.9282						
11	.9602						
12	.9602						
13	.9172						
14	.9122						
15	.8322	.1905	.1905	.1905	.1905	.1905	.1905
16	.9172	.1905	.1905	.1905	.1905	.1905	.1905
17	.1905	.1905	.1905	.1905	.1905	.1905	.1905
18	.1905	.1905	.1905	.1905	.1905	.1905	.1905
19	.1905	.1905	.1905	.1905	.1905	.1905	.1905
20	.1905	.1905		.1905	.1905	.1905	.1905
21	.1905	.1905	.1905	.1905	.1905	.1905	.1905
22	.1905	.1905	.1905	.1905	.1905	.1905	.1905
23	.6401	.7621	.7164	.7811	.8288	.0625	.7935
24	.1905	.6154	.7186	.6718	.852	.852	.6859
Max	.9602	1.2163	1.1984	1.1174	1.2963	1.3279	1.2955
Min	.1905	.1905	.1905	.1905	.1905	.0625	.1905
Avg	.5348	.5203	.5545	.5447	.5705	.5626	.5527

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274083 / 33/11 KV AKOLEKATI

Feeder No / Name : 203 / 11 KV AKOLEKATI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7042	.415	.3772	.4338	.4715	.4527	.3772
2	.6249	.3772	.3584	.4904	.4715	.415	.3772
3	.6249						
4	.6478						
5	.9393						
6	1.085						
7	1.3094						
8	1.2811						
9		1.1069	1.1069	.8993	1.0082	1.1069	1.0212
10		1.0494	1.1069	.8916	1.1142	1.2018	1.1069
11		.9877	1.2492	.8619	1.0802	1.2498	1.1126
12		1.1728	1.2492	.945	1.1431	1.2346	1.0822
13		1.2193	1.326	.9755	1.1431	1.174	
14		1.2346	1.0848	1.0494	1.1561	1.1736	
15	.2427	1.1279	1.0494	1.0936	1.1248	1.1574	1.1279
16	.2987	1.0669	.8993	.9297	1.1248	1.1126	1.0185
17	.3734	.3292	.2743	.2987	.3018	.3734	.2054
18	.415	.4207	.3547	.3361	.3584	.4481	.2561
19	.5093	.5975	.4938	.5544	.5847	.5658	.3961
20	.679	.6722	.6602	.5914	.6602	.7167	.4835
21	.5601	.5601	.567	.6036	.6036	.6036	.5601
22	.5041	.5228	.5041	.5093	.5093	.5093	.5281
23	.4904	.4854	.415	.4904	.5093	.4338	.3734
24	.7042	.4527	.415	.3734	.4904	.4904	.3961
Max	1.3094	1.2346	1.326	1.0936	1.1561	1.2498	1.1279
Min	.2427	.3292	.2743	.2987	.3018	.3734	.2054
Avg	.6663	.7666	.7495	.6849	.7697	.8011	.6514

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274083 / 33/11 KV AKOLEKATI

Feeder No / Name : 204 / 11KV MARDI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8402	.6805	.8288	.8215	.8192	.8288	1.0059
2	.9335	.631	7.9395	.8619	.8288	.7773	.9724
3		.6135	.7459	1.0802	.7545	.7545	.9221
4		.6626	.8785	1.3611	.7545	.8192	1.1065
5		.8413	1.0774	1.4043	.9945	.9556	1.3077
6		1.1269	1.2742	1.4419	1.2136		1.5432
7		1.2346	1.4918	1.5432	1.2309	1.3717	1.749
8		1.1401	1.4403	1.3904		1.3375	1.5769
9	1.1105						
10	1.1105						
11	.9116						
12	.9614						
13	.9831						
14	1.0526						
15	1.1469		.5788		.6283	.695	.695
16	1.1469	.6908	.6401	.8131	.7023	.7316	.7947
17		.7468	.6908	.7682	.7842	.8871	.7133
18	.8316	.8962		.7682	.8215	.9979	.6878
19	1.0534	1.1763	.8779	1.2696	.8775		
20	1.2197	1.363	.9795	1.4003	.9522	.9709	.8029
21	1.1949	1.251	.8779	1.3306	.8962	.8962	.7421
22	1.0829	1.0829	.7577	1.1458	.8402	.7468	.7282
23	.7362	.9221	.8383	.8619	.9054	1.1065	.9602
24	.8316	.7164	.8718	.9088	.8785	.8718	1.073
Max	1.2197	1.363	7.9395	1.5432	1.2309	1.3717	1.749
Min	.7362	.6135	.5788	.7682	.6283	.695	.6878
Avg	1.0087	.928	1.3405	1.1277	.8754	.9218	1.0224

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274083 / 33/11 KV AKOLEKATI

Feeder No / Name : 205 / 11kv Banegaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2317	1.0288	1.3336	1.3908	.9526	1.0479	1.4098
2	.2389	.9907	1.2574	1.4098	.8573	.9907	1.3336
3		.9907	1.2384	1.467	.8573	.9526	1.2955
4		1.0479	1.4861	1.5432	.8573	1.0479	1.467
5		1.2384	1.6575	1.6575	1.2574	1.1431	1.7528
6		1.6766	1.7718	1.0669	1.8671	1.5623	2.0195
7		2.1148	1.9433	1.1622	2.0576	1.8099	2.4387
8		1.9052	1.448	2.1338	2.0957	1.7147	1.8671
9	1.6194						
10	2.0957						
11	2.191						
12	2.191						
13	2.21						
14	2.1338						
15	2.1719		.1715	.1593	.1509	.1635	.1692
16	2.1719		.16	.1383	.1646	.1886	.1698
17	.176	.192	.1635	.2027	.21	.2202	
18	.1949	.2538	.2058	.2317	.2389	.2679	.1713
19	.3041	.3102	.2766	.2751	.2824	.2721	.2515
20	.3475	.3018	.333	.3258	.362	.3384	.3492
21	.3185	.2515	.2743	.2881	.3185	2.8197	.2961
22	.2824	.2467	.2679	.2401	.2896	.2538	.1698
23	1.105	1.4289	1.2384	1.105	1.0479	1.5242	1.2003
24	.2317	1.0669	1.3717	1.3336	1.0669	1.086	1.4861
Max	2.21	2.1148	1.9433	2.1338	2.0957	2.8197	2.4387
Min	.176	.192	.16	.1383	.1509	.1635	.1692
Avg	1.1231	.9403	.9222	.8962	.8297	.9669	1.0498

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274083 / 33/11 KV AKOLEKATI

Feeder No / Name : 206 / 11kv BB Darphal

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3829	.0381	.0572	.0381	.0381	.4572	.3227
2	.3574	.0381	.0572	.0381	.0381	.4572	.2934
3	.3628						
4	.3628						
5	.4923						
6	.5744						
7	.7514						
8	.7021						
9		.4999	.4862	.5573	.583	.9465	1.1271
10		.5853	.5881	.5521	.6638	1.1174	1.3803
11		.7148	.6638	.6382	.663	1.2308	1.3914
12		.7802		.7021	.6859	1.1488	1.468
13		.6893	.6602	.7404	.7324	1.1142	1.5158
14		.6127	.7183	.7903	.7914	1.1233	1.4297
15	.0381	.5872	.7322	1.1431	.8169	1.1744	1.3146
16	.0381	.5281	.6379	.7404	.8297	1.2765	1.4424
17	.0572	.0381		.0381	.3353	.3353	.4268
18	.0572	.0572	.0381	.0381	.4515	.4115	.5093
19	.0953	.0953	.0762	.0572	.5117	.503	.5498
20	.1143	.1143	.0953	.0953	.5719	.6173	.5268
21	.0762	.0953	.0572	.0953	.5487	.5201	.4904
22	.0572	.0572	.0572	.0762	.5182	.4458	.1823
23	.0381	.0572	.0572	.0381	.503	.3765	.4161
24	.4085	.0381	.0572	.0381	.0381	.4877	.3567
Max	.7514	.7802	.7322	1.1431	.8297	1.2765	1.5158
Min	.0381	.0381	.0381	.0381	.0381	.3353	.1823
Avg	.2759	.3126	.3150	.3565	.5178	.7635	.8413

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274083 / 33/11 KV AKOLEKATI

Feeder No / Name : 207 / 11 KV Narotewadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1276	.2858	.3429	.3048	.3048	.2667	.381
2	.1276	.2858	.3048		.3048	.2286	.3429
3		.2858	.2858	.4001	.3048	.2858	.2858
4		.3429	.3429	.4763	.3048	.381	.5144
5		.5144	.4572	.6287	.381	.4763	.6287
6		.6287	.6287	.8954	.5335	.7621	.7621
7		.5906	.8764	1.0288	.6859	.9335	.9145
8		.5144		.8764	.6097	.8954	.724
9	.3429						.724
10	.4763					.8954	
11	.5144						
12	.5144						
13	.4954						
14	.4954						
15	.5144		.1238	.1021	.0766	.1286	.1808
16	.5144	.1315	.0953	.1021	.0766	.153	.1429
17	.1181	.1734	.2553	.1021	.1021	.1974	.1947
18	.1417	.217	.216	.1276	.1404	.2429	.1532
19	.2008	.2515	.2599	.2298	.1787	.2715	.2126
20	.2601	.2515	.2553	.2553	.2425	.306	.2561
21	.2425	.2298	.2008	.2425	.217	.2553	.2425
22	.217	.2225	.1738	.2298	.1915	.204	.192
23	.3239	.4001	.362	.3048	.3239	.4191	.4191
24	.1276	.3048	.381	.4001	.3429	.2858	.4001
Max	.5144	.6287	.8764	1.0288	.6859	.9335	.9145
Min	.1181	.1315	.0953	.1021	.0766	.1286	.1429
Avg	.3197	.3312	.3272	.3945	.2956	.3994	.4038



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274083 / 33/11 KV AKOLEKATI

Feeder No / Name : 208 / 11KV SAWITRIBAI FULE EXP NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.08	.0572	.0953	.0857	.0876	.0572	.0572
2	.0838	.0572	.0953	.0934	.0857	.0572	.0572
3	.0724	.0572	.0762	.0743	.0857	.0572	.0572
4	.0667	.0572	.0762	.08	.08	.0572	.0572
5	.0667	.0572	.0762	.0781	.08	.0572	.0572
6	.0667	.0572	.0762	.0857	.0857	.0572	.0572
7	.0934	.0762	.0762	.0914	.0857	.0572	.0572
8	.1067	.0953	.0953	.1029	.0838	.0572	.0762
9	.1067	.0953	.0953	.1143	.0953	.0572	.0762
10	.1143	.0953	.1181	.1238	.0953	.0953	.0953
11	.1143	.1334	.1296	.1181	.0762	.0953	.1029
12	.1143	.1334	.1353	.1105	.0762	.0762	
13	.1143	.1334	.1315	.1105	.0762	.0762	1.0235
14	.1143	.1334	.1334	.1086	.0762	.0762	.9659
15	.1143	.1334	.1391	.1067	.0762	.0572	.1124
16	.1143	.1143	.1467	.1334	.0572	.0381	.1029
17	.1143	.1143	.1296	.1181	.0572	.0572	.0914
18	.0953	.0762	.0972	.0953	.0572	.0572	.0705
19	.0762	.0762	.1029	.0191	.0572	.0572	.0762
20	.0762	.0762	.1067	.0972	.0762	.0572	.0895
21	.0762	.0953	.0953	.0991	.0572	.0572	.0838
22	.0762	.0953	.101	.101	.0572	.0572	.0876
23	.0572	.0953	.0762	.0914	.0572	.0572	.0724
24	.0724	.0572	.0953	.0762	.0914	.0572	.0572
Max	.1143	.1334	.1467	.1334	.0953	.0953	1.0235
Min	.0572	.0572	.0762	.0191	.0572	.0381	.0572
Avg	.0911	.0905	.1042	.0965	.0756	.0620	.1558

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274089 / 33/11 KV WADALA

Feeder No / Name : 201 / 11 KV PADASALI Ag.  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.086	.1905	.1905	.1905	.1905	.1905	.1905
2	1.0867	.1905	.1905	.1905	.1905	.1905	.1905
3	1.1946	.1905	.1905	.1905	.1905	.1905	.1905
4	1.1218	.1905	.2286	.1905	.1905	.2286	.1905
5	1.2308	.1905	.2667	.1905	.1905	.2667	.1905
6	1.4582						
7	3.0769						
8	3.2579						
9		2.878	2.2939	2.0885	2.34	2.4348	1.829
10		2.774	2.6246	1.9113	2.5149	2.7435	2.1262
11		2.7435	2.7206	2.2611	2.8147	3.0864	2.2611
12		2.7435	2.7435	2.5587	2.8807	3.0514	2.3061
13		2.5149	2.6871	2.5911	2.8395	2.6825	2.3663
14		2.4272	2.7183	2.4863	2.915	2.6825	2.7801
15		2.572	2.982	2.5232	2.9647	2.7808	2.7343
16		2.5312	2.5888	2.5263	3.0178	2.7854	2.8121
19	.1524	.2667	.1524	.1524	.3048	.1524	.1143
20	.1905	.3048	.2286	.1905	.3429	.1524	.1524
21	.1905	.2286	.2286	.1905	.2667	.1524	.1524
22	.2286	.1905	.1905	.1905	.1905	.1905	.1905
23	.1143	.1905	.1905	.1905	.1905	.1905	.1905
24	1.0852	.1905	.1905	.1905	.1905	.1905	.1905
Max	3.2579	2.878	2.982	2.5911	3.0178	3.0864	2.8121
Min	.1143	.1905	.1524	.1524	.1905	.1524	.1143
Avg	1.1053	1.2373	1.2425	1.1055	1.3014	1.2812	1.1136

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274089 / 33/11 KV WADALA

Feeder No / Name : 204 / 11KV Gaothan Wadala  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.086	1.1584	.9015	1.0277	1.2437	.9259	.9221
2	1.2308	1.153	.9465	1.3032	1.2757	.9709	.9116
3	1.4266	1.3321	.9945	1.4419	1.3717	1.0174	1.3927
4	1.448	1.5565	1.2346	1.5432	1.5402	1.1904	1.5089
5	1.4582	1.4842	1.5089	1.5775	1.5432	1.3763	1.5565
10	.9114	.7282	.9465	.9465	1.0631	.9012	1.0242
11	.8413	.6859	.815	.7973	.8842	.8383	.6859
12	.7796	.7011	.6733	.7087	.823	.7888	.695
13	.6556	.6935	.6733	.6447	.8063	.7377	.631
14	.6379	.6241	.6447	.591	.6626	.7461	.6935
15	.5731	.6588	.6379	.6379	.6588	.6882	.6024
16	.6268	.6661	.7265	.6485	.6661	.6554	.631
17	.7087	.7282	.8413	.7545	.7011	.6706	.7545
18	.7973	.9036	1.0387	.823	.8413	.9326	.631
19	1.0136	1.0867	1.4266	1.166	1.0745	1.2003	.9922
20	1.0852	1.4232	1.5074	1.382	1.4232	1.4737	1.1218
21	1.4118	1.2136	1.4175	1.3748	1.2483	1.2136	1.166
22	1.1584	1.0576	1.39	1.0608	1.0513	1.1218	1.3176
23	1.086	1.0056	.8573	1.0517	.9945	.9431	1.0631
24	1.406	1.0136	.9114	.8764	.9709	.9465	.9431
Max	1.4582	1.5565	1.5089	1.5775	1.5432	1.4737	1.5565
Min	.5731	.6241	.6379	.591	.6588	.6554	.6024
Avg	1.0171	.9937	1.0047	1.0179	1.0422	.9669	.9622

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274089 / 33/11 KV WADALA

Feeder No / Name : 205 / 11KV Shelgaon AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0517		.0381	.0762	.0762	.0381	.0762
2	1.1584	.1524	.0381	.0762	.0762	.0381	.0762
3	1.1946	.0762		.0762	.0762	.0381	.0762
4	1.3756	.0762		.0762	.0762	.0381	.0762
5	1.4022	.0762	.0381	.0762	.0762	.0381	.0762
6	2.1719						
7	2.8959						
8	2.7435						
9		2.1033		1.262	2.2325	2.0885	1.989
10		2.3579		1.6118	2.2291	2.6216	1.7147
11		2.332		1.7101	2.3908	2.6825	2.7343
12		2.3838		1.7436	2.4006	2.5819	2.4006
13		2.2539		1.9989	2.4348	2.4577	2.0805
14		2.1434		1.7101	2.5434	2.4577	2.572
15	1.0631	2.191		1.8442	2.5377	2.4577	2.572
16				2.0454	2.7343	2.5232	2.5941
17						.0762	
19	.1143	.0381	.0762	.0762	.0381	.0762	.1143
20	.0762	.0381	.0762	.0762	.0381	.0762	.1143
21	.0762	.0381	.0762	.0762	.0381	.0762	.1143
22	.0762	.0381	.0762	.0762		.0762	.1143
23	.0762	.0381	.0762	.0762	.0381	.0762	.1143
24	2.577	.0762	.0381	.0762	.0762	.0381	.0762
Max	2.8959	2.3838	.0762	2.0454	2.7343	2.6825	2.7343
Min	.0762	.0381	.0381	.0762	.0381	.0381	.0762
Avg	1.2035	.9655	.0593	.7771	1.1174	1.0278	1.0361

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274089 / 33/11 KV WADALA

Feeder No / Name : 206 / 11KV Nannaj Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	1.448	1.3717	1.086	1.1218	1.3717	1.3717
2	.1524	1.4998	1.4373	1.073	1.1317	1.4373	1.387
3	.1524	1.3565	1.4563	1.1568	1.0852	1.387	1.3717
4	.1524	1.4118	1.4575	1.2269	1.153	1.4403	1.4251
5	.1524	1.3575	1.5089	1.3077	1.3032	1.5089	1.5089
6		1.3756	1.6617	1.4419	1.7364	1.9547	2.4577
7		2.0805	2.7999	1.9662	2.2085	2.7515	2.5396
8		2.2786	2.6406		2.9264	2.915	2.3758
9	1.5089		1.6095				
10	2.1795		2.3266				
11	2.1956		2.3266				
12	2.2283		2.3967				
13	2.3594		2.3922				
14	2.4249						
15	2.13		2.1879	.0762		.0762	.0762
16	2.2939		2.0119	.1143		.0762	.1143
17	.0762		.0762	.1143	.1143	.0762	.0953
18	.0762		.0762	.1143	.1524	.0762	.1143
19	.0762	.1524	.1143	.1524	.1905	.1524	.0762
20	.0762	.1905	.1524	.1524	.1905	.1524	.0762
21	.0762	.1524	.1524	.1524	.1905	.1524	.0762
22	.0762	.1524	.1143	.1524	.1524	.1524	
23	1.5203	1.4022	1.3717	1.5947	1.3375	1.3032	1.166
24	1.2689	1.5203	1.4217	1.2894	1.3717	1.3523	1.3032
Max	2.4249	2.2786	2.7999	1.9662	2.9264	2.915	2.5396
Min	.0762	.1524	.0762	.0762	.1143	.0762	.0762
Avg	1.0157	1.1699	1.4376	.7748	1.0229	1.0187	1.0315

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274089 / 33/11 KV WADALA

Feeder No / Name : 207 / 11KV LokmangalR&D Exp NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9					.0191	.0381
10		.0191		.0191	.0381	.0381
11	.0191	.0191		.0191	.0381	.0381
12	.0191	.0381		.0191	.0381	.0381
13		.0381		.0191	.0381	.0381
14		.0381		.0191	.0381	.0381
15		.0381	.0191	.0191	.0381	.0381
16	.0191		.0191		.0572	.0381
17	.0191		.0191		.0572	.0191
18					.0381	
Max	.0191	.0381	.0191	.0191	.0572	.0381
Min	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0318	.0191	.0191	.0400	.0360

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274135 / 33/11 KV DONGAON

Feeder No / Name : 201 / 11 KV DONGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17
HR	Load (MW)	Load (MW)
19		.2286
24	1.4998	
<b>Max</b>	<b>1.4998</b>	<b>.2286</b>
<b>Min</b>	<b>1.4998</b>	<b>.2286</b>
<b>Avg</b>	<b>1.4998</b>	<b>.2286</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274135 / 33/11 KV DONGAON

Feeder No / Name : 202 / 11 KV KAWATHE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17
HR	Load (MW)	Load (MW)
19		.0762
24	1.4918	
<b>Max</b>	<b>1.4918</b>	<b>.0762</b>
<b>Min</b>	<b>1.4918</b>	<b>.0762</b>
<b>Avg</b>	<b>1.4918</b>	<b>.0762</b>



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274135 / 33/11 KV DONGAON

Feeder No / Name : 203 / 11 KV DONGAON GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-AUG-17	02-AUG-17
HR	Load (MW)	Load (MW)
19		.679
24	.8059	
<b>Max</b>	<b>.8059</b>	<b>.679</b>
<b>Min</b>	<b>.8059</b>	<b>.679</b>
<b>Avg</b>	<b>.8059</b>	<b>.679</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274135 / 33/11 KV DONGAON

Feeder No / Name : 204 / 11 KV NANDUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17
HR	Load (MW)	Load (MW)
19		.3018
24	.0686	
Max	.0686	.3018
Min	.0686	.3018
Avg	.0686	.3018

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274135 / 33/11 KV DONGAON

Feeder No / Name : 205 / 11 KV SOREGAON GFSS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17
HR	Load (MW)	Load (MW)
19		.7421
24	.2058	
<b>Max</b>	<b>.2058</b>	<b>.7421</b>
<b>Min</b>	<b>.2058</b>	<b>.7421</b>
<b>Avg</b>	<b>.2058</b>	<b>.7421</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274135 / 33/11 KV DONGAON

Feeder No / Name : 206 / 11 KV PATHRI

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-AUG-17	02-AUG-17
HR	Load (MW)	Load (MW)
19		.1698
24	.703	
<b>Max</b>	<b>.703</b>	<b>.1698</b>
<b>Min</b>	<b>.703</b>	<b>.1698</b>
<b>Avg</b>	<b>.703</b>	<b>.1698</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274168 / 33/11 KV MIDC C. KATI - 2

Feeder No / Name : 201 / 11KV Rama

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0377	.0377	.0343	.0514	.0377	.0343
2	.0343	.0377	.0377	.0343	.0343	.0566	.0171
3	.0343	.0377	.0377	.0343	.0343	.037	.0171
4	.0343	.0377	.0377	.0343	.0343	.056	.0171
5	.0343	.0377	.0377	.0343	.0343	.0373	.0171
6	.0343	.0377	.0377	.0343	.0343	.056	.0171
7	.0343	.0377	.0377	.0171	.0343	.0377	.0171
8	.0343	.0566	.0377	.0514	.0343	.0924	.0171
9	.0343	.0566	.12	.0514	.1029	.1109	.0514
10	.0754	.0566	.1372	.0943	.1478	.0857	.0566
11	.0754	.0566	.1543	.132	.1494	.0857	.1132
12	.0754	.0554	.1372	.1698	.1478	.0857	.0943
13	.0754	.0566	.0686	.1509	.1294	.0857	.0754
14	.0754	.0747	.1029	.1132	.1867	.0857	.0754
15	.0754	.0739	.12	.1132	.112	.0857	.0754
16	.0566	.0377	.12	.1132	.0943	.0686	.0739
17	.0566	.0566	.12	.1132	.1109	.0686	.056
18	.0377	.0554	.12	.0943	.0747	.0686	.056
19	.0377	.0377	.1029	.0754	.0566	.0686	.0377
20	.0377	.056	.1029	.0566	.0754	.0686	.056
21	.0377	.0377	.0686	.0377	.0566	.0343	.056
22	.0377	.0377	.0686	.0377	.0566	.0343	.0377
23	.0377	.0377	.0343	.0566	.0377	.0343	.0566
24	.0343	.0377	.0377	.0343	.0514	.0377	.0343
Max	.0754	.0747	.1543	.1698	.1867	.1109	.1132
Min	.0343	.0377	.0343	.0171	.0343	.0343	.0171
Avg	.0473	.0477	.0799	.0716	.0784	.0633	.0483

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274168 / 33/11 KV MIDC C. KATI - 2

Feeder No / Name : 202 / 11KV Bhutada

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.8676	.8501	1.1317	.7716	.924	1.1145
2	.9431	.8676	.7842	1.1317	.7716	1.0349	1.1145
3	.9431	.8676	.8589	1.0288	.7373	.961	1.0288
4	.8916	.8676	.8402	1.0288	.7373	1.0059	1.0288
5	.8916	.8676	.8501	.9431	.7716	.9145	.9945
6	.8573	.8676	.7947	.8573	.7716	.8686	.9945
7	.7545	.8676	.8501	.7716	.8402	.9425	.8916
8	.7716	.9431	.9922	.7888	.8402	1.1706	.9774
9	.823	.9808	1.1317	.8916	.8402	1.0719	1.0631
10	1.226		1.3032	1.1317	1.2437	1.2346	1.3769
11	1.4712		1.5261	.811	1.2382	1.406	1.5655
12	1.358		1.5089	1.5655	1.4352	1.3375	1.6032
13	1.1317		1.2174	1.5466	1.3432	1.166	1.5655
14	1.0751		1.3032	1.5466	1.4148	1.2003	1.7541
15	1.226		1.2346	1.5655	1.4373	1.2003	1.6032
16	1.3203		1.2346	1.5655	1.4706	1.2003	1.387
17	1.3769		1.2689	1.4146	1.595	1.166	1.2178
18	1.226		1.2689	1.3203	1.3756	1.166	1.1157
19	1.0751	.7023	1.2003	1.226	1.3432	1.166	1.0745
20	.9808	.7762	1.2003	1.226	1.267	1.166	1.2012
21	.9808	.8686	1.0631	1.1317	1.1643	1.0288	1.134
22	.9431	.9055	1.0974	1.1317	.961	1.0802	1.1523
23	.8676	.8501	1.0974	.9619	1.0974	1.1145	1.1088
24	.9602	.8676	.8131	1.1317	.8573	.9795	1.1145
Max	1.4712	.9808	1.5261	1.5655	1.595	1.406	1.7541
Min	.7545	.7023	.7842	.7716	.7373	.8686	.8916
Avg	1.0432	.8645	1.0954	1.1604	1.0969	1.1044	1.2159

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274168 / 33/11 KV MIDC C. KATI - 2

Feeder No / Name : 205 / 11KV LDK

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9259	.7545	.7207	1.1317	1.0288	1.0534	.9431
2	.8573	.7545	.6908	1.1317	.9774	.961	.9431
3	.8573	.7545	.7392	1.0631	.9774	1.0719	.8573
4	.7716	.7545	.6653	1.0288	.9774	.9425	.8573
5	.7716	.7167	.7655	.9431	.9945	.8501	.7716
6	.6859	.7167	.6722	.9431	.9945	.8686	.6859
7	.5658	.7167	.6348	.7716	.9945	.8316	.6001
8	.6001	.6602	.6348	.7888	.9945	1.0164	.6344
9	.6173	.6602	.8745	.8573	1.0802	1.1827	.6859
10	.9054	.7207	.9431	1.4712	1.439	1.2003	1.1317
11	1.2826	.8029	1.166	1.5655	1.4074	1.2346	1.1317
12	1.226	.7947	1.2003	1.6409	1.3611	1.2003	1.1506
13	1.1883	.7577	1.2517	1.6032	1.2536	1.0802	1.0751
14	1.1883	.8402	1.2517	1.5278	1.3352	1.1145	1.3014
15	1.226	.8686	1.2689	1.5655	1.4175	1.166	1.226
16	1.226	.7577	1.3203	1.5655	1.4723	1.166	1.1999
17	1.2637	.7842	1.3203	1.4146	1.4352	1.2003	1.0985
18	1.226	.8686	1.3203	1.358	1.3352	1.1145	1.134
19	1.1694	.7762	1.286	1.2826	1.4327	.9945	1.1088
20	1.1317	.9055	1.2003	1.226	1.4148	.9259	1.1403
21	1.1694	.7842	1.166	1.1317	1.2986	.9431	1.1827
22	.9431	.8048	1.1831	1.1317	1.3306	.9774	1.134
23	.8299	.8402	1.1831	1.1317	1.0829	.9945	1.0349
24	.9259	.8299	.7577	1.166	1.0288	1.1088	.9945
Max	1.2826	.9055	1.3203	1.6409	1.4723	1.2346	1.3014
Min	.5658	.6602	.6348	.7716	.9774	.8316	.6001
Avg	.9814	.7760	1.0090	1.2267	1.2110	1.0500	1.0010

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274168 / 33/11 KV MIDC C. KATI - 2

Feeder No / Name : 206 / 11KV V.Datta

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5658	.4715	.5658	.5487	.6348	.6516
2	.5487	.5658	.4435	.5658	.5487	.5914	.6516
3	.5144	.5658	.4805	.5144	.5316	.5544	.6173
4	.5144	.4904	.4435	.5144	.5144	.5544	.6173
5	.463	.4527	.4435	.4801	.5144	.4854	.5144
6	.463	.4527	.4854	.4801	.9945	.5228	.4801
7	.4458		.4527	.463	.4801	.462	.4458
8	.463	.4715	.462	.5144	.4801	.4755	.4801
9	.5144	.5093	.5144	.5487	.6001	.6653	.5144
10	.6036	.5093	.5487	.7545	.6468	.6516	.6979
11	.6413	.5093	.5316	.9054	.695	.6859	.6413
12	.6413	.462	.5316	.6979	.7023	.6859	.679
13	.5847	.4904	.5316	.8299	.7087	.583	.7167
14	.5847	.4527	.5316	.9054	.7207	.6173	.6413
15	.6036	.4481	.5316	.7922	.6099	.6516	.7545
16	.6602	.4904	.583	.7733	.7442	.6516	.5601
17	.6602	.4715	.583	.7545	.7442	.6516	.5729
18	.679	.5093	.583	.679	.7762	.6516	.4854
19	.679	.4755	.5658	.6036	.7023	.6516	.4854
20	.6036	.4854	.5487	.5658	.6468	.6859	.5093
21	.6036	.4668	.5487	.5281	.6653	.6516	.5601
22	.6036	.4904	.5658	.4904	.5601	.6687	.5788
23	.5847	.4904	.5658	.6602	.5093	.6687	.5914
24	.5487	.5847	.4527	.5658	.5487	.5373	.6859
Max	.679	.5847	.583	.9054	.9945	.6859	.7545
Min	.4458	.4481	.4435	.463	.4801	.462	.4458
Avg	.5732	.4961	.5167	.6314	.6330	.6100	.5889



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274168 / 33/11 KV MIDC C. KATI - 2

Feeder No / Name : 207 / 11KV Venky Express NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8916	1.1317	.961	1.2003	1.1145	.961	1.0631
2	.8916	1.1317	.9979	1.166	1.1145	1.0534	1.0631
3	.8573	.9808	.9522	1.166	1.1145	.9511	1.0288
4	.8573	.9808	.8775	1.1317	1.1145	.9425	1.0288
5	.7716	.9242	.924	1.1317	1.1145	1.0349	.9945
6	.7716	.9242	.8029	1.0288	1.1145	1.1088	.9945
7	.6859	.9242	.8501	.9945	1.0974	1.134	.9431
8	.7202	.9054	.7577	1.0288	1.0974	1.2012	.9774
9	.7545	.9054	.823	1.0631	1.2003	1.3032	1.0288
10	1.0374	.8779	1.0802	1.3203	1.2437	1.2346	1.3203
11	1.226	.924	.9431	1.3392	1.3717	1.2346	1.3203
12	1.226	.961	1.0631	1.358	1.2851	1.2346	1.3392
13	1.1694	.924	1.1488	1.3203	1.1458	1.1488	1.358
14	1.1694	1.0059	1.1488	1.3014	1.1827	1.1145	1.2637
15	1.226		1.2003	1.226		1.166	1.1317
16	1.3014	.9795	1.3203	1.1506	.0377	1.2003	1.1523
17	1.3014	.9922	1.3203	1.1506	.415	1.2003	1.2012
18	1.2637	1.0164	1.3203	1.1506	.2829	1.1145	1.1088
19	1.2637	1.0242	1.2346	1.1506	.2829	.8573	1.1458
20	1.226	.961	1.166	1.226	.3395	.823	1.1088
21	1.226	1.0349	1.1488	1.3014	.3206	.9431	1.2178
22	1.1694	1.0349	1.166	1.3014	1.0974	1.1317	1.1523
23	1.1506	1.0059	1.2003	1.2071	1.0719	1.1317	.9511
24	.8916	1.1506	1.0164	1.2003	1.1145	1.0242	1.0974
Max	1.3014	1.1506	1.3203	1.358	1.3717	1.3032	1.358
Min	.6859	.8779	.7577	.9945	.0377	.823	.9431
Avg	1.0437	.9870	1.0593	1.1923	.9249	1.0937	1.1246

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274168 / 33/11 KV MIDC C. KATI - 2

Feeder No / Name : 401 / 33KV KOTHARI PRIMA NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0566		.1029	.1029	.1663	.1029
2	.0514	.0566		.1029	.1029	.1663	.1029
3	.0514	.0566		.1029	.1029	.168	.1029
4	.0514	.0566		.1029	.1029	.2218	.1029
5	.0514	.0566		.1029	.1029	.2241	.1029
6	.0514		.0566	.1029	.1029	.1663	.1029
7	.0514		.1132	.0514	.1029	.2218	.1029
8	.0514		.0566	.0514	.0514	.1663	.1543
9	.0514		.1543	.0514	.1543		.2058
10	.0566	.4572	.1543	.1132	.2241	.2058	
11	.0566		.1029	.1698	.2195	.2572	
12	.0566		.1029	.1698	.2149	.2058	
13	.0566		.1029	.1698	.2218	.1543	
14	.0566		.1029	.1698	.2218	.1543	
15	.0566		.1029	.1698	.2218	.1029	
16	.0566		.0514	.1132	.168	.1029	.2218
17	.0566		.0514	.1698	.2241	.1029	.1663
18	.0566		.0514	.2263	.2218	.1543	.2218
19	.0566		.0514	.2263	.2218	.1543	.168
20	.0566		.0514	.1698	.168	.2058	.1663
21	.0566		.0514	.1132	.2241	.1543	.1663
22	.0566		.0514	.1132	.1132	.1543	.168
23	.0566		.0514	.1132	.1663	.1029	.056
24	.0514	.0566		.0514	.1029	.2218	.1029
Max	.0566	.4572	.1543	.2263	.2241	.2572	.2218
Min	.0514	.0566	.0514	.0514	.0514	.1029	.056
Avg	.0544	.1138	.0812	.1263	.1608	.1711	.1399

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274183 / 33/11 KV VASANT VIHAR

Feeder No / Name : 201 / 11KV Vasant Vihar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2896	.3077	.3077	.2896	.3258	.362	.3258
2	.2896	.2896	.2896	.2896	.2896	.3439	.3077
3	.2896	.2896	.2715	.2715	.2715	.3258	.3077
4	.2896	.2896	.2715	.2715	.2715	.3077	.2896
5	.2896	.2896	.2534	.2715	.2715	.2896	.2896
6	.2896	.3258	.2715	.2534	.2715	.2715	.2715
7	.2896	.3258	.2896	.2715	.3258	.2715	.3077
8	.2715	.3077	.2715		.3077	.2715	.3077
9	.2896	.3258	.2715	.2715	.2534	.2715	.3258
10	.2534	.3077	.2715	.2534	.2715	.2715	.2896
11	.2534	.2715	.2353	.2534	.2353	.2534	.2715
12	.2353	.2534	.2353	.3077	.2534	.3258	.2353
13	.2534	.2172	.2172	.2715	.2534	.2534	.2172
14	.2172		.2172	.2715	.2353	.2896	.2534
15	.2353		.1991	.2715	.2896	.2896	.2172
16	.2172	.2715	.2534	.2896	.2715	.2896	.2303
17	.2353	.2353	.2172	.2715	.2534	.2896	.2715
18	.2534	.2353	.2172	.2353	.2534	.3077	.2534
19	.3077	.2896	.3258	.2534	.2896	.3258	.2896
20	.362	.362	.3439	.362	.3801	.3801	.362
21	.3801	.3258	.3439	.3801	.3982	.362	.362
22	.3801	.3439	.3801	.3982	.3982	.362	.3982
23	.362	.3439	.3439	.3982	.362	.362	.3801
24	.2896	.3258	.3258	.3077	.3439	.362	.3258
Max	.3801	.362	.3801	.3982	.3982	.3801	.3982
Min	.2172	.2172	.1991	.2353	.2353	.2534	.2172
Avg	.2843	.2970	.2760	.2920	.2949	.3100	.2954

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274183 / 33/11 KV VASANT VIHAR

Feeder No / Name : 202 / 11KV BHOGAON

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3937	1.4299	1.3756	1.3937	1.4661	1.4842	1.4661
2	1.3937	1.2851	1.3937	1.3394	1.3937	1.3937	1.4842
3	1.3394	1.2851	1.4118	1.3575	1.4118	1.3575	1.4842
4	1.3937	1.3937	1.3575	1.4118	1.4118	1.4299	1.6108
5	1.6651	1.5565	1.4842	1.4661	1.5203	1.6108	1.7737
6	1.9366	1.9547	1.7918	1.7556	1.9004	1.7918	2.009
7	1.828	1.9547	1.828	1.9547	1.6832	1.7918	2.0271
8	1.6832	1.7556	1.7375		1.647	1.8461	1.7556
9	1.5565	1.6832	1.5203	1.4118	1.5384	1.6832	1.5746
10	1.5384	1.5384	1.5203	1.4299	1.5203	1.5203	1.5023
11	1.4299	1.4661	1.6108	1.4299	1.3394	1.5384	1.4661
12	1.5023	1.5384	1.2851	1.3756	1.4299	1.5203	1.3937
13	1.3756	1.4118	1.3032	1.5746	1.5384	1.5927	1.4118
14	1.4661		1.3575	1.3575	1.6108	1.5023	1.4299
15	1.5565		1.3756	1.3575	1.5023	1.5023	1.4661
16	1.5746	1.4661	1.2127	1.3937	1.4661	1.5023	1.448
17	1.6108	1.6108	1.5203	1.4661	1.5927	1.3937	1.4118
18	1.647	1.6108	1.4661	1.5023	1.5927	1.5927	1.4299
19	1.647	1.7737	1.5203	1.7013	1.7194	1.6289	1.2308
20	2.0995	1.9185	1.8823	1.9185	1.9547	1.7918	1.647
21	1.8461	1.8461	1.7737	1.8461	1.8823	1.8099	1.7013
22	1.7918	1.7737	1.7375	1.828	1.7737	1.7556	1.7194
23	1.647	1.5565	1.5565	1.6108	1.7013	1.5927	1.5746
24	1.3937	1.4661	1.4661	1.4299	1.5023	1.5384	1.4661
Max	2.0995	1.9547	1.8823	1.9547	1.9547	1.8461	2.0271
Min	1.3394	1.2851	1.2127	1.3394	1.3394	1.3575	1.2308
Avg	1.5965	1.6034	1.5204	1.5353	1.5875	1.5905	1.5618

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274203 / 33/11 KV BIBI DARPHAL

Feeder No / Name : 201 / 11KV RANMASALE AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.8059
Max	.8059
Min	.8059
Avg	.8059

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274203 / 33/11 KV BIBI DARPHAL

Feeder No / Name : 202 / 11KV BIBIDARFAL SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	1.2689
Max	1.2689
Min	1.2689
Avg	1.2689

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274203 / 33/11 KV BIBI DARPHAL

Feeder No / Name : 203 / 11 KV RANMASALE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	1.2689
Max	1.2689
Min	1.2689
Avg	1.2689

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274215 / 33/11 KV KALMAN

Feeder No / Name : 201 / 11KV BHAGAIWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.3734	.3361	.2241	.2667	.2096	.3361
2	.2667	.3734	.3361	.1867	.2667	.2286	.3921
3	.3048	.4481	.2241	.1867	.3048	.2667	.4108
4	.4001	.4108	.5228	.2614	.4001	.3429	.4481
5	.5144	.4481	.4481	.4854	.5335	.4954	.4481
10	.2614	.1494	.2987	.2477	.2096		.2667
11	.1307	.2241	.2241	.1715	.1524		.2286
12	.1307	.2241	.1867	.1524	.1524		.1715
13	.1307	.112	.168	.1524	.1524		.1715
14		.1307	.168	.1334	.1334		.1524
15	.1307	.1494	.168	.1334	.1334		.1715
16	.1307	.1867	.1867	.1334	.1715		.1905
17	.1307	.1867	.2241	.1715	.1905		.2286
18	.1494		.3361		.2286		.2667
19	.168	.2241	.4481	.2858	.4954		.3048
20	.2987	.2614	.3921	.4763	.5144		.4572
21	.3361	.2427	.3361	.362	.381		.3429
22	.2987	.3361	.2987	.2858	.3048		.2667
23	.3361	.4108	.2427	.2667	.2858		.2667
24	.2667	.3547	.3361	.2241	.2667	.2286	.3361
Max	.5144	.4481	.5228	.4854	.5335	.4954	.4572
Min	.1307	.112	.168	.1334	.1334	.2096	.1524
Avg	.2448	.2761	.2941	.2390	.2772	.2953	.2929



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274215 / 33/11 KV KALMAN

Feeder No / Name : 202 / 11KV SAKHAREWADI AG  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1622						
2	1.1622						
3	1.2193						
4	1.3146						
5	1.4861						
6	2.0576						
7	1.6604						
8	1.6129						
9		.7907	1.0437	.5693	1.6004		1.5623
10		.8381	1.1702	1.0098	1.6385	1.2334	1.8099
11		1.0753	1.4232	1.1622	1.7909		1.9433
12		.9804	1.7394	1.2765	1.3336	1.3283	2.0767
13		.8697	1.6129	1.5623	1.7147	1.9605	2.1338
14		.8065	1.2809	1.6385	1.8671	1.8343	1.9052
15		.759	1.4706	1.5813	1.8099	1.7394	2.0957
16		.6009	1.1227	1.5813	1.7147	2.0241	2.21
24	1.2574						
Max	2.0576	1.0753	1.7394	1.6385	1.8671	2.0241	2.21
Min	1.1622	.6009	1.0437	.5693	1.3336	1.2334	1.5623
Avg	1.4370	.8401	1.3580	1.2977	1.6837	1.6867	1.9671

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274215 / 33/11 KV KALMAN

Feeder No / Name : 203 / 11KV KAUTHALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.427	.7116	.4744	.4763	.6097	8.9407
2			.7907	.6958	.5335	.5716	.8697
3		.5376	.759	.6958	.6097	.6668	.9172
4		.5535	.6325	.7274	.7621	.7621	.9804
5		.5535	.7116	.5376	.8954	.8002	.9488
6		.5693	.6642	.6167	1.4289	1.3336	.9488
7		.6009	1.0437	1.0437	1.448	1.7528	1.0279
8		.5535	1.0437	.9962	1.3336		1.0753
9	.6483					1.3599	
10	.6325						
11	.8697						
12	1.0911						
13	1.0911						
14	1.1069						
15	1.1227						
16	1.2651						
18					.1524		
23	.3795	.3163	.4111	.4763	.6287	.4586	.6668
24		.4111	.506	.427	.4763	.6859	.8539
Max	1.2651	.6009	1.0437	1.0437	1.448	1.7528	8.9407
Min	.3795	.3163	.4111	.427	.1524	.4586	.6668
Avg	.9119	.5025	.7274	.6691	.7950	.9001	1.7230

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277002 / 132/33/11 KV DEGAON

Feeder No / Name : 203 / 11KV NEHRU NAGAR Ag. SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3765	.0886	.08			.0934	.0953
2	1.3765	.0886	.081			.0934	.0953
3	1.3765	.0876	.081			.0934	.0953
4	1.2803	.0876	.081			.0905	.0953
5	1.3765	.0876	.0829			.0905	.0953
6	1.7204	.1772	.0829			.0905	.0953
7	2.0119	.0895	.081			.0905	.0953
8		.0895				.0886	.0953
9	.0895	1.5565		1.7204	1.9204	2.0119	1.7394
10	.08	2.0719		2.1548	2.3205		2.3758
11	.0867	2.1052	1.6804	2.3205	2.5606	2.3472	2.4577
12	.0895	2.1052	2.5101	2.4291	2.6216		2.4291
13			2.5911	1.9433	2.2405	2.4006	2.3758
14	.0867	2.4034	2.672	2.4291	2.7035	2.4006	1.7204
15	.0943	.7811	2.4006	2.4291		2.672	1.6404
16	.0848	.8907	.8192	2.2672	2.5396	2.5606	1.6204
17		.0953	.0953	.0953	.0924	.0953	.06
18		.0953	.0953	.0953	.0924		.0695
19		.0953	.0953	.0953	.0924		.0762
20		.0953	.0953	.0953	.0924	.0953	.0734
21		.0953	.0953	.0953	.0924	.0953	.0772
22						.0953	.0753
23						.0953	.0734
24	1.3765	.0886	.08			.0914	.0953
Max	2.0119	2.4034	2.672	2.4291	2.7035	2.672	2.4577
Min	.08	.0876	.08	.0953	.0924	.0886	.06
Avg	.8338	.6322	.7263	1.3977	1.4474	.7846	.7384

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277002 / 132/33/11 KV DEGAON

Feeder No / Name : 204 / 11KV DEGAON-AG-  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	2.5606	2.5777			2.3148	2.7673
2	.0953	2.5301	2.5777			2.2377	2.7673
3	.0953	2.5301	2.5463			2.2377	2.7673
4	.0953	2.5301	2.5463			2.2377	2.7673
5	.0953	2.6406	2.5777			2.3434	2.8807
6	.0953	2.834	2.6882			2.4996	3.0769
7	.0953	3.0407	3.0836			2.7673	3.3198
8		3.2007				2.9254	3.4008
9	3.6437	.0953		.081	.0953	.0953	.0953
10	3.6437	.0953		.0953	.0953	.0953	.0953
11	3.6008	.0953	.0953	.0953		.0953	.0953
12	3.4408	.0953	.0953	.0953	.0953	.0953	.0953
13	3.1626	.0953	.0953	.0953	.0953	.0953	.0953
14	3.1626		.0953	.0953	.0953	.0953	.0953
15	3.0407		.0953	.0953		.0953	.0953
16	2.9254		.0953	.0953	.0953	.0953	.0953
17		.0953	.0953	.0953		.0953	.0953
18		.0953	.0953	.0953	.0953	.0953	.0953
19		.0953	.0953	.0953	.0953	.0953	.0953
20		.0953	.0953	.0953	.0953	.0953	.0953
21		.0953	.0953	.0953	.0953	.0953	.0953
22						.0953	.0953
23						2.8464	2.8807
24	.2839	2.6406	2.6558			2.5463	2.7673
Max	3.6437	3.2007	3.0836	.0953	.0953	2.9254	3.4008
Min	.0953	.0953	.0953	.081	.0953	.0953	.0953
Avg	1.7232	1.3400	1.1738	.0942	.0953	1.0954	1.2804

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277002 / 132/33/11 KV DEGAON

Feeder No / Name : 207 / 11KV BALE SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	.1372	.1391			.1829	.1658
2	1.2803	.1372	.1391			.1829	.1658
3	1.2803	.1372	.1372			.1829	.1658
4	1.2803	.1429	.1372			.1829	.1658
5	1.3603	.1467	.1372			.1829	.1658
6	1.6194	.1467	.1372			.1791	.1658
7	2.0719	.1296	.1353			.181	.1658
8		.1315				.1848	.1658
9	.1238	1.6385		1.6385	1.6804	1.7604	1.5813
10	.16	1.9062		1.7004	1.7604	2.1862	2.0719
11	.1543	2.1548	2.0243	2.0005	1.4842	2.13	2.0719
12	.1067	2.13	2.1052	2.0243	1.9204		2.0719
13	.1048	2.1052	2.1862	2.0243	1.8623	1.9433	1.8404
14	.1619	2.1548	2.2119	2.0243	2.0243		1.8623
15	.1619	2.1548	2.13	2.13		2.1052	1.9062
16	.1067	2.1548	1.8976	1.9662	1.9433	1.9204	1.9433
17		.1658	.1658	.1658	.0943	.1658	.0943
18		.1658	.0953	.1658	.0943		.0943
19		.1658	.1658	.1658	.1867		.0943
20		.1658	.1658	.1658	.1867	.1658	.1867
21		.1658	.1658	.1658	.1829	.1658	.1829
22					.1848	.1658	.1829
23						.1658	.1791
24	1.2803	.1372	.1391			.1848	.1658
Max	2.0719	2.1548	2.2119	2.13	2.0243	2.1862	2.0719
Min	.1048	.1296	.0953	.1658	.0943	.1658	.0943
Avg	.7833	.8397	.7587	1.2567	1.0465	.7259	.7440

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277002 / 132/33/11 KV DEGAON

Feeder No / Name : 209 / 11KV TIKEKAR WADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0829	.4687	.5401			.463	.6249
2	.0829	.4687	.5401			.463	.6249
3	.0829	.4687	.5335			.463	.6249
4	.0829	.4687	.5335			.463	.6249
5	.0829	.4744	.6249			.463	.7116
6	.0829	.5668	.7116			.6325	.7907
7	.0829	.7116	.7811			.9602	.9602
8		.703				.9488	.9602
9	.703	.0829		.0819	.081	.081	.1658
10	.7811	.0953	.0819	.0953	.081	.0953	.1658
11	.8592	.0953	.0819	.0953	.081	.0953	.1658
12	.8592	.0819	.0953	.0953	.0953	.0953	.1658
13	.9374	.0819	.0953	.0953	.0953	.0953	.0953
14		.0819	.0953	.0953	.0953	.0953	.081
15	.7811	.0819	.0953	.0953	.0953	.0953	.0819
16	.8697	.0953	.0953	.0953	.0953	.0953	.0819
17		.0953	.0953	.0953	.0819	.0953	.0819
18		.0953	.0953	.0953	.0819	.0953	.0819
19		.0953	.0953	.0953	.0819	.0953	.0819
20		.0953	.0953	.0953	.0819	.0953	.0819
21		.0953	.0953	.0953	.0819	.0953	.0819
22					.0819	.0953	.0819
23					.081	.6173	.4687
24	.0829	.4687	.5401			.6097	.6173
Max	.9374	.7116	.7811	.0953	.0953	.9602	.9602
Min	.0829	.0819	.0819	.0819	.081	.081	.081
Avg	.4303	.2715	.2961	.0943	.0861	.3085	.3543

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277002 / 132/33/11 KV DEGAON

Feeder No / Name : 210 / 11KV GAONTHAN DEGAON  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6335	.5316	.6335			.5373	.6535
2	.6335	.5316	.6335			.5373	.6535
3	.6335	.5316	.6335			.5373	.6535
4	.7392	.6268	.6335			.5373	.7468
5	.8402	.7316	.7392			.6335	.8488
6	1.0269	1.0164	1.0269			.924	.9431
7	1.1203	1.0164	1.1203			.924	1.0374
8		.8316				.823	.8402
9	.8316	.7164		.6401	.6268	.724	.724
10					.543	.6335	.6201
11	.5316		.443	.543	.2658	.6201	.5316
12	.5316		.543	.543	.543	.5373	.5316
13	.4525	.543	.543		.6201	.543	.543
14	.4525	.5316	.5373	.543	.6201		.5373
15	.4525		.5316	.543	.6335	.543	.5373
16	.543	.6335	.543	.5373	.5373	.5373	.6335
17		.6468	.6401	.6535	.5373	.5487	.6335
18		.7468	.7392	.7468	.7316	.6535	.5373
19		.9335	.9335	.9431	.924	.8402	.7316
20		1.0269	1.1317	1.0374	1.0269	1.0269	.8316
21		.9335	.9335	.8402	.8316	.8488	.8316
22					.7316	.8402	.7392
23						.7468	.6468
24	.6335	.5373	.6335			.6268	.6535
Max	1.1203	1.0269	1.1317	1.0374	1.0269	1.0269	1.0374
Min	.4525	.5316	.443	.5373	.2658	.5373	.5316
Avg	.6704	.7259	.7144	.6882	.6552	.6836	.6933

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277002 / 132/33/11 KV DEGAON

Feeder No / Name : 213 / 11KV URBAN DEGAON NEW  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2686	.2743			.2686	.2572
2	.2743	.2686	.2743			.2686	.2572
3	.2743	.2686	.2743			.2686	.2572
4	.2743	.2686	.2743			.2686	.2572
5	.2743	.2715	.3696			.2686	.3772
6	.3696	.3658	.3696			.2715	.3772
7	.2743	.2715	.2743			.2715	.2801
8		.2715				.2715	.2801
9	.181	.1791		.2801	.2715	.1791	.1791
10	.2686	.181		.181	.1772	.181	.1772
11	.2658		.181	.1829	.1791	.1772	.1791
12	.181	.181	.2715	.181	.1791	.181	.181
13	.181	.1791	.2715	.1772	.181	.181	.2686
14	.1791	.1772	.2658	.181	.1791	.181	.2658
15	.2686	.1772	.2715	.181	.181	.1772	.2658
16	.2686	.181	.2658	.1772	.181	.1772	.2658
17		.1829	.2715	.1829	.181		.2658
18		.1829	.2743	.2743	.1829		.2686
19		.2801	.2743	.2801	.2743	.2801	.2743
20		.3734	.3734	.3734	.3696	.2801	.3696
21		.3734	.3734	.3734	.2743	.2801	.3696
22					.2743	.2772	.2743
23					.2686	.2743	.2686
24	.2743	.2686	.2743			.2686	.2572
Max	.3696	.3734	.3734	.3734	.3696	.2801	.3772
Min	.1791	.1772	.181	.1772	.1772	.1772	.1772
Avg	.2552	.2463	.2884	.2327	.2236	.2388	.2697



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277002 / 132/33/11 KV DEGAON

Feeder No / Name : 405 / 33KV SIDHANATH MINERALS NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	.2058
Max	.2058
Min	.2058
Avg	.2058

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277002 / 132/33/11 KV DEGAON

Feeder No / Name : 605 / 110 KV Sidhnath Exp.

Feeder KV- 100 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	.0624
Max	.0624
Min	.0624
Avg	.0624

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277024 / 132/33 KV SOREGAON

Feeder No / Name : 401 / 33KV PWW Soregaon  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-AUG-17
HR	Load (MW)
24	1.286
Max	1.286
Min	1.286
Avg	1.286

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277027 / 132/33 KV MIDC C.KATI

Feeder No / Name : 402 / 33KV HT CONSUMER FEEDER SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 33 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17
HR	Load (MW)
24	.1029
Max	.1029
Min	.1029
Avg	.1029

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277027 / 132/33 KV MIDC C.KATI

Feeder No / Name : 403 / 33KV PAKNI Exp.

Feeder KV- 33 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-AUG-17
HR	Load (MW)
24	.6173
Max	.6173
Min	.6173
Avg	.6173

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277027 / 132/33 KV MIDC C.KATI

Feeder No / Name : 404 / 33KV CIMCO Exp.

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	1.286
Max	1.286
Min	1.286
Avg	1.286

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277027 / 132/33 KV MIDC C.KATI

Feeder No / Name : 405 / 33KV PRECISION NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	.1029
Max	.1029
Min	.1029
Avg	.1029

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277027 / 132/33 KV MIDC C.KATI

Feeder No / Name : 406 / 33KV Betul Express NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	.1029
Max	.1029
Min	.1029
Avg	.1029



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277027 / 132/33 KV MIDC C.KATI

Feeder No / Name : 407 / 33KV Lahoti Exp NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	.1029
Max	.1029
Min	.1029
Avg	.1029

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 278005 / 220/132/33 KV BALE

Feeder No / Name : 402 / 33KV Arihant Exp.

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
23	.1029
Max	.1029
Min	.1029
Avg	.1029

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 278005 / 220/132/33 KV BALE

Feeder No / Name : 407 / 33 KV BIO-ENERGY

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	.0514
Max	.0514
Min	.0514
Avg	.0514

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274091 / 33/11 KV ANTROLI

Feeder No / Name : 201 / 11 KV VINCHUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3413	.1905	.1905	.1905	.1905	.1905	.1905
2	1.4327	.1905	.1905	.1905	.1905	.1905	.1905
3	1.4327	.1905	.1905	.1905	.1905	.1905	.1905
4	1.5581	.1905	.1905	.1905	.1905	.1905	.1905
5	1.7556	.1905	.2286	.1905	.1905	.1905	.1905
6	1.848	.1905	.2667	.2286	.1905	.2477	.1905
7	1.8861	.1905	.2858	.2858	.1905	.2286	.1905
8	1.8861	.1905	.2286	.2858	.1905	.1905	.1905
9	.1905	1.3717	1.4003	1.5432	1.4003	1.4937	1.5432
10	.1905	1.6632	1.6804	1.6118	1.587	1.5432	1.7147
11	.1905	1.6632	1.7528	1.7556	1.587	1.7147	1.6651
12	.1905	1.7556	1.7909	1.848	1.6804	1.7147	1.5432
13	.1905	1.7556	1.8099	1.848	1.587	1.7147	1.5775
14	.1905	1.5708	1.8099	1.848	1.587	1.7147	1.5432
15	.1905		1.829	1.848	1.6804	1.7147	1.6289
16	.1905	1.7556	1.7194	1.848	1.587	1.7147	1.6651
17	.1905	.1905	.1905	.1905	.1905	.1905	
18	.1905	.2286	.2286	.1905	.2286	.1905	.1905
19	.1905	.2667	.2858	.1905	.2667	.1905	.2858
20	.1905	.2858	.2858	.1905	.2667	.2858	.2858
21	.1905	.2858	.2858	.1905	.2667	.1905	.1905
22	.1905	.2477	.1905	.1905	.2477	.1905	.1905
23	.1905	.2286	.1905	.1905	.2096	.1905	.1905
24	1.3413	.1905	.1905	.1905	.1905	.1905	.1905
Max	1.8861	1.7556	1.829	1.848	1.6804	1.7147	1.7147
Min	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Avg	.7225	.6515	.7255	.7261	.6703	.6902	.6926

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274091 / 33/11 KV ANTROLI

Feeder No / Name : 202 / 11 KV VADAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	.1905	.1334	.1905	.1905	.1524	.1905
2	1.3717	.1905	.1334	.1905	.1905	.1524	.1905
3	1.5249	.1905	.1334	.1905	.1905	.1524	.1905
4	1.6476	.1905	.1334	.1905	.1905	.1524	.1905
5	1.7528	.1905	.1524	.1905	.1905	.1524	.1905
6	1.97	.1905	.1715	.1905	.1905	.1905	.1905
7	1.9879	.1905	.1715	.2858	.1905	.1905	.1905
8	1.9879	.1905	.1524	.1905	.1905	.1715	
9	.1905	1.5432	1.6804	1.4548	1.5497	2.4272	2.915
10	.1905	1.7556	1.9605	1.4232	1.5432		3.2579
11	.1905	1.9404	1.595	1.4575	1.5339	3.0864	3.3436
12	.1905	1.6632	1.7194	1.5089	1.5339	3.0864	2.452
13			1.701	1.5089	1.4784	3.0864	2.6578
14		1.6078	1.5546	1.5089	1.4415	3.0864	2.6749
15	.1905		1.6095	1.3603	1.4784	2.6578	2.8121
16	.1905	1.6632	1.5912	1.2803	1.386	2.6578	2.9797
17	.1905	.1334		.1905		.1905	
18	.1905	.1524		.1905		.1905	
19	.1905	.1905	.2096	.1905	.2096		
20	.1905	.2286	.3048	.1905	.2286	.1905	.2858
21	.1905	.2286	.2858	.1905	.2286	.1905	.2858
22	.1905	.1905	.2286	.1905	.1905	.1905	.2477
23	.1905	.1524	.1524	.1905	.1905	.1905	.1524
24	.1524	.1905	.1524	.1524	.1905	.1905	.1905
Max	1.9879	1.9404	1.9605	1.5089	1.5497	3.0864	3.3436
Min	.1524	.1334	.1334	.1524	.1905	.1524	.1524
Avg	.7383	.5984	.7239	.6087	.6685	1.0335	1.2794

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274091 / 33/11 KV ANTROLI

Feeder No / Name : 203 / 11 KV KUSUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	2.2291	2.2405	2.1491	2.0729	2.4949	3.8104
2	.5716	2.2291	2.2405	2.1491	2.0729	2.4949	3.4294
3	.6668	2.2291	2.2405	2.1491	2.1548	2.4949	3.4294
4	.6668	2.2291	2.2405	2.1719	2.1548	2.4949	3.4294
5	.6668	2.2291	2.3339	2.1491	2.2552	2.6797	3.4294
6	.724	2.4863	2.4949	2.1719	2.2805	2.8645	
7	.724	2.6578	2.6242	2.1849	2.2805	3.8409	
8	.724	2.2291	2.6981	2.19	2.2805	3.8409	
9	2.7435	.381	.5335	.4477	.3429	.8383	
10	2.8292	.4572	.5906	.4763	.3429		
11	2.8292	.5525	.4763	.4954	.3239		
12	2.572	.5716	.4763	.4954	.3239		1.1431
13	2.572	.5716	.4954	.4954	.3239		1.4289
14	2.572		.5144	.4954	.3239	1.1431	1.6766
15	2.6578		.5144	.4763	.3239	1.3336	1.7528
16	2.572		.5144	.4763	.362	1.3336	1.7147
17	.381		.4572	.4763	.2096	1.3336	
18	.381		.4763	.4763	.2286		
19	.5716		.5144	.381	.3048	1.3336	
20	.5716	.6668	.5525	.3239	.3429	1.1431	1.5242
21	.5716	.724	.4572	.2858	.3429	1.1431	1.4289
22	.5716	.7049	.4191	.2286	.3048	1.1431	1.2765
23	2.1434		2.0576	2.0719	2.4949	3.4294	3.6283
24	.1524	2.2291	2.2405	2.1033	2.0729	2.4949	3.8104
Max	2.8292	2.6578	2.6981	2.19	2.4949	3.8409	3.8104
Min	.1524	.381	.4191	.2286	.2096	.8383	1.1431
Avg	1.3336	1.4928	1.2668	1.1467	1.1050	2.0987	2.4608

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274091 / 33/11 KV ANTROLI

Feeder No / Name : 204 / 11 KV INDIAN PUBLIC SCHOOL SINGLE PHASING  
(IP Feeder KV- 11 / OUTGOING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.5144	.6535	.543	.6001	.7392	.6859
2	.0953	.5144	.6535	.5487	.6001	.7392	.6859
3	.0953	.5144	.6535	.5487	.6201	.7392	.6859
4	.0953	.5144	.6535	.543	.7087	.7392	.6859
5	.0953	.5144	.8402	.543	.8288	.924	.6859
6	.0953	.7716	1.0269	.905	.9945	1.1088	.8573
7	.0953	1.0288	1.4003	1.2803	1.0526	1.2936	1.1145
8	.0953	1.0288	1.2696	1.2197	1.0526	1.386	1.0288
9	.8573	.0953	.0953	.0953	.0953	.0953	.0953
10	.8573	.0953	.0953	.0953	.0953	.0953	.0953
11	.8573	.0953	.0953	.0953	.0953	.0953	.0953
12	.8573	.0953		.0953	.0953	.0953	.0953
13	.8573			.0953	.0953	.0953	.0953
14	.8573	.0953		.0953		.0953	.0953
15	.8573		.0953	.0953		.0953	.0953
16	.8573	.0953	.0953	.0953	.0953	.0953	.0953
17	.0953	.0953	.0953	.0953	.0953	.0953	.0953
18	.0953	.1143	.0953	.0953	.1334	.0953	.0953
19	.0953	.1334	.0953	.1334	.1715	.0953	.0953
20	.0953	.1524	.0953	.1334	.1715	.1905	.1143
21	.0953	.1524	.0953	.1334	.1524	.1905	.0953
22	.0953	.1334	.0953	.0953	.1334	.1905	.0953
23	.4287		.543	.6668	.7316	.6859	.298
24	.2286	.5144	.6535	.543	.6001	.7316	.6859
Max	.8573	1.0288	1.4003	1.2803	1.0526	1.386	1.1145
Min	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Avg	.3687	.3461	.4474	.3662	.4190	.4461	.3653

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274091 / 33/11 KV ANTROLI

Feeder No / Name : 205 / 11 KV EXPRESS FDR  
 CRE/PHONIX Feeder KV- 11 /  
 OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
 (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0514		
2		.0514		
3		.0514		
4	.0366	.0514		
5	.0366	.0514		
6	.037	.0514		
7	.037	.0514		
8	.037	.0514		
9	.0362	.052		
10	.0362			
11	.0362		.0362	.0509
12	.0514		.0351	.0543
13	.0514		.0537	.056
14	.0514		.0339	.0543
15	.0514		.0351	.0362
16	.0514		.0366	.0343
17	.0514		.0358	.0343
18	.0514		.0339	.0343
19	.0514		.037	
20	.0514		.0362	
21	.0514			
22	.0514			
23	.0514			
24	.0152	.0514		
Max	.0514	.052	.0537	.056
Min	.0152	.0514	.0339	.0343
Avg	.0440	.0515	.0374	.0443



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274091 / 33/11 KV ANTROLI

Feeder No / Name : 207 / 11 KV KHANAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	1.2003	1.307	1.2269	1.4918	1.1888	1.8861
2	.1905	1.2003	1.307	1.2269	1.4918	1.2012	1.8861
3	.1905	1.2003	1.307	1.2269	1.4918	1.2012	1.8861
4	.1905	1.2003	1.307	1.2269	1.4413	1.2012	1.8861
5	.2286	1.2003	1.4003	1.2536	1.4074	1.2936	1.8861
6	.2286	1.5432	1.5708	1.5223	1.4074	1.386	2.1434
7	.2667	1.7147	1.7556	1.6832	1.4074	1.7556	2.3148
8	.2667	1.7147	1.7187	1.7375	1.4074	1.8111	2.3148
9	1.7147	.1905	.1524	.1715	.2286	.2858	.4763
10	1.8004	.1905	.1715	.2096	.2477		.6668
11	1.8861	.1905	.2286	.2096	.2477		
12	1.7147	.2096	.2286	.2096	.2477		.6097
13	1.7147		.2096	.2096	.2096		.6668
14	1.5432		.2096	.2096	.2096	.4763	.724
15	1.5432		.2096	.1905	.2286	.5716	.8002
16	1.5432		.2096	.1905	.1524	.5716	.8192
17	.1905		.1524	.1905	.1715	.5716	
18	.0953		.1524	.1905	.1715		
19	.1905		.1715	.1905	.1524	.6668	
20	.1905	.2477	.1715	.1524	.1715	.6668	.5906
21	.1905	.2477	.1524	.1524	.1715	.6668	.5525
22	.1905	.2477	.1143	.1524	.1524	.6668	.3048
23	.0152	1.307	1.267	1.3375	1.2012	1.8861	1.6118
24	.1905	1.2003	1.307	1.2003	1.4918	1.2012	1.8861
Max	1.8861	1.7147	1.7556	1.7375	1.4918	1.8861	2.3148
Min	.0152	.1905	.1143	.1524	.1524	.2858	.3048
Avg	.6861	.8827	.6992	.6780	.7084	1.0142	1.2956

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274092 / 33/11KV BHANDKAWATHE

Feeder No / Name : 201 / 11 KV BALAGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
1	.3429
2	.3772
3	.3772
4	.3429
5	.3601
6	.3601
7	.3429
8	.1372
9	2.13
24	.1524
<b>Max</b>	<b>2.13</b>
<b>Min</b>	<b>.1372</b>
<b>Avg</b>	<b>.4923</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274092 / 33/11KV BHANDKAWATHE

Feeder No / Name : 202 / 11 KV NIMBARGI (SPARE) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
1	2.5888
2	2.652
3	2.6852
23	.0762
24	2.6189
<b>Max</b>	<b>2.6852</b>
<b>Min</b>	<b>.0762</b>
<b>Avg</b>	<b>2.1242</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274092 / 33/11KV BHANDKAWATHE

Feeder No / Name : 203 / 11 KV B'KAWATHE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	05-AUG-17
HR	Load (MW)	Load (MW)
11		.0762
24	.0762	
Max	.0762	.0762
Min	.0762	.0762
Avg	.0762	.0762

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274092 / 33/11KV BHANDKAWATHE

Feeder No / Name : 204 / LOKMANGAL EXPRESS FEEDER NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
23	.0152
Max	.0152
Min	.0152
Avg	.0152

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274092 / 33/11KV BHANDKAWATHE

Feeder No / Name : 205 / 11 KV AMBEDKAR NAGAR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	03-AUG-17
HR	Load (MW)	Load (MW)
17		.0762
23	.0152	
24	.1524	
Max	.1524	.0762
Min	.0152	.0762
Avg	.0838	.0762

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274092 / 33/11KV BHANDKAWATHE

Feeder No / Name : 206 / 11 KV SADEPUR ( SPARE) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.0762
Max	.0762
Min	.0762
Avg	.0762

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274092 / 33/11KV BHANDKAWATHE

Feeder No / Name : 207 / 11 KV TELGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.0152
Max	.0152
Min	.0152
Avg	.0152



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274093 / 33/11 KV HOTAGI

Feeder No / Name : 201 / 11 KV FATATEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	.9431	.9431	.9431	.9335	.9431	.9431
2	1.2003	.9431	1.0374	.9431	.9335	.9431	1.0374
3	1.2003	1.0374	1.1317	1.1317	.9335	.9431	1.1317
4	1.286	1.0374	1.226	1.226	1.1203	1.1317	1.226
5	1.4575	1.1317	1.3203	1.3203	1.307	1.307	1.3203
6	1.6766	1.3203				1.307	
7	2.1548	1.3203	1.1317	1.226		1.1203	
8	2.0119	.9431				.9431	
9	.7545	1.5432	1.7147	1.8861	1.8652	1.6766	1.9719
10	.5658	1.8004	2.0576	1.8861	2.0576	2.0348	2.0576
11	.5658		1.9281	1.8861	1.9719	2.0576	1.9719
12	.5658		1.9281	1.8861	1.9719	2.0576	1.9719
13	.5658		2.0119	1.8861	1.5432	2.0576	2.0576
14	.6602		2.0119	2.0576	1.5432	2.0348	2.1434
15	.6602		2.0119	2.0576	2.0576	1.9719	2.1948
16	.5658	1.8861	2.0119	2.0576	2.0576	1.95	2.1434
17	.6602	.7545	.6535	.7545			.7545
18	.6602	.7545	.7545	.8488	.9431	.9431	.7545
19	.9431	.9431	.9431	.9335	1.0269	1.0374	.9431
20	1.226	1.2136	1.2136	1.2936	1.2136	1.226	1.2136
21	1.3203	1.1203	1.307	1.307	1.2136	1.226	1.2136
22	1.1317	1.1203	1.1317	1.2136	1.1317	1.1317	1.2136
23	.9431	.9335	.9431	.9335	.9431	.8488	.9431
24	.061	.9431	.9431	.9431	.9335	.9431	.8488
Max	2.1548	1.8861	2.0576	2.0576	2.0576	2.0576	2.1948
Min	.061	.7545	.6535	.7545	.9335	.8488	.7545
Avg	1.0016	1.1415	1.3798	1.3919	1.3851	1.3841	1.4312

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274093 / 33/11 KV HOTAGI

Feeder No / Name : 202 / 11 KV AUJ HIPPALE YATNAL SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.8573	1.0288	1.0288	1.0288	1.0288	1.0288
2	.7545	.8573	1.0288	1.0288	1.0288	1.0288	1.0288
3	.7545	.9431	1.0288	1.0288	1.0288	1.0288	1.1145
4	.8488	1.0288	1.2003	1.1145	1.0288	1.0288	1.2003
5	1.0374	1.2003	1.3413	1.286	1.2003	1.0288	1.3717
6	1.307	1.3717	1.5089	1.6766	1.5261	1.3565	1.6289
7	1.307	.6859	1.5089	1.286	1.6766	1.5089	1.5432
8	.9431	1.4575	.6859	1.2003	1.6766	1.5089	1.1145
9	1.5261	.8488	.7545	.7545	.7545	.7545	.8488
10	1.6956	.7545	.7545	.7545	.6602	.7545	.7545
11	1.7147		.6602	.7545	.5658	.7545	.5658
12	1.5432		.4715		.5658	.7545	.5658
13	1.5432		.5658	.5658	.5658	.7545	.5658
14	1.6032		.4715	.5658	.5658	.7545	.5658
15	1.4575		.4715	.5658	.5658	.5658	.5658
16	1.3717	.6602	.5658	.5658	.5658	.5658	.5658
17	.5658	.8488	.5658	.5658	.5658	.5658	.6602
18	.6602	.7545	.6602	.7545	.6602	.7545	.6602
19	.7545	.8488	.9431	.8488	.9431	.9431	.7545
20	1.1317	1.0374	1.1203	.9335	.9431	.9431	1.2136
21	1.0374	1.0374	.9335	1.1203	1.0269	.9431	1.0374
22	.7545	.9431	1.094	.9431	.9431	.8488	.9431
23	.8573	1.0288	1.0288	.9431	1.1317	1.0288	1.1145
24	.1524	.8573	1.0288	1.0288	1.0288	1.0288	1.0288
Max	1.7147	1.4575	1.5089	1.6766	1.6766	1.5089	1.6289
Min	.1524	.6602	.4715	.5658	.5658	.5658	.5658
Avg	1.0865	.9485	.8926	.9267	.9270	.9264	.9350

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274093 / 33/11 KV HOTAGI

Feeder No / Name : 203 / 11 KV HOTAGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.6859	.9431	.8573	.8573	.9431	.9431
2	.5658	.6859	.9431	.8573	.8573	.9431	.9431
3	.5658	.6859	.9326	.8669	.8573	.9431	.9431
4	.6602	.7716	1.0174	.8573	.9431	.9431	1.0288
5	.8488	.8573	1.1145	.9431	.9431	1.0288	1.1145
6	1.0374	1.0288	1.2574	1.1145	1.1269	1.2717	1.286
7	.9431	1.2136	1.4575	1.4413	1.3003	1.4251	1.4575
8	.8488	1.1269	1.3717	1.3717	1.3003	1.3413	1.3717
9	.4382	.7545	.6859	.7545	.7545	.7545	.6602
10	.4287	.5658	.6602	.7545	.6602	.6602	.5658
11	.4287		.5658	.7545	.4715	.5658	.5658
12	.3429		.5658	.4715	.4715	.5658	.5658
13	.3429		.4715	.4715	.4715	.5658	.5658
14	.3429		.4715	.4715	.4715	.5658	.5658
15	.3429		.4715	.4715	.5658	.5658	.5658
16		.5658	.4715	.4715	.5658	.5658	.5658
17	.5658	.6602	.4715	.4715	.5658	.5658	.5658
18		.6602	.6602	.4715	.5658	.5658	.5658
19	.7545	.7545	.7545	.6602	.7545	.6602	.6602
20	.8488	.9431	.8488	.8488	.8488	.8488	.9431
21	.8488	.8488	.8488	.8488	.8488	.7545	.7545
22	.6602	.7545	.6602	.7545	.6602	.6602	.7545
23	.6859	.9431	.8573	.8573	.9431	.9431	.9431
24	.5658	.6859	.9431	.8573	.8573	.9431	.9431
Max	1.0374	1.2136	1.4575	1.4413	1.3003	1.4251	1.4575
Min	.3429	.5658	.4715	.4715	.4715	.5658	.5658
Avg	.6197	.7996	.8102	.7792	.7776	.8163	.8266

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274093 / 33/11 KV HOTAGI

Feeder No / Name : 204 / 11 KV BHARAT GARMENT  
EXPRESS Feeder KV- 11 /  
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
23	3.0483
24	.0152
Max	3.0483
Min	.0152
Avg	1.5318

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274094 / 33/11 KV MANDRUP

Feeder No / Name : 201 / 11 KV YELEGAON(KANDALGAON) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	1.0059	1.0059	1.0059	1.1736	1.0898	.6706
2	.2801	1.3413	1.1736	1.0059	1.1736	1.3413	.8383
3	.2801	1.5089	1.1736	.6706	1.3413	1.5927	.8383
4	.2801	1.5927	1.5089	.8383	1.3413	1.5927	1.0059
5	.2801	1.6766	1.5089	1.3413	1.5089	2.0119	1.3413
6	.2801	1.8442	1.7604	1.6766	1.6766	2.0119	1.6766
7	.2801	1.9281	1.7604	2.0119	1.9281	2.0119	2.0119
8	.2801	1.9281	1.7604	2.3472	1.8442	1.9281	2.0119
9	1.5089	.2829	.2801	.1867	.1867	.2829	.1867
10	1.5927	.2801	.2801	.1867	.1886	.1867	.1867
11	1.6766	.2801	.1867	.1867	.1886	.1867	.1867
12	1.6766	.2801	.1867	.1867	.1886	.1867	.1867
13	1.7604	.2801	.1867	.1867	.1886	.1867	.1867
14	1.6766	.2801	.1867	.1867	.1886	.1867	.1867
15	1.5927	.2801	.1867	.2801	.1886	.1867	.1867
16	1.5927	.2801	.1867	.1867	.1886	.1867	.1867
17	.2829	.2801	.1867	.1867	.1886	.1867	.1867
18	.2829	.2801	.1867	.1867	.2829	.1867	.1867
19	.2829	.2801	.2801	.1867	.2829	.1867	.1867
20	.2829	.3734	.2801	.1867	.2829	.1867	.2801
21	.2829	.3734	.2801	.1867	.2829	.1867	.2801
22	.2829	.2801	.2801	.2801	.2829	.1867	.2801
23	.9221	.9221	.6706	.8383	.9221	.6706	.7545
24	.2801	1.0059	1.0059	1.0059	1.0059	1.0898	.6706
Max	1.7604	1.9281	1.7604	2.3472	1.9281	2.0119	2.0119
Min	.2801	.2801	.1867	.1867	.1867	.1867	.1867
Avg	.7591	.7860	.6876	.6476	.7094	.7521	.6131

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274094 / 33/11 KV MANDRUP

Feeder No / Name : 202 / 11 KV BASAVNAGAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.2829	.3734	.2801	.3734	.2829	.2801
2	1.0059	.2829	.3734	.2801	.3734	.2829	.2801
3	1.0059	.2829	.3734	.2801	.3734	.2829	.2801
4	1.0059	.2829	.3734	.2801	.3734	.2829	.2801
5	1.0898	.2829	.4668	.3734	.3734	.3772	.2801
6	1.0898	.3772	.4668	.3734	.3734	.3772	.3734
7	1.0898	.3772	.4668	.3734	.3734	.3772	.3734
8	1.5089	.3772	.3734	.3734	.3734	.2829	.2801
9	.2801	.9221	1.0059	.8383	.8383	1.0898	
10	.2829	.9221	1.0059	.8383	.0838	1.0059	.6706
11	.2829	.8383	1.0059	1.0059	.9221	1.1736	.8383
12	.2829	1.0059	1.1736	1.0059	1.1736	1.1736	.9221
13	.2829	1.0059	1.3413	1.0059	1.1736	1.3413	.9221
14	.2829	1.0059	1.0059	.8383	1.1736	.6706	1.0059
15	.2829	1.0059	1.1736	.8383	1.0898	1.0059	1.1736
16	.2829	1.0059	1.1736	1.0059	1.0898	1.1736	1.1736
17		.3734	.2801	.3734	.2829	.2801	.2801
18		.3734	.2801	.3734	.3772		.2801
19	.1886	.3734	.3734	.3734	.4715		.3734
20	.4715	.4668	.3734	.3734	.4715		.3734
21	.4715	.4668	.3734	.3734	.4715		.3734
22	.4715	.3734	.3734	.3734	.4715		.3734
23	.3772	.3734	.3734	.3734	.3772		.3734
24	.8383	.2829	.3734	.3734	.3734	.2829	.2801
Max	1.5089	1.0059	1.3413	1.0059	1.1736	1.3413	1.1736
Min	.1886	.2829	.2801	.2801	.0838	.2801	.2801
Avg	.6233	.5559	.6231	.5408	.5762	.6524	.5148

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274094 / 33/11 KV MANDRUP

Feeder No / Name : 203 / 11 KV WANGI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6706	.1886	.2801	.0934	.2801	.1886	.3734
2	.8383	.1886	.2801	.0934	.2801	.1886	.3734
3	.8383	.1886	.2801	.1867	.2801	.1886	.1867
4	.8383	.1886	.2801	.1867	.3734	.1886	.1867
5	1.0898	.1886	.3734	.1867	.3734	.2829	.1867
6	1.0898	.2829	.3734	.3734	.3734	.3772	.2801
7	1.0898	.2829	.3734	.3734	.3734	.3772	.2801
8	1.1736	.2829	.3734	.3734	.2801	.2829	.1867
9	.2801	.9221	.9221	.8383	.8383	.9221	.6706
10	.1886	1.0059	1.0059	.8383	.9221	1.0059	.8383
11	.1886	1.0059	1.0059	.9221	.9221	1.1336	.8383
12	.1886	1.0059	1.1736	.9221	1.0898	1.1736	.9221
13	.1886	1.0059	1.1736	.9221	1.0898	1.1736	.9221
14	.1886	1.0059	.6706	.8383	1.0898	1.0059	1.0059
15	.1886	1.0059	.8383	.8383	1.0059	1.0059	1.0059
16	.0943	1.0059	.8383	.9221	1.0059		1.0059
17	.1886	.2801	.1867	.1867	.1886		.1867
18	.1886	.2801	.1867	.1867	.2829		.1867
19	.1886	.3734	.1867	.2801	.2829	1.1736	.2801
20	.1886	.3734	.1867	.2801	.2829		.2801
21	.1886	.3734	.0934	.2801	.2829		.2801
22	.1886	.2801	.0934	.2801	.1886		.2801
23	.1886	.2801	.0934	.2801	.1886		.2801
24	.6706	.1886	.2801	.0934	.2801	.1886	.3734
Max	1.1736	1.0059	1.1736	.9221	1.0898	1.1736	1.0059
Min	.0943	.1886	.0934	.0934	.1886	.1886	.1867
Avg	.4636	.5077	.4812	.449	.5231	.6387	.4754

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274094 / 33/11 KV MANDRUP

Feeder No / Name : 205 / 11 KV MANDRUP

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.5658	.7468	.5601	.6535	.5658	.5601
2	.8383	.5658	.7468	.5601	.6535	.5658	.5601
3	.8383	.5658	.7468	.4668	.6535	.5658	.5601
4	.8383	.5658	.7468	.4668	.7468	.5658	.4668
5	1.0059	.5658	.7468	.7468	.7468	.6602	.4668
6	1.0059	.6602	.7468	.7468	.7468	.6602	.5601
7	1.0059	.6602	.7468	.7468	.7468	.6602	.6535
8	1.0059	.6602	.5601	.3734	.6535	.5658	.6535
9	.5601	.7545	.7545	.6706	.7545	.9221	.6706
10	.4715	.8383	.8383	.6706	.8383	1.0059	.6706
11	.4715	.8383	.8383	.6706	.9431	1.0059	.6706
12	.4715	.7545	1.0059	.6706	1.0059	1.0059	.6706
13	.4715	.7545	1.0059	.6706	1.0059	.6706	.6706
14	.4715	.7545	1.1736	.6706	1.0059	.6706	.6706
15	.4715	.6706	1.1736	.6706	1.4754	1.0059	.6706
16	.3772	.6706	1.1736	.7545	.9221	1.1736	.6706
17	.4715	.7468	.3734	.5601	.4715	.5601	.5601
18	.5658	.5601	.7468	.5601	.6602	.5601	.5601
19	.5658	.7468	.7468	.6535	.6602	.5601	.7468
20	.5658	.7468	.7468	.7468	.6602	.3734	.7468
21	.5658	.7468	.7468	.7468	.7545	.4668	.7468
22	.7545	.7468	.7468	.7468	.7545	.7468	.7468
23	.5658	.6535	.7468	.6535	.6602	.5601	.6535
24	.6706	.5658	.7468	.5601	.6535	.5658	.5601
Max	1.0059	.8383	1.1736	.7545	1.4754	1.1736	.7468
Min	.3772	.5601	.3734	.3734	.4715	.3734	.4668
Avg	.6517	.6816	.8064	.6393	.7845	.6943	.6320



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274094 / 33/11 KV MANDRUP

Feeder No / Name : 206 / 11 KV KARKAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	1.0059	1.0059	.8383	1.3413	1.1736	1.0059
2	.5601	1.1736	1.1736	.8383	1.3413	1.3413	.8383
3	.5601	1.3413	1.1736	.8383	1.5089	1.3413	.8383
4	.5601	1.3413	1.4251	1.0059	1.5089	1.5927	.6706
5	.7468	1.5089	1.4251	1.1736	1.6766	1.5927	.6706
6	.7468	1.5089	1.6766	1.5089	1.8442	1.8442	1.3413
7	.7468	1.6766	1.6766	1.6766	1.8442	1.8442	1.8442
8	.7468	1.6766	1.8442	2.0119	1.6766	1.8442	1.6766
9	1.5089	.3772	.3734	.4668	.3734	.5658	.2801
10	1.5927	.5601	.1867	.4668	.3772	.1867	.2801
11	1.5927	.5601	.1867	.5601	.2829	.1867	.3734
12	1.5927	.3734	.1867	.3734	.3772	.1867	.3734
13	1.6766	.3734	.1867	.3734	.3772	.1867	.3734
14	1.6766	.3734	.1867	.3734	.3772	.1867	.3734
15	1.6766	.3734	.1867	.3734	.3772	.1867	
16	1.5927	.3734	.1867	.3734	.3772	.1867	.3734
17	.3772	.5601	.1867	.3734	.3772	.2801	.3734
18	.4715	.7468	.1867	.5601	.4715		.5601
19	.4715	.7468	.2801	.5601	.4715		.7468
20	.4715	.7468	.2801	.7468	.4715		.7468
21	.4715	.7468	.2801	.7468	.4715		.7468
22	.4715	.7468	.4668	.7468	.4715		.7468
23	.8383	1.0059	.8383	1.0059	1.0059		1.0059
24	.5601	1.0059	1.0059	.8383	1.1736	1.0059	1.0059
Max	1.6766	1.6766	1.8442	2.0119	1.8442	1.8442	1.8442
Min	.3772	.3734	.1867	.3734	.2829	.1867	.2801
Avg	.9279	.8710	.6919	.7846	.8573	.8741	.7498

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274096 / 33/11 KV TAKALI

Feeder No / Name : 201 / 11 KV AUJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	1.8099	1.0288	1.7147	2.1434	1.7147	1.3717
2	.724	.181	1.0288	1.7147	2.1434	2.0576	1.3717
3	.724	1.9909	1.0288	2.0576	2.1434	2.2291	1.3717
4	.724	1.9909	1.0288	2.0576	2.1434	2.3148	1.3717
5	.905	2.1719	1.0288	2.0576	2.1434	2.3148	1.4575
6		2.1719	1.166	2.4006	2.1434	2.2291	1.5432
7		2.1719		2.6578	2.3148	2.3148	1.6289
8		1.3032	1.3213	2.6578	2.4006	2.4863	1.5775
9	2.4434	1.2308	1.3575	2.572	2.4691	2.2291	1.5432
10	2.4434	1.1145	1.3575	2.572		1.7147	1.6289
11	2.7149		.6154	.362		.543	.3982
12	2.6244	.4525		.362		.4287	.543
13	2.8054		.2572			.543	.5792
14	2.8959	.5068				.543	.6335
15	2.9864	.4525		.362		.4525	.5973
16	2.8054	.4525		.362		.543	.6335
17	.5658	.724	.362	.362		.543	.6335
18	.6859	.8145	.5792	.362		.543	.6697
19	.7716		.5973	.543		.5973	.6335
20	1.0288	.724	.6335	.4525		.5973	.543
21	1.0288	.724	.724	.4525		.543	.5611
22	.8573	.724	.724	.4525		.543	.5068
23	.8573	.724	.724	.4525		.4525	.4887
24	.1524	.8573	.543	.724	.4525	.362	.362
Max	2.9864	2.1719	1.3575	2.6578	2.4691	2.4863	1.6289
Min	.1524	.181	.2572	.362	.4525	.362	.362
Avg	1.4985	1.1092	.8477	1.2596	2.0497	1.2016	.9437

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274096 / 33/11 KV TAKALI

Feeder No / Name : 202 / 11 KV TAKALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6878	2.5339	2.2634	2.2291	2.572	2.6578	2.2291
2	.6878	2.5339	2.2634	2.2291	2.572	2.6578	2.2291
3	.6335	2.7149	2.2634	2.3148	2.572	2.7263	2.2291
4	.724	2.9864	2.2634	2.4006		2.7263	2.2291
5	.905	3.1312	2.3148	2.452	2.572	2.8635	2.4006
6	.9774	3.2217	2.3491	2.6578	2.6749	2.915	2.452
7	.8145	3.3665		2.8807	2.6578	2.9321	
8	.6697	3.8009	2.7149	2.7606	2.9492	2.6749	2.6406
9	3.6923	3.8009	3.0226	2.7949		2.8121	2.572
10	3.6018	3.3436	2.8235	2.8464		2.7092	2.6063
11	2.8416	.4458	.3601	.4525		.4163	.3982
12	2.2986	.4887	.3601	.4887		.4706	.4344
13	3.5113	.4887	.4287	.4887		.463	
14	3.4389		.5068	.4887		.5068	.4163
15	3.4389	.4525	.5068	.5068		.5249	.4525
16	3.4751	.4887	.5068	.5068		.4887	.4706
17	.2915	.4887	.4887	.543		.5068	.4344
18	.5601	.5068	.4887	.5973		.543	.4525
19	.5144	.5792	.543	.6335		.5973	.5068
20	.6687	.6697	.543	.6878		.6878	.5973
21	.6001	.5973	.543	.5973		.6335	.6154
22	.5144	.6001	.4887	.543		.5973	.543
23	.4801	.543	.4344	.5068		.543	.4344
24	.1524	.4287	.4525	.4344	.4525	.4525	.4344
Max	3.6923	3.8009	3.0226	2.8807	2.9492	2.9321	2.6406
Min	.1524	.4287	.3601	.4344	.4525	.4163	.3982
Avg	1.5075	1.6614	1.2578	1.3767	2.3778	1.4628	1.2626

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274096 / 33/11 KV TAKALI

Feeder No / Name : 203 / 11 KV NANDANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3546	.2743	.2715	.0543		.2715	.3077
2	1.3889	.2743	.2715	.0543		.2715	.3077
3	1.4575	.3086	.2715	.0543		.2172	.2915
4	1.4575	.3086	.2715	.0543		.2172	.3077
5	1.5432	.3429	.362	.0724		.2353	.3077
6	1.5775	.3772	.3982	.0724		.3439	.3258
7	1.7147	.3086		.0724		.4163	.3258
8	1.7661	.2743	.2915	.0724			.2353
9	.2058	.2401	.2572			.2534	.2353
10	.1372	.1486	.1886	.2172		.2353	
11	.12	1.9204	1.9185	1.5432		1.749	1.5775
12	.1372	1.8519	1.9004	1.5775		1.6289	1.7375
13	.1372	2.0233	1.9547	1.4403		1.749	1.7147
14	.1372	1.9719	1.869	1.4232		1.8461	1.749
15	.1372	1.8519	1.8347	1.4575		1.7147	1.7833
16	.1543	1.8861	1.8347	1.5089		1.7318	1.7833
17	.2058	1.7318	1.5261	1.5432		1.7147	1.7833
18	.2743	1.7318	1.286	1.5775		1.5947	1.7147
19	.2743	.3077		.362		.3982	.2896
20	.4287	.3801		.362		.3982	.543
21	.3772	.3801		.362		.4706	.4887
22	.3086	.2715	.0543	.362		.4163	.3801
23	.2915	.2715	.0543	.3258		.362	.362
24	.1067	.2743	.2715	.0543	.3258	.3077	.362
Max	1.7661	2.0233	1.9547	1.5775	.3258	1.8461	1.7833
Min	.1067	.1486	.0543	.0543	.3258	.2172	.2353
Avg	.6539	.8213	.8544	.6358	.3258	.8062	.8223

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274096 / 33/11 KV TAKALI

Feeder No / Name : 204 / 11 KV KUDAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2065	.5144	.543	.6335	.543	.543	.4115
2	3.2065	.5144	.543	.6335	.543	.5068	.4115
3	3.2065	.6516	.5144	.6335	.543	.5068	.4115
4	3.3436	.7716	.5144	.724	.543	.4525	.4344
5	3.4294	.8573	.6335	.8145	.6335	.543	.6335
6	3.6351	.8916	.9774	.905	1.0136	.6878	.9955
7	3.4465	.7373		.8145	.9231	.905	.9412
8	3.3093	.583	.5658	.543	.5792	.7602	.6154
9	.463	.3429			.4163		.4801
10	.2572	.2715	.4287	.3258		.362	
11	.4115	3.6523	3.8371	3.6008		3.4979	3.7723
12	.3772	3.5151	3.6923	3.7723		3.5151	1.7318
13	.3772	3.4294	3.7647	3.6694			1.8861
14	.3772	3.5322	3.5494	3.6694		3.6008	1.9033
15	.4287	3.4294	3.6351	3.738		3.4808	1.9033
16		3.2579	3.4294	3.275		3.6866	1.9204
17	.4287	3.1379	3.1036	3.2579		3.5494	1.9376
18	.5487	1.8519	2.915	3.2065		3.2922	1.8519
19	.6687		.7602	.5973		.7545	.6335
20	.8745		.8688	.724		.8402	.8507
21	.823	.7716	.905	.6878		.7602	.8145
22	.6859	.8145	.9231	.6516		.724	.5973
23	.5487	.6335	.6878	.5792		.543	.543
24	3.1722	.463	.543	.543	.543	.5792	.4115
Max	3.6351	3.6523	3.8371	3.7723	1.0136	3.6866	3.7723
Min	.2572	.2715	.4287	.3258	.4163	.362	.4115
Avg	1.6185	1.5738	1.6970	1.6522	.6281	1.5496	1.1344

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274096 / 33/11 KV TAKALI

Feeder No / Name : 205 / 11 KV KURGHOT

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-AUG-17	02-AUG-17	03-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
8		1.8823	.0857
9		2.0271	.0857
10			.0857
24	.1524		
Max	.1524	2.0271	.0857
Min	.1524	1.8823	.0857
Avg	.1524	1.9547	.0857

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274096 / 33/11 KV TAKALI

Feeder No / Name : 206 / 11 KV RTO CHECK POST  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362	.0343	.0362	.0362	.0362	.0362	.0362
2	.0362	.0343	.0362	.0362	.0362	.0362	.0362
3	.0362	.0343	.0362	.0362	.0362	.0362	.0362
4	.0362	.0343	.0362	.0181	.0362	.0362	.0362
5	.0362	.0171	.0362	.0181	.0362	.0362	.0362
6	.0181	.0171	.0181	.0181	.0362	.0181	.0181
7	.0181	.0171		.0181	.0181	.0181	.0181
8	.0181	.0171	.0171	.0181	.0181	.0171	.0181
9	.0171	.0171	.0171	.0171	.0181	.0181	.0362
10		.0181	.0171	.0171	.0181	.0181	
11		.0181	.0171	.0171	.0181	.0181	
12	.0171	.0181	.0171	.0171	.0181	.0181	
13	.0171	.0181	.0171	.0171	.0181	.0181	
14	.0171	.0181	.0171	.0171	.0181	.0181	
15	.0171	.0181	.0171	.0171	.0095	.0181	
16	.0171	.0181	.0171	.0171	.0181	.0181	
17	.0171	.0181	.0171	.0171	.0181	.0181	
18	.0171	.0181	.0171	.0171	.0181	.0181	
19	.0171	.0181	.0171	.0171	.0181	.0181	
20	.0171	.0362	.0343	.0362	.0362	.0362	
21	.0343	.0362	.0343	.0362	.0362	.0362	
22	.0343	.0362	.0343	.0362	.0362	.0362	
23	.1562	.0362	.0343	.0362	.0362	.0362	
24	.0362	.0343	.0362	.0181		.0362	.0362
Max	.1562	.0362	.0362	.0362	.0362	.0362	.0362
Min	.0171	.0171	.0171	.0171	.0095	.0171	.0181
Avg	.0303	.0243	.0251	.0229	.0256	.0256	.0308

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274097 / 33/11 KV TANDULWADI

Feeder No / Name : 202 / 11 KV MUSTI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2634	1.2955	1.6004	1.3336	1.2193	1.2574	1.3336
2	2.2634	1.3336	1.6004	1.3717	1.3336	1.2574	1.3336
3	2.4006	1.3336	1.829	1.4861	1.448	1.448	1.3717
4	2.5377	1.5242	2.21	1.5242	1.5623	1.6004	1.5242
5	2.7435	1.7147	1.9052	1.8671	1.7528	1.829	1.7147
6	3.2922						1.6575
7	3.2236						1.4098
8	3.2236						1.2003
9	1.0669	2.572	3.5151	2.7263	3.2236	3.2579	2.7435
10	.7621	3.3951	.4287	1.7147	3.4294	3.8104	3.3779
11	.6478	3.0864	.8059	2.8121	3.4637	3.858	3.7894
12	.6287	3.3608	2.4863		3.3608	3.4122	3.6866
13	.6287		3.2579	2.6749	3.6694	3.6694	3.5151
14	.6097		3.2579	3.0864	3.7723	3.5837	3.3608
15	.6668		3.4637	3.155	3.8409	3.155	
16	.6668		3.3436	2.7435	3.4979	3.2579	3.4294
17	.724		.7621		.724	.8002	.8764
18	.9335	2.1262	1.0098	1.1431	.8383	.8383	.9526
19	1.6766	2.1948	1.3717	1.2955	1.2955	1.2765	1.1431
20	1.467	2.2634	1.5623	1.4861	1.5623	1.5242	1.4289
21	1.3146	1.5623	1.3336	1.448	1.4098	1.4289	1.3336
22	1.1812		1.3336	1.2955	1.2955	1.2574	1.2574
23	1.2003	1.5623	1.2193	1.2193	1.2765	1.2003	1.1431
24	.1524	1.1431	1.5813	1.1431	1.1431	1.2574	1.1431
Max	3.2922	3.3951	3.5151	3.155	3.8409	3.858	3.7894
Min	.1524	1.1431	.4287	1.1431	.724	.8002	.8764
Avg	1.5115	2.0312	1.8989	1.8698	2.1485	2.1419	1.9446



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274097 / 33/11 KV TANDULWADI

Feeder No / Name : 203 / 11 KV BORAMANI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7528	1.8519	2.332	2.0576	2.0576	2.6063	2.7435
2	1.829	1.8519	2.4006	2.0576	2.1948	2.6063	2.8121
3	2.0576	1.8861	2.4006	2.0576	2.332	2.6749	2.915
4	2.1338	1.8861	2.4348	2.4006	2.4006	2.7435	2.915
5		2.0576	2.5377	2.6063	2.5377	2.9492	3.0178
6		2.1948	2.6749	2.7435	3.0864	3.6351	3.4294
7		3.4294	1.5775	2.0576	3.7037	3.9781	3.7037
8		3.6351	1.2346	3.5665	3.7723	3.9095	3.7037
9	3.3608	1.1431	.9145	1.1431	1.1431	1.2955	1.2955
10	3.6351	.9907	.6859	1.0669	1.0669	.9907	1.2955
11	3.8409	1.829	.6859	.9145	.9907	.9145	1.1431
12	3.8409	1.829	.9907	.8383	.9907	.9145	1.1431
13	3.9095		.9145	.8383	.9145	.9907	1.1431
14	3.2922		.9907	.8383	.9145	.9907	1.1431
15	3.3608			.9145		.9907	.9907
16	3.3608		.9145	.9145	.9145	.9145	1.1431
17	1.0669		1.0669	.9907	1.0669		1.1431
18	1.2193	3.7647	1.1431	1.0669	1.2193	1.0669	1.2193
19	1.1431	4.0542	1.829	1.448	1.5242	1.5242	1.3717
20	2.0576	3.6199	2.1338	2.1338	2.1338	2.1338	2.0576
21	2.0576	3.658	1.7528	2.0576	2.0576	1.9052	1.9814
22	1.9052		1.829	1.9814	1.9814	1.9052	1.9052
23	.1524	2.0576	2.1948	2.0576	2.6063	2.8807	2.572
24	1.7528	1.8519	2.332	2.0576	2.0576	2.6063	2.7435
Max	3.9095	4.0542	2.6749	3.5665	3.7723	3.9781	3.7037
Min	.1524	.9907	.6859	.8383	.9145	.9145	.9907
Avg	2.3865	2.4217	1.6509	1.7004	1.8986	2.049	2.0638

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274098 / 33/11 Ule

Feeder No / Name : 201 / 11 KV ULEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.2829	.2452	.2829	.2829	
10	.2829	.2263	.2263	.2263	
11	.2263	.2075	.1698	.1886	
12	.2263	.1886	.1698	.1341	
13		.1886	.1509	.132	
14		.1886	.1509	.1509	
15		.1886	.1509	.1509	
16		.2075	.1698	.1698	
17					.2075
18					.2263
19					.2829
20					.3772
21					.3584
22					.3206
23					.8383
Max	.2829	.2452	.2829	.2829	.8383
Min	.2263	.1886	.1509	.132	.2075
Avg	.2546	.2051	.1839	.1794	.3730

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274098 / 33/11 Ule

Feeder No / Name : 202 / 11 KV KASEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	04-AUG-17	05-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
9	1.5927	.4338	.5658
10		.415	.6413
11	1.6263	.3772	.4527
12	1.7604	.3961	.4338
13	1.9281	.4527	.415
14	2.2257	.4904	.3772
15			.3961
16			.4338
Max	2.2257	.4904	.6413
Min	1.5927	.3772	.3772
Avg	1.8266	.4275	.4645

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274098 / 33/11 Ule

Feeder No / Name : 204 / 11 KV MANCHUKONDA EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.0754	.0566	.0566	.0566	
10	.0754	.0754	.0566	.0566	
11	.0566	.0754	.0566	.0566	
12	.0566	.0566	.0568	.0566	
13	.0566	.0566	.0566	.0566	
14	.0566	.0566	.0566	.0566	
15	.0566	.0566	.0566	.0566	
16	.0566	.0566	.0566	.0566	
17					.0566
18					.0566
19					.0566
20					.0566
21					.0566
22					.0566
23					.0566
Max	.0754	.0754	.0568	.0566	.0566
Min	.0566	.0566	.0566	.0566	.0566
Avg	.0613	.0613	.0566	.0566	.0566

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274098 / 33/11 Ule

Feeder No / Name : 205 / 11 KV KHADAKI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.3206	2.0119	1.576	2.0119	
10	.2829	2.1795	3.1855	3.0346	
11	.2263	2.5149	2.3137	3.0681	
12	.2075	2.8502	3.0178	3.0178	
13		3.0346	2.9508	2.934	
14		3.0178	2.9005	2.9005	
15		3.0514	2.5819	3.0178	
16		2.9843	2.5652	3.1017	
17					.2829
18					.6036
19					.3772
20					.4715
21					.6036
22					.5658
23					.415
Max	.3206	3.0514	3.1855	3.1017	.6036
Min	.2075	2.0119	1.576	2.0119	.2829
Avg	.2593	2.7056	2.6364	2.8858	.4742

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274098 / 33/11 Ule

Feeder No / Name : 206 / 11 KV Stone Crusher  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.2058	.1372	.1372	.1543	
10	.2915	.2572	.4458	.6687	
11	.3429	.3429	.6516	.7716	
12	.4287	.463	.6001	.6859	
13	.4115	.5658	.6173	.6516	
14	.4287	.6173	.6516	.7202	
15	.3772	.823	.6687	.6173	
16	.3601	.6859	.6859	.5487	
17					.3429
18					.2743
19					.2915
20					.2915
21					.2743
22					.2572
23					.1543
24	.1524				
Max	.4287	.823	.6859	.7716	.3429
Min	.1524	.1372	.1372	.1543	.1543
Avg	.3332	.4865	.5573	.6023	.2694

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274098 / 33/11 Ule

Feeder No / Name : 207 / 11 KV ULE GAONTHAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.1524
Max	.1524
Min	.1524
Avg	.1524

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274098 / 33/11 Ule

Feeder No / Name : 208 / 11 KV EKRUKH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.4527	.7545	.7545	
10	.4904	.5658	.6602	
11		.4527	.547	
12		.4715	.6224	
13	.4904	.4715	.6602	
14	.4904	.4715	.7167	
15	.5093	.4904	.7167	
16	.5281		.7356	
17				.3395
18	.4527			.3772
19				.4904
20				.6036
21				.5658
22				.4904
23				.6036
Max	.5281	.7545	.7545	.6036
Min	.4527	.4527	.547	.3395
Avg	.4877	.5254	.6767	.4958



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274098 / 33/11 Ule

Feeder No / Name : 209 / 11 KV BORAMANI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.6706	1.1401	1.0227	
10		1.2742	1.3203	
11		1.4922	1.3077	
12		1.5089	1.2574	
13		1.4922	1.3077	
14		1.4754	1.3413	
15	1.3748	1.4419	1.3748	
16	1.3413	1.4251	1.3413	
17				.0377
18				.0566
19				.0943
20				.1509
21				.1139
22				.0943
23				.0943
Max	1.3748	1.5089	1.3748	.1509
Min	.6706	1.1401	1.0227	.0377
Avg	1.1289	1.4063	1.2842	.0917

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274099 / 33/11 KV VALSANG

Feeder No / Name : 201 / 11 KV DINDUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	1.0802	.8993	1.4352	1.4815	1.4937
2	.7621	1.078	.9105	1.4529	1.4685	1.4937
3	.8002	1.1717	.9145	1.4506	1.4022	1.531
4	.9145	1.2186	.9842	1.5813	1.6975	1.7185
5	1.0479	1.2955	1.0494	1.9204	1.8976	1.7528
6		1.6091	1.3443	2.1559	1.9997	1.9814
7		2.2565	1.6667	2.7808	2.5309	
8		2.1872	1.7747	2.6558	2.0309	2.0622
9	1.9509	.4687	.2096	.6097	.6668	.724
10	2.2377		.2096	.4001	.4954	.4763
11	2.2531	.3239	.1905	.381	.4001	1.5623
12	2.4684	.3239	.1715	.381	.362	.362
13	2.271			.3429	.381	.362
14	1.7438	.0953	.381	.362	.381	.381
15	2.1643	.0953	.4001	.362	.381	.4001
16	2.0081	.1715	.4001	.3429	.4382	.4382
17	.381	.1905	.4191	.362	.5144	.4191
18	.4382	.1905	.4001	.4382	.4572	.4382
19	.6287	.2858	.8002	.6859	1.0669	.8002
20	.9145	.4954	1.0479	.9335	.9717	1.0669
21	.9526	.4763	.9907	1.0098	.8573	.9717
22	.8383	.362	.8383	.8002	1.4529	.8383
23	1.0031	.8535	1.4022	1.531	1.5466	1.6766
24	.743	.9907	.9061	1.4022	1.4784	1.5278
Max	2.4684	2.2565	1.7747	2.7808	2.5309	2.0622
Min	.381	.0953	.1715	.3429	.362	.362
Avg	1.2992	.7827	.7961	1.0741	1.0983	1.0643

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274099 / 33/11 KV VALSANG

Feeder No / Name : 202 / 11 KV ACHEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7099	.4001	.3429	.381	.4001	.3429
2	.7186	.4191	.3429	.362	.4191	.3429
3	.7407	.4382	.3429	.362	.4572	.3429
4	.7621	.4572	.362	.4191	.4954	.381
5	.8436	.5335	.4001	.4954	.5335	.5716
6	1.1736	.6478	.4382	.6097	.6287	.6097
7	1.4685	.5335	.4001		.5335	
8	1.5699	.4572	.362		.4191	
9	.3429	1.0059	1.2651	1.5051	1.1873	1.1126
10	.3048		1.2955	1.3717	1.5432	1.1888
11	.2477	1.4529	1.3443	.7716	1.4373	1.5466
12	.2096	1.439	1.3117		1.2342	1.4632
13	.2286	.9722	1.4842	1.2803	1.2029	1.4022
14	.2477	1.0364	1.4175	1.2803	1.3565	1.2193
15	.2667	1.1561	1.4373	1.2803	1.326	1.1873
16	.3048	1.3108	.2858	1.3413	1.3717	1.2811
17	.2858	.2858	.2858	.2477	.2667	.3048
18	.3239	.3429	.4763	.362	.2096	.3239
19	.5335	.4763	.6668	.4191	.4572	.5144
20	.6478	.6287	.6668	.5144	.6097	.6478
21	.7049	.5906	.5906	.5906	.5525	.5716
22	.4954	.4763	.4572	.4572	.4763	.4954
23	.4572	.362	.381	.381	.362	.381
24	.0152	.4191	.362	.381	.381	.3429
Max	1.5699	1.4529	1.4842	1.5051	1.5432	1.5466
Min	.0152	.2858	.2858	.2477	.2096	.3048
Avg	.5668	.6888	.6966	.7054	.7442	.7534

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274099 / 33/11 KV VALSANG

Feeder No / Name : 203 / 11 KV L.CHINCHOLI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9602	.4763	.381	.381	.4191	.4001
2	.9877	.4572	.381	.381	.4572	.4001
3	.9259	.4763	.381	.381	.4954	.4001
4	.9877	.5144	.4001	.4191	.5335	.5335
5	1.1561	.5906	.4382	.5335	.5716	.5716
6	1.4255	.724	.5144	.7049	.7811	.724
7	1.6821	.6287	.743	.6859	.743	.7049
8	1.7814	.5906	.5716	.5525	.5906	.6478
9	.5144	1.6385	1.3889	.7316	1.1888	1.387
10	.3429		1.4022	.7562	1.5278	1.5935
11	.2858	1.5242	1.5684		1.5779	1.5242
12	.2286	1.3435	1.6004	1.3717	1.4706	1.3108
13	.2477	1.3735	1.531	1.448	1.4373	1.3717
14	.2667	1.3272	1.4842	1.3717	1.448	1.4373
15	.2858	1.3435	1.4685	1.4217	1.5364	1.4661
16	.2667	1.4842	1.5364	1.5154	1.406	1.4175
17	.3429	.362	.3048	.3048	.3429	.3239
18	.4191	.381	.3429	.3239	.4382	.362
19	.5335	.5335	.5144	.5144	.5525	.5335
20	.724	.6287	.6287	.5716	.6859	.6859
21	.5906	.5716	.4954	.6097	.5906	.6097
22	.5335	.5335	.4954	.6097	.5525	.5335
23	.5335	.5335	.4001	.4191	.4191	.4191
24	.945	.4954	.4001	.381	.381	.4001
Max	1.7814	1.6385	1.6004	1.5154	1.5779	1.5935
Min	.2286	.362	.3048	.3048	.3429	.3239
Avg	.7070	.8057	.8072	.7126	.8395	.8232

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274099 / 33/11 KV VALSANG

Feeder No / Name : 204 / 11 KV SOOT MIL SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3549	.4572	.3086	.4687	.442	.3395
2	.3658	.4475	.3125	.5401	.4843	.3437
3	.3906	.4218	.3048	.6097	.4687	.3163
4	.3858	.4115	.3506	.6249	.4321	.3749
5	.3858	.4586	.381	.6097	.506	.4687
6	.6097	.4374	.442	.6249	.5182	.5792
7	.6478	.4752	.5487	.6405	.6097	.5792
8	.5716	.4687	.5247	.5487	.5487	.5624
9	.4012	.3749	.5335	.6097	.5335	.5716
10	.4877		.4954	.4572	.4572	.5525
11		.4954	.4382	.4572	.4191	.5335
12	.5312	.5716	.381	.4572	.4191	.5716
13	.5281	.5525	.4191	.4572	.4001	.5716
14	.4321	.5716	.4191		.4572	.5716
15	.506	.5716	.4001	.4191	.4954	.5716
16	.4534	.5716		.4191	.4001	.5716
17	.5335	.6097	.4191	.381	.4191	.6478
18	.4572	.4954	.4954	.4572	.4191	.4954
19	.5906	.6859		.6097	.6478	.6097
20	.8383	.8002	.5906	.743	.9145	.8383
21	.8764	.7621	.6478	.8383	.8383	.7811
22	.7621	.724	.6478	.724	.724	.724
23	.5487	.3163	.5335	.381	.3906	.3658
24	.3353	.5247	.3048	.442	.4268	.3353
Max	.8764	.8002	.6478	.8383	.9145	.8383
Min	.3353	.3163	.3048	.381	.3906	.3163
Avg	.5215	.5307	.4499	.5444	.5155	.5365

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274099 / 33/11 KV VALSANG

Feeder No / Name : 205 / 11 KV HANJAGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762		.4321	.3353	.3353	.4167
2	.0953		.4268	.3395	.3658	.4115
3	.0953		.4268	.3858	.381	.4218
4	.0953		.4531	.3963	.4012	.4374
5	.0953		.4843	.4321	.4687	.442
6	.0953		.5468	.4999	.5312	.5487
7	.0762		.6874	.5944	.578	.6718
8	.0572		.6481	.5944	.6636	.6401
9	.4877		.0572	.0572	.0572	.0572
10	.571		.0381	.0381	.0381	
11	.5487		.0381	.0381	.0381	.0191
12	.5556		.0381	.0381	.0381	.0381
13	.5864		.0381	.0381	.0381	.0572
14	.5639		.0381	.0381	.0381	.0572
15	.4268		.0381	.0572	.0572	.0572
16	.5468		.0381	.0381	.0572	.0572
17	.4268	.0762	.0572	.0381	.0381	.0572
18	.0381	.0762	.0762	.0572	.0572	.0572
19	.0572	.0762	.0762	.0762	.0572	.0762
20	.0572	.0953	.1143	.0762	.0953	.1143
21		.0953	.0953	.1143	.0953	.0953
22		.0762	.0953	.0953	.0762	.0762
23		.3963	.3201	.3353	.381	.381
24	.0762		.4115	.3201	.3201	.4115
Max	.5864	.3963	.6874	.5944	.6636	.6718
Min	.0381	.0762	.0381	.0381	.0381	.0191
Avg	.2680	.1274	.2365	.2097	.2170	.2436

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274099 / 33/11 KV VALSANG

Feeder No / Name : 206 / Kardehalli

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6093	.2858	.2477	.2477	.2477	.2477
2	.6173	.2667	.2477	.2286	.2286	.2477
3	.6401	.2858	.2286	.2286	.2286	.2477
4	.6722	.2858	.2286	.2286	.2667	.2667
5	.6722	.3429	.2477	.2667	.3048	.2858
6	.9442	.381	.2858	.3429	.362	.362
7	1.3717	.3048	.2667		.2858	.2858
8	1.3117	.2096	.2286		.2096	.1905
9	.1334	.8025	1.0031	.6859	.8535	.9755
10	.1715		1.0669	.7811	1.0936	.8488
11	.1715	1.1584	1.0974	.7522	1.1265	1.1279
12	.0953	1.1279	1.1574	.7316	1.2191	1.1561
13	.1143	1.078	1.1092	.7621	1.1992	1.1584
14	.0953	1.078	1.078	.8951	1.0364	1.0936
15	.1524	1.0364	1.0669	.884	1.0936	1.078
16	.1715	1.0936	1.0822	.8688	1.0669	1.1069
17	.1905	.1524	.1524	.1143	.1524	.1524
18	.2096	.1715	.1905	.1715	.1715	.1905
19	.2858	.2477	.2667	.2477	.2477	.2477
20	.362	.3429	.3429	.3239	.381	.3239
21	.362	.3048	.362	.362	.362	.2858
22	.3429	.3048	.3239	.3048	.3239	.3239
23	.3239	.2667	.2667	.2858	.2667	.2667
24	.5864	.3048	.2667	.2667	.2667	.2477
Max	1.3717	1.1584	1.1574	.8951	1.2191	1.1584
Min	.0953	.1524	.1524	.1143	.1524	.1524
Avg	.4420	.5145	.5339	.4537	.5414	.5299

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274100 / 33/11 KV WADAKBAL

Feeder No / Name : 201 / 11 KV HATTUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8488	1.5089	1.6289	1.4575	1.6975	1.5432	1.4842
2	.8488	1.5432	1.6289	1.406	1.6975	1.5432	1.5384
3	.8488	1.6975	1.6289	1.4746	1.6975	1.5432	1.5565
4	.8488	1.6975	1.6289	1.4403	1.8861	1.5432	1.4842
5	.9431	2.0748	1.7604	1.5384	2.2634	1.7147	1.6004
6	1.1317	2.6406	1.9433	1.9204	2.5463	1.8861	2.0062
7	.9431	2.6406	2.2672	2.13	2.5463	2.4863	2.2138
8	.9054	3.3951	2.4006	2.0805	2.6406	2.4006	2.3482
9	2.3577	.6602		.5658	.5658	.6224	.5658
10	2.6406	.6602		.5281	.5658	.5658	.5658
11	2.4379	.6036		.5281	.5658	.6036	.5658
12	2.6433	.5658		.5281	.5658	.6036	.5658
13	2.6406			.5281	.5658	.6602	.5658
14	2.6406			.4904	.5658	.6602	.5658
15	2.6406			.4904	.6224	.6602	.5658
16	2.4897	.4904		.5281	.6036	.6413	.5658
17	.415	.5658		.5281	.6224	.6036	.6036
18	.4536	.7545		.6413	.7545	.679	.7545
19	.6036	.9431		.8299	.9054	.8488	.7922
20	.9431	.9431		1.1317	1.0374	1.094	1.1317
21	.9431	.9431		1.1317	1.0374	1.0185	1.0374
22	.8488	.9054		.9431	.9431	.9431	.9431
23	1.5089	.9054		1.6975	1.5432		1.3717
24	.9054	1.5089	1.6289	1.5089	1.6975	1.5432	1.5203
Max	2.6433	3.3951	2.4006	2.13	2.6406	2.4863	2.3482
Min	.415	.4904	1.6289	.4904	.5658	.5658	.5658
Avg	1.4346	1.3166	1.8351	1.0853	1.2557	1.1482	1.1214



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274100 / 33/11 KV WADAKBAL

Feeder No / Name : 202 / 11KV WADAKBAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1886			.2829		
2		.1886		.2829	.0943		.2772
3		.1886	.2614		.0943		
4		.1886		.2801	.2829		.2772
5		.1886			.4715	.3658	
6		.1886	.5658	.462	.4715	.4572	.4668
7		.4715			.571	.5487	
8	.0943	.5658	.5601	.5658	.5658	.5487	.6468
9	.3772	.0943		.0943	.0943	.0943	.0943
10	.3772			.0943	.0943	.0943	.0943
11	.3772			.0943			.0943
12	.3772		.0943	.0943		.0943	.0943
13	.3772			.0943			.0943
14	.3772			.0943		.0943	.0943
15	.3772			.0943			.0943
16	.3772	.0943		.0943	.0943	.0943	.0943
17	.0943			.0943			.0943
18	.0943		.1509	.0943		.1132	.0943
19	.0943			.0943			.0943
20	.0943			.0943		.1886	.0943
21	.0943		.1463	.0943	.0943		.0943
22	.0943	.0943		.0943		.1132	.0943
23	.1886	.2561	.2641	.2829	.2743		.2832
24	.1524	.3772	.2614	.2715	.2829	.2743	.2829
Max	.3772	.5658	.5658	.5658	.571	.5487	.6468
Min	.0943	.0943	.0943	.0943	.0943	.0943	.0943
Avg	.2364	.2373	.2880	.1733	.2692	.2370	.1777

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274100 / 33/11 KV WADAKBAL

Feeder No / Name : 203 / 11 KV RAJUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3772			.3772		
2		.3772		.3395	.3772		.3018
3		.3772	.3018		.3772		
4		.3772		.3395	.5281		.3018
5		.3772			.3772		
6		.4904	.4715	.5281	.5658		
7		.547			.5281		
8	1.8861		.5281	.4527	.415	.4527	.415
9	.2263	1.2003	1.5089	1.0374	1.5089	1.5432	1.1317
10	.2829			1.4146	1.3717	1.6834	1.3203
11	.2829	1.7147		1.5089			1.3203
12	.2829		1.5043	1.5089		1.5432	1.3203
13	.2829			1.5089			1.3203
14	.0943			1.5089		1.4419	1.3203
15	.2829		1.5089	1.5089			1.3203
16	.2829	1.3375		1.5089	1.7147	1.3923	1.3203
17	.3395	.1509	.1886	.2832	.1509	.1886	.3395
18	.415			.3395			.3395
19	.4904		.4527	.4527		.4527	.415
20				.5658			.5847
21			.5281	.5281	.5658	.4904	.5093
22	.4527	.415		.415		.3772	.4527
23	.3772	.3395	.3292	.3772	.3772		.3772
24	.1524	.3772	.3018	.3395	.3772	.3395	.3018
Max	1.8861	1.7147	1.5089	1.5089	1.7147	1.6834	1.3203
Min	.0943	.1509	.1886	.2832	.1509	.1886	.3018
Avg	.4088	.6042	.6931	.8233	.6408	.9005	.7743

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274100 / 33/11 KV WADAKBAL

Feeder No / Name : 204 / 11 KV AURAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.0566			.0566		
2	.2561	.0566		.0566	.0566		.0566
3	.2561	.0566	.0566		.0566		
4	.2561	.0566		.0566	.0566		.0566
5	.3292	.0566			.0566		
6	.4938	.0566	.0566	.0943	.0566		.0943
7	.6036	.0566			.0566		
8	.6401	.0566		.0754	.0566	.0566	.0754
9	.0566	.4572	.4207	.5281	.5281	.5487	.3772
10	.0566	.4755	.5658	.4904	.5487	.4904	.5658
11	.0566	.4755	.5658	.5281	.5487	.5281	.5658
12	.0566	.4572	.5658	.5093	.5487	.5658	.5658
13	.0566		.6036	.5281	.5487	.5658	.5658
14	.0566		.6036	.5281	.5487	.5281	.5658
15	.0566		.5658	.5093	.5487	.5544	.5658
16	.0566	.4904	.5658	.5281	.5144	.6348	.5658
17	.0566	.0566	.0566	.0566	.0566	.0566	.0566
18	.0566	.0566		.0566	.0566		.0566
19	.0566	.0566	.0943	.0566	.0566		.0566
20	.0566	.0566		.0566	.0566		.0566
21	.0566	.0566	.0754	.0566	.0566	.0943	.0566
22	.0566	.0566		.0566			.0566
23	.0566	.0566	.0566	.0566	.0566	.0754	.0566
24	.1524	.0566	.0566	.0566	.0566	.0566	.0566
Max	.6401	.4904	.6036	.5281	.5487	.6348	.5658
Min	.0566	.0566	.0566	.0566	.0566	.0566	.0566
Avg	.1705	.1553	.3273	.2443	.2254	.3658	.2537

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274100 / 33/11 KV WADAKBAL

Feeder No / Name : 205 / SINDHKHED AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0377			.0377		
2		.0377		.0377	.0377		.0377
3		.0377	.0377		.0377		
4		.0377		.0377	.0377		.0377
5		.0377			.0377		
6		.0377	.0377	.0566	.0377		.0754
7		.0377			.0377		
8		.0377		.0566	.0377	.0377	.0754
9	.0377						
10	.0377						
11	.0377						
12	.0377						
13	.0377						
14	.0377						
15	.0377						
16	.0377						
23	.0377	.0377		.0377	.0377		.0377
24		.0377	.0377	.0377	.0377	.0377	.0377
Max	.0377	.0377	.0377	.0566	.0377	.0377	.0754
Min	.0377	.0377	.0377	.0377	.0377	.0377	.0377
Avg	.0377	.0377	.0377	.044	.0377	.0377	.0503

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274100 / 33/11 KV WADAKBAL

Feeder No / Name : 206 / 11 KV MANGOLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5658	.7682	.7316	.7922	.7682	.724
2		.5658	.7682	.7392	.7922	.7682	.724
3		.5658	.7682	.7392	.7922	.7682	.724
4		.6602	.7682	.7392	.8488	.7682	.7316
5		.7164	.823	.8048	.9431	.8779	.8059
6		1.0374	.8573	.924	1.1317	1.0059	.8954
7		1.1317	1.1145	1.0974	.7545	.9431	.9955
8	.0566	1.0374	1.1145	1.1203	1.0374	.9431	1.1088
9	1.0374	.0566	.0566	.0566	.0566	.0566	.0566
10	1.1317				.0566	.0754	.0566
11	1.1317			.0566	.0566		.0566
12	1.1385		.0566	.0566		.0566	.0566
13	1.0374						.0566
14	.9431						.0566
15	.9431		.0566				.0566
16	.9431	.0566			.0566	.0566	.0566
17	.0566						.0566
18	.0566		.0754	.0566		.0754	.0566
19	.0566			.0566			.0566
20	.0566			.0566		.0943	.0566
21	.0566		.0943	.0566	.0566		.0566
22	.0566			.0566	.0566	.0566	.0566
23	.5658	.811	.7023	.7922	.7682		.679
24	.0566	.5658	.7682	.7392	.7922	.7682	.7392
Max	1.1385	1.1317	1.1145	1.1203	1.1317	1.0059	1.1088
Min	.0566	.0566	.0566	.0566	.0566	.0566	.0566
Avg	.5485	.6475	.5861	.4933	.5620	.5052	.3717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274100 / 33/11 KV WADAKBAL

Feeder No / Name : 207 / 11 KV WANGI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7545	.823	.8764	.9431	.823	.8145
2		.7545	.823	.8764	.9431	.823	.823
3		.7545	.823	.8954	.9431	.823	.823
4		.7545	.823	.8954	.9431	.823	.8316
5		.7545	.9145	1.0059	1.1317	.9145	.8192
6		.9431	1.0288	1.0974	1.1317	.9431	1.1336
7		1.5089	1.1831	1.267	1.3203	.9431	1.0059
8	.4527	.9431	1.2346	1.3717	1.4146	.8573	.7362
9	.9431	.4338	.3772	.3395	.3961	.3772	.1886
10	.9431		.1886	.3018	.3395	.1886	.1886
11	.9431		.1886	.2641	.2829	.1886	.2641
12	.9431		.1509	.2641	.2452	.1886	.2641
13	.9431				.2263	.2263	.2641
14	.9431		.1886		.2641		.1886
15	.9431		.2263		.2641	.2263	.2263
16	.9431	***	.2263		.2641	.2263	.2829
17	.2641		.2263		.2829	.2641	.3395
18	.3772		.2641	.3584	.3395	.2641	.3772
19	.4527		.4527	.4904	.4527	.4527	.4527
20	.6036		.5658	.5658	.6036	.5658	.5847
21	.5281		.5281	.5281	.5658	.5281	.5093
22	.4527		.415	.4904	.4904	.415	.4527
23	.7545	.8413	.8779	.9431	.7716		.7545
24	.3395	.7545	.823		.9431	.823	.8145
Max	.9431	29.5974	1.2346	1.3717	1.4146	.9431	1.1336
Min	.2641	.4338	.1509	.2641	.2263	.1886	.1886
Avg	.6923	3.2329	.5805	.7129	.6459	.5402	.5475

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274113 / 33/11 KV KUMBHARI

Feeder No / Name : 201 / 11 KV GODUTAI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8215	1.1203	.961	.9335	.9335	.9431	.9709
2	.8215	1.0829	.924	.8962	.9335	.9054	.8962
3	.7842	1.0269	.8316	.8589	.8589	.8299	.8962
4	.7842	1.0829	.8686	.8215	.8589	.8488	.8589
5	.7468	.8402	.8501	.8215	.8215	.8488	.8215
6	.7468	.7468	.8501	.8215	.7842	.811	.8589
7	.7468	.7468	.6838	.7468	.7468	.7922	.8215
8	.7468	.7468	.6653	.6722	.7468	.7922	.8215
9	.7468	.7468		.7468	.7468	.7842	.7468
10	.6722	.6722	.6653	.7468	.7095	.7468	.7468
11	.6722	.6348	.5914	.6722	.6722	.7842	.7468
12	.6908	.5975	.6348	.5975	.6722	.7842	.7468
13	.7468	.6413	.6722	.6722	.7095	.8215	.7468
14	.7468	.6413	.6722	.6722	.7468	.7842	.7095
15	.7468	.6413	.7095	.7468	.7468	.8215	.7095
16	.7842	.6413	.6722	.7468	.7468	.8215	.6722
17	.8402	.6413	.5975	.8215	.7468	.8215	.7468
18	.9149	.6036	.7468	.9709	.7282	.7842	.8215
19	1.1203	.8501	1.1203	1.0456	1.0642	1.0456	.9335
20	1.1763	1.2012	1.2696	1.0829	1.3443	1.2696	1.0456
21	1.3256	1.2012	1.2696	1.2323	1.307	1.2696	1.1576
22	1.251	1.2012	1.2696	1.307	1.2696	1.2696	1.1949
23	1.1203	1.1088	1.0456	1.1949	1.0642	1.1203	1.0269
24	.8962	1.1203	.924	.9709	1.0456	1.0829	1.0456
Max	1.3256	1.2012	1.2696	1.307	1.3443	1.2696	1.1949
Min	.6722	.5975	.5914	.5975	.6722	.7468	.6722
Avg	.8604	.8557	.8476	.8666	.8752	.9076	.8643

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274113 / 33/11 KV KUMBHARI

Feeder No / Name : 202 / 11 KV KUMBHARI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.9709	.7468	.3361	.3361	.3361	.3734
2	.2987	.9896	.7842	.3361	.2987	.3361	.3361
3	.2987	.8402	.7095	.4854	.2987	.3772	.3361
4	.2987	.8962	.7282	.5975	.2987	.415	.4854
5	.3361	.8962	.7095	.6722	.3361	.4527	.5975
6	.4854	.9335	.6722		.4854	.7167	.6348
7	.5975	1.1203	.7095		.5975	.7167	
8	.5228	.9149		.6722	.5601	.5658	.6722
9	.3734	.6161	.4481	.4904	.3734	.4481	.5228
10	.2987	.5281	.3734	.2614	.3734	.4294	.3361
11	.2801	.4527	.2263	.2241	.2614	.3734	.2987
12	.2801	.3772	.2641	.2241	.2427	.2987	.2614
13	.2427	.3772	.0191	.2241	.2427	.2987	.2614
14	.2427	.2452	.0191	.1867	.2427	.2987	.2241
15	.2241	.2241	.2957	.1867	.2427	.2614	.2241
16	.2427	.2614		.1867	.2614	.2614	.2241
17	.7468	.2614	.2926	.2614	.2987	.3018	.2987
18		.2987	.3734	.3361	.3174	.3734	.3734
19		.4108	.5228	.4481	.3921	.4481	.4481
20	.7095	.5601	.5975	.4108	.6348	.5975	.4481
21	.7095	.5228	.5228	.3734	.6535	.5228	.4481
22	.5601	.4294	.4481	.3734	.3734	.4481	.4108
23	.7655	.3547	.3734	.3361	.3361	.3734	.3734
24	.3361	1.0269	.3361	.3734	.3361	.3361	.3734
Max	.7655	1.1203	.7842	.6722	.6535	.7167	.6722
Min	.2241	.2241	.0191	.1867	.2427	.2614	.2241
Avg	.4175	.6045	.4624	.3635	.3664	.4161	.3897



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274113 / 33/11 KV KUMBHARI

Feeder No / Name : 203 / 11KV MICROWAVE  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366	.029	.0724	.0671	.061	.061	.0663
2	.0366	.029	.0869	.0671	.061	.061	.0663
3	.0373	.029	.1158	.0995	.0617	.061	.0983
4	.0366	.029	.1303	.1326	.0926	.0772	.1311
5	.0549	.029	.1448	.1581	.0926	.0781	.1581
6	.0732	.0434	.1448	.1543	.1219	.1562	.1698
7	.0732	.029	.2027	.1739	.1829	.2372	.208
8	.0732	.029	.2027	.213	.216	.1852	.2105
9	.1067	.0549	.0914	.0732	.0537	.0732	.0532
10	.1303	.037	.0732	.0549	.0549	.0549	.0366
11	.1448	.037	.0549	.0366	.0366	.0549	.0366
12	.1158	.037	.0366	.0366	.0549	.0537	.0366
13	.1158	.037	.0373	.0366	.0732	.0549	.0366
14	.1158	.037	.056	.0366	.0366	.056	.0366
15	.1158	.037	.056	.0366	.0366	.0549	.0366
16	.1158	.037	.0554	.0366	.0366	.0549	.0366
17	.0366	.037	.0549	.0366	.0366	.0549	.0366
18	.0366	.0554	.056	.0549	.0549	.056	.0549
19	.0549	.0739	.0739	.0732	.0914	.0549	.0549
20	.0732	.0739	.0724	.0732	.0732	.0732	.0549
21	.0549	.0554	.0724	.0549	.0549	.0549	.0549
22	.0366	.0554	.0554	.056	.0732	.0549	.0366
23	.0305	.0724	.0549	.061	.0457	.0732	.064
24	.0366	.0297	.0724	.0509	.061	.061	.0671
Max	.1448	.0739	.2027	.213	.216	.2372	.2105
Min	.0305	.029	.0366	.0366	.0366	.0537	.0366
Avg	.0726	.0422	.0864	.0781	.0735	.0774	.0767

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274113 / 33/11 KV KUMBHARI

Feeder No / Name : 204 / 11 KV LOKMANGAL MEDICAL NON SHEDDABLE EXPRESS HV FEEDERS  
EXPRES Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0762	.0762	.0953	.0953	.0953	.0953
2	.0762	.0762	.0762	.0953	.0762	.0953	.0953
3	.0762	.0762	.0762	.0762	.0762	.0762	.0762
4	.0572	.0762	.0572	.0762	.0572	.0762	.0762
5	.0572	.0953	.0762	.0762	.0572	.0762	.0762
6	.0572	.0953	.0762	.0762	.0762	.0762	.0572
7	.0572	.0762	.0762	.0762	.0762	.0762	.0762
8	.0762	.0762	.0762	.0762	.0762	.0572	.0953
9	.1143	.0953	.1143	.1143	.0953	.0762	.1143
10	.1334	.1524	.1334	.1143	.1524	.0953	.1143
11	.1334	.1524	.1334	.1334	.1524	.0953	.1334
12	.1334	.1334	.1334	.1334	.1524	.0953	.1334
13	.1334	.1334	.1334	.1334	.1334	.0953	.1334
14	.1524	.1334	.1524	.1334	.1143	.0953	.1143
15	.1524	.1334	.1143	.1334	.1143	.0762	.1143
16		.1334	.1143	.1143	.0953	.0762	.1143
17	.1334	.1143	.1143	.1143	.0953	.0762	.1143
18	.1143	.0953	.0953	.1143	.0953	.0762	.0953
19	.1143	.0953	.0953	.0953	.0953	.0762	.0953
20	.0953	.1143	.0953	.0953	.0953	.0953	.0953
21	.1143	.1143	.0953	.0953	.0953	.0953	.0953
22	.1143	.1143	.1143	.0953	.0953	.1143	.0953
23	.0953	.0953	.1143	.0953	.0953	.0953	.0953
24	.0953	.0762	.0762	.0953	.0953	.0953	.0953
Max	.1524	.1524	.1524	.1334	.1524	.1143	.1334
Min	.0572	.0762	.0572	.0762	.0572	.0572	.0572
Avg	.1036	.1056	.1008	.1024	.0985	.0858	.1000

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274113 / 33/11 KV KUMBHARI

Feeder No / Name : 205 / 11 KV MINAXI TAI SANE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.3109	.3292	.2926	.2926	.3292	.3292
2	.2926	.2743	.2743	.2926	.2926	.3292	.3292
3	.2926	.2743	.2743	.2743	.2561	.3292	.2926
4	.2926	.2743	.2926	.2743	.2561	.3292	.2743
5	.2561	.2561	.2926	.2561	.2195	.2561	.2743
6	.2195	.2378	.2926	.2926	.2195	.2561	.2743
7	.2195	.2378	.2561	.2378	.2195	.2561	.2743
8	.2195	.2195		.2378	.2195	.2743	.2378
9	.2195	.2378	.2195	.2378	.2195	.2561	.2378
10	.2195	.2195	.2195	.2195	.2195	.2561	.2195
11	.2195	.1829	.1463	.2195	.2195	.2195	.2195
12	.2195	.1829	.1646	.1829	.2195	.2195	.2195
13	.1829	.1829	.1829	.1829	.1829	.2427	.2195
14	.2012	.1829		.1829	.2195	.2241	.2195
15	.2378	.1829	.1829	.2195	.2378	.2195	.2195
16	.2195	.2195	.1646	.2195	.1646	.2195	.2195
17	.2378	.2012	.1829	.2195	.1829	.2378	.2561
18	.2561	.1829	.2012	.2561	.1829	.2241	.2561
19	.2926	.2561	.3109	.3292	.3292	.3292	.2926
20	.3841	.3658	.4024	.3658	.4108	.4024	.3292
21	.4024	.3658	.4024	.4024	.3921	.3841	.3658
22	.3841	.3841	.4024	.4024	.3734	.4024	.3658
23	.3475	.3475	.3292	.3658	.3547	.3658	.3292
24	.3292	.3292	.2926	.3292	.3292	.3292	.3658
Max	.4024	.3841	.4024	.4024	.4108	.4024	.3658
Min	.1829	.1829	.1463	.1829	.1646	.2195	.2195
Avg	.2698	.2545	.2644	.2705	.2589	.2871	.2759

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274113 / 33/11 KV KUMBHARI

Feeder No / Name : 206 / 11 KV KUMBHARI AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.7011	.6135	.2454	.5258	.7362	.7011
2	.1829	.7362	.8413	.2804	.7011	.7362	.7011
3	.1829	.7537	.9114	.3155	.8413	.7362	.7712
4	.181	.8589	1.0517	.4207	1.1218	.8413	1.0166
5	.2172	.7011	1.1744	.4557	1.3321	.8764	1.1218
6	.2507	1.2269	1.0166	.3155	1.4022	1.2269	1.3321
7	.3224	1.2971	1.5775	1.5775	1.4022	1.6126	1.6827
8	.2561	1.4022	1.6126	1.262	1.4022	1.6126	1.6126
9	.9114	.2012	.2103	.2149	.1463	.2195	.1791
10	1.1568	.1928	.1928	.1829	.1829	.2012	.1829
11	.5258	.1753	.1402	.1463	.1829	.1829	.1463
12	1.1393	.1753	.1402	.1463	.1463	.1463	.1463
13	1.1043	.1753	.1433	.1463	.1646	.1463	.1463
14	1.0517	.1753	.1433	.1829	.1463	.1433	.1463
15	1.0517	.1753	.1433	.1829	.1463	.1433	.1463
16	1.0517	.1753	.1791		.1463	.1433	.1463
17	.1463	.1753	.2149		.1463	.1463	.1829
18	.1463	.1753	.2149		.1463	.1463	.2195
19	.2012	.2103	.2507	.1829	.1646	.2195	.2195
20	.2743	.2279	.2865	.1829	.2743	.2195	.2195
21	.2378	.2103	.2865	.2195	.2743	.2195	.1829
22	.2195	.1928	.2149	.2195	.2378	.2195	.1829
23	.631	.5258	.2103	.5258	.7011	.6173	.5258
24	.1829	.7011	.5258	.2454	.5258	.7011	.6661
Max	1.1568	1.4022	1.6126	1.5775	1.4022	1.6126	1.6827
Min	.1463	.1753	.1402	.1463	.1463	.1433	.1463
Avg	.4920	.4809	.5123	.3643	.5192	.5081	.5241

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274141 / 33/11 KV AHERWADI

Feeder No / Name : 202 / 11 KV AHERWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.6097	.4778	.6097	.6401	.4988	.6859
2	.2667	.6401	.4371	.7316	.6401	.4464	.7926
3	.2667	.6706	.5502	.9907	.6401	.5213	.9755
4	.1905	.7468	.7375	1.0479	.6554	.7164	1.0802
5	.2667	.8749	.8796	.888	.6874	.823	1.1265
6	.3048	1.078	1.012	1.0669	.9962	.9602	1.3279
7	.3048	1.1717	1.2041	1.1431	1.2163	1.2193	1.3717
8	.1905	1.1717	1.1145	1.2193	1.2323	1.1589	1.2498
9	.6173	.1905	.1905	.1524	.1715	.1905	.1905
10	.8124	.1905	.1905	.1524	.1905	.1905	.1905
11	.9217	.1905	.1905		.1715	.1905	.1905
12	.9145	.1905	.1524		.1715	.1524	.1905
13	.8688	.1715	.1524		.1715	.1905	.1905
14	.953	.1715	.1524	.1905	.1905	.1905	.1905
15	.9962	.1524	.1524	.1905	.1905	.1905	.1905
16	1.0242	.1715	.1905	.2096	.1715	.1905	.1905
17	.1905	.1715	.2286	.2477	.1524	.2286	.1905
18	.1905	.1905	.2286	.3048	.1715	.3048	.2667
19	.2477	.2667	.381	.3429	.2667	.3429	.3048
20	.2858	.3048	.4191	.3239	.3048	.4191	.3239
21	.2667	.2858	.3429	.2858	.2858	.381	.2667
22	.2286	.2667	.3048	.2477	.2667	.3429	.2477
23	.5182	.431	.4572	.6097	.5281	.503	.5487
24	.3048	.5792	.5068	.5335	.6401	.5135	.6097
Max	1.0242	1.1717	1.2041	1.2193	1.2323	1.2193	1.3717
Min	.1905	.1524	.1524	.1524	.1524	.1524	.1905
Avg	.4765	.4537	.4439	.5471	.4480	.4528	.5372

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274141 / 33/11 KV AHERWADI

Feeder No / Name : 203 / 11 KV Madre

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9602	.3048	.362	.3048	.3429	.362	.3429
2	.9907	.3239	.362	.3048	.3239	.381	.3429
3	1.0517	.381	.362	.3048	.3429	.381	.3048
4	1.1111	.4572	.4382	.3429	.4954	.5335	.3429
5	1.1574	.5335	.5144	.4572	.6668	.6097	.3429
6	1.2193	.6097	.6287	.6097	.8192	.7621	.4572
7	1.2193		.5525	.743	.6859	.743	.6668
8	1.1431	.5144	.4001	.6097	.5525	.5525	.5716
9	.4763	1.1138	1.1265	1.0669	1.1126	1.1873	1.0669
10	.3429	1.1288	1.1126	1.1873	1.1431	1.1431	1.1431
11	.2667	1.0987	1.1126	1.1405	1.1728	1.1574	.8383
12	.2667	1.1111	1.0669	1.0936	.8655	1.1111	1.0974
13	.2858	1.0269	.9145	1.1043	.8655	1.1574	1.0957
14	.2667	1.086	.9145	1.0402	1.0122	1.2037	1.0936
15	.2477	.9002	.9145	.7116	1.189	1.1431	1.0957
16	.2667	1.0623	.9145	1.0562	1.174	1.1431	1.1092
17	.2858	.2286	.2858	.3048	.2286	.2858	.2858
18	.1905	.4191	.3429	.3239	.2667	.3429	.5335
19	.4382	.5525	.5716	.3239	.5144	.5716	.6097
20	.5906	.5716	.6287	.5525	.5716	.5716	.5716
21	.5335	.4572	.5716	.5144	.4954	.5144	.5144
22	.4001	.4191	.4572	.4572	.4382	.4572	.4572
23	.3429	.381	.381	.381	.362	.381	.3429
24	.9145	.3048	.362	.3429	.3429	.362	.381
Max	1.2193	1.1288	1.1265	1.1873	1.189	1.2037	1.1431
Min	.1905	.2286	.2858	.3048	.2286	.2858	.2858
Avg	.6237	.6516	.6374	.6366	.666	.7107	.6503

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274150 / 33/11 KV KARKAL

Feeder No / Name : 201 / 11 KV LAWANGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
23	.061
24	.1524
Max	.1524
Min	.061
Avg	.1067

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274150 / 33/11 KV KARKAL

Feeder No / Name : 202 / 11 KV KARKAL

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-AUG-17
HR	Load (MW)
23	.0762
24	.1524
Max	.1524
Min	.0762
Avg	.1143



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274150 / 33/11 KV KARKAL

Feeder No / Name : 203 / 11 KV AUJ (M)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
23	.0762
24	.1524
Max	.1524
Min	.0762
Avg	.1143

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274150 / 33/11 KV KARKAL

Feeder No / Name : 204 / 11 KV MALKAWATHE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
23	.0762
24	.0762
Max	.0762
Min	.0762
Avg	.0762

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274150 / 33/11 KV KARKAL

Feeder No / Name : 205 / 11 KV GAIKWAD WASTI  
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-AUG-17	05-AUG-17
HR	Load (MW)	Load (MW)
11		.0762
23	.0762	
24	.1524	
Max	.1524	.0762
Min	.0762	.0762
Avg	.1143	.0762

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274150 / 33/11 KV KARKAL

Feeder No / Name : 206 / 11 KV PATIL NAGAR  
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-AUG-17
HR	Load (MW)
24	.0762
Max	.0762
Min	.0762
Avg	.0762

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274199 / 33/11 KV GUNJEGAON

Feeder No / Name : 201 / 11 KV AKOLE (M) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0743	.5201	.743	.6241	.5944	.5201	.5944
2	.0743	.5201	.8322	.639	.5944	.5201	.6241
3	.0743	.5201	.8768	.639	.5944	.5201	.6836
4	.0892	.5201	.9214	.6687	.6687	.5944	.8619
5	.1189	.5201	.8916	.6687	.743	.6687	.9511
6	.2229	.743	.8619	.8025	.8173	.8173	1.0105
7	.208	.9659	1.0402	.9808	1.0402	.9659	1.0551
8	.1635	.8916	1.07	.9511	.9659	.9957	.9659
9	.9659	.0892	.1189	.0892	.1486	.1337	.104
10	.9362	.0892	.0743	.0743	.104	.104	.104
11	.8916	.0743	.0594	.0743	.0743	.0892	.0743
12	.8916	.0594	.0743	.0743	.0594	.0743	.0743
13	.743	.0594	.0594	.0743	.0594	.0743	.0594
14	.8173	.0743	.0743	.0743	.0594	.0743	.0743
15	.8173		.0743	.0743	.0743	.0743	.0743
16	.8173	.0743	.0743	.0743	.0743	.0594	.0743
17	.104	.0892		.0743	.0892	.0892	.0743
18	.1189	.1189	.1337	.0743	.1189	.104	.0594
19	.1635	.1486	.1486	.1486	.1635	.1486	.1189
20	.208	.1932	.1635	.1486	.1783	.1486	.1486
21	.1783	.1486	.1337	.1486	.1486	.1337	.1486
22	.1189	.104	.104	.1486	.104	.1189	.1189
23	.535	.743	.6539	.6687	.5201	.6093	.6687
24	.0743	.5201	.743	.6241	.6687	.5201	.5944
Max	.9659	.9659	1.07	.9808	1.0402	.9957	1.0551
Min	.0743	.0594	.0594	.0743	.0594	.0594	.0594
Avg	.3919	.3386	.4316	.3591	.3610	.3399	.3882

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274199 / 33/11 KV GUNJEGAON

Feeder No / Name : 202 / 11 KV KANDALGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3321	1.1069	1.1069	1.2809	1.186	1.2651	1.3283
2	.3163	1.1069	1.1069	1.2651	1.186	1.2651	1.3283
3	.3163	1.1069	1.2967	1.2967	1.2651	1.2651	1.3599
4	.3321	1.1069	1.3599	1.2809	1.4232	1.2651	1.4232
5	.3953	1.1069	1.4864	1.4232	1.5813	1.3441	1.5023
6	.5851	1.5497	1.692	1.692	1.6604	1.4232	2.0557
7	.5218	2.0557	2.2771	2.2455	2.1348	1.8501	2.1032
8	.4111	1.8976	2.1696	2.0557	2.0557	1.8976	1.9766
9	1.8501	.3163	.3269	.3795	.3953	.3479	.3163
10	2.0557	.2846	.3479	.2846	.3163	.3321	.3163
11	1.9766	.2846	.2688	.2372	.3163	.3005	.3163
12	1.8976	.2688	.3005	.2372	.2688	.2846	.3005
13	1.8185	.253	.2846	.2372	.3163	.2846	.3163
14	1.7394	.253	.3005	.3163	.3163	.253	.3163
15	1.7394		.3163	.3163	.3163	.253	.253
16	1.7394	.2688	.2688	.2372	.3163	.2688	.2846
17	.3163	.2846		.3163	.2846		.3005
18	.3637		.4111	.3163	.3163	.2846	.3163
19	.3953	.506	.4586	.3953	.427	.4428	.4744
20	.5535	.5851	.5218	.5535	.4586	.4428	.5376
21	.5376	.4111	.4428	.4744	.427	.4111	.506
22	.427	.3953	.3479	.3953	.3953	.427	.4428
23	1.1069	1.1385	1.2967	1.3441	1.2651	1.3283	1.2492
24	.3321	1.1069	1.0753	1.2809	1.2651	1.4175	1.2967
Max	2.0557	2.0557	2.2771	2.2455	2.1348	1.8976	2.1032
Min	.3163	.253	.2688	.2372	.2688	.253	.253
Avg	.9191	.7906	.8463	.8276	.8289	.8110	.8592

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274199 / 33/11 KV GUNJEGAON

Feeder No / Name : 203 / 11 KV GUNJEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1163	.1417	.1417	.1595	.1772	.1772	.1417
2	1.134	.1417	.1595	.1595	.1772	.1772	.1595
3	1.1517	.1595	.1772	.1595	.1772	.1772	.1595
4	1.1517	.1772	.3544	.1772	.1772	.2126	.1772
5	1.1871	.2481	.3189	.2126	.2658	.2481	.2658
6	1.5238	.3012	.3012	.2835	.2658	.2835	.3189
7	2.0376	.2835	.3366	.3012	.3544	.3189	.3012
8	1.825	.2658	.3189	.2658	.2658	.2481	.2658
9	.1932	1.7718	1.825	1.5769	1.4175	1.6832	1.5415
10	.1417	1.7364	1.9313	1.6301	1.5238	1.825	1.6124
11	.124	1.7364	1.7541		1.5415	1.5769	1.5947
12	.124	1.5415	1.6832	1.5947	1.5415	1.5592	1.4706
13	.0886	1.5238	1.5947	1.6832	1.5061	1.5061	1.3466
14	.0886	1.5061	1.4706	1.6832	1.5061	1.4529	1.3643
15	.1063		1.4175	1.5061	1.5061	1.3289	1.3643
16	.1063	1.4883	1.4883	1.3289	1.4706	1.3289	1.134
17	.124	.124	.1595	.1772	.1595	.1063	.124
18	.1772	.1595	.2126	.1772	.1417	.124	.124
19	.1949	.2126	.2481	.2658	.2481	.2303	.2126
20	.2835	.2835	.2835	.2658	.2835	.2126	.2658
21	.2481	.2303	.2481	.2681	.2658	.2126	.2481
22	.2126	.1949	.2126	.1772	.1949	.1949	.2303
23	.1772	.1772	.1595	.1772	.1772	.1772	.1595
24	1.1163	.1772	.1417	.1595	.1772	.1772	.1417
Max	2.0376	1.7718	1.9313	1.6832	1.5415	1.825	1.6124
Min	.0886	.124	.1417	.1595	.1417	.1063	.124
Avg	.6097	.6340	.7058	.6256	.6467	.6475	.6135

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274202 / 33/11 KV INGALAGI

Feeder No / Name : 201 / 11 KV KANBAS

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3953	.1905	.2286	.2096	.2096	.2096	.1905
2	.4428	.1905	.2286	.1905	.2096	.2096	.1905
3	.4428	.1905	.2096	.1905	.2096	.2286	.1905
4	.4744	.1905	.2096	.1905	.2286	.2286	.1905
5	.6009	.2286	.2477	.2286	.3048	.2667	.2858
6	.7116	.2667	.2667	.3048	.381	.3239	.3048
7	.8697	.3048	.2096	.2858	.3048	.3429	.3429
8	.8381	.1905	.1715	.1905	.2286	.2286	.2286
9	.1143	.5182	.6802	.5571	.571	.5182	.4915
10	.1143	.6401	.8322	.5921	.5937	.5735	.5601
11	.0762		.7907	.6241	.6718	.7373	.578
12	.0762		.8002	.5693	.6562	.7865	.5468
13	.0953		.7907	.5921	.679	.7373	.5401
14	.0953		.7116	.6882	.6249	.6554	.6481
15	.0953		.6562	.68	.4744	.7373	.679
16	.0953		.703	.6562	.5535	.6554	.7343
17	.0572	.1334	.0762	.1143	.1143	.0953	.1143
18	.1334	.1524	.1905	.1143	.1334	.1334	.1334
19	.1905	.2667	.2286	.2096	.1905	.2286	.2286
20	.3048	.3048	.2858	.2667	.2667	.3429	.2667
21	.2858	.3239	.3048	.2667	.2667	.2858	.2858
22	.2286	.2667	.2858	.2477	.2477	.2667	.2477
23	.2286	.2096	.2286	.2286	.2096	.2286	.2286
24	.3953	.1905	.2096	.2096	.2096	.2286	.1905
Max	.8697	.6401	.8322	.6882	.679	.7865	.7343
Min	.0572	.1334	.0762	.1143	.1143	.0953	.1143
Avg	.3068	.2644	.3978	.3503	.3558	.3854	.3499



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274202 / 33/11 KV INGALAGI

Feeder No / Name : 202 / 11 KV TILLEHAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4999	.2286	.2667	.2477	.2667	.2667	.2286
2	.5535	.2286	.2858	.2477	.2667	.2667	.2286
3	.5761	.2286	.2667	.2477	.3239	.2477	.2286
4	.7773	.2286	.2667	.2858	.3048	.2477	.2858
5	1.004	.2858	.3048	.2667	.381	.2858	.3429
6	1.0802	.3429	.4191	.381	.5335	.4382	.4001
7	1.3283	.381	.4001	.4763	.381	.4572	.4572
8	1.2346	.2858	.2858	.3048	.3048	.3429	.3048
9	.1715	.7842	1.0648	.7935	1.0623		1.1012
10	.1143	1.1523	1.2967	1.1498			1.1523
11	.1143		1.2811	1.1469	1.1561		1.1385
12	.1334		1.2346	1.0526	1.1544		1.1092
13	.1334		1.1873	1.0402	1.0753		1.0623
14	.1334		1.1111	1.0364	1.0279		1.0494
15	.1524		1.1279	1.0082	.9998		1.0802
16	.1524		1.1584	1.0722	.9488		1.2186
17	.1715	.1715	.1524	.1524	.1715		.1905
18	.2096	.1905	.1905	.1905	.2096		.1905
19	.3239	.3429	.2286	.3048	.3429		.2667
20	.4001	.381	.3048	.381	.381		.381
21	.3429	.3429	.3429	.3429	.362		.3429
22	.2858	.2858	.3239	.3048	.3048		.3429
23	.2667	.2667	.2858	.2858	.2667		.2667
24	.4999	.2667	.2667	.2667	.2667	.2667	.2667
Max	1.3283	1.1523	1.2967	1.1498	1.1561	.4572	1.2186
Min	.1143	.1715	.1524	.1524	.1715	.2477	.1905
Avg	.4441	.3552	.5856	.5411	.5431	.3133	.5682

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274202 / 33/11 KV INGALAGI

Feeder No / Name : 203 / 11 KV INGALGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.4428	.4321	.3163	.3395	.421	.5535
2	.2286	.4428	.4321	.3479	.3593	.4161	.5851
3	.2286	.4744	.4534	.3795	.3906	.4001	.6325
4	.3048	.6009	.4321	.3953	.4167	.5121	.7116
5	.381	.7116	.506	.6009	.4687	.9172	.7907
6	.4191	.7907	.8223	.7748	.571	.9686	.9488
7	.3239	.7907	.8539	.9804	.8535	1.012	1.0279
8	.2286	.8223		.8223	.823	1.0595	.9488
9	.4744	.1715	.1524	.1524	.1905		.2286
10	.7116	.1524	.1334	.1334	.0762		.1905
11	.7773		.1334	.1334	.0953		.1524
12	.7907		.1524	.1334	.1715		.1524
13	.7907		.1524	.1334	.1524		.1524
14	.7432		.1524	.1524	.1524		.1524
15	.7116		.1524	.1334	.1524		.1524
16	.7116		.1715	.1715	.1905		.1715
17	.1905	.1715	.1715	.1715	.1715		.1905
18	.2096	.2096	.1905	.1905	.1905		.1905
19	.2477	.362	.2667	.2667	.362		.3048
20	.362	.381	.381	.381	.381		.381
21	.3239	.3429	.3429	.3429	.3429		.3429
22	.3048	.3048	.3048	.3048	.3239		.3048
23	.4744	.3605	.2846	.3125	.3605		.4572
24	.2286	.4744	.3887	.3163	.3437	.4049	.5535
Max	.7907	.8223	.8539	.9804	.8535	1.0595	1.0279
Min	.1905	.1524	.1334	.1334	.0762	.4001	.1524
Avg	.4332	.4448	.3245	.3353	.3283	.6791	.4282

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274207 / 33/11 KV NIMBARGI S/S

Feeder No / Name : 201 / NIMBARGI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.191	.2587	.2241	.2801	.2218	.3018	.2587
2	2.2786	.2614	.1848	.2641	.2241		.2241
3	2.3405	.2987	.2195	.2641	.2614		.2241
4	2.4863	.3326	.2614	.2987	.2926		.2957
5	2.8826	.439	.3326	.3292	.3326		.3292
6	3.2693	.5544	.3734	.3696	.4668		.3696
7	3.476	.4481	.415	.4572	.4108		.4108
8	3.437	.3326	.3326	.3734	.2772	.1886	.3142
9	.3326	3.0521	3.155	2.4006	2.8166	2.7435	3.0007
10	.2218	3.2526	3.2693	2.7092	3.1893	2.8656	3.1207
11	.2054	3.3303	3.2217	2.9647	3.3128	3.0013	3.086
12	.2218	3.2074	3.2693	2.692	2.2891	3.1722	3.0178
13	.2587	2.713	3.2693	2.8292	3.0687	3.1722	3.0521
14	.2587	2.9835	3.2217	2.9473	3.035	3.0007	3.0007
15	.2402	3.155	3.3065	3.1207	3.0178	3.1901	2.9673
16	.2614	3.1017	3.2579	3.1893	3.2602	3.2074	
17		.1867		.2241	.1848	.2033	.2987
18	.2402	.2263		.2218	.1886	.1867	.3361
19	.3881	.2218	.4668	.3142	.2241	.3326	.4024
20	.462	.2614	.4668	.4435	.2218	.4435	.462
21	.4854	.2641	.3772	.4481	.2614	.3921	.462
22	.4024	.2772	.3395	.4435	.2641	.3921	.4108
23	.3658	.2987	.2987	.3511	.2772	.3361	.3734
24	.1524	.2957	.2829	.2987	.2957	.2801	.3142
Max	3.476	3.3303	3.3065	3.1893	3.3128	3.2074	3.1207
Min	.1524	.1867	.1848	.2218	.1848	.1867	.2241
Avg	1.1677	1.2397	1.3885	1.1764	1.1831	1.5228	1.1622

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274207 / 33/11 KV NIMBARGI S/S

Feeder No / Name : 202 / SADEPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	1.1568	1.1736	1.2269	1.2689	.9114	1.2407
2	.2641	1.2209	1.3203	1.3146	1.3203	.7209	1.4251
3	.2263	1.2887	1.4737	1.3717	1.3413	.9536	1.6632
4	.2263	1.3717	1.5261	1.5432	1.4083	.9221	1.8861
5	.2987	1.4563	1.6651	1.6956	1.5089	1.1145	2.1498
6	.3326	1.6118	1.166	1.8442	1.6461	1.4022	2.4099
7	.4668	1.8724	1.5083	1.8442	1.8861	1.6278	2.6578
8	.3734	1.7703	1.4754	1.8652	1.9244	1.6118	2.7435
9	1.6461	.1867	.1886	.3734	.2241	.1886	.3734
10	1.8176	.1886		.2987	.2241	.2241	.3326
11	1.7147	.2218	.2614	.2957	.2263	.2241	.3326
12	1.8004	.2241	.3018	.2587	.1848	.2218	.3018
13	1.7661	.1886	.3018	.2587	.2241	.2012	.6584
14	1.6991	.1848	.2614	.2561	.2263	.2033	
15	1.7164	.2241	.2743	.2561	.2218	.1848	
16	1.7337	.2263	.2801	.2772	.1867	.2241	
17	.2218	.2587	.3018	.2402	.2263	.2218	.7316
18		.2614	.3361	.2218	.2614	.2218	
19	.2926	.2829	.3772	.2614	.2772	.2987	.823
20	.3734	.3326	.415	.4435	.3395	.3361	.9145
21	.4066	.3734	.3734	.4066	.3696	.2957	.8871
22	.3326	.2829	.3361	.3734	.2801	.2957	.8779
23	1.073	1.0288	1.0288	1.1869	.823	1.0174	2.8292
24	.2286	1.1065	1.1393	1.1145	1.2209	.8573	1.0852
Max	1.8176	1.8724	1.6651	1.8652	1.9244	1.6278	2.8292
Min	.2218	.1848	.1886	.2218	.1848	.1848	.3018
Avg	.8380	.7217	.7602	.8012	.7425	.6034	1.3162

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274219 / 33/11kV AURAD

Feeder No / Name : 201 / 11 KV SANJWAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.4877						
8	.4572	.0686	.0152	.0152	.0152	.0343	.0305
9	.0171						
10		.442	.4725				
11				.4001			
12					.4877		.4572
16	.0152	.4268	.381	.4115	.4115	.4801	.4268
24	.1524	.0171	.0152	.0152	.0152	.0171	.0171
Max	.4877	.442	.4725	.4115	.4877	.4801	.4572
Min	.0152	.0171	.0152	.0152	.0152	.0171	.0171
Avg	.2259	.2386	.2210	.2105	.2324	.1772	.2329

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274219 / 33/11kV AURAD

Feeder No / Name : 202 / 11 KV BANDALGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2					.442		
6		.4801		.4115			
7			.4572				
8	.0171	.4572	.0152	.3658	.3658	.3963	.4572
9	.4877	.0171		.0152	.0152	.0171	.0152
16	.3963	.0171	.0152	.0152	.0152	.0171	.0152
23	.0152						
24	.0171	.3048	.2743	.2896	.2439	.2591	.3048
Max	.4877	.4801	.4572	.4115	.442	.3963	.4572
Min	.0152	.0171	.0152	.0152	.0152	.0171	.0152
Avg	.1867	.2553	.1905	.2195	.2164	.1724	.1981

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274219 / 33/11kV AURAD

Feeder No / Name : 203 / 11 KV TEMPLE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.2401						.3658
6		.2439	.2267	.2134			
8	.1372	.2439	.1677	.1524	.1829	.2743	.2743
10						.0857	
11		.1029	.061	.08	.0762		
16	.2134	.1715	.0914	.0914	.1219	.1524	.1524
17	.0686		.0762				.1543
24	.1715	.1829	.1219	.1067	.1219	.2134	.1829
Max	.2401	.2439	.2267	.2134	.1829	.2743	.3658
Min	.0686	.1029	.061	.08	.0762	.0857	.1524
Avg	.1662	.1890	.1242	.1288	.1257	.1815	.2259

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 277016 / 132/33 kv mandrup

Feeder No / Name : 404 / Enrich Solar 1

Feeder KV- 33 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.0457
Max	.0457
Min	.0457
Avg	.0457



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 277016 / 132/33 kv mandrup

Feeder No / Name : 405 / 33KV NTPC2

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
23	.0457
Max	.0457
Min	.0457
Avg	.0457

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 277016 / 132/33 kv mandrup

Feeder No / Name : 407 / 33KV NTPC 1

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	.0457
Max	.0457
Min	.0457
Avg	.0457

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 277016 / 132/33 kv mandrup

Feeder No / Name : 409 / 33 KV NAMRATA

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
23	.0457
Max	.0457
Min	.0457
Avg	.0457

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 277016 / 132/33 kv mandrup

Feeder No / Name : 410 / Enrich Solar 2

Feeder KV- 33 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.0457
Max	.0457
Min	.0457
Avg	.0457

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 277016 / 132/33 kv mandrup

Feeder No / Name : 702 / 132 KV LOKMANGAL EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 132 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
23	.1829
Max	.1829
Min	.1829
Avg	.1829

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (A) S/DN.[086] BU 4086

Substation No/ Name :- 277026 / 132/11KV Navives S/Stn

Feeder No / Name : 201 / 11 KV Urja Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (A) S/DN.[086] BU 4086

Substation No/ Name :- 277026 / 132/11KV Navives S/Stn

Feeder No / Name : 205 / 11KV Shoubray

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	1.1317
Max	1.1317
Min	1.1317
Avg	1.1317

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (A) S/DN.[086] BU 4086

Substation No/ Name :- 277026 / 132/11KV Navives S/Stn

Feeder No / Name : 206 / 11KV Choupad

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	1.3523
Max	1.3523
Min	1.3523
Avg	1.3523



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (A) S/DN.[086] BU 4086

Substation No/ Name :- 277026 / 132/11KV Navives S/Stn

Feeder No / Name : 207 / 11KV Nirale wasti  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-AUG-17
HR	Load (MW)
24	.6068
Max	.6068
Min	.6068
Avg	.6068

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (A) S/DN.[086] BU 4086

Substation No/ Name :- 277026 / 132/11KV Navives S/Stn

Feeder No / Name : 208 / 11KV Hiraj Naka

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	1.262
Max	1.262
Min	1.262
Avg	1.262

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (B) S/DN.[087] BU 4087

Substation No/ Name :- 274008 / 33/11 KV Water Works

Feeder No / Name : 201 / 11KV WATER WORKS SOLAPUR SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4449	1.46	1.4784	1.4415		1.4632	1.4815
2	1.4266	1.4563	1.4632	1.3676	1.4842	1.4632	1.4266
3	1.4118	1.419	1.307	1.3443	1.4118	1.4415	1.4083
4	1.4083	1.4003	1.4003	1.363	1.3717	1.4045	1.423
5	1.5384	1.4523		1.3817	1.4266	1.5708	1.4784
6	1.6244	1.5655	1.3575	1.6244	1.5154	1.5524	1.5708
7	1.5497	1.4937	1.4784	1.4937	1.4815	1.4784	1.4784
8	1.4784	1.46	1.4784	1.423	1.4415	1.4784	1.5181
9	1.6461	1.4045	1.4045	1.4449		.6161	1.5546
10	1.7193	1.46	1.5181	1.4815		.5601	1.5708
11	1.7372	1.3937	1.6278	1.5927		.5544	1.6078
12	1.701	1.4299	1.4998	1.4842		.5914	1.5708
13	1.7558	1.5364	1.5524			.6535	1.587
14	1.6448	1.5364	1.5708	1.5746		1.3443	1.5684
15	1.7741	1.5912	1.7372	1.6461		1.587	1.6057
16	1.8111	1.6651	1.6632	1.6817		1.587	1.6244
17	1.6817	1.8107	1.5364	1.7372		1.4969	1.6078
18	1.7375	1.9404	1.7013	1.7013	1.7918	1.5384	1.5927
19	2.1357	2.0328	2.0953	2.0237	2.2262	1.8781	1.9136
20	2.1719	2.1845	2.0953	2.1132	2.1849	1.9342	1.949
21	1.9728		1.8461	1.8983	1.9366	1.8625	1.8625
22	1.8473		1.8461	1.8642	1.828	1.7737	1.8823
23	1.7187		1.6827	1.7193	1.7375	1.7375	1.7558
24	1.5339	1.531	1.5708	1.4969	1.5181	1.5729	1.5729
Max	2.1719	2.1845	2.0953	2.1132	2.2262	1.9342	1.949
Min	1.4083	1.3937	1.307	1.3443	1.3717	.5544	1.4083
Avg	1.6863	1.5821	1.6048	1.6043	1.6683	1.3809	1.6088

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (B) S/DN.[087] BU 4087

Substation No/ Name :- 274008 / 33/11 KV Water Works

Feeder No / Name : 202 / 11 KV DAV FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7865	.7947	.7712	.695	.7865	.7865	.8048
2	.7762	.9795	.7442	.695	.7316	.7682	.7865
3	.7499	.7682		.6584	.7316	.7316	.7682
4	.7499	.7392	.7522	.6653	.7207	.7577	.7655
5	.8131	.7392	.8145	.7023	.7392	.7762	.7842
6	.8686	.8215	.8507	.8131	.8215	.7947	.8029
7	.7865	.7842		.7947	.7282	.7023	.7655
8	.7682	.6653	.9145	.6767	.7207	.7577	.7865
9	.695	.6154	.7421	.6379	.6908	.7392	.7316
10	.724	.6335	.6805	.6626	.6348	.7095	.7023
11	.6626	.4572	.7265	.6268	.6653	.7095	.6535
12	.6024	.5121	.6268	.6154	.6268	.6653	.6468
13	.6516	.567	.7087	.6447	.6878	.6535	.6653
14	.6878	.5175	.6984	.6335	.6767	.6535	.6722
15	.695	.6099	.724	.6036	.7059		.6722
16	.7133	.5914	.6984	.6767	.695	.6653	.6722
17	.6805	.7023	.6201	.6154		.6697	.6584
18	.6805	.8402	.7186	.6024	.7964	.6626	.6335
19	.9036	.9335	.9114	.7011	.8954	.8589	.8238
20	.9922	1.0164	.9745	.9745	1.0387	.9671	.9774
21	.985		.9492	.9492	1.0679	.9671	1.0136
22	.9774		.9593	.9774	1.0498	.9145	.9877
23	.8596		.8413	.8596	.9328	.9425	.924
24	.8501	.7762	.8501	.7316	.8048	.8596	.8501
Max	.9922	1.0164	.9745	.9774	1.0679	.9671	1.0136
Min	.6024	.4572	.6201	.6024	.6268	.6535	.6335
Avg	.7775	.7174	.7853	.7172	.7804	.7701	.7729

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (B) S/DN.[087] BU 4087

Substation No/ Name :- 274008 / 33/11 KV Water Works

Feeder No / Name : 203 / 11 KV BHAVANI PETH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.6653	.5975	.5914	.6653	.6584	.6401
2	.6036	.6401	.5975	.5914	.6401	.6401	.6401
3	.6099	.6283	.6468	.567	.5487	.6219	.5853
4	.5853	.6219	.6468	.567	.5544	.6219	.5975
5	.6283	.6401	.5601	.5853	.5544	.6161	.6348
6	.6653	.7392	.5228	.7316	.7392	.6535	.6722
7	.6161	.6348	.5544	.6401	.6348	.5975	.6348
8	.6733	.6348	.6468	.6878	.6984	.6653	.6767
9	.6447	.6099	.6626	.7164		.6722	.6468
10	.6447	.6653	.6268	.7522		.7095	.5788
11	.7186	.5544	.6733	.6661		.7023	.5788
12	.6935	.6099	.7087	.6379		.7392	.5544
13	.7442	.5788	.6878	.6697		.7468	.5359
14	.724	.5415	.6468	.591		.7095	.5415
15	.7133	.5415	.7133	.7682		.7023	.5228
16	.6767	.5788	.6878	.7602		.7023	.5601
17	.8059	.6535	.7421	.7796		.7207	.6161
18	.8059	.8316	.8238	.7619	.7011	.6878	.6099
19	1.0692	.924	1.0867	1.0166	1.1218	.9882	.8063
20	1.0985	1.0269	1.0867	1.0099	1.0808	.9922	.8682
21	1.0517		.9671	.985	.9671	.9568	.8775
22	.9568		.8775	.9313	.9134	.8596	.8688
23	.823		.7682	.7682	.8326	.823	.7762
24	.6838	.6838	.5359	.6468	.6838	.7133	.7207
Max	1.0985	1.0269	1.0867	1.0166	1.1218	.9922	.8775
Min	.5853	.5415	.5228	.567	.5487	.5975	.5228
Avg	.7449	.6669	.7112	.7259	.7557	.7292	.6560

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (B) S/DN.[087] BU 4087

Substation No/ Name :- 274008 / 33/11 KV Water Works

Feeder No / Name : 204 / 11 KV SAMACHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4382	.4207	.3988	.3988	.4557	.4334	.4334
2	.4252	.3988	.3772	.3856	.3988	.4334	.4161
3	.4075	.3814	.3772	.3856	.3814	.3988	.4119
4	.4031	.3856	.3944	.3801	.3856	.394	.4119
5	.4207	.4207	.3988	.3982	.4031	.394	.4344
6	.4607	.4344	.3814	.4525	.4163	.394	.4344
7	.4525	.4298	.4207	.5068	.4656	.4298	.4525
8	.443	.4656	.4382	.4298	.4163	.4477	.4382
9	.4733	.4961	.5121	.5068		.5487	.4733
10	.6089	.5611	.5792	.543		.5487	.5316
11	.695	.567	.724	.6516			.567
12	.7522	.4706	.7421	.724		.6468	.567
13	.7701	.5792	.7602	.7133		.6535	.5373
14	.7421	.695	.7499	.7499		.6535	.543
15	.724	.6767	.7499	.6838		.5975	.543
16	.724	.6584	.7133	.6838		.5729	.543
17	.724	.695	.6805	.6697		.5973	.5611
18	.7343	.7762	.7796	.724	.724	.6661	.5847
19	.9036	.8686	.9391	.9391	.9955	.8063	.6935
20	.9214	.9335	.8859	.9214	.985	.7796	.6344
21	.6762		.631	.7011	.7442	.6661	.5658
22	.5935		.583	.5895	.5895	.5721	.5375
23	.5375		.5028	.5028	.5028	.5258	.4784
24	.4508	.4557	.4161	.4161	.4557	.4681	.4607
Max	.9214	.9335	.9391	.9391	.9955	.8063	.6935
Min	.4031	.3814	.3772	.3801	.3814	.394	.4119
Avg	.6034	.5605	.5890	.5857	.5546	.5490	.5106

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (B) S/DN.[087] BU 4087

Substation No/ Name :- 274008 / 33/11 KV Water Works

Feeder No / Name : 205 / 11 KV JODBHAVI PETH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2263	.2103	.2054	.2263	.2075	.2263
2	.2075	.2054	.2149	.1867	.2075	.2263	.2263
3	.2012	.2054	.197	.1867	.1886	.2075	.2075
4	.1829	.1886	.197	.1886	.1886	.2075	.2263
5	.2033	.2075	.2012	.2075	.2075	.2075	.2075
6	.2075	.2241	.2378	.2075	.2452	.2075	.2263
7	.2241	.2075	.2195	.1886	.1867	.1886	.2075
8	.2303	.2054	.2402	.2172	.2561	.2427	.2427
9	.2601	.2218	.2507	.2481		.2801	.2218
10	.2713	.2587	.2743	.2883		.2772	.2241
11	.3561	.2218	.3086	.285		.3326	.2427
12	.3077	.2075	.3391	.3113		.3361	.2427
13	.3239	.2427	.2984	.3052		.2801	.2561
14	.2915	.2075	.2658	.2601		.2801	.2561
15	.3315	.2452	.3155	.2835		.2587	.2587
16	.3149	.2427	.2743	.2774		.2587	.2587
17	.3391	.2801	.2883	.298		.2658	.2587
18	.3222	.3142	.3086	.2601	.3277	.2515	.3086
19	.39		.3944	.3561	.4239	.3601	.3121
20	.4031	.3734	.3681	.3814	.3856	.3506	.3506
21	.3544	.3174	.3582	.3366	.3403	.3224	.3403
22	.3045		.3403	.3439	.3439	.3258	.3109
23	.2743		.2772	.2987	.2801	.2957	.2801
24	.2103	.2452	.2614	.2241	.2452	.2452	.2452
Max	.4031	.3734	.3944	.3814	.4239	.3601	.3506
Min	.1829	.1886	.197	.1867	.1867	.1886	.2075
Avg	.2807	.2404	.2767	.2644	.2702	.2673	.2557

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (B) S/DN.[087] BU 4087

Substation No/ Name :- 274008 / 33/11 KV Water Works

Feeder No / Name : 207 / 11 KV PUMP HOUSE

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.3361	.3174	.3326	.3361	.2572	.3086
2	.3395	.3395	.3142	.3326	.3361	.2915	.3086
3	.3584	.3547	.3142	.3326	.3361	.3086	.3086
4	.3361	.3361	.3292	.3326	.3361	.0347	.3294
5	.3361	.3395	.3292	.3326	.3361	.3294	.3294
6	.3174	.3547	.3258	.1886	.3361	.3121	.3121
7	.3547	.3361		.1886	.1646	.3121	.3121
8	.3294	.3326	.3292	.1886	.16	.3121	.3052
9	.333	.3326	.2075	.2012	.2	.3086	.3391
10	.333	.3142	.3292	.2896	.2429	.3121	.3353
11	.3506	.3326	.3326		.2858	.3121	.3315
12	.3467	.3326	.2075		.3361	.2915	.3481
13	.3326	.3326	.3326		.3395	.3121	.3441
14	.3326	.3292	.3292	.3361	.3206	.3155	.3277
15	.3326	.3326	.3511	.3326	.2987	.298	.3277
16	.3326	.3326	.3511	.3361	.2987	.3012	.3441
17	.3142	.3361	.3326	.065		.3403	.3641
18	.3142	.3511	.3142	.3174	.3174	.3429	.3429
19	.3142	.3511	.3142	.3361	.285	.3429	.3601
20	.3142	.3511	.3142	.3361	.2458	.3601	.3561
21	.3142		.3142	.3361	.2753	.3601	.3601
22	.3142		.3142	.3174	.2753	.3429	.3601
23	.3361		.3326	.3361	.2429	.3121	.3294
24	.3361	.3361	.3475	.3326	.3174	.2915	.3121
Max	.3584	.3547	.3511	.3361	.3395	.3601	.3641
Min	.3142	.3142	.2075	.065	.16	.0347	.3052
Avg	.3316	.3378	.3167	.2905	.2879	.3042	.3332



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (B) S/DN.[087] BU 4087

Substation No/ Name :- 274133 / 33/11KV RAJENDRA CHOWK S/STN

Feeder No / Name : 201 / 11 KV SAKHAR PETH FEEDER SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.182	1.182	1.1999	1.1641	1.1765	1.2178	1.2536
2	1.1403	1.1403	1.1765	1.1403	1.086	1.1641	1.2178
3	1.1041	1.1041	1.1403	1.1041	1.0387	1.1283	1.1999
4	1.0791	1.0791	1.1157	1.0791	1.0387	1.086	1.1946
5	1.0425	1.0425	1.0608	1.0608	1.0745	1.086	1.1765
6	1.1088	1.1088	1.1088	1.1088	1.1283	1.0498	1.1888
7	1.0903		1.1458	1.1827	1.1222	1.086	1.2254
8	1.1157	1.2254	1.0791	1.1157	1.1157	1.0974	1.2437
9	1.2127	1.3169	1.1523	1.2071	1.1523	1.2437	1.3169
10	1.3575	1.448	1.3756	1.4299	1.39	1.3213	1.3169
11	1.5364	1.5181	1.4998	1.5546	1.5223	1.448	1.4118
12	1.576	1.4449	1.5023	1.7194	1.576	1.4632	1.3969
13	1.6297	1.39	1.5927	1.6461	1.6118	1.5023	1.4148
14	1.448	.8962	1.5384	1.4449	1.379	1.3937	1.3937
15	1.4632	1.4815	1.4815	1.39	1.4449	1.3611	1.3253
16	1.5023	1.39	1.4661	1.5546	1.4998	1.379	1.2071
17	1.6108	1.4661	1.5384	1.5939	1.5546	1.3937	1.2986
18	1.7193	1.6289	1.6832	1.5939	1.576	1.576	1.3432
19	2.0199	1.8804	2.1033	2.0508	2.073	1.858	1.8404
20	2.2325	1.9806	2.1033	2.2325	2.1794	1.9281	1.8604
21	1.9667	1.8604	1.8404	2.0553	1.9667	1.8054	1.701
22	1.701	1.5947	1.5947	1.6832	1.6478	1.6118	1.5947
23	1.3969	1.4148	1.3611	1.4175	1.5223	1.4327	1.4299
24	1.2357	1.2489	1.2536	1.1999	1.267	1.2536	1.267
Max	2.2325	1.9806	2.1033	2.2325	2.1794	1.9281	1.8604
Min	1.0425	.8962	1.0608	1.0608	1.0387	1.0498	1.1765
Avg	1.4363	1.3845	1.4214	1.4471	1.4226	1.3703	1.3675

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (B) S/DN.[087] BU 4087

Substation No/ Name :- 274133 / 33/11KV RAJENDRA CHOWK S/STN

Feeder No / Name : 202 / 11 KV NETAJI FEEDER SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5014	.5014	.5014	.5014	.5068	.5014	.5373
2	.4887	.4887	.4887	.4887	.4706	.5014	.5373
3	.4706	.4706	.4706	.4706	.4477	.4835	.5014
4	.4572	.4572	.4572	.439	.4477	.4706	.5068
5	.439	.439	.439	.4572	.4656	.4344	.4887
6	.462	.4805	.4805	.462	.4656	.4163	.4572
7	.4805	.462	.5175	.4805	.4706	.4344	.4755
8	.4938	.4755	.5121	.4755	.4755	.4572	.4938
9	.4805	.4938	.5121	.4938	.5121	.5121	.5304
10	.5792	.5068	.5304	.5792	.6283	.567	.462
11	.6219	.462	.6335	.6036	.6335	.5249	.4938
12	.6984	.4572	.6697	.5853	.5194	.5973	.4525
13	.6447	.4805	.5611	.6036	.591	.591	.5304
14	.6154	.4251	.6335	.6036	.5853	.5487	.4805
15	.5853	.5228	.6401	.6099	.6036	.4887	.4525
16	.6154	.5415	.6219	.6584	.695	.543	.4805
17	.6154	.4887	.591	.7164	.6516	.567	.499
18	.6984	.543	.6556	.691	.6661	.6268	.4784
19	.7619	.6626	.8589	.8842	.815	.7186	.6661
20	.8505	.7888	.8238	.8669	.8413	.7537	.691
21	.7712	.7265	.7362	.7712	.7796	.7186	.691
22	.7087	.6733	.6733	.691	.691	1.6118	.691
23	.6089	.6089	.5731	.5847	.591	.6447	.6154
24	.5194	.5249	.5194	.5194	.5249	.5194	.5792
Max	.8505	.7888	.8589	.8842	.8413	1.6118	.691
Min	.439	.4251	.439	.439	.4477	.4163	.4525
Avg	.5904	.5284	.5875	.5932	.5866	.5930	.5330

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274019 / 33/11 KV CIVIL

Feeder No / Name : 201 / 11 KV RAMLAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						1.3213	1.3394
2						1.267	1.3032
3						1.2308	1.267
4						1.2127	1.2308
5						1.2308	1.1946
6						1.2489	1.2127
7						1.2851	1.2489
8						1.2851	1.3032
9	1.4661	1.3756	1.5384				1.4661
10	1.7013	1.5604	1.8099				1.7194
11	1.8099		1.8461				1.7375
12	1.828	1.7556	1.7375				1.7737
13	1.8642		1.7556				1.7918
14	1.7737	1.7556	1.7194				1.7194
15	1.7918	1.7194	1.6651				1.647
16	1.8823		1.647				1.6651
17	1.8461	1.8099		1.8099	1.647		
18		1.8099		1.8099	1.7013		
19		1.9366		1.9547	2.0452		
20		2.1357		2.0271	2.009		
21		1.9909		1.9366	1.8461		
22		1.7737		1.7737	1.7375		
23		1.5384		1.5565	1.5746		
24	1.3937				1.3575	1.448	1.4299
Max	1.8823	2.1357	1.8461	2.0271	2.0452	1.448	1.7918
Min	1.3937	1.3756	1.5384	1.5565	1.3575	1.2127	1.1946
Avg	1.7357	1.7635	1.7149	1.8383	1.7398	1.2811	1.4735

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274019 / 33/11 KV CIVIL

Feeder No / Name : 204 / 11 KV BAPUJI NAGAR SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.9465	
2						.9114	
3						.929	
4						.9114	
5						.8939	
6						.929	
7						.9114	
8						1.0166	
9	.964	1.1043	.9114				1.1393
10	.9465	.964	.9114				1.0166
11	.8939						.9465
12	.8939	.8413	.8764				.8764
13	.929						.8764
14	.9114	.8589					.8764
15	.9114	.8589	.8764				.8939
16	.8764		.8413				.8764
17	.929	.8413	.8413	.8764	.9465		
18		.8589		1.3146	.964		
19		1.0341		1.4723	1.3672		
20		1.3321		1.6126	1.4899		
21		1.2269		1.5249	1.4022		
22		1.1919		1.4198	1.3321		
23		1.1218		1.2795	1.1919		
24	1.0341				1.0867	1.0341	
Max	1.0341	1.3321	.9114	1.6126	1.4899	1.0341	1.1393
Min	.8764	.8413	.8413	.8764	.9465	.8939	.8764
Avg	.9290	1.0195	.8764	1.3572	1.2226	.9426	.9377

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274019 / 33/11 KV CIVIL

Feeder No / Name : 205 / 11 KV JAGDAMBA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						1.1157	
2						1.0974	
3						1.0608	
4						1.0974	
5						1.134	
6						1.2254	
7						1.0974	
8						1.1888	
9	1.2986	1.0974	1.1523				1.262
10		1.3717	1.0974				1.262
11							1.1157
12		1.262	1.0059				1.1888
13							1.1888
14		1.1706					1.0974
15		1.134	1.0059				1.0425
16			.9877				1.0608
17		1.1706		1.2071	1.2437		
18		1.2437		1.4632	1.2803		
19		1.5181		1.6461	1.6827		
20		1.8473		1.8839	1.6827		
21		1.7558		1.7741	1.6095		
22		1.6461		1.701	1.5546		
23		1.6095		1.5729	1.4449		
24	1.2986				1.39	1.2071	
Max	1.2986	1.8473	1.1523	1.8839	1.6827	1.2254	1.262
Min	1.2986	1.0974	.9877	1.2071	1.2437	1.0608	1.0425
Avg	1.2986	1.4022	1.0498	1.6069	1.4861	1.136	1.1523

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274019 / 33/11 KV CIVIL

Feeder No / Name : 206 / 11 KV DAK BUNGLOW  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.8048	.8413
2						.7682	.823
3						.7499	.8048
4						.7316	.8048
5						.7682	.823
6						.7682	.8413
7						.7133	.8596
8						.7682	.9511
9	.9511	.9328	.8779				.9511
10	.8413	.9877	.9694				.9328
11	1.0059						.9328
12	1.0242	2.5057	.9877				.9694
13	.9877						1.0059
14	1.0242	2.524					.9877
15	1.0242	2.268	.8596				.9145
16	1.0059		1.1157				.9694
17	1.134	.9694		1.0608	.9328		
18		1.0974		1.0974	1.0974		
19		1.1523		1.1523	1.1523		
20		1.1888		1.2437	1.2071		
21		1.0974		1.1706	1.2254		
22		1.0242		1.0608	1.0608		
23		.9328		.9145	.9511		
24	.8779				.8413	.8779	.8962
Max	1.134	2.524	1.1157	1.2437	1.2254	.8779	1.0059
Min	.8413	.9328	.8596	.9145	.8413	.7133	.8048
Avg	.9876	1.3900	.9621	1.1000	1.0585	.7723	.9005

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274019 / 33/11 KV CIVIL

Feeder No / Name : 207 / 11 KV SHIDDHESHWAR PETH SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.2715	
2						.2534	
3						.2534	
4						.2534	
5						.2715	
6						.2715	
7						.2715	
8						.3077	
9	.3439	.3077	.2896				.3439
10	.2896	.3258	.3258				.3258
11	.3077						.2715
12	.362	.3801	.3439				.3439
13	.3439						.362
14	.3258	.362					.3439
15	.3258	.3077	.3077				.3439
16	.362		.3439				.362
17	.3258	.362		.3439	.3258		
18		.3801		.362	.3439		
19		.362		.3801	.3982		
20		.362		.3439	.3801		
21		.3439		.3439	.3439		
22		.3258		.3258	.3258		
23		.2896		.3077	.3258		
24	.2715				.2715	.2896	
Max	.362	.3801	.3439	.3801	.3982	.3077	.362
Min	.2715	.2896	.2896	.3077	.2715	.2534	.2715
Avg	.3258	.3424	.3222	.3439	.3394	.2715	.3371

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274019 / 33/11 KV CIVIL

Feeder No / Name : 208 / 11KV CIVIL EXPRESS  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.2149	.2328
2						.2149	.2328
3						.2149	.2507
4						.2149	.2507
5						.2328	.2686
6						.2507	.2686
7						.2686	
8						.2328	
9	.3582	.4119	.3045				.2865
10	.394	.3761	.3403				.3801
11	.394						.4163
12	.4119	.3761	.3582				.3439
13	.3761						.3582
14	.3403	.2865					.2507
15	.3403	.2865	.3224				.2507
16	.2686		.2865				.2686
17	.2507	.2686		.2686	.2686		
18		.2507		.2686	.2507		
19		.2507		.2865	.2507		
20		.2507		.2686	.2507		
21		.2507		.2507	.2507		
22		.2507		.2507	.2328		
23		.2328		.197	.2328		
24	.2328				.2149	.2149	.2328
Max	.4119	.4119	.3582	.2865	.2686	.2686	.4163
Min	.2328	.2328	.2865	.197	.2149	.2149	.2328
Avg	.3367	.291	.3224	.2558	.2440	.2288	.2861



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274095 / 33/11KV ADITYA NAGAR

Feeder No / Name : 201 / 11 KV Limyewadi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0791	1.0642	1.086	1.1157	1.0974	1.0679	1.134
2	1.0608	1.0269	1.0608	1.0974	1.0719	1.0679	1.0608
3	1.0425	.9522	1.0242	1.0608	1.0164	1.0317	1.0608
4	1.0425	1.0082	1.0269	1.0349	1.0349	1.0498	1.0608
5	1.134	1.0642	1.1389	1.1643	1.1273	1.0679	1.1458
6	1.39	1.3203	1.2696	1.3256	1.2197	1.1584	1.2696
7	1.3014	1.3392	1.3491	1.3491	1.386	1.1765	1.4003
8	1.1949	1.1128	1.2071	1.1827	1.2803	1.2696	1.363
9	1.0164	1.1128	1.0719	1.0903	1.1584	1.2136	1.251
10	.9328	1.1128	.8686	1.0164	1.0534	1.0829	1.0642
11	.823	.3772	.8501	.8131	.8688	.9522	.9511
12	.8048	.3584	.8316	.8501	.8775	.9055	.8962
13	.823	.3772	.7947	.8413	.9313	.961	.9145
14	.8048	.3206	.8501	.8413	.9313	.9425	.924
15	.823	.4715	.4435	.823	.9694	.9795	.9328
16	.8962	.3018	.8686	.8962	.9328	.9979	.9328
17	.8238	.4706	.9231	.905	.8962	1.0164	.961
18	1.0099	.9922	1.0166	.8869	.9134	1.0208	.9231
19	1.2269	1.3112	1.262	1.2445	1.2357	1.134	1.134
20	1.4148	1.4506	1.4175	1.448	1.4118	1.4299	1.5546
21	1.4327	1.4864	1.4148	1.448	1.3937	1.4266	1.4998
22	1.3073	1.3969	1.3611	1.39	1.3575	1.39	1.4998
23	1.1576	1.2489	1.2178	1.2071	1.2489	1.2986	1.3352
24	1.0791	1.0829	1.1222	1.1523	1.1273	1.1222	1.2071
Max	1.4327	1.4864	1.4175	1.448	1.4118	1.4299	1.5546
Min	.8048	.3018	.4435	.8131	.8688	.9055	.8962
Avg	1.0676	.9483	1.0615	1.091	1.1059	1.1151	1.1448

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274095 / 33/11KV ADITYA NAGAR

Feeder No / Name : 202 / 11 KV Modi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0829	1.0829	1.1088	1.0974	1.0974	1.1016	1.1088
2	1.0269	1.0642	1.1203	1.0974	1.0974	1.0456	1.0719
3	1.0269	1.0456	1.0269	1.0164	1.0164	1.0456	1.0349
4	1.0456	1.0456	1.0374	1.0269	1.0164	1.0642	1.0456
5	1.1016	1.0456	1.0374	1.1203	1.1203	1.1389	1.0642
6	1.2696	1.1317	1.1203	1.226	1.2136	1.1389	1.1506
7	1.2637	1.1576	1.1203	1.226	1.1203	1.1949	1.226
8	1.1763	1.1128	1.1203	1.1203	1.0349	1.1694	1.1128
9	1.1273	1.0082	1.1203	1.1506	1.0164	1.1883	1.1506
10	1.0791	1.1016	1.0269	1.094	1.0082	1.1389	1.094
11	1.0974	1.2323	.9709	1.1317	1.0642	1.0562	1.1088
12	3.1561		1.0269	1.1506	1.134	1.1203	1.0974
13	1.0974		1.1203	1.1576	1.0719	1.0456	1.0974
14	1.1706		1.1576	1.1763	1.0719	1.0269	1.2012
15	1.0425		1.0456	1.1016	1.1016	1.0269	1.1088
16	1.0242		1.0829	1.1576	1.1016	1.0082	1.0974
17	1.134	1.0498	1.1222	1.1827	1.1273	1.1576	1.2826
18	1.1765	1.2127	1.1641	1.2851	1.2127	1.1403	1.2197
19	1.4685	1.3394	1.4685	1.576	1.4998	1.5384	1.5912
20	1.7193	1.5912	1.6651	1.8099	1.647	1.6832	1.7924
21	1.5927	1.6278	1.5546	1.6278	1.5912	1.5546	1.6644
22	1.4118	1.4632	1.4266	1.5181	1.4449	1.423	1.5339
23	1.2752	1.2803	1.2803	1.2803	1.2803	1.2936	1.3676
24	1.1576	1.1389	1.1888	1.1888	1.1888	1.1576	1.1827
Max	3.1561	1.6278	1.6651	1.8099	1.647	1.6832	1.7924
Min	1.0242	1.0082	.9709	1.0164	1.0082	1.0082	1.0349
Avg	1.2802	1.1964	1.1714	1.2300	1.1783	1.1858	1.2252

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274095 / 33/11KV ADITYA NAGAR

Feeder No / Name : 203 / 11 KV Mahalaxmi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6653	.6535	.7316	.6335	.6335	.6767	.6154
2	.6653	.6535	.7316	.6335	.6335	.6584	.6154
3	.6468	.6348	.6268	.5487	.6335	.6401	.6584
4	.6468	.6348	.6401	.6401	.6401	.6219	.6468
5	.6908	.6535	.7316	.7392	.7316	.6219	.6653
6	.8775	.7733	.823	.7392	.823	.7682	.7468
7	.9425	.8488	.8145	.924	.9145	.8596	.7842
8	.8145	.7577	.8145	.823	.8145	.8596	.8589
9	.7602	.7392	.6878	.7499	.724	.6535	.7865
10	.724	.6653	.6878	.6584	.6516	.8869	.695
11	.6335	.6099	.6516	.5973	.631	.7421	.6584
12	.5973	.5544	.6154	.5249	.6241	.6878	.6401
13	.5973	.6653	.6516	.5373	.6415	.6697	.6401
14	.5611	.6468	.5973	.5552	.6379	.6516	.5487
15	.5792	.6099	.5611	.5731	.6447	.6516	.5487
16	.5973	.6099	.6154	.591	.6268	.6516	.6401
17	.5847	.5784	.631	.591		.6516	.6516
18	.5847	.5895	.6687	.6135	.6762	.6733	.6024
19	.7619	.7712	.7628	.7522	.7973	.7362	.7522
20	.9134	.8775	.9036	.8775	.8688	.8596	.8869
21	.9492	.8954	.9313	.8962	.8869	.8507	.9231
22	.8775	.9671	.8954	.8962	.905	.8688	.905
23	.7947	.905	.7164	.8145	.8145	.8326	.8326
24	.695	.6838	.7316	.724	.6401	.7316	.7602
Max	.9492	.9671	.9313	.924	.9145	.8869	.9231
Min	.5611	.5544	.5611	.5249	.6241	.6219	.5487
Avg	.7150	.7074	.7176	.6931	.7215	.7294	.7110

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274095 / 33/11KV ADITYA NAGAR

Feeder No / Name : 204 / 11 KV RAILWAY EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.2829	.2829	.2829	.2829	.2452	.2829
2	.2829	.3018	.2829	.2829	.2829	.2641	.2641
3	.3206	.2829	.2829	.2829	.2829	.2263	.2641
4	.2829	.3018	.2829	.2829	.1886	.2452	.2829
5	.3018	.2641	.2829	.2829	.1886	.2641	.2829
6	.3206	.3018	.2829	.3772	.2829	.3018	.3018
7	.2641	.2829	.2829	.2829	.2829	.2829	.2641
8	.2829	.3395	.2829	.2829	.2829	.2829	.2829
9	.3584	.3772	.2829	.3018	.2829	.3018	.3772
10	.3772	.3772	.3584	.3395	.3584	.2829	.415
11	.4527	.415	.3584	.3584	.3206	.2641	.3772
12	.3961	.4527	.3772	.3395	.3772	.2829	1.1317
13	.3772	.415	.3961	.3961	.415	.3395	.3772
14	.3584	.3584	.3584	.3961	.3772	.3018	.3772
15	.3772	.3584	.3772	.3961	.3584	.3018	.3772
16	.4338	.4527	.415	.3961	.3206	.2829	.3772
17	.3772	.415	.3961	.3961	.3395	.2452	.3772
18	.3961	.3772	.3961	.3395	.3018	.2829	.3584
19	.3584	.3772	.3961	.3961	.3206	.3395	.3584
20	.3584	.3584	.3584	.3395	.3584	.3584	.3772
21	.3772	.3206	.3395	.3395	.3395	.3584	.3584
22	.3584	.3206	.3206	.3584	.3584	.3395	.3395
23	.3395	.2829	.2829	.2829	1.2883	.2829	.3206
24	.2829	.3018	.2829	.2829	.2829	.2452	.3206
Max	.4527	.4527	.415	.3961	1.2883	.3584	1.1317
Min	.2641	.2641	.2829	.2829	.1886	.2263	.2641
Avg	.3466	.3466	.3316	.334	.3531	.2884	.3686

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274095 / 33/11KV ADITYA NAGAR

Feeder No / Name : 205 / 11KV GANGA EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	.0189	.0189	.0377	.0377	.0377
2	.0377	.0189	.0189	.0189	.0377	.0377	.0189
3	.0377	.0377	.0189	.0189	.0377	.0189	.0189
4	.0377	.0189	.0189	.0189	.0377	.0189	.0189
5	.0189	.0377	.0189	.0377	.0377	.0377	.0377
6	.0189	.0189	.0377	.0377	.0377	.0189	.0189
7	.0377	.0377	.0377	.0377	.0377	.0189	.0189
8	.0754	.0377	.0377	.0377	.0566	.037	.0566
9	.0739	.0754	.056	.056	.0377	.0566	.0566
10	.0739	.0566	.056	.0373	.0566	.0566	.0566
11	.0554	.0754	.056	.0747	.0566	.0754	.0566
12	.0924	.0566	.0747	.0747	.0754	.0566	.0754
13	.0739	.0566	.0747	.0747	.0566	.0377	.0754
14	.0739	.0566	.0747	.056	.0754	.0754	.0566
15	.0554		.112	.056	.0943	.0943	.0566
16	.0554		.0373	.056	.0754	.0377	.0754
17	.0754		.0377	.0377	.0747	.0377	.0566
18	.0754	.0377	.0566	.0754	.0747	.0377	.0754
19	.0566	.0566	.0377	.0566	.0754	.0377	.0754
20	.0754	.0566	.0566	.0566	.0566	.0377	.0566
21	.0566	.0566	.0377	.0566	.0566	.0377	.0377
22	.0566	.0377	.0566	.0566	.0566	.0377	.0377
23	.0377	.0377	.0377	.0566	.0377	.0189	.0377
24	.0377	.0377	.0377	.0189	.0377	.0377	.0377
Max	.0924	.0754	.112	.0754	.0943	.0943	.0754
Min	.0189	.0189	.0189	.0189	.0377	.0189	.0189
Avg	.0553	.0449	.0461	.0470	.0549	.0416	.0479

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274200 / 33/11KV GADDA MAIDAN

Feeder No / Name : 201 / 11KV COLLECTOR OFFICE

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8962	.8962	.9335	.9335	1.0082	.9709	.8962
2	.8589	.8589	.8402	.8402	.9335	.9335	.8589
3	.8589	.8589	.8402	.8215	.9335	.9335	.8589
4	.8589	.8402	.8215	.8029	.8962	.8962	.8215
5	.8775	.8402	.8589	.8589	.8962	.8962	.8962
6	.8962	.8589	.8962	.8962	.8589	.9335	.9149
7	.9335	.9896	.8962	.9335	.8589	.8589	.9335
8	1.0642	.9896	.9522	.9335	1.0269	.9896	1.0456
9	1.0829	1.0082	1.1389	1.1203	1.0829	.9896	1.1576
10	1.2136	1.307	1.251	1.2136	1.1949	1.0269	1.2696
11	1.4003		1.4003	1.251	1.3256	1.0456	1.3256
12	1.419		1.4937	1.5497	1.4563	1.2136	1.3817
13	1.4377		1.4377		1.4377	1.2323	1.363
14	1.363		1.363	1.4937	1.3443	1.2136	1.2883
15	1.3256		1.4377	1.4003	1.307	1.2136	1.2883
16	1.4563		1.4377	1.5123	1.3817	1.2136	1.363
17	1.475	1.4003	1.3817	1.5684	1.3817	1.2136	1.3817
18	1.3817	1.3443	1.419	1.4563	1.4003	1.0642	1.307
19	1.531	1.531	1.587	1.5497	1.587	1.3443	1.3256
20	1.531	1.5684	1.5123	1.643	1.587	1.4003	1.531
21	1.4003	1.4377	1.475	1.531	1.4937	1.4003	1.4003
22	1.2696	1.2883	1.2696	1.3443	1.3443	1.2883	1.3443
23	1.1576	1.1763	1.1949	1.1576	1.1949	1.2323	1.2323
24	.9335	1.0269	1.0082	.9709	1.0829	1.0456	1.0829
Max	1.531	1.5684	1.587	1.643	1.587	1.4003	1.531
Min	.8589	.8402	.8215	.8029	.8589	.8589	.8215
Avg	1.1926	1.1234	1.2019	1.2079	1.2089	1.1063	1.1778

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR

Feeder No / Name : 201 / 11 KV MIDC NO 3

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1802			.2058		.1905	.1612
2	.1802			.1907		.1905	.1543
3	.1781			.1311		.1905	.1433
4	.144			.2035		.1905	.1417
5	.1715			.1492		.1905	.2033
6	.1734			.1715		.2096	.1254
7	.2126			.2481		.2667	.1254
8	.5127			.514		.1943	.1075
9	.5735	.1075	.5546	.7775	.7287	.2241	.116
10	.7868	.1017	.5468	.771	.823	.3086	.1147
11	.8522		.744	.7602	.9179	.3725	.116
12	.8882		.7034	.7981	.8779	.3401	.116
13	.6676		.5702	.6287	.6954	.3277	.1214
14	.7002		.487	.6144	.7049	.2688	.124
15	.7716		.5639	.724	.7682	.3239	.1107
16	.6259		.5075	.6767	.6763	.2559	.1107
17		.0191	.4729	.6371	.6135	.2134	.0934
18		.0995	.3961	.4858	.6019	.1943	.0812
19		.0995	.285	.2883	.4096	.1886	.088
20		.0781	.1989	.2254	.2713	.218	.1505
21		.08	.1638	.2401	.2267	.1966	.1505
22		.1014	.1715	.2058	.2427	.1715	.0926
23		.0914	.197	.1949	.2058	.156	.1372
24	.1423			.1772		.2096	.128
Max	.8882	.1075	.744	.7981	.9179	.3725	.2033
Min	.1423	.0191	.1638	.1311	.2058	.156	.0812
Avg	.4565	.0865	.4375	.4175	.5843	.2330	.1255

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR

Feeder No / Name : 202 / 11KV Bhadrawati

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1524		.2096	.1524
2	.1715			.1524		.2096	.1524
3	.1715			.1715		.2096	.1334
4	.1715			.1524		.2096	.1524
5	.1715			.1524		.2096	.1715
6	.1715			.1715		.2096	.1715
7	.2427			.2614		.1905	.1524
8	.5571			.5571		.2641	.1715
9	.8124	.1475	.679	.6636	.6944	.3174	.1791
10	1.0111	.1949	.8951	.8796	.953	.4119	.1612
11	.9957	.1991	.9877	.9755	1.0517	.5552	.2601
12	1.0402	.1677	.8962	.9877	.884	.4706	.0709
13	.8642	.1844	.8482	.8642	.8429	.3292	.1214
14	.7253	.1526	.7522	.6249	.8025	.2534	.1389
15	.8796	.1115	.7842	.8802	.8573	.3856	.1646
16	.9488	.0747	.7926	.7968	.8951	.3721	.1646
17		.1524	.8333	.873	.888	.4344	.1696
18		.1334	.759	.7655	.703	.4525	.1357
19		.1143	.4805	.4706	.4572	.3258	.168
20		.1334	.3292	.2957	.3326	.3361	.1509
21		.1334	.2378	.2195	.2534	.3174	.1334
22		.1715	.2378	.2012	.2353	.2772	.1143
23		.1334	.1715	.1524	.2229	.1715	.1334
24	.1524			.1524		.2286	.1715
Max	1.0402	.1991	.9877	.9877	1.0517	.5552	.2601
Min	.1524	.0747	.1715	.1524	.2229	.1715	.0709
Avg	.5679	.1469	.6456	.4822	.6716	.3063	.1540



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR

Feeder No / Name : 203 / 11KV MIDC NO.4

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905			.1905		.1715	.1905
2	.1715			.1905		.1715	.1905
3	.1905			.1905		.1715	.1715
4	.1715			.1715		.1715	.1715
5	.1905			.1905		.1715	.1905
6	.1905			.1905		.1905	.1905
7	.2096			.2096		.1905	.1905
8	.602			.5468		.2452	.1715
9	.8145		1.2309	.8145	.8993	.3142	.1905
10	.9267		1.2041	.9305	.9587	.3547	.1905
11	1.0433		1.247	.9328	.9877	.3921	.1905
12	.9242		1.2483	1.0292	1.0014	.4066	.1905
13	.8655		1.0467	.7727	.8288	.3018	.1905
14	.7579		.8543	.7133	.7674	.2801	.1905
15	.8002		.7133	.8002	.9414	.2801	.1905
16	.8398		.6984	.7727	.9442	.2987	.1905
17		.0191	.5864	.6097	.7042	.3018	.2096
18		.2286	.5243	.5535	.68	.2957	.2286
19		.2286	.2829	.3018	.3921	.2286	.2096
20		.4001	.1905	.2402	.2858	.2096	.2096
21		.381	.1905	.2286	.2477	.1905	.1905
22		.362	.1905	.2096	.2427	.1905	.1905
23		.3429	.1905	.1905	.2477	.1905	.2096
24	.1905			.1715		.1905	.1715
Max	1.0433	.4001	1.2483	1.0292	1.0014	.4066	.2286
Min	.1715	.0191	.1905	.1715	.2427	.1715	.1715
Avg	.5341	.2803	.6932	.4647	.6753	.2462	.1921

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR

Feeder No / Name : 204 / 11 KV MIDC NO.5

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3696			.3696		.3326	.3547
2	.3658			.3475		.3142	.3326
3	.3696			.3475		.3206	.3326
4	.3547			.3475		.3206	.3109
5	.3696			.3696		.3206	.2926
6	.3921			.4108		.3206	.3142
7	.4755			.499		.3772	.3206
8	.8916			.8688		.5601	.2801
9	1.3937	.2686	1.3565	1.3546	.9934	.7164	.3326
10	1.5604	.2534	1.6278	1.5895	1.8031	.8779	.2865
11	1.643	.2743	1.848	1.6918	1.8945	.9492	.2865
12	1.5752	.2926	1.7924	1.46	1.9033	.6068	.2835
13	1.5009	.2743	1.4661	1.3523	1.6991	.6733	.2835
14	1.2323	.2534	1.0229	1.1149	1.189	.7602	.2427
15	1.3496	.2534	1.387	1.1873	1.576		.2454
16	1.5242	.2507	1.382	1.2631	1.5769		.2686
17		.2667	1.0822	.9957	1.2742		.2543
18		.2534	.9181	1.0279	1.1584		.2743
19		.3109	.7619	.8417	.8139		.3366
20		.3475	.5973	.5973	.6241		.3658
21		.3475	.4887	.4938	.5258		.362
22		.3475	.4024	.462	.4572		.3224
23		.3206	.3881	.3961	.4344		.3018
24	.3696			.3921		.3696	.3584
Max	1.643	.3475	1.848	1.6918	1.9033	.9492	.3658
Min	.3547	.2507	.3881	.3475	.4344	.3142	.2427
Avg	.9257	.2877	1.1014	.8242	1.1949	.5213	.3060

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR

Feeder No / Name : 205 / 11 KV SANKURI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905			.1905		.1905	.2096
2	.1905			.1905		.1905	.2096
3	.1905			.1905		.1905	.1905
4	.1715			.1905		.1905	.1905
5	.1905			.2096		.1905	.2096
6	.1905			.2477		.2096	.2096
7	.2477			.2477		.2286	.1905
8	.5079			.4999		.2858	.1715
9	.5468	.0629	.5765	.5944	.7362	.2896	.2096
10	.6173	.0671	.5851	.6371	.7074	.2561	.2096
11	.6622		.7011	.751	.7232	.3018	.2096
12	.7282		.602	.7145	.7093	.4207	.2096
13	.5624		.5197	.5639	.5721	.3206	.2096
14	.5138		.4816	.5401	.587	.3734	.2286
15	.5247		.6093	.6241	.7613	.3511	.2054
16	.5693		.578	.6249	.724	.3361	.2054
17		.0191	.5155	.5468	.7282	.3174	.2096
18		.1905	.39	.4973	.5344	.2957	.1905
19		.2096	.2477	.2477	.3361	.2096	.1905
20		.2096	.2286	.2286	.2667	.2096	.1905
21		.2096	.2096	.2096	.2286	.2096	.1905
22		.1715	.2286	.1905	.2241	.2096	.2858
23		.1905	.2096	.1715	.2263	.2096	.3048
24	.1905			.1905		.2096	.1905
Max	.7282	.2096	.7011	.751	.7613	.4207	.3048
Min	.1715	.0191	.2096	.1715	.2241	.1905	.1715
Avg	.3997	.1478	.4455	.3875	.5377	.2582	.2092

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR

Feeder No / Name : 206 / 11 KV VINKAR

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096			.2477			.2096
2	.1905			.2096			.1905
3	.1905			.2286			.1905
4	.1905			.2286			.1905
5	.2096			.2286			.2096
6	.2286			.2477			.2286
7	.3048			.3206			.2477
8	.5937			.7042			.2477
9	.9054	.1823	.6773	.8993	1.5604	.3395	.1715
10	1.0174	.1966	.8916	1.1138	1.0385	.5906	.3048
11	1.1294	.1585	1.0974	1.2498	1.2492	.4763	.3048
12	1.0151	.16	1.1265	1.2651	1.2037	.4973	.2858
13	.9998	.1547	.8097	1.0031	1.0517	.5258	.1524
14	.7375	.1783	1.1736	.8223	.9181	.5087	.1715
15	1.0185	.1572	.8642	1.0364	.9334	.5087	.2096
16	1.1105	.1715	.933	1.0212	1.142	.5548	.2096
17		.2096	.8333	.9842	1.0084	.5544	.1886
18		.2096	.8122	.7716	.9555	.5281	.1677
19		.2096	.5093	.543	.6447	.3961	.1715
20		.2286	.3921	.4251	.4572	.3584	.1524
21		.2286	.362	.3048	.3921	.2858	.1524
22		.1905	.2858	.2858	.3429	.2477	.1524
23		.2096	.2667	.3048	.2858	.2286	.1715
24	.2096			.2667			.2096
Max	1.1294	.2286	1.1736	1.2651	1.5604	.5906	.3048
Min	.1905	.1547	.2667	.2096	.2858	.2286	.1524
Avg	.6036	.1897	.7356	.6130	.8789	.4401	.2038

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR

Feeder No / Name : 404 / 33 kv BIDI GHARKUL  
Feeder KV- 33 / INCOMING

SHEDDABLE URBAN

DATE	02-AUG-17	03-AUG-17	04-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.0543
2			.0543
3			.0543
4			.0543
5			.0543
6			.0543
7			.0543
8			.0543
17	.9774	.0543	.0543
18		.0543	.0543
19		.0543	.0543
20	.0543	.0543	.0543
21	.0543	.0543	.0543
22	.0543	.0543	.0543
23	.0543	.0543	.0543
24			.0543
Max	.9774	.0543	.0543
Min	.0543	.0543	.0543
Avg	.2389	.0543	.0543

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR

Feeder No / Name : 405 / 33 KV CIVIL

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	7.951	1.4415	1.386	7.6681	1.386	8.175	8.1185
2	7.7246	1.3306	1.2752	7.4983	1.3306	7.9498	7.8509
3	7.5561	1.3306	1.2752	7.6127	1.3306	7.7235	7.6818
4	7.5561	1.3306	1.2752	7.4995	1.3306	7.6115	7.5686
5	7.9921	1.386	1.2752	7.7824	1.3169	7.78	7.9087
6	8.4802	1.4969	1.4415	8.4431	1.4266	8.1728	8.666
7	9.0158	1.5524	1.6832	9.2284	1.6832	8.2836	8.994
8	9.2759	1.6632	2.0885	10.4727	2.1125	9.1478	9.2701
9	11.5055	1.5364	10.5864	11.5621	11.0654	5.8345	9.1569
10	12.4955	1.5364	11.1415	11.9822	11.5427	7.4257	9.1569
11	13.1025		11.801	12.2188	3.5632	7.7492	8.8392
12	13.3048		11.9702	12.8178	12.7721	8.0058	8.8392
13	12.1994		11.0122	12.0062	11.6952	6.438	8.7277
14	11.6975		10.663	11.2775	11.3106	5.9906	8.4591
15	11.933		11.1997	11.294	11.5432	6.5895	8.4168
16	12.1399		10.9145	11.7644	11.9108	6.8918	8.4025
17	2.332	9.4993	10.715	11.5586	11.6667	9.4267	8.8244
18	2.2965	9.9965	11.6621	11.7284	11.7358	9.5771	8.5031
19	2.2885	12.1645	12.6647	14.0924	13.618	12.0622	11.2197
20	2.5766	13.3093	13.4488	14.1198	14.0586	12.6121	12.2805
21	2.392	12.4108	12.8104	12.8303	13.0915	12.4743	11.5536
22	2.1491	11.4912	11.378	11.9382	11.7119	11.6581	11.1802
23	11.6198	10.0366	9.9811	10.1498	10.1486	10.2418	9.8103
24	8.5134	1.5524	1.4969	8.6277	1.4415	8.9084	8.7397
Max	13.3048	13.3093	13.4488	14.1198	14.0586	12.6121	12.2805
Min	2.1491	1.3306	1.2752	7.4983	1.3169	5.8345	7.5686
Avg	8.2541	5.2814	7.7144	10.6739	7.6997	8.6137	9.0904

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274045 / 33/11 KV BIDI GHARKUL

Feeder No / Name : 201 / 11 KV BIDIGHARKUL  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-AUG-17
HR	Load (MW)
24	.905
Max	.905
Min	.905
Avg	.905

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274045 / 33/11 KV BIDI GHARKUL

Feeder No / Name : 203 / 11KV GANDHI NAGAR SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.6859	.8145	.6859	.7716	.7716	.6859
2		.6001	.7164	.6859	.7716	.7716	.6859
3	.8573	.6001	.7087	.6859	.7716	.6859	.6859
4	.9431	.6001	.7164	.6859	.7716	.6859	.6859
5	.9431	.6001	.724	.6859	.7716	.6859	.6859
6	.9431	.6001	.8059	.6859	.7716	.6859	.6859
7	.9431	.6859	.8059	.8573	.9431	.6859	.6859
8	1.6289	.6001	1.3575	1.3717	1.4575	.7716	.6859
9	1.6004	.6001	1.3937	1.5718	1.6651	.8573	.6535
10	1.7337	.6001	1.6137	1.7147	1.7861	.9116	.6535
11	1.8004	.6001	1.5927	1.8328	1.8671	.9945	.7468
12	1.9805	.6859	1.5927	1.8099	1.9471	.8383	.6535
13	1.7604	.6001	1.3889	1.5432	1.5203	.8383	.7468
14	1.5604	.6001	1.3117	1.406	1.5927	.8478	.7468
15	1.4861	.6001	1.3717	1.4861	1.6137	.7459	.6602
16	1.7147	.6001	1.3117	1.4661	1.5604	.7907	.6602
17	1.5242	.6001	1.3717	1.5384	1.5242	.8573	.6859
18	1.5432	.6859	1.3003	1.3441	1.448	.8573	.6859
19	1.286	.8573	1.1269	1.2003	1.3927	1.0288	.7716
20	1.2003	.8573	1.0517	1.2289	1.2955	.9431	.9431
21	1.0288	.8573	.8669	1.1022	1.1469	.9431	.9431
22	.9431	.8573	.8859	1.0059	1.0898	.9431	.8573
23	.9431	.7716	.7973	.9431	.9431	.8573	.6859
24	.8573	.6859	.8145	.6859	.8573	.7716	.7716
Max	1.9805	.8573	1.6137	1.8328	1.9471	1.0288	.9431
Min	.8573	.6001	.7087	.6859	.7716	.6859	.6535
Avg	1.3078	.6680	1.1017	1.1760	1.2617	.8238	.7230



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274045 / 33/11 KV BIDI GHARKUL

Feeder No / Name : 207 / 11 KV GADAGI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1145	1.1765	1.0288	1.0288	1.0288	1.0288
2	1.0288	1.0288	1.086	.9431	1.0288	1.0288	1.0288
3	1.0288	1.0288	1.0745	.9431	1.0288	1.0288	1.0288
4	1.0288	1.0288	1.086	.9431	1.0288	1.0288	1.0288
5	1.0288	1.0288	1.1765	1.0288	1.0288	1.0288	1.1145
6	1.1145	1.0288	1.1888	1.0288	1.2003	1.0288	1.1145
7	1.1145	1.0288	1.1888	1.0288	1.2003	1.0288	1.1145
8	1.0288	.9431	.9955	1.0288		1.0288	1.1145
9	1.0288	.8573	.924	1.0059	1.1765	1.1088	1.0164
10	.9431	.8573	.9955	1.086	1.1765	1.0745	.924
11	.9431	.8573	.8954	.8954	1.0517	1.086	.8402
12	.9431	.7716	.8954	.9955	1.0631	1.0059	.8402
13	1.0288	.7716	.905	.9955	1.1517	1.086	.8402
14	1.0288	.6859	1.0059	.9145	1.0745	1.0059	.9335
15	1.0288	.7716	1.0164	1.0164	1.0059	1.0164	.9431
16	1.0288	.8573	.924	1.0059	1.1888	1.0164	.9431
17	1.0288	.8573	.9536	1.0974	1.2536	.9431	.9431
18	1.1145	.8573	1.0631	1.1765	1.3575	1.1145	.9431
19	1.3717	1.0288	1.387	1.4327	1.6118	1.286	
20	1.5432	1.4575	1.6651	1.7718	1.8604	1.6289	1.5432
21	1.5432	1.4575	1.647	1.8099	1.8804	1.6289	1.6289
22	1.5432	1.4575	1.4737	1.7013	1.7194	1.5432	1.5432
23	1.3717	1.286	1.2403	1.3289	1.4632	1.3717	1.2003
24	1.1145	1.1145	1.1765	1.0288	1.0288	1.0288	1.0288
Max	1.5432	1.4575	1.6651	1.8099	1.8804	1.6289	1.6289
Min	.9431	.6859	.8954	.8954	1.0059	.9431	.8402
Avg	1.1294	1.0074	1.1309	1.1348	1.2438	1.1323	1.0732

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274191 / 33/11 KV POLYTECHNIC

Feeder No / Name : 201 / AMRAPALI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4338	.4527	.4481	.4338	.4527	.4527	.5093
2	.4338	.4338	.4108	.4338	.4527	.4527	.4904
3	.415	.415	.4108	.4338	.415	.4338	.4715
4	.415	.4108	.4108	.415	.415	.4338	.4527
5	.4294	.4481	.4108	.4108	.415	.4294	.4338
6	.5041	.4854	.4668	.4668	.4481	.4668	.5121
7	.6283	.5658	.5914	.5415	.5975	.5601	.5138
8	.8259	.6348	.78	.8684	.779	.6348	.5914
9	.9414	.5788	.8539	.9031	.9214	.6219	.5914
10	1.0059	.5601	.8592	.9755	.9633	.6767	.5914
11	1.0974		.9877	1.0536	1.0551	.6767	.5601
12	1.0822		.9686	1.0364	1.07	.6697	.5788
13	.9012		.8192	.9061	.953	.6154	.5415
14	.8642		.7935	.8436	.8642	.6219	.5281
15	.9722		.9122	.9217	.945	.6401	.5281
16	1.012		.8421	.9646	.9722	.6878	.5228
17	.9374	.7343	.8697	.9374	.9297	.6697	.5304
18	.9014	.7023	.8745	.933	.953	.7164	.4854
19	.8859	.823	.8775	.964	.964	.8048	.6584
20	.9671	.9328	.9231	.9774	.985	.8688	.7316
21	.9145	.8413	.8413	.8779	.8688	.823	.7023
22	.7392	.6283	.6653	.7023	.7023	.7762	.6653
23	.5788	.5415	.5228	.547	.5658	.6535	.5601
24	.4715	.5093	.4668	.4668	.4527	.5093	.5281
Max	1.0974	.9328	.9877	1.0536	1.07	.8688	.7316
Min	.415	.4108	.4108	.4108	.415	.4294	.4338
Avg	.7649	.5943	.7086	.7506	.7559	.6207	.5533

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274191 / 33/11 KV POLYTECHNIC

Feeder No / Name : 202 / 11 KV ASHOK CHOWK1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4207	.4525	.4024	.4163	.4525	.4572	.4163
2	.4207	.4207	.4024	.4163	.4344	.4572	.4024
3	.4024	.4207	.4024	.4163	.4344	.4572	.3841
4	.3982	.4207	.4024	.4163	.4344	.4572	.3841
5	.4477	.439	.3841	.4163	.4298	.4938	.3841
6	.5258	.4755	.4024	.4477	.4477	.543	.4835
7	.5487	.4755	.5028	.5138	.5434	.5611	.4458
8	.7579	.4887	.6802	.7977	.6859	.5316	.4961
9	.8642	.4525	.7529	.8623	.8522	.5784	.4961
10	.8792	.4706	.7613	.9054	.8387	.5426	.4961
11	.9198		.823	.8135	.9335	.5533	.4119
12	.9469		.8206	.9069	.9069	.5898	.4298
13	.7649		.6836	.8093	.8116	.547	.4119
14	.8002		.6984	.7472	.7545	.5375	.4207
15	.8036		.724	.743	.823	.5533	.4066
16	.7964		.6661	.7674	.7649	.547	.4207
17	.7472	.5028	.6537	.7002	.7407	.5735	.4298
18	.7385	.5068	.7133	.7095	.7573	.5304	.3801
19	.6874	.6201	.779	.8029	.7701	.6443	.5316
20	.8139	.7712	.7888	.823	.8551	.703	.631
21	.7455	.7362	.7362	.7888	.78	.6859	.5847
22	.6836	.691	.6588	.7186	.7011	.631	.5731
23	.5552	.5304	.5373	.5611	.5792	.543	.499
24	.4755	.4887	.4572	.4525	.4706	.5121	.4344
Max	.9469	.7712	.823	.9069	.9335	.703	.631
Min	.3982	.4207	.3841	.4163	.4298	.4572	.3801
Avg	.6727	.5202	.6181	.6647	.6751	.5513	.4564

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274191 / 33/11 KV POLYTECHNIC

Feeder No / Name : 203 / 11 KV PATHAN BAG1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5093	.5281	.5228	.4668	.5041	.5228	.5281
2	.4715	.4904	.4854	.4715	.4668	.4904	.5093
3	.4715	.4904	.4668	.4527	.4668	.4904	.4904
4	.4715	.4904	.4668	.4527	.4668	.4715	.4904
5	.4904	.4854	.4668	.4715	.462	.4904	.4904
6	.5228	.5228	.5601	.5041	.5175	.5281	.5121
7	.5975	.547	.5788	.6161	.5729	.547	.5487
8	.6859	.5228	.6733	.7108	.7108	.6283	.5228
9	.7042	.5228	.6859	.7122	.7209	.5544	.3734
10	.8619	.5415	.6874	.6802	.6882	.7701	.5228
11	.9054		.7127	.6964	.7287	.6984	.4481
12	.8551		.6718	.6464	.7116	.6805	.4481
13	.6443		.5765	.5801	.639	.6089	.4251
14	.7202		.5765	.5967	.6154	.5487	.4481
15	.7461		.6068	.6104	.6706	.567	.4715
16	.6588		.6024	.6241	.6344	.5853	.4481
17	.7011	.6516	.583	.5895	.6274	.5487	.4805
18	.6836	.6036	.6344	.6001	.6104	.5611	.4668
19	.7133	.695	.7265	.7619	.7011	.6626	.6516
20	.7964	.7783	.788	.788	.788	.7602	.7316
21	.7602	.7602	.7421	.7602	.7421	.7316	.695
22	.7499	.7392	.695	.7207	.7316	.7207	.7023
23	.6348	.6348	.5975	.6348	.6348	.6535	.6535
24	.547	.5658	.5601	.5228	.5041	.5601	.547
Max	.9054	.7783	.788	.788	.788	.7701	.7316
Min	.4715	.4854	.4668	.4527	.462	.4715	.3734
Avg	.6626	.5872	.6111	.6113	.6215	.5992	.5252

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 277012 / 132/33/11 KV SUB STATION

MIDC

Feeder No / Name : 201 / 11 KV SIDDHESHWAR  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17
HR	Load (MW)
24	.4668
Max	.4668
Min	.4668
Avg	.4668

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 277012 / 132/33/11 KV SUB STATION

MIDC

Feeder No / Name : 202 / 11 KV MIDC NO 1

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17
HR	Load (MW)
24	.4715
Max	.4715
Min	.4715
Avg	.4715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 277012 / 132/33/11 KV SUB STATION

MIDC

Feeder No / Name : 203 / 11 KV GANDHI NAGAR

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17
HR	Load (MW)
24	.2858
Max	.2858
Min	.2858
Avg	.2858

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 277012 / 132/33/11 KV SUB STATION

MIDC

Feeder No / Name : 204 / 11 KV POLYTECHNIC  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17
HR	Load (MW)
24	.1905
Max	.1905
Min	.1905
Avg	.1905



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 277012 / 132/33/11 KV SUB STATION

MIDC

Feeder No / Name : 205 / 11 KV YASHAWANT MILL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.4763
Max	.4763
Min	.4763
Avg	.4763

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 277012 / 132/33/11 KV SUB STATION

MIDC

Feeder No / Name : 207 / 11 KV MIDC NO 2

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17
HR	Load (MW)
24	.2858
Max	.2858
Min	.2858
Avg	.2858

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 277012 / 132/33/11 KV SUB STATION  
MIDCFeeder No / Name : 401 / 33 KV JULE SOLAPUR  
Feeder KV- 33 / INCOMING

SHEDDABLE RURAL

DATE	01-AUG-17
HR	Load (MW)
24	2.572
Max	2.572
Min	2.572
Avg	2.572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 277012 / 132/33/11 KV SUB STATION

MIDC

Feeder No / Name : 402 / 33 KV INDUSTRIAL ESTATE

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	01-AUG-17
HR	Load (MW)
24	2.572
Max	2.572
Min	2.572
Avg	2.572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 277012 / 132/33/11 KV SUB STATION

MIDC

Feeder No / Name : 403 / Hotgi

Feeder KV- 33 / INCOMING

DATE	01-AUG-17
HR	Load (MW)
24	.0572
Max	.0572
Min	.0572
Avg	.0572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 277012 / 132/33/11 KV SUB STATION

MIDC

Feeder No / Name : 404 / 33 KV BIDII GHARKUL

SHEDDABLE URBAN

Feeder KV- 33 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5624			.6316		.6241	.583
2	.6093			.583		.5761	.583
3	.6093			.6316		.5761	.5344
4	.5624			.6316		.5761	.5344
5	.6093			.6316		.5761	.583
6	.6562			.6802		.5761	.583
7	.8436			.9231		.6722	.583
8	2.0622			2.2348		.9122	.583
9	3.1402	.5155	2.7206	3.1093	3.255	1.2003	.583
10	3.5151	.5624	3.3522	3.7894	3.7894	1.2003	.6316
11	3.9838		3.3036	4.1295	4.2753	1.7284	.7287
12	3.7963		3.6008	3.9352	4.0324	1.7764	.5344
13	3.4214		2.9287	3.4008	3.5951	1.3443	.4858
14	2.8121		2.9635	2.7206	3.1093	1.3923	.4858
15	3.3276		2.8938	3.3036	3.5951	1.4403	.5344
16	3.5151		2.9887	3.255	3.6437	1.4883	.5344
17		.048	2.8327	3.0121	3.4494	1.4575	.5407
18		.4801	2.4966	2.6235	2.915	1.4575	.3932
19		.5281	1.5364	1.6518	1.749	1.166	.4915
20		.5761	1.1523	1.166	1.2631	1.0202	.4915
21		.5761	.9122	.8745	1.0202	.8745	.4915
22		.5761	.7682	.8259	.8745	.6802	.4915
23		.5344	.6722	.7202		.6316	.4915
24	1.134			.6802		.6722	.6316
Max	3.9838	.5761	3.6008	4.1295	4.2753	1.7764	.7287
Min	.5624	.048	.6722	.583	.8745	.5761	.3932
Avg	2.0683	.4885	2.3415	1.9227	2.8976	1.0258	.5462

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 277012 / 132/33/11 KV SUB STATION

MIDC

Feeder No / Name : 405 / 33 KV CIVIL

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	7.1862			6.8336		7.0165	7.1696
2	6.9599			6.6655		6.8467	6.9456
3	6.8467			6.7776		6.7901	6.7776
4	6.7901			6.7215		6.7901	6.6655
5	7.1862			7.0016		6.9599	7.1136
6	7.5257			7.5617		7.356	7.5617
7	8.035			8.2339		7.2428	7.7298
8	9.1667			10.0823		8.0659	7.9538
9	11.7696	7.8978	10.7545	11.5947	11.2603	8.1779	7.8418
10	12.8447	8.1219	11.7627	12.6029	12.392	8.85	7.7858
11	13.5803		12.6029	12.995	13.107	9.2981	7.5617
12	16.1523		12.7149	13.5551	13.5551	9.5222	7.7858
13	12.6183		11.4266	12.0428	11.8747	8.626	7.5617
14	11.7696		10.7545	11.3706	11.5387	8.626	7.3937
15	12.0525		11.3146	11.7627	12.0988	8.626	7.3937
16	12.2222		10.8665	11.8747	12.1548	8.794	7.3937
17		7.6389	10.5864	11.5947	11.8187	8.514	7.7298
18		8.3745	10.9785	11.3146	11.5387	8.2899	7.2817
19		10.1852	10.9785	12.2668	12.3228	10.3064	9.4662
20		11.3169	11.3706	12.0988	12.2108	10.8105	10.3624
21		10.5247	10.8665	10.8665	11.3146	10.6424	9.8023
22		9.9589	9.8583	10.3064	10.3064	9.9703	9.4662
23		8.738	8.738	8.9621	9.2233	8.738	8.57
24	7.5823			7.6178		8.2047	7.5617
Max	16.1523	11.3169	12.7149	13.5551	13.5551	10.8105	10.3624
Min	6.7901	7.6389	8.738	6.6655	9.2233	6.7901	6.6655
Avg	10.0170	9.1952	11.0383	10.1127	11.7811	8.4610	7.8698

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 277012 / 132/33/11 KV SUB STATION

MIDC

Feeder No / Name : 406 / 33 KV PAPER PLANT - I

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	01-AUG-17
HR	Load (MW)
24	.7716
Max	.7716
Min	.7716
Avg	.7716



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 277012 / 132/33/11 KV SUB STATION

MIDC

Feeder No / Name : 407 / 33 KV PAPER PLANT - II

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	01-AUG-17
HR	Load (MW)
24	1.286
Max	1.286
Min	1.286
Avg	1.286

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274003 / INDUSTRIAL ESTATE.

Feeder No / Name : 201 / 11KV RAMWADI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0277	.9671	.985	1.0631	.9568	1.0099	1.0454
2	1.0277	.9671	.9671	.9922	.9391	.9922	1.0099
3	1.0277	.8954	.9492	.9922	.9214	.9745	1.0099
4	.9745	.8954	.9313	.9922	.8859	.9568	.9922
5	.9745	.8954	.9313	.9922	.8682	.9214	.9745
6	.9745	.8775	.9134	1.0029	.8505	.8859	.9745
7	.9745	.8775	.9671	.9036	.8859	.8328	.9745
8	.9214	.8954	.9313		.8328	.8682	.9214
9	.8859		.9492	.9745	.9922	.8505	.9922
10	.9745		.9955		.9568		.9391
11	.9568		.9955	.9391	.9568		.9391
12	.9568		.9492	.9391			.9036
13	.9745		.9671	1.0099	.9214		.9214
14	.9568			.9214	.8859		.9214
15	.9391		.9745	.9922	.9214		.9568
16	.9922		.9568	.9922	.9568		.9922
17	.9745	1.1641	.9391	.9922		.8682	.9568
18	.9922	1.1283	1.0277	.9922	1.0985	.9036	.9214
19	1.1163	1.2715	1.2403	1.2934	1.2403	1.134	
20	1.3289	1.3611	1.2757	1.2934	1.258	1.2226	
21	1.2894	1.379	1.258		1.2403		
22	1.3253	1.2715			1.2403		1.2403
23	1.1283	1.182	1.1163	1.134	1.1163	1.1517	1.1517
24	1.0277	1.0029	1.0029	1.0631	.9745	1.0454	1.0808
Max	1.3289	1.379	1.2757	1.2934	1.258	1.2226	1.2403
Min	.8859	.8775	.9134	.9036	.8328	.8328	.9036
Avg	1.0301	1.0645	1.0102	1.0238	.9955	.9745	.9914

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274003 / INDUSTRIAL ESTATE.

Feeder No / Name : 202 / 11KV PRESS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1509	.1509	.1509	.1509	.1509	.1509
2	.1509	.1509	.1509	.1509	.1509	.1509	.1509
3	.1509	.1509	.1509	.1509	.1509	.1509	.1509
4	.1698	.1509	.1509	.1509	.1509	.1509	.1463
5	.1698	.1509	.1509	.1509	.1509	.1509	.1509
6	.1698	.1509	.1509	.1509	.1509	.1509	.1509
7	.1698	.1509	.1509	.1509	.1509	.1698	.1509
8	.1698	.1698	.1509	.132	.1509	.1698	.1509
9	.2641		.2641	.1886	.1886	.1698	.2075
10	.3206		.2829		.2829	.2641	.2641
11	.3772		.3206	.2452	.3772	.3018	.3206
12	.3206		.3206	.3206	.3206	.3772	.3395
13	.2829		.2075	.2641	.2452	.2829	.2452
14	.3395		.2075	.1886	.2829	.3206	.2829
15	.3206		.2829	.2829	.2829	.3206	.2263
16	.3584		.2263	.2075	.3206	.3584	.2263
17	.3018	.1509	.2452	.2075		.3206	.2452
18	.3018	.1509	.2263	.2263	.2829	.2829	.2075
19	.2075	.1463	.2075	.1886	.2075	.1509	
20	.2075	.1509	.1698	.1886	.1886	.1509	
21	.1509	.1509	.1698		.1698		
22	.1509	.1509			.1698		.1509
23	.1509	.1509	.1509	.1698	.1509	.1509	.1698
24	.1509	.1433	.1509	.1509	.1509	.1509	.1509
Max	.3772	.1698	.3206	.3206	.3772	.3772	.3395
Min	.1509	.1433	.1509	.132	.1509	.1509	.1463
Avg	.2295	.1513	.2017	.1913	.2099	.2203	.2019

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274003 / INDUSTRIAL ESTATE.

Feeder No / Name : 203 / 11KV POLYTECHNIC

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7282	.7207	.6908	.7468	.7392	.7468	.7842
2	.7282	.6468	.6908	.7468	.7207	.7282	.7655
3	.7282	.6468	.6908	.7468	.7282	.7095	.7468
4	.6908	.6468	.6722	.7468	.7095	.6908	.7468
5	.6908	.6468	.6722	.7392	.7095	.6722	.7282
6	.6908	.6838	.6722	.7762	.7095	.6535	.7282
7	.6984	.6838	.6535	.7762	.6838	.6535	.7282
8	.8059	.6984	.7716	.8962	.7888	.7164	.7207
9	.9774		.823	.9694	.8223	.7716	.6203
10	.9602		.8495		.8642	.823	.5138
11	.9665		.8817	.8954	.9122	.8764	.5256
12	.8848		.7865	.8764	.8619	.8669	.5079
13	.8453		.7122	.8238	.779	.6556	.5609
14	.9054		.7122	.7442		.7087	.5609
15	.9431		.7625	.8505		.7796	.591
16	.9536		.7373	.8589		.815	.6154
17	.8356	.6697	.7209	.8059		.8238	.5407
18	.8785	.6335	.8333	.7293	.9339	.8063	.5182
19	.9465	.8238		.9088	.9945	.964	
20	1.0692	.9671	1.0517	1.0566	1.0692	1.0924	
21	1.0099	.9774	1.0566		.9602		
22	.905	.9231			.8869		.8596
23	.8501	.8131	.8962	.8131	.823	.8413	.7947
24	.7282	.7207	.6908	.7468	.7392	.7842	.7947
Max	1.0692	.9774	1.0566	1.0566	1.0692	1.0924	.8596
Min	.6908	.6335	.6535	.7293	.6838	.6535	.5079
Avg	.8509	.7439	.7740	.8216	.8218	.7809	.6644

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274003 / INDUSTRIAL ESTATE.

Feeder No / Name : 204 / 11KV MEDICAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1163	1.1462	1.0745	1.1999	1.0924	1.0924	1.182
2	1.1163	1.0745	1.0566	1.1999	1.0566	1.0566	1.1641
3	1.1163	1.0745	1.0387	1.1999	1.0566	1.0208	1.1283
4	1.0631	1.0745	1.0208	1.1462	1.0387	.985	1.0745
5	1.0631	.985	1.0029	1.1462	1.0208	.9492	1.0387
6	1.0631	.985	.9671	1.1462	1.0208	.9313	1.0029
7	.9922	.985	1.0387	1.0924	.985	1.0029	1.0208
8	.9745	.9313	.9492	1.0745	1.0029	.985	1.0208
9	.9214		.9313	.9492	.9134	.985	1.0566
10	.9214		.9134		.8775	.9313	.9134
11	.8682		.788	.8417	.8417	.9492	.8775
12	.8505		.9313	.8954	.8417	.9313	.8059
13	.8859		.9492	.9134	.8417	.9313	.8596
14	.8682		.8954	.8417	.8417	.8775	.8859
15	.8859		.9134	.8238	.8596	.9313	.8775
16	.8505		.8954	.8775	.8596	.9134	.8775
17	.8682	1.0208	.9391	.8775		.9671	.8596
18	.9922	.9492	1.0745	.8775	1.0566	1.0029	.8596
19	1.134	1.2536	1.1871	1.1999	1.2536	1.2894	
20	1.4175	1.3969	1.4118	1.4685	1.4685	1.4148	
21	1.4148	1.379	1.3998		1.4506		
22	1.3432	1.3611			1.3432		1.4148
23	1.2715	1.2715	1.2715	1.2894	1.2178	1.2894	1.2715
24	1.1163	1.1462	1.0924	1.1999	1.1283	1.1283	1.2178
Max	1.4175	1.3969	1.4118	1.4685	1.4685	1.4148	1.4148
Min	.8505	.9313	.788	.8238	.8417	.8775	.8059
Avg	1.0464	1.1271	1.0323	1.0600	1.0465	1.0257	1.0195

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274003 / INDUSTRIAL ESTATE.

Feeder No / Name : 206 / 11KV ESTATE 2

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1981	.281	.18	.2576	.2263	.2191	.2524
2	.1833	.2572	.1627	.2427	.213	.2143	.2429
3	.1734	.2429	.152	.2315	.2031	.2048	.2334
4	.1536	.2334	.1494	.2109	.1981	.2	.2149
5	.16		.16	.2006	.1882	.1953	.2058
6	.1829	.2	.1734	.1903	.1882	.2048	.1966
7	.2241	.2143	.1814	.2315	.2	.2096	.2286
8		.2972	.2724	.3334	.3018	.2542	.3102
9	.5144		.503	.431	.4424	.4424	.463
10	.6068		.4973		.463	.503	.5493
11	.6401		.5487	.5218	.5028	.5426	.5548
12	.6556		.5611	.5365	.5373	.6001	.5548
13	.6089		.6268	.4917	.5552	.5365	.4973
14	.567		.5258	.5365		.5426	.5258
15	.5487		.5959	.5087		.5895	.5083
16	.5201		.5316	.5658		.5959	.567
17	.5144	.3978	.543			.8238	.4359
18	.5144		.5609	.503	.5028	.5144	.4359
19	.4254		.5028	.3307	.4748	.3368	.4359
20	.4548	.2201	.3734	.3201		.3517	.421
21	.3963	.1715	.3601		.317		.4287
22	.3334	.1981			.3963		.2923
23	.3096	.1524	.3022	.3138	.2477	.2572	.2515
24	.213	.2953	.1858	.2824	.2366	.2286	.262
Max	.6556	.3978	.6268	.5658	.5552	.8238	.567
Min	.1536	.1524	.1494	.1903	.1882	.1953	.1966
Avg	.3956	.2432	.3761	.3620	.3366	.3894	.3778

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274003 / INDUSTRIAL ESTATE.

Feeder No / Name : 207 / 11 KV ESTATE-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8417	.8417	.9145	.8059	.8869	.8954
2		.8417	.8238	.823	.8059	.8688	.8775
3		.8417	.8238	.823	.7964	.8326	.8596
4		.8238	.8145	.8316	.7964	.8145	.8417
5		.8238	.8145	.7947	.7783	.7964	.8417
6		.8238	.7964	.7947	.7783	.7783	.8417
7		.8238	.7964	.7577	.8048	.7133	.8413
8	.7186	.7712	.823	.7783	.8059	.7682	.7964
9	.7888		.8059	.8417	.8328	.788	.8238
10	.788		.8059	.8775	.8417	.8326	.8507
11	.8238		.8869	.8775	.8417	.8688	.8688
12	.7701		.7783	.8775		.8775	.7973
13	.8059		.8238	.8859	.8939	.8954	.8507
14	.8326		.8145	.7701	.8589	.8507	.8507
15	.7964		.7964	.7712	.8589	.7964	.7537
16	.8059		.8326	.7602	.8063	.8507	.7712
17	.815	.9882	.8238	.7716		.8413	.7888
18	.8402	.9189	.9955	.7625	.9991	.823	.7545
19	1.0117	1.0923	1.0802	1.1096	1.1317	1.0631	
20	1.1871	1.1744	1.1317	1.1919	1.166	1.1361	
21	1.182	1.1694	1.1871		1.0974		
22	1.1104	1.134			1.0166		1.1104
23	.9671	.985	.9492	.985	.9774	1.0029	1.0029
24	.8596	.8417	.8417	.9145	.8417	.905	.9313
Max	1.1871	1.1744	1.1871	1.1919	1.166	1.1361	1.1104
Min	.7186	.7712	.7783	.7577	.7783	.7133	.7537
Avg	.8884	.9310	.8734	.8597	.888	.8632	.8548

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274003 / INDUSTRIAL ESTATE.

Feeder No / Name : 209 / 11KV MITRAGOTRI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.4917	.4917	.5434	.503	.5197	.5365
2	.5658	.4917	.3429	.5434	.503	.503	.5197
3	.5316	.4917	.4801	.5316	.4862	.503	.5197
4	.5316	.4239	.463	.4973	.4862	.4862	.503
5	.5144	.4239	.4458	.4973	.4694	.4862	.503
6	.5144	.4144	.4287	.4917	.4534	.4862	.503
7	.4801	.4144	.4287	.4807	.4144	.4024	.4694
8	.4973	.4321	.426	.4915	.4801	.4144	.4588
9	.4862		.5087	.5426	.4784	.4321	.4854
10	.5138		.503		.4687	.4641	.4096
11	.5144		.4428	.4917	.4801	.4862	.4024
12	.5028		.427	.5256	.4801	.5201	.3856
13	.5375		.4527	.4973	.4481	.5144	.407
14	.4908		.4428	.5028		.5083	.463
15	.5609		.4748	.5434		.4334	.4382
16	.5959		.503	.5493		.4973	.4334
17	.4967	.4481	.5533	.5316		.5256	.3749
18	.4904	.4161	.5935	.5281	.571	.5636	.3963
19	.6019	.5506	.7442	.6882	.6722	.7045	
20	.6722	.6226	.6642	.6882	.7127	.7455	
21	.6882	.6226	.703		.7291		
22	.639	.6062			.6325		.6344
23	.5935	.583	.6135	.57	.6036	.6036	.6001
24	.5658	.4917	.5087	.5434	.5197	.5365	.5533
Max	.6882	.6226	.7442	.6882	.7291	.7455	.6344
Min	.4801	.4144	.3429	.4807	.4144	.4024	.3749
Avg	.5480	.4953	.5062	.5371	.5296	.5153	.4760



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 201 / 11 KV MANTRI CHANDAK  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.5601	.5544	.5544
2					.5415	.5359	.5175
3					.5415	.5359	.499
4					.5415	.5175	.499
5					.5544	.5175	.5175
6					.5914	.5228	.5415
7					.5544	.5601	.6161
8					.6161	.5729	.5544
17	.5788	.5544	.4938	.543	.5487	.5316	
18		.6283	.5729	.5611	.567	.5853	
19	.8501	.7207	.7762	.6516	.6516	.6733	
20	.8686	.7947	.8048	.7964	.7964	.691	
21	.8501	.7762	.7865	.7682	.7682	.7265	
22	.8048	.7392	.7762	.7499	.7316		
23	.6767	.7023					
24	.6335				.5788	.5914	.5914
Max	.8686	.7947	.8048	.7964	.7964	.7265	.6161
Min	.5788	.5544	.4938	.543	.5415	.5175	.499
Avg	.7518	.7023	.7017	.6784	.6095	.5797	.5434

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 202 / 11 KV VIMANTAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.4668	.547	.5093
2					.4668	.5281	.4904
3					.4481	.5281	.4904
4					.4481	.5093	.4715
5					.4715	.5093	.4715
6					.5093	.5281	
7					.4338	.5281	.5228
8					.5093	.5847	.4481
17	.4904	.5601	.5281	.4344	.5068	.5316	
18		.5847	.5228	.4525	.5304	.5121	
19	.6224	.5847	.6348	.543	.543	.567	
20	.6602	.679	.6036	.5973	.5973	.5847	
21	.6602	.679	.6036	.5249	.5792	.6584	
22	.6154	.6413	.5658	.5249	.6036		
23	.5729	.5658					
24	.1715				.4668	.5658	.5281
Max	.6602	.679	.6348	.5973	.6036	.6584	.5281
Min	.1715	.5601	.5228	.4344	.4338	.5093	.4481
Avg	.5419	.6135	.5765	.5128	.5054	.5487	.4915

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 203 / 11 KV SHINDU VIHAR  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.8865	.9054	.9431
2					.8488	.8865	.9242
3					.8488	.8865	.9054
4					.9054	.8865	.9054
5					.9431	.9054	.9431
6					1.0562	.9242	1.0185
7					.9997	.9619	1.094
8					.9619	.9997	1.0374
17	.7282	.7682	.7842	.7316	.7783	.7619	
18		.7947	.8686	.7499	.7421	.7442	
19	1.1016	.9979	1.0719	1.0608	1.086	.8859	
20	1.2696	1.2323	1.2323	1.1888	1.1403	1.0277	
21	1.2323	1.1949	1.1949	1.0498	1.1584	1.1523	
22	1.1949	1.1576	1.1506	1.0498	1.1222		
23	1.0562	1.1203					
24	.9774				.9242	.9619	.9808
Max	1.2696	1.2323	1.2323	1.1888	1.1584	1.1523	1.094
Min	.7282	.7682	.7842	.7316	.7421	.7442	.9054
Avg	1.0800	1.0380	1.0504	.9718	.9601	.9207	.9724

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 204 / 11 KV SHIVASHAI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.1867	.2241	.2054
2					.1867	.2054	.1867
3					.1867	.2054	.1867
4					.2241	.2054	.2241
5					.2614	.2241	.2801
6					.2987	.2452	.3395
7					.2987	.2801	.3395
8					.2829	.3206	.3206
17	.2454	.2241	.3582	.2534	.2896	.2534	
18	.2427	.2772	.3366	.2896	.2534	.2353	
19	.2801	.3326	.362	.2896	.2835	.2715	
20	.3326	.3881	.3841	.2896	.2835	.2534	
21	.3326	.3696	.3841	.2715	.2896	.2896	
22	.3361	.3361	.3696	.2534	.2896		
23	.2987	.2987					
24	.2534				.2241	.2427	.2241
Max	.3361	.3881	.3841	.2896	.2987	.3206	.3395
Min	.2427	.2241	.3366	.2534	.1867	.2054	.1867
Avg	.2902	.3181	.3658	.2745	.2559	.2469	.2563

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 205 / 11 KV KUMATHA GAOTHAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.5093	.5041	.5041
2					.4904	.4854	.5041
3					.4904	.4854	.5041
4					.5281	.5041	.5228
5					.5658	.5415	.5601
6					.6413	.6224	.6224
7					.5601	.5788	.5847
8					.499	.5228	.4668
17	.4119	.4382	.3856	.4525	.4344	.4607	
18	.4287	.4973	.4287	.4887	.4887	.4252	
19	.4784	.5611	.5194	.5487	.5853	.439	
20	.6219	.6584	.6401	.6335	.6154	.6379	
21	.5914	.6219	.6584	.5792	.5853	.6201	
22	.5415	.5601	.6838	.543	.6154		
23	.4805	.5228					
24	.439				.5281	.5228	.5228
Max	.6219	.6584	.6838	.6335	.6413	.6379	.6224
Min	.4119	.4382	.3856	.4525	.4344	.4252	.4668
Avg	.4992	.5514	.5527	.5409	.5425	.5250	.5324

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 206 / 11 KV SANTOSH NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.9145	.8779	.9145
2					.8779	.8596	.8779
3					.8779	.823	.8871
4					.8779	.823	.8871
5					.9055	.8413	.924
6					.924	.8596	.9522
7					.9055	.9145	.9709
8					.8962	.8962	.961
17	.9511	.9145	.9412	.9114	1.0498	.8505	
18	1.0317	.9412	1.0387	.9955	1.1403	1.0679	
19	1.1946	1.1765	1.2308	1.1584	1.267	1.2403	
20	1.379	1.3937	1.3756	1.3756	1.3937	1.3466	
21	1.3611	1.3756	1.3756	1.3213	1.3394	1.3289	
22	1.3432	1.3394	1.3253	1.2851	1.3032		
23	1.086	1.2489					
24	.9922				.9511	.9145	.9511
Max	1.379	1.3937	1.3756	1.3756	1.3937	1.3466	.9709
Min	.9511	.9145	.9412	.9114	.8779	.823	.8779
Avg	1.1674	1.1985	1.2145	1.1746	1.0416	.9746	.9251

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 207 / 11KV WATER SUPPLY NON SHEDDABLE WATER SUPPLY AND  
Feeder KV- 11 / OUTGOING UTILITY

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.3077	.3077	.3077
2					.3077	.3077	.3077
3					.3077	.3077	.3077
4					.3077	.3077	.3077
5					.3077	.3077	.3077
6					.3077	.3077	.4525
7					.4525	.3077	.3077
8					.3077	.3077	.3077
17	.181	.2715	.3258	.3258	.2835	.362	
18	.362	.2715	.4344	.3258	.439	.4344	
19	.3801	.2715	.2715	.3258	.3258	.3258	
20	.181	.4525	.4525	.3258	.3258	.3258	
21	.181	.2715	.3077	.3258	.3292	.3258	
22	.181	.2715	.3077	.3258	.3258		
23	.181	.2715					
24	.181				.3077	.3077	.3258
Max	.3801	.4525	.4525	.3258	.4525	.4344	.4525
Min	.181	.2715	.2715	.3258	.2835	.3077	.3077
Avg	.2285	.2974	.3499	.3258	.3295	.3245	.3258

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 208 / 11 KV SHANTIVAN  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.5376	.5535	.6009
2					.5376	.5693	.6009
3					.5535	.5693	.6325
4					.5535	.6009	.6642
5					.6009	.6325	.7116
6					.6958	.7116	.8223
7					.9172	.8539	.9488
8					.9804	.9804	.9962
17	.0633	.0633	.0633	.0633	.0633	.0474	
18		.0791	.0791	.0633	.0633	.0633	
19	.0949	.0949	.1107	.0633	.0474	.0633	
20	.1107	.1265	.1265	.0633	.0633	.0633	
21	.1267	.1107	.1107	.0633	.0474	.0474	
22	.1086	.0949	.1107	.0633	.0633		
23	.427	.2846					
24	.3163				.506	.6009	.5693
Max	.427	.2846	.1265	.0633	.9804	.9804	.9962
Min	.0633	.0633	.0633	.0633	.0474	.0474	.5693
Avg	.1782	.122	.1002	.0633	.4154	.4541	.7274



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 209 / 11 KV IMS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.7682	.8145	.8326
2					.7316	.7964	.8326
3					.7316	.7964	.8688
4					.7682	.8145	.9412
5					.823	.8326	.9955
6					.9511	.8869	1.0679
7					.9511	.9231	1.1584
8					.9511	.9412	1.1041
17	.7421	.6878	.6878	.695	.7316	.7421	
18		.724	.7964	.7421	.7682	.7602	
19	1.0498	.8688	.905	.9774	1.0136	1.0608	
20	1.1765	1.0317	1.0498	1.0679	1.1041	1.1157	
21	1.1403	.9955	1.0498	1.0679	1.0974	1.1157	
22	1.1222	.9412	1.0317	1.0498	.9922		
23	.9231	.9231					
24	.905				.823	.8326	.8507
Max	1.1765	1.0317	1.0498	1.0679	1.1041	1.1157	1.1584
Min	.7421	.6878	.6878	.695	.7316	.7421	.8326
Avg	1.0084	.8817	.9201	.9334	.8804	.8881	.9613

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 210 / 11 KV BOMBAY PARK  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.6516	.6516	.6697
2					.6335	.6335	.6516
3					.6335	.6335	.6516
4					.6335	.6154	.6516
5					.6516	.6154	.6697
6					.6516	.6335	.6878
7					.6878	.6697	.7783
8					.724	.7421	.7602
17	.5249	.543	.5068	.5068	.5316	.6154	
18		.5792	.6154	.4887	.5493	.6335	
19	.7964	.724	.724	.6878	.7059	.7602	
20	.905	.8688	.8326	.8869	.7964	.8326	
21	.905	.8688	.8145	.8507	.7973	.8326	
22	.905	.8688	.7964	.8688	.815		
23	.724	.7602					
24	.6878				.6697	.6697	.6878
Max	.905	.8688	.8326	.8869	.815	.8326	.7783
Min	.5249	.543	.5068	.4887	.5316	.6154	.6516
Avg	.7783	.7447	.7150	.7150	.6755	.6813	.6898

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 211 / 11 KV NEHARU NAGAR  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.6335	.6516	.6697
2					.6154	.6335	.6516
3					.6154	.6335	.6516
4					.6335	.6516	.6697
5					.6697	.6697	.6878
6					.7059	.7059	.724
7					.6878	.7421	.7602
8					.6697	.7421	.7059
17	.6516	.5487	.6219	.5792	.567	.5792	
18		.5853	.6767	.5973	.6024	.6154	
19	.8507	.695	.7682	.8688	.7602	.8413	
20	.9593	.8596	.8962	.905	.8507	.905	
21	.9412	.823	.9511	.8688	.8238	.8779	
22	.8869	.7865	.9877	.8507	.7973		
23	.7421	.7316					
24	.724				.6516	.6697	.6878
Max	.9593	.8596	.9877	.905	.8507	.905	.7602
Min	.6516	.5487	.6219	.5792	.567	.5792	.6516
Avg	.8223	.7185	.8170	.7783	.6856	.7085	.6898

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274122 / PAPER PLANT

Feeder No / Name : 202 / 11 KV SHANKAR NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2696	1.1949	1.1763	1.1763	1.1949	1.1763	1.1949
2	1.1763	1.1763	1.1203	1.1389	1.1576	1.1203	1.1763
3	1.1763	1.1576	1.1203	1.1203	1.1389	1.1203	1.1576
4	1.1389	1.1576	1.1389	1.1203	1.1576	1.1389	1.1576
5	1.1949	1.1949	1.2136	1.2136	1.2323	1.1949	1.1949
6	1.251	1.3817	1.307	1.419	1.307	1.2323	1.307
7	1.3256	1.307	1.5684	1.363	1.2696	1.251	1.2883
8	1.2136	1.251	1.3443	1.307	1.2696	1.1576	1.251
9	1.1763	1.0829	1.3256	1.1203	1.1389	1.251	.0934
10	1.1576	1.1763	1.2696	1.0642	1.1203	1.251	1.1389
11	1.1016		1.2323	1.0642	1.1203	1.1949	1.1389
12	1.1016		1.1576	1.1016	1.1763	1.2696	1.1576
13	1.1576		1.2136	1.1203	1.1016	1.1949	1.1576
14	1.1763		1.2696	.9335	1.1763	1.1949	1.1576
15	1.1203		1.1763	1.0269	1.1576	1.251	1.1576
16	1.1576	1.3256	1.0829	1.0642	1.2136	1.1949	1.1763
17	1.1576	1.2136	1.1389	1.0082	1.2323	1.1389	1.2136
18	1.307	1.0288	1.307	1.0642	1.2883	1.307	1.0269
19	1.475	1.4937	1.5497	1.475	1.6617	1.4377	1.4003
20	1.8484	1.643	1.7364	1.7551	1.8858	1.6804	1.7177
21	1.7551	1.6057	1.8298	1.7177	1.8671	1.5927	1.6804
22	1.7364	1.7551	1.6991	1.7551	1.7364	1.7551	1.8111
23	1.5684	1.5497	1.5123	1.531	1.3817	1.5684	1.6057
24	1.419	1.3817	1.4003	1.3256	1.3817	1.3817	1.3817
Max	1.8484	1.7551	1.8298	1.7551	1.8858	1.7551	1.8111
Min	1.1016	1.0288	1.0829	.9335	1.1016	1.1203	.0934
Avg	1.2984	1.3198	1.3288	1.2494	1.3070	1.2940	1.2393

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274122 / PAPER PLANT

Feeder No / Name : 203 / 11 KV SHIDDHESHWAR  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0934	.0934	.0934	.0934	.112	.0934
2	.0934	.0934	.0934	.0934	.0934	.112	.0934
3	.0934	.0934	.0934	.0934	.0934	.112	.0934
4	.0934	.112	.0934	.0934	.0857	.112	.0934
5	.112	.112	.112	.1307	.0934	.112	.0934
6	.1307	.1307	.112	.1097	.0934	.112	.112
7	.056	.112	.112	.0934	.112	.112	.112
8	.0934	.0934	.112		.112	.112	.0934
9	.0934	.0934	.112	.0934	.0934	.112	.0934
10	.112	.0934	.112	.0934	.112	.112	.0934
11	.112		.112	.112	.112	.112	.112
12	.112		.0747	.112	.112	.112	.0934
13	.112		.0934	.112	.112	.112	.0934
14	.112		.112	.0934	.112	.112	.0934
15	.112		.112	.112	.112	.112	.0934
16	.112	.0934	.112	.112	.112	.112	.0934
17	.0934	.0934	.0934	.0934	.112	.0934	.0934
18	.0934	.0934	.112	.0934	.112	.112	.0934
19	.0934	.112	.112	.112	.0934	.0934	.112
20	.112	.112	.112	.112	.0934	.112	.112
21	.112	.112	.112	.112	.112	.112	.112
22	.112	.112	.112	.112	.112	.112	.112
23	.1239	.112	.112	.0934	.112	.112	.112
24	.112	.0934	.112	.0934	.0934	.112	.112
Max	.1307	.1307	.112	.1307	.112	.112	.112
Min	.056	.0934	.0747	.0934	.0857	.0934	.0934
Avg	.1040	.1032	.1058	.1030	.1039	.1105	.1004

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274122 / PAPER PLANT

Feeder No / Name : 204 / 11 KV SWAGAT NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.39	1.4266	1.39	1.39	1.39	1.4632	1.4266
2	1.3717	1.3717	1.3535	1.3352	1.3352	1.3717	1.3717
3	1.3717	1.3535	1.3352	1.3169	1.3535	1.3717	1.3717
4	1.3535	1.3169	1.3535	1.3169	1.2986	1.3352	1.3717
5	1.4083	1.4083	1.4083	1.4083	1.3352	1.3717	1.3717
6	1.6095	1.5364	1.5364	1.6644	1.4998	1.4632	1.4632
7	1.4998	1.4449	1.4998	1.5729	1.4449	1.4449	1.4449
8	1.5546	1.3169	1.5364	1.5912	1.4998	1.4083	1.39
9	1.5364	1.1888	1.4998	1.4937	1.39	1.4632	1.2803
10	1.6278	1.262	1.4815	1.5729	1.4998	1.5546	1.2986
11	1.5912		1.4632	1.5546	1.5729	1.7737	1.262
12	1.5546		1.4449	1.5181	1.4632	1.6461	1.3169
13	1.6095		1.39	1.5181	1.4815	1.5912	1.2437
14	1.6095		1.4266	1.3717	1.5729	1.5181	1.2803
15	1.6827		1.4998	1.4632	1.701	1.6461	1.2986
16	1.701	1.3535	1.5546	1.3717	1.6461	1.6644	1.3169
17	1.6278	1.2986	1.5729	1.5546	1.6461	1.5729	1.2803
18	1.6095	1.262	1.6644	1.5546	1.6278	1.5729	1.0974
19	1.829	1.4632	1.957	1.829	1.957	1.7193	1.4815
20	2.2862	1.8656	2.2497	2.2314	2.3045	2.1033	1.957
21	2.1033	1.8839	2.1765	2.0851	2.2862	2.1216	1.9204
22	2.0119	1.8656	2.0485	2.0485	2.1033	2.0911	1.8839
23	1.701	1.701	1.7375	1.6827	1.7924	1.829	1.6278
24	1.5181	1.5181	1.5181	1.5729	1.4998	1.5546	1.5546
Max	2.2862	1.8839	2.2497	2.2314	2.3045	2.1216	1.957
Min	1.3535	1.1888	1.3352	1.3169	1.2986	1.3352	1.0974
Avg	1.6316	1.4651	1.5874	1.5841	1.6126	1.6105	1.4297

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274122 / PAPER PLANT

Feeder No / Name : 205 / 11 kv Hatture Nager

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2743	.2743	.2561	.2743	.2743	.2743
2	.2743	.2743	.2743	.2561	.2743	.2743	.2743
3	.2561	.2561	.2743	.2561	.2561	.2926	.2561
4	.2561	.2743	.2926	.2743	.2561	.2926	.2743
5	.3109	.2926	.3292	.2926	.2926	.3109	.2926
6	.3292	.3475	.3841	.3475	.3475	.3292	.3109
7	.3475	.3475	.4207	.3841	.3475	.3292	.3292
8	.2926	.2743	.4024	.2743	.2926	.3658	.3292
9	.2378	.2561	.3658	.2743	.2743	.2926	.2926
10	.2378	.2378	.3475	.2743	.2561	.2743	.2378
11	.2195		.3658	.1829	.2378	.2378	.2378
12	.2378		.3109	.2378	.2378	.2378	.2561
13	.2378		.2926	.2378	.2378	.2561	.2561
14	.2378		.2926	.2378	.2378	.2743	.2561
15	.2561		.2743	.2561	.2561	.2743	.2561
16	.2378	.3292	.2926	.2561	.2561	.2561	.2743
17	.2378	.2926	.2926	.2743	.2926	.2561	.2561
18	.3109	.3109	.3109	.2743	.3109	.3292	.2743
19	.3475	.3658	.4207	.3658	.4207	.3841	.3475
20	.4755	.439	.439	.4755	.4572	.4207	.4024
21	.3841	.4207	.4207	.3841	.439	.4207	.3841
22	.4024	.4024	.3841	.4024	.4024	.3841	.4024
23	.3292	.3292	.3109	.3292	.3292	.3292	.3292
24	.3109	.3109	.3109	.2561	.3109	.3109	.3109
Max	.4755	.439	.439	.4755	.4572	.4207	.4024
Min	.2195	.2378	.2743	.1829	.2378	.2378	.2378
Avg	.2934	.3177	.3368	.2942	.3041	.3086	.2964

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274122 / PAPER PLANT

Feeder No / Name : 403 / 33 KV KIRLOSKAR

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.3375	6.1054	2.2634	6.3295	4.4136	3.7912	6.2174
2	4.5268	6.4975	2.2068	3.6969	3.5848	1.9805	6.1614
3	2.1502	4.425	1.6975	6.3295	3.3048	2.2068	3.3608
4	3.4517	6.1054	2.1502	4.145	4.9851	4.4702	6.2174
5	4.9794	2.2405	2.3765	2.0165	5.2652	2.2634	6.3295
6	4.0175	6.0494	3.678	2.2405	6.2174	1.6975	6.2174
7	2.2634	1.2883	3.9043	4.7051	4.9291	1.4146	5.0972
8	6.2243	.8962	6.5638	4.369	5.4332	1.8107	4.0329
9	3.9609	.9619	1.9805	6.3375	5.3755	2.2068	7.0731
10	4.7531	.9619	2.6029	5.4887	3.4517	1.9239	6.6204
11	5.036		4.0175	3.6214	2.5463	1.7541	4.5268
12	2.2068		8.7706	6.7901	2.6595	2.9424	4.9794
13	4.8097		5.5453	6.7901	3.3385	1.8107	3.678
14	6.7901		4.3004	6.7335	4.1307	1.7541	3.6214
15	2.6029		4.4702	5.6584	2.7726	2.3765	2.4897
16	2.9424	.679	4.5268	4.357	5.8282	4.9794	4.1307
17	3.1927	.679	4.369	5.3755	2.7726	6.1614	7.0731
18	2.4086	.8488	4.201	3.9043	4.357	4.0889	7.0731
19	2.5766	.8488	2.4086	4.5268	4.3004	6.7776	5.6584
20	3.9209	.9054	3.7529	2.6595	3.9609	7.1696	5.4887
21	3.3048	1.1883	3.5848	2.0725	2.037	4.537	2.9424
22	5.1532	1.4712	2.2405	3.9769	5.1492	3.9209	3.5648
23	2.4086	4.357	2.6886	4.201	2.6029	6.8896	2.5463
24	5.7716	3.7529	1.358	3.0247	5.6573	6.0545	5.7693
Max	6.7901	6.4975	8.7706	6.7901	6.2174	7.1696	7.0731
Min	2.1502	.679	1.358	2.0165	2.037	1.4146	2.4897
Avg	3.9912	2.6454	3.5691	4.5562	4.1281	3.5409	5.0362



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274122 / PAPER PLANT

Feeder No / Name : 404 / 33 KV HOTGI

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	2.0062	2.2634	2.524	2.3663	2.3148	2.3663
2	1.5432	2.0062	2.2634	2.5789	2.3663	2.3663	2.4177
3	1.5947	2.1605	2.3148	2.6337	2.4177	2.4177	2.4177
4	1.8519	2.2634	2.3148	2.8006	2.572	2.5206	2.572
5	2.3148	2.4177	2.4691	2.1605	2.7778	2.572	2.7778
6	2.6235	3.0864	2.6749	3.3436	2.5206	3.1893	2.6235
7	3.1893	1.6975	2.6749	3.2373	2.9835	3.9095	2.9835
8	2.4691	2.9835	1.3375	2.4691	2.8292	3.4465	2.3663
9	2.1091	2.6235	2.6235	2.0576	2.2634	2.3663	2.2119
10	2.1605	2.2634	2.572	2.3148	2.2634	2.6235	2.5206
11	2.1091		2.572	2.0062	2.2634	2.3663	2.4177
12	2.1091		2.4691	2.0062	2.4691	2.5206	2.3148
13	2.0062		2.3663	2.0576	1.749	2.1605	2.4691
14	1.9033		2.4691	1.9547	1.749	2.3663	2.4177
15	1.9547		2.6749	2.1605	2.2634	2.3663	2.5206
16	1.5947	.5658	2.4691	2.3148	2.5206	2.4177	2.6235
17	.6173	.7202	.5658	.5144	.5144	.3086	.6687
18	.5144	.7202	.6687	.6173	.7716	.7716	.6687
19	.823	.823	.9259	.7716	.9259	.7716	.7202
20	1.0802	1.0288	.9774	1.0288	1.1317	.9774	.9774
21	1.0288	1.0288	1.0802	1.0288	1.1317	1.0802	.9774
22	.9774	1.0288	2.3594	1.0288	1.0288	.9774	1.0288
23	2.0576	2.2634	2.2119	2.3148	2.3663	2.3663	2.4177
24	1.8004	2.0062	2.2119	2.3148	2.2634	2.3148	7.1502
Max	3.1893	3.0864	2.6749	3.3436	2.9835	3.9095	7.1502
Min	.5144	.5658	.5658	.5144	.5144	.3086	.6687
Avg	1.7490	1.7733	2.0638	2.0100	2.0212	2.1455	2.2762

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274184 / 33/11 KV I.T.I SUB STATION

Feeder No / Name : 201 / 11 KV FURDE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3544	.3366	.3544	.443	.4075	.3544	.3544
2	.3366	.3366	.362	.4252	.3898	.362	.3544
3	.3366	.3366	.3544	.4075	.3898	.3544	.3544
4	.3475	.3189	.3366	.3544	.3721	.3544	.3544
5	.3366	.3189	.3366	.3544	.3721	.3544	.362
6	.3721	.3189	.3544	.3544	.3721	.3898	.3982
7	.3721	.3366	.3721	.4075	.2303	.4075	.4163
8	.3721	.3366	.3012	.3898	.4075	.4075	.3544
9	.3544	.3189	.3012	.3721	.3012	.3801	.3544
10	.3544	.3012	.3721	.3544	.3012	.3898	.3544
11	.3721	.2835	.3189	.3366	.3366	.3801	.3366
12	.3721	.2835	.3012	.3189	.3189	.3801	.3366
13	.3544	.3012	.3544	.3544	.3721	.3366	.3189
14	.3544	.2835	.3721	.3544	.3898	.3366	.3189
15	.3544	.3012	.3544	.3544	.3544	.3439	.3189
16	.3366	.3544	.3189	.3189	.3366	.3189	.3189
17	.3544	.3898	.3366	.3898	.3189	.3366	.3366
18	.4075	.4075	.5316	.443	.3189	.4163	.3544
19	.4607	.4961	.5316	.4784	.4252	.443	.443
20	.4961	.567	.5847	.4961	.4252	.4607	.4784
21	.5138	.5138	.5316	.4784	.4784	.4961	.4784
22	.4784	.4607	.5316	.4607	.443	.4525	.4887
23	.4075	.4075	.4961	.443	.4163	.0543	.4163
24	.3721	.3898	.3544	.4784	.4252	.3544	.3544
Max	.5138	.567	.5847	.4961	.4784	.4961	.4887
Min	.3366	.2835	.3012	.3189	.2303	.0543	.3189
Avg	.3821	.3625	.3901	.3987	.3710	.3694	.3732

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274184 / 33/11 KV I.T.I SUB STATION

Feeder No / Name : 202 / 11 KV INDIRA NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3012	.3658	.3189	.3544	.4075	.3189	.3189
2	.2835	.3366	.3189	.3366	.3982	.3045	.3012
3	.2835	.3189	.3189	.3366	.3801	.3077	.3012
4	.2835	.3189	.3012	.3189	.3544	.3077	.3012
5	.2835	.3189	.3189	.3189	.362	.3077	.3077
6	.3189	.3366	.3189	.3366	.362	.3189	.3012
7	.3012	.3544	.3189	.3544	.3366	.3439	.3189
8	.3189	.3189	.3189	.3366	.3012	.3189	.3012
9	.3189	.3012	.2835	.3189	.3077	.3189	.2835
10	.2835	.2835	.2835	.3012	.3077	.3012	.2835
11	.3012	.2835	.2658	.2835	.3077	.2658	.2835
12	.2835	.2658	.2481	.2835	.2353	.2835	.2658
13	.3012	.2658	.3012	.3012	.2896	.3189	.2658
14	.2835	.2835	.2835	.3012	.3077	.3189	.2658
15	.3012	.2835	.3012	.3012	.3077	.3012	.2658
16	.3012	.2658	.2835	.3012	.3012	.2835	.2658
17	.3189	.2658	.3366	.3721	.3077	.3189	.2658
18	.3544	.2835	.4252	.443	.3077	.3366	.2835
19	.4075	.3544	.4607	.4784	.362	.3898	.3544
20	.4607	.4075	.4607	.4961	.4344	.4075	.3898
21	.4961	.4252	.443	.4887	.4525	.3898	.4252
22	.4252	.4252	.4252	.443	.3982	.3544	.4075
23	.3898	.3544	.4075	.443	.3544	.362	.4607
24	.3258	.3721	.3189	.3898	.4252	.3189	.3189
Max	.4961	.4252	.4607	.4961	.4525	.4075	.4607
Min	.2835	.2658	.2481	.2835	.2353	.2658	.2658
Avg	.3303	.3246	.3359	.3600	.3462	.3249	.3140

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274184 / 33/11 KV I.T.I SUB STATION

Feeder No / Name : 203 / 11 KV VIJAPUR NAKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2481	.2303	.2481	.2481	.2896	.2715	.2481
2	.2303	.2126	.2481	.2353	.2715	.2658	.2481
3	.2303	.2126	.2303	.2172	.2534	.2534	.2481
4	.2303	.2126	.2303	.2172	.2534	.2481	.2481
5	.2303	.2126	.2481	.2353	.2534	.2534	
6	.2481	.2303	.2481	.2534	.2534	.2715	.2481
7	.2658	.2481	.2658	.2534	.2715	.2534	.2658
8	.2658	.2481	.2658	.2534	.2835	.2481	.2658
9	.2835	.2481	.2481	.2534	.2715	.2658	.2481
10	.2835	.2303	.2481	.2534	.2715	.2896	.2658
11	.2835	.2303	.2658	.2534	.2896	.2715	.2658
12	.2658	.2481	.2481	.2534	.2715	.2715	.2658
13	.2658	.2658	.2835	.2715	.2896	.3077	.2658
14	.2303	.2658	.2658	.2715	.2715	.2835	.2658
15	.2481	.2658	.2658	.2715	.2896	.2896	.2658
16	.2481	.2658	.2481	.2534	.3012	.2896	.2481
17	.2658	.2658	.2658	.3077	.2715	.3077	.2481
18	.2835	.2658	.2534	.3189	.2715	.3439	.2481
19	.3189	.3366	.3439	.3366	.3012	.3439	.2481
20	.3366	.3366	.3366	.362	.362	.3439	.2658
21	.3366	.3544	.3189	.362	.3439	.3258	.3012
22	.3012	.3189	.3077	.3366	.3077	.2896	.3189
23	.2658	.2481	.2835	.3189	.3012	.2715	.2481
24	.2481	.2658	.2481	.2658	.3012	.2658	.2658
Max	.3366	.3544	.3439	.362	.362	.3439	.3189
Min	.2303	.2126	.2303	.2172	.2534	.2481	.2481
Avg	.2673	.2591	.2673	.2751	.2852	.2844	.2612

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274184 / 33/11 KV I.T.I SUB STATION

Feeder No / Name : 204 / 11 KV ITI NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
10	.0177
11	.0177
12	.0181
13	.0181
16	.0181
Max	.0181
Min	.0177
Avg	.0179

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274184 / 33/11 KV I.T.I SUB STATION

Feeder No / Name : 205 / 11 KV RAMLING NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1417	.1595	.1417	.1417	.1612	.1448	.1417
2	.124	.1417	.1417	.1595	.1629	.1267	.1417
3	.124	.1417	.124	.1417	.1629	.1267	.124
4	.124	.1417	.124	.1417	.1612	.1254	.124
5	.124	.1417	.1417	.124	.1629	.1267	.124
6	.1417	.1417	.1595	.1417	.1629	.1612	.1448
7	.1772	.1772	.1772	.1595	.1612	.1433	.1595
8	.1772	.1417	.1772	.1417	.1595	.1595	.1595
9	.1772	.1595	.1595	.1417	.1612	.1629	.1417
10	.1595	.124	.1417	.1417	.1448	.1433	.1417
11	.124	.124	.124	.1417	.1433	.1433	.1417
12	.1063	.1063	.1063	.1417	.1254	.1595	.1417
13	.124	.1063	.124	.1417	.1254	.1417	.1448
14	.124	.1063	.124	.1417	.1254	.1267	.1417
15	.124	.1063	.124	.1417	.1267	.1254	.1417
16	.1063	.124	.1063	.1417	.124	.1254	.1417
17	.124	.124	.1417	.1595	.1267	.1433	.1417
18	.1417	.1417	.1629	.1772	.1267	.1448	.1417
19	.1772	.1595	.1772	.1772	.1629	.1629	.1772
20	.2126	.1949	.1772	.2126	.1991	.181	.1949
21	.2126	.1949	.1772	.2126	.181	.181	.1949
22	.1949	.1949	.1772	.2126	.181	.1715	.2126
23	.1949	.1772	.1772	.1949	.1791	.1595	.1949
24	.1448	.1772	.1417	.1595	.1791	.1417	.1448
Max	.2126	.1949	.1772	.2126	.1991	.181	.2126
Min	.1063	.1063	.1063	.124	.124	.1254	.124
Avg	.1492	.1462	.1470	.1580	.1544	.1470	.1524