Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ I SUB-DN.[100] BU 6335
Substation No/ Name :- 274035 / 33/11 KV AKLUJ S/STN.
Feeder No / Name : 201 / 11KV MARKET YARD SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.381		.3353
2	.3353	.4287		.3048
3	.3353	.381		.3353
4	.3353	.381		.3353
5	.4572	.6097	.3048	.381
6	.8383	.7621	.3048	.8383
9	.6097	.6097	.6859	.7621
10	.381	.4572	.6706	.381
11	.381	.381	.3353	.381
12	.381	.3048	.3353	.381
13	.381	.3048	.3353	.381
14	.381		.3353	.381
15	.381	.3048		.381
16	.381	.3048		.381
17	.381	.3048	.5868	.381
18	.5335	.381	.5868	.6097
19	.6859	.6097	.7545	.7621
20	.6859	.6859	.6706	.7621
21	.6097		.5868	.6097
22	.4572	.381	.4191	.4572
23	.381	.3048	.4191	.4572
24	.3353	.381		.3353
Max	**.8383**	**.7621**	**.7545**	**.8383**
Min	**.3353**	**.3048**	**.3048**	**.3048**
Avg	**.4538**	**.4329**	**.4887**	**.4697**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ I SUB-DN.[100] BU 6335
Substation No/ Name :- 274035 / 33/11 KV AKLUJ S/STN.
Feeder No / Name : 202 / 11KV AKLUJ URBAN SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.4572		.4191
2	.4191	.4572		.4191
3	.4191	.4572		.3929
4	.4191	.4572		.4191
5	.8383	.6859	.381	.8383
6	.9221	.9145	.9145	.9221
9	1.1431	1.0669	.9907	.9907
10	.8383	.9907	.9907	.9145
11	.8383	.8383	.8383	.7621
12	.6097	.7621	.7545	.7621
13	.6097	.6859	.7545	.7621
14	.6097		.503	.6859
15	.6097	.6097		.6859
16	.6097	.6097		.6859
17	.6097	.6859	1.0898	.7621
18	.8383	.7621	1.0059	.9145
19	.9907	.9907	1.1022	.9907
20	.9907	.9907	.9145	.9907
21	.8383		.9221	.8383
22	.7621	.8383	.8383	.7621
23	.6097		.503	.6097
24	.4191	.4572	.381	.4191
Max	**1.1431**	**1.0669**	**1.1022**	**.9907**
Min	**.4191**	**.4572**	**.381**	**.3929**
Avg	**.6983**	**.7220**	**.8053**	**.7249**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ I SUB-DN.[100] BU 6335
Substation No/ Name :- 274035 / 33/11 KV AKLUJ S/STN.
Feeder No / Name : 203 / 11KV DIVISION SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3048		.3048
2	.3734	.3048		.3353
3	.3353	.3048		.3353
4	.3048	.3048		.3353
5	.4191	.4572	.381	.3353
6	.4191	.6097	.6097	.4191
9	.5335	.6097	.7621	.5335
10	.381	.5335	.7621	.381
11	.6097	.5335	.503	.4572
12	.4572	.4572	.4191	
13	.4572	.4572	.4191	.4572
14	.4572		.4191	.4572
15	.4572	.4572		.4572
16	.4572	.4572		.4572
17	.4572	.4572	.9221	.4572
18	.6097	.5335	1.0059	.7621
19	.7621	.8383	1.0898	.9145
20	.7621	.7621	.8383	
21	.6097		.5868	.6859
22	.5335	.5335	.4239	.4572
23	.381		.3353	.381
24	.3353	.3048	.4572	.3048
Max	**.7621**	**.8383**	**1.0898**	**.9145**
Min	**.3048**	**.3048**	**.3353**	**.3048**
Avg	**.4735**	**.4853**	**.6209**	**.4614**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ I SUB-DN.[100] BU 6335
Substation No/ Name :- 274035 / 33/11 KV AKLUJ S/STN.
Feeder No / Name : 206 / 11 KV MIDC GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677	.1524		.1524
2	.1677	.1524		.1677
3	.1677	.1524		.1677
4	.1677	.1524		.1524
5	.1981	.1524	.1524	.2012
6	.2515	.2286	.1524	.2515
9	.1829		.1524	.1524
10	.2286	.1524	.1524	.1981
11	.3048	.3048	.218	.3048
12	.3048	.2286	.2515	
13		.3048	.2515	.3048
14	.3048		.3353	.3048
15	.3048	.3048		.3048
16	.3048	.3048		.3048
17	.3048	.3048	.1981	.3048
18	.3048	.3048	.2515	.3048
19	.3048	.1524	.2515	.3048
20	.3048	.1524	.218	.3048
21	.3048		.1677	.2286
22	.2286	.1524	.1677	.1829
23	.1524		.1524	.1524
24	.1524	.1524	.1524	.1677
Max	**.3048**	**.3048**	**.3353**	**.3048**
Min	**.1524**	**.1524**	**.1524**	**.1524**
Avg	**.2435**	**.2117**	**.2016**	**.2342**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ I SUB-DN.[100] BU 6335
Substation No/ Name :- 274035 / 33/11 KV AKLUJ S/STN.
Feeder No / Name : 207 / DR INAMDAR NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0274		.0203
2		.0274		.0218
3		.0274		.0218
4		.0274		.0201
5		.0244	.0229	.0237
6	.0319	.0244	.0259	.0235
7	.0319	.0244	.0198	.0285
8	.0268	.0244		.0213
9	.0244	.0244	.0198	.0168
10	.0213	.0305	.0229	.0229
11	.0335	.0381	.0213	.0305
12	.0366	.0305	.0268	.0305
13	.0457	.0381	.0436	.0305
14	.0472		.0352	.0305
15	.0518	.0594		.0305
16	.0472	.0533		.0366
17	.0472	.0564	.0335	.0396
18	.0472	.0457	.0469	.0427
19	.0472	.0381	.0319	.0396
20	.0518	.0412	.0302	.0396
21	.0427		.0251	.0366
22	.0427	.0259	.0218	.0305
23	.0274	.0259	.0339	.0274
24		.0274		.0261
Max	**.0518**	**.0594**	**.0469**	**.0427**
Min	**.0213**	**.0244**	**.0198**	**.0168**
Avg	**.0391**	**.0337**	**.0288**	**.0288**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ I SUB-DN.[100] BU 6335
Substation No/ Name :- 274037 / 33/11 KV LAWANG S/STN
Feeder No / Name : 201 / 11 KV WAGHOLI FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1265	.1326	1.8442	1.5023
2	.1265	.1326	1.8023	1.5023
3	.1265	.1658	1.8652	1.5023
4	.1265	.1658	1.8442	1.6604
5	.1581	.1658	1.8652	1.6604
6	.1581	.1989	1.9281	1.7185
7	.1562	.1658	2.0576	2.0309
8	.1562	.1326	2.2043	2.1872
9	.1562	.1326	2.1862	2.4006
10		.125	.1326	.1372
11	2.2634	2.2653	.1326	.1372
12	2.3472	2.3434	.1326	.1372
13	2.3472	2.2377		.1372
14	2.2634	2.1605		.1372
15	2.2634	2.3434		.1372
16	2.0119	2.3434		.1372
17	2.1795	2.2653		.1372
18	2.2672	2.4006		.1696
19	.1658	.1715	.1898	.2035
20	.1658	.1715	.1898	.1989
21	.1989	.1372	.1898	.2035
22	.1989	.1372	.1581	.1696
23	.1658	.1372	.1581	.1357
24	.1265	.1326	1.8861	1.5813
Max	**2.3472**	**2.4006**	**2.2043**	**2.4006**
Min	**.1265**	**.125**	**.1326**	**.1357**
Avg	**.8807**	**.8652**	**1.1537**	**.8302**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ I SUB-DN.[100] BU 6335
Substation No/ Name :- 274037 / 33/11 KV LAWANG S/STN
Feeder No / Name : 203 / 11 KV LAWANG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5384	1.5384	.1174	.1296
2	1.6004	1.5384	.1147	.1326
3	1.6004	1.5384	.1311	.1326
4	1.6804	1.6194	.1638	.1296
5	1.8404	1.7814	.1638	.16
6	1.8404	1.8623	.1966	.192
7	2.0005	1.9433	.1966	.144
8	2.1605	2.0243	.1966	.128
9	2.2405	1.9433	.1658	.1638
10	.2058	.1562	.116	.1311
11	.1311	.125	2.0243	2.3266
12	.1296	.125	2.1052	2.4577
13	.1311	.125		2.3758
14	.1311	.125		2.2939
15	.1311	.125		2.2939
16	.0983			2.2939
17	.0983	.125		2.2939
18	.1658	.1296		2.2672
19	.1823	.1311	.1943	.1989
20	.1823	.1638	.1943	.1989
21	.1658	.1638	.1943	.1658
22	.1658	.1311	.1619	.1492
23	.1658	.1147	.1619	.1492
24	1.5384	1.5384	.1147	.1296
Max	**2.2405**	**2.0243**	**2.1052**	**2.4577**
Min	**.0983**	**.1147**	**.1147**	**.128**
Avg	**.8385**	**.8290**	**.3730**	**.8766**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ I SUB-DN.[100] BU 6335
Substation No/ Name :- 274037 / 33/11 KV LAWANG S/STN
Feeder No / Name : 205 / J K SANGAM FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5257	1.5223	.1311	.1174
2	1.4922	1.5384	.1311	.1174
3	1.4419	1.5708	.1311	.1174
4	1.5927	1.5708	.1638	.1677
5	1.7736	1.6032	.1966	.2012
6	1.8724	1.7004	.2622	.2321
7	2.0056	1.8623	.2622	.1989
8	1.989	1.9109	.2458	.1989
9	1.989	2.0081	.2321	.1966
10	.1966	.0983	.1326	.1638
11	.0983	.0819	2.0243	2.2119
12	.0972	.0819	2.0243	2.3758
13	.0983	.0819		2.2939
14	.0983	.0791		2.2939
15	.0983	.0819		2.2939
16	.0983			2.2939
17	.0983	.0983		2.2119
18	.1326	.1311		2.2186
19	.1658	.1966	.2012	.1943
20	.1658	.1966	.2012	.1658
21	.1326	.1638	.2012	.1326
22	.1326	.1638	.1677	.116
23	.116	.1311	.1341	.0995
24	1.5592	1.4899	.1311	.1174
Max	**2.0056**	**2.0081**	**2.0243**	**2.3758**
Min	**.0972**	**.0791**	**.1311**	**.0995**
Avg	**.7904**	**.7984**	**.3874**	**.8638**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ I SUB-DN.[100] BU 6335
Substation No/ Name :- 274037 / 33/11 KV LAWANG S/STN
Feeder No / Name : 206 / Vajrai FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9907		.1457	.1389
2	1.9907		.1457	.1389
3	2.0216		.1457	.1235
4	2.0988		.1619	.1389
5	2.2222		.1619	.1677
6	2.332		.1781	.1677
7	2.4234		.1781	.1829
8	2.5758		.1943	.1981
9	2.6063		.1989	.1619
10	.1943		.2155	.2105
11	.1134		2.8502	3.3198
12	.0972		3.1579	3.3522
13	.0972			3.3684
14	.0972	.0903		3.4818
15	.0972	.1067		3.6437
16	.0972	.1372		3.6866
17	.0972	.1067		3.6437
18	.1823	.1457		3.2388
19	.2652	.2105	.2006	.2105
20	.2486	.1943	.2006	.2105
21	.2321	.1781	.1852	.1989
22		.1619	.1852	.1823
23		.1619	.1543	.1658
24	2.0062		.1619	.1543
Max	**2.6063**	**.2105**	**3.1579**	**3.6866**
Min	**.0972**	**.0903**	**.1457**	**.1235**
Avg	**1.0949**	**.1493**	**.4901**	**1.2703**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ I SUB-DN.[100] BU 6335
Substation No/ Name :- 274037 / 33/11 KV LAWANG S/STN
Feeder No / Name : 207 / 11 KV CANAL AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4973	.4641	1.7295	1.8347
2	.4973	.4807	1.749	1.8004
3	.5415	.4807	1.7833	1.8347
4	.5144	.4973	1.8004	1.9033
5	.5087	.5138	1.8861	1.989
6	.5087	.5304	1.9719	2.0008
7	.5256	.5304	2.0919	2.2721
8	.4917	.5304	2.3491	2.3739
9	.4917	.4807	2.1052	2.4006
10	.5144	.4917	.4641	.4917
11	2.452	2.2721	.431	.4458
12	2.572	2.323	.4475	.4458
13	2.6063	2.323		.4458
14	2.3491	2.1704		.4409
15	2.4348	2.323		.4458
16	2.4863	2.4078		.4458
17	2.4863	2.2891		.4458
18	2.1862	2.2291		.4973
19	.5304	.5487	.5487	.5304
20	.5138	.5487	.5487	.5304
21	.5138	.5316		.5138
22	.4973	.5316	.5788	.5138
23	.4973	.5316	.5144	.4973
24	.4973	.4641	1.749	1.8347
Max	**2.6063**	**2.4078**	**2.3491**	**2.4006**
Min	**.4917**	**.4641**	**.431**	**.4409**
Avg	**1.1548**	**1.1039**	**1.3382**	**1.1223**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ I SUB-DN.[100] BU 6335
Substation No/ Name :- 274047 / 33/11 KV VIZORI S/STN.
Feeder No / Name : 202 / VIZORI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8848	.8907	.8642	.3441
2		.8907	.9221	.8951	.3163
3		.9393	1.0059	.9414	.3201
4		.9831	.9602	1.0494	.3593
5		.9922	1.0402	1.1111	.4321
6		1.0311	1.0526	1.1728	.4696
7		1.1717	1.2631	1.25	.5281
8		1.358	1.5223	1.4506	.5312
9		1.3435	1.5684	1.4815	.5344
10		.1372	.1219	.1067	.1372
11		.1067	.1067	.061	.0914
12		.1067	.0914	.0762	.0829
13			.0914	.061	.0829
14				.0762	.061
15					.9755
16			.1219		.1067
17		.1219	.1829		.1219
18		.2429	.2195	.0905	.2591
19		.3077	.3475	.1448	.3239
20		.3239	.3109	.2149	.3239
21		.4534	.2926	.2896	.3563
22		.3077	.3109	.2454	.3239
23	.2753	.2915	.3658	.2629	.3077
24		.9069	.8802	.8333	.3605
Max	**.2753**	**1.358**	**1.5684**	**1.4815**	**.9755**
Min	**.2753**	**.1067**	**.0914**	**.061**	**.061**
Avg	**.2753**	**.6450**	**.6213**	**.6037**	**.3229**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ I SUB-DN.[100] BU 6335
Substation No/ Name :- 274047 / 33/11 KV VIZORI S/STN.
Feeder No / Name : 205 / EXPRESS FEEDER WATER SUPPLY Feeder KV- 11 / OUTGOING NON SHEDDABLE WATER SUPPLY AND UTILITY

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0335	.3401	.3768	.1989
2	.0339		.3932	.1989
3	.0332	.3521	.426	.2294
4	.0655	.4024	.426	.2968
5	.0983	.4862	.4588	.3749
6	.25	.4372	.4915	.3906
7	.2561	.421	.4915	.216
8	.2429	.4858	.4752	.4973
9	.2458	.4372	.5407	.502
10	.2896	.4572	.3506	.4115
11	.2743	.442	.3658	.547
12	.2439	.381	.5639	.4877
13		.4475	.5335	.4572
14		.4807	.3201	.3048
15		.4572	.3201	.3506
16		.4115	.3506	.3506
17	.1981	.4268	.3506	.3506
18	.3018	.5243	.2949	.421
19	.3521	.4424	.2785	.4696
20	.3688	.426	.2753	.503
21	.3563	.426	.2561	.5182
22	.3401	.3932	.2343	.4858
23	.3401	.3277	.2105	.4534
24	.0332	.3239	.3605	.213
Max	**.3688**	**.5243**	**.5639**	**.547**
Min	**.0332**	**.3239**	**.2105**	**.1989**
Avg	**.2179**	**.4230**	**.3810**	**.3845**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ I SUB-DN.[100] BU 6335
Substation No/ Name :- 274115 / 33/11 KV SANGAM
Feeder No / Name : 202 / BABHULGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1677	.1865	.1865	.1696
2		.1677	.1696	.1865	.1696
3		.1844	.1696	.1865	.1696
4			.1865	.1865	.2035
5		.2012	.1865	.1865	.2035
6		.2347	.2035	.2035	.2374
7			.2204	.2204	.2374
8		.3391	.2204	.2374	.2035
9		.2035	.2035	.2204	.2035
10		.2374	.2035	.2035	.1696
11		1.0682	1.153	1.1869	1.2717
12		1.1022	1.1869	1.3565	1.5261
13		1.153	1.1361		1.6956
14		1.1869	1.1022		1.7804
15		1.1361	1.0513		1.7804
16		1.0174			1.6956
17		1.0682	1.1022		1.6108
18		1.153	1.1361		1.5261
19		.2035	.2035	.2035	.2035
20		.2035	.2035	.2035	.2035
21		.2035	.1865	.2035	.2035
22	.1677	.2035	.1865	.1696	.2035
23	1.6766	.1865	.1865	.1696	.1696
24		.1677	.2204	.1865	.1696
Max	**1.6766**	**1.1869**	**1.1869**	**1.3565**	**1.7804**
Min	**.1677**	**.1677**	**.1696**	**.1696**	**.1696**
Avg	**.9222**	**.5359**	**.4785**	**.3165**	**.6670**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ I SUB-DN.[100] BU 6335
Substation No/ Name :- 274143 / 33/11 kV ANANDNAGAR
Feeder No / Name : 201 / 11 KV CHAKORE FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1888	.9755	.9755	1.0364
2		1.1888	1.0059	1.0059	1.0974
3		1.2041	1.0669	1.0364	1.1279
4		1.2803	1.1888	1.0669	1.2193
5		1.3565	1.2498	1.1888	1.3413
6		1.5546	1.4632	1.6766	1.5851
7		1.829	1.6766	1.9052	1.7985
8		1.8747	1.9509	2.0119	1.8595
9		1.7833	2.0119	1.9814	1.9204
10		.2743	.3048	.3048	.3048
11		.3048	.2134	.2134	.1981
12		.3353	.1981		.1981
13		.3658	.2134		.1829
14			.2286		.1677
15			.2591		.1677
16		.381	.2286		.2439
17		.4115			.2743
18	1.5699	.4268	.4115		
19	.442	.4877	.442	.4877	.3353
20	.442	.4268	.442	.4268	.3658
21	.4268	.3963	.442	.4572	.3963
22	.4268	.4268	.4268	.4572	.381
23	.3963	.4572	.4268	.4268	.442
24		1.1279	.9145	.945	1.0059
Max	**1.5699**	**1.8747**	**2.0119**	**2.0119**	**1.9204**
Min	**.3963**	**.2743**	**.1981**	**.2134**	**.1677**
Avg	**.6173**	**.8674**	**.7714**	**.9746**	**.7674**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ I SUB-DN.[100] BU 6335
Substation No/ Name :- 274143 / 33/11 kV ANANDNAGAR
Feeder No / Name : 202 / 11 KV KONDBAVI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4115	.4268	.4268	.4572
2		.4115	.4572	.4268	.4268
3		.4115	.4572	.4268	.4268
4		.4268	.4877	.4268	.4572
5		.4877	.5182	.4572	.4877
6		.5335	.5487	.5335	.5182
7		.503	.5792	.5335	.5487
8		.4268	.5182	.5335	.5487
9		.381	.4268	.3658	.4268
10		.3048	.3048	.3201	.3048
11		1.1736	1.6461	2.0576	2.1643
12		1.2803	1.9357		2.1795
13		1.3413	1.8595		2.1948
14		1.4327	1.9966		2.1643
15		1.5089	2.0881		2.1338
16		1.6309	2.1643		2.1643
17		1.8138	1.9966		2.1491
18	.3963		1.7833		2.1338
19	.4268	.4572	.4268	.5487	.3353
20	.442	.4268	.442	.4572	.3658
21	.442	.3963	.4268	.4572	.3963
22	.4268	.3963	.4268	.4268	.4115
23	.4268	.4268	.4268	.4268	.4268
24		.4115	.4268	.4268	.4572
Max	**.442**	**1.8138**	**2.1643**	**2.0576**	**2.1948**
Min	**.3963**	**.3048**	**.3048**	**.3201**	**.3048**
Avg	**.4268**	**.7389**	**.9488**	**.5442**	**1.0117**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ I SUB-DN.[100] BU 6335
Substation No/ Name :- 274143 / 33/11 kV ANANDNAGAR
Feeder No / Name : 203 / 11 KV VATHPHALI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0457	.0457	.0457	.0457
2		.0457	.061	.0457	.061
3		.0457	.061	.0457	.061
4		.0457	.0762	.061	.0762
5		.061	.0914	.0762	.0914
6		.0914	.0914	.0914	.0914
7		.0914	.1219	.0914	.1219
8		.0914	.0914	.0762	.1067
9		.061	.061	.0762	.0914
10		.0305	.0457	.0305	.0457
11		.1219	.2591	.3201	.4115
12		.1677	.3048		.4268
13		.2134	.3658		.4115
14		.2743	.3963		.3963
15		.3048	.442		.381
16		.3353	.3658		.381
17		.2743	.3048		.4287
18	.0762		.2896		.3658
19	.0914	.0914	.0762	.1219	.061
20	.0914	.0762	.0914	.1067	.0457
21	.0914	.0762	.0914	.0914	.0762
22	.0762	.0914	.0762	.0762	.0914
23	.061	.0457	.0762	.0457	.061
24		.0457	.0457	.0457	.0457
Max	**.0914**	**.3353**	**.442**	**.3201**	**.4287**
Min	**.061**	**.0305**	**.0457**	**.0305**	**.0457**
Avg	**.0813**	**.1186**	**.1638**	**.0852**	**.1823**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ I SUB-DN.[100] BU 6335
Substation No/ Name :- 274143 / 33/11 kV ANANDNAGAR
Feeder No / Name : 204 / vaibhav agrotech ht consumer Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS (CONTINOUS PROCESS)(NO STAGGERING)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0017	.0017	.0017	.0017
2		.0017	.0017	.0015	.0017
3		.0017	.0017	.0017	.0017
4		.0017	.0017	.0017	.0017
5		.0017	.0017	.0017	.0017
6		.0017	.0017	.0017	.0017
7		.0017	.0017	.0017	.0017
8		.0017	.0017	.0017	.0017
9		.0017	.0017	.0017	.0017
10		.0017	.0017	.0015	.0017
11		.0017	.0017	.0017	.0017
12		.0017	.0017		.0017
13		.0017	.0017		.0017
14		.0017	.0017		.0017
15		.0017	.0017	.0017	.0017
16		.0017	.0017	.0017	.0017
17		.0017	.0017	.0017	.0017
18	.0017	.0017	.0017	.0017	.0017
19	.0017	.0017	.0017	.0017	.0017
20	.0017	.0017	.0017	.0017	.0017
21	.0017	.0017	.0017	.0017	.0017
22	.0017	.0017	.0017	.0017	.0017
23	.0017	.0017	.0017	.0017	.0017
24		.0017	.0017	.0017	.0017
Max	**.0017**	**.0017**	**.0017**	**.0017**	**.0017**
Min	**.0017**	**.0017**	**.0017**	**.0015**	**.0017**
Avg	**.0017**	**.0017**	**.0017**	**.0017**	**.0017**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ I SUB-DN.[100] BU 6335
Substation No/ Name :- 274196 / 33/11KV KHANDALI SUB STATION
Feeder No / Name : 201 / 11KV KHANDALI NAGTHANA SINGLE PHASING FEEDER Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2229	.2481	.2058	.2743
2		.2229	.2126	.2058	.2743
3		.2401	.2126	.2229	.2572
4		.2572	.2126		.2401
5		.3086	.3189	.2572	.2915
6		.3772	.3544	.3772	.3429
7		.3601	.3898	.3772	.4115
8		.3544	.3366	.2835	.4252
9		.2835	.3544	.3012	.4075
10		.1949	.2126	.2658	.2481
11		.7265	.7973	.815	.8682
12		.7202	.7973		.8859
13		.6859	.7619		.8859
14		.6516	.7442		.8682
15		.6001	.7087		.815
16			.7716		.8328
17		.6733	.703		.7265
18		.7265	.7373		
19		.3366	.2915	.2401	.2658
20		.3012	.3086	.2572	.3189
21	.2572	.3012	.2743	.2572	.3012
22	.2401	.2658	.2058	.2572	.3012
23	.2401	.2481	.2058	.2743	.2658
24		.2229	.2481	.2058	.2572
Max	**.2572**	**.7265**	**.7973**	**.815**	**.8859**
Min	**.2401**	**.1949**	**.2058**	**.2058**	**.2401**
Avg	**.2458**	**.4036**	**.4337**	**.3002**	**.4681**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ I SUB-DN.[100] BU 6335
Substation No/ Name :- 274196 / 33/11KV KHANDALI SUB STATION
Feeder No / Name : 202 / 11KV DATTANAGAR FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0631	1.1765	.9774	1.0288
2		1.0631	1.1765	.9945	
3		1.0974	1.1765	.9945	1.1145
4		1.2003	1.3032	1.0117	1.166
5		1.2003	1.3032	1.0802	1.2003
6		1.286	1.448	1.3032	1.5432
7			1.5384	1.5089	1.5947
8		1.6118	1.773	1.8446	1.8804
9		1.6655	1.8088	1.7909	1.6644
10		.394	.3582	.394	.394
11		.3582	.2865	.2686	.3403
12		.3086	.2686		.3224
13		.2915	.2686		.2865
14		.3086	.2686		.2865
15		.2572	.3045		.2865
16			.2743		
17		.3801	.3429		.4163
18		.4706	.4458		
19		.5611	.4801	.4287	.4525
20		.5611	.4801	.3772	.5068
21	.4287	.543	.4287	.4458	.5068
22	.3944	.5249	.3944	.4115	.4706
23	.3772	.5068	.3944	.4287	.4706
24		1.0631	1.2127	.9431	.9431
Max	**.4287**	**1.6655**	**1.8088**	**1.8446**	**1.8804**
Min	**.3772**	**.2572**	**.2686**	**.2686**	**.2865**
Avg	**.4001**	**.7598**	**.7880**	**.8943**	**.8036**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ I SUB-DN.[100] BU 6335
Substation No/ Name :- 274196 / 33/11KV KHANDALI SUB STATION
Feeder No / Name : 203 / 11KV BHOSALE WASTI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2743	.192	.2401	.2572
2		.2743	.192	.2134	.2572
3		.2743	.16	.2134	.2401
4		.2896	.16	.2439	.2229
5		.3048	.2241	.2743	.2572
6		.3506	.2881	.3658	.3086
7		.3353	.3361	.3353	.3944
8		.2881	.2401	.2721	.3201
9		.2401	.2241	.208	.3201
10		.192	.192	.192	.2241
11		1.6324	2.0005	1.9204	2.0965
12		2.1948	2.0805		2.1605
13		2.1434	2.0805		2.1605
14		2.1434	2.0805		2.2405
15		1.989	2.0325		2.2725
16			1.9052		2.0805
17		1.8084	1.8442		1.9364
18		1.8884	1.9814		
19		.2881	.2591	.3086	.192
20		.2881	.2743	.2915	.2721
21	.3048	.2561	.2591	.2915	.2721
22	.2743	.2561	.2439	.3086	.2401
23	.2743	.2401	.2439	.2915	.2241
24		.2743	.2241	.2286	.2743
Max	**.3048**	**2.1948**	**2.0805**	**1.9204**	**2.2725**
Min	**.2743**	**.192**	**.16**	**.192**	**.192**
Avg	**.2845**	**.7924**	**.8216**	**.3646**	**.8358**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ I SUB-DN.[100] BU 6335
Substation No/ Name :- 274196 / 33/11KV KHANDALI SUB STATION
Feeder No / Name : 204 / 11KV ITI KHADALI FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
8	.0129	.0111	.0148
Max	**.0129**	**.0111**	**.0148**
Min	**.0129**	**.0111**	**.0148**
Avg	**.0129**	**.0111**	**.0148**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ I SUB-DN.[100] BU 6335
Substation No/ Name :- 274198 / 33/11 kv BABULGOAN SUB STATI
Feeder No / Name : 201 / BABULGOAN FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7956	.4049	.3269	.3121	.407
2	.8048	.3887	.3201	.3121	.39
3	.7956	.3841	.2972	.381	.39
4	.8192	.426	.3048	.3658	.4024
5	.8192	.4858	.3311	.3567	.4527
6	.8421		.3864	.4115	.5138
7	.8907	.5182	.4161	.4365	.4862
8	1.073	.3048	.4214	.381	.4694
9	1.0442	.2622	.2526		.3222
10	.2652	.2012	.1981	.1829	.2429
11	.2012	1.0517	.8688	.9362	1.0212
12	.1677	1.0254	.9181		1.1142
13	.1677	1.0364	.945		1.1568
14	.1823	1.0254	.9783		1.1271
15		.9722	.9332		1.1012
16		.8688	.9568		1.1305
17		.9105	.9259		1.17
18		.8471	.8471		1.1233
19		.3086	.3201	.3121	.3321
20		.2675	.3658	.3462	.3953
21		.3201	.3353	.3506	.4111
22		.3462	.3462	.3418	.3953
23		.3506	.3353	.3269	.3321
24	.779	.3506	.3612	.3269	.3353
Max	**1.073**	**1.0517**	**.9783**	**.9362**	**1.17**
Min	**.1677**	**.2012**	**.1981**	**.1829**	**.2429**
Avg	**.6432**	**.5677**	**.5288**	**.3800**	**.6343**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ I SUB-DN.[100] BU 6335
Substation No/ Name :- 274198 / 33/11 kv BABULGOAN SUB STATI
Feeder No / Name : 202 / WAFEGAON FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.216	.9145	.9259	.8025	.9061
2	.2006	.9259	.9031	.884	.884
3	.2006	.9259	.888	.8951	.8993
4	.1829	.9297	1.0686	.9259	.9259
5	.2006	.9297	1.0669	1.0536	.945
6	.2623	.9602	1.2346	1.0686	.9722
7	.3201	1.0822	1.1888	1.0957	1.0669
8	.216	1.1584	1.2342	1.174	1.3735
9	.2006	1.2346	1.2944		1.4661
10	.2134	.0926	.1957	.1189	.0617
11	1.5546	.0892	.1677	.1635	.1189
12	1.5851	.0914	.104		.0914
13	1.6156	.1219	.1204		.1107
14	1.6156	.1054	.1067	.1189	.1265
15		.1219	.1204	.1505	.1581
16		.104	.1355	.1806	.1898
17		.1932	.1486	.2286	.2214
18		.2709	.2229	.2675	.253
19		.2286	.2743	.2559	.2688
20		.1981	.2972	.2743	.3005
21		.1932	.2743	.2709	.2846
22		.1806	.2229	.2743	.2688
23		.1783	.2408	.2378	.2372
24	.2134	.9105	.8796	.7727	.888
Max	**1.6156**	**1.2346**	**1.2944**	**1.174**	**1.4661**
Min	**.1829**	**.0892**	**.104**	**.1189**	**.0617**
Avg	**.5865**	**.5059**	**.5548**	**.5340**	**.5424**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274040 / 33/11KV NEWARE S/SN.
Feeder No / Name : 201 / 11KV JAMBHUD SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743			.3077	1.3603		1.4022
2	.2743			.3077	1.5043		1.448
3	.2743			.3077	1.5384		1.4022
4	.2743			.3077	1.5384		1.4899
5	.2743			.3077	1.5384		1.4899
6	.2743			.3258	1.5927		1.4899
7	.2926			.3258	1.6289		1.5775
8	.2926			.3258	1.7194		1.8404
9	.2715	.3258	.2743		1.8404	2.0119	
10	.2534	.2715	.2195		.2172	.2172	
11	2.0157	2.3137	2.1491		.2172	.2534	
12	2.0157	2.3663	2.1849		.2172		
13		2.3663	2.0595		.2534		
14	2.1384	2.3663	2.0595		.2534		
15	2.2786	2.4188	2.364		.2715		
16	2.3663	2.489	2.364		.2715		
17		2.5431		2.3282			.3658
18		2.4177		2.0774			.3658
19		.2195		.2743		.2534	.2743
20		.2743		.2926		.2172	.2743
21		.2743		.2743		.2172	.2743
22		.2743		.2195		.2172	.2743
23		.2743	.2896	.2195		.2172	.2195
24	.2743			.3077	1.5203		1.448
Max	**2.3663**	**2.5431**	**2.364**	**2.3282**	**1.8404**	**2.0119**	**1.8404**
Min	**.2534**	**.2195**	**.2195**	**.2195**	**.2172**	**.2172**	**.2195**
Avg	**.8653**	**1.4130**	**1.5516**	**.5318**	**1.0284**	**.4506**	**.9773**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274040 / 33/11KV NEWARE S/SN.
Feeder No / Name : 202 / 11KV KONDARPATTA FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1142		1.0526			
2	1.1142		1.0526			
3	1.1142		1.1012			
4	1.1469		1.1012			
5	1.3108		1.1336			
6	1.3763		1.2146			
7	1.5074		1.4575			
8	1.6876		1.587			
9	1.7328	1.8351				
11				1.5384	1.6385	
12				1.6194		
13				1.6194		
14				1.6518		
15				1.6194		
16				1.7004		
17						1.7204
18						1.7204
24	1.065		1.0526			
Max	**1.7328**	**1.8351**	**1.587**	**1.7004**	**1.6385**	**1.7204**
Min	**1.065**	**1.8351**	**1.0526**	**1.5384**	**1.6385**	**1.7204**
Avg	**1.3169**	**1.8351**	**1.1948**	**1.6248**	**1.6385**	**1.7204**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274040 / 33/11KV NEWARE S/SN.
Feeder No / Name : 203 / NEWARE FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					1.2955		1.2146
2					1.2955		
3					1.3279		1.2146
4					1.3279		1.2146
5					1.3441		1.2146
6					1.3765		1.2146
7					1.3765		1.2146
8					1.4251		1.3765
9					1.5384	1.5074	
11	1.5565	1.7204	1.7204				
12	1.5384	1.7004	1.7204				
13	1.5384	1.7204	1.6385				
14	1.5384	1.7004	1.7204				
15	1.4575	1.7328	1.7204				
16	1.5384	1.6194	1.7204				
17		1.6518		1.6194			
18		1.6194		1.5708			
24					1.3279		1.2146
Max	**1.5565**	**1.7328**	**1.7204**	**1.6194**	**1.5384**	**1.5074**	**1.3765**
Min	**1.4575**	**1.6194**	**1.6385**	**1.5708**	**1.2955**	**1.5074**	**1.2146**
Avg	**1.5279**	**1.6831**	**1.7068**	**1.5951**	**1.3635**	**1.5074**	**1.2348**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274040 / 33/11KV NEWARE S/SN.
Feeder No / Name : 204 / 11KV NADURE FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9717		.9231			
2	.9717		.9231			
3	1.004		.9393			
4	1.004		.9393			
5	1.0526		.9231			
6	1.0526		.9717			
7	1.085		.9717			
8	1.166		.9717			
9	1.166	1.166				
11				1.2146	1.3108	
12				1.2955		
13				1.2955		
14				1.3765		
15				1.2955		
16				1.2955		
17						1.3765
18						1.4575
24	.9393		.8907			
Max	**1.166**	**1.166**	**.9717**	**1.3765**	**1.3108**	**1.4575**
Min	**.9393**	**1.166**	**.8907**	**1.2146**	**1.3108**	**1.3765**
Avg	**1.0413**	**1.166**	**.9393**	**1.2955**	**1.3108**	**1.417**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274040 / 33/11KV NEWARE S/SN.
Feeder No / Name : 205 / NEWARE GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6535			.6535	.6535		.7468
2	.6535			.7095	.6535		.7392
3	.7468			.7842	.7468		.7316
4	.8402			.924	.8402		.8316
5	1.0269			1.0608	1.0269		.9145
6	.9335			1.1088	1.0269		1.0164
7	.7468			.8962	.9335		.924
8	.5975			.7468	.7842		.7095
9	.5228	.5544	.4572		.6535	.5601	
10	.3696	.5487	.4572		.4572	.5601	
11	.3658	.3658	.3658		.4024	.3734	
12	.2743	.3696	.3658		.3292		
13	.2743	.3696			.3292		
14	.2772	.3734	.3658		.2743		
15	.3326	.3734	.2772		.2743		
16	.3734	.3734	.2957		.2743		
17		.3734		.3734			.3734
18		.4668		.6535			.5228
19		.7468		.7468		.8402	.7468
20		.6535		.6908		.7468	.7468
21		.7095		.6535		.6535	.7468
22		.6535		.6535		.6535	.6535
23		.6535	.5975	.6535	.5975	.6535	.5975
24	.6161			.6535	.7468		.6535
Max	**1.0269**	**.7468**	**.5975**	**1.1088**	**1.0269**	**.8402**	**1.0164**
Min	**.2743**	**.3658**	**.2772**	**.3734**	**.2743**	**.3734**	**.3734**
Avg	**.5650**	**.5057**	**.3978**	**.7476**	**.6113**	**.6301**	**.7284**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274041 / NIMGAON
Feeder No / Name : 201 / 11KV SHRI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9145	.9145	1.1431	.1524
2		.9145	.9145	1.2193	.1524
3		1.0669	1.0669	1.2955	.1524
4		1.0669	1.0669	1.3717	.1524
5		1.2193	1.0669	1.448	.1524
6		1.3717	1.2193	1.5242	.1524
7		1.5242	1.5242	1.6766	.0762
8		1.6004	1.6766	1.7528	.0762
9	1.829	1.6004	1.829	1.829	.0762
10	.0762	.0762	.0762	.0762	.0762
11	.0762	.0762	.0762	1.0669	1.3717
12	.0762	.0762	.0762		1.5242
13	.0762	.0762	.0762		1.6766
14	.0762	.0762	.0762		1.6766
15	.0762		.0762		1.6766
16	.0762		.0762		1.6766
17	.0762		.0762		1.6004
18	.0762	.0762	.0762		1.5242
19	.1524	.1524	.1524	.1524	.1524
20	.1524	.1524	.1524	.1524	.1524
21	.1524	.1524	.1524	.1524	.1524
22	.1524	.1524	.1524	.1524	.1524
23	.0762	.1524	.1524	.1524	.1524
24		.9145	.9145	1.1431	.1524
Max	**1.829**	**1.6004**	**1.829**	**1.829**	**1.6766**
Min	**.0762**	**.0762**	**.0762**	**.0762**	**.0762**
Avg	**.2134**	**.6387**	**.5684**	**.9593**	**.6192**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274041 / NIMGAON
Feeder No / Name : 202 / 11 KV NARALACHIWADI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1219	.1524	.1219	.7621
2		.1219	.1524	.1219	.7621
3		.1067	.1219	.1219	.7621
4		.1067	.1524	.1219	.7621
5		.1524	.1524	.0762	.8383
6		.1524	.1219		.9145
7		.0914	.1219	.1219	.9145
8		.0914	.1524	.1219	1.0669
9	.1067	.0914	.1067	.0762	1.0669
10	.1067	.0762	.1067	.0762	.0762
11	.7621	.7621	.9145	1.0212	.061
12	.9145	.7621	.9907		.061
13	1.0669	.8383	.9907		.061
14		1.0059	.9907		.061
15	1.0669	.9907	.9145		.061
16	.9145	.9145	.9145		.061
17	.9145	.9145	.8383		.0762
18	.9145	.9145	.7621		.0914
19	.1524	.1524	.061	.1219	.1524
20	.1524	.1524	.1219	.1219	.1524
21	.1524	.1524	.1524	.1219	.1524
22	.1524	.1524	.1524	.1219	.1524
23	.1524	.1524	.1219	.1219	.1524
24		.1524	.1524	.1219	.7621
Max	**1.0669**	**1.0059**	**.9907**	**1.0212**	**1.0669**
Min	**.1067**	**.0762**	**.061**	**.0762**	**.061**
Avg	**.5378**	**.3804**	**.3925**	**.1695**	**.4160**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274041 / NIMGAON
Feeder No / Name : 203 / 11KV NIMGAON VILLAGE AG/SDT Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1524	.1524	.1524	.381
2		.1524	.1524	.1524	.381
3		.1524	.1524	.1524	.381
4		.1524	.1524	.1524	.4572
5		.1524	.1524	.1524	.5335
6		.1524	.1524	.1524	.5335
7		.0762	.0762	.1524	.6097
8		.0762	.0762	.1524	.6859
9	.1067	.0762	.0762	.0762	.6859
10	.1067	.0762	.0762	.0762	.0762
11	.7621	.5335	.6097	.4572	.0762
12	.7621	.6097	.6859		.061
13	.7621	.6859	.7621		.061
14	.9145	.6859	.7621		.061
15	.9145	.6859	.6859		.0457
16	.7621	.6097	.6097		.061
17	.7621	.6097	.6097		.061
18	.7621	.6097			.0762
19	.1524	.1524	.1524	.1524	.1524
20	.1524	.1524	.1524	.1524	.1524
21	.1524	.1524		.1524	.1524
22	.1524	.1524	.1524	.1524	.1524
23		.1524	.1524	.1524	.1524
24		.1524	.1524	.1524	.381
Max	**.9145**	**.6859**	**.7621**	**.4572**	**.6859**
Min	**.1067**	**.0762**	**.0762**	**.0762**	**.0457**
Avg	**.5160**	**.2985**	**.3048**	**.1614**	**.2655**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274041 / NIMGAON
Feeder No / Name : 204 / NIMGAON GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0457	.0762	.0914	.0762
2		.0457	.0762	.0914	.0762
3		.061	.0762	.0914	.0762
4		.061	.0762	.1067	.0762
5		.0762	.0762	.1067	.0914
6		.0762	.0762	.1219	.1067
7		.061	.0914	.1219	.1067
8		.061	.0914	.0914	.0914
9	.061	.061	.0762	.0914	.0762
10	.061	.061	.061	.0914	.0762
11	.061	.0762	.061	.061	.0762
12	.061	.0762	.061		.061
13	.061	.0914	.0457		.061
14	.0457	.0914	.0457		.061
15	.0457	.0762	.061		.061
16	.0457	.0762	.0457		.061
17	.0457	.0762	.061		.0762
18		.0762			.0762
19	.061	.0762	.061	.0762	.1067
20	.0762	.0762	.061	.0914	.1372
21	.0762	.0762		.0914	.1219
22	.061	.0762	.0914	.0914	.1219
23	.061	.0762	.0914	.0914	.1219
24		.0457	.0762	.0914	.0914
Max	**.0762**	**.0914**	**.0914**	**.1219**	**.1372**
Min	**.0457**	**.0457**	**.0457**	**.061**	**.061**
Avg	**.0588**	**.0699**	**.0700**	**.0941**	**.087**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274041 / NIMGAON
Feeder No / Name : 205 / naganemala SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.381	.4572	.4572	.1524
2		.381	.5335	.5335	.1524
3		.4572	.5335	.6097	.1524
4		.4572	.5335	.6097	.1524
5		.4572	.5335	.6097	.1524
6		.4572	.5792	.6097	.1524
7		.5335	.5792	.6097	.1524
8		.6097	.6097	.6859	.1524
9		.6097	.6859	.6859	.1524
10		.0762	.0914	.0762	.1524
11	.0762	.0762	.061	.0762	.5335
12	.061	.0762	.061		.6097
13		.0762	.0457		.6859
14	.061	.0457	.0457		.6859
15	.061	.0457	.0457		.6859
16	.061	.061	.0457		.6859
17	.0762	.0762	.061		.6859
18	.0762	.1067	.0762		.6859
19	.1524	.1524	.1219	.0914	.1524
20	.1524	.1524	.1219	.1524	.1524
21	.1524	.1524	.1219	.1524	.1524
22	.1524	.1524	.1219	.1524	.1524
23	.1524	.1524	.1524	.1524	.1524
24		.4572	.4572	.4572	.1524
Max	**.1524**	**.6097**	**.6859**	**.6859**	**.6859**
Min	**.061**	**.0457**	**.0457**	**.0762**	**.1524**
Avg	**.1029**	**.2585**	**.2782**	**.3954**	**.3207**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274041 / NIMGAON
Feeder No / Name : 206 / jay khanderaya SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1219	.1219	.1219	.5335
2		.1219	.1219	.1067	.5335
3		.1067	.1219	.1067	.5335
4		.1067	.1219	.1067	.6097
5		.1341	.1219	.0914	.6097
6		.1524	.0914	.0914	.6097
7		.1067	.0914	.0914	.6859
8		.1067	.0762	.0914	.7621
9		.0762	.0762	.0762	.7621
10		.0762	.0762	.0762	.0914
11	.6097	.6097	.7621	.7621	.061
12	.6859	.6859	.7621		.0457
13	.7621	.7621	.8383		.0457
14	.8383	.7621	.8383		.0457
15	.7621	.7621	.7621		.0457
16	.7621	.7621	.7621		.0457
17	.6859	.7621	.6859		.061
18	.6859	.7621	.6097		.0762
19	.1524	.1524	.1219	.1219	.0914
20	.1524	.1524	.1219	.1219	.1524
21	.1524	.1524	.1219	.1219	.1524
22	.1524		.1219	.1219	.1524
23	.1524	.1524	.1524	.1219	.1524
24		.1524	.1524	.1219	.5335
Max	**.8383**	**.7621**	**.8383**	**.7621**	**.7621**
Min	**.1524**	**.0762**	**.0762**	**.0762**	**.0457**
Avg	**.5042**	**.3365**	**.3264**	**.1443**	**.3080**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274041 / NIMGAON
Feeder No / Name : 207 / MAULI **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1524	.1524	.1524	.9145
2		.1524	.1524	.1524	.9145
3		.1524	.1524	.1524	.9145
4		.1524	.1524	.1524	1.0669
5		.1524	.1524	.1524	1.0669
6		.1524	.1524	.1524	1.0669
7		.0762	.1524	.1524	1.2193
8		.0762	.1524	.0762	1.2193
9	.0762	.0762	.0762	.0762	1.2193
10	.0762	.0762	.0762	.0762	.0762
11	.7621	.9145	.8383	.0762	.0762
12	.9145	1.0669	.9907		.0762
13	1.0669	1.0669	1.1431		.0762
14	1.2193	1.0669	1.0669		.0762
15	1.2193	1.0669	1.0669		.0762
16	1.3717		1.0669		.0762
17	1.2193	.9145	.9907		.0762
18	1.0669	.9145	.9145		.0762
19	.1524	.1524	.1524	.1524	.1524
20	.1524	.1524	.1524	.1524	.1524
21	.1524	.1524	.1524	.1524	.1524
22	.1524	.1524	.1524	.1524	.1524
23	.1524	.1524	.1524	.1524	.1524
24		.1524	.1524	.1524	.9145
Max	**1.3717**	**1.0669**	**1.1431**	**.1524**	**1.2193**
Min	**.0762**	**.0762**	**.0762**	**.0762**	**.0762**
Avg	**.6503**	**.3976**	**.4318**	**.1345**	**.4985**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274041 / NIMGAON
Feeder No / Name : 208 / KESHAVNAGAR FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2286	.3048	.3048	.1219
2		.2286	.3048	.381	.1219
3		.2286	.381	.381	.1219
4		.3048	.4572	.381	.1219
5		.3048	.4572	.4572	.1219
6		.3048	.4572	.5335	.0914
7		.4572	.4572	.5335	.0914
8		.4572	.4877	.5335	.0914
9		.4572	.5335	.5335	.0914
10		.0457	.0762	.0762	.0914
11	.0457	.0457	.061	.0762	.4572
12	.0457	.0457	.061		.4572
13	.0457	.061	.0457		.5335
14	.0305	.0762	.061		.5335
15	.0305	.0762	.061		.5335
16	.0305	.0762	.061		.4572
17	.0457	.0762	.061		.4572
18	.0457	.0762			.4572
19	.1067	.0762		.0914	.1524
20		.0762	.0914	.0914	.1524
21	.1524	.0762	.0914	.0914	.1524
22	.1524		.0914	.1219	.1219
23	.1067	.0762	.0914	.1219	.1219
24		.3048	.3048	.3048	.1219
Max	**.1524**	**.4572**	**.5335**	**.5335**	**.5335**
Min	**.0305**	**.0457**	**.0457**	**.0762**	**.0914**
Avg	**.0699**	**.1809**	**.2272**	**.2950**	**.2407**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274041 / NIMGAON
Feeder No / Name : 209 / BALIRAJA FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4572	.3048	.4572	.0762
2		.4572	.3048	.5335	.0762
3		.4572	.381	.5335	
4		.4572	.4572	.5335	.0762
5		.5335	.4572	.6097	.0762
6		.6097	.5335	.6859	.061
7		.6859	.6097	.6859	.061
8		.7621	.6859	.7621	.061
9		.7621	.7621	.8383	.061
10		.061	.0762	.061	.061
11	.0457	.061	.0457	.061	.6097
12	.0457	.061	.061		.6859
13	.0457	.061	.0457		.7621
14	.0305	.061	.0457		.7621
15	.0305	.061	.0457		.7621
16	.0305	.061	.0457		.7621
17	.0457	.061	.0457		.7621
18	.0457	.061	.061		.7621
19	.061	.061	.0762	.0762	.0914
20	.0762	.061	.0762	.0762	.0762
21	.0762	.061	.0762	.0762	.0914
22	.0762	.061	.0762	.0762	.0914
23	.0762	.061	.0762	.0762	.0914
24		.4572	.3048	.4572	.0762
Max	**.0762**	**.7621**	**.7621**	**.8383**	**.7621**
Min	**.0305**	**.061**	**.0457**	**.061**	**.061**
Avg	**.0528**	**.2706**	**.2356**	**.3882**	**.3042**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274042 / PILIV
Feeder No / Name : 201 / BACHERI **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	1.829			.503
2	1.9719	1.9052			.503
3	2.4863	2.1186			.4877
4	2.8292	2.4387			.4877
5	3.2236	2.6216			.5639
6	3.2579	2.7435	2.2862		.5792
7	2.6749	2.7892			.6097
8	3.0864	3.4294			.3658
9		.463	2.2862	2.4082	
10			.3963	.3506	
11		.2401	.3506	.381	
12		.2572	.3048		
13		.2743	.2743		
14		.2915	.2286		
15		.3086	.1677		
16			.2591		
17		.3048	.2572		.381
18			.5316		
19			.6001	.5944	
20			.6516	.5944	
21			.6859	.5792	
22			.5144	.5639	
23		.503	.6001	.5487	.6097
24	.8573	1.5242	1.6766		.4877
Max	**3.2579**	**3.4294**	**2.2862**	**2.4082**	**.6097**
Min	**.8573**	**.2401**	**.1677**	**.3506**	**.3658**
Avg	**2.3986**	**1.4142**	**.7101**	**.7526**	**.5071**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274042 / PILIV
Feeder No / Name : 202 / PILIV SECTION GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5316		.3772			.2915
2	.4973		.3772			.2915
3	.5144		.3944			.3258
4	.5144		.4287			.3772
5	.5316		.5658			.4801
6	.5658		.583	.6001		.5144
7	.5316		.5658			.5487
8	.5144		.463			.4801
9			.3772	.4458	.4801	
10			.3258	.4287	.4458	
11			.3086	.3601	.4287	
12			.2915	.3429		
13			.2401	.3429		
14			.3086	.3258		
15			.2229	.2915		
16				.2743	.2572	
17		.3429		.3601	.3086	.2743
18		.4115		.4287	.4973	
19		.5316		.6001		
20		.6001		.5658	.4801	
21		.5144		.6173	.4287	
22		.4458		.4973	.3772	
23		.3944	.5316	.4287	.3086	.2572
24			.3772	.5487		.2915
Max	**.5658**	**.6001**	**.583**	**.6173**	**.4973**	**.5487**
Min	**.4973**	**.3429**	**.2229**	**.2743**	**.2572**	**.2572**
Avg	**.5251**	**.4630**	**.3964**	**.4388**	**.4012**	**.3757**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274042 / PILIV
Feeder No / Name : 203 / CHANDAPURI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716		.6859			.1372
2	1.1145		.7164			.1372
3	1.3717		.7621			.1372
4	1.4746		.8383			.1524
5	1.4575		.8993			.1829
6	1.4918		.9907	.8383		.2286
7	1.5432		1.0669			.2591
8	1.5775		1.3717			.2286
9			1.5089	1.1431	.9907	
10			.1372	.1219	.1677	
11			.12	.1067	.0762	
12			.1372	.1067		
13			.1029	.0914		
14			.12	.0914		
15			.1029	.0914		
16				.1067		
17		.1067		.1372		1.2955
18		.1219		.1543		
19		.1524		.2401	.2439	
20		.1524		.2058	.2286	
21		.1677		.2572	.2134	
22		.1677		.2401	.1829	
23		.1524	.1677	.1886	.1524	.1524
24			.5944	.4572		.1372
Max	**1.5775**	**.1677**	**1.5089**	**1.1431**	**.9907**	**1.2955**
Min	**.7716**	**.1067**	**.1029**	**.0914**	**.0762**	**.1372**
Avg	**1.3503**	**.1459**	**.6072**	**.2693**	**.2820**	**.2771**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274042 / PILIV
Feeder No / Name : 204 / KUSMODE **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601		.2591			2.0576
2	.3429		.2591			1.8747
3	.3258		.2439			1.9814
4	.3429		.2896			2.5606
5	.3772		.3353			
6	.3601		.3353	.381		2.5149
7	.3772		.3048			2.5911
8	.2915					2.5453
9			.2915	.3201	.3048	
10			.3258	.1981	.3201	
11			3.0864	2.4082	2.5149	
12			3.2065	2.5149		
13			3.2579	2.5911		
14			3.2922	2.7435		
15			3.275	2.6978		
16				2.4996		
17		2.8959	2.4082	2.7778		.2286
18		2.7435		2.7435		
19		.3048		.3772	.3048	
20		.3353		.3429	.2896	
21		.3201		.3601	.2743	
22		.2743		.3086	.2439	
23		.2286	.3201	.2915	.2286	.2743
24	.3429		.2591	.2743		1.7528
Max	**.3772**	**2.8959**	**3.2922**	**2.7778**	**2.5149**	**2.5911**
Min	**.2915**	**.2286**	**.2439**	**.1981**	**.2286**	**.2286**
Avg	**.3467**	**1.0146**	**1.2794**	**1.4018**	**.5601**	**1.8381**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274042 / PILIV
Feeder No / Name : 205 / SULEWADI **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0762			.6859
2	.1029	.0762			.7316
3	.1029	.0762			.7926
4	.1029	.0914			.9145
5	.12	.1219			.945
6	.1372	.1372	.0762		1.0059
7	.0857	.1067			.9907
8	.0857	.0857			1.0669
9		.0857	.0762	.0762	
10		.0857	.0762	.0762	
11		1.2517	.9907	.7468	
12		1.3375	1.0669		
13		1.3375	.7316		
14		1.4575	.6859		
15		1.4746	.7468		
16			.8383		
17		1.2193	1.2517		
18			1.2003		
19			.12	.1372	
20			.1029	.1219	
21			.0857	.1219	
22			.0857	.1067	
23		.0762	.0857	.0914	.0762
24		.0762	.0762		.6097
Max	**.1372**	**1.4746**	**1.2517**	**.7468**	**1.0669**
Min	**.0857**	**.0762**	**.0762**	**.0762**	**.0762**
Avg	**.1029**	**.5096**	**.4881**	**.1848**	**.7819**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274042 / PILIV
Feeder No / Name : 207 / Sheri **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.0762			1.0822
2	.1029	.0762			1.0669
3	.1029	.381			1.1431
4	.12	.0914			1.2955
5	.1372	.1219			1.3717
6	.1372	.1677	.0762		1.3717
7	.12	.1372			1.4327
8	.1029	.1067			1.3565
9		.0857	.0762	.0762	
10			.0762	.0762	
11		1.5432	1.326	1.448	
12		1.6461	1.3717		
13		1.6289	1.3413		
14		1.5947	1.2346		
15		1.6118	1.3108		
16			1.2346		
17		1.2955			
18			1.3375		
19			.1372	.1524	
20			.12	.1372	
21			.12	.1219	
22			.0857	.1067	
23		.0762	.0857	.0914	.0762
24		.0762	.0762		.8688
Max	**.1372**	**1.6461**	**1.3717**	**1.448**	**1.4327**
Min	**.1029**	**.0762**	**.0762**	**.0762**	**.0762**
Avg	**.1158**	**.6304**	**.6256**	**.2763**	**1.1065**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274042 / PILIV
Feeder No / Name : 208 / PILIV (URBAN) GAOTHAN SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743		.2743			.1829
2	.2915		.2572			.1829
3	.3086		.2572			.2229
4	.2915		.3772			.2134
5	.3258		.4973			.2572
6	.3429		.4801	.3658		.3258
7	.3258		.4458			.3601
9			.2743	.2915	.3048	
10			.2915	.2915	.3201	
11			.2743	.2743	.2743	
12			.2572	.2743		
13			.2229	.2572		
14			.2058	.2572		
15			.1886	.2743		
16				.2743		
17		.2896	.2286	.2915	.2743	.3048
18		.3048		.3429	.2743	
19		.3353		.3258	.3353	
20		.3658		.3601	.3353	
21				.3429	.3429	
22		.3353		.2401	.3086	
23		.2743	.3506	.2572	.2229	.2286
24	.2572		.2439	.3201		.1829
Max	**.3429**	**.3658**	**.4973**	**.3658**	**.3429**	**.3601**
Min	**.2572**	**.2743**	**.1886**	**.2401**	**.2229**	**.1829**
Avg	**.3022**	**.3175**	**.3016**	**.2965**	**.2993**	**.2462**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274043 / SALMUKH
Feeder No / Name : 201 / 11KV KALAMWADI. SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2134	.1677	.1677	1.3717	1.1431	1.6766	.1829
2	.2134	.1677	.1829	1.448	1.2193	1.7528	.1829
3	.2134	.1829	.1829	1.5242	1.2955	1.7528	.1981
4	.2286	.1981	.1981	1.6004	1.3717	1.829	.2134
5	.2439	.2286	.2134	1.6766	1.5242	1.829	.2286
6	.2591	.2439	.2286	1.7528	1.6004	1.9052	.2439
7				1.829	2.0576	2.1338	
8				1.9052	2.2862		
9							2.21
10							2.3624
11							2.6673
12							2.5911
13							2.5149
14							2.4387
15							2.3624
16							2.2862
17	2.4387	2.5911	2.7435				
18	2.6673	2.5149	2.5911				
19	2.5911	2.5149	2.2862	.2439	.2591	.2286	.2286
20	2.4387	2.2862	1.9814	.2286	.2743	.2134	.2134
21	2.2862	2.1338	1.829	.2286	.2591	.1981	.1981
22	2.1338	1.829	1.6766	.2134	.2439	.1981	.1829
23	1.9814	1.6766	1.6004	.2134	.2286	.1829	.1677
24	1.7528	1.829	1.3717	1.5242	.1981	.2439	.1829
Max	**2.6673**	**2.5911**	**2.7435**	**1.9052**	**2.2862**	**2.1338**	**2.6673**
Min	**.2134**	**.1677**	**.1677**	**.2134**	**.1981**	**.1829**	**.1677**
Avg	**1.4044**	**1.3260**	**1.2324**	**1.1257**	**.9972**	**1.0880**	**1.0928**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274043 / SALMUKH
Feeder No / Name : 202 / 11KV TANDULWADI FEEDER. SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	.1677	.1829	.2896	.1829
2	1.3717	.1981	.1829	.3048	.1829
3	1.448	.2134	.1981	.3048	.1829
4	1.5242	.2286	.2134	.3201	.1829
5	1.6004	.2439	.2134	.3506	.2134
6	1.6766	.2591	.2286	.4268	.2286
7	1.9052				
8	1.9814				
9		1.6766	1.7528	1.2955	
10		1.7528	1.829		
11		1.829	1.6766		
12		1.9052	1.829		
13		1.9052	1.7528		
14		1.9814	1.7528		
15		1.829	1.6766		
16		1.829	1.6004		
17					2.4387
18					2.5149
19	.2439	.2286	.3048	.2439	2.21
20	.2286	.2134	.2896	.2286	1.829
21	.2134	.2134	.2896	.2134	1.7528
22	.1981	.1981	.2743	.2134	1.6766
23	.1829	.1829	.2591	.1981	1.6004
24	.1677	.1677	.1677	.2591	.1981
Max	**1.9814**	**1.9814**	**1.829**	**1.2955**	**2.5149**
Min	**.1677**	**.1677**	**.1677**	**.1981**	**.1829**
Avg	**.9972**	**.8612**	**.8337**	**.3576**	**1.0996**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274043 / SALMUKH
Feeder No / Name : 203 / SALMUKH GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4268	.4725	.5335	.5335	.5639	.4877	.4115
2	.4268	.4877	.5944	.6097	.5944	.5944	.4115
3	.442	.5792	.6859	.6097	.6401	.6554	.442
4	.4877	.6554	.7773	1.1431	.7164	.7316	.5944
5	.6706	.7773	.884	1.2193	.7468	.8383	.7926
6	.8383	.8383	.9297	1.1888	.8688	.8688	.9145
7	.6097	.7773	.7773	1.1431	.7926	.8078	.6554
8	.9145	.7316	.6249	1.1126	.7011	.7621	.7621
9	.6706	.8535	1.0517	.9602	.5182	.503	.9907
10	.7316	.9907	.9145	.8993	.442	.4877	.9145
11	.7926	.7621	.7621	.5335	.5182	.442	.823
12	.7621	.7316	.823	.5335	.6097	.3658	.8078
13	.6249	.6706	.8078	.442	.6859	.3353	.7621
14	.4725	.5792	.8688	.3353	.7926	.3201	.7773
15	.4268	.5182	.7926	.7468	.884	.3048	.7926
16	.381	.7773	.8535	.8383	.9145	.3048	.8078
17	.5487	.8993	.7316	.9297	.6859	.3658	.8535
18	.7316	1.0364	.5487	.8383	.5487	.5182	.8688
19	.7773		.945	.8383	.6554	.7621	.7468
20	.823	.7164	.7316	.7773	.7164	.6401	.7011
21	.7468	.6706	.5944	.7164	.6401	.6249	.6554
22	.6401	.5792	.5182	.6706	.5792	.5792	.5639
23	.5639	.5182	.4877	.5792	.4572	.503	.5335
24	.442	.4572	.442	.4572	.5182	.381	.4268
Max	**.9145**	**1.0364**	**1.0517**	**1.2193**	**.9145**	**.8688**	**.9907**
Min	**.381**	**.4572**	**.442**	**.3353**	**.442**	**.3048**	**.4115**
Avg	**.6230**	**.6991**	**.7367**	**.7773**	**.6579**	**.5493**	**.7087**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274043 / SALMUKH
Feeder No / Name : 204 / Shendechinch **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1524	.2134	.1677	.1524	.1372	1.6004
2	.1829	.1524	.2134	.1829	.1829	.1524	1.5242
3	.1981	.1524	.2286	.1981	.2134	.1677	1.5242
4	.2134	.1677	.2286	.1981	.2286	.1829	1.6004
5	.2286	.1829	.2439	.2134	.2439	.1981	1.6766
6	.2591	.1981	.2439	.2286	.2591	.2134	1.7528
7							1.829
8							1.9509
9	2.2862	2.1338	1.9814				
10	2.4387	2.2862	2.21				
11	2.2862	2.1338	2.1338				
12	2.21	2.21	2.0576				
13	2.1338	2.1338	1.9814				
14	1.9814	2.0576	1.9052				
15	1.9814	1.9814	1.829				
16	1.829	1.9052	1.829				
17				2.5911	2.2862		
18				2.4387	2.1338		
19	.1981	.2896	.2286	2.21	1.9814	1.9814	.2134
20	.1829	.2591	.2134	1.9814	1.829	1.9052	.1981
21	.1677	.2439	.1981	1.9052	1.6766	1.829	.1829
22	.1524	.2286	.1829	1.829	1.5242	1.7528	.1677
23	.1524	.2134	.1677	1.6766	1.3717	1.7528	.1524
24	.1829	.1524	.1981	.1524	1.6004	1.2193	1.6766
Max	**2.4387**	**2.2862**	**2.21**	**2.5911**	**2.2862**	**1.9814**	**1.9509**
Min	**.1524**	**.1524**	**.1677**	**.1524**	**.1524**	**.1372**	**.1524**
Avg	**.9724**	**.9617**	**.9244**	**1.1409**	**1.1203**	**.9577**	**1.1464**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274043 / SALMUKH
Feeder No / Name : 205 / FALAWANI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219	.1524	.1524	.1677	.1372	.1524	1.3717
2	.1219	.1677	.1524	.1829	.1372	.1677	1.2955
3	.1372	.1677	.1677	.1981	.1524	.1677	1.2955
4	.1524	.1829	.1829	.2134	.1677	.1829	1.3717
5	.1829	.1981	.1981	.2286	.1829	.1981	1.5242
6	.1981	.2134	.2134	.2439	.1981	.2134	1.5242
7							1.6766
8							1.9052
9	1.829	1.7528	1.448				
10	1.9814	1.829	1.6766				
11	2.0576	1.829	1.6004				
12	1.829	1.7528	1.5242				
13	1.6766	1.6766	1.448				
14	1.6004	1.6004	1.448				
15	1.5242	1.5242	1.448				
16	1.3717	1.6004	1.3717				
17				2.21	2.0576		
18				2.1338	1.9052		
19	.1829	.1829	.2286	1.7528	1.6766	1.7528	.2134
20	.1677	.1677	.2134	1.6766	1.5242	1.6766	.1981
21	.1524	.1372	.1981	1.6004	1.3717	1.6766	
22	.1524	.1219	.1829	1.5242	1.2955	1.6004	.1677
23	.1524	.1219	.1677	1.2955	1.2193	1.5242	.1372
24	.1219	.1524	.1372	.1524	1.1431	1.0669	1.3717
Max	**2.0576**	**1.829**	**1.6766**	**2.21**	**2.0576**	**1.7528**	**1.9052**
Min	**.1219**	**.1219**	**.1372**	**.1524**	**.1372**	**.1524**	**.1372**
Avg	**.7857**	**.7766**	**.7080**	**.9700**	**.9406**	**.8650**	**1.0810**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274043 / SALMUKH
Feeder No / Name : 207 / maloli **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5242	.2134	.1372	.1677	.1677
2		1.6766	.2286	.1524	.1829	.1524
3		1.7528	.2439	.1677	.2229	.1524
4		1.829	.2591	.2134	.2286	.1677
5		1.9052	.2743	.2439	.2591	.1981
6	2.0576	1.9814	.2743	.2591	.3048	.2286
7	2.21	2.3624				
8	2.3624	2.3624				
9			2.3624	2.2862	2.1338	
10			2.4387	2.5149		
11			2.5911	2.5149		
12			2.5149	2.5149		
13			2.4387	2.4387		
14			2.4387	2.2862		
15			2.5149	2.2862		
16			2.5911	2.2862		
17						3.0483
18						2.9721
19	.2743	.2743	.1981	.2286	.2134	2.5911
20	.2591	.2915	.1981	.2439	.2134	2.4387
21	.2286	.2439	.1829	.2134	.1981	2.2862
22	.2134	.2286	.1829	.1829	.1981	2.1338
23	.1981	.2134	.1372	.1677	.1829	1.9814
24		.1829	.1981	.1219	.1524	.1677
Max	**2.3624**	**2.3624**	**2.5911**	**2.5149**	**2.1338**	**3.0483**
Min	**.1981**	**.1829**	**.1372**	**.1219**	**.1524**	**.1524**
Avg	**.9754**	**1.2020**	**1.1241**	**1.0730**	**.3583**	**1.3347**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274046 / 33/11KV VELAPUR
Feeder No / Name : 201 / BONDLE SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0669	1.0669	1.0669	1.0669
2		1.0669	1.2193	1.1279	1.0669
3		1.2193	1.2193	1.1431	1.1431
4		1.2193	1.3717	1.2193	1.1431
5		1.2955	1.3717	1.3717	1.2193
6		1.448	1.5242	1.6766	1.3717
7		1.7528	1.829	1.829	1.5242
8		2.0576	2.0576	1.9814	1.6766
9		2.1338	2.1338	2.1338	1.829
19		.3048	.3429	.2286	.3048
20		.2286	.3429	.3048	.3048
21		.2286	.3429	.3048	.2286
22		.2286	.2572	.3048	.2286
23	.3048	.2286	.2572	.3048	.2286
24		1.0669	1.0669	1.0669	1.0669
Max	**.3048**	**2.1338**	**2.1338**	**2.1338**	**1.829**
Min	**.3048**	**.2286**	**.2572**	**.2286**	**.2286**
Avg	**.3048**	**1.0364**	**1.0936**	**1.0710**	**.9602**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274046 / 33/11KV VELAPUR
Feeder No / Name : 202 / VELAPUR GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4572	.5144	.5335	.4572
2		.4572	.5144	.6097	.4572
3		.4572	.6859	.6859	.5335
4		.6859	.7716	.7621	.6859
5		.9145	1.0288	.8383	.8383
6		1.0669	1.2003	.9907	1.0669
7		1.1431	1.286	.9145	1.2193
8		1.1431	1.2003	.7621	1.0669
9		.9145	1.0288	.7621	.9145
10		.7621	.9431	.8383	.8383
11			.8573	.7621	.7621
12			.6859	.6097	.6859
13			.6859	.6097	.6097
14			.6859		.6097
15			.7716	.6097	.6097
16			.8573	.6859	.6097
17		.7621	.9431	.7621	.7621
18		.9145	.9431	.8383	.9145
19		1.0669	1.286	.9907	1.0669
20		.8383	1.1145	.9907	.9145
21			.9431	.9145	.7621
22			.8573	.7621	.6097
23	.6097	.6097	.7716	.6859	.6097
24		.4572	.6859	.4572	.4572
Max	**.6097**	**1.1431**	**1.286**	**.9907**	**1.2193**
Min	**.6097**	**.4572**	**.5144**	**.4572**	**.4572**
Avg	**.6097**	**.7907**	**.8859**	**.7555**	**.7526**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274046 / 33/11KV VELAPUR
Feeder No / Name : 203 / 11 KV NEVARE SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0762	.0857	.0762	.0762
2			.0762	.0857	.0762	.0762
3			.0762	.0857	.0762	.0762
4			.0762	.0857	.0762	.0762
5			.0762	.1715	.0762	.0762
6			.0762	.1715	.1524	.0762
11			2.1338	1.9052	2.1338	2.4387
12			2.21	2.2862		2.2862
13			2.2862	2.3624		2.2862
14			2.2862	2.1338		2.4387
15			1.829	2.4387		2.4387
16			2.1338	2.2862		2.2862
17			2.21	2.0576		2.1338
18			2.1338	2.1338		1.9814
19			.1524	.1715	.0762	.1524
20	.1715		.1524	.1715		.1524
21	.1715		.0762	.1715	.0762	.0762
22	.1715		.0762	.1715	.0762	.0762
23	.1715	.0762	.0762	.0857	.0762	.0762
24			.0762	.0857	.0762	.0762
Max	**.1715**	**.0762**	**2.2862**	**2.4387**	**2.1338**	**2.4387**
Min	**.1715**	**.0762**	**.0762**	**.0857**	**.0762**	**.0762**
Avg	**.1715**	**.0762**	**.9145**	**.9574**	**.2540**	**.9678**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274046 / 33/11KV VELAPUR
Feeder No / Name : 204 / 11KV NIMGAON SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.2193	1.3717	1.0669	.9907
2			1.3717	1.5242	1.2193	.9907
3			1.448	1.6766	1.5242	1.1431
4			1.5242	1.829	1.6766	1.2955
5			1.6766	1.829	1.829	1.448
6			1.9814	1.9814	2.2862	1.829
7			2.2862	2.4387	2.2862	2.4387
8			2.21	2.5911	2.3624	2.4387
9			2.1338	2.5149	2.7435	2.4387
11			.6859			
12			.6859			
13			.6859			
14			.6859			
15			.6859			
16			.6859			
19			.1524	.1715	.1524	.1524
20	.1715		.0762	.1715	.1524	.1524
21	.1715			.0857	.1524	.0762
22	.1715			.0857	.0762	.0762
23	.0857	.1524	.0762	.0857	.0762	.0762
24			1.2193	1.3717	.9907	.9907
Max	**.1715**	**.1524**	**2.2862**	**2.5911**	**2.7435**	**2.4387**
Min	**.0857**	**.1524**	**.0762**	**.0857**	**.0762**	**.0762**
Avg	**.1501**	**.1524**	**1.1311**	**1.3152**	**1.2396**	**1.1025**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274046 / 33/11KV VELAPUR
Feeder No / Name : 205 / TANDULWADI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7621	.9907	.9907	.9907
2		.7621	1.0669	.9907	1.0669
3		.9145	1.0669	.9907	1.0669
4		1.0669	1.2193	1.0669	1.1431
5			1.2193	1.0669	1.2955
6		1.2193	1.3717	1.3717	1.3717
7		1.6766	1.6766	1.7528	1.6004
8		1.9814	2.0576	1.829	1.9052
9		1.9814	1.9814	1.829	1.9814
18			.1715		
19		.1524	.1715	.1524	.1524
20		.1524	.1715	.1524	.1524
21		.1524	.1715	.1524	.0762
22		.5487	.1715	.0762	.0762
23	.1524	.0762	.0857	.0762	.0762
24		.7621	.9907	.9145	.9907
Max	**.1524**	**1.9814**	**2.0576**	**1.829**	**1.9814**
Min	**.1524**	**.0762**	**.0857**	**.0762**	**.0762**
Avg	**.1524**	**.8720**	**.9115**	**.8942**	**.9297**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274046 / 33/11KV VELAPUR
Feeder No / Name : 206 / BHAKAREWADI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1524	.0857	.0762	.0762
2		.1524	.0857	.0762	.0762
3		.1524	.0857	.0762	.0762
4		.1524	.0857	.0762	.1524
5		.1524	.1715	.0762	.1524
6		.1524	.1715	.0762	.1524
11		1.829	1.6766	1.6766	1.3717
12		1.9814	1.7528		1.829
13		1.9814	1.7528		1.829
14		1.9814	1.6766		1.829
15		1.7528	1.6766		1.7528
16		1.6766	1.6766		1.6766
17		1.6766	1.6004		1.6766
18		1.5242	1.5242		1.5242
19		.1524	.1715	.1524	.1524
20		.1524	.1715	.1524	.1524
21		.1524	.1715	.1524	.1524
22		.0762	.1715	.0762	.0762
23	.1524	.0762	.0857	.0762	.0762
24		.1524	.0857	.0762	.0762
Max	**.1524**	**1.9814**	**1.7528**	**1.6766**	**1.829**
Min	**.1524**	**.0762**	**.0857**	**.0762**	**.0762**
Avg	**.1524**	**.8040**	**.7440**	**.2169**	**.7430**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274046 / 33/11KV VELAPUR
Feeder No / Name : 207 / UGHDEWADI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0762	.0857	.0762	.0762
2		.0762	.0857	.0762	.0762
3		.0762	.0857	.0762	.0762
4		.0762	.0857	.0762	.0762
5		.0762	.1715	.0762	.0762
6		.0762	.1715	.1524	.0762
11		.9907	1.0669	1.0669	1.2955
12		1.2193	1.2193		1.2955
13		1.3717	1.0669		1.2955
14		1.3717	1.2193		1.0669
15		1.3717	1.2193		1.0669
16		1.0669	.9907		1.2193
17		1.1431	1.0669		1.2193
18		.9145	.9145		1.2193
19		.1524	.1715	.0762	.1524
20		.0762	.1715	.0762	.0762
21		.0762	.0857	.0762	.0762
22		.0762	.0857	.0762	.0762
23	.0762	.0762	.0857	.0762	.0762
24		.0762	.0857	.0762	.0762
Max	**.0762**	**1.3717**	**1.2193**	**1.0669**	**1.2955**
Min	**.0762**	**.0762**	**.0857**	**.0762**	**.0762**
Avg	**.0762**	**.5220**	**.5068**	**.1583**	**.5334**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274046 / 33/11KV VELAPUR
Feeder No / Name : 208 / NAGTHANA SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1524	.0857	.0762	
2		.1524	.0857	.0762	.1524
3		.1524	.0857	.0762	.1524
4		.1524	.0857	.0762	.1524
5		.1524	.1715	.0762	.1524
6		.1524	.1715	.0762	.1524
11		1.9814	1.829	1.829	2.21
12		1.829	1.829		2.1338
13		1.829	1.6766		2.2862
14		1.829	1.6766		2.21
15		1.6766	1.829		2.1338
16		1.6766	1.9052		1.9814
17		1.6766	1.9814		1.829
18		1.6766	1.829		1.829
19		.1524	.1715	.1524	.1524
20		.1524	.1715	.1524	.1524
21		.1524	.1715	.1524	.1524
22		.0762	.0857	.1524	.0762
23	.1524	.0762	.0857	.1524	.0762
24		.1524	.0857	.0762	.1524
Max	**.1524**	**1.9814**	**1.9814**	**1.829**	**2.2862**
Min	**.1524**	**.0762**	**.0857**	**.0762**	**.0762**
Avg	**.1524**	**.7926**	**.8007**	**.2403**	**.9546**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274088 / SHRIPUR
Feeder No / Name : 201 / SHRIPUR GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3506	.2572	.2572	.3506
2	.3506	.3429	.3429	.3506
3	.3506	.4287	.4287	.3506
4	.4382	.4287	.4287	.5258
5	.4382	.4287	.4287	.5258
6	.4382	.5144	.5144	
7	.5258	.4287	.5144	
8	.5258	.4287	.4287	
9	.3506	.2572	.4287	
10	.362	.2715	.362	
11	.2715	.2715	.2715	.2572
12	.2715	.2715	.2715	.2572
13	.2743	.2715	.2743	.2572
14	.2715	.181	.181	.1715
15	.2715	.4525	.181	.1715
16	.2715	.181	.2715	.1715
17	.2572	.1715	.2629	.2572
18	.4287	.2572	.3506	.2572
19	.5144	.5144	.7011	.3429
20	.5144	.4287	.7011	.3429
21	.5144	.3429	.5258	.3429
22	.3429	.2572	.3506	.3429
23	.2572	.2572	.3506	.3429
24	.3506	.2572	.2572	.3506
Max	**.5258**	**.5144**	**.7011**	**.5258**
Min	**.2572**	**.1715**	**.181**	**.1715**
Avg	**.3726**	**.3293**	**.3785**	**.3142**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274088 / SHRIPUR
Feeder No / Name : 202 / MAHALUNG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1469	1.0669	1.0669	.0876
2	1.1469	1.0669	1.0669	.0876
3	1.1469	1.0669	1.0669	.0876
4	1.1469	1.0669	1.0669	.0876
5	1.2289	1.1431	1.1431	.0876
6	1.3108	1.2193	1.2193	.0876
7	1.6385	1.6766	1.6766	
8	1.8023	1.6766	1.6766	
9	1.8842	1.6766	1.829	
11				1.9814
12				1.9814
13				1.9814
14				1.9814
15				1.9814
16				1.9814
17				1.829
18				1.829
19	.0857	.0857	.0876	.0857
20	.0857	.0857	.0876	.0857
21	.0857	.0857	.0876	.0857
22	.0857	.0857	.0876	.0857
23	.0857	.0857	.0876	
24	1.1469	1.0669	1.0669	.0876
Max	**1.8842**	**1.6766**	**1.829**	**1.9814**
Min	**.0857**	**.0857**	**.0876**	**.0857**
Avg	**.9352**	**.8770**	**.8878**	**.8685**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274088 / SHRIPUR
Feeder No / Name : 203 / UMBARE **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0876	.0857	.0857	.4915
2	.0876	.0857	.0857	.4915
3	.0876	.0857	.0857	.4915
4	.0876	.0857	.0857	.4915
5	.0876	.0857	.0857	.4915
6	.0876	.0857	.0857	.5735
7				.8192
8				.9831
9				1.065
11	.9602	.9602	.8802	
12	.9602	1.0279		
13	1.2003	1.1203		
14	1.1203	1.1203		
15	1.1203	1.0279		
16	1.1203	1.0402		
17	1.0669	.8383		
18	.9907	.9145		
19	.0857	.0857	.0876	.0857
20	.0857	.0857	.0876	.0857
21	.0857	.0857	.0876	.0857
22	.0857	.0857	.0876	.0857
23	.0857	.0857	.0876	
24	.0876	.0857	.0857	.4915
Max	**1.2003**	**1.1203**	**.8802**	**1.065**
Min	**.0857**	**.0857**	**.0857**	**.0857**
Avg	**.4790**	**.4539**	**.1475**	**.4809**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274088 / SHRIPUR
Feeder No / Name : 204 / CHAUKI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9831	1.0669	1.0669	.0876
2	.9831	1.0669	1.0669	.0876
3	.9831	1.0669	1.0669	.0876
4	.9831	1.0669	1.0669	.1753
5	1.1469	1.0669	1.0669	.1753
6	1.2289	1.1431	1.0669	.1753
7	1.3927	1.448	1.5242	
8	1.5565	1.5242	1.6004	
9	1.6385		1.6766	
11				1.7528
12				1.7528
13				1.6004
14				1.7528
15				1.7528
16				1.7528
17				1.5242
18				1.2955
19	.1372	.1372	.0876	.0857
20	.1372	.1372	.0876	.0857
21	.1372	.1372	.0876	.0857
22	.12	.1372	.0876	.0857
23	.1029	.1029	.0876	
24	.9831	1.0669	1.0669	.0876
Max	**1.6385**	**1.5242**	**1.6766**	**1.7528**
Min	**.1029**	**.1029**	**.0876**	**.0857**
Avg	**.8342**	**.7977**	**.8472**	**.7581**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274088 / SHRIPUR
Feeder No / Name : 205 / MALEWADI AG/SDT SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0876	.0857	.0857	1.2289
2	.0876	.0857	.0857	1.2289
3	.0876	.1372	.1029	1.2289
4	.1753	.1372	.1372	1.2289
5	.1753	.1715	.1715	1.3108
6	.1753	.1715	.1715	1.4746
7				1.6385
8				2.0481
9				2.2119
11	1.8404	1.7604	1.6804	
12	1.8404			
13	1.8185	1.5813		
14	1.7604	1.6004		
15	1.7604	1.5813		
16	1.8404	1.6604		
17	1.7528	1.5242		
18	1.6766	1.6004		
19	.0857	.12	.0876	.0857
20	.1372	.1372	.1753	.0857
21	.1372	.1372	.1753	.0857
22	.12	.1372	.0876	.0857
23	.0857	.1029	.0876	
24	.0876	.0857	.0857	1.2289
Max	**1.8404**	**1.7604**	**1.6804**	**2.2119**
Min	**.0857**	**.0857**	**.0857**	**.0857**
Avg	**.7866**	**.6746**	**.2411**	**1.0837**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274088 / SHRIPUR
Feeder No / Name : 206 / Borgaon Gaothan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7888	.6859	.6859	.7011
2	.8764	1.1145	1.1145	.8764
3	1.2269	1.286	1.286	1.1393
4	1.4022	1.4575	1.4575	1.4022
5	1.7528	1.4575	1.5432	1.5775
6	1.6651	1.6289	1.5432	1.5775
7	1.4899	1.4575	1.286	1.4899
8	1.3146	1.286	1.2003	1.4022
9	1.1393	1.0288	1.1145	1.1393
10	.924	.823	.9145	.8573
11	.823	.7392		.6859
12	.7392	.6468	.6401	.6001
13	.6401	.5544	.5544	.5144
14	.5544	.5487	.5544	.5144
15	.5487	.4572	.4572	.5144
16	.5487	.5487	.5544	.5144
17	.6859	.6001	.7011	.8573
18	.9431	.7716	.8764	.9431
19	1.2003	1.2003	1.2269	1.0288
20	1.286		1.1393	1.2003
21	1.0288	1.1145	.964	1.2003
22	.8573	.9431	.8764	1.3717
23	.7716	.7716	.7011	1.3717
24	.7888	.6859	.6859	.7011
Max	**1.7528**	**1.6289**	**1.5432**	**1.5775**
Min	**.5487**	**.4572**	**.4572**	**.5144**
Avg	**.9998**	**.9482**	**.9599**	**1.0075**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274088 / SHRIPUR
Feeder No / Name : 207 / Mundafane Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6554	.6097	.6097	
2	.6554	.6097	.6097	
3	.6554	.6097	.6097	
4	.6554	.6097	.6097	
5	.6554	.6859	.6097	
6	.6554		.6097	
7	.8192	.8383	.7621	
8	.8192	.8383	.7621	
9	.9012	.8383	.7621	
11				.9145
12				.8383
13				.9145
14				.9145
15				.9145
16				.9145
17				.8383
18				.8383
24	.6554	.6097	.6097	
Max	**.9012**	**.8383**	**.7621**	**.9145**
Min	**.6554**	**.6097**	**.6097**	**.8383**
Avg	**.7127**	**.6944**	**.6554**	**.8859**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274102 / KHALAVE
Feeder No / Name : 201 / 11 KV TAMKHEDA AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7926	.7164	.7926	.0667
2	.7926	.7468	.823	.0667
3	.8078	.7926	.7926	.08
4	.7926	.8383	.8993	.0934
5	.8078	.8993	.945	.12
6	.8078	.9602	.9602	.1334
7	.945	1.1736	1.1279	.1467
8	1.1126	1.2651	1.0974	.1467
9	1.1431	1.2346	1.1431	.16
10	.1524	.1067	.0934	.1677
11	.1219	.1067	.08	1.1736
12	.1067	.1067		1.2955
13	.1067	.0914		1.3565
14	.1219	.0914		1.3717
15	.1219	.0914		1.2193
16	.1067	.0914		1.3413
17	.1219	.0914		1.326
18	.1677	.1219		1.2193
19	.1524	.1219	.1334	.1524
20	.1372		.12	.1219
21	.1372	.1067	.1067	.1219
22	.1219	.1067	.0934	.1067
23	.1067	.1067	.08	.1067
24	.7926	.6859	.7621	.08
Max	**1.1431**	**1.2651**	**1.1431**	**1.3717**
Min	**.1067**	**.0914**	**.08**	**.0667**
Avg	**.4407**	**.4632**	**.5912**	**.5073**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274102 / KHALAVE
Feeder No / Name : 202 / 11 KV TONDLE AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5699	1.6156	1.4937	.16
2	1.6309	1.7071	1.5242	.1467
3	1.7071	1.829	1.6461	.1734
4	1.829	1.9052	1.7071	.2
5	1.8595	1.9814	1.7985	.2267
6	1.9509	2.0729	1.829	.2667
7	2.2558	2.1491	2.0424	.2934
8	2.5453	2.4387	2.271	.3067
9	2.4844	2.4691	2.2862	.2534
10	.2286	.2286	.2286	.2134
11	.1524	.1524	.1829	2.2862
12	.1372	.1524		2.4387
13	.1677	.1677		2.4539
14	.1829	.1677		2.5149
15	.1677	.1372		2.4844
16	.1677	.1677		2.3624
17	.2134	.1829		2.5453
18	.2896	.2439		2.5453
19	.3048	.2591	.2534	.2743
20	.2286	.2591	.2534	.2439
21	.2134	.2286	.2	.2134
22	.2134	.1981	.1734	.2134
23	.1829	.1829	.1829	.1829
24	1.5699	1.5394	1.3717	.16
Max	**2.5453**	**2.4691**	**2.2862**	**2.5453**
Min	**.1372**	**.1372**	**.1734**	**.1467**
Avg	**.9272**	**.9348**	**1.1438**	**.9650**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274102 / KHALAVE
Feeder No / Name : 203 / 11 KV KHALAVE AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0152	.0152	.0152	.0267
2	.0152	.0152	.0152	.0267
3	.0152	.0152	.0152	.04
4	.0152	.0152	.0152	.04
5	.0152	.0152	.0152	.0533
6	.0152	.0152	.0152	.0533
7	.0152	.0152	.0152	.0667
8	.0152	.0152	.0152	.0667
9	.0152	.0152	.0152	.08
10	.0152	.0152	.0133	.0152
11	.0762	.0457	.0533	.0152
12	.0914	.0762		.0152
13	.1067	.0762		.0152
14	.1067	.0762		.0152
15	.1067	.0762		.0152
16	.0914	.0762		.0152
17	.0914	.061		.0152
18	.0914	.061		.0152
19	.0152	.0152	.0133	.0152
20	.0152	.0152	.0133	.0152
21	.0152	.0152	.0133	.0152
22	.0152	.0152	.0133	.0152
23	.0152	.0152	.0133	.0152
24	.0152	.0152	.0152	.0267
Max	**.1067**	**.0762**	**.0533**	**.08**
Min	**.0152**	**.0152**	**.0133**	**.0152**
Avg	**.0419**	**.0330**	**.0168**	**.0289**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274102 / KHALAVE
Feeder No / Name : 204 / 11 KV SHERI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1067	.0914	.1524	1.4003
2	.1067	.0914	.1219	1.4003
3	.1067	.0914	.1219	1.467
4	.1219	.1067	.1219	1.5337
5	.1219	.1219	.1524	1.6537
6	.1524	.1524	.1524	1.7337
7	.1829		.1829	2.1338
8	.1677	.1829	.1524	2.2672
9	.1219	.1524	.1219	2.3339
10	.1524	.1524	.1067	.1372
11	2.3472	2.4387	2.1338	.1219
12	2.5606	2.6216		.1067
13	2.5911	2.652		.1219
14	2.652	2.5606		.1219
15	2.5911	2.5911		.1067
16	2.4996	2.3472		.1067
17	2.4691	2.4387		.0914
18	2.4996	2.4387		.1372
19	.1524	.1219	.1334	.1829
20	.1219	.1219	.1334	.1524
21	.1219	.1219	.1067	.1219
22	.1219	.1219	.1067	.1219
23	.0914	.0914	.0914	.1067
24	.1067	.0914	.1524	1.307
Max	**2.652**	**2.652**	**2.1338**	**2.3339**
Min	**.0914**	**.0914**	**.0914**	**.0914**
Avg	**.9278**	**.9523**	**.2497**	**.7903**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274102 / KHALAVE
Feeder No / Name : 205 / 11 KV BONDALE GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.1829	.2439	.1334
2	.2591	.1677	.2439	.1334
3	.2591	.1524	.2743	.12
4	.2896	.2134	.3048	.16
5	.3048	.2439	.3353	.2
6	.3201	.2743	.3658	.2401
7	.3353	.3201	.3506	.3334
8	.2591	.3048	.2743	.2401
9	.3048	.2743	.2286	.2
10	.2743	.2134	.2667	.2896
11	.3506	.1829	.2934	.3353
12	.2591	.2134		.3048
13	.2286	.1829		.2743
14	.1677	.1372		.2134
15	.1524	.1372		.1219
16	.1524	.1372		.1372
17	.2286	.1981		.2286
18	.2286	.2134		.2591
19	.3658	.3201	.381	.3353
20	.2591	.3201	.3734	.3048
21	.2896	.2439	.381	.2591
22	.2743	.2134	.381	.2591
23	.1981	.2134	.1981	.2134
24	.2286	.1981	.2286	.16
Max	**.3658**	**.3201**	**.381**	**.3353**
Min	**.1524**	**.1372**	**.1981**	**.12**
Avg	**.2591**	**.2191**	**.3015**	**.2273**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274127 / UMBARE(VELAPUR)
Feeder No / Name : 203 / MIRE SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	16-DEC-17	17-DEC-17	18-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.9907	
2		1.0669	
3		1.0669	
4		1.1888	
5		1.2955	
6		1.3717	
7		1.448	
8		1.5242	
9			1.2955
10			.0762
11			.0914
12			.1067
13			.0914
14			.0914
15			.0762
16	1.5851		.0914
17	1.5546		
18	1.5242		
19	.061		
20	.0762		
21	.0762		
22	.0762		
23	.061		
24		.9907	
Max	**1.5851**	**1.5242**	**1.2955**
Min	**.061**	**.9907**	**.0762**
Avg	**.6268**	**1.2159**	**.2400**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274127 / UMBARE(VELAPUR)
Feeder No / Name : 204 / 11KV ANUSEWASTI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	16-DEC-17	17-DEC-17	18-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1		1.0753	
2		1.186	
3		1.2967	
4		1.3916	
5		1.5023	
6		1.5813	
7		1.7078	
8		1.8027	
9			1.8976
10			.0633
11			.0633
12			.0949
13			.0791
14			.0791
15			.0949
16	1.9608		.0949
17	1.8976		
18	1.8976		
19	.0791		
20	.0791		
21	.0949		
22	.0949		
23	.0949		
24		.9488	
Max	**1.9608**	**1.8027**	**1.8976**
Min	**.0791**	**.9488**	**.0633**
Avg	**.7749**	**1.3881**	**.3084**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274127 / UMBARE(VELAPUR)
Feeder No / Name : 205 / 11KV THITEWASTI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17
HR	Load (MW)
11	1.3592
12	1.3748
13	1.3748
14	1.3748
15	1.406
16	1.406
Max	**1.406**
Min	**1.3592**
Avg	**1.3826**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274153 / Vitthalwadi
Feeder No / Name : 201 / MALKHAMBI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0762	.0667	.0857	.9145
2		.0762	.0762	.0857	1.0288
3		.0857	.0762	.0857	.9907
4		.0762	.0762	.0857	.9907
5		.1524	.0762	.0857	1.0669
6		.1524	.1524	.12	1.0669
7		.1524	.1524	.1715	1.1431
8		.1524	.1524	.0857	1.448
9		.0762	.1524	.0857	.5335
10		.1524	.1372	.0857	.1543
11		1.4575	1.448	1.2955	.0857
12		1.5432	1.5394		.0857
13		1.3717	1.5003		.0857
14		1.5432	1.6004		.0857
15		1.5432	1.4289		.0857
16			1.448		.0857
17		1.448	1.6289		.0857
18		1.4575	1.3717		.0857
19		.1715	.1524	.0857	.0857
20		.1524	.3086	.0857	.0857
21	.1524	.0762	.1715	.0857	.0857
22	.1334	.0762	.0857	.0857	.0857
23	.1524	.0762	.0857	.0857	.0857
24		.1524	.0762	.0857	.9145
Max	**.1524**	**1.5432**	**1.6289**	**1.2955**	**1.448**
Min	**.1334**	**.0762**	**.0667**	**.0857**	**.0857**
Avg	**.1461**	**.5314**	**.5818**	**.1639**	**.4736**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274153 / Vitthalwadi
Feeder No / Name : 202 / GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0762	.0762	.0857	.0857
2			.0762	.0762	.0857	.0857
3			.0762	.0762	.0857	.1372
4			.0762	.0762	.12	.1715
5			.1524	.1524	.1715	.2058
6			.1981	.1829	.2229	.2401
7			.1981	.1981	.2229	.2058
8			.1524	.1524	.1715	.2058
9			.1524	.1524	.0857	.1372
10			.0762	.0686	.0857	.1029
11			.0762	.0857	.0857	.1029
12			.0762	.0857		.0857
13			.0762	.0514		.0857
14			.0762	.0514		.0857
15			.0762	.0514		.0857
16				.0514		.1372
17			.0762	.0857		.0857
18			.1524	.1029		
19			.1524	.2058	.2058	.0857
20			.1524	.2058	.1715	.0857
21	.0857	.1334	.0762	.1715	.1372	.0857
22		.0762	.0762	.12		.0857
23		.0762	.0762	.0857	.0857	.0857
24			.0762	.0762	.0857	.0857
Max	**.0857**	**.1334**	**.1981**	**.2058**	**.2229**	**.2401**
Min	**.0857**	**.0762**	**.0762**	**.0514**	**.0857**	**.0857**
Avg	**.0857**	**.0953**	**.1067**	**.1101**	**.1318**	**.1200**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274153 / Vitthalwadi
Feeder No / Name : 203 / MALEWADI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.448	1.448	1.3717	.5144
2		1.6289	1.448	1.3717	.5144
3		1.6289	1.7147	1.3717	.6001
4		1.6289	1.7147	1.4289	.6001
5		1.7147	1.5242	1.5242	.6859
6		1.8004	1.8004	1.6766	.6859
7		2.2291	2.2291	1.829	.6001
8		2.572	2.3148	1.9052	.6001
9		2.4006	2.3148	2.1338	.5144
10		.381	.3429	.4287	
11		.3048	.3429	.3429	1.6766
12		.3048	.3258		1.829
13		.3048	.3086		2.0576
14		.3048	.3086		1.9814
15		.3048	.2915		2.1338
16			.2915		2.0576
17		.381	.3429		2.21
18		.4668	.4287		
19		.4668	.5144	.7716	.6687
20		.4668	.5144	.6859	.6859
21	.5335	.5335	.5144	.6001	.6859
22	.4572	.4572	.5144	.5144	
23	.4572	.4572	.4287	.5144	.6516
24		1.6289	1.448	1.5432	.5144
Max	**.5335**	**2.572**	**2.3148**	**2.1338**	**2.21**
Min	**.4572**	**.3048**	**.2915**	**.3429**	**.5144**
Avg	**.4826**	**1.0354**	**.9761**	**1.1773**	**1.0699**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274153 / Vitthalwadi
Feeder No / Name : 204 / KAWADE FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2193	1.3717	1.1431	.0857
2		1.286	1.4575	1.1431	.0857
3		1.286	1.3717	1.1431	.0857
4		1.3717	1.5432	1.2193	.0857
5		1.4575	1.6289	1.2193	.0857
6		1.5432	1.5242	1.2955	.0857
7		1.8861	1.6766	1.5242	.0857
8		1.8861	1.9719	1.6766	.0857
9		1.8861	1.9719	1.7528	.0857
10		.0667	.0857	.0857	.0857
11		.0667	.0857	.0857	1.5242
12		.0667	.0857		1.6004
13		.0667	.0857		1.6004
14		.0667	.0857		1.6766
15		.0667	.0857		1.9719
16			.0857		1.7985
17		.0667	.0857		1.8595
18		.0667	.12		
19		.0667	.12	.0857	.0857
20		.0667	.12	.0857	.0857
21	.0762	.0762	.12	.0857	.0857
22	.0762	.0762	.0857	.0857	.0857
23	.0667	.0762	.0857	.0857	.0857
24		1.3717	1.2193	1.1431	.0857
Max	**.0762**	**1.8861**	**1.9719**	**1.7528**	**1.9719**
Min	**.0667**	**.0667**	**.0857**	**.0857**	**.0857**
Avg	**.0730**	**.6995**	**.7114**	**.8153**	**.5827**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274153 / Vitthalwadi
Feeder No / Name : 205 / VITTHALWADI AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4572	.3048	.3429	
2		.4572	.3429	.3429	
3		.4572	.3048	.3429	
4		.4572	.3048	.3429	
5		.5335	.3048	.5144	
6		.6097	.381	.5144	
7		.6097	.381	.5144	1.6004
8		.6097	.5335	.5144	1.6766
9		.6001	.6001	.6001	1.829
10		.3334	.5144	.5144	.1372
11		2.0576	1.6766	1.5242	.1715
12		2.0576	1.829		.1715
13		1.7147	2.1434		.1715
14		1.5432	1.9052		.2572
15		1.3717	1.829		
16			1.829		
17		1.267	1.7147		.3258
18		1.7147	1.7528		
19		.3048	.3429	.4287	.5144
20		.2667	.4287	.4287	.5144
21	.4572	.3048	.4287	.4287	.5144
22	.5335	.3048	.4287	.4287	.5487
23	.5335	.3048	.3429	.4287	.5487
24		.5335	.3048	.3429	
Max	**.5335**	**2.0576**	**2.1434**	**1.5242**	**1.829**
Min	**.4572**	**.2667**	**.3048**	**.3429**	**.1372**
Avg	**.5081**	**.8205**	**.8720**	**.5032**	**.6415**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274160 / Kolegaon
Feeder No / Name : 201 / KOLEGAON GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1791	.1433	.1698	.1658
2		.1791	.1612	.1698	.1492
3		.1991	.1791	.1698	.1492
4		.2172	.2328	.2218	.1989
5		.2865	.2715	.2896	.2321
6		.3224	.362	.362	.2984
7		.3582	.3439	.3801	.3647
8		.3077	.2353	.2321	.2486
9		.2715	.2033	.1989	.2429
10		.2507	.2402	.1823	.1619
11		.181	.1509	.1823	.1619
12		.1448	.1307	.1326	.1134
13		.1086	.132	.0995	.1296
14		.0905	.132	.0995	.1296
15		.1086	.1132	.0995	.0972
16	.1086	.1267	.1132	.116	.0972
17	.1448	.1629	.132	.1326	.1457
18	.2353	.2353	.2195	.1658	.2105
19	.3224	.2686	.3077	.3149	.2915
20	.3224	.2865	.3258	.2984	.3077
21	.5517	.2328	.2378	.2321	
22	.5201	.2172	.1886	.1989	.1781
23	.4161	.1629	.1698	.1658	.1619
24		.1791	.1433	.1698	.1658
Max	**.5517**	**.3582**	**.362**	**.3801**	**.3647**
Min	**.1086**	**.0905**	**.1132**	**.0995**	**.0972**
Avg	**.3277**	**.2115**	**.2029**	**.1993**	**.1914**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274160 / Kolegaon
Feeder No / Name : 202 / Kolegaon Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5261	1.3203	1.1437	.1658
2		1.56	1.3546	1.1271	.1658
3		1.56	1.4074	1.21	.1658
4		1.8652	1.5939	1.2431	.1658
5		2.0805	1.7511	1.278	
6		2.1672	1.9591	1.2631	
7		2.452	2.5206	2.1348	
8		2.6791	2.8317	1.8823	
9		2.5206	2.1032	1.8099	
10		.1612	.1829	.1658	
11	.1326	.1433	.1294	.1492	
12	.1326	.1086	.1294		1.9757
13	.1326	.1086	.1294		2.0243
14	.116	.1267	.1294		2.251
15	.116	.1267	.1478		2.4291
16	.1492	.1448	.1478		2.5911
17	.1989	.1448			2.4291
18	.2652	.2686	.2195		2.4291
19	.2486	.3224	.3258	.2486	.2591
20	.2321	.3077	.3439	.2321	.2753
21	.1989	.2534	.2195	.2321	.2105
22	.1989	.2172	.1829	.1989	.2105
23	.1989	.1991	.1663	.1658	.1943
24		1.5089	1.3032	1.1768	.1658
Max	**.2652**	**2.6791**	**2.8317**	**2.1348**	**2.5911**
Min	**.116**	**.1086**	**.1294**	**.1492**	**.1658**
Avg	**.1785**	**.9397**	**.8956**	**.9213**	**1.0652**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274160 / Kolegaon
Feeder No / Name : 203 / Phalawni Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2686	.2896	.2195	1.0136
2		.2686	.3077	.2195	1.0425
3		.2865	.3045	.2378	1.086
4		.2865	.3189	.2715	1.1584
5		.3403	.3721	.3077	1.3032
6		.394	.4887	.4163	1.7375
7		.4656	.4706	.4656	2.0851
8		.3439	.3801	.2984	2.2443
9		.3077	.2534	.2486	2.2996
10		.2353	.2172	.1989	.1619
11		1.9765	1.9204	1.6651	.1457
12		2.332	2.1348		.1457
13		2.3148	2.2613		.1457
14		2.4006	2.1822		.1457
15		2.2805	2.0557		.1457
16		1.9071	2.0005		.1457
17		2.0285	1.8244		.1619
18		1.7684	1.6194		.2429
19	.3647	.3224	.3801	.3647	.2915
20	.3647	.3403	.362	.3315	.3239
21	.3315	.3224	.3258	.2984	.3563
22	.2984	.2865	.3077	.2818	.2915
23	.2652	.3077	.2896	.2818	
24		.2686	.2896	.2378	1.0136
Max	**.3647**	**2.4006**	**2.2613**	**1.6651**	**2.2996**
Min	**.2652**	**.2353**	**.2172**	**.1989**	**.1457**
Avg	**.3249**	**.9189**	**.8898**	**.3732**	**.7690**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274175 / KHUDUS
Feeder No / Name : 201 / DOMBALWADI **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3018	.3018	.2347	.2683	.8802
2		.3018	.3018	.2347	.2683	.8802
3		.3353	.3018	.2683	.3018	1.0562
4		.3353	.3353	.2683	.3018	1.0562
5		.3688	.3353	.3018	.3353	1.1523
6		.3688	.3353	.3018	.3353	1.2003
7						1.9204
8						1.9685
9						2.0165
11	1.5581	1.7124	1.3592	1.442	1.9044	
12	1.757	1.7124	1.5912	1.7404		
13	1.7901	1.8564	1.5912	1.7404		
14	1.7695		1.6244			
15	1.7695	1.7764	1.6907	1.5249		
16	1.704	1.6804	1.4255	1.6741		
17	1.6907	1.7284	1.2266	1.6244		
18	1.5912	1.6004	1.326	1.4918		.2347
19	.2347	.2683	.2683	.3353	.3018	.285
20	.2347	.2683	.2347	.3353	.3185	.285
21	.2347	.3018	.2347	.3353	.3185	.2515
22	.2347	.3018	.2347	.3353	.3185	.2515
23	.2347	.3018	.2347	.3018	.3185	.2515
24		.2012	.3018	.2347	.2515	.8802
Max	**1.7901**	**1.8564**	**1.6907**	**1.7404**	**1.9044**	**2.0165**
Min	**.2347**	**.2012**	**.2347**	**.2347**	**.2515**	**.2347**
Avg	**1.1387**	**.8275**	**.7628**	**.7750**	**.4263**	**.9106**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274175 / KHUDUS
Feeder No / Name : 202 / AMBEMALA **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.285	1.094	1.0442	1.2763	.3353
2		.285	1.094	1.0442	1.2763	.3353
3		.3018	1.094	1.0608	1.3426	.3018
4		.3018	1.1603	1.1271	1.3426	.3018
5		.3521	1.4089	1.1934	1.4089	.3018
6		.3688	1.4089	1.2929	1.5083	.3018
7		1.3443	1.5415	1.5249	1.5415	
8		1.7284	1.8679	1.757	1.6907	
9	1.8842	1.9845	2.0645	1.757	1.6804	
10		.1677				
11	.0678	.1174	.0678		.0168	1.7604
12	.0678	.1174	.0848		.0335	1.8244
13	.0678	.0671	.0678		.0335	1.8244
14	.0678	.0671	.0678		.0335	1.7604
15	.0678	.0503	.0509	.0678	.0503	1.6644
16	.0509	.0503	.0678	.0678	.0503	1.7124
17			.0509	.0678	.0503	1.4883
18	.2012	.2347	.218	.2515	.0671	1.5043
19	.3018	.3353	.3856	.4191	.3018	.2683
20	.3018	.3353	.3521	.4191	.3353	.3018
21	.3018	.3521	.3521		.3353	.285
22	.3185	.3521	.3353	.4191	.3353	.285
23	.3185	.3521	.3353	.4024	.3353	.285
24		.2515	1.094	1.0442	1.1437	.3353
Max	**1.8842**	**1.9845**	**2.0645**	**1.757**	**1.6907**	**1.8244**
Min	**.0509**	**.0503**	**.0509**	**.0678**	**.0168**	**.2683**
Avg	**.3091**	**.4262**	**.7071**	**.8311**	**.7039**	**.8589**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274175 / KHUDUS
Feeder No / Name : 203 / KHUDUS FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2515	.3353	.285	.2683	.9762
2		.2515	.3353	.285	.3018	1.1203
3		.2683	.3688	.3018	.3018	1.1203
4		.2683	.3688	.3018	.3018	1.2483
5		.285	.3521	.3353	.3353	1.3923
6		.285	.3521	.3353	.3353	1.5844
7						2.2405
8						2.1445
9						2.1925
11	1.7072	1.8404	1.442	1.4586	1.6484	
12	2.0809	1.8884	1.6907	1.7238		
13	2.1136	1.9845	1.7695	1.7404		
14	2.0153		1.7695			
15	1.9006	1.7924	1.6741	1.7736		
16	1.8515	1.7284	1.5249	1.7901		
17	1.7859	1.7284	1.5249	1.7901		
18	1.6741	1.6324	1.4586	1.6575		.2012
19	.3018	.3856	.3018	.3688	.3688	.3018
20	.3018	.3856	.3018	.3521	.3688	.3018
21	.3018	.3856	.3185	.3521	.3688	.3018
22	.3018	.3856	.3353	.3521	.3856	.285
23	.3018	.3856	.3185	.3353	.3856	.2683
24		.218	.3353	.2683	.2683	.9762
Max	**2.1136**	**1.9845**	**1.7695**	**1.7901**	**1.6484**	**2.2405**
Min	**.3018**	**.218**	**.3018**	**.2683**	**.2683**	**.2012**
Avg	**1.2799**	**.8606**	**.8439**	**.8319**	**.4337**	**1.0410**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274175 / KHUDUS
Feeder No / Name : 204 / ZANJEWADI FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7362	.5967	.6962	.7625	.1677
2		.7362	.5967	.6962	.7625	.1677
3		.7362	.7127	.7625	.779	.1677
4		.8322	.7127	.8453	.779	.1341
5		.9122	.8951	.9282	.8453	.1341
6		1.0082	1.1603	1.0111	.9448	.1341
7		1.2163	1.1934	1.1105	1.1768	
8		1.3443	1.4089	1.1768	1.3757	
9	1.3923	1.3923	1.4089	1.1768	1.1843	
11						1.2163
12						1.3763
13						1.2803
14						.7202
15						.7682
16						.8002
18	.1006		.1006	.0335		.7042
19	.1341	.1341	.1174	.1341	.1341	.1174
20	.1341	.1341	.1174	.1509	.1341	.1174
21	.1341	.1341	.1341	.1509	.1341	.1174
22	.1509	.1677	.1509	.1509	.1677	.1174
23	.1509	.1677	.1509	.1341	.1677	.1341
24		.7362	.5967	.6962	.6133	.1677
Max	**1.3923**	**1.3923**	**1.4089**	**1.1768**	**1.3757**	**1.3763**
Min	**.1006**	**.1341**	**.1006**	**.0335**	**.1341**	**.1174**
Avg	**.3139**	**.6925**	**.6283**	**.6159**	**.6641**	**.4496**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274213 / GARWAD SUBSTATION
Feeder No / Name : 201 / GARWAD FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2193	1.2003	1.0288	.5573
2		1.2631	1.3375	1.286	.5647
3		1.406	1.3717	1.3375	.5573
4		1.4937	1.4575	1.4918	.5716
5		1.5935	1.6289	1.5775	.5944
6		1.7814	1.9719	1.6461	.5858
7	1.829	1.829	2.2291	1.8861	.6241
8	2.1872	1.8595	2.4863	2.3148	.5144
9	2.1643	1.9052	2.4006	2.3148	.4715
10	.2229	.2572	.2572	.3429	.2858
11		.2286	.1715	.2572	
12	.1429	.1715	.1715		2.0622
13	.1372	.1429	.1715		2.1033
14	.1372	.1372	.1715		2.21
15	.1429	.1429	.1715		2.3967
16	.1372	.1646	.1715		2.1338
17	.2469	.2143	.1715		2.1091
18	.3567	.4572	.2572		1.9814
19	.4161	.5335	.6001	.5201	.4572
20	.3715	.5487	.6001	.4287	.5001
21	.3572	.5335	.5144	.4572	.5144
22	.3429	.583	.3429	.4572	.5144
23	.3144	.5487	.3429	.5001	.5001
24		1.1145	1.2003	.9431	.5144
Max	**2.1872**	**1.9052**	**2.4863**	**2.3148**	**2.3967**
Min	**.1372**	**.1372**	**.1715**	**.2572**	**.2858**
Avg	**.5942**	**.8387**	**.8916**	**1.1053**	**1.0141**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274213 / GARWAD SUBSTATION
Feeder No / Name : 202 / CHANDAPURI FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2027	.2229	.2401	1.0669
2		.2	.2229	.2572	1.1145
3		.2143	.2229	.2572	1.1888
4		.2143	.2401	.2401	1.3108
5		.2286	.2401	.2229	1.4022
6		.2572	.2572	.2058	1.5061
7	.2429	.2572	.2572	.2572	1.448
8	.2	.2	.2572	.2572	1.4784
9	.1286	.1286	.1715	.1715	1.4937
10	.1143	.1286	.1372	.1715	.1943
11	1.5242	1.2574	1.5947	1.2193	
12	1.6404	1.4842	1.7833		
13	1.6461	1.5394	1.7833		
14	1.6766	1.5242			
15	1.6404	1.5546	1.6461		.1286
16	1.5242	1.7004	1.5432		.1337
17	1.3717	1.448	1.5089		.1286
18	1.3279	1.2289	1.3717		.1429
19	.2	.2439	.2229	.1858	.1715
20	.2143	.2286	.2401	.2	.2
21	.2286	.2572	.2401	.2	.2286
22	.2286	.2572	.2229	.2	.2439
23	.2572	.2572	.2229	.2143	.2143
24		.2572	.2401	.2401	.9659
Max	**1.6766**	**1.7004**	**1.7833**	**1.2193**	**1.5061**
Min	**.1143**	**.1286**	**.1372**	**.1715**	**.1286**
Avg	**.8333**	**.6362**	**.6456**	**.2788**	**.7381**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274214 / DASUR
Feeder No / Name : 201 / DASUR PATI **FEEDER SEPERATION/PURE AG**
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7164	.6706	.7011	.1219
2	.7621	.7011	.7316	.1219
3	.7621	.7316	.7621	.1219
4	.7926	.7316	.7926	.1219
5	.8535	.7621		.1524
6	.9145	.8383	.9145	.1829
7	1.0669	.9907	1.0364	.1829
8	1.1126	1.0822	1.1126	.1524
9	1.1431	1.1888	1.1279	.1219
10	.0762	.1029	.1219	.1029
11	.061	.061	.1219	1.3375
12	.061	.061		1.3717
13	.061	.0762		1.406
14	.061	.061		1.4403
15	.061	.0762		1.4575
16	.061	.061		1.4746
17	.0914	.0762		1.406
18	.1677	.1219		1.3717
19	.1372	.1715	.1677	.1715
20	.1219	.1543	.1524	.1543
21	.1372	.1372	.1524	.1543
22	.1067	.12	.1372	.1372
23	.1524	.12	.1219	.12
24	.6859	.6401	.6401	.1219
Max	**1.1431**	**1.1888**	**1.1279**	**1.4746**
Min	**.061**	**.061**	**.1219**	**.1029**
Avg	**.4236**	**.4057**	**.5496**	**.5628**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274214 / DASUR
Feeder No / Name : 202 / 11 KV NANAWARE WASTI FEEDER SEPERATION/PURE AG FEEDER Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.3353	.2743	.4268
2	.3353	.3353	.2743	.4268
3	.3658	.3658	.3048	.4572
4	.3963	.4268	.3353	.5182
5	.4268	.4572	.3963	.5639
6	.4877	.5182	.4268	.6249
7	.4877	.4572	.5182	.7621
8	.4268	.4725	.5182	.8078
9	.2743	.3353	.3658	.7468
10	.2134	.2401	.2134	.2229
11	.7926	.9602	.8383	.2058
12	.1677	.1829		.2229
13	.1372	.2134		.2229
14	.1067	.0914		.2058
15	.1219	.2134		.2229
16	.1981	.2134		.2401
17	.2439	.2286		.3086
18	.4115	.3658		.3429
19	.4572	.4458	.3963	.4458
20	.3658	.3944	.3048	.4115
21	.3506	.3429	.2743	.3429
22	.3353	.3258	.2439	.2915
23	.3353	.3258	.2286	.2229
24	.3201	.3353	.2743	.3963
Max	**.7926**	**.9602**	**.8383**	**.8078**
Min	**.1067**	**.0914**	**.2134**	**.2058**
Avg	**.3372**	**.3576**	**.3640**	**.4017**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
AKLUJ II SUB-DN.[716] BU 4716
Substation No/ Name :- 274214 / DASUR
Feeder No / Name : 203 / 11 KV BHIMA NADI FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4572	.5182	
2	.4572	.4572	.5335	
3	.4877	.4572	.5335	
4	.4877	.4877	.5335	
5	.5182	.4877	.5487	
6	.5487	.5487	.5944	
7	.5639	.6249	.6401	
8	.5792	.6249	.7164	
9	.5792	.6706	.7316	
11				.823
12				.8916
13				.8745
14				.8916
15				.8916
16				.9088
17				.8916
18				.583
24	.442	.4268	.503	
Max	**.5792**	**.6706**	**.7316**	**.9088**
Min	**.442**	**.4268**	**.503**	**.583**
Avg	**.5121**	**.5243**	**.5853**	**.8445**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
MALSHIRAS S/DN.[808] BU 4808
Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn
Feeder No / Name : 201 / 11KV JADHAVWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2458	.2591	.2785	.1943	1.2452
2				.2591	.2785	.2429	1.1797
3				.2591	.2949	.2915	.2949
4				.2915	.2949	.2915	.2949
5				.3239	.2949	.2915	.2949
6				.3401	.3932	.3077	.3277
7				.3563		.3077	.3277
8			.2458	.3077	.3277	.3077	.3441
9				.2267	.2785	.2753	.2949
10				.176		.1943	.2458
11				1.3763			.16
12		1.587		1.6712			.1457
13		1.4575		1.7204			.16
14		1.587		1.704			.1475
15				1.704			.1475
16			1.7695	1.6712	1.6712		.1638
17				1.6518	1.6876	.1989	.1966
18				1.6032	1.8023		.2458
19	.2401				.2785	1.7004	1.7368
20	.2401				.2785	1.6194	1.5238
21	.2241	.2267			.2785	1.3927	
22	.2241	.2267			.2622	1.3765	
23	.2401	.2429	.2622	.2785	.2622	1.3279	1.1584
24			.2458	.2591	.2818	.1943	1.3108
Max	**.2401**	**1.587**	**1.7695**	**1.7204**	**1.8023**	**1.7004**	**1.7368**
Min	**.2241**	**.2267**	**.2458**	**.176**	**.2622**	**.1943**	**.1457**
Avg	**.2337**	**.8880**	**.5538**	**.8220**	**.5438**	**.6185**	**.5430**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
MALSHIRAS S/DN.[808] BU 4808
Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn
Feeder No / Name : 202 / 11KV CHAUR WASTI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3605	.3201	.3605	.3605	.3239
2				.3201		.3605	.3239
3				1.1523		1.9006	.3239
4				1.3123			.3239
5				1.5043		1.9006	.3563
6				1.6004		1.9662	.3887
7				1.7924		2.13	.3887
8				2.1125	2.2283	2.2611	.3563
9				2.1052	2.2939	2.2119	.3239
10				1.9919		2.13	.3239
11				.3239			2.0729
12		.3239		.3239			2.2186
13		.3239		.3239			2.1376
14		.2915		.2915			2.0729
15				.2915			2.0405
16			.2949	.3239	.2949		1.8138
17				.3239	.3277		1.6518
18				.3239	.3277		1.4737
19	.3887					.3887	.3887
20	.3887					.3887	.3887
21	.3887	.3887				.3887	
22	.3563	.3887				.3887	
23	.3563	.3563	1.4091	2.4939	.3605	.3563	.3353
24			.3605	.3201	.3605	.1989	.3563
Max	**.3887**	**.3887**	**1.4091**	**2.4939**	**2.2939**	**2.2611**	**2.2186**
Min	**.3563**	**.2915**	**.2949**	**.2915**	**.2949**	**.1989**	**.3239**
Avg	**.3757**	**.3455**	**.6063**	**.9776**	**.8193**	**1.1554**	**.9266**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
MALSHIRAS S/DN.[808] BU 4808
Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn
Feeder No / Name : 203 / 11KV SIDACHIWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1677	.1619	.1829	.1475	1.6385
2				.1619		.1475	1.6057
3				.1619		.1638	.1638
4				.1619		.1638	.1638
5				.1619		.1802	.1638
6				.1781		.1802	.1966
7				.1619		.1966	.213
8			.1475	.1619	.1677	.213	.1966
9			.1372	.144	.1524	.1802	.1638
10				.144		.1802	.1638
11				1.3923			.1457
12		1.9433		1.8461			.1457
13		1.9433		1.8785			.1619
14				1.8461			.1296
15				1.8138			.1134
16			2.0153	1.7444	1.4327		.1134
17				1.7124	1.4175		.1296
18				1.6804	1.4022		.1296
19	.2105				.1311	2.0891	2.0081
20	.2105				.1311	1.9595	1.8623
21	.2105	.1619			.1311	1.8947	
22	.2105	.1943			.1311	1.8785	
23	.2105	.1943	.1638	.1829	.1311	1.749	1.5851
24			.1981	.1619		.1475	
Max	**.2105**	**1.9433**	**2.0153**	**1.8785**	**1.4327**	**2.0891**	**2.0081**
Min	**.2105**	**.1619**	**.1372**	**.144**	**.1311**	**.1475**	**.1134**
Avg	**.2105**	**.8874**	**.4716**	**.7929**	**.4919**	**.7170**	**.5330**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
MALSHIRAS S/DN.[808] BU 4808
Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn
Feeder No / Name : 204 / 11KV DEV AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.2289	1.3123	1.1888	.7956	.16
2				1.2803		.7956	.16
3				.16		.1492	.9922
4				.16		.1326	1.0402
5				.192		.1326	1.0883
6				.2241		.1326	1.1203
7				.2401		.1326	1.3443
8			.213	.2241	.213		1.5364
9			.1966	.1781	.1372	.1326	1.6324
10				.1781		.0995	1.5844
11				.1619			.128
12		.144		.144			.128
13		.0972		.144			.128
14		.0972					.128
15				.128			.128
16			.1147	.1619	.1067		.1296
17				.1619	.0914		.1457
18				.1781	.061		.1457
19	1.6644				.9116	.208	.1943
20	1.5364				.8619	.208	.1781
21	1.4723	1.4251			.8453	.192	
22	1.3763	1.3765			.7956	.1943	
23	1.3443	1.3279	1.4091	1.2498	.779	.1781	.1524
24			1.278	1.3603	1.2193	.779	.176
Max	**1.6644**	**1.4251**	**1.4091**	**1.3603**	**1.2193**	**.7956**	**1.6324**
Min	**1.3443**	**.0972**	**.1147**	**.128**	**.061**	**.0995**	**.128**
Avg	**1.4787**	**.7447**	**.7401**	**.4126**	**.6009**	**.2842**	**.5646**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
MALSHIRAS S/DN.[808] BU 4808
Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn
Feeder No / Name : 205 / 11KV MALSHRAS URBAN SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.852	.8916	.8478	.8573	.8573
2				.7888		.8059	.7716
3				.8916		.9259	.823
4				1.0974		1.0631	
5				1.166		1.2003	1.0631
6				1.2517		1.3375	1.2689
7				1.3032		1.166	1.2346
8				1.0631	1.1361	1.0802	1.2174
9			.9831	.9945	.9835	.9259	1.0288
10				.9431		.9088	.9259
11				.9259		.8916	.9602
12		.8402		.823		.823	
13		.823		.7545		.7202	.8402
14		.7888		.6859		.6687	.7202
15				.6344		.6516	.6516
16			.7291	.823	.7122	.6344	.7888
17			.7701	.8916	.7291	.6859	.8916
18				1.0288	1.0513		.9431
19	1.2689				1.0526	1.3375	1.166
20	1.2346					1.2346	1.1317
21	1.1317	1.1317				1.0974	
22	1.046	1.0631	1.065			1.0288	
23	.9602	.9774	.9995	.9175	.8535	.9945	.823
24			.9012	1.0288	.8817	.9088	.8916
Max	**1.2689**	**1.1317**	**1.065**	**1.3032**	**1.1361**	**1.3375**	**1.2689**
Min	**.9602**	**.7888**	**.7291**	**.6344**	**.7122**	**.6344**	**.6516**
Avg	**1.1283**	**.9374**	**.9**	**.9452**	**.9164**	**.9543**	**.9499**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
MALSHIRAS S/DN.[808] BU 4808
Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn
Feeder No / Name : 206 / 11KV Medad AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3277	.3277	.3353	.3563	.3239
2				.3277		.3563	.3239
3				1.4746		1.4899	.3239
4				1.5729		1.587	.3239
5				1.6385		1.6356	.3563
6				1.7859		1.7814	.421
7				2.3102		2.1538	.3725
8			2.769	2.5888	2.8018	2.6397	.3077
9			2.7854	2.5606	2.7526	2.6558	.2591
10				2.6235		2.2672	.2267
11				.176			2.6558
12		.128		.1619			2.7854
13		.1296		.1781			2.7368
14		.1781		.1457			2.7692
15				.1457			2.7044
16			.2374	.1966	.1524		2.4646
17				.2294	.1829	.3441	2.2725
18				.3113	.1829		2.1925
19	.3239				.2785	.3725	.3521
20	.3239				.3277	.3725	.3361
21	.3077	.3077			.3277	.3563	
22	.3077	.3077			.3277	.3563	
23	.3239	.3239	.3277	.3201	.3441	.3401	.3201
24			.3277	.3277	.3201	.3401	.3239
Max	**.3239**	**.3239**	**2.7854**	**2.6235**	**2.8018**	**2.6558**	**2.7854**
Min	**.3077**	**.128**	**.2374**	**.1457**	**.1524**	**.3401**	**.2267**
Avg	**.3174**	**.2292**	**1.1292**	**.9701**	**.6945**	**1.1415**	**1.1433**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
MALSHIRAS S/DN.[808] BU 4808
Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn
Feeder No / Name : 207 / 11KV TARANGFAL AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4096	.4372		.421	.3978
2				.4372		.421	.3978
3				.4372		.4534	1.8233
4				.4534		.5506	1.9227
5				.4696		.5182	1.989
6				.502		.4858	2.1382
7				.4858		.4858	2.5194
8			.426	.4372	.4572	.4696	.4641
9			.426	.3239		.4049	3.0498
10				.3077		.3401	2.9172
11				2.1538			.3239
12		3.0769		2.7044			.2915
13		3.0931		2.672			.3239
14		3.0445		2.6558			.2591
15				2.6235			.2267
16			2.2939	2.4939			.2267
17			2.343	2.332	2.1338		.2591
18				2.1538	1.9814		.2915
19	.3887				.426	.3563	.3887
20	.3887				.3932	.3725	.3725
21	.4049	.3887			.3768	.3725	
22	.4049	.4049			.3768	.3887	
23	.421	.421	.4424	.3932	.3932	.3887	.3963
24			.426	.4372	.3658	.3887	.3978
Max	**.421**	**3.0931**	**2.343**	**2.7044**	**2.1338**	**.5506**	**3.0498**
Min	**.3887**	**.3887**	**.4096**	**.3077**	**.3658**	**.3401**	**.2267**
Avg	**.4016**	**1.7382**	**.9667**	**1.2455**	**.7671**	**.4261**	**.9717**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
MALSHIRAS S/DN.[808] BU 4808
Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn
Feeder No / Name : 208 / 11 KV TARANGFAL GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4424	.4641		.3978	.3978
2				.4641		.431	.3978
3				.4641		.4641	.431
4				.4973		.5304	.4641
5				.5304		.6299	.5304
6				.6464		.663	.6299
7				.6299		.4973	.5967
8			.5079	.4973	.4694	.4807	.5304
9			.4752	.2984		.3978	
10				.2321		.3149	
11				.1989			.2652
12		.2155		.1658			.2155
13		.2155		.1658			.2155
14		.1989		.1658			.2155
15				.1658			.2155
16			.2458	.2321	.2347		.2321
17			.2458	.2984	.285		.2652
18				.3725	.4191		.3481
19	.5304				.4321	.6299	.5304
20	.4973				.4784	.5304	.4807
21	.3978	.4973			.4475	.4973	
22	.3647	.3647			.4012	.4641	
23	.3647	.3647	.4588	.3658	.3549	.4144	.4115
24			.3605	.4641	.4024	.3812	.4144
Max	**.5304**	**.4973**	**.5079**	**.6464**	**.4784**	**.663**	**.6299**
Min	**.3647**	**.1989**	**.2458**	**.1658**	**.2347**	**.3149**	**.2155**
Avg	**.4310**	**.3094**	**.3909**	**.3660**	**.3925**	**.4828**	**.3894**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
MALSHIRAS S/DN.[808] BU 4808
Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn
Feeder No / Name : 209 / 11KV KALE-PANDARE AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.4419	1.4899	1.704	1.5249	.2105
2				1.4575		1.4752	.2105
3				.2591		.2652	1.4089
4				.2591		.2818	1.4575
5				.2591		.2984	1.5546
6				.3077		.3315	1.6518
7				.3239		.2818	1.9433
8			.2785	.2915	.2785	.2652	2.1862
9			.2622	.2294	.2294	.2155	2.2348
10				.1802		.1989	2.17
11				.1638			.1296
12		.144		.1457			.1296
13		.144		.1457			.1296
14		.144		.1296			.16
15				.1296			.1619
16			.0983	.1619	.1147		.1943
17			.1475	.1619	.1147		.1943
18				.1781	.1524		.2105
19	2.1956				1.9062	.2949	.2915
20	2.1464				1.873	.2622	.2915
21	2.0317	1.7924			1.8233	.2458	
22	1.8187	1.5684	1.7204		1.7901	.2458	
23	1.7368	1.4723	1.6057	1.8991	1.6741	.2458	.2134
24			1.4582	1.5223	1.6613	1.5912	.2267
Max	**2.1956**	**1.7924**	**1.7204**	**1.8991**	**1.9062**	**1.5912**	**2.2348**
Min	**1.7368**	**.144**	**.0983**	**.1296**	**.1147**	**.1989**	**.1296**
Avg	**1.9858**	**.8775**	**.8766**	**.4848**	**1.1101**	**.5015**	**.7891**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
MALSHIRAS S/DN.[808] BU 4808
Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn
Feeder No / Name : 210 / COURT-(GOVT) EXPRESS FEEDER Feeder KV- 11 / OUTGOING NON SHEDDABLE WATER SUPPLY AND UTILITY

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1147	.1326	.1067	.1326	.1326
2				.1326		.1326	.1326
3				.1326		.1326	.1326
4				.1326		.1326	.1326
5				.1326		.1326	.1326
6				.1326		.1326	.1326
7				.1326		.1326	.1326
8			.1147	.1326	.1067	.1326	.1326
9				.1326	.1067	.1326	.1326
10				.1326		.1326	.1326
11				.1326		.1326	.1326
12		.1326		.1326		.1326	.1326
13		.1326		.1326		.1326	.1326
14				.1326		.1326	.1326
15				.1326		.1326	.1326
16			.1147	.1326	.1067	.1326	.1326
17				.1326	.1147	.1326	.1326
18				.1326	.1067	.1326	.1326
19	.1326					.1326	.1326
20	.1326				.1147	.1326	.1326
21	.1326				.0819	.1326	
22	.1326				.0983	.1326	
23	.1326		.1147	.1067	.1147	.1326	.1067
24			.1147	.1326	.0914	.1326	.1326
Max	**.1326**	**.1326**	**.1147**	**.1326**	**.1147**	**.1326**	**.1326**
Min	**.1326**	**.1326**	**.1147**	**.1067**	**.0819**	**.1326**	**.1067**
Avg	**.1326**	**.1326**	**.1147**	**.1313**	**.1045**	**.1326**	**.1314**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
MALSHIRAS S/DN.[808] BU 4808
Substation No/ Name :- 274105 / 33/11KV ISLAMPUR S/Stn
Feeder No / Name : 201 / 11KV KANHER AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0972	.1134	.1524	.7865
2		.0972	.1296	.1524	.852
3		.1134	.1296	.1524	.8848
4		.1134		.1524	.9831
5		.1296	.1619	.1562	1.1142
6		.1457	.1457	.1524	1.1797
7		.1457	.1457	.1372	1.3108
8		.1457	.1296	.1219	1.4582
9		.1134	.1457	.1524	.1296
10		.1296	.1219	.1134	.1311
11		.1296	.1219		.1311
12		.1134	.1219		.1147
13		.081	.1067		.1147
14		.081	.1067		.0983
15		.081	.1067		.0983
16		.0972	.1372		.1147
17		1.3279	1.2334		.0983
18		1.4737	1.326	.1296	.1147
19		1.4575	1.3441	.1457	.1638
20		1.3603	1.3441	.1457	.1638
21		1.2955	1.2176	.1457	.1802
22		1.2146	1.186	.1296	.1802
23	1.2452	1.1336		.1296	.1638
24		1.2289	1.0202	1.1069	.1296
Max	**1.2452**	**1.4737**	**1.3441**	**1.1069**	**1.4582**
Min	**1.2452**	**.081**	**.1067**	**.1134**	**.0983**
Avg	**1.2452**	**.5128**	**.4816**	**.1986**	**.4457**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
MALSHIRAS S/DN.[808] BU 4808
Substation No/ Name :- 274105 / 33/11KV ISLAMPUR S/Stn
Feeder No / Name : 202 / 11KV ISLAMPUR AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.852	.7125	.7287	.081
2		.852	.7287	.7287	.0972
3		.9503	.7287	.7611	.0648
4		1.0159	.8097	.7773	.1134
5		1.1142	.9054	.8097	.1457
6		1.2289	1.0202	.8421	.1619
7		1.3599	1.166	1.004	.1781
8		1.5238	1.3765	1.2631	.1457
9		1.4091	1.2955	1.247	.0972
10		.0972	.1094	.081	.0819
11		.0972	.1094		1.4575
12		.0648	.0937		1.6194
13		.0486	.0625		1.6842
14		.0486	.0469		1.7166
15		.0486	.0781		1.6842
16		.0648	.0937		1.6518
17		.0972	.0937		1.4575
18		.1134	.1094	.0972	1.2955
19		.1134	.125	.1296	.1638
20		.1296	.125	.1134	.1311
21		.1296	.125	.1134	.1475
22		.1296	.125	.1296	.1311
23	.0972	.1457	.125	.0972	.1311
24		.8356	.664	.6964	.081
Max	**.0972**	**1.5238**	**1.3765**	**1.2631**	**1.7166**
Min	**.0972**	**.0486**	**.0469**	**.081**	**.0648**
Avg	**.0972**	**.5196**	**.4512**	**.5659**	**.6050**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
MALSHIRAS S/DN.[808] BU 4808
Substation No/ Name :- 274105 / 33/11KV ISLAMPUR S/Stn
Feeder No / Name : 203 / 11KV MANAKI AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6554	1.0526	.583	.2267
2		.6882	1.1174	.7287	.2267
3		.7865	1.1174	.9488	.2429
4		1.1142	1.166	1.2803	.2591
5		1.2452	1.3117	1.3603	.2753
6		1.4582	1.5546	1.4723	.2915
7		2.1792	1.7814	1.7924	.2915
8		1.7532	1.8785	1.7604	.2591
9			.2429	.2187	1.5565
10			.2187	.1781	2.0243
11			.1875		2.2186
12			.1718		2.2024
13			.1718		2.17
14			.1562		2.251
15			.1562		2.5425
16			.1406		2.17
17			.1875		.1802
18			.1875	.2105	.2294
19			.2343	.2429	.2949
20			.2343	.2429	.2949
21		.2429	.2343	.2429	.2949
22		.2429	.2343	.2267	.2785
23	.2753	.2429	.2343	.2429	.2622
24		.2429	.2429	.2343	.2267
Max	**.2753**	**2.1792**	**1.8785**	**1.7924**	**2.5425**
Min	**.2753**	**.2429**	**.1406**	**.1781**	**.1802**
Avg	**.2753**	**.9043**	**.5923**	**.7039**	**.8862**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
MALSHIRAS S/DN.[808] BU 4808
Substation No/ Name :- 274105 / 33/11KV ISLAMPUR S/Stn
Feeder No / Name : 204 / ISLAMPUR GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1041	1.0526	1.0808	1.1041
2		1.1222	1.1822	1.0985	1.086
3		1.1584	1.3765	1.1517	1.1222
4		1.2489	1.4413	1.2403	1.1584
5		1.3032	1.4737	1.4175	1.2489
6		1.3756	1.5223	1.6655	1.3756
7		1.5565	1.3765	1.6301	1.5384
8		1.2308	1.166	1.4352	1.3032
9		1.0679	.9717	1.0985	1.1041
10		.7611	.815	.7783	.7796
11		.6478	.6024		.7087
12		.583	.567		.6556
13		.4372	.567	.5068	.6024
14		.4534	.5493	.543	.5493
15		.4534	.6024	.5792	.5847
16		.4858	.6024	.5973	.6201
17		.5668	.6556	.724	
18		.9393	.9745	1.0498	1.2048
19		1.1012	1.5415	1.448	1.5061
20		1.1498	1.4175	1.267	1.3289
21		1.1984	1.3289	1.2489	1.1871
22		1.1498	1.2226	1.2308	1.1694
23	1.1584	1.0526	1.1694	1.1222	1.1163
24		1.1222	.9717	1.0808	.9774
Max	**1.1584**	**1.5565**	**1.5415**	**1.6655**	**1.5384**
Min	**1.1584**	**.4372**	**.5493**	**.5068**	**.5493**
Avg	**1.1584**	**.9696**	**1.0479**	**1.0906**	**1.0448**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
MALSHIRAS S/DN.[808] BU 4808
Substation No/ Name :- 274105 / 33/11KV ISLAMPUR S/Stn
Feeder No / Name : 205 / GORADWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3563	.3401	.3125	.2591
2		.3401	.3401	.3125	.2915
3		.3401	.3725	.3125	.3239
4		.3563	.3887	.3437	.3239
5		.3725	.4049	.3906	.3401
6		.3887	.4191	.4062	.3563
7		.3725	.4049	.3749	.3563
8		.3563	.421	.3437	.3239
9		2.4249		.2656	.2915
10		2.4291		.2429	.2458
11		2.5101			.2294
12		2.5911			.2294
13		2.6073			.2294
14		2.5911	2.0243		.1966
15		2.5587	2.3562		.1966
16		2.3158	2.372		.1966
17		.2267	.2031		2.1052
18		.2753	.2343	2.4453	2.5425
19		.3077	.3125	2.6052	2.3967
20		.3401	.3125	2.4577	2.1052
21		.3401	.3437	2.4249	2.0567
22		.3563	.3281	2.2611	1.9109
23	.3725	.3563	.3281	2.1628	1.8623
24		.3563	.3563	.3125	1.9989
Max	**.3725**	**2.6073**	**2.372**	**2.6052**	**2.5425**
Min	**.3725**	**.2267**	**.2031**	**.2429**	**.1966**
Avg	**.3725**	**1.0612**	**.6454**	**1.0573**	**.8904**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
MALSHIRAS S/DN.[808] BU 4808
Substation No/ Name :- 274105 / 33/11KV ISLAMPUR S/Stn
Feeder No / Name : 206 / SARGARWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2267	.2591	.25	
2		.2429	.2915	.25	
3		.2429	.3239	.25	
4		.2591	.3239	.25	
5		.2753	.3725	.3437	
6		.2915	.3563	.3749	
7		.3239	.3401	.3437	
8		.2429	.3018	.2968	
9		.1943	.1943	.25	
10		.1781	.1718	.1943	
11		1.1984	1.4575		
12		1.3765	1.587		
13		1.4899	1.7328		
14		1.4575	1.6032		
15		1.4575	1.6356		
16		1.5546	1.5708		
17		1.166	1.5223		
18		1.3117	1.3279	1.3435	.2622
19		.2105	.25	.2429	.3277
20		.2267	.25	.2591	.3277
21		.2267	.25	.2591	.2949
22		.2267	.25	.2591	.2949
23	.2429	.2429	.25	.2591	.2949
24		.2267	.2429	.25	
Max	**.2429**	**1.5546**	**1.7328**	**1.3435**	**.3277**
Min	**.2429**	**.1781**	**.1718**	**.1943**	**.2622**
Avg	**.2429**	**.6187**	**.7027**	**.3339**	**.3004**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
MALSHIRAS S/DN.[808] BU 4808
Substation No/ Name :- 274132 / 33KV KACHREWADI S/STN
Feeder No / Name : 201 / DESHMUKH PATTA AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2286	.2572	1.4022
2	.2572	.2286	.2572	1.3717
3	.2572	.2286	.2572	1.6004
4	.2572	.2134	.2401	1.448
5	.2572	.2134	.2401	1.4632
6	.2401	.2134	.2401	1.5242
7	.2401	.1829	.2058	1.6004
8	.2058	.1524	.1677	1.5546
9	.1715	.1524	.1715	1.6004
10	.1715	.1524		.1524
11	1.1431	1.1431		.1715
12	1.1431	1.3717		
14	.9145	1.5384		
15	.9907	1.5432		
16	1.1431	1.4746		
17	1.3717	1.5432		
18	1.2193	1.3717		.1715
19	.1829	.2058	.1829	.2401
20	.1829	.2058	.1829	.2401
21	.2134	.2401	.1829	.2401
22	.2134	.2401	.2134	.2401
23	2.0005	.2572	.2286	.2572
24	.2572	.2572		1.2193
Max	**2.0005**	**1.5432**	**.2572**	**1.6004**
Min	**.1715**	**.1524**	**.1677**	**.1524**
Avg	**.5779**	**.5808**	**.2163**	**.9165**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
MALSHIRAS S/DN.[808] BU 4808
Substation No/ Name :- 274132 / 33KV KACHREWADI S/STN
Feeder No / Name : 202 / 11KV UMBARE DAHIGAON AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.166	1.0669	1.1736	.3353
2	1.1145	1.1584	1.2742	.3353
3	1.1145	1.2803	1.4083	.3048
4	1.1317	1.3717	1.4419	.2743
5	1.166	1.5546	1.5089	.2896
6	1.3032	1.6461	1.5089	.3353
7	1.6289	1.7528	1.6766	.3658
8	2.0233	1.829	1.989	.3048
9	1.9719	1.829	1.9662	.2134
10	.2058	.1829		.1829
11	.1829	.2286		2.0919
12	.1524	.2286		
13		.1372		
14		.1311		2.4177
15		.1658		2.4863
16		.1658		2.4863
17		.1981		2.332
18	.2134	.213		2.2291
19	.2743	.3353	.2134	.3429
20	.3048	.3353	.2134	.3772
21	.3353	.3605	.2591	.4115
22	.3353	.4024	.3353	.4115
23	.3353	.4024	.2896	.4115
24	1.2174	1.0898		.3048
Max	**2.0233**	**1.829**	**1.989**	**2.4863**
Min	**.1524**	**.1311**	**.2134**	**.1829**
Avg	**.8514**	**.7527**	**1.0899**	**.8747**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
MALSHIRAS S/DN.[808] BU 4808
Substation No/ Name :- 274132 / 33KV KACHREWADI S/STN
Feeder No / Name : 203 / KHANDOBA WASTI AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.7316	.7865	.1829
2	.8402	.823	.8192	.1677
3	.8745	.9145	.9012	.2134
4	.9602	1.0364	.9831	.2591
5	1.1145	1.1279	1.065	.2286
6	1.166	1.2193	1.2616	.2134
7	1.5089	1.4022	1.4746	.2134
8	1.6804	1.6156	1.6518	.2134
9	1.6804	1.5242	1.6244	.1372
10	.1543	.1829		.1219
11	.1524	.1638		1.7147
12	.1524	.1457		1.8004
13	.1372			
14	.1372	.0648		1.5604
15	.1372	.0983		1.6804
16	.1372	.1006		1.4403
17	.1372	.1677		1.4746
18	.1524	.1677		1.2346
19	.1677	.2458	.1372	.1715
20	.1829	.2683	.1372	.1715
21	.1981	.2683	.1524	.1886
22	.1981		.1524	.1715
23	.1981	.2155	.1981	.1715
24	.7888	.7373		.1677
Max	**1.6804**	**1.6156**	**1.6518**	**1.8004**
Min	**.1372**	**.0648**	**.1372**	**.1219**
Avg	**.5700**	**.6010**	**.8103**	**.6043**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
MALSHIRAS S/DN.[808] BU 4808
Substation No/ Name :- 274132 / 33KV KACHREWADI S/STN
Feeder No / Name : 204 / 11KV KACHAREWADI GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2134	.2743	.1036	.2321	.2134
2		.2743	.1067	.2321	.2134
3	.2134	.2743	.1097	.2321	.2439
4		.2915	.1143	.2486	.2439
5	.2439	.3086	.1235	.2818	.2439
6		.3429	.1372	.3315	.2439
7		.3772	.1311	.3481	.2134
8		.2915	.1158	.2785	.1981
9		.2229	.1021	.2105	.1829
10		.2058	.0869		.1829
11		.0777	.1677		.1886
12		.0716	.1524		.1715
13		.0655			
14		.0579	.0995		.1372
15		.0549	.12		.1543
16		.061	.1006		.12
17		.0625	.1311		.1372
18		.0777	.1943		.2058
19		.0914	.2949	.1829	.2572
20		.0945	.2984	.1829	.2401
21		.0991		.1829	.2229
22		.1006	.2321	.1829	.2229
23		.1021	.2321	.2134	.2229
24		.2401	.2294		.1981
Max	**.2439**	**.3772**	**.2984**	**.3481**	**.2572**
Min	**.2134**	**.0549**	**.0869**	**.1829**	**.12**
Avg	**.2236**	**.1717**	**.1538**	**.2386**	**.2025**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
MALSHIRAS S/DN.[808] BU 4808
Substation No/ Name :- 274132 / 33KV KACHREWADI S/STN
Feeder No / Name : 205 / KAMALMALA AG FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.3658	.2915	2.0729
2		.3658	.2915	2.2253
3	.3429	.3658	.2915	2.3167
4	.3772	.3658	.3077	2.2405
5	.3772	.3658	.3077	2.1643
6	.3944	.3963	.3239	2.1186
7	.4115	.3506	.3887	2.0729
8	.3429	.3048	.407	
9	.3258	.2743	.3185	
10	.2572	.2896		
11	1.8138	2.0719		
12	1.89	2.3371		
13	1.9814	1.8399		
14	1.9509	1.9006		
15	1.9052	1.9595		
16	1.8595	2.0317		
17	1.829	2.0481		
18	1.7071	1.9006		.2915
19	.2591	.3441	.2591	.2915
20	.2743	.3647	.2896	.3429
21	.3201	.3563	.3201	.3772
22	.3353	.3077	.3201	.3601
23	.3353	.2949	.2896	.3429
24	.3258	.3315		2.0119
Max	**1.9814**	**2.3371**	**.407**	**2.3167**
Min	**.2572**	**.2743**	**.2591**	**.2915**
Avg	**.8670**	**.8972**	**.3148**	**1.3735**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
MALSHIRAS S/DN.[808] BU 4808
Substation No/ Name :- 274132 / 33KV KACHREWADI S/STN
Feeder No / Name : 206 / TIRWANDI AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.4877	.6371	.2134
2	.6001	.5487	.6371	.1829
3	.6173	.6097	.6539	.2286
4	.6516	.6401	.6539	.2134
5	.5487	.6706	.6706	.2134
6	.6687	.7316	.6554	.2439
7	.9259	.7468	.8421	.2591
8	1.0117	.823	.9448	.2743
9	1.0117	.884	.8886	.1677
10	.1543	.1829		.1981
11	.1219	.1341		.8916
12	.1219	.1174		1.0631
13	.1219	.1006		
14	.1067	.0838		1.046
15	.1067	.1341		1.1145
16	.1067	.1134		1.1488
17	.1067	.116		1.0974
18	.1372	.1475		1.0288
19	.1829	.3077	.1677	.3086
20	.2439	.3277	.1829	.3086
21	.2591	.3277	.1677	.3258
22	.2591	.3113	.1677	.3429
23	.2591	.2984	.1829	.3429
24	.5487	.4858		.1981
Max	**1.0117**	**.884**	**.9448**	**1.1488**
Min	**.1067**	**.0838**	**.1677**	**.1677**
Avg	**.3933**	**.3888**	**.5323**	**.4962**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
MALSHIRAS S/DN.[808] BU 4808
Substation No/ Name :- 274177 / 33/11KV MANDAVE S/S
Feeder No / Name : 201 / 11KV LAXMINAGAR AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3048	.3258	.9777
2	.3429	.3048	.3258	1.2443
3	.3734	.3048	.3429	1.2798
4	.3601	.3201	.8573	1.5109
5	.3944	.3944	.4115	1.7776
6	.4115	.4268	.4801	2.0442
7	.4458	.381	.4801	2.293
8	.3944	.3201	.4115	2.4352
9	.3201	.2915	.3555	2.0729
10	.2134	.2229	.2666	.1829
11	1.7223	2.0919		.1372
12	1.768	2.2977		.1067
13	1.768	2.4646		.1524
14	1.5546	2.3339		.1677
15	1.7071	1.989		.1219
16	2.2291	1.8861		.1219
17	1.7071	1.869		.1524
18	1.6918	1.9791	1.8309	.2439
19	.3201	.3429	.2489	.3353
20	.3048	.3734	.2666	.3048
21	.3048	.3734	.2844	.2896
22	.3048	.3258	.3022	.2896
23	.3048	.3258	.2844	.2896
24	.3429	.3048	.3258	.8532
Max	**2.2291**	**2.4646**	**1.8309**	**2.4352**
Min	**.2134**	**.2229**	**.2489**	**.1067**
Avg	**.8179**	**.9262**	**.4588**	**.8077**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
MALSHIRAS S/DN.[808] BU 4808
Substation No/ Name :- 274177 / 33/11KV MANDAVE S/S
Feeder No / Name : 202 / 11KV GIRVI AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2174	1.2689	1.3546	.4658
2	1.2174	1.286	1.4232	.4658
3	1.286	1.286	1.5089	.4658
4	1.3375	1.3375	1.5432	.4845
5	1.4403	1.6461	1.6461	.4845
6	1.4918	1.8004	1.9547	.5031
7	1.9033			.5404
8	2.1605		2.5549	.5031
9	2.1948		2.59	.3258
10	.2572	.3429	.2795	.2401
11	.1886	.2743		2.2291
12	.1886	.2229		2.4691
13	.1886	.2058		2.5206
14	.2058	.1715		2.452
15	.2058	.1886		2.4863
16	.2058	.2058		2.5549
17	.2743	.2915		2.4348
18	.3429	.3429	.4099	2.2119
19	.4973	.4801	.4658	.4801
20	.5144	1.0117	.5404	.4973
21	.5144	.4801	.5217	.4973
22	.5144	.463	.5217	.4973
23	.4801	.463	.5031	.5144
24	1.1831	1.2689	1.3546	.4845
Max	**2.1948**	**1.8004**	**2.59**	**2.5549**
Min	**.1886**	**.1715**	**.2795**	**.2401**
Avg	**.8338**	**.7161**	**1.1983**	**1.1170**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
MALSHIRAS S/DN.[808] BU 4808
Substation No/ Name :- 274177 / 33/11KV MANDAVE S/S
Feeder No / Name : 203 / 11KV MANDAVE GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7888	.8059	.7545	.801
2	.7888	.823	.7545	.7846
3	.7888	.823	.8059	.7846
4	.8916	.8573	.8573	.8173
5	.9945	.9945	.9774	.8991
6	1.1488	1.2003	1.166	1.0625
7	1.2174	1.1488	1.1317	1.1279
8	.9088	1.0802	.9602	1.0789
9	.8402	.8745	.8991	.9945
10	.6859	.7095	.6866	.7373
11	.7202	.6516	.7029	.6516
12	.6001	.6001		.6001
13	.5316	.5658		.5487
14	.5144	.4973	.5558	.5144
15	.5144	.5316	.5885	.5487
16	.5144	.583	.6048	.6001
17	.6516	.7545	.6375	.6687
18	1.0288	.9259	.8664	.9259
19	1.0974	1.046	.9318	1.166
20	.9774	1.0117	.9645	
21	.9431	.9088	.9154	.9945
22	.8916	.8573	.8827	.9259
23	.823	.7888	.85	.823
24	.7888	.8059	.7545	.801
Max	**1.2174**	**1.2003**	**1.166**	**1.166**
Min	**.5144**	**.4973**	**.5558**	**.5144**
Avg	**.8188**	**.8269**	**.8295**	**.8198**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
MALSHIRAS S/DN.[808] BU 4808
Substation No/ Name :- 274177 / 33/11KV MANDAVE S/S
Feeder No / Name : 204 / 11KV AHILYANAGAR AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.5335	.4458	1.3336
2	.4801	.5335	.4458	1.6194
3	.4801	.5525	.4458	1.9052
4	.4973	.6478	.4458	
5	.5316	.6287	.4973	2.3434
6	.5658	.6859	.5487	2.4768
7	.583	.5906	.4973	2.7054
8		.4954	.4287	2.7435
9		.4458	.381	2.8387
10		.3258	.362	.3048
11	2.1529	2.1262		.2667
12	2.4958	2.2634		.2096
13	2.4958	2.332		.1715
14	2.572	2.332		.1905
15	2.5339	2.2291		.1905
16	2.4958	2.1605		.2286
17	2.3053	2.0576		.2667
18	2.191	1.9204	2.0195	.362
19	.5144	.463	.381	.4954
20	.5144	.463	.4382	.5335
21	.5525	.463	.4954	.5335
22	.5525	.4801	.5144	.5335
23	.5525	.4801	.4954	.5335
24	.9945	.5335	.4458	1.2003
Max	**2.572**	**2.332**	**2.0195**	**2.8387**
Min	**.4801**	**.3258**	**.362**	**.1715**
Avg	**1.2639**	**1.0726**	**.5463**	**1.0429**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
MALSHIRAS S/DN.[808] BU 4808
Substation No/ Name :- 274177 / 33/11KV MANDAVE S/S
Feeder No / Name : 205 / 11KV PURANDAWADE AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6344	.6668	.5487	.1905
2	.6344	.6668	.583	.1905
3	.7373	.6668	.583	.2286
4	.8029	.743	.6687	.2286
5	.8573	.8764	.7373	.2477
6	.9602	1.0669	.8402	.2477
7	1.3817	1.448	1.0117	.3239
8	1.4746	1.5432	1.406	.2858
9	1.467	1.406	1.467	.2286
10	.1905	.1543	.2096	.1905
11	.1334	.1372		1.1241
12	.1334	.1029		1.2765
13	.1334	.1029		1.3146
14	.1143	.1029		1.3336
15	.1143	.1029		1.3336
16	.1334	.1029		1.3336
17	.1715	.1543		1.3146
18	.2286	.2058	.2477	.8002
19	.3048	.2743	.2477	.2858
20	.2477	.2401	.2286	.2477
21	.2096	.2058	.2286	.2096
22	.1905	.1715	.2096	.2096
23	.1905	.1715	.2096	.1905
24	.6001	.6478	.5487	.1905
Max	**1.4746**	**1.5432**	**1.467**	**1.3336**
Min	**.1143**	**.1029**	**.2096**	**.1905**
Avg	**.5019**	**.4984**	**.5868**	**.5636**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
NATEPUTE[103] BU 6360
Substation No/ Name :- 274036 / 33/11 KV DAHIGAON SUBSTATION
Feeder No / Name : 201 / 11KV DAHIGAON AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4801	.5144	.5144	1.2346
2		.4801	.5144	.503	1.3717
3		.463	.5144	.5144	1.3717
4		.463	.5144	.5975	1.3717
5		.463	.5144	.5868	1.5261
6		.5316	.5144	.5868	1.6289
7		.5316	.5316	.5365	1.8004
8		.463	.4801	.463	2.3663
9		.4115	.4115	.3772	2.1605
10		.3258	.2229	.3429	.3772
11		2.4006	2.0576	2.0919	.1715
12		2.5206	2.2382	2.1434	.1715
13		2.2291	2.3739		.2058
14		2.2291	2.1879	1.7833	.2058
15		1.8004	2.1434	2.2462	.2401
16		1.8861	1.7604	2.1434	.2743
17		2.0919	1.8442	1.9719	.3086
18		1.6975	1.5927	1.7661	.4115
19		.5144	.5868	.5658	.5658
20		.5144	.4793	.5487	.5365
21		.5144	.9831	.5316	.5316
22	.5316	.5144	.503	.5316	.503
23	.5144	.5144	.5144	.5144	.5144
24		.4801	.5144	.503	.9945
Max	**.5316**	**2.5206**	**2.3739**	**2.2462**	**2.3663**
Min	**.5144**	**.3258**	**.2229**	**.3429**	**.1715**
Avg	**.523**	**1.0217**	**1.0213**	**.9723**	**.8685**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
NATEPUTE[103] BU 6360
Substation No/ Name :- 274036 / 33/11 KV DAHIGAON SUBSTATION
Feeder No / Name : 202 / 11KV KALAMBOLI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3717	1.286	1.2574	.5144
2		1.6289	1.3717	1.2574	.5144
3		1.6289	1.3717	1.3717	.5144
4		1.6804	1.3717	1.4251	.5144
5		1.8004	1.5432	1.5089	.5658
6		2.0576	1.5432	1.6289	.6173
7		2.1434	1.989	2.1434	.6687
8		2.3148	2.3148	2.3148	.5144
9		2.2291	2.332	2.2382	
10		.3601	.3018	2.2291	.4458
11		.3086	.2201	.2743	2.2634
12		.2229		.2743	2.4006
13					2.4863
14		.2572	.2058		
15		.2572	.2058		
16		.3086	.3086		
17		.3258	.4115	.5144	
18		.5487	.4287	.5144	2.572
19		.6173	.6173	.6344	.6001
20		.6173	.6001	.6173	.5868
21		.6173	.5658	.6173	.57
22	.6001	.6173	.5487	.5658	.5487
23	.583	.6173	1.286	.5144	.5144
24		1.3375	1.286	1.2574	.5144
Max	**.6001**	**2.3148**	**2.332**	**2.3148**	**2.572**
Min	**.583**	**.2229**	**.2058**	**.2743**	**.4458**
Avg	**.5916**	**1.0378**	**1.0050**	**1.1579**	**.9435**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
NATEPUTE[103] BU 6360
Substation No/ Name :- 274036 / 33/11 KV DAHIGAON SUBSTATION
Feeder No / Name : 203 / 11KV SHINDEWADI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.286	1.0288	1.2717	.3944
2		1.286	1.166	1.2717	.3944
3		1.3717		1.2574	.3944
4		1.5089		1.3413	.4115
5		1.6289		1.5432	.4287
6		1.8861		1.8861	.4458
7		1.9204		2.2131	.4801
8		2.2805		2.572	.463
9		2.2634		2.431	.3772
10		.2401		2.4006	.3429
11		.2401		.2229	2.3148
12		.2401			2.7435
13		.1715			2.8292
14		.1715	1.5432	.2058	2.8292
15		.1715	.1783	.2915	2.1434
16				.2229	2.9492
17			.2201	.2572	2.8292
18		.4287	.3018	.3258	2.572
19		.4287	.5487	.4973	.5144
20		.4287	.4973	.4458	.503
21		.4287	.4287	.4115	.463
22	.3772	.4287	.3856	.4115	.3944
23	.3772	.4287	.3521	.3944	.3688
24		1.286	1.0288	1.0402	.3944
Max	**.3772**	**2.2805**	**1.5432**	**2.572**	**2.9492**
Min	**.3772**	**.1715**	**.1783**	**.2058**	**.3429**
Avg	**.3772**	**.9330**	**.6400**	**1.0416**	**1.1659**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
NATEPUTE[103] BU 6360
Substation No/ Name :- 274036 / 33/11 KV DAHIGAON SUBSTATION
Feeder No / Name : 204 / 11KV SHERIWADI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4115	.4458	.3944	.7888
2		.4115	.4458	.3944	.8402
3		.3944	.4458	.3856	.8573
4		.3944	.4458	.3567	.9431
5		.4287	.4458	.4287	1.0288
6		.4287	.5144	.4694	1.2003
7		.4458	.5144	.4694	1.286
8		.3772	.4458	.4458	1.5432
9		.3429	.3601	.3601	1.166
10		.2915	.3018	.3601	.3086
11		1.7147	1.4251	1.4918	.1715
12		1.7661	1.5592	1.6289	.1715
13		1.7147	1.5592		.1715
14		1.7147	1.5089	1.0631	.1715
15		1.6461	1.3375	1.4575	.1715
16		1.5432		1.4575	.2058
17		1.3032	1.1888		.2229
18		.463	1.2574	1.2346	.3429
19		.463	.4607	.463	.5144
20		.5658	.4973	.4458	.503
21		.5658	.463	.4115	.4458
22	.3944	.5658	.4024	.3601	.3772
23	.4287	.5658	.3944	.3086	.3688
24		.4115	.5144	.3418	.7888
Max	**.4287**	**1.7661**	**1.5592**	**1.6289**	**1.5432**
Min	**.3944**	**.2915**	**.3018**	**.3086**	**.1715**
Avg	**.4116**	**.7888**	**.7363**	**.6695**	**.6079**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
NATEPUTE[103] BU 6360
Substation No/ Name :- 274036 / 33/11 KV DAHIGAON SUBSTATION
Feeder No / Name : 205 / 11KV DAHIGAON GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9335	.8573	.8145	.7468
2		.9335	.8573	.8145	.7468
3		.9335	.8573	.8059	.7468
4		.9335	.8573	.8954	.9335
5		1.0269	.8573	.9955	.9335
6		1.2136	1.2003	1.1517	1.0269
7		1.1203	1.2003	1.1393	1.1203
8		.9335		.8916	.9335
9		.7468	.8573	.7442	.6535
10		.6001	.8145	.6535	.8402
11		.5144	.6859	.5601	.5731
12		.5144	.5365	.5601	.4287
13		.5144	.0518		.4287
14		.5144	.4887		.3045
15		.3429	.4287	.5601	.4287
16		.5144	.4477	.5601	.4287
17		.5144	.5144	.7468	.4477
18		.6859	.6268	.7468	.8954
19		1.0288	.9221	1.0269	1.1145
20		1.2003	1.086	.9335	1.086
21		1.0288	.8573	.9335	.9955
22	1.0269	1.0288	.8954	.8402	.8954
23	.9335	1.0288	.8417	.8962	.8954
24		.9335	.8573	.8145	.7468
Max	**1.0269**	**1.2136**	**1.2003**	**1.1517**	**1.1203**
Min	**.9335**	**.3429**	**.0518**	**.5601**	**.3045**
Avg	**.9802**	**.8225**	**.7652**	**.8220**	**.7646**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
NATEPUTE[103] BU 6360
Substation No/ Name :- 274036 / 33/11 KV DAHIGAON SUBSTATION
Feeder No / Name : 206 / 11KV EXPRESS SHIVPRASAD NON SHEDDABLE EXPRESS HV FEEDERS MILK Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.112	.1543	.1006	.112
2		.112	.1372	.1006	.112
3		.112	.1372	.0892	.112
4		.112	.1372	.0892	.112
5		.112	.1372	.1006	.112
6		.1307	.1372	.1174	.1307
7		.1494	.1372	.1006	.1494
8		.1494	.1029	.12	.1307
9		.1494	.1372	.104	.1307
10		.1372	.2058	.1307	.168
11		.1886	.2058	.168	.1715
12		.1886	.2229	.1494	.1715
13		.1029	.1341		.1715
14		.1029	.132	.112	.1372
15		.1029	.1189	.112	
16		.1029	.0892	.112	.12
17		.12	.104	.1307	.12
18		.12	.1029	.1307	.1029
19		.1543	.104	.0934	.12
20		.1543	.1715	.1307	.1509
21		.1543	.1715	.1494	.1677
22	.1307	.1543	.104	.1307	.1341
23	.1307	.1543	.104	.112	.1341
24		.112	.1543	.104	.112
Max	**.1307**	**.1886**	**.2229**	**.168**	**.1715**
Min	**.1307**	**.1029**	**.0892**	**.0892**	**.1029**
Avg	**.1307**	**.1329**	**.1393**	**.1169**	**.1340**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
NATEPUTE[103] BU 6360
Substation No/ Name :- 274036 / 33/11 KV DAHIGAON SUBSTATION
Feeder No / Name : 207 / 11 KV PIRALE AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2058	.2058	.2058	.3601
2		.2058	.2058	.2058	.3601
3		.2229	.2058	.2058	.5144
4		.2229	.2058	.218	.5144
5		.2229	.2058	.2614	.6173
6		.2572	.2401	.2572	.6516
7		.2915	.2743	.2515	.7716
8		.2572	.2058	.2058	1.046
9		.2229	.2058	.1677	1.0974
10		.1715	.1715	.1715	.1543
11		1.0288	.9431	.8745	.1029
12		1.0288	.9221	1.1145	.1029
13		1.0288	.8886		.1029
14		1.0288		.583	.0857
15		1.046	.8573	.9602	
16		1.0288	.8471	.8745	.12
17		.8745	.8573	.6859	.1372
18		.7888	.7459	.6687	.1886
19		.2229		.2401	.2572
20		.2401	.2401	.2058	.2572
21		.2401	.2229	.2058	.2347
22	.2229	.2401	.218	.2058	.2229
23	.2058	.1886	.2012	.2229	.2012
24		.2058	.2058	.2012	.3601
Max	**.2229**	**1.046**	**.9431**	**1.1145**	**1.0974**
Min	**.2058**	**.1715**	**.1715**	**.1677**	**.0857**
Avg	**.2144**	**.4780**	**.4216**	**.3997**	**.3679**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
NATEPUTE[103] BU 6360
Substation No/ Name :- 274039 / 33/11 KV NATEPUTE SUB-STATION
Feeder No / Name : 201 / 11KV DHARMPURI AG Feeder KV- 11 / OUTGOING SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.583	.583	1.5432
2	.6859	.6173	.6001	1.6975
3	.6859	.6516	.6001	1.8519
4	.6859	.6859	.6859	2.0062
5	.7716	.7202	.6859	2.1605
6	.8059	.7545	.7716	2.3148
7	.7716		.6859	2.4691
8	.7545	.6516	.6687	2.4348
9	.6687	.5144	.5144	
10	.4115	.4458	.463	
11	2.3663	2.332	2.2977	
12	2.7778	2.6235	2.7778	
13	2.4863	2.3148	2.6063	.3772
14	2.8635	2.6749	2.7606	.4115
15	2.915	2.6063	2.572	.4115
16	2.8292	2.2805		
17	2.5034	2.4348		
18	2.332	2.0919	1.7833	.703
19	.7202	.7202	.7202	.7716
20	.6859	.6859	.6859	.8059
21	.6516	.6001	.6516	.6859
22	.6173	.583	.6173	.6859
23	.583	.583	.583	.6516
24	.6001	.5487	.583	1.406
Max	**2.915**	**2.6749**	**2.7778**	**2.4691**
Min	**.4115**	**.4458**	**.463**	**.3772**
Avg	**1.3239**	**1.2480**	**1.1317**	**1.2993**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
NATEPUTE[103] **BU 6360**
Substation No/ Name :- 274039 / 33/11 KV NATEPUTE SUB-STATION
Feeder No / Name : 202 / 11KV NATEPUTE VG **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.6001	.5658	.583
2	.6859	.6859	.6687	.6859
3	.6859	.7716	.7716	.7888
4	.6859	.8573	.8573	.8916
5	.8573	.9602	.8573	.9945
6	1.0802	1.0631	1.0802	1.1145
7	1.0802	1.166	1.1488	1.2346
8	.7316	1.1317	1.2346	1.166
9	1.1831	1.0974	1.046	1.0974
10	1.0631	.9945	.9602	1.0117
11	.9602	.9945	.8573	.9774
12		.8745	.7888	1.0974
13	.8745	.823	.7545	.8402
14	.823	.7888	.7202	.8059
15	.8745	.8402	.703	.8402
16	.8745	.8573	.7888	.9088
17	.9088	.8573	.7716	.8916
18	1.0288	.9259	.9259	.9945
19	1.1317	1.166	1.1317	1.0288
20	.9945	.8573	.9774	1.046
21	.8573	.8402	.823	.823
22	.7202	.6001	.6687	.823
23	.583	.583	.5144	.6001
24	.5658	.5144	1.5947	.4801
Max	**1.1831**	**1.166**	**1.5947**	**1.2346**
Min	**.5658**	**.5144**	**.5144**	**.4801**
Avg	**.8616**	**.8688**	**.8838**	**.9052**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
NATEPUTE[103] BU 6360
Substation No/ Name :- 274039 / 33/11 KV NATEPUTE SUB-STATION
Feeder No / Name : 203 / 11KV MANDAVE AG Feeder KV- 11 / OUTGOING
SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.3944	.3429	.823
2	.3601	.4115	.3429	.8916
3	.4287	.4287	.3429	.9602
4	.4458	.4458	.3772	1.0288
5	.4801	.4801	.4287	1.0974
6	.4973	.5144	.4801	1.1831
7	.4973	.5487	.4973	1.2689
8	.4973	.463	.4973	1.406
9	.4287	.3772	.4458	1.5432
10	.3086	.3086	.3258	.3429
11	1.3546	1.2003	1.3889	.2572
12	1.406	1.5089	1.4746	.1715
13	1.5947	1.5432	1.3546	.1886
14	1.3889	1.4575	1.3375	.1886
15	1.4918	1.3203	1.0117	.1886
16	1.3032	1.3203	1.2689	.1886
17	1.3546	1.3375	1.2346	.2229
18	1.3032	1.3032	1.2003	.3086
19	.4115	.463	.4458	.4801
20	.3772	.4115	.4287	.4973
21	.3944	.4287	.4115	.4801
22	.3601	.3772	.3944	.4287
23	.3772	.3601	.3772	.3944
24	.3601	.3772	.3429	.7545
Max	**1.5947**	**1.5432**	**1.4746**	**1.5432**
Min	**.3086**	**.3086**	**.3258**	**.1715**
Avg	**.7409**	**.7409**	**.6980**	**.6373**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
NATEPUTE[103] BU 6360
Substation No/ Name :- 274039 / 33/11 KV NATEPUTE SUB-STATION
Feeder No / Name : 204 / 11KV LONAND AG Feeder KV- 11 / OUTGOING
SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	1.406	1.2003	1.3717
2	1.5432	1.5089	1.3717	1.5261
3	1.9033	1.6118	1.6289	1.6804
4	1.9033	1.7318	1.7318	1.8347
5	1.9204	1.8519	1.8004	1.989
6	1.9204	1.9719	1.8347	2.1434
7	2.4006	2.0919	2.1948	2.2977
8	2.4863	1.9547	2.3834	2.2634
9	2.2805	1.8176	2.2119	2.2291
10	.4458	.4458	.463	.4801
11	2.0576	2.1262	2.6063	1.6804
12	2.5892	2.452	2.8121	.2915
13	2.4863		2.5892	2.0062
14	2.3491	.7716	2.4177	1.9204
15	2.332		2.452	2.0233
16	2.3663	1.6632	2.2119	1.8176
17	2.3491	2.7435	2.3148	2.0576
18	2.0233	2.4691	1.9204	1.9547
19	.823	.9088	.7888	.8573
20	.8059	.8573	.7545	.8573
21	.7888	.8573	.7373	.823
22	.7716	.823	.7202	.6859
23	.7545	.823	.6859	.8059
24	1.406	1.3032	1.2003	1.2346
Max	**2.5892**	**2.7435**	**2.8121**	**2.2977**
Min	**.4458**	**.4458**	**.463**	**.2915**
Avg	**1.7604**	**1.5541**	**1.7097**	**1.5346**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
NATEPUTE[103] BU 6360
Substation No/ Name :- 274039 / 33/11 KV NATEPUTE SUB-STATION
Feeder No / Name : 205 / 11KV PHADATARI GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2572	.2572	.2572
2	.2572	.2743	.2572	.2743
3	.2572	.2915		.2915
4	.3086	.3086	.4287	.3086
5	.4115	.3429	.4287	.3429
6	.4458	.3772	.463	.3772
7	.3429	.4115	.3429	.4115
8	.2743	.3258	.3429	.3258
9	.2572	.2401	.2229	.2401
10	.2229	.1715		.1886
11	.1715	.1715	.1886	.1715
12	.1543	.1543	.1715	.1715
13	.1372	.1029	.1029	.1886
14	.12	.1029	.1029	.1372
15	.1372		.0857	.1029
16	.1715	.12		
17	.1715	.1886		
18	.1372	.1886	.2229	.2401
19	.3086	.4115	.3772	.3429
20	.2915	.3429	.3429	.3601
21	.2743	.2915	.3086	.3429
22	.2572	.2743	.2743	.3086
23	.2401	.2743	.2401	.2743
24	.2572	.2401	.2572	.2401
Max	**.4458**	**.4115**	**.463**	**.4115**
Min	**.12**	**.1029**	**.0857**	**.1029**
Avg	**.2443**	**.2550**	**.2709**	**.2681**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
NATEPUTE[103] BU 6360
Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN
Feeder No / Name : 201 / 11KV WATER SUPPLY SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.286	1.2717	1.3565	.3561
2		1.2717	1.286	1.3717	.362
3		1.3717	1.448	1.3717	.3391
4		1.3717	1.5604	1.4575	.3391
5		1.3565	1.5261	1.5432	.39
6		1.4413	1.6108	1.5432	.373
7		1.8004	2.0576	2.1195	.373
8		2.0805	2.4587	2.3148	.3391
9		2.2043	2.5139	2.1795	.3018
10		.2683	.2774	.2683	.2515
11		.2374	.2429	.2515	2.5911
12		.1943	.2347	.2374	2.6825
13		.1677	.2267		2.9874
14		.1619	.218	.1524	2.5149
15			.1943	.1677	2.3472
16		.1619	.1677	.1677	2.3739
17		.3277	.3391	.2543	2.2891
18		.3605	.3239	.3944	2.1628
19		.407	.4239	.4239	.4096
20		.407	.4096	.4191	.407
21		.407	.3932	.4096	.407
22	.3944	.4287	.407	.4239	.4239
23	.3944	.4239	.4239	.4115	.4115
24		1.2003	1.1869	1.286	.3772
Max	**.3944**	**2.2043**	**2.5139**	**2.3148**	**2.9874**
Min	**.3944**	**.1619**	**.1677**	**.1524**	**.2515**
Avg	**.3944**	**.8408**	**.8834**	**.8924**	**1.0754**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
NATEPUTE[103] BU 6360
Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN
Feeder No / Name : 203 / 11KV PALASMANDAL SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3601	.3772	.3584	1.8099
2		.3353	.3391	.3086	1.7147
3		.3353	.3222	.3086	1.6289
4		.3429	.3258	.3222	1.6108
5		.4108	.3429	.3601	1.6956
6		.373	.3561	.3772	1.8861
7		.3429	.3601	.3258	2.4863
8		.3052	.3222	.3222	2.7978
9		.3401	.2947	.4024	2.934
10		.3077	.2947	.3353	.3018
11		2.8826	2.713	2.8502	.2683
12			2.753	3.0178	.2267
13		3.0178	3.0178		.2347
14		3.0283	2.915	2.6825	.2105
15		3.0769	2.934	2.753	.2012
16		3.2388	2.672	3.0178	.2515
17		3.0013	2.7664	3.103	.2543
18		2.6707	2.7362	2.7808	.2458
19		.4096	.5935	.5087	.5087
20		.4239	.5087	.4239	.5087
21		.4748	.4239	.4588	.5087
22	.3772	.5087	.4287	.4748	.4748
23	.4287	.4973	.3391	.4748	.4854
24		.4115	.4854	.3429	1.7147
Max	**.4287**	**3.2388**	**3.0178**	**3.103**	**2.934**
Min	**.3772**	**.3052**	**.2947**	**.3086**	**.2012**
Avg	**.4030**	**1.1781**	**1.1926**	**1.1439**	**1.0400**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
NATEPUTE[103] BU 6360
Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN
Feeder No / Name : 204 / 11KV FONDSHIRAS GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6443	.5765	.4973	.5658
2		.6516	.6274	.5087	.6443
3		.6687	.7545	.5144	.6952
4		.7969	.9149	.6274	.7969
5		.8648	.9015	.7122	.9259
6		.9156	.9602	.7888	1.0117
7		.8817	.8817	.7122	.8745
8		.823	.8139	.5765	.7377
9		.6316	.6415		.6783
10		.57	.6068	.6104	.5344
11		.503	.5533	.5365	.4696
12		.3887	.503	.4534	.3725
13		.3887	.3239	.4191	.373
14		.3725	.3018	.4191	.3239
15		.3688	.3353	.3725	.3077
16		.3563	.3401	.3563	.3563
17		.426	.4191	.4239	.3932
18		.6554	.5087	.6783	.5735
19		.8573	.6952	.8478	.9496
20		.6952	.5571	.788	.7122
21		.7291	.6274	.6882	.6783
22	.6104	.6613	.6104	.6613	.6613
23	.5935	.6878	.4239	.5765	.6104
24		.583	.5765	.4748	.5596
Max	**.6104**	**.9156**	**.9602**	**.8478**	**1.0117**
Min	**.5935**	**.3563**	**.3018**	**.3563**	**.3077**
Avg	**.6020**	**.6301**	**.6023**	**.5758**	**.6169**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
NATEPUTE[103] BU 6360
Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN
Feeder No / Name : 205 / 11KV TAMSHIDWADI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4409	.4239	.4748	1.0682
2		.4359	.4191	.503	1.0974
3		.4801	.4748	.6001	1.166
4		.4973	.4917	.6104	1.17
5		.5087	.4917	.6104	1.2971
6		.543	.5487	.5765	1.3546
7		.4917	.5144	.5426	1.7833
8		.39	.4287	.4748	2.1195
9		.3077	.3294	.3521	2.1795
10		.2683	.2774	.3018	.2753
11		2.2672	2.2131	2.3472	.2267
12		2.3967	2.431	2.5149	.1619
13		2.5149	2.5149		.1781
14		2.5149	2.5316	2.0119	.1943
15		2.2672	2.5149	2.0119	.2012
16		2.2672	2.5149	2.1795	.2347
17		2.2611	2.7978	2.1704	.2374
18		2.0481	1.9826	2.0517	.3441
19		.4096	.4578	.4578	.4409
20		.407	.3932	.4578	.4409
21		.39	.407	.4096	.4409
22	.3772	.407	.407	.4409	.4409
23	.4287	.4115	.4458	.4409	.4409
24		.4287	.4115	.4578	1.0682
Max	**.4287**	**2.5149**	**2.7978**	**2.5149**	**2.1795**
Min	**.3772**	**.2683**	**.2774**	**.3018**	**.1619**
Avg	**.4030**	**1.0564**	**1.1010**	**.9999**	**.7734**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
NATEPUTE[103] BU 6360
Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN
Feeder No / Name : 206 / 11KV KADAMWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.543	1.3889	1.3735	.5316
2		1.8111	1.406	1.3889	.5487
3		1.8823	1.5261	1.4918	.5548
4		1.8991	1.6118	1.595	.6154
5		2.0008	1.8861	1.5939	.6485
6		2.0748	1.8991	1.8143	.6878
7		2.5652	2.4756	2.3908	.5087
8		2.8826	2.9165	2.999	.4801
9		2.7831	3.0687	2.4453	.3856
10		.3239	.3121	.3185	.3077
11		.2591	.2429	.285	3.0769
12		.2347	.2429	.2591	3.2065
13		.2267	.2347		3.2388
14		.218	.2267	.218	3.3036
15		.218	.2347	.218	3.4537
16		.2105	.2429	.218	3.3198
17		.2883		.2204	3.0864
18		.3149	.3113	.3391	2.7808
19		.4973	.4915	.4917	.5316
20		.4578	.4752	.5365	.4917
21		.4917	.4917	.4915	.5426
22	.6001	.5596	.4748	.5596	.5935
23	.6001	.5765	.5765	.5935	.6241
24		1.4232	1.3056	1.3226	.5426
Max	**.6001**	**2.8826**	**3.0687**	**2.999**	**3.4537**
Min	**.6001**	**.2105**	**.2267**	**.218**	**.3077**
Avg	**.6001**	**1.0726**	**1.0453**	**1.0071**	**1.4192**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
NATEPUTE[103] BU 6360
Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN
Feeder No / Name : 207 / 11KV CHAVANWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	20-DEC-17
HR	Load (MW)
20	.5426
21	.4915
Max	.5426
Min	.4915
Avg	.5171

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
NATEPUTE[103] BU 6360
Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN
Feeder No / Name : 208 / 11 KV ISHWAR PIND AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6203	.4694	.5087	.168
2		.6687	.4917	.5256	.1543
3		.6687	.4917	.5256	.1715
4		.6952	.5596	.5765	.1696
5		.7716	.6344	.6613	.1865
6		.8059	.6613	.6783	.2058
7		.9835	.9945	.8309	.2058
8		1.1022	1.1022	1.0343	.1696
9		1.0688	1.0749	1.0202	.1509
10		.1134	.1214	.0972	.1006
11		.1006	.0671	.081	1.2955
12		.0648	.0671	.0972	1.3927
13		.0648	.0648		1.3927
14		.0671	.0671	.0648	1.4089
15		.0648	.081	.0486	1.4089
16		.081	.0972	.0503	1.4089
17		.0983	.0671	.0686	1.3565
18		.1311	.0983	.1357	1.2616
19		.1802	.1886	.1865	.1966
20		.1696	.1638	.1844	.1715
21		.1696	.1696	.1311	.1696
22	.1715	.1865	.1509	.1543	.1696
23	.1715	.181	.1696	.1629	.1696
24		.5765	.4668	.4578	.1543
Max	**.1715**	**1.1022**	**1.1022**	**1.0343**	**1.4089**
Min	**.1715**	**.0648**	**.0648**	**.0486**	**.1006**
Avg	**.1715**	**.4014**	**.3550**	**.3601**	**.5683**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
NATEPUTE[103] BU 6360
Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN
Feeder No / Name : 209 / 11 KV MARKADWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1509	.1357	.1867	.373
2		.1543	.1494	.1526	.3921
3		.1357	.1357	.1357	.3561
4		.1494	.1509	.1357	.3944
5		.1357	.1696	.1543	.4344
6		.1357	.1696	.1696	.4525
7		.1017	.1448	.1372	.5973
8		.1017	.1187	.1029	.7122
9		.0648	.1214	.0972	.6964
10		.0972	.1214	.1296	.0838
11		.7773	.5506	.6874	.0648
12		.8097	.6478	.7287	.0648
13		.8383	.9496	.7287	.0648
14		.8383		.7042	.0648
15		.8048	.6478	.7712	.0678
16		.7449	.6539	.8139	.0648
17		.6882	.6316	.7461	.0678
18		.6274	.5571	.8139	.0655
19		.1311	.1187	.1187	.1526
20		.1311	.1187	.1174	.1696
21		.1526	.1526	.1311	.1865
22	.1543	.1943	.1526	.1715	.2204
23	.1543	.1753	.1715	.1543	.1734
24		.1543	.1526	.1696	.3772
Max	**.1543**	**.8383**	**.9496**	**.8139**	**.7122**
Min	**.1543**	**.0648**	**.1187**	**.0972**	**.0648**
Avg	**.1543**	**.3456**	**.3010**	**.3441**	**.2624**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
NATEPUTE[103] BU 6360
Substation No/ Name :- 274130 / 33/11 KV DHARMPURI
Feeder No / Name : 201 / 11KV KOTHALE SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)
1	1.0974	.9774
2	1.166	1.046
3	1.2003	1.0802
4	1.2003	1.1488
5	1.2346	1.1831
6	1.2689	1.2174
7	1.3032	1.2689
8	1.5089	1.4575
9	1.5947	1.5604
10	.2401	.2743
11	.1715	.1715
12	.1715	
13	.1715	
14	.1543	
15	.1372	
16	.1715	
17	.2229	
18	.2572	
19	.3258	.3258
20	.3086	.3086
21	.2915	.2915
22	.2915	.2743
23	.2743	.2572
24	1.0288	.9088
Max	**1.5947**	**1.5604**
Min	**.1372**	**.1715**
Avg	**.6580**	**.8089**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
NATEPUTE[103] BU 6360
Substation No/ Name :- 274130 / 33/11 KV DHARMPURI
Feeder No / Name : 202 / 11KV GURSALE SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)
1	.2229	.2229
2	.2229	.2229
3	.2401	.2401
4	.2401	.2572
5	.2401	.2743
6	.2401	.2915
7	.2743	.3086
8	.2058	.2572
9	.1886	.2058
10	.1715	.1886
11	.9088	1.166
12	1.046	1.1831
13		1.2003
14	1.0288	1.2346
15	.9259	1.2517
16	.8745	1.2517
17		1.2174
18	.823	1.1831
19	.2229	.2401
20	.2229	.2229
21	.2229	.2229
22	.2058	.2058
23	.2058	.1886
24	.2229	
Max	**1.046**	**1.2517**
Min	**.1715**	**.1886**
Avg	**.4162**	**.5755**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
NATEPUTE[103] BU 6360
Substation No/ Name :- 274130 / 33/11 KV DHARMPURI
Feeder No / Name : 203 / 11KV SHINDEWADI FEEDER
Feeder KV- 11 / OUTGOING

DATE	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)
1	.0069	.0069
2	.0069	.0069
3	.0069	.0069
4	.0069	.0069
5	.0069	.0069
6	.0069	.0069
7	.0069	.0069
8	.0069	.0069
9	.0069	.0069
10	.0069	.0069
11	.0069	.0069
12	.0069	.0069
13	.0069	.0069
14	.0069	.0069
15	.0069	.0069
16	.0069	.0069
17	.0069	.0069
18	.0069	.0069
19	.0069	.0069
20	.0069	.0069
21	.0069	.0069
22	.0069	.0069
23	.0069	.0069
24	.0069	.0069
Max	**.0069**	**.0069**
Min	**.0069**	**.0069**
Avg	**.0069**	**.0069**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
NATEPUTE[103] **BU 6360**
Substation No/ Name :- 274130 / 33/11 KV DHARMPURI
Feeder No / Name : 204 / 11KV DHARMPURI GAOTHAN **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)
1	.4801	.4973
2	.5144	.4801
3	.5144	.4801
4	.5487	.5658
5	.583	.6344
6	.6687	.7716
7	.7545	.8573
8		.6859
9	.6344	.5316
10	.4115	.4458
11	.2743	.3429
12	.2743	.3258
13		.3086
14		.2915
15	.3944	.2572
16	.4287	.3601
17	.463	.463
18	.4973	.5487
19	.3258	.7716
20	.3086	.7202
21	.2915	.6687
22	.2915	.6173
23	.2743	.5144
24	.4801	.4973
Max	**.7545**	**.8573**
Min	**.2743**	**.2572**
Avg	**.4483**	**.5266**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
NATEPUTE[103] BU 6360
Substation No/ Name :- 274130 / 33/11 KV DHARMPURI
Feeder No / Name : 205 / 11 KV MASUGADE SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)
1	.6859	.8402
2	.7202	.8916
3	.7888	.9259
4	.823	.9774
5	.8573	.9945
6	.8916	1.046
7	.9259	1.0802
8	1.1145	1.2689
9	1.2003	1.5089
10	.1886	.2058
11	.1372	.1886
12		.1886
13		.1886
14	.1372	.1715
15	.1372	.1715
16	.1543	.2058
17	.1715	.2229
18	.2058	.2572
19	.3258	.2572
20	.3086	.3086
21	.2915	.2915
22	.2572	.2401
23	.2058	.2229
24	.6173	.7716
Max	**1.2003**	**1.5089**
Min	**.1372**	**.1715**
Avg	**.5066**	**.5594**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
NATEPUTE[103] BU 6360
Substation No/ Name :- 274130 / 33/11 KV DHARMPURI
Feeder No / Name : 206 / 11 KV KARUNDE AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)
1	.3086	.3429
2	.2915	.3601
3	.2915	.3944
4	.2743	.4287
5	.2743	.4458
6		.4458
7	.4287	.463
8	.3601	.3258
9	.2743	.2743
10	.1886	.2743
11	1.1145	1.1317
12	1.3032	1.1831
13	1.5261	1.2174
14		1.2517
15	1.0802	1.2689
16	.9774	1.2517
17	.8916	1.2174
18	.7888	1.1831
19	.3429	.3601
20	.3429	.3429
21	.3258	.3258
22	.3086	.3086
23	.3086	.2915
24	.3086	.3258
Max	**1.5261**	**1.2689**
Min	**.1886**	**.2743**
Avg	**.5596**	**.6423**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
AKLUJ O AND M DIVISION[537]
NATEPUTE[103] BU 6360
Substation No/ Name :- 274130 / 33/11 KV DHARMPURI
Feeder No / Name : 207 / 11 KV MOROCHI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)
1	.2229	.2401
2	.2401	.2401
3	.2401	.2401
4	.2572	.2401
5	.2743	.2743
6	.2743	.2915
7	.2743	.3086
8	.2572	.2743
9	.1886	.2401
10	.1543	.2058
11	.8059	.9774
12	.9088	.9774
13	1.0288	.9602
14	1.0117	.9431
15	.9602	.9259
16	.9088	.8916
17	.8573	.8573
18	.7716	.823
19	.2915	.2915
20	.2743	.2743
21	.2572	.2401
22	.2401	.2229
23	.2401	.2058
24	.2229	.2401
Max	**1.0288**	**.9774**
Min	**.1543**	**.2058**
Avg	**.4651**	**.4744**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274001 / 33/11 KV BORGAON S/STN.
Feeder No / Name : 204 / 11KV BORGAON AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.4191	
2				.503	
3				.503	
4				.5868	
5				.6203	
6				.6371	
10			.8718		
17			.0168		
18			.0168		
19			.0168		
20			.0168		
21			.0335		
22			.0335		
23			.0168		
24	.0168	.0168	.0168	.0168	.0168
Max	**.0168**	**.0168**	**.8718**	**.6371**	**.0168**
Min	**.0168**	**.0168**	**.0168**	**.0168**	**.0168**
Avg	**.0168**	**.0168**	**.1155**	**.4694**	**.0168**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274001 / 33/11 KV BORGAON S/STN.
Feeder No / Name : 205 / BABHULGAON Ag FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0168	
2				.0168	
3				.0168	
4				.0168	
5				.0168	
6				.0168	
10			.0168		
11			1.8275		
12			2.0119		
13			2.2634		
14			2.3472		
15			2.2634		
16			2.1628		
17			2.0957		
18			1.6933		
19			.0168		
20			.0168		
21			.0168		
22			.0168		
23			.0168		
24	.0168	.0168	.0168	.0168	.0168
Max	**.0168**	**.0168**	**2.3472**	**.0168**	**.0168**
Min	**.0168**	**.0168**	**.0168**	**.0168**	**.0168**
Avg	**.0168**	**.0168**	**1.1189**	**.0168**	**.0168**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274002 / 33/11 KV CHIKHARDE S/S
Feeder No / Name : 201 / CHIKHARDE FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.406	
2			1.4403	
3			1.4746	
4			1.3717	
5			1.5089	
6			1.7147	
7			1.6461	
8	.6344		1.7147	
9	.4458			
10	.3772		1.9547	
11	1.5261			
12	2.0233			
13	1.9719			
14	1.8004			
15	2.0576			.2229
16	1.989	1.7833		.2229
17		1.7147		
18		1.8176		
19		.6173		
20		.5487		
21		.5144		
22		.4458		
23		.4115		
24			.4287	
Max	**2.0576**	**1.8176**	**1.9547**	**.2229**
Min	**.3772**	**.4115**	**.4287**	**.2229**
Avg	**1.4251**	**.9817**	**1.4660**	**.2229**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274002 / 33/11 KV CHIKHARDE S/S
Feeder No / Name : 202 / NARI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6516	
2			.583	
3			.5487	
4			.6173	
5			.6859	
6			.7373	
7			.8402	
8	2.2119		.7545	
9	2.1605			
10	1.989		.7545	
11	1.5261			
12	1.8004			
13	1.8861			
14	.1543			
15	.1543			1.6118
16	.1543	.3601		2.0233
19		.5144		
20		.6173		
21		.5658		
22		.6859		
23		.6344		
24			.5658	
Max	**2.2119**	**.6859**	**.8402**	**2.0233**
Min	**.1543**	**.3601**	**.5487**	**1.6118**
Avg	**1.3374**	**.5630**	**.6739**	**1.8176**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274002 / 33/11 KV CHIKHARDE S/S
Feeder No / Name : 203 / YELAMB FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4287	
2			.4287	
3			.4287	
4			.4287	
5			.5144	
6			.5144	
7			.5144	
8	1.8861		.5144	
9	1.8861			
10	1.8861		.5144	
11	.4287			
12	.4287			
13	.4287			
14	.4287			
15	.4287			3.4294
16	.4287	.4287		2.7435
17		.5144		
18		.5144		
19		.5144		
20		.5144		
21		.5144		
22		.5144		
23		.5144		
Max	**1.8861**	**.5144**	**.5144**	**3.4294**
Min	**.4287**	**.4287**	**.4287**	**2.7435**
Avg	**.9145**	**.5037**	**.4763**	**3.0865**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] **BU 1392**
Substation No/ Name :- 274002 / 33/11 KV CHIKHARDE S/S
Feeder No / Name : 204 / forest Feeder **FEEDER SEPERATION/PURE AG**
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)
8	.12	
9	.12	
10	.12	
15		.1029
16		.4973
Max	.12	.4973
Min	.12	.1029
Avg	.12	.3001

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274002 / 33/11 KV CHIKHARDE S/S
Feeder No / Name : 205 / Indapur SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.3717	
2			1.4232	
3			1.7147	
4			1.5432	
5			1.5089	
6			.7545	
7			.6173	
8	.6173		.6859	
9	.4973			
10	.3086		.7202	
11	.12			
14	1.8176			
15	2.2462			.12
16	2.332	1.4403		.1372
17		1.5432		
18		1.3032		
19		1.3717		
20		1.3032		
21		1.1831		
22		1.2517		
23		1.2517		
24			1.3717	
Max	**2.332**	**1.5432**	**1.7147**	**.1372**
Min	**.12**	**1.1831**	**.6173**	**.12**
Avg	**1.1341**	**1.3310**	**1.1711**	**.1286**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274002 / 33/11 KV CHIKHARDE S/S
Feeder No / Name : 206 / Sawargaon Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1715	
2			.1715	
3			.1715	
4			.2058	
5			.2401	
6			1.4403	
7			1.4746	
8	.2401		1.3717	
9	.1543			
10	.1372		1.3717	
11	.0857			
12	.0857			
13	.0857			
14	.0857			
15	.0857			.0686
16	.0857	.1715		.0686
17		.2229		
18		.2401		
19		.2743		
20		.2401		
21		.2058		
22		.1715		
23		.1715		
24			.1715	
Max	**.2401**	**.2743**	**1.4746**	**.0686**
Min	**.0857**	**.1715**	**.1715**	**.0686**
Avg	**.1162**	**.2122**	**.6790**	**.0686**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] **BU 1392**
Substation No/ Name :- 274002 / 33/11 KV CHIKHARDE S/S
Feeder No / Name : 207 / MAHAGAON AG **FEEDER SEPERATION/PURE AG**
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.6859
2			.6859
3			.6859
4			.6859
5			.6859
6			.6859
7			.6859
8			.6859
10			.6859
11	.7716		
12	.8916		
13	.9774		
14	.8059		
15	.7716		
16	.6859	.6859	
17		.6859	
18		.6859	
Max	**.9774**	**.6859**	**.6859**
Min	**.6859**	**.6859**	**.6859**
Avg	**.8173**	**.6859**	**.6859**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274004 / 33/11 KV PANGAON S/S
Feeder No / Name : 201 / 11 KV PANGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0762	.0762	.3185	.503
2				.0762	.0762	.4024	.5868
3				.0762	.0762	.4715	.7545
4				.0762	.0762	.503	.8383
5				.0762	.0762	.6706	1.0059
6				.0762	.0762	1.0059	1.2574
7				.0762	.0762	1.0898	1.8442
8				.0762	.0762	1.3413	2.1795
9				.0762	.0762	1.6766	2.0576
10			.0762	.0762	.0943	1.5927	1.9052
11			1.2955	1.2955	1.5432		
12			1.829		2.0454		
13			2.0576	1.6766	2.3472		
14			2.0576	1.9052	2.0119		
15			1.9052	1.829	2.2634		
16			1.9052	1.9814	2.2634		
17			1.829	1.9814	2.2634	.0838	.0762
18			1.5242	1.6766	1.8442	.0838	.0762
19			.0762	.0762	.0943	.0838	.0762
20			.0857	.0762	.0943	.0838	.0762
21	.0943		.0762	.0762	.0943	.0838	.0762
22			.0762	.0762	.0943	.0838	.0762
23			.0762	.0762	.0943	.0838	.0762
24		.0943		.0762	.0762	.0943	.0838
Max	**.0943**	**.0943**	**2.0576**	**1.9814**	**2.3472**	**1.6766**	**2.1795**
Min	**.0943**	**.0943**	**.0762**	**.0762**	**.0762**	**.0838**	**.0762**
Avg	**.0943**	**.0943**	**1.0621**	**.5898**	**.7462**	**.5418**	**.7528**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274004 / 33/11 KV PANGAON S/S
Feeder No / Name : 202 / 11 KV SAKAT AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0762	.0762	.1715	.1677
2			.0762	.0762	.2347	.1677
3			.0762	.0762	.2347	.1677
4			.0762	.0762	.2683	.1677
5			.0762	.0762	.3018	.1677
6			.0762	.0762	.3353	.1677
7			.0762	.0762	.4191	.1677
8			.0762	.0762	.8383	.6706
9			.0762	.0762	.503	.6097
10		.0762	.0762	.0943	.3353	.4572
11		.1524	.381	.4191		
12		.2286	.5335	.7209		
13	.7545	.6097	.6097	.8383		
14		.7621	.6097	.7545		
15		.7621	.6859	.8048		
16		.7621	.6859	.8383		
17		.7621	.6859	.8048	.0838	.0762
18		.6097	.4572	.3353	.0838	.0762
19		.0762	.0762	.0943	.0838	.0762
20		.0762	.0762	.0943	.0838	.0762
21		.0762	.0762	.0943	.0838	.0762
22		.0762	.0762	.0943	.0838	.0762
23		.0762	.0762	.0943	.0838	.0762
24			.0762	.0762	.0943	.0838
Max	**.7545**	**.7621**	**.6859**	**.8383**	**.8383**	**.6706**
Min	**.7545**	**.0762**	**.0762**	**.0762**	**.0838**	**.0762**
Avg	**.7545**	**.3647**	**.2445**	**.2852**	**.2402**	**.1960**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274004 / 33/11 KV PANGAON S/S
Feeder No / Name : 203 / 11 KV KALEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7621	.9145	.0943	.0838
2		.7621	.9145	.0943	.0838
3		.7621	.9145	.0943	.0838
4		.8383	.9145	.0943	.0838
5		1.0669	.3353	.0943	.0838
6		1.3717	1.3717	.0943	.0838
7		2.4387	1.829	.0943	.0838
8		2.6673	1.9052	.0943	.0838
9		1.6766	1.829	.0838	.0762
10	1.829	1.5242	1.8442	.0838	.0762
11				1.6766	
12				2.1795	
13				2.0119	1.9814
14				2.431	2.1338
15				2.431	2.3624
16				2.5149	2.3624
17	.0762	.0762	.0943	2.1795	2.1338
18	.0762	.0762	.0943	1.9281	1.829
19	.0762	.0762	.0943	.0838	.0762
20	.0762	.0762	.0943	.0838	.0762
21	.0762	.0762	.0943	.0838	.0762
22	.0762	.0762	.0943	.0838	.0762
23	.0762	.0762	.0943	.0838	.0762
24		.0762	.0762	.0943	.0838
Max	**1.829**	**2.6673**	**1.9052**	**2.5149**	**2.3624**
Min	**.0762**	**.0762**	**.0762**	**.0838**	**.0762**
Avg	**.2953**	**.8044**	**.7505**	**.7828**	**.6405**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274004 / 33/11 KV PANGAON S/S
Feeder No / Name : 204 / 11 KV OLD GAONTHAN FEEDER GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1715	.1715	.1886	.1886
2			.1715	.1715	.1886	.1886
3			.1715	.1715	.2075	.3395
4			.2572	.2572	.2263	.3772
5			.3429	.4287	.2829	.4715
6			.6001	.6001	.6602	.5658
7			.6001	.6516	.6602	.6602
8			.6859	.6859	.679	.6036
9			.6001	.6001	.5658	.4287
10		.4287	.5144	.4715	.4715	.4287
11		.3429	.2572	.2829	.2263	.3429
12		.1715	.1715	.2829	.1886	.2572
13		.1715	.1715	.1886	.1886	.1715
14		.1715	.1715	.1886	.1886	.1715
15		.1715	.1715	.1886	.1886	.1715
16		.1715	.1715	.2263	.1886	.2058
17		.2572	.1715	.2263	.1886	.2572
18		.4287	.4287	.4715	.3772	.5144
19		.6001	.6001	.6602	.6602	.6516
20		.4287	.5144	.5658	.5658	.5144
21	.3772	.3429	.3429	.4715	.3772	.3429
22		.2572	.2572	.3772	.2829	.2572
23		.1715	.1715	.2452	.1886	.1715
24			.1715	.1715	.2263	.1886
Max	**.3772**	**.6001**	**.6859**	**.6859**	**.679**	**.6602**
Min	**.3772**	**.1715**	**.1715**	**.1715**	**.1886**	**.1715**
Avg	**.3772**	**.2940**	**.3287**	**.3649**	**.3403**	**.3529**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274004 / 33/11 KV PANGAON S/S
Feeder No / Name : 205 / 11 KV NEW PANGAON GAOTHAN SEPARATED GAOTHAN FEEDERS
FEED Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.1715	.1886	.1886
2		.1715	.1715	.1886	.1886
3		.1715	.1715	.1886	.1886
4		.2229	.2572	.2641	.3395
5		.2572	.3429	.3772	.3772
8		.3944	.4115	.4527	.3772
9		.3429	.3429	.4527	.3429
10	.3086	.2572	.2829	.3395	.2572
11	.2572	.2229	.2829	.2829	.2572
12	.1715	.2058	.2829	.1886	.2058
13	.1715	.1715	.2263	.1886	.1715
14	.1715	.1715	.1886	.1886	.1715
15	.1715	.1715	.2263	.1886	.1715
16	.1715	.1715	.2263	.1886	.1715
17	.2229	.1715	.2641	.1886	.1715
18	.2572	.2572	.2829	.2829	.2572
19	.3944	.3429	.3395	.3772	.3429
20	.3429		.3772	.9431	.3429
21	.2572	.2572	.415	.3395	.2572
22	.2572	.2058	.2829	.2829	.2058
23	.1715	.1715	.2641	.1886	.1715
24		.1715	.1715	.2263	.1886
Max	**.3944**	**.3944**	**.415**	**.9431**	**.3772**
Min	**.1715**	**.1715**	**.1715**	**.1886**	**.1715**
Avg	**.2376**	**.2229**	**.2719**	**.2958**	**.2430**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] **BU 1392**
Substation No/ Name :- 274005 / 33/11 KV PANGARI S/S
Feeder No / Name : 206 / Shirale Ag Fdr **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	15-DEC-17	16-DEC-17	17-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1		1.7016	
2		1.7847	
3		1.8251	
4		2.0557	
5		2.177	
6		2.3133	
7		2.7349	
8	2.9828	2.8937	3.0613
20	.019		
21	.019		
22	.019		
23	.019	.019	.019
24	.019	.019	.019
Max	**2.9828**	**2.8937**	**3.0613**
Min	**.019**	**.019**	**.019**
Avg	**.5130**	**1.7524**	**1.0331**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274005 / 33/11 KV PANGARI S/S
Feeder No / Name : 207 / Pangri Gaothan Feeder GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.1306	
2		.1494	
3		.1494	
4		.2054	
5		.2611	
6		.2798	
7		.2425	
8	.2798	.2798	.4103
16	.1679	.1865	.1492
17	.1865		
18	.1865		
19	.2798		
20	.1865		
21	.1865		
22	.1679		
23	.1865	.1865	.2238
24	.1679	.1679	.1865
Max	**.2798**	**.2798**	**.4103**
Min	**.1679**	**.1306**	**.1492**
Avg	**.1996**	**.2035**	**.2425**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274006 / 33/11 KV UPALE (D)
Feeder No / Name : 201 / JAMGAON FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)
1	.2401	1.6461
2	.2058	1.6461
3	.2058	1.6461
4	.2058	1.6461
5	.2058	1.0974
6		1.5775
7		1.5775
8		2.0576
9		2.7435
10		2.332
11		2.4006
12		2.6406
20	.0343	.0343
21	.0343	.0343
22	1.8176	.0343
23	1.8519	.0343
24	.2401	1.6804
Max	**1.8519**	**2.7435**
Min	**.0343**	**.0343**
Avg	**.5042**	**1.4605**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274006 / 33/11 KV UPALE (D)
Feeder No / Name : 204 / Jamgaon GAONTHAN FEEDER GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)
1	.2058	.1543
2	.2058	.1543
3	.2401	.1543
4	.2572	.1715
5	.2915	.2229
6	.4801	.4287
7	.583	.4973
8	.4801	.4801
9	.3601	.3772
10		.1715
11	.1715	
12	.1543	.12
13	.12	.1372
14	.1372	.1029
15	.1029	.12
16	.1543	.1029
17	.1543	
18	.0154	
19	.2915	.4458
20	.4973	.4115
21	.3429	.3772
22	.2572	.2401
23	.1886	.2401
24	.2058	.1543
Max	**.583**	**.4973**
Min	**.0154**	**.1029**
Avg	**.2564**	**.2507**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] **BU 1392**
Substation No/ Name :- 274006 / 33/11 KV UPALE (D)
Feeder No / Name : 207 / Upale(D) Gaothan feeder **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)
1	.1543	.1372
2	.12	.1372
3	.12	.1543
4	.1543	.1715
5	.2058	.1715
6	.2401	.2058
8	.2401	.2058
9	.1886	.2058
10	.1886	.1715
11	.1715	.1715
12	.1543	.1543
13	.1372	.1372
14	.12	.1029
15	.1715	.1029
16	.1715	.12
17	.2058	.1372
18	.2058	.1715
19	.2401	.2401
20	.2058	.2401
21	.2058	.2229
22		.2058
23	.1715	.2058
24	.1543	.1372
Max	**.2401**	**.2401**
Min	**.12**	**.1029**
Avg	**.1785**	**.17**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] **BU 1392**
Substation No/ Name :- 274006 / 33/11 KV UPALE (D)
Feeder No / Name : 208 / 11 kv Zaregaon Ag Feeder **FEEDER SEPERATION/PURE AG**
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)
1	.0514	.0343
2	.0514	.0343
3	.0514	.0343
4	.0514	.0343
5	.0514	.0343
6	1.2003	
7	1.3032	
8	1.3375	
9	1.406	
10	1.6118	
11	1.8519	
12	1.7147	
13	1.7147	
14		1.7147
17		1.8176
18		1.7833
19		1.6461
20	.0343	1.5775
21	.0343	1.5432
22	.0343	.0343
23	.0343	.0343
24	.0514	.0343
Max	**1.8519**	**1.8176**
Min	**.0343**	**.0343**
Avg	**.6992**	**.7398**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274007 / 33/11 KV VAIRAG SUB STATION
Feeder No / Name : 201 / 11 KV Raleras SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	1.5242		.061
2	.7621	1.5242	.0457	
3	1.2193	1.448	.0457	.0457
4	1.3717	1.6004	.0457	.0457
5	1.5242	1.3717	.0457	.0457
6	1.9052	1.6766	.0457	
7	2.4387	1.9814	.0457	
8	2.4387	2.3777		
9	2.3624	2.2862		
10	2.2862	2.21		
11	.0762			2.1338
12	.061			2.5149
13				2.4387
14	.061		.061	2.5149
15	.061		.061	2.8197
16	.061	.0762	.061	2.7435
17	.0762		.061	2.5911
18	.0914		.061	2.2862
19	.1067		.0914	.0762
20	.1067		.0914	.0762
21	.1219	.0457	.0762	
22	.1067		.0762	
23	.1067	.0457	.061	
24	.1067	.1067	.0457	.0762
Max	**2.4387**	**2.3777**	**.0914**	**2.8197**
Min	**.061**	**.0457**	**.0457**	**.0457**
Avg	**.7786**	**1.3053**	**.0601**	**1.3646**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274007 / 33/11 KV VAIRAG SUB STATION
Feeder No / Name : 204 / 11 KV VAIRAG Urban Feeder GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4572	.5335	.4572
2	.4572		.4572
3	.4572		.4572
4	.4572	.5335	.5335
5	.6097		.5335
6	.7621		.6097
7	.8383		.7621
8	.7621	.7621	.7621
9	.7621		.6859
10	.6859		.7164
11	.6401		.7316
12	.6097	.6097	.7316
13	.6097		.7316
14	.6097		.7316
15	.6097		.7316
16	.6706		.7316
17	.7164		.7621
18	.7621		.8078
19	.9145	.7621	.8535
20	.9145		.8383
21	.8383	.8383	.8383
22	.7621		.7926
23	.6401	.6097	.7468
24	.6097	.6097	.4572
Max	**.9145**	**.8383**	**.8535**
Min	**.4572**	**.5335**	**.4572**
Avg	**.6732**	**.6573**	**.6859**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274007 / 33/11 KV VAIRAG SUB STATION
Feeder No / Name : 205 / 11 KV IRLE SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
11	1.448	1.0669	.945
12	1.6766	1.0669	
13	1.7528	1.2193	1.326
14	1.7071	1.3717	1.2193
15	1.6766	1.5242	1.2803
16	1.5242	1.5242	1.6461
17	1.4937	1.5242	1.6004
18	1.5242	1.6004	1.326
Max	**1.7528**	**1.6004**	**1.6461**
Min	**1.448**	**1.0669**	**.945**
Avg	**1.6004**	**1.3622**	**1.3347**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274123 / 33/11 KV SURDI S/S
Feeder No / Name : 201 / 11 KV MALWANDI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5335	.6859	.0914	
2		.5335	.6859	.0914	
3		.7011	.8383	.0914	
4		.7621	.9145	.0914	
5		.9145	.945	.1143	.1509
6		.9145	.9907		
7		1.3413	1.387		
8		1.4022	1.7071		.1677
9	1.5242		1.5242	.1677	.1677
10	1.3717	1.1279	1.4632		.1219
11	.0686	.0762	.0686	1.4251	1.6004
12	.0914	.0762	.0686	2.0119	1.6766
13	.0914	.0914	.0686		1.7528
14	.0914	.0762			1.829
15	.0914	.0762			1.6461
16	.0914	.0762			1.6461
17	.1029	.0762	.0914		1.5242
18	.1029	.0762	.16		1.1888
19	.1143	.1219	.16		.1524
20	.1257	.1372	.1486		.1524
21	.1143	.1219	.1143		.1524
22	.1143	.1372	.1029		.1067
23	.1029	.1372	.1029		.1067
24		.1219	.1067	.1029	.1341
Max	**1.5242**	**1.4022**	**1.7071**	**2.0119**	**1.829**
Min	**.0686**	**.0762**	**.0686**	**.0914**	**.1067**
Avg	**.2799**	**.4188**	**.5874**	**.4653**	**.7932**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274123 / 33/11 KV SURDI S/S
Feeder No / Name : 202 / 11 KV GULPOLI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.061	.0762	.3048	
2		.061	.0762	.3048	
3		.061	.0762	.3048	
4		.061	.0762	.381	
5		.061	.0762	.4572	.6706
6		.0762	.0914	.6097	
7		.0762	.1067		
8		.061	.0762		1.5927
9	.0343		.0572	1.3413	1.5927
10	.0343	.0457	.0572	1.1736	1.3717
11	1.0669	1.1431	.7011		
12	1.1431	1.2193	1.3717	.0503	.0762
13	1.2193	1.2955	1.3717		.0762
14	1.2955	1.1431			.0457
15	1.3717	1.0669			.061
16	1.448	1.1431	1.3717		.0457
17	1.3717	.9145	1.5242		.061
18	1.0669	.9145	1.3717		.0762
19	.0572	.1067	.0343		.0914
20	.0914	.1067	.0343		.0914
21	.0686	.1067	.0343		.0914
22	.0572	.0914	.0343		.0914
23	.0572	.0762	.0343		.0914
24		.0762	.0914	.0343	.0503
Max	**1.448**	**1.2955**	**1.5242**	**1.3413**	**1.5927**
Min	**.0343**	**.0457**	**.0343**	**.0343**	**.0457**
Avg	**.6922**	**.4334**	**.3975**	**.4962**	**.3634**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274123 / 33/11 KV SURDI S/S
Feeder No / Name : 203 / 11 KV SURDI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3108	1.0669	.0686	
2		1.3717	1.3413	.0686	
3		1.4632	1.4175	.0686	
4		1.7071	1.5242	.1372	
5		1.9204	1.9814	.16	.2515
6		2.5301	2.0576	.1943	
7		2.8654	2.3624		
8		2.7587			.3018
9	.0914			2.5987	2.934
10	.1143	.0914			2.2862
11		.061		3.1855	2.5911
12		.061		3.1855	2.2862
13	.0686	.061			2.5911
14	.0572	.061	.0686		2.713
15	.0572	.061	.0572		2.9721
16	.0686	.0762	.0572		2.8654
17	.0686	.0762	.0914		.1372
18	.0914	.0762	.1143		.1829
19	.1372	.2286	.16		.2286
20	.1372	.2286	.1981		.2286
21	.1143	.1829	.1143		.2134
22	.1143	.1524	.1029		.1829
23	.0914	.1524	.0914		.1524
24		.0914	.1219	.0914	.1341
Max	**.1372**	**2.8654**	**2.3624**	**3.1855**	**2.9721**
Min	**.0572**	**.061**	**.0572**	**.0686**	**.1341**
Avg	**.0932**	**.7647**	**.7183**	**.9758**	**1.2918**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274123 / 33/11 KV SURDI S/S
Feeder No / Name : 205 / 11 kV Yawali Ag feeder FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0305	.0457	1.3717	
2		.0305	.0305	1.3717	
3		.0457	.0305	1.3717	
4		.0457	.0305	1.3717	
5		.061	.0305	1.5242	2.0119
6		.061	.0457	1.6613	
7		.0762	.0457		2.5149
8		.061	.0457		.503
9	.0229		.0457	.0503	.0335
10	.0229	.0305	.0229		.0305
11	.0229	.0305	.0229	.0503	.0457
12	.0229	.0457	.0229		.0152
13	.0229	.0305			.0152
14	.0343	.0457	.0229		.0152
15	.0343	.0457	.0343		.0305
16	.0343		.0343		
17	2.9569	2.9721	2.8654		.0457
18	2.8045	2.9264	2.5911		.0457
19	2.5911	2.6673	2.4387		.061
20	2.4387	1.9814	2.1643		.061
21	2.1643	2.0729	2.1338		.061
22	2.0729	1.9814	1.9814		.061
23	1.9814	1.6613	1.768		.061
24		1.9509	1.7528	1.6766	.0671
Max	**2.9569**	**2.9721**	**2.8654**	**1.6766**	**2.5149**
Min	**.0229**	**.0305**	**.0229**	**.0503**	**.0152**
Avg	**1.1485**	**.8570**	**.7916**	**1.1611**	**.3155**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274123 / 33/11 KV SURDI S/S
Feeder No / Name : 206 / 11 kV Turk-Pimpari AG FEEDER SEPERATION/PURE AG
Feeder Feeder KV- 11 /
OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0914	.0762	.0686	
2			.061	.0686	
3		.0762	.061	.0686	
4		.0762	.061	.0686	
5		.0914	.1219	.08	.1174
6		.1067	.1219	.0914	
7		.0762	.1067		
8		.0914	.1219		
9	.9145		.9755	.1174	.1006
10	.9907	.7468	1.0669		.0914
11	1.0669	.9145	1.1279	.1006	.0762
12	1.1279	.7621	1.1584		.0762
13	1.1584	.884	1.2193		.061
14	1.1279	.9145	1.1888		.0762
15	1.1584	.9907	1.1584		.0762
16	1.1584	.9145	1.0669		.0762
17	.0686	.0914	.0686		1.1279
18	.0686	.0914	.08		.9755
19	.08	.1067	.08		.8383
20	.0914	.1067	.0914		.7926
21	.0914	.1219	.0914		.7621
22	.08	.1067	.0914		.7316
23	.08	.1219	.08		.6859
24		.0914	.0762	.0686	.5868
Max	**1.1584**	**.9907**	**1.2193**	**.1174**	**1.1279**
Min	**.0686**	**.0762**	**.061**	**.0686**	**.061**
Avg	**.6175**	**.3443**	**.4314**	**.0814**	**.4266**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274125 / 33/11 KV KASARWADI S/S
Feeder No / Name : 201 / 11 KV SOUNDARE FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9945	.8383	.0686	.061
2		.9945	.8993	.0686	.061
3		1.0288	.8993	.0686	.061
4		1.1145	.8993	.0686	.061
5		1.166	.9145	.0686	.0457
6		1.2174	1.2193	.0514	.0457
7		1.6804	1.3717	.0514	.061
8		1.6289	1.4175	.1029	.0457
9		.0686	.061	1.5261	1.8861
10		.0857		1.448	1.989
11		.061		1.4937	1.9204
12		.0457	.0686	1.6766	2.0233
13		.0457	.0686	1.768	1.9547
14		.0457	.0686	1.7833	1.8004
15	.0686	.061	.0857		1.7833
16	.0686	.061	.0857		1.7318
17	.0686	.061	.0686		
18	.0514	.061	.0343	.061	
19	.0686	.061	.0686	.061	.0514
20	.0686	.0762	.0686	.061	.0686
21	.0686	.0762	.0686	.061	.0686
22	.0686	.061	.0686	.061	
23	.0686	.061	.0686	.061	.0686
24		.0857	.061	.0686	.061
Max	**.0686**	**1.6804**	**1.4175**	**1.7833**	**2.0233**
Min	**.0514**	**.0457**	**.0343**	**.0514**	**.0457**
Avg	**.0667**	**.4518**	**.4275**	**.5085**	**.7547**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274125 / 33/11 KV KASARWADI S/S
Feeder No / Name : 202 / 11 KV KORFALE FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17
HR	Load (MW)	Load (MW)
1	.0514	.0914
2	.0514	.0914
3	.0686	.0914
4	.0686	.0914
5	.0686	.0914
6	.0686	.1067
7	.1029	.0914
8	.1029	.1067
9	.1029	.0914
10	.1029	
11	.0914	
12	.0914	
13	.0914	
14	.1067	
15	.1219	
16	.1524	
18	2.1948	
19	2.5911	
20	2.1491	
21	1.5851	
22	1.5546	
23	1.5546	
24	1.8519	1.5394
Max	**2.5911**	**1.5394**
Min	**.0514**	**.0914**
Avg	**.6489**	**.2393**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274125 / 33/11 KV KASARWADI S/S
Feeder No / Name : 203 / 11 KV KASARWADI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0514	.0457	.0514	.0457
2		.0514	.0457	.0514	.0457
3		.0514	.0457	.0514	.0457
4			.061	.0514	.0457
5		.0514	.061	.0514	.0457
6		.0514	.061	.0514	.0457
7		.0514	.061	.0514	.0457
8		.0514	.0457	.0686	.0305
9		1.3889	1.2193	.0514	.0514
10		1.7833	1.6975	.061	.0514
11		1.7528	1.5775	.061	.0514
12		1.7375	1.9033	.061	.0514
13		1.8138	1.9547	.061	.0514
14		1.829	1.4575		.0514
15	2.2634	1.829	1.9547		.0514
16	2.2119	1.8442	1.7833		.0686
17	.0514	.061	.0514		2.2291
18	.0514	.061	.0514		1.9376
19	.0514	.061		1.2041	1.7147
20	.0514	.061	.0686	1.2041	1.5775
21	.0686	.061	.0686	1.2041	1.5775
22	.0686	.0457	.0686	1.2041	1.5432
23	.0686	.0457	.0686	1.1736	1.5432
24		.0857	.0457	.0686	1.1736
Max	**2.2634**	**1.8442**	**1.9547**	**1.2041**	**2.2291**
Min	**.0514**	**.0457**	**.0457**	**.0514**	**.0305**
Avg	**.5430**	**.6444**	**.6260**	**.3570**	**.5865**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274125 / 33/11 KV KASARWADI S/S
Feeder No / Name : 204 / KASARWADI GAONTHAN FEEDER GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.2915	.1715	.2572
2		.1715	.2915	.1715	.2743
3		.1715	.2915	.1715	.2572
4		.2572	.3086	.1715	.2572
5		.3429	.3601	.2572	.3944
6		.4287	.4973	.4287	.4801
7		.6001	.6173	.5144	.5316
8		.5144	.5144	.5144	.4801
9		.2572	.4801	.3429	.4973
10		.1715	.2401	.1715	.3086
11		.1715	.1715	.12	.1715
12		.1886	.1715	.12	.1372
13		.1886	.1715	.1715	.1372
14		.1715	.1715	.1715	.1372
15	.1715	.1715	.1715	.1715	.1715
16	.1715	.1715	.1715	.1715	.1715
17	.1715	.2229	.1715	.2058	.2058
18	.2572	.3086	.2572	.2401	.3772
19	.4287	.5487	.4287	.4801	.5144
20	.3429	.4801	.3429	.5487	.463
21	.2572	.3258	.3429	.5316	.3772
22	.1715	.2915	.1715	.3086	.3429
23	.1715	.2915	.1715	.2915	.3086
24		.1715	.2915	.1715	
Max	**.4287**	**.6001**	**.6173**	**.5487**	**.5316**
Min	**.1715**	**.1715**	**.1715**	**.12**	**.1372**
Avg	**.2382**	**.2829**	**.2958**	**.2758**	**.3154**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274125 / 33/11 KV KASARWADI S/S
Feeder No / Name : 205 / 11 KV Maruti Technofab NON SHEDDABLE EXPRESS HV FEEDERS
Express Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.12	.2229	.1886	.1543
2		.12	.2229	.1886	.1543
3		.12	.2229	.1886	.1543
4		.1372	.2229	.1886	.1543
5		.1372	.2229	.1886	.1715
6		.1543	.2058	.1886	.1715
7		.0857	.2058	.1886	.1715
8		.1372	.1543	.1372	.2058
9		.1372	.1715	.0857	.2229
10		.1543	.1715	.1543	.2229
11		.1543	.1372	.1715	.1715
12		.1543	.1372	.1543	.1886
13		.1543	.1543	.1543	.2058
14		.1886	.1715	.1543	.2058
15	.2058	.2229	.1715	.1543	.2229
16	.2058	.2572	.1543	.1543	.2401
17	.2058	.2401	.1372	.1543	.2058
18	.2572	.2401	.1543	.1543	.2401
19	.2229	.2572	.1715	.1543	.2229
20	.1715	.2401	.1543	.1543	.1543
21	.12	.2401	.1543	.1543	.1543
22	.12	.2401	.2058	.1543	.1543
23	.12	.2229	.2058	.1543	.1543
24		.12	.2743	.2058	.1543
Max	**.2572**	**.2572**	**.2743**	**.2058**	**.2401**
Min	**.12**	**.0857**	**.1372**	**.0857**	**.1543**
Avg	**.181**	**.1765**	**.1836**	**.1636**	**.1858**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274157 / Jamgaon
Feeder No / Name : 201 / Industrial Feeder SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 33 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1883	.9145	1.3014	.5144
2		1.1317	.9145	1.2449	.5716
3		1.1317	.9145	1.1317	.5144
4		1.1883	.9145	1.1883	.5144
5		1.358	.9717	1.2449	.5716
6		1.1317	1.1431	1.6975	.6859
7		1.3014	1.3717	1.4969	.9145
8		1.7924	1.5432	1.1523	1.0154
9		1.5364	1.4014	1.1763	1.6804
10		1.7918	2.2885	1.3443	1.8296
11		1.9879	2.5738	1.7364	2.1948
12		2.6578	2.5628	1.9605	2.524
13		2.7869	2.6463	2.1415	2.4177
14			2.1422	1.4638	2.3388
15			2.5493	1.578	2.524
16		2.4177	2.696	1.578	2.9687
17		2.4208	3.0298	1.5415	2.384
18		2.2519	2.4177	1.0093	2.2965
19		2.0268	1.5844	.8522	1.6804
20		1.2949	1.6975	.6859	1.6244
21		1.2949	1.6409	.6859	1.6804
22		1.4146	1.5844	.743	1.6244
23	1.6804	1.3663	1.5278	.6287	1.358
24		1.1317	1.0288	1.2449	.5716
Max	**1.6804**	**2.7869**	**3.0298**	**2.1415**	**2.9687**
Min	**1.6804**	**1.1317**	**.9145**	**.6287**	**.5144**
Avg	**1.6804**	**1.6638**	**1.7525**	**1.2845**	**1.5417**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274157 / Jamgaon
Feeder No / Name : 202 / Gaothan Fdr **GAOTHAN FEEDER**
Feeder KV- 33 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9054	.9008	1.0642	.8462
2		.9054	.9008	1.0082	.9044
3		1.0751	1.0134	1.1203	1.074
4		1.4146	1.2386	1.4003	1.2461
5		1.7924	1.6804	1.9605	1.8692
6		2.5206	2.6326	2.6326	2.268
7		2.8006	2.8567	2.8006	2.7642
8		2.5206	2.4646	2.1845	2.5819
9		1.8484	1.7329	1.5684	1.9605
10		1.0534	1.1008	1.0082	1.386
11		.9328	.8578	.8402	
12		.823	.6687	.8402	.5487
13		.7682	.6539	.7842	.6447
14			.6821	.7282	.691
15			.6289	.7842	.691
16		.7682	.7042	.8962	.8145
17		.7682	.8688	.8651	
18		1.6244	1.4815	1.4799	1.6244
19		1.9959	2.1285	2.3357	2.0725
20		1.7924	1.9605	1.9897	1.7924
21		1.5123	1.6244	1.5716	1.2323
22		1.1835	1.3443	1.1727	1.0082
23	1.1203	1.0697	1.1763	.9017	.9522
24		.9522	.9008	1.1203	.8462
Max	**1.1203**	**2.8006**	**2.8567**	**2.8006**	**2.7642**
Min	**1.1203**	**.7682**	**.6289**	**.7282**	**.5487**
Avg	**1.1203**	**1.4103**	**1.3418**	**1.3774**	**1.3554**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274157 / Jamgaon
Feeder No / Name : 203 / Ag Feeder FEEDER SEPERATION/PURE AG
Feeder KV- 33 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	5.9757	6.3306	4.6759	6.3157
10	4.9554	7.1108	3.9273	6.5587
11	7.1274	6.2698	6.265	6.7341
12	7.1416		5.9259	6.4883
13	7.2748	7.0045		6.39
14		6.9146		6.1934
15		7.0042		6.6358
16	5.2955	3.5528		6.8816
Max	**7.2748**	**7.1108**	**6.265**	**6.8816**
Min	**4.9554**	**3.5528**	**3.9273**	**6.1934**
Avg	**6.2951**	**6.3125**	**5.1985**	**6.5247**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274157 / Jamgaon
Feeder No / Name : 204 / Shelgaon(m)Ag. FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0457	.0463	.061	.0305
2		.0457	.0468	.061	.0305
3		.0457	.0463	.061	.0305
4		.0457	.0463	.061	.0305
9		1.6766		2.037	2.1605
10		1.6918	2.1491	2.3148	2.3303
11		2.1186	2.1795	2.4846	2.392
12		2.2377	2.1948	2.0679	2.3148
13		2.2685			
14			2.3349		2.1605
15			2.1823		
16		2.2994	1.9814		2.3472
19		.0623	.061	.0611	
20		.0623	.0914	.0611	
21		.0468	.0914	.0611	
22		.0468	.0762	.0458	
23	.061	.0468	.0762	.0458	
24		.0457	.0463	.061	.0305
Max	**.061**	**2.2994**	**2.3349**	**2.4846**	**2.392**
Min	**.061**	**.0457**	**.0463**	**.0458**	**.0305**
Avg	**.061**	**.7991**	**.8531**	**.6774**	**1.2598**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274157 / Jamgaon
Feeder No / Name : 205 / DEVGAON Ag FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7842	1.0936	1.2483	.8886
2	.8482	1.1405	1.2163	.9532
3	.8802	1.2029	1.2803	1.034
4	.8962	1.2654	1.3123	1.244
5	.9122	1.4529	1.5203	1.454
6	1.085	1.7654	1.7284	1.6641
7	1.6194	2.1559	2.3805	2.6496
8	1.7328	1.9997	2.2834	2.5042
17	2.1216	2.0805		2.2068
18	2.1963	1.9524	.0323	2.2531
19	1.6204	1.8404	.0323	1.9753
20	1.5586	1.6804	.0162	1.7901
21	1.4043	1.5524	.0323	1.6049
22	1.3735	1.4403	.0323	1.4815
23	1.3443	1.1683	.0162	1.4815
24		1.1363	1.1203	.0162
Max	**2.1963**	**2.1559**	**2.3805**	**2.6496**
Min	**.7842**	**1.0936**	**.0162**	**.0162**
Avg	**1.3585**	**1.5580**	**.9501**	**1.5751**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274158 / 33/11 KV Shendri S/Stn
Feeder No / Name : 201 / Gaothan Feeder GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1886	.1867	.1715	.1698
2		.1886	.1867	.1715	.1698
3		.2263	.1867	.2058	.1698
4		.3018	.2241	.2401	.2641
5		.415	.4108	.3429	.3961
6		.5658	.5601	.3772	.5658
7		.5658	.5975	.4458	.5281
8		.4904	.4854	.4115	.4854
9		.3772	.3772	.3696	.5041
10		.2743	.2572		.2987
11		.1677	.1715		.1886
12		.1402	.12		.1132
13			.1372		.1132
14			.12		.1132
15			.1067		.1132
16		.1372	.1067	.1715	.1509
17		.2126	.2058		.1886
18		.3189	.2229	.362	.3018
19		.4755	.4115	.5121	.4904
20		.4024	.3429	.4108	.415
21		.3658	.2743	.3734	.3395
22	.2641	.2587	.1715	.2054	.1886
23	.2263	.2218	.1543	.2054	.1886
24		.1886	.1848	.1543	.168
Max	**.2641**	**.5658**	**.5975**	**.5121**	**.5658**
Min	**.2263**	**.1372**	**.1067**	**.1543**	**.1132**
Avg	**.2452**	**.3087**	**.2584**	**.3018**	**.2760**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274158 / 33/11 KV Shendri S/Stn
Feeder No / Name : 202 / Shripat-Pimpri Feeder AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2058	.1867	.1372	.1494
2		.2012	.1867	.1372	.1494
3		.2012	.1867	.1715	.1494
4		.2012	.2241	.1715	.1494
5		.2012	.2241	.1886	.2241
6		.2012	.2614	.2058	.2427
7		.3018	.2987	.2401	.2987
8		.2652	.3361	.2915	.2987
9		.2321	.2987	.2614	.3547
10		.2267	.2896		.2614
11		1.8435	2.0424	2.2672	2.3205
12		2.753	3.0178	3.2388	2.572
13		2.4966	2.9504	3.2388	
14			2.9721	2.8826	2.4291
15			2.713		2.4291
16		3.1459			
17		2.8654	3.0178		3.0483
18		2.753	1.89		3.0788
19		.2614	.2058	.3174	.1829
20		.2218	.1886	.2801	.2134
21		.2218	.1886	.2614	.1829
22		.2218	.1372	.2241	.1524
23	.2103	.1829	.1372	.1867	.1753
24		.2103	.1829	.1372	.1494
Max	**.2103**	**3.1459**	**3.0178**	**3.2388**	**3.0788**
Min	**.2103**	**.1829**	**.1372**	**.1372**	**.1494**
Avg	**.2103**	**.8825**	**.9625**	**.7810**	**.8733**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274158 / 33/11 KV Shendri S/Stn
Feeder No / Name : 203 / Shendri Feeder AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4801	.4801	.4252	.7335
2		.6249	.4801	.4725	.7335
3		.7621	.7514	.5609	.7335
4		.9145	.7678	.6036	.8916
5		1.0669	.8421	.9069	.8859
6		1.1431	.9328	1.2346	.9717
7		1.7833	1.8004	1.813	1.8595
8		1.9033	2.2005	2.284	2.1033
9		1.9204	2.0831	2.2558	1.829
10		1.8892	2.0831		1.6766
11		.1014	.0514	.1143	.1524
12		.0781	.0686	.1715	.1429
13			.0579	.1715	
14			.068	.0953	
15			.0703		
16		.0625	.0634		
17		.0819	.0914		
18		.1414	.0838		
19		.1707	.1429	.1734	.1867
20		.1254	.1467	.16	.1867
21		.1307	.1162	.1143	.1867
22	.2401	.1307	.1111	.1048	.16
23	.1966	.1075	.101	.0953	.16
24		.1638	.1075	.1372	.0857
Max	**.2401**	**1.9204**	**2.2005**	**2.284**	**2.1033**
Min	**.1966**	**.0625**	**.0514**	**.0953**	**.0857**
Avg	**.2184**	**.6563**	**.5709**	**.6260**	**.7600**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274158 / 33/11 KV Shendri S/Stn
Feeder No / Name : 204 / PWW Express Feeder NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2641	.2641
2			.2641	.2641
3			.2641	.2641
4			.2641	.2641
5	.2641	.2641	.2641	.2641
6	.2641	.2641	.2641	.2641
7	.2561	.2641	.2641	.2641
8	.2641	.2641	.2641	.2641
9	.2641	.2641	.2641	.2641
10	.2641	.2641		.2641
11		.2641	.2641	.2641
12		.2641		.2641
13		.2641		.2641
14		.2641		.2641
15		.2641		.2641
16		.2641		.2561
17	.2641	.2401		.2641
18		.2401		.2641
19	.2641	.2641	.2641	.2641
20	.2641	.2641		.2561
21	.2641	.2641		.2641
22	.2641	.2641	.2641	.2641
23	.2641	.2641	.2641	
24		.2641	.2641	.2641
Max	**.2641**	**.2641**	**.2641**	**.2641**
Min	**.2561**	**.2401**	**.2641**	**.2561**
Avg	**.2634**	**.2617**	**.2641**	**.2634**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274192 / Gaudgaon Sub station
Feeder No / Name : 201 / 11 KV Gaudgaon feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4115	.3429	1.3717
2	.4115	.3429	1.3717
3	.4115	.3429	1.3717
4	.6344	1.1145	1.3717
5	.9088	1.1145	1.3203
6	1.0288		
7	1.0288		
8	.9602		
9	.6859	.823	
10	.5487	.6001	.6859
11		.3429	.4458
12	.3429	.3429	.3429
13	.3086	.3772	.3086
14	1.6289	.3772	.3086
15	1.6118	.3772	.2743
16	1.4403	.4287	.3086
17	1.406	.4287	.4115
18	1.2689	.8573	.583
19	1.286	.8916	.8573
20	1.1317	.823	.7202
21	1.0288	.6344	.583
22	.4115	1.2003	1.5089
23	.3429	1.3717	1.4403
24	.4115	.3429	1.3717
Max	**1.6289**	**1.3717**	**1.5089**
Min	**.3086**	**.3429**	**.2743**
Avg	**.8543**	**.6418**	**.8479**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274192 / Gaudgaon Sub station
Feeder No / Name : 202 / 11 KV Raulgaon Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.823	.8573	.3086
2	.823	.8573	.3086
3	.6859	.8573	.3429
4	.6859	.8573	.4287
5	.7202	.6859	.5658
6	.6859	.6516	1.2003
7	.6859	1.0288	1.5432
8	.6516	1.5089	1.6289
9	.3772	1.749	1.6289
10		1.8004	1.6804
11		1.8004	1.5775
12	.1029	1.7661	1.7833
13	.1029	.1715	1.4746
14		.1715	.1372
15	.1372		.1372
16	.1715	.1715	.1372
17	.2743	.2229	.2401
18	.4115	.2915	.4115
19	.7202	.6516	.6859
20	.583	.5144	.5487
21	.3772	.3772	.3772
22	1.0288	.3429	.2743
23	1.166	.3086	.2743
24	.9431	1.0288	.3086
Max	**1.166**	**1.8004**	**1.7833**
Min	**.1029**	**.1715**	**.1372**
Avg	**.5789**	**.8119**	**.7502**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274192 / Gaudgaon Sub station
Feeder No / Name : 203 / 11 KV Bhalgaon Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2743	.1886	.2743
2	.2743	.1886	.2743
3	.2915	.1886	.2915
4	.3429	.2743	.3772
5	.3944	.4458	.3772
6	1.9719	.5144	.7202
7	2.0576		.6859
8	2.1605	.3887	.5487
9	2.1605	.463	.463
10	2.1605	.1715	.3429
11	2.0233	.12	.2401
12	2.1262	.12	.1372
13	2.0233	.12	.1372
14	.12	.12	2.4006
15	.12	.1715	2.5034
16	.1372	.1715	2.332
17	.1715	.2058	2.5377
18	.3086	1.8861	2.2291
19	.5144	1.8861	2.2291
20	.4801	1.8861	2.0576
21	.3429	1.8004	1.989
22	.2401	.463	.2401
23	.1886	.3429	.2058
24	.2743	.1886	.2743
Max	**2.1605**	**1.8861**	**2.5377**
Min	**.12**	**.12**	**.1372**
Avg	**.8816**	**.5350**	**.9945**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274208 / 33/11 KV Pathari Sub station
Feeder No / Name : 201 / 11 Kv pathari Gaothan feeder Feeder KV- 11 / OUTGOING **GAOTHAN FEEDER**

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0686	.1029	.0857	.1372
2		.1029	.1372	.0686	.1029
3		.1372	.1715	.0686	.1029
4		.1372	.2058	.12	.1372
5		.1715	.2743	.2058	.2058
6		.2058	.3601	.3601	.2401
7		.2915	.3601	.3429	.3086
8		.3086	.3086	.2915	.2743
9		.2572	.2058	.2572	.2058
10		.1715	.1372		.1715
11	.1715	.1029	.1029	.1372	.1029
12	.1029	.0686	.0857	.1372	.0686
13	.12	.0686	.0686	.12	.0686
14	.1029	.0514	.0857	.0857	.0686
15	.1029	.0686	.0686	.0686	.0686
16	.0686	.0686	.0857	.1029	.0686
17	.1029	.12	.1029	.0857	.1029
18	.2401	.2401	.2058	.2401	.2058
19	.2572	.3086	.3086	.3086	.3086
20	.2743	.2229	.2401	.2743	.2229
21	.2229	.1715	.2058	.2058	.1715
22	.1372	.1372	.1372	.1715	.1372
23	.1029	.1029	.1029	.1372	.1029
24		.0857	.1029	.1029	.1372
Max	**.2743**	**.3086**	**.3601**	**.3601**	**.3086**
Min	**.0686**	**.0514**	**.0686**	**.0686**	**.0686**
Avg	**.1543**	**.1529**	**.1736**	**.1730**	**.1551**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274208 / 33/11 KV Pathari Sub station
Feeder No / Name : 202 / 11 Kv Dhanore Ag feeder FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11	1.0974	1.3889	1.4232	1.406
12	1.3717	1.5947	1.4575	1.406
13	1.5089	1.5604	1.5261	1.4403
14	1.3717	1.5775	1.5775	1.3717
15	1.406	1.4403	1.6118	1.4746
16	1.5604	1.5261	1.6118	1.4403
17	1.5432	1.4918	1.2346	1.5432
18	1.3375	1.2003		1.3717
Max	**1.5604**	**1.5947**	**1.6118**	**1.5432**
Min	**1.0974**	**1.2003**	**1.2346**	**1.3717**
Avg	**1.3996**	**1.4725**	**1.4918**	**1.4317**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274208 / 33/11 KV Pathari Sub station
Feeder No / Name : 203 / 11 KV Pimpalwadi Ag FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.823	.583	.7545	.7202
2		.8573	.6173	.7716	.7545
3		.823	.6173	.823	.823
4		.8573	.6516	.8745	.823
5		.9431	.6687	.9259	.8573
6		1.0117	.7888	.9602	.9259
7		1.0288	.9774	1.0288	.9945
8		1.166	1.1317	1.2003	.8916
9		1.1145	1.1145	1.166	.9259
10		.9945	1.046	1.1317	.9259
11	1.1145				
12	1.4403				
13	1.4575				
14	1.3717				
15	1.406				
16	1.3717				
17	1.166				
18	1.0288				
Max	**1.4575**	**1.166**	**1.1317**	**1.2003**	**.9945**
Min	**1.0288**	**.823**	**.583**	**.7545**	**.7202**
Avg	**1.2946**	**.9619**	**.8196**	**.9637**	**.8642**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274221 / 33/11KV BAVI SUB STATION
Feeder No / Name : 201 / 11 KV DAM FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2439	.3201	.3353	.2743	.7468	.8993
2	.2439	.3201	.3201	.2743	.823	.9145
3	.3048	.3353	.3201	.3048	.8993	.945
4	.3048	.3506	.3201	.3048	1.0974	1.0059
5	.3048	.442	.3506	.3353	1.2041	1.1279
6	.3048	.5792	.3658	.381	1.3717	1.2651
7	.3658	.5944	.381	.4572	1.4022	1.2955
8	.3658	.4725	.3963	.4268	1.4022	1.4937
9			.3048	.3048	1.3717	1.3717
10				.2896	1.3565	1.3413
11	1.387		1.5242	1.5242	.0914	.0914
12	1.2803	1.6613	1.7375	1.5851	.0914	.0914
13	1.2193	1.7071	1.7223	1.7071	.0914	.0914
14	1.4937	1.8442	1.4175	1.768	.0914	.0914
15	1.4937	1.8595	1.4175	1.7985	.0914	.0914
16	1.6766	1.89	1.5546	1.8442	.0914	.0914
17	1.4327	1.89	1.4937	1.8595		.1219
18	1.2498	1.7985	1.3413	1.5242		.1524
19	.3353	.381	.4268	.2134	.3963	.3963
20		.3658	.4268	.2743	.381	.3658
21		.3658	.3658	.2439	.2896	.442
22	.442	.3506	.3353	.2286	.2439	.4572
23	.442	.3506	.3048	.2286	.2286	.3963
24	.2439	.3201	.3353	.3048	.2134	.1981
Max	**1.6766**	**1.89**	**1.7375**	**1.8595**	**1.4022**	**1.4937**
Min	**.2439**	**.3201**	**.3048**	**.2134**	**.0914**	**.0914**
Avg	**.7567**	**.8666**	**.7608**	**.7691**	**.6353**	**.6141**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274221 / 33/11KV BAVI SUB STATION
Feeder No / Name : 202 / 11 KV TANDULWADI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.2896	.2591	.2743	.0762	.061
2	.3658	.2896	.2743	.2743	.0762	.061
3	.3658	.3048	.3048	.2743	.0914	.061
4	.3963	.3201	.3048	.2743	.0914	.0762
5	.4572	.381	.3963	.3048	.0914	.1067
6	.4572	.3963	.442	.3048	.1067	.1524
7	.5182	.4115	.442	.3353	.1372	.1677
8	.5335	.442	.4725	.4115	.1677	.1677
9	.5487	.4572	.4725	.4268	.0914	.1067
10	.5182	.4268	.4572	.442	.0762	.0914
11	.0457	.061	.061	.0457	.503	.4877
12	.0457	.0305	.0305	.0457	.6097	.5487
13	.0305	.0305	.0305	.0305	.6249	.5639
14	.0305	.0305	.0305	.0305	.6249	.5487
15	.0305	.0305	.0305	.0457	.6401	.5487
16	.0305	.0457	.0305	.061	.6401	.5792
17	.061	.0457	.0457	.061	.5335	.5182
18	.0762	.1219	.0914	.0914	.503	.4572
19	.0762	.1067	.1372	.0914	.1219	.0914
20	.0914	.1067	.1219	.1067	.1067	.1067
21	.0914	.1067	.0914	.1067	.0762	.0914
22	.0914	.1067	.0762	.1067	.0762	.0914
23	.0914	.0914	.0762	.0914	.061	.061
24	.061	.061	.0914	.061	.0914	.061
Max	**.5487**	**.4572**	**.4725**	**.442**	**.6401**	**.5792**
Min	**.0305**	**.0305**	**.0305**	**.0305**	**.061**	**.061**
Avg	**.2242**	**.1956**	**.1988**	**.1791**	**.2591**	**.2420**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274222 / 33/11 KV HINGANI.P SUB STATION
Feeder No / Name : 201 / 11KV HINGANI.P AG FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	21-DEC-17
HR	Load (MW)
16	2.0919
Max	2.0919
Min	2.0919
Avg	2.0919

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] **BU 1392**
Substation No/ Name :- 274222 / 33/11 KV HINGANI.P SUB STATION
Feeder No / Name : 202 / 11KV NANDANI AG FEEDER **FEEDER SEPERATION/PURE AG Feeder KV- 11 / OUTGOING**

DATE	21-DEC-17
HR	Load (MW)
8	1.406
Max	1.406
Min	1.406
Avg	1.406

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] **BU 1392**
Substation No/ Name :- 274222 / 33/11 KV HINGANI.P SUB STATION
Feeder No / Name : 203 / 11KV GAVTHAN FEEDER **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	21-DEC-17
HR	Load (MW)
8	.3086
16	.1372
24	.2401
Max	**.3086**
Min	**.1372**
Avg	**.2286**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274235 / 33/11 KV RATANJAN SUB STATION
Feeder No / Name : 201 / 11 KV GAVTHAN FEEDER GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.3429	.2058	.1715
2		.1715	.2915	.2058	.2058
3		.1715	.2743	.2401	.2743
4		.3086	.3086	.3086	.3429
5		.3944	.4287	.3601	.4458
6		.3772	.5487	.4973	.5144
7		.4115	.4458	.4801	.4801
8		.3601	.4115	.4458	.3772
9	.3086	.2743	.3258	.2743	.3429
10	.2572	.2401	.2401	.2401	.1715
11	.1543	.1715	.1715	.1372	.1715
12	.2058	.1543	.1715	.1029	.1715
13	.1886	.1543	.1543	.1372	
14	.1715	.1372	.2058	.1372	
15	.1715	.1715			.1543
16	.2058	.1543	.1886	.1372	.1543
17	.2229	.1715	.2058	.1372	.2058
18	.2401	.2743	.2229	.2401	.3086
19	.3601	.3944	.3772	.3429	.4801
20	.3086	.4287	.3601	.3772	.5487
21	.3429	.4801	.2915	.2743	.5144
22	.2229	.4115	.2058	.2058	.4115
23	.2058	.4115	.2058	.1715	.3601
24		.12	.3944	.2229	.1715
Max	**.3601**	**.4801**	**.5487**	**.4973**	**.5487**
Min	**.1543**	**.12**	**.1543**	**.1029**	**.1543**
Avg	**.2378**	**.2715**	**.2945**	**.2557**	**.3172**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (R) S/DN.[091] BU 1392
Substation No/ Name :- 274236 / 33/11 KV DHAMANGAON SUB STATIO
Feeder No / Name : 201 / 11 KV RALERAS FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2481	.2835	.5316	.583
2	.2835	.3189	.6733	.7888
3	.2835	.3189	.6859	.8916
4	.3544	.3544	.9602	1.166
5	.4961	.4617	.9389	1.2574
6	.6379	.5688	1.2071	1.3748
7	.6733	.7087	1.3916	1.5415
8	.6024	.7087	1.4918	1.757
9	.567	.7087	1.5912	1.7901
10	.443	.6201	1.4586	1.7772
11	1.1145	1.4083	.2126	.2303
12	1.4754	1.7736	.2515	.2658
13	1.5424	1.8896		.1772
14	1.6095	1.7736		.1772
15	1.7101	1.8564		.2481
16	1.8778	1.6409		.2481
17	1.5089	1.4754	.3189	.3898
18	1.5089	1.4754	.3544	.3898
19	1.6478	.4252	.5121	.3898
20	.6733	.7466	.3544	.3898
21	.5316	.6733		.3189
22	.2835	.4961	.3189	.2835
23	.2835	.4961	.2835	.2835
24	.2481	.2835	.3898	.2481
Max	**1.8778**	**1.8896**	**1.5912**	**1.7901**
Min	**.2481**	**.2835**	**.2126**	**.1772**
Avg	**.8585**	**.8944**	**.7330**	**.7070**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (U) S/DN.[090] BU 1384
Substation No/ Name :- 274197 / 33/11 Kv Barshi Town Sub stati
Feeder No / Name : 201 / 11KV TOWN FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.743	.6401	.7354	
2		.6668	.6401	.7538	.6287
3		.6668	.6036	.7722	.6097
4			.6036	.7354	.5716
5		.6668	.6401	.7906	.7049
6		.9526	.7499	.8825	.7621
7		1.0288	.8779	1.1399	.9526
8		1.105	1.0059	1.1031	1.0479
9		.9526	.8641	.9744	1.0479
10		.8596	.8273		.9193
11		.9328	.8457		.8825
12		.9145	.8273	.7621	.8457
13		.823	.7722	.9145	.8273
14			.7354	.8573	.8089
15			.717		.8273
16		1.1706	.7722	.8954	.8641
17		1.3169	1.0112	.9907	.9744
18			1.1583	1.1431	1.2502
19	1.4289	1.3717	1.3237	1.4289	1.3237
20	1.5242	1.2071	1.287	1.3336	1.2318
21	1.6004	.9694	1.1399	1.1431	1.0112
22	1.3336	.8596	.8089	.8573	.956
23	1.2574	.7499	.8273	.7621	.8089
24		.8383	.6767	.7722	.6478
Max	**1.6004**	**1.3717**	**1.3237**	**1.4289**	**1.3237**
Min	**1.2574**	**.6668**	**.6036**	**.7354**	**.5716**
Avg	**1.4289**	**.9398**	**.8481**	**.9404**	**.8915**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (U) S/DN.[090] BU 1384
Substation No/ Name :- 274197 / 33/11 Kv Barshi Town Sub stati
Feeder No / Name : 202 / 11 KV INDUSTRIAL ESTATE NO.02 Feeder KV- 11 / OUTGOING SHEDDABLE FEEDER HAVING WEEKLY STAGGERING (MIDC, EQUIVALENT)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5716	.5658	.567	.2477
2		.4954	.5281	.5292	.2286
3		.381	.4715	.5103	.2286
4		.4191	.4715	.5292	.2096
5		.4191	.415	.4914	.2477
6		.5716	.5093	.5103	.2858
7		.6097	.547	.4725	.4382
8		.5906	.5847	.4914	.4382
9		.7621	.6804	.4536	.6287
10		.8488	.9072	.5144	.7182
11		.9242	1.134	.4763	.7371
12		.9054	1.0973	.4763	.7182
13		.7545	1.0017	.381	.756
14			.9261	.2667	.6615
15			.7938	.2858	.6804
16		.6413	.8127	.2858	.6615
17		.7922	.8694	.2667	.6993
18		.7545	.8505	.2667	.7371
19	1.0479	.7733	.9261	.2858	.6426
20	.9717	.7545	.8505	.2477	.567
21	.8002	.5658	.7182	.2858	.5292
22	.6668	.6413	.6048	.2858	.5103
23	.6668	.6036	.6237	.2858	.4536
24		1.0098	.5658	.5481	.2667
Max	**1.0479**	**1.0098**	**1.134**	**.567**	**.756**
Min	**.6668**	**.381**	**.415**	**.2477**	**.2096**
Avg	**.8307**	**.6722**	**.7273**	**.4047**	**.5122**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (U) S/DN.[090] **BU 1384**
Substation No/ Name :- 274197 / 33/11 Kv Barshi Town Sub stati
Feeder No / Name : 203 / 11 KV BHAGAWANT FEEDER **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1905	.1829	.2213	.1905
2		.1715	.1629	.2029	.1905
3		.1715	.1646	.1844	.1905
4		.1905	.1829	.2213	.1715
5		.2667	.2195	.2582	.3239
6		.381	.3109	.2951	.381
7		.4382	.3841	.332	.381
8		.4191	.362	.3873	.4382
9		.3239	.2766	.2951	.362
10		.2195	.2398	.2858	.2582
11		.2195	.2582	.2667	.2582
12		.2012	.2398	.2858	.2398
13		.2012	.2582	.2477	.2766
14			.2398	.2667	.2766
15			.2398	.2667	.2582
16		.3109	.2582	.2477	.2766
17		.2926	.3135	.2477	.2766
18		.2378	.3504	.381	.3135
19	.4001	.3658	.332	.4191	.332
20	.4382	.3292	.3135	.362	.2951
21	.4572	.2743	.2582	.2858	.2766
22	.381	.2743	.2213	.2286	.2398
23	.2667	.2012	.2213	.1905	.1844
24		.2286	.2012	.2029	.1905
Max	**.4572**	**.4382**	**.3841**	**.4191**	**.4382**
Min	**.2667**	**.1715**	**.1629**	**.1844**	**.1715**
Avg	**.3886**	**.2686**	**.2580**	**.2743**	**.2742**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (U) S/DN.[090] BU 1384
Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI
Feeder No / Name : 203 / 11KV CANCER FEEDER SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3203	1.3203	1.3336	
2	1.1203	1.3203	1.3336	
3	1.1203	1.3203	1.3336	
4	1.3203	1.3203	1.3336	
5	1.3203	1.3203	1.3336	
6	1.3203	1.3203	1.3336	
7	1.3203	1.3203	1.3336	
8	1.3203	1.3203	1.1431	
9	1.5089	1.307	1.1203	1.307
10	1.5089	1.6632	1.307	1.307
11	1.848	1.7147	1.2003	1.5089
12	1.848	1.5242	1.307	1.3203
13	1.848	1.3336	1.1203	1.1317
14	.7316	1.3336	1.1203	1.3203
15	1.6632	1.5242	1.1203	1.307
16	1.6632	1.7147	1.1203	1.4937
17	1.6804	1.7147	1.1203	1.4937
18	1.307	1.7147	1.1203	1.5089
19	1.307	1.3336	1.1203	1.3203
20	1.307	1.1431	1.1203	1.307
21	1.6804	1.1431		1.3203
22	1.6804	1.3336	1.1203	1.3203
23	1.4937	1.3336	1.1203	1.307
24	1.3203	1.3203	1.5242	
Max	**1.848**	**1.7147**	**1.5242**	**1.5089**
Min	**.7316**	**1.1431**	**1.1203**	**1.1317**
Avg	**1.4399**	**1.4048**	**1.2235**	**1.3516**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (U) S/DN.[090] BU 1384
Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI
Feeder No / Name : 204 / 11KV I.T.I. FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.362	.381	
2	.3391	.362	.381	
3	.3353	.362	.381	
4	.3391	.3658	.381	
5	.5144	.5487	.381	
6	.5258	.5487	.5335	
7	.7087	.724	.5716	
8	.724	.7316	.7621	
9	.7164	.7087	.7621	.7087
10	.7087	.7087	.7468	.7164
11	.5258	.7621	.7468	.7011
12	.5258	.7621	.7468	.5201
13	.5258	.7621	.5601	.5144
14	.5258	.5716	.5601	.5201
15	.5258	.5716	.3734	.5144
16	.5258	.5716	.3734	.3391
17	.5316	.5716	.3734	.3467
18	.7087	.7621	.5601	.7011
19	.7087	.7621	.5601	.7087
20	.7087	.7621	.7468	.7087
21	.5258	.7621	.7468	.5258
22	.5258	.7621	.5601	.5258
23	.3506	.5716	.3734	.5144
24	.3429	.543	.381	
Max	**.724**	**.7621**	**.7621**	**.7164**
Min	**.3353**	**.362**	**.3734**	**.3391**
Avg	**.5338**	**.6217**	**.5393**	**.5710**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (U) S/DN.[090] BU 1384
Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI
Feeder No / Name : 206 / 11KV MILL FEEDER SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	1.3203	1.1431	
2	1.0974	1.3203	1.1431	
3	1.086	1.3203	1.1431	
4	1.267	1.3203	1.1431	
5	1.2803	1.3203	1.1431	
6	1.4784	1.5089	1.3336	
7	1.6804	1.6804	1.7147	
8	1.6804	1.6975	1.7147	
9	1.2936	1.6804	1.5242	1.2803
10	1.4784	1.4937	1.307	1.2803
11	1.4784	1.7147	1.307	1.4784
12	1.6632	.381	1.307	1.6632
13	1.4784	.7621	1.307	1.6632
14	1.1088	.9526	1.307	1.2803
15	1.6632	1.5242		1.4784
16	1.6804	1.7147		1.8671
17	1.8671	1.7147	1.4937	1.8671
18	1.8671	1.7147	1.4937	1.6632
19	1.6975	1.5242	1.4937	1.4784
20	1.4937	1.3336	1.307	1.2803
21	1.4937	1.3336	1.307	1.2803
22	1.307	1.3336	1.1203	1.0974
23	1.307	1.3336	1.1203	1.086
24	1.2803	1.307	1.1431	
Max	**1.8671**	**1.7147**	**1.7147**	**1.8671**
Min	**1.086**	**.381**	**1.1203**	**1.086**
Avg	**1.4587**	**1.3878**	**1.3189**	**1.4496**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (U) S/DN.[090] BU 1384
Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI
Feeder No / Name : 207 / 11KV JAIN MANDIR FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8954	.9335	.9526	
2	.8859	.924	.9526	
3	.8954	.924	.9526	
4	1.086	.9335	.9526	
5	1.2803	1.307	.9526	
6	1.4632	1.4937	1.5242	
7	1.848	1.6461	1.7147	
8	1.848	1.8671	1.9052	
9	1.6804	1.829	1.7147	1.6632
10	1.4632	1.2803	1.307	1.4632
11	1.0517	1.1431	1.307	1.2536
12	1.0631	.9526	1.307	1.0517
13	1.0631	1.1431	.9335	1.0402
14	.905	.9526	.9335	.8573
15	1.0745	.9526	.9335	.8573
16	.8954	.9526	.9335	.8859
17	1.086	1.1431	.9335	1.0631
18	1.448	1.5242	1.4937	1.448
19	1.8099	1.9052	1.5432	1.6461
20	1.829	1.7147	1.6804	1.6461
21	1.6461	1.5242	1.4937	1.4632
22	1.2803	1.3336	1.1203	1.267
23	1.1088	1.1431	.9335	.8859
24	.8859	.9335	.9526	
Max	**1.848**	**1.9052**	**1.9052**	**1.6632**
Min	**.8859**	**.924**	**.9335**	**.8573**
Avg	**1.2705**	**1.2690**	**1.2262**	**1.2328**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (U) S/DN.[090] BU 1384
Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI
Feeder No / Name : 208 / 11KV BHAVANI PETH SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8954	.924	.9526	
2	.8859	.924	.9526	
3	.8859	.924	.9526	
4	1.0745	.924	.9526	
5	1.267	1.1203	.9526	
6	1.2803	1.307	1.3336	
7	1.4784	1.4937	1.3336	
8	1.4784	1.4937	1.7147	
9	1.4784	1.4632	1.5242	1.4784
10	1.4632	1.2803	1.307	1.4632
11	1.2536	1.3336	1.4937	1.2536
12	1.267	1.3336	1.6804	1.2536
13	1.267	1.3336	1.4937	1.2403
14	1.267	1.3336		1.0631
15	1.267	1.3336	1.2803	1.0517
16	1.267	1.3336		1.0517
17	1.4632	1.3336	1.4937	1.2536
18	1.848	1.7147	1.6804	1.6632
19	1.848	1.9052	1.8671	1.6632
20	1.829	1.9052	1.8671	1.6461
21	1.4784	1.5242	1.6804	1.4632
22	1.2936	1.3336	1.307	1.2803
23	1.1088	1.1431	1.1203	1.0745
24	.905	.924	.9526	
Max	**1.848**	**1.9052**	**1.8671**	**1.6632**
Min	**.8859**	**.924**	**.9526**	**1.0517**
Avg	**1.3146**	**1.3183**	**1.3588**	**1.3266**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (U) S/DN.[090] BU 1384
Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI
Feeder No / Name : 213 / 11KV BARSHI TEXTILE MILL NON SHEDDABLE EXPRESS HV FEEDERS
EXPRE Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9335	.9431	.9526	
2	.9335	.9431	.9526	
3	.924	.9431	.9526	
4	.9335	.9431	.9526	
5	.9431	.9431	.9526	
6	.9335	.9431	.9526	
7	1.1317	.9431	.9526	
8	1.1317	.9431	.5716	
9	.9431	.9431	.5716	.9335
10	.924	.9431	.5601	.9335
11	.9431	.9526	.7468	.9431
12	.9431	.7621	.7468	1.1317
13	.9335	.9526	.5601	.9335
14	.9431	.9526	.5601	.9335
15	.9431	.9526		.9335
16	.9431	.9526		.924
17	.9431	.9526	.0857	.9335
18	.9431	.9526	.0934	.9335
19	.9431	.9526	.0934	.9335
20	.9431	.9526	.0934	.924
21	.9431	.9526	.0934	.9335
22	.9431		.0857	.924
23	.9431		.0934	.9335
24	.9335	.9335	.9526	
Max	**1.1317**	**.9526**	**.9526**	**1.1317**
Min	**.924**	**.7621**	**.0857**	**.924**
Avg	**.9548**	**.9388**	**.5717**	**.9455**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (U) S/DN.[090] BU 1384
Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI
Feeder No / Name : 403 / Agalgaon
Feeder KV- 33 / INCOMING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4289	1.3575	1.2511	.9717
2	1.3146	1.086	1.1943	.9717
3		1.1946	1.2511	.9145
4		1.1946	1.1374	.9145
5	1.2003	1.2489	1.3649	1.2003
6	1.829	1.5203	1.5355	1.3146
7	2.0005	1.7375	1.763	1.7147
8	2.0576	1.9004	1.8198	1.829
9	2.0005	1.8767	1.5924	1.8861
10	1.8656	1.9905	1.6575	1.763
11	1.9204	2.0473	.8002	1.763
12	1.8656	2.1042	1.4861	1.8198
13	1.7558	1.9905	1.4861	1.6492
14		1.8198	1.2574	1.5355
15		1.7061	.5144	1.5355
16	2.0302	1.9336	1.3717	1.763
17	2.1948	2.1042	1.4861	2.1611
18	2.2805	2.2179	1.7718	2.3885
19	2.4691	2.3885	2.0576	2.1042
20	2.2497	2.0473	1.8861	2.0473
21	1.7918	1.8198	1.6575	1.6492
22	1.7375	1.4218	1.3146	1.3649
23	1.5746	1.3649	1.1431	1.2511
24	1.6004	1.4118	1.2511	1.0288
Max	**2.4691**	**2.3885**	**2.0576**	**2.3885**
Min	**1.2003**	**1.086**	**.5144**	**.9145**
Avg	**1.8584**	**1.7285**	**1.4188**	**1.5642**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (U) S/DN.[090] BU 1384
Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI
Feeder No / Name : 407 / 33KV Atlanta Feeder (T/F 1) Feeder KV- 33 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7721	2.6326	2.7435	
2	2.1491	2.6326	2.5149	
3	2.1719	2.6326	2.572	
4	2.7149	2.6326	2.572	
5	3.2922	3.1927	2.572	
6	3.3265	3.3608	3.315	
7	3.9209	3.7146	3.5437	
8	3.8809	3.9209	3.8866	
9	3.9209	3.8809	10.6424	3.8809
10	3.8409	3.638	10.0823	3.2922
11	3.4568	3.5437		3.2579
12	3.4568	3.315	10.0823	2.6863
13	3.4568	3.315	7.8418	2.6863
14	2.1948	2.8578	7.8418	2.7149
15	3.4568	2.9721	7.2817	2.6863
16	3.1602	3.315	7.2817	2.6863
17	3.2922	3.4294	7.2817	2.7149
18	3.4928	4.0009	9.5222	3.8409
19	3.8009	4.0009	10.0823	3.8409
20	3.8809	3.5437	10.6424	3.8409
21	3.8809	3.4294	21.0048	3.3265
22	3.4928	3.4294	8.4019	3.2922
23	2.9687	2.9721	7.2817	2.7149
24	2.8006		2.8578	
Max	**3.9209**	**4.0009**	**21.0048**	**3.8809**
Min	**2.1491**	**2.6326**	**2.5149**	**2.6863**
Avg	**3.2826**	**3.3201**	**7.0369**	**3.1642**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
BARSHI (U) S/DN.[090] BU 1384
Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI
Feeder No / Name : 408 / 33KV Atlanta Feeder (T/F 2) Feeder KV- 33 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.4353	4.357	4.1724	
2	3.8809	4.357	4.1152	
3	3.8409	4.357	4.0581	
4	4.4353	4.357	4.0581	
5	4.481	4.5268	4.0009	
6	5.0412	4.9228	4.6868	
7	5.6584	5.0926	4.5725	
8	5.6584	5.0926	4.5725	
9	5.0926	5.0412	11.7627	5.0412
10	5.6584	5.2092	10.6424	4.9897
11	5.156	5.7156	12.3228	4.9383
12	5.5441	4.0009		5.5441
13	5.2092	4.8583	11.2026	4.9383
14	4.481	4.6868	10.6424	4.4353
15	5.4332	5.2584		4.9383
16	5.4332	5.7156		5.487
17	5.7693	5.7156	10.3624	5.5441
18	6.2243	6.4015	10.9225	5.5441
19	5.7693	5.7156	11.4826	5.6013
20	5.4332	5.2584	11.4826	5.0926
21	5.0926	4.6868	10.9225	5.0926
22	4.6965	4.6868	9.2421	4.5268
23	4.6965	4.6296	8.682	
24	4.5268	4.5268	4.1724	
Max	**6.2243**	**6.4015**	**12.3228**	**5.6013**
Min	**3.8409**	**4.0009**	**4.0009**	**4.4353**
Avg	**5.0687**	**4.9654**	**8.0037**	**5.1224**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
JEUR SUB-DIVISION[757] BU 4757
Substation No/ Name :- 274010 / 33/11 KV SUBSTATION JEUR (SO J
Feeder No / Name : 201 / 11 KV JEUR URBAN GAONTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
23	.5316						
24		.5316	.5258	.5316	.443	.4382	.443
Max	**.5316**	**.5316**	**.5258**	**.5316**	**.443**	**.4382**	**.443**
Min	**.5316**	**.5316**	**.5258**	**.5316**	**.443**	**.4382**	**.443**
Avg	**.5316**	**.5316**	**.5258**	**.5316**	**.443**	**.4382**	**.443**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
JEUR SUB-DIVISION[757] BU 4757
Substation No/ Name :- 274010 / 33/11 KV SUBSTATION JEUR (SO J
Feeder No / Name : 203 / 11 KV DAHIGAON-SHETFAL AG SEPARATED AG FEEDERS HAVING SPECIAL Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.8233	1.8442	1.8442	1.7604	1.5927	.1677	.0848
Max	**1.8233**	**1.8442**	**1.8442**	**1.7604**	**1.5927**	**.1677**	**.0848**
Min	**1.8233**	**1.8442**	**1.8442**	**1.7604**	**1.5927**	**.1677**	**.0848**
Avg	**1.8233**	**1.8442**	**1.8442**	**1.7604**	**1.5927**	**.1677**	**.0848**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
JEUR SUB-DIVISION[757] BU 4757
Substation No/ Name :- 274010 / 33/11 KV SUBSTATION JEUR (SO J
Feeder No / Name : 204 / 11 KV DAHIGAON W/S EXPRESS Feeder KV- 11 / OUTGOING NON SHEDDABLE WATER SUPPLY AND UTILITY

DATE	15-DEC-17	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.3506	.1753	.2629	.2658	.2629	.2658
Max	**.3506**	**.1753**	**.2629**	**.2658**	**.2629**	**.2658**
Min	**.3506**	**.1753**	**.2629**	**.2658**	**.2629**	**.2658**
Avg	**.3506**	**.1753**	**.2629**	**.2658**	**.2629**	**.2658**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
JEUR SUB-DIVISION[757] BU 4757
Substation No/ Name :- 274011 / 33/11 KV SUBSTATION KANDAR (S
Feeder No / Name : 205 / 11 KV WADSHIWANE-SATOLI SEPARATED AG FEEDERS HAVING SPECIAL AG Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.1829	.1829	.1829	.1829	.1524	.1829	.9145
9	.1524	.2134	.1829	.1829	.1524	.1829	.8383
10	.2134	.1829	.2134	.1829	.1524	.1829	.9145
11	.9145	.9145	.9907	.8383	.7621		.1829
12	.9145	.9145	.9907	.9145	.9145		.1829
13	.9145	.8383	.9145	.9145	.9145		.1829
14	.9145	.9145	.8383	.9907	.9145		.1829
Max	**.9145**	**.9145**	**.9907**	**.9907**	**.9145**	**.1829**	**.9145**
Min	**.1524**	**.1829**	**.1829**	**.1829**	**.1524**	**.1829**	**.1829**
Avg	**.6010**	**.5944**	**.6162**	**.6010**	**.5661**	**.1829**	**.4856**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
JEUR SUB-DIVISION[757] BU 4757
Substation No/ Name :- 274011 / 33/11 KV SUBSTATION KANDAR (S
Feeder No / Name : 206 / 11 KV KANDAR VILLAGE AG Feeder KV- 11 / OUTGOING SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.8383	.8383	.9145		.8383	.9907	.1829
9	.9145	.8383	.9907		.8383	.9907	.1829
10	.8383	.8383	.8383		.9907	.7621	.1829
11	.2134	.1829	.1829		.1829		.9145
12	.1829	.1829	.1829		.1829		.8383
13	.1829	.1829	.1829		.1829		.8383
14	.1829	.1829	.1829	.1829	.1829		.8383
Max	**.9145**	**.8383**	**.9907**	**.1829**	**.9907**	**.9907**	**.9145**
Min	**.1829**	**.1829**	**.1829**	**.1829**	**.1829**	**.7621**	**.1829**
Avg	**.4790**	**.4638**	**.4964**	**.1829**	**.4856**	**.9145**	**.5683**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
JEUR SUB-DIVISION[757] **BU 4757**
Substation No/ Name :- 274011 / 33/11 KV SUBSTATION KANDAR (S
Feeder No / Name : 207 / 11 KV HARITKRANTI AG EXPRESS F Feeder KV- 11 / OUTGOING **PURELY LIS FEEDERS**

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.1219	.0762	.0762	.1219	.0762	.0762	.1219
9	.1219	.0762	.0762	.0762	.0762	.0762	.1219
10	.0762	.0762		.0762	.0762	.0762	.0762
11					.0762		.1219
12							.1219
13							.1219
14	.1219						.1219
Max	**.1219**	**.0762**	**.0762**	**.1219**	**.0762**	**.0762**	**.1219**
Min	**.0762**	**.0762**	**.0762**	**.0762**	**.0762**	**.0762**	**.0762**
Avg	**.1105**	**.0762**	**.0762**	**.0914**	**.0762**	**.0762**	**.1154**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
JEUR SUB-DIVISION[757] BU 4757
Substation No/ Name :- 274011 / 33/11 KV SUBSTATION KANDAR (S
Feeder No / Name : 208 / 11 KV KANDAR BACKWATER AG Feeder KV- 11 / OUTGOING SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.9907	.9907	.9907	.9907	.9907	.9907	.1829
9	.8383	.9907	.9907	.8383	.8383	.9907	.1829
10	.9907	.8383	.9907	.9907	.9907	.8383	.1829
11	.1829	.1829	.1829	.1829	.1829		.9907
12	.1829	.2134	.1829	.1829	.1829		.8383
13	.1829	.2134	.1829	.1829	.1829		.8383
14	.1829	.1829	.1829	.1829	.1524		.8383
Max	**.9907**	**.9907**	**.9907**	**.9907**	**.9907**	**.9907**	**.9907**
Min	**.1829**	**.1829**	**.1829**	**.1829**	**.1524**	**.8383**	**.1829**
Avg	**.5073**	**.5160**	**.5291**	**.5073**	**.5030**	**.9399**	**.5792**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
JEUR SUB-DIVISION[757] BU 4757
Substation No/ Name :- 274013 / 33/11 KV SUBSTATION KEM (SO KA
Feeder No / Name : 201 / 11 KV KEM GAONTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17
HR	Load (MW)
1	.3961
2	.3772
3	.415
4	.3961
5	.4527
6	.4904
7	.4527
24	.3772
Max	**.4904**
Min	**.3772**
Avg	**.4197**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
JEUR SUB-DIVISION[757] **BU 4757**
Substation No/ Name :- 274013 / 33/11 KV SUBSTATION KEM (SO KA
Feeder No / Name : 202 / 11 KV WADSHIVANE AG SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17
HR	Load (MW)
1	.3461
2	.3182
3	2.0435
4	2.0765
5	2.1754
6	2.2248
7	2.2413
8	2.2413
24	.3296
Max	**2.2413**
Min	**.3182**
Avg	**1.5552**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
JEUR SUB-DIVISION[757] **BU 4757**
Substation No/ Name :- 274013 / 33/11 KV SUBSTATION KEM (SO KA
Feeder No / Name : 203 / 11 KV MALAWADI AG SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17
HR	Load (MW)
1	.4285
2	.3955
3	.3626
4	.3461
5	.3617
6	.3804
7	.427
8	.4614
24	.4614
Max	**.4614**
Min	**.3461**
Avg	**.4027**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
JEUR SUB-DIVISION[757] BU 4757
Substation No/ Name :- 274013 / 33/11 KV SUBSTATION KEM (SO KA
Feeder No / Name : 205 / 11 KV UPALWATE AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	18-DEC-17
HR	Load (MW)	Load (MW)
1		.3296
2		.3296
3		.3296
4		.3296
5		.3296
6		.3296
7		.3296
8		.3296
11	1.4832	
12	1.4832	
13	1.4832	
14	1.4832	
15	1.4832	
16	1.4832	
24		.3296
Max	**1.4832**	**.3296**
Min	**1.4832**	**.3296**
Avg	**1.4832**	**.3296**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
JEUR SUB-DIVISION[757] BU 4757
Substation No/ Name :- 274013 / 33/11 KV SUBSTATION KEM (SO KA
Feeder No / Name : 206 / 11 KV KEM VILLAGE AG SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	18-DEC-17
HR	Load (MW)	Load (MW)
3		.3296
4		.3296
5		.3296
6		.3296
7		.3296
8		.3296
9	.3296	
10	.3296	
Max	**.3296**	**.3296**
Min	**.3296**	**.3296**
Avg	**.3296**	**.3296**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
JEUR SUB-DIVISION[757] **BU 4757**
Substation No/ Name :- 274145 / 33/11 KV SUBSTATION UMRAD (SO
Feeder No / Name : 201 / 11 KV UMRAD-KUMBHEJ GAOTHAN FEEDER GAONTHAN Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
23			.463		.4801		
24	.4191	.5144		.4527		.4287	.4287
Max	**.4191**	**.5144**	**.463**	**.4527**	**.4801**	**.4287**	**.4287**
Min	**.4191**	**.5144**	**.463**	**.4527**	**.4801**	**.4287**	**.4287**
Avg	**.4191**	**.5144**	**.463**	**.4527**	**.4801**	**.4287**	**.4287**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
JEUR SUB-DIVISION[757] **BU 4757**
Substation No/ Name :- 274145 / 33/11 KV SUBSTATION UMRAD (SO
Feeder No / Name : 203 / 11 KV BHAIRAVNATH AG Feeder KV- 11 / OUTGOING **SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER**

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.7545	.7545	.7545	.6706	.7545	.6706	.0838
Max	**.7545**	**.7545**	**.7545**	**.6706**	**.7545**	**.6706**	**.0838**
Min	**.7545**	**.7545**	**.7545**	**.6706**	**.7545**	**.6706**	**.0838**
Avg	**.7545**	**.7545**	**.7545**	**.6706**	**.7545**	**.6706**	**.0838**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
JEUR SUB-DIVISION[757] BU 4757
Substation No/ Name :- 274145 / 33/11 KV SUBSTATION UMRAD (SO
Feeder No / Name : 204 / 11 KV UMRAD AG Feeder KV- 11 / OUTGOING SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0838	.0838	.0838	.0838	.0838	.0838	.0838
Max	**.0838**	**.0838**	**.0838**	**.0838**	**.0838**	**.0838**	**.0838**
Min	**.0838**	**.0838**	**.0838**	**.0838**	**.0838**	**.0838**	**.0838**
Avg	**.0838**	**.0838**	**.0838**	**.0838**	**.0838**	**.0838**	**.0838**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
JEUR SUB-DIVISION[757] BU 4757
Substation No/ Name :- 274145 / 33/11 KV SUBSTATION UMRAD (SO
Feeder No / Name : 205 / 11 KV BHAIRAVNATH NEW AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.7545	.7545	.7545	.8383	.9221	.5868	.0503
Max	**.7545**	**.7545**	**.7545**	**.8383**	**.9221**	**.5868**	**.0503**
Min	**.7545**	**.7545**	**.7545**	**.8383**	**.9221**	**.5868**	**.0503**
Avg	**.7545**	**.7545**	**.7545**	**.8383**	**.9221**	**.5868**	**.0503**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
JEUR SUB-DIVISION[757] BU 4757
Substation No/ Name :- 274145 / 33/11 KV SUBSTATION UMRAD (SO
Feeder No / Name : 206 / 11 KV SOGAON NEW AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
23					.0503		.8383
24	.0503	.0503	.0503	.0503		.0503	
Max	.0503	.0503	.0503	.0503	.0503	.0503	.8383
Min	.0503	.0503	.0503	.0503	.0503	.0503	.8383
Avg	.0503	.0503	.0503	.0503	.0503	.0503	.8383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
JEUR SUB-DIVISION[757] BU 4757
Substation No/ Name :- 274145 / 33/11 KV SUBSTATION UMRAD (SO
Feeder No / Name : 207 / 11 KV POPHALAJ-KUMBHEJ AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.0503
24	.0503	.0503	.0503	.0503	.0503	.0503	
Max	**.0503**	**.0503**	**.0503**	**.0503**	**.0503**	**.0503**	**.0503**
Min	**.0503**	**.0503**	**.0503**	**.0503**	**.0503**	**.0503**	**.0503**
Avg	**.0503**	**.0503**	**.0503**	**.0503**	**.0503**	**.0503**	**.0503**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
JEUR SUB-DIVISION[757] BU 4757
Substation No/ Name :- 274163 / 33/11 KV SUSTATION DAHIGAON (S
Feeder No / Name : 202 / 11 KV Dahigaon AG Feeder KV- 11 / OUTGOING SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.4575	1.3717	1.6289	.0857	.0857
Max	**1.4575**	**1.3717**	**1.6289**	**.0857**	**.0857**
Min	**1.4575**	**1.3717**	**1.6289**	**.0857**	**.0857**
Avg	**1.4575**	**1.3717**	**1.6289**	**.0857**	**.0857**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
JEUR SUB-DIVISION[757] BU 4757
Substation No/ Name :- 274163 / 33/11 KV SUSTATION DAHIGAON (S
Feeder No / Name : 203 / 11 KV SHETPHAL AG Feeder KV- 11 / OUTGOING SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0857	.0857	.0857	1.2003	1.2003
Max	**.0857**	**.0857**	**.0857**	**1.2003**	**1.2003**
Min	**.0857**	**.0857**	**.0857**	**1.2003**	**1.2003**
Avg	**.0857**	**.0857**	**.0857**	**1.2003**	**1.2003**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
JEUR SUB-DIVISION[757] BU 4757
Substation No/ Name :- 274163 / 33/11 KV SUSTATION DAHIGAON (S
Feeder No / Name : 204 / 11 KV WANGI-2 AG SEPARATED AG FEEDERS HAVING SPECIAL Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0857	.0857	.0857	.0857	.0857
Max	**.0857**	**.0857**	**.0857**	**.0857**	**.0857**
Min	**.0857**	**.0857**	**.0857**	**.0857**	**.0857**
Avg	**.0857**	**.0857**	**.0857**	**.0857**	**.0857**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
JEUR SUB-DIVISION[757] BU 4757
Substation No/ Name :- 274179 / 33/11 KV SUBSTATION KAVITGAON
Feeder No / Name : 202 / 11 KV YASHOBA AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
23	.2555	.2589	.2263	.1955	.2109
24		.2435	.2606	.2452	.1955
Max	**.2555**	**.2589**	**.2606**	**.2452**	**.2109**
Min	**.2555**	**.2435**	**.2263**	**.1955**	**.1955**
Avg	**.2555**	**.2512**	**.2435**	**.2204**	**.2032**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
JEUR SUB-DIVISION[757] **BU 4757**
Substation No/ Name :- 274179 / 33/11 KV SUBSTATION KAVITGAON
Feeder No / Name : 204 / 11 KV SANGAVI NO.2 AG **FEEDER SEPERATION/PURE AG**
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
23	.036	.0309	.0189	.0412	.0394
24		.036	.0309	.0189	.0394
Max	.036	.036	.0309	.0412	.0394
Min	.036	.0309	.0189	.0189	.0394
Avg	.036	.0335	.0249	.0301	.0394

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KARMALA S/DN.[093] BU 1376
Substation No/ Name :- 274014 / 33/11 KV MANGI S/S
Feeder No / Name : 229 / 11 WADGAON/BOSE AG SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0762	.0953	.0572	.0762
2		.0762	.0572	.0572	.0762
3		.0762	.0572	.724	.8192
4		.0953	.0762	.7621	.8954
5		.1143	.0762	.9526	.9717
6		.1334	.0953	1.0098	1.1812
7		.1524	.0953	1.0479	1.2574
8		.1334	.0953	1.2003	1.4289
9		.0953	.0762	1.2193	
10		.0572	.0762	1.2003	
11		1.3527	1.3336		
12		1.5623	1.4289		
13			1.5242		
14			1.4861		
15			.9145		
16			.9335		
17			1.4098		
18			1.2765		
19			.1143	.1334	.0762
20		.1143	.1143	.1143	.0762
21	.0953	.1143	.0953	.0953	.0762
22	.0953	.0953	.0953	.0953	.0572
23	.0762	.0953	.0762	.0953	.0572
24		.0762	.0953	.0572	.0762
Max	**.0953**	**1.5623**	**1.5242**	**1.2193**	**1.4289**
Min	**.0762**	**.0572**	**.0572**	**.0572**	**.0572**
Avg	**.0889**	**.2600**	**.4874**	**.5513**	**.5090**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KARMALA S/DN.[093] **BU 1376**
Substation No/ Name :- 274014 / 33/11 KV MANGI S/S
Feeder No / Name : 230 / 11 KV MANGI AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2058	.2572	.2401	.2058
2		.2229	.2572	.2229	.2229
3		.4458	.4287	.6859	1.4575
4		.5487	.4801	1.1145	1.6804
5		.6001	.6859	2.4006	1.7833
6		.6687	.7716	2.8292	2.3834
7		.7373	.8573	2.8978	2.9321
8		.6516	.823	3.275	3.3608
9		.5144	.7373	3.2236	3.618
10		.4458	.6173	2.8464	3.2065
11		2.8635	3.035	.3601	.4115
12		3.7037	3.4294	.4287	.4973
13			3.6694	.4973	.4801
14			3.4294		.4801
15			3.2236		.4973
16					.5144
17			3.4979		.5316
18			3.0521		.4458
19			.3086	.3601	.3258
20		.3429	.2915	.3429	.3258
21	.3086	.3258	.2401	.2915	.3258
22	.2572	.2915	.2401	.2572	.2743
23	.2401	.2743	.2401	.2401	.2572
24		.2229	.2743	.2401	.2229
Max	**.3086**	**3.7037**	**3.6694**	**3.275**	**3.618**
Min	**.2401**	**.2058**	**.2401**	**.2229**	**.2058**
Avg	**.2686**	**.7686**	**1.3412**	**1.1976**	**1.1017**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KARMALA S/DN.[093] BU 1376
Substation No/ Name :- 274014 / 33/11 KV MANGI S/S
Feeder No / Name : 231 / 11 KV PUNWAR AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.5487	.5144		
4	.5658	.6001		
5	.6001	.6859		
6	.6687	.7716		
7	.823	.7716		
8	.9088	.823		
9	.8916	.823		
10	.8573	.7545		
11			.8402	.8573
12			.8916	.9602
13			.9602	.7888
14				.823
15				.8573
16				.9259
17				.8916
18				.0686
Max	**.9088**	**.823**	**.9602**	**.9602**
Min	**.5487**	**.5144**	**.8402**	**.0686**
Avg	**.733**	**.7180**	**.8973**	**.7716**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KARMALA S/DN.[093] **BU 1376**
Substation No/ Name :- 274014 / 33/11 KV MANGI S/S
Feeder No / Name : 241 / 11KV GFSS Mangi **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0532	.124	.1063	.0532
2		.0532	.1063	.1063	.0532
3		.0532	.0886	.1063	.0532
4		.1063	.1417	.1772	.1063
5		.2126	.2658	.2572	.1417
6		.5316	.3544	.3429	.2126
7		.4961	.4287	.443	.4607
8		.3189	.2658	.2481	.3189
9		.2658	.2126	.2481	.1772
10		.1772	.1772	.2126	.1772
11		.0709	.1063	.1063	
12		.0709	.0709	.0709	.1063
13			.0709	.0709	.0709
14			.0709	.0709	.0709
15			.0709		.0709
16				.0709	.0709
17			.0709		.1063
18			.1417		.1949
19			.4252	.5316	.4784
20		.2835	.3189	.4252	.3189
21	.2126	.2743	.2126	.3189	.2126
22	.1772	.1417	.2126	.1417	.2058
23	.1417	.1417	.1772	.1063	.2126
24		.1063	.1417	.1417	.0886
Max	**.2126**	**.5316**	**.4287**	**.5316**	**.4784**
Min	**.1417**	**.0532**	**.0709**	**.0709**	**.0532**
Avg	**.1772**	**.1975**	**.1850**	**.2049**	**.1723**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KARMALA S/DN.[093] **BU 1376**
Substation No/ Name :- 274015 / 33/11 KV MANJARGAON S/S
Feeder No / Name : 235 / 11KV MANJARGAON GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17
HR	Load (MW)	Load (MW)
1		.1905
2		.1905
3		.1905
4		.2667
5		.3429
6		.381
7		.3429
8	.3429	.2667
9	.2667	.1524
10		.3048
11		.2286
12		.2286
13		.2286
15		.2667
16		.3048
17		.1905
18		.2286
19		.2667
20		.2286
21		.2286
22		.1905
23		.1905
24		.1905
Max	**.3429**	**.381**
Min	**.2667**	**.1524**
Avg	**.3048**	**.2435**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KARMALA S/DN.[093] BU 1376
Substation No/ Name :- 274016 / 33/11 KV PAREWADI S/S
Feeder No / Name : 240 / 11KV POMALWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4					1.829
16	2.3167	2.2862	2.5149	2.4996	
20	2.3167	2.2862	2.4539	2.332	
24					1.7985
Max	**2.3167**	**2.2862**	**2.5149**	**2.4996**	**1.829**
Min	**2.3167**	**2.2862**	**2.4539**	**2.332**	**1.7985**
Avg	**2.3167**	**2.2862**	**2.4844**	**2.4158**	**1.8138**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KARMALA S/DN.[093] **BU 1376**
Substation No/ Name :- 274087 / 33/11 KV JINTI S/S
Feeder No / Name : 253 / 11 KV JINTI AG **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2955	1.2193	1.448	1.3717	1.3717
2	1.6766	1.7528	1.6766	1.829	1.6766
3	1.6766	1.829	2.2862	1.829	1.829
4	1.9814	1.9814	2.4387	2.2862	
5	2.2862	2.2862	2.5911	2.4387	
6	2.5911	2.4387	2.8959	2.8959	
7	3.0483	2.5911	2.8197	2.8959	
8	2.8959	2.7435	3.0483	2.9721	
9	.7621	.8383	.7621	.8383	
10	.5335	.7621	.6097	.4572	
11		.4572	.3048	.6097	
12	.3048	.381	.381	.381	
13	.3048	.381	.1524	.381	
14	.3048	.4572	.3048	.381	
15	.3048	.381	.3048	.381	
16	.3048	.4572	.3048	.381	
17	.3048	.3048	.381	.5335	
18	.4572	.6097	.6859	.6859	
19	.5335	.9145	.9907	.7621	
20	.7621	1.0669	.7621	.7621	
21	.7621	.6859	.6859	.6859	
22	.6859	.5335	.5335	.6097	
23	.4572	.4572	.4572	.4572	
24	.4572	.4572	.5335	.381	.4572
Max	**3.0483**	**2.7435**	**3.0483**	**2.9721**	**1.829**
Min	**.3048**	**.3048**	**.1524**	**.381**	**.4572**
Avg	**1.0735**	**1.0828**	**1.1399**	**1.1336**	**1.3336**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KARMALA S/DN.[093] **BU 1376**
Substation No/ Name :- 274087 / 33/11 KV JINTI S/S
Feeder No / Name : 256 / 11 KV TAKALI AG **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0762	.0762
2	.0762	.0762	.0762	.0762
3	.0762	.0762	.0762	
4	.0762	.0762	.0762	
5	.0762	.0762	.0762	
6	.0762	.0762	.0762	
7	.0762	.0762	.0762	
8	.0762	.0762	.0762	
9	.0762	.0762	.0762	
10	.0762	.0762	.0762	
11	.0762	.0762	.0762	
12	.0762	.0762	.0762	
13	.0762	.0762	.0762	
14	.0762	.0762	.0762	
15	.0762	.0762	.0762	
16	.0762	.0762	.0762	
17	.381	.4572	.5335	
18	.4572	.5335	.5335	
19	.5335	.2858	.4572	
20	.381	.6097	.4572	
21	.381	.4572	.381	
22	.381	.4572	.4572	
23	.381	.5335	.381	
24	.4572	.3048	.4572	.381
Max	**.5335**	**.6097**	**.5335**	**.381**
Min	**.0762**	**.0762**	**.0762**	**.0762**
Avg	**.1905**	**.2024**	**.2032**	**.1778**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KARMALA S/DN.[093] BU 1376
Substation No/ Name :- 274124 / 33/11 KV POTEGAON S/S
Feeder No / Name : 201 / 11 KV POTEGAON/TARATGAON SEPARATED AG FEEDERS HAVING SPECIAL AG Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.1524	.1524	.1524	.1524	.1524	1.2193	1.2193
16	1.0669		1.3717	1.3717			
23	.1524	.1524	.1524	.1524	.1524	.1524	.1524
24	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Max	**1.0669**	**.1524**	**1.3717**	**1.3717**	**.1524**	**1.2193**	**1.2193**
Min	**.1524**	**.1524**	**.1524**	**.1524**	**.1524**	**.1524**	**.1524**
Avg	**.3810**	**.1524**	**.4572**	**.4572**	**.1524**	**.5080**	**.5080**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KARMALA S/DN.[093] **BU 1376**
Substation No/ Name :- 274124 / 33/11 KV POTEGAON S/S
Feeder No / Name : 202 / 11KV Borgaon AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.3717	1.829	1.0669	1.6766	1.3717	.1524	.1524
16							1.829
23	.1524	.1524	.1524	.1524	.1524	.1524	.1524
24	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Max	**1.3717**	**1.829**	**1.0669**	**1.6766**	**1.3717**	**.1524**	**1.829**
Min	**.1524**	**.1524**	**.1524**	**.1524**	**.1524**	**.1524**	**.1524**
Avg	**.5588**	**.7113**	**.4572**	**.6605**	**.5588**	**.1524**	**.5716**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KARMALA S/DN.[093] BU 1376
Substation No/ Name :- 274124 / 33/11 KV POTEGAON S/S
Feeder No / Name : 203 / 11KV Ghargaon/ Padali AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.7621	1.0669	1.0669	1.2193	1.2193	.1524	.1524
16							1.2193
23	.1524	.1524	.1524	.1524	.1524	.1524	.1524
24	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Max	**.7621**	**1.0669**	**1.0669**	**1.2193**	**1.2193**	**.1524**	**1.2193**
Min	**.1524**	**.1524**	**.1524**	**.1524**	**.1524**	**.1524**	**.1524**
Avg	**.3556**	**.4572**	**.4572**	**.5080**	**.5080**	**.1524**	**.4191**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KARMALA S/DN.[093] BU 1376
Substation No/ Name :- 274124 / 33/11 KV POTEGAON S/S
Feeder No / Name : 242 / 11KV GFSS Potegaon GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.1524	.1829	.1524	.1677	.1829	.1829	.1829
16	.0914	.0914	.1219	.1219	.0914		.1067
23	.1219	.1219	.1372	.1219	.1524	.1524	.1524
24	.1524	.1219	.1219	.1219	.1219	.1524	.1219
Max	**.1524**	**.1829**	**.1524**	**.1677**	**.1829**	**.1829**	**.1829**
Min	**.0914**	**.0914**	**.1219**	**.1219**	**.0914**	**.1524**	**.1067**
Avg	**.1295**	**.1295**	**.1334**	**.1334**	**.1372**	**.1626**	**.1410**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KARMALA S/DN.[093] **BU 1376**
Substation No/ Name :- 274210 / 33/11 KV JATEGAON SUB STATION
Feeder No / Name : 201 / JATEGAON GAOTHAN **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17
HR	Load (MW)	Load (MW)
1		.104
2		.0914
3		.1094
4		.1219
5		.1562
6		.192
7		.1698
17	.0926	
18	.1219	
24		.1054
Max	**.1219**	**.192**
Min	**.0926**	**.0914**
Avg	**.1073**	**.1313**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KARMALA S/DN.[093] **BU 1376**
Substation No/ Name :- 274210 / 33/11 KV JATEGAON SUB STATION
Feeder No / Name : 202 / WADGAON AG FEEDER **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	18-DEC-17	19-DEC-17
HR	Load (MW)	Load (MW)
1		.0743
2		.0743
3		.8688
4		.9482
5		1.0669
6		1.1439
7		1.2346
17	.0743	
18	.104	
24		.0753
Max	**.104**	**1.2346**
Min	**.0743**	**.0743**
Avg	**.0892**	**.6858**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KARMALA S/DN.[093] **BU 1376**
Substation No/ Name :- 274210 / 33/11 KV JATEGAON SUB STATION
Feeder No / Name : 203 / KHADAKI AG FEEDER **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	18-DEC-17	19-DEC-17
HR	Load (MW)	Load (MW)
1		.1204
2		.1054
3		.1067
4		.1219
5		.1635
6		.1981
7		.1806
17	1.8534	
18	1.752	
24		.1219
Max	**1.8534**	**.1981**
Min	**1.752**	**.1054**
Avg	**1.8027**	**.1398**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KARMALA S/DN.[093] BU 1376
Substation No/ Name :- 274211 / HINGANI SUB STATION
Feeder No / Name : 202 / 11 KV MAKAI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0823	.1067	.1067	.1021
2	.0823	.1067	.1097	
3	.0945	.1097	.1097	.1036
4	.0975	.1097	.1097	.1021
5	.1006		.1128	.1036
6	.1006	.1158	.1219	.1143
7	.0781	.128	.128	.1219
8	.1417	.1494	.1494	.128
9	.1524	.1524	.1494	.1219
10	.1524	.1494	.1463	.1189
16	.0122			
Max	**.1524**	**.1524**	**.1494**	**.128**
Min	**.0122**	**.1067**	**.1067**	**.1021**
Avg	**.0995**	**.1253**	**.1244**	**.1129**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KARMALA S/DN.[093] BU 1376
Substation No/ Name :- 274212 / 33/11Kv Korti Substation
Feeder No / Name : 201 / 11 KV RAJURI AG SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.2126	.2126	.2279	.3052	.2743
4	1.8576	2.1399	1.8212	1.5242	.3688	.3521
6	2.4291	2.472	2.5006	1.709	.4359	.503
8	2.6703	2.5789	2.6564	1.9319	.547	.5365
10	2.0719	2.4006	2.2862	1.4737		.4359
12	.1949	.2658	.2401	.3052		2.0005
14	.2481	.2481	.2743	.2915		2.1434
16	.2629	.2835	.2713	.3185		2.0576
18	.2454	.4024	.3185	.3521		2.2114
20	.2915	.4024	.3521	.3353		.3521
22	.2303	.2401	.2629	.3222		.2572
24		.2303	.2303	.2279	.3052	.2481
Max	**2.6703**	**2.5789**	**2.6564**	**1.9319**	**.547**	**2.2114**
Min	**.1949**	**.2126**	**.2126**	**.2279**	**.3052**	**.2481**
Avg	**1.0502**	**.9897**	**.9522**	**.7516**	**.3924**	**.9477**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KARMALA S/DN.[093] BU 1376
Substation No/ Name :- 274212 / 33/11Kv Korti Substation
Feeder No / Name : 202 / 11KV KORTI GAOTHAN SEPARATED GAOTHAN FEEDERS
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.0724	.0724	.0732	.0732	.0732
4	.1267	.1463	.0905	.1463	.1448	.0914
6	.1991	.2103	.181	.2103	.2172	.1791
8	.181	.2103	.2126	.181	.1928	.1949
10	.1267	.1463	.1448			.1086
12	.1267	.1448	.1086	.0914		.1267
14	.0914	.1086	.0914	.0905		.1086
16	.0914	.1086	.0914	.0905		.1267
18	.181		.1267	.1629		.1772
20	.1629	.1448	.1646	.1629		.1448
22	.1086	.181	.1086	.1267		.0905
24		.0905	.0905	.0905	.0905	.0914
Max	**.1991**	**.2103**	**.2126**	**.2103**	**.2172**	**.1949**
Min	**.0914**	**.0724**	**.0724**	**.0732**	**.0732**	**.0732**
Avg	**.1396**	**.1422**	**.1236**	**.1297**	**.1437**	**.1261**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KARMALA S/DN.[093] BU 1376
Substation No/ Name :- 274212 / 33/11Kv Korti Substation
Feeder No / Name : 203 / 11 KV GOREWADI AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.128	.1086	.1267	.1448	.1267
4	.1646	.181	.1629	.181	.9374	.9069
6	.2303	.2303	.2454	.2683	1.1431	1.4632
8	.2658	.2572	.3052	.2883	1.5935	1.8278
10	.1629		.2303	.1629		.8855
12	1.6255	1.387	1.6404	1.3123		.1267
14	1.7535	1.7833	1.8442	1.4449		.1448
16	1.7147	1.7911	1.6872	1.3717		.1267
18	1.4043	1.4373	1.5546	1.2193		.1772
20	.1646	.2149	.1772	.181		.2303
22	.1448	.1646	.1629	.1629		.1267
24		.1097	.1097	.128	.1448	.1267
Max	**1.7535**	**1.7911**	**1.8442**	**1.4449**	**1.5935**	**1.8278**
Min	**.1448**	**.1097**	**.1086**	**.1267**	**.1448**	**.1267**
Avg	**.7631**	**.6986**	**.6857**	**.5706**	**.7927**	**.5224**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KARMALA S/DN.[093] BU 1376
Substation No/ Name :- 274220 / 33/11 KV ZARE SUBSTATION
Feeder No / Name : 201 / 11KV ZARE AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	1.1888	1.2936	.823	1.0277	.924		
11						.6767	1.0242
18	.4572	.4344	.4572	.439	.4481	.9492	.9979
23	.4435	.4119	.4481	.4251	.4075	.4163	.4207
24	.4294	.4207	.3898	.4294	.439	.3944	.4344
Max	**1.1888**	**1.2936**	**.823**	**1.0277**	**.924**	**.9492**	**1.0242**
Min	**.4294**	**.4119**	**.3898**	**.4251**	**.4075**	**.3944**	**.4207**
Avg	**.6297**	**.6402**	**.5295**	**.5803**	**.5547**	**.6092**	**.7193**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KARMALA S/DN.[093] BU 1376
Substation No/ Name :- 274220 / 33/11 KV ZARE SUBSTATION
Feeder No / Name : 202 / 11 KV KHADKEWADI AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7						2.4291	
10						1.5844	2.6783
11	3.1741	2.1472	2.4209	2.1033	2.6595		
18	2.1132	2.809	2.1472	2.4646	2.4272		.3696
23	.3982	.2926	.2987	.2926	.362	.2303	.2507
24	.2195	.3696	.2715	.3258	.3121	.3429	.2126
Max	**3.1741**	**2.809**	**2.4209**	**2.4646**	**2.6595**	**2.4291**	**2.6783**
Min	**.2195**	**.2926**	**.2715**	**.2926**	**.3121**	**.2303**	**.2126**
Avg	**1.4763**	**1.4046**	**1.2846**	**1.2966**	**1.4402**	**1.1467**	**.8778**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KARMALA S/DN.[093] BU 1376
Substation No/ Name :- 274220 / 33/11 KV ZARE SUBSTATION
Feeder No / Name : 203 / 11KV ZARE GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	.4294	.4294	.2614	.3658	.2587		.4207
11						.3174	
18	.2587	.2587	.4481	.2218	.2402	.3658	.3734
23	.3292	.1433	.2218	.1886	.2195	.1791	.3696
24	.2172	.2172	.1187	.2374	.2229	.2743	.1595
Max	**.4294**	**.4294**	**.4481**	**.3658**	**.2587**	**.3658**	**.4207**
Min	**.2172**	**.1433**	**.1187**	**.1886**	**.2195**	**.1791**	**.1595**
Avg	**.3086**	**.2622**	**.2625**	**.2534**	**.2353**	**.2842**	**.3308**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KURDUWADI S/DN.[092] **BU 1368**
Substation No/ Name :- 274024 / MAHISGAON S/STN
Feeder No / Name : 403 / Vitthal Corporation (Textile & Feeder KV- 33 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.7435	2.4691	2.524	2.3663
2		2.7938	2.5766	2.4983	2.4177
3		2.7869	2.4966	2.5486	2.6063
4		2.7641	2.6326	2.5206	2.8395
5		2.7692	2.7149	2.6292	2.7435
6		2.7435	2.7401	2.6235	2.5252
7		2.7149	2.7435	2.7343	2.3663
8		2.6326	2.7435	2.7641	2.3926
9		2.7343		2.3663	2.5514
10	2.3388	2.1605	2.1845	2.2611	2.2634
11	2.7435	2.524	2.2365	2.4983	2.524
12	2.7149	2.524	2.4446	2.5252	2.5206
13	2.6326	2.3102	2.6818	2.6063	2.4714
14	2.7343	2.5766	2.4691	2.3663	2.6337
15	2.6326	2.2028	2.4446	2.5514	2.5789
16	2.8235	2.3045	2.4691	2.5252	2.3594
17	2.1605	2.6886		2.6063	2.8006
18	2.6578	2.6886	2.3663	2.3663	2.4446
19	2.5252	2.8006	2.4446	2.7435	2.4451
20	2.5514	2.6057	2.4177	2.2885	2.4188
21	2.5789	2.6886	2.3405	2.7435	2.6863
22	2.6063	2.2885	2.3148	2.3926	2.6337
23	2.5514	2.4188	2.4966	2.4451	2.6886
24		2.7692	2.5252	2.4177	2.4177
Max	**2.8235**	**2.8006**	**2.7435**	**2.7641**	**2.8395**
Min	**2.1605**	**2.1605**	**2.1845**	**2.2611**	**2.2634**
Avg	**2.5894**	**2.5931**	**2.4979**	**2.5228**	**2.5290**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KURDUWADI S/DN.[092] BU 1368
Substation No/ Name :- 274155 / Chobe Pimpari
Feeder No / Name : 201 / Chobe Pimpari Bogda FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0533	.0686	.0667	.04	.0667	.3109	.2267
2	.0533	.0549	.0533	.04	.0667	.3334	.2534
3	.04	.0549	.0533	.0533	.0667	.3201	.2534
4	.04	.0412	.0533	.0533		.3201	.3334
5	.04	.0549	.0667	.0533	.0667	.3334	.4001
6	.04	.0549	.0533	.0533	.0667	.3201	.4001
7	.04	.0549	.0533	.0533	.0667	.3201	.4268
8	.0533	.0549	.0533	.0533	.0667	.3734	.5335
9	.0533	.0549	.0533	.0533	.0533	.4401	.5335
10	.0667	.0823	.04	.0667	.0667	.4401	.5335
11	.4134	.4572	.2934		.4134	.0667	.04
12	.5068	.5001	.4268		.4268	.0667	.04
13	.5068	.5287	.4401	.4668	.4934	.0533	.0533
14	.4268	.543	.4934	.5201	.4934		.0533
15	.4401	.5573	.4934	.5201	.5201		
16	.4001	.543	.4801	.5335	.4934		.0667
17		.5144	.4668	.5201	.4534		.0667
18	.3868	.4858	.4268	.4668	.4534		.0667
19	.08	.1143	.1067	.0934	.0934	.08	.1067
20	.08	.1	.0934	.08	.0934	.0934	.1067
21	.08	.1143	.08	.0667	.1067	.0934	.0934
22	.0667	.1143	.08	.0667	.0934	.08	.08
23	.0667	.0857	.0667	.0667	.0667	.0533	.0667
24	.0533	.0686	.0667	.0667	.0667	.0648	.0667
Max	**.5068**	**.5573**	**.4934**	**.5335**	**.5201**	**.4401**	**.5335**
Min	**.04**	**.0412**	**.04**	**.04**	**.0533**	**.0533**	**.04**
Avg	**.1734**	**.2210**	**.1900**	**.1812**	**.2111**	**.2191**	**.2088**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KURDUWADI S/DN.[092] BU 1368
Substation No/ Name :- 274155 / Chobe Pimpari
Feeder No / Name : 202 / 11KV Bogewadi AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8592	.8749	.7343	.5937	.8436	.1134	.1134
2	.8592	.8905	.8124	.7186	.8749	.1134	.1296
3	1.0155	.9686	.9374	.9217	1.3123	.1134	.1457
4	1.0936	1.0623	.9998	1.2342	1.5466	.1457	.1943
5	1.3435	1.3123	1.2811	1.3592	1.781	.1619	.2105
6	1.4998	1.5154		1.5466	1.8747	.2105	.2915
7	1.9997	1.7966	1.8747	1.6248	2.0466	.3077	.3239
8	2.0309	1.9685	2.1247	1.9997	2.3434	.3239	.2753
9	2.3122	1.9372	1.9841	1.781	2.1403	.2105	.2591
10	1.9685	1.9216	1.9997	1.7654	2.0309	.1943	.2267
11	.0937	.0937	.1562		.1094	1.5546	2.17
12		.0937	.1406		.125	2.0729	2.4453
13	.1094	.0937	.1406	.0781	.1562	2.2672	2.5911
14	.125		.1406	.1094	.1562		2.4129
15	.1094		.1406	.1562	.1718		
16	.1094		.125	.1875	.1718		2.251
17			.1562	.2031	.1406		2.5749
18	.1718		.2031	.1562	.2031		1.7976
19	.2031	.2343	.25	.2343	.2656	.2267	.2429
20	.2031	.25	.2031	.2187	.25	.2105	.2105
21	.1562	.2343	.1562	.2031	.2187	.1943	.1781
22	.125	.1718	.125	.1406	.1718	.1134	.1457
23	.1094	.1562	.1094	.125	.1406	.0972	.1134
24	.0937	.0937	.125	.1094	.125	.1296	.0972
Max	**2.3122**	**1.9685**	**2.1247**	**1.9997**	**2.3434**	**2.2672**	**2.5911**
Min	**.0937**	**.0937**	**.1094**	**.0781**	**.1094**	**.0972**	**.0972**
Avg	**.7542**	**.8247**	**.6487**	**.7030**	**.8000**	**.4611**	**.8435**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KURDUWADI S/DN.[092] BU 1368
Substation No/ Name :- 274155 / Chobe Pimpari
Feeder No / Name : 203 / GFSS chobepimpri GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0181	.0181	.0127	.0181	.0181	.0181	.0181
2	.0181	.0181	.0109	.0181	.0181	.0181	.0181
3	.0181	.0181	.0181	.0181	.0181	.0181	.0181
4	.0181	.0181	.0181	.0181	.0181	.0181	.0181
5	.0181	.0181	.0181	.0181	.0181	.0181	.0181
6	.0181	.0181	.0181	.0181	.0181		.0181
7	.0181	.0181	.0181	.0181	.0181	.0181	.0181
8	.0181	.0109	.0181	.0181	.0181	.0181	.0181
9	.0181	.0181	.0181	.0181	.0181	.0181	.0181
10	.0181	.0181	.0181	.0181	.0181	.0181	.0181
11	.0181	.0181	.0181		.0181	.0181	.0181
12	.0109	.0181	.0181		.0181	.0181	.0181
13	.0109	.0181	.0181	.0181	.0181	.0181	.0181
14	.0109	.0181	.0181	.0181	.0181		.0181
15	.0109	.0181	.0181	.0181	.0181		
16	.0109	.0181	.0181	.0145	.0181		.0109
17		.0181	.0181	.0145	.0181		.0127
18	.0181	.0181	.0181		.0181		.0181
19	.0181	.0181	.0181	.0181	.0181	.0181	.0181
20	.0181	.0181	.0181	.0181	.0181	.0181	.0175
21	.0181	.0181	.0181	.0181	.0181	.0181	.0181
22	.0181	.0181	.0181	.0181	.0181	.0181	.0181
23	.0181	.0181	.0181	.0181	.0181	.0181	.0181
24	.0181	.0181	.0181	.0181	.0181	.0181	.0181
Max	**.0181**	**.0181**	**.0181**	**.0181**	**.0181**	**.0181**	**.0181**
Min	**.0109**	**.0109**	**.0109**	**.0145**	**.0181**	**.0181**	**.0109**
Avg	**.0165**	**.0178**	**.0176**	**.0178**	**.0181**	**.0181**	**.0175**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KURDUWADI S/DN.[092] BU 1368
Substation No/ Name :- 274167 / 33/11K V PADSALI S/STn.
Feeder No / Name : 201 / PADSALI AG.(Old Butashte) SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.2278	
2		.2441	
3		.2857	
4		.3193	
5		.4201	
6		.6217	
7		.689	
9		.4881	
10		.3254	
11		1.3179	
12		1.7897	
13		1.9362	
14		1.9362	
15		1.9687	
16		1.9687	
17		1.9199	
18		1.6921	
19		.4881	
21		.2603	
22		.2441	
23	.2278	.2278	.2619
24		.2115	
Max	**.2278**	**1.9687**	**.2619**
Min	**.2278**	**.2115**	**.2619**
Avg	**.2278**	**.8901**	**.2619**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KURDUWADI S/DN.[092] BU 1368
Substation No/ Name :- 274167 / 33/11K V PADSALI S/STn.
Feeder No / Name : 202 / DHORE WASTI AG FEEDER(OLD SEPARATED AG FEEDERS HAVING SPECIAL LAUL Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1176	.1176	
2			.1344	
3		.7058	.6385	
4		.8234	.7562	
5		1.0418	1.0082	
6		1.2267	1.4283	
7		1.6972	1.1763	
8		1.8148	1.5964	
9		1.8484	1.7476	
10		1.6132	1.6468	
11			.1447	
12		.1176	.1447	
13		.1512		
14		.1512	.1286	
15		.168		
16		.1512	.3538	
17		.1512	.1447	
18		.2521	.2573	
19		.3697	.3538	
20		.3361	.2734	
21		.1848	.193	
22		.1848	.1286	
23	.1344	.1512	.1286	.1644
24		.1176	.1176	
Max	**.1344**	**1.8484**	**1.7476**	**.1644**
Min	**.1344**	**.1176**	**.1176**	**.1644**
Avg	**.1344**	**.6080**	**.5736**	**.1644**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KURDUWADI S/DN.[092] BU 1368
Substation No/ Name :- 274167 / 33/11K V PADSALI S/STn.
Feeder No / Name : 203 / GFSS Padsali GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0733	.0733	
2		.0733	.0733	
3		.0916	.0733	
4		.11	.0916	
5		.1466	.1283	
6		.1833	.165	
7		.2016	.2016	
8		.2016	.1833	
9		.165	.1833	
10		.165	.1466	
11		.1283	.11	
12		.11	.11	
13		.11	.11	
14		.11	.0916	
15		.11	.11	
16		.1283	.11	
17		.1466	.1466	
18		.165	.1466	
19		.1833	.1833	
20		.1466	.1833	
21		.11	.0916	
22		.0916	.0733	
23	.0916	.0733	.0733	.0917
24		.0733	.0733	
Max	**.0916**	**.2016**	**.2016**	**.0917**
Min	**.0916**	**.0733**	**.0733**	**.0917**
Avg	**.0916**	**.1291**	**.1222**	**.0917**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KURDUWADI S/DN.[092] BU 1368
Substation No/ Name :- 274167 / 33/11K V PADSALI S/STn.
Feeder No / Name : 204 / New BUtashte AG Feeder FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1286	.1286	
2		.1447	.1286	
3		.1608	.1608	
4		.1769	.2412	
5		.2412	.2894	
6		.3055	.3216	
7		.3377	.3859	
8		.3538	.3216	
9		.2734	.2573	
10		.209	.193	
11		1.3668	1.2864	
12		1.4472	1.5276	
13		1.608	1.608	
14		1.4472	1.4472	
15		1.608	1.608	
16		1.608	1.5276	
17		1.4472	1.608	
18		1.4472	1.4472	
19		1.4472	.2573	
20		.2412	.1286	
21		.3377	.1447	
22		.193	.1608	
23	.1449	.1608	.1447	1.1163
24		.1286		
Max	**.1449**	**1.608**	**1.608**	**1.1163**
Min	**.1449**	**.1286**	**.1286**	**1.1163**
Avg	**.1449**	**.7008**	**.6663**	**1.1163**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KURDUWADI S/DN.[092] BU 1368
Substation No/ Name :- 274167 / 33/11K V PADSALI S/STn.
Feeder No / Name : 205 / UJANI (M) AG FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.7218	1.7384	
2		1.6887	1.6556	
3		.2483	.298	
4		.2649	.3146	
5		.3311	.3808	
6		.4139	.4967	
7		.5629	.596	
8		.5464	.596	
9		.6126	.4305	
10		.3808	.4305	
11		.2318		
12		.298		
13		.298		
14		.3311		
15		.3311	.3311	
16		.3311	.3642	
17		.4305	.298	
18		.3973	.4967	
19		2.4006	2.3179	
20		2.1523	2.1523	
21		2.0695	1.9867	
22		1.9867	1.8212	
23	1.9393	1.9371	1.8212	.3266
24		1.755	1.8212	
Max	**1.9393**	**2.4006**	**2.3179**	**.3266**
Min	**1.9393**	**.2318**	**.298**	**.3266**
Avg	**1.9393**	**.9051**	**1.0174**	**.3266**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KURDUWADI S/DN.[092] BU 1368
Substation No/ Name :- 274167 / 33/11K V PADSALI S/STn.
Feeder No / Name : 206 / NEW LAUL AG FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2392	.2551	
2		.2551	.2551	
3		1.6744	1.4352	
4		1.802	1.6744	
5		2.0412	1.9136	
6		2.2325	2.392	
7		2.5833	2.5514	
8		2.5993	2.7428	
9		2.7428	2.9501	
10		2.8066	2.7109	
11		.2551	.287	
12		.2551	.2551	
13		.3189	.2551	
14		.4146	.287	
15		.4146	.3189	
16		.4465	.3189	
17		.4146	.3508	
18			.4465	
19		.5422	.5741	
20		.4784	.5103	
21		.3827	.3827	
22		.3508	.3508	
23	.2711	.287	.3189	.3097
24		.2392		
Max	**.2711**	**2.8066**	**2.9501**	**.3097**
Min	**.2711**	**.2392**	**.2551**	**.3097**
Avg	**.2711**	**1.0337**	**1.0233**	**.3097**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KURDUWADI S/DN.[092] BU 1368
Substation No/ Name :- 274188 / 33/11 KV KURDU SUBSTATION
Feeder No / Name : 201 / 11 KV PIMPALKHUNTE AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5611	.6878	.5792	.4858
2		.7421	.7602	.5792	.4525
3		1.086	.8688	.6335	.4525
4		1.8099	1.086	.6878	.543
5		1.9004	1.448	.7602	.724
6		1.9547	1.9185	.8507	.8145
7		2.0814	1.9909		
8		2.1176	2.19		
9		2.3348	2.3529	2.1776	2.1719
10	2.6244	1.9366	2.5701	2.2624	1.9909
11	2.6244	2.5882	2.8416	2.3529	1.4118
12	2.7511	2.4977	2.8959	2.3529	1.9547
13	2.9502	2.5339	2.8597	2.3529	1.9366
14	2.8416	2.1719	2.8597		1.9366
15	2.8416	2.4615	2.7149		2.0271
16	2.7149	2.4796	2.6244	2.1719	1.8642
17				2.5339	2.1719
18				2.5339	2.6244
19	.7059	.724	.7421	2.1719	2.2986
20	.6516	.6878	.6516	2.1719	1.9909
21	.6154	.6697	.6335	3.0769	1.9366
22	.5792	.6335	.6335	1.8099	1.8099
23	.5973	.5973	.5792	1.6289	1.6651
24		.5792	.5792	.5792	1.448
Max	**2.9502**	**2.5882**	**2.8959**	**3.0769**	**2.6244**
Min	**.5792**	**.5611**	**.5792**	**.5792**	**.4525**
Avg	**1.8748**	**1.5977**	**1.6586**	**1.7134**	**1.5778**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KURDUWADI S/DN.[092] BU 1368
Substation No/ Name :- 274188 / 33/11 KV KURDU SUBSTATION
Feeder No / Name : 202 / 11 KV AMBAD FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.8573	.7716	.823	.6859	1.3717	1.286
2	.6241	.9116	.7716	.8573	.7545	1.3717	1.3003
3	.8505	1.0774	.9945	.9709	.8402	1.3565	1.3717
4	1.0631	1.326	1.1022	1.3546	1.0749	1.4413	1.4575
5	1.3375	1.5432	1.5432	1.6617	1.4217	1.5261	1.7147
6	1.4582	1.6078	1.8347	1.933	1.6461	1.7147	2.0576
7	1.0174	1.9062	2.2891	1.95	2.2213	2.3739	2.3739
8	1.9448	1.9669	2.1879	1.9113	2.1195	2.2977	2.0348
9						1.8861	1.7147
10						1.8861	1.8861
11						1.8004	.9709
12						1.8004	1.8519
13							1.7147
14							2.1033
15							2.2436
16						1.7147	2.1948
17			2.713	2.2969	2.5774		
18	2.7808	2.3537	2.3205	2.3472	2.8147		
19	2.2382	2.1548	2.1026	2.1548	2.3868	.6859	1.0288
20	1.989	1.8233	1.8107	1.8896	2.1874	.6935	.6001
21	1.5249	1.6787	1.6956	1.6575	1.9033	.5144	.5144
22	1.3426	1.4737	1.5775	1.4413	1.6804	.5144	.5487
23	1.2071	1.2887	1.3717	1.286	1.406	.4334	.6173
24		.6516	.6516	.7545	.6516	1.3904	.4287
Max	**2.7808**	**2.3537**	**2.713**	**2.3472**	**2.8147**	**2.3739**	**2.3739**
Min	**.5144**	**.6516**	**.6516**	**.7545**	**.6516**	**.4334**	**.4287**
Avg	**1.4209**	**1.5081**	**1.6086**	**1.5806**	**1.6482**	**1.4091**	**1.4552**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KURDUWADI S/DN.[092] BU 1368
Substation No/ Name :- 274188 / 33/11 KV KURDU SUBSTATION
Feeder No / Name : 203 / GFSS KURDU GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3086	.3086	.3086	.3086	.3086	.2915
2	.3944	.3086	.3086	.3429	.3086	.3086	.2915
3	.4115	.3429	.3429	.3944	.3429	.3429	.3429
4	.5144	.4287	.4458	.4458	.4287	.4115	.4287
5	.5487	.5144	.5144	.5144	.5144	.5144	.5658
6	.6001	.6516	.6001	.6516	.6001	.6001	.6516
8						.4801	.5487
9	.5316	.5487	.5144	.5316	.5316	.4287	.5144
10	.463	.5144	.5316	.5144	.5144	.463	.4287
11	.463	.5487	.463	.4458	.3772	.4115	.3944
12	.3601	.3944	.4115	.3944	.3258	.4115	
13	.3429	.3772	.3601	.3944	.2915	.3429	.2743
14	.2915	.3772		.3086	.2743		.3429
15	.2229	.3429	.3086	.3086	.2743		.2915
16	.2915	.3258	.3429	.3258	.2572		.2572
17	.3429	.3429	.3086	.3086	.2743	.3772	.2915
18	.463	.463	.3429	.4458	.3944	.4801	.4458
19	.5316	.5658	.583	.5658	.5658	.6001	.5316
20	.5144	.4801	.5144	.5658	.5144	.6001	.5144
21	.463	.4287	.4458	.4973	.4287	.5144	.4801
22	.3772	.3429	.3772	.4287	.3601	.4287	.4801
23	.3601	.3086	.3772	.3944	.3429	.3429	.3601
24	.3258	.3086	.3086	.2915	.2915	.3429	.2915
Max	**.6001**	**.6516**	**.6001**	**.6516**	**.6001**	**.6001**	**.6516**
Min	**.2229**	**.3086**	**.3086**	**.2915**	**.2572**	**.3086**	**.2572**
Avg	**.4162**	**.4193**	**.4148**	**.4263**	**.3874**	**.4355**	**.4100**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KURDUWADI S/DN.[092] BU 1368
Substation No/ Name :- 274223 / DHAVLAS S/STN
Feeder No / Name : 202 / Dhavlas Bogda Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3					.1188
4					.1528
5					.1528
8					.1358
9					.1358
10					.2037
11	.1867		.1528	.2207	
12	.1358			.1698	
13	.1358		.2037	.1528	
14	.1358		.1867	.1528	
15	.1358		.1698	.1358	
16	.1358		.1867	.1528	
17	.1358	.1358	.1698	.1528	
18	.1358	.1358	.1528	.1358	
Max	**.1867**	**.1358**	**.2037**	**.2207**	**.2037**
Min	**.1358**	**.1358**	**.1528**	**.1358**	**.1188**
Avg	**.1422**	**.1358**	**.1746**	**.1592**	**.1500**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KURDUWADI S/DN.[092] **BU 1368**
Substation No/ Name :- 274223 / DHAVLAS S/STN
Feeder No / Name : 203 / jhakale-Bhogewadi Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.099	.1155	.2805
2		.099	.1155	.3135
3	1.5839	1.5839	1.2209	1.9799
4	1.7819	1.6994	1.3199	1.9964
5	1.9139	1.8149	1.5839	2.1449
6	1.9799	2.0459	1.7819	2.1284
7	2.4089	2.6398	2.3759	2.0459
8	2.5738	2.7058	2.6398	2.3099
9	2.5409	2.5738	2.4749	2.3759
10	2.4419	2.4089	2.5079	2.5409
11	.099	.1155	.198	.099
12	.1155	.099		.099
13	.1155	.099		.099
14	.099	.099	.2145	
15	.099	.099	.198	.099
16	.099	.099	.198	
17	.1155	.132	.2145	.099
18		.1815	.231	.132
19	.2145	.1815	.264	
20	.2145	.165	.198	.231
21	.165	.1485	.2145	.165
22	.1485	.132	.231	.132
23	.099	.1155	.264	.132
24	.099	.066	.099	.2475
Max	**2.5738**	**2.7058**	**2.6398**	**2.5409**
Min	**.099**	**.066**	**.099**	**.099**
Avg	**.8655**	**.8085**	**.8482**	**.9357**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KURDUWADI S/DN.[092] BU 1368
Substation No/ Name :- 274224 / BARLONI S/STN
Feeder No / Name : 201 / GFSS Barloni SHEDDABLE RURAL
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1524	.1143		.1334	.0762
2		.0953	.1143	.1143	.0762	.0762
3		.1905	.1334	.0762	.5639	.5906
4	.1219	.1715	.1524	.0762	.5944	.724
5	.1524	.2096	.1905	.1143	.6097	.6554
6	.1829	.2477	.2477	.1524	.6706	.7468
7	.1829	.3048	.3048	.2667	.6401	.7926
8	.2286	.2096	.2858	.2477	.6554	.884
9	.1829	.2286	.1905	.2096	.6097	.7316
10	.1677	.1334	.1905	.1524	.6554	.7164
11	.4725	.6859			.0914	.1143
12		.9526		.7316		.1143
13	.6706	.9526	.7621	.5335		.1143
14	.7011	.9717	.8383	.7011		.1143
15	.6097	.9526	.8383	.5487		.1143
16	.5792	.9145	.7621	.5487		.1143
17	.5487	.7811	.724	.6249		.1334
18	.6554		.6287	.6097		.1524
19	.1829	.2667	.1524	.2286	.2286	.2286
20	.1524		.1524	.1677	.2286	.1905
21	.1219	.1905	.1524	.362	.1905	.1905
22	.1524	.1524	.1524	.3429	.1715	.1524
23	.1372	.1143	.1143	.381	.1524	.1143
24		.1715	.1143	.1143	.0953	.0762
Max	**.7011**	**.9717**	**.8383**	**.7316**	**.6706**	**.884**
Min	**.1219**	**.0953**	**.1143**	**.0762**	**.0762**	**.0762**
Avg	**.3265**	**.4114**	**.3325**	**.3320**	**.3745**	**.3299**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KURDUWADI S/DN.[092] BU 1368
Substation No/ Name :- 274224 / BARLONI S/STN
Feeder No / Name : 202 / Barloni Ag FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.2096	.1905	.2286	.3429	.2096
2	.1524	.2286	.1905	.2286	.1905	.2096
3	1.2803	1.9052	1.829	1.7718	.4763	.2096
4	1.5851	2.6673	2.0576	1.8138	.362	.2667
5	2.0576	2.572	2.2672	1.8442	.4382	.3239
6	2.1186	2.6673	2.6292	2.1033	.4191	.3429
7	2.5911	2.9912	3.2007	2.5149	.6287	.442
8	2.4844	2.9721	2.9531	2.6368	.503	.5182
9	2.5911	3.1626	2.5339	2.5758	.3963	.4382
10	2.4387	3.0864	2.4958	2.332		.362
11	.1829	.2286		.1524		2.2558
12	.1524			.1905		2.4691
13	.1677	.2286	.2286	.1524		2.4996
14	.1524	.2667		.1715		2.4539
15	.1524	.2477	.2286	.1524		
16	.1372	.2667	.2286	.1905		
17	.1524		.2858	.1905		2.4387
18	.2439	.3048		.3429		2.5758
19	.3658	.4382	.381	.3239	1.6309	.3658
20	.2743	.381	.381	.362	.3658	.3239
21	.2439	.362	.3429	.3048	.3239	.2667
22	.1677	.2858	.3048	.2858	.3239	.2286
23	.2134	.2286	.2667	.3048	.3048	.1905
24	.1524	.1905	.1905	.2286	.3239	.2286
Max	**2.5911**	**3.1626**	**3.2007**	**2.6368**	**1.6309**	**2.5758**
Min	**.1372**	**.1905**	**.1905**	**.1524**	**.1905**	**.1905**
Avg	**.8421**	**1.1769**	**1.1593**	**.8918**	**.4687**	**.8918**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KURDUWADI S/DN.[092] **BU 1368**
Substation No/ Name :- 274224 / BARLONI S/STN
Feeder No / Name : 203 / Bandhara Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3					.7621	.7468
4					.8535	.8383
5			.0762	.0762	.9145	.8993
6	.061		.0953	.0762	.9907	1.0364
7	.0914		.1143		1.3146	1.0974
8	.0914	.1143	.1143		1.0669	1.0974
9		.0762	.0762		1.0974	1.1126
10			.0762		1.0974	.9145
11	1.1888	1.5623	1.467	1.5242	.0953	
12	1.5394	1.9814		1.2955		
13	1.5242	1.9624	1.7147	1.2651		
14	1.5699	1.9814	1.8099	1.2498		
15	1.5546	1.9624	1.829	1.2193		
16	1.3565	1.9243	1.7718	1.1584		
17	1.5242	1.829	1.7147	1.2498		
18	1.3717	1.6575	1.5813	1.1126		.0762
19		.0762	.1143		.1143	.1143
20		.0762	.0762		.0762	.0762
21			.0762		.0762	.0762
22					.0762	
Max	**1.5699**	**1.9814**	**1.829**	**1.5242**	**1.3146**	**1.1126**
Min	**.061**	**.0762**	**.0762**	**.0762**	**.0762**	**.0762**
Avg	**1.0794**	**1.2670**	**.7942**	**1.0227**	**.6566**	**.6738**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KURDUWADI S/DN.[092] **BU 1368**
Substation No/ Name :- 274240 / 33/11 KV TANDULWADI
Feeder No / Name : 201 / GFSS Tandulwadi **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0751	.0705	.1393	.0697	.0743
2		.0705	.1393	.0697	.0743
3		.0705	.1393	.0697	.0743
4		.141	.1741	.0697	.0743
5		.1762	.209	.1741	.1477
6		.2291	.2438	.209	.2415
7		.2643	.209	.2264	.2415
8		.2467	.2264	.2438	.2786
9		.1939	.209	.2264	
10		.141	.1741	.209	.2043
11		.141	.0697	.1393	.0929
12		.0705	.0697	.1219	.0929
13		.0705	.0697	.0697	.0743
14		.0705	.0697		.0743
15		.0705			.1486
16		.0705		.0697	.1486
17		.0705	.0697	.1219	.0743
18		.1586	.1567	.1393	.1672
19		.2467	.1393	.2264	.1858
20		.282	.1915	.1741	.2229
21		.141	.1393	.1219	.1858
22		.141	.0697	.1045	.1486
23		.141		.0697	.1486
24		.0705	.1393	.0697	.0743
Max	**.0751**	**.282**	**.2438**	**.2438**	**.2786**
Min	**.0751**	**.0705**	**.0697**	**.0697**	**.0743**
Avg	**.0751**	**.1395**	**.1451**	**.1362**	**.1413**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KURDUWADI S/DN.[092] BU 1368
Substation No/ Name :- 274240 / 33/11 KV TANDULWADI
Feeder No / Name : 202 / Ridhore Ag FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3221	.451		
2	.3527	.466		
3	.3681	.5111		
4	.3988	.5111		
5	.4448	.481		
6	.4754	.466		
7	.5061	.5111		
8	.6135			
9	.6288	.5111		
10	.6441	.5111		
11			.4954	.743
12				.6668
13				.7621
14				1.0098
15				1.0098
16				1.0669
17				1.0669
18				.9145
Max	**.6441**	**.5111**	**.4954**	**1.0669**
Min	**.3221**	**.451**	**.4954**	**.6668**
Avg	**.4754**	**.4911**	**.4954**	**.9050**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
KURDUWADI S/DN.[092] BU 1368
Substation No/ Name :- 274240 / 33/11 KV TANDULWADI
Feeder No / Name : 203 / Tandulwadi Ag FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1903	.9136	1.5226
2	.1713	.1903	1.0278	1.5607
3	.1713	.2094	1.142	1.5226
4	.1903	.2094	1.2371	1.5036
5	.2094	.2284	1.142	1.4275
6	.2094	.1903	1.18	1.3323
7	.2284	.2284	1.142	1.3133
8	.2284	.3236	1.142	1.2752
9	.1713	.2094	1.3133	
10		.2094	1.2942	1.3133
11		1.2942	.1713	.1523
12	1.5226	1.6178		.1523
13	1.6178	1.713		.1523
14	1.6939	1.6368		.1142
15	1.6749	1.6559		.1523
16	1.5988	1.5988		.1523
17	1.6749	1.5036		.1523
18	1.5797	1.3704		.1903
19	.1903	.1903	.2094	.1903
20	.2094	.1903	.2094	.1713
21	.2284	.1713	.2094	.1713
22	.1903		.1903	.1713
23	.2094	.1713	.1713	.1903
24	.1713	.1903	.1523	.1713
Max	**1.6939**	**1.713**	**1.3133**	**1.5607**
Min	**.1713**	**.1713**	**.1523**	**.1142**
Avg	**.6734**	**.6736**	**.7557**	**.6546**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
MADHA SUB-DIVISION[806] BU 4806
Substation No/ Name :- 274022 / 33/11KV MADHA SUBSTATION
Feeder No / Name : 201 / Nimgaon SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1372	.5144	.6173
2	.12	.1372	.5487	.6687
3	.1372	.12	.5658	.6344
4	.1543	.1372	.5658	.7202
5	.1715	.1543	.5658	.6859
6	.2058	.2058	.6344	.7373
7	.2058	.2229	.8573	1.046
8	.1886	.1543	.8573	1.2174
9	.1715	.1029	.7621	1.1736
10	.1715	.1372		1.0669
11	.9145	1.0288		.0857
12	1.0669	1.1431		.1715
13	1.286	1.2193		.1715
14	1.2193	1.2955		.1886
15	1.3717	1.2803	.1715	.2058
16	1.2517	1.0669	.1715	.2572
17	1.3546	1.2003	.1715	.1715
18	1.1831	1.1145	.1715	.1372
19	.1715	.1886	.2572	.2229
20	.2058	.2058	.2229	.2229
21	.1715	.2058	.2058	.2058
22	.1715	.1715	.1715	.1715
23	.1372	.1372	.1372	.1543
24	.1372	.1372	.12	.1372
Max	**1.3717**	**1.2955**	**.8573**	**1.2174**
Min	**.12**	**.1029**	**.12**	**.0857**
Avg	**.5120**	**.4960**	**.4038**	**.4613**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
MADHA SUB-DIVISION[806] BU 4806
Substation No/ Name :- 274022 / 33/11KV MADHA SUBSTATION
Feeder No / Name : 202 / MADHA GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2401	.2058	.2401
2	.2229	.2229	.2058	.2572
3	.2229		.2058	.2572
4	.2572	.2401	.2572	.2743
5	.3086	.3086	.2743	.2743
6	.4287	.3772	.4115	.4287
7	.5144	.4973	.5487	.583
8	.5658	.4973	.5658	.5658
9	.463	.463	.4801	.4801
10	.4801	.463	.463	.5316
11	.4458	.463		.4115
12	.4287	.4458		.4973
13	.4287	.4801		.4973
14	.3944	.4458		.463
15	.4115	.4458		.4801
16	.4458	.4458	.4801	.4287
17	.4287	.4287	.6001	.4115
18	.5658	.5487	.583	.5144
19	.5658	.6344	.6344	.5487
20	.5316	.5658	.583	.5487
21	.4458	.4801	.4801	.4458
22	.3601	.3601	.3944	.3772
23	.2743	.2572	.2915	.2572
24	.2401	.2401	.2401	.2401
Max	**.5658**	**.6344**	**.6344**	**.583**
Min	**.2229**	**.2229**	**.2058**	**.2401**
Avg	**.4030**	**.4153**	**.4160**	**.4172**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
MADHA SUB-DIVISION[806] BU 4806
Substation No/ Name :- 274023 / 33/11KV MANEGAON SUB STATION
Feeder No / Name : 201 / WAKAV SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.2058	.1402	.1715
2		.1715	.2058	.1402	.1715
3		.1715	.2058	.1402	.1715
4		.1715	.2058	.1402	.1715
5		.1715	.2058	.1402	.1715
6		.1715	.2572	.1402	.2058
7		.1715	.3429	.1753	.2058
8		.1715	.3429	.1753	.2058
9		1.3032	1.3032	.1753	.1715
10		1.3032	1.3889	.1715	.1715
11		1.3546	1.2795	.1715	.1715
12		1.406	1.2795	.1715	.1715
13		1.3032	1.2795	.1715	.1715
14		1.3546	1.2269	.1715	.1715
15		1.4575	1.2269	.1715	.1715
16		1.5261	1.2269	.1715	.1715
17		.1715	.1753	1.406	1.5089
18		.2058	.1753	1.6118	1.5604
19		.2572	.1753	1.4918	1.3546
20		.2572	.1753	1.406	1.3032
21		.2572	.1753	1.2517	1.2003
22		.2058	.1402	.9945	.9431
23	.1715	.2058	.1402	.7888	.9431
24		.1715	.2058	.1402	.7888
Max	**.1715**	**1.5261**	**1.3889**	**1.6118**	**1.5604**
Min	**.1715**	**.1715**	**.1402**	**.1402**	**.1715**
Avg	**.1715**	**.5880**	**.5644**	**.4858**	**.5187**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
MADHA SUB-DIVISION[806] BU 4806
Substation No/ Name :- 274023 / 33/11KV MANEGAON SUB STATION
Feeder No / Name : 202 / MANEGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.4575	1.8347	.1753	.2572
2		1.4575	1.8347	.1753	.2572
3		1.4746	1.8347	.1753	.2572
4		1.7147	1.8347	.1753	.2572
5		1.9719	2.5034	.1753	.2572
6		2.4863	2.6063	.2629	.3429
7		3.0521	3.0521	.3506	.4287
8		2.8978	2.5377	.3506	.3772
9		.2572	.5144	2.5941	2.6063
10		.2572	.3429	2.692	2.3834
11		.2572	.2629	2.6406	2.5892
12		.2572	.2629	2.7435	2.8464
13		.2572	.2629		3.0007
14		.2572	.2629		3.0007
15		.2572	.2629		3.0007
16		.2572	.1753		3.0007
17		.2572	.2629	.2572	.2572
18		.3429	.2629	.2572	.3086
19		.5144	.2629	.3429	.3086
20		.5144	.2629	.3429	.2572
21		.5144	.1753	.2572	.2572
22		.4287	.1753	.2572	.2572
23	.2572	.4287	.1753	.2572	.2572
24		.2572	.4287	.1753	.2572
Max	**.2572**	**3.0521**	**3.0521**	**2.7435**	**3.0007**
Min	**.2572**	**.2572**	**.1753**	**.1753**	**.2572**
Avg	**.2572**	**.9095**	**.9330**	**.7329**	**1.1260**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
MADHA SUB-DIVISION[806] BU 4806
Substation No/ Name :- 274023 / 33/11KV MANEGAON SUB STATION
Feeder No / Name : 203 / ANGENGAON(U) SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.2058	.1753	.1715
2		.1715	.2058	.1753	
3		.1715	.2058	.1753	.1715
4		.1715	.2058	.1753	.1715
5		.1715	.2058	.1753	.1715
6		.1715	.2572	.1753	.2058
7		.1715	.3429	.1753	.2572
8		.1715	.3429	.1753	.2572
9		2.1434	2.2634	.1753	.2058
10		2.1434	2.4863	.1715	.1715
11		2.4691	2.4539	.1715	.1715
12		2.6235	2.4539	.1715	.1715
13		2.7778	2.4539	.1715	.1715
14		2.4691	2.0332	.1715	.1715
15		2.572	2.3487	.1715	.1715
16		2.3663	2.2786	.1715	.1715
17		.1715	.1753	2.5549	2.4006
18		.2058	.1753	2.5034	2.5034
19		.2572	.1753	2.4348	2.3491
20		.2572	.1753	2.2634	2.2977
21		.2572	.1753	2.0919	2.1434
22		.2058	.1753	1.989	1.989
23	.1715	.2058	.1753	1.6289	1.8861
24		.1715	.2058	.1753	1.6289
Max	**.1715**	**2.7778**	**2.4863**	**2.5549**	**2.5034**
Min	**.1715**	**.1715**	**.1753**	**.1715**	**.1715**
Avg	**.1715**	**.9445**	**.9240**	**.7675**	**.8700**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
MADHA SUB-DIVISION[806] BU 4806
Substation No/ Name :- 274023 / 33/11KV MANEGAON SUB STATION
Feeder No / Name : 204 / KHAIRAO SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8402	.9088	.1227	.1715
2		.8402	.9088	.1227	.1715
3		.8402	.9088	.1227	.1715
4		.9431	.9088	.1227	.1715
5		1.046	1.0631	.1227	.1715
6		1.2517	1.0802	.1227	.2058
7		1.4575	1.5089	.1753	.2058
8		1.5604	1.6118	.1753	.2058
9		.1715	.3429	1.5424	1.6118
10		.1715	.2572	1.6118	1.7147
11		.1715	.1753	1.4575	1.869
12		.1715	.1753	1.5604	1.6118
13		.1715	.1753		1.6632
14		.1715	.1753		1.6632
15		.1715	.1753		1.406
16		.1715	.1753		1.6118
17		.1715	.1753	.1715	.1715
18		.2058	.1753	.1715	.1715
19		.2572	.1753	.2058	.1715
20		.2572	.1753	.1715	.1715
21		.2572	.1753	.1715	.1715
22		.2058	.1227	.1715	.1715
23	.1715	.2058	.1227	.1715	.1715
24		.1715	.2058	.1227	.1715
Max	**.1715**	**1.5604**	**1.6118**	**1.6118**	**1.869**
Min	**.1715**	**.1715**	**.1227**	**.1227**	**.1715**
Avg	**.1715**	**.4951**	**.4950**	**.4308**	**.6666**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
MADHA SUB-DIVISION[806] BU 4806
Substation No/ Name :- 274023 / 33/11KV MANEGAON SUB STATION
Feeder No / Name : 205 / KAPASEWADI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.2058	1.1744	1.3717
2		.1715	.2058	1.1744	1.3717
3		.1715	.2058	1.1744	1.5261
4		.1715	.2058	1.2269	1.6289
5		.1715	.2058	1.3321	1.6289
6			.2572	1.4548	1.7147
7		.1715	.3429	2.1033	2.2462
8		.1715	.3429	1.9982	2.0919
9		.1715	.3429	.1753	.1715
10		.1715	.2058	.1715	.1715
11		.1715	.1753	.1715	.1715
12		.1715	.1753	.1715	.1715
13		.1715	.1753	.1715	.1715
14		.1715	.1753	.1715	.1715
15		.1715	.1753	.1715	.1715
16		.1715	.1753	.1715	.1715
17		2.2119	1.9806	.1715	.1715
18		2.2805	1.9806	.1715	.1715
19		2.1605	1.9806	.2058	.1715
20		1.9547	1.8861	.1715	.1715
21		1.749	1.7528	.1715	.1715
22		1.8347	1.4899	.1715	.1715
23	1.2689	1.749	1.3321	.1715	.1715
24		1.2689	1.749	1.2269	.1715
Max	**1.2689**	**2.2805**	**1.9806**	**2.1033**	**2.2462**
Min	**1.2689**	**.1715**	**.1753**	**.1715**	**.1715**
Avg	**1.2689**	**.7731**	**.7385**	**.6448**	**.6802**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
MADHA SUB-DIVISION[806] BU 4806
Substation No/ Name :- 274023 / 33/11KV MANEGAON SUB STATION
Feeder No / Name : 206 / kumbhej SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.1715	.3155	.2058
2		.1715	.1715	.3155	.2058
3		.1715	.1715	.3155	.2058
4		.1715	.1715	.3681	.2058
5		.1715	.1715	.3681	.2058
6		.1715	.2058	.4733	.2572
7		.1715	.2915	.4382	.3086
8		.1715	.2915	.5959	.3086
9		.1715	.2058	.1753	.1715
10		.1715	.1715	.1715	.1715
11		.1372	.1753	.1715	.1715
12		.1372	.1753	.1715	.1715
13		.1372	.1753	.1715	.1715
14		.1372	.1753	.1715	.1715
15		.1372	.1753	.1715	.1715
16		.1372	.1753	.1715	.1715
17		.6344	.6485	.1715	.1715
18		.8059	.5959	.1715	.1715
19		.8745	.5959	.2058	.1715
20		.7716	.5434	.1715	.1715
21		.7716	.5434	.1715	.1715
22		.5487	.3681	.1715	.1715
23	.4287	.5144	.3681	.1715	.1715
24		.4287	.5144		.1715
Max	**.4287**	**.8745**	**.6485**	**.5959**	**.3086**
Min	**.4287**	**.1372**	**.1715**	**.1715**	**.1715**
Avg	**.4287**	**.3287**	**.3022**	**.2522**	**.1936**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
MADHA SUB-DIVISION[806] BU 4806
Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION
Feeder No / Name : 201 / Uplai(BK) SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0514	.0343	.2572	.2572
2		.0514	.0686	.2572	.2572
3		.0686	.0686	.2572	.3429
4		.0686	.0686	.2572	.4287
5		.0514	.0857	.2572	.3429
6		.1029	.12	.2572	.4287
7		.1029	.12	.2572	.5144
8		.1029	.1029		.4287
9		.1715	.0857	.4287	.4287
10		.0514	.0857	.3429	.4287
11		.2572	.3429	.0686	.0514
12		.3429	.4287	.0343	.0514
13		.4287	.4287	.0343	.0514
14		.4287	.4287	.0343	.0514
15		.4287	.4287	.0343	.0343
16		.4287	.4287	.0343	.0343
17		.5144	.3429	.0514	.0686
18		.4287	.3429	.0514	.0686
19		.0857	.0857	.0514	.1029
20		.0857	.0857	.0514	.12
21		.0857	.0857	.0514	.0857
22		.0686	.0857	.0514	.0514
23	.0514	.0343	.0686	.0514	.0514
24			.0343	.0686	.0686
Max	**.0514**	**.5144**	**.4287**	**.4287**	**.5144**
Min	**.0514**	**.0343**	**.0343**	**.0343**	**.0343**
Avg	**.0514**	**.1931**	**.1858**	**.1409**	**.1979**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
MADHA SUB-DIVISION[806] BU 4806
Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION
Feeder No / Name : 202 / Rophale(KH) SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4287	.6859	.2572	.2572
2		.6859	1.0288	.2572	.1715
3		1.2003	1.286	.2572	.1715
4		1.5432	1.5432	.2572	.2572
5		1.8004	1.6289	.2572	.2572
6		2.0576	1.7147	.2572	.2572
7		2.2291	2.1434	.2572	.2572
8		2.0576	2.3148	.2572	.2572
9		2.1434	1.9719	.2572	.1715
10		2.0576	2.1434	.2572	.1715
11		.1715	.1715	1.7147	1.5432
12		.1715	.1715	2.4863	2.4863
13		.1715	.1715	2.572	2.8292
14		.1715	.1715		2.7435
15		.1715	.1715		2.8292
16		.1715	.1715		2.572
17		.1715	.1715	2.1434	2.3148
18		.1715	.1715	2.4006	2.1434
19		.2572	.2572	.3429	.2572
20		.2572	.2572	.3429	.2572
21		.1715	.2572	.4287	.2572
22		.1715	.2572	.4287	.2572
23	.1715	.1715	.2572	.1715	.1715
24		.1715	.1715	.2572	.1715
Max	**.1715**	**2.2291**	**2.3148**	**2.572**	**2.8292**
Min	**.1715**	**.1715**	**.1715**	**.1715**	**.1715**
Avg	**.1715**	**.7823**	**.8038**	**.7553**	**.9609**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
MADHA SUB-DIVISION[806] BU 4806
Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION
Feeder No / Name : 204 / GAONTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.2572	.2572	.2572
2		.1715	.2572	.2572	.1715
3		.2572	.2572	.2572	.1715
4		.2572	.2572	.2572	.2572
5		.2572	.3429	.2572	.3086
6		.3429	.4287	.2572	.2572
7		.3429	.4287	.2572	.3429
8		.3429	.4287	.3429	.3429
9		.3086	.3429	.3429	.3429
10		.2572	.2572	.3429	.3429
11		.2572	.3429	.4287	.2572
12		.2572	.3429	.1715	.2572
13		.2572	.2572		.2572
14		.2572	.2572		.2572
15		.2572	.2572		.2572
16		.2572	.1715	.2572	.2572
17		.2572	.2572	.2572	.2572
18		.3429	.2572	.2572	.3429
19		.4287	.3429	.3429	.4287
20		.4287	.3429	.3429	.4287
21		.4287	.3429	.4287	.4287
22		.4287	.3429	.3429	.4287
23	.3429	.3429	.2572	.3429	.4287
24		.3429	.3429	.2572	.2572
Max	**.3429**	**.4287**	**.4287**	**.4287**	**.4287**
Min	**.3429**	**.1715**	**.1715**	**.1715**	**.1715**
Avg	**.3429**	**.3022**	**.3072**	**.2980**	**.3058**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
MADHA SUB-DIVISION[806] BU 4806
Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION
Feeder No / Name : 205 / Kumbhej SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2572	.5144	.1715	.1715
2		.4287	.5144	.1715	.1715
3		.5144	.6001	.1715	.1715
4		.7716	.7716	.1715	.2572
5		1.1145	.8573	.1715	.1715
6		1.286	1.0288	.2572	.1715
7		1.3717	1.286	.2572	.1715
8		1.3717	1.3717	.1715	.2572
9		1.5432	1.286	.1715	.1715
10		1.286	1.286	.1715	.1715
11		.1715	.1715	.4287	1.2003
12		.0857	.1715	.9431	1.4575
13		.0857	.0857	1.0288	1.5432
14		.0857	.0857		1.5432
15		.0857	.0857	.0857	1.5432
16		.0857	.0857		1.5432
17		.0857	.1715	1.3717	1.3717
18		.0857	.1715	1.2003	1.286
19		.0857	.2572	.2572	.1715
20		.0857	.2572	.3429	.1715
21		.0857	.2572	.3429	.1715
22		.0857	.2572	.3429	.1715
23	.1715	.0857	.1715	.2572	.1715
24		.1715	.0857	.1715	.2572
Max	**.1715**	**1.5432**	**1.3717**	**1.3717**	**1.5432**
Min	**.1715**	**.0857**	**.0857**	**.0857**	**.1715**
Avg	**.1715**	**.4715**	**.4930**	**.3936**	**.6037**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
MADHA SUB-DIVISION[806] BU 4806
Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION
Feeder No / Name : 206 / UPLAI(KH) FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2058	.2401	.2572	.1543
2		.2058	.2058	.2572	.1543
3		.2572	.2058	.2572	.1715
4		.2572	.2401	.2572	.2058
5		.3086	.3086	.2572	.2572
6		.3601	.3429	.2572	.2915
7		.3601	.4115	.3429	.3258
8		.3944	.3944	.3258	.2915
9		.2915	1.5432	.3429	.2743
10		.2229	1.9204	.3429	.2229
11		1.8004	2.0576	.3086	.1886
12		2.1434	2.692	.2743	.1715
13			2.6578	.2401	.1715
14			2.572	.2915	.1715
15		1.5432	2.6578	.2401	.2572
16		1.989	2.572	.3258	.2743
17		1.8861	.2572	1.286	.8573
18		2.1776	.3429	1.8176	2.332
19		.3258	.3429	1.8347	2.0233
20		.3429	.3429	1.8347	1.8347
21		.3086	.2915	1.8519	1.6289
22		.2401	.2572	1.869	1.5261
23	.2058	.2401	.2572	1.7147	1.4403
24		.2058	.2229	.2572	1.6289
Max	**.2058**	**2.1776**	**2.692**	**1.869**	**2.332**
Min	**.2058**	**.2058**	**.2058**	**.2401**	**.1543**
Avg	**.2058**	**.7303**	**.9724**	**.7102**	**.7023**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
MADHA SUB-DIVISION[806] BU 4806
Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION
Feeder No / Name : 207 / vittalwadi FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0857	.0343	.6001	.5658
2		.0857	.0343	.6001	.6859
3		.1029	.0343	.6001	.823
4		.1372	.0343	.6859	.9259
5		.1372	.0343	.6859	.9774
6		.1715	.0343	.7716	1.0631
7		.1715	.1715	.7716	1.1488
8		.1543	.1715	.5144	1.1831
9		.1372	.1372	.0686	.1372
10		.0343	.12	.0857	.0857
11		1.0974	.0857	.0514	.0686
12		.0686	.0514	.0686	.0686
13		.0686	.0686	.1029	.0857
14		.0686	.0686	.0514	.0686
15		.0686	.0514	.0686	.0686
16		.0686	.0686		.0857
17		1.5604	1.2003	.0686	.0686
18		1.1317	1.6289	.0857	.0857
19		1.0631	1.3717	.0857	.1029
20		.9945	1.2003	.0857	.12
21		.8573	.7716	.0857	.0857
22		.823	.6859	.0857	.0686
23	.0857	.7545	.6001	.0514	.0686
24		.0857	.7545	.6001	.0514
Max	**.0857**	**1.5604**	**1.6289**	**.7716**	**1.1831**
Min	**.0857**	**.0343**	**.0343**	**.0514**	**.0514**
Avg	**.0857**	**.4137**	**.3922**	**.2989**	**.3622**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
MADHA SUB-DIVISION[806] BU 4806
Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION
Feeder No / Name : 208 / londewadi FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5144	.6001	.2572	.2572
2		1.1145	1.286	.2572	.2572
3		1.3717	1.5432	.3429	.3086
4		1.7147	1.6289	.3429	.3429
5		2.0576	1.7147	.3429	.4115
6		2.2291	1.8004	.4287	.4801
7		2.452	2.3834	.5144	.5144
8		2.1262	2.5549	.8573	.463
9		2.4177	.4287	1.7147	1.6289
10		2.1948	.3086	2.332	2.4006
11		.2058	.2572	2.4006	2.6063
12		.2058	.1715	2.332	2.572
13		.2058	.1715	2.3491	2.4863
14		.2401	.1715	2.3663	2.3148
15		.2401	.1715	2.4691	2.1434
16		.2401	.1715	2.4177	1.9033
17		.2058		.1715	.1715
18		.2229	.3429	.3429	.3258
19		.3086	.3429	.1715	.4973
20		.4115	.4287	.2058	.463
21		.3429	.3944	.2401	.3429
22		.2401	.3429	.2401	.3086
23	.2915	.2401	.2572	.2401	.2743
24		.5144	.2401	.2572	.2401
Max	**.2915**	**2.452**	**2.5549**	**2.4691**	**2.6063**
Min	**.2915**	**.2058**	**.1715**	**.1715**	**.1715**
Avg	**.2915**	**.9174**	**.7701**	**.9831**	**.9881**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
MADHA SUB-DIVISION[806] BU 4806
Substation No/ Name :- 274162 / Darphal(sina) s/s
Feeder No / Name : 201 / Darphal SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2452	.2641	.2263	.2279
2		.2452	.2641	.1886	.2126
3		.2829	.2452	.5535	.4218
4		.3206	.3206	.5937	.5571
5		.3772	.415	.6401	.6802
6		.6036	.6036	.7362	.9259
7		.679	.6413	.8002	.9998
8		.6036	.5658	.8002	1.0911
9		.4715	.4904	.8333	1.0883
10		.3734	.3018	.9442	
11		1.0437	1.2637	.2454	
12		1.1092	1.2452	.2303	
13		1.1574	1.2631		
14		1.2176	1.2163	.2454	
15		1.2963	1.2163	.2835	
16		1.2323	1.2163	.2534	
17		1.166	1.1702	.333	
18		1.1336	1.1797	.4854	
19	.6348	.5975	.5658	.298	
20	.5228	.547	.4527	.333	
21	.415	.4338	.3547	.3841	
22	.2829	.3018		.3475	
23	.2641	.2829		.2947	
24		.2641	.2641	.2427	.2454
Max	**.6348**	**1.2963**	**1.2637**	**.9442**	**1.0911**
Min	**.2641**	**.2452**	**.2452**	**.1886**	**.2126**
Avg	**.4239**	**.6661**	**.7055**	**.4475**	**.6450**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
MADHA SUB-DIVISION[806] BU 4806
Substation No/ Name :- 274162 / Darphal(sina) s/s
Feeder No / Name : 202 / kevad SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1698	.1509	.1494	.2012
2		.1509	.1509	.1509	.2195
3		.5281	.3149	.1886	.3012
4		.5182	.3725	.2241	.3294
5		.6081	.4752	.415	.3681
6		.7011	.8029	.5658	.4207
7		.7926	.9762	.679	.4681
8		.9282	1.0526	.5658	.5434
9		.9061	1.0402	.4887	.3944
10		1.0437	.9602	.2561	
11		.1494	.1886	.8179	
12		.1494	.1494	.7842	
13		.1663	.1509		
14		.1886	.1509	.7562	
15		.2033	.1509		
16		.2614	.1494		
17		.3326	.1886		
18		.3734	.3395		
19	.4338	.415	.3772	.3012	
20	.3772	.3584	.3395	.3475	
21	.3018	.2614	.2987	.2743	
22	.2075	.2263		.2561	
23	.1886	.168		.1402	
24		.1698	.168	.1478	.1227
Max	**.4338**	**1.0437**	**1.0526**	**.8179**	**.5434**
Min	**.1886**	**.1494**	**.1494**	**.1402**	**.1227**
Avg	**.3018**	**.4071**	**.4067**	**.3952**	**.3369**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
MADHA SUB-DIVISION[806] BU 4806
Substation No/ Name :- 274162 / Darphal(sina) s/s
Feeder No / Name : 203 / Undergoan SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3395	.2452	.3018	.2658
2		.3395	.2829	.3018	.298
3		.9724	.7287	.3395	.3841
4		.9724	.8356	.4527	.4207
5		1.094	.9448	.6036	.5487
6		1.0753	1.0978	.6413	.6135
7		1.2452	1.247	.679	.7011
8		1.5249	1.2929	.6036	.7362
9		1.2955	1.3757	.4207	.9568
10		1.1431	1.3603	.3801	
11		.2987	.1494	1.0802	
12		.2614	.1509	1.0802	
13		.2241	.1509		
14		.2427		1.1111	
15		.2033			
16		.2427			
17		.2829	.3395		
18		.3772			
19	.6224	.4715	.6722	.439	
20	.6602	.4904	.6283	.4207	
21	.4904	.4715	.5658	.4031	
22	.3961	.3584		.3475	
23	.3772	.2641		.3121	
24		.3584	.2452	.3395	.2481
Max	**.6602**	**1.5249**	**1.3757**	**1.1111**	**.9568**
Min	**.3772**	**.2033**	**.1494**	**.3018**	**.2481**
Avg	**.5093**	**.6062**	**.6841**	**.5399**	**.5173**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
MADHA SUB-DIVISION[806] BU 4806
Substation No/ Name :- 274162 / Darphal(sina) s/s
Feeder No / Name : 204 / Darfal Water Supply FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0151	.0151	.0145	.029
2		.0151	.0151	.0145	.0293
3		.0151	.0151	.0145	.029
4		.0151	.0151	.0145	.029
5		.0151	.0151	.029	.029
6		.1054	.0903	.1158	.1882
7		.1355	.0903	.1303	.2027
8		.1656	.1355	.1593	.2172
9		.2709	.1957	.2027	.2462
10		.286		.2751	
11		.301	.2027	.3475	
12		.301	.2107	.333	
13		.286	.1505		
14		.0151	.0145		
15		.0151	.0145	.029	
16		.0151	.0145	.029	
17		.0151	.029	.029	
18		.0151	.029	.029	
19	.0301	.0301	.029	.029	
20	.0301	.0301	.029	.029	
21	.0301	.0301	.029	.029	
22	.0301	.0301		.029	
23	.0151	.0151		.029	
24		.0151	.0151	.0145	.029
Max	**.0301**	**.301**	**.2107**	**.3475**	**.2462**
Min	**.0151**	**.0151**	**.0145**	**.0145**	**.029**
Avg	**.0271**	**.0897**	**.0645**	**.0876**	**.1029**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
TERMBHURNI S/DN.[821] BU 4821
Substation No/ Name :- 274021 / BEMBALE
Feeder No / Name : 201 / Humbe Wasti AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0937		.1094	.0937
2	.0937		.1094	.0937
3	.0937		.1094	.0937
4	.0937		.125	.0937
5	.0937		.125	.0937
6	.1094		.1406	.1094
7	.1094		.1406	.125
8	.1094		.1406	.125
9	.0937		.125	.1094
10	.1094		.125	.1094
11	1.406			1.7185
12	1.6404			1.8435
13	1.6248			1.8747
14				1.9372
15	1.6404			1.9528
16	1.6248			1.9528
17				1.7966
18	1.6404		1.7966	1.7185
19	.0937		.125	.125
20	.1094		.125	.125
21	.125		.1094	.125
22	.0937		.0937	.1094
23	.0937	.1094	.0937	.1094
24	.0937		.1094	.0937
Max	**1.6404**	**.1094**	**1.7966**	**1.9528**
Min	**.0937**	**.1094**	**.0937**	**.0937**
Avg	**.5084**	**.1094**	**.2178**	**.6887**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
TERMBHURNI S/DN.[821] BU 4821
Substation No/ Name :- 274021 / BEMBALE
Feeder No / Name : 205 / Goathan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	19-DEC-17
HR	Load (MW)
2	.6097
Max	.6097
Min	.6097
Avg	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
TERMBHURNI S/DN.[821] BU 4821
Substation No/ Name :- 274025 / 33/11KV PIMPLNEAR SUBSTATION
Feeder No / Name : 201 / WIRELESS SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.2294	.2134	
2	.2134	.2294	.2134	
3	.2134	.2294	.2134	
4	.2439		.2134	
5	.2591	.2622	.2134	
6	.2743	.2984	.2439	
7	.2591	.3315	.2134	
8	.2439		.2134	
9	.1219	.2134	.1989	.1829
10	.1219	.1829	.1326	.1524
11	.1219	.1372		.1219
12	.0914	.1067		.0914
13	.1219	.1067		.0914
14	.1219	.1067		.0914
15	.0914	.1219		.0914
16	.0914	.1219		.0914
17	2.3205	2.2558		.2294
18	2.3205	2.4996		.2652
19	2.3868	2.4387		.2652
20	2.3205	2.1948		.2321
21	2.1628	1.8595		.1989
22	2.1795	1.7985		.1989
23	1.989	1.6918		.1989
24	1.6461	1.9227	1.5851	
Max	**2.3868**	**2.4996**	**1.5851**	**.2652**
Min	**.0914**	**.1067**	**.1326**	**.0914**
Avg	**.8375**	**.8791**	**.3322**	**.1669**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
TERMBHURNI S/DN.[821] BU 4821
Substation No/ Name :- 274025 / 33/11KV PIMPLNEAR SUBSTATION
Feeder No / Name : 202 / PIMPALNER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0729	2.2377	2.0119	
2	2.1033	2.2377	1.829	
3	2.1338	2.2377	1.7985	
4	2.1643	2.3205	1.7071	
5	2.1795	2.3758	1.6766	
6	2.1948	2.4863	1.6918	
7	2.5911	2.5194	1.7071	
8	2.6825		2.0271	
9	.3048	.1524	2.3205	2.4082
10	.3048	.2439	2.4143	2.6825
11		.1829		2.7435
12	.1829	.1524		2.8349
13	.1829	.1524		2.4996
14	.1219	.1524		2.4996
15	.1219	.1829		2.5911
16	.1219	.1219		2.6825
17	.3315	.1219		.3315
18	.3647	.1372		.3647
19	.3978	.3048		.3481
20	.3647	.1524		.3647
21	.3315	.1677		.3315
22	.3353	.1829		.3315
23	.2652	.1829		.3315
24	.2439	.2652	.2439	
Max	**2.6825**	**2.5194**	**2.4143**	**2.8349**
Min	**.1219**	**.1219**	**.2439**	**.3315**
Avg	**.9608**	**.8379**	**1.7662**	**1.5564**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
TERMBHURNI S/DN.[821] BU 4821
Substation No/ Name :- 274025 / 33/11KV PIMPLNEAR SUBSTATION
Feeder No / Name : 203 / NIMGAON (T) SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2134	.1966	.1829	
2	.2134	.1989	.2134	
3	.2439	.1989	.2134	
4	.2743	.2294	.2134	
5	.3048	.2321	.2134	
6	.3353	.2652	.2439	
7	.2439	.2652	.2439	
8	.2134		.2439	
9	1.9509	1.89	.2321	.1829
10	2.0119	1.9509	.1989	.1372
11	2.0119	2.0119		.1219
12	2.1338	2.0424		.1219
13	2.1338	2.0119		.1067
14	2.0271	1.9814		.1067
15	2.1338	2.0119		.1219
16	1.9509	2.1033		.1219
17	.2652	.0914		2.3205
18	.2652	.1829		2.3868
19	.2652	.2058		2.3868
20	.2321	.2058		2.2377
21	.1989	.2058		2.0553
22	.1989	.2058		1.989
23	.1989	.2058		1.8233
24	.1829	.1989	.1829	
Max	**2.1338**	**2.1033**	**.2439**	**2.3868**
Min	**.1829**	**.0914**	**.1829**	**.1067**
Avg	**.8418**	**.8301**	**.2166**	**1.0814**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
TERMBHURNI S/DN.[821] BU 4821
Substation No/ Name :- 274025 / 33/11KV PIMPLNEAR SUBSTATION
Feeder No / Name : 204 / PIMPALNER GAONTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.3601	.3429	
2	.4458	.3601	.3429	
3	.4801	.4334	.3772	
4	.5144	.463	.4458	
5	.5487	.5144	.4801	
6	.6516	.5487	.5487	
7	.6001	.5487	.5487	
8	.5658		.4973	
9	.5144	.4973	.463	.5487
10	.4115	.463	.4287	.5144
11	.4287	.4287		.463
12	.3429	.3601		.3601
13	.3258	.3258		.3601
14	.3086	.2915		.3601
15	.3201	.2915		.3429
16	.3201	.3086		.3258
17	.4287	.3429		.463
18	.5144	.4801		.5144
19	.583	.5316		.5658
20	.5316	.463		5.2984
21	.4801	.4287		.463
22	.4287	.3944		.4287
23	.3772	.3772		.3772
24	.3772	.3601	.2743	
Max	**.6516**	**.5487**	**.5487**	**5.2984**
Min	**.3086**	**.2915**	**.2743**	**.3258**
Avg	**.4546**	**.4162**	**.4318**	**.7590**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
TERMBHURNI S/DN.[821] BU 4821
Substation No/ Name :- 274025 / 33/11KV PIMPLNEAR SUBSTATION
Feeder No / Name : 205 / Dahiwali SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.0686	.061	
2	.1372	.0686	.061	
3	.1372	.1017	.061	
4	.1543	.1017	.061	
5	.1543	.1357	.061	
6	.1543	.1696	.061	
7	.1372	.1696	.061	
8	.12		.061	
9	2.1338		.0343	.12
10	2.21	2.4006	.0343	.1029
11	2.3472	2.6406		.0857
12	2.3167	2.7949		.0686
13	2.2862	2.6749		.0686
14	2.2862	2.5206		.0686
15	2.1643	2.5034		.0686
16	2.2253	2.4691		.0686
17	.0686	.1029		2.572
18	.0686	.0514		2.7435
19	.0686	.061		2.7435
20	.1029	.0686		2.7435
21	.1372	.0686		.2743
22	.1029	.0686		.2743
23	.0686	.0686		.2401
24	.1372	.0686	.061	
Max	**2.3472**	**2.7949**	**.061**	**2.7435**
Min	**.0686**	**.0514**	**.0343**	**.0686**
Avg	**.8273**	**.8808**	**.0561**	**.8162**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
TERMBHURNI S/DN.[821] BU 4821
Substation No/ Name :- 274025 / 33/11KV PIMPLNEAR SUBSTATION
Feeder No / Name : 206 / TAMBAVE AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	2.0348	2.1033	
2	2.0919	2.0348	2.1338	
3	2.1091	2.1195	2.1338	
4	2.1262	2.1548	2.1033	
5	2.1262	2.2377	1.7375	
6	2.1434	2.3205	1.7985	
7	2.4177	2.2939	1.8595	
8	2.572		2.0119	
9	.2134	.3258	2.1879	2.5034
10	.2134	.2058	2.3148	2.692
11	.2134	.1715		2.7092
12	.2134	.1715		2.7778
13	.2134	.1715		
14	.2134	.1715		2.6235
15	.2134	.2058		2.2558
16	.2134	.1715		2.2253
17	3.2579	2.572		.2572
18	3.1539	2.6749		.2572
19	3.2217	2.7435		.3086
20	3.0178	2.7092		.2572
21	2.7846	2.4348		.2572
22	2.7349	2.4348		.2572
23	2.6825	2.4348		.2572
24	2.5206	2.5434	2.0576	
Max	**3.2579**	**2.7435**	**2.3148**	**2.7778**
Min	**.2134**	**.1715**	**1.7375**	**.2572**
Avg	**1.7802**	**1.6234**	**2.0402**	**1.4028**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
TERMBHURNI S/DN.[821] BU 4821
Substation No/ Name :- 274026 / TEMBHURNI
Feeder No / Name : 207 / GOATHAN TEMBHURNI GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	21-DEC-17
HR	Load (MW)
1	.9145
2	.9145
3	.8573
4	.9145
5	1.0288
6	1.3717
7	1.5432
8	1.7147
24	.9145
Max	**1.7147**
Min	**.8573**
Avg	**1.1304**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
TERMBHURNI S/DN.[821] BU 4821
Substation No/ Name :- 274026 / TEMBHURNI
Feeder No / Name : 208 / AKOLE BHAGIRATH GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	21-DEC-17
HR	Load (MW)
1	.4287
2	.4287
3	.4287
4	.4287
5	.5316
6	.7087
7	.5853
8	.5487
24	.4287
Max	**.7087**
Min	**.4287**
Avg	**.5020**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
TERMBHURNI S/DN.[821] BU 4821
Substation No/ Name :- 274027 / WARWADE
Feeder No / Name : 202 / PARITE AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4096	.4588		
2			.3932	.4588		
3			.4915	.4096		
4			.6226	.639		
5			.8192	.8356		
6			.9503	.9012		
15		2.6155	2.5652			
16	2.3807	2.8502	2.7161	2.8464		
17		2.3472	2.7664			
18		2.1795	2.0454			
19		2.0119	2.0454			.6539
20		1.9784	1.8442			.57
21		1.7939	1.7604			.4862
22		1.6263	1.6933			.4191
23		.4424	.6554			1.6975
24		.3277	.4096	.5243	.3688	1.3546
Max	**2.3807**	**2.8502**	**2.7664**	**2.8464**	**.3688**	**1.6975**
Min	**2.3807**	**.3277**	**.3932**	**.4096**	**.3688**	**.4191**
Avg	**2.3807**	**1.8173**	**1.3867**	**.8842**	**.3688**	**.8636**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
TERMBHURNI S/DN.[821] BU 4821
Substation No/ Name :- 274027 / WARWADE
Feeder No / Name : 203 / Gaonthan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4024		
2			.3688		
3			.3688		
4			.4862		
5			.6036		
6			.8048		
8	.5533	.7545	.8048		.7716
9		.7042	.7209		
10			.6036		.5144
11		.5365	.503		.5658
12		.4191	.4588		.5658
13		.3856	.3277		.4801
14		.3688	.3605		.4973
15		.3688	.3605		.5144
16	.3856	.3856	.3768		.5487
17		.4191			.5316
18		.5365	.6062		.6001
19		.7209	.6371		.7716
20		.6371	.5868		.6859
21		.5365	.5533		.6344
22		.4694	.503		.5487
23		.4024			.5144
24	.4024	.4024	.4024	.3944	.5316
Max	**.5533**	**.7545**	**.8048**	**.3944**	**.7716**
Min	**.3856**	**.3688**	**.3277**	**.3944**	**.4801**
Avg	**.4471**	**.5030**	**.5162**	**.3944**	**.5798**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
TERMBHURNI S/DN.[821] BU 4821
Substation No/ Name :- 274027 / WARWADE
Feeder No / Name : 204 / AKOLE BK **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3916	1.1401		
2		1.3413	1.1401		
3		1.3748	1.1568		
4		1.4419	1.1904		
5		1.4922	1.2239		
6		1.5424	1.4083		
8				1.6461	1.8861
9					1.9033
10					1.869
11					1.8347
12					1.869
13					1.8176
14					1.7147
19	.3113	.2785	.2622		.3185
20	.2785	.2785	.2294	.2572	.285
21	.2458	.2785	.2294	.2572	.2683
22	.213	.2785	.2294	.2572	.285
23	1.3413	1.2239		.2401	.2683
24	1.3413	1.4419	1.1736	.9945	.2515
Max	**1.3413**	**1.5424**	**1.4083**	**1.6461**	**1.9033**
Min	**.213**	**.2785**	**.2294**	**.2401**	**.2515**
Avg	**.6219**	**1.0303**	**.8531**	**.6087**	**1.1208**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
TERMBHURNI S/DN.[821] BU 4821
Substation No/ Name :- 274027 / WARWADE
Feeder No / Name : 205 / Palwan ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.0059		
2			.9892		
3			.9892		
4			1.0898		
5			1.1904		
6			1.4251		
7			2.649		
8	3.0849	2.7664	2.8837	1.8861	2.3148
9	3.1017	3.1017	3.0514		2.332
10	3.1017	3.152	3.1184		2.2291
11	3.219	2.6658	3.3029		2.0919
12	3.3532	2.7161	3.2023		1.869
13	3.0178	2.7664	2.9508		1.869
14	2.9843	2.9172	2.8669		1.8861
15					2.7435
16					3.1722
17					3.1893
18					2.6406
19	.4915	.7045	.6882		2.8121
20	.6226	.5243	.5898		2.5892
21	.3768	.4915	.4915		2.3834
22	.3441	.4588	.4588		2.2634
23	.7373	1.0395			.5365
24	.7377	.7865	1.0059	.9602	.4694
Max	**3.3532**	**3.152**	**3.3029**	**1.8861**	**3.1893**
Min	**.3441**	**.4588**	**.4588**	**.9602**	**.4694**
Avg	**1.9364**	**1.8531**	**1.7868**	**1.4232**	**2.1995**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
TERMBHURNI S/DN.[821] BU 4821
Substation No/ Name :- 274149 / 33/11 KV ARAN S/S
Feeder No / Name : 202 / JADHAVWADI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	19-DEC-17
HR	Load (MW)
24	1.326
Max	1.326
Min	1.326
Avg	1.326

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
TERMBHURNI S/DN.[821] BU 4821
Substation No/ Name :- 274176 / 33/11kV SURLI
Feeder No / Name : 201 / AKOLE(KH) AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	1.5089	1.5394		1.7375
24	.2543	.1829	.2286	.2543
Max	**1.5089**	**1.5394**	**.2286**	**1.7375**
Min	**.2543**	**.1829**	**.2286**	**.2543**
Avg	**.8816**	**.8612**	**.2286**	**.9959**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
TERMBHURNI S/DN.[821] BU 4821
Substation No/ Name :- 274176 / 33/11kV SURLI
Feeder No / Name : 202 / SHIRAL (T) AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.1919	1.1736	1.2803	1.3226
Max	**1.1919**	**1.1736**	**1.2803**	**1.3226**
Min	**1.1919**	**1.1736**	**1.2803**	**1.3226**
Avg	**1.1919**	**1.1736**	**1.2803**	**1.3226**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
TERMBHURNI S/DN.[821] BU 4821
Substation No/ Name :- 274176 / 33/11kV SURLI
Feeder No / Name : 203 / SURLI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	1.5242	1.4327	1.8176	1.448
24	.1715	.1524	.1524	.2035
Max	**1.5242**	**1.4327**	**1.8176**	**1.448**
Min	**.1715**	**.1524**	**.1524**	**.2035**
Avg	**.8479**	**.7926**	**.985**	**.8258**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
TERMBHURNI S/DN.[821] BU 4821
Substation No/ Name :- 274176 / 33/11kV SURLI
Feeder No / Name : 204 / SHIRAL GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.2896	.2743	.3155
16	.1219	.1067	.1017	.0914
24	.1543	.1524	.1677	.1696
Max	**.1543**	**.2896**	**.2743**	**.3155**
Min	**.1219**	**.1067**	**.1017**	**.0914**
Avg	**.1381**	**.1829**	**.1812**	**.1922**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
TERMBHURNI S/DN.[821] BU 4821
Substation No/ Name :- 274186 / Parite
Feeder No / Name : 201 / KALWEL WASTI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0457	.0457		.0457
2		.0457	.061	.061	.0457
3		.1524	.1524	.061	.061
4		.1524	.1677	.061	.061
5		.1677	.1829	.0914	.061
6		.1981	.2286	.0914	.0762
7			.2591		
8			.2743		
9			.2896		
10			.2896		
11					.2439
12					.2743
13					.2743
14					.2896
15					.2896
16					.2743
17					.2743
18				.2591	.2896
19	.061	.061	.061	.0457	.061
20	.061	.061	.061	.0457	.0457
21	.0457	.061	.061	.0457	.0457
22	.0457	.0457	.061	.0457	.0457
23	.0457	.0457	.061	.0457	.0457
24		.0457	.0457	.061	.0457
Max	**.061**	**.1981**	**.2896**	**.2591**	**.2896**
Min	**.0457**	**.0457**	**.0457**	**.0457**	**.0457**
Avg	**.0518**	**.0902**	**.1439**	**.0762**	**.1425**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
TERMBHURNI S/DN.[821] BU 4821
Substation No/ Name :- 274186 / Parite
Feeder No / Name : 202 / KADAM WASTI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0152	.0152	.0152	.0152
2		.0152	.0152	.0152	.0152
3		.3048	.2439	.0152	.0152
4		.3048	.2591	.0152	.0152
5		.3201	.2743	.0152	.0305
6		.3506	.3201	.0152	.0305
7			.3963		
8			.4115		
9			.4115		
10			.4115		
11					.4268
12					.442
13					.4572
14					.4572
15					.4572
16					.4725
17					.4877
18				.3201	.4877
19	.0152	.0152	.0152		.0152
20	.0152	.0152	.0152	.0152	.0152
21	.0152	.0152	.0152	.0152	.0152
22	.0152	.0152	.0152	.0152	.0152
23	.0152	.0152	.0152	.0152	.0152
24		.0152	.0152	.0152	.0152
Max	**.0152**	**.3506**	**.4115**	**.3201**	**.4877**
Min	**.0152**	**.0152**	**.0152**	**.0152**	**.0152**
Avg	**.0152**	**.1168**	**.1781**	**.0406**	**.1951**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
TERMBHURNI S/DN.[821] BU 4821
Substation No/ Name :- 274186 / Parite
Feeder No / Name : 203 / PARITE AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3932	.3725	.3353	.3768
2		.4096	.3725	.3353	.3768
3		.4424	.4049	1.2193	1.3763
4		.4752	.4534	1.2498	1.6549
5		.5407	.502	1.2955	1.9334
6		.5898	.5668	1.448	2.1136
7				1.8842	2.769
8					3.0312
9					2.9165
10				1.9662	2.5232
11			2.21		
12			2.7435		
13		2.8988	2.7282		
14		3.1255	2.713		
15		3.0769	2.713		
16		2.9959	2.6825		
17		2.4939	2.5911		
18	.3932	2.672	2.4387		
19	.3932	.3725	.381	.3768	.3932
20	.3605	.4049	.3658	.3768	.3768
21	.3605	.4049	.3506	.3605	.3605
22	.3605	.3725	.3506	.3441	.3605
23	.3605	.3563	.3506	.3441	.3441
24		.3932	.3563	.3353	.3605
Max	**.3932**	**3.1255**	**2.7435**	**1.9662**	**3.0312**
Min	**.3605**	**.3563**	**.3506**	**.3353**	**.3441**
Avg	**.3714**	**1.2455**	**1.2824**	**.8479**	**1.3292**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
TERMBHURNI S/DN.[821] BU 4821
Substation No/ Name :- 274187 / Dahiwali
Feeder No / Name : 201 / UPALWATE BOGADA AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0972	.0457	.3201	.3201
2		.0972	.0457	.3201	.3353
3		.0648	.0457	.3201	.3658
4		.0972	.0457	.3521	.4268
5		.081	.061	.3841	.503
6		.081	.0762	.3841	.5639
7		.0972	.0914	.6249	.7926
8		.1296	.1052	.7011	.8535
9		.0914		.0857	.0914
10		.0762	.0895	.1029	.061
11		.0457	.0716	.0686	.061
12		.0457	.0716		.0457
13			.0895		.061
14			.0895		.061
15					.061
16		.061	.0716		.061
17		1.6156	1.6716	.0686	.0914
18	1.3765	1.2498	1.4403	.0857	.0914
19	.9069	.8535	1.0242	.1029	.0914
20	.7449	.6401	.8417	.1029	.0762
21	.583	.4268	.6401	.0857	.061
22	.421	.3658	.6241	.0857	.061
23	.3239	.3353	.3361	.0686	.061
24		.3563	.3048	.3201	.0686
Max	**1.3765**	**1.6156**	**1.6716**	**.7011**	**.8535**
Min	**.3239**	**.0457**	**.0457**	**.0686**	**.0457**
Avg	**.7260**	**.3290**	**.3583**	**.2413**	**.2194**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
TERMBHURNI S/DN.[821] BU 4821
Substation No/ Name :- 274187 / Dahiwali
Feeder No / Name : 202 / DAHIWALI AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.989	1.6766	.2149	.2058
2		2.0576	1.7375	.2126	.2058
3		2.1434	1.8138	.2103	.2058
4		2.2119	1.89	.2279	.2229
5		2.2291	1.9662	.2328	.2401
6		2.332	2.0424	.2507	.2743
7		2.8464	2.1338	.2149	.2401
8		2.8807	2.4383	.1791	.2058
9		.0914	.1254	2.2253	2.3167
10		.0914	.1075	2.6673	2.7435
11		.0762	.0905	2.5911	2.713
12		.0762	.0905		2.6825
13		.0762	.0895		2.713
14		.0762	.0905		2.7435
15		.061	.0724		2.6063
16		.061	.0895		2.4691
17		.0762	.0895	.1029	.0914
18	.1372	.1067	.1433	.2058	.1219
19	.1715	.1524	.2149	.2229	.1829
20	.1543	.1524		.2229	.1981
21	.1543	.1524	.2149	.2229	.1981
22	.1715	.1524	.2149	.2058	.1829
23	.1543	.1524	.2149	.2058	.1829
24		.1543	.1372	.2149	.2058
Max	**.1715**	**2.8807**	**2.4383**	**2.6673**	**2.7435**
Min	**.1372**	**.061**	**.0724**	**.1029**	**.0914**
Avg	**.1572**	**.8500**	**.7689**	**.5700**	**1.0063**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
TERMBHURNI S/DN.[821] BU 4821
Substation No/ Name :- 274187 / Dahiwali
Feeder No / Name : 203 / DAHIWALI BOGADA AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1029	.0762	.1075	.0686
2		.1029	.0762	.1075	.0686
3		.0686	.0762	.1075	.0686
4		.1029	.0762	.1075	.0686
5		.1029	.0762	.1075	.0857
6		.1029	.0914	.1254	.1029
7		.1029	.0914	.1075	.1029
8		.0686	.0716	.1075	.0857
9		1.768	1.7966	.0686	.0762
10		1.89	1.9372	.0686	.061
11		1.9204		.0514	.0457
12		1.768	2.0485		.0457
13		1.5242	1.7869		.0457
14			1.6964		.0457
15			1.6004		.0457
16		1.6156	1.6004		.0457
17		.0457	.0526	1.89	1.768
18	.0857	.061	.0716	1.8595	
19	.1029	.061	.0895	1.8442	1.4022
20	.0686	.0914	.0895	1.7071	1.3413
21	.1029	.0914	.0895	1.6461	1.3108
22	.1029	.0914	.1075	1.6156	1.2803
23	.0857	.0914	.1052	1.5851	1.1736
24		.0857	.0762	.1052	1.5699
Max	**.1029**	**1.9204**	**2.0485**	**1.89**	**1.768**
Min	**.0686**	**.0457**	**.0526**	**.0514**	**.0457**
Avg	**.0915**	**.5391**	**.5993**	**.7010**	**.4743**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
TERMBHURNI S/DN.[821] BU 4821
Substation No/ Name :- 274193 / MIDC TEMBHURNI
Feeder No / Name : 201 / MIDC TEMBHURNI SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4801		.6344	.3429
2		.5144		.4115	.3429
3		.5316		.4115	.3429
4		.463		.4801	.3429
5		.4458		.5144	.3429
6		.4287		.463	.3429
7		.4115		.4458	.3086
8		.4115		.3944	.3086
9		.4973	.5144	.3429	.3601
10		.7716	.9088	.3772	.6173
11		.8059	.7888	.3429	.7373
12		.7545	.9431	.4801	.6687
13		.703	.703		.7888
14		.6859	.7888		.7545
15		.7202	.8402		.7202
16		.8573	.8916	.2058	.7888
17		.6344	.7888	.3086	.7545
18		.6516	.6859	.4287	.7545
19	.5658	.6516	.7202	.4458	.703
20	.5144	.6516	.6516	.4287	.5144
21	.463	.6344	.5487	.4287	.5487
22	.4458	.6344	.5144	.3429	.6344
23	.5144		.5144	.3429	.5144
24		.4801		.4973	.3429
Max	**.5658**	**.8573**	**.9431**	**.6344**	**.7888**
Min	**.4458**	**.4115**	**.5144**	**.2058**	**.3086**
Avg	**.5007**	**.6009**	**.7202**	**.4156**	**.5365**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
TERMBHURNI S/DN.[821] BU 4821
Substation No/ Name :- 274193 / MIDC TEMBHURNI
Feeder No / Name : 202 / KANHERGAON AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5699		1.2193	1.2003
2		1.9052		1.448	1.2003
3		1.7985		1.3413	1.2003
4		1.9814		1.4327	1.3717
5		1.7833		1.829	1.5432
6		1.8747		1.9966	1.7661
7		1.829		1.9662	2.4006
8		1.9052		2.2558	2.5377
9		2.0576	1.9509	2.5206	2.3777
10		2.0748	1.768	2.3663	2.332
19	.2439	.2401	.2439	.2915	.2439
20	.2591	.2058	.2591	.2915	.2286
21	.2439	.2058	.2286	.2915	.2134
22	.2286	.2058	.2134	.2915	.1981
23	.2134		.2134	.2915	.2439
24		.1677		.1677	.2915
Max	**.2591**	**2.0748**	**1.9509**	**2.5206**	**2.5377**
Min	**.2134**	**.1677**	**.2134**	**.1677**	**.1981**
Avg	**.2378**	**1.3203**	**.6968**	**1.2501**	**1.2093**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
TERMBHURNI S/DN.[821] BU 4821
Substation No/ Name :- 274193 / MIDC TEMBHURNI
Feeder No / Name : 203 / VENEGAON AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4572		.4268	.4973
2		.4877		.4572	.4973
3		.5487		.5487	.4973
4		.5639		.5639	.4973
5		.5944		.5792	.6001
6		.6097		.5792	.6859
11		2.3148	1.6004	1.8861	1.6461
12		2.5377	1.9814		2.0881
13		2.4863	2.0119		2.2253
14		2.4863	2.0119		2.1795
15		2.4863	1.9814		2.1491
16		2.3663	1.9509		2.1186
17		2.2291	1.8595		1.9814
18		2.0919	1.7985	2.2291	1.8442
19	.4877	.4801	.4115	.4973	.442
20	.4572	.4801	.3963	.4973	.4115
21	.4725	.4801	.3658	.4973	.4268
22	.442	.4801	.3963	.4973	.4268
23	.4268		.4115	.4973	.442
24		.4268		.4115	.4973
Max	**.4877**	**2.5377**	**2.0119**	**2.2291**	**2.2253**
Min	**.4268**	**.4268**	**.3658**	**.4115**	**.4115**
Avg	**.4572**	**1.2951**	**1.3213**	**.7263**	**1.1077**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
TERMBHURNI S/DN.[821] BU 4821
Substation No/ Name :- 274209 / 33/11 KV BHEND SUB STATION
Feeder No / Name : 201 / 11 KV BHEND AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1372	.1219	.1524	.1524	.1524
2		.1372	.1219	.1524	.1524	.1524
3		.945	.6401	.8535	.2134	.2134
4		1.1888	.8535	1.0669	.2591	.2743
5		1.3108	1.0974	1.3108	.2743	.3353
6		1.3717	1.3413	1.5546	.3658	.3963
7		1.8595	1.9814	1.6461		
8		1.6766	2.0424	2.0729		
9	1.9204	2.0729	2.0424	2.2253		
10	1.6766	1.4937	2.0729	1.1279		
11					1.7375	1.6461
12						1.8595
13						2.0729
14						2.2253
15						2.2558
16						2.2862
17						1.0364
18					2.1643	1.9814
19	.2439	.2134	.2134	.3048	.2439	.3048
20	.1981	.2134	.2439	.2743	.2134	.2743
21	.1524	.1524	.2439	.2439	.2134	.2286
22	.1524	.1219	.2439	.1829	.1219	.1829
23	.1524	.1219	.2134	.1981	.1219	.1829
24		.1524	.1219	.2134	.1524	.1524
Max	**1.9204**	**2.0729**	**2.0729**	**2.2253**	**2.1643**	**2.2862**
Min	**.1524**	**.1219**	**.1219**	**.1524**	**.1219**	**.1524**
Avg	**.6423**	**.8231**	**.8497**	**.8488**	**.4562**	**.9107**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
TERMBHURNI S/DN.[821] BU 4821
Substation No/ Name :- 274232 / MITKALWADI S/S
Feeder No / Name : 201 / MITKALWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.8724	1.6964	1.749	1.6156
2		1.9204	1.7966	1.7532	1.6156
3		1.9685	1.906	1.7532	1.6156
4		1.9528	1.829	1.7328	1.6872
5		2.0165	1.9528	1.7814	1.6872
6		1.9841	1.9204	1.8461	1.6872
7		1.9841	1.9509	1.917	1.7185
8		2.0153	2.1285	1.9826	1.8122
9		2.0805	1.9292	2.0481	1.8435
10		2.0719	1.9216	1.7375	1.9524
11		.0343	.0914	.0572	.104
12		.0419	.1067	.0572	.1052
13		.04	.0914		
14		.0412	.0914		.1214
15		.0457	.0762		.1214
16		.0503	.0914		.1214
17		.0457	.0753		
18		.056	.1067	.0914	.156
19		.0652	.0892	.0914	.1387
20		.0652	.0892	.0667	.1387
21		.0734	.088	.0762	.1387
22	.1029	.0514	.0903	.0667	.1052
23	.1029	.0572	.0743	.0914	.0876
24		.104	.0476	.0743	.0914
Max	**.1029**	**2.0805**	**2.1285**	**2.0481**	**1.9524**
Min	**.1029**	**.0343**	**.0476**	**.0572**	**.0876**
Avg	**.1029**	**.8599**	**.8434**	**.9986**	**.8484**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
TERMBHURNI S/DN.[821] BU 4821
Substation No/ Name :- 274232 / MITKALWADI S/S
Feeder No / Name : 202 / MALEGAON CANAL AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1928	.2033	.1981	.3086
2		.1907	.2195	.1981	.3086
3		.2058	.2195	.2286	.3258
4		.2058	.2743	.2623	.3258
5		.2743	.2743	.3086	.3429
6		.3772	.2926		.3772
7		.463	.2957	.3749	.4115
8		.4115	.3696	.3353	.3429
9		.2947	.2957	.2286	.2743
10		.2218	.2218	.1886	.2572
11		1.4217	1.4575	1.6004	1.8187
12		1.7528	1.8515	1.7654	1.9204
13		1.5546	1.8515		
14		1.7223	1.8515		1.8724
15		1.6105	1.7166		1.9364
16		1.4299	1.6385		1.8724
17		1.5394	1.6549		
18		1.5089	1.704	1.5546	1.6221
19		.3142	.2896	.3258	.3086
20		.2743	.2591	.3429	.2572
21		.2561	.2286	.3429	.2254
22	.208	.2378	.1981	.3429	.208
23	.1907	.2378	.1981	.3258	.208
24		.1907	.2012	.1981	.3429
Max	**.208**	**1.7528**	**1.8515**	**1.7654**	**1.9364**
Min	**.1907**	**.1907**	**.1981**	**.1886**	**.208**
Avg	**.1994**	**.7037**	**.7403**	**.5068**	**.7212**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
TERMBHURNI S/DN.[821] BU 4821
Substation No/ Name :- 278022 / 220/33 kV TEMBHURNI EHV
Feeder No / Name : 408 / JINDAL EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.9259	
2		.9259	
3		.9259	
4		.9259	
5		.9259	
6		.9259	
7		.9259	
8	.7716	.9259	.9259
9		.7716	
10		.7716	
11		.7716	
12		.7716	
13		.7716	
14		.7716	
15		.7716	
16	.9259	.7716	.8745
17	.7716		
18	.7716		
19	.7716		
20	.7716		
21	.7716		
22	.7716		
23	.7716		
24	.8745	.7716	.823
Max	**.9259**	**.9259**	**.9259**
Min	**.7716**	**.7716**	**.823**
Avg	**.7973**	**.8442**	**.8745**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
BARSI DIVISION[531]
TERMBHURNI S/DN.[821] BU 4821
Substation No/ Name :- 278022 / 220/33 kV TEMBHURNI EHV
Feeder No / Name : 409 / MILLENIUM EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1		1.1317	
2		1.1317	
3		1.1317	
4		1.1317	
5		1.1317	
6		1.1317	
7		1.1317	
8	1.2346	1.1317	1.1431
9		1.0288	
10		1.0288	
11		1.0288	
12		1.0288	
13		1.0288	
14		1.0288	
15		1.0288	
16	1.286	1.0288	1.3375
17	1.1317		
18	1.1317		
19	1.1317		
20	1.1317		
21	1.1317		
22	1.1317		
23	1.1317		
24	1.3375	1.1317	1.0059
Max	**1.3375**	**1.1317**	**1.3375**
Min	**1.1317**	**1.0288**	**1.0059**
Avg	**1.178**	**1.0833**	**1.1622**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
MANGALVEDHA[102] BU 6351
Substation No/ Name :- 274028 / 33/11 KV ANDHALGAON SUBSTATION
Feeder No / Name : 201 / 11 KV KHUPSANGI FEEDER Feeder KV- 11 / OUTGOING SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1524	.1524	.1524	.6097	.9145
2	.1524	.1524	.1524	.1524	.1524	.6097	1.2193
3	.1524	.1829	.1829	.1829	.1829	.6097	1.448
4	.2134	.1829	.2286	.2134	.2743	.6097	.7621
5	.3048	.2439	.2743	.2743	.3048	.9145	1.5546
6	.3201	.3353	.3658	.3353	.381	1.1888	1.5699
7	.3506	.3353			.4115	1.1888	1.6004
8		.3658	.3048			1.3717	1.6766
9							1.4327
16	1.5242	1.8595	1.6461	1.6613	1.6766		
17	1.5242	1.829	1.6004	1.3717	1.7071		
18	1.4327	1.5089	1.6766	1.3413	1.4632		
19	.3048	.3658	.3658	.3658	.2591	.2286	
20	.2743	.3048	.3048	.3048	.2591	.1829	.1524
21	.2134	.2743	.2743	.2439	.2439	.1524	.1524
22	.1981	.2286		.2134	.1981	.1524	.1524
23	.1524	.1829		.1829	.1981	.1524	.1524
24	.1524	.1524	.1524	.1524	.1524	.7621	.7316
Max	**1.5242**	**1.8595**	**1.6766**	**1.6613**	**1.7071**	**1.3717**	**1.6766**
Min	**.1524**	**.1524**	**.1524**	**.1524**	**.1524**	**.1524**	**.1524**
Avg	**.4639**	**.5092**	**.5487**	**.4765**	**.5011**	**.6238**	**.9657**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
MANGALVEDHA[102] BU 6351
Substation No/ Name :- 274028 / 33/11 KV ANDHALGAON SUBSTATION
Feeder No / Name : 205 / 11 Kv Kacharewadi feeder Feeder KV- 11 / OUTGOING SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1334	.1524	.1524	.1334	.5304	.4973
2	.1219	.1334	.1524	.1524	.1334	.5304	.5801
3	.1524	.1334	.1905	.1524	.1905	.4973	.779
4	.1524	.1334	.1905	.1905	.2667	.4973	1.2431
5	.2286	.1334	.2286	.1905	.2858	.4973	1.2929
6	.2667	.2286	.3239	.2286	.3239	.6299	1.2929
7	.3239	.2667			.3429	.6962	1.326
8	.2858	.2667	.1524			.9945	1.326
9							1.326
10							1.0442
12							.0572
16	1.0608	1.4586	1.1768	1.0774	1.1934		
17	1.1271	1.4586	1.442	.9602	1.1934		
18	.9614	1.0111	1.2266	.9297	.9945		
19	.2286	.2858	.2286	.2439	.1989	.381	
20	.2667	.2858	.2667	.1677	.2652	.3429	.0953
21	.2667	.1905	.2667	.1372	.2286	.2858	.1143
22	.1715	.1905	.1905	.1219	.1715	.1905	.1143
23	.1334	.1905	.1905	.1067	.1492	.1715	.1524
24	.1524	.1334	.1524	.1524	.1334	.5801	.4641
Max	**1.1271**	**1.4586**	**1.442**	**1.0774**	**1.1934**	**.9945**	**1.326**
Min	**.1219**	**.1334**	**.1524**	**.1067**	**.1334**	**.1715**	**.0572**
Avg	**.3560**	**.3902**	**.4082**	**.3309**	**.3878**	**.4875**	**.7316**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
MANGALVEDHA[102] BU 6351
Substation No/ Name :- 274028 / 33/11 KV ANDHALGAON SUBSTATION
Feeder No / Name : 206 / 11 KV MAHAMADABAD(S) FEEDER Feeder KV- 11 / OUTGOING **SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER**

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.448	1.267	1.4842	1.4842	1.5927		.3258
2	1.5927	1.267	1.4842	1.4842	1.6651		.3258
3	1.8099	1.6289	1.5927	1.6108	1.7737		.362
4	1.8461	1.6289	2.0814	1.7194	1.9909		.3982
5	2.0633	1.9909		2.0814	2.1719		.5068
6	2.2624	2.5339	2.6968	2.7149	2.7149		.6335
7	3.0588	3.5113		3.1855	3.2579		.5611
8		3.4389	3.2579	2.3167			.4706
9							.3982
10							.3258
11							3.5656
12							2.19
13							3.2579
14							3.3846
15							3.7466
16	.3258						3.3846
17	.3258						3.5113
18	.5068					2.3529	3.5475
19	.6335		.724	.7602	.3982	.724	.362
20	.6878	.8507	.5792	.6335	.6335	.6335	.3982
21	.5792	.724	.4344	.5792	.5792	.5068	.3801
22	.362	.5792	.362	.5068	.4344	.4344	.362
23	.362	.3258	.3258	.3982	.4706	.3258	.3258
24	.9955	1.086	1.4842	1.4842	.7602		.3258
Max	**3.0588**	**3.5113**	**3.2579**	**3.1855**	**3.2579**	**2.3529**	**3.7466**
Min	**.3258**	**.3258**	**.3258**	**.3982**	**.3982**	**.3258**	**.3258**
Avg	**1.1787**	**1.6025**	**1.3756**	**1.4971**	**1.4187**	**.8296**	**1.3771**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
MANGALVEDHA[102] BU 6351
Substation No/ Name :- 274029 / 33KV BATHAN S/S
Feeder No / Name : 202 / 11KV SARKOLI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	16-DEC-17
HR	Load (MW)
24	.3086
Max	.3086
Min	.3086
Avg	.3086

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
MANGALVEDHA[102] BU 6351
Substation No/ Name :- 274029 / 33KV BATHAN S/S
Feeder No / Name : 204 / Bathan Gaothan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)
10		.104
11	.112	
24	.112	
Max	.112	.104
Min	.112	.104
Avg	.112	.104

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
MANGALVEDHA[102] BU 6351
Substation No/ Name :- 274031 / 33KV S/S HULJANTI
Feeder No / Name : 201 / 11KV HULJANTI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8573	.9488	.1696	.1943
2		1.0802	.9962	.1526	.1943
3		1.166	1.1069	.1526	.1943
4		1.5261	1.186	.1696	.2105
5		1.7833	1.7394	.2543	.2267
6		2.0576	1.8976	.3052	.2753
7		1.9033	2.0241		.3401
8		2.1262		.3561	.3239
9		1.9204	1.8185	.2883	.2267
10				.2374	
11				2.2382	2.2377
12					1.6244
14				1.7804	1.6575
15				2.1534	
16				2.34	2.2542
17				2.2891	2.1879
18				2.0687	2.1548
19	.3239	.3018	.3077	.3222	.2753
20	.3563	.3222	.2753	.3052	.2753
21	.3239	.2883	.2429	.2713	.2591
22	.2915	.2543	.1943	.2374	.2429
23	.2429	.2204	.1781	.2374	.2105
24		.7545	.8381	.1696	.1943
Max	**.3563**	**2.1262**	**2.0241**	**2.34**	**2.2542**
Min	**.2429**	**.2204**	**.1781**	**.1526**	**.1943**
Avg	**.3077**	**1.1041**	**.9824**	**.7856**	**.7505**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
MANGALVEDHA[102] BU 6351
Substation No/ Name :- 274031 / 33KV S/S HULJANTI
Feeder No / Name : 202 / 11 KV SODDI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2012	.1492	.7209	.7625
2		.1844	.1492	.788	.8288
3		.1677	.1492	.9556	.9116
4		.1677	.1658	1.0898	.9945
5		.218	.1823	1.3413	1.1603
6		.2347	.1989	1.4251	1.2597
7		.1844		1.5424	1.7736
8				1.861	1.873
9				1.9281	1.3757
10		.1006	.1457		
11		1.2742	1.5546		
12		1.4251	1.5223		
13		1.643	1.4251		
14		1.8778	1.5223		
15		1.8442	1.7652		
16		1.9448	1.8138		
17		1.7939	1.6518		
18	1.8564	1.4251			
19	.2267	.2012		.2012	.2347
20	.2753	.2515	.1492	.2012	.2012
21	.2591	.2515	.1492	.1844	.1844
22	.2591	.2347	.1492	.1677	.1677
23	.2429	.218	.1658	.1526	.1509
24		.2012	.1492	.6539	.5801
Max	**1.8564**	**1.9448**	**1.8138**	**1.9281**	**1.873**
Min	**.2267**	**.1006**	**.1457**	**.1526**	**.1509**
Avg	**.5199**	**.7293**	**.6925**	**.8809**	**.8306**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
MANGALVEDHA[102] BU 6351
Substation No/ Name :- 274031 / 33KV S/S HULJANTI
Feeder No / Name : 203 / 11 KV MARAWADE FEEDER SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6325	.8192	.1581	.1638
2		.7907	.8192	.1581	.1638
3		.9488	.9831	.1581	.1638
4		1.1069	1.1469		.1638
5		1.4232	1.2651	.3163	.3277
6		1.8976	1.7394	.3163	.3277
7		2.5301	2.372	.4744	.3277
8		2.5301	2.372		.4915
9		.6325	2.0557	.3163	.3277
10				.3163	
11				1.2651	2.3205
12				1.2651	1.4918
13					2.8178
14				1.2651	2.8178
15				2.372	
16				2.2138	2.652
17					2.652
18					2.652
19	.3277	.3163	.3277	.3163	.3277
20	.3277	.3163	.3277	.3163	.3277
21	.1638	.3163	.1638	.1581	
22	.1638	.1581	.1638	.1581	.1638
23	.1638	.1581	.1638	.1581	.1638
24		.6325	.6554	.1581	.1638
Max	**.3277**	**2.5301**	**2.372**	**2.372**	**2.8178**
Min	**.1638**	**.1581**	**.1638**	**.1581**	**.1638**
Avg	**.2294**	**.9593**	**1.0250**	**.6242**	**1.0004**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
MANGALVEDHA[102] BU 6351
Substation No/ Name :- 274031 / 33KV S/S HULJANTI
Feeder No / Name : 204 / Gaothan Huljanti GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3506	.362	.2804	.3224
2		.3856	.3982	.2804	.3224
3		.4207	.3982	.298	.3582
4		.5609	.4525	.333	.5014
5		.7164	.6154	.6733	.6447
6		.985	.8859	.8859	.905
7		1.1222	.9214	1.0745	1.0608
8		.9134	.8764	.9671	1.0242
9		.6733	.7011	.7796	.7316
10		.6201	.5316	.5847	
11			.5068	.5083	.4938
12		.4031	.4163	.4207	.439
13		.4031	.362		.439
14		.3506	.3258	.4207	.4024
15		.3856	.4344	.4207	.5487
16		.4382	.4344	.4207	.4344
17		.4908	.5068	.5609	.5487
18	.6878	.7087		.6135	.6219
19	.8779	.8954	.8939	.9313	.8779
20	.8048	.8059	.7537	.788	.7499
21	.6219	.6201	.5552	.6379	.5853
22	.439	.4557	.362	.4557	.439
23	.3841	.4075	.3439	.3506	.3439
24			.362	.298	.3403
Max	**.8779**	**1.1222**	**.9214**	**1.0745**	**1.0608**
Min	**.3841**	**.3506**	**.3258**	**.2804**	**.3224**
Avg	**.6359**	**.5960**	**.5391**	**.5645**	**.5711**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
MANGALVEDHA[102] BU 6351
Substation No/ Name :- 274031 / 33KV S/S HULJANTI
Feeder No / Name : 205 / 11 Kv Yedrav Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0937	.0972	.5468	.6154
2		.0937	.1134	.6093	.6478
3		.125	.1134	.703	.6802
4		.1406	.1296	.9061	.7287
5		.1562	.1619	.9374	.7935
6		.2031	.2105	1.406	.9717
7		.2187	.1781	1.5935	1.2631
8		.2187	.1296	1.906	1.5708
9		.1406	.1296	1.656	1.4089
10		.0625	.1781		
11		.8905	1.4998		
12			1.3435		
13		1.9528	.9374		
14		2.1559	1.8591		
15		1.6872	1.8278		
16		2.1247	1.9841		
17		2.1247	1.8278		
18	2.0405	1.8747	1.7654		
19	.1619	.1718	.1943	.1875	.2267
20	.1296	.1562	.1619	.1875	.1781
21	.1134	.1406	.1457	.1562	.1457
22	.1134	.125	.1134	.125	.1296
23	.1134	.1094	.0972	.125	.0972
24		.1094	.0972	.4531	.5344
Max	**2.0405**	**2.1559**	**1.9841**	**1.906**	**1.5708**
Min	**.1134**	**.0625**	**.0972**	**.125**	**.0972**
Avg	**.4454**	**.6555**	**.6373**	**.7666**	**.6661**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
MANGALVEDHA[102] BU 6351
Substation No/ Name :- 274032 / 33/11KV HUNNUR S/S
Feeder No / Name : 201 / 11 kv Hunnur Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1457	.1619	.3887	
2		.1619	.1943	.7611	
3		.1943	.2105	.9555	
4		.2105	.2267	1.166	
5		.2591	.2915	1.5223	
6		.3725	.3239	1.6032	
7		.3887	.3725	1.7328	
8		.3563		1.8461	
9		.2753	.2105	1.7004	
10	.2267	.2105	.1781		
11	1.5384	1.5384	1.5708		
12	1.8947	1.7004	1.7166		
13	1.9757	2.0243	1.9595		
14	1.9433	1.8623	1.7652		
15	1.8461	2.0243	1.9109		
16	1.8461	2.0243	1.8461		
17	1.9757	1.8299	1.8138		
18	1.9109	1.6194	1.5223		
19	.2915	.2267	.2915		.1943
20	.2429	.1943	.2429		.1781
21	.2267	.1943	.2105		.1619
22	.1943	.1943	.1943		.1619
23	.1619	.1781	.1457		.1619
24		.1619	.1619	.3077	
Max	**1.9757**	**2.0243**	**1.9595**	**1.8461**	**.1943**
Min	**.1619**	**.1457**	**.1457**	**.3077**	**.1619**
Avg	**1.1625**	**.7645**	**.7618**	**1.1984**	**.1716**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
MANGALVEDHA[102] BU 6351
Substation No/ Name :- 274032 / 33/11KV HUNNUR S/S
Feeder No / Name : 203 / 11 Kv Mahamdabad Feeder SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0152	.0305	.0762	
2		.0152	.0305	.1372	
3		.0152	.0305	.1829	
4		.0152	.0305	.2591	
5		.0305	.0457	.3048	
6		.0457	.0457	.3201	
7		.061	.0457	.3658	
8		.0457		.442	
9		.0305	.0152	.381	
10	.0152	.0152	.0152		
11		.2134	.2286		
12	.4268	.4858	.3201		
13	.4268	.4268	.381		
14	.4572	.3963	.3506		
15	.3963	.4115	.3506		
16	.3963	.3963	.3201		
17	.381	.3963	.2896		
18	.3658	.3658	.2591		
19	.0457	.0305	.0152		.0305
20	.0305	.0305	.0152		.0305
21	.0152	.0305	.0152		.0305
22	.0152	.0305	.0152		.0305
23	.0152	.0305	.0152		.0305
24		.0152	.0305	.0762	
Max	**.4572**	**.4858**	**.381**	**.442**	**.0305**
Min	**.0152**	**.0152**	**.0152**	**.0762**	**.0305**
Avg	**.2298**	**.1479**	**.1259**	**.2545**	**.0305**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
MANGALVEDHA[102] BU 6351
Substation No/ Name :- 274032 / 33/11KV HUNNUR S/S
Feeder No / Name : 205 / MANEWADI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1543	.1715	.724	
2		.1715	.1886	.9231	
3		.1886	.1886	1.0498	
4		.2058	.2058	1.267	
5		.2058	.2229	1.6651	
6		.2401	.2401	1.7375	
7		.2401	.2572	1.9728	
8		.2401		2.19	
9		.1543	.1715	1.5927	
10	.2058	.2058			
11	1.4575	1.6632	1.4299		
12	1.8519	1.8861	2.1719		
13	1.9033	2.1605	2.4072		
14	1.989	.5144	2.3529		
15		2.1434	2.0995		
16	1.046	2.2291	2.0452		
17	1.5947	2.0919	2.009		
18	1.6118	1.749	1.7375		
19	.2229	.2058	.2353		.1886
20	.2058	.1886	.2172		.1886
21	.1715	.1886	.181		.1715
22	.1715	.1715	.181		.1715
23	.1715	.1715	.1448		.1543
24		.1543	.1715	.4525	
Max	**1.989**	**2.2291**	**2.4072**	**2.19**	**.1886**
Min	**.1715**	**.1543**	**.1448**	**.4525**	**.1543**
Avg	**.9695**	**.7302**	**.8650**	**1.3575**	**.1749**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
MANGALVEDHA[102] BU 6351
Substation No/ Name :- 274032 / 33/11KV HUNNUR S/S
Feeder No / Name : 206 / Lonar SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5487	.6516	.2058	
2		.6344	.6859	.2058	
3		.7202	.7716	.2572	
4		.8573	.8573	.2401	
5		1.046	1.0288	.2401	
6		1.3203	1.2517	.2743	
7		1.6975	1.6632	.3258	
8		2.0405		.3258	
9		1.6975	1.6632	.1886	
10					.3258
11				.3772	1.286
12				1.6289	1.9204
13				1.9547	1.9547
14					1.9547
15					1.9033
16					1.8861
17					2.0576
18					1.8861
19	.3086	.2572	.2572		.2572
20	.2915	.2743	.2401		.2572
21	.2572	.2743	.2401		.2401
22	.2572	.2743	.2229		.2401
23	.2401	.2572	.2058		.2401
24		.4801	.5144	.2401	
Max	**.3086**	**2.0405**	**1.6632**	**1.9547**	**2.0576**
Min	**.2401**	**.2572**	**.2058**	**.1886**	**.2401**
Avg	**.2709**	**.8253**	**.7324**	**.4973**	**1.1721**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
MANGALVEDHA[102] BU 6351
Substation No/ Name :- 274034 / 33/11 KV NIMBONI S/S
Feeder No / Name : 201 / 11KV JALIHAL FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		1.7166	1.7375	1.7833	.3429	.3086
16						1.7652
23	.1715	.1715	.1886	.1886	.2058	.1543
24		.5144	.3772	.4801	.1715	.1543
Max	**.1715**	**1.7166**	**1.7375**	**1.7833**	**.3429**	**1.7652**
Min	**.1715**	**.1715**	**.1886**	**.1886**	**.1715**	**.1543**
Avg	**.1715**	**.8008**	**.7678**	**.8173**	**.2401**	**.5956**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
MANGALVEDHA[102] BU 6351
Substation No/ Name :- 274034 / 33/11 KV NIMBONI S/S
Feeder No / Name : 202 / 11KV NANDESHWAR FEEDER SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.2915	.3086		1.768	1.6004
16		2.1643		2.0119		
23	.2229	.2058	.1886	.1886	.2058	.1715
24		.1715	.1715	.1715	.4287	.4458
Max	**.2229**	**2.1643**	**.3086**	**2.0119**	**1.768**	**1.6004**
Min	**.2229**	**.1715**	**.1715**	**.1715**	**.2058**	**.1715**
Avg	**.2229**	**.7083**	**.2229**	**.7907**	**.8008**	**.7392**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
MANGALVEDHA[102] BU 6351
Substation No/ Name :- 274034 / 33/11 KV NIMBONI S/S
Feeder No / Name : 205 / Gaothan Nimboni GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.8259	.8421	.7449	1.004	.6173
16		.3429	.3772			
23	.3429	.3772	.3601	.3772	.3429	.3601
24		.2743	.3429	.3429	.3429	.3772
Max	**.3429**	**.8259**	**.8421**	**.7449**	**1.004**	**.6173**
Min	**.3429**	**.2743**	**.3429**	**.3429**	**.3429**	**.3601**
Avg	**.3429**	**.4551**	**.4806**	**.4883**	**.5633**	**.4515**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
MANGALVEDHA[102] BU 6351
Substation No/ Name :- 274121 / 33/11KV MARAPUR
Feeder No / Name : 201 / 11KV MARAPUR SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.1248	
2				1.0802	
3				1.1574	
4				1.3272	
5				1.4998	
6				1.6872	
7				2.1285	
8				2.3205	
9		.3475			
10		.1067	.08		
11		2.2565	1.4043		
12		2.4939			
13		2.6052	2.4905		
14		2.4291	2.652		
15		2.3967	2.7681		
16		2.4577	2.6216		
17		2.3644	2.2929	.7316	.7407
18		2.2611	2.1559	.602	.6642
19		.4024	.3772	.3772	.1829
20		.3258	.3315	.3353	.3258
21	.2372		.2743	.2785	.2743
22	.2214		.1947	.2315	.2267
23	.1875		.1467	.1715	.1806
24		.2134		1.2186	1.2186
Max	**.2372**	**2.6052**	**2.7681**	**2.3205**	**1.2186**
Min	**.1875**	**.1067**	**.08**	**.1715**	**.1806**
Avg	**.2154**	**1.5893**	**1.3684**	**1.0170**	**.4767**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
MANGALVEDHA[102] **BU 6351**
Substation No/ Name :- 274121 / 33/11KV MARAPUR
Feeder No / Name : 205 / ITI COLLAGE **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.5376	
2				.506	
3				.5535	
4				.6009	
5				.6642	
6				.7842	
7				.9172	
8				1.1843	
10		.1227	.1187		
11		1.0648	1.1405		
12		1.1702	1.25		
13		1.2334	1.3603		
14		1.1561	1.2803		
15			1.2176		
16		1.1069	1.2492		
17		1.1797	1.2334		
18		1.1797	1.1069	.1134	
19		.2195	.2427	.1075	.1715
20		.1629	.1848	.2241	.2481
21	.1478	.1463	.1478	.1886	.2103
22	.1307	.1075	.1086	.168	.1715
23	.1097	.1052	.1086	.1494	.1187
24		.1075		.5376	.578
Max	**.1478**	**1.2334**	**1.3603**	**1.1843**	**.578**
Min	**.1097**	**.1052**	**.1086**	**.1075**	**.1187**
Avg	**.1294**	**.6473**	**.7678**	**.4824**	**.2497**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
MANGALVEDHA[102] BU 6351
Substation No/ Name :- 274121 / 33/11KV MARAPUR
Feeder No / Name : 206 / GUNJEGAON FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1791	
2				.1791	
3				.1791	
4				.2172	
5				.2561	
6				.3326	
7				.4108	
8				.4294	
9		2.0645			
17				2.649	2.6886
18			.1543	2.4863	2.5301
19		.4163	.4294	.3511	.2058
20		.3292	.3734	.3361	.2774
21	.2743		.2772	.2987	.2507
22	.2507		.2172	.2427	.2149
23	.2149		.181	.1867	.1772
24		1.5432		.181	.1867
Max	**.2743**	**2.0645**	**.4294**	**2.649**	**2.6886**
Min	**.2149**	**.3292**	**.1543**	**.1791**	**.1772**
Avg	**.2466**	**1.0883**	**.2721**	**.5572**	**.8164**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
MANGALVEDHA[102] BU 6351
Substation No/ Name :- 274140 / 33/11KV Bramhapuri S/S
Feeder No / Name : 201 / 11 Kv Machnur new SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0549	.8078	.0732
2	.0514	.0549	.8383	.0732
3	.0514	.0549	.8535	.0732
4	.0514	.0549	.9145	.0914
5	.0514	.0549	.945	.0914
6	.0514	.0549	.9907	.0914
7	.0514	.0549	1.0669	.1097
8	.0514	.0549	1.1736	1.1142
9	.0514	.0549	1.2289	1.1736
10	.0514	.0514	.0549	.0514
11	1.2346	1.3717	.0549	.0514
12	1.326	1.4022	.0549	.0514
13	1.3717	1.4022	.0549	.0514
14	1.3717	1.4022	.0549	.0514
15	1.4022	1.3717		.0514
16	1.3108	1.3108		.0514
17	1.3927	1.3108		.0514
18	1.278	1.2498	.0549	.0514
19	.0549	.0514	.0549	.0514
20	.0549	.0514	.0549	.0514
21	.0549	.0514	.0549	.0514
22	.0549	.0514	.0549	.0514
23	.0549	.0514	.0549	.0514
24	.0514	.0549	.8078	.0732
Max	**1.4022**	**1.4022**	**1.2289**	**1.1736**
Min	**.0514**	**.0514**	**.0549**	**.0514**
Avg	**.4803**	**.4866**	**.4872**	**.1535**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
MANGALVEDHA[102] BU 6351
Substation No/ Name :- 274140 / 33/11KV Bramhapuri S/S
Feeder No / Name : 202 / 11 Kv Bramhpuri Feeder SEPARATED AG FEEDERS HAVING SPECIAL River Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6226	.0686	.0732
2	.6859	.6226	.0686	.0732
3	.7888	.5735	.0686	.0732
4	.7888	.5735	.0686	.0732
5	.7011	.6226	.0686	.0732
6	.7164	.6554	.0686	.0732
7	.7316	.6882	.0686	.0732
8	.7316	.7373	.0686	.0732
9	.7316	.4915	.0732	.0686
10	.0686	.0686	.0732	.0686
11	.0686	.0686	.8192	.5792
12	.0686	.0686	.8029	.7468
13	.0686	.0686	.8356	
14	.0686	.0686	.852	.7468
15	.0686	.0686	.852	.7621
16	.0686	.0686	.8356	.7773
17	.0732	.0686	.9175	.7926
18	.0732	.0686	.9503	.823
19	.0732	.0686	.0732	.0686
20	.0732	.0686	.0732	.0686
21	.0732	.0686	.0732	.0686
22	.0732	.0686	.0732	.0686
23	.0732	.0732	.0732	.0686
24	.6859	.6554	.0686	.0732
Max	**.7888**	**.7373**	**.9503**	**.823**
Min	**.0686**	**.0686**	**.0686**	**.0686**
Avg	**.3433**	**.3003**	**.3331**	**.2768**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
MANGALVEDHA[102] BU 6351
Substation No/ Name :- 274140 / 33/11KV Bramhapuri S/S
Feeder No / Name : 203 / 11kv GFSS Bramhapuri GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1448	.1372	.1448
2	.1543	.1448	.1372	.1448
3	.1715	.1448	.1715	.1629
4	.2058	.181	.1886	.2172
5	.2401	.2172	.2401	.2715
6	.2915	.2896	.2743	.3258
7	.2743	.3077	.3086	.3258
8	.2572	.2896	.2915	.2896
9	.2058	.1991	.2715	.2058
10	.1886	.1715	.1991	.1886
11	.1886	.1372	.181	.1829
12	.1715	.1715	.1991	.1715
13	.1372	.1715	.1991	.1543
14	.1372	.1372	.1991	.1372
15	.1543	.1372	.1629	.12
16	.12	.1029	.1448	.12
17	.1629	.1543	.1629	.1372
18	.1991	.2229	.181	.1715
19	.2353	.2572	.2715	.1886
20	.2353	.2229	.2353	.1886
21	.2172	.2229	.2172	.1886
22	.1991	.1886	.2172	.1715
23	.1629	.1543	.1629	.1543
24	.1543	.1629	.1372	.1629
Max	**.2915**	**.3077**	**.3086**	**.3258**
Min	**.12**	**.1029**	**.1372**	**.12**
Avg	**.1924**	**.1889**	**.2038**	**.1886**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
MANGALVEDHA[102] BU 6351
Substation No/ Name :- 274140 / 33/11KV Bramhapuri S/S
Feeder No / Name : 204 / 11 KV BRAHAMPURI BORE SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7164	.7373	.0686	.0732
2	.7164	.7537	.0686	.0732
3	.7621	.7701	.0686	.0732
4	.7926	.7865	.0686	.0732
5	.823	.7865	.0686	.0732
6	.884	.8029	.0686	.0732
7	.9602	.8848	.0686	.0732
8	1.166	1.0322	.0686	.0732
9	1.0212	.7537	.0732	.0686
10	.0732	.0686	.0732	.0686
11	.0686	.0686	1.0159	1.2174
12	.0686	.0686	1.1797	1.1126
13	.0686	.0686	1.1633	1.1431
14	.0686	.0686	1.2944	1.1888
15	.0686	.0686	1.2452	1.2193
16	.0686	.0686	1.2616	1.2346
17	.0732	.0686	1.2452	1.2346
18	.0732	.0686	1.1469	1.0974
19	.0732	.0686	.0732	.0686
20	.0732	.0686	.0732	.0686
21	.0732	.0686	.0732	.0686
22	.0732	.0686	.0732	.0686
23	.0732	.0686	.0732	.0686
24	.7164	.7373	.0686	.0732
Max	**1.166**	**1.0322**	**1.2944**	**1.2346**
Min	**.0686**	**.0686**	**.0686**	**.0686**
Avg	**.3981**	**.3752**	**.4451**	**.4411**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
MANGALVEDHA[102] BU 6351
Substation No/ Name :- 274140 / 33/11KV Bramhapuri S/S
Feeder No / Name : 205 / Machnur AG-2
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0686	.0732	.6401	.6554
2		.0686	.0732	.6401	.6882
3		.061	.0732	.6706	.6882
4		.0686	.0732	.6706	.6882
5		.0686	.0732	.7011	.7209
6		.0686	.0732	.7316	.7209
7		.0686	.0732	.7773	.7865
8		.0686	.0732	.9145	.9012
9		.0686	.0732	1.0322	.9145
10		.0686	.0686	.0732	.0686
11		1.0669	1.0822	.0732	.0686
12		1.1431	1.2041	.0732	.0686
13		1.1431	1.2193	.0732	.0686
14		1.0364	1.2193	.0732	.0686
15		1.0364	1.1431		.0686
16		1.0059	1.1431		.0686
17		1.1797	.9907		.0686
18		.9831	.9907	.0732	.0686
19	.0732	.0732	.0686	.0732	.0686
20		.0732	.0686	.0732	.0686
21		.0732	.0686	.0732	.0686
22		.0732	.0686	.0732	.0686
23		.0732	.0686	.0732	.0686
24		.0686	.0732	.6401	.6554
Max	**.0732**	**1.1797**	**1.2193**	**1.0322**	**.9145**
Min	**.0732**	**.061**	**.0686**	**.0732**	**.0686**
Avg	**.0732**	**.4045**	**.4223**	**.3916**	**.3492**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
MANGALVEDHA[102] BU 6351
Substation No/ Name :- 274185 / 33/11 KV KHOMNAL SUBSTATION
Feeder No / Name : 201 / 11 KV KHOMNAL AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.852	.6859	.1886	.1372
2		.9831	.7164	.1886	.1372
3		1.0486	.7926	.1886	.1372
4		1.1142	.9145	.2058	
5		1.6057	1.0364	.2743	.2439
6		1.6956	1.1736	.3772	.3658
7		1.7635	1.829	.5144	.4572
8		2.0645	2.0119	.4458	.381
9		1.9334	1.9052	.2915	.2915
10					.2572
11				1.7101	2.2466
12					2.3807
13					2.304
14					2.2874
15			.1372		1.0111
16			.1715		
17			.1886		
18			.2058	1.7528	1.5775
19	.3277	.3201	.2915	.3353	.2915
20	.2949	.3048	.2743	.2743	.2743
21	.2622	.2134	.2915	.2134	.2401
22	.1966	.1829	.2058	.1829	.2229
23	.1966	.1677	.1886	.1524	.1715
24		.7865	.6554	.1715	.1372
Max	**.3277**	**2.0645**	**2.0119**	**1.7528**	**2.3807**
Min	**.1966**	**.1677**	**.1372**	**.1524**	**.1372**
Avg	**.2556**	**1.0024**	**.7198**	**.4393**	**.7406**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
MANGALVEDHA[102] BU 6351
Substation No/ Name :- 274185 / 33/11 KV KHOMNAL SUBSTATION
Feeder No / Name : 202 / 11 KV DONGARGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1677	.1524	.463	.2743
2		.1696	.1524	.463	.2743
3		.1696	.1524	.4801	.2896
4		.2035		.5487	.381
5		.2058	.2134	.6687	.5335
6		.3052	.3201	.8059	.6859
7		.4115	.3963	.9945	1.1888
8		.3605	.3658	1.406	1.4175
9		.2622	.2439	1.2689	1.2308
10					.2317
11		1.1004	1.1149	.1981	
12		1.1728	1.3032		
13		1.2742	1.4045		.1067
14		1.2742	1.4045		.1372
15		1.2163	1.3756		.1562
16		1.1728	1.3032		.2058
17		1.1004	1.3176		.1372
18		1.1279	1.4403	.2439	.2743
19	.2949	.3048	.3258	.3506	.3258
20	.2622	.2743	.2915	.3048	.2743
21	.2713	.2134	.2401	.2134	.2058
22	.2374	.1981	.2058	.1829	.2058
23	.2035	.1829	.2058	.1829	.1715
24		.2058	.1524	.4801	.2743
Max	**.2949**	**1.2742**	**1.4403**	**1.406**	**1.4175**
Min	**.2035**	**.1677**	**.1524**	**.1829**	**.1067**
Avg	**.2539**	**.5684**	**.6401**	**.5444**	**.4083**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
MANGALVEDHA[102] BU 6351
Substation No/ Name :- 274185 / 33/11 KV KHOMNAL SUBSTATION
Feeder No / Name : 203 / 11 KV KHOMNAL GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0373	.0187		.0187
2		.0373	.0187	.0187	.0187
3		.0373	.0187	.0373	.0373
4		.056	.0373	.056	.0373
5		.0747	.056	.0934	.0747
6		.0934	.1307	.112	.112
7		.1307	.1307	.1494	.1307
8		.0934	.0934	.0934	.1307
9		.0492	.056	.0373	.0747
10		.0373	.0373	.0377	.0373
11		.0373	.0189	.0377	.0377
12		.0377	.0189	.0189	.0377
13		.0377	.0377	.0189	.0189
14		.0189	.0377	.0377	.0377
15		.0189	.0377	.0377	.0377
16		.0189	.0377		.0373
17		.0377	.0377	.0373	.0373
18		.0187	.056	.056	.0747
19	.0934	.0934	.112	.0373	.0934
20	.0934	.0934	.0934	.0934	.0747
21	.0747	.056	.0747	.056	.0747
22	.056	.0373	.056	.0373	.056
23	.0373	.0373	.0373	.0187	.0373
24		.0373	.0187	.0373	.0187
Max	**.0934**	**.1307**	**.1307**	**.1494**	**.1307**
Min	**.0373**	**.0187**	**.0187**	**.0187**	**.0187**
Avg	**.0710**	**.0511**	**.0530**	**.0527**	**.0561**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR (U)[099] BU 6319
Substation No/ Name :- 274116 / 33/11 KV PADHARPUR (U)
Feeder No / Name : 201 / DARSHAN MANDAP SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.463	.4801	.4973
2	.5847	.463	.463	.4801
3	.5658	.463	.463	.4801
4	.6036	.5144	.5144	.5144
5	.7167	.583	.6173	.5658
6	.811	.8745	.823	.8059
7	.9808	.9619	.8573	.8745
8	.9242		.8402	.8573
9	.9242	.9054	.8676	.8676
10	.8676	.8299	.7922	.811
11	.8676	.8865	.811	.7167
12	.811	.6979	.811	.811
13	.811	.7545	.7922	.7545
14	.7545	.7545	.7167	.7733
15	.7356	.7167	.679	
16	.6344	.6859	.6001	.1715
17	.6859	.7202	.6516	.5487
18	1.2003	1.2003	1.046	.7373
19	1.2517	1.2003	1.286	.7373
20	1.166	1.1145	1.166	.6516
21	.9602	.8916	.9431	.5316
22	.7545	.6859	.7202	.5144
23	.6173	.583	.5658	.2743
24	.7356	.4801	.4801	.5144
Max	**1.2517**	**1.2003**	**1.286**	**.8745**
Min	**.5658**	**.463**	**.463**	**.1715**
Avg	**.8153**	**.7578**	**.7495**	**.6300**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR (U)[099] BU 6319
Substation No/ Name :- 274116 / 33/11 KV PADHARPUR (U)
Feeder No / Name : 202 / 11KV GANESHNAGAR SHEDDABLE URBAN PANDHARPUR Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5093	.4287	.4115	.4458
2	.5093	.4115	.4115	.4115
3	.5093	.4115	.4287	.4115
4	.5658	.4287	.4287	.4115
5	.6224	.4801	.4801	.4458
6	.7167	.6344	.6173	.583
7	.9242	.8402	.8402	.7888
8	.811	.8865	.7716	.7545
9	.7733	.8299	.811	.7545
10	.679	.3206	.6036	.6036
11	.6224	.679	.6036	.6413
12	.6602	.6224	.6224	.6224
13	.6413	.5658	.547	.6224
14	.6413	.6979	.5093	.5093
15	.6224	.5658	.4904	.463
16	.5144	.5144	.4801	.4458
17	.5487		.5144	.5144
18	.6687	.6516	.6173	.6516
19	.8059	.8059	.823	.7888
20	.7888	.7716	.7888	.8059
21	.7202		.7202	.7545
22	.6516	.6516	.6344	.6859
23	.5487	.5487	.5144	.4973
24	.5658	.4458	.4115	.4801
Max	**.9242**	**.8865**	**.8402**	**.8059**
Min	**.5093**	**.3206**	**.4115**	**.4115**
Avg	**.6509**	**.5997**	**.5867**	**.5872**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR (U)[099] BU 6319
Substation No/ Name :- 274116 / 33/11 KV PADHARPUR (U)
Feeder No / Name : 203 / CABLE EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0343	.0229	.0343
2	.0377	.0343	.0343	.0343
3	.0377	.0343	.0343	.0343
4	.0377	.0343	.0343	.0343
5	.0377	.0343	.0343	.0343
6	.0377	.0343	.0343	.0343
7	.0377	.0343	.0343	.0343
8	.0377	.0377	.0343	.0343
9	.0377	.0377	.0377	.0377
10	.0377	.0377	.0377	.0377
11	.0377	.0377	.0377	.0377
12	.0377	.0377	.0377	
13	.0377	.0377	.0377	.0377
14	.0377	.0377	.0377	.0377
15	.0377	.0377	.0377	.0343
16	.0343	.0343	.0343	.0343
17	.0343	.0343	.0343	.0343
18	.0343	.0343	.0343	.0343
19	.0343	.0343	.0343	.0343
20	.0343	.0343	.0343	.0343
21	.0343	.0343	.0343	.0343
22	.0343	.0343	.0343	.0343
23	.0343	.0343	.0343	.0343
24	.0377	.0343	.0343	.0343
Max	**.0377**	**.0377**	**.0377**	**.0377**
Min	**.0343**	**.0343**	**.0229**	**.0343**
Avg	**.0366**	**.0354**	**.0348**	**.0350**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR (U)[099] BU 6319
Substation No/ Name :- 274116 / 33/11 KV PADHARPUR (U)
Feeder No / Name : 204 / 11 KV AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1372	.12	
2	.132	.1372	.12	
3	.132	.1372	.12	
4	.1509	.1372	.1372	
5	.1509	.1543	.1372	
6	.1698	.1543	.1372	
7	.1698	.1886	.1886	
8	.2075	.2263	.1886	
9	.2075	.2263	.1886	
11				.2452
12				.2829
13				.3018
14				.3018
17				.1715
24	.1509	.1372	.12	
Max	**.2075**	**.2263**	**.1886**	**.3018**
Min	**.132**	**.1372**	**.12**	**.1715**
Avg	**.1603**	**.1636**	**.1457**	**.2606**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR (U)[099] BU 6319
Substation No/ Name :- 274116 / 33/11 KV PADHARPUR (U)
Feeder No / Name : 205 / 11 KV SARGAM SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3961	.3258	.3086	.3086
2	.3772	.3258	.3086	.3086
3	.3395	.3258	.3086	.3086
4	.3395	.3429	.3429	.3086
5	.3772	.3772	.3772	.3429
6	.4527	.4801	.4115	.4458
7	.5281	.5144	.4801	.4801
8	.5281	.5281	.4458	.463
9	.547	.4904	.4904	.4715
10	.4904	.5281	.4527	.4904
11	.5658	.5281	.4904	.5281
12	.5658	.5281	.5281	.5658
13	.5281	.4904	.5281	.5281
14	.5281	.4904	.5281	.4904
15	.5281	.4904	.4904	.4287
16	.4801	.4458	.4801	.4115
17	.5144	.5144	.5144	.5144
18	.6001	.6173	.5487	.583
19	.6173	.6687	.5658	.583
20	.5658	.5144	.5316	.5144
21	.4973	.4801	.463	.4115
22	.4115	.3772	.3772	.4115
23	.3772	.3429	.3429	.3429
24	.4338	.3429	.3429	.3429
Max	**.6173**	**.6687**	**.5658**	**.583**
Min	**.3395**	**.3258**	**.3086**	**.3086**
Avg	**.4829**	**.4612**	**.4441**	**.4410**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR (U)[099] BU 6319
Substation No/ Name :- 274116 / 33/11 KV PADHARPUR (U)
Feeder No / Name : 206 / 11 KV AMBIKA SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6224	.5144	.5144	.5144
2	.6036	.5144	.5144	.5144
3	.6036	.5144	.5487	.5144
4	.7167	.5658	.6001	.5658
5	.811	.6687	.6859	.6516
6	1.094	1.1145	1.0117	1.0117
7	1.3392	1.1831	1.166	1.1831
8	1.1694	1.2449	.9945	1.1488
9	.8676	1.1317	.9431	1.1317
10	.8865	.811	.7545	.8299
11	.8865	.7733	.7545	.7733
12	.7545	.6979	.7356	.6979
13		.6979	.7167	.7167
14	.679	.6224	.679	.6602
15	.6413	.6413	.6224	
16	.6173	.6173	.6001	.4801
17	.6859	.6173	.6516	.6344
18	.9774	1.0117	.9259	.8916
19	1.1488	1.0974	1.0631	
20	1.0288	.9774	.9774	.9602
21	.8916	.8573	.8573	.8573
22	.7202	.703	.7202	.823
23	.6001	.5658	.5658	.5658
24	.7167	.5144	.5144	.5144
Max	**1.3392**	**1.2449**	**1.166**	**1.1831**
Min	**.6001**	**.5144**	**.5144**	**.4801**
Avg	**.8288**	**.7774**	**.7549**	**.7564**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR (U)[099] BU 6319
Substation No/ Name :- 274144 / 33/11 KV LINK ROAD
Feeder No / Name : 201 / 11 KV Manisha Nagar SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3326	.3142	.3142	.3077
2		.2957	.2957	.2957	.2896
3		.2957	.2957	.2772	.2896
4		.2957	.2957	.2772	.2896
5		.3696	.3696	.3881	.362
6		.4805	.462	.5175	.4525
7		.7023	.5729	.6838	.6697
8		.7392	.7207	.8131	.7602
9		.5487	.5144	.6859	.6859
10		.4458	.4115	.4458	.4458
11		.4115	.3944	.4801	.3944
12		.3772	.3601		.3429
13		.3601	.3429		.3258
14		.3429	.3429	.4115	.3258
15		.3429	.2743	.2915	.3086
16		.3258	.3258	.3772	.3086
17		.3982	.6516	.4163	.4251
18		.5973	.6335	.5249	.5544
19		.6516	.6516	.6335	.6099
20		.6516	.6335	.6154	.6468
21		.6154	.5973	.5611	.5544
22	.5175	.6154	.5611	.5249	.499
23	.4251	.4435	.4251	.362	.3881
24		.3511	.3326	.3142	.3077
Max	**.5175**	**.7392**	**.7207**	**.8131**	**.7602**
Min	**.4251**	**.2957**	**.2743**	**.2772**	**.2896**
Avg	**.4713**	**.4579**	**.4491**	**.4641**	**.4393**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR (U)[099] BU 6319
Substation No/ Name :- 274144 / 33/11 KV LINK ROAD
Feeder No / Name : 202 / 11KV PANI PURWATHA EXP. NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2218	.2587	.2218	.2241
2		.2402	.2957	.2218	.2241
3		.2957	.2957	.3142	.2987
4		.3696	.2957	.3881	.5228
5		.499	.499	.5359	.5601
6		.6653	.6653	.6653	.6908
7		.6838	.7207	.6653	.6908
8		.6468	.6653	.6283	.6722
9		.6001	.5316	.5487	.5487
10		.5658	.5316	.5487	.5658
11		.5316	.5144	.5144	.583
12		.5316	.4801		.5658
13		.5144	.4801		.6859
14		.4801	.4801	.463	.7716
15		.4973	.4458	.2915	.7373
16		.5487	.3944	.3772	.703
17		.5975	.5788	.4108	.9055
18		.5601	.5415	.6161	.8686
19		.3361	.3361	.5788	.7392
20		.2427	.2987	.5601	.3142
21		.2241	.3174	.5041	.3326
22	.2218	.2427	.2987	.4481	.3511
23	.2218	.2402	.2587	.5041	.3142
24		.2218	.2402	.2218	.2241
Max	**.2218**	**.6838**	**.7207**	**.6653**	**.9055**
Min	**.2218**	**.2218**	**.2402**	**.2218**	**.2241**
Avg	**.2218**	**.4399**	**.4343**	**.4649**	**.5456**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR (U)[099] BU 6319
Substation No/ Name :- 274144 / 33/11 KV LINK ROAD
Feeder No / Name : 203 / 11 KV ISBAWI SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.462	.4805	.499	.462
2		.5175	.462	.462	.4435
3		.5175	.462	.4805	.3881
4		.5359	.462	.462	.3881
5		.6468	.5729	.5729	.5359
6		.8686	.7392	.8131	.7023
7		1.1643	.9055	1.1458	1.0164
8		1.0719	1.1273	1.0719	1.1273
9		.9602	1.0288	.8059	.5487
10		.7373	.6687	.6344	.6173
11		.6859	.6516	.6173	.6001
12		.5487	.6516		.6001
13		.5658	.6173		.6173
14		.6001	.6173	.6859	.6516
15		.5316	.6001	.583	.5144
16		.5144	.5316	.5658	.583
17		.7762	.8131	.6838	.8131
18		.9425	.8501	.8316	.8871
19		.9795	.9979	1.0349	.924
20		.9425	.924	.961	.4251
21		.961	.9425	.9425	.8316
22	.8316	.961	.8501	.8686	.7577
23	.6653	.6283	.6653	.6283	.5914
24		.5359	.499	.5729	.4805
Max	**.8316**	**1.1643**	**1.1273**	**1.1458**	**1.1273**
Min	**.6653**	**.462**	**.462**	**.462**	**.3881**
Avg	**.7485**	**.7356**	**.7134**	**.7238**	**.6461**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR (U)[099] BU 6319
Substation No/ Name :- 274144 / 33/11 KV LINK ROAD
Feeder No / Name : 402 / 33KV Bandishegaon NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / INCOMING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		5.5996	5.8213	4.3799	6.3203
2		5.9877	6.0431	4.4907	6.7638
3		6.2649	6.3203	4.768	7.0965
4		6.5975	6.8193	5.0452	7.54
5		7.0965	7.6509	5.3778	8.3716
6		7.8727	8.2608	6.154	9.0369
7		7.1519	7.7063	5.0452	9.425
8		7.54	7.54	5.7659	10.4784
9		6.5329	1.8519	6.2243	5.7613
10		1.749	1.5947	1.8004	1.749
11		9.7737	9.928	4.321	6.893
12		10.751	10.3395		4.8868
13		10.9054	10.3395		8.2305
14		10.4424	10.2881	5.9156	8.1276
15		10.2366	9.5679	10.5967	8.2819
16		10.5453	9.7737	10.8025	8.0761
17		11.1991	10.0903	10.9682	9.1478
18		10.9774	10.2566	10.8111	6.8193
19		3.1047	3.1602	3.2156	3.1602
20		2.7721	2.8829	2.8275	2.9384
21		2.5503	2.6057	2.5503	2.5503
22	2.1622	2.2731	2.3285	2.384	2.2177
23	1.9959	2.0513	1.9959	3.8255	3.8255
24		5.4332	5.7105	4.2135	6.3758
Max	**2.1622**	**11.1991**	**10.3395**	**10.9682**	**10.4784**
Min	**1.9959**	**1.749**	**1.5947**	**1.8004**	**1.749**
Avg	**2.0791**	**6.8920**	**6.6198**	**5.5220**	**6.4197**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274048 / 33/11 KV BHALWANI SUBSTATION
Feeder No / Name : 201 / 11KV Bhalwani SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.406	1.5893	1.4403	1.1603
2	.2058	.2218	.1715	.9945
3	.2058	.2218	.1715	.9945
4	.2401	.2587	.2058	.9945
5	.2743	.3142	.2572	1.1603
6	.3258	.3696	.3258	1.4918
7	.3258	.3696	.3086	1.9393
8	.3258	.3326	.3429	2.2708
9	.2439	.2439	.2572	2.2634
16		.1981		.1543
17	.2402	.2401	.2134	.1715
18	2.7681	2.7435	2.1548	.2058
19	***	2.572	2.3205	.2401
20	2.2045	2.1434	1.8233	.2572
21	1.6575	1.7147	1.6575	.2743
22	1.5746	1.6289	1.4918	.2401
23	1.5249	1.5261	1.4089	.2229
24	1.5775	1.5249	1.4403	1.326
Max	**12.4314**	**2.7435**	**2.3205**	**2.2708**
Min	**.2058**	**.1981**	**.1715**	**.1543**
Avg	**1.6195**	**1.0118**	**.9407**	**.9090**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274048 / 33/11 KV BHALWANI SUBSTATION
Feeder No / Name : 202 / 11KV Jainwadi SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.462	.4287	.462
2	1.3717	1.326	1.2003	.462
3	1.3717	1.326	1.286	.462
4	1.4575	1.4089	1.286	.499
5	1.6289	1.5746	1.4575	.5544
6	1.8347	1.8233	1.8347	.6468
7	2.2291	2.2377	2.3148	
8	2.7606	2.6023	2.8121	
9	.4572	2.4387	2.2634	
10				2.915
11				2.8292
12				2.5892
13				2.4006
14				2.2634
15				2.2119
16		.3353		2.1948
17		.4115	.3963	1.9547
18	.5729	.4458	.5544	.4115
19	.6099	.4801	.7023	.4287
20	.5729	.4801	.6468	.4458
21	.5175	.4801	.5914	.4801
22	.4805	.4287	.499	.4458
23	.462	.4287	.4805	.4458
24	.4287	.4287	.4287	.462
Max	**2.7606**	**2.6023**	**2.8121**	**2.915**
Min	**.4287**	**.3353**	**.3963**	**.4115**
Avg	**1.0740**	**1.0621**	**1.1284**	**1.2174**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274048 / 33/11 KV BHALWANI SUBSTATION
Feeder No / Name : 203 / 11 KV KESKARWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0924	.1029	.1109
2	.1029	.1109	.1029	.1109
3	.1029	.1109		.1109
4	.1372	.1294	.1372	.1294
5	.1715	.1663	.1715	.1848
6	.1886	.2218	.2058	.2402
7				.2033
8				.1663
9				.1543
10		1.6766	1.6766	
11	1.4937	1.6461	1.4937	
12	1.448	1.5242	1.4327	
13	1.3717	1.4632		
14	1.2955	1.387		
15	1.2193	1.3565		
16		1.3413		.1029
17	1.1934	1.4746	1.1584	.1543
18	.1109	.1029	.1663	2.0748
19	.1109	.1372	.1663	2.0576
20	.1294	.1543	.1478	1.8861
21	.1109	.1543	.1294	1.7147
22	.1109	.1372	.1109	1.5432
23	.1109	.1029	.1109	1.4575
24	.0857	.0924	.1029	.1109
Max	**1.4937**	**1.6766**	**1.6766**	**2.0748**
Min	**.0857**	**.0924**	**.1029**	**.1029**
Avg	**.5042**	**.6468**	**.4635**	**.6952**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274048 / 33/11 KV BHALWANI SUBSTATION
Feeder No / Name : 204 / 11 KV BHALWANIN GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2934	.3269	.2667	.3429
2	.2934	.3269	.3429	.3429
3	.2934	.3418	.2667	.3334
4	.3334	.4012	.3334	.3334
5	.4601	.5201	.4207	.4207
6	.6573		.5916	.6704
7	.631	.8471	.5521	.7099
8	.5916	.639	.5521	.5784
9	.4268	.4401	.3681	.4338
10	.3734	.3467	.2934	.4001
11	.2534	.2401	.2743	.3467
12	.2134	.2134	.2134	.2667
13	.2134	.2134	.2134	.2134
14	.2134	.2134		.2134
15	.2401	.2134		.2401
16		.2401		.2401
17	.3567	.2934	.3601	.2534
18	.5647	.3467	.4755	.3334
19	.6539	.4995	.6687	.4668
20	.6093	.5784	.6093	.1578
21	.5201	.539	.5201	
22	.4458	.4601	.3567	
23	.3567	.2761	.3121	
24	.2934	.3269	.2934	.3269
Max	**.6573**	**.8471**	**.6687**	**.7099**
Min	**.2134**	**.2134**	**.2134**	**.1578**
Avg	**.4038**	**.3845**	**.3945**	**.3631**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274048 / 33/11 KV BHALWANI SUBSTATION
Feeder No / Name : 205 / 11 KV CHOUGHULEWADI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.5089	1.3717	1.5775
2	.1715	.1524	.1715
3	.1715	.1524	.1715
4	.1886	.1677	.2401
5	.2058	.1829	.2401
6	.2401	.1981	.2743
7	.2229	.2134	.2401
8		.2134	.2058
9	.1829	.1829	.1543
16		.1067	
17	.1109	.12	.1067
18	1.989	2.0576	1.989
19	2.0553	2.1262	2.1382
20	1.989	2.0576	1.8233
21	1.8233	1.8861	1.6575
22	1.8233	1.8861	1.6575
23	1.6244	1.6461	1.4918
24	1.5432	1.7002	1.6289
Max	**2.0553**	**2.1262**	**2.1382**
Min	**.1109**	**.1067**	**.1067**
Avg	**.9907**	**.9123**	**.9275**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274048 / 33/11 KV BHALWANI SUBSTATION
Feeder No / Name : 206 / 11 KV GARDI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2058	.1829	.2572
2	.6859	.6097	.6859
3	.6859	.6097	.8573
4	.9431	.8383	.9431
5	1.0288	.9145	1.286
6	1.286	1.0669	
7	1.8861	1.6766	2.0576
8	2.4006	1.9814	2.2291
9	1.9052	1.9814	2.0576
16		.1829	
17	.1848	.2058	.1829
18	.3696	.2058	.3326
19	.3696	.2572	.3696
20	.3142	.2572	.3696
21	.2772	.2572	.3696
22	.2772	.2572	.1848
23	.2772	.2572	.1848
24	.2058	.1829	.2572
Max	**2.4006**	**1.9814**	**2.2291**
Min	**.1848**	**.1829**	**.1829**
Avg	**.7825**	**.6625**	**.7891**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274048 / 33/11 KV BHALWANI SUBSTATION
Feeder No / Name : 207 / 11 KV SATPUTEWADI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1524	.1715
2	.1715	.1524	.1715
3	.1715	.1524	.1715
4	.2058	.1981	.2058
5	.2401	.2286	.2401
6	.2743	.2743	.2743
10	2.1033	2.0424	1.9814
11	1.89	2.0119	1.89
12	1.829	1.9509	1.829
13	1.829	1.9204	1.7985
14	1.829	1.829	
15	1.7985	1.7375	
16		1.7375	
17	1.9062	1.7833	1.6766
18		.1715	.1848
19	.2587	.1715	.2218
20	.2587	.1715	.1848
21	.2218	.1715	.1848
22	.2033	.1715	.1848
23	.1848	.1715	.1848
24	.1715	.1524	.1715
Max	**2.1033**	**2.0424**	**1.9814**
Min	**.1715**	**.1524**	**.1715**
Avg	**.8273**	**.8263**	**.6515**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274049 / 33/11 KV BHANDHSHEGAON
Feeder No / Name : 201 / 11 KV SHELAVE SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3375	1.4575		.1715
2		1.3717	1.4918		.1715
3		1.4575	1.5261		.1715
4		1.6289	1.6289		.1715
5		1.6289	1.7147		.2058
6		1.7661	1.8861		.2058
7		1.9719	1.9719		
8		2.2805	2.4863		
9		2.2805	2.4863	2.2291	
11					2.3663
12					2.3148
13					3.035
14					3.0693
15					2.9664
16					2.8978
17					2.8292
19	.2058	.2572	.1543	.2572	.0857
20	.2401	.2401	.1543	.2229	.0857
21	.2401	.2401	.1886	.1886	.0857
22	.2229	.2229	.1886	.1886	.0857
23	.1886	.2058	.1886	.1715	.0857
24		1.2003	1.3717		.1715
Max	**.2401**	**2.2805**	**2.4863**	**2.2291**	**3.0693**
Min	**.1886**	**.2058**	**.1543**	**.1715**	**.0857**
Avg	**.2195**	**1.2060**	**1.2597**	**.5430**	**1.1145**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274049 / 33/11 KV BHANDHSHEGAON
Feeder No / Name : 202 / 11 KV BHALAWANI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1543	.1372	.1372	.9431
2		.1543	.1543	.1372	1.0288
3		.1715	.1715	.1543	1.0288
4		.1715	.1715	.1715	1.2003
5		.2401	.2401	.2401	1.3717
6		.3429	.2743	.3086	1.5432
7					2.0576
8					2.4006
9					2.4006
11	2.2291	2.0576	2.0576		
12	2.4006	2.4006	2.1948		
13	2.4006	2.4006	2.2462		
14	2.4006	2.2291	2.2805	2.0919	
15	2.3148	2.3148	2.2291	2.2291	
16	2.2291	2.3148	2.2119	2.452	
17	2.2291	2.2291	2.2119	2.4006	
18	2.1262	2.0576	2.0576	2.2291	
19	.1715	.2401	.2915	.1715	
20	.1715	.2229	.2572	.1715	.2058
21	.1543	.2058	.1715	.1543	.1715
22	.1372	.1715	.1543	.1543	.1543
23	.1372	.1372	.1372	.1372	.1372
24		.1543	.1372	.1372	.9431
Max	**2.4006**	**2.4006**	**2.2805**	**2.452**	**2.4006**
Min	**.1372**	**.1372**	**.1372**	**.1372**	**.1372**
Avg	**1.4694**	**1.0185**	**.9894**	**.7928**	**1.1133**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274049 / 33/11 KV BHANDHSHEGAON
Feeder No / Name : 203 / 11 KV PALASHI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.1715	.1372	1.286
2		.1715	.1886	.1543	1.286
3		.2058	.2229	.1886	1.3717
4		.2401	.2401	.2401	1.5432
5		.3086	.2915	.3086	1.8004
6		.3429	.3429	.3429	2.0576
7					2.4863
8					2.6578
9					2.1434
11	2.572	2.572	2.7263		
12	2.8292	2.915	2.8121		
13	2.7435	2.915	2.8978		
14	2.8292	2.915	2.8464	2.7263	
15	2.8292	2.915	2.6578	2.8121	
16	2.7435	2.8292	2.5549	2.9321	
17	2.572	2.7778	2.692	2.915	
18	2.6578	2.6063	2.452	2.572	
19	.2058	.3086	.2915	.2401	.3258
20	.2229	.3086	.2229	.2229	.2572
21	.1886	.2743	.2229	.2058	.1886
22	.1715	.2058	.1715	.1715	.1715
23	.1543	.1372	.1372	.1372	.1543
24		.1543	.1543	.1372	1.286
Max	**2.8292**	**2.915**	**2.8978**	**2.9321**	**2.6578**
Min	**.1543**	**.1372**	**.1372**	**.1372**	**.1543**
Avg	**1.7477**	**1.2637**	**1.2149**	**.9673**	**1.2677**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274049 / 33/11 KV BHANDHSHEGAON
Feeder No / Name : 204 / 11 KV PIRACHI KUROLI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3717	1.3717	1.4575	
2		1.4575	1.4232	1.5432	
3		1.4575	1.5089	1.6289	
4		1.5089	1.5775	1.6804	.1715
5		1.5432	1.6289	1.7147	.2058
6		1.6632	1.8004	1.7147	.2572
7		1.9204	1.7147	1.9376	
8		2.1434		2.0919	
9		2.2291	2.0576	2.0062	
11					1.989
12					2.0576
13					2.1948
14					2.2634
15					2.4691
16					2.572
17					2.6235
18					2.3148
19	.2058	.2401	.1715		.2401
20	.2401	.2229	.1715		.1886
21	.1886	.2058	.1715		.1543
22	.1543	.1715	.1543		.1543
23	.1372	.1543	.1372		.1543
24		1.3375	1.3375	1.3717	
Max	**.2401**	**2.2291**	**2.0576**	**2.0919**	**2.6235**
Min	**.1372**	**.1543**	**.1372**	**1.3717**	**.1543**
Avg	**.1852**	**1.1751**	**1.0876**	**1.7147**	**1.2506**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274049 / 33/11 KV BHANDHSHEGAON
Feeder No / Name : 205 / 11 KV BHANDISHEGAON GAOTHAN FEEDER
GAOTHAN Feeder KV- 11 /
OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5658	.6001	.5316	.5144
2		.6001	.6173	.5316	.5144
3		.6859	.6859	.5658	.6001
4		.8573	.8573	.6859	.6859
5		1.0288	1.0288	1.0288	.9431
6		1.166	1.1488	1.1317	1.1145
10	.6001	.5658	.5487	.5658	.5658
11	.4458	.4801	.3944	.4458	.5144
12	.463	.3944	.3601		.4115
13	.3944	.3772	.3429		.3601
14	.3601	.3601	.3086		.3258
15		.3772	.3429	.3944	.3429
16	.4287	.3944	.3601	.3601	.3601
17	.4801	.4801	.3601	.5144	.3944
18	.5658	.7373	.6859	.6859	.6859
19	.7545	.9431	.9431		.9602
20	.6859	.9088	.8916	.8059	.8745
21	.6001	.823	.7716	.7716	.7545
22	.5487	.6859	.6859	.6859	.6859
23	.5658	.5658	.5316	.5144	.5487
24		.5658	.5658	.5144	.5144
Max	**.7545**	**1.166**	**1.1488**	**1.1317**	**1.1145**
Min	**.3601**	**.3601**	**.3086**	**.3601**	**.3258**
Avg	**.5302**	**.6459**	**.6205**	**.6314**	**.6034**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274049 / 33/11 KV BHANDHSHEGAON
Feeder No / Name : 206 / 11 Kv Supali SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0686	.0686	.0686	.6859
2		.0686	.0686	.0686	.6859
3		.0686	.0686	.0686	.7202
4		.0857	.0686	.0686	.7202
5		.0857	.0857	.0686	.7373
6		.0857	.0686	.0686	.7716
7					.8573
8					.9431
9					.7716
11	1.1145	1.2346	1.046		
12	1.286	1.2003	1.0802		
13	1.286	1.2003	1.0802		
14	1.2346	1.2003	1.1145	.7888	
15	1.2003	1.2003	1.0631	.9259	
16	1.2003	1.1145	1.0288	1.0288	
17	1.2003	1.0631	1.0802	1.0288	
18	1.2346	1.0288	.9602	.9431	
19	.0686	.0686	.0686	.0686	.0686
20	.0686	.0686	.0857	.0686	.0686
21	.0686	.0686	.0686	.0686	.0686
22	.0686	.0686	.0686	.0686	.0686
23	.0686	.0686	.0686	.0686	.0686
24		.0686	.0686	.0686	.6859
Max	**1.286**	**1.2346**	**1.1145**	**1.0288**	**.9431**
Min	**.0686**	**.0686**	**.0686**	**.0686**	**.0686**
Avg	**.7769**	**.5058**	**.4655**	**.3258**	**.5281**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274049 / 33/11 KV BHANDHSHEGAON
Feeder No / Name : 207 / TEJUS AGRO EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.12	.1543	.1715	.2058
2		.12	.1715	.1715	.1715
3		.12	.1886	.1886	.1715
4		.12	.2401	.1886	.1715
5		.1543	.2229	.1715	.2058
6		.1372	.2915	.1886	.1715
7		.1029	.2229	.2229	.1886
8		.1543	.2401	.2058	.1715
9		.1372	.2229	.2058	.1886
10		.1715	.2572	.1886	.0857
11	.0686	.1543	.1886		.2401
12	.0514	.2401	.1886		.1715
13	.12	.1372	.1715		.1715
14	.1543	.12	.1543		.1372
15	.1543	.1543	.1715		.1372
16	.2058	.2058	.1886		.1715
17	.2229	.2743	.1886		.1715
18	.1715	.1372	.2229	.0514	.0686
19	.1715	.1715	.2743	.0686	.1543
20	.1372	.1543	.2058	.0514	.1372
21	.1372	.1543	.1886	.0514	.2401
22	.1372	.1372	.1886	.1494	.2801
23	.1372	.1372	.1886	.2058	.2915
24		.1372	.12	.1715	.2058
Max	**.2229**	**.2743**	**.2915**	**.2229**	**.2915**
Min	**.0514**	**.1029**	**.12**	**.0514**	**.0686**
Avg	**.1438**	**.1522**	**.2022**	**.1561**	**.1796**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274050 / 33/11 CHALE S/STN
Feeder No / Name : 201 / 11 KV KALERAN SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1524	.1524	.1524	1.3717	1.2955
2	.1524	.1524	.1524	.1524	.1524	1.3717	1.3717
3	.1524	.1524	.1524	.1524	.1524	1.3717	1.3717
4	.1524	.1524	.1524	.1524	.1524	1.6766	1.5242
5						1.6766	1.5242
6						1.829	1.6004
7						1.829	1.829
8						1.829	1.829
9							1.9052
11	1.829	1.829	1.829	1.9814	1.9814		
12	1.9814	1.9052	1.829	1.9814	1.9814		
13	1.9814	1.9052	1.829	2.1338	1.9814		
14	1.9814	1.9052	1.829	2.1338	1.9814		
15	1.9814	1.9052	1.829	2.1338	1.9814		
16	1.829	1.9814		2.1338	1.9814		
17	1.829	1.9052		2.1338	1.9814		
18	1.829	1.7528		2.1338	1.9814		
19	.1524	.1524		.1524	.1524	.1524	.1524
20	.1524	.1524	.1524	.1524	.1524	.1524	.1524
21	.1524	.1524	.1524	.1524	.1524	.1524	.1524
22	.1524	.1524	.1524	.1524	.1524	.1524	.1524
23	.1524	.1524	.1524	.1524	.1524	.1524	.1524
24	.1524	.1524	.1524	.1524	.1524	1.3717	1.2955
Max	**1.9814**	**1.9814**	**1.829**	**2.1338**	**1.9814**	**1.829**	**1.9052**
Min	**.1524**	**.1524**	**.1524**	**.1524**	**.1524**	**.1524**	**.1524**
Avg	**.9314**	**.9230**	**.7512**	**1.0161**	**.9653**	**1.0778**	**1.0872**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274050 / 33/11 CHALE S/STN
Feeder No / Name : 202 / 11 KV AMBE SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.4572	.3048	.4572	.381	.1524	.1524
2	.381	.4572	.3048	.4572	.381	.1524	.1524
3	.4572	.4572	.3048	.4572	.4572	.1524	.1524
4		.4572	.3048	.4572	.4572	.1524	.1524
5	.4572	.4572	.4572	.4572	.4572		
6	.4572	.4572	.4572	.4572	.4572		
7	.4572	.4572	.3048	.4572			
8	.4572	.4572	.4572	.4572	.4572		
9	.4572	.4572	.4572	.4572	.4572		
10						.3048	
11						.3048	.2286
12						.3048	.2286
13						.3048	.2286
14						.4572	.2286
15						.4572	.2286
16						.4572	.2286
17						.4572	.2286
18						.2286	.2286
19	.1524	.1524	.1524	.1524	.1524	.1524	.1524
20	.1524	.1524	.1524	.1524	.1524	.1524	.1524
21	.1524	.1524	.1524	.1524	.1524	.1524	.1524
22	.1524	.1524	.1524	.1524	.1524	.1524	.1524
23	.1524	.1524	.4572	.1524	.1524	.1524	.1524
24	.381	.4572	.3048	.4572	.381	.1524	.1524
Max	**.4572**	**.4572**	**.4572**	**.4572**	**.4572**	**.4572**	**.2286**
Min	**.1524**	**.1524**	**.1524**	**.1524**	**.1524**	**.1524**	**.1524**
Avg	**.3320**	**.3556**	**.3150**	**.3556**	**.3320**	**.2527**	**.1863**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274050 / 33/11 CHALE S/STN
Feeder No / Name : 203 / 11 Kv Ranzani SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1524		.1524	.9145	.9145
2	.1524	.1524	.1524		.1524	.9145	.9145
3	.1524	.1524	.1524		.1524	.9145	.9145
4	.1524	.1524	.1524		.1524	.9145	.9145
5						.9145	.9145
6						1.2193	1.829
7						1.6766	1.829
8						1.829	2.2862
9						1.3717	2.2862
11	1.829	1.829	1.3717		2.2862		
12	2.2862	1.9814	1.3717	2.1338	2.2862		
13		2.2862	1.3717	2.7435	2.2862		
14	1.9814	2.2862	1.3717	1.2193	2.2862		
15	2.2862	1.9814	1.3717	2.7435	2.2862		
16	2.2862	1.6004		2.4387	2.2862		
17	2.2862	2.2862		2.4387	2.2862		
18	1.829	1.9814		2.4387	2.2862		
19	.1524	.2286		.1524	.1524	.2286	.1524
20	.1524	.2286	.1524	.1524	.1524	.2286	.1524
21	.1524	.1524	.1524	.1524	.1524	.2286	.1524
22	.1524	.1524		.1524	.1524	.1524	.1524
23	.1524	.1524	.1524	.1524	.1524	.1524	.1524
24	.1524	.1524	.1524		.1524	.7621	.9145
Max	**2.2862**	**2.2862**	**1.3717**	**2.7435**	**2.2862**	**1.829**	**2.2862**
Min	**.1524**	**.1524**	**.1524**	**.1524**	**.1524**	**.1524**	**.1524**
Avg	**.9593**	**.9949**	**.6214**	**1.4099**	**1.1008**	**.8281**	**.9653**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274050 / 33/11 CHALE S/STN
Feeder No / Name : 204 / 11 KV CHALE GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4572	.6097	.4572	.4572	.4572	.4572
2	.6097	.4572	.6097	.4572	.4572	.4572	.4572
3	.6097	.4572	.6097	.4572	.4572	.4572	.4572
4	.6097	.6097	.9145	.6097	.7621	.4572	.7621
5	.7621	.7621	.9145	.7621	.7621	.4572	.7621
6	.9145	.9145	.9145	.7621	.6859	.9145	.7621
7	.9145	.9145	.9145	.7621	.7621	.9145	.9145
8	.9145	.6097	.7621		.7621	.7621	.7621
9	.9145	.6097	.6097	.4572	.5335	.6097	.7621
10	.6097	.4572	.6097		.5335	.4572	.4572
11	.4572		.6097	.4572	.4572	.381	.4572
12	.4572	.5335	.4572	.4572	.4572	.381	.4572
13	.4572	.4572	.4572	.4572	.4572	.381	.4572
14	.381	.4572	.4572	.4572	.4572	.3048	.4572
15	.4572	.4572	.4572	.4572	.4572	.3048	.4572
16	.4572	.4572		.4572		.3048	.4572
17	.6859	.5335		.4572	.4572	.381	.4572
18	.7621	.8383		.4572	.4572		.4572
19	.7621	.9145		.9145	.9145	.9907	.6097
20	.7621	.9145	.9145	.9145	.7621	.8383	.7621
21	.6097	.7621	.9145	.7621	.6097	1.0669	.7621
22	.6097	.6097	.9145	.7621	.6097	.8383	.6097
23	.4572	.6097	.6097	.6097	.4572	.4572	.6097
24	.4572	.4572	.6097	.6097	.4572	.4572	.6097
Max	**.9145**	**.9145**	**.9145**	**.9145**	**.9145**	**1.0669**	**.9145**
Min	**.381**	**.4572**	**.4572**	**.4572**	**.4572**	**.3048**	**.4572**
Avg	**.6287**	**.6196**	**.6935**	**.5889**	**.5732**	**.5666**	**.5906**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274050 / 33/11 CHALE S/STN
Feeder No / Name : 205 / 11 Kv Chale SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	1.0669	1.0669		.9145	.1524	.1524
2	.9145	1.0669	1.0669		.9145	.1524	.1524
3		1.0669	1.0669		.9145	.1524	.1524
4	.9145	1.0669	1.0669		.9145	.1524	.1524
5	.9145	1.0669	1.0669	.9145	.9145		
6	.9145	1.0669	1.0669	1.0669	.9145		
7	1.2193	1.0669	1.0669	1.0669	.9145		
8	1.2193	1.0669	1.0669	1.2193	.9145		
9	1.2193	1.0669	1.3717	1.2193	.9145		
11						1.2193	1.3717
12						1.2193	1.3717
13						1.5242	1.3717
14						1.3717	1.3717
15						1.5242	1.3717
16						1.5242	1.3717
17						1.5242	1.3717
18						1.5242	1.3717
19		.1524	.1524	.1524	.1524	.1524	.1524
20		.1524	.1524	.1524	.1524	.1524	.1524
21		.1524	.1524	.1524	.1524	.1524	.1524
22		.1524	.1524	.1524	.1524	.1524	.1524
23		.1524	.1524	.1524	.1524	.1524	.1524
24	.9145	1.0669	1.0669		1.0669	.1524	.1524
Max	**1.2193**	**1.0669**	**1.3717**	**1.2193**	**1.0669**	**1.5242**	**1.3717**
Min	**.9145**	**.1524**	**.1524**	**.1524**	**.1524**	**.1524**	**.1524**
Avg	**1.0161**	**.7621**	**.7824**	**.6249**	**.6706**	**.7197**	**.6943**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274050 / 33/11 CHALE S/STN
Feeder No / Name : 206 / 11 KV DARLING SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.6097	.6097	.4572	.7621		
2	.7621	.6097	.6097	.6097	.7621		
3	.7621	.6097		.6097	.7621		
4	.7621	.6097	.6097	.6097	.7621		
5	.7621	.6097	.7621	.6097	.7621		
6	.9145	.6097	.7621	.7621	.7621		
7	.9145	.9145	.7621	.7621	.9145		
8	1.0669	.9145	.9145	.9145	1.0669		
9	1.0669	.9145	.9145	1.0669	1.0669		
11						1.0669	1.3717
12						1.0669	1.3717
13						1.2193	1.3717
14						1.3717	1.3717
15						1.3717	1.3717
16						1.3717	1.3717
17						1.2193	1.3717
18						1.2193	1.3717
24	.7621	.6097	.6097	.4572	.7621		
Max	**1.0669**	**.9145**	**.9145**	**1.0669**	**1.0669**	**1.3717**	**1.3717**
Min	**.7621**	**.6097**	**.6097**	**.4572**	**.7621**	**1.0669**	**1.3717**
Avg	**.8535**	**.7011**	**.7282**	**.6859**	**.8383**	**1.2384**	**1.3717**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274053 / 33/11 KV KHARDI
Feeder No / Name : 201 / 11 KV KHARDI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0974	.9555	.2743	.3086
2		1.0974	1.0202	.2743	.3086
3		1.0974	1.166	.2743	.3429
4		1.0974	1.3603	.2743	.3429
5		1.0974	1.5546	.3086	.3772
6		1.8595	1.9433	.3772	.3944
7		2.4082	2.4777		
8		2.5606	2.6882		
9		2.5911	2.4082		
10		.3086	.2572	.3258	.3086
11		.2572	.2401	1.768	1.7528
12				2.1491	1.9966
13				1.9509	2.1491
14				2.4387	2.2862
15				2.2862	2.3167
16				2.3167	2.1338
17				2.3158	1.9662
18				1.9919	1.8595
19	.3429	.4801	.3772		.463
20	.4115	.5144	.4115	.4287	.463
21	.3944	.4973	.4115	.3944	.463
22	.3429	.463	.3429	.3601	.4801
23	.2743	.4287	.2743	.3258	.4801
24	.9755		.2743		.3086
Max	**.9755**	**2.5911**	**2.6882**	**2.4387**	**2.3167**
Min	**.2743**	**.2572**	**.2401**	**.2743**	**.3086**
Avg	**.4569**	**1.1160**	**1.0684**	**1.0966**	**1.0239**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274053 / 33/11 KV KHARDI
Feeder No / Name : 202 / 11 KV BOHALI SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3086	.3258	1.0669	1.004
2			.3086	.3429	1.0669	1.004
3			.3086	.4115	1.0669	1.0688
4			.3086	.4801	1.0669	
5			.4458	.5144	1.0669	1.2631
6			.4458	.5316	1.1736	1.4575
7					1.5089	2.332
8					1.5432	2.8178
9					1.5947	2.4387
10			.2743	.2743	.2572	.2572
11			1.9662	2.0271	.2058	.1886
12	2.5606		2.3472	2.2862		
13			2.4387	2.4539		
14			2.4996	2.4387		
15			2.2862	1.4575		
16			1.8595	1.829		
17		2.5149	2.3967	2.1643		
18		2.4387	1.8461	2.2405		
19		.3429	.3772	.3772	.4458	.463
20		.3772	.3772	.4115	.463	.4458
21		.3772		.4115	.4115	.3772
22		.3086	.3772	.3429	.3601	.3429
23		.3086	.3429	.3429	.3258	.3429
24		.3086		1.0669		.9393
Max	**2.5606**	**2.5149**	**2.4996**	**2.4539**	**1.5947**	**2.8178**
Min	**2.5606**	**.3086**	**.2743**	**.2743**	**.2058**	**.1886**
Avg	**2.5606**	**.8721**	**1.1324**	**1.0824**	**.8515**	**1.0464**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274053 / 33/11 KV KHARDI
Feeder No / Name : 203 / 11 KV T SHETPHAL SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.0729	2.0081	.2743	.3429
2		2.0729	2.0081	.2743	.3429
3		2.0729	2.1376	.2743	.3429
4		2.0729	2.1376	.2743	.3429
5		2.0729	2.2024	.2743	.3429
6		2.5606	2.2672	.2743	.3429
7		2.8045	2.915		
8		2.6216	2.915		
9		2.4996			
10		.1372	.2058		
11		.2058	.2058	2.8045	2.3777
12				3.1703	2.4387
13				2.2558	2.6825
14				2.4387	2.5911
15				2.5911	2.4387
16				2.4387	2.4387
17				2.8502	2.4387
18				2.5911	2.3167
19	.3429	.2743	.3429	.3429	.2439
20	.4115	.2743	.4115	.4115	.2743
21	.4115	.2743	.4115	.4115	.2743
22	.3429	.2743	.3429	.3429	.2743
23	.2743	.2743	.2743	.3429	.2743
24	1.9814		.2743		.3429
Max	**1.9814**	**2.8045**	**2.915**	**3.1703**	**2.6825**
Min	**.2743**	**.1372**	**.2058**	**.2743**	**.2439**
Avg	**.6274**	**1.4103**	**1.3163**	**1.2967**	**1.1732**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274053 / 33/11 KV KHARDI
Feeder No / Name : 204 / 11 KV KHARDI GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3429	.2743	.3086	.2743
2		.3429	.3086	.3086	.3086
3		.3429	.3944	.3086	.3086
4		.3429	.4801	.3086	.3772
5		.4801	.5316	.3772	.4801
6		.5487	.583	.4801	.6001
7		.4973	.6001	.5144	.6859
8		.4458	.6001	.4973	.5658
9		.4115		.4801	.4801
10		.3601	.3086	.3258	.3429
11		.3258	.2401		.2915
12		.2915		.3086	.2572
13		.2915	.2058		.2743
14		.3258	.2058	.2572	.2743
15		.2743	.2058	.3086	.2572
16		.2915	.3086		.3086
17	.3429	.3086	.3772	.3601	.3429
18	.4115	.4458	.4458	.4801	.4458
19	.4458	.6173	.4801	.6173	.5658
20	.4973	.4973	.463	.5316	.5144
21	.4801	.4287	.463	.4287	.4801
22	.4458	.3429	.4458	.3258	.4115
23	.3772	.2743	.4115	.2743	.3429
24	.3429		.3086		.2743
Max	**.4973**	**.6173**	**.6001**	**.6173**	**.6859**
Min	**.3429**	**.2743**	**.2058**	**.2572**	**.2572**
Avg	**.4179**	**.3839**	**.3928**	**.3901**	**.3944**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274053 / 33/11 KV KHARDI
Feeder No / Name : 205 / 11KV Umbargaon SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3772	.3772	.945	.9717
2		.3772	.3772	.945	1.1012
3		.3772	.4115	.945	1.1984
4		.3772	.4458	.945	1.3279
5		.3772	.4801	1.4327	1.4251
6		.3772	.4801	1.5546	1.6194
7				2.1948	2.2348
8				2.3777	2.7854
9				2.5606	2.5911
10		.2743	.2401	.2743	.3086
11		1.829	2.0729	.2743	.2401
12		2.3472	2.2862		
13		2.5911	2.4082		
14		2.7435	2.4387		
15		2.774	2.4387		
16		2.5606	2.4387		
17	2.6216	2.7206	2.4387		
18	2.4996	2.5587	2.4387		
19	.3086	.4115	.4458	.4458	.4458
20	.3772	.4115	.4115	.4115	.4458
21	.3772	.4115	.3772	.4115	.4458
22	.3772	.3772	.3772	.3772	.4115
23	.3772	.3772	.3772	.3772	.3772
24	.3772		.945		.9069
Max	**2.6216**	**2.774**	**2.4387**	**2.5606**	**2.7854**
Min	**.3086**	**.2743**	**.2401**	**.2743**	**.2401**
Avg	**.9145**	**1.2326**	**1.1765**	**1.0295**	**1.1080**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274053 / 33/11 KV KHARDI
Feeder No / Name : 206 / 11KV Kasegaon (BEND WASTI) SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0974	1.0364	.3086	.4458
2		1.0974	1.0364	.3086	.4801
3		1.0974	1.1336	.3086	.4801
4		1.0974	1.2631	.3086	.5144
5		1.0974	1.4575	.3429	.5487
6		2.1948	1.6842	.4115	.5487
7		2.4996	2.332		
8		2.7435	3.0178		
9		2.6216	2.5911		
10		.2743	.3086	.3429	
11		.2401	.2743	2.3472	2.0424
12				2.8045	2.2558
13				2.9835	2.5149
14				2.7435	2.5606
15				2.774	2.4996
16				2.6216	2.4387
17				2.915	2.2862
18				2.6235	2.2253
19	.3429	.5144	.3429	.4801	.4458
20	.3772	.4801	.4115	.5144	.4458
21	.4115	.4801	.3772	.4801	.4458
22	.3772	.4458	.3086	.4801	.4458
23	.3086	.4115	.3086	.4458	.4115
24	1.0364		.3086		.4458
Max	**1.0364**	**2.7435**	**3.0178**	**2.9835**	**2.5606**
Min	**.3086**	**.2401**	**.2743**	**.3086**	**.4115**
Avg	**.4756**	**1.1496**	**1.0701**	**1.3273**	**1.2241**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274056 / 33/11 SONAKE
Feeder No / Name : 204 / GADEGAON **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6461	1.6804	1.0974	1.3413	1.5089	1.1736	1.0059
2	1.7375	1.6461	1.2803	1.3413	1.5089	1.3413	1.0059
3	1.7375	1.6461	1.6461	1.5089	1.5927	1.3413	1.3413
4	1.829	1.829	1.829	1.6766	1.6766	1.4251	1.6575
5	2.0119	1.829	2.0119	2.0119	1.8233	1.5927	1.989
6	2.1948	2.1948	2.1948	2.3472	1.989	1.8442	2.1548
7	2.652	2.7435	2.4691	2.431	2.3205	2.2634	2.4034
8	2.8349	2.9264	2.8349	2.5987	2.2377	2.4863	.663
9	2.4691	2.5606	2.4691	2.0957	2.1548	2.4863	.543
10	.462	.4668	.462	.4525		.362	.4525
11	2.1719	2.3777	2.2862	2.0957	1.9281	1.6766	2.1795
12	.2772	2.652		2.2634	2.2634	1.989	2.2377
13	2.5339	2.5606	2.5606	2.3472	2.3472	2.3205	
14	2.5606		2.5606	2.1795	2.2634	2.3205	2.3472
15	2.5606	2.3777	2.652	2.1795	2.1795	2.4034	2.431
16	2.5339	2.7435	2.652	2.1795	2.0957	2.4863	2.4863
17	2.5339	2.4691	2.5606	2.1795	2.0119	2.4863	2.5149
18	2.4691	2.1948	2.3777	2.1795	2.0119		2.3205
19	.6468	.7392	.6468	.6335	.6335	.724	.724
20	.7392	.6468	.6468	.543	.543	.724	.6335
21	.7392	.6468	.5601	.543	.543	.724	.543
22	.5544	.5544	.3696	.543	.543	.6878	.543
23	.6468	.5544	.462	.543	.543	.543	.543
24	1.6461	1.6461	1.0974	1.4251	1.5927	1.0059	1.0059
Max	**2.8349**	**2.9264**	**2.8349**	**2.5987**	**2.3472**	**2.4863**	**2.5149**
Min	**.2772**	**.4668**	**.3696**	**.4525**	**.543**	**.362**	**.4525**
Avg	**1.7579**	**1.8124**	**1.7273**	**1.6516**	**1.6657**	**1.5829**	**1.4663**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274056 / 33/11 SONAKE
Feeder No / Name : 205 / Gaothan No.1 Takali- Gadegaon Feeder KV- 11 / OUTGOING **GAOTHAN FEEDER**

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0934	.1867	.0905	.0905	.0905	.0905
2	.0934	.0934	.1867	.0905	.0905	.0905	.0905
3	.0934	.0934	.1867	.0905	.0905	.0905	.0905
4	.0934	.0934	.1867	.0905	.0905	.0905	.0905
5		.1867	.1867	.0905	.181	.0905	.0905
6	.0934	.2801	.2801	.0905	.181	.181	.2715
7	.1867	.1867	.2801	.0905	.181	.181	.2715
8	.1867	.1867	.1867	.0905	.181	.181	.2715
9	.1867	.0934	.2801	.0905	.181	.181	.181
10	.1867	.1867	.2801	.0905		.181	.181
11	.0934	.2801	.1867	.181	.0905		.181
12	.2801	.2801	.1867	.0905	.0905	.181	.0905
13	.0934	.1867	.1867	.0905	.0905	.0905	.0905
14	.1867	.1867	.1867		.0905	.0905	.0905
15	.1867	.1867	.1867	.0905	.0905	.0905	.0905
16	.0934	.2801	.1867	.0905	.0905	.0905	.0905
17	.1867	.2801	.0934	.0905	.0905	.0905	.181
18	.0934	.2801	.0934	.181	.181		.181
19	.1867	.2801	.1867	.2715	.181	.181	.181
20	.2801	.2801	.2801	.181	.181	.181	.181
21	.2801	.2801	.1867	.181	.181	.181	.181
22	.2801	.1867	.1867	.181	.0905	.181	.0905
23	.1867	.1867	.1867	.0905	.0905	.0905	.0905
24	.0934	.0934	.1867	.0905	.0905	.0914	.0905
Max	**.2801**	**.2801**	**.2801**	**.2715**	**.181**	**.181**	**.2715**
Min	**.0934**	**.0934**	**.0934**	**.0905**	**.0905**	**.0905**	**.0905**
Avg	**.1655**	**.1984**	**.1984**	**.1180**	**.1259**	**.1317**	**.1433**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274056 / 33/11 SONAKE
Feeder No / Name : 206 / 11KV Navale College Express Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS (CONTINOUS PROCESS)(NO STAGGERING)

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0934	.0934		.0905	.0905	.0905
2	.0934	.0934	.0934	.0905	.0905	.0905	.0905
3	.0934	.0934	.0934	.0905	.0905	.0905	.0905
4	.0934	.0934	.0934	.0905	.0905	.0905	.0905
5	.0934	.0934	.0934	.0905	.0905	.0905	.0905
6	.0934	.0934	.0934	.0905	.0905	.0895	.0905
7	.0934	.0934	.0934	.0905	.0905	.0905	.0905
8	.0934	.0934	.0934	.0905	.0905	.0905	.0905
9	.0934	.0934	.0934	.0905	.0905	.0905	.0905
10	.0934	.0934	.0934	.0905		.0905	.0905
11	.0934	.0934	.0934	.0905	.0905	.0905	.0905
12	.0934	.0934	.0934	.0905	.0905	.0905	.0905
13	.0934	.0934	.0934	.0905	.0905	.0905	.0905
14	.0934	.0934	.0934	.0905	.0905	.0905	.0905
15	.0934	.0934	.0934	.0905	.0905	.0905	.0905
16	.0934	.0934	.0934	.0905	.0905	.0905	
17	.0934	.0934	.0934	.0905	.0905	.0905	
18		.0934	.0934	.0905	.0905		.0905
19	.0934	.0934	.0934	.0905	.0905	.0905	.0905
20	.0934	.0934	.0934	.0905	.0905	.0905	.0905
21	.0934	.0934	.0934	.0905	.0905	.0905	.0905
22	.0934	.0934	.0934	.0905	.0905	.0905	.0905
23	.0934	.0934	.0934	.0905	.0905	.0905	.0905
24	.0934	.0934	.0934	.0895	.0905	.0905	.0905
Max	**.0934**	**.0934**	**.0934**	**.0905**	**.0905**	**.0905**	**.0905**
Min	**.0934**	**.0934**	**.0934**	**.0895**	**.0905**	**.0895**	**.0905**
Avg	**.0934**	**.0934**	**.0934**	**.0905**	**.0905**	**.0905**	**.0905**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274114 / 33/11 KV ANAWALI
Feeder No / Name : 201 / 11 KV ANAWALI **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	.9431	1.0374	.1886	.1509	.1509
2	1.1317	.9431	1.0374	.1886	.1886	.1509
3	1.1317	.9431	1.0374	.1886	.1698	.1509
4	1.5089	1.1317	1.1317	.1886	.1698	.1886
5	1.5089	1.1317	1.3203	.1886	.1698	.2263
6	1.5089	1.5089	1.5089	.1886	.1698	.2641
7	1.8861	1.9805	1.6975	.1886	.1646	.1698
8	2.0748	1.829	1.8861	.1698	.2263	.1509
9	2.2634	1.829	1.6461	.1886	.2263	.1509
10	.132	.1886	.132	.1509	.1698	
11	.132		.132	1.9805	2.0748	1.6975
12	.132		.132	1.9805	2.1691	
13	.132		.132	1.9805	2.2634	
14	.132	.1886	.132	1.9805	2.2634	1.5089
15	.132	.1698	.1698	2.0748	2.2634	
16	.1509	.1698	.1698	2.0748	2.0748	2.452
17	.1509	.1698	.1698	2.0748	2.0748	2.2634
18	.1698	.1698	.1698	2.1691	2.0748	1.8861
19	.1698		.2829	.2829	.1509	.2263
20	.1698	.1698	.2263	.2641	.2263	.2075
21	.1698	.1698	.2263	.2263	.2263	.1698
22	.1509	.1698	.2263	.2263	.1886	.1698
23	.132	.1698	.1698	.1886	.1463	.1698
24	1.1317	.9431	.7545	.1886	.1698	.132
Max	**2.2634**	**1.9805**	**1.8861**	**2.1691**	**2.2634**	**2.452**
Min	**.132**	**.1698**	**.132**	**.1509**	**.1463**	**.132**
Avg	**.7222**	**.7459**	**.6470**	**.8134**	**.8405**	**.6243**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274114 / 33/11 KV ANAWALI
Feeder No / Name : 202 / 11 KV TAWASHI SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1509	.128	.9431	.9431	1.5089
2	.1509	.1698	.132	1.1317	1.0974	1.5089
3	.1509	.1698	.1509	1.3203	1.3203	1.829
4	.1698	.1698	.1646	1.5089	1.5089	1.8861
5	.1829	.1886		1.6975	1.6975	1.8861
6	.1698	.1886	.1886	1.8861	1.8861	2.2634
7	.2075	.2075	.1886	2.452	2.5463	2.5463
8	.2075	.1886		2.452	2.6406	2.452
9	.1698	.1886		2.6406	2.9235	2.452
10	.1698	.1886		.1886	.1698	
11	3.0178			.1509	.1698	.1698
12	3.2065	2.3577		.1509	.1698	
13	3.2065		2.8292	.1698	.1646	
14	3.2065	2.8292	3.2065	.1698	.2195	
15	3.2065	3.2065	3.3951	.1698	.2263	
16	3.2065	3.2065	3.3951	.1698	.1698	
17	3.0178	3.2065	3.3951	.1698	.2075	
18	2.8292	2.6406	3.3951	.1698	.2641	.1698
19	.1886		.2452	.1698	.3018	.1698
20	.1646	.1886	.2452	.1698	.3395	.1698
21	.1698	.1509	.2263	.1509	.1698	.1698
22	.1698	.1463	.2263	.1509	.1698	.1698
23	.1698	.1509	.2195	.1698	.1698	.1698
24	.1698	.1698	.132	.9431	.9431	1.5089
Max	**3.2065**	**3.2065**	**3.3951**	**2.6406**	**2.9235**	**2.5463**
Min	**.1509**	**.1463**	**.128**	**.1509**	**.1646**	**.1698**
Avg	**1.1533**	**.9554**	**1.2146**	**.8040**	**.8508**	**1.2371**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274114 / 33/11 KV ANAWALI
Feeder No / Name : 203 / 11 KV ANAVALI GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7545	.6602	.9431	.9145	.7545
2	.7545	.7545	.6602	.9431	.9431	.9431
3	.9431	.9145	.8488	.9431	.9431	1.1317
4	.9431	.9431	.9431	.9431	1.0374	1.1317
5	1.1317	1.1317	1.0974	.9431	1.0374	1.3203
6	1.3203	1.3203	1.3203	1.1317	1.1317	1.3203
7	1.3203	1.3203	1.4146	1.3203	1.3203	1.4146
8	1.1317	1.1317	1.3203	1.3203	1.1317	1.1317
9	1.1317	1.0374	.9431	1.0974	.9431	.9431
10	.7316	.9431	.9431	.9431	.7545	
11	.5658	.7316		.7545	.5658	.7545
12	.5658	.7545		.7545	.3772	
13	.5658	.7545	.5658	.5658	.3772	
14	.5658	.7316	.5658	.5658	.3772	.3772
15	.5658	.5658	.5658	.7545	.3772	
16	.7545	.5658	.7545	.9431	.7545	.3772
17	.7545	.8488	.7545	.9431	.9431	.7545
18	1.0374	.9145	.9431	.9431	.9431	.9431
19	1.0974		1.1317	1.3203	1.1317	1.3203
20	1.1317	1.226	.9431	1.1317	1.1317	1.1317
21	1.1317	1.0059	.9431	.9431	1.1317	.9431
22	1.0059	.8488	.9431	.9431	1.0374	.9431
23	.9431	.7545	.9431	.9431	.7545	.9431
24	.9431	.9431	.7545	.9431	.9431	.7545
Max	**1.3203**	**1.3203**	**1.4146**	**1.3203**	**1.3203**	**1.4146**
Min	**.5658**	**.5658**	**.5658**	**.5658**	**.3772**	**.3772**
Avg	**.9080**	**.9085**	**.9072**	**.9574**	**.8751**	**.9667**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274114 / 33/11 KV ANAWALI
Feeder No / Name : 204 / Shirgaon **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.5658	.3772	.2263	.2263	.2641
2	.5658	.5658	.3772	.2263	.2263	.3018
3	.5658	.5658	.4715	.2058	.2263	.3772
4	.7545	.5658	.4715	.2263	.2263	.3772
5	.7545	.7545	.5658	.2263	.2263	.3395
6	.9431	.9431	.5658	.2263	.2829	.3395
7	1.0374	1.1317	.9431	.2263	.2829	.415
8	1.0374	1.0374	1.1317	.2263	.2829	.3772
9	.9431	.9431	1.0374	.2641	.2829	.3395
10	.1886	.2263	.2075	.2195	.2641	
11	.1829	.2075	.2075	.9431	.9431	.9431
12	.2075	.2075	.2075	.9431	1.1317	
13	.2075	.2263	.2641	.9431	1.1317	
14	.2075	.2263	.2641	.9431	1.1317	.9431
15	.2075	.2263	.2641	.9431	1.1317	
16	.2263	.2263	.2829	1.1317	1.1317	1.1317
17	.2641	.2263	.2829	1.1317	1.1317	.9431
18	.3018	.2829	.2829	1.1317	1.1317	.9431
19	.3018		.2829	.2829	.2641	.2829
20	.3018	.2829	.2263	.2263	.2641	.2829
21	.3395	.2263	.2263	.2195	.2641	.2263
22	.3018	.1886	.2263		.2263	.2263
23	.2641	.1886	.2263	.2263	.2263	.2263
24	.5658	.5658	.3772	.2263	.2263	.2263
Max	**1.0374**	**1.1317**	**1.1317**	**1.1317**	**1.1317**	**1.1317**
Min	**.1829**	**.1886**	**.2075**	**.2058**	**.2263**	**.2263**
Avg	**.4682**	**.4600**	**.4071**	**.5028**	**.5360**	**.4753**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274114 / 33/11 KV ANAWALI
Feeder No / Name : 205 / VITHURAYA **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1132	.132	.7545	.5658	1.1317
2	.1509	.132	.132	.7545	.7545	1.1317
3	.1698	.132	.1698	.9431	.7545	1.3203
4	.1829	.132	.1886	.9431	.9431	1.5089
5	.2263	.1509	.2263	1.0374	1.1317	1.5089
6	.2263	.1509	.2641	1.226	1.3203	1.8861
7	.2263	.2075	.2263	1.7918	1.8861	1.8861
8	.2075	.1886	.1886	1.8861	2.0748	1.9805
9	.1886	.1463	.1698	2.2634	2.2634	1.9805
10	.1886	.1509	.1509	.1509	.1509	
11	1.6975	1.829	2.452	.132	.1097	.132
12	2.2634	1.8861	2.452	.132	.1698	
13	2.3777	2.2634	2.452	.1132	.1132	
14	2.452	2.2634	2.6406	.0943	.1097	.132
15	2.3577	2.3577	2.6406	.0943	.1132	.132
16	2.2634	2.452	2.452	.0943	.0914	.0943
17	2.0748	2.452	2.3577	.132	.1132	.1509
18	1.9805	2.2634	2.3577	.132		.1509
19	.1698	.1132	.1886	.2263	.1886	.2075
20	.2075	.132	.1886	.2263	.2075	.2075
21	.1886		.1886	.2263	.1698	.1886
22	.1698	.1509	.1886	.2263	.1509	.1886
23	.1509	.132	.1886	.2263	.128	.1829
24	.1509	.1509	.132	.5658	.5658	.9431
Max	**2.452**	**2.452**	**2.6406**	**2.2634**	**2.2634**	**1.9805**
Min	**.1509**	**.1132**	**.132**	**.0943**	**.0914**	**.0943**
Avg	**.8509**	**.8674**	**.947**	**.5988**	**.6120**	**.8117**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274114 / 33/11 KV ANAWALI
Feeder No / Name : 206 / SIDDHANATH **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.5658	.5658	.2263	.2263	.2263
2	.7545	.5658	.5658	.2263	.2263	.2641
3	.7545	.7545	.5658	.2263	.1886	.2641
4	.9431	.7545	.7545	.2263	.2263	.3018
5	.9431	.9431	.8488	.2641	.2263	.3395
6	1.1317	1.1317	.9619	.2452	.2263	.3395
7	1.4146	1.6032	1.3203	.2829	.2641	.3395
8	1.5089	1.6975	1.6975	.2829	.2641	.3018
9	1.6032	1.6975	1.6032	.2263	.2641	.3018
10	.3961	.2263	.3772	.2263	.2263	
11	.3961	.2641	.3772		1.6975	1.3203
12	.3961	.2641	.3772	1.6975	1.6975	
13	.3961	.3395	.4715	1.6975	1.8861	
14	.3961	.3395	.4715	1.6975	1.8861	.9431
15	.3961	.3772	.4338	1.6975	1.8861	1.6975
16	.3961	.3772	.415	1.6975	1.6032	1.6975
17	.3772	.3772	.415	1.7918	1.5089	1.5089
18	.3772	.3772	.415	1.7918	1.5089	1.1317
19	.415	.3395	.3395	.2829	.3395	.3395
20	.415	.2452	.2641	.2263	.2641	.3772
21	.3772	.2263	.2641	.2263	.2641	.3658
22	.3772	.2263	.2263	.2263	.3018	.3395
23	.3395	.1886	.2263	.2263	.2452	.3395
24	.7545	.5658	.5658	.2263	.2263	.2263
Max	**1.6032**	**1.6975**	**1.6975**	**1.7918**	**1.8861**	**1.6975**
Min	**.3395**	**.1886**	**.2263**	**.2263**	**.1886**	**.2263**
Avg	**.6672**	**.6020**	**.6051**	**.6921**	**.7356**	**.6174**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274114 / 33/11 KV ANAWALI
Feeder No / Name : 207 / MAN **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5089	1.3203	1.1317	.2641		.2641
2	1.5089	1.3203	1.226	.2641	.2641	.3018
3	1.5089	1.5089	1.3203	.2641	.2641	.3018
4	1.8861	1.5089	1.5089	.3395	.2561	.3395
5	1.8861	1.8861	1.6975	.3772	.2641	.3658
6	2.0748	2.0748	2.0182	.4207	.3658	.415
7	2.452	2.5463	2.2634	.4715	.415	.415
8	2.452	2.4691	2.452	.415	.3772	.3772
9	2.452	2.5463	2.3954	.3772	.3772	.3395
10	.2829	.2263	.1886	.3395	.3395	
11	.2829	.1698	.1698	2.1691	2.6406	
12	.2829	.1698	.1698	2.2634	2.6406	
13	.3018	.2263	.1886	2.452	2.6406	
14	.3018	.2829	.2829	2.452	2.6406	2.8292
15	.2829	.3018	.2829	2.452	2.6406	2.8292
16	.3018	.3018	.2263	2.452	2.2634	2.8292
17	.3395	.3018	.2829	2.452	2.452	2.5606
18	.3584	.3018	.2829	2.452	2.452	2.0748
19	.3395	.3206	.2829	.3395	.3395	.3395
20	.3395	.3018	.2829	.3018	.3395	.3772
21	.3018	.2641	.2829	.3018	.3395	.3772
22	.3018	.2263	.3395	.3018	.3018	.3772
23	.2641	.1886	.3018	.2829	.2641	.3772
24	1.5089	1.1317	1.1317	.2641	.2829	.2641
Max	**2.452**	**2.5463**	**2.452**	**2.452**	**2.6406**	**2.8292**
Min	**.2641**	**.1698**	**.1698**	**.2641**	**.2561**	**.2641**
Avg	**.9800**	**.9124**	**.8629**	**1.0196**	**1.0939**	**.9178**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274131 / 33/11KV WAKHARI
Feeder No / Name : 201 / WAKHARI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0669	1.0669	.1219	.1219
2		1.0669	1.0669	.1219	.1219
3		1.0669	1.0669	.1219	.1219
4		1.1431	1.2003	.1524	.1219
5		1.2193	1.2193	.1524	.1524
6		1.3717	1.6289	.1524	.1524
7		1.7528	1.9814	.1715	.1524
8		1.9052	1.9814	.1524	.1715
9		1.9814	1.9814	.1524	.1372
10		.1715	.1372	.1524	.1715
11		.1372	.1219	1.8861	1.5851
12		.1029	.1219	2.2291	2.1033
13		.1029	.0914	1.9814	2.0119
14		.1029	.0914	1.9814	1.9814
15		.1372	.1029	1.9814	1.9204
16	.061	.1372	.0914	2.0729	1.9204
17	.061	.1372	.1029	2.0576	1.9204
18	.0914	.2058	.1715	1.829	2.0424
19	.1715	.1715	.1524	.1524	.2401
20	.1524	.1829	.1715	.1524	.2401
21	.1524	.1829	.1524	.1524	.2401
22	.1524	.1829	.1524	.1524	.2058
23	.1219	.1372	.1219	.1219	.2058
24		1.0669	1.0669	.1219	.1219
Max	**.1715**	**1.9814**	**1.9814**	**2.2291**	**2.1033**
Min	**.061**	**.1029**	**.0914**	**.1219**	**.1219**
Avg	**.1205**	**.6556**	**.6685**	**.7635**	**.7568**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274131 / 33/11KV WAKHARI
Feeder No / Name : 202 / KHED BHALWANI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2193	1.0669	.0305	.0305
2		1.2193	1.0669	.0305	.0305
3		1.2193	1.0669	.0343	.0305
4		1.3717	1.3717	.0343	.0305
5		1.3717	1.3717	.0305	.0305
6		1.6766	1.4937	.0305	.0305
7		1.9052	1.829	.0305	.0305
8		1.9814	1.9814	.0305	.0343
9		2.0729	2.2291	.0305	.0343
10		.0343	.0305	.0305	.0343
11		.0343	.0305	1.9204	2.2862
12		.0343	.0343	2.2862	2.4996
13		.0343	.0343	2.4387	2.6216
14			.0305	2.4387	2.6825
15			.0343	2.4387	2.7435
16	.0305	.0343	.0343	2.5301	2.774
17	.0305	.0343	.0343	2.4387	2.774
18	.0305	.0305	.0343	2.4387	2.0729
19	.0305	.0305	.0343	.0305	.0343
20	.0305	.0305	.0343	.0305	.0343
21	.0305	.0305	.0343	.0305	.0343
22	.0305	.0305	.0343	.0305	.0343
23	1.2193	.0305	.0343	.0305	.0343
24		1.2193	1.0669	.0305	.0305
Max	**1.2193**	**2.0729**	**2.2291**	**2.5301**	**2.774**
Min	**.0305**	**.0305**	**.0305**	**.0305**	**.0305**
Avg	**.1791**	**.7112**	**.6255**	**.8094**	**.8739**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274131 / 33/11KV WAKHARI
Feeder No / Name : 203 / KOUTHALI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.0305	.0305	1.0669
2	.0305	.0305	.0305	1.2003
3	.0305	.0305	.0305	1.0669
4	.0305	.0305	.0305	1.0669
5	.0305	.0305	.0305	1.2193
6	.0305	.0305	.0343	1.3717
7	.0305	.0305	.0305	2.0576
8	.0343	.0305	.0305	1.9814
9	.0343	.0343	.0305	2.1338
10	.0343	.0343	.0305	.0343
11	1.9509	1.9509	.0305	
12	2.2558	1.9814	.0305	
13	1.89	2.0729	.0305	
14	.0343	2.0729	.0305	
15	2.0729	2.0729	.0305	
16	2.0729	2.0119	.0305	
17	2.1948	2.0119	.0305	
18	2.0119		.0305	.0343
19	.0305	.0343	.0305	.0343
20	.0305	.0343	.0305	.0343
21	.0305	.0343	.0305	.0343
22	.0305	.0343	.0305	.0343
23	.0305	.0343	.0305	.0343
24	.0305	.0305	.0305	1.0669
Max	**2.2558**	**2.0729**	**.0343**	**2.1338**
Min	**.0305**	**.0305**	**.0305**	**.0343**
Avg	**.6243**	**.6387**	**.0307**	**.8513**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274131 / 33/11KV WAKHARI
Feeder No / Name : 204 / SHIRDHONE SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.7621	.7621
2				.8573	.7621
3				.7621	.7621
4				.7621	.7621
5				.7621	.7621
6				.9145	
7				1.3413	1.3108
8				1.3413	1.3413
9				1.2955	1.3413
11		1.768	1.89		
12		1.9509	1.89		
13		1.829	1.89		
14		1.9509	1.89		
15		1.9509	1.89		
16	1.89	1.9509	1.89		
17	1.89	2.0729	1.829		
18	1.5242	1.89	1.5242		
24				.7621	.7621
Max	**1.89**	**2.0729**	**1.89**	**1.3413**	**1.3413**
Min	**1.5242**	**1.768**	**1.5242**	**.7621**	**.7621**
Avg	**1.7681**	**1.9204**	**1.8367**	**.9560**	**.9518**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274131 / 33/11KV WAKHARI
Feeder No / Name : 205 / WAKHARI GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3086		.3086	.2743
2		.3086	.3292	.3086	.2743
3		.3429	.3292	.3429	.3048
4		.3772	.4024	.3772	.3658
5		.4115	.439	.4115	.4268
6		.4458	.4755	.463	.4458
7		.3429	.3658	.3086	.3353
8		.3086		.2743	.3086
9		.2572		.2572	.2743
10		.2058		.2058	.2229
11		.1372		.1829	
12			.1463	.1543	
13			.1097	.1219	
14				.1372	
15			.1646	.12	
16	.1524	.0686	.1646	.12	
17	.1524	.1372	.1524	.2058	
18	.2229	.2229	.1981	.2743	.2058
19	.2572	.2572	.2743	.3772	.3772
20	.3429	.3429	.3353	.4115	.3429
21	.3048	.4115	.3658	.4115	.3429
22	.3048	.4115	.3353	.3353	.3429
23	.3086	.3429	.2743	.2743	.3258
24		.3086	.3292	.2743	.2743
Max	**.3429**	**.4458**	**.4755**	**.463**	**.4458**
Min	**.1524**	**.0686**	**.1097**	**.12**	**.2058**
Avg	**.2558**	**.2975**	**.2884**	**.2774**	**.3203**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274131 / 33/11KV WAKHARI
Feeder No / Name : 206 / 11 KV Mauli Gavthan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3086	.3429	.3429	.3086
2		.3086	.3429	.3429	.3086
3		.3086	.4115	.4115	.3429
4		.4115	.4458	.4458	.4115
5		.4458	.4801	.4458	.4801
6		.5316	.5144	.5487	.5144
7		.5144	.5144	.5658	.5144
8		.4458	.4115	.5144	.4115
9		.4115	.4115	.4458	.3772
10		.4287	.4207	.4115	.3772
11		.4801	.4207	.4115	.3944
12		.3772	.3429	.3772	.4801
13		.3429	.3258	.3429	.4458
14		.2915	.3429	.3086	.4287
15		.3258	.3429	.2401	.4115
16	.3772	.3429	.3429	.2401	.4115
17	.3772	.3944	.3048	.3772	.4115
18	.3429	.3944	.2743	.4115	.4801
19	.4115	.4458	.3048	.4801	.4801
20	.4458	.4458	.3963	.4458	.4801
21	.4458	.463	.3963	.4115	.463
22	.4458	.4115	.3658	.3048	.4458
23	.4115	.3429	.3048	.3086	.4115
24		.3429	.3429	.3429	.3086
Max	**.4458**	**.5316**	**.5144**	**.5658**	**.5144**
Min	**.3429**	**.2915**	**.2743**	**.2401**	**.3086**
Avg	**.4072**	**.3965**	**.3793**	**.3949**	**.4208**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274138 / 33/11 KV KASEGAON
Feeder No / Name : 201 / 11 KV SIDDHESHWAR SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859			.381	.4191	.362
2	.703			.381	.4001	.362
3	.8842			.381	.4191	.381
4	1.2483			.4572	.4763	.4382
5	1.387			.5716	.5335	.5144
6	1.5604			.5906	.6287	.6287
7	2.3059			.5906	.6478	.6478
8	2.9127			.5144	.5525	.5716
9						.4763
10						.3429
11						1.8861
12						2.1776
13						2.5892
14						2.6063
15						2.4691
16						2.5034
17	.2096	.2477	.2401	2.5833		
18	.381	.4572	.3601	2.4446		
19	.4954	.5525	.4287	.4458		
20	.4572	.4763	.3772	.4287		
21	.381	.4001	.3601	.3944		
22	.381	.381	.3429	.3429		
23	.381	.381	.3429	.3429		
24	.6687			.362	.4001	.362
Max	**2.9127**	**.5525**	**.4287**	**2.5833**	**.6478**	**2.6063**
Min	**.2096**	**.2477**	**.2401**	**.3429**	**.4001**	**.3429**
Avg	**.9401**	**.4137**	**.3503**	**.7008**	**.4975**	**1.1364**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274138 / 33/11 KV KASEGAON
Feeder No / Name : 202 / 11 KV SATWAI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1269			.2743	.2058	.2401	
2	1.1443			.2743	.2058	.2401	
3	1.2309				.2058	.2401	
4	1.3696			.2743	.2058	.2401	
5	1.4563			.3258	.2572	.2743	
6	1.7337			.3258	.3258	.2915	
7	2.2192			.4458	.3601	.3601	
8	2.4272			.3601	.3258	.3772	
9							.4458
10							.3601
11							2.5034
12							2.7606
13							2.7606
15							2.572
16							2.6578
17	.2743	.3601	.3086	2.5659			
18	.3258	.2915	.2915	2.5833			
19	.2915	.3601	.3601	.3429			
20	.2743	.3086	.3601	.2915			
21	.2743	.2743	.3258	.2915			
22	.2572	.2743	.3086	.2401			
23	.2229	.2743	.2915	.2229			
24	1.1443			.2743	.2058	.2401	
Max	**2.4272**	**.3601**	**.3601**	**2.5833**	**.3601**	**.3772**	**2.7606**
Min	**.2229**	**.2743**	**.2915**	**.2229**	**.2058**	**.2401**	**.3601**
Avg	**.9858**	**.3062**	**.3209**	**.6062**	**.2553**	**.2782**	**2.0086**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274138 / 33/11 KV KASEGAON
Feeder No / Name : 203 / 11 KV DESHMUKH NAGAR SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229			.4801	.583	.5316	
2	.2401			.4801	.6001	.5658	
3	.2743			.4973	.6173	.5658	
4	.3086			.6001	.7202	.703	
5	.3429			.6859	.823	.8059	
6	.3601			.9088	1.046	.9774	
7	.3601			1.2689	1.3889	1.4403	
8	.2743			1.5947	1.9204	1.8176	2.1434
9							2.0062
10							.1543
11							.1715
12							.1905
13							.1715
14							.1524
15							.1715
16							.1524
17	1.3546	1.749	1.7511	.1715			
18	1.3889	1.6632	1.491	.2572			
19	.2858	.2743	.2572	.2915			
20	.2858	.2572	.2743	.2401			
21	.2477	.2229	.2229	.2401			
22	.2286	.2401	.2401	.2401			
23	.2477	.2477	.2401	.2401			
24	.2401			.463	.5316	.463	
Max	**1.3889**	**1.749**	**1.7511**	**1.5947**	**1.9204**	**1.8176**	**2.1434**
Min	**.2229**	**.2229**	**.2229**	**.1715**	**.5316**	**.463**	**.1524**
Avg	**.4164**	**.6649**	**.6395**	**.5412**	**.9145**	**.8745**	**.5904**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274138 / 33/11 KV KASEGAON
Feeder No / Name : 204 / 11 KV GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715			.1334	.1524	.1524	
2	.1886			.1334	.1524	.1524	
3	.2229			.1524	.1524		
4	.2401			.1715	.1715	.1143	
5	.2915			.1905	.2667	.1334	
6	.3772			.3239	.362	.2096	
7	.4115			.4191	.362	.2477	
8	.2915			.381	.4001	.1905	
9							.4001
10							.3239
11							.3048
13							.1334
14							.2477
15							.2286
17	.2286	.3077	.12	.2229			
18	.362	.2353	.2229	.2572			
19	.362	.3439	.3086	.3772			
20	.362	.3077	.3086	.2915			
21	.3239	.2667	.2229	.3944			
22	.2286	.1905	.1372	.2058			
23	.1905	.1334	.1372	.1372			
24	.1715			.1334	.1524	.1524	
Max	**.4115**	**.3439**	**.3086**	**.4191**	**.4001**	**.2477**	**.4001**
Min	**.1715**	**.1334**	**.12**	**.1334**	**.1524**	**.1143**	**.1334**
Avg	**.2765**	**.2550**	**.2082**	**.2453**	**.2413**	**.1691**	**.2731**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274138 / 33/11 KV KASEGAON
Feeder No / Name : 206 / Dongare Shala **SHEDDABLE RURAL**
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772			.724	.8573	.8573	
2	.4115			.724	.8573	.8764	
3	.5316			.7621	.9335	.9335	
4	.6173			.9145	1.2193	1.1812	
5	.6516			1.1431	1.3336	1.4098	
6	.6859			1.467	1.848	1.6194	
7	.6516			2.2862	2.7244	2.3815	
8	.7716			2.934	3.4103	3.2388	
9							3.1245
10							.4382
11							.3048
12							.2477
15							.381
16							.4382
17	2.4006	3.0483	2.4966	.4801			
18	2.5911	2.8006	2.3752	.5658			
19	.7811	.724	.6001	.7202			
20	.7049	.6097	.5316	.5658			
21	.6287	.4954	.4115	.463			
22	.4763	.4382	.3601	.3601			
23	.5525	.4191	.3601	.3258			
24	.3944			.6859	.8192	.8002	
Max	**2.5911**	**3.0483**	**2.4966**	**2.934**	**3.4103**	**3.2388**	**3.1245**
Min	**.3772**	**.4191**	**.3601**	**.3258**	**.8192**	**.8002**	**.2477**
Avg	**.8267**	**1.2193**	**1.0193**	**.9451**	**1.5559**	**1.4776**	**.8224**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274142 / 33/11 KV SARKOLI
Feeder No / Name : 201 / 11 KV SARKOLI **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.2058	.2572	.2572	1.3717
2	.1715	.2743	.1886	.2743	.2743	1.3717
3		.2743	.2229	.2915	.2743	1.3717
4	.1715	.2743	.2572	.3258	.2743	1.3889
5						1.3889
6						1.6289
7						1.6289
8						1.8347
9						2.0062
11	2.0576	2.1434	2.0233	1.9719		
12	2.1091	2.1948	2.1091	2.0748		
13	2.1434	2.2291	1.9719	2.0576		
14	2.1434	2.2291	2.0748	2.0062	2.1262	
15	2.1948	2.1091	2.1948	2.1434	2.2977	
16	2.1948	2.2805	2.2634	2.1776	2.2977	
17	2.0576	2.2805	2.2634	2.1948	2.2977	
18	2.0233	2.2634	2.2462	2.1605	1.7318	
19	.2572	.2401	.3086	.2743	.2058	.3258
20	.2572	.2058	.2915	.2572	.2401	.2572
21	.2572	.2058	.2572	.2401	.1372	.2229
22	.1715	.1886	.2401	.2229	.1372	.1886
23	.1715	.1886	.2229	.2401	.1372	.1715
24	.1715	.1715	.1886	.2572	.2572	1.3717
Max	**2.1948**	**2.2805**	**2.2634**	**2.1948**	**2.2977**	**2.0062**
Min	**.1715**	**.1715**	**.1886**	**.2229**	**.1372**	**.1715**
Avg	**1.1014**	**1.1069**	**1.0850**	**1.0793**	**.8631**	**1.1020**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274142 / 33/11 KV SARKOLI
Feeder No / Name : 202 / 11 KV OZEWADI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.7716	.7373	.8573	.7716	.1543
2	.823	.9602	.8402	.9259	.8573	.1886
3	.8573	.9602	.8745	.9774	.9431	.1886
4	.9431	.9602	.9259	1.046	.9945	.1886
5	1.0288	.9602	1.0117	1.1317	1.0288	
6	1.4575	1.6461	1.1831	1.3546	1.2003	
7	1.6461	1.6461	1.6289	1.5947	1.4746	
8	1.6804	1.8347	1.8004	1.7147	1.6289	
9	1.6975	1.7661	1.7318	1.6975	1.7147	
11						1.7318
12						2.0576
13						2.0919
14						2.0576
15				.12		2.1948
16	.12	.1372	.0686	.12	.1715	2.1091
17	.12	.1029	.0857	.12	.1372	1.989
18	.12	.1029	.12	.1372	.1372	1.286
19	.1372	.12	.1715	.1543	.1543	.2058
20	.1372	.1543	.1543	.1715	.1715	.1715
21	.1372	.1372	.1543	.1715	.1372	.1543
22	.1029	.1372	.1543	.1543	.1372	.1543
23	.1029	.1372	.1372		.12	.1715
24	.7716	.7716	.7202	.8059	.7716	.1543
Max	**1.6975**	**1.8347**	**1.8004**	**1.7147**	**1.7147**	**2.1948**
Min	**.1029**	**.1029**	**.0686**	**.12**	**.12**	**.1543**
Avg	**.7030**	**.7392**	**.6944**	**.7364**	**.6973**	**.9583**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274142 / 33/11 KV SARKOLI
Feeder No / Name : 203 / 11 KV KHATAKALI SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5144	.6859	.6344	.5487	.1715
2		.6516	.6687	.6344	.5487	
3		.6516	.6859	.6516	.583	.1715
4		.6516	.6859	.6516	.6001	.1715
5		.6516	.703	.7202	.6516	
6		.8916	.7545	.7716	.6859	
7	.7716	.8916	.9088	.823	.7202	
8	.9431	1.0117	.9602	.9088	.8573	
9	.9945	1.046	.9602	.9259	.8745	
11						.8916
12						1.1488
13						1.0631
14						1.1145
15						1.2174
16						1.2003
17						1.1831
18						.8916
19	.12	.1715	.1715	.12	.1715	.2572
20	.12	.1372	.1715	.1372	.1715	.2401
21	.12	.1372	.1543	.1372	.1543	.2058
22	.1029	.12	.12	.12	.1372	.1886
23	.1029		.1029	.5487	.12	.1886
24		.5144	.6001	.6344	.5487	.1715
Max	**.9945**	**1.046**	**.9602**	**.9259**	**.8745**	**1.2174**
Min	**.1029**	**.12**	**.1029**	**.12**	**.12**	**.1715**
Avg	**.4094**	**.5744**	**.5556**	**.5613**	**.4915**	**.6163**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274142 / 33/11 KV SARKOLI
Feeder No / Name : 204 / 11 KV AMBIKA NAGAR SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1715	.1029	.1029	.1029	.8573
2	.1029	.1715	.12	.1029	.1029	.8573
3	.1029	.1715	.1029	.1029	.1029	1.3032
4	.1029	.1715	.1029	.12	.1029	1.3032
5						1.3032
6						1.7318
7						1.7318
8						1.6804
11	1.8861	1.8519	1.6289	1.8004		
12	1.9719	1.7147	1.8519	1.7147		
13	2.0576	1.8004	1.9376	2.0576		
14	2.0576	1.8347	1.9204	2.0576	1.5432	
15	2.0576	1.869	1.9204	1.8861	1.989	
16	2.0576	1.8861	1.9547	1.8861	1.989	
17	2.0576	1.9376	1.8519	1.8861	1.989	
18	2.0062	1.8176	1.7833	1.8004	1.5432	
19	.1715	.1372	.1372	.1543	.1715	
20	.1715	.12	.12	.1715	.1715	
21	.1715	.12	.12	.1543	.1715	
22	.1715	.1029	.1029	.1372	.1372	
23	.1715	.1029	.1029		.12	
24	.1029	.1715	.1029	.1029	.1029	.4287
Max	**2.0576**	**1.9376**	**1.9547**	**2.0576**	**1.989**	**1.7318**
Min	**.1029**	**.1029**	**.1029**	**.1029**	**.1029**	**.4287**
Avg	**.9736**	**.8974**	**.8869**	**.9552**	**.6893**	**1.2441**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274142 / 33/11 KV SARKOLI
Feeder No / Name : 205 / SHIVAJI NAGAR **SHEDDABLE RURAL**
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3429	.3944	.3601	.3772	.1543
2	.4287	.4973	.3944	.3601	.4287	.1543
3	.4287	.4973	.4287	.3944	.4287	.1543
4	.4801	.4973	.4287	.4115	.4801	.1715
5	.6001	.4973	.4801	.4801	.5144	
6	.6344	.6859	.5144	.5658	.5487	
7	.6344	.7545	.6516	.6173	.6001	
8	.6859	.8573	.7202	.6344		
9		.9259	.7202	.7202	.6173	
11						.6859
12						.7888
13						.8573
14						.8745
15				.1029		.9088
16	.1715	.12	.0857	.12	.1715	.8916
17	.1715	.12	.1029	.1029	.1715	.8745
18	.1715	.12	.1372	.1029	.1715	.7716
19	.1715	.1372	.1543	.12	.1715	.1543
20	.1715	.1029	.1372	.12	.1715	.1029
21	.1715	.0857	.12	.12	.1715	.1029
22	.1715	.0857	.12	.1029	.1715	.1029
23	.1715	.0857	.0857	.1029	.1715	.0857
24	.3429	.3429	.3601	.3601	.3429	.1372
Max	**.6859**	**.9259**	**.7202**	**.7202**	**.6173**	**.9088**
Min	**.1715**	**.0857**	**.0857**	**.1029**	**.1715**	**.0857**
Avg	**.3520**	**.3753**	**.3353**	**.3104**	**.3359**	**.4430**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274142 / 33/11 KV SARKOLI
Feeder No / Name : 206 / SARKOLI GAVTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.6859	.1543	.1372	.1715
2	.1715	.1715	.1886	.1543	.1372	.1715
3	.1715	.1715	.2058	.1715	.1372	.1715
4	.1543	.2058	.2058	.2058	.1372	.1715
5	.2058	.2058	.2572	.2401	.1715	.1715
6	.2401	.2058	.3429	.2743	.2401	.2058
7	.3086	.2058	.2915	.3086	.3086	.2401
9	.2058	.2058	.1715	.2401		.1715
10	.2058	.2058	.1715	.1886	.1543	.2058
11	.1715	.1715	.1715	.1715	.1543	.1715
12	.1715	.1715	.1715	.1543	.1543	.1543
13	.1715	.1715	.1372	.1372	.1372	.12
14	.1715	.1715	.12	.12	.1372	.12
15	.1715	.1543	.12	.1372	.1543	.1029
16	.1715	.1543	.1715	.1372	.1543	.1372
17	.1715	.1715	.2058	.1715	.1715	.1543
18	.2058	.2058	.2058	.2229	.2058	.2401
19	.2058	.2401	.2743	.2743	.2572	.3601
20	.2058	.2743	.2229	.2743	.1715	.2401
21	.2058	.2401	.2058	.2572	.1715	.2401
22	.1715	.2058	.1715	.2058	.1715	.2058
23	.1715	.1715	.1715	.1715	.1715	.1886
24	.1715	.1715	.1715	.1543	.1543	.1715
Max	**.3086**	**.2743**	**.6859**	**.3086**	**.3086**	**.3601**
Min	**.1543**	**.1543**	**.12**	**.12**	**.1372**	**.1029**
Avg	**.1901**	**.1924**	**.2192**	**.1968**	**.1723**	**.1864**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274161 / 33/11 KV PIRACHI KUROLI
Feeder No / Name : 201 / 11 KV DHONDEWADI FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6478	.4858	.4858	.0905
2		.6478	.4858	.4858	.0905
3		.6478	.4858	.4858	.0905
4		.6478	.4858	.4858	.0905
5		.6478	.6478	.6478	.0905
6		.6478	.8097	.8097	.0905
7		.8097	.9717	1.1336	.0905
8		.9717	1.1336	.9717	.0905
9		.9717	.9717	.9717	.0905
10	.0905	.0905	.0905	.181	.0905
11	.0905	.0905	.0905		.9717
12	.0905	.0905	.0905		1.1336
13	.0905	.0905	.0905		1.1336
14		.0905		.0905	1.1336
15	.0905	.0905		.0905	1.1336
16	.0905	.0905	.0905	.0905	.9717
17	.0905	.0905	.0905	.0905	1.1336
18	.0905	.0905	.0905	.0905	.9717
19	.0905	.0905	.0905	.0905	.0905
20	.0905	.0905	.0905	.0905	.0905
21	.0905	.0905	.0905	.0905	.0905
22	.0905	.0905	.0905	.0905	.0905
23	.0905	.0905	.0905		.0905
24		.6478		.4858	.0905
Max	**.0905**	**.9717**	**1.1336**	**1.1336**	**1.1336**
Min	**.0905**	**.0905**	**.0905**	**.0905**	**.0905**
Avg	**.0905**	**.3564**	**.3602**	**.3980**	**.4180**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274161 / 33/11 KV PIRACHI KUROLI
Feeder No / Name : 202 / 11 KV PIRACHI KUROLI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.181	.181	.181	1.2955
2		.181	.181	.181	1.2955
3		.181	.181	.181	1.4575
4		.181	.181	.181	1.4575
5		.181	.181	.181	1.7166
6		.181	.181	.181	1.6194
7		.181	.181	.181	1.6194
8		.181	.181	.181	1.7814
9		.181	.181	.181	1.7814
10	.181	.181	.181	.181	.181
11	2.2672	2.2672	2.1052	2.1052	.0905
12	2.2672	2.4291	2.2672		
13	2.2672	2.4291	2.1052		
14	2.2672	2.2672	2.1052	2.1052	
15	2.2672	2.2672	2.2672	2.1052	
16	2.2672	2.4291	2.1052	2.1052	.0905
17	2.2672	2.4291	2.1052	2.1052	.181
18	2.1872	2.2672	1.9433	2.1052	.181
19	.181	.181	.181	.181	.181
20	.181	.181	.181	.181	.181
21	.181	.181	.181	.181	.181
22	.181	.181	.181	.181	.181
23	.181	.181	.181	.181	.181
24		.181		.181	1.2955
Max	**2.2672**	**2.4291**	**2.2672**	**2.1052**	**1.7814**
Min	**.181**	**.181**	**.181**	**.181**	**.0905**
Avg	**1.3674**	**.9034**	**.8573**	**.7058**	**.8474**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274161 / 33/11 KV PIRACHI KUROLI
Feeder No / Name : 203 / 11 KV CHANDRABHAGA FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6478	.4858	.4858	.0905
2		.6478	.4858	.4858	.0905
3		.6478		.4858	.0905
4		.6478	.4858	.4858	.0905
5		.6478	.6478	.6478	.0905
6		.6478	.8097	.8097	.0905
7		.8097	.9717	1.1336	.0905
8		.9717	1.1336	.9717	.0905
9		.9717	.9717	.9717	.0905
10	.0905	.0905	.0905	.0905	.0905
11	.0905	.0905	.0905	.0905	.9717
12	.0905	.0905	.0905		1.1336
13	.0905	.0905	.0905		1.1336
14	.0905	.0905	.0905	.0905	1.1336
15	.0905	.0905	.0905	.0905	1.1336
16	.0905	.0905	.0905	.0905	.9717
17	.0905	.0905	.0905	.0905	1.1336
18	.0905	.0905	.0905	.0905	.9717
19	.0905	.0905	.0905	.0905	.0905
20	.0905	.0905	.0905	.0905	.0905
21	.0905	.0905	.0905	.0905	.0905
22	.0905	.0905	.0905	.0905	.0905
23	.0905	.0905	.0905	.0905	.0905
24		.6478		.4858	.0905
Max	**.0905**	**.9717**	**1.1336**	**1.1336**	**1.1336**
Min	**.0905**	**.0905**	**.0905**	**.0905**	**.0905**
Avg	**.0905**	**.3564**	**.3300**	**.3659**	**.4180**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274161 / 33/11 KV PIRACHI KUROLI
Feeder No / Name : 204 / 11 KV GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4163	.4344		.4344
2		.4163	.4525	.4706	.4344
3		.4706	.4706	.5249	.4525
4		.543	.4887		.5068
5		.6516	.5792		.5792
6		.7602	.7602		.6516
7		.724	.724	.7602	.7602
8		.6697	.6154	.6335	.6878
9		.543	.4706	.4887	.6154
10		.4344	.3801	.3439	.4163
11	.3439	.2715	.2715	.2534	.3439
12	.3258	.181	.1991		.3258
13	.3439	.1629			.3258
14		.1448	.2172	.2534	.3077
15	.3439	.181	.2715	.2353	.3077
16	.4163	.2353	.3077	.2172	.3258
17	.4525	.3258	.3258	.3439	.4163
18	.5792	.6154	.5611	.5792	.6154
19		.7602	.7602	.5792	.7964
20	.724	.6878	.724	.543	.6878
21	.6878	.6154	.6335	.5068	.5792
22	.4525	.5068	.543	.4706	.5068
23	.362	.4344	.4344	.4525	.4525
24		.362		.4344	.4344
Max	**.724**	**.7602**	**.7602**	**.7602**	**.7964**
Min	**.3258**	**.1448**	**.1991**	**.2172**	**.3077**
Avg	**.4574**	**.4631**	**.4829**	**.4495**	**.4985**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274161 / 33/11 KV PIRACHI KUROLI
Feeder No / Name : 205 / NEW DHONDEWADI FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.181	.181	.181	.6964
2		.181	.181	.181	.7125
3		.2172	.181	.181	.7935
4		.2715	.181	.2172	.8907
5		.3258	.181	.2715	.9555
6		.362	.2896	.3258	1.0364
7		.3982	.2896	.3258	1.1498
8		.362	.2715	.3258	1.3279
9		.2534	.2172	.2172	1.2146
10	.181	.1448	.1448	.181	.181
11	1.1822	1.1012	1.1336	1.085	.1086
12	1.5565	1.166	1.2308		.0905
13	1.3765	1.1498	1.3394		.0905
14	1.3117	1.1174	1.3032	1.1012	.0724
15	1.1984	1.1336	1.1336	1.2146	.0905
16	1.1336	1.166	1.1174	1.2955	.1086
17	1.0364	1.085	1.1336	1.2308	.181
18	.9878	1.0526	.9878	1.166	.2172
19	.2715	.2172	.2715	.2353	.2715
20	.2353	.2172	.2896	.2172	.2353
21	.2172	.181	.2534	.1991	.1991
22	.1991	.181	.1991	.181	.181
23	.1991	.181	.181	.181	.181
24		.181	.181	.181	.6478
Max	**1.5565**	**1.166**	**1.3394**	**1.2955**	**1.3279**
Min	**.181**	**.1448**	**.1448**	**.181**	**.0724**
Avg	**.7919**	**.5345**	**.5364**	**.4861**	**.4847**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274165 / 33/11KV PALASHI
Feeder No / Name : 201 / UJANI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0926	.0617	.0926	.3086
2		.108	.0772	.0926	.3704
3		.108	.0772	.108	.3858
4		.108	.0926	.108	.4321
5		.0926	.0926	.1389	.463
6		.108	.0926	.1543	.4938
7		.108	.0926	.1543	.7099
8		.0926	.0926	.1698	.9568
9		.0625	.0625	.1235	.9374
10		.0625	.0625	.0772	.0469
11		.5937	.4843	.6327	.0469
12		.6562	.7811	.8951	.0469
13	.7407	.6562	.8436	.0772	.0625
14	.7407	.6562	.7655		.0625
15	.6944	.6718	.7499		.0781
16	.7407	.6718	.6874		.0781
17	.787	.6562	.7562	.6944	.1094
18	.6327	.5401	.6481	.7099	.1875
19	.108	.0772	.1389	.1235	.1389
20	.108	.0772	.1235	.1235	.1235
21	.0926	.0772	.0926	.0926	.1235
22	.0926	.0617	.0926	.108	.108
23	.0772	.0617	.0926	.1235	.1235
24		.0926	.0617	.0926	.3241
Max	**.787**	**.6718**	**.8436**	**.8951**	**.9568**
Min	**.0772**	**.0617**	**.0617**	**.0772**	**.0469**
Avg	**.4377**	**.2705**	**.2968**	**.2330**	**.2799**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274165 / 33/11KV PALASHI
Feeder No / Name : 202 / RAMESHWAR SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3704	.4012	.3395	.1389
2		.4012	.4475	.3858	.1389
3		.4475	.3858	.3704	.1235
4		.5093	.8488	.571	.1235
5		.6019		.8951	.1389
6		.8025	1.034	.9722	.1543
7		.9568	1.1265	1.0031	.1852
8		1.0957	1.3272	1.1265	.216
9		1.0517	1.1888	1.1574	.1829
10		.0914	.0914	.108	.1524
11		.1219	.1067	.108	1.0059
12		.1372	.1219	.1389	1.1888
13	.1235	.1219	.1372	.1389	1.2193
14	.0926	.1219	.1067		1.3108
15	.1543	.1524	.1067		1.3413
16	.1852	.1829	.1067		1.2193
17	.2469	.2286	.1389	.1852	1.2193
18	.2315	.2469	.1852	.1698	1.0517
19	.0926	.216	.216	.1543	.1235
20	.0926	.216	.216	.1543	.108
21	.0772	.1852	.216	.1698	.108
22	.108	.1543	.1852	.1389	.1235
23	.1389	.1543	.1543	.1389	.1543
24		.3549	.3704	.3241	.1235
Max	**.2469**	**1.0957**	**1.3272**	**1.1574**	**1.3413**
Min	**.0772**	**.0914**	**.0914**	**.108**	**.108**
Avg	**.1403**	**.3718**	**.4008**	**.4167**	**.4938**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274165 / 33/11KV PALASHI
Feeder No / Name : 203 / 11Kv palashi SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6097	.6859	.6706	.1219
2		.6401	.6636	.7164	.1219
3		.5335	.6554	.6859	.1067
4		.4572	.7468	.7621	.1067
5		.6401	.8078	.9297	.1219
6		.9145	.9105	1.0517	.1372
7		.9907	.945	1.0822	.1372
8		1.1888	1.0212	1.0822	.1677
9		1.3125	.9488	1.0059	.0949
10		.0791	.0474	.0772	.0791
11		.0474	.0474	.061	1.2334
12		.0474	.0474	.0617	1.3599
13	.061	1.3125	.0474	.0617	1.4232
14	.061	.0474	.0474		1.439
15	.061	.0474	.0474		1.4232
16	.0762	.0633	.0633		1.3916
17		.0791	.0914	.0762	1.2809
18	.108	.1067	.1067	.1219	1.1702
19	.1067	.1067	.1372	.1219	.0914
20	.0914	.1067	.1372	.1067	.1067
21	.0914	.1219	.1372	.0914	.0914
22	.1067	.1067	.1372	.0914	.1067
23	.0914	.0914	.1219	.1219	.1219
24		.5944	.6097	.6249	.1067
Max	**.108**	**1.3125**	**1.0212**	**1.0822**	**1.439**
Min	**.061**	**.0474**	**.0474**	**.061**	**.0791**
Avg	**.0855**	**.4269**	**.3838**	**.4574**	**.5226**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274165 / 33/11KV PALASHI
Feeder No / Name : 204 / Palashi Gavthan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2507	.2353	.2715	.3224
2			.2353	.2715	.3582
3		.2686	.3258	.3258	.3761
4		.3224	.362	.4525	.4298
5		.3761	.3801	.5068	.4835
6		.4656	.5249	.6335	.5731
7		.4656	.4525	.6154	.5552
8		.4835	.362	.362	.591
9		.2896	.3439	.4706	.4525
10		.2896	.2846	.3258	.362
11		.3077	.3077	.2715	.3439
12		.3077	.181	.2172	.3077
13	.2715	.2715	.1267	.2172	.2715
14	.181	.2715	.1629		.2172
15	.1791	.2896	.181		.2715
16	.2149	.3258	.2353		.3258
17	.2328	.3801	.2353	.2149	.3801
18	.3761	.5068	.3258	.5014	.543
19	.4298	.4525	.4887	.4656	.4835
20	.4656	.3982	.4706	.4656	.4477
21	.3582	.3258	.4525	.4477	.4477
22	.3045	.3077	.3801	.3761	.3582
23	.2507	.2715	.3439	.3224	.3224
24		.2865	.2715	.3077	
Max	**.4656**	**.5068**	**.5249**	**.6335**	**.591**
Min	**.1791**	**.2507**	**.1267**	**.2149**	**.2172**
Avg	**.2967**	**.3441**	**.3196**	**.3830**	**.4010**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-I S/DN[098] BU 6327
Substation No/ Name :- 274225 / 33/11 KV GADEGAON
Feeder No / Name : 201 / 11 KV LAXAMAN DAS FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.2801	.3361	.2614		1.9605	1.9418
2	.2987	.2801	.3361	.2614	1.9791	2.0538	2.0165
3	.3547	.3361	.3734	.2614	2.0165	2.1472	2.0538
4	.3361	.3361	.5041	.2987	2.0911	2.2032	2.0911
5	.3734	.3734	.5041	.3361	2.1472	2.2405	2.0538
6	.3921	.4108	.5041	.3361	2.2405	2.2405	2.1472
7	.4481	.4481	.5601	1.7924	2.4272	2.3339	2.1285
8	.4668	.4481	.5601	2.4272	2.6326	2.3152	2.1658
9	.3921	.3921	.4294	2.5766	2.5393	2.4832	2.2592
10	.3361	.3361	.3734	.3361	.3547	.3174	.3174
11	2.2032	2.0538	2.1098	.2241	.3361		.2987
12	2.4086	2.1472	2.1472	.1867	.3174	.2801	.2801
13	2.4086	2.1472		.1494	.3174	.2614	.2801
14	2.3152	2.1658	2.0538	.1867	.2987	.2427	.2987
15	2.2779	2.1658	.1867	.2241	.2801	.2801	.2801
16	2.2592	2.2032	.2054	.2987	.3361	.2614	.2801
17	2.2405	2.2032	.2987	.3361	.3734	.3361	.3361
18	2.0911	2.2218	.3361	.4668	.4294	.4481	.4481
19	.4294	.2241	.4481	.4668	.3921	.4854	.4854
20	.3921	.2241	.4108	.4481	.3361	.4108	.4481
21	.3734	.2801	.3174	.3734	.3547	.3734	.3734
22	.3361	.2801	.2987	.2987	.3734	.3174	.3734
23	.2614	.2801	.2801	.2801	.3361	.2801	.3361
24	.2801	.2614	.3361	.2614	1.8858	1.8298	1.8298
Max	**2.4086**	**2.2218**	**2.1472**	**2.5766**	**2.6326**	**2.4832**	**2.2592**
Min	**.2614**	**.2241**	**.1867**	**.1494**	**.2801**	**.2427**	**.2801**
Avg	**.9989**	**.9375**	**.6048**	**.5454**	**1.0780**	**1.1349**	**1.0635**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274051 / 33/11 KV GURSALE
Feeder No / Name : 201 / 11 KV GURUSALE **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061	.0686	2.0576	1.5089
2	.061	.0686	2.0576	1.5089
3	.061	.0686	2.0233	1.6804
4	.061	.0686	2.0576	1.8519
5	.061	.0686	2.1434	1.989
6	.061	.0686	2.1605	2.0576
7		.0686	2.5377	2.332
8		.0686	2.5377	2.4006
9	2.8121	2.7435		
10	2.8807	2.8807		
11	2.9492	2.8807		
12	2.9492	2.5377		
13	3.0178	2.7778		
14	3.0178	3.0178		
15	3.0864	2.5606		
16	2.8121	2.5606		
17	.0686	.061		.0686
18	.0686	.061	.0686	.0686
19	.0686	.061	.0686	.061
20	.0686	.061	.0686	.061
21	.0686	.061	.0686	.061
22	.0686	.061	.0686	
23	.0686	.061	.0686	.061
24	.061	.0686	.0686	.0686
Max	**3.0864**	**3.0178**	**2.5377**	**2.4006**
Min	**.061**	**.061**	**.0686**	**.061**
Avg	**1.1106**	**.9585**	**1.2037**	**1.0519**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274051 / 33/11 KV GURSALE
Feeder No / Name : 202 / 11 KV HOLE SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3429	1.0288	
2	.3048	.3429	1.0288	
3	.3048	.3429	1.166	
4	.3048	.3429	1.2346	
5	.3048	.3429	1.3717	
6	.3048	.3429	1.3889	
7		.3429		
8		.3429	1.4403	1.166
9	1.6461	1.8519		
10	1.989	1.989		
11		2.0576		
12	1.8004	1.989		
13	1.8519	1.989		
14	1.8519	1.989		
15	1.8519	1.768		
16	1.8519	1.768		
17	.2743	.3048		.3048
18	.2743	.3048		.3048
19	.3429	.3048	.3429	.3048
20	.3429	.3048		.3048
21	.3429	.3048	.2743	.3048
22	.3429	.3048	.2743	.3048
23	.3429	.3048	.2743	.3048
24	.3048	.3429	.3429	.2743
Max	**1.989**	**2.0576**	**1.4403**	**1.166**
Min	**.2743**	**.3048**	**.2743**	**.2743**
Avg	**.8209**	**.8592**	**.8473**	**.3971**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274051 / 33/11 KV GURSALE
Feeder No / Name : 203 / 11 KV CHILAIWADI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4006	.823	.3772	.4115
2	2.4006	.9602	.3772	.4115
3	2.7092	1.0974	.3772	.4115
4	2.7092	1.3717	.3772	.4115
5	2.7435	1.5089	.3772	.4115
6	2.7435	1.7833	.3772	.5487
7	3.1722	2.1948		.5487
8	3.1379	2.1948		.4115
9				2.7435
10				2.332
11				2.7435
12				2.8807
13				3.0178
14			.6859	3.0178
15		.2743	.6859	3.0178
16		.2743	.3429	2.8807
17	.1372	.2743		.2743
18	.1372	.3772	.4115	.4115
19	.2743	.3772	.4115	
20	.2743	.3772	.4115	.3772
21	.2743	.3772	.4115	.3772
22	.2743	.3772	.4115	.3772
23	.2743	.3772	.4115	.3772
24	.3772	.2743	.3772	.4115
Max	**3.1722**	**2.1948**	**.6859**	**3.0178**
Min	**.1372**	**.2743**	**.3429**	**.2743**
Avg	**1.5025**	**.8497**	**.4265**	**1.2524**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274051 / 33/11 KV GURSALE
Feeder No / Name : 204 / 11 KV GURSALE GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5487	.5658	.583
2	.583	.5487	.6516	.583
3	.6859	.5487	.6859	.6859
4	.7545	.7202	.9088	.8573
5	.823	.9259	.9945	1.0974
6	.8573	1.0288	1.0288	1.2346
7	1.0802	1.0288		1.1317
8	.9602	.823	1.0288	1.1317
9	.7545	.7545	1.0288	.9602
10	.583	.6859		.7545
11	.4801	.4801		.6859
12	.3772	.4458		.583
13	.3429	.5144		.5144
14	.2401	.3429	.4801	.4801
15	.3086	.3772	.5144	.4458
16	.3429	.4801	.3086	.4801
17	.6173	.6344		.583
18	.7888	.7373	.6516	.7545
19	.9945	.7373	1.2346	.7545
20		.6859	1.0974	.7202
21	.7202	.6516	.7888	.6859
22	.6859	.6173	.7202	.6516
23	.583	.583	.6859	.583
24	.5487	.5487	.5487	.583
Max	**1.0802**	**1.0288**	**1.2346**	**1.2346**
Min	**.2401**	**.3429**	**.3086**	**.4458**
Avg	**.6374**	**.6437**	**.7735**	**.7302**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274051 / 33/11 KV GURSALE
Feeder No / Name : 205 / 11 KV AMR BIOTECH NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0076	.0171	.0057	.0057
2	.0076	.0171	.0057	.0057
3	.0076	.0171	.0057	.0057
4		.0171	.0057	.0057
5	.0076	.0171	.0057	.0057
6	.0076	.0171	.0057	.0057
7	.0076	.0171		.0057
8	.0057	.0171	.0057	.0057
9	.0057	.0057	.0057	.0057
10	.0057	.0057	.0057	.0057
11	.0057	.0057	.0057	.0057
12	.0057	.0057	.0057	.0057
13	.0057	.0057	.0057	.0057
14	.0057	.0057	.0057	.0057
15	.0171	.0076	.0057	.0057
16	.0171	.0076	.0057	
17	.0171	.0076	.0057	.0076
18	.0171	.0076	.0057	.0076
19	.0171	.0076	.0057	.0076
20	.0171	.0076	.0057	.0076
21	.0171	.0076	.0057	.0076
22	.0171	.0076	.0057	.0076
23	.0171	.0076	.0057	.0076
24	.0076	.0171	.0057	.0057
Max	**.0171**	**.0171**	**.0057**	**.0076**
Min	**.0057**	**.0057**	**.0057**	**.0057**
Avg	**.0107**	**.0107**	**.0057**	**.0063**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274051 / 33/11 KV GURSALE
Feeder No / Name : 206 / 11 KV KARKHANA SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2291	1.7814	.1943	.1943
2	2.2291	1.7814	.2429	.1943
3	2.7435	2.3482	.1943	.1943
4	3.2579	2.6397	.1943	.1943
5	3.4294	2.6397	.1943	.2267
6	3.6008	2.9312	.1943	.2267
7	3.6008		.1943	.2267
8			.1943	.2401
9			3.5951	3.1093
10			3.2388	3.5627
11			3.6437	3.4979
12			3.5627	3.5627
13			3.7894	3.4494
14			4.1295	3.2388
15			3.8866	3.2388
16			3.8866	3.2388
17	.1943	.2058		.2058
18	.1943	.2058	.2267	.2058
19	.1943	.2058	.2267	.2058
20	.1943	.2058	.2267	.2058
21	.1943	.2058	.2267	.2058
22	.1943	.2058	.1943	.2058
23	.1943	.2058	.1943	.2058
24	.2058	.1943	.1943	.1943
Max	**3.6008**	**2.9312**	**4.1295**	**3.5627**
Min	**.1943**	**.1943**	**.1943**	**.1943**
Avg	**1.5104**	**1.1255**	**1.4272**	**1.2596**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274051 / 33/11 KV GURSALE
Feeder No / Name : 207 / 11 KV JACKWELL SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.0171		
17	.5144	.5487		.6516
18	.5144	.5487	.583	.7202
19	.4801	.5487	.5847	.7202
20	.4801	.5487	.502	.6859
21	.4801	.5144	.502	.703
22	.4801	.5144	.4534	.6687
23	.4801	.5144	.4801	.6687
24	.5316	.4973	.5316	.4973
Max	**.5316**	**.5487**	**.5847**	**.7202**
Min	**.4801**	**.0171**	**.4534**	**.4973**
Avg	**.4951**	**.4725**	**.5195**	**.6645**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274052 / 33/11 KV KARKAMB
Feeder No / Name : 202 / 11 KV SANGAVI SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1			1.2003
2			1.2003
3			1.1888
4			1.3375
5			1.4861
6			1.6556
7			1.6347
8			1.6556
9	2.0081		
10	.421		
12	.1619		
13	.1638		
14	.1619		
15	.1696		
16	.1619		
17		.2267	
18		.3439	
19		.3403	
20		.3326	
21		.3224	
22		.3224	
23		.3121	
24			1.1174
Max	**2.0081**	**.3439**	**1.6556**
Min	**.1619**	**.2267**	**1.1174**
Avg	**.4640**	**.3143**	**1.3863**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274052 / 33/11 KV KARKAMB
Feeder No / Name : 203 / 11 KV RANMALA **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	15-DEC-17	16-DEC-17	17-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.3567
2			.3567
3			.3572
4			.3715
5			.3525
6			.362
7			.3763
8			.3715
9	.3567		
10	.3429		
12	.8145		
13	1.0002		
14	.9431		
15	1.0145		
16	.9122		
17		.9214	
18		.9282	
19		.3437	
20		.3462	
21		.3841	
22		.3567	
23		.3749	
24			.3429
Max	**1.0145**	**.9282**	**.3763**
Min	**.3429**	**.3437**	**.3429**
Avg	**.7692**	**.5222**	**.3608**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274052 / 33/11 KV KARKAMB
Feeder No / Name : 204 / 11 KV JADHAVWADI SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.0953
2			.0953
3			.0953
4			.0953
6			.0953
7			.0953
8			.0953
9	.0953		
10	.0953		
11	1.2431		
12	1.286		
13	1.3032		
14	1.3032		
15	1.2929		
16	1.1431		
17		1.1431	
18		1.0402	
19		.0572	
20		.0572	
21		.0753	
22		.0743	
23		.0714	
24			.0953
Max	**1.3032**	**1.1431**	**.0953**
Min	**.0953**	**.0572**	**.0953**
Avg	**.9703**	**.3598**	**.0953**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274052 / 33/11 KV KARKAMB
Feeder No / Name : 206 / 11 KV Karkamb Gaothan **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.3582
2			.3582
3			.543
4			.5258
5			.724
6			.7468
7			.543
8			.543
9	.543		
10	.5258		
11	.5373		
12	.543		
13	.5487		
14	.362		
15	.3658		
16	.362		
17		.362	
18		.3582	
19		.7087	
20		.724	
21		.7164	
22		.362	
23		.3582	
24			.362
Max	**.5487**	**.724**	**.7468**
Min	**.362**	**.3582**	**.3582**
Avg	**.4735**	**.5128**	**.5227**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274054 / 33/11 KV MENDHAPUR
Feeder No / Name : 202 / 11 KV KHARATWADI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5546	1.7328	1.6356	1.6194
2		1.6194	1.7652	1.6518	1.6356
3		1.6842	1.8299	1.668	1.5384
4		1.749	1.9433	1.749	1.5708
5		1.8785	2.251	1.8138	1.5223
6		2.251	2.6397	1.9919	2.0243
7		2.5587	2.6235	2.5749	2.2672
8		3.0283	2.9797	2.1862	2.0405
9		1.9919	2.8988	2.2024	2.2024
10	.3887	.4858	.2753	.7287	.4049
11	2.3644	1.9433	2.2186	2.2996	2.8178
12	2.5425	2.0567			3.2065
13	2.5263	2.17	2.5587		3.4818
14	2.4291	2.2024	2.6073		3.5141
15	2.4777	2.332	1.7652	2.9473	3.3522
16	2.2186		2.2672	3.0121	3.3036
17	2.3644	2.3158	2.251	3.0283	3.2712
18	2.6235	2.0729	2.2348	2.9312	3.2065
19	.583	.6478	.7287	.8583	.4372
20	.6802	.7125	.7125	.7287	.5344
21	.7125	.7287	.6802	.6154	.6154
22	.6478	.7125	.6478	.6478	.6316
23	.4858	.5344	.5182	.5992	.502
24		1.4251	1.4899	1.6356	1.6518
Max	**2.6235**	**3.0283**	**2.9797**	**3.0283**	**3.5141**
Min	**.3887**	**.4858**	**.2753**	**.5992**	**.4049**
Avg	**1.6460**	**1.6807**	**1.8095**	**1.7860**	**1.9730**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274054 / 33/11 KV MENDHAPUR
Feeder No / Name : 203 / 11 KV PANDHAREWADI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1132	.0943	.8684	.9555
2		.1132	.1132	.8848	.9878
3		.1509	.132	.9175	1.0526
4		.2263	.2263	.9393	1.1498
5		.3018	.2829	1.0526	1.2631
6		.3395	.3395	1.2146	1.3765
7		.3772	.3961	1.5223	1.4575
8		.3395	.3961	1.6842	1.5546
9		.2641	.3018	1.8138	1.7652
10	.2263	.2263	.132	.1132	.132
11	1.4899	1.5061	1.5238	.1132	.0566
12	1.6032	1.7004			.132
13	1.668	1.6356	1.6356		.0943
14	1.7328	1.668			.0943
15	1.6518	1.6032	1.2146	.0754	.0943
16	1.3603	1.5061	1.7652	.0943	.1509
17	1.4899	1.5384	1.2955	.1886	.2263
18	1.5223	1.6032	1.7166	.2075	.2829
19	.1698	.1698	.3206	.2263	.3584
20	.2263	.2263	.2641	.2641	.3206
21	.2829	.2829	.2263	.2829	.2263
22	.2452	.2452	.1509	.1886	.1132
23	.132	.1509	.1132	.1509	.1132
24		.1132	.0943	.8684	.8907
Max	**1.7328**	**1.7004**	**1.7652**	**1.8138**	**1.7652**
Min	**.132**	**.1132**	**.0943**	**.0754**	**.0566**
Avg	**.9858**	**.6834**	**.5789**	**.6510**	**.6187**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274054 / 33/11 KV MENDHAPUR
Feeder No / Name : 204 / 11 KV Jadhavwadi Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9667	1.0159	.2263	.2401
2		1.1142	1.2616	.2263	.2572
3		1.3279	1.3927	.2263	.2829
4		1.5223	1.5565	.2641	.3395
5		1.6356	1.7814	.3018	.3429
6		1.9595	2.1214	.3772	.3772
7		2.3805	2.2834	.4527	.3961
8		2.3644	2.4453	.3772	.3772
9		1.1336	2.5263	.3206	.2829
10	.1132	.1509	.2075	.3395	.2829
11	.1132	.132	.132	2.2024	2.5911
12	.0972	.0943	.132		2.6235
13	.1132	.1132	.0943		2.6558
14	.1132	.0943	.0943		2.9473
15	.132	.0943	.132	2.8826	2.9797
16	.1509	.132	.0943	2.7206	3.0121
17	.1886	.1509	.132	2.5911	2.8826
18	.3018	.3018	.2263	2.5101	2.6235
19	.3584	.3772	.415	.415	.2263
20	.3772	.3395	.3772	.3772	.2829
21	.3584	.3018	.3395	.3395	.3584
22	.3206	.2263	.3018	.2641	.3206
23	.2641	.1886	.2263	.2641	.3018
24		.8848	.9667	.2263	.2641
Max	**.3772**	**2.3805**	**2.5263**	**2.8826**	**3.0121**
Min	**.0972**	**.0943**	**.0943**	**.2263**	**.2263**
Avg	**.2144**	**.7494**	**.8440**	**.8526**	**1.1354**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274054 / 33/11 KV MENDHAPUR
Feeder No / Name : 205 / 11 KV Ropale Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0943	.1132	.7865	.8259
2			.0943	.1132	.7865	.9393
3			.1132	.1509	.7865	1.0526
4			.132	.1886	.8097	1.1498
5			.132	.1886	.8097	1.2955
6			.132	.2075	.9393	1.5384
7			.2075	.2075	1.1822	1.7652
8			.1886	.1698	1.2793	2.2186
9	.1132		.1509	.1509	1.3927	2.2186
10		.1698	.132	.0943	.0754	.0754
11		1.4251	1.2955	1.3765	.0754	.0754
12		1.5223	1.4737	1.4251		.0754
13		1.587	1.5708	1.3765		.0754
14		1.7976	1.6356	1.3927		.0754
15		1.7652	1.6842	1.7328	.0566	.0943
16		1.7328	1.7166	1.6842	.0943	.132
17		1.6356	1.668	1.7166	.1132	.132
18		1.4413	1.6032	1.6032	.1132	.2075
19		.0943	.1132	.1509	.1132	.2075
20		.1132	.132	.1509	.132	.1698
21		.1132	.132	.1509	.1509	.1698
22		.1132	.1132	.1132	.1509	.132
23		.0943	.0943	.0943	.1509	.1029
24			.0943	.132	.7865	.7287
Max	**.1132**	**1.7976**	**1.7166**	**1.7328**	**1.3927**	**2.2186**
Min	**.1132**	**.0943**	**.0943**	**.0943**	**.0566**	**.0754**
Avg	**.1132**	**.9718**	**.6126**	**.6118**	**.5136**	**.6441**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274055 / 33/11 KV PAT KUROLI
Feeder No / Name : 201 / 11 KV DEWADE FEEDER SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772		.4287	.5144	.9945	.9755
2	.4115		.4287	.5144	1.0288	1.0669
3	.4115		.4801	.4287	1.0288	1.1279
4	.4287		.5144	.6173	1.0631	1.1888
5	.4287		.5144	.6173	1.166	1.2346
6	.4287		.6001	.6173	1.286	1.326
7	.4115		.583	.6173	1.5089	1.3717
8	.3944		.4287	.5658	1.5432	1.4175
9	.4115		.3429	.4458	1.6804	1.2803
10	.2743		.3429	.3086	.2743	.2915
11	1.1145		1.2803	1.4403	.2572	.2058
12	1.3375		1.1431	1.5089	.2743	.2058
13	1.3375		1.2193	1.4746	.2229	.1715
14	1.3203		1.3413	1.4575	.1886	.1715
15	1.3032		1.387	1.3717	.1886	.1715
16	1.3203	1.2689	1.3717		.1543	.2401
17	1.3032	1.3717	1.3717	1.3889	.2743	.2743
18	1.286	1.4575	1.2346	1.3717	.3429	.3772
19	.4458	.3429	.5316	.5487	.4801	.3772
20	.4287	.5144	.5144	.4801	.3601	.4115
21	.4287		.4973	.4458	.3429	.4115
22	.3944	.463	.4973	.4458	.3429	.4458
23	.3601	.4115	.4287	.4115	.3772	.4458
24	.3772		.4115	.5144	1.0288	.884
Max	**1.3375**	**1.4575**	**1.387**	**1.5089**	**1.6804**	**1.4175**
Min	**.2743**	**.3429**	**.3429**	**.3086**	**.1543**	**.1715**
Avg	**.6973**	**.8328**	**.7456**	**.7873**	**.6837**	**.6698**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274055 / 33/11 KV PAT KUROLI
Feeder No / Name : 204 / 11 KV SHEVATE SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429		.3048	.2572	.0686	.1029
2	.3772		.3353	.2915	.0686	.1029
3	.4287		.3506	.3086	.0686	.12
4	.4287		.3658	.3429	.0857	.12
5	.4287		.4115	.3429	.1029	.1029
6	.4287		.4572	.3601	.1029	.12
7	.463		.5792	.5487	.0857	.12
8	.4801		.6097	.5658	.0857	.12
9	.4973		.7011	.463	.0686	.0857
10	.0514		.1067	.0514	.0514	.0686
11	.0514		.0686	.0514	.4287	.4287
12	.0343		.0343	.0514	.463	.4268
13	.0514		.0343		.4458	.6516
14	.0514		.0343	.0514	.4287	.6516
15	.0343		.0343	.0514	.5487	.5944
16	.0343	.0857	.0343	.0514	.5658	.5639
17	.0514	.0857	.0343	.0686	.5316	.5335
18	.0514	.0857	.0686	.0686	.5487	.2334
19	.1029	.1029	.1029	.0857	.1029	.0514
20	.0857	.1029	.0857	.1029	.1029	.0514
21	.0857		.1029	.0857	.0857	.0686
22	.0686	.0857	.1029	.0857	.0686	.0686
23	.0514	.0857	.0686	.0686	.0686	.0514
24	.3429		.3048	.2058	.0686	.1029
Max	**.4973**	**.1029**	**.7011**	**.5658**	**.5658**	**.6516**
Min	**.0343**	**.0857**	**.0343**	**.0514**	**.0514**	**.0514**
Avg	**.2093**	**.0906**	**.2222**	**.1983**	**.2186**	**.2309**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274055 / 33/11 KV PAT KUROLI
Feeder No / Name : 206 / 11 KV PAT.KUROLI GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715		.1829	.1715	.1715	.1715
2	.1715		.3658	.1715	.1715	.1829
3	.1715		.3658	.1715	.1715	.1829
4	.3429		.3658	.1715	.3429	.1715
5	.3429		.3658	.3429	.3429	.1829
6	.3429		.5658	.3429	.3429	.1829
7	.3429		.3658	.3429	.3429	.1715
8	.3429		.3658	.3429	.3429	.1829
9	.1715		.1829	.3429	.1715	.1829
10	.1715		.1829	.1715	.1715	.1715
11	.1715		.1829	.1715	.1715	
12	.1715		.0914	.1715	.1715	.1829
13	.1867		.0914	.1715	.1715	.1829
14	.1715		.0914	.1715	.1715	.0914
15	.1715		.0914	.1715		.0914
16	.1715	.1715	.0914			.0914
17	.1715	.1715	.1829	.1715	.1715	.0857
18	.1715	.1715	.1715	.1715	.1715	.1829
19	.3429	.1715	.3658	.3429	.1715	.3658
20	.3429	.3429	.3658	.3429	.3429	.3658
21	.3429	.3429	.3658	.3429	.3429	.3429
22	.3429	.1715	.1829	.3429	.1715	.1829
23	.1715	.1715	.1829	.1715	.1715	.1829
24	.1715		.1829	.1715	.1715	.1829
Max	**.3429**	**.3429**	**.5658**	**.3429**	**.3429**	**.3658**
Min	**.1715**	**.1715**	**.0914**	**.1715**	**.1715**	**.0857**
Avg	**.2364**	**.2144**	**.2479**	**.2386**	**.2260**	**.1876**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274057 / 33/11 KV TUNGAT
Feeder No / Name : 202 / 11 KV SUSTE **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	.0343	.0343	.4268	.5944
2	.0343	.0343	.0343	.0335	.0343	.4572	.5639
3	.0343	.0343	.0343	.0343	.0343	.4572	.5792
4	.0343	.0343	.0343	.0343	.0343	.442	.5639
5	.0343	.0343	.0343	.0343	.0343	.5182	.6097
6	.0343	.0343	.0343	.0343	.0343	.5944	.7316
7	.0343	.0343	.0343	.0343	.0343	.7011	.7468
8	.0343	.0343	.0343	.0343	.0343	.823	.7926
9	.0343	.0343	.0343	.0343	.0343	.8078	.8535
10	.0343	.0343	.0343	.0343	.0343	.0343	.0343
11	.7773	.7621	.7316	.7316	.7926	.0343	.0343
12	.9145	.8078	.7926	.7926	.8535	.0343	.0343
13	.9755	.7926	.7468	.823	.884	.0343	.0343
14	1.046	.823	.7316	.884	.884	.0343	.0343
15	.9145	.8535	.7316	.8535	.823	.0343	.0343
16	.884	.8688	.7316	.8535	.823	.0343	.0343
17	.8535	.7926	.6706	.8535	.7926	.0343	.0343
18	.7316	.823	.6706	.7926	.7773	.0343	.0343
19	.0343	.0343	.0343	.0335	.0335	.0343	.0343
20	.0343	.0343	.0343	.0343	.0343	.0343	.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	.0343
22	.0343	.0343	.0343	.0343	.0343	.0343	.0343
23	.0343	.0343	.0343	.0343	.0343	.0343	.0343
24		.0343	.0343	.0343	.0343	.4268	.5792
Max	**1.046**	**.8688**	**.7926**	**.884**	**.884**	**.823**	**.8535**
Min	**.0343**	**.0343**	**.0343**	**.0335**	**.0335**	**.0343**	**.0343**
Avg	**.3309**	**.2947**	**.2648**	**.2971**	**.2991**	**.2556**	**.2956**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274057 / 33/11 KV TUNGAT
Feeder No / Name : 203 / 11 KV ROPALE SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4327	1.3717	1.1888	1.2193	1.2498	.0343	.0686
2	1.4632		1.2193	1.2346	1.3108	.0343	.0686
3	1.4937	1.4327	1.2193	1.2193	1.3717	.0343	.0686
4	1.5089	1.4784	1.2498	1.2498	1.4022	.0343	.0686
5	1.5242	1.5089	1.2803	1.2955	1.4327	.0343	.0686
6	1.5851	1.5242	1.4327	1.4632	1.4632	.0343	.0686
7	1.7528	1.5851	1.5546	1.768	1.7071	.0343	.0686
8	1.9052	1.6461	1.5546	2.0729	1.89	.0343	.0686
9	1.829	1.829	1.8595	2.0119	1.829	.0343	
10	.0686	.0686	.0686	.0671	.0343	.0343	
11	.0686	.061	.0686	.0686	.0343	1.7071	1.8595
12	.0686	.0686	.0686	.0686	.0343	2.1948	2.2558
13		.0686	.0686	.0686	.0343	2.0729	
14		.0686	.0686	.0686	.0343	2.4082	.7926
15		.0686	.0686		.0343	2.1033	
16	.0686	.0686	.0686	.0686	.0343	2.1338	2.2558
17	.0686	.0686	.0686	.0686	.0343	2.2558	2.1186
18	.0686		.0686	.0686	.0343	2.0119	2.0424
19	.0686	.0686	.0686	.0686	.0343	.0686	.0343
20	.0686	.0686	.0686	.0686	.0343	.0686	.0343
21	.0686	.0686	.0686	.0686	.0343	.0686	.0343
22	.0686	.0686	.0686	.0686	.0343	.0686	.0343
23	.0686	.0686	.0686	.0686	.0343	.0686	.0343
24		1.3717	1.1888	1.2803	1.2193	.0343	.0686
Max	**1.9052**	**1.829**	**1.8595**	**2.0729**	**1.89**	**2.4082**	**2.2558**
Min	**.0686**	**.061**	**.0686**	**.0671**	**.0343**	**.0343**	**.0343**
Avg	**.7625**	**.6651**	**.6128**	**.6828**	**.6398**	**.7337**	**.6057**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274057 / 33/11 KV TUNGAT
Feeder No / Name : 204 / 11 KV NARANCHOLI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1543	.0686	.1029	.12	1.1584	1.2041
2		.1715	.0857	.1029	.1372	1.1888	1.2498
3		.1886	.0857	.1372	.1715	1.1736	1.2803
4		.1886	.1029	.1543	.1886	1.2193	1.5432
5		.2229	.12	.1715	.2401	1.2803	1.6766
6		.2572	.1715	.1715	.2743	1.6613	1.7528
7		.2915	.1886	.1543	.2743	1.9357	2.1338
8		.2743	.1715	.1543	.2915	2.1491	2.4539
9		.2229	.1543	.1372	.2229	2.1795	2.1795
10		.1509	.12	.1543	.1372	.12	.1543
11		2.3015	2.4691	2.1491	2.2558	.12	.0857
12		1.9662	2.8349	2.8349	2.5301	.1029	.0343
13		2.9721	2.8959	2.8654	2.5453	.1029	.0514
14	2.8654	2.9264	2.8349	.7926	2.3624	.1029	.0857
15	2.8197	2.9569	2.4387	2.271	2.3929	.1029	.0686
16		2.6978	1.5242	2.8502	2.774	.12	.1029
17		2.9111	2.6063	2.6063	2.652	.12	.1543
18	2.6978	2.5301	2.2862	2.5149	2.4387	.1543	.2229
19	.2743	.1715	.1715	.2572	.1715	.1543	.2058
20	.2401	.1715	.1543	.2058	.1543	.1543	.1715
21	.1886	.1372	.1372	.1715	.1372	.1372	.1543
22	.1715	.1372	.1029	.1372	.1372	.1372	.1372
23	.1543	.0857	.1029	.12	.12	.1372	.1372
24		.1372	.0686	.1029	.1029	1.1431	1.2193
Max	**2.8654**	**2.9721**	**2.8959**	**2.8654**	**2.774**	**2.1795**	**2.4539**
Min	**.1543**	**.0857**	**.0686**	**.1029**	**.1029**	**.1029**	**.0343**
Avg	**1.1765**	**1.0094**	**.9124**	**.8883**	**.9513**	**.7023**	**.7691**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274057 / 33/11 KV TUNGAT
Feeder No / Name : 205 / 11 KV TUNGAT GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2229	.2572	.2743	.2743	.2229	.3086
2		.3258	.2743	.2572	.3258	.2401	.2915
3		.3429	.3086	.2915	.3772	.2401	.2915
4		.4287	.3601	.3258	.4458	.2743	.3429
5		.4973	.4115	.3772	.4973	.4973	.4458
6		.5316	.5316	.5144	.5316	.5658	.4801
7		.4801	.583	.5487	.5487	.5316	.463
8		.3772	.4801	.463	.4458	.4801	.4801
9		.2743	.3601	.3258	.2683	.3429	.3772
10		.3086	.4458	.3258	.2743	.2915	.2572
11		.2915	.2915	.2743	.2229	.2572	.2229
12		.2743	.2915	.2058	.2058	.2058	.2572
13		.2401		.1886	.2058	.2229	
14		.2058	.2229	.2058	.1543	.1886	.0686
15		.1715	.2058	.1543		.1715	.1886
16	.2401	.2401	.1886	.1543	.1886	.1715	.1886
17	.2572	.2401	.2572	.2229	.2229		.2058
18	.4115		.3429	.3086	.3429	.3429	.3772
19	.4458	.463	.463		.5144	.463	.5144
20	.4115	.463	.4115	.3944	.4115	.4458	.4458
21	.3429	.4115	.4115	.3258	.3772	.4115	.3944
22	.3086	.3772	.3772	.2915	.3258	.3772	.3429
23	.2572	.3429	.3086	.2229	.2401	.2743	.2915
24		.2401	.2572	.2572	.2401	.2229	.2915
Max	**.4458**	**.5316**	**.583**	**.5487**	**.5487**	**.5658**	**.5144**
Min	**.2401**	**.1715**	**.1886**	**.1543**	**.1543**	**.1715**	**.0686**
Avg	**.3344**	**.3370**	**.3496**	**.3004**	**.3322**	**.3236**	**.3273**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274058 / 33/11 KV UMBRE
Feeder No / Name : 201 / 11 KV KANHAPURI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.218	.1677	.1526	.2374
2			.2035	.1509	.1187	
3			.2035	.1844	.1526	.2374
4			.2204	.1509	.1187	.2374
5			.2543	.1677	.1696	
6			.2883	.2012	.1865	
7		.1844	.3222	.1677	.1696	
8			.2374	.2012	.1865	
9			.1696	.2012	2.8147	
10			.2035	.218	2.8656	
11			.1677	.1844	3.086	
12			.1509	.1677	3.0521	
13			.1844	.1509	3.0352	2.9673
14			.1677	.1174	3.103	2.9673
15			.1174	.1006	3.0521	2.9673
16			.1174	.1174	2.9843	3.0182
17			3.3364	.1844	.1696	
18			3.2023	2.7999	.2204	
19		3.4202	3.1352	2.934	.2204	
20	3.3532	3.3532	3.0514	2.9675	.2204	
21	3.0178	3.2861	3.0011		.2374	
22	2.6825	3.219	2.934		.2204	
23	2.6825	3.1352	2.7999		.2035	
24			3.0178	2.6993	2.8317	.2374
Max	**3.3532**	**3.4202**	**3.3364**	**2.9675**	**3.103**	**3.0182**
Min	**2.6825**	**.1844**	**.1174**	**.1006**	**.1187**	**.2374**
Avg	**2.934**	**2.7664**	**1.1543**	**.6778**	**1.2322**	**1.6087**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274058 / 33/11 KV UMBRE
Feeder No / Name : 202 / 11 KV KAROLE **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1372	.1029	.0617	.0949
2			.116	.0876	.088	.0781
3			.1235	.116	.0762	.0903
4			.1457	.104	.0914	.108
5			.1658	.0709	.0791	.0949
6			.1524	.0867	.0762	.1147
7		.0926	.1219	.0995	.0926	.1326
8			.0974	.1014	.1067	1.2955
9			.12		1.5364	1.531
10			.1	.1463	1.5089	
11			.0857	.1029	1.5394	1.656
12			.0812	.0781	1.6288	1.7497
13			.0511	.0587	1.5741	1.7497
14			.0581	.08	1.7661	1.7185
15				.0867	1.5546	1.6872
16				.0457	1.5895	1.6716
17			1.8991	1.5394	.0772	.0781
18			1.7652	1.4523	.0926	.0781
19		1.7236	1.6004	1.4661	.0903	.125
20	1.8404	1.6004	1.6356	1.5339	.0926	.125
21	1.7604	1.6741	1.6409	1.5384	.1094	.0937
22	1.6004	1.5384	1.4661	1.3889	.0926	.0937
23	1.4403	1.6078	1.6032		.0791	.0937
24			1.4373	1.4706	1.3146	.0949
Max	**1.8404**	**1.7236**	**1.8991**	**1.5394**	**1.7661**	**1.7497**
Min	**1.4403**	**.0926**	**.0511**	**.0457**	**.0617**	**.0781**
Avg	**1.6604**	**1.3728**	**.6638**	**.5344**	**.6383**	**.6328**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274058 / 33/11 KV UMBRE
Feeder No / Name : 203 / 11 KV UMBRE **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.743	.9145	.9145	.0572	.0579
2		.743	1.0002	.8573	.0572	.0579
3		.8916	.9431	.9431	.0572	.0579
4		1.0402	1.0574	1.0002	.0572	.0579
5		1.0402	1.0002	.9145	.0572	.0579
6		1.0402	1.086	1.0002	.0572	.0579
7		1.0402	1.1431	1.1431	.0572	.0579
8			.0572	1.1145	.0572	.0579
9			.0572	.0572	.0572	.0579
10			.0572	.0572	.0572	.0579
11			.0572	.0572	.0579	.0572
12			.0572	.0572	.0579	.0572
13			.0572	.0572	.0579	.0572
14			.0572	.0572	.0579	.0572
15			.0572	.0572	.0579	.0572
16			.0572	.0572	.0579	.0572
17			.0572	.0572	1.1584	1.0717
18			.0572	.0572	1.2163	1.0717
19		.0594	.0572	.0572	1.2574	1.1431
20		.0594	.0572	.0572	1.1294	1.0717
21	.0579	.0594	.0572		1.0715	1.0002
22	.0579	.0594	.0572		1.0425	.9288
23	.0579	.0594	.0572		1.0425	.9288
24		.0594	.0594	.0579	.0572	.9556
Max	**.0579**	**1.0402**	**1.1431**	**1.1431**	**1.2574**	**1.1431**
Min	**.0579**	**.0594**	**.0572**	**.0572**	**.0572**	**.0572**
Avg	**.0579**	**.5304**	**.3383**	**.4110**	**.3706**	**.3789**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274058 / 33/11 KV UMBRE
Feeder No / Name : 204 / 11 KV UMBRE GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3582	.3696	.3506	
2			.4024	.3395	.3982	.4854
3			.3506	.3696	.4435	.4435
4			.4066	.4481	.4854	.4481
5			.415	.4435	.4527	.4534
6			.439	.5281	.5281	.4854
7		.4344	.4904	.4854	.4656	
8			.4298	.4854	.439	
9			.3982	.4298	.3506	.3506
10			.3506	.3772	.3658	.362
11			.3582	.3506	.181	.3658
12			.3361	.3155	.1387	2.0271
13			.2743	.2865	.156	.181
14			.2507	.2454	.1372	.2172
15			.2454	.2454	.1372	.2172
16			.2804	.2058	.2103	.2172
17			.3224	.2804	.2454	.2172
18			.3582	.3224	.3856	.362
19		.3479	.4024	.3658	.4481	.4344
20	.4656	.3978	.3982	.4481	.5121	.4344
21	.4298	.3612	.4435		.4854	.4344
22	.4298	.3563	.4344		.4854	.3982
23	.394	.3647	.4066		.4527	.362
24			.415	.3772	.3658	.4527
Max	**.4656**	**.4344**	**.4904**	**.5281**	**.5281**	**2.0271**
Min	**.394**	**.3479**	**.2454**	**.2058**	**.1372**	**.181**
Avg	**.4298**	**.3771**	**.3736**	**.3676**	**.3592**	**.4452**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274058 / 33/11 KV UMBRE
Feeder No / Name : 205 / 11KV Kanal Fata Feeder SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			2.2291	1.829	.2543	.1581
2			2.3838	2.0243	.2721	.1823
3			2.3034	2.0056	.2286	.1581
4			2.2977	1.929	.2818	.2035
5			2.3205	1.9919	.3429	.2105
6			2.3529	2.1628	.2778	.2134
7		2.3205	2.2977	2.3834	.2572	.2006
8			2.4446	2.5415	.2804	.2107
9			.0943	.2452	.2149	.1928
10			.1663	.2772	.1829	.1829
11			.1227	.2218	.1772	.1829
12			.1372	.1612	.181	.1463
13			.1214	.1402	.1629	.1463
14			.1433	.1612		.1463
15			.1543	.1848	.1372	.1463
16			.1402	.181	.1227	.1463
17			.1492	.1928	2.774	2.5777
18			.1739	.1543	2.7566	2.7664
19		.1677	.1658	.2155	2.6791	2.8502
20	.2458	.1457	.1943	.192	2.6452	2.4996
21	.2458	.1698	.1526		2.451	2.6825
22	.213	.1492	.1698		2.5652	2.6825
23	.1966	.1943	.1524		2.5029	2.6825
24			.1739	.2035	.2401	2.4756
Max	**.2458**	**2.3205**	**2.4446**	**2.5415**	**2.774**	**2.8502**
Min	**.1966**	**.1457**	**.0943**	**.1402**	**.1227**	**.1463**
Avg	**.2253**	**.5245**	**.8767**	**.9237**	**.956**	**1.0018**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274058 / 33/11 KV UMBRE
Feeder No / Name : 206 / 11 KV SANGAVI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			2.0317	1.8023	.1943	
2			2.13	1.8842	.1619	.2105
3			2.2119	1.8187	.2105	.1943
4			2.1464	1.917	.2429	.1781
5			2.2119	1.8842	.2429	.2267
6			2.1464	1.9662	.2915	.2591
7		2.0243	2.1956	.1677	.3563	.2591
8			2.2119	2.1956	.3239	.2753
9			.2458	.1638	.3113	.2915
10			.213	.1802		.2591
11			.1619	.1475	.1619	.2591
12			.1781	.1802	.1781	.1943
13			.1943	.1638	.1619	.1619
14			.1619	.1966	.1943	.081
15			.0972	.1638		.0972
16			.1134	.1802	.081	.0972
17			.1457	.1475	2.251	2.4615
18			.1781	.1475	2.2672	2.4615
19		.1966	.1475	.1638	2.251	2.5101
20	.1781	.1802	.1619	.1966	2.2186	2.4291
21	.1781	.1638	.1781		2.1214	2.4291
22	.1781	.1966	.1943		2.0243	2.4615
23	.1619	.1475	.1619		1.9595	2.4615
24			.1802	.1966	.1457	1.9109
Max	**.1781**	**2.0243**	**2.2119**	**2.1956**	**2.2672**	**2.5101**
Min	**.1619**	**.1475**	**.0972**	**.1475**	**.081**	**.081**
Avg	**.1741**	**.4848**	**.8333**	**.7554**	**.8342**	**.9639**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274058 / 33/11 KV UMBRE
Feeder No / Name : 207 / 11 KV JALOLI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.181		2.3529	2.3891
2			.1991	.181	2.2624	2.4434
3			.1629	.2172	2.3348	2.4072
4			.181	.181	2.2624	2.4253
5			.2353	.2353	2.3529	2.5882
6			.2172	.2534	2.5158	2.733
7		.2715	.2353	.1991	2.5701	2.8959
8			3.0769	.2172	2.7873	3.0407
9			3.1493	2.8959	.2172	.1629
10			3.0769	2.9502	.1629	.181
11			3.0769	2.8959		
12			2.9683	2.9864		.0724
13			2.914	2.8416		.0724
14			2.8778	2.914		.0724
15			2.914	2.9502		.0724
16			2.9683	2.8597	.0905	.0724
17			.1991	.1991	.1448	.1267
18			.181	.181	.1629	.1134
19		.1991	.2172	.1629	.1629	.181
20	.2172	.181	.1629	.1991	.181	.1619
21	.2172	.1991	.181		.1991	.181
22	.2172	.1629	.1991		.1629	.181
23	.2172	.181	.181		.181	.181
24			.1448	.1448	.1629	.1629
Max	**.2172**	**.2715**	**3.1493**	**2.9864**	**2.7873**	**3.0407**
Min	**.2172**	**.1629**	**.1448**	**.1448**	**.0905**	**.0724**
Avg	**.2172**	**.1991**	**1.2458**	**1.2833**	**1.1193**	**.9964**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274058 / 33/11 KV UMBRE
Feeder No / Name : 208 / 11 KV KALANANI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0191			.0463	.0452
2		.0191			.0457	.0457
3		.0191			.0486	.0469
4		.0191			.0503	.0474
5		.0191			.0446	.0457
6		.0191			.0446	.0452
7		.0191			.0463	.0497
8					.0514	.0486
9			.0572	.044		
10			.0572	.0434		
11			.0343	.0452		.0191
12			.0354	.0497		.0191
13			.0358	.0514		.0191
14			.052	.0497		.0191
15			.0514	.0457		.0191
16			.0362	.0474		.0191
17						.0191
18						.0191
19						.0191
20						.0191
21	.0191					.0191
22	.0133					.0191
23	.0133					.0191
24		.0191				
Max	**.0191**	**.0191**	**.0572**	**.0514**	**.0514**	**.0497**
Min	**.0133**	**.0191**	**.0343**	**.0434**	**.0446**	**.0191**
Avg	**.0152**	**.0191**	**.0449**	**.0471**	**.0472**	**.0297**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274058 / 33/11 KV UMBRE
Feeder No / Name : 209 / 11 KV SUTAR MALA **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1905	.1143	.1143	.1905
2			.1524	.1524	.1524	.1905
3			.1143	.1143	.1143	.1905
4			.1143	.1143	.1143	.1905
5			.1524	.1524	.1143	.2667
6			.1905	.1524	.1524	.2667
7		.1905	.1905	.1143	.1143	.2286
8			.1524	.1524	.1143	.2286
9			.1524	.1143	2.5911	2.7054
10			.1905	.1143	2.6673	2.7435
11			.1524	.0762	2.6673	2.7625
12			.1524	.0762	2.7054	2.8578
13			.1143	.1143	2.6673	2.6673
14			.1143	.0762	2.7054	2.6673
15			.1143	.1143	2.6673	2.6673
16			.1143	.1143	2.6673	2.6673
17			3.2388	3.1245		.1143
18			3.2769	2.9721	.1524	.1143
19		3.1245	3.1245	2.8959	.1905	.1905
20	3.0483	3.0483	3.0483	2.8197	.1905	.1524
21	2.8578	2.9721	3.2007		.1524	.1905
22	2.8578	2.8959	3.2007		.1905	.1905
23	2.6673	2.8578	3.1245		.1905	.1524
24			2.7435	2.9721	2.5149	.1905
Max	**3.0483**	**3.1245**	**3.2769**	**3.1245**	**2.7054**	**2.8578**
Min	**2.6673**	**.1905**	**.1143**	**.0762**	**.1143**	**.1143**
Avg	**2.8578**	**2.5149**	**1.1383**	**.7929**	**1.1266**	**1.0328**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274104 / 33/11 KV TARAPUR
Feeder No / Name : 201 / 11 KV TARAPUR **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0953	.0953	.9907	.9145
2		.0953	.0953	1.0212	.9145
3		.1143	.0953	1.0364	.9145
4		.1143	.0953	1.0802	1.0031
5		.1334	.1143	1.0974	.9145
6		.1524	.1334	1.1279	1.0212
7		.1334	.1334	1.2346	1.1431
8		.1143	.1334	1.4842	1.3904
9		.1143	.1143	1.4784	1.5466
10		.0953	.1143	.0953	.0953
11		1.6309	1.6156	.0953	.0953
12		1.8138		.0953	.0953
13			1.8442	.0953	.0953
14		1.5699	1.768	.0953	.0953
15		1.7528	1.9753	.0953	.0953
16		1.7223	1.7985	.0953	.0953
17		1.7071	1.8595	.0953	.0953
18		.1677	1.7747	.1143	.1334
19		.1143	.0953	.1334	.1334
20		.1143	.0953	.1334	.1334
21		.0953	.0953	.1334	.0953
22		.0953	.0953	.1143	.0953
23	.0953	.0953	.0953	.0953	.0953
24		.0953	.0953	1.0059	1.0364
Max	**.0953**	**1.8138**	**1.9753**	**1.4842**	**1.5466**
Min	**.0953**	**.0953**	**.0953**	**.0953**	**.0953**
Avg	**.0953**	**.5277**	**.6231**	**.5435**	**.5103**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274104 / 33/11 KV TARAPUR
Feeder No / Name : 206 / 11 KV SUSTE SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0191	.0191	.0457	.061
2		.0191	.0191	.0617	.061
3		.0381	.0191	.061	.061
4		.0381	.0191	.0772	.0762
5		.0381	.0191	.0762	.0914
6		.0381	.0381	.0914	.1389
7		.0381	.0381	.1524	.1718
8		.0572	.0381	.1677	.2343
9		.0381	.0381	.1981	.2134
10		.0191	.0191	.0191	.0191
11		.1372	.1829	.0191	.0191
12		.1524	.2134	.0191	.0191
13			.1932	.0191	.0191
14		.1219	.2286	.0191	.0191
15		.1524	.1981	.0191	.0191
16		.1981	.2343	.0191	.0191
17		.2286	.1852	.0191	.0191
18		.1981	.1677	.0381	.0381
19		.0305	.0191	.0381	.0381
20		.0381	.0191	.0381	.0191
21		.0191	.0191	.0191	.0191
22		.0191	.0191	.0191	.0191
23	.0191	.0191	.0191	.0191	.0191
24		.0191	.0191	.0457	.0457
Max	**.0191**	**.2286**	**.2343**	**.1981**	**.2343**
Min	**.0191**	**.0191**	**.0191**	**.0191**	**.0191**
Avg	**.0191**	**.0729**	**.0827**	**.0542**	**.0608**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274119 / 33/11 KV DEGAON
Feeder No / Name : 201 / 11 KV DEGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6802	.6401	.6173	.7545
2		.6668	.6668	.6173	.8059
3		.6668	.7202	.6516	.8745
4		.7335	.8002	.7202	.9431
5		1.0212	.9469	.8745	1.0802
6		1.0536	1.0536	1.0974	1.2003
7		1.0212	.9469	1.2003	1.5089
8		.6668	.9335	1.406	1.5775
9		.8669	.7602	1.2003	1.2651
10		.4934	.4801	.5201	.6706
11		.9755	1.0364	.3353	.4134
12		1.0974	1.2689	.2134	.4534
13		1.1584	1.3717	.1867	.3467
14		1.2955	1.1431	.3601	.3734
15		1.1279	1.1279	.3601	.3734
16	1.1736	1.1584	1.0822	.3868	.4001
17	1.0669	1.1431	1.0669	.4934	.4401
18	1.1126	1.2193	1.1736	.7202	.7602
19	.8669	1.0269	1.1736	1.0269	1.0269
20	.9335	.9069	1.1279	.9069	.9469
21	.7868	.8535	.8002	.8002	.8002
22	.7335	.7468	.7335	.6935	.6935
23	.7068	.6935	.6668	.6268	.6535
24		.6802	.6135	.583	.6859
Max	**1.1736**	**1.2955**	**1.3717**	**1.406**	**1.5775**
Min	**.7068**	**.4934**	**.4801**	**.1867**	**.3467**
Avg	**.9226**	**.9147**	**.9306**	**.6916**	**.7937**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274119 / 33/11 KV DEGAON
Feeder No / Name : 202 / 11 KV ADHIV **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7926	.884	.2572	.3353
2		.8535	.9145	.2572	.3772
3		.9145	.945	.2401	.381
4		.945	1.0059	.2915	.4268
5		1.0059	1.0822	.4973	.5487
6		1.2041	1.1584	.583	.6687
7		1.5242	1.4022	.7202	.7373
8		1.6309	1.5394	.583	.7373
9		1.4327	1.4175	.4458	.503
10		.3258	.3258	.2915	.3601
11		.2743	.2058	1.4784	1.6004
12		.1715	.1886	1.6004	1.7071
13		.2229	.1715		1.89
14		.1886	.2229	1.6613	1.8747
15		.2058	.2401	1.8138	1.89
16	.2915	.2229	.2572	1.6766	1.89
17	.3086	.2915	.2743	1.6004	1.768
18	.4458	.4801	.4801		1.6918
19	.5144	.6173	.6344	.5658	.6344
20	.583	.5658	.6173	.4801	.6001
21	.4458	.4973	.583	.4287	.5316
22	.3772	.3048	.3429	.3506	.4115
23	.2743	.2915	.2915	.3353	.3086
24		.7621	.8688	.2743	.3353
Max	**.583**	**1.6309**	**1.5394**	**1.8138**	**1.89**
Min	**.2743**	**.1715**	**.1715**	**.2401**	**.3086**
Avg	**.4051**	**.6552**	**.6689**	**.7469**	**.9254**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274119 / 33/11 KV DEGAON
Feeder No / Name : 203 / 11 KV AJANSOND SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0191	.0191	.7926	.7164
2		.0191	.0191	.823	.7773
3		.0191	.0191	.823	.8383
4		.0191	.0191	.8383	.884
5		.0191	.0191	.8688	.9145
6		.0191	.0191	1.1584	1.0364
7		.0191	.0191	1.3565	1.387
8		.0191	.0191	1.6289	1.6004
9			.0191	1.5261	1.326
10		.0191	.0191	.0191	.0191
11		1.2041	1.4327	.0191	.0191
12		1.5546	1.4937	.0191	.0191
13		1.6156	1.5699	.0191	.0191
14		1.3413	1.6613	.0191	.0191
15		1.5699	1.6461	.0191	.0191
16	1.448	1.5851	1.5699	.0191	.0191
17	1.448	1.5242	1.6004	.0191	.0191
18	1.387	1.4937	1.4937	.0191	.0191
19	.0191	.0191	.0191	.0191	.0191
20	.0191	.0191	.0191	.0191	.0191
21	.0191	.0191	.0191	.0191	.0191
22	.0191	.0191	.0191	.0191	.0191
23	.0191	.0191	.0191	.0191	.0191
24		.0191	.0191	.7621	.6554
Max	**1.448**	**1.6156**	**1.6613**	**1.6289**	**1.6004**
Min	**.0191**	**.0191**	**.0191**	**.0191**	**.0191**
Avg	**.5473**	**.5293**	**.5322**	**.4519**	**.4335**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274119 / 33/11 KV DEGAON
Feeder No / Name : 204 / 11 KV S.Dumala SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4801	.3601	.3429	.3429
2		.5144	.3772	.3429	.3772
3		.6001	.3944	.4115	.463
4		.6516	.4287	.4458	1.6804
5		.6516	.463	.6173	.6001
6		.7716	.5658	.6859	.6687
7		.8402	.583	.7716	.7202
8		.7716	.6516	.6859	.6173
9		.6687	.5658	.5487	.4973
10		.4115	.3772	.3944	.3772
11		.3429	.3429	.6859	.7202
12		.3086	.3429	.6859	.7545
13		.2401	.3258	.6687	.8059
14		.1372	.3258	.6001	.823
15		.2743		.7373	.7716
16	.3429	.2915	.3258	.823	.7202
17	.3258	.3429	.3429	.7888	.7888
18	.4458	.5658	.5144	.703	.7202
19	.5144	.6516	.6516	.6173	.6001
20	.583	.6173	.6344	.5316	.4801
21	.4973	.4801	.6001	.4801	.4801
22	.4287	.4115	.4458	.3772	.3772
23	.3601	.3772	.3772	.3258	.3086
24		.463	.3601	.3601	.3258
Max	**.583**	**.8402**	**.6516**	**.823**	**1.6804**
Min	**.3258**	**.1372**	**.3258**	**.3258**	**.3086**
Avg	**.4373**	**.4944**	**.4503**	**.5680**	**.6259**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274119 / 33/11 KV DEGAON
Feeder No / Name : 205 / 65 ACRE GAONTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0381	.0381	.0572	.0381
2		.0381	.0381	.0381	.0381
3		.0381	.0381	.0572	.0381
4		.0572	.0572	.0572	.0381
5		.0572	.0572	.0572	.0191
6		.0572	.0572	.0572	.0381
7		.0381	.0381	.0572	.0381
8		.0381	.0381	.0572	.0381
9		.0381	.0191	.0381	
10		.0953	.0572	.0572	.0381
11		.0572	.0762	.0762	.0572
12		.0572	.0762	.0953	.0572
13		.1143	.0762	.0762	.0572
14		.0762	.1143	.0762	.0572
15		.0381	.0762	.0762	.0572
16	.0762	.0572	.0572	.0572	.0572
17	.0381	.0381	.0762	.0191	.0572
18	.0381	.0762	.0762	.0381	.0572
19	.0381	.0381	.0762	.0381	.0381
20	.0381	.0572	.0572	.0381	.0381
21	.0762	.0572	.0572	.0381	.0191
22	.0572	.0572	.0572	.0381	.0381
23	.0572	.0572	.0572	.0381	.0381
24		.0514	.0381	.0572	.0381
Max	**.0762**	**.1143**	**.1143**	**.0953**	**.0572**
Min	**.0381**	**.0381**	**.0191**	**.0191**	**.0191**
Avg	**.0524**	**.0553**	**.0588**	**.054**	**.0431**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274120 / 33/11 KV BHOSE
Feeder No / Name : 201 / 11 KV PEHE **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3048	.2896	.0171	.0171
2		.3201		.0152	.0171
3		.3353		.0305	.0171
4		.3353		.0305	.0173
5		.3506		.0305	.0171
6		.3658		.0457	.0171
7		.4572	.442	.0305	.0343
8		.4877	.4572	.0305	.0343
9	.381	.4572	.3963	.0305	.0152
10	.0152	.0305	.0305	.0171	.0305
11	.0152	.0152	.0152	.3944	.3963
12	.0152	.0152	.0152	.4287	.442
13	.0152	.0152	.0152	.463	
14	.0152	.0152	.0152	.4458	
15	.0152	.0152	.0171	.4458	.1677
16	.0152	.0152	.0171	.463	.1524
17	.0152	.0305	.0171	.463	.1524
18	.0152	.0305	.0152	.4801	
19	.0305	.0305	.0152	.0343	.2439
20	.0305	.0305	.0152	.0343	.2743
21	.0152	.0305	.0305	.0343	.2591
22	.0152	.0305	.0305	.0343	.2439
23	.0152	.0152	.0305	.0343	.2286
24		.2896	.2743	.0152	.0171
Max	**.381**	**.4877**	**.4572**	**.4801**	**.442**
Min	**.0152**	**.0152**	**.0152**	**.0152**	**.0152**
Avg	**.0416**	**.1676**	**.1126**	**.1687**	**.1331**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274120 / 33/11 KV BHOSE
Feeder No / Name : 202 / 11 KV SUGAON BHOSE SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4327				.2572
2	1.4327				.2572
3	1.3717				.2915
4					.3429
5	1.5242		1.4327		.3772
6	1.7071		1.5851		.3429
7	2.1643		1.7985		.3086
8	2.1643		2.0424		.3086
9	2.0424		1.9052		.2134
10	1.4327	.2134	.1677		.1829
11	1.4327	.1219			1.8595
12	1.3717	.1219			2.0576
13	1.448	.1067	.1677	1.8519	2.0729
14	.1067	.1067	.1715	2.0062	2.1033
15	.1067	.1219		2.0576	2.0881
16	.1219	.1219	.1829	2.1091	2.0729
17	.1372	.1829	.2058	2.1262	1.9814
18	.2439	.2591	.2896		
19	.3506	.3048		.3429	.2286
20	.3048	.2439		.3086	
21	.2743	.2286		.2743	.2286
22	.2286	.2286		.2229	.2134
23	.1829	.1981		.1886	
24	1.4632				.2401
Max	**2.1643**	**.3048**	**2.0424**	**2.1262**	**2.1033**
Min	**.1067**	**.1067**	**.1677**	**.1886**	**.1829**
Avg	**1.0020**	**.1829**	**.9045**	**1.1488**	**.8585**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274120 / 33/11 KV BHOSE
Feeder No / Name : 203 / 11 KV BHOSE GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2743	.2743	.3601	.3086
2		.2896	.2743	.3944	.3086
3		.3353	.3353	.381	.3429
4		.442	.3963	.463	.463
5		.503	.4725	.4268	.5487
6		.5487	.5944	.5182	.6344
7		.5335	.5335	.4725	.6173
8		.4877	.4725	.3963	.583
9	.3963	.4115	.381	.381	.4268
10	.3048	.3201	.3048	.3086	.2896
11	.2439	.1981	.2439	.2572	.2439
12	.1829	.1981	.2134	.2229	.1981
13	.1981	.1829	.1677	.2401	.1829
14	.1981	.1829	.1372	.2229	.1829
15	.2439	.1981	.2058	.2229	.1677
16	.2439	.2134	.2401	.2572	.1524
17	.2896	.3353	.2591	.2172	
18	.381	.4268	.381	.4801	.4268
19	.503	.4877	.4725	.5144	.442
20	.4115	.4268	.4115	.463	.442
21	.3658	.3506	.3201	.4287	.3658
22	.3048	.3048	.2896	.4115	.3201
23	.2743	.2591	.2743	.3429	.3258
24		.2743	.2591	.3086	.3086
Max	**.503**	**.5487**	**.5944**	**.5182**	**.6344**
Min	**.1829**	**.1829**	**.1372**	**.2172**	**.1524**
Avg	**.3028**	**.3410**	**.3298**	**.3621**	**.3601**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274120 / 33/11 KV BHOSE
Feeder No / Name : 204 / 11 KV Sol Patti Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2134	.1981	1.1126	1.5432
2		.2134	.2134	1.1431	1.5432
3		.2286	.2134	1.3375	1.5775
4		.2743	.2286	1.2193	1.6118
5		.3048	.2286	1.4232	1.6804
6		.3201	.3353	1.3413	1.7318
7		.3048	.3048	1.4937	2.1948
8		.2896	.3048	1.8138	2.692
9	.2591	.2286	.2286	2.0576	2.1186
10	.2286	.2896	.2591	.3086	.2896
11	2.0576	1.9814	1.7375	.2743	.1677
12	2.0881	2.1338	2.1186	.2401	.1829
13	2.2862	2.1795	2.1491	.2229	
14	2.3929	2.21	2.21	.2058	
15	.2134	2.2862	2.3834	.1886	
16	2.1338	***		.2058	
17	2.0424	2.1643	2.1186	.2058	
18	2.0424	1.9662	2.0576		
19	.2896	.3048		.2915	
20	.2591	.2743	.1677	.3429	
21	.2286	.2439	.2591	.3086	
22	.2134	.2439	.2572	.2915	
23	.1981	.1981	.2229	.2572	
24		.2134	.1981	1.2174	1.4746
Max	**2.3929**	**23.4568**	**2.3834**	**2.0576**	**2.692**
Min	**.1981**	**.1981**	**.1677**	**.1886**	**.1677**
Avg	**1.1289**	**1.7718**	**.8361**	**.7610**	**1.4468**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274120 / 33/11 KV BHOSE
Feeder No / Name : 205 / 11 KV Nematwadi Feeder SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0914		.8745	.8573
2		.1067		.8383	.8916
3		.1219	.1219	.884	.9602
4		.1372		.9297	1.0288
5		.1372		1.1317	1.1317
6		.1524		.9755	1.2003
7		.1829	.1677	1.2346	1.5775
8		.1829	.1524	1.387	1.7318
9	.1219	.1372	.1677	1.4022	1.4022
10	.1067	.1677	.1677	.1543	.1219
11	1.326	1.326	1.6975	.12	.0762
12	1.5242	1.6004	1.7071	.1029	.1829
13	1.6461	1.6461	1.9547	.1029	.1219
14	1.6766	1.6766	1.989	.12	.061
15	1.7071	1.6156	1.7375	.12	.0762
16	1.6461	1.5546	1.6918	.12	.0914
17	1.6004	1.5546	1.6918	.1372	.1524
18	1.5394	1.5699	1.6156	.2058	.1829
19	.1677	.1677	.1524	.2229	.1829
20	.1524	.1524	.1219	.2401	.1677
21	.1219	.1372	.12	.2058	.1524
22	.1067	.1219	.12	.1715	.1372
23		.1219	.1307	.1543	.1219
24		.0914	.1219	.7316	.8573
Max	**1.7071**	**1.6766**	**1.989**	**1.4022**	**1.7318**
Min	**.1067**	**.0914**	**.12**	**.1029**	**.061**
Avg	**.9602**	**.6147**	**.8226**	**.5236**	**.5612**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274139 / 33/ 11 Kv Shankargaon
Feeder No / Name : 202 / 11 Kv AMBE CHINCHOLI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1271	1.2209	.8648	.9221
2		1.1469	1.2209	.9326	.9221
3		1.2239	1.2717	.9326	.9389
4		1.3077	1.2717	.9326	.9724
5		1.326	1.3735	1.0174	.9945
6		1.4754	1.4922	1.0174	1.2574
7		1.5592	1.7101	1.0682	1.3226
8		1.6057	1.7604	1.2209	1.3226
9		1.8442	1.7295	1.2717	1.3245
10	.381	.3239	.4572	.4001	.5144
11	1.4586	1.3565	1.6956		1.9227
12	1.4586	1.5261	1.7295	1.9334	1.9826
13	1.4746	1.6108	1.7295	1.989	2.1792
14	1.643	1.6787	1.7604	2.0287	2.2996
15	1.6057	1.6617	1.7604	2.1125	2.3158
16	1.5729	1.6617	1.7604	2.1216	2.3266
17	1.6078	1.6787	1.7295	2.1628	2.2672
18	1.5927	1.6787	1.7295		2.2939
19	.381	.4001	.4572	.381	.5525
20	.4191	.4572	.5144	.4191	.5144
21	.4382	.4572	.5144	.4191	.4954
22	.4191	.381	.4572	.4382	.4572
23	.4001	.4001	.3429	.4382	.381
24		1.1401	1.2209	.8648	.8951
Max	**1.643**	**1.8442**	**1.7604**	**2.1628**	**2.3266**
Min	**.381**	**.3239**	**.3429**	**.381**	**.381**
Avg	**1.0609**	**1.2095**	**1.2879**	**1.1349**	**1.3073**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274148 / 33/11 Kv Puluj
Feeder No / Name : 201 / 11 Kv Kalamal **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1		1.2003	
2		1.3375	
3		1.4575	
4		1.6289	
5		1.7147	
6		1.8519	
7		1.9719	
8		2.1434	
9		2.3663	2.3205
10	.2743		.2347
11	1.3717		.2683
12	1.5089		.3018
13	1.6804		.3353
14	2.0233		.3018
15	3.9438		.3353
16	2.3834		.3018
17	2.572		.3353
18	2.572		.3688
19	.3086		.3018
20	.2743		
21	.3086		.3353
22	.3086		.3688
23	.2401		.3353
24		1.1145	1.1603
Max	**3.9438**	**2.3663**	**2.3205**
Min	**.2401**	**1.1145**	**.2347**
Avg	**1.4121**	**1.6787**	**.5070**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274148 / 33/11 Kv Puluj
Feeder No / Name : 202 / 11 Kv Fulchincholi SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.1372	
2		.1715	
3		.1715	
4		.1715	
5		.1715	
6		.2058	
7		.2058	
8		.2058	
9		.2058	.1905
10	.1715		.1677
11	.1372		1.0288
12	.1715		1.2003
13	.1715		1.3717
14	.2058		1.4575
15	.2058		1.5432
16	.2058		1.8004
17	.2058		1.9719
18	.2058		2.1434
19	.1715		.1677
20	.1715		.2012
21	.1715		.1677
22	.1715		.1677
23	.1372		.2012
24		.1372	.1905
Max	**.2058**	**.2058**	**2.1434**
Min	**.1372**	**.1372**	**.1677**
Avg	**.1789**	**.1784**	**.8732**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274148 / 33/11 Kv Puluj
Feeder No / Name : 203 / 11 Kv Puluj Gaothan **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.4458	
2		.4287	
3		.4287	
4		.4287	
5		.0857	
6		.4458	
7		.4801	
8		.4801	
9		.5144	.4641
10	.4801		.463
11	.463		.4458
12	.4458		.4287
13	.4287		.4458
14	.4287		.4115
15	.4287		.3772
16	.4458		.3429
17	.463		.4115
18	.4801		.4458
19	.463		.3772
20	.4801		.463
21	.4973		.4458
22	.4973		.4115
23	.4801		.4287
24		.4458	.4144
Max	**.4973**	**.5144**	**.4641**
Min	**.4287**	**.0857**	**.3429**
Avg	**.4630**	**.4184**	**.4236**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274148 / 33/11 Kv Puluj
Feeder No / Name : 204 / 11 kv PULUJ **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1		1.1145	
2		1.2003	
3		1.3375	
4		1.4575	
5		1.5432	
6		1.6804	
7		1.8004	
8		1.9719	
9		2.1434	2.1548
10	.0857		.0838
11	1.3375		.1029
12	1.4575		
13	1.6289		
14	1.7147		.1006
15	1.9719		.1006
16	2.0576		.1341
17	2.2291		.1006
18	2.4006		.0838
19	.1372		.1006
20	.1372		.1006
21	.1372		.1006
22	.1029		.1006
23	.1029		.1006
24		1.0288	.9945
Max	**2.4006**	**2.1434**	**2.1548**
Min	**.0857**	**1.0288**	**.0838**
Avg	**1.1072**	**1.5278**	**.3113**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274148 / 33/11 Kv Puluj
Feeder No / Name : 205 / 11 KV VITE **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.1372	
2		.1372	
3		.1715	
4		.1715	
5		.1715	
10	.1372		.2012
11	.1372		.1029
12	.1372		1.166
13	.1372		1.2003
14	.1372		1.3717
15	.1715		1.6289
16	.1715		1.8861
17	.1715		1.9719
18	.2058		2.1434
19	.1715		.1677
20	.1715		.2347
21	.1715		.2012
22	.1715		.2347
23	.1372		.1677
24		.1372	.1905
Max	**.2058**	**.1715**	**2.1434**
Min	**.1372**	**.1372**	**.1029**
Avg	**.1593**	**.1544**	**.8579**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274164 / 33/11 KV Nandure
Feeder No / Name : 201 / 11 kv Nanure Gaothan **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2218	.1848	.197	.2033
2		.2218	.1848	.2149	.2033
3		.2218	.1848	.2507	.2218
4		.2218	.2957	.2865	.2218
5		.2218	.3326	.3224	.2033
6		.3326	.3326	.3224	.2957
7		.3142	.4066	.3045	.2957
8		.3511	.3696		.3142
9		.3326	.2587	.2686	.2772
10	.2587	.2033	.2218	.197	.2033
11	.2218	.2033	.1791	.1612	.1433
12	.2033	.1848	.1075	.1791	.1075
13	.1848	.1848	.1075	.1791	.1075
14	.1663	.2033	.1075	.1791	
15	.1663	.2218	.1075	.197	.1075
16	.1848	.2587	.1433	.2149	.1433
17	.2957	.2957	.1791	.2149	.197
18	.3142	.4251	.2328	.2507	
19	.3511	.4066	.2865	.2865	.2507
20	.3696	.4066	.2686	.2865	.2865
21	.3326	.3326	.2149	.2507	.3224
22	.2957	.2957	.1791	.2149	.3224
23	.2218	.2218	.1791	.2149	.2507
24		.2218	.1848	.1791	.2033
Max	**.3696**	**.4251**	**.4066**	**.3224**	**.3224**
Min	**.1663**	**.1848**	**.1075**	**.1612**	**.1075**
Avg	**.2548**	**.2711**	**.2187**	**.2336**	**.2219**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274164 / 33/11 KV Nandure
Feeder No / Name : 202 / 11 KV Pehe **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1989	.1638	1.9062	1.8067
2		.1823	.1638	1.9062	1.8564
3		.1823	.1638	1.9227	1.8564
4		.1823	.1638	1.9559	1.9725
5		.1823	.1638	1.9393	2.0885
6		.1989	.1638	2.0553	2.1382
7		.1989	.1638	2.2211	2.1382
8		.1989	.1802	2.2708	2.1879
9		.1492	.1802	2.2542	2.1714
10	.1658	.1326	.1638	.116	.1326
11	2.4863	2.3594	2.0809	.0829	
12	2.5857	2.3594	2.2775	.0995	.0829
13		2.2119	2.3102	.116	.0829
14	2.5526	2.2119	2.3758	.0995	
15	2.5857	2.2119	2.4086	.116	.0829
16	2.4531	2.2119	2.3266	.1326	.1492
17	2.4697	2.2939	2.3102	.1326	.0829
18	2.3868	2.3102	2.0317	.1326	
19	.1492	.1475	.1638	.1492	.0995
20	.1658	.1638	.2294	.1658	.1492
21	.1989	.1638	.1966	.1658	.1658
22	.2155	.1638	.1475	.1823	.1658
23	.1989	.1638	.1475	.1492	.1658
24		.1989	.1638	1.9227	1.6409
Max	**2.5857**	**2.3594**	**2.4086**	**2.2708**	**2.1879**
Min	**.1492**	**.1326**	**.1475**	**.0829**	**.0829**
Avg	**1.4318**	**.8741**	**.8684**	**.9248**	**1.0103**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274164 / 33/11 KV Nandure
Feeder No / Name : 203 / 11 KV Ave SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5655	1.5181	.1739	.2056
2		1.5497	1.5181	.1739	.2056
3		1.5813	1.5181	.1898	.1898
4		1.5813	1.5181	.2056	.1739
5		1.7078	1.5497	.2056	.1898
6		1.7711	1.5497	.2372	.1898
7		1.8027	1.5497	.2056	.2056
8		1.8185	1.5813	.1581	.1898
9		1.8027	1.6129	.1423	.1265
10	.1265	.1423	.1423	.1265	.1107
11	.1265	.1265	.1265	1.7236	1.8027
12	.1107	.1265	.0791	1.7553	1.9766
13	.1107	.1265	.0791	1.7394	1.945
14	.0949	.1107	.0791	1.7711	1.9292
15	.1107	.1107	.0791	1.7553	2.0241
16	.1265	.1423	.1265	1.7394	1.9925
17	.1265	.1423	.1423	1.7394	2.0083
18	.1265	.1581	.1423	1.7394	1.9608
19	.1423	.1739	.1581	.1739	.1739
20	.1581	.1739	.1739	.2214	.1898
21	.2214	.1739	.1739	.2056	.1739
22	.1898	.1739	.1581	.2056	.1898
23	.1581	.1739	.1581	.2056	.2056
24		1.5023	1.5181	.1581	.2056
Max	**.2214**	**1.8185**	**1.6129**	**1.7711**	**2.0241**
Min	**.0949**	**.1107**	**.0791**	**.1265**	**.1107**
Avg	**.1378**	**.7808**	**.7188**	**.7063**	**.7735**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274174 / 33/11 KV Shevate Sub Station
Feeder No / Name : 201 / 11 KV Shevate Gaothan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0762	.0953	.0857	.1067
2		.0914	.0762	.0857	.1219
3		.0914	.0953	.0857	.1067
4		.0914	.1143	.0857	.1067
5		.0914	.1334	.0857	.1067
6		.1067	.1715	.1715	.1524
7		.1219	.1524	.2058	.1829
8		.1524	.1715	.3086	.2286
9		.1715	.2058	.3201	.1715
10	.1829	.1905	.2915	.3048	.2743
11	.1829	.2667	.3258	.2591	.4115
12	.1219	.1905	.2572	.2286	.3601
13	.0914	.1143	.1886	.2439	.3258
14	.1372	.2286	.1886	.1829	.2058
15	.1524	.1905	.1715	.2286	.1715
16	.1219	.1715	.2229	.2743	.2058
17	.1067	.1334	.2058	.3048	.2058
18	.1219	.1524	.2572	.2134	.1886
19	.1219	.1715	.1886	.1981	.2058
20	.1372	.1905	.1715	.1524	.2058
21	.1219	.0953	.1372	.1067	.1715
22	.0914	.1143	.1372	.1067	.1715
23	.0762	.0953	.12	.1067	.1715
24		.0762	.1143	.1029	.1067
Max	**.1829**	**.2667**	**.3258**	**.3201**	**.4115**
Min	**.0762**	**.0762**	**.0762**	**.0857**	**.1067**
Avg	**.1263**	**.1407**	**.1747**	**.1854**	**.1944**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274174 / 33/11 KV Shevate Sub Station
Feeder No / Name : 202 / 11 KV Shevate AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2286	.2096	1.6842	1.5546
2		.2286	.1905	1.6842	1.5851
3		.2439	.2096	1.6842	1.6004
4		.2439	.2286	1.749	1.6004
5		.2439	.2667	1.7814	1.6461
6		.2591	.3239	1.9109	1.7528
7		.2743	.362	2.3644	2.1338
8		.3048	.3429	2.4291	2.332
9		.3239	.3429	2.3167	2.2253
10	.3048	.2477	.2401	.1067	.1524
11	2.2405	2.572	2.2024	.1219	.1219
12	2.4387	2.6673	2.7206	.1067	.1067
13	2.4691	2.915	2.672	.1067	.1067
14	2.4387	2.934	2.5911	.1067	.0762
15	2.4539	2.8578	2.5587	.0914	.0762
16	2.4387	2.7625	2.4939	.1067	.1219
17	2.4082	2.7054	2.4939	.1067	.1829
18	2.3167	2.8387	2.0405	.1677	.3048
19	.2134	.3048	.3429	.2134	.2743
20	.2286	.3239	.3086	.2286	
21	.2134	.2858	.2743	.2286	.2591
22	.2134	.2667	.2572	.2134	.2134
23	.2134	.2858	.2401	.2286	.2134
24		.2286	.2286	1.7661	1.5546
Max	**2.4691**	**2.934**	**2.7206**	**2.4291**	**2.332**
Min	**.2134**	**.2286**	**.1905**	**.0914**	**.0762**
Avg	**1.4708**	**1.1061**	**1.0059**	**.896**	**.8780**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274174 / 33/11 KV Shevate Sub Station
Feeder No / Name : 203 / Ulabhagat Mala SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8383	1.105	.2572	.2439
2		.8383	1.1812	.2572	.2439
3		.884	1.2955	.2572	.2286
4		.884	1.4098	.2743	.2439
5		.9145	1.5051	.2915	.2591
6		1.3565	1.7147	.3601	.3353
7		1.5699	2.0005	.4287	.3506
8		2.0957	2.5339	.463	.381
9		2.1719	1.1498	.3963	.2896
10	.1829	.2286	.2058	.3353	.2591
11	.1829	.2667	.1886	1.1584	1.6156
12	.1677	.2286	.1715	1.448	2.1338
13	.1524	.2096	.1543	1.5851	2.0729
14	.1524	.1905	.1543	1.6918	2.1033
15	.1524	.2096	.1715	1.4937	2.1491
16	.1829	.2286	.2229	1.5546	2.1338
17	.1981	.2667	.2229	1.6004	2.1033
18	.2286	.3429	.2058	1.6309	2.0424
19	.2591	.3239	.3429	.2134	.2134
20	.2743	.3048	.3429	.2134	.1981
21	.2286	.2667	.3258	.2286	.2286
22	.2134	.2286	.3086	.2134	.2134
23	.1524	.2096	.2572	.2134	.2134
24		.8078	1.0288	.2572	.2286
Max	**.2743**	**2.1719**	**2.5339**	**1.6918**	**2.1491**
Min	**.1524**	**.1905**	**.1543**	**.2134**	**.1981**
Avg	**.1949**	**.6611**	**.7583**	**.7010**	**.8535**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274174 / 33/11 KV Shevate Sub Station
Feeder No / Name : 204 / CHOUFULA FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0669	1.3717	.1715	.2134
2		1.0974	1.7147	.1715	.2134
3		1.1431	1.9243	.1715	.1981
4		1.2193	2.0005	.1715	.1981
5		1.2955	2.0576	.1715	.1829
6		1.6004	2.191	.1886	.1829
7		1.7985	2.2862	.2401	.1829
8		2.2862	2.4577	.2401	.1524
9		2.3624	1.749	.2286	.1677
10	.1829	.0953	.2401	.2134	.1524
11	.2134	.0762	.1029	1.768	2.1033
12	.2134	.0953	.1029	1.9662	2.1643
13	.1981	.0762	.1029	2.0576	.7621
14	.2134	.0953	.1029	2.21	2.3167
15	.2286	.1143	.1029	2.2405	2.4691
16	.2134	.1334	.1029	2.271	2.3472
17	.2286	.1143	.12	2.2862	2.3167
18	.2134	.1334	.1543	2.0576	2.1643
19	.2134	.2286	.2058	.1981	.1524
20	.2134	.2096	.2229	.1981	.1524
21	.1981	.1905	.2229	.2134	.1829
22	.1981	.2096	.2058	.2134	.1524
23	.1829		.1886	.2134	.1677
24		1.0517	1.1431	.1715	.2286
Max	**.2286**	**2.3624**	**2.4577**	**2.2862**	**2.4691**
Min	**.1829**	**.0762**	**.1029**	**.1715**	**.1524**
Avg	**.2079**	**.7258**	**.8781**	**.8347**	**.8135**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274181 / 33/11 KV BABHULGAON SUBSTATION
Feeder No / Name : 201 / 11 KV BABHULGAON GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3353	.3018	.285
2	.3353	.3856	.3521	.3688
3	.3688	.4191	.3856	.4024
4	.4191	.4862	.4359	.4694
5	.4862	.503	.4862	.5197
6	.5365	.4359	.5197	.5868
7	.4191	.4191	.5197	.5533
8	.4191	.3521	.4694	.4024
9	.3521	.3688	.4359	.4694
10	.4191	.3688	.3856	.3856
11	.3521	.3688		.3521
12	.285	.3353		.2683
13	.2515	.285		.285
14	.2347	.2012		.2515
15	.1677	.2012	.2347	.218
16	.2012	.2515	.3185	.218
17	.2683	.2683	.3018	.2515
18	.4024	.3856	.4191	.3856
19	.5197	.5197	.57	.5365
20	.6371	.5365	.5533	.503
21	.4359	.4527	.503	.4359
22	.3521	.3521	.3856	.3856
23	.3185	.3018	.3353	.3353
24	.285	.3018	.285	.3018
Max	**.6371**	**.5365**	**.57**	**.5868**
Min	**.1677**	**.2012**	**.2347**	**.218**
Avg	**.3653**	**.3681**	**.4099**	**.3821**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274181 / 33/11 KV BABHULGAON SUBSTATION
Feeder No / Name : 202 / BABHULGAON AG Feeder KV- 11 / OUTGOING **SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER**

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.6706	.061	.061
2	.7164	.6249	.0762	.061
3	.7926	.7164	.0762	.0762
4	.8383	.823	.0914	.0914
5	.945	.945	.0914	.1067
6	1.0212	1.0669	.1067	.0937
7	1.2803	1.2651	.1067	.1094
8	1.4632	1.387	.0762	.0781
9	1.4937	1.3413	.061	.0625
10	.0305	.0457	.0457	.0469
11	.0305	.0914		1.4998
12	.0305	.0762		1.7966
13	.0305	.0305		1.906
14	.0305	.0762		1.8278
15	.0305	.0305	1.5699	1.7654
16	.0305	.0305	1.6918	1.7185
17	.1219		1.768	1.7071
18		.0457	1.6309	1.6309
19	.061	.0762	.0762	.0762
20	.061	.0762	.0762	.0762
21	.061	.0762	.0762	.0762
22	.0457	.061	.0762	.0762
23	.0305	.061	.0762	.0762
24	.6097	.6401	.061	.0762
Max	**1.4937**	**1.387**	**1.768**	**1.906**
Min	**.0305**	**.0305**	**.0457**	**.0469**
Avg	**.4520**	**.4460**	**.3948**	**.6290**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274181 / 33/11 KV BABHULGAON SUBSTATION
Feeder No / Name : 203 / 11 KV ROPALE Feeder KV- 11 / OUTGOING
SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.064	.064	1.5684	1.3763
2	.064	.064	1.6644	1.4083
3	.096	.08	1.6644	1.4563
4	.096	.096	1.6964	1.4883
5	.128	.128	1.7284	1.5684
6	.128	.128	1.7924	1.5364
7	.128	.112	2.1765	1.9204
8	.064	.08	2.3045	2.1765
9	.064	.064	2.3045	2.2405
10	.08	.08	.064	.064
11	2.7526	2.3685		.064
12	3.1367			.0625
13	3.0727	2.6886		.064
14	3.0087	2.8166		.064
15	3.0087	2.7526	.064	.064
16	2.7526	2.7526	.064	.064
17	2.9447	2.7526	.064	.064
18	2.6886	2.7526	.064	.064
19	.064	.064	.064	.064
20	.08	.064	.064	.064
21	.064	.064	.064	.064
22	.064	.064	.064	.064
23	.064	.064	.064	.064
24	.064	.064	1.6324	1.4083
Max	**3.1367**	**2.8166**	**2.3045**	**2.2405**
Min	**.064**	**.064**	**.064**	**.0625**
Avg	**1.0282**	**.8767**	**.9586**	**.7281**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274182 / 33/11 KV SUSTE SUBSTATION
Feeder No / Name : 201 / 11KV SHINGARE/CHAWAN WASTI FE Feeder KV- 11 / OUTGOING SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1581	.5937	
2			.1562	.6249	
3			.1581	.6249	.6249
4			.1581	.703	
5			.1562	.7811	
6			.1562	.8592	
7			.2056	1.0155	.7621
8			.2372	1.0311	1.0822
9		.1715	.1562	1.1248	1.1431
10		.1423	.125		.125
11		.9488	1.0467		.0781
12		1.0936	1.2186		.125
13		1.1248	1.1561	.1372	.125
14		1.1561	1.1717		.1406
15		1.1717	1.1405		.1406
16		1.1717	1.2186	.12	.1562
17		1.1873	1.2186		.1562
18		1.2029	1.1717		.1562
19		.1265	.2031		.1875
20		.1581	.1875		.1875
21		.1581	.1718	.2229	.1875
22		.1423	.1406		.1562
23	.1886	.1265	.1094	.2058	.125
24		.1715	.1423	.578	
Max	**.1886**	**1.2029**	**1.2186**	**1.1248**	**1.1431**
Min	**.1886**	**.1265**	**.1094**	**.12**	**.0781**
Avg	**.1886**	**.6409**	**.4985**	**.6159**	**.3144**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274182 / 33/11 KV SUSTE SUBSTATION
Feeder No / Name : 202 / 11KV WATAR WAT FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.463	.1337	.1715
2			.463	.1486	
3		.5335	.463	.1486	
4			.463	.1783	
5			.463	.208	
6			.7407	.2229	
7		.5792	.787	.2378	.2572
8		.7926	.8025	.2526	.1886
9		.7926		.208	.1543
10		.0926	.1189		.1372
11		.1543			.7621
12		.1543			.884
13		.1852			.884
14		.1543			.884
15		.1543		.7773	.8688
16		.1543	.1486	.8078	.884
17		.1698	.1635		.7926
18		.1852	.2229	.7468	.7926
19		.2006	.2526		.1219
20		.216	.208		.1677
21		.1852	.1932	.2058	.1981
22		.1389	.1635		.1981
23	.2058	.1235	.1337	.1715	.1677
24		.2896	.4321	.1337	.1886
Max	**.2058**	**.7926**	**.8025**	**.8078**	**.884**
Min	**.2058**	**.0926**	**.1189**	**.1337**	**.1219**
Avg	**.2058**	**.2766**	**.3712**	**.3054**	**.4581**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
PANDHARPUR R-II S/DN[715] BU 4715
Substation No/ Name :- 274182 / 33/11 KV SUSTE SUBSTATION
Feeder No / Name : 203 / 11KV SUSTE RIVER SIDE FEEDER Feeder KV- 11 / OUTGOING SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0324	.9145	.5792
2			.0324	.9145	
3			.0324	.9145	
4			.0324	.945	
5			.0324	.9907	
6			.0324	1.0212	
7		.0343		1.0364	.7011
8			.0324	1.0364	.823
9		.0171	.0305	1.0669	.8535
10		.0162	.0305		.0316
11		1.2308	1.1888		.0158
12		1.3603	1.2498		.0316
13		1.3443	1.2651	.0171	.0316
14		1.3603	1.2803		.0312
15		1.3603	1.2651		.0316
16		1.3603	1.2193	.0171	.0316
17		1.3603	1.1736		.0316
18		1.3123	1.1584		.0316
19		.016	.0305		.0316
20		.032	.0305		.0305
21		.032	.0305	.0171	.0316
22		.032	.0305		.0316
23	.0171	.032	.0305	.0171	.0316
24		.0171	.0324	.9145	.4725
Max	**.0171**	**1.3603**	**1.2803**	**1.0669**	**.8535**
Min	**.0171**	**.016**	**.0305**	**.0171**	**.0158**
Avg	**.0171**	**.6422**	**.4467**	**.7016**	**.2029**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274059 / 33/11 KV ACHAKDANI SUBSTATION
Feeder No / Name : 241 / 11 KV IAKSHMINAGAR FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	19-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524				
2	.1524	.0762	.0762		
3	.1524	.0762	.0762		
4	.1524	.0762	.0762		
5		.0762	.0762		
6	.1524	.0762			
10				.1619	
11				.1619	
12				.1619	
13			1.2193		
14			1.448		
15			1.829		
16			1.3889		
17			1.5242		
18			1.829		
19	1.0669	1.5242	.0762		.1619
20	.9907	.0762	.0762		.1619
21	1.0669	.0762	.0762		.1619
22	1.2193	.0762	.0762		.1619
23		.0762	.0762		.1619
24	1.2193	.0762	.0762		
Max	**1.2193**	**1.5242**	**1.829**	**.1619**	**.1619**
Min	**.1524**	**.0762**	**.0762**	**.1619**	**.1619**
Avg	**.6325**	**.2078**	**.6250**	**.1619**	**.1619**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274059 / 33/11 KV ACHAKDANI SUBSTATION
Feeder No / Name : 242 / 11 KV Thombarewadi feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17
HR	Load (MW)	Load (MW)
1	.2286	.1524
2	.2286	.0762
3	.1524	.0762
4	.1524	.0762
5	.1524	.0762
6	.1524	.0762
7		1.0669
8		1.1431
9		1.829
10		1.9052
11		1.829
12		1.6766
19		.0762
24	.0762	.0762
Max	**.2286**	**1.9052**
Min	**.0762**	**.0762**
Avg	**.1633**	**.7240**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274059 / 33/11 KV ACHAKDANI SUBSTATION
Feeder No / Name : 244 / 11 KV Khavaspur feeder Feeder KV- 11 / OUTGOING **SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER**

DATE	16-DEC-17
HR	Load (MW)
1	1.9814
2	.7621
3	.9145
4	1.829
5	1.9052
6	1.829
24	.9907
Max	**1.9814**
Min	**.7621**
Avg	**1.4588**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274061 / 33/11 KV Geradi
Feeder No / Name : 241 / 11 KV Gherdi feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.7316	.7621	
2	1.2346	.9907	1.0669	
3	1.3717	1.0212	1.3717	
4	1.5394	1.1584	1.5242	
5	1.6766	1.3565	1.6004	
6	1.7985	1.5394	1.829	
7	1.829	1.7071		.1372
8		1.448		
9	1.5394	1.6766		.2286
10	.1372	.1524		.1524
11	.1372	.1219		1.5242
12	.1524	.1219		1.2498
13	.1219	.1219		
14	.1372	.1372		1.768
15	.1372	.1372		1.7985
16	.1524	.1372	.1372	1.768
17	.1524	.1524		1.1431
18	.2134	.1981	.1677	1.0059
19	.2591	.1981		.2743
20	.2439	.2439		.2591
21	.2286	.2134		.2286
22	.2134	.2134		.2134
23	.2134	.2134	.1677	.2134
24	.4268	.442	.5182	.1677
Max	**1.829**	**1.7071**	**1.829**	**1.7985**
Min	**.1219**	**.1219**	**.1372**	**.1372**
Avg	**.6382**	**.6014**	**.9145**	**.7583**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274061 / 33/11 KV Geradi
Feeder No / Name : 242 / 11 KV Pare SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3201	.3506	.5335	
2	.381	.381	.6097	
3	.381	.381	.7621	
4	.4572	.442	.8383	
5	.4572	.7164	.9145	
6	.6097	.7926	.9907	
7	.7621	.8535	1.0669	.0914
8	.9755	1.0669	1.1431	
9	.945	.6706		.1067
10	.1372	.1524		.1219
11	.1219	.1067		1.0669
12	.1067	.0914		1.2498
13	.1067	.1067		1.1584
14	.0914	.1067		1.2041
15	.0914	.0914		1.2346
16	.0914	.0914	.0762	1.1584
17	.1219	.1219		1.2193
18	.1677	.1372	.1067	.8993
19	.1677	.1524		.1829
20	.1524	.1372		.1524
21	.1219	.1219		.1372
22	.1219	.1219		.1219
23	.1067	.1067	.1372	.1067
24	.3353	.3353	.3963	.1067
Max	**.9755**	**1.0669**	**1.1431**	**1.2498**
Min	**.0914**	**.0914**	**.0762**	**.0914**
Avg	**.3055**	**.3182**	**.6313**	**.6070**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274061 / 33/11 KV Geradi
Feeder No / Name : 243 / 11 KV Hangirge feeder SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.2134	.2134	
2	.1829	.2134	.2134	
3	.1829	.2134	.2134	
4	.1829	.2439	.2439	
5	.1829	.2439	.2439	
6	.2134	.2743	.2439	
7	.2286	.3048	.2743	2.1186
8	.2134	.2591	.3048	
9	.2134	.1829		2.0271
10	.1829	.1829		.1829
11	1.6918	2.0576		.1524
12	1.9814	2.1338		.1219
13	2.1033	2.1033		.1219
14	2.0424	2.0576		.1219
15	2.0119	1.9814		.1219
16	2.0576	2.1643	1.9814	.1524
17	2.1643	1.6004		.1372
18	.7164	1.6004	1.6309	.2134
19	.2743	.2743		.2896
20	.2591	.2591		.2591
21	.2286	.2286		.2439
22	.2134	.2134		.2134
23	.2134		.1981	.2134
24	.1981	.2134	.2134	.442
Max	**2.1643**	**2.1643**	**1.9814**	**2.1186**
Min	**.1829**	**.1829**	**.1981**	**.1219**
Avg	**.7551**	**.8356**	**.4979**	**.4196**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274061 / 33/11 KV Geradi
Feeder No / Name : 244 / Gaothan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2439	.2439	
2	.2134	.2439	.2439	
3	.2134	.2439	.2439	
4	.2134		.2439	
5	.2743		.3048	
6	.3963		.4268	
7	.4572	.4268	.4572	.3353
8	.4877	.4268	.3048	
9	.4572	.2743		.4268
10	.3048	.2439		.3353
11	.2743	.2439		.2439
12	.2134	.2439		.2134
13	.2134	.2134		.2134
14	.1981	.2134		.1829
15	.1829	.1829		.1829
16	.1829	.1829	.2439	.2439
17	.2439			.2439
18	.3353	.4268	.3963	.3963
19	.5182	.5182		.5335
20	.4877	.4877		.4572
21	.4268	.4268		.3963
22	.3048	.3048		.3048
23	.2743	.2743	.3048	.2743
24	.2134	.2439	.2439	.2439
Max	**.5182**	**.5182**	**.4572**	**.5335**
Min	**.1829**	**.1829**	**.2439**	**.1829**
Avg	**.3048**	**.3033**	**.3048**	**.3075**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274063 / 33/11 KV KOLA SUBSTATION
Feeder No / Name : 242 / 11 KV Gaudwadi feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6154	.6154	.5668	.2343
2	.6154	.6478	.5668	.2656
3	.6478	.6802	.7287	.2968
4	.6802	.7773	.8097	.2656
5	.7773	1.0364	.8907	.3125
6	1.0364	1.1336	1.1012	.3281
7	1.4089	1.3927	1.3765	.3281
8	1.3748	1.8138	1.7166	.3125
9	1.406	1.749	1.587	.1406
10	.2343	.2105	.1943	.1406
11		.2267	.1457	1.406
12	.1943	.1619	.1457	1.7497
13	.2343	.3077	.1781	1.4842
14	.2031	.1619	.1943	1.7497
15	.2187	.1943	.1943	1.8591
16	.2031	.2591		1.531
17	.2187	.2429		1.531
18	.3281	.2267		
19	.2968	.2915	.2915	.2812
20	.3125	.2915	.2968	.2915
21	.2656	.3077	.2812	.2591
22	.2343	.2591	.2343	.3077
23	.2187	.2267	.1875	.2915
24	.6478	.4858	.5668	.2343
Max	**1.4089**	**1.8138**	**1.7166**	**1.8591**
Min	**.1943**	**.1619**	**.1457**	**.1406**
Avg	**.5379**	**.5708**	**.5835**	**.6783**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274063 / 33/11 KV KOLA SUBSTATION
Feeder No / Name : 243 / 11 KV Junoni feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.583	.7125	.6478	.2591
2	.5992	.8097	.7287	.2267
3	.5992	.9069	.8097	.2753
4	.6478	1.004	.9393	.3077
5	.7125	1.1012	1.1012	.2753
6	1.1336	1.0688	1.2631	.2915
7	1.6032	1.1984	1.6842	.3239
8	1.3592	1.6194	1.7328	.2753
9	1.406	1.3279	1.6518	.2105
10	.25	.1134	.1457	.1619
11		.1134	.1134	1.7652
12	.2031	.1457	.1134	1.8623
13	.1094	.0972	.1781	1.8623
14		.1457	.1781	1.7328
15		.1781	.1619	
16	.1406	.1296		1.9109
17	.1562	.1296		1.8623
18	.2187	.1619		1.3927
19	.25	.2591	.2915	.3239
20	.25	.2429	.2812	.2753
21	.2031	.2267	.2656	.2753
22	.2187	.1943	.2187	.2267
23	.2343	.1781	.2031	.2591
24	.6154	.4696	.6478	.2591
Max	**1.6032**	**1.6194**	**1.7328**	**1.9109**
Min	**.1094**	**.0972**	**.1134**	**.1619**
Avg	**.5473**	**.5223**	**.6361**	**.7224**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274063 / 33/11 KV KOLA SUBSTATION
Feeder No / Name : 244 / 11 KV Pachegaon feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1781	.2267	.1619	1.0526
2	.1781	.2267	.1619	1.1336
3	.1781	.2429	.1619	1.1336
4	.1781	.2429	.1943	1.2146
5	.1943	.2429	.1943	1.2955
6	.2105	.2429	.1943	1.2955
7	.2105	.2429	.2105	1.3765
8	.1943	.2429	.2105	1.4575
9	.1619	.2429	.1943	1.4575
10	.1619	.2429	.1296	.1619
11		1.0526	.9717	.1619
12	1.0526	1.1336	1.1336	.1296
13	1.0526	1.1336	1.1336	.1296
14	1.1336	1.1336	1.0155	.1296
15	1.0936	1.3765	1.0526	.1296
16	1.2146	1.3765		.1134
17	1.3765	1.4575		.1134
18	1.2955	1.4575		.1296
19	.2267	.1943	.1781	.2105
20	.2267	.1943	.1943	.2105
21	.2267	.1943	.1943	.2105
22	.2267	.1619	.1943	.2105
23	.2267	.1619	.2105	.2105
24	.1781	.2267	.1619	.9717
Max	**1.3765**	**1.4575**	**1.1336**	**1.4575**
Min	**.1619**	**.1619**	**.1296**	**.1134**
Avg	**.4946**	**.5688**	**.3930**	**.6100**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274063 / 33/11 KV KOLA SUBSTATION
Feeder No / Name : 245 / KOLA GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4858	.4687	.4858	.4687
2	.4858	.4687	.4858	.4687
3	.583	.5937	.4858	.4999
4	.6478	.6874		.5624
5	.6478	.7811		.6249
6	.9717	1.0311	1.0364	.6249
7	.6802	.9686	.8097	.7499
8	.4999	.6249	.6802	.6562
9	.3749	.6249	.6478	.5937
10	.4062	.4687	.5182	.5624
11		.4374	.4858	.4999
12	.5624	.4374	.421	.4999
13	.4062	.4062	.421	.3749
14		.3749	.421	.4062
15		.4374	.421	.4687
16	.5312	.4999		.4374
17	.6249	.6249		.4999
18	.8124	.6249		.7186
19	.9374	.9374	1.1336	1.0311
20	.8124	.9061	.9686	1.004
21	.6249	.7811	.8749	.9069
22	.5937	.4999	.6874	.7125
23	.5937	.4687	.5312	.6154
24	.4858	.4687	.4858	.4687
Max	**.9717**	**1.0311**	**1.1336**	**1.0311**
Min	**.3749**	**.3749**	**.421**	**.3749**
Avg	**.6080**	**.6093**	**.6316**	**.6023**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274063 / 33/11 KV KOLA SUBSTATION
Feeder No / Name : 246 / 11 KV KOMBADWADI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1943	.2267	.1619	1.1336
2		.1943	.2267	.1619	1.1336
3		.1943	.2429	.1619	1.2146
4		.1943	.2429	.2105	1.2955
5		.2105	.2429	.2105	1.3765
6		.2429	.2267	.2267	1.3765
7		.2267	.2267	.2267	1.4575
8		.2105	.2267	.2267	1.4575
9		.1619	.2267	.2105	1.5384
10		.1619	.2429	.1619	.1619
11			1.0526	1.2955	.1619
12		1.2146	1.2146	1.4575	.1457
13		1.2146	1.2146	1.4575	.1457
14		1.3765	1.2955	1.3765	.1457
15		1.3765	1.2955	1.3765	.1457
16		1.3765	1.2955		.1296
17		1.5384	1.5384		.1296
18		1.5384	1.587		.1457
19		.2429	.2105	3.4008	.2267
20		.2429	.2105	.2105	.2267
21		.2429	.2105	.2105	.2267
22		.2429	.1943	.2267	.2267
23	.1943	.2429	.1619	.2267	.2267
24		.1943		.1619	.9717
Max	**.1943**	**1.5384**	**1.587**	**3.4008**	**1.5384**
Min	**.1943**	**.1619**	**.1619**	**.1619**	**.1296**
Avg	**.1943**	**.5668**	**.6006**	**.6362**	**.6417**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274063 / 33/11 KV KOLA SUBSTATION
Feeder No / Name : 247 / 11 KV BUDDIHAL FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.247	.8097	.8907	.2267
2	1.247	.9393	.9717	.2267
3	1.2308	1.004	.9717	.2753
4	1.2955	1.0688	1.1012	.2105
5	1.2631	1.2793	1.2631	.1943
6	1.5223	1.3927	1.3765	.2267
7	1.9757	1.587	1.7652	.2429
8	1.6404	1.8947	2.1052	.2105
9	1.6872	1.9271	1.8623	.1943
10	.2031	.1296	.1619	.2105
11		.081	.1134	1.8299
12	.1718	.081	.1457	1.9109
13	.1718	.1781	.2105	2.0243
14	.2187	.1619	.1943	2.332
15	.1875	.2105	.1943	2.3482
16	.2343	.0972		
17	.25	.1134		2.4129
18	.2343	.1457		2.1214
19	.2343	.1943	.2591	.2915
20	.2343	.1781	.2656	.2591
21	.2343	.1781	.2968	.2915
22	.2031	.1781	.25	.3077
23	.2343	.1781	.1562	.2753
24	1.2146	.7287	.8907	.2105
Max	**1.9757**	**1.9271**	**2.1052**	**2.4129**
Min	**.1718**	**.081**	**.1134**	**.1943**
Avg	**.7450**	**.6140**	**.7355**	**.8189**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274065 / 33/11KV SHIRBHAVI S/STN.
Feeder No / Name : 241 / 11 KV Shirbhavi feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2321	.2347	.2515	.7377
2	.2652	.2515	.285	.7712
3	.2984	.2347	.3185	.8383
4	.3315	.2683	.3521	.8383
5	.3647	.3353	.3856	.9054
6	.431	.4191	.4527	.9389
7	.431	.4359	.4527	1.5089
8	.3647	.3688	.3856	2.0957
9	.3149	.285	.2984	1.7269
10	.2321	.2321	.2155	.2591
11	1.3094	1.4586	1.6244	.1619
12	1.7404	1.9725	1.9559	.1296
13	1.8233	1.989	2.0388	.1296
14	1.873	1.21	2.0056	.1134
15	1.8067	1.7901	2.0222	.1326
16	1.8896	1.9725		.1989
17	1.326	2.0454	1.4419	.2321
18	1.3413	.3856	1.7604	.2818
19	.4024	.3856	.4694	.3978
20	.3353	.3521	.4191	.3481
21	.3018	.3018	.3018	.2984
22	.2515	.2515	.2515	.2486
23	.2543	.2347	.2347	.2321
24	.2321	.2347	.2347	.6706
Max	**1.8896**	**2.0454**	**2.0388**	**2.0957**
Min	**.2321**	**.2321**	**.2155**	**.1134**
Avg	**.7564**	**.7354**	**.7895**	**.5915**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274065 / 33/11KV SHIRBHAVI S/STN.
Feeder No / Name : 242 / 11KV Dhyati Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2321	.2347	.3018	.7712
2	.2652	.2347	.2683	.8048
3		.2347	.2347	.8048
4	.3315	.2515	.2347	.8383
5	.3315	.3185	.2683	1.0059
6	.3647	.4024	.3018	1.073
7	.3978	.4359	.3353	1.6766
8	.3647	.3353	.3353	2.0957
9	.3647	.2683	.3149	
10	.2652	.1989	.2321	
11	1.326	1.326	1.6409	
12	.1326	1.6575	1.989	
13	1.6575	1.9062	1.989	.1943
14	1.7404	1.989	1.9559	.1619
15	1.6575	2.1548	2.0553	.1658
16	1.989	2.1548		.1989
17	1.989	2.2131	1.2742	.1989
18	1.6766	1.9616	1.643	.2652
19	.3658	.5197	.4359	.3647
20	.3688	.4694	.4024	.3315
21	.3018	.4359	.3018	.2984
22	.3018	.4024	.2683	.2652
23	.2683	.3688	.2515	.2321
24	.2321	.2347	.3353	.6706
Max	**1.989**	**2.2131**	**2.0553**	**2.0957**
Min	**.1326**	**.1989**	**.2321**	**.1619**
Avg	**.7359**	**.8629**	**.7552**	**.6209**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274065 / 33/11KV SHIRBHAVI S/STN.
Feeder No / Name : 243 / 11 KV Haldahiwadi feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9116	.8383	.7209	.2683
2	.9945	.8718	.8048	.2515
3	1.0774	.9389	.8886	.2683
4	1.1271	1.073	.9724	.285
5	1.1934	1.2071	1.073	.3856
6	1.4586	1.4754		.4694
7	1.9227	2.1795	1.8442	.4694
8	2.1879	2.5149		.3688
9	2.2211		2.42	.3353
10	.1989	.2321	.2321	.1619
11	.1326	.1326	.1658	1.8461
12	.1326	.0995	.0995	2.2996
13	.0995	.0995	.1326	2.17
14	.0995	.0995	.1326	2.332
15	.1326	.1326	.0995	2.5232
16	.0995	.1326		2.2874
17	.1658	.1677	.2012	2.2211
18	.2683	.1677	.3018	2.0553
19	.4359	.4024	.4694	.3978
20	.3688	.4024	.4191	.0332
21	.3018	.4024	.3688	.3315
22	.2683	.3018	.3018	.3315
23	.2683	.3018	.2683	.2984
24	.8288	.7545	.6371	.2683
Max	**2.2211**	**2.5149**	**2.42**	**2.5232**
Min	**.0995**	**.0995**	**.0995**	**.0332**
Avg	**.7040**	**.6490**	**.5978**	**.9441**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274065 / 33/11KV SHIRBHAVI S/STN.
Feeder No / Name : 244 / Gaothan feeder GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2652	.2515	.2347	.2683
2	.2984	.2347	.2347	.3018
3	.3315	.2347	.2347	.285
4	.3315	.2515	.2347	.3018
5	.3647	.3521	.2683	.3688
6	.3978	.4359	.3018	.4694
7	.431	.4359	.3688	.4359
8	.3978	.4024	.3353	.3353
9	.3647	.3018	.2984	.3018
10	.3315	.2984	.2652	.2591
11	.2984	.2652	.2321	.2267
12	.2652	.2321		
13		.1658	.1658	.1311
14	.0995	.0995	.0995	.2105
15	.0995	.0995	.0995	.1326
16	.1326	.0995		.1658
17	.1326	.1677	.218	.1989
18	.2347	.2347	.3018	.2652
19	.3658	.3018	.4694	.431
20	.3688		.4359	.3978
21	.3353	.3353	.3688	.3647
22	.3018		.3018	.2984
23	.285	.2683	.285	.2652
24	.2321	.2683	.2347	.2683
Max	**.431**	**.4359**	**.4694**	**.4694**
Min	**.0995**	**.0995**	**.0995**	**.1311**
Avg	**.2898**	**.2608**	**.2722**	**.2906**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274065 / 33/11KV SHIRBHAVI S/STN.
Feeder No / Name : 245 / Devkatewadi feeder FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7459	.6706	.6036	.2683
2	.7956	.7377	.7377	.2683
3	.8288	.7712	.8718	.3856
4	.9116	.8383	1.0059	.3353
5	.9945	.9389	.8048	.4024
6	1.326	1.073	1.1401	.503
7	1.6575	1.8442	1.7436	.4694
8	2.1216	2.2131	2.2801	.4024
9	1.4918	2.079	2.2542	.3353
10	.2652	.1989	.1989	.2915
11	.1989	.1989	.1326	1.4575
12	.1326	.1658	.1326	1.9109
13		.1326	.1326	1.8138
14	.1326	.0995	.0995	1.8138
15	.1326	.0995	.0995	.4973
16	.1326	.1326		1.8233
17	.1658	.2012	.2347	1.6575
18	.2683	.2012	.3353	1.5746
19	.3963	.4694	.5365	.3978
20	.3688	.4694	.4359	.3315
21	.3521	.4694	.3688	.3315
22	.3353	.4694	.3353	.3315
23	.3018	.3353	.3018	.2652
24	.663	.6036	.4694	.2683
Max	**2.1216**	**2.2131**	**2.2801**	**1.9109**
Min	**.1326**	**.0995**	**.0995**	**.2652**
Avg	**.6400**	**.6422**	**.6633**	**.7557**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274065 / 33/11KV SHIRBHAVI S/STN.
Feeder No / Name : 246 / 11KV WATER SUPPLY NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0332	.0335	.0335	.0335
2	.0332	.0335	.0335	.0335
3	.0332	.0335	.0335	.0335
4	.0332	.0335	.0335	.0335
5	.0332	.0335	.0335	.0335
6	.0332	.0335	.0335	.0335
7	.0332	.0335	.0335	.0335
8	.0332	.0335	.0335	.0335
9	.0332	.0335	.0332	.0335
10	.0332	.0332	.0332	.0324
11	.0332	.0332	.0332	.0324
12	.0332	.0995	.0332	.0324
13	.0332	.0332	.0332	.0324
14	.0332	.0332	.0332	.0324
15	.0332	.0332	.0332	.0332
16	.0332	.0332		.0332
17	.0332	.0335	.0335	.0332
18	.0335	.0335	.0335	.0332
19	.0335	.0335	.0335	.0332
20	.0335	.0335	.0335	.0332
21	.0335	.0335	.0335	.0332
22	.0335	.0335	.0335	.0332
23	.0335	.0335	.0335	.0332
24	.0332	.0335	.0335	.0335
Max	**.0335**	**.0995**	**.0335**	**.0335**
Min	**.0332**	**.0332**	**.0332**	**.0324**
Avg	**.0333**	**.0362**	**.0334**	**.0332**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274069 / 33/11 KV MANJARI S/S
Feeder No / Name : 242 / 11 KV Bamni feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5068	.4588	.6226	.3277
2		.4706	.5144	.7537	.3353
3		.5068	.5609	.8192	.3688
4		.5068	.6379	.9831	.3688
5		.543	.695	1.1191	.3688
6			.7377	1.0513	.4359
7		.724	.9831	1.0814	.8817
8		.8573	1.134	.945	1.0486
9		.8383	1.0486	.9831	.852
10		.0335	.0328	.0335	.0655
11		.2012	.0328	.0335	.0328
12			.0328		.0335
13			.0328		.0328
14					.0328
15		.1006	.0655		.0335
16		.0335	.0655		.0328
17		.0328	.0655		.0335
18		.0655	.0655	.0671	.0655
19		.0983	.0655	.0671	.0671
20	.0343	.0655	.0655	.1017	.1006
21	.0343	.0655	.0655	.0983	.0655
22	.0343	.0678	.0655	.0983	.0671
23	.0362	.0663	.0655	.0678	.0671
24		.5144	.3353	.4588	.3018
Max	**.0362**	**.8573**	**1.134**	**1.1191**	**1.0486**
Min	**.0343**	**.0328**	**.0328**	**.0335**	**.0328**
Avg	**.0348**	**.3149**	**.3403**	**.5214**	**.2508**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274069 / 33/11 KV MANJARI S/S
Feeder No / Name : 243 / 11 KV Sangewadi Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2172	.1677	.1311	.1677
2		.2172	.2035	.1638	.1658
3		.2172	.2058	.1966	.2058
4		.2534	.2126	.1966	.2347
5		.2534	.2294	.1966	.2347
6		.2534	.2374	.1966	.2347
7		.2058	.2401	.1966	.2347
8		.2058	.2195	.1966	.2347
9		.2172	.1966	.2058	.2012
10		.2012	.1966	.1006	.1677
11		.2012	.7537	1.3435	1.3435
12			1.1797		1.4419
13			1.3763		
14			1.3108		1.3108
15		1.5089	1.3763		1.6385
16		1.4251	1.4091		1.6712
17		1.4419	1.4746		1.5074
18		1.278	1.1469	1.4419	1.5424
19		.2012	.1638	.2347	.2347
20	.2172	.2012	.1966	.2347	.1966
21	.2401	.1677	.1966	.2035	.1638
22	.2534	.1638	.1966	.1638	.1677
23	.0362	.1311	.1311	.1357	.1311
24			.1311	.1311	.1341
Max	**.2534**	**1.5089**	**1.4746**	**1.4419**	**1.6712**
Min	**.0362**	**.1311**	**.1311**	**.1006**	**.1311**
Avg	**.1867**	**.4481**	**.5480**	**.3150**	**.5898**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274069 / 33/11 KV MANJARI S/S
Feeder No / Name : 244 / 11 KV Gaothan Feeder GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5792	.2347	.3353	.3277
2		.6516	.2683	.3688	.3353
3		.543	.2683	.503	.4409
4		.543	.3353	.8383	.5365
5		.6878	.4588	.8383	.6036
6		.905	.583	.8048	
7		.823	.6104	.7712	.8048
8		.6859	.57	.7377	.7537
9		.57	.426	.4359	.4588
10		.4024	.3277	.3353	.426
11		.2012	.2294	.3018	.2622
12			.2374		
13			.2294		.1966
14			.2294		.2347
15		.2347	.2294		.2622
16		.1966	.2294		.2622
17		.1966	.2294		.3605
18		.426	.2294	.5898	.4694
19		.5898	.4588	.6036	.7377
20	.5487	.5243	.4915	.7373	.5898
21	.6154	.4588	.5376	.6226	.5243
22	.6173	.3605	.5243	.5243	.3277
23	.5792	.2294	.3052	.3052	.3018
24		.543	.2347	.3353	.2949
Max	**.6173**	**.905**	**.6104**	**.8383**	**.8048**
Min	**.5487**	**.1966**	**.2294**	**.3018**	**.1966**
Avg	**.5902**	**.4929**	**.3532**	**.5549**	**.4323**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274069 / 33/11 KV MANJARI S/S
Feeder No / Name : 245 / 11 KV DEVALE AG FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2172	.2401	.2347	.2294
2		.2534	.2401	.2347	.2515
3		.2534	.2515	.3018	.2515
4		.2896	.2683	.3018	.2622
5		.2896	.2743	.3018	.3018
6		.2534	.3292	.3353	.3353
7			.3018	.3353	.1638
8			.3018	.3353	.3018
9		.2012	.2294	.2622	.2294
10		.1677	.2374	.2347	.2294
11			1.4419	1.6712	.9389
12			1.6385		1.5402
13			1.6057		1.6712
14			1.6057		1.7695
15		.3353	1.6385		1.8778
16		1.5729	1.704		1.8778
17		.9831	1.6385		1.9006
18		1.3435	1.5729	1.7368	1.6385
19		.1966	.2294	.3018	.2622
20	.2172	.2949	.2622	.3018	.2622
21	.2267	.2683	.2949	.2458	.2294
22	.2534	.2347	.2294	.2458	.2294
23	.2743	.2374	.2294	.2294	.2294
24		.2534	.2401	.2347	.2294
Max	**.2743**	**1.5729**	**1.704**	**1.7368**	**1.9006**
Min	**.2172**	**.1677**	**.2294**	**.2294**	**.1638**
Avg	**.2429**	**.4248**	**.7085**	**.4358**	**.7172**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274069 / 33/11 KV MANJARI S/S
Feeder No / Name : 246 / 11 KV SAve Gaonthan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.543	.3353	.3688	.3605
2		.5249	.3688	.4359	
3		.543	.503	.503	.3353
4		.5182	.5868	.6706	.4694
5		.7611	.6706	.7042	.5735
6		.905	.8718	.7377	.8356
7			.8745	.7545	.8848
8			.5992	.7545	.7537
9		.4694	.3441	.5365	.4915
10		.4359	.3277	.426	.4191
11		.3688	.2949	.3605	.0033
12			.2949		.3018
13			.2622	.3688	.2622
14		.3018			.285
15		.3353	.2785	.3688	.1638
16		.3353	.2622		.3441
17		.4096			.4096
18		.5571	.3277	.57	.5197
19		.6371	.3277	.5898	.6226
20	.6516	.5256	.4748	.5898	.5868
21	.6516	.4588	.5735	.5243	.503
22	.6878	.4096	.4915	.503	.4588
23	.724	.3605	.373	.3441	.3521
24		.5792	.3353	.3353	.3353
Max	**.724**	**.905**	**.8745**	**.7545**	**.8848**
Min	**.6516**	**.3018**	**.2622**	**.3353**	**.0033**
Avg	**.6788**	**.4990**	**.4445**	**.5223**	**.4466**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274069 / 33/11 KV MANJARI S/S
Feeder No / Name : 247 / 11 KV Save AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.086	.6478	.6706	.7865
2		1.1946	.8383	.8383	.7865
3			.9431	1.0059	.8192
4		1.2003	1.1065	1.6766	.9175
5		1.3756	1.1736	1.7101	.9503
6		1.5927	1.1736	1.8275	1.1469
7		1.8461	1.8442	1.8778	1.7814
8		1.9909	1.9784	2.0957	2.3594
9		1.9113	2.0481	2.0972	1.7772
10		.2515	.2294	.2458	.2515
11		.1844	.2294	.2294	.1966
12			.2294		.1966
13			.1852		.2294
14		.1677			.2347
15		.1844	.2622		.1638
16		.1638	.2622		.1802
17		.1174			.2347
18		.285	.2622	.2785	.285
19		.3185	.2622	.4024	.3521
20	.2743	.285	.2949	.3441	.3018
21	.3077	.2458	.2785	.3353	.2622
22	.3077	.2458	.213	.3018	.2622
23	.3258	.2204	.2035	.2458	.2294
24		1.4118	.6554	.5365	.7373
Max	**.3258**	**1.9909**	**2.0481**	**2.0972**	**2.3594**
Min	**.2743**	**.1174**	**.1852**	**.2294**	**.1638**
Avg	**.3039**	**.7752**	**.6964**	**.9289**	**.6434**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274110 / 33/11 KV ALEGAON S/S
Feeder No / Name : 241 / 11 KV Waki Gheradi Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0857	.0762	.081	.4572
2		.0857	.0762	.081	.4572
3		.0857	.0762	.081	.6097
4		.0857	.0762	.081	.7621
5		.0857	.0762	.081	.9145
6		.0857	.0762	.081	.9145
7		.0857	.0762	.081	.9907
8		.0857	.0762	.081	1.0669
9		.0857	.0762	.081	.6097
10		.0857	.4049	.081	.1134
11	.9145	.7621	.4049	.7621	.1134
12	1.0669	.8383	.3239	.6097	.1134
13	1.0669	.9145	.3239		
14	1.2193	1.0669	.4049	.4572	
15	.8383	1.1431	.4049	.7621	.1134
16	.7621	1.0669	.5668	.8383	.1134
17	.9145	.9907	.4858	.9145	.1134
18	.9145	.8383	.4049	.6097	.1134
19	.081	.0857	.081	.081	.1134
20	.081	.1029	.081	.081	.1134
21	.081	.1372	.081	.081	.1134
22	.081	.1029		.081	
23	.081	.0857	.081	.081	
24		.0857	.0762	.081	.3048
Max	**1.2193**	**1.1431**	**.5668**	**.9145**	**1.0669**
Min	**.081**	**.0857**	**.0762**	**.081**	**.1134**
Avg	**.6232**	**.3782**	**.2092**	**.2717**	**.4111**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274110 / 33/11 KV ALEGAON S/S
Feeder No / Name : 242 / 11 KV Alegaon Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7621	.8907	.6859	.1134
2		.9145		1.1431	.1134
3		.9145	1.0526	1.5242	.1134
4		1.5242	1.1336	1.6766	.1134
5		1.829	1.2955	1.829	.1134
6		2.1338	2.0243	1.9052	.1134
7		2.5911	2.4291	2.21	.1134
8		2.7435	2.834	2.6673	.1134
9		2.7435	2.672	2.5911	.1134
10		.12	.1067		.1134
11	.1134	.12	.1067	.1134	.4572
12	.1134	.12	.1067	.1134	
13	.1134	.12		.1134	
14	.1134	.12			2.21
15	.1134	.12			2.2862
16	.1134	.12	.1067		2.3624
17	.1134	.12	.1067	.1134	2.5149
18	.1134	.12	.1067	.1134	2.21
19	.1134	.12	.1134	.1134	.1134
20	.1134	.1372	.1134	.1134	.1134
21	.1134	.1715	.1134	.1134	.1134
22	.1134	.1372	.1134	.1134	
23	.1134	.12		.1134	
24		.7621		.6097	.1134
Max	**.1134**	**2.7435**	**2.834**	**2.6673**	**2.5149**
Min	**.1134**	**.12**	**.1067**	**.1134**	**.1134**
Avg	**.1134**	**.7785**	**.8570**	**.8988**	**.6814**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274110 / 33/11 KV ALEGAON S/S
Feeder No / Name : 244 / Alegaon Gaothan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2572	.2572	.2401	.2267
2		.2743	.2572	.2743	.2429
3		.3086	.2572	.3086	.2753
4		.3429	.2743	.3772	.2753
5		.463	.3086	.4458	.3077
6		.5144	.4115	.4973	.3725
7		.5487	.5487	.5316	.502
8		.4458	.4458	.5144	.4049
9		.3429	.4115	.3772	.4049
10		.3086	.3772	.3086	.2429
11	.2572	.2915	.3086	.2572	.2267
12	.2058	.2572	.2743	.1715	.2105
13	.1715	.1715	.2401	.1886	.2105
14	.1886	.1715	.1715		.1943
15	.2229	.1715	.1543		.2105
16	.2572	.1715	.1543		.1619
17	.2915	.2058	.2401	.2743	.1457
18	.3429	.3429	.3258	.3258	.2105
19	.4115	.4115	.3429	.3944	.2753
20	.3429	.4115	.3086	.3601	.3077
21	.3086	.3772	.2743	.2915	.3563
22	.2743	.3429	.2572	.2572	
23	.2572	.2915	.1886	.2401	
24		.2572	.2572	.1715	.2105
Max	**.4115**	**.5487**	**.5487**	**.5316**	**.502**
Min	**.1715**	**.1715**	**.1543**	**.1715**	**.1457**
Avg	**.2717**	**.3201**	**.2936**	**.3242**	**.2716**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274110 / 33/11 KV ALEGAON S/S
Feeder No / Name : 245 / Wanichanchale AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2572	.2286	.2429	.7621
2		.2572	.2286	.2429	.9145
3		.2572	.2286	.2429	1.1431
4		.2572	.2286	.2429	1.2193
5		.2572	.2591	.2429	1.3717
6		.2572	.3658	.2429	1.5242
7		.2572	.3353	.2429	1.9814
8		.3429	.3048	.2429	2.1338
9		.2915	.2286	.2429	1.9052
10		.2572	.1524	.2429	.2429
11	1.9814	1.9052	.9717		.2105
12	2.572	2.1338	1.3765		.1619
13	2.4387	2.0576	1.4575	1.5242	.1619
14	2.7435	2.0424	1.6194	1.1431	.1619
15	2.1338	2.0271	1.7814	2.1338	.1457
16	1.9814		2.1052	2.2862	.1457
17	1.5242	1.6461		2.2862	.1457
18	1.829	1.6156	2.0243	1.9814	.2105
19	.3239	.3086	.2429	.3239	.2267
20	.2915	.3429	.2429	.3239	.2429
21	.2591	.2743	.2429	.3239	.2591
22	.2591	.2572	.2429	.2429	
23	.2429	.2572	.2429	.2429	
24		.2572	.2286	.2429	.5335
Max	**2.7435**	**2.1338**	**2.1052**	**2.2862**	**2.1338**
Min	**.2429**	**.2572**	**.1524**	**.2429**	**.1457**
Avg	**1.4293**	**.7747**	**.6669**	**.7038**	**.7184**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274118 / 33/11 KV Y.MANGEWADI S/S
Feeder No / Name : 241 / 11 KV Watambare Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1619	.1619	.1619	.3239
2	.1619	.1619	.1619	.4858
3	.1619	.1619	.1619	.4858
4	.1619	.1619	.1619	.4858
5	.1619	.1619	.1619	.4858
6	.1619	.1619	.1619	.4858
7	.1619	.1619	.1619	.4858
8	.1619	.1619	.1619	.4858
9	.1619	.1619	.1619	.4858
10	.1619	.1619	.1619	.1619
11	.3239	.3239	.4858	.1619
12	.3239	.3239	.4858	.1619
13	.3239	.3239	.4915	.1619
14	.3239	.3239	.4858	.1619
15	.3239	.3239	.4858	.1619
16	.4858	.3239	.4915	.1619
17	.4858	.3239	.4858	.1619
18	.4858	.3239	.4858	.1619
19	.1619		.1619	.1619
20	.1619		.1619	.1619
21	.1619		.1619	.1619
22	.1619		.1562	.1619
23	.1619		.1638	.1619
24	.1619	.1619	.1619	.3239
Max	**.4858**	**.3239**	**.4915**	**.4858**
Min	**.1619**	**.1619**	**.1562**	**.1619**
Avg	**.2361**	**.2301**	**.2702**	**.2834**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274118 / 33/11 KV Y.MANGEWADI S/S
Feeder No / Name : 242 / 11 KV Y.Mangewadi Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9433	1.7814	1.4575	.3239
2	1.9433	1.6194	1.6385	.3239
3	1.9433	1.4575	1.7814	.3239
4	2.1052	1.6194	1.8023	.3239
5	2.1052	1.7814	1.6194	.3239
6	2.1052	1.7814	1.7814	.4858
7	2.1052	1.9433	1.9433	.4858
8	2.1052	2.1052	1.7814	.4858
9	2.1052	1.9433	1.7814	.3239
10	.1619		.1619	.3239
11	.3239		.3239	1.7814
12	.3239		.3239	1.9433
13	.3239			1.6194
14	.3239		.3239	
15	.3239		.3239	1.4575
16	.3239		.1619	
17	.3239		.3239	1.9433
18	.3239			1.9433
19	.3239		.3277	.3239
20	.3239		.3239	.3239
21	.3239		.3239	.3239
22	.3239		.3239	.3239
23	.1619		.3277	.1619
24	1.6194	1.4575	1.6194	.3239
Max	**2.1052**	**2.1052**	**1.9433**	**1.9433**
Min	**.1619**	**1.4575**	**.1619**	**.1619**
Avg	**1.0121**	**1.7490**	**.9444**	**.7361**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274118 / 33/11 KV Y.MANGEWADI S/S
Feeder No / Name : 243 / 11 KV Balwadi Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1619	.1619	.1619	2.1052
2	.1619	.1619	.1619	2.1052
3	.1619	.1619	.1619	2.4291
4	.1619	.1619	.1619	2.5911
5	.1619		.1619	2.753
6	.1619	.1619	.1619	2.753
7	.1619	.1619	.1619	3.0769
8	.1619	.1619	.1638	3.2388
9	.1619	.1619	.1638	3.4008
10	.1619	.1619	.1619	.1619
11	2.915	2.915	3.2388	.1619
12	3.4008	3.2388	3.0769	.1619
13	3.2388	3.4008	3.2388	.1619
14	3.0769	3.5627	3.0769	.1619
15	3.5627	3.4008	3.0769	.1619
16	3.7247	3.5627	3.0769	.1619
17	3.2388	3.7247	3.0769	.1619
18	3.5627	3.7247	3.0769	.1619
19	.1619		.1619	.1619
20	.1619		.1619	.1619
21	.1619		.1619	.1619
22	.1619		.1619	.1619
23	.1619		.1619	.1619
24	.1619	.1619	.1638	1.9433
Max	**3.7247**	**3.7247**	**3.2388**	**3.4008**
Min	**.1619**	**.1619**	**.1619**	**.1619**
Avg	**1.2213**	**1.6194**	**1.1473**	**1.1943**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274118 / 33/11 KV Y.MANGEWADI S/S
Feeder No / Name : 244 / 11 KV Ajnale Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.4858	.6554	.1619
2	.6478	.4858	.6478	.1619
3	.6478	.4858	.8097	.1619
4	.6478	.4858	.8097	.1619
5	.6478	.6478	.6478	.1619
6	.6478	.6478	.6478	.1619
7	.8097	.6478	.6478	.1619
8	.8097	.6478	.6478	.1619
9	.9717	.6478	.6478	.1619
10	.1619	.1619	.1619	.1619
11	.1619		.1619	.6478
12	.1619	.1619	.1619	.6478
13	.1619	.1619		.6478
14	.1619	.1619	.1619	.6478
15	.1619	.1619	.1619	.6478
16	.1619	.1619	.1562	.6478
17	.1619	.1619	.1638	.6478
18	.1619	.1619		.8097
19	.1619	.1562	.1619	.1619
20	.1619			.1619
21	.1619		.1619	.1619
22	.1619		.1562	.1619
23	.1619		.1638	.1619
24	.4858	.6478	.6478	.1619
Max	**.9717**	**.6478**	**.8097**	**.8097**
Min	**.1619**	**.1562**	**.1562**	**.1619**
Avg	**.3846**	**.3832**	**.4087**	**.3306**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274118 / 33/11 KV Y.MANGEWADI S/S
Feeder No / Name : 245 / Ligadewadi feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1336	1.2955	1.1336	.1619
2	1.4575	1.1336	***	.1619
3	1.6194	1.1336	.9717	.1619
4	1.6194	1.4575	.8907	.1619
5	1.6194	1.4575	.8097	.1619
6	1.6194	1.7814	.8097	.1619
7	1.6194	1.7814	.1619	.1619
8	1.6194	1.7814	.9831	.1619
9	1.7814	1.406	.9831	.1619
10	.1619	2.6235	.1638	.1619
11	.1619	.1619	.1638	1.6194
12	.1619	.1619	.1638	1.7814
13	.1619		.1638	1.7814
14	.1619		.1638	1.6194
15	.1619		.1638	
16	.1619		.1638	1.4575
17	.1619		.1638	1.6194
18	.1619		.1638	1.7814
19	.1619		.1638	.1619
20	.1619		.1638	.1619
21	.1619			.1619
22	.1619		.1638	.1619
23			.1638	.1619
24	.9717	1.2955	1.1336	.1619
Max	**1.7814**	**2.6235**	**15.7408**	**1.7814**
Min	**.1619**	**.1619**	**.1619**	**.1619**
Avg	**.7463**	**1.3439**	**1.1194**	**.6196**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274118 / 33/11 KV Y.MANGEWADI S/S
Feeder No / Name : 246 / Kamlapur feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1619	.1619	1.1336
2	.1715	.1619	.1619	1.2955
3	.1715	.1619	.1619	1.2955
4	.1715	.1619	.1619	1.6194
5	.1715	.1619	.1619	1.6194
6	.3429	.3239	.1619	1.6194
7	.3429	.3906	.1619	1.6194
8	.3429		.1619	1.4575
9	.3429	.3239	.1619	1.6194
10	.3429	.1619	.2267	.3239
11	1.8861		1.9757	.3239
12	1.7147		2.0081	.3239
13	1.8861		1.9757	.3239
14	2.0576		1.8138	.3239
15	1.7147		1.6194	.3239
16	1.7147		1.4575	.3239
17	1.9433		1.4575	.3239
18	1.7814		1.5223	.3239
19	.3239		.3563	.3239
20	.3239		.3401	.3239
21	.3239		.3239	.3239
22	.3239		.1943	.3239
23	.1619		.1619	.1619
24	.1753	.1619	.1619	1.1336
Max	**2.0576**	**.3906**	**2.0081**	**1.6194**
Min	**.1619**	**.1619**	**.1619**	**.1619**
Avg	**.7876**	**.2172**	**.7105**	**.7827**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274137 / 33/11 kv Gaigavan sub station
Feeder No / Name : 241 / 11 KV Gaigavan Feeder FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)
1		.4049
2		.4049
3		.5344
4		.5992
5		1.166
6		1.1822
7		1.2955
8		1.4089
9		1.326
10		.1372
11		.12
12		.1372
13		.1029
14		.1029
16	.7926	.0857
17		.1086
18		.1086
19		.181
20		.181
21		.2896
22		.2353
23		.2534
24		.3239
Max	**.7926**	**1.4089**
Min	**.7926**	**.0857**
Avg	**.7926**	**.4648**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274137 / 33/11 kv Gaigavan sub station
Feeder No / Name : 242 / 11 KV Khilarwadi Feeder FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6316	.7287	.6316	.7287	.4163
2		.9393	.9393	.7935	1.0202	.4525
3	.3209	1.004	1.4737	.8583	1.247	.362
4	.2896	1.1822	1.668	1.4251	1.3765	.3982
5	.3258	1.2631	1.7652	1.2793	1.5708	.3982
6	.3086	1.5061	1.8947	1.668	1.8138	.4525
7	.3944	1.749	2.0081	2.0081	2.1862	.5068
8	.3086	1.9757	2.332		1.9433	.4706
9	.3086	1.7071	1.9814		1.89	.3086
10					.12	.2572
11				.2401	.12	1.5851
12	1.9509	.12	.2058	.2401	.1543	2.3167
13				.1715	.1543	2.2405
14				.1886	.1886	2.1491
15				.1715	.2058	
16	1.2346	.2058	.2229	.1886	.2229	2.1033
17						1.8442
18						1.8785
19						.4344
20						.4163
21						.3801
22						.362
23						.362
24	.3201	.4372	.3239	.4049	.502	.3801
Max	**1.9509**	**1.9757**	**2.332**	**2.0081**	**2.1862**	**2.3167**
Min	**.2896**	**.12**	**.2058**	**.1715**	**.12**	**.2572**
Avg	**.5762**	**1.0601**	**1.2953**	**.7335**	**.9085**	**.8902**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274137 / 33/11 kv Gaigavan sub station
Feeder No / Name : 243 / 11 KV Dhalewadi Feeder FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5639	.2172	.2896	.2353	.2534	.4049
2		.2172	.3258	.2172	.2534	.4534
3		.1991	.2715	.2172	.2353	.502
4		.1991	.2534	.181	.2715	.5506
5	.8993	.181	.1991	.181	.2896	.7935
6	1.1431	.1629	.2353	.1629	.2534	1.1174
7		.181	.2534	.1629	.2427	1.3765
8		.181	.181		.2172	1.4737
9	1.6461		.1715		.1715	1.4022
10					.1715	.1372
11				1.2346	1.3565	.0857
12	.0857	1.5089	1.6004	1.4937	1.6156	.0857
13				1.5851	1.6004	.0857
14				1.5699	1.6004	.0857
15				1.3717	1.5242	
16	.1029	1.7071	1.6004	1.387	1.3413	.0857
17						.12
18						.2172
19						.2353
20						.2353
21						.2534
22						.2715
23		.1543				.2534
24	.442	.2353	.2715	.2534	.2715	.3239
Max	**1.6461**	**1.7071**	**1.6004**	**1.5851**	**1.6156**	**1.4737**
Min	**.0857**	**.1543**	**.1715**	**.1629**	**.1715**	**.0857**
Avg	**.6976**	**.4287**	**.4711**	**.7324**	**.6864**	**.4587**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274137 / 33/11 kv Gaigavan sub station
Feeder No / Name : 244 / 11kv gaighavan gaothan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143		.16	.0991	.16	.16
2			.16	.1029	.1677	.1677
3			.1753	.1067	.1867	.1791
4			.1981	.1105	.1943	.1715
5	.1791		.2134	.1296	.2058	.1829
6	.1486		.221	.1334	.2248	.1943
7	.1562		.2439	.1372	.2324	.2058
8		.1296	.202	.1334	.1905	.2248
9	.1181	.1448	.1791	.1219	.1791	.1905
10					.1219	.1219
11				.1029	.0991	.1067
12	.08	.1143	.08	.08	.061	.0762
13				.0762	.061	.08
14				.0762	.0572	1.3908
15				.0762	.0686	
16	.0762	.0914	.08	.0724	.0876	.0876
17						.1029
18						.1562
19						.2324
20						.2058
21						.1715
22						.1791
23						.1677
24	.1524		.1486	.0953	.1486	.1486
Max	**.1791**	**.1448**	**.2439**	**.1372**	**.2324**	**1.3908**
Min	**.0762**	**.0914**	**.08**	**.0724**	**.0572**	**.0762**
Avg	**.1281**	**.1200**	**.1718**	**.1034**	**.1439**	**.2132**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274154 / 33/11 KV Junoni S/Stn
Feeder No / Name : 241 / 11 KV Jujarpur Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1619	.1526	.1357	.3932
2		.1619	.1357	.1357	.4588
3		.1619	.1357	.1357	.4858
4		.1619	.1526	.1526	.5243
5		.1943	.1696	.1696	.5735
6		.2429	.2012	.2035	.6226
7		.2429	.218	.2204	.9175
8		.1943	.1844	.1865	1.1633
9	.1457	.1526	.1677	.1509	1.0227
10	.1296	.1017	.1017		.1509
11	1.0526		1.0059	.9231	.1341
12	1.1336	1.0562	1.2407	1.2407	.0671
13	1.2146	1.2407	1.3245	.4858	.1174
14	1.247	1.3413	.9724	1.1797	.1174
15	1.247	1.291	1.0059	1.1174	.1174
16	1.2955	1.2742	.9724		.1174
17	1.3279	1.2239	.9556		.1341
18	1.0526	1.1401	1.0059		.1677
19	.1943	.1865	.1865	.1844	.2012
20	.2105	.1865	.1865	.218	.1677
21	.2105	.1696	.1696	.2515	.1677
22	.2105	.1696	.1526	.218	.1509
23	.1781	.1696	.1372	.1509	.1341
24		.1619	.1526	.1372	.4096
Max	**1.3279**	**1.3413**	**1.3245**	**1.2407**	**1.1633**
Min	**.1296**	**.1017**	**.1017**	**.1357**	**.0671**
Avg	**.7233**	**.4951**	**.4620**	**.3799**	**.3549**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274154 / 33/11 KV Junoni S/Stn
Feeder No / Name : 242 / 11 KV Junoni Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0162	.0162	.0162	.0819
2		.0162	.0162	.0162	.0983
3		.0162	.0162	.0162	.0983
4		.0162	.0162	.0162	.1311
5		.0162	.0162	.0324	.1311
6		.0324	.0324	.0324	.1638
7		.0324	.0324	.0486	.2294
8		.0162	.0162	.0486	.3113
9	.0324	.0162	.0162	.0335	.2458
10	.0162	.0162	.0162		.0168
11	.2429		.421	.2458	.0168
12	.2915	.3239	.5182	.3277	.0168
13	.2429	.2915	.4858	.1638	.0168
14	.2267	.3239	.4534	.2458	.0168
15	.2429	.2753	.4696	.2294	.0168
16	.2429	.2591	.4858		.0168
17	.2753	.2591	.4858		.0335
18	.1943	.2267	.4858		.0335
19	.0324	.0486	.0324	.0335	.0335
20	.0324	.0324	.0486	.0335	.0335
21	.0162	.0324	.0486	.0335	.0335
22	.0162	.0324	.0324	.0335	.0335
23	.0162	.0162	.0162	.0335	.0335
24		.0162	.0162	.0162	.0983
Max	**.2915**	**.3239**	**.5182**	**.3277**	**.3113**
Min	**.0162**	**.0162**	**.0162**	**.0162**	**.0168**
Avg	**.1414**	**.1014**	**.1748**	**.0828**	**.0809**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274154 / 33/11 KV Junoni S/Stn
Feeder No / Name : 243 / 11 KV H.Mangewadi feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5668	.6036	.5426	.1844
2		.5992	.6613	.6371	
3		.6478	.763	.6706	.2012
4		.7287	1.0004	.7209	.218
5		.8583	1.2378	1.1401	.213
6		1.085	1.6263	1.4251	.2515
7		1.3765	1.6766	1.4586	.3185
8		1.5061	1.5927	1.4922	.2347
9	1.3441	1.4251	1.4754	1.6032	.218
10		.1526	.1357		.1844
11	.1134		.0848	.1174	1.5089
12	.1134	.1017	.0857	.1006	1.1065
13	.1134	.0678	.0857	.1006	1.4089
14	.0972	.0848	.0848	.1174	1.7328
15	.0972	.0848	.0848	.1006	1.7328
16	.1134	.1017			1.7328
17	.1457	.1187	.0848		1.6356
18	.1619	.1357	.1372		1.4575
19	.2267	.2035	.2035	.285	.2267
20	.2591	.2035	.2374	.2683	.2347
21	.2591	.1865	.2035	.2515	.1844
22	.2105	.1696	.1865	.2347	.1844
23	.1619	.1526	.1696	.218	.1844
24		.5506	.5197	.5087	.2012
Max	**1.3441**	**1.5061**	**1.6766**	**1.6032**	**1.7328**
Min	**.0972**	**.0678**	**.0848**	**.1006**	**.1844**
Avg	**.2441**	**.4829**	**.5626**	**.5997**	**.6763**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274154 / 33/11 KV Junoni S/Stn
Feeder No / Name : 244 / 11 KV JUNONI GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.1387	.1372	.1509
2		.1715	.1387	.12	.1509
3		.1715	.1372	.1214	.1677
4		.1715	.156	.1372	.1677
5		.2058	.1907	.1715	.1802
6		.2743	.2572	.2743	.218
7		.3086	.2743	.3086	.3018
8		.2401	.2572	.2572	.218
9	.2058	.1715	.2058	.218	.1677
10	.1886	.1543	.2229		.1174
11	.2229		.2229	.1509	.1677
12	.2058	.1543	.1886	.1509	.1677
13		.1372	.1715	.1174	.1677
14	.1715	.1372	.1372	.1341	.1677
15	.1543	.1372	.1372	.1509	.1677
16	.1715	.1543	.1372		.1677
17	.2058	.2058	.1372		.1844
18	.3086	.2401	.2229		.2515
19	.2915	.2572	.2774	.3185	.285
20	.2915	.2572	.2427	.2683	.285
21	.2572	.2058	.2058	.2347	.2347
22	.2229	.1715	.156	.2012	.1844
23	.1715	.156	.1387	.1844	.1341
24		.1715	.1372	.1372	.1677
Max	**.3086**	**.3086**	**.2774**	**.3185**	**.3018**
Min	**.1543**	**.1372**	**.1372**	**.1174**	**.1174**
Avg	**.2192**	**.1924**	**.1871**	**.1897**	**.1906**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274166 / 33/11 KV Chopadi Sub-Station
Feeder No / Name : 241 / Chopadi Gaothan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1372	.12	.12	.12
2			.12	.1372	.1543	.1372
3			.1372	.1543	.1886	.1543
4			.1715	.1715	.2058	.1715
5			.2058	.1886	.2743	.1886
6			.2915	.2572	.3086	.2915
7			.3601	.3429	.3258	.3429
8			.3086	.3429	.3601	.3086
9	.2572	.3258	.2572	.2743	.2915	.2915
10	.2401	.3086	.2915	.2743	.2915	.2401
11	.2058	.2401	.2572	.2401	.2229	.2058
12	.2229	.2229	.2401	.1715	.2229	.1886
13	.1715	.1886	.1886	.12	.1886	.1543
14	.12	.1543	.0857	.1543	.12	.12
15	.1372	.1543	.12	.1372	.1543	.1372
16	.2058	.1372	.1543	.1886	.1886	.1543
17			.1886	.2058	.1543	.2229
18			.2743	.2743	.2743	.2743
19			.3258	.3258	.2915	.2915
20			.2572	.2915	.2572	.2915
21			.2229	.2572	.2401	.2401
22			.2058	.1372	.2058	.2058
23			.1372	.1372	.1372	.1372
24			.12	.1372	.1372	.12
Max	**.2572**	**.3258**	**.3601**	**.3429**	**.3601**	**.3429**
Min	**.12**	**.1372**	**.0857**	**.12**	**.12**	**.12**
Avg	**.1951**	**.2165**	**.2108**	**.2100**	**.2215**	**.2079**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274166 / 33/11 KV Chopadi Sub-Station
Feeder No / Name : 242 / balwadi feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3563	.3077	.2915	.8745
2			.3563	.3077	.3239	.9231
3			.4372	.3401	.3563	.9717
4			.4696	.4049	.421	1.1012
5			.5182	.4696	.4858	1.1822
6			.7287	.6154	.6316	1.3279
7			.6802	.664	.6478	1.7814
8			.5344	.5182	.583	2.1214
9	2.3482	2.2672	.3887	.4696	.4049	2.0405
10	.3563	.3239	.3401	.3563	.3563	.3887
11	.2915	.2753	1.8623	1.9595	1.9919	.2753
12	.3077	.2753	2.2186	2.2186	2.2834	.2591
13	.2915	.2591	2.17	2.4291	2.2024	.2915
14	.2753	.2753	2.3158	1.6194	2.1538	.2753
15	.2591	.2591	2.5263	2.0891	2.332	.2753
16	.2429	.2753	2.5425	2.2672	2.2672	.2915
17			2.3158	2.251	2.3805	.2915
18			2.2024	2.251	2.1376	.3563
19			.5182	.5182	.5668	.5182
20			.4372	.4858	.5344	.4858
21			.4049	.4534	.4372	.421
22			.3563	.3725	.3725	.3401
23			.3077	.2915	.3077	
24			.3887	.3401	.2915	.7449
Max	**2.3482**	**2.2672**	**2.5425**	**2.4291**	**2.3805**	**2.1214**
Min	**.2429**	**.2591**	**.3077**	**.2915**	**.2915**	**.2591**
Avg	**.5466**	**.5263**	**1.0574**	**1**	**1.0317**	**.7625**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274166 / 33/11 KV Chopadi Sub-Station
Feeder No / Name : 243 / BANDGARWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1943	.1619	.2429	.0972
2			.2105	.1943	.2915	.0972
3			.2591	.1943	.3401	.1134
4			.3401	.2267	.3725	.1457
5			.3887	.2429	.421	.1943
6			.502	.3725	.4858	.2267
7			.5506	.4049	.5668	.3077
8			.7935	.8421	.8421	.2429
9	.1296	.1457	.7449	.7449	.6964	.1134
10	.1134	.1134	.0972	.1134	.0972	.0486
11	.5992	.5506	.081	.0972		.5668
12	.6316	.5992	.0972	.0486	.0486	.5992
13	.6316	.6478	.081	.0972	.0486	.7773
14	.7287	.6802	.0648	.0648	.0486	.7773
15	.5182	.7287	.0648	.0648	.0486	.6964
16	.5668	.6478	.081	.0972	.0648	.7935
17			.0972	.1134	.081	.6802
18			.1296	.1296	.1134	.7449
19			.2105	.2105	.1943	.2429
20			.1457	.1619	.1457	.1943
21			.1134	.1457	.0972	
22			.1134	.1134	.0972	.1134
23			.0972	.0972	.081	
24			.2267	.1781	.1943	.0972
Max	**.7287**	**.7287**	**.7935**	**.8421**	**.8421**	**.7935**
Min	**.1134**	**.1134**	**.0648**	**.0486**	**.0486**	**.0486**
Avg	**.4899**	**.5142**	**.2369**	**.2132**	**.2443**	**.3578**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274166 / 33/11 KV Chopadi Sub-Station
Feeder No / Name : 244 / chopadi SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2753	.4049	.3401	.1296
2			.2915	.4372	.4372	.1457
3			.4049	.5668	.4696	.1943
4			.4696	.6154	.5182	.2105
5			.5668	.7125	.6964	.3077
6			.7611	.9069	.8907	.421
7			1.0526	.6478	1.1012	.4858
8			.8097	1.0526	1.247	.3725
9	.1296	.1943	1.1336	1.166	1.1498	.2267
10	.0972	.1296	.1457	1.4413	.1296	.1457
11	1.2146	1.1984	.1457	.1134	.081	1.0688
12	1.3117	1.2308	.1134	.1134	.081	1.166
13	1.2955	1.4251	.1296	.0972	.1296	1.2955
14	1.2793	1.5061	.1134	.0972	.0972	1.3927
15	1.3441	1.5708	.0972	.081	.081	1.3441
16	1.3765	1.4251	.1457	.1134	.0972	1.1822
17			.1619	.1372	.1134	1.166
18			.2267	.2105	.2105	.9878
19			.3239	.3077	.2429	.3077
20			.2591	.2915	.2915	.2429
21			.2429	.2429	.2591	.2753
22			.1781	.1781	.1619	.1943
23			.1457	.1457	.1457	.1619
24			.3077	.4696	.3077	.1457
Max	**1.3765**	**1.5708**	**1.1336**	**1.4413**	**1.247**	**1.3927**
Min	**.0972**	**.1296**	**.0972**	**.081**	**.081**	**.1296**
Avg	**1.0061**	**1.0850**	**.3542**	**.4396**	**.3866**	**.5654**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274169 / 33/11 KV Wadegaon Sub-Station
Feeder No / Name : 241 / Wadegaon Gaothan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0972	.081	.0762	.081
2		.0972	.081	.0762	.081
3		.0972	.081	.0762	.081
4		.0972	.1134	.1067	.1134
5		.0972	.1457	.1524	.1619
6		.2267	.2267	.2439	.1619
7		.2753	.2591	.2591	.2429
8		.1943	.1943	.2134	.2105
9		.1943	.1543	.1886	.1543
10		.0972	.1029	.1029	.1029
11		.0972	.0857	.1029	.0857
12		.0972	.0857	.1029	.0857
13		.081	.0857	.1029	.0857
14		.081	.0857	.0857	.0857
15		.081	.0857	.0686	.0857
16		.081	.0857	.0857	.0857
17		.1134	.0857	.0762	.1029
18		.1781	.1677	.1372	.1543
19		.1981	.1524	.2286	.2058
20		.1524	.1981	.2134	.1886
21	.1134	.1457	.1524	.1619	.1619
22	.1134	.1134	.0914	.1134	.1296
23	.0972	.0972	.0762	.0972	.0972
24		.0972	.081	.0762	.081
Max	**.1134**	**.2753**	**.2591**	**.2591**	**.2429**
Min	**.0972**	**.081**	**.0762**	**.0686**	**.081**
Avg	**.108**	**.1287**	**.1233**	**.1312**	**.1261**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274169 / 33/11 KV Wadegaon Sub-Station
Feeder No / Name : 243 / DIGHEMALA FEEDER SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2591	.2591	.1677	.6478
2		.2591	.2591	.1677	.6478
3		.2591	.2591	.1829	.6478
4		.2915	.2591	.2134	.8097
5		.3239	.2915	.2439	1.4575
6		.421	.3887	.3048	1.7814
7		.502	.421	.381	1.9433
8		.4858	.4696	.3963	2.1538
9		.421	.3772	.3944	1.6004
10		.3239	.3086	.2915	.2743
11		2.4291	1.7528	2.0424	.2229
12		2.4291	2.0576	2.2558	.3086
13		2.4291	1.9814	2.1795	.3429
14		2.4291	2.0729	2.1643	.3944
15		2.4291	2.1338	2.1712	.3772
16		2.4939		2.2862	.3772
17		2.5911	1.9204	1.9204	.3772
18		1.6032	1.9338	1.8671	
19		.3353	.3048	.3963	.4287
20		.2591		.3963	.3601
21	.3725	.3239	.2286	.3887	.3239
22	.3239	.2915	.1829	.3239	.3239
23	.2915	.2591	.1677	.3239	.3239
24		.2591	.2591	.1677	.6478
Max	**.3725**	**2.5911**	**2.1338**	**2.2862**	**2.1538**
Min	**.2915**	**.2591**	**.1677**	**.1677**	**.2229**
Avg	**.3293**	**1.0045**	**.8313**	**.9011**	**.7292**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274169 / 33/11 KV Wadegaon Sub-Station
Feeder No / Name : 244 / BURLEWADI FEEDER **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2429	.2429	.2	.0972
2		.2429	.2429	.2	.0972
3		.2429	.2429	.2401	.0972
4		.3239	.2429	.2934	.0972
5		.6478	.4858	.3467	.1619
6		.8097	.8097	.5201	.3239
7		1.004	.9717	.8402	.3725
8		1.004	1.166	.9469	.3239
9		1.166	1.0059	.9907	.2229
10		.1134	.1543	.1715	.1715
11		.0972	.1372	.12	.5792
12		.0972	.1372	.1029	.9907
13		.0972	.0857	.1029	.9907
14		.0972	.0857	.0857	.9602
15		.081	.0857	.0857	.884
16		.081	.0857	.0857	1.0974
17		.1134	.0914	.1067	.9602
18		.1781	.2134	.1829	.8402
19		.2743	.2134	.2896	.2572
20		.1981	.2439	.2743	.2401
21	.1781	.1619	.1829	.2105	.1943
22	.1619	.2915	.1524	.1619	.1619
23	.1619	.2591	.1219	.1134	.1296
24		.2429	.2429	.2	.0972
Max	**.1781**	**1.166**	**1.166**	**.9907**	**1.0974**
Min	**.1619**	**.081**	**.0857**	**.0857**	**.0972**
Avg	**.1673**	**.3362**	**.3185**	**.2863**	**.4312**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274170 / 33/11 KV Akola Sub-Station
Feeder No / Name : 241 / Akola SSTn Gaothan Feeder GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2401	.2401	.2401	.2401
2		.2401	.2229	.2229	.2401
3		.2743	.2401	.2401	.2572
4		.3086	.2743	.2743	.2915
5		.463	.4115	.4115	.4458
6		.7202	.7202	.6687	.6687
7		.7716	.7716	.7716	.7888
8		.6687	.6687	.6516	.6859
9		.4287	.5658	.583	.6001
10		.3429	.3944	.5144	.5144
11		.3772	.4115	.4287	.3772
12		.3258	.3258	.3944	.3086
13		.3086	.3086	.2572	.2743
14		.3772	.3258	.3772	.2743
15		.2229	.3086	.3086	.2915
16		.3429	.3258	.3086	.3601
17	.3772	.3258	.3429	.3601	.3429
18	.4287	.4287	.4115	.4287	.4458
19	.6001	.5658	.5658	.583	.583
20	.463	.4973	.4973	.5487	.4973
21	.3944	.3944	.4458	.463	.463
22	.3601	.3429	.3429	.3772	.3772
23	.3086	.3086	.2915	.3258	.3258
24		.2401	.2401	.2401	.2743
Max	**.6001**	**.7716**	**.7716**	**.7716**	**.7888**
Min	**.3086**	**.2229**	**.2229**	**.2229**	**.2401**
Avg	**.4189**	**.3965**	**.4022**	**.4158**	**.4137**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274170 / 33/11 KV Akola Sub-Station
Feeder No / Name : 246 / DATT MANDIR AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2058	.2058	.1886	1.0802
2		.2058	.1886	.2058	.9945
3		.2229	.2229	.1715	1.0288
4		.2572	.2401	.2229	1.0802
5		.3601	.3086	.3086	1.1317
6		.5487	.4801	.3601	1.2174
7		.5144	.5144	.4973	.8745
8		.3601	.3944	.3772	.9431
9		.3258	.3086	.3086	.2572
10		.2058	.1886	.2058	.2229
11		.1715	.1543	.2058	.1886
12		.1715		.1372	.1886
13		.1543	.1372	.1372	.1372
14		.1372	.12	.1372	.1715
15		.1543	.1543	.1543	.2058
16		.1543	.1543	.1372	.12
17	2.0233	1.9376	1.8519	1.8861	.1543
18	2.3148	1.7661	2.3663	1.989	.1715
19	2.0576	1.6804	2.2462	1.9376	.2743
20	1.869	1.8176	2.0748	1.8861	.2401
21	1.8004	1.7318	1.7833	1.7147	.2058
22	1.6289	1.5089	1.6975	1.5947	.1886
23	1.5089	1.3889	1.5775	1.4232	.1715
24		1.3889	1.3375	1.406	1.2517
Max	**2.3148**	**1.9376**	**2.3663**	**1.989**	**1.2517**
Min	**1.5089**	**.1372**	**.12**	**.1372**	**.12**
Avg	**1.8861**	**.7237**	**.8134**	**.7330**	**.5208**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274170 / 33/11 KV Akola Sub-Station
Feeder No / Name : 247 / SOMNATH MANDIR AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9945	.823	.823	.1715
2		.9431	.9945	.9945	.1543
3		1.0288	1.0631	1.0631	.1715
4		1.1145	1.2003	1.2003	.2058
5		1.166	1.406	1.5432	.2401
6		1.4746	1.6804		.3086
7		2.0919	2.2634	2.0062	.3944
8			2.452	2.3148	.3258
9		.2229	.2401	.2572	1.8004
10		.1715	.2401	.2058	2.0748
11		.1886	.1886	.1715	2.1262
12		.1886	.1886	.2572	2.0748
13		.1886	.1372	.2401	2.1262
14		.1543	.1543	.2229	2.1605
15		.1543	.1886	.2058	2.1434
16		.1543	.1715	.2401	2.2291
17	.2058	.2229	.1886	.2572	.1715
18	.2572	.2229	.2229	.2743	.2572
19	.3429	.3086	.3944	.2743	.3258
20	.2743	.3086	.3429	.3429	.2915
21	.2401	.2401	.2229	.2401	.2058
22	.2229	.2229	.2229	.2058	.1886
23	.1715	.1715	.1715	.1886	.1715
24		.1372	.1372	.1543	.1715
Max	**.3429**	**2.0919**	**2.452**	**2.3148**	**2.2291**
Min	**.1715**	**.1372**	**.1372**	**.1543**	**.1543**
Avg	**.2450**	**.5248**	**.6373**	**.5949**	**.8538**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274170 / 33/11 KV Akola Sub-Station
Feeder No / Name : 248 / AKOLA AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.1372	.1715	.1886
2		.1715	.1372	.1715	.1715
3		.1886	.1543	.1886	.1886
4		.1886	.1715	.2058	.2058
5		.2229	.2058	.2229	.2229
6		.2229	.2915	.2743	.2743
7		.3258	.3086	.2915	.2058
8		.2572	.2915	.3601	.3086
9		1.2517	1.3889	1.4232	.2572
10		1.4232	1.749	1.5775	.2401
11		1.6118	1.7661	1.749	.2058
12		1.5604	1.7661	1.7147	.1886
13		1.4232	1.5947	1.5947	.2058
14		1.4403	1.4232	1.5947	.2058
15		1.4232		1.7318	.2058
16		1.5089	1.5604	1.6632	.2229
17	.1543		.1372	.1543	1.749
18	.1543	.2058	.2743	.1715	1.9547
19	.2401	.2743	.3601	.2229	1.6118
20	.2401	.2229	.3086	.2743	1.5947
21	.2229	.2229	.2401	.2401	1.5089
22	.2229	.2058	.2058	.2229	1.4575
23	.2058	.1715	.1715	.2058	1.3717
24		.1715	.1543	.1886	.1886
Max	**.2401**	**1.6118**	**1.7661**	**1.749**	**1.9547**
Min	**.1543**	**.1715**	**.1372**	**.1543**	**.1715**
Avg	**.2058**	**.6464**	**.6434**	**.6923**	**.6223**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274172 / 33/11 kv KATAFAL SUBSTATION
Feeder No / Name : 201 / 11 KV KATAFAL FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1658	.1658	.1326	1.5746
2		.1492	.1658	.116	1.6575
3		.1658	.1823	.116	1.7072
4		.2321	.1989	.1823	1.8233
5		.2652	.2486	.2652	
6		.2818	.3149	.2984	
7	.3149	.3315	.3149	.3315	
8	.2984		.2984	.2818	2.6686
9		.1823	.1989	.2155	3.3979
10		.1492	.116	.1326	.1989
11		2.6852	2.6023	2.6023	.116
12		2.9007	3.1659		.0995
13		3.315	3.199		.116
14		3.3648	2.9835		.116
15	3.1327	2.7846	3.3648		.0995
16	3.3979	3.0996	3.1824		.116
17	3.199	3.3813	2.7681		.116
18	3.1493	2.652	1.9393	2.0056	.1658
19	.2818	.2818	.2652	.2818	.2652
20	.2486	.2486	.2486	.2486	.2321
21	.2321	.2155	.2155	.2321	.2155
22	.2155	.2155	.1823	.1989	.1989
23	.1823	.1989	.1658	.1823	.1989
24		.1823	.1823	.1492	1.5415
Max	**3.3979**	**3.3813**	**3.3648**	**2.6023**	**3.3979**
Min	**.1823**	**.1492**	**.116**	**.116**	**.0995**
Avg	**1.3320**	**1.1934**	**1.1112**	**.4429**	**.7917**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274172 / 33/11 kv KATAFAL SUBSTATION
Feeder No / Name : 202 / 11 KV ITAKI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3077	.3077	.2915	.0486
2		.2915	.3401	.3239	.0486
3		.3239	.3563	.3887	.0486
4		.3887	.4049	.6154	.0486
5		.4696	.502	.6964	.0648
6		.502	.5668	.7611	.0648
7	.8745	.8421	.8259	.8421	.081
8	.9717	.9878	1.0364	.8907	.0972
9		.8907	.8907	.9069	.0648
10		.0486	.0324	.0486	.0486
11		.0486	.0324	.0324	.8097
12		.0324	.0324		1.0202
13		.0324	.0324		1.1336
14		.0324	.0324		1.0526
15	.0324	.0324	.0324		.9717
16	.0324	.0324	.0324		1.0364
17	.0324	.0324	.0324		.9717
18	.0486	.0486	.0324	.081	.7611
19	.081	.0648	.0648	.081	.0972
20	.0648	.0648	.0648	.081	.081
21	.0486	.0648	.0486	.0486	.0648
22	.0486	.0648	.0486	.0486	.0648
23	.0324	.0486	.0324	.0486	
24		.2753	.2915	.3077	.0486
Max	**.9717**	**.9878**	**1.0364**	**.9069**	**1.1336**
Min	**.0324**	**.0324**	**.0324**	**.0324**	**.0486**
Avg	**.2061**	**.2470**	**.2530**	**.3608**	**.3795**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274172 / 33/11 kv KATAFAL SUBSTATION
Feeder No / Name : 203 / KATAFAL GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0934	.0934	.0934	.112
2			.0934	.0934	.0747	.0934
3			.112	.112	.0934	.0934
4			.1494	.1307	.1494	.112
5			.2054	.168	.2241	.168
6			.2427	.2241	.2427	.2347
7		.3174	.2801	.2987	.2801	.3361
8		.2801	.2614	.2614	.2614	.2427
9	.1494		.1867	.2241	.2054	.2614
10			.168	.2054	.168	.1867
11			.112	.1307	.112	.1307
12			.0934	.0934		.0934
13	.1307		.0934	.0934		.056
14	.0747		.0747	.0934		.0747
15	.112	.112	.0747	.0747		.0934
16	.112	.1494	.112	.0934		.1307
17	.1867	.168	.1494	.112		.112
18		.2054	.1867	.168	.2241	.168
19	.2614	.2427	.2801	.2427	.3734	.2801
20	.2427	.2241	.2241	.2241	.2987	.2054
21	.1867	.1867	.168	.1867	.2054	
22	.168	.168	.1494	.168	.168	.1494
23	.1307	.112	.112	.1307	.1494	.1307
24			.112	.112	.112	.1307
Max	**.2614**	**.3174**	**.2801**	**.2987**	**.3734**	**.3361**
Min	**.0747**	**.112**	**.0747**	**.0747**	**.0747**	**.056**
Avg	**.1595**	**.1969**	**.1556**	**.1556**	**.1909**	**.1563**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274173 / NIJAMPUR(MANEGAON)
Feeder No / Name : 244 / MANEGAON GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0857	.1372	.081	.0857
2		.1029	.1372	.081	.1029
3		.0857	.1715	.081	.0857
4		.1029	.2058	.0972	.12
5		.1543	.2058	.1134	.1886
6		.2229	.2229	.1296	.2401
7		.2058	.2401	.1619	.2743
8		.1886	.1715	.1781	.2058
9	.1715	.1372	.1134	.1781	.12
10	.12	.12	.1134	.0686	.0857
11	.1029	.0686	.0972	.1029	.0857
12	.1029	.0857	.081		.0686
13	.0857	.1029	.0486		.0514
14	.0686	.0686	.081		.0857
15	.0686	.0514			.0686
16	.0857	.0686			.0857
17	.1029	.1029	.1296	.12	.1715
18	.1715	.1543	.1619	.2229	.2058
19	.2058	.1543	.1781	.2058	.1886
20	.1543	.1372	.1619	.2229	.1543
21	.12	.1029	.1296	.1715	.1372
22	.1029	.0857	.0972	.1543	.1029
23	.0857	.0857	.0972	.1029	.0857
24		.0857	.12	.081	.1029
Max	**.2058**	**.2229**	**.2401**	**.2229**	**.2743**
Min	**.0686**	**.0514**	**.0486**	**.0686**	**.0514**
Avg	**.1166**	**.1150**	**.1410**	**.1344**	**.1293**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274173 / NIJAMPUR(MANEGAON)
Feeder No / Name : 249 / NIJAMPUR AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2753	.2915	.2915	.7287
2		.2591	.3077	.3077	.8421
3		.2915	.3401	.3077	.9878
4		.2915	.3887	.3077	1.085
5		.4049	.421	.4696	1.4413
6		.4858	.4372	.4858	1.668
7		.4696	.4858	.421	2.0405
8		.3725	.3887	.3887	2.2024
9	.3563	.3239	.2267	.3887	1.7004
10	.2429	.2267	.2267	.2401	.1781
11	1.5061	1.8299	1.8461	1.4575	.1619
12	1.9757	1.9271	2.1052	1.9271	.2591
13	2.0243	1.7328	1.8461		.2267
14	1.9595	1.7814	2.0243		.1943
15	1.9919	1.8785	1.9433		.1619
16	1.9109	1.7004	1.7814		.1781
17	1.8785	1.6842		1.3279	.2105
18	1.8138	1.668		1.6194	.3239
19	.3887	.4372	1.7814	.3239	.4534
20	.3401	.3401	1.6194	.3401	.3887
21	.3563	.3077	.3563	.3401	.3563
22	.3239	.2753	.3239	.3077	.3239
23	.3077	.2429	.2915	.2591	.3077
24		.2591	.2591	.2591	.5992
Max	**2.0243**	**1.9271**	**2.1052**	**1.9271**	**2.2024**
Min	**.2429**	**.2267**	**.2267**	**.2401**	**.1619**
Avg	**1.1584**	**.8111**	**.8951**	**.5885**	**.7092**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274173 / NIJAMPUR(MANEGAON)
Feeder No / Name : 251 / DONGARGAON AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.442	.5335	.4858	.3725
2		.5487	.5944	.4858	.3725
3		.6554	.6859	.5668	.3887
4		.884	.8993	.6478	.421
5		1.0822	1.1431	.9717	.4534
6		1.2955	1.3413	1.2955	.4858
7		1.4022	1.4632	1.5384	.4696
8		1.6613	1.768	1.7004	.3725
9	1.448	1.4632	1.6518	1.7004	.2439
10	.1981	.1524	.2591	.2743	.2743
11	.1829	.1524	.3239	.3201	1.3717
12	.1829	.1372	.2915	.3506	1.5089
13	.1677	.1219	.2915		
14	.1829	.1677	.2429		
15	.1981	.1981	.3239		
16	.1981	.1829	.3239		.4877
17	.2591	.2896	.3563	.2743	.0655
18	.2896	.3506	.3887	.2743	.8535
19	.442	.4725	.4534	.4115	.1219
20	.4115	.4725	.502	.3658	.1677
21	.4268	.442	.4858	.381	.2439
22	.4115	.4115	.421	.3658	.1981
23	.4115	.381	.4858	.3506	.1067
24		.381	.442	.4858	.3887
Max	**1.448**	**1.6613**	**1.768**	**1.7004**	**1.5089**
Min	**.1677**	**.1219**	**.2429**	**.2743**	**.0655**
Avg	**.3607**	**.5728**	**.6530**	**.6623**	**.4461**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274178 / SHIVANE
Feeder No / Name : 241 / SHIVANE **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7545	.7716	.6859	.463
2		.823	.7888	.6859	.4973
3		.8916	.823	.7716	.5144
4		.9431	.8916	1.2003	.6001
5		1.166	1.0288	1.3203	.6859
6		1.5432	1.5604	1.7318	.703
7		1.9547	1.7147	1.8519	
8		1.9547	2.0748	1.869	.5487
9		1.9376	1.9033	1.9204	
10		.3086	.2572	.2743	.2915
11		.2401	.2572	.2572	1.9204
12		.2229	.2572	.2401	1.9376
13		.2229	.2572	.2401	2.1605
14	.2572	.2058	.2401	.2572	1.7318
15	.2401	.2401	.2229	.2572	2.0576
16	.2401	.2229	.2572	.2743	2.0748
17	.3258	.2915	.3086	.3429	
18	.4115	.3944	.3601	.4973	1.8519
19	.4287	.4801	.4801	.583	.583
20	.5316	.4287	.463	.5487	.5487
21	.4287	.4115	.4458	.5144	.4973
22	.3944	.3944	.4287	.463	.3429
23	.3429	.3258	.3772	.4115	.5144
24		.5487	.6001	.6001	.4458
Max	**.5316**	**1.9547**	**2.0748**	**1.9204**	**2.1605**
Min	**.2401**	**.2058**	**.2229**	**.2401**	**.2915**
Avg	**.3601**	**.7045**	**.6987**	**.7416**	**.9986**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274178 / SHIVANE
Feeder No / Name : 242 / WAKI SHIVANE SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2267	.2429	.1943	.8421
2		.2743	.2591	.2105	.8421
3		.2591	.2915	.2267	.8745
4		.3239	.2915	.2267	.9393
5		.3725	.3401	.2753	1.004
6		.3563	.3725	.3401	1.1174
7		.3887	.4049	.3887	1.5546
8		.3239	.3401	.3239	2.0567
9		.2429	.2591	.2429	1.7814
10		.1715	.1619	.1619	.1457
11		1.5223	1.6518	1.668	.0972
12		1.8785	1.9433	1.9757	.0972
13		1.9595	2.0567	1.9757	.0972
14	1.8785	1.8947	1.9433	1.9595	.0972
15	1.9595	1.8947	1.9109	2.0119	.1134
16	1.5708	1.9757	2.0081	1.9271	.1296
17	1.7166	1.9919	1.9433	1.8299	.1457
18	1.6518	1.749	1.5089	1.7004	.2429
19	.2429	.2753	.2753	.2915	.3239
20	.2591	.2591	.2591	.2591	.2915
21	.2591	.2429	.2267	.2267	.2429
22	.2105	.2105	.2105	.2105	.2267
23	.2105	.2267	.1943	.2105	.2105
24		.1943	.2105	.1943	.7611
Max	**1.9595**	**1.9919**	**2.0567**	**2.0119**	**2.0567**
Min	**.2105**	**.1715**	**.1619**	**.1619**	**.0972**
Avg	**.9959**	**.8006**	**.8044**	**.7930**	**.5931**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274178 / SHIVANE
Feeder No / Name : 243 / GALVEWADI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1029	.0857		.4287
2		.0857	.0857		.463
3			.0857		.4973
4		.1029	.0857	.1029	.5487
5			.12		.6516
6		.1715	.1543		.7888
7		.1715	.1886	.2401	1.0288
8		.1543	.1715	.1886	1.166
9			.1372	.1886	.9774
10		.1029	.0857		.0857
11		.9602	.9259	1.0117	.0857
12		1.1488	1.0631	1.166	.0686
13		1.2174	1.1488	1.1831	.0686
14	1.166	1.166	1.1488	1.1317	.0686
15	1.0631	1.1488	1.1488	1.0974	.0857
16	1.1488	1.166	1.1317	1.0974	.1029
17	1.1317	1.1145	1.1145	1.1145	.1029
18	1.1145	.9945	1.0802	1.0802	.1715
19	.1543	.1886	.1886	.2058	
20	.1715	.1543	.1715	.1543	.1543
21	.12	.12	.1543	.1543	
22	.1372	.1029	.1029	.1029	
23	.0686	.0857	.1029	.0857	.1029
24		.0857	.1029	.0857	.3429
Max	**1.166**	**1.2174**	**1.1488**	**1.1831**	**1.166**
Min	**.0686**	**.0857**	**.0857**	**.0857**	**.0686**
Avg	**.6276**	**.5021**	**.4494**	**.5773**	**.3805**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274239 / 33/11KV WATAMBARE
Feeder No / Name : 201 / WATAMBARE GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1543	.1715	.12	.1543	.1372	.12
2	.1372	.1543	.1715	.1372	.1543	.1543	.1543
3	.1543	.1886	.1886	.1029	.1543	.1715	.1372
4	.1715	.2058	.1886	.12	.1715	.1715	.1543
5	.1886	.2229	.2058	.1543	.2058	.2058	.1715
6	.2058	.2401	.2058	.1715	.2229	.2401	.1886
7	.2401	.2401	.2229	.1886	.2401	.2572	.1715
8	.12	.1886	.1715	.2058		.1715	.2058
9	.1372	.1715	.1372	.0857	.1543	.1543	.1029
10	.12	.1715	.1715	.1029	.12	.1372	
11	.1715	.1715	.1372	.1372	.1029	.1029	.1543
12	.1543	.1886	.1543	.1372	.1029	.1029	.1543
13	.1543	.1715	.12	.12	.1029	.1372	.1372
14	.1543	.1543	.1372		.12	.1543	.1372
15	.1372	.1372	.1543	.12	.12	.12	.1372
16	.1372	.1543	.12	.1543	.1372	.1715	.1372
17	.1372	.1715	.1543	.1543	.1543	.12	
18	.1543	.1715	.1372	.1886	.1715	.1372	.1886
19	.2058	.2229	.1715	.1886	.2058	.2401	.2058
20	.1886	.2058	.1543	.2058	.1886	.1543	.2229
21	.1886	.1715	.1715	.1886	.1715	.1715	.2058
22	.1715	.1543	.1543	.1715	.1543	.2058	.1886
23	.1715	.1543	.1372	.1715	.1372	.1372	.1715
24	.1029	.1543	.1543	.1029	.1543	.1372	.1029
Max	**.2401**	**.2401**	**.2229**	**.2058**	**.2401**	**.2572**	**.2229**
Min	**.1029**	**.1372**	**.12**	**.0857**	**.1029**	**.1029**	**.1029**
Avg	**.1593**	**.1801**	**.1622**	**.1491**	**.1566**	**.1622**	**.1613**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274239 / 33/11KV WATAMBARE
Feeder No / Name : 202 / 11 KV WATAMBARE AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1886	.2058	1.0631	.9602	.9431	.1543
2	.2058	.2058	.2058	1.2003	1.0288	1.1145	.1715
3	.2572	.3086	.2401	1.3375	1.2346	1.2003	.1886
4	.2743	.3258	.2401	1.4746	1.286	1.2146	.2058
5	.2915	.3429	.2743	1.6118	1.3717	1.4575	.2229
6	.3086	.3601	.2743	1.749	1.4918	1.6289	.2401
7	.3429	.3429	.3086	1.9376	1.5775	1.7833	.2572
8		.2229	.2572	2.0919	1.749	1.8861	.2743
9		.2058	.2229	1.9547	1.7147	1.8519	.2058
10		.1715	.1715	.1372	.1372	.1715	
11		1.8861	1.7833	.1715	.1029	.1715	1.4403
12	1.3717		1.8004	.1543	.1029	.0686	1.5432
13	1.7833	1.3717	1.7147	.1543	.1029	.1029	1.749
14	1.7147	1.8176	1.8861		.1372	.0686	1.9204
15	1.7833	1.8861	1.7833	.1543	.1543	.1372	1.8861
16	1.8861	1.9204	1.8861	.1715	.1715	.1543	1.7147
17	1.4403	1.989	1.869	1.7661	.2058	.1715	
18	1.6804	1.8861	1.8519	.2058	.2229	.2058	1.6461
19	.2743	.2572	.2401	.2058	.2572	.3086	
20	.2401	.2401	.1715	.2401	.2401	.2572	
21	.2229	.2058	.2058	.2229	.2229	.2401	
22	.2229	.1886	.1715	.2058	.2058	.2058	.1886
23	.2058	.1715	.1715	.1886	.1715	.1886	
24	.1372	.1886	.1715	.9259	.8916	.8573	.1372
Max	**1.8861**	**1.989**	**1.8861**	**2.0919**	**1.749**	**1.8861**	**1.9204**
Min	**.1372**	**.1715**	**.1715**	**.1372**	**.1029**	**.0686**	**.1372**
Avg	**.7407**	**.7254**	**.7545**	**.8402**	**.6559**	**.6829**	**.7859**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 274239 / 33/11KV WATAMBARE
Feeder No / Name : 203 / 11 KV ANAKDHAL AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9088	.8573	.8573	.0857	.12	.1029	
2	1.1488	1.0288	.9431	.1029	.12	.1029	.9774
3	1.2174	1.1145	1.0288	.12	.12	.1372	1.1145
4	1.3032	1.286	1.1145	.1372	.1372	.1715	1.2174
5	1.406	1.406	1.286	.1543	.1715	.2058	1.3203
6	1.406	1.5089	1.4575	.1715	.2058	.2401	1.4232
7	1.4746	1.5432	1.5432	.1886	.2401	.2572	1.5604
8	1.8347	1.6289	1.6118	.2229	.2229	.1886	1.6461
9	1.5432	1.6118	1.6461	.1715	.1886	.1715	1.5775
10	.0171	.1029	.12	.1372	.1543	.1715	
11	.0857	.1029	.1029	1.6461	1.4746	.1715	.0857
12	.0857	.0857	.0857	1.7833	1.5432	1.4403	.0857
13	.0857	.0857	.2401	1.7147	1.6461	1.3717	
14	.1029	.0686	.0857			1.406	.0857
15	.0857	.0857	.1029	1.4403	1.4403		.0857
16	.0686	.0857	.0686	1.5775	1.5089		.0857
17	.1029	.1029	.0686	1.6118		1.4575	.12
18	.1543	.1372	.12	1.6461	1.5089	1.4403	
19	.1715	.1886	.1715	.1372	.1543	.2058	.1715
20	.1715	.1715	.12	.1543	.0857	.4287	.1715
21	.1543	.1543	.1372	.1372	.12	.3086	.1543
22	.1543	.12	.12	.12	.1029	.2058	.1372
23	.1372	.12	.1029	.12	.0857	.1029	.1372
24	.8573	.6859	.6859	.0686	.12	.0857	.7888
Max	**1.8347**	**1.6289**	**1.6461**	**1.7833**	**1.6461**	**1.4575**	**1.6461**
Min	**.0171**	**.0686**	**.0686**	**.0686**	**.0857**	**.0857**	**.0857**
Avg	**.6116**	**.5951**	**.5758**	**.5934**	**.5214**	**.4715**	**.6473**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 276009 / 132/33/11 KV SANGOLA S/S
Feeder No / Name : 271 / 11 KV SANGOLA U SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2572	.2572	.1715	.2572	.2572
2	.2572	.2572	.2572	.1715	.2572	.1715
3	.3429	.3429	.1715	.1715	.1715	.2572
4	.4287	.2572	.2572	.2572	.1715	.2572
5	.5144	.3429	.2572	.3429	.2572	.2572
6	.4287	.4287	.3429	.4287	.3429	.3429
7	.4287	.5144	.4287	.5144	.4287	.5144
8		.4287	.5144	.5144		.5144
9	.4287	.3429	.4287	.1715	.3429	.3429
10	.3429	.2572	.3429	.3429	.2572	.3429
11	.3429	.2572	.3429	.2572	1.3717	.3429
12		.2572	.2572		.2572	.2572
13		.2572		.2572	.2572	.2572
14		.2572	.3429	.2572	.2572	.2572
15		.2572	.2572	.2572	.2572	.2572
16		.2572	.3429	.2572	.2572	.2572
17			.3429	.2572	.2572	.3429
18		.3429	.3429	.2572	.4287	.3429
19		.4287	.4287	.5144	.4287	.4287
20		.4287	.4287	.4287	.4287	.3429
21		.3429	.3429	.4287	.3429	.3429
22		.3429	.2572	.2572	.3429	.2572
23		.2572	.2572	.2572	.2572	.2572
24	.2572	.2572	.2572	.1715	.2572	.2572
Max	**.5144**	**.5144**	**.5144**	**.5144**	**1.3717**	**.5144**
Min	**.2572**	**.2572**	**.1715**	**.1715**	**.1715**	**.1715**
Avg	**.3663**	**.3206**	**.3243**	**.3019**	**.3429**	**.3108**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 276009 / 132/33/11 KV SANGOLA S/S
Feeder No / Name : 272 / 11 KV Gherdi Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.3429	.6859	.6859	.6859	.5144
2	.3429	.3429	.6859	.6859	.6001	.4287
3	.3429	.3429	.6859	.7716	.6001	.4287
4	.5144	.5144	.8573	.9431	1.0288	.7716
5	.6859	.6001	1.0288	1.1145	1.286	1.1145
6	.6859	.6859	1.286	1.5432	1.9719	1.286
7	.6859	.6859	1.5432	2.1434	2.0576	2.0576
8	.6859	.6001	1.9719	2.3148	2.3148	1.9719
9	.5144	.5144	2.0062	2.4006	2.2291	2.4863
10	.4287	.4287	.5144	.3429	.3429	.4287
11	1.8004	2.1434	.4287	.4287	.3429	.3429
12	2.1434	2.4006	.4287	.4287	.3429	.4287
13	2.572	2.4006	.4287	.3429	.2572	.5144
14	2.915	2.4006	.3429	.3429	.3429	.4287
15	2.8292	2.4006	.4287	.3429	.3429	.4287
16	2.6578	2.4863	.5144	.3429	.3429	.5144
17	2.572	2.0576	.5144	.3429	.3429	.4287
18	2.2291	1.9719	.6001	.3429	.5144	.5144
19	.5144	.5144	.6001	.4287	.6001	.5144
20	.6001	.5144	.5144	.3429	.6001	.5144
21	.6001	.4287	.5144	.3429	.5144	.5144
22	.4287	.3429	.4287	.3429	.4287	.3429
23	.3429	.3429	.6001	.3429	.4287	.3429
24	.4287	.3429	.6001		.7716	.5144
Max	**2.915**	**2.4863**	**2.0062**	**2.4006**	**2.3148**	**2.4863**
Min	**.3429**	**.3429**	**.3429**	**.3429**	**.2572**	**.3429**
Avg	**1.1646**	**1.0753**	**.7587**	**.7679**	**.8037**	**.7430**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 276009 / 132/33/11 KV SANGOLA S/S
Feeder No / Name : 274 / 11 KV Chincholi Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.4287	.2572	.2572	.1715	.2572	.3429
2	.3429	.3429	.2572	.2572	.2572	.2572	.4287
3	.4287	.3429	.2572	***	.2572	.2572	.4287
4	.6001	.6859	.2572	.2572	.2572	.0257	.5144
5	.7716	.7716	.3429	.3429	.2572	.2572	.6001
6	.9431	.8573	.4287	.4287	.3429	.4287	.9431
7	1.3717	1.3717	.4287	.4287	.5144	.4287	1.4575
8	1.286	1.286	.4287	.4287	.4287	.4287	1.4575
9	1.3717	.3429	.3429	.2572	.3429	.3429	
10	.2572	.2572	.3429		.3086	.2572	
11	.3429	.2572	1.286	1.1145	1.1145	1.1145	
12	.2572	.3429	1.286	1.6289	1.3717	1.5432	
13	.1715	.3429	1.7147	1.7147	1.5432	1.7147	
14	.1715	.2572	1.5432	1.7147	1.8004	1.6289	
15	.2572	.3429	1.8004	1.7147	1.8004	1.6289	
16	.2572	.4287	1.4575	1.8004	1.7147	1.8004	
17	.2572	.4287	1.5432	1.7147	1.6289	1.7147	
18	.3429	.4287	1.4575		1.5432	1.5432	
19	.4287	.3429	.3429	.5144	.3429	.3429	
20	.4287	.3429	.3429	.5144	.3429	.3429	
21	.3429	.3429	.2572	.4287	.3429	.2572	
22		.3429	.2572	.2572	.3429	.2572	
23	.3429	.2572	.1715	.2572	.2572	.2572	
24	.3429	.4287	.2572		.1715		.3429
Max	**1.3717**	**1.3717**	**1.8004**	**14.4548**	**1.8004**	**1.8004**	**1.4575**
Min	**.1715**	**.2572**	**.1715**	**.2572**	**.1715**	**.0257**	**.3429**
Avg	**.5069**	**.4822**	**.7109**	**1.4518**	**.7273**	**.7429**	**.7240**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 276009 / 132/33/11 KV SANGOLA S/S
Feeder No / Name : 276 / 11 KV Mahud Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	16-DEC-17	18-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2572	.6001	.5144
2	.2572	.6001	.6001
3	.2572	.6859	.6001
4	.2572	.7716	.6859
5	.3429	1.0288	.9431
6	.5144	1.3717	1.1145
7	.6001	1.8004	1.7147
8	.5144	2.2291	1.8861
9	.3429	2.3148	2.2291
10	.3429	.3429	.2572
11	1.5432	.2572	.2572
12	2.0576	.2572	.3429
13	2.1434	.2572	.4287
14	2.0919		
15	2.1434		.3429
16	2.2291		.3429
17	2.0576		.2572
18	1.8861		.4287
19	.3429		.3429
20	.3429		.3429
21	.3429		.2572
22	.2572		.2572
23	.2572		.2572
24	.2572	.5144	.5144
Max	**2.2291**	**2.3148**	**2.2291**
Min	**.2572**	**.2572**	**.2572**
Avg	**.9016**	**.9308**	**.6486**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 276009 / 132/33/11 KV SANGOLA S/S
Feeder No / Name : 277 / 11 KV Chandolwadi SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	16-DEC-17	17-DEC-17	18-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.3429	.2572	.3429
2	.7716	.3429	.2572	.3429
3	.7716	.3429	.2572	.3429
4	1.2003	.3429	.2572	.3429
5	1.4575	.4287	.5144	.4287
6	1.8861	.5144	.6001	.6001
7	2.4863		.6001	.6001
8	2.4006	.6001	.6001	.6001
9	2.7435		.4287	.4287
10	.3429		.3429	.4287
11	.3429		2.0576	2.3148
12			2.6578	2.8292
13	.3429		2.7435	2.8292
14	.3429		2.4006	
15	.3429		2.6578	2.1434
16	.4287		2.6578	2.8292
17	.4287		2.572	2.8292
18	.5144		2.2291	2.7435
19	.6001		.5144	.5144
20	.4287		.4287	.5144
21	.4287		.4287	.4287
22			.3429	.3429
23	.3429		.3429	.2572
24	.7716	.2572	.2572	
Max	**2.7435**	**.6001**	**2.7435**	**2.8292**
Min	**.3429**	**.2572**	**.2572**	**.2572**
Avg	**.9119**	**.3965**	**1.1003**	**1.1379**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
PANDHARPUR DIVISION[536]
SANGOLA[101] BU 6343
Substation No/ Name :- 276009 / 132/33/11 KV SANGOLA S/S
Feeder No / Name : 278 / 11 KV super feeder SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	16-DEC-17	18-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4287	.4287	.3429
2	.3429	.4287	.3429
3	.3429	.4287	.3429
4	.3429	.4287	.3429
5	.3429	.4287	.3429
6	.3429	.4287	.3429
7	.3429	.4287	.3429
8	.3429	.4287	.3429
9	.4287	.4287	.3429
10	.5144	.5144	.3429
11	.6001	.6001	.3429
12	.6001	.6859	.3429
13	.4287	.6001	.3429
14	.5144	.6001	
15	.4287	.6001	.3429
16	.4287	.5144	.1715
17	.4287	.5144	.2572
18	.4801	.5144	.2572
19	.4287	.4287	.2572
20	.4287		.3429
21	.4287		.3429
22	.3429		.3429
23	.3429		.2572
24	.3429	.5144	.3429
Max	**.6001**	**.6859**	**.3429**
Min	**.3429**	**.4287**	**.1715**
Avg	**.4165**	**.4973**	**.3205**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274067 / 33/ 11 KV HANNUR S/S
Feeder No / Name : 201 / 11 KV CHUNGI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0995	1.0288	.9145
2		.0995	1.0517	.9374
3		.0995	1.0288	.9374
4		.0829	.9831	.9717
5		.0829	1.2289	1.2289
6		.116	1.3603	1.3108
7		.116	1.3927	1.3108
8		.116		
9		.0829		
10		1.7604		
11		1.8351		
12		1.7604		
13		1.8842		
14		1.8404	.0486	.0358
15		1.8842	.0486	.0537
16			.0492	.0549
17			.0497	.0549
18		.0876	.0829	.0716
19		.0895	.0829	.0895
20		.0895	.0838	.2593
21		.0876	.0838	.0895
22		.8764	.703	1.065
23	.0995	.9991	.8592	1.0402
24		.0995	1.0517	.8488
Max	**.0995**	**1.8842**	**1.3927**	**1.3108**
Min	**.0995**	**.0829**	**.0486**	**.0358**
Avg	**.0995**	**.6450**	**.6232**	**.6264**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274067 / 33/ 11 KV HANNUR S/S
Feeder No / Name : 202 / 11 KV BOREGAON AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1311		1.7966
2		.1326	1.7604	1.8185
3		.1492	1.8023	1.8404
4		.1492	1.9662	2.3758
5		.1658	2.1605	2.8673
6		.1658	2.4806	2.9007
7		.1658	2.6726	2.8673
8		.1326		
9		.1326		
10		2.9492		
11		3.1295		
12		3.1207		
14		3.1131	.0857	.08
15		3.0887	.0857	.096
16			.1017	.0983
17			.1029	.0983
18		.1638	.1052	.16
19		.192	.1772	.1966
20		.192	.2629	.2458
21		.2058	.2629	.2401
22		1.6004	1.6404	1.5565
23	.1311	1.7204	1.6975	1.6004
24		.1311	1.6804	1.7185
Max	**.1311**	**3.1295**	**2.6726**	**2.9007**
Min	**.1311**	**.1311**	**.0857**	**.08**
Avg	**.1311**	**.9967**	**1.1203**	**1.2532**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274067 / 33/ 11 KV HANNUR S/S
Feeder No / Name : 203 / 11 KV HANNUR GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.2629	.2667
2		.362	.2667
3		.362	.2629
4		.5068	.2629
5		.5068	.4001
6		.4934	.5411
7		.5921	.6173
8		.4934	.5335
9		.423	.4001
10		.4058	.3429
11		.2782	.3429
12		.2743	.2705
13		.2743	.2743
14		.2705	.2782
15		.2705	.2743
16			.2782
17			.2743
18		.3286	.2782
19		.3944	.4115
20		.4001	.4734
21		.3286	.4801
22		.3334	.2743
23	.1972	.2667	.2743
24		.2801	.2705
Max	**.1972**	**.5921**	**.6173**
Min	**.1972**	**.2629**	**.2629**
Avg	**.1972**	**.3685**	**.3479**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274067 / 33/ 11 KV HANNUR S/S
Feeder No / Name : 204 / 11 KV NANHEGAON GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3326	.2686	.2801
2	.3696	.2686	.2772
3	.3696	.2743	.2801
4	.462	.2686	.2801
5	.5487	.2686	.5601
6	.5853	.2865	.5601
7	.5121	.2865	.5601
8	.3734	.2743	.5601
9	.2801	.2561	.4668
10	.2686	.1829	.3658
11	.2686	.181	.3582
12	.1753	.1829	.2686
13	.1753	.181	.2743
14	.1753	.1867	.2686
15	.1753	.1867	.2686
16		.0934	.3292
17		.0934	.3292
18	.2629	.1867	.2686
19	.2629	.2801	.2686
20	.2686	.2801	.1791
21	.2686	.2801	.1791
22	.2743	.1848	.1829
23	.2772	.1848	.1791
24	.2801	.2743	.1353
Max	**.5853**	**.2865**	**.5601**
Min	**.1753**	**.0934**	**.1353**
Avg	**.3167**	**.2255**	**.3200**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274067 / 33/ 11 KV HANNUR S/S
Feeder No / Name : 205 / 11 KV SULTANPUR AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5535	.0164	.0166
2		.5535	.0164	.0166
3		.5376	.016	.0168
4		.5376	.016	.0166
5		.5535	.0164	.0166
6		.6009	.0164	.0168
7		.6009	.016	.0166
8			.0164	.0166
9			.0164	.0162
10			.4915	.6401
11			.4973	.7045
12			.6706	.6882
13			.6706	.6722
14		.016	.7459	.6882
15		.0164		.7202
16				.7209
17			.5304	.6882
18		.0164	.0166	.0164
19		.0164	.0168	.0164
20		.0164	.0162	.0164
21		.016	.0162	.016
22		.0164	.0164	.016
23	.5535	.0164	.0164	.0164
24		.5693	.016	.0164
Max	**.5535**	**.6009**	**.7459**	**.7209**
Min	**.5535**	**.016**	**.016**	**.016**
Avg	**.5535**	**.2898**	**.1758**	**.2411**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274067 / 33/ 11 KV HANNUR S/S
Feeder No / Name : 206 / 11 KV BAWKARWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0279	.1372	.081
2		1.1069	.0857	.0819
3		1.186	.0838	.0829
4		1.186	.0838	.0838
5		1.2651	.0819	.0829
6			.0819	.0829
7		1.4232	.08	.0838
8			.1311	.0829
9			.1638	.1341
10			1.4089	1.9524
11			1.4089	1.9685
12			1.8442	2.0805
13			1.8442	2.2119
14			1.8442	2.1605
15				2.0805
16				2.0005
17			1.5746	1.9662
18		.1372	.116	.064
19		.1753	.1174	.0848
20		.1791	.1326	.0819
21		.1791	.1326	.08
22		.1753	.0838	.08
23	.9488	.1753	.0838	.0819
24		1.0279	.1402	.0848
Max	**.9488**	**1.4232**	**1.8442**	**2.2119**
Min	**.9488**	**.1372**	**.08**	**.064**
Avg	**.9488**	**.7111**	**.5300**	**.7406**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274067 / 33/ 11 KV HANNUR S/S
Feeder No / Name : 207 / 11 KV ANV Express NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0162	.0358	.0166
2		.0162	.0351	.0166
3		.0162	.0351	.0166
4		.0162	.0343	.0168
5		.0162	.0335	.0168
6		.0162	.0164	.0166
7		.0162	.0164	.0168
8		.0162	.0166	.0166
9		.0162	.0168	.0166
10		.048	.0166	.08
11		.048	.0166	.08
12		.0492	.0168	.048
13		.032	.0168	.0492
14			.0166	.0503
15			.0166	.0335
16			.0168	.0351
17			.0166	.0351
18		.0335	.0166	.0358
19		.0343	.0168	.0358
20		.0343	.0166	.0351
21		.0343	.0166	.0351
22		.0351	.0168	.0351
23	.0162	.0351	.0166	.0171
24		.0162	.0358	.0168
Max	**.0162**	**.0492**	**.0358**	**.08**
Min	**.0162**	**.0162**	**.0164**	**.0166**
Avg	**.0162**	**.0273**	**.0212**	**.0322**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274070 / 33/11 KV NAGANSUR S/STN
Feeder No / Name : 201 / 11 KV NAVADAGI AG SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.16	.16	.16	.16	.0905	1.086
2	.16	.16	.16	.16	.0895	1.448
3	.16	.16	.16	.16	.0905	1.8099
4	.16	.16	.16	.16	.0914	1.9909
5	.16	.16	.16	.16	.181	2.1719
6	.16	.16	.16	.16	.1791	2.3529
7	.16	.16	.16	.16	.1791	2.6244
8	.16	.16	.16	.16	.1753	
9	.16	.16	.16	.16	.1677	
10	1.7604	1.5203	1.6804	1.6004	1.6766	
11	1.9204	1.7604	1.6004	1.8976	1.8442	
12	1.7604	1.9204	1.6804	1.7966	1.8442	
13	1.2003	1.9204	1.7604	1.7966	1.8442	
14	.8802	1.7604	1.6804	1.7185	1.8804	.181
15	1.7604	1.7604	1.6804	1.7185		.181
16	1.7604	1.7604	1.8404	1.6766		.181
17	1.6004	1.6804	1.6804	1.5604		.181
18	.16	.16	.16	.1791	.1791	.181
19	.16	.16	.16	.1753	.1791	.181
20	.16	.16	.16	.1734	.1791	.181
21	.16	.16	.16	.1715	.1791	.181
22	.16	.16	.16	.1753	.7164	.8145
23	.16	.16	.16	.0895	.7164	1.086
24	.16	.16	.16	.16	.0905	.8954
Max	**1.9204**	**1.9204**	**1.8404**	**1.8976**	**1.8804**	**2.6244**
Min	**.16**	**.16**	**.16**	**.0895**	**.0895**	**.181**
Avg	**.6335**	**.6935**	**.6735**	**.6804**	**.5987**	**.9849**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274070 / 33/11 KV NAGANSUR S/STN
Feeder No / Name : 203 / 11 KV Nagansur GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.543	.6335	.543	.543	.6335
2	.6335	.724	.724	.543	.6335	.6335
3	.905	.905	.905	.8145	.724	.8145
4	1.086	1.1765	1.267	.9955	.905	1.0745
5	1.3575	1.3575	1.3575	1.1765	1.1765	1.267
6	1.448	1.448	1.448	1.5384	1.448	1.448
8	1.1203	1.267	1.1765	1.3575	1.267	1.267
9	1.1765	1.086	.9955	1.086	.9955	1.1765
10	.724	.905	.724	.8145	.724	.905
11	.4858	.8145	.6335		.6335	.6335
12	.362	.6335	.4525	.4525	.4525	.543
13	.362	.4525	.362	.362	.4525	.362
14		.4525	.362	.362	.362	.362
15		.4525	.2715	.2715		.362
16	.4525	.4525	.362	.362		.4525
17	.543	.543	.4525	.4525		.543
18	.905	1.086	.724	.905	.905	.8145
19	1.1765	1.3575	.9955	1.267	1.267	1.267
20	1.086	1.1765	.8145	1.1765	1.086	1.1765
21	.8145	1.086	.724	.9955	.724	.9955
22	.6335	.6335	.543	.6335	.6335	.724
23	.905	.6335	.543	.543	.543	.6335
24	.5487	.543	.543	.543	.543	.543
Max	**1.448**	**1.448**	**1.448**	**1.5384**	**1.448**	**1.448**
Min	**.362**	**.4525**	**.2715**	**.2715**	**.362**	**.362**
Avg	**.8226**	**.8578**	**.7397**	**.7816**	**.8009**	**.8101**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274070 / 33/11 KV NAGANSUR S/STN
Feeder No / Name : 204 / 11kv Rly Station Gaothan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4525	.4525	.4525	.362	.2715	.362
2	.4525	.543	.543	.362	.2715	.4525
3	.543	.6335	.543	.362	.362	.543
4	.6335	.724	.6335	.4525	.4525	.6335
5	.724	.8145	.8145	.6335	.6335	.8145
6	.905	.905	.905	.905	.905	.905
7	.905	.8145	.724	.905	.8145	.8145
8	.6335	.724	.6335	.6335	.724	.724
9	.543	.543	.543	.543	.543	.543
10	.362	.543	.362	.362	.4525	.4525
11	.362	.4525	.2715	.362	.362	.362
12	.362	.362	.2715	.2715		.362
13	.181	.2715	.2715	.2715		.2715
14	.362		.181	.2715		.2715
15	.362		.2715	.2715		.2715
16	.362	.362	.2715	.2715		.362
17	.362	.4525	.2715	.362		.4525
18	.6335	.724	.4525	.6335	.6335	.543
19	.724	.8145	.6335	.6335	.8145	.724
20	.6335	.724	.543	.6335	.6335	.6335
21	.543	.6335	.4525	.4525	.4525	.4525
22	.362	.4525	.362	.362	.362	.362
23	.362	.4525	.362	.2715	.2715	.362
24	.362	.362	.362	.362	.2715	.362
Max	**.905**	**.905**	**.905**	**.905**	**.905**	**.905**
Min	**.181**	**.2715**	**.181**	**.2715**	**.2715**	**.2715**
Avg	**.5053**	**.5800**	**.4638**	**.4563**	**.5128**	**.5015**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274070 / 33/11 KV NAGANSUR S/STN
Feeder No / Name : 205 / 11 KV Gaudgaon Bk Ag FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905	.08	.08	.08	.08	.4001
2	.08	.08	.08	.08	.081	.4001
3	.08	.08	.08	.08	.081	.4801
4	.08	.08	.08	.08	.081	.5601
5	.08	.08	.08	.08	.081	.6401
6	.08	.08	.08	.08	.081	.7202
7	.08	.08	.08	.08	.081	.8002
8	.08	.08	.08	.08	.081	
9	.08	.08	.08	.08	.081	
10	.6401	.5601	.6401	.4801	.6478	
11	.7202	.7202	.6401	.663	.7287	
12	.8002	.7202	.6401	.4096	.8097	
13	.4801	.7202	.7202	.6478	.8097	
14	.7202	.7202	.7202	.6478	.7287	.0905
15	.6401	.7202	.7682	.6478		.0905
16	.6401	.7116	.7202	.6478		.0905
17	.5601	.6401	.6401	.6478		.0905
18	.08	.08	.08	.081	.081	.0905
19	.08	.08	.08	.081	.081	.0905
20	.08	.08	.08	.081	.081	.0905
21	.08	.08	.08	.081	.081	.0905
22	.08	.08	.08	.081	.3239	.362
23	.08	.08	.08	.081	.3239	.4525
24	.08	.08	.08	.08	.081	.4049
Max	**.8002**	**.7202**	**.7682**	**.663**	**.8097**	**.8002**
Min	**.08**	**.08**	**.08**	**.08**	**.08**	**.0905**
Avg	**.2705**	**.2830**	**.2821**	**.2532**	**.2622**	**.3302**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274071 / 33/11 KV SHIRWAL S/S
Feeder No / Name : 201 / 11 KV MOTYAL AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953		
2	.0953	.0953		
3	.0953	.0953		
4	.0953	.0953		
5	.0953	.0953		
6	.1905	.0953		
7	.2858	.1905		
10			.2858	.1905
11			.2858	.381
12			.2858	.381
13			.381	.381
14			.381	.381
15			.381	.381
16			.381	.381
17			.2858	.381
22	.0953			
23	.0953			
24	.0953	.0953		
Max	**.2858**	**.1905**	**.381**	**.381**
Min	**.0953**	**.0953**	**.2858**	**.1905**
Avg	**.1239**	**.1072**	**.3334**	**.3572**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274071 / 33/11 KV SHIRWAL S/S
Feeder No / Name : 202 / 11 KV WAGADARI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	3.2388	4.0962
2	.0953	.0953	3.2388	4.0962
3	.0953	.0953	3.2388	4.0962
4	.0953	.0953	3.2388	3.8104
5	.0953	.0953	3.2388	3.7151
6			3.1436	4.1914
7			3.9057	3.2388
10	4.2867	3.6199		
11		3.9057		
12		3.9057		
13	4.0009	3.9057		
14	4.0962	4.0009		
15	4.382	3.9057		
16	4.0009	3.8104		
17	3.8104	3.4294		
20	.0953	.0953	.0953	.0953
21	.0953	.0953	.0953	.0953
22	.0953	2.8578	3.5246	3.4294
23	.0953	3.2388	3.8104	4.0009
24	.0953	.0953	3.2388	4.0962
Max	**4.382**	**4.0009**	**3.9057**	**4.1914**
Min	**.0953**	**.0953**	**.0953**	**.0953**
Avg	**1.5956**	**2.0746**	**2.8340**	**3.2468**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274071 / 33/11 KV SHIRWAL S/S
Feeder No / Name : 203 / 11 KV SANGAVI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	1.9052	2.191
2	.0953	.0953	2.0005	2.191
3	.0953	.0953	2.0005	2.191
4	.0953	.0953	2.0005	2.2862
5	.0953	.0953		2.3815
6			2.0957	2.572
7			2.572	2.7625
10	3.0483	3.0483		
11	2.7625	3.4294		
12	3.3341	3.0483		
13	3.7151	3.2388		
14	3.4294	3.6199		
15	3.1436	3.5246		
16	2.9531	3.2388		
17	1.9052	2.8578		
20	.0953	.0953	.0953	.0953
21	.0953	.0953	.0953	.0953
22	.0953	1.6194	2.191	1.9052
23	.0953	1.8099	2.191	2.0957
24	.0953	.0953	1.9052	2.191
Max	**3.7151**	**3.6199**	**2.572**	**2.7625**
Min	**.0953**	**.0953**	**.0953**	**.0953**
Avg	**1.4025**	**1.6776**	**1.7320**	**1.9131**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274071 / 33/11 KV SHIRWAL S/S
Feeder No / Name : 204 / 11 KV Shirwal Gaothan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.381	.2858
2	.381	.381	.381	.2858
3	.381	.4763	.4763	.2858
4	.4763	.5716	.5716	.381
5	.7621	.7621	.7621	.6668
6	1.0479	.9526	.9526	.9526
7	1.2384	1.0479	1.1431	1.0479
8	.8573	.9526	1.0479	.9526
9	.7621	.7621	.5716	.7621
10	.5716	.5716	.5716	.5716
11	.4763	.381	.381	.381
12	.381	.2858	.381	.381
13	.381	.2858	.2858	.2858
14	.381	.2858	.2858	.2858
15	.381	.2858	.2858	.2858
16	.381	.2858	.2858	.2858
17	.381		.2858	.381
18	.5716	.5716		.5716
19	.8573	.8573	.7621	.7621
20	.6668	.7621	.7621	.6668
21	.5716	.5716	.5716	.5716
22	.381	.381	.381	.381
23	.381	.381	.2858	.381
24	.381	.381	.381	.2858
Max	**1.2384**	**1.0479**	**1.1431**	**1.0479**
Min	**.381**	**.2858**	**.2858**	**.2858**
Avg	**.5596**	**.5467**	**.5301**	**.5041**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274071 / 33/11 KV SHIRWAL S/S
Feeder No / Name : 205 / 11kv Wagdari Goathan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2858	.2858	.1905
2	.1905	.2858	.2858	.1905
3	.1905	.2858	.381	.1905
4	.2858	.381	.4763	.2858
5	.5716	.4763	.5716	.381
6	.8573	.7621	.7621	.5716
7	.8573	.8573	.8573	.7621
8	.7621	.7621	.7621	.7621
9	.5716		.6668	.6668
10	.381	.4763	.381	.381
11		.381	.2858	.381
12	.2858	.2858	.2858	.2858
13	.2858	.2858	.2858	.381
14	.2858	.2858	.2858	.2858
15	.2858	.2858	.2858	
16	.2858	.2858	.2858	.381
17	.2858	.381	.2858	.381
18	.4763	.5716	.4763	.5716
19	.5716	.7621	.6668	.6668
20	.5716	.7621	.5716	.5716
21	.4763	.5716	.4763	.4763
22	.381	.381	.2858	.2858
23	.2858	.2858	.2858	.2858
24	.2858	.2858	.2858	.1905
Max	**.8573**	**.8573**	**.8573**	**.7621**
Min	**.1905**	**.2858**	**.2858**	**.1905**
Avg	**.4183**	**.4515**	**.4366**	**.4142**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274071 / 33/11 KV SHIRWAL S/S
Feeder No / Name : 206 / 11kv Borgaon Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6673	3.2388	.0953	.0953
2	2.4768	3.2388	.0953	.0953
3	2.4768	3.2388	.0953	.0953
4	2.2862	3.3341	.0953	.0953
5	2.2862	3.4294	.0953	.0953
6	2.4768	3.4294		
7	3.2388	4.1914		
10			.1905	3.2388
11			3.3341	3.8104
12			3.6199	
13			3.6199	3.8104
14			3.4294	3.8104
15			3.6199	4.0009
16			3.9057	3.8104
17			2.6673	3.6199
20	.0953	.0953	.0953	.0953
21	.0953	.0953	.0953	.0953
22	3.1436	.0953	.0953	.0953
23	3.2388	.0953	.0953	
24	2.6673	3.2388	.0953	.0953
Max	**3.2388**	**4.1914**	**3.9057**	**4.0009**
Min	**.0953**	**.0953**	**.0953**	**.0953**
Avg	**2.2624**	**2.3101**	**1.4078**	**1.6849**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274072 / 33/11 KV TADWAL SUBSTATION
Feeder No / Name : 201 / 11 KV TADWAL AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4266	1.4861	.104	.1189
2	1.4266	1.4861	.1189	.1337
3	1.4415	1.5604	.1486	.1486
4	1.4563	1.5604	.1486	.1783
5	1.4861	1.6198	.1783	.1932
6	1.6495	1.709		.1932
7	2.0508	2.1251		
10			1.917	1.7238
11			1.9765	2.0018
12			2.0656	2.1399
13			1.9616	2.1674
14			2.0805	1.8873
15			2.021	2.0469
16			2.0656	2.021
17			2.0805	1.9616
19	.1486	.1635	.1635	.16
20	.1486	.1635	.1783	.1698
21	.1372	.1486	.1486	.1524
22	1.382	.1189	.1189	.104
23	1.4563	.104	.1189	.1189
24	1.4118	1.4712	.104	.1189
Max	**2.0508**	**2.1251**	**2.0805**	**2.1674**
Min	**.1372**	**.104**	**.104**	**.104**
Avg	**1.2017**	**1.0551**	**.9315**	**.8870**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274072 / 33/11 KV TADWAL SUBSTATION
Feeder No / Name : 202 / 11 KV KHANAPUR AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.061	1.5466	1.5466
2	.0566	.0617	1.5655	1.6032
3	.0566	.061	1.5655	1.6409
4	.0566	.061	1.5844	1.6975
5	.0566	.061	1.6032	1.7353
6	.0566	.061	1.6787	1.773
7			1.9993	2.0748
10	1.6766	1.9204		
11	1.7528	2.3765		
12	1.8138	2.1313		
13	1.8747	2.2822		
14	1.829	2.3011		
15	2.0576	2.2634		
16	2.0881	2.2634		
17	1.9662	2.2634		
19	.1067	.1132	.1132	.128
20	.1067	.1132	.1132	.128
21	.1067	.1132	.132	
22	.0457	1.5278	1.5278	1.7187
23	.0457	1.5278	1.5278	1.5364
24	.0566	.061	1.5466	1.5278
Max	**2.0881**	**2.3765**	**1.9993**	**2.0748**
Min	**.0457**	**.061**	**.1132**	**.128**
Avg	**.7933**	**1.0812**	**1.2695**	**1.4259**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274072 / 33/11 KV TADWAL SUBSTATION
Feeder No / Name : 203 / 11 KV MHAISALGI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0617	.0617	1.5895	1.5123
2	.0617	.0617	1.6049	1.5123
3	.0463	.0617	1.6049	1.5123
4	.0463	.0617	1.6358	1.5278
5	.0463	.0617	1.6358	1.5278
6	.0463	.0617	1.6821	1.5278
7			1.7747	1.6975
10	2.0216	1.9444		
11	2.0216	2.0988		
12	2.0988	2.1605		
13	2.1451	2.1759		
14	2.1296	2.1605		
15	2.1296	2.1451		
16	2.1605	2.1296		
17	2.1142	2.0988		
19	.1852	.1698	.1698	.2006
20	.2006	.1543	.1852	.1852
21	.2006	.1543	.2006	.1852
22	.0772	1.5741	1.4815	1.4506
23	.0617	1.5895	1.5278	1.4352
24	.0772	.0617	1.5895	1.5278
Max	**2.1605**	**2.1759**	**1.7747**	**1.6975**
Min	**.0463**	**.0617**	**.1698**	**.1852**
Avg	**.8966**	**1.0494**	**1.2832**	**1.2156**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274072 / 33/11 KV TADWAL SUBSTATION
Feeder No / Name : 204 / 11 KV MANGRUL AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3923	1.4403	.128	.112
2	1.4403	1.4403	.128	.112
3	1.4723	1.4563	.128	.128
4	1.5203	1.4723	.16	.144
5	1.5844	1.4883	.176	.16
6	1.7444	1.4883	.176	.176
7	2.2725	2.2613		
10			1.5203	1.3923
11			1.8564	2.0083
12			2.0005	2.0557
13			1.9044	1.9925
14			1.9204	1.9292
15			1.7124	1.945
16			1.8724	2.0083
17			1.7604	1.7394
19	.1898	.192	.176	.192
20	.1739	.176	.176	.176
21	.1739	.176	.176	.1581
22	1.3599	.144	.112	.112
23	1.3757	.128	.112	.1107
24	1.3923	1.4403	.128	.112
Max	**2.2725**	**2.2613**	**2.0005**	**2.0557**
Min	**.1739**	**.128**	**.112**	**.1107**
Avg	**1.2378**	**1.0233**	**.8162**	**.8382**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274072 / 33/11 KV TADWAL SUBSTATION
Feeder No / Name : 205 / 11KV TADWAL GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4755	.4075	.4207	.3841
2	.5304	.4572	.439	.4572
3	.6036	.4938	.5487	.567
4	.6767	.5487	.695	.7133
5	.7316	.6767	.823	.823
6	.7682	.8596	.8779	.8596
7	.5121			
9	.4207	.4572	.5121	.5121
10	.3292	.4024	.3841	.3658
11	.2561	.3109	.3292	.3109
12	.2561	.3292	.3109	.2743
13	.1829	.3292	.2926	.3292
14	.2012	.3109	.2743	.3292
15	.2012	.3109	.2926	.3475
16	.2195	.3292	.2195	.3841
17	.2743	.3292	.2743	.4938
18	.4024	.4207	.439	.5487
19	.6036	.6401	.6767	.7023
20	.5487	.6584	.695	.5544
21	.5121	.5487		.5487
22	.4207	.439	.6219	.4207
23	.4024	.4207	.3841	.3658
24	.4572	.4024	.4207	.3841
Max	**.7682**	**.8596**	**.8779**	**.8596**
Min	**.1829**	**.3109**	**.2195**	**.2743**
Avg	**.4342**	**.4583**	**.4729**	**.4853**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274072 / 33/11 KV TADWAL SUBSTATION
Feeder No / Name : 206 / 11 kv Gokul Mauli NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0886	.0362	.0354	.0709
2	.0886	.0362	.0354	.0532
3	.0886	.0362	.0366	.0532
4	.0886	.0362	.0354	.0532
5	.0886	.0362	.0354	.0532
6	.0709	.0362	.0532	.0532
7	.0354	.0543	.0354	.0354
8	.0532	.0543		.0354
9	.1417	.0724	.0886	.0532
10	.1448	.0905	.0709	.0886
11	.1629	.0709	.0709	.0905
12	.1629	.0886	.0886	.128
13	.0362	.0354	.0354	.0354
14	.0543	.0532	.0354	.0354
15	.0905	.0886	.0886	.128
16	.1086	.0886	.1063	.0532
17	.0905	.0886	.1063	.0537
18	.0905	.124	.1063	.1097
19	.0905	.124	.124	.1267
20	.1629	.1063	.1417	.1463
21	.1254	.0895	.1417	.128
22	.0724	.0886	.0886	.0716
23	.0543	.0532	.0633	.0543
24	.0886	.0366	.0354	.0709
Max	**.1629**	**.124**	**.1417**	**.1463**
Min	**.0354**	**.0354**	**.0354**	**.0354**
Avg	**.0950**	**.0677**	**.0721**	**.0742**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274072 / 33/11 KV TADWAL SUBSTATION
Feeder No / Name : 207 / 11 KV Mangrul Gaothan Feeder Feeder KV- 11 / OUTGOING **GAOTHAN FEEDER**

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1791	.1433	.1433	.1433
2	.197	.1612	.1433	.1433
3	.2149	.1791	.1791	.1612
4	.2507	.2149	.2149	.2328
5	.2865	.2507	.2686	.2865
6	.3045	.3045	.3403	.3224
7	.2149			
9	.1791	.2149	.197	.197
10	.1433	.1075	.1612	.1433
11	.0895	.1075	.1075	.1254
12	.1075	.1075	.1075	.1086
13	.0905	.1075	.0895	.1086
14	.0895	.1075	.0895	.0895
15	.0895	.1075	.0716	.1267
16	.1075	.1075	.0594	.1267
17	.1254	.1075	.1075	.1629
18	.1791	.197	.1612	.2172
19	.2149	.2686	.2328	.3077
20	.2172	.2865	.2507	.2896
21	.1791	.2507	.2328	.2534
22	.1448	.1433	.1433	.1433
23	.1433	.1433	.1433	.1433
24	.1791	.1433	.1433	.1433
Max	**.3045**	**.3045**	**.3403**	**.3224**
Min	**.0895**	**.1075**	**.0594**	**.0895**
Avg	**.1707**	**.1710**	**.1631**	**.1807**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274086 / 33/11 KV KARAJGI
Feeder No / Name : 201 / 11 KV HILLI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	16-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)
1	.5658	.0686
2	.6001	.0686
3		.0686
4		.0686
5		.0686
6		.0686
7		.0686
8		.0358
10		.9431
11		1.0288
12		1.1145
13		1.0974
14		1.0974
15		1.0974
16		1.0974
17		1.1145
18		.0686
19		.0686
20	.0343	
21	.0343	.0343
22	.0343	.0343
23	.5316	.0343
24	.6001	.0686
Max	**.6001**	**1.1145**
Min	**.0343**	**.0343**
Avg	**.3429**	**.4280**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274086 / 33/11 KV KARAJGI
Feeder No / Name : 202 / 11 KV HANDRAL AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	16-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)
1	.1029	1.3717
2	.12	1.406
3	.12	
4	.12	1.4575
5	.12	1.5089
6	.1372	1.5432
7	.1372	2.0576
8	.1029	.0857
9	.0857	.1029
10	1.8861	.0857
11	2.1776	
12	2.2977	.0686
13	2.332	
14	2.2291	.0686
15	2.0748	.0514
16	2.0919	.0514
17		.0686
18		.1029
19		.1029
20	.1543	.12
21	.1543	.12
22	.1372	1.3717
23	.1372	1.2689
24	.12	1.3717
Max	**2.332**	**2.0576**
Min	**.0857**	**.0514**
Avg	**.8018**	**.6850**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274086 / 33/11 KV KARAJGI
Feeder No / Name : 204 / 11KV KARJAGI GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)
1	.2229	.5144
2	.2229	.5144
3	.3086	.5487
4		.583
5	.3772	.6173
7		.6344
8	.5487	.6001
9		.5658
10	.4115	.3772
11	.3429	.3086
12	.3086	.3086
14	.3086	
15	.3258	
16	.3429	
17	.4287	.2743
18		.3086
19	.5144	.3429
20	.5487	
21	.6173	.2915
22	.3086	.2401
23	.2572	.2058
24	.2572	.4801
Max	**.6173**	**.6344**
Min	**.2229**	**.2058**
Avg	**.3696**	**.4287**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274086 / 33/11 KV KARAJGI
Feeder No / Name : 205 / 11 KV HILLI GAONTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)
1	.1715	.3429
2	.1886	.3601
3	.1886	.3944
4	.3086	.4287
5	.3429	.4287
6	.463	.463
7	.4973	.4801
8		.3772
9		.3086
10		.1715
11		.1372
12		.1543
13		.1543
14		.1715
15		.1543
16		.1715
17		.2058
18		.3086
19		.3429
20	.4115	.3601
21	.3429	.2058
22	.2572	.1543
23	.2401	.3601
24	.1715	
Max	**.4973**	**.4801**
Min	**.1715**	**.1372**
Avg	**.2986**	**.2885**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274086 / 33/11 KV KARAJGI
Feeder No / Name : 206 / 11 KV JEUR AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	16-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)
1	.6859	.0857
2	.8573	.0857
3	.8916	.0857
4	1.0288	.0857
5	1.2003	.0857
6	1.8004	.0857
7	1.869	.0857
8	.12	.0857
9	.0857	.0857
10	.0857	.0857
11	.0857	
12	.0857	1.2003
13	.0857	
14	.0857	
15	.0857	
16	.0857	.5487
17	.0857	.4458
18	.0857	.0686
19	.0857	.0686
20	.0857	.0857
21	.0857	.0857
22	.7202	.7373
23		.1029
24	.6859	.0857
Max	**1.869**	**1.2003**
Min	**.0857**	**.0686**
Avg	**.4771**	**.2143**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274103 / 33/11 KV KORSEGAON S/S
Feeder No / Name : 201 / 11 KV SHEGAON MIX AG SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.286	.7621	.5201	.6859
2		1.286	.7621	.5201	.6935
3		1.286	1.0669	.5144	.6068
4		1.286	1.0669	.5201	.6068
5		1.3717	1.0669	.5201	.6859
6		1.3717	1.3927	.5144	.6859
7		1.6289	1.6385		
8				1.4575	1.6004
9				1.6004	1.6604
10			1.6604	.4915	1.7394
11				2.0005	1.7966
12					1.8747
13				1.6604	1.8976
14		.6401	.6201	1.9204	1.8976
15		.6401	.6201	1.9766	1.3441
16		.7316	.6201		
19	.5544	.5487	.6201	.6935	.6201
20	.5544	.5487	.5258	.6935	.6135
21	.5544	.5487	.5316	.6859	.6201
22	.5544	.5487	.5316	.6859	.6135
23	.5544	.5487	.5316	.6935	.6135
24		1.286	.7621	.5144	.6935
Max	**.5544**	**1.6289**	**1.6604**	**2.0005**	**1.8976**
Min	**.5544**	**.5487**	**.5258**	**.4915**	**.6068**
Avg	**.5544**	**.9724**	**.8694**	**.9570**	**1.0775**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274103 / 33/11 KV KORSEGAON S/S
Feeder No / Name : 202 / 11 KV S.JAWALAGE MIX AG SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8669	1.2193	.1715	.1753
2		.8669	1.2193	.1715	.1734
3		.8669	1.4575	.1715	.1715
4		.8669	1.4575	.1734	.1734
5		1.3717	1.4575	.0857	.1715
6		1.8233	1.6385	.1715	.1734
7		2.3205			
10				1.6194	1.5813
11				1.6194	1.5623
12					1.5813
13				1.5384	1.5813
14		.1829	.1734	1.5384	1.5813
15		.1829	.1715	1.6385	1.406
16		.1829	.1715	1.6385	1.4232
17				1.6004	1.406
19	.2801	.1829	.1734	.1753	
20	.2801	.1829	.1753	.1734	
21	.2801	.1829	.1734	.1715	.1772
22	.2801	.1829	.1715	.1753	.1753
23	.2801	.1829	.1753	.0867	.1753
24		.8669	1.2193	.1734	.1734
Max	**.2801**	**2.3205**	**1.6385**	**1.6385**	**1.5813**
Min	**.2801**	**.1829**	**.1715**	**.0857**	**.1715**
Avg	**.2801**	**.7071**	**.7369**	**.6891**	**.7701**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274103 / 33/11 KV KORSEGAON S/S
Feeder No / Name : 203 / 11 KV KORSEGAON MIX AG SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3696	.2743	.3467	.3582
2		.3696	.2743	.3429	.3506
3		.3696	.2743	.3467	.3467
4		.3696	.3658	.3506	.3467
5		.3696	.3658	.3429	.3467
6		.3696	.3658	.0867	.3467
8		1.6956	1.6385		
9		1.6385	1.5623		
10		1.6385	1.6604		
11		1.6385	1.6604		
12		1.6385	1.5813		
13		1.6385	1.5813		
14		1.6385	1.5813		
15		1.6385	1.5813		
16				1.7604	1.6604
17				1.7604	1.6404
18				1.6004	1.6404
19	.3696	.2743	.362	1.6604	1.5432
20	.3696	.2743	.3544	1.6804	1.5813
21	.3696	.2743	.3506	1.5813	1.5623
22	.3696	.2743	.3506	1.6004	1.5623
23	.3696	.2743	.3506	1.4403	1.5813
24		.3696	.2743	.3467	.3467
Max	**.3696**	**1.6956**	**1.6604**	**1.7604**	**1.6604**
Min	**.3696**	**.2743**	**.2743**	**.0867**	**.3467**
Avg	**.3696**	**.8562**	**.8405**	**1.0165**	**1.0143**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274103 / 33/11 KV KORSEGAON S/S
Feeder No / Name : 204 / 11 KV KUMTHA MIX FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0943	.0914	.3239	.3277
2			.0943	.0914	.3391	.3277
3			.0943	.0914	.3277	.3201
4			.0943	.0914	.3239	.3277
5			.0943	.0914	.3277	.3239
6			.0943	.0914	.3277	.3239
7					.3239	.3277
10			.3048	.3201	.3125	
11			.3048	.3277	.3163	
12			.3048	.3239	.3163	
13			.3048	.3201	.3163	
14			.3048	.3201	.3125	.0088
15			.3048	.3163	.3163	.0089
16			.3048	.3201	.3163	
17		.2658	.3048	.3201	.3163	
19		.0943	.0914	.0857	.0857	.0088
20		.0943	.0914	.0867	.0089	.0089
21		.0943	.0914	.0857	.0088	.0089
22	.0088	.0943	.0914	.0867	.0089	.0089
23		.0943	.0914	.0857	.3163	.0088
24			.0943	.0914	.3277	.3201
Max	**.0088**	**.2658**	**.3048**	**.3277**	**.3391**	**.3277**
Min	**.0088**	**.0943**	**.0914**	**.0857**	**.0088**	**.0088**
Avg	**.0088**	**.1229**	**.1778**	**.1819**	**.2654**	**.1774**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274103 / 33/11 KV KORSEGAON S/S
Feeder No / Name : 205 / 11 KV KALKARJAL MIX FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0943	.0914	1.8023	1.4403
2		.0943	.0914	1.7604	1.4232
3		.0943	.0914	1.7814	1.6194
4		.0943	.0914	1.7604	1.6004
5		.0943	.0914	1.8404	1.7604
6		.0943	.0914	1.8842	1.7604
7				1.8623	1.8976
14				.0857	.0088
15				.0867	.009
16		1.9662	2.1348	.0857	.0088
17	2.0481	1.9662	1.8976		
18	2.0481	1.8842	1.8976		
19	1.9662	1.8023	1.8976	.0857	.0088
20	1.9662	1.8023	1.8976	.0857	.0088
21	1.9662	1.8023	1.7394	.0867	.0089
22	1.9662	1.8023	1.7394	.0867	.0088
23	1.9662	1.8023	1.7394	.0857	
24		.0943	.0914	1.7814	1.4403
Max	**2.0481**	**1.9662**	**2.1348**	**1.8842**	**1.8976**
Min	**1.9662**	**.0943**	**.0914**	**.0857**	**.0088**
Avg	**1.9896**	**1.0325**	**1.0389**	**.9476**	**.8669**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274107 / 33/11 KV DUDHANI S/STN
Feeder No / Name : 201 / 11 KV RUDDEWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.307	1.4937	1.7556	1.5154	1.4937	1.7737	.0377
2	1.386	1.6632	1.7375	1.9044	1.5708	1.848	.0377
3	1.6095	2.0119	1.6289	1.9022	1.6289	2.0328	.0373
4	1.6827	2.1033	1.6118	1.9909	1.6108	2.3411	
5	2.0008	2.0719	1.7804	2.0698	1.6598	2.2786	
6	2.1548	2.2119	2.0719	2.0687	1.7604	2.3663	
7	2.2939	2.4291	2.13	2.1548	2.3537	2.3739	
10							2.4949
11							2.4926
13							2.3205
14							2.3266
15							2.4249
19	.037	.0739	.037	.037	.037	.0373	.037
20	.0373	.0747	.0366		.037	.037	.0373
21	.0377	.0747	.037	.037	.0373	.037	.037
22	1.4937	1.4784	1.2567	1.2197	.5544	.037	.0373
23	1.6632	1.7737	1.3169	1.307	.8775	.0373	.0373
24	1.1203	1.8671	1.7556	1.4937	1.4937	.9335	.0373
Max	**2.2939**	**2.4291**	**2.13**	**2.1548**	**2.3537**	**2.3739**	**2.4949**
Min	**.037**	**.0739**	**.0366**	**.037**	**.037**	**.037**	**.037**
Avg	**1.2941**	**1.4867**	**1.3197**	**1.4751**	**1.1627**	**1.2410**	**.8854**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274107 / 33/11 KV DUDHANI S/STN
Feeder No / Name : 202 / 11 KV BOROTI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0377	.056	.0373	.037	.0373	1.0269
2	.0373	.0373	.056	.0377	.0373	.0377	1.2136
3	.0377	.0377	.0566	.0373	.0373	.0377	1.2936
4							1.2803
5							1.1765
6							1.1393
7							1.7528
10	1.2936	.7392	1.3306	1.2012	1.1643	1.4632	
11	1.6461	1.6461	1.6461	1.7558	1.6956		
12	1.97	1.7528	1.6476	1.9669	1.8233		
13	2.2043	1.4413	1.7635	1.873	1.989		
14	2.2119	1.8233	1.7901	1.8515	1.8023		
15	1.989	1.8023	1.8023	1.8842	1.2955		
16	2.2939	1.8023	1.8138	1.8299	1.4089		
17	1.4575	1.7004	1.5074	1.7004	1.4575	.9339	
19	.037	.056	.0554	.0366	.037	.037	.037
20	.037	.056	.056		.037	.037	.037
21	.0366	.0566	.0373	.037	.0373	.0373	.0373
22	.0373	.056	.0373	.0373	.0373	.462	.499
23	.0373	.056	.037	.0373	.0373	.6584	.5975
24	.0377	.0373	.0566	.0373	.0373	.0373	.8871
Max	**2.2939**	**1.8233**	**1.8138**	**1.9669**	**1.989**	**1.4632**	**1.7528**
Min	**.0366**	**.0373**	**.037**	**.0366**	**.037**	**.037**	**.037**
Avg	**.9060**	**.7728**	**.8088**	**.8975**	**.7630**	**.3435**	**.8445**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274107 / 33/11 KV DUDHANI S/STN
Feeder No / Name : 203 / 11 KV DUDHANI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5544	.4481	.6283	.4066	.4481	.6908	.0377
2	.5975	.5544	.6348	.4481	.4481	.7392	.0377
3	.6219	.5914	.5914	.4805	.4066	.8131	.0377
4	.6878	.6283	.5853	.6154	.362	.8596	
5	.631	.6584	.6268	.6783	.3403	.8954	
6	.4239	.6661	.7011	.6962	.3856	.964	
7	.547	.7011	.8413	.6226	.4382		
10							.6838
11							1.0164
13							.6783
14							.8288
15							.852
19	.037	.037	.037	.0373	.037	.037	.037
20	.037	.0373	.0373		.0373	.0373	.0373
21	.0373	.0373	.037	.037	.037	.037	.0373
22	.3174	.5914	.3326	.3109	.2218	.0373	.0377
23	.3326	.6283	.3658	.3734	.499	.0377	.0373
24	.5544	.3696	.6283	.4108	.4668		.0373
Max	**.6878**	**.7011**	**.8413**	**.6962**	**.499**	**.964**	**1.0164**
Min	**.037**	**.037**	**.037**	**.037**	**.037**	**.037**	**.037**
Avg	**.4138**	**.4576**	**.4652**	**.4264**	**.3175**	**.4680**	**.3140**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274107 / 33/11 KV DUDHANI S/STN
Feeder No / Name : 205 / Kallappawadi Ag FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0373	.0373	.0377	.0566	.0377	.9335
2	.037	.0373	.0373	.0377	.056	.0377	.9808
3	.0373	.0377	.0373	.0377	.0566	.0377	1.094
4							1.1203
5							1.1203
6							1.1458
7							1.5565
10	1.2567	.8215	1.134	1.0164	1.2437		
11	1.531	1.587	1.3306	1.6448	1.5927		
12	1.643	1.6126		1.7375	1.6108		
13	1.6278	1.0517	.8688	1.7635	1.7101		
14	1.8652	1.5261		1.6741	1.6575		
15	1.6766	1.4918	1.0513	1.5729			
16	1.3763	1.3927	1.6244	1.5074	.6554		
17	1.3927	1.0526	1.5074	1.3441	1.4091	.9774	
18							.037
19	.0373	.0373	.0549		.037	.037	.0373
20	.0373	.037	.0554		.037	.0554	.037
21	.037	.0373	.056	.056	.037	.056	
22	.0373	.0373	.0377	.0554		.7392	.2772
23	.0377	.0377	.0377	.056	.0373	.7762	.5041
24	.0377	.0377	.0377	.0373	.056	.0377	.8402
Max	**1.8652**	**1.6126**	**1.6244**	**1.7635**	**1.7101**	**.9774**	**1.5565**
Min	**.037**	**.037**	**.0373**	**.0373**	**.037**	**.037**	**.037**
Avg	**.7474**	**.6396**	**.5272**	**.8386**	**.6835**	**.2792**	**.7449**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274146 / 33/11kv Guddewadi Sub/Stn
Feeder No / Name : 201 / ALAGI MIX AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0953	.1905		.9488
2		.0953	.1905		.9602
3		.0953	.1905		.9922
4		.0953	.1905		.9922
5		.1143	.1905		1.0526
6					1.2574
7					1.2574
10		1.6385	1.5565		
11		1.8652	1.5565		
12		1.8652	1.8233		
13		1.8652	1.8233		
14		1.8442	1.9281		
15		1.8652	1.9281		
16		1.7804	1.9281		
17		1.6956	1.7404		
19	.1524	.1905	.1905	.1334	.0953
20	.1334	.1905	.1905	.1334	.0953
21	.1334	.1905	.1905	.1334	.0953
22	.1334	.1905	1.5746	.8749	1.1336
23	.1143	.1905	1.5746	.8855	1.1336
24		.1143	.1905		.9172
Max	**.1524**	**1.8652**	**1.9281**	**.8855**	**1.2574**
Min	**.1143**	**.0953**	**.1905**	**.1334**	**.0953**
Avg	**.1334**	**.8411**	**1.0078**	**.4321**	**.8409**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274146 / 33/11kv Guddewadi Sub/Stn
Feeder No / Name : 202 / GUDDEWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0762	.0953		.9602
2		.0762	.0953		.9602
3		.0762	.0953		.9602
4		.0762	.0953		1.004
5		.0762	.0953		1.0486
6					1.0774
7					1.0898
10		1.4089	1.4089		
11		1.5089	1.4089		
12		1.5927	1.5089		
13		1.5927	1.5927		
14		1.5746	1.5927		
15		1.5927	1.5746		
16		1.5927	1.4918		
17		1.4251	1.3927		
19	.0762	.0953	.0953	.0762	.0953
20	.1143	.0953	.0953	.0762	.0953
21	.1143	.0953	.0953	.0762	.0953
22	.1143	.0953	1.3927	.8749	.9602
23	.0762	.0953	1.3927	.9172	.9602
24		.0762	.0953		.9488
Max	**.1143**	**1.5927**	**1.5927**	**.9172**	**1.0898**
Min	**.0762**	**.0762**	**.0953**	**.0762**	**.0953**
Avg	**.0991**	**.6959**	**.8218**	**.4041**	**.7889**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274146 / 33/11kv Guddewadi Sub/Stn
Feeder No / Name : 203 / GUDDWADI GAOTHAN FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4481	.2801		.2987
2		.4481	.2801		.2987
3		.4854	.2801		.2987
4		.4854	.2801		.3361
5		.4854	.4668		.3734
9		.2801	.2801	.0934	.2614
10		.1867	.1867	.0934	.168
11		.1867	.1867	.0934	.112
12		.1867	.1867	.0934	.0934
13		.1867	.1867	.0934	.0934
14		.1867	.1867	.0934	
15		.1867	.1867	.0943	.0934
16		.1867	.1867	.0934	.1867
17		.1867	.1867	.0934	.1867
18		.2801		.1867	.2801
19	.3361	.4668			.4668
20	.3734	.3734	.1867	.3361	.3734
21	.4294	.3734	.1867	.3361	.3734
22	.4481	.2801	.1867	.2987	
23	.4481	.2801	.1867	.2987	.2801
24		.4481	.2801		.2987
Max	**.4481**	**.4854**	**.4668**	**.3361**	**.4668**
Min	**.3361**	**.1867**	**.1867**	**.0934**	**.0934**
Avg	**.4070**	**.3156**	**.2309**	**.1641**	**.2565**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274146 / 33/11kv Guddewadi Sub/Stn
Feeder No / Name : 204 / 11KV ANKALGI PURE AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.6204	1.5384		.1905
2		1.713	1.5384		.1905
3		1.821	1.5384		.1905
4		1.829	1.5384		.1905
5		1.829	1.5746		.1905
6		1.829	1.4918		
7		1.8138	1.7404		
10				2.2939	2.3537
11				2.2939	2.572
12				1.8842	2.4863
13				2.4034	2.5149
14				2.4813	
15				2.5149	2.431
16				2.5149	2.5434
17				2.5149	2.5434
19	.0953	.0953	.0953	.1905	.0953
20	.0953	.0953	.0953	.1905	.0953
21	.0953	.0953	.0953	.1905	.0953
22	1.3889	1.5203	.0953	.1905	.0953
23	1.4815	1.5203	.0953	.1905	.0953
24		1.5051	1.5203		.1905
Max	**1.4815**	**1.829**	**1.7404**	**2.5149**	**2.572**
Min	**.0953**	**.0953**	**.0953**	**.1905**	**.0953**
Avg	**.6313**	**1.3298**	**.9967**	**1.5272**	**1.0591**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274151 / 33/11KV KUDAL SUB/STN
Feeder No / Name : 201 / ANDEWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.056	.0572	.6859	.6344
2			.056	.0572	.6859	.6344
3			.056	.0572	.7716	.6687
4			.056	.0572	.7373	.6687
5			.056	.0572	.7716	.6859
6			.056	.0572	.7716	.6859
7				.0572	.7716	.6859
8				.0572		
9				.0572		
10	1.0288		.9431	.7716		
11	1.0288		.9945	.7716		
12	1.0174		.9945	.7716		
13	1.0174		1.0288	.7716		
14	1.0174		1.046	.7716	.0191	.056
15	1.0174		1.046	.7716	.0191	.056
16	1.0174		1.0631	.7716	.0381	.056
17	1.1022		1.0631	.7716	.0381	.056
18					.0572	.056
19	.056	.056	.0381	.0572	.0572	.056
20	.056	.056	.0572	.0572	.0572	.056
21	.056	.056	.0572	.0572	.0572	.056
22	.056	.056	.0572	.6859	.6001	.5258
23	.056	.056	.0572	.6859	.6001	.6001
24			.056	.0381	.6859	.6173
Max	**1.1022**	**.056**	**1.0631**	**.7716**	**.7716**	**.6859**
Min	**.056**	**.056**	**.0381**	**.0381**	**.0191**	**.056**
Avg	**.6559**	**.056**	**.4419**	**.3595**	**.4125**	**.3808**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274151 / 33/11KV KUDAL SUB/STN
Feeder No / Name : 202 / SANGMESHWAR AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.7716	.8402	.0572	.0572
2			.823	.8402	.0572	.0572
3			.823	.8402	.0572	.0572
4			.8478	.8573	.0572	.0572
5			.8478	.8573	.0572	.0572
6			.8478	.8573	.0572	
7			.9326	.8573		
10					1.0288	1.2003
11					1.0288	1.2003
12					1.0288	1.2346
13					1.0288	1.2378
14	.056		.0191	.0572	1.0288	1.2378
15	.056		.0191	.0572	1.0288	1.2039
16	.056		.0191	.0572	1.0288	1.1869
17	.056		.0191	.0572	1.0288	1.2003
18	.056		.0381	.0572		
19	.056	.0373	.0381	.0572	.0572	.0373
20	.056	.0373	.0381	.0572	.0572	.0373
21	.056	.0373	.0381	.0572	.0572	.0373
22	.7011	.7716	.7202	.0572	.0572	.0373
23	.8573	.7716	.8059	.0572	.0572	.0373
24			.7716	.823	.0572	.0572
Max	**.8573**	**.7716**	**.9326**	**.8573**	**1.0288**	**1.2378**
Min	**.056**	**.0373**	**.0191**	**.0572**	**.0572**	**.0373**
Avg	**.2006**	**.3310**	**.4678**	**.4080**	**.4458**	**.5385**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274151 / 33/11KV KUDAL SUB/STN
Feeder No / Name : 203 / DEVIKAWATHA AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0373	.0381	.6344	.6859
2			.0373	.0381	.6344	.703
3			.0373	.0381	.6859	.703
4			.0373	.0381	.6859	.703
5			.0373	.0381	.6859	.7202
6			.0373	.0381	.6859	.7202
7				.0381		.7716
10			.6859	.6516		
11		.8573	.7202	.6859		
12			.7716	.6859		
13			.823	.6859		
14			.8402	.7202	.0191	.0373
15	.8573		.8402	.7202	.0191	.0373
16	.8573		.8402	.7202	.0381	.0373
17	.8573		.8402	.7202	.0381	.0373
18					.0381	.0373
19	.0373		.0381	.0381	.0381	.0373
20	.0373		.0381	.0381	.0381	.0373
21	.0373	.0373	.0381	.0381	.0381	.0373
22	.0373	.0373	.0381	.6344	.6516	.6859
23	.0373	.0373	.0381	.6344	1.2003	.6859
24			.0373	.0381	.6344	.6859
Max	**.8573**	**.8573**	**.8402**	**.7202**	**1.2003**	**.7716**
Min	**.0373**	**.0373**	**.0373**	**.0381**	**.0191**	**.0373**
Avg	**.3448**	**.2423**	**.3407**	**.3466**	**.3980**	**.4091**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274156 / 33/11KV MOTYAL SUB/STN
Feeder No / Name : 201 / 11KV KURNUR (MIX AG) SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	1.3717	1.5971
2	.0381	.0381	1.387	1.6091
3	.0381		1.5394	1.6204
4			1.5394	1.7124
5			1.5741	1.7236
6			1.5741	1.7341
7			1.8056	1.7438
10	1.9216	1.9052		
11	2.2283	2.1759		
12	2.2685	2.1142		
13	2.4036	1.9052		
14	2.4194	2.271		
15	2.359	2.2253		
16	2.2965	2.21		
17	2.2184	2.0988		
19	.0572	.0572	.0572	.0572
20	.0572	.0572	.0572	.0762
21	.0381	.0572	.0572	.0572
22	.0381	1.3717	1.5893	1.531
23	.0381	1.4022	1.6004	1.6964
24	.0572	.0381	1.4022	1.5623
Max	**2.4194**	**2.271**	**1.8056**	**1.7438**
Min	**.0381**	**.0381**	**.0572**	**.0572**
Avg	**1.0891**	**1.2478**	**1.1965**	**1.2862**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274156 / 33/11KV MOTYAL SUB/STN
Feeder No / Name : 202 / 11kv KURNUR GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1524	.1905
2	.1524	.1524	.1524	.1905
3	.1524	.1905	.1905	.2286
4	.1715	.2667	.2401	.2858
5	.2667	.3429	.3258	.3841
6	.3239	.4191	.5415	.4733
7	.2858	.4572	.5788	.5721
8	.3048	.439	.5601	.567
9	.1905	.3475	.4207	.4572
10		.2303	.2477	.362
11		.1524	.1905	.2286
12		.1143	.1524	.1753
13	.1006	.1143	.1524	.1578
14	.1006	.1334	.1524	.1524
15	.1187	.0953	.1524	.1524
16	.12	.1524	.1524	.1905
17	.1492	.1905	.1905	.2279
18	.2715	.2858	.2858	.3982
19	.3841	.4763	.4298	.4001
20	.3258	.3429	.3658	.381
21	.2126	.2286	.2858	.2667
22	.1578	.1905	.2286	.2096
23	.1417	.1905	.3239	.1715
24	.1524	.1524	.1905	.1905
Max	**.3841**	**.4763**	**.5788**	**.5721**
Min	**.1006**	**.0953**	**.1524**	**.1524**
Avg	**.2017**	**.2424**	**.2776**	**.2922**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274156 / 33/11KV MOTYAL SUB/STN
Feeder No / Name : 203 / 11 KV Badole Ag FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.6636		
2	.4938	.6481		
3	.4784	.6481		
4	.6173	.679		
5	.703	.7716		
6	.8322	.787		
7	1.0562	1.0082		
10			.9105	.8907
11			.9686	1.1843
12			1.0437	1.2176
13			1.0155	1.2643
14			1.0031	1.3117
15			.9804	1.2163
16			.7682	1.1203
17			.7968	1.1069
22	.5864			
23	.6562			
24	.5937	.6481		
Max	**1.0562**	**1.0082**	**1.0437**	**1.3117**
Min	**.4784**	**.6481**	**.7682**	**.8907**
Avg	**.6635**	**.7317**	**.9359**	**1.1640**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274180 / AKKALKOT TOWN SUB-STATION
Feeder No / Name : 201 / 11 KV AKKALKOT URBAN FEEDER Feeder KV- 11 / OUTGOING **SHEDDABLE URBAN**

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8413		.823	.7682
2	.823		.7865	.7316
3	.823		.7865	.7316
4	.823		.9145	.7682
5	.9145		1.0974	.823
6	1.1523		1.1888	.9145
7	1.1888		1.2803	1.2071
8	1.262	1.3169	1.2437	1.2437
9	1.2254	1.2071	1.1706	1.1523
10	1.2803	1.1888	1.1706	1.0974
11	1.1888	1.1157	1.0974	
12	1.0425	1.0425	1.0425	
13	1.0059	1.0974	1.0059	
14	.9511	.9511	1.0059	
15	.8779	.9511	1.0059	
16	.9511	1.0059	.9877	
17	1.0974	1.1523	1.0059	
18			1.3535	
19			1.5729	
20			1.4815	
21			1.3169	
22			1.0974	
23	.9694	.9145	.9145	
24	.8779	.8596	.823	.8048
Max	**1.2803**	**1.3169**	**1.5729**	**1.2437**
Min	**.823**	**.8596**	**.7865**	**.7316**
Avg	**1.0156**	**1.0669**	**1.0905**	**.9311**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274180 / AKKALKOT TOWN SUB-STATION
Feeder No / Name : 202 / 11 KV SAMARTH NAGAR FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734		.4251	.4668
2	.3547		.462	.4481
3	.3547		.5175	.4481
4	.3734		.5544	.4668
5	.4668		.6468	.5601
6	.5788		.7023	.6722
7	.7468		.7577	.8215
8	.8029	.7095	.7762	.7842
9	.7095	.6722	.6653	.6161
10	.6161	.6348	.6838	.5975
11	.5975	.6161	.6468	
12	.5601	.5914	.5914	
13	.5601	.6838	.5359	
14	.5601	.462	.5175	
15	.5601	.6653	.4475	
16	.5601	.7842	.5175	
17	.5601	.8131	.5175	
18			.6283	
19			.6838	
20			.7947	
21			.7207	
22			.6283	
23	.5601	.462	.5175	
24	.3734	.5788	.462	
Max	**.8029**	**.8131**	**.7947**	**.8215**
Min	**.3547**	**.462**	**.4251**	**.4481**
Avg	**.5405**	**.6394**	**.6000**	**.5881**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274180 / AKKALKOT TOWN SUB-STATION
Feeder No / Name : 203 / 11 KV Swami Vihar FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1467		.1204	.1656
2	.1467		.1204	.1656
3	.1467			.1656
4	.1467		.1505	.1505
5	.1467		.1355	.1505
6	.1467		.1355	.1505
7	.1467		.1355	
8	.0185	.0185	.1204	
9	.0147	.0185	.0301	
10	.0147	.0554	.0301	
11	.0147	.0739	.0301	
12	.0147	.1054	.0301	
13	.0147	.1054	.0301	
14	.0147	.1204	.0301	
15	.0147	.1204	.0301	
16	.0147	.0753	.0301	
17	.0147	.1505	.0301	
18			.0452	
19			.0452	
20			.0452	
21			.0452	
22			.0903	
23	.0147	.1054	.1505	
24	.0185	.0185	.1054	.1656
Max	**.1467**	**.1505**	**.1505**	**.1656**
Min	**.0147**	**.0185**	**.0301**	**.1505**
Avg	**.0637**	**.0806**	**.0746**	**.1591**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274206 / 33/11 KV KINI SUBSTATION
Feeder No / Name : 201 / 11 KV GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2614	.2614	.1867	.2054
2		.2614	.2614	.1867	.2241
3		.3361	.3361	.2987	.2987
4		.547	.3734	.3734	.5228
5		.6602	.5175	.5228	.7023
6		.6979	.7392	.7392	.7468
7		.7468	.7762	.7682	.7842
8		.6348	.6653	.6722	.7468
9		.4854	.5228	.5601	.6722
10	.2801	.3734	.3734	.3361	.3734
11	.2241	.2241	.2614	.2241	.2614
12	.1867	.2241	.1867	.168	.2241
13	.1494	.1867	.1867	.1494	.1494
14	.1307	.1867	.1867	.1663	.168
15	.1494		.1494	.168	.1867
16	.2241	.2241	.1867	.1867	.168
17	.2987	.2987	.2801	.2427	.2427
18	.4294	.4854	.3734	.4668	.4481
19	.4108	.5601	.5601	.5975	.5975
20	.3921	.4481	.4481	.5175	.4108
21	.2987	.3734	.3361	.4481	.3547
22	.2614	.2987	.2241		.2427
23		.2801	.1867	.2241	.2054
24		.2614	.2614	.1867	.2054
Max	**.4294**	**.7468**	**.7762**	**.7682**	**.7842**
Min	**.1307**	**.1867**	**.1494**	**.1494**	**.1494**
Avg	**.2643**	**.3937**	**.3606**	**.3648**	**.3809**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274206 / 33/11 KV KINI SUBSTATION
Feeder No / Name : 202 / 11 KV KINI AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0936	1.0802		
2		1.0936	1.0802		
3		1.1385	1.0802		
4		1.1385	1.0802		
5		1.1702	1.3117		
6		1.1873	1.3916		
7		1.2811	1.3916		
10				1.2963	1.4746
11					1.6842
12				1.5729	1.8138
13				1.6518	1.8785
14				1.704	1.8785
15					1.749
16					1.6004
17				1.6385	1.6004
20			.1715		
22	1.0623	1.0494			
23	1.0936	1.0802			
24		1.0936	1.0802		
Max	**1.0936**	**1.2811**	**1.3916**	**1.704**	**1.8785**
Min	**1.0623**	**1.0494**	**.1715**	**1.2963**	**1.4746**
Avg	**1.0780**	**1.1326**	**1.0742**	**1.5727**	**1.7099**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274206 / 33/11 KV KINI SUBSTATION
Feeder No / Name : 203 / 11 KV KAZIKANBUS AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.0402	1.2308
2				1.0402	1.278
3				1.0402	1.2803
4				1.0402	1.3279
5				1.0402	1.3763
6				1.0402	1.4419
7				1.1111	1.6194
10		1.3717			
11		1.7368			
12	1.8023	1.6712	1.1523		
13	1.8138	1.4746	.8642		
14	1.8461	1.4746			
15	1.8461	1.3763	1.7695		
16	1.7814	1.4746	1.7695		
17	1.6644	1.4746	1.7695		
22				1.1797	1.2498
23				1.1984	1.3123
24				1.0105	1.2125
Max	**1.8461**	**1.7368**	**1.7695**	**1.1984**	**1.6194**
Min	**1.6644**	**1.3717**	**.8642**	**1.0105**	**1.2125**
Avg	**1.7924**	**1.5068**	**1.465**	**1.0741**	**1.3329**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274228 / 33/11 KV Mirajgi Sub-station
Feeder No / Name : 201 / 11 KV Hattikanbas Ag FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.096	.0762	.0926	.0762	1.0936
2	.0949	.0762	.0926	.0762	1.0936
3	.096	.0762	.0926	.0772	1.0936
4	.096	.0762	.0926	.0926	1.2498
5	.0972	.0914	.1235	.0914	1.4232
6	.0972	.1219	.1235		1.5023
7					1.6404
10	1.8747	1.5546	1.656	2.1605	
11	2.1348	1.7204	2.2138	2.4034	
12	2.3403		2.2138	2.4863	
13	2.372		2.2672	2.4531	
14	2.372	2.13	2.2405	2.6023	
15	2.3482	2.5724	2.2085	2.3537	
16	2.2996	2.6216	2.3266	2.1956	
17	2.2024	2.6216	2.2996	2.13	
19	.0914	.0753	.0762	.1372	
20	.0926	.0903	.0926	.1372	
21	.0926	.1204	.0926	.1372	
22	.0617	.1204	.0772	.1372	
23	.0772	.0914	.0781	.1067	
24	.0983	.0762	.0926	.0772	1.0155
Max	**2.372**	**2.6216**	**2.3266**	**2.6023**	**1.6404**
Min	**.0617**	**.0753**	**.0762**	**.0762**	**1.0155**
Avg	**.9518**	**.7952**	**.9276**	**1.0490**	**1.264**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274228 / 33/11 KV Mirajgi Sub-station
Feeder No / Name : 202 / 11 KV Basalegaon Ag FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1717	1.1336	1.0155	.9374
2	1.1717	1.1336	1.0155	.9374
3	1.1717	1.1469	1.0155	.0937
4	1.186	1.1469	1.1069	1.0155
5	1.2651	1.2289	1.2651	1.0155
6	1.2811	1.3435	1.5813	1.0936
7	1.5935	1.7368	1.6604	1.4232
14	.0743	.0446	.0602	.0446
15	.0457	.0446	.0602	.0446
16	.0474	.0446	.0602	.0452
17	.0781	.0446	.0602	.0452
18	.0937	.0594	.0602	.0452
19	.0903	.0594	.0602	.0452
20	.0753	.0594	.0743	.0457
21	.0602	.0446	.0743	.0457
22	.9374	.9717	.7716	.7202
23	1.0155	1.0155	.9374	.7611
24	1.1717	1.1336	1.0279	.9374
Max	**1.5935**	**1.7368**	**1.6604**	**1.4232**
Min	**.0457**	**.0446**	**.0602**	**.0446**
Avg	**.6961**	**.6885**	**.6615**	**.5165**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
AKKALKOT S/DN.[096] BU 1341
Substation No/ Name :- 274228 / 33/11 KV Mirajgi Sub-station
Feeder No / Name : 203 / 11 KV Mirajgi Gaothan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1848	.1848	.1867
2	.1494	.1848	.1848	.1867
3	.1494	.1848	.1848	.1848
4	.1494	.2218	.2772	.1848
5	.2801	.2772	.3326	.2801
6	.4066	.3696	.4066	.4066
7	.2801	.3326	.3326	.3734
8	.2218	.2772	.2772	.2801
9	.2241	.1848	.2218	.2241
10	.1478	.1478	.2033	.1848
11	.1478	.1294	.2218	.1294
12	.1478	.1109	.1867	.1294
13	.1109	.1109	.1494	.0924
14	.1109	.0924	.1109	.0924
15	.1478	.1109	.1109	.0924
16	.1478	.1109	.1478	.0924
17	.1848	.1478	.1848	.112
18	.2772	.2772	.2772	.2054
19	.2957	.3326	.3326	.2427
20	.2587	.2772	.2957	.2054
21	.2402	.2218	.2587	.168
22	.2218	.1848	.1867	.1494
23	.1848	.1848	.1867	.1307
24	.1494	.1848	.1848	.1867
Max	**.4066**	**.3696**	**.4066**	**.4066**
Min	**.1109**	**.0924**	**.1109**	**.0924**
Avg	**.1993**	**.2017**	**.2267**	**.1884**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] **BU 1350**
Substation No/ Name :- 274073 / 33/11 KV ANAGAR
Feeder No / Name : 201 / 11 KV ANAGAR AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	19-DEC-17
HR	Load (MW)
12	1.0669
Max	**1.0669**
Min	**1.0669**
Avg	**1.0669**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274073 / 33/11 KV ANAGAR
Feeder No / Name : 204 / 11 KV PASALEWADI MIX AG SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0686	.0686	.0886	.0829
2			.0686	.0686	.0886	.0829
3			.0686	.0857	.0886	.0819
4			.0686	.0857	.0886	.0829
5			.0686	.0857	.0886	.0819
6			.0686	.0857	.0886	.0829
7			.0686	.0857	.0886	.081
8			.0686	.0857	.0886	.0819
9			.3429	.3429	.3544	.3932
10	.3932	.4287	.4115	.3721		.4115
11	.3768	.4287	.4115	.4031		.4115
12	.3978	.4287	.4115	.3898		.3944
13	.3856	.4287	.4115	.3898		.3944
14	.3978	.4287	.4115	.3982		.3772
15	.3932	.4115	.4115	.3898		.3772
16	.3932	.3944	.4115	.3898		.3772
17		.0686	.0686	.0886		.0857
18		.0686	.0857	.0876	.0655	.0857
19		.0857	.1029	.0886	.0819	.0686
20		.0857	.1029	.0886	.0819	.0686
21		.0857	.1029	.0886	.0829	.0686
22		.0686	.0686	.0886	.0838	.0686
23		.0686	.0686	.0886	.0819	.0686
24			.0686	.0686	.0886	.0819
Max	**.3978**	**.4287**	**.4115**	**.4031**	**.3544**	**.4115**
Min	**.3768**	**.0686**	**.0686**	**.0686**	**.0655**	**.0686**
Avg	**.3911**	**.2486**	**.1850**	**.1839**	**.1019**	**.1830**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] **BU 1350**
Substation No/ Name :- 274073 / 33/11 KV ANAGAR
Feeder No / Name : 205 / 11 KV ANAGAR GAOTHAN **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5144	.5144	.5316	.4915
2			.5144	.5144	.5316	.4973
3			.5144	.5144	.5316	.4915
4			.6173	.5144	.7087	.5801
5			.9431	.9431	.8859	.8192
6			1.2003	1.0288	1.0631	.8907
7			1.1317	1.2003	1.2403	1.065
8			1.1145	1.2003	1.2403	1.065
9			.7716	.9431	.8859	.8192
10	.6882	.7888	.6001	.7087	.7373	.6859
11	.547	.6859	.6859			.6173
12		.6001	.6001	.6135	.5571	.6173
13	.5735	.6001	.5144	.5316	.5801	.5487
14	.5801	.6001	.5144	.5316	.5365	.5487
15	.5735	.6001	.5144	.5316	.5735	.5144
16	.5801	.5487	.5144	.6135	.5735	.5144
17	.5407	.6859	.6001	.7087	.5735	.6859
18		.7716	.7716	.7973	.6882	.8573
19		.9431	1.0288	.9745	1.0322	.9602
20		1.0288	.8573	.7973	.9945	.8916
21		.7716	.6859	.7087	.8288	.7888
22		.6859	.5144	.7087	.5735	.6859
23		.583	.5144	.5316	.4915	.6173
24			.5144	.5144	.5316	.4915
Max	**.6882**	**1.0288**	**1.2003**	**1.2003**	**1.2403**	**1.065**
Min	**.5407**	**.5487**	**.5144**	**.5144**	**.4915**	**.4915**
Avg	**.5833**	**.7067**	**.6980**	**.7237**	**.7344**	**.6977**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] **BU 1350**
Substation No/ Name :- 274074 / 33/11 KV BEGAMPUR
Feeder No / Name : 201 / 11 KV ARDHANARI AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0171	.0171	.9945
2	.0171	.0171	.0171	.823
3	.0171	.0171	.0171	.823
4	.0171	.0171	.0171	.8916
5	.0171	.0171	.0171	.9431
6	.0171	.0171	.0171	1.0288
7	.0171	.0171	.0171	1.0288
8	.0171	.0171	.0171	.0171
9	.0171	.0171	.0171	
10	.9907	.8383		.0171
11	1.0669	.9145		.0171
12	1.0669	1.0669		.0171
13	1.2193	1.0669		.0171
14	1.0669	1.0669		.0171
15	1.0669	1.0669		.0171
16	1.1431	1.0669		.0171
17	1.2193	.9907		.0171
18	.0171	.0171	.0171	.0171
19	.0171	.0171	.0171	.0171
20	.0171	.0171	.0171	.0171
21	.0171	.0171	.0171	.0171
22	.0171	.0171	.6859	.5944
23	.0171	.0171	.8573	.6859
24	.0171	.0171	.0171	.8573
Max	**1.2193**	**1.0669**	**.8573**	**1.0288**
Min	**.0171**	**.0171**	**.0171**	**.0171**
Avg	**.3797**	**.3480**	**.1114**	**.3866**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274074 / 33/11 KV BEGAMPUR
Feeder No / Name : 202 / 11 KV ARBALI AG SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5775	1.5089	1.2689	.0514
2	1.5604	1.4746	1.2689	.0514
3	1.5604	1.4575	1.286	.0514
4	1.5947	1.5089	1.3375	.0514
5	1.5947	1.5432	1.3375	.1372
6	1.6289	1.5604	1.3889	.1372
7	1.8004	1.5604	1.3717	.1372
8	.0514	.1715	.1715	.1372
9	.0514	.1715	.0514	
10	.0514			1.7147
11				2.0576
12				2.1262
13	.0514			2.2634
14	.0514			2.332
15	.0514			2.332
16	.0514	.0514		2.2634
17	.0514	.0514		2.1948
18	.1372	.1372		.0514
19	.1372	.1543		.1372
20	.0514	.1543	.0514	.1543
21	.0514	.0514	.0514	.0514
22	1.2803	1.1126	.0514	.0514
23	1.5432	1.286	.0514	.0514
24	1.5775	1.5432	1.286	.0514
Max	**1.8004**	**1.5604**	**1.3889**	**2.332**
Min	**.0514**	**.0514**	**.0514**	**.0514**
Avg	**.7503**	**.8610**	**.7839**	**.8081**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274074 / 33/11 KV BEGAMPUR
Feeder No / Name : 203 / 11 KV BEGAMPUR AG SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0514	.0514	1.4575
2	.0514	.0514	.0514	1.4575
3	.0514	.0514	.0514	1.5089
4	.0514	.0514	.0514	1.5432
5	.0514	.2058	.0514	1.5775
6	.0514	.2401	.0514	1.8519
7	.0514	.2058	.0514	2.4006
8	.0514	.1715	.1886	.2058
9	.0514	.1715	.2229	.1715
10	1.3717	1.4937		.1372
11	1.7833	1.7223		.1372
12	1.768	1.7528		.1372
13	1.7985			
15	1.7375			
16	1.5242	1.7528		
17	1.5242	1.7528		
18	.0514	.0514		.0514
19	.1372	.1372	.0514	.1715
20	.1372	.1372	.1372	.1715
21	.0514	.1715	.1372	.1372
22	.0514	.0514	1.2498	1.3108
23	.0514	.0514	1.4918	1.4327
24	.0514	.0514	.0514	1.4746
Max	**1.7985**	**1.7528**	**1.4918**	**2.4006**
Min	**.0514**	**.0514**	**.0514**	**.0514**
Avg	**.5435**	**.4917**	**.2593**	**.9124**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274074 / 33/11 KV BEGAMPUR
Feeder No / Name : 204 / 11 KV BEGAMPUR GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2401	.1886	.2058
2	.2401	.2229	.1715	.2229
3	.2229	.2229	.1715	.2229
4	.2229	.2572	.2058	.2572
5	.4287	.4115	.4115	.4973
6	.5144	.5487	.5316	.583
7	.6173	.5144	.5658	.6173
8	.4458	.5144	.5487	.583
9	.3429	.3772	.4458	.5144
10	.2743	.2743	.3772	.3772
11		.2401	.3086	.2743
12	.2915		.2743	
13	.2401	.2229	.2401	.3086
14	.2229	.2401	.2229	.2743
15			.2229	.2401
16		.2401		.2401
17	.3601	.2229	.2743	.3086
18	.4458	.463	.4458	.3944
19	.6001	.4973		.583
20	.4458	.3772	.583	.5144
21	.3944	.3429	.4801	.4287
22	.2743	.2572	.3086	.2915
23	.2401	.2058	.2229	.2229
24	.2401	.2229	.1886	.2058
Max	**.6173**	**.5487**	**.583**	**.6173**
Min	**.2229**	**.2058**	**.1715**	**.2058**
Avg	**.3487**	**.3235**	**.3359**	**.3638**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274074 / 33/11 KV BEGAMPUR
Feeder No / Name : 205 / 11KV YENKI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6516	.6859	.0857
2	.6859	.7202	.6516	.0857
3	.7202	.7202	.6516	.0686
4	.7202	.823	.7202	.0686
5	.7888	.7716	.7716	.0857
6	.8573	.8573	.8573	.0857
7	1.0802	1.0117	1.0802	.0857
8	.1372	.1543	.1886	.1543
9	.1543	.1372	.1715	.1372
10	.0857			.9259
11				1.0631
12				1.1317
13	.0514			1.2346
14	.0514			1.2003
15	.0514			1.2003
16	.0686			1.2346
17	.0686	.0857		1.1317
18	.1372	.1543	.0686	.1372
19	.1029	.1372	.0857	.1543
20	.1372	.1372	.0857	.1543
21	.1372	.1715	.1029	.1372
22	.6249	.6249	.0686	.0857
23	.703	.703	.0857	.0686
24	.6859	.6859	.6859	.0857
Max	**1.0802**	**1.0117**	**1.0802**	**1.2346**
Min	**.0514**	**.0857**	**.0686**	**.0686**
Avg	**.3971**	**.5028**	**.4351**	**.4501**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] **BU 1350**
Substation No/ Name :- 274074 / 33/11 KV BEGAMPUR
Feeder No / Name : 206 / 11 KV KOTHALE AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.1029	.1029	.9945
2	.0857	.1029	.1029	.8535
3	.0857	.12	.1029	.9602
4	.0686	.12	.1029	1.0288
5	.0686	.1372	.1029	1.0288
6	.0857	.1372	.12	1.0288
7	.0857	.1543	.1372	1.1145
8	.0686	.1372	.12	.0686
9	.0686	.12	.12	.0857
10	1.1279	1.1279		.0514
11	1.2193	1.1584		.0686
12	1.2498	1.2193		.0686
13	1.2651	1.1888		.0686
14	1.2498	1.1584		
15	1.2498	1.1584		.1029
16	1.2193	.7316		.0857
17	1.1888	.9145		.1029
18	.1372	.1372	.0857	.1029
19	.12	.12	.1029	.0686
20	.1029	.1372	.0514	.0686
21	.1029	.1372	.0514	.0686
22	.1029	.1372	.9145	1.1279
23	.1029	.12	1.0288	.7926
24	.0857	.1029	.1029	.9945
Max	**1.2651**	**1.2193**	**1.0288**	**1.1279**
Min	**.0686**	**.1029**	**.0514**	**.0514**
Avg	**.4678**	**.4450**	**.2093**	**.4755**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] **BU 1350**
Substation No/ Name :- 274076 / 33/11 KV KAMTI
Feeder No / Name : 201 / 11 KV SHINGOLI AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2439	.2439	.2743	.2683	1.7528
2	.2683	.3018	.2743	.2439	1.7528
3	.2439	.3048	.2743	.2683	1.7528
4	.2439	.3048	.2743	.2439	1.829
5	.2743	.3353	.2743	.2896	2.0576
6	.3048	.3658	.3048	.3658	2.21
7	.3353	.3658	.3048	.4268	2.6216
8	.3658	.3353	.3353	.3658	.3353
9	2.7435	.2743	.3963	.3353	.3048
10	3.2861	3.0483	2.5149	3.6046	.2743
11	3.0788	2.8959	2.4387		.2743
12	3.2922		2.7435		
13	2.9569	2.7435	3.0483		
14	3.0178	2.8959	3.0483		
15	2.713	3.0483	2.7435		
16	2.9874	3.1398	2.8959		
17	2.7435	2.7435	2.7435	.2439	
18	.4268	.3353	.2743	.3353	.3963
19	.4268	.4268	.3658	.4268	.4268
20	.3963	.4268	.3658	.3658	.3963
21	.3048	.3201	.3353	.3353	.3658
22	.2743	.3201	.2743	1.9052	1.9814
23	.2743	.3048	.2439	1.89	2.1338
24	.2439	.2439	.3048	.2439	1.829
Max	**3.2922**	**3.1398**	**3.0483**	**3.6046**	**2.6216**
Min	**.2439**	**.2439**	**.2439**	**.2439**	**.2743**
Avg	**1.3103**	**1.1185**	**1.1272**	**.6755**	**1.2608**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274076 / 33/11 KV KAMTI
Feeder No / Name : 202 / 11 KV ICHAGAON AG SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.6766	1.4937	1.5242	.1067
2	1.3717	1.7528	1.3717	1.5242	.1067
3	1.3717	1.7528	1.3717	1.5242	.1067
4	1.6461	1.7528	1.6766	1.6766	.1067
5	1.9814	1.9448	1.9052	1.7528	.1067
6	2.3624	1.7833	2.1948	1.9814	.1219
7	2.5911	2.3624	2.3624	2.3624	.1677
8	.1981	.1219	.0914	.1067	.1524
9	.1524	.1524	.0914	.1219	.1219
10	.0914	.061			2.6063
11	.0762	.061			3.094
12	.0762	.0914	.061		2.9721
13	.061	.0914			2.9111
14	.061				2.9569
15	.061	.0457	.0762		2.7435
16	.061	.061	.0762		2.6063
17	.0914	.061	.0762	1.6309	2.4387
18	.1524	.1067	.1219	.1372	.1981
19	.1677	.1829	.1524	.1829	.2134
20	.1829	.1829	.1829	.1829	.1981
21	.1524	.1677	.1524	.1524	.1829
22	1.4937	1.4175	1.5546	.1067	.1067
23	1.5242	1.4937	1.5242	.0762	.1067
24	1.3717	1.6766	1.4937	1.5242	.0762
Max	**2.5911**	**2.3624**	**2.3624**	**2.3624**	**3.094**
Min	**.061**	**.0457**	**.061**	**.0762**	**.0762**
Avg	**.7780**	**.8261**	**.9015**	**.9746**	**1.0212**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274076 / 33/11 KV KAMTI
Feeder No / Name : 205 / 11 KV KAMATI BK. GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.3658	.2743	.3048	.3048
2	.3353	.3353	.2743	.3048	.3048
3	.3353	.3353	.2743	.3048	.3048
4	.3658	.4572	.3353	.3658	.3658
5	.4268	.5182	.4268	.4268	.4694
6	.5182	.5335	.5792	.4877	.5182
7	.6097	.6539	.6097	.6097	.6097
8	.5182	.4877	.5182	.5182	.5182
9	.4572	.3963	.4572	.4572	.4572
10	.4725	.3658	.4268	.381	.381
11	.381				.3856
12	.381				.2896
13	.3201	.3353	.3353		.3185
14	.3048	.3201	.3353		.2286
15	.2896	.3201			.2439
16	.2439	.3048	.3048		.3353
17	.3048	.3963	.3353	.3353	
18	.4572	.4877	.5792	.5639	.503
19	.5335	.6097	.6097	.6859	.5944
20	.4877	.6401	.6097	.7316	.5868
21	.4572	.2896	.5182	.5182	.4268
22	.4268		.4268	.3658	.2743
23	.3963	.2743	.3658	.3506	.2743
24	.3658	.3658	.2743	.3048	.3048
Max	**.6097**	**.6539**	**.6097**	**.7316**	**.6097**
Min	**.2439**	**.2743**	**.2743**	**.3048**	**.2286**
Avg	**.4052**	**.4187**	**.4224**	**.4454**	**.3913**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] **BU 1350**
Substation No/ Name :- 274076 / 33/11 KV KAMTI
Feeder No / Name : 206 / 11 KV HARALWADI AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	1.448	1.2193	1.2193	.1677
2	1.2193	1.643	1.2193	1.2193	.1524
3	1.2193	1.4937	1.2193	1.2193	.1524
4	1.3717	1.5242	1.2193	1.2955	.1524
5	1.5242	1.6004	1.448	1.4022	.2012
6	1.6766	1.6461	1.5242	1.4022	.2134
7	1.829	1.8747	1.9052	1.6004	.2286
8	.1829	.1829	.2743	.2134	.1829
9	.1524	.2286	.2134	.1829	.1677
10	.1981	.2134	.1829	.1677	1.9814
11	.1524	.2134	.1524		2.1033
12	.1524		.1677		2.0881
13	.1829		.1829		2.1491
14	.1829	.1981	.1829		2.1643
15	.1372	.1829	.1981		2.1643
16	.1829	.1829	.1829		2.1491
17	.2134	.2286	.1524	1.7528	2.0881
18	.2743	.2286	.2134	.1829	.1981
19	.2134	.2591	.1981	.2439	.1981
20	.2134	.2591	.2134	.218	.1981
21	.1829	.1981	.1829	.1981	.1829
22	1.326	1.3108	1.2498	.1829	.1677
23	1.3717	1.3413	1.2193	.1677	.1677
24	1.2498	1.448	1.2193	1.2193	.1524
Max	**1.829**	**1.8747**	**1.9052**	**1.7528**	**2.1643**
Min	**.1372**	**.1829**	**.1524**	**.1677**	**.1524**
Avg	**.6929**	**.8139**	**.6725**	**.7827**	**.8238**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274076 / 33/11 KV KAMTI
Feeder No / Name : 207 / 11 KV DADPUR AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219	.1372	.1219	.1219	.8383
2	.1219	.1524	.1219	.1219	.8383
3	.1219	.1524	.1219	.1219	.8383
4	.1219	.1524	.1219	.1219	.8383
5	.1524	.1829	.1524	.1524	.9145
6	.1829	.1981	.2134	.2134	1.0364
7	.2439	.2439	.2591	.2134	1.3717
8	.2134	.2134	.2439	.2134	.2134
9	1.2193	.1677	.1829	.1829	.1829
10	1.3717		1.3717	1.5242	
11	1.5394		1.387		
12	1.4175				
13	1.5394	1.1126	1.5394		
14	1.5546	1.2193	1.6004		
15	1.5089	1.326	1.6004		
16	1.4937	1.326	1.5242		
17	1.3717	1.2651	1.4175	.0762	
18	.1372	.1829	.1829	.1372	.2012
19	.1677	.1981	.2286	.2134	.2134
20	.1829	.1981	.2134	.1829	.1981
21	.1524	.1981	.1829	.1372	.1677
22	.1219	.1219	.1372	.884	.8383
23	.1372	.1219	.1219	.8993	.9145
24	.1219	.1372	.1219	.1219	.8383
Max	**1.5546**	**1.326**	**1.6004**	**1.5242**	**1.3717**
Min	**.1219**	**.1219**	**.1219**	**.0762**	**.1677**
Avg	**.6382**	**.4289**	**.5726**	**.3133**	**.6527**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274077 / 33/11 KV LAMBOTI
Feeder No / Name : 201 / 11 KV LAMBOTI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7558	1.7737		
2	1.7558	.1867		
3	1.7147	1.6289		
4	1.7974	1.5893		
5	1.7901	1.6385		
6	1.7901	1.6194		
7	2.0153	1.8299	.8764	.9717
12	.3395	.3961		
13	.3018	.3772		
14	.415	.3961		
15	.3584	.3961		
17				2.915
18				.8676
19				1.0288
20				.9907
21				.9526
22				.7545
24	1.7528	1.5497	.5658	
Max	**2.0153**	**1.8299**	**.8764**	**2.915**
Min	**.3018**	**.1867**	**.5658**	**.7545**
Avg	**1.3156**	**1.1151**	**.7211**	**1.2116**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274077 / 33/11 KV LAMBOTI
Feeder No / Name : 207 / 11KV TOLL PLAZA
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0434	.0415		
2	.0434	.0415		
3	.0434	.0434		
4	.0434	.0434		
5	.0434	.0434		
6	.0434	.0434		
7	.0245	.0226	.0207	.0245
8	.0132	.0132		
9	.0132	.0132		
10	.0132	.0132		
11	.0151	.0151		
12	.0151	.0132		
13	.017	.0151		
14	.0132	.0151		
15	.0132	.0132		
17				.0187
18				.034
19				.049
20				.0528
21				.0547
22				.0453
24	.0434	.0434		
Max	**.0434**	**.0434**	**.0207**	**.0547**
Min	**.0132**	**.0132**	**.0207**	**.0187**
Avg	**.0276**	**.0271**	**.0207**	**.0399**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274081 / 33/11 KV PENUR
Feeder No / Name : 201 / 11 KV KONHARI PAPRI SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5144	.5144	.5144	
2		.5144	.5144	.5144	
3		.5144	.5144	.5144	
4		.5144	.5144	.5144	
5		.5144	.5144	.5144	
6		3.6008	3.4294	3.4294	
7		3.9438	3.4294	3.4294	
8		3.6008	3.4294	3.4294	
16					.5144
17					.5144
18					.5144
19					.5144
20					.5144
21					.5144
22					3.4294
23	.5144	.5144	.5144	.5144	3.4294
24		.5144	.5144	.5144	
Max	**.5144**	**3.9438**	**3.4294**	**3.4294**	**3.4294**
Min	**.5144**	**.5144**	**.5144**	**.5144**	**.5144**
Avg	**.5144**	**1.4746**	**1.3889**	**1.3889**	**1.2432**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274081 / 33/11 KV PENUR
Feeder No / Name : 202 / 11 KV PATKUL SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5144	.5144	.5144	
2		.5144	.5144	.5144	
3		.5144	.5144	.5144	
4		.5144	.5144	.5144	
5		.5144	.5144	.5144	
9		3.6008	3.4294	2.915	
10		3.6008	3.4294	3.6008	
11		2.7435	2.8292	3.4294	3.4294
12					3.2579
14					2.0576
15					3.0864
16					3.2579
17					2.4006
19					.5144
20					.5144
21					.5144
22					.5144
23	.5144	.5144	.5144	.5144	.5144
24		.5144	.5144	.5144	
Max	**.5144**	**3.6008**	**3.4294**	**3.6008**	**3.4294**
Min	**.5144**	**.5144**	**.5144**	**.5144**	**.5144**
Avg	**.5144**	**1.3546**	**1.3289**	**1.3546**	**1.8238**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274081 / 33/11 KV PENUR
Feeder No / Name : 203 / 11 KV PENUR SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5144	3.4294	.5144	
2		3.6008	3.4294	.5144	
3		.5144	.5144	.5144	
4		.5144	.5144	.5144	
5		.5144	.5144	.5144	
11					3.7723
12		3.858	3.9438		4.1152
13		4.0295	3.9438		3.9438
14		3.9438	3.9438		4.0295
15					3.9438
16					.5144
17					.5144
19					.5144
20					.5144
21					.5144
22					.5144
23	.5144	.5144	.5144	.5144	.5144
24		.5144	.5144	.5144	
Max	**.5144**	**4.0295**	**3.9438**	**.5144**	**4.1152**
Min	**.5144**	**.5144**	**.5144**	**.5144**	**.5144**
Avg	**.5144**	**1.8519**	**2.1262**	**.5144**	**1.9505**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274081 / 33/11 KV PENUR
Feeder No / Name : 205 / 11 KV YEWATI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5144	.5144	.5144	
2		.5144	.5144	.5144	
3		.5144	.5144	.5144	
4		.5144	.5144	.5144	
5		.5144	.5144	.5144	
15		3.4294	3.4294		
16		3.4294	3.4294		
17		3.4294			
19			.5144	.5144	.5144
20			.5144	.5144	.5144
21			.5144	.5144	.5144
22			.5144	.5144	
23	.5144	.5144	.5144	.5144	3.4294
24		.5144	.5144	.5144	
Max	**.5144**	**3.4294**	**3.4294**	**.5144**	**3.4294**
Min	**.5144**	**.5144**	**.5144**	**.5144**	**.5144**
Avg	**.5144**	**1.3889**	**.9629**	**.5144**	**1.2432**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274081 / 33/11 KV PENUR
Feeder No / Name : 206 / 11 KV PENUR GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6859	.6859	.6859	
2		.6859	.6859	.6859	
3		.6859	.6859	.6859	
4		.6859	.6859	.6859	
5		.6859	.6859	.6859	
11					.6859
12					.6859
14			.6859		.6859
15		.6859	.6859		.6859
16		.6859	.6859		.6859
17		.6859	.6859		.6859
18		.6859	.6859	.6859	.6859
19		.6859	.6859	.6859	.6859
20		.6859	.6859	.6859	.6859
21		.6859	.6859	.6859	.6859
22		.6859	.6859	.6859	.6859
23	.6859	.6859	.6859	.6859	.6859
24		.6859	.6859	.6859	
Max	**.6859**	**.6859**	**.6859**	**.6859**	**.6859**
Min	**.6859**	**.6859**	**.6859**	**.6859**	**.6859**
Avg	**.6859**	**.6859**	**.6859**	**.6859**	**.6859**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274082 / 33/11 KV SHETPHAL
Feeder No / Name : 201 / 11 KV ASHTI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)
16	2.7435	
17	3.0026	
18	2.8502	
19	2.4996	.2058
20	2.271	.1715
21	2.0729	.1372
22		.1372
23		1.89
Max	**3.0026**	**1.89**
Min	**2.0729**	**.1372**
Avg	**2.5733**	**.5083**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274082 / 33/11 KV SHETPHAL
Feeder No / Name : 204 / 11 KV BAIRAGWADI AG SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)
10	2.0729	2.3015
11	2.1338	2.1033
12	2.1948	2.271
13	1.7985	2.0271
14	1.7833	2.3929
15	2.0729	2.2862
16		2.4082
17		2.6216
18		2.1795
19	.4801	2.3015
20	.463	2.2862
21	.4287	2.21
22		1.9814
23		1.8747
Max	2.1948	2.6216
Min	.4287	1.8747
Avg	1.492	2.2318

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274082 / 33/11 KV SHETPHAL
Feeder No / Name : 205 / 11 KV SHETFAL GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)
10	.3944	.3944
11	.3048	.3429
12	.2572	.3429
13	.2058	.2743
14	.1715	.2743
15	.2572	.2572
16	.2572	.2572
17	.3429	.3086
18	.4287	
19	.5144	.5487
20	.5144	.5144
21	.4287	.4287
22		.3429
23		.2572
Max	.5144	.5487
Min	.1715	.2572
Avg	.3398	.3495

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274082 / 33/11 KV SHETPHAL
Feeder No / Name : 209 / 11 KV TELANGWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)
10		2.0119
11		1.9509
12		2.2405
14		1.7833
16		1.6004
17		1.9814
19	.2572	.2915
20	.2058	.2572
21	.1715	
22		.1543
23		.12
Max	**.2572**	**2.2405**
Min	**.1715**	**.12**
Avg	**.2115**	**1.2391**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274112 / 33/11 KV KURUL
Feeder No / Name : 203 / 11 KV ANKOLI AG SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.096			1.1717
2		.096			
3		.096			
4		.096			
5		.144			
6		.144			1.2029
7		.208			1.7185
8		.16			
9		.144			
10			1.768		.108
11		2.2024	1.8623		.112
12		2.2672	2.4006		.112
13		2.1376	2.1052		.112
14		2.1862	2.1862		.096
15		2.0081	2.2291		.112
16			2.2291		.112
17			1.9204		.112
18			.1715		.112
19			.2058		.112
20			.2058		.112
21			.1715		.112
22	.096				.9602
23	.096			1.0155	
24		.096			1.0936
Max	**.096**	**2.2672**	**2.4006**	**1.0155**	**1.7185**
Min	**.096**	**.096**	**.1715**	**1.0155**	**.096**
Avg	**.096**	**.8054**	**1.4546**	**1.0155**	**.4395**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274112 / 33/11 KV KURUL
Feeder No / Name : 204 / 11 KV KURUL GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2881			.3258
2		.3041			
3		.3201			
4		.4001			
5		.4321			
6		.5761			.6344
7		.5601	.5182		.6274
8		.5121	.5182		
9		.4801	.4534		
10			.4801		.463
11			.4115		.4481
12			.4973		.4321
13			.4801		.3841
14			.4458		.3521
15			.3601		.3201
16			.3772		.4321
17			.3944		.4801
18			.4287		.5601
19			.6687		.5281
20			.7716		.4961
21			.7202		.4641
22	.3521				.4001
23	.2881			.3189	.3521
24		.2881			.3403
Max	**.3521**	**.5761**	**.7716**	**.3189**	**.6344**
Min	**.2881**	**.2881**	**.3601**	**.3189**	**.3201**
Avg	**.3201**	**.4161**	**.5017**	**.3189**	**.4467**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] **BU 1350**
Substation No/ Name :- 274112 / 33/11 KV KURUL
Feeder No / Name : 205 / 11 KV NEW KURUL **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2483			.1235
2		1.2163			
3		1.2163			
4		1.2323			
5		1.2483			
6		1.6004			.216
7		1.7604	1.8138		.2623
8		.144	.2105		
9		.144	.1619		
10			.1134		2.0833
11			.12		2.2405
12			.12		
13			.12		2.3365
14			.12		2.3205
15			.12		2.2405
16					2.3205
17					2.4006
18			.1457		.192
19			.1886		.192
20			.2058		.192
21			.1619		.192
22	1.1203				.16
23	1.2803			.1562	.16
24		1.2803			.1389
Max	**1.2803**	**1.7604**	**1.8138**	**.1562**	**2.4006**
Min	**1.1203**	**.144**	**.1134**	**.1562**	**.1235**
Avg	**1.2003**	**1.1091**	**.2770**	**.1562**	**1.0454**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274112 / 33/11 KV KURUL
Feeder No / Name : 206 / 11 KV SHEJBABHULGAON SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2241			1.5242
2		.2241			
3		.2401			
4		.2401			
5		.2401			
6		.3041			1.5804
7		.4481	.3725		2.363
8		.3201	.3401		
9		.2721	.2915		
10			2.7263		.2107
11			2.7435		.2401
12			2.915		.2401
13			2.7435		.2401
14			2.6578		
15			2.7949		.2401
16			2.7435		.2401
17			2.4863		.2561
18			.2229		.2561
19			.3258		.2401
20			.3429		.2561
21			.3429		.2561
22	.2561				1.4403
23	.2241			1.4022	1.6004
24		.2241			1.3847
Max	**.2561**	**.4481**	**2.915**	**1.4022**	**2.363**
Min	**.2241**	**.2241**	**.2229**	**1.4022**	**.2107**
Avg	**.2401**	**.2737**	**1.6033**	**1.4022**	**.7393**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274112 / 33/11 KV KURUL
Feeder No / Name : 207 / 11 KV S.WARWADE AG SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1683			.108
2		1.1523			
3		1.1523			
4		1.1523			
5		1.1523			
6		1.3603			.1852
7		1.9364	1.9433		.2315
8		.16	.2267		
9		.16	.1781		
10			.1717		2.1605
11			.1717		2.3685
12			.1543		2.4806
13			.1372		2.3685
14			.1372		
15			.1717		2.0005
16					2.0005
17			.1543		2.0005
18			.1543		.208
19			.2229		.192
20			.2229		.192
21			.2229		.16
22	1.1203				.144
23	1.1523			.1372	.128
24		1.2003			.1235
Max	**1.1523**	**1.9364**	**1.9433**	**.1372**	**2.4806**
Min	**1.1203**	**.16**	**.1372**	**.1372**	**.108**
Avg	**1.1363**	**1.0595**	**.3049**	**.1372**	**1.0030**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274126 / 33/11 KV CHANDRAMOULI
Feeder No / Name : 201 / 11 KV CHANDRAMOULI ESTATE SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7373		
2		.7045		
3		.7127		
4		.6882		
5		.6554		
6		.6554		
7		.7045		
16		.5735	.3277	
17		.6268	.4477	.663
18		.6201	.4477	.5636
19		.5316	.3582	.6299
20		.5373	.3544	.5801
21	.6962	.6268	.4525	.5304
22	.6962			.5365
23	.7459			.5087
24		.7545		
Max	**.7459**	**.7545**	**.4525**	**.663**
Min	**.6962**	**.5316**	**.3277**	**.5087**
Avg	**.7128**	**.6520**	**.3980**	**.5732**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274126 / 33/11 KV CHANDRAMOULI
Feeder No / Name : 203 / 11 KV WADWAL GAVTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3052		
2		.3052		
3		.3391		
4		.373		
5		.4161		
6		.4961		
7		.6697		
15			.3277	
16		.3277		
17		.4334	.4733	.3391
18		.5201	.4681	.5083
19		.5609	.5548	.567
20		.4784	.5258	.5316
21	.4161	.4382	.4382	.4557
22	.3391			.407
23	.3052			.3506
24		.3052		
Max	**.4161**	**.6697**	**.5548**	**.567**
Min	**.3052**	**.3052**	**.3277**	**.3391**
Avg	**.3535**	**.4263**	**.4647**	**.4513**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274126 / 33/11 KV CHANDRAMOULI
Feeder No / Name : 204 / 11 KV VARDHMAN EXPRESS FEEDER Feeder KV- 11 / OUTGOING NON SHEDDABLE EXPRESS HV FEEDERS (CONTINOUS PROCESS)(NO STAGGERING)

DATE	18-DEC-17	19-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.037
2			.0332
3			.037
4			.0373
5			.037
6			.037
7			.037
8			.037
9			.0373
10			.037
11			.037
12			.037
13			.037
14			.037
15			.037
16	.0366	.0366	.0366
17	.0362	.0362	.0549
18	.0362	.0362	.0549
19	.0362	.0358	.0366
20	.0362	.0362	.0366
21	.0362	.0362	.0366
22			.0366
23			.0366
24			.0373
Max	**.0366**	**.0366**	**.0549**
Min	**.0362**	**.0358**	**.0332**
Avg	**.0363**	**.0362**	**.0383**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274194 / 33/11 KV BHAMBEWADI
Feeder No / Name : 201 / 11 KV BHAMBHEWADI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3239	.2915	1.7147	1.9433
2		.3239	.2915	1.7147	1.9433
3		.381	.2743	1.749	1.9052
4		.4001	.3772	1.869	2.1338
5		.4954	.4115	1.8347	2.3243
6		.6859	.4801	1.9376	2.4768
7				2.4006	2.553
10		2.7435	2.915		
11		2.8635	3.0521	.2915	.3258
12		2.8292	2.6749	.2401	.3429
13		2.6749	2.572		.2229
14		2.572	2.4006		.2229
15		2.8121	2.6063		.2572
16		2.7435	2.934		
17	2.8292	2.8807	2.9721	.2401	.2572
18			.4572	.5144	.3429
19		.3429	.6859	.6859	.4115
20		.4458	.5906	.6668	.4801
21		.3772	.4763	.4572	.463
22		.3429	1.9243	1.9624	1.749
23		.3086	1.9052	2.0195	1.7147
24		.3239	.3086	1.7147	1.9814
Max	**2.8292**	**2.8807**	**3.0521**	**2.4006**	**2.553**
Min	**2.8292**	**.3086**	**.2743**	**.2401**	**.2229**
Avg	**2.8292**	**1.3435**	**1.4572**	**1.2949**	**1.2026**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274194 / 33/11 KV BHAMBEWADI
Feeder No / Name : 202 / 11kv Ashte SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4954	.3429	.1715	.1715
2		.381	.3086	.1715	.1905
3		.381	.3086	.1886	.1905
4		.4001	.3429	.1886	.2858
5		.4382	.3772	.2229	.381
6		.4763	.4115	.4801	.4763
7		.4954			
10				.8573	.8573
11		.1372	.1543	.8745	.9259
12		.1715	.1715	.8402	.9431
13		.1715	.1715		.8573
14		.1715	.1543		.8916
15		.1372	.1715		.8573
16		.1372	.1905		.8916
17	.1715	.1886	.2667	.8916	.6687
18		.2058	.362	.2477	.1372
19		.8059	.4763	.381	.1543
20		.8573	.3429	.4191	.1715
21		.7888	.3048	.2477	.0171
22		.2229	.2286	.2477	.12
23		1.1317	.2286	.1715	.1372
24		.4954	.3772	.1715	.1715
Max	**.1715**	**1.1317**	**.4763**	**.8916**	**.9431**
Min	**.1715**	**.1372**	**.1543**	**.1715**	**.0171**
Avg	**.1715**	**.4138**	**.2846**	**.3984**	**.4522**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274201 / 33/11 KV KURANWADI(ASHTI)
Feeder No / Name : 201 / 11 KV KURANWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0594	.0469	.0469	.0469	.0469	.0469	.4744
2	.0594	.0469	.0469	.0469	.0625	.0469	.4999
3	.0594	.0625	.0469	.0655	.0633	.0625	.5693
4	.0594	.0625	.0625	.0655	.0625	.0633	.6325
5	.0594	.0781	.0781	.0625	.0633	.0772	.7042
6	.0892	.0937	.0937	.0949	.0937	.0949	.759
7							1.1069
10	.6836	.9374	.7968	.7499	.8322	.7748	
11	.7727	1.0155	.9374	.7811	.8697		
12	.8322	.9842	.9998	.8124	.8436		
13	.8619	1.0155	1.0155		.8436		
14	.8916	1.0467	1.0467	.6249	.8905		
15	.9065	.9998	.9998	.8124	.9374		
16	.9214	1.0311	.9374	.9061	1.0242		
17	.9362	.9998	.9374	.7811	.9172		
19	.0743	.0625	.0625	.0469	.0625	.0625	.0625
20	.0743	.0625	.0469	.0469	.0625	.0633	.0633
21	.0594	.0469	.0469	.0469	.0474	.0633	.0469
22	.0594	.0469	.0469	.0469	.0469	.3437	.3906
23	.0594	.0469	.0469	.0486	.048	.3749	.4111
24	.0594	.0625	.0469	.0648	.0633	.0469	.4111
Max	**.9362**	**1.0467**	**1.0467**	**.9061**	**1.0242**	**.7748**	**1.1069**
Min	**.0594**	**.0469**	**.0469**	**.0469**	**.0469**	**.0469**	**.0469**
Avg	**.3789**	**.4374**	**.4171**	**.3237**	**.3941**	**.1632**	**.4717**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274201 / 33/11 KV KURANWADI(ASHTI)
Feeder No / Name : 202 / 11 KV ASHTI GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.2218	.2218	.2218	.1898	.2218	.2195
2	.2218	.2218	.2218	.2218	.192	.2195	.2172
3	.2587	.2587	.2587	.2587	.2187	.2587	.2507
4	.2439	.2957	.3326	.3326	.25	.3292	.2896
5	.4435	.3326	.4435	.4066	.2846	.4344	.362
6	.5544	.5175	.5175	.5544	.4801	.5487	.5068
7	.4066	.4435	.4805	.4066	.3163	.5121	.5068
8	.3696	.3696	.4066	.3696	.3239	.4435	.4706
9	.2587	.3326	.3326	.3326	.2812	.2957	.394
10	.2218		.2218	.2587	.2267	.2172	.3258
11	.1848	.1848		.2772	.1562		.2172
12	.1478	.1848	.1478	.1478	.125		.181
13	.1478	.1848	.1478	.1109	.0949		.181
14	.1478	.1478	.1109	.0739	.125		.1463
15	.1478	.1478	.1109	.1109	.1265		.1463
16	.1848	.1848	.1109	.1848	.125		.1829
17	.2587	.2218		.1848	.1581		.1829
18	.3326	.3326	.3326	.3326	.2881		.3292
19	.3326		.4435	.4805	.3841	.362	.439
20	.3696	.3696	.3696	.4066	.3201	.439	.4024
21	.3326	.3326	.3326	.2957	.2881	.3658	.3292
22	.2439	.2957	.2957	.2587	.2214	.2957	.2926
23	.2587	.2587	.2587	.2218	.1898	.2561	.2561
24	.1829	.2218	.2218	.2218	.1898	.2195	.2218
Max	**.5544**	**.5175**	**.5175**	**.5544**	**.4801**	**.5487**	**.5068**
Min	**.1478**	**.1478**	**.1109**	**.0739**	**.0949**	**.2172**	**.1463**
Avg	**.2697**	**.2755**	**.2873**	**.2780**	**.2315**	**.3387**	**.2938**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274201 / 33/11 KV KURANWADI(ASHTI)
Feeder No / Name : 203 / 11 KV MASOBA AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	1.3927	1.3927	1.7328	1.6712	1.6194	.0983
2	1.2803	1.4251	1.4575	1.7328	1.7204	1.6385	.0983
3	1.2498	1.4575	1.5223	1.7814	1.6518	1.704	.0983
4	1.3413	1.5546	1.6194	1.8138	1.7695	1.692	.1311
5	1.3717	1.6518	1.7166	1.8461	1.7814	1.7236	.1475
6	1.4632	2.0698	1.8461	1.8461	1.9006	1.8027	
7	1.9814	2.1052	2.17	1.9757	2.13	2.0241	
10							2.0153
11							2.2119
12							2.2348
13							2.2348
14							2.2024
15							2.2611
16							2.2283
17							2.2283
19	.1219	.0972	.0972	.0972	.1296	.125	.1311
20	.1219	.0972	.0972	.1296	.1311	.125	.1311
21	.0914	.0648	.081	.0648	.0983	.125	.1296
22	1.1584	1.3927	1.4575	1.5223	1.5074	.0949	.0972
23	1.2193	1.4251	1.5384	1.5546	1.5402	.0949	.0972
24	1.2498	1.3765	1.3279	1.6194	1.6194	1.587	.0972
Max	**1.9814**	**2.1052**	**2.17**	**1.9757**	**2.13**	**2.0241**	**2.2611**
Min	**.0914**	**.0648**	**.081**	**.0648**	**.0983**	**.0949**	**.0972**
Avg	**1.0669**	**1.2392**	**1.2557**	**1.3628**	**1.3578**	**1.1043**	**.9934**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274205 / 33/11 KV DEWADI
Feeder No / Name : 202 / 11 KV DEWADI AG SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3717	1.3717	1.3375	.3086
2		1.4575	1.3203	1.3546	.2915
3		1.4575	1.3375	1.406	.2743
4		1.5432	1.3375	1.4746	.3086
5		1.5947	1.5604	1.6118	.3258
6		2.0576	2.0233	1.8861	.3086
7		2.8464	3.0864	2.4691	.3086
10					2.4177
11					2.8978
12					3.0178
13					3.0521
14					3.0864
15					3.0693
16					3.0521
17					2.8978
19		.3429	.4801	.4801	.2915
20		.3258	.4287	.4287	.3086
21		.3258	.3429	.3429	.3258
22	1.4575	1.1317		.3429	.3429
23	1.5432	1.3717		.3086	.3601
24		1.4575	1.406	1.3717	.3258
Max	**1.5432**	**2.8464**	**3.0864**	**2.4691**	**3.0864**
Min	**1.4575**	**.3258**	**.3429**	**.3086**	**.2743**
Avg	**1.5004**	**1.3295**	**1.3359**	**1.1396**	**1.3129**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274205 / 33/11 KV DEWADI
Feeder No / Name : 203 / 11 KV WAFALE AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3086	.3429	.3429	1.3717
2		.3429	.3772	.3944	1.4575
3		.3086	.4287	.4458	1.5432
4		.4287	.4801	.5144	1.6632
5		.5658	.583	.583	2.0233
6		.6173	.6687	.6173	2.9492
7					3.1207
10		2.3148	2.4006		
11		2.4863	2.6063		
12		2.0576	2.7092		
13		2.572			
14		2.6063	2.6406		
15		2.915	2.5377		
16		2.7778	2.3663		
17		2.6578	2.572		
18			2.572		
19		.6001	.6173	.6859	.4115
20		.5658	.4801	.6001	.4458
21		.4458	.4801	.4801	.4287
22	.3944	.4287		1.2689	1.0117
23	.3429	.4115		1.3032	1.1488
24		.3429	.3772	.3772	1.3375
Max	**.3944**	**2.915**	**2.7092**	**1.3032**	**3.1207**
Min	**.3429**	**.3086**	**.3429**	**.3429**	**.4115**
Avg	**.3687**	**1.2877**	**1.4022**	**.6344**	**1.4548**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] **BU 1350**
Substation No/ Name :- 274205 / 33/11 KV DEWADI
Feeder No / Name : 205 / 11 KV DEWADI - WAFALE GAOTHAN FEEDER
GAONTHAN Feeder KV- 11 /
OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2572	.2401	.2401	.3429
2		.2572	.2229	.2401	.3258
3		.2743		.2743	.3429
4		.2743		.2915	.3601
5		.2915	.3258	.3429	.3772
6		.3258	.3772	.3772	.3429
7		.3258	.3944	.3429	.3086
8		.2915	.3258	.3086	.3086
9		.2572	.2915	.2743	.3429
10		.1886	.2229		.2572
11		.1715	.2058		.2401
12		.1543	.2058		.2058
13		.1543	.1715		.1886
14		.1543	.1715		.1715
15		.1543	.1372		.2229
16		.1886	.1372		.2572
17		.1886	.1715		.3086
18		.3086	.2743		.3429
19		.3772	.3429	.3772	.3772
20		.3601	.3429	.3944	.3944
21		.2743	.3086	.3772	.3429
22	.3258	.2572		.3429	.3086
23	.3086	.2572		.3601	.2915
24		.2743	.2401	.2572	.3429
Max	**.3258**	**.3772**	**.3944**	**.3944**	**.3944**
Min	**.3086**	**.1543**	**.1372**	**.2401**	**.1715**
Avg	**.3172**	**.2508**	**.2555**	**.3201**	**.3043**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274229 / 33/11 KV WAD-DEGAON S/S
Feeder No / Name : 201 / 11 KV NEW KOTHALE AG (WAD- SEPARATED AG FEEDERS HAVING SPECIAL DEGA Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.9145	.7621	
2	.9145	.7621	
3	.9145	.8573	
4	1.0059	.8078	
5	1.0669	.9145	
6	1.0974	1.0669	
7	1.3413	1.3717	
8	.1543	.0857	
9			.1372
10			1.0974
11			1.4022
15			1.7071
16	.1372		1.829
17	.1029		
18	.12		
19	.1543		
20	.1543		
21	.1372		
22	.8573		
23	.7621		
24	.9145	.7621	
Max	**1.3413**	**1.3717**	**1.829**
Min	**.1029**	**.0857**	**.1372**
Avg	**.6323**	**.8211**	**1.2346**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274229 / 33/11 KV WAD-DEGAON S/S
Feeder No / Name : 202 / 11 KV WAD-DEGOAN AG (WAD-DEGAV Feeder KV- 11 / OUTGOING SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.0669	1.0059	
2	1.0669	1.0814	
3	1.0669	1.0059	
4	1.0974	1.1126	
5	1.2193	1.1126	
6	1.4937	1.5242	
7	1.9052		
8	.12		
9			.1029
10			1.5851
11			2.0424
12			1.9814
13			2.0424
14			2.0424
16			1.768
17	.0857		
18	.1029		
19	.1372		
20	.1372		
21	.1029		
22	1.0059		
23	1.0059		
24	1.0669	1.0059	
Max	**1.9052**	**1.5242**	**2.0424**
Min	**.0857**	**1.0059**	**.1029**
Avg	**.7926**	**1.1212**	**1.6521**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274229 / 33/11 KV WAD-DEGAON S/S
Feeder No / Name : 203 / 11 KV AUNDHI AG (WAD-DEGAV SEPARATED AG FEEDERS HAVING SPECIAL S.S Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2058	.1886	
2	.2058	.1886	
3	.2058	.1886	
4	.2401	.2058	
5	.3086	.2058	
6	.3601	.3086	
7	.3944	.3429	
8	.3429	.3429	
9			.2058
10			.1829
11			.6706
15			.2035
16			.1715
17	1.3717		.1715
18	.2229		
19	.2743		
20	.2401		
21	.2058		
22	.2058		
23	.1886		
24	.2058	.1886	
Max	**1.3717**	**.3429**	**.6706**
Min	**.1886**	**.1886**	**.1715**
Avg	**.3237**	**.2400**	**.2676**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274230 / 33/11 KV JAMGAON S/S
Feeder No / Name : 201 / 11 KV JAMGAON AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	.823
2	.0343	.0343	.0343	.8573
3	.0343	.0343	.0514	.8916
4	.0514	.0343	.0514	.8916
5	.0514	.0514	.0514	.9602
6	.0514	.0514	.0514	1.0288
7	.0343	.0514	.0514	1.0974
8	.0343	.0514	.0514	.0514
9	.0686		.0514	.0514
10	.823	.823	.823	.0343
11		.9602		.0343
12	1.166	1.1317		.0343
13	.583	1.2003		.0343
14	.9945	1.2003		.0343
15	1.166	1.2346		.0171
16	.0343	1.2346		.0171
17	.583	1.2346	.0514	.0343
18	.0343	.0514	.0514	.0343
19	.0514	.0514	.0514	.0343
20	.0514	.0514	.0514	.0343
21	.0343	.0514	.0514	.0343
22	.0343	.0343	.5144	.3429
23	.0343	.0343	.6173	.4115
24	.0343	.0343	.0343	.7202
Max	**1.166**	**1.2346**	**.823**	**1.0974**
Min	**.0343**	**.0343**	**.0343**	**.0171**
Avg	**.2617**	**.4205**	**.1486**	**.3544**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274230 / 33/11 KV JAMGAON S/S
Feeder No / Name : 202 / 11 KV KORAWALI AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.3546	1.2689	.1029
2	1.2689	1.3889	1.3717	.1029
3	1.3717	1.5947	1.5432	.1029
4	1.5432	1.6804	1.5775	.1372
5	1.8176	1.7661	1.6118	.1372
6	1.989	1.9204	1.7147	.1372
7	2.1262	2.0233	1.7661	.1372
8	.1372	.1543	.1543	.1372
9	.1372	.1372	.1372	.1372
10		.1029	.0686	2.3148
11	.1372	.0857		2.3663
12		.0857		1.7147
13	.12	.0857		1.6975
14	.1029	.0857		2.2119
15	.0686	.1029		2.1776
16	.0857	.1029		2.1434
17	.1029	.2229	1.869	2.2119
18	.1372	.1715	.1372	.1372
19	.1543	.1543	.1372	.1543
20	.1543	.1372	.1372	.1372
21	.1372	.1372	.1372	.1372
22	.9945	.8916	.1372	
23	1.0631	1.166	.1372	
24	.8916	1.0802	1.2003	.1029
Max	**2.1262**	**2.0233**	**1.869**	**2.3663**
Min	**.0686**	**.0857**	**.0686**	**.1029**
Avg	**.7077**	**.6930**	**.8393**	**.8472**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274230 / 33/11 KV JAMGAON S/S
Feeder No / Name : 203 / 11 KV JAMGAON GAONTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.0857	.0857	.1029
2	.1029	.0857	.0857	.1029
3	.1029	.0857	.0857	.12
4	.1372	.1029	.1543	.1543
5	.1715	.1543	.1886	.1886
6	.2058	.2229	.2229	.2401
7	.2401	.2572	.2572	.2572
8	.1715	.1715	.2058	.2572
9	.1372	.12	.1372	.1372
10	.1029	.1029	.0686	.1029
11		.0686		.1029
12	.0686	.0686		.0686
13	.0686	.0686		.0686
14	.0857	.0686		.0686
15	.0857	.0857		.0686
16	.0857	.0857		.0686
17	.1029	.1029	.0857	.1029
18	.1543	.1372	.1029	.1715
19	.2229	.1372	.12	.2229
20	.1715	.2058	.1715	.1715
21	.1543	.2229	.2058	.1715
22	.1372	.1886	.2401	
23	.1029	.1715	.1715	
24	.1029	.1029	.12	.1029
Max	**.2401**	**.2572**	**.2572**	**.2572**
Min	**.0686**	**.0686**	**.0686**	**.0686**
Avg	**.1312**	**.1293**	**.1505**	**.1387**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274234 / 33/11 KV HIVARE S/S
Feeder No / Name : 201 / 11 KV YAWALI AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)
1	.6097	.7926
2	.6401	.884
3	1.448	.9145
4	.7316	1.3717
5	1.1126	1.5242
6	1.2803	1.6766
7	2.0271	2.5606
8	.3963	.5316
9	.2743	
10		.3258
11		.2572
12		.1715
13		.1715
14		.2058
15		.2058
16		.2229
17		.2229
18	.4287	.3601
19	.4287	.4458
20	.3772	.3429
21	.3258	.3086
22	.7468	.823
23	.7468	.884
24	.5639	.7468
Max	**2.0271**	**2.5606**
Min	**.2743**	**.1715**
Avg	**.7586**	**.6935**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
MOHOL S/DN.[097] BU 1350
Substation No/ Name :- 274234 / 33/11 KV HIVARE S/S
Feeder No / Name : 202 / BHAGIRATH GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)
1	.12	.12
2	.1029	.1029
3	.1029	.1372
4	.12	.1886
5	.1543	.2229
6	.2058	.2572
7	.2401	.2401
8	.2058	.2229
9	.2058	
10	.1715	
11		.1715
12		.1715
13		.1715
14		.1715
15		.1715
16		.1886
17		.2058
18	.2572	.2743
19	.3429	.2743
20	.3086	.2572
21	.2572	.2085
22	.1372	.1372
23	.1219	.12
24	.12	.1372
Max	**.3429**	**.2743**
Min	**.1029**	**.1029**
Avg	**.1867**	**.1887**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1
Feeder No / Name : 201 / 11KV Sakal SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-DEC-17	16-DEC-17	18-DEC-17	19-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6535	.6908	.2401
2			.6348	.6908	.2557
3			.6535	.6722	.2561
4			.6468	.6653	.2439
5			.6653	.6468	.2601
6			.6283	.6468	.2561
7			.7282	.6468	.2683
9			.9774		
10			.9774		
11			.9945		
12			1.0288		
13			1.0631		
14			1.0974		
17		1.1622	1.1812	1.086	
18			.9997	.8131	
19	.9242		1.0288		
20			.7023		
21			.6516		
22			.6838		
23					.5731
24			.6535	.6908	.2629
Max	**.9242**	**1.1622**	**1.1812**	**1.086**	**.5731**
Min	**.9242**	**1.1622**	**.6283**	**.6468**	**.2401**
Avg	**.9242**	**1.1622**	**.8325**	**.7249**	**.2907**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1
Feeder No / Name : 202 / 11KV VENKY SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-DEC-17	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1509			.1307
2			.132	.112		.112
3			.132	.112		.0934
4			.112	.0934		.0943
5			.0934	.0934		.0754
6			.0934	.0934		.0747
7			.0747	.0934		.056
9			.0857			
10			.1715			
11			.2058			
12			.2229			
13			.2229			
14			.2229			
17	.2452	.2263	.2263	.2452	.2452	
18	.2075		.1509	.2075		
19	.1886		.1509			
20			.1698			
21			.1698			
22			.1509			
23						.1698
24			.1509	.1307		.1509
Max	**.2452**	**.2263**	**.2263**	**.2452**	**.2452**	**.1698**
Min	**.1886**	**.2263**	**.0747**	**.0934**	**.2452**	**.056**
Avg	**.2138**	**.2263**	**.1545**	**.1312**	**.2452**	**.1064**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1
Feeder No / Name : 203 / 11 KV Smruti Express Feeder Feeder KV- 11 / OUTGOING NON SHEDDABLE EXPRESS HV FEEDERS (CONTINOUS PROCESS)(NO STAGGERING)

DATE	15-DEC-17	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4904	.4668		.4338
2				.4481		.4382
3			.4763	.4481		.4572
4			.4572	.4668		.4572
5			.4382			
6			.415	.4668		.4527
7			.3961	.4904		.4481
9			.4287			
10			.4115			
11			.4115			
12			.4287			
13			.4287			
14			.4458			
17	.6036	.4338	.4904	.4715	.3961	
18	.5847		.4527	.4904		
19	.5847		.4338			
20			.4527			
21			.4527			
22			.4527			
23						.5093
24			.4904	.4715		.4481
Max	**.6036**	**.4338**	**.4904**	**.4904**	**.3961**	**.5093**
Min	**.5847**	**.4338**	**.3961**	**.4481**	**.3961**	**.4338**
Avg	**.591**	**.4338**	**.4449**	**.4689**	**.3961**	**.4556**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1
Feeder No / Name : 204 / 11KV BANG DATA SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-DEC-17	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
17	.6602	.9619	1.1317	.8676	.8488	
18	.9997		.9619	.8573		
19	.9619		1.0374			
20			.679			
21			.743			
22			.7167			
23						.6478
Max	**.9997**	**.9619**	**1.1317**	**.8676**	**.8488**	**.6478**
Min	**.6602**	**.9619**	**.679**	**.8573**	**.8488**	**.6478**
Avg	**.8739**	**.9619**	**.8783**	**.8625**	**.8488**	**.6478**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1
Feeder No / Name : 205 / 11KV BPL SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-DEC-17	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.9335			.415
2			.8962	.7922		.4338
3				.7733		.4108
4			.8676	.7545		.3921
5			.9054	.7842		.3921
6			.9431	.7655		.4338
7			1.0082	.7468		.4527
9			.8916			
10			.7545			
11			.8573			
12			.9259			
13			.8916			
14			.8573			
17	1.3203	1.0185	1.0185	1.0562	.2641	
18			.9431	.8299		
19	.8676		.8299			
20			.7167			
21			.8676			
22			.7922			
23						.7545
24			.9431	.8299		.3961
Max	**1.3203**	**1.0185**	**1.0185**	**1.0562**	**.2641**	**.7545**
Min	**.8676**	**1.0185**	**.7167**	**.7468**	**.2641**	**.3921**
Avg	**1.0940**	**1.0185**	**.8865**	**.8147**	**.2641**	**.4534**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1
Feeder No / Name : 206 / 11KV INDIAN OIL GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.9335		.9335
2			.9149	.9709		.9795
3			.9709	1.0642		1.0456
4			1.0642	1.0829		1.094
5			1.1088	1.1203		1.1317
6			1.2696	1.1949		1.1949
7			1.3256	1.251		1.307
9			.9088			
10			1.0117			
11			.9945			
12			.9774			
13			.9431			
14			.7716			
17		1.1827	.9694	.9774	.9313	
18			1.3169	1.1946		
19	1.4266		1.386			
20			1.1643			
21			1.1016			
22			.9619			
23						.8299
24			.9335	.8962		.8962
Max	**1.4266**	**1.1827**	**1.386**	**1.251**	**.9313**	**1.307**
Min	**1.4266**	**1.1827**	**.7716**	**.8962**	**.9313**	**.8299**
Avg	**1.4266**	**1.1827**	**1.0576**	**1.0686**	**.9313**	**1.0458**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1
Feeder No / Name : 207 / 11KV AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	18-DEC-17	19-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1307	.1494	1.1203
2				.1494	1.0829
3			.1494		1.1576
4			.1698	.1509	
5			.1867	.1698	1.2696
6			.1867	.1867	1.3443
7			.2054	.1867	1.4563
10			1.4746		
11			1.5775		
12			1.6289		
13			1.6289		
14			1.6632		
17	1.4706	1.3272	1.6032	1.3426	
18	.1492		.1132	.1132	
19	.096		.2075		
20			.1886		
21			.1886		
22			.1509		
23					.9014
24			.1494	.1494	1.0269
Max	**1.4706**	**1.3272**	**1.6632**	**1.3426**	**1.4563**
Min	**.096**	**1.3272**	**.1132**	**.1132**	**.9014**
Avg	**.5719**	**1.3272**	**.6446**	**.2887**	**1.1699**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1
Feeder No / Name : 210 / 11kv ASHOK POLYMERS Exp. NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	15-DEC-17	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.9709	.9335		.583
2			.9335	.8962		.5243
3			.8962	.8686		.4858
4			.8589	.8501		.4973
5			.8131	.8131		.5197
6			.811	.8029		.5304
7			.811	.8402		.57
9			1.0802			
10			.9945			
11			1.1145			
12			1.1488			
13			1.0974			
14			1.046			
17		1.1273	1.1949	1.134	.7449	
18			1.1273	1.2696		
19	.5182		1.1273			
20			1.0498			
21			.985			
22			1.0454			
23						.8328
24			.9896	.9709		.6722
Max	**.5182**	**1.1273**	**1.1949**	**1.2696**	**.7449**	**.8328**
Min	**.5182**	**1.1273**	**.811**	**.8029**	**.7449**	**.4858**
Avg	**.5182**	**1.1273**	**1.0048**	**.9379**	**.7449**	**.5795**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 274083 / 33/11 KV AKOLEKATI
Feeder No / Name : 201 / 11KV KARAMBA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905		.5735	.5182
2	.1905		.6062	.5182
3	.1905		.6706	.503
4	.1905		.7545	.503
5	.1905		1.1568	.6371
6	.1905		1.2574	1.0059
7	.1905		1.3077	1.1869
8	.1905		.1905	
9	.1905		.1905	
10	.9568	1.2289	.1905	.1905
11	1.0997	1.2616	.1905	.1905
12	1.1012			.1905
13	1.1469	1.3108		
14	1.0526	1.3763	.1905	
15	1.1248	1.2944	.1905	.1905
16	1.034	1.2289	.1905	.1905
17	1.166	1.1469	.1905	2.0576
18	.1905	.1905	.1905	.1905
19	.1905	.1905	.1905	.1905
20	.1905	.1905	.1905	.1905
21	.1905	.1905	.1905	.1905
22	.1905	.6009	.5735	.7682
23	.1905	.6154	.5898	.7449
24	.1905		.5898	.5898
Max	**1.166**	**1.3763**	**1.3077**	**2.0576**
Min	**.1905**	**.1905**	**.1905**	**.1905**
Avg	**.4888**	**.8328**	**.4712**	**.5374**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 274083 / 33/11 KV AKOLEKATI
Feeder No / Name : 203 / 11 KV AKOLEKATI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.1905	.2829	.3734
2	.7316	.1905	.2641	.4108
3	.7011	.1905	.2641	.4108
4	.9755	.1905	.3395	.4481
5	1.3592	.1905	.4527	.5601
6	1.4883	.1905	.5093	.7095
7	1.7004	.1905	.7356	
8	.679	.1905	.5415	
9	.4527		.4481	
10		.132	1.0254	1.2193
11	.2263	.1509	1.1294	1.2803
12	.1886	.132		1.3413
13	.1698	.1307		1.4937
14	.1132	.1307	1.1584	
15	.1132	.1509	1.46	1.5432
16	.132	.1698	1.3108	1.5586
17		.2263	.5556	1.5339
18	.4481	.3584	.2614	.5281
19	.5788	.547	.4854	.6602
20	.7282	.4481	.5975	.5281
21	.4854	.3961	.4854	
22	.5944	.3361	.3734	.3206
23	.6722	.3206	.3734	.3018
24	.7621	.1905	.3018	.3734
Max	**1.7004**	**.547**	**1.46**	**1.5586**
Min	**.1132**	**.1307**	**.2614**	**.3018**
Avg	**.6392**	**.2324**	**.6071**	**.8208**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 274083 / 33/11 KV AKOLEKATI
Feeder No / Name : 204 / 11KV MARDI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7095	.7655	.823	.7888
2	.7095	.6535	.7973	.78
3	.6722	.7282	.8859	.8139
4	.8962	.9522	1.0745	.8139
5	1.0642	1.1949	1.1919	1.1022
6	1.2883	1.307	1.4022	1.387
7			1.4899	1.7857
8	1.2696	.9335		
9	1.419	.9335		
10	1.3094	1.3077		
11	1.2266	1.3413		
12	1.3592	1.4251		
13	1.5927	1.4922		
14	1.491	1.5424		
15	1.3757	1.5089		.6348
16	1.5257	1.4419		
17		1.4251		.7468
18	.7421	.8029	.8962	1.0269
19	.9335	1.251	1.2136	1.1203
20	1.3443	1.1576	1.3443	1.0829
21	1.0082	1.0269	1.1016	1.0456
22	.9335	.779	.7975	.9221
23	.7468	.7712	.823	.8886
24	.7468	.8962	.8059	.7975
Max	**1.5927**	**1.5424**	**1.4899**	**1.7857**
Min	**.6722**	**.6535**	**.7973**	**.6348**
Avg	**1.1075**	**1.1147**	**1.0462**	**.9836**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 274083 / 33/11 KV AKOLEKATI
Feeder No / Name : 205 / 11kv Banegaon SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1195	.1132	1.1241	1.1431
2	.1195	.1069	1.1812	1.1431
3	.1132	.1303	1.3336	1.2193
4	.1646	.152	1.7147	1.448
5	.2058	.2743	2.0005	1.6956
6	.2881	.3332	2.2481	1.8671
7	.3978	.4271	2.3624	1.9433
8	.3429	.3269	.2515	
9			.2389	
10	2.0767	2.2481	.2606	.1692
11	2.4387	2.3624	.2534	.1269
12	2.5339			.1198
13	2.572			.0846
14	2.5149	1.7337		.0916
15	2.4577	2.4196	.1006	.0817
16	2.0005	2.4768	.1372	.1006
17	.1524	2.2862	.192	.1132
18	.2606	.2201	.2058	.2606
19	.2641	.2734	.2058	.3429
20	.3647	.2389	.3041	.282
21	.2012	.1823	.2534	.2256
22	.2172	1.1431	1.1431	1.448
23	.2027	1.105	1.1812	1.4098
24	.1195	.152	1.086	1.1812
Max	**2.572**	**2.4768**	**2.3624**	**1.9433**
Min	**.1132**	**.1069**	**.1006**	**.0817**
Avg	**.8751**	**.8907**	**.8466**	**.7499**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 274083 / 33/11 KV AKOLEKATI
Feeder No / Name : 206 / 11kv BB Darphal SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4329	.2936	.0381	.0381
2	.4001	.3591	.0381	.0381
3	.3887	.4599	.0381	.0381
4	.4664	.5361	.0762	.0381
5	.57	.6068	.0953	.0762
6	.7276	.6811	.1143	.0953
7	.8297	.743	.1334	.0762
8	.0953	.0762	.0953	
9	.0953		.0762	
10	.0572	.0381	.5578	.7442
11	.0381	.0381	.6341	.743
12	.0381	.0381		.7926
13	.0381	.0381		.1532
14	.0381	.0381	.7087	.6127
15	.0381	.0381	.823	.6893
16	.0381	.0381	.7926	.7148
17	.0381	.0381	.7276	.7659
18	.0381	.0572		.0572
19	.0572	.0953	.0762	.0762
20	.0953	.0762	.0953	.0953
21	.0762	.0381	.0572	.0572
22	.2353	.0381	.0381	.0572
23	.3788	.0381	.0381	.0572
24	.4464	.3887	.0381	.0381
Max	**.8297**	**.743**	**.823**	**.7926**
Min	**.0381**	**.0381**	**.0381**	**.0381**
Avg	**.2357**	**.2084**	**.2520**	**.2752**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 274083 / 33/11 KV AKOLEKATI
Feeder No / Name : 207 / 11 KV Narotewadi SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1276	.1404	.2286	.3429
2	.1276	.108	.2667	
3	.1257	.1276	.3239	.381
4	.1257	.1404	.4191	.381
5	.176	.1659	.5335	.4572
6	.217	.216	.6097	
7	.3286	.0255	.7621	.7621
8	.2715	.2425	.1772	
9	.1915		.1536	
10		.7049	.1276	.2
11		.8192	.1143	.1429
12	.8002	.8383		.1429
13	.8383	.8764		.1286
14	.7621	.9145	.0686	.1021
15	.8192	.8764	.0766	.1021
16	.7049	.8383	.0894	.0894
17	.4382	.8383	.1276	.1276
18		.2008	.1532	.1915
19	.2401	.2601	.1787	.2553
20	.217	.217	.2553	.217
21	.1894	.1915	.2042	.1659
22	.1915	.2858	.2667	.4001
23	.168	.2667	.3048	.381
24	.1276	.1623	.2667	.3048
Max	**.8383**	**.9145**	**.7621**	**.7621**
Min	**.1257**	**.0255**	**.0686**	**.0894**
Avg	**.3423**	**.4112**	**.2595**	**.2638**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 274083 / 33/11 KV AKOLEKATI
Feeder No / Name : 208 / 11KV SAWITRIBAI FULE EXP NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.0572	.0572
2		.0572	.0553
3		.0572	.0553
4		.0572	.0572
5		.0572	.0591
6		.0572	.061
7		.0572	.0667
8		.0572	
9		.0762	
10	.0762		.0572
11	.0762		.0953
12	.0762		.0953
13	.0762		.0572
14	.0762	.0553	.0572
15	.0572	.0705	.0572
16	.0572	.0648	.0572
17	.0572	.061	.724
18	.0572	.061	.0572
19	.0572	.061	.0762
20	.0572	.0667	.0762
21	.0572	.0667	.0762
22	.0572		.0572
23	.0572	.061	.0572
24		.0572	.0591
Max	**.0762**	**.0762**	**.724**
Min	**.0572**	**.0553**	**.0553**
Avg	**.0640**	**.061**	**.0942**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 274089 / 33/11 KV WADALA
Feeder No / Name : 201 / 11 KV PADASALI Ag. SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.9281	2.4417	.3048	.3048
2		1.8625	2.4756	.3048	.3048
3		1.9387	2.4348	.3048	.3429
4		1.8781	2.4143	.3429	.381
5		2.2085	2.4863	.3429	.381
6		2.8807	2.0348		
7		3.0521	2.8166		
8	3.0476				
10				2.5911	3.3234
11				2.6871	3.1855
12					2.652
13					3.0521
14	.1524	.2667			3.2594
15	.2286	.2667	.3429		3.1855
16	.381	.381			3.1893
17	.5335			2.6871	3.0521
18	.2286				
19	.2667	.4572	.2667		.4572
20	.2667	.4191	.381	.3048	.5335
21	.2667	.3429	.381	.381	.4572
22	2.2436	2.332	.381	.3048	.4191
23	1.8652	2.5095	.3429	.3048	.3048
24		1.7147	2.4863	.1524	.3048
Max	**3.0476**	**3.0521**	**2.8166**	**2.6871**	**3.3234**
Min	**.1524**	**.2667**	**.2667**	**.1524**	**.3048**
Avg	**.8619**	**1.5274**	**1.5490**	**.8472**	**1.5311**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 274089 / 33/11 KV WADALA
Feeder No / Name : 204 / 11KV Gaothan Wadala GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8951	.6661	.9602	.8478
2		.9945	.6836	.9831	.9816
3		1.153	.7802	1.153	1.2437
4		1.5074	1.3077		1.4883
5		1.5261	1.56	1.5432	1.6126
8		1.1919	1.2346	1.166	1.166
9		1.0288		1.1191	1.0852
10		.7712	.8573	.8589	.8764
11		.6661	.6661	.7712	.7282
12		.6733	.5138		.6024
13		.5373	.4961		.5731
14		.5609	.4607		.5144
15		.4973	.443		.5138
16		.5144	.4961		.5258
17		.5373	.6104	.7716	.5434
18		1.4883	1.0517	1.0974	1.0288
19		1.4864	1.1869	1.3672	1.3904
20		1.3847	1.4746	1.4582	1.2689
21	1.0174	1.0749	1.278	1.3032	1.1218
22	.9945	.7537	1.0852	.9945	.7545
23	.9602	.631	.9503	.9114	.5596
24		.8478	.6379	.9602	.78
Max	**1.0174**	**1.5261**	**1.56**	**1.5432**	**1.6126**
Min	**.9602**	**.4973**	**.443**	**.7712**	**.5138**
Avg	**.9907**	**.9419**	**.8781**	**1.0887**	**.9185**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 274089 / 33/11 KV WADALA
Feeder No / Name : 205 / 11KV Shelgaon AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5424	1.3226	.0762	.0762
2		1.6461	1.286	.0762	.0762
3		1.7974	1.2742	.0762	.0762
4		1.8107	1.3226	.0762	.0762
5		2.1216	1.3426	.0762	.0762
6		2.3838	1.6975		.0762
7	2.7664	2.572	2.3137		.0762
10				1.9334	2.5434
11				2.13	2.7978
12					2.5652
13					3.035
14	.0762	.0762			2.8487
15	.0762	.1143			2.6658
16	.0762	.1143			2.4348
17	.0762	.1715		1.6095	2.2131
18	.0762	.1143			
19	.0762	.0762	.0762	.0762	.0762
20	.0762	.0762		.0762	.0762
21	.0762	.0762	.0762	.0762	.0762
22	1.6804	1.286	.0762	.0762	.0762
23	1.5939	1.3077	.0762	.0762	.0762
24		1.4918	1.3717	.0762	.0762
Max	**2.7664**	**2.572**	**2.3137**	**2.13**	**3.035**
Min	**.0762**	**.0762**	**.0762**	**.0762**	**.0762**
Avg	**.6046**	**1.0433**	**1.0196**	**.4651**	**1.0521**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 274089 / 33/11 KV WADALA
Feeder No / Name : 206 / 11KV Nannaj Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1524	.1524	1.2003	.7122
2		.1524	.1524	1.2437	.8139
3		.1524	.1143	1.2048	.8413
4		.1524	.1524	1.2136	1.0029
5		.1524	.1524	1.4685	1.2178
6				1.6575	1.382
7				1.7436	2.489
10	1.7695	2.0576	1.643		
11		2.5652	2.0645		
12	2.0119	2.652	2.3266		
13	2.8182	2.8334	1.8442		
14	2.7199	2.8464	2.13		
15	2.8121	2.2539	2.5263		
16	2.7846	2.1948	2.2939		.2286
17	2.7435	1.9204	2.1735		.2286
18	.1524	.1905	.1524	.1524	.2286
19	.1524	.2286	.1524	.1524	.2667
20	.1905	.2286	.1524	.1524	.2667
21	.1905	.1905	.1524	.9816	.2286
22	.1905	.1143	1.7147	.9145	1.2003
23	.1905	.1524	1.3565	.9145	1.3226
24		.1905	.1524	1.2689	.788
Max	**2.8182**	**2.8464**	**2.5263**	**1.7436**	**2.489**
Min	**.1524**	**.1143**	**.1143**	**.1524**	**.2286**
Avg	**1.4405**	**1.0691**	**1.0780**	**1.0192**	**.8261**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 274089 / 33/11 KV WADALA
Feeder No / Name : 207 / 11KV LokmangalR&D Exp NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
10	.0572	.0381	
11	.0381	.0381	.0191
12	.0381		.0191
13	.0381		.0191
14	.0381		.0381
15	.0381		.0381
16	.0381		.0381
17	.0381		.0191
Max	**.0572**	**.0381**	**.0381**
Min	**.0381**	**.0381**	**.0191**
Avg	**.0405**	**.0381**	**.0272**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 274168 / 33/11 KV MIDC C. KATI - 2
Feeder No / Name : 201 / 11KV Rama SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3772	.2641	.1509
2	.3429	.3772	.2641	.1509
3	.3086	.3429	.2263	.1509
4	.3086	.3429	.2263	.1509
5	.2743	.2572	.1886	.1509
6	.2401	.2572	.1886	.1509
7	.2058	.1715	.1509	.1509
8	.3018	.2743	.1509	.1886
9		.3772	.1509	.2641
10	.415	.4527	.1509	.4904
11	.4527	.4904	.1509	.4527
12	.415	.5281	.1509	.4527
13	.2641	.3772	.1509	.3018
14	.3772	.5658	.1509	
15	.4904	.4527	.1509	
16	.5281	.5281	.1509	
17	.4115	.4527	.1509	.5658
18	.4115	.415	.0754	.5658
19	.3429	.3395	.1509	.4527
20	.3429	.2641	.1509	.3018
21	.3429	.3395	.1886	.3018
22	.3772	.3018	.1509	.2641
23	.3772	.3395	.1509	.2641
24	.3429	.3772	.3395	.1509
Max	**.5281**	**.5658**	**.3395**	**.5658**
Min	**.2058**	**.1715**	**.0754**	**.1509**
Avg	**.3572**	**.3751**	**.1760**	**.2892**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 274168 / 33/11 KV MIDC C. KATI - 2
Feeder No / Name : 202 / 11KV Bhutada SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	1.0974	1.2012	.9054
2	1.2003	1.0974	1.1883	.9431
3	1.166	1.0974	1.2637	.9619
4	1.166	1.0802	1.1273	.9054
5	1.1488	1.0802	1.2197	.8865
6	1.1488	1.0802	1.1827	.924
7	1.1317	1.0631	1.2197	.9979
8	1.358	1.166	1.1317	1.2567
9	1.6598	1.6032	1.1643	1.6448
10	1.6032	1.9239	1.1506	1.905
11	1.5278	1.7918	1.1317	2.0182
12	1.7541	1.8673	1.7164	2.0182
13	1.7918	1.4146	1.1883	1.6221
14	1.6221	1.5089	1.094	1.6409
15	1.8861	1.6975	1.1694	
16	1.5278	1.6032	1.0374	
17	1.3375		1.0425	1.6032
18	1.2346	1.386	1.2071	1.6032
19	1.0631	1.2567	1.1273	1.5655
20	1.0288	1.2936	1.1643	1.5655
21	1.0288		1.1088	1.4146
22	1.0631	1.2382	1.0534	1.3203
23	1.0974	1.2936	.9054	1.5089
24	1.2003	1.0974	1.2752	.961
Max	**1.8861**	**1.9239**	**1.7164**	**2.0182**
Min	**1.0288**	**1.0631**	**.9054**	**.8865**
Avg	**1.3311**	**1.3517**	**1.1696**	**1.3715**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 274168 / 33/11 KV MIDC C. KATI - 2
Feeder No / Name : 205 / 11KV LDK SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.166	1.0288	.811	.811
2	1.0974	.9431	1.2936	.7545
3	1.0288	.9431	.7392	.7922
4	.9431	.8573	.7733	.7167
5	.9431	.7716	.7922	.7545
6	.7888	.7202	.7392	.7922
7	.6859	.6516	.7545	.7922
8	.8299	.7545	.7577	.8488
9	.8676	.9431	.8215	1.1827
10	1.1694	1.1317		1.2826
11	1.4146	1.094	.8488	1.4146
12	1.358	1.0374	.7922	1.4335
13	1.2449	1.1506	.7167	1.3769
14	1.5089	1.2637	.7733	
15	1.4335	1.2637	.8676	
16	1.4712	1.4523	.8488	
17	1.2689	1.2382	.7167	1.358
18	1.2689	1.2936	.6838	1.3392
19	1.2689	1.3121	.7545	1.2826
20	1.2003	.8552	.7356	1.1883
21	1.2003	1.1643	.7762	
22	1.166	1.2012	.8676	1.226
23	1.166	1.1088	.811	1.1694
24	1.166	1.166	.7762	.7577
Max	**1.5089**	**1.4523**	**1.2936**	**1.4335**
Min	**.6859**	**.6516**	**.6838**	**.7167**
Avg	**1.1524**	**1.0561**	**.8022**	**1.0637**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 274168 / 33/11 KV MIDC C. KATI - 2
Feeder No / Name : 206 / 11KV V.Datta SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.5144	.5093	.5093
2	.7202	.5144	.4715	.4904
3	.7202	.4801	.5093	.5281
4	.6516	.4801	.4715	.5093
5	.6173	.4801	.5093	.547
6	.5144	.4801	.4715	.5093
7	.4801	.463	.4715	.5281
8	.6224	.5144	.5093	.5847
9	.679	.6224	.4527	.6413
10	.7545	.6224	.415	.6979
11	.8488	.6036	.4904	
12	.7733	.5658	.4527	.8676
13	.7356	.7167	.4904	
14	.8299	.6602	.4527	.6602
15	.811	.8488	.4338	
16	.8488	.7922	.4715	
17	.7202	.7356	.5093	.7545
18	.6859	.7545	.4904	.6979
19	.6001	.7167	.4527	.7167
20	.5487	.5847	.5093	.7167
21	.5144	.5658	.5281	.6602
22	.5144	.6036	.5281	.6602
23	.5144	.5658	.5093	.5847
24	.7545	.5144	.547	.5658
Max	**.8488**	**.8488**	**.547**	**.8676**
Min	**.4801**	**.463**	**.415**	**.4904**
Avg	**.6756**	**.6000**	**.4857**	**.6215**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 274168 / 33/11 KV MIDC C. KATI - 2
Feeder No / Name : 207 / 11KV Venky Express NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.7888	.7545	1.0534
2	.6859	.7888	.7922	.961
3	.6859	.7888	.811	.9795
4	.6859	.7716	.7733	.924
5	.6859	.7716	.7545	1.0349
6	.6516	.7716	.7167	.9795
7	.6516	.7716	.2641	.924
8	.7922	.823	.6224	.9979
9	.9054	.9054	.8676	
10	.9431	.9242	.9997	1.1694
11	.9431	.9242	1.1128	1.1883
12	.8865	.9619	.415	.7356
13	.9054	.8676	.3206	1.0374
14	.8488	.9054	1.0562	
15	.9054	.9054	1.0185	.7545
16	.9619	.8865	1.1506	1.1317
17		.8865	1.0534	1.1694
18		.8676	1.0164	1.1694
19		.9054	.9808	1.0374
20		.7545	1.0349	.9997
21	.7545	.7733	.9795	1.0374
22	.7202	.7545	1.0534	1.0562
23	.7888	.7922	1.0534	1.0185
24	.6859	.7888	.7922	.9979
Max	**.9619**	**.9619**	**1.1506**	**1.1883**
Min	**.6516**	**.7545**	**.2641**	**.7356**
Avg	**.7887**	**.8366**	**.8497**	**1.0162**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 274168 / 33/11 KV MIDC C. KATI - 2
Feeder No / Name : 401 / 33KV KOTHARI PRIMA NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1543	.2263	
2	.1029	.1543	.1698	
3	.1029	.1543	.1698	
4	.1029	.1543	.1698	
5	.1029	.1029	.1698	
6	.1029	.1029		
7	.1029	.1543		
8	.1132	.1543		.2263
9	.1698	.1132		.1698
10	.1132	.1698		.1698
11	.1698	.1698		.1698
12	.1698	.1698		.1698
13	.1698	.1698		.1698
14	.1132	.1698		
15	.1132	.1698		
16	.1698	.1698		
17	.1543	.1698		.3395
18	.1543	1.6409		.2829
19	.1543	.2263		.2263
20	.1543	.2263		.2263
21	.1543	.1698		.2829
22	.1543	.1698		.3395
23	.1543	.1698		.2263
24	.1029	.1543	.1698	
Max	**.1698**	**1.6409**	**.2263**	**.3395**
Min	**.1029**	**.1029**	**.1698**	**.1698**
Avg	**.1335**	**.2234**	**.1792**	**.2307**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 274183 / 33/11 KV VASANT VIHAR
Feeder No / Name : 201 / 11KV Vasant Vihar SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1991	.1991	.2172	.1991
2		.1991	.1991	.1991	.1991
3		.181	.181	.1991	.1991
4		.1629	.1629	.181	.1991
5		.1629	.181	.181	.1991
6		.1991	.2172	.1991	.2172
7		.2896	.3258	.3258	.2896
8		.2896	.3258	.3439	.3077
9	.2715	.2896	.2534	.3258	.3258
10	.2715	.2353	.2534	.2715	.2715
11	.2534	.2715	.1991	.2353	.2353
12	.2353	.2534	.2172	.2172	.2353
13	.2172	.2172	.2172		.1991
14	.1991	.1991	.2172	.2172	.1448
15	.1991	.1991	.2353	.181	
16		.2172	.2172	.181	.2172
17		.2172	.2172	.181	.2172
18		.2896	.2896	.2715	.2534
19		.3439	.3439	.3439	.3439
20		.3439	.3439	.3439	.3439
21		.3258		.3258	.3077
22	.2715	.2896		.3077	.3077
23	.2353	.2715		.2534	.2534
24		.2172	.2353	.2353	.2172
Max	**.2715**	**.3439**	**.3439**	**.3439**	**.3439**
Min	**.1991**	**.1629**	**.1629**	**.181**	**.1448**
Avg	**.2393**	**.2444**	**.2396**	**.2495**	**.2471**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 274183 / 33/11 KV VASANT VIHAR
Feeder No / Name : 202 / 11KV BHOGAON SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9955	1.0498	.9774	1.0498
2		.9955	.9955	.9412	.9955
3		.9593	.9593	.9412	1.0498
4		1.086	1.086	1.0679	1.1041
5		1.2489	1.2851	1.3394	1.3213
6		1.5927	1.6832	1.647	1.6832
7		1.7194	1.7918	1.8461	1.9366
8		1.7194	1.5746	1.8823	1.8642
9	1.7375	1.5023	1.267	1.6289	1.6289
10	1.3575	1.448	1.2127	1.4661	1.5203
11		1.3575	1.267	1.3394	1.2851
12	1.1765	1.3756	1.1946	1.2489	1.3394
13	1.1403	1.4661	1.1946		1.267
14	1.1041	1.3213	1.3032	1.3032	1.4299
15	1.1041	1.267	1.3394	1.2851	1.3575
16		1.1403	1.4118	1.0679	1.3575
17		1.4118	1.3032	1.448	1.4118
18		1.7194	1.6108	1.5746	1.647
19		1.828	1.8823	1.828	1.6651
20		1.6651	1.6651	1.7194	1.6651
21		1.5203		1.5203	1.4842
22	1.3032	1.3394		1.3213	1.2127
23	1.1222	1.1403	1.1041	1.1584	1.1041
24		1.0317	1.0679	1.0136	1.086
Max	**1.7375**	**1.828**	**1.8823**	**1.8823**	**1.9366**
Min	**1.1041**	**.9593**	**.9593**	**.9412**	**.9955**
Avg	**1.2557**	**1.3688**	**1.3295**	**1.3724**	**1.3944**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 274215 / 33/11 KV KALMAN
Feeder No / Name : 201 / 11KV BHAGAIWADI GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17
HR	Load (MW)	Load (MW)
1	.168	.1905
2	.2241	.1715
3	.4481	.2286
4	.1867	.3429
5	.1867	.362
6	.1867	.4572
7	.3734	.4954
8	.168	
9	.1905	
10	.2286	
11	.1334	
12	.1143	
13	.1143	
14	.0953	
15	.0953	
16	.1143	
17	.1715	
18	.3429	
19	.4572	
20	.4001	
21	.3429	
22	.2286	
23	.2286	
24	.112	.2096
Max	**.4572**	**.4954**
Min	**.0953**	**.1715**
Avg	**.2213**	**.3072**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 274215 / 33/11 KV KALMAN
Feeder No / Name : 202 / 11KV SAKHAREWADI AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17
HR	Load (MW)	Load (MW)
1	1.4864	1.2765
2	1.9978	1.2955
3	1.6762	1.4098
4	1.7711	1.4289
5	1.866	1.4289
6	1.9608	1.8099
7	1.9608	1.9624
22	1.5242	
23	1.6194	
24	1.4864	1.6385
Max	**1.9978**	**1.9624**
Min	**1.4864**	**1.2765**
Avg	**1.7349**	**1.5313**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 274215 / 33/11 KV KALMAN
Feeder No / Name : 203 / 11KV KAUTHALI AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17
HR	Load (MW)
10	1.1812
11	1.448
12	1.7528
13	1.8099
14	1.6385
15	1.6766
16	1.6194
17	1.6004
Max	**1.8099**
Min	**1.1812**
Avg	**1.5909**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 277002 / 132/33/11 KV DEGAON
Feeder No / Name : 203 / 11KV NEHRU NAGAR Ag. SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.7204		1.5746	.0924	.0914
2		1.7204		1.4746	.0924	.0914
3		1.7204		1.4746	.0924	.0914
4		1.7204		1.5746	.0924	.0914
5		1.7204		1.6575	.0924	.0914
6		1.9062		1.6575	.0924	.0914
7		2.2377		1.8233	.0924	.0924
8		.0857		.0905	.0924	.0914
9				.0914	.0829	
10				.0914	2.0719	
11				.0905	2.6282	
13		.08			2.6825	
14		.08			2.8502	
15		.081			2.934	
16		.0829			2.6825	
17			.0905			1.9062
18			.0924			.0934
19			.0924			.0934
20			.0924			.0934
21			.0924			.0934
22	1.6385		1.4575	.0924	.0905	
23	1.8233		1.6385	.0924	.0914	
24		1.8233		1.5746	.0924	.0914
Max	**1.8233**	**2.2377**	**1.6385**	**1.8233**	**2.934**	**1.9062**
Min	**1.6385**	**.08**	**.0905**	**.0905**	**.0829**	**.0914**
Avg	**1.7309**	**1.1522**	**.5080**	**.9543**	**.9414**	**.2217**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 277002 / 132/33/11 KV DEGAON
Feeder No / Name : 204 / 11KV DEGAON-AG- SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0953		.0953	2.2653	2.3434
2		.0953		.0953	2.2653	2.1605
3		.0953		.0953	2.2809	2.1605
4		.0953		.0953	2.1872	2.1605
5		.0953		.0953	2.1872	2.2653
6		.0953		.0953	2.372	2.372
7		.0943		.0943	2.7206	2.753
8		.0953		.0953	.0953	.0953
9				.0953	.0953	
10				3.7294	.0953	
11				3.7685	.0953	
12				3.6046	.0953	
13		3.6046		3.6046	.0953	
14		3.6046		3.5227	.0953	
15		3.6046		3.6046	.0953	
16		3.0769		3.5227	.0953	
17			3.2388			.0953
18			.0953			.0953
19			.0953			.0953
20			.0953			.0953
21			.0943			.0953
22	.0953		.0953	2.4006	2.3434	
23	.0953		.0953	2.3434	2.4215	
24		.0953		.0953	2.2929	2.3434
Max	**.0953**	**3.6046**	**3.2388**	**3.7685**	**2.7206**	**2.753**
Min	**.0953**	**.0943**	**.0943**	**.0943**	**.0953**	**.0953**
Avg	**.0953**	**1.1344**	**.5442**	**1.6344**	**1.2734**	**1.3665**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 277002 / 132/33/11 KV DEGAON
Feeder No / Name : 207 / 11KV BALE SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3765		1.2955	.0905	.0914
2		1.3765		1.2955	.1753	.1734
3		1.3765		1.2955	.1772	.1734
4		1.3765		1.2955	.1772	.1734
5		1.4575		1.3927	.1753	.1734
6		1.6385		1.5565	.1753	.1734
7				1.989		.1734
8		.1867		.181	.1848	.181
9				.1848	.1638	
10				.1829	1.8023	
11				.1829	2.1548	
12					2.3205	
13		.1886		.1848	2.3205	
14		.1886		.1829	2.3205	
15		.0934		.181	2.2377	
16		.1867		.181	2.1548	
17			.0934			2.13
18			.1848			.1886
19			.1829			.1886
20			.181			.1867
21			.181			.1867
22	1.3927		1.2955	.1829	.1848	
23	1.3765		1.2803	.0895	.0924	
24		1.4746		1.2955	.0905	.0914
Max	**1.3927**	**1.6385**	**1.2955**	**1.989**	**2.3205**	**2.13**
Min	**1.3765**	**.0934**	**.0934**	**.0895**	**.0905**	**.0914**
Avg	**1.3846**	**.9101**	**.4856**	**.7305**	**.9443**	**.3061**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 277002 / 132/33/11 KV DEGAON
Feeder No / Name : 209 / 11KV TIKEKAR WADI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0829		.0819	.5468	.6173
2		.0829		.0819	.5468	.6173
3		.0829		.0819	.5468	.6173
4		.0829		.0819	.5468	.6173
5		.0829		.0819	.6325	.703
6		.0829		.0819	.7116	.8002
7		.1658		.0819	.8802	1.0526
8		.0819		.0819	.0819	.0829
9				.0819	.0819	
10				.8802	.0953	
11				.9602	.0819	
12				1.0402	.0819	
13		1.0279		1.0402	.0819	
14		1.0279			.0819	
15		.9488			.0819	
16		1.0279		.0781	.0819	
17			.8592			.0953
18			.0819			.0829
19			.0829			.0819
20			.0829			.0819
21			.0819			.0819
22	.0819		.0829	.5468	.6249	
23	.0819		.0829	.5401	.6249	
24		.0829		.0829	.5468	.6173
Max	**.0819**	**1.0279**	**.8592**	**1.0402**	**.8802**	**1.0526**
Min	**.0819**	**.0819**	**.0819**	**.0781**	**.0819**	**.0819**
Avg	**.0819**	**.3739**	**.1935**	**.3474**	**.3662**	**.4392**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 277002 / 132/33/11 KV DEGAON
Feeder No / Name : 210 / 11KV GAONTHAN DEGAON GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.443		.443	.443	.443
2		.443		.443	.443	.443
3		.443		.443	.443	.443
4		.5373		.5373	.443	.5373
5		.6268		.6401	.5316	.724
6		1.0164		1.0269	.6335	.924
7		1.0269		1.0269	.924	.924
8		1.0269		.9431	1.0269	.924
9				.6335	.8145	
10				.543	.6335	
11				.4525	.5373	
12				.4572	.543	
13		.362		.4477	.4572	
14		.362		.4525		
15		.362		.4525		
16		.2715		.4525	.543	
17			.5487			.6335
18			.7392			.823
19			.8316			.924
20			.7316			.924
21			.543			.724
22	.5373		.443	.543	.543	
23	.443		.443	.443	.4477	
24		.443		.443	.443	.4477
Max	**.5373**	**1.0269**	**.8316**	**1.0269**	**1.0269**	**.924**
Min	**.443**	**.2715**	**.443**	**.443**	**.443**	**.443**
Avg	**.4902**	**.5664**	**.6114**	**.5697**	**.5794**	**.7028**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-I S/DN.[094] BU 1325
Substation No/ Name :- 277002 / 132/33/11 KV DEGAON
Feeder No / Name : 213 / 11KV URBAN DEGAON NEW GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1753		.1753	.1772	.1772
2		.1753		.1753	.1772	.1772
3		.1753		.1753	.1772	.1772
4		.1753		.1753	.1772	.1791
5		.2658		.2686	.1772	.2715
6		.2686		.2686	.2715	.3658
7		.2686		.2686	.2715	.2715
8		.2715		.2686	.2715	.2715
9				.1791	.2743	
10					.1791	
11				.1829	.1829	
12				.181	.181	
13				.1848	.1848	
14		.1791		.1772	.1848	
15		.1791		.181	.1829	
16		.1829		.1829	.1829	
17			.1829			.1791
18			.2743			.2715
19			.2743			.2715
20			.2743			.2715
21			.181			.1791
22	.2686		.1791	.1791	.1791	
23	.1753		.1753	.1772	.1772	
24		.1753		.1753	.1772	.1772
Max	**.2686**	**.2715**	**.2743**	**.2686**	**.2743**	**.3658**
Min	**.1753**	**.1753**	**.1753**	**.1753**	**.1772**	**.1772**
Avg	**.2220**	**.2077**	**.2202**	**.1987**	**.1993**	**.2315**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274091 / 33/11 KV ANTROLI
Feeder No / Name : 201 / 11 KV VINCHUR SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	1.9605	.1905	.1905
2	2.0576	1.9605	.1905	.1905
3	2.0576	1.9605	.1905	.1905
4	2.0576	1.9605	.1905	.1905
5	2.0576	2.0538	.1905	.1905
6	2.4006	2.4272	.2286	.1905
7	2.7435	2.5873	.2858	.1905
8	.1905	.2286	.2858	.1905
9	.1905	.1905		.1905
10	.1905	.1905	2.2786	2.0576
11	.1905	.1905	2.2786	2.0576
12	.1905	.1905		2.4006
13	.1524			2.572
14	.1334	.1905		2.572
15	.1143	.1905		2.572
16	.1524	.1905		2.572
17	.1715	.1905	1.8861	2.572
18	.2286		.1905	.1905
19	.2667	.2858	.1905	.1905
20	.2667	.2858	.1905	.1905
21	.2477	.1905	.1905	.1905
22	1.9605	.1905	.1905	.1905
23	1.9605	.1905	.1905	.1905
24	2.0576	1.9605	.1905	.1905
Max	**2.7435**	**2.5873**	**2.2786**	**2.572**
Min	**.1143**	**.1905**	**.1905**	**.1905**
Avg	**1.0040**	**.8985**	**.5294**	**.9343**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274091 / 33/11 KV ANTROLI
Feeder No / Name : 202 / 11 KV VADAPUR SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	1.7375	1.6651
2	.1905	.1905	1.7556	1.6289
3	.1905	.1905	1.7375	1.7147
4	.1905	.1905	1.7375	1.6575
5	.1905	.1905	1.8099	1.8233
6	.2858	.1905	1.9909	1.989
7	.2858	.2286	2.2624	
8	.1905	.2286	.2477	
9	.1905	.1715		
10	2.524	2.3285	.1905	.1905
11	2.7166	2.652	.1905	.1905
12	2.9199	2.8275		.1905
13	3.0308	2.963		.1905
14	3.0493	2.9938		.1905
15	3.0123	2.6326		.1905
16	2.8645	2.6606		.1905
17	2.8645	2.6147	.1905	.1905
18	.1905	.1524	.1905	.2286
19	.2286	.2286	.1905	.2858
20	.2286	.2667	.1905	.2858
21	.2096	.2286	.1905	.1905
22	.1905	1.6632	1.4918	1.6289
23	.1905	1.6632	1.5432	1.8004
24	.1905	.1905	1.7375	1.6651
Max	**3.0493**	**2.9938**	**2.2624**	**1.989**
Min	**.1905**	**.1524**	**.1905**	**.1905**
Avg	**1.0965**	**1.1599**	**1.0769**	**.8613**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274091 / 33/11 KV ANTROLI
Feeder No / Name : 203 / 11 KV KUSUR SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.4763	2.0119	2.1434
2	.4763	.4763	1.9909	2.1434
3	.4763	.4763	1.9909	2.2291
4	.4763	.4763	1.9909	2.2969
5	.4763	.4763	1.9909	2.431
6	.6668	.5906	2.3529	2.4646
7	.6668	.7049	2.6612	2.4646
8	.4763	.5525	.362	.381
9	.2858	.2667	.4572	.4763
10	3.1786	2.9384	.5716	.5716
11	3.3634	3.0226		.5716
12	3.4004	3.271		.6668
13		2.2965		.6668
14	3.4558	2.0485		.6668
15	3.2526	2.9938		.6668
16	3.1971	3.0123		
17	3.1417	2.9321	.6668	
18	.4763	.2286	.6287	.6602
19	.6478	.3048	.4763	.381
20	.6478	.3429	.381	.381
21	.6478	.2858	.0381	.2858
22	.5525	1.8823	1.8861	1.8861
23	.4763	1.848	1.8861	2.0576
24	.4763	.4763	2.0119	2.1434
Max	**3.4558**	**3.271**	**2.6612**	**2.4646**
Min	**.2858**	**.2286**	**.0381**	**.2858**
Avg	**1.3649**	**1.3492**	**1.3531**	**1.3016**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274091 / 33/11 KV ANTROLI
Feeder No / Name : 204 / 11 KV INDIAN PUBLIC SCHOOL SINGLE PHASING
(IP Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.9335	.0953	.0953
2	.9431	.9335	.0953	.0953
3	.9431	.9335	.0953	.0953
4	.9431	.9335	.0953	
5	.9431	.9335	.0953	.0953
6	1.1145	1.1203	.0953	.0953
7	1.3717	1.2136	.1334	.0953
8	.0953	.0953	.1524	.0953
9	.0953	.0953	.0572	.0953
10	.0953	.0953	.8573	1.4575
11	.0953	.0953	.8573	1.4575
12	.0953	.0953		1.5432
13	.0953	.0953		1.5432
14	.0953	.0953		1.5432
15	.0953	.0953		1.3717
16	.0953	.0953		1.3717
17	.0953	.0953	.9116	1.3717
18	.1524	.0953	.0953	
19	.1715	.1334	.1334	.0953
20	.1715	.0953	.1334	.0953
21	.1524	.0953	.1334	.0953
22	.9335	.0953	.1334	.0953
23	.9335	.0953	.1334	.0953
24	.9431	.9335	.0953	.0953
Max	**1.3717**	**1.2136**	**.9116**	**1.5432**
Min	**.0953**	**.0953**	**.0572**	**.0953**
Avg	**.4839**	**.3957**	**.2315**	**.5906**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274091 / 33/11 KV ANTROLI
Feeder No / Name : 205 / 11 KV EXPRESS FDR CRE/PHONIX Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS (CONTINOUS PROCESS)(NO STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905	.0732	.0366	.0543
2	.0905	.0924	.0343	.0532
3	.0905	.0924	.0343	.0532
4	.0905	.0914	.0351	.052
5	.0905	.0716	.0362	.052
6	.0905	.0543	.0358	.0537
7	.0905	.0358	.037	.0537
8	.0914	.0373	.0709	.0549
9	.0914	.037	.0732	.0549
10	.0554	.0358	.0514	.0554
11	.0549	.0328	.0497	.0554
12	.0543	.0324	.0497	.0924
13	.0362		.0497	.0914
14	.0362		.0343	.0914
15		.037	.0343	.0924
16				.0924
17	.0526	.0716		.0924
18	.056	.0747		.0914
19	.056	.0532	.0537	.0905
20	.056	.0543	.0716	.0905
21	.0373	.0526	.0709	.0905
22	.037	.0724	.0709	.0914
23	.037	.0543	.0693	.0924
24	.0905	.037	.0514	.0543
Max	**.0914**	**.0924**	**.0732**	**.0924**
Min	**.0362**	**.0324**	**.0343**	**.052**
Avg	**.0671**	**.0568**	**.0500**	**.0728**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274091 / 33/11 KV ANTROLI
Feeder No / Name : 207 / 11 KV KHANAPUR SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.9335	.1905	.1905
2	.6859	.9335	.1905	.1905
3	.6859	.9335	.1905	.1905
4	.6859	.9335	.1905	.1905
5	.6859	.9335	.1905	.1905
6	.7716	1.2012	.1905	.2286
7	1.1145	1.2936	.2667	.2286
8	.1905	.2286	.2286	.2286
9	.1905	.2286	.0762	.2286
10	.2477	.2096	1.3717	1.4575
11	.2096	.2477	1.3717	1.4575
12	.2096	.2667		1.4575
13	.1905	.2858		1.5432
14	.1905	.2858		1.5432
15	.1905	.2858		1.5432
16	.2096	.3048		1.5432
17	.2096	.2667	1.1768	1.4575
18	.2477	.2667	.2477	.2477
19	.2667	.3048	.2477	.2858
20	.2477	.2667	.2477	.2858
21	.2286	.1905	.2477	.1905
22	.9335	.2096	.2477	.1905
23	.9335	.1905	.1905	.1905
24	.6859	.9335	.1905	.1905
Max	**1.1145**	**1.2936**	**1.3717**	**1.5432**
Min	**.1905**	**.1905**	**.0762**	**.1905**
Avg	**.4541**	**.5056**	**.3818**	**.6438**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274093 / 33/11 KV HOTAGI
Feeder No / Name : 201 / 11 KV FATATEWADI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3003	1.286	.6602	.6401
2		1.3146	1.286	.7545	.6602
3		1.2269	1.286	.8488	.7545
4		1.2269	1.3717	1.1317	.8488
5		1.3003	1.5261	1.226	1.307
6		1.3717	1.6766	1.3203	1.4003
7		2.2291	1.8233	1.3203	
8		1.1317	1.0374	1.1317	1.1317
9		.9431	.7545		.7922
10		.6602	.5658		2.1434
11		.5658	.4715		2.1548
12		.5658	.4715		1.6385
13		.4715	.4715		1.9662
14		.4715	.4715		1.9662
15		.4715	.4715		1.9433
16		.4715	.5658		1.6194
17		.5658	.5658		1.8023
18	.9431	.8488	.9431	1.8861	.9335
19	1.1317	1.1317	1.1317	1.226	1.1203
20	1.226	1.1317	1.1317	1.3203	1.1203
21	1.0374	1.0374	1.1317	1.226	1.0269
22	1.2003	1.2003	.6602	.8488	.8402
23	1.387	1.286	.6602	.6602	.7468
24		1.387	1.286	.6602	.6602
Max	**1.387**	**2.2291**	**1.8233**	**1.8861**	**2.1548**
Min	**.9431**	**.4715**	**.4715**	**.6602**	**.6401**
Avg	**1.1543**	**1.0130**	**.9603**	**1.0814**	**1.2703**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274093 / 33/11 KV HOTAGI
Feeder No / Name : 202 / 11 KV AUJ HIPPALE YATNAL SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5658	.5658	.9431	1.0288
2		.6602	.5658	.9326	1.0288
3		.7545	.5658	1.0174	1.0288
4		.8488	.6602	1.0174	1.2136
5		1.0374	.8402	1.2003	1.3717
6		1.3203	1.307	1.4575	1.6108
7		1.3203	1.307	1.7147	2.0119
8		.5658	.9431	.9431	.8488
9		.8488	.8488	.7545	.7545
10		1.2003	1.4575	.6602	.4668
11		1.7147	1.5432	.5658	
12		1.7147	1.8861	.4715	.4715
13		1.7147	1.7147	.4715	.3772
14		1.9719	1.7147		.3772
15		2.0576	1.7147		.3772
16		2.0576	1.7147		.3772
17		1.3717	1.7147	.7545	.4668
18	.8488	.7545	.7468	.9431	.8488
19	.9431	.8488	1.0374	1.0374	.9335
20	.9431	.8488	.8488	.8488	.8402
21	.8488	.7545	.6602	.8488	.6535
22	.7545	.5658	.9431	.9431	1.1269
23	.6602	.5658	.9431	1.0288	1.0402
24		.5658	.5658	.9431	1.0288
Max	**.9431**	**2.0576**	**1.8861**	**1.7147**	**2.0119**
Min	**.6602**	**.5658**	**.5658**	**.4715**	**.3772**
Avg	**.8331**	**1.1095**	**1.1171**	**.9284**	**.8819**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274093 / 33/11 KV HOTAGI
Feeder No / Name : 203 / 11 KV HOTAGI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5658	.5601	.4715	.763	.8573
2		.5658	.5601	.4715	.763	.8573
3		.5658	.5601	.4715	.7716	.8573
4		.6602	.6535	.6602	.8573	.9431
5		.8488	.8488	.9335	.8573	.9431
6		1.0269	1.0374	1.0269	1.0059	1.0288
7		1.0269	1.1317	1.1203	1.2003	1.286
8		1.1203	1.0374	1.0374	1.0374	1.1317
9		.9431	.4715	.8488	.8488	.8488
10		.8573	.8573	1.286	.6602	.6602
11		1.0288	1.2003	1.3203	.5658	.5658
12		1.0288	1.2003	1.2003	.4287	.4715
13		1.0288	1.0288	1.2003	.4715	.4715
14		.8573	1.2003	1.2003		.3772
15		1.0288	1.2003	1.2003		.3772
16		1.0288	1.2003	1.1145		.3772
17		1.1145	1.1145	1.1145		.4715
18		.6602	.6602	.6602	.7545	.6602
19		.8488	.8488	.8488	.9431	.8488
20	.8488	.8488	.8488	.8488	.8488	.7545
21	.7545	.6602	.6602	.5658	.6602	.6602
22	.6602	.5658	.5658	.6859	.7716	.8764
23	.5658	.5658	.4715	.763	.8573	.8573
24		.5658	.5658	.4715	.7545	.8573
Max	**.8488**	**1.1203**	**1.2003**	**1.3203**	**1.2003**	**1.286**
Min	**.5658**	**.5658**	**.4715**	**.4715**	**.4287**	**.3772**
Avg	**.7073**	**.8338**	**.8535**	**.8968**	**.7910**	**.7517**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274093 / 33/11 KV HOTAGI
Feeder No / Name : 204 / 11 KV BHARAT GARMENT EXPRESS Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS (CONTINOUS PROCESS)(NO STAGGERING)

DATE	17-DEC-17	18-DEC-17	19-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.0381	.0381
2		.0381	.0381
3		.0381	.0381
4		.0381	.0381
5		.0381	.0381
6		.0381	.0381
7		.0381	.0381
8		.0381	.0381
9		.0381	.0381
10		.0381	.0381
11		.0381	.0381
12		.0381	.0381
13		.0381	.0381
14		.0381	.0381
15		.0381	.0381
16		.0381	
17		.0381	
18	.0381	.0381	
19	.0381	.0381	
20	.0381	.0381	
21	.0381	.0381	
22	.0381	.0381	
23	.0381	.0381	
24		.0381	.0381
Max	**.0381**	**.0381**	**.0381**
Min	**.0381**	**.0381**	**.0381**
Avg	**.0381**	**.0381**	**.0381**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274096 / 33/11 KV TAKALI
Feeder No / Name : 201 / 11 KV AUJ SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2715	.2172	.4287	.4287
2		.2715	.2172	.4287	.4287
3		.2715	.2172	.4287	.4287
4		.2715	.2172	.4287	.4287
5		.2715	.2715	.4287	.4287
6		.2172	.3258	.5144	.4287
7		.2172	.362	.5144	.4287
8		.2172	.3258	.2572	.2715
9		.2172	.2715	.2715	.2715
10	.2058	.3429	.5144	.181	.2715
11	.2058	.4287	.5144	.181	.2172
12	.2401	.4287	.5144	.181	.2172
13	.2058	.3429	.5144	.181	.2172
14	.2058	.3429	.5144	.181	.181
15	.2572	.3429	.5144	.181	.181
16	.2572	.3086	.5144	.181	.181
17	.3086	.3429	.5144	.181	.181
18	.2172	.2715	.2572		.2715
19	.3258	.2715	.3429	.2172	.3258
20	.2715	.3258	.362	.2715	.3258
21	.2715	.2715	.362	.2715	.2715
22	.2715	.2172	.4287	.4287	.3086
23	.2715	.2172	.4287	.4287	.3086
24		.2715	.2172	.4287	.4287
Max	**.3258**	**.4287**	**.5144**	**.5144**	**.4287**
Min	**.2058**	**.2172**	**.2172**	**.181**	**.181**
Avg	**.2511**	**.2897**	**.3725**	**.3128**	**.3096**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274096 / 33/11 KV TAKALI
Feeder No / Name : 202 / 11 KV TAKALI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4525		1.5432	1.6289
2		.362		1.5432	1.7147
3		.543	.4525	1.5432	1.7147
4		.543	.4525	1.5432	1.8004
5		.5792	.543	1.5432	1.8004
6		.6697	.5973	1.7147	1.8861
7		.6335	.6335	1.9376	1.9719
8		.5611	.5973	.5316	.543
9		.3801	.3982	.3944	
10	2.2291	2.2805	2.332	.2896	
11	2.3491	2.332	2.5034	.2172	
12	2.4348	2.3148	2.5034	.2534	
13	2.4348	2.1262	2.452	.2715	
14	2.4348	2.1091	2.4006	.2534	
15	2.4006	2.1434	2.4006	.2534	
16	2.3663	2.2291	2.2291	.2896	
17	2.3834	2.3148	2.1605	.3077	
18	.3258	.6154	.4163	.3982	
19	.543	.5068	.543	.5068	
20	.5068	.543	.543	.5792	
21	.4525	.4163	.4525	.4525	
22	.4525	.4163	1.5432	1.6289	
23	.4525	.3982	1.5432	1.6289	
24		.4525	.3982	1.5432	1.6289
Max	**2.4348**	**2.332**	**2.5034**	**1.9376**	**1.9719**
Min	**.3258**	**.362**	**.3982**	**.2172**	**.543**
Avg	**1.5547**	**1.0801**	**1.2771**	**.8820**	**1.6321**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274096 / 33/11 KV TAKALI
Feeder No / Name : 203 / 11 KV NANDANI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0288	1.2003	.2715	.2715
2		1.0288	1.286	.2572	.3258
3		1.1145	1.286	.2572	.3801
4		1.1145	1.286	.2572	.3801
5		1.1145	1.286	.3429	.3801
6		1.0631	1.286	.4287	.4163
7		1.3889	1.3375	.3944	.4163
8		.3077	.3439	.3258	.3439
9		.2534	.3077	.2353	.1448
10	.2172	.181	.181	1.3717	1.5775
11	.181	.2172	.181	1.4403	1.7147
12	.181	.2172	.181	1.4403	1.7147
13	.1629	.181	.181	1.3203	1.7147
14	.1448	.181	.181	1.4232	1.6289
15	.181	.181	.181		1.6975
16	.181	.1991	.181	1.4232	1.6118
17		.2353	.2172	1.2517	1.6118
18	.2896	.3258	.2896	.2715	.2715
19	.3982	.362	.362	.3258	.3439
20	.3801	.3982	.362	.3982	.4163
21	.362	.3077	.362	.362	.362
22	1.0288	1.166	.2715	.2715	.3258
23	1.0288	1.2003	.2572	.2715	.2715
24		1.0288	1.2003	.2715	.2715
Max	**1.0288**	**1.3889**	**1.3375**	**1.4403**	**1.7147**
Min	**.1448**	**.181**	**.181**	**.2353**	**.1448**
Avg	**.3643**	**.6165**	**.5920**	**.6353**	**.7747**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274096 / 33/11 KV TAKALI
Feeder No / Name : 204 / 11 KV KUDAL SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.7147	1.5089	.4287	.4525
2		1.7147	1.5089	.4287	.4525
3		1.7147	1.5089	.4287	.543
4		1.7147	1.5432	.4287	.6335
5		1.7147	1.6289	.5144	.724
6		1.749	1.6975	.703	.8145
7		1.9719	1.6975	.703	.8507
8		.5973	.6516	.6344	.8145
9		.3801	.4163		.4706
10	.3801	.3801	.2172	1.9204	2.2291
11	.3077	.2715	.2353	2.1776	2.5377
12	.2715	.2572	.2353	2.2977	2.6578
13	.2715	.2172			2.7435
14	.2534	.1991	.2172		2.7949
15	.2715	.2172	.2172		2.7435
16	.2715	.2353	.2715	2.1605	2.7263
17	.3258	.2715	.2896	2.2634	2.5549
18	.4706	.4525	.5249	.4887	.4525
19	.7602	.543	.6335	.5792	.6154
20	.6878	.6878	.6335	.6878	.724
21	.5973	.5249	.543	.5611	.5611
22	1.5432	1.3375	.4287	.4344	.5068
23	1.5432	1.5089	.4287	.4525	.4525
24		1.7147	1.5089	.4287	.4525
Max	**1.5432**	**1.9719**	**1.6975**	**2.2977**	**2.7949**
Min	**.2534**	**.1991**	**.2172**	**.4287**	**.4525**
Avg	**.5682**	**.9204**	**.8064**	**.9361**	**1.2712**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274096 / 33/11 KV TAKALI
Feeder No / Name : 205 / 11 KV KURGHOT SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.4575	1.3717
2				1.4575	1.3717
3				1.4575	1.3717
4				1.4575	1.3717
5				1.4575	1.3717
6				1.4575	1.3717
7				1.5432	1.5432
10	1.8861	1.9204	1.9719		
11	1.989	2.1948	2.0576		
12	1.9204	2.1434	2.0576		
13	1.989	2.1434	2.0576		
14	1.989	2.0233	1.9719		
15	1.8861	1.989	1.9719		
16	1.7147	2.1262	1.8861		
17	1.9204	2.1262	1.8861		
22			1.4575	1.3717	1.4575
23			1.4575	1.3717	1.4746
24				1.4575	1.3717
Max	**1.989**	**2.1948**	**2.0576**	**1.5432**	**1.5432**
Min	**1.7147**	**1.9204**	**1.4575**	**1.3717**	**1.3717**
Avg	**1.9118**	**2.0833**	**1.8776**	**1.4489**	**1.4077**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274096 / 33/11 KV TAKALI
Feeder No / Name : 206 / 11 KV RTO CHECK POST NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0171	.0362	.0343	.0343
2		.0171	.0181	.0343	.0343
3		.0171	.0362	.0343	.0171
4		.0171	.0181	.0362	.0171
5		.0171	.0362	.0343	.0171
6		.0171	.0362	.0171	.0171
7		.0171	.0181	.0181	.0171
8		.0171	.0181	.0181	.0171
9		.0171	.0181	.0181	.0181
10	.0171	.0171	.0181		.0181
11	.0171	.0171	.0181	.0171	.0181
12	.0171	.0171	.0181	.0171	.0181
13	.0171	.0171	.0181	.0171	.0181
14	.0171	.0181	.0181	.0171	.0181
15		.0181	.0181	.0171	.0181
16		.0181	.0181	.0171	.0181
17	.0171	.0181	.0181	.0171	.0181
18	.0171	.0181	.0181	.0171	.0181
19	.0171	.0181	.0362	.0171	.0181
20	.0171	.0362	.0362	.0171	.0362
21	.0171	.0362	.0362	.0171	.0362
22	.0171	.0362	.0362	.0171	.0362
23	.0171	.0362	.0343	.0343	.0362
24		.0171	.0362	.0343	.0343
Max	**.0171**	**.0362**	**.0362**	**.0362**	**.0362**
Min	**.0171**	**.0171**	**.0181**	**.0171**	**.0171**
Avg	**.0171**	**.0205**	**.0256**	**.0225**	**.0229**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274097 / 33/11 KV TANDULWADI
Feeder No / Name : 202 / 11 KV MUSTI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.7147	2.1262	.7621	.7621
2		1.8861	2.1605	.7621	.7621
3		1.8861	2.2291	.8002	.8383
4		1.8861	2.2291	.9145	.9526
5		2.0576	2.2634	1.448	1.448
6		2.1434	2.7092	1.4861	1.4861
7		2.8292	3.0864		
8		1.0669	1.4098		1.4289
9		.9335	.9907	.9717	1.3336
10		.6478		2.332	2.5034
11		.5335		2.7435	2.7435
12		.4191		2.915	2.6749
13		.4191	.5144		2.8807
14		.4191	.4572		2.9321
15		.4191	.5144		2.4691
16		.381	.5144	2.8292	2.8121
17		.4191	.6097	2.915	2.6235
18			1.1812	.9526	.9145
19		1.1812	1.105	1.2384	1.1241
20		1.105	1.0669	1.1431	1.1431
21		.9907	1.0288	1.0288	1.0288
22		2.1605	.7621	.8573	.7621
23	1.7147	2.1262	.7621	.7621	.6859
24		1.7147	2.1262	.7621	.7621
Max	**1.7147**	**2.8292**	**3.0864**	**2.915**	**2.9321**
Min	**1.7147**	**.381**	**.4572**	**.7621**	**.6859**
Avg	**1.7147**	**1.2756**	**1.4213**	**1.4539**	**1.6118**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274097 / 33/11 KV TANDULWADI
Feeder No / Name : 203 / 11 KV BORAMANI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0288	1.0669	1.6461	1.8519
2		.9145	1.0669	1.7147	1.7833
3		.9145	1.1431	1.7147	1.7833
4		1.1431	1.2955	1.7147	2.1262
5		1.5242	1.3717	1.7833	2.3663
6		1.6766	1.6766	2.1262	2.5377
7				2.7435	2.8121
8		1.5242	1.5242	1.5242	1.5242
9		1.2193	1.1431	1.1431	1.1431
10		2.1948	2.4006	.7621	.7621
11			2.7435	.6097	.6859
12		2.4006	2.5377	.5335	.6097
13		2.5377	2.7435		.5335
14		2.6063	2.6749	.6097	.6859
15		2.6063	2.6063	.6097	.6097
16		2.6063		.6097	.6859
17		2.5377	2.332	.7621	.7621
18		1.2955	1.2955	1.0669	1.0669
19		1.448	1.3717	1.5242	1.5242
20		1.3717	1.448	1.448	1.5242
21		1.2955	1.2955	1.1431	1.2955
22		1.1431	1.6461	1.8519	1.9204
23	1.1431	1.1431	1.6461	1.9204	1.8519
24		1.1431	1.0669	1.6461	1.8519
Max	**1.1431**	**2.6063**	**2.7435**	**2.7435**	**2.8121**
Min	**1.1431**	**.9145**	**1.0669**	**.5335**	**.5335**
Avg	**1.1431**	**1.6489**	**1.7317**	**1.3569**	**1.4291**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274098 / 33/11 Ule
Feeder No / Name : 201 / 11 KV ULEWADI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
17	1.1065	.0566	.0566
18	.0943	.0943	.0754
19	.132	.132	.0754
20	.0943	.1132	.1509
21	.0754	.0754	.0943
22	.6371	.8383	.7545
23	.6539	.8718	.7712
24		.6706	.8048
Max	**1.1065**	**.8718**	**.8048**
Min	**.0754**	**.0566**	**.0566**
Avg	**.3991**	**.3565**	**.3479**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274098 / 33/11 Ule
Feeder No / Name : 204 / 11 KV MANCHUKONDA EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
17	.0566	.0754	.0566
18	.0566	.0758	.0943
19	.0566	.0754	.0943
20	.0566	.0566	.0754
21	.0566	.0566	.0686
22	.0566	.0566	.0754
23	.0566	.0566	.0754
24		.0566	.0566
Max	**.0566**	**.0758**	**.0943**
Min	**.0566**	**.0566**	**.0566**
Avg	**.0566**	**.0637**	**.0746**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274098 / 33/11 Ule
Feeder No / Name : 205 / 11 KV KHADAKI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
17	.2641	2.6658	2.9843
18	.4338	.3587	.3584
19	.6602	.5103	.5281
20	.6224	.6036	.5093
21	.547	.5281	.4715
22	.5281	.4904	.4527
23	.4904	.4715	.4338
24			.4338
Max	**.6602**	**2.6658**	**2.9843**
Min	**.2641**	**.3587**	**.3584**
Avg	**.5066**	**.8041**	**.7715**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274098 / 33/11 Ule
Feeder No / Name : 206 / 11 KV Stone Crusher SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
17	.463	.2743	.4458
18	.3429	.3086	.1372
19	.2572	.2572	.12
20	.2401	.2572	.1494
21	.2229	.2572	.1543
22	.2058	.2401	.1372
23	.1886	.1886	.1494
24		.1715	.1715
Max	**.463**	**.3086**	**.4458**
Min	**.1886**	**.1715**	**.12**
Avg	**.2744**	**.2443**	**.1831**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274098 / 33/11 Ule
Feeder No / Name : 207 / 11 KV ULE GAONTHAN SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
17	1.5729	.3018	.4338
18	.5658	.4715	.6979
19	.7167	.679	.6036
20	.7	.7167	.5658
21	.679	.5847	.4527
22	1.2826	1.1568	1.2742
23	1.2407	1.2742	1.3077
24		1.3413	1.3077
Max	**1.5729**	**1.3413**	**1.3077**
Min	**.5658**	**.3018**	**.4338**
Avg	**.9654**	**.8158**	**.8304**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274098 / 33/11 Ule
Feeder No / Name : 208 / 11 KV EKRUKH SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
17	.57	.0758	.0754
18	.1509	.1509	.1509
19	.1886	.2075	.2075
20	.1698	.1509	.1886
21	.1509	.1372	.132
22	.3018	.3772	.4191
23	.3018	.415	.3688
24			.4024
Max	**.57**	**.415**	**.4191**
Min	**.1509**	**.0758**	**.0754**
Avg	**.2620**	**.2164**	**.2431**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274098 / 33/11 Ule
Feeder No / Name : 209 / 11 KV BORAMANI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
17		2.7999	2.6658
18	.6224	.5658	.6602
19	.7545	.6602	.6432
20	.679	.7733	.6602
21	.6036	.7167	.5658
22	.5658	.6602	.5281
23	.5281	.6036	.495
24		.4904	.5281
Max	**.7545**	**2.7999**	**2.6658**
Min	**.5281**	**.4904**	**.495**
Avg	**.6256**	**.9088**	**.8433**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274099 / 33/11 KV VALSANG
Feeder No / Name : 201 / 11 KV DINDUR SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2096	.2858	1.0852	1.2803
2		.2096	.2667	1.1065	1.3108
3		.2096	.2667	1.1271	1.326
4		.2477	.2667	1.2742	1.3565
5		.3239	.362	1.3077	1.4175
6		.4954	.4954	1.4586	1.6004
7		.4572	.5144		1.9204
8		.381	.4572	.381	
9		.3239	.3239	.2667	.3048
10		1.6617	1.7341	.1334	.1715
11		1.8275	1.6716	.1143	.0762
12		1.9498	1.8501	.1334	
13		1.8351	2.0934	.1334	
14		2.0809	1.174	.1715	.1143
15		1.9989	1.8244	.1334	.0953
16		1.9662	1.8122	.1143	.0953
17		1.8842	1.7158	.1905	.1524
18		.3048		.2858	.2477
19		.4954	.4763	.4763	.4572
20		.4572	.4763	.4382	.4572
21		.3429	.3429	.362	.362
22		.3239	1.0631	1.5623	1.1288
23	.2096	.3048	1.0682		1.1591
24		.2096	.2858	1.1022	1.2651
Max	**.2096**	**2.0809**	**2.0934**	**1.5623**	**1.9204**
Min	**.2096**	**.2096**	**.2667**	**.1143**	**.0762**
Avg	**.2096**	**.8542**	**.9055**	**.6072**	**.7761**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274099 / 33/11 KV VALSANG
Feeder No / Name : 202 / 11 KV ACHEGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9907	.7385	.2858	.3239
2		.9907	.7529	.3048	.3239
3		1.0517	.7727	.3429	.3239
4		1.0822	.7727	.4191	.362
5		1.2346	1.0402	.4954	.4382
6		1.3717	1.2334	.6859	.6859
7		1.4784	1.4148	.6287	
8		.3658	.6478	.5716	
9		.4763	.4382	.4191	.4001
10		.3048	.3048	1.2929	1.3226
11		.2667	.2096	1.5893	1.5009
12		.1905	.1524	1.6598	
13		.1905	.2096	1.5844	1.3056
14		.1905	.1905		1.2176
15		.2286	.1905		1.4415
16		.2096	.2096	1.5466	1.2186
17		.2477	.2286	1.1873	1.2186
18		.4572	.381	.4763	
19		.5906	.6097	.6668	.6478
20		.5716	.6478	.6287	.6287
21		.4382	.5144	.4763	.4763
22		.7133	.4001	.3429	.3048
23	.9297	.7282	.2858		.2477
24		.9602	.724	.2667	.3239
Max	**.9297**	**1.4784**	**1.4148**	**1.6598**	**1.5009**
Min	**.9297**	**.1905**	**.1524**	**.2667**	**.2477**
Avg	**.9297**	**.6388**	**.5446**	**.7558**	**.7356**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274099 / 33/11 KV VALSANG
Feeder No / Name : 203 / 11 KV L.CHINCHOLI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0974	.8833	.3048	.4001
2		1.0974	.9214	.3429	.381
3		1.1126	.9214	.381	.381
4		1.1888	.9214	.4191	.4382
5		1.2346	1.0402	.4954	.4954
6		1.3413	1.3077	.7621	.7811
7		1.5546	1.6804	.8002	
8		.5944	.6859	.8192	
9		.6287	.5716	.5906	.6097
10		.381	.3429	1.2492	1.3603
11		.2477	.2477	1.4175	1.6032
12		.2286	.2286	1.7002	
13		.2096	.2096	.1663	1.6004
14		.2096	.1905		1.7284
15		.2096	.1905		1.668
16		.2096	.1905	1.4842	1.3441
17		.3048	.3048	1.2037	1.2308
18		.5525	.4191	.5144	.5335
19		.6668	.6859	.7621	.724
20		.6097	.6668	.5144	.6287
21		.4763	.5525	.4954	.5335
22		.8977	.4001	.362	.4001
23	1.0517	.9065	.3239		.3429
24		1.0822	.8688	.3048	.4001
Max	**1.0517**	**1.5546**	**1.6804**	**1.7002**	**1.7284**
Min	**1.0517**	**.2096**	**.1905**	**.1663**	**.3429**
Avg	**1.0517**	**.7101**	**.6148**	**.7185**	**.8374**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274099 / 33/11 KV VALSANG
Feeder No / Name : 204 / 11 KV SOOT MIL SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3429	.381	.2713	.2134
2		.3429	.3429	.2134	.2134
3		.3429	.3429	.2374	.2134
4		.362	.3239	.2683	.2439
5		.4382	.4763	.3018	.362
6		.6097	.7049	.3605	.3353
7		.724	.7049	.5243	
8		.6478	.6668	.5716	
9		.5716	.4954	.5716	.5335
10		.503	.4733	.4001	.4191
11		.503	.5201	.381	.3429
12		.4915	.8669	.362	
13		.5243	.5182	.3239	.381
14		.5243	.5079	.3239	.381
15		.426	.4915	.3239	.3429
16		.426	.5571	.3239	.3429
17		.3932	.4973	.362	.381
18		.5906	.4954	.5335	.5716
19		.743	.724	.6478	.6859
20		.743	.6478	.6859	.6668
21		.6287	.6097	.6097	.6287
22		.4191	.5258	.2134	.3506
23	.362	.4001	.4801		.3467
24		.3429	.381	.3052	.2134
Max	**.362**	**.743**	**.8669**	**.6859**	**.6859**
Min	**.362**	**.3429**	**.3239**	**.2134**	**.2134**
Avg	**.362**	**.5017**	**.5306**	**.3964**	**.3890**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274099 / 33/11 KV VALSANG
Feeder No / Name : 205 / 11 KV HANJAGI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0381	.0572	.4191	.3658
2		.0381	.0572	.4359	.381
3		.0381	.0572	.4527	.381
4		.0572	.0572	.4973	.4115
5		.0762		.4915	.442
6		.0953	.1143	.5571	.5639
7		.0953	.1143	.639	
8		.0762	.1143	.0953	
9		.0572		.0572	.0762
10		.6036	.5075	.0381	.0381
11		.6539	.514	.0381	.0381
12		.663	.514	.0381	
13		.6464	.5213	.0381	.0381
14		.6062	.4938	.0381	.0381
15		.6554	.4451	.0191	.0191
16		.639	.4734	.0381	.0381
17		.5407	.4599	.0572	.0381
18		.0953	.0572	.0953	.0762
19		.1143	.1143	.1143	.1143
20		.1143	.0953	.0953	.0953
21		.0762	.0762	.0762	.0762
22		.0572	.3772	.4382	.4763
23	.0381	.0572	.39		.3467
24		.0381	.0572	.407	.3658
Max	**.0381**	**.663**	**.5213**	**.639**	**.5639**
Min	**.0381**	**.0381**	**.0572**	**.0191**	**.0191**
Avg	**.0381**	**.2555**	**.2576**	**.2251**	**.2105**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274099 / 33/11 KV VALSANG
Feeder No / Name : 206 / Kardehalli SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6401	.679	.1715	.2096
2		.6401	.6636	.1524	.2096
3		.6859	.6554	.1715	.2096
4		.7468	.6554	.1905	.2286
5		1.0288	.8097	.2286	.2858
6		1.1279	1.1174	.3429	.3239
7		1.2041	1.5074	.381	
8		.2286	.2286	.3429	
9		.2096	.2286	.2477	.2286
10		.1715	.1715	1.2483	1.1363
11		.1524	.1334	1.4091	1.4255
12		.1334	.1334		
13		.1524	.1334	1.4575	1.5223
14		.1334	.1143	1.5023	1.4413
15		.1524	.1143		1.5708
16		.1524	.1143	1.4255	1.2803
17		.1524	.1524	1.0031	
18		.3048	.2096	.2477	.2477
19		.381	.362		.362
20		.3048	.3048	.3239	.362
21		.2858	.2858	.2858	.3239
22		.6874	.2286	.2286	.2667
23	.6401	.679	.1905		.2096
24		.6401	.6874	.1715	.2096
Max	**.6401**	**1.2041**	**1.5074**	**1.5023**	**1.5708**
Min	**.6401**	**.1334**	**.1143**	**.1524**	**.2096**
Avg	**.6401**	**.4581**	**.4117**	**.5766**	**.6027**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274100 / 33/11 KV WADAKBAL
Feeder No / Name : 201 / 11 KV HATTUR SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4904	1.3717	
2	.4904	1.3717	1.2498
3	.4904	1.3717	
4	.4904	1.3717	1.3565
5	.5658	1.6289	
6	.6602	2.1948	2.0557
7	.811	2.332	
8	.6602	.6602	.8299
9			.7545
10	2.0576	.5281	.5658
11	2.4006		.5658
12	2.4006	.4715	.5658
13	2.4006		
14	2.3148		
15	1.9719		
16	1.9719		
17	1.9719		.5658
18	.5281	.6413	
19	.8488		
20	.8488	1.0374	
21	.7922		
22	1.4575	1.4575	
23	1.406	1.4251	
24	.5281	1.406	1.3413
Max	**2.4006**	**2.332**	**2.0557**
Min	**.4904**	**.4715**	**.5658**
Avg	**1.2417**	**1.2846**	**.9851**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274100 / 33/11 KV WADAKBAL
Feeder No / Name : 202 / 11KV WADAKBAL SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0094	.0943		
2		.0094	.0914	.3109	.3429
3		.0094	.0943		
4		.0094	.0943	.3206	.3506
5		.0094	.0943		
6		.0094	.0943	.7316	.6859
7		.0094	.0943	.7316	
8		.0094	.0943	.1132	.1886
9		.0094	.0943		
10		.0094	.7316	.0943	
11		.0094	.7316		
12		.0094	.7682	.0943	
13		.0094			
14		.0094	.7316	.0943	
15		.0094	.7316		
16		.0094	.7316		
17		.0094	.695		
18		.0094	.1132	.0943	
19		.0943			
20		.0943		.1886	
21	.0943	.0943	.1132		
22	.0943	.0943		.362	
23	.0943	.0943	.3658	.3582	
24		.0094	.0943	.3475	.3582
Max	**.0943**	**.0943**	**.7682**	**.7316**	**.6859**
Min	**.0943**	**.0094**	**.0914**	**.0943**	**.1886**
Avg	**.0943**	**.0271**	**.3327**	**.2955**	**.3852**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274100 / 33/11 KV WADAKBAL
Feeder No / Name : 203 / 11 KV RAJUR SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9431	.9431		
2		.9431	.9431	.2641	.2263
3		.9431	.9431		
4		1.1317	1.1317	.2641	.2263
5			1.5089		
6			1.8861	.5658	.4527
7		1.5089	1.8861		
8		1.5089	.415	.3772	
9		1.5089			
10		.3772	.3018	1.0288	
11		.2829	.2641		
12		.2263	.2263	1.1843	
13		.1886			
14		.1886	.1886		
15		.1886	.1886		
16		.1886	.1886		
17		.1886			
18		.3395	.2641	.3772	
19		.3395			
20		.4904		.5281	
21	.3772	.5281	.415		
22	.9431	.8488		.2641	
23	.9431	.9431	.3018	.2263	
24		.9431	.9431	.2829	.2263
Max	**.9431**	**1.5089**	**1.8861**	**1.1843**	**.4527**
Min	**.3772**	**.1886**	**.1886**	**.2263**	**.2263**
Avg	**.7545**	**.6704**	**.7188**	**.4875**	**.2829**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274100 / 33/11 KV WADAKBAL
Feeder No / Name : 204 / 11 KV AURAD SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3772	.3395	.0566	
2		.3772	.3395	.0566	.0566
3		.3658	.3395	.0566	
4		.3772	.3772	.0566	.0566
5		.3772	.3772	.0566	
6		.4715	.4715	.0566	.0943
7		.5658	.5281	.0566	
8		.5658	.0566	.0566	.0566
9		.0566	.0566		.0566
10		.0566	.0566	.4298	.4287
11		.0566	.0566		.5144
12		.0566	.0566	.5853	.5144
13		.0566	.0566		
14		.0566	.0566		
15		.0566	.0566		
16		.0571	.0566		
17		.0566	.0566		
18		.0566	.0566	.0566	
19		.0566	.0566		
20		.0566	.0566	.0566	
21	.0566	.0566	.0566		
22	.3772	.3395	.0566	.0566	
23	.3772	.3395	.0566	.0566	
24		.3772	.3395	.0566	.0566
Max	**.3772**	**.5658**	**.5281**	**.5853**	**.5144**
Min	**.0566**	**.0566**	**.0566**	**.0566**	**.0566**
Avg	**.2703**	**.2196**	**.1674**	**.1167**	**.2039**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274100 / 33/11 KV WADAKBAL
Feeder No / Name : 205 / SINDHKHED AG FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0943	.0943	.7316	
2		.0943	.0943	.7316	.8573
3		.0943	.0943	.7316	
4		.0943	.0943	.7316	.9145
5		.0943	.132	.8954	
6		.0943	.1886	1.1393	1.2269
7		.0943	.2075	1.1919	
8		.0943	.1509	.3018	
9		.0943	.1132		.0566
10		.8488	1.4575	.0754	.0566
11		.8488	1.5775		.0566
12		.8488	1.5432	.0754	.0566
13		.8488	1.4575		
14		.8488	1.4575		
15		.7545	1.406		
16		.7545	1.406		
17		.7545	1.3717		
18		.1132	.1886	.1132	
19		.1132	.1886		
20		.1132	.1886	.1509	
21	.0943	.1132	.1698		
22	.0943	.1132	.823	.8764	
23	.0943	.0943	.7316	.8573	
24		.0943	.0943		.8764
Max	**.0943**	**.8488**	**1.5775**	**1.1919**	**1.2269**
Min	**.0943**	**.0943**	**.0943**	**.0754**	**.0566**
Avg	**.0943**	**.3380**	**.6346**	**.6145**	**.5127**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274100 / 33/11 KV WADAKBAL
Feeder No / Name : 207 / 11 KV WANGI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2829	.1509	.5487	
2		.2829	.1509	.5487	.503
3		.2829	.1509	.5487	
4		.2829	.1509	.5487	.4915
5		.2829	.1886	.695	
6		.3772	.3772	.823	1.0059
7		.3772	.4527	.8413	
8	.3395	.7544	.2829	.3018	.3018
9	.9431	.3772	.1886		
10	1.1317	1.226	1.0288	.0943	.1886
11	1.1317	1.226	1.1145		.1886
12	1.1317		1.1145	.0943	.1886
13	1.1317	1.1317	1.1145		
14	1.1317	1.1317	1.0631		
15	1.1317	1.1317	1.0288		
16	1.1317	1.1317	.9945		.2641
17	1.1317	1.0374	.9431		
18	.1886	.1509	.2263	.1886	
19	.2829	.2829	.3395		
20	.2829	.2829	.3018	.4527	
21	.5658	.1886	.2641		
22	.5658	.1886	.6401	.503	
23	.5658	.1509	.5853	.5087	
24	.1886	.5658	.1509	.5487	.5144
Max	**1.1317**	**1.226**	**1.1145**	**.8413**	**1.0059**
Min	**.1886**	**.1509**	**.1509**	**.0943**	**.1886**
Avg	**.7633**	**.5708**	**.5418**	**.4831**	**.4052**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274113 / 33/11 KV KUMBHARI
Feeder No / Name : 201 / 11 KV GODUTAI **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6722	.8215	.7468	.7468
2		.6722	.7468	.7095	.7095
3		.5975	.7468	.6908	.6722
4		.6348	.7095	.6535	.5975
5		.7095	.7095	.7095	.5975
6		.7095	.7468	.6908	.5228
7		.7468	.7468	.6535	.6722
8		.7468	.7095	.6348	.7468
9		.6722	.6348		.6348
10		.6722	.5601	.5228	.5601
11			.4668	.4481	.5601
12		.5975	.4481	.4854	.5228
13		.5601	.4668	.5228	.5228
14		.4854	.4668	.5601	.4854
15		.4854	.4854		.4854
16		.4854	.5228		.5601
17		.5228	.5041	.4481	.6722
18		.8589	.8402	.7468	.7468
19		1.1203	1.1203	.8962	1.1576
20		1.0829	1.0642	1.0456	.9335
21		1.0082	.8962	1.1576	.9335
22	.8962	.9709	.8402	.8962	.8589
23	.7095	.9335	.7468	.8215	.7842
24		.7095	.8589	.7468	.7842
Max	**.8962**	**1.1203**	**1.1203**	**1.1576**	**1.1576**
Min	**.7095**	**.4854**	**.4481**	**.4481**	**.4854**
Avg	**.8029**	**.7241**	**.7025**	**.7042**	**.6862**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274113 / 33/11 KV KUMBHARI
Feeder No / Name : 202 / 11 KV KUMBHARI **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3361	.3361	.3547	.3361
2		.2987	.2987	.3734	.2987
3		.2987	.2987	.7468	.2987
4		.4435	.2987	.7282	.4481
5		.5228	.3361	.7095	.5975
6		.6722	.5975	.7095	.6722
7		.7468	.7468	.7282	.7842
8		.7095	.5975	.6908	.6722
9		.5975	.4481		
10		.3361	.2241	.4854	
11	.3734		.2427	.2987	.2614
12	.3734	.2241	.2241	.0187	.2241
13	.2614	.2241	.2241	.0187	.2241
14	.2241	.2241	.2427	.3361	.1867
15	.1867	.1867	.1867		.1867
16		.2241	.2241		.1867
17		.2614	.2427	.3361	.2614
18		.3361	.3547	.4481	.3734
19		.5228	.5228	.4854	.5601
20	.5601	.4481	.5415	.5228	.4854
21	.4481	.4108	.4668	.5975	.4108
22	.3361	.3734	.3734	.3361	.3361
23	.3361	.3361	.3361	.3395	.3361
24		.3361	.3361	.3361	.3361
Max	**.5601**	**.7468**	**.7468**	**.7468**	**.7842**
Min	**.1867**	**.1867**	**.1867**	**.0187**	**.1867**
Avg	**.3444**	**.3943**	**.3625**	**.4572**	**.3853**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274113 / 33/11 KV KUMBHARI
Feeder No / Name : 203 / 11KV MICROWAVE SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0549	.1052	.0983
2			.0549	.1402	.0983
3			.0549	.1578	.1265
4			.0549	.2103	.1581
5			.0732	.2279	.1562
6			.0914	.2629	.1875
7			.1097	.2743	.1875
8			.0914	.1097	.1086
9			.0732	.0914	.0895
10			.1829	.0732	.0732
11	.1898		.2241	.0362	.0549
12	.2214		.2561	.0366	.0366
13	.2056		.2743	.0377	.0366
14	.1875		.2561	.0537	.0366
15	.1718	.208	.2743		.0366
16		.2622	.2743		.0366
17		.2774	.2561	.037	.0549
18		.0549	.0732	.0543	.0549
19		.0914	.0732	.0537	.0732
20		.0732	.0732	.0543	.0732
21		.0549	.0732	.0724	.0549
22		.0549	.0732	.1017	.0819
23		.0549	.0526	.0829	.0819
24			.0549	.0876	.0829
Max	**.2214**	**.2774**	**.2743**	**.2743**	**.1875**
Min	**.1718**	**.0549**	**.0526**	**.0362**	**.0366**
Avg	**.1952**	**.1258**	**.1304**	**.1073**	**.0866**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274113 / 33/11 KV KUMBHARI
Feeder No / Name : 204 / 11 KV LOKMANGAL MEDICAL EXPRES Feeder KV- 11 / OUTGOING
NON SHEDDABLE EXPRESS HV FEEDERS (CONTINOUS PROCESS)(NO STAGGERING)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0762	.0762	.0572	.0762
2		.0762	.0762	.0572	.0762
3		.0762	.0572	.0572	.0762
4		.0572	.0572	.0572	.0572
5		.0572	.0572	.0572	.0572
6		.0762	.0572	.0572	.0762
7		.0572	.0572	.0572	.0572
8		.0762	.0572	.0572	.0762
9		.0953	.0762	.0762	.0953
10	.0572	.1143	.0953	.0953	.0953
11	.0762		.0953	.0953	.1143
12	.0762	.1143	.1143	.0953	.1143
13	.0572	.1143	.1334	.0953	.1143
14	.0572	.1143	.1143	.0953	.1143
15	.0572	.0953	.1334		.1143
16		.0953	.1143		.0953
17		.0953	.0953	.0762	.0762
18		.0953	.0572	.0572	.0762
19		.0953	.0549	.0572	.0762
20	.0572	.0953	.0572	.0762	.0953
21	.0762	.0762	.0762	.0762	.0953
22	.0762	.0762	.0572	.0762	.0953
23	.0762	.0762	.0572	.0762	.0762
24		.0762	.0762	.0572	.0762
Max	**.0762**	**.1143**	**.1334**	**.0953**	**.1143**
Min	**.0572**	**.0572**	**.0549**	**.0572**	**.0572**
Avg	**.0667**	**.0862**	**.0793**	**.0710**	**.0865**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274113 / 33/11 KV KUMBHARI
Feeder No / Name : 205 / 11 KV MINAXI TAI SANE GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2926	.2926	.2378	.2561
2		.2926	.2561	.2743	.2561
3		.2561	.2561	.2926	.2926
4		.2561	.2561	.2926	.2561
5		.2743	.2195	.2195	.2378
6		.2743	.2195	.2195	.2195
7		.2561	.2195	.2195	.2561
8		.2195	.2561	.2195	.2195
9		.2195	.2561	.2012	.2195
10	.2195	.2195	.1829	.1829	.2195
11	.2195	.2195	.1829	.1829	.2195
12	.1829	.1829	.1463	.1463	.1829
13	.1829	.1829	.1646	.1463	.1829
14	.1829	.1829	.1646	.1463	.1829
15	.1829	.1829	.1829		.1829
16		.1829	.1829		.2195
17		.1829	.1646	.1463	.2561
18		.2926	.2743	.2195	.2926
19		.3658	.3475	.2926	.3658
20	.439	.4024	.3658	.3658	.4024
21	.3658	.3292	.3475	.3292	.4024
22	.3292	.2926	.3292	.2926	.3658
23	.2926	.2926	.2743	.2926	.3292
24		.2926	.2926	.2378	.2926
Max	**.439**	**.4024**	**.3658**	**.3658**	**.4024**
Min	**.1829**	**.1829**	**.1463**	**.1463**	**.1829**
Avg	**.2597**	**.2561**	**.2431**	**.2344**	**.2629**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274113 / 33/11 KV KUMBHARI
Feeder No / Name : 206 / 11 KV KUMBHARI AG SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1791	.2195	.5258	.7011
2		.1791	.2195	.6135	.7011
3		.2149	.1829	.7316	1.0166
4		.2507	.1829	1.0517	1.3321
5		.2507	.2561	1.2795	1.2971
6		.3224	.3292	1.4022	1.262
7			.4024	1.4022	1.7528
8		.3224	.2926	1.4632	.2865
9		.2865	.2195	.3109	.2865
10		1.4022	1.3717	.2195	.2561
11	1.0517	1.4022	1.6095	.1829	.2195
12	1.1218	1.4548	1.7924	.1463	.1829
13	1.3321	1.5775	1.7375	.1463	.1829
14	1.4022	1.6126	1.7375	.1463	.1829
15	.9816	1.5775	1.701		.1829
16		1.4899	1.701		.1829
17		1.3321	1.4449		.2195
18			.3292		.2195
19		.2926	.2743	.2507	.2926
20	.2149	.2561	.2926	.2865	.2561
21	.1791	.2195	.2743	.3224	.1829
22	.1791	.2195	.2378	.7011	.631
23	.2149	.2195	.7362	.7362	.7011
24		.2149	.2195	.7362	.7712
Max	**1.4022**	**1.6126**	**1.7924**	**1.4632**	**1.7528**
Min	**.1791**	**.1791**	**.1829**	**.1463**	**.1829**
Avg	**.7419**	**.6944**	**.7402**	**.6328**	**.5542**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274141 / 33/11 KV AHERWADI
Feeder No / Name : 201 / 11 KV BANKALGI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.1905	
2		.1905	
3		.1905	
4		.1524	
5		.2286	
6		.3048	
7		.3429	
8		.2286	
9		.1905	
10	1.0669		.1905
11	1.2651		.1905
12	1.3108		.1905
13	1.3435		.1905
14	1.1736		.1524
15	1.1584		.1524
16	1.1584		.1905
17	1.0974		.2286
18	.2286		.3048
19	.3048		.4191
20	.4191		.3429
21	.3429		.3429
22	.3048		.6859
23	.2667		.6859
24		.1905	
Max	**1.3435**	**.3429**	**.6859**
Min	**.2286**	**.1524**	**.1524**
Avg	**.8172**	**.2210**	**.3048**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274141 / 33/11 KV AHERWADI
Feeder No / Name : 202 / 11 KV AHERWADI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1905	1.1203	.5068	.4633
2		.1905	1.2003	.5213	.4778
3		.1905	1.2651	.5498	.4715
4		.2286	1.3603	.5647	.5944
5		.3429	1.4232	.5201	.7926
6		.3429	1.5203	.7522	.9762
7		.3048	1.6194	1.1883	1.2803
8		.2477	.2286	.2667	.3048
9		.2286	.5906	.2286	.2286
10	1.2967	.4191	1.1443	.1905	1.2963
11	1.3272	.3048	1.2346	.1905	1.3889
12	1.3117	.2286	1.2041	.1905	1.3889
13	1.2342	.2286	1.174		1.3889
14	1.1736	.2286	1.0269		1.3426
15	1.1736	.2286	1.0686		1.358
16	1.1888	.2286	1.1584		1.3272
17	1.1888	.2858	.9701	.1905	1.3123
18	.2858	.3429	.2286	.2286	.4191
19	.3429	.6287	.3048	.3048	.6668
20	.3048	.5144	.2858	.2667	.5906
21	.2667	.4001	.2667	.2286	.5335
22	.2477	.9145	.4572	.4755	.3429
23	.2286	.945	.4778	.4755	.2858
24		.2096	1.1203	.5068	.4633
Max	**1.3272**	**.945**	**1.6194**	**1.1883**	**1.3889**
Min	**.2286**	**.1905**	**.2286**	**.1905**	**.2286**
Avg	**.8265**	**.3490**	**.9354**	**.4174**	**.8206**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274141 / 33/11 KV AHERWADI
Feeder No / Name : 203 / 11 KV Madre SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1265		.3048	.2858
2		1.1574		.3429	.3048
3		1.1728		.381	.3239
4		1.2498		.4763	.5335
5		1.3904		.5716	.6859
6		1.5203		.6668	.7621
7		1.6004		.6287	.5906
8		.6668	.6287	.4763	.5144
9		.4763	.4001	.4191	.4763
10	.381		.3429	1.1589	
11	.3429		.2858	1.3283	
12	.3048		.2667	1.4022	
13	.2858		.2477	1.3413	
14	.2667		.2477		
15	.2286		.2667		
16	.2667		.2477		
17	.3048		.2667	1.0669	
18	.4763		.4763	.5144	
19	.6478		.6287	.6097	
20	.5906		.5906	.5335	
21	.4763		.4382	.4001	
22	.9934		.3429	.3239	
23	1.0957		.3239	.2858	
24		1.0957		.2858	.2858
Max	**1.0957**	**1.6004**	**.6287**	**1.4022**	**.7621**
Min	**.2286**	**.4763**	**.2477**	**.2858**	**.2858**
Avg	**.4758**	**1.1456**	**.3751**	**.6437**	**.4763**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274199 / 33/11 KV GUNJEGAON
Feeder No / Name : 201 / 11 KV AKOLE (M) SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0625	.0594	.4458	.4531
2	.0625	.0743	.4458	.4687
3	.0625	.0743	.4458	.4999
4	.0781	.104	.5201	.5312
5	.1562	.1189	.5201	.5468
6	.2187	.1486	.5201	.6093
7	.2812	.2824	.6687	.828
8	.2343	.2378	.1932	.25
9	.1562	.1337	.1486	.1562
10	.8436	.8619	.0937	.0937
11	.7343	.8916	.0469	
12	.9842	.9659	.0469	
13	1.0155	.9659		.0625
14	.9374	.9659		.0469
15	.9686	.8916		.0312
16	.9374	.8402		.0625
17	.9061	.8916	.1094	.0781
18	.1337	.1337	.125	.1406
19	.1635	.1486	.1718	.1562
20	.1337	.1486	.1875	.1406
21	.1189	.1189	.1094	.125
22	.0743	.3715	.4218	.4374
23	.0743	.4458	.4531	.4531
24	.0625	.0594	.4458	.4531
Max	**1.0155**	**.9659**	**.6687**	**.828**
Min	**.0625**	**.0594**	**.0469**	**.0312**
Avg	**.3917**	**.4139**	**.3060**	**.3011**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274199 / 33/11 KV GUNJEGAON
Feeder No / Name : 202 / 11 KV KANDALGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2881	.2846	1.2651	1.3283
2	.2881	.3163	1.2651	1.3443
3	.2881	.3163	1.3441	1.3603
4	.3201	.3163	1.3916	1.3923
5	.4001	.3795	1.4232	1.4403
6	.5441	.5535	1.4864	1.6004
7	.5761	.6483	1.945	2.2725
8	.5281	.6009	.5535	.5921
9	.3361	.3637	.3795	.4481
10	1.9204	2.2929	.3201	.3795
11	1.6164	2.4194		.3005
12	2.0965	2.6882	.3041	.2846
13	2.2085	2.6882		.253
14	2.2405	2.6566		.2214
15	2.3205	2.6566		.208
16	2.3205	2.6092		.2881
17	2.2725	2.372	.3521	.2561
18	.427		.4001	.4001
19	.506	.506	.5761	.4801
20	.4744	.4428	.5601	.4801
21	.3953	.3795	.4321	.4481
22	.3005	1.186	1.3763	1.3443
23	.3005	1.186	1.3123	1.3443
24	.2881	.2846	1.2651	1.3283
Max	**2.3205**	**2.6882**	**1.945**	**2.2725**
Min	**.2881**	**.2846**	**.3041**	**.208**
Avg	**.9690**	**1.2238**	**.9448**	**.8248**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274199 / 33/11 KV GUNJEGAON
Feeder No / Name : 203 / 11 KV GUNJEGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0155	1.2226	.1772	.125
2	1.0311	1.3289	.1772	.125
3	1.0623	1.382	.1772	.1406
4	1.0623	1.4529	.2126	.1562
5	1.1717	1.5769	.2481	.2187
6	1.4217	1.7364	.3544	.2812
7	1.8278	1.9667	.3898	.3437
8	.2968	.3189	.3721	.3437
9	.2656	.2481	.2658	.2812
10	.1718	.2126	1.3435	1.4373
11		.1595	1.8122	2.1715
12	.1406	.124	1.9841	2.0934
13	.125	.1063		2.1091
14	.125	.1063		2.0778
15	.1094	.0886		2.0309
16	.1094			1.8122
17	.1562	.1595	1.9841	1.9216
18	.2481	.2303	.1875	
19	.3189	.3012	.2968	.25
20	.2658	.2481	.2656	.2812
21	.2303	.2303	.2031	.192
22	1.0454	.2126	.1406	.1562
23	1.0985	.1772	.125	.1406
24	1.0155	1.1871	.1772	.125
Max	**1.8278**	**1.9667**	**1.9841**	**2.1715**
Min	**.1094**	**.0886**	**.125**	**.125**
Avg	**.6224**	**.6425**	**.5447**	**.8180**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274202 / 33/11 KV INGALAGI
Feeder No / Name : 201 / 11 KV KANBAS SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5344	.6802	.1715	.1905
2		.5281	.6802	.1715	.1905
3		.5281	.7287	.1715	.1905
4		.5601	.7287	.1715	.1905
5		.6562	.7287	.2286	.2286
6		.9282	.8097	.3429	.2858
7		1.0562	.9717	.4191	.4001
8		.1715	.3239	.3048	.3429
9		.1334	.2096		.2286
10		.1143	.1524	.2096	.9555
11			.1143		.9717
12		.0953	.1143		.8848
13		.0953	.0762	.1334	.9175
14		.0953	.0953	.1143	.8642
15		.0953	.0953	.0953	.8097
16		.1334	.0953	.1143	.7773
17		.1524	.1334	.1715	.1524
18		.2286	.1905	.2286	.3048
19		.2667	.2667	.381	.2667
20		.3048	.2286	.381	.2667
21	.3048	.2858	.1905	.2667	.2477
22	.5735	.4744	.1715	.4915	.2286
23	.5898	.6478	.1715	.4858	.1905
24		.5668	.6478	.1715	.1905
Max	**.5898**	**1.0562**	**.9717**	**.4915**	**.9717**
Min	**.3048**	**.0953**	**.0762**	**.0953**	**.1524**
Avg	**.4894**	**.3762**	**.3585**	**.2489**	**.4282**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274202 / 33/11 KV INGALAGI
Feeder No / Name : 202 / 11 KV TILLEHAL SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.759	.8322	.2286	.2286
2		.7842	.8421	.2286	.2286
3		.9122	.8421	.2286	.2286
4		1.078	.8907	.2667	.2286
5		1.2186	1.0526	.3048	.2286
6		1.2811	1.186	.381	.3429
7		1.3123	1.4232	.4954	.4572
8		.3429	.381	.381	.4001
9		.2667	.2667	.3048	.2667
10		.1715	.2286	1.2631	1.1984
11		.1334	.1524		1.2651
12		.1334	.1524		1.3279
13		.1334	.1524		1.0978
14		.1524	.1334		1.2955
15		.1524	.1334	1.2803	1.3923
16		.1524	.1524	1.3603	1.3603
17		.1905	.1905	1.2967	1.3435
18		.3429	.2286	.1905	.1905
19		.381	.3048	.4001	.4001
20		.4001	.3429	.3429	.362
21	.2858	.381	.3429	.2858	.3048
22	.7773	.7373	.2477	.2286	.2858
23	.7682	.8002	.2286	.2286	.2667
24		.7682	.7907	.2286	.2286
Max	**.7773**	**1.3123**	**1.4232**	**1.3603**	**1.3923**
Min	**.2858**	**.1334**	**.1334**	**.1905**	**.1905**
Avg	**.6104**	**.5410**	**.4791**	**.4963**	**.6221**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274202 / 33/11 KV INGALAGI
Feeder No / Name : 203 / 11 KV INGALGI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2096	.1905	.4801	.5601
2		.1905	.1905	.4858	.5601
3		.2096	.1905	.4801	.5535
4		.2286	.1905	.5121	.5535
5		.2286	.2286	.7202	.6642
6		.3429	.3429	.7682	.7907
7		.2286	.381	.8802	.8223
8		.3048	.3048	.2858	.3429
9		.2286	.2286	.2096	.2667
10		.8322	.6009	.1334	.1715
11		.759	1.1603	.1334	.1334
12		.7907	1.1336		.1143
13		.8223	1.1469		.1143
14		.7907	.8002		.0953
15		.759	1.0402		.0953
16		.8223	1.0562		.1143
17		.8539	.9602		.1334
18		.2667	.7621		.1905
19		.3048	.3048		.381
20		.3429	.3429		.3429
21	.2667	.2858	.2667		.2667
22	.2286	.2286	.4481		.6154
23	.2096	.1905	.4481		.6401
24		.2096	.1905	.4534	.5601
Max	**.2667**	**.8539**	**1.1603**	**.8802**	**.8223**
Min	**.2096**	**.1905**	**.1905**	**.1334**	**.0953**
Avg	**.2350**	**.4346**	**.5379**	**.4619**	**.3784**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274219 / 33/11kV AURAD
Feeder No / Name : 201 / 11 KV SANJWAD SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7							.8535
8	.1029	.1029	.0686	.0171	.1372	.0857	.0686
16	1.0212	1.0669	.8383	1.0059	1.0822	.0171	.0171
24	.0171	.0171	.1029	.0171	.12	.8383	.6859
Max	**1.0212**	**1.0669**	**.8383**	**1.0059**	**1.0822**	**.8383**	**.8535**
Min	**.0171**	**.0171**	**.0686**	**.0171**	**.12**	**.0171**	**.0171**
Avg	**.3804**	**.3956**	**.3366**	**.3467**	**.4465**	**.3137**	**.4063**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274219 / 33/11kV AURAD
Feeder No / Name : 202 / 11 KV BANDALGI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.12	.1029	.12	.1372	.12	.1543	.1543
16	.0171	.1029	.0686	.0686	.0857		.9755
24	.6554	.6401	.6859	.5944	.6097	.1029	.0857
Max	**.6554**	**.6401**	**.6859**	**.5944**	**.6097**	**.1543**	**.9755**
Min	**.0171**	**.1029**	**.0686**	**.0686**	**.0857**	**.1029**	**.0857**
Avg	**.2642**	**.2820**	**.2915**	**.2667**	**.2718**	**.1286**	**.4052**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR RURAL DIVISION[533]
SOLAPUR R-II S/DN.[095] BU 1333
Substation No/ Name :- 274219 / 33/11kV AURAD
Feeder No / Name : 203 / 11 KV TEMPLE SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.2058	.2401	.2058	.3429	.2572	.3258	.3772
16	.1372	.1543	.1715	.1543	.1372		.1829
24	.1677	.1829	.2439	.1829	.2439	.2743	.1715
Max	**.2058**	**.2401**	**.2439**	**.3429**	**.2572**	**.3258**	**.3772**
Min	**.1372**	**.1543**	**.1715**	**.1543**	**.1372**	**.2743**	**.1715**
Avg	**.1702**	**.1924**	**.2071**	**.2267**	**.2128**	**.3001**	**.2439**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (B) S/DN.[087] BU 4087
Substation No/ Name :- 274008 / 33/11 KV Water Works
Feeder No / Name : 201 / 11KV WATER WORKS SOLAPUR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9036	.9036	.8589	.8413
2	.8859	.8596	.8413	.8063
3	.8859	.8596	.8413	.8063
4	.8859	.9134	.8063	.8063
5	.9412	1.0387	.8859	1.0974
6	1.1888	1.267	1.1403	1.0974
7	1.3491	1.4045	1.386	1.3443
8	1.3352	1.3352	1.386	1.2936
9	1.3676	1.3394	1.3394	1.2197
10	1.3032	1.382	1.3073	1.3121
11	1.3253	1.4327	1.2894	1.3717
12	1.262	1.379	1.258	1.2308
13	1.2357	1.3213	1.1568	1.1946
14		1.2308	1.0867	1.1946
15	1.1765	1.182	1.1041	1.182
16	1.1641	1.2308	1.0974	1.2894
17	1.3289	1.382	1.1462	1.448
18	1.7511	1.7164	1.6126	1.6651
19	1.8898	1.893	1.7896	2.0119
20	1.6651	1.7896	1.6644	1.7926
21	1.4548	1.4883	1.4217	1.4969
22	1.2934	1.2757	1.2757	1.3717
23	1.0454	1.0166	1.0166	1.0029
24	.9492	.9391	.8939	.8589
Max	**1.8898**	**1.893**	**1.7896**	**2.0119**
Min	**.8859**	**.8596**	**.8063**	**.8063**
Avg	**1.2429**	**1.2742**	**1.1919**	**1.2390**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (B) S/DN.[087] BU 4087
Substation No/ Name :- 274008 / 33/11 KV Water Works
Feeder No / Name : 202 / 11 KV DAV FEEDER **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4784	.443	.4287	.4287
2	.4607	.4252	.3944	.4115
3	.443	.4225	.3856	.4075
4	.4477	.4477	.4075	.4075
5	.4666	.4656	.443	.5121
6	.6219	.6401	.5973	.6767
7	.7095	.6908	.7282	.8029
8	.7577	.7392	.7682	.8507
9	.6697	.6447	.6584	.8238
10	.6024	.5609	.5493	.7164
11	.4961	.5258	.5014	.5487
12	.4854	.5087	.407	.5658
13	.4508	.4733	.3772	.5144
14		.4031	.3772	.4161
15	.4382	.4031	.3856	.3814
16	.4207	.4382	.3898	.5304
17	.4681	.4508	.4239	
18	.7522	.6687	.6415	.7762
19	.8238	.8402	.7888	
20	.7802	.7802	.7628	.8775
21	.7455	.7455	.7362	.8402
22	.6556	.6379	.6485	.7762
23	.5316	.5201	.5375	.5014
24	.4961	.443	.4508	.4458
Max	**.8238**	**.8402**	**.7888**	**.8775**
Min	**.4207**	**.4031**	**.3772**	**.3814**
Avg	**.5740**	**.5549**	**.5329**	**.6005**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (B) S/DN.[087] BU 4087
Substation No/ Name :- 274008 / 33/11 KV Water Works
Feeder No / Name : 203 / 11 KV BHAVANI PETH SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3801	.3439	.3544	.3258
2	.362	.3258	.3189	.3045
3	.362	.3258	.3189	.2865
4	.362	.3258	.3189	.2865
5	.3841	.3109	.3189	.3658
6	.5121	.4207	.4525	.4572
7	.4854	.5658	.547	.6036
8	.6036	.6219	.5788	.6219
9	.5611	.5258	.5415	.6219
10	.6268	.5721	.5121	.6584
11	.567	.583	.4805	.631
12	.5087	.57	.4024	.6068
13	.5083	.4908	.3475	.5083
14		.4854	.3658	.4607
15	.4854	.4854	.3696	.4854
16	.5083	.5087	.3174	.5258
17	.5316	.5533	.3921	.6135
18	.8309	.763	.6485	.6588
19	.8059	.8987	.7265	.8669
20	.7628	.7716	.7087	.7202
21	.7108	.6762	.6268	.6001
22	.5256	.5959	.5792	.5201
23	.4706	.4733	.4656	.4075
24	.4163	.3982	.3582	.362
Max	**.8309**	**.8987**	**.7265**	**.8669**
Min	**.362**	**.3109**	**.3174**	**.2865**
Avg	**.5335**	**.5247**	**.4604**	**.5208**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (B) S/DN.[087] BU 4087
Substation No/ Name :- 274008 / 33/11 KV Water Works
Feeder No / Name : 204 / 11 KV SAMACHAR **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3441	.3441	.3281	.3201
2	.3401	.3441	.3125	.3201
3	.3441	.3441	.3201	.3201
4	.3441	.3441	.3201	.3201
5	.3561	.3441	.3277	.3481
6	.3814	.4024	.407	.3481
7	.4607	.443	.4525	.443
8	.4681	.4784	.4854	.4681
9	.4508	.4607	.4508	.4733
10	.5138	.4681	.4681	.5083
11	.5847	.5548	.5138	.5083
12	.5258	.5609	.5375	.5258
13	.5434	.5493	.5028	.5609
14		.5138	.4854	.5434
15	.4607	.5194	.4477	.5138
16	.4733	.4961	.4835	.5258
17	.4854	.5609	.5316	.6135
18	.7712	.7975	.8238	.7265
19	.8322	.9015	.9391	.8505
20	.7373	.8573	.823	.7011
21	.5801	.6371	.6036	.6135
22	.4588	.503	.4752	.4578
23	.3932	.4049	.4161	.4024
24	.3647	.3441	.3361	.3321
Max	**.8322**	**.9015**	**.9391**	**.8505**
Min	**.3401**	**.3441**	**.3125**	**.3201**
Avg	**.4876**	**.5072**	**.4913**	**.4894**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (B) S/DN.[087] BU 4087
Substation No/ Name :- 274008 / 33/11 KV Water Works
Feeder No / Name : 205 / 11 KV JODBHAVI PETH SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1387	.124	.1017	.1187
2	.1227	.1254	.1017	.12
3	.124	.1075	.1017	.1029
4	.124	.1075	.1017	.12
5	.1267	.1433	.1214	.1433
6	.1463	.1612	.1595	.1791
7	.1646	.1829	.1848	.2033
8	.1928	.1928	.181	.2427
9	.2321	.208	.2279	.2254
10	.2214	.2258	.2035	.2601
11	.2172	.2494	.1886	.2629
12	.2172	.2347	.1802	.2641
13	.2054	.2172	.1696	.1932
14		.176	.1715	.1829
15	.2	.208	.1791	.2054
16	.1858	.2201	.1402	.208
17	.1882	.2378	.1578	.2378
18	.2972	.2896	.2321	.2709
19	.3353	.3281	.2785	.301
20	.2949	.2846	.2561	.2751
21	.2652	.2401	.2294	.2751
22	.2035	.213	.2012	.1974
23	.1543	.1638	.1658	.1389
24	.1387	.124	.1017	.1187
Max	**.3353**	**.3281**	**.2785**	**.301**
Min	**.1227**	**.1075**	**.1017**	**.1029**
Avg	**.1955**	**.1985**	**.1724**	**.2020**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (B) S/DN.[087] BU 4087
Substation No/ Name :- 274008 / 33/11 KV Water Works
Feeder No / Name : 207 / 11 KV PUMP HOUSE NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2214	.3142	.3142	.3142
2	.2214	.3142	.3109	.3142
3	.2214	.3142	.3109	.3142
4	.2214	.3142	.3109	.3142
5	.2214	.3142	.3326	.3142
6	.064	.3142	.3326	.3142
7	.0617	.3142	.3326	.3326
8	.2294	.3109	.3326	.3326
9	.2486	.2534	.3142	.3292
10	.2515	.2534	.3142	.3292
11	.2683	.2561	.3395	.3292
12	.2515	.3109	.3142	.3326
13	.2486	.3292	.3109	.3511
14		.3292	.3292	.3511
15	.2458	.3292	.3326	.3696
16	.1783	.3292	.3326	.3547
17	.0669	.3142	.3142	.3511
18	.3142	.3292	.3174	.3326
19	.3142	.3142	.3326	.3292
20	.3109	.3142	.3326	.3292
21	.0718	.3174	.3361	.3326
22	.0718	.3142	.3361	.2801
23	.3142	.3326	.3326	.2321
24	.3326	.3142	.3326	.3326
Max	**.3326**	**.3326**	**.3395**	**.3696**
Min	**.0617**	**.2534**	**.3109**	**.2321**
Avg	**.2153**	**.3105**	**.3250**	**.3257**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (B) S/DN.[087] BU 4087
Substation No/ Name :- 274133 / 33/11KV RAJENDRA CHOWK S/STN
Feeder No / Name : 201 / 11 KV SAKHAR PETH FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8505	.8063	.8063	.7802
2	.8238	.7796	.7796	.7455
3	.788	.7619	.7522	
4	.7783	.7522	.7164	.7011
5	.8326	.788	.7602	.7442
6	.8954	.8869	.8507	.8505
7	.9671		.9328	.9412
8	.9593	1.0059	1.0498	.9774
9	1.0791	1.086	1.1222	1.0317
10	1.182	1.134	1.1871	1.1462
11	1.2894	1.182	1.1283	1.2178
12	1.262	1.1641	1.1393	1.1871
13	1.2934	1.1871	1.1163	1.2445
14	1.2048	1.0985	1.0808	1.134
15	1.0985	1.0631	.9745	.9745
16	1.1104	1.0808	.9214	1.0277
17	1.1744	1.1043	.9882	1.1043
18	1.6991	1.6827	1.4737	1.5261
19	1.9033	1.8551	1.7147	1.869
20	1.7318	1.8031	1.6118	1.749
21	1.4746	1.4413	1.3735	1.4217
22	1.166	1.1145	1.166	1.1963
23	.929	.9088	.9088	.9326
24	.8859	.8413	.823	.8059
Max	**1.9033**	**1.8551**	**1.7147**	**1.869**
Min	**.7783**	**.7522**	**.7164**	**.7011**
Avg	**1.1408**	**1.1099**	**1.0574**	**1.1004**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (B) S/DN.[087] BU 4087
Substation No/ Name :- 274133 / 33/11KV RAJENDRA CHOWK S/STN
Feeder No / Name : 202 / 11 KV NETAJI FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3366	.3366	.333	.3294
2	.3224	.3189	.3189	.3155
3	.3224	.3012	.3012	.2804
4	.3077	.3045	.2865	.2835
5	.3258	.3224	.3077	.3012
6	.362	.362	.3439	.3403
7	.4298	.4207	.3841	.3801
8	.4706	.4755	.4344	.5373
9	.5121	.4887	.4572	.5249
10	.5138	.5014	.4887	.5792
11	.5373	.5194	.4119	.5731
12	.4961	.4607	.4075	.5721
13	.567	.4784	.3898	.5609
14	.4525	.4525	.3801	.4961
15	.4525	.4784	.3439	.4298
16	.4961	.443	.362	.4607
17	.5083	.4908	.3801	.5784
18	.7455	.7362	.5784	.6344
19	.7888	.7282	.6687	.7888
20	.6859	.6935	.6687	.7373
21	.6344	.5935	.5935	.6762
22	.5144	.4801		.5548
23	.4031	.3772	.3772	.4334
24	.3544	.3506	.3429	.3429
Max	**.7888**	**.7362**	**.6687**	**.7888**
Min	**.3077**	**.3012**	**.2865**	**.2804**
Avg	**.4808**	**.4631**	**.4157**	**.4879**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (C) S/DN.[088] BU 4088
Substation No/ Name :- 274019 / 33/11 KV CIVIL
Feeder No / Name : 201 / 11 KV RAMLAL **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9593	.905	
2		.905	.8507	
3			.8145	
4		.9593	.8688	
5		1.0136	.905	
6		1.0679	.9593	
7		1.2308	1.2127	
8		1.267	1.267	1.4661
9	1.2489	1.2127	1.3213	1.3394
10	1.3969	1.4118		1.3394
11	1.3937	1.448		1.3394
12	1.4118		1.3575	1.3575
13	1.3032	1.3213		1.2308
14	1.3032	1.2308		1.1041
15	1.3032	1.2308		1.1765
16	1.3032	1.1765	1.1584	
24		.9955	.9412	.9593
Max	**1.4118**	**1.448**	**1.3575**	**1.4661**
Min	**1.2489**	**.905**	**.8145**	**.9593**
Avg	**1.3330**	**1.1620**	**1.0468**	**1.2569**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (C) S/DN.[088] BU 4088
Substation No/ Name :- 274019 / 33/11 KV CIVIL
Feeder No / Name : 204 / 11 KV BAPUJI NAGAR **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6268	.5731	
2			.5731	.5373	
3			.5373	.5373	
4			.6268	.6268	
5			.7343	.7522	
6			.788	.8596	
7			.8417	1.0387	
8			.9134	1.0924	.9671
9		1.1462	1.0029	.9671	.9671
10		.9671	.8775		.8417
11		.9134	.7343		.7522
12		.8059	.6626	.3761	.7522
13		.8059	.7164		.6984
14		.788	.6447		.6626
15		.788	.6447	.3224	.6805
16	.6089	.6805	.6268	.2865	
24			.6805	.6447	.6626
Max	**.6089**	**1.1462**	**1.0029**	**1.0924**	**.9671**
Min	**.6089**	**.6805**	**.5373**	**.2865**	**.6626**
Avg	**.6089**	**.8619**	**.7195**	**.6626**	**.7760**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (C) S/DN.[088] BU 4088
Substation No/ Name :- 274019 / 33/11 KV CIVIL
Feeder No / Name : 205 / 11 KV JAGDAMBA **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.8962	.7682	
2			.823	.7316	
3			.7682	.6767	
4			.8779	.7865	
5			1.0059	.9511	
6			1.1523	1.2071	
7			1.2803	1.3352	
8			1.3535	1.4449	1.39
9		1.4449	1.3535	1.3169	1.2437
10		1.39	1.1157		1.0242
11		1.262	1.0608		.9511
12		1.1523	.9877	1.6095	.9328
13		1.1157	1.0242		.823
14		1.0791	.9145		.8048
15		.9877	.9328	1.4815	.7865
16	.9877	.9328	.9145		
24			.9511	.823	.9877
Max	**.9877**	**1.4449**	**1.3535**	**1.6095**	**1.39**
Min	**.9877**	**.9328**	**.7682**	**.6767**	**.7865**
Avg	**.9877**	**1.1706**	**1.0242**	**1.0944**	**.9938**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (C) S/DN.[088] BU 4088
Substation No/ Name :- 274019 / 33/11 KV CIVIL
Feeder No / Name : 206 / 11 KV DAK BUNGLOW NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6584	.5853	
2			.6219	.5487	
3			.567	.5487	
4			.6036	.5853	
5			.6767	.6401	
6			.7133	.6767	
7			.7316	.7133	
8			.8048	.9145	.8413
9		.8596	.8779		.8413
10		.823	.8048		.7682
11		.7865	.7682		.7682
12		.823	.7316		.7682
13		.8596	.7499		.7682
14		.8413	.7865		.7682
15		.8048	.8048		.7316
16	.8779	.823	.7499		
24			.695	.6219	.6767
Max	**.8779**	**.8596**	**.8779**	**.9145**	**.8413**
Min	**.8779**	**.7865**	**.567**	**.5487**	**.6767**
Avg	**.8779**	**.8276**	**.7262**	**.6483**	**.7702**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (C) S/DN.[088] BU 4088
Substation No/ Name :- 274019 / 33/11 KV CIVIL
Feeder No / Name : 207 / 11 KV SHIDDHESHWAR PETH SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1991		
2			.181	.181	
3			.181	.181	
4			.181	.1991	
5			.1991	.1991	
6			.2172	.2172	
7			.2353	.2896	
8			.2534	.3077	.2896
9		.2896	.3077	.362	.2715
10		.2896	.2715		.2896
11		.3077	.2896	.1991	.2896
12		.3258	.2896		.3258
13		.3439	.2896		.3077
14		.3077	.3077		.3077
15		.2715	.2896	.3439	.2715
16	.3258	.2896	.2353	.2896	
24			.2534	.2172	.2172
Max	**.3258**	**.3439**	**.3077**	**.362**	**.3258**
Min	**.3258**	**.2715**	**.181**	**.181**	**.2172**
Avg	**.3258**	**.3032**	**.2459**	**.2489**	**.2856**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (C) S/DN.[088] BU 4088
Substation No/ Name :- 274019 / 33/11 KV CIVIL
Feeder No / Name : 208 / 11KV CIVIL EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3403	.3045	
2			.3045	.2865	
3			.3045	.2686	
4			.3403	.3045	
5			.3403	.3582	
6			.3582	.394	
7			.4298	.4119	
8			.4656	.4835	.5194
9			.5552	.6268	.5731
10		.5731	.6447		.5731
11		.591	.6089		.6089
12		.6089	.5731	.591	.5552
13		.5194	.5731		.5194
14		.5014	.5194		.4298
15		.5014	.4298		.4835
16	.4298	.3582	.394	.394	
24			.3761	.3403	.3403
Max	**.4298**	**.6089**	**.6447**	**.6268**	**.6089**
Min	**.4298**	**.3582**	**.3045**	**.2686**	**.3403**
Avg	**.4298**	**.5219**	**.4446**	**.3970**	**.5114**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (C) S/DN.[088] BU 4088
Substation No/ Name :- 274095 / 33/11KV ADITYA NAGAR
Feeder No / Name : 201 / 11 KV Limyewadi **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6767	.6401	.5853	.5853
2		.6767	.6219	.5853	.5853
3		.6584	.6401	.5853	.5853
4		.6838	.6468	.6036	.5853
5		.7762	.7392	.7577	.7207
6		1.0719	1.0719	1.0903	1.0349
7		1.2136	1.2883	1.1576	1.2136
8		1.2136	1.307	1.2323	
9		.9896	1.0719	1.0719	
10		.8589	.924	1.0164	.9055
11		.7356	.7392	.7947	.7207
12		.6602	.6401	.6653	.6099
13		.5853	.6283		.5544
14		.5853	.6219		.5359
15		.5853	.5792	.5729	.499
16		.567	.6219	.5544	.5544
17		.6556	.724	.6283	.5914
18		.964	.8775	.7947	.9795
19		1.0985	1.2048	1.1403	1.1765
20		1.0631	1.1218	1.0277	1.0808
21		1.0317	.9991	1.0808	1.0166
22		.905	.8328	.9412	.8859
23	.6219	.724	.7059	.7499	.6878
24		.695	.6767	.6219	.6219
Max	**.6219**	**1.2136**	**1.307**	**1.2323**	**1.2136**
Min	**.6219**	**.567**	**.5792**	**.5544**	**.499**
Avg	**.6219**	**.8198**	**.8302**	**.8299**	**.7605**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (C) S/DN.[088] BU 4088
Substation No/ Name :- 274095 / 33/11KV ADITYA NAGAR
Feeder No / Name : 202 / 11 KV Modi **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7865	.7133	.7499	.6767
2	.7133	.695	.6767	.695
3	.7133	.6767	.6401	.7499
4	.695	.7577	.7133	.6584
5	.7682	.8131	.8501	.8131
6	.9511	.9979	1.0534	.9979
7	1.0829	.9896	1.0456	1.0456
8	1.1203	1.1389	1.0642	
9	.9896	.924	1.1088	
10	1.0082	.9145	1.0164	.924
11	.924	.823	1.0164	.924
12	.8131	.823	.8316	.8316
13	.7947	.8316		.8316
14	.924	.8316		.7392
15	.924	.7316	.8316	.7392
16	.8316	.7316	.924	.7316
17	.9328	.8145	.9425	.8871
18	1.3394	.985	1.0719	1.1827
19	1.448	1.3432	1.3937	1.4842
20	1.3937	1.382	1.3073	1.3432
21	1.267	1.2757	1.2894	1.258
22	1.1403	1.1041		1.0317
23	.9231	.905	.8869	.8869
24	.823	.8413	.7865	.695
Max	**1.448**	**1.382**	**1.3937**	**1.4842**
Min	**.695**	**.6767**	**.6401**	**.6584**
Avg	**.9711**	**.9185**	**.9619**	**.9148**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (C) S/DN.[088] BU 4088
Substation No/ Name :- 274095 / 33/11KV ADITYA NAGAR
Feeder No / Name : 203 / 11 KV Mahalaxmi **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4733	.4557	.4334	.4334
2	.4607	.4557	.4382	.4207
3	.443	.4382	.4382	.4207
4	.4607	.4382	.4252	.4207
5	.5493	.5083	.5138	.4784
6	.691	.6733	.7265	.6379
7	.9036	.9036	.9391	.8682
8	.9391	.8238	.8682	
9	.8238	.724	.8316	
10	.7343	.9511	.724	.7011
11	.6135	.5373	.6335	.6135
12	.5548	.543	.543	.5258
13	.4801	.5258		.5258
14	.4973	.5258		.5258
15	.4801	.4382	.5258	.5258
16	.4973	.4382	.5258	.543
17	.5596	.5201	.5083	.5792
18	.6613	.583	.5895	.6878
19	.78	.8916	.8059	.8939
20	.78	.9088	.8059	.8238
21	.7461	.823	.7716	.7712
22	.6173	.7202	.6516	.6762
23	.5316	.5316	.5144	.5201
24	.4733	.4733	.4681	.4334
Max	**.9391**	**.9511**	**.9391**	**.8939**
Min	**.443**	**.4382**	**.4252**	**.4207**
Avg	**.6146**	**.6180**	**.6219**	**.5921**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (C) S/DN.[088] BU 4088
Substation No/ Name :- 274095 / 33/11KV ADITYA NAGAR
Feeder No / Name : 204 / 11 KV RAILWAY EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2263	.2263	.2263
2	.2452		.2263	.2263
3	.2641	.2263	.2263	.2452
4	.2452	.2263	.2452	.2452
5	.2452	.2263	.2452	.2263
6	.2452	.2452	.2452	.2452
7	.2641	.2641	.2641	.2452
8	.2641	.2641	.2829	
9	.2829	.2829	1.1088	
10	.3584	.3018	.3772	.2829
11	.3584	.3772	.2829	.2829
12	.3395	.3772	.2829	.2829
13	.3206	.3772		.0754
14	.3206	.2829		.2829
15	.3395	.2829	.2829	.2829
16	.3206	.2829	.2829	.2829
17	.3206	.2829	.3206	.3018
18	.3584	.3018	.3206	.3395
19	.3584	.3206	.3018	.3206
20	.3206	.2829	.2829	.2829
21	.3395	.2829	.2829	.3018
22	.3018	.2263	.2829	.3018
23	.2641	.2641	.2452	.2641
24	.2452	.2641	.2452	.2263
Max	**.3584**	**.3772**	**1.1088**	**.3395**
Min	**.2263**	**.2263**	**.2263**	**.0754**
Avg	**.2979**	**.2813**	**.3119**	**.2623**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (C) S/DN.[088] BU 4088
Substation No/ Name :- 274095 / 33/11KV ADITYA NAGAR
Feeder No / Name : 205 / 11KV GANGA EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0189	.0189	.0189
2	.0189	.0189	.0189	.0189
3	.0189	.0189	.0189	.0189
4	.0377	.0189	.0189	.0189
5	.0189	.0189	.0189	.0189
6	.0189	.0189	.0189	.0189
7	.0377	.0189	.0377	.0377
8	.0377	.0189	.0377	
9	.0377	.0377	.0377	
10	.0377	.0377	.0754	.0377
11	.0377	.0943	.0566	.0754
12	.0566	.0943	.0566	.0943
13	.0566	.0754		.0754
14	.0566	.0566		.0566
15	.0377	.0377	.0566	.0377
16	.0377	.0377	.0566	.0377
17	.0377	.0377	.0566	.0566
18	.0377	.0377	.0377	.0377
19	.0377	.0566	.0189	.0377
20	.0377	.0377	.0189	.0377
21	.0377	.0377	.0189	.0377
22	.0377	.0377	.0377	.0377
23	.0189	.0189	.0377	.0377
24	.0189	.0189	.0189	.0189
Max	**.0566**	**.0943**	**.0754**	**.0943**
Min	**.0189**	**.0189**	**.0189**	**.0189**
Avg	**.0346**	**.0377**	**.0352**	**.0394**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (C) S/DN.[088] BU 4088
Substation No/ Name :- 274200 / 33/11KV GADDA MAIDAN
Feeder No / Name : 201 / 11KV COLLECTOR OFFICE
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6348	.6535	.6161	.6348
2	.6348	.6535	.5975	.6348
3	.6535	.6348	.5975	.6161
4	.6348	.6348	.5975	.6161
5	.6348	.6535	.5487	.6161
6	.6161	.6535	.5975	.6348
7	.6722	.7095	.7468	.7095
8	.7095		.8029	.8029
9	.8589	.8962	.8402	.8402
10	.9896	.9896	.9149	.9149
11	1.0751	1.0269	1.0456	1.0642
12	1.1128	1.0829	1.0562	1.0082
13	1.094	.9896	1.0185	1.0269
14	1.0374	.9896	.9335	.9522
15	.9997	.9522	.9335	1.0269
16	1.0374	1.0642	.9709	1.0082
17	1.0456	1.0829	.9896	1.0269
18	1.307	1.1949	1.1203	1.3443
19	1.307	1.2696	1.3817	1.2883
20	1.1949	1.1949	1.251	1.1576
21	1.1203	1.0829	1.1016	1.0456
22	.9335	.9335	.8962	.8962
23	.7842	.7655	.8215	.7095
24	.6535	.6535	.6161	.6348
Max	**1.307**	**1.2696**	**1.3817**	**1.3443**
Min	**.6161**	**.6348**	**.5487**	**.6161**
Avg	**.9059**	**.9027**	**.8748**	**.8838**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (D) S/DN.[089] BU 4089
Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR
Feeder No / Name : 201 / 11 KV MIDC NO 3 SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1475	.2401	.192	.0667
2		.1619	.2267	.192	.0676
3		.1619	.2294	.1638	.0676
4		.1457	.2155	.1823	.0686
5		.1619	.218	.1475	.0686
6		.1781	.2035	.1372	.0695
7		.2006	.2058	.1612	.0695
8		.4668	.5571	.0972	.4115
9	.6493	.6219	.5999	.1017	.5007
10	.7099	.7021	.723	.1132	.5868
11	.7602	.8471	.8032	.1075	.6135
12	.8025	.7531	.7125	.1029	.6573
13	.5841	.5681	.4268	.0838	.6173
14	.7125	.6344	.7068	.081	.5068
15	.6996	.7167	.744	.0791	.6179
16	.6802		.7145	.0772	.5441
17		.6866	.7602	.081	.6382
18		.6268	.5792	.0819	.5335
19		.3239	.3479	.0848	.2486
20		.373	.3155	.0848	.2279
21		.3113	.2896	.0781	.2658
22		.2561	.2846	.0667	.2103
23	.2481		.2214	.0657	
24		.1638	.2401	.192	.0667
Max	**.8025**	**.8471**	**.8032**	**.192**	**.6573**
Min	**.2481**	**.1457**	**.2035**	**.0657**	**.0667**
Avg	**.6496**	**.4186**	**.4402**	**.1148**	**.3359**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (D) S/DN.[089] BU 4089
Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR
Feeder No / Name : 202 / 11KV Bhadrawati SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2286	.2096	.1524	.1143
2		.2286	.2286	.1524	.1143
3		.2096	.2477	.1524	.1143
4		.2286	.2667	.1715	.0819
5		.2286	.2543	.1715	.0819
6		.2477	.2683	.1715	.0819
7		.2452	.0168	.1905	.0819
8		.5401	.7291	.1715	.503
9	.8842	.7225	.7316	.1715	.6415
10	1.1218	.9442	.7526	.1715	.7969
11	1.1218	1.034	.884	.1715	.6836
12	1.0883	.9442	.8951	.1524	.7827
13	.7676	.6472	.7773	.1334	.6019
14	.6093	.9962	.7811	.1143	.5937
15	.9231	.9105	.8025	.0953	.6748
16	1.0883	.9602	.7811	.0953	.5765
17		.8697	.7968	.1143	.8592
18		.7811	.6327	.1334	.6327
19		.362	.4108	.2096	.3584
20		.2477	.3018	.1715	.2477
21		.2096	.2263	.1524	.1905
22		.1715	.1905	.1334	.1905
23	.2477		.1886	.1334	
24		.2286	.1905	.1524	.1143
Max	**1.1218**	**1.034**	**.8951**	**.2096**	**.8592**
Min	**.2477**	**.1715**	**.0168**	**.0953**	**.0819**
Avg	**.8725**	**.5298**	**.4819**	**.1516**	**.3965**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (D) S/DN.[089] BU 4089
Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR
Feeder No / Name : 203 / 11KV MIDC NO.4 SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1905	.1905	.2096	.1905
2		.1905	.1905	.2096	.1905
3		.1905	.1905	.2096	.2096
4		.1905	.1905	.2286	.2096
5		.1905	.1905	.2096	.2096
6		.1905		.1905	.2286
7		.2286	.1905	.1715	.2286
8		.6097	.7613	.1905	.503
9	.8368	.823	.8741	.1905	.7775
10	.9318	.9328	.9469	.1905	.86
11	1.0562	1.0136	.8792	.1905	
12	1.0574	1.0402	.904	.1905	1.0014
13	.7922	.7895	.7573	.2286	.7145
14	.9069	.8002	.8067	.2286	.7002
15	.9469	.9335	.9739	.2286	.8859
16	.8522	.8535	.8505	.1715	.8368
17		.8522	.8657	.1905	.8522
18		.8093	.7002	.2286	.7649
19		.4287	.4557	.1715	.4382
20		.2286	.2957	.1715	.2534
21		.2286	.2195	.1715	.1905
22		.2286	.2402	.1715	.1905
23	.2096		.2658	.2096	
24		.1905	.1905	.2477	
Max	**1.0574**	**1.0402**	**.9739**	**.2477**	**1.0014**
Min	**.2096**	**.1905**	**.1905**	**.1715**	**.1905**
Avg	**.8433**	**.5276**	**.5274**	**.2001**	**.4970**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (D) S/DN.[089] BU 4089
Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR
Feeder No / Name : 204 / 11 KV MIDC NO.5 SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3206	.3475	.3326	.2328
2		.3018	.3696	.2926	.2353
3		.2829	.3696	.2926	.2534
4		.2829	.3761	.2772	.2534
5		.3018	.4108	.3174	.2561
6		.3395	.4338	.3326	.2772
7		.4338	.4338	.3772	.2772
8		.9907	1.1443	.3292	.8383
9	1.2266	1.1961	1.2717	.3086	1.1149
10	1.3676	1.3253	1.2795	.2949	1.1717
11	1.4575	1.4464	1.3213	.2429	1.262
12	1.4563	1.4047	1.3855	.2294	1.3253
13	1.1126	1.2742	1.1584	.1823	1.057
14	1.142	1.0288	1.1279	.1844	.9054
15	1.1385	1.2378	1.2795	.1865	1.1544
16	1.3003	1.2934	1.3575	.1823	1.2548
17		1.2656	1.3394	.1696	1.1797
18		1.2407	1.278	.2126	1.1873
19		.7969	.8215	.2896	.7628
20		.6001	.6001	.2896	.5373
21		.5258	.5028	.2715	.5194
22		.4298	.4557	.2715	.4706
23	.3547		.3814	.2328	
24		.3142	.3475	.3511	.2328
Max	**1.4575**	**1.4464**	**1.3855**	**.3772**	**1.3253**
Min	**.3547**	**.2829**	**.3475**	**.1696**	**.2328**
Avg	**1.1729**	**.8102**	**.8247**	**.2688**	**.7287**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (D) S/DN.[089] BU 4089
Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR
Feeder No / Name : 205 / 11 KV SANKURI SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2096	.2096	.2286	.1715
2		.2667	.2286	.2477	.1715
3		.1905	.2286	.2286	.1715
4		.2096	.2477	.2096	.1715
5		.2096	.2477	.2286	.1715
6		.2286	.2667	.2286	.1715
7		.2452	.2858	.2286	.1715
8		.4915	.6241	.1905	.3641
9		.9442	.6478	.1715	.5256
10	.7375	.7407	.7526	.1715	.6081
11	.8078	.7819	.7628	.1715	.7282
12	.759	.7674	.8362	.1715	.7282
13	.5258	.5304	.5304	.1905	.4191
14	.6472	.5121	.6401	.1905	.4744
15	.6554	.6895	.7727	.1905	.5639
16		.7482	.7811	.1905	.6249
17		.7011	.6773	.1905	.639
18		.6483	.5376	.1905	.5218
19		.3547	.3174	.1905	.2096
20		.2477	.2286	.1905	.2286
21		.2286	.2286	.1905	
22		.2096	.2427	.1715	.1905
23	.6401		.2452	.1715	
24		.2096	.2096	.2641	.1715
Max	**.8078**	**.9442**	**.8362**	**.2641**	**.7282**
Min	**.5258**	**.1905**	**.2096**	**.1715**	**.1715**
Avg	**.6818**	**.4507**	**.4479**	**.1999**	**.3726**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (D) S/DN.[089] BU 4089
Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR
Feeder No / Name : 206 / 11 KV VINKAR SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2096	.2477	.3361	.5525
2		.2075	.2561	.3142	.5525
3		.1886	.2561	.3206	.5525
4		.1886	.2772	.2641	.5525
5		.2075	.2772	.2614	.5525
6		.2075	.2987	.2195	.5525
7		.3326	.3174	.2614	.5525
8		.6097	.7775	.1905	.5247
9	.8288	.8288	.9907	.1829	.7573
10	1.0536	1.0151	1.07	.2012	.9412
11	1.1294	1.142	1.3032	.1753	1.1145
12	1.1279	1.1717	1.2929	.1543	1.1092
13	.873	.9332	.9259	.1829	.8484
14	.7093	.8322	1.1736	.1593	.86
15	1.0431	1.1294	1.2146	.1195	.9202
16	1.1584	1.2308	1.2029	.1257	1.0136
17			1.1288	.1257	.9602
18		1.0136	1.1145	.1669	.9318
19		.6882	.6962	.1303	.5864
20		.4344	.503	.1296	.3637
21		.381	.431	.1353	.2824
22		.2858	.407	.1429	.2812
23	.2096		.3109	.1905	
24		.2096	.2477	.3109	.5525
Max	**1.1584**	**1.2308**	**1.3032**	**.3361**	**1.1145**
Min	**.2096**	**.1886**	**.2477**	**.1195**	**.2812**
Avg	**.9037**	**.6112**	**.6967**	**.2000**	**.6919**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (D) S/DN.[089] BU 4089
Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR
Feeder No / Name : 405 / 33 KV CIVIL **SHEDDABLE URBAN**
Feeder KV- 33 / INCOMING

DATE	15-DEC-17	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			5.5744	7.4263	5.1234	6.6993
2			5.2915	7.4829	5.0285	6.8227
3		4.6965	5.2349	7.548	4.9337	6.9439
4		4.8097	5.4612	7.6046	4.9337	7.0085
5		5.036	5.9705	7.7698	5.3464	7.0645
6		6.2243	7.4349	7.9327	6.7107	7.3343
7		7.0731	8.5534	8.5299	8.0053	7.9836
8		8.3179	10.5768	7.9784	8.794	9.285
9	8.8838		11.1986	10.8334	8.4414	10.4059
10	9.0535		10.8419	10.9585	7.8127	10.1635
11	9.3364		11.0591	10.7825	7.4235	9.9811
12	9.2798		11.0111	10.7099	6.5055	10.0755
13	8.9403		9.8411	9.856	6.2351	8.7345
14	7.6955		8.8272	9.1609	6.3483	8.2538
15	8.1482		10.0189	9.4862	6.4141	8.5837
16	8.0916		9.5868	9.5868	4.952	8.9066
17			10.7545	10.3984	6.7627	9.6451
18			12.8567	12.3868	9.2507	11.5935
19			12.5497	12.528	11.1522	12.1091
20			11.6753	12.001	10.6676	11.4844
21			9.9074	10.2	9.6005	10.3601
22			8.5374	8.7809	8.7111	8.8077
23	6.2809		1.1283	6.5689	7.0577	1.0517
24			5.8482	7.4772	6.07	6.5746
Max	**9.3364**	**8.3179**	**12.8567**	**12.528**	**11.1522**	**12.1091**
Min	**6.2809**	**4.6965**	**1.1283**	**6.5689**	**4.9337**	**1.0517**
Avg	**8.4122**	**6.0263**	**8.7392**	**9.3328**	**7.1784**	**8.5780**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (D) S/DN.[089] BU 4089
Substation No/ Name :- 274045 / 33/11 KV BIDI GHARKUL
Feeder No / Name : 203 / 11KV GANDHI NAGAR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	17-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
2	.6859		
3	.6859		
4	.6859		
5	.6859		
7	.7716		
8	1.4575		
17		1.9719	1.8861
18		1.8861	1.7147
19		1.4575	1.2003
20		.8573	1.1145
21		1.0288	.8573
22		.9431	.8573
23		.8573	.7716
Max	**1.4575**	**1.9719**	**1.8861**
Min	**.6859**	**.8573**	**.7716**
Avg	**.8288**	**1.286**	**1.2003**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (D) S/DN.[089] BU 4089
Substation No/ Name :- 274045 / 33/11 KV BIDI GHARKUL
Feeder No / Name : 207 / 11 KV GADAGI **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	17-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.7716		
2	.6859		
3	.6859		
4	.6859		
5	.6859		
6	.8573		
7	1.1145		
8	1.2003		
17		.7716	.8573
18		1.2003	1.0288
19		1.4575	1.4575
20		1.4575	1.3717
21		1.3717	1.286
22		1.286	.9431
23		.9431	.7716
24	.8573		
Max	**1.2003**	**1.4575**	**1.4575**
Min	**.6859**	**.7716**	**.7716**
Avg	**.8383**	**1.2125**	**1.1023**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (D) S/DN.[089] BU 4089
Substation No/ Name :- 274191 / 33/11 KV POLYTECHNIC
Feeder No / Name : 201 / AMRAPALI **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3206	.2801	.298	.2772
2	.3206	.2801	.3045	.2614
3	.3206	.2801	.3142	.2614
4	.3206	.2801	.3142	.2614
5	.3206	.3174	.3361	.2801
6	.3734	.3547	.3734	.3361
7	.4031	.5359	.5041	.4854
8	.7127	.6952	.5788	.5731
9	.8916	.8579	.5228	.8124
10	.8398	.8173	.462	.8429
11	.9002	.8655	.4066	.7775
12	.9267	.8949	.3881	.8288
13	.7727	.7922	.3881	.639
14	.7188	.6687	.3658	.587
15	.7895	.7093	.3511	.6287
16	.8109	.7628	.3361	.6908
17	.8067	.8036	.3547	.724
18	1.0402	.9181	.5068	.8535
19	.9389	.8642	.6878	.8322
20	.7619	.8383	.6516	.7164
21	.6697	.6661	.567	.6626
22	.4938	.5373	.4755	.4961
23	.3696	.3988	.3326	.3439
24	.3174	.2987	.3467	.2772
Max	**1.0402**	**.9181**	**.6878**	**.8535**
Min	**.3174**	**.2801**	**.298**	**.2614**
Avg	**.6309**	**.6132**	**.4236**	**.5604**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (D) S/DN.[089] BU 4089
Substation No/ Name :- 274191 / 33/11 KV POLYTECHNIC
Feeder No / Name : 202 / 11 KV ASHOK CHOWK1 **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2481	.2629	.2743	.2454
2	.2481	.2629	.2658	.2481
3	.2481	.2658	.2686	.2534
4	.2481	.2658	.2686	.2534
5	.2481	.2835	.2926	.2715
6	.3224	.3544	.3511	.3439
7	.4607	.567	.4805	.5249
8	.7253	.7748	.5175	.6203
9	.8116	.8779	.439	.8398
10	.7735	.8387	.3544	.7649
11	.8169	.8162	.3224	.771
12	.8808	.7914	.2947	.8032
13	.7404	.6916	.2835	.5999
14	.6704	.6001	.2658	.5624
15	.7796	.7419	.2686	.6539
16	.7042	.7293	.2686	.644
17	.7545	.743	.2507	.6664
18	.9198	.8002	.3988	.727
19	.8223	.8025	.5765	.7842
20	.7125	.7522	.6001	.6802
21	.6203	.6299	.5658	.6203
22	.5365	.5304	.4973	.5256
23	.3601	.3391	.3601	.3561
24	.2454	.2883	.3018	.2743
Max	**.9198**	**.8779**	**.6001**	**.8398**
Min	**.2454**	**.2629**	**.2507**	**.2454**
Avg	**.5791**	**.5837**	**.3653**	**.5431**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (D) S/DN.[089] BU 4089
Substation No/ Name :- 274191 / 33/11 KV POLYTECHNIC
Feeder No / Name : 203 / 11 KV PATHAN BAG1 **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3174	.2926	.2926	.2926
2	.3174	.2926	.2801	.2743
3	.3174	.2957	.2801	.2743
4	.3174	.2957	.2801	.2743
5	.3174	.3326	.3174	.2743
6	.4251	.4066	.3734	.3658
7	.4854	.5914	.4668	.6219
8	.6859	.7011	.5415	.6984
9	.6718	.6962	.5359	.6783
10	.6009	.7682	.439	.5851
11	.5639	.6874	.3439	.5335
12	.4988	.587	.2507	.4923
13	.427	.4877	.2149	.3913
14	.443	.4475	.2507	.3749
15	.5268	.5418	.2534	.4548
16	.4725	.5312	.2561	.4268
17	.5418	.587	.2957	.5401
18	.7116	.6325	.4119	.6316
19	.7291	.663	.6024	.6661
20	.6762	.6344	.591	.6661
21	.6024	.5895	.5847	.6024
22	.5194	.5316	.5316	.5014
23	.3982	.3761	.4163	.3801
24	.3326	.3292	.3224	.3258
Max	**.7291**	**.7682**	**.6024**	**.6984**
Min	**.3174**	**.2926**	**.2149**	**.2743**
Avg	**.4958**	**.5124**	**.3805**	**.4719**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (D) S/DN.[089] BU 4089
Substation No/ Name :- 277012 / 132/33/11 KV SUB STATION MIDC
Feeder No / Name : 404 / 33 KV BIDIi GHARKUL SHEDDABLE URBAN
Feeder KV- 33 / OUTGOING

DATE	15-DEC-17	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5556	.6093	.6481	.6481	.5155
2		.5093	.6093	.6944	.6019	.5624
3		.5093	.5624	.7407	.6019	.6093
4		.5093	.5624	.787	.5556	.6562
5		.5556	.5624	.8333	.6019	.703
6		.6481	.6562	.8796	.6019	.7499
7		.7407	.8436	.9259	.5093	.7968
8		2.2685	2.3434	2.6389	.5556	1.6872
9	2.963		3.0933	3.1019	.5556	2.484
10	3.5648		3.6088	3.4259	.6019	3.1402
11	3.75		4.0306	3.9352	.5556	3.5151
12	3.6111		3.89	3.8889	.5093	3.7026
13	2.7315		2.9527	3.0093	.463	2.7652
14	2.6852		2.8121	3.2407	.4167	2.7183
15	3.2407		3.562	3.5648	.4167	2.9527
16	3.5648		3.6088	3.5151	.4218	3.4214
17			3.4682	3.4722	.4218	3.2808
18			3.3276	3.1019	.4687	2.9527
19			2.2497	1.713	.5624	1.5466
20			1.2186	1.25	.5155	1.0311
21			.9842	1.0185	.5155	.8905
22			.7499	.9259	.4687	.8436
23	.6481			.7407	.4687	
24		.5556	.6093	.6019	.6481	.4687
Max	**3.75**	**2.2685**	**4.0306**	**3.9352**	**.6481**	**3.7026**
Min	**.6481**	**.5093**	**.5624**	**.6019**	**.4167**	**.4687**
Avg	**2.9732**	**.7613**	**2.0398**	**2.0272**	**.5286**	**1.8258**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (D) S/DN.[089] BU 4089
Substation No/ Name :- 277012 / 132/33/11 KV SUB STATION MIDC
Feeder No / Name : 405 / 33 KV CIVIL Feeder KV- 33 / INCOMING **SHEDDABLE URBAN**

DATE	15-DEC-17	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		5.4887	4.9794	6.9599	4.9228	6.0545
2		5.5453	4.8097	7.1296	4.8663	6.1677
3		5.2624	4.7531	7.2994	4.6965	6.2809
4		5.3755	4.9794	7.4126	4.6965	6.394
5		5.5453	5.4887	7.4691	4.9794	6.5072
6		6.7901	6.8467	7.5257	6.1677	6.6204
7		7.8087	7.8652	7.5823	7.1296	1.1317
8		10.4681	10.1852	10.4681	7.6389	8.7706
9	1.8673		11.5998	11.4301	7.1296	10.2418
10	12.3354		11.8827	11.8261	6.9033	10.751
11	12.9013		12.3354	11.8261	6.6204	11.1471
12	9.2798		12.2788	11.6564	5.8282	11.3169
13	9.6759		10.2418	10.4681	5.4321	9.2798
14	10.072		9.5062	10.2418	5.4887	9.0535
15	11.2603		7.9784	10.8642	5.6584	9.5628
16	10.9774		10.8076	10.751	5.4321	9.9023
17			11.8261	11.4301	6.2243	10.6945
18			12.9578	12.392	8.1482	11.7696
19			11.5432	11.4301	9.7325	10.8076
20			10.4115	10.6379	9.2798	10.1852
21			8.714	9.0535	8.2613	9.1101
22			7.5257	7.9784	7.5823	7.8652
23	6.9599			6.3375	6.1677	
24		5.9414	5.3189	6.8467	5.8282	5.8848
Max	**12.9013**	**10.4681**	**12.9578**	**12.392**	**9.7325**	**11.7696**
Min	**1.8673**	**5.2624**	**4.7531**	**6.3375**	**4.6965**	**1.1317**
Avg	**9.4810**	**6.4695**	**8.9059**	**9.4590**	**6.4506**	**8.5000**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (E) S/DN.[579] BU 4579
Substation No/ Name :- 274003 / INDUSTRIAL ESTATE.
Feeder No / Name : 201 / 11KV RAMWADI SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.631	.7362	.6661	.6485
2	.631	.7362	.6661	.6485
3	.631	.7362	.6661	.6485
4	.631	.7362	.6661	.6485
5	.6485	.7712	.7011	.6485
6	.6836	.7888	.7537	.7362
7	.8238	.7888	.8413	.8238
8	.8764	.8413	.8764	.8764
9	.8238	.964	.929	.8939
10		.8589	.8063	.8063
11		.7712	.7888	.7537
12		.7186	.7011	.7537
13		.7362	.7186	.7362
14		.7011	.6485	.7011
15		.7186	.6135	.6661
16		.7011	.6836	.7011
17	.7362	.7011	.6661	.7712
18	.929	.929	.9465	.9465
19	1.1218	1.1393	1.1043	1.1218
20	1.0867	1.1043	1.0341	1.0517
21	1.0341	1.0867	.9991	1.0166
22	.929	.9816	.929	.9465
23	.8589	.7888	.7888	.7888
24	.7011	.7362	.6661	.7011
Max	**1.1218**	**1.1393**	**1.1043**	**1.1218**
Min	**.631**	**.7011**	**.6135**	**.6485**
Avg	**.8104**	**.8238**	**.7858**	**.7931**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (E) S/DN.[579] BU 4579
Substation No/ Name :- 274003 / INDUSTRIAL ESTATE.
Feeder No / Name : 202 / 11KV PRESS SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677	.1698	.1698	.1509
2	.148	.1886	.1698	.1509
3	.144	.1886	.1886	.1509
4	.14	.1886	.1886	.1509
5	.148	.1698	.1698	.1509
6	.5335	.1698	.1698	.1509
7	.1802	.1698	.1509	
8	.2473	.1698	.1509	.1698
9	.3018	.2075	.1509	.1713
10		.3018	.1509	
11		.333	.1509	
12		.3395	.1509	.3772
13		.1886	.1509	.2075
14		.2829		.3018
15		.3018		.3395
16		.3206		.3206
17	.3772	.3584	.1698	.3395
18	.3018	.3018	.1698	.3584
19	.2452	.2641	.1698	.2452
20	.1886	.2075	.1698	.1886
21	.1886	.1698	.1698	.1886
22	.1698	.1698	.1509	
23	.1886	.1698	.1509	.1509
24	.1509	.1698	.1698	.1509
Max	**.5335**	**.3584**	**.1886**	**.3772**
Min	**.14**	**.1698**	**.1509**	**.1509**
Avg	**.2248**	**.2292**	**.1635**	**.2208**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (E) S/DN.[579] BU 4579
Substation No/ Name :- 274003 / INDUSTRIAL ESTATE.
Feeder No / Name : 203 / 11KV POLYTECHNIC SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4668	.4458	.4287	.4024
2	.4108	.4359	.4287	.3658
3	.4108	.4359	.4191	.3658
4	.4108	.4359	.4191	.3658
5	.4108	.4588	.4641	.3658
6	.5415	.4588	.4915	.3658
7	.695	.5636	.5571	.679
8	.823	.7545	.6299	.8417
9	1.0208	.8745	.6661	1.0341
10		.929	.5658	.8916
11		.9431	.4382	.9214
12		.8573	.4382	.964
13		.7011	.4207	.6805
14		.7202	.3641	.7186
15		.8764	.3189	.7362
16		.9313	.333	.7282
17	.7287	.7093	.394	.6485
18	1.0402	.8619	.6379	.8223
19	.9724	.9282	.7712	.8886
20	.8817	.8916	.7362	.8238
21	.815	.8063	.7265	.7796
22	.6733	.6935	.6447	.5535
23	.5847	.4508	.5304	.4111
24	.4668	.4607	.4382	.4024
Max	**1.0402**	**.9431**	**.7712**	**1.0341**
Min	**.4108**	**.4359**	**.3189**	**.3658**
Avg	**.6678**	**.6927**	**.5109**	**.6565**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (E) S/DN.[579] BU 4579
Substation No/ Name :- 274003 / INDUSTRIAL ESTATE.
Feeder No / Name : 204 / 11KV MEDICAL **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7087	.7011	.6733	.6201
2	.6556	.7011	.6733	.6201
3		.7011	.6733	.6201
4	.6556	.7011	.6733	.6201
5	.6556	.7362	.7442	.6201
6	.6556	.7712	.7973	.7973
7		.9114	.9391	.9036
8	.9214	.9465	1.0631	.9568
9	.929	.8939	.9991	.9214
10		.7362	.8413	.7537
11		.6485	.6661	.7186
12		.6661	.6661	.631
13		.7712	.6485	.5959
14		.631	.631	.583
15		.6485	.5434	.5784
16		.6485	.5609	.5959
17	.6201	.6379	.567	.5847
18	.9922	.9391	.9036	.8505
19	1.1517	1.2403	1.1163	1.2048
20	1.1694	1.2403	1.1163	1.1871
21	1.0985	1.1163	1.0985	1.1163
22	.9922	1.0166	1.0099	.9568
23	.8505	.815	.7973	.7442
24	.7087	.7265	.6733	.6556
Max	**1.1694**	**1.2403**	**1.1163**	**1.2048**
Min	**.6201**	**.631**	**.5434**	**.5784**
Avg	**.8510**	**.8144**	**.7948**	**.7682**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (E) S/DN.[579] BU 4579
Substation No/ Name :- 274003 / INDUSTRIAL ESTATE.
Feeder No / Name : 206 / 11KV ESTATE 2 SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677	.2401	.1593	.148
2	.148	.216	.1844	.1334
3	.144	.216	.2012	.1219
4	.14	.1829	.2263	.1143
5	.148	.1677	.216	.1296
6	.16	.136	.2241	.1486
7	.1802	.14	.2481	.18
8	.2473	.3201	.2553	.2629
9	.4207	.4458	.3429	.4382
10		.5609	.3113	.4458
11		.591	.3086	.4706
12		.5434	.3258	.5194
13		.4801	.3721	.4887
14		.5138	.3544	.5434
15		.5201	.3506	.5316
16		.4835	.3544	.5316
17	.5788	.5249	.2281	.4961
18	.5121	.426	.3144	.4784
19	.3944	.4001	.3269	.4239
20	.3286	.3658	.2721	.3506
21	.3018	.3185	.2362	.3144
22	.2724	.3605	.2401	.322
23	.2724	.2441	.2281	.221
24	.1677	.2601	.1593	.148
Max	**.5788**	**.591**	**.3721**	**.5434**
Min	**.14**	**.136**	**.1593**	**.1143**
Avg	**.2697**	**.3607**	**.2683**	**.3318**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (E) S/DN.[579] BU 4579
Substation No/ Name :- 274068 / JULE SOLAPUR
Feeder No / Name : 201 / 11 KV MANTRI CHANDAK **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4755	.3403
2	.4755	.4938	.3258
3	.4572	.5304	.3258
4	.4938	.5601	.3658
5	.4755	.5493	.4066
6	.4854	.5487	.462
7	.5975	.5853	.6224
8	.6767	.6535	.6224
9	.5175		.5544
10	.4887		.462
11	.4706		.3881
12	.4163		.3658
13	.362		.3292
14	.3439		.2865
15			.2865
16			.3439
17	.4887	.3982	.4207
18	.6584	.4525	.5359
19	.7316	.7602	.7023
20	.7059	.7133	.6584
21	.6516	.5853	.5853
22	.5792	.4755	.4572
23	.4854	.4119	
24	.4854	.4668	.3582
Max	**.7316**	**.7602**	**.7023**
Min	**.3439**	**.3982**	**.2865**
Avg	**.5229**	**.5413**	**.4437**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (E) S/DN.[579] BU 4579
Substation No/ Name :- 274068 / JULE SOLAPUR
Feeder No / Name : 202 / 11 KV VIMANTAL **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3921	.3475	.2829
2	.3658	.3292	.2829
3	.3475	.3109	.3206
4	.3361	.3292	.3174
5	.3475	.3292	.3734
6	.3292	.3109	.4294
7	.3658		.3921
8	.3841	.4572	.3961
9	.3881		.3772
10	.3921		.3772
11	.3921		.5281
12	.3361		
13	.2743		.3395
14	.3018		
15			.3018
16			.3841
17	.3772	.3658	.4108
18	.4904	.4024	.4338
19	.5658	.547	.5281
20	.4527	.5847	.5093
21	.415	.4527	.4527
22	.415	.3772	.3772
23	.3658	.3206	
24	.3658	.3658	.2829
Max	**.5658**	**.5847**	**.5281**
Min	**.2743**	**.3109**	**.2829**
Avg	**.3818**	**.3887**	**.3856**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (E) S/DN.[579] BU 4579
Substation No/ Name :- 274068 / JULE SOLAPUR
Feeder No / Name : 203 / 11 KV SHINDU VIHAR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.6584	.5487	.5487
2	.6767	.567	.5544
3	.7282	.6401	.5914
4	.7468	.7316	.6348
5	.7577	.7682	.6722
6	.8131	.8596	.7655
7	.9145	.8962	1.0642
8	1.0059	.9145	1.0562
9	.8871		.9054
10	.8299		.8488
11	.6602		.6602
12	.6224		.5847
13	.5658		.5658
14	.5658		.5658
15			.547
16			.5415
17	.7167	.6099	.6348
18	.8962	.6653	.7655
19	1.0829	1.0349	1.0829
20	.9979	1.0164	1.0349
21	.9795	.8501	.924
22	.8686	.7316	.7762
23	.6535	.6401	
24	.6401	.5975	.567
Max	**1.0829**	**1.0349**	**1.0829**
Min	**.5658**	**.5487**	**.5415**
Avg	**.7849**	**.7545**	**.7344**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (E) S/DN.[579] BU 4579
Substation No/ Name :- 274068 / JULE SOLAPUR
Feeder No / Name : 204 / 11 KV SHIVASHAI **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2195	.2195	.1494
2	.2587	.1867	.1494
3	.2743	.2241	.1867
4	.2987		.2054
5	.2743		.2241
6	.2926		.2427
7	.2801	.2926	.2801
8	.2987	.3361	.2829
9	.2804		.2427
10	.3506		.2241
11	.2804		.181
12	.2804		.181
13	.2454		
14	.2126		.1448
15			.1132
16			.1307
17	.2303	.2743	.181
18	.2865	.3109	.2303
19	.3077	.3292	.2743
20	.2772	.3077	.2561
21	.2587	.2534	.2378
22	.2218	.2218	.2195
23	.1848	.1848	
24	.1829	.1829	.1494
Max	**.3506**	**.3361**	**.2829**
Min	**.1829**	**.1829**	**.1132**
Avg	**.2635**	**.2557**	**.2039**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (E) S/DN.[579] BU 4579
Substation No/ Name :- 274068 / JULE SOLAPUR
Feeder No / Name : 205 / 11 KV KUMATHA GAOTHAN **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3921	.3475	.2926
2	.4024	.3292	.2772
3	.4251	.3658	.2772
4	.439	.4108	.3174
5	.4938	.439	.3772
6	.5304	.4755	.4715
7	.499	.4572	.5228
8	.4805	.4755	.5121
9	.3658		.3841
10	.3841		.3439
11	.2926		.2896
12	.2926		.2534
13	.2926		.2353
14	.3142		.2303
15			.2303
16			.2658
17	.3258	.3658	.3155
18	.3681	.4207	.4334
19	.543	.5914	.543
20	.5175	.5415	.5792
21	.4805	.4668	.4706
22	.4251	.4108	.4024
23	.3292	.3734	
24	.3658	.3361	.3109
Max	**.543**	**.5914**	**.5792**
Min	**.2926**	**.3292**	**.2303**
Avg	**.4072**	**.4254**	**.3624**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (E) S/DN.[579] BU 4579
Substation No/ Name :- 274068 / JULE SOLAPUR
Feeder No / Name : 206 / 11 KV SANTOSH NAGAR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.7282		.5316
2	.695		.5258
3	.6767		.5258
4	.6584	.7282	.567
5	.6908	.7842	.6089
6	.7023	.8316	.6878
7	.7947	.9145	.8316
8	.961	.961	.9709
9	.823		.7421
10	.691		.6733
11	.6024		.5847
12	.567		.5316
13	.5609		.4961
14	.5548		.4961
15			.4961
16			.5493
17	.7796	.6379	.7011
18	1.0029	.724	.9189
19	1.182	1.1163	1.1163
20	1.134	1.1043	1.0631
21	1.0631	.9114	.929
22	.9391	.7712	.7362
23	.7468	.6516	
24	.7133		.5487
Max	**1.182**	**1.1163**	**1.1163**
Min	**.5548**	**.6379**	**.4961**
Avg	**.7849**	**.8447**	**.6883**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (E) S/DN.[579] BU 4579
Substation No/ Name :- 274068 / JULE SOLAPUR
Feeder No / Name : 207 / 11KV WATER SUPPLY NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2172	.181	.2172
2	.181	.2172	.2172
3	.2172	.2172	.2172
4	.2172	.2172	.2172
5	.2172	.2172	.2172
6	.2172	.4163	.4163
7	.2172	.4163	.4163
8	.2172	.2172	.2172
9	.2172		.2172
10	.2353		.2172
11	.2353		.2172
12	.2353		.4163
13	.4163		.2172
14	.4163		
15			.4163
16			.2172
17	.2172	.2353	.2172
18	.2172	.2172	.4163
19	.2172	.4163	.4163
20	.2172	.2172	.2172
21	.2172	.2172	.2172
22	.2172	.2172	.2172
23	.2172	.2172	
24	.2172	.181	.2172
Max	**.4163**	**.4163**	**.4163**
Min	**.181**	**.181**	**.2172**
Avg	**.2361**	**.2511**	**.2715**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (E) S/DN.[579] BU 4579
Substation No/ Name :- 274068 / JULE SOLAPUR
Feeder No / Name : 208 / 11 KV SHANTIVAN SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0949	.0949	.5218
2	.0791	.0791	.5376
3	.0949	.0949	.5693
4	.0949	.0791	.6009
5	.1107	.0949	.6325
6	.0949	.0949	.6483
7	.0949	.0949	
8	.8065	.7432	
9	.9962		
10	.9962		
11	.9488		
12	.9488		
13	.9172		.0474
14	.9172		.0474
15			.0791
16			.0949
17			.1107
18			.1265
19			.1265
20			.1107
21			.0949
22	.0949	.5693	.6009
23	.0791	.5376	
24	.0791	.0791	.506
Max	**.9962**	**.7432**	**.6483**
Min	**.0791**	**.0791**	**.0474**
Avg	**.4381**	**.2329**	**.3209**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (E) S/DN.[579] BU 4579
Substation No/ Name :- 274068 / JULE SOLAPUR
Feeder No / Name : 209 / 11 KV IMS **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.5544	.5487	.4525
2	.5975		.4344
3	.6219		.4344
4	.6722		.4887
5	.7842		.5792
6	.8962		.724
7	.9694	1.0059	.9774
8	1.0425	1.0974	1.0679
9	.7783		
10	.724		
11	.5973		
12	.543		
13	.543		
14	.4887		
17	.6878	.543	.543
18	.8507	.6154	.6878
19	.9412	.9955	.9412
20	.8869	.9412	.8326
21	.8326	.724	.724
22	.7602	.6154	.5792
23	.6036	.5068	
24	.5853	.5853	.4706
Max	**1.0425**	**1.0974**	**1.0679**
Min	**.4887**	**.5068**	**.4344**
Avg	**.7255**	**.7435**	**.6625**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (E) S/DN.[579] BU 4579
Substation No/ Name :- 274068 / JULE SOLAPUR
Feeder No / Name : 210 / 11 KV BOMBAY PARK **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4572	.5281	.3761
2	.4854	.5487	.3582
3	.5228	.567	.3582
4	.5415	.6535	.394
5	.5788	.7133	.4477
6	.5853	.7316	.5373
7	.7316	.8413	.7343
8	.7842	.9149	.788
9	.5121		
10	.4572		
11	.4755		
12	.4024		
13	.3841		
14	.3841		
17	.4755	.4119	.4119
18	.695	.5014	.591
19	.7682	.7343	.7343
20	.7499	.6984	.6984
21	.695	.5731	.5731
22	.6401	.5014	.5014
23	.4938	.4477	
24	.4755	.4755	.394
Max	**.7842**	**.9149**	**.788**
Min	**.3841**	**.4119**	**.3582**
Avg	**.5589**	**.6151**	**.5265**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (E) S/DN.[579] BU 4579
Substation No/ Name :- 274068 / JULE SOLAPUR
Feeder No / Name : 211 / 11 KV NEHARU NAGAR **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4755	.4481	.439
2	.5041	.4572	.4207
3	.5415	.4755	.4207
4	.5975	.5487	.4572
5	.6401	.6036	.4938
6	.7095	.6767	.567
7	.6767	.6722	.6584
8	.695	.6767	.7133
9	.5847		
10	.5316		
11	.4961		
12	.4607		
13	.4252		
14	.4252		
17	.5316	.4938	.4755
18	.691	.5487	.6584
19	.7442	.8048	.7682
20	.7087	.7682	.7133
21	.6733	.695	.6584
22	.6024	.5853	.5853
23	.4938	.5121	
24	.5228	.4572	.4572
Max	**.7442**	**.8048**	**.7682**
Min	**.4252**	**.4481**	**.4207**
Avg	**.5787**	**.5890**	**.5658**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (E) S/DN.[579] BU 4579
Substation No/ Name :- 274122 / PAPER PLANT
Feeder No / Name : 202 / 11 KV SHANKAR NAGAR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7468	.7095	.6908	.6535
2		.7282	.6908	.6722	.6161
3		.7282	.6908	.6161	.6161
4		.7095	.6908	.6348	.6161
5		.8589	.8215	.7282	.6535
6		1.0456	1.0829	.9522	.9149
7		1.2136	1.4003	1.2136	1.1389
8		1.1576	1.363	1.1949	1.1576
9		1.0829	1.1949	1.0269	1.1389
10		.9522	.9896	.9149	.9335
11		.9335	.9335	.8215	.8962
12	.9522	.8589	.9149	.3734	.8215
13		.7842	.8962	.8962	.8029
14		.7842	.8402	.7468	.7655
15		.8029	.8589	.6348	.7842
16		.8029	.8402	.7468	.7842
17		.8215	.8775	.8215	.8589
18		1.2883	1.4003	1.251	1.1949
19		1.4563	1.5123	1.3256	1.5123
20		1.4003	1.5123	1.419	1.5123
21		1.363	1.419	1.3443	1.2696
22		1.1763	1.0456	1.1389	1.1016
23		.9522	.9335	.8962	.8962
24		.8589	.8029	.7655	.7655
Max	**.9522**	**1.4563**	**1.5123**	**1.419**	**1.5123**
Min	**.9522**	**.7095**	**.6908**	**.3734**	**.6161**
Avg	**.9522**	**.9795**	**1.0176**	**.9094**	**.9335**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (E) S/DN.[579] BU 4579
Substation No/ Name :- 274122 / PAPER PLANT
Feeder No / Name : 203 / 11 KV SHIDDHESHWAR SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0747	.056	.0747
2	.056	.0747	.056	.056
3	.0747	.0747	.056	.056
4	.0747	.0747	.0747	.056
5	.0747	.0934	.0747	.0747
6	.0934	.0934	.112	.0934
7	.0934	.0934	.0934	.0934
8	.0934	.0934	.0747	.0934
9	.0934	.0934	.0747	.0934
10	.0934	.0934	.0747	.112
11	.0934	.1494	.0747	.0934
12	.0934	.0934	.0934	.0934
13	.0934	.0934	.0934	.0934
14	.0934	.168	.0934	.0934
15	.0934	.1494	.0934	.0934
16	.0934	.1494	.0934	.0934
17	.0934	.0934	.0934	.0934
18	.0934	.0934	.0934	.0934
19	.0934	.0934	.0934	.0934
20	.0934	.0934	.0934	.0934
21	.0934	.0747	.0934	.0934
22	.0934	.0747	.0934	.0747
23	.0934	.056	.0934	.056
24	.0747	.0934	.056	.0934
Max	**.0934**	**.168**	**.112**	**.112**
Min	**.056**	**.056**	**.056**	**.056**
Avg	**.0872**	**.0973**	**.0833**	**.0856**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (E) S/DN.[579] BU 4579
Substation No/ Name :- 274122 / PAPER PLANT
Feeder No / Name : 204 / 11 KV SWAGAT NAGAR **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9511	.9328	.823	.6219
2	.9328	.9145	.7682	.6161
3	.8962	.7865	.7316	.6161
4	.8779	.8596	.7316	.6535
5	.9328	.9145	.8413	.7468
6	1.262	1.262	1.134	1.0242
7	1.5181	1.4449	1.3352	1.2803
8	1.6461	1.6278	1.3717	1.5364
9	1.5364	1.5546	1.0974	1.4632
10	1.5181	1.5546	.9877	1.4083
11	1.4266	1.39	.8962	1.4083
12	1.4083	1.4815	.7499	1.3352
13	1.1888	1.2803	.7316	1.0425
14	1.1157	1.2254	.7316	1.0974
15	1.2803	1.4266	.8048	1.1888
16	1.3169	1.3169	.7682	1.2254
17	1.3535	1.5546	.7499	1.4815
18	1.7741	1.9022	1.2437	1.5729
19	1.7741	1.9753	1.5181	1.957
20	1.8656	1.8839	1.4449	1.8473
21	1.6827	1.6461	1.4632	1.5729
22	1.4449	1.3535	1.2071	1.3352
23	1.1888	1.0608	.8779	1.0242
24	1.0059	1.0242	.8779	.7133
Max	**1.8656**	**1.9753**	**1.5181**	**1.957**
Min	**.8779**	**.7865**	**.7316**	**.6161**
Avg	**1.3291**	**1.3489**	**.9953**	**1.1987**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (E) S/DN.[579] BU 4579
Substation No/ Name :- 274122 / PAPER PLANT
Feeder No / Name : 205 / 11 kv Hatture Nager **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1829	.1646	.1646
2	.2012	.1829	.1646	.1646
3	.1829	.1829	.1646	.1646
4	.1829	.1829	.1646	.1646
5	.2378	.2378	.1829	.1829
6	.2743	.3475	.2561	.2378
7	.3475	.439	.3658	.3109
8	.3109	.3475	.3841	.3292
9	.2561	.4207	.2743	.2561
10	.2195	.3658	.2195	.2195
11	.2012	.3475	.1829	.2012
12	.2012	.2926	.1646	.1829
13	.1829	.2743	.1646	.1646
14	.1829	.2378	.1829	.1646
15	.2012	.2012	.1829	.1646
16	.1463	.2012	.1646	.1829
17	.2378	.2195	.2012	.2195
18	.2926	.4024	.3109	.3658
19	.4024	.4207	.3475	.3841
20	.3475	.3292	.3841	.3841
21	.3109	.3292	.3109	.3292
22	.2743	.2561	.2743	.2378
23	.1829	.1829	.7316	.1829
24	.1829	.1829	.1646	.1646
Max	**.4024**	**.439**	**.7316**	**.3841**
Min	**.1463**	**.1829**	**.1646**	**.1646**
Avg	**.2417**	**.2820**	**.2545**	**.2302**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (E) S/DN.[579] BU 4579
Substation No/ Name :- 274122 / PAPER PLANT
Feeder No / Name : 403 / 33 KV KIRLOSKAR NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	7.0016	5.9414	5.4893	5.7133
2	6.3855	6.2243	6.1614	5.3212
3	5.7133	7.9218	6.1054	2.9127
4	5.3212	7.9218	4.313	6.1614
5	6.6095	3.9609	4.6491	2.0725
6	6.6095	3.678	3.4728	4.7611
7	3.2487	3.5648	2.5206	3.5848
8	7.6178	5.3189	1.0082	2.9127
9	8.514	6.5535	1.1203	7.3937
10	6.1614	7.1696		6.6095
11	4.7051	6.7215	1.6804	6.5535
12	6.4975	6.7215	.8402	5.4332
13	6.6655	6.3855	.8962	2.9127
14	8.57	6.5535	.8962	8.1779
15	8.682	6.5535	.6161	5.6573
16	3.6408	4.9851	1.0082	8.4019
17	5.998	3.9209	.9619	8.738
18	8.8838	4.0889	1.4712	2.6886
19	4.2438	6.8336	.9619	6.6095
20	7.356	3.7529	2.1502	5.1532
21	5.998	6.3295	1.0751	6.1054
22	5.8282	5.6573	2.8292	5.0412
23	8.714	6.8896	2.7726	5.6013
24	2.4086	3.4517	3.0247	1.6244
Max	**8.8838**	**7.9218**	**6.1614**	**8.738**
Min	**2.4086**	**3.4517**	**.6161**	**1.6244**
Avg	**6.3072**	**5.7125**	**2.4358**	**5.2559**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (E) S/DN.[579] BU 4579
Substation No/ Name :- 274122 / PAPER PLANT
Feeder No / Name : 404 / 33 KV HOTGI **SHEDDABLE RURAL**
Feeder KV- 33 / INCOMING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	1.6461	2.2119	2.3148
2	1.5947	1.5947	2.3663	2.4177
3	1.6461	1.6975	2.4177	2.5206
4	1.6975	1.8519	2.572	
5	1.9547	2.0576	2.8807	3.1893
6	2.1091	2.3148	3.3436	2.9835
7	3.4465	3.0864	4.0124	3.3951
8	1.1831	1.0288	1.1831	1.0288
9	.9774	1.9547	.5144	1.9033
10		3.2407	.6173	2.6749
11	3.2922	3.1893	.5144	2.8807
12	1.3889	3.3951	.463	1.8519
13	2.4691	3.1893	.4115	2.572
14	3.4465	1.9033		2.572
15	3.1893	3.4465		2.572
16	2.9321	3.3436		2.1605
17	2.9321	.9259		3.5494
18	.8745	.9259	2.5206	.7716
19	1.0288	1.0288	1.1317	.9774
20	1.0288	1.0288	1.1317	1.0802
21	.9774	.9259	1.0802	1.6975
22	1.6975	2.2634	2.4691	2.4177
23	1.8004	2.1605	2.4177	2.2119
24	1.749	1.8004	2.1605	2.3663
Max	**3.4465**	**3.4465**	**4.0124**	**3.5494**
Min	**.8745**	**.9259**	**.4115**	**.7716**
Avg	**1.9547**	**2.0833**	**1.8210**	**2.2656**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (E) S/DN.[579] BU 4579
Substation No/ Name :- 274184 / 33/11 KV I.T.I SUB STATION
Feeder No / Name : 201 / 11 KV FURDE **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3366	.3189			.2481
2		.3189	.3189			.2303
3		.3189	.3189			.2303
4		.3189	.3544			.2303
5		.3189	.3544			.2303
6		.3189				.3012
7		.3721	.4075			.362
8		.3544	.443			.3801
9		.3189	.4075	.3366		.3189
10		.3012	.3012	.3189	.3439	.3012
11		.2658	.3012	.3012	.2715	.2534
12		.2481	.3258	.2303	.2534	.2303
13		.2481	.2658	.2481	.2896	.2353
14		.2126	.2658	.2481	.2896	.2353
15			.2835	.2353	.2835	.2303
16		.2303	.2835	.2481	.2835	.3077
17		.2303				.2534
18		.3544				
19		.443				
20		.4075				
21		.3721				
22		.3544				
23		.3544		.3189		
24	.3189	.3366	.3366	.2303	.2896	.2481
Max	**.3189**	**.443**	**.443**	**.3366**	**.3439**	**.3801**
Min	**.3189**	**.2126**	**.2658**	**.2303**	**.2534**	**.2303**
Avg	**.3189**	**.3189**	**.3304**	**.2716**	**.2881**	**.2681**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (E) S/DN.[579] BU 4579
Substation No/ Name :- 274184 / 33/11 KV I.T.I SUB STATION
Feeder No / Name : 202 / 11 KV INDIRA NAGAR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2835	.2481			.1772
2		.2658	.2481			.181
3		.2658	.2303			.1772
4		.2658	.2303			.181
5		.2658	.2481			.1772
6		.2658				.2303
7	.3189	.3012	.3012			.2896
8	.3189	.3189	.3012			.3077
9	.3012	.3012	.3012	.3012	.3982	.2835
10		.2835	.2835	.2896	.2353	.2481
11		.2303	.2835	.2715	.2353	.2534
12		.2303	.2172	.2715	.181	.1949
13		.2481	.2353	.2715	.197	.2715
14		.2126	.2303	.2534	.181	.2172
15		.2303	.1991	.2534	.1772	.1991
16		.2303	.1991	.2481	.1595	.2353
17		.2303				.2534
18		.3189				
19		.3898				
20		.3544				
21		.3366				
22		.3012				
23		.2835		.2481		
24		.3012	.2658	.1949	.2353	.1772
Max	**.3189**	**.3898**	**.3012**	**.3012**	**.3982**	**.3077**
Min	**.3012**	**.2126**	**.1991**	**.1949**	**.1595**	**.1772**
Avg	**.313**	**.2798**	**.2514**	**.2603**	**.2222**	**.2253**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (E) S/DN.[579] BU 4579
Substation No/ Name :- 274184 / 33/11 KV I.T.I SUB STATION
Feeder No / Name : 203 / 11 KV VIJAPUR NAKA SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1949	.1772			.1417
2	.1772	.1772			.1448
3	.1772	.1772			.1417
4	.1772	.1595			.1448
5	.1772	.1595			.1417
6	.1772	.1772			.2353
7	.1949	.1949			.2353
8	.2303	.1949			.2303
9	.2303	.1949	.2534	.2715	.2353
10	.2303	.1949	.2353	.2172	.2303
11	.2126	.2126	.2353	.2172	.2172
12	.2126	.1949	.2126	.1991	.1991
13	.2303	.1991	.2172	.2172	.2172
14	.1949	.1991	.2126	.1991	.1991
15	.1772	.181	.1991	.1772	.181
16	.1772	.181	.2172	.1629	.181
17	.1772				.181
18	.2303				
19	.2835				
20	.2658				
21	.2481				
22	.2303				
23	.2126		.1991		
24	.2126	.1949	.1448	.181	.1417
Max	**.2835**	**.2126**	**.2534**	**.2715**	**.2353**
Min	**.1772**	**.1595**	**.1448**	**.1629**	**.1417**
Avg	**.2097**	**.1865**	**.2127**	**.2047**	**.1888**

Date:- 04-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (E) S/DN.[579] BU 4579
Substation No/ Name :- 274184 / 33/11 KV I.T.I SUB STATION
Feeder No / Name : 204 / 11 KV ITI NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)
8		.0183
9	.0543	.0181
10	.0362	.0183
11	.0181	
14	.0181	
15	.0181	.0181
16	.0181	.0181
17		.0181
Max	**.0543**	**.0183**
Min	**.0181**	**.0181**
Avg	**.0272**	**.0182**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

BARAMATI ZONE[052]
SOLAPUR CIRCLE[530]
SOLAPUR URBAN DIVISION[131]
SOLAPUR (E) S/DN.[579] BU 4579
Substation No/ Name :- 274184 / 33/11 KV I.T.I SUB STATION
Feeder No / Name : 205 / 11 KV RAMLING NAGAR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.124	.124			.1086
2	.1063	.1063			.1086
3	.1063	.1063			.1086
4	.1063	.1063			.1086
5	.124	.124			.1086
6	.1063	.1417			.1267
7	.124	.1417			.1629
8	.1595	.1772			.181
9	.1772	.1417	.1448	.1448	.1448
10	.1949	.1595	.1629	.1629	.1629
11	.1417	.1417	.1448	.1595	.1448
12	.124	.1267	.1267	.1267	.1086
13	.124	.1267	.1267	.1267	.1063
14		.1267	.1267	.1086	.1086
15		.1267	.1267	.1086	.1086
16	.1417	.1267	.1267	.1086	.1086
17	.1417				.1267
18	.1595				
19	.1772				
20	.1772				
21	.1772				
22	.1772				
23	.1595		.1629		
24	.1417	.1417	.1086	.1629	.1086
Max	**.1949**	**.1772**	**.1629**	**.1629**	**.181**
Min	**.1063**	**.1063**	**.1086**	**.1086**	**.1063**
Avg	**.1442**	**.1321**	**.1358**	**.1344**	**.1246**