

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113015 / LOKPRIYA

Feeder No / Name : 201 / RACHANA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4525	.543	.5792	.6154	.4525	.543	.4525
2	.4525	.4706	.543	.543	.4525	.5068	.4525
3	.4525	.4706	.5068	.543	.362	.5068	.362
4	.543	.4525	.5068	.5249	.362	.4706	.362
5	.543	.4887	.5611	.5249	.362	.4706	.362
6	.543	.5973	.6154	.5611	.4525	.4706	.4525
7	.543		.5973	.6154	.543	.5249	.4525
8	.6335	.6516	.6697	.5792	.6335	.5973	.6335
9	.5973	.6154	.6516	.724	.6516	.543	.5792
10	.5792	.543	.543	.6335	.5792	.5487	.5973
11	.4887	.5611	.5611	.6335	.5611	.543	.543
12	.5068	.5068	.4706	.543	.5068	.543	.4706
13	.4344	.4706	.4887	.543	.5068	.543	.4887
14	.4706	.4706	.4706	.4525	.4706	.4525	.4706
15	.3982	.4525	.4344	.4525	.4344	.4525	.4163
16	.3982	.4163	.4163	.4525	.4163	.4525	.4163
17	.4344	.4525	.4344	.4525	.4525	.4525	.4163
18		.5068	.5249	.4525	.4887	.543	.4525
19	.5611	.6154	.6154	.543	.5973	.6335	.5792
20	.6878	.6878	.6878	.6335	.6335	.6335	.6154
21	.7421	.7059	.7059	.6335	.6335	.6335	.6335
22	.7059	.7421	.724	.6335	.6335	.6335	.6154
23	.6878	.6878	.6878	.6335	.6154	.6335	.5973
24	.543	.6154	.6154	.6335	.543	.5792	.543
Max	.7421	.7421	.724	.724	.6516	.6335	.6335
Min	.3982	.4163	.4163	.4525	.362	.4525	.362
Avg	.5391	.5532	.5671	.5649	.5143	.5380	.4985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113015 / LOKPRIYA

Feeder No / Name : 202 / UDAYSHREE FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.3077	.2957	.3077	.3109	.3077	.3658
2	.2743	.2534	.3142	.2715	.2743	.2534	.3292
3	.2195	.2534	.3077	.2715	.2715	.2534	.3292
4	.2195	.2534	.2587	.2715	.2743	.2534	.2926
5	.2195	.2534	.2587	.2715	.2561	.2534	.2926
6	.2743	.2715	.2715	.2715	.2561	.2534	.2743
7	.2743		.3511	.2957	.2561	.2534	.2743
8	.3109	.3258	.2957	.3326	.2743	.2896	.2926
9	.2896	.2957	.3326	.3658	.3077	.2926	.3077
10	.2715	.2772	.2957	.3109	.3439	.2926	.2896
11	.2534	.2587	.2587	.2926	.2896	.2743	.2715
12	.2534	.2402	.2772	.2926	.2715	.2926	.2534
13	.2353	.2587	.2587	.2743	.2534	.2561	.2353
14	.2353	.2587	.2957	.2743	.2534	.2561	.2172
15	.2353	.2402	.2353	.2561	.2534	.2378	.2172
16	.2353	.2402	.2353	.2402	.2534	.2561	.2172
17	.2353	.2402	.2772	.2378	.2353	.2378	.2172
18		.2587	.2534	.2926	.2715	.2561	.2715
19	.2896	.3142	.3077	.3658	.3258	.3475	.3258
20	.362	.3881	.362	.3658	.362	.3658	.3439
21	.3439	.3881	.3982	.3658	.362	.3658	.3258
22	.3982	.3881	.3881	.3658	.3801	.3841	.3258
23	.3982	.4066	.4251	.3292	.362	.3658	.3258
24	.2561	.3258	.3326	.362	.3109	.3258	.3658
Max	.3982	.4066	.4251	.3658	.3801	.3841	.3658
Min	.2195	.2402	.2353	.2378	.2353	.2378	.2172
Avg	.2765	.2912	.3036	.3035	.2921	.2885	.2901

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113015 / LOKPRIYA

Feeder No / Name : 204 / DAV COLLEGE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5544	.543	.9425	.8326	.6468	.8145	.8316
2	.5544	.5068	.8686	.727	.6468	.7783	.8316
3	.6468	.5068	.8131	.724	.5544	.7421	.7392
4	.6468	.5068	.7762	.6899	.5544	.7421	.7392
5	.6468	.543	.7392	.6878	.5544	.724	.6468
6	.7392	.5611	.7577	.6878	.6468	.724	.6468
7	.7392		.7762	.7602	.6468	.724	.7392
8	.7392	.724	.8131	.7602	.6468	.7964	.924
9	.6878	.7762	.9955	1.0164	.9231	.924	1.0498
10	.7059	.8131	1.0136	1.0164	.9412	.924	1.1041
11	.6878	.7207	.9593	.924	.9955	1.0164	.8507
12	.7421	.6838	.905	.8316	.8869	1.0164	.9955
13	.7059	.6283	.8326	.8316	.8145	1.0164	.905
14	.6154	.6283	.7602	.7392	.724	.924	.8326
15	.5611	.5487	.8145	.7392	.7964	.924	.7964
16	.5792	.6283	.7964	.6468	.6878	.7392	.7602
17	.5973	.6099	.7964	.7392	.8869	.8316	.8507
18	.5973	.9979	.7783	.7392	.8688	.924	.3801
19	.724	1.1458	1.0317	.924	1.1222	1.1088	1.1041
20	.7964	1.2382	1.0498	.924	1.086	1.2012	1.0679
21	.8145	1.2752	1.0498	.924	1.0679	1.2012	1.086
22	.7964	1.2567	.9955	.8316	1.0317	1.1088	.9774
23	.7421	1.0534	.9774	.8316	1.0136	1.0164	.9774
24	.5544	.6335	.9795	.9471	.7392	.8869	.924
Max	.8145	1.2752	1.0498	1.0164	1.1222	1.2012	1.1041
Min	.5544	.5068	.7392	.6468	.5544	.724	.3801
Avg	.6739	.7622	.8843	.8115	.8118	.9087	.8650

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113015 / LOKPRIYA

Feeder No / Name : 205 / 11kV SARVAMANGAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.3258	.3439	.362	.3658	.3439	.3658
2	.2743	.1448	.3258	.3258	.3292	.3077	.3658
3	.2743	.3077	.3077	.3258	.3292	.3077	.3292
4	.2926	.3077	.3077	.3258	.2926	.2896	.3292
5	.2926	.3077	.3077	.3077	.2926	.2896	.3292
6	.3109	.3077	.3326	.3077	.2743	.2896	.3109
7	.3109	.3801	.362	.3077	.2743	.2896	.3109
8	.3292	.3801	.3982	.362	.2957	.2896	.3658
9	.3258	.3801	.3801	.4024	.362	.3658	.3982
10	.3801	.4163	.3439	.3658	.3982	.3658	.3982
11	.3258	.3077	.3258	.3658	.3982	.3658	.3801
12	.3801	.362	.3734	.3292	.3801	.4024	.3982
13	.3077	.3258	.3258	.3109	.3439	.3292	.3077
14	.362	.3258	.3439	.2926	.362	.3658	.3439
15	.3258	.3077	.2896	.2743	.3258	.3658	.2896
16	.2715	.2896	.3077	.2561	.2534	.2743	.2534
17	.3439	.3258	.3439	.2743	.2715	.3109	.3077
18	.3258	.362	.362	.3109	.3258	.3658	.3258
19	.3801	.3801	.3982	.3658	.3801	.3658	.3801
20	.4706	.4887	.4163	.4572	.4344	.4024	.4163
21	.5068	.4525	.4706	.3658	.4344	.4572	.4163
22	.4525	.4344	.4525	.3658	.4163	.3658	.3982
23	.3982	.4163	.4525	.3841	.4163	.3841	.362
24	.3109	.3439	.3801	.3982	.3658	.362	.3841
Max	.5068	.4887	.4706	.4572	.4344	.4572	.4163
Min	.2715	.1448	.2896	.2561	.2534	.2743	.2534
Avg	.3466	.3492	.3605	.3393	.3467	.3440	.3528

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113015 / LOKPRIYA

Feeder No / Name : 206 / RCF

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.905	1.0136	1.0317	1.1041	.905	1.0679	1.086
2	.905	.8869	.9955	1.0189	.905	.9593	1.086
3	.905	.8869	.9593	1.0136	.8145	.9412	.9955
4	.9955	.8869	1.0136	.9774	.8145	.8869	.9955
5	.9955	.9593	1.0679	.9774	.905	.9412	.9955
6	1.086	1.0136	1.1041	1.0498	.905	.9593	1.086
7	1.086	1.0317	1.1403	.9955	.9955	.9412	1.086
8	1.086	1.1403	1.1946	1.0498	.9955	.905	1.1765
9	1.0136	1.0679	1.0679	1.086	.9955	1.086	1.086
10	1.0136	1.0317	1.0498	1.1765	1.1222	1.086	1.1222
11	.9412	.8869	.9231	1.1765	1.0679	1.086	1.0498
12	.8688	.7783	1.0136	.9955	.9412	.9955	.8507
13	.7964	.8145	.8145	.905	.8688	.9955	.8145
14	.7964	.7421	.8145	.905	.8326	.905	.7964
15	.7421	.7059	.7421	.8145	.7964	.8145	.7602
16	.6335	.724	.7602	.7316	.7783	.8145	.7059
17	.7059	.724	.7783	.724	.7602	.8145	.6878
18	.7783	.7602	.8688	.905	.8326	.905	.8145
19	.9593	.9955	1.0136	1.086	.9955	1.086	1.0136
20	1.1041	1.1222	1.2308	1.1765	1.1584	1.1765	1.1584
21	1.1765	1.2308	1.275	1.086	1.1041	1.9805	1.1765
22	1.1946	1.2308	1.267	1.086	1.1584	1.1765	1.1765
23	.6154	1.2308	1.267	1.086	1.1765	1.1765	1.1222
24	.905	1.086	1.1041	1.2308	.9955	1.1584	1.1765
Max	1.1946	1.2308	1.275	1.2308	1.1765	1.9805	1.1765
Min	.6154	.7059	.7421	.724	.7602	.8145	.6878
Avg	.9254	.9563	1.0207	1.0149	.9510	1.0358	1.0008

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113015 / LOKPRIYA

Feeder No / Name : 207 / Lokpriya S/Stn

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0943	.0953	.0943	.0953	.0943	.0953
2	.0953	.0905	.0953	.0905	.0953	.0943	.0953
3	.0953	.0905	.0953	.0943	.0953	.0943	.0953
4	.0953	.0943	.0953	.0943	.0953	.0943	.0953
5	.0953	.0943	.0953	.0943	.0953	.0943	.0953
6	.0953	.0943	.0953	.0943	.0953	.0943	.0953
7	.0953		.0953	.0905	.0953	.0943	.0953
8	.0953	.0943	.0953	.0943	.0953	.0943	.0953
9	.0943	.0953	.0943	.0953	.0943	.0953	.0943
10	.0943	.0953	.0943	.0953	.0943	.0953	.0943
11	.0943	.0953	.0943	.0953	.0943	.0953	.0943
12	.0943	.0953	.0943	.0953	.0943	.0953	.0943
13	.0943		.0905	.0953	.0943	.0953	.0943
14	.0943	.0953	.0943	.0953	.0905	.0953	.0943
15	.0943	.0953	.0943	.0953	.0943	.0953	.0943
16	.0943	.0953	.0943	.0953	.0943	.0953	.0943
17	.0943	.0953	.0943	.0953	.0943	.0953	.0943
18	.0943	.0953	.0943	.0953	.0943		.0943
19	.0943	.0953	.0905	.0953	.0943	.0953	.0943
20	.0943	.0953	.0943	.0953	.0943	.0953	.0943
21	.0943	.0953	.0943	.0953	.0943	.0953	.0943
22	.0943	.0953	1.0562	.0953	.0943	.0953	.0943
23	.0943	.0953	.0943	.0953	.0943	.0953	.0943
24	.0953	.0943	.0953	.0943	.0953	.0943	.0953
Max	.0953	.0953	1.0562	.0953	.0953	.0953	.0953
Min	.0943	.0905	.0905	.0905	.0905	.0943	.0943
Avg	.0947	.0946	.1344	.0946	.0945	.0949	.0947

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113015 / LOKPRIYA

Feeder No / Name : 208 / Bhandup Station

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.905	1.086	1.1222	1.1222	1.086	1.0136	.9955
2	.905	.9231	1.086	1.0498	1.086	.9231	.9955
3	.905	.9231	1.0317	.9774	.9955	.905	.905
4	.9955	.9231	.9593	.9774	.9955	.8688	.905
5	.9955	.9412	.905	.9774	.9955	.905	.8145
6	1.086	.9955	.9774	.9593	.905	.905	.8145
7	1.086	1.1584	1.1222	.9593	.905	.905	.905
8	1.086	1.2851	1.1765	1.0498	.9955	.9231	1.086
9	1.086	1.267	1.1765	1.0974	1.0498	.9955	1.1222
10	.9231	1.1403	1.1222	1.086	1.0498	1.086	1.086
11	1.0679	1.0498		1.1765	1.0679	1.086	1.0136
12	1.0317	1.086	1.0136	1.6289	.9593	.9955	1.0136
13	1.0136	.9774	.9774	.9955	.9412	.9955	1.0317
14	.9231	.9231	.9471	.905	.8688	.905	.905
15	.8326	.8869	.905	.8145	.8688	.905	.8688
16	.8145	.8573	.8688	.724	.8145	.8145	.7964
17	.8507	1.3937	.905	.8145	.7783	.8145	.7964
18	.905	.9774	.9593	.9145	.9231	.8145	.8507
19	1.1403	1.1946	1.2308	1.1765	1.1222	1.1765	1.1584
20	1.3032	1.3213	1.3213	1.1765	1.2308	1.1765	1.2308
21	1.3213	1.3756	1.3213	1.1765	1.2308	1.267	1.2127
22	1.3394	1.3575	1.3575	1.1765	1.1765	1.267	1.1946
23		1.3032	1.3032	1.1765	1.1765	1.267	1.1584
24	.9955	1.1584	1.1946	1.2127	1.086	1.1041	1.086
Max	1.3394	1.3937	1.3575	1.6289	1.2308	1.267	1.2308
Min	.8145	.8573	.8688	.724	.7783	.8145	.7964
Avg	1.0223	1.1044	1.0863	1.0552	1.0128	1.0008	.9978

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113015 / LOKPRIYA

Feeder No / Name : 209 / Bhandupeshwar Kund

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4715	.5658	1.6409	1.7541	1.6975	1.5278	1.6032
2	.4715	.5093	1.5844	1.5466	1.6975	1.4146	1.6032
3	.3772	.5093	1.5278	1.5089	1.6032	1.358	1.5089
4	.3772	.5093	1.4523	1.5211	1.5384	1.3203	1.5089
5	.3772	.5281	1.4523	1.5089	1.5089	1.358	1.4146
6	.4715	.5281	1.5089	1.5089	1.5089	1.3769	1.4146
7	.4715	.5093	1.5089	1.5466	1.4146	1.4146	1.4146
8	.4715	.4904	1.5655	1.5203	1.4146	1.3957	1.5089
9	.4904	.4715	1.5655	1.6975	1.5844	1.5089	1.4146
10	.4527	.4338	1.6409	1.7918	1.7164	1.6032	1.4712
11	.4527	.4338	1.647	1.6975	1.6975	1.6032	1.4712
12	.4715	.4715	1.6598	1.6975	1.6409	1.6032	1.358
13	.4715	.4527	1.6032	1.5089	1.6032	1.5089	.547
14	.4715	.4527	1.4523	1.5089	1.5089	1.5089	1.2071
15	.4527	.4527	1.4299	1.4146	1.4712	1.4146	1.3014
16	.4338	.3961	1.4712	1.3203	1.4523	1.4146	1.1506
17	.4338	.415	1.4661	1.3203	1.4523	1.4146	1.2071
18	.4338	1.4712	1.4661	1.5089	1.4523	1.6032	1.3014
19	.5093	1.6787	1.8296	1.7918	1.6975	1.7918	1.6598
20	.6036	1.8484	1.9993	1.9805	1.9427	1.9805	1.9239
21	.6224	1.9427	2.0748	1.9805	1.9427	1.9805	1.905
22	.679	1.9616	2.0936	1.9805	1.9427	1.9004	1.773
23	1.267	1.8861	2.0182	1.8861	1.8673	1.8861	1.7918
24	.5658	.5847	1.7164	1.8673	1.6975	1.6787	1.6975
Max	1.267	1.9616	2.0936	1.9805	1.9427	1.9805	1.9239
Min	.3772	.3961	1.4299	1.3203	1.4146	1.3203	.547
Avg	.5125	.8126	1.6406	1.6403	1.6272	1.5653	1.4649

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113016 / AMFORGE

Feeder No / Name : 201 / Mahavir-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2401	.2572	.2743	.2858	.2229	.2401
2	.1886		.2229	.2572	.2858	.2401	.2229
3	.2058		.2058	.2401		.2401	.2058
4	.2058	.2401	.2058	.2401		.2401	.1886
5	.2058		.2229	.2572		.2401	.1886
6	.2401	.2401	.2572	.2572	.2667	.2401	.2058
7	.3601	.3258	.3429	.2743	.3048	.3086	.2572
8	.3429	.3772	.3086	.3258	.3048	.2915	.3429
9	.2915	.3772	.2915	.3601	.3086	.3258	.3429
10	.3429	.3429	.2915		.3086	.3772	.3601
11	.2572	.2572	.2572		.3429	.3429	.2915
12	.2058	.1886	.2229	.3048	.2743	.2401	.3086
13	.2572	.2058	.2572		.3086	.2743	.2229
14	.2058	.1886	.2401	.2286	.2058	.2743	.2058
15		.1886	.2058		.2229	.2229	
16		.1886	.1886	.2477	.2229	.2229	.1886
17	.1715	.1543	.1886		.2058	.2229	.1543
18	.1886	.1886	.2058	.2286	.2058	.2572	.1886
19	.2229	.2743	.2401		.2229	.3086	.2572
20	.2743	.2743	.2743	.2858	.2915	.2915	.2915
21	.2915	.2915	.2915	.2858	.2572	.2915	.2572
22	.2743	.3429	.3086	.2858	.2743	.2572	.2572
23	.2743	.2743	.3086		.2401	.2915	.2401
24	.2229	.2572	.2743	.3086	.2858	.2572	.2915
Max	.3601	.3772	.3429	.3601	.3429	.3772	.3601
Min	.1715	.1543	.1886	.2286	.2058	.2229	.1543
Avg	.2486	.2580	.2529	.2742	.2679	.2701	.2483

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113016 / AMFORGE

Feeder No / Name : 202 / ANGEL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1372	.1372	.1372	.1524	.1372	.1372
2	.1372		.1372	.1372	.1524	.1372	.1372
3	.1372		.1372	.1372		.1372	.1372
4	.1372	.1372	.1372	.1372		.1372	.1372
5	.1372	.1372	.1372	.1372		.1372	.1372
6	.1372	.1372	.1372	.1372	.1524	.1372	.1372
7	.1372	.1372	.1372	.1372	.1524	.1372	.1372
8	.1372	.1715	.1372	.1543	.1524	.1372	.1372
9	.1372	.1372	.1372	.1372	.1372	.1372	.1372
10	.1372	.1372	.1372		.1372	.1543	.1372
11	.1372	.1372	.1543		.1372	.1372	.1543
12	.1372	.1372	.1372	.1524	.1372	.1372	.1372
13	.1372	.1372	.1372		.1372	.1372	.1372
14	.1372	.1372	.1372	.1524	.1372	.1372	.1372
15		.1372	.1372		.1372	.1372	
16		.1372	.1372	.1524	.1372	.1372	.1372
17	.1372	.1372	.1372		.1372	.1372	.1372
18	.1372	.1372	.1372	.1524	.1372	.1543	.1372
19	.1372	.1543	.1372		.1372	.1715	.1543
20	.1372	.1543	.1372	.1524	.1372	.1543	.1543
21	.1372		.1715	.1524	.1372	.1543	.1543
22	.1372	.1543	.1543	.1524	.1372	.1543	.1372
23	.1372	.1372	.1372		.1543	.1372	.1372
24	.1372	.1372		.1372	.1524	.1372	.1372
Max	.1372	.1715	.1715	.1543	.1543	.1715	.1543
Min	.1372	.1372	.1372	.1372	.1372	.1372	.1372
Avg	.1372	.1413	.1402	.1445	.1424	.1422	.1402

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113016 / AMFORGE

Feeder No / Name : 204 / J BHARAT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2517	1.406	1.4232	1.5947	1.6004	1.5432	1.5089
2	1.1488		1.4232	1.5261		1.4232	1.406
3	1.1488		1.406	1.4746		1.3203	1.3375
4	1.1145	1.2346	1.3717	1.4232		1.3032	1.286
5	1.8004	1.2689	1.4232	1.4232		1.3546	1.3203
6	1.7147	1.4746	1.4746	1.4575	1.5242	1.3717	1.4232
7	1.8861	1.6118	1.5775	1.4575	1.5242	1.3203	1.4403
8	2.0233	1.7833	1.7318	1.5775	1.6004	1.406	1.5261
9	1.989	1.6975	1.7147	1.6289	1.5432	1.5432	1.5775
10	2.0919	1.6289	1.5775		1.6289	1.6461	1.6632
11	2.0062	1.6289	1.5089		1.5089	1.5947	1.5089
12	1.9719	1.5432	1.4918	1.7147	1.5089	1.5604	1.5261
13	1.989	1.5432	1.4403		1.5089	1.5261	1.4403
14	2.0405	1.5432	1.4575	1.5623	1.406	1.4575	1.4232
15		1.4918	1.4575		1.3375	1.3717	
16		1.4403	1.406	1.3717	1.3375	1.3375	1.2346
17	1.4403	1.4746	1.4403		1.3375	1.3032	1.2517
18	1.5432	1.5604	1.4575	1.6766	1.4918	1.6804	1.4403
19	1.8347	1.8861	1.9376		1.8519	1.8861	1.8519
20	2.0919	2.0233	2.1091	2.1719	2.0062	1.989	2.0576
21	2.1091	2.1434	2.1605	2.1338	1.989	1.9719	2.0576
22	2.0062	2.0062	2.0405	2.0576	1.9376	1.9204	1.9033
23	1.869	1.9033	1.989		1.8347	1.8347	1.7833
24	1.3717	1.6461	1.7147	1.8176	1.7909	1.6804	1.6804
Max	2.1091	2.1434	2.1605	2.1719	2.0062	1.989	2.0576
Min	1.1145	1.2346	1.3717	1.3717	1.3375	1.3032	1.2346
Avg	1.7474	1.6336	1.6139	1.6511	1.6134	1.5561	1.5499

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113016 / AMFORGE

Feeder No / Name : 206 / PANNALAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2346	1.3203	1.4746	1.5089	1.6004	1.4403	2.1948
2	1.1317		1.4232	1.4403	1.4861	1.3717	2.0919
3	1.0974		1.3717	1.3889		1.3203	2.0748
4	1.0974	1.1488	1.3203	1.3375		1.286	2.0576
5	1.1831		1.3546	1.3546		1.3032	2.1262
6	1.2346	1.2689	1.406	1.3717	1.5051	1.4403	2.1776
7	1.3203	1.4746	1.4403	1.3203	1.467	1.3203	2.0576
8	1.3375	1.5089	1.5604	1.4403	1.6385	1.3375	2.3148
9	1.6804	1.7318	1.9204	1.5604	1.7318	1.6461	2.7435
10	2.1948	2.1776	2.1776		2.2291	1.9719	3.2065
11	2.2119	2.2291	2.332		2.332	1.989	3.2922
12	2.2291	2.2291	2.332	2.2481	2.4863	2.9492	3.3265
13	2.0576	1.8004	1.749		2.0405	2.6578	3.035
14	1.8861	2.0576	1.8861	1.9052	2.0405	2.4691	2.7435
15		2.1948	2.0405		1.9547	2.1091	
16		2.0748	1.9547	1.6956	1.8861	2.1776	2.8978
17	2.1948	2.1948	2.0233		1.9376	2.1605	2.9664
18	2.1262	2.2462	1.9719	1.7909	1.989	2.4177	2.572
19	2.1948	2.2291	2.0919		2.1948	2.7092	2.8807
20	2.1605	2.332	2.1434	2.1338	2.1262	2.8635	2.6749
21	1.9204	2.0405	1.8519	2.1338	1.9204	2.9492	2.572
22	1.6804	1.9204	1.7661	1.9814	1.869	2.915	2.2291
23	1.6118	1.8176	1.7661		1.749	2.6235	2.0919
24	1.3375	1.4918	1.6118	1.6289	1.7528	1.5089	2.3663
Max	2.2291	2.332	2.332	2.2481	2.4863	2.9492	3.3265
Min	1.0974	1.1488	1.3203	1.3203	1.467	1.286	2.0576
Avg	1.6874	1.8804	1.7904	1.6612	1.9018	2.0390	2.5519

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113016 / AMFORGE

Feeder No / Name : 207 / NEHA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9259	1.0631	1.0802	1.2003	1.1431	1.0974	1.0288
2	.8916		1.0288	1.0974	1.0288	1.0288	.9945
3	.823		.9945	1.0631		.9945	.9602
4	.7716	.9088	.9431	1.0288		.9602	.9431
5	.8402		.9774	1.0288		.9945	.9945
6	.9945	1.0288	1.0288	1.046	1.1431	1.046	1.0117
7	1.0288	1.1831	1.166	1.0802	1.1812	.9945	1.0631
8	1.1488	1.2689	1.2174	1.2174	1.3336	1.1145	1.0802
9	1.286	1.5089	1.4232	1.286	1.2346	1.1831	1.3375
10	1.5261	1.6118	1.5775		1.4746	1.3375	1.5947
11	1.6289	1.5432	1.5775		1.5432	1.3546	1.7318
12	1.5432	1.6118	1.5604	.4954	1.4918	1.3203	1.5775
13	1.4746	1.406	1.406		1.3375	1.2003	1.4232
14	1.3375	1.4918	1.5089	1.2955	1.3032	1.166	1.406
15		1.406	1.4232		1.286	1.0802	
16		1.3717	1.406	1.2193	1.3032	1.1145	1.4232
17	1.3375	1.5261	1.4232		1.3032	1.1145	1.4232
18	1.4918	1.5432	1.5089	1.3336	1.4403	1.2689	1.4918
19	1.5947	1.6118	1.5432		1.5604	1.3889	1.6289
20	1.6118	1.7147	1.6461	1.5051	1.5947	1.406	1.5947
21	1.5604	1.6289	1.5947	1.4861	1.4575	1.3546	1.4746
22	1.4403	1.5261	1.4918	1.4098	1.5089	1.286	1.3203
23	1.3032	1.3203	1.4232		1.3375	1.2346	1.3032
24	1.0117	1.1831	1.2174	1.2689	1.2193	1.2517	1.1488
Max	1.6289	1.7147	1.6461	1.5051	1.5947	1.406	1.7318
Min	.7716	.9088	.9431	.4954	1.0288	.9602	.9431
Avg	1.2533	1.4028	1.3403	1.1801	1.3441	1.1788	1.3024

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113016 / AMFORGE

Feeder No / Name : 208 / Lodha Imperia

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.6516	.6859	.703	.743	.703	.7202
2	.5316		.6516	.6516	.6859	.6687	.6687
3	.5316		.6001	.6001		.6344	.6173
4	.5316	.5658	.583	.6001		.6344	.6001
5	.5487		.6173	.6687		.6516	.6344
6	.583	.6859	.6859	.6859	.7621	.6516	.6859
7	.7716	.7888	.823	.703	.7621	.6859	.7202
8	.8916	.9259	.9602	.8573	.9526	.7202	.8745
9	1.0631	1.1317	1.166	.8745	1.0288	.9431	1.0631
10	1.2174	1.3375	1.1145		1.0117	1.0288	1.2003
11	1.2003	1.166	1.2346		1.1488	.9088	1.1317
12	1.1317	1.1831	1.0974	.9717	1.0631	.8916	.9945
13	1.0117	1.046	1.1145		1.0288	.9259	.9602
14	.9945	1.166	.9945	.7621	.9774	.8916	.8916
15		1.1145	1.2174		.9945	.8059	
16		1.0631	1.1145	.6859	.9088	.7202	.9602
17	.9945	1.0288	1.0631		.8916	.703	.8916
18	.8916	.9259	.9088	.743	.8402	.7545	.7888
19	.9602	.9945	1.0117		.9774	.8745	.9602
20	1.0288	.9602	1.0288	.9145	.9088	.8916	.9602
21	.9602	.9088	.9602	.8954	.8745	.8916	.9774
22	.8916	.8916	.8916	.8764	.8745	.8402	.823
23	.7545	.8402	.8745		.8402	.823	.7888
24	.6173	.7202	.7545	.7716	.8002	.7545	.7373
Max	1.2174	1.3375	1.2346	.9717	1.1488	1.0288	1.2003
Min	.5316	.5658	.583	.6001	.6859	.6344	.6001
Avg	.8488	.9570	.9231	.7626	.9083	.7916	.8544

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113022 / DREAMS

Feeder No / Name : 200 / Dheeraj Dreams-3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	27-AUG-17
HR	Load (MW)
9	.6478
Max	.6478
Min	.6478
Avg	.6478

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113022 / DREAMS

Feeder No / Name : 201 / Dheeraj Dreams-2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.4954	.5335		.5906	.5716	.5335
2	.4763		.4763		.5906	.6097	.5335
3	.4572		.4763		.5716	.5716	.4763
4	.4763		.4572		.5525	.5525	
5	.4763		.4763		.5335		
6	.5716		.4763		.4954		
7	.7049		.5716		.5144	.5525	
8	.743	.8573	.8002		.5525	.5716	
9		.9717		.7811	.8192	.6478	.8954
10			.9717	.8573		.6668	.9526
11		.8954	.8954	.8002	.8954	.8573	.9907
12		.8383	.8002	.8002	.8383	.8192	.8383
13		.7621	.8002	.7621	.6668	.8002	.8192
14		.7049	1.5623	.7049	.743	.6287	.7049
15	.6859	.7049		.5906	.724	.6097	.7049
16		.8192	.8573	.5335	.724		.7621
17		.743	.743	.5335	.6668		.6859
18	.7621	.6668	.5906	.5906	.6097		.5716
19	.6478	.6478		.5906	.6668		.6859
20		.7049		.5716			
21		.724		.6287	.6478		.7049
22		.6859		.6859	.6097		.724
23	.6859	.724		.6668	.6287		.6097
24	.4954	.6097	.6097	.6668	.5906	.6478	.6287
Max	.7621	.9717	1.5623	.8573	.8954	.8573	.9907
Min	.4572	.4954	.4572	.5335	.4954	.5525	.4763
Avg	.5892	.7385	.7117	.6728	.6469	.6505	.7123

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113022 / DREAMS

Feeder No / Name : 202 / Dheeraj dreams-4

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905		.3048		.2477		.2096
2	.1905		.3239		.2667		.1715
3	.1715		.3429		.2667		.1715
4	.1715		.3048		.2858		
5	.1715		.2667		.2667		
6	.2286		.3048		.2286		
7	.3429		.4001		.2096		
8	.4763	.2286	.5716		.1905		
9		.5525		.1905	.4001	.2286	
10			.6668	.2667		.3048	
11		.5906	.6287	.2286	.4191	.362	.5144
12		.6097	.5716	.2477	.4191	.4382	.5144
13		.5144	.5335	.2096	.4001	.362	.4763
14		.5144	.5144	.2096	.4191	.2667	.4382
15	.4954	.5716		.1905	.3239	.2477	.4191
16		.5144	.4954	.2096	.3429		.4572
17		.4763	.4763	.1905	.3239		.4382
18	.4572	.4572	.4382	.2096	.3429		.4382
19	.4572	.4382		.1905	.362		.4763
20		.4001		.1905			.4191
21				.2096	.3239		.3429
22		.3239		.1905	.3048		.3048
23	.2667	.3048		.1905	.3048		.2667
24	.2286	.2286	.2858	.3239	.2096		.2286
Max	.4954	.6097	.6668	.3239	.4191	.4382	.5144
Min	.1715	.2286	.2667	.1905	.1905	.2286	.1715
Avg	.2960	.4484	.4371	.2155	.3118	.3157	.3698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113022 / DREAMS

Feeder No / Name : 203 / Dheeraj Dreams 5

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2286			.2286	.3048	.2286
2	.1905				.1905	.2667	.1905
3	.1905				.2286	.2286	.1905
4	.1715				.2096	.3048	
5	.1905				.1905	.3239	
6	.2667					.3429	
7	.3429				.1905	.3048	
8	.2667	.3048			.1905		
9		.3048		.3239	.3239	.3048	.2858
10			.2667	.3239		.2858	.2667
11		.2477	.2477	.3239	.3048	.2858	.3048
12		.2096	.2096	.3048	.3048	.2667	.2286
13		.1905	.1905	.2286	.2667	.1905	.2096
14		.1715	.1715	.2096	.1905	.1905	.1905
15	.2667	.1715		.2286	.2477	.1905	.2286
16		.1905	.2096	.2477	.2477		.1524
17		.1905	.2096	.1905	.2096		.1524
18	.2286	.1905	.1905	.2096	.1905		.2096
19	.2286	.2286		.1905	.2096		.2667
20		.1905		.1905			.2667
21				.1905	.2477		.2286
22		.362		.1905	.3048		.2858
23	.2667	.3429		.1905	.3048		.2477
24	.2286	.2286		.3048		.3048	.2477
Max	.3429	.362	.2667	.3239	.3239	.3429	.3048
Min	.1715	.1715	.1715	.1905	.1905	.1905	.1524
Avg	.233	.2346	.2120	.2405	.2391	.2731	.2306

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113022 / DREAMS

Feeder No / Name : 205 / Jam Theatre

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	1.5242			2.0957	2.3815	2.1529
2	1.4861				2.1148	2.0957	2.0195
3					2.0576	2.2672	1.9243
4	.5525				2.0767	2.0576	
5	.724				2.1338		
6	.8192				2.1719		
7	1.086				2.2481	2.0005	
8	1.2193	1.829			2.3243	1.9243	
9		1.7909		2.8006	2.6292	2.5911	2.4577
10			3.6389	2.8006		2.6101	2.5911
11		1.7909	3.4484	2.7625	2.6673	2.553	2.5339
12		1.9243	3.4294	2.6292	2.5339	2.5149	2.5149
13		1.6575	3.1436	2.3624	2.2291	2.3815	2.3434
14		1.7909	3.2007	2.2862	2.21	2.2862	2.2672
15	1.105	1.6194		2.0767	2.3434	2.21	2.1529
16		1.7147	.7049	2.0005	2.1148		2.0195
17		1.6766	2.6482	2.0576	2.3434		2.1148
18	1.7718	2.9912	2.6673	2.3243	2.5911		2.5149
19	2.0576	4.0962		2.8578	2.9912		2.5149
20		4.401		2.9912			3.1817
21				2.8578	2.8578		3.1055
22		4.0581		2.8197	2.8006		2.8387
23	1.9814	3.7723		2.6673	2.6863		2.5339
24	1.6956	1.7528		2.7054		2.6673	2.4006
Max	2.0576	4.401	3.6389	2.9912	2.9912	2.6673	3.1817
Min	.5525	1.5242	.7049	2.0005	2.0576	1.9243	1.9243
Avg	1.3352	2.3994	2.8602	2.5625	2.3915	2.3244	2.4306

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113022 / DREAMS

Feeder No / Name : 206 / Police Station

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335		.5716		.4954	.4763	.4382
2	.5144		.5906		.4763	.4572	.4191
3	.4954		.6097		.4572	.4763	.4191
4	.5144		.5716		.4763	.4572	
5	.4572		.5525		.4572	.4191	
6	.5144		.5335		.4382	.381	
7	.5335		.5716		.4572	.4572	
8	.5906	.5335	.6478		.4763	.6097	
9		.8573		.8764	.8954	.5906	.7621
10			1.3717	.8764		.6668	1.2384
11		1.6575	1.4861	.8002	1.4098	.7049	1.467
12		1.3908	1.467	.8573	1.3336	.724	1.448
13		1.1622	1.1812	.6859	1.0669	.6287	1.1431
14		1.3908	1.467	.7621	1.3146	.7049	1.3336
15	1.4098	1.5242		.8192	1.4098	.6478	1.3527
16		1.5813	1.448	.743	1.3717		1.3908
17		1.5242	1.3717	.7049	1.2574		1.3336
18	1.1812	1.2384	1.1622	.5906	1.1622		1.2193
19	1.086	1.1431		.4954	1.086		1.0288
20		.9526		.5144			.8764
21				.4954	.5906		.6287
22		.6287		.4763	.5906		.5906
23	.5335	.5525		.4572	.5335		.5716
24	.5525	.5716	.6478	.5716	.4954	.5525	.4572
Max	1.4098	1.6575	1.4861	.8764	1.4098	.724	1.467
Min	.4572	.5335	.5335	.4572	.4382	.381	.4191
Avg	.6859	1.1139	.9560	.6704	.8296	.5596	.9536

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113023 / Haryali

Feeder No / Name : 200 / Marathon

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2915	.3582	.3086	.2915	.3258	.3429
2	.2572	.2743	.3224	.2743	.2743	.3086	.3258
3	.2572	.2572	.3224	.2743	.2401	.2915	.2915
4	.2401	.2401	.2865	.2572	.2401	.2572	.2572
5	.2401	.2401	.2865	.2401	.2401	.2572	.2401
6	.2401	.3086	.3224	.2915	.2572	.2915	.2743
7	.4115	.3429	.394	.3772	.3086	.3258	.3258
8	.4115	.3944	.4298	.4458	.4115	.3772	.4287
9	.3429	.394	.394	.4115	.3772	.3601	.394
10	.3601	.3582	.394	.3772	.3601	.3429	.394
11	.3429	.3224	.3582	.3772	.3601	.3772	.394
12	.2572	.2865	.3086	.3601	.3601	.3601	.3224
13	.2915	.2865	.3086	.2915	.2743	.3601	.2865
14	.2743	.2865	.2743	.2915	.2401	.2743	.2865
15	.2401	.2865	.2401	.2743	.2401	.2743	.2865
16	.2401	.2865	.2401	.2572	.2401	.2401	.2507
17	.2572	.2507	.2401	.2401	.2401	.2401	.2507
18	.2572	.3224	.2572	.3086	.2401	.3086	.2865
19	.3429	.3582	.3601	.3601	.3772	.3944	.394
20	.3772	.394	.3944	.4115	.3772	.4115	.4656
21	.3772	.4298	.4115	.3944	.3772	.3944	.394
22	.3944	.4298	.4115	.3601	.3601	.3772	.394
23	.3772	.4298	.3772	.3944	.3601	.3944	.394
24	.2915	.3258	.3582	.3429	.3258	.3429	.3601
Max	.4115	.4298	.4298	.4458	.4115	.4115	.4656
Min	.2401	.2401	.2401	.2401	.2401	.2401	.2401
Avg	.3065	.3249	.3354	.3301	.3072	.3286	.3350

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113023 / Haryali

Feeder No / Name : 201 / 11kV Lodha kanjur feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4575	1.4746		1.3032
2	1.3889	1.3717		1.2174
3	1.3032	1.3032		1.1145
4	1.286	1.286		1.0631
5	1.3203	1.3375		1.1488
6	1.3546	1.4746		1.2003
7	1.4232	1.5432		1.2689
8	1.5089	1.6118		1.4918
9	1.6289	1.9753		1.6461
10	1.6632	1.9387		1.6461
11	1.7318	1.9753		1.6461
12	1.749	1.8656	.4801	1.5729
13	1.5775	1.7924	1.6461	1.4632
14	1.5261	1.7193	1.406	1.3535
15	1.5261	1.7193	1.2689	1.3535
16	1.4575	1.7558	1.286	1.3169
17	1.4918		1.2689	1.3169
18	1.6461		1.4918	1.39
19	1.8519		1.5604	1.6461
20	2.0062		1.6804	1.6827
21	1.9547		1.5775	1.6827
22	1.9204		1.6118	1.6461
23	1.869		1.5432	1.5364
24	1.5432	1.6118		1.3889
Max	2.0062	1.9753	1.6804	1.6827
Min	1.286	1.286	.4801	1.0631
Avg	1.5911	1.6327	1.4018	1.4207

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113023 / Haryali

Feeder No / Name : 202 / Railway

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1488	1.1831	1.9387	1.749	1.4746	1.6118	.0171
2	1.1317	1.1145	1.8656	1.6118	1.4232	1.5432	.2915
3	1.0974	1.0802	1.829	1.4746	1.3889	1.4918	.2572
4	1.0631	1.0631	1.8107	1.4232	1.3375	1.4403	.2572
5	1.0288	1.0974	1.8107	.9374	1.3375	1.406	.2401
6	1.0802	1.2346	1.8484	1.4918	1.3717	1.4575	.2915
7	1.2346	1.286	1.9239	1.5089	1.4232	1.4918	.3258
8	1.3717	1.4403	2.037	1.6804	1.5432	1.5261	.3944
9	1.5947	1.8861	2.3011	2.0576	2.1434	1.7661	.7922
10	1.8519	1.9239	2.6029	2.2119	2.1605	1.8004	.9431
11	1.8004	1.9993	2.8292	2.1776	2.2634		.9808
12	1.989	2.1125	2.4691	1.869	2.3834	.463	.8676
13	1.6632	1.9239	2.2634	1.8519	2.2291	.3944	.8676
14	1.7147	1.8484	2.2634	1.6118	1.9204	.3772	.8676
15	1.6632	1.8484	2.332	1.5775	2.2291	.4115	.8299
16	1.6804	1.8107	2.2291	1.4575	2.0062	.3944	.8299
17	1.6632	2.0485	2.1948	1.5089	1.9376	.4115	.7922
18	1.6118	2.6406	2.1434	1.7661	2.0062	.3944	.6413
19	1.5947	2.5652	2.2119	1.869	2.1091	.4458	.6036
20	1.7833	2.6029	2.3834	2.0405	2.1605	.463	.6036
21	.3772	2.3777	2.3663	1.9033	2.0919	.463	.4904
22	1.6461	2.4143	2.2634	1.8519	1.9719	.4458	.4527
23	1.5089	2.3011	2.1605	1.8519	1.9376	.3772	.415
24	1.2174	1.3717	2.0748	1.9204	1.6632	1.9376	.3601
Max	1.989	2.6406	2.8292	2.2119	2.3834	1.9376	.9808
Min	.3772	1.0631	1.8107	.9374	1.3375	.3772	.0171
Avg	1.4382	1.7989	2.1730	1.7252	1.8547	.9789	.5589

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113030 / 22/11kV Lodha Receiving

Statio

Feeder No / Name : 200 / Lodha Supremus

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1629	.1543	.1715	.1629	.1715	.1543
2	.1543	.1629	.1372	.1715	.181	.1715	.1543
3	.1543	.1448	.1372	.1715	.1629	.1715	.1543
4	.1543	.1448	.1543	.1715	.1448	.1715	.1372
5	.1543	.1448	.1543	.1715	.1448	.1715	.1543
6	.1543	.1629	.1543	.1715	.1629	.1715	.1543
7	.1372	.181	.1715	.1715	.1629	.1715	.1372
8	.1715	.2534	.2286	.1715	.1905	.1905	.1715
9	.3439	.2743	.4001	.1629	.2477	.1543	.4001
10	.4525	.4115	.5144	.181	.2858	.1543	.4763
11	.4525	.4287	.4954	.1629	.3239	.1715	.5144
12	.4525	.3944	.5144	.181	.3048	.1543	.4001
13	.3801	.3429	.4382	.1629	.3239	.1543	.4001
14	.3982	.3772	.4001	.181	.2858	.1543	.4191
15	.4163	.3944	.4572	.181	.3239	.1543	.4572
16	.4344	.3601	.4572	.1629	.2667	.1543	.4191
17	.4344	.3944	.4191		.2667	.1543	.381
18	.3395	.3258	.362	.181	.2477	.1372	.381
19	.2896	.2743	.3048	.181	.2096	.1543	.3239
20	.2534	.2401	.2667	.1629	.2096	.1543	.2667
21	.2172	.2058	.2286	.1629	.1905	.1543	.2096
22	.181	.1886	.2096	.1629	.1905	.1543	.2096
23	.1991	.1886	.2096	.1629	.1715	.1543	.181
24	.1543	.181	.1543	.1905	.181	.1905	.1543
Max	.4525	.4287	.5144	.1905	.3239	.1905	.5144
Min	.1372	.1448	.1372	.1629	.1448	.1372	.1372
Avg	.2764	.2642	.2968	.1718	.2226	.1623	.2838

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113030 / 22/11kV Lodha Receiving

Statio

Feeder No / Name : 201 / Lodha Jolly Board

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.132	.1372	.1524	.132	.1334	.12
2	.1372	.132	.1372	.1524	.132	.1334	.12
3	.1372	.132	.12	.1524	.1509	.1334	.12
4	.12	.132	.12	.1524	.132	.1334	.12
5	.12	.1509	.12	.1524	.132	.1334	.12
6	.1372	.1509	.12	.1334	.132	.1334	.12
7	.1715	.1509	.1543	.1334	.1509	.1334	.12
8	.6859	.7545	.7811	.1524	.5716	.1334	.7716
9	.5093	.7373	.5335	.1509	.6478	.12	.8383
10	.8676	.7888	.8383	.1698	.381	.12	.8764
11	.9808	.8916	1.0288	.1509	.6287	.12	.9335
12	.7167	.8745	1.0288	.132	.2096	.1372	.8383
13	.7922	.3944	.5144	.132	.8002	.12	.8954
14	.547	.823	.5906	.1509	.6287	.12	1.0098
15	.8488	.8402	.9145	.1509	.2477	.12	
16	.9619	.7202	.5525	.1698		.12	.9717
17	.7356	.8059	1.0098		.2096	.12	1.0288
18	.9619	.6859	.8764	.1509	.1905	.1029	.5144
19	.679	.4115	.4382	.1886	.1905	.1029	.6859
20	.3772	.3944	.2477	.1509	.1905	.1029	.362
21	.1886	.2058	.2096	.1509	.1524	.1029	.1715
22	.1698	.1715	.1905	.132	.1524	.12	.1524
23	.1509	.1543	.1715	.1509	.1524	.1372	.1509
24	.1372	.1509	.1543	.1715	.1509	.1334	.12
Max	.9808	.8916	1.0288	.1886	.8002	.1372	1.0288
Min	.12	.132	.12	.132	.132	.1029	.12
Avg	.4696	.4494	.4579	.1515	.2811	.1236	.4853

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]
 THANE (U) CIRCLE[539]
 BHANDUP URBAN DIVISION[555]
 BHANDUP (E) S/DN.[733] BU 4733
 Substation No/ Name :- 113030 / 22/11kV Lodha Receiving
 Statio
 Feeder No / Name : 203 / Lodha -3 feeder
 Feeder KV- 11 / OUTGOING

DATE	26-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)
16		.9717
17	.1524	
Max	.1524	.9717
Min	.1524	.9717
Avg	.1524	.9717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113030 / 22/11kV Lodha Receiving

Statio

Feeder No / Name : 204 / Lodha Aurum Grandies

SHEDDABLE URBAN

feeder Feeder KV- 11 /
OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1698	.1715	.2096	.1698	.1715	.1886
2	.1372	.1886	.1543	.2096	.1886	.1524	.1715
3	.1543	.1698	.1543	.2096	.1698	.1524	.1543
4	.1543	.1698	.1543	.2096	.1698	.1524	.1715
5	.1715	.1886	.1715	.2096	.1509	.1524	.1886
6	.2058	.3018	.2401	.2286	.1509	.1715	.2229
7	.3086	.3395	.3086	.2667	.1886	.1715	.3086
8	.3772	.3961	.362	.3048	.2667	.1715	.3429
9	.2829	.2915	.3239	.3206	.3239	.2229	.362
10	.2829	.2572	.2667	.3206	.3239	.3429	.2477
11	.2641	.2229	.2667	.3018	.3429	.2915	.2667
12	.2452	.2058	.2667	.2641	.2477	.2915	.2286
13	.1698	.1543	.2286	.2075	.2096	.2743	.1715
14	.1698	.1372	.1715	.1886		.2229	.1715
15	.1698	.1372	.1524	.1886	.1905	.1372	
16	.1509	.1372	.1715	.1698	.1715	.1372	.1524
17	.1509	.1543	.1715		.1524	.1715	.1715
18	.1698	.1543	.1715	.1698	.1524	.1886	.2477
19	.2075	.2058	.1715	.2075	.1715	.1372	.1905
20	.2263	.1715	.2477	.2263	.1905	.2058	.1905
21	.2075	.1715	.2286	.2075	.1905	.1886	.2477
22	.2075	.2058	.2096	.1509	.2096	.1886	.2286
23	.2075	.2058	.1905	.1886	.1715	.1886	.2075
24	.1543	.1886	.1886	.2096	.1509	.1905	.1543
Max	.3772	.3961	.362	.3206	.3429	.3429	.362
Min	.1372	.1372	.1524	.1509	.1509	.1372	.1524
Avg	.2054	.2052	.2143	.2248	.2024	.1948	.2169

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113032 / 22kV Lodha Switching

Feeder No / Name : 300 / 22 kV Toyo/Steel - II SHEDDABLE URBAN
Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	26-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		.3048		.3048	
8	.6097	.4572	.6097	.3048	.4954
9	.9145	.9907	.6097	.381	.8002
10	1.0288	1.1431	1.0669	.4572	.9907
11	.9907	1.105	.9907	.4191	.9907
12	1.0288	1.105	1.0669	.4572	1.0288
13	1.0288	1.0669	1.1431	.381	.9907
14	1.105	1.1431	.9907	.3429	.9145
15	1.0669	1.0669	.9526	.3429	.9907
16	1.1431	1.2193	.9526	.3048	.9526
17	1.105	.9526	.9526	.3048	.9526
18	.7621	.8383	.7621		.6859
19	.4572	.6097	.4191		.4191
20	.381	.3429	.381		.4191
21	.3429	.3048	.3048		.3048
Max	1.1431	1.2193	1.1431	.4572	1.0288
Min	.3429	.3048	.3048	.3048	.3048
Avg	.8546	.8434	.8002	.3637	.7811

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113032 / 22kV Lodha Switching

Feeder No / Name : 302 / 22kV Lodha I-Think

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.381	.3048		
9	.4572	.4572	.3048	.3048
10	.6097	.5716	.3048	.3048
11	.6478	.6097	.3048	.3048
12	.6478	.6097	.3048	.3048
13	.6859	.4572	.3048	.3429
14	.6097	.381	.3048	.3048
15	.6478	.3048	.3048	.3048
16	.6478	.3048	.3048	.3048
17	.6097	.3048	.3048	.3048
18	.6097	.3048		
20	.3429			
Max	.6859	.6097	.3048	.3429
Min	.3429	.3048	.3048	.3048
Avg	.5748	.4191	.3048	.3090

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

BHANDUP (E) S/DN.[733] BU 4733

Substation No/ Name :- 113032 / 22kV Lodha Switching

Feeder No / Name : 303 / 22kV HDFC Bank

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.3429	.3429	.3429		.3429
2	.3429	.3429	.3429	.3429	.3048	.3048	.3048
3	.3429	.3429	.3048	.3429	.3429	.3429	.3429
4	.3429	.3429	.3429	.3429	.3048	.3429	.3048
5		.381	.3429	.3048	.3429	.3429	.3429
6	.3429	.3429	.3429	.3429	.3048	.3429	.3429
7	.3429	.381	.381	.3429	.3429	.3429	.381
8	1.2955	1.1431	1.1812	.381	.381	.3048	1.2574
9	1.5242	1.4861	1.2955	.3429	.4191	.3048	1.5623
10	1.6385	1.6766	1.4098	.381	.381	.381	1.4861
11	1.4861	1.4861	1.448	.3429	.381	.381	1.4861
12	1.3717	1.448	1.448	.381	.4191	.3429	1.5242
13	1.448	1.448	1.4098	.3429	.381	.3429	1.5242
14	1.4861	1.5242	1.448	.381	.5335	.381	1.448
15	1.5242	1.5623	1.4098	.3429	.4191	.3429	1.448
16	1.5242	1.5242	1.4098	.3429	.4191	.3048	1.4098
17	1.4098	1.5623	1.4098		.381	.3429	1.5242
18	1.4098	1.2955	1.3336	.3429	.4191	.3429	1.448
19	.6478	.6097	.6097	.3429	.3429	.3048	.5716
20	.4954	.4954	.5335	.3048	.3429	.3048	.4572
21	.4954	.4954	.4572	.3429	.381	.3429	.4572
22	.4572	.4572	.4572	.3429	.3429	.3048	.4191
23	.3429	.381	.4191	.3429	.3429	.3048	.4191
24	.9526	.9145	.9526	.8383	.3429	.3429	.3429
Max	1.6385	1.6766	1.448	.8383	.5335	.381	1.5623
Min	.3429	.3429	.3048	.3048	.3048	.3048	.3048
Avg	.9377	.9161	.8764	.3678	.3715	.3346	.8812

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

ISHWAR NAGAR S/DN.[732] BU 4732

Substation No/ Name :- 113019 / NITIE SUBSTATION

Feeder No / Name : 202 / NITIE GATE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6701	.7545	.9431	.8748	.819	.7545	.7922
2	.6143	.7922	.8775	.819	.7818	.7167	.7468
3	.6335	.7167	.8589	.7818	.7446	.7167	.7545
4	.5963	.679	.8215	.7259	.7073	.679	.7922
5	.6335	.6413	.8029	.7818	.7446	.6413	.8299
6	.6708	.6413	.7922	.7446	.7632	.6036	.8676
7	.5963	.679	.811	.6887	.6515	.6036	.8865
8	.7647	.7468	.8299	.8004	.7073	.6036	.9149
9	1.0051	1.0082	.9997	.9865	.8376	.6722	1.0562
10	.9431	1.1576	1.0807	.9493	.8215	.7282	1.0082
11	.9431	1.1317	1.1168	.8935	1.0456	.7733	1.0082
12	.9054	1.0751	1.0796	.9121	.9335	.7922	1.0082
13	.8589	.9709	.9679	.8748	.8962	.7733	.8589
14	.7842	.9808	1.0796	.8004	.8589	.7468	.9335
15	.8962	.9997	1.0424	.7446	.8676	.7356	1.0829
16	.8589	1.0374	1.0051	.819	.7545	.7356	1.3443
17	.9335	1.0185	1.061	.7818	.7545	.7468	1.2323
18	.9709	.9619	1.0051	.819	.8589	.811	1.2696
19	.9335	1.0185	1.0238	.9307	.8589	.8488	1.2696
20	.9335	1.094	1.0796	.9493	.9054	.8865	1.2323
21	.8962	1.0562	.9865	.8935	.9054	.8962	1.2696
22	.8589	.9979		.9307	.8676	.9242	1.0456
23	.8676	.9896		.8935	.8299	.8676	.9335
24	.7073	.9335		.9121	.8562	.811	
Max	1.0051	1.1576	1.1168	.9865	1.0456	.9242	1.3443
Min	.5963	.6413	.7922	.6887	.6515	.6036	.7468
Avg	.8115	.9201	.9650	.8462	.8238	.7528	1.0060

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

ISHWAR NAGAR S/DN.[732] BU 4732

Substation No/ Name :- 113019 / NITIE SUBSTATION

Feeder No / Name : 203 / TUNGWA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.3395	.3395	.381	.381	.2641	.2829
2	.3048	.3584	.3206	.362	.3239	.2452	.2614
3	.3239	.3772	.3018	.3429	.3048	.2452	.2641
4	.3048	.3395	.2987	.3239	.2858	.2641	.2641
5	.3239	.3395	.2987	.3429	.3239	.2452	.2829
6	.3239	.3772	.3174	.362	.3239	.2263	.2829
7	.3239	.3395	.3361	.3429	.3429	.2641	.2801
8	.3429	.3361	.3547	.362	.3429	.2641	.2829
9	.4572	.3734	.415	.4191	.4191	.2427	.3018
10	.415	.4527	.4954	.4954	.2987	.3206	.3361
11	.4904	.4527	.5144	.4954	.2614	.3018	.2987
12	.4854	.4108	.4954	.4572	.2987	.3018	.3361
13	.4481	.4294	.4572	.4382	.2801	.3018	.2241
14	.4108	.4338	.4572	.4382	.2614	.3018	.2241
15	.4108	.4294	.4572	.4763	.2641	.2641	
16	.4108	.3921	.4763	.4001	.2801	.2641	
17	.4481	.4481	.4191	.4001	.3395	.2829	.3734
18	.4481	.4527	.4191	.5144	.2614	.3018	.4854
19	.4854	.5281	.4763	.4572	.3361	.3206	.4108
20	.5228	.5847	.5144	.4572	.3395	.3395	.4854
21	.4481	.4904	.4382	.4191	.3018	.3584	.4108
22	.4108	.4294		.4001	.3018	.3206	.4108
23	.3772	.3921		.362	.2829	.3239	.4108
24	.362	.3395		.4001	.3429	.2858	
Max	.5228	.5847	.5144	.5144	.4191	.3584	.4854
Min	.3048	.3361	.2987	.3239	.2614	.2263	.2241
Avg	.4001	.4103	.4097	.4104	.3124	.2854	.3290

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

ISHWAR NAGAR S/DN.[732] BU 4732

Substation No/ Name :- 113019 / NITIE SUBSTATION

Feeder No / Name : 204 / RESIDENCY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4393	1.4712	1.6032	1.5529	1.4961	1.6221	1.5089
2	1.3446	1.358	1.5844	1.515	1.4582	1.5844	1.4712
3	1.3635	1.2826	1.5684	1.4393	1.4393	1.5466	1.4712
4	1.3256	1.2826	1.5497	1.4014	1.4014	1.4712	1.4523
5	1.3635	1.3014	1.5466	1.4203	1.4393	1.358	1.4335
6	1.4014	1.3203	1.5089	1.4582	1.3635	1.3203	1.4335
7	1.4961	1.5089	1.5089	1.3825	1.6286	1.3957	1.4146
8	1.4203	1.5684	1.4937	1.3825		1.4712	1.4146
9	1.515	1.5684	1.6221	1.515	1.7044	1.4937	1.7164
10	1.6598	1.6409	1.6459	1.5718	1.7551	1.6221	1.5684
11	1.6975	1.6975	1.7612	1.515	1.7551	1.6221	1.643
12	1.6057	1.6991	1.7044	1.4771	1.6804	1.6221	1.6804
13	1.643	1.6032	1.5529	1.515	1.6804	1.5655	1.6057
14	1.643	1.5844	1.6476	1.4203	1.643	1.5089	1.4937
15	1.6057	1.5339	1.5908	1.4203	1.7177	1.4712	1.5684
16	1.5684	1.6221	1.5908	1.4203	1.6804	1.3957	1.531
17	1.5684	1.5655	1.5529	1.4014	1.6598	1.4003	1.5684
18	1.6057	1.6787	1.515	1.4582	1.6057	1.4937	1.643
19	1.643	1.6787	1.7044	1.5908	1.7177	1.6975	1.6804
20	1.6804	1.6975	1.7612	1.7233	1.773	1.7737	1.643
21	1.7177	1.7177	1.7423	1.7612	1.8484	1.7541	1.6804
22	1.6804	1.773		1.7801	1.773	1.6975	1.6804
23	1.6598	1.7364		1.7044	1.7353	1.6975	1.6057
24	1.534	1.6244		1.5908	1.534	1.5278	
Max	1.7177	1.773	1.7612	1.7801	1.8484	1.7737	1.7164
Min	1.3256	1.2826	1.4937	1.3825	1.3635	1.3203	1.4146
Avg	1.5492	1.5631	1.6074	1.5174	1.6300	1.5464	1.5612

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

ISHWAR NAGAR S/DN.[732] BU 4732

Substation No/ Name :- 113024 / M&B

Feeder No / Name : 201 / MMRDA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.8589	.8589	.9526	.9335	.8962	.9526
2	.7621	.7655	.8215	.8383	.8589	.8402	.9335
3	.724	.7468	.8215	.8192	.8215	.7842	.9335
4	.724	.7468	.8029	.8383	.8215	.7842	.9335
5	.7049	.7842	.8029	.8573	.8589	.7655	.9526
6	.743	.8589	.8402	.8764	.8589	.7842	1.0669
7	.8573	.9709	.9335	.9145	.8962	.8215	1.0098
8	1.0288	1.0456	1.0082	1.0288	.9896	.9335	1.2193
9	1.0479	1.1949	1.1203	1.0669	1.0082	.9709	1.3336
10	1.1203	1.1949	1.4098	1.1949	1.2323	1.2193	1.448
11	1.1949	1.2136	1.2955	1.2136	1.1576	1.1241	1.419
12	1.1949	1.2323	1.2384	1.1203	1.1576	1.2003	1.3817
13	1.1763	1.1949	1.1812	1.1203	1.1576	1.2384	1.2696
14	1.1203	1.1576	1.1622	1.0082	1.0829	1.105	1.1949
15	1.1576	1.1949	1.1622	.9808	1.0082	1.0669	1.2323
16	1.1949	1.2323	1.1812	.9335	1.0082	1.105	1.2323
17	1.1203	1.1763	1.2003	.9709	.9709	1.086	1.2136
18	1.1949	1.2323	1.2193	.9709	1.0269	1.2384	1.3443
19	1.307	1.3443	1.3717	1.2323	1.2323	1.4289	1.4563
20	1.3443	1.3817	1.4289	1.3443	1.2696	1.6385	1.4937
21	1.419	1.4377	1.4098	1.4003	1.3817	1.6766	1.531
22	1.3817	1.3443	1.3717	1.307	1.2696	1.5242	1.4563
23	1.2323	1.1389	1.1812	1.0829	1.0829	1.4098	1.2136
24	.8954	1.0082	1.0082	1.0669	.9709	.9896	1.105
Max	1.419	1.4377	1.4289	1.4003	1.3817	1.6766	1.531
Min	.7049	.7468	.8029	.8192	.8215	.7655	.9335
Avg	1.0587	1.1024	1.1180	1.0475	1.0440	1.1096	1.2220

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

ISHWAR NAGAR S/DN.[732] BU 4732

Substation No/ Name :- 113024 / M&B

Feeder No / Name : 202 / Neptune

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.0762	.112	.0762	.0762	.0934	.1334
2	.1143	.1143	.112	.0762	.0762	.112	.1143
3	.1143	.1143	.0934	.0762	.0747	.1307	.1143
4	.1143	.0762	.0934	.1143	.0572	.1307	.1334
5	.1143	.0762	.112	.1334	.0381	.1307	.0953
6	.1334	.0762	.1307	.1143	.0381	.112	.1143
7	.1715	.0762	.1867	.1143	.0381	.112	.1334
8	.2477	.0762	.2241	.2477	.0762	.1867	.1715
9	.2096	.1905	.2241	.2477	.2241	.1867	.2286
10	.1867	.1867	.2096	.1867	.2241	.1524	.2667
11	.1867	.1867	.1905	.2614	.112	.1905	.2241
12	.1494	.1867	.2096	.112	.1867	.2286	.1494
13	.0934	.1494	.1524	.1494	.1494	.1143	.2286
14	.112	.1867	.1715	.112	.1494	.1143	.1867
15	.112	.112	.1524	.112	.1494	.1524	.1524
16	.112	.1494	.1524	.0934	.1494	.1143	.0747
17	.1524	.1307	.1143	.0747	.1494	.1334	.112
18	.2286	.1494		.1143	.1307	.1334	.1494
19	.2286	.1867	.1524	.1494	.112	.1715	.1494
20	.1905	.1867	.1715	.0747	.1867	.1334	.112
21	.1143	.1867	.2096	.112	.1494	.1334	.112
22	.1494	.1494	.1905	.1524	.1143	.1524	.112
23	.1143	.1307	.1334	.0747	.112	.1524	.1494
24	.1143	.112	.1494	.1524	.0762	.112	.1905
Max	.2477	.1905	.2241	.2614	.2241	.2286	.2667
Min	.0934	.0762	.0934	.0747	.0381	.0934	.0747
Avg	.1499	.1361	.1586	.1305	.1188	.1410	.1503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

ISHWAR NAGAR S/DN.[732] BU 4732

Substation No/ Name :- 113024 / M&B

Feeder No / Name : 209 / Hanuman silk mills

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.4572	.4108	.4763	.3921	.3361	.3048
2	.3429	.4001	.3734	.4191	.3734	.2987	.3048
3	.3239	.4191	.3734	.4001	.3239	.2987	.3048
4	.3239	.381	.3734	.381	.3174	.2987	.3048
5	.3239	.381	.3734	.381	.3174	.2987	.2858
6	.3239	.381	.3734	.381	.3429	.2987	.2286
7	.3429	.4191	.3734	.362	.3361	.2987	.3048
8	.4191	.4191	.4481	.381	.4191	.3361	.362
9	.6478	.5975	.6348	.5144	.5228	.3734	.5716
10	.8589	.9335	.9907	.7095	.7095	.5716	.8383
11	1.0082	1.0082	1.0098	.6908	.8589	.6287	.8589
12	1.0456	1.0642	1.0669	.7468	.8215	.6668	.9335
13	.8962	.9335	.8954	.6722	.7842	.5906	.8402
14	1.0082	1.0456	.9907	.6348	.8215	.6097	.8962
15	1.0456	1.0082	1.0288	.6348	.8215	.6097	.8962
16	1.0456	.9335	1.0098	.6348	.8589	.6097	.8962
17	.9907	.9709	.9717	.6348	.8215	.6478	.9335
18	.9907	.8589	.8764	.5228	.7468	.5716	.8589
19	.9145	.8775	.8383	.5601	.6348	.5716	.7468
20	.7468	.6722	.724	.5041	.5601	.5335	.6348
21	.6097	.6722	.6668	.4854	.5228	.4572	.5601
22	.5975	.5975	.6097	.4854	.4854	.4954	.5228
23	.5228	.5601	.5716	.4854	.4854	.4572	.5041
24	.4382	.4954	.5041	.5716	.4108	.4294	.4191
Max	1.0456	1.0642	1.0669	.7468	.8589	.6668	.9335
Min	.3239	.381	.3734	.362	.3174	.2987	.2286
Avg	.6721	.6869	.6870	.5279	.5704	.4703	.5963

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

ISHWAR NAGAR S/DN.[732] BU 4732

Substation No/ Name :- 113024 / M&B

Feeder No / Name : 212 / Prestine

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0479	1.4377	1.5684	1.5432
2		.9717	1.4003	1.4937	1.467
3		.9526	1.4003	1.4937	1.467
4		.9526	1.3817	1.4937	1.4861
5		.9717	1.4003	1.531	1.4289
6		.9717	1.419	1.4937	1.5051
7		.9907	1.4377	1.4937	1.6194
8		.9526	1.6057	1.5684	1.848
9		1.0479	1.9044	1.6804	2.2862
10		.9709	2.0538	1.829	2.4006
11		1.0082	2.0911	1.848	2.4272
12	1.4289	1.7177	2.0911	1.7909	2.3152
13	1.4861	1.6057	1.643	1.7718	2.2592
14	1.8099	1.5684	1.8671	1.7337	2.2405
15	1.7528	1.419	1.8671	1.5432	2.1658
16	1.6766	1.5123	1.9044	1.5432	2.1658
17	1.6766	1.4937	1.8671	1.5242	2.2592
18	1.6194	1.5684	1.9231	1.6575	2.1658
19	1.5623	1.6804	2.0538	1.848	2.2405
20	1.3717	1.7364	2.0538	1.9433	2.3525
21	1.3527	1.7364	1.8671	1.9052	2.1658
22	1.2193	1.6804	1.8298	1.848	1.9418
23	1.105	1.6804	1.7551	1.8099	1.8298
24		1.0288	1.5123	1.643	1.6956
Max	1.8099	1.7364	2.0911	1.9433	2.4272
Min	1.105	.9526	1.3817	1.4937	1.4289
Avg	1.5051	1.3028	1.7403	1.6690	1.9698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113012 / NBR5

Feeder No / Name : 201 / METRO MARBLE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171		.0171	.017	.0171	.0171	.0168
2	.0171		.0171	.0179	.0171	.0177	.017
3	.0171		.0171	.0177	.0171	.0177	.0177
4	.0171		.0171	.017	.0171	.0177	.0177
5	.0171		.0171	.017	.0171	.0171	.0168
6	.0171		.0171	.0177	.0171	.0171	.017
7	.0171		.0171	.0179	.0171	.0171	.017
8	.0171		.0171	.0177	.0171	.0171	.0168
9		.0171	.0179	.0171	.0171	.0168	
10		.0171	.0168	.0171	.0171	.017	
11		.0171	.0177	.0171	.0171	.0168	
12		.0171	.0177	.0171	.0171	.0179	
13		.0171	.0177	.0171	.0171	.017	
14		.0171	.0177	.0171	.0171	.017	
15		.0171	.0168	.0171	.0171	.0177	
16		.0171	.0177	.0171	.0171	.0168	
17		.0171	.0168	.0171	.0171	.0179	
18		.0177	.0168	.0171	.0171	.0177	
19		.0171	.0168	.0171	.0171	.0168	
20		.0175	.0179	.0171	.0177	.0179	
21		.0177	.0179	.0171	.0171	.0177	
22		.0171	.0177	.0171	.0171	.0168	
23		.0171	.0177	.0171	.0171	.0179	
24	.0171		.0171	.0177	.0171	.0171	.017
Max	.0171	.0177	.0179	.0179	.0177	.0179	.0177
Min	.0171	.0171	.0168	.017	.0171	.0168	.0168
Avg	.0171	.0172	.0173	.0173	.0171	.0173	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113012 / NBR5

Feeder No / Name : 202 / NEELA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.567	.5975	.6219	.5788	.5487	.5914	.5788
2	.5304	.4904	.6468	.5788	.4938	.5544	.5041
3	.4938	.4854	.6099	.5415	.4755	.5228	.4668
4	.4755	.5041	.5544	.5041	.4755	.4854	.4481
5	.4572	.4668	.5415	.5228	.4755	.4715	.4481
6	.4755	.5975	.5788	.5228	.5304	.4527	.4854
7	.5304	.5601	.5175	.5601	.4973	.4251	.5658
8	.4755	.6161	.5487	.4854	.4572	.4207	.4854
9	.5788	.6468	.6908	.6219	.6401	.4904	.6535
10	.0747	.9694	.9328	.7865	.823	.6722	.811
11	1.1389	1.0903	1.0059	.8779	.9694	.7865	1.1016
12	1.2449	1.2254	.9774	.8596	.6401	.8871	1.1949
13	1.0642	1.134	.9231	.7865	.7133	.8145	1.0269
14	1.0562	1.0242	.8779	.7133	.695	.7602	.9335
15	1.1041	1.1888	1.0059	.8048	.7133	.7316	1.1203
16	1.2136	1.2071	.9877	.8048	.6584	.7865	.9709
17	1.0562	1.1888	.9328	1.0242	.6219	.7499	1.0456
18	1.0374	1.1706	.9145	.823	.4938	.7682	1.0829
19	1.0642	1.0242	.9774	.8596	.8596	.7682	1.0608
20	1.0829	1.0425	1.0059	.8779	.8501	.7655	1.0059
21	.9896	.9145	.8413	.823	.7865	.7655	.8596
22	.7282	.8131	.8413	.7316	.6584	.7655	.7468
23	.6413	.7682	.6722	.7133	.6401	.6722	.5788
24	.6767	.6161	.6838	.6535	.6036	.6283	.5975
Max	1.2449	1.2254	1.0059	1.0242	.9694	.8871	1.1949
Min	.0747	.4668	.5175	.4854	.4572	.4207	.4481
Avg	.7816	.8476	.7871	.7107	.6384	.6557	.7822

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113012 / NBR5

Feeder No / Name : 203 / SOHEL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7095	.8215	.9335	.9997	.7095	.8402	.7356
2	.6722	.7282	.8962	.7356	.6535	.811	.679
3	.6348	.6722	.8865	.7545	.6535	.7733	.6413
4	.5975	.6161	.8488	.7282	.6348	.7167	.6224
5	.5975	.7577	.7922	.7356	.6348	.7356	.5975
6	.7655	.8299	.811	.7095	.7282	.7545	.6348
7	.8962	.8865	.8775	.7922	.7655	.7095	.8029
8	1.0642	1.0829	1.0456	.8488	.7095	.8029	.9619
9	1.1016	1.2323	1.2071	.9149	1.1389	.8299	1.0374
10	1.5466	1.643	1.587	1.1949	1.5154	1.1694	1.5684
11	1.6804	1.8298	1.7926	1.226	1.8111	1.1694	1.6598
12	1.6221	1.8484	1.6448	1.2323	1.7177	1.1317	1.7364
13	1.4563	1.5524	1.4937	1.1016	1.4415	1.0562	1.4377
14	1.531	1.6244	1.6057	.9522	1.587	1.1128	1.4937
15	1.6991	1.7364	1.7177	1.0374	1.587	1.1128	1.6804
16	1.7737	1.7737	1.6804	1.0082	1.4937	1.0751	1.5893
17	1.5466	1.643	1.643	1.0374	1.5123	.8676	1.6991
18	1.2826	1.5497	1.475	.9522	1.4377	.8865	1.475
19	1.475	1.531	1.4563	1.1016	1.4003	.8865	1.4377
20	1.307	1.3817	1.2136	1.094	1.2883	.9242	1.307
21	1.1389	1.1576	1.0829	1.0082	1.094	.9054	1.1576
22	1.0082	1.1016	1.0562	.9335	1.0456	.9242	1.0562
23	.9522	.9896	1.0751	.8775	.9709	.8676	.9431
24	.8962	.9335	1.0082	.9997	.7655	.9709	.8488
Max	1.7737	1.8484	1.7926	1.2323	1.8111	1.1694	1.7364
Min	.5975	.6161	.7922	.7095	.6348	.7095	.5975
Avg	1.1648	1.2468	1.2429	.9573	1.1373	.9181	1.1585

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113012 / NBR5

Feeder No / Name : 204 / ASIAN PAINTS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.4338	.4527	.3477	.415	.4338	.2401
2	.4527	.4294	.4527	.362	.415	.4338	.2401
3	.4338	.4338	.4338	.3429	.415	.415	.2241
4	.4338	.4527	.4338	.3292	.415	.3961	.1981
5	.4338	.4108	.4338	.3155	.415	.415	.2
6	.4715	.4527	.4527	.2934	.415	.3961	.208
7	.4338	.4108	.4527	.3155	.415	.415	.2241
8	.4904	.4904	.5093	.285	.5093	.415	.2542
9	.7545	.7167	.6661	.4527	.7167	.2881	.6979
10	1.0456	1.0185	1.2071	.4338	.9997	.4031	.9522
11	1.1949	1.2696	1.1694	.547	1.2449	.499	1.2136
12	1.3014	1.226	1.3014	.4715	1.1883	.499	1.2136
13	.9328	1.0642	.9808	.4715	.9808	.4904	1.0269
14	1.2449	1.1389	1.2449	.4904	1.1128	.4656	1.0829
15	1.1883	1.094	1.1694	.4904	1.0562	.4805	1.1389
16	1.226	1.1317	1.2071	.4904	.9808	.4656	1.0456
17	1.1883	1.0751	1.0185	.4715	1.0185	.3768	1.1203
18	.9896	1.0751	.8865	.415	.8676	.2858	.9619
19	.7842	.9242	.7356	.4338	.7167	.2721	.8029
20	.6535	.7167	.5658	.4715	.5658	.2641	.6348
21	.5788	.5658	.4887	.415	.5093	.2481	.5175
22	.5041	.5281	.4239	.415	.4904	.2481	.4481
23	.4854	.5093	.3658	.3961	.4527	.2629	.4338
24	.4527	.4294	.4715	.3612	.415	.4294	.2601
Max	1.3014	1.2696	1.3014	.547	1.2449	.499	1.2136
Min	.4338	.4108	.3658	.285	.415	.2481	.1981
Avg	.7553	.7499	.7302	.4091	.6971	.3874	.6392

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113012 / NBR5

Feeder No / Name : 205 / SHIV COLD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6219	.5601	.7468	.6413	.6219	.6099	.5281
2	.5853	.5601	.7842	.6602	.6401	.679	.5847
3	.5487	.5249	.7282	.679	.6584	.6036	.5658
4	.5487	.5228	.679	.6224	.6401	.5601	.5281
5	.5487	.6979	.7167	.5658	.6401	.5788	.547
6	.4938	.6535	.6602	.5847	.6401	.6161	.547
7	.567	.6722	.6722	.6224	.5487	.5415	.547
8	.8048	.8131	.7762	.679	.4938	.6161	.679
9	1.251	1.307	1.2883	.7499	.9709	.6979	1.0679
10	1.9978	2.1622	2.1399	.823	1.5708	.9896	1.9239
11	2.3899	2.4579	2.4434	.8962	2.0302	1.0425	2.2405
12	2.3899	2.5688	2.5882	.8962	2.1033	1.0534	2.2965
13	2.1125	2.1437	2.1538	.9145	1.7741	1.0608	1.9231
14	2.2081	2.3285	2.3348	.8413	2.0144	1.0164	2.1658
15	2.3577	2.3655	2.2862	.8413	1.9959	.9877	2.2779
16	2.2634	2.4579	2.2624	.7499	1.9605	.9955	2.2405
17	2.4897	2.3101	2.2986	.8962	1.8296	.9511	2.3152
18	2.1098	2.0513	1.8823	.6767	1.587	.811	1.9044
19	1.7164	1.6617	1.4632	.7499	1.358	.6348	1.531
20	1.2826	1.1576	1.1706	.6767	.9896	.6602	1.1016
21	.8775	.8686	.8779	.7682	.8131	.547	.8962
22	.7095	.7762	.7356	.6219	.7095	.547	.7167
23	.6535	.7282	.7167	.5853	.6099	.6224	.6979
24	.6036	.6348	.7023	.7167	.6219	.6283	.547
Max	2.4897	2.5688	2.5882	.9145	2.1033	1.0608	2.3152
Min	.4938	.5228	.6602	.5658	.4938	.5415	.5281
Avg	1.3388	1.3744	1.3795	.7274	1.1592	.7521	1.2655

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113012 / NBR5

Feeder No / Name : 206 / Advani

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7356	.7545	.7733	.6483	.5658	.7733	.5693
2	.7356	.7468	.7167	.6325	.547	.7356	.5851
3	.7167	.7282	.6979	.6093	.5281	.6979	.5693
4	.6979	.7468	.679	.5792	.5281	.679	.5468
5	.6979	.6036	.6602	.5418	.5281	.6413	.5468
6	.6979	.5975	.7356	.6173	.5093	.6602	.5155
7	.6348	.5975	.5847	.4607	.5281	.6413	.5376
8	1.0642	1.1576	.7545	.6068	.7545	.6602	.6316
9	1.4901	1.3014	1.2012	.7167	1.1506	.8962	1.0751
10	1.7924	1.9044	2.1125	.8299	1.5089	.9774	1.8111
11	1.9044	2.0165	2.3011	.811	1.7164	.985	1.9231
12	2.1285	2.2068	2.2445	.8488	1.6991	1.0498	1.9418
13	2.1691	2.2257	2.2822	.7356	1.8296	1.0498	1.6804
14	2.0182	1.8298	2.1098	.8299	1.4523	.9313	1.9231
15	2.2218	1.8296	2.2068	.9242	1.5497	1.2752	1.6804
16	2.2218	1.9805	2.1472	.9808	1.6244	1.363	1.7551
17	1.9978	1.8296	2.037	.8865	1.5655	1.358	1.6632
18	1.9239	1.773	1.7918	.7545	1.5278	1.4523	1.363
19	1.5844	1.3957	1.4335	.9149	1.4901	1.3957	1.4377
20	1.1763	1.094	1.4003	.8402	1.3392	1.358	1.363
21	1.0082	1.0374	1.1222	.7922	1.251	1.2449	.9328
22	.8488	.8299	.8063	.6224	.8488	1.0082	.8402
23	.7922	.8488	.7042	.6036	.7922	.6241	.7922
24	.7545	.7545	.811	.6802	.5847	.7922	.6081
Max	2.2218	2.2257	2.3011	.9808	1.8296	1.4523	1.9418
Min	.6348	.5975	.5847	.4607	.5093	.6241	.5155
Avg	1.3339	1.2829	1.3464	.7278	1.1008	.9687	1.1372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113012 / NBRS

Feeder No / Name : 207 / Inamdar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6219	.7468	.823	.9431	.8596	.8413	.8299
2	.6219	.6722	.7947	.8865	.7865	.7947	.7733
3	.6219	.679	.7577	.811	.7316	.7392	.7356
4	.6036	.6224	.7282	.7733	.695	.6722	.7167
5	.6036	.6535	.7468	.7468	.6767	.6535	.6979
6	.6036	.7356	.7095	.7545	.695	.7095	.6908
7	.7499	.7468	.823	.7545	.6584	.6838	.7282
8	.7316	.9149	.8962	.8215	.823	.7316	.7468
9	.8589	.9877	.9896	1.0059	.9328	.8676	.8775
10	1.1883	1.2382	1.1765	1.0608	1.1157	.9694	1.2449
11	1.2136	1.3676	1.2803	1.1706	1.3169	1.0059	1.2696
12	1.2637	1.3352	1.2757	1.1523	1.2437	.9955	1.3256
13	1.0829	1.1523	1.0808	1.0791	1.0791	1.6832	1.1016
14	1.1128	1.262	1.1694	.9511	1.1523	.8869	1.0456
15	1.226	1.1888	1.2127	.9511	1.1523	.8413	1.1016
16	1.1694	1.2197	1.1641	.9145	1.1523	.7783	1.1016
17	1.0829	1.2071	1.0924	.9328	1.1706	.7865	1.134
18	1.0562	1.1706	1.1222	.9145	1.0974	.8316	1.1389
19	1.1506	1.1523	1.1403	1.0242	1.262	.9149	1.2323
20	1.1694	1.262	1.2308	1.0791	1.1706	.9709	1.1949
21	1.1016	1.1157	1.0791	1.0242	1.0608	.9522	1.0829
22	1.0082	1.0903	1.1203	.9694	.9328	.9709	.9242
23		1.0242	1.0829	.9145	.9694	.9522	.9054
24	.7316	.8962	.9328	1.0082	.8962	.924	.9242
Max	1.2637	1.3676	1.2803	1.1706	1.3169	1.6832	1.3256
Min	.6036	.6224	.7095	.7468	.6584	.6535	.6908
Avg	.9380	1.0184	1.0179	.9435	.9846	.8815	.9802

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113012 / NBR5

Feeder No / Name : 208 / NAHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9993	2.1313	2.0559	2.0513	2.0559	1.8861	1.922
2	1.905	1.8298	2.0182	1.9959	2.0182	1.9239	1.7556
3	1.8296	1.9993	1.9616	1.8665	1.9427	1.8484	1.7194
4	1.773	1.9231	1.8673	1.7375	1.905	1.7541	1.6832
5	1.7164	1.8484	1.8484	1.7556	1.8861	1.773	1.6834
6	1.6975	1.9231	1.8107	1.8107	1.7541	1.905	1.6651
7	2.1125	2.0351	2.0748	1.9387	1.9993	1.9616	1.7194
8	2.3388	2.3339	2.3954	2.1253	2.4143	2.2068	2.0698
9	2.838	2.7538	2.9235	2.452	2.6217	2.2822	2.5206
10	3.3981	3.546	3.6025	3.2253	3.3951	2.9424	3.0247
11	3.6782	3.6403	3.9609	2.999	3.7912	3.3762	2.8006
12	3.4915	3.7146	3.8477	3.0367	3.7342	3.3573	3.3234
13	3.2301	3.1927	3.5648	2.7915	3.1121	3.0933	2.95
14	3.1499	3.2301	3.4139	2.5463	3.0556	2.6972	3.3048
15	3.3608	3.5271		2.8858	3.5271	3.1121	3.5475
16	3.2819	3.6969	3.81	3.1121	3.5648	2.963	3.3608
17	3.6969	3.3048	3.6403	2.6406	3.3573	2.4874	3.4019
18	2.9874	3.3234	3.6591	2.7538	3.2253	2.8669	3.4915
19	3.4894	3.6591	3.4705	2.7538	3.3385	2.7538	3.1499
20	3.1927	3.263	3.2442	2.9235	3.1687	2.7349	3.3421
21	2.6326	2.7538	2.6217	2.452	2.5463	2.3765	2.5206
22	2.5393	2.3954	2.6783	2.1313	2.3577	2.3899	2.1691
23	2.1807	2.1879	2.4331	2.0559	2.1691	1.957	2.037
24	2.0182	2.0725	2.0748	2.0328	2.0748	2.0182	1.9753
Max	3.6969	3.7146	3.9609	3.2253	3.7912	3.3762	3.5475
Min	1.6975	1.8298	1.8107	1.7375	1.7541	1.7541	1.6651
Avg	2.6891	2.7619	2.8251	2.4197	2.7090	2.4445	2.5474

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113012 / NBR5

Feeder No / Name : 209 / TITAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8589	.9522	1.0082	1.094	.9522	1.1016	.9522
2	.8865	.8775	1.0456	1.0185	.8775	1.1576	.9054
3	.8402	.8676	.9896	.9808	.8215	1.0642	.8488
4	.8029	.811	.9431	.9619	.7842	1.0185	.8029
5	.7468	.8962	.9242	.9149	.7468	.9808	.7842
6	.8775	.9896	.9997	.811	.8871	1.0374	.8029
7	1.1317	1.1763	1.363	1.2071	.9896	1.0374	.9335
8	1.1506	1.2323	1.3443	1.2071	1.1576	1.1203	1.0269
9	1.3957	1.5123	1.423	1.2883	1.386	1.1506	1.363
10	1.6991	1.8298	1.6289	1.643	1.6632	1.3717	1.8484
11	1.8107	1.8298	1.8804	1.9427	1.9035	1.4118	1.8298
12	1.6598	1.7741	1.7737	1.7737	1.7926	1.4506	1.7924
13	1.4937	1.5339	1.4842	1.4712	1.4415	1.2715	1.3717
14	1.5089	1.587	1.6095	1.363	1.6263	1.2127	1.4937
15	1.5927	1.6078	1.6108	1.531	1.7187	1.267	1.7177
16	1.7353	1.7556	1.7193	1.531	1.7187	1.2308	1.7364
17	1.7164	1.6632	1.6478	1.4937	1.6817	1.1706	1.7551
18	1.6975	1.8671	1.5424	1.475	1.6632	1.0791	1.6244
19	1.7353	1.7741	1.7558	1.475	1.7926	1.2437	1.7737
20	1.6598	1.5497	1.4815	1.3817	1.6448	1.1949	1.5684
21	1.475	1.475	1.4632	1.2136	1.4377	1.0269	1.4563
22	1.2696	1.307	1.2197	1.1576	1.3443	1.0642	1.1763
23	1.1706	1.307	1.251	1.0829	1.2696	1.0829	1.1576
24	.9149	1.0751	1.1576	1.1506	1.0269	1.2071	1.0269
Max	1.8107	1.8671	1.8804	1.9427	1.9035	1.4506	1.8484
Min	.7468	.811	.9242	.811	.7468	.9808	.7842
Avg	1.3263	1.3855	1.3861	1.2987	1.3470	1.1647	1.3229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113012 / NBR5

Feeder No / Name : 212 / Samarth Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.3395	.1097	.0514	.1307	.1097	.0091
2	.3174	.132	.3326	.0579	.1867	.2195	.0091
3	.7468	.6722	.3881	.4961	.2241	.3326	.0084
4	.3361	.112	.4938	.3563	.1307	.4251	.0091
5	.6348	.8488	.6036	.1772	.1307	.1294	.1286
6	.3174	.7468	.1829	.0793	.112	.1646	.4372
7	.1646	.3772	.2378	.0945	.2054	.0732	.567
8	.1494	.112	.1646	.048	.2801	.0914	.04
9	.3584	.1829	.0945	.1494	.1463	.0137	.3109
10	.4338	.3658	.3641	.0747	.0732	.013	.7167
11	.0747	.7023	.4961	.168	.3475	.013	.0747
12	.3395	.2378	.6036	.0747	.6401		.112
13	.2054	1.0425	.1189	.0732	.2561	.013	.1494
14	.4904	.8596	.2835	.0732	.6036	.0137	.5041
15	.0934	.6335	.0429	.3174	.3475	.013	.181
16	.6348	.1646	.2353	.0747	.1463	.0137	.7655
17	.7842	.1463	.6722	.0739	.8596	.016	.4854
18	.7468	.5914	.0838	.1867	.4207	.0091	.0747
19	.3395	.1463	.9997	.1867	.2743	.0091	.1307
20	.6979	.128	.7392	.1867	.695	.013	.112
21	.6413	.4024	.3125	.1494	.0732	.0091	.3841
22	.0943	.4938	.4508	.112	.6584	.0084	.3547
23	.6036	.3292	.25	.6908	.2378	.0091	.5975
24	.4854	.1867	.6401	.032	.1307	.5729	.0091
Max	.7842	1.0425	.9997	.6908	.8596	.5729	.7655
Min	.0747	.112	.0429	.032	.0732	.0084	.0084
Avg	.4162	.4147	.3708	.1660	.3046	.0994	.2571

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113012 / NBR5

Feeder No / Name : 213 / FILIX

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0943	.1132	.124	.0943	.1132	.0905
2	.0943	.0934	.1132	.0777	.0943	.0943	.0905
3	.0943	.0934	.1132	.0905	.0943	.1132	.0905
4	.0943	.0934	.0943	.0886	.0943	.0943	.0905
5	.0943	.0934	.0943	.0886	.0943	.0943	.0905
6	.0754	.0747	.0943	.0648	.0943	.0943	.0248
7	.0754	.0747	.0754	.0448	.0754	.0943	.0488
8	.132	.1646	.1132	.0905	.0943	.0943	.0905
9	.2075	.2829	.2452	.0943	.1886	.112	.2614
10	.5041	.5281	.547	.1698	.3395	.1509	.5041
11	.5788	.6036	.679	.2075	.3772	.2452	.6535
12	.4163	.547	.5658	.2075	.3395	.2075	.5788
13	.4527	.4904	.5281	.1886	.3206	.2452	.5228
14	.4668	.4668	.4715	.1698	.3018	.1886	.4481
15	.5658	.5847	.547	.1698	.415	.1886	.4668
16	.5658	.547	.547	.1886	.2641	.2641	.5415
17	.5041	.5658	.4904	.132	.2641	.2641	.4481
18	.3734	.4527	.4527	.1509	.2641	.2801	.4108
19	.3018	.3395	.3206	.2263	.2075	.2987	.3361
20	.3018	.3018	.2641	.1886	.1886	.2801	.2427
21	.2054	.2075	.1886	.1698	.1698	.2614	.168
22	.112	.1132	.1307	.1132	.1132	.2427	.1132
23	.112	.1132	.1307	.0943	.0189	.181	.112
24	.0943	.112	.0943	.1109	.0943	.1132	.1109
Max	.5788	.6036	.679	.2263	.415	.2987	.6535
Min	.0754	.0747	.0754	.0448	.0189	.0943	.0248
Avg	.2715	.2933	.2922	.1355	.1918	.1798	.2723

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113031 / RUNWAL

Feeder No / Name : 202 / Runwal Green-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2112	.2263	.2471	.2603	.2131	.2659	.2245
2	.198	.2226	.2358	.2546	.2226	.2546	.2395
3	.2226	.2169	.2207	.2641	.2094	.2226	.2414
4	.1905	.2207	.2169	.2433	.2056	.2018	.2867
5	.198	.2131	.2131	.2395	.2226	.2037	.3037
6	.1848	.215	.2358	.2546	.2037	.1905	.2659
7	.198	.2263	.2112	.2603	.1905	.1792	.249
8	.2282	.2924	.1962	.2282	.1943	.2414	.2999
9	.1943	.2207	.2641	.2754	.1924	.2471	.2509
10	.1452	.2226	.2905	.3357	.2791	.2678	.3395
11	.2358	.2282	.2942	.2754	.3037	.3452	
12	.2773	.2339	.2377	.3621	.3527	.3791	.3867
13	.2112	.2282	.298	.2659	.3112	.3037	.2697
14	.1641	.2169	.3074	.2546	.2942	.3414	.2584
15	.1886	.1905	.2188	.2622	.298	.3263	.2791
16	.2131	.1962	.2433	.2565	.2697	.2678	.2169
17	.2471	.2414	.2867	.2169	.2414	.2131	.249
18	.2207	.198	.3169	.232	.2546	.2905	.2358
19	.2961	.2565	.3395	.3301	.2659	.2282	.2697
20	.2263	.298	.332	.3056	.3131	.3621	.2509
21	.2377	.3188	.3527	.2735	.2867	.3867	.2414
22	.3056	.3433	.3414	.2565	.2924	.3414	.3074
23	.2924	.3225	.2924	.2471	.281	.2678	.2961
24	.2131	.232	.2678	.2961	.2339	.2942	.1943
Max	.3056	.3433	.3527	.3621	.3527	.3867	.3867
Min	.1452	.1905	.1962	.2169	.1905	.1792	.1943
Avg	.2208	.2409	.2692	.2688	.2555	.2759	.2677

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113036 / HDIL

Feeder No / Name : 201 / Khalasa Compound

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3584	.3921	.3734	.2987	.3772	.3018
2	.3239	.362	.3361	.3772	.2801	.3584	.2829
3	.3395	.3395	.3174	.3734	.2801	.3584	.2641
4	.3239	.3206	.3174	.3361	.2427	.3395	.2641
5	.3429	.3239	.3547	.3292	.2427	.3395	.2641
6	.3547	.3584	.3547	.3395	.2641	.3395	.2829
7	.3511	.415	.3841	.3772	.2772	.3395	.3018
8	.4435	.4755	.4108	.3511	.3584	.3395	.3772
9	.5731	.6268	.6219	.4294	.5041	.3142	.5601
10	.7796	.815	.8048	.5228	.7095	.3475	.7796
11	.8413	.8417	.8589	.5121	.7282	.3292	.7712
12	.8669	.8962	.8962	.4755	.7164	.4207	.7712
13	.8859	.8215	.7392	.4108	.6379	.3511	.7796
14	.7442	.7842	.7682	.4854	.6878	.4251	.7362
15	.8063	.8413	.8413	.4854	.7701	.3982	.7362
16	.815	.8029	.7964	.4805	.6556	.3734	.8063
17	.7282	.8589	.7602	.4481	.6535	.3361	.7712
18	.6859	.8402	.7499	.4108	.6348	.3174	.7796
19	.6733	.7095	.6908	.3547	.5975	.3048	.6878
20	.5731	.6161	.5975	.3395	.4338	.3018	.5487
21	.4344	.4854	.4108	.2987	.3961	.3018	.4527
22	.3881	.4572	.3961	.2987	.3961	.3018	.415
23	.4108	.4572	.415	.3174	.415	.3018	.4338
24	.3584	.3772	.3961	.415	.3206	.4527	.3018
Max	.8859	.8962	.8962	.5228	.7701	.4527	.8063
Min	.3239	.3206	.3174	.2987	.2427	.3018	.2641
Avg	.5576	.5910	.5671	.3976	.4792	.3487	.5279

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

BHANDUP URBAN DIVISION[555]

PANNALAL S/DN.[734] BU 4734

Substation No/ Name :- 113036 / HDIL

Feeder No / Name : 202 / Killburn

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.7049	.5601	.7733	.5228	.7167	.679
2	.6668	.6478	.5788	.7167	.5041	.679	.6413
3	.6287	.6036	.5544	.6979	.4668	.6413	.6036
4	.6036	.6287	.6036	.6722	.4715	.6036	.6036
5	.6224	.6668	.6154	.6722	.4805	.6036	.6036
6	.6859	.7049	.6219	.6413	.4854	.6036	.6036
7	.6602	.7049	.7842	.7468	.5788	.679	.679
8	.811	.8676	.8215	.6767	.6722	.7922	.7922
9	1.0829	1.0534	1.1203	.7682	.9709	.8215	1.0456
10	1.6461	.8145	1.6804	1.0456	1.3032	.9709	1.448
11	1.6651	1.6118	1.7193	.9709	1.448	.9955	1.5939
12	1.5604	1.6991	1.6832	.9709	1.4327	1.0349	1.576
13	1.134	1.1706	1.262	.8215	1.0985	.9055	1.5043
14	1.4352	1.4937	1.4937	.8413	1.267	.9055	1.2696
15	1.6126	1.6289	1.6991	.9709	1.4327	.9328	1.4632
16	1.5074	1.5181	1.5912	.9709	1.3466	.8215	1.448
17	1.4327	1.5729	1.643	.9145	1.2696	.8029	1.448
18	1.3756		1.6095	.8048	1.419	.7842	1.3756
19	1.2071	1.3817	1.3676	.8413	1.1888	.8676	1.3169
20	1.2752	1.2437	1.2696	.8589	1.0562	.9054	1.2936
21	.9795	1.0791	.9877	.7842	.9808	.8299	.9808
22	.8589	.9328	.9522	.6908	.7922	.7922	.8676
23	.7922	.8962	.9054	.6224	.7545	.7545	.8299
24	.6668	.7621	.5601	.8589	.5658	.7167	.7167
Max	1.6651	1.6991	1.7193	1.0456	1.448	1.0349	1.5939
Min	.6036	.6036	.5544	.6224	.4668	.6036	.6036
Avg	1.0649	1.0603	1.1118	.8055	.9379	.7984	1.0577

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113020 / Hariomnagar receiving

Feeder No / Name : 201 / AMIT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1109	.1109	.1478	.1478	.1294	.1294	.1294
2	.0924	.1109	.1294	.1294	.1109	.1294	.1109
3	.0924	.1109	.1109	.1109	.1109	.1109	.1109
4	.0924	.1109	.0924	.0924	.0924		.0924
5	.0924	.1109	.0924	.0924	.0924	.0924	.0924
6	.1109	.1109	.1109	.1109	.0739	.0924	.1109
7	.1109	.1109	.1109	.1109	.0739	.0924	.1109
8	.1109	.1109	.1109	.1109		.0924	.1109
9	.1109	.0924	.1109	.1109	.1294	.1109	.1109
10	.0924	.0924	.1109	.1478	.1294	.1109	.1109
11	.0924	.0924	.1109	.1109	.1109	.1109	.1109
12	.1109	.0924	.1109	.1294	.1294	.1109	.1109
13	.0739	.0924	.1109	.1109	.1109	.1109	.1109
14	.0924	.0924	.0924	.1109	.1109	.0924	.1109
15	.0739	.0924	.0924	.0924	.1109	.0924	.1109
16	.0739	.0739	.0924	.0739	.0924	.0924	.0739
17	.0924	.0924	.0924	.0739	.0739	.1109	.0924
18	.0924		.0924	.0924	.0924	.1109	.1109
19	.1109	.1109	.1109	.1294		.1109	.1294
20	.1294	.1478	.1109	.1478	.1109	.1109	.1109
21	.1294	.1478	.1109	.1478	.1294	.1109	.1109
22	.1294	.1294	.1478	.1294	.1294	.1109	.1478
23	.1294	.1294	.1478	.1478	.1478	.1294	.1294
24	.1109	.1109	.1663	.1294	.1478	.1294	.1478
Max	.1294	.1478	.1663	.1478	.1478	.1294	.1478
Min	.0739	.0739	.0924	.0739	.0739	.0924	.0739
Avg	.1024	.1077	.1132	.1163	.1109	.1085	.1124

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113020 / Hariomnagar receiving

Feeder No / Name : 202 / HARIOM NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2427	.2427	.2427	.2601	.2774	.2601	.2774
2	.2254	.2254	.2427	.2601	.2774	.2601	.2427
3	.2254	.2254	.2254	.2427	.2774	.2601	.208
4	.2254	.2254	.2254	.208	.2774	.2601	.208
5	.2427	.2254	.2254	.208	.2774	.2601	.1734
6	.2601	.2427	.2427	.2254	.2601	.2601	.1734
7	.2601	.2601	.2774	.2427	.2601	.2254	.2427
8	.2774	.3467	.3121	.2947	.2774	.2254	.2427
9	.3467	.3814	.3467	.3467	.3467	.2947	.3814
10	.3814	.3814	.3988	.3294	.3467	.3467	.3814
11	.3467	.3988	.4334	.3121	.3641	.3814	.3988
12	.3814	.3641	.3814	.3467	.3294	.2774	.3467
13	.3467	.3467	.3467	.3294	.3467	.2947	
14	.3467	.3294	.3121	.2601	.3294	.2947	.2774
15	.3121	.3121	.3121	.2601	.3121	.2601	.2774
16	.3467	.3467	.2774	.2774	.2774	.2427	.2427
17	.3467	.3121	.2774	.2601	.2427	.2427	.2601
18	.2601		.3121	.2947	.2601	.2947	.2601
19	.2774	.2601	.2427	.3294		.2774	.2774
20	.3121	.2947	.3121	.3467	.2947	.3121	.2601
21	.2947	.2947	.2774	.3294	.2947	.2774	.2774
22	.2947	.3294	.2947	.3294	.3121	.2427	.2427
23	.2601	.3294	.2774	.3121	.2947	.2774	.2947
24	.2254	.2601	.3294	.2774	.3121	.2774	.2774
Max	.3814	.3988	.4334	.3467	.3641	.3814	.3988
Min	.2254	.2254	.2254	.208	.2427	.2254	.1734
Avg	.2933	.3015	.2969	.2868	.2977	.2752	.2706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113020 / Hariomnagar receiving

Feeder No / Name : 203 / KALPTARU

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5596	.6104	.6783	.78	.7122	.6783	.6952
2	.5426	.5765	.6783	.7291	.9694	.6443	.6443
3	.5426	.5426	.6443	.6952	.6613	.6443	.6274
4	.5765	.5426	.6274	.6783	.6443	.6104	.5935
5	.5765	.5765	.5935	.6443	.6443	.6104	.5935
6	.6783	.6783	.6613	.6952	.6104	.5765	.6783
7	.8139	.8139	.7291	.7291	.6104	.5765	.78
8	.8139	.9156	.8478	.8139	.6783	.6443	.6952
9	.7461	.8139	.8309	.8648	.8817	.7461	.78
10	.7461	.7461	.7291		.8817	.8648	.8139
11	.6783	.6443	.6952	.8478	.8648	.7461	.6952
12	.6104	.5935	.6783	.78	.7461	.7969	
13	.5765	.5765	.6443	.6783	.6443	.763	.6443
14	.5596	.5087	.6104	.6274	.7291	.7291	.5935
15	.5087	.5596	.5765	.6104	.6783	.6783	.5256
16	.5087	.5256	.5426	.6104	.6104	.6443	.5087
17		.5087	.5765	.5935	.5765	.6104	.4748
18	.4917		.6104	.6443	.5765	.6443	.5765
19	.7461	.6443	.6443	.7122		.7122	.6274
20	.7122	.7461	.7461	.7461	.7122	.7461	.7291
21	.78	.7122	.8478	.7291	.7461	.7122	.763
22	.78	.8478	.8139	.7291	.78	.8478	.7122
23	.78	.8139	.8309	.7461	.78	.763	.7122
24	.6104	.6952	.78	.8139	.7461	.7969	.7291
Max	.8139	.9156	.8478	.8648	.9694	.8648	.8139
Min	.4917	.5087	.5426	.5935	.5765	.5765	.4748
Avg	.6495	.6606	.6924	.7173	.7167	.6994	.6606

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113020 / Hariomnagar receiving

Feeder No / Name : 204 / SAINATH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.631	.3681	.8194	1.2269	1.1568	1.1393	1.2795
2	.3155	.333	.4031	1.1919	1.0517	1.1218	1.2094
3	.3155	.333	.3681	1.1393	1.0517	1.0867	1.1393
4	.3155	.333	.3681	1.1043	1.0166	.9816	1.0692
5	.3506	.3506	.3506	1.0867	1.0166	.9465	1.0517
6	.4207	.4207	.333	1.1568	.9816	.929	.9991
7	.5083	.4557	.4557	1.2269	.9816	.9465	1.0867
8	.4733	.4207	.5258	1.3672	1.0517	1.0166	1.1393
9	.3856	.4557	.4557	1.4899	1.4899	1.1568	1.4198
10	.4908	.5609	.4908	1.5424	1.4198	1.4022	1.4373
11	.4031	.3856	.8414	1.4373	1.5074	1.3672	1.2971
12	.4557	.3506	.3856	1.4198	1.2971	1.3321	
13	.3856	.3681	.3506	1.2445	1.1919	1.2269	1.1568
14	.3506	.333	.3506	1.1218	1.1393	1.1744	.9816
15	.3155	.3155	1.0166	1.0166	1.0166	1.1393	.8589
16	.3155	.333	.9816	.9465	.9991	1.0692	.8939
17	.2804	.298	1.0692	.964	.964	1.0341	.9991
18	.2804		.9991	1.0867	1.0517	1.1919	1.0166
19	.3856	.3681	1.2445	1.3321		1.2971	1.2269
20	.4207	.4557	1.3672	1.2971	1.3146	1.2971	1.2971
21	.4382	.4557	1.4022	1.2795	1.4022	1.3146	1.2971
22	.4557	.5258	1.4899	1.3496	1.4198	1.3321	1.2269
23	.4908	1.0516	1.4373	1.3672	1.262	1.3672	1.2971
24	.7362		.9816	1.4373	1.3672	1.2971	1.3146
Max	.7362	1.0516	1.4899	1.5424	1.5074	1.4022	1.4373
Min	.2804	.298	.333	.9465	.964	.929	.8589
Avg	.4134	.4215	.7703	1.2430	1.1805	1.1736	1.1607

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113020 / Hariomnagar receiving

Feeder No / Name : 205 / SANDEEP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3475	.3841	.4024	.4572	.4024	.4024	.3841
2	.5121	.3658	.3841	.4207	.3475	.4024	.3658
3	.3292	.3475	.3841	.3841	.3475	.3658	.3292
4	.3292	.3475	.3658	.3658	.3292	.3658	.3109
5	.3658	.3475	.3658	.3292	.3292	.3475	.3109
6	.4024	.3475	.3475	.3658	.3292	.3475	.3292
7	.439	.3658	.4024	.4024	.3292	.3475	.3475
8	.4024	.439	.4755	.4024	.3292	.2926	.4024
9	.439	.439	.439	.4207	.4207	.4024	.3841
10	.439	.4024	.4024	.4024	.439	.4024	.4207
11	.4207	.4024	.4024	.439	.439	.4024	.4024
12	.4207	.4207	.3841	.3658	.4435	.3475	
13	.3658	.4024	.4024	.3475	.3658	.3475	.3292
14	.3658	.3475	.3841	.3658	.3475	.3475	.2926
15	.3292	.3292	.3292	.2561	.3292	.3109	.2561
16	.2926	.2743	.3292	.2926	.2926	.3109	.2743
17	.3109	.3475	.3109	.2926	.2561	.3292	.4024
18	.3292	.3109	.3841	.3658	.3658	.3475	.3658
19	.439	.4024	.4572	.439		.4207	.5121
20	.5304	.4938	.4938	.4572	.4024	.4207	.4572
21	.5121	.5304	.5487	.4207	.4207	.4755	.5304
22	.4755	.5304	.5853	.6653	.4207	.4024	.4572
23	.4755	.5121	.5121	.4572	.4024	.4572	.4572
24	.439	.3841	.5121	.4938	.4572	.439	.4207
Max	.5304	.5304	.5853	.6653	.4572	.4755	.5304
Min	.2926	.2743	.3109	.2561	.2561	.2926	.2561
Avg	.4047	.3948	.4169	.4004	.3716	.3765	.3801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113020 / Hariomnagar receiving

Feeder No / Name : 301 / ETERNITY-I Incomer to NON SHEDDABLE EXPRESS HV FEEDERS
 Eternity Feeder KV- 22 / (CONTINUOUS PROCESS)(NO STAGGERING)
 INCOMING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.4743	3.8809	3.733	4.1396	3.9918	3.9918	4.0657
2	3.1047	3.6591	3.5852	3.9548	3.5482	3.6961	3.9179
3	3.2526	3.4743	3.5113	3.6222	3.3265	3.6222	3.6222
4	3.2526	3.3265	3.3634	3.4374	3.2526	3.5482	3.4374
5	3.4743	3.6961	3.3265	3.4374	3.2526	3.4743	3.3634
6	3.6222	4.0657	4.0287	3.5852	3.3265	3.4743	3.5852
7	3.9918		4.3614	4.1027	3.4743	3.77	3.9918
8	4.4353	4.3614	4.8049	4.2135	4.0657	3.6222	4.1766
9	4.4723	4.8788	4.768	4.8788	4.3614	3.77	4.4353
10	5.1745	5.0267	4.8788	4.5831	4.694	4.1766	4.731
11	4.9897	5.1745	5.0636	4.731	4.768	4.5092	4.8788
12	4.9158	5.1006	4.3983	4.2875	4.6571	4.3614	
13	4.3983	4.2135	4.694	4.1027	4.3244	4.2875	4.3614
14	4.3244	4.3983	4.8788	3.9918	4.2875	4.2135	4.1396
15	4.2135	4.2505	4.5092	3.4743	3.9918	3.9918	3.6961
16	4.0657	4.5831	4.3983	3.5482	3.6961	3.9918	3.9918
17	4.2135	4.3983	4.3983	3.9548	3.6961	3.9918	4.0657
18	4.731		4.4353	3.77	4.1027	4.0287	4.1027
19	5.0267	5.3593	5.1006	4.3614		4.5462	4.768
20	5.8398	5.7289	5.4702	5.1006	4.5831	5.2484	5.0267
21	5.4702	5.9137	5.655	4.8788	5.1006	5.0636	5.3593
22	5.4332	5.2484	5.1006	4.3614	4.9158	4.8419	4.8419
23	5.3593	4.9528	5.1006	4.731	4.6571	4.5462	4.3614
24	4.1027	4.2505	4.0657	4.5831	4.2135	4.3614	4.2505
Max	5.8398	5.9137	5.655	5.1006	5.1006	5.2484	5.3593
Min	3.1047	3.3265	3.3265	3.4374	3.2526	3.4743	3.3634
Avg	4.3891	4.5428	4.4846	4.1596	4.0995	4.1304	4.2248

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113020 / Hariomnagar receiving

Feeder No / Name : 302 / ETERNITY-II Incomer to NON SHEDDABLE EXPRESS HV FEEDERS
Eternit Feeder KV- 22 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9335	1.0456	1.0829	1.2323	1.0829	1.0456	1.1576
2	.8962	.9709	1.0082	1.1576	.8962	1.0456	1.0829
3	.8962	.9335	.9335	1.1203	.8962	.9709	1.0082
4	.8589	.9709	.9335	1.0082	.8589	.9709	.9335
5	.8962	1.0082	.8215	.9335	.8589	.9335	.9335
6	.9709	1.0829	1.0456	1.0082	.8962	.9335	1.0456
7	1.0829	1.1203	1.307	1.0456	.9335	.9335	1.1949
8	1.307	1.6057	1.1949	1.1203	1.1203	.9709	2.0165
9	1.7551	1.7924	1.1949	1.307	1.419	1.1576	2.2779
10	2.0538	2.2032	2.2405	1.3443	1.5684	1.2696	2.2779
11	2.1658	2.4272	2.6139	1.2696	1.6804	1.358	2.3899
12	2.1658	2.3899	2.4646	1.1949	1.7177	1.307	
13	2.0538	2.1285	2.2032	1.1576	1.5684	1.2696	2.1658
14	2.0538	2.1285	2.1658	1.0829	1.4563	1.2696	2.0911
15	2.0165	2.1502	2.2032	1.0456	1.419	1.1576	2.0538
16	2.0165	2.2032	2.2405	1.0829	1.3817	1.1203	2.0165
17	2.0165		2.2405	1.0456	1.307	1.1949	1.9418
18	1.9044	2.0911	2.0165	1.1203	1.2696	1.1949	1.7924
19	1.7551	1.7353	1.8298	1.2696	1.307	1.307	1.6057
20	1.5684	1.643	1.643	1.307	1.3817	1.3443	1.5684
21	1.4937		1.5684	1.2696		1.419	1.3443
22	1.419	1.3817	1.3817	1.2323	1.2696	1.3443	1.1949
23	1.307	1.307	1.3817	1.1949	1.2696	1.2696	1.2323
24		1.1576	1.1949	1.3957	1.1203	1.1949	1.2323
Max	2.1658	2.4272	2.6139	1.3957	1.7177	1.419	2.3899
Min	.8589	.9335	.8215	.9335	.8589	.9335	.9335
Avg	1.5473	1.6126	1.6213	1.1644	1.2469	1.1659	1.5895

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113040 / Pioneer S/stn.

Feeder No / Name : 204 / 11 Kv Chintamani

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.4327		1.6118	
2		1.2894		1.5402	
3		1.2178		1.4327	
4		1.0387		1.3969	
5		1.0745		1.2894	
6		1.2536		1.2178	
7		1.4685		1.3611	1.3575
8		1.6834		1.4327	
9		1.7551			
10	1.7193	1.7551	1.8267		1.8625
11	1.6834	1.8267	1.8625		1.8267
12	1.6834		1.6834		1.7909
13	1.576		1.6118		1.6834
14			1.4327		1.4327
15			1.3969		1.3611
16	1.4685		1.3611		1.3611
17	1.4685				
18	1.576				1.5402
19	1.8267		1.8267		1.9342
20	2.0416		2.0416		1.9909
21	2.0058		1.9342		1.8625
22	2.0058		1.7909		1.7551
23	1.8625		1.8267		1.7551
24		1.7909		1.8267	
Max	2.0416	1.8267	2.0416	1.8267	1.9909
Min	1.4685	1.0387	1.3611	1.2178	1.3575
Avg	1.7431	1.4655	1.7163	1.4566	1.6796

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113040 / Pioneer S/stn.

Feeder No / Name : 205 / 11 Kv Ganadhiraj

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.4327		1.97	
2		1.3611		1.7909	
3		1.2536		1.6118	
4		1.182		1.4327	
5		1.4327		1.4327	
6		1.5043		1.3969	
7		1.9521		1.4327	1.5203
8		2.0774		1.4327	
9		2.0416			
10			1.8625		1.8625
11		1.9342	1.8267		1.8625
12			1.7551		1.6476
13	1.576		1.5402		1.4327
14			1.5043		.6984
15			1.3969		1.3611
16	1.4685		1.3611		1.2894
17	1.3969				
18	1.576				1.5402
19			1.97		1.97
20			2.0416		2.1491
21			2.0416		2.1132
22			2.0774		2.0416
23			2.0774		2.0058
24		1.7909		2.0774	
Max	1.576	2.0774	2.0774	2.0774	2.1491
Min	1.3969	1.182	1.3611	1.3969	.6984
Avg	1.5044	1.6330	1.7879	1.6198	1.6782

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113521 / P.M.G.P. RECEIVING

Feeder No / Name : 201 / ANKITA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2328	.2865	.2865	.3045	.2507	.2865	.2686
2	.197	.2507	.2686	.2865	.2149	.2328	.2507
3	.1791	.197	.2507	.2686	.197	.2149	.2149
4	.1612	.1791	.2328	.2328	.1791	.197	.2149
5	.2149	.197	.2328	.2328	.2149	.2149	.2328
6	.2686	.2865	.2865	.2507	.2507	.2328	.2507
7	.3045	.3761	.2865	.2507	.3045	.2507	.2686
8	.3045	.4119	.3761	.3045	.2865	.2507	.2865
9	.3224	.3761	.3045	.3761	.3403	.3045	.3761
10		.3224	.3403	.4119	.3582	.2865	.3045
11	.3582	.3403	.3403	.394	.394	.2865	.3224
12	.3224	.2865	.3045	.3582	.3582	.3224	.2686
13	.2865	.2865	.2865	.3224	.3045	.3224	.2865
14	.2865	.2686	.2686	.2507	.2507	.2686	.2507
15	.2686	.2507	.2507	.2507	.2507	.2686	.2149
16	.2507	.2507	.2686	.2507	.2507	.2686	.2328
17	.2686	.2507	.2507	.2686	.2507	.3045	.2507
18	.2865	.2507	.2865	.2507	.2865	.2865	.2507
19	.3224	.2865	.3582	.3224	.3224	.2865	.3224
20	.3582	.3761	.3761	.3224	.3045	.2865	.3045
21	.3582	.394	.394	.3403	.3403	.3403	.394
22	.3403	.3761	.3761	.3582	.3224	.3403	.3224
23	.3582	.394	.394	.3045	.3403	.3224	.2865
24	.2686	.3045	.3224	.3403	.2865	.3045	.2865
Max	.3582	.4119	.394	.4119	.394	.3403	.394
Min	.1612	.1791	.2328	.2328	.1791	.197	.2149
Avg	.2834	.3000	.3059	.3022	.2858	.2783	.2776

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113521 / P.M.G.P. RECEIVING

Feeder No / Name : 204 / SAMPADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.124	.124	.1417	.124	.1417	.124	.1417
2	.124	.124	.124	.124	.124	.124	.124
3	.124	.1063	.124	.124	.124	.124	.1063
4	.1063	.1063	.124	.1063	.1063	.1063	.1063
5	.124	.124	.1417	.124	.124	.124	.124
6	.124	.124	.1417	.124	.1417	.124	.1417
7	.124	.124	.1417	.1417	.1595	.124	.1417
8	.1417	.124	.1417	.1595	.1417	.124	.1417
9	.124	.1417	.1417	.1595	.1417	.124	.1417
10	.124	.124	.1417	.1417	.124	.1417	.124
11	.124	.124	.124	.124	.124	.124	.124
12	.124	.124	.124	.1417	.124	.1417	.124
13	.124	.124	.1417	.124	.124	.124	.124
14	.124	.124	.124	.1417	.124	.124	.124
15	.124	.124	.124	.124	.124	.1417	.124
16	.124	.124	.124	.124	.124	.124	.124
17	.124	.124	.124	.124	.124	.124	.124
18	.124	.124	.124	.124	.124	.1417	.124
19	.1417	.1417	.124	.1417	.124	.124	.124
20	.1949	.2126	.1595	.1417	.1417	.1417	.1417
21	.1595	.1772	.1772	.1772	.1772	.1772	.1595
22	.1772	.1772	.1772	.1772	.1772	.1949	.1772
23	.1772	.1417	.1772	.1417	.1417	.1417	.1417
24	.124	.1417	.1417	.1595	.1417	.124	.1417
Max	.1949	.2126	.1772	.1772	.1772	.1949	.1772
Min	.1063	.1063	.124	.1063	.1063	.1063	.1063
Avg	.1336	.1336	.1388	.1373	.1343	.1329	.1321

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113521 / P.M.G.P. RECEIVING

Feeder No / Name : 205 / LALITA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2686	.2865	.3582	.3582	.3403	.3582	.3403
2	.2507	.2865	.3403	.3403	.3045	.3224	.2865
3	.2328	.2715	.3045	.3045	.2507	.2686	.2507
4	.2149	.2686	.2865	.2865	.2328	.2507	.2328
5	.2507	.3045	.2865	.2865	.2507	.2686	.2328
6	.2865	.3045	.3582	.3045	.2686	.2865	.2686
7	.394	.394	.3582	.394	.3224	.3045	.3761
8	.4298	.4298	.4298	.4298	.3761	.3403	.3582
9	.4298	.4298	.394	.4298	.394	.4119	.3761
10		.394	.4119	.4298	.4477	.394	.4298
11	.4477	.4477	.4119	.4477	.394	.4298	.4298
12	.4298	.4298	.3761	.3761	.4119	.3761	.4119
13	.3582	.394	.3582	.394	.3403	.3761	.3582
14	.3403	.3582	.3761	.3582	.3224	.2865	.2865
15	.3224	.3403	.3582	.3224	.3224	.3224	.2865
16	.2865	.3224	.3761	.2865	.3045	.3224	.3224
17	.3582	.3582	.394	.3224	.3045	.3403	.3045
18	.394	.3403	.3582	.3582	.394	.3582	.3582
19	.4477	.3761	.4298	.394	.4298	.4298	.4119
20	.4656	.4656	.4656	.4119	.4477	.4298	.4835
21	.4477	.4835	.4656	.394	.4298	.4298	.4656
22	.4656	.4298	.5014	.3761	.4298	.4656	.4298
23	.4477	.4298	.4298	.4119	.4298	.4298	.394
24	.3045	.3403	.394	.4298	.394	.394	.3761
Max	.4656	.4835	.5014	.4477	.4477	.4656	.4835
Min	.2149	.2686	.2865	.2865	.2328	.2507	.2328
Avg	.3597	.3702	.3843	.3686	.3559	.3582	.3530

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113521 / P.M.G.P. RECEIVING

Feeder No / Name : 206 / NEELAM NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2328	.2865	.3224	.3582	.3224	.3045	.2865
2	.2149	.2865	.2865	.3224	.2865	.2686	.2686
3	.197	.2507	.2507	.3045	.2507	.2328	.2507
4	.197	.2507	.2507	.2865	.2328	.2149	.2328
5	.2328	.2686	.2686	.2865	.2328	.2328	.2328
6	.2686	.3045	.3224	.3045	.2686	.2686	.2686
7	.3582	.4119	.3403	.3224	.3045	.3045	.3224
8	.3582	.4477	.3761	.3224	.2865	.2865	.2865
9	.394	.3582	.3761	.3761	.3224	.3582	.3403
10	.394	.3224	.3582	.3761	.394	.3582	.3582
11	.3403	.4119	.3403	.3582	.3761	.3761	.3403
12	.3045	.3403	.3403	.394	.3224	.394	.3403
13	.2865	.2686	.2865	.3045	.3224	.3403	.2686
14	.2507	.2686	.2686	.2686	.2865	.2507	.2507
15	.2507	.2507	.2328	.2507	.2507	.2507	.2507
16	.2507	.2328	.2686	.2328	.2328	.2507	.2149
17	.197	.2507	.2507	.2507	.2328	.2865	.2328
18	.2686	.2507	.2686	.2686	.2686	.3224	.2507
19	.3403	.3224	.3224	.3403	.3045	.3761	.3224
20	.3761	.3761	.3761	.3761	.3403	.3582	.3403
21	.3761	.362	.3582	.3403	.3403	.394	.3582
22	.3582	.4298	.394	.3403	.3403	.3761	.3582
23	.3582	.4119	.394	.3582	.3403	.3761	.3582
24	.2896	.3403	.3582	.394	.3403	.3403	.3582
Max	.394	.4477	.394	.394	.394	.394	.3582
Min	.197	.2328	.2328	.2328	.2328	.2149	.2149
Avg	.2956	.3210	.3171	.3224	.3000	.3134	.2955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113521 / P.M.G.P. RECEIVING

Feeder No / Name : 207 / M H B

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.695	.7682	.8962	.7316	.7316	.8413
2	.5853	.6219	.7316	.8048	.695	.695	.7316
3	.5487	.6036	.695	.7316	.6584	.6219	.695
4	.5121	.6036	.6584	.6767	.6219	.5853	.6767
5	.5853	.6401	.695	.695	.6584	.6036	.695
6	.6767	.695	.7316	.7133	.6767	.6219	.7316
7	.8048	.7499	.7865	.7682	.7499	.6036	.8779
8	.8413	.8048	.8413	.8413	.7865	.7316	.8596
9	.8413	.9145	.9328	.9694	.8596	.823	.9877
10	.9877	.9328	.8596	.9694	.9877	.9694	.9877
11	.8413	.8962	.9145	.9145	.9328	.9694	1.0059
12	.8413	.8048	.8413	.9328	.8779	.9328	.9145
13	.7499	.7316	.823	.8779	.8326	.8413	.8962
14	.7682	.7316	.6767	.7499	.8413	.823	.7865
15	.7316	.3142	.7316	.8962	.7133	.7865	.7316
16	.6767	.6401	.695	.695	.7133	.7499	.7133
17	.6036	.6767	.695	.695	.7316	.8048	.6767
18	.7499	.7133	.7682	.7316	.7865	.7865	.7316
19	.8596	.8048	.8962	.8779	.9511	.9511	.9145
20	.9145	.8779	1.0059	.8413	.8962	.9328	.8962
21	.9328	.9145	1.1706	.8413	.9328	.9511	.9694
22	.9328	.9877	1.2437	.9145	.9694	1.0974	.9145
23	.9511	.9877	1.0242	.9328	.9877	1.0791	.8779
24	.695	.7499	.9328	.9328	.7316	.8413	.9877
Max	.9877	.9877	1.2437	.9694	.9877	1.0974	1.0059
Min	.5121	.3142	.6584	.6767	.6219	.5853	.6767
Avg	.7613	.7538	.8383	.8291	.8052	.8139	.8375

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113521 / P.M.G.P. RECEIVING

Feeder No / Name : 208 / Renuka

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1584	1.3394	1.5023	1.5927	1.4118	1.448	1.4118
2	1.0679	1.1765	1.4118	1.448	1.3394	1.3756	1.2489
3	.9774	1.1403	1.2489	1.2489	1.267	1.3032	1.1946
4	.9774	1.1041	1.1946	1.1946	1.1946	1.1946	1.2308
5	1.086	1.1403	1.2308	1.2308	1.2308	1.2308	1.2127
6	1.1946	1.2127	1.3756	1.3032	1.2127	1.267	1.267
7	1.3575	1.2127	1.5203	1.448	1.4118	1.2851	1.2851
8	1.5746	1.647	1.647	1.6108	1.448	1.448	1.5384
9	1.7194	1.8823	1.828	1.6651	1.7013	1.5023	1.7013
10		1.9185	1.9366	1.9366	1.8461	1.7918	1.9004
11	1.9909	2.0995	2.0633	1.9185	1.9366	1.9728	1.9547
12	1.9004	1.9185	1.9366	1.7375	1.9366	1.9547	1.9004
13	1.9004	1.8823	1.8823	1.6108	1.7013	1.7375	1.7375
14	1.5927	1.7556	1.7918	1.5746	1.5203	1.5565	1.6108
15	1.5223	1.7013	.1448	1.3032	1.4118	1.448	1.4842
16	1.5203	1.5927	1.6289	1.2851	1.3937	1.4118	1.4118
17	1.5927	1.7013	1.6832	1.3575	1.4118	1.5565	1.4842
18	1.7556	1.6832	1.8099	1.6651	1.5565	1.8099	1.5927
19	1.9547	2.0271	2.1176	1.8823	1.9004	2.0814	1.9547
20	2.0271	2.0995	2.2081	1.9366	1.9004	2.1176	1.9547
21	2.0271	2.0814	2.1719	1.9185	1.9185	2.1176	1.9185
22	1.9004	2.0271	2.0452	1.8099	1.7737	1.8823	1.7194
23	1.7375	1.9185	2.0271	1.7013	1.7556	1.8642	1.6289
24	1.5927	1.448	1.647	1.8461	1.5927	1.6108	1.7013
Max	2.0271	2.0995	2.2081	1.9366	1.9366	2.1176	1.9547
Min	.9774	1.1041	.1448	1.1946	1.1946	1.1946	1.1946
Avg	1.5708	1.6546	1.6689	1.5927	1.5739	1.6237	1.5852

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113521 / P.M.G.P. RECEIVING

Feeder No / Name : 209 / Shripad

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3696	.4251	.4251	.4435	.4066	.4435	.4066
2	.3326	.3881	.3696	.3881	.3881	.4066	.3326
3		.3696	.4066	.3696	.3511	.3881	.2957
4		.3696	.3696	.4066	.3142	.3326	.2587
5		.4251	.4066	.4066	.3511	.3403	.2957
6	.3696	.4435	.4435	.4435	.4066	.3696	.3326
7	.4066	.462	.4435	.462	.4251	.3696	.3511
8	.462	.4805	.4251	.4435	.3881	.3696	.3881
9	.4435	.4805	.4435	.5544	.4435	.3881	.4066
10	.5359	.499	.4435	.4805	.4435	.3881	.3326
11	.3881	.462	.4066	.462	.462	.4435	.3511
12	.3696	.3511	.3881	.3881	.4435	.4066	.3696
13	.3511	.3881	.3696	.4066	.3881	.3881	.3142
14	.3511	.3511	.3881	.4066	.462	.3511	.3142
15	.3326		.3326	.3881	.3881	.3326	.2587
16	.3142	.3326	.3511	.3326	.3511	.3142	.2587
17	.3511	.2957	.3511	.3326	.3326	.3511	.2402
18	.3511	.3511	.4066	.3696	.3511	.3881	.3696
19	.4572	.499	.499	.5175	.7023	.5544	.5544
20	.5121	.5359	.5544	.5359	.7023	.6838	.5914
21	.4938	.5359	.499	.5359	.7023	.5914	.5914
22	.5121	.499	.5544	.5359	.7023	.5914	.5359
23	.5304	.5544	.5544	.5544	.7207	.5359	.5359
24	.3881	.439	.4805	.5359	.4435	.6838	.4066
Max	.5359	.5544	.5544	.5544	.7207	.6838	.5914
Min	.3142	.2957	.3326	.3326	.3142	.3142	.2402
Avg	.4106	.4321	.4297	.4458	.4612	.4338	.3788

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113521 / P.M.G.P. RECEIVING

Feeder No / Name : 210 / Gurupushyamrut

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.8688	1.0136	1.0136	.8688	.9231	.8688
2	.6878	.7964	.9412	.9412	.7964	.8869	.7783
3	.6516	.7421	.7783	.7964	.7421	.7964	.7421
4	.6154	.7059	.7602	.7602	.7059	.7602	.724
5	.6878	.724	.7783	.7964	.7059	.7783	.7783
6	.8326	.9412	.9593	.8688	.7964	.8145	.8326
7	1.0136	1.086	1.1041	.9593	.8869	.8688	.9231
8	1.0317	1.1222	1.1041	1.0136	1.0136	.9231	1.0498
9	1.086	1.2851	1.1403	1.1403	1.0136	1.0498	1.0498
10	.9231	1.1041	1.1222	1.1584	1.1584	1.1041	1.0498
11	.9593	1.0136	.9412	1.0317	1.0136	.9774	1.086
12	.9412	.905	.8869	.9955	.8869	1.0136	.9955
13	.9231	.905	.9774	.8688	.9134	.9774	.9231
14	.8326	.8869	.905	.7602	.8507	.8688	.8507
15	.7602	.7964	.8326	.724	.7964	.7964	.7602
16	.724	.8048	.8688	.6878	.7964	.7602	.724
17	.7421	.8145	.8507	.724	.8145	.8326	.724
18	.8869	.8326	.905	.905	.8507	.8688	.9231
19	1.0679	1.0136	1.086	1.0136	1.0317	1.086	1.0679
20	1.1765	1.1041	1.1403	1.0136	1.1222	1.1041	1.2127
21	1.1584	1.1403	1.1584	1.0498	1.1222	1.1222	1.1584
22	1.1584	1.1584	1.2308	1.0498	1.1041	1.1222	1.086
23	1.1765	1.2489	1.2308	1.0498	1.1222	1.1041	1.0317
24	.8507	.9774	1.086	1.1765	1.0136	1.0679	1.0679
Max	1.1765	1.2851	1.2308	1.1765	1.1584	1.1222	1.2127
Min	.6154	.7059	.7602	.6878	.7059	.7602	.724
Avg	.9005	.9574	.9917	.9374	.9219	.9420	.9337

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

NEELAM NAGAR S/DN.[705] BU 4705

Substation No/ Name :- 113521 / P.M.G.P. RECEIVING

Feeder No / Name : 211 / Navghar HTP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1294	.1294	.1478	.1294	.1478	.1294	.1478
2	.1294	.1109	.1478	.1294	.1294	.1294	.1478
3	.1294	.1109	.1294	.1294	.1109	.1294	.1294
4	.1109	.1109	.1294	.1109	.1294	.1109	.1109
5	.1294	.1294	.1294	.1294	.1478	.1294	.1109
6	.1294	.1294	.1478	.1294	.1478	.1294	.1294
7	.1294	.1294	.1478	.1478	.1663	.1294	.1478
8	.1478	.1478	.1478	.2218	.1478	.1294	.1294
9	.1663	.1663	.1478	.2033	.1478	.1294	.1478
10	.1478	.1478	.1663	.1848	.1848	.1663	.1848
11	.1478	.1294	.1478	.1663	.2033	.1478	.1663
12	.1294	.1294	.1663	.1663	.1294	.1848	.1294
13	.1294	.1294	.1294	.1294	.1294	.1663	.1663
14	.1294	.1294	.1478	.1478	.1294	.1478	.1294
15	.1294	.1294	.1294	.1478	.1294	.1478	.7602
16	.1294	.1294	.1478	.1294	.1294	.1294	.1294
17	.1294	.1294	.1294	.1294	.1294	.1294	.1294
18	.1294	.1478	.1294	.1478	.1294	.1478	.1294
19	.1294	.1294	.1294	.1478	.1663	.1478	.1294
20	.1478	.1478	.1663	.1478	.1448	.1478	.1478
21	.1478	.1478	.1848	.1663	.1848	.1663	.1294
22	.1478	.1478	.1663	.1478	.1848	.1478	.1478
23	.1848	.1478	.1848	.1478	.1663	.1478	.1478
24	.1294	.1478	.1478	.1848	.1294	.1478	.1294
Max	.1848	.1663	.1848	.2218	.2033	.1848	.7602
Min	.1109	.1109	.1294	.1109	.1109	.1109	.1109
Avg	.1371	.1348	.1478	.1509	.1477	.1425	.1649

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 113021 / LOK EVEREST

Feeder No / Name : 201 / ACC

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8131	1.0164	1.0456	1.0164	1.0719	.8775
2		.7762	.961		.961	1.0349	.8402
3		.7577	.924	.9149	.8962	.9795	.7842
4		.7392	.8316		.8316	.924	.7468
5		.7392	.7762	.7842	.7392	.8316	.8402
6	.7392	.8131	.7392		.8316	.7392	.9335
7	.9425	.9795	.8686	1.0642	.9425	.7762	1.0269
8	1.0719	1.0719	.9979	1.1458	1.0349	.9709	1.1016
9	1.2883	1.3306	1.2936	1.2752	1.3306	1.1203	1.419
10	1.7372	1.7372		1.2197	1.5708	1.2136	1.7187
11		1.885	2.0513	1.3121	1.7187		1.9959
12	1.7002		1.8111	1.2197	1.6817	1.3443	1.8665
13	1.6817	1.6817	1.7364	1.2382	1.4784	1.1576	1.7002
14	1.5708	1.6632	1.6263	1.0164	1.3491	1.0829	1.6632
15	1.6817	1.7187	1.7556	.9979	1.2752	1.1203	1.5708
16		1.6817	1.7187	.9425	1.2752	1.2136	1.5339
17		1.6263		.9979	.8808	1.1949	1.4415
18	1.423	1.6263	1.531	.961	1.2012	1.1576	1.5524
19	1.4045	1.4784	1.4937	1.0534	1.2197	1.1389	1.5339
20	1.2936	1.3676		1.2197	1.1827	1.2323	1.3676
21	1.2567	1.3306	1.2936	1.1273	1.1643	1.1949	1.2012
22	1.1827	1.2197		1.1273	1.0719	1.1203	1.1643
23	1.1273	1.1827		1.1088	1.0903		1.0534
24	.8686	.9979	1.0719		1.0534	1.1088	
Max	1.7372	1.885	2.0513	1.3121	1.7187	1.3443	1.9959
Min	.7392	.7392	.7392	.7842	.7392	.7392	.7468
Avg	1.3106	1.2703	1.2894	1.0886	1.1582	1.0786	1.3015

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 113021 / LOK EVEREST

Feeder No / Name : 202 / LOK KAILASH SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5335	.6099	.5359	.5544	.6099	.4435
2		.4805	.5914		.5175	.5729	.4066
3		.4435	.5544	.4435	.4805	.5359	.3696
4		.4066	.5175		.4435	.499	.3696
5		.4066	.4805	.3881	.4066	.462	.4066
6	.462	.462	.5175		.499	.4805	.462
7	.5544	.5914	.5729	.4251	.5544	.5175	.5175
8	.6838	.7392	.6283	.5544	.6283	.5914	.5544
9	.8316	.8215	.924	.6283	.7762	.7577	.7392
10	1.0349	1.2197		.8131	1.0534	.8316	1.0903
11		1.448	1.1643	.9979	1.1273		1.2936
12	1.3121		1.3121	.9979	1.2382	1.0349	1.2567
13	1.1827	1.3676	1.2382	.924	1.1088	.9979	1.2382
14	1.2936	1.3306	1.2936	.8501	1.0719	.961	1.1458
15		1.3306	1.2752	.7762	1.1827	.9979	1.1273
16		1.3306	1.2382	.8686	1.1273	1.0349	1.1458
17		1.423		.8131	1.0534	1.0903	1.1643
18	1.4784	1.5154	1.2936	.9055	1.1458	1.1273	1.3491
19	1.4415	1.5154	1.3676	.9979	1.2752	1.1643	1.46
20	1.3491	1.423		.961	1.2197	1.1643	1.2936
21	1.2384	1.2382	1.0719	.961	1.0164	.9055	1.0534
22	.8871	.8501		.6838	.7577	.6099	.7392
23	.6283	.7023		.6099	.6838		.5914
24		.5544	.6468		.5914	.6468	
Max	1.4784	1.5154	1.3676	.9979	1.2752	1.1643	1.46
Min	.462	.4066	.4805	.3881	.4066	.462	.3696
Avg	1.0270	.9623	.9104	.7568	.8547	.7997	.8790

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 113021 / LOK EVEREST

Feeder No / Name : 204 / CITY OF JOY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1088	1.4784	1.4784	1.386	1.386	1.2382
2		1.0164	1.4415		1.3306	1.3306	1.1949
3		.961	1.386	1.2936	1.2382	1.2752	1.1088
4		.924	1.3121		1.1458	1.2012	1.0534
5		.9055	1.2012	1.1088	1.0164	1.0164	1.1458
6	.8871	1.0164	1.2936		1.1088	.9795	1.2567
7	1.1088	1.423	1.386	1.2567	1.2936	1.0903	1.3306
8	1.386	1.5339	1.46	1.46	1.386	1.3121	1.46
9	1.3306	1.4784	1.4784	1.6632	1.5154	1.5708	1.5339
10	1.3306	1.467		1.6632	1.4784	1.5154	1.6617
11		1.3717	1.423	1.5893	1.5154		1.5154
12	1.1458		1.2567	1.3306	1.423	1.423	1.4045
13	1.2012	1.1273	1.2567	1.2197	1.2567	1.386	1.3121
14	1.0534	1.2012	1.2012	1.2012	1.2197	1.2012	1.1827
15		1.0903	1.2197	1.0719	1.1458	1.2696	1.1273
16		1.0534	1.0719	.9979	1.0719	1.3121	.9795
17		1.0164		1.0719	1.1458	1.3491	.924
18	.8871	1.0534	1.2197	1.1458	1.1088	1.386	1.1458
19	1.0534	1.2752	1.3676	1.3121	1.2936	1.423	1.3306
20	1.2567	1.3676		1.3676	1.4415	1.5339	1.4415
21	1.386	1.5154	1.6078	1.4415	1.46	1.6078	1.4784
22	1.4784	1.5154		1.4415	1.386	1.5524	1.3676
23	1.4415	1.5154		1.4969	1.46		1.46
24	1.1088	1.3306	1.5154		1.423	1.4415	
Max	1.4784	1.5339	1.6078	1.6632	1.5154	1.6078	1.6617
Min	.8871	.9055	1.0719	.9979	1.0164	.9795	.924
Avg	1.2037	1.2290	1.3462	1.3306	1.3021	1.3438	1.2893

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 113021 / LOK EVEREST

Feeder No / Name : 205 / NEW SHANTI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3921	.4066	.5041	.5975	.4481	.5415	.4435
2	.3547	.4066	.4854		.4108	.5228	.4066
3	.3361	.3881	.4668	.5041	.3734	.5041	.3696
4	.3361	.3696	.4481		.3361	.4854	.3511
5	.3174	.3881	.4108	.4294	.3174	.3734	.3511
6	.3734	.4435	.4668		.4108	.4108	.4251
7	.4294	.5544	.5228	.5729	.4668	.4481	.499
8	.4854	.5914	.5601	.5601	.5415	.6535	.6099
9	.9335	.924	.9896	.6348	.6722	.7095	.7947
10	1.4003	1.4098		.7842	1.2323	.7282	1.2136
11		1.7147	1.6057	.8249	1.251		1.475
12	1.4415		1.643	.8215	1.251	.9149	1.4937
13	1.251	1.3817	1.3256	.7095	1.1203	.7842	1.2323
14	1.4784	1.5123	1.5684	.6722	1.0642	.7947	1.2696
15	1.5123	1.6057	1.475	.7468	1.0456	.8402	1.2696
16		1.531	1.4937	.7095	1.1949	.8029	1.2696
17		1.531		.6535	1.1203	.7468	1.251
18	1.3676	1.475	1.2936	.7095	1.0082	.7023	1.1763
19	1.1827	1.1949	1.1763	.7842	.8215	.6468	.9709
20	.9055	1.0082		.6535	.8215	.6283	.8215
21	.7392	.7655	.7282	.5601	.6535	.5914	.6535
22	.5914	.5228		.5601	.5788	.6099	.5415
23	.5729	.5618		.4854	.4854		.4668
24	.4108	.462	.5228		.4854	.5601	
Max	1.5123	1.7147	1.643	.8249	1.251	.9149	1.4937
Min	.3174	.3696	.4108	.4294	.3174	.3734	.3511
Avg	.8006	.9195	.9309	.6487	.7546	.6364	.8415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 113021 / LOK EVEREST

Feeder No / Name : 206 / GALA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6348	.7049	.743	.6097	.6668	.6097
2		.5914	.6668		.5716	.6287	.5716
3		.5716	.6287	.6478	.5335	.5716	.5144
4		.5335	.5716		.4954	.4763	.4763
5		.5525	.5335	.5716	.4572	.381	.5335
6	.5716	.6478	.6097		.5335	.4763	.5847
7	.6287	.8383	.7049	.6668	.5716	.5716	.6413
8	.724	.8002	.7811	.724	.6097	.6478	.724
9	1.1241	1.2384	1.105	.724	.9526	1.0479	1.1622
10	1.3336	1.4289		.8192	1.086	1.1812	1.3908
11		1.5242	1.448	.8002	1.2193		1.3527
12	1.2936		1.4098	.8383	1.086	1.1622	1.4289
13	1.0098	1.1431	1.1431	.724	.9526	1.105	1.105
14	1.1827	1.2384	1.3717	.6478	.9717	1.086	1.2193
15		1.4289		.6668	.9335	1.0479	1.2193
16		1.3717		.6478	.8192	1.0098	1.3336
17		1.3336		.6478	.8954	.9526	1.2003
18	1.1827	1.2574	1.1241	.6478	.8764	.8954	1.1241
19	1.0719	1.086	1.0669	.743	.9526	.8573	1.105
20	1.0349	1.105		.7621	.9526	.8002	1.1241
21	.8764	.8764	.8383	.7621	.8954	.7621	.8764
22	.7947	.8192		.7049	.8002	.7811	.724
23	.8299	.8383		.6859	.7621		.7621
24	.6668	.7356	.724		.6478	.7049	
Max	1.3336	1.5242	1.448	.8383	1.2193	1.1812	1.4289
Min	.5716	.5335	.5335	.5716	.4572	.381	.4763
Avg	.9550	.9824	.9078	.7087	.7994	.8097	.9471

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 113021 / LOK EVEREST

Feeder No / Name : 207 / SANT DYNESHWAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9055	1.0791	1.1458	1.0974	1.0974	1.0164
2		.8686	1.0425		1.0425	1.0608	.9795
3		.8316	1.0059	1.0349	.9877	.9694	.924
4		.7762	.9328		.9145	.9145	.8686
5		.7762	.8596	.9055	.823	.823	.8316
6	.7316	.8316	.7682		.8596	.8596	.9055
7	.8596	.961	.8779	.924	1.0059	.9328	.9979
8	1.0059	1.0349	.9145	1.0791	1.134	1.0164	1.0534
9	1.0242	1.1273	1.134	1.134	1.2437	1.1273	1.1458
10	1.134	1.3306		1.2254	1.4002	1.1827	1.4969
11		1.2936	1.2254	1.2803	1.3352		1.4266
12	1.1827		1.3352	1.134	1.2986	1.2567	1.4266
13	1.1888	1.2071	1.2752	1.0974	1.2331	1.2197	1.2986
14	1.0719	1.262	1.2437	1.0608	1.1888	1.0349	1.1523
15		1.2071	1.2071	.9145	1.134	1.1088	1.1523
16		1.2254	1.1888	.9145	1.0974	1.1643	1.1523
17		1.2803		.9511	1.0242	1.2197	1.2254
18	1.2012	1.1888	1.2936	1.0059	1.1523	1.2567	1.3169
19	1.3491	1.39	1.4045	1.1523	1.3169	1.2936	1.4083
20	1.3121	1.3352		1.2437	1.2437	1.2936	1.4266
21	1.2567	1.3169	1.3676	1.2254	1.2803	1.2752	1.3352
22	1.2012	1.2437		1.134	1.1523	1.1643	1.2071
23	1.1643	1.2071		1.1888	1.134		1.134
24	.8596	1.0349	1.1157		1.134	1.0974	
Max	1.3491	1.39	1.4045	1.2803	1.4002	1.2936	1.4969
Min	.7316	.7762	.7682	.9055	.823	.823	.8316
Avg	1.1029	1.1146	1.1195	1.0876	1.1347	1.1077	1.1688

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 113021 / LOK EVEREST

Feeder No / Name : 208 / OLD RAM GOPAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0669	1.1431	1.2384	.7621	1.0098	.9526
2		.9979	1.105		.724	.9526	.8865
3		.961	1.0479	1.0479	.6859	.8573	.811
4		.924	.9717		.6478	.7621	.7621
5		.9979	.8954	.8573	.6097	.6668	.8383
6	.8954	1.0719	.9717		.6478	.7621	.9335
7	.9907	1.1088	1.105	.9907	.7621	.8002	1.0098
8	1.1812	1.2012	1.2574	.9145	.8764	.9717	1.094
9	1.8671	1.8111	1.9433	.8954	1.2574	1.3336	1.7541
10	2.4768	2.4768		.9526	1.7337	1.3717	2.191
11		2.5873	2.7435	.9907	1.8861		2.8006
12	2.5133		2.6292	1.0669	1.9624	1.6004	2.6292
13	2.1338	2.2481	2.2672	1.0669	1.6575	1.4098	2.1719
14	2.2177	2.5149	2.4006	.9907	1.6956	1.3527	2.2291
15		2.4577	2.6292	.9526	1.6766	1.3769	2.5149
16		2.4768	2.553	.9907	1.6575	1.3203	2.572
17		2.3434		.9526	1.6194	1.2574	2.3243
18	2.2916	2.1529	2.3053	.8764	1.6766	1.2003	2.191
19	2.0698	1.8861	2.0195	.9526	1.3717	1.1622	1.9814
20	1.7353	1.7909		.8764	1.2384	1.086	1.7147
21	1.2574	1.2574	1.2826	.8002	1.0098	.8764	1.1241
22	1.2197	1.2574		.7049	1.0288	.9145	1.1812
23	1.0719	1.1812		.8002	1.0479		1.1431
24	1.0479	1.0456	1.1812		.8002	1.0479	
Max	2.5133	2.5873	2.7435	1.2384	1.9624	1.6004	2.8006
Min	.8954	.924	.8954	.7049	.6097	.6668	.7621
Avg	1.6646	1.6442	1.7080	.9459	1.2098	1.0951	1.6439

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 113021 / LOK EVEREST

Feeder No / Name : 301 / 22 KV RUNWAL ANTHURIAM NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 22 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.7095
6	.8495						
7	.8383		.7621		.8764		
8	.8764		.7621		1.6073	.6722	.8215
9	.9526		.8299	1.7748	.8383		
10	.9526			.9526	.8764		
11			.8764	.8383	.8764		.9526
12	.8876	.8383	.8764	.8383	.8383	.8962	1.8167
13				1.5966	.8383		.9526
14		.724	1.4908	.8764	.8299		.9526
15				.8383			.6413
16		1.4618	.7621	1.4848			1.5234
17		.884		.6097	1.3687		.724
18		1.6205	.7316	.7621	1.3863		1.4675
19		.9526	.8189	1.6293	.7621	.8589	1.1812
20		1.7248		.8383	.8383	.8215	1.448
21		.8383		.8383	.8383		1.448
22		1.8242		.8383	.8383		1.3336
23		.9145		1.6556	.8764		1.3717
24	.0112	.724	.8764		.8383	.8764	
Max	.9526	1.8242	1.4908	1.7748	1.6073	.8962	1.8167
Min	.0112	.724	.7316	.6097	.7621	.6722	.6413
Avg	.7669	1.137	.8787	1.0914	.958	.8250	1.1563

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 113039 / RUNWAL ANTHURIAM

Feeder No / Name : 201 / RAMONA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8				.0453	
9			.048		
12					.0468
13			.0645		
14		.0308			
16	.037		.0434		.025
17				.0431	
18	.0409	.0315		.0404	.0463
19		.0203	.0538		
20	.0454				
22	.0307				
23			.0504		
Max	.0454	.0315	.0645	.0453	.0468
Min	.0307	.0203	.0434	.0404	.025
Avg	.0385	.0275	.0520	.0429	.0394

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 113039 / RUNWAL ANTHURIAM

Feeder No / Name : 202 / GEMINI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8				.7473	
9			.8242		
12					.7738
13			.6979		
14		.3381			
16	.3118		.578		.6481
18	.6225	.3189		.6219	.618
19		.872	.783		
20	.0183				
22	.0081				
23			.8075		
Max	.6225	.872	.8242	.7473	.7738
Min	.0081	.3189	.578	.6219	.618
Avg	.2402	.5097	.7381	.6846	.6800

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 113039 / RUNWAL ANTHURIAM

Feeder No / Name : 203 / R SQUARE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8				.0223	
9			.0092		
12					.0721
13			.027		
14		.0654			
16	.0483		.0245		.0662
18		.0302		.0275	.0274
19	.043	.0541	.0104		
23			.0086		
Max	.0483	.0654	.027	.0275	.0721
Min	.043	.0302	.0086	.0223	.0274
Avg	.0457	.0499	.0159	.0249	.0552

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 283071 / PANCHPAKHADI REC STN

Feeder No / Name : 202 / HUGALI-I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6335	.6626	.7059	.6516	.6697	.6697
2		.5792	.591	.6878	.5792	.6154	.6516
3		.5249	.5552	.5792	.5249	.5611	.5792
4		.4525	.5014	.543	.4887	.5068	.543
5		.5068	.5373	.5973	.4344	.4706	.5792
6		.5973	.591	.6335	.4706	.543	.6154
7		.7059	.6805	.6878	.543	.5973	.6516
8		.724	.8238	.724	.5973	.6878	.7783
9		.8869	.9671	.7783	.7421	.6878	.905
10		1.0317	1.0924	.9593	.9412	.8326	1.0498
11	1.1403	1.086	1.2357	.8507	.9955	.905	1.1222
12	.9955	1.1946	1.1283	.7783	.9774	.8507	1.0679
13	.9671	1.0136	1.0029	.724	.9412	.8869	.9774
14	.9593	1.0498	1.0029	.7421	.8326	.8326	.9231
15	.9231	1.0317	1.0029	.6878	.8688	.7421	.9955
16	.905	.905	.9492	.6516	.724	.6878	.9412
17	.8688	.9412		.6878	.6878	.6878	.905
18	.8869	.8688	1.0029	.7602	.7602	.7421	.7964
19	.8869	.8688	.8954	.8688	.7602	.8688	.8688
20	.8869	.905	.8954	.8869	.8326	.9231	.8869
21	.8145	.8326	.8775	.8326	.8326	.8869	.8326
22	.8145	.8507	.8596	.8869	.8145	.8145	.7964
23	.7783	.7964	.8059	.8145	.7964	.7964	.7783
24		.6878	.6984	.5731	.7421	.7602	.7783
Max	1.1403	1.1946	1.2357	.9593	.9955	.9231	1.1222
Min	.7783	.4525	.5014	.543	.4344	.4706	.543
Avg	.9098	.8198	.8417	.7351	.7308	.7315	.8205

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 283071 / PANCHPAKHADI REC STN

Feeder No / Name : 204 / DENTAL PRODUCT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3944	.3772	.4115	.3772	.4115	.4115
2		.3601	.3258	.3944	.3429	.3944	.4115
3		.3429	.3086	.3772	.2915	.3601	.3772
4		.3772	.2743	.3772	.3086	.3258	.3772
5		.4287	.3601	.4115	.3258	.3429	.3944
6		.463	.4287	.4458	.3601	.3772	.4115
7		.5144	.4973	.4973	.3944	.4287	.4458
8		.5144	.4801	.4458	.4458	.4458	.4458
9		.4973	.4801	.5316	.463	.4458	.5144
10		.463	.4458	.5658	.4287	.4801	.4801
11	.4115	.463	.3944	.4801	.4801	.5144	.4458
12	.4287	.3772	.3258	.4115	.4287	.4115	.4115
13	.3944	.3429	.3601	.3429	.3944	.4115	.3772
14	.3258	.3258	.3258	.3429	.3258	.3601	.3601
15	.3086	.3258	.3258	.3258	.3086	.3258	.3258
16	.2915	.2743	.3772	.3258	.3429	.3258	.3086
17	.3086	.3086		.3429	.3772	.3086	.3258
18	.3086	.3086	.3258	.3601	.3086	.3772	.3601
19	.3601	.3772	.3944	.463	.4458	.4115	.3944
20	.4287	.4801	.4458	.4287	.4287	.4458	.4458
21	.463	.4801	.463	.463	.4458	.463	.4458
22	.4801	.4973	.5316	.4458	.463	.4973	.4801
23	.4801	.4801	.463	.463	.4115	.463	.4458
24	.3601	.4287	.4115	.4115	.4115	.4115	.463
Max	.4801	.5144	.5316	.5658	.4801	.5144	.5144
Min	.2915	.2743	.2743	.3258	.2915	.3086	.3086
Avg	.3772	.4094	.3966	.4194	.3879	.4058	.4108

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 283071 / PANCHPAKHADI REC STN

Feeder No / Name : 205 / DEEVECHA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2865	.2865	.3045	.2865	.2865	.2507
2		.2686	.2865	.2686	.2686	.2507	.2149
3		.2507	.2686	.2507	.2507	.2149	.2149
4		.2686	.2328	.2507	.2328	.2328	.2149
5		.2686	.2149	.2865	.2507	.2328	.2507
6		.3045	.2507	.3045	.2507	.2507	.2865
7		.3224	.2865	.3403	.2686	.2865	.3224
8		.3045	.3403	.3761	.2865	.2507	.3761
9		.3761	.3224	.3582	.4119	.3224	.3582
10		.3582	.394	.3403	.3761	.3582	.394
11	.4119	.3761	.4477	.3761	.394	.3045	.4119
12	.3761	.394	.4298	.3045	.394	.3403	.394
13	.3582	.3403	.3761	.3403	.4119	.3582	.3761
14	.3582	.3403	.3582	.3045	.3403	.3224	.3582
15	.3582	.3045	.2865	.2865	.3224	.3045	.3403
16	.3403	.3224	.3761	.2686	.3045	.2865	.3045
17	.3045	.2865		.2686	.3224	.2865	.2865
18	.2686	.2328	.2865	.2865	.2507	.2865	.2865
19	.3045	.2865	.3045	.3403	.2865	.3403	.3224
20	.3045	.3224	.3224	.3224	.2865	.3403	.3761
21	.3224	.3224	.3224	.3224	.2865	.3582	.3761
22	.3224	.3224	.3403	.3224	.3224	.3761	.3761
23	.3403	.3224	.3403	.3224	.3045	.3582	.3582
24		.3045	.3045	.3045	.3045	.2865	.3224
Max	.4119	.394	.4477	.3761	.4119	.3761	.4119
Min	.2686	.2328	.2149	.2507	.2328	.2149	.2149
Avg	.3362	.3119	.3208	.3104	.3089	.3015	.3239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 283071 / PANCHPAKHADI REC STN

Feeder No / Name : 206 / S H KELKAR SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9955	1.3756	1.1765	1.5023	1.3575	1.4118	1.1222
2		1.3032	1.086	1.2308	1.267	1.2308	1.1222
3		1.2127	1.0136	1.1403	1.2127	1.1765	.9955
4		1.1222	.9593	1.086	1.1222	1.086	.9412
5		1.267	1.086	1.1946	1.2489	1.0317	.9774
6		1.4299	1.4118	1.3575	1.3756	1.0679	1.086
7		1.5927	1.6289	1.5023	1.448	1.1222	1.2127
8		1.647	1.5565	1.5927	1.5203	1.1946	1.4842
9		1.9185	1.7194	1.7194	1.7375	1.3937	1.7013
10		2.0271	1.9547	1.8461	1.828	1.6289	1.7013
11	1.7737	1.8642	1.7375	1.6108	1.7194	1.5565	1.5746
12	1.5746	1.7013	1.6289	1.5384	1.5203	1.6289	1.4661
13		1.7013	1.6108	1.448	1.5203	1.3937	1.3937
14	1.6651	1.7013	1.4842	1.267	1.5565	1.3575	1.2851
15	1.5565	1.5746	1.4661	1.2308	1.448	1.1584	1.3394
16	1.448	1.448	1.5384	1.1946	1.3756	1.2851	1.2851
17	1.3756	1.4118		1.2127	1.1946	1.1403	1.1041
18	1.2851	1.2489	1.2851	1.2489	1.267	1.4118	1.2308
19	1.4299	1.4118	1.3756	1.3575	1.4299	1.3937	1.3213
20	1.3213	1.448	1.448	1.4842	1.4118	1.4842	.7602
21	1.5023	1.5565	1.5746	1.448	1.448	1.4661	.7783
22	1.5927	1.5384	1.5565	1.3937	1.4842		.724
23	1.5203	1.4842	1.7556	1.3575	1.5565	1.5927	.7602
24	1.3032	1.448	1.3575	1.647	1.4299	1.5203	1.267
Max	1.7737	2.0271	1.9547	1.8461	1.828	1.6289	1.7013
Min	.9955	1.1222	.9593	1.086	1.1222	1.0317	.724
Avg	1.4531	1.5181	1.4527	1.4005	1.4367	1.3362	1.1931

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 283071 / PANCHPAKHADI REC STN

Feeder No / Name : 207 / TRIDEV

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7701	1.0029	.985	1.0679	1.086	1.0317
2		.9313	.9134	1.0136	1.0136	.9774
3		.8775	.8417	.9412	.9412	.9412
4		.8059	.788	.8145	.8688	.8869
5		.8596	.8596	.8507	.905	.8326
6		.9134	.8954	.905	.9593	.8507
7		.985	.985	.9593	.9955	.905
8		1.0208	1.1641	1.0679	1.0317	1.0136
9		1.1641	1.1641	1.1765	1.2127	1.0679
10		1.2178	1.2357	1.3394	1.267	1.1946
11	1.1999	1.182	1.2894	1.2489	1.1946	1.2308
12	1.1283	1.182	1.182	1.1222	1.0498	1.1946
13		1.1462	1.0745	1.0317	1.0498	1.086
14	1.0924	1.0745	1.0924	.9955	.9774	.9231
15	1.0387	1.0029	1.0566	.9231	.9412	.8869
16	.985	1.0029	1.0029	.8688	.9412	.9231
17	.9313	1.0029		.8688	.8688	.8869
18	.9671	1.0566	1.0208	.9955	.9412	.9955
19	1.0745	1.1641	1.182	1.1584	1.1403	1.1403
20	1.2178	1.182	1.182	1.1584	1.1765	1.2308
21	1.2178	1.2178	1.2894	1.1946	1.1946	1.1765
22	1.2178	1.2715	1.2536	1.2127	1.2308	
23	1.182	1.2536	1.2357	1.1765	1.2308	
24	.9134	1.0924	1.0745	1.1999	1.1584	1.1222
Max	1.2178	1.2715	1.2894	1.3394	1.267	1.2308
Min	.7701	.8059	.788	.8145	.8688	.8326
Avg	1.0669	1.0671	1.0769	1.0538	1.0573	1.0227

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 283071 / PANCHPAKHADI REC STN

Feeder No / Name : 208 / TATA FISION

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4572	.5304	.4938	.5487	.5121	.4938
2		.4024	.4572	.5121	.5121	.4572	.439
3		.3658	.4207	.4572	.4572	.4572	.4024
4		.3841	.3841	.439	.4024	.4207	.4024
5		.4207	.4207	.4572	.3658	.4024	.439
6		.4938	.439	.4755	.4207	.439	.4572
7		.5487	.4938	.5121	.4572	.439	.4938
8		.5121	.5121	.5304	.4938	.5121	.5121
9		.6036	.6219	.6584	.5487	.5487	.6219
10		.6584	.6584	.6036	.6584	.5853	.6584
11	.5487	.6219	.6036	.6401	.7316	.6584	.6767
12	.6401	.6584	.6401	.695	.6584	.5487	.695
13	.567	.5487	.6036	.5304	.5853	.5304	.6036
14	.4755	.4755	.567	.4755	.4755	.4938	.5304
15	.4572	.4755	.5487	.4572	.4755	.4755	.4938
16	.4938	.4755	.4938	.4207	.4755	.4572	.4938
17	.5304	.4755		.4755	.5121	.5121	.4755
18	.567	.5487	.5121	.5304	.5487	.5304	.567
19	.6219	.5853	.6036	.6219	.6219	.6584	.6219
20	.6036	.6584	.6401	.6219	.6584	.6767	.695
21	.695	.6219	.695	.6401	.6219	.695	.6401
22	.567	.6584	.695	.5853	.567	.6036	.6036
23	.5487	.6219	.695	.5853	.6219	.567	.5853
24		.5121	.5853	.6219	.6036	.5487	.5487
Max	.695	.6584	.695	.695	.7316	.695	.695
Min	.4572	.3658	.3841	.4207	.3658	.4024	.4024
Avg	.5628	.5327	.5574	.5434	.5426	.5304	.5479

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 283071 / PANCHPAKHADI REC STN

Feeder No / Name : 209 / YOGI HILL SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3756	1.5023	1.6644	1.4632	1.4998	1.3717
2		1.3032	1.4299	1.4449	1.39	1.3717	1.2437
3		1.1765	1.3032	1.2437	1.3169	1.2803	1.1523
4		1.1222	1.2308	1.1888	1.2803	1.2254	1.0974
5		1.2489	1.1403	1.2254	1.2437	1.134	1.134
6		1.3575	1.267	1.2803	1.3169	1.1706	1.1888
7		1.448	1.4842	1.3535	1.3535	1.2071	1.3352
8		1.647	1.4842	1.5364	1.4083	1.3535	1.4632
9		1.7194	1.7013	1.7741	1.701	1.5364	1.6827
10		1.7013	1.8099	1.8839	1.957	1.6461	1.7741
11	1.7556	1.7013	1.7918	1.8839	1.829	1.6827	1.8107
12	1.6832	1.7013	1.7194	1.6827	1.6461	1.7558	1.7924
13	1.448	1.448	1.5565	1.4632	1.5364	1.6461	1.6095
14	1.3394	1.4842	1.5746	1.3535	1.5364	1.4266	1.4449
15	1.3032	1.3032	1.4661	1.2803	1.4632	1.3717	1.4083
16	1.3394	1.4118	1.4842	1.2437	1.4266	1.2803	1.4083
17	1.3575	1.3756		1.2986	1.4266	1.2437	1.3535
18	1.3937	1.4118	1.3213	1.4083	1.4632	1.4998	1.4083
19	1.4842	1.3756	1.448	1.6827	1.5729	1.4998	1.5546
20	1.5746	1.4842	1.6289	1.5729	1.6461	1.5729	1.6278
21	1.5203	1.6651	1.5927	1.5729	1.6095	1.5546	1.4998
22	1.7375	1.7375	1.6832	1.6278	1.6461	1.6278	1.5912
23	1.6289	1.6289	1.7556	1.5364	1.6095	1.6095	1.5729
24		1.4842	1.5565	1.6651	1.5181	1.5729	1.5912
Max	1.7556	1.7375	1.8099	1.8839	1.957	1.7558	1.8107
Min	1.3032	1.1222	1.1403	1.1888	1.2437	1.134	1.0974
Avg	1.5050	1.4713	1.5188	1.4945	1.5150	1.4487	1.4632

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

PACH RASTA S/DN.[704] BU 4704

Substation No/ Name :- 283071 / PANCHPAKHADI REC STN

Feeder No / Name : 210 / SAPTERSHI SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3391	.373	.4409	.407	.407	.4578
2		.3052	.3222	.373	.373	.373	.407
3		.2883	.2883	.3391	.3391	.3391	.373
4		.2713	.2713	.3391	.2883	.3391	.3391
5		.3052	.2543	.3391	.2713	.2883	.3561
6		.3222	.3222	.3561	.3052	.2713	.373
7		.39	.4409	.373	.3222	.2883	.373
8		.4748	.4409	.407	.3391	.373	.39
9		.5596	.6104	.5087	.373	.4578	.5087
10		.5765	.5596	.5426	.5087	.4748	.5765
11	.4748	.5087	.5596	.5087	.4917	.4409	.5256
12	.2883	.4748	.5426	.4748	.4409	.407	.4409
13	.3052	.4578	.4578	.407	.407	.4578	.4917
14	.407	.4409	.4748	.39	.407	.373	.3561
15	.39	.4409	.4409	.373	.407	.373	.7461
16	.373	.39	.39	.3391	.39	.373	.5935
17	.3561	.3391		.3222	.3561	.3391	.5596
18	.3391	.3391	.407	.3391	.3391	.4578	.5935
19	.3391	.407	.407	.39	.4409	.4578	.7122
20	.373	.4239	.4239	.407	.4409	.4239	.763
21	.4578	.4239	.4578	.407	.4409	.39	.8309
22	.4409	.4578	.4409	.4409	.4578	.4239	.78
23	.4578	.4409	.4917	.4578	.4409	.4917	.763
24		.39	.407	.5256	.4409	.407	.5256
Max	.4748	.5765	.6104	.5426	.5087	.4917	.8309
Min	.2883	.2713	.2543	.3222	.2713	.2713	.3391
Avg	.3848	.4070	.4254	.4084	.3928	.3928	.5348

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113013 / 22/11 KV SARVODAYA

Feeder No / Name : 201 / MHADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-AUG-17
HR	Load (MW)
12	2.3045
13	.5487
Max	2.3045
Min	.5487
Avg	1.4266

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113013 / 22/11 KV SARVODAYA

Feeder No / Name : 202 / MAASHPURAM SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6767	.7499		.7316		.7682
2		.6584	.6584		.6584		.6584
3	.567	.6036	.6401		.6219		.6401
4		.5853	.6219		.6219	.6401	.6036
5		.6584	.6219		.6219	.9877	.6219
6		.7316	.7133		.7499	.695	.695
7	.7499	.8779	.8413		.8048	.7865	.695
8		.9145	.9511	.8676	.8962	.823	.9328
9	1.0608	1.1706	1.0791	.9694	.9694	.9511	1.0974
10	1.0608	1.0791	1.134	.9328		1.134	1.1523
11	1.1157	1.0791	1.1706	.9145		1.0791	1.2437
12	1.0242	1.0242	1.1157	.8962	1.0974	1.0608	1.1888
13	1.0974	.9877	1.1157	.8413	.9511	1.0608	1.1157
14	.9328	.9877	.9328	.7865		.8962	.9511
15	.9328	.9145	.9145	.7133		.8962	.8962
16	.8962		.8962	.6584		.8596	.8779
17	.8596	.9328	.8596	.6767		.8962	.9145
18		.8596		.7316		.8596	.8779
19	1.0242	.9145		.8779		.9328	.9145
20	.9328	.9511		.8596		.9328	.9145
21	.9145	.9694		.9145		.9145	.9328
22	.8779	.9694		.8596		.8962	.8962
23	.9328	.9511		.8596		.9328	.823
24	.6767	.823	.8962	1.0185	.823	.8596	.8779
Max	1.1157	1.1706	1.1706	1.0185	1.0974	1.134	1.2437
Min	.567	.5853	.6219	.6584	.6219	.6401	.6036
Avg	.9209	.8835	.8840	.8458	.7956	.9093	.8871

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113013 / 22/11 KV SARVODAYA

Feeder No / Name : 203 / UDYOGKSHETRA SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3109	.3109		.3109		.2926
2		.2743	.2743		.2926		.2743
3	.2896	.2743	.2743		.2926		.2743
4		.2926	.2743		.2926	.2926	.2561
5		.2926	.2743		.2926	.2926	.2561
6		.3109	.2926		.2926	.2926	.2926
7	.3077	.2926	.2926		.2926	.2926	.2926
8		.3841	.3109	.3395	.2743	.2743	.3109
9	.4938	.439	.5487	.3841	.4024	.2743	.5121
10	.7316	.724	.8596	.4207		.3292	.823
11	.7316	.8962	.7499	.3658		.3475	.8596
12	.7499	.7499	.8413	.3475	.5249	.4024	.8048
13	.6219	.7499	.7133	.3475	.4572	.3658	.7316
14	.567	.6401	.6584	.3841		.3841	.695
15	.6584	.695	.695	.3475		.2926	.7499
16	.7316		.7316	.2926		.3109	.7865
17	.695	.7316	.7316	.3109		.3109	.7133
18		.6767		.3109		.3841	.6767
19	.5487	.5853		.3658		.3841	.4755
20	.439	.4572		.3658		.3841	.4572
21	.4207	.4938		.3658		.3841	.439
22	.4207	.439		.3658		.4024	.439
23	.4024	.4207		.4024		.4024	.4207
24	.2896	.3658	.3475	.3961	.3475	.3292	.3658
Max	.7499	.8962	.8596	.4207	.5249	.4024	.8596
Min	.2896	.2743	.2743	.2926	.2743	.2743	.2561
Avg	.5352	.4998	.5101	.3596	.3394	.3397	.5083

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113013 / 22/11 KV SARVODAYA

Feeder No / Name : 204 / SAIDHAM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	28-AUG-17
HR	Load (MW)
17	.5415
18	.4481
19	.5415
20	.5041
21	.4854
22	.4668
23	.4668
Max	.5415
Min	.4481
Avg	.4935

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113013 / 22/11 KV SARVODAYA

Feeder No / Name : 205 / SARVODAYA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	28-AUG-17
HR	Load (MW)
17	1.1283
18	1.0208
19	1.182
20	1.2357
21	1.3253
22	1.2357
23	1.3073
Max	1.3253
Min	1.0208
Avg	1.2050

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113013 / 22/11 KV SARVODAYA

Feeder No / Name : 206 / SHREERAM SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2071	1.2851		1.3213		1.4118
2		1.0791	1.1765		1.2308		1.1946
3		1.0974	1.1403		1.1584		1.1584
4		1.0608	1.1222		1.086	1.1706	1.1403
5		1.134	1.1222		1.086	1.1157	1.1584
6		1.2071	1.2308		1.1041	1.2071	1.1946
7	1.1706	1.2986	1.3937		1.1584	1.2437	1.2489
8		1.4998	1.5023	1.3203	1.3213	1.2254	1.4842
9	1.4266	1.5912	1.5203	1.3032	1.3213	1.2986	1.5023
10	1.4998	1.5729	1.5384	1.4299		1.448	1.5203
11	1.4815	1.5181	1.6108	1.5203		1.4842	1.5927
12	1.4266	1.5546	1.4842	1.3937	1.4083	1.3756	1.4118
13	1.3535		1.267	1.3032	1.2437	1.3937	1.3937
14	1.2437	1.3352	1.3032	1.2308		1.2308	1.2127
15	1.2437	1.2803	1.267	1.1222		1.2489	1.2127
16	1.2071		1.267	1.086		1.2127	1.1765
17	1.1157	1.2986	1.267	1.1403		1.2127	1.1403
18		1.3717		1.267		1.3937	1.2851
19	1.4815	1.5565		1.3756		1.448	1.5203
20	1.5181	1.5746		1.5023		1.647	1.6289
21	1.6278	1.6289		1.5384		1.6108	1.5746
22	1.5729	1.6289		1.5384		1.5746	1.448
23	1.5181	1.5746		1.4842		1.6108	1.4842
24	1.1888	1.39	1.5384	1.6221	1.4118	1.4998	1.5384
Max	1.6278	1.6289	1.6108	1.6221	1.4118	1.647	1.6289
Min	1.1157	1.0608	1.1222	1.086	1.086	1.1157	1.1403
Avg	1.3798	1.3845	1.3354	1.3634	1.2376	1.3644	1.3597

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113013 / 22/11 KV SARVODAYA

Feeder No / Name : 207 / RAJA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.415	.4572		.2477		.2829
2		.3961	.415		.2667		.2829
3	.3734	.415	.4382		.2667		.2829
4		.3772	.381		.2641	.3174	.2829
5		.415	.3961		.2477	.3018	.2829
6		.4527	.4572		.2858	.3206	.3018
7	.5281	.4904	.4715		.3048	.3395	.2987
8		.6224	.6478	.3961	.415	.3961	.3921
9	.811	.8488	.8192	.381	.6602	.4904	.7811
10	1.0829	1.1506	1.1128	.4338		.4954	1.0185
11	1.1576		1.2071	.3772		.5658	1.1506
12	1.1389	1.2803	1.1506	.4108	1.0082	.4763	1.0562
13	1.0456		1.0751	.3395	.8215	.4338	.9431
14	1.0185	1.0185	1.094	.3018		.4715	.9242
15	1.0562	1.1506	1.0751	.3361		.4001	.9619
16	.9896		1.0562	.3018		.4001	3.5837
17	.9896	1.0534	1.0374	.2987		.3048	3.263
18		.9425		.3395		.3961	3.3385
19	.8488	.8402		.3361		.3395	2.8669
20	.679	.7655		.3395		.381	2.5086
21	.5601	.6224		.3048		.3018	2.1502
22	.5041	.5658		.3048		.3018	1.9239
23	.4715	.5525		.3048		.3048	
24	.4668	.4715	.4763	.4338	.2858	.4527	.3018
Max	1.1576	1.2803	1.2071	.4338	1.0082	.5658	3.5837
Min	.3734	.3772	.381	.2987	.2477	.3018	.2829
Avg	.8072	.7070	.7649	.3494	.4229	.3901	1.2687

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113013 / 22/11 KV SARVODAYA

Feeder No / Name : 208 / KARIA SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2803	1.3032		1.3213		1.3937
2		1.134	1.1946		1.1946		1.2127
3	.9511	1.0791	1.1403		1.1403		1.1584
4		1.0608	1.086		1.1584	1.134	1.1041
5		1.134	1.1584		1.086	1.1157	1.1041
6		1.2437	1.267		1.086	1.1523	1.1403
7	1.2437	1.3535	1.3394		1.2127	1.1706	1.2851
8		1.4449	1.3756	1.3769	1.3032	1.2437	1.3756
9	1.4266	1.4266	1.4842	1.5565	1.448	1.3717	1.5023
10	1.4998	1.4266	1.5203	1.6651		1.5746	1.5384
11	1.4083		1.5023	1.5927		1.5746	1.448
12	1.2803	1.3535	1.4083	1.5565	1.4998	1.4842	1.3937
13	1.1706		1.3394	1.4118	1.3535	1.3575	1.2489
14	1.1157	1.2071	1.2308	1.3213		1.2489	1.1765
15	1.0974	1.2071	1.1584	1.1584		1.2127	1.1222
16	1.0425		1.1584	1.1765		1.2127	1.1222
17	1.0425	1.1765	1.1403	1.1403		1.1222	1.086
18		1.1946		1.267		1.3213	1.1946
19	1.2986	1.3032		1.4118		1.3756	1.3575
20	1.4449	1.5023		1.4842		1.4842	1.4118
21	1.5546	1.5023		1.4661		1.4299	1.4661
22	1.5364	1.4842		1.4661		1.4661	1.3575
23	1.5181	1.5384		1.4842		1.4299	1.4118
24	1.2071	1.4083	1.4299	1.6032	1.4118	1.39	1.4118
Max	1.5546	1.5384	1.5203	1.6651	1.4998	1.5746	1.5384
Min	.9511	1.0608	1.086	1.1403	1.086	1.1157	1.086
Avg	1.2846	1.3077	1.2909	1.4199	1.2680	1.3273	1.2926

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113013 / 22/11 KV SARVODAYA

Feeder No / Name : 209 / nahurgaon SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.2314	2.4508		2.1948		2.396
2		1.9936	2.1033		2.0485		2.0851
3	1.6278	1.8473	1.957		1.9753		1.9753
4		1.7924	1.9204		1.9387		1.9022
5		1.9753	1.9022		1.9753	2.7069	1.8839
6		2.1033	2.1033		2.1033	2.0668	2.0485
7	2.1765	2.3594	2.396		2.1948	1.957	2.1216
8		2.5789	2.396	2.3577	2.2497	1.9936	2.3594
9	2.2862	2.6155	2.5972	2.6886	2.7801	2.2497	2.5423
10	2.6703	2.6703	2.8166	2.7801		2.652	2.7618
11	2.6155	2.4874	2.7252	2.6703		2.5423	2.8532
12	2.3045	2.3045	2.5423	2.5972	2.4143	2.7069	2.5972
13	1.7193		2.396	2.2862	2.4143	2.5423	2.3045
14	1.39	2.2131	2.3777	2.2314		2.1765	2.1765
15	2.2314	2.1765	2.3045	2.0485		2.3411	2.0302
16	2.1582		2.2131	2.0302		2.1948	2.1765
17	2.0668	2.0851	2.268	1.9753		2.2497	1.0974
18		2.1582		2.1033		2.3411	1.0608
19	2.4508	2.3777		2.4691		2.5606	1.2803
20	2.524	2.652		2.5606		2.7252	1.4266
21	2.6886	2.7984		2.6337		2.652	1.4449
22	2.8166	3.0361		2.7435		2.6886	1.39
23	2.7801	2.963		2.6337		2.7984	1.3352
24	2.1216	2.5789	2.6703	2.9424	2.4508	2.5057	2.5972
Max	2.8166	3.0361	2.8166	2.9424	2.7801	2.7984	2.8532
Min	1.39	1.7924	1.9022	1.9753	1.9387	1.957	1.0608
Avg	2.2722	2.3636	2.3411	2.4560	2.2283	2.4326	1.9936

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113018 / 22/11 KV BEST

Feeder No / Name : 201 / MARATHON

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395		.3772	.4527		.415	.5658
2	.3395		.3395	.415		.3772	.4904
3	.2926		.3395	.3772		.3395	.4715
4	.3292		.3395	.3772		.3395	.4715
5	.3658		.3772	.3772		.3395	.5281
6	.3658		.415	.3961		.3772	.6036
7	.439		.4715	.4527		.415	.5658
8	.439		.4338	.4527		.4904	.6036
9	.4755		.4715			.4527	.7545
10	.5853	.6036	.5658	.5093	.5281	.4715	.9431
11	.567		.6036		.5658	.5281	.9054
12	.547		.6036	.5281	.5281	.6036	.8299
13	.5121		.5658		.4904	.4904	.679
14	.439	.4527	.4904		.4527	.4527	.6413
15	.4755	.4904	.5658		.4715	.415	.6036
16	.4572	.547	.4904		.4904	.415	.6584
17	.439	.4715	.4715		.4904	.4527	.4715
18	.5121	.4715	.4527		.415	.4715	.679
19	.4755	.4715	.5281	.4527	.4715	.4527	.7356
20		.4904	.5281		.4715	.4715	.7167
21	.4715	.5281	.5281		.4715	.4527	.679
22		.5658	.4904		.4715	.4715	.6602
23	.4715	.4904	.4904	.4527	.4715	.6602	.679
24	.3658	.3961	.4715	.4904	.4338	.4527	.6602
Max	.5853	.6036	.6036	.5281	.5658	.6602	.9431
Min	.2926	.3961	.3395	.3772	.415	.3395	.4715
Avg	.4411	.4983	.4755	.4411	.4816	.4503	.6499

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113018 / 22/11 KV BEST

Feeder No / Name : 202 / RITA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5847		.7167	.7167		.7167	.7167
2	.5316		.679	.679		.6979	.6602
3	.4961		.6036	.5658		.679	.6036
4	.5121		.6036	.5658		.6413	.5658
5	.4607		.6036	.5658		.6036	.5658
6	.5138		.6224	.6224		.6036	.5658
7	.6024		.679	.6602		.6036	.6036
8	.7087		.8299	.679		.6224	.679
9	.7442		.8676			.6602	.9054
10	.9745	.9054	.9808	.8488	.9431	.7733	1.0562
11	.9922		1.0185		1.0185	.8299	1.1317
12	.9922	.9431	1.0562	.8676	.9431	.9054	1.1317
13	.9922		1.1317		.9054	.7922	1.0562
14	.8859	.9431	.9808		.8676	.7733	1.0185
15	.8505	.9808	.9619		.7922	.7545	.9431
16	.8682	.9997	1.0185		.7545	.8676	.9054
17	.8859	.9431	.9431		.7167	.7922	.9431
18	.9214	.9431	.8676		.8299	.8299	.8676
19	.9214	.9808	.9619	.811	.9054	.9054	1.0185
20		1.0185	.9054		.9054	.8676	.9808
21	.9242	.9619	.9619		.8676	.8676	.9431
22		.9054	.8676		.7545	.8299	.7545
23	.7545	.8488	.8299	.7356	.7545	.8299	.8488
24	.6556	.7167	.7545	.7922	.7356	.7545	.7922
Max	.9922	1.0185	1.1317	.8676	1.0185	.9054	1.1317
Min	.4607	.7167	.6036	.5658	.7167	.6036	.5658
Avg	.7624	.9300	.8519	.7008	.8463	.7584	.8441

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113018 / 22/11 KV BEST

Feeder No / Name : 203 / BHAWANI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975		.7545	.7545		.7922	.8299
2	.5788		.679	.679		.7167	.679
3	.5975		.6224	.6413		.679	.6413
4	.5601		.6224	.6036		.6602	.6224
5	.5601		.6224	.6413		.6602	.6413
6	.6908		.7167	.6979		.6602	.679
7	.8215		.8299	.679		.679	.8299
8	.9335		1.0562	.7922		.7545	.9054
9	1.1763		1.2071			.9431	1.1317
10	1.4003	1.4146	1.5089	1.0562	1.1317	1.1694	1.3957
11	1.7177		1.6975		1.4523	1.3957	1.8861
12	1.6804	1.7541	1.8107	1.3203	1.5466	1.5655	1.8861
13	1.7177		1.6975		1.4335	1.5089	1.6975
14	1.4937	1.5844	1.6598		1.3203	1.3203	1.6032
15	1.4937	1.6032	1.6221		1.2826	1.1694	1.5089
16	1.4937	1.6221	1.6975		1.2449	1.2071	1.5089
17	1.4937	1.6975	1.6598		1.1694	1.3203	1.5844
18	1.7551	1.8861	1.7353		1.3392	1.4712	1.8107
19	1.9418	1.9805	1.8861	1.3014	1.5089	1.6221	1.9239
20		1.8861	1.6598		1.4335	1.6221	1.8107
21	1.5466	1.6032	1.4712		1.4335	1.4335	1.5089
22		1.1694	1.1694		1.094	.9808	1.0562
23	.8865	.9808	1.0185	.9054	.9431	.9808	.9431
24	.7095	.7545	.8299	.8676	.8676	.8676	.9431
Max	1.9418	1.9805	1.8861	1.3203	1.5466	1.6221	1.9239
Min	.5601	.7545	.6224	.6036	.8676	.6602	.6224
Avg	1.1748	1.5336	1.2598	.8415	1.2801	1.0908	1.2511

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703]

BU 4703

Substation No/ Name :- 113018 / 22/11 KV BEST

Feeder No / Name : 204 / ASHOK CORPORATION

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1694		1.2449	1.3203		1.1317	1.0185
2	1.094		1.1317	1.2449		.9808	.7922
3	1.0562		1.0185	1.1317		.9431	.8299
4	1.0185		.9054	1.1317		.9054	.8299
5	1.0185		.9054	1.1694		.9242	.8299
6	1.0562		1.0185	1.0562		.9242	.9054
7	1.094		1.0751	1.0562		.9431	.8299
8	1.1317		1.2449	1.2071		.9431	.9808
9	1.5089		1.6598			1.0185	1.6032
10	1.8107	1.8861	1.9616	1.4335	1.5089	1.2449	1.8861
11	2.1879		2.1879		1.7353	1.2826	2.1125
12	2.1125	1.9993	2.2634	1.5278	1.8107	1.3203	2.1125
13	1.8861		1.9616		1.8484	1.3203	1.9616
14	1.8861	2.037	1.9805		1.8861	1.2826	1.9616
15	1.9616	1.9805	1.9993		1.8107	1.1317	
16	1.9239	1.9427	2.0748		1.6975	1.094	1.8861
17	1.9616	2.1691			1.5466	1.094	2.0748
18	1.8484	1.8861			1.5844	1.0562	1.9239
19	2.037	2.1691	1.9805	1.4146	1.6598	1.1317	1.9993
20		1.9616	1.7353		1.6221	1.226	1.8107
21	1.5655	1.9427	1.6221		1.4712	1.1317	1.5844
22		1.4335	1.5089		1.3957	1.2071	1.358
23	1.4523	1.5089	1.5089	1.358	1.358	1.2071	1.2826
24	1.3203	1.3203	1.3957	1.4712	1.2449	1.2449	1.1317
Max	2.1879	2.1691	2.2634	1.5278	1.8861	1.3203	2.1125
Min	1.0185	1.3203	.9054	1.0562	1.2449	.9054	.7922
Avg	1.5501	1.8644	1.5629	1.2710	1.6120	1.1121	1.4655

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113018 / 22/11 KV BEST

Feeder No / Name : 205 / SONAR BUNGLOW SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8688		1.0562	1.1317		1.1317	1.1317
2	.7964		.9431	1.0185		1.0562	.9808
3	.7602		.9054	.9808		.9808	.9431
4	.8688		.9054	.9808		.9431	.9054
5	.9412		.9054	.8916		.9431	.9431
6	.9231		1.0185	1.1694		1.0185	.9808
7	1.1584		1.2826	1.2071		1.1317	1.1694
8	1.1946		1.358	1.2071		1.2826	1.358
9	1.2308		1.358			1.358	1.2826
10	1.2127	1.3769	1.358	1.4146	1.2826	1.358	1.358
11	1.086		1.2826		1.2071	1.3203	1.2826
12	1.0498	1.0751	1.094	1.1128	1.8107	1.2071	1.2826
13	1.0136		1.0562		1.1317	1.1694	1.0562
14	.9593	1.0185	1.0562		1.0185	1.0562	1.0562
15	.9412	1.0185	1.0562		1.0185	1.0185	1.0562
16	.9412	1.0185	1.0562		1.0185	1.1317	1.0562
17	1.0498	1.0562	1.0562		1.0185	1.1317	1.094
18	1.1946	1.1317	1.1694		1.1317	1.226	1.0974
19	1.267	1.358	1.3203	1.2826	1.3203	1.3957	1.358
20		1.358	1.358		1.358	1.3957	1.4523
21	1.4146	1.3957	1.3957		1.3957	1.4146	1.4335
22		1.358	1.4146		1.3203	1.3769	1.2826
23	1.3014	1.358	1.358	1.2449	1.2449	1.358	1.2826
24	1.0498	1.1506	1.1694	1.2449	1.2071	1.2449	1.226
Max	1.4146	1.3957	1.4146	1.4146	1.8107	1.4146	1.4523
Min	.7602	1.0185	.9054	.8916	1.0185	.9431	.9054
Avg	1.0556	1.2057	1.1639	1.1451	1.2323	1.1938	1.1696

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703]

BU 4703

Substation No/ Name :- 113018 / 22/11 KV BEST

Feeder No / Name : 207 / AMBEDKAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0924		.0943	.0943		.0943	.0943
2	.0739		.0754	.0943		.0943	.0943
3	.0739		.0732	.0943		.0943	.0943
4	.0739		.0754	.0943		.0943	.0943
5	.0739		.0754	.0943		.0943	.0754
6	.0739		.0754	.0754		.0943	.0754
7	.0924			.0754		.0754	.0943
8	.0924		.1132	.0754		.0754	.0943
9	.0924		.1132			.0754	.0943
10	.1109	.1132	.132	.0754	.0754	.0754	.1132
11	.1109		.1132		.0754	.0754	.0943
12	.0924	.132	.1132	.0754	.0943	.0754	.1132
13	.1294		.132		.0943	.0566	.132
14	.0924	.1132	.132		.0754	.0754	.1132
15	.1294	.1132	.1132		.0754	.0754	.1132
16	.1294	.1132	.0943		.0754	.0754	.0943
17	.1109	.132	.0943		.0754	.0754	.0943
18	.0924	.0754	.0943		.0754	.0754	.0943
19	.0924	.0754	.0943	.0754	.0754	.0754	.0754
20		.0943	.0943		.0943	.0943	.0943
21	.0754	.0943	.0943		.0943	.0943	.0943
22		.0943	.0943		.0943	.0943	.0943
23	.0943	.0943	.0943	.0943	.0943	.0943	.0943
24	.0924	.0943	.0943	.0943	.0943	.0943	.0943
Max	.1294	.132	.132	.0943	.0943	.0943	.132
Min	.0739	.0754	.0732	.0754	.0754	.0566	.0754
Avg	.0951	.1030	.0991	.0856	.0842	.0833	.0967

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113018 / 22/11 KV BEST

Feeder No / Name : 208 / CAMP III

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5893		1.9239	2.1879		2.1879	2.037
2	1.5339		1.8107	1.9616		1.9805	1.9239
3	1.4784		1.6975	1.9239		1.8484	1.8861
4	1.4415		1.6975	1.8861		1.8107	1.773
5	1.5524		1.6975	1.8861		1.6975	1.7918
6	1.6632		1.8107	1.8296		1.6975	1.7918
7	1.848		1.9239	2.037		1.773	1.8484
8	2.1437		2.0748	2.1502		1.8861	2.0748
9	2.4394		2.6783			2.1879	2.4143
10	2.347	2.6595	2.6406	2.6595	2.4897	2.3388	2.6029
11	2.4764		2.6783		2.6406	2.4143	2.4897
12	2.5503	2.4897	2.7538	2.4331	2.5652	2.5652	2.5652
13	2.384		2.5652		2.3388	2.452	2.3765
14	2.2177	2.3011	2.2634		2.1502	2.1879	1.9239
15	2.1807	2.1879	2.2257		1.9616	1.9616	1.773
16	1.9959	1.9616	2.1879		1.9616	1.9616	1.5844
17	1.885	1.9805	1.9239		1.9616	1.9993	1.6598
18	1.922	2.1879	2.0936		2.0748	2.2257	1.8107
19	2.1437	2.3577	2.3577	2.2822	2.4897	2.6029	2.1125
20		2.0748	2.6029		2.6406	2.6406	2.2634
21	2.3388	2.4897	2.4897		2.5652	2.452	2.1691
22		2.4897	2.5652		2.4897	2.3765	2.0182
23	2.1502	2.4143	2.4331	2.4143	2.5274	2.5652	1.9805
24	1.848	2.0748	2.2257	2.3577	2.2257	2.3388	2.3011
Max	2.5503	2.6595	2.7538	2.6595	2.6406	2.6406	2.6029
Min	1.4415	1.9616	1.6975	1.8296	1.9616	1.6975	1.5844
Avg	2.0059	2.2822	2.2217	2.1546	2.3388	2.1730	2.0488

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113018 / 22/11 KV BEST

Feeder No / Name : 209 / P &T COLONY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8316		1.0185	1.1317		1.0185	1.1317
2	.7762		.9431	1.0185		.9431	1.0185
3	.7207		.8676	.9431		.9054	.9431
4	.7392		.8299	.9054		.8676	.9054
5	.7468		.8299	.9054		.8676	.8488
6	.8316		.9054	.9054		.8676	.7167
7	.961		.9808	.9808		.9054	.9054
8	.9979		1.0562	1.0374		.9431	.9808
9	1.0349		1.2449			.9808	1.0562
10	1.1088	1.1317	1.2071	1.1506	1.2071	1.0562	1.1883
11	1.1458		1.1883		1.1694	.9431	1.226
12	1.1088	1.1128	1.1883	1.094	1.1317	.8299	.9431
13	1.0534		1.1506		1.1317	1.0185	1.1317
14	1.0534	.9242	1.094		1.094	.9808	1.0562
15	.9795	.8299	1.094		1.0562	.9431	.9808
16	.9979	.7733	1.094		1.0185	.9431	.6036
17	.9979	1.1883	.9054		1.0374	.9808	.679
18	.9795	1.1317	1.094		.9997	1.0562	.7167
19	1.1458	1.1883	1.1317	1.1317	1.094	1.1883	.7922
20		1.3203	1.226		.9431	1.1506	.8488
21	1.226	1.3392	1.2826		1.2071	1.226	.9242
22		1.2826	1.2826		1.1694	1.2071	.8488
23	1.2071	1.3014	1.2449	1.1317	1.2071	1.2071	.8488
24	.9795	1.0374	1.1317	1.2071	1.0751	1.094	1.1317
Max	1.226	1.3392	1.2826	1.2071	1.2071	1.226	1.226
Min	.7207	.7733	.8299	.9054	.9431	.8299	.6036
Avg	.9829	1.1201	1.0830	1.0418	1.1028	1.0052	.9344

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113018 / 22/11 KV BEST

Feeder No / Name : 210 / MANORANJAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17
HR	Load (MW)
18	.0943
Max	.0943
Min	.0943
Avg	.0943

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113018 / 22/11 KV BEST

Feeder No / Name : 212 / P KHERAJ

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747		.0943	.0943		.0943	1.1317
2	.0747		.0754			.0754	.9619
3	.056		.0754	.0754		.0754	.8676
4	.1307		.0754	.0754		.0754	.8488
5	.0747		.0754	.0754		.0754	.8488
6	.0747		.0754	.0754		.0754	.8676
7	.0934		.0943	.1132		.0754	1.0185
8	.1307		.132	.1132		.0754	1.2826
9	.1867		.1886			.1132	1.4712
10	.2241	.132	.1886	.1132	.1509	.1132	1.5089
11	.1867		.1886		.1509	.1132	1.5466
12	.1867	.0943	.2075	.1132	.9431	.1509	1.358
13	.1867		.2641		.1698	.132	1.2826
14	.1494	.0943	.1886		.1886	.1509	1.2449
15	.2054	.1509	.1886		.1509	.1509	
16	.1867	.1886	.1509		.1509	.1509	1.3957
17	.1867	.1886	.1886		.0943	.132	1.226
18	.1867	.1509	.1886		.1509	.132	1.1888
19	.168	.1509	.1886	.1132	.132	.1509	1.4712
20		.1509	.1886		.1132	.1509	1.5089
21	.132	.1509	.1509		.1132	.1509	1.5089
22		.1132	.1132		.132	1.5089	1.358
23	.132	.132	.1132	.1132	.1132	1.4335	1.3203
24	.112	.132		.0943	.1132		1.3203
Max	.2241	.1886	.2641	.1132	.9431	1.5089	1.5466
Min	.056	.0943	.0754	.0754	.0943	.0754	.8488
Avg	.1427	.1407	.1476	.0975	.1911	.2329	1.2408

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113025 / 22/11 KV NIRMAL LIFE S/STN

Feeder No / Name : 200 / Corporate SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.4108	.3734	.4481	.4668	.4854	.4668
2	.3547	.3734	.3547	.4108	.4108	.4108	.3921
3	.2987	.3361	.3361	.3734	.3772	.3734	.3547
4	.2987		.2987	.3734	.3734	.3361	.2987
5	.2987	.2987	.2987	.3361	.3734	.3174	.2987
6	.3174	.3174	.2987	.3361	.4108	.3361	.3174
7	.3174	.3361	.3174	.3547	.3547	.3174	.3361
8	.2987	.3547	.4854	.3361	.3734	.4108	.3361
9	.5144	.6348	.5788	.5041	.5415	.5228	.7842
10	1.1763	1.1016	.9522	.6535	.9522	.6535	.9335
11	1.1763	1.307	1.0642	.8215	1.2136	.7282	1.1389
12	1.1812	1.2136	1.1949	.8029	1.0082	.7655	1.1949
13	.9522	1.0829	1.0642	.7842	1.1203	.7468	1.1949
14	.9522	1.0082	1.0829	.7468	1.0642	.6908	1.1576
15	1.0642	.9709	1.0456	.7468	1.0082	.7468	1.1203
16	.9522	.9896	1.1576	.7545	.9335	.7655	1.1203
17	1.2136	1.0269	1.0829	.7842	.8775	.8215	1.1203
18	1.1949	1.1016	1.0829	.7842	.8954	.8215	1.0269
19	1.1576	.9709	1.0829	.7842	.8029	.8775	1.1389
20	.8402	.8402	.9335	.7655	.7842	.8402	.9149
21	.8589	.7842	.8402	.8029	.8029	.8215	
22	.8215	.7282	.7468	.7468	.7468	.6535	
23	.6348	.5415	.6348	.6348	.6348	.6348	
24	.4481	.5041	.4854	.4668		.5228	.5041
Max	1.2136	1.307	1.1949	.8215	1.2136	.8775	1.1949
Min	.2987	.2987	.2987	.3361	.3547	.3174	.2987
Avg	.7373	.7493	.7414	.6064	.7186	.6084	.7691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703]

BU 4703

Substation No/ Name :- 113025 / 22/11 KV NIRMAL LIFE S/STN

Feeder No / Name : 201 / OPEL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.2667	.2286	.2286	.1905	.2286
2	.1524	.1905	.1905	.1905	.1905	.1905	.1905
3	.1524	.1905	.2286	.1905	.1905	.1905	.1524
4	.1524		.1524	.1905	.1715	.1715	.1524
5	.2286	.1715	.1524	.1524	.1715	.1715	.1905
6	.2667	.1905	.1905	.1715	.1524	.1524	.2286
7	.2667	.2286	.2667	.1905	.1524	.1715	.2667
8	.2667	.1905	.2667	.2096	.1524	.1905	.2286
9	.2667	.2286	.2667	.3048	.1905	.1905	.2477
10	.2286	.1524	.1905	.3239	.2096	.2286	.1905
11	.1905	.1905	.1524	.2286	.2286	.2667	.1715
12	.1524	.1524	.1715	.2667	.1905	.2667	.1715
13	.1715	.1524	.1524	.2858	.1715	.2286	.1715
14	.1524	.1524	.1524	.2667	.1905	.1905	.1715
15	.1524	.1905	.1715	.2286	.1715	.1905	.1715
16	.1524	.1524	.1524	.2286	.1524	.1905	.1715
17	.1524	.1524	.1524	.1715	.1524	.2667	.1524
18	.1524	.1524	.1524	.1905	.1524	.1905	
19	.1715	.1905	.1524	.1905	.1715	.2286	
20	.1715	.2286	.2096	.1905	.1905	.2667	
21	.2096	.2477	.2286	.1905	.1905	.2667	
22	.2477	.2667	.2286	.2286	.2096	.2667	
23	.2286	.2667	.2477	.2477	.1715	.2286	
24	.2286	.1905	.2667	.2477	.2286	.2286	.2667
Max	.2667	.2667	.2667	.3239	.2286	.2667	.2667
Min	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Avg	.1961	.1922	.1984	.2215	.1826	.2135	.1958

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113025 / 22/11 KV NIRMAL LIFE S/STN

Feeder No / Name : 202 / Amruta

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	1.0098	.9526	1.1431	.9526	.9907	.9145
2	.8002	.9335	.9145	1.086	.8573	.9145	.8383
3	.7621	.8954	.8383		.8573	.8764	.7621
4	.7621		.8002	.9907	.8764	.8002	.724
5	.6859	.9145	.8764	.9145	.9145	.8764	.8383
6	.8002	.9907	.9335	.9335	.8192	.8573	.9145
7	1.0669	1.086	1.0098	.8764	.8383	.9335	.9335
8	.9717	1.1812	1.2574	1.1241	.9145	.8573	.9907
9	1.2574	1.3717	1.2574	1.105	1.1241	1.0098	1.0374
10	1.3527	1.467	1.4289	1.1622	1.2003	1.0669	1.0374
11	1.448	1.5242	1.4289	1.1622	1.2765	1.2765	1.0562
12	1.3908	1.2955	1.3527	1.105	1.2384	1.086	1.0185
13	1.3717	1.3146	1.2955	1.0479	1.2193	1.1812	1.3336
14	1.3717	1.2193	1.2955	.9907	1.2574	1.1241	1.2384
15	1.2765	1.2384	1.2765	.9526	1.0098	.9717	1.2384
16	1.1812	1.2574	1.2384	.9526	1.0098	.9717	1.2003
17	1.2384	1.2765	1.2384	.9907	1.0669	.9526	1.2384
18	1.2765	1.2193	1.2003	1.0098	.9907	1.1241	
19	1.2574	1.2955	1.2003	1.105	1.1812	1.2003	1.2574
20	1.2384	1.2384	1.2384	1.1812	1.1812	1.1812	1.1812
21	1.2765	1.2384	1.2193	1.105	1.1622	1.1622	1.2384
22	1.2955	1.2574	1.2384	1.105	1.1241	1.0288	1.3146
23	1.2003	1.2384	1.1812	1.1241	1.1241	1.086	1.7909
24	.9335	1.0669	.9907	1.1622	1.086	.9526	.9526
Max	1.448	1.5242	1.4289	1.1812	1.2765	1.2765	1.7909
Min	.6859	.8954	.8002	.8764	.8192	.8002	.724
Avg	1.1280	1.1970	1.1526	1.0578	1.0534	1.0201	1.0891

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113025 / 22/11 KV NIRMAL LIFE S/STN

Feeder No / Name : 203 / Runwal

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1524	.1524	.1715	.1524	.1905
2	.1524	.1524	.1524	.1524	.1715	.1524	.1524
3	.1524	.1524	.1524	1.0288	.1524	.1524	.1524
4	.1524		.1524	.1524	.1524	.1524	.1524
5	.1524	.1524	.1524	.1524	.1524	.1524	.1524
6	.1524	.1524	.1524	.1524	.1524	.1524	.1524
7	.1715	.1715	.1524	.1524	.1524	.1524	.1905
8	.1524	.1524	.1524	.1524	.1524	.1524	.1905
9	.1524	.1524	.1905	.1715	.1524	.1524	.1524
10	.1524	.2667	.1524	.1905	.1524	.2286	.1524
11	.1905	.2286	.1524	.2286	.1524	.1905	.1524
12	.1524	.2286	.1524	.1524	.1524	.2286	.1524
13	.1524	.2286	.1524	.1524	.1715	.1905	.1524
14	.1524	.1905	.1524	.1524	.1715	.1905	.1715
15	.1524	.2286	.1524	.1524	.1524	.1905	1.0288
16	.1524	.2667	.1524	.1524	.1524	.1524	.9335
17	.1524	.2286	.1524	.1524	.1524	.1905	.8573
18	.1524	.1905	.1524	.1524	.1524	.1905	
19	.1524	.2286	.1715	.1524	.1524	.2286	.724
20	.1524	.2286	.1715	.1715	.1524	.2286	.5716
21	.1715	.2286	.1715	.1524	.1524	.2286	.5716
22	.1524	.2286	.1524	.1524	.1524	.2286	.5144
23	.1524	.2286	.1905	.1715	.1524	.2286	.4572
24	.1524	.1524	.1524	.1715	.1715	.1524	.1905
Max	.1905	.2667	.1905	1.0288	.1715	.2286	1.0288
Min	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Avg	.1556	.1996	.1580	.1969	.1564	.1842	.3529

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113025 / 22/11 KV NIRMAL LIFE S/STN

Feeder No / Name : 204 / sonapur htp SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4715	.5658	.6036	.6602	.4715	.5658	.4715
2	.4527	.547	.5658	.6036	.3772	.5658	.4338
3	.415	.6036	.5281	.5658	.3772	.5093	.3772
4	.4715		.4904	.5658	.3772	.4715	.3772
5	.5281	.6602	.5847	.5847	.415	.4904	.4715
6	.6036	.7167	.679	.6036	.4715	.5093	.5281
7	.679	.7545	.7356	.5658	.5847	.5228	.5847
8	.7356	.7733	.811	.6413	.6224	.5281	.7545
9	.9619	.9054	1.0185	.6413	.8299	.679	
10	.9431	1.0185	1.0185	.7545	.9431	.7733	
11	.9808	1.0374	1.1317	.5847	1.0374	.547	
12	.9808	1.1128	1.0185	.6413	.8865	.547	
13	.8676	.9431	.9619	.6036	.8676	.5093	.9431
14	.8488	.9054	.9997	.5658	.9054	.4715	.8676
15	.9054	.9431	1.0562	.5281	.8676	.4904	2.5463
16	.9619	.9808	1.0185	.5281	.9619	.4527	2.8292
17	.9431	1.0185	1.0185	.4904	.8299	.4527	2.7915
18	.9431	.9808	.9431	.3772	.9808	.4338	2.6595
19	.8676	.9619	.9054	.4338	.8488	.4527	2.7161
20	.7922	.8676	.8488	.4904	.7356	.4338	2.4897
21	.7733	.8299	.7733	.4715	.6413	.4527	2.2634
22	.679	.811	.7545	.4715	.6413	.5658	2.2822
23	.6413	.6979	.7545	.5281	.6224	.5093	2.4143
24	.547	.6979	.6602	.6979	.5658	.6224	.5093
Max	.9808	1.1128	1.1317	.7545	1.0374	.7733	2.8292
Min	.415	.547	.4904	.3772	.3772	.4338	.3772
Avg	.7497	.8406	.8283	.5666	.7026	.5232	1.4655

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

MULUND DIVISION[554]

SARVODAY S/DN.[703] BU 4703

Substation No/ Name :- 113025 / 22/11 KV NIRMAL LIFE S/STN

Feeder No / Name : 205 / vasant oscar 2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7682	.9511	1.0242	1.0791	.9145	1.1706	1.0242
2	.7316	.9145	.9511	1.0425	.8488	1.134	.9511
3	.6584	.8779	.8779	1.0059	.7316	1.0974	.9145
4	.6584		.8779	.9511	.7316	.9877	.8779
5	.7682	.9145	.9511	.9145	.7316	.9511	.9511
6	.8413	.9511	1.0242	.8596	.7865	.8596	1.0242
7	.9511	.9877	1.0608	.9877	.823	1.0059	1.1157
8	1.0425	1.0974	1.2071	.9145	.823	1.0425	1.0425
9	1.0974	1.0974	1.1157	1.3169	1.2803	1.1157	1.2071
10	1.2803	1.2254	1.1888	1.3169	1.3535	1.3169	1.2803
11	1.1888	1.2803	1.2071	1.3352	1.4632	1.4815	1.3352
12	1.134	1.2254	1.1523	1.2803	1.3169	1.3717	1.2437
13	1.0608	1.1157	1.1523	1.1888	1.134	1.2803	1.0974
14	.9145	1.0974	1.0608	1.0059	1.0242	1.1888	1.0608
15	1.0059	1.134	.9877	.9145	1.134	1.0242	1.0425
16	1.0242	1.1523	.9877	.9145	1.1706	.9145	1.0242
17	.9145	.9328	1.0242	.9877	1.0608	1.0974	1.0059
18	1.1523	1.0608	1.0608	.9877	1.0608	1.2071	1.0425
19	1.1523	1.0608	1.2254	1.0974	1.2071	1.1706	1.2071
20	1.1523	1.2071	1.262	1.1888	1.39	1.2803	1.2986
21	1.134	1.1706	1.2254	1.0608	1.2254	1.1523	1.1888
22	1.134	1.1157	1.2254	1.0974	1.2986	1.1888	1.0791
23	1.2254	1.1157	1.2803	1.1523	1.2986	1.3717	1.0791
24	.8413	1.0242	1.0791	1.1157	1.0608	1.2803	1.0974
Max	1.2803	1.2803	1.2803	1.3352	1.4632	1.4815	1.3352
Min	.6584	.8779	.8779	.8596	.7316	.8596	.8779
Avg	.9930	1.0743	1.0921	1.0715	1.0779	1.1538	1.0913

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - III[551]

MUMBRA[152]

BU 4391

Substation No/ Name :- 283087 / BHARAT GEAR SWITCHING

STATION

Feeder No / Name : 301 / SAGAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11						9.1221	8.4865
12					8.9255		
18			7.9012				
20	9.6571						
24	9.465	9.225	9.7394	10.4253			
Max	9.6571	9.225	9.7394	10.4253	8.9255	9.1221	8.4865
Min	9.465	9.225	7.9012	10.4253	8.9255	9.1221	8.4865
Avg	9.5611	9.225	8.8203	10.4253	8.9255	9.1221	8.4865

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - III[551]

MUMBRA[152] BU 4391

Substation No/ Name :- 283087 / BHARAT GEAR SWITCHING

STATION

Feeder No / Name : 303 / SHIL PHATA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11						1.1694	1.2048
12					1.1694		
18			1.0631				
24	.8916	1.0631	1.0631	1.134			
Max	.8916	1.0631	1.0631	1.134	1.1694	1.1694	1.2048
Min	.8916	1.0631	1.0631	1.134	1.1694	1.1694	1.2048
Avg	.8916	1.0631	1.0631	1.134	1.1694	1.1694	1.2048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - III[551]

MUMBRA[152] BU 4391

Substation No/ Name :- 283087 / BHARAT GEAR SWITCHING

STATION

Feeder No / Name : 304 / KAUSA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11						.9145	1.0719
12					1.0498		
18			.7762				
20	.8131						
24	.8573	.9945	1.0288	1.1827			
Max	.8573	.9945	1.0288	1.1827	1.0498	.9145	1.0719
Min	.8131	.9945	.7762	1.1827	1.0498	.9145	1.0719
Avg	.8352	.9945	.9025	1.1827	1.0498	.9145	1.0719

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - III[551]

MUMBRA[152] BU 4391

Substation No/ Name :- 283087 / BHARAT GEAR SWITCHING

STATION

Feeder No / Name : 305 / SHARIFA ROAD

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11						11.0883	10.8596
12					10.8292		
18			11.3398				
20	9.8766						
24	8.5734	9.6022	9.9451	11.3169			
Max	9.8766	9.6022	11.3398	11.3169	10.8292	11.0883	10.8596
Min	8.5734	9.6022	9.9451	11.3169	10.8292	11.0883	10.8596
Avg	9.225	9.6022	10.6425	11.3169	10.8292	11.0883	10.8596

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - III[551]

MUMBRA[152] BU 4391

Substation No/ Name :- 283087 / BHARAT GEAR SWITCHING

STATION

Feeder No / Name : 308 / Devari Pada

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11						2.6703	2.8959
12					2.5339		
18			2.524				
20	2.9683						
24	2.4691	2.7092	2.8807	3.1493			
Max	2.9683	2.7092	2.8807	3.1493	2.5339	2.6703	2.8959
Min	2.4691	2.7092	2.524	3.1493	2.5339	2.6703	2.8959
Avg	2.7187	2.7092	2.7024	3.1493	2.5339	2.6703	2.8959

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - III[551]

SHIL SUB DIVISION[643] BU 4643

Substation No/ Name :- 208295 / 100/22kV Mumbra S/Stn.

Feeder No / Name : 302 / 22kV Kalyan Phata Feeder

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
8	1.4403	1.3717	4.0124
16	2.1605	2.3663	
24	1.5775	1.6461	3.8409
Max	2.1605	2.3663	4.0124
Min	1.4403	1.3717	3.8409
Avg	1.7261	1.7947	3.9267

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - III[551]

SHIL SUB DIVISION[643] BU 4643

Substation No/ Name :- 283090 / khidkali s/s

Feeder No / Name : 301 / DIVA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	8.0933	8.8477	10.048	9.4307	8.5048	7.8875	
2	7.7161	8.5734	9.808	9.0878	8.2305	7.8875	
3	7.6132	8.9506	9.3964	8.7449	8.642	8.2991	
4	7.6818	9.4307	9.0878	8.5048	8.9163	8.4019	
5	7.7161	9.9109	9.2593	9.2593	9.1907	8.7449	
6	9.4307		10.4595		9.6708	9.0878	
7	8.9849	10.5281	9.9451	1.2003	9.2593	9.4307	
8	8.9163	9.1564	9.2593	.9259	10.7339	9.0878	9.2593
9	8.7792	8.8477	8.5734	.9602	9.6022	10.8368	
10	8.5734	8.7106	8.2305		8.8135	9.4307	
11	7.9904	7.8875	7.7161		8.0247	8.7449	
12	7.5789	7.4074			7.8875	8.059	7.8532
13		7.2017	7.0302		7.5446	7.7161	
14		6.7215	7.2017	10.1852	8.5734	7.3731	6.6873
15	6.8244	6.4129	7.2359	8.9849	7.7161	7.0302	6.31
16		6.4472	7.5446	8.6077	6.4815	7.0645	6.6873
17		6.4815	7.2017	8.5734	7.4074	7.5446	6.8244
18		7.2017	7.3731	8.6763	7.8189	8.059	7.6132
19	9.4307		9.0878	9.7394	9.225	9.7737	9.1907
20	11.4198	12.0028	10.4595	10.5624	10.3224	10.8025	10.1509
21	11.7627			10.3567	10.4595	10.631	
22	11.797		12.1742	10.4595	9.9451	10.8025	
23	11.1454		10.974	9.8423	10.0137	10.2881	.7545
24	8.7106	9.4993	11.6255	9.7737	8.9163	8.6763	8.9163
Max	11.797	12.0028	12.1742	10.5624	10.7339	10.8368	10.1509
Min	6.8244	6.4129	7.0302	.9259	6.4815	7.0302	.7545
Avg	8.9560	8.4326	9.0769	8.0987	8.8292	8.8192	7.2952

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - III[551]

SHIL SUB DIVISION[643] BU 4643

Substation No/ Name :- 283090 / khidkali s/s

Feeder No / Name : 302 / RIVERWOOD

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743		.3086	.3429	.3429	.2743	
2	.2743	.2743	.2743	.3086	.2743	.2743	
3	.2743	.3086	.3086	.2743		.2743	
4	.2743	.3429	.3429	.2743	.3086	.2743	
5	.3086	.3772	.3772	.3086	.2743	.3086	
6	.3429	.3429	.4115	.3772	.3429	.3429	
7	.3772	.3772	.4115	.3772	.3429	.3772	
8	.4115	.4458	.4115	.4115	.4115	.3772	.4115
9	.3772	.4115	.4115	.4115	.4115	.4115	
10	.3429	.4115	.4115		.4458	.4458	
11		.3772	.4115		.4115	.4115	
12	.3772	.3772	.4115	.4115	.3772	.4115	.4115
13		.3772	.3429		.3429	.3429	
14		.3086	.3086	.3772	.3086	.3429	.3429
15	.2743	.3772	.3429	.3429	.2743	.3086	.2743
16		.3772	.3429	.3086	.3086	.3086	.3086
17		.3086	.3429	.2743	.3086	.3429	.3086
18		.3086	.3429	.3086	.3086	.3429	.3086
19	.3772	.3772	.3772	.3429	.3772	.4458	.3429
20	.4115	.4115	.3772	.3772	.3772	.4115	.4115
21	.3772		.3772	.3772	.3772		
22	.3772		.4115	.3772	.4115		.3429
23	.3772	.5144	.4115	.3772	.4115		.3429
24	.2743	.3772	.3772	.3772	.3086	.3429	.3429
Max	.4115	.5144	.4115	.4115	.4458	.4458	.4115
Min	.2743	.2743	.2743	.2743	.2743	.2743	.2743
Avg	.3391	.3707	.3686	.3494	.3504	.3511	.3458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

KALWA S/DN.[128]

BU 4261

Substation No/ Name :- 283086 / SHIVAJI HOSPITAL 22/11 KV

Feeder No / Name : 202 / BUDHAJI NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
1		1.3352	1.5203
2		1.2803	1.448
3		1.2437	1.3756
4		1.1163	1.3032
5		1.0749	1.3756
6		1.3466	1.5203
7		1.6124	1.5927
8			1.7013
9		1.829	1.7013
10	1.5546	1.7375	
11	1.4998	1.4842	
12	1.3535	1.448	
13		1.3756	
14		1.2308	
15	1.0425	1.1946	
16		1.1403	
17		1.1765	
18	1.2934	1.3394	
19		1.8099	
20	2.0485	2.0271	
21		2.0271	
22	1.9753	1.9185	
23		1.828	
24		1.5592	1.6832
Max	2.0485	2.0271	1.7013
Min	1.0425	1.0749	1.3032
Avg	1.5382	1.4841	1.5222

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

KALWA S/DN.[128] BU 4261

Substation No/ Name :- 283086 / SHIVAJI HOSPITAL 22/11 KV

Feeder No / Name : 203 / KALWA NAKA SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	25-AUG-17
HR	Load (MW)
21	1.4998
22	1.382
Max	1.4998
Min	1.382
Avg	1.4409

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

KALWA S/DN.[128]

BU 4261

Substation No/ Name :- 283086 / SHIVAJI HOSPITAL 22/11 KV

Feeder No / Name : 204 / S. T. WORKSHOP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3611	1.382	1.576	1.7551	1.4266	1.5181	1.576
2	1.2894	1.3352	1.5043	1.576	1.3289	1.3643	1.3611
3	1.2178	1.2403	1.4327	1.4327	1.3169	1.4146	1.2894
4	1.0745	1.2803	1.3611	1.3969	1.3169	1.2757	1.2536
5	1.2536	1.4632	1.4327	1.3969	1.2803	1.2403	1.2715
6	1.3432	1.4632	1.4685	1.3969	1.3352	1.1744	1.2894
7	1.4327	1.5912	1.5043	1.5402	1.3717	1.2048	1.4327
8	1.6118		1.6834	1.5043	1.4815	1.4266	1.6118
9	1.773	1.7193	1.6834	1.7551	1.5238	1.5729	1.6834
10	1.7375	1.6834	1.7193	1.7909	1.6124	1.6118	1.6476
11	1.6827	1.6655	1.6655	1.6461	1.701	1.7551	1.7551
12		1.7013	1.6476	1.6461	1.4723	1.6476	1.6476
13		1.6118	1.5402		1.4175	1.4864	1.4685
14		1.4327	1.5043	1.2437		1.3611	1.3611
15	1.39	1.3611			1.3213	1.2536	1.3253
16		1.3611	1.3969		1.2136	1.2178	1.2894
17		1.3611	1.379		1.2071	1.2536	1.3073
18	1.5546	1.4842	1.4327	1.2254	1.3643	1.4327	1.3432
19		1.8446	1.9342	1.5947	1.4723	1.6834	1.7372
20	2.0302	1.97	1.9879	1.7187	1.7187	1.7551	1.7013
21		1.9721	1.9521	.4755	1.6651	1.7909	1.6834
22	1.9022	1.9342	1.8983	1.6827	1.6478	1.7193	1.6118
23		1.9163	1.8804	1.6461	1.6126	1.6834	1.5402
24	1.4327	1.5257	1.7013	1.8088	1.5546	1.5415	1.6118
Max	2.0302	1.9721	1.9879	1.8088	1.7187	1.7909	1.7551
Min	1.0745	1.2403	1.3611	.4755	1.2071	1.1744	1.2536
Avg	1.5054	1.5783	1.6211	1.5116	1.4505	1.4744	1.4917

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

KALWA S/DN.[128]

BU 4261

Substation No/ Name :- 283086 / SHIVAJI HOSPITAL 22/11 KV

Feeder No / Name : 205 / SHIVAJI HOSPITAL NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1463	.1509	.1698	.1772	.1772	.1886
2	.1509	.1463	.1509	.1698	.156	.1417	.1698
3		.1463	.1509	.1509	.1417	.1463	.1509
4	.1509	.1417	.1509	.1509	.1417	.1417	.1509
5	.1509	.1402	.1509	.1509	.1463	.1417	.1509
6	.1509	.1417	.1509	.1509	.1463	.1417	.1509
7		.1387	.1509	.1509	.1463	.1463	.1509
8	.2641		.1886	.1698	.1949	.1772	.2641
9	.3018	.3109	.3018	.2075	.2835	.1772	.3206
10	.2926	.3206	.3584	.2829	.3086	.1698	.3395
11	.2926	.3206	.3584	.2378	.2835	.1698	.3206
12		.3206	.3395	.1646	.2926	.2829	.3961
13		.3395	.3395		.2774	.1698	.3018
14		.2641	.3395	.1829		.1698	.3018
15	.2926	.3018		.1829	.3109	.1698	.3206
16		.3018	.3584		.1772	.1698	.3018
17		.2452	.2452	.1829	.1578	.1698	.2452
18	.2012	.1886	.2801		.1595	.1698	.2075
19			.2614	.1829	.1734	.1886	.2263
20	.1646	.2075	.2263	.1595	.1829	.1886	.1886
21		.1698	.1886		.1753	.1698	.1698
22	.1646	.1698	.1698		.1753	.1886	
23		.1698	.1698	.1646	.1829	.1886	.1698
24	.1509	.1646	.1509	.1886	.1734	.1772	.2263
Max	.3018	.3395	.3584	.2829	.3109	.2829	.3961
Min	.1509	.1387	.1509	.1509	.1417	.1417	.1509
Avg	.2057	.2180	.2318	.179	.1985	.1722	.2354

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

KALWA S/DN.[128]

BU 4261

Substation No/ Name :- 283086 / SHIVAJI HOSPITAL 22/11 KV

Feeder No / Name : 301 / CHINCHPADA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9709	1.0608	1.0974	1.1576	1.0608	1.0985	1.1203
2	.8962	.9214	1.0242	1.094	.9015	1.0166	.9335
3	.8589	.905	.9511	1.0456	.8669	.9465	.9335
4	.8589	.9145	.9511	1.0456	.9431	.8859	1.0829
5	.9709	.9568	1.0242	1.0456	.9214	.8859	1.1203
6	1.0456	1.0631	1.0974	1.0829	.9362	.9465	1.1576
7	1.1576	1.1694	1.2437	1.1203	1.0498	1.0166	1.1949
8	1.2323		1.4266	1.419	1.1443	1.2757	1.3443
9	1.3817	1.5364	1.4266	1.419	1.3112	1.4217	1.531
10	1.3169	1.39	1.3443	1.419	1.267	1.4563	1.4998
11	1.2071	1.2803	1.2323	1.3535	1.2071	1.3817	1.3535
12			1.307	1.2803	1.0631	1.3443	1.2437
13		1.134	1.1576		.9922	1.2178	1.134
14		1.0608	1.0829	1.0242		1.1458	1.0387
15	.9511	.9511		.9145	.9922	1.0829	1.0242
16		.9877	1.0829		.9709	1.0082	1.0242
17		3.5848	1.0456		1.0082	1.0456	.9511
18	1.0242	1.0242	1.0456	.9145	.9877	1.2323	1.0242
19		1.39	1.4937	1.1706	1.0631	1.4937	1.4266
20	1.4998	1.5364	1.6057	1.3535	1.3672	1.643	1.4632
21		1.5729	1.531	1.39	1.3321	1.531	1.4998
22	1.39	1.3535	1.3817		1.3253	1.419	1.39
23		1.3535	1.3817	1.1706	1.3443	1.39	1.3169
24	1.0456	1.1568	1.2437	1.3443	1.134	1.2803	1.3169
Max	1.4998	3.5848	1.6057	1.419	1.3672	1.643	1.531
Min	.8589	.905	.9511	.9145	.8669	.8859	.9335
Avg	1.1130	1.2865	1.2251	1.1882	1.0952	1.2152	1.2135

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

KALWA S/DN.[128]

BU 4261

Substation No/ Name :- 283086 / SHIVAJI HOSPITAL 22/11 KV

Feeder No / Name : 302 / KALWA NAKA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5133	2.4874	2.6612	2.7351	2.4874	2.4874	2.5133
2	2.3655	2.2786	2.5133	2.5873	2.0805	2.1262	2.3655
3	2.2177	2.2314	2.4394	2.5503	2.1437	2.0199	2.1437
4	2.1068	2.1948	2.5133	2.4764	2.0553	2.0851	2.2546
5	2.5133	2.3045	2.5133	2.5133	2.2634	1.949	2.3655
6	2.809	2.5606	2.6612	2.7351	2.4539	2.0553	2.5133
7	2.9938	3.0498	2.8829	2.7721	2.5869	2.3034	2.5873
8	2.9569		3.1786	3.0678	2.9264	2.6578	2.4394
9	2.5873	2.9995	3.0678	3.1417	2.5514	2.9058	2.5873
10	2.5972	2.9938	2.9569	3.2526	2.5766	2.9569	2.846
11	2.7435	2.846	2.4764	3.0727	2.4874	2.9199	2.846
12	2.6703	2.2916	2.3285	2.8166	2.1735	2.5873	2.7351
13		2.5873	2.5133		2.0199	2.4764	2.4764
14		2.4025	2.4025	2.268		2.2177	2.3285
15	2.1948	2.3655		2.0553	1.9845	2.2177	2.1068
16		2.2546	2.2916		2.0199	2.2546	2.1437
17		2.3655	1.0349		2.0553	2.1807	2.1068
18	2.4874	2.4394	2.4764	2.268	2.3411	2.5133	2.4394
19		2.9569	3.1047	2.8532	2.4806	2.9569	2.9938
20		3.3634	3.3265	2.9264	2.9995	3.1786	3.0308
21		3.1786	3.3265		2.8746	2.9938	3.0678
22	2.7641	2.8829	3.2895		3.1459	3.0308	
23	2.9995	3.2895	3.2526	2.7801	2.7641	3.1047	2.846
24	2.6612	2.8349	3.0308	3.1786	2.6703	2.6223	2.8829
Max	2.9995	3.3634	3.3265	3.2526	3.1459	3.1786	3.0678
Min	2.1068	2.1948	1.0349	2.0553	1.9845	1.949	2.1068
Avg	2.5989	2.6591	2.7062	2.7395	2.4410	2.5334	2.5487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

POWER HOUSE S/DN.[727] BU 4727

Substation No/ Name :- 283070 / THANE (W)RECVING STATION

Feeder No / Name : 201 / CLOCK TOWER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-AUG-17
HR	Load (MW)
14	2.0328
15	1.9204
Max	2.0328
Min	1.9204
Avg	1.9766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

POWER HOUSE S/DN.[727] BU 4727

Substation No/ Name :- 283070 / THANE (W)RECIIVING STATION

Feeder No / Name : 202 / BALAWANT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.4003				1.307
2	1.0269			1.4937	1.2136	1.4003	1.2136
3			1.307				
4	.9335			1.307		1.2136	1.2136
5			1.4937		1.2136		
6			1.4937	1.4937		1.2136	1.2136
7	1.4003		1.587	1.4937		1.307	1.4003
8					1.587		
9	1.8671	2.1472				1.6804	1.7556
10			2.4272	1.8671			2.2405
11	2.5206	2.6139				1.8671	
12	2.4272	2.6139	2.6139		2.0538		
13						1.7737	
14	2.3339	2.4272	2.4272	1.4937	1.8671	1.587	2.1472
15		2.4272					
16			2.3339	1.307	1.6804	1.587	2.1472
17		2.3339				1.587	2.0538
18	2.3339		2.3339	1.4937	1.6804	1.6804	
19		2.3339					
20		2.2405	2.4272	1.7737	1.9605	1.9605	2.1472
21		2.1472					
22		1.8671			1.7737	1.7737	1.7737
23		1.6804					
24	1.2136		1.587	1.6804	1.587	1.587	1.587
Max	2.5206	2.6139	2.6139	1.8671	2.0538	1.9605	2.2405
Min	.9335	1.6804	1.307	1.307	1.2136	1.2136	1.2136
Avg	1.7841	2.2575	1.9527	1.5404	1.6617	1.5870	1.7077

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

POWER HOUSE S/DN.[727] BU 4727

Substation No/ Name :- 283070 / THANE (W)RECIIVING STATION

Feeder No / Name : 203 / RAVI UDAY SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2743				.2743
2	.1829				.2801	.2772	.2743
3			.2743				
4	.1829			.1848		.1848	.0914
5			.2743		.2801		
6			.2743	.3696		.2772	.2743
7	.2743		.3658	.3696		.2772	.3658
8					.3734		
9	.4668	.4572				.3658	.4572
10			.5544	.4668			.4572
11	.5601	.5487				.4572	
12	.5601	.6401	.5544	.4668	.5544		
13						.5121	
14	.5601	.5487	.5544	.4572	.462	.4572	.6401
15		.5487					
16			.5544	.3734	.462	.4572	.5487
17		.5487				.4572	.3734
18	.5601		.5544	.3658	.4668	.4572	
19		.6401					
20		.5487	.5544	.4572	.462	.4572	.5487
21		.5487					
22		.4572			.3696	.3658	.3658
23		.4572					
24	.2743		.3658	.3696	.3658	.3696	.3658
Max	.5601	.6401	.5544	.4668	.5544	.5121	.6401
Min	.1829	.4572	.2743	.1848	.2801	.1848	.0914
Avg	.4024	.5404	.4296	.3881	.4076	.3838	.3875

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

POWER HOUSE S/DN.[727] BU 4727

Substation No/ Name :- 283070 / THANE (W)RECVING STATION

Feeder No / Name : 204 / NIRAJ

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1848				.1867
2	.1867			.2801	.0934	.2801	.1867
3			.1867				
4	.1848			.1867		.1867	.1867
5			.1867		.0934		
6			.1867	.2801		.2801	.1867
7	.1867		.1867	.2801		.2801	.1867
8					.1867		
9	.1867	.1867				.1867	.1867
10			.2801	.2801			.2801
11	.3734	.2801				.2801	
12	.3734	.3734	.3734	.2801	.2801		
13						.3734	
14	.3734	.3734	.3734	.2801	.2801	.3734	.2801
15		.3734					
16			.3734	.2801	.2801	.1867	.2801
17		.3734				.1867	.2801
18	.3734		.2801	.2801	.2801	.1867	
19		.3734					
20		.3734	.3734	.2801	.2801	.2801	.2801
21		.3734					
22		.1867			.2801	.1867	.1867
23		.1867					
24	.1867		.1867	.2801	.2801	.2801	.1867
Max	.3734	.3734	.3734	.2801	.2801	.3734	.2801
Min	.1848	.1867	.1848	.1867	.0934	.1867	.1867
Avg	.2695	.314	.2643	.2716	.2334	.2534	.2226

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

POWER HOUSE S/DN.[727] BU 4727

Substation No/ Name :- 283070 / THANE (W)RECVING STATION

Feeder No / Name : 205 / THANE AUDITORIUM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4668				.5601
2	.2801				.3734	.2801	.5601
3			.4668				
4	.2801			.2801		.2801	.5601
5			.4668		.3734		
6			.5228	.4668		.3734	.5601
7	.3734		.4668	.3734		.3734	.7468
8					.4668		
9	.1715	.5601				.5601	.8402
10			.8402	.6535			1.0269
11		1.1203				.8402	
12	.9335	1.1203	.9335	.6535	.8402		
13						1.0269	
14	.9335	.9335	.9335	.5601	.7468	.9335	1.2136
15		.9335					
16			.9335	.5601	.7468	.7468	1.0269
17		1.1203				.7468	1.0269
18	1.0269		.9335	.6535	.7468	.7468	
19		1.1203					
20		1.1203	1.0269	.7468	.8402	1.2136	1.1203
21		.9335					
22		.6535			.6535	.8402	.8402
23		.4668					
24	.4668		.5601	.5601	.4668	.4668	.6535
Max	1.0269	1.1203	1.0269	.7468	.8402	1.2136	1.2136
Min	.1715	.4668	.4668	.2801	.3734	.2801	.5601
Avg	.5582	.9166	.7126	.5508	.6255	.6735	.8258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

POWER HOUSE S/DN.[727] BU 4727

Substation No/ Name :- 283070 / THANE (W)RECVING STATION

Feeder No / Name : 206 / PURNIMA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5601				.5601
2	.5601			.4668	.5601	.4668	.5601
3			.5601				
4	.4668			.3734		.3734	.5601
5			.5601		.4668		
6			.5601	.5601		.5601	.5601
7	.6535		.8402	.6535		.6535	.7468
8					.8402		
9	1.307	1.4937					1.2136
10			2.0538	1.2136			1.7737
11	2.4272	2.6139				2.0328	
12	2.5206	2.7073	2.6139	1.6804	2.1472		
13						2.1472	
14	2.5206	2.5206	2.6139	1.4003	1.8671	2.1472	2.2405
15		2.5206					
16			2.7073	1.4003	1.9605	1.8671	2.1472
17		2.7073				1.7737	2.2405
18	2.6139		2.7073	1.4937	1.7737	1.9605	
19		2.7073					
20		2.2405	2.3339	1.4937	1.6804	1.7737	1.9605
21		1.9605					
22		1.1203			.9335	.8402	1.0059
23		.7392					
24	.5601		.6535	.6535	.6535	.6535	.6535
Max	2.6139	2.7073	2.7073	1.6804	2.1472	2.1472	2.2405
Min	.4668	.7392	.5601	.3734	.4668	.3734	.5601
Avg	1.5144	2.1210	1.5637	1.0354	1.2883	1.3269	1.2479

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

POWER HOUSE S/DN.[727] BU 4727

Substation No/ Name :- 283070 / THANE (W)RECVING STATION

Feeder No / Name : 208 / LAKE VIEW

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6468				.5544
2	.5544			.6535	.5544	.462	.462
3			.5544				
4	.462			.462		.2801	.462
5			.5544		.5544		
6			.5544	.5544		.5544	.462
7	.6468		.7392	.7392		.5544	.5544
8					.6468		
9	.924	.924				.7392	.8316
10			1.2936	.924			1.2012
11	1.386	1.386				.0924	
12	1.2936	1.4784	1.4784	.924	1.1088		
13						1.0164	
14	1.2936	1.386	1.386	.8316	.924	.924	1.2936
15		1.2936					
16			1.4003	.7392	.924	.924	
17		1.386				.924	1.1088
18	1.386		1.4003	.8316	1.0164	1.0164	
19		1.4784					
20		1.4003	1.307	.985	1.1088	1.1088	1.2136
21		1.2936					
22		1.0164			.7392	.8316	.924
23		.8316					
24	.6468		.7392	.8402	.6468	.6468	.6468
Max	1.386	1.4784	1.4784	.985	1.1088	1.1088	1.2936
Min	.462	.8316	.5544	.462	.5544	.0924	.462
Avg	.9548	1.2613	1.0045	.7713	.8224	.7196	.8095

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

POWER HOUSE S/DN.[727] BU 4727

Substation No/ Name :- 283070 / THANE (W)RECVING STATION

Feeder No / Name : 209 / Shreerang

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	26-AUG-17
HR	Load (MW)	Load (MW)
2	.9145	
4	.823	
8	1.1888	
9	1.2803	
11	1.3717	
12	1.3717	
14	1.2803	
18	1.2803	
24	1.0164	.6535
Max	1.3717	.6535
Min	.823	.6535
Avg	1.1697	.6535

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

POWER HOUSE S/DN.[727] BU 4727

Substation No/ Name :- 283070 / THANE (W)RECVING STATION

Feeder No / Name : 210 / CHIRANJIVI SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1848			
2	.1848			.2772	.1867	.2772
3			.1848			
4	.1848			.1848		.1848
5			.1848		.1848	
6			.1848	.2772		.2772
7	.1848		.1848	.2772		.2772
8					.2772	
9	.3696	.3696				.2772
10			.3696	.2801		
11	.3696	.3696				.2772
12	.3696	.2772	.3696	.2801	.3696	
13						.2772
14	.2772	.2772	.3696	.2801	.2772	.2772
15		.2772				
16			.2772	.2801	.2772	.1848
17		.2772				.1848
18	.2772		.2772	.2801	.2772	.1848
19		.3696				
20		.3658	.3696	.2801	.2772	
21		.3696				
22		.3696			.2772	
23		.2772				
24	.1848		.2772	.2772	.2801	.2772
Max	.3696	.3696	.3696	.2801	.3696	.2772
Min	.1848	.2772	.1848	.1848	.1848	.1848
Avg	.2669	.3273	.2695	.2704	.2684	.2464

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

POWER HOUSE S/DN.[727] BU 4727

Substation No/ Name :- 283070 / THANE (W)RECVING STATION

Feeder No / Name : 211 / MTNL -TRS-

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	26-AUG-17
HR	Load (MW)
24	1.587
Max	1.587
Min	1.587
Avg	1.587

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

POWER HOUSE S/DN.[727] BU 4727

Substation No/ Name :- 283070 / THANE (W)RECIIVING STATION

Feeder No / Name : 212 / VPM

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINOUS PROCESS)(NO

STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0886				.0886
2	.1867			.0914	.0876	.0914	.0886
3			.0886				
4	.1772			.0914		.0914	.0895
5			.0886		.0876		
6			.0886	.0914		.0914	.0886
7	.1772		.0886	.0914		.0914	.0886
8					.0876		
9	.1753	.2658					.0886
10			.3658	.0876			.0876
11	.2629	.3544				.0886	
12	.2629	.3582	.3658	.0876	.1829		
13						.0886	
14		.3582	.3658	.0876	.0914	.0886	.2629
15		.2658					
16			.3658	.0876	.0914	.0886	.2629
17		.1772				.0886	.2629
18	.3506		.0914	.0876	.0914	.0886	
19		.1753					
20		.0876	.0914	.0876		.0886	
21		.0876			.0914		
22		.0876			.0914	.0886	.0876
23		.0886					
24	.1772		.0886	.0914	.0876	.0914	.0867
Max	.3506	.3582	.3658	.0914	.1829	.0914	.2629
Min	.1753	.0876	.0886	.0876	.0876	.0886	.0867
Avg	.2213	.2097	.1815	.0893	.0990	.0897	.1319

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283072 / 22/11kv vrindavan s/s

Feeder No / Name : 201 / RABODI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3443		1.5123		1.4712
3	1.307		1.307		
5	1.1949		1.2696		1.3203
7	1.2696		1.419		1.2637
8	1.251	1.4003	1.419		
9	1.3256	1.419			
10	1.2883	1.3443		1.5466	
11		1.4003			
12	1.3203	1.2696		1.6221	
13		1.307			
14	1.307	1.3817		1.5089	
15		1.2883		1.3203	
16				1.2071	
17		1.1576			
18				1.5089	
21		1.7364			
22				1.5844	
23		1.6804		1.6032	
24	1.3443		1.6244		1.5844
Max	1.3443	1.7364	1.6244	1.6221	1.5844
Min	1.1949	1.1576	1.2696	1.2071	1.2637
Avg	1.2952	1.3986	1.4252	1.4877	1.4099

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283072 / 22/11kv vrindavan s/s

Feeder No / Name : 202 / H T CABIN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975		.7842		.6602
3	.5975		.6722		.5281
5	.6348		.6535		.4904
7	.6908		.7095		.5658
8	.7468	.8029	.7842		
9	.7095	.7842			
10	.6348	.6908		.9431	
11		.6348			
12	.6722	.6908		.7545	
13		.6535			
14	.5601	.5975		.6413	
15		.5975		.5658	
16				.5847	
18				.6413	
20				.7545	
22				.7922	
23		.8402		.7733	
24	.6348		.8402		.7545
Max	.7468	.8402	.8402	.9431	.7545
Min	.5601	.5975	.6535	.5658	.4904
Avg	.6479	.6991	.7406	.7167	.5998

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283072 / 22/11kv vrindavan s/s

Feeder No / Name : 203 / VRINDAVAN - 4

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	25-AUG-17
HR	Load (MW)
15	.017
Max	.017
Min	.017
Avg	.017

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283072 / 22/11kv vrindavan s/s

Feeder No / Name : 205 / R W SAWANT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.531		1.7924		1.5089
3	1.4377		1.6244		1.5466
5	1.531		1.531		1.3957
7	1.8111		1.7924		1.3769
8	1.8298	1.9978	1.9418		
9	2.1285	2.2405			
10	2.4272	2.5206		2.0182	
11		2.3339			
12	2.5206	2.3339		1.9616	
13		1.9978			
14	2.2592	2.4646		1.6975	
15		2.4832		1.7541	
16				1.6598	
18				1.6975	
20				2.0748	
22				1.7918	
23		2.0538		1.9805	
24	1.587		1.8671		1.7353
Max	2.5206	2.5206	1.9418	2.0748	1.7353
Min	1.4377	1.9978	1.531	1.6598	1.3769
Avg	1.9063	2.2696	1.7582	1.8484	1.5127

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283072 / 22/11kv vrindavan s/s

Feeder No / Name : 206 / INDIAN LEAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9709		1.3443		1.0185
3	.8962		1.1389		.8676
5	.9149		.9522		.7922
7	1.0082		1.0269		.9054
8	1.0456	1.1576	1.2136		
9	1.2323	1.4377			
10	1.6057	1.587		1.3203	
11		1.6244			
12	1.587	1.7177		1.226	
13		1.6057			
14	1.475	1.5684		1.0562	
15		1.5497		.9808	
16				.8676	
18				.9431	
20				1.2826	
22				1.226	
23		1.363		1.3014	
24	1.0456		1.4003		1.2449
Max	1.6057	1.7177	1.4003	1.3203	1.2449
Min	.8962	1.1576	.9522	.8676	.7922
Avg	1.1781	1.5124	1.1794	1.1338	.9657

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283072 / 22/11kv vrindavan s/s

Feeder No / Name : 207 / T.M.C.PUMPING

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0829		1.3443		1.1317
3	1.0642		1.1389		.9431
5	1.1203		1.1763		.9808
7	1.307		1.2883		1.1128
8	1.3256	1.4146	1.4937		
9	1.4003	1.7177			
10	1.6057	1.7364		1.3392	
11		1.643			
12	1.4937	1.5684		1.1694	
13		1.363			
14		1.4003		1.1694	
15		1.4003		1.0751	
16				1.0562	
18				1.094	
20				1.3957	
22				1.358	
23		1.475		1.3203	
24	1.1389		1.4003		1.3203
Max	1.6057	1.7364	1.4937	1.3957	1.3203
Min	1.0642	1.363	1.1389	1.0562	.9431
Avg	1.2821	1.5243	1.3070	1.2197	1.0977

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283089 / 22 KV VIKAS

Feeder No / Name : 201 / VIKAS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	1.134	1.2536	1.2437	1.0631	1.2437	1.1041	1.2071
24	.8326	.9145	.9511	1.0608	.9511	.9511	1.0242
Max	1.134	1.2536	1.2437	1.0631	1.2437	1.1041	1.2071
Min	.8326	.9145	.9511	1.0608	.9511	.9511	1.0242
Avg	.9833	1.0841	1.0974	1.0620	1.0974	1.0276	1.1157

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283089 / 22 KV VIKAS

Feeder No / Name : 202 / K-VILLA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	1.5893	1.7002	1.7193	1.4784	1.5893	1.3817	1.6827
24	1.2567	1.4937	1.6263	1.5364	1.4563	1.4415	1.531
Max	1.5893	1.7002	1.7193	1.5364	1.5893	1.4415	1.6827
Min	1.2567	1.4937	1.6263	1.4784	1.4563	1.3817	1.531
Avg	1.423	1.5970	1.6728	1.5074	1.5228	1.4116	1.6069

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283089 / 22 KV VIKAS

Feeder No / Name : 205 / Ganraj

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	1.0425	1.0829	1.134	.9568	1.1949	1.1523	1.0242
24	.8589	1.0242	1.2071	1.134	.9774	1.0456	1.0242
Max	1.0425	1.0829	1.2071	1.134	1.1949	1.1523	1.0242
Min	.8589	1.0242	1.134	.9568	.9774	1.0456	1.0242
Avg	.9507	1.0536	1.1706	1.0454	1.0862	1.0990	1.0242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283089 / 22 KV VIKAS

Feeder No / Name : 206 / SHETH DEVELOPERS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	.811	.8299	.7682	.8589	.9054	.9431	.8048
24	.8299	1.0185	1.0185	1.0242	.9431	.9431	1.0185
Max	.8299	1.0185	1.0185	1.0242	.9431	.9431	1.0185
Min	.811	.8299	.7682	.8589	.9054	.9431	.8048
Avg	.8205	.9242	.8934	.9416	.9243	.9431	.9117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283112 / 22/11 KV Rustomjee

Feeder No / Name : 202 / Rustamji Mira Bhainder NON SHEDDABLE WATER SUPPLY AND
Pumping Feeder KV- 11 / OUTGOING UTILITY

DATE	22-AUG-17	23-AUG-17	24-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9		.1848		.1848
10	.1848			
11		.1848		
12	.4805			.1848
13	.1848	.2218		
14		.1478	.1848	.1848
15	.3326	.1478	.1848	.2218
Max	.4805	.2218	.1848	.2218
Min	.1848	.1478	.1848	.1848
Avg	.2957	.1774	.1848	.1941

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283112 / 22/11 KV Rustomjee

Feeder No / Name : 203 / Shyam Sub Station feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9		.8048	.8048	.7682
10	.8413			
11		.8048	.9145	
12	.8413			.7682
13	.6584	.7682		
14	.6219	.695	.6584	.695
15	.695			.7316
Max	.8413	.8048	.9145	.7682
Min	.6219	.695	.6584	.695
Avg	.7316	.7682	.7926	.7408

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283112 / 22/11 KV Rustomjee

Feeder No / Name : 204 / Acura 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9		.6036	.5658	.6036
10	.6036			
11		.5281		
12	.4527			1.8673
13	.3772	.415		
14	.3395	.3018	.4527	.3772
15	.3395		.5281	.3395
Max	.6036	.6036	.5658	1.8673
Min	.3395	.3018	.4527	.3395
Avg	.4225	.4621	.5155	.7969

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283112 / 22/11 KV Rustomjee

Feeder No / Name : 207 / 11 kV Manish Builders

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9		1.0456	1.0829	1.0082
10	1.0082			
11		1.2323	1.2696	
12	1.1203			1.1949
13	1.0456	1.1576		
14	1.1203	1.2323	1.2323	1.0456
15	1.0456			1.0082
Max	1.1203	1.2323	1.2696	1.1949
Min	1.0082	1.0456	1.0829	1.0082
Avg	1.068	1.1670	1.1949	1.0642

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - II[557]

VIKAS COMPLEX S/DN.[726] BU 4726

Substation No/ Name :- 283112 / 22/11 KV Rustomjee

Feeder No / Name : 208 / 11 kV Old Civil

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9		1.4563	1.5684	1.643
10	1.4937			
11		1.6057	1.6804	
12	1.531			1.643
13	1.307	1.531		
14	1.531	1.5684	1.7551	1.643
15	1.3443	1.419	1.419	1.2696
Max	1.531	1.6057	1.7551	1.643
Min	1.307	1.419	1.419	1.2696
Avg	1.4414	1.5161	1.6057	1.5497

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728] BU 4728

Substation No/ Name :- 283085 / TARANGAN S/STN

Feeder No / Name : 201 / Solanki Dham

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-AUG-17
HR	Load (MW)
15	.1905
Max	.1905
Min	.1905
Avg	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283085 / TARANGAN S/STN

Feeder No / Name : 202 / Navnirman

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.448	1.2574	1.2765	1.4861
2		1.3717	1.2193	1.1812	1.3717
3		1.2574	1.1812	1.105	1.3336
4		1.2193	1.1622	1.105	1.2955
5		1.1431	1.1431	1.0669	1.2384
6		1.2384	1.1431	1.1431	1.2955
7		1.3717	1.2193	1.2384	1.3336
8		1.5051	1.3717	1.2765	1.4289
9		1.6575	1.4861	1.3908	1.5242
10		1.6575	1.5432		
11		1.5623	1.5813		
12	1.4861	.2477	1.5051	1.6194	1.467
13	1.5623	1.4289	1.4861	1.6194	
14	1.4861	1.2955	1.3717	1.5242	
15	1.3717	1.2003	1.2765	1.3336	
16	1.3717		1.2003	1.1812	
17	1.4098	1.2193	1.2574		
18	1.467	1.2765	1.3336	1.3336	
19	1.7909	1.6194	1.6766	1.7147	
20	1.8671	1.6385	1.6956	1.7147	
21	1.8671	1.6575	1.7337	1.7147	1.7147
22	1.8099	1.6956	1.5813	1.7147	1.6004
23	1.8099	1.6004	1.6575	1.5242	1.5242
24		1.7337	1.448	1.448	1.5242
Max	1.8671	1.7337	1.7337	1.7147	1.7147
Min	1.3717	.2477	1.1431	1.0669	1.2384
Avg	1.6083	1.3933	1.3971	1.3917	1.4384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283085 / TARANGAN S/STN

Feeder No / Name : 203 / Wimblon

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2667	.2477	.1905	.1905	.1905	.2858
2	.1905	.2286	.2477	.1905	.2096	.1905	.2667
3	.1905	.1905	.2286	.1715	.1905	.1715	.2286
4	.1715	.1905	.2286	.1715	.2096	.1715	.2286
5	.1715	.1905	.2286	.1715	.1715	.1715	.2286
6	.2286	.2286	.2858	.2286	.2286	.1905	.2667
7	.3048	.3048	.3239	.2858	.3048	.1905	.3239
8	.3048	.3048	.3048	.2667	.3048	.2286	.3048
9	.3048	.3048		.2667	.3048	.3048	.2858
10	.3048	.3429		.2667	.3048		
11			.2858	.2477	.3048		
12			.3048		.3239	.3239	.2858
13			.3048	.2477	.3048	.3048	
14			.2667	.3048	.3048	.2858	
15			.2286	.3048	.3048	.2858	
16			.2286		.3048	.2858	
17			.2286	.3048	.2286		
18	.3048		.2477	.2667	.2477	.2858	
19	.3239		.2477	.3048	.3239	.3048	
20	.3048	.3048	.3048	.3048	.3048	.3048	
21	.3429	.3048	.3048	.3048	.3048	.3048	.3048
22	.3239		.3048	.3048	.3048	.3048	.3048
23	.3239	.2858	.2477	.2286	.2286	.2858	.2858
24	.2667	.2858	.2477	.1905	.2286	.2286	.2858
Max	.3429	.3429	.3239	.3048	.3239	.3239	.3239
Min	.1715	.1905	.2286	.1715	.1715	.1715	.2286
Avg	.2701	.2667	.2659	.2511	.2683	.2531	.2776

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283085 / TARANGAN S/STN

Feeder No / Name : 205 / Tarangan

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3336	1.5242	1.7528	1.7337	1.467	1.5051	1.6194
2	1.2765	1.3717	1.7147	1.6385	1.4289	1.4098	1.6194
3	1.2193	1.3336	1.6766	1.5623	1.3717	1.3717	1.5242
4	1.2193	1.3336	1.6575	1.4861	1.3146	1.3336	1.5242
5	1.2955	1.3717	1.6194	1.4289	1.2955	1.2955	1.4289
6	1.5432	1.6766	1.7147	1.6194	1.4289	1.4861	1.4289
7	1.8861	1.8671	1.9052	1.9052	1.5623	1.6385	1.6194
8	1.8671	1.8861	2.0005	1.9052	1.7528	1.5432	1.7147
9	1.9243	2.0576		2.0195	1.8099	1.7147	1.8099
10	2.2481	2.0576		1.9624	1.9624		
11			2.1148	1.7718	1.6956		
12			2.0005	1.6194	1.6575	1.8099	
13			1.9624	1.5432	1.5242	1.7147	
14			1.8861	1.4861	1.5051	1.5242	
15			1.829	1.3717	1.5051	1.3336	
16			1.8861		1.4289	1.3336	
17			1.848	1.3717	1.467		
18	1.6575		1.7337	1.5051	1.4861	1.5242	
19	1.9052		2.0005	1.8099	1.848	1.9052	
20	1.9624	2.0386	2.0005	1.8099	1.848	1.9052	
21	2.0767	2.0005	2.2672	2.0005	.1905	1.9052	2.0005
22	2.0957		2.0767	1.9243	1.9243	1.9052	1.7718
23	1.8861	1.9052	1.9243	1.829	1.7528	1.7147	1.7147
24	1.3717	1.6766	1.8099	1.9243	1.6575	1.6194	1.7147
Max	2.2481	2.0576	2.2672	2.0195	1.9624	1.9052	2.0005
Min	1.2193	1.3336	1.6194	1.3717	.1905	1.2955	1.4289
Avg	1.6923	1.7215	1.8810	1.7056	1.5369	1.5949	1.6531

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283085 / TARANGAN S/STN

Feeder No / Name : 206 / Pumping

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.743	.8383	.9145	.9526	.8002	.7811	.9145
2	.724	.724	.8764	.8954	.7621	.724	.8573
3	.6859	.724	.8573	.8383	.6859	.6859	.8573
4	.6668	.6859	.8383	.8002	.6478	.6668	.8383
5	.724	.724	.8764	.8002	.6478	.6859	.8573
6	.8764	.9145	.9145	.9145	.743	.743	.9145
7	.9717	1.0288	.9526	.9907	.8573	.8002	.9526
8	1.0288	.9717	.9526	1.0479	.9526	.8573	.9526
9	1.0288	1.105		1.0098	1.105	.9335	1.0479
10	1.2574	1.2955		1.0669	1.2193		
11			1.3717	.9907	1.2384		
12			1.3336	.9526	1.1622	1.0479	
13			1.105	.8954	1.086	1.0479	
14			1.1431	.8954	1.086	.9526	
15			1.1622	.8192	1.0479	.9526	
16			1.105		1.0098	.8573	
17			1.1431	.7621	.9717		
18	1.1241		1.1431	.8573	.9717	.8573	
19	1.2193		1.2765	1.0479	1.1241	1.1431	
20	1.2003	1.3336	1.2955	1.105	1.1241	.1143	
21	1.2384	1.2384	1.2003	1.0669	1.105	1.1431	1.1431
22	1.105		1.105	1.0669	1.105	1.0479	1.0479
23	1.0479	1.1431	1.2193	1.0098	.9526	.9526	1.0479
24	.7811	.9526	.9526	1.0288	.9145	.8954	.9526
Max	1.2574	1.3336	1.3717	1.105	1.2384	1.1431	1.1431
Min	.6668	.6859	.8383	.7621	.6478	.1143	.8383
Avg	.9661	.9771	1.0790	.9485	.9717	.8519	.9526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728] BU 4728

Substation No/ Name :- 283085 / TARANGAN S/STN

Feeder No / Name : 305 / Mahavir-II

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7							.1905
8			.1905				.1905
9	.1905	.2286			.2286		
10	.2286	.2286			.2286		
11			.381		.2286		
12			.381	.1524	.3429	.1905	
13			.381	.1524	.3048	.1905	
14			.381	.2286		.1905	
15			.381	.1905	.3429	.1905	
16			.381		.3048	.1905	
17			.3048	.1905	.3048		
18	.3048		.3048	.1905	.3048	.1905	
19	.2286		.3048	.1524	.3048	.1905	
20	.2286	.381	.3048	.1905	.2286	.1905	
21	.1905	.1905	.2286	.1524		.1905	.1905
22	.1905		.2286	.1524	.1905	.1905	.1905
23	.1905	.1905	.1905		.1905		.1905
24		.1905	.1905				
Max	.3048	.381	.381	.2286	.3429	.1905	.1905
Min	.1905	.1905	.1905	.1524	.1905	.1905	.1905
Avg	.2191	.2350	.3023	.1753	.2696	.1905	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283085 / TARANGAN S/STN

Feeder No / Name : 306 / Kalpataru-II

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.4954	.4191	.4572	.4191	.4191	.381
2	.3048	.381	.3048	.381	.3048	.3429	.3429
3	.2667	.3048	.2667	.3048	.2667	.3048	.3048
4	.2667	.2667	.2667	.2667	.2667	.2667	.2667
5	.2667	.2667	.2667	.2667	.2667	.2667	.2667
6	.2286	.2286	.2667	.2667	.2286	.2286	.2667
7	.2667	.2286	.2667	.2667	.2286	.2286	.2667
8	.3048	.3048	.3048	.3048	.2667	.2667	.3048
9	1.1431	.9526		.724	.7621	1.0288	1.1431
10	1.1812	1.105		1.1431	1.1431		
11			1.7528	1.7528	1.7147		
12			2.2862	2.0957	2.21	2.2862	
13			2.0576	2.0957	2.0957	2.2862	2.0957
14			2.0576	2.0195	2.1338	2.2862	
15			2.0195	2.0195	2.1338	2.0957	
16			1.9814		2.0576	2.0957	
17			1.9433	1.9052	2.0576		
18	1.7528		1.9433	1.7147	1.6004	2.0957	
19	1.9052		1.829	1.8671	1.8671	2.2862	
20	1.7909	1.9052	1.7909	1.9052	1.8671		
21	1.8671	1.9052	1.829	1.8671	1.829	2.2862	1.9052
22	1.6004		1.448	1.448	1.448	2.0957	1.4861
23	1.1812	1.1431	.9526	.9526	1.105	.5335	.9526
24	.4954	.6097	.5335	.5335	.4954	.4954	.5335
Max	1.9052	1.9052	2.2862	2.0957	2.21	2.2862	2.0957
Min	.2286	.2286	.2667	.2667	.2286	.2286	.2667
Avg	.8943	.7212	1.2176	1.1547	1.1987	1.2098	.7512

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283091 / ETERNITY S/STN

Feeder No / Name : 201 / Kankia

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	.4763	.4763	.5335	.381	.4572	.4572
2	.381	.4191	.4191	.4954		.4382	.4191
3	.381	.4001	.4001	.4763	.3429	.4191	.4001
4	.3429	.362	.4001	.4382	.362	.4191	.4001
5	.3429	.4191	.4191	.4191	.4001	.4001	.4191
6	.4191	.4954	.4382	.381	.3429	.381	.4572
7	.5144	.5525	.5716	.362	.362	.381	.4954
8	.5906	.9526	.724	.381	.5144	.4001	.5906
9	1.0669	1.1812	1.1622	.5716	.6478	.4763	1.2003
10	1.1241	1.3336	1.3146	.5906	.8573	.5525	1.3146
11	1.2384	1.467	1.5242	.5716	.8573	.5906	1.4289
12		1.4861	1.467	.5144	.8764	.6097	1.3908
13		1.2384	1.3336	.5525	.8002	.5525	1.3336
14		1.2955		.5716	.743	.5716	1.2765
15		1.2765	1.2574	.5144	.7811	.5144	1.2384
16			1.3336	.5144	.743	.5144	1.2574
17			1.2955	.5144	.6668	.5144	1.1812
18	1.0288	1.105	1.1241	.5144	.5716	.5525	1.0288
19	.9526	.7811	.9526	.5525	.5716	.6097	.8002
20	.6859	.724	.7049	.5525	.6097	.5716	.724
21	.6097	.6478	.6668	.5144	.5525	.5525	.6287
22	.5525	.5716	.5716	.5144	.5144	.5335	.5144
23	.5716	.5716	.5716	.4954	.5525		.5144
24		.5144	.4954	.5716	.4382	.4763	.4763
Max	1.2384	1.4861	1.5242	.5906	.8764	.6097	1.4289
Min	.3429	.362	.4001	.362	.3429	.381	.4001
Avg	.6590	.8305	.8532	.5049	.5865	.4995	.8311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283091 / ETERNITY S/STN

Feeder No / Name : 202 / Sandipani

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7909	1.9243	1.9433	2.1719	2.0005	2.0767	2.0386
2	1.7528	1.8099	1.9052	2.1148	1.9814	2.0005	1.7909
3	1.7528	1.7528	1.7909	2.0576	1.8671	1.9052	1.7147
4	1.6766	1.829	1.7528	2.0005	1.829	1.829	1.6004
5	1.6956	1.7337	1.829	1.9433	1.6194	1.7528	1.5813
6	1.7337	1.8099	1.848	1.8861	1.6575	1.6766	1.6766
7	1.7528	1.9243	1.9052	1.829	1.6194	1.6004	1.7528
8	1.829	1.8671	2.0576	1.9052	1.7718	1.6956	1.829
9	1.9814	2.0386	2.0386	2.0576	2.0005	1.7909	2.0005
10	2.0386	1.8861	2.0005	2.1148	1.9814	1.9624	2.0005
11	1.9814	1.8861	2.0195	2.0957	2.0957	1.9814	1.9433
12		1.8861	1.9814	1.8671	1.8861	1.9052	1.8861
13		1.7528	1.8099	1.7909	1.7718	1.8099	1.7337
14			1.7337	1.6575	1.6766	1.7147	1.6004
15			1.7147	1.5242	1.6385	1.6194	1.6004
16			1.7528	1.467	1.6004	1.6004	1.5813
17			1.8099	1.6004	1.6575	1.6385	1.6766
18	1.7528	1.7718	1.8861	1.7528	1.8099	1.7718	2.2672
19	2.1529	2.1338	2.1719	2.21	2.0957	2.1719	2.2672
20	2.4958	2.4958	2.4768	2.3624	2.3624	2.3815	2.4577
21	2.4768	2.5339	2.4768	2.2481	2.3624	2.3815	2.4006
22	2.4768	2.4958	2.4958	2.21	2.3434	2.3243	2.2862
23	2.3434	2.5339	2.4387	2.1719	2.2291	2.2672	2.21
24		2.0957	2.1719	2.2481	2.0386	2.1719	2.1338
Max	2.4958	2.5339	2.4958	2.3624	2.3624	2.3815	2.4577
Min	1.6766	1.7337	1.7147	1.467	1.6004	1.6004	1.5813
Avg	1.9814	2.0081	2.0005	1.9703	1.9123	1.9179	1.9179

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728] BU 4728

Substation No/ Name :- 283091 / ETERNITY S/STN

Feeder No / Name : 203 / ACC-I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-AUG-17
HR	Load (MW)
21	.9907
Max	.9907
Min	.9907
Avg	.9907

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283091 / ETERNITY S/STN

Feeder No / Name : 205 / Jay Tower

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2384	1.448	1.105	1.448	1.2955	1.2765	1.2955
2	1.1812	1.3908	1.0669	1.4289	1.2384	1.2193	1.1812
3	1.1812	1.3336	.9717	1.3908	1.1812	1.1431	1.0098
4	1.2193	1.2384	.9335	1.3717	1.086	1.086	.9145
5	1.2193	1.1812	.9335	1.3336	1.0479	1.0098	.7621
6	1.2955	1.3336	.9907	1.3146	1.105	.9526	.8192
7	1.3717	1.5051	1.2003	1.2955	1.1241	.8954	.9335
8	1.448	1.5242	1.3908	1.3527	1.2765	1.2193	1.2955
9	1.448	1.5051	1.3908	1.3527	.9526	1.2384	1.3336
10	1.4289	1.4861	1.3146	1.2574	1.3336	1.2765	1.3336
11	1.448	1.4861	1.3527	1.1812	1.3527	1.2384	1.3336
12		1.4861	.8573	1.1812	1.2193	1.2574	1.2765
13			1.2765	1.1241	1.2193	1.2193	1.2384
14				1.1812	1.2955	1.2574	1.2765
15			1.2384	1.0479	1.1812	1.2193	1.1622
16			1.1431	1.0669	1.105	1.1241	1.0669
17			1.1241	1.0669	1.1241	1.1241	1.1431
18	1.3146	1.2193	1.105	1.086	1.1622	.8573	1.2003
19	1.6385	1.5051	1.2765	1.3908	.9717	1.3717	1.3336
20	1.7337	1.7337	1.467	1.4098	1.4861	1.3908	1.5242
21	1.848	1.9243	1.2765	1.1812	1.5813	1.6194	1.5813
22	1.8099	1.6766	1.3717	1.2955	1.2193	1.5623	1.5051
23	1.7147	1.7147	1.5623	1.4289	1.467		1.448
24		1.4861	1.105	1.4861	1.3336	1.3527	1.3908
Max	1.848	1.9243	1.5623	1.4861	1.5813	1.6194	1.5813
Min	1.1812	1.1812	.8573	1.0479	.9526	.8573	.7621
Avg	1.4435	1.4831	1.1936	1.2781	1.2233	1.2135	1.2233

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283094 / RAHEJA S/STN

Feeder No / Name : 201 / L.I.C. Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2384	1.4289	1.3717	1.3908	1.3146	1.467
2		1.0479	1.1431	1.3336	1.3527	1.2955	1.3908
3		1.0479	1.0479	1.3146	1.3146	1.2574	1.3527
4		1.0479	1.0479	1.2765	1.2574	1.2384	1.3527
5		1.0479	1.0479	1.2193	1.2384	1.2003	1.2765
6		1.0479	1.1431	1.1812	1.1812	1.1431	1.2003
7		1.2384	1.2384	1.1622	1.1431	1.086	1.2574
8		1.3336	1.3336	1.3336	1.2574	1.1431	1.2384
9		1.3908	1.3336	1.3336	1.2384	1.2384	1.2384
10		1.5051	1.5242	1.3336	1.5242	1.3336	1.5242
11		1.6004	1.7147	1.4289	1.5242	1.4289	1.7147
12		1.6575	1.7147	1.3336	1.5242	1.5242	1.5242
13		1.6194	1.5242	1.3336	1.4289	1.5242	1.5242
14	1.448	1.5242	1.5242	1.2384	1.4289	1.3336	1.4289
15	1.4289	1.5242	1.5242	1.1431	1.3336	1.3336	1.3336
16		1.3908	1.4289	1.0479	1.2384	1.1622	1.3527
17		1.2765	1.4289	1.105	1.2384	1.1431	1.2955
18		1.2955	1.3908	1.2193	1.2384	1.2193	1.2765
19	1.5623	1.6385	1.5242	1.4098	1.4861	1.4861	1.5242
20	1.6385	1.6575	1.6766	1.5242	1.5813	1.6766	1.6004
21	1.7147	1.7147	1.7147	1.6004	1.6575	1.7147	1.6385
22	1.6194	1.7147	1.6385	1.5242	1.6194	1.6385	1.5623
23	1.5242	1.6194	1.5623	1.4861	1.5242	1.105	1.467
24		1.4289	1.4289	1.448	1.4098	1.467	1.467
Max	1.7147	1.7147	1.7147	1.6004	1.6575	1.7147	1.7147
Min	1.4289	1.0479	1.0479	1.0479	1.1431	1.086	1.2003
Avg	1.5623	1.4003	1.4202	1.3209	1.3805	1.3336	1.4170

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283094 / RAHEJA S/STN

Feeder No / Name : 202 / Gangotri

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2384	1.5242	
2		1.1431	1.2384	
3		1.1431	1.1431	
4		1.1431	1.1431	
5		1.1431	1.1431	
6		1.1431	1.3336	
7		1.4289	1.4289	
8		1.5242	1.4289	
9		1.5432	1.4289	
10		1.6194	1.6194	
11		1.6385	1.6194	
12		1.5242		
13		1.4289		
14	1.2955	1.3336		
15	1.2193	1.3336		
16		1.2574		
17		1.2955		
18		1.4289		
19	1.6385	1.7147		
20	1.8099	1.8671		
21	1.848	1.848		.6668
22	1.7147	1.848		
23	1.7147	1.8099		
24		1.5242	1.5242	
Max	1.848	1.8671	1.6194	.6668
Min	1.2193	1.1431	1.1431	.6668
Avg	1.6058	1.4551	1.3813	.6668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283094 / RAHEJA S/STN

Feeder No / Name : 203 / Tip-Top Plaza

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1905	.1905	.1715	.1524	.1524	.1905
2		.1905	.1905	.1715	.1524	.1524	.1524
3		.1905	.1905	.1524	.1524	.1524	.1524
4		.1905	.1905	.1524	.1524	.1524	.1524
5		.1905	.0953	.1524	.1524	.1524	.1524
6		.1905	.1905	.1524	.1524	.1524	.1524
7		.1905	.1905	.1524	.1524	.1524	.1524
8		.1905	.1905	.2096	.1905	.2858	.2096
9		.2286	.1905	.1905	.1905	.2858	.1905
10		.2667	.2858	.1905	.2858	.381	.1905
11		.2477	.1905	.1905	.2858	.4763	.1905
12		.2858	.1905	.1905	.2858	.4763	.1905
13		.2858	.1905	.1905	.2858	.4763	.2858
14	.4001	.3048	.1905	.1905	.2858	.4763	.2858
15	.3048	.3048	.1905	.1905	.1905	.381	.2858
16		.3048	.1905	.1905	.2858	.3048	.2477
17		.2286	.1524	.1715	.2096	.4572	.2096
18		.2096	.1715	.1905	.2286	.5335	.2096
19	.2667	.2667	.2477	.2286	.3048	.6668	.2477
20	.2667	.2286	.2286	.2286	.2858	.6668	.2286
21	.2858	.2286	.2096	.2286	.3048		.2096
22	.2858	.2286	.2286	.2286	.2286	.5716	.2096
23	.2858	.1905	.1905	.1715	.2096	.3048	.2096
24		.1905	.1905	.1334	.1715	.1905	.1905
Max	.4001	.3048	.2858	.2286	.3048	.6668	.2858
Min	.2667	.1905	.0953	.1334	.1524	.1524	.1524
Avg	.2994	.2302	.1945	.1842	.2207	.3479	.2040

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283094 / RAHEJA S/STN

Feeder No / Name : 204 / Anand Timber

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5716	.5716	.6478	.5906	.6097	.6097
2		.5716	.5716	.6287	.5716	.6097	.5716
3		.5716	.5716	.5906	.5335	.5716	.5525
4		.5716	.5716	.5716	.5144	.5525	.5335
5		.4763	.5716	.5716	.5335	.5335	.5335
6		.5716	.5716	.5525	.4954	.5335	.5144
7		.5716	.5716	.5335	.4763	.4954	.4954
8		.5716	.5716	.5716	.5716	.4763	.6097
9		.5906	.5716	.5716	.6668	.5716	.6668
10		.5144	.8573	.6668	.6668	.6668	.7621
11		.5525	.8573	1.3336	.6668	.6668	.7621
12		.4191	.7621	.5716	.7621	.5716	.8573
13		.5906	.6668	.4763	.5716	.5716	.5716
14	.8002	.7621	.7621	.4763	.6668	.5716	.6668
15	.6097	.7621	.7621	.4763	.6668	.5716	.6668
16		.7621	.7621	.381	.6668	.4763	.6859
17		.724	.6668	.4191	.6668	.4191	.6478
18		.743	.6668	.4572	.6859	.4763	.6668
19	.8192	.8383	.6668	.5144	.6478	.5716	.7621
20	.724	.743	.6668	.6097	.6668	.6478	.724
21	.724	.724	.6668	.6097	.6478	.6478	.6668
22	.7621	.6478	.7621	.6097	.6668	.6478	.6287
23	.6668	.6668	.724	.6097	.6478	.7049	.6478
24		.6668	.6668	.7621	.6097	.6668	.6287
Max	.8192	.8383	.8573	1.3336	.7621	.7049	.8573
Min	.6097	.4191	.5716	.381	.4763	.4191	.4954
Avg	.7294	.6327	.6692	.5922	.6192	.5763	.6430

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283094 / RAHEJA S/STN

Feeder No / Name : 205 / A.C.C.-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0479	1.2384	1.1812	1.3717	1.2384	1.3527
2		.9526	1.0479	1.1622	1.3336	1.1812	1.3146
3		.9526	1.0479	1.1241	1.2765	1.1431	1.2765
4		.9526	1.0479	1.1431	1.2384	1.105	1.2574
5		.9526	1.0479	1.2003	1.1812	1.0669	1.2193
6		1.1431	1.2384	1.2384	1.1241	1.0288	1.1622
7		1.2384	1.5242	1.2955	1.0669	1.0098	1.1431
8		1.5242	1.5242	1.2574	1.1812	1.2384	1.4098
9		1.5623	1.5242	1.5242	1.3336	1.2384	1.5242
10		1.467	1.5242	1.4289	1.5242	1.6194	1.5242
11		1.5242	1.5242	1.3336	1.6194	1.4289	1.6194
12		1.7147	1.5242	1.2384	1.6194	1.5242	1.5242
13		1.5242	1.4289	1.4289	1.5242	1.3336	1.3336
14	1.2384	1.2574	1.5242	1.3336	1.1431	1.4289	1.3336
15	1.4098	1.4098	1.2384	1.0479	1.1431	1.1431	1.1431
16		1.4289	1.2384	1.1431	1.1431	1.0669	1.2193
17		1.2384	1.2003	.9717	1.3527	1.105	1.2574
18		1.2955	1.2384	1.1812	1.3527	1.4289	1.1812
19	1.5432	1.3527	1.5432	1.3527	1.6385	1.5242	1.5813
20	1.6766	1.8099	1.8099	1.5623	1.6956	1.5623	1.5432
21	1.7528	1.7147	1.5242	1.5623	1.5242	1.5242	1.6766
22	1.4289	1.4861	1.467	1.4289	1.5623	1.3908	1.3527
23	1.5242	1.4289	1.5623	1.3908	1.448	1.3336	1.2574
24		1.2384	1.2384	1.5242	1.3527	1.2193	1.4098
Max	1.7528	1.8099	1.8099	1.5623	1.6956	1.6194	1.6766
Min	1.2384	.9526	1.0479	.9717	1.0669	1.0098	1.1431
Avg	1.5106	1.3424	1.3678	1.2940	1.3646	1.2868	1.3590

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283094 / RAHEJA S/STN

Feeder No / Name : 206 / Raheja

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0479	1.4289	1.4098	1.3336	1.2955	1.2574
2		.8573	1.2384	1.3717	1.2955	1.2574	1.1431
3		.8573	1.1431	1.3336	1.2574	1.1812	1.1622
4		.7621	1.0479	1.2955	1.2384	1.105	1.1241
5		.8573	1.1431	1.3336	1.2765	1.1812	1.1812
6		.9526	1.2384	1.3146	1.3336	1.2193	1.2384
7		1.2384	1.3336	1.3146	1.3146	1.2955	
8		1.2384	1.4289	1.4098	1.3908	1.2003	1.3717
9		1.2955	1.6194	1.5242	1.3336	1.1431	1.2384
10		1.4098	1.7147	1.5242	1.7147	1.3336	1.5242
11		1.5242	1.6194	1.5242	1.6194	1.4289	1.6194
12	1.448	1.5623	1.5242	1.5242	1.5242	1.3336	1.4289
13		1.3336	1.4289	1.3336	1.5242	1.2384	1.4289
14	1.3527	1.3336	1.4289	1.1431	1.4289	1.3336	1.2384
15	1.3908	1.3717	1.4289	1.1431	1.3336	1.2384	1.3336
16		1.3336	1.3336	1.1431	1.3336	1.1431	1.2955
17		1.3336	1.2765	1.2003	1.1431	1.0479	1.2765
18		1.3336	1.2955	1.3717	1.2384	1.3717	1.3336
19	1.6194	1.5623	1.4861	1.5242	1.7147	1.5623	1.5242
20	1.5242	1.6385	1.6766	1.5623	1.6194	1.6385	1.5242
21	1.6194	1.6194	1.6194	1.2955	1.6766	1.6575	1.4861
22	1.5242	1.5813	1.6575	1.5623	1.5242	1.5623	1.4098
23	1.4289	1.6194	1.6004	1.4861	1.4289	1.4861	1.448
24		1.3336	1.4289	1.5242	1.3717	1.3908	
Max	1.6194	1.6385	1.7147	1.5623	1.7147	1.6575	1.6194
Min	1.3527	.7621	1.0479	1.1431	1.1431	1.0479	1.1241
Avg	1.4885	1.2916	1.4226	1.3821	1.4154	1.3186	1.3449

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283094 / RAHEJA S/STN

Feeder No / Name : 207 / Nitin Casting

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8573	1.1431	1.0288	1.1622	.8954	1.1431
2		.7621	.8573	.9907	1.105	.8573	1.1241
3		.7621	.8573	.9526	1.086	.8573	1.086
4		.7621	.8573	.9717	1.0479	.8383	1.0479
5		.7621	.9526	1.0098	1.0098	.8954	1.0479
6		.9526	.9526	1.0669	1.0288	.9145	1.0098
7		1.0479	1.1431	1.0479	.9526	.9335	.9907
8		1.2384	1.1431	1.1431	1.086	.9717	1.1431
9		1.3527	1.2384	1.1431	1.2384	1.0479	1.2384
10		1.448	2.0005	1.1431	1.3336	1.1431	1.3336
11		1.5242	2.0005	1.3336	1.5242	1.1431	1.3336
12		1.5051	1.6194	1.1431	1.4289	1.1431	1.3336
13		1.3908	1.8099	1.1431	1.1431	1.1431	1.2384
14	1.6575	1.2955	1.9052	1.0479	1.2384	1.1431	1.2384
15	1.7909	1.2574	1.9052	1.0479	1.1431	1.0479	1.1431
16		1.2765	1.6194	.9526	1.1431	.9717	1.105
17		1.2765	1.3527	.9526	1.0669	1.0098	1.0669
18		1.3527	1.3717	1.0669	1.1622	1.105	1.105
19	1.2955	1.4289	1.4289	1.1812	1.2384	1.2574	1.2574
20	1.4289	1.3908	1.448	1.2955	1.3146	1.3908	1.2955
21	1.467	1.5242	1.5242	1.2955	1.3717	1.448	1.3717
22	1.4289	1.467	1.4861	1.3527	1.3336	1.4289	1.3146
23	1.2384	1.3336	1.3717	1.1812	1.1241	1.2955	1.1812
24		1.0479	1.1431	1.2765	1.1431	1.1241	1.1812
Max	1.7909	1.5242	2.0005	1.3527	1.5242	1.448	1.3717
Min	1.2384	.7621	.8573	.9526	.9526	.8383	.9907
Avg	1.4724	1.2090	1.3805	1.1153	1.1844	1.0836	1.1804

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

GADKARI S/DN.[728]

BU 4728

Substation No/ Name :- 283094 / RAHEJA S/STN

Feeder No / Name : 208 / SITAVIHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.572	2.8578	2.7625	.9526	2.7244	1.0288
2		2.572	2.7625	2.6673	.9145	2.6673	1.0098
3		2.572	2.572	2.6101	.8954	2.5911	.9717
4		2.572	2.572	2.5339	.9335	2.4768	.9526
5		2.4768	2.572	2.2862	1.0669	2.2862	1.0479
6		2.4768	2.7625	2.0767	1.2574	2.2862	1.105
7		2.2862	2.572	1.2574	1.7909	1.3336	1.2384
8		2.8578	2.9531	.9907	2.4768	1.0479	2.8578
9		2.9721	3.1436	1.0479	2.8578	1.2384	2.9531
10		3.0483	3.5246	1.0479	2.9531	1.3336	3.4294
11		2.9912	3.6199	1.0479	2.9531	1.3336	3.5246
12		3.5056	3.5246	.9526	3.0483	1.3336	3.3341
13		3.3532	3.2388	.9526	2.9531	1.2384	3.0483
14	3.0864	3.2388	3.1436	.9526	2.7625	1.3336	3.2388
15	3.1055	3.2388	2.6673	.9526	2.6673	1.1431	2.9531
16		3.3341	3.3341	.9526	2.9531	1.1431	3.1626
17		3.4675	3.1817	.9145	3.0483	.9717	3.0674
18		3.2769	3.2388	.9717	2.8578	1.0479	3.0483
19	3.1626	3.2579	3.1245	.9526	2.8578	1.0479	3.1626
20	3.0674	3.1436	3.0864	.9907	2.915	1.0669	2.934
21	3.0483	3.0483	2.9531	1.0669	2.7816	1.1431	2.8578
22	2.7625	2.9531	2.7625	.9907	2.6292	1.1431	2.6292
23	2.572	2.572	2.8959	1.0288	2.7054	1.105	2.5911
24		2.7625	2.8578	2.8578	.9526	2.7816	1.0669
Max	3.1626	3.5056	3.6199	2.8578	3.0483	2.7816	3.5246
Min	2.572	2.2862	2.572	.9145	.8954	.9717	.9526
Avg	2.9721	2.9396	2.9967	1.4527	2.2577	1.5758	2.3839

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

KISAN NAGAR[540]

BU 4540

Substation No/ Name :- 283100 / KISAN NAGAR

Feeder No / Name : 201 / Sub-Station No.6

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9335	1.1389	1.0082	1.1203	.9522	1.0082	.9522
2	.9335	1.0829	.9522	1.0456	.8962	.8775	.9149
3	.8589	.8589	.8589	.9335	.8402	.8589	.8589
4	.8215	.7655	.8589	.8962	.8029	.8215	.8029
5	.8215	.8029	.8402	.8962	.7655	.8215	.8215
6	.8962	.9149	.8775	.9335	.8029	.8215	.8589
7	.9709	.9896	.9522	.9335	.8589	.8402	.9149
8	1.0642	1.1016	1.1389	1.0456	.9896	.9709	1.0829
9	1.0642	1.251	1.2136	1.1576	1.1949	1.1949	1.1576
10	1.307	1.2136	1.2696	1.1389	1.1576	1.1576	1.2696
11	1.2136	1.2323	1.2696	1.1016	1.2696	1.1949	1.1763
12	1.2323	1.2323	1.3256	1.0829	1.1203	1.1389	1.1203
13	1.1576	1.1203	1.3817	1.0269	1.1016	1.1016	1.1016
14	1.251	1.1203	1.1949	.8962	1.0642	1.1203	1.0642
15	1.1016	1.1203	1.0829	.8775	1.0269	1.0456	1.1763
16	1.0456	1.0456	1.0829	.8029	1.0456	1.0829	1.0456
17	.9896	1.0456	1.1016	.8029	.9709	.9335	1.0082
18	1.0829	1.0642	1.1576	.8775	1.0269	.8962	1.0642
19	1.2323	1.2883	1.2136	1.1016	1.1949	1.2136	1.2696
20	1.3256	1.3817	1.363	1.1576	1.3256	1.2883	1.5684
21	1.307	1.3817	1.3443	1.1949	1.251	1.2883	1.419
22	1.2883	1.3256	1.363	1.1763	1.2883	1.251	1.2883
23	1.4377	1.3256	1.1576	1.4563	1.1763	1.1949	1.2323
24	1.0082	1.1949	1.1949	1.1576	1.1389	1.0829	1.1203
Max	1.4377	1.3817	1.3817	1.4563	1.3256	1.2883	1.5684
Min	.8215	.7655	.8402	.8029	.7655	.8215	.8029
Avg	1.0977	1.1249	1.1335	1.0339	1.0526	1.0502	1.0954

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

KISAN NAGAR[540]

BU 4540

Substation No/ Name :- 283100 / KISAN NAGAR

Feeder No / Name : 203 / Nair Hotel

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7741	1.848	1.7741	2.0328	1.7187	1.7372	1.7556
2	1.7002	1.8111	1.6817	1.922	1.6263	1.6078	1.6448
3	1.6263	1.5154	1.5893	1.8111	1.5339	1.5524	1.5893
4	1.5524	1.46	1.5524	1.6632	1.4969	1.5154	1.46
5	1.5524	1.5339	1.5339	1.5893	1.4969	1.5154	1.4415
6	1.5524	1.5893	1.7187	1.5893	1.5154	1.4784	1.5154
7	1.6263	1.7002	1.7187	1.6632	1.5524	1.423	1.5708
8	1.7187	1.848	1.8296	1.7741	1.7187	1.5893	1.7002
9	1.9035	1.9959	2.0513	1.885	1.885	1.885	1.9589
10	2.1807	2.3101	2.4025	1.9774	2.4025	2.0883	2.347
11	2.1622	2.6242	2.3285	2.0144	2.2177	2.1437	2.2731
12	2.1068	2.2177	2.3101	1.848	2.1068	2.0144	2.1437
13	2.0698	2.0698	2.2916	1.8665	1.9404	1.9404	2.0513
14	2.1253	2.1807	2.1068	1.7002	1.9774	2.0698	1.8665
15	2.0513	2.0698	2.1068	1.6078	1.7556	1.8111	1.8665
16	1.9589	2.0328	1.9959	1.5339	1.8111	1.6632	1.848
17	2.0144	1.9589	2.0513	1.5708	1.7741	1.7002	1.885
18	1.9774	1.9774	2.0328	1.6448	1.9035	1.922	2.0883
19	2.1992	2.2361	2.2361	1.9774	2.2177	2.1622	2.2361
20	2.3285	2.3655	2.5133	2.1437	2.2361	2.2361	2.4949
21	2.3285	2.4025	2.384	2.1807	2.1992	2.1992	2.2731
22	2.2546	2.384	2.4025	2.1622	2.1622	2.1622	2.1253
23	2.347	2.1992	2.1807	2.2177	2.1253	2.1068	2.0144
24	1.7741	1.9959	2.0328	2.0328	1.9404	1.9589	1.9589
Max	2.347	2.6242	2.5133	2.2177	2.4025	2.2361	2.4949
Min	1.5524	1.46	1.5339	1.5339	1.4969	1.423	1.4415
Avg	1.9535	2.0136	2.0344	1.8503	1.8881	1.8534	1.9212

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

KISAN NAGAR[540]

BU 4540

Substation No/ Name :- 283100 / KISAN NAGAR

Feeder No / Name : 204 / Administrative Bldg.

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.924	.9425	.9055	1.0719	.9055	.8871	.8686
2	.8501	.8871	.8871	1.0349	.8501	.8131	.8131
3	.8131	.7392	.8501	.924	.7947	.7762	.7577
4	.7392	.7207	.7947	.8501	.7762	.7023	.6838
5	.7392	.7392	.7577	.7392	.7762	.7023	.7023
6	.7762	.7947	.8316	.7392	.7577	.7207	.7207
7	.8501	.8871	.8871	.8131	.8316	.7392	.8131
8	.8501	.9425	.9425	.8686	.8316	.7947	.8501
9	1.0719	1.1458	1.1088	1.0164	1.0164	.8501	1.0534
10	1.2197	1.2197	1.2012	1.0349	1.1273	1.0164	1.2197
11	1.1827	1.2567	1.2197	.9795	1.1273	.924	1.2197
12	1.1273	1.2567	1.2382	.9055	1.0164	.9425	1.1827
13	1.0164	1.0534	1.0719	.8316	.9979	.8501	1.1088
14	1.0164	1.0903	1.1273	.8501	.924	.8131	1.0719
15	1.0349	1.0903	1.1458	.7947	.8686	.7577	1.0534
16	1.1088	1.0534	1.1088	.7577	.8686	.7207	1.0349
17	1.0903	1.0534	1.1273	.7392	.8316	.7207	1.0164
18	1.0903	1.0349	1.0719	.8501	.8316	.7947	1.0903
19	1.1643	1.0903	1.0719	.9425	.9795	.924	1.1273
20	1.1643	1.1643	1.1458	1.0903	1.0164	1.0164	1.1827
21	1.1643	1.1088	1.1643	1.0903	1.0164	1.0534	1.1273
22	1.1827	1.0903	1.1643	1.0534	1.0164	1.0164	1.0719
23	1.1088	1.1088	1.1273	1.0349	1.0349	.9979	1.0903
24	.924	1.0534	1.0534	1.0719	.9979	.9425	.9425
Max	1.2197	1.2567	1.2382	1.0903	1.1273	1.0534	1.2197
Min	.7392	.7207	.7577	.7392	.7577	.7023	.6838
Avg	1.0087	1.0218	1.0418	.9202	.9248	.8532	.9918

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

KISAN NAGAR[540]

BU 4540

Substation No/ Name :- 283100 / KISAN NAGAR

Feeder No / Name : 205 / Kalibai

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2957	.3142	.3142	.3326	.3326	.3142	.3142
2	.2587	.2957	.2957	.3326	.2957	.2218	.2957
3	.2218	.2957	.2772	.2957	.2402	.2402	.2772
4	.2218	.2772	.2772	.2957	.2218	.2587	.2772
5	.1848	.2772	.2587	.2587	.2587	.2587	.2957
6	.2587	.2957	.3142	.2587	.2587	.2587	.2957
7	.2957	.3511	.3326	.2957	.2957	.2957	.3142
8	.3142	.3511	.3511	.3326	.3142	.3142	.3326
9	.3881	.3511	.3326	.3696	.3511	.3511	.3881
10	.3326	.3881	.3696	.3326	.3326	.3511	.3511
11	.3326	.3142	.3326	.3326	.3142	.3326	.3326
12	.3326	.3511	.3511	.3326	.3326	.3326	.3696
13	.2957	.3142	.3142	.3142	.2957	.3142	.3142
14	.3142	.3326	.3142	.2957	.3142	.2957	.3142
15	.3142	.3142	.2957	.2957	.2957	.2957	.3142
16	.2957	.2957	.2957	.2402	.2957	.2957	.3142
17	.2957	.2957	.2957	.2587	.2957	.2218	.2957
18	.2957	.2957	.2957	.2402	.3142	.2957	.3142
19	.3326	.2957	.3142	.3326	.3511	.3142	.3511
20	.4251	.3881	.4251	.3881	.3696	.4066	.4066
21	.3696		.3881	.3696	.4066	.3881	.3881
22	.3511	.3511	.3696	.3696	.3511	.3881	.3696
23	.3511	.3696		.3326	.3511	.3696	.3326
24	.3142	.3326	.3511	.3511	.3326	.3511	.3326
Max	.4251	.3881	.4251	.3881	.4066	.4066	.4066
Min	.1848	.2772	.2587	.2402	.2218	.2218	.2772
Avg	.3080	.3238	.3246	.3149	.3134	.3111	.3288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

KISAN NAGAR[540]

BU 4540

Substation No/ Name :- 283100 / KISAN NAGAR

Feeder No / Name : 206 / Old Modella

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7712	.8764	.8063	.9816	.8589	.8939	.8764
2	.7011	.8063	.7712	.9465	.8063	.7712	.8413
3	.6661	.7712	.7537	.8764	.7712	.7537	.7712
4	.631	.6836	.7011	.8063	.7712	.7362	.7362
5	.631	.7186	.7186	.7011	.7362	.7186	.7011
6	.631	.7362	.7362	.7011	.7011	.7186	.7186
7	.7011	.7537	.7888	.7362	.7186	.7011	.7537
8	.8589	.8764	.8413	.7888	.8413	.8413	.8413
9	.9465	.964	.9465	.8939	.929	.8939	.9114
10	.9991	1.0692	1.0341	.9114	.7442	1.0867	1.0692
11	1.0517	1.0692	1.0867	.8939	1.0517	1.0867	1.0867
12	1.1393	1.1043	1.0517	.8589	1.0341	.9991	1.0692
13	.9991	.9816	1.0341	.8413	1.0166	.9991	.964
14	.9816	.9991	1.0166	.8063	.964	.9816	.929
15	.964	.9465	.9816	.7537	.929	.8939	.8939
16	.9816	.9991	1.0517	.7011	.929	.8939	.8939
17	.9991	.964	.9991	.7362	.8939	.929	.8939
18	.9991	.9816	1.0166	.7888	.9412	.9991	.9816
19	1.0517	1.0692	1.0341	.8939	1.0517	1.1043	1.1568
20	1.1744	1.1218	1.1218	1.0166	1.1393	1.1393	1.1919
21	1.1043		1.1043	1.0341	1.0692	1.0517	1.0692
22	1.0692	1.0166	1.0692	.964	1.0867	1.0692	1.0341
23	.9465	.9465	.9816	.9816	1.0692	.9991	.964
24	.7712	.9114	.9114	.9816	.9114	.9465	.964
Max	1.1744	1.1218	1.1218	1.0341	1.1393	1.1393	1.1919
Min	.631	.6836	.7011	.7011	.7011	.7011	.7011
Avg	.9071	.9290	.9399	.8581	.9152	.9253	.9297

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

KOPRI S/DN.[655]

BU 4655

Substation No/ Name :- 283074 / WALMIKI S/S

Feeder No / Name : 203 / Walmiki

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6161	.6908	.7282	.6535	.6908	.6722
2		.5975	.6348	.6908	.5975	.6722	1.2696
3		.5975		.6722	.5788	.6535	.6161
4	.5415	.5788		.6348	.5975	.6161	.6161
5	.5601	.6161		.6535	.6161	.5788	.6348
6	.7282	.8215	.7655	.8029	.6348	.6161	.6722
7	.7842	.7468	.8029	.7282	.6535	.5975	.7095
8	.8029	.8402	.8775	.7842	.7282	.6722	.7468
9	.7842	.8589	.7842	.8589	.7095		.8402
10	.7842	.8962	.8029	.8775		.8402	.8215
11		.7842		.8215	.7655	.7842	.8589
12		.7468		.6722	.7468	.7842	.6908
13		.7468		.6535		.7282	.6722
14	.6535	.7095		.6161		.6722	.6348
15	.5975	.6348	.6348		.5975	.5788	.5975
16		.5788		.5228		.5788	.5601
17		.5975	.6161	.5601		.5788	.5228
18	.5975		.6161	.6348		.6535	.6535
19	.7655		.8029	.7655	.8059	.8402	.8029
20	.8775		.9149	.8402	.8775	.8589	.8402
21	.8775	.8215	.8589	.8029	.7842	.8215	.8215
22	.8215		.9149	.7655	.7655	.8402	.7842
23	.8029	.8215		.7282	.8215	.8029	.7468
24		.7095	.8215	.8215	.7282	.7842	.8029
Max	.8775	.8962	.9149	.8775	.8775	.8589	1.2696
Min	.5415	.5788	.6161	.5228	.5788	.5788	.5228
Avg	.7319	.7160	.7692	.7233	.7034	.7063	.7328

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

KOPRI S/DN.[655]

BU 4655

Substation No/ Name :- 283074 / WALMIKI S/S

Feeder No / Name : 204 / Devika

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8962	1.0082	1.1016	.9522	.9522	.9522
2		.8775	.9149	.9709	.9149	.9149	.8962
3		.8215		.9522	.8589	.8215	.8402
4	.7468	.8215		.9149	.8029	.8029	.8775
5	.7468	.8402		.9522	.8402	.8402	.8402
6	.9335	1.0082	1.0269	.9896	.8775	.8775	.8962
7	1.307	1.2696	1.1763	1.2136	1.0829	.9149	1.1016
8	1.251	1.363	1.3256	1.2136	1.1203	1.0082	1.2323
9	1.2323	1.2696	1.2696	1.2323	1.2136		1.2323
10	1.0642	1.1389	1.1389	1.2136		1.1389	1.0829
11		.9709	1.0269	1.251	1.2136	1.2323	1.0829
12		.8962		1.0642	1.0269	1.1016	1.0269
13		.8775		1.0082		1.0456	.9522
14		.8589		.8962		.9335	.8962
15	.7468		.8215		.8029	.8775	.8029
16		.8029	.6348	.8029		.8402	.7655
17		.8402	.8402	.8215		.8029	.7468
18	.8589		.9335	.9335		.9896	.8589
19	1.1203		1.1763	1.1763	1.251	1.251	1.1949
20	1.4377		1.4937	1.2883	1.2883	1.4003	1.307
21	1.3443	1.4003	1.363	1.2696	1.2323	1.2696	1.2323
22	1.307		1.307	1.1576	1.1763	1.2323	1.1576
23	1.2323			1.1576	1.1576	1.1763	1.0456
24		1.0642	1.1389	1.2136	1.0829	1.0829	1.0642
Max	1.4377	1.4003	1.4937	1.2883	1.2883	1.4003	1.307
Min	.7468	.8029	.6348	.8029	.8029	.8029	.7468
Avg	1.0949	1.0010	1.0939	1.0780	1.0497	1.0220	1.0036

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

KOPRI S/DN.[655]

BU 4655

Substation No/ Name :- 283074 / WALMIKI S/S

Feeder No / Name : 205 / Puranik

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1576	1.3256	1.4563	1.2323	1.2883	1.307
2		1.0456	1.1389	1.2696	1.1203	1.2323	1.1576
3		1.0082		1.2323	1.0642	1.1203	1.0642
4	.8962	.9896		1.1576	1.0456	1.1016	1.1016
5	.9522	.9896		1.1763	1.0642	1.0642	1.0642
6	1.0829	1.251	1.307	1.3443	1.1203	1.1763	1.1576
7	1.4377	1.419	1.4377	1.3443	1.1949	1.1576	1.2883
8	1.2883	1.3817	1.475	1.5123	1.1763	1.251	1.419
9	1.363	1.4003		1.4937	1.307		1.5684
10		1.5123	1.6804	1.6057		1.5123	1.4937
11		1.587	1.6244	1.531	1.6057	1.6244	1.531
12		1.4937		1.475	1.531	1.6244	1.4937
13		1.419				1.4563	1.4563
14	1.2696	1.4003		1.2696		1.419	1.307
15	1.251	1.3256	1.363		1.3256	1.2696	1.1763
16		1.2696	1.307	1.0829		1.2136	1.1763
17		1.307	1.3817	1.1016		1.251	1.1203
18	1.3443		1.3817	1.2696		1.4563	1.3443
19	1.6057		1.7737	1.6244	1.7924	1.8111	1.6804
20	1.7551		1.8858	1.7177	1.6289	1.8298	1.7737
21	1.7551	1.7551	1.8111	1.643	1.6617	1.7364	1.7364
22	1.6244		1.7364	1.5684	1.643	1.587	1.5123
23	1.531	1.6057		1.531	1.587	1.5684	1.4377
24		1.2883	1.4377	1.5497	1.363	1.4937	1.475
Max	1.7551	1.7551	1.8858	1.7177	1.7924	1.8298	1.7737
Min	.8962	.9896	1.1389	1.0829	1.0456	1.0642	1.0642
Avg	1.3683	1.3303	1.5042	1.4071	1.3591	1.4020	1.3684

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

KOPRI S/DN.[655]

BU 4655

Substation No/ Name :- 283074 / WALMIKI S/S

Feeder No / Name : 206 / Gautam Tower

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2883	1.4377	1.531	1.363	1.4377	1.363
2		1.1949	1.3256	1.419	1.3256	1.3256	1.2696
3		1.1576		1.3443	1.2323	1.2696	1.2136
4	1.0456	1.1389		1.3256	1.1576	1.251	1.1576
5	1.0829	1.1763		1.3256	1.1763	1.2136	1.1763
6	1.1576	1.307	1.307	1.419	1.2323	1.2323	1.2323
7	1.3256	1.4003	1.4563	1.475	1.475	1.2136	1.3443
8	1.419	1.475	1.5684	1.5123	1.363	1.307	1.4563
9	1.4377	1.5684	1.6057	1.5497	1.4937		1.5123
10	1.6057	1.6804	1.6991	1.643		1.4563	1.6991
11		1.7924	1.7551	1.5497	1.6991	1.4937	1.6804
12		1.6991		1.4937	1.643	1.4937	
13		1.6617		1.4003		1.5123	1.6057
14	1.419	1.587		1.3817		1.419	1.4937
15	1.4377	1.4937	1.5684		1.3817	1.251	1.4003
16		1.4937	1.5497	1.1949		1.251	1.4003
17		1.4937	1.5497	1.251		1.2696	1.307
18	1.5684		1.6057	1.3256		1.3817	1.4377
19	1.7551		1.9044	1.6617	1.8858	1.7551	1.8484
20	1.9978		2.0351	1.8298	1.7737	1.9418	1.8858
21	1.9231	1.8484	1.8858	1.6991	1.7551	1.8298	1.8298
22	1.7177		1.7737	1.6057	1.6057	1.6804	1.6244
23	1.6057	1.6244		1.5684	1.6244	1.587	1.4937
24		1.4937	1.587	1.643	1.5123	1.5684	1.531
Max	1.9978	1.8484	2.0351	1.8298	1.8858	1.9418	1.8858
Min	1.0456	1.1389	1.307	1.1949	1.1576	1.2136	1.1576
Avg	1.4999	1.4787	1.6244	1.4847	1.4833	1.4409	1.4766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

THANE DIVISION - I[553]

KOPRI S/DN.[655]

BU 4655

Substation No/ Name :- 283074 / WALMIKI S/S

Feeder No / Name : 207 / BSUP Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5975	.6722	.7095	.6722	.6908	.6722
2		.5975	.6161	.6722	.6161	.6348	.6348
3		.5415		.6348	.6535	.6348	.6161
4	.5415	.5788		.6413	.6161	.6348	.5601
5	.5601	.5788		.6348	.5601	.6348	.5601
6	.5601	.6161	.7095	.7468	.6535	.5228	.6535
7	.6535	.6722	.6722	.7282	.6908	.5601	.7282
8	.6722	.7095	.6535	.6535	.6161	.6348	.6161
9	.6722	.7842	.7468	.6908	.6161		.6348
10	.6535	.6348	.6348	.7095		.6348	.6161
11		.6161		.5788	.5975	.5601	.5975
12		.5601		.5788	.5415	.5601	.5601
13		.6161		.6348		.6535	.5601
14	.5601	.5975		.6535		.5975	.5788
15	.6348	.6348	.5975		.5975	.5415	.5975
16		.5041	.5975	.5228		.5601	.4481
17		.4854	.4668	.4294		.4481	.3734
18	.4668		.4481	.4481		.4854	.4668
19	.5601		.6348	.5975	.6161	.5975	.6535
20	.6348		.7842	.6722	.7095	.6722	.7655
21	.6908	.6722	.7655	.6722	.6348	.6722	.7468
22	.6908		.7842	.6348	.7842	.6348	.6722
23	.7468	.7655		.7095	.7468	.7655	.7842
24		.6722	.7468	.7468	.6908	.7282	.7282
Max	.7468	.7842	.7842	.7468	.7842	.7655	.7842
Min	.4668	.4854	.4481	.4294	.5415	.4481	.3734
Avg	.6199	.6217	.6582	.6392	.6452	.6113	.6177

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283079 / VASANT VIHAR

Feeder No / Name : 201 / SHOPPING FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9745	1.1765	1.2127	1.3394	1.0791	1.2308	1.2127
2	.9568	1.1222	1.1765	1.267	1.0059	1.1104	1.1584
3	.9568	1.086	1.1403	1.2308	.9328	.9391	1.1222
4	.929	1.0498	1.086	1.1946	.8596	.8682	1.1222
5	1.0985	1.0136	1.0498	1.1765	.9145	.8939	1.1403
6	1.2094	1.1222	1.2851	1.1946	1.0059	.985	1.1584
7	1.3289	1.4299	1.5023	1.1946	1.0608	1.0985	1.2489
8	1.5402	1.5565	1.4299	1.3394	1.1157	1.2226	1.4118
9	1.5565	1.7013	1.5746	1.701	1.5546	1.5223	1.6108
10	1.5203	1.4299	1.7556	1.7193	1.6651	1.5384	1.6108
11	1.5565	1.4842	1.5746	1.6301	1.7556	1.6108	1.6108
12	1.5384	1.5565	1.5043	1.5415	1.7194	1.6832	1.4685
13	1.4299	1.3289	1.3998	1.4883	1.3998	1.5592	1.4352
14	1.3575	1.2757	1.3289	1.387	1.3253	1.4685	1.3466
15	1.3937	1.2226	1.258	1.153	1.379	1.4148	1.2934
16	1.262	1.134	1.2437	1.1157	1.1523	1.1523	1.2437
17	1.2986	1.1523	1.2986	1.1523	1.2254	1.3169	1.2254
18	1.3352	1.3169	.567	1.2803	1.3535	1.4266	1.2851
19	1.4632	1.4449	1.6278	1.4449	1.5912	1.5546	1.5746
20	1.6461	1.6278	1.6461	1.4083	1.4998	1.6278	1.5565
21	1.5546	1.6095	1.6644	1.3717	1.4998	1.5912	1.5927
22	1.4449	1.5912	1.4815	1.39	1.4266	1.4998	1.448
23	1.4299	1.4842	1.5746	1.3352	1.4506	1.4661	1.3717
24	1.0277	1.2308	1.3575	1.5023	1.262	1.3575	1.3756
Max	1.6461	1.7013	1.7556	1.7193	1.7556	1.6832	1.6108
Min	.929	1.0136	.567	1.1157	.8596	.8682	1.1222
Avg	1.3254	1.3395	1.3642	1.3566	1.3014	1.3391	1.3593

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283079 / VASANT VIHAR

Feeder No / Name : 202 / M R S FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4607	.4887	.543	.5792	.4938	.5373	.6154
2	.443	.4525	.5068	.543	.4755	.4835	.5068
3	.4252	.4344	.4525	.543	.4572	.4477	.5068
4	.4252	.4344	.3982	.5068	.439	.4207	.5068
5	.5083	.4344	.3982	.543	.4572	.4382	.543
6	.5316	.5068	.7059	.6335	.4755	.4835	.6516
7	.6733	.905	.8507	.7783	.5487	.5552	.8145
8	.7442	.7783	.7964	.7421	.6219	.6024	.724
9	.7421	.7602	.7421	.7682	.695	.6984	.7059
10	.7059	.724	.7602	.7619	.7421	.8507	.6697
11	.724	.6697	.724	.6556	.7783	.8145	.6516
12	.6878	.6335	.7522	.6485	.6697	.7059	.6268
13	.6516	.6556	.6201	.6661	.7087	.7164	.6201
14	.543	.5847	.5493	.5375	.591	.6268	.5316
15	.5249	.5138	.4784	.5144	.5853	.4835	.4252
16	.4755	.4755	.5304	.4572	.4755	.4755	.439
17	.4572	.5121	.5304	.4755	.4572	.4938	.5121
18	.5487	.5487	.567	.5487	.5487	.5487	.4887
19	.6584	.695	.6036	.7316	.567	.7133	.7421
20	.7133	.6584	.695	.6401	.6767	.7133	.6878
21	.695	.6401	.6401	.6036	.6401	.6401	.6516
22	.5853	.6584	.6584	.6401	.6036	.6219	.6154
23	.6335	.6697	.7059	.6036	.6626	.6697	.5304
24	.4961	.5611	.6154	.6516	.567	.6268	.6516
Max	.7442	.905	.8507	.7783	.7783	.8507	.8145
Min	.4252	.4344	.3982	.4572	.439	.4207	.4252
Avg	.5856	.5998	.6177	.6155	.5807	.5987	.6008

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283079 / VASANT VIHAR

Feeder No / Name : 203 / VOLTAS FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8859	1.0208	1.0566	1.1641	1.0425	.9568	1.0566
2	.8589	.985	.985	1.1104	.9877	.9036	.985
3	.8505	.9313	.9313	1.0745	.9328	.8682	.9313
4	.8682	.8954	.9313	1.0745	.8962	.8682	.8954
5	.9114	.8954	1.0387	1.0387	.8596	.8505	.9671
6	1.0631	1.0387	1.3611	1.1104	1.0242	.9036	1.1462
7	1.1517	1.3611	1.3969	1.2178	1.0974	.9568	1.2894
8	1.258	1.4506	1.4327	1.379	1.1523	1.0387	1.3432
9	1.3394	1.379	1.4327	1.4266	1.262	1.2178	1.3073
10	1.2715	1.3937	1.3756	1.4883	1.3575	1.4118	1.3394
11	1.3253	1.3575	1.3394	1.4548	1.4661	1.4575	1.3575
12	1.3253	1.3394	1.3432	1.4548	1.379	1.3213	1.3253
13	1.2715	1.2757	1.3112	1.2795	1.3466	1.3073	1.3073
14	1.182	1.0985	1.0985	1.1616	1.1104	1.1283	.9036
15	1.0208	1.0454	1.0277	.9259	1.0791	1.0566	.9214
16	1.0059	1.0059	1.0425	.9694	1.0425	.9877	.9511
17	.9877	1.0425	1.1157	1.0059	.9877	1.0791	.9511
18	1.0608	1.0791	1.1523	1.0608	1.0974	1.1706	1.134
19	1.262	1.2803	1.3352	1.2986	1.2254	1.3535	1.3169
20	1.4083	1.3717	1.4083	1.2986	1.3352	1.3169	1.3352
21	1.3717	1.3717	1.3352	1.2071	1.262	1.2986	1.2986
22	1.3169	1.3352	1.3535	1.262	1.2986	1.3352	1.3352
23	1.3432	1.3432	1.3611	1.2254	1.2715	1.3253	1.262
24	1.0277	1.1462	1.2178	1.2715	1.1157	1.182	1.2178
Max	1.4083	1.4506	1.4327	1.4883	1.4661	1.4575	1.3575
Min	.8505	.8954	.9313	.9259	.8596	.8505	.8954
Avg	1.1403	1.1851	1.2243	1.2067	1.1512	1.1373	1.1616

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283079 / VASANT VIHAR

Feeder No / Name : 204 / TOWER FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1517	1.2403	1.382	1.4529	1.3032	1.3432	1.3289
2	1.134	1.1517	1.3289	1.4175	1.267	1.2403	1.2757
3	1.134	1.1163	1.2757	1.382	1.2489	1.1871	1.2403
4	1.1163	1.1163	1.2403	1.3289	1.1946	1.1871	1.2403
5	1.1517	1.0985	1.2048	1.3289	1.2127	1.2403	1.3289
6	1.2934	1.2403	1.3998	1.382	1.267	1.2715	1.4175
7	1.3432	1.5415	1.6655	1.448	1.3394	1.3112	1.3643
8	1.4148	1.4529	1.6478	1.5592	1.3937	1.3611	1.4529
9	1.5927	1.6301	1.7364	1.7741	1.5746	1.5581	1.5061
10	1.5592	1.7556	1.6832	1.8804	1.7194	1.9185	1.6289
11	1.6655	1.6289	1.6832	1.7364	1.828	1.828	1.7556
12	1.5238	1.5384	1.6297	1.6126	1.6655	1.7375	1.5238
13	1.3998	1.4175	1.6301	1.5424	1.5415	1.6118	1.4864
14	1.4175	1.4706	1.4529	1.4737	1.4506	1.4685	1.3289
15	1.2403	1.2226	1.382	1.286	1.4661	1.5402	1.2403
16	1.3575	1.1765	1.3394	1.2851	1.1946	1.3032	1.2127
17	1.1584	1.1765	1.2127	1.3213	1.3213	1.3213	1.2308
18	1.2489	1.2308	1.3756	1.267	1.3575	1.3937	1.262
19	1.4661	1.4842	1.647	1.6289	1.5927	1.6832	1.6297
20	1.7556	1.7375	1.7556	1.647	1.8099	1.7737	1.7551
21	1.7375	1.8642	1.8099	1.6651	1.7918	1.7918	1.6118
22	1.6651	1.7918	1.8642	1.6832	1.7194	1.7375	1.6118
23	1.6124	1.6478	1.7364	1.5384	1.5939	1.6655	1.5023
24	1.2403	1.4175	1.4883	1.6301	1.448	1.4864	1.5238
Max	1.7556	1.8642	1.8642	1.8804	1.828	1.9185	1.7556
Min	1.1163	1.0985	1.2048	1.267	1.1946	1.1871	1.2127
Avg	1.3908	1.4228	1.5238	1.5113	1.4709	1.4984	1.4358

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283079 / VASANT VIHAR

Feeder No / Name : 205 / SIDDHACAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1595	.2195	.2378	.2561	.2033	.2328	.2195
2	.1595	.1829	.1829	.2195	.1848	.1949	.2012
3	.1595	.1646	.1646	.1829	.1663	.1791	.1829
4	.1595	.1646	.1646	.1646	.1663	.1595	.1646
5	.1646	.1646	.1829	.1646	.1848	.1578	.1829
6	.2378	.2012	.3292	.2195	.2033	.1772	.2378
7	.2743	.2926	.3292	.3109	.2402	.1949	.2743
8	.2926	.2743	.3109	.3292	.2587	.2149	.3109
9	.3292	.3475	.2926	.3658	.3142	.3403	.3475
10	.2926	.3439	.3582	.3721	.3258	.362	.3258
11	.3109	.3258	.3258	.2804	.3439	.3403	.3077
12	.2743	.3077	.2686	.2804	.2865	.3258	.2658
13	.2378	.2658	.2658	.2629	.2835	.2865	.2658
14	.2012	.2303	.2481	.2103	.2149	.2328	.2481
15	.2012	.2126	.2126	.1886	.2218	.2149	.2126
16	.2033	.2218	.2218	.2033	.2033	.2218	.1848
17	.2033	.2218	.2218	.2218	.2218	.2218	.2033
18	.2218	.2402	.2218	.2218	.2218	.2402	.2218
19	.2402	.2402	.2402	.2772	.2772	.2587	.2772
20	.2772	.2772	.2957	.2772	.2772	.2772	.2957
21	.2772	.2957	.2957	.2772	.2957	.2587	.2957
22	.2772	.2772	.2772	.2587	.2587	.2587	.2772
23	.2743	.2926	.3109	.2402	.2686	.2926	.2402
24	.197	.2378	.2743	.2743	.2402	.2507	.2926
Max	.3292	.3475	.3582	.3721	.3439	.362	.3475
Min	.1595	.1646	.1646	.1646	.1663	.1578	.1646
Avg	.2344	.2501	.2597	.2525	.2443	.2456	.2515

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283095 / 22KV KASARWADWALI SWG STN

Feeder No / Name : 301 / Serendipity mall

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7			.1524			
8			.1524			
9			.1524			
10	.4954				.3429	
11	.6478		.5716		.5335	
12				.5335	.6097	.6478
13				.5716		.6478
14				.5716		.6478
15				.6478	.5716	.6478
16					.6097	
17				.4954		
20				.5335		
21		.5335		.5335		
22		.2667		.4191		
23				.1905	.2286	
Max	.6478	.5335	.5716	.6478	.6097	.6478
Min	.4954	.2667	.1524	.1905	.2286	.6478
Avg	.5716	.4001	.2572	.4996	.4827	.6478

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283095 / 22KV KASARWADWALI SWG STN

Feeder No / Name : 302 / Iron and Metal

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191					.381
2	.4572					.381
3	.4191					.381
4	.4191					.381
5	.4191					.381
6	.4572					.381
7	.5335		.6478		.3048	.4191
8	.724		.7621			
9	.8764		.8383			
10	1.0288				.5335	
11	.9907		.9907		.4954	
12				.6097	.4572	.4572
13				.4191	.4572	.4572
14				.4191	.4191	.4191
15				.4191	.4191	.2667
16					.4191	
17				.4191	.381	
18					.381	
19					.381	
20				.381	.381	
21		.5335		.3429	.381	
22		.4954		.3429	.3048	
23				.3429	.3048	
24	.4572				.3429	.381
Max	1.0288	.5335	.9907	.6097	.5335	.4572
Min	.4191	.4954	.6478	.3429	.3048	.2667
Avg	.6001	.5145	.8097	.4106	.3977	.3905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283095 / 22KV KASARWADWALI SWG STN

Feeder No / Name : 303 / Bombay Metal and Alloy NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429					.3048
2	.3429					.2667
3	.3429					.3048
4	.3048					.3048
5	.3429					.3048
6	.3429					.3048
7	.381		.3429		.3048	.3048
8	.4572		.4572			
9	.5335		.5716			
10	.5335				.4191	
11	.5335		.5335		.381	
12				.381	.381	.3429
13				.381	.381	.3429
14				.3429	.381	.3429
15				.381	.381	.3048
16					.3429	
17				.381	.3429	
18					.3429	
19					.3048	
20				.381	.3048	
21		.4954		.4191	.3048	
22		.5335		.381	.3048	
23				.381	.3048	
24	.3048				.381	.3048
Max	.5335	.5335	.5716	.4191	.4191	.3429
Min	.3048	.4954	.3429	.3429	.3048	.2667
Avg	.3969	.5145	.4763	.381	.3477	.3112

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283095 / 22KV KASARWADWALI SWG STN

Feeder No / Name : 304 / G Corp

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667					.2286
2	.3048					.1524
3	.3048					.1524
4	.2667					.1524
5	.2667					.1524
6	.3048					.1905
7	.381		.3429		.2286	.1905
8	.381		.3429			
9	.6859		.6478			
10	.724				.5335	
11	.7621		.6859		.5716	
12				.3048	.5335	.2286
13				.4572	.5335	.2667
14				.4954	.4954	.2286
15				.4954	.4954	.1905
16					.4954	
17				.5335	.4954	
18					.4954	
19					.3429	
20				.5335	.3429	
21		.5335		.4954	.2286	
22		.4572		.4954	.2286	
23				.6097	.2286	
24	.3048				.4954	.2286
Max	.7621	.5335	.6859	.6097	.5716	.2667
Min	.2667	.4572	.3429	.3048	.2286	.1524
Avg	.4128	.4954	.5049	.4911	.4215	.1969

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283097 / 22/11 KV SOHAM S/S

Feeder No / Name : 201 / Soham 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2058	.2229	.2401	.2401	.2401	.2572
2	.2058	.1715	.2229	.2401	.2401	.2229	.2058
3	.1886	.1715	.2058	.2401	.2229	.2229	.1715
4	.1715	.1715	.2058	.2229	.2229	.2058	.1715
5	.6173	.1715	.2058	.2229	.2058	.2058	.1715
6	.1715	.2058	.2058	.2229	.2058	.1886	.1715
7	.1886	.2229	.2058	.2229	.1715	.1886	.1715
8	.1886	.1886	.1886	.2229	.2572	.1886	.1886
9	.2058	.2229	.2229	.2572	.2401	.2058	.2058
10	.2401	.3086	.2229	.3086	.2743	.3086	.2058
11	.2572	.2572	.2743	.2401	.2743	.2915	.2401
12	.2572	.2572	.2743	.2572	.2572	.2743	.2058
13	.2229	.2401	.1886	.2401		.2229	.2058
14	.2058	.2058	.2058	.2229	.2401		.2058
15	.2058	.2058	.2229	.2229	.2401	.2229	.2058
16	.1886	.1886	.2572	.2401			.2058
17	.1715	.2058	.2401	.2401	.2401	.2229	.2058
18	.2058	.2572	.2572	.2401	.2229	.2229	.2058
19		.2743	.2743	.2572	.2743	.2915	.2743
20	.2915	.2743	.2915	.2572	.2915	.2743	.2572
21	.3429	.2743	.2743	.2743	.2572	.2915	.2401
22	.2915	.2915	.2743	.2915	.2401	.2572	.2401
23	.2401	.2572	.2915	.2743	.2401	.2572	.2401
24	.5144	.2229	.2401	.2401	.2401	.2401	.2572
Max	.6173	.3086	.2915	.3086	.2915	.3086	.2743
Min	.1715	.1715	.1886	.2229	.1715	.1886	.1715
Avg	.2513	.2272	.2365	.2458	.2409	.2385	.2129

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283097 / 22/11 KV SOHAM S/S

Feeder No / Name : 202 / Unnati

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.4287	.463	.4458	.3944	.4115	.4287
2	.3429	.3772	.4287	.4458	.3944	.4115	.3772
3	.3429	.3429	.4115	.4287	.3772	.3944	.3429
4	.3429	.3429	.4115	.4287	.3772	.3944	.3429
5	.3429	.4287	.4115	.4115	.3601	.3772	.3601
6	.3601	.4801	.4458	.3944	.3601	.3772	.3772
7	.4287	.5487	.463	.3772	.3601	.3601	.4287
8	.4801	.463	.4801	.3601	.3601	.3258	.4115
9	.5316	.5487	.4973	.5144	.4458	.4287	.4287
10	1.2517	.5316	.5658	.4973	.463	.463	.4287
11	.5144	.4973	.4801	.4458	.4458	.5144	.4287
12	.5316	.4801	.4801	.4287	.4458	.4801	.4458
13	.463	.4458	.4458	.3944		.4287	.4287
14	.4115	.4458	.3944	.3601	.3601		.3601
15	.3429	.4287	.3944	.3429	.3429	.4287	.3086
16	.3601	.4287	.3944	.3429			.3258
17	.3772	.4115	.4115	.3601	.3601	.3944	.3429
18	.3429	.3772	.3429	.3601	.3258	.3944	.3429
19		.4115	.4287	.3772	.3772	.4287	.4287
20	.4115	.4115	.4458	.3944	.4287	.4458	.4115
21	.4458	.4115	.4115	.4287	.4115	.463	.4287
22	.463	.4458	.4458	.4458	.4287	.4287	.4287
23	.4801	.4973	.5316	.4458	.4801	.463	.4458
24	.4287	.4458	.4801	.463	.3944	.4287	.4801
Max	1.2517	.5487	.5658	.5144	.4801	.5144	.4801
Min	.3429	.3429	.3429	.3429	.3258	.3258	.3086
Avg	.4525	.4430	.4444	.4122	.3952	.4201	.3972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283097 / 22/11 KV SOHAM S/S

Feeder No / Name : 203 / Regency

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0631	1.1488	1.2174	1.3032	1.166	1.4918	1.2517
2	1.0288	1.1317	1.2003	1.3032	1.166	1.2174	1.2174
3	.9945	1.1145	1.2003	1.286	1.1488	1.2174	1.1831
4	.9945	1.0974	1.166	1.286	1.1488	1.1831	1.1488
5	.9945	1.166	1.166	1.2689	1.1317	1.1831	1.1145
6	1.0288	1.2003	1.166	1.2517	1.1145	1.1488	1.0631
7	1.0802	1.2689	1.2517	1.2517	1.1145	1.2003	1.0288
8	1.1488	1.2003	1.286	1.2517	1.0974	1.2003	1.0974
9	1.3032	1.3203	1.3375	1.3546	1.286	1.2689	1.3375
10	1.2517	1.3375	1.3032	1.3889	1.3375	1.2346	1.2517
11	1.286	1.3375	1.4232	1.406	1.4918		1.3203
12	1.1317	1.2174	1.2689	1.2174	1.3032	1.3375	1.2174
13	1.1145	1.2174	1.2003	1.1831		1.1831	1.2346
14	1.046	1.2003	1.166	1.1488	1.0288		1.2003
15	1.0288	1.166	1.0117	.9431	1.046	1.0117	1.046
16	1.0631	1.166	1.0802	.9774			1.0802
17	1.0802	1.1488	1.0974	1.1317	1.1145	1.1317	1.0802
18	1.0974	1.1488	1.2346	1.0802	1.1145	1.1488	1.1145
19		1.2517	1.2517	1.1317	1.2174	1.2689	1.1145
20	1.2346	1.286	1.2689	1.166	1.1488	1.2689	1.2174
21	1.2689	1.3203	1.286	1.2003	1.1831	1.286	1.166
22	1.286	1.3546	1.3375	1.2346	1.2517	1.286	1.1831
23	1.2689	1.3546	1.3889	1.2517	1.2689	1.3375	1.2689
24	1.0631	1.166	1.2517	1.3203	1.1831	1.2346	1.2689
Max	1.3032	1.3546	1.4232	1.406	1.4918	1.4918	1.3375
Min	.9945	1.0974	1.0117	.9431	1.0288	1.0117	1.0288
Avg	1.1242	1.2217	1.2317	1.2224	1.1847	1.2305	1.1753

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283097 / 22/11 KV SOHAM S/S

Feeder No / Name : 204 / Omkareshwar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2572	.2401	.2572	.2572	.2401	.2572
2	.2401	.2572	.2401	.2401	.2572	.2401	.2401
3	.2229	.2401	.2401	.2401	.2401	.2229	.2229
4	.2229	.2058	.2401	.2229	.2401	.2229	.2058
5	.2229	.2058	.2401	.2229	.2401	.2229	.1715
6	.2229	.2401	.2401	.2229	.2229	.2058	.2058
7	.2229	.2572	.2572	.2058	.2229	.1886	.2229
8	.2401	.2572	.2572	.1886	.2572	.2743	.2401
9	.2743	.2572	.2572	.2058	.2572	.2572	.2401
10	.2915	.3601	.2915	.2743	.2572	.2572	.2572
11	.3429	.3429	.3258	.2572	.2743	.2743	.2915
12	.2743	.3086	.2743	.2743	.2915	.2915	.2915
13	.2915	.2915	.2743	.2572		.2401	.2915
14	.2743	.2743	.2743	.2572	.2572		.2743
15	.2743	.2743	.2743	.2743	.2401	.2401	.2743
16	.2743	.2572	.2572	.2915			.2743
17	.2572	.2572	.2572	.3086	.2572	.2401	.2743
18	.2572	.2572	.2572	.2915	.2401	.2401	.2743
19		.2743	.2743	.2915	.2401	.2572	.2915
20	.2572	.2743	.2743	.2572	.2572	.2572	.2915
21	.2572	.2743	.2572	.2915	.3086	.2572	.2743
22	.2572	.2743	.2915	.3086	.2572	.2572	.2743
23	.2572	.2743	.2915	.2915	.2743	.2572	.2743
24	.2572	.2572	.2572	.2572	.2572	.2572	.2572
Max	.3429	.3601	.3258	.3086	.3086	.2915	.2915
Min	.2229	.2058	.2401	.1886	.2229	.1886	.1715
Avg	.2579	.2679	.2643	.2579	.2549	.2455	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283097 / 22/11 KV SOHAM S/S

Feeder No / Name : 205 / HAWARE ESTATE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.166	1.286	1.3375	1.4918	1.286	1.4232	1.3717
2	1.166	1.2689	1.3032	1.4918	1.2689	1.4232	1.3203
3	1.1145	1.2517	1.286	1.4746	1.2689	1.406	1.2689
4	1.1145	1.2003	1.286	1.4746	1.2517	1.3889	1.2003
5	1.1145	1.286	1.286	1.4575	1.2517	1.3546	1.2517
6	1.166	1.3032	1.3375	1.4403	1.2346	1.3546	1.3032
7	1.2174	1.3375	1.406	1.406	1.2174	1.3375	1.2003
8	1.2346	1.286	1.3375	1.3203	1.2517	1.3375	1.3546
9	1.1317	1.2346	1.1831	1.3032	1.3032	1.3889	1.3889
10	1.1317	1.2003	1.2174	1.3717	1.2689	1.3546	1.4232
11	1.1145	1.046	1.1145	1.2689	1.1317	1.3203	1.2003
12	.9774	1.0631	.9945	1.1145	1.1317	1.1831	1.1831
13	.9602	1.0288	.9431	1.0974		1.0288	1.0288
14	.8916	1.0288	.9431	1.0802	.7888		1.0288
15	.8573	.9945	.9774	.823	.9259	.9602	.8745
16	.8916	.9259	.9945	.7716			.9088
17	.9431	.9259	.9945	.9088	.8916	.1543	.9431
18	.9259	.9088	.9259	.9774	1.0117	1.0288	.9945
19		1.0974	1.1488	.9945	1.2174	1.2517	1.2346
20	1.2174	1.166	1.2003	1.0288	1.2003	1.2689	1.2346
21	1.2517	1.2346	1.286	1.1145	1.2174	1.286	1.2346
22	1.286	1.3375	1.3203	1.1488	1.286	1.286	1.2003
23	1.3889	1.3546	1.4403	1.2517	1.406	1.3889	1.3032
24	1.2003	1.3375	1.3889	1.5261	1.3032	1.4403	1.406
Max	1.3889	1.3546	1.4403	1.5261	1.406	1.4403	1.4232
Min	.8573	.9088	.9259	.7716	.7888	.1543	.8745
Avg	1.1071	1.1710	1.1938	1.2224	1.1870	1.2439	1.2024

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283097 / 22/11 KV SOHAM S/S

Feeder No / Name : 206 / MERIT MAGNUM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2058	.2229	.2229	.1886	.1715	.1715
2	.1543	.1715	.2058	.2058	.1715	.1715	.1715
3	.1543	.1543	.1886	.2058	.1715	.1715	.1715
4	.1543	.1543	.1886	.1886	.1715	.1543	.1543
5	.1543	.1715	.1886	.1715	.1543	.1543	.1543
6	.1543	.1886	.1715	.1715	.1543	.1372	.1372
7	.1715	.2058	.1886	.1543	.1543	.1372	.1372
8	.2229	.2058	.1886	.1372	.1543	.1372	.1372
9	.2401	.2229	.2915	.2058	.2058	.1715	.2058
10	.2229	.1886	.2058	.2572	1.2689	.2229	.2229
11	.1886	.2229	.1886	.2229	.2229	.2058	.2229
12	.1715	.2058	.1886	.1715	.1715	.1886	.2229
13	.1372	.2058	.1543	.1715		.1715	.2058
14	.1372	.1886	.1543	.1543	.1886		.1715
15	.1372	.1886	.1543	.1372	.1886	.1715	.1543
16	.1372	.1886	.1543	.1543			.1543
17	.0343	.1715	.1372	.1543	.1543		.1372
18	.1372	.1715	.1543	.1543	.1715	.1715	.1372
19		.1715	.1715	.1372	.2058	.2058	.1715
20	.2401	.2058	.2229	.1715	.2229	.2058	.2058
21	1.2517	.2058	.1886	.1886	.2401	.2058	.2058
22	.2401	.2401	.2229	.2058		.2229	.2229
23	.2058	.2401	.2229	.2058	.2401	.2058	.2058
24	.1715	.2058	.2401	.2229	.1886	.1886	.2401
Max	1.2517	.2401	.2915	.2572	1.2689	.2229	.2401
Min	.0343	.1543	.1372	.1372	.1543	.1372	.1372
Avg	.2170	.1951	.1915	.1822	.2376	.1797	.1801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283097 / 22/11 KV SOHAM S/S

Feeder No / Name : 207 / ORIAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0171	.0171	.0171	.0171	.0171	.0343
2	.0171	.0171	.0171	.0171	.0171	.0171	.0171
3	.0171	.0171	.0171	.0171	.0171	.0171	.0171
4	.0171	.0171	.0171	.0171	.0171	.0171	.0171
5	.0171	.0171	.0343	.0171	.0171	.0171	.0171
6	.0171	.0171	.0171	.0171	.0171	.0171	.0171
7	.0171	.0171	.0171	.0171	.0171	.0171	.0171
8	.0171	.0171	.0171	.0171	.0171	.0171	.0171
9	.0171	.0171	.0171	.0171	.0171	.0171	.0171
10	.0343	.0171	.0171	.0171	.0171	.0171	.0171
11	.0343	.0171	.0343	.0171	.0343	.0171	.0171
12	.0343	.0343	.0343	.0171	.0343	.0171	.0171
13	.0343	.0343	.0343	.0343		.0171	.0343
14	.0343	.0343	.0343	.0343	.0171		.0343
15	.0343	.0343	.0343	.0343	.0171	.0171	.0343
16	.0343	.0343	.0343	.0343			.0343
17	.0343	.0343	.0343	.0343	.0171	.0171	.0343
18	.0343	.0343	.0343	.0343	.0171	.0171	.0343
19		.0343	.0343	.0343	.0171	.0171	.0343
20	.0343	.0343	.0343	.0343	.0171	.0171	.0343
21	.0343	.0343	.0343	.0343	.0171	.0171	.0343
22	.0343	.0343	.0343	.0343	.0171	.0171	.0343
23	.0171	.0343	.0343	.0343	.0171	.0343	.0343
24	.0343	.0171	.0343	.0343	.0343	.0171	.0343
Max	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.0268	.0257	.0279	.0257	.0194	.0179	.0264

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283101 / 22/22 KV HYPERCITY SWITCHING

Feeder No / Name : 301 / Ovla

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147					1.9052
2	1.6385					1.7147
3	1.7147					1.7147
4	1.6766					1.7147
5	1.6385					1.7147
6	1.7147					1.7147
7	2.1338				1.7147	1.6385
8	2.2481		2.3243			
9	2.5149		2.553			
10	2.9721				2.5149	
11	2.8959		3.1245		2.5911	
12			3.2007	2.1338	2.6292	2.21
13				2.0576	2.2862	2.21
14				1.6766	2.1719	2.0576
15				1.7909	2.0195	1.7909
16					2.3243	
17				1.7147	2.2862	
18					2.0957	
19					2.0195	
20		2.553		2.2481	2.0957	
21		2.4387		2.0195	2.2862	
22		2.4387		2.0576	2.0576	
23				2.1338	2.7435	
24	1.7909				1.9814	1.9052
Max	2.9721	2.553	3.2007	2.2481	2.7435	2.21
Min	1.6385	2.4387	2.3243	1.6766	1.7147	1.6385
Avg	2.0545	2.4768	2.8006	1.9814	2.2386	1.8576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283101 / 22/22 KV HYPERCITY SWITCHING

Feeder No / Name : 302 / 22KV HAWARE CITY

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905					.2286
2	.1905					.2286
3	.1524					.2286
4	.1905					.2286
5	.1524					.2286
6	.1905					.2286
7	.2667		.2667		.2667	.2667
8	.2667		.3429			
9	.3048		.3429			
10	.3048				.2667	
11	.2667		.3429		.3048	
12			.3429	.3048	.3048	.2667
13				.3429	.2286	.2286
14				.3048	.2286	.2667
15				.2667	.2286	.2286
16					.1905	
17				.2667	.1905	
18					.1905	
19					.2667	
20		.2667		.2286	.2667	
21		.2667			.2667	
22		.3048		.2667	.2667	
23				.2667	.2667	
24	.2286				.2667	.2286
Max	.3048	.3048	.3429	.3429	.3048	.2667
Min	.1524	.2667	.2667	.2286	.1905	.2286
Avg	.2254	.2794	.3277	.2810	.2500	.2381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283101 / 22/22 KV HYPERCITY SWITCHING

Feeder No / Name : 303 / Chenna

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859					.8764
2	.6859					.8764
3	.724					.8764
4	.6859					.8764
5	.7621					.8764
6	.724					.8383
7	.7621		.7621		.8002	.8764
8	.9526		.8383			
9	1.0669		.9526			
10	1.2574				.9907	
11	1.2574		1.3336		.9907	
12			1.2955	1.0288	.9907	.9907
13				.9907	.9526	.9907
14				.8383	.9526	.9526
15				.8002	.9526	1.0288
16					1.0669	
17				.8383	.9907	
18					.9907	
19					1.0669	
20		1.2574		.9145	1.105	
21		1.1431		.9145	1.0669	
22		1.105		.8764	1.0288	
23				.8764	.9907	
24	.724				.8002	.8764
Max	1.2574	1.2574	1.3336	1.0288	1.105	1.0288
Min	.6859	1.105	.7621	.8002	.8002	.8383
Avg	.8574	1.1685	1.0364	.8976	.9836	.9113

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283101 / 22/22 KV HYPERCITY SWITCHING

Feeder No / Name : 304 / Incommer to Haware SS NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 22 / INCOMING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905					.1905
2	.1905					.1905
3	.1905					.1905
4	.1905					.1905
5	.1905					.1905
6	.1905					.1905
7	.1905		.1905		.1905	.1905
8	.1905		.1905			
9	.1905		.1905			
10	.1905				.1905	
11	.1905		.1905		.1905	
12			.1905	.1905	.1905	.1905
13				.1905	.1905	.1905
14				.1905	.1905	.1905
15				.1905	.1905	.1905
16					.1905	
17				.1905	.1905	
18					.1905	
19					.1905	
20		.1905		.1905	.1905	
21		.1905		.1905	.1905	
22		.1905		.1905	.1905	
23				.1905	.1905	
24	.1905				.1905	.1905
Max	.1905	.1905	.1905	.1905	.1905	.1905
Min	.1905	.1905	.1905	.1905	.1905	.1905
Avg	.1905	.1905	.1905	.1905	.1905	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283101 / 22/22 KV HYPERCITY SWITCHING

Feeder No / Name : 305 / Incommer to Lodha SS NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / INCOMING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143					.1143
2	.1143					.1143
3	.1143					.1143
4	.1143					.1143
5	.1143					.1143
6	.1143					.1143
7	.1143		.1143		.1143	.1143
8	.1143		.1143			
9	.1143		.1143			
10	.1143				.1143	
11	.1143		.1143		.1143	
12			.1143	.1143	.1143	.1143
13				.1143	.1143	.1143
14				.1143	.1143	.1143
15				.1143	.1143	.1143
16					.1143	
17				.1143	.1143	
18					.1143	
19					.1143	
20		.1143		.1143	.1143	
21		.1143		.1143	.1143	
22		.1143		.1143	.1143	
23				.1143	.1143	
24	.1143				.1143	.1143
Max	.1143	.1143	.1143	.1143	.1143	.1143
Min	.1143	.1143	.1143	.1143	.1143	.1143
Avg	.1143	.1143	.1143	.1143	.1143	.1143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283103 / 22/11KV LODHA SUBSTATION

Feeder No / Name : 201 / MANGALMURTI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.5716
2				.5335
3				.4954
4				.4572
5				.4572
6				.4954
7			.4954	.5335
8		.5144	.5335	.6478
9		.5716	.5525	.6859
10		.5716	.5335	.6668
11		.5906	.5525	.6478
12		.5144	.5525	.7049
13		.4954	.5335	
14	.4572	.4763	.5144	
15		.4572	.4191	
16		.4954	.4763	
17		.4382	.4763	
18	.4572	.4572		
19		.5335		
20		.5906		
21		.5906		
22		.5716		
23		.5906		
24	.5525		.5144	.6097
Max	.5525	.5906	.5525	.7049
Min	.4572	.4382	.4191	.4572
Avg	.4890	.5287	.5128	.5774

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283103 / 22/11KV LODHA SUBSTATION

Feeder No / Name : 202 / BHAINDERPADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2096	.2096
2				.1905	.1905
3				.1715	.1715
4				.1524	.1715
5				.1524	.1524
6				.1715	.1715
7			.2286	.1905	.2096
8		.2096	.2286	.2096	.2477
9		.2286	.2286		.2286
10		.2477	.2286		.2858
11		.2286	.2477		.2667
12		.2096	.1905		
13		.1905	.1905		
14	.2096	.2286	.2096		
15		.2096	.2096		
16		.1905	.1905		
17		.1715	.2096		
18	.1905	.1715	.2477		
19		.2096			
20		.2477			
21		.2477			
22		.2477			
23		.2667			
24			.2096	.2286	.2286
Max	.2096	.2667	.2477	.2286	.2858
Min	.1905	.1715	.1905	.1524	.1524
Avg	.2001	.2191	.2169	.1863	.2112

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283103 / 22/11KV LODHA SUBSTATION

Feeder No / Name : 203 / CIEOLA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.1143	.1334
2						.1143	.1334
3						.0953	.1143
4						.0953	.1143
5						.1143	.0953
6						.1143	.0953
7			.0762			.0953	.1143
8			.0953			.0953	.0953
9		.1143	.1334			.1334	.1143
10		.1143	.1143			.1334	.1524
11		.0762	.1143			.1143	.1334
12		.0762	.0953		.1334	.1143	.1143
13		.0762	.0953			.1143	
14	.1143	.1143	.1334	.0953		.0953	
15		.0953	.0953	.0953		.0953	
16		.1143	.0762			.0762	
17		.0762	.0953			.0762	
18	.0762	.0953	.0953	.0953		.1143	
19		.1143		.1334		.1334	
20		.1143				.1524	
21		.1524				.1143	
22		.1143				.1143	
23		.1334					
24	.1715		.1143			.1334	.1143
Max	.1715	.1524	.1334	.1334	.1334	.1524	.1524
Min	.0762	.0762	.0762	.0953	.1334	.0762	.0953
Avg	.1207	.1054	.1026	.1048	.1334	.1110	.1173

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283103 / 22/11KV LODHA SUBSTATION

Feeder No / Name : 204 / IGNIS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3429
2				.3429
3				.3048
4				.3048
5				.3239
6				.3429
7			.381	.381
8			.4001	.362
9		.381	.362	.3429
10			.4001	.3429
11		.3239	.3239	.362
12		.362	.3048	
13		.4001	.362	
14	.3239	.3239	.362	
15		.3048	.3239	
16		.3048	.3048	
17		.3429	.3239	
18	.3239	.3048		
19		.4001		
20		.4572		
21		.4191		
22		.4191		
23		.4001		
24	.362		.381	.381
Max	.362	.4572	.4001	.381
Min	.3239	.3048	.3048	.3048
Avg	.3366	.3674	.3525	.3445

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283103 / 22/11KV LODHA SUBSTATION

Feeder No / Name : 205 / COSMOS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.381	.4191
2				.362	.4001
3				.3239	.381
4				.3239	.3429
5				.3429	.3429
6				.381	.381
7			.4382	.4001	.4382
8			.4954	.4382	.4191
9		.5144	.4572	.5144	.4954
10		.4001	.4572	.4763	.4763
11		.4191	.4382	.381	.2477
12		.3239	.3239	.381	.3429
13		.3429	.3239	.3239	
14	.3048	.2858	.3429	.3048	
15		.2858	.3048	.3048	
16		.2858	.3239	.3048	
17		.3048	.3239	.2858	.3048
18	.3048	.3429	.381	.362	
19		.4382		.4572	
20		.4954		.4572	
21		.5335		.4001	
22		.4763		.4382	
23		.4954			
24			.4572	.4001	.4572
Max	.3048	.5335	.4954	.5144	.4954
Min	.3048	.2858	.3048	.2858	.2477
Avg	.3048	.3963	.3898	.3802	.3892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283103 / 22/11KV LODHA SUBSTATION

Feeder No / Name : 206 / GIRIKUNJ

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-AUG-17
HR	Load (MW)
10	.362
Max	.362
Min	.362
Avg	.362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283103 / 22/11KV LODHA SUBSTATION

Feeder No / Name : 207 / SPLENDORA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
9		.1524	
14	.1334		
17			.1334
18	.1334		
24		.1715	
Max	.1334	.1715	.1334
Min	.1334	.1524	.1334
Avg	.1334	.1620	.1334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283104 / 22/11 KV ANILINE SUBSTATION

Feeder No / Name : 201 / SANGHAVI HILLS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.112	.1143	.1143	.1143	.1143	.1494
2	.0724	.0924	.1143	.1143	.1143	.0953	.1294
3	.0739	.0739	.0953	.1143	.0953	.0953	.112
4	.0732	.0747	.0953	.0953	.0953	.0953	.112
5	.0739	.0747	.0953	.0953	.0953	.0953	.112
6	.0934	.0914	.0953	.1143	.1143	.0953	.128
7	.0914	.1109	.1143	.0953	.1143	.1143	.1307
8	.112	.1143	.1143	.1143	.1143	.1143	.1109
9	.112	.1334	.1524	.1334	.1334	.1143	.128
10	.112	.0953	.1334	.1334	.1524	.112	.1267
11	.0934	.0953	.0953	.1334	.1334	.1109	.1307
12	.0924	.1143	.0953	.1334	.1334	.1494	.1294
13	.112		.1143	.1334	.1143	.1294	.1294
14	.0934	.1143	.1143	.1143	.1143	.1097	.0924
15	.0934	.0953	.1143	.1143	.1143	.112	.0924
16	.0924	.0953	.1143	.1143	.1143	.112	.0934
17	.0934	.0953	.1143	.1334	.1334	.112	.0924
18	.112	.1143	.1143	.1334	.1334	.128	.112
19	.1109	.1143	.1143	.1143	.1334	.1663	.112
20	.112	.1143	.1334	.1143	.1334	.128	.1307
21	.1294	.1143		.1334	.1143	.1463	.1307
22	.1294	.1334		.1334	.1334	.128	.1109
23	.112	.1334	.1524	.1334	.1334	.1307	.1267
24	.0924	.1109	.1334	.1334	.1334	.1143	.1307
Max	.1294	.1334	.1524	.1334	.1524	.1663	.1494
Min	.0724	.0739	.0953	.0953	.0953	.0953	.0924
Avg	.0989	.1051	.1152	.1207	.1215	.1176	.1189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283104 / 22/11 KV ANILINE SUBSTATION

Feeder No / Name : 202 / BORIVADE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2378	.2858	.2667	.2286	.2286	.2743
2		.2241	.2667	.2477	.2096	.1905	.2772
3		.2241	.2477	.2096	.2096	.1905	.2587
4		.2054	.2286	.2286	.2096	.1905	.2427
5		.2012	.2286	.2477	.2096	.1905	.2218
6		.2218	.2477	.2667	.2096	.1905	.2241
7		.2614	.2667	.3239	.2477	.2096	.2402
8		.2477	.2667	.3048	.2477	.2477	.2561
9		.2286	.2096		.2858	.2858	.2378
10		.3429	.2096	.3048	.2858	.2614	.2427
11		.2286	.2858	.3048	.2477	.3142	.2561
12			.3048	.2667	.3429	.2587	.2195
13		.2667	.2286	.2667	.2858	.2926	.2195
14		.1905	.2096	.2286	.2096	.2743	.2012
15		.1905	.2286	.2096	.2286	.2195	.1663
16	.2033	.1715	.2286	.2096	.2286	.2218	.1663
17	.2402	.2477	.2096	.2096	.2096	.2218	.1829
18	.2241	.2286	.2096	.2477	.2096	.2195	.1867
19	.2402	.2096	.2286	.2286	.2667	.2353	.2054
20	.2402	.2477	.2477	.2286	.2667	.2614	.2218
21	.2402	.2667		.2286	.2667	.2614	.2241
22	.2614	.2667		.2286	.2477	.2614	.2801
23	.2561	.2858	.2858	.2477	.2477	.2801	.2561
24		.2427	.3048	.2858	.2286	.2477	.0934
Max	.2614	.3429	.3048	.3239	.3429	.3142	.2801
Min	.2033	.1715	.2096	.2096	.2096	.1905	.0934
Avg	.2382	.2364	.2468	.2518	.2429	.2398	.2231

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283104 / 22/11 KV ANILINE SUBSTATION

Feeder No / Name : 203 / RUTU ENCLAVE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5228	.5975	.5716	.6668	.6668	.6668	.6348
2	.4481	.5415	.5335	.5716	.6668	.6287	.4066
3	.4108	.5228	.4763	.5335	.6287	.5906	.4805
4	.3921	.5121	.4191	.4763	.6287	.5906	.462
5	.4435	.5359	.4382	.5716	.6287	.5906	.439
6	.5487	.6099	.5716	.6097	.6668	.6097	.462
7	.6653	.8215	.7621	1.2574	.743	.6478	.5487
8	.8215	.8383	.8383	.9145	.7621	.6838	.6767
9	.7577	.9145	.8764	.9717	.8573	.8215	.8215
10	.6838	.6668	.8573	.8954	.8954	.8413	.8413
11	.6468	.7049	.724	.8573	.8573	.7577	.6767
12	.6219	.6859	.724	.8002	.8002	.8215	.6838
13	.6348	.6097	.6668	.7811	.6668	.7842	.6838
14	.5544	.5906	.6668	.6097	.5716	.7095	.6099
15	.5415	.5716	.6668	.5525	.5716	.6653	.5359
16	.4938	.5716	.6287	.5716	.5525	.6283	.5544
17	.5041	.5906	.5906	.6287	.5716	.6283	.5601
18	.5415	.6287	.5906	.7049	.6668	.6584	.5544
19	.5853	.6668	.6859	.6668	.6668	.7133	.5975
20	.6697	.7049	.7621	.6668	.7049	.7468	.6908
21	.7468	.724		.724	.724	.7468	.6722
22	.7133	.7621		.7621	.724	.7392	.6908
23	.7133	.8383	.8383	.3048	.7049	.7468	.6767
24	.5544	.6283	.8002	.7621	.6668	.6859	.7023
Max	.8215	.9145	.8764	1.2574	.8954	.8413	.8413
Min	.3921	.5121	.4191	.3048	.5525	.5906	.4066
Avg	.5923	.6600	.6677	.7025	.6914	.6960	.6109

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283104 / 22/11 KV ANILINE SUBSTATION

Feeder No / Name : 204 / RUBY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0747	.0762	.0762	.0953	.0572	.112
2	.0373	.0549	.0762	.0762	.0762	.0572	.112
3		.0549	.0762	.0762	.0762	.0572	.0934
4		.056	.0762	.0953	.0762	.0572	.0747
5	.056	.056	.0572	.0953	.0762	.0572	.0747
6	.056	.0747	.0762	.1143	.0762	.0572	.0747
7	.056	.0732	.0762	.1143	.0762	.0572	.0934
8	.056	.0762	.0953	.0953	.0762	.0762	.1097
9	.0934	.0762	.0762	.0762	.0953	.0953	.1086
10	.0747	.0762	.0762	.0953	.0953	.0934	.0747
11	.0747	.1334	.0762	.1334	.1143	.0934	.0732
12	.0554	.1143	.0762	.0762	.0762	.112	.0739
13	.056	.1143	.0572	.0762	.0762	.0934	.0747
14	.056	.0953	.0572	.0762	.0762	.0739	.0554
15	.0549	.0572	.0572	.0762	.0572	.0739	.0554
16	.056	.0762	.0572	.0762	.0572	.0739	.0549
17	.056	.0762	.0572	.0762	.0762	.0554	.037
18	.056	.0953	.0572	.0953	.0762	.0747	.056
19	.0914	.0953	.0572	.0953	.0762	.0934	.0747
20	.1109	.0953	.1143	.0953	.0762	.0747	.0943
21	.1097	.0953		.0953	.0762	.0747	.0934
22	.1097	.0953		.0953	.0953	.0747	.0934
23	.112	.0953	.0762	.1143	.0953	.1109	.0754
24	.0747	.0732	.0953	.0953	.0953	.0762	.112
Max	.112	.1334	.1143	.1334	.1143	.112	.112
Min	.0373	.0549	.0572	.0762	.0572	.0554	.037
Avg	.0709	.0827	.0728	.0913	.0810	.0759	.0813

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283104 / 22/11 KV ANILINE SUBSTATION

Feeder No / Name : 205 / SAFIRE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0381	.0572	.0572	.0572	.056
2					.0572	.0572	.0373
3					.0572	.0572	
4					.0572	.0572	
5			.0381	.0381	.0572	.0572	
6	.0373	.056	.0381		.0572	.0572	
7	.056	.056	.0381		.0572	.0572	.0373
8	.056	.0572	.0381	.0762	.0572		.056
9	.056	.0762			.0572		.037
10	.0373			.0572	.0572	.0747	.037
11		.0381		.0572	.0762	.0549	.037
12		.0381		.0572	.0572	.037	.037
13		.0381		.0572	.0572		.0373
14		.0381		.0572			.0377
15		.0381					.0366
16		.0381		.0572			.0366
17	.0373	.0381	.0381	.0572	.0572		.0366
18	.056	.0381	.0381	.0572	.0572		.037
19	.056	.0381	.0381	.0572	.0572		.056
20	.0554	.0381		.0572	.0572	.0366	
21	.037	.0381		.0572	.0572	.0373	.0566
22	.037	.0381		.0572	.0572	.037	.0566
23	.037	.0381	.0381	.0572	.0572	.0373	.056
24			.0381	.0572	.0572	.0572	.056
Max	.056	.0762	.0381	.0762	.0762	.0747	.0566
Min	.037	.0381	.0381	.0381	.0572	.0366	.0366
Avg	.0465	.0436	.0381	.0572	.0581	.0515	.0441

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283104 / 22/11 KV ANILINE SUBSTATION

Feeder No / Name : 206 / SOLITARE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0554	.0572	.0953	.0762	.0572	.0747
2	.0373	.056	.0381	.0953	.0762	.0572	.0747
3	.0366	.0549	.0381	.0762	.0762	.0572	.056
4	.0373	.037	.0762	.0762	.0762	.0572	.056
5	.0373	.0373	.0572	.0953	.0762	.0572	.0554
6	.056	.0549	.0762	.0762	.0762	.0572	.0554
7	.0739	.0747	.0762	.0953	.0762		.0554
8	.0924	.0953	.0762	.0953	.0762		.0739
9	.0549	.0572	.0381	.0762	.0762	.0572	.0554
10	.0739	.0762	.0381	.0953	.0762	.0747	.0924
11	.0747	.0953	.0572	.0953	.0762	.0739	.0732
12	.0747	.0762		.0762	.0762	.0732	.0724
13	.0739	.0572		.0762	.0762	.0747	.0732
14	.0914	.0762		.0572	.0953	.0739	.0739
15	.0934	.0762		.0572	.0953	.0914	.0732
16	.0549	.0762		.0572	.0953	.0934	.0732
17	.056	.0762		.0762	.0762	.0739	.0739
18	.0747	.0953		.0762	.0762	.0934	.0747
19	.0924	.1143		.0953	.0953	.1307	.0934
20	.1294	.0953		.1143	.0762	.1307	.0934
21	.1307	.1143		.1143	.0762	.112	.0934
22	.0739	.0762		.0953	.0953	.112	.0934
23	.0739	.0572	.0762	.0953	.0953	.0934	.0732
24	.0377	.0554	.0762	.1143	.0953	.0762	.0747
Max	.1307	.1143	.0762	.1143	.0953	.1307	.0934
Min	.0366	.037	.0381	.0572	.0762	.0572	.0554
Avg	.0695	.0725	.0601	.0865	.0818	.0808	.0733

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283104 / 22/11 KV ANILINE SUBSTATION

Feeder No / Name : 207 / INTERLINK ANILINE TO NON SHEDDABLE EXPRESS HV FEEDERS
 HAWARE SU Feeder KV- 11 / (CONTINUOUS PROCESS)(NO STAGGERING)
 INCOMING

DATE	24-AUG-17
HR	Load (MW)
13	.0762
14	.0572
15	.0572
16	.0762
17	.0762
18	.0762
19	.1143
20	.1143
Max	.1143
Min	.0572
Avg	.0810

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283105 / 22/22 KV PATLIPADA SWITCHING

Feeder No / Name : 302 / POKHRAN

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6118	1.6804	1.8176	1.9547	2.2291	2.332	2.6063
2	1.4746	1.5432	1.7147	1.7833	2.0919	2.1262	2.0233
3	1.406	1.3717	1.4746		1.9547	2.0576	1.9204
4	1.3717	1.3032	1.4403	1.4403	1.8176	1.9547	1.9547
5	1.3032	1.3032	1.406	1.406	1.8176	1.9547	1.989
6	1.5775	1.4403	1.5775	1.3717	1.9204	2.0576	2.0576
7	1.2803	2.1262	1.8519	1.7833	2.2634	2.3663	2.5034
8	1.989	1.9204	1.9204	1.9204	2.8121	2.5034	2.7435
9	2.332	2.2977	2.1605	2.0576	3.3608	2.8464	3.2922
10	3.0178		2.8464	2.0919	4.1152	3.4979	4.1495
11	3.155	2.9835	3.1207	2.1605	4.1838	3.6694	4.2524
12	3.2236	3.2922	3.1893	2.2291	3.9781	3.6694	4.0124
13	2.6063	2.7092	2.5034	1.7833	3.4294	3.4979	3.4294
14	2.8807	2.7778	2.6749	1.8519	3.4637	3.2579	3.4979
15	3.155	2.915	2.8121	1.7833	3.7037	3.3608	3.6694
16	3.0864	2.9835	2.915	1.7147	3.6351	3.0521	3.4294
17	2.8807	2.8121	2.7092	1.749	3.3608	3.0521	3.3951
18	2.7435	2.7092	2.6749	1.7833	3.3608	3.2579	3.4637
19	3.1207	2.9492	3.0864	2.0576	3.8066	3.5665	3.7037
20	2.9492	2.8464	2.7435	1.989	2.2862	3.4294	3.4294
21	2.572	2.1948	2.5034	1.989	3.2579	3.2236	2.9835
22	2.2291	2.1262	2.2291	1.9204	3.1207	3.2236	2.8807
23	2.0576	2.1605	2.0919	2.6749	2.9492	3.0178	2.8807
24	1.8519	1.8861	2.0576	2.0576	2.6063	2.7435	2.7435
Max	3.2236	3.2922	3.1893	2.6749	4.1838	3.6694	4.2524
Min	1.2803	1.3032	1.406	1.3717	1.8176	1.9547	1.9204
Avg	2.3282	2.2753	2.3134	1.8936	2.9802	2.9049	3.0421

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283105 / 22/22 KV PATLIPADA SWITCHING

Feeder No / Name : 303 / ANILINE

Feeder KV- 22 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	28-AUG-17
HR	Load (MW)
3	2.0576
4	2.0233
5	2.0919
6	2.332
7	2.4348
8	2.6749
9	2.8464
10	2.8464
11	2.7778
12	2.6749
13	2.4348
14	2.1262
15	2.0576
16	2.0576
17	2.1605
18	2.3663
19	2.6406
20	2.8464
21	2.7435
22	2.6749
Max	2.8464
Min	2.0233
Avg	2.4434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283105 / 22/22 KV PATLIPADA SWITCHING

Feeder No / Name : 304 / AKBAR CAMP

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7545	.823	.8573	.7888	2.4348	2.1262
2	.6859	.6859	.7545	.7888	.6859	2.4006	1.7833
3	.7202	.6173	.7545	.7545	.7202	2.332	2.3663
4	.6859	.6859	.6859	.7545	.6859	2.2977	2.3663
5	.6173	.7202		.7545	.6859	2.2977	2.4006
6	.7545	.823		.823	.6859	2.2977	2.4006
7	.9945	.9602		.8573	.823	2.2634	2.5034
8	1.1317	1.2003	1.0288	.9259	1.5089	2.5034	2.6406
9	1.1317	1.166	.8573	.7888	2.2977	2.4348	2.572
10	1.2689	3.0864	.9945	.8573	2.6063	2.4348	3.0178
11	1.3717	3.0864	1.0974	.823	2.572	2.4006	3.0864
12	1.2003	3.0178	.8916	.823	2.4691	2.572	2.7435
13	1.1317	2.8807	.9259	.823	2.5377	2.6406	2.7435
14	1.2346	2.9492	.8573	.7545	2.4691	2.6063	2.8121
15	1.0631	2.6063	1.2689	.7202	2.4348	2.4006	2.8121
16	1.2346	2.7435	1.2346	.6859	2.4006	2.5377	2.6749
17	1.2003	1.2346	1.1317	.6859	2.5034	2.4691	2.7092
18	1.166	1.2003	1.1317	.823	2.5377	2.2977	2.7435
19	1.2003	1.2346	1.2346	.9259	2.4691	2.6749	2.8121
20	1.2003	1.2346		.9602	2.7092	2.6749	2.8807
21	1.0974	1.0974	1.1317	.9259	2.6063	2.6406	2.6063
22	1.0631	1.0631	1.0974	.8916	2.572	2.6063	2.6749
23	.9259	.9945	1.0288	.8573	2.4691	2.6063	2.5377
24	.7202	.8573	.8573	.8916	.7888	2.4691	2.332
Max	1.3717	3.0864	1.2689	.9602	2.7092	2.6749	3.0864
Min	.6173	.6173	.6859	.6859	.6859	2.2634	1.7833
Avg	1.0231	1.5375	.9894	.8230	1.8761	2.4706	2.5978

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283105 / 22/22 KV PATLIPADA SWITCHING

Feeder No / Name : 305 / KASARVADAVALI & STN X'MER NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 22 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	28-AUG-17
HR	Load (MW)
5	.823
6	1.0974
7	1.5775
8	1.7833
9	2.0576
10	2.572
11	2.572
12	2.4006
13	2.5377
14	2.4691
15	2.2634
16	2.4006
17	2.3663
18	2.4348
19	3.7037
20	1.8861
21	1.7147
22	1.5089
23	1.4403
Max	3.7037
Min	.823
Avg	2.0847

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283105 / 22/22 KV PATLIPADA SWITCHING

Feeder No / Name : 306 / G.B. South SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0864	3.1207	3.0864	3.4979	2.8121	3.0864	3.1893
2	2.7435	2.9835	2.8807	3.3265	2.6406	2.9492	2.6063
3	2.572	2.915	2.8464	3.2922	2.5377	2.7778	2.572
4	2.5377	2.8121	2.8121	3.1893	2.4006	2.7435	2.6406
5	2.5034	2.8807	2.7778	3.155	2.4006	2.7092	2.6749
6	2.6749	3.0178	2.9492	3.1207	2.5034	2.8121	2.7435
7	2.8464	3.155	3.0864	3.0864	2.6063	2.915	2.9835
8	3.3608	3.4637	3.3951	3.1207	3.2236	2.915	3.4294
9	3.9438	4.1152	4.8011	3.4294	4.0466	3.4979	4.2867
10	4.6639	5.1097	7.4417	3.7723	4.6296	4.2181	5.144
11	5.4184	5.6242	8.059	3.6694	5.0069	4.5953	5.6927
12	5.0755	4.9726	7.6818	3.6694	5.0069	4.6296	5.5213
13	4.0124	4.3896	3.2579	3.5665	4.3896	4.3896	4.5953
14	4.5268	4.5953	5.4184	3.3608	4.5268	4.0466	4.8697
15	5.0069	4.5953	5.5556	2.9835	4.5953	4.0124	4.9383
16	4.9383	4.6296	5.5556	2.8464	4.5268	3.9438	4.7668
17	5.0412	4.5268	5.5213	2.9835	4.561	4.0466	4.5953
18	4.8011	4.2181	4.9726	3.1207	4.6639	4.0466	4.8354
19	4.8011	4.4925	5.3155	3.5665	4.8011	4.2524	5.2469
20	4.7325	4.6639	5.3841	3.7037	4.8354	4.3896	4.9383
21	4.8697	4.321	5.0069	3.8409	4.6982	4.3896	4.561
22	3.9095	3.8409	4.2181	3.1893	4.1152	3.9781	3.8066
23	3.738	3.6008	4.2181	3.1207	3.7037	3.7723	3.8066
24	2.9492	3.4294	3.1893	3.738	2.9835	3.4979	3.4979
Max	5.4184	5.6242	8.059	3.8409	5.0069	4.6296	5.6927
Min	2.5034	2.8121	2.7778	2.8464	2.4006	2.7092	2.572
Avg	3.9481	3.9781	4.5596	3.3479	3.8423	3.6923	4.0809

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283107 / 22/11KV HAWARE CITY

SUBSTATION

Feeder No / Name : 201 / RATANTEJ

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.5716	.6478	.5906	.5144	.5335	.5906
2	.5144	.5525	.6287	.5525	.4763	.4954	.5716
3	.4954	.5716	.6478	.5144	.4763	.4572	.5335
4	.5335	.5716	.5716	.5144	.4572	.4572	.5144
5	.5144	.5525	.6097	.4763	.4572	.4382	.5144
6	.5525	.5144	.6287	.5335	.4763	.4954	.5144
7	.5335	.5525	.6097	.5906	.5716	.5335	
8	.5716	.5335	.6287	.5716	.6097	.6287	.5525
9	.5906	.5525	.6478	.5716	.5716	.6287	.5906
10	.6287	.5906	.7621	.6859	.724		.6478
11	.5906	.6287	.724	.6668	.6859	.6859	.6668
12	.6097	.6668	.7049	.6668	.7621		.7049
13	.6478	.6859	.6478	.6287	.6478	.5716	.5716
14	.6478	.6478	.5525	.5525	.6097	.6097	.4572
15	.6668	.6859	.4382	.5144	.6478	.6287	.5335
16	.5144	1.3336	.5335	.5144	.6478	.6478	.5906
17	.5525	.6859	.6097	.4954	.6097	.6668	.5716
18	.5906	.6668	.6668	.5525	.6668	.7049	.6668
19	.5716	.6859	.6859	.6287	.724	.724	.7049
20	.6668	.6668	.6859	.7049	.724	.7811	.7049
21	.6859	.6668	.724	.6478	.6668	.7049	.5906
22	.6287	.6478	.6668	.6287	.6287	.6668	.6478
23	.5906	.6287	.6478	.6287	.6287	.6668	.6097
24	.5144	.6478	.6478	.6097	.5716	.5906	.5906
Max	.6859	1.3336	.7621	.7049	.7621	.7811	.7049
Min	.4763	.5144	.4382	.4763	.4572	.4382	.4572
Avg	.5787	.6462	.6383	.5851	.6065	.6053	.5931

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283107 / 22/11KV HAWARE CITY

SUBSTATION

Feeder No / Name : 202 / PLATINUM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.5716	.5525	.4382	.4001	.4191	.5335
2	.5144	.5525	.5716	.4001	.381	.381	.4954
3	.4954	.5144	.5716	.381	.3429	.381	.4572
4	.5335	.5525	.5525	.362	.3429	.362	.4954
5	.5144	.5716	.5335	.362	.362	.3429	.4572
6	.5525	.5525	.5906	.4191	.4001	.381	.5144
7	.6097	.5144	.6097	.4572	.4954	.4382	
8	.6668	.5525	.6097	.6478	.5716	.4954	.5335
9	.743	.5906	.6287	.7049	.6668	.5716	.6287
10	.6097	.5906	.5906	.7049	.7621	.5716	.5906
11	.5716	.5716	.6097	.5335	.6287	.5525	.5716
12	.5525	.5716	.4954	.5335	.5716		.5525
13	.5335	.5525	.4954	.5144	.5525	.5335	.4954
14	.4763	.5525	.4191	.4382	.4382	.381	.4191
15	.4001	.5335	.4001	.4001	.4191	.381	.381
16	.4191	.5144	.4001	.4382	.4763	.4001	.4382
17	.4382	.5335	.4954	.4954	.5144	.4763	
18	.4763	.4954	.4191	.5335	.4954	.4382	.5144
19	.4954	.4954	.5144	.5335	.4954	.5525	.5335
20	.5144	.5144	.5335	.4954	.4954	.4763	.5716
21	.5144	.5525	.5144	.4954	.5525	.5144	.5144
22	.5525	.5335	.5144	.5144	.5144	.4572	.5144
23	.5716	.5335	.5906	.4954	.4954	.4572	.4763
24	.4954	.5906	.5525	.5144	.4572	.4763	.4572
Max	.743	.5906	.6287	.7049	.7621	.5716	.6287
Min	.4001	.4954	.4001	.362	.3429	.3429	.381
Avg	.5303	.5462	.5319	.4922	.4930	.4539	.5066

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283107 / 22/11KV HAWARE CITY

SUBSTATION

Feeder No / Name : 203 / 11 KV HAWARE CITY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.4382	.4572	.362	.3239	.381	
2	.4001	.4763	.4763	.362	.3048	.362	.362
3	.4382	.4572	.5144	.3429	.3048	.362	.4001
4	.4191	.4382	.4954	.3429	.2858	.3239	.0762
5	.4572	.4191	.4763	.3239	.2858	.3048	.362
6	.4954	.4572	.4572	.362	.3048	.3048	.362
7	.4763	.4763	.4954	.4001	.381	.362	
8	.4954	.4954	.5144	.4572	.381	.4382	
9	.4954	.4954	.4954	.4763	.4382	.4572	.4191
10	.4191	.4763	.4001	.4763	.4572	.4382	.4763
11	.4001	.4382	.4001	.4763	.4001	.4382	.4763
12	.362	.4001	.4191	.4572	.4191		.4191
13	.3239	.362	.362	.381	.4191	.4572	.4001
14	.2858	.3429	.4001	.3239	.4191	.3429	.3048
15	.2477	.362	.3048	.2858	.4001	.381	.2858
16	.2858	.3239	.2858	.2858	.3429	.362	.2858
17	.3239	.3429	.3048	.3048	.3048	.3048	.3239
18	.362	.3429	.2858	.3239	.3239	.3429	.3048
19	.4001	.3239	.4382	.381	.4191	.4001	.4191
20	.4191	.4001	.4001	.4191	.381	.4001	.4001
21	.4382	.4382	.4382	.4382	.4191	.4382	.5144
22		.4572	.4382	.4001	.4572	.4763	.4572
23	.4382	.4763	.4572	.381	.4001	.4763	.4191
24	.362	.4572	.4763	.4001	.362	.4191	.362
Max	.4954	.4954	.5144	.4763	.4572	.4763	.5144
Min	.2477	.3239	.2858	.2858	.2858	.3048	.0762
Avg	.3968	.4207	.4247	.3818	.3723	.3901	.3729

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283107 / 22/11KV HAWARE CITY

SUBSTATION

Feeder No / Name : 204 / UNNATI GREEN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.1524	.1715	.1334	.1143	.1143	.1143
2	.362	.1524	.1715	.1143	.0953	.1143	.1143
3	.3429	.1524	.1715	.1143	.0953	.0953	.1334
4	.3239	.1715	.1524	.0953	.0953	.0953	.1334
5	.362	.1715	.1524	.0953	.0953	.1143	.1334
6	.3429	.1715	.1334	.1143	.0953	.1905	.1334
7	.362	.1715	.1334	.1143	.1143	.1334	
8	.381	.1334	.1334	.1143	.1334	.1334	.1334
9	.381	.1334	.1524	.1334	.1143	.1334	.1334
10	.362	.1334	.1524	.1334	.1715	.1524	.1715
11	.362	.1524	.1524	.1524	.1715	.1334	.1334
12	.381	.1334	.1715	.1334	.1334		.1334
13	.362	.1334	.1334	.1334	.1334	.1334	.1143
14	.3429	.1334	.0953	.1143	.1143	.1143	.1143
15		.1334	.0953	.0953	.0953	.1524	.1334
16		.1143	.0953	.0953	.1143	.0953	.0953
17		.1143	.0953	.0953	.1143	.1143	.0953
18		.0953	.0953	.0953	.0953	.1143	.1143
19	.1715	.0953	.1334	.1143	.0953	.1143	.1334
20	.1715	.1143	.1524	.1334	.1143	.1143	.1143
21	.1715	.1143	.1334	.1143	.1143	.1143	.1334
22	.1715	.1334	.1334	.1334	.1143	.1143	.1143
23	.1524	.1524	.1334	.1143	.1524	.1143	.1143
24	.3239	.1524	.1524	.1334	.1143	.1143	.1143
Max	.381	.1715	.1715	.1524	.1715	.1905	.1715
Min	.1524	.0953	.0953	.0953	.0953	.0953	.0953
Avg	.3077	.1381	.1374	.1175	.1167	.1226	.1243

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

KOLSHETH URBAN S/DN.[541] BU 4541

Substation No/ Name :- 283113 / 22/11 KV ACME-JAI BHAWANI

NAGA

Feeder No / Name : 201 / OAKWOOD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.128	.1829	.1463	.2012	.1463	.1646	.168
2	.1463	.1829	.1646	.1829	.1463	.1463	.1463
3	.1463	.1646	.1463	.1646	.1463	.1646	.1494
4	.1646	.168	.1463	.1463	.128	.1646	.1494
5	.1646	.1829	.1463	.1463	.128	.1646	.1494
6	.1829	.1829	.1646	.1646	.128	.1463	.1463
7	.1829	.2012	.1829	.1646	.1829	.1646	.2012
8	.2378	.2195	.2195	.2378	.2195	.2012	.1991
9	.2195	.2195	.2012	.2195	.2195	.2195	.2743
10	.2561	.2241	.2561	.2195	.2195	.2012	.2614
11	.2614	.2054	.1829	.2561	.2743	.2561	.2926
12	.2378	.2195	.2195	.1829	.2195	.2926	.2012
13	.2402	.1646	.2012	.2012	.2378	.2012	.2012
14	.168	.1646	.1829	.1463	.2378	.2012	.1829
15	.1867	.1646	.2561	.2012	.2012	.2195	.1829
16	.2054	.1646	.2195	.1646	.2195	.1829	.1698
17	.2054	.1646	.2195	.2012	.1829	.2195	.1886
18	.2427	.2012	.2561	.1829	.2561	.2378	.2075
19	.2801	.2195	.2195	.2195	.2195	.2561	.2075
20	.2427	.2195	.2561	.2012	.2195	.2378	.2263
21	.2218	.2012	.2378	.2012	.2195	.2195	.2195
22	.2033	.2195	.2561	.2012	.2195	.2378	.2263
23	.2054	.1829	.2195	.1646	.2012	.2012	.1886
24	.128	.1829	.2012	.2012	.1646	.1646	.1829
Max	.2801	.2241	.2561	.2561	.2743	.2926	.2926
Min	.128	.1646	.1463	.1463	.128	.1463	.1463
Avg	.2024	.1918	.2043	.1905	.1974	.2027	.1968

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283035 / 22/11 SHIVAI NAGAR

Feeder No / Name : 202 / NILLKANTH HEIGHTS
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	23-AUG-17	25-AUG-17	26-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.5792		
8		.7059	.6878	
12		.6697		.7842
16				.5228
20				.7655
23				.7468
24	.6219	.724	.6878	
Max	.6219	.724	.6878	.7842
Min	.6219	.5792	.6878	.5228
Avg	.6219	.6697	.6878	.7048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283035 / 22/11 SHIVAI NAGAR

Feeder No / Name : 203 / SHIVAI NAGAR NO.2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-AUG-17	25-AUG-17	26-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.4207		
8		.6036	.4938	
12		.5487		.5068
16				.4706
23				.5611
24	.4668	.5121	.4938	
Max	.4668	.6036	.4938	.5611
Min	.4668	.4207	.4938	.4706
Avg	.4668	.5213	.4938	.5128

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283035 / 22/11 SHIVAI NAGAR

Feeder No / Name : 204 / GANESH NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-AUG-17	25-AUG-17	26-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		1.0269		
8		1.1763	1.1576	
12		1.1203		1.5497
16				1.4563
20				1.5123
23				1.3256
24	1.1273	1.251	1.1389	
Max	1.1273	1.251	1.1576	1.5497
Min	1.1273	1.0269	1.1389	1.3256
Avg	1.1273	1.1436	1.1483	1.4610

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283035 / 22/11 SHIVAI NAGAR

Feeder No / Name : 205 / SHIVAI NAGAR NO.1
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	23-AUG-17	25-AUG-17	26-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.6516		
8		.8326	.7783	
12		.7602		
16				.5611
20				.8688
23				.7421
24	.724	.7421	.6878	
Max	.724	.8326	.7783	.8688
Min	.724	.6516	.6878	.5611
Avg	.724	.7466	.7331	.724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283035 / 22/11 SHIVAI NAGAR

Feeder No / Name : 206 / ATHARV PARK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-AUG-17	25-AUG-17	26-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.462		
8		.7392	.6099	
12		.6283		.6283
16				.499
20				.5729
23				.5914
24	.499	.6099	.5359	
Max	.499	.7392	.6099	.6283
Min	.499	.462	.5359	.499
Avg	.499	.6099	.5729	.5729

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283035 / 22/11 SHIVAI NAGAR

Feeder No / Name : 207 / MADHUBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-AUG-17	25-AUG-17	26-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.2033		
8		.2402	.1294	
12		.2587		
16				.5729
20				.4435
23				.2957
24	.2743	.2402	.1478	
Max	.2743	.2587	.1478	.5729
Min	.2743	.2033	.1294	.2957
Avg	.2743	.2356	.1386	.4374

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283035 / 22/11 SHIVAI NAGAR

Feeder No / Name : 208 / WATER PUMPING

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-AUG-17	25-AUG-17	26-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.3258		
8		.3761	.3403	
12		.3224		.394
16				.2865
20				.4119
23				.3761
24	.3206	.3761	.3403	
Max	.3206	.3761	.3403	.4119
Min	.3206	.3224	.3403	.2865
Avg	.3206	.3501	.3403	.3671

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283037 / 22/11 KV DOSTI VIHAR

Feeder No / Name : 201 / DF-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3077	.3174	.3361	.3734	
2	.2896	.2987	.3361	.3734	
3	.2743	.2801	.3174	.3361	
4	.3142	.3174	.3547	.3361	
5	.3326	.3361	.3547	.3734	
6	.3511	.3361	.3734	.4108	
7	.3696	.3547	.3734	.4108	
8	.3881	.4481	.3547	.462	
9	.362	.4294	.3361	.462	
10	.3881	.4294	.3547	.4668	
11	.3734	.3734	.3547	.4668	
12	.3174	.3547	.3547	.3734	
13	.3547	.3547	.3547	.3734	
14	.2896	.3547	.3734	.3734	
15	.2715	.3326	.3921	.3361	
16	.2743	.3361	.4108	.3361	
17	.3292	.3174	.4108	.3174	
18	.3475	.3734	.3921	.3734	
19	.3881	.3734	.3921	.3734	
20	.4108	.4108	.4481	.4108	
21	.4108	.4481	.4854	.4108	
22	.4207	.4294	.4854	.3921	
23	.4024	.4251	.4481	.3734	
24	.3292	.3658	.4481	.4108	.3547
Max	.4207	.4481	.4854	.4668	.3547
Min	.2715	.2801	.3174	.3174	.3547
Avg	.3457	.3665	.3851	.3886	.3547

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283037 / 22/11 KV DOSTI VIHAR

Feeder No / Name : 203 / DF-3

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1991		.2241	.2241	
2	.181	.1867	.1867	.1867	
3	.1829	.2054	.1867	.1867	
4	.2012	.2241	.1867	.1867	
5	.2195	.2427	.1867	.2241	
6	.2378	.2614	.2241	.2241	
7	.2561	.2427	.2241	.2801	
8	.3077	.3174	.2241	.2801	
9	.2743	.3174	.2427	.2801	
10	.2172	.3174	.2427	.2801	
11	.2195	.2801	.2241	.2801	
12	.2033	.2241	.2241	.2241	
13	.2012	.2241	.1867	.2241	
14	.2054	.2241	.2614	.1867	
15	.1848	.1867	.2915	.1867	
16	.1867	.1867	.3174	.1867	
17	.2012	.1867	.2614	.168	
18	.2195	.1867	.2614	.2241	
19	.2743	.2241	.2614	.2241	
20	.2926	.2241	.2614	.2801	
21	.2772	.2801	.3361	.2801	
22		.2801	.3361	.3174	
23	.2378	.2801	.2987	.3174	
24		.2195	.2614	.2614	.2427
Max	.3077	.3174	.3361	.3174	.2427
Min	.181	.1867	.1867	.168	.2427
Avg	.2264	.2401	.2463	.2381	.2427

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283037 / 22/11 KV DOSTI VIHAR

Feeder No / Name : 205 / DF-5

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2772	.3696	.3174	
2	.2614	.2427	.3361	.2801	
3	.2402	.3361	.3361	.2801	
4	.3292	.3734	.3361	.3361	
5	.3475	.4108	.3547	.3734	
6	.3658	.4854	.3921	.4668	
7	.4294	.5228	.4294	.462	
8	.4938	.5041	.4668	.499	
9	.462	.462	.4668	.5544	
10	.3658	.462	.4668	.5544	
11	.3292	.462	.4294	.5359	
12	.2987	.3174	.3734	.3734	
13	.2378	.3174	.3174	.3734	
14	.2561	.3174	.3361	.3361	
15	.2801	.3174	.3734	.3361	
16	.2743	.2801	.3734	.3361	
17	.2561	.2614	.4108	.2772	
18	.2743	.3696	.4294	.3772	
19	.4024	.3696	.4294	.3734	
20	.4481	.3696	.4294	.3696	
21	.4572	.462	.4294	.4108	
22	.4207	.5228	.4108	.415	
23	.4207	.3921	.3734	.4108	
24		.3841	.3921	.3547	.3734
Max	.4938	.5228	.4668	.5544	.3734
Min	.2378	.2427	.3174	.2772	.3734
Avg	.3446	.3841	.3943	.3918	.3734

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283037 / 22/11 KV DOSTI VIHAR

Feeder No / Name : 206 / DF-6

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8962	.9593	.9955	1.086	
2	1.0534	1.0498	.9412	1.0317	
3	1.0425	1.1222	.9412	1.0269	
4	1.0059	1.1584		1.0269	
5	1.0974	1.2127	1.0136	1.0679	
6	1.1576	1.1403	1.086	1.1403	
7	1.262	1.2308	1.1765	1.267	
8	1.1765	1.3213	1.2308	1.3213	
9	1.2437	1.3575	1.267	1.3756	
10	1.3306	1.3575	1.3575	1.3756	
11	1.2803	1.3575	1.3575	1.3756	
12	1.2323	1.2883	1.2489	1.2851	
13	1.0425	1.2489	1.1584	1.267	
14	1.0608	1.1765	1.251	1.267	
15	1.0425	1.086	1.2127	1.1946	
16	.9511	1.086	1.2127	1.1222	
17	.9877	1.0136	1.1946		
18	1.0082	1.086	1.1946	1.1041	
19	1.2071	1.1765	1.1946	1.2308	
20	1.3169	1.267	1.267	1.3575	
21	1.363	1.3443	1.3394	1.3575	
22	1.3535	1.3575	1.3394	1.3394	
23	1.1946	1.3394	1.3032	1.3394	
24		1.0608	1.086	1.1222	1.0679
Max	1.363	1.3575	1.3575	1.3756	1.0679
Min	.8962	.9593	.9412	1.0269	1.0679
Avg	1.1438	1.1999	1.1900	1.2209	1.0679

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283037 / 22/11 KV DOSTI VIHAR

Feeder No / Name : 207 / DF-7

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.1494	.2241	.2241	
2	.128	.181	.1867	.1867	
3	.1848	.2241	.1867	.1867	
4	.2195	.2614	.168	.1494	
5	.2427	.2801	.168	.1494	
6	.2614	.3174	.1867	.2054	
7	.2743	.2987	.1867	.2427	
8	.2743	.3361	.2054	.2427	
9	.2534	.3174	.2054	.3547	
10	.2926	.2801	.2241	.2987	
11	.2218	.2241	.2054	.2614	
12	.2012	.1867	.2054	.2614	
13	.1509	.1867	.1867	.2241	
14	.1463	.1867	.1867	.2241	
15	.1698	.1494	.2241	.1867	
16	.1463	.1494	.2241	.1494	
17	.1494	.1494	.2614	.1494	
18	.2012	.1867	.2801	.1867	
19	.2743	.1867	.2801	.1867	
20	.2241	.2241	.2801	.1867	
21	.2378	.2427	.3696	.2241	
22		.2614	.3696	.2241	
23	.2012	.2614	.3696	.2218	
24		.2012	.2427	.2772	.2054
Max	.2926	.3361	.3696	.3547	.2054
Min	.128	.1494	.168	.1494	.2054
Avg	.2092	.2268	.2345	.2168	.2054

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283080 / 22/11KV MHADA S/STN

Feeder No / Name : 203 / FEEDER NO. 3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3174	.4251	.3734	.4435	.5175	.4668	.3326
2	.2987	.3881	.3361	.4066	.5544	.3921	.2957
3	.2987	.3142	.3361	.3326	.3142	.3921	.2957
4	.3174	.3511	.3734	.3326	.5914	.4108	.3142
5	.4294	.4435	.7095	.3696	.7023	.5415	.3326
6	.4854	.7207	.7392	.6283	.7392	.6535	.3696
7	.6722	.7577	.7577	.7023	.7577	.6908	.4435
8		.8589	.8501	.5729	.8131	.8215	.5914
9		.8775	.8871	.8501	.8215	.8316	.7577
10	.823	.8962	.9055	.8501	.8962	.8871	.8316
11	.7499	.7842	.8686	.8501	.8215	.7947	.8316
12	.6036	.7522	.9055	.7762	.7655	.8686	.8316
13	.5304	.7842	.8871	.6468	.5601	.7392	.8501
14	.4755	.6908	.6653	.5544	.4854	.6838	.7577
15	.5121	.6908	.462	.499	.5228	.4066	.4251
16	.439	.4481	.5359	.5729	.5228		.6283
17	.5487	.5228	.6468	.5544	.5415	.6283	.5544
18	.6584	.6535	.6838	.7682	.7468	.6653	.6468
19	.8596	.8589	.7947	.8501	.8029	.8686	.7762
20	.8962	.8871	.8871	.8686	.8775	.8131	.8131
21	.9328	.8402	.8871	.7392	.8029	.7577	.8316
22		.7842	.7947	.7023	.7468	.7577	.7577
23	.7207	.7842	.7577	.7207	.7655		.7392
24	.6348	.6099	.6722	.6283	.5914	.6535	.6099
Max	.9328	.8962	.9055	.8686	.8962	.8871	.8501
Min	.2987	.3142	.3361	.3326	.3142	.3921	.2957
Avg	.5811	.6718	.6965	.6342	.6775	.6693	.6091

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283080 / 22/11KV MHADA S/STN

Feeder No / Name : 204 / FEEDER NO. 4

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0302	2.1948	2.2862	2.3594	2.1948	2.1033	2.1399
2	1.8839	2.0485	2.1582	2.2314	2.1948	2.0119	2.0119
3	1.8107	2.0485	2.0485	2.0851	1.9022	2.0119	2.0119
4	1.7924	2.1765	2.0302	2.0119	2.3777	1.9936	1.9936
5	1.8107	2.1948	2.0302	2.0485	2.3411	2.0119	2.0119
6	1.957	2.268	2.1948	2.1948	2.4874	2.0302	2.0302
7	2.2497	2.4143	2.3777	2.3777	2.524	2.0668	2.0668
8		2.5789	2.7252	2.5606	2.4326	2.3777	2.3777
9		2.7435	2.7618	2.7252	2.7618	2.4691	2.5503
10	2.5972	2.7618	2.7069	2.7435	2.652	2.652	2.5789
11	2.524	2.5606	2.524	2.6155	2.5789	2.5789	2.5972
12	2.3411	2.396	2.4326	2.4143	2.4143	2.6155	2.3411
13	2.268	2.3045	2.3045	2.268	2.2862	2.4874	2.2862
14	2.2314	2.4326	2.1216	2.1399	2.1948	2.2497	2.1033
15	2.1582	2.4143	2.0668	1.9387	2.1033	2.0851	1.9936
16	2.1033	2.1948	2.2862	1.9936	2.1033	1.949	2.0851
17	2.2131	2.2497	2.4691	2.0302	2.1582	2.1582	2.1948
18	2.396	2.4874	2.4874	2.1948	2.4326	2.5057	2.3045
19	2.7984	2.9264	2.8349	2.1948	2.652	2.7984	2.7801
20	3.091	3.2007	3.1642	2.7801	2.8349	2.9264	2.963
21	3.1276	3.2007	3.1824	2.8715	2.8166	2.8349	2.9264
22	3.0361	3.091	3.219	2.7801	2.7801	2.8349	2.7435
23	2.8166	2.9447	2.9014	2.6703	2.652		2.5972
24	2.2862	2.4691	2.7252	2.6886	2.396	2.5057	2.4691
Max	3.1276	3.2007	3.219	2.8715	2.8349	2.9264	2.963
Min	1.7924	2.0485	2.0302	1.9387	1.9022	1.949	1.9936
Avg	2.3419	2.5126	2.5016	2.3716	2.4280	2.3591	2.3399

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283080 / 22/11KV MHADA S/STN

Feeder No / Name : 205 / FEEDER NO. 5

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5014	.6036	.591	.6584	.5121	.5731	.5853
2	.4656	.5487	.5373	.5853	.5487	.5194	.5304
3	.4656	.5304	.5373	.5487	.5304	.4835	.4938
4	.4835	.567	.5373	.5487	.567	.4656	.4755
5	.5014	.5121	.5373	.567	.4755	.4656	.4755
6		.6036	.5731	.6036	.6036	.4835	.4938
7		.5853	.6268	.7316	.5121	.5014	.5121
8		.6447	.6447	.6584	.6401	.6089	.6219
9		.6268	.695	.7316	.6626	.7316	.695
10	.6201	.6516	.6584	.7316	.6805	.7316	.6767
11	.5847	.6089	.6219	.6767	.6089	.6584	.6401
12	.5316	.5373	.7133	.5121	.591	.6219	.6036
13	.5138	.5373	.6584	.5853	.5731	.6219	.567
14	.5138	.5373	.567	.5487	.5731	.5853	.4938
15	.4607	.5552	.5304	.5121	.4835	.567	.4572
16	.443	.4835	.5121	.5487	.4835	.5487	.4572
17	.443	.5014	.5304	.5853	.4835	.5304	.4755
18	.4607	.5373	.567		.5194	.5853	.5121
19	.6733	.6447	.7133	.6767	.6268	.7316	.6767
20	.7442	.788	.7682	.7499	.7343	.7682	.7316
21	.7973	.8059	.8048	.7316	.7164	.7499	.7316
22	.7865	.8059	.8048	.7133	.6984	.7499	.7316
23	.8413	.7522	.7865	.695	.7343		.6767
24	.591	.695	.6805	.7133	.6401	.6626	.6767
Max	.8413	.8059	.8048	.7499	.7343	.7682	.7316
Min	.443	.4835	.5121	.5121	.4755	.4656	.4572
Avg	.5711	.6110	.6332	.6354	.5916	.6063	.5830

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283110 / 22/11 kv Akruti Substation

Feeder No / Name : 201 / LAXMI INDUSTRIES SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.3841			.2743	.2743
2	.2561	.3841			.2743	.2743
3	.2743	.4024			.2743	.2743
4	.2743	.3658			.2561	.2561
5	.2926	.3658			.2743	.2743
6	.2743	.3475			.2561	.2743
7	.2743	.3292			.2561	.2743
8	.3475	.3109	.3292		.3292	.3292
9	.3658	.4938			.3658	.3475
10	.5304	.5853		.3841	.5121	.439
11	.6036	.6767		.3841	.6219	.4755
12	.6219	.6767	.695	.3475	.5853	.4207
13	.5487	.5487		.2561	.4938	.3475
14	.5304	.5487		.2378		.7316
15	.5304	.5853	.6036	.2378	.4207	.3292
16	.5304	.5853		.3109	.4207	.3109
17	.6219	.5487	.5853	.2378	.4207	.3109
18	.5487	.5487		.2561	.4207	.3292
19	.5487	.5304		.3109	.4572	
20	.4938	.4938		.3109	.4572	
21	.4572	.4572		.2743	.4024	
22	.4024	.3658		.3292	.3475	
23	.3658			.3109	.3475	
24	.2926	.3658	.3292		.2926	.3109
Max	.6219	.6767	.695	.3841	.6219	.7316
Min	.2561	.3109	.3292	.2378	.2561	.2561
Avg	.4275	.4739	.5085	.2992	.3809	.3465

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283110 / 22/11 kv Akruti Substation

Feeder No / Name : 202 / Old MSEB SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6154	.7059			.6335	.6335
2	.5973	.6697			.6335	.6335
3	.6335	.6516			.6154	.6335
4	.6697	.6697			.6154	.6154
5	.6697	.6878			.5973	.5973
6	.6878	.7059			.6154	.5973
7	.6878	.724			.5973	.5973
8	.724	.7421	.7602		.6516	.6154
9	.724	.7783			.724	.6878
10	.7783	.8145		.724	.7421	.7421
11	.8145	.8145		.7783	.8507	.7421
12	.8326	.8145	.7964	.724	.724	.7421
13	.724	.7783		.6335	.6697	.7059
14	.724	.7602		.5973		.6516
15	.7421	.724	.6516	.5792	.6516	.6878
16	.7059	.7421		.5611	.6516	.7059
17	.7783	.7783	.7421	.5792	.6516	.5068
18	.8145	.7783		.6697	.7421	.7783
19	.9412	.9231		.8326	.8507	
20	.9955	.9955		.8507	.8869	
21	.9412	.9593		.8145	.8688	
22	.905	.9593		.7783	.8326	
23	.8326			.7421	.7602	
24	.6335	.724	.8507		.724	.7059
Max	.9955	.9955	.8507	.8507	.8869	.7783
Min	.5973	.6516	.6516	.5611	.5973	.5068
Avg	.7572	.7783	.7602	.7046	.7083	.6621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283110 / 22/11 kv Akruiti Substation

Feeder No / Name : 203 / VIHANG PARK SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.463	.5658			.4973	.4458
2	.4458	.5487			.4973	.4458
3	.463	.5316			.4973	.4458
4	.4801	.5658			.4801	.4458
5	.5316	.583			.4801	.463
6	.583	.583			.4801	.463
7	.583	.6001			.4801	.463
8	.5316	.6173	.6001		.5316	.5487
9	.5316	.5658			.6173	.5487
10	.4801	.6001		.6001	.6001	.5487
11	.4801	.5144		.5316	.4458	.5144
12	.4458	.4458	.4458	.4973	.4458	.463
13	.4287	.463		.4458	.4287	.4458
14	.5144	.4458		.463		.4458
15	.4115	.4458	.4458	.463	.4115	.463
16	.3772	.3772		.4458	.4115	.4458
17	.3944	.4458	.463	.4115	.3601	.463
18	.4458	.4458		.5415	.463	.4801
19	.5792	.5658		.5487	.5487	
20	.5658	.6516		.5658	.583	
21	.6001	.6516		.6344	.6344	
22	.6878	.6859		.6859	.6344	
23	.6516			.6173	.6001	
24	.4801	.5487	.6173		.583	.583
Max	.6878	.6859	.6173	.6859	.6344	.583
Min	.3772	.3772	.4458	.4115	.3601	.4458
Avg	.5065	.5412	.5144	.5323	.5092	.4801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

LOKMANYA NAGAR[591] BU 4591

Substation No/ Name :- 283110 / 22/11 kv Akruti Substation

Feeder No / Name : 206 / BHAITHI COLONY SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8596	.985			.8954	.9134
2	.8775	.985			.8954	.9134
3	.8954	.985			.8954	.9134
4	.9134	.9671			.9134	.9134
5	.9313	1.0029			.9492	.9134
6	.985	1.0208			.9671	.9134
7	1.0029	1.0387			.9671	.9134
8	1.0029	1.0745	.985		.985	.9313
9	1.0387	.9492			1.0029	.9492
10	.8954	1.0029		1.0029	.9671	.9313
11	.8417	.9492		.9671	1.0029	.985
12	.8954	.8954	.8954	.9671	.8954	.9313
13	.8775	.8954		.8954	.8596	.9134
14	.788	.8954		.8417	.8417	.8954
15	.8059	.8954	.8059	.788	.8238	.9313
16	.8417	.8059		.788	.8238	.9492
17	.8238	.9134	.8417	.8059	.8775	.985
18	.9313	.9134		.8954	.985	1.0029
19	1.0208	1.0745		1.0387	1.0387	
20	1.1283	1.1641		1.0566	1.1283	
21	1.1462	1.182		1.0745	1.0924	
22	1.1641	1.1283		1.0745	1.1104	
23	1.1462			1.0387	1.0745	
24	.8954	1.0029	1.0745		.9671	.9671
Max	1.1641	1.182	1.0745	1.0745	1.1283	1.0029
Min	.788	.8059	.8059	.788	.8238	.8954
Avg	.9462	.9881	.9205	.9453	.9566	.9351

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283076 / 22/22 KV WAGLE ETATE

SWITCHING

Feeder No / Name : 301 / Feeder No I

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.7723	4.5268	4.1495	3.9609	3.5837	3.7723	3.7723
2	3.7723	4.5268	4.1495	3.7723	3.5837	3.7723	3.5837
3	3.7723	4.5268	4.1495	3.7723	3.5837	3.7723	3.5837
4	3.7723	4.5268	4.1495	3.7723	3.5837	3.5837	3.5837
5	3.7723	4.5268	4.1495	3.7723	3.5837	3.5837	3.5837
6	3.7723	4.5268	4.1495	3.7723	3.5837	3.5837	3.5837
7		4.7154	4.3381	3.9609	3.5837	3.5837	3.9609
8	5.0926	5.4698	5.2812	3.9609	3.9609	3.9609	4.7154
9	6.6015	6.7901	6.7901	3.9609	4.904	4.7154	6.7901
10	7.7332	8.2991		4.1495	6.0357	5.4698	7.9218
11	8.1104	8.8649	8.4877	3.9609	6.0357	5.6584	7.7332
12	8.6763	8.6763	7.7332	3.7723	6.0357	6.0357	7.5446
13	6.7901	6.9787	6.0357	3.7723	4.904	4.904	6.4129
14	7.7332	7.5446	7.1674	3.5837	5.6584	5.2812	7.1674
15	7.5446	7.7332	7.1674	3.3951	5.4698	5.2812	7.1674
16	8.2991	7.5446	6.7901	3.3951	5.4698	5.0926	6.9787
17	7.9218	5.2812	6.9787	3.3951	5.6584	4.7154	6.7901
18	7.7332	7.1674	6.7901	3.3951	5.4698	4.904	6.4129
19	7.356	6.0357	6.2243	3.7723	5.2812	5.0926	6.6015
20	6.2243	6.0357	6.0357	3.9609	5.2812	4.904	6.0357
21	5.6584	4.7154	4.904	3.7723	4.5268	4.3381	4.3381
22	5.4698	5.0926	4.904	3.9609	4.3381	4.5268	4.7154
23	5.0926	4.7154	4.904	3.7723	4.3381	4.3381	4.5268
24	3.9609	4.5268	4.1495	4.1495	3.5837	3.9609	3.9609
Max	8.6763	8.8649	8.4877	4.1495	6.0357	6.0357	7.9218
Min	3.7723	4.5268	4.1495	3.3951	3.5837	3.5837	3.5837
Avg	6.0275	5.9728	5.6338	3.7880	4.6682	4.5346	5.4777

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283076 / 22/22 KV WAGLE ETATE

SWITCHING

Feeder No / Name : 302 / Feeder No -II

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6975	1.6975	1.8861	1.8861	1.6975	1.6975	1.8861
2	1.6975	1.5089	1.5089	1.6975	1.5089	1.6975	1.6975
3	1.6975	1.5089	1.5089	1.6975	1.5089	1.6975	1.6975
4	1.6975	1.3203	1.5089	1.6975	1.5089	1.5089	1.6975
5	1.6975	1.3203	1.5089	1.6975	1.5089	1.5089	1.6975
6	1.713	1.3203	1.5089	1.6975	1.5089	1.5089	1.6975
7	1.5089	1.3203	1.6975	1.5089	1.5089	1.6975	1.6975
8	2.2634	2.0748	2.2634	1.5089	1.6975	1.8861	2.2634
9	3.0178	2.8292	3.0178	1.5089	2.2634	1.8861	3.2065
10	3.3951	3.5837		1.5089	2.8292	2.2634	3.7723
11	3.7723	3.5837	3.9609	1.6975	3.2065	2.2634	3.9609
12	3.0178	3.5837	3.6008	1.6975	3.0178	2.452	3.9609
13	3.7723	3.3951	3.9609	1.5089	2.6406	2.452	3.7723
14	3.5837	3.3951	3.7723	1.5089	2.8292	2.452	3.9609
15	3.3951		3.7723	1.5089	2.6406	2.2634	3.7723
16	3.3951	3.5837	3.7723	1.5089	2.6406	2.2634	3.9609
17	3.3951	3.5837	3.7723	1.3203	2.6406	2.2634	3.7723
18	2.8292	3.3951	3.3951	1.5089	2.452	1.8861	3.0178
19	2.452	2.8292	2.8292	1.5089	2.2634	1.8861	3.0178
20	1.8861	2.452	2.6406	1.5089	2.0748	1.8861	2.2634
21	1.8861		2.452	1.6975	1.8861	1.6975	2.0748
22	1.6975	2.0748	2.0748	1.6975	1.8861	1.6975	1.6975
23	1.6975	2.2634	2.0748	1.6975	1.8861	1.6975	2.0748
24	1.8861	1.6975	2.0748	2.0748	1.6975	1.6975	1.8861
Max	3.7723	3.5837	3.9609	2.0748	3.2065	2.452	3.9609
Min	1.5089	1.3203	1.5089	1.3203	1.5089	1.5089	1.6975
Avg	2.4605	2.4691	2.6331	1.6189	2.1376	1.9254	2.6878

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283076 / 22/22 KV WAGLE ETATE

SWITCHING

Feeder No / Name : 305 / Feeder No V

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8861	2.2634	3.7722	1.8861	1.8861	1.8861	1.8861
2	1.8861	2.2634	3.7722	1.8861	1.8861	1.8861	1.8861
3	1.8861	2.2634	1.8861	1.8861	1.8861	1.8861	1.8861
4	1.8861	2.2634	1.8861	1.8861	1.8861	1.8861	1.8861
5	1.8861	2.2634	1.8861	1.8861	1.8861	1.8861	1.8861
6	2.0748	2.2634	1.8861	1.8861	1.8861	1.8861	2.0748
7	1.6975	2.2634	1.8861	1.8861	1.8861	1.8861	2.2634
8	2.0748	2.6406	2.452	1.8861	2.2634	2.452	2.452
9	3.2065	3.3951	3.0178	1.8861	2.6406	2.6406	3.3951
10	3.7723	4.1495	3.0178	1.8861	2.8292	2.8292	3.7723
11		4.1495	3.7723	1.8861	3.0178	3.0178	4.1495
12	3.3951	4.1495	3.7723	1.8861	2.8292	3.0178	3.9609
13	3.3951	3.2065	3.0178	1.8861	2.452	2.452	3.2065
14	4.1495	7.5446	3.5837	1.6975	3.2065	3.0178	3.7723
15	3.7723		3.3951	1.8861	2.6406	2.6406	3.9609
16	3.9609	3.9609	3.3951	1.6975	2.6406	2.452	3.7723
17	3.7723		3.3951	1.6975	2.6406	2.452	3.0178
18	3.3951	3.0178	3.3951	1.8861	2.8292	2.6406	3.0178
19	3.0178	2.8292	3.0178	1.8861	2.6406	3.0178	3.0178
20	5.2812	2.6406	2.8292	1.8861	2.452	2.6406	2.6406
21	2.452	2.2634	2.6406	1.8861	2.452	2.6406	3.0178
22	2.6406	2.452	2.2634	1.8861	2.0748	2.452	2.2634
23	2.2634	2.0748	2.2634	1.8861	1.8861	2.2634	2.2634
24	1.8861	2.2634	2.0748	2.0748	1.8861	1.8861	2.0748
Max	5.2812	7.5446	3.7723	2.0748	3.2065	3.0178	4.1495
Min	1.6975	2.0748	1.8861	1.6975	1.8861	1.8861	1.8861
Avg	2.8538	3.0264	2.8449	1.8704	2.3577	2.4048	2.8135

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283076 / 22/22 KV WAGLE ETATE

SWITCHING

Feeder No / Name : 310 / Feeder No IV

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1317	.9431	.9431	.7545	1.1317	.9431
2		.9431	.9431	.9431	.7545	.9431	.7545
3		.9431	.9431	.9431	.7545	.9431	.7545
4		.9431	.9431	.9431	.7545	.9431	.7545
5		.9431	.9431	.9431	.7545	.9431	.7545
6		.9431	.9431	.9431	.7545	.9431	.7545
7		.9431	1.1317	.7545	.7545	1.1317	.9431
8		1.1317	1.1317	.7545	1.3203	1.1317	1.1317
9		2.0748	1.8861	.7545	1.5089	1.3203	1.5089
10		1.8861		.7545	1.5089	1.3203	1.8861
11		2.2634	2.0748	.7545	1.5089	1.6975	1.8861
12		1.8861	1.8861	.7545	1.5089	1.3203	1.8861
13		1.6975	1.8861	.7545	1.1317	1.1317	1.5089
14		1.5089	1.5089	.7545	1.5089	1.1317	1.6975
15	2.0748	1.8861	1.5089	.7545	1.1317	1.1317	1.5089
16	2.0748	1.8861	1.5089	.7545	1.3203	1.1317	1.6975
17	1.8861	2.2634	1.8861	.7545	1.5089	1.3203	1.5089
18	1.6975	1.6975	1.6975	.7545	1.3203	1.1317	1.5089
19	1.5089	1.8861	1.6975	.7545	1.3203	1.3203	1.3203
20	1.3203	1.3203	1.3203	.7545	1.5089	1.3203	1.3203
21	1.5089		1.3203	.7545	1.1317	1.3203	1.1317
22	1.1317	1.1317	1.1317	.7545	1.1317	.9431	.9431
23	1.1317	1.1317	1.1317	.7545	.9431	.9431	1.1317
24		1.1317	.9431	1.1317	.7545	1.1317	.9431
Max	2.0748	2.2634	2.0748	1.1317	1.5089	1.6975	1.8861
Min	1.1317	.9431	.9431	.7545	.7545	.9431	.7545
Avg	1.5927	1.4597	1.3613	.8174	1.1396	1.1553	1.2574

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283076 / 22/22 KV WAGLE ETATE

SWITCHING

Feeder No / Name : 320 / Kisan Nagar-2 Incomer to NON SHEDDABLE EXPRESS HV FEEDERS
Kisan Feeder KV- 22 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8861	2.2634	2.2634	2.2634	2.2634	2.2634	2.0748
2	1.6975	2.0748	2.0748	2.0748	2.0748	2.2634	1.8861
3	1.6975	2.0748	2.0748	1.8861	2.0748	2.0748	1.6975
4	1.6975	2.0748	2.0748	1.8861	2.0748	2.0748	1.6975
5	1.6975	2.0748	2.0748	1.8861	1.8861	2.0748	1.6975
6	1.6975	2.0748	2.0748	1.8861	1.8861	1.8861	1.8861
7	1.8861	2.0748	2.0748	2.0748	1.8861	1.8861	1.8861
8	2.0748	2.2634	2.2634	2.0748	2.0748	2.0748	2.0748
9	2.452	2.452	2.452	2.2634	2.452	2.2634	2.452
10	2.6406	2.8292		2.2634	2.6406	2.2634	2.6406
11	2.452	2.8292	2.6406	2.2634	2.452	2.2634	2.6406
12	2.452	2.6406	2.8292	2.0748	2.452	2.2634	2.6406
13	2.2634	2.2634	2.452	2.0748	2.2634	2.2634	2.2634
14	2.2634	2.452	2.452	1.8861	2.2634	2.0748	2.2634
15	2.2634		2.452	1.8861	2.2634	1.8861	2.2634
16	2.2634	2.2634	2.452	1.6975	2.0748	1.8861	2.2634
17	2.2634		2.452	1.8861	2.0748	1.8861	2.2634
18	2.2634	2.452	2.2634	1.8861	2.0748	2.0748	2.2634
19	2.452	2.452	2.452	2.2634	2.6406	2.2634	2.6406
20	2.6406	2.8292	2.8292	2.452	2.6406	2.6406	2.8292
21	2.6406	2.452	2.8292	2.452	2.6406	2.452	2.452
22	2.452	2.6406	2.6406	2.452	2.452	2.452	2.452
23	2.452	2.452	2.6406	2.452	2.452	2.452	2.452
24	2.0748	2.2634	2.452	2.452	2.2634	2.2634	2.2634
Max	2.6406	2.8292	2.8292	2.452	2.6406	2.6406	2.8292
Min	1.6975	2.0748	2.0748	1.6975	1.8861	1.8861	1.6975
Avg	2.1926	2.3748	2.4028	2.1141	2.2634	2.1769	2.2477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283077 / 22 /11KV WAGLE ESTATE S/S

Feeder No / Name : 202 / NEW RAM GOPAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1509	.1698	.1509	.1509	.1509	
2	.1509	.1509	.1509	.1509	.1509	.1509	
3		.1509					
4		.1509					
6			.1509				.1509
7			.1509				.1509
8	.1698	.1886	.1509		.1698		.1886
9	.1886	.1886	.2263		.1886	.1886	.2263
10	.3772	.3772		.1509	.2452	.2263	.3584
11	.3772	.3772	.4527	.1509	.2829	.2075	.415
12	.3772	.4338	.3961	.1509	.2263	.2263	.3961
13	.3395	.3772	.3395	.1509	.2829	.2263	.3395
14	.3772	.415	.3584		.2263	.1886	.3584
15	.3772	.4338	.3772		.2452	.1698	.3772
16	.3961	.415	.3395		.2263	.1509	.3961
17	.415	.3206	.3772		.2263	.1509	.3961
18	.3772	.2452	.2263		.2263	.1886	.2829
19	.2641	.2829	.2641	.1509	.2263	.1886	.2641
20	.2452	.2829	.2452	.1509	.2263	.1886	.2452
21	.2452	.2829	.2263	.1886	.2075	.1886	.2263
22		.1886	.1886	.1698	.1886	.1886	.1886
23	.1886	.1886	.1698	.1698	.1886	.1886	.1698
24	.1509	.1698	.1886	.1698	.1509	.1698	.1698
Max	.415	.4338	.4527	.1886	.2829	.2263	.415
Min	.1509	.1509	.1509	.1509	.1509	.1509	.1509
Avg	.2871	.2748	.2575	.1588	.2124	.1855	.2790

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283077 / 22 /11KV WAGLE ESTATE S/S

Feeder No / Name : 203 / JAI MAHARASHTRA NAGAR
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0374	1.1317	1.1317	1.226	1.0374	1.0374	1.1317
2	1.0374	1.0374	1.1317	1.226	1.0374	1.0374	1.0374
3	1.0374	1.0374		1.226	1.0374	1.0374	1.0374
4	1.0374	1.0374	1.1317	1.226	1.0374	1.0374	1.0374
5	1.0374	1.0374	1.1317	1.226	1.0374	1.0374	1.0374
6	1.1317	1.0374	1.1317	1.226	1.0374	1.0374	1.0374
7	1.226	.9431	1.1317	1.0374	1.0374	1.0374	1.1317
8	1.226	1.226	1.3203	1.0374	1.0374	1.1317	1.3203
9	1.8861	1.8861	1.7918	1.1317	1.4146		1.9805
10	2.2634	2.6406		1.0374	1.6975	1.3203	2.452
11	2.3577	2.7349		1.0374	1.6975	1.5089	2.5463
12	2.3577	2.452		1.1317	1.6975	1.6032	2.7349
13	2.1691	2.0748		1.0374	1.5089	1.3203	2.0748
14	2.2634	2.1691		.9431	1.6032	1.4146	2.1691
15	2.1691	2.452		1.0374	1.5089	1.4146	2.0748
16	2.2634	2.2634		.9431	1.4146	1.3203	2.6406
17	2.1691	2.1691	2.0748	.9431	1.5089	1.4146	2.2634
18	1.9805	1.8861	1.6032	.9431	1.4146	1.226	1.6975
19	1.6975	1.5089	1.5089	1.0374		1.3203	1.4146
20	1.3203	1.5089	1.3203	1.1317	1.3203	1.3203	1.3203
21	1.3203	1.226	1.3203	1.1317	1.1317	1.3203	1.226
22	1.226	1.226	1.6975	1.1317	1.1317	1.3203	1.226
23	1.226	1.226	1.3203	1.0374	1.1317	1.3203	1.1317
24	1.0374	1.1317	1.3203	1.3203	1.0374	1.0374	1.226
Max	2.3577	2.7349	2.0748	1.3203	1.6975	1.6032	2.7349
Min	1.0374	.9431	1.1317	.9431	1.0374	1.0374	1.0374
Avg	1.6032	1.6268	1.3792	1.1003	1.2834	1.2424	1.6229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283077 / 22 /11KV WAGLE ESTATE S/S

Feeder No / Name : 205 / RAILADEVI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	.6602	.7545	.6602	.6602	.7545	.6602
2	.6602	.6602	.7545	.6602	.6602	.6602	.6602
3	.6602	.6602		.6602	.6602	.6602	.6602
4	.6602	.6602	.6602	.6602	.6602	.6602	.6602
5	.6602	.6602	.6602	.6602	.6602	.6602	.6602
6	.6602	.6602	.6602		.6602	.6602	.6602
7	.6602	.6602	.7545	.6602	.6602	.6602	.6602
8	.7545	.8488	.9431	.6602	.6602	.6602	.7545
9	1.1317	1.226	1.1317	.6602	.8488	.7545	1.1317
10	1.6032	1.6032		.6602	1.1317	.8488	1.5089
11	1.6975	1.7918	1.8861	.6602	1.1317	.9431	1.6032
12	1.6975	1.6975	1.7147	.6602	1.1317	.9431	1.6032
13	1.4146	1.4146	1.5089	.6602	.9431	.7545	1.3203
14	1.6032	1.6975	1.5089	.6602	1.0374	.8488	1.4146
15	1.6975	1.7918	1.7918	.6602	1.0374	.9431	1.6032
16	1.5089	1.6975	1.6975	.6602	1.0374	.8488	1.6032
17	1.5089	1.6975	1.6975	.6602	1.0374	.8488	1.5089
18	1.4146	1.5089	1.4146	.6602	.9431	.8488	1.226
19	1.1317	1.226	1.1317	.6602	.9431	.8488	1.226
20	1.0374	1.0374	.9431	.6602	.9431	.8488	1.0374
21	.7545	.7545	.8488	.6602	.7545	.8488	.8488
22	.7545	.8488	.7545	.4715	.7545	.7545	.7545
23	.6602	.7545	.7545	.6602	.7545	.7545	.7545
24	.6602	.6602	.7545	.6602	.6602	.7545	.6602
Max	1.6975	1.7918	1.8861	.6602	1.1317	.9431	1.6032
Min	.6602	.6602	.6602	.4715	.6602	.6602	.6602
Avg	1.0688	1.1199	1.1239	.6520	.8488	.7820	1.0492

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283083 / 22/11KV Ramnagar Substation

Feeder No / Name : 202 / 11KV Hanuman Nagar SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.811			.7545
2			.7733			.7545
3			.7545			.7167
4			.7356			.7356
5			.7167			.7356
6			.7545	.6413		.7545
7			.7545	.6979		.7922
8			.679			.8488
9	.9088	.9808	.6602		1.0185	.8745
10	.9945	1.3769	.6602		1.1883	1.166
11	1.0117	1.3769	.679		1.2826	1.2174
12	.8916	1.3957	.6224		1.3014	1.1831
13	.9088	.9808	.6224		.8865	.9088
14	.9945	1.3203	.6036		1.226	1.2346
15	1.1831	1.2826	.6036		1.226	1.166
16	1.2003	1.3203	.5847		1.226	1.3375
17	1.0631	1.3392	.6224		1.0751	1.2346
18	1.0802	1.1883	.6224		1.1506	
19	1.0117	1.1694	.6036		1.1317	
20	.8916	1.2071	.6413		.9997	
21		.9619	.6602		.9242	
22		.8865	.6602		.8865	
23		.8488	.6602			
24			.811	.6413		.7922
Max	1.2003	1.3957	.811	.6979	1.3014	1.3375
Min	.8916	.8488	.5847	.6413	.8865	.7167
Avg	1.0117	1.1757	.6790	.6602	1.1088	.9560

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283083 / 22/11KV Ramnagar Substation

Feeder No / Name : 203 / 11KV TMT Depo

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.415			.3961
2			.415			.3961
3			.3961			.3772
4			.415			.3772
5			.3961			.3584
6			.3961	.3584		.3772
7			.3961	.3772		.3772
8			.3772			.415
9	.4115	.4904	.3961		.4527	.4287
10	.4801	.5658	.415		.4715	.4801
11	.5144	.6413	.3772		.4904	.5316
12	.4801	.1886	.3772		.547	.5144
13	.5487	.1886	.3772		.4338	.5144
14	.6001	.1886	.3772		.4904	.5144
15	.6173	.4715	.3584		.5093	.5144
16	.5144	.6413	.3395		.4904	.5316
17	.4287	.6036	.3584		.5093	.5487
18	.463	.6036	.1509		.4338	
19	.4287	.5093	.415		.4715	
20	.4115	.5281	.4338		.4715	
21		.4715	.415		.4527	
22		.4715	.4338		.4527	
23		.4527	.415			
24			.4338	.3961		.415
Max	.6173	.6413	.4338	.3961	.547	.5487
Min	.4115	.1886	.1509	.3584	.4338	.3584
Avg	.4915	.4678	.3867	.3772	.4769	.4482

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283083 / 22/11KV Ramnagar Substation

Feeder No / Name : 204 / NSIL-HT

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER MIDC EQUIVALENT

HAVING WEEKLY STAGGERING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9		.4115	.2829		.2743
10	.3258	.4115	.4904	.1698	.463
11	.3601	.4115	.415	.1698	.4458
12	.3086	.2743	.3395	.1698	.3086
13	.3429	.3086	.3772		.3258
14	.3086	.2915	.3395		.3772
15	.3258	.2743	.3018		.3429
16	.3429	.2915	.3772		.2915
17		.3086	.3772		.3258
18			.3395		
19			.2075		
20			.1886		
21			.1698		
Max	.3601	.4115	.4904	.1698	.463
Min	.3086	.2743	.1698	.1698	.2743
Avg	.3307	.3315	.3235	.1698	.3505

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283083 / 22/11KV Ramnagar Substation

Feeder No / Name : 205 / I-THINK IT Park-1 SHEDDABLE FEEDER MIDC EQUIVALENT
Feeder KV- 11 / OUTGOING HAVING WEEKLY STAGGERING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	.1543	.1715	.1698	.1543
11	.1715	.1886	.2075	.1715
12	.1886	.1715	.2075	.1715
13	.1886	.1715	.1886	.1715
14	.1886	.1715	.1886	.1886
15	.1886		.2075	.1886
16	.1886		.2075	.1715
17	.1715		.2075	.1715
18	.1715		.1886	
Max	.1886	.1886	.2075	.1886
Min	.1543	.1715	.1698	.1543
Avg	.1791	.1749	.1970	.1736

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283099 / 22/22KV Ashar IT Park

Switchin

Feeder No / Name : 301 / 22KV Sathenagar Feeder

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.5837	2.452	2.452	2.4897	2.452	2.452	2.2634
2	3.3951	2.452	2.452	2.4143	2.452	2.452	2.2634
3	3.3951	2.452	2.452	2.3388	2.2634	2.452	2.2634
4	3.2065	2.452	2.452	2.3388	2.2634	2.2634	2.2634
5	3.0178	2.452	2.2634	2.2634	2.0748	2.2634	2.2634
6	3.0178	2.452	2.2634	2.2634	2.0748	2.2634	2.2634
7	3.0178	2.452	2.2634	2.1879	2.0748	2.2634	2.2634
8	3.5837	2.452	2.6406	2.3765	2.0748	2.0748	2.6406
9	4.7154	3.0178	3.2065	2.4143	2.452	2.6406	3.2065
10	5.2812	3.5837	3.6591	2.452	2.8292	2.8292	3.7723
11	5.4698	3.5837	3.5837	2.2634	3.0178	3.0178	3.5837
12	5.4698	3.5837	3.5837	2.2634	3.0178	2.8292	3.5837
13	4.904	3.5837	3.2065	2.0748	2.6406	2.8292	3.2065
14	5.2812		3.2065	2.0748	2.8292	2.8292	3.3951
15	3.3951	3.3951	3.3951	1.8861	3.0178	2.6406	3.2065
16	3.2065	3.3951	3.2065	1.8861	2.8292	2.8292	3.2065
17	3.2065	3.3951	3.3951	1.8861	2.6406	2.6406	3.3951
18	3.2065	3.3951	3.2442	2.0748	2.8292	2.6406	3.2065
19	3.2065	3.2065	2.7161	2.2634	2.6406	2.8292	3.0178
20	3.2065	3.3951	3.1687	2.452	2.8292	3.0178	2.8292
21	2.8292	3.2065	2.4897	2.6406	2.6406	3.0178	2.8292
22	2.8292	2.8292	2.9047	2.6406	2.6406	3.0178	2.8292
23	2.6406	2.8292	2.7915	2.6406	2.6406	3.0178	2.6406
24	3.7723	2.6406	2.6406	2.6029	2.6406	2.6406	2.8292
Max	5.4698	3.5837	3.6591	2.6406	3.0178	3.0178	3.7723
Min	2.6406	2.452	2.2634	1.8861	2.0748	2.0748	2.2634
Avg	3.7016	2.9850	2.9015	2.2995	2.5777	2.6563	2.8843

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

BHANDUP (U) ZONE[053]

THANE (U) CIRCLE[539]

WAGLE ESTATE DIVISION[409]

WAGLE ESTATE S/DN.[542] BU 4542

Substation No/ Name :- 283099 / 22/22KV Ashar IT Park

Switchin

Feeder No / Name : 303 / Ashir IT complex feeder

SHEDDABLE FEEDER HAVING WEEKLY

Feeder KV- 22 / OUTGOING

STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3203	.9431	1.1317	1.1694	1.3203	.9431	.9431
2	1.3203	.9431	1.1317	1.1317	1.3203	.9431	.9431
3	1.1317	.9431	1.1317	1.0562	1.1317	.9431	.9431
4	1.1317	.9431	1.1317	.9808	1.1317	.9431	.7545
5	.9431	.9431	1.1317	.9808	.9431	.9431	.7545
6	.9431	.9431	1.1317	.9808	1.1317	.9431	.7545
7	1.1317	.9431	1.1317	.9054	1.1317	.9431	.9431
8	1.1317	1.1317	1.3203	1.0185	1.1317	.9431	1.1317
9	2.0748	2.2634	2.0748	1.4712	1.5089	1.4335	2.0748
10	2.6406	2.6406	2.6029	1.8107	1.8861	1.5089	2.6406
11	2.6406	2.6406	2.7538	1.5089	1.8861	1.6975	2.6406
12	2.6406	2.8292	2.8669	1.3203	1.8861	1.5089	2.6406
13	2.6406	2.6406	2.5652	1.3203	1.8861	1.5089	2.452
14	2.6406	2.6406	2.8292	1.3203	1.8861	1.5089	2.8292
15	2.8292	2.8292	2.8292	1.3203	1.8861	1.5089	2.6406
16	3.0178	3.0178	3.0178	1.3203	1.8861	1.5089	2.6406
17	3.0178	3.0178	2.9424	1.3203	1.6975	1.3203	2.452
18	2.6406	3.0178	2.7538	1.3203	1.6975	1.3203	2.2634
19	2.2634	2.2634	2.2634	1.3203	1.5089	1.1317	2.0748
20	1.8861	2.0748	1.6975	1.3203	1.3203	1.1317	1.6975
21	1.5089	1.6975	1.6221	1.3203	1.1317	1.1317	1.6975
22	1.5089	1.5089	1.5089	1.3203	1.1317	1.1317	1.5089
23	1.3203	1.3203	1.3957	1.3203	1.1317	1.1317	1.3203
24	1.3203	1.1317	1.3203	1.2071	1.3203	1.1317	1.1317
Max	3.0178	3.0178	3.0178	1.8107	1.8861	1.6975	2.8292
Min	.9431	.9431	1.1317	.9054	.9431	.9431	.7545
Avg	1.9019	1.8862	1.9286	1.2527	1.4539	1.215	1.7447