

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. EAST S/DN.[155] BU 4359

Substation No/ Name :- 283078 / 22/22 KV JUCHANDRA SW/ST.

Feeder No / Name : 301 / 22KV PERERA FEEDER

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5238		1.9387	1.8625	1.6644	1.8625	
2	1.4529		1.829	1.7909	1.7002	1.7193	
3	1.4175		1.829	1.701	1.4563	1.701	2.0416
4	1.4175		1.8099	1.6301	1.4175	1.5947	1.701
5	1.4529		1.6827	1.5424	1.448	1.5592	
6	1.4175		1.6651	1.6126	1.4937	1.4883	
7	1.4529		1.5203	1.6476	1.4883	1.4373	1.9631
8	1.387		1.5203	1.491	1.6095	1.4723	1.7528
9	1.3523		1.5043	1.5604	1.5203	1.4723	1.6118
10	1.4217		1.4883	1.6297	1.7193	1.5074	1.4723
11	.1387		1.5364	1.5257	1.5074	1.5074	
12			1.4217	1.5592	1.4723	1.4373	1.7833
13	1.4175		1.4217	1.4883	1.406	1.4403	1.5775
14	1.3969	1.4563	1.3672		1.3375	1.4022	1.4243
15	1.3176		1.4217	1.3466	1.3032	1.4022	1.3717
16	1.382	1.3717	1.4217	1.382	1.3321	1.4723	1.2346
17	1.4266	1.4403	1.5074	1.3176	1.4723	1.4746	1.3466
18	1.2894	1.3565	1.3717	1.5684	1.4327	1.4373	1.4685
19	1.701	1.5424	1.5424	1.6632	1.7375	1.7528	1.829
20	1.8781	1.9342	1.9136	1.8427	1.97	1.8983	1.9022
21	1.949		2.0058	1.885	1.97	1.9909	2.0119
22	1.9418	2.0416	2.0774	1.9342	1.9547	2.0271	1.9909
23		1.9753	2.1132	1.9136	1.97	1.97	1.9022
24	1.6301	1.7684	1.9387	1.97	1.7909	1.8983	1.7909
Max	1.949	2.0416	2.1132	1.97	1.97	2.0271	2.0416
Min	.1387	1.3565	1.3672	1.3176	1.3032	1.4022	1.2346
Avg	1.4439	1.6541	1.6603	1.6463	1.5906	1.6219	1.6935

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. EAST S/DN.[155] BU 4359

Substation No/ Name :- 283078 / 22/22 KV JUCHANDRA SW/ST.

Feeder No / Name : 302 / 22KV JUCHANDRA FEEDER

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1458		1.5684	1.4045	1.134	1.3443	
2	1.1088		1.5684	1.3306	1.0402	1.2567	
3	1.0719		1.4937	1.2803	1.0402	1.2567	1.4045
4	1.1088		1.4937	1.3169	1.134	1.2803	1.2437
5	1.1088		1.419	1.2308	1.2803	1.2936	
6	1.1827		1.419	1.267	1.3443	1.2936	
7	1.2197		1.3443	1.3394	1.307	1.3169	1.6095
8	1.1706		1.3443	1.3169	1.2567	1.2803	1.4632
9	1.1706		1.1827	1.0387	1.1827	1.2803	1.4415
10	1.0974		1.0498	1.1584	1.1706	1.1706	
11	1.0631		1.086	1.0402	1.0974	1.1706	
12	.9709		1.0498	.9709	.9145	1.134	1.2757
13	.9671		1.0136	.9568	1.0242	1.0029	1.2048
14	1.0029	1.2894	.9774	.9709	1.0242	1.0608	1.134
15	.9015		1.0136	.8505	1.0242	1.0242	1.1104
16	.9568	1.267	.9774	.8669	.9145	1.0242	1.1584
17	.9922	1.2048	1.0242	.8669	1.0349	1.0498	1.1706
18	.9568	1.1462	1.0136	.9015	.9979	1.0608	1.1827
19	1.2048	1.3032	1.134	1.0745	1.2696	1.2437	1.4563
20	1.3611	1.5364	1.4415	1.2936	1.419	1.4784	1.4563
21	1.4175		1.3306	1.2757	1.419	1.5154	1.4937
22	1.4327	1.6095	1.5364	1.3676	1.419	1.4415	1.3443
23	1.2483	1.5432	1.6263	1.3676	1.419	1.4415	1.3817
24	1.2936	1.2483	1.5684	1.4632	1.2567	1.3676	1.3676
Max	1.4327	1.6095	1.6263	1.4632	1.419	1.5154	1.6095
Min	.9015	1.1462	.9774	.8505	.9145	1.0029	1.1104
Avg	1.1314	1.3498	1.2782	1.1646	1.1718	1.2412	1.3277

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. EAST S/DN.[155] BU 4359

Substation No/ Name :- 283078 / 22/22 KV JUCHANDRA SW/ST.

Feeder No / Name : 303 / 22KV BAPANE FEEDER

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6118		1.8625	1.419	3.0678	1.7909	
2	1.576		1.8267	1.3756	2.9874	1.6834	
3	1.576		1.7909	1.3672	2.9767	1.6476	
4	1.5402		1.7193	1.3672	3.083	1.6834	
5	1.5402		1.7193	1.3672	3.2217	1.7193	
6	1.576		1.7013	1.3672	3.2922	1.8267	
7	1.6118		1.6834	1.4415	3.4019	1.3169	
8	1.7372		1.8625	1.2929	3.6595	1.97	
9	1.6834		1.9521	1.3672	3.8009	2.1491	
10	2.3461		2.364	1.4118	2.7286	2.2725	
11	4.6201		1.9067	3.1207	2.2207	2.0005	
12	4.4353		1.8519	2.7641	2.3102	1.9204	
13	3.9179		1.6636	2.7995	2.1491	1.9204	1.4327
14	4.1907	1.8446	1.9033		2.0774	1.7284	1.3969
15	4.5359		1.8046	2.6699	2.4356	1.9845	1.4685
16	4.5725	1.2894	1.5508	2.7286	2.3282	2.0485	2.1849
17	4.1907	1.2536	1.9258	2.6223	2.2923	1.6964	2.1849
18	4.0569	1.6118	1.5493	2.9729	2.1491	1.7604	2.1849
19	3.7449	2.5072	1.8244	2.9412	2.3461	1.9204	2.4177
20	4.513	2.8654	2.0127	3.65	2.2028	2.0645	2.2565
21	4.4296		1.8244	3.5482	2.2565	1.9204	2.364
22	4.2798	2.3282	1.8244	3.4743	2.1491	1.8884	2.2565
23		2.0595	1.6796	3.2526	1.97	1.8023	1.9163
24	1.7013	3.3311	1.8625	1.6217	3.1417	1.8804	1.7368
Max	4.6201	3.3311	2.364	3.65	3.8009	2.2725	2.4177
Min	1.5402	1.2536	1.5493	1.2929	1.97	1.3169	1.3969
Avg	3.0429	2.1212	1.8194	2.2584	2.6770	1.8582	1.9834

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. EAST S/DN.[155] BU 4359

Substation No/ Name :- 283501 / 22/22 KV AGRAWAL SW/ST

Feeder No / Name : 300 / AGRAWAL SW.ST. CONSUMPTION

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0343	.0343	.0343	.0377		.0343
2	.0377	.0343	.0343	.0343	.0377		.0343
3	.0377	.0343	.0343	.0343	.0377		.0343
4		.0343	.0343	.0343	.0377		.0343
5		.0343		.0343	.0377		.0343
6		.0343		.0343	.0377		.0343
7	.0377	.0343		.0343	.0377		.0343
8	.0377	.0343	.0343	.0343	.0377	.0343	.0343
9		.0377	.0343	.0343	.0377	.0377	.0343
10	.0377	.0377	.0343	.0343		.0377	.0377
11	.0377	.0377	.0343	.0377		.0377	.0377
12	.0377	.0343	.0343	.0377		.0377	.0377
13	.0377	.0377	.0343	.0377		.0377	.0377
14	.0377	.0377	.0343	.0377		.0377	.0377
15	.0377	.0377	.0343	.0377	.0171	.0377	.0377
16	.0377	.0377	.0343	.0377	.0171	.0377	.0377
17	.0377	.0377	.0343	.0377		.0377	.0377
18	.0377		.0343	.0377		.0377	
19	.0343		.0343	.0377		.0343	
20	.0343		.0343	.0377		.0343	
21	.0343		.0343	.0377		.0343	
22	.0343		.0343	.0377		.0343	
23	.0343	.0343	.0343	.0377	.0343	.0343	.0343
24	.0377	.0343	.0343	.0343	.0377	.0343	.0343
Max	.0377	.0377	.0343	.0377	.0377	.0377	.0377
Min	.0343	.0343	.0343	.0343	.0171	.0343	.0343
Avg	.0369	.0357	.0343	.0361	.0343	.0363	.0357

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. EAST S/DN.[155] BU 4359

Substation No/ Name :- 283501 / 22/22 KV AGRAWAL SW/ST

Feeder No / Name : 301 / 22KV HEERA FEEDER

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.5268	3.8409	3.7037	3.8409	1.4712	3.4294	3.4294
2	4.0741	3.7037		3.7037	1.4712	3.2922	3.0178
3	4.0741	3.7037		3.2922	1.3957	3.2922	3.0178
4	3.9232	3.2922		3.2922	1.358	3.155	3.0178
5	3.7723	3.2922	3.2922	3.0178	1.3957	3.2922	3.0178
6	3.8477	3.2922		3.0178	2.2634	3.2236	2.8807
7	3.7723	3.4294		2.8807	1.8484	3.155	3.0178
8	5.8093	4.4582	3.7037	2.1948	2.8669	3.2922	3.4294
9	7.3937	7.6955	6.31	1.9204	6.7901	5.6242	6.1728
10	9.8457	9.808	8.642	1.5432	8.2305	8.4499	9.3176
11	10.6379	10.487	9.6022	1.773	8.5048	9.0912	9.4307
12	10.2229	10.2606	9.3279	1.6221	8.642	9.4307	9.8457
13	7.8087	7.2805	6.8587	1.3957	6.31	6.3375	6.941
14	10.9397	10.5624	8.7792	1.3203	8.5048	8.7894	9.0535
15	10.6379	10.5624	9.0535	2.7161	8.2305	8.6763	9.5439
16	10.5624	10.4115	9.465	1.2449	8.3676	9.0535	9.3553
17	9.7702	10.0343	8.5048	1.2071	7.9561	8.3745	9.0535
18	8.9403	8.0933	7.5446	1.2071	7.1331	7.3937	7.6818
19	7.5446	7.1331	6.5844	1.5466		6.1728	7.1331
20	5.7613	5.2126	5.3498	2.1125	5.0755	4.9383	5.2126
21	4.1838	4.3896	4.2524	2.2634	4.1152	3.7037	4.2524
22	4.1152	4.1152	4.1152	2.2634	3.5665	3.4979	3.8409
23	3.8409	3.9781	3.8409	2.2634	3.7037	3.5665	3.5665
24	4.6776	3.7037	4.1152	3.8409	1.5844	3.7037	3.4294
Max	10.9397	10.5624	9.6022	3.8409	8.642	9.4307	9.8457
Min	3.7723	3.2922	3.2922	1.2071	1.358	3.155	2.8807
Avg	6.6951	6.3642	6.4761	2.3117	4.8168	5.5390	5.7775

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. EAST S/DN.[155] BU 4359

Substation No/ Name :- 283501 / 22/22 KV AGRAWAL SW/ST

Feeder No / Name : 302 / 22KV AGRAWAL FEEDER

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.1303	4.4239		4.8011	2.4143	4.5268	4.4582
2	5.7339	4.5268		4.8011	2.452	4.3896	4.4582
3	4.904	4.5268		4.6639	2.3765	4.5268	5.2126
4	4.6776	4.5268		4.6639	2.3011	4.5268	4.3896
5	4.5268	4.3896	4.1152	4.3896	2.3388	4.6639	4.3896
6	4.904	4.3896		4.3896	2.4897	4.8011	4.4582
7	5.1303	4.8011	4.5268	3.7723	3.2065	4.8011	4.7668
8	7.1296	5.9671		3.2236	4.5268	5.487	4.9383
9	9.2798	10.0343	6.7215	2.9492	8.2236	7.6818	7.2017
10	12.7126	12.7504	6.9959	2.5034	10.6996	12.524	12.26
11	12.7126	14.0707	7.6132	2.9424	10.974	12.524	13.4294
12	13.1276	14.1084	7.3388	2.6029	11.9342	12.9013	12.4109
13	8.9781	6.9662	7.5446	2.3388	7.5446	7.8464	8.6008
14	12.524	12.6749	10.4938	2.6406	10.2881	10.5624	9.0535
15	12.7504	12.9767	10.7682	2.7915	10.5624	11.8073	12.1468
16	12.9013	13.1653	11.797	2.452	11.1111	12.6749	11.845
17	12.3731	13.0144	10.4938	2.3011	10.2881	12.0713	11.3169
18	10.3738	9.8766	9.6708	2.4143	8.9163	9.4307	9.4307
19	8.3676	9.3964	8.3676	2.2634	7.8875	8.5734	8.5734
20	7.4074	8.2305	7.9561	2.5652	6.9959	7.1331	7.2702
21	7.4074	6.1728	6.31	2.6406	5.487	5.5556	6.8587
22	5.4184	5.487	5.487	2.8669	5.0412	5.2126	6.9959
23	4.9383	5.144	5.2126	2.7915	4.8011	4.6639	4.8011
24	5.5076	4.5953	5.0755	5.144	2.6783	4.8011	4.3896
Max	13.1276	14.1084	11.797	5.144	11.9342	12.9013	13.4294
Min	4.5268	4.3896	4.1152	2.2634	2.3011	4.3896	4.3896
Avg	8.2882	8.1757	7.5827	3.2880	6.4808	7.6536	7.6523

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. EAST S/DN.[155] BU 4359

Substation No/ Name :- 283501 / 22/22 KV AGRAWAL SW/ST

Feeder No / Name : 303 / 22KV KAMAN FEEDER

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5089	6.1386		6.5844	4.5268	6.8587	6.4815
2	1.358	5.7613		6.5844	4.8285	6.4472	6.4129
3	1.2071	5.7613		6.31	4.6399	6.1728	6.4129
4	2.2634	5.7613		6.0357	4.5268	6.0357	6.4129
5	5.6584	5.2126	4.8011	5.7613	4.5645	6.0357	6.4129
6	6.1866	5.2126		5.3498	4.5268	5.8985	5.8985
7	6.1866	5.2126		5.3498	4.6399	5.6242	5.8985
8	7.4691	5.7613	6.1728	5.0755	5.4321	5.9671	6.1728
9	9.9589	10.1098	8.3676	4.9383	5.3567	8.7792	9.6708
10	13.9198	12.9767	12.3457	4.5268	6.0357	13.1276	
11	13.1276	14.1084	13.2373	3.7723	11.797	13.0899	13.4294
12	14.9383	14.1084	12.8944	4.7908	12.0713	13.1653	13.2408
13	10.3738	10.1098	9.1221	4.1495	8.5048	10.1852	8.4122
14	13.1653	12.3731	11.2483	3.81	10.8368	12.1091	12.524
15	9.2798	13.5803	11.797	3.7723	11.6598	12.6749	13.0144
16	13.2408	13.7689	12.0713	3.8477	11.1111	13.1276	13.7312
17	13.2785	13.618	11.6598	4.0741	10.5624	12.3731	12.6749
18	12.5617	10.974	11.2483	4.225	10.4253	12.2222	11.9342
19	9.7394	11.1111	10.5624	4.6022	10.4253	10.5624	10.1509
20	9.0535	9.6022	9.7394	5.2812	8.9849	9.5336	9.0535
21	7.8875	8.0247	7.9561	5.583	7.8189	7.8875	8.2305
22	7.0645	6.8587	7.6818	5.4321	7.1331	7.476	6.9959
23	6.9959	6.7215	7.2702	4.9794	6.8587	6.9959	6.9959
24		6.31	6.4472	7.1331	4.9417	6.9959	6.7901
Max	14.9383	14.1084	13.2373	7.1331	12.0713	13.1653	13.7312
Min	1.2071	5.2126	4.8011	3.7723	4.5268	5.6242	5.8985
Avg	8.5401	9.1324	9.7013	5.0820	7.5920	9.1394	8.9979

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. EAST S/DN.[155] BU 4359

Substation No/ Name :- 283501 / 22/22 KV AGRAWAL SW/ST

Feeder No / Name : 304 / 22KV VTIC CHINCHPADA

SHEDDABLE URBAN

FEEDER Feeder KV- 22 /  
OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5652	2.4691	2.6063	2.7435	1.2826	2.1948	2.332
2	2.1948	2.332		2.5377	1.3957	2.0576	2.332
3	2.4143	2.332		2.4006	1.3203	2.0576	2.332
4	2.1948	2.332		2.1948	1.358	2.1948	2.332
5	2.2634	2.1948	2.1948	2.1948	1.2826	2.332	2.332
6	2.332	2.1948	2.4691	2.1948	1.358	2.1948	2.4691
7	3.7723	2.6063	2.4691	2.1948	1.773	2.332	2.7435
8	3.4294	3.0178	2.6063	2.0576	2.1125	2.332	2.7435
9	4.8285	6.0357	4.8011	1.7147	4.6776	4.3896	4.7668
10		7.0542	6.1728	1.5432	5.2126	6.0357	6.9033
11		7.6955	6.7215	1.773	5.3498	6.3375	7.0919
12	7.2428	7.62	6.7215	1.7353	5.6242	5.8848	7.2428
13	5.6584	5.4698	4.9383	1.3957	4.2524	4.6776	4.3759
14	5.6584	7.3937	6.4472	1.5089	5.487	5.8848	6.7901
15	6.7147	6.7901	6.4472	1.358	5.3498	6.0357	6.9033
16	6.9787	7.2805	6.4472	1.6221	5.487	6.0357	6.7901
17	6.8279	6.941	5.8985	1.3203	4.9383	5.6584	6.4883
18	6.8279	5.487	5.487	1.3957	4.5268	5.4321	5.487
19	4.6639	4.8011	4.5268	1.5844	3.7037	4.1152	4.3896
20	4.1152	3.9781	3.7037	1.358	3.2922	3.155	3.5665
21	3.0864	3.0178	3.0178	1.5089	2.7435	2.6063	3.0178
22	2.7435	3.0178	3.155	1.358	2.6063	2.6063	2.6063
23	2.7435	2.7435	2.8807	1.358	2.6063	2.7435	2.6063
24	2.6063	2.7435	2.7435	2.7435	1.358	2.332	2.6063
Max	7.2428	7.6955	6.7215	2.7435	5.6242	6.3375	7.2428
Min	2.1948	2.1948	2.1948	1.3203	1.2826	2.0576	2.332
Avg	4.1756	4.4812	4.4026	1.8248	3.2958	3.8177	4.2187



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. EAST S/DN.[155] BU 4359

Substation No/ Name :- 283501 / 22/22 KV AGRAWAL SW/ST

Feeder No / Name : 305 / 22KV RAYCHEM RPG EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS  
FEEDER Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4115	.3086	.3429	.0377	.1372	.1715
2		.3429		.3429	.0377	.1372	.2058
3		.3429		.2743	.0377	.1372	.2058
4	.3018	.3429		.0343	.0377	.1715	.2401
5	.2263	.3772	.3429	.2058	.0377	.1715	.2401
6	.2641	.3429		.2058	.0377	.1715	.2058
7	.3018	.3772		.1715	.0377	.2058	.2743
8	.3772	.5144	.1715	.1372	.0377	.3086	.3772
9	.5281	.5658	.5487	.1372	.0377	.3429	.4115
10	.679	.6413	.6859	.1372	.0686	.3772	.6036
11	.6036	.7167	.583	.1509	.0686	.4904	.6413
12	.4904	.6036	.6173	.1509	.0686	.5281	.6036
13	.4904	.5658	.5487	.1509	.0686	.3772	.5658
14	.5658	.6036	.6173	.1509	.0686	.4527	.679
15	.5281	.5281	.5144	.0377	.0686	.3772	.6413
16	.5658	.7545	.6173	.0377	.0343	.2401	.5658
17	.6036	.679	.6173	.0377	.0686	.2401	.5658
18	.4904	.5487	.6173	.0377	.0686	.2058	.4801
19	.4458	.5487	.4458	.0377	.0343	.2401	.3429
20	.4458	.4115	.4115	.0377	.0343	.2058	.2743
21	.4115	.4458	.3086	.0377	.0343	.1715	.2743
22	.4115	.3086	.2743	.0377	.0343	.2058	.2743
23	.3429	.3086	.2401	.0377	.0343	.2058	.2401
24			.3086	.2401	.0377	.0343	.2058
Max	.679	.7545	.6859	.3429	.0686	.5281	.679
Min	.2263	.3086	.1715	.0343	.0343	.0343	.1715
Avg	.4537	.4905	.4621	.1322	.0472	.2556	.3871

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. EAST S/DN.[155] BU 4359

Substation No/ Name :- 283502 / 22/22 KV NAVGHAR SW/ST

Feeder No / Name : 300 / NAVGHAR SW.ST. CONSUMPTION

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0229	.0191	.0229	.0191	.0229	.0229	.0229
2	.0229	.0191	.0229	.0191	.0229	.0229	.0229
3	.0229	.0191	.0229	.0191	.0229	.0229	.0229
4	.0229	.0191	.0229	.0191	.0229	.0229	.0229
5	.0229	.0191	.0229	.0191	.0229	.0229	.0229
6	.0267	.0191	.0381	.0191	.0191	.0229	.0267
7	.0229	.0076	.0076	.0191	.0076	.0076	.0114
8	.0076	.0076	.0076	.0076	.0076	.0076	.0076
9	.0076	.0076	.0076	.0076	.0076	.0076	.0076
10	.0076	.0076	.0076	.0076	.0076	.0076	.0076
11	.0076	.0076	.0076	.0076	.0076	.0076	.0076
12	.0076	.0076		.0076	.0076	.0076	.0076
13	.0076	.0076		.0191	.0076	.0076	.0076
14	.0076	.0076		.0076	.0076	.0076	.0076
15	.0076	.0076		.0076	.0191	.0076	.0076
16	.0076	.0076		.0076	.0076		.0076
17	.0076	.0076		.0076	.0076	.0076	.0076
18	.0076	.0076		.0076	.0191	.0076	.0076
19	.0152	.0267		.0076	.0076	.0229	.0229
20	.0191	.0762		.0229	.0191	.0229	.0343
21	.0191	.08		.0229	.0179	.0229	.0495
22	.0191	.0457		.0229	.0191	.0229	.0343
23	.0191	.0267		.0229	.0191	.0229	.0305
24	.0229	.0191	.0267	.0191	.0229	.0229	.0229
Max	.0267	.08	.0381	.0229	.0229	.0229	.0495
Min	.0076	.0076	.0076	.0076	.0076	.0076	.0076
Avg	.0151	.0200	.0181	.0145	.0147	.0156	.0179

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. EAST S/DN.[155] BU 4359

Substation No/ Name :- 283502 / 22/22 KV NAVGHAR SW/ST

Feeder No / Name : 301 / 22KV VASAI FEEDER

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0087	3.5101	3.7563	3.7967	3.7609	3.5818	3.6561
2	2.9683	3.5101	3.5437	3.2952	3.5101	3.4743	3.3665
3	2.8654	3.4385	3.3669	3.152	3.2952	3.2236	3.2236
4	3.0803	3.4385	3.3311	3.0803	3.1878	3.0445	3.152
5	3.5101	3.4385	3.5475	2.7938	3.2236	3.0445	
6	3.5117	3.6222	3.6892	2.2923	3.4385	3.1161	.8596
7	3.2922	3.6534	3.8371	2.2923	3.5818	3.2952	4.0543
8	3.3303	3.5101	3.6534	2.5789	3.6534	3.4728	3.8683
9	3.152	3.4385	3.4743	2.4451	3.6534	3.4728	3.94
10	3.152	3.5475	3.4385	2.4806	3.5101	3.3311	3.5818
11	3.2952	3.4751	3.4027	2.4097	3.3665	3.6176	3.3669
12	3.2236	3.4027	3.4027	1.701	3.2247	3.3669	3.4385
13	3.152	3.2952		1.5947	3.2602	3.4027	3.2952
14	3.0803	3.2236		2.2325	3.0476	3.4675	3.0803
15	3.0445	3.2952		3.2247	3.1184	3.1878	2.9995
16	3.0445	3.2956		3.0121	2.9058	3.152	3.2217
17	3.0803	3.3669		3.083	3.1893	3.1878	3.2236
18	3.1878	3.4728		1.6655	3.5437	3.4385	1.8625
19	3.8683	4.0474		1.8427	3.7967	3.8683	2.0633
20	4.119	4.3801		4.5249	4.1549	4.2981	4.4056
21	4.1907	4.4056		4.3698	4.1907	4.4414	4.4296
22	4.0832	4.4887		4.2981	4.2715	4.4414	4.3698
23	3.94	4.2265		4.1549	4.3077	4.513	4.3698
24	3.2236	3.6534	4.0969	4.1907	4.0116	4.0181	4.0543
Max	4.1907	4.4887	4.0969	4.5249	4.3077	4.513	4.4296
Min	2.8654	3.2236	3.3311	1.5947	2.9058	3.0445	.8596
Avg	3.3502	3.6307	3.5800	2.9380	3.5502	3.5607	3.3862

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. EAST S/DN.[155] BU 4359

Substation No/ Name :- 283502 / 22/22 KV NAVGHAR SW/ST

Feeder No / Name : 304 / 22KV RAMDASNAGAR FEEDER SHEDDABLE URBAN  
Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.439	.5068	.5121	.543	.543	.5014	.4706
2	.4024	.5068	.5121	.543	.5068	.5731	.4344
3	.439	.4706	.4755	.5068	.4706	.4298	.4344
4	.4024	.5792	.4755	.5068	.4706	.4344	.4344
5	.4755	.4706	.5121	.4706	.4706	.4344	.4706
6	.4755	.4706	.5121	.4706	.4706	.4344	.5068
7	.439	.4706	.4755	.4706	.5068	.4344	.4706
8	.439	.4706	.439	.5068	.5068	.4344	.4706
9	.4755	.5121	.4344	.4961	.4706	.4706	.4706
10	.4344	.4755	.4344	.4961	.4344	.4344	.4755
11	.4344	.4755	.4344	.4961	.4607	.4344	.5121
12	.4344	.439		.4607	.4607	.4344	.4755
13	.4344	.439		.4961	.4252	.4344	.4755
14	.3982	.4024		.3898	.4252	.3982	.4656
15	.3982	.439		.3898	.4252	.3982	.4298
16	.4344	.439		.3544	.3898	.3982	.439
17	.4344	.439		.3544	.3898	.3982	.439
18	.4344	.4755		.3898	.4252	.4344	.4656
19	.4344	.5121		.4252	.5731	.5792	.5487
20	.5792	.5121		.5373	.5731	.5792	.5853
21	.5731	.5487		.543	.5731	.5792	.6219
22	.5792	.5487		.5792	.5792	.6154	.6219
23	.5792	.5121		.543	.6154	.6154	.5853
24	.439	.5068	.5487	.5792	.543	.5792	.543
Max	.5792	.5792	.5487	.5792	.6154	.6154	.6219
Min	.3982	.4024	.4344	.3544	.3898	.3982	.4298
Avg	.4587	.4843	.4805	.4812	.4879	.4775	.4936

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. EAST S/DN.[155] BU 4359

Substation No/ Name :- 283503 / 22/22 KV MSEB COLONY VASAI

SW/

Feeder No / Name : 300 / MSEB COLONY SWST

NON SHEDDABLE EXPRESS HV FEEDERS

CONSUMPTION Feeder KV- 22 /  
OUTGOING(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.3734	.0762	.1029	.0762		.0686	
10			.0686		.1715		
16							.1029
24		.1905	.0686	.1905	.0686		.1905
Max	.3734	.1905	.1029	.1905	.1715	.0686	.1905
Min	.3734	.0762	.0686	.0762	.0686	.0686	.1029
Avg	.3734	.1334	.0800	.1334	.1201	.0686	.1467

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. EAST S/DN.[155] BU 4359

Substation No/ Name :- 283503 / 22/22 KV MSEB COLONY VASAI

SW/

Feeder No / Name : 302 / 22KV EVERSHERE CITY FEEDER

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.4296	5.3727		6.1347			5.6394
2	4.2524	5.144	4.9383	5.7918	4.8011	5.144	5.144
3	4.0398	4.9916		5.487			5.0297
4	4.1461	4.9154	4.6639	5.3346	4.5953	4.8011	4.9154
5	4.0752	4.8011		5.2202			4.9916
6	4.6422	5.4489	4.7325	5.3346	4.9383	4.6296	5.4489
7	5.7053	5.3727		7.3541			5.5251
8	5.1029	5.7156	5.1783	5.9061	5.487	4.9726	5.6394
9	4.9966	5.6394	5.0069	6.9349	1.6461	5.144	5.487
10	4.8903	5.032	4.8011	5.9823	1.6804	5.6394	4.9726
11	4.6422	4.9257	4.9611	5.3509	6.5158		4.7668
12	4.6422	4.7131	4.6422	5.0675	5.7537	6.0966	4.6639
13		4.7131	4.7554	5.1029	5.487	5.5632	4.561
14		4.6422	4.9611	4.8548	5.2965	5.3727	4.4239
15	4.5725	4.7131	4.6068	4.8194	5.0678	5.1059	4.3553
16	4.4963	4.2524	4.5005	4.5005	4.9916	5.144	3.9438
17	4.7249	4.3587	4.6068	6.5204	5.1059	4.9916	
18	4.7249	4.2867	4.9916	4.5953	5.2202		4.7668
19	5.5632	4.6639	5.4108		5.9442	5.7537	
20	5.9061	5.5213	6.2872	6.2414	6.4015	6.211	5.6242
21	6.4396	6.2414	6.7063		6.592	6.4396	
22	6.592	6.4472	6.9349	6.1043	6.7444	6.9349	5.8985
23	6.7063	6.31	7.0873	6.31		6.973	
24	5.0675	6.0585	5.7956	6.592	5.5899	5.8985	6.5158
<b>Max</b>	<b>6.7063</b>	<b>6.4472</b>	<b>7.0873</b>	<b>7.3541</b>	<b>6.7444</b>	<b>6.973</b>	<b>6.5158</b>
<b>Min</b>	<b>4.0398</b>	<b>4.2524</b>	<b>4.5005</b>	<b>4.5005</b>	<b>1.6461</b>	<b>4.6296</b>	<b>3.9438</b>
<b>Avg</b>	<b>5.0163</b>	<b>5.1784</b>	<b>5.2784</b>	<b>5.7064</b>	<b>5.1505</b>	<b>5.6009</b>	<b>5.1157</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. EAST S/DN.[155] BU 4359

Substation No/ Name :- 283503 / 22/22 KV MSEB COLONY VASAI

SW/

Feeder No / Name : 304 / 22KV GOKHIWARE FEEDER

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8671	2.0576		2.2862			2.0576
2	1.7551	1.9052	1.6461	2.21	1.7147	1.7833	1.9814
3	1.7177	1.8671		2.0957			1.9433
4	1.6057	1.829	1.7833	2.0195	1.6461	1.6804	1.8671
5	1.5684	1.8671		2.0195			1.8671
6	1.9418	2.0576	1.8519	2.0576	1.7147	1.7147	1.9814
7	1.9044	2.0195		1.9814			2.0576
8	1.9791	2.0576	1.9547	2.1338	1.7833		2.1338
9	1.9791	2.1719	1.9547	1.9814	1.989	2.0233	2.2862
10	2.2405	2.2032	2.1605	2.0195	2.0233	2.3243	2.1948
11	2.3899	2.2405	2.3525	1.8671	2.2862	2.3624	2.2634
12	2.2779	2.2405		1.8298	2.2862	2.3624	2.2291
13		2.0911	2.1285	1.7177	2.1719	2.0957	1.989
14		2.2405		1.643	2.1338	2.3243	2.0233
15	2.2481	2.0911	2.6139	1.6057	2.5149	2.2862	1.989
16	2.1338	2.2032	2.4272	1.531	2.2862	2.1338	1.8861
17	2.2862	2.2779	2.3525	1.6057	2.2862	2.2862	
18	2.1719	2.0919	2.2481	1.6118	2.2862		1.989
19	2.5149	2.1948	2.4768		2.553	2.4387	
20	2.5911	2.4006	2.7054	1.9547	2.5911		2.4006
21	2.5911	2.1605	2.5911		2.553	2.553	
22	2.4768	2.3663	2.6292	2.0233	2.4768	2.4768	2.2634
23	2.3624	2.2634	2.553			2.4387	
24	2.0165	2.1719	2.0576	2.4387	1.989	2.0233	2.21
<b>Max</b>	<b>2.5911</b>	<b>2.4006</b>	<b>2.7054</b>	<b>2.4387</b>	<b>2.5911</b>	<b>2.553</b>	<b>2.4006</b>
<b>Min</b>	<b>1.5684</b>	<b>1.829</b>	<b>1.6461</b>	<b>1.531</b>	<b>1.6461</b>	<b>1.6804</b>	<b>1.8671</b>
<b>Avg</b>	<b>2.1191</b>	<b>2.1279</b>	<b>2.2493</b>	<b>1.9349</b>	<b>2.1729</b>	<b>2.1946</b>	<b>2.0807</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. EAST S/DN.[155] BU 4359

Substation No/ Name :- 283504 / 22/22 KV GAURAI PADA (INDOOR)

S

Feeder No / Name : 301 / GAURAI PADA SWST

NON SHEDDABLE EXPRESS HV FEEDERS

CONSUMPTION Feeder KV- 22 /  
OUTGOING(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0026	.0026	.0257	.0257	.0257	.0257	.0026
2			.0257	.0026	.0257	.0026	.0026
3			.0257	.0026	.0257	.0257	.0026
4		.0026	.0257	.0026	.0257	.0026	.0026
5			.0257	.0026	.0257	.0037	.0026
6			.0257	.0026	.0257	.0026	.0026
7	.0026	.0026	.0257	.0026	.0257	.0026	
8	.0026	.0026	.0026	.0257	.0026	.0026	
9	.0257	.0257	.0026		.0026	.0026	.0026
10	.0026				.0026	.0257	
11	.0026						.0026
12	.0026				.0026	.0026	.0026
13					.0026	.0026	.0026
14	.0026				.0026	.0026	.0025
15					.0026		.0026
16			.0026		.0026		.0026
17	.0026		.0026		.0026		.0026
18	.0026	.0026		.0026	.0026	.0257	.0026
19	.0257	.0257		.0257			.0257
20	.0257	.0257		.0257	.0026		.0257
21	.0257	.0257		.0257		.0257	.0257
22				.0257	.0026		.0257
23		.0257		.0257	.0026	.0026	.0257
24	.0026	.0026	.0257	.0026	.0257	.0026	.0026
Max	.0257	.0257	.0257	.0257	.0257	.0257	.0257
Min	.0026	.0026	.0026	.0026	.0026	.0026	.0025
Avg	.0092	.0131	.018	.0134	.0114	.0095	.0081



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. EAST S/DN.[155] BU 4359

Substation No/ Name :- 283504 / 22/22 KV GAURAIKADA (INDOOR)

S

Feeder No / Name : 302 / 22KV GAURAIKADA FEEDER

SHEDDABLE FEEDER HAVING WEEKLY

Feeder KV- 22 / OUTGOING

STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.315	2.6566	2.6946	2.7705	1.8217	2.4669	2.4289
2			2.6187	2.6566	1.8596	2.3909	2.315
3			2.5428	.0026	1.8976	2.2012	2.2771
4			2.3909	2.6187	1.8976	2.0873	2.2012
5			2.315	2.353	1.8596	1.9735	2.1253
6	2.0494		2.2391	2.353	1.8596	1.9355	2.0494
7	2.2012	2.4289	2.5428	2.315	2.0873	2.0873	2.3909
8	2.4669	2.7325	2.9223	2.2771	2.2771	2.4669	2.4669
9	3.5674	3.4915	3.8331	2.2391	2.5428	3.112	2.0114
10	4.6301	4.668		2.0873	3.7193	4.2506	
11	4.8199	4.7439		2.1253			4.7819
12	4.7819	4.706		2.1253	3.8711	4.3644	4.8578
13		3.1879		1.9735	2.7325	3.4915	3.4156
14	4.4783	4.2126		1.8217	3.5837	3.909	4.5542
15		4.3644		1.7078	3.5295	4.2506	4.5921
16		4.706	4.5542	1.7078	3.6813	4.3265	4.4403
17	4.6301	4.4024	4.4783	1.7078	3.4156	3.7572	4.1747
18	4.4024	4.4024		1.8596	2.9602	3.7193	3.6813
19	4.0608	4.3265		1.8976		3.909	4.2506
20	3.9849	3.7572		2.2012	3.2259	3.6054	3.909
21	3.3777	3.2259		2.2391		3.0741	3.0361
22				2.1632	2.6946		2.8464
23		2.9982		2.0494	2.6187	2.6946	2.8843
24	2.4669	2.6566	2.7705	2.8843	1.9355	2.4289	2.5428
Max	4.8199	4.7439	4.5542	2.8843	3.8711	4.3644	4.8578
Min	2.0494	2.4289	2.2391	.0026	1.8217	1.9355	2.0114
Avg	3.6155	3.7593	2.9919	2.0890	2.6700	3.1138	3.2275

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. EAST S/DN.[155] BU 4359

Substation No/ Name :- 283504 / 22/22 KV GAURAI PADA (INDOOR)

S

Feeder No / Name : 303 / 22KV VTIC SECTOR-1 FEEDER SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	.8764	1.105	.9907	.6097	.9907	.9526
2			1.0288	.9526	.6097	.8383	.8002
3			.9526	.9145	.5716	.8764	.7621
4		.8002	.9145	.8764	.5716	.8383	.8383
5			.9526	.8764	.6097	.8383	.8002
6	.8764		.9145	.8764	.6478	.8002	.8764
7	.9145	.9526	.9907	.7621	.6859	.8383	.9145
8	1.0669	1.1431	1.1812	.8002	.6859	.9907	1.1812
9	1.5242	1.6004	1.6766	.7621	1.2574	1.5623	1.5623
10	.2324	2.2862		.6478	.1791	2.0195	
11	.2667	2.8578		.6097			2.5149
12	.2743	2.7816		.6478	.2172	.2439	2.7435
13		2.1338		.4572	.1524	.1715	2.1719
14	.2553	2.4387		.5716	2.21	.221	3.315
15		2.5911		.5716	.2134	2.0957	2.7435
16		2.6673	3.658	.5335	.2134	2.1338	2.3243
17	2.4387	2.5911	2.4387	.6097	.1981	2.0957	2.4387
18	.2286	2.6292		.6478	.1715	1.9433	1.9433
19	1.8671	1.7909		.6478		1.9433	1.6004
20	1.4861	1.4861		.6478	.1296	1.2955	1.4098
21	1.2193	1.1431		.6478		1.1431	1.2193
22				.6478	.9907		.9145
23		1.1431		.6859	.0953	.9145	.9145
24	.9526	.9526	1.0288	1.0288	.6478	.8764	.9526
Max	2.4387	2.8578	3.658	1.0288	2.21	2.1338	3.315
Min	.2286	.8002	.9145	.4572	.0953	.1715	.7621
Avg	.9704	1.8350	1.4035	.7256	.5556	1.1669	1.5606

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. EAST S/DN.[155] BU 4359

Substation No/ Name :- 283504 / 22/22 KV GAURAI PADA (INDOOR)

S

Feeder No / Name : 304 / 22KV BHODAPADA FEEDER

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.4648	4.6587	4.8053	4.9188	3.0648	4.4582	4.5405
2			4.6918	4.881	3.254	4.1999	4.1621
3			4.5026	4.8053	3.2162	4.3134	6.8107
4		6.3945	4.3513	4.6868	3.1405	4.2378	6.5837
5			4.3134	4.4648	3.1027	4.2756	6.4323
6	4.1621		4.3513	4.4648	3.254	4.3134	.9838
7	4.0752	8.2485	4.3891	4.427	3.4054	4.427	4.7297
8	4.4648	6.054	5.2594	4.1621	4.1243	4.9945	7.7566
9	6.6215	6.9999	6.6594	3.9729	6.0161	3.4432	9.4593
10	8.2107	8.7026		3.8216	7.9837	7.6508	
11	9.0809	9.3836		3.4432			8.7404
12		9.4215		3.7081	8.8918	8.135	9.0809
13		7.681		3.5189	7.0756	7.4161	7.9837
14	8.5134	9.0053		3.2259	8.0215	7.6053	8.362
15		9.1188		3.1027	8.362	7.681	9.0053
16		9.0809	9.6485	2.9891	8.7026	7.4918	8.5891
17	8.5134	8.7026	8.6269	2.8756	8.4755	7.6283	8.6647
18	8.3242	8.3242		2.9891	7.4539	7.0377	7.3783
19	7.2269	7.8323		3.1405		6.6594	7.4539
20	6.6594	6.9999		3.5567	6.5458	6.3945	6.6594
21	5.8648	5.9405		3.5945		5.2594	5.2594
22				3.5567	5.2594		5.2972
23		5.3729		3.2918	5.1837	4.9188	4.9567
24	4.427	4.6918	4.9945	5.1459	3.1783	4.8432	4.654
Max	9.0809	9.4215	9.6485	5.1459	8.8918	8.135	9.4593
Min	4.0752	4.6587	4.3134	2.8756	3.0648	3.4432	.9838
Avg	6.4721	7.5060	5.5495	3.8643	5.6053	5.7902	6.6758

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. EAST S/DN.[155] BU 4359

Substation No/ Name :- 283504 / 22/22 KV GAURAI PADA (INDOOR)

S

Feeder No / Name : 305 / 22KV VTIC SECTOR-2 FEEDER SHEDDABLE FEEDER HAVING WEEKLY

Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.424	2.7649	2.8028	2.5755	1.3635	2.424	2.424
2			2.5377	2.2725	1.3635	2.2725	2.121
3			2.2725	2.121	1.3635	2.1968	2.0453
4		1.8938	2.121	1.8938	1.3635	2.121	2.0074
5			2.0453	1.818	1.3256	2.0453	1.9316
6	1.7044		2.0074	1.818	1.3256	2.0453	1.9316
7	1.9695	2.121	2.2346	1.7044	1.4771	2.0831	2.0074
8	2.4619	2.2725	2.5377	1.4014	1.8559	2.2725	2.2565
9	4.7723	3.8855	4.2799	1.4014	3.8254	3.4467	4.2042
10	6.6661	6.3631		1.4014	5.8707	5.4919	
11	7.5372	7.3478		1.4393			6.9691
12		7.3099		1.4393	6.6661	5.8328	6.6282
13		4.545		1.4771	4.5072	4.3935	4.9238
14	6.8933	6.5524		1.4014	6.2243	5.6434	6.2873
15		6.7797		1.4393	6.1358	6.0222	6.7039
16		6.3252	6.7797	1.3635	6.2494	6.0601	6.6282
17	6.9312	6.0601	6.4388	1.3635	5.7192	6.0222	6.5903
18	6.2873	5.9464		.9848	5.6813	4.9617	5.6813
19	5.4919	5.2647		1.4014		4.848	4.9617
20	4.242	4.1284		1.4393	4.242	4.0905	4.1284
21	3.4845	3.03		1.4771		3.1815	3.03
22				1.4771	2.727		2.5755
23		2.8407		1.4393	2.5377	2.6513	2.6892
24	2.6134	2.727	2.727	2.7649	1.3635	2.6134	2.6134
Max	7.5372	7.3478	6.7797	2.7649	6.6661	6.0601	6.9691
Min	1.7044	1.8938	2.0074	.9848	1.3256	2.0453	1.9316
Avg	4.5342	4.6399	3.2320	1.6381	3.4851	3.7600	3.9713

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. EAST S/DN.[155] BU 4359

Substation No/ Name :- 283504 / 22/22 KV GAURAI PADA (INDOOR)

S

Feeder No / Name : 306 / 22KV TRINITY SAND &  
MINERALS E Feeder KV- 22 /  
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1595	.6139	1.2003	.0818	.6859	.7503	.5798
2			1.2689	1.1254	.5144	.8867	.0958
3			1.1741	1.2618	.583	1.0913	.0443
4		.8867	.6818	1.0572	.618	.8185	.3001
5			.7196	1.2277	.0514	.3751	.8867
6	.5798		.6859	1.2346	.048	1.0913	.648
7	.4092	.6139	.0857	1.2003	.1166	.6139	.648
8	.5115	.0443	.0926	.0926	.5144	.0047	.0546
9	.1705	.0614	.048	.0857	.0583	.0477	.0477
10	.8497	.8916		.0892	.1054	.6139	
11	.7138	1.406		.0857			.0546
12		1.3375		.0857	.5098	1.2576	.6821
13		1.2346		.0892	.5438	.5778	1.1595
14	.6798	1.3032		.096	.5115	1.0876	1.1595
15		.823		.096	.4758	1.0631	1.1254
16		.1097	1.3375	.096	1.2236	1.0974	.583
17	.6859	.9602	1.3032	.0926	.7478		.7888
18	.9517	1.4403		.0926	1.0197	.5144	.1166
19	.7888	1.406		.0857		.7202	.0823
20	.0857	.0789		.0823	1.0876	.0823	.072
21	.5144	.0995		.0823		.0892	.0857
22				.0926	.6139		.0583
23		1.166		.1269	.6458	.8867	.1749
24	1.1254	.8526	1.2003	.1807	.7888	.787	1.1936
Max	1.1595	1.4403	1.3375	1.2618	1.2236	1.2576	1.1936
Min	.0857	.0443	.048	.0818	.048	.0047	.0443
Avg	.6590	.8068	.8165	.3684	.5459	.6884	.4627

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. EAST S/DN.[155] BU 4359

Substation No/ Name :- 283506 / 22/22 KV NAIKPADA (WALIV)

SW/S

Feeder No / Name : 300 / NAIKPADA SWST CONSUMPTION NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / OUTGOING (NON-CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.0754	.0754					.0754
7			.0754	.0754	.1142	.0754	
9			.0754		.1132		
12	.4527	.0754		.0754	.0754		.4527
13			.0754			.0754	
15		.0754			.0754		
16				.0754			
18		.0754		.0754	.415		
19			.0754		.439	.0754	.0754
20	.6413				.7167		
21	.3772						
24	.3772	.3772		.3772		.415	.3772
Max	.6413	.3772	.0754	.3772	.7167	.415	.4527
Min	.0754	.0754	.0754	.0754	.0754	.0754	.0754
Avg	.3848	.1358	.0754	.1358	.2784	.1603	.2452

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. EAST S/DN.[155] BU 4359

Substation No/ Name :- 283506 / 22/22 KV NAIKPADA (WALIV)

SW/S

Feeder No / Name : 301 / 22KV NAIKPADA FEEDER  
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.9794	5.0926	5.2812	5.2058	2.7915	4.9794	4.3004
2	4.7531	4.9794		5.0549		4.904	4.225
3	4.5645	4.6776	4.8285	4.8285	2.5652	4.6022	4.1495
4	4.3381	4.5268		4.4136		4.5268	4.0741
5	4.225	4.5268	4.5268	4.2627	2.4897	4.3004	4.0741
6	4.1118	4.1495	4.3759	4.225	2.5652	4.1495	4.1118
7	4.3004	4.6399	4.5268	4.1872	2.7161	4.0364	4.1495
8	4.8285	5.0172	4.904		3.0178	4.6399	4.7531
9	6.8656	6.8656	6.9787	2.5652	6.2243	6.262	6.5638
10	9.3176	9.5062	9.2798	2.5652		8.7517	8.9403
11	9.9966	6.4129	9.5439	2.5652	8.9403	9.2421	9.129
12	9.808	10.1852	10.072	2.5274	9.3553	8.6386	9.6571
13	8.5254		7.9595	2.5652	7.4691	6.9033	6.9787
14	9.3176		9.0535			8.3368	9.3553
15	9.9211	9.7325	9.8457		9.2044	9.1667	9.2421
16	9.9589	9.9966	10.2984	2.3388	9.5062	9.4307	9.5816
17	9.8834	9.7325	9.9589	2.1879	9.0535	9.3176	9.7702
18	8.9781	9.0535	8.6763	2.2634	7.8841	8.3368	8.6386
19	8.4877	8.5631	8.1104	2.3388	7.9595	7.9973	8.8649
20	7.2428	7.356	7.2805	2.4897	6.9033	6.7147	6.941
21	5.8093	6.1866	6.262	2.6029	5.0549	5.5453	
22	5.4321		5.6962		4.904	5.1303	4.6022
23	5.4321	5.4698	6.1488	3.0178	5.0549	4.7908	5.2812
24	5.2058	5.3567	5.3567	5.3189	2.9424	5.0549	4.4513
<b>Max</b>	<b>9.9966</b>	<b>10.1852</b>	<b>10.2984</b>	<b>5.3189</b>	<b>9.5062</b>	<b>9.4307</b>	<b>9.7702</b>
<b>Min</b>	<b>4.1118</b>	<b>4.1495</b>	<b>4.3759</b>	<b>2.1879</b>	<b>2.4897</b>	<b>4.0364</b>	<b>4.0741</b>
<b>Avg</b>	<b>6.9285</b>	<b>6.7632</b>	<b>7.2257</b>	<b>3.3762</b>	<b>5.8301</b>	<b>6.4899</b>	<b>6.6015</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. EAST S/DN.[155] BU 4359

Substation No/ Name :- 283506 / 22/22 KV NAIKPADA (WALIV)

SW/S

Feeder No / Name : 303 / 22KV TUNGARESHWAR-HIGHWAY SHEDDABLE FEEDER HAVING WEEKLY

FEED Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7915	2.8669	2.9424	2.9424	2.037	2.7435	2.9047
2	2.6406	2.7161		2.7915		2.9424	2.7915
3	2.4897	2.6406	2.8669	2.6406	1.9616	2.9047	2.6406
4	2.4143	2.6029		2.5274		2.9047	2.6029
5	2.2634	2.6406	2.5652	2.452	1.8861	2.8292	2.5652
6	2.3388	2.7915	2.4897	2.452	2.037	2.9047	2.5652
7	2.7538	2.7915	2.7915	2.4897	2.2257	3.0556	2.6029
8	2.9424	2.8669	2.7915	2.1879	2.452	2.9047	2.7538
9	3.7723	3.9986	3.4705	2.037	3.7723	3.5082	4.1118
10	6.2243	6.0357	5.8471	2.1125		5.4698	5.9225
11	6.4129	6.7147	6.5638	2.2257	5.9225	6.0357	6.6015
12	6.4506	6.7901	6.3375	2.1125	6.2997	5.998	6.6015
13	4.6399		5.3189	1.8861	5.0549	3.9232	4.4136
14	6.6392		5.998			5.2812	5.8093
15	6.5261	6.5638	6.2243		5.8848	5.4698	6.4129
16	6.4506	6.6015	5.9602	1.9993	5.8471	5.4321	6.2997
17	6.2997	6.4129	5.7339	1.8861	6.0357	5.5076	6.1866
18	5.6584	5.7339	5.3944	1.773	5.5076	5.2435	5.7339
19	5.4698	5.8093	4.8285	1.8107	5.2812	4.904	5.3567
20	4.7154	5.0926	4.1495	1.9616	4.5645	4.0364	4.4136
21	3.4328	3.4705	3.3196	1.6975	3.2442	3.131	3.2065
22	3.3573		3.3196		3.2819	3.1687	3.3573
23	2.9995	3.2442	3.131	2.0748	3.0556	3.0556	1.5466
24	2.9801	2.9424	3.0178	3.0556	2.0748	3.0178	3.0178
<b>Max</b>	<b>6.6392</b>	<b>6.7901</b>	<b>6.5638</b>	<b>3.0556</b>	<b>6.2997</b>	<b>6.0357</b>	<b>6.6015</b>
<b>Min</b>	<b>2.2634</b>	<b>2.6029</b>	<b>2.4897</b>	<b>1.6975</b>	<b>1.8861</b>	<b>2.7435</b>	<b>1.5466</b>
<b>Avg</b>	<b>4.2776</b>	<b>4.3489</b>	<b>4.3210</b>	<b>2.2436</b>	<b>3.9213</b>	<b>4.0155</b>	<b>4.1841</b>



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. EAST S/DN.[155] BU 4359

Substation No/ Name :- 283506 / 22/22 KV NAIKPADA (WALIV)

SW/S

Feeder No / Name : 304 / 22KV REMI FEEDER

SHEDDABLE FEEDER HAVING WEEKLY

Feeder KV- 22 / OUTGOING

STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3957	1.5844	1.358	1.5466	.9808	1.4335	1.2826
2	1.358	1.5089		1.4335		1.4335	1.2449
3	1.358	1.3203	1.4335	1.358	.9054	1.3203	1.2449
4	1.358	1.2071		1.358		1.2826	1.2071
5	1.3957	1.2449	1.358	1.3203	.8299	1.2449	1.2449
6	1.4335	1.5089	1.358	1.3203	.8299	1.2826	1.2826
7	1.4712	1.5089	1.5089	1.3203	.9808	1.358	1.3203
8	1.8107	1.6221	1.358	1.2449	1.0562	1.5844	1.5466
9	2.452	2.7538	2.7915	.9808	2.2634	2.3388	3.0178
10	3.9986	3.1687	3.5837	1.0562		3.3951	3.5082
11	3.7346	3.6214	3.8855	1.0562	2.9424	3.5837	3.9986
12	3.7723	3.4328	3.9609	1.0185	2.8669	3.4328	3.9232
13	2.9424		3.0933	1.0562	2.7915	2.6029	
14	3.5837		3.9232			3.0933	3.9986
15	3.8855	3.546	3.6214		3.2819	3.2819	3.546
16	3.546	3.8477	3.6591	.7545	3.3196	3.2442	3.9232
17	3.4705	3.3951	3.4328	.9054	3.2819	3.2065	3.4705
18	3.1687	3.0178	3.1687	.9808	2.8669	2.8292	3.5082
19	2.6029	2.8669	2.6029	.9808	2.3765	2.4143	2.7915
20	2.4143	2.1879	2.2634	.9808	1.8861	1.7353	2.1502
21	1.9616	1.6221	1.773	1.0185	1.5089	1.5089	1.6975
22	1.5466		1.773		1.5466	1.4712	1.6598
23	1.6221	1.4335	1.6598	.9808	1.5844	1.358	1.4335
24	1.3957	1.6975	1.5089	1.6598	.9808	1.4335	1.2826
<b>Max</b>	<b>3.9986</b>	<b>3.8477</b>	<b>3.9609</b>	<b>1.6598</b>	<b>3.3196</b>	<b>3.5837</b>	<b>3.9986</b>
<b>Min</b>	<b>1.358</b>	<b>1.2071</b>	<b>1.358</b>	<b>.7545</b>	<b>.8299</b>	<b>1.2449</b>	<b>1.2071</b>
<b>Avg</b>	<b>2.4033</b>	<b>2.2903</b>	<b>2.5034</b>	<b>1.1586</b>	<b>1.9540</b>	<b>2.1612</b>	<b>2.3601</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. URBAN S/DN[156] BU 4341

Substation No/ Name :- 283210 / 22/22KV PAPDI SWITCHING

Feeder No / Name : 351 / UMELA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.9683	2.0995	2.1719	2.0271	2.0995	2.0271
2		2.7511	1.9547	2.0271	1.8823	2.0271	2.0271
3		2.6787	1.8823	2.0271	1.8099	1.9547	1.8823
4		2.6063	1.8823	1.8823	1.8099	1.8099	1.8823
5		2.6063	1.8823	1.8099	2.2443	1.8823	1.9547
6		2.8235	2.0271	2.0271	1.8099	2.0995	2.0995
7		2.7511	2.0271	2.0271	1.8823	1.9547	1.9547
8	2.6063	2.6063	1.8099	1.9547		1.8823	2.0271
9	2.3891	2.4615	1.6651	1.9547		1.9547	1.7375
10	2.3167	2.3167	1.5927	1.8823	1.5927	1.8099	1.8823
11	2.2443	2.2443	1.5203	1.8099	2.4615	1.8823	1.8099
12	2.2443		1.5203	1.7375	2.2443	1.8823	1.7375
13	2.1719		1.5927	1.6651	1.9547	1.7375	1.6651
14	2.3891	2.3167	1.5203	1.5927	1.8099	1.6651	1.5927
15	2.2443		1.5203	1.448	1.8099	1.7375	1.448
16	2.0995	2.3167	1.448	1.448	1.7375	1.5927	1.5203
17	2.1719	2.3891	1.5203	1.448	1.5927	1.5927	
18		1.3032	1.5927	2.4615	1.9547	1.7375	2.3167
19	4.1991	2.0995	2.0995	1.9547	2.1719	2.2443	2.6063
20	3.9819	2.4615	2.3891	2.2443	2.3891	2.4615	2.4615
21	3.7647	2.4615	2.4615	2.3167	2.3891	2.3891	2.3891
22	3.7647	2.5339	2.4615	2.3167	2.3891	2.4615	2.4615
23	3.5475	2.5339	2.4615	2.3167	2.3891	2.5339	2.3891
24	2.8959	3.1131	2.3167	2.3891	2.1719	2.2443	2.2443
Max	4.1991	3.1131	2.4615	2.4615	2.4615	2.5339	2.6063
Min	2.0995	1.3032	1.448	1.448	1.5927	1.5927	1.448
Avg	2.8145	2.4925	1.8853	1.9547	2.0238	1.9849	2.0051

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. URBAN S/DN[156] BU 4341

Substation No/ Name :- 283210 / 22/22KV PAPDI SWITCHING

Feeder No / Name : 352 / VASAI

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		6.0814	6.4434	4.0543	3.4751	3.7647	3.3303
2		5.647	6.009	3.7647	3.2579	3.4027	3.0407
3		5.647	5.7918	3.5475	3.1855	3.2579	2.9683
4		5.4298	5.5022	3.4751	3.1131	3.1855	2.8959
5		5.4298	5.5746	3.5475	3.9819	3.3303	2.8235
6		5.647	6.0814	3.6199	3.0407	3.9819	3.1131
7		5.5022	3.7647	3.5475	3.0407	3.3303	3.1855
8	5.3574	5.647	3.3303	3.5475		3.1131	4.7782
9	5.2126	5.7194	3.4751	3.6923	4.3439	3.4027	3.6199
10	5.4298	5.7194	3.5475	3.5475	3.4751	3.4751	3.6199
11	5.3574	5.7918	3.7647	3.9095	3.7647	3.5475	3.6199
12	5.285		3.6199	5.4298	3.4027	3.4751	3.4751
13	5.2126		3.5475	5.4298	3.3303	3.3303	3.2579
14	5.0678	5.3574	3.4027	5.0678	3.2579	3.1855	3.1131
15	5.2126		3.3303	1.8099	3.2579	3.1131	2.8959
16	5.3574	5.4298	3.2579	3.1855	3.2579	3.0407	3.0407
17	5.2126	5.5022	3.4027	5.647	3.2579	3.1131	
18		5.5746	3.5475	5.7918	3.4751	3.3303	4.3439
19	8.8325	6.733	4.1991	6.6606	4.0543	4.0543	4.6334
20	8.2533	7.2398	4.561	4.1991	4.2715	4.4163	4.3439
21	7.6017	7.3846	4.4887	4.0543	3.9819	4.2715	4.1991
22	7.5294	7.8189	4.6334	3.9819	4.1991	4.2715	4.0543
23	7.2398	7.6017	4.7058	3.9819	4.1991	4.4163	4.0543
24	5.7194	6.5882	6.5882	4.561	3.7647	4.0543	4.1267
Max	8.8325	7.8189	6.5882	6.6606	4.3439	4.4163	4.7782
Min	5.0678	5.3574	3.2579	1.8099	3.0407	3.0407	2.8235
Avg	6.1176	6.0710	4.4404	4.1689	3.5821	3.5777	3.5884

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. URBAN S/DN[156] BU 4341

Substation No/ Name :- 283210 / 22/22KV PAPDI SWITCHING

Feeder No / Name : 353 / NAIGAON

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8299	.8299	.9808	.679	.8299	.7545
2		.9054	.9054	.9808	.7545	.8299	.679
3		.8299	.9054	.9808	.7545	.9054	.679
4		.7545	.8299	.9054	.7545	.8299	.6036
5		.679	.7545	.8299	.679	.7545	.5281
6		.6036	.679	.7545	.6036	.6036	.5281
7		.6036	.6036	.679	.6036	.6036	.5281
8	.6036	.7545	.679	.6036	.6036	.6036	.6036
9	1.0562	1.0562	1.1317	.679	.9808	.7545	.9808
10	1.7353	1.7353	1.7353	.679	1.5844	.7545	1.5844
11	2.1125		1.9616	.7545	1.5089	.8299	1.8861
12	2.037	1.9616	1.8107	.7545	1.6598	.9054	1.9616
13	1.4335		1.5844	.8299	1.358	.8299	1.5089
14	1.8861	1.8107	1.8861	.8299	1.6598	.8299	1.7353
15	1.9616		2.1125	.7545	1.6598	.7545	1.8107
16	1.8861	1.8861	2.1125	.7545	1.6598	.7545	1.8107
17	1.8861	1.8107	1.9616	.679	1.6598	.679	1.5089
18	1.6598	2.037	1.7353		1.2071	.6036	1.5089
19	1.358	1.358	1.4335	.679	1.2071	.679	1.5089
20	1.1317	1.358	1.358	.7545	1.0562	.6036	1.2071
21	1.0562	1.0562	1.0562	.679	.9054	.6036	1.0562
22	1.1317	1.0562	1.0562	.7545	.9054	.7545	.9054
23	1.0562	1.0562	1.0562	.7545	.8299	.7545	.9054
24	.8299	.9054	.8299	.9808	.7545	.8299	.679
Max	2.1125	2.037	2.1125	.9808	1.6598	.9054	1.9616
Min	.6036	.6036	.6036	.6036	.6036	.6036	.5281
Avg	1.4601	1.1928	1.2920	.7840	1.0845	.7451	1.1443

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. URBAN S/DN[156] BU 4341

Substation No/ Name :- 283210 / 22/22KV PAPDI SWITCHING

Feeder No / Name : 354 / SANDOR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.4143	2.5606	2.6337	2.4874	2.5606	2.3777
2		2.268	2.4143	2.5606	2.3411	2.4874	2.9264
3		2.1216	2.268	2.268	2.1948	2.3411	2.1216
4		2.0485	2.1948	2.1216	2.1948	2.1216	1.9845
5		1.9753	2.268	2.0485	2.1948	2.1948	2.0485
6		2.1948	2.3411	2.1948	2.1948	2.268	2.1948
7		2.5606	2.1216	2.1216	2.1216	2.1948	2.0485
8	2.7801	1.9753	1.9022	2.0485		2.1216	1.9022
9	2.7801	1.9753	1.9022	2.0485	2.1216	1.9753	1.9753
10	2.5606	1.829	1.9022	1.9753	2.0485	1.9753	1.9022
11	2.4143		1.7558	1.9022	2.0485	1.9022	2.1948
12	2.1948		1.829	1.9753	2.0485	1.9753	1.9022
13	2.1948		1.7558	1.9753	2.0485	1.9022	1.829
14	2.1216	1.9022	1.9022	1.9022		1.9753	1.829
15	2.1216		1.9753	1.9022	2.7069	1.9753	1.7558
16	2.0485	1.9022	1.6095	1.9022	2.268	1.9753	1.7558
17	2.0485	1.9753	1.9022	1.9753	2.1216	1.9753	1.829
18	2.0485	1.9753	1.9753		2.268	2.0485	2.0485
19	2.4143	2.3411	2.3411	2.9264	2.4874	2.4143	2.5606
20	2.9995	2.8532	2.7069	2.9995	2.9264	2.8532	2.7801
21	2.9264	2.9264	2.7801	2.9264	2.8532	2.7801	2.7069
22	3.0727	3.0727	2.9995	2.8532	2.9264	2.9264	2.7801
23	2.9995	3.0727	3.1459	2.9264	2.9264	2.9995	2.7069
24		2.6337	2.7801	2.9264	2.6337	2.7069	2.6337
Max	3.0727	3.0727	3.1459	2.9995	2.9264	2.9995	2.9264
Min	2.0485	1.829	1.6095	1.9022	2.0485	1.9022	1.7558
Avg	2.4829	2.3009	2.2222	2.3093	2.3710	2.2771	2.1998

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. URBAN S/DN[156] BU 4341

Substation No/ Name :- 283210 / 22/22KV PAPDI SWITCHING

Feeder No / Name : 355 / Dattani

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1524	.1524	.1143	.1524	.1524	.1524
2		.1143	.1524	.1143	.1524	.1524	.1524
3		.1524	.1524	.1143	.1524	.1524	.1524
4		.1524	.1524	.1143	.1524	.1524	.1524
5		.1524	.1524	.1143	.1524	.1524	.1524
6		.1524	.1524	.1143	.1524	.1524	.1524
7		.1905	.1524	.1143	.1524	.1524	.1524
8	.1524	.1905	.1524	.1143		.1524	.1524
9	.1524	.1905	.1524	.1143	.1524	.1524	.1524
10	.1524	.2286	.1524	.1524	.1524	.1524	.1524
11	.3429		.4572	.4572	.4191	.3048	.3048
12	.381		.4954	.4572	.4954	.4572	.3429
13	.4572		.4954	.5716	.4954	.6097	.5335
14	.4191	.5335	.4572	.4954	.5335	.5335	.4191
15	.4572		.4954	.5335	.6478	.6478	.4191
16	.5335	.6097	.4954	.4572	.5335	.5716	.4191
17	.4954	.6097	.4954	.4572	.5335	.5716	.4954
18	.5335	.5716	.5335		.5335	.6478	.4954
19	.6097	.6097	.5335	.5335	.5716	.6859	.6097
20	.5335	.5716	.5335	.6478	.6097	.8002	.5716
21	.4572	.5716	.5335	.4954	.4954	.6478	.4954
22	.1524	.1905	.2286	.1905	.1905	.3048	.2667
23	.1524	.1905	.1905	.1524	.1524	.1524	.2286
24	.1524	.1143	.1524	.1524	.1524	.1524	.1143
Max	.6097	.6097	.5335	.6478	.6478	.8002	.6097
Min	.1524	.1143	.1524	.1143	.1524	.1524	.1143
Avg	.3609	.3125	.3175	.2949	.3363	.3588	.3017

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. URBAN S/DN[156] BU 4341

Substation No/ Name :- 283210 / 22/22KV PAPDI SWITCHING

Feeder No / Name : 356 / SAIBABA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.9022	2.0485	2.2443	2.0485	2.1216	2.0485
2		1.7558	1.9022	4.4993	1.829	1.9387	1.829
3		1.6827	1.829	4.0238	1.829	1.829	1.7558
4		1.6095	1.7558	3.8043	1.7558	1.7558	1.7558
5		1.6827	1.7558	3.7311	2.1948	1.829	1.7558
6		1.9753	2.1948	3.8775	1.7558	2.0119	2.0485
7		1.9387	2.1216	3.658	1.829	1.9387	1.9753
8	1.7558	1.8656	1.9022	2.0485	2.1216	1.9022	1.9022
9	1.5364	1.6461	1.7558	1.9022	1.6827	1.9022	1.829
10	1.6095	1.6827	1.6827	1.9022	1.6827	1.9753	1.829
11	1.5203	1.4998	1.5364	1.7924	1.6827	1.9753	1.7558
12	1.39		1.4998	1.6827	1.829	1.9022	1.6095
13	1.4632		1.4998	1.6827	1.6461	1.829	1.5364
14	1.4632	1.6095	1.5364	1.5364	1.5364	1.6827	1.5364
15	1.4632		1.5364	1.6095	1.7193	1.6827	1.4632
16	1.4266	1.4632	1.4998	1.5364	1.6461	1.6827	1.4632
17	1.4632	1.5364		1.5364	1.4632	1.6827	
18		1.5364	.7316	1.6095	1.7193	1.7558	2.268
19	2.5972	1.829	1.9387	1.9753	1.9022	2.3411	2.268
20	2.4874	2.1948	2.268	2.0485	2.0485	2.268	2.3411
21	2.524	2.4874	2.4143	2.1948	2.1948	2.4874	2.3411
22	2.4874	2.4874	2.4874	2.3045	2.3411	2.5606	2.4874
23	2.5972	2.6337	2.5972	2.268	2.4143	2.6337	2.4874
24	1.829	2.1582	2.3411	2.4508	2.268	2.3045	2.3411
Max	2.5972	2.6337	2.5972	4.4993	2.4143	2.6337	2.4874
Min	1.39	1.4632	.7316	1.5364	1.4632	1.6827	1.4632
Avg	1.8509	1.8656	1.8624	2.4133	1.8808	1.9997	1.9403

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. URBAN S/DN[156] BU 4341

Substation No/ Name :- 283210 / 22/22KV PAPDI SWITCHING

Feeder No / Name : 357 / MULGAON

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0242	3.8409	3.219	3.5848	3.5848
2		.9511	3.6214	3.1459	3.4019	3.3653
3		.9145	3.4751	3.0727	3.2922	3.3653
4		.8779	3.3653	3.0727	3.0727	3.2922
5		.9145	3.2922	2.9995	3.1459	3.2922
6		.9511	3.5117	3.0727	3.2922	3.5117
7		3.7311	3.2922	2.9995	3.1459	3.4385
8		3.3653	3.1093	2.9995	3.0727	3.219
9		2.9995	2.9995	2.9264	3.1093	3.1093
10		2.9995	3.0361	2.7801	3.1824	3.219
11		2.8532	3.219	2.9264	3.0361	3.219
12		2.7069	.7316	2.8166	3.0727	2.9264
13		2.7435	.6584	2.6337	2.9264	2.9995
14		2.7801	.7316	2.8532	3.0727	2.9264
15		3.0361	.7316	2.963	3.0727	2.7801
16		2.963	.6584	2.7801	2.9995	3.1459
17		3.0727	.6584	2.7801	2.9995	3.1459
18		2.9264		2.8898	2.9995	2.9995
19	1.2803	3.5117	.7316	3.3288	3.7311	.9511
20	1.2437	4.0969	3.8043	3.8409	4.0969	4.0238
21	1.1706	4.1701	3.7311	3.9506	4.1701	4.0969
22	1.2437	4.2433	3.658	3.9872	4.3164	4.3896
23	1.2437	4.4627	3.658	4.0604	4.3896	4.0969
24		1.0974	4.2433	3.5848	3.7677	4.0238
Max	1.2803	4.4627	4.2433	4.0604	4.3896	4.3896
Min	1.1706	.8779	.6584	2.6337	2.9264	.9511
Avg	1.2364	2.6414	2.6417	3.1535	3.3730	3.2968



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. URBAN S/DN[156] BU 4341

Substation No/ Name :- 283210 / 22/22KV PAPDI SWITCHING

Feeder No / Name : 358 / GIRIJ

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0562	1.0562	1.2071	1.0562	1.2071	1.0562
2		.9054	1.0562	1.2071		1.0562	.9054
3		.9054	1.0562	1.0562	.9054	1.0562	.9054
4		.9054	1.0562	.9808	.9054	1.0562	.9054
5		.9054	1.0562	.9054	.9054	.9808	.9054
6		.9808	1.0562	.9808	1.0562	1.0562	1.0562
7		1.0562	.9054	.9808	.9054	.9808	.9054
8	.9054	.9054	.9054	.9054	.9054	.9054	.9054
9	.9054	.9054	1.0562	1.0562	.9054	1.0562	.9054
10	.9054	.9054	1.0562	1.0562	1.0562	1.0562	1.0562
11	1.0562		1.0562	1.0562	1.0562	1.2071	1.0562
12	1.0562		1.2071	.9054	1.2071	1.2071	1.2071
13	1.0562		1.0562	1.0562	1.2071	1.2071	1.0562
14	1.0562	1.0562	1.0562	1.0562	1.0562	1.0562	1.2071
15	1.0562		1.2071	1.0562	1.0562	1.0562	1.4335
16	1.0562	1.0562	1.0562	1.0562	1.0562	1.0562	1.5089
17	1.2071	1.2071	1.2071	.9054	1.0562	1.0562	1.2071
18	1.2071	1.2071	1.2071		1.2071	1.2071	1.2071
19	1.358	1.358	1.358	1.2071	1.2071	1.358	1.2071
20	1.5089	1.5089	1.5089	1.5089	1.5089	1.5089	1.2071
21	1.5089	1.6598	1.5089	1.5089	1.5089	1.5089	1.2071
22	1.5089	1.6598	1.5089	1.358	1.5089	1.358	1.2071
23	1.358	1.5089	1.358	1.358	1.358	1.358	1.2071
24	1.0562	1.0562	1.2071	1.358	1.2071	1.2071	1.358
Max	1.5089	1.6598	1.5089	1.5089	1.5089	1.5089	1.5089
Min	.9054	.9054	.9054	.9054	.9054	.9054	.9054
Avg	1.1627	1.1355	1.1568	1.1186	1.1218	1.1568	1.1160

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. WEST S/DN.[697] BU 4697

Substation No/ Name :- 283507 / SUNCITY SWITCHING SUBSTATION

Feeder No / Name : 300 / STATION TRANSFORMER FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.5716	.381	.4954	.3734	.4191	.4191
2	.3734	.5716	.381	.4572	.3734	.4191	.4572
3	.3734	.5716	.381	.4572	.381	.4191	.4191
4	.3734	.5716	.4191	.4954	.381	.4191	.4572
5	.3734	.4572	.4191	.4572	.381	.4191	.4191
6	.3734	.1524	.381	.4572	.3734	.4191	.4191
7	.3734	.1524	.3429	.1143	.112	.4572	.4191
8	.112	.1524	.381	.1143	.112		.4191
9	.112	.1524	.381	.0762	.112	.4191	.4191
10	.1524	.4191	.4191	.1143	.112	.4191	.1143
11	.1524	.4191	.1143	.112	.1905	.3429	.1143
12	.1524	.3048	.0762	.112	.1905	.4191	.0762
13	.1524	.3048	.1143		.1524	.4191	.0762
14	.1524	.381	.1143	.112	.1524	.381	.0762
15	.1524	.4191	.1143	.112	.1524	.4191	.0762
16	.1524	.4572	.1143	.112	.1524		.1143
17	.1524	.4191	.1143	.112	.1905	.3048	.1143
18	.1524	.4191	.1143	.112	.1905	.4191	.0762
19	.5716	.4191	.1143	.1143	.4572		.1905
20	.5716		.5335	.4108	.5716		.5335
21	.5716	.4572	.5716	.4108	.4191		.5716
22	.5716	1.0669	.5335	.3734			.5335
23	.5716	.4191	.5335	.3734		.4954	.4954
24	.4108	.5716	.381	.5335	.3734	.4572	.4572
Max	.5716	1.0669	.5716	.5335	.5716	.4954	.5716
Min	.112	.1524	.0762	.0762	.112	.3048	.0762
Avg	.3116	.4274	.3096	.2713	.2684	.4149	.3112

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. WEST S/DN.[697] BU 4697

Substation No/ Name :- 283507 / SUNCITY SWITCHING SUBSTATION

Feeder No / Name : 303 / Chulna Road SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0102	3.5056	3.8104		3.4675	3.5056	3.4294
2	2.8959	3.2769	3.4294	2.1338	3.3532	3.2388	2.934
3	2.8197	3.0102	3.2007	1.7147	3.0864	3.2007	3.0483
4	2.7816	3.1245	3.1245	1.6004	3.0102	3.2388	2.934
5	3.0483	3.2007	3.2388	1.5242	2.9721	3.0483	2.934
6	3.3913	3.2769	3.658	1.448	2.934	2.9721	3.1626
7	3.2388	3.5056	3.4675	1.4861	3.3913	3.0483	3.2007
8	3.315	3.315	3.4675	4.1152	3.3913	3.2769	3.1626
9	3.0102	2.7816	3.5437	3.8485	3.3913	3.315	
10	3.0102	8.8402	3.2388	2.8578	3.2769	3.2769	3.0864
11	3.1245	7.0112	3.2007	2.7054	3.2769	3.4294	3.0483
12		3.2007	3.2007		3.315	3.3532	2.934
13	2.934	3.1626	3.0864		3.1245	3.1245	2.8959
14	2.9721		3.2007	3.9247	3.0102	3.1245	2.934
15	2.9721	3.2388	3.1245	3.5437	3.1245	3.0102	2.6292
16	2.8578	3.0483	3.0864	3.1245	3.0102	3.0483	2.5911
17	3.0102	3.1626	4.4582	3.2769	3.0102	3.1245	2.7816
18	3.2769	3.2388	4.2676	3.4294	3.2769	3.0864	3.0864
19	3.658	.6859	3.8866	4.3058	3.5437		3.3532
20	4.2295	4.382	4.2676	4.0771	4.1533		4.382
21	4.4963	4.5725	4.6106	4.1533	4.1914	4.2676	4.1152
22	4.382	4.6868	4.6868	4.4582	4.1914	4.1914	4.1914
23	4.1914	4.5725	4.763	4.2295	3.9628	4.3439	4.0771
24	3.3913	3.9247	4.039	4.3058	3.7723	3.2388	4.1914
Max	4.4963	8.8402	4.763	4.4582	4.1914	4.3439	4.382
Min	2.7816	.6859	3.0864	1.448	2.934	2.9721	2.5911
Avg	3.3051	3.7706	3.6691	3.1554	3.3849	3.3393	3.2653

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

VASAI RD. WEST S/DN.[697] BU 4697

Substation No/ Name :- 283507 / SUNCITY SWITCHING SUBSTATION

Feeder No / Name : 304 / Station Road

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3624	2.6292	2.6673	3.0102	1.7147	2.8197	3.3913
2	2.21	2.8578	2.4768	2.6673	1.7909	2.6673	2.2481
3	2.1338	3.2007	2.4768	2.4768	1.8671	2.4768	2.553
4	2.0576	3.1626	2.3624	3.5818	1.9814	2.4387	2.2481
5	2.1338	3.2007	2.2862	3.6199	2.1338	2.4768	2.2862
6	2.4768	3.0483	2.5911	3.5437	2.5149	2.4387	2.4006
7	2.5911	2.8197	2.8578	3.9628	2.7816	2.6673	2.6292
8	2.7816	2.8578	2.9721	4.0771	2.8959	2.8578	3.0102
9	3.1626	3.2007	3.2769	4.3058	2.8197	2.7816	
10	3.7342	3.9247	4.0009	4.5344	3.2388	3.5056	3.7342
11	4.2295	4.4963	4.6487	4.5725	3.6199	3.7723	4.039
12	4.1533		3.4675	4.6487	3.7723	3.8104	4.1914
13	4.1533		4.3439		3.658	3.7342	4.039
14	4.0009	4.4582	4.2676		3.3532	3.3532	3.8104
15	4.0009	4.5725	4.4582		2.21	3.3532	3.7723
16	4.1152	4.5725	4.6106		4.1533	3.0483	3.7723
17	4.4201		4.6868	3.5818	4.0009	3.3532	
18	4.4963		4.4963	.6097	4.1914	3.5818	4.5725
19	4.7249	4.9535	4.8773	4.5725	4.2295		4.5725
20	4.8773	4.9535	4.8011	4.4963	4.3439		4.3439
21	4.382	4.6487	4.5344	4.1152	4.1533	4.1914	4.0009
22	3.6961	3.8104	3.8104		3.6199	3.5818	3.5818
23	3.3532	3.4675	3.5437		3.5056	3.3532	3.315
24	2.5911	2.934	3.1626	3.315		3.2388	3.315
Max	4.8773	4.9535	4.8773	4.6487	4.3439	4.1914	4.5725
Min	2.0576	2.6292	2.2862	.6097	1.7147	2.4387	2.2481
Avg	3.4516	3.6885	3.6532	3.6495	3.1543	3.1592	3.4467

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

WADA S/DN.[158]

BU 4158

Substation No/ Name :- 283516 / 22/22 KV COCA COLA S/W

STATION

Feeder No / Name : 301 / 22KV CHINCHGHAR FEEDER

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

Feeder KV- 22 / OUTGOING

(NON CONTINOUS PROCESS)(NO

STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7167	.8676	2.3011	1.094	.7202	.8676	.823
2	.679	.7922	2.2634	1.094	.7545	.8299	.8573
3	.679	.7545	2.2257	1.0562	.6859	.7922	.823
4	.7167	.7167	2.3388		.6859	.7922	.823
5	.7545	.7922	2.3765	.9808	.7545	.8299	.8916
6	.8299	.9054	2.452	.9431	.7545	.9054	.9259
7	.9808	1.0185	2.5652	.9431	.8916	.9808	1.0631
8	.9808	2.1124	2.7915	.9808	.8916	1.1694	1.0631
9	.9431	1.8108	2.7161	.9808		2.1605	.9602
10	.9808	.9054	5.2435	.9431	.9431	1.0288	.8916
11	.9054	.9431	2.5274	.8299	.9054	.9945	.9602
12	.9054	1.0562	2.6029	.6036	.9054	.9602	.9602
13	.8299	.8755	2.3765	.7202	.8299	.9259	.8916
14	.7922	.8676	2.1502	.679	.7545	.8916	.823
15	.8299	.8676	2.4143	.5487	.7167	.8573	.8573
16	.7545	.8676	2.3765	.6036	.6413	.8573	.823
17	.8676	1.8484	2.4362	.6173	.7167	.823	.7888
18	1.0185	2.5652	2.2257	.6413	.8676	1.0288	.9259
19	1.0562	2.7538	2.4143	.8573	1.0185	.9945	1.0974
20	1.2071	2.9801	1.2826	.8916	1.1694	1.1317	1.0974
21	1.0562	2.7915	1.3203	.8573	1.0185	1.0631	1.0288
22	1.0562	2.6783	1.4746	.823	.9431	1.0288	.9945
23	.9808	2.5274	1.2449	.7545	.9054	.9259	.9602
24	1.4334	.8676	4.8502	1.1317	.7545	.8676	.8916
<b>Max</b>	<b>1.4334</b>	<b>2.9801</b>	<b>5.2435</b>	<b>1.1317</b>	<b>1.1694</b>	<b>2.1605</b>	<b>1.0974</b>
<b>Min</b>	<b>.679</b>	<b>.7167</b>	<b>1.2449</b>	<b>.5487</b>	<b>.6413</b>	<b>.7922</b>	<b>.7888</b>
<b>Avg</b>	<b>.9148</b>	<b>1.4652</b>	<b>2.4571</b>	<b>.8511</b>	<b>.8360</b>	<b>.9878</b>	<b>.9259</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

WADA S/DN.[158]

BU 4158

Substation No/ Name :- 283516 / 22/22 KV COCA COLA S/W

STATION

Feeder No / Name : 302 / 22KV COCACOLA EXPRESS

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9801	3.7723	2.7161	2.8669	.6516	2.2257	2.4691
2	2.7915	3.6591	2.8292	2.9801	.6173	2.3011	2.9492
3	2.8669	3.81	2.6783	2.8292	.6173	2.1502	2.915
4	3.0556	3.6214	2.7161	2.9424	.6859	2.3765	2.9835
5	3.131	3.5082	2.6406	2.3388	.6859	2.2634	2.7435
6	3.2442	2.9801	2.5652	1.2071	.6859	2.1125	2.5034
7	2.7538	2.4897	2.3765	.8299	.823	1.7353	2.1262
8	3.0556	2.8292	3.0933	.7167	.9259	1.8484	2.7092
9	3.546	2.7915	3.5837	.4904		1.9204	2.6749
10	3.5837	2.8292	2.6029	.4904	1.358	2.0919	2.0576
11	2.7915	3.2819	2.4143	.5281	1.6598	1.8861	2.8464
12	2.9801	3.2819	3.6591	.5281	1.8484	2.2634	2.1262
13	3.7346	2.5652	2.9424	.4801	1.5844	2.6406	2.5377
14	3.131	3.2442	2.7915	.4458	2.2257	2.2291	2.1605
15	3.0933	2.4897	2.452	.4458	1.8861	2.2977	1.749
16	3.6591	2.5652	3.1687	.5281	2.2634	2.7778	1.5775
17	3.6214	2.4897	3.3573	.4458	1.9239	2.2977	1.6118
18	3.7723	2.6783	3.1687	.4801	2.037	2.7435	2.0576
19	3.81	3.2819	3.9609	.4801	2.3765	2.572	2.2634
20	3.81	3.2819	2.9424	.6173	2.6029	3.0864	2.572
21	3.3196	3.3196	3.0556	.6173	2.3765	2.9835	2.6406
22	3.7346	3.1687	2.8669	.583	2.1502	2.4006	2.4348
23	3.6214	2.9801	2.7915	.6173	1.9239	2.332	1.9204
24	2.7538	3.5837	2.5652	3.2819	.6516	2.8669	2.5377
<b>Max</b>	<b>3.81</b>	<b>3.81</b>	<b>3.9609</b>	<b>3.2819</b>	<b>2.6029</b>	<b>3.0864</b>	<b>2.9835</b>
<b>Min</b>	<b>2.7538</b>	<b>2.4897</b>	<b>2.3765</b>	<b>.4458</b>	<b>.6173</b>	<b>1.7353</b>	<b>1.5775</b>
<b>Avg</b>	<b>3.2850</b>	<b>3.1043</b>	<b>2.9141</b>	<b>1.1571</b>	<b>1.5027</b>	<b>2.3501</b>	<b>2.3820</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

WADA S/DN.[158]

BU 4158

Substation No/ Name :- 283516 / 22/22 KV COCA COLA S/W

STATION

Feeder No / Name : 303 / 22KV ONIDA FEEDER

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

Feeder KV- 22 / OUTGOING

(NON CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9047	2.9424	2.8292		.6516	2.1502	2.332
2	2.6029	2.6029	2.8669	1.9993	.6173	2.3765	2.2977
3	2.7915	2.8292	2.6406	2.037	.6516	2.2257	2.332
4	2.5274	2.452	2.7538	1.9239	.6516	2.452	2.4006
5	2.3765	2.6406	2.7161	1.6221	.7545	2.5652	1.8861
6	1.5466	2.7161	2.5652	1.2449	.7888	2.452	1.4403
7	2.4143	1.9616	3.131	1.1317	.823	1.9239	1.8176
8	2.9424	1.8861	1.6975	.7167	.9602	1.2826	3.0521
9	1.9993	2.0748	2.2634	.7167		1.3032	1.3375
10	2.0748	2.1502	2.3388	.7167	1.5844	1.3717	1.9204
11	2.1502	2.1502	2.1125	.7167	1.5089	1.4403	1.9547
12	1.8484	1.9993	1.9993	.679	1.4335	1.3717	1.9547
13	1.8861	2.0748	1.8484	.6173	1.5089	1.2689	1.7833
14	1.9239	2.3011	1.9616	.679	1.7353	1.406	1.5775
15	2.0748	2.0556	1.9616	.583	1.8861	1.3032	1.8176
16	2.1879	2.1502	2.2634	.583	1.6598		1.6461
17	1.7353	1.773	2.1125	.583	1.2826	1.3032	1.8519
18	1.6975	1.773	1.6221	.5487	1.2826	1.2003	1.4403
19	1.8107	1.5844	1.6221	.6173	1.2071	1.3375	1.7353
20	2.452	2.2257	2.2257	.6516	1.8107	1.7833	1.6804
21	2.9424	2.6029	2.2257	.6516	2.1502	2.4691	2.5034
22	2.9801	2.2257	2.4143	.6516	1.6975	1.6461	2.8121
23	2.5274	2.9424	1.9993	.6859	2.037	1.5089	2.6406
24	2.7161	2.3388	3.3573	1.9616	.6516	1.8861	2.1605
<b>Max</b>	<b>2.9801</b>	<b>2.9424</b>	<b>3.3573</b>	<b>2.037</b>	<b>2.1502</b>	<b>2.5652</b>	<b>3.0521</b>
<b>Min</b>	<b>1.5466</b>	<b>1.5844</b>	<b>1.6221</b>	<b>.5487</b>	<b>.6173</b>	<b>1.2003</b>	<b>1.3375</b>
<b>Avg</b>	<b>2.2964</b>	<b>2.2689</b>	<b>2.3137</b>	<b>.9704</b>	<b>1.2754</b>	<b>1.7403</b>	<b>2.0156</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

WADA S/DN.[158]

BU 4158

Substation No/ Name :- 283516 / 22/22 KV COCA COLA S/W

STATION

Feeder No / Name : 304 / 22 KV PRIYADARSHANI FEEDER NON SHEDDABLE EHV INDUSTRIAL FEEDERS

Feeder KV- 22 / OUTGOING

(NON CONTINOUS PROCESS)(NO  
STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.1687	3.546	4.1495	2.8292	1.8861	2.6029
2	3.131	3.4328	3.6969	2.9801	1.7353	2.9424
3	3.2819	3.2065	3.0833	3.0556	1.8107	3.0933
4	2.9801	3.3573	2.9424	2.8669	1.8107	2.8669
5	3.131	3.2819	2.7161	2.7161	1.8861	2.7161
6	3.2819	3.2065	2.5652	2.6406	1.9239	2.452
7	2.7161	2.9047	2.3765	2.2257	2.037	2.1879
8	2.3388	3.4705	2.6406	2.037	2.4897	1.9239
9	4.8285	3.5082	4.489		3.131	3.7346
10	5.0926		3.6214			
11	5.3944		3.4705			
12	3.8855		4.4136		1.8861	
13	3.8855		2.6029		1.2071	
14	2.9424		4.0741		3.4705	
15	3.7723		4.1495		3.2442	
16	4.0741		4.5679		4.489	
17	3.546	4.1118	3.9609		2.8292	
18	4.1495	3.9986	4.8285		3.3196	
19	4.489	5.3944	5.5076		3.2819	
20	4.4136	4.7908	6.0357		3.1687	
21	3.7346	4.7154	3.8827		4.1872	
22	3.6214	4.5645	5.6962		3.2065	
23	3.3573	3.7685	5.0549		4.3004	
24	3.3573	2.8669	4.3381	3.4328	1.8861	3.2819
<b>Max</b>	<b>5.3944</b>	<b>5.3944</b>	<b>6.0357</b>	<b>3.4328</b>	<b>4.489</b>	<b>3.7346</b>
<b>Min</b>	<b>2.3388</b>	<b>2.8669</b>	<b>2.3765</b>	<b>2.037</b>	<b>1.2071</b>	<b>1.9239</b>
<b>Avg</b>	<b>3.6906</b>	<b>3.7721</b>	<b>3.9527</b>	<b>2.7538</b>	<b>2.6903</b>	<b>2.7802</b>



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

WADA S/DN.[158]

BU 4158

Substation No/ Name :- 283516 / 22/22 KV COCA COLA S/W

STATION

Feeder No / Name : 305 / 22 KV KHARIWALI FEEDER

SHEDDABLE FEEDER HAVING WEEKLY

Feeder KV- 22 / OUTGOING

STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.094	1.094	1.1317	1.1317	.9259	1.094	1.2003
2	1.094	1.0185	1.0658	.9808	.8916	1.0562	1.0288
3	1.0562	.9808	1.0278	.9054	.9259	1.0562	.9945
4	1.0185	1.0185	1.094	.9808	.8573	1.0185	1.0288
5	1.2449	1.094	1.1317	1.1317	1.0288	1.0562	1.0974
6	1.4335	1.3203	1.2449	1.2826	1.0974	1.094	1.2346
7	1.6221	1.5844	1.3957	1.3957	1.2689	1.358	1.3375
8	1.4712	1.5466	1.5089	1.3203	1.2689	1.3957	1.4746
9	1.6975	1.5089	1.773	1.2449		1.4712	1.6118
10	1.5466	.5658	2.037	1.094	1.094	1.4403	1.989
11	1.6975		1.8484	.9808	1.0562	1.8484	1.7833
12	2.037	2.1125	2.037	.9808	1.6598	1.989	1.9547
13	2.2257	1.6221	1.8861	.8676	1.6221	1.6461	1.9204
14	1.3203	1.2449	1.2071	.7545	1.2449	1.3717	1.2003
15	1.2071	1.9239	1.4712	.7545	1.358	1.3032	1.2003
16	1.6598		2.3388	.8676	.7922	1.8176	1.3717
17	1.6975	1.8861	1.8861	.8916	2.037	1.5089	1.749
18	2.2634	2.1125	2.2634	.9602	1.9616	1.749	2.0576
19	1.9993	2.1125	2.452	1.2003	1.6975	1.6804	1.5089
20	1.4712	1.4335	1.4846	1.166	1.4335	1.3717	1.406
21	1.8484	1.4712	1.3957	1.0974	1.2449	1.3032	1.2689
22	1.2826	1.358	1.358	1.1694	1.2826	1.2689	1.2003
23	1.1694	1.2449	1.2449	.9945	1.1317	1.0974	1.0974
24	1.1317	1.0562	1.1317	1.2071	.9602	1.094	1.0974
Max	2.2634	2.1125	2.452	1.3957	2.037	1.989	2.0576
Min	1.0185	.5658	1.0278	.7545	.7922	1.0185	.9945
Avg	1.5121	1.4232	1.5590	1.0567	1.2540	1.3787	1.4089

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

WADA S/DN.[158]

BU 4158

Substation No/ Name :- 283516 / 22/22 KV COCA COLA S/W

STATION

Feeder No / Name : 306 / 22 KV DHODIA EXPRESS

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3395	.3018	.3018	.2401	.3395	.3086
2	.3395	.3772	.2641	.3018	.2401	.3395	.2743
3	.2103	.3772	.2263	.3018	.2401	.3018	.2743
4	.3018	.3395	.2641	.3395	.2401	.3018	.2743
5	.3395	.3018	.2641	.3395	.2743	.3018	.3086
6	.3395	.2641	.2641	.2641	.2401	.2641	.2743
7	.2263	.3018	.2641	.3018	.2743	.3018	.2743
8	.2641	.415	.3395	.2641	.2743	.3018	.2743
9	.7167	.6036	.8299	.2641		.3395	.4115
10	.7922	.7922	.5658	.3395	.3018	.2058	.4801
11	.679		.5281	.3086	.3395	.3086	.4801
12	.7922	.2263	.8299	.2641	1.8484	.3772	.5144
13	.6036	.6036	.7167	.2401	.3395	.3429	.4458
14	.679	.7545	.6036	.2743	.3395	.2401	.4115
15	.679	.5658	.7922	.3086	.3772	.2743	.5144
16	.7545	.7545	.8676	.3429	.3018	.2401	.5487
17	.5658	.7545	.5658	.2743	.415	.3086	.5144
18	.415	.5281	.4527	.3086	.3772	.3086	.4801
19	.3772	.4527	.4527	.3086	.3018	.2743	.3086
20	.3772	.3395	.3772	.3086	.3395	.3086	.3429
21	.3018	.3772	.3772	.2743	.3395	.2743	.3429
22	.2641	.2641	.3018	.2743	.2263	.2743	.3086
23	.2641	.3018	.3018	.3086	.3395	.3429	.4115
24	.3395	.2641	.3395	.3018	.2401	.3018	.3086
Max	.7922	.7922	.8676	.3429	1.8484	.3772	.5487
Min	.2103	.2263	.2263	.2401	.2263	.2058	.2743
Avg	.4567	.4478	.4621	.2965	.3674	.2989	.3786

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

WADA S/DN.[158]

BU 4158

Substation No/ Name :- 283516 / 22/22 KV COCA COLA S/W

STATION

Feeder No / Name : 307 / ESSEL PROPACK EXPRESS

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9054	.8676	.7922	.9054	.7545	.9808	.7888
2	.9054	.8676	.8299	.9808	.7888	.9431	.7888
3	.8676	.9054	.9054	.9431	.7545	.9431	.7545
4	.8299	.8676	.9808	.9054	.7888	.9431	.7545
5	.8299	.8676	.8676	.8676	.823	.9054	.7888
6	.7922	.8299	.8676	.8299	.823	.9054	.8573
7	.7545	.8299	.9431	.8676	.823	.8299	.823
8	.8299	.8676	.9808	.8299	.7888	.9431	.7888
9	.8299	.9054	1.0185	.9054		.9431	.823
10	.8299	.7545	1.0185	.8676	.8676	.8573	.8573
11	.9808	.8676	.9808	.9431	.8299	.8573	.8573
12	.9431	.8676	.9808	.8676	.9054	.9808	.7888
13	.9054	.7922	.9808	.823	.9054	.8573	.8916
14	.8299	.8676	.9431	.8573	.9054	.823	.823
15	.8676	.8299	.9431	.7545	.9054	.7888	.7888
16	.9431	.9054	.9431	.7888	.9808	.8916	.8573
17	.8676	.9431	.9808	.7888	.9054	.8573	.7545
18	.9054	.8676	1.0185	.7888	1.0185	.8573	.8573
19	.9808	.9054	.9808	.7888	1.0185	.8573	.8916
20		.9431	.9808	.823	.9431	.823	.8916
21	.8676	.8676	.9808	.7888	.9808	.8573	.7888
22	.8676	.9431	.9431	.7888	.8676	.9054	.823
23	.8676	.9054	.8676	.7888	.9431	.7888	.8573
24	.8676	.8299	.8676	.8676	.7888	.9808	.8573
Max	.9808	.9431	1.0185	.9808	1.0185	.9808	.8916
Min	.7545	.7545	.7922	.7545	.7545	.7888	.7545
Avg	.8726	.8708	.9415	.8484	.8744	.8883	.8230

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

WADA S/DN.[158]

BU 4158

Substation No/ Name :- 283519 / 22/22 KV ASPEE SW/STN

Feeder No / Name : 301 / 22 KV DAKIWALI INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	25-AUG-17
HR	Load (MW)
24	2.4006
Max	2.4006
Min	2.4006
Avg	2.4006

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

WADA S/DN.[158]

BU 4158

Substation No/ Name :- 283519 / 22/22 KV ASPEE SW/STN

Feeder No / Name : 303 / 22 KV TANASA FEEDER

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.4115	.5281	.4458	.2058	.4115	.4115
2	.3772	.3429	.5281	.4115		.4458	.3772
3	.3429	.3395	.415	.3772		.3429	.3429
4	.3086	.3018	.3772	.3429		.2743	.3429
5	.3086	.2641	.3772	.3086	.2058	.2401	.3086
6	.3086	.2263	.415	.2743	.2058	.2743	.4115
7	.3772	.2263	.3395	.2401	.2058	.2743	.3772
8	.3086	.3395	.4527	.2058	.2058	.3086	.3772
9	.583	.4527	.583	.2058	.4801	.583	.6173
10	.6859	.7167	.7202	.2058	.6173	.6173	.6173
11	.6859	.8299	.7888	.2058	.6859	.6516	.7888
12	.6859	.7545	.7545	.2058	.6859	.6859	.7545
13	.6173	.5658	.9602		.6859	.6173	.6516
14	.7545	.7545	.7202		.4801	.7545	.6859
15	.7202	.7545	.7545	.2058	.6516	.6859	.6859
16	.6173	.7167	.583		.7202	.7202	.6516
17	.583	.6413	.583		.7545	.6859	.6859
18	.6516	.679	.6859		.583	.6516	.7202
19	.6516	.6036	.5144		.583	.583	.7545
20	.583	.6036	.9945		.5144	.5487	.4458
21	.4801	1.2449	.4458		.5487	.6859	.3772
22	.4458	.415	.4458		.5144	.6173	.4115
23	.4115	.5658	.4801		.5144	.583	.4115
24	.3429	.4115	.4527	.4801		.4801	.4801
Max	.7545	1.2449	.9945	.4801	.7545	.7545	.7888
Min	.3086	.2263	.3395	.2058	.2058	.2401	.3086
Avg	.5087	.5484	.5791	.2940	.5024	.5301	.5287

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

WADA S/DN.[158]

BU 4158

Substation No/ Name :- 283519 / 22/22 KV ASPEE SW/STN

Feeder No / Name : 304 / 22 KV MUSARNE FEEDER

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.166	1.2003	1.5089	.8573	.3772	1.0974	.7888
2	1.1317	1.0974	1.094	.9945	.3772	1.2346	.9259
3	.9945	1.1317	1.3203	1.2003	.3772	1.0288	.823
4	1.0974	1.0562	1.5844	1.0288	.4458	.8573	.823
5	1.0974	1.094	1.4335	1.0631	.5144	.9945	1.0631
6	1.2346	1.2449	1.2449	.8916	.5144	1.0974	.9259
7	1.2003	1.1317	1.0562	.9259	.5487	.9259	.9602
8	1.166	1.5466	.5658	.823	.6859	.9259	.9259
9	.823	1.0562	.8299	.4801	.9259	.823	.7202
10	.8916	.9808	1.166	.5144	1.0288	.7545	.823
11	.8573	.2641	.9259	.5144	.823	.6516	.6859
12	.823	1.0185	.9259	.4801	.8916	.6859	.8573
13	.6516	.9808	.9602	.4115	.8916	.6516	.6516
14	.7888	.9808	.9945	.4115	.9945	.6859	.6516
15	.823	.9431	.8916	.3772	.8573	.583	.7888
16	.823	1.094	.9945	.4115	.9259	.6173	.8916
17	.7545	.9431	.9259	.4458	.823	.4115	.9259
18	.7888	.9431	.7888	.4115	.6516	.5144	.9259
19	.7888	.8676	.7545	.4458	.6516	.6173	.7888
20	.9945	1.1317	.9945		.7888		.6859
21	1.166	1.2449	1.2689	.3429	1.0631	.8573	1.0974
22	1.0631	1.5089	1.406	.3772	1.2003	.8916	1.0288
23	1.4403	1.358	1.0288	.3772	1.2003	.8573	.9602
24	1.0631	1.3032	1.358	1.1317	.3772	1.166	
Max	1.4403	1.5466	1.5844	1.2003	1.2003	1.2346	1.0974
Min	.6516	.2641	.5658	.3429	.3772	.4115	.6516
Avg	.9845	1.0884	1.0842	.6486	.7473	.8230	.8573

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

WADA S/DN.[158]

BU 4158

Substation No/ Name :- 283519 / 22/22 KV ASPEE SW/STN

Feeder No / Name : 305 / 22 KV BHARATIYA FEEDER

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	23-AUG-17
HR	Load (MW)
22	.6413
Max	.6413
Min	.6413
Avg	.6413

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

WADA S/DN.[158]

BU 4158

Substation No/ Name :- 283519 / 22/22 KV ASPEE SW/STN

Feeder No / Name : 306 / 22KV HIL EXPRESS

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.583	.5658	
2	.2058	.583		
3	.3429	.6036	.6036	
4	.5144	.6036	.5658	
5	.5144	.6036	.5658	
6	.4801	.6036	.5658	
7	.5144	.5281	.5658	
8	.5487	.6036	.6036	
9	.5487	.6036	.6413	
10	.583	.6036	.6173	
11	.3086	.7167	.5487	
12	.5487	.7167	.5144	.1372
13	.6173	.6036	.4115	
14	.5487	.6413	.5144	
15	.5487	.6036	.5144	
16	.583	.5281	.4801	
17	.6516	.6413	.4801	
18	.5144	.6413		
19	.583	.6413		
20	.5487	.6413		
21	.5144	.6036		
22	.5144	.6413		
23	.5487	.5658		
24	.3772	.6516	.6413	
Max	.6516	.7167	.6413	.1372
Min	.2058	.5281	.4115	.1372
Avg	.4958	.6149	.5529	.1372



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

WADA S/DN.[158]

BU 4158

Substation No/ Name :- 288055 / 220/22 KV WADA SUBSTN

Feeder No / Name : 301 / 22 KV AMBADI FEEDER

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.8861		1.5432	.9602		
2		1.8519					
6					1.1317		1.7147
7		2.1605	1.7833	1.3032	1.1317	1.4403	1.6118
8	2.2291	2.2291	2.0576	1.0974	1.2003	1.6118	1.8519
9		2.572	.9259	1.0974			
10	2.5034	2.4348	2.1948	1.0974	1.6118	2.0919	2.4006
11		2.6063	2.2977	.9945	1.749	2.1262	2.4006
12	2.2291		2.2291	.8916	1.5432	2.2634	2.2291
13		2.1262		.8916		2.2634	2.1605
14				.8573			2.3663
15		2.4691	2.3663			1.989	2.4348
16			2.332	.7888	1.5432		2.4006
17		2.572	2.2977	.8573			2.4006
18			2.1948				2.4348
19		2.2291		.9945	1.8176		2.3663
20		2.2291		1.0974	2.0919	1.9547	2.2291
21		2.0576	1.989	1.0631	1.7147		2.1262
22	2.1605	2.1948	1.9547	.9945	1.5432	1.989	1.9547
23	1.9204	2.1948		.9945	1.5432	1.8861	2.0576
24		2.0233	1.8861	1.749	.8916	1.5089	1.749
Max	2.5034	2.6063	2.3663	1.749	2.0919	2.2634	2.4348
Min	1.9204	1.8519	.9259	.7888	.8916	1.4403	1.6118
Avg	2.2085	2.2398	2.0392	1.0772	1.4624	1.9204	2.1605

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

WADA S/DN.[158]

BU 4158

Substation No/ Name :- 288055 / 220/22 KV WADA SUBSTN

Feeder No / Name : 302 / 22 KV KALAMBHA FEEDER

SHEDDABLE FEEDER HAVING WEEKLY

Feeder KV- 22 / OUTGOING

STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		12.9973		12.6543	11.2826		
2		11.7627					
6					10.4938		11.0082
7			11.1454	10.5967	10.974	7.8532	11.6941
8	10.391	7.5103	10.8025	10.4595	9.225	10.7682	12.0028
9	10.8025		11.4884	10.9054			
10	7.476	11.8313	9.0535	5.6927	6.7215	6.0014	6.5158
11		11.1111	7.1331	8.5734	9.6022	5.8299	9.225
12	9.225		9.5336	8.882	9.6022	8.882	9.9451
13	9.0535	9.4993		7.7504		6.4815	9.2593
14				8.7106			8.7792
15		9.0535	8.9506			9.3622	8.882
16				8.0933	8.9849		9.3622
17		9.6365		8.5391			9.7051
18			7.9218				9.7051
19		9.3622		8.5734	9.465		10.1509
20		9.9451		9.2593	9.5679	10.0137	9.1221
21		9.808	8.7449	9.2593	9.6022		10.7339
22	11.6255	11.1454	11.7627	10.048	10.5281	11.4198	12.1742
23	12.2085	12.6886		11.5226	12.6886	12.4486	12.9973
24		7.6475	11.4198	11.8656		11.4541	12.38
Max	12.2085	12.9973	11.7627	12.6543	12.6886	12.4486	12.9973
Min	7.476	7.5103	7.1331	5.6927	6.7215	5.8299	6.5158
Avg	10.1117	10.2856	9.8142	9.4933	9.9029	9.1377	10.2024

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

WADA S/DN.[158]

BU 4158

Substation No/ Name :- 288055 / 220/22 KV WADA SUBSTN

Feeder No / Name : 303 / 22 KV INDUSTRIAL FEEDER

SHEDDABLE FEEDER HAVING WEEKLY

Feeder KV- 22 / OUTGOING

STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9602		1.3032	1.2346		
2		.9945					
3					1.2346		
6					1.2003		1.166
7		1.0974	1.1317	1.166	1.3375	1.0974	1.1317
8	1.3032	1.2003	1.0974	1.166	1.2346	1.1317	.8573
9	1.3717	1.5775	2.0233				
10	1.989	2.0919	1.6461		1.3717	1.2689	2.1948
11		1.7833	2.0233	1.0631	1.3375	1.3375	1.5432
12	2.4006		2.2634	1.2003	1.0974	1.3375	1.7147
13		1.9547		1.0974		1.406	1.3375
14				1.0974			1.4746
15		6.1043	2.7778			1.8176	1.2346
16		6.2757		1.2346	1.406		2.8464
17		1.6461	1.4746	1.2346			2.0576
18			2.332	1.2346			1.4403
19		2.6406	2.2291	1.2346	.9602		3.1893
20		1.4403		1.2346	1.2003	1.2003	1.7833
21		3.3951	1.6118	1.3375	.9602		2.6406
22	1.4403	1.2689	1.0974	1.3375	1.2346	1.2346	1.4403
23	1.0631	1.6461		1.2346	1.4403	1.2003	2.2291
24		1.2003	1.166	1.166	1.3375	1.166	1.6461
Max	2.4006	6.2757	2.7778	1.3375	1.4403	1.8176	3.1893
Min	1.0631	.9602	1.0974	1.0631	.9602	1.0974	.8573
Avg	1.5947	2.1928	1.7595	1.2089	1.2392	1.2907	1.7737

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

WADA S/DN.[158]

BU 4158

Substation No/ Name :- 288055 / 220/22 KV WADA SUBSTN

Feeder No / Name : 304 / 22 KV PARALI FEEDER

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2003		1.2689	1.0631		
2		1.2003					
6					1.2346		1.5089
7		1.6804	1.5432	1.0631	1.3375	.1372	1.6804
8	1.3032	1.3375	1.2346	1.2689	1.2689	.1029	1.6118
9			.9602	.8573			
10	.9602	.9259	.7888	1.0631	.8573	.1029	
11		.7888	.8573	.4458	.8916	.0686	.3772
12	.8573		.6859	.4801	.823	.0686	.8573
13		.8916		.4458			.8573
14				.5144			.9602
15		.7545	.4458			.7202	.8916
16		.7545	.7545		1.0288		.9945
17		.8573	.8573	1.2003			1.3032
18			.9259				1.5089
19		1.5775		1.406	1.749		1.8861
20		1.6804		1.6461	1.9204	1.989	1.7147
21		1.7147	1.749	1.6461	1.8176		1.6461
22	1.5775	1.5775	1.6118	1.4746	1.6804	1.7147	1.4403
23	1.3032	1.4403		1.4403	1.5775	1.4746	1.2346
24		1.2346	1.2346	1.3032	1.3375	1.5089	1.3717
Max	1.5775	1.7147	1.749	1.6461	1.9204	1.989	1.8861
Min	.8573	.7545	.4458	.4458	.823	.0686	.3772
Avg	1.2003	1.2260	1.0499	1.0953	1.3277	.7888	1.2850

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

WADA S/DN.[158]

BU 4158

Substation No/ Name :- 288055 / 220/22 KV WADA SUBSTN

Feeder No / Name : 305 / 22 KV COCACOLA FEEDER

SHEDDABLE FEEDER HAVING WEEKLY

Feeder KV- 22 / OUTGOING

STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6516		.6173	.2743		
2		.583					
3					.2401		
6					.2401		.5487
7		.583	.583	.3429	.3086	.5144	.5144
8	.4801	.6516	.6173	.2401	.5144	.5144	
9	.6859	.7888	.7545	.2401			
10	.7545	.8573	.7202	.2401	.6859	.7545	.823
11		.7545	.7888	.2401	.7888	.823	.8573
12	.8573		.6516	.2401	.7545	.7545	.8573
13		.823		.2058		.6859	.8573
14				.2401			.7888
15		.7545	.8916			.6859	.7545
16		.7888		.2058	.6859		.7545
17		.8573	.7888	.2058			.7888
18			.7888				.8916
19		.6516	.6859	.2401	.583		.6516
20		.6859		.2401	.6173	.583	.6859
21		.6173	.6173	.2401	.6173		.6173
22	.583	.583	.583	.2401	.4801	.5144	.5487
23	.6516	.5487		.2401	.5487	.583	.6173
24		.6173	.6173	.6173	.2401	.5487	.4801
Max	.8573	.8573	.8916	.6173	.7888	.823	.8916
Min	.4801	.5487	.583	.2058	.2401	.5144	.4801
Avg	.6687	.6940	.6991	.2845	.5053	.6329	.7081

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

WADA S/DN.[158]

BU 4158

Substation No/ Name :- 288055 / 220/22 KV WADA SUBSTN

Feeder No / Name : 306 / 22 KV MSRM FEEDER

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		12.6543		10.4253	6.5158		
2		10.7339					
6					8.1962		.2058
7		11.0425	8.5734	7.9218	8.059	8.2991	
8	8.6077	8.882	8.7106	7.0988	6.31	8.5734	3.7723
9			4.8011	7.9904			
10	5.9328	8.8477	8.6077	8.1962	5.6584	8.1276	10.9397
11		9.465	8.5391	7.3731	8.2648	5.0069	9.3622
12	8.7792		8.5734	7.8532	8.1962	5.7613	9.225
13		8.8477		8.5391		7.5446	9.6022
14				7.0645			9.6022
15		8.5391	8.1619			8.3333	9.1907
16		8.4362	6.1728	7.7161	7.6818		9.3622
17		8.4019	8.2991	8.059			8.5734
18			8.2991				8.7449
19		4.6639		8.4362	8.4705		9.1221
20		6.9273		8.2305	8.9849	5.7956	8.7449
21		7.6818	8.4019	7.6132	4.6639		8.1962
22	9.0192	7.5789	10.1509	7.8532	9.0535	10.2195	9.2593
23	13.0316	11.7284		9.8766	10.9397	10.8368	13.3402
24		13.2373	11.5912		9.465	11.8313	12.5172
Max	13.0316	13.2373	11.5912	10.4253	10.9397	11.8313	13.3402
Min	5.9328	4.6639	4.8011	7.0645	4.6639	5.0069	.2058
Avg	9.0741	9.2292	8.3756	8.1405	7.8900	8.2118	8.8094

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

WADA S/DN.[158]

BU 4158

Substation No/ Name :- 288055 / 220/22 KV WADA SUBSTN

Feeder No / Name : 307 / 22 KV BOKADIA FEEDER  
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6							.0686
7			.0152				.0343
8	.0343			.0686		.0686	
9	.0686						
10	.0114				.0686		.0038
11		.0152	.0343	.0686			
12	.0076						.0686
13		.0152				.0343	
15		.0152					
16		.0152					
17				.0686			.0686
19							.0343
20		.0152			.0686	.0686	
22		.0152					
24			.0152	.0686			
Max	.0686	.0152	.0343	.0686	.0686	.0686	.0686
Min	.0076	.0152	.0152	.0686	.0686	.0343	.0038
Avg	.0305	.0152	.0216	.0686	.0686	.0572	.0464

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

WADA S/DN.[158]

BU 4158

Substation No/ Name :- 288055 / 220/22 KV WADA SUBSTN

Feeder No / Name : 308 / 22 KV VARALA FEEDER

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		6.8244		6.9616	1.6461		
2		6.3786					
3					8.8477		
6					5.4527		6.1728
7		6.2757	5.5556	2.3663	5.0412	5.6242	6.5158
8		2.332	5.487	1.5432	5.1097	5.487	
9	5.9328	6.07	6.07	1.5089			
10	6.0357	2.7778	6.2757	1.4403	2.0576	2.2977	2.4006
11		2.915	2.6749	1.2003	2.0233	1.9547	2.6063
12	6.1728		2.4691	1.2003	1.989	1.8861	2.2634
13		2.1605		1.3375		1.7147	1.9204
14				1.3375		1.749	1.989
15		2.5034	2.2977			1.7833	2.0576
16		2.5377		1.2003	3.2236		2.1605
17		2.6749	4.1838	1.4403			2.1605
18			3.4294	1.4403			2.2291
19		2.1948	4.561	1.4746	2.5034		2.4691
20		2.2977		1.749	2.0919	2.1262	2.332
21		2.4691	3.1207	1.6804	2.0233		2.915
22	5.487	6.653	7.476	4.561	6.1043	6.3786	6.3786
23	6.5158	6.7901		5.487	7.5789	7.1331	7.2702
24		6.4129	6.5158	7.8875	5.4527	6.6187	6.9616
<b>Max</b>	<b>6.5158</b>	<b>6.8244</b>	<b>7.476</b>	<b>7.8875</b>	<b>8.8477</b>	<b>7.1331</b>	<b>7.2702</b>
<b>Min</b>	<b>5.487</b>	<b>2.1605</b>	<b>2.2977</b>	<b>1.2003</b>	<b>1.6461</b>	<b>1.7147</b>	<b>1.9204</b>
<b>Avg</b>	<b>6.0288</b>	<b>4.1334</b>	<b>4.6244</b>	<b>2.5454</b>	<b>4.0764</b>	<b>3.7294</b>	<b>3.5766</b>



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

WADA S/DN.[158]

BU 4158

Substation No/ Name :- 288055 / 220/22 KV WADA SUBSTN

Feeder No / Name : 309 / 22 KV ABITGHAR FEEDER

SHEDDABLE FEEDER HAVING WEEKLY

Feeder KV- 22 / OUTGOING

STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		13.8203		9.8423	11.4198		
2		15.6379					
6					12.0028		10.0137
7		14.7462	10.1166	10.5967	10.9397	11.0082	12.8944
8	9.4993	12.8944	10.8368	10.3224	9.9451	8.4019	
9		13.9575		9.7394			
10	9.9451	12.62		10.1509	9.7737	9.9451	10.4938
11		14.2318		9.225	10.4938	11.6255	14.8491
12	9.7051			10.8368	10.3224	9.4993	13.3059
13		12.8601		9.5679		10.631	14.8491
14				10.2538			13.3745
15		16.0837	13.7517			12.3457	11.3169
16		11.4198	15.0549	10.8368	9.9451		12.4486
17		12.9973	13.0316	11.2826			10.1509
18			13.9232				13.7174
19		12.7915		11.9685	8.0933		14.0261
20		17.0096		10.8025	10.3224	11.214	13.6831
21		18.6214	13.6489	13.3402	11.2483		12.9973
22	11.5226	11.0082	11.8999	10.6996	10.3224	10.974	15.0549
23	10.8368	15.9465		10.2538	11.7284	11.0082	8.1962
24		17.4554	13.9232	13.7517	10.9397	11.5569	9.8766
Max	11.5226	18.6214	15.0549	13.7517	12.0028	12.3457	15.0549
Min	9.4993	11.0082	10.1166	9.225	8.0933	8.4019	8.1962
Avg	10.3018	14.3589	12.9096	10.7924	10.5355	10.7463	12.4264

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

WADA S/DN.[158]

BU 4158

Substation No/ Name :- 288055 / 220/22 KV WADA SUBSTN

Feeder No / Name : 310 / 22 KV KHUPARI FEEDER

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		5.487		.6173	5.6927		
2		4.8011					
3					4.561		
6					4.5268		5.1783
7		3.9781	5.4184	3.6008	4.6639	4.5268	4.2867
8	4.561	4.8011		4.5268	2.9492	4.1495	
9	5.2469	4.7325	2.3663	5.7613			
10	5.0069	5.2469	5.1097	4.6639	6.0014	4.6639	6.5158
11		4.904	3.3265	4.5268	6.3786	4.8354	5.0069
12	5.1097		6.2071	4.6639	6.5158	4.8354	1.8519
13		4.5268		4.0466		4.7325	4.561
14				5.144			4.4239
15		5.0755	4.8354			4.7668	3.0521
16		2.9492		4.8011	3.6008		5.2469
17		6.1386	2.4691	4.2867			4.4239
18			5.0069				4.8011
19		3.1207	5.7613	4.4582	4.2181		4.4582
20		5.4527		5.6927	4.321	4.7325	4.4582
21		4.7325	3.155	4.7668	4.1495		4.1838
22	4.3553	5.6584	4.561	5.487	5.2812	4.561	4.4582
23	5.6927	5.0069		5.0069	4.3896	4.1495	5.6927
24		2.8464	4.2181	4.5953	4.2867	4.0809	5.5556
Max	5.6927	6.1386	6.2071	5.7613	6.5158	4.8354	6.5158
Min	4.3553	2.8464	2.3663	.6173	2.9492	4.0809	1.8519
Avg	4.9954	4.6740	4.3696	4.5086	4.7691	4.5486	4.5974

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

WADA S/DN.[158]

BU 4158

Substation No/ Name :- 288055 / 220/22 KV WADA SUBSTN

Feeder No / Name : 311 / 22 KV TUSA FEEDER

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		4.8354		4.2524	4.4239		
2		4.4582					
6					3.8409		1.5775
7			2.0233	3.8752	3.738	1.749	1.3032
8	1.989	2.9492	1.7147	1.8176	3.6351	1.5432	1.9547
9	1.5775		1.7147	1.4403			
10	1.7833	3.6351	1.8176	1.5089	3.9438	1.5432	2.0233
11		1.4746	1.6118	1.3717	1.749	1.5432	2.1262
12	2.1605		1.5432	1.3717	1.3717	1.406	2.0576
13		1.4746		1.3032		1.406	1.3375
14							2.0233
15		1.3375	1.4746			1.3375	1.5089
16				.9945	1.8861		1.8176
17			1.9547	.9945			1.8861
18			1.5432				2.1262
19		1.8519		1.0288	2.0576		2.1262
20		1.7833		1.0974	1.9204	2.0576	2.0233
21		1.8176	1.6461	1.1317	1.8519		2.0576
22	1.6804	1.6461	2.1262		2.9835		3.738
23	4.6296	4.8697			4.3553		5.4527
24		3.3951	4.321	4.2524	1.0631	4.561	1.5775
Max	4.6296	4.8697	4.321	4.2524	4.4239	4.561	5.4527
Min	1.5775	1.3375	1.4746	.9945	1.0631	1.3375	1.3032
Avg	2.3034	2.7329	1.9576	1.8886	2.7729	1.9052	2.1510

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

WADA S/DN.[158]

BU 4158

Substation No/ Name :- 288055 / 220/22 KV WADA SUBSTN

Feeder No / Name : 312 / 22 KV GAURDIAN CASTING SHEDDABLE FEEDER HAVING WEEKLY  
FEEDER Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		12.6543			7.9904		
2		12.9287					
7		11.1797			9.225		
8	9.9451		10.4595			8.9506	9.1564
9	11.7627						
10				10.631		8.3333	
11				10.2195			10.6996
12	11.6255			8.3333			10.6996
13				8.882			10.6996
14				1.5089			10.7339
15							10.2538
16		9.0878		7.8189			10.2195
17							11.3169
18							4.8354
19				11.4884			12.4143
20				7.3731			7.5103
21				4.2181			11.0082
22	11.8656			9.225			8.882
23	11.0425			10.2538			5.2469
24		12.6543			10.2538	11.0082	
Max	11.8656	12.9287	10.4595	11.4884	10.2538	11.0082	12.4143
Min	9.9451	9.0878	10.4595	1.5089	7.9904	8.3333	4.8354
Avg	11.2483	11.7010	10.4595	8.1775	9.1564	9.4307	9.5483

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

WADA S/DN.[158]

BU 4158

Substation No/ Name :- 288055 / 220/22 KV WADA SUBSTN

Feeder No / Name : 313 / 22 KV KHANIWALI FEEDER

SHEDDABLE FEEDER HAVING WEEKLY

Feeder KV- 22 / OUTGOING

STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4801		.4458	.6173		
2		.5144					
3					.583		
6					.4801		.583
7		.5144	.5144	.5144	.5144	.4801	.4458
8	.4458	.4458	.4801	.4458	.4801	.4801	.5144
9	.6173	.5487	.5144	.4115			
10	.6173	.583	.6516	.4115	.5144	.6173	.5487
11		.583	.6173	.3772	.5144	.6173	.6516
12	.583		.6173	.4458	.4801	.5144	.6859
13		.6173		.4458		.5487	.5487
14				.3772			.6173
15		.6173	.583			.5487	.5144
16		.6173		.3772	.4115		.6173
17		.6516	.6173	.4115			.6859
18			.583				.6173
19		.4458	.5487	.4801	.5144		.6173
20		.5487		.4801	.5144	.4801	.6173
21		.5487	.5487	.4458	.4801		.5144
22	.5144	.4801	.5144	.4458	.4801	.4458	.4801
23	.583	.6516		.6173	.5144	.6516	.4801
24		.4458	.6173	.6173	.6173	.4458	.6173
Max	.6173	.6516	.6516	.6173	.6173	.6516	.6859
Min	.4458	.4458	.4801	.3772	.4115	.4458	.4458
Avg	.5601	.5467	.5698	.4559	.5144	.5300	.5754

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

WADA S/DN.[158]

BU 4158

Substation No/ Name :- 288055 / 220/22 KV WADA SUBSTN

Feeder No / Name : 314 / 22 KV Wada

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5775		1.6118	1.4746		
2		1.4746					
3					1.4403		
6					1.6461		1.5432
7		2.5034	2.4006	2.2634	1.9204	2.0576	1.9547
8	2.0919	2.1605	2.0576	2.1605	1.8861	1.9547	1.9204
9	1.8861	1.8861	2.0233	1.9547			
10	1.6461	1.8861	1.8519	1.8176	1.9204	1.8861	1.9204
11		1.8861		1.6461	1.7147	1.8519	2.0233
12	1.6804		1.7147	1.6804	1.5775	1.749	1.8861
13				1.4403		1.5775	1.7833
14				1.2346			1.5775
15		1.8519	1.7147			1.5089	1.5089
16		1.9204		1.2346	1.5089		1.6804
17		1.8861	1.6461	1.3375			1.6804
18			1.7833				1.9204
19		2.1262		1.6461	1.9547		2.1605
20		2.5034		1.8176	2.0233	2.0576	2.0576
21		2.2977	2.0576	1.7833	1.9204		1.8861
22	2.0233	2.0919	1.989	1.6804	1.7833	1.7833	1.7833
23	1.8176	1.9204		1.6461	1.7147	1.6804	1.6804
24		1.5775	1.7147	1.7147	1.5432	1.5775	1.5775
Max	2.0919	2.5034	2.4006	2.2634	2.0233	2.0576	2.1605
Min	1.6461	1.4746	1.6461	1.2346	1.4403	1.5089	1.5089
Avg	1.8576	1.9719	1.9049	1.6865	1.7352	1.7895	1.8080

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

WADA S/DN.[158]

BU 4158

Substation No/ Name :- 288055 / 220/22 KV WADA SUBSTN

Feeder No / Name : 315 / MIDC Express

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8916		.5144	.1715		
2		.5487					
3					.1715		
6					.1715		.3772
7		.4801	.4801	.4115	.1715	.3772	.3772
8	.6173	.6516	.6173	.1715	.3772	.6516	
9	1.2003	.583	.4115	.1029			
10	.7888	.5487	.9602	.1715	.3772	.5144	.7888
11		.7888	.8916	.1715	.3086	.7545	1.5775
12	1.5432		1.0288	.1715	.4801	.3429	.9945
13		.6516		.2743		.3429	.6859
14				.1372			.6516
15		.823	.583			.6859	.9602
16		.7888		.1715	1.0631		.6859
17		.7202	.4115	.1715			1.5089
18							1.2346
19		.3772	.3429	.1715	.3429		.3429
20		.4115		.1372	.3772	.3429	.5144
21		.4458	.3429	.1029	.4115		.5144
22	.4801	.5144	.5487	.1372	.5144	.5144	.7545
23	.6516	.5144		.1372	.8573	.4115	.6859
24		.6173	.5487	.583	.1372	.4801	.6859
Max	1.5432	.8916	1.0288	.583	1.0631	.7545	1.5775
Min	.4801	.3772	.3429	.1029	.1372	.3429	.3429
Avg	.8802	.6092	.5973	.2199	.3955	.4926	.7847

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

WADA S/DN.[158]

BU 4158

Substation No/ Name :- 288055 / 220/22 KV WADA SUBSTN

Feeder No / Name : 316 / KUDUS 1

Feeder KV- 22 / INCOMING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		5.0069		5.4527	4.1152		
2		5.3498					
5		5.1097					
6					4.2181		5.1783
7		6.1728	6.5844	5.0412	4.7668	4.9383	4.8354
8	5.6584	6.2757	6.5501	4.8011	4.6639	4.7325	5.3841
9			8.4019	4.2181			
10	7.3045	2.0233	7.4417	4.1152	6.31	6.3786	8.5734
11		2.0233	8.7792	4.0809	2.2634	6.3786	7.8532
12	6.4815		9.9451	3.8752	4.6982	6.7901	7.2017
13		2.8464		3.9095		5.4527	6.0357
14				3.8066			7.6475
15		2.915	7.7846			6.4129	6.1728
16		1.2346	8.642	3.8066	5.5899		7.2359
17		8.9849	8.1962	3.8752			7.1674
18			8.2648				8.6763
19		8.7449		4.4239	6.5158		7.0645
20		9.2593		4.561	6.6873	6.893	7.2359
21		8.5391	6.3786	4.4239	5.5899		7.7161
22	6.4815	8.4019	6.3443	4.1495	6.0014	6.7558	6.2757
23	6.0357	6.7215		4.4239	5.8299	6.2414	7.3731
24		5.144	6.6187	5.5556	4.1838	4.5268	3.315
Max	7.3045	9.2593	9.9451	5.5556	6.6873	6.893	8.6763
Min	5.6584	1.2346	6.3443	3.8066	2.2634	4.5268	3.315
Avg	6.3923	5.5737	7.6870	4.3835	5.1024	5.9546	6.719



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

WADA S/DN.[158]

BU 4158

Substation No/ Name :- 288055 / 220/22 KV WADA SUBSTN

Feeder No / Name : 317 / KUDUS 2

Feeder KV- 22 / INCOMING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		7.0645		6.0357	2.8464		
2		6.2757					
3					2.8464		
6					3.0521		5.9671
7		5.7956	5.487	4.0124	3.2579	4.8011	5.6927
8	7.3045	6.1728	6.5158	2.8121	3.6351	4.4239	7.1674
9	6.8587	6.1386	6.4129	2.6063			
10	6.893	6.4472	6.653	2.6406	4.1495	4.8354	5.6584
11		6.5501	7.0302	2.7435	4.4582	4.9383	6.3786
12	6.6187		6.6187	2.7092	4.8354	4.9726	6.1386
13		6.0014		2.6749		5.144	6.0357
14				2.7092			5.2469
15		5.5213	5.7613			5.0412	4.8011
16		2.4348	6.9273	2.7092	5.144		4.9726
17		5.6584	6.7558	2.6063			5.0069
18			5.8985				5.144
19		5.8985		2.6749	4.6982		5.3498
20		6.5501		2.8121	5.4184	5.487	5.6927
21		6.5844	6.31	2.8464	5.8299		6.1386
22	6.8587	7.3388	7.1674	2.9492	5.1783	6.2757	6.9616
23	5.9328	6.07		2.9492	5.5899	5.8985	6.4815
24		7.0302	6.2071	6.0357	2.9492	5.727	
Max	7.3045	7.3388	7.1674	6.0357	5.8299	6.2757	7.1674
Min	5.9328	2.4348	5.487	2.6063	2.8464	4.4239	4.8011
Avg	6.7444	6.0901	6.4419	3.2075	4.2593	5.2313	5.8138

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

WADA S/DN.[158]

BU 4158

Substation No/ Name :- 288069 / 220/33/22 KV BHAVEGHAR S/STN

Feeder No / Name : 301 / 22 KV VASURI

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	1.2003		1.2346	.6859	.6859	1.1317
2	1.4403	1.5432		1.2003	.5487	.8573	1.0974
3	1.1317	1.0974		1.1317	.8573	.823	1.2003
4	1.5432	1.5432		1.1317	.823	.8916	1.3717
5	1.406	1.4403	1.0974	1.2003	.7202	.8573	.9945
6	1.2003	1.3717	1.3375	1.1317	.7888	.7888	1.0288
7	1.3717	1.2346		.9259	.7545	.7545	1.2003
8	1.2689	1.406		.7545	.7888	.6859	1.3375
9	1.7833	1.8861		.6173	1.0288	1.0974	2.2977
10	2.2634	1.6461	1.5432	.5487	.8916	1.1317	2.4006
11	2.0576		1.7147	.6173	.7888	1.4403	2.2291
12	1.8176			.4458	.8573	.9945	2.5034
13	1.2689	1.3032	1.2689	.5144	.6859	.7202	1.749
14	2.1948	1.5089		.4115	.583	1.166	1.7833
15	1.7833	1.6804		.4801	.6859	.9602	1.8176
16	2.4006	1.7147		.4801	.7202	.8573	1.9204
17	2.1605	1.8519			.7545	1.3375	2.0233
18	1.6804	1.8519	1.166		.7545	1.3717	1.9547
19	2.3663	1.749	1.6118	.6516	.8916	1.166	1.8176
20	2.1262	1.749	1.2346	.6859	.8573	1.1317	1.2346
21	1.6118	1.4403		.6516	.9945	.8916	1.4403
22	1.406	1.406	1.4746	.5487	1.1317	.9945	1.2003
23	1.3032	1.2689		.583	.9259	.823	1.4403
24	1.1317	1.1317	1.166	1.2689	.6516	1.0288	.7545
Max	2.4006	1.8861	1.7147	1.2689	1.1317	1.4403	2.5034
Min	1.1317	1.0974	1.0974	.4115	.5487	.6859	.7545
Avg	1.6775	1.5011	1.3615	.7825	.7988	.9774	1.5804

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

WADA S/DN.[158]

BU 4158

Substation No/ Name :- 288069 / 220/33/22 KV BHAVEGHAR S/STN

Feeder No / Name : 302 / 22 KV PALSAI

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.7888		1.3717	1.406	1.406	.8573
2	.8573	.9945		1.2689	1.3717	1.3717	.9945
3	.9602	1.0288		1.4403	1.5432	1.4403	.9945
4	1.1317	.9602		1.4746	1.3717	1.5432	1.1317
5	.9602	.9602	1.2689	1.5432		1.4403	1.0631
6	1.2003	1.2689	1.3717	1.4746		1.3375	1.2346
7	1.3375	1.4403		1.6118		1.3717	1.3717
8	1.2346	1.5432		1.3032	1.4403	1.4403	1.3717
9	1.1317	1.0974		1.2346	1.3375	1.3032	1.2346
10	1.0974	.9945	.6859	1.0631	1.0631	1.166	1.166
11	1.0288	.8573	1.0288	.9259	.9259	1.2003	1.0288
12	1.0631			.823	1.0288	1.166	.8573
13	.9602	.7888	1.0288	.7545	.9945	1.0974	.9602
14	.823	.7888		.7888	.9602	1.0288	.9259
15	.9259	.8916		.6859	.9602	1.0631	.823
16	.9259	.8573		.823	.9945	1.2003	
17	.9945	.9259				1.3032	
18	.9945	.8573	1.2346		.8573	1.4746	
19	1.3032	1.406	1.406	1.3717	1.5775	1.5775	1.5432
20	1.6461	1.5432	1.6118	1.5432	1.6461	1.5775	1.4403
21	1.4746	1.5089		1.3375	1.4746	1.5089	1.3375
22	1.2689	1.2003	1.3032	1.3032	1.4403	1.3375	1.166
23	.9602	1.166		1.2003	1.1317	1.0631	.9945
24	.7888	.9945	1.0631	1.3032	1.406	1.166	1.0631
Max	1.6461	1.5432	1.6118	1.6118	1.6461	1.5775	1.5432
Min	.7888	.7888	.6859	.6859	.8573	1.0288	.823
Avg	1.0802	1.0810	1.2003	1.2112	1.2466	1.3160	1.1219

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

WADA S/DN.[158]

BU 4158

Substation No/ Name :- 288069 / 220/33/22 KV BHAVEGHAR S/STN

Feeder No / Name : 303 / 22KV ASPEE FEEDER

SHEDDABLE RURAL

Feeder KV- 22 / INCOMING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.1495	3.8066		4.4582	2.4348	3.8752	5.5556
2	4.9726	4.2181		4.321	2.2291	4.2524	4.1838
3	6.4129	5.3155		3.3951	2.7092	6.5158	3.8066
4	6.4472	5.6584		3.8409	2.2291	4.1152	3.3951
5	5.2126	5.2126	4.0466	3.2579	2.4006	3.7723	5.2469
6	6.4472	3.9781	3.7037	3.0864	2.6063	3.9438	3.4637
7	6.4815	6.31		3.0521	2.6063	4.2867	3.2236
8	5.9671	5.2126		2.9492	2.915	3.5665	3.6694
9	6.4129	6.4472		2.4691	3.8066	4.0809	4.4925
10	6.9959	6.3786	5.2126	2.4006	4.0124	4.1152	3.8066
11	7.3388	5.3155	5.7613	2.5377	4.1152	4.5268	4.3553
12	2.6749			2.2977	4.0809	3.8066	
13	5.1783	3.818	5.6584	2.1605	3.8409	3.8752	3.5322
14	6.1386	7.3731		2.2291	3.738	3.9781	4.1152
15	6.1043	5.9328		2.1605	4.0466	4.6982	4.4239
16	5.2126	6.2757		2.2977	3.6008	4.1838	5.8299
17	2.915	6.1386			3.8066	4.0809	4.5953
18	6.3443	5.2469	4.904		3.4979	5.2469	5.6584
19	4.321	4.4239	4.904	2.3663	3.5322	4.5953	4.2867
20	5.144	4.561	4.8354	2.5377	3.6694	4.5953	5.3155
21	4.561			2.3663	3.7723	4.9383	4.2867
22	4.5268	4.4925	4.9383	2.4006	4.8697	4.3896	4.2524
23	4.6296	4.5953		2.4006	3.5665	3.6008	4.3896
24	4.561	4.6296	4.7325	4.6639	2.3663	3.6694	2.3663
Max	7.3388	7.3731	5.7613	4.6639	4.8697	6.5158	5.8299
Min	2.6749	3.8066	3.7037	2.1605	2.2291	3.5665	2.3663
Avg	5.3812	5.2428	4.8697	2.8931	3.3522	4.2796	4.2718

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

WADA S/DN.[158]

BU 4158

Substation No/ Name :- 288069 / 220/33/22 KV BHAVEGHAR S/STN

Feeder No / Name : 304 / 22KV VAISHNAV FEEDER  
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.155	4.8697		4.8011	3.8066	3.7723	6.0014
2	3.1893	5.9671		4.6296	3.738	3.9438	5.9671
3	3.3608	4.2181		4.6982	3.9438	3.738	4.8697
4	3.3951	3.8409		4.8354	3.9781	4.4239	6.4815
5	3.0178	6.4472	3.6351	4.8697	3.8066	4.1152	6.2414
6	3.155	4.6639	4.5953	4.7668	3.738	4.7325	2.7092
7	3.2579	5.9671		4.8354	4.4239	4.561	4.5953
8	3.9781	4.8697		3.3265	4.1152	4.7325	4.5268
9	2.6063	1.8519		4.5268	4.2524	4.6982	4.5953
10	3.1207	4.321	4.4925	3.9095	4.561	4.7325	4.3896
11	2.6406	5.0069		4.6982	3.738	4.8697	5.0412
12	2.6406			4.3553	3.8409	3.8066	4.9383
13	4.4239	3.0521	4.8011		3.9438	4.5953	3.0178
14	1.5089	5.0069		4.3896	3.9781	4.5953	4.3896
15	4.4582	4.6639		4.3896	4.4582	4.8697	4.2867
16	3.3608	4.321		4.2524	3.9095	4.6639	3.2579
17	4.4239	3.3951			4.5268	3.5665	4.6639
18	2.4006	3.3951	4.9726		4.2181	2.5034	4.2181
19	4.9383	3.4294	3.2579	2.4006	2.7435	5.0069	5.9671
20	3.3608	3.3608	4.9726	3.2579	4.0124	4.6296	3.2579
21	4.8011	2.8464		4.321	4.904	4.5268	4.6296
22	5.5556	3.3265		2.4348	4.5268	5.0755	4.5268
23	2.2977	1.6118		2.7092	3.155	4.8697	5.5556
24	5.5899	5.6242	4.8697	4.7325	2.0576	4.2867	5.144
Max	5.5899	6.4472	4.9726	4.8697	4.904	5.0755	6.4815
Min	1.5089	1.6118	3.2579	2.4006	2.0576	2.5034	2.7092
Avg	3.5265	4.1764	4.4496	4.1495	3.9323	4.3881	4.7197

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VASAI DIVISION[434]

WADA S/DN.[158]

BU 4158

Substation No/ Name :- 288069 / 220/33/22 KV BHAVEGHAR S/STN

Feeder No / Name : 401 / 33 KV KALISMA

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.463			.5144	.5658	.5144
2	.7202	.463			.5658	.5144	.5658
3	.823	.5144			.823	.5658	.5658
4	.7202	.5658			.8745	.6173	.6173
5	.7202	.4115			.7202	.6687	.6173
6	.6173	.463	.4115		.7202	.5658	.7202
7	.3601	.3601			.8745	.6173	.5658
8	.4115	.3086			.7202	.5144	.5144
9	.3086	.3601				.6173	.6173
10	.463	.6173	.4115	.3601	.7202	.7202	.7716
11	.463		.463	.463	.7202	.7716	.7202
12	.463				.7202	.7716	.6687
13	.4115	.4115	.3601	.5144	.7716	.7202	.5658
14	.4115	.4115		.7202	.7716		.5144
15	.4115	.463		.7716	.7202	.7716	.5658
16	.4115	.5144		.823	.7202	.6173	.5658
17	.3601	.463		.8745	.823	.6173	.8745
18	.463	.463	.5144	.8745	.8745	.5144	.7716
19	.463	.463	.4115	.823	.823	.5658	.7202
20	.463	.3601	.3601	.5487	.7202	.7202	.5658
21	.3601	.3601		.7202	.6687	.6687	.5658
22	.4115	.4115	.3086	.823	.6173	.5658	.7202
23	.4115	.4115		.6687	.6687	.5658	.5658
24	.6173	.463	.4115	.3601	.5658	.8745	.6173
Max	.823	.6173	.5144	.8745	.8745	.8745	.8745
Min	.3086	.3086	.3086	.3601	.5144	.5144	.5144
Avg	.5037	.4419	.4058	.6675	.7269	.6396	.6280

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VIRAR O&amp;M DIVISION[440]

NALASOPARA WEST S/DN[157] BU 4375

Substation No/ Name :- 283518 / 22/22kv Nalasopara west  
switch

Feeder No / Name : 301 / NIRMAL

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17
HR	Load (MW)	Load (MW)
8		2.0995
20	2.6787	
24		2.3891
Max	2.6787	2.3891
Min	2.6787	2.0995
Avg	2.6787	2.2443

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VIRAR O&amp;M DIVISION[440]

NALASOPARA WEST S/DN[157] BU 4375

Substation No/ Name :- 283518 / 22/22kv Nalasopara west  
switch

Feeder No / Name : 302 / UMRALA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17
HR	Load (MW)	Load (MW)
8		1.9909
20	2.5339	
24		2.3529
<b>Max</b>	<b>2.5339</b>	<b>2.3529</b>
<b>Min</b>	<b>2.5339</b>	<b>1.9909</b>
<b>Avg</b>	<b>2.5339</b>	<b>2.1719</b>



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VIRAR O&amp;M DIVISION[440]

NALASOPARA WEST S/DN[157] BU 4375

Substation No/ Name :- 283518 / 22/22kv Nalasopara west  
switch

Feeder No / Name : 303 / SRIPRASTHA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17
HR	Load (MW)	Load (MW)
20	2.2805	
24		2.2081
<b>Max</b>	<b>2.2805</b>	<b>2.2081</b>
<b>Min</b>	<b>2.2805</b>	<b>2.2081</b>
<b>Avg</b>	<b>2.2805</b>	<b>2.2081</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VIRAR O&amp;M DIVISION[440]

NALASOPARA WEST S/DN[157] BU 4375

Substation No/ Name :- 283518 / 22/22kv Nalasopara west  
switch

Feeder No / Name : 304 / INCOMER NO.1

SHEDDABLE URBAN

Feeder KV- 22 / INCOMING

DATE	22-AUG-17	23-AUG-17
HR	Load (MW)	Load (MW)
20	7.6017	
24		7.0226
<b>Max</b>	<b>7.6017</b>	<b>7.0226</b>
<b>Min</b>	<b>7.6017</b>	<b>7.0226</b>
<b>Avg</b>	<b>7.6017</b>	<b>7.0226</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VIRAR O&amp;M DIVISION[440]

NALASOPARA WEST S/DN[157] BU 4375

Substation No/ Name :- 283518 / 22/22kv Nalasopara west  
switchFeeder No / Name : 305 / Station Feeder  
Feeder KV- 22 / OUTGOING

SHEDDABLE URBAN

DATE	22-AUG-17	23-AUG-17
HR	Load (MW)	Load (MW)
20	3.2941	
24		2.6787
<b>Max</b>	<b>3.2941</b>	<b>2.6787</b>
<b>Min</b>	<b>3.2941</b>	<b>2.6787</b>
<b>Avg</b>	<b>3.2941</b>	<b>2.6787</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VIRAR O&amp;M DIVISION[440]

NALASOPARA WEST S/DN[157] BU 4375

Substation No/ Name :- 283518 / 22/22kv Nalasopara west  
switch

Feeder No / Name : 306 / SOPARA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17
HR	Load (MW)	Load (MW)
20	2.2443	
24		2.4977
<b>Max</b>	<b>2.2443</b>	<b>2.4977</b>
<b>Min</b>	<b>2.2443</b>	<b>2.4977</b>
<b>Avg</b>	<b>2.2443</b>	<b>2.4977</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VIRAR O&amp;M DIVISION[440]

NALASOPARA WEST S/DN[157] BU 4375

Substation No/ Name :- 283518 / 22/22kv Nalasopara west  
switch

Feeder No / Name : 307 / INCOMER NO 2

SHEDDABLE URBAN

Feeder KV- 22 / INCOMING

DATE	22-AUG-17	23-AUG-17
HR	Load (MW)	Load (MW)
20	5.5746	
24		5.104
Max	5.5746	5.104
Min	5.5746	5.104
Avg	5.5746	5.104

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VIRAR O&amp;M DIVISION[440]

VIRAR EAST S/DN.[706] BU 4706

Substation No/ Name :- 283092 / NARANGI

Feeder No / Name : 301 / SHIRSAD FEEDER

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.7134	3.9476	5.4575	5.567	4.8247	5.2332	5.6818
2	4.4536	4.8247	5.1958	5.3814	4.2981	5.0463	5.607
3	4.8247	4.8247	5.1584	5.1959	4.268	5.0463	5.4201
4	5.1959	5.0103	5.0463	5.1959	4.4536	5.2332	5.0463
5	5.567	5.567	5.607	5.3814	4.8618	5.7939	5.0463
6	5.7154	6.1237		5.7526	5.1959	5.7939	5.0463
7	5.901	6.4948	6.5415	6.3093	5.3814	5.7939	
8	5.6041	6.1237	6.0516	6.3093	5.7154	5.8313	5.4201
9	4.3051	5.1959	6.0556	5.9381	5.6041	6.0556	5.0474
10	5.567	5.3072	5.9381		5.9381	5.7526	5.3814
11	5.7526	4.8247	6.1237	5.308	5.3814	5.567	5.0103
12	5.567	4.0825	5.1959	4.8968	5.1959	5.7526	4.3393
13	5.567	5.1216	5.1959	4.4856	5.0103	5.3814	4.268
14	4.4536	4.8247		4.1492	4.4536	4.8247	4.268
15	5.3814	5.1959		4.2987	5.1959	5.1959	4.6392
16	5.3814	5.4928	5.567	3.9623	5.1959	5.0103	4.6392
17	5.1959	5.3072	5.567	4.3423			4.9361
18	5.1959		5.3814	4.2309		5.607	5.2701
19	5.9381		6.1237	5.1216	6.3172		6.1237
20	7.0515	7.4012	7.4227	6.1608	7.0648	7.177	6.6804
21	6.866	7.1022	7.4227	6.235	6.8779	6.7284	6.2721
22	6.4948	6.9527	7.0515	5.567			5.9381
23	6.1237	6.5415	6.3093	5.567			5.8639
24	4.7134	5.1959	5.7939	6.1237	5.0845	5.2332	5.4201
Max	7.0515	7.4012	7.4227	6.3093	7.0648	7.177	6.6804
Min	4.3051	3.9476	5.0463	3.9623	4.268	4.8247	4.268
Avg	5.4804	5.5210	5.9146	5.2817	5.3159	5.6029	5.2767

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VIRAR O&amp;M DIVISION[440]

VIRAR EAST S/DN.[706] BU 4706

Substation No/ Name :- 283092 / NARANGI

Feeder No / Name : 302 / ARNALA FEEDER

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.5022	5.9099	6.4434	6.8054	6.1538	6.3348	6.3942
2	5.4298	5.7308	6.2262	6.4472	5.9728	6.1538	6.2833
3	5.6108	5.5518	6.0452	6.089		6.0452	6.1725
4	5.647	5.5518	6.0452	6.089	6.0814	6.0452	6.1725
5	5.7918	5.7308	6.0452	6.4472	5.5022	6.19	6.4682
6	6.1176	5.9099		6.6263	5.9366	6.3203	6.4682
7	5.9366	5.9099	5.9728	6.4472	6.1538	6.2833	
8	5.466	5.7308	5.7194	6.2681	5.828	6.0985	6.3573
9	4.3439	5.9099	5.9004		5.8642	5.9137	6.5188
10	5.5518	5.466	5.7308		5.7918	5.9099	6.089
11	5.1936	5.4298	5.3727	5.466	5.5022	5.7308	5.7308
12	5.3727	5.5746	5.7308	5.3212	5.3936	5.5518	5.5518
13	5.0145	5.2488	5.7308	4.6696	5.0316	5.3727	5.9099
14	5.5518	5.4298		4.6696	4.7782	5.0145	4.8354
15	5.3727	5.3212	6.9845	4.742	5.0678	5.3727	4.8354
16	4.8354	3.0521	6.4472	4.6696	5.4298	5.1936	4.6563
17	5.1936	5.2488	3.0445	4.9592		5.1764	5.2126
18	5.3727		5.5518	5.104		5.4332	5.5022
19	6.089		7.8799	5.9728	6.4072		6.8054
20	5.7308	7.6741	7.7008	6.4434	6.653	7.3552	7.1674
21	7.5217	7.6741	7.7008	6.4434	6.8378	7.2074	6.9502
22	7.5217	7.9275	7.8799				6.8778
23	7.1636	7.7465	8.059	6.6968			6.914
24	6.371	6.6263	7.2398	7.5217	6.5158	7.0588	7.0595
Max	7.5217	7.9275	8.059	7.5217	6.8378	7.3552	7.1674
Min	4.3439	3.0521	3.0445	4.6696	4.7782	5.0145	4.6563
Avg	5.7376	5.9252	6.3387	5.8999	5.8369	5.9887	6.1275

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VIRAR O&amp;M DIVISION[440]

VIRAR EAST S/DN.[706] BU 4706

Substation No/ Name :- 283092 / NARANGI

Feeder No / Name : 303 / VIRAR -W- FEEDER

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.7009		5.2544	5.2433	4.8817	5.0732	4.892
2	4.5201	5.7857	4.7108	4.8817		4.9645	4.7108
3	4.7009	5.4241	4.7108	4.7009	4.8817	4.7108	4.5296
4	4.8817	5.2433	5.0369	4.7009	4.8817	4.7108	4.5296
5	4.7009	5.2433	5.2544	4.8817	4.4478	4.892	4.7108
6	4.6647	5.0625		4.8817	4.3754	5.0007	4.7108
7	4.8455	5.0625	5.3268	4.8817	4.5562	4.6383	
8	4.6647	5.0625	5.0732	5.0625	4.3754	4.8557	4.747
9	4.5924	5.0625	4.7108	4.8817	4.8817	4.8195	4.7009
10	4.8817		4.7009		4.7009	5.0625	4.8817
11	4.7009	4.6286	4.8817	4.8195	4.1585	4.8817	4.7009
12	4.1585	4.3393	4.3393	4.7833	4.2308	4.7009	
13	4.3393	4.4839	4.5201	4.5296	4.4116	4.5201	4.1585
14	4.1585	4.3393	4.3393	4.3847	4.1223	4.3393	3.9777
15	3.9777	4.3393	4.1585	4.5296	4.3393	4.3393	3.9777
16	3.7969	2.3504	3.9777	3.9136	3.9777	4.1585	3.6161
17	4.7009	3.9777	4.1585	3.8692		4.3484	3.7969
18	4.8817		4.3393	4.1223		4.4209	4.1946
19	5.7857		5.4241	5.2795	5.4355		5.1348
20	6.5089	6.3415	5.9665	5.6411	5.8704	6.5951	6.1473
21	6.8705	6.3415	6.3281	5.4603	5.1094	6.1965	5.171
22	7.2321	6.7763	6.3281	5.4241			5.7857
23	6.6897	6.0516	5.7857	5.4241			4.9179
24	4.9179	6.1473	4.892	5.4241	5.0625	5.3268	5.2544
Max	7.2321	6.7763	6.3281	5.6411	5.8704	6.5951	6.1473
Min	3.7969	2.3504	3.9777	3.8692	3.9777	4.1585	3.6161
Avg	4.9947	5.1032	4.9660	4.8574	4.6684	4.8836	4.6930



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VIRAR O&amp;M DIVISION[440]

VIRAR EAST S/DN.[706] BU 4706

Substation No/ Name :- 283092 / NARANGI

Feeder No / Name : 304 / VIRAR EAST FEEDER

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.7918		6.4015	6.8054	6.3348	6.4682	6.4682
2	5.9728	7.3426	6.182	6.4472	6.1538	6.2833	6.1725
3	5.9728	6.8054	5.9179	6.089	6.0814	6.1725	6.1725
4	6.1538	6.4472	5.9816	5.9099	5.7918	6.1725	6.2833
5	6.5158	6.2681	6.2014	5.9099	5.5022	6.2833	6.4682
6	6.371	6.4472		6.2681	5.8642	6.4682	6.3203
7	7.2036	6.9845	7.1331	6.4472	6.0814	6.5421	
8	6.8778	7.5217	7.2645	6.6263	6.8416	7.2813	7.0588
9	6.8416	7.7008	7.6189	6.8054	7.095	7.8727	6.9845
10	7.1636	7.1674	7.3426		7.0588	7.3426	7.5217
11	8.059	7.9275	7.5217	6.2014	7.095	7.7008	7.5217
12	6.8054	7.8189	7.1636	6.2014	6.914	7.7008	7.5217
13	5.3727	7.095	6.6263	5.4927	6.1538	7.1636	6.9845
14	4.6563	6.6606	6.2681	5.3509	6.0452	6.089	6.2681
15	5.3727	6.9502	6.4472	5.3727	6.1538	6.8054	6.6263
16	5.3727	7.095	6.4472	4.9257	6.3348	6.4472	6.4472
17	5.3727	7.0226	6.6263	4.8144		6.8008	6.8054
18	5.5518		6.4472	5.4298		6.8378	6.6244
19	6.9845		7.5217	6.5158	6.981		7.8189
20	7.8799	8.2739	8.2381	7.1312	7.6139	8.4271	8.2533
21	8.2381	8.4172	8.2381	7.457	7.7987	8.1314	8.1447
22	7.8799	7.9515	8.059	7.7103			7.7827
23	7.1636	7.7725	7.8799	7.2398			7.2398
24	6.4072	6.6263	6.9128	7.5217	6.6968	6.8378	7.2074
Max	8.2381	8.4172	8.2381	7.7103	7.7987	8.4271	8.2533
Min	4.6563	6.2681	5.9179	4.8144	5.5022	6.089	6.1725
Avg	6.4992	7.2522	6.9757	6.2901	6.5296	6.9442	6.9868

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VIRAR O&amp;M DIVISION[440]

VIRAR EAST S/DN.[706] BU 4706

Substation No/ Name :- 283092 / NARANGI

Feeder No / Name : 306 / RAILWAY virar east  
Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1118	.1118	.1119	.1118	.1118	.1119	.1119
2	.1118	.1118	.1119	.1118	.1118	.1119	.1119
3	.1086	.1118	.1119	.1118	.1118	.1119	.1119
4	.1118	.1118	.1119	.1118	.1118	.1119	.1119
5	.1118	.1118	.1119	.1118	.1118	.1119	.1119
6	.1118	.1118		.1118	.1118	.1119	.1119
7	.1118	.1118	.1492	.1118	.1118	.1492	
8	.1118	.1118	.1492	.1118	.1118	.1492	.1492
9	.1118	.1118	.1119	.1118	.1118	.1492	.1118
10	.1118	.1118	.1118		.1118	.1118	.1075
11	.1118	.1118	.1118	.1119	.1118	.1118	.1118
12	.1118	.1118	.1118	.1119	.1118	.1118	.1118
13	.1118	.1118	.1118	.1119	.1118	.1118	.1118
14	.1118	.1118		.1119	.1118	.1118	.1118
15	.1118	.1118	.1118	.1119	.1118	.1118	.1118
16	.1118	.1118	.1118	.1119	.1118	.1118	.1118
17	.1118	.1118	.1118	.1118		.1119	.1118
18	.1118		.1118	.1118		.1119	.1118
19	.1118		.1118	.1118	.1492		.1118
20	.1118	.1492	.1118	.1118	.1492	.1492	.1118
21	.1118	.1492	.1118	.1118	.1119	.1492	.1118
22	.1118	.1492	.1118				.1118
23	.1118	.1492	.1118	.1118			.1118
24	.1118	.1118	.1119	.1118	.1118	.1119	.1119
Max	.1118	.1492	.1492	.1119	.1492	.1492	.1492
Min	.1086	.1118	.1118	.1118	.1118	.1118	.1075
Avg	.1117	.1186	.1152	.1118	.1155	.1207	.1133

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VIRAR O&amp;M DIVISION[440]

VIRAR EAST S/DN.[706] BU 4706

Substation No/ Name :- 283510 / 22/22 KV Parol Swiching

Feeder No / Name : 301 / Vajreshwari

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.3336	1.3717	1.3717	1.3336	1.3336
2			1.2955	1.3717	1.4098	1.2955	
3	1.1431		1.2955	1.3336	1.448	1.3717	
4	1.1812		1.2955	1.4098	1.4098	1.3717	
5				1.4861	1.2955	1.448	
6			1.6004	1.6766	1.448	1.5242	
7	1.5623		1.7528	1.7528	1.5242	1.6766	
8	1.3717		1.5242	1.6385	1.6004	1.6004	
9				1.4098		1.6766	
10			1.2955	1.2574	1.448	1.5242	
11			1.2193	1.2193	1.3336	1.448	
12			1.1812	1.2193	1.2193	1.3717	
13	1.1431		1.0669	1.2193	.9526	1.2574	
14	1.0669	1.2955	.9907	1.1812	.9145	1.1812	
15	1.1431	1.3336	1.0288	1.1431	1.105		
16		1.0669	1.0669	1.0669		1.2193	
17		1.2955	1.1431	1.9052		1.2574	
18		1.3336	1.2574	1.2955		1.3717	
19		1.4861	1.2955	1.4861		1.6385	
20		1.7528	1.7909	1.6004	1.7528	1.7528	
21		1.7147	1.7909	1.5623	1.6766	1.6766	
22		1.6004	1.6766		1.5623	1.5623	
23		1.4861			1.5242	1.4861	
24		1.2955	1.3717	1.448	1.3717	1.4098	1.3336
Max	1.5623	1.7528	1.7909	1.9052	1.7528	1.7528	1.3336
Min	1.0669	1.0669	.9907	1.0669	.9145	1.1812	1.3336
Avg	1.2302	1.4237	1.3463	1.4116	1.3878	1.4546	1.3336

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VIRAR O&amp;M DIVISION[440]

VIRAR EAST S/DN.[706] BU 4706

Substation No/ Name :- 283510 / 22/22 KV Parol Swiching

Feeder No / Name : 302 / PAROL outgoing

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.5623	1.6766	1.829	1.6766	1.6385
2			1.5242	1.6385	1.9052	1.6385	1.6385
3	1.5623		1.5242	1.6766	1.9433	1.6766	1.6004
4	1.5623		1.5623	1.7147	1.9433	1.6766	1.6385
5				1.7528	1.9052	1.7528	
6			1.829	1.829	1.9814	1.829	
7	1.9052		1.829	1.9814	2.21	1.9814	
8	1.7147		1.6385	1.8671	1.7528	1.9052	3.1626
9				1.7147		1.7528	
10			1.5623	1.6766	1.7909	1.829	
11			1.448	1.6004	1.7909	1.829	
12			1.4861	1.6004		1.7528	
13	.9145		1.4861	1.6385	1.4861	1.5242	
14	1.5242	1.6385	1.3717	1.7528		1.6004	
15		1.5242	1.5623	1.7528	1.6004		
16		1.448	1.5242	1.7909		1.6004	
17		1.6766	1.6004	1.9052		1.6385	
18		1.3336	1.7147	1.9052		1.7909	
19		1.6004	1.9814	1.9052		1.9433	
20		2.1338	2.0576	1.9433	1.9814	2.1338	3.3913
21		1.8671	2.0957	1.8671	1.9052	1.829	3.1245
22		1.8671	1.829		1.829	1.7909	2.9721
23		1.6385			1.7147	1.7147	2.6292
24		1.5623	1.5623	1.7147	1.7909	1.6766	1.6766
Max	1.9052	2.1338	2.0957	1.9814	2.21	2.1338	3.3913
Min	.9145	1.3336	1.3717	1.6004	1.4861	1.5242	1.6004
Avg	1.5305	1.6627	1.6548	1.7684	1.8447	1.7627	2.3472

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VIRAR O&amp;M DIVISION[440]

VIRAR WEST S/DN.[154] BU 4464

Substation No/ Name :- 283096 / 22/22 Agashi switching stn.

Feeder No / Name : 301 / 22 KV ARNALA-I SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4861	1.4861	1.5242	1.5242	1.4098	1.448	1.4861
2	1.4098	1.4098		1.5242	1.3717	1.3717	1.3717
3	1.3336	1.4098	1.448	1.4861	1.3717	1.3336	1.3336
4	1.2955	1.4098	1.4861	1.448	1.3336	1.3717	1.2955
5	1.4098	1.448	1.4861	1.448	1.1431	1.448	1.4098
6	1.5242	1.4098	1.4861	1.5242	1.448	1.5242	1.6004
7	1.5242	1.448	1.4861	1.6385	1.5242	1.5242	1.6004
8	1.3717	1.3717	1.3336	1.6004	1.4098	1.3717	1.5242
9	1.2955	1.448	1.3336	1.6766	1.4098	1.4098	1.5623
10	1.3336	1.2955	1.2574	1.3717	1.3717	1.448	1.448
11	1.105	1.2193	1.1812	1.2955	1.3336	1.448	1.3717
12	1.2574	1.1812	1.2574	1.2955	1.2574	1.3717	1.3336
13	1.2193	1.2955	1.1812	1.105	1.2193	1.2955	1.3336
14	1.2955	1.2955		1.105	1.105	1.1812	1.0669
15	1.2193	1.2955	1.6385	1.1431	1.2193	1.2193	1.1812
16	1.105	1.2955	1.5242	1.1431	1.2955	1.1812	
17	1.2193	1.2193		1.1812	1.2955	1.2193	1.2193
18	1.2955	1.2574	1.4098	1.105	1.2193	1.2193	1.3336
19	1.6766	1.6004	1.7909	1.3717	1.3717	1.4861	1.6766
20	1.829	1.7909	1.9433	1.5242	1.4861	1.6766	1.7528
21	1.7528	1.7909	1.9433	1.4861	1.4861	1.6385	1.7147
22	1.7528	1.7909	1.9052	1.6004	1.6385	1.6766	1.7528
23	1.6766	1.829	1.8671	1.5242	1.6385	1.6385	1.6766
24	1.5623	1.5242	1.6385	1.7528	1.5242	1.5623	1.5623
Max	1.829	1.829	1.9433	1.7528	1.6385	1.6766	1.7528
Min	1.105	1.1812	1.1812	1.105	1.105	1.1812	1.0669
Avg	1.4146	1.4384	1.5296	1.4114	1.3701	1.4194	1.4612

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VIRAR O&amp;M DIVISION[440]

VIRAR WEST S/DN.[154] BU 4464

Substation No/ Name :- 283096 / 22/22 Agashi switching stn.

Feeder No / Name : 302 / 22KV AGASHI SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.448	1.3717	1.4098	1.6766	1.448	1.4861	1.3717
2	1.4098	1.2193	1.3336	1.6004	1.3717	1.4098	1.3336
3	1.3336	1.1812	1.2955	1.5623	1.3336	1.3336	1.2955
4	1.3336	1.1431	1.2193	1.5242	1.2955	1.3717	1.2574
5	1.4098	1.2193	1.2955	1.448	1.2193	1.3336	1.2193
6	1.4861	1.1431	1.3336	1.448	1.1431	1.2955	1.2574
7	1.4098	1.3336	1.2955	1.4098	1.2574	1.2955	1.2193
8	1.2955	1.2574	1.3717	1.448	1.2955	1.2955	1.2955
9	1.2574	1.2955	1.2574	1.5242	1.2955	1.2574	1.3717
10		1.1431	1.2955	1.3717	1.3336	1.2955	1.3717
11	1.105	1.1812	1.2193	1.1812	1.2955	1.3336	1.2955
12	1.1431	1.2193	1.1812	1.0669	1.2955	1.2574	1.1431
13	1.0669	1.105	1.2193	1.105	1.2193	1.2193	1.3336
14	1.0669	1.1431		1.0669	1.1431	1.1812	1.0669
15	1.105	1.1431	1.5623	1.0669	1.1431	1.1812	1.105
16	1.0288	1.1431		1.1431	1.2193	1.1812	
17	1.105	1.1431	1.2955	1.2193	1.105	1.1812	1.1431
18	1.1812	1.2193	1.105	1.1431	1.1812	1.2193	1.2193
19	1.1431	1.2955	1.4098	1.3717	1.2193	1.4098	1.5242
20	1.6004	1.6004	1.6766	1.5242	1.4861	1.6385	1.5242
21	1.5242	1.7909	1.6766	1.5623	1.4098	1.5623	1.6004
22	1.829	1.7147	1.7528	1.5242	1.5623	1.6004	1.6385
23	1.5623		1.9052	1.6766	1.6385	1.6004	1.5623
24	1.448	1.448	1.829	1.7147	1.5242	1.5623	1.5623
Max	1.829	1.7909	1.9052	1.7147	1.6385	1.6385	1.6385
Min	1.0288	1.105	1.105	1.0669	1.105	1.1812	1.0669
Avg	1.3171	1.2806	1.4064	1.3908	1.3098	1.3543	1.3353

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VIRAR O&amp;M DIVISION[440]

VIRAR WEST S/DN.[154] BU 4464

Substation No/ Name :- 283109 / 22 KV GLOBAL CITY

Feeder No / Name : 301 / VIRAR WEST-2 SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2177	2.2916	2.4272	2.6886	2.2779	2.6139	2.4025
2	2.1216	2.2177	2.3899	2.5133	2.3152	2.4272	2.2916
3	1.9753	2.0698	2.4272	2.4394	2.2405	2.3899	2.2177
4	1.9022	1.9959	2.5393	2.3655	2.2405	2.3525	2.1216
5	1.9753	2.0698	2.5019	2.2916	2.2779	2.3525	2.0485
6	2.0851	2.5133	2.5393	2.4025	2.2779	2.2779	2.3655
7	2.4764	2.6242	2.6513	2.5503	2.2805	2.2405	2.3285
8	2.4025	2.4394	2.4897	2.6513	2.5393	2.3152	2.4025
9	2.2916	2.5873	2.3899	2.4025	2.4272	2.3525	2.3285
10	2.2546	2.5019	2.4272	2.4646	2.3899	2.2779	2.5503
11	2.2546	2.5019	2.4394	2.5019	2.3525	2.3655	2.4394
12	2.1068	2.4272	2.4025	2.3152	2.3899	2.4394	2.2916
13	2.1068	2.0538	2.2916	2.1285		2.3285	2.2177
14	2.1068	2.1285	2.2177	2.1658	2.0911	2.2177	2.1216
15	1.9959	2.2032	2.2177	2.0165	2.1658	2.1216	1.9753
16		2.1285	2.1582	1.9044	1.9791	2.1216	1.9387
17	2.1807	2.2032	2.1216		2.1658	2.0851	1.9022
18	2.0698	2.1285	2.2546		2.1658	2.1582	2.2177
19	1.9589	2.6513	2.6513	2.8753	2.5766	2.726	2.8006
20	2.7721	3.3234	2.9995	2.838	2.7633	2.9127	2.9127
21	2.9569	3.0994	3.0727	2.9874	2.8006	2.95	2.9264
22	2.7721	3.1367	2.9995	2.9127	2.8753	2.838	2.8753
23	2.846	2.726	3.0361	2.6513	2.8006	2.9264	2.726
24	2.3655	2.5503	2.726	2.8753	2.5393	2.8006	2.6886
Max	2.9569	3.3234	3.0727	2.9874	2.8753	2.95	2.9264
Min	1.9022	1.9959	2.1216	1.9044	1.9791	2.0851	1.9022
Avg	2.2694	2.4405	2.5155	2.4974	2.3884	2.4413	2.3788

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VIRAR O&amp;M DIVISION[440]

VIRAR WEST S/DN.[154] BU 4464

Substation No/ Name :- 283109 / 22 KV GLOBAL CITY

Feeder No / Name : 302 / Y.K.NAGAR SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5133	2.6612	2.9874	3.2861	
2	2.4508	2.6612	2.838	3.1417	
3	2.268	2.5133	2.8006	3.0308	
4	2.1948	2.4025	2.7915	2.9569	
5	2.3411	2.5133	2.8006	2.809	
6	2.7435	2.809	2.8753	2.6242	
7	2.9938	2.809	3.0247	2.846	
8	3.1786	3.3634	3.5848	3.2487	
9	3.2526	3.3265	3.2442	3.2156	
10	3.4743	3.2487	3.1741	3.2861	
11	3.4743	3.3608	3.6961	3.3234	
12	3.3265	3.5101	3.4374	3.1741	
13	3.1786	3.1367	3.4374	3.0994	
14	3.0308	3.1741	3.2156	3.1367	
15	2.9938	3.0247	3.1786	2.6513	
16	2.9199	3.1367	3.0727	1.9044	
17	2.9199	3.0994	2.9995		
18	2.9938	3.1367	3.1417		
19	3.4374	3.0994	3.6222		
20	3.6961	3.8089	3.8409		
21	3.77	3.9956	3.9506		
22	3.5852	3.6222	3.5117		3.6595
23	3.3634	3.5101	3.5482		3.3981
24	2.6242	2.9938	3.2487	3.4728	
Max	3.77	3.9956	3.9506	3.4728	3.6595
Min	2.1948	2.4025	2.7915	1.9044	3.3981
Avg	3.0302	3.1216	3.2509	3.0122	3.5288



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VIRAR O&amp;M DIVISION[440]

VIRAR WEST S/DN.[154] BU 4464

Substation No/ Name :- 283109 / 22 KV GLOBAL CITY

Feeder No / Name : 303 / GLOBAL CITY

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.961	1.1088	1.1576	1.1949	1.1203	1.1203	1.1088
2	.9145	1.0719	1.0829	1.1458	1.0829	1.0829	1.0349
3	.9511	1.0719	1.0829	1.1088	1.0456	1.0456	.961
4	.9877	1.0349	1.0456	1.1088	1.0456	.9709	.9145
5	.9877	1.1088	1.1203	1.0719	1.0082	1.0082	.9511
6	1.0242	1.2197	1.1576	1.1827	1.1203	1.0456	1.0719
7	1.1458	1.2567	1.2696	1.0719	1.1949	1.1576	1.1088
8	1.1827	1.1827	1.0456	1.3443	1.2696	1.1203	1.1458
9	.9979	1.1827	1.0456	1.2197	1.1576	1.307	1.2197
10	1.0349	1.1203	1.0456	1.1576	1.1203	1.1949	1.0349
11	.9979	1.0829	1.1458	1.1203	1.1949	1.1458	1.0349
12	1.0349	.9335	1.0349	1.0829	1.1576	1.1088	1.0719
13	.8871	.8962	1.0349	.9335		1.0719	.8871
14	.8871	.8962	.924	.8962	.9709	1.0349	.8413
15	.8871	.9335	1.0719	.8962	.8962	.9877	.8779
16	.924	1.0082	.9877	.7842	1.0082	1.0242	.8048
17	.8501	.9709	.9511		1.0082	1.0242	.9145
18	.924	.9335	.9979		1.0082	1.0974	1.0349
19	3.4374	1.0829	1.1203	1.3817	1.1203	1.2323	1.1949
20	1.1458	1.307	1.2437	1.3443	1.2696	1.2323	1.2323
21	1.2567	1.2696	1.2803	1.3817	1.2323	1.2323	1.2437
22	1.2567	1.307	1.3169	1.1949	1.307	1.307	1.2323
23	1.2936	1.307	1.3169	1.1949	1.307	1.2437	1.2696
24	1.0719	1.1458	1.2323	1.307	1.2323	1.2696	1.1949
Max	3.4374	1.307	1.3169	1.3817	1.307	1.307	1.2696
Min	.8501	.8962	.924	.7842	.8962	.9709	.8048
Avg	1.1267	1.1014	1.1130	1.1420	1.1251	1.1277	1.0578

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VIRAR O&amp;M DIVISION[440]

VIRAR WEST S/DN.[154] BU 4464

Substation No/ Name :- 283109 / 22 KV GLOBAL CITY

Feeder No / Name : 306 / RUSTAMJI EVERSHERINE

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1088	1.1827	1.1949	1.1949	1.1203	1.0456	1.1088
2	1.1706	1.1088	1.1203	1.1088	1.0829	1.0456	1.0719
3	1.0974	1.1088	1.1203	1.1088	1.0456	.9709	.961
4	1.0974	1.1088	1.1694	1.0719	1.0082	.9335	.9145
5	1.134	1.1458	1.0829	1.0719	1.0082	.9335	.9145
6	1.2071	1.2197	1.1203	1.1088	3.0994	1.1576	1.1827
7	1.3676	1.3306	1.3443	1.2567	1.3817	1.2696	1.2197
8	1.4045	1.5524	1.4563	1.3443	1.3817	1.3443	1.3306
9	1.5893	1.4045	1.3443	1.4784	1.4937	1.4937	1.4784
10	1.2197	1.3817	1.1949	1.2323	1.307	1.307	1.4415
11	1.4045	1.419	1.3306	1.307	1.4937	1.4045	1.2567
12	1.2567	1.4563	1.2197	1.2323	1.307	1.4784	1.4415
13	1.2197	1.2696	1.2567	1.1949		1.4045	1.1458
14	1.1827	1.307	1.1088	1.1576	1.1203	1.2936	1.0974
15	1.1827	1.1949	1.1827	1.0456	1.1576	1.2071	1.0242
16	1.0719	1.2323	1.134	.9709	1.419	1.2071	1.1706
17	1.1088	1.0829	1.134		1.2696	1.2071	1.0242
18	1.1827	1.0829	1.1458		1.2323	1.2437	1.1458
19	1.3306	1.2696	1.1949	1.3817	1.4937	1.4937	1.4937
20	1.4415	1.4563	1.4998	1.4563	1.3817	1.5684	1.531
21	1.5154	1.4563	1.4632	1.419	1.419	1.4937	1.39
22	1.4784	1.3817	1.4266	1.419	1.4563	1.4563	1.419
23	1.3676	1.4563	1.39	1.4563	1.4563	1.39	1.419
24	1.1458	1.2567	1.307	1.3443	1.2323	1.2323	1.2323
Max	1.5893	1.5524	1.4998	1.4784	3.0994	1.5684	1.531
Min	1.0719	1.0829	1.0829	.9709	1.0082	.9335	.9145
Avg	1.2619	1.2861	1.2476	1.2437	1.3638	1.2742	1.2256

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VIRAR O&amp;M DIVISION[440]

VIRAR WEST S/DN.[154] BU 4464

Substation No/ Name :- 283109 / 22 KV GLOBAL CITY

Feeder No / Name : 307 / Incomer 1

SHEDDABLE URBAN

Feeder KV- 22 / INCOMING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.6899	7.3922	7.7298	8.4019	4.481	4.481	4.3983
2	6.5112	7.2074	7.8045	7.7248	4.5184	4.4437	4.2505
3	6.1454	6.9117	7.5804	7.577	4.1629	3.9582	3.9918
4	6.0357	6.653	7.319	7.54	4.2943	3.9956	3.8409
5	6.2917	6.8378	7.3937	7.0965	4.257	4.0703	3.8043
6	6.9502	7.7618	7.4684	7.1704	4.3317	4.3317	4.3614
7	7.8727	7.7618	8.2526	7.6879	4.7798	4.5184	4.4723
8	7.7987	8.0205	8.2152	8.3272	4.9665	4.7051	4.768
9	7.7618	8.3532	8.0659	8.4271	4.8544	5.0412	4.731
10	7.54	7.8791	7.8045	8.0659	4.8918	5.0038	4.8419
11	7.8357	8.0285	8.464	8.0659	4.7424	4.8788	4.6571
12	7.1704	7.9538	7.8727	7.5804	4.7798	4.8049	4.5462
13	6.7638	7.3937	7.9466	7.0203		4.5831	4.1396
14	6.9856	7.3937	7.4291	6.9829	3.9209	4.3244	3.8409
15	6.8378	7.207	7.6509	6.4883	4.0703	4.2067	3.7311
16	4.731	7.319	7.3891	6.0494	3.9956	4.1701	3.6946
17	6.8008	7.2443	7.1696		4.2196	4.0969	3.6946
18	6.8747	7.1696	7.2443		4.2196	4.3896	4.1027
19	7.7618	8.2899	8.514	5.4893	4.9291	5.3026	5.3399
20	8.3532	9.5969	9.4742	5.5266	5.3772	5.4519	5.3772
21	9.3141	9.5595	9.5473	5.6013	5.3399	5.5266	5.3772
22	8.9076	9.2981	9.1815	5.3772	5.4146	5.4893	9.0367
23	7.7987	9.1114	9.0352	5.1532	5.4893	5.4138	8.738
24	6.9856	7.7987	8.1779	8.8127	4.8918	5.2279	5.0785
Max	9.3141	9.5969	9.5473	8.8127	5.4893	5.5266	9.0367
Min	4.731	6.653	7.1696	5.1532	3.9209	3.9582	3.6946
Avg	7.1966	7.8393	8.0304	7.0985	4.6490	4.6840	4.7839

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VIRAR O&amp;M DIVISION[440]

VIRAR WEST S/DN.[154] BU 4464

Substation No/ Name :- 283520 / 22/22KV MHADA SWITCHING

STATIO

Feeder No / Name : 302 / INCOMER NO-2

SHEDDABLE URBAN

Feeder KV- 22 / INCOMING

DATE	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		4.9816	5.8943	5.514	5.438	5.514
2		4.6014	5.7042	5.1718	5.3239	5.3239
3		4.5633	5.514	4.9436	5.2098	5.1338
4		4.4873	5.3239	4.6394	5.7042	5.0197
5		4.7915	5.1338	4.3732	4.8295	4.9436
6		4.9436	4.8676	4.5253	4.4493	4.9056
7		5.0197	5.0197	4.7915	4.6014	4.8295
8		5.3239	5.3239	5.2478	5.1718	4.8676
9		5.1338	5.5521	5.2098	5.2098	5.1338
10		5.1718	5.3999	5.2859	5.438	5.0197
11		5.476	5.2098	5.476	5.476	5.3239
12		5.2478	4.9436	5.476	5.3619	5.3999
13			4.9436	5.514	5.2478	4.9436
14			4.6394	4.9436	5.0577	4.6394
15		6.3506	4.4112	4.8676	4.8295	4.5633
16		5.514	4.2971	4.6774	4.7154	4.4493
17	6.6168	5.476	4.3732	4.7154	4.9056	4.9056
18	5.8183	5.438	4.6774	5.2098	5.0957	4.8295
19	6.3506	6.3126	5.7422	5.8943	6.0464	6.0084
20	6.3887		5.9704	6.1225	6.3506	6.1225
21	6.5028		5.9323	6.1225	6.3887	5.9704
22	6.3506		6.3126	6.1225	6.0844	5.7422
23	6.0464		5.8183	6.3506	5.9323	5.514
24		5.5901	6.0084	5.476	5.514	4.9056
Max	6.6168	6.3506	6.3126	6.3506	6.3887	6.1225
Min	5.8183	4.4873	4.2971	4.3732	4.4493	4.4493
Avg	6.2963	5.2457	5.2922	5.2779	5.3492	5.1670

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

KALYAN ZONE[054]

VASAI CIRCLE[540]

VIRAR O&amp;M DIVISION[440]

VIRAR WEST S/DN.[154] BU 4464

Substation No/ Name :- 283520 / 22/22KV MHADA SWITCHING

STATIO

Feeder No / Name : 307 / M.B.ESTATE

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.4718	2.8521	2.6619	2.776	2.738
2		2.2817	2.6619	2.6619	2.738	2.738
3		2.2436	2.6619	2.6239	2.738	2.7
4		2.1676	2.5859	2.5859	2.6619	2.6619
5		2.1676	2.4718	2.3958	2.5859	2.6239
6		2.0915	2.4338	2.2436	2.2056	2.5479
7		2.5098	2.5098	2.3577	2.3197	2.5479
8		2.6619	2.6619	2.6239	2.5479	2.4338
9		2.6619	2.776	2.5859	2.5859	2.5479
10		2.5479	2.7	2.5479	2.7	2.5479
11		2.738	2.6239	2.738	2.738	2.6239
12		2.6239	2.5859	2.8521	2.6619	2.6619
13			2.4718		2.6239	2.4338
14			2.3197	2.4718	2.5098	2.2817
15		3.1563	2.2056	2.4338	2.3958	2.2436
16		2.776	2.2056	2.3197	2.3577	2.5859
17	3.2704	2.738	2.2056	2.3197	2.4338	2.4338
18	2.8901	2.7	2.3197		2.5479	2.5098
19	3.1563	3.2324	2.776	2.9281	3.0042	3.0042
20	3.2704	3.1943	2.8901	3.0422	3.1563	3.0422
21	3.2324	3.1943		3.0422	3.1943	2.9662
22	3.1563	3.1183	3.1563	3.0422	3.0422	2.8521
23	2.9662	3.0042	2.8521	2.9662	2.9281	2.738
24		2.776	2.9662	2.776	2.776	2.776
<b>Max</b>	<b>3.2704</b>	<b>3.2324</b>	<b>3.1563</b>	<b>3.0422</b>	<b>3.1943</b>	<b>3.0422</b>
<b>Min</b>	<b>2.8901</b>	<b>2.0915</b>	<b>2.2056</b>	<b>2.2436</b>	<b>2.2056</b>	<b>2.2436</b>
<b>Avg</b>	<b>3.1346</b>	<b>2.6844</b>	<b>2.6041</b>	<b>2.6464</b>	<b>2.6762</b>	<b>2.6350</b>