

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 201 / 11 KV SAKALPAPER

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.1109		.1294	
4	.1109	.1097	.0924	.1109	.112	.128	.112
6		.1109		.1097		.1109	
8	.168	.1478	.168	.1294	.1478	.1294	.1294
10	.1478		.1663		.1478		.1307
12	.2033		.1829		.1829		.1494
13				.1307		.168	
14	.1478		.1463		.1829		.1494
15		.2218		.1478		.2033	
16	.2195		.2195		.1848		.168
17	1.4289	.2033		.1494			
18	.1829		.1663		.1663		.1307
19		.2033		.1307		.1848	
20	.1646		.1646		.1478		.1494
21		.1663		.1478		.1494	
22	.1478		.168		.168		
24	.1494	.1294	.1307	.1294	.1294	.1294	.1294
Max	1.4289	.2218	.2195	.1494	.1848	.2033	.168
Min	.1109	.1097	.0924	.1097	.112	.1109	.112
Avg	.2792	.1616	.1605	.1297	.1570	.1481	.1387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 202 / 11 KV KUKERAJA Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.7392			
3						.8215	
4	.7842	.7392	.7842	.7023	.7023		.8501
6		.7947		.7133		.7947	
8	.9425	.9795	.924	.7762	.9149	.961	.9149
10	1.922		1.8858		2.0513		1.9418
12	2.1068		2.0328		2.1253		2.0911
13				1.0642		2.1253	
14	2.0851		1.957		2.0883		2.0165
15		2.1845		.9979		2.1285	
16	2.0883		1.8665		2.0883		1.9418
17				.9335			
18	1.6817	1.7924	1.423		1.6817		
19		1.307		.8871		1.4045	
20	1.1888		1.1088		1.2883		.9522
21		1.1389		.9149		1.1088	
22	.9795		.9335		.9795		
24	.9425	.8779	.8871	.8871	.8402	.961	.9335
Max	2.1068	2.1845	2.0328	1.0642	2.1253	2.1285	2.0911
Min	.7842	.7392	.7842	.7023	.7023	.7947	.8501
Avg	1.4721	1.2268	1.3803	.8616	1.4760	1.2882	1.4552

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 203 / 11 KV GAUTAM COMPLEX Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				1.1458			
3						1.1088	
4	1.1576	1.0719	1.1643	1.0164	1.0269		1.1576
6		.9979		.9979		.9877	
8	1.5154	1.6448	1.0269	.8962	1.4969	1.5339	1.4969
10	2.6612		1.9404		2.8275		2.6886
12	3.1417		2.1992		3.0308		2.8006
13				1.2197		2.8006	
14	3.0862		2.0328		2.9938		2.8193
15		3.1047		1.1949		2.809	
16	3.1047		1.885		2.8532		2.726
17				1.1643			
18	2.384	2.6427	1.4998		2.4949		
19		1.6078		1.1389		1.587	
20	1.4415		1.3717		1.4632		1.4563
21		1.3491		1.2012		1.386	
22	1.3491		1.2986		1.3491		
24	1.4377	1.3306	1.363	1.3121	1.3306	1.3306	1.3306
Max	3.1417	3.1047	2.1992	1.3121	3.0308	2.809	2.8193
Min	1.1576	.9979	1.0269	.8962	1.0269	.9877	1.1576
Avg	2.1279	1.7187	1.5782	1.1287	2.0867	1.6930	2.0595

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 205 / 11 KV ARENJA TOWER Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.6099			
3						.6283	
4	.6535	.5487	.6653	.5544	.5415		1.7737
6		.5729		.5729		.5175	
8	.7392	.7207	.5729	.5175	.6468	.6838	.6653
10	1.2936		1.0349		1.3491		1.363
12	1.386		1.0642		1.4415		1.3443
13				.6348		1.46	
14	1.4415		1.0974		1.4969		1.419
15		1.4937		.6161		1.4003	
16	1.4045		1.0242		1.4045		1.3256
17				.5914			1.3256
18	1.0903		.8131		1.2883		
19		.8962		.5601		.8501	
20	.8048		.7023		.8316		
21		.6722		.7023		.7655	
22	.7392		.6468		.7282		
23							.7282
24	.7762	.7133	.7023	.7207	.6468	.7207	
Max	1.4415	1.4937	1.0974	.7207	1.4969	1.46	1.7737
Min	.6535	.5487	.5729	.5175	.5415	.5175	.6653
Avg	1.0329	.8025	.8323	.6080	1.0375	.8783	1.2431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 207 / 11 KV CIDCO PUMP Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.7207			
3						.6767	
4	.7392	.6099	.6283	.6099	.6653		.7023
6		.6099		.5359		.6283	
8	.6348	.5914	.6161	.5359	.7095	.6468	.5975
10	.5914		.5359		.6767		.5975
12	.7577		.5729		.5304		.5041
13				.5359		.5228	
14	.5853		.5544		.6099		.5601
15		.5544		.5729		.5729	
16	.5914		.5544		.6036		.5228
17				.5788			
18	.5544		.5175		.5121		
19		.6653		.5544		.6908	
20	.6838		.6283		.6161		.6535
21		.7023		.6908		.7392	
22	.7762		.6767		.7842		
24	.8402	.7762	.7842	.7762	.8215	.8131	.8589
Max	.8402	.7762	.7842	.7762	.8215	.8131	.8589
Min	.5544	.5544	.5175	.5359	.5121	.5228	.5041
Avg	.6754	.6442	.6069	.6111	.6529	.6613	.6246

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 208 / 11 KV INFOTECH PARK Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.8871			
3						.9979	
4	1.0349	.9425	1.0456	.8215	.8962		.9709
6		.9335		.7842		.9425	
8	1.0642	1.1088	1.0719	.8501	1.0349	1.1576	1.0164
10	1.9404		1.7002		1.9589		1.9791
12	2.1285		1.7741		2.1068		2.0351
13				1.0269		2.0911	
14	2.0698		1.6448		2.1845		2.1285
15		2.2032		1.0082		2.0883	
16	2.0698		1.7002		2.0698		2.0351
17				.9795			
18	1.8107		1.3121		1.8858		
19		1.6057		.9522		1.5154	
20	1.4449		1.0425		1.3121		1.363
21		1.2696		.9425		1.2136	
22	1.2382		.9328		1.2012		
24	1.1763	1.0903	1.1088	.961	.9055	1.1088	1.1088
Max	2.1285	2.2032	1.7741	1.0269	2.1845	2.0911	2.1285
Min	1.0349	.9335	.9328	.7842	.8962	.9425	.9709
Avg	1.5978	1.3077	1.3333	.9213	1.5556	1.3894	1.5796

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 209 / 11 KV RBI Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	02-JUN-17
HR	Load (MW)
15	2.2032
Max	2.2032
Min	2.2032
Avg	2.2032

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 210 / 11 KV MTNL / DIWALA Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.9979			
3						1.0082	
4	.9979	.9425	1.0349	.961	.961		.961
6		.9795		.9145		.9511	
8	1.2883	1.3306	1.3256	.9425	1.1763	1.2382	1.2323
10	2.9938		2.5688		3.0493		3.0247
12	3.1786		2.384		3.2674		3.0247
13				1.0349			
14	3.0862		2.2916		3.1367		
15		3.0862		1.0719		3.0247	
16	2.9813		2.2177		3.0862		2.8753
17				1.0642			
18	2.0485		1.9035		2.0538		
19		1.5708		.9979		1.4937	
20	1.2567		1.1273		1.2012		
21		1.0719		1.0082		1.1273	
22	1.1088		1.0349		1.0534		
23							1.1949
24	1.0642	1.0164	1.0829	1.0534	1.0082	1.0349	1.0082
Max	3.1786	3.0862	2.5688	1.0719	3.2674	3.0247	3.0247
Min	.9979	.9425	1.0349	.9145	.961	.9511	.961
Avg	2.0004	1.4283	1.6971	1.0046	1.9994	1.4112	1.9030

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 212 / 11 KV MAYURESH COSMOSS Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.1109			
3						.1294	
4	.112	.1109	.0934		.0924		.0934
6		.1109		.0924		.1109	
8	.0924	.1294	.0924	.1109	.112	.0914	.1109
10	.3696		.3511		.4066		.3921
12	.4435		.4066		.462		.4481
13				.1109			
14	.4251		.3475		.4066		.3547
15		.4805		.1109		.4481	
16	.4805		.3696		.5175		.4481
17				.112			
18	.3511		.2587		.4066		
19		.2054		.1294		.2587	
20	.1478		.1478		.1663		.1494
21		.1307		.112		.1307	
22	.1509		.128		.128		
24	.1478	.1294	.1109	.1294	.1307	.1294	.1294
Max	.4805	.4805	.4066	.1294	.5175	.4481	.4481
Min	.0924	.1109	.0924	.0924	.0924	.0914	.0934
Avg	.2721	.1853	.2306	.1132	.2829	.1855	.2658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 403 / 33 KV NMMC Only one consumer of WW with HT-IV

Feeder KV- 33 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				1.7541			
3						1.7541	
4	1.3146	1.3014	1.3146	1.7541	1.9433		1.9433
6		1.3014		1.7541		1.2449	
8	1.358	.8488	1.3146	1.8107	.8573	.8488	.743
10	1.3014		1.3014		.8488		.7842
12	1.3014		1.2449		.8488		.6161
13				1.829			
14	1.3014		1.3014		1.3014		.2241
15		1.3146		1.8861		.1715	
16	1.3014		1.3014		1.3014		.2241
17				1.3014			
18	1.3014		1.3014		1.3014		
19		.8573		.8573		.9145	
20	.8488		1.3014		.8488		.1698
21		.8573		.8002		.8002	
22	.7922		1.3014		1.2449		
24	1.4289	.1132	1.3146	1.8107	1.3146	1.2449	1.2449
Max	1.4289	1.3146	1.3146	1.8861	1.9433	1.7541	1.9433
Min	.7922	.1132	1.2449	.8002	.8488	.1715	.1698
Avg	1.2250	.942	1.2997	1.5558	1.1811	.9970	.7437

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 201 / 11 KV Sector 8-A Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							2.4272
2		2.0957		2.0957			
3	1.643	1.9052	1.7177	1.9052			1.8671
4	1.6057	1.7147	1.6244	1.6194	1.643	1.6804	
5	1.587	1.6194	1.4937	1.5242	1.6057	1.643	1.6804
6	1.531	1.5242	1.4563	1.5051	1.4937	1.531	1.4937
7	1.3443	1.4289	1.3443	1.3527	1.3443	1.4563	1.3817
8	1.3256	1.3717	1.3443	1.3336	1.4003	1.3443	
9		1.419	1.3443	1.307	1.307	1.3443	1.363
10	1.4098	1.3443	1.3717	1.363	1.3443	1.4003	1.3717
11	1.3908	1.3443	1.4289	1.3443	1.307	1.4003	1.3717
12			1.448		1.3443		1.3527
13	1.467	1.4003	1.4289	1.4003	1.307	1.4003	1.3146
14	1.5813	1.4563	1.448	1.3817	1.4563	1.4003	1.448
15	1.5813	1.531	1.6004	1.419	1.531	1.5497	1.467
16	1.5432	1.419		1.475	1.4563	1.5123	
17	1.3527	1.2696	1.3527		1.3443	1.4377	1.2003
18	1.3336	1.2323	1.3336	1.307	1.2696	1.2323	1.1812
19	1.4098	1.4563	1.6194	1.3817	1.3443	1.307	1.2574
20	1.8671	1.6617	1.7337	1.6804	1.6057	1.6617	1.5432
21	1.9624	1.7924	1.8671	1.7737	1.8298	1.8111	
22	2.21		2.0195	1.9978	2.1285		
23	2.4196		2.4006			2.4646	
24	2.4272	2.4006	2.4086	2.4577	2.3525	2.5393	2.5766
Max	2.4272	2.4006	2.4086	2.4577	2.3525	2.5393	2.5766
Min	1.3256	1.2323	1.3336	1.307	1.2696	1.2323	1.1812
Avg	1.6496	1.5693	1.6089	1.5812	1.5207	1.5851	1.5469

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 203 / 11 KV CBD SEC 8 B Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							1.2696
2		1.0479		1.0479			
3	1.0456	.9526	1.0829	.9526			1.0082
4	1.0456	.8573	.9709	.8764	1.0456	1.0829	
5	.9335	.8002	.8962	.8764	.9335	.9335	.9335
6	.8962	.7621	.8402	.8764	.7842	.8589	.8962
7	.7842	.7621	.7468	.743	.8215	.8589	.8402
8	.8215	.7811	.7095	.743	.8402	.8775	
9		.7095	.8589	.8589	.8402	.8589	.8775
10	.8764	.7842	.8954	.7842	.8215	.8215	.7811
11	.8573	.7468	.8383	.8402	.8589		.8002
12	.8573		.8764		.7842		.8192
13	.8383	.8029	.8192	.7468	.8215	.7842	.7621
14	.8192	.7842	.8573	.7468		.7468	.8383
15	.8573	.8589	.8764	.8962	.8402	.8775	.8002
16	.8573	.7842		.8589	.8215	.8775	
17	.8764	.6722	.7811		.7842	.7095	.724
18	.8954	.7842	.7811	.8402	.6535	.7095	.6668
19	.9335	.8962	.9526	.8775	.8402	.8215	.8573
20	1.0479	.9709	1.0669	1.0456	.9896	1.0269	.9907
21	1.1431	1.0269	1.086	.9896	1.0829	1.1016	
22	1.2955		1.1812	1.1203	1.1576		
23	1.3717		1.2574			1.3443	
24	1.419	1.3146	1.307	1.3336	1.3443	1.3443	1.363
Max	1.419	1.3146	1.307	1.3336	1.3443	1.3443	1.363
Min	.7842	.6722	.7095	.743	.6535	.7095	.6668
Avg	.9749	.8550	.9372	.9027	.8982	.9242	.8958

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 204 / 11 KV S/STN T/F SECT-06 Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.1867
2		.1905		.1524			
3	.168	.1524	.168	.1334			.168
4	.1494	.1334	.1494	.1334	.1494	.1494	
5	.1494	.1143	.1494	.1334	.1494	.1494	.1307
6	.1307	.1143	.1307	.1143	.1307	.1307	.1307
7	.112	.1143	.112	.1334	.112	.1307	.1307
8	.1307	.1143	.112	.1143	.112	.112	
9		.112	.1307	.0934	.112	.112	.1307
10	.1334	.0934	.1334	.1307	.112	.0934	.1143
11	.0953	.112	.1143	.112	.112		.0953
12	.1143		.1334		.112		.1143
13	.1143	.112	.1334	.112	.0934	.0934	.1143
14	.1143	.112	.1334	.1494		.112	.1524
15	.1143	.112	.1334	.1307	.112	.1307	.1143
16	.1143	.112		.1307	.1307	.112	
17	.1334	.0934	.1143		.112	.0934	.1143
18	.1143	.112	.0953	.112	.112	.0934	.0953
19	.1334	.1307	.0953	.1307	.112	.112	.1143
20	.1334	.1307	.1334	.1494	.1307	.1494	.1524
21	.1524	.1494	.1715	.1867	.1494	.1494	
22	.2096		.1715	.1867	.168		
23	.2286		.1905			.2241	
24	.2054	.2096	.1867	.1905	.2241	.2054	.2241
Max	.2286	.2096	.1905	.1905	.2241	.2241	.2241
Min	.0953	.0934	.0953	.0934	.0934	.0934	.0953
Avg	.1405	.1262	.1377	.1365	.1287	.1307	.1343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 206 / 11 KV KENDRIYA SADAN Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.5601
2		.5716		.4763			
3	.4108	.4191	.4481	.4191			.4854
4	.3734	.381	.4108	.3429	.4854	.4108	
5	.3734	.381	.4108	.3429	.4108	.4108	.3734
6	.3734	.362	.3734	.3429	.3361	.3734	.3361
7	.3734	.362	.2987	.3239	.3361	.3361	.3174
8	.4108	.4382	.3547	.362	.3734	.4108	
9		.4668	.4481	.4108	.4108	.4668	.4481
10	.5716	.5228	.7049	.4108	.5601	.6161	.5335
11	.7049	.6161	.7049	.4668	.6535		.6859
12	.743		.7621		.6722		.6097
13	.381	.6908	.724	.4668	.6908	.7095	.6668
14	.724	.7282	.724	.4854		.7095	.6668
15	.743	.6722	.6859	.4854	.6908	.6908	.7049
16	.743	.6722		.4668	.7095	.6535	
17	.6668	.6535	.6287		.6908	.7282	.6859
18	.6668	.6535	.5906	.4481	.5975	.6535	.6287
19	.6859	.6722	.6478	.5228	.6722	.6535	.6097
20	.743	.6535	.6668	.5601	.7095	.7095	.6478
21	.7049	.6348	.6478	.5601	.6722	.7095	
22	.6097		.6097	.5975	.5975		
23	.6287		.6668			.5975	
24	.6348	.6478	.6161	.6287	.5975	.5975	.6161
Max	.743	.7282	.7621	.6287	.7095	.7282	.7049
Min	.3734	.362	.2987	.3239	.3361	.3361	.3174
Avg	.5841	.5600	.5774	.4560	.5719	.5799	.5633

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 207 / 11 KV SECTOR-09 NEW Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							1.307
2		1.0479		1.2384			
3	1.0082	.9526	1.2323	1.1431			1.1203
4	.9335	.8573	1.0456	1.0479	1.0456	1.0082	
5	.8962	.8573	.9335	.8573	.9709	.9335	.9335
6	.8589	.8573	.8962		.8402	.8215	.8215
7	.7468	.8002	.7842	.7811	.7842	.8402	.7842
8	.8402	.8192	.7468	.362	.7842	.8215	
9		.7842	.7468	.7842	.7842	.8215	.7095
10	.7621	.7842	.8192	.7468	.7095	.7655	.743
11	.8002	.7468	.7811	.7468	.7095		.7049
12	.8192		.8192		.7282		.743
13	.8573	.8215	.8192	.7842	.7468	.7468	.7049
14	.7621	.8029	.8764	.8589		.8215	.8192
15	.7621	.8775	.9145	.8962	.8589	.8589	.8192
16	.8764	.7842		.8962		.7655	
17	.7621	.7095	.7811		.8029	.7842	.6668
18	.7811	.7842	.7811	.7468	.7095	.6908	.6668
19	.8383	.9335	1.0098	.7468	.7842	.7095	.7621
20	1.086	1.0269	1.0098	1.0082	.9709	.9709	1.0098
21	1.1812	1.0829	1.105	1.0456	1.0829	1.0829	
22	1.3336		1.2193	1.1203	1.2696		
23	1.448		1.4289			1.4377	
24	1.419	1.3146	1.4563	1.4861	1.4003	1.4563	1.4563
Max	1.448	1.3146	1.4563	1.4861	1.4003	1.4563	1.4563
Min	.7468	.7095	.7468	.362	.7095	.6908	.6668
Avg	.9415	.8822	.9622	.9104	.8879	.9076	.8689

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 208 / 11 KV RBI SEC 10 Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.7468
2		.6478		.6859			
3	.5975	.6478	.6348	.6287			.5601
4	.5975	.6478	.5975	.6287	.7095	.6722	
5	.5601	.6478	.5975	.6287	.6348	.6722	.5601
6	.5601	.6478	.5975	.6287	.5975	.6348	.5601
7	.6722	.6859	.6535	.5906	.6722	.7095	.6348
8	.7468	.8764	.7842	.724	.8589	.7842	
9		1.1949	.9335	.7095	1.419	1.307	1.1576
10	2.2862	2.2405	1.4289	.7468	2.3339	2.2405	2.3053
11	2.572	2.5953	1.4098	.6722	2.6139		2.6673
12	2.5911		1.5813		2.6699		2.6673
13	2.5339	2.5206	1.467	.7842	2.6139	2.5393	2.2862
14	2.5339	2.3712	1.4289	1.0829		2.4272	2.5149
15	2.4958	2.3339	1.5623	1.0082	2.5766	2.3525	2.4006
16	2.4958	2.2779		1.0829	2.6139	2.5393	
17	2.4196	2.1845	1.3908		2.4272	2.4086	2.2481
18	1.7337	1.6244	1.1431	1.0456	1.9418	1.8484	
19	1.4098	1.0269	.8764	.7842	1.0829	1.1576	1.3146
20	.9526	.8589	.8573	.7468	.8775	.7842	.8573
21	.7621	.8589	.8764	.8215	.8215	.7468	
22	.8002		.8383	.8775	.7842		
23	.743		.8383			.7468	
24	.7468	.6859	.7095	.8002	.8215	.8215	.7842
Max	2.5911	2.5953	1.5813	1.0829	2.6699	2.5393	2.6673
Min	.5601	.6478	.5975	.5906	.5975	.6348	.5601
Avg	1.4672	1.3788	1.0098	.7839	1.5300	1.4107	1.5166

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 210 / 11 KV RBI (NEW)

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716						.9335
2		.9145		.8383			
3	.8962	.8383	.9335	.8383			.8962
4	.8962		.8962	.8383	.7842	.7842	
5	.8962	.8383	.8962	.9145	.7842	.7842	.8589
6	.9335		.9335	.6668	.7468	.7842	.7842
7	.8402	.8192	.8402		.7468	.8215	.7468
8	.7842	.8192	.7842	.6859	.8215	.8775	
9		.8962	.8402	.6722	.8402	1.0082	.9522
10	1.2955	1.2136	.8764	.6722	1.2696	1.1203	1.1622
11	1.2574	1.1949	.9526	.6348	1.1763		1.2765
12	1.2955		.9526		1.1763		1.2574
13	1.2193	1.1576	.8002	.7095	1.1949	1.1949	1.2003
14	1.2574	1.2323	.9145	.6722		1.1389	1.2193
15	1.2384	1.1949	.8573	.7095	1.1763	1.5123	1.1431
16	1.2384	1.1763		.7095	1.0829	1.1203	
17	1.086	1.0456	.8383		1.1203	1.1203	1.0479
18	.9335	.8962	.8764	.7095	.9335	.9335	.9145
19	.9145	.9335	.9907	.7468	.8215	.7655	.8383
20	.9145	.8775	.8192	.8589	.9335	.9709	.8383
21	.9907	.8402	.9526	.8402	.9335	.9335	
22	.9335		.9145	.7468	.9335	.9335	
23	.9907		.9907			.9335	
24	.7716	.9717	1.0082	1.0288	.8402	.8962	.9335
Max	1.2955	1.2323	1.0082	1.0288	1.2696	1.5123	1.2765
Min	.7716	.8192	.7842	.6348	.7468	.7655	.7468
Avg	1.0161	.9922	.8985	.7628	.964	.9807	1.0002

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284011 / 33/11kV New Sec 15 CBD S/s

Feeder No / Name : 201 / 11kV New Sec 15 STN Station Trasformer Feeder
TRANSFORME Feeder KV- 11 /
OUTGOING

DATE	01-JUN-17
HR	Load (MW)
11	.0514
Max	.0514
Min	.0514
Avg	.0514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 201 / 11KV PHANASPADA Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5813	1.4918	1.6632	1.6385	1.7187	1.448	1.6004
2	1.7337	1.4918	1.5364	1.2574	1.6632	1.4299	1.7337
3	1.6385	1.3889	1.4632	1.3336	1.4969	1.3969	1.6385
4	1.2003	1.3546	1.39	1.4861	1.4937	1.3969	1.3717
5	1.5432	1.3032	1.3306	1.448	1.4003	1.3937	1.3908
6	1.467	1.2517	1.2936	1.4098	1.4003	1.2803	1.2955
7	1.3717	1.2174	1.2696	1.3336	1.3817	1.3121	1.3336
8	1.3717	1.2003	1.2136	1.2765	1.251	1.3491	1.2003
9	1.2955	1.1317	1.1576	1.2003	1.2696	1.2197	1.1812
10	1.046	1.0349	1.0829	1.2384	1.1389	1.1458	1.086
11	1.046	1.0719	.9896	1.1088	1.0349		.7207
12	1.0117	1.0974	.9907	1.1273	.9979	1.1241	1.0164
13	1.0802	1.0608	1.1622	1.2012	1.0242	1.1241	.9979
14	1.0974	1.0791	1.1622	1.1458	1.0242	1.1431	.9795
15	1.1145	1.1157	1.2193	1.2012	1.0791	1.1622	.9979
16	1.0974	1.0608	1.2193	1.2012	1.0608	1.1241	.9979
17	1.0631	.9877	1.1431	1.2197	1.1706	1.1241	.961
18	1.166	1.134	1.2193	1.2567	1.2437	1.105	.9425
19	1.2346	1.2437	1.2955	1.3491	1.267	1.1431	1.1088
20	1.3889	1.3169	1.467	1.4784	1.3032	1.4289	1.2567
21	1.4232	1.3717	1.6194	1.5708	1.4815	1.4861	1.3121
22	1.6118	1.5893	1.6766	1.7187	1.8107	1.5813	1.4415
23	1.6289	1.6448	1.7528	1.7187		1.7528	1.423
24	1.6766	1.5089	1.7002	1.7909	1.3121	1.4842	1.7147
Max	1.7337	1.6448	1.7528	1.7909	1.8107	1.7528	1.7337
Min	1.0117	.9877	.9896	1.1088	.9979	1.105	.7207
Avg	1.3287	1.2562	1.3341	1.3629	1.3054	1.3111	1.2376

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 202 / 11KV PUJIT PLAZA SECTOR-11 Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4458	.439		.5359	.4435	.5525
2	.4763	.4115		.3429	.462	.4024	.4763
3	.4382	.3772	.4024	.3429	.4294	.3658	.4382
4	.3429	.3772	.3658	.4001	.3734	.3696	.4191
5	.4191	.3429	.3326	.4001	.3361	.3881	.4191
6	.381	.3258	.3326	.381	.3361	.3361	.4191
7	.4001	.3429	.3696	.3429	.3547	.3547	.3429
8	.4001	.3429	.4066	.362	.3921	.3921	.4191
9	.5144	.4287	.4435	.3429	.5415		.5335
10	.583	.5853	.5914	.362	.6722	.6348	.6478
11	.6344	.567	.5729	.3511	.6348		.6401
12	.6173	.567	.6287	.3696		.6478	.5914
13	.5658	.5853	.6478	.4066	.6468	.6668	.6099
14	1.1145	.6036	.6097	.3881	.6584	.6859	.5914
15	.6173	.6154	.6287	.4251	.7023	.6668	.6468
16	.6173	.5973	.5716	.4251	.6468	.6097	.6099
17	.5658	.5792	.5525	.3881	.5914	.6478	.5729
18	.5658	.5121	.4763	.3511	.5175	.5906	.5175
19	.5144	.4755	.4572	.3696	.4755	.5144	.462
20	.4973	.439	.4001	.4066	.4572	.4572	.4251
21	.4458	.4207	.4191	.4435	.439	.4954	.4251
22	.5144	.462	.4572	.499	.499	.5144	.462
23	.5316	.4805	.5716	.5914	.4435	.6287	.462
24	.5144	.5144		.5525	.5544	.4435	.6097
Max	1.1145	.6154	.6478	.5914	.7023	.6859	.6478
Min	.3429	.3258	.3326	.3429	.3361	.3361	.3429
Avg	.5304	.4750	.4853	.4019	.5087	.5116	.5122

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 203 / 11KV BELAPUR DTC Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907		1.0829	1.2003	1.251	1.2323	1.3527
2	1.2003		1.0456	1.105	1.1576	1.1458	1.2003
3	1.086		.9979	1.1431	1.0456	1.0719	1.086
4	1.1241		.961	1.0098	.9709	.961	1.1431
5	.9907		.8779	.9907	.9335	.8962	1.105
6	.9335		.8413	.8764	.9335	.8589	1.0288
7	.9526		.8131	.8383	.9149	.8488	.8383
8	.8573		.8215	.8192	.8488	.8299	1.0098
9	.8573		.8029	.8192	.8488	.7545	.9717
10		.7282	.6722	.7811	.7545	.6413	.8383
11		.6722	.6348	.7133	.6224		.7577
12		.6099	.8192	.695	.6722	.7621	.7577
13			.743	.7316	.7282	.7049	.8131
14		.6584	.7811	.7682	.7947	.724	.8131
15		.6878	.743	.8131	.6468	.8192	.8686
16		.6878	.8383	.8131	.6767	.7811	.7947
17		.6697	.7811	.8131	.695	.7811	.8316
18		.8238	.743	.7577	.7682	.8764	.7392
19		.8238	.8002	.9055	.8131	.8383	.924
20		.8507	.9145	.9709	.9055	1.1431	1.0719
21		.8869	1.0098	1.0642	.8962	1.2384	1.1088
22		1.0608	1.086	.9335	1.0642	1.3717	1.251
23		1.1273	1.2765	1.251	1.2136	1.6004	1.307
24	.8573		1.1763	1.2765	1.2696	1.2696	1.5432
Max	1.2003	1.1273	1.2765	1.2765	1.2696	1.6004	1.5432
Min	.8573	.6099	.6348	.695	.6224	.6413	.7392
Avg	.9850	.7913	.8860	.9204	.8927	.9631	1.0065

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 204 / 11KV S/STN TRANSFORMER Urban/Sheddable Urban Feeder
R.M.U S Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0686	.0762	.0762	.0762	.0762	.0762
2	.0572	.0686	.0762	.0762	.0762	.0762	.0762
3	.0572	.0686	.0762	.0572	.0762	.0762	.0572
4	.0572	.0686	.0572	.0572	.0762	.0762	.0762
5	.0762	.0686	.0572	.0762	.0762	.0762	.0762
6	.0762	.0514	.0572	.0762	.0762	.0762	.0762
7	.0762	.0514	.0572	.0762	.0762	.0572	.0762
8	.0762	.0686	.0572	.0762	.0762	.0572	.0762
9	.0762	.0686	.0953	.0762	.0762	.0762	.0762
10	.0514	.0572	.0572	.0762	.0762	.0572	.0762
11	.0514	.0762	.0572	.0572	.0572		.0762
12	.0514	.0762	.0762	.0572	.0572	.0762	.0572
13	.0514	.0762	.0762	.0762	.0572	.0762	.0762
14	.0514	.0762	.0762	.0762	.0572	.0762	.0762
15	.0514	.0762	.0762	.0572	.0572	.0762	.0762
16	.0514	.0762	.0762	.0572	.0572	.0762	.0572
17	.0514	.0762	.0762	.0572	.0572	.0762	.0572
18	.0514	.0762	.0762	.0762	.0762	.0762	.0762
19	.0514	.0762	.0762	.0572	.0762	.0762	.0762
20		.0762	.0762	.0572	.0762	.0762	.0572
21		.0762	.0762	.0572	.0762	.0762	.0762
22			.0762	.0762	.0572	.0762	.0572
23		.0762	.0762	.0762	.0762	.0762	.0572
24	.0762	.0686	.0762	.0762	.0762	.0762	.0762
Max	.0762	.0762	.0953	.0762	.0762	.0762	.0762
Min	.0514	.0514	.0572	.0572	.0572	.0572	.0572
Avg	.0610	.0706	.0715	.0683	.0699	.0737	.0707

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 205 / 11KV SAI VIHAR Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432		1.4045	1.5051	1.4299	1.4661	1.5242
2	1.3717		1.2936	1.2193	1.3032	1.3969	1.3717
3	1.2765		1.2437	1.2193	1.1584	1.3611	1.2765
4	1.2003		1.1706	1.2003	1.086	1.2308	1.2765
5	1.2384		1.1584	1.1812	1.0745	1.0498	1.2193
6	1.086		1.1222	1.0669	1.0745	1.0566	1.2003
7	1.1622		1.1706	1.0669	1.0745	1.1104	1.0669
8	1.3717		1.1458	1.1241	1.1462	1.1462	1.2955
9	1.4861		1.2936	1.1812	1.4685	1.6476	1.5623
10		1.8111	1.6263	1.2765	1.9521	1.9879	1.7909
11		1.922	1.8665	1.3491	2.0774		2.2361
12			2.2291	1.4045	2.0416	2.3243	2.0513
13		2.0485	1.9052	1.4266	1.9845	2.2862	1.9774
14		2.1216	1.9052	1.4632	1.9667	2.21	2.1253
15		2.1807	1.9624	1.4266	2.1209	2.4387	2.2546
16		2.0485	1.9243	1.4266	1.9631	2.3434	2.0698
17		1.8656	1.7337	1.3352	1.893	2.3053	2.0328
18		1.7558	1.6004	1.2986	1.7703	2.0005	1.848
19		1.6095	1.6766	1.5181	1.701	2.0005	1.6632
20		1.6278	1.7147	1.5565	1.6124	1.7718	1.6448
21		1.6461	1.7909	1.6289	1.5592	1.848	1.5524
22		1.6263	1.6956	1.6289	1.5939	1.7718	1.4529
23		1.5893	1.6956	1.7194	1.7013	1.848	1.2048
24	1.6766		1.5339	1.6575	1.5384	1.5203	1.7337
Max	1.6766	2.1807	2.2291	1.7194	2.1209	2.4387	2.2546
Min	1.086	1.5893	1.1222	1.0669	1.0745	1.0498	1.0669
Avg	1.3413	1.8348	1.5776	1.3700	1.5955	1.7444	1.6430

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 206 / 11KV CHROMA SECTOR-15 Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.3772	.4435	.3429	.4435	.4854	.4763
2	.4191	.3429	.3841	.3239	.4066	.4435	.4191
3	.4001	.3086	.3292	.3429	.3772	.4066	.4001
4	.3239	.2915	.3292	.362	.3772	.3658	.4001
5	.362	.2743	.3511	.362	.3772	.3547	.362
6	.3429	.2743	.3511	.3429	.381	.4108	.362
7	.362	.3429	.3326	.3429	.381	.4572	.3429
8	.4954	.4287	.3142	.362	.4572	.4954	.4763
9	.5144	.463	.3696	.3429	.4954	.5716	.5144
10	.7716	.6219	.5914	.4001	.7282	.7049	.743
11	.9259	.8779	.7762	.5792	.9522		1.0185
12	.9431	.9694	1.086	.5973	.9709	1.0669	1.0374
13	.9602	.9694	.9335	.6283	1.0082	1.1241	1.0562
14	.9602	.9511	.9145	.6468	.9522	1.105	1.0374
15	.9602	.9511	.8383	.6838	1.0082	1.086	1.0185
16	.9259	.8962	.8192	.6838	1.0082	1.086	.9997
17	.8745	.8507	.8002	.6468	.9709	1.0098	.9149
18	.7545	.8145	.724	.6099	.924	.9526	.8215
19	.7545	.7964	.7621	.6283	.8501	.8192	.8131
20	.703	.7421	.7621	.6838	.7865	.7621	.7762
21	.6173	.7133	.724	.7392	.7865	.7621	.6838
22	.5487	.5853	1.6956	.6653	.6584	.6668	.5544
23	.463	.5359	.5906	.5544	.5729	.6478	.5175
24	.6097	.4115	.499	.5335	.4435	.5228	.5716
Max	.9602	.9694	1.6956	.7392	1.0082	1.1241	1.0562
Min	.3239	.2743	.3142	.3239	.3772	.3547	.3429
Avg	.6461	.6163	.6551	.5169	.6799	.7090	.6799

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 207 / 11KV OLD R.M.U SECTOR-15 Urban/Sheddable Urban Feeder
S/Stn Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.3772	.3544	.4572	.4344	.3982	.4763
2	.4382	.3601	.3189	.3239	.3506	.362	.4382
3	.381	.3429	.2865	.3048	.3155	.3582	.381
4	.3239	.3086	.2865	.362	.3155	.3403	.381
5	.3429	.3086	.2896	.3239	.2804	.3224	.381
6	.2858	.3086	.2534	.3239	.2774	.2804	.3239
7	.2477	.2572	.2534	.2667	.2774	.2774	.2667
8	.2286	.2743	.2172	.2667	.2427	.2427	.2667
9	.5716	.5487	.2534	.3048	.2774	.5028	.3429
10	.4801	.4525	.543	.2667	.5028	.4207	.5335
11	.4287	.5068	.5068	.2715	.4334		.4161
12	.4287	.5373	.4763	.2896	.4115	.5906	.4161
13	.5487	.5373	.6097	.3403	.4287	.4954	.5028
14	.5144	.5014	.4763	.2865	.4287	.6287	.4334
15	.4458	.4607	.6097	.3224	.4458	.5335	.5548
16	.4801	.4607	.5144	.3224	.5487	.6097	.4854
17	.5144	.4252	.4954	.3224	.5201	.4763	.5028
18	.4287	.3856	.5525	.3403	.4854	.5144	.3988
19	.2572	.2804	.5716	.2865	.3814	.4954	.3544
20	.2915	.2454	.3429	.2896	.2947	.3239	.3012
21	.3772	.3681	.362	.3801	.3681	.362	.2835
22	.3772	.5083	.381	.4163	.4207	.4191	.3155
23	.4115	.4607	.4382	.4344	.443	.4763	.3155
24	.4763	.4115	.443	.4572	.4344	.4344	.5144
Max	.5716	.5487	.6097	.4572	.5487	.6287	.5548
Min	.2286	.2454	.2172	.2667	.2427	.2427	.2667
Avg	.4041	.4012	.4098	.3317	.3883	.4289	.3994

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 208 / 11KV GREAT EASTERN SUMMIT Urban/Sheddable Urban Feeder
SECT Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9243		1.6448	1.7528	1.7013	1.6651	1.9052
2	1.8099		1.5524	1.5051	1.5592	1.576	1.8099
3	1.7718		1.4266	1.4098	1.4706	1.5043	1.7718
4	1.448		1.3535	1.5242	1.3032	1.3672	1.5432
5	1.5432		1.2437	1.4289	1.2003	1.2795	1.4861
6	1.3908		1.1827	1.3336	1.0974	1.2136	1.3336
7	1.2384		1.1088	1.1622	1.0631	1.1145	1.1622
8	1.2955		1.0719	1.1622	1.166	1.0802	1.3146
9	1.6004		1.2567	1.1622	1.3717	1.4575	1.5242
10		2.0328	1.7556	1.1241	1.9376	1.8313	1.9624
11		2.1765	1.9959	1.1831	2.1948	2.4006	2.3045
12		2.3045	2.4387	1.1317		2.4387	2.2131
13		2.396	2.0576	1.2934	2.1672	2.3434	2.2131
14		2.4579	2.0386	1.2757	2.1498	2.4196	2.2131
15		2.4949	2.1338	1.4175	2.2365	2.4958	2.4326
16		2.1807	2.1148	1.4175	2.2192	2.4577	2.2497
17		1.9936	1.8861	1.382	1.9418	2.2672	2.0668
18		1.8656	1.5623	1.3112	1.893	2.1529	1.9204
19		1.6278	1.6004	1.3466	1.6827	1.8671	1.7528
20		1.5912	1.5813	1.4563	1.5238	1.7147	1.5074
21		1.5893	1.6194	1.5083	1.5947	1.6194	1.4373
22		1.7372	1.6004	1.491	1.6478	1.7147	1.3717
23		1.7741	1.7528	1.647	1.7909	1.9052	1.3889
24	2.0576		1.8111	1.8099	1.8099	1.7737	1.9433
Max	2.0576	2.4949	2.4387	1.8099	2.2365	2.4958	2.4326
Min	1.2384	1.5893	1.0719	1.1241	1.0631	1.0802	1.1622
Avg	1.6080	2.0159	1.6579	1.3848	1.6836	1.8192	1.7845

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284061 / 33/33KV SBI IDBI NMMC

Swt/Stn

Feeder No / Name : 401 / 33KV SBI - 2

HV Express Feeder

Feeder KV- 33 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.503	.4344	.5658	.4681	.5658	.463
2	.4458	.4475	.4344	.5658	.4115	.5658	.4161
3	.4458	.3932	.4344	.5144	.407	.5144	.3561
4	.4458	.3978	.4344	.5144	.3521	.5144	.3601
5	.4458	.3521	.4344	.5144	.3052	.5658	.3121
6	.4458	.3052	.4344	.5658	.3601	.5658	.2629
7	.4458	.3601	.4344	.6173	.4733	.5144	.3721
8	.503	.5258	.5344	.6173	.5973	.6687	.4298
9	.8356	.5258	.8745	.6173	.7682	.9259	.499
10	.9259	.7682	1.1831		.8316	1.0642	1.0642
11	.9882	1.0082	1.2346		1.1763	1.0534	1.1763
12	1.0517	1.1763	1.1831		1.1763	1.1203	1.1763
13	1.1163	1.1763	1.1831		.4252	1.1643	1.1203
14	1.1946	1.1763	1.1831		1.1831	1.2323	1.1763
15	1.1523	1.1763	1.1831		1.1831	1.1643	1.1763
16	1.1088	1.1763	1.1831		1.1317	1.1203	1.1763
17	1.1203	.7282	1.0288		1.0802	1.1088	1.0082
18	1.0425	.7042	.9774	.8871	.9259	1.0425	.7682
19	.9774	.6882	.7202	.9522	.7716	.9231	.7202
20	.8596	.6882	.6687	.8316	.6687	.8059	.6464
21	.7888	.5218	.6173	.7682	.6173		.5344
22	.7282	.503	.5658	.6447	.6173	.631	.503
23	.6687	.4458	.5658	.5316	.6173	.5721	.4572
24	.4572	.5658	.4458	.5658	.4527	.6173	.5658
Max	1.1946	1.1763	1.2346	.9522	1.1831	1.2323	1.1763
Min	.4458	.3052	.4344	.5144	.3052	.5144	.2629
Avg	.7767	.6797	.7655	.6421	.7084	.8270	.6975

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284061 / 33/33KV SBI IDBI NMMC

Swt/Stn

Feeder No / Name : 404 / 33KV NMMC - 2 (1)

HV Express Feeder

Feeder KV- 33 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1286	.2572	.1286	.1543	.1509	.1543	.2486
2	.1286	.2543	.1286	.1543	.1492	.1543	.2458
3	.1286	.2012	.1286	.1543	.1475	.1543	.2012
4	.1286	.1989	.1286	.1543	.1492	.1543	.2058
5	.1286	.1966	.1286	.1543	.2012	.1543	.156
6	.1286	.144	.1286	.1543	.2035	.1543	.1578
7	.1286	.2401	.1286	.1543	.2572	.1543	.2658
8	.1303	.2401	.1783	.1543	.3121	.1543	.3761
9	.5596	.2846	.5847	.1543	.3681	.6687	.4938
10	.6584	.3281	.6687	.1457	.4835	.7842	.7356
11	.7207	.8488	.6687	.1475	.8488	.8316	.8488
12	.7842	.8488	.7202	.1492	.8145	.8779	.8488
13	.8316	.8488	.7202	.1509	.6687	.9425	.8488
14	.8779	.8488	.6687	.2035	.7202	.9877	1.1883
15	.8316	.7922	.6687	.2058	.7716	.9425	.8488
16	.7682	.7922	.6687	.208	.7202	.8779	.8488
17	.7207	.5258	.7202	.2103	.7716	.8145	.7922
18	.6584	.4115	.6173	.2126	.6687	.7522	.5258
19	.5973	.1943	.1543	.2149	.463	.6379	.1829
20	.5373	.1898	.1543	.2172	.3601		.1286
21	.4252	.1372	.1543	.1612	.1543		.1303
22	.3681	.1337	.1543	.1595	.1543	.3601	.1286
23	.3121	.1286	.1543	.156	.1543	.3052	.1286
24	.1286	.2515	.1286	.1543	.4578	.1543	.3601
Max	.8779	.8488	.7202	.2172	.8488	.9877	1.1883
Min	.1286	.1286	.1286	.1457	.1475	.1543	.1286
Avg	.4504	.3874	.3619	.1702	.4229	.5078	.4540

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 201 / 11 KV Sector-19 Ulwe Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7					1.467		
8		1.2765	1.3146	1.3527	1.3527		
9	1.2955	1.2193	1.3336			1.3336	
10	1.3717	1.3336	1.3908				
11	1.4098	1.3717	1.3908		1.3146		
12		1.4098	1.4289		1.3336		
13	1.3336	1.3908	1.3336		1.2574	1.3336	
14		1.4098					1.3146
15	1.448				1.4098	1.5432	
16						1.5051	
17	1.4289		1.3908		1.3908	1.5051	1.3717
18	1.448	1.448	1.2574		1.2574	1.4861	
19	1.5242	1.5242	1.448	1.5051			
20	1.6194			1.5242			
21				1.5242			
22				1.7528		1.7147	
23	1.9862			1.8671	1.829	1.6956	
24	1.8861	1.8861	1.7528		1.7909		1.6575
Max	1.9862	1.8861	1.7528	1.8671	1.829	1.7147	1.6575
Min	1.2955	1.2193	1.2574	1.3527	1.2574	1.3336	1.3146
Avg	1.5229	1.4270	1.4041	1.5877	1.4403	1.5146	1.4479

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 202 / 11 KV Sector-21 Ulwe Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7					.3048		
8		.3048	.2858	.2858	.3048		
9	.2858	.2858	.2858			.2667	
10	.2667	.2667	.2858				
11	.2858	.2858	.3239		.3048		
12		.2858	.3048		.2858		
13	.2667	.2477	.2858		.2477	.2858	
14		.2667					.3048
15	.3048				.2858	.2858	
16						.2858	
17	.2477		.3239		.2667		.2667
18	.2477	.2858	.2667		.2286	.2858	
19	.2667	.2858	.2858	.3429		.2858	
20	.3239			.3429			
21				.362			
22				.362		.4382	
23	.4572			.4191	.4382	.4382	
24	.4382	.4382	.4191		.4572		.4382
Max	.4572	.4382	.4191	.4191	.4572	.4382	.4382
Min	.2477	.2477	.2667	.2858	.2286	.2667	.2667
Avg	.3083	.2953	.3067	.3525	.3124	.3215	.3366

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 203 / 11 KV Unnati Feeder Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7					.8192		
8		.7049	.724	.7811	.743		
9	.8002	.7621	.7049			.724	
10	.7049	.7049	.6859				
11	.6859	.6859	.7049		.6668		
12		.6668	.6668		.6859		
13	.6478	.7621	.6668		.6859	.6287	
14		.724					.6287
15	.7621				.724	.7811	
16						.7049	
17	.6668		.6859		.6668	.7049	.6478
18	.6287	.6859	.6287		.6287	.6668	
19	.7621	.7811	.7811	.724		.7811	
20	.9145			.8383			
21				1.0669			
22				1.0479		.9717	
23	1.1241			1.1241	1.1812	1.086	
24	1.1431	1.105	1.0479		1.086		1.105
Max	1.1431	1.105	1.0479	1.1241	1.1812	1.086	1.105
Min	.6287	.6668	.6287	.724	.6287	.6287	.6287
Avg	.8037	.7583	.7297	.9304	.7888	.7832	.7938

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 204 / 11 KV Sector-5 Feeder Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7					.6859		
8		.6478	.6478	.6478	.6478		
9	.6478	.5716	.6097			.6097	
10	.5335	.5144	.5335				
11	.5525	.5144	.5716		.4954		
12		.5335	.5335		.5335		
13	.5716	.5716	.5716		.5716	.5716	
14		.5525					.5716
15	.6668				.6097	.6097	
16						.6097	
17	.6287		.4954		.5525	.6097	.5716
18	.5525	.6287	.5525		.5716	.5716	
19	.6478	.7049	.6287	.6097			
20	.7621			.724			
21				.8002			
22				.8954		.9335	
23	.9145			.9145	.9717	.9526	
24	.9335	.9335	.9717		.9335		.9526
Max	.9335	.9335	.9717	.9145	.9717	.9526	.9526
Min	.5335	.5144	.4954	.6097	.4954	.5716	.5716
Avg	.6738	.6173	.6116	.7653	.6573	.6835	.6986

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 205 / 11 KV Sector-20 Feeder Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7					.4572		
8		.4382	.4382	.4382	.4382		
9	.3048	.4382	.4382			.4572	
10	.4572	.4191	.4572				
11	.4572	.4191	.4382		.4191		
12		.4382	.4382		.4382		
13	.4382	.4191	.4763		.4191	.4382	
14		.4191					.4191
15	.4572				.4382	.4763	
16						.4954	
17	.4572		.4763		.5144	.4954	.4382
18	.4191	.4382	.4382		.4763	.4954	
19	.4572	.4572	.4954	.4954			
20	.5335			.5716			
21				.5716			
22				.5525		.5716	
23	.6097			.6097	.6478	.6668	
24	.6097	.6097	.6097		.6287		.6668
Max	.6097	.6097	.6097	.6097	.6478	.6668	.6668
Min	.3048	.4191	.4382	.4382	.4191	.4382	.4191
Avg	.4728	.4496	.4706	.5398	.4877	.5120	.5080

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 206 / 11 KV Sec-5 Plot No-70 Urban/Sheddable Urban Feeder
Ulwe Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7					.0572		
8		.0381	.0572	.0572	.0572		
9	.0572	.0381	.0572			.0572	
10	.0381	.0381	.0572				
11	.0572	.0572	.0572		.0572		
12		.0572	.0572		.0572		
13	.0572	.0381	.0572		.0762	.0572	
14		.0381					.0572
15	.0572				.0572	.0572	
16						.0572	
17	.0572		.0572		.0572	.0572	.0572
18	.0572	.0381	.0381		.0381	.0572	
19	.0381	.0381	.0572	.0572			
20	.0572			.0572			
21				.0572			
22				.0572		.0572	
23	.0572			.0762	.0762	.0762	
24	.0572	.0572	.0572		.0762		.0572
Max	.0572	.0572	.0572	.0762	.0762	.0762	.0572
Min	.0381	.0381	.0381	.0572	.0381	.0572	.0572
Avg	.0537	.0438	.0553	.0604	.0610	.0596	.0572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 208 / 11 KV Wahal Sec-23 Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7					1.4289		
8		1.2574	1.3908	1.3527	1.3527		
9	1.4289	1.3336	1.3336			1.2955	
10	1.2574	1.1812	1.2955				
11	1.3146	1.2384	1.2193		1.2955		
12		1.448			1.2765		
13	1.3336	1.3908	1.3527		1.2384	1.1431	
14		1.5242					1.3336
15	1.5051				1.448	1.5623	
16						1.3908	
17	1.2765		1.4098		1.2765	1.3336	1.2574
18	1.1431	1.3717	1.2384		1.1812	1.2384	
19	1.467	1.5051	1.4861	1.2955			
20	1.7147			1.5242			
21				1.6956			
22				1.9052		2.0386	
23	1.9433			2.0386	2.0767	2.0957	
24	2.0576	1.9814	1.9814		2.0576		2.0005
Max	2.0576	1.9814	1.9814	2.0386	2.0767	2.0957	2.0005
Min	1.1431	1.1812	1.2193	1.2955	1.1812	1.1431	1.2574
Avg	1.4947	1.4232	1.4120	1.6353	1.4632	1.5123	1.5305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

M/S LNT SEAWOODS PVT. BU 4893
LTD.[893]

Substation No/ Name :- 284010 / 33/11 KV L & T Seawoods

Feeder No / Name : 201 / TOWER 1 Franchisee feeder(<=33 KV)

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0229	.0286	.0095	.021	.0229	.0152	.0267
2	.0229	.0267	.021	.021	.0229	.0152	.0286
3	.0191	.0191	.0152	.0229	.021	.0114	.0305
4	.0152	.0229	.0152	.021	.0229	.0171	.0305
5	.0229	.021	.0229	.0171	.0171	.0171	.0171
6	.021	.021	.0171	.0171	.0171	.0171	.0324
7	.0229	.021	.021	.0229	.0229	.0191	.0171
8	.0229	.0248		.0286	.0286	.0362	.0324
9	.0286	.0267	.0229	.0305	.0324	.04	.0286
10	.0267		.0248	.0229	.0286	.0362	.0324
11	.0305	.0324	.0343	.0362	.0362	.04	.0229
12	.0305	.0362	.0286	.0286		.04	.0324
13	.0324	.0286	.0305	.0362	.0362	.0343	.1296
14	.0171	.0324	.0362	.0362	.04	.0362	.4858
15	.0267	.0362	.0343	.0286	.0305	.04	.0362
16			.0191	.0305	.0362	.101	.1105
17	.0305	.0362	.0362	.0343	.0343	.1029	.04
18	.0286	.0514	.0229	.0324	.0362	.04	.0229
19	.0324	.0362	.0362	.0305	.0343	.0229	.0419
20	.0267	.0324	.0362	.0286	.0324	.0229	.0362
21	.0267	.0229	.0286	.0305	.0305	.0362	.0305
22	.0229	.0305	.0229	.0305	.0171	.0171	
23	.0229	.0229	.0171		.0229	.0229	.0305
24	.021	.0229	.0229	.0229	.0267	.0171	
Max	.0324	.0514	.0362	.0362	.04	.1029	.4858
Min	.0152	.0191	.0095	.0171	.0171	.0114	.0171
Avg	.0250	.0288	.0250	.0274	.0283	.0333	.0589

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

M/S LNT SEAWOODS PVT. BU 4893
LTD.[893]

Substation No/ Name :- 284010 / 33/11 KV L & T Seawoods

Feeder No / Name : 202 / Tower 2

Franchisee feeder(<=33 KV)

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.16	.1619	.3277	.1848	.1734	.3258	.0514
2	.1638	.0914	.3334	.1962	.1924	.3277	.1638
3	.1619	.0495	.3391	.1886	.1734	.3334	.0495
4	.1029	.0533	.3315	.2115	.1581	.3334	.0514
5	.16	.1619	.3582	.1886	.1696	.3258	.1048
6	.1658	.1867	.341	.2	.1791	.3372	.1086
7	.1696	.2763	.3334	.1924	.181	.3563	.1829
8	.282	.8478	.3601	.2058	.804	.7926	.663
9	.3334	.2991	.3334	.2039	.7468	.7849	.5887
10	.3563	.8916	.4325	.6821	.8211	.7868	.5163
11	.3582	.8288	.7145	.4439	.823	.8897	.684
12	.3944	.8211	.4363	.7068		.764	.6611
13	.4268	.8326	.684	.4306	.8078	.7049	.8707
14	.3963	.823	.7411	.6001	.8307	.7373	.6516
15	.3563	.8916	.4744	.4515	.8421	.6497	.6649
16	.4039	.8554	.5087	.6611	.8269	.6668	.7888
17	.4134	.8135	.6992	.4344	.7964	.6573	.7202
18	.3487	.7888	.4782	.4249	.7907	.6611	.7354
19	.3334	.5316	.4115	.4134	.4896	.4896	.7202
20	.2991	.4306	.3944	.3887	.4896	.4763	.4896
21	.1886	.3849	.4039	.3944	.3525	.3849	.4172
22	.1829	.3544	.3734	.3753	.341	.1638	
23	.1658	.3525	.2096	.1734	.3277	.1715	
24	.1715	.1848	.3315	.2058	.1658	.3258	.1524
Max	.4268	.8916	.7411	.7068	.8421	.8897	.8707
Min	.1029	.0495	.2096	.1734	.1581	.1638	.0495
Avg	.2706	.4964	.4313	.3566	.4992	.5186	.4562

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

M/S LNT SEAWOODS PVT. BU 4893
LTD.[893]

Substation No/ Name :- 284010 / 33/11 KV L & T Seawoods

Feeder No / Name : 203 / Retail 1 Franchisee feeder(<=33 KV)

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2458	.2172	.2324	.2591	.301	.2305
2	.2572	.2172	.1505	.2705	.1734	.2991	.2534
3	.2648	.2134	.1429	.2248	.221	.3029	.2667
4	.2115	.2096	.1391	.2172	.2515	.141	.2477
5	.1524	.2153	.2134	.2267	.242	.1391	.2229
6	.2191	.1943	.1315	.2267	.2172	.1372	.221
7	.1658	.1848	.2248	.2248	.2229	.202	.2572
8	.2496	.1848	.261	.1829	.2	.2172	.2515
9	.282	.2058	.2743	.3182	.2591	.2991	.2572
10	.5392	.7564	.7335	.8421	1.789	1.8214	.7583
11	2.0157	2.2577	1.8233	2.5149	2.4139	2.3396	1.9909
12	1.789	2.5225	2.1681	2.4901		2.2672	1.9909
13	1.8138	2.2805	2.1167	2.2462	2.2653	2.0138	1.6404
14	1.8061	1.8957	2.151	2.3034	1.7661	1.6556	1.6099
15	2.2424	2.4272	1.5737	2.2996	2.0309	2.09	1.8728
16	2.1776	2.1434	2.3396	2.3243	1.7661	1.8138	1.9281
17	1.9719	2.3282	2.3167	2.3091	2.1853	2.1357	1.5565
18	2.1586	2.4158	2.0881	2.1586	2.0938	2.0328	1.9223
19	2.0138	2.3624	2.2996	2.2729	2.1472	1.9757	1.8652
20	2.1795	2.2043	1.7414	2.2234	2.0786	1.8957	1.9338
21	2.0614	2.1281	1.7814	2.2996	2.1033	1.9757	1.9204
22	.5887	.6306	1.728	1.97	.6116	.4096	
23	.3639	.3715	.4706	.4801	.3829	.3391	
24	.2572	.1867	.1524	.3029	.2763	.421	.1772
Max	2.2424	2.5225	2.3396	2.5149	2.4139	2.3396	1.9909
Min	.1524	.1848	.1315	.1829	.1734	.1372	.1772
Avg	1.0849	1.1993	1.1350	1.2984	1.1285	1.1344	1.0625

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

M/S LNT SEAWOODS PVT. BU 4893
LTD.[893]

Substation No/ Name :- 284010 / 33/11 KV L & T Seawoods

Feeder No / Name : 204 / Retail 2 Franchisee feeder(<=33 KV)

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2267	.2553	.1981	.2839	.2534	.3925	.2763
2	.221	.2058	.2	.2458	.2743	.442	.2858
3	.2629	.1924	.2172	.2648	.2591	.4325	.2915
4	.242	.1905	.2343	.2572	.2267	.4115	.2896
5	.2096	.2096	.2191	.2477	.2267	.402	.2896
6	.2191	.1962	.2172	.2382	.242	.3887	.2458
7	.2039	.1886	.1315	.2401	.2153	.3829	.242
8	.6097	.2991	.2191	.2572	.2229	.4134	.2782
9	.6192	.1619	.2134	.4344	.2572	.2991	.3315
10	1.9643	1.1222	.6192	1.467	1.6785	1.749	1.5623
11	2.513	1.9319	1.8519	1.7604	1.93	2.0367	1.9662
12	2.5415	1.7299	1.8176			1.9833	1.9509
13	2.4729	1.6709	2.1472	1.6937	1.8652	1.9947	1.8385
14	2.4006	1.7661	2.0995	1.688	1.7337	2.0252	1.8309
15	2.4082	1.7433	2.1091	1.6518	1.7642	2.0748	1.7871
16	2.2653	1.7128	1.8957	1.6328	1.8214	1.9071	1.89
17	2.1605	1.5985	1.7928	1.6328	1.6766	2.0576	1.7985
18	2.2272	1.6785	1.7833	1.6366	1.7071	1.8747	1.8442
19	1.8766	1.7433	1.7509	1.6747	1.6423	1.8842	1.7985
20	1.8328	1.6975	1.7661	1.6747	1.8061	1.8499	1.8252
21	1.9071	1.6671	1.8576	1.6042	1.6994	1.7585	1.8804
22	.7526	.8002	1.608	1.5699	.8878	.6097	
23	.4191	.3639	.4877	.4839	.5144	.423	
24	.3086	.2591	.2439	.2572	.2705		.3125
Max	2.5415	1.9319	2.1472	1.7604	1.93	2.0748	1.9662
Min	.2039	.1619	.1315	.2382	.2153	.2991	.242
Avg	1.2860	.9744	1.0700	.9955	1.0076	1.2084	1.1280

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

M/S LNT SEAWOODS PVT. BU 4893

LTD.[893]

Substation No/ Name :- 284010 / 33/11 KV L & T Seawoods

Feeder No / Name : 205 / Basement

Franchisee feeder(<=33 KV)

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1296	.1372	.1486	.1619	.1486	.1391	.1296
2	.1429	.1353	.1372	.1486	.1486	.1448	.1448
3	.1315	.141	.1372	.1372	.1638	.1334	.1524
4	.1334	.1429	.1353	.1429	.1581	.1334	.1467
5	.1372	.1429		.1543	.1677	.1372	.1391
6	.1448	.141	.1658	.1467	.1543	.1353	.1391
7	.1353	.1448	.1296	.1467	.1429	.1372	.2877
8	.1448	.1829	.1505	.1677	.1638	.1581	.1334
9	.1905	.2572	.1696	.1715	.1505	.1772	.1238
10	.1886	.1486	.1467	.1943	.1543	.1791	.1734
11	.1943	.1696	.181	.1677	.1848	.1943	.1334
12	.181	.1562	.1829	.1658		.2039	.141
13	.1772	.1658	.1848	.181	.1772	.1734	.1734
14	.1753	.141	.1886	.1696	.181	.1448	.1581
15	.1696	.1505	.1848	.1696	.1696	.1581	.1734
16	.202	.1524	.1677	.1658	.2039	.1391	.1734
17	.1696	.1753	.1486	.141	.1696	.1562	.1734
18	.1867	.1543	.1677	.1772	.1581	.1734	.1753
19	.1886	.1524	.1619	.1753	.1505	.1696	.1658
20	.1505	.1505	.16	.1543	.1677	.1524	.1562
21	.1391	.1486	.1505	.1696	.1619	.1467	.1372
22	.1543	.1391	.1619	.1696	.141	.1372	
23	.1772	.1581	.1619	.1619	.1638	.1638	
24	.1543	.16	.1391	.1524	.1715	.1429	.1505
Max	.202	.2572	.1886	.1943	.2039	.2039	.2877
Min	.1296	.1353	.1296	.1372	.141	.1334	.1238
Avg	.1624	.1562	.1592	.1622	.1632	.1554	.1582

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

M/S LNT SEAWOODS PVT. BU 4893
LTD.[893]

Substation No/ Name :- 284010 / 33/11 KV L & T Seawoods

Feeder No / Name : 206 / Utility Building Franchisee feeder(<=33 KV)
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362	.021	.0229	.0229	.0457	.0362	.0343
2	.0324	.0324	.0267	.04	.0343	.0324	.0362
3	.0324	.0324	.0324	.0305	.0305	.0324	.0324
4	.0324	.0171	.0171	.0343	.0495	.0324	.0324
5	.0286	.0191	.0457	.0343	.0248	.0343	.0171
6	.0324	.0248	.0191	.0305	.0171	.0171	.021
7	.0286	.04	.0324	.0324	.0171	.0305	.0286
8	.0171	.0229	.0514	.0343	.0495	.0152	.021
9	.0514	.021	.0248	.0267	.0324	.04	.0324
10	.0248	.0286	.0267	.0362	.0343	.0305	.0362
11	.0362	.0305	.0476	.0438	.0438	.0324	.021
12	.0343	.0343	.0191	.0305		.0457	.021
13	.0514	.0152	.0324	.0305	.021	.0362	.0362
14	.0362	.0229	.0419	.0152	.0438	.0457	.021
15	.021	.021	.0171	.0324	.0457	.0495	.0229
16	.0343	.0171	.0305	.0381	.0324	.0343	.0324
17	.04		.0495	.021	.04	.0343	.04
18	.0286	.0438	.0419	.0438	.0229	.04	.0343
19	.0229	.0171	.0171	.0324	.0438	.0324	.0229
20	.0305	.0362	.0438	.0343	.0267	.0324	.0229
21	.0267		.0286	.0324	.04	.0343	.0514
22	.021		.0343	.0229	.0343	.0305	
23	.0171	.0438	.0171	.0324	.0324	.0248	
24	.0267	.0438	.0305	.021	.0171	.0343	.0248
Max	.0514	.0438	.0514	.0438	.0495	.0495	.0514
Min	.0171	.0152	.0171	.0152	.0171	.0152	.0171
Avg	.0310	.0279	.0313	.0314	.0339	.0337	.0292

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

M/S LNT SEAWOODS PVT. BU 4893

LTD.[893]

Substation No/ Name :- 284010 / 33/11 KV L & T Seawoods

Feeder No / Name : 209 / Retail 1 Standby

Franchisee feeder(<=33 KV)

Feeder KV- 11 / OUTGOING

DATE	02-JUN-17
HR	Load (MW)
7	.0191
Max	.0191
Min	.0191
Avg	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

M/S LNT SEAWOODS PVT. BU 4893
LTD.[893]

Substation No/ Name :- 284010 / 33/11 KV L & T Seawoods

Feeder No / Name : 211 / Basement Standby Franchisee feeder(<=33 KV)

Feeder KV- 11 / OUTGOING

DATE	03-JUN-17
HR	Load (MW)
5	.1448
Max	.1448
Min	.1448
Avg	.1448

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 201 / 11KV AIR INDIA

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7364	1.7177	1.7177	1.7177	1.7737	1.7924	1.8298
2	1.6617	1.6617	1.5684	1.5684	1.6804	1.6244	1.6804
3	1.5684	1.5684	1.4563	1.4563	1.5684	1.475	1.5123
4	1.4937	1.4937	1.3443	1.3443	1.4937	1.3443	1.3443
5	1.4003	1.4003	1.2696	1.2696	1.419	1.307	1.251
6	1.2696	1.2136	1.1949	1.1576	1.307	1.2323	1.2136
7	1.1576	1.1016	1.0829	1.0082	1.1576	1.1389	1.1203
8	1.0456	1.0269	1.0829	.9149	1.1763	1.0456	1.0269
9	.9896	.9709	1.0456	.9335	1.0269	1.0082	.9709
10	1.0829	1.0082	1.0456	1.0082	1.0082	.9896	.9335
11	1.0456	.9335	1.0642	1.0456	.9335	.9896	.9149
12	.9709	.9896	1.0082	1.0082	.8962	.9896	.9149
13	.9709	.9709	1.0082	.9709	.9335	.9522	.9149
14	1.1576	.9709	1.0269	.9896	.9709	.9896	.9335
15	1.1389	1.1203	1.1203	1.1389	.9335	1.0642	1.0269
16	1.1016		1.1389	1.1389	1.1389	1.0642	.9709
17	1.0642	.9335	.9335	1.1576	1.0829	1.0269	.9149
18	1.0269	1.0269	1.0269	1.1203	1.0269	1.0829	.9896
19	1.0456	1.0642	1.1389	1.0829	1.0642	1.0829	.9709
20	1.307	1.1763	1.1389	1.2136	1.1949	1.251	1.0642
21	1.251	1.1949	.8589	1.251	1.307	1.307	1.1203
22	1.5684	1.4003	1.2136	1.4563	1.4003	1.3817	1.2323
23	1.7364	1.7364	1.6617	1.8111	1.8671	1.8484	1.2696
24	1.8484	1.7551	1.8671	1.7924	1.9605	1.9791	1.9791
Max	1.8484	1.7551	1.8671	1.8111	1.9605	1.9791	1.9791
Min	.9709	.9335	.8589	.9149	.8962	.9522	.9149
Avg	1.2766	1.2363	1.2089	1.2315	1.2634	1.2486	1.1708

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 202 / 11KV JAWAHAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.3921	.3734	.3734	.4294	.4108	.4108
2	.4108	.3734	.3361	.3361	.3734	.3734	.3734
3	.3734	.3361	.3174	.3174	.3361	.3361	.3361
4	.3361	.3174	.2987	.2987	.3174	.3174	.3361
5	.3174	.2987	.2987	.2801	.2987	.2987	.3174
6	.2987	.2801	.2801	.2427	.2987	.2801	.3174
7	.2241	.2614	.2801	.2241	.2801	.2614	.2614
8	.2427	.2054	.3174	.2427	.2427	.2054	.2241
9	.2054	.2241	.2801	.2241	.3174	.2614	.2801
10	.2987	.2801	.3174	.2801	.2987	.2801	.2801
11	.2987	.2801	.3547	.2987	.2614	.2801	.2801
12	.3174	.3174	.3921	.2614	.2534	.2987	.2801
13	.2801	.2801	.3734	.2801	.2801	.2801	.2614
14	.3547	.2801	.4481	.2801	.2614	.2987	.2801
15	.3547	.3547	.4481	.2801	.2801	.3174	.2987
16	.3547		.4108	.2987	.3734	.3361	.2987
17	.3921	.3361	.3174	.3174	.3921	.3361	.3361
18	.2987	.2987	.3174	.3547	.2987	.2427	.2427
19	.2987	.3174	.3734	.3921	.2987	.2801	.2801
20	.3734	.3547	.4108	.4294	.3547	.2987	.2801
21	.2801	.3547	.4294	.3921	.4294	.2987	.2801
22	.4294	.3921	.4481	.3734	.4668	.4108	.3174
23	.4854	.4668	.4294	.4481	.4668	.4668	.3174
24	.4854	.4294	.4294	.4294	.4668	.4481	.4668
Max	.4854	.4668	.4481	.4481	.4668	.4668	.4668
Min	.2054	.2054	.2801	.2241	.2427	.2054	.2241
Avg	.3400	.3231	.3617	.3190	.3365	.3174	.3065

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 203 / 11KV BANK OF INDIA

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.2427	.2054	.2241	.2241	.1867	.1867
2	.1307	.1494	.2054	.2054	.2054	.1867	.1307
3	.112	.1307	.168	.1867	.1867	.1867	.112
4	.112	.112	.168	.168	.168	.168	.112
5	.168	.112	.168	.168	.168	.168	.0934
6	.1494	.168	.2241	.168	.168	.2427	.168
7	.2241	.2241	.2427	.2241	.2241	.2427	.2241
8	.2241	.2241	.2241	.2054	.2054	.2241	.2054
9	.2054	.1867	.2054	.1867	.2241	.2054	.2054
10	.2427	.2241	.2054	.2427	.2427	.2427	.0934
11	.2427	.2427	.1867	.2614	.2614	.2801	.0934
12	.2614	.1494	.1867	.1494	.2614	.2801	.0934
13	.2614	.1494	.112	.1494	.2614	.2614	.0934
14	.2241	.2801	.0934	.2241	.2614	.2427	.0934
15	.2614	.2801	.112	.2241	.2614	.2801	.112
16	.2614		.168	.2241	.2801	.2801	.0934
17	.168	.2614	.2614	.2241	.2987	.2614	.0747
18	.168	.2614	.2427	.2241	.2427	.2427	.0934
19	.1867	.168	.2427	.2241	.2427	.1494	.0934
20	.2427	.168	.2427	.1494	.2427	.2614	.0934
21	.168	.2801	.2427	.2614	.2614	.2427	.0747
22	.2427	.168	.2614	.2427	.2427	.2241	.0934
23	.2427	.2427	.2427	.2614	.2427	.2614	.0747
24	.2427	.2614	.2054	.2614	.2427	.1494	.1494
Max	.2614	.2801	.2614	.2614	.2987	.2801	.2241
Min	.112	.112	.0934	.1494	.168	.1494	.0747
Avg	.2038	.2038	.2007	.2108	.2342	.2279	.1191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 205 / 11KV ARMY NIWAS

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5041	.4481	.4481	.4668	.4668	.4108	.4481
2	.4481	.3921	.4108	.4294	.4294	.3734	.3921
3	.3921	.3547	.3734	.4108	.4108	.3361	.3361
4	.3547	.3174	.3361	.3734	.3734	.3361	.2987
5	.3174	.2801	.3174	.3361	.2987	.3174	.2614
6	.2614	.2614	.2801	.3174	.2614	.2987	.2427
7	.2801	.2614	.2987	.2614	.2801	.2987	.2427
8	.2614	.2801	.2801	.2427	.2801	.2801	.2427
9	.2801	.2801	.2054	.1867	.2241	.2427	.2427
10	.2054	.2054	.2241	.2241	.2427	.2054	.2054
11	.2054	.2241	.2241	.2614	.1867	.2241	.1867
12	.2054	.3174	.2987	.2241	.2614	.2614	.2054
13	.2427	.2241	.2614	.2241	.2614	.2614	.2427
14	.2801	.2427	.2614	.2614	.2241	.2427	.2054
15	.3174	.2801	.2801	.2241	.2427	.2801	.2241
16	.2801		.2614	.2427	.2614	.2054	.2054
17	.3361	.2241	.2427	.2614	.2241	.2054	.2054
18	.2054	.2241	.2054	.2241	.1867	.1867	.168
19	.3174	.2427	.2987	.2987	.2054	.2801	.2241
20	.2801	.2801	.2614	.2801	.2614	.2427	.2614
21	.3174	.3547	.2987	.2987	.3547	.3361	.2241
22	.3921	.3734	.3361	.3547	.3547	.3734	.2987
23	.4668	.4294	.4108	.4668	.5041	.4668	.2987
24	.5228	.4854	.4854	.5041	.5041	.4668	.4854
Max	.5228	.4854	.4854	.5041	.5041	.4668	.4854
Min	.2054	.2054	.2054	.1867	.1867	.1867	.168
Avg	.3198	.3036	.3042	.3073	.3042	.2972	.2645

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 206 / 11 KV LENYADRI

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9896	.9335	.9335	.8962	.9709	1.0082	.9522
2	.8775	.8775	.8589	.8589	.8962	.9335	.8029
3	.7655	.8402	.7468	.7842	.8589	.8215	.7095
4	.6722	.7468	.6722	.6722	.7842	.7468	.6535
5	.6348	.6722	.5601	.5601	.6722	.6722	.6161
6	.5975	.5975	.5041	.5041	.5601	.5041	.5601
7	.4854	.5415	.5041	.5041	.5601	.5601	.5041
8	.4668	.4481	.4668	.4481	.5041	.4481	.5041
9	.5415	.4854	.4854	.4481	.4481	.5228	.4668
10	.4854	.4854	.4854	.4108	.5041	.5041	.4668
11	.5788	.5041	.5601	.4854	.4481	.5041	.4668
12	.4668	.5415	.5415	.5276	.4854	.5415	.5228
13	.5601	.5415	.4854	.5041	.5415	.5228	.5601
14	.5975	.5788	.4854	.5228	.5788	.5228	.5415
15	.7282	.6722	.6161	.6348	.5975	.5975	.5601
16	.6535		.6161	.5975	.5788	.5975	.5601
17	.5601	.5228	.5415	.5788	.5601	.2801	.5041
18	.4854	.5041	.5228	.5415	.4668	.4294	.4668
19	.5415	.5788	.5788	.5041	.5041	.5041	.5228
20	.6908	.6535	.5788	.6348	.6908	.5975	.5601
21	.9149	.7282	.6535	.6535	.7095	.7095	.5975
22	.9149	.7655	.7095	.7842	.8029	.7655	.6161
23	.9522	1.0082	.8962	.9335	1.0456	1.0082	.7095
24	1.0829	.9709	1.0642	.9522	1.0642	1.0829	1.0456
Max	1.0829	1.0082	1.0642	.9522	1.0642	1.0829	1.0456
Min	.4668	.4481	.4668	.4108	.4481	.2801	.4668
Avg	.6768	.6608	.6278	.6226	.6597	.6410	.6029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 207 / 11KV BHIMA SHANKAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4377	1.307	1.3443	1.3443	1.4003	1.4937	1.3817
2	1.307	1.2323	1.2696	1.2696	1.3443	1.3443	1.2883
3	1.2323	1.1389	1.1576	1.1949	1.2696	1.1949	1.1576
4	1.1389	1.0456	1.0456	1.1203	1.1949	1.0829	1.0269
5	1.0456	.9335	.8962	.9335	.9709	.9335	.9709
6	.8589	.8589	.7282	.8402	.8215	.7655	.8775
7	.7655	.7468	.7282	.6722	.7095	.7468	.7095
8	.7282	.6908	.6908	.6348	.7468	.7468	.7282
9	.7282	.7095	.6348	.6348	.7468	.7468	.6908
10		.6535	.7095	.7468	.5788	.6535	.6535
11	.6535	.6722	.7095	.6908	.6722	.6722	.6722
12	.7095	.6535	.7655	.8215	.7095	.7095	.6535
13	.7095	.7282	.6908	.6908	.6908	.6908	.6348
14	.7842	.7842	.7655	.7655	.6908	.7282	.6908
15	.8775	.8402	.8215	.8589	.6535	.7842	.6722
16	.7842		.7842	.8402	.7095	.8029	.6348
17	.6908	.6348	.7095	.8215	.6722	.7282	.5975
18	.7282	.7095	.6908	.7468	.6722	.6908	.6535
19	.7282	.7842	.7282	.7282	.6535	.6908	.6535
20	.9896	.8962	.8402	.8962	.9149	.9149	.8029
21	1.0642	.9709	.9522	1.0082	.9709	1.0456	.9335
22	1.2883	1.1763	1.1203	1.2136	1.2883	1.251	1.0082
23	1.5123	1.4377	1.3443		1.643	1.5684	1.0829
24	1.643	1.363	1.4377	1.3817	1.5123	1.587	1.4937
Max	1.643	1.4377	1.4377	1.3817	1.643	1.587	1.4937
Min	.6535	.6348	.6348	.6348	.5788	.6535	.5975
Avg	.9741	.9116	.8985	.9068	.9265	.9406	.8612

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 209 / 11 KV STN TRF

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203	1.0456	1.0456	.9335	1.0456	1.0829	1.0456
2	1.0456	.9709	.9335	.8589	.9335	.9709	.9335
3	.9335	.8589	.8589	.7468	.8589	.8589	.8775
4	.8589	.8029	.7468	.7095	.7468	.7468	.8029
5	.8029	.7468	.7095	.6535	.7095	.7282	.7468
6	.7842	.7095	.6535	.6348	.6908	.6908	.6535
7	.6535	.6348	.6722	.6348	.6535	.7095	.7095
8	.6908	.6722	.6535	.6908	.6722	.7095	.6722
9	.6535	.6161	.6722	.7468	.6535	.7095	.6535
10	.6908	.6722	.6348	.6908	.6535	.6722	.6161
11	.6535	.6722	.6535	.7095	.6535	.6908	.5788
12	.6722	.6535	.6908	.7282	.6722	.6908	.5788
13	.6722	.6535	.6722	.7655	.6722	.6908	.5975
14	.6908	.6722	.6535	.7282	.6722	.6161	.5601
15	.7095	.7655	.7842	.6908	.6722	.7468	.6535
16	.6908		.6908	.6908	.7282	.6722	.5788
17	.6161	.5788	.5975	.6908	.6908	.6535	.6535
18	.6535	.7282	.7095	.7095	.6722	.6348	.5975
19	.7468	.7095	.7468	.7468	.7095	.7095	.6535
20	.8775	.9149	.8029	.8215	.7468	.8402	.7468
21	.9335	.8775	.8589	.8215	.8962	.8962	.8775
22	.9335	.9522	.8775	.9149	.9149	.8962	.7655
23	1.0642	1.1203	1.0456	1.4377	1.1203	1.1203	.7842
24	1.2136	1.0642	1.1203	1.0456	1.1203	1.1389	1.1203
Max	1.2136	1.1203	1.1203	1.4377	1.1203	1.1389	1.1203
Min	.6161	.5788	.5975	.6348	.6535	.6161	.5601
Avg	.8067	.7866	.7702	.7834	.7733	.7865	.7274

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 202 / 11KV APPEJAY

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1273	1.2197	1.1389	1.0829	1.1016	1.1576	1.1949
2		1.0534	1.0642	1.0269	.9709	1.094	1.0829
3	.9335	.961	.9709	.8962	.8775	1.0185	.9522
4	.8589	.8596	.8215	.8488	.8215	.9335	.8215
5	.8402	.8048	.7468	.7922	.7468	.8215	.7468
6	.8215	.8501	.7762	.7167	.7842	.8589	.7655
7		.7947	.7947	.7655	.8215	.8029	.7842
8	.8402	.8402		.7842		.811	
9		.8402		.8215		.8775	
10	.9335	.9055	.9149	.7922		.9149	.8215
11	.9709	.8871	.8962	.8299		.9709	.9522
12	.9896	.924	.961	.8589		.9522	.8962
13	1.0829	.9979	1.0349	.8962	1.0269	.9335	1.0719
14	1.1016	.9795	.9795	.9335	.9896	.9522	.9896
15	1.0829	.9979	.9795	.9709	.9997	.9709	.9709
16	1.0456		.9795	.9709	.9709	.9896	.8775
17	.9709	.8596	.9149	.9335	.8775	1.0082	.8029
18	.9979		.924	.9149	.8589	.9979	.8215
19	1.1706		1.0974	1.1458	1.0425	1.0164	.9979
20	1.251	1.0608	1.0608	1.0903	1.0903	1.1827	1.0349
21	1.2254			1.2323	1.1827	1.1763	1.0242
22	1.2071		1.0903	1.1949			1.0719
23	1.2136	.961	1.1203	1.1389	1.2323		.9709
24	1.2012	1.2696	1.2136	1.1389	1.1949	1.2323	1.2883
Max	1.251	1.2696	1.2136	1.2323	1.2323	1.2323	1.2883
Min	.8215	.7947	.7468	.7167	.7468	.8029	.7468
Avg	1.0413	.9509	.9752	.9490	.9772	.9852	.9518

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 203 / 11KV CIDCO OFFICE

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9774	.9774	.9877	.9511	.9877	.9795	.9877
2	.9328	.8688	.8962	.8779	.8962	.924	.9328
3	.8048	.7522	.7682	.7682	.8048	.8871	.7682
4	.7316	.6447	.695	.695	.7133	.7316	.695
5	.6584	.5731	.567	.6516	.5853	.695	.5853
6	.6401	.6154	.5792	.5792	.5487	.7133	.6584
7		.5792	.5792	.5611	.5611	.6722	.6219
8	.6036	.6036		.5194		.7282	
9		.6401		.543		.7762	
10	.6767	.6219	.6036	.5853		1.0269	.9328
11	.695	.6767	.695	.5973		1.0082	1.0269
12	.7499	.695	.6767	.5973		1.0456	1.1016
13	.7316	.7133	.6767	.6154	.7316	.9979	.9896
14	.7392	.7133	.6401	.6219	.7023	1.0164	.9709
15	.7577	.7133	.7133	.7133	.7392	1.0425	1.1016
16	.7023		.695	.6767	.6838	1.0608	1.0269
17	.695	.6697	.6516	.6767	.6767	.9511	.9335
18	.6626		.6626	.6584	.6335	.905	.7023
19	.7619		.7442	.7421	.7087	.7964	.7602
20	.8417	.823	.788	.7964	.8238	.905	.8779
21	.8682		.8059	.8413	.8238	.905	.8048
22	.9231		.8326	.8596			.8413
23	1.0059	1.0608	1.0242	1.0608	1.0242		
24	1.0317	1.0425	1.0608	1.0242	1.0608	1.0242	1.0974
Max	1.0317	1.0608	1.0608	1.0608	1.0608	1.0608	1.1016
Min	.6036	.5731	.567	.5194	.5487	.6722	.5853
Avg	.7814	.736	.7429	.7172	.7614	.8996	.877

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 204 / 11KV STEP GARDEN

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7207	.6838	.7468	.7023	.6535	.7655	.6283
2	.6283	.6468	.6348	.6468	.5788	.6908	.5729
3	.5544	.6219	.5788	.5914	.5041	.5975	.5175
4	.499	.6219	.5601	.5487	.4435	.4805	.462
5	.4435	.5544	.499	.5121	.4066	.499	.3881
6	.499	.5121	.462	.439	.462	.5175	.4066
7		.499	.4938	.4572	.5121	.462	.4066
8	.4805	.4805		.439		.4805	
9		.4435		.4572		.4668	
10	.462	.462	.462	.4435		.4854	.4066
11	.499	.4805	.4805	.462		.4481	.4435
12	.5175	.499	.499	.462		.4668	.4251
13	.499	.5175	.499	.4805	.499	.4668	
14	.5041	.5175	.4805	.4805	.4854	.4481	.499
15	.5228	.499	.4805	.5359	.5041	.4294	.4668
16	.4854		.4805	.499	.4481	.4481	.4435
17	.462	.4435	.4207	.4805	.4668	.4435	.4251
18	.4572		.4344	.462	.3982	.4251	.3982
19	.5304		.5068	.4938	.4755	.439	.4163
20	.6099	.5853	.5304	.5853	.567	.5304	.5068
21	.5914		.5487	.5853	.5853	.5544	.0494
22	.6838		.6036	.6036	.6468		.567
23	.7762	.7762	.7392	.7392	.7947		.6283
24	.8316	.7468	.7842	.7392	.7468	.8029	.7207
Max	.8316	.7762	.7842	.7392	.7947	.8029	.7207
Min	.4435	.4435	.4207	.439	.3982	.4251	.0494
Avg	.5572	.5574	.5421	.5353	.5357	.5158	.4656

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 205 / 11KV JUINAGAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0851	2.0119	1.9774	1.9959	2.1437	2.1992	2.1216
2	1.9204	1.8473	1.848	1.848	1.9035	1.9605	1.9022
3	1.7924	1.6651	1.7002	1.7375	1.8296	1.7737	1.7193
4	1.5364	1.5927	1.5524	1.6095	1.6817	1.5708	1.4632
5	1.4266	1.4449	1.4632	1.5546	1.5364	1.5154	1.4266
6	1.4083	1.4815	1.4998	1.4118	1.5546	1.5524	1.5364
7		1.5565	1.5203	1.4661	1.5912	1.5546	1.6095
8	1.6461	1.6278		1.5203		1.701	
9		1.4449		1.4632		1.4998	
10	1.3169	1.2936	1.2936	1.39		1.3535	1.3169
11	1.2752	1.2012	1.2567	1.3535		1.2254	1.2012
12	1.262	1.2437	1.2567	1.3717		1.1706	1.1706
13	1.262	1.2986	1.2254	1.3676	1.1888	1.1888	1.2323
14	1.3121	1.3535	1.2382	1.386	1.2382	1.1706	1.1946
15	1.3676	1.2986	1.39	1.5154	1.3256	1.2071	1.2936
16	1.3352		1.2986	1.5154	1.3306	1.2254	1.2071
17	1.2254	1.2071	1.1584	1.4784	1.2012	1.2803	1.1157
18	1.1999		1.267	1.4415	1.1888	1.4118	1.1041
19	1.4327		1.4506	1.5729	1.4842	1.4661	1.3073
20	1.8642	1.7737	1.7737	1.9022	1.828	1.773	1.7556
21	2.0271			1.9547	1.9185	1.8461	1.7556
22	2.1033		1.7918	1.9909	2.0485		1.829
23	2.2546	2.1538	2.1807	2.2131	2.2916		1.9035
24	2.2497	2.2361	2.1437	2.1622	2.2361	2.2546	2.2314
Max	2.2546	2.2361	2.1807	2.2131	2.2916	2.2546	2.2314
Min	1.1999	1.2012	1.1584	1.3535	1.1888	1.1706	1.1041
Avg	1.6047	1.5649	1.5374	1.6343	1.6590	1.5409	1.5181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 206 / 11KV TRUPTI FEEDER

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2752	1.2254	1.1827	1.2012	1.1827	1.2567	1.1827
2	1.1827	1.134	1.1273	1.1088	1.1273	1.1576	1.0719
3	1.0903	1.0679	1.0164	1.0456	.9795	1.0456	.9425
4	.924	.905	.9425	.8962	.8871	.924	.8501
5	.8501	.8779	.8131	.8402	.7762	.8316	.7392
6	.8871	.8686	.8501	.7392	.8501	.8686	.8131
7		.9055	.8686	.8131	.9055	.8871	.8686
8	.924	.9055		.7947		.8871	
9		.8131		.8131		.8131	
10	.8871	.7947	.8131	.7865		.8316	.8316
11	.8871	.8501	.8501	.7682		.8501	.8501
12	.9055	.8686	.8779	.8048		.8871	.8596
13	.8871	.8871	.9145	.8501	.8871	.8501	.8596
14	.9335	.924	.8686	.8871	.8131	.8316	.8501
15	.9522	.8871	.8871	.924	.924	.8686	.8501
16	.9425		.8048	.9055	.8501	.8871	.8048
17	.9145	.7947	.8048	.924	.8501	.924	.823
18	.9231		.8326	.924	.8048	.9877	.8869
19	1.0317		1.0608	.9877	.9877	1.0059	.8954
20	1.2254	1.1706	1.1584	1.1888	1.1523	1.2071	1.1222
21	1.2254		1.1222	1.2071	1.2071	1.2197	1.0498
22	1.2012		1.1088	1.2071	1.1458		1.0791
23	1.3121	1.3676	1.2936	1.2936	1.3121		1.1273
24	1.3491	1.2936	1.2936	1.2752	1.3306	1.3121	1.3306
Max	1.3491	1.3676	1.2936	1.2936	1.3306	1.3121	1.3306
Min	.8501	.7947	.8048	.7392	.7762	.8131	.7392
Avg	1.0323	.9758	.9769	.9661	.9986	.9697	.9404

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 207 / 11KV AUGUSTEEN FEEDER

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203	1.0719	1.0082	1.0456	1.0082	1.0456	1.0082
2	1.0082	1.0164	.9522	.9709	.9522	.9709	.9149
3	.9335	1.0164	.8215	.8962	.8962	.8865	.8029
4	.8215	.9795	.7468	.7922	.7655	.811	.7095
5	.7842	.8962	.6535	.7545	.6535	.7842	.5788
6	.9335	.9149	.5975	.6602	.6348	.8775	.5601
7		.7095	.6535	.6161	.6535	.6535	.5975
8	.8775	.8589		.7468		.7842	
9		.8131		.6161		.7282	
10	.8775	.8316	.8215	.6908		.7468	.7468
11	.9335	.8775	.9149	.7842		.8589	.8215
12	.9335	.8962	.8962	.7468		.8402	.8402
13	.9425	.9335	.8962	.7842	.8589	.7762	.8589
14	.961	.9149	.8589	.8029	.8402	.7392	.8402
15	.9795	.9149	.9335	.8402	.8775	.7762	.8402
16	.9335		.8402	.8775	.8589	.7947	.7947
17	.8589	.7842	.8215	.8402	.8962	.8871	.7392
18	.8589		.8402	.8029	.8215	.9425	.7762
19	1.0829		1.0456	1.0719	1.0456	.9979	.961
20	1.1827	.9896	.9522	.924	.9896	.8501	1.1763
21	1.0164		.9709	.961	1.0082	.8962	.8962
22	1.0642		.9335	.961	1.0269		.8596
23	1.0642	1.1016	1.0642	1.0456	1.0456		.8316
24	1.1949	1.1389	1.1203	1.1016	1.1203	1.1016	1.1016
Max	1.1949	1.1389	1.1203	1.1016	1.1203	1.1016	1.1763
Min	.7842	.7095	.5975	.6161	.6348	.6535	.5601
Avg	.9710	.9295	.8792	.8472	.8923	.8522	.8298

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 208 / 11KV RAILWAY COMPLEX

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	.4001	.362	.3772	.4001	.7842	.8573
2	.3429	.362	.3429	.3395	.362	.7095	.743
3	.3048	.3206	.3048	.2829	.3239	.6602	.6478
4	.2667	.2829	.2858	.3048	.2858	.6036	.5906
5	.2286	.3429	.2667	.2477	.2667	.5658	.5716
6	.2667	.3048	.2452	.2477	.3048	.6348	.6097
7		.3239	.2829	.2667	.3239	.5788	.6224
8	.3395	.3429		.3239		.6036	.6413
9		.381		.3772		.7167	.679
10	.5847	.5658	.5716	.4001		.7545	.7167
11	.679	.6979	.6478	.4191		.9054	.9054
12	.7356	.7167	.6602	.4382		.9431	.9054
13	.6979	.7356	.6413	.4572	.6602	.9808	.9054
14	.7167	.7545	.6224	.4763	.6602	1.0082	.8865
15	.7356	.7167	.6602	.4382	.7356	.9335	.9619
16	.6979		.6036	.3961	.6602	.9896	.9242
17	.6979	.6224	.5658	.3772	.679	.9335	.8676
18	.6224		.5415	.3584	.6224	.9522	.8215
19	.6036		.5601	.4338	.6161	.9425	.8501
20	.6413	.5601	.5228	.4338	.5788	.9979	.924
21	.5281		.4904	.4108	.547	.8775	.7392
22	.415		.3772	.3921	.415	.9054	.7023
23	.3961	.4338	.4001	.415	.3961	.9619	.6908
24	.4191	.415	.381	.3961	.4191	.8402	.9145
Max	.7356	.7545	.6602	.4763	.7356	1.0082	.9619
Min	.2286	.2829	.2452	.2477	.2667	.5658	.5716
Avg	.5146	.4884	.4698	.3754	.4872	.8243	.7783

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 201 / 11KV NRI COMPLEX

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0727	2.8959	2.9264	2.8532	2.8959	3.1093	3.0727
2	2.9264	2.733	2.7801	2.6155	2.6787	2.963	2.8898
3	2.7069	2.6155	2.5972	2.4143	2.2986	2.652	2.7801
4	2.3777	2.3777	2.3777	2.2131	1.9404	2.396	2.4326
5	1.9022	2.1033	2.1582	2.0119	1.8296	2.1582	2.1582
6	1.7558	1.7741	1.8473	1.8839	1.7556	1.9387	1.9204
7	1.5729	1.5912	1.5729	1.7193	1.5912	1.7375	1.7375
8	1.6078	1.6461	1.5708	1.5181		1.6095	1.4784
9	1.7177	1.5181	1.6817	1.5912	1.6461	1.5912	1.6263
10	1.6817	1.6095	1.7372		1.6095		1.6263
11	1.4969	1.5729	1.6827	1.5729	1.5729	1.6278	1.4415
12	1.7193	1.6644	1.6644		1.5364	1.6278	
13	1.701	1.701	1.829	1.6827	1.4998	1.7558	1.4045
14	.4435	1.701	1.7924	1.9022	1.6461	1.9022	1.5339
15		2.0302	1.7193	2.1582	1.6461	1.9936	1.848
16	2.0302	1.7741	1.6461	2.1765	1.701	1.829	1.5893
17	1.7924	1.5154	1.6095	2.0302	1.7375	1.7375	1.4415
18		1.4784	1.4266	1.7375	1.6461	1.5708	1.1706
19	1.5181	1.7002	1.701	1.6278	1.4632	1.6632	
20	1.957	2.0328	1.957	1.9936	2.0119	1.9959	
21	2.2314	2.3101	2.1033	2.2131	2.3411	2.4579	
22		2.6242	2.2862	2.6787	2.963	2.7905	
23	2.8597	2.9384	2.652	2.8054	3.3836	3.0493	
24	3.2341	2.9321	3.1181	3.0178	3.0226	3.219	3.1786
Max	3.2341	2.9384	3.1181	3.0178	3.3836	3.219	3.1786
Min	.4435	1.4784	1.4266	1.5181	1.4632	1.5708	1.1706
Avg	2.0145	2.0350	2.0182	2.1099	2.0181	2.1468	1.9628

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 203 / 11KV BPCL

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7069	2.552	2.6337	2.5789	2.7149	2.7069	2.7801
2	2.5606	2.4072	2.4508	2.3777	2.4615	2.4874	2.5972
3	2.396	2.2624	2.2497	2.2314	2.3167	2.3411	2.4508
4	2.2314	2.1216	2.0485	2.0119	1.9936	2.1948	2.3411
5	2.0119	1.8473	1.8656	1.8656	1.7924	1.9753	2.0851
6	1.8473	1.7558	1.7558	1.7375	1.7375	1.8656	1.8656
7	1.7558	1.7193	1.7741	1.7375	1.7193	1.7924	1.7558
8	1.7741	1.7558	1.8665	1.7375		1.7375	1.885
9	1.7737	1.6827	1.6448	1.5181	1.6644	1.7924	1.7372
10	1.7002	1.5181	1.8665		1.5364		1.5893
11	1.6263	1.6644	1.7924	1.5546	1.6461	1.6278	1.7556
12	1.6827	1.6827	1.7558		1.701	1.6278	
13	1.6827	1.8107	1.9387	1.5729	1.701	1.6644	1.7926
14	1.8107	1.8107	1.829	1.8107	1.829	1.829	1.848
15		1.9753	1.8656	1.829	1.829	2.1033	1.7002
16	2.0302	1.829	1.9204	2.0302	1.8656	1.9774	1.7741
17	1.7375	1.8296	1.9753	1.8473	1.8656	1.9774	1.922
18		1.9589	1.8473	1.7375	1.9204	1.8111	1.701
19	1.9022	1.922	1.8656	1.7375	1.9753	1.8665	
20	2.1765	2.1437	2.1216	2.0851	2.1216	2.0144	
21	2.3228	2.0513	2.1033	2.0302	2.1765	2.2361	
22		2.2731	2.2497	2.2443	2.4326	2.4025	
23	2.6244	2.6057	2.4691	2.4977	2.8349	2.6242	
24	2.809	2.6787	2.7905	2.7435	2.7873	2.8532	2.9014
Max	2.809	2.6787	2.7905	2.7435	2.8349	2.8532	2.9014
Min	1.6263	1.5181	1.6448	1.5181	1.5364	1.6278	1.5893
Avg	2.0554	1.9941	2.0283	1.9780	2.0271	2.0656	2.0268

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 204 / 11KV SWP

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.2241	.3361	.4668	.3921	.2801	.3361
2	.2614	.2054	.2987	.4854	.4108	.3361	.2987
3	.2987	.168	.2614	.4294	.4481	.3734	.2987
4	.3361	.2241	.2614	.3734	.4108	.4108	.2987
5	.3361	.2987	.2614	.2987	.3361	.3361	.3734
6	.3921	.1867	.2614	.2427	.3734	.2427	.3921
7	.3174	.4481	.2427	.2987	.1867	.4108	.2801
8	.2402	.4294	.3142	.3734		.5601	.3696
9	.2587	.5415	.4805	.3921	.2987	.5975	.3881
10	.4251	.3361	.2614		.3734		.5041
11	.2218	.4854	.3734	.3734	.4668	.5975	.499
12	.2427	.6722	.5041		.6161	.5975	
13	.2218	.5601	.4854	.5228	.4481	.6348	.4668
14	.2402	.5601	.3361	.4294	.5601	.5788	.3734
15		.5975	.3734	.6161	.4668	.5788	.5601
16	.2218	.4481	.3734	.5228	.3734	.4805	.4668
17	.2033	.3881	.3174	.7468	.2987	.3696	.4668
18		.3881	.3734	.4108	.2801	.4435	.4481
19	.1867	.3696	.3734	.3734	.2614	.4435	
20	.4854	.3511	.3174	.4668	.5601	.5914	
21	.6535	.2772	.2801	.4108	.2427	.5914	
22		.2957	.3174	.5041	.3734	.5041	
23	.4668	.4251	.3734	.5975	.5601	.4066	
24	.3142	.2241	.3881	.4108	.4481	.2987	.3547
Max	.6535	.6722	.5041	.7468	.6161	.6348	.5601
Min	.1867	.168	.2427	.2427	.1867	.2427	.2801
Avg	.3154	.3794	.3402	.4430	.3994	.4637	.3986

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 205 / 11KV DELHI PUBLIC SCHOOL Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0572	.0381	.0381	.0572	.0381	.0381
2	.0381	.0572	.0381	.0381	.0572	.0381	.0381
3	.0381	.0381	.0381	.0381	.0381	.0381	.0381
4	.0381	.0381	.0381	.0381	.0381	.0381	.0381
5	.0381	.0572	.0381	.0572	.0381	.0572	.0381
6	.0381	.0381	.0381	.0572	.0381	.0572	.0381
7	.0572	.0572	.0572	.0572	.0572	.0572	.0381
8	.0381	.0572	.0572	.0762	.0572	.0572	.0381
9	.0381	.0572	.0572	.0381	.0572	.0572	.0572
10	.0572	.0572	.0572		.0762		.0762
11	.0572	.0572	.0762	.0572	.0953	.0953	.0762
12	.0572	.0762	.0762		.0953	.0953	
13	.0572	.0572	.0572	.0572	.0953	.0953	.0762
14	.0572	.0572	.0762	.0572	.0762	.0762	.0762
15		.0572	.0762	.0572	.0762	.0762	.0572
16	.0572	.0572	.0762	.0572	.0762	.0572	.0572
17	.0381	.0572	.0572	.0572	.0572	.0572	.0572
18		.0381	.0572	.0572	.0572	.0381	.0572
19	.0572	.0572	.0572	.0572	.0381	.0572	
20	.0572	.0572	.0572	.0572	.0572	.0381	
21	.0572	.0572	.0572	.0572	.0572	.0572	
22		.0572	.0381	.0572	.0572	.0381	
23	.0572	.0572	.0381	.0572	.0572	.0572	
24	.0572	.0572	.0381	.0381	.0572	.0381	.0572
Max	.0572	.0762	.0762	.0762	.0953	.0953	.0762
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.0490	.0548	.0540	.0529	.0612	.0572	.0529

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 206 / 11KV NEELKANTH TOWER

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7633	2.7149	2.7351	2.6703	2.5339	2.5789	2.6612
2	2.5873	2.552	2.6242	2.4691	2.371	2.3777	2.5503
3	2.4394	2.3167	2.4025	2.268	2.2443	2.268	2.4646
4	2.3101	2.1765	2.2546	2.1948	2.1216	2.1582	2.3285
5	2.1807	2.0851	2.0698	2.0851	1.9753	2.0119	2.0698
6	2.0328	1.9387	1.9589	1.957	1.829	1.829	1.922
7	1.9035	1.829	1.9035	1.829	1.7193	1.7375	1.7741
8	1.829	1.7924	1.7924	1.6827		1.6461	1.6278
9	1.7741	1.6461	1.7375	1.5912	1.5546	1.6095	1.4266
10	1.7741	1.6827	1.7193		1.4815		1.5181
11	1.7741	1.8111	1.7924	1.7193	1.6095	1.7375	1.6461
12	1.7924	1.7556	1.8656		1.6827	1.7375	
13	1.9022	1.8296	1.9022	1.7558	1.7375	1.8296	1.6644
14	2.0485	1.848	1.9387		1.8839	1.9774	1.6461
15		2.1253	1.9753	1.957	1.8839	1.9774	1.7193
16	2.0851	1.9959	2.0119	2.0119	1.9204	1.8665	1.6644
17	1.9204	1.8656	2.0302	1.957	1.9204	1.8665	1.6644
18		2.0119	1.9753	1.9753	1.829	1.829	1.6461
19	2.0668	1.9753	2.0485	1.9022	1.7741	1.7924	
20	2.1582	2.0668	2.0668	2.1033	2.1216	1.9936	
21	2.2862	2.1216	2.2131	2.1033	2.1399	2.1399	
22		2.3594	2.2862	2.2314	2.3777	2.3777	
23	2.8597	2.6886	2.5606	2.4253	2.6703	2.5972	
24	2.7984	2.7511	2.8166	2.8349	2.5882	2.7435	2.7435
Max	2.8597	2.7511	2.8166	2.8349	2.6703	2.7435	2.7435
Min	1.7741	1.6461	1.7193	1.5912	1.4815	1.6095	1.4266
Avg	2.1565	2.0808	2.1117	2.0821	1.9987	2.0297	1.9299

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 207 / 11KV KOKAN RAILWAY

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9959	1.9959	1.885	1.848	2.0144	1.922	7.5804
2	1.848	1.8665	1.7002	1.7372	1.7187	1.7556	1.848
3	1.7002	1.6817	1.5893	1.6263	1.5893	1.6263	1.7002
4	1.5524	1.5893	1.4415	1.4784	1.4415	1.5154	1.5893
5	1.423	1.386	1.3306	1.3491	1.386	1.4045	1.4784
6	1.2382	1.2197	1.2382	1.2012	1.2567	1.3121	1.3676
7	1.1827	1.1088	1.1827	1.1643	1.2012	1.2567	1.2567
8	1.1157	1.1643	1.1157	1.1088		1.2012	1.1706
9	1.134	1.1088	1.0974	1.0719	1.1273	1.1273	1.134
10	1.0425	1.0534	1.1157		1.0349		1.134
11	1.1088	1.0349	1.1088	1.1088	1.0719	1.1523	1.0425
12	1.0719	1.0534	1.1088		1.1088	1.1523	
13	1.1088	1.0719	1.1458	1.0903	1.1088	1.0719	1.0608
14	1.2012	1.0719	1.1088	1.1157	1.1088	1.2012	1.0349
15		1.1827	1.1088	1.2197	1.1088	1.2136	1.1088
16	1.1643	1.1458	1.1458	1.2936	1.1643	1.1273	.9795
17	1.1088	1.0791	1.1458	1.2197	1.2012	1.1273	1.0719
18		1.2071	1.2012	1.1827	1.2197	1.134	.9979
19	1.3306	1.262	1.4045	1.2382	1.2567	1.2437	
20	1.46	1.3717	1.4045	1.3676	1.4045	1.4266	
21	1.4969	1.4083	1.423	1.4969	1.5339	1.5729	
22		1.6095	1.4784	1.7002	1.7187	1.701	
23	1.9404	1.8839	1.7372	1.848	2.0144	1.9753	
24	2.0485	2.0698	1.9753	1.9589	2.0698	2.0698	2.0485
Max	2.0485	2.0698	1.9753	1.9589	2.0698	2.0698	7.5804
Min	1.0425	1.0349	1.0974	1.0719	1.0349	1.0719	.9795
Avg	1.3939	1.3594	1.3414	1.3830	1.3852	1.4039	1.6447

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 208 / 11kV KENDRIYA VIHAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2405	2.0119	2.0351	2.0302	2.2131	2.1216	2.0911
2	2.0351	1.829	1.8671	1.9204	2.1033	2.0119	1.9418
3	1.8298	1.6644	1.7551	1.829	1.9753	1.8656	1.7551
4	1.6804	1.6095	1.643	1.701	1.7924	1.7375	1.6804
5	1.5684	1.4632	1.531	1.5729	1.6095	1.6461	1.6057
6	1.475	1.4632	1.4563	1.4632	1.4998	1.5546	1.5123
7	1.419	1.3535	1.3817	1.4632	1.4266	1.5546	1.4377
8	1.4045	1.4415	1.4045	1.4083		1.5181	1.6078
9	1.4045	1.5154	1.3491	1.3717	1.4083	1.4266	1.4937
10	1.7002	1.6632	1.6263		1.701		1.6448
11	1.7372	1.6617	1.6827	1.5729	1.701	1.8111	1.6078
12	1.7741	1.7177	1.7741		1.701	1.8298	
13	1.7926	1.6991	1.7193	1.6827	1.6461	1.7741	1.5893
14	1.7741	1.7177	1.7924	1.6827	1.6461	7.4476	1.6263
15		1.8858	1.7924	1.7741	1.7375	1.9035	1.7556
16	1.829	1.8111	1.829	1.7924	1.829	1.922	1.5912
17	1.7193	1.7372	1.829	1.7558	1.957	1.922	1.6644
18		1.8665	1.829	1.9022	1.829	1.848	1.6461
19	1.9204	1.8296	1.7924	1.6827	1.7558	1.885	
20	2.0485	1.9774	1.8839	1.9204	2.0485	2.0144	
21	2.0668	2.0328	2.0485	2.0485	2.1033	2.1068	
22		2.0513	2.0119	2.0485	2.2314	2.1992	
23	2.2131	2.1622	2.0851	2.1033	2.2862	2.2592	
24	2.3101	2.0668	2.1622	2.1582	2.268	2.268	2.2405
Max	2.3101	2.1622	2.1622	2.1582	2.2862	7.4476	2.2405
Min	1.4045	1.3535	1.3491	1.3717	1.4083	1.4266	1.4377
Avg	1.8068	1.7597	1.7617	1.7675	1.8465	2.1142	1.6940

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 209 / 11KV SEAWOODS PH-I

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5775	1.5089	1.5775	1.5089	1.5257	1.5927	1.5432
2	1.5432	1.4083	1.4403	1.4419	1.3413	1.5089	1.4403
3	1.4403	1.3077	1.3717	1.358	1.2574	1.3916	1.3375
4	1.3375	1.2039	1.2689	1.2574	1.2039	1.2742	1.2003
5	1.2346	1.1361	1.166	1.1401	1.153	1.1736	1.0974
6	1.166	1.0513	1.0802	1.0395	1.1022	1.0898	1.0288
7	1.0174	1.0174	1.0513	1.0059	1.0852	1.0562	.9774
8	.9326		.9835	.9556		1.0059	.9326
9	.9156	.8139	.9326	.9221	.8648	.9221	.8648
10	.9496	.8987	.9496		.8987		.8817
11	.9326	.9326	.9389	.9221	.9221	.9221	.9156
12	.9835	.9326	.9389		.9221	.9221	
13	.9496	.9156	.9556	.8886	.9221	.9221	.8648
14	1.0343	.9156	1.0395	.9556	1.0059	.9892	.9326
15		1.0343	1.0059	1.073	1.0059	.9892	.9496
16	1.0395	1.0174	1.0059	1.1233	1.0059	1.0004	.9221
17	1.0562	.9326	1.0395	1.0227	1.0059	1.0004	.9221
18			.9221	.9054	.9724	.9835	.8886
19	.9724	.9496	1.0059	.9221	.9221	.9326	
20	1.0395	.9835	1.0059	1.073	1.0898	1.0852	
21	1.1401	1.1191	1.0395	1.073	1.1233	1.1022	
22		1.2548	1.1233	1.2071	1.3413	1.2378	
23	1.4251	1.5261	1.3748	1.5089	1.643	1.3904	
24	.168	1.5424	1.6108	1.6095	1.5927	1.6766	1.6108
Max	1.5775	1.5424	1.6108	1.6095	1.643	1.6766	1.6108
Min	.168	.8139	.9221	.8886	.8648	.9221	.8648
Avg	1.0883	1.1092	1.1178	1.1324	1.1264	1.1378	1.0728

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284008 / 33/11 KV Amey Sec-6 Nerul

Feeder No / Name : 203 / 11 KV E type Wadhva

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8589		.7468		.7762	
2		.8215		.6722		.7392	
3		.8215		.6722		.7468	
4		.7842		.6348		.7095	
5		.7095		.6348		.6283	
6		.5601		.5975		.5914	
7		.5601	.6097	.5228	.5544	.5729	
8		.5415		.5175		.6099	
9				.6161		.5729	.5729
10	.6161		.6287	.6468	.5914		.5359
11	.5601		.5975		.5359		.4805
12	.6348		.5975	.6468	.5544		.5544
13	.6535		.6348		.499		.6099
14	.6908		.6535	.7577	.5601	.5914	.6099
15	.7947	.6668	.6535		.5729		.462
16	.6838		1.0082		.5359		.4435
17	1.1576		.5975		.5175		.4805
18	.4435	.6097	.5975	.7762	.5175		.5359
19	.5975		.5975		.5175	.6283	.5914
20	.6722		.6908		.7023		.5914
21	.7282		.7282	.8501	.7392		.6283
22	.8029		.7282		.7392	.7577	.6653
23	.8215		.7468		.7762		.6099
24	.8589	1.1016	.8573	.7468	.8686	.7762	
Max	1.1576	1.1016	1.0082	.8501	.8686	.7762	.6653
Min	.4435	.5415	.5975	.5175	.499	.5729	.4435
Avg	.7144	.7305	.6830	.6693	.6114	.6693	.5581

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284008 / 33/11 KV Amey Sec-6 Nerul

Feeder No / Name : 204 / 11 KV Great Estern

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0456		1.0269		1.1949	
2		1.0456		.9896		1.1949	
3		1.0082		.9896		1.1203	
4		1.0082		.9335		1.0829	
5		.9149		.9335		.7842	
6		.7468		.7468		.7468	
7		.5788	.6859	.5788	.6722	.6722	
8		.5601		.5975		.6722	
9				.7095		.8962	.7842
10	1.1016		1.0479	.7282	.9709		.9896
11	1.1576		1.0829		1.1763		1.1389
12	1.2323		1.1016	.8215	1.1949		1.0829
13	1.2323		1.1576		1.1576		1.0642
14	1.1949		1.1949	.8589	1.1203	1.1949	1.0642
15	1.2696	1.2955	1.2136		1.2323		1.1576
16	1.2323		.6908		1.1576		1.0829
17	1.1576		.8215		1.1203		1.0456
18	1.0269	.9907	.8589	.7468	1.0456		.9522
19	.9896		.9335		.8962	.9709	.9522
20	1.0269		.9709		.9522		.9335
21	1.0456		.9522	1.0082	1.0269		.9335
22	1.1203		.9522		1.0269	1.0642	.8402
23	1.1016		1.0082		1.1016		.8962
24	1.1389	1.1016	1.2193	1.0642	1.2936	1.1576	
Max	1.2696	1.2955	1.2193	1.0642	1.2936	1.1949	1.1576
Min	.9896	.5601	.6859	.5788	.6722	.6722	.7842
Avg	1.1352	.936	.9932	.8489	1.0716	.9809	.9945

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284009 / 33 KV Sec-19A Nerul

Feeder No / Name : 201 / Station Transformer

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0183		.0171			.0171	.0181
2			.0171			.0171	
3			.0171			.0171	
4			.0171	.0343		.0171	
5	.0183		.0171			.0171	.0181
6	.0183		.0171			.0171	.0181
7	.0183		.0171			.0171	
8			.0171			.0171	
9			.0171			.0171	
10		.0171			.0171	.0183	
11		.0171			.0171	.0183	.0183
12		.0171			.0171	.0183	
13		.0171			.0171	.0183	.0181
14		.0171			.0171	.0181	.0181
15		.0171			.0171		
16		.0171			.0171	.0183	.0183
17	.0343				.0171	.0181	.0181
18		.0171			.0171	.0181	.0183
19					.0171		.0183
20		.0171			.0171		.0183
21					.0171		.0183
22		.0171			.0171		.0183
23		.0171			.0171	.0183	.0183
24	.0183		.0171			.0171	.0183
Max	.0343	.0171	.0171	.0343	.0171	.0183	.0183
Min	.0183	.0171	.0171	.0343	.0171	.0171	.0181
Avg	.0210	.0171	.0171	.0343	.0171	.0176	.0182

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284009 / 33 KV Sec-19A Nerul

Feeder No / Name : 202 / RHYAN

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366	.0343	.0343	.0343	.0343	.0343	.0362
2		.0347	.0343	.0343	.0343	.0343	
3		.0343	.0343	.0343		.0343	
4		.0343	.0343	.0343	.0343	.0343	
5	.0366	.0347	.0343	.0343	.0343	.0343	.0362
6	.0366	.0347	.0343		.0343	.0343	.0362
7	.0366	.0343	.0343	.0343	.0343	.0343	
8	.0343	.0343	.0343	.0343	.0343	.0343	
9	.0343	.0343	.0343	.0343	.0343	.0343	
10	.0343	.0343	.0343	.0343	.0343	.0366	
11	.0343	.0343	.0343	.0343	.0343	.0366	.0366
12	.0343	.0343	.0343		.0343	.0366	
13	.0343	.0343	.0343	.0343	.0343	.0366	.0362
14	.0343	.0343	.0343	.0343	.0343	.0362	.0362
15	.0343	.0343	.0343	.0343	.0343		
16	.0343	.0343	.0343		.0343	.0366	.0366
17	.0343	.0343	.0343	.0343	.0343	2.2262	.0362
18	.0343	.0343	.0343	.0343	.0343	.0362	.0366
19	.0343	.0343	.0343		.0343		.0366
20	.0343		.0343		.0343		.0366
21	.0343		.0343	.0154	.0343	.0366	.0366
22	.0343	.0343	.0343		.0343	.0362	.0366
23	.0343	.0343	.0343	.0343	.0343	.0366	.0366
24	.0366	.0343	.0343	.0343	.0343	.0343	.0366
Max	.0366	.0347	.0343	.0343	.0343	2.2262	.0366
Min	.0343	.0343	.0343	.0154	.0343	.0343	.0362
Avg	.0348	.0344	.0343	.0333	.0343	.1397	.0364

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642] BU 4642

Substation No/ Name :- 284009 / 33 KV Sec-19A Nerul

Feeder No / Name : 203 / CPWD S/S

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	.0183
Max	.0183
Min	.0183
Avg	.0183

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284009 / 33 KV Sec-19A Nerul

Feeder No / Name : 204 / NCRD

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3594	2.0576	2.2462	2.1776	2.1434	2.1605	2.2443
2		2.0405	2.1605	2.0576	1.9719	2.0233	
3		1.8861	2.1605	2.0576	1.8004	1.7318	
4		1.6804	2.0919	1.8861	1.7147	1.6804	
5	2.1033	1.5775	1.869	1.7661	1.6975	1.6118	1.6651
6	2.0851	1.5432	1.5432	1.6804	1.5432	1.5604	1.6108
7	1.7924	1.4575	1.5089	1.5432	1.5261	1.5261	1.5927
8	1.6975	1.3889	1.406	1.406	1.4575	1.4746	1.5023
9	1.7318	1.5261	1.4746	1.4232	1.6118	1.5432	1.5746
10	1.869	1.6461	1.6975	1.5261	1.9547	1.9022	1.8461
11	2.2462	1.749	2.0919	1.6975	2.1091	2.396	2.2314
12	2.3148	2.0748	2.1948		2.3491	2.4691	
13	2.3663	2.2977	2.2977	1.749	2.4006	2.4874	2.3891
14	2.4006	2.2634	2.2977	1.8347	2.4177	2.4072	2.3348
15	2.4863	2.2291	2.3834	1.8176	2.452		
16	2.3491	2.2291	2.2291	1.8176	2.4006	2.396	2.2862
17	2.1948	2.0748	2.1262	1.8861	2.2977	2.2262	2.1765
18	2.1605	2.1091	1.989	1.8176	2.0748	2.2805	2.1033
19	2.1262	2.1262	1.9719		2.0062		2.0668
20	2.1605	2.1948	2.1091	2.1948	2.0576		2.0302
21	2.1262	2.2291	2.0233	1.7833	2.0919		2.0119
22	2.3148	2.2634	2.0405	2.1776	2.1091		1.9753
23	2.3663	2.332	2.3148	2.2634	2.1948	2.5057	1.957
24	2.4143	2.1091	2.3148	2.2119	2.2291	2.2634	2.5423
Max	2.4863	2.332	2.3834	2.2634	2.452	2.5057	2.5423
Min	1.6975	1.3889	1.406	1.406	1.4575	1.4746	1.5023
Avg	2.1745	1.9619	2.0226	1.8534	2.0255	2.0340	2.0074

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284009 / 33 KV Sec-19A Nerul

Feeder No / Name : 205 / Navdurga S/S

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0791	1.0288	1.0974	.9431	1.0802	1.0802	1.1584
2		.9774	1.0288	.8573	1.1145	1.0117	
3		.9602	.9259	.8402	.9945	.9431	
4		.9431	.8573	.8059	.8059	.8745	
5	.8596	.8573	.823	.6859	.8059	.8059	.8507
6	.9694	.6859	.7202	.6344	.6859	.7545	.7783
7	.9877	.6344	.6344	.6001	.6516	.6516	.6154
8	.8745	.6001	.583	.5487	.6516	.6516	.6335
9	.6859	.583	.583	.583	.6344	.6516	.6516
10	.6516	.6173	.6001	.7202	.6344	.7133	.6697
11	.6687	.6687	.6687		.703	.695	.6584
12	.6859	.703	.5316	.703	.6687		
13	.7202	.703	.6687	.6859	.703		.6878
14	.7716	.7202	.6687	.703	.7202	.7059	.6878
15	.7716	.7373	.7202	.823	.7545		
16	.8402	.7545	.6859	.8573	.7716	.823	.7133
17	.7373	.6516	.6687		.7202	.7602	.6697
18	.703	.703	.6687	.6859	.6687	.724	.6036
19	.7888	.7716	.7888	.7716	.7202	.7499	.7133
20	.8916	.8745	.8573	.9945	.823	.9145	.7499
21	.9602	.9945	.8745	.9774	.8745	.9694	.7682
22	1.046	1.046	.9431	1.0117	.9602	1.0974	.8962
23	1.0974	1.0802	1.046	1.1145	1.1317	1.262	.9511
24	1.0974	1.0974	1.1317	1.1145	1.1145	1.2174	1.2254
Max	1.0974	1.0974	1.1317	1.1145	1.1317	1.262	1.2254
Min	.6516	.583	.5316	.5487	.6344	.6516	.6036
Avg	.8518	.8080	.7823	.8028	.8080	.8598	.7728

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284009 / 33 KV Sec-19A Nerul

Feeder No / Name : 206 / 11 KV DY Patil

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9328	1.1831	1.0802	1.2003	.9431	1.046	1.2127
2		1.2174	1.046	1.1831	.9431	1.0117	
3		1.2346	.9945	1.1831	.9259	1.0288	
4		1.2517	.9259	1.1488		1.0631	
5	.8596	1.3032	.9945	1.1145	1.0631	1.0974	.8688
6	.9694	1.3203	1.1145	1.166	1.1488	1.166	1.1403
7	1.0425	1.3546	1.406	1.286	1.2346	1.3375	1.3575
8	1.0288		1.4403	1.2174	1.5261	1.4403	1.4842
9	1.1145	1.4232	1.6289	1.166	1.5089	1.3717	1.4118
10	1.5089	1.4575	1.7147	.9945	1.6461	1.39	1.267
11	1.5261	1.5089	2.0405	1.0288	1.5947	1.4815	1.3352
12	1.5432	1.5604	2.0062	1.4918	1.5604	1.5729	
13	1.5432	1.5432	1.8347	1.4575	1.6461	1.5729	1.1222
14	1.5775	1.6461	1.8347	1.3889	1.5089	1.5023	1.1584
15	1.7147	1.6975	1.8004	1.3375	1.8861		
16	1.6289	1.749	1.7147	1.286	.823	1.7375	1.6278
17	1.7147	1.6118	1.6289	1.2003	1.7661	1.5565	1.4661
18	1.3203	1.5432	1.5432	1.3032	1.5432	1.4118	1.3169
19	1.5432	1.4746	1.6118	1.3032	1.5947	1.7924	1.4083
20	1.5604	1.406	1.2346	1.2174	1.406	1.5546	1.2986
21	1.2689	1.3546	1.2003	1.0288	1.286	1.2437	1.2254
22	1.3032	1.3032	1.166	1.1488	1.3546	1.2803	1.134
23	1.2517	1.2174	1.1145	1.0117	1.1317	1.3535	1.0791
24	.9694	1.166	1.1145	1.1488	.9774	.0343	1.262
Max	1.7147	1.749	2.0405	1.4918	1.8861	1.7924	1.6278
Min	.8596	1.166	.9259	.9945	.823	.0343	.8688
Avg	1.3296	1.4142	1.4246	1.2089	1.3486	1.3064	1.2724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284009 / 33 KV Sec-19A Nerul

Feeder No / Name : 207 / 11 KV Brahmakumari

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9936	.823	2.2977	2.2291	2.4006	2.3148	2.5339
2		.8573	2.1948	1.6975	2.3205	2.1948	
3		1.1317	2.0919	1.5947	2.3148	2.0748	
4		1.2174	1.869	1.5947	1.9376	1.9547	
5	1.6644	1.4232	1.7318	1.5432	1.7661	1.8519	1.7918
6	1.5546	1.5604	1.7147	1.4746	1.7147	1.749	1.7375
7	1.5912	1.4403	1.5432	1.4575	1.5261	1.6289	
8	1.4918	1.4403	1.5089	1.4403	1.5604	1.5604	
9	1.4918	1.5089	1.406	1.4403	1.4575	1.5089	
10	1.4918	1.5432	1.5432	1.4403	1.5089	1.6827	
11	1.5432	1.5775	1.6289	1.4403	1.5604	1.6644	1.5729
12	1.6289	1.6118	1.6118	1.5604	1.5775	1.6461	
13	1.6804	1.6289	1.6118	1.5432	1.5947	1.7558	1.5565
14	1.7147	1.6461	1.6118	1.5432	1.6118	1.7556	1.5746
15	1.7318	1.6118	1.6632	1.6804	1.6804		
16	1.7147	1.5775		1.7318	1.6118	1.6644	1.5364
17	1.6289	1.4575	1.4918	1.5947	1.5261	1.6108	1.4842
18	1.6289	1.5604	1.5604	1.4918	1.5089	1.6289	1.4815
19	1.7318	1.6461	1.6804	1.6461	1.6632	2.1033	1.7193
20	1.9719	1.6804	1.8004	1.8861	1.7318	2.1216	1.8107
21	2.0405	1.869	2.0576	2.0748	1.9204		1.8473
22	2.2119	2.1262	2.0576	2.1776	2.1776	2.3777	1.9387
23	2.4348	2.4863	2.4348	2.4863	2.3663	2.7252	1.9936
24	2.009	.703	2.5549	2.3834	2.452	2.6406	2.7801
Max	2.4348	2.4863	2.5549	2.4863	2.452	2.7252	2.7801
Min	1.4918	.703	1.406	1.4403	1.4575	1.5089	1.4815
Avg	1.7596	1.5053	1.8116	1.7147	1.8121	1.9189	1.8239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284009 / 33 KV Sec-19A Nerul

Feeder No / Name : 208 / 11 KV Anand Vaibhav Garden Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4938	.3429	.5144	.4801	.463
2		.3258	.4801	.4287	.4458
3		.2743	.4115	.3772	.4801
4		.2743	.3772	.3429	.3772
5	.3475	.2915	.3429	.3086	.4458
6	.3475	.3086	.3772	.0291	.3772
7	.3109	.3258	.3429	.2743	.3258
8	.2743	.2915	.9259	.2915	.3258
9	.3086	.2915	.3086	.3086	.2915
10	.3086	.2743	.2915	.3086	.2915
11	.3086	.3086	.2743	.3086	.2401
12	.3258	.3258	.2743	.3258	.3086
13	.3429	.3086	.2743	.3601	.2915
14	.3601	.3429	.2915	.3772	.3086
15	.4115	.3601	.3086		.3086
16	.3429	.3429	.2915	.3772	.3429
17	.3086	.2915	.2915	.3429	.3086
18		.3258	.3086	.3086	.3258
19	.3601	.3772	.3601	.3086	.3258
20	.4287	.4115	.3944	.3086	.3944
21	.4287	.4287	.3944	.3429	.4458
22	.4801	.463	.4287	.4801	.4458
23	.4973	.4973	.4973	.4973	.5144
24	.5249	.4801	.5487	.5144	.3429
Max	.5249	.4973	.9259	.5144	.5144
Min	.2743	.2743	.2743	.0291	.2401
Avg	.3756	.3444	.3879	.3479	.3636

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 288057 / 220/33/22KV NERUL S/Stn

Feeder No / Name : 306 / 22KV KUKSHET S/STN - I

HV Express Feeder

Feeder KV- 22 / INCOMING

DATE	01-JUN-17
HR	Load (MW)
24	4.5724
Max	4.5724
Min	4.5724
Avg	4.5724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642] BU 4642

Substation No/ Name :- 288057 / 220/33/22KV NERUL S/Stn

Feeder No / Name : 311 / 22KV KUKSHET S/STN INCOMER

HV Express Feeder

II Feeder KV- 22 / INCOMING

DATE	01-JUN-17
HR	Load (MW)
24	2.5149
Max	2.5149
Min	2.5149
Avg	2.5149

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 283034 / 22/22KV Shirawane MIDC

Feeder No / Name : 301 / 22KV Feeder No 1- Fugro SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905		.1905		.1715		.1905
2	.1905		.1905				.1905
3	.1905		.1905				.1905
4	.1905		.1905				.1905
5	.1905		.1905				.1905
6	.1905		.1905			.1715	.1905
7	.1905	.1905	.1905		.1715	.1715	.1905
8	.1905	.1905	.1905		.1715	.1715	.1905
9	.2667	.2286	.1905	.1905	.2401	.2058	.2667
10	.3429	.4191	.2058		.3429	.381	
11	.4191	.4191		.2286		.4191	.3772
12		.4191	.2743		.3772	.4191	
13	.381	.381		.2286		.381	
14	.381	.3429	.2401		.3429	.3429	.6097
15		.381	.2058	.2286		.3429	.381
16		.3429		.2667		.381	
17		.381		.2667		.381	
18		.2667		.2286	.3086	.3048	
19		.2286		.1905	.2058	.2286	
20		.1905		.2286		.1715	
21		.1905	.1905	.2286			
22		.1905		.2286			
23		.1905		.1715		.1715	
24	.1905		.1905	.1905	.1715	.1715	.1905
Max	.4191	.4191	.2743	.2667	.3772	.4191	.6097
Min	.1905	.1905	.1905	.1715	.1715	.1715	.1905
Avg	.2504	.2914	.2014	.2213	.2504	.2833	.2576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 283034 / 22/22KV Shirawane MIDC

Feeder No / Name : 302 / 22KV Feeder No2- Vilaxmi- SHEDDABLE FEEDER HAVING WEEKLY
Hari Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669		1.2574		1.2346		1.105
2	1.0288		1.2955				1.3717
3	1.0288		1.2955				1.2955
4	1.0669		1.2193				1.2955
5	1.1431		1.2193				1.2193
6	1.2574		1.2193			1.1317	1.2193
7	.8764	.8764	.9526		.8573	.823	.8764
8	1.105	1.0669	1.105		.9945	.8916	1.1431
9	1.1812	1.0669	.9526	.7621	.9259	.9259	1.105
10	1.4098	1.4098	1.2003		1.1317	1.4098	
11	1.5623	1.4098		.8383		1.4861	1.3375
12		1.4098	1.3717		1.3717	1.5623	
13	1.4861	1.3336		.8764		1.4861	
14	1.6766	1.4098	1.2346		1.3375	1.5242	1.3336
15		1.5242	1.406	.8764		1.5242	1.4861
16		1.448		.8764		1.6004	
17		1.4861		.8383		1.5242	
18		1.3336		.8002	1.3375	1.4861	
19		1.0288		.8002	1.0288	1.2193	
20		.9145		.7621		.9945	
21		.8002	.8383	1.0288			
22		.7621		.8383			
23		1.1431		1.0631		.7202	
24	1.3717		1.2193	1.1812	1.1317	1.2346	1.4098
Max	1.6766	1.5242	1.406	1.1812	1.3717	1.6004	1.4861
Min	.8764	.7621	.8383	.7621	.8573	.7202	.8764
Avg	1.2329	1.2014	1.1858	.8878	1.1351	1.2673	1.2460

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 283034 / 22/22KV Shirawane MIDC

Feeder No / Name : 303 / 22KV Feeder No3- Dy. Patil SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572		.4572		.4458		.5716
2	.4191		.4572				.5335
3	.381		.4572				.5335
4	.381		.4191				.5335
5	.381		.4572				.4954
6	.381		.4572			.3429	.4191
7	.4191	.4191	.381		.3429	.3429	.381
8	.5335	.5335	.5335		.4801	.4801	.4954
9	.6478	.5335	.6097	.6097	.583	.583	.6478
10	.724	.6097	.7545		.7202	.6859	
11	.8764	.724		.6478		.6097	.7888
12		.7621	.7545		.823	.7621	
13	.8002	.7621		.6478		.7621	
14	.8764	.8002	.7888		.7888	.9145	.8002
15		.8002	.7202	.6478		.8764	1.829
16		.7621		.6478		.9145	
17		.724		.6478		.8383	
18		.6859		.6097	.6859	.8764	
19		.5335		.6097	.6173	.7621	
20		.6097		.5716		.6173	
21		.5335	.6859	.6097			
22		.5716		.5335			
23		.4954		.4801		.4801	
24	.4954		.4572	.5335	.4801	.5144	.5335
Max	.8764	.8002	.7888	.6478	.823	.9145	1.829
Min	.381	.4191	.381	.4801	.3429	.3429	.381
Avg	.5552	.6388	.5594	.5997	.5967	.6684	.6586

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 283034 / 22/22KV Shirawane MIDC

Feeder No / Name : 304 / 22KV Feeder No4- Lalit SHEDDABLE FEEDER HAVING WEEKLY
Vitessi Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859		.6478		.5144		.6478
2	.6859		.6478				.6859
3	.6478		.6478				.6478
4	.6478		.6478				.6478
5	.6478		.6097				.6097
6	.6859		.6097			.6173	.6859
7	.8383	.8764	.5716		.6173	.6173	.7621
8	.9907	.8764	.7621		.7888	.9259	.9526
9	1.2574	.9907	1.0288	.7621	1.0974	1.0974	1.105
10	1.4098	1.0669	1.0631		1.2346	1.3336	
11	1.4861	1.2193		.9145		1.448	1.2346
12		1.2574	1.1317		1.3032	1.448	
13	1.4098	1.105		.9145		1.2955	
14	1.448	1.2574	1.0631		1.2689	1.3717	1.2955
15		1.2193	1.1317	.9526		1.4098	1.2955
16		1.105		.9145		1.3717	
17		1.0288		.8764		1.2574	
18		.9145		.8383	1.3032	1.1431	
19		.8383		.8002	1.0631	1.0288	
20		.7621		.724		.823	
21		.7621	.8764	.6859			
22		.6859		.6478			
23		.724		.5487		.6173	
24	.724		.6478	.6859	.6173	.6516	.6478
Max	1.4861	1.2574	1.1317	.9526	1.3032	1.448	1.2955
Min	.6478	.6859	.5716	.5487	.5144	.6173	.6097
Avg	.9689	.9817	.8058	.7896	.9808	1.0857	.8629

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 283034 / 22/22KV Shirawane MIDC

Feeder No / Name : 305 / 22KV Feeder No5- Jaspal - SHEDDABLE FEEDER HAVING WEEKLY
Shree Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147		1.6004		1.4403		1.6385
2	1.7147		1.5623				1.5623
3	1.6766		1.5623				1.5623
4	1.6766		1.6004				1.5623
5	1.6766		1.6004				1.6004
6	1.6385		1.6004			1.406	1.5242
7	1.6004	1.5242	1.5623		1.4746	1.4746	1.5242
8	1.829	1.829	1.7528		1.5432	1.5432	1.6766
9	2.1719	1.9052	2.0957	1.7147	2.0233	1.989	1.9052
10	2.5911	2.0957	2.0576		2.2977	2.4006	
11	2.7816	2.4006		1.7909		2.2481	1.6118
12		2.4387	1.7147		2.4006	2.4387	
13	2.6292	2.4387		1.9052		2.3243	
14	2.5149	2.3624	1.8176		1.5775	2.4006	1.9433
15		2.4006	1.8861	1.9814		2.3624	2.21
16		2.2481		2.0576		2.2862	
17		2.2862		2.0195		2.3624	
18		2.1719		1.9052	2.0576	2.21	
19		1.9814		1.8671	1.749	2.21	
20		1.6766		1.7528		1.5775	
21		1.6766	1.7528	1.6766			
22		1.5623		1.5623			
23		1.6385		1.4746		1.4746	
24	1.7528		1.6385	1.6385	1.4746	1.4746	1.6766
Max	2.7816	2.4387	2.0957	2.0576	2.4006	2.4387	2.21
Min	1.6004	1.5242	1.5623	1.4746	1.4403	1.406	1.5242
Avg	1.9978	2.0375	1.7203	1.7959	1.8038	2.0108	1.6921

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 283034 / 22/22KV Shirawane MIDC

Feeder No / Name : 306 / 22KV Feeder No6- Elder - SHEDDABLE FEEDER HAVING WEEKLY
Geldop Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286		.2286		.2058		.1905
2	.1905		.2286				.1905
3	.1905		.1905				.1905
4	.1905		.1905				.1905
5	.2286		.1905				.1905
6	.2667		.2286			.2058	.2286
7	.2667	.2286	.2667		.2401	.2058	.2286
8	.2667	.2286	.2667		.2401	.2058	.2667
9	.3429	.2286	.3048	.3048	.3086	.3429	.3429
10	.381	.2667	.3429		.3772	.4954	
11	.4954	.2667		.4191		.4572	.4801
12		.2667	.3429		.4115	.4572	
13	.5335	.3048		.4191		.4191	
14	.4572	.3048	.4458		.4115	.4572	.4572
15		.3048	.4115	.4191		.4572	.4572
16		.3048		.381		.4191	
17		.3048		.381		.381	
18		.3048		.3429	.3772	.381	
19		.3048		.2667	.3086	.381	
20		.2286		.2667		.2058	
21		.2286	.2667	.2667			
22		.2286		.2286			
23		1.6385		.2058		.2401	
24	.2667		.2286	.1905	.2058	.1715	.1905
Max	.5335	1.6385	.4458	.4191	.4115	.4954	.4801
Min	.1905	.2286	.1905	.1905	.2058	.1715	.1905
Avg	.3075	.3496	.2756	.3148	.3086	.3461	.2773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284005 / 33/11KV Sec 30, Sanpada

S/Stn

Feeder No / Name : 201 / 11KV SAMNA

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.2936	1.1283	1.1145	1.3306	1.1584	1.1145
2	.9431	1.2012	1.0745	.9431	1.2936	1.0498	.9431
3	.8916	1.1088	.9877	.8916	1.2012	.9231	.8059
4	.7373	1.0164	.8779	.8059	1.1088	.8596	.7202
5	.6859	.924	.8048	.7202	.924	.8048	.6173
6	.6173	.7682	.7421	.6173	.7392	.695	.583
7	.5316	.6036	.6219	.583	.6219	.6036	.583
8	.5316	.5729	.5487	.5144	.6468	.6036	.5316
9	.583	.5544	.6219	.5487	.5914	.5853	.5487
10	.6859	.7762	.7701	.6838	.7023	.7059	.6344
11	.7762	.788	.7373	.7392	.695	.6344	.7023
12	.8131	.7442	.7545	.823	.6697	.6859	.7207
13	.8316	.7421	.703	.8779	.6767	.5658	.7392
14	.8316	.7522	.7202	.9145	.6767	.6344	.7762
15	.8501	.8238	.823	.9425	.6767	.7545	.8131
16	.8316	.724	.7716	.8871	.7059	.703	.7023
17	.7392	.6697	.7202	.8316	.724	.7373	.6838
18	.6653	.7421	.7202	.8131	.7133	.6516	.6653
19	.7392	.7522	.7373	.8131	.695	.703	.6468
20	.8871	.7964	.7716	.7947	.7964	.7373	.6468
21	.961	.8869	.9088	.924	.8688	.7545	.7392
22	1.1088	1.0136	.9259	1.1088	1.0608	.9602	.924
23	1.2567	1.1584	1.1317	1.3491	1.2851	1.1317	.9979
24	1.166	1.3306	1.182	1.2346	1.3491	1.267	1.2003
Max	1.2567	1.3306	1.182	1.3491	1.3491	1.267	1.2003
Min	.5316	.5544	.5487	.5144	.5914	.5658	.5316
Avg	.8206	.8643	.8244	.8532	.8647	.7879	.7517

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284005 / 33/11KV Sec 30, Sanpada

S/Stn

Feeder No / Name : 202 / 11 KV MITTAL TOWER

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2195	.2378	.1886	.2402	.2195	.2058
2	.1715	.2218	.2195	.1715	.2218	.2195	.1886
3	.1715	.1848	.1848	.1715	.1848	.2012	.1715
4	.1715	.1829	.1663	.1543	.1848	.1829	.1715
5	.1543	.1829	.1663	.1543	.1848	.1646	.1543
6	.1543	.1848	.1829	.1543	.1848	.1478	.1543
7	.1543	.1829	.1829	.1372	.1848	.1646	.1543
8	.1372	.2033	.1829	.1372	.2033	.1463	.1543
9	.1372	.1663	.1646	.1372	.1848	.1829	.1543
10	.1886	.1848	.1629	.1478	.1848	.1829	.1543
11	.2218	.1991	.1715	.1478	.1829	.1715	.1663
12	.2218	.1991	.1715	.1663	.1646	.1543	.1663
13	.2218	.181	.1715	.1663	.1646	.1543	.1848
14	.2402	.181	.1886	.1848	.1829	.1543	.1848
15	.2402	.2172	.1886	.1848	.2012	.1715	.2033
16	.2402	.1991	.1715	.2033	.2195	.1715	.2402
17	.2218	.1991	.1715	.1848	.1829	.1715	.2218
18	.2033	.181	.1543	.1848	.1829	.1543	.2218
19	.2218	.1991	.1715	.1848	.1646	.1543	.1848
20	.2033	.1629	.1715	.1848	.1646	.1543	.1848
21	.2218	.181	.1715	.1848	.1829	.1543	.1848
22	.2218	.2172	.1715	.2058	.1829	.1715	.1848
23	.2218	.2353	.1886	.2401	.2378	.2401	.2218
24	.2401	.2402	.2172	.2058	.2587	.2378	.2401
Max	.2402	.2402	.2378	.2401	.2587	.2401	.2402
Min	.1372	.1629	.1543	.1372	.1646	.1463	.1543
Avg	.1995	.1961	.1805	.1743	.1930	.1762	.1856

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284005 / 33/11KV Sec 30, Sanpada

S/Stn

Feeder No / Name : 203 / 11 KV IPCL

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.4066	.3801	.3086	.4435	.3841	.3086
2	.2915	.3881	.3292	.2915	.4066	.3475	.2915
3	.2572	.3696	.3292	.2915	.3696	.3142	.2915
4	.2572	.3475	.2926	.2572	.3326	.2772	.2743
5	.2401	.3326	.2561	.2572	.3326	.2772	.2743
6	.2572	.3326	.2561	.2229	.2957	.2957	.2572
7	.2401	.3142	.2926	.2229	.2561	.2378	.2572
8	.2915	.3142	.3109	.2058	.2772	.2926	.2915
9	.3429	.4251	.439	.2572	.5175	.4572	.3772
10	.5316	.5914	.543	.2957	.5914	.567	.5316
11	.5914	.6335	.5487	.3326	.6767	.6001	.5914
12	.6283	.6154	.6173	.3696	.6767	.6001	.6099
13	.6468	.6335	.6001	.4066	.6584	.6173	.6468
14	.6653	.6516	.6173	.4251	.6401	.5658	.6653
15	.6838	.6697	.6173	.4435	.6401	.6344	.6838
16	.6653	.6697	.5658	.4435	.7059	.6344	.6283
17	.6653	.6154	.5487	.4435	.7059	.6001	.6099
18	.6468	.6335	.583	.462	.6219	.5658	.6099
19	.5914	.6154	.5144	.462	.6036	.583	.5914
20	.5544	.5068	.463	.4435	.5304	.5487	.5544
21	.499	.4525	.4115	.462		.4287	.5175
22	.462	.4706	.4115	.499	.4572	.4115	.4805
23	.4435	.3982	.3772	.5175	.4572	.4458	.4435
24	.4115	.4251	.3982	.3429	.4805	.4024	.3944
Max	.6838	.6697	.6173	.5175	.7059	.6344	.6838
Min	.2401	.3142	.2561	.2058	.2561	.2378	.2572
Avg	.4670	.4922	.4460	.3610	.5077	.4620	.4659

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284005 / 33/11KV Sec 30, Sanpada

S/Stn

Feeder No / Name : 208 / 11 KV PUDHARI

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2561	.2172	.1543	.2218	.2012	.1715
2	.1543	.2378	.1829	.1543	.2218	.1829	.1543
3	.1543	.2218	.1646	.1372	.2033	.1646	.1543
4	.1543	.1829	.1478	.1029	.2033	.1294	.1372
5	.1372	.1848	.1294	.1029	.1848	.1294	.12
6	.0914	.1848	.1097	.1029	.1848	.1097	.12
7	.12	.1848	.1097	.1029	.1848	.128	.1543
8	.1372	.2195	.1646	.12	.2033	.1646	.1886
9	.3086	.3109	.2926	.12	.4251	.3658	.3258
10	.5316	.5729	.4344	.1663	.6283	.6036	.5144
11	.6099	.6154	.4287	.1663	.6219	.5658	.5914
12	.6468	.5973	.463	.1663	.6767	.6001	.6283
13	.6653	.5973	.4458	.1848	.6584	.5487	.6653
14	.7023	.0732	.4458	.2218	.6036	.5658	.6838
15	.7023	.5973	.4287	.2218	.6767	.583	.6653
16	.6653	.5973	.3944	.0739	.5853	.5658	.5359
17	.5544	.5611	.3601	.1848	.5853	.5316	.462
18		.5249	.3258	.1848	.567	.463	.3696
19	.4435	.3258	.2401	.1848	.3292	.3086	.3142
20	.4066	.2195	.1886	.1848	.2561	.2572	.2957
21	.3696	.2378	.1543	.1848	.2378	.1886	.2772
22	.3326	.2378	.1886	.2218	.2378	.2058	.2218
23	.3142	.2378	.1886	.2218	.2561	.2229	.2033
24	.2401	.2772	.2378	.1715	.2402	.2561	.2401
Max	.7023	.6154	.463	.2218	.6767	.6036	.6838
Min	.0914	.0732	.1097	.0739	.1848	.1097	.12
Avg	.3752	.344	.2685	.1599	.3831	.3351	.3414

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284005 / 33/11KV Sec 30, Sanpada

S/Stn

Feeder No / Name : 209 / 11 KV MILLENIUM

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0732	.0762	.0762	.0739	.0762
2	.0572	.0762	.0739	.0572	.0762	.0739	.0572
3	.0572	.0762	.0739	.0572	.0762	.0554	.0572
4	.0572	.0762	.0554	.0572	.0572	.0554	.0572
5	.0762	.0762	.0554	.0762	.0572	.5853	.0686
6	.0762	.0762	.0554	.0762	.0572	.0739	.0762
7	.0762	.0572	.0739	.0762	.0572	.0739	.0762
8	.0762	.0572	.0554	.0762	.0762	.0554	.0762
9	.0762	.0762	.0549	.0762	.0762	.0554	.0686
10	.0762	.0762	.0739	.0762	.0762	.0739	.0686
11	.0762	.0549	.0762	.0762	.0554	.0762	.0762
12	.0762	.0549	.0686	.0762	.0554	.0762	.0762
13	.0762	.0739	.0762	.0762	.0554	.0762	.0762
14	.0762	.0732	.0762	.0762	.0554	.0762	.0762
15	.0762	.0732	.0762	.0762	.0554	.0762	.0762
16	.0762	.0732	.0762	.0762	.0739	.0762	.0762
17	.0762	.0732	.0762	.0762	.0739	.0762	.0762
18	.0762	.0732	.0762	.0762	.0739	.0762	.0762
19	.0762	.0732	.0762	.0762	.0739	.0762	.0762
20	.0762	.0732	.0762	.0762	.0739	.0762	.0762
21	.0762	.0732	.0762	.0762	.0739	.0762	.0762
22	.0762	.0739	.0572	.0762	.0739	.0572	.0762
23	.0762	.0732	.0514	.0762	.0739	.0572	.0762
24	.0762	.0762	.0554	.0762	.0762	.0554	.0762
Max	.0762	.0762	.0762	.0762	.0762	.5853	.0762
Min	.0572	.0549	.0514	.0572	.0554	.0554	.0572
Avg	.0738	.0715	.0683	.0738	.0679	.0910	.0729

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 201 / 11 KV VASHI RLY I

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0754	.0686	.0754	.0686	.0754	.0754
2		.0754	.0686	.0754	.0686	.0754	.0754
3		.0754	.0686	.0754	.0686	.0754	.0754
4	.0686	.0754	.0686	.0754	.0686	.0754	.0754
5	.0686	.0754	.0686	.0762	.0686	.0754	.0754
6	.0686	.0754	.0686	.0754	.0069	.0754	.0754
20	.0754	.0686	.0754	.0686	.0754	.0754	.0686
21	.0754	.0686	.0754	.0686	.0754	.0754	.0686
22	.0762	.0686	.0754	.0686	.0754	.0754	.0686
23	.0754	.0686	.0754	.0686	.0754	.0754	.0686
24		.0754	.0754	.0754	.0069	.0754	.0754
Max	.0762	.0754	.0754	.0762	.0754	.0754	.0754
Min	.0686	.0686	.0686	.0686	.0069	.0754	.0686
Avg	.0721	.0729	.0717	.073	.0599	.0754	.0729

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 202 / 11 KV SHAH GROUP

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.4527	.4115	.4715	.4458	.4715	.4715
2		.415	.3429	.415	.4115	.4527	.4527
3		.3772	.3086	.3772	.3429	.415	.3961
4	.3086	.3772	.2915	.3772	.3086	.3772	.3772
5	.3086	.3772	.1029	.3395	.2915	.3772	.3772
6	.3086	.3395	.2743	.3395	.2743	.3395	.3395
7	.2915	.3395	.2743	.3206	.2915	.3395	.3395
8	.2743	.3018	.2743	.3018	.2915	.3206	.3395
9	.2743	.3206	.3239	.3018	.0274	.3206	.2829
10	.2915	.3018	.3206	.2829	.2743	.3206	.2743
11	.3206	.2743	.3206	.2743	.3206	.3395	.2743
12	.3206	.2743	.3395	.2915	.3018		.2743
13	.3206	.2743	.3584	.3086	.3206		.2743
14	.3206	.2915	.3395	.3086	.3018	.3018	.2572
15	.3395	.2743	.3395	.3086	.3395	.3395	.2743
16	.3395	.2743	.3584	.3086	.3206	.3206	.2743
17	.3772	.2915	.3395	.3086	.3395	.3018	.2743
18	.3206	.2915	.3395	.3086	.3206	.3395	.2743
19	.3395	.2915	.3206	.3086	.3206	.3206	.2743
20	.3772	.2915	.3584	.3086	.3206	.3395	.3086
21	.3961	.2743	.3772	.3429	.415	.3395	.3429
22	.4338	.3258	.3961	.3944	.4338	.415	.3772
23	.4904	.3944	.4715	.4287	.5281	.4904	.3944
24	.4801	.5281	.4458	.4904	.4801	.5281	.5281
Max	.4904	.5281	.4715	.4904	.5281	.5281	.5281
Min	.2743	.2743	.1029	.2743	.0274	.3018	.2572
Avg	.3483	.3314	.3346	.3424	.3343	.3686	.3356

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 203 / 11 KV ASSAM BHAVAN

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.9054	.8573	.9054	.7716	.9431	1.1317
2		.8488	.823	.8488	.7202	.9054	1.0562
3		.8299	.7716	.8299	.6859	.8676	.9808
4	.6859	.7922	.7545	.7922	.6001	.8299	.9431
5	.6516	.7545	.7202	.7922	.5487	.8299	.8676
6	.6516	.7545	.7373	.7545	.5144	.8299	.8299
7	.6344	.7922	.7716	.7545	.5487	.811	.7922
8	.6173	.7922	.7202	.7167	.6344	.7733	.6979
9	.6344	.6979	.7621	.7167	.6344	.7545	.7167
10	.6173	.7545	.7545	.679	.6173	.7922	.6687
11	.7545	.703	.7922	.6344	.7545	.7733	.6859
12	.811	.7373	.7922	.6344	.7922		.6859
13	.811	.7716	.7733	.6173	.8299		.703
14	.8488	.823	.8299	.6173	.8299	.8299	.7202
15	.9054	.8059	.8299	.6173	.9054	.9431	.7545
16	.8865	.7545	.8299	.6173	.8299	.7733	.7202
17	.8299	.7202	.7545	.6001	.7356	.7733	.6687
18	.7356	.703	.679	.5144	.7545	.7545	.6687
19	.7167	.7716	.7922	.6344	.7545	.7545	.6859
20	.9054	.8573	.8299	.703	.8676	.9431	.703
21	.9431	.8916	.9054	.7202	.9054	.8299	.703
22	.9808	.8573	.8676	.7545	.9431	.8488	.7202
23	.9808	.8745	.9431	.7716	.9619	1.0185	.7202
24	.7888	.9431	.8916	.9431	.7888	.9619	1.2071
Max	.9808	.9431	.9431	.9431	.9619	1.0185	1.2071
Min	.6173	.6979	.679	.5144	.5144	.7545	.6687
Avg	.7801	.7973	.7993	.7154	.7470	.8428	.7930

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 204 / 11 KV REAL TRADE

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.5281	.3772	.4527	.4458	.4527	.5281
2		.4904	.3429	.4527	.4287	.4527	.5281
3		.4715	.3429	.415	.3772	.415	.4715
4	.3429	.4715	.3429	.4527	.3429	.4715	.4527
5	.3601	.4904	.4287	.4527	.3429	.4715	.4527
6	.3772	.5281	.463	.5281	.3772	.5281	.4715
7	.5144	.547	.5144	.5847	.4973	.5847	.4904
8	.583	.6602	.6859	.5847	.5487	.6413	.6602
9	.8916	.9619	.9145	.6413	.7202	.9431	.679
10	.8916	.9808	.9808	.7922	.8916	1.0562	.9431
11	1.1694	1.0288	1.2826	.7716	1.3203	1.3769	1.1145
12	1.358	1.2003	1.358	.8573	1.358		1.1145
13	1.358	1.286	1.5089	.9431	1.3957	1.3014	.1183
14	1.3203	1.3203	1.3957	1.0288	1.4523	1.3014	1.2346
15	1.4523	1.166	1.3769	1.0802	1.3203	1.358	1.1317
16	1.3957	1.1145	1.4335	1.0288	1.3203	1.4335	1.1145
17	1.4523	1.0802	1.2826	.9431	1.2071	1.2449	1.046
18	1.358	1.0631	1.3014	.823	1.2071	1.2826	1.0288
19	1.2826	1.0288	1.2637	.8573	1.2826	1.2071	.9431
20	.9431	.9431	1.1317	.9088	1.094	1.1694	.8573
21	.9619	.8916	.9997	.7716	.8488	.8488	.7716
22	.7356	.8573	.7167	.5487	.679	.6413	.6859
23	.6036	.6001	.679	.5144	.547	.6602	.6001
24	.4973	1.0288	.3772	.4715	.4458	.4904	.5281
Max	1.4523	1.3203	1.5089	1.0802	1.4523	1.4335	1.2346
Min	.3429	.4715	.3429	.415	.3429	.415	.1183
Avg	.9217	.8641	.8959	.7044	.8521	.8840	.7486

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 205 / 11 KV VASHI RLY -2

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.012	.1132	.12	.132	.12	.1132	.132
2		.1132	.12	.1132	.12	.1132	.132
3		.1132	.1029	.1132	.12	.1132	.132
4	.1029	.1132	.1029	.1132	.1029	.1132	.1132
5	.12	.1132		.1132	.1029	.1132	.1132
6	.12	.132	.12	.1132	.1029	.132	.1132
7	.12	.1509	.12	.132	.1029	.1509	.132
8	.12	.1509	.1372	.132	.12	.1509	.132
9	.2058	.1886	.1715	.1509	.2058	.1886	.2263
10	.2401	.2452	.0754	.1509	.2401	.2829	.2401
11	.2641	.2915	.2263	.1372	.3018	.2452	.2743
12	.2641	.3086	.2641	.1372	.3018		.3086
13	.2829	.2572	.2263	.1372	.3018	.3018	.3086
14	.2829	.2229	.2263	.1372	.2641	.3206	.2743
15	.2829	.2229	.2263	.1372	.3206	.2641	.2401
16	.2829	.2401	.2452	.1372	.3206	.2829	.2401
17	.3018	.2401	.2263	.1372	.3018	.2641	.2401
18	.2641	.2401	.2263	.1372	.3206	.2829	.2229
19	.2452	.2058	.2075	.1372	.2829	.2452	.2058
20	.2075	.1715	.2075	.1372	.2075	.2075	.1715
21	.1886	.1372	.1886	.1372	.1698	.1886	.1543
22	.1509	.1372	.1509	.1372	.1509	.1698	.1372
23	.1509	.12	.1509	.1372	.1509	.1509	.12
24	.12	.2915	.12	.1509	.12	.132	.1509
Max	.3018	.3086	.2641	.1509	.3206	.3206	.3086
Min	.012	.1132	.0754	.1132	.1029	.1132	.1132
Avg	.1968	.1883	.1723	.1333	.2022	.1968	.1881

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 206 / 11 KV CIDCO WATER PUMP Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.4527	.4801	.3772	.3772	.4527	.415
2		.415	.4287	.3772	.3429	.415	.3961
3		.3772	.3772	.3395	.3086	.3772	.3961
4	.3601	.3395	.3429	.3395	.3086	.3772	.3772
5	.3772	.3395	.3772	.3395	.2915	.3395	.3772
6	.3944	.3772	.3944	.415	.3086	.3772	.3961
7	.3601	.4527	.4115	.4338	.3258	.4338	.4338
8	.2743	.4527	.4287	.4338	.3429	.4527	.4715
9	.4973	.4904	.4954	.415	.4115	.5281	.4527
10	.6687	.7545	.7545	.4715	.6687	.7922	.5144
11	.8299	.823	.9808	.5144	.9997	1.0562	.9602
12	1.094	.9774	1.0185	.5316	1.1317		.9259
13	1.094	.9431	1.0185	.5658	1.226	1.0562	.9431
14	1.094	.9602	1.0185	.5487	1.2071	1.0562	.9431
15	1.2071	1.0288	1.0562	.5658	1.1694	1.0374	.9945
16	1.1883	1.0631	.9808	.5144	1.1694	1.0185	.8573
17	1.0562	1.0288	.9054	.4801	1.0562	.9997	.7888
18	.8865	.8059	.8299	.4458	.9054	.8676	.6859
19	.7167	.7716	.6979	.5144	.7545	.6979	.5487
20	.5658	.6859	.6036	.5487	.6413	.6036	.5144
21	.5281	.5487	.4904	.5144	.6036		.4801
22	.5281	.5487	.4904	.4801	.6036	.4904	.4287
23	.4904	.5316	.4715	.4458	.547	.4715	.3772
24	.5144	.823	.5144	.3961	.4115	.4715	.4527
Max	1.2071	1.0631	1.0562	.5658	1.226	1.0562	.9945
Min	.2743	.3395	.3429	.3395	.2915	.3395	.3772
Avg	.6881	.6663	.6486	.4587	.6714	.6533	.5888

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 207 / 11 KV RUPA IT

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
16	1.2826
17	1.2826
18	1.0562
19	1.0562
Max	1.2826
Min	1.0562
Avg	1.1694

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 208 / 11 KV LIFE STYLE

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0686		.0686		
2			.0686		.0686		
3			.0686		.0686		
4			.0686		.0686		
5			.0069		.0069		
12	.0754						
13	.0754	.0686					
14	.0754	.0686					
15	.0754						
16	.0754			.0686			
17	.0754			.0686		.0754	
18	.0754			.0686			.0686
19	.0754	.0686		.0069		.0754	.0686
20	.0754	.0686				.0754	.0686
21	.0754	.0069					.0069
22	.0754					.0754	
23	.0754						
Max	.0754	.0686	.0686	.0686	.0686	.0754	.0686
Min	.0754	.0069	.0069	.0069	.0069	.0754	.0069
Avg	.0754	.0563	.0563	.0532	.0563	.0754	.0532

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway
S/StnFeeder No / Name : 209 / 11 KV ICICI Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
15	1.7541
16	.811
17	1.8673
18	1.6598
19	1.5844
20	1.5089
Max	1.8673
Min	.811
Avg	1.5309

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 402 / 33 KV BSEL

HV Non-Express Feeder

Feeder KV- 33 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2263	.2058	.2263	.2058	.2263	.2263
2		.2263	.2058	.2263	.2058	.2263	.2263
3		.2263	.2058	.2263	.2058	.2263	.2263
4	.2058	.2263	.2058	.2263	.2058	.2263	.2263
5	.2058	.2263	.2058	.2263	.2058	.2263	.2263
6	.2058	.2263	.2058	.2263	.2058	.2263	.2263
7	.2058	.2263	.2058	.2263	.2058	.2263	.2263
8	.2058	.2263	.2058	.2263	.2058	.2263	.2263
9	.4115	.4527	.4572	.2263	.4115	.4527	.4527
10	.823	.9054	.679	.2263	.823	.9054	.6173
11	.9054	.823	.679	.2058	.9054	.9054	.823
12	.9054	.823	.679	.2058	.9054		.823
13	.9054	.823	.679	.2058	.9054	.9054	.823
14	.9054	.823	.679	.2058	.9054	.9054	.823
15	.9054	.823	.679	.2058	.9054	.9054	.823
16	.9054	.823	.679	.2058	.9054	.9054	.823
17	.9054	.823	.4527	.2058	.9054	.9054	.6173
18	.679	.0823	.4527	.2058	.9054	.9054	.6173
19	.4527	.4115	.2263	.2058	.4527	.4527	.4115
20	.2263	.4115	.2263	.2058	.2263	.2263	.4115
21	.2263	.2058	.2263	.2058	.2263		.4115
22	.2263	.2058	.2263	.2058	.2263	.2263	.2058
23	.2263	.2058	.2263	.2058	.2263	.2263	.2058
24	.2058	.823	.2058	.2263	.2058	.2263	.2263
Max	.9054	.9054	.679	.2263	.9054	.9054	.823
Min	.2058	.0823	.2058	.2058	.2058	.2263	.2058
Avg	.5164	.4698	.3791	.2152	.4870	.4938	.4552

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 403 / 33 KV VISHWAROOP

HV Non-Express Feeder

Feeder KV- 33 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.4712	1.3375	1.1317	1.0288	1.4712	1.4712
2		1.358	1.2346	1.1317	.9259	1.358	1.4712
3		1.2449	1.1317	1.0185	.9259	1.2449	1.4712
4	.9259	1.2449	1.0288	1.0185	.9259	1.1317	1.358
5	.9259	1.1317	1.0288	1.0185	.9259	1.1317	1.2449
6	.9259	1.1317	1.0288	1.0185	1.0288	1.1317	1.2449
7	1.2346	1.1317	1.0288	1.0185	1.1317	1.2449	1.1317
8	1.4403	1.4712	1.1317	1.1317	1.2346	1.5844	1.4712
9	1.9547	1.6975	1.3717	.9054	1.9547	1.6975	1.6975
10	1.9547	2.037		1.0185	1.8519	2.2634	1.6461
11	2.037	1.8519		.9259	2.1502	2.2634	1.8519
12	2.037	1.8519		1.0288	2.1502		1.8519
13	2.1502	1.8519	1.5844	1.0288	2.1502	2.2634	1.8519
14	2.1502	1.8519	1.4712	1.0288	2.037	2.2634	1.9547
15	2.1502	1.9547	1.5844	1.0288	2.1502	2.1502	2.0576
16	2.2634	1.9547	1.4712	1.0288	2.1502	2.1502	2.0576
17	2.2634	2.0576	1.5844	1.0288	2.3765	2.3765	1.9547
18	2.3765	2.0576	1.4712	1.0288	2.3765	2.3765	1.9547
19	2.037	2.0576	1.358	1.0288	1.9239	1.9239	1.749
20	1.8107	1.9547	1.2449	1.0288	1.8107	1.8107	1.6461
21	1.6975	1.5432	1.2449	1.0288	1.6975		1.5432
22	1.8107	1.5432	1.1317	1.0288	1.6975	1.6975	1.3375
23	1.8107	1.4403	1.1317	1.0288	1.6975	1.6975	1.2346
24	1.4403	1.8519	1.4403	1.1317	1.0288	1.5844	1.5844
Max	2.3765	2.0576	1.5844	1.1317	2.3765	2.3765	2.0576
Min	.9259	1.1317	1.0288	.9054	.9259	1.1317	1.1317
Avg	1.7808	1.6560	1.2877	1.0339	1.6388	1.7644	1.6182

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 404 / 33 KV SEC 30 SANPADA FRM

HV Non-Express Feeder

VASHI Feeder KV- 33 / INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.2177	1.9879	1.8004	2.2731	2.009	1.8004
2		2.0513	1.8461	1.5947	2.1622	1.8461	1.5947
3		1.885	1.701	1.5432	1.9959	1.5912	1.4403
4		1.7558	1.4815	1.3375	1.885	1.4415	1.3375
5		1.6632	1.4266	1.286	1.6078	1.3717	1.1831
6		1.5524	1.3032	1.1317	1.386	1.3169	1.1317
7		1.2752	1.1946	1.0802	1.2752	1.1523	1.1831
8	1.1317	1.3306	1.2071	1.0288	1.3306	1.2071	1.2346
9	1.4403	1.4969	1.5203	1.0802	1.7741	1.6289	1.4403
10	1.9547	2.1399	1.9547	1.3306	2.1622	2.0633	1.8519
11	2.2177	2.2565	1.9547	1.4415	2.1719	2.0062	2.1068
12	2.384	2.1719	2.0062	1.5524	2.1719	2.1091	2.1622
13	2.384	2.1719	1.9547	1.6632	2.1719	1.9547	2.2731
14	2.4949	2.2262	2.0062	1.7741	2.1399	1.9547	2.3285
15	2.4949	2.2857	2.1091	1.8296	2.2262	2.2119	2.4394
16	2.4394	2.2262	1.9547	1.7741	2.2805	2.1091	2.1622
17	2.2177	2.1176	1.8004	1.7187	2.2262	2.1091	1.9959
18	1.9959	2.1176	1.8004	1.7187	2.1176	1.8519	1.9404
19	2.0513	1.9547	1.6975	1.7187	1.8107	1.8004	1.7741
20	2.1068	1.7375	1.6461	1.6632	1.7918	1.749	1.7187
21	2.0851	1.7918	1.6461	1.8296	1.7918	1.5947	1.7187
22	2.1622	1.9547	1.749	2.1068	2.009	1.749	1.8296
23	2.2177	2.0633	1.9033	2.384	2.2805	2.0576	1.885
24	2.0576	2.2731	2.0633	1.9547	2.384	2.1719	2.1091
Max	2.4949	2.2857	2.1091	2.384	2.384	2.2119	2.4394
Min	1.1317	1.2752	1.1946	1.0288	1.2752	1.1523	1.1317
Avg	2.1080	1.9465	1.7464	1.5976	1.9761	1.7941	1.7767

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 201 / 11 KV NMMC WATER PUMP Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.7252	2.5789		2.7721	2.4394	2.4949
2	2.5423	2.5789	2.4326		2.5688		2.3655
3	2.396	2.4326	2.2131		2.3655		2.2177
4	2.1948	2.2131	2.0851		2.1253		2.0513
5	1.9936	2.0668	1.8839		1.9589		1.922
6	1.8473	1.829	1.7558		1.8111		1.7926
7	1.7558	1.5912	1.6278		1.5524		1.6817
8	1.6827	1.5546	1.5729	1.46	1.6632		1.5339
9	1.6278	1.4815	1.6461	1.5154	1.5893	1.6078	1.4784
10	1.6461		1.6827	1.46	1.6632		1.4045
11	1.5546		1.7193	1.6632	1.8111	1.4784	1.4969
12				1.7556	1.7375	1.6632	1.4969
13	1.5729	1.5729	1.7187	1.6817	1.7375	1.7556	1.5708
14	1.7193	1.7924	1.5893	1.7741	1.7193	1.7002	1.6078
15	1.7924		1.6448	1.885	1.7193	1.7556	1.6632
16			1.7187	1.7556	1.7187	1.8296	1.5524
17	1.7741	1.5364	1.7375	1.7556	1.7556	1.885	1.6448
18		1.7193	1.7924	1.8296	1.8111	1.9035	1.7372
19		1.8656	2.0668	1.9035	1.9774	1.8665	1.7741
20	2.3045	2.1033	2.0668	2.2546	2.2131	2.1807	2.0328
21	2.3777	2.2497	2.1399	2.384	2.1948	2.1807	2.1068
22	2.4143	2.2862		2.5318	2.3045	2.2546	2.1622
23	2.7252	2.6155		2.7536	2.8349	2.809	2.1437
24	2.8166	2.8166	2.7069	2.7166	2.9199	2.7721	2.6981
Max	2.8166	2.8166	2.7069	2.7536	2.9199	2.809	2.6981
Min	1.5546	1.4815	1.5729	1.46	1.5524	1.4784	1.4045
Avg	2.0388	2.0543	1.9229	1.9459	2.0219	2.0051	1.8596

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 202 / 11 KV TEJASWINI HOSTEL Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.1658	2.0538		2.2445	2.1691	2.1691
2	2.1285	1.9978	1.8858		2.1313		2.0559
3	2.0351	1.8671	1.7924		1.9993		1.905
4	1.9605	1.7924	1.7364		1.8861		1.8296
5	1.8484	1.6804	1.6804		1.7918		1.7353
6	1.7364	1.6244	1.643		1.7353		1.6975
7	1.6617	1.587	1.6057		1.6975		1.6787
8	1.7551	1.8298	1.8111	1.773	1.8484		1.8673
9	1.8298	1.8671	1.9605	1.8107	1.8861	1.9239	1.8484
10	2.1472		2.1845	2.037	2.0182		2.3388
11	2.1472		2.4272	1.9993	2.452	2.0182	2.1502
12			2.452	2.1691	2.4459	2.1691	2.1691
13	2.2405	2.3152	2.452	2.1125	2.3152	2.1502	2.3388
14	2.5019	2.3152	2.4709	2.1125	2.4459	2.1691	2.2822
15	2.5206		2.5086	2.1502	2.5766	2.2068	2.2257
16			2.4897	2.2068	2.5688	2.1502	2.3765
17	2.4459	2.3712	2.2405	2.1691	2.4949	2.1313	2.3011
18		2.4459	2.3525	2.1313	2.4209	2.1691	2.2822
19		2.4832	2.5206	2.1691	2.4949	2.3954	2.2634
20	2.4646	2.4646	2.4459	2.3954	2.5019	2.5086	2.3765
21	2.4272	2.3899	2.3899	2.4331	2.5019	2.5086	2.4709
22	2.4459	2.2965		2.3577	2.4272	2.4143	2.3954
23	2.4086	2.3152		2.3388	2.3525	2.4143	2.1879
24	2.3339	2.2592	2.2032	2.32	2.3388	2.2822	2.3011
Max	2.5206	2.4832	2.5206	2.4331	2.5766	2.5086	2.4709
Min	1.6617	1.587	1.6057	1.773	1.6975	1.9239	1.6787
Avg	2.1599	2.1088	2.1503	2.1580	2.2323	2.2363	2.1353

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 203 / 11 KV SANPADA INDL SEC 6 Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715		.1524	.1715	.1715
2	.1715	.1715	.1715		.1524		.1715
3	.1715	.1715	.1715		.1524		.1715
4	.1715	.1715	.1715		.1524		.1524
5	.1524	.1524	.1715		.1524		.1524
6	.1524	.1524	.1715		.1524		.1524
7	.1715	.1715	.1715		.1334		.1524
8	.1715	.1715	.1524	.1524	.1334		.1524
9	.1715	.1715	.1715	.1524	.1334	.1524	.1524
10	.2096		.1905	.1334	.2096		.2096
11	.2477		.2096	.1334	.2286	.1715	.2477
12			.1905	.1334	.1905	.1715	.1905
13	.2286	.2286	.1524	.1524	.2096	.1524	.1905
14	.2096	.2286	.1905	.1524	.2286	.1524	.2096
15	.2096		.1905	.1334	.2477	.1524	.2096
16			.1905	.1334	.2096	.1905	.2096
17	.2096	.2096	.1715	.1334	.1905	.1905	.2096
18		.2096	.1905	.1524	.1905	.2096	.2096
19		.1715	.1715	.1334	.1715	.2096	.1905
20	.2096	.1715	.1715	.1524	.1715	.2096	.2096
21	.1905	.1715	.1524	.1524	.1715		.1905
22	.1715	.1715		.1524	.1715	.1715	.1905
23	.1905	.1715		.1524	.1524	.1715	.1715
24	.1715	.1715	.1715	.1715	.1524	.1524	.1715
Max	.2477	.2286	.2096	.1715	.2477	.2096	.2477
Min	.1524	.1524	.1524	.1334	.1334	.1524	.1524
Avg	.1877	.1795	.1758	.1457	.1754	.1753	.1850

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 204 / 11 KV SEC 6 SUBSTATION Urban/Sheddable Urban Feeder
TRANSFO Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1763	1.1203		1.2696	1.0829	1.251
2	1.1949	1.1016	1.0269		1.1763		1.1576
3	1.1203	1.0082	.9149		1.0642		1.0269
4	.9896	.9149	.8215		.9522		.9149
5	.8589	.8215	.7282		.8402		.8029
6	.7282	.6908	.6535		.7282		.7095
7	.5601	.5788	.5601		.5601		.5975
8	.5601	.5228	.5601	.4854	.5228		.5228
9	.5415	.4854	.5788	.4668	.5041	.4854	.4854
10	.5415		.5601	.5601	.5041		.4668
11	.5601		.5601	.5788	.5041	.5601	.4854
12			.5975	.5788	.5041	.5788	.5415
13	.5975	.5415	.6161	.6348	.5041	.6161	.4668
14	.5975	.5975	.6535	.6535	.5601	.6535	.5415
15	.6908		.6722	.6535	.6161	.6722	.6161
16			.6535	.7095	.6535	.7095	.5601
17	.6348	.5041	.5975	.6535	.6161	.6535	.4668
18		.5788	.6161	.6535	.5975	.6348	.4854
19		.6348	.6161	.6161	.5973	.5975	.5228
20	.7282	.7095	.6722	.7095	.6348	.6535	.6348
21	.8402	.7842	.7655	.7095	.7282	.6535	.6348
22	.9149	.9149		.8215	.9522	.8589	.7655
23	1.0829	1.1763		1.2136	1.307	1.2883	.9335
24	1.363	1.2696	1.1949	1.1203	1.3256	1.2883	1.2883
Max	1.363	1.2696	1.1949	1.2136	1.3256	1.2883	1.2883
Min	.5415	.4854	.5601	.4668	.5041	.4854	.4668
Avg	.795	.7901	.7154	.6952	.7593	.7492	.7033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 205 / 11 KV SAIKRIPA SEC 10 Urban/Sheddable Urban Feeder

SANPADA Feeder KV- 11 /

OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7356	.7167	.6413		.6668	.6478	.7049
2	.6602	.6413	.5658		.5906		.6287
3	.5658	.5658	.4904		.5144		.5716
4	.5093	.5093	.415		.4572		.5144
5	.4527	.4338	.3772		.4001		.4382
6	.3961	.3772	.3395		.362		.4001
7	.3772	.3395	.3395		.3429		.381
8	.415	.3584	.3961	.3048	.381		.4382
9	.4527	.4715	.4338	.4191	.4954	.5144	.4954
10	.5281		.415	.4001	.4954		.4954
11	.4338		.4527	.4191	.4954	.4382	.5144
12			.4382	.381	.4904	.4191	.4572
13	.415	.4527	.4191	.4191	.4715	.381	.4382
14	.4338	.4338	.4191	.4191	.4527	.4191	.4572
15	.4527		.0191	.4191	.4338	.4191	.4572
16			.4191	.4382	.4108	.4382	.381
17	.3961	.3772	.415	.4191	.3734	.4191	.3429
18		.3961	.3961	.4001	.3547	.4001	.4001
19		.4338	.4527	.381	.4481	.381	.4191
20	.5093	.4904	.4668	.4954	.4527	.4954	.4572
21	.5658	.5281	.4854	.5144	.5281	.4954	.4954
22	.6036	.5847		.5906	.6413	.5716	.5335
23	.6979	.6979		.724	.7733	.7049	.5525
24	.7733	.7733	.6979	.6859	.743	.724	.724
Max	.7733	.7733	.6979	.724	.7733	.724	.724
Min	.3772	.3395	.0191	.3048	.3429	.381	.3429
Avg	.5187	.5043	.4316	.4606	.4906	.4918	.4874

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 206 / 11 KV SAMTA SEC 4/7 Urban/Sheddable Urban Feeder
SANPADA Feeder KV- 11 /
OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8111	1.7741	1.7002		1.9418	1.6991	1.7364
2	1.7372	1.6817	1.6078		1.8484		1.6617
3	1.6448	1.5893	1.5524		1.7364		1.5497
4	1.4969	1.4784	1.4415		1.6057		1.419
5	1.386	1.3306	1.3121		1.475		1.2883
6	1.2382	1.2197	1.1827		1.307		1.1389
7	1.0349	1.1088	1.0164		1.1576		1.0082
8	1.0903	1.0719	.9795	1.0829	1.1203		1.0829
9	1.1273	1.1458	1.0534	1.1389	1.1389	1.0642	1.1389
10	1.2197		1.1643	1.1016	1.2136		1.1949
11	1.2567		1.2567	1.1576	1.363	1.1016	1.2323
12			1.3169	1.2323	1.2752	1.1763	1.2696
13	1.3491	1.5708	1.3717	1.0642	1.1643	1.2136	1.2696
14	1.3491	1.5708	1.3535	1.2323	1.2752	1.0642	1.3256
15	1.46		1.2986	1.307	1.3676	1.251	1.3443
16			1.262	1.3443	1.39	1.307	1.251
17		1.2752	1.2127	1.2323	1.2986	1.3443	1.1576
18		1.3491	1.1765	1.1949	1.1706	1.2323	1.2696
19		1.4045	1.3937	1.251	1.39	1.363	1.307
20	1.4969	1.6448	1.4449	1.5497	1.5524	1.5684	1.4003
21	1.5893	1.6632	1.4632	1.5123	1.6448	1.5684	1.4937
22	1.6448	1.7187		1.587	1.7556	1.5497	1.5123
23	1.8296	1.848		1.7737	1.885	1.8858	1.5123
24	1.8665	1.8296	1.8296	1.7924	1.9978	1.8671	1.8858
Max	1.8665	1.848	1.8296	1.7924	1.9978	1.8858	1.8858
Min	1.0349	1.0719	.9795	1.0642	1.1203	1.0642	1.0082
Avg	1.4541	1.4882	1.3359	1.3267	1.4615	1.391	1.3521

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 208 / 11 KV LAXMI SEC10 SANPADA Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0351	2.0351	2.0725		2.0538	1.9791	2.0165
2	1.8858	1.8858	1.9231		1.9605		1.8858
3	1.7924	1.7924	1.7924		1.8484		1.8111
4	1.6991	1.6804	1.7177		1.7364		1.7364
5	1.643	1.6244	1.643		1.6804		1.6617
6	1.6057	1.5684	1.6244		1.6057		1.6057
7	1.6244	1.587	1.6057		1.5684		1.643
8	1.531	1.5123	1.6244	1.531	1.587		1.6057
9	1.4563	1.5123	1.531	1.475	1.4937	1.4377	1.3817
10	1.419		1.4563	1.4563	1.4563		1.3817
11	1.3817		1.4003	1.419	1.3817	1.3817	1.3256
12			1.4003	1.419	1.363	1.419	1.3443
13	1.3256	1.363	1.3817	1.363	1.3256	1.419	1.3817
14	1.3817	1.4003	1.363	1.4563	1.3443	1.4563	1.363
15	1.4563		1.4003	1.531	1.3817	1.531	1.3443
16			1.419	1.531	1.419	1.4937	1.307
17		1.3443	1.4377	1.4937	1.419	1.5123	1.2883
18		1.531	1.4377	1.4937	1.4003	1.531	1.419
19		1.6991	1.6244	1.6057	1.5497	1.5123	1.4563
20	1.7924	1.7924	1.7364	1.8298	1.7551	1.7737	1.6804
21	1.9418	1.8298	1.8298	1.9044	1.8858	1.7737	1.7177
22	2.0538	2.0165		1.9791	2.0351	1.9791	1.6617
23	2.2032	2.1658		2.1658	2.2779	2.1285	1.587
24	2.1658	2.2032	2.2218	2.0538	2.1472	2.1098	2.2032
Max	2.2032	2.2032	2.2218	2.1658	2.2779	2.1285	2.2032
Min	1.3256	1.3443	1.363	1.363	1.3256	1.3817	1.2883
Avg	1.7050	1.7128	1.6201	1.6299	1.6532	1.6524	1.5754

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284055 / 33/11 KV Sec 14,Nerul s/stn

Feeder No / Name : 201 / 11 KV SUN HOME Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2068	2.0748	2.1068	2.0748	2.1691	2.1285	2.2822
2	2.0559	1.9239	2.0351	1.9044	2.037	1.8484	2.1502
3	1.9239	1.8296	1.9239	1.8484	1.9239	1.8111	2.037
4	1.8296	1.7551	1.8484	1.6263	1.7924	1.6975	1.9427
5	1.7164	1.6804	1.6598	1.5089	1.7177	1.5684	1.7164
6	1.5844	1.6221	1.5844	1.4377	1.6787	1.5655	1.6221
7	1.4523	1.4146	1.475	1.4901	1.4901	1.6032	1.4901
8	1.4712	1.5278	1.4415	1.3769	1.4523	1.3957	1.4335
9	1.3769	1.4523	1.4712	1.4712	1.4146	1.4523	1.3769
10	1.3443	1.3443	1.358	1.3169	1.3769	1.1576	1.2826
11	1.3256	1.2136	1.2883	1.3769	1.2826	1.3203	1.1949
12	1.2136	1.2449	1.2136	1.3443	1.2826	1.1883	1.1576
13	1.251	1.226	1.2071	1.3443	1.1883	1.2449	1.1203
14	1.307	1.3256	1.307	1.3957	1.2696	1.3203	1.251
15	1.4563	1.4146	1.4146	1.587	1.4377	1.4146	1.3256
16	1.4523	1.358	1.4563	1.6244	1.3957	1.3203	1.1389
17	1.2883	1.226	1.1949	1.4937	1.3014	1.3014	1.1389
18	1.2323	1.3256	1.2323	1.363	1.2826	1.1883	1.0829
19	1.2449	1.3392	1.3769	1.3203	1.2449	1.4712	1.1317
20	1.6787	1.6617	1.6032	1.6032		1.6409	1.4712
21	1.8296	1.7541	1.773	1.773		1.7918	1.6032
22	1.9993	1.8858	1.8673	1.9805		2.037	1.6787
23	2.2068	2.2822	2.1472	2.3577	2.3577	2.4331	1.8673
24	2.2068	2.2257	2.3339	2.2032	2.4331	2.2916	2.4143
Max	2.2068	2.2822	2.3339	2.3577	2.4331	2.4331	2.4143
Min	1.2136	1.2136	1.1949	1.3169	1.1883	1.1576	1.0829
Avg	1.6106	1.5878	1.5967	1.6176	1.5966	1.5913	1.5379

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284055 / 33/11 KV Sec 14,Nerul s/stn

Feeder No / Name : 204 / Spare (11 KV Sec 30 Nerul Urban/Sheddable Urban Feeder
link Feeder KV- 11 / OUTGOING

DATE	07-JUN-17
HR	Load (MW)
10	.0566
Max	.0566
Min	.0566
Avg	.0566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284055 / 33/11 KV Sec 14,Nerul s/stn

Feeder No / Name : 205 / 11 KV SUBSTATION Urban/Sheddable Urban Feeder
 TRANSFORMER S Feeder KV- 11 /
 OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0566	.0549	.0566	.0566	.0566
2	.0566	.0566	.0566	.0549	.0566	.0566	.0566
3	.0566	.0566	.0566	.0566	.0566	.0566	.0566
4	.0566	.0566	.0566	.0566	.0566	.0566	.0566
5	.0566	.0566	.0566	.0566	.0566	.0566	.0566
6	.0566	.0566	.0566	.0566	.0566	.0566	.0566
7	.0566	.0566	.0566	.0566	.0566	.0566	.0566
8	.0566	.0566	.0566	.0566	.0566	.056	.0566
9	.0754	.0566	.0566	.0566	.0566	.0566	.0566
10	.056	.0566	.0566	.0566	.0566	.0566	.0566
11	.0566	.0566	.056	.056	.0566	.0754	.056
12	.056	.0566	.056	.056	.0566	.0566	.056
13	.056	.0566	.056	.056	.0566	.0566	.056
14	.056	.0566	.056	.056		.0566	.056
15	.056	.0566	.056	.056	.0566	.0754	.056
16	.056	.0566	.056	.056	.0566	.0566	
17	.056	.0566	.056	.056	.0566	.0566	.056
18	.056	.0566	.056	.056	.0566	.0566	.056
19	.0566	.0566	.056	.0566	.0566	.0566	.056
20	.0566	.0566	.0566	.0566	.0566	.0566	.0566
21	.0566	.0566	.0566	.0566	.0566	.0566	.0566
22	.0566	.056	.056	.0754	.0566	.0754	.0566
23	.0566	.0566	.0566	.0566	.0566	.0754	.0566
24	.0566	.0566	.056	.0566	.0566	.0566	.056
Max	.0754	.0566	.0566	.0754	.0566	.0754	.0566
Min	.056	.056	.056	.0549	.0566	.056	.056
Avg	.0572	.0566	.0563	.0570	.0566	.0597	.0564

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284055 / 33/11 KV Sec 14,Nerul s/stn

Feeder No / Name : 206 / 11 KV KUKSHET Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7541	1.8107	1.8484	1.8484	1.8296	1.8673	1.8861
2	1.7353	1.7353	1.8296	1.8107	1.773	1.7177	1.8484
3	1.6787	1.6598	1.7372	1.773	1.6787	1.6263	1.7918
4	1.6032	1.5844	1.6787	1.6598	1.5089	.6036	1.6975
5	1.6032	1.4901	1.5089	1.5089	1.4712	1.4937	1.6409
6	1.5466	1.3957	1.4146	1.2803	1.4335	1.363	1.5278
7	1.5278	1.4523	1.3957	1.3769	1.4523	1.4377	1.4146
8	1.4632	1.4523	1.4523	1.4003	1.5089	1.4712	1.4901
9	1.3957	1.4712	1.2826	1.2826	1.4146	1.4523	1.3392
10	1.3443	1.2883	1.3203	1.2826	1.2637	1.4712	1.2449
11	1.2696	1.2696	1.251	1.2696	1.2449	1.226	1.2323
12	1.251	.0566	1.251	1.2696	1.2826	1.2449	1.1576
13	1.2696	1.2826	1.2323	1.251	1.2696	1.2449	1.226
14	1.307	1.3443	1.2696	1.2323	1.3203	1.3014	1.251
15	1.2883	1.3256	1.251	1.358	1.358	1.3203	.5788
16	1.2696	1.1888	1.2883	1.3256	1.3392	1.1883	1.1576
17	1.1576	1.1763	1.1389	1.251	1.226	1.2071	1.1203
18	1.2136	1.226	1.1389	1.251	1.1694	1.2071	1.1763
19	.5847	1.4146	1.358	1.3957	1.3769	1.5655	1.2637
20	1.773	1.6598	1.6409	1.6975	1.4901	1.7353	1.6975
21	1.7918	1.6598	1.6032	1.7164	1.6787	1.7164	1.6221
22	1.8673	1.8296	1.8107	1.7353	1.8484	1.8296	1.6975
23	1.8861	1.8861	1.848	1.9239	1.9993	1.8484	1.6409
24	1.9427	1.8861	1.8861	1.8673	1.9239	1.8656	1.9427
Max	1.9427	1.8861	1.8861	1.9239	1.9993	1.8673	1.9427
Min	.5847	.0566	1.1389	1.2323	1.1694	.6036	.5788
Avg	1.4802	1.4394	1.4765	1.4903	1.4942	1.4585	1.4436

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284055 / 33/11 KV Sec 14,Nerul s/stn

Feeder No / Name : 207 / 11 KV AGRI KOLI Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7922	.7167	.7733	.7282	.7655	.8316	.7545
2	.7545	.6979	.7282	.7167	.7167	.8299	.6979
3	.7356	.679	.6908	.6413	.7167	.7842	.6413
4	.6979	.6602	.6413	.6036	.679	.7167	.6224
5	.6602	.6036	.5658	.5658	.6036	.6722	.5847
6	.6036	.5658	.5601	.5281	.5847	.5658	.5658
7	.5658	.5658	.547	.499	.6413	.5975	.547
8	.5281	.5658	.5658	.5281	.5281	.5093	.547
9	.5093	.4904	.5658	.5228	.5093	.4481	.5093
10	.4668	.5281	.7356	.5093	.5281	.4481	.547
11	.4481	.4294	.7095	.5041	.4481	.4715	.4294
12	.4854	.4715	.679	.5041	.4527	.4527	.4108
13	.4854	.4904	.7282	.5228	.4904	.4715	.4294
14	.4481	.4527	.4854	.5041	.4904	.4715	.3921
15	.056	.547	.4854	.4854	.4715	.4904	.4108
16	.4854	.4715	.5601	.5415	.4481	.3658	.3734
17	.4854	.4481	.5228	.5788	.4904	.4715	.3921
18	.4481	.5228	.4668	.5975	.5093	.4527	.4108
19	.4715	.4715	.5658	.6224	.4715	.5093	.4338
20	.547	.547	.5847	.6224	.5281	.5658	.5093
21	.6413	.6224	.6602	.7545	.6036	.6036	.4904
22	.6979	.7167	.679	.7356	.7282	.7356	.5281
23	.7356	.7167	.7282	.7545	.7733	.811	.5658
24	.8676	.7922	.811	.7733	.811	.8676	.811
Max	.8676	.7922	.811	.7733	.811	.8676	.811
Min	.056	.4294	.4668	.4854	.4481	.3658	.3734
Avg	.5674	.5739	.6267	.5977	.5829	.5893	.5252

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284055 / 33/11 KV Sec 14,Nerul s/stn

Feeder No / Name : 401 / 33 KV SEC 30 NERUL S/STN Urban/Sheddable Urban Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7878	1.6975	1.701	1.6827	1.9547	1.8073	1.7878
2	1.6301	1.5432	1.6478	1.5775	1.8004		1.6301
3		1.5432	1.5415		1.8004	1.6804	
4	1.262	1.4918	1.4352	1.3146	1.5432	1.4883	1.3146
5	1.1568	1.3889	1.2757	1.1568	1.4403		1.262
6	1.3146	1.1831	1.2226	1.262	1.1831	1.3443	1.1043
7	1.0517	1.1317	1.1694	1.0517	1.0802	1.2883	1.1043
8	1.0517	1.0288	1.0099	.9465		1.1694	1.0517
9	1.2094	1.1317	1.1163	1.1043	1.2346		1.1043
10	1.2346	1.1694	1.2226	1.1317	1.2757	1.2757	1.1317
11	1.3375	1.2757	1.4352	1.1317	1.4883	1.4352	1.286
12	1.3889	1.382	1.4352	1.1831	1.5415		1.3375
13	1.3375	1.4352	1.382	1.286	1.5947	1.4198	1.2346
14	1.4403	1.4883		1.286	1.4883	1.4723	1.2346
15	1.5432	1.4352	1.4723	1.4403	1.4883	1.5249	1.3375
16	1.4918	1.382	1.4723	1.4403	1.382	1.5249	1.2346
17	1.4403	1.382		1.3889	1.4352		1.2346
18	1.3889	1.4352	1.4723	1.286	1.382	1.4723	1.1831
19	1.4918	1.4883	1.5775	1.3375	1.4883	1.3672	1.2346
20	1.5432	1.5947	1.5775		1.6478	1.5775	1.4403
21	1.5947	1.7924	1.5775	1.5947	1.7541	1.6827	
22	1.749	1.8073	1.6301	1.749	1.9136	1.7878	
23	1.8004	1.9136	1.7353	1.6975	2.0199	2.0508	
24	1.9982	1.8004	1.9136	1.8404	2.0062		2.0508
Max	1.9982	1.9136	1.9136	1.8404	2.0199	2.0508	2.0508
Min	1.0517	1.0288	1.0099	.9465	1.0802	1.1694	1.0517
Avg	1.4454	1.4551	1.4556	1.3586	1.5627	1.5205	1.3150

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 201 / 11 KV SEC 24, SEC 30 STN Urban/Sheddable Urban Feeder
NERU Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	2.2119	2.6139	2.3525	2.332	2.4272	2.4646
2	.0373	2.0062	2.5766	2.2405	2.1434	2.3712	2.3525
3		1.8861	2.5019		1.8861	2.3152	
4		1.8347	2.4272	1.9418	1.749	2.2405	1.9791
5		1.8004	2.3152	1.8298	1.7147	2.1845	1.8298
6	.0373	1.749	2.2032	1.8298	1.7833	2.0538	1.8298
7		1.7147	2.0351	1.9044	1.7147	1.9791	1.9791
8	.0373	1.7318	1.8298	1.8298	1.8519	1.8298	1.8484
9	.0373	1.5432	1.7737	1.7924	1.6289	1.8298	1.7364
10	.0343	1.6991	1.6057	1.4746	1.587	1.643	1.5604
11	.0343	.9149	1.5684	1.4746	1.6244	1.587	1.406
12	.0343	1.6804	1.587	1.4918	1.643		1.3546
13	.0343	1.6804	1.587	1.4746	1.6617	1.5684	1.3032
14	.0514	1.6991		1.4575	1.643	1.7364	1.3717
15	.0343	1.6057	1.6057	1.4746		1.6617	1.3889
16	.0343	1.587	1.587	1.6289	1.6057	1.5497	1.3546
17	1.4232	1.5123		1.5604	1.587		1.2174
18	1.3203	1.5123	1.587	1.5432	1.5684	1.531	1.3717
19	1.5604	1.6655	1.7177	1.6289	1.6991	1.6804	1.406
20	1.8176	1.8484	1.8858		1.9231	1.9044	1.4746
21	1.9547	2.0351	2.0725	1.869	2.2218	2.0725	
22	2.0576	2.2779	2.1472	2.0233	2.5393	2.2405	
23	2.2977	2.5393	2.3899	2.0405	2.6139	2.6513	
24	.0373	2.2291	2.6513	2.4459	2.3491	2.5206	2.5953
Max	2.2977	2.5393	2.6513	2.4459	2.6139	2.6513	2.5953
Min	.0343	.9149	1.5684	1.4575	1.5684	1.531	1.2174
Avg	.6456	1.7902	2.0122	1.7868	1.8726	1.9808	1.6912

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 202 / 11 KV METRO,SEC 30 STN Urban/Sheddable Urban Feeder
NERUL Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5953	.1372	.168	.1494	.12	.1494	.168
2	1.1203	.12	.1494	.1307	.12	.1307	.168
3		.12	.1307		.12	.1494	
4	.9335	.12	.112	.1307	.1029	.1494	.1494
5	.8589	.1029	.1307	.1307	.12	.1307	.1307
6	.8215	.1029	.112	.1307	.12	.1494	.1494
7	.7655	.1029	.1494	.1307	.12	.1307	.1307
8	2.0165	.1029	.168	.112	.12	.1494	.1494
9	1.8858	.1372	.1494	.1307	.12	.0934	.1494
10	1.5947	.112	.112	.12	.1494	.168	.1372
11	1.5604	.1307	.112	.12	.1494	.1494	.1372
12	1.5604	.112	.112	.12	.1307		.12
13	1.5775	.1307	.0934	.1029	.1494	.112	.1029
14	1.5947	.112		.12	.1494	.112	.1029
15	1.5775	.112	.112	.12	.1307	.0934	.12
16	1.6118	.112	.1307	.12	.1494	.1307	.12
17	.12	.112		.1372	.1494		.12
18	.1029	.1494	.112	.12	.112	.112	.12
19	.12	.1307	.112	.1372	.1307	.1307	.12
20	.12	.1494	.112		.1494	.1307	.12
21	.12	.1494	.1307	.12	.1494	.1307	
22	.12	.1307	.1494	.1372	.1494	.1494	
23	.12	.1494	.1307	.1372	.168	.168	
24	2.6886	.1543	.1494	.1494	.1372	.1494	.168
Max	2.6886	.1543	.168	.1494	.168	.168	.168
Min	.1029	.1029	.0934	.1029	.1029	.0934	.1029
Avg	1.1124	.1247	.1290	.1276	.1340	.1350	.1342

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 204 / 11 KV NERUL GYMKHANA Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0343	.0373		.1029	.0373	
2	.056	.0343	.0373	.056	.1029	.0373	.056
3		.0343	.056		.0857	.0373	
4	.056	.0514	.0373	.056	.0857	.0373	.056
5	.056	.0514	.056	.056	.0686		
6		.0686			.0686		.056
7	.056	.0686	.056	.056	.0686	.056	.0747
8	.0747	.0686	.0747	.0747	.0686	.0373	.0747
9	.0747	.0686	.0747	.0747	.0343	.0373	.0747
10	.0686	.056		.0686	.0373	.056	.0686
11	.0686	.056	.056	.0686	.0373	.056	.0514
12	.0686	.0373		.0686	.0373		.0686
13	.0686	.056	.0747	.0514	.0373	.0373	.0514
14	.0686	.0373		.0514	.0373	.056	.0514
15	.0686	.056	.056	.0514	.0373	.0373	.0514
16	.0686	.0373	.056	.0514	.0373	.056	.0343
17	.0514	.056		.0686	.0373		.0514
18	.0514		.0747	.0686	.0373	.056	.0514
19	.0686		.0934	.0686	.056	.0747	.0686
20	.0686	.0373	.0934		.056	.0747	.0686
21	.0514		.1307	.1029	.056	.0747	
22	.0514	.056	.056	.1029	.0373	.056	
23	.0514		.056	.1029	.056	.056	
24	.056	.0514	.0373	.056	.1029	.0373	.056
Max	.0747	.0686	.1307	.1029	.1029	.0747	.0747
Min	.0514	.0343	.0373	.0514	.0343	.0373	.0343
Avg	.0618	.0508	.0639	.0678	.0577	.0504	.0592

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 205 / 11 KV SEC 14 S/S NERUL Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	04-JUN-17	05-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0171		.0171	
2		.0171		.0171	
3		.0171		.0171	
4		.0171		.0171	
5		.0171		.0171	
6		.0171		.0171	
7		.0171		.0171	
8		.0171		.0171	
9				.0171	
10	.0171		.0171		.0171
11	.0171		.0171		.0171
12	.0171		.0171		.0171
13	.0171		.0171		.0171
14	.0171	.0373	.0171		.0171
15	.0171		.0171		.0171
16	.0171		.0171		.0171
17	.0171		.0171		.0171
18	.0171		.0171		.0171
19	.0171		.0171		.0171
20	.0171				.0171
21	.0171		.0171		
22	.0171		.0171		
23	.0171		.0171		
24		.0171		.0171	
Max	.0171	.0373	.0171	.0171	.0171
Min	.0171	.0171	.0171	.0171	.0171
Avg	.0171	.0191	.0171	.0171	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 206 / 11 KV SEC-50 NRI Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	04-JUN-17	05-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0171		.0171	
2		.0171		.0171	
3		.0171		.0171	
4		.0171		.0171	
5		.0171		.0171	
6		.0171		.0171	
7		.0171		.0171	
8		.0171		.0171	
9		.0171		.0171	
10	.0171		.0171		.0171
11	.0171		.0171		.0171
12	.0171		.0171		.0171
13	.0171		.0171		.0171
14	.0171		.0171		.0171
15	.0171		.0171		.0171
16	.0171		.0171		.0171
17	.0171		.0171		.0171
18	.0171		.0171		.0171
19	.0171		.0171		.0171
20	.0171				.0171
21	.0171		.0171		
22	.0171		.0171		
23	.0171		.0171		
24		.0171		.0171	
Max	.0171	.0171	.0171	.0171	.0171
Min	.0171	.0171	.0171	.0171	.0171
Avg	.0171	.0171	.0171	.0171	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 208 / 11 KV HAWARE Sec 28 Nerul Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.5316	.5975	.5487	.5487	.5975	.6219
2	.5487	.463		.5121	.5144		.5487
3		.3772	.5415		.3772	.5228	
4	.4572	.3429		.4024	.3429		.439
5	.4024	.3429	.4854	.3658	.3258	.4854	.4024
6	.3841	.3258	.4481	.4024	.2915		.3475
7	.3292	.3258	.4108	.4024	.2743	.4108	.3841
8	.3658	.3086	.3174	.3475	.3086	.3734	.3841
9	.3475	.3086	.3174	.3841	.3429	.4108	.3658
10	.3086	.3361	.3292	.3772	.3734	.3475	.3429
11	.3258	.3174	.3658	.3086	.3547	.3475	.3258
12	.3086	.2987	.3109	.3258	.3734		.2743
13	.2915	.3174	.3109	.3258	.2987	.3109	.2572
14	.3086	.3361		.3086	.3361	.3292	.2401
15	.2915	.3174	.3109	.3086	.3174	.3475	.0171
16	.2915	.2987	.3292	.3601	.2987	.3109	.2915
17	.3258	.2987		.3258	.3174		.3086
18	.3086	.2987	.3109	.2915		.2926	.2915
19	.3086	.3547	.3475	.3258	.3361	.2926	.2401
20	.3772	.4108	.3841		.3734	.3658	.3429
21	.4115	.6348	.4024	.3772	.5601	.4207	
22	.3944	.8215	.439	.4458	.6722	.5121	
23	.5487		.567	.4287	.6722	.6584	
24	.6219	.5658	.6535	.5853	.583	.6722	.695
Max	.6219	.8215	.6535	.5853	.6722	.6722	.695
Min	.2915	.2987	.3109	.2915	.2743	.2926	.0171
Avg	.3853	.3884	.4090	.3846	.3997	.4215	.3560

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela

s/s

Feeder No / Name : 201 / 11 KV RAGHULEELA NEW Urban/Sheddable Urban Feeder

FEEDER Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3174					.5658
2	.2614		.4668	.4668		.4668	.4527
3		.2263					.3584
4	.2427	.2075	.3734	.3361		.2801	.2829
5		.2263					.2263
6	.2241	.2075	.2801	.2614		.2241	.2075
7	.2054	.2452	.2427	.2427		.2054	.2263
8	.2801	.2641	.2614	.2241		.2054	.2427
9	.3361	.3734	.3734	.3361		.3361	.4108
10	1.2883	1.7737	1.251		1.1016	1.3256	.4481
11	1.9044	1.475	1.3443		2.0725	1.9044	2.3152
12		2.3525	2.4646		2.3899	2.3712	
13	2.3339	2.3339	2.4459		2.4086	2.4272	2.3899
14	2.3339	2.2965	2.4646		2.4832	2.6139	2.3339
15	2.3712	2.3152	2.5019		2.4459	2.2779	2.4459
16	2.3899	2.2592	2.4459		2.3899	2.0538	2.2965
17	2.4459	2.3339	2.5019		2.3899	2.5019	2.3525
18	2.3525	2.3899	1.8671		2.5206	2.1285	2.3899
19	1.9418	2.4272	1.9605		2.5206		2.5766
20	1.9791	2.3712	2.2405		2.5766		2.5206
21	1.0642	1.7737	2.4646	2.0351	2.2779	.9896	
22		1.1016			1.4003		
23		1.0269	.8402		.9149		
24	.3174	.3547	.8402	.7842		.8215	.5601
Max	2.4459	2.4272	2.5019	2.0351	2.5766	2.6139	2.5766
Min	.2054	.2075	.2427	.2241	.9149	.2054	.2075
Avg	1.3485	1.3327	1.4816	.5858	2.1352	1.3608	1.2801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela

s/s

Feeder No / Name : 203 / 11 KV VASHI RLY 3

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.132					.132
2	.1494	.132	.1494	.1494		.1307	.132
3		.132					.132
4	.1307	.132	.1307	.1307			.1509
5		.132					.1509
6	.1494	.132	.1494	.1307		.1307	.1509
7	.2054	.1509	.1494	.1494		.1494	.1509
8	.168	.1867	.168			.2241	.2241
9	.2614	.2801	.1867	.1494		.2614	.2801
10	.2614	.2427	.1867		.2801	.2801	.2801
11	.2614	.2427	.2054		.2614	.2614	.2801
12		.2427	.2054		.2801	.2614	
13	.2614	.2427	.1867		.2987	.2801	.2614
14	.2801	.2614	.2054		.2801	.2801	.2614
15	.2987	.2614	.2241		.2614	.2801	.2801
16	.2987	.2427	.1867		.2801	.2614	.2427
17	.2801	.2614	.1867		.2987	.2427	.2614
18	.2801	.2614	.1867		.2801	.2801	.2801
19	.2614	.2614	.1867		.2801		.2614
20	.2427	.2427	.2241		.2801		.2241
21	.2241	.2054	.1867		.2614	.2054	
22		.1867			.2801		
23		.168	.1867		.1494		
24	.1494	.1509	.1494	.168		.1494	.1509
Max	.2987	.2801	.2241	.168	.2987	.2801	.2801
Min	.1307	.132	.1307	.1307	.1494	.1307	.132
Avg	.2313	.2035	.1821	.1463	.2694	.2299	.2144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela

s/s

Feeder No / Name : 204 / 11 KV MICROTECH

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5658					.4715
2	.4668	.547	.4854	.3547		.4108	.415
3		.4904					.3206
4	.3734	.415	.3734	.3174		.3547	.3584
5		.3772					.3584
6	.3547	.3584	.2801	.2801		.3547	.3772
7	.4108	.3206	.2614	.2614		.3921	.3961
8	.6535	.6535	.3174			.5601	.6161
9	.7468	.7282	.5041	.2987		.8402	.8589
10	1.1203	1.0082	.6722		1.1389	1.1576	.9335
11	1.307	1.2696	.9335		1.363	1.4003	1.2696
12		1.363	1.1949		1.4377	1.4937	
13	1.4003	1.4377	1.1203		1.475	1.531	1.4377
14	1.419	1.4563	1.1016		1.531	1.475	1.4563
15	1.5123	1.4937	1.1016		1.531	1.475	1.4937
16	.0934	1.3443	.9896		1.4377	1.3443	1.2136
17	.0747	1.1763	.8775		1.363	1.3443	1.1016
18	.1307	1.1203	.7095		1.3443	1.1949	1.0642
19	.1494	1.1203	.6722		1.3443		1.1576
20	1.0082	1.0269	.6908		1.1203		1.0082
21	.9149	.8402	.7095		.9335	.8775	
22		.7095			.8402		
23		.6908	.5975		.6535		
24	.6161	.6036	.5601	.4294		.5041	.547
Max	1.5123	1.4937	1.1949	.4294	1.531	1.531	1.4937
Min	.0747	.3206	.2614	.2614	.6535	.3547	.3206
Avg	.7085	.8799	.7076	.3236	1.2510	.9830	.8428

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela

s/s

Feeder No / Name : 205 / 11 kV SUBSTATION TRF

Urban/Sheddable Urban Feeder

Raghuleel Feeder KV- 11 /

OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0377					
2	.0747		.0747	.0747		.0747	
3		.0566					
4	.0747		.0747	.0747		.0747	
6	.056		.0747	.0747		.0747	
7	.056	.0566	.056	.056		.056	
8	.056		.056	.056			.0566
9	.056	.056	.056	.056		.056	.0747
10	.056	.0747	.056		.0747	.056	.056
11	.0747	.056	.056		.0747	.0747	.056
12		.056	.056		.056	.056	
13	.056	.056	.056		.056	.056	.056
14	.056	.056	.056		.056	.0747	.0747
15	.056	.056	.0747		.056	.056	.056
16	.056	.0747	.056		.056	.056	.056
17	.056	.056	.056		.0747	.0747	.056
18		.0747	.0747		.056		.056
19		.056	.056		.056		.056
20		.056	.056		.0747		.0747
21		.056	.0747		.056	.0747	
22		.056			.0747		
23		.0747	.056		.056		
24	.056	.0566					
Max	.0747	.0747	.0747	.0747	.0747	.0747	.0747
Min	.056	.0377	.056	.056	.056	.056	.056
Avg	.0600	.0591	.0619	.0654	.0627	.0654	.0607

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela

s/s

Feeder No / Name : 206 / 11 KV MAITHILLI

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.4335					1.4335
2	1.587	1.358	1.4563	1.475		1.531	1.358
3		1.3203					1.3014
4	1.4937	1.3014	1.419	1.4563		1.4937	1.3957
5		1.358					1.4146
6	1.4377	1.3957	1.419	1.419		1.4377	1.4146
7		1.4712	1.4377	1.4377		1.5123	1.4523
8	1.6244	1.5278	1.475	1.4377		1.5123	1.4937
9	2.0165	1.9044	1.6991	1.4937		1.8298	1.9418
10	2.1658	2.2592	2.1098		2.2218	2.2218	2.1285
11	2.4272	2.4086	2.2405		2.4086	2.4832	2.2779
12		2.1098	2.2218		2.3899	2.4272	
13	2.3712	2.0351	2.0538		2.4086	2.4086	2.2779
14	2.3899	2.0911	2.0165		2.3525	2.3712	2.2779
15	.6535	2.3712	1.9978		2.2291	2.3899	2.3339
16	.6908	2.2965	2.1845		2.4459	2.1434	2.2779
17	.6908	2.2592	1.9231		2.3525	2.4272	2.2405
18	.5601	2.2779	1.8858		2.3339	2.2218	2.2405
19	.4108	1.9791	1.7737		1.9605		1.8671
20	.3361	1.8111	1.7177		1.8484		1.7364
21	1.6991	1.7177	1.6804		1.7177	1.6244	
22		1.5684			1.5497		
23		1.5497	1.5123		1.5497		
24	1.6991	1.4712	1.531	1.5123		1.5684	1.5089
Max	2.4272	2.4086	2.2405	1.5123	2.4459	2.4832	2.3339
Min	.3361	1.3014	1.419	1.419	1.5497	1.4377	1.3014
Avg	1.4267	1.8032	1.7877	1.4617	2.1263	1.9767	1.8187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela

s/s

Feeder No / Name : 207 / 11 KV FISH MARKET

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1509					.2075
2	.1867	.132	.2054	.2054		.2054	.1698
3		.132					.1509
4	.168	.132	.1867	.1867		.1867	.1509
5		.132					.1509
6		.132	.1494	.168		.168	.1509
7	.1494	.1509	.1307	.1494		.1307	.1509
8	.112	.168	.1307	.1307			.1132
9	.1307	.0934	.112	.1307		.1307	.112
10	.112	.0934	.0934		.112	.0934	.0747
11	.0747	.0934	.112		.0934	.0747	.0747
12		.0934	.0934		.0934	.0934	
13	.0934	.0934	.112		.0934	.0934	.0934
14	.0934	.112	.112		.0934	.112	.112
15	.112	.0934	.112		.0934	.0934	.1029
16	.112	.0934	.112		.112	.0934	.0934
17	.112	.0934	.112		.0934	.0934	.0934
18	.1307	.112	.112		.0934	.0934	.112
19	.168	.1867	.168		.1494		.1307
20	.2054	.2054	.168		.168		.1494
21	.2427	.1867	.1867		.1867	.1867	
22		.2241			.1867		
23		.2241	.2241		.2241		
24	.2054	.1886	.2241	.2054		.2241	.2263
Max	.2427	.2241	.2241	.2054	.2241	.2241	.2263
Min	.0747	.0934	.0934	.1307	.0934	.0747	.0747
Avg	.1417	.1382	.1428	.1680	.1281	.1296	.1310

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela

s/s

Feeder No / Name : 208 / 11 KV ORISSA BHAVAN

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1886					.1886
2	.2054	.1698	.2054	.2054		.1867	.1698
3		.1509					.1698
4	.168	.1509	.1867	.1867		.168	.1698
5		.1509					.1509
6	.1494	.1509	.168	.168		.168	.1509
7	.168	.1698	.168	.168		.3174	.1698
8	.3361	.3174	.2241	.1867			.3018
9	.7095	.547	.3547	.2054		.6908	.5601
10	1.0082	.9709	.5975		1.0082	1.0082	.8402
11	1.0829	.9709	.6908		1.1203	1.0269	.9709
12		.9335	.7282		1.1576	1.0269	
13	1.0456	1.0269	.7095		1.0082	1.0456	1.0269
14	1.0269	.8775	.7655		1.0829	1.1203	.9709
15	1.0456	.9896	.7095		1.1203	1.0642	1.0269
16	1.0456	.9335	.6908		1.0829	1.0082	
17	.9335	.8775	.5788		1.0082	.9896	.8029
18	.5975	.6908	.5601		.8775	.8589	.7468
19	.6535	.6348	.3547		.6908		.6348
20	.4481	.3734	.2801		.5228		.4668
21	.3734	.2801	.2427		.2987	.3547	
22		.2614			.2801		
23		.2427	.2427		.2241		
24	.2241	.2075	.2054	.2614		.2054	.2263
Max	1.0829	1.0269	.7655	.2614	1.1576	1.1203	1.0269
Min	.1494	.1509	.168	.168	.2241	.168	.1509
Avg	.6234	.5111	.4332	.1974	.8202	.7025	.5129

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela

s/s

Feeder No / Name : 209 / 11 KV CIDCO BUSINESS

HV Non-Express Feeder

CENTER Feeder KV- 11 /

OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0566					.0377
2	.112	.0566	.0747	.0747		.0747	.0566
3		.0377					.0377
4	.0747	.0566	.0747	.0747		.0747	.0377
5		.0566					.0377
6	.0747	.1698	.0747	.0747		.0747	.2075
7	.056	.3395	.3547	.1307		.3734	.3772
8	.2427	.3395	.3734	.3361		.3734	.3547
9	.2614	.3361	.3734	.3921		.4108	.4108
10	.2614	.2614	.4108		.3734	.4668	.4108
11	.2614	.2987	.4108		.3921	.4854	.4294
12		.2241	.4108		.3921	.4668	
13	.2801	.2987	.4294		.3921	.4481	.4481
14	.2801	.2987	.4108		.3921	.4481	.4294
15	.2427	.2987	.4108		.3734	.4481	.4481
16	.2801	.3174	.4294		.3734	.4668	
17	.2614	.2987	.4108		.3734	.4668	.4108
18	.2241	.2987	.4108		.3547	.4481	.3361
19	.1494	.2614	.4108		.3547		.2427
20	.0747	.0747	.4108		.3734		.056
21	.0747	.056	.3547		.3734	.168	
22		.056			.0934		
23			.1867		.056		
24	.1867	.0377	.056	.056		.0747	.0377
Max	.2801	.3395	.4294	.3921	.3921	.4854	.4481
Min	.056	.0377	.056	.056	.056	.0747	.0377
Avg	.1888	.1970	.3240	.1627	.3334	.3394	.2530

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela
s/sFeeder No / Name : 401 / 33 KV VASHI RLY S/STN FRM HV Non-Express Feeder
RAGH Feeder KV- 33 / INCOMING

DATE	01-JUN-17	03-JUN-17	05-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
2		.2241	
11			1.1763
13	.8402		
Max	.8402	.2241	1.1763
Min	.8402	.2241	1.1763
Avg	.8402	.2241	1.1763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada

s/stn

Feeder No / Name : 201 / 11 KV RELIANCE Sanpada Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3							.7762
4							.7392
6							.5544
7	.4801			.4119	.5853		
8		.543		.439			.5611
9					.7133		.7468
10	.8059		.8573				
11				.6173	1.0288		
12			1.0288				
13	1.0631				.9945	1.0498	.9602
14	1.0136		.9945	.6687		1.0349	1.0288
15	.9955					1.0608	
16			.9431		1.0288		.9259
17	.9593					.9877	
18	.8326			.6516		.8686	.823
19	.8413					.8589	
20	.7059					.7577	
21	.724		.6268			.695	
22	.7522		.7421			.7577	
23			.7421	.9231		.7577	
24	.9602	.905	.8916	.7682	.8779		.8871
Max	1.0631	.905	1.0288	.9231	1.0288	1.0608	1.0288
Min	.4801	.543	.6268	.4119	.5853	.695	.5544
Avg	.8445	.724	.8533	.6400	.8714	.8829	.8003

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada

s/stn

Feeder No / Name : 202 / 11 KV SAI PRIDE

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3							1.5074
4							1.2757
6							1.0288
7	1.1145			.933	1.1317		
8		.9779		.9922			1.0454
9					1.0288		.9665
10	.8962		1.2003				
11				1.0669	.884		
12			1.166				.945
13	1.0402				.8535	1.0974	
14	.9922		.9297	1.0364		1.0277	.8535
15	1.0936					1.0608	
16			1.1126		.9297		.8535
17	.9061					.9945	
18	.9665			1.0059		1.0867	.5182
19	1.1043					1.0682	
20	1.1984					1.2517	
21	1.2967		1.3904			1.3073	
22	1.5729		1.4548			1.6644	
23			1.4403	1.7284		1.6278	
24	1.6461	1.6613	1.8839	1.5497	1.6766		1.9161
Max	1.6461	1.6613	1.8839	1.7284	1.6766	1.6644	1.9161
Min	.8962	.9779	.9297	.933	.8535	.9945	.5182
Avg	1.1523	1.3196	1.3223	1.1875	1.0841	1.2187	1.0910

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20,Sanpada

s/stn

Feeder No / Name : 203 / 11 KV SEWERAGE TREATMENT Urban/Sheddable Urban Feeder

PLANT Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3							.2033
4							.2218
6							.3361
7	.4287			.2743	.3696		
8		.5853		.1867			.6283
9					.7947		1.1763
10	.8326		.7202				
11				.2401	.9602		
12			.5144				.6173
13	.9231				.8573	.6838	
14	.9877		.5144	.3258		.8238	.8573
15	.8238					.7392	
16			.463		.7716		.4458
17	.8413					.5601	
18	.695			.3772		.5975	.7202
19	.6283					.6283	
20	.3841						
21	.2402		.2241			.2402	
22	.2715		.1829			.1848	
23			.1848	.3109			
24	.2743	.2957	.1524		.2772		.2614
Max	.9877	.5853	.7202	.3772	.9602	.8238	1.1763
Min	.2402	.2957	.1524	.1867	.2772	.1848	.2033
Avg	.6109	.4405	.3695	.2858	.6718	.5572	.5468

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20,Sanpada

s/stn

Feeder No / Name : 204 / 11 KV PAN INDIA VASHI Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3							.3734
4							.3547
6							.3696
7	.3944			.3511	.3361		
8		.4755		.3658			.439
9					.7095		.5914
10	.8871		.6859				
11				.5144	.9945		
12			.7888				.9945
13	.9055				1.0288	1.0082	
14	.9593		.7888	.5316		.9328	.9945
16	1.0164		.7716		1.0802		.9602
17	.9425					.9055	
18	.9328			.4458		.8501	.9259
19	.6584					.7682	
20	.567					.5914	
21	.4938		.4805			.4805	
22	.4755		.4066			.4854	
23			.4066	.4066			
24	.5144	.4066	.5228	.3982	.4066		.4251
Max	1.0164	.4755	.7888	.5316	1.0802	1.0082	.9945
Min	.3944	.4066	.4066	.3511	.3361	.4805	.3547
Avg	.7289	.4411	.6065	.4305	.7593	.7528	.6428

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20,Sanpada

s/stn

Feeder No / Name : 205 / 11 KV KESHAV KUNJ

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3							1.4232
4							1.3375
6							1.335
7	1.2003			1.1523	1.335		
8		1.2483		1.0595			1.1145
9					1.3395		1.3169
10	1.3441		1.5775				
11				1.5432	1.6461		
12			1.7833				1.5775
13	1.5123				1.6461	1.5927	
14	1.5466		1.7833	1.7147		1.7164	1.6461
15	1.7078					1.6476	
16			1.8004		1.7147		1.5089
17	1.4373					1.5415	
18	1.4373			1.5089		1.595	1.3717
19	1.4419					1.6118	
20	1.4217					1.5249	
21	1.6975		1.4232			1.595	
22	2.1948		1.6918			1.8991	
23			1.7833	1.9357			
24	2.2634	1.7459	2.3045	1.768	2.2862		2.5194
Max	2.2634	1.7459	2.3045	1.9357	2.2862	1.8991	2.5194
Min	1.2003	1.2483	1.4232	1.0595	1.335	1.5249	1.1145
Avg	1.6004	1.4971	1.7684	1.5260	1.6613	1.636	1.5151

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20,Sanpada

s/stn

Feeder No / Name : 206 / 11 KV LADIES HOSTELL,SEC Urban/Sheddable Urban Feeder

10,SA Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3							.8215
4							.7655
6							.7842
7	.9602			.9522	.8589		
8		.9522		1.1389			1.0456
9					.8589		.7842
10	.7842		.8573				
11				.6516	.7888		
12			.8573				.8573
13	.6613				.823	.8029	
14	.8215		.7888	.703		.8402	.6516
15	.9145					1.1949	
16			.7888		.7888		.7716
17	.8962					.9709	
18	1.0082			.8916		.9335	.8573
19	1.0164					1.0642	
20	1.1203					1.1576	
21	1.1088		1.0829			1.1949	
22	1.1458		.9335			1.1576	
23			1.0349	1.0903			
24	1.1145	1.0082	1.1949		1.094		1.0082
Max	1.1458	1.0082	1.1949	1.1389	1.094	1.1949	1.0456
Min	.6613	.9522	.7888	.6516	.7888	.8029	.6516
Avg	.9627	.9802	.9423	.9046	.8687	1.0352	.8347

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20,Sanpada

s/stn

Feeder No / Name : 207 / Sector 11 sanpada Bhoomi Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3							.6468
6							.5175
7	.463			.4251	.5121		
8		.5175		.4024			.439
9					.6626		.6584
10	.9774		.823				
11				.4458	.9259		
12							.8916
13	.9134		.8916		.8573	.8962	
14	.8326		.823	.6516		.924	.8573
15	1.0059					.9134	
16			.7716				.7888
17	.9145					.9145	
18	.7701			.583		.8131	.6516
19	.7133					.7577	
20	.7207					.7023	
21	.6283		.5544			.6154	
22	.695		.5792			.6838	
23			.6878	.7602			
24	.7373	.7421	.7164	.7522	.7842		.788
Max	1.0059	.7421	.8916	.7602	.9259	.924	.8916
Min	.463	.5175	.5544	.4024	.5121	.6154	.439
Avg	.7810	.6298	.7309	.5743	.7484	.8023	.6932

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada

s/stn

Feeder No / Name : 209 / Cidco Exhibition

HV Non-Express Feeder

Centre, Vashi Feeder KV- 11 /

OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3							.0747
6							.0747
7	.0686			.056	.056		
8		.056		.056			.0747
9					.056		.0747
10	.056		.0686				
11				.0686			
12							.0686
13	.056		.0686			.056	
14	.056		.0686			.056	
15	.056					.6722	
16			.0686				
17	.056					.6722	
18	.056					.6722	.0686
19	.056					.7095	
20	.056					.7282	
21	.056		.056			.6348	
22	.056		.056			.7282	
23			.056	.056			
24	.0686	.056	.056	.056	.056		.0747
Max	.0686	.056	.0686	.0686	.056	.7282	.0747
Min	.056	.056	.056	.056	.056	.056	.0686
Avg	.0581	.056	.0623	.0585	.056	.5477	.0730

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284254 / 33/33KV Sec- 20 Sanpada

Feeder No / Name : 401 / Feeder No1-33KV IC Sec14
Nerul Feeder KV- 33 / INCOMING

HV Non-Express Feeder

DATE	01-JUN-17
HR	Load (MW)
24	4.473
Max	4.473
Min	4.473
Avg	4.473

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284254 / 33/33KV Sec- 20 Sanpada

Feeder No / Name : 402 / Feeder No 2- 33KV IC NRI HV Non-Express Feeder
Sec 5 Feeder KV- 33 / INCOMING

DATE	01-JUN-17
HR	Load (MW)
24	.4001
Max	.4001
Min	.4001
Avg	.4001

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 401 / 33 KV IC-1 SEC 6 SANPADA
SS Feeder KV- 33 / INCOMING

HV Non-Express Feeder

DATE	01-JUN-17
HR	Load (MW)
23	1.0185
24	.0103
Max	1.0185
Min	.0103
Avg	.5144

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 402 / 33KV INCOMER to NRI SS

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17	03-JUN-17
HR	Load (MW)	Load (MW)
17		7.4691
23	6.6873	
24	7.0165	
Max	7.0165	7.4691
Min	6.6873	7.4691
Avg	6.8519	7.4691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 404 / 33 KV IC-1 SEC 20 SANPADA

HV Non-Express Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17
HR	Load (MW)
23	4.321
24	.0057
Max	4.321
Min	.0057
Avg	2.1634

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 405 / 33 KV Amey

Urban/Sheddable Urban Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17
HR	Load (MW)
23	.5658
Max	.5658
Min	.5658
Avg	.5658

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 407 / 33 KV IC-1 SEC 14 NERUL

HV Non-Express Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17
HR	Load (MW)
24	.4166
Max	.4166
Min	.4166
Avg	.4166

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 409 / 33 KV INCOMER TO SEC-12 B
SS Feeder KV- 33 / INCOMING

HV Express Feeder

DATE	01-JUN-17
HR	Load (MW)
24	.6533
Max	.6533
Min	.6533
Avg	.6533

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 410 / 33 KV IC-2 SEC 20 SANPADA

HV Non-Express Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17
HR	Load (MW)
24	1.3631
Max	1.3631
Min	1.3631
Avg	1.3631

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 411 / 33KV INCOMER to Sec-19D
VASHI Feeder KV- 33 / INCOMING

HV Express Feeder

DATE	01-JUN-17
HR	Load (MW)
24	4.3021
Max	4.3021
Min	4.3021
Avg	4.3021

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 413 / 33 KV IC- 33/33KV

HV Non-Express Feeder

Switching Se Feeder KV- 33 /

INCOMING

DATE	01-JUN-17
HR	Load (MW)
1	.0103
23	1.2449
Max	1.2449
Min	.0103
Avg	.6276

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 414 / 33KV INCOMER to Sec-19D
Vashi Feeder KV- 33 / INCOMING

HV Express Feeder

DATE	01-JUN-17
HR	Load (MW)
24	4.5153
Max	4.5153
Min	4.5153
Avg	4.5153

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 415 / 33 KV IC VASHI RLY S/STN Urban/Sheddable Urban Feeder
Feeder KV- 33 / INCOMING

DATE	01-JUN-17
HR	Load (MW)
1	.0154
23	1.358
Max	1.358
Min	.0154
Avg	.6867

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 416 / 33 KV IC-2 SEC 6 SANPADA
Feeder KV- 33 / INCOMING

HV Non-Express Feeder

DATE	01-JUN-17
HR	Load (MW)
1	.0103
23	2.3765
Max	2.3765
Min	.0103
Avg	1.1934

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 417 / 33 KV IC SEC 30 NERUL STN

HV Non-Express Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17
HR	Load (MW)
1	.0103
24	1.0185
Max	1.0185
Min	.0103
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 201 / 11 KV KL-1

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	2.846
Max	2.846
Min	2.846
Avg	2.846

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 202 / 11 KV B G SHIRKE

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	1.2483
Max	1.2483
Min	1.2483
Avg	1.2483

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 203 / 11 KV V M JOG

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	2.8921
Max	2.8921
Min	2.8921
Avg	2.8921

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 204 / 11 KV Herambha

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	2.3712
Max	2.3712
Min	2.3712
Avg	2.3712

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 205 / 11 KV SEC 14

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	2.6797
Max	2.6797
Min	2.6797
Avg	2.6797

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING
S/SFeeder No / Name : 206 / 11 KV STP 12 FEEDER
Feeder KV- 11 / OUTGOING

HV Express Feeder

DATE	01-JUN-17
HR	Load (MW)
24	.0554
Max	.0554
Min	.0554
Avg	.0554

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 208 / SEC-9/E FEEDER NO-2

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	.4168
Max	.4168
Min	.4168
Avg	.4168

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223032 / 22/11 KV Kalmboli Steel

Market

Feeder No / Name : 201 / 11 KV STEEL CHAMBER

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1552	.1573	.1571	.1349	.1441	.1515	.1608
2	.1515	.1573	.1552	.1331	.1386	.1478	.1571
3	.1497	.1536	.1515	.1368	.1368	.1441	.1515
4	.1331	.1536	.146	.1368	.1349	.1405	.1515
5	.1386	.1536	.1423	.1441	.1331	.1368	.1497
6	.1331	.1463	.1405	.1294	.1368	.1294	.1405
7	.1183	.1317		.1294	.1405	.1294	.1386
8	.1238	.1244	.1811	.1405	.1331		.1349
9	.1515	.2495		.1977	.2014	.2033	.194
10	.439	.4269	.5175	.2384	.4287	.414	.3841
11	.6584	.669	.608	.255	.5969		.6438
12	.7316	.669	.632	.2883	.6727		.7316
13	.7023	.7503	.706	.2864	.6745	.7429	.7096
14	.6584	.706	.5858	.2181	.7023	.7096	.6621
15	.6584	.669	.6579	.2255	.706	.706	.6731
16	.7096		.6745	.2144	.7023	.5988	.684
17	.6292	.5951	.547	.2014	.6246	.6339	.5853
18	.5487	.4842	.4897	.1515	.5175	.5581	.5121
19	.4134		.3493	.1719		.4177	.4024
20	.2926	.2643	.255	.1589		.2938	.278
21	.2231	.1885	.231	.1589		.231	.2122
22	.1866	.1756	.1903		.1885	.2107	.1866
23	.1646	.1608	.17	.1497	.1774	.1885	.1719
24	.1497	.1463	.1497	.1478	.1534	.1441	.1737
Max	.7316	.7503	.706	.2883	.706	.7429	.7316
Min	.1183	.1244	.1405	.1294	.1331	.1294	.1349
Avg	.3509	.3333	.3562	.1804	.3545	.3349	.3495

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 201 / 11 KV C.E. FEEDER Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			3.2674			3.3608	
2			3.0807			3.1417	
3			2.9874			2.9569	
4			2.8006			2.8645	
5			2.6139			2.6797	
6			2.4272			2.5873	
7	2.4646	2.1491	2.2779		2.364	2.4272	
8		2.1491	2.2405		2.3152	2.4025	2.3152
9		2.0416	2.2405	2.3152	2.1849	2.2177	
10			2.3152	2.1849	2.2916	2.2405	2.2923
11			2.3525		2.2916		2.2923
12	2.2405	2.2779	2.3525	2.2405	2.2405		2.1491
13	2.2405	2.2405	2.3152		2.2546		2.1849
14		2.4394	2.2779	2.2565			
15	2.5431	2.6513	2.3152		2.4646		
16		1.9044	2.2405		2.5133		2.364
17		2.2405		2.3282	2.4949	3.2114	
18	2.3282	2.5873	2.5393	2.3899	2.2032	3.5101	2.1849
19	2.5393	2.5133	2.6139		2.4949	3.2114	
20	2.6863	2.8645	2.6139	2.7633	2.8645	3.3608	2.6505
21		2.9569	2.9874		2.894		
22	3.1741	3.1786	3.1367	3.546			
23	3.5101	3.3265	3.2487		3.6961		
24	3.5818	3.3311	3.3981	2.1658		3.6961	
Max	3.5818	3.3311	3.3981	3.546	3.6961	3.6961	2.6505
Min	2.2405	1.9044	2.2405	2.1658	2.1849	2.2177	2.1491
Avg	2.7309	2.5533	2.6367	2.4656	2.5045	2.9246	2.3042

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 202 / 11 KV N.T.F.C. FEEDER HV Non-Express Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2987			.2587	
2			.2987			.2614	
3			.2614			.2614	
4			.2241			.2587	
5			.2241			.2241	
6			.2241			.2241	
7	.2286	.2195	.2587		.1791	.2241	
8		.2614	.2614		.2507	.2241	.2286
9		.2987	.2587	.2641	.2507	.2957	
10			.2667	.2507	.4066	.4191	.3224
11			.2667		.4066		.3224
12	.4108	.4435		.2149			.394
13			.3048		.4108		.3734
14		.4435	.3048	.2241			
15	.4108	.4481	.3048		.4435		
16		.4108	.3048		.4481	.1524	.2241
17		.3696	.2987	.2149	.4481	.1905	
18	.2987	.2957	.2667	.2507	.3326	.1905	.1433
19	.2614	.2957	.2667		.2957	.1143	
20	.2507	.2957	.3048	.2149	.2587	.1524	.0716
21		.2587	.3018		.2587		
22	.2865	.2587	.3018	.2149			
23	.2865	.2957	.3429	.2507	.2587		
24	.3429	.3361	.2587	.3429		.2614	
Max	.4108	.4481	.3429	.3429	.4481	.4191	.394
Min	.2286	.2195	.2241	.2149	.1791	.1143	.0716
Avg	.3085	.3288	.2785	.2443	.3320	.2321	.2600

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 203 / SUB STATION T/F Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0187			.0187	
2			.0187			.0187	
3			.0187			.0187	
4			.0187			.0187	
5			.0187			.0187	
6			.0187			.0187	
7		.0183	.0187		.0183	.0187	
8		.0187	.0187		.0179	.0187	.0191
9		.0187	.0187	.0191	.0183	.0187	
10			.0191	.0183	.0187	.0191	
11			.0191		.0187		.0187
12	.0187	.0187	.0191	.0179			.0187
13			.0191		.0187		.0179
14			.0191	.0187			
15	.0187	.0185	.0191		.0187		
16		.0187	.0191		.0187		.0179
17		.0187	.0191	.0179	.0187		
18	.0179	.0187	.0191	.0187	.0187		.0187
19	.0179	.0187	.0191		.0187		
20	.0179	.0187	.0191	.0179	.0187		.0187
21		.0185	.0191		.0187		
22	.0187	.0187	.0191	.0187			
23	.0187	.0187	.0191	.0183	.0187		
24		.0187	.0185	.0191		.0187	
Max	.0187	.0187	.0191	.0191	.0187	.0191	.0191
Min	.0179	.0183	.0185	.0179	.0179	.0187	.0179
Avg	.0184	.0186	.0189	.0185	.0186	.0187	.0185

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 204 / 11 KV MHATMA FEEDER Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			3.4004			3.4541	
2			3.2674			3.2674	
3			3.1741			2.9874	
4			2.9874			2.8006	
5			2.6139			2.6139	
6			2.3339			2.4272	
7	2.1658	2.0058	2.2177		2.1491	2.4025	
8		2.0058	2.3339		2.0774	2.3101	2.2916
9		2.0165	2.2779	2.2405	2.0774	2.3339	
10			2.3899	2.0774	2.4394	2.3899	2.3152
11			2.4272		2.4025		2.3152
12	2.5393	2.3285	2.5393	2.2405	2.4394		2.2207
13		2.4646	2.4272		2.4394		2.3152
14		2.5133	2.3525	2.2405			
15	2.5072	2.6797	2.3152		2.6797		
16		1.9404	2.2779		2.5873	3.2114	2.2923
17		2.2177	2.3152	2.3899	2.4025	3.0247	
18	2.2923	2.2177	2.4272	2.364	2.2177	2.7633	2.1491
19	2.5393	2.5873	2.5393		2.5873	2.5393	
20	2.9995	2.9569	2.9127	2.8654	2.9874	3.2861	2.9127
21		3.0247	3.062		3.2341		
22	3.1367	3.4189	3.2861	3.2952			
23	3.5848	3.8439	3.8089	3.7342	4.1076		
24	3.8866	3.5101	3.6961	3.6595		4.0329	
Max	3.8866	3.8439	3.8089	3.7342	4.1076	4.0329	2.9127
Min	2.1658	1.9404	2.2177	2.0774	2.0774	2.3101	2.1491
Avg	2.8502	2.6082	2.7243	2.7107	2.5885	2.8653	2.3515

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 205 / 11Kv Pump P2

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			3.4355			3.4189	
2			3.2674			3.2674	
3			3.1741			2.9569	
4			2.9938			2.809	
5			2.6139			2.6242	
6			2.2405			2.4272	
7	2.268	2.0774	2.2405		2.2405	2.3101	
8		2.0774	2.1472		2.2207	2.3339	2.1948
9		2.0774	2.1472	1.9753	2.2405	2.3101	
10			2.268	2.1658	2.3101	2.3411	
11			2.3411		2.3101		2.3899
12	2.268	2.2177	2.4143	2.0774	2.2177		2.3152
13		2.2779	2.3411		2.3101		2.2207
14		2.4394	2.268	2.1658			
15	2.5072	2.4949	2.2314		2.4025		
16		1.848	2.1948		2.4949	3.2922	2.2207
17		1.9605	2.268	2.1658	2.3101	2.9995	
18	2.3152	2.2177	2.3777	2.1658	2.2177	2.7069	2.0485
19	2.2923	2.3339	2.7801		2.4949	2.8532	
20	2.838	2.6242		2.7633	2.7721	3.0727	2.5072
21		2.7721	2.9995		2.9874		
22	3.1367	3.2341	3.219	3.0803			
23	3.5848	3.6037	3.5848	3.5818	4.0657		
24	3.9232	3.5117	3.7342	3.219		3.6961	
Max	3.9232	3.6037	3.7342	3.5818	4.0657	3.6961	2.5072
Min	2.268	1.848	2.1472	1.9753	2.2177	2.3101	2.0485
Avg	2.7926	2.4855	2.6644	2.5360	2.5063	2.8387	2.271

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 206 / HORIZON SCHOOL

HV Non-Express Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4854			.5601	
2			.4854			.5175	
3			.4668			.4854	
4			.4668			.4854	
5			.5041			.4854	
6			.5975			.5228	
7	.4954	.6722	.6722		.6348	.6535	
8		.7316	.7468		.7164	.7468	.7167
9		.9335	.9709	.5335	.9335	1.0269	
10			1.0082	.4298	1.307	1.2574	
11			1.1203		1.307		1.2696
12	1.3169	1.3306	1.1203	.5853			1.2437
13		1.2567	1.0185		1.3443		1.0745
14		1.3306	.9431	.5975			
15	1.2178	1.2567	.9054		1.3443		
16		1.0349	.7922		1.0456	2.1125	1.1576
17		.9335	.7545	.2149	.924	1.094	
18	.7095	.7095	.7095	.5373	.7468	1.094	.7095
19	.6447	.6348	.7095		.6722		
20	.7095	.6722	.6478	.5601	.6722		.6348
21		.5975	.5658		.6722		
22	.5731	.6348	.5281	.5487			
23	.5731	.5914	.5281	.4656	.5601		
24	.5228	.5373	.5975	.4954		.5601	
Max	1.3169	1.3306	1.1203	.5975	1.3443	2.1125	1.2696
Min	.4954	.5373	.4668	.2149	.5601	.4854	.6348
Avg	.7514	.8661	.7227	.4968	.9200	.8287	.9723

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 207 / 11 kv khandeshwar railway EHV Non-Express Feeder
stn Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0305			.0305	
2			.061			.0305	
3			.061			.061	
4			.0686			.061	
5			.061			.061	
6			.061			.061	
7	.0221	.0335	.0305		.032	.0305	
8		.0335	.0084		.0328	.0076	.0701
9		.0335	.0076	.0072	.0335	.0076	
10			.0114	.032	.0076	.0072	
11			.0122		.0076		.032
12	.032	.0076	.0114	.032			.0335
13			.0213		.0076		.032
14		.0076		.032			
15	.0373	.0076	.0229		.0076		
16		.0076	.0316		.0076		.0328
17		.0076	.0305	.0335	.0076		
18	.032	.0305	.0324	.0335	.0076		.0335
19	.0335	.0305	.0339		.0305		
20	.0671	.0305	.0339	.0671	.0343		.064
21		.0305	.0351		.0305		
22	.0671	.037	.0351	.0671			
23	.0716	.0305	.0686	.064	.0305		
24	.0373	.0671	.061	.0373		.0305	
Max	.0716	.0671	.0686	.0671	.0343	.061	.0701
Min	.0221	.0076	.0076	.0072	.0076	.0072	.032
Avg	.0444	.0263	.0361	.0406	.0198	.0353	.0426

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 201 / 11 KV STATION T/F

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0532	.0566	.0566	.0532	.0566	
2	.0566	.0532	.0566	.0566	.0532	.0566	
3	.0566	.0532	.0566	.0566	.0532	.0566	
4	.0566	.0532	.0566	.0566	.0532	.0566	
5	.0566	.0532	.0566	.0566	.0532	.0566	
6	.0566	.0532	.0566	.0566	.0532	.0566	
7	.0566	.0566	.0566	.0566	.0532	.0566	
8	.0532	.0566	.0566	.0566	.0532	.0568	
9	.0532	.0566	.0566	.0532	.0566	.0532	.0566
10	.0532	.0566	.0566	.0532	.0566	.0532	
11	.0532	.0566	.0566	.0532	.0566	.0532	
12	.0532	.0566	.0566	.0532		.0532	
13	.0532	.0566	.0566	.0532	.0566	.0532	
14	.0532	.0566	.0566	.0532	.0566	.0532	
15	.0532	.0566	.0566	.0532	.0754	.0532	
16	.0532	.0566	.0566	.0532	.0566	.0532	.0566
17	.0532	.0566	.0566	.0532	.0566	.0532	
18	.0532	.0566	.0566	.0532	.0566	.0532	
19	.0532	.0566	.0566	.0532	.0566	.0532	
20	.0532	.0566	.0566	.0532	.0566	.0532	
21	.0532	.0566		.0532	.0566		
22	.0532	.0566	.0566	.0532	.0566		
23	.0532	.0566	.0566	.0532	.0566	.0566	.0566
24	.0566	.0532	.0566	.0566	.0532	.0566	.0566
Max	.0566	.0566	.0566	.0566	.0754	.0568	.0566
Min	.0532	.0532	.0566	.0532	.0532	.0532	.0566
Avg	.0543	.0556	.0566	.0545	.0561	.0548	.0566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 203 / 11 KV JUI GAON

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.1495	3.1893	3.7723	3.3951	3.898	3.8289	4.3381
2	3.678	3.1184	3.1876	3.3196	3.4019	3.5648	4.0552
3	3.3951	2.8704	3.0556	3.0556	3.1184	3.0178	3.7723
4	3.1687	2.6932	2.9047	2.8669	2.8704	2.9235	3.5837
5	2.999	2.64	2.9235	2.8104	2.8349	2.8858	3.3951
6	2.9613	2.5692	2.6783	2.7915	2.7286	2.9047	3.3196
7	2.8669	2.9801	2.7726	2.5274	2.6046	2.7161	3.263
8	3.0556	2.9613	2.8292	2.6783	2.516	3.0178	3.2253
9	2.8349	3.0367	3.1499	2.64	3.1499	3.0476	
10	2.8349	3.0556	3.1876	2.6046	3.1876	3.083	3.3196
11	2.8349	3.2065	3.3951	3.1893	2.8481	2.9944	3.4328
12	2.8349	3.3008	3.0556	3.1716		2.8704	3.2065
13	2.7286	3.1687	3.263	3.083	2.8292	2.8349	2.9424
14	2.7109	2.6406	3.0178	3.0653	3.0178	2.8172	2.9801
15	2.7109	2.4897	3.4517	3.0476	3.4517	2.7818	2.999
16	2.6932	2.2634	3.0744	3.0476	3.131	2.6578	3.0178
17	2.6046	2.5274	2.8669	2.959	2.8669	2.6046	2.7915
18	2.64	3.0367	3.1121	2.8704	3.1121	2.5337	2.6783
19	3.0121	3.6969	3.1876	3.2602	3.3196	3.1893	3.0178
20	3.5437	3.4894	3.8477	3.5437	3.6403	3.4019	3.6025
21	3.6677	3.678		3.8449	4.0552	3.7209	3.3951
22	2.0553	3.7346	4.0741	3.9866	4.3759	4.0043	3.4328
23	3.9335	4.4324	4.4136	4.3233	4.6399	4.7154	3.7346
24	4.5456	3.5968	4.0175	3.9986	4.1815	4.1872	4.3759
Max	4.5456	4.4324	4.4136	4.3233	4.6399	4.7154	4.3759
Min	2.0553	2.2634	2.6783	2.5274	2.516	2.5337	2.6783
Avg	3.1025	3.0990	3.2712	3.1700	3.2948	3.1793	3.3860

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 204 / 11 KV SURAJ PARK FEEDER Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8481	2.516	2.6783	2.6783	2.516	2.8481	2.8292
2	2.5463	2.3388	2.4709	2.4897	2.3034	2.6783	2.6406
3	2.4143	2.1085	2.2822	2.2445	2.1439	2.4143	2.5652
4	2.2068	1.949	2.2445	2.0748	2.073	2.1879	2.5086
5	2.1125	1.9313	2.1879	2.0559	2.0022	2.0559	2.452
6	2.0936	1.8959	2.0748	2.037	1.949	2.1502	2.4143
7	2.1125	2.0559	2.1313	1.9427	2.073	2.1502	2.3765
8	2.1502	1.9805	2.2257	2.2445	2.1085	2.2822	2.3577
9	1.9845	2.0559	2.2068	2.073	2.2068	2.073	
10	1.949	2.0936	2.1879	2.0376	2.1879	1.949	2.2634
11	1.9667	2.037	2.1879	1.9845	1.9805	1.8959	2.1502
12	1.9667	2.1313	2.0559	1.9845		1.8781	2.2634
13	1.949	2.0182	1.9427	1.949	1.9993	1.8959	2.1879
14	1.8959	1.905	2.037	1.949	2.037	1.8959	2.1313
15	1.9136	1.8673	2.0936	1.949	2.0936	1.8781	2.0748
16	1.8959	1.773	2.037	1.9667	2.0182	1.8073	1.9993
17	1.8781	1.9427	1.9805	1.9667	1.9805	1.7896	1.9805
18	1.825	2.1691	2.0748	1.949	2.0748	1.7718	1.9616
19	2.073	2.3577	2.3011	2.2502	2.1879	2.1262	2.2634
20	2.3388	2.5274	2.4897	2.3743	2.6783	2.4097	2.5274
21	2.4806	2.5274		2.5337	2.8481	2.516	2.5463
22	2.5337	2.6595	2.6972	2.64	2.8858	2.6578	2.6217
23	2.64	2.8481	2.8481	2.7818	3.0367	3.131	2.5086
24	3.0178	2.64	2.8858	2.8858	2.7286	3.0744	2.9424
Max	3.0178	2.8481	2.8858	2.8858	3.0367	3.131	2.9424
Min	1.825	1.773	1.9427	1.9427	1.949	1.7718	1.9616
Avg	2.1997	2.1804	2.2749	2.2101	2.2658	2.2299	2.3724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 205 / 11 KV AWAS FEEDER

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.3951	2.7109	3.2065	3.0744	3.1716	3.1876	3.3951
2	3.0178	2.516	3.0178	2.6783	2.8704	2.8858	3.2065
3	2.9235	2.3034	2.7726	2.452	2.6578	2.5652	3.0178
4		2.2502	2.6406	2.3954	2.4983	2.452	2.8292
5	2.4331	2.1971	2.5086	2.3388	2.392	2.4143	2.6406
6	2.3954	2.1616	2.3954	2.2634	2.268	2.3954	2.5652
7	2.2257	2.2257	2.3011	2.1879	2.2148	2.3765	2.452
8	2.3011	2.2068	2.2257	2.2068	2.1085	2.2634	2.2822
9	2.1616	2.1691	2.2257	2.1262	2.2257	2.1262	
10	2.1439	2.1502	2.2822	2.1439	2.2822	2.073	2.3388
11	2.1794	2.1313	2.32	2.2325	2.2634	2.0376	2.3954
12	2.1794	2.2445	2.2445	2.2148		2.073	2.2634
13	2.2148	2.1691	2.3011	2.2325	2.1125	2.1085	2.1313
14	2.2148	2.0182	2.2634	2.2502	2.2634	2.1439	2.1125
15	2.2502	1.9427	2.452	2.2502	2.452	2.1439	2.1125
16	2.268	1.8107	2.3765	2.3034	2.2634	2.1616	2.1125
17	2.3034	2.1313	2.3388	2.3211	2.3388	2.2325	2.1879
18	2.3743	2.6217	2.4922	2.3743	2.4897	2.2325	2.2068
19	2.6578	2.8669	2.6029	2.5869	2.5652	2.4629	2.452
20	3.0476	2.9424	2.8481	2.6932	3.0178	2.8704	2.9424
21	3.1893	3.0933		2.9944	3.2819	3.0121	2.9235
22	3.1893	3.1687	3.3041	3.1007	3.3196	3.1893	2.9613
23	3.1361	3.3762	3.3762	3.3133	3.6403	3.7723	2.8481
24	3.6214	3.083	3.3762	3.3196	3.2956	3.4894	3.5271
Max	3.6214	3.3762	3.3762	3.3196	3.6403	3.7723	3.5271
Min	2.1439	1.8107	2.2257	2.1262	2.1085	2.0376	2.1125
Avg	2.601	2.4371	2.6031	2.5023	2.6084	2.5279	2.6045

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 206 / 11 KV KAMOTHE VILLAGE Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.5837	3.1893	3.2819	3.3951	3.3133	3.3951	3.5837
2	3.1876	2.959	3.0556	3.1499	3.0121	3.1687	3.3951
3	2.8669	2.6932	2.8292	2.8669	2.7641	2.8481	3.2065
4	2.7349	2.5514	2.7726	2.7161	2.516	2.7349	3.0178
5	2.6406	2.4629	2.7161	2.6217	2.4629	2.6029	.9431
6	2.6029	2.3743	2.584	2.584	2.3743	2.6406	2.7915
7	2.4709	2.452	2.5274	2.3577	2.4274	2.452	2.7349
8	2.4331	2.4143	2.4897	2.4143	2.4983	2.5274	2.6029
9	2.1616	2.3765	2.4331	2.2148	2.4331	2.2502	
10	2.1262	2.2634	2.32	2.2148	2.32	1.9845	2.5463
11	2.1262	2.2634	2.4331	2.1971	2.3011	2.1439	2.4709
12	2.1262	2.2257	2.4331	2.2148		2.1616	2.2822
13	2.1262	2.0748	2.32	2.2325	2.2068	2.1262	2.2634
14	2.2325	2.0559	2.452	2.3034	2.452	2.1439	2.2634
15	2.3388	1.905	2.6217	2.3211	2.6217	2.1439	2.2634
16	2.392	2.0182	2.4331	2.3211	2.3577	2.1616	2.2634
17	2.4097	2.2257	2.3388	2.3388	2.3388	2.1971	2.2445
18	2.516	2.7538	2.6783	2.3743	2.6783	2.2148	2.2634
19	2.8881	3.0933	2.9235	2.5337	2.7349	2.6932	2.5463
20	3.0121	3.2253	3.0744	2.8527	3.3196	2.9944	3.0933
21	3.1893	3.1876		3.2602	3.3762	3.1007	3.0367
22	3.2956	3.4517	3.3762	3.3488	3.6214	3.3665	3.2253
23	3.3665	3.6214	3.6025	3.4551	3.9043	3.9232	3.2442
24	3.7912	3.3311	3.5648	3.5648	3.4551	3.7723	3.7534
Max	3.7912	3.6214	3.6025	3.5648	3.9043	3.9232	3.7534
Min	2.1262	1.905	2.32	2.1971	2.2068	1.9845	.9431
Avg	2.6925	2.6321	2.7505	2.6606	2.7604	2.6562	2.6972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 208 / 11 KV O/G SPARE-8

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0532	.0754	.0754	.0709	.0754	
2	.0754	.0532	.0566	.0754	.0709	.0566	
3	.0566	.0532	.0754	.0754	.0709	.0754	
4	.0754	.0532	.0754	.0754	.0709	.0754	
5	.0566	.0532	.0754	.0754	.0709	.0754	
6	.0754	.0532	.0758	.0754	.0709	.0754	
7	.0754	.0754	.0754	.0754	.0709	.0566	
8	.0754	.0566	.0754	.0948	.0709	.0566	.0566
9	.0709	.0566	.0754	.0886	.0754	.0532	
10	.1417	.1698	.1698	.124	.0754	.1417	.1509
11	.1417	.1509	.1509	.124	.132	.1417	.1509
12	.1417	.1509	.1698	.124		.124	.1509
13	.1417	.1509	.0943	.124	.0754	.124	.1509
14	.1417	.1509	.1509	.124	.0754	.124	.1509
15	.1417	.1509	.1509	.1417	.1509	.124	.1509
16	.1417	.1509	.1509	.1417	.1509	.1417	.1509
17	.1417	.1698	.1509	.1417	.1509	.1417	.1509
18	.1417	.1698	.1698	.1595	.1509	.1417	.1509
19	.1595	.1509	.0754	.1595	.1698	.1417	.1509
20	.1595	.1698	.1698	.1595	.1698	.1595	.1509
21	.1595	.1698		.1595	.1509	.1595	.1509
22	.1595	.1698	.1509	.1595	.1698	.1595	.0566
23	.0532	.0754	.1509	.0709	.0754	.0566	.0566
24	.0754		.0754	.0754	.0709	.0754	.0566
Max	.1595	.1698	.1698	.1595	.1698	.1595	.1509
Min	.0532	.0532	.0566	.0709	.0709	.0532	.0566
Avg	.1116	.1156	.1148	.1125	.1048	.1065	.1273

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 211 / BHAGWATI HEIGHTS

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5466	1.6655	1.5844	1.6221	1.5415	1.6787	1.5089
2	1.4901	1.5238	1.6221	1.6032	1.4175	1.4712	1.4146
3	1.3203	1.3998	1.4901	1.4335	1.2757	1.226	1.3203
4	1.2826	1.2757	1.358	1.358	1.1871	1.2071	1.2826
5	1.226	1.134	1.2071	1.2071	1.134	1.1694	1.2637
6	1.1317	1.0277	1.094	1.1506	1.0985	1.1883	1.2449
7	1.1506	1.094	1.1128	1.1128	1.0985	1.1694	1.226
8	1.1506	1.1128	1.094	1.0562	1.3112	1.1128	1.226
9	1.0808	1.0751	1.1883	1.0631	1.1883	1.0985	1.2071
10	1.0808	1.1128	1.1506	1.0631	1.1506	1.0985	1.1883
11	1.0985	1.1506	1.2449	1.1871	1.1694	1.0631	1.1694
12	1.0985	1.2449	1.2637	1.2757		1.134	1.1694
13	1.134	1.1317	1.3203	1.258	1.1883	1.134	1.094
14	1.2226	.9808	1.2071	1.2757	1.2071	1.134	1.0751
15	1.258	.9431	1.2826	1.2757	1.2826	1.134	1.0751
16	1.2934	.9242	1.3392	1.2757	1.2637	1.1517	1.0751
17	1.2934	1.094	1.3014	1.2757	1.2826	1.1871	1.1317
18	1.2757	1.3769	1.3014	1.2757	1.358	1.2403	1.2071
19	1.3643	1.4712	1.4335	1.3112	1.3957	1.4352	1.3203
20	1.6301	1.5466	1.5278	1.3998	1.6409	1.5592	1.4146
21	1.6301	1.5466		1.5947	1.6409	1.5947	1.358
22	1.5947	1.6787	1.6032	1.6478	1.6787	1.6832	1.4523
23	1.701	1.7918	1.7541	1.6655	1.9239	1.8861	1.4146
24	1.8296	1.949	1.6787	1.6787	1.6478	1.8296	1.6975
Max	1.8296	1.949	1.7541	1.6787	1.9239	1.8861	1.6975
Min	1.0808	.9242	1.094	1.0562	1.0985	1.0631	1.0751
Avg	1.3285	1.3021	1.3548	1.3361	1.3514	1.3161	1.2724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 212 / SHIVSENA OFFICE

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.905	1.5238	1.6221	1.6221	1.701	1.8861	2.0748
2	1.773	1.3998	1.4901	1.4901	1.5947	1.5089	1.8861
3	1.4712	1.3112	1.3957	1.3957	1.4529	1.358	1.6975
4	1.358	1.2757	1.358	1.358	1.3466	1.3014	1.5089
5	1.358	1.2403	1.3203	1.3203	1.3112	1.3203	1.4146
6	1.3014	1.2226	1.3014	1.3014	1.258	1.4146	1.4335
7	1.3203	1.1883	1.3392	1.226	1.258	1.2449	1.3957
8	1.3769	1.226	1.3392	1.358	1.3112	1.3769	1.3957
9	1.2757	1.1694	1.3203	1.2757	1.3203	1.2226	1.3769
10	1.2757	1.2449	1.3392	1.2757	1.3392	1.1694	1.358
11	1.2757	1.2826	1.3769	1.258	1.4335	1.2757	1.358
12	1.2757	1.3769	1.5089	1.2757		1.2757	1.2826
13	1.2757	1.226	1.4335	1.2757	1.2637	1.258	1.3769
14	1.2757	.9997	1.3769	1.2757	1.3769	1.258	1.3203
15	1.3466	.9619	1.4523	1.2757	1.4523	1.258	1.3203
16	1.2934	1.094	1.3957	1.2403	1.3014	1.2403	1.2637
17	1.1871	1.1317	1.2071	1.2226	1.2637	1.1871	1.2071
18	1.1517	1.2449	1.226	1.1517	1.2449	1.134	1.1883
19	1.1694	1.3203	1.3392	1.1871	1.226	1.2934	1.2826
20	1.4883	1.3957	1.4146	1.4529	1.5844	1.382	1.4146
21	.6379	1.5278		1.6301	1.6787	1.5769	1.4335
22	1.6655	1.7164	1.6975	1.6478	1.8484	1.7187	1.5278
23	1.8604	1.9239	1.9239	1.8781	2.1125	2.1502	1.5655
24	2.1125	1.701	1.9239	1.905	1.949	2.1313	2.0748
Max	2.1125	1.9239	1.9239	1.905	2.1125	2.1502	2.0748
Min	.6379	.9619	1.2071	1.1517	1.226	1.134	1.1883
Avg	1.3930	1.3210	1.4392	1.3875	1.4621	1.4143	1.4649

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 302 / 22 KV Venkatesh Feeder Urban/Sheddable Urban Feeder
Feeder KV- 22 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2634	2.1262	2.2634	2.2634	2.1262	2.2257	2.1879
2	2.037	2.1262	2.037	2.037	2.0553	1.8484	1.9993
3	1.8107	1.9136	1.8107	1.8107	1.9845	1.8107	1.8861
4	1.6975	1.7364	1.6975	1.6975	1.8427	1.6975	1.8107
5	1.7353	1.5238	1.7353	1.7353	1.5947	1.6598	1.773
6	1.6598	1.5238	1.6598	1.6598	1.4883	1.7353	1.7353
7	1.6975	1.6221	1.6598	1.5844	1.5592	1.6221	1.7353
8	1.6975	1.6221	1.7353	1.773	1.5947	1.6975	1.7353
9	1.5947	1.5844	1.7353	1.6655	1.7353	1.5947	1.6975
10	1.6301	1.6221	1.773	1.6301	1.6975	1.5947	1.6975
11	1.5592	1.6975	1.8107	1.6301	1.6975		1.6975
12	1.5947	1.6598	1.8107	1.6301			1.6598
13	1.5947	1.5844	1.7353	1.5947	1.6975	1.8073	1.6975
14	1.6301	1.5089	1.7353	1.6655	1.7353	1.6655	1.6975
15	1.5947	1.4712	1.7353	1.6301	1.6975	1.6655	1.6598
16	1.5592	1.4712	1.6975	1.5592	1.6598	1.4883	1.6598
17	1.4883	1.4335	1.5466	1.5592	1.6598	1.4883	1.5844
18	1.4883	1.6598	1.6221	1.4529	1.6598	1.4175	1.5089
19	1.7718	1.8861	1.9239	1.5592	1.7353	1.6655	1.7353
20	2.1971	2.037	2.0748	1.8781	2.037	1.8781	1.9993
21	2.3034	2.1125		1.9845	2.2634	2.0199	2.037
22	2.268	2.1502	2.2257	2.268	2.2634	2.0908	2.037
23	2.1971	2.2634	2.2634	2.2325	2.4897	2.5274	2.0748
24	2.4897	2.268	2.3011	2.3011	2.2325	2.452	2.452
Max	2.4897	2.268	2.3011	2.3011	2.4897	2.5274	2.452
Min	1.4883	1.4335	1.5466	1.4529	1.4883	1.4175	1.5089
Avg	1.8150	1.7752	1.8517	1.7834	1.8481	1.8024	1.8233

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 303 / 22 KV JAWAHAR

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9239	2.1971	1.9239	1.9239	1.7718	1.8861	1.358
2	1.8861	1.8427	1.8861	1.8861	1.6655	1.8107	1.2449
3	1.8107	1.8427	1.8107	1.8107	1.6655	1.6975	1.1317
4	1.8484	1.7718	1.8484	1.7353	1.6301	1.6975	1.2071
5	1.8107	1.6655	1.8107	1.8107	1.6301	1.6975	1.358
6	1.8484	1.5592	1.8484	1.9616	1.5947	1.6975	1.5089
7	1.8484	1.8107	1.358	1.9616	1.6655	1.8107	1.7353
8	1.8484	1.773	1.8861	1.8484	1.7718	1.5844	1.8484
9	2.1971	2.7538	3.0933	1.7718	3.131	1.6655	2.1879
10	3.4019	3.2065	3.0933	1.8427	3.2819	1.949	2.9424
11	3.4728	3.4328	3.2065	2.6932	3.7723	1.8427	3.546
12	3.5437	3.5837	3.3573	2.6932		1.8781	3.6591
13	3.5437	3.3951	2.7915	2.6932	3.1687	1.8781	2.9047
14	3.4019	3.4705	3.0556	2.6932	3.0556	2.0908	3.0178
15	3.2602	3.5082	3.2819	2.6932	3.2819	2.1262	3.3951
16	3.1893	3.4705	3.131	2.6578	3.5837	2.0553	3.3951
17	3.083	3.3196	3.2065	2.5514	3.3951	1.949	3.0178
18	2.3388	2.7915	2.6783	2.3034	3.3573	1.4883	2.5652
19	2.3034	2.4143	2.3765	2.1262	2.3765	1.4529	2.3765
20	1.2963	2.1879	2.2257	1.8427	1.9993	1.3112	2.1879
21	1.8073	2.1125		1.8427	2.1502	1.3112	1.8861
22	1.8427	1.9239	2.1125	1.9136	1.9239	1.2757	2.0748
23	1.8781	2.0748	2.1125	1.701	2.0748	1.4712	1.9616
24	2.0748		1.9993	2.037		1.9616	1.3957
Max	3.5437	3.5837	3.3573	2.6932	3.7723	2.1262	3.6591
Min	1.2963	1.5592	1.358	1.701	1.5947	1.2757	1.1317
Avg	2.3942	2.5264	2.4389	2.1248	2.4521	1.7329	2.2461

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224001 / 33/11 KV Sec-27 Kharghar S/S

Feeder No / Name : 201 / 11 kv pl no.39, sec-27 Urban/Sheddable Urban Feeder
feeder Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	.0018
Max	.0018
Min	.0018
Avg	.0018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224001 / 33/11 KV Sec-27 Kharghar S/S

Feeder No / Name : 207 / 11 kv Juhi developers Urban/Sheddable Urban Feeder
feeder Feeder KV- 11 /
OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	.0017
Max	.0017
Min	.0017
Avg	.0017

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224001 / 33/11 KV Sec-27 Kharghar S/S

Feeder No / Name : 208 / 11KV Station Transformer Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	.0017
Max	.0017
Min	.0017
Avg	.0017

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224001 / 33/11 KV Sec-27 Kharghar S/S

Feeder No / Name : 212 / 11 kv Ramsheth thakur Urban/Sheddable Urban Feeder
feeder Feeder KV- 11 /
OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	.0018
Max	.0018
Min	.0018
Avg	.0018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224001 / 33/11 KV Sec-27 Kharghar S/S

Feeder No / Name : 402 / 33KV Incomer No-II Urban/Sheddable Urban Feeder
Feeder KV- 33 / INCOMING

DATE	01-JUN-17
HR	Load (MW)
24	.0154
Max	.0154
Min	.0154
Avg	.0154

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224002 / Sector-29, 33-33KV Swithing

St

Feeder No / Name : 403 / 33KV Incomer No-III

Urban/Sheddable Urban Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17
HR	Load (MW)
24	.0219
Max	.0219
Min	.0219
Avg	.0219

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224002 / Sector-29, 33-33KV Swithing

St

Feeder No / Name : 404 / 33 kv outgoing sec-27

Urban/Sheddable Urban Feeder

feeder Feeder KV- 33 /

INCOMING

DATE	01-JUN-17
HR	Load (MW)
24	.0055
Max	.0055
Min	.0055
Avg	.0055

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224002 / Sector-29, 33-33KV Swithing
StFeeder No / Name : 406 / 33 kv tata feeder no-1
Feeder KV- 33 / OUTGOING

HV Express Feeder

DATE	01-JUN-17
HR	Load (MW)
24	.011
Max	.011
Min	.011
Avg	.011

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224002 / Sector-29, 33-33KV Swithing
StFeeder No / Name : 407 / 33 kv Tata Feeder
Feeder KV- 33 / OUTGOING

HV Express Feeder

DATE	01-JUN-17
HR	Load (MW)
24	.011
Max	.011
Min	.011
Avg	.011

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224002 / Sector-29, 33-33KV Swithing

St

Feeder No / Name : 409 / 33 kv outgoing sec-35I Urban/Sheddable Urban Feeder
feeder Feeder KV- 33 / INCOMING

DATE	01-JUN-17
HR	Load (MW)
24	.0603
Max	.0603
Min	.0603
Avg	.0603

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224008 / 33 /11 KV KHARGHAR SEC-12

S/ST

Feeder No / Name : 207 / 11 KV MILLANIUM PARK

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.4728	3.3421			3.5475		
2	3.1181					2.8006	
3					2.8193		
4						2.2405	
5					2.0538		
6						2.4086	
7					2.1472		
9				2.1285	2.2177	2.2177	2.2177
10			2.4086	2.2177	2.3655	2.4209	2.2916
11			2.6326	2.4209	2.4394	2.4209	2.2916
12			2.6699	2.4209	2.5318	2.5318	
13			2.5953	2.4025	2.4764	2.4394	
14			2.5953	2.4579	2.5318	2.5133	
15			2.9313	2.5318	2.6797	2.6242	
16			2.894	2.5318	2.7166	2.5133	
17				2.4949	2.6797	2.4764	
18		2.4832		2.7351	2.4209	2.4209	
19				2.7721	2.5873	2.5133	
20				2.8304	2.8275	2.8275	
21				3.0308	2.9569	2.9938	
22				3.1602	3.3265		
23				3.5667	3.807	3.8624	
24	3.8836				3.9548	3.8462	3.807
Max	3.8836	3.3421	2.9313	3.5667	3.9548	3.8624	3.807
Min	3.1181	2.4832	2.4086	2.1285	2.0538	2.2177	2.2177
Avg	3.4915	2.9127	2.6753	2.6468	2.7544	2.6707	2.6520

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224008 / 33 /11 KV KHARGHAR SEC-12

S/ST

Feeder No / Name : 208 / SUB STATION T/F

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0131			.0236
3				.0236
5				.0229
9			.0131	
10		.0131	.0131	
11		.0131		
12		.0131		
13		.0131		
14		.0131		
15		.0131		
16		.0131		
24	.0236			
Max	.0236	.0131	.0131	.0236
Min	.0131	.0131	.0131	.0229
Avg	.0184	.0131	.0131	.0234

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 201 / Spare Link feeder

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4006	1.5432		2.2291		2.4006	2.572
2			1.8861		2.2291		2.2291
3	2.0576	1.3717		1.8861		2.0576	1.8004
4			1.7147		1.6289		1.5432
5	1.7147	1.3717		1.5432		1.7147	1.3717
6			1.7147		1.7147		1.286
7	1.3717	1.5432		1.3717		1.3717	1.5432
8			1.5432		1.5432		1.3717
9	1.3717	1.5432		1.3717		1.3717	
10			1.7147		1.5432		1.3717
11	1.5432	1.5432		1.5432		1.3717	
12			1.7147		1.5432		1.5432
13	1.5432	1.7147		1.7147		1.5432	
14			1.3717		1.7147		1.5432
15	1.7147	1.5432		1.7147	1.7147	1.6289	
16			1.0288				
17	1.4575	1.5432		1.8861		1.7147	1.5432
18			1.0288		1.3717		1.3717
19	1.5432	1.7147		1.7147		1.5432	1.5432
20			1.8861		1.7147		1.8004
21	2.0576	2.0576		2.0576		***	
22			2.0576		2.2291		
23	2.4006	2.4006		2.4006		2.7435	1.8861
24	2.7435	2.572	2.4006	2.4006	2.7435	2.7435	2.7435
Max	2.7435	2.572	2.4006	2.4006	2.7435	20.6962	2.7435
Min	1.3717	1.3717	1.0288	1.3717	1.3717	1.3717	1.286
Avg	1.8400	1.7279	1.6718	1.8334	1.8076	3.3001	1.7096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 203 / 11 KV MURBI SECTOR-19

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	1.5432		1.3717		1.5432	1.5432
2			1.286		1.286		1.2003
3	1.5432	1.1145		1.2003		1.3717	1.0288
4			1.0288		.8573		1.0288
5	1.2003	.8573		1.0288		1.0288	1.0288
6			1.2003		1.0288		1.0288
7	1.0288	1.0288		1.0288		1.0288	1.2003
8			1.0288		1.0288		1.0288
9	.9431	1.0288		.9431		1.0288	
10			1.0288		1.0288		1.0288
11	1.0288	1.0288		1.0288		1.0288	
12			1.0288		1.0288		1.0288
13	1.2003	1.2003		1.0288		1.0288	
14			1.2003		1.2003		1.0288
15	1.3717	1.1145		1.0288	1.2003	1.1145	
16			1.2003				.8916
17	1.0288	1.0288		1.2003		1.2003	.9602
18			1.0288		1.0288		.9602
19	1.0288	1.0288		1.0288		1.0288	.9602
20			1.0288		1.0288		.9602
21	1.2003	1.2003		1.2003		1.2003	
22			1.2003		1.3717		
23	1.5432	1.5432		1.5432		1.7147	1.2346
24	1.7147	1.7147	1.7147	1.5432	1.7147	1.7147	1.7147
Max	1.7147	1.7147	1.7147	1.5432	1.7147	1.7147	1.7147
Min	.9431	.8573	1.0288	.9431	.8573	1.0288	.8916
Avg	1.2728	1.1871	1.1646	1.1673	1.1503	1.2332	1.1031

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 204 / 11 KV VIGNHAR SECTOR-12 Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6578	2.4006		2.572		2.572	2.7435
2			2.0576		2.4006		2.4006
3	2.4006	1.7147		2.0576		2.3148	1.9719
4			1.8004		1.8861		1.7147
5	1.9719	1.6289		1.7147		2.0576	1.7147
6			2.0576		2.0576		1.7147
7	1.8861	1.8861		1.7147		2.0576	2.0576
8			1.8861		1.8861		1.8861
9	1.8004	1.8861		1.8861		1.9719	
10			2.0576		2.0576		2.0576
11	2.3148	2.1434		2.1434		2.2291	
12			2.4006		2.2291		2.2291
13	2.2291	2.3148		2.2291		2.3148	
14			2.2291		2.2291		2.1434
15	2.4006	2.1948		2.2291	2.2291	2.2291	
16			2.3148				1.8861
17	2.572	2.0576		2.3148		2.2291	2.1434
18			2.2291		2.1434		2.0576
19	2.4006	2.4006		2.3148		2.2291	2.2291
20			2.6578		2.7435		2.4006
21	2.8292	2.6578		2.6578		2.8292	
22			2.6578		2.915		
23	2.8292	2.7435		2.915		3.0007	2.3148
24	2.915	2.7435	2.8292	2.8292	3.0007	2.915	3.0007
Max	2.915	2.7435	2.8292	2.915	3.0007	3.0007	3.0007
Min	1.8004	1.6289	1.8004	1.7147	1.8861	1.9719	1.7147
Avg	2.4006	2.2133	2.2648	2.2753	2.3148	2.3808	2.1481

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 205 / SUB STATION T/F

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	03-JUN-17
HR	Load (MW)
8	1.8861
Max	1.8861
Min	1.8861
Avg	1.8861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 206 / 11 KV AWHO SECTOR-14

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7435	2.6578		2.572		2.7435	2.7435
2					2.4006		2.3148
3	2.4006	1.8004		2.4006		2.2291	1.8004
4			1.8861		1.7147		1.4575
5	1.6289	1.3717		1.7147		1.7147	1.3717
6			.6001		1.7147		1.3717
7	1.3717	1.5432		1.3717		1.7147	1.5432
8			1.4623		1.5432		1.3717
9	1.5432	1.5432		1.5432		1.7147	
10			1.5432		1.5432		1.6289
11	1.7147	1.6289		1.8004		1.7147	
12			1.7147		1.7147		1.7147
13	1.8861	1.7147		1.7147		1.7147	
14			1.8861		1.8861		1.6804
15	1.8861	1.7147		2.0576	1.8861	1.8004	
16			2.0576				1.8004
17	1.9719	1.6289		2.0576		1.8861	1.7147
18			1.8861		1.7147		1.6975
19	1.8861	1.8861		1.8861		1.8004	1.7147
20			2.0576		2.0576		2.0576
21	2.3148	2.2291		2.2291		2.3148	
22			2.4006		2.572		
23	2.7435	2.915				3.0864	2.2291
24	2.915	2.915	2.915	2.8292	3.0007	3.0007	2.915
Max	2.915	2.915	2.915	2.8292	3.0007	3.0864	2.915
Min	1.3717	1.3717	.6001	1.3717	1.5432	1.7147	1.3717
Avg	2.0774	1.9653	1.8554	2.0147	1.9790	2.1104	1.8404

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 207 / VISHWAJYOTH

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	1.9719		1.7147		2.0576	2.0576
2			.4287		1.7147		1.7147
3	1.7147	1.286		1.5432		1.7147	1.3717
4			1.3717		1.3717		1.2003
5	1.2003	1.0288		1.2003		1.3717	1.2003
6			1.6289		1.286		1.2003
7	1.2003	1.2003		1.2003		1.2003	1.3717
8			1.1145		1.2003		1.2003
9	1.1145	1.2003		1.0288		1.1145	
10			.9431		1.2003		1.0288
11	1.286	1.2003		1.286		1.2003	
12			.8573		1.286		1.2003
13	1.3717	1.3717		1.286		1.286	
14			1.0288		1.3717		1.3375
15	1.3717	1.2003		1.4575	1.4575	1.286	
16			1.4575				1.286
17	1.286	1.0288		1.3717		1.3717	1.2003
18			1.2003		1.2003		1.2003
19	1.2003	1.2003		1.286		1.286	1.0288
20			1.286		1.2003		1.286
21	1.4575	1.4575		1.3717		1.4575	
22			1.5432		1.6289		
23	1.9719	1.9719				2.2291	1.5432
24	2.2291	2.1434	2.0576	1.8861	2.2291	2.1434	2.2291
Max	2.2291	2.1434	2.0576	1.8861	2.2291	2.2291	2.2291
Min	1.1145	1.0288	.4287	1.0288	1.2003	1.1145	1.0288
Avg	1.4970	1.4047	1.2431	1.3860	1.4289	1.5168	1.3698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 208 / 11 KV JALVAYU SECTOR-20 Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	2.3148		1.2003		2.572	2.572
2			2.0576		2.1434		2.1434
3	1.0288	1.7147		.8573		2.0576	1.7147
4			1.5432		1.6289		1.4575
5	.8573	1.5432		.7716		1.7147	1.3717
6			1.7147		1.7147		1.3717
7	.8573	1.7147		.7716		1.5432	1.5432
8			1.5432		1.5432		1.5432
9	.7716	1.5432		.6859		1.3717	
10			1.2003		1.5432		1.5432
11	.7716	1.6289		.8573		1.4575	
12			.8573		1.5432		1.5432
13	.8573	1.7147		.8573		1.5432	
14			.8573		1.7147		1.5432
15	.8573	1.7147		1.7147	1.7147	1.5432	
16			.9431				1.5432
17	.8573	1.5432		1.8861		1.3717	1.5432
18			1.2003		1.5432		1.5432
19		1.7147		1.7147		1.7147	1.7147
20			1.0288		1.7147		1.7147
21	2.0576	2.0576		2.0576		2.0576	
22			1.0288		2.2291		
23	2.572	2.572				2.915	2.0576
24	1.3717	2.572	2.7435	1.2003	2.915	2.7435	2.7435
Max	2.572	2.572	2.7435	2.0576	2.915	2.915	2.7435
Min	.7716	1.5432	.8573	.6859	1.5432	1.3717	1.3717
Avg	1.1717	1.8730	1.3932	1.2146	1.829	1.8927	1.7337

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 209 / 11 kV \sector 18

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	1.5432		1.3717		1.7147	1.5432
2			1.286		1.3717		1.286
3	1.3717	1.0288		1.2003		1.3717	1.0288
4			.8573		1.1145		.7716
5	1.2003	.8573		.8573		1.2003	.7716
6			1.0288		1.1145		.8573
7	1.0288	1.0288		.8573		1.0288	1.0288
8			.9431		1.0288		.9431
9	.9431	1.0288		.8573		1.0288	
10			.8573		1.0288		.9431
11	.9431	.9431		.8573		1.0288	
12			.8573		.9431		.9431
13	1.0288	1.0288		.9431		.9431	
14			1.0288		.9431		1.0117
15	1.0288	.8573		1.0288	1.0288	1.0288	
16							.9431
17	1.0288	.7716		1.0288		1.0288	.9431
18			.9431		.8573		.8573
19	.8573	.9431		.9431		.8573	.8573
20			.9431		1.0288		.9431
21	1.1145	1.2003				1.2003	
22			1.2003		1.3717		
23	1.6289	1.7147				1.8004	1.2003
24	1.8861	1.7147	1.7147	1.5432	1.8004	1.8861	1.7147
Max	1.8861	1.7147	1.7147	1.5432	1.8004	1.8861	1.7147
Min	.8573	.7716	.8573	.8573	.8573	.8573	.7716
Avg	1.2135	1.1277	1.0600	1.0444	1.1360	1.2398	1.0326

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 210 / 11 kV \ Vastuvihar

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.4287		.5144		.5144	.4287
2			.3429		.2572		.3429
3	.4287	.3429		.4287		.4287	.2572
4			.3429		.2572		.2572
5	.4287	.3429		.3429		.3429	.2572
6			.4287		.3429		.2572
7	.3429	.4287		.3429		.3429	.3429
8			.3429		.3429		.3429
9	.1715	.3429		.1715		.1715	
10			.2572		.3429		.3429
11		.3429		.3429		.2572	
12			.1715		.3429		.2572
13	.1715	.3429		.3429		.3429	
14			.1715		.3429		.1715
15	.3429	.3429		.3429	.3429	.3429	
16			.3429				.2743
17	.3429	.3429		.3429		.3429	.2743
18			.5144		.3429		.2743
19	.3429	.3429		.3429		.3429	.2401
20			.3429		.3429		.3086
21	.4287	.4287				.9431	
22			.4287		.4287		
23	.6859	.5144				.5144	
24	.5144	.5144	.5144	.5144	.5144	.5144	.6001
Max	.6859	.5144	.5144	.5144	.5144	.9431	.6001
Min	.1715	.3429	.1715	.1715	.2572	.1715	.1715
Avg	.3930	.3891	.3501	.3663	.3501	.4155	.3076

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 211 / 11 kV Sector 27

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715		.1715		.1715	.1715
2					.1715		.1715
3	.1715	.1715		.1715		.1715	.1715
4					.1715		.1715
5	.1715	.1715		.1715		.1715	.1715
6					.1715		.1715
7	.1715	.1715		.1715		.1715	.2572
8					.1715		.2572
9	.1715	.1715		.1715		.1715	
10			.1715		.2572		.1715
11		.1715		.1715		.1715	
12			.1715		.2572		.1715
13	.1715	.1715		.1715		.1715	
14			.1715		.1715		.1715
15	.1715	.1715		.1715	.1715	.1715	
16			.1715				.1543
17	.1715	.1715		.1715		.1715	.1029
18			.1715		.1715		.1543
19	.1715	.1715		.1715		.1715	.1543
20			.1715		.1715		.2058
21	.2572	.1715				.1715	
22			.1715		.1715		
23	.2572	.1715				.2572	.2572
24	.1715	.1715		.1715	.2572	.1715	.1715
Max	.2572	.1715	.1715	.1715	.2572	.2572	.2572
Min	.1715	.1715	.1715	.1715	.1715	.1715	.1029
Avg	.1858	.1715	.1715	.1715	.1929	.1781	.1810

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 212 / Sector-30 Owe village

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.6001		.5144		.5144
2					.1715	
3	.4287	.4287		.4287		.3429
4					.1715	
5	.3429	.4287		.2572		.3429
6					.2572	
7	.1715	.3429		.1715		.2572
8					.2572	
9	.2572	.4287		.1715		.4287
10			.3429		.2572	
11	.5144	.6001		.3429		.5144
12			.4287		.4287	
13	.5144	.6859		.3429		.5144
14			.5144		.5144	
15	.6001	.4287		.4287	.5144	.5144
16			.4287			
17	.6001	.4287		.4287		.5144
18			.5144		6.1557	
19	.5144	.6001		.3429		.5144
20			.3429		.4287	
21	.5144	.5144				.3429
22			.5144		.5144	
23	.6001	.4287				.4287
24	.6001	.6859		.5144	.4287	.5144
Max	.6001	.6859	.5144	.5144	6.1557	.5144
Min	.1715	.3429	.3429	.1715	.1715	.2572
Avg	.4748	.5078	.4409	.3585	.8416	.4419

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 201 / 11 kv CIDCO Sewrage Pump Urban/Sheddable Urban Feeder
Secto Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2405				2.2405		
2	2.0538		2.0725		2.0538		
3	1.8671				1.8671		
4	1.6804		1.8671		1.7177		
5	1.6804				1.643		
6	1.6804		1.6804		1.6057		
7			1.475				
8	2.2965	1.587	1.5123		1.587		
11	2.3712	2.2592	2.4459		2.7446		
12			2.3899				
13		2.6699	2.6886				
14		2.6886	2.7446				
15	3.0247	2.9687	2.5393				
16		2.8006		2.2405	2.4832		
17		2.1658		1.8858	2.4832		
18		2.3712		2.2218		2.2592	
19		2.4832		2.4646		2.0911	
20		2.3899		2.4832	2.4832		
21		2.3152		2.4832		2.4832	
22		2.2405		2.2218	2.3712	2.4086	
23				2.2965			
24	2.3712		2.3712		2.3339	2.6139	2.6139
Max	3.0247	2.9687	2.7446	2.4832	2.7446	2.6139	2.6139
Min	1.6804	1.587	1.475	1.8858	1.587	2.0911	2.6139
Avg	2.1266	2.4117	2.1624	2.2872	2.1242	2.3712	2.6139

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 202 / 11 KV CIDCO S/STN SEC-10 Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0829				1.1203		
2	1.0082		.9709		1.0829		
3	.9335				1.0082		
4	.8775		.8589		.9335		
5	.8215				.8775		
6	.7842		.7842		.8589		
7			.7842				
8	.6722		.6908		.6908		
11	.5975	.6535	.6722		.5975		
12			.7095				
13		.6908	.6908				
14		.7282	.7095				
15	.7655	.7842	.8215				
16		.7468		.7468	.6908		
17		.6908		.7842	.6535		
18		.7655		.6908		.6722	
19		.7095		.7655		.6722	
20		.7842		.8589	.7655		
21		.8962		.8775		.8775	
22		.9709		.9896	.9709	1.0642	
23				1.1576			
24	1.1389		1.0456		1.1949	1.307	1.2323
Max	1.1389	.9709	1.0456	1.1576	1.1949	1.307	1.2323
Min	.5975	.6535	.6722	.6908	.5975	.6722	1.2323
Avg	.8682	.7655	.7944	.8589	.8804	.9186	1.2323

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 203 / 11KV CIDCO Sec-2 Kharghar Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5684				1.587		
2	1.4937		1.6804		1.4563		
3	1.4003				1.3443		
4	1.307		.9709		1.1203		
5	1.1203				.9709		
6	.8962		.8402		.8962		
7			.8215				
8		.8962	.8775		.8962		
11	.8589	1.8298	1.9231		1.6991		
12			2.0725				
13		1.9978	2.0351				
14		1.9791	1.9978				
15	2.2405	2.0725	2.2405				
16		1.9791		1.8671	1.9044		
17		1.8858		1.8484	1.7551		
18		1.8671		1.7551		1.8111	
19		1.6804		1.6991		1.8484	
20		1.9418		1.8671	1.9418		
21		1.8298		1.9418		1.8858	
22		1.6617			1.7177	1.7177	
23				1.6804			
24	1.6617		1.7737		1.7177	1.7924	1.8484
Max	2.2405	2.0725	2.2405	1.9418	1.9418	1.8858	1.8484
Min	.8589	.8962	.8215	1.6804	.8962	1.7177	1.8484
Avg	1.3941	1.8018	1.5667	1.8084	1.4621	1.8111	1.8484

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 204 / 11 KV Prajapati S/stn Sec- Urban/Sheddable Urban Feeder
2 kh Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0807				3.1741		
2	2.8006		2.9874		2.9874		
3	2.5766				2.8006		
4	2.4272		2.4272		2.6139		
5	2.2405						
6	2.2592		2.1472		2.1845		
7			2.3339				
8	2.2965	2.5019	2.4459		2.7073		
11	2.6699	2.6886	2.4646		2.6513		
12			2.5766				
13		2.9687	2.8753				
14		2.5019	2.6886				
15	2.9687	3.0994	3.2301				
16		2.7633		2.894	2.5579		
17		2.2592		3.062	2.4832		
18		2.6513		2.9127		2.5019	
19		2.95		2.838		2.8193	
20		2.894		2.838	2.8006		
21		2.9874		2.838		2.7446	
22		3.0994		3.1181	3.0247	3.062	
23				3.2301			
24	3.2487		3.3981		3.2674	3.5101	3.5475
Max	3.2487	3.0994	3.3981	3.2301	3.2674	3.5101	3.5475
Min	2.2405	2.2592	2.1472	2.838	2.1845	2.5019	3.5475
Avg	2.6569	2.7804	2.6886	2.9664	2.7711	2.9276	3.5475

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 205 / 11 KV Railway station Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867				.1867		
2	.1494		.1494		.1494		
3	.112						
4	.0934		.0934		.0934		
5	.0934				.0934		
6	.1494		.1307		.1494		
7			.112				
8	.112	.0934	.0934		.0934		
11	.1494	.1494	.1307		.1307		
12			.1867				
13		.1494	.1867				
14		.168	.1494				
15	.168	.168	.1494				
16		.1494		.1494	.1307		
17		.1307			.1307		
18		.1494		.112		.1307	
19		.2427		.1867		.1867	
20		.2427		.2241	.2241		
21		.2427		.2614		.2241	
22		.2427			.2427	.2054	
23				.2241			
24	.2054		.2241		.2241	.2241	.2054
Max	.2054	.2427	.2241	.2614	.2427	.2241	.2054
Min	.0934	.0934	.0934	.112	.0934	.1307	.2054
Avg	.1419	.1774	.1460	.1930	.1541	.1942	.2054

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 206 / SUB STATION T/F Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187				.0187		
2	.0187		.0187		.0187		
3	.0187				.0187		
4	.0187		.0187		.0187		
5	.0187				.0187		
6	.0187		.0187		.0187		
7			.0187				
8							.0187
15	.0168						
16		.0187		.0187			
17		.0187		.0187			
18		.0187		.0187			
19		.0187		.0187			
20		.0187		.0187			
21		.0187		.0187			
22		.0187		.0187			
23				.0187			
24	.0187		.0187		.0187	.0187	
Max	.0187	.0187	.0187	.0187	.0187	.0187	.0187
Min	.0168	.0187	.0187	.0187	.0187	.0187	.0187
Avg	.0185	.0187	.0187	.0187	.0187	.0187	.0187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 207 / 11 KV Glow Max

HV Non-Express Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747				.0747		
2	.0373		.0187		.0187		
3	.0373				.0187		
4	.0373		.0187		.0187		
5	.0373				.0187		
6	.0373		.0187		.0187		
7			.0187				
8	.0373	.0373	.0373		.0187		
11	.3921	.3547	.3361		.3174		
12			.3734				
13		.3547	.3547				
14		.3361					
15	.3174	.3361	.3734				
16		.3547		.3361	.3361		
17		.3547		.3174	.3174		
18		.3174		.2987		.3174	
19		.2987		.3174		.3174	
20		.2801		.3174	.2987		
21		.2801		.3174		.2987	
22		.2614		.2801	.2801	.2801	
23				.2614			
24	.2054		.1867		.2241	.2241	.2241
Max	.3921	.3547	.3734	.3361	.3361	.3174	.2241
Min	.0373	.0373	.0187	.2614	.0187	.2241	.2241
Avg	.1213	.2972	.1736	.3057	.1508	.2875	.2241

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 208 / 11 KV Balaji Angan Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8006				2.8006		
2	2.5206		2.6139		2.7073		
3	2.2405				2.6139		
4	2.0538		2.4272		2.4272		
5	1.4937				2.2405		
6	.9896		1.9418		1.9044		
7			1.8671				
8	1.9791	1.9791	1.9418				
11	2.838	2.8006	2.4272		1.9044		
12			2.4646				
13		2.6699	2.4646				
14		2.6513	2.3525				
15	2.9313	2.8006	2.6139				
16		2.6139		2.0538	2.6139		
17		2.2405		1.9791	2.3525		
18		2.0911		1.8298		2.0165	
19		2.2405		1.9791		2.1285	
20		2.4272		2.1472	2.1658		
21		2.5206		2.2779		2.3525	
22		2.6139		2.5393	2.6139	2.5019	
23				2.8753			
24	3.062		2.8006		2.9127	3.062	2.838
Max	3.062	2.8006	2.8006	2.8753	2.9127	3.062	2.838
Min	.9896	1.9791	1.8671	1.8298	1.9044	2.0165	2.838
Avg	2.2909	2.4708	2.3559	2.2102	2.4381	2.4123	2.838

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 209 / 11kV NIFT Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187				.0187		
2	.0187		.0187		.0187		
3	.0187				.0187		
4	.0187		.0187		.0187		
5	.0187				.0187		
6	.0187		.0187		.0187		
7			.0187				
16		.0187		.0187			
17		.0187		.0187			
18		.0187		.0187			
19		.0187		.0187			
20		.0187		.0187			
21		.0187		.0187			
22		.0187		.0187			
23				.0187			
24	.0187		.0187		.0187	.0187	.0187
Max	.0187	.0187	.0187	.0187	.0187	.0187	.0187
Min	.0187	.0187	.0187	.0187	.0187	.0187	.0187
Avg	.0187	.0187	.0187	.0187	.0187	.0187	.0187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 210 / 11kV outgoing feeder 10 Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.1741				3.1741		
2	2.9874		2.4646		2.9874		
3	2.8006				2.8006		
4	2.6139		2.2405		2.6139		
5	2.4272				2.2405		
6	2.3339		2.2032		2.1472		
7			1.9605				
8	1.9044	1.9418	1.9044		1.9231		
11	1.9791	1.9231	1.9978		1.7737		
12			1.7364				
13		2.0725	1.9044				
14		2.1098	1.9044				
15	2.2405	2.2779	2.2779				
16				2.2405	1.9978		
17				.0187	1.9044		
18				1.9978		1.8111	
19				2.1285		1.9978	
20				2.4272	2.2032		
21		2.4646		2.5953		2.4272	
22		2.6513		2.9313	2.838	2.8006	
23		2.2405		3.3234			
24	3.4541		2.7633		3.3608	3.4355	3.3981
Max	3.4541	2.6513	2.7633	3.3234	3.3608	3.4355	3.3981
Min	1.9044	1.9231	1.7364	.0187	1.7737	1.8111	3.3981
Avg	2.5915	2.2102	2.1234	2.2078	2.4588	2.4944	3.3981

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 211 / 11 KV S N Park

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1949				1.307		
2	1.1203		1.0829		1.1949		
3	1.0269				1.1203		
4	.9335		.9335		1.0456		
5	.8402				.9709		
6	.8962		.9149		.9335		
7			.8589				
8	.9709	1.0269	1.0456		1.0082		
11	1.0456	1.1203	1.1203		1.1949		
12			1.1016				
13		1.1203	1.0269				
14		1.1389	1.0642				
15	1.1949	1.2323	1.1016				
16		1.2136		.9709	1.1203		
17		.9522		.9522	1.0082		
18		1.0456		.7842		.9149	
19		.9522		.9335		.9522	
20		1.0082		1.0269	1.0642		
21		1.1203		1.1389		1.1389	
22		1.1576		1.1763	1.1203	1.2136	
23				1.3256			
24	1.2883		1.2323		1.363	1.3443	1.419
Max	1.2883	1.2323	1.2323	1.3256	1.363	1.3443	1.419
Min	.8402	.9522	.8589	.7842	.9335	.9149	1.419
Avg	1.0512	1.0907	1.0439	1.0386	1.1116	1.1128	1.419

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 213 / 11kV BPCL Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373				.0187		
2	.0373		.0373		.0187		
3	.0373				.0187		
4	.0373		.0373		.0187		
5	.0373				.0187		
6	.0373		.0747		.0187		
7			.0373				
8	.2801	.3174	.0747		.3174		
11	.3547	.3921	.168		.4481		
12			.1494				
13		.4108	.112				
14		.3921	.1307				
15	.3734	.3734	.0934				
16		.3734		.0187	.4108		
17		.3547		.0187	.3734		
18		.1494		.0187		.2801	
19		.0747		.0373		.112	
20		.056		.0373	.0747		
21		.0373		.0373		.056	
22		.0373		.0373	.0373	.0373	
23				.0373			
24	.0373		.0373		.0187	.0373	.0187
Max	.3734	.4108	.168	.0373	.4481	.2801	.0187
Min	.0373	.0373	.0373	.0187	.0187	.0373	.0187
Avg	.1269	.2474	.0866	.0303	.1379	.1045	.0187

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 201 / plot no 51 sec-30 feeder Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1			4.2181
24	4.4067	4.0124	
Max	4.4067	4.0124	4.2181
Min	4.4067	4.0124	4.2181
Avg	4.4067	4.0124	4.2181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 202 / mass housing s/s no-1 Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.12
24	.1029	.0857	
Max	.1029	.0857	.12
Min	.1029	.0857	.12
Avg	.1029	.0857	.12

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 203 / LIG MASS HOUSING Feder Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.2743
24	.2401	.2401	
Max	.2401	.2401	.2743
Min	.2401	.2401	.2743
Avg	.2401	.2401	.2743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 204 / sec-34A feeder prop. Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1			1.3375
24	1.3375	1.2346	
Max	1.3375	1.2346	1.3375
Min	1.3375	1.2346	1.3375
Avg	1.3375	1.2346	1.3375

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 205 / pl no.42 & 43, sec-35D Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.1886
24	.2058	.1715	
Max	.2058	.1715	.1886
Min	.2058	.1715	.1886
Avg	.2058	.1715	.1886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 207 / MASS HOUSING S/S NO.3 Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.0857
24	.12	.1029	
Max	.12	.1029	.0857
Min	.12	.1029	.0857
Avg	.12	.1029	.0857

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 210 / MASS HOUSING S/S NO.4 Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.1715
24	.1543	.1372	
Max	.1543	.1372	.1715
Min	.1543	.1372	.1715
Avg	.1543	.1372	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 211 / MASS HOUSING S/S NO.2 Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.0686
24	.0857	.0686	
Max	.0857	.0686	.0686
Min	.0857	.0686	.0686
Avg	.0857	.0686	.0686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 212 / arihant abhilasha pl no-10 Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1			2.2634
24	1.9547	1.9204	
Max	1.9547	1.9204	2.2634
Min	1.9547	1.9204	2.2634
Avg	1.9547	1.9204	2.2634

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 229019 / 400/33/22KV Kharghar S/Stn

Feeder No / Name : 402 / 33KV SECTOR-12 Urban/Sheddable Urban Feeder
Feeder KV- 33 / INCOMING

DATE	01-JUN-17
HR	Load (MW)
13	.0219
Max	.0219
Min	.0219
Avg	.0219

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 229019 / 400/33/22KV Kharghar S/Stn

Feeder No / Name : 403 / 33KV Sec-29 Urban/Sheddable Urban Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17
HR	Load (MW)
24	.0219
Max	.0219
Min	.0219
Avg	.0219

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 229019 / 400/33/22KV Kharghar S/Stn

Feeder No / Name : 404 / 33KV CBD - II

EHV Non-Express Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17
HR	Load (MW)
24	.0224
Max	.0224
Min	.0224
Avg	.0224

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 229019 / 400/33/22KV Kharghar S/Stn

Feeder No / Name : 405 / 33KV SECTOR-19 Urban/Sheddable Urban Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17
HR	Load (MW)
13	.0165
Max	.0165
Min	.0165
Avg	.0165

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 229019 / 400/33/22KV Kharghar S/Stn

Feeder No / Name : 408 / 33KV SECTOR-2 Urban/Sheddable Urban Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17
HR	Load (MW)
24	.036
Max	.036
Min	.036
Avg	.036

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 229019 / 400/33/22KV Kharghar S/Stn

Feeder No / Name : 409 / 33 KV INCOMER to KAMOTHE Urban/Sheddable Urban Feeder
SS Feeder KV- 33 / INCOMING

DATE	01-JUN-17
HR	Load (MW)
24	.0224
Max	.0224
Min	.0224
Avg	.0224

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 229019 / 400/33/22KV Kharghar S/Stn

Feeder No / Name : 410 / Sub Station Transformer- Urban/Sheddable Urban Feeder
No-1 Feeder KV- 33 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	.0051
Max	.0051
Min	.0051
Avg	.0051

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 229019 / 400/33/22KV Kharghar S/Stn

Feeder No / Name : 411 / SUB STATION TRANSFORMER-II Urban/Sheddable Urban Feeder
Feeder KV- 33 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	.0051
Max	.0051
Min	.0051
Avg	.0051

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 223034 / 22/11 KV Taloja Panchanand

Sub

Feeder No / Name : 201 / 11 kv sect-10 Taloja

Sheddable Rural/Mix Feeder

Panchanan Feeder KV- 11 /

OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	2.2291
Max	2.2291
Min	2.2291
Avg	2.2291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 223035 / 22/22 KV Nawada Switching

Stat

Feeder No / Name : 201 / 22 kv Ghot gav feeder

Sheddable Rural/Mix Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	4.1152
Max	4.1152
Min	4.1152
Avg	4.1152

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 226003 / 100/22 KV TALOJA S/STN

Feeder No / Name : 301 / AUX station transformer Urban/Sheddable Urban Feeder
Feeder KV- 22 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 226003 / 100/22 KV TALOJA S/STN

Feeder No / Name : 303 / 22kv Ghot gav incomer

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17
HR	Load (MW)
24	4.1152
Max	4.1152
Min	4.1152
Avg	4.1152

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 226003 / 100/22 KV TALOJA S/STN

Feeder No / Name : 304 / 22kv Feeder MIDC-1

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17
HR	Load (MW)
24	4.1152
Max	4.1152
Min	4.1152
Avg	4.1152

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 226003 / 100/22 KV TALOJA S/STN

Feeder No / Name : 305 / 22kv Feeder MIDC-2

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17
HR	Load (MW)
24	5.144
Max	5.144
Min	5.144
Avg	5.144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 226003 / 100/22 KV TALOJA S/STN

Feeder No / Name : 306 / 22kv Feeder MIDC-3

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17
HR	Load (MW)
24	4.2867
Max	4.2867
Min	4.2867
Avg	4.2867

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 226003 / 100/22 KV TALOJA S/STN

Feeder No / Name : 307 / 22kv Feedr MIDC-4
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17
HR	Load (MW)
24	5.144
Max	5.144
Min	5.144
Avg	5.144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 226003 / 100/22 KV TALOJA S/STN

Feeder No / Name : 308 / 22kv Feeder Panvel

Sheddable Rural/Mix Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	4.7325
Max	4.7325
Min	4.7325
Avg	4.7325

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 226003 / 100/22 KV TALOJA S/STN

Feeder No / Name : 310 / 22kv Feeder Wavanje

Sheddable Rural/Mix Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	6.1728
Max	6.1728
Min	6.1728
Avg	6.1728

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 226003 / 100/22 KV TALOJA S/STN

Feeder No / Name : 311 / 22kv Feeder Bel-1
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17
HR	Load (MW)
17	6.1728
Max	6.1728
Min	6.1728
Avg	6.1728

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 226003 / 100/22 KV TALOJA S/STN

Feeder No / Name : 312 / 22kv Feeder MIDC-5

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17
HR	Load (MW)
24	4.321
Max	4.321
Min	4.321
Avg	4.321

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 226003 / 100/22 KV TALOJA S/STN

Feeder No / Name : 313 / Dorf Kettle

HV Non-Express Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 226003 / 100/22 KV TALOJA S/STN

Feeder No / Name : 315 / 22KV Apcotex

HV Non-Express Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	1.0288
Max	1.0288
Min	1.0288
Avg	1.0288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 226003 / 100/22 KV TALOJA S/STN

Feeder No / Name : 316 / 22 KV KALAMBOLI U/G FEEDER Urban/Sheddable Urban Feeder
Feeder KV- 22 / INCOMING

DATE	01-JUN-17
HR	Load (MW)
24	5.8299
Max	5.8299
Min	5.8299
Avg	5.8299

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 226003 / 100/22 KV TALOJA S/STN

Feeder No / Name : 317 / Technova OLD Express

HV Non-Express Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 226003 / 100/22 KV TALOJA S/STN

Feeder No / Name : 318 / Hindustan Copper(HCL)

HV Non-Express Feeder

(Express Feeder KV- 22 /

OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 226003 / 100/22 KV TALOJA S/STN

Feeder No / Name : 319 / Kellogs(Express)

HV Non-Express Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 226003 / 100/22 KV TALOJA S/STN

Feeder No / Name : 320 / 22 kv Taloja Panchanand
income Feeder KV- 22 / OUTGOING

HV Non-Express Feeder

DATE	01-JUN-17
HR	Load (MW)
24	1.0288
Max	1.0288
Min	1.0288
Avg	1.0288

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 226003 / 100/22 KV TALOJA S/STN

Feeder No / Name : 321 / BEL-II (Sola ,BE, DN)

HV Non-Express Feeder

EXPRESS Feeder KV- 22 /

OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	1.0288
Max	1.0288
Min	1.0288
Avg	1.0288

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 226003 / 100/22 KV TALOJA S/STN

Feeder No / Name : 322 / HTW REXAM

HV Non-Express Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 226003 / 100/22 KV TALOJA S/STN

Feeder No / Name : 601 / Hindalco - II

EHV Express Feeder

Feeder KV- 100 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	4.6764
Max	4.6764
Min	4.6764
Avg	4.6764

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 226003 / 100/22 KV TALOJA S/STN

Feeder No / Name : 603 / 100Kv Hindalco - I

EHV Express Feeder

Feeder KV- 100 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	4.6764
Max	4.6764
Min	4.6764
Avg	4.6764

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 226003 / 100/22 KV TALOJA S/STN

Feeder No / Name : 604 / 100 kv Deepak Fertilisers

EHV Express Feeder

Feeder KV- 100 / OUTGOING

DATE	01-JUN-17	02-JUN-17
HR	Load (MW)	Load (MW)
11		3.1176
24	3.1176	
Max	3.1176	3.1176
Min	3.1176	3.1176
Avg	3.1176	3.1176

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 228028 / 220/100/22 KV TALOJA S/STN

Feeder No / Name : 303 / 22kv Feeder Galaxy

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 228028 / 220/100/22 KV TALOJA S/STN

Feeder No / Name : 305 / 22 KV LINK LINE

Feeder KV- 22 / INCOMING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 228028 / 220/100/22 KV TALOJA S/STN

Feeder No / Name : 309 / 22kv omayya

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 228028 / 220/100/22 KV TALOJA S/STN

Feeder No / Name : 310 / Technova New

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 228028 / 220/100/22 KV TALOJA S/STN

Feeder No / Name : 312 / 22KV REXAM

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 228028 / 220/100/22 KV TALOJA S/STN

Feeder No / Name : 313 / 22KV JINDAL DRUGS HV Non-Express Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
17	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 228028 / 220/100/22 KV TALOJA S/STN

Feeder No / Name : 314 / 22 kv VVF - II

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 228028 / 220/100/22 KV TALOJA S/STN

Feeder No / Name : 602 / 100 kvFGIL

EHV Express Feeder

Feeder KV- 100 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	3.1176
Max	3.1176
Min	3.1176
Avg	3.1176

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 228028 / 220/100/22 KV TALOJA S/STN

Feeder No / Name : 604 / 100KV BOC

EHV Express Feeder

Feeder KV- 100 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	3.1176
Max	3.1176
Min	3.1176
Avg	3.1176

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 223001 / 22/22 KV BHINGARI SWITCHING

ST

Feeder No / Name : 302 / 22 KV PANVEL-I

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.3155	4.8011	4.6296	4.5268	5.144	4.8011	4.321
2	5.2469	4.6296	3.2922	4.3896	4.8697	4.6296	3.4294
3	5.144	4.3553	3.4294	4.1152	4.7325	4.4582	2.7435
4	4.6296	3.738	4.7325	3.9781	4.5268	4.1838	3.4294
5	4.1495	3.4979	4.2867	3.7723	4.1838	4.0809	3.9095
6	3.4637	3.4294	4.1152	3.4294	3.7723	3.7037	3.7037
7	3.2922	3.1893	4.8011	3.155	3.4979	3.5665	3.5665
8	3.4637	3.2236	4.5268	3.155	3.4979	3.3265	3.3608
9	3.9438	3.6351	3.4637	.2743	4.1838	3.6351	3.4294
10		4.2524	3.9438	3.1893	4.321	3.7037	3.8066
11	5.6242	4.1152	4.3553	3.2579	4.9383	3.7723	3.9781
12	5.6584	5.5556	5.3498	3.4637	4.8697		3.6008
13	5.2469	5.5556	5.144	4.5953	4.5953		4.0466
14	5.487	5.6242	4.5953	4.6296			4.2181
15	5.6242	.583	4.2867	4.6296			4.4925
16	5.6584	4.4582	5.4527	4.561	4.8354	2.7435	4.4582
17	5.2469	4.4582	4.1838	4.3896	4.2524	4.8011	3.7723
18	4.8697	4.3896	4.0466	4.1838	3.8752	4.1838	3.7037
19	4.8354	4.0124	4.0466	4.6296	4.0466	4.1838	3.7723
20	4.9383	4.2524	4.2181	5.144	4.2181	4.5268	4.1152
21	5.2469	4.2181	4.1838	5.3841	4.321	4.8011	
22	4.8697	4.8011	4.4582	5.5556	5.1783	4.904	3.9438
23	5.2469	5.0069	4.8697	5.4527	5.2812	4.8011	
24	5.4527	4.904	5.0069	4.7325	5.2812	4.904	4.904
Max	5.6584	5.6242	5.4527	5.5556	5.2812	4.904	4.904
Min	3.2922	.583	3.2922	.2743	3.4979	2.7435	2.7435
Avg	4.8980	4.1953	4.3924	4.1081	4.4737	4.1855	3.8502

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 223001 / 22/22 KV BHINGARI SWITCHING

ST

Feeder No / Name : 307 / Sainagar

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.2126	4.8697	5.144	5.8299	4.904	5.2126	5.487
2	5.144	4.8011	5.0755	5.5213	4.4925	5.144	5.3498
3	4.8697	4.5268	4.7325	5.2469	4.2867	4.904	5.1783
4	4.6296	4.2867	4.1152	4.8697	4.0466	4.6982	4.1152
5	3.738	4.1152	3.9438	4.1152	3.8066	4.1838	4.2524
6	3.6694	3.9095	4.6296	3.9781	3.2579	3.8066	4.1152
7	3.4979	3.4294	4.9726	3.4294	3.2922	3.4979	3.9438
8	3.3608	2.9835	4.8011	3.2922	3.3265	3.2579	3.4637
9	3.2922	2.915	3.2579	3.0521	3.0178	3.0521	3.0864
10	3.1207	2.9835	3.2579	3.1207	2.8807	3.2579	3.1893
11	3.0864	2.7435		3.155	2.7092	3.4294	3.0864
12	3.0178	3.0178	3.1207	3.155			2.915
13	3.0178	2.9835	3.2579	2.915	3.0178	.2743	2.8464
14	3.2922	3.5665	3.3608	2.8807	3.4637		3.0864
15	3.6694	3.8409	3.4294	3.2579	3.7037		3.2579
16	3.5665			3.2922	3.4294	4.3896	3.2236
17	2.915	3.2922	3.2579	3.0178	2.9492	4.1152	3.155
18	2.7092	3.1893	3.3608	2.5377	2.915	3.7037	2.6406
19	3.0521	3.1893	3.8409	3.1207	2.9835	3.5665	3.2579
20	3.8066	3.6008	3.9095	3.6694	3.5322	3.9781	3.5322
21	3.7723	3.738	3.8066	3.8752	3.7037	4.1152	
22	4.0809	4.1838	4.3553	3.9095		4.561	4.1838
23	4.7325	4.7668	4.8011	4.8354	5.1097	4.4582	4.321
24	5.3155	5.0069	5.144	4.9726	5.2469	5.3841	5.8299
Max	5.3155	5.0069	5.144	5.8299	5.2469	5.3841	5.8299
Min	2.7092	2.7435	3.1207	2.5377	2.7092	.2743	2.6406
Avg	3.7737	3.7365	4.0716	3.7937	3.6398	3.9519	3.8051

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 223001 / 22/22 KV BHINGARI SWITCHING

ST

Feeder No / Name : 310 / 22 KV PANVEL-III

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5377	2.4691	2.0576	2.4348	2.4006	2.2291	2.7435
2	2.4691	2.4348	2.332	2.2291	2.2291	2.1948	2.572
3	2.4006	2.332	2.1948	2.1262	2.0576	2.1262	2.332
4	2.2291	1.8861	1.8519	1.989	1.749	2.0576	2.572
5	1.7833	1.7147	1.7147	1.7833	1.5432	1.8861	1.9547
6	1.7147	1.6804	1.6461	1.9204	1.5432	1.7833	1.9204
7	1.5775	1.5432	1.749	1.3032	1.6118	1.7147	1.8861
8	1.6461	1.5775	2.0576	1.6461	1.6118	1.6461	1.8176
9	1.9547	2.1605	2.1605	1.8861	2.0576	1.6804	2.1948
10	2.5377	2.0919	2.9492	2.572	2.332	1.5775	2.8121
11	3.0521		4.0809	2.4348	2.8807	2.915	4.0124
12	2.7778	2.4006	2.7435	2.2977	2.7778	3.0864	3.9781
13	2.8464		2.8121	2.5034	3.738	3.1893	3.9781
14	2.8464	2.7092	2.8807	2.572	3.8066	3.4637	4.1152
15	3.2579	3.0178	2.9492	2.4348	5.1783	3.5665	4.2181
16	2.9835		1.749	2.5034	4.0124	3.6351	4.1152
17	2.7778	3.5665	3.3608	2.2634	3.738	3.5322	3.8066
18	2.572	3.5665	3.9095	2.2291	3.4979	3.3608	3.4979
19	2.4691	3.3265	3.6351	2.1948	3.1207	3.2922	3.5322
20	2.4691	3.3608	3.4637	2.2977	3.6694	3.4979	3.3951
21	2.332	3.3265	3.3951	2.2634	3.3608	2.8807	3.0521
22	2.0919	3.155	2.915	2.1605		2.915	2.7435
23	2.4006	3.0521	2.8807	2.5377	2.5377	2.7435	2.5034
24	2.572	2.5034		2.6749	2.4691	2.4006	2.7778
Max	3.2579	3.5665	4.0809	2.6749	5.1783	3.6351	4.2181
Min	1.5775	1.5432	1.6461	1.3032	1.5432	1.5775	1.8176
Avg	2.4291	2.5655	2.6734	2.2191	2.7793	2.6406	3.0221

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 224004 / 33/11KV NEW PANVEL SEC-7

S/STN

Feeder No / Name : 201 / 11 kV Station Trasformer Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	.0187
Max	.0187
Min	.0187
Avg	.0187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 224004 / 33/11KV NEW PANVEL SEC-7

S/STN

Feeder No / Name : 205 / 11 kV Sector 8

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	2.5579
Max	2.5579
Min	2.5579
Avg	2.5579

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 224004 / 33/11KV NEW PANVEL SEC-7

S/STN

Feeder No / Name : 206 / 11kv sect-3

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	3.4915
Max	3.4915
Min	3.4915
Avg	3.4915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 224004 / 33/11KV NEW PANVEL SEC-7

S/STN

Feeder No / Name : 207 / 11KV SECT-5

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	.5601
Max	.5601
Min	.5601
Avg	.5601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 224004 / 33/11KV NEW PANVEL SEC-7

S/STN

Feeder No / Name : 208 / 11kv mpk

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	3.2526
Max	3.2526
Min	3.2526
Avg	3.2526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 224004 / 33/11KV NEW PANVEL SEC-7

S/STN

Feeder No / Name : 209 / 11 KV ESRGSR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	1.5432
Max	1.5432
Min	1.5432
Avg	1.5432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 224006 / 33/11 kV Sector 15, New

Panvel

Feeder No / Name : 204 / 11 kV Shreeyash feeder

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 224012 / 33/11 KV KALPATARU RIVERSIDE

Feeder No / Name : 201 / 11KV KALPATARU KRISHNA-1 Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.2054	.2054	.1494	.2427	.2241	.2614
2	.2427	.168	.1829	.1307	.2054	.2054	.2241
3	.2427	.168	.1463	.1307	.168	.1867	.1829
4	.2241	.1494	.1097	.112	.1494	.1867	.1494
5	.2054	.1494	.0934	.112	.1494	.168	.112
6	.1867	.1494	.1097	.1494	.1307	.168	.0934
7	.168	.1307	.1646	.1494	.1307	.1494	.168
8	.1494	.1494	.1494	.1307	.1307	.1867	.168
9	.168	.1307	.1307	.1307	.1307	.1307	.1307
10	.1307	.1307	.1307	.1494	.0934	.1307	.1307
11	.112	.1307	.1307	.1307	.112	.1307	.1307
12	.112	.1307	.1494	.1307	.112	.1494	.1307
13	.1307	.112	.1307	.1307	.112	.1494	.1494
14	.1307	.112	.1494	.1307	.112	.168	.1494
15	.1494	.112	.168	.1494	.1494	.1867	.1494
16	.1494	.112	.1494	.1494	.1494	.1494	.1494
17	.1494	.1307	.1494	.1494	.1494	.1494	.1494
18	.1494	.1494	.1494	.1307	.1494	.1494	.1307
19	.1494	.1494	.1307	.1307	.112	.1494	.1307
20	.168	.1494	.1494	.1494	.1307	.1494	.1494
21	.168	.1829	.2054	.168	.168	.1829	
22	.1867	.2054	.168	.1867	.1867	.2012	
23	.2241	.2427	.2241	.2614	.2801	.2987	.1867
24	.2858	.2427	.2427	.2054	.2614	.2614	.2987
Max	.2858	.2427	.2427	.2614	.2801	.2987	.2987
Min	.112	.112	.0934	.112	.0934	.1307	.0934
Avg	.1768	.1539	.1550	.1478	.1548	.1755	.1602

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 224012 / 33/11 KV KALPATARU RIVERSIDE

Feeder No / Name : 202 / 11KV KALPATARU NARMADA-1 Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075	.1509	.1509	.132	.168	.1698	.1509
2	.1886	.1509	.1132	.1132	.1509	.1698	.132
3	.1886	.132	.0943	.1132	.132	.1509	.1132
4	.1698	.132	.0754	.0943	.1132	.132	.0943
5	.1509	.132	.0754	.0943	.1132	.132	.0754
6	.132	.1132	.0943	.132	.1132	.1132	.0754
7	.1132	.0943	.0754	.1132	.0943	.0943	.0943
8	.0943	.0754	.0943	.0754	.1132	.0895	.0943
9	.0943	.1132	.0943	.0943	.1132	.0943	.0943
10	.0943	.1132	.132	.0943	.1132	.132	.0943
11	.0943	.0943	.0943	.0943	.1132	.1132	.0943
12	.1132	.1132	.1132	.0943	.1132	.0943	.0943
13	.132	.0943	.132	.0943	.1132	.0943	.1132
14	.1509	.0943	.1509	.0943	.1132	.1132	.1132
15	.1509	.0943	.1132	.0943	.1132	.132	.1132
16	.1509	.0754	.132	.1132	.1132	.1132	.1132
17	.1132	.0943	.1132	.1132	.1132	.1132	.1132
18	.0943	.1132	.0754	.0943	.1132	.0943	.1132
19	.0754	.0943	.0943	.0754	.0754	.0943	.0754
20	.0943	.132	.0943	.1132	.1132	.1132	.0943
21	.132	.1132	.1132	.132	.1132	.132	
22	.1509	.132	.1132	.132	.1698	.1509	
23	.1509	.1509	.1132	.1698	.1698	.1905	.132
24	.1715	.1698	.1698	.1698	.1698	.1886	.1886
Max	.2075	.1698	.1698	.1698	.1698	.1905	.1886
Min	.0754	.0754	.0754	.0754	.0754	.0895	.0754
Avg	.1337	.1155	.1092	.1100	.1226	.1256	.1080

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 224012 / 33/11 KV KALPATARU RIVERSIDE

Feeder No / Name : 203 / 11 KV KALPATARU KAVERI-1 Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1227	.1433	.1052	.1075	.1433	.1433	.1791
2	.1227	.1433	.0876	.1075	.1254	.1433	.1433
3	.1052	.1254	.0701	.0895	.1254	.1254	.1075
4	.1052	.1254	.0701	.0895	.1075	.1254	.0895
5	.1052	.1254	.0876	.0895	.1075	.1254	.0716
6	.1052	.1254	.0876	.1075	.1075	.1254	.0895
7	.0876	.1254	.1052	.1075	.0895	.1075	.1254
8	.0876	.1075	.1227	.1075	.1075	.1254	.1254
9	.0914	.1254	.1052	.132	.1254	.0895	.1075
10	.0914	.1227	.1075	.1254	.0895	.1075	.0876
11	.128	.1227	.1132	.1254	.1075	.1075	.0876
12	.128	.1402	.1075	.1254	.1075	.1075	.0876
13	.128	.1227	.1612	.1254	.1075	.1075	.1052
14	.128	.1227	.1254	.1254	.1075	.0895	.1052
15	.1463	.1227	.1075	.1254	.1075	.0895	.1052
16	.1463	.1227	.1075	.1254	.1075	.0895	.1227
17	.1463	.1052	.1254	.1254	.1075	.0895	.1227
18	.128	.0876	.0895	.1075	.1075	.0895	.1402
19	.0914	.1052	.0895	.0895	.0876	.0895	.0876
20	.128	.1227	.1075	.1075	.0895	.1075	.1052
21	.128	.1402	.1254	.1075	.1075	.1433	
22	.128	.1402	.1254	.1254	.1254	.1612	
23	.1433	.1402	.1254	.1433	.1254	.197	.1402
24	.2401	.1612	.1402	.1433	.1433	.1433	.2149
Max	.2401	.1612	.1612	.1433	.1433	.197	.2149
Min	.0876	.0876	.0701	.0895	.0876	.0895	.0716
Avg	.1234	.1261	.1083	.1152	.1111	.1179	.1159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 224012 / 33/11 KV KALPATARU RIVERSIDE

Feeder No / Name : 303 / 22KV O/g 2(Panvel 2)

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.3573	6.2464	5.8528	6.1725	6.7638	5.8398	6.9502
2	5.8398	5.8398	5.1212	5.6181	6.2464	5.6181	6.2186
3	5.5441	5.4332	4.3896	5.0636	5.6181	5.2484	5.487
4	5.1745	4.6571	3.658	4.6201	5.2484	4.9897	5.1212
5	4.731	4.3244	3.2922	4.4353	4.9158	4.731	4.3896
6	4.4353	4.2505	3.658	4.2875	4.3614	4.4353	3.658
7	4.1396	3.9179	3.9872	3.8809	4.1027	4.0287	4.0238
8	3.8809	3.9548	3.8409	3.6961	4.0287	3.9918	3.8409
9	4.3896	4.3614	4.1335	3.8836	4.3244	4.3244	4.2433
10	5.5441	5.8528	5.5441	4.694	5.9137		5.3593
11	6.5421	6.2186	6.7638	4.8419	6.3942		6.3942
12	6.653	6.6575		4.8419	5.9877	7.3891	6.3942
13	6.8008	6.6575	6.7269	4.8419	5.7289	7.3525	6.3573
14	6.9856	6.2186	6.6899	4.8788	5.8029	7.3891	6.3942
15	7.0595	5.8528	6.6899	4.8788	5.9137	7.4257	6.4682
16	6.8747	5.487	6.579	4.9528	7.0965	6.9502	6.5421
17	6.6899	5.8528	6.0616	5.0267	6.2833	6.5844	6.1355
18	6.7269	5.8528	6.1355	5.0267	6.0246	6.5112	5.8768
19	6.7269	6.0723	6.653	5.1006	6.2464	6.4381	5.9137
20	4.7782	5.8528	6.6899	5.5441	6.616	6.9867	6.3573
21	6.3573	5.6333	6.4312	5.6699	6.1725	6.5844	
22	5.9137	6.3283	5.9137	5.5441	5.7659	6.2186	
23	6.5421	6.3649	6.7638	6.4975	6.7269	7.316	5.4702
24	6.8378	6.653	6.3649	6.4682	6.653	6.0616	7.3891
Max	7.0595	6.6575	6.7638	6.4975	7.0965	7.4257	7.3891
Min	3.8809	3.9179	3.2922	3.6961	4.0287	3.9918	3.658
Avg	5.8969	5.6059	5.5626	5.0194	5.7890	6.0189	5.6811

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 228013 / 220/33/22 KV ONGC PANVEL

Feeder No / Name : 301 / 22Kv ONGC Express

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	3.0864
Max	3.0864
Min	3.0864
Avg	3.0864

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 228013 / 220/33/22 KV ONGC PANVEL

Feeder No / Name : 302 / 22 KV Bhingari I/C-I Urban/Sheddable Urban Feeder
Feeder KV- 22 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	12.0028
Max	12.0028
Min	12.0028
Avg	12.0028

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 228013 / 220/33/22 KV ONGC PANVEL

Feeder No / Name : 303 / 22 KV BHINGARI-II Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	13.1002
Max	13.1002
Min	13.1002
Avg	13.1002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 228013 / 220/33/22 KV ONGC PANVEL

Feeder No / Name : 304 / 22 KV NEW PANVEL Urban/Sheddable Urban Feeder
Feeder KV- 22 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
16	.7545
24	7.8875
Max	7.8875
Min	.7545
Avg	4.321

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 228013 / 220/33/22 KV ONGC PANVEL

Feeder No / Name : 404 / 33 KV RAILWAY I Urban/Sheddable Urban Feeder
Feeder KV- 33 / INCOMING

DATE	01-JUN-17
HR	Load (MW)
24	2.1605
Max	2.1605
Min	2.1605
Avg	2.1605

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 228013 / 220/33/22 KV ONGC PANVEL

Feeder No / Name : 405 / 33KV KALPATARU INCOMING-1 Only one consumer of WW with HT-IV
Feeder KV- 33 / INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.5295	6.989	6.4929	6.7696	7.5401	6.4975	7.7618
2	6.2003	6.6026	5.7225	6.3306	7.0439	6.2781	6.8793
3	5.8711	6.2185	4.952	5.7247	6.3831	5.7247	5.9968
4	5.5967	5.3932	4.2913	5.2857	5.9419	5.3932	5.6104
5	5.048	4.8994	3.6877	5.0663	5.6127	5.1738	4.8949
6	4.4993	4.8446	4.2913	4.9017	5.0068	5.0092	4.1816
7	4.225	4.5153	4.5679	4.5176	4.5679	4.5702	4.2959
8	4.0604	4.4581	4.4581	4.2935	4.5679	4.6251	4.4033
9	4.5542	4.8446	4.7348	4.3901	4.8446	4.7782	4.7325
10	5.8299	6.4358	5.9968	5.064	5.8847	.3429	5.6516
11	6.9821	6.7078	7.204	5.2812	6.8175	.3429	6.3649
12	7.0919	7.2588	5.0617	5.2812	6.5981	8.0247	6.4746
13	7.2588	7.1468	6.9296	5.2812	6.214	7.9149	6.5421
14	7.4234	6.7078	7.0942	5.336	6.2688	7.9721	6.4866
15	7.5903	6.3786	7.1491	5.3932	6.5455	7.9721	6.5295
16	20.1795	5.9374	6.9845	5.503	5.8322	7.4234	6.6392
17	7.1491	6.3786	6.4906	5.5579	6.8199	7.0919	6.1454
18	7.1491	6.4334	6.3786	5.5007	6.4883	7.0919	5.9808
19	7.0919	6.4883	6.925	5.4984	6.5432	6.5844	5.9808
20	7.4234	6.4358	7.0919	5.8871	7.037	.4001	6.4198
21	6.7672	6.1637	6.8199	6.1614	6.7101	.4572	
22	6.438	6.9342	6.3831	6.1088	6.438		
23	7.0439	7.0462	7.2657	6.9914	7.5423	8.0384	5.5418
24	2.8806	7.2108	7.0462	6.9914	7.3206	6.8268	8.0955
Max	20.1795	7.2588	7.2657	6.9914	7.5423	8.0384	8.0955
Min	2.8806	4.4581	3.6877	4.2935	4.5679	.3429	4.1816
Avg	6.7035	6.1846	6.0008	5.5465	6.2737	5.4145	5.9822

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

URAN[126]

BU 0337

Substation No/ Name :- 223033 / 22/22 KV URAN SWITCHING

Feeder No / Name : 302 / 22 KV Dronagiri

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	1.5729
Max	1.5729
Min	1.5729
Avg	1.5729

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

URAN[126]

BU 0337

Substation No/ Name :- 223033 / 22/22 KV URAN SWITCHING

Feeder No / Name : 303 / 22 KV Chirner

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	3.0045
Max	3.0045
Min	3.0045
Avg	3.0045

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

URAN[126] BU 0337

Substation No/ Name :- 223033 / 22/22 KV URAN SWITCHING

Feeder No / Name : 304 / 22 KV Industrial Urban/Sheddable Urban Feeder
Feeder KV- 22 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	1.491
Max	1.491
Min	1.491
Avg	1.491

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

URAN[126] BU 0337

Substation No/ Name :- 228005 / 220/22 KV GTPS URAN

Feeder No / Name : 301 / 22 KV Incomer to 22/22 KV Urban/Sheddable Urban Feeder
Uran Feeder KV- 22 / INCOMING

DATE	01-JUN-17
HR	Load (MW)
24	6.4842
Max	6.4842
Min	6.4842
Avg	6.4842

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

URAN[126]

BU 0337

Substation No/ Name :- 228005 / 220/22 KV GTPS URAN

Feeder No / Name : 302 / ONGC -1 FEEDER

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	3.9529
Max	3.9529
Min	3.9529
Avg	3.9529

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

URAN[126]

BU 0337

Substation No/ Name :- 228005 / 220/22 KV GTPS URAN

Feeder No / Name : 303 / N.A.D. FEEDER

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	1.1576
Max	1.1576
Min	1.1576
Avg	1.1576

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

URAN[126] BU 0337

Substation No/ Name :- 228005 / 220/22 KV GTPS URAN

Feeder No / Name : 304 / ONGC-2 FEEDER

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	2.9767
Max	2.9767
Min	2.9767
Avg	2.9767

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

URAN[126]

BU 0337

Substation No/ Name :- 228005 / 220/22 KV GTPS URAN

Feeder No / Name : 305 / JNPT FEEDER

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	1.6834
Max	1.6834
Min	1.6834
Avg	1.6834

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

URAN[126]

BU 0337

Substation No/ Name :- 228005 / 220/22 KV GTPS URAN

Feeder No / Name : 306 / GTP FEEDER

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17
HR	Load (MW)
24	.7522
Max	.7522
Min	.7522
Avg	.7522

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

URAN[126]

BU 0337

Substation No/ Name :- 228005 / 220/22 KV GTPS URAN

Feeder No / Name : 810 / 220kv JNPT

EHV Express Feeder

Feeder KV- 220 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	9.0535
Max	9.0535
Min	9.0535
Avg	9.0535

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

URAN[126]

BU 0337

Substation No/ Name :- 228005 / 220/22 KV GTPS URAN

Feeder No / Name : 811 / 220kv ONGC

EHV Express Feeder

Feeder KV- 220 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	8.6763
Max	8.6763
Min	8.6763
Avg	8.6763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641] BU 4641

Substation No/ Name :- 283001 / 22/22 KV Airoli, Sec-1

Swt/Stn

Feeder No / Name : 311 / 22 KV Airoli Naka
Feeder KV- 22 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	01-JUN-17	04-JUN-17	06-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
9		4.1152	
20			4.7531
23	.7545		
Max	.7545	4.1152	4.7531
Min	.7545	4.1152	4.7531
Avg	.7545	4.1152	4.7531

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641] BU 4641

Substation No/ Name :- 283001 / 22/22 KV Airoli, Sec-1

Swt/Stn

Feeder No / Name : 312 / 22KV Gigaplex

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641] BU 4641

Substation No/ Name :- 283001 / 22/22 KV Airoli, Sec-1

Swt/Stn

Feeder No / Name : 313 / 22KV CIDCO -3

Urban/Sheddable Urban Feeder

Feeder KV- 22 / INCOMING

DATE	01-JUN-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641] BU 4641

Substation No/ Name :- 283001 / 22/22 KV Airoli, Sec-1

Swt/Stn

Feeder No / Name : 315 / 22 KV C.L.D.

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641] BU 4641

Substation No/ Name :- 283001 / 22/22 KV Airoli, Sec-1

Swt/Stn

Feeder No / Name : 317 / 22 KV H.T. Media

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 202 / 11 KV Sector - 7

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		3.7157	4.1495		4.0552	4.1914	
2		3.3573	4.0009		3.4294		
3		3.1687	3.81		3.2922	3.9628	
4		2.9235	3.6008		3.0178		
5		2.7915	3.4294			3.5056	
6		2.32					
7	2.2672	2.1879			2.0233	3.2388	2.3011
8			2.3011		2.0576	2.2672	2.1691
9		2.1313	2.0576				
10	2.3954	2.4143	2.5149		2.3624	2.4196	
11					2.5149		
12	2.7726						
13		2.7435	2.9047	2.6673			
14			3.0933				2.6482
15			3.1121	2.934			
16	2.8669				2.8769	2.8292	
17		2.553	2.6406	2.8578			
19		2.5892		2.9531	2.6101		
20				3.1817	3.2007		
21		3.4328			3.296		
22				3.315			
23					4.0771	4.3947	
24	4.6868	4.1495	4.3058	3.9986	4.4963		
Max	4.6868	4.1495	4.3058	3.9986	4.4963	4.3947	2.6482
Min	2.2672	2.1313	2.0576	2.6673	2.0233	2.2672	2.1691
Avg	2.9978	2.8913	3.2247	3.1296	3.0936	3.3512	2.3728

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 203 / 11 KV Sector - 10

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.6406	2.3148		2.2291	2.8197
2		2.2634	2.4577		2.1605	
3		1.9805	2.3388		2.0405	2.553
4		1.8861	2.1338		1.8176	
5		1.8673	1.7147		1.6632	2.1719
6		1.773				
7	1.6956	1.6975			1.4575	1.7147
8			1.3392		1.3717	1.6385
9		1.3957	1.3336			
10	1.6598	1.5844	1.2765		1.5242	
11	1.4626				1.6956	
13	1.5466	1.6385	1.7164	1.3336		
14			1.7353			
15			1.8296	1.9433		
16	1.905				1.7909	1.5089
17		1.5466	1.6032	1.829		
19		1.3769		1.8671	1.5432	
20				2.1338	2.0957	
21		2.2481			2.1338	
22				2.4768		
23					2.8006	2.7538
24	2.8578	2.7538	2.7244	2.3388	2.7816	
Max	2.8578	2.7538	2.7244	2.4768	2.8006	2.8197
Min	1.4626	1.3769	1.2765	1.3336	1.3717	1.5089
Avg	1.8546	1.9037	1.886	1.9889	1.9404	2.1658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 204 / 11 KV Sector -15

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		3.1121	3.0864		3.0521	3.5818
2		3.0178	3.0521		2.8464	3.4294
3		2.6217	2.9492		2.7435	
4		2.452	2.8635		2.6406	3.2388
5		2.4331	2.7606		2.5206	
6		2.3011				2.9721
7	2.2862	2.1313			2.3148	
8			1.9624		1.9547	2.2291
9		1.9993	1.9814			
10	1.9993	2.037	2.0767		2.0957	2.21
11	2.0748				2.0957	
13		2.1338	2.2634	3.4294		
14			2.3011			
15			2.4143	2.21		
16	2.8858				2.3434	2.2822
17		1.9052	2.0936	2.2862		
19		2.1879		2.2481	1.9814	
20				2.6292	2.6673	
21		2.7816			2.8578	
22				2.8387		
23					3.6199	3.6214
24	3.7342	3.5837	3.5437	3.3573	3.677	
Max	3.7342	3.5837	3.5437	3.4294	3.677	3.6214
Min	1.9993	1.9052	1.9624	2.21	1.9547	2.21
Avg	2.5961	2.4784	2.5653	2.7141	2.6274	2.9456

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 205 / 11 KV Railway

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1132	.1029		.12	.1143	
2		.1132	.0857		.1029		
3		.1132	.0857		.1029	.0953	
4		.1132	.0953		.1029		
5		.1132	.0953		.1029	.0953	
6		.1132					
7	.1143	.1132			.1029	.1143	
8			.0953		.1029	.1143	.1132
9		.1132	.1143				
10	.1132	.1132	.1143		.1143	.1143	
11	.1132				.1143		
12	.1143						
13		.0953	.1132	.1143			
14			.1132				.1143
15			.1132	.1334			
16	.1132				.1143	.1132	
17		.1143	.1132	.1143			
19		.0953		.1334	.1143		
20				.0953	.1143		
21		.1143			.1143		
22				.1143			
23					.1143	.1132	
24	.1334	.1132	.1143	.1132	.1143		
Max	.1334	.1143	.1143	.1334	.12	.1143	.1143
Min	.1132	.0953	.0857	.0953	.1029	.0953	.1132
Avg	.1169	.1108	.1043	.1169	.1101	.1093	.1138

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 206 / 11 KV Ajanta Sector -13

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1132	.1372		.1029	.1715	
2		.1132	.12		.1029		
3		.1132	.12		.1029	.1334	
4		.1132	.1029		.1029		
5		.1132	.1029		.1029	.1143	
6		.1132					
7	.0953	.1132			.1029	.1143	.1132
8			.1132		.1029	.1334	.1132
9		.1132	.1143				
10	.1132	.1132	.1143		.1143	.1143	
11	.1132				.1143		
13			.1132	.1143			
14		.1143	.1132				.1143
15			.1132	.1334			
16	.1132				.1143	.1132	
17		.1143	.1132	.1143			
19		.1132		.1334	.1143		
20				.1143	.1334		
21		.1524			.1524		
22				.1334			
23					.1715	.1132	
24	.1143	.1132	.1143	.1132	.1715		
Max	.1143	.1524	.1372	.1334	.1715	.1715	.1143
Min	.0953	.1132	.1029	.1132	.1029	.1132	.1132
Avg	.1098	.1162	.1148	.1223	.1204	.1260	.1136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 207 / 11 KV Sector - 4

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.9424	2.915		2.7949	3.2007
2		2.8104	2.7778		2.692	
3		2.5463	2.6406		2.6063	2.8959
4			2.5377		2.4006	
5		2.452	2.4348		2.2634	2.5911
6		2.3011				
7	2.572	2.4897			2.2805	2.4006
8			1.9719		2.0748	2.2481
9	2.0957	2.2068	2.0957			
10	2.2257	2.1125	2.1719		2.191	1.848
11	2.4331				2.2862	
12	2.3765					
13		2.0957	2.452	2.3624		
14	2.0767		2.3954			
15			2.4143	2.4958		
16	2.4331				2.4387	2.3011
17		2.1879	2.2257	2.3053		
19		2.4387		2.4958	2.2291	
20				2.9721	2.9531	
21		2.9531			2.9912	
22				3.0864		
23					3.1817	3.131
24	3.5246	3.2065	3.3341	3.1499	3.315	
Max	3.5246	3.2065	3.3341	3.1499	3.315	3.2007
Min	2.0767	2.0957	1.9719	2.3053	2.0748	1.848
Avg	2.4672	2.5187	2.4898	2.6954	2.5799	2.5771

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 208 / 11 KV Sector-8

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.7353	1.7147		1.2517	1.1431
2		1.5089	1.5775		1.166	
3		1.4146	1.4403		1.0974	.8002
4		1.3203	1.3375		.9259	
5		1.2637	1.2346		.823	.5335
6		1.3014				
7	1.2384	1.3392			1.0802	.8573
8			1.046		1.1145	1.0669
9		1.358	1.3146			
10	1.4146	1.3769	1.448		1.3717	1.2765
11	1.3957				1.2765	
12	1.4901					
13		1.448	1.5466	1.467		
14			1.5278			
15			1.4523	1.5623		
16	1.5278				1.3336	1.2826
17		1.3957	1.2826	1.3908		
19		1.7353		1.2574	1.086	
20				1.4289	1.3717	
21		1.4861			1.5623	
22				1.6385		
23					1.6575	2.0748
24	2.1719	1.8673	2.0005	1.8484	2.1719	
Max	2.1719	1.8673	2.0005	1.8484	2.1719	2.0748
Min	1.2384	1.2637	1.046	1.2574	.823	.5335
Avg	1.5398	1.4679	1.4556	1.5133	1.2860	1.1294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 210 / 11 KV Sector-20A NG

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.1691	2.0576		1.989	2.4387	
2		1.905	2.0062		1.8861	2.3243	
3		1.7918	1.869		1.8004		
4		1.6975	1.5432		1.6118	2.0957	
5		1.5089	1.4403		1.5089		
6		1.5278				1.7909	
7	1.3908	1.4335			1.2174	1.6004	
8			1.0288		1.1317	1.2955	
9		1.226	1.1241				
10	1.1317	1.1317	1.1506		.9602	1.1812	
11	1.1128				1.0098		
12	1.1128						
13	1.1128	1.1812	1.226	1.1241			
14			1.2449				1.086
15			1.2826	1.2003			
16	.9431				1.1812	1.2071	
17		1.086	1.1506	1.3527			
19		1.2765		1.2955	1.0479		
20				1.448	1.4289		
21		1.6004			1.6766		
22				1.9052			
23					2.4768	2.4922	
24	2.4387	2.2634	2.3815	2.1502	2.5149		
Max	2.4387	2.2634	2.3815	2.1502	2.5149	2.4922	1.086
Min	.9431	1.086	1.0288	1.1241	.9602	1.1812	1.086
Avg	1.3204	1.5571	1.5004	1.4966	1.5628	1.8251	1.086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 211 / 11KV Sector-14A

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		4.225	4.2696		4.0638	4.9535	
2		3.7534	4.1152		3.9438		
3		3.5648	3.9781		3.7723	4.5725	
4		3.3951	3.8409		3.4294		
5		3.3196	3.4294		3.2579	4.1724	
6		2.999					
7	3.0102	2.8669			2.6406	3.5056	
8			2.4863		2.5377	2.9912	
9		2.9047	2.7816				
10	2.8292	2.8481	2.6235		2.8387	3.0293	
11	2.9424				3.0293		
12	3.0556						
13		3.1245	3.3008	2.934			
14			3.4328				3.0483
15			3.4139	3.2579			
16	3.2475				3.3532	3.0178	
17		3.0483	2.9047	3.0483			
19		3.4675		3.2388	2.8578		
20				3.7342	3.8104		
21		3.9609			3.8676		
22				4.1914			
23					4.9916	4.9983	
24	5.0488	4.9139	4.8773	4.5456	4.9916		
Max	5.0488	4.9139	4.8773	4.5456	4.9916	4.9983	3.0483
Min	2.8292	2.8481	2.4863	2.934	2.5377	2.9912	3.0483
Avg	3.3556	3.4566	3.4965	3.5643	3.5590	3.9051	3.0483

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 301 / 22KV Diva Gaon

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3957	1.3032		1.4403	1.448	
2		1.3203	1.2346		1.3717		
3		1.2071	1.166		1.3375	1.1431	
4		1.1317	1.0974		1.3032		
5		1.1317	1.0288		1.166	.9907	
6		1.0562					
7	1.0185	1.0185			.9259	.9907	
8			.8916		.9259	.9907	
9		.8676	.9526				
10	.9431	.9431	.9526		.8764	.8383	
11	.9808				.9145		
12	1.0185						
13		.9907	1.094	1.0288			
14			1.1317				.9526
15			1.1317	1.105			
16	1.094				1.0288	.9431	
17		.9808	1.0185	1.0288			
19		1.105		1.1812			
20				.8383			
21		1.4098			1.3717		
22				1.4098			
23					1.5623	1.5466	
24	1.5242	1.5844	1.4861	1.5466	1.5623		
Max	1.5242	1.5844	1.4861	1.5466	1.5623	1.5466	.9526
Min	.9431	.8676	.8916	.8383	.8764	.8383	.9526
Avg	1.0965	1.1530	1.1145	1.1626	1.2143	1.1114	.9526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283027 / 22/22KV Rabale MIDC Swt/stn

Feeder No / Name : 302 / Hamara Mahanagar (R.M.U. SHEDDABLE FEEDER HAVING WEEKLY
W-404 Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17
HR	Load (MW)
24	2.0576
Max	2.0576
Min	2.0576
Avg	2.0576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283027 / 22/22KV Rabale MIDC Swt/stn

Feeder No / Name : 305 / NARAYAN DAIRY (R.M.U. W- SHEDDABLE FEEDER HAVING WEEKLY
413) Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17
HR	Load (MW)
24	3.4294
Max	3.4294
Min	3.4294
Avg	3.4294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283027 / 22/22KV Rabale MIDC Swt/stn

Feeder No / Name : 306 / Roshn Hotel (R.M.U. R-320) SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17
HR	Load (MW)
24	2.7435
Max	2.7435
Min	2.7435
Avg	2.7435

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283027 / 22/22KV Rabale MIDC Swt/stn

Feeder No / Name : 307 / R.M.U. R-201

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17
HR	Load (MW)
24	2.0576
Max	2.0576
Min	2.0576
Avg	2.0576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283027 / 22/22KV Rabale MIDC Swt/stn

Feeder No / Name : 308 / TECHNOPROCESS (R.M.U. R- SHEDDABLE FEEDER HAVING WEEKLY
260) Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17
HR	Load (MW)
23	2.4006
Max	2.4006
Min	2.4006
Avg	2.4006

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 301 / 22 KV KALWA - I

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.3841	5.4184	5.2126	5.144	3.3608	5.6584	
2	3.4294	5.0412	4.9726	4.9383	4.1838	5.2469	
3	4.8011	4.7325	4.7325	4.6982	3.8752	5.0069	5.0069
4	4.6296	4.561	4.6296	4.5953	3.6694	4.8011	
5	4.5268	4.4239	4.5268	4.4582	3.4637	4.6982	
6	4.2524	4.3553	4.2524	4.2867	4.0466	4.5953	
7	4.3553	4.2867	4.1495	4.1495	4.4239	2.6063	
8	4.1838	4.1152	3.9781		4.4582	4.6982	
9	4.1152	4.0124	3.8409	4.1152	4.2524	4.3553	7.0302
10	4.1152	3.8752	3.9438		4.0809	4.2867	7.6818
11	3.9438	3.9095	3.7037	3.9438	4.0124	4.0124	6.5844
12	4.0124	3.8409	2.5149	3.8752	3.8409	3.9095	6.4815
13	3.9781	4.0466	2.5149	3.9781	3.7723	3.8752	6.1728
14	4.0124	4.1495	3.8409	4.0124	4.0466	3.9438	3.7037
15	3.8752	4.1152	3.9095	4.0466	4.1838	3.8409	3.6351
16	3.7723	3.8752	3.6694	4.1152	4.0466		
17	3.6694	3.9095	3.4637	3.8409	3.8752	3.9095	
18	3.9438	4.2181	3.7037	3.9438	4.6639		1.749
19	4.2181	4.6639	4.3896	4.0466	5.0755	4.321	
20	4.8697	5.0755	4.8697	4.321	5.2812		
21	5.487	5.1783	5.0412		5.6242	3.7494	
22	5.7956	5.5213	3.5894		5.8985		
23	5.8985	5.8299		3.4637	6.1043	6.2414	5.7613
24	5.6927	5.7956	5.6584	5.5899	3.2579	5.8985	5.8299
Max	5.8985	5.8299	5.6584	5.5899	6.1043	6.2414	7.6818
Min	3.4294	3.8409	2.5149	3.4637	3.2579	2.6063	1.749
Avg	4.4567	4.5396	4.1351	4.2781	4.3124	4.4827	5.4215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 302 / 22 KV Airoli -1(O/G)

Urban/Sheddable Urban Feeder

Feeder KV- 22 / INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.2414	9.6708	9.2593	8.5048	8.8135	8.3333	
2	8.5048	9.2936	8.6763	8.059	8.3333	7.6132	
3	7.0302	8.6763	7.3045	7.2017	8.059	6.9616	8.1276
4	6.4815	7.476	6.5158	6.0014	7.4417	6.0357	
5	6.1043	6.4472	5.9328	5.487	6.9273	5.8299	
6	5.8642	5.9328	5.487	5.3155	6.7215	5.6584	
7	5.8985	5.7956	5.6927	5.1783	6.2414	6.31	
8	6.6873	6.6187	6.1728	5.144	6.6873	6.7901	
9	7.0302	7.0988	5.6927	5.0412	6.893	7.1331	7.0645
10	7.3731	7.3045	6.2757		7.476	7.476	7.2017
11	7.7846	7.5103	6.4815	5.4184	7.8189	7.7504	7.2017
12	7.8875	7.5446	6.9616	5.5556	7.7846	7.7504	7.0988
13	8.1619	7.9561	4.8011	5.727	7.6818	8.059	7.3731
14	8.3676	8.2648	7.2702	6.2414	8.0247	7.8875	7.5446
15	8.2305	8.5048	7.3388	6.2757	8.4362	8.059	7.3731
16	8.059	8.2991	7.0302	6.31	7.9218		7.2359
17	7.8875	7.6132	6.6873	5.9328	8.1619	7.8875	7.1674
18	7.6818	7.9218	6.9273	6.1728	8.1962		7.0988
19	7.7504	7.8532	7.0988	6.2414	8.1276	7.2017	
20	8.5048	8.6077	7.7161	6.8244	8.2305		
21	8.7106	8.5048	7.3045	7.5789	8.2305	8.4705	
22	9.0192	8.3676	7.6132	7.8189	8.7106		
23	9.3964	9.3279		9.4993	9.2936	9.6365	8.2648
24	9.6022	9.9794	9.1221	8.6077	9.8766	9.5336	9.465
Max	9.6022	9.9794	9.2593	9.4993	9.8766	9.6365	9.465
Min	5.8642	5.7956	4.8011	5.0412	6.2414	5.6584	7.0645
Avg	7.6775	7.9404	6.9288	6.5277	7.9204	7.5189	7.5552

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 303 / 22 KV Airoli - II

HV Express Feeder

Feeder KV- 22 / INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9831	1.3375	1.3717	1.3032	1.4746	1.5089	
2	1.4403	1.2346	1.3032	1.2689	1.3717	1.4746	
3	1.3717	1.0974	1.2689	1.2346	1.3032	1.3717	1.3717
4	1.3032	1.0288	1.3032	1.2003	1.2346	1.3032	
5	1.2346	.9602	1.2346	1.2346	1.2003	1.3375	
6	1.2003	1.0288	1.2003	1.2346	1.2003	1.2689	
7	1.166	1.1317	1.1317	1.166	1.1317	1.2346	
8	1.166	1.0288	1.0631	1.0974	1.1317	1.166	
9	1.0974	1.0631	1.0974	1.0631	1.0974	1.1317	1.0974
10	1.2003	1.0974	1.1317		1.166	1.0974	1.0974
11	1.2003	1.1317	1.0974	1.2346	1.166	.7316	1.0974
12	1.166	1.0974	.7316	1.166	1.0974	1.0631	1.0631
13	1.1317	1.0974	.7316	1.0631	1.0974	.6859	1.0974
14	1.0974	1.1317	1.0974	1.0974	1.0631	1.0631	1.0288
15	5.487	1.166	1.1317	1.1317	1.1317	1.0974	1.0631
16	5.4184	1.0974	1.0974	1.2346	1.1317		
17	5.3155	1.0631	1.0631	1.1317	1.0631	1.0288	
18	1.0974	1.0974	1.0974	1.0631	1.166		
19	1.0974	1.2346	1.2003	1.0974	1.2346	.7316	
20	1.2346	1.3032	1.3032	1.2346	1.3717		
21	1.3717	1.3375	1.3717	1.3717	1.3717	1.406	
22	1.5432	1.4403	1.5089	1.5089	1.5089		
23	1.6118	1.5089		1.6461	1.6118	1.6461	.7545
24	1.4746	1.5432	1.4746	1.5089	1.6118	1.5775	1.0288
Max	5.487	1.5432	1.5089	1.6461	1.6118	1.6461	1.3717
Min	.9831	.9602	.7316	1.0631	1.0631	.6859	.7545
Avg	1.7671	1.1774	1.1744	1.2301	1.2474	1.1963	1.0700

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 304 / 22 KV Rabale MIDC

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9835	3.4294	3.0864	3.4637	3.1207	3.7723	
2	1.8976	3.3265	3.1207	3.0864	3.0521	3.6694	
3	2.8121	3.1893	3.0864	3.0521	3.0178	3.5322	3.6351
4	2.7435	3.0864	3.0178	2.9492	3.0864	3.3608	
5	2.8807	3.0178	2.9835	3.0521	3.1893	3.3265	
6	2.915	2.915	3.0178	3.1207	3.2579	3.2579	
7	2.9835	2.9835	3.0864	3.1893	3.3608	3.0178	
8	3.0864	3.0864	3.7723	3.6008	4.0124	4.0466	
9	4.1838	3.2579	5.0755	4.1838	4.7325	5.4184	5.487
10	5.1783	3.6694	6.4472		6.3786	6.5501	5.144
11	5.7956	4.1152	6.653	5.3498	6.5844	7.0645	5.487
12	5.5899	4.0466	4.3896	5.5899		6.7901	5.4184
13	5.487	3.7723	5.1783	4.0466	.8916	5.5213	5.5213
14	5.6927	4.0466	5.6584	5.2812	5.487	6.7901	5.6242
15	5.487	3.9781	6.2414	5.1783	5.8299	6.6187	5.487
16	5.4184	1.8519	6.3443	5.1097	5.6927		5.3498
17	5.3155	3.3608	6.1043	4.4239	5.2126	6.6873	5.0755
18	5.487	3.4979	5.1097	3.8752	4.904		4.8011
19	5.0069	3.2579	4.6639	3.738	4.6639	5.2126	
20	4.4239	3.3265	4.321	3.5665	4.4582		
21	3.9095	3.3608	4.1495	3.3608	4.3896	4.321	
22	3.5322	3.2922	2.5606	3.1207	3.9095		
23	3.3951	3.0178		3.2236	3.4637	3.6008	3.1893
24	3.2579	3.6351	3.155	3.5665	3.2236	3.8409	3.9438
Max	5.7956	4.1152	6.653	5.5899	6.5844	7.0645	5.6242
Min	1.8976	1.8519	2.5606	2.9492	.8916	3.0178	3.1893
Avg	4.1443	3.3551	4.401	3.8752	4.1704	4.8200	4.9357

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 305 / 22 KV Ghansoli

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	8.1276	8.6763	8.2991	8.2305	8.2648	7.8189	8.5048
2	7.7504	8.2648	8.1619	8.1276	7.9904	7.7504	
3	7.476	7.9218	7.6818	5.0983	7.476	7.6818	7.4074
4	7.2359	7.1674	7.2702	7.2359	7.3731	7.5789	
5	6.8587	6.7901	7.3388	6.893	7.1674	7.3388	
6	7.0302	6.7215	7.4074	6.8587	6.9616	7.2359	
7	6.9273	6.9616	6.9959	6.7901	6.8587	7.0645	
8	7.1331	6.7558	7.1331	6.8587	6.8244	7.1331	
9	6.9273	6.5158	7.0645	6.9273	6.893	7.0988	6.7558
10	6.5844	6.1728	6.6873		6.4815	6.7215	6.2414
11	6.4129		6.3443	6.6187	6.2071	6.2414	6.0014
12	6.4472		6.2757	6.5158	6.0357	6.1728	5.8299
13	6.4129	.0309	6.2414	6.3786	5.9328	6.1728	5.8642
14	6.3786		6.3443	6.5844	5.8985	5.8985	5.9328
15	6.2757	7.1331	6.3786	6.6873	6.07	6.4129	5.8299
16	6.2071	6.7215	6.1728	6.7901	6.07		5.5899
17	6.1386	6.653	5.9328	6.4129	5.8985	6.4472	5.487
18	6.4472	6.9273	6.3443	6.5501	6.7215		5.3498
19	7.0645	7.7161	7.2702	6.7215	7.9561	7.0302	
20	8.1619	8.5734	8.2648	6.9616	8.3676		
21	8.7792	8.5734	7.6475	7.5103	8.2305	8.9163	
22	8.9163	8.4705	8.1276	8.3676	8.4705		
23	8.8477	8.9163		8.3676	8.3333	9.0878	8.8477
24	8.5734	8.5048	8.5048	8.4362	8.5048	7.8875	5.6699
Max	8.9163	8.9163	8.5048	8.4362	8.5048	9.0878	8.8477
Min	6.1386	.0309	5.9328	5.0983	5.8985	5.8985	5.3498
Avg	7.2131	7.1509	7.1256	7.0401	7.1245	7.1845	6.3794

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 306 / 22 KV Railway -II

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3201	.4801	.4801		.4801	.4801	
2	.4801	.4801	.4801		.4801	.4801	
3	.4801	.4801	.4801		.4801	.4801	.4458
4		.4801	.4458		.4801	.4801	
5		.4801	.4801	.4458	.4801	.4801	
6		.4801	.4801		.4801	.4801	
7		.4458	.4458	.4458	.4458	.4458	
8	.4458	.5144	.4458	.4458	.4458	.4458	
9	.4801	.5144	.4458	.4458	.4458	.4801	.2972
10	.4801	.5144	.4458		.4801	.4801	.4801
11	.5144	.5144	.5144	.4458	.4801		.4801
12	.5144	.5144	.3201	.4458	6.0357		.4801
13	.5144	.5144		.4458	.4801	.5144	.4801
14	.5487	.5144	.4801	.4458	.4801	.4801	.4801
15	.5144	.5144	.5144	.4458	.5144	.5144	.4801
16	.5144	.5144	.4801	.4458	.5144		.4801
17	.5144	.4801	.5144	.4458	.5144	.4801	.4458
18	.4801	.4458	.4458	.4458	.5144		.4115
19	.4801	.4458	.4458	.4458	.4801	.3772	
20	.4801	.4801	.4801	.4801	.4801		
21	.4801	.4801	.4458	.4801	.4801	.4801	
22	.5144	.4801	.4458	.4801	.4801		
23	.4801	.4801		.4801	.4801	.4801	.4458
24	.4801	.5144	.4801	.4801	.4801	.4801	.5144
Max	.5487	.5144	.5144	.4801	6.0357	.5144	.5144
Min	.3201	.4458	.3201	.4458	.4458	.3772	.2972
Avg	.4858	.4901	.4635	.4553	.7130	.4744	.4555

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 309 / 22 KV Railway -I

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0864	3.0521	3.2236	3.0864	3.0864	3.155	
2	2.7435	2.8464	3.0864	2.8121	2.915	3.0864	
3	2.6063	2.6749	2.8464	2.572	2.7778	3.0178	2.8121
4	2.4006	2.4348	2.6063	2.5377	2.7092	2.8464	
5	2.4348	2.332	2.572	2.6063	2.572	2.7092	
6	2.3663	2.2977	2.5377	2.4691	2.5377	2.6063	
7	2.2977	2.5034	2.6406	2.6406	2.6063	2.6749	
8	2.2634	2.332	2.4006	2.4691	2.4006	2.2977	
9	2.332	2.2291	2.1948	1.4861	2.2291	2.332	2.1605
10	2.1262	2.0576	2.1605		2.0233	2.1948	2.2291
11	2.1262		1.989	2.1262	2.1948	2.2291	2.1948
12	2.2291		2.2291	2.1605	2.2634	2.2291	2.2291
13	2.332		1.6004	2.2291	2.2291	2.2634	2.2634
14	2.4006		2.2291	2.2977	2.4006	2.4006	2.2977
15	2.2977		2.1605	2.0919	2.4006	2.2291	2.2634
16	2.2291		2.2291	1.9547	2.1605		2.1605
17	2.0919	2.8121	2.0919	2.1605	2.1262	1.4632	2.0576
18	2.0919	1.749	2.1262	2.1262	2.332		2.0919
19	2.1262	2.8807	2.2291	2.1948	2.6063	2.1605	
20	2.572	3.1207	2.572	2.4691	2.8121		
21	2.9492	3.0178	2.915	2.9492	2.9492	1.9433	
22	3.1207	3.2922	3.1207	3.1207	3.2236		
23	3.4294	3.5665		3.2236	3.4637	3.6008	3.3608
24	3.2579	3.2236	3.3608	3.2579	3.2236	3.2922	3.0178
Max	3.4294	3.5665	3.3608	3.2579	3.4637	3.6008	3.3608
Min	2.0919	1.749	1.6004	1.4861	2.0233	1.4632	2.0576
Avg	2.4963	2.6901	2.4836	2.4801	2.5935	2.5366	2.3953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 311 / 22 KV Cidco II

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4746	1.3717	1.3717	1.3717	1.406	3.0864	
2	1.2346	1.2346	1.3032	1.2346	1.3032	2.9835	
3	1.2003	1.0974	1.2346	1.2003	1.2346	2.8121	2.4691
4	1.166	1.0288	1.166	.9945	1.0974	2.4348	
5	1.0974	1.0631	1.0288	1.0288	1.0288	2.2291	
6	1.166	1.2003	1.0974	1.0631	1.0974	2.1605	
7	1.1317	1.3717	1.0974	1.3032	1.166	2.2977	
8	1.2346	1.3375	1.2346	1.166	1.2346	2.1948	
9	1.2346	1.2689	1.2689	1.0288	1.3032	2.1262	2.1262
10	1.5432	1.1317	1.5775		1.8519	2.4006	2.4691
11	.6859	1.2346	1.3032	1.0974	1.6118	2.6063	1.9547
12	1.1317		1.5432	1.2346	1.5775	2.4691	2.0576
13	1.2003	1.1317	1.5432	1.3717	1.749		2.0919
14	1.2689	1.6118	1.3717	1.2346	1.6461	2.6063	2.1262
15	1.3032	1.3717	1.3032	1.3375	1.6118	2.2977	2.0576
16	1.3375	1.4746	1.3032	1.4403	1.7147		1.8176
17	1.3717	1.0288	1.3032	1.1317	1.3032	2.2634	1.7147
18	1.0631	1.0974	1.1317	1.166			1.6118
19	1.2346	1.166	.9831	1.2003		2.1262	
20	1.3032	1.406	1.2689	1.3032	2.915		
21	1.3717	.9945	1.2346	1.3717	2.6749	2.5034	
22	1.6804	.9945	1.6461	1.4403	3.0864		
23	1.749	1.166		1.406	3.3951	3.1207	2.9492
24	1.5432	1.4403	1.4746	1.4746	1.5089	3.1893	2.8121
Max	1.749	1.6118	1.6461	1.4746	3.3951	3.1893	2.9492
Min	.6859	.9945	.9831	.9945	1.0288	2.1262	1.6118
Avg	1.2803	1.2271	1.2952	1.2435	1.7053	2.5215	2.1737

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 312 / 22 KV Vodafone

HV Non-Express Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	1.8176	.823		.8916	1.0974	
2	1.166	.9945	.8573		.823	.823	
3	1.166	.8573	.823	.823	.8573	.8916	1.2003
4	1.0288	.8916	.823		.8573	.8573	
5	.823	.8573	.823		.7888	.9602	
6	.9259	.7888	.823		1.0288	1.166	
7	1.2003	.823	1.2003	1.3375	1.2346	.823	
8	.823	.8916	1.166	.823	1.0288	1.2346	
9	1.2346	.8573	.8573	.8573	.8573	.8573	1.2003
10	.8573	.9259	.8916	.823	.8916	1.2346	.8573
11	.663	.8573	.9945	.8573	1.2689	.6401	1.2346
12	.8916	.8573	1.2003	.8916	.8573	1.2689	
13	.823	.8573	1.2003	.8573	1.2689	.8916	
14	.8573	.8573		1.2346	.8916	1.2346	
15	.823	1.2689	1.2346	1.0288	1.3032	.5944	
16	.8573	.8573		.8573	.8916		
17	.8916	1.2003	.8573	.823	.8916	3.3265	.7888
18	.8573	.8573	1.2346	.8573	.8916		1.1317
19	1.2346	.8573	.8573	.8573	1.0288	.8573	
20	1.0288	1.0974	1.2346	.8573	1.2689		
21	.8573	.8573	.823	.823	.8573	1.3032	
22	1.2346	.9602	.823	.8916	1.2003		
23	.823	.823		1.2346	.8573	1.2003	.9945
24	1.2003	1.2346	.8573	.8573	.8573	1.2003	.8573
Max	1.2346	1.8176	1.2346	1.3375	1.3032	3.3265	1.2346
Min	.663	.7888	.823	.823	.7888	.5944	.7888
Avg	.9621	.9645	.9716	.9259	.9831	1.1231	1.0331

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641] BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 602 / 100 KV Mukund -II

EHV Express Feeder

Feeder KV- 100 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
23	31.176
Max	31.176
Min	31.176
Avg	31.176

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641] BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 604 / 100KV Sify Technocity

EHV Express Feeder

Feeder KV- 100 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
23	12.4704
Max	12.4704
Min	12.4704
Avg	12.4704

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641] BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 610 / 100 KV Reliable

EHV Express Feeder

Feeder KV- 100 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	23.382
Max	23.382
Min	23.382
Avg	23.382

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641] BU 4641

Substation No/ Name :- 288068 / 220/100/22 KV Patani

Knowledge

Feeder No / Name : 302 / 22 KV KALWA - II

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	6.8587
Max	6.8587
Min	6.8587
Avg	6.8587

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641] BU 4641

Substation No/ Name :- 288068 / 220/100/22 KV Patani

Knowledge

Feeder No / Name : 303 / 22 KV Cidco-I

HV Express Feeder

Feeder KV- 22 / INCOMING

DATE	01-JUN-17
HR	Load (MW)
24	6.1728
Max	6.1728
Min	6.1728
Avg	6.1728

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641] BU 4641

Substation No/ Name :- 288068 / 220/100/22 KV Patani

Knowledge

Feeder No / Name : 304 / 22 KV Newa Garden

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
23	6.8587
Max	6.8587
Min	6.8587
Avg	6.8587

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641] BU 4641

Substation No/ Name :- 288068 / 220/100/22 KV Patani

Knowledge

Feeder No / Name : 308 / 22KV Mumbra-II

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	10.2881
Max	10.2881
Min	10.2881
Avg	10.2881

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641] BU 4641

Substation No/ Name :- 288068 / 220/100/22 KV Patani

Knowledge

Feeder No / Name : 309 / 22KV Mumbra - I

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	10.2881
Max	10.2881
Min	10.2881
Avg	10.2881

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641] BU 4641

Substation No/ Name :- 288068 / 220/100/22 KV Patani

Knowledge

Feeder No / Name : 310 / 22 KV Times of India

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	1.0288
Max	1.0288
Min	1.0288
Avg	1.0288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641] BU 4641

Substation No/ Name :- 288068 / 220/100/22 KV Patani

Knowledge

Feeder No / Name : 312 / 22 KV Sandoz

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
23	2.0576
Max	2.0576
Min	2.0576
Avg	2.0576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641] BU 4641

Substation No/ Name :- 289005 / 400/220/100/22 KV Kalwa SS

Feeder No / Name : 808 / 220 KV Kalwa Siemens EHV Express Feeder

Feeder KV- 220 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
23	34.2936
Max	34.2936
Min	34.2936
Avg	34.2936

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 201 / 11 KV Multi Soft MBP stn Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	06-JUN-17
HR	Load (MW)
19	.7811
Max	.7811
Min	.7811
Avg	.7811

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 202 / 11 KV Reliance

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6668	.6859	.6668	.4763	.7049	.724
2	.6859	.6287	.6287	.6668	.4763	.6859	.6859
3	.6668	.6287	.6287	.6478	.4763	.6859	.6668
4	.6668	.6287	.6287	.6287	.4382	.6859	.6668
5	.6478	.6287	.6287	.6287	.4763	.6859	.6668
6	.6478	.6287	.6287	.6478	.7049	.6859	.6668
7	.6668	.6668	.6478	.6478	.6668	.6859	.6859
8	.7811	.6668	.724	.6859	.8383	.8002	.8002
9	1.105	1.105	.8573	.7049	1.1812	1.1812	1.1622
10	1.3527	1.3336	1.0669	.6478	1.448	1.3908	1.2955
11	1.467	1.4098	1.105	.6478	1.467		1.3717
12	1.3336	1.3908	1.0669	.6478	1.4289	1.467	1.3336
13	1.2955	1.3908	.9717	.6668	1.2765	1.3336	1.2574
14	1.3717	1.3717	.9907	.6668	1.3527		1.3336
15	1.467	1.4289	.9907	.6859	1.5242	1.4098	1.3527
16	1.3527	1.3717	.9907	.743	1.4861	1.3908	1.2765
17	1.3717	1.3146	.8764	.6668	1.5051	1.2955	1.2003
18	1.2003	1.2193	.8192	.6478	1.2955	1.2765	1.1431
19	1.1622	1.105	.8764	.7049	1.2003	1.1241	1.0479
20	1.0479	1.0098	.8383	.7621	1.0479	1.0288	.9717
21	.8573	.9145	.8002	.743	.8764	.8764	.8383
22	.7621	.8383	.724	.724	.8383	.8192	.8002
23	.7621	.8002	.6859	.6859	.8002	.8002	.743
24	.724	.724	.724	.6859	.6668	.7621	.743
Max	1.467	1.4289	1.105	.7621	1.5242	1.467	1.3717
Min	.6478	.6287	.6287	.6287	.4382	.6859	.6668
Avg	1.0034	.9947	.8161	.6771	.9979	.9898	.9764

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 203 / 11 KV Mastek MBP s/stn HV Express Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4382	.4001	.381	.4001	.381	.4001	.4191
2	.4191	.381	.381	.4001	.381	.381	.4191
3	.4191	.381	.381	.4001	.381	.381	.4001
4	.4191	.381	.381	.4001	.381	.381	.4001
5	.4001	.381	.381	.4191	.381	.381	.381
6	.4001	.381	.381	.4001	.381	.381	.4001
7	.7049	.8192	.381	.4191	.5716	.5716	.9335
8	1.0288	1.0479	.4572	.2477	1.1241	1.2003	1.2765
9	1.2193	1.2003	.9335	.4001	1.1812	1.2765	1.2765
10	1.2193	1.2193	.9526	.4382	1.1622		1.2384
11	1.2765	1.2003	.9145	.4382	1.3146		1.3146
12	1.0479	1.1622	.9526	.4572	1.3146	1.3146	1.2574
13	1.1622	1.1622	.9907	.4382	1.2574	1.3527	.9907
14	1.0288	1.1622	.9907	.4382	1.3336		1.1241
15	1.2003	1.2003	.9526	.4191	1.3908	1.3527	1.105
16	1.1622	1.0288	.8573	.4191	1.2765	1.3146	1.1622
17	1.1431	1.1431	.9335	.4191	1.2384	1.2384	1.2574
18	1.0479	1.1431	.5144	.4191	1.2765	1.2765	1.2003
19	1.086	1.105	.4763	.4382	1.2765	1.105	1.0479
20	.6859	.6859	.4572	.4001	.724	.6859	.6478
21	.5716	.5525	.4191	.4382	.6859	.6287	.4572
22	.4572	.5525	.4191	.4001	.5716	.4763	.4763
23	.4572	.4572	.4382	.4001	.5335	.4763	.4382
24	.4191	.4382	.4382	.4191	.381	.4001	.4191
Max	1.2765	1.2193	.9907	.4572	1.3908	1.3527	1.3146
Min	.4001	.381	.381	.2477	.381	.381	.381
Avg	.8089	.8161	.6152	.4112	.8708	.8083	.8351

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 204 / 11 KV Hexaware MBP s/stn HV Express Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.2667	.3048	.2096	.2477	.3239	.3048
2	.3239	.2667	.2667	.2477	.2477	.3048	.2858
3	.3429	.2667	.2667	.2286	.2477	.3048	.2667
4	.3239	.2667	.2667	.2477	.2477	.3048	.2667
5	.3048	.2667	.2667	.2477	.2477	.3048	.2477
6	.2858	.2667	.2667	.2477	.2477	.3048	.2667
7	.2667	.2477	.2667	.2286	.3048	.3048	.3048
8	.6097		.2667	.2667	.6668	.5335	.5525
9	.7811	.7621	.4001	.3239	.7811	.8192	.7049
10	.8192	.8002	.4191	.3048	.8192		.7049
11	.7811	.8002	.4191	.3239	.8192		.8192
12	.8764	.8954	.4191	.2858	.8573	.8192	.8764
13	.8573	.8954	.4191	.3048	.8573	.8383	.8573
14	.9145	.8573	.4382	.3048	.8954		.8383
15	.8764	.7811	.4191	.2858	.8954	.8192	.8192
16	.8764	.8192	.4191	.3048	.9145	.8573	.724
17	.8383	.8002	.4001	.3048	.9145	.8383	.7621
18	.7621	.7049	.4001	.2858	.8573	.8002	.743
19	.6097	.6859	.362	.2858	.8002	.7049	
20	.5335	.4763	.3429	.2667	.5335	.5716	.6668
21	.4763	.4763	.3048	.2858	.5144	.4763	.4001
22	.381	.4191	.2286	.2477	.4572	.4001	.3239
23	.381	.4001	.2477	.2667	.381	.4001	.3239
24	.3429	.3239	.3429	.2286	.2477	.3429	.3239
Max	.9145	.8954	.4382	.3239	.9145	.8573	.8764
Min	.2667	.2477	.2286	.2096	.2477	.3048	.2477
Avg	.5779	.5542	.3397	.2723	.5835	.5416	.5384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 205 / 11 KV Life Cycle

HV Non-Express Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.3239	.3429	.3429	.3048	.362	.362
2	.381	.3239	.3429	.3429	.3048	.3048	.362
3	.381	.3239	.3429	.3429	.3048	.2858	.3429
4	.381	.3239	.3429	.3239	.3048	.2858	.3429
5	.362	.3239	.3429	.3239	.3048	.2858	.3239
6	.3429	.3239	.3429	.3429	.3429	.2858	.3429
7	.381	.3429	.381	.3429	.362	.2858	.4001
8	.4572	.4572	.4382	.362	.4954	.4191	.4382
9	.5144	.4572	.4382	.381	.5716	.5335	.4954
10	.5335	.5525	.4572	.4001	.5906		.5335
11	.5525	.5525	.4763	.4001	.6478		.5335
12	.5906	.5525	.4954	.4001	.6478	.7049	.5525
13	.5716	.5525	.4954	.4001	.6287	.743	.5525
14	.5716	.6668	.4954	.4001	.6287		.5716
15	.5906	.6287	.4954	.4191	.6287	.724	.5906
16	.5525	.6097	.4954	.4191	.6097	.6668	.5335
17	.5525	.6097	.4382	.4191	.6097	.5906	.5335
18	.5144	.5906	.4572	.4191	.5906	.5716	.4954
19	.5335	.6287	.4763	.4382	.5906	.5716	.4954
20	.4954	.6097	.5335	.4382	.5525	.5716	.4572
21	.4382	.5525	.4954	.4572	.4954	.5716	.4191
22	.4191	.5525	.4763	.4763	.4954	.5144	.381
23	.4191	.4382	.4191	.4572	.4763	.5144	.362
24	.4001	.3429	.381	.362	.3048	.4382	.4191
Max	.5906	.6668	.5335	.4763	.6478	.743	.5906
Min	.3429	.3239	.3429	.3239	.3048	.2858	.3239
Avg	.4707	.4850	.4334	.3921	.4914	.4872	.4517

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 206 / 11 KV Aptech

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3048	.3048	.2858	.2858	.3048	.3239
2	.3429	.3048	.3048	.2858	.2667	.3048	.3239
3	.3239	.3048	.3048	.2858	.2858	.3048	.3239
4	.3239	.3048	.3048	.2667	.2858	.2858	.3239
5	.3239	.3048	.3048	.2667	.2858	.2858	.2858
6	.724	.6287	.3048	.2667	.4572	.2858	.5335
7	.8383	.8192	.3429	.2667	.8192	.381	.8573
8	.9335	.8764	.4572	.2858	1.086	.9145	.8954
9	1.0669	1.0288	.5144	.3048	1.1431	1.0288	.9907
10	1.2003	1.1622	.7621	.3239	1.2765		1.1622
11	1.3146	1.1812	.8573	.3239	1.3146		1.2955
12	1.3527	1.2574	.8573	.3429	1.4289	1.3717	1.2574
13	1.3146	1.2574	.8573	.3429	1.3717	1.3336	1.3527
14	1.3717	1.2955	.8383	.362	1.448		1.2765
15	1.4289	1.2955	.8192	.362	1.4289	1.2384	1.2765
16	1.3717	1.2384	.8192	.362	1.3527	1.3336	1.1622
17	1.2193	1.086	.7049	.362	1.2955		1.2193
18	1.1431	1.086	.4954	.3429	1.1431	1.0479	1.0479
19	.9526	.8383	.381	.3048	1.0098	.8954	.9335
20	.8192	.6859	.362	.3429	.8192	.8002	.7621
21	.6287	.6478	.3239	.2858	.5335	.4763	.5716
22	.4954	.5144	.3048	.2858	.4954	.4191	.4382
23	.4382	.381	.3239	.2667	.4001	.3429	.3239
24	.4382	.3048	.3429	.2858	.2858	.362	.3429
Max	1.4289	1.2955	.8573	.362	1.448	1.3717	1.3527
Min	.3239	.3048	.3048	.2667	.2667	.2858	.2858
Avg	.8629	.7962	.5080	.3088	.8550	.6859	.8034

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 207 / 11 KV ML Tower

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953	.0953	.0953	.0953	.0953
2	.0953	.0953	.0953	.0953	.0953	.0953	.0953
3	.0953	.0953	.0953	.0953	.0953	.0953	.0953
4	.0953	.0953	.0953	.0953	.0953	.0953	.0953
5	.0953	.0953	.0953	.0953	.0953	.0953	.0953
6	.0953	.0953	.0953	.0953	.0953	.0953	.0953
7	.0953	.0953	.0953	.0953	.0953	.0953	.0953
8	.0953	.0953	.0953	.0953	.0953	.0953	.0953
9	.0953	.0953	.0953	.0953	.0953	.0953	.0953
10	.0953	.0953	.0953	.0953	.0953		.0953
11	.0953	.0953	.0953	.0953	.0953		.0953
12	.0953	.0953	.0953	.0953	.0953	.0953	.0953
13	.0953	.0953	.0953	.0953	.0953	.0953	.0953
14	.0953	.0953	.0953	.0953	.0953		.0953
15	.0953	.0953	.0953	.0953	.0953	.0953	.0953
16	.0953	.0953	.0953	.0953	.0953	.0953	.0953
17	.0953	.0953	.0953	.0953	.0953	.0953	.0953
18	.0953	.0953	.0953	.0953	.0953	.0953	.0953
19	.0953	.0953	.0953	.0953	.0953	.0953	.0953
20	.0953	.0953	.0953	.0953	.0953	.0953	.0953
21	.0953	.0953	.0953	.0953	.0953	.0953	.0953
22	.0953	.0953	.0953	.0953	.0953	.0953	.0953
23	.0953	.0953	.0953	.0953	.0953	.0953	.0953
24	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Max	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Min	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Avg	.0953	.0953	.0953	.0953	.0953	.0953	.0953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 208 / 11 KV core project

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429		.3048	.3239	.2858	.3239	.3239
2	.3048	.2858	.2858	.2858	.2858	.3048	.3239
3	.3239	.2858	.2858	.2858	.2858	.2858	.3239
4	.3239	.2858	.2858	.2667	.2858	.2858	.3239
5	.3048	.2858	.2858	.2667	.2858	.2858	.3048
6	.3048	.2858	.2858	.2477	.3048	.2858	.3048
7	.2858	.3048	.2858	.2667	.3048	.2858	.2667
8	.2667	.3239	.3239	.2858	.381	.3048	.3048
9	.4572	.4572	.381	.2858	.4572	.4763	.4191
10	.5525	.5335	.4191	.3239	.6097	.5525	.5716
11	.5906	.5716	.4763	.3048	.6097	.6097	.6097
12	.5525	.5525	.4572	.3239	.5906	.6478	.5906
13	.5906	.5525	.4572	.3048	.6478	.5906	.5906
14	.6097	.5525	.4763	.3048	.6287		.5906
15	.5906	.5335	.4572	.3429	.6097	.6097	.5906
16	.5525	.5335	.4382	.3239	.5716	.5906	.5335
17	.5525	.5335	.362	.3048	.5335	.5906	.4954
18	.5335	.4763	.3429	.3239	.5335	.5525	.4763
19	.4572	.4191	.362	.3048	.4954	.4382	.4001
20	.4001	.4191	.3429	.2858	.4382	.4001	.381
21	.381	.4001	.3048	.3239	.381	.381	.362
22	.3429	.3429	.3048	.2667	.381	.362	.362
23	.3429	.3239	.3048	.2858	.381	.3429	.3239
24	.3048	.3429	.3048	.3048	.2858	.3429	.3429
Max	.6097	.5716	.4763	.3429	.6478	.6478	.6097
Min	.2667	.2858	.2858	.2477	.2858	.2858	.2667
Avg	.4279	.4175	.3556	.2977	.4406	.4283	.4215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 209 / 11 KV kk Railway Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2291	2.191	.9526	.6668	.7621	.8002	.7049
2	2.0386	1.9433	.9526	.6097	.6668	.7621	.6668
3	1.8861	1.7147	.9526	.5716	.6668	.6859	.6287
4	1.829	1.7147	.8764	.5144	.5716	.5716	.6478
5	1.7337	1.5242	.8764	.5144	.5716	.5716	.6859
6	1.5242	1.467	.7621	.5144	.5716	.5716	.6478
7	1.5813	1.448	.724	.4954	.5335	.5716	.6668
8	1.448	1.4861	.6287	.5144	.6478	.6478	.5144
9	1.6194	1.4861	.6287	.5335	.7049	.6478	.6097
10	1.7337	1.5242	.8192	.6668	.7811	.7621	.724
11	1.7909	.9717	.9335	.6478	.8002	.7621	.8764
12	1.829		.9335	.8192	.8002	.8002	.8764
13	1.9243		.9145	.6478	.743	.8573	.8573
14	1.7528		.9526	.6478	.7621		.7621
15	1.848	.4954	.9145	.8002	.8954	.9145	.724
16	1.8099	.8954	.8573	.743	.8954	.743	.7811
17	1.6766	.8383	.8954	.743	.8002	.8954	.6668
18	1.8099	.8954	.8954	.7811	.8192	.6859	.7811
19	1.8861	.8764	.9526	.9145	.9335	.7811	.8192
20	1.9624	.9907	.9526	.8383	.9907	.9145	.8573
21	2.0957	.8764	.9335	.743	.9717	.9717	.8383
22	2.2862	.9526	.9526	.7621	.9717	.8764	.8954
23	2.5339	.8383	.8573	.9717	.9717	.8573	.8573
24	2.5339	2.4768	.9526	.8383	.8002	.9526	.7811
Max	2.5339	2.4768	.9526	.9717	.9907	.9717	.8954
Min	1.448	.4954	.6287	.4954	.5335	.5716	.5144
Avg	1.8901	1.3146	.8780	.6875	.7764	.7654	.7446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 211 / 11 KV Rupa HT SS

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.1524	.3048	.1524	.1143	.3048	.3239
2	.3048	.1524	.3048	.1524	.1143	.2667	.3048
3	.3048	.1524	.3048	.1524	.1143	.2667	.3048
4	.3239	.1524	.3048	.1143	.1143	.2667	.3048
5	.3239	.1524	.3048	.1143	.1143	.2667	.3048
6	.3239	.1524	.3048	.1143	.1143	.2667	.3048
7	.3048	.1524	.3048	.1143	.3048	.2667	.3048
8	.4001	.1905	.3048	.3048	.381	.4001	.381
9	.5335	.2286	.381	.3048	.4954	.4763	.4954
10	.5335	.3048	.4572	.1143	.5335	.4954	.5144
11	.5335	.3048	.4572	.3048	.5525	1.0098	.5716
12	.5716	.3429	.4572	.3048	.5716	.6097	.5335
13	.5716	.3429	.4572	.3239	.5335	.6097	.5335
14	.5716	.3429	.4382	.3239	.5144		.5906
15	.5525	.4954	.4382	.3048	.5716	.5716	.5144
16	.5525	.4954	.4191	.3239	.5525	.5906	.5144
17	.5144	.4954	.381	.3239	.5335	.5716	.4763
18	.5525	.4954	.4001	.3429	.5335	.5335	.4763
19	.3048	.4382	.362	.3048	.4763	.4572	.4572
20	.2667	.381	.3239	.3048	.4382	.4382	.381
21	.1905	.362	.3239	.3048	.381	.381	.4001
22	.1524	.3239	.3048	.3048	.381	.3429	
23	.1524	.3239	.3239	.3048	.3429	.3239	
24	.3239	.1524	.3048	.1524	.1524	.3048	.3048
Max	.5716	.4954	.4572	.3429	.5716	1.0098	.5906
Min	.1524	.1524	.3048	.1143	.1143	.2667	.3048
Avg	.3945	.2953	.3612	.2445	.3723	.4357	.4226

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 212 / 11 KV Rupa SS - 3

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.4572	.4572	.4382	.4001	.4382	.4954
2	.4954	.4572	.4191	.4191	.4001	.381	.4763
3	.4382	.4572	.4191	.4382	.4001	.381	.4572
4	.4382	.4191	.4191	.4191	.4001	.381	.4572
5	.4191	.4572	.4191	.4191	.4001	.381	.4572
6	.4382	.4572	.4191	.4382	.4001	.381	.4382
7	.4954	.4572	.4191	.4382	.4572	.4572	.5144
8	.6668	.6478	.4954	.4572	.6859	.6287	.6478
9	.8954	.4572	.6097	.4763	.9526	.9145	.8954
10	1.086	.4572	.6859	.4954	1.0479	.9907	.9717
11	.9907	.9526	.6668	.4763	1.086	1.0098	1.0098
12	.9907	.9526	.6859	.4572	1.0669	1.086	.9717
13	.9907	.9526	.724	.4954	1.0288	1.0288	.9526
14	.9907	.9907	.724	.4954	1.0288		.9907
15	1.0479	1.0288	.743	.4572	1.0479	1.086	1.0098
16	1.0479	1.0288	.6668	.4763	1.0288	1.0479	1.0098
17	.9907	.9717	.6478	.4572	.9907	.9907	.9526
18	.9526	.8764	.6097	.4572	.9526	.9717	.8192
19	.6859	.6478	.5335	.4191	.7049	.7049	.6668
20	.5716	.5906	.4954	.4382	.5906	.5906	.4954
21	.4954	.4954	.4572	.381	.5144	.5144	
22	.4763	.4572	.4382	.4001	.4954	.5144	
23	.4572	.4763	.4382	.4191	.4763	.5144	
24	.5144	.4572	.4763	.4382	.4191	.4763	.4954
Max	1.086	1.0288	.743	.4954	1.086	1.086	1.0098
Min	.4191	.4191	.4191	.381	.4001	.381	.4382
Avg	.7113	.6501	.5446	.4461	.7073	.6900	.7231

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 213 / 11 KV Rupa SS - 4

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002	.8764	.8002	.7811	.7621	.8192	.8192
2	.8192	.8764	.8002	.7811	.7621	.7621	.8002
3	.8002	.8383	.8002	.7811	.7621	.7621	.8002
4	.7811	.8383	.8002	.7621	.7621	.7621	.8002
5	.8002	.8764	.8002	.7811	.7621	.7621	.8002
6	.7811	.8764	.8002	.7621	.7621	.7621	.7811
7	.7811	.8764	.8002	.7811	.8002	.8954	.8002
8	1.0098	1.0669	.8954	.8002	.9907	.9907	1.0098
9	1.2003	1.2193	.9907	.8192	1.3146	1.1431	1.1812
10	1.448	1.4861	1.2193	.8383	1.5623	1.5051	1.448
11	1.5051	1.448	1.2384	.8573	1.5623	1.5813	1.4861
12	1.5242	1.448	1.2003	.8573	1.5813	1.6004	1.467
13	1.467	1.448	1.1812	.8383	1.3717	1.4861	1.4861
14	1.4861	1.448	1.1622	.8383	1.5051		1.467
15	1.5242	1.448	1.1622	.7621	1.5051	1.4861	1.4861
16	1.467	1.448	1.1812	.8383	1.5432	1.467	1.467
17	1.448	1.3527	1.1622	.8192	1.4289	1.467	1.3717
18	1.3717	1.2765	1.0669	.7811	1.3336	1.3908	1.3336
19	1.2193	1.0288	.9526	.7811	1.1812	1.1241	1.0669
20	1.105	.9145	.8192	.7621	.9907	.9907	1.0669
21	.9526	.8764	.7811	.7621	.8954	.9145	
22	.9335	.8192	.7811	.7621	.8573	.8764	
23	.9145	.7811	.7811	.7621	.8383	.8573	
24	.8383	.9145	.8002	.7811	.7621	.8192	.8002
Max	1.5242	1.4861	1.2384	.8573	1.5813	1.6004	1.4861
Min	.7811	.7811	.7811	.7621	.7621	.7621	.7811
Avg	1.1241	1.1034	.9574	.7954	1.1082	1.0967	1.1304

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 214 / 11 KV Rupa SS - 6

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1905	.1905	.1905	.1905	.2286
2	.2286	.1905	.1905	.1905	.1905	.1905	.2286
3	.1905	.1905	.1905	.1524	.1905	.1905	.2286
4	.1905	.1905	.1905	.1524	.1905	.1905	.2286
5	.1905	.1905	.1905	.1524	.1905	.1905	.1905
6	.1905	.1905	.1905	.1524	.1905	.1905	.1905
7	.1905	.1905	.1905	.1905	.2286	.1905	.2286
8	.3048	.3429	.3048	.1905	.362	.3048	.3239
9	.4001	.4191	.3048	.2286	.4382	.4191	.362
10	.4191	.381	.362	.2286	.4572	.4382	.4001
11		.2667	.362	.2286	.4763	.4572	.4382
12	.4572	.4954	.4191	.2286	.5144	.4954	.4382
13	.4954	.4954	.4572	.2286	.4763	.4954	.4954
14	.4763	.5335	.4382	.2286	.4763	.4954	.4954
15		.5335	.4191	.2667	.4572	.4763	.4954
16	.4191	.4763	.381	.2286	.4572	.4572	.4572
17	.4382	.381	.3048	.2286	.4382	.4191	.4191
18	.4572	.4382	.3048	.2286	.4191	.4572	.381
19	.4191	.4191	.3048	.2286	.4191	.4382	.4382
20	.381	.381	.3048	.2286	.4191	.3429	.3239
21	.3429	.362	.3048	.2286	.3048	.3048	
22	.2858	.3429	.3048	.2286	.3048	.3048	
23	.2667	.2667	.2667	.1905	.3048	.3048	
24	.2286	.2286	.2286	.2286	.1905	.3048	.2286
Max	.4954	.5335	.4572	.2667	.5144	.4954	.4954
Min	.1905	.1905	.1905	.1524	.1905	.1905	.1905
Avg	.3256	.3374	.2961	.2096	.3453	.3437	.3438

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 301 / 22 Kv O/G Indian Express HV Express Feeder
Feeder KV- 22 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1905		.381	.1905	
2	.1905	.1905	.1905	.1905	.381	.1905	.1905
3	.1905	.1905	.1905		.381	.1905	
4	.1905	.1905	.1905	.1905	.381	.1905	
5	.1905	.1905	.1905	.1905	.1905	.1905	
6	.1905	.1905	.1905	.1905	.1905	.1905	.1905
7	.1905	.1905	.1905	.1905	.1905	.1905	
8	.1905	.1905	.1905	.1905	.1905	.1905	.1905
9	.1905	.1905		.1905	.1905		.1905
10	.1905	.1905	.1905	.1905	.1905	.1905	.1905
11	.1905	.1905	.1905	.1905	.1905		.1905
12	.1905	.1905	.1905	.1905	.1905	.1905	.1905
13		.1905	.1905	.1905	.1905	.1905	.1905
14		.1905	.1905	.1905	.1905		.1905
15	.1905	.1905	.1905	.1905	.1905		.1905
16	.1905	.1905	.1905	.1905	.1905	.1905	.1905
17	.1905	.1905	.1905	.1905	.1905	.1905	.1905
18	.1905	.1905		.1905	.1905		
19	.1905	.1905	.1905	.1905	.1905	.1905	
20	.1905			.1905	.1905		
21	.1905			.1905		.1905	
22	.1905	.1905		.1905			
23	.1905		.1905	.1905	.1905	.1905	
24	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Max	.1905	.1905	.1905	.1905	.381	.1905	.1905
Min	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Avg	.1905	.1905	.1905	.1905	.2251	.1905	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 302 / 22 Kv L&T I

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	07-JUN-17
HR	Load (MW)
24	.1905
Max	.1905
Min	.1905
Avg	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 303 / 22Kv O/G Electronic Sadan HV Express Feeder
Feeder KV- 22 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.7621	.7621		.7621	.7621	
2	.7621	.7621	.7621	.7621	.7621	.7621	.7621
3	.7621	.7621	.7621		.7621	.7621	
4	.7621	.7621	.7621	.7621	.7621	.7621	
5	.7621	.7621	.7621	.7621	.7621	.7621	
6	.7621	.7621	.7621	.7621	.7621	.7621	.7621
7	.7621	.7621	.7621	.7621	.7621	.7621	
8	.7621	.7621	.7621	.7621	.7621	1.1431	.7621
9	1.1431	1.5242		.7621	1.9052		1.9052
10	1.9052	1.9052	1.1431	.7621	1.9052	1.3336	1.9052
11	1.9052	1.9052	1.1431	.7621	1.9052		1.9052
12	1.9052	1.9052	1.1431	.7621	1.9052	1.3336	1.9052
13		1.9052	1.1431	.7621	1.9052	1.3336	1.9052
14		1.9052	1.1431	.7621	1.9052		1.9052
15	1.9052	1.9052	1.1431	.7621	1.9052		1.9052
16	1.9052	1.9052	1.1431	.7621	1.9052	1.5242	1.9052
17	1.9052	1.9052	1.1431	.7621	1.9052	1.5242	1.9052
18	1.5242	1.5242		.7621	1.9052		
19	1.5242	1.3336	.7621	.7621	1.5242	1.3336	
20	1.1431			.7621	1.1431		
21	1.1431			.7621		.9526	
22	.7621	.7621		.7621			
23	.7621		.7621	.7621	.7621	.7621	
24	.7621	.7621	.7621	.7621	.7621	.7621	.7621
Max	1.9052	1.9052	1.1431	.7621	1.9052	1.5242	1.9052
Min	.7621	.7621	.7621	.7621	.7621	.7621	.7621
Avg	1.1951	1.2974	.9225	.7621	1.3337	1.0198	1.5535

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 304 / 22Kv Hindustan Platinum

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.7621	
2				.7621	.381
3				.7621	
4				.7621	.381
5				.7621	
6				.7621	
7				.7621	
8				.7621	.381
9					.5716
10			1.1431	.9526	.5716
11			1.1431		.5716
12			1.1431	.9526	.5716
13		.1905	1.1431	.9526	.5716
14	1.1431		1.1431		.5716
15			1.1431		.5716
16			1.1431	.7621	.5716
17			1.1431	.7621	.5716
18			.7621		
19			.7621	.7621	
20			.7621		
21				.7621	
23			.7621	.381	
24				.7621	.381
Max	1.1431	.1905	1.1431	.9526	.5716
Min	1.1431	.1905	.7621	.381	.381
Avg	1.1431	.1905	1.0161	.7733	.5130

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 306 / 22KV L&T - II

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.381		.381	.381	
2	.381	.381	.381	.381	.381	.381	.381
3	.381	.381	.381		.381	.381	
4	.381	.381	.381	.381	.381	.381	
5	.381	.381	.381	.381	.381	.381	
6	.381	.381	.381	.381	.381	.381	.381
7	.381	.381	.381	.381	.381	.381	
8	.381	.381	.381	.381	.381	.381	.381
9	.7621	.381			.7621		.381
10	.7621	.381	.381	.381	.7621	.5716	.381
11	.381	.381	.381	.381	.7621		.381
12	.381	.381	.381	.381	.7621	.5716	.381
13		.381	.381	.381	.7621	.5716	.381
14		.381	.381	.381	.7621		.381
15	.381	.381	.381	.381	.7621		.381
16	.381	.381	.381	.381	.7621	.5716	.381
17	.381	.381	.381	.381	.7621	.5716	.0381
18	.381	.381		.381	.7621		
19	.381	.381	.381	.381	.7621	.5716	
20	.381			.381	.381		
21	.381			.381		.5716	
22	.381	.381		.381			
23	.381		.381	.381	.381	.381	
24	.381	.381	.381	.381	.381	.381	.381
Max	.7621	.381	.381	.381	.7621	.5716	.381
Min	.381	.381	.381	.381	.381	.381	.0381
Avg	.4156	.381	.381	.381	.5716	.4595	.3546

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 307 / 22 kv CTRLS

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6385	1.6004	1.7147		1.5242	1.5242	
2	1.6385	1.6004	1.7147	1.7147	1.5242	1.5242	1.5242
3	1.6385	1.6004	1.7147		1.5242	1.5242	
4	1.6385	1.6004	1.7147	1.7147	1.5242	1.5242	
5	1.6385	1.6004	1.7147	1.6766	1.5242	1.5242	
6	1.6385	1.6004	1.7147	1.6766	1.5242	1.5242	1.5242
7	1.6385	1.6004	1.7147	1.6766	1.5242	1.5242	
8	1.6385	2.5911	1.7528	1.6766	1.5623	1.5623	1.5242
9	1.6385	2.6673		1.6766	1.5623		1.5623
10	1.6766	2.7054	1.7909	1.7528	1.6004		1.5623
11	1.7147	2.7054	1.7909	1.7528	2.6673		1.6004
12	.6097	2.6673	1.7909	1.7147	2.7435	1.6004	1.6004
13		2.7054	1.7528	1.7147	1.9052	1.5623	1.5623
14		2.7054	1.7528	1.5242	1.7528		1.6004
15	.6097	2.7435	1.7528	1.5242	1.6004		1.6004
16	.6097	2.6673	1.7528	1.5242	.7621	1.6004	1.6004
17	1.4861	2.0195	1.7528	1.5242	.7621	1.6004	1.5623
18	1.3717	1.7909		1.5242	.7621		
19	1.5623	1.7147	1.7528	1.5242	1.5242	1.5242	
20	1.5242			1.5242	1.5242		
21	1.5242			1.5242	1.5242	1.5242	
22	1.5242	1.7147		1.5242	1.5242		
23	1.5242		1.7147	1.5242	1.5242	1.5242	
24	1.6385	1.5242	1.7147	1.7147	1.5242	1.5242	1.5623
Max	1.7147	2.7435	1.7909	1.7528	2.7435	1.6004	1.6004
Min	.6097	1.5242	1.7147	1.5242	.7621	1.5242	1.5242
Avg	1.4601	2.1012	1.7408	1.6229	1.5623	1.5433	1.5682

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 308 / 22 kv Electronic Zone

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0483	2.6673	3.0483		2.2862		
2	3.0483	2.6673	3.0483	2.2862	2.2862		2.2862
3	3.0483	2.6673	3.0483		2.2862	2.2862	
4	3.0483	2.6673	3.0483	2.2862	2.2862	2.2862	
5	3.0483	2.6673	3.0483	2.2862	2.2862	2.2862	
6	3.0483	2.6673	3.0483	2.2862	2.2862	2.2862	2.2862
7	3.0483	2.6673	3.0483	2.2862	2.2862	2.2862	
8	3.0483	3.0483	3.0483	2.2862	2.6673	2.6673	2.2862
9	1.6766	6.0966		2.2862	3.8104		5.3346
10	6.4777	6.0966	5.3346		6.8587		6.8587
11	6.8587	6.4777	5.3346		6.8587		6.8587
12	6.8587	6.4777	5.3346		6.8587	6.8587	6.8587
13		6.4777	5.3346		6.8587	6.8587	6.8587
14		6.4777	5.3346	3.0483	6.8587		6.8587
15	6.8587	6.4777	3.8104	2.6673	6.8587		6.8587
16	6.8587	6.4777	3.8104	2.6673	6.8587	6.8587	6.8587
17	6.8587	6.4777	3.8104	2.6673	6.8587	6.4777	6.8587
18	4.9535	4.5725		2.6673	4.1914		
19	3.8104	3.4294	3.4294	2.6673	4.1914	3.4294	
20	3.4294			2.2862	3.8104		
21	3.0483			2.6673	3.0483	3.0483	
22	3.0483	3.0483		2.6673	3.0483		
23	3.0483		2.6673	2.6673	3.0483	2.6673	
24	3.0483	3.0483	3.0483	2.2862	2.6673	3.0483	2.2862
Max	6.8587	6.4777	5.3346	3.0483	6.8587	6.8587	6.8587
Min	1.6766	2.6673	2.6673	2.2862	2.2862	2.2862	2.2862
Avg	4.1464	4.4455	3.7703	2.4979	4.2232	3.8104	5.3345

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 309 / 22 KV Spare

Urban/Sheddable Urban Feeder

Feeder KV- 22 / OUTGOING

DATE	05-JUN-17
HR	Load (MW)
17	.9526
Max	.9526
Min	.9526
Avg	.9526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 310 / Systime computers EL-207

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1905		.1905	.1905	
2		.1905	.1905	.1905	.1905	.1905	.1905
3	.1905	.1905	.1905		.1905	.1905	
4	.1905	.1905	.1905	.1905	.1905	.1905	
5	.1905	.1905	.1905	.1905	.1905	.1905	
6	.1905	.1905	.1905	.1905	.1905	.1905	.1905
7	.1905	.1905	.1905	.1905	.1905	.1905	
8	.1905	.1905	.1905	.1905	.1905	.1905	.1905
9	.1905	.1905		.1905	.1905		.1905
10	***	.1905	.1905	.1905	.1905	.1905	.1905
11	.1905	.1905	.1905	.1905	.1905		.1905
12	.1905	.1905	.1905	.1905	.1905	.1905	.1905
13		.1905	.1905	.1905	.1905	.1905	.1905
14		.1905	.1905	.1905	.1905		.1905
15	.1905	.1905	.1905	.1905	.1905		.1905
16	.1905	.1905	.1905	.1905	.1905	.1905	.1905
17	.1905	.1905	.1905	.1905	.1905	.1905	.1905
18	.1905	.1905		.1905	.1905		
19	.1905	.1905	.1905	.1905	.1905	.1905	
20	.1905			.1905	.1905		
21	.1905			.1905		.1905	
22	.1905	.1905		.1905			
23	.1905		.1905	.1905	.1905	.1905	
24	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Max	61.8047	.1905	.1905	.1905	.1905	.1905	.1905
Min	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Avg	3.1245	.1905	.1905	.1905	.1905	.1905	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 202 / 11KV KRISHNA TOWER Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17
HR	Load (MW)	Load (MW)
1		.5487
2		.5144
3	.6224	.5144
4	.5281	.5144
5	.4527	.4458
6	.415	.3772
7	.3772	.3429
8	.3772	.3258
9	.3429	.3395
10	.4191	.3961
11	.4191	
12	.4001	
13	.4572	
14	.4572	
15	.5716	
16	.5335	
17	.4458	
18	.4458	
19	.4458	
20	.4973	
21	.4973	
22	.5144	
23	.5487	
24	.6224	.5658
Max	.6224	.5658
Min	.3429	.3258
Avg	.4723	.4441

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 203 / 11KV P/3

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6859	.6859	.7167	.6687	.6516	.7922
2		.6859	.6173	.679	.6344	.6173	.7545
3	.811	.6859	.6344	.6413	.6001	.5487	.6413
4	.7545	.6173	.6173	.6036	.6001	.5144	.6036
5	.7167	.5487	.6173	.5658	.583	.5144	.6036
6	.679	.5144	.6344	.5658	.583	.4458	.6602
7	.6979	.5144	.6344	.6036	.5144	.5144	.7167
8	.6036	.5144	.5144	.6224	.6687	.5487	.547
9	.5144	.5525	.5093	.4458	.463	.5281	.463
10	.5144	.5093	.4715	.463	.4287	.4904	.463
11	.5144	.4715	.4904	.463	.4115	.4715	.4287
12	.4954	.5093	.5093	.463	.4287	.4715	.4287
13	.4954	.5093	.5093	.463	.4287	.4904	.4287
14	.5144	.5281	.4904	.463	.4458	.4904	.4458
15	.5335	.5093	.415	.4973	.4458	.5093	.4287
16	.5144	.5093	.415	.4801	.4287	.4904	.4115
17	.4458	.4287	.4527	.4801	.4287	.4904	.3772
18	.4801	.463	.5281	.4973	.4287	.4904	.4115
19	.4973	.4973	.5658	.4973	.5144	.5658	.463
20	.703	.6516	.679	.6687		.7733	.6516
21	.8916	.6687	.8865	.8745		.9242	.823
22	.7202	.6859	.7356	.703		.7733	.6859
23	.7202	.7373	.811	.7373		.8488	.6859
24	1.9427	.7202	.7373	.7545	.7202	.7202	.8299
Max	1.9427	.7373	.8865	.8745	.7202	.9242	.8299
Min	.4458	.4287	.415	.4458	.4115	.4458	.3772
Avg	.6709	.5716	.5901	.5812	.5213	.5785	.5727

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 204 / 11KV Mathadi HTP Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		3.6008	3.618	3.8477	3.618	3.6694	4.1118
2		3.4294	3.2579	3.5837	3.5322	3.3779	3.81
3	3.8855	3.4294	3.1893	3.3951	3.3951	3.2579	3.5837
4	3.6591	3.4294	3.1207	3.2442	3.155	3.0864	3.3951
5	3.3951	3.0864	3.0178	3.1121	2.9321	2.572	3.1687
6	3.0556	2.7435	2.8635	2.9047	2.7949	2.4006	3.0178
7	2.9235	2.572	2.6406	2.7349	2.6235	2.4348	2.9235
8	2.8858	2.572	2.5549	2.7726	2.5377	2.4006	2.7538
9	2.7625	2.6217	2.6217	2.4177	2.4006	2.6029	2.4006
10	2.5149	2.5086	2.5274	2.2805	2.2805	2.5086	2.2119
11	2.4768	2.3815	2.4897	2.2977	2.0576	2.3577	2.0919
12	2.4196	2.3388	2.4709	2.2291	2.0405		1.989
13	2.4768	2.1091	2.5274	2.1948	2.1262	2.3577	1.9719
14	2.6101	2.2462	2.5274	2.2977	2.1434	2.3954	2.0748
15	2.4196	2.4006	2.4897	2.3491	2.1262	2.4143	2.0576
16	2.2481	2.3491	2.4897	2.5377	2.1262	2.3765	1.9547
17	1.989	2.2119	2.452	2.5206	2.1605	2.3765	1.9719
18	2.4006	2.3148	2.5463	2.3834	2.1948	2.3388	
19	2.5549	2.6749	2.7538	2.5206	2.3834	2.6783	1.989
20	2.8807	2.7606	2.9801	2.9492		3.1687	2.5892
21	3.0693	2.915	3.0178	3.0007		3.2442	2.6406
22	3.275	3.2407	3.3762	3.2065		3.4705	2.8292
23	3.6694	3.7037	3.8855	3.6866		4.1118	3.1893
24	4.3193	3.7723	3.6694	3.9986	3.858	4.2181	4.2816
Max	4.3193	3.7723	3.8855	3.9986	3.858	4.2181	4.2816
Min	1.989	2.1091	2.452	2.1948	2.0405	2.3388	1.9547
Avg	2.9041	2.8089	2.8787	2.8527	2.6243	2.8617	2.7395

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 205 / 11KV Sector-22&23 Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2442	3.0864		1.773	1.6975	1.5604	1.6975
2		2.9492	1.4918	1.6598	1.6289	1.4918	1.6221
3		2.8464	1.4403	1.5466	1.5604	1.406	1.5089
4	3.0933	2.7435	1.3375	1.4335	1.4575	1.3717	1.4335
5	2.7349	2.4006	1.3032	1.3203	1.3032	1.2003	1.358
6	2.4897	2.0919	1.2174	1.2071	1.1831	1.0288	1.3203
7	2.32	2.0919	1.1488	1.1317	1.0631	1.0974	1.2826
8	2.5652	2.1605	1.0974	1.1317	1.1145	1.0974	1.1694
9	2.7054	2.0919	1.1694	1.0117	1.0974	1.1317	.9945
10	1.9814	2.0576	1.1506	.9945	1.0631	1.1128	.9774
11	2.3053	1.2174	1.1317	1.0288	.9602	1.094	.9431
12	2.4196	2.1262	1.1317	.9602	1.0288	1.1128	1.0117
13	2.4006	2.1948	1.1128	.9945	.9945	1.1317	.9259
14	2.5149	1.6804	1.1883	.9945	1.0288	1.1506	.9602
15	2.3815	1.6461	1.1694	1.1317	1.0288	1.2071	.9774
16	2.4768		1.1317	1.1831	1.0288	1.1128	.9431
17	2.0919	1.166	1.094	1.1145	.9602	1.094	.9602
18	2.0748	1.1488	1.1694	1.046	.9602	1.0751	.9431
19	2.0919	1.1317	1.226	1.0974	1.0288	1.2071	.9945
20	2.2977	1.2346	1.3014	1.2174		1.3957	1.166
21	2.3491	1.3546	1.4712	1.406		1.4901	1.2174
22	2.5034	1.4746	1.5655	1.4403		1.6221	1.3203
23	3.2065	1.7318	1.7353	1.6804		1.8484	1.3889
24	3.6969	3.155	1.6975	1.8484	1.7833	1.7833	1.8673
Max	3.6969	3.155	1.7353	1.8484	1.7833	1.8484	1.8673
Min	1.9814	1.1317	1.094	.9602	.9602	1.0288	.9259
Avg	2.5430	1.9905	1.2818	1.2647	1.1986	1.2843	1.2076

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 206 / 11 KV P-2 S/S Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.7147	1.5089	1.6975	1.6804	1.6289	1.8861
2		1.5432	1.406	1.6221	1.6118	1.406	1.6975
3	1.8484	1.5432	1.3717	1.5089	1.5089	1.3717	1.5089
4	1.6032	1.3717	1.3032	1.4335	1.3889	1.2003	1.358
5	1.3203	1.0288	1.2346	1.3203	1.2689	.9259	1.2826
6	1.2071	.8573	1.1145	1.2071	1.0288	.8573	1.1317
7	1.094	.8573	.9259	.9619	.8916	.9259	1.0185
8	1.0562	.8745	.8402	.9619	.8573	.8916	.9619
9	1.0479	.8745	.9054	.823	.8573	.9808	.7716
10	1.2003	.8573	1.2071	.9088	.9945	1.1128	.9602
11	1.2384	.8573	1.3203	1.1145	1.1145	1.2449	1.0974
12	1.3146	1.3375	1.4146	1.1831	1.3375	1.2637	1.1831
13	1.3527	1.1831	1.3014	1.1831	1.2003	1.2826	1.0802
14	1.4098	1.3032	1.5278	1.1317	1.286	1.358	1.2174
15	1.5623	1.4746	1.5089	1.2517	1.2346	1.4146	1.2517
16	1.6194	1.3717	1.5089	1.3032	1.2003	1.4901	1.1831
17	1.286	1.2346	1.5278	1.286	1.2003	1.358	1.0802
18	1.3375	1.2689	1.4146	1.1488	1.1145	1.2637	1.1317
19	1.3375	1.286	1.4901	1.0631	1.2174	1.4146	1.166
20	1.4918	1.3889	1.5466	1.2689		1.5655	1.2689
21	1.5604	1.4403	1.5089	1.406		1.5844	1.286
22	1.6289	1.6461	1.6221	1.5947		1.6975	1.3889
23	1.8347	1.7318	1.7918	1.6461		1.905	1.5089
24	1.9993	1.8004	1.6975	1.7541	1.749	1.8519	2.0182
Max	1.9993	1.8004	1.7918	1.7541	1.749	1.905	2.0182
Min	1.0479	.8573	.8402	.823	.8573	.8573	.7716
Avg	1.4250	1.2853	1.3750	1.2825	1.2371	1.3332	1.2683

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 207 / 11KV SECTOR-19 Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6859	.6516	.6602	.6516	.6516	.7167
2		.6859	.6344	.6413	.6516	.6001	.6413
3	.7733	.6859	.6516	.6036	.6173	.583	.5658
4	.7167	.6859	.6001	.6036	.583	.5487	.5658
5	.679	.6173	.5658	.5658	.583	.5144	.5281
6	.6224	.5487	.5316	.5658	.5658	.4801	.5281
7	.5847	.5144	.5144	.547	.5144	.5144	.547
8	.5658	.5144	.5316	.5281	.5144	.5144	.6036
9	.5906	.5144	.5093	.4973	.4973	.5658	.4287
10	.4763	.5144	.5281	.463	.4458	.4715	.4287
11	.4763	.3944	.5281	.4115	.3944	.4338	.3772
12	.4763	.4763	.5093	.4287	.4115	.4338	.4115
13	.5335	.4115	.547	.4458	.4115	.4338	.3944
14	.5335	.4458	.5093	.4458	.4115	.4904	.4115
15	.5144	.4287	.5093	.463	.4115	.4904	.4115
16	.5525	.4287	.4904	.4801	.4115	.4715	.3944
17	.4458	.4287	.4904	.4801	.3944	.4715	.3772
18	.4801	.4115	.5093	.4458	.3944	.4527	.3772
19	.4973	.4973	.5847	.5144	.4801	.547	.463
20	.5487	.5487	.6413	.6001		.6224	.5658
21	.583	.5658	.6224	.583		.6413	.5658
22	.6516	.6344	.6602	.6344		.7545	.5658
23	.6687	.6687	.7167	.6687		.811	.6173
24	.7922	.7202	.6859	.6979	.6687	.6687	.811
Max	.7922	.7202	.7167	.6979	.6687	.811	.811
Min	.4458	.3944	.4904	.4115	.3944	.4338	.3772
Avg	.5801	.5428	.5718	.5406	.5007	.5486	.5124

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 208 / 11KV BEVERLY PARK -II Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7202	.6516	.6036	.6344	.6344	.7922
2		.6859	.6173	.6036	.6001	.6173	.7167
3	.7356	.6859	.6344	.5847	.583	.583	.6413
4	.7356	.6859	.6173	.5658	.6001	.5487	.6036
5	.7167	.6516	.6173	.5658	.583	.5144	.6602
6	.7167	.583	.6001	.5847	.5487	.5144	.7167
7	.7733	.6173	.6173	.6036	.6516	.583	.7733
8	.7922	.6516	.6344	.6602	.6516	.583	.8299
9	.743	.6173	.6602	.6344	.6173	.679	.6687
10	.724	.6173	.7733	.7202	.6516	.6979	.6516
11	.724	.1886	.7545	.7545	.6344	.5847	.6001
12	.6859	.5658	.7356	.6344	.583	.6036	.6344
13	.6668	.5487	.7167	.703	.5487	.6602	.5316
14	.6859	.5144	.811	.7545	.583	.6413	.6687
15	.6478	.5487	.7545	.6859	.5487	.5847	.6344
16	.6287	.5144	.7167	.7202	.5144	.5658	.5316
17	.5144	.5487	.6413	.6859	.4801	.5281	.463
18	.5658	.5487	.6602	.7202	.4287	.4904	.5316
19	.583	.5658	.6602	.6344	.4458	.6224	.5658
20	.7373	.6687	.7167	.6859		.811	.6687
21	.7716	.6859	.6224	.6859		.8676	.7202
22	.7373	.6344	.6413	.7373		.8676	.703
23	.7373	.6687	.6602	.7373		.9242	.7202
24	.9431	.7373	.6859	.6602	.6516	.703	.9054
Max	.9431	.7373	.811	.7545	.6516	.9242	.9054
Min	.5144	.1886	.6001	.5658	.4287	.4904	.463
Avg	.7075	.6023	.6750	.6636	.5770	.6421	.6639

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 211 / 11 KVMetro Bar Sectore -15 Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1		1.6118	
2		1.3546	
3		1.3717	
4		1.3375	
5		1.3375	
6		1.2003	
8			1.2003
9	1.4918		1.1317
10	1.2689		1.166
11	1.2174		1.1831
12	1.0117		1.2003
13	1.3717		1.2174
14	1.5604		1.1488
15	1.4232		1.3546
16	1.4403		1.166
17	1.4746		1.0802
18	1.4918		.9431
19	1.4575		1.0802
20			1.3203
21			1.286
22			1.4575
23			1.3546
24		1.7833	
Max	1.5604	1.7833	1.4575
Min	1.0117	1.2003	.9431
Avg	1.3827	1.4281	1.2056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 212 / 11 KV KOPERKHIRANE VILLAGE Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	.9526
Max	.9526
Min	.9526
Avg	.9526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 213 / 11KV AVENUE SUPERMART Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	1.1431
Max	1.1431
Min	1.1431
Avg	1.1431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 214 / 11 KV JIMMY TOWER Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	1.9052
Max	1.9052
Min	1.9052
Avg	1.9052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283030 / 22/22KV Krishna Steel

Swt/Stn

Feeder No / Name : 301 / 22 Kv SONY DADC

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2667	.1905	.3429	.1905	.1905	.1905
2	.2286	.2667	.1905	.3429	.1905	.1905	.1905
3	.2286	.2667	.1905	.3429	.1905	.1905	.1905
4	.2286	.2667	.1905	.3048	.1905	.1905	.1905
5	.2286	.2667	.1905	.3048	.1905	.1905	.1905
6	.2286	.2667	.1905	.2667	.1905	.1905	.1905
7	.2286	.2286	.1905	.2667	.1905	.1905	.1905
8	.2286	.3048	.1905	.2286	.1905	.1905	.1905
9	.2667	.3048	.2667	.2286	.1905	.1905	.1905
10	.381	.1905	.2667	.2286	.1905	.1905	.2286
11	.381	.1905	.3048	.2286	.2286	.1905	.2667
12	.381		.3048	.2286	.2286	.1905	.2286
13	.3048	.1905	.3048	.2286	.1905	.1905	.2286
14	.3429	.1905	.3048	.2286	.2286	.1905	.2286
15	.381	.1905	.3048	.2286	.2286	.1905	.2667
16	.381	.1905	.3048	.2286	.2286	.1905	.2667
17	.4572	.1905	.2286	.2286	.2286	.1905	.2286
18	.2286	.1905	.2286	.2286	.1905	.1905	.2286
19	.1905	.1905	.2286	.2286	.1905	.1905	.2286
20	.1905	.1905	.2286	.2286	.1905	.1905	.2286
21	.1905	.1905	.2286	.2286	.1905	.1905	.2286
22	.2286	.1905	.2286	.2286	.1905	.1905	.2286
23	.2667	.1905	.3429	.2286	.1905	.1905	.2286
24	.2667	.2667	.1905	.3429	.2286	.1905	.1905
Max	.4572	.3048	.3429	.3429	.2286	.1905	.2667
Min	.1905	.1905	.1905	.2286	.1905	.1905	.1905
Avg	.2778	.2253	.2413	.2572	.2016	.1905	.2175

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283030 / 22/22KV Krishna Steel

Swt/Stn

Feeder No / Name : 302 / 22 KV BASF

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9052	1.9052	1.7147	1.5242	1.1431	2.0195	1.9052
2	1.9052	1.9052	1.5242	1.5242	1.1431	2.0195	1.9052
3	1.9052	1.9052	1.5242	1.5242	1.1431	2.0195	1.9052
4	1.9052	1.9052	1.5242	1.7147	1.1431	2.0195	1.9052
5	1.9052	1.9052	1.5242	1.7147	1.5242	2.0195	1.9052
6	1.9052	1.7909	1.5242	1.7147	1.9052	1.9052	1.9052
7	1.9052	1.9052	1.5242	1.7147	1.9052	2.0957	1.9052
8	2.2862	2.553	1.5242	1.5242	2.2862	2.8578	2.6673
9	2.8578	2.8959	1.7147	1.1431	2.6673	3.0483	2.8578
10	2.9721	2.8578	1.7147	1.1431	2.8578	3.2388	2.8578
11	2.8959	2.8578	1.9052	1.1431	3.0483	3.2388	2.8578
12	2.934	2.8578	1.9052	.9526	3.0483	3.0483	2.8578
13	2.553	2.8578	1.9052	1.1431	2.9721	3.0483	2.8578
14	2.7435	2.8578	1.7147	1.1431	2.9721	3.0483	2.8578
15	3.0483	2.8578	1.7147	1.1431	3.1626	3.0483	3.2388
16	3.0483	2.6673	1.7147	1.1431	3.1626	3.0483	3.2388
17	2.9721	2.6673	1.7147	1.1431	3.0483	3.0483	3.2388
18	2.7816	2.4768	1.5242	1.1431	2.7816	2.8578	3.0483
19	2.2862	2.2862	1.5242	1.1431	2.4768	2.2862	2.6673
20	2.2862	1.9052	1.5242	1.1431	2.4768	2.2862	2.6673
21	1.9814	1.9052	1.3336	1.1431	2.0957	1.9052	1.9052
22	1.9052	1.9052	1.3336	1.1431	2.0195	1.9052	1.9052
23	1.7147	1.9052	1.3336	1.1431	2.0195	1.9052	1.7147
24	1.9052	1.9052	1.9052	1.5242	1.1431	2.0195	1.9052
Max	3.0483	2.8959	1.9052	1.7147	3.1626	3.2388	3.2388
Min	1.7147	1.7909	1.3336	.9526	1.1431	1.9052	1.7147
Avg	2.3545	2.3101	1.6194	1.3098	2.2561	2.4974	2.4450

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283030 / 22/22KV Krishna Steel

Swt/Stn

Feeder No / Name : 303 / 22 KV EVEREST ANGAN

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.8104	4.5725	3.8104	3.8104	3.8104	4.5725	4.1914
2	3.8104	4.5725	4.1914	3.8104	3.8104	4.5725	4.1914
3	3.8104	4.5725	4.1914	3.4294	3.8104	4.5725	3.8104
4	3.8104	4.5725	3.8104	3.4294	3.8104	4.5725	3.8104
5	3.8104	4.5725	3.8104	3.4294	3.8104	4.382	3.8104
6	3.8104	4.1914	3.8104	3.4294	3.4294	4.382	3.8104
7	3.8104	3.8104	2.6673	3.8104	3.4294	3.8866	3.4294
8	4.5725	3.8104	3.4294	3.8104	3.8104	4.2676	3.4294
9	4.9535	4.1914	4.1914	3.8104	4.1914	4.5725	3.0483
10	5.7156	4.5725	4.5725	3.8104	5.144	4.9535	2.8578
11	6.0966	4.5725	4.9535	3.8104	5.3346	5.3346	5.7156
12	6.0966	4.5725	4.1914	3.8104	5.3346	3.8104	5.7156
13	5.2584	4.5725	4.1914	3.4294	4.9535	4.9535	4.9535
14	6.0966	4.5725	4.1914	3.8104	5.4108	5.3346	4.9535
15	6.0966	4.5725	4.1914	3.8104	5.3346	5.3346	5.7156
16	6.1728	4.5725	4.1914	3.8104	5.5251	5.3346	5.7156
17	6.0966	4.5725	4.1914	3.8104	5.7156	5.3346	5.7156
18	5.3346	4.1914	3.8104	3.8104	5.3346	5.3346	4.5725
19	4.5725	4.1914	3.8104	3.4294	4.763	4.5725	4.1914
20	5.2584	4.1914	3.4294	3.8104	5.144	4.9535	4.1914
21	5.2584	4.1914	3.4294	4.1914	4.9535	4.763	4.5725
22	4.9535	4.1914	3.4294	3.8104	4.763		4.5725
23	4.9535	4.1914	3.4294	3.8104	4.9535	4.1914	4.5725
24	4.5725	4.5725	3.8104	3.8104	3.8104	4.5725	4.1914
Max	6.1728	4.5725	4.9535	4.1914	5.7156	5.3346	5.7156
Min	3.8104	3.8104	2.6673	3.4294	3.4294	3.8104	2.8578
Avg	4.9472	4.3820	3.9057	3.7310	4.5995	4.7199	4.4058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283030 / 22/22KV Krishna Steel

Swt/Stn

Feeder No / Name : 304 / 22 KV BHAVKALESHWAR

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9052	2.2862	1.9052	2.2862	1.9052	2.21	1.9052
2	1.9052	2.2862	1.5242	2.2862	1.9052	2.21	1.5242
3	1.9052	2.2862	1.5242	2.2862	1.9052	2.21	1.5242
4	1.9052	2.2862	1.5242	1.9052	1.9052	2.21	1.5242
5	1.9052	2.2862	1.5242	1.9052	1.9052	1.9052	1.5242
6	1.9052	2.0957	1.5242	2.2862	1.9052	1.9052	1.5242
7	1.9052	1.7147	1.5242	2.2862	1.9052	1.9814	1.9052
8	2.2862	1.7147	1.9052	2.4768	2.2862	2.1338	1.9052
9	3.0483	2.21	2.6673	2.6673	3.0483	2.8197	1.5242
10	4.0009	2.2862	3.8104	3.0483	4.1914	3.8104	3.4294
11	4.5725	1.9052	4.1914	3.0483	4.7249	3.8104	3.6199
12	4.4963	2.2862	4.1914	3.4294		4.1914	3.6199
13	3.8104	2.2862	4.1914	3.4294	2.21	3.8104	3.0483
14	4.1914	2.2862	4.1914	3.4294	1.9052	3.8104	3.0483
15	4.5725	2.2862	4.1914	3.4294	1.9052	4.1914	3.0483
16	4.5725	2.2862	4.1914	3.0483	1.9052	4.1914	3.8104
17	4.5725	2.2862	3.8104	3.0483	3.8104	3.8104	3.8104
18	3.6199	2.2862	3.8104	2.6673	3.2388	3.0483	3.0483
19	3.2388	1.9052	3.8104	2.6673	2.6673	3.0483	3.0483
20	2.8959	1.9052	3.8104	2.6673	2.6673	2.6673	3.0483
21	2.5911	1.9052		2.2862	2.4768	2.6673	2.6673
22	2.4768	1.9052	2.2862	2.2862	2.2862		2.2862
23	2.2862	1.9052	2.2862	2.2862	2.21	1.9052	2.2862
24	1.9052	2.2862	1.9052	2.2862	2.2862	2.21	1.9052
Max	4.5725	2.2862	4.1914	3.4294	4.7249	4.1914	3.8104
Min	1.9052	1.7147	1.5242	1.9052	1.9052	1.9052	1.5242
Avg	3.0197	2.1322	2.8826	2.6435	2.4850	2.9025	2.5244

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283030 / 22/22KV Krishna Steel

Swt/Stn

Feeder No / Name : 305 / 22KV N0CIL RCD

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2862	2.6673	2.4768	2.6673	2.4768	2.8578	2.6673
2	2.2862	2.6673	2.2862	2.6673	2.4768	2.8578	2.6673
3	2.2862	2.6673	2.2862	2.6673	2.4768	2.8578	2.6673
4	2.2862	2.6673	2.2862	2.6673	2.4768	2.8578	2.6673
5	2.2862	2.6673	2.2862	2.6673	2.4768	2.8578	2.6673
6	2.2862	2.3624	2.2862	2.6673	2.6673	2.5149	2.6673
7	2.2862	2.4768	2.2862	2.4768	2.6673	2.2862	2.6673
8	2.2862	2.5911	2.2862	2.4768	2.6673	2.3624	2.4768
9	2.6673	2.6673	2.6673	2.4768	2.6673	2.7816	2.6673
10	2.6673	2.6673	2.6673	2.4768	2.8578	2.8578	2.8578
11	2.553	2.6673	2.6673	2.4768	2.934	2.8578	3.0483
12	2.4768	2.6673	2.6673	2.4768	2.934	2.8578	2.8578
13	2.6673	2.6673	2.6673	2.4768	2.934	2.8578	2.8578
14	2.7816	2.6673	2.6673	2.4768	2.8578	2.6673	2.8578
15	2.6673	2.6673	2.6673	2.6673	2.8959	2.6673	2.8578
16	2.553	2.4768	2.6673	2.4768	3.0483	2.6673	2.8578
17	2.4006	2.4768	2.6673	2.4768	2.8578	2.6673	2.8578
18	2.4768	2.4768	2.6673	2.4768	2.553	2.6673	2.6673
19	2.6673	2.4768	2.4768	2.4768	2.6673	2.6673	2.6673
20	2.5911	2.4768	2.4768	2.6673	2.553	2.6673	2.6673
21	2.6673	2.6673	2.4768	2.6673	2.7435	2.6673	2.4768
22	2.6673	2.6673	2.4768	2.6673	2.7435	2.6673	2.4768
23	2.4768	2.6673	2.4768	2.6673	2.6673	2.6673	2.4768
24	2.2862	2.553	2.6673	2.6673	2.4768	2.6673	2.8578
Max	2.7816	2.6673	2.6673	2.6673	3.0483	2.8578	3.0483
Min	2.2862	2.3624	2.2862	2.4768	2.4768	2.2862	2.4768
Avg	2.4815	2.5990	2.5085	2.5721	2.6991	2.7086	2.7149

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283032 / 22/11KV Ghansoli Gharonda

S/St

Feeder No / Name : 201 / 11 KV PATEL HEIGHT

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.885	3.2156	3.3265	3.6961	3.308	3.2941
2	1.848	1.7741	3.1417	3.1602	3.4928	3.0862	2.9864
3	1.7187	1.6632	2.9938	2.9384	2.7351	2.809	2.7511
4	1.6632	1.6817	2.8829	2.2177	2.6242	2.7351	2.5606
5	1.5893	1.5154	2.4025	2.2546	2.4209	2.5688	2.4508
6	1.3121	1.3121	2.1253	2.1992	2.2916	2.3655	2.3045
7	1.0903	1.1458	2.3285	2.1622	2.2177	2.1992	2.1948
8	1.0719	1.1273	2.0698	1.848	1.9959	2.1253	2.1033
9	1.1088	1.1403	1.9204	1.922	2.0513	2.0883	2.0119
10	1.2382	1.2127	2.1068	1.9959	2.1253	2.1068	1.9022
11	1.2382	2.1068	2.0698	2.0485	2.1253	2.1068	2.1216
12		2.1437	2.1807	2.1582	2.1437	1.9959	2.0883
13	1.3676	2.1807	2.1807	2.1582	2.1807	2.1068	2.0698
14	1.4045	2.2916	2.4394	2.1399	2.4209	2.2177	2.0883
15	1.46	2.4579	2.347	2.3411	2.4025	2.2916	2.2731
16	1.4415	2.1253	2.2361	2.3777	2.3285	2.2546	1.922
17	1.3676	2.1437	2.2546	2.3777	2.1807	2.2546	1.848
18	1.2382	2.1357	2.1807	2.3594	1.9959	2.0883	1.885
19	1.2403	2.2624	2.2916	2.3411	2.1068	2.2177	1.9774
20	1.4118	2.4434	2.4209	2.4764	2.4394	2.4615	2.268
21	1.5384	2.6244	2.4949	2.7166	2.6797	2.4977	2.396
22	1.7013	2.9864	3.0493	3.1232	3.0678	3.2579	2.7252
23	2.0271	3.3846	3.2895	3.1786	3.807	3.6561	3.0727
24	2.2546	2.0513	3.4932	3.4558	3.7515	3.7515	3.6742
Max	2.2546	3.3846	3.4932	3.4558	3.807	3.7515	3.6742
Min	1.0719	1.1273	1.9204	1.848	1.9959	1.9959	1.848
Avg	1.4696	1.9915	2.5048	2.4699	2.5534	2.5230	2.3737

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283032 / 22/11KV Ghansoli Gharonda

S/St

Feeder No / Name : 202 / 11 KV HAWARE

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		3.1786	3.1602	3.1417	3.4743	3.2341	3.3265
2		2.9569	2.9384	2.9754	3.1602	3.0123	3.0493
3		2.7351	2.6242	2.7351	2.9384	2.8645	2.809
4		2.5133	2.5688	2.5688	2.809	2.7536	2.6797
5		2.6242	2.4394	2.4579	2.6427	2.7351	2.4394
6		2.5318	2.4025	2.4764	2.4394	2.4764	2.3285
7		2.2916	2.3285	2.384	2.4025	2.4025	2.2916
8		2.384	2.2546	2.1068	2.2731	2.3655	2.2546
9		2.2546	2.2361	2.2361	2.2731	2.384	2.2177
10		2.4394	2.3655	2.3655	2.2361	2.4764	2.347
11		2.4209	2.4579	2.384	2.4949	2.4949	2.4394
12		2.5318	2.4949	2.5318	2.4394	2.4579	2.2731
13		2.5503	2.5318	2.5873	2.4764	2.4394	2.3285
14		2.4764	2.5133	2.4394	2.5318	2.4764	
15	2.5873	2.4764	2.347	2.4764	2.4949	2.5133	2.5318
16	2.4394	2.2177	2.3101	2.5688	2.4764	2.3285	2.1437
17	2.3101	2.2361	2.3285	2.6057	2.4209	2.3285	2.1622
18	2.4579	2.4764	2.4025	2.7351	2.2361	2.3285	2.1807
19	2.6797	2.6612	2.6612	2.6981	2.5873	2.7351	2.347
20	3.1417	2.9754	2.9384	2.9938	3.0308	3.1417	2.8715
21	3.2526	3.0493	3.0493	3.1417	3.1971	3.1602	2.963
22	3.4743	3.1602	3.1602	3.3819	3.3634	3.5113	2.9447
23	3.4743	3.4374	3.271	3.4743	3.5298	3.6222	3.0178
24		3.5667	3.5482	3.4004	3.5482	3.6591	3.6037
Max	3.4743	3.5667	3.5482	3.4743	3.5482	3.6591	3.6037
Min	2.3101	2.2177	2.2361	2.1068	2.2361	2.3285	2.1437
Avg	2.8686	2.6727	2.6389	2.7028	2.7282	2.7459	2.5891

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283032 / 22/11KV Ghansoli Gharonda

S/St

Feeder No / Name : 204 / 11 KV Severage Pump

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7621	.743	.5716	.1715	.8002	.6979
2		.5525	.6859	.5525	.7049	.6097	.6413
3		.5335	.5716	.5525	.5716	.6287	.6036
4		.5716	.5906	.4572	.5335	.6097	.5658
5		.6859	.5716	.4954	.5335	.6668	.5281
6		.6287	.6097	.5525	.5335	.6097	.4527
7		.5525	.6287	.4954	.4572	.381	.3772
8		.547	.6478	.5144	.4763	.4527	.3395
9		.5281	.6036	.4763	.5144	.5658	.3018
10		.6413	.6478	.6287	.3239	.547	.6224
11		.6224	.5144	.6097	.3429	.6224	.5601
12		.4527	.6097	.4954	.6287	.5281	.6413
13		.6668	.4572	.5716	.5144	.6036	.3018
14		.6859	.5144	.6287	.6478	.5658	.3961
15	.6097	.5144	.5906	.6478	.6668	.6602	.3547
16	.5335	.3429	.5716	.6859	.6287	.6036	.3361
17	.5335	.2858	.6287	.5716	.5335	.5281	.4108
18	.4001	.5335	.4191	.6859	.3048	.4904	.2987
19	.5906	.5906	.5144	.724	.4763	.3772	.4715
20	.679	.6602	.5716	.5335	.6097	.5281	.5788
21	.5093	.6602	.5906	.6478	.5144	.6602	.5906
22	.7167	.6413	.6478	.5716	.7621	.7922	.7356
23	.8488	.7922	.6668	.6859	.7811	.8865	.5975
24		.9145	.7922	.724	.7621	.7811	.8865
Max	.8488	.9145	.7922	.724	.7811	.8865	.8865
Min	.4001	.2858	.4191	.4572	.1715	.3772	.2987
Avg	.6024	.5986	.5996	.5867	.5414	.6041	.5121

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283032 / 22/11KV Ghansoli Gharonda

S/St

Feeder No / Name : 205 / 11 KV Swaraj Ghansoli

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0762	.0953	.0762	.0953	.0953	.0953
2		.0762	.0953	.0762	.0953	.0762	.0762
3		.0953	.0953	.0762	.0762	.0762	.0762
4		.0953	.0762	.0953	.0762	.0762	.0572
5		.0762	.0762	.0762	.0762	.0762	.0572
6		.0953	.0762	.0953	.0572	.0572	.0572
7		.0543	.0762	.0762	.0572	.0572	.0572
8		.0543	.0762	.0572	.0572	.0572	.0572
9		.0895	.0549	.0762	.0381	.0572	.0572
10		.0914	.0572	.0572	.0572	.0953	.0762
11		.0943	.0762	.0762	.0572	.0572	.0953
12		.0754	.1143	.1143	.0762	.0572	.0953
13		.0762	.0762	.0953	.0762	.0762	.0572
14		.0572	.1143	.0953	.0572	.0762	.0572
15	.0572	.0762	.0762	.0953	.0572	.0572	.0762
16	.0762	.0572	.0762	.0762	.0762	.0572	.0572
17	.0762	.0762	.0762	.0762	.0762	.0572	.0572
18	.0953	.0762	.0953	.1143	.0762	.0762	.0381
19	.1143	.0953	.1143	.1143	.0762	.0953	.0572
20	.0953	.1143	.0953	.0762	.0953	.0953	.0762
21	.0953	.0953	.0762	.1143	.0953	.1143	.0953
22	.0953	.0953	.0953	.0953	.0953	.1143	.0762
23	.0762	.0953	.0953	.0953	.0953	.1143	.1143
24		.0953	.0953	.0953	.0953	.0953	.0953
Max	.1143	.1143	.1143	.1143	.0953	.1143	.1143
Min	.0572	.0543	.0549	.0572	.0381	.0572	.0381
Avg	.0868	.0827	.0857	.0873	.0746	.0778	.0715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283032 / 22/11KV Ghansoli Gharonda

S/St

Feeder No / Name : 206 / 11 KV SHAKTI SEC-8

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1905	.2667	.1905	.1334	.1143	.132
2	.1143	.1715	.1905	.1715	.1143	.1143	.0943
3	.2858	.1524	.1524	.1524	.1143	.0953	.0566
4	.2286	.1524	.1524	.0762	.0953	.0953	.0566
5	.1524	.1905	.1143	.0762	.0953	.0762	.0566
6	.0953	.2286	.1524	.0762	.0572	.0953	.1132
7	.1524	.2096	.2286	.2096	.1905	.2667	.1509
8	.2096	.2033	.2096	.1905	.2096	.2263	.1886
9	.2286	.1886	.1905	.2096	.2096	.2075	.1886
10	.1334	.2075	.2096	.0572	.2477	.2263	.2075
11	.2286	.2075	.2477	.0762	.2477	.0943	.2452
12		.2096	.2477	.2286	.2477	.2452	.2096
13	.2477	.2096	.0953	.0572	.0953	.2452	.2096
14	.0762	.2477	.0953	.2286	.2667	.1132	.2477
15	.2477	.2477	.2667	.1905	.2477	.2452	.0572
16	.2286	.1715	.2477	.0762	.2477	.1509	.2054
17	.2477	.2286	.2096	.0953	.2477	.0732	.2054
18	.2096	.2477	.0762	.0953	.2477	.2263	.112
19	.2286	.2477	.2286	.0762	.2286	.2452	.2054
20	.2263	.2452	.0953	.2477	.2858	.0943	.2263
21	.2452	.2452	.0953	.2477	.2858	.2452	.2054
22	.2641	.2641	.2667	.0762	.2587	.2641	.2054
23	.2829	.1143	.2667	.1524	.1334	.2829	.1698
24	.1524	.2858	.1334	.1905	.1334	.2667	.3018
Max	.2858	.2858	.2667	.2477	.2858	.2829	.3018
Min	.0762	.1143	.0762	.0572	.0572	.0732	.0566
Avg	.2039	.2111	.1850	.1437	.1934	.1796	.1688

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283032 / 22/11KV Ghansoli Gharonda

S/St

Feeder No / Name : 207 / 11 KV Tulsi Graphics

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0953	.0953	.0572	.0953	.0953	.0953
2	.0762	.0953	.0953	.0762	.0953	.0762	.0762
3	.0762	.0762	.0762	.0572	.0762	.0762	.0762
4	.0762	.0762	.0762	.0572	.0762	.0762	.0572
5	.0762	.0762	.0572	.0381	.0572	.0762	.0572
6	.0572	.0572	.0572	.0381	.0572	.0953	.0572
7	.0572	.0572	.0762	.0762	.0572	.0381	.0572
8	.0572	.0381	.0572	.0381	.0572	.0572	.0762
9	.0953	.0572	.0572	.0572	.0762	.0953	.0762
10	.0572	.0381	.0572	.0572	.0762	.0572	.0572
11	.0572	.0381	.0572	.0381	.0572	.0572	.0572
12		.0572	.0762	.0572	.0572	.0572	
13	.0572	.0381	.0572	.0572	.0572	.0572	
14	.0572	.0381	.0762	.0381	.0572	.0572	.0381
15	.0381	.0381	.0762	.0572	.0572		
16	.0572		.0572	.0572	.0572		
17	.0572		.0572	.0572			
18	.0572	.0572		.0572	.0762	.0762	.0381
19	.0572	.0572	.0572	.0572	.0572	.0381	
20	.0762	.0572	.0572	.0572	.0572	.0572	.0381
21	.0762	.0762	.0572	.0572	.0762	.0572	.0572
22	.0953	.0762	.0953	.0953	.0953	.0762	.0762
23	.0953	.0762	.0762	.0953	.0953	.1143	.0762
24	.1143	.1143	.0953	.0762	.1143	.0953	.1143
Max	.1143	.1143	.0953	.0953	.1143	.1143	.1143
Min	.0381	.0381	.0572	.0381	.0572	.0381	.0381
Avg	.0693	.0632	.0696	.0588	.0713	.0708	.0656

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283033 / 22/22 KV Lnt Mahape Swt stn

Feeder No / Name : 301 / 22KV Mahape MIDC (O/G-I) SHEDDABLE FEEDER HAVING WEEKLY
Shree Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17
HR	Load (MW)
24	1.9052
Max	1.9052
Min	1.9052
Avg	1.9052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283033 / 22/22 KV Lnt Mahape Swt stn

Feeder No / Name : 302 / 22KV Mahape MIDC (O/G-II) SHEDDABLE FEEDER HAVING WEEKLY
New Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17
HR	Load (MW)
24	3.8104
Max	3.8104
Min	3.8104
Avg	3.8104

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283033 / 22/22 KV Lnt Mahape Swt stn

Feeder No / Name : 303 / 22KV Shil

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17
HR	Load (MW)
24	4.382
Max	4.382
Min	4.382
Avg	4.382

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283033 / 22/22 KV Lnt Mahape Swt stn

Feeder No / Name : 304 / 22 Kv Ekvira

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17
HR	Load (MW)
24	1.9052
Max	1.9052
Min	1.9052
Avg	1.9052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 284059 / 33/11 KV Sector- 12B, K

Khaira

Feeder No / Name : 202 / 11 KV SECTOR 10 HTP

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.9609	3.4558	3.77	3.7157	3.2895	3.2739	3.2922
2		3.4189	3.5852	3.4894	3.6222	3.1459	3.1093
3		3.1971	3.4019	3.3385	3.308	3.0361	3.0178
4	3.3008	3.0308	3.2739	3.131	3.1602	2.9081	2.9081
5	3.2065	2.9569	3.1093	3.0367	3.1047	2.8532	2.8715
6	3.131	2.9199	3.0544	2.9801	3.0493	2.7252	2.7069
7		2.809	2.8898	2.9047	2.8275	2.652	2.6703
8	3.0178	2.809	2.8715	2.8858	2.846	2.7252	2.6886
9	2.9047	2.6981	2.8532	2.9235	2.9014	2.7252	2.6886
10	2.8481	2.7166	2.7984	2.7349	2.7721	2.6797	2.6703
11	2.6886	2.7435	2.8292	2.7166	2.7721	2.5688	2.5606
12	2.7618	2.7721	2.9047	2.846	2.7252	2.6057	2.524
13		2.6155	2.7915	2.6427	2.5789	2.6057	2.3777
14	3.0544	2.7435	2.8858	2.7536	2.7069	2.6612	2.4508
15	2.9995	3.0361	2.9047	2.7905	2.8715	2.6427	2.4326
16	2.7984	2.8275	2.8858	2.9014	2.8349	2.396	2.3594
17	2.7252	2.6886	2.8481	2.8829	2.7252	2.4691	2.2862
18	2.846	3.0178	3.0367	2.7721	2.7618	2.5606	2.3411
19	3.0678	3.2007	3.2253	2.8829	2.8715	2.7435	2.524
20	3.5662	3.5852	3.5648	3.4189	3.3288	3.1642	3.0544
21	3.6969	3.6776	3.678	3.4004	2.9995	3.2373	3.0544
22	3.7885	3.807	3.7157	3.5482	3.3836	3.4202	
23	3.8809	3.9918	3.8855	3.7146	3.6946	3.8043	
24	4.1118	3.9733	3.9548	3.9609	3.5482	3.8409	3.6763
Max	4.1118	3.9918	3.9548	3.9609	3.6946	3.8409	3.6763
Min	2.6886	2.6155	2.7915	2.6427	2.5789	2.396	2.2862
Avg	3.2178	3.1122	3.1966	3.0988	3.0285	2.8935	2.7393

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 284059 / 33/11 KV Sector- 12B, K

Khaira

Feeder No / Name : 203 / 11 KV SECTOR 9

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.3573	3.271	3.1602	3.1876	3.2526	3.1417	3.1786
2		3.0493	3.0678	2.999	3.0493	2.8829	3.0493
3		2.8645	3.0123	2.8858	2.8829	2.5873	2.8829
4	2.8669	2.809	2.8645	2.7349	2.809	2.4579	2.7351
5	2.7538	2.6797	2.7721	2.6595	2.6797	2.384	2.6981
6	2.584	2.6057	2.6612	2.6217	2.5688	2.2916	2.6612
7		3.1971	3.1786	3.0933	2.5503	2.6797	3.1786
8	2.6406	2.4764	2.5133	2.7915	3.4189	2.1437	2.5503
9	2.4331	2.4394	2.384	2.3765	2.4394	2.1068	2.384
10	2.4897	2.384	2.4394	2.3765	2.384	2.384	2.384
11	2.3285	2.4025	2.4143	2.3285	2.4025	2.4394	2.3285
12	2.4025	2.3655	2.3765	2.347	2.3285	2.4579	2.384
13		2.4579	2.4897	2.2731	2.347	2.384	2.347
14	2.6797	2.5688	2.5274	2.4579	2.4579	2.5318	2.2916
15	2.7166	2.6981	2.5652	2.5133	2.4949	2.5873	2.4025
16	2.6057	2.5133	2.3577	2.5688	2.5133	2.4025	2.3101
17	2.4209	2.3285	2.3388	2.4949	2.347	2.3655	2.2177
18	2.4272	2.4764	2.3577	2.5133	2.3101	2.4025	2.2361
19	2.5503	2.6242	2.6029	2.4764	2.5318	2.5688	2.3655
20	3.1971	3.0862	2.9235	3.0862	2.9199	3.0862	2.9014
21	4.1581	3.77	3.9043	3.9918	3.7515	3.77	3.9733
22	3.4374	3.3265	3.1499	3.2526	3.4374	3.4004	
23	3.4928	3.4189	3.4139	3.4558	3.6222	3.5852	
24	3.6214	3.5113	3.5113	3.3762	3.4558	3.6591	3.4189
Max	4.1581	3.77	3.9043	3.9918	3.7515	3.77	3.9733
Min	2.3285	2.3285	2.3388	2.2731	2.3101	2.1068	2.2177
Avg	2.8582	2.8052	2.7911	2.7859	2.7898	2.6958	2.6763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 284059 / 33/11 KV Sector- 12B, K

Khaira

Feeder No / Name : 204 / 11 KV SISILY PARK

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8865	.8238	.905	.8488	.7164	.8059	.788
2		.7522	.8145	.7545	.7343	.7701	.6805
3		.6805	.724	.7356	.6805	.6805	.6268
4	.6979	.6447	.6805	.6602	.6626	.6268	.5731
5	.6602	.6268	.6447	.6036	.6268	.591	.5731
6	.6413	.5731	.5731	.5658	.5731	.5731	.5373
7		.5194	.5138	.5658	.4298	.5373	.5731
8	.5658	.5014	.5138	.547	.4298	.5014	.4706
9	.547	.5014	.5316	.5847	.5014	.5014	.4656
10	.5093	.5014	.5138	.9054	.5194	.5194	.443
11	.4835	.5138	.5658	.5731	.5014	.5373	.4784
12	.5373	.4835	.6036	.591	.5014	.5194	.5138
13		.5493	.6413	.5194	.5552	.5194	.5194
14	.6626	.5552	.5847	.5731	.5194	.5014	.4835
15	.6268	.591	.6413	.6089	.6089	.5373	.5194
16	.6268	.5731	.6224	.6089	.5552	.5014	.5175
17	.5373	.5373	.5658	.6089	.5373	.5014	.5014
18	.5068	.5194	.547	.5552	.5014	.4835	.4607
19	.5731	.5731	.5658	.5552	.5194	.5014	.4607
20	.6447	.591	.6602	.6089	.6268	.6447	.5731
21	.7164	.6697	.679	.6447	.6447	.6447	.591
22	.7522	.7316	.7545	.7164	.7343	.6626	
23	.8238	.7499	.8865	.788	.8596	.8596	
24	.9808	.8775	.9145	.8865	.8417	.8417	.8596
Max	.9808	.8775	.9145	.9054	.8596	.8596	.8596
Min	.4835	.4835	.5138	.5194	.4298	.4835	.443
Avg	.6490	.6100	.6520	.6504	.5992	.5984	.5550

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 284059 / 33/11 KV Sector- 12B, K

Khaira

Feeder No / Name : 205 / 11 KV BHAKTI HTP 12A

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.905	1.7375	1.8111	1.7164	1.7556	1.7556	1.6289
2		1.5746	1.5565	1.6221	1.5565	1.5927	1.4842
3		1.448	1.3937	1.4523	1.448	1.4118	1.3575
4	1.4146	1.3756	1.3253	1.3392	1.3756	1.267	1.2308
5	1.226	1.1765	1.2536	1.2071	1.2127	1.1765	1.1946
6	1.1317	1.0498	1.1104	1.1128	1.1222	1.086	1.0679
7		.9955	.8954	.9997	1.0498	1.0317	1.0317
8	1.0185	.9412	1.0029	.9619	1.0136	1.0136	1.0136
9	1.0751	.9593	.9492	1.0562	1.0136	.9955	.9412
10	.9619	.9593	.9492	.9997	.9774	.9231	.8954
11	.905	.9134	1.0562	1.0136	.9231	.9231	.8596
12	.9231	.8954	1.0374	1.0317	.8417	.905	.8417
13		.9922	1.0562	1.0136	.8954	.8869	.8238
14	1.0136	1.0924	1.0562	1.0679	.9492	.9593	.9492
15	1.0498	1.1999	1.226	1.1584	1.0566	1.0136	.9134
16	.8688	1.0208	1.1694	1.2127	1.0566	.8869	.9214
17	.9412	.8954	.9997	1.1041	.8775	.8326	.788
18	.9412	.985	.9619	1.0679	.8059	.8507	.7164
19	.9774	1.0566	.9619	1.0498	.8238	.905	.8059
20	1.1765	1.2127	1.1694	1.1403	1.0566	1.1222	1.0317
21	1.3756	1.3032	1.2071	1.267	1.2357	1.2127	1.1222
22	1.4842	1.4266	1.3203	1.3756	1.4506	1.3575	
23	1.7013	1.7193	1.6221	1.6651	1.8267	1.7918	
24	2.0559	1.8461	1.9387	1.7918	1.8642	1.9004	1.8099
Max	2.0559	1.8461	1.9387	1.7918	1.8642	1.9004	1.8099
Min	.8688	.8954	.8954	.9619	.8059	.8326	.7164
Avg	1.2073	1.1990	1.2096	1.2261	1.1745	1.1584	1.0650

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 284059 / 33/11 KV Sector- 12B, K

Khaira

Feeder No / Name : 206 / 11 KV SECTOR 8

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0178	3.807	3.6961	3.6591	3.77	3.8439	3.6961
2		3.4374	3.4928	3.4328	3.4189	3.5113	3.5113
3		3.2526	3.1971	3.2442	3.2341	3.1971	3.3634
4	3.3762	3.1047	3.1047	3.131	3.0862	3.1047	2.9938
5	3.3008	2.9754	2.9569	3.0367	2.9384	2.9569	2.9199
6	3.0933	2.8645	2.7905	2.9613	2.8275	2.846	2.846
7		3.2895	3.0862	2.9047	2.5688	3.1417	3.0862
8	2.9047	2.6242	2.6242	2.8669	3.0308	2.6612	2.6427
9	2.6406	2.5133	2.4579	2.6783	2.5688	2.5873	2.3655
10	2.5274	2.5503	2.5873	2.6595	2.5503	2.5503	2.384
11	2.4579	2.4764	2.5652	2.6057	2.384	2.4209	2.2731
12	2.4579	2.5318		2.6242	2.5133	2.4209	2.3285
13		2.5133	2.6029	2.6242	2.4764	2.4394	2.347
14	2.5873	2.6427	2.6595	2.6981	2.6242	2.5503	2.396
15	2.7905	2.8275	2.7726	2.8275	2.7166	2.5057	2.4209
16	2.6427	2.4764	2.6595	2.7905	2.6612	2.5133	2.3101
17	2.6326	2.5503	2.5652	2.8829	2.5318	2.4764	2.3655
18	2.5873	2.6057	2.6595	2.846	2.5133	2.5503	2.347
19	2.8275	2.8645	2.9424	2.809	2.7166	2.6612	2.5318
20	3.5298	3.3634	3.3196	3.4004	3.4004	3.3265	3.1602
21	4.0472	4.0657	4.0175	4.1211	4.0842	3.7515	3.807
22	3.8255	3.6961	3.6214	3.807	3.77	3.6961	
23	4.0287	4.0472	3.9043	4.0103	4.2135	4.1027	
24	3.3196	4.1396	4.0287	3.8666	4.1766	4.2505	2.2177
Max	4.0472	4.1396	4.0287	4.1211	4.2135	4.2505	3.807
Min	2.4579	2.4764	2.4579	2.6057	2.384	2.4209	2.2177
Avg	3.0298	3.0508	3.0570	3.1037	3.0323	3.0028	2.7415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 284059 / 33/11 KV Sector- 12B, K

Khaira

Feeder No / Name : 207 / 11 KV SHUBHAM

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0178	2.7905	2.8275	2.7349	2.846	2.809	2.7721
2		2.5688	2.5972	2.5086	2.5503	2.6242	2.5873
3		2.384	2.3228	2.4709	2.384	2.4949	2.4394
4	2.452	2.2731	2.2862	2.3011	2.2731	2.2916	2.1992
5	2.2822	2.1807	2.2131	2.0748	2.1437	2.2177	2.1622
6	2.1502	2.0883	1.9936	1.9616	2.0513	2.1068	1.9404
7		1.885	1.9022	1.8296	1.9589	1.9774	1.8111
8	1.8861	1.7556	1.7741	1.7353	1.8296	1.8665	1.6817
9	1.7918	1.7926	1.8107	1.7353	1.7556	1.9035	1.6078
10	1.8484	1.7372	1.6644	1.7541	1.7187	1.8665	1.6461
11	1.6632	1.6461	1.6787	1.7002	1.5893	1.7187	1.4998
12	1.3491	1.5729	1.7164	1.6817	1.5339	1.5708	1.4449
13		1.6644	1.7164	1.5708	1.4969	1.7556	1.4815
14	1.885	1.8473	1.8484	1.8111	1.6632	1.9035	1.6095
15	1.9959	1.9387	1.905	1.9589	1.7741	1.848	1.6278
16	1.9035	1.7558	1.905	1.9404	1.8111	1.7187	1.5729
17	1.6448	1.5364	1.6598	1.9035	1.6078	1.5893	1.3535
18	1.6448	1.6461	1.7164	1.7372	1.4969	1.5524	1.4449
19	1.6817	1.8107	1.7541	1.7741	1.6448	1.7187	1.4998
20	2.0328	2.0144	1.8861	2.1253	1.9589	2.0698	1.7556
21	2.1992	2.1437	1.9616	2.1253	2.1437	1.9589	1.8473
22	2.4394	2.4579	2.1691	2.4394	2.4579	2.2731	
23	2.6981	2.7721	2.5274	2.7166	2.9199	2.8645	
24	3.2819	2.9014	2.8645	2.8104	3.0123	3.0493	2.9754
Max	3.2819	2.9014	2.8645	2.8104	3.0123	3.0493	2.9754
Min	1.3491	1.5364	1.6598	1.5708	1.4969	1.5524	1.3535
Avg	2.0924	2.0485	2.0292	2.0584	2.0259	2.0729	1.8618

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 286002 / 100/22KV Nocil S/Stn

Feeder No / Name : 302 / 22kv Reliance fdr nocil SHEDDABLE FEEDER HAVING WEEKLY
 s/s Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17
HR	Load (MW)
24	1.9052
Max	1.9052
Min	1.9052
Avg	1.9052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 286002 / 100/22KV Nocil S/Stn

Feeder No / Name : 304 / 22kv Nocil-Star

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17
HR	Load (MW)
24	1.9052
Max	1.9052
Min	1.9052
Avg	1.9052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 286002 / 100/22KV Nocil S/Stn

Feeder No / Name : 310 / CTRLS

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	3.8104
Max	3.8104
Min	3.8104
Avg	3.8104

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 286002 / 100/22KV Nocil S/Stn

Feeder No / Name : 311 / 22KV Gharodha Incomer

HV Express Feeder

Feeder KV- 22 / INCOMING

DATE	01-JUN-17
HR	Load (MW)
24	3.8104
Max	3.8104
Min	3.8104
Avg	3.8104

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 288060 / 220/22KV Mahape S/Stn

Feeder No / Name : 301 / 22 KV MBP I (I/C)

HV Express Feeder

Feeder KV- 22 / INCOMING

DATE	01-JUN-17
HR	Load (MW)
24	1.9052
Max	1.9052
Min	1.9052
Avg	1.9052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 288060 / 220/22KV Mahape S/Stn

Feeder No / Name : 303 / 22KVPETROLPUMP SHEDDABLE FEEDER HAVING WEEKLY
FDR.MAHAPES/STN Feeder KV- 22 / STAGGERING (MIDC, EQUIVALENT)
OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	3.0483
Max	3.0483
Min	3.0483
Avg	3.0483

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 288060 / 220/22KV Mahape S/Stn

Feeder No / Name : 304 / 22KV Eletronic Sadan I/C-I

HV Express Feeder

Feeder KV- 22 / INCOMING

DATE	01-JUN-17
HR	Load (MW)
24	1.9052
Max	1.9052
Min	1.9052
Avg	1.9052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 288060 / 220/22KV Mahape S/Stn

Feeder No / Name : 305 / 22KV MAHAPE MIDC(I/C-I) -
1 Feeder KV- 22 / OUTGOING

HV Express Feeder

DATE	01-JUN-17
HR	Load (MW)
24	2.21
Max	2.21
Min	2.21
Avg	2.21

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 288060 / 220/22KV Mahape S/Stn

Feeder No / Name : 306 / 22KV STAR FDR MAHAPE S/STN SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17
HR	Load (MW)
24	3.8104
Max	3.8104
Min	3.8104
Avg	3.8104

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 288060 / 220/22KV Mahape S/Stn

Feeder No / Name : 307 / 22KV HARDILLIYA FDR MAHAPE SHEDDABLE FEEDER HAVING WEEKLY
S/S Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17
HR	Load (MW)
24	3.8104
Max	3.8104
Min	3.8104
Avg	3.8104

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 288060 / 220/22KV Mahape S/Stn

Feeder No / Name : 309 / 22 KV Indian Express I/C-
II Feeder KV- 22 / INCOMING

HV Express Feeder

DATE	01-JUN-17
HR	Load (MW)
24	3.8104
Max	3.8104
Min	3.8104
Avg	3.8104

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 288060 / 220/22KV Mahape S/Stn

Feeder No / Name : 311 / SHIL-KAUSA-MUMBRA II Urban/Sheddable Urban Feeder
Feeder KV- 22 / INCOMING

DATE	01-JUN-17
HR	Load (MW)
24	12.1399
Max	12.1399
Min	12.1399
Avg	12.1399

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 288060 / 220/22KV Mahape S/Stn

Feeder No / Name : 312 / 22 KV MAHAPE MIDC(I/C-II)-
II Feeder KV- 22 / OUTGOING

HV Express Feeder

DATE	01-JUN-17
HR	Load (MW)
24	3.8104
Max	3.8104
Min	3.8104
Avg	3.8104

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 288060 / 220/22KV Mahape S/Stn

Feeder No / Name : 313 / PRIDE DEVELOPER

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	1.9052
Max	1.9052
Min	1.9052
Avg	1.9052

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 288060 / 220/22KV Mahape S/Stn

Feeder No / Name : 314 / 22KV Krishna Steel-I
Feeder KV- 22 / INCOMING

HV Express Feeder

DATE	01-JUN-17
HR	Load (MW)
24	1.9052
Max	1.9052
Min	1.9052
Avg	1.9052

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 288060 / 220/22KV Mahape S/Stn

Feeder No / Name : 315 / 22KV krishna steel -II
Feeder KV- 22 / INCOMING

HV Non-Express Feeder

DATE	01-JUN-17
HR	Load (MW)
24	3.8104
Max	3.8104
Min	3.8104
Avg	3.8104

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 288060 / 220/22KV Mahape S/Stn

Feeder No / Name : 317 / 22KV MAHAPE TO KOPERKHIRNE

HV Express Feeder

Feeder KV- 22 / INCOMING

DATE	01-JUN-17
HR	Load (MW)
24	1.9052
Max	1.9052
Min	1.9052
Avg	1.9052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 288060 / 220/22KV Mahape S/Stn

Feeder No / Name : 318 / 22kv MBP-III(I/C)

HV Express Feeder

Feeder KV- 22 / INCOMING

DATE	01-JUN-17
HR	Load (MW)
24	3.8104
Max	3.8104
Min	3.8104
Avg	3.8104

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 288060 / 220/22KV Mahape S/Stn

Feeder No / Name : 321 / 22kv Lubrizol switching
Income Feeder KV- 22 / INCOMING

HV Express Feeder

DATE	01-JUN-17
HR	Load (MW)
24	6.0966
Max	6.0966
Min	6.0966
Avg	6.0966

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 288060 / 220/22KV Mahape S/Stn

Feeder No / Name : 322 / 22kv Lubrizol switching
Income Feeder KV- 22 / INCOMING

HV Express Feeder

DATE	01-JUN-17
HR	Load (MW)
24	5.3346
Max	5.3346
Min	5.3346
Avg	5.3346

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 288060 / 220/22KV Mahape S/Stn

Feeder No / Name : 802 / 220 KV MAHAPE - TIFIL

EHV Non-Express Feeder

Feeder KV- 220 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	38.104
Max	38.104
Min	38.104
Avg	38.104

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283019 / 22/11KV Vashi, Sec-1 S/Stn

Feeder No / Name : 201 / 11KV WASHI PLAZA OG Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4415	1.423	1.4632	1.3121	1.419	1.4937	1.4415
2	1.363	1.3306	1.3394	1.2567	1.3443	1.386	1.363
3	1.2696	1.262	1.2308	1.1088	1.2637	1.2567	1.2696
4	1.1763	1.1946	1.1523	1.0349	1.1827	1.1523	1.1883
5	1.0719	1.086	1.0719	1.0164	1.0829	1.1157	1.094
6	.9795	1.0349	.9694	.9979	.9709	.9979	.9896
7	.8962	.924	.8869	.8501	.8589	.9055	.8589
8	1.0719	.9979	.9694	.8316	1.0269	.9709	.9979
9	1.5364	1.5565	1.4266	1.0349	1.5729	1.5729	1.3717
10	2.4508	2.396	2.1582	1.3169	2.3045	2.5057	2.3411
11	3.1602	2.9995	2.8349	1.6095	3.1047	3.0727	2.809
12	3.271	3.1459	3.0544	1.701	3.2156		2.9938
13	3.0544	2.9995	2.963	1.7741	3.1786	3.1824	2.914
14	3.1417	3.0544	2.8532	1.8107	3.1971		2.9502
15	3.2341	3.1459	2.8645	1.7924	3.2861	2.9447	2.963
16	3.2156	2.9081	2.8829	1.7741	3.1047	2.8349	2.7801
17	2.9754	2.7069	2.5789	1.6461	3.0123	2.8898	2.524
18	2.7618	2.4615	2.268	1.4969	2.7252	2.7252	2.2131
19	2.3045	2.1538	2.0995		2.3045	2.2916	2.009
20	2.0668	1.8461	1.8823	1.5524	2.0668	2.0144	1.8099
21	1.829	1.6289	1.701	1.46	1.7741	1.7187	1.3937
22	1.5708	1.5912	1.4045	1.2936	1.7002	1.423	1.1706
23	1.6078	1.5364	1.4784	1.419	1.6617	1.5524	1.2071
24	1.6448	1.6448	1.5729	1.423	1.4784	1.6057	1.5339
Max	3.271	3.1459	3.0544	1.8107	3.2861	3.1824	2.9938
Min	.8962	.924	.8869	.8316	.8589	.9055	.8589
Avg	2.0456	1.9595	1.8794	1.3701	2.0349	1.8915	1.8411

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283019 / 22/11KV Vashi, Sec-1 S/Stn

Feeder No / Name : 202 / 11KV RAILWAY QUARTERS OG Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.251	1.2567	1.2936	1.1706	1.2752	1.4045	1.2936
2	1.1949	1.1643	1.1827	1.0608	1.1827	1.2936	1.2323
3	1.1506	1.0903	1.0829	.9877	1.1016	1.1523	1.1576
4	1.0829	.9877	.9425	.961	.9896	.9877	1.094
5	1.0164	.8779	.9335	.905	.9431	.9145	1.0082
6	.9511	.8131	.9149	.9134	.8775	.8962	.924
7	.8962	.7947	.8871	.8326	.8048	.8686	.823
8	.6767	.7947	.8589	.7316	.7762	.8131	.7392
9	.6161	.6348	.6722	.6283	.6908	.7468	.5788
10	.7095	.6908	.7468	.6535	.7842	.7655	.7095
11	.811	.7468	.8402	.7842	.8299	.8589	.7842
12	.8589	.8215	.8589	.7842	.8775		.7842
13	.8962	.8962	.9149	.8029	.8775	.8402	.8029
14	.9709	.9055	.9522	.8962	.9522		.8029
15	1.0269	1.0719	.9709	.8962	1.0374	.8962	.8962
16	.9896	.9055	.8775	1.0082	.9522	.8215	.8402
17	.8589	.8501	.8316	.9709	.9149	.8402	.7682
18	.8029	.8316	.9149	.7842	.8029	.8589	.6767
19	.9328	.961	.924		.8779	.9149	.7865
20	1.134	1.1273	1.1088	1.1016	1.0974	1.1949	1.0608
21	1.0608	1.0534	.9979	1.0642	1.0425	1.1763	.9511
22	1.2012	1.2012	.9877	.5041	1.1827	1.1763	1.0082
23	1.3676	1.3491	1.2437	1.3491	1.386	1.4003	1.1763
24	1.4003	1.423	1.4045	1.2254	1.4003	1.5154	1.3676
Max	1.4003	1.423	1.4045	1.3491	1.4003	1.5154	1.3676
Min	.6161	.6348	.6722	.5041	.6908	.7468	.5788
Avg	.9941	.9687	.9726	.9137	.9857	1.0153	.9278

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283019 / 22/11KV Vashi, Sec-1 S/Stn

Feeder No / Name : 203 / 11KV MGM OG HV Express Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.4763	.4527	.4338	.5228	.4763	.4904
2	.3961	.4382	.415	.3961	.4854	.4572	.4572
3	.362	.4191	.381	.3772	.4527	.4382	.4191
4	.362	.3961	.415	.415	.4001	.4763	.381
5	.3429	.3961	.4527	.4338	.4191	.4763	.3961
6	.4001	.3772	.4854	.415	.4338	.4954	.4338
7	.4763	.4763	.547	.415	.4527	.5525	.4668
8	.6097	.5716	.5788	.547	.5601	.6287	.4854
9	.5716	.6036	.5601	.5281	.6097	.6535	.5601
10	.6668	.5788	.6413	.4854	.7049	.7282	.5281
11	.6668	.6161	.6859	.5975	.6668	.7095	.6287
12	.5716	.7095	.6979	.5415	.724		.6097
13	.5525	.7095	.6478	.6161	.5525	.6348	.5335
14	.7621	.6535	.6668	.5975	.724		.5281
15	.724	.6348	.679	.6161	.7167	.5975	.5906
16	.724	.6348	.6413	.5415	.724	.5975	.59
17	.6478	.5415	.6287	.5415	.7049	.6161	.5335
18	.5906	.5041	.5847	.5601	.6668	.6161	.5335
19	.6287	.5975	.5658		.6097	.5601	.5335
20	.6097	.5601	.5093	.4668	.6097	.5228	.4763
21	.5716	.4854	.547	.5041	.6097	.5415	.4763
22	.5335	.5228	.547	.5041	.5716	.5601	.5093
23	.5525	.5415	.4527	.5041	.5906	.4854	.5093
24	.3961	.5335	.5228	.4715	.5601	.5144	.5041
Max	.7621	.7095	.6979	.6161	.724	.7282	.6287
Min	.3429	.3772	.381	.3772	.4001	.4382	.381
Avg	.5473	.5407	.5544	.5004	.5864	.5608	.5073

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283019 / 22/11KV Vashi, Sec-1 S/Stn

Feeder No / Name : 204 / 11KV HTP ABHYUDAYA BANK OG Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8215	.8775	.8589	.8676	.8402	.8589	.8775
2	.7655	.811	.7947	.7545	.7655	.7842	.8215
3	.7167	.6602	.7468	.679	.6979	.7023	.7733
4	.6602	.6224	3.2341	.5658	.5914	.6468	.7167
5	.5975	.5847	.6161	.5281	.5847	.5544	.6535
6	.5415	.547	.5788	.547	.5975	.5175	.5975
7	.5788	.6036	.5544	.5281	.6036	.5415	.5601
8	.6348	.6535	.6722	.6036	.5658	.5975	.5975
9	.7842	.7655	.8402	.6161	.7282	.8402	.6908
10	1.5466	1.5684	1.5655	.9896	1.5278	1.587	1.4712
11	2.4897	2.3899	2.0182	1.4969	2.452	2.4025	2.4143
12	2.6513	2.5206	2.6783	1.5684	2.6406		2.4897
13	2.6406	2.5766	2.5086	1.475	2.4897	2.5019	2.3011
14	2.4897	2.5579	2.5274	1.475	2.32		2.3388
15	2.5652	2.6783	2.452	1.419	2.5086	2.347	2.3577
16	2.6029	2.4209	2.4143	1.4969	2.452	2.3285	2.1502
17	2.5086	2.384	2.2445	1.0456	2.4143	2.3525	2.037
18	2.4006	2.2634	2.2068	1.4563	2.32	2.2731	2.0559
19	2.1719	2.1285	2.0767		2.1719	2.0725	1.9624
20	2.0005	1.9418	1.848	1.5524	1.8861	1.848	1.8671
21	1.7353	1.6448	1.7147	1.4563	1.6766	1.4563	1.6004
22	1.3014	1.3121	1.226	1.1763	1.3203	1.0642	.9907
23	1.0751	.9896	.9997	.9522	1.0082	.9979	.8002
24	.9335	.9149	.9149	.9242	.9149	.9242	.9335
Max	2.6513	2.6783	3.2341	1.5684	2.6406	2.5019	2.4897
Min	.5415	.547	.5544	.5281	.5658	.5175	.5601
Avg	1.5506	1.5174	1.5955	1.0510	1.5032	1.3727	1.4191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283019 / 22/11KV Vashi, Sec-1 S/Stn

Feeder No / Name : 205 / 11KV NBSA OG Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1949	1.0082	1.1763	1.0829	1.1203	1.0829	1.2012
2	1.1317	.9335	1.0829	.9335	1.0456	.9896	1.1016
3	1.0751	.9335	.9896	.9242	.9808	.9522	1.0456
4	.9997	.9149	.8775	.8865	.9335	.8775	.9997
5	.9242	.8775	.8402	.8589	.8589	.8589	.9431
6	.8865	.8488	.8215	.8402	.8215	.8215	.8775
7	.8589	.8865	.8029	.8402	.7922	.8029	.7842
8	.9054	.9242	.9335	.8215	.811	.9149	.7842
9	.9149	.8962	.9896	.8215	.8316	.9149	.8402
10	1.0269	1.0269	1.1763	.8402	1.0456	1.0829	1.0269
11	1.1203	1.0456	1.2136	.8775	1.1576	1.1763	1.0642
12	1.1763	1.1389	1.363	.8962	1.1949		1.0642
13	1.2883	1.0642	1.3957	.8589	1.3014	1.2323	1.2071
14	1.1763	1.1763	1.3203	.9149	1.1949		1.1389
15	1.2883	1.251	1.2883	.9522	1.2012	1.1203	1.1389
16	1.2197	1.1389	1.251	.9709	1.1827	1.1389	.9709
17	1.1203	.961	1.1203	.8775	1.1088	1.0829	.9335
18	1.1694	1.094	1.1016	.8402	1.0829	1.0642	.9522
19	1.2071	1.1273	1.2449		1.094	1.1576	1.0185
20	1.4146	1.307	1.3957	1.307	1.3769	1.363	1.2696
21	1.2826	1.1016	1.2071	1.1389	1.2071	1.1763	
22	1.1763	1.1389	1.0829	1.1506	1.2826	.9709	
23	1.2696	1.1576	1.2136	1.2883	1.307	1.1576	
24	1.2197	1.2323	1.2883	1.1389	1.1949	1.1458	1.2136
Max	1.4146	1.307	1.3957	1.307	1.3769	1.363	1.2696
Min	.8589	.8488	.8029	.8215	.7922	.8029	.7842
Avg	1.1270	1.0494	1.1324	.9592	1.0887	1.0493	1.0274

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283019 / 22/11KV Vashi, Sec-1 S/Stn

Feeder No / Name : 206 / 11KV SEC-6 ROW OG Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0748	1.905	2.1313	2.1125	2.0911	2.1691	2.0725
2	1.9239	1.7353	1.9605	1.7164	1.9418	1.9993	1.9231
3	1.7918	1.6787	1.8111	1.5089	1.7924	1.8484	1.7918
4	1.6409	1.6598	1.643	1.4563	1.643	1.6598	1.6409
5	1.5089	1.358	1.6057	1.3392	1.4901	1.6194	1.475
6	1.358	1.2449	1.5684	1.3203	1.3203	1.5623	1.3392
7	1.226	1.2071	1.5466	1.226	1.1694	1.4712	1.1694
8	1.1128	1.094	1.0642	1.094	1.1016	1.1317	1.0642
9	1.0374	1.0185	1.0456	1.0185	1.094	1.0456	1.0082
10	1.094	1.0082	1.1016	1.0456	1.094	1.0082	.9808
11	1.0829	1.0642	1.1576	1.0903	1.0829	1.0269	.9522
12	1.0829	1.1016	1.1389	1.1576	1.1128		.9709
13	1.1576	1.0642	1.2071	1.2012	1.1016	1.1203	.9619
14	1.363	1.3256	1.3014	1.2936	1.251		1.0269
15	1.4003	1.4003	1.363	1.4415	1.4003	1.1576	1.2696
16	1.3256	1.2136	1.3443	1.423	1.307	1.1389	.9522
17	1.1128	1.0082	1.1128	1.2567	1.1203	1.0349	.9242
18	1.0562	1.0082	.9619	1.1949	1.094	.9522	.811
19	1.1506	1.1576	1.0751		1.094	1.0456	.8865
20	1.4523	1.475	1.3769	1.419	1.467	1.8111	1.226
21	1.5466	1.46	1.3957	1.5339	1.5466	1.587	1.3392
22	1.7164	1.7926	1.6598	1.7556	1.8673	1.7187	1.4523
23	2.037	2.1691	1.9993	2.0559	2.2634	2.1437	1.7353
24	2.2634	2.2257	2.2822	2.1879	2.2405	2.3388	2.1992
Max	2.2634	2.2257	2.2822	2.1879	2.2634	2.3388	2.1992
Min	1.0374	1.0082	.9619	1.0185	1.0829	.9522	.811
Avg	1.4382	1.3906	1.4523	1.4282	1.4453	1.4814	1.2989

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 302 / 22KV JAYSYNTH O/G FEEDER SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2469	.2103	.2191	.2012	.2058	.2103	.2774
2	.2378	.1928	.2382	.2103	.2058	.2195	.2096
3	.2016	.1928	.2103		.2774	.2382	.2286
4	.2016	.1928	.2191		.1905	.2382	.2286
5	.192	.1928	.192		.1905	.2382	.2477
6	.192	.1928	.192		.1981	.2477	.2382
7	.2378	.2016	.2286		.1981	.2382	.2382
8	.2378	.2016	.1829		.1981	.2382	.2
9	.2561	.2016	.128	.2477	.208	.218	.2286
10	.1905	.2016	.192	.2378	.208	.208	.2667
11	.181	.1928	.192	.2378	.3102	.176	.1905
12	.1665	.1928	.3277	.2279		.4294	.1429
13	.152	.2599	.3841	.2576	.3506	.4024	.2576
14	.1593	.1646	.4024	.2576	.1928	.4294	.1829
15	.1738		.4024	.2378		.4287	.1905
16	.1738			.2378		.4854	.1905
17	.1448		.1753	.1905		.2191	.1905
18	.1738		.1844	.1981	.2195	.181	
19	.1665		.2096	.2058	.2012	.2096	
20	.181		.192	.1829	.3353	.2378	
21	.1593		.176	.2058	.3681	.2378	
22	.1665		.3441	.2058	.4161	.2804	
23	.2652	.2515	.3921	.2058		.218	
24	.2469	.1738	.2858	.2454	.1981	.3856	.3475
Max	.2652	.2599	.4024	.2576	.4161	.4854	.3475
Min	.1448	.1646	.128	.1829	.1905	.176	.1429
Avg	.1960	.2010	.2465	.2219	.2459	.2756	.2254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 303 / 22KV Akshar Feeder (Old SHEDDABLE FEEDER HAVING WEEKLY
Phizer Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT))

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2071	1.2308	1.1317	1.1088	1.2071	1.1317	1.2449
2	1.2071	1.1946	1.1317	1.1458	1.0608	1.2071	1.2071
3	1.1317	1.1946	1.1694		.9877	1.2071	1.1317
4	1.1317	1.1584	1.1317		.9511	1.1694	1.0562
5	1.0562	1.1584	2.2634		.9511	1.1694	.8676
6	1.0562	1.1584			.9145	1.1694	.7377
7	1.0402	1.086	1.1317		.8048	1.1694	.6706
8	2.1033	1.1584	1.3203		.8779	1.2071	1.2323
9	1.6975	1.5565	1.8107	1.4266	1.2826	1.6598	1.5466
10	1.8861	1.7375	2.2257	1.7193	2.0748	2.1125	1.1317
11	2.2257	1.8823	2.3765	1.7924	2.1879	2.3388	2.3388
12	2.2257		2.3011	1.9022	2.3765	2.3011	2.4143
13	2.1879		2.037	1.5729	2.3388	2.037	2.2634
14	2.1879		2.2634	1.9022	2.3388	2.1502	2.452
15	2.1879	1.9616	2.3765	1.7558	2.3388	2.1879	2.037
16	2.4897	1.9993		1.6095		2.4143	1.9616
17	2.1125		2.0748	1.3535		1.9616	2.0748
18	1.4712		1.5844	1.4632	1.8107	1.7353	
19	1.358		1.2071	1.39	1.1317	1.358	
20	1.2071		1.0562	1.0242	1.1317	1.1317	
21	1.0185		1.0185	.9877	1.1317	.9054	
22	1.0185		1.2826	.9145		.9431	
23	1.1317	1.2865	1.2449	.9145		1.0608	
24	1.358	1.2826	1.2826	1.0349	1.2071	1.358	1.0242
Max	2.4897	1.9993	2.3765	1.9022	2.3765	2.4143	2.452
Min	1.0185	1.086	1.0185	.9145	.8048	.9054	.6706
Avg	1.5707	1.4031	1.6101	1.3899	1.4553	1.5453	1.5218

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 304 / 22KV NOVARTIS EXPRESS

HV Express Feeder

FEEDER Feeder KV- 22 /
OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.08	.0674	.048	.0457	.0777	.0686	.0549
2	.08	.0674	.048	.0674	.0777	.0686	.056
3	.0686	.0674	.048		.0777	.0686	.0572
4	.0457	.0686	.0305		.0777	.0686	.0549
5	.0709	.0686	.0457		.0777	.0686	.0503
6	.0686	.0674	.0457		.0777	.0686	.0492
7	.0709	.0674	.048		.0777	.0686	.0492
8	.0709		.048		.0777	.0686	.0549
9	.1132	.0674	.08	.0777	.0777	.0572	.0663
10	.0686	.0674	.08	.0777	.0777	.0686	.0572
11	.0686	.0674	.08	.0777	.0686	.0674	.0686
12	.0686	.0457	.0754	.0777	.0892	.0903	.0572
13	.0686	.048		.0777	.08	.1017	.0572
14	.0686	.0457	.1132	.0777	.064	.1029	.0492
15	.0686		.112	.0777		.1017	.0777
16	.0686			.0777		.1029	.0686
17	.0686		.1029	.0777		.1052	.0594
18	.0686		.1132	.0777	.0686	.0949	
19	.0686		.0949	.0777	.0686	.096	
20	.0686		.072	.0777	.0686	.0937	
21	.0686		.048	.0777	.1029	.0983	
22	.0686		.0457	.0777	.0663	.056	
23	.0686	.0914	.0503	.0777		.0663	
24	.08	.0686	1.7147	.061	.0777	.0686	.0655
Max	.1132	.0914	1.7147	.0777	.1029	.1052	.0777
Min	.0457	.0457	.0305	.0457	.064	.056	.0492
Avg	.0712	.0651	.1429	.0744	.0766	.0800	.0585

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 305 / 22KV PHIZER EXPRESS FEEDER HV Express Feeder
Feeder KV- 22 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0625	.048	.061	.0686	.0648	.0693	.0709
2	.0625	.048	.061	.0693	.0648	.0686	.0716
3	.0625	.048	.061		.0648	.0686	.0709
4	.0457	.048	.061		.0648	.0686	.0381
5	.0541	.048	.061		.0648	.0686	.0335
6	.0229	.048	.061		.0648	.0686	.0328
7	.0191	.048	.061		.0648	.0457	.0328
8	.0191	.048	.061		.0648	.0259	.0389
9	.0019	.048	.061	.0655	.0648	.0389	.0404
10	.0198	.048	.0655	.0655	.0412	.0389	.0305
11	.0198	.048	.0655	.0655	.0366	.0465	.0305
12	.0198		.0655	.0655	.0404	.0572	.0343
13	.0198	.0457	.0655	.0655	.0381	.0533	.0229
14	.0198	.0305	.0663	.0655	.0381	.0389	.0404
15	.0213		.0655	.0655		.0373	.032
16	.0191			.0655		.0373	.029
17	.0213		.0663	.0655		.0389	.032
18	.0213		.0663	.0655	.0282	.0396	
19	.0213		.0655	.0655	.0305	.0427	
20	.0518		.0663	.0655	.0457	.0472	
21	.0518		.0655	.0655	.0754	.0518	
22	.0518		.0678	.0655	.0747	.0602	
23	.0518	.0686	.0678	.0655		.0678	
24	.0914	.0518	.061	.0686	.0648	.061	.0747
Max	.0914	.0686	.0678	.0693	.0754	.0693	.0747
Min	.0019	.0305	.061	.0655	.0282	.0259	.0229
Avg	.0355	.0483	.0639	.0661	.0548	.0517	.0420

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 306 / 22KV LUBRIZOL EXPRESS

HV Express Feeder

FEEDER Feeder KV- 22 /

OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5089	1.6975	1.5844	1.6975	2.1125	1.7353	1.7353
2	1.6221	1.6221	1.9993	1.7353	1.8107	1.6975	1.6598
3	1.6221	1.6221	1.6221		1.8107	1.6975	1.6975
4	1.6975	1.6221	1.6975		1.773	1.6598	1.6598
5	1.6975	1.5844	1.6975		1.773	1.6598	1.6975
6	1.6975	1.5844	1.6975		1.773	1.5844	1.6975
7	1.773	1.5844			1.7353	1.5844	1.6975
8	1.773	1.6598	1.6975		1.9993	1.6598	1.7353
9	2.0748	1.7353	1.8107	1.6598	1.8861	1.8861	1.8484
10	1.9616	1.8861	2.0748	1.6975	2.037	1.9239	1.8861
11	1.8861	2.037	2.2257	1.7353	2.037	2.037	2.0748
12	1.8107	1.9616	1.773	1.773	1.9239	1.9993	2.037
13	1.773	1.8861		1.773	1.9616	1.8861	1.9993
14	1.8107	1.8861	1.6975	1.6975	1.9616	2.037	2.1125
15	1.8861		1.6975	1.6598	1.8861	2.3388	2.3765
16	1.9239			1.6975	2.1879	2.037	
17	1.7353		1.6221	2.037	1.7353	2.1879	1.773
18	1.7353		1.6598	2.1125	1.9616	1.8107	
19	1.7353		1.8861	1.9616	1.9616	1.8861	
20	1.7353		2.1502	1.8861	1.8861	1.8861	
21	1.773		2.037	1.8484	1.773	1.9239	
22	1.7353		1.7353	1.8107	1.6598	1.8107	
23	1.6598	1.6975	1.7353	2.0748		1.7924	
24	1.5089	2.037	1.6975	1.7353	2.1502	2.037	1.8107
Max	2.0748	2.037	2.2257	2.1125	2.1879	2.3388	2.3765
Min	1.5089	1.5844	1.5844	1.6598	1.6598	1.5844	1.6598
Avg	1.7557	1.7565	1.7999	1.8107	1.9042	1.8649	1.8529

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 307 / 22KV NANDKAMAL EXPRESS HV Express Feeder

FEEDER Feeder KV- 22 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0023	.0229	.0549	.0503	.0667	.0617
2	.0343	.0229	.0229	.0579	.0503	.08	.0652
3	.0343	.032	.0229		.0503	.08	.0762
4	.0343	.032	.0229		.0503	.0747	.0652
5	.0343	.0229	.0229		.0503	.0533	.0549
6	.0343	.0229	.0229		.0503	.056	.048
7	.0343	.0229	.0229		.0503	.16	.048
8	.0229	.0229	.3018		.0503	.7922	.7167
9	.0229	.0572	.3395	.0671	.0503	.7545	.6413
10	.0206	.0229	.3772	.0671	.0503	.7545	.1296
11	.0194	.0229	.415	.0754	.679	.7167	.0229
12	.0194	.0229	.4527	.0671	.679	.679	.0229
13	.0194	.0229	.3605	.0251	.679	.7095	.0171
14	.0217	.0229	.3521	.0251	.7167	.6036	.0229
15	.0217		.2054	.0503		.679	.0171
16	.0674			.0503		.5658	
17	.0217		.3772	.0503		.5658	.0229
18	.0217		.1635	.0503	.2526	.4904	
19	.0217		.1132	.0503	.1334	.3772	
20	.0217		.0975	.0503	.08	.3772	
21	.0217		.061	.0503	.0907	.0762	
22	.0217		.0701	.0503	.0846	.0686	
23	.0217	.0229	.061	.0503		.0686	
24	2.6292	.0217	.0229	.064	.0503	.0747	.0652
Max	2.6292	.0572	.4527	.0754	.7167	.7922	.7167
Min	.0194	.0023	.0229	.0251	.0503	.0533	.0171
Avg	.1357	.0248	.1709	.0531	.1974	.3718	.1234

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 308 / 22KV BALMER LAWARIE HV Express Feeder
EXPRESS FE Feeder KV- 22 /
OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5844	1.8861	1.9616	1.6598	1.3203	2.037	1.6975
2	1.5844	1.7353	1.9616	1.9044	1.2071	2.0748	1.6598
3	1.6221	1.7353	1.8861		1.2449	1.9993	1.6221
4	1.6221	1.6975	1.8861		1.2449	1.9616	1.6221
5	1.6975	1.6598	1.8107		1.2826	1.8107	1.5089
6	1.6975	1.6221	1.6975		1.3203	1.6975	1.4712
7	1.6221	1.3957	1.5089		1.3957	1.7353	1.4712
8	1.6975	1.2826	1.5844		1.5844	1.5242	1.6598
9	1.773	1.5466	1.6221	1.2826	1.6221	1.8861	1.6598
10	1.5089	1.5844	1.5844	1.3203	1.7353	1.8861	1.7044
11	1.2071	1.6598	1.5089	1.2826	1.6975	1.8484	1.7353
12	1.1317	1.7044	1.3957	1.358	1.6975	1.5089	1.5844
13	1.1317	1.773	1.6598	1.2826	1.7353	1.9993	1.3957
14	1.2449	1.9616	1.5844	1.358	1.5089	1.8861	1.773
15	1.094		1.5089	1.2449		1.7353	1.6598
16	1.358			1.3203		1.9993	1.9616
17	.9054		1.5089	1.3203		1.6975	1.773
18	1.2071		1.9616	1.2826	1.358	1.8484	
19	1.358		1.9993	1.4712	1.5089	1.7353	
20	1.1317		1.7353	1.3203	1.5844	1.5844	
21	1.773		1.8861	1.2449	1.6975	1.6598	
22	1.7353		1.6598	1.2826	1.5089	1.773	
23	1.8484	1.7924	1.4712	1.2826		1.5844	
24	1.6975	2.037	1.9993	1.773	1.4335	1.8107	1.5089
Max	1.8484	2.037	1.9993	1.9044	1.7353	2.0748	1.9616
Min	.9054	1.2826	1.3957	1.2449	1.2071	1.5089	1.3957
Avg	1.4681	1.6921	1.7123	1.3884	1.4844	1.8035	1.6371

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 309 / 22KV Zoetis Pharma (PHIZER HV Express Feeder
EX Feeder KV- 22 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3772	.3772	.3326	.3772	.3772	.3772
2	.3772	.3772	.3772	.3326	.3772	.415	.3772
3	.3772	.3772	.3772		.3772	.415	.415
4	.3772	.3772	.3772		.3772	.415	.3772
5	.415	.3772	.3772		.3395	.4527	.415
6	.415	.3772	.3772		.3395	.4527	.3772
7	.4527	.415	.3772		.3395	.4527	.415
8	.4527	.5281	.3772		.5281	.5281	.4904
9	.7167	.5281	.3772	.3395	.6413	.7545	.6413
10	.7167	.679	.5281	.3395	.7167	.7922	.6413
11	.7545	.695	.679	.3395	.7621	.7922	.7545
12	.7545	.7545	.679	.3772	.679	.8676	.7545
13	.7316	.7545	.5658	.3772	.679	.7316	.7545
14	.7545	.7545	.6413	.3772	.7167	.852	.7545
15	.9054		.6413	.3772		.7922	.7545
16	.7545			.3772		.7922	.679
17	.7922		.5281	.3772		.7545	.5658
18	.6413		.4904	.3772	.6413	.679	
19	.4527		.3772	.3772	.5658	.5281	
20	.4527		.3772	.3772	.5658	.415	
21	.4527		.3772	.3772	.4527	.415	
22	.3772		.3734	.3772	.415	.3772	
23	.3772	.415	.3734	.3772		.415	
24	.3772	.3772	.3772	.3734	.3772	.415	.415
Max	.9054	.7545	.679	.3772	.7621	.8676	.7545
Min	.3772	.3772	.3734	.3326	.3395	.3772	.3772
Avg	.5523	.5103	.4523	.3658	.5134	.5784	.5533

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 310 / 22 KV MAZDA FEEDER SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17	02-JUN-17
HR	Load (MW)	Load (MW)
1	1.773	1.773
2	1.773	1.8107
3	2.1125	1.8107
4	1.7353	1.8484
5	1.773	1.8484
6	1.773	1.9993
7	1.773	1.8484
8	2.2634	1.9993
9	2.4143	2.1879
10	2.9047	2.3388
11	3.2819	2.8292
12		2.6406
13		2.452
14		2.6406
16	3.2442	
17	3.2442	
18	2.8669	
19	2.4143	
20	2.3388	
21	1.9993	
22	1.8861	
23	1.8484	
24	1.7353	1.8484
Max	3.2819	2.8292
Min	1.7353	1.773
Avg	2.2577	2.1250

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 311 / 22kv Everest Nivara SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.6036	.4527	.6036	.5658	.5658	.6036
2	.5281	.5658	.4527	.5658	.5281	.5658	.5658
3	.4904	.5281	.3772		.4904	.5658	.6036
4	.4904	.4904	.4904		.4904	.5658	.5281
5	.5281	.4904	.4904		.5281	.5658	.5281
6	.5281	.4527	.4161		.5281	.5658	.4904
7	.4904	.415	.4527		.5281	.5658	.4904
8	.5658	.4904	.4527		.5658	.5658	.5281
9	.7167	.679	.6036	.4904	.6036	.7545	.6413
10	.7545	.7167	.6413	.4904	.8299	.8299	.7545
11	.7545	.7922	.679	.4904	.8676	.8676	.7545
12	.7545	.7545	.679	.4904	.8299	.7922	.7545
13		.7167	.679	.5121	.8299	.7922	.7545
14		.7545	.6413	.5281	.8299	.7922	.7545
15			.7167	.5281		.8299	.7545
16	.8299			.4527		.8299	.7545
17	.8299		.5658	.4904		.7922	.7545
18	.7167		.5658	.4904	.7545	.7167	
19	.679		.6413	.4904	.679	.6036	
20	.679			.5658	.679	.6036	
21	.7167		.6036	.5658	.6036	.6413	
22	.6859		.6036	.5658		.679	
23	.7545		.6036	.5658		.6413	
24	.5281	.679	.4904	.6036	.5658	.5658	.6413
Max	.8299	.7922	.7167	.6036	.8676	.8676	.7545
Min	.4904	.415	.3772	.4527	.4904	.5658	.4904
Avg	.6452	.6086	.5590	.5272	.6472	.6774	.6476

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 312 / 22kv Chunabhatti

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9808	.9054	.7545	.9054	.8299	1.0185	.8676
2	.9808	.8676	.7545	.9054	.8299	1.0185	.8299
3	1.0185	.8676	1.8861		.8676	1.0185	.8299
4	1.0185	.8676	.7545		.8676	1.0185	.7545
5	.9431	.9054	.7545		.8299	1.0562	.7922
6	.9431	.9054	.7545		.8299	1.0562	.7167
7	.9431	.7545	.7545		.8676	1.0562	.7167
8	.9431	.7922	.7545		.8676	1.0562	.7922
9	.9431	.7545	.9054	.8676	1.0185	1.0562	.9054
10	1.0185	.8299	1.094	1.0185	1.2449	1.1694	1.1317
11	1.0562	.8676	1.094	1.0185	1.2071	1.1694	1.1317
12	1.0562	.8316	1.094	.9808	1.2449	1.2449	1.1317
13		1.8861	1.0185	1.0562	1.1317	1.094	1.1317
14		.9054	.9431	1.0562	1.1317	1.2071	1.2449
15			.9808	1.0185		1.2449	1.1694
16	1.1317			1.0562		1.2071	1.1317
17	1.0562		.9431	.9431		1.2071	1.1317
18	.9808		.9431	1.0562	1.0185	1.094	
19	1.0185		.8676	.9431	1.0185	.9808	
20	1.0185		.8676	.9431	1.0185	.9431	
21	.9808		.9054	.9431	1.094	.9431	
22	1.0185		.8299	.8676		.9054	
23	.9808	.7545	.8676	.8676		.9054	
24	1.0185	.9808	.7545	.8299	.8299	1.0185	.8299
Max	1.1317	1.8861	1.8861	1.0562	1.2449	1.2449	1.2449
Min	.9431	.7545	.7545	.8299	.8299	.9054	.7167
Avg	1.0023	.9173	.9251	.9598	.9867	1.0704	.9578

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 302 / 22KV Kukshet Incomer II
From N Feeder KV- 22 / OUTGOING

HV Express Feeder

DATE	01-JUN-17
HR	Load (MW)
24	2.8578
Max	2.8578
Min	2.8578
Avg	2.8578

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 303 / 22KV KUKSHET FEEDER SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7796	.7442	.8413	.7796	.7362	.8326	.7442
2	.7522	.724	.7602	.7522	.788	.788	.7964
3	.7442	.7362	.788	.7602	.7362	.7282	.7796
4	.7964	.6935	.788	.7796	.6859	.7011	.7362
5	.7964	.7522	.7087	.7164	.7011	.7282	.6859
6	.788	.7087	.7087	.7602	.7522	.7202	.6859
7	.7796	.663	.6783	.6859	.7011	.7282	.6859
8	.7796	.7011	.7011	.6783	.7796	.724	.6706
9	.961	.9145	.8779	.7164	.9511	1.0349	.8871
10	1.1694	1.1203	1.094	.8131		1.1576	1.2071
11	1.2826		1.2071	.7164	1.1317	1.1576	1.1694
12	1.2071		1.094	.724	1.2071	1.2323	1.1317
13	1.0082		.8962	.6935	1.0349	1.1203	1.0562
14	1.1576	.961	1.0185	.7164	1.0829	1.0456	1.1317
15	1.2071	1.1317	1.0562	.724	1.2071	.8589	1.094
16	1.2071	1.1203	1.1694	.7316	1.0456	.8413	1.1694
17	.961	.9979	1.094	.724	.8501	.7964	1.0456
18	.8501	.8779	1.0456	.724	.6859	.7964	
19	.9335	.7602	.8048	.6859	.6554	.7011	
20	.8048	.7087	.788	.6478	.663	.6859	
21	.6935	.7011	.724	.6706	.6401	.6173	
22	.6935	.7087	.7011	.6478	.6478	.6859	
23	.6859	.6935	.7011	.6935	.8779	.7362	
24	.7087	.6935	.7964	.7011	.7087	.8779	.6935
Max	1.2826	1.1317	1.2071	.8131	1.2071	1.2323	1.2071
Min	.6859	.663	.6783	.6478	.6401	.6173	.6706
Avg	.9061	.8149	.8768	.7184	.8378	.8457	.9095

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 304 / 22KV TATA TELE

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.105	1.1431	1.1431	1.105	1.1431	1.1431
2	1.1812	1.105	1.0669	1.1431	1.105	1.105	1.105
3	1.1431	1.0669	1.105	1.105	1.0669	1.105	1.1431
4	1.105	1.105	1.1431	1.105	1.105	1.0669	1.105
5	1.1431	1.105	1.0669	1.0669	1.105	1.105	1.105
6	1.0669	1.1431	1.105	1.105	1.1431	1.105	1.0669
7	1.2193	1.1431	1.2193	1.105	1.1812	1.1812	1.1812
8	1.2574	1.2574	1.2193	1.1431	1.2193	1.2955	1.2193
9	1.5623	1.4861	1.2955	1.1431	1.6385	1.7147	1.5242
10	1.7147	1.7147	1.4098	1.1812	1.7147	1.7909	1.6385
11	1.7147	1.6766	1.448	1.2193	1.7909	1.7909	1.7147
12	1.7909	1.7147	1.4861	1.1812	1.7528	1.7528	1.6766
13	1.6385	1.6385	1.4098	1.1812	1.6766	1.7147	1.6004
14	1.7147	1.7147	1.448	1.2193	1.7528	1.7528	1.5623
15	1.7528	1.6766	1.4098	1.2193	1.7147	1.7909	1.4861
16	1.6766	1.7147	1.4098	1.2193	1.7147	1.7147	1.6004
17	1.6766	1.6004	1.3717	1.1812	1.7147	1.7147	
18	1.6004	1.5623	1.2574	1.2193	1.6385	1.6766	
19	1.448	1.4098	1.1812	1.1431	1.5242	1.4861	
20	1.3336	1.3336	1.1431	1.1812	1.2955	1.3336	
21	1.2193	1.2574	1.1431	1.2193	1.2193	1.2193	
22	1.2193	1.1812	1.1431	1.1812	1.1812	1.1431	
23	1.1812	1.1812	1.1431	1.1812	1.1812	1.1431	
24	1.1812	1.1431	1.1431	1.1812	1.1431	1.1812	1.1812
Max	1.7909	1.7147	1.4861	1.2193	1.7909	1.7909	1.7147
Min	1.0669	1.0669	1.0669	1.0669	1.0669	1.0669	1.0669
Avg	1.4035	1.3765	1.2463	1.1653	1.4035	1.4178	1.3561

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 305 / 22KV NANDKAMAL + HPCL HV Express Feeder
EXPRESS Feeder KV- 22 /
OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	1.0669	.9526				1.105
2	.8383	.9907	.9145				1.0669
3	.8002	1.0288	.8764				.9907
4	.8383	.9145	.9145				1.0669
5	.8383	.9526	.8764				1.0669
6	.8383	.9907	.9145				1.0669
7	.6859	1.4098	.1524	.1524			1.1431
8	.724	.9526	.1524	.1524			1.2574
9	.9907	1.2955	.1524	.1524			1.2955
10	.9145	1.5242	.1524	.1524			1.829
11	.9907	1.4098	.1524	.1524			1.4098
12	.9526	1.3336	.1524	.1524			1.7147
13	.8764	1.4098	.1524	.1524			1.829
14	1.5242	1.5242	.1524	.1524			1.7528
15	1.7147	1.6385		.1524			1.7909
16	1.6004	1.6385		.1524			1.7528
17	.9145	1.4098		.1524			
18	.8002	1.2574		.1524			
19	.6097	1.105		.1524			
20	.6478	1.0669		.1524		.8383	
21	.6097	1.0669		.1524		.8383	
22	.6097	.9526		.1524		1.0669	
23	.9907	.9145		.1524		1.105	
24	.8764	1.0288	.9526		.1524		1.105
Max	1.7147	1.6385	.9526	.1524	.1524	1.105	1.829
Min	.6097	.9145	.1524	.1524	.1524	.8383	.9907
Avg	.9177	1.2034	.5080	.1524	.1524	.9621	1.3673

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 307 / 22KV Amines

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1719	2.21	.8002	.8002	1.0288	.8383	2.21
2	2.1338	2.2862	.8002	.8383	.9526	.8002	2.1338
3	2.21	2.21	.8383	.8383	.9145	.7621	2.2481
4	2.1719	2.2862	.8002	.8764	1.0288	.8002	2.2862
5	2.1719	2.21	.7621	.8383	.9526	.8002	2.2481
6	2.3243	2.3243	.8002	.8383	.9907	.8764	2.2862
7	2.4768	2.21	.8002	.8764	1.0288	.9907	2.553
8	2.5149	2.3624	1.0288	.9145	.9526	.9907	2.5911
9	2.8578	2.4387	1.1812	1.1431	1.0288	1.3717	3.0864
10	3.0864	2.7054	1.5242	1.4098	1.2955	1.5623	3.2388
11	3.2007	2.4387	1.5623	1.6004	1.448	1.6766	3.4294
12	3.2769	2.4387	1.4861	1.4861	1.6766	1.5242	3.0864
13	2.8578	2.4387	1.4098	1.1431	1.2955	1.4098	2.8197
14	2.7816	2.6673	1.3717	1.3717	1.2193	1.3336	3.2007
15	2.9721	2.5911	1.6766	1.5623	1.6004	1.3717	3.315
16	3.0483	2.4006	1.5623	1.5242	1.5242	1.448	3.4294
17	2.7816	.8764	1.448	1.2193	1.3717	1.3336	
18	2.8197	2.4387	1.0669	1.2574	1.2955	1.448	
19	2.5911	2.3243	.9145	1.0669	1.105	1.105	
20	2.4006	2.2862	.9526	.9145	1.0288	1.105	
21	2.3624	.8002	.8764	.9526	.9907	2.3624	
22	2.2862	.8002	.8383	1.0288	.9907	2.2862	
23	2.21	.8002	.8002	1.0288	.8764	2.1719	
24	2.1338	2.1719	.8383	.8383	.9907	.8764	2.0576
Max	3.2769	2.7054	1.6766	1.6004	1.6766	2.3624	3.4294
Min	2.1338	.8002	.7621	.8002	.8764	.7621	2.0576
Avg	2.5768	2.1132	1.0892	1.0987	1.1495	1.3019	2.7188

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 308 / 22KV Vishal

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	1.0669	.8764	.8002	.8764	.9907	.7621
2	.8764	.9907	.8383	.8383	.8383	.9526	.724
3	.9145	.9526	.8764	.8764	.9907	.9145	.7621
4	.9145	.8383	.9145	.8764	.8383	.8383	.724
5	.9145	1.0669	.8764	.8764	.8764	.9526	.6478
6	.8383	.9526	.8764	.8764	.9145	.9526	.6859
7	.8383	.8383		.8383	.9907	.9526	.6859
8	.8383	.8764	.6097	.8383	.8764	1.0288	.6097
9	.8764	.8383	.6478	.8383	.9145	1.0288	.6859
10	.9907	.9526	.6478	.8002	.9526	.9907	.8002
11	1.0288	.9526	.7621	.8764	.9526	.9526	.7621
12	1.0669	.9526	.7621	.9145	1.0669	1.0669	.8002
13	.9907	.9145	.6859	.9145	.9526	.9526	.7621
14	1.0288	.9145	.9145	.8764	.9526	.9907	.724
15	1.0669	1.0288	.9145	.8383	.9907	1.0288	.8002
16	.9907	.9907	.8383	.8764	1.0288	1.0288	.7621
17	.9907	.9145	.8383	.8764	.9907	.9145	.724
18	1.0669	.8383	.724	.8764	.9907	.8383	
19	1.0288	.9526	.9145	.8764	.9526	.9145	
20	.9907	.9145	.9145	.9526	1.105	.7621	
21	1.0288	.9145	.9145	.9907	.9907	.7621	
22	.9145	.8764	.9145	.8764	.9526	.7621	
23	.9145	.9145	.9145	.8764	.9907	.724	
24	.9145	1.0288	.8764	.8764	.9907	.9526	.7621
Max	1.0669	1.0669	.9145	.9907	1.105	1.0669	.8002
Min	.8383	.8383	.6097	.8002	.8383	.724	.6097
Avg	.9558	.9367	.8284	.8732	.9574	.9272	.7325

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 309 / 22KV R & D

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.8002	.6859	.9526	.6859	.9526	.8383
2	.724	.8383	.724	.9145	.724	.9145	.8002
3	.6859	.724	.6859	.8764	.8764	.9526	.7621
4	.6859	.6859	.6859	.8383	.8383	.724	.724
5	.6859	.8002	.6097	.7621	.6097	.9145	.6478
6	.8002	.7621	.6478	.6859	.8002	.8764	.6859
7	.7621	.8002	.6478	.6478	.9145	.9145	.7621
8	.724	.8002	.724	.6478	.8764	.724	.8383
9	.8002	.8002	.8002	.6859	1.0288	1.0288	.9145
10	.9145	1.0288	1.0288	.7621	1.0669	1.1812	1.0288
11	1.0669	1.0669	1.0669	.8383	1.2193	1.2955	1.0669
12	1.105	1.2193	1.2193	.9526	1.2955	1.3336	1.0288
13	1.0288	1.1431	1.1431	.8764	1.0288	1.2193	1.0669
14	1.1431	1.0288	1.1812	.724	1.105	1.1431	1.0288
15	1.2193	1.105	1.0669	.8383	1.3336	1.3336	1.0669
16	1.1431	1.0669	1.0288	.8764	1.2574	1.2574	1.0669
17	1.1431	.9145	.8002	.9145	1.1431	.9526	
18	1.105	.8383	.9145	.7621	.9526	.9907	
19	.9907	.8383	.8764	.6859	.9145	.6478	
20	1.0288	.8764	.9145	.7621	.8383	.6859	
21	.8764	.724	.6478	.724	.8002	.6097	
22	.6859	.724	.5716	.6097	.8383	.8383	
23	.5335	.6859	.9526	.5716	.6859	.9145	
24	.6478	.6859	.724	1.0288	.5335	.9145	.8764
Max	1.2193	1.2193	1.2193	1.0288	1.3336	1.3336	1.0669
Min	.5335	.6859	.5716	.5716	.5335	.6097	.6478
Avg	.8828	.8732	.8478	.7891	.9320	.9717	.8943

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 284060 / 33/11KV Vashi, Sector- 19D

S/S

Feeder No / Name : 201 / 11 KV STATION TRANSFORMER Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	.1905
Max	.1905
Min	.1905
Avg	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 284060 / 33/11KV Vashi, Sector- 19D

S/S

Feeder No / Name : 202 / 11 KV 'L' WING DANA MARKET Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	1.0479
Max	1.0479
Min	1.0479
Avg	1.0479

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 284060 / 33/11KV Vashi, Sector- 19D

S/S

Feeder No / Name : 203 / 11 KV 'C' WING MASALA Urban/Sheddable Urban Feeder
MARKET Feeder KV- 11 /
OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 284060 / 33/11KV Vashi, Sector- 19D

S/S

Feeder No / Name : 207 / 11 KV UTI SUB STATION Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	1.2574
Max	1.2574
Min	1.2574
Avg	1.2574

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 284060 / 33/11KV Vashi, Sector- 19D

S/S

Feeder No / Name : 208 / 11 KV SUNVILL

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	1.4289
Max	1.4289
Min	1.4289
Avg	1.4289

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 286007 / 100/22/11KV Vashi S/Stn

Feeder No / Name : 201 / 11KV CIDCO PUMP HOUSE Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	.6287
Max	.6287
Min	.6287
Avg	.6287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 286007 / 100/22/11KV Vashi S/Stn

Feeder No / Name : 202 / 11KV MAFCO OFFICE Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	.743
Max	.743
Min	.743
Avg	.743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 286007 / 100/22/11KV Vashi S/Stn

Feeder No / Name : 203 / 11KV FRUIT MARKET Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	1.0479
Max	1.0479
Min	1.0479
Avg	1.0479

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 286007 / 100/22/11KV Vashi S/Stn

Feeder No / Name : 204 / 11KV SECTOR 15 INDOOR S/S Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	.9717
Max	.9717
Min	.9717
Avg	.9717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 286007 / 100/22/11KV Vashi S/Stn

Feeder No / Name : 205 / 11KV MINI MARKET 9/16 Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	1.2574
Max	1.2574
Min	1.2574
Avg	1.2574

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 286007 / 100/22/11KV Vashi S/Stn

Feeder No / Name : 206 / 11KV GRAIN MARKET Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	.7049
Max	.7049
Min	.7049
Avg	.7049

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 286007 / 100/22/11KV Vashi S/Stn

Feeder No / Name : 208 / 11KV PUNJAB NATIONAL BANK Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	1.4861
Max	1.4861
Min	1.4861
Avg	1.4861

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 286007 / 100/22/11KV Vashi S/Stn

Feeder No / Name : 209 / 11KV VASHI - 9 OG Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	1.2003
Max	1.2003
Min	1.2003
Avg	1.2003

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 286007 / 100/22/11KV Vashi S/Stn

Feeder No / Name : 211 / 11KV SATRA PLAZA - II Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	.5716
Max	.5716
Min	.5716
Avg	.5716

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 286007 / 100/22/11KV Vashi S/Stn

Feeder No / Name : 301 / 22KV VASHI SECTOR 1

HV Express Feeder

Feeder KV- 22 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	7.316
Max	7.316
Min	7.316
Avg	7.316

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 286007 / 100/22/11KV Vashi S/Stn

Feeder No / Name : 303 / 22KV KOPERKHAIRNE
Feeder KV- 22 / OUTGOING

HV Express Feeder

DATE	01-JUN-17
HR	Load (MW)
24	5.3346
Max	5.3346
Min	5.3346
Avg	5.3346

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 286007 / 100/22/11KV Vashi S/Stn

Feeder No / Name : 304 / 22KV MAFCO COLD STORAGE SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17
HR	Load (MW)
24	3.2388
Max	3.2388
Min	3.2388
Avg	3.2388

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 286007 / 100/22/11KV Vashi S/Stn

Feeder No / Name : 305 / 22KV FEEDER NO. 5
Feeder KV- 22 / INCOMING

HV Non-Express Feeder

DATE	01-JUN-17
HR	Load (MW)
24	2.7816
Max	2.7816
Min	2.7816
Avg	2.7816

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 286007 / 100/22/11KV Vashi S/Stn

Feeder No / Name : 309 / 22KV BARC (JANTA MARKET) SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17
HR	Load (MW)
24	3.5437
Max	3.5437
Min	3.5437
Avg	3.5437

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 286007 / 100/22/11KV Vashi S/Stn

Feeder No / Name : 310 / 22KV SAWALA COLD STORAGE SHEDDABLE FEEDER HAVING WEEKLY
TURBH Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17
HR	Load (MW)
24	2.5149
Max	2.5149
Min	2.5149
Avg	2.5149

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 286007 / 100/22/11KV Vashi S/Stn

Feeder No / Name : 312 / 22KV TURBHE NAKA Urban/Sheddable Urban Feeder
Feeder KV- 22 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	3.2007
Max	3.2007
Min	3.2007
Avg	3.2007