

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 201 / 11 KV SAKALPAPER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0914			
2			.0686		
3		.0914			.0914
4	.0924		.0686	.0934	
5		.1097			
6		.1097	.0686		.0914
7					.0914
8	.1109	.0914	.0857	.0924	.0914
9					.1097
10	.1109	.1109		.1109	
11			.1109		.112
12	.112	.112		.1307	
13					.112
14	.1294	.1132		.112	
15			.112		.1294
16	.1294	.2614		.1294	
17			.1109		.1478
18	.1097	.0857		.128	.0857
19	.1097		.1097		
20	.1097	.0857		.0914	.1029
21	.1097				
22		.0686		.1097	
23	.1097				
24	.1374	.1811	.0686	.1566	.0914
Max	.1374	.2614	.112	.1566	.1478
Min	.0924	.0686	.0686	.0914	.0857
Avg	.1142	.1163	.0893	.1155	.1047

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 202 / 11 KV KUKERAJA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8871			
2			.7888		
3		.8501			.8501
4	.8501		.7202		
5		.8131			
6		.8131	.7545		.8501
7					.8871
8	1.386	.8871	.823	1.0269	.961
9					1.2567
10	1.6817	1.423		1.7741	
11			1.0456		1.9044
12	1.8111	1.6804		1.9791	
13					1.8111
14	1.848	1.6975		1.9791	1.8111
15			1.0903		1.885
16	1.8296	1.643		1.8296	
17			1.0456		1.7187
18	1.5893	1.2689		1.6078	1.5089
19	1.3676		1.0534		
20	1.2382	1.0802			1.1145
21	1.1827				
22		1.0288		1.1458	
23	1.0164				
24	.9335	.8871	.8745	.961	.9425
Max	1.848	1.6975	1.0903	1.9791	1.9044
Min	.8501	.8131	.7202	.961	.8501
Avg	1.3945	1.1507	.9107	1.5379	1.3462

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 203 / 11 KV GAUTAM COMPLEX

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8686			
2			.7545		
3		.8131			.7762
4	.8131		.6516	.8589	
5		.8316			
6		.7947	.6859		.8131
7					.8131
8	1.1458	.8316	.6859	.8686	.9055
9					1.1827
10	1.4415	1.1458		1.5708	
11			.961		1.6617
12	1.5684	1.3817		1.6804	
13					1.5123
14	1.6263	1.3769		1.7364	
15			.9896		1.5893
16	1.5893	1.251		1.5893	
17			.9425		1.5339
18	1.46	.9945		1.4784	1.3032
19	1.2752		.9522		
20	1.1273	.9259		1.1088	1.0288
21	1.0534				
22		.9088		.9795	
23	.9979				
24	.8962	.9425	.823	.924	.8686
Max	1.6263	1.3817	.9896	1.7364	1.6617
Min	.8131	.7947	.6516	.8589	.7762
Avg	1.2495	1.0051	.8274	1.2795	1.1657

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 205 / 11 KV ARENJA TOWER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1829			
2			.1372		
3		.1829			.1829
4	.2241		.1372	.2033	
5		.1829			
6		.1829	.1715		.2012
7					.2561
8	.3921	.2378	.1543	.2614	.2926
9					.3292
10	.462	.4251		.462	
11			.2772		.4805
12	.4668	.4481		.4668	
13					.4668
14	.4251	.415		.4668	
15			.2033		.4805
16	.499	.4481		.4854	
17			.2054		.4435
18	.4251	.3086		.4024	.3429
19	.3475		.2587		
20	.3109	.2743		.2926	.3429
21	.2926				
22		.2572		.2743	
23	.2561				
24	.2402	.2195	.1715	.2054	.1829
Max	.499	.4481	.2772	.4854	.4805
Min	.2241	.1829	.1372	.2033	.1829
Avg	.3618	.2896	.1907	.3520	.3335

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 207 / 11 KV CIDCO PUMP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4805			
2			.4115		
3		.4435			.3881
4	.4805		.3772	.5228	
5		.4435			
6		.5359	.4115		.5175
7					.462
8	.6099	.5175	.5658	.6838	.5359
9					.5544
10	.6468	.6468		.5359	
11			.5041		.5175
12	.3921	.4668		.4481	
13					.4481
14	.3696	.4338		.3921	
15			.3881		.3511
16	.3696	.4108		.3511	
17			.5228		.462
18	.5544	.5658		.5544	.463
19	.6099		.7392		
20	.5729	.583		.5544	.6344
21	.5359				
22		.5144		.5359	
23	.499				
24	.4668	.462	.463	.5175	.4805
Max	.6468	.6468	.7392	.6838	.6344
Min	.3696	.4108	.3772	.3511	.3511
Avg	.5090	.5003	.4870	.5096	.4845

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 208 / 11 KV INFOTECH PARK SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7762			
2			.583		
3		.7762			.7023
4	.7023		.5487	.6468	
5		.7577			
6		.7577	.5487		.6468
7					.7392
8	1.1273	.8316	.6173	.7842	.8316
9					.961
10	1.3121	1.1643		1.3676	
11			.7577		1.46
12	1.4937	1.2883		1.531	
13					1.475
14	1.4415	1.2449		1.475	
15			.8316		1.4784
16	1.6817	1.2323		1.6263	
17			.8131		1.46
18	1.386	.9259		1.3121	1.2689
19	1.1643		.8215		
20	.9979	.7545		.9795	.8573
21	.9055				
22		.703		.8501	
23	.8501				
24	.7655	.7577	.6516	.7095	.8131
Max	1.6817	1.2883	.8316	1.6263	1.4784
Min	.7023	.703	.5487	.6468	.6468
Avg	1.1523	.9208	.6859	1.1282	1.0578

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 209 / 11 KV RBI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2195			
2			.1715		
3		.2195			.2195
4	.2241		.1543	.2218	
5		.2195			
6		.2195	.1372		.2378
7					.1829
8	.2587	.1646	.1543	.2427	.2012
9					.2195
10	.1663	.2218		.2402	
11			.2033		.2033
12	.1867	.2054		.1867	
13					.2054
14	.1848	.1886		.2054	
15			.1663		.1663
16	.1663	.1494		.1663	
17			.168		.2218
18	.2195	.2058		.2195	.2229
19	.2561		.2957		
20	.2743	.2401		.2561	.2572
21	.2561				
22				.2561	
23	.2561				
24	.2218	.2378	.2401	.2614	.2378
Max	.2743	.2401	.2957	.2614	.2572
Min	.1663	.1494	.1372	.1663	.1663
Avg	.2226	.2076	.1879	.2256	.2146

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 210 / 11 KV MTNL / DIWALA SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4435			
2			.3429		
3		.4251			.4251
4	.4251		.3429	.4854	
5		.4435			
6		.4805	.3601		.4805
7					.4805
8	.5975	.499	.3601	.6283	.5914
9					1.0534
10	1.2382	.7762		1.46	
11			.5228		1.4045
12	1.3817	.8402		1.5123	
13					1.4377
14	1.4045	.8488		1.419	
15			.499		1.4045
16	1.386	.7655		1.4045	
17			.5175		1.3121
18	.8686	.5144		.961	.8402
19	.6653		.5041		
20	.5914	.4458		.5914	.5316
21	.5175				
22		.4287		.4805	
23	.4938				
24	.4481	.462	.3944	.4435	.4251
Max	1.4045	.8488	.5228	1.5123	1.4377
Min	.4251	.4251	.3429	.4435	.4251
Avg	.8348	.5672	.4271	.9386	.8656



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 212 / 11 KV MAYURESH COSMOSS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0914			
2			.1029		
3		.0914			.0914
4	.1109		.1029	.0934	
5		.0914			
6		.0914	.1029		.0914
7					.0914
8	.1307	.1097	.0857	.1294	.1097
9					.128
10	.2218	.2033		.2587	
11			.1109		.2957
12	.2987	.2801		.3361	
13					.2614
14	.2587	.2641		.2987	
15			.1294		.3142
16	.2957	.2427		.3142	
17			.1294		.2772
18	.2012	.1543		.2195	.1372
19	.1646		.112		
20	.1463	.12		.128	.12
21	.1097				
22		.12		.1097	
23	.1097				
24	.112	.0914	.12	.0739	.0914
Max	.2987	.2801	.1294	.3361	.3142
Min	.1097	.0914	.0857	.0739	.0914
Avg	.18	.1501	.1107	.1962	.1674

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 403 / 33 KV NMMC NON SHEDDABLE WATER SUPPLY AND  
Feeder KV- 33 / OUTGOING UTILITY

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2686			
2			.2572		
3		.3224			.2458
4	.3292		.2572	.3292	
5		.2686			
6		.3224	.3086		.2458
7					.2486
8	.3292	.2686	.2572	.3292	.2949
9					.2949
11			.3292		
15			.3292		
18	.3224	.2572		.2984	.3086
19	.3224		.2743		
20	.3224	.3601		.2486	.3086
21	.3224				
22		.2572		.2984	
23	.3224				
24	.2772	.2686	.2572	.3292	.2486
Max	.3292	.3601	.3292	.3292	.3086
Min	.2772	.2572	.2572	.2486	.2458
Avg	.3185	.2882	.2838	.3055	.2745

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 201 / 11 KV Sector 8-A

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5975		.6097	.5975
2	.5335			.6097	
3	.5335	.5228		.6097	.5601
4	.5335			.6478	
5	.5716	.5601		.6859	.5601
6	.6668	.6036		.724	.6535
7	.7621	.6161		.7811	.7842
8	.8383				
9	.7811	.8962		.9335	.8589
10	.8215		.8383	.8962	.7468
11	.6908			.8402	.7468
12	.6722	.8215	.7811	.7733	.6722
13	.5975		.7049	.7282	
14	.5788			.6908	
15	.5228	.6348	.5716	.6535	.5601
16	.5415		.5716	.6348	
17	.5415		.6097	.5601	
18	.7095	.7095	.8383		.6722
19	.8299		.9335	.8402	.8029
20	.811		.9145	.8215	.8402
21	.8215		.8764	.8215	.8215
22			.8764	.8029	.7842
23	.7468		.8002	.7468	
24	.6097	.6722		.6668	.6535
Max	.8383	.8962	.9335	.9335	.8589
Min	.5228	.5228	.5716	.5601	.5601
Avg	.6647	.6634	.7764	.7308	.7072

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 203 / 11 KV CBD SEC 8 B

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8192	.8299		.7621	.7095
2	.8002			.7621	
3	.8002	.7468		.7621	.6722
4	.8002			.7621	
5	.8383	.7842		.8002	.7095
6	.9145	.8215		.8764	.8962
7	.9717	.8402		1.0669	.9709
8	1.0669				
9		1.1203		1.2003	1.0829
10	1.0456		1.1241	1.0269	.9335
11	.7842			.9335	.8589
12	.7842	.8962	.8764	.8589	.8402
13	.7095		.7811	.7922	
14	.6908			.7655	
15	.6535	.7468	.7049	.7095	.6722
16	.6348		.6287	.8029	
17	.7095		.7811	.6908	
18	.8962	.9335	1.1241		.8775
19	1.0082		1.1812	1.1203	1.1203
20	.9808		1.086	1.0082	.9896
21	.9335		1.0669	1.0269	1.0269
22			.9717	.9896	.9709
23	.8688		.8954	.7842	
24	.8573	.8589		.7621	.7468
Max	1.0669	1.1203	1.1812	1.2003	1.1203
Min	.6348	.7468	.6287	.6908	.6722
Avg	.8440	.8578	.9351	.8756	.8799

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 204 / 11 KV S/STN T/F SECT-06

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0747		.0953	.0747
2	.0953			.0953	
3	.0953	.0754		.0953	
4	.0953			.0953	
5	.0953	.0747		.0953	.0747
6	.0953	.0747		.0953	.0934
7	.1143	.0754		.0953	.112
8	.1143				
9		.112		.1143	.112
10	.0934		.1143	.0934	.112
11	.0934			.0934	.0934
12	.0934	.0934	.0953	.0754	.0747
13	.0747		.0953	.0747	
14	.0754			.0747	
15	.0934	.0747	.0762	.0747	.0747
16	.0934		.0762	.0747	
17	.0747		.0953	.0747	
18	.0943	.0934	.0953		.112
19	.0934		.0953	.0934	.0934
20	.0943		.1143	.0934	.0934
21	.0934		.1143	.0943	.112
22			.1143	.0934	.0934
23	.0934		.0953	.0934	
24	.0953	.0943		.0953	.0934
Max	.1143	.112	.1143	.1143	.112
Min	.0747	.0747	.0762	.0747	.0747
Avg	.0935	.0843	.0985	.0900	.0946

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 206 / 11 KV KENDRIYA SADAN SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2614		.3048	.2614
2	.2667			.2858	
3		.2452		.2667	.2241
4	.2477			.2667	
5	.2477	.2427		.2667	.2241
6		.2427		.2858	.2614
7		.2241		.3239	.2614
9	.381	.3361		.381	.3734
10	.3734		.3429	.4294	.3734
11	.3734			.4108	.4108
12	.4108	.4481	.381	.4294	.3734
13	.3361		.3239	.4338	
14	.3547			.3921	
15	.3361	.3734	.2858	.3547	.3361
16	.3734		.3048	.3961	
17	.3734		.3429	.4108	
18	.415	.4854	.724		.4481
19	.4715		.5144	.4481	.5041
20	.415		.4572	.4294	.5041
21	.362		.4382	.4108	.4481
22			.381	.3547	.3734
23	.2987		.362	.2987	
24	.3048	.2801		.3048	.2801
Max	.4715	.4854	.724	.4481	.5041
Min	.2477	.2241	.2858	.2667	.2241
Avg	.3488	.3139	.4048	.3584	.3536

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 207 / 11 KV SECTOR-09 NEW

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.4854		.5335	.5228
2	.4954			.5335	
3	.4954	.4481		.5335	.4854
4	.4954			.5335	
5	.5335	.4481		.5335	.4854
6	.6097	.4854		.5716	.5601
7		.6161		.6668	.5228
8	.724				
9	.5335	.7468		.8383	.7468
10	.6224		.7621	.7095	.5975
11	.4854			.5601	.5228
12	.4715	.5975	.6097	.4854	.4668
13	.4481		.5525	.5041	
14	.4715			.4294	
15	.3772	.4481	.4191	.3921	.3734
16	.3772		.4572	.5228	
17	.3361		.4572	.3921	
18	.5281	.5601	.724		.5601
19	.5975		.7621	.6535	.6722
20	.6161		.724	.6535	
21	.6161		.724	.6722	.6722
22			.6859	.6161	.5975
23	.5658		.6478	.5601	
24	.5335	.5228		.5716	.5601
Max	.724	.7468	.7621	.8383	.7468
Min	.3361	.4481	.4191	.3921	.3734
Avg	.5212	.5358	.6271	.5667	.5564

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 208 / 11 KV RBI SEC 10

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5975		.5716	.5601
2	.5716			.5335	
3	.5716	.4854		.5335	.4854
4	.5716			.5335	
5	.6097	.4904		.5335	.4854
6	.6478	.5228		.5716	.5041
7	.6668	.5601		.6097	.6722
8	.724				
9		.6348		1.2955	.9335
10	1.643		.6859	1.8484	1.643
11	1.8298			1.9044	1.7551
12	1.7924	.9709	.5716	1.8671	.5975
13	1.643		.5335	1.7364	
14	1.6617			1.7013	
15	1.6244	1.0082	.6478	1.7924	1.6057
16	1.6975		.6097	1.8298	
17	1.6617		.6859	1.7924	
18	1.3817	.8215	.7621		1.3817
19	.9335		.8002	1.307	.8962
20	.8215		.8002	1.0082	.7468
21	.7468		.7621	.7282	.7842
22			.743	.7095	.7095
23	.6722		.7049	.6335	
24	.6097	.6348		.5716	.5975
Max	1.8298	1.0082	.8002	1.9044	1.7551
Min	.5716	.4854	.5335	.5335	.4854
Avg	1.0752	.6726	.6922	1.1188	.8974



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 210 / 11 KV RBI (NEW)

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4294		.4108
3		.4294		.4108
5		.4294		.4108
6		.4294		.5281
7		.4294		.4481
10	.7468		.7655	
11	.7095		.7468	
12	.3361		.7468	
13	.6348		.7468	
14	.6516		.7545	
15	.7167		.6161	
16	.7167		.7468	
17	.6348		.6161	
18	.4668			
19	.4481		.4108	
20	.4527		.4108	
21	.4294		.4108	
22			.4108	
23	.4481		.4108	
24		.4294		.4108
Max	.7468	.4294	.7655	.5281
Min	.3361	.4294	.4108	.4108
Avg	.5686	.4294	.5995	.4366

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 201 / 11KV PHANASPADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9979	.9114	.9896	.9335	.9795
2	.9694	.8764	.9335	.8871	.9425
3	.9511	.929	.8962	.8238	.9795
4	.905	.8764	.9054	.8779	.924
5	.905	.929	.8865	.9511	.961
6	.9511	1.0099	.8865	1.0269	1.0719
7	1.0425	.9391	.9431	1.1128	1.0534
8	1.0974	1.0099	1.0374	1.0751	1.1088
9	1.1157	1.0642	1.0082	1.094	1.0374
10	.9313	1.0269	1.0082	1.0269	.9054
11	.8063	.8775	.961	.8238	.8299
12	.7373	.8402	.9425	.7619	.7842
13	.7888	.8215	.9145	.815	.7655
14	.703	.8215	.8779	.6836	.7468
15	.6443	.7842	.8596	.6836	.7468
16	.6274	.7468	.8688	.6661	.7842
17	.7122	.8775	.8869	.7442	.8402
18	.8322	1.0082	.9412	.9511	.8775
19	.9922	1.0829	.9774		1.0456
20	.9671	1.1203	1.0425	1.0719	1.0642
21	.9492	1.1016	1.0791	1.1088	1.0829
22	1.0029	1.1016	1.0719	1.0534	1.0269
23	1.0029	1.0642	1.0642	1.0349	.9522
24	.9979	.8682	1.0269	.9709	
Max	1.1157	1.1203	1.0791	1.1128	1.1088
Min	.6274	.7468	.8596	.6661	.7468
Avg	.9013	.9454	.9587	.9208	.9352

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 202 / 11KV PUJIT PLAZA SECTOR-11 SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0838	.0663	.0857	.0686	.08
2	.0838	.0663	.0838	.0686	.064
3	.0829	.0663	.0838	.0678	.064
4	.0663	.0663	.0671	.0671	.176
5	.0655	.0663	.0648	.0655	.064
6	.0655	.0663	.0648	.0655	.064
7	.0663	.0663	.0486	.0648	.064
8	.0663	.0829	.0648	.0648	.064
9	.0995	.1132	.0648	.0983	.1478
10	.1844	.1509	.081	.2103	.2033
11	.1886	.1494	.08	.2279	.2033
12	.1886	.1494	.08	.1715	.2033
13	.1886	.1494	.08	.1886	.1848
14	.1543	.1494	.081	.1886	.1848
15	.2058	.1494	.0648	.2229	.1848
16	.1886	.1494	.0648	.1886	.1848
17	.1715	.1307	.0819	.1715	.1663
18	.1543	.112	.0819	.1543	.1663
19	.1372	.0934	.0819	.1174	.132
20	.1006	.0934	.0829	.0819	.0857
21	.1174	.0747	.0829	.064	.0686
22	.0829	.0732	.0838	.08	.0686
23	.0663	.0857	.0678	.08	.0857
24	.0838	.0829	.0857	.0686	.08
Max	.2058	.1509	.0857	.2279	.2033
Min	.0655	.0663	.0486	.064	.064
Avg	.1205	.1022	.0754	.1186	.1246

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 203 / 11KV BELAPUR DTC SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5068		.6602		
2	.4887		.6036		
3	.4755		.6036		
4	.4755		.5658		
5	.4706		.5658		
6	.5014		.5658		
7	.5731		.5658		
8	.6805		.679	.6602	
9	.591	.6224	.6348		.7167
10		.5658	.5975		.5093
11		.4904	.5601		.4338
12		.4904	.5175		.4527
13		.5093	.5175		.4294
14		.5093	.4805		.4108
15		.4715	.4805		.4108
16		.4527	.5175		.4481
17		.4715	.5304		.4481
18		.6602	.5487		.5041
19		.6535	.5487		.6722
20		.6722	.5914		.6161
21		.7095	.6283		.6413
22		.7545	.6348		.6413
23		.7167	.6348		.6224
24	.5249		.679		
Max	.6805	.7545	.679	.6602	.7167
Min	.4706	.4527	.4805	.6602	.4108
Avg	.5288	.5833	.5797	.6602	.5305

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 204 / 11KV S/STN TRANSFORMER SHEDDABLE URBAN  
R.M.U S Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0762	.0572	.0762
2	.0572	.0572	.0762	.0572	.0762
3	.0572	.0572	.0762	.0381	.0762
4	.0572	.0572	.0762	.0381	.0572
5	.0381	.0572	.0762	.0381	.0762
6	.0381	.0762	.0762	.0381	.0572
7	.0381	.0572	.0572	.0381	.0572
8	.0381	.0572	.0762	.0572	.0572
9	.0381	.0762	.0762	.0762	.0572
10	.0762	.0572	.0381	.0572	.0762
11	.0762	.0572	.0381	.0572	.0572
12	.0762	.0762	.0381	.0572	.0572
13	.0572	.0572	.0381	.0572	.0381
14	.0572	.0572	.0381	.0572	.0572
15	.0572	.0572	.0572	.0572	.0572
16	.0572	.0762	.0572	.0572	.0572
17	.0762	.0381	.0572	.0572	
18	.0572	.0381	.0572	.0572	.0381
19	.0572	.0572	.0572	.0572	.0572
20	.0572	.0762	.0381	.0572	.0381
21	.0572	.0572	.0381	.0572	.0572
22		.0762	.0381		.0762
23	.0381	.0762	.0381	.0572	.0762
24	.0572	.0572	.0762	.0572	.0572
Max	.0762	.0762	.0762	.0762	.0762
Min	.0381	.0381	.0381	.0381	.0381
Avg	.0555	.0612	.0572	.0539	.0605

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 205 / 11KV SAI VIHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17	13-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9259		1.0631			
2	.8817		1.0288			.9326
3	.8478					.9326
4	.8383		.9221			.9221
5	.8048		.852			.9389
6	.8309		.8192			.9389
7	.8745		.9012			
8	.9945		.9339	.9339		.9556
9	.9602	1.0867	.8848		1.086	
10		1.0985	.8619		1.3032	
11		1.2934	.9614		1.448	
12		1.2934	1.0111		1.3756	
13		1.4175	1.0277		1.448	
14		1.4175	1.0442		1.3575	
15		1.382	1.0774		1.3575	
16		1.3466	1.094		1.3575	
17		1.3112	1.1105		1.3575	
18		1.3643	1.1568		1.3575	
19		1.382	1.1736		1.3575	
20		1.382	1.2039		1.262	
21		1.3998	1.1523		1.2269	
22		1.2757	1.2003		1.1361	
23		1.2048	1.2094		1.1022	
24	.9602		1.1517			
Max	.9945	1.4175	1.2094	.9339	1.448	.9556
Min	.8048	1.0867	.8192	.9339	1.086	.9221
Avg	.8919	1.3104	1.0366	.9339	1.3022	.9368

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 206 / 11KV CHROMA SECTOR-15

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17	13-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3189	.2683	.3506	.333	.3086	.3544
2	.2804	.2347	.3155	.3086	.2915	.3544
3	.2629	.218	.2401	.2915	.2572	.3189
4	.2427	.2012	.2401	.2883	.2401	.3189
5	.208	.1844	.2058	.2713	.2229	.2658
6	.1696	.2012	.2058	.2743	.2229	.2658
7	.2035	.2012	.2058	.2743	.2572	
8	.3222	.2374	.2743	.2401	.3772	
9	.3561	.2743	.2743	.443	.3961	
10	.4115	.3761	.2572	.5194	.4904	
11	.5552	.5194	.3052	.6154	.679	
12	.5731	.5373	.3561	.7316	.7095	
13	.6984	.591	.3688	.695	.7095	
14	.6767	.591	.4024	.695	.6535	
15	.6219	.5373	.4527	.7316	.6535	
16	.6283	.5194	.4862	.695	.6535	
17	.5729	.5014	.503	.6584	.6535	
18	.6283	.5014	.5197	.6767	.6535	
19	.6283	.5014	.5197	.695	.5853	
20	.5853	.5552	.5426	.5316	.543	
21	.4252	.5194	.5596	.4961	.4887	
22	.333	.4656	.4508	.4382	.4252	
23	.3086	.4119	.3681	.4207	.3721	
24	.3189	.3429	.3681	.333	.4733	.4252
Max	.6984	.591	.5596	.7316	.7095	.4252
Min	.1696	.1844	.2058	.2401	.2229	.2658
Avg	.4304	.3955	.3655	.4857	.4716	.3291

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 208 / 11KV GREAT EASTERN SUMMIT SHEDDABLE URBAN  
SECT Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17	13-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9945		1.0288	.9709		.8592
2	.9259		.9945	.9882		.8592
3	.8817		.9724	1.0056		.8749
4	.852		.8535			.8962
5	.9054		.8535			.9602
6	.9556		.8002			.9602
7			.8145			
8	1.0974		.8573	.9659		
9	1.2517	1.0974	.8288		1.2346	
10		1.283	.8109		1.4403	
11		1.335	.8398		1.5089	
12		1.283	.9122		1.4746	
13		1.1789	.9846		1.3889	
14		1.1789	1.0269		1.3375	
15		1.1616	1.0856		1.3717	
16		1.1616	1.0669		1.3717	
17		1.1963	1.0562		1.406	
18		1.3003	1.0395		1.406	
19		1.2483	1.0395		1.3375	
20		1.2174	1.0682		1.1736	
21		1.1317	1.0242		1.1469	
22		1.0974	1.0631		1.0311	
23		1.0631	1.0117		.9686	
24	1.0288		1.0288	.9709		.8905
Max	1.2517	1.335	1.0856	1.0056	1.5089	.9602
Min	.852	1.0631	.8002	.9659	.9686	.8592
Avg	.9881	1.1956	.9609	.9803	1.3065	.9001



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284061 / 33/33KV SBI IDBI NMMC

Swt/Stn

Feeder No / Name : 401 / 33KV SBI - 2

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2143	.1235	.132	.3658
2	.2229	.2143	.1235	.132	.3658
3	.2229	.2143	.1235	.132	.3658
4	.2229	.2143	.1235	.132	.3658
5	.2229	.2143	.1235	.132	.3658
6	.2229	.2143	.1235	.132	.3658
7	.2229	.2143	.1235	.132	.3658
8	.2229	.2143	.1235	.2286	.3658
9	.4572	.2143	.1235	.4801	.3658
10	.7499	.2143	.2286	.8048	.639
11		.2143	.2286	.8048	.8139
12	.6401	.2143	.2286	.6962	.823
13	.6401	.2143	.2286	.6962	1.0517
14	.6401	.2143	.2286	.6962	.8413
15	.6401	.2143	.2286		.8413
16	.587	.2143	.2286	.639	.8413
17	.6401	.2143	.2286	.639	.7202
18	.587	.2143	.2286	.5281	.503
19	.4904	.2143	.2286	.4687	.2286
20	.2143	.2143	.2286	.4687	.2286
21	.2143	.2143	.2286	.4687	.2286
22	.2143	.2143	.132	.4687	.2286
23	.2143	.1235	.132	.4687	.2286
24	.2229	.2143	.1235	.132	.3658
Max	.7499	.2143	.2286	.8048	1.0517
Min	.2143	.1235	.1235	.132	.2286
Avg	.3885	.2105	.1768	.4179	.4948

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284061 / 33/33KV SBI IDBI NMMC

Swt/Stn

Feeder No / Name : 403 / 33KV SBI - 1 & SUB ST/N NON SHEDDABLE EXPRESS HV FEEDERS  
 XMER Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0869		.0869	.0869	.0869
2	.0869		.0869	.0869	.0869
3	.0869		.0869	.0869	.0869
4	.0869	.0869	.0869	.0869	.0869
5	.0869	.0869	.0869		.0869
6	.0869	.0869	.0869	.0869	.0869
7	.088	.0869	.0869	.0869	
8	.0869	.0869	.0869	.0869	.0869
9	.0869	.0869	.0869	.0869	.0869
10	.0869	.0869	.0869	.0869	.0869
11	.0869	.0869	.0869	.0869	.0869
12	.0869	.0869	.0869	.0869	.0869
13	.0869	.0869	.0869	.0869	.0869
14	.0869	.0869	.0869	.0983	.0869
15	1.6941	.0869	.0869	.0869	.0869
16	.0869	.0869	.0869	.0869	.0869
17	.0869	.0869	.0869	.0869	.0869
18	.0869	.0869	.0869	.0869	.0869
19	.0869	.0869	.0869	.0869	.0869
20	.0869	.0869	.0869	.0869	.0869
21	.0869	.0869		.0869	.0869
22	.0869	.0869	.0869	.0869	
23	.0869	.0869	.0869	.0869	
24	.0869	.0869	.0869	.0869	.0869
Max	1.6941	.0869	.0869	.0983	.0869
Min	.0869	.0869	.0869	.0869	.0869
Avg	.1539	.0869	.0869	.0874	.0869

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284061 / 33/33KV SBI IDBI NMMC

Swt/Stn

Feeder No / Name : 404 / 33KV NMMC - 2 (1)

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1372	.1372	.1372	.1337
2	.132	.1372	3.2465	.1372	.1337
3	.132	.1372	.1372	.1372	.1337
4	.132	.1372	.1372	.1372	.1337
5	.132	.1372	.1372	.1372	.1337
6	.132	.1372	.1372	.1372	.1337
7	.132	.1372	.1372	.1372	.1337
8	.132	.1372	.1372	.1372	.1337
9	.1875	.1372	.1372	.3749	.1337
10	.3841	.1372	.1372	.4801	.4115
11	.3841	.1372	.1372	.4801	.4572
12	.3841	.1372	.1372	.4801	.4572
13	.3841	.1372	.1372	.4801	.503
14	.3841	.1372	.1372	.4801	.503
15		.1372	.1372	.427	.503
16	.3841	.1372	.2286	.427	.4915
17	.3201	.1372	.1372	.3749	.3749
18	.1372	.1372	.1372	.3241	.2743
19	.1372	.1372	.1372	.1806	.1337
20	.1372	.1372	.1372	.1806	.1337
21	.1372	.1372	.1372	.1806	.1337
22	.1372	.1372	.1372	.1337	
23	.1372	.1372	.1372	.1337	
24	.132	.1372	.1372	.1372	.1337
Max	.3841	.1372	3.2465	.4801	.503
Min	.132	.1372	.1372	.1337	.1337
Avg	.2097	.1372	.2706	.2655	.2597

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 201 / 11 KV Sector-19 Ulwe

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0743	2.1719		2.2862	
2	.0743	2.0957			
3	.0743	2.0957		2.2481	
4	.0743	2.0576			
5	.0743	2.2862		2.553	
6	.0743	2.572			
7	.0743	2.7435		2.6292	
8	.0743	2.4768			2.572
9	1.9243	2.3434		2.1148	2.3815
10	1.7909	2.1338			2.21
11		2.0386		2.0576	2.0576
12	1.9243	2.0957		1.9243	
13	1.9052	1.8671		1.8671	.8764
14	1.8099	1.9433		1.9243	.8002
15	1.6766	2.0386		1.9243	.7621
16	1.7147	2.0767		1.8671	
17				2.0767	
18				2.4577	
19				2.6863	
20				2.7435	
21				2.8387	
22				2.4958	
24	1.9814	2.21	2.2291		2.0957
Max	1.9814	2.7435	2.2291	2.8387	2.572
Min	.0743	1.8671	2.2291	1.8671	.7621
Avg	.9576	2.1910	2.2291	2.2762	1.7194

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 202 / 11 KV Sector-21 Ulwe

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2286		.2667	
2		.2286			
3		.2096		.2477	
4		.2096			
5		.2096		.2858	
6		.2477			
7		.2667		.3239	
8		.2477			.3048
9	.3239	.2477		.3048	.3048
10	.2667	.2667			.2477
11	.2286	.2858		.2477	.2286
12	.2096	.2667		.2286	.2096
13	.2286	.2667		.2477	.1905
14	.1905	.2477		.2286	.1905
15	.1715	.2096		.2096	.1905
16	.1715	.2477		.2286	
17				.2667	
18				.3048	
19				.2858	
20				.3048	
21				.3239	
22				.2858	
24	.2286	.2667	.2667		.2477
Max	.3239	.2858	.2667	.3239	.3048
Min	.1715	.2096	.2667	.2096	.1905
Avg	.2244	.2443	.2667	.2701	.2350

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 203 / 11 KV Unnati Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6859		.6859	
2		.6668			
3		.6478		.6478	
4		.6668			
5		.724		.743	
6		.7621			
7		.8002		.8764	
8	.7621	.7621			.8002
9	.7621	.743		.8192	.8002
10	.7811	.6668			.7811
11	.5906	.6478		.5906	.6097
12	.5335	.6097		.5525	.5716
13	.5335	.5525		.4954	.4572
14	.5335	.5716		.4954	.4763
15	.5335	.6478		.5144	.5716
16	.4382	.5144		.4954	
17				.5906	
18				.6859	
19				.8192	
20				.8192	
21				.8192	
24	.6287	.6859	.724		.6859
Max	.7811	.8002	.724	.8764	.8002
Min	.4382	.5144	.724	.4954	.4572
Avg	.6097	.6680	.724	.6656	.6393

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 204 / 11 KV Sector-5 Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6287		.6478	
2		.6097			
3		.5716		.6668	
4		.5716			
5		.6097		.8002	
6		.7621			
7		.8573		.8764	
8	.7811	.724			.8383
9	.6668	.6097		.6859	.6478
10	.5906	.6859			.5716
11	.4954	.7621		.5525	.6859
12	.4763	.6097		.5144	.6478
13	.4572	.4954		.4763	.4382
14	.4382	.4954		.4572	.4001
15	.4382	.4954		.4382	
16	.4382	.5335		.4763	
17				.6097	
18				.6859	
19				.743	
20				.724	
21				.743	
24	.6287	.6287	.6478		.6478
Max	.7811	.8573	.6478	.8764	.8383
Min	.4382	.4954	.6478	.4382	.4001
Avg	.5411	.6265	.6478	.6311	.6097

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 205 / 11 KV Sector-20 Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.381		.4191	
2		.381			
3		.381		.4001	
4		.4001			
5		.4191		.4382	
6		.4382			
7		.4382		.5335	
8	.5335	.5716			.5144
9	.4954	.5906		.5335	.4382
10	.4382	.5335			.4572
11	.4382	.4572		.4382	.4191
12	.362	.4572		.362	.381
13	.3429	.4382		.4001	.362
14	.3429	.4191		.381	.362
15	.3239	.4191		.362	.362
16	.4191	.4763		.4191	
17				.4382	
18				.4572	
19				.4763	
20				.4763	
21				.4763	
24	.362	.4001	.4001		.4191
Max	.5335	.5906	.4001	.5335	.5144
Min	.3239	.381	.4001	.362	.362
Avg	.4058	.4471	.4001	.4382	.4128



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 206 / 11 KV Sec-5 Plot No-70 SHEDDABLE URBAN  
Ulwe Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0381		.0762	
2		.0381			
3		.0381		.0572	
4		.0572			
5		.0572		.0762	
6		.0572			
7		.0572		.0762	
8	.0762	.0572			.0572
9	.0572	.0762		.0572	.0762
10	.0953	.0572			.0572
11	.0953	.0572		.0762	.0762
12	.0762	.0762		.0572	.0762
13	.0762	.0572		.0572	.0572
14	.0762	.0572		.0572	.0572
15		.0572		.0572	.0572
16	.0572	.0572		.0572	
17				.0572	
18				.0572	
19				.0762	
20				.0762	
21				.0762	
24	.0572	.0572	.0572		.0572
Max	.0953	.0762	.0572	.0762	.0762
Min	.0572	.0381	.0572	.0572	.0572
Avg	.0741	.0561	.0572	.0655	.0635

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 207 / 11 KV Ulwe Sub Station

SHEDDABLE URBAN

Transfo Feeder KV- 11 / OUTGOING

DATE	09-DEC-17
HR	Load (MW)
8	.1524
16	.2477
Max	.2477
Min	.1524
Avg	.2001

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 208 / 11 KV Wahal Sec-23

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.8671		1.9243	
2		1.7909			
3		1.7909		1.7909	
4		1.7528			
5		1.9052		1.9433	
6		2.0005			
7		1.9624		2.0576	
8	1.9624	2.0957			1.7528
9	1.8861	2.21		1.3527	2.0957
10	1.6004	2.0957			2.1148
11	1.7147	1.9624		1.6194	1.448
12	1.6956	1.8671		1.6575	1.467
13	1.6575	1.6194		1.5623	1.6956
14	1.3336	1.4289		1.4098	1.5051
15	1.2765	1.3527		1.3146	1.4861
16	1.448	1.4861		1.4289	
17				1.5813	
18				1.7528	
19				1.9052	
20				2.0576	
21				2.1338	
22				2.1148	
24	1.1622	1.8861	1.8861		1.8861
Max	1.9624	2.21	1.8861	2.1338	2.1148
Min	1.1622	1.3527	1.8861	1.3146	1.448
Avg	1.5737	1.8279	1.8861	1.7416	1.7168

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 201 / 11KV AIR INDIA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975	.6535	.7095	.7095	.6348
2	.5601	.5975	.6722	.6722	.5975
3	.5601	.5601	.6348	.6348	.5975
4	.5975	.5601	.6348	.6348	.5788
5	.6722	.5788	.6348	.6722	.5975
6	.7842	.6722	.6722	.8029	.7468
7	.9522	.7842	.6535	.9335	.9522
8	.8589	.7468	.6908	.8589	.8962
9	.8962	.8775	.8589	.8589	.8589
10	.8589	.9149	.8589	.8589	.8215
11	.8215	.8962	.9149	.8029	.7842
12	.8402	.8589	1.0082	.8215	.8402
13	.8402	.8402	.9522	.8215	.7095
14	.7468	.7282	.8029	.6348	.6348
15	.6535	.7095	.7468	.5975	.6348
16	.6348		.6908	.6348	.6161
17	.5788	.6722	.7282	.6908	.6535
18	.8402	.9149	.8589	.7282	.6908
19	.8402	.8589	.8775	.7842	.8402
20	.8589	.8589	.8402	.8589	.8589
21	.8402	.8402	.8402	.8589	.8402
22	.7842	.8029	.8215	.8402	.8215
23	.7842	.8029	.8215	.7842	.7282
24	.6722	.7282	.7468	.7468	.6722
Max	.9522	.9149	1.0082	.9335	.9522
Min	.5601	.5601	.6348	.5975	.5788
Avg	.7531	.7590	.7780	.7601	.7336

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 202 / 11KV JAWAHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	.1867	.1494	.168	.1494
2	.1494	.168	.1494	.1494	.1494
3	.1494	.1494	.1494	.1494	.1494
4	.1494	.1494	.1494	.1494	.1494
5	.1494	.1494	.1494	.1494	.1494
6	.168	.1494	.168	.1867	.168
7	.2427	.168	.1867	.2054	.2241
8	.2054	.1494	.1867	.2427	.2801
9	.2614	.168	.2427	.2427	.2614
10	.2054	.2987	.2614	.2987	.3361
11	.3174	.2801	.3174	.2801	.3174
12	.3361	.3174	.3174	.3174	.3174
13	.2801	.2987	.2801	.3174	.3174
14	.2427	.2427	.2427	.2614	.2801
15	.2054	.2801	.2427	.2614	.2801
16	.2427	.2614	.2614	.2427	.2614
17	.2801	.2987	.2614	.2614	.2801
18	.3174	.2987	.3174	.168	.168
19	.3174	.3174	.3174	.1867	.2241
20	.2987	.3361	.3174	.2054	.2427
21	.2987	.3174	.3174	.2241	.2054
22	.2987	.3174	.2987	.2054	.2054
23	.2241	.2427	.2241	.168	.168
24	.1494	.2054	.1867	.1867	.168
Max	.3361	.3361	.3174	.3174	.3361
Min	.1494	.1494	.1494	.1494	.1494
Avg	.2357	.2396	.2373	.2178	.2272

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 203 / 11KV BANK OF INDIA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5041	.4108	.3734	.4108	.4668
2	.4481	.3734	.3361	.3734	.4108
3	.3734	.3361	.3361	.3361	.3921
4	.3361	.3361	.3361	.3361	.3921
5	.3734	.3921	.3361	.4854	.4294
6	.4294	.4668	.6348	.5415	.5788
7	.7468	.7095	.6722	.7282	.7468
8	.6348	.5975	.5975	.8589	.8589
9	.8402	.5228	.6161	.8589	.5601
10	.4668	.5601	.5415	.4481	.5041
11	.4854	.5228	.4294	.5041	.5041
12	.4668	.4854	.5041	.4854	.4854
13	.3734	.5041	.4481	.5041	.5228
14	.5041	.3547	.5415	.5041	.2987
15	.4108	.3547	.4668	.4481	.3734
16	.5975	.3361	.2987	.4481	.4294
17	.5975	.4294	.5975	.4854	.5975
18	.6161	.6161	.5041	.6161	.3921
19	.7655	.8402	.8589	.6348	.8145
20	.6348	.6535	.5975	.6348	.5975
21	.6161	.6535	.5975	.5041	.4668
22	.5228	.5975	.6348	.5415	.5228
23	.5975	.5788	.5228	.5975	.5228
24	.4294	.5041	.5041	.4481	.5228
Max	.8402	.8402	.8589	.8589	.8589
Min	.3361	.3361	.2987	.3361	.2987
Avg	.5321	.5057	.5119	.5306	.5163

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 205 / 11KV ARMY NIWAS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1494	.1867	.168	.1494
2	.1494	.1494	.168	.1494	.1494
3	.1494	.1494	.168	.1494	.1494
4	.1494	.1494	.168	.1494	.1494
5	.1494	.1494	.168	.1494	.1494
6	.168	.168	.3361	.168	.168
7	.2614	.2427	.2054	.2614	.2614
8	.3174	.2801	.2614	.3361	.2987
9	.2987	.3174	.2987	.2801	.3174
10	.2614	.2987	.2614	.2987	.2614
11	.2054	.2427	.2614	.2241	.2054
12	.2427	.2987	.2801	.2614	.2427
13	.2241	.2054	.2241	.2054	.168
14	.1867	.1867	.2241	.168	.168
15	.2054	.1867	.1867	.168	.168
16	.1867	.1867	.1494	.168	.168
17	.168	.1867	.168	.168	.168
18	.2241	.2614	.168	.2614	.2614
19	.2801	.2614	.2241	.2427	.2241
20	.2427	.2427	.2054	.2427	.2427
21	.2614	.2614	.2054	.2427	.2427
22	.2427	.2427	.1867	.2427	.2241
23	.2241	.2012	.2241	.1867	.2241
24	.168	.1494	.2054	.1867	.168
Max	.3174	.3174	.3361	.3361	.3174
Min	.1494	.1494	.1494	.1494	.1494
Avg	.2132	.2153	.2139	.2116	.2054

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 206 / 11 KV LENYADRI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.3174	.2987	.2987	.2987
2	.2987	.2987	.2801	.4668	.2801
3	.2987	.2614	.2801	.2801	.2801
4	.2801	.2614	.2801	.2987	.2801
5	.2987	.2801	.2987	.3174	.2987
6	.3361	.3361	.3174	.3361	.3547
7	.3547	.3734	.3361	.3547	.4294
8	.4108	.3734	.3361	.3734	.4481
9	.4294	.4294	.3921	.3921	.4481
10	.3921	.3921	.3921	.4854	.4854
11	.3547	.4668	.4481	.4108	.4108
12	.3174	.4108	.3734	.2987	.3361
13	.3174	.3921	.3921	.3547	.3174
14	.3174	.3361	.3361	.2987	.3174
15		.3547	.3174	.3174	.3174
16	.3174	.3734	.3174	.3361	.3361
17	.3361	.3734	.5975	.2987	.2987
18	.4108	.4294	.3921	.3921	.3921
19	.4481	.4668	.4854	.4108	.4481
20	.4294	.4668	.4481	.4481	.4294
21	.4294	.4481	.4481	.4294	.4108
22	.3921	.4294	.3547	.4108	.3921
23	.3734	.4294	.3547	.3174	.3921
24	.3174	.3361	.3547	.3361	.3174
Max	.4481	.4668	.5975	.4854	.4854
Min	.2801	.2614	.2801	.2801	.2801
Avg	.3547	.3765	.3680	.3610	.3633



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 207 / 11KV BHIMA SHANKAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.4854	.5228	.5228	.4668
2	.4294	.4481	.4854	.4854	.4481
3	.4108	.4294	.4481	.4481	.4108
4	.4294	.4294	.4481	.4481	.4108
5	.4668	.4668	.4481	.5601	.4481
6	.5601	.5041	.4481	.6535	.5601
7	.6535	.5601	.4854	.6908	.6348
8	.6535	.6161	.4854	.7095	.7095
9	.6348	.6348	.6722	.6161	.6348
10	.6535	.6535	.7095	.5975	.5601
11	.5041	.6348	1.6057	.5788	.5041
12	.4668	.5601	.6535	.5601	.4854
13	.4854	.5601	.5415	.4668	.4668
14	.4668	.4668	.5415	.4294	.3921
15	.4108	.4481	.4668	.3921	.3921
16	.3921	.4108	.4108	.3921	.3734
17	.3361	.4668	.4854	.3921	.3921
18	.5228	.6161	.6161	.5415	.5601
19	.6161	.7095	.6348	.5975	.5975
20	.6161	.6722	.6908	.6908	.5975
21	.7095	.6908	.6908	.6535	.6348
22	.6535	.6535	.6161	.6161	.6348
23	.6161	.6348	.6535	.5975	.5975
24	.4854	.5415	.5601	.5415	.5041
Max	.7095	.7095	1.6057	.7095	.7095
Min	.3361	.4108	.4108	.3921	.3734
Avg	.5259	.5539	.5967	.5492	.5173

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 209 / 11 KV STN TRF

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0187	.0187	.0187	.0187
2	.0187	.0187	.0187	.0187	.0187
3	.0187	.0187	.0187	.0187	.0187
4	.0187	.0187	.0187	.0187	.0187
5	.0187	.0187	.0187	.0187	.0187
6	.0187	.0187	.0187	.0187	.0187
7	.0187	.0187	.0187	.0187	.0187
8	.0187	.0187	.0187	.0187	.0187
9	.0187	.0187	.0187	.0187	.0187
10	.0187	.0187	.0187	.0187	.0187
11	.0187	.0187	.0187	.0187	.0187
12	.0187	.0187	.0187	.0187	.0187
13	.0187	.0187	.0373	.0187	.0187
14	.0187	.0187	.0187	.0187	.0187
15	.0187	.0187	.0187	.0187	.0187
16	.0187	.0187	.0187	.0187	.0187
17	.0187	.0187	.0187	.0187	.0187
18	.0187	.0187	.0187	.0187	.0187
19	.0187	.0187	.0187	.0187	.0187
20	.0187	.0187	.0187	.0187	.0187
21	.0187	.0187	.0187	.0187	.0187
22	.0187	.0187	.0187	.0187	.0187
23	.0187	.0187	.0187	.0187	.0187
24	.0187	.0187	.0187	.0187	.0187
Max	.0187	.0187	.0373	.0187	.0187
Min	.0187	.0187	.0187	.0187	.0187
Avg	.0187	.0187	.0195	.0187	.0187

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

NERUL S/DN.[642] BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 202 / 11KV APPEJAY SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17
HR	Load (MW)
1	.4294
2	.4108
3	.3921
4	.3772
5	.3961
6	.4338
8	.5658
9	.5847
24	.4481
Max	.5847
Min	.3772
Avg	.4487

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

NERUL S/DN.[642] BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 203 / 11KV CIDCO OFFICE SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17
HR	Load (MW)
1	.4115
2	.3641
3	.3467
4	.3467
5	.3641
6	.4207
7	.4784
8	.5373
9	.5731
24	.4287
Max	.5731
Min	.3467
Avg	.4271

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 204 / 11KV STEP GARDEN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024	.4435	.4207	.439	.3658
2	.3658	.4435	.3841	.3841	
3	.3658	.3881	.3658	.3658	.2987
4	.4024	.3511	.3258	.3696	.3142
5	.462	.3881	.3439	.462	.3881
6	.4805	.4251	.4207	.5544	.4251
7	.4805	.462	.4251	.499	.462
8	.499	.4435	.4805	.499	.4854
9	.4805	.4805	.5175	.4435	.4066
10		.4805	.499	.4805	
11		.4572	.5175	.4207	
12		.4435	.4805	.4207	
13		.4024	.499	.4344	
14		.3841	.462	.362	
15		.3658	.4066	.362	
16		.3439	.4207	.3475	
17		.362	.4024	.3258	
18		.4525	.5249	.394	
19	.5121	.5487	.5487	.4887	
20	.5359	.543	.543	.5068	
21	.5175	.5304	.5304	.4755	
22	.4805	.4755	.5304	.4572	
23		.4572	.5121	.439	
24	.4163	.4435	.4572	.4572	.4024
Max	.5359	.5487	.5487	.5544	.4854
Min	.3658	.3439	.3258	.3258	.2987
Avg	.4572	.4382	.4591	.4329	.3943

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 205 / 11KV JUINAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8596	.924	1.0164	1.0349	.961
2	.8131	.8779	.9335	.924	.924
3	.7392	.8048	.8316	.8501	.8316
4	.7468	.823	.7947	.7577	.8775
5	.8686	.9145	.8686	.9335	.9335
6	1.1016	.9694	.9979	1.2323	1.0269
7	1.2696	1.2803	.961	1.307	1.251
8	1.5339	1.4632	1.5154	1.5893	1.5339
9	1.2936	1.3535	1.4415	1.386	1.2567
10		1.1888	1.3491	1.1273	
11		.9979	1.1389	.9328	
12		.8871	.9979	.7392	
13		.8402	.9055	.7316	
14		.7947	.8871	.7133	
15		.7392	.8316	.6653	
16		.7207	.8131	.6219	
17		.7392	.8501	.6767	
18		1.0317	1.1706	.8869	
19	1.2071	1.1946	1.3032	1.1946	
20	1.3306	1.3394	1.3937	1.3032	
21	1.2936	1.3213	1.3169	1.2127	
22	1.1827	1.2437	1.2254	1.1888	
23		1.1273	1.2012	1.0903	
24	.9877	.9979	1.0534	1.1088	.9979
Max	1.5339	1.4632	1.5154	1.5893	1.5339
Min	.7392	.7207	.7947	.6219	.8316
Avg	1.0877	1.0239	1.0749	1.0087	1.0594

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 206 / 11KV TRUPTI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5359	.6401	.5914	.6283	.5914
2	.462	.6099	.5601	.5914	.5544
3	.3881	.5729	.5228	.5544	.4854
4	.4251	.5359	.499	.6099	.5041
5	.5228	.5914	.5359	.7095	.6161
6	.6535	.6283	.5788	.7655	.6535
7	.7282	.6653	.6348	.8029	.7468
8	.8215	.6653	.7842	.8962	.8402
9	.7282	.7762	.7468	.7842	.7655
10		.6653	.7095	.6584	
11		.6468	.7392	.6036	
12		.6468	.6516	.5853	
13		.6099	.6154	.6036	
14		.5853	.5853	.5487	
15		.5487	.5729	.5121	
16		.5304	.5487	.5249	
17		.567	.6154	.5249	
18		.7522	.8145	.7087	
19	.7783	.8596	.8869	.8145	
20	.8779	.8869	.9231	.8507	
21	.823	.8779	.8326	.8048	
22	.7499	.7865	.7865	.7499	
23		.7316	.7499	.6767	
24	.6099	.6401	.6468	.6838	.6283
Max	.8779	.8869	.9231	.8962	.8402
Min	.3881	.5304	.499	.5121	.4854
Avg	.6503	.6675	.6722	.6747	.6386

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 207 / 11KV AUGUSTEEN FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.8962	.9335	.9055	.8775
2	.415	.8215	.8488	.8316	.8402
3	.3961	.7655	.7545	.7577	.7842
4	.4527	.8215	.7655	.7947	.8871
5	.5281	.9335	.8029	.9335	1.0164
6	.6161	.9896	1.0082	1.1763	1.1088
7	.4854	1.1203	.8402	1.0164	1.0534
8	.7282	1.2323	1.1949	1.423	1.3121
9	.7842	1.1016	1.2696	1.2567	1.1643
10		1.0829	1.0456	1.2382	
11		1.1763	1.1827	1.1643	
12		1.2323	1.2752	1.0903	
13		1.1949	1.1827	1.0903	
14		1.0269	1.1273	1.0349	
15		1.0082	1.0164	.961	
16		.9896	.9055	.961	
17		1.0269	.9795	.9979	
18		1.251	1.4969	1.2012	
19	1.4937	1.587	1.5708	1.5154	
20	1.4563	1.587	1.4415	1.4415	
21	1.2883	1.3443	1.2752	1.2382	
22	1.1203	1.2323	1.1458	1.1458	
23		1.0456	1.1088	1.0164	
24	.4668	.9522	.9896	.9795	.9055
Max	1.4937	1.587	1.5708	1.5154	1.3121
Min	.3961	.7655	.7545	.7577	.7842
Avg	.7601	1.1008	1.0901	1.0905	.9950



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 208 / 11KV RAILWAY COMPLEX

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1886	.2075	.1867
2	.1886	.1715	.1698	.1886	.1698
3	.1698	.1715	.1509	.1698	.1509
4	.168	.1524	.1494	.1698	.168
5	.1867	.1524	.168	.1886	.1867
6	.2033	.1715	.1848	.2075	.1867
7	.2452	.1905	.2096	.2263	.2263
8	.2263	.2096	.2012	.2801	.2427
9	.3018	.2641	.2427	.3429	.2829
10		.3395	.3429	.3961	
11		.362	.362	.4527	
12		.362	.3961	.4715	
13		.362	.3961	.4715	
14		.3961	.3772	.4527	
15		.3772	.3584	.4715	
16		.3961	.3239	.4338	
17		.3772	.3048	.4338	
18		.3921	.3395	.4435	
19	.5041	.4108	.3395	.4481	
20	.4294	.3772	.3584	.4294	
21	.3734	.3206	.3395	.3239	
22	.2427	.2858	.3206	.2858	
23		.2286	.3239	.2263	
24	.2263	.1886	.2075	.2263	.2054
Max	.5041	.4108	.3961	.4715	.2829
Min	.168	.1524	.1494	.1698	.1509
Avg	.2610	.2853	.2815	.3312	.2006

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 201 / 11KV NRI COMPLEX

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9694	1.0608	1.0974	1.1157	.9511
2	.9145	.9877	1.0425	1.1088	.9145
3	.8413	.9511		1.0164	.8779
4	.9511	.8962		1.0719	.8413
5	1.0608	.9145		1.2012	.9877
6	1.2254	.9511		1.2382	1.134
7	1.2803	1.0425		1.3491	1.2986
8	1.3169	1.2752		1.2567	1.2752
9	1.2803	1.2936		1.3717	1.2936
10	1.2437	1.4969	1.3535	1.3169	1.2567
11	1.2437		1.39	1.1888	1.1888
12	1.2437	1.2936		1.1523	1.0974
13	1.1157			1.1523	1.0974
14	1.0974	1.1706	1.1888	1.0974	1.0974
15	1.1888			1.0608	1.0608
16	1.0242			1.0242	.9877
17	1.0242		1.0059	1.0608	.9328
18	1.0349			1.1273	1.2437
19	1.2197			1.262	1.3352
20	1.3306			1.423	1.3717
21	1.3121			1.386	1.4266
22	1.2567	1.2437	1.3169	1.2936	1.2803
23	1.2012	1.1888	1.2803	1.1643	
24	1.0242	1.1458	1.134	1.1523	1.0164
Max	1.3306	1.4969	1.39	1.423	1.4266
Min	.8413	.8962	1.0059	1.0164	.8413
Avg	1.1417	1.1275	1.2010	1.1913	1.1290

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 203 / 11KV BPCL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9328	1.0974	1.0608	1.0974	.9145
2	.8413	1.0608	1.0059	1.0425	.8779
3	.9145	.9511		1.0059	.8048
4	1.0608	.8779		1.0608	.8413
5	1.2803	.9877		1.1706	.9511
6	1.4998	1.2437		1.2986	1.1706
7	1.5729	1.3352		1.6095	1.4083
8	1.6461	1.3121		1.5729	1.5893
9	1.4998	1.3491		1.4266	1.4784
10	1.4083	1.4969	1.4632	1.4998	1.3306
11	1.3169		1.4998	1.39	1.3352
12	1.2254	1.4045		1.3535	1.2803
13	1.262			1.2986	1.1888
14	1.1888	1.0974	1.3169	1.2803	.9511
15	1.0974			1.2437	1.0059
16	1.0059			1.1706	1.1157
17	1.2803		1.3717	1.2803	1.2254
18	1.5154			1.423	1.5181
19	1.46			1.4784	1.5729
20	1.423			1.5708	1.5546
21	1.3676			1.6817	1.5181
22	1.2936	1.4266	1.3717	1.5154	1.3169
23	1.2567	1.2071	1.3169	1.2197	
24	1.0242	1.1706	1.0974	1.0974	1.0164
Max	1.6461	1.4969	1.4998	1.6817	1.5893
Min	.8413	.8779	1.0059	1.0059	.8048
Avg	1.2656	1.2012	1.2783	1.3245	1.2159

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 204 / 11KV SWP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.2614	.3174	.2241	.2241
2	.2241	.2614	.3174	.1867	.1867
3	.1867	.2614		.1867	.1494
4	.1494	.2801		.1494	.1494
5	.1867	.3361		.2054	.1867
6	.2241	.3547		.2241	.1867
7	.3734	.4108		.3361	.2241
8	.5601	.5544			.499
9	.5601	.4435		.4108	.5175
10	.5601	.4066	.4294	.4108	.5175
11	.5041		.4481	.5601	.5601
12	.4435	.5544		.5228	.4481
13	.2614			.4481	.4108
14	.4108	.2957	.3361	.4481	.4481
15	.5415			.4108	.4668
16	.6161			.4108	.4481
17	.5601		.2614	.4108	.4481
18	.3511			.4251	.2614
19	.3511			.3511	.2987
20	.3881			.3326	.2427
21	.3881			.3142	.2427
22	.3511	.2241	.2427	.2957	.2241
23	.3511	.3361	.1867	.2987	
24	.3361	.3142	.3361	.2054	.2402
Max	.6161	.5544	.4481	.5601	.5601
Min	.1494	.2241	.1867	.1494	.1494
Avg	.3816	.3530	.3195	.3378	.3296

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 205 / 11KV DELHI PUBLIC SCHOOL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0572	.0572	.0381
2	.0381	.0381	.0572	.0572	.0381
3	.0381	.0381		.0381	.0381
4	.0381	.0381		.0572	
5	.0381	.0572		.0572	.0381
6	.0381	.0572		.0572	.0572
7	.0762	.0381			.0762
8	.1334	.0762		.0953	.0953
9	.1334	.0953		.1334	.0953
10	.1334	.0953	.0762	.1334	.0953
11	.1334		.0572	.0953	.0762
12	.1334	.0762		.0953	.0762
13	.0953			.0953	.0762
14	.0762	.0762	.0572	.0762	.0572
15	.0572			.0762	.0572
16	.0572			.0762	.0762
17	.0572		.0572	.0572	.0762
18	.0572			.0572	.0762
19	.0572			.0381	.0762
20	.0572			.0572	.0572
21	.0572			.0572	.0953
22	.0572	.0572	.0572	.0572	.0762
23	.0572	.0572	.0762	.0572	
24	.0572	.0381	.0762	.0572	.0572
Max	.1334	.0953	.0762	.1334	.0953
Min	.0381	.0381	.0572	.0381	.0381
Avg	.0715	.0584	.0635	.0713	.0684

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 206 / 11KV NEELKANTH TOWER  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	1.1827	1.1706	1.2071	1.1458
2	1.0242	1.1458	1.1157	1.1888	1.0719
3	.9694	1.1088		1.1523	.9979
4	1.0974	1.0719		1.2254	.961
5	1.3535	1.1827			1.1088
6	1.5729	1.2936		1.5546	1.423
7	1.6095	1.423		1.6095	1.5893
8	1.6461	1.4815		1.5912	1.5729
9	1.6095	1.4815		1.5729	1.5546
10	1.5729	1.6278	1.39	1.4266	1.5181
11	1.5339		1.5729	1.46	1.5546
12	1.5339	1.6095		1.4937	1.5364
13	1.423			1.4784	1.4632
14	1.3676	1.3535	1.3535	1.4045	1.39
15	1.3676			1.4415	1.39
16	1.4083			1.423	
17	1.4784		1.4083	1.4784	1.3717
18	1.5364			1.5364	1.6644
19	1.6278			1.6644	1.6827
20	1.5364			1.6461	1.5364
21	1.4449			1.5546	1.4998
22	1.4083	1.4266	1.4632	1.4632	1.39
23	1.3535	1.39	1.39	1.3535	
24	1.1888	1.2437	1.2071	1.2437	1.1706
Max	1.6461	1.6278	1.5729	1.6644	1.6827
Min	.9694	1.0719	1.1157	1.1523	.961
Avg	1.4067	1.3348	1.3413	1.4422	1.3906

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 207 / 11KV KOKAN RAILWAY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6653	.7468	.7023	.7762	.6722
2	.6099	.7095	.6653	.7392	.6348
3	.5544	.6535		.8131	.7095
4	.6468			.924	.8215
5	.8131	.6722		1.0164	.9335
6	1.0349	.7468			1.0269
7	1.0164	.8029		1.0719	1.1389
8	1.0164	.9425		1.0719	1.0349
9	1.0164	.9979		.9979	.9979
10	1.0349	1.0349	1.1088	.961	.9425
11	.9335		1.0719	.8871	.8316
12	.7842	.7392		.8215	.7762
13	.7095			.7655	.6653
14	.6535	.7023	.7762	.7095	.6099
15	.6161			.6535	.6099
16	.5041			.6535	.6468
17	.6161		.7947	.7468	.7023
18	.8131			.7947	.924
19	.9795			.9795	.9795
20	.9979			1.0349	.9425
21	.961			.9795	.961
22	.8871	.9425	.9425	.8871	.8686
23	.8316	.8871	.924	.7947	
24	.7392	.7762	.7392	.8131	.7133
Max	1.0349	1.0349	1.1088	1.0719	1.1389
Min	.5041	.6535	.6653	.6535	.6099
Avg	.8098	.8110	.8583	.8649	.8323

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 208 / 11kV KENDRIYA VIHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	1.0719	1.0974	.2926	1.0349
2	.8413	.9979	1.0719	.9425	1.0082
3	.9511	.924		.9979	.961
4	1.0974	.8686		1.1273	.9979
5	1.2071	.961		1.2936	1.1827
6	1.3169	1.0719		1.386	1.2936
7	1.3717	1.1458		1.4784	1.3676
8	1.4266	1.3717		1.4784	1.3352
9	1.3717	1.2936		1.386	1.3717
10	1.3352	1.4083	1.4266	1.3535	1.3535
11	1.3491		1.4449	1.39	1.3169
12	1.3491	1.4632		1.3491	1.2071
13	1.2567			1.2936	1.2071
14	1.2012	1.2254	1.3169	1.2567	1.1523
15	1.1643			1.2012	1.1888
16	1.1088			1.2382	1.2437
17	1.2567		1.3717	1.3306	1.2803
18	1.39			1.4083	1.6095
19	1.5912			1.5729	1.6095
20	1.5729			1.6461	1.5364
21	1.5364			1.5181	1.4998
22	1.39	1.4266	1.4449	1.3169	1.2254
23	1.2071	1.2437	1.2803	1.1888	
24	1.0242	1.0974	1.1157	1.0242	1.0425
Max	1.5912	1.4632	1.4449	1.6461	1.6095
Min	.8413	.8686	1.0719	.2926	.961
Avg	1.2596	1.1714	1.2856	1.2696	1.2620



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284008 / 33/11 KV Amey Sec-6 Nerul

Feeder No / Name : 203 / 11 KV E type Wadhva

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3475	.3109	.3475	.4024	.3292
2	.3292	.3109		.3658	.3292
3	.3292	.2926		.3658	.3109
4	.3109	.2926		.3292	.3475
5	.3292	.2926		.3109	.4024
6	.3475	.3475		.4024	.4207
7	.4755	.4024		.5487	.4755
8	.4755	.4207	.4024	.4938	.4207
9	.5304	.4755	.439	.5487	.5853
10	.3841		.3841	.439	.3841
11	.439	.4755	.5304	.4207	.439
12	.3475	.4938	.5487	.3475	.4024
13	.3292	.4207	.4755	.3475	.3292
14	.3292	.4481	.4024	.3475	.3475
15	.3292	.3475	.4024	.2926	.3475
16	.3475	.3841	.3841	.2926	
17	.3841	.3658	.4207	.3292	.3658
18	.3475		.4755	.3475	.4572
19	.439	.5121	.5121	.3841	.4938
20	.4755	.4938	.5121	.439	.5121
21	.4755	.439	.5487	.4755	.4938
22	.4207	.4572	.4572	.439	.4572
23	.4024	.3841	.4024	.4207	.4755
24	.3475	.3658	.3658	.4024	.3658
Max	.5304	.5121	.5487	.5487	.5853
Min	.3109	.2926	.3475	.2926	.3109
Avg	.3864	.3970	.4451	.3955	.4127

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284008 / 33/11 KV Amey Sec-6 Nerul

Feeder No / Name : 204 / 11 KV Great Eastern

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.4854	.4854	.5228	.4294
2	.4481	.4854		.5228	.3547
3	.4108	.4668		.4854	.3547
4	.4108	.4668		.4481	.3734
5	.4481	.4668		.4481	.4481
6	.4854	.4294		.4854	.5041
7	.5228	.4294		.5041	.5788
8	.5975	.5228		.6161	.5788
9	.6161	.6535		.7095	.6908
10	.7842		.6535		.6908
11	.8215	.4668	.6348	.8029	.7282
12	.7655	.8215	.6722	.7095	.7655
13		.6908	.6908	.7095	.7095
14	.6908	.6535	.5415	.6722	.6161
15	.6722	.5601	.4854	.6535	.6535
16	.6722	.6161	.4481	.6908	
17	.6908	.5788	.4854	.7282	.5601
18	.7282		.5788	.7282	.7468
19	.7468	.7095		.6722	.6908
20	.7655	.6535	.6161	.6722	.6722
21	.7282	.6348	.6348	.6348	.6535
22	.6161	.6161	.6348	.6348	.5601
23	.5975	.4294	.5788	.5601	.5415
24	.4854	.5415		.5415	.5041
Max	.8215	.8215	.6908	.8029	.7655
Min	.4108	.4294	.4481	.4481	.3547
Avg	.6153	.5627	.5815	.6153	.5828

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284009 / 33 KV Sec-19A Nerul

Feeder No / Name : 201 / Station Transformer

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0183		.0183	
2		.0183		.0183	
3		.0183		.0183	
4		.0183		.0183	
5		.0183		.0183	
6				.0183	
7				.0183	
8		.0183		.0183	
9		.0183		.0183	
10	.0183		.0183		.0183
11	.0183		.0183		.0183
12	.0183		.0183		.0183
13	.0183		.0183		.0183
14	.0183		.0189		.0183
15	.0183		.0183		.0183
16	.0183		.0189		.0183
17	.0183		.0183		.0183
18	.0183		.0183		.0183
19	.0183		.0183		.0183
20	.0183		.0183		.0183
21	.0183		.0183		.0183
22	.0183		.0183		.0183
23	.0183		.0183		.0183
24		.0183		.0183	
Max	.0183	.0183	.0189	.0183	.0183
Min	.0183	.0183	.0183	.0183	.0183
Avg	.0183	.0183	.0184	.0183	.0183

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284009 / 33 KV Sec-19A Nerul

Feeder No / Name : 202 / RHYAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0297	.0366	.032	.0366	.0297
2	.0297	.0366	.0316	.0366	.0297
3	.0297	.0366	.0316	.0366	.0297
4	.0297	.0366	.032	.0366	.0297
5	.0297	.0366	.032	.0366	.0297
6	.0297	.0366	.032	.0366	.0297
7	.0297	.0366	.032	.0366	.0297
8	.0297	.0366	.032	.0351	.0297
9	.0297	.0366	.048	.0366	.0297
10	.0366	.032	.0366	.0297	.0366
11	.0366	.048	.0366	.0297	.0549
12	.0549	.048	.0366	.0297	.0549
13	.0549	.048	.0366	.0297	.0366
14	.0366	.048	.0366	.0297	.0366
15	.0366	.048	.0366	.0377	.0549
16	.0366	.048	.0366	.0377	.0366
17	.0366	.032	.0366	.0297	.0366
18	.0366	.032	.0366	.0377	.0366
19	.0366	.032	.0366	.0297	.0366
20	.0366	.032	.0366	.0297	.0366
21	.0366	.032	.0366	.0297	.0366
22	.0366	.032	.0366	.0297	.0366
23	.0366	.032	.0366	.0297	.0366
24	.0297	.0366	.032	.0366	.0297
Max	.0549	.048	.048	.0377	.0549
Min	.0297	.032	.0316	.0297	.0297
Avg	.0353	.0379	.0353	.0335	.0360

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284009 / 33 KV Sec-19A Nerul

Feeder No / Name : 204 / NCRD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1088	1.1157	1.2136	1.1157	1.1458
2	1.0719	1.0059	1.1203	1.0791	1.1827
3	1.0349	.8779	1.0269	1.0059	1.2012
4	1.0903	.8962	.961	.9511	1.2936
5	1.1088	.8779	.961	.9145	1.3121
6	1.1643	1.0059	1.0269	1.1157	1.3676
7	1.2012	1.0974	1.0642	1.3352	1.386
8	1.423	1.2437	1.1949	1.3535	1.3491
9	1.4784	1.39	1.3443	1.5181	1.423
10	1.4998	1.6057	1.5364	1.7002	1.6095
11	1.7924	1.9044	1.701	1.7926	1.829
12	1.9204	2.0351	1.7558	1.7926	1.7924
13	1.8473	1.8671	1.7193	1.8111	1.7193
14	1.6827	1.8671	1.5912	1.7187	1.5912
15	1.5912	1.7177	1.4266	1.7372	1.6461
16	1.5364	1.6991	1.4266	1.8111	1.6461
17	1.6095	1.7364	1.5364	1.8296	1.6095
18	1.7193	1.8484	1.7558	1.8296	1.7924
19	1.7741	1.8671	1.8473	1.8111	1.7193
20	1.6644	1.7737	1.7924	1.8111	1.6644
21	1.6095	1.7924	1.7375	1.7372	1.6095
22	1.5364	1.643	1.643	1.5154	1.4815
23	1.4083	1.4003	1.4815	1.3491	1.3169
24	1.1273	1.1706	1.251	1.2071	1.1458
Max	1.9204	2.0351	1.8473	1.8296	1.829
Min	1.0349	.8779	.961	.9145	1.1458
Avg	1.4584	1.4766	1.4215	1.4934	1.4931

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

NERUL S/DN.[642] BU 4642

Substation No/ Name :- 284009 / 33 KV Sec-19A Nerul

Feeder No / Name : 205 / Navdurga S/S

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4207	.4572	.4668	.4572	.4207
2	.3841	.4024	.3921	.4024	.4024
3	.3658	.3475	.3547	.3475	.3658
4	.3475	.3658	.3734	.3658	.4024
5	.4207	.4207	.4108	.4024	.4572
6	.4572	.439	.4481	.5304	.5487
7	.5304	.4755	.4854	.5853	.5853
8	.6401	.4755	.5228	.6401	.6036
9	.5853	.5853	.5415	.6036	.5853
10	.6036	.6722	.5487	.6401	.6219
11	.5853	.7095	.6036	.5487	.5121
12	.5304	.7095	.6767	.5487	.5121
13	.5304	.6535	.6401	.5304	.4755
14	.5121	.5601	.5853	.4938	.4938
15	.439	.5175	.4938	.4572	.4755
16	.4755	.5975	.567	.5487	.4572
17	.5304	.5788	.5121	.5853	.4938
18	.6036	.5788	.6219	.5853	.567
19	.5853	.6722	.6584	.6036	.6401
20	.6584	.6908	.6584	.6219	.6036
21	.5853	.6722	.6401	.5853	.5853
22	.5853	.5914	.5853	.5487	.5853
23	.5487	.5601	.567	.5304	.5487
24	.439	.5121	.5041	.5121	.439
Max	.6584	.7095	.6767	.6401	.6401
Min	.3475	.3475	.3547	.3475	.3658
Avg	.5152	.5519	.5358	.5281	.5159

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284009 / 33 KV Sec-19A Nerul

Feeder No / Name : 206 / 11 KV DY Patil

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	.695	.6602	.567	.5847
2	.6413	.6401	.6161	.5121	.5658
3	.6036	.567	.5601	.4938	.5281
4	.5658	.5487	.5175	.5304	.547
5	.5281	.5853	.5228	.6036	.6036
6	.547	.6036	.5601	.6401	.6413
7	.5658	.6036	.6161	.6767	.7167
8	.8299	.8596	.7468	.9511	.8488
9	.9808	.9694	.7282	1.0242	1.0374
10	1.1888	1.1506	.7682	1.3014	2.3411
11	1.2254	1.2696	.8596	1.3014	2.2497
12	1.1523	1.1763	.8962	1.2449	2.2314
13	1.1157	1.0829	.8596	1.2071	2.2131
14	1.1888	1.251	.8962	1.3014	2.0119
15	1.3169	1.2323	.8048	1.2637	2.1948
16	1.3169	1.1576	.8779	1.1694	2.0851
17	1.2254	1.1203	.8413	.9431	1.9753
18	.8596	.9709	.7316	1.0185	2.1216
19	.7316	.8299	.695	.8299	2.2862
20	.7499	.7842	.7316	.7545	2.1948
21	.6767	.7468	.695	.679	1.9022
22	.7682	.6722	.6584	.5847	1.8473
23	.7316	.7095	.7133	.7095	1.7193
24	.679	.7316	.7095	.6219	.6224
Max	1.3169	1.2696	.8962	1.3014	2.3411
Min	.5281	.5487	.5175	.4938	.5281
Avg	.8687	.8733	.7194	.8721	1.5029

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284009 / 33 KV Sec-19A Nerul

Feeder No / Name : 207 / 11 KV Brahmakumari

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4118	1.0791	1.1203	1.1157	1.0498
2	1.0679	1.0059	.9774	1.0608	1.0136
3	1.086	.9328	.9335	1.0059	.9955
4	1.1765	.8962	.924	.9877	1.0679
5	1.2489	.9511	1.0269	1.0242	1.086
6	1.267	1.1888	1.0829	1.1523	1.1765
7	1.3032	1.2803	1.1763	1.3535	1.2851
8	1.3032	1.3717	1.251	1.4266	1.4118
9	1.2851	1.2437	1.363	1.2437	1.2851
10	1.2437	1.4563	1.4083	1.2826	1.1706
11	1.2437	1.3256	1.4083	1.2449	1.2254
12	1.1888	1.419	1.4266	1.2071	1.1523
13	1.1888	1.3817	1.3306	1.1694	1.0974
14	1.0974	1.2696	1.1706	1.0136	1.0425
15	.9694	1.1016	1.0974	1.0136	.9877
16	1.0059	1.1203	1.0791	1.086	1.0059
17	1.0242	1.307	1.1706	1.2851	1.0791
18	1.2437	1.419	1.39		1.1888
19	1.4632	1.531	1.4632	1.4299	1.39
20	1.4632	1.5123	1.5181	1.5023	1.4083
21	1.4083	1.4377	1.4083	1.4118	1.39
22	1.3717	1.4563	1.3535	1.2489	1.3535
23	1.2803	1.2883	1.3352	1.2489	1.1706
24	1.0317	1.134	1.1763	1.2071	1.086
Max	1.4632	1.531	1.5181	1.5023	1.4118
Min	.9694	.8962	.924	.9877	.9877
Avg	1.2239	1.2546	1.2330	1.2053	1.1716



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284009 / 33 KV Sec-19A Nerul

Feeder No / Name : 208 / 11 KV Anand Vaibhav Garden

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.7499	.6535	.823	.8402
2	.1867	.695	.6161	.7682	.8215
3	.168	.6401	.5601	.7133	.7655
4	.1867	.6767	.5601	.6767	.7282
5	.2427	.7133	.5975	.7499	.7842
6	.2427	.7133	.5975	.7865	.8029
7	.2614	.7133	.6348	.8413	.8029
8	.2614	.823	.7095	.9511	.9149
9	.2987	.9328	.7655	.9694	.9896
10	.2195	1.0456	.9145	1.0269	1.0059
11	1.1523	1.1389	1.4083	.8589	1.6461
12	1.134	1.1203	1.0974	.9335	1.5364
13	1.0974	1.0829	1.0608	1.0269	1.5181
14	1.0425	1.0082	1.0425	.7842	1.4815
15	.9145	1.0082	.9145	.7655	1.39
16	.8779	.9149	.8596	.9335	1.3535
17	.8779	.9149	.9145	1.0269	1.4266
18	1.0791	.9335	1.134	1.0829	1.5546
19	1.2803	1.1016	1.2437	1.2323	1.829
20	1.1523	1.0642	1.2254	1.251	1.7375
21	1.1888	.9979	1.2254	.9149	1.5912
22	1.0608	.9149	1.0974	.8402	1.3717
23	.8596	.7655	.9145	.9149	1.262
24	.2241	.823	.7095	.8779	.8775
Max	1.2803	1.1389	1.4083	1.251	1.829
Min	.168	.6401	.5601	.6767	.7282
Avg	.6764	.8955	.8940	.9062	1.2096

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284051 / 33/11KV SBI S/Stn

Feeder No / Name : 201 / 11KV SBI I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3921	.3921	.4668
2			.4668	.3361	.3734
3			.4481	.3734	.3361
4			.4668	.4108	.3361
5			.3734	.4668	.3734
6			.3734	.4854	.4108
7			.3361	.4854	.4668
8			.4481	.4294	.4854
11	.4668				
12	.4108				
15	.2987	.4668	.3921	.5228	
16		.4854	.3734	.5041	
17	.3361	.5041	.4294	.4854	
18	.4854	.5415	.5415	.5415	
19		.5601	.5975	.5228	
20		.5228	.6161	.5041	
21		.5041	.6161	.4481	
22		.5041	.5975	.4668	
23		.4668	.3734	.4854	
24			.4481	.3734	.4854
Max	.4854	.5601	.6161	.5415	.4854
Min	.2987	.4668	.3361	.3361	.3361
Avg	.3996	.5062	.4606	.4574	.4149

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 283034 / 22/22KV Shirawane MIDC

Feeder No / Name : 301 / 22KV Feeder No 1- Fugro SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.5335	.5716	.5335	.5335
2	.4954	.4191	.5716	.5335	.4572
3	.4572	.4191	.5716	.4954	.4572
4	.4191	.381	.5716	.4954	.381
5	.4191	.4572	.5716	.5335	.4191
6	.381	.4572	.5716	.5335	.4572
7	.4572	.5335	.4954	.6097	.5716
8	.5335		.5716		.5716
9	.6097	.6097	.5335	.6097	.6478
10		.6859		.9526	.8764
11	.8764	.6859	.5716	1.0288	.9907
12	.8764	.8383	.5716	.9907	1.0288
13		.724	.5716	.9907	.8764
14	.9145	.6478	.5716	.9907	.9526
15	.9145	.7621	.5716	.9907	.9526
16	.9145	.7621	.5335	.9907	.9907
17	.8764	.724	.4954	.8764	
18	.8383	.6097	.5716	.8764	.8383
19	.8002	.6097	.5335	.8002	.8383
20		.6097	.5335	.724	.7621
21		.6097	.5335	.6859	.6859
22	.5716	.5716		.6097	.5716
23	.4954	.5716	.5335	.724	.5335
24	.5335	.5716	.5716	.5335	.5716
Max	.9145	.8383	.5716	1.0288	1.0288
Min	.381	.381	.4954	.4954	.381
Avg	.6440	.5997	.5543	.7439	.6942

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 283034 / 22/22KV Shirawane MIDC

Feeder No / Name : 302 / 22KV Feeder No2- Vilaxmi- SHEDDABLE FEEDER HAVING WEEKLY  
 Hari Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.9145	.8002	.381	.7621
2	.8764	.7621	.8002	.3048	.9526
3	.8764	.724	.7621	.3048	.8764
4	.7621	.6097	.6859	.3048	.6859
5	.7621	.5335	.6097	.2667	.6478
6	.6859	.6478	.5335	.2667	.7621
7	.6097	.724	.4572	.2667	.8002
8	.5335		.381	.2667	.8764
9	.6097	.6097	.4572	.2667	.724
10		.6478		.4191	.6859
11	.7621	.7621	.6097	.4572	.724
12	.6859	.8002	.5335	.4954	.8002
13	.8383	.7621	.5716	.5335	.9145
14	.7621	.6478	.5716	.5716	.8764
15	.8002	.8002	.6859	.4191	1.105
16	.6859	.724		.6859	.8383
17	.7621	.7621		.724	
18	.5716	.8383		.8383	1.0288
19	.4954	.6097	.2667	.5716	.6859
20		.5716	.2286	.6478	.6097
21	.4572	.5716	.2667	.7621	.7621
22	.381	.5716		.9145	.9145
23	.8383	.6859	.381	1.0288	.9526
24	.9526	.9907	.8002	.381	1.1431
Max	.9526	.9907	.8002	1.0288	1.1431
Min	.381	.5335	.2286	.2667	.6097
Avg	.7101	.7074	.5475	.5033	.8317

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 283034 / 22/22KV Shirawane MIDC

Feeder No / Name : 303 / 22KV Feeder No3- Dy. Patil SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.381	.4954	.381	.4191
2	.4191	.3429	.4572	.3429	.381
3	.381	.3429	.381	.3429	.3048
4	.3429	.381	.381	.3048	.3048
5	.3048	.381	.381	.3429	.381
6	.3429	.4191	.381	.4191	.381
7	.381	.4191	.3429	.4954	.381
8	.381		.381	.5716	.4954
9	.4191	.5335	.5335	.5716	.6478
10		.724		.724	.724
11	.5716	.6478	.6478	.8002	.8002
12	.5335	.724	.6859	.7621	.8002
13	.4954	.6859	.6859	.7621	.6859
14	.5716	.7621	.6859	.7621	.724
15	.6097	.8002	.6859	.7621	.7621
16	.4954	.8002	.381	.8764	.8764
17	.6097	.7621	.6097	.8383	
18	.6097	.6859	.4572	.6859	.724
19	.5335	.5716	.4191	.6097	.6097
20		.6478	.5716	.5716	.4954
21	.4954	.5716	.4954	.5335	.4954
22	.4572	.5335		.4954	.4954
23	.4191	.4954	.4191	.4572	.4572
24	.4572	.4572	.5716	.381	.4572
Max	.6097	.8002	.6859	.8764	.8764
Min	.3048	.3429	.3429	.3048	.3048
Avg	.4659	.5683	.5023	.5747	.5567

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 283034 / 22/22KV Shirawane MIDC

Feeder No / Name : 304 / 22KV Feeder No4- Lalit SHEDDABLE FEEDER HAVING WEEKLY  
 Vitessi Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.5716	.6859	.5335	.6478
2	.6097	.6478	.6478	.6097	.6097
3	.5716	.6478	.6859	.6097	
4	.5716	.6097	.6859	.6478	.4954
5	.6097	.6859	.6859	.6859	.5335
6	.6478	.724	.6859	.6859	.6097
7	.6859	.724	.6859	.7621	.6859
8	.6859		.6478	.8002	.7621
9	.8383	.8383	.724	.9145	.9526
10		.9907		1.105	.9526
11	.9526	1.105	.8383	1.1812	1.105
12	.9145	1.2193	.8383	1.1431	1.105
13	.9145	1.0288	.724	1.1812	1.0288
14	.9526	1.105	.724	1.1431	1.1431
15	.9526	1.105	.7621	1.1812	1.1431
16		1.105	.6478	1.2193	1.105
17	.8383	1.0288	.6478	1.0288	
18	.8383	.9526	.6859	1.0288	.8764
19	.8383	.9526	.724	.9145	.8764
20		.9526	.6478	.8002	.8002
21	.6097	.8383	.6478	.7621	.7621
22	.6097	.7621		.6859	.6859
23	.5716	.6859	.5716	.6097	.6097
24	.6478	.5716	.724		.6478
Max	.9526	1.2193	.8383	1.2193	1.1431
Min	.5716	.5716	.5716	.5335	.4954
Avg	.7367	.8631	.6963	.8797	.8244

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 283034 / 22/22KV Shirawane MIDC

Feeder No / Name : 305 / 22KV Feeder No5- Jaspal - SHEDDABLE FEEDER HAVING WEEKLY  
 Shree Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	1.6004	1.6004	1.6004	1.6004
2	1.448	1.5242	1.5623	1.5623	1.5242
3	1.3717	1.4098	1.5242	1.5623	1.448
4	1.5242	1.3336	1.5242	1.5242	1.3336
5	1.6004	1.448	1.5242	1.6004	1.2574
6	1.6004	1.5242	1.5242	1.6004	1.3717
7	1.6766	1.5242	1.5242	1.7147	1.4861
8	1.7528		1.5242	1.7147	1.6766
9	1.829	1.5242	1.4098	1.7528	1.6766
10		1.8671		1.9814	2.0576
11	1.8671	1.829	1.9052	1.9052	2.0576
12	2.0576	1.6385	1.7909	1.9814	2.21
13	1.9052	1.6385	1.7147	2.0195	1.9814
14	2.1719	1.7528	1.9433	1.7147	2.2862
15	2.1338	1.7909	1.8671	1.829	1.7147
16	2.0957	1.7528	1.6004	1.7147	2.4768
17	2.1338	1.829	1.6004	1.7528	
18	1.7909	1.7147	1.6766	1.829	1.6385
19	1.6766	1.6766	1.5623	1.7528	1.6385
20		1.6385	1.6766	1.5623	1.5242
21	1.6004	1.6385	1.4861	1.6004	1.5623
22	1.6004	1.448		1.6004	1.6385
23	1.6766	1.6004	1.6004	1.6766	1.448
24	1.6004	1.7147	1.6004	1.6004	1.6385
Max	2.1719	1.8671	1.9433	2.0195	2.4768
Min	1.3717	1.3336	1.4098	1.5242	1.2574
Avg	1.7563	1.6269	1.6246	1.7147	1.7064

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 283034 / 22/22KV Shirawane MIDC

Feeder No / Name : 306 / 22KV Feeder No6- Elder - SHEDDABLE FEEDER HAVING WEEKLY  
 Geldop Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.3048	.2667	.2667	.2667
2	.2667	.2667	.3048	.2667	.2667
3	.2286	.2667	.3048	.2286	.2286
4	.2286	.2286	.3048	.2286	.1905
5		.2286	.3048	.2286	.2286
6	.2667	.2667	.3048	.2286	.2286
7	.2667	.2667	.3048	.3048	.2667
8	.2667		.3048		.3048
9	.2667	.3048	.381	.3048	.4572
10		.2667		.4572	.381
11	.3048	.2667	.4954	.4572	.4954
12	.3048	.3048	.4191	.4191	.4572
13	.2667	.3048	.381	.4191	.4191
14	.3048	.2667	.381	.5335	.3429
15	.3048	.3048	.381	.4572	.381
16	.3048	.2667	.3429	.4572	.4954
17	.3048	.3048	.4572	.4191	
18	.3048	.3048	.4572	.5716	.4191
19	.3048	.3048	.4572	.4954	.3048
20		.3048	.3048	.2667	.3048
21	.3048	.2667	.2667	.2667	.2667
22		.2667		.2667	.2667
23	.3048	.2667	.2667	.2667	.2667
24	.2667	.3048	.2667	.2667	.2667
Max	.3048	.3048	.4954	.5716	.4954
Min	.2286	.2286	.2667	.2286	.1905
Avg	.2819	.2800	.3481	.3512	.3263



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284005 / 33/11KV Sec 30, Sanpada

S/Stn

Feeder No / Name : 201 / 11KV SAMNA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.462	.4755	.4287	.4938	.5359
2	.4251	.5121	.3944	.5121	.5175
3	.3881	.4755	.3944	.5121	.499
4	.3696	.439	.3772	.4755	.4805
5	.3696	.439	.3772	.4938	.462
6	.3511	.4572	.3429	.5487	.4805
7	.4066	.4755	.3772	.5853	.5175
8	.499	.4938	.3944	.5487	.5544
9	.5487	.5121	.4458	.5487	.5914
10	.6036	.6219	.5487	.5487	.5729
11	.6401	.583	.2012	.5729	.5487
12	.5853	.583	.6401	.5544	.5487
13	.5487	.583	.6219	.5359	.4801
14	.4755	.4458	.4572	.4805	.4287
15	.4938	.4458	.4572	.4251	.4458
16	.4207	.4458	.5304	.4066	.4801
17	.4755	.583	.5853	.462	.4458
18	.5853	.583	.5304	.5544	.5658
19	.5304	.5658	.5304	.5729	.6001
20	.5121	.5487	.3292	.5544	.583
21	.567	.5658		.5544	.583
22	.5853	.5316	.5487	.5359	.5487
23	.3109	.5316	.5853	.5175	.4973
24	.499	.4938	.4973	.5121	.5544
Max	.6401	.6219	.6401	.5853	.6001
Min	.3109	.439	.2012	.4066	.4287
Avg	.4855	.5163	.4607	.5211	.5217

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284005 / 33/11KV Sec 30, Sanpada

S/Stn

Feeder No / Name : 202 / 11 KV MITTAL TOWER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1109	.1109	.1029	.128	.1294
2	.1109	.1294	.1029	.128	.1294
3	.1294	.1097	.1029	.1097	.1109
4	.1109	.1109	.0857	.1097	.1109
5	.1109	.0924	.0857	.1109	.1109
6	.1109	.1109	.0857	.1109	.1109
7	.1478	.1294	.0857	.1109	.1294
8	.1663	.1294	.1029	.1109	.1478
9	.1829	.1463	.1029	.1463	.1478
10	.1829	.128	.1372	.1463	.1663
11	.1463	.1372	.1109	.1478	.1543
12	.1294	.1372	.1097	.1294	.1543
13	.1097	.1029	.1097	.1294	.1029
14	.128	.12	.128	.1294	.12
15	.1463	.1372	.0914	.1294	.12
16	.1463	.12	.0914	.1294	.12
17	.1294	.12	.0924	.1478	.1029
18	.128	.1372	.128	.1478	.12
19	.1294	.1372	.128	.1478	.12
20	.1294	.1029	.128	.1478	.1029
21	.1294	.12	.1109	.1478	.1029
22	.1478	.12	.128	.1478	.1029
23	.1294	.12	.1109	.1478	.12
24	.1294	.1646	.12	.128	.1478
Max	.1829	.1646	.1372	.1478	.1663
Min	.1097	.0924	.0857	.1097	.1029
Avg	.1343	.1239	.1076	.1320	.1244

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284005 / 33/11KV Sec 30, Sanpada

S/Stn

Feeder No / Name : 203 / 11 KV IPCL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.2195	.2058	.2378	.2587
2	.2033	.2195	.1886	.2195	.2402
3	.1848	.2195	.1886	.2195	.2402
4	.1848	.1829	.1715	.1829	.2218
5	.1848	.2012	.1715	.2195	.2218
6	.1848	.2195	.1715	.2195	.2218
7	.2218	.2195	.1886	.2012	.2402
8	.2587	.2195	.2229	.2195	.2587
9	.3658	.2561	.2229	.2926	.3696
10	.3841	.3292	.2401	.4066	.3696
11	.4024	.3601	.3109	.4251	.3772
12	.439	.3944	.3109	.4435	.4115
13	.439	.4115	.3109	.462	.4115
14	.439	.3601	.2926	.4805	.3772
15	.4572	.3601	.2926	.4805	.3944
16	.4572	.3944	.2926	.462	.3944
17	.4572	.4287	.1829	.4435	.3601
18	.4207	.4287		.462	.4115
19	.439	.3772	.3292	.4805	.4115
20	.3658	.3429	.3292	.462	.3429
21	.3292	.3258	.3109	.4066	.3429
22	.3109	.3086	.2926	.3326	.3086
23	.3109	.2915	.2926	.2957	.2401
24	.2402	.2378	.2229	.2561	.2772
Max	.4572	.4287	.3292	.4805	.4115
Min	.1848	.1829	.1715	.1829	.2218
Avg	.3293	.3045	.2497	.3463	.3210

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284005 / 33/11KV Sec 30, Sanpada

S/Stn

Feeder No / Name : 208 / 11 KV PUDHARI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1109	.1097	.1029	.1109	.1478
2	.1109	.1109	.0857	.1109	.1294
3	.1109	.0924	.0857	.1097	.1294
4	.0924	.0924	.0857	.0924	.1294
5	.0924	.0924	.0857	.0924	.1294
6	.0924	.1109	.0857	.1109	.1109
7	.1109	.1097	.1029	.1109	.1294
8	.1478	.1463	.0857	.5487	.1478
9	.1829	.1646	.1372	.2012	.1478
10	.3292	.2926	.1543	.4207	.3696
11	.2561	.2743	.1663	.4066	.3429
12	.1829	.3086	.1829	.4066	.3429
13	.1829	.2915	.1646	.3881	.3429
14	.1646	.2915	.1646	.4066	.3429
15	.1646	.2743	.1463	.4066	.3429
16	.1646	.2743	.1463	.3696	.3258
17	.1463	.2743	.1829	.3696	.3601
18	.3841	.2572	.128	.3326	.3086
19	.2561	.1886	.1463	.2772	.2229
20	.1463	.1372	.1294	.2402	.1715
21	.1463	.1372	.1294	.2033	.1372
22	.1463	.12	.128	.1848	.12
23	.1109	.1029	.1109	.1294	.1029
24	.1109	.1109	.1029	.128	.1478
Max	.3841	.3086	.1829	.5487	.3696
Min	.0924	.0924	.0857	.0924	.1029
Avg	.1643	.1819	.1267	.2566	.2159

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284005 / 33/11KV Sec 30, Sanpada

S/Stn

Feeder No / Name : 209 / 11 KV MILLENIUM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0554	.0762	.0554	.0762
2	.0762	.0554	.0514	.0739	.0762
3	.0762	.0554	.0572	.0739	.0762
4	.0762	.0739	.0514	.0554	.0762
5	.0572	.0554	.0762	.0549	.0762
6	.0572	.0549	.0762	.0554	.0572
7	.0572	.0554	.0762	.0554	.0572
8	.0572	.0554	.0762	.0554	.0572
9	.0554	.0549	.0762	.0554	.0572
10	.0554	.0549	.0762	.0732	.0762
11	.0549	.0762	.0732	.0762	.0762
12	.0554	.0762	.1109	.0762	.0762
13	.0549	.0762	.0554	.0762	.0762
14	.0549	.0762	.0549	.0762	.0762
15	.0549	.0762	.0554	.0762	.0762
16	.0554	.0762	.0554	.0762	.0762
17	.0554	.0762	.0554	.0762	.0762
18	.0549	.0762	.0549	.0762	.0762
19	.0554	.0762	.0549	.0762	.0762
20	.0554	.0762	.0739	.0762	.0762
21	.0554	.0762	.0554	.0762	.0762
22	.0554	.0572	.128		.0572
23	.0554	.0572	.0554	.0762	.0572
24	.0762	.0554	.0762	.0554	.0762
Max	.0762	.0762	.128	.0762	.0762
Min	.0549	.0549	.0514	.0549	.0572
Avg	.0599	.0658	.0689	.0686	.0715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 201 / 11 KV VASHI RLY I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.0762	.0754	.0754
2		.0754	.0762	.0754	.0754
3	.0754	.0754	.0762	.0754	.0754
4	.0754	.0754	.0762	.0754	.0754
5	.0754	.0754	.0762	.0754	.0747
6	.0754	.0754	.0762		.0754
7	.0754				
17	.0754				
18	.0754	.0762		.0754	
19	.0754	.0762	.0754	.0754	.0754
20	.0754	.0762	.0754	.0754	.0754
21	.0754	.0762	.0754	.0754	.0754
22	.0754	.0762	.0754	.0747	.0754
23	.0754	.0762	.0754	.0754	.0754
24	.0754	.0754	.0762	.0754	.0754
Max	.0754	.0762	.0762	.0754	.0754
Min	.0754	.0754	.0754	.0747	.0747
Avg	.0754	.0758	.0759	.0753	.0753

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 202 / 11 KV SHAH GROUP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1698	.2096	.2075	.1698
2	.1886	.1698	.1905	.2075	.168
3	.1886	.1886	.1715	.1698	
4	.1509	.2054	.1524	.1886	.1698
5	.1698	.2241	.1524	.2263	.2075
6	.1886	.2452	.2858	.2452	.2263
7	.2263	.2452	.2477	.2829	.2452
8	.2263	.2452	.2096	.2829	.2452
9	.2641	.2641	.2286	.3206	.2641
10	.2075	.2477	.2829	.2641	.2452
11	.2075	.2286	.3018	.2641	.1886
12	.1886	.2667	.2075	.2075	.2075
13	.1698	.2477	.2075	.2075	.1886
14	.1698	.2096	.2263	.1494	.1698
15	.132	.2286	.2075	.1886	.1698
16	.1698	.1905	.1886	.2263	.1698
17	.1698	.2096	.2263	.1698	.2075
18	.2096	.2286	.2263	.2054	.1886
19	.1886	.2096	.2452	.2263	.2263
20	.2452	.2096	.1886	.2075	.2452
21	.1886	.2286	.2075	.2075	.2452
22	.2075	.2286	.2263	.2075	.2075
23	.2075	.2286	.2075	.2075	.1886
24	.1886	.1698	.2096	.2075	.168
Max	.2641	.2667	.3018	.3206	.2641
Min	.132	.1698	.1524	.1494	.168
Avg	.1926	.2204	.2170	.2199	.2049

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 203 / 11 KV ASSAM BHAVAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.0762	.0754	.0754
2	.0754	.0754	.0762	.0754	.0747
3	.0754	.0754	.0762	.0754	.0747
4	.0943	.0754	.0762	.0754	.0754
5	.0754	.0754	.0762	.0754	.0747
6	.0754	.0754	.0762	.0754	.0747
7	.0754	.0754	.0762	.0754	.0754
8	.0754	.0754	.0762	.0754	.0754
9	.0943	.0754	.0762	.0754	.0754
10	.0754	.0762	.0943	.0754	.0754
11	.0754	.0762	.0943	.0754	.0754
12	.0754	.0762	.0943	.0754	.0943
13	.0754	.0953	.0943	.0754	.0754
14	.0754	.0953	.0943	.0739	.0754
15	.0934	.0762	.0754	.0747	.0943
16	.0943	.0953	.0754	.0747	.0754
17	.0943	.0953	.0754	.0754	.0754
18	.0762	.0953	.0754	.0754	.0943
19	.0754	.1334	.1132	.0754	.0943
20	.0754	.1334	.0943	.0754	.0943
21	.0754	.1143	.0754	.0754	.0943
22	.0754	.0953	.0943	.0754	.0943
23	.0754	.0762	.0943	.0754	.0943
24	.0943	.0754	.0762	.0943	.0754
Max	.0943	.1334	.1132	.0943	.0943
Min	.0754	.0754	.0754	.0739	.0747
Avg	.0801	.0870	.0836	.0761	.0816



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 204 / 11 KV REAL TRADE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.4527	.4191	.415	.415
2	.5093	.415	.381	.3772	.3734
3	.3772	.4108	.3429	.3584	.3921
4	.3395	.3772	.3429	.3772	.4191
5	.3772	.362	.3239	.3772	.3961
6	.3772	.3772	.3429	.3961	.4191
7	.415	.3772	.381	.3961	.4338
8	.4527		.4001	.4527	.4338
9	.6224	.4904	.4572	.5658	.6036
10	.7167	.6668	.6413	.7922	.7356
11	.8488	.9526	.6979	.9054	.9054
12	1.0374	.9145	.7356	.9054	1.0185
13	.9808	.9145	.8299	.9242	.8865
14	.9431	.9145	.9431	.9242	.8676
15	.9896	.9907	.811	.9242	.9997
16	.9808	.9526	.811	1.0562	.9242
17	.9431	.9335	.7545	1.0185	.9431
18	.9431	.9335	.7733	.8299	.9242
19	.8299	.8954	.8488	.811	.8865
20	.8299	.7621	.811	.7545	.7922
21	.6979	.7049	.7167	.7356	.7356
22	.5847	.6097	.5847	.5658	.5847
23	.4715	.4954	.5658	.5281	.4904
24	.547	.4338	.4572	.4715	.4338
Max	1.0374	.9907	.9431	1.0562	1.0185
Min	.3395	.362	.3239	.3584	.3734
Avg	.6810	.6668	.5989	.6609	.6673

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 206 / 11 KV CIDCO WATER PUMP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3239	.3429	.3395	.2641
2	.415	.3239	.3239	.3018	.2452
3	.3584	.3429	.3239	.2829	.2477
4	.3395	.3361	.3048	.3206	.2667
5	.2829	.3696	.3239	.3772	.3018
6	.3018	.415	.3239	.3584	.3395
7	.3206	.4108	.3429	.3584	.3584
8	.3395	.3395	.362	.3961	.3547
9	.3772	.3206	.3048	.3961	.4481
10	.5281	.4763	.3961	.5658	.5281
11	.6979	.6859	.4338	.6979	.7167
12	.679	.8002	.415	.7356	.7167
13	.7167	.7811	.4715	.7922	.679
14	.7356	.743	.4338	.7922	
15	.7733	.7811	.4338	.7733	.7167
16	.7282	.7621	.4527	.7167	.7356
17	.7167	.7049	.3961	.6602	.6602
18	.6224	.6097	.4527	.7356	.6413
19	.6224	.6097	.415	.5093	.547
20	.5093	.5716	.5281	.415	.4527
21	.3584	.4382	.4715	.3772	.3961
22	.3961	.4382	.4338	.3584	.415
23	.4338	.4001	.4338	.3961	.415
24	.3772	.3395	.362	.3584	.3734
Max	.7733	.8002	.5281	.7922	.7356
Min	.2829	.3206	.3048	.2829	.2452
Avg	.5003	.5135	.3951	.5006	.4704

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 208 / 11 KV LIFE STYLE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0747	.0953	.0754	.0754
2	.0754	.0747	.0953	.0754	.0747
3	.0754	.0739	.0953	.0754	.0754
4	.0754	.0747	.0762	.0754	.0754
5	.0754	.0754	.0762	.0754	.0762
6	.0754	.0747	.0762	.0754	.0739
7	.0754	.0754	.0762	.0754	.0747
8	.0754	.0943	.0762	.0754	.0754
9	.0754	.0943	.0762	.0754	.0754
10	.1132	.2286	.0943	.1132	.1509
11	.6413	.6859	.6602	.5847	.7356
12	.8299	.8573	.8299	.8488	.7922
13	.7922	.8192	.8488	.8299	.8488
14	.7922	.8192	.8488	.6722	.8299
15	.8299	.8383	.811	.9242	.7922
16	.7356	.8002	.811	.6979	.8299
17	.7167	.8383	.811	.6224	.7922
18	.7733	.9335	.7545	.7356	.7922
19	.811	.9717	.7545	.7095	.811
20	.7922	.8954	.7733	.7545	.7922
21	.7545	.8002	.7356	.5658	.7922
22	.132	.4763	.2075	.2641	.1886
23	.0754	.1524	.0943	.1132	.132
24	.0943	.0754	.1143	.0754	.0943
Max	.8299	.9717	.8488	.9242	.8488
Min	.0754	.0739	.0762	.0754	.0739
Avg	.3984	.4543	.4122	.3829	.4188

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 402 / 33 KV BSEL

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2263	.2286	.2263	.2195
2		.2263	.2286	.2263	.2263
3		.2263	.2286	.2263	.2241
4		.2263	.2286	.2263	.2263
5		.2263	.2286	.2263	.2263
6		.2263	.2286	.2263	.2263
7	.2263	.2263	.2286	.2263	.2241
8	.2263	.2263	.2286	.2263	.2263
9	.4527	.2263	.2286	.4527	.2241
10	.679	.4572	.2263	.679	.4527
11	.679	.4572	.2263	.679	.679
12	.679	.4572	.2263	.679	.679
13	.679	.4572	.2263	.679	.679
14	.679	.4572	.2263	.679	.679
15	.679	.4572	.2263	.6653	.679
16	.679	.4572	.2263	.679	.679
17	.679	.2286	.2263	.679	.679
18	.4527	.2286	.2263	.4527	.679
19	.2263	.2286	.2263	.2241	.2263
20	.2263	.2286	.2263	.2263	.2263
21	.2263	.2286	.2263	.2263	.2263
22	.2263	.2286	.2263	.2263	.2263
23	.2263	.2286	.2263	.2263	.2263
24	.2263	.2263	.2286	.2263	.2263
Max	.679	.4572	.2286	.679	.679
Min	.2263	.2263	.2263	.2241	.2195
Avg	.4527	.2943	.2273	.3954	.3861

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 403 / 33 KV VISHWAROOP

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.358	1.358	1.0288	1.0185	1.358
2	1.2449	1.3443	1.0288	1.0185	1.3443
3	1.0185	1.2449	.9145	.9054	1.2323
4	.9054	1.2449	.9145	.9054	1.2323
5	1.2449	1.2449	.9145	1.0185	1.1317
6	1.1317	1.1317	1.0288	1.1317	1.2449
7	1.2449	1.1203	1.0288	1.1317	1.358
8	1.358	1.1317	1.0288	1.358	1.3443
9	1.5844	1.1317	1.0288	1.5844	1.4712
10	1.6975	1.1431	1.0185	1.8107	1.6975
11	1.8107	1.1431	1.0185	1.9239	1.8107
12	1.8107	1.2574	1.0185	1.6975	1.4712
13	1.6975	1.2574	1.0185	1.9239	1.8107
14	1.6975	1.1431	1.1317	1.9239	1.8107
15	1.8107	1.2574	1.1317	1.9044	1.8107
16	1.8107	1.2574	1.1317	1.9239	1.9239
17	1.8107	1.2574	1.1317	1.9239	1.9239
18	1.8107	1.2574	1.1317	1.9239	1.9239
19	1.8107	1.2574	1.1317	1.6975	1.8107
20	1.6975	1.2574	1.1317	1.5844	1.5844
21	1.5844		1.1317	1.5844	1.5844
22	1.4712	1.1431	1.1317	1.4712	1.4712
23	1.358	1.1431	1.1317	1.358	1.2449
24	1.4712	1.358	1.0288	1.0185	1.358
Max	1.8107	1.358	1.1317	1.9239	1.9239
Min	.9054	1.1203	.9145	.9054	1.1317
Avg	1.5184	1.2211	1.0557	1.4893	1.5397

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 404 / 33 KV SEC 30 SANPADA FRM NON SHEDDABLE EXPRESS HV FEEDERS

VASHI Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9425	.9328	.8745	.9877	1.1088
2	.8871	.9877	.7716	.9877	1.0534
3	.8316	.8779	.7716	.9877	.9979
4	.8316	.8779	.7202	.8779	.9425
5	.7762	.823	.7202	.9328	.9425
6	.7207	.9328	.7202	1.0425	.9425
7	.8871	.9328	.823	1.0425	.9979
8	1.0534	1.0425	.8745	1.0425	1.1088
9	1.262	1.0974	.9774	1.2071	1.2752
10	1.5364	1.3717	1.1317	1.5364	1.5524
11	1.4815	1.3889	1.2071	1.6078	1.4918
12	1.3169	1.4918	1.262	1.6078	1.4918
13	1.3169	1.4403	1.262	1.6078	1.3889
14	1.2071	1.2346	.4938	1.5524	1.286
15	1.2071	1.2346	.9877	1.4969	1.3375
16	1.2071	1.286	1.0974	1.386	1.3889
17	1.262	1.4403	1.2071	1.4415	1.286
18	1.5364	1.4403	1.0974	1.5524	1.4403
19	1.3169	1.286	1.1523	1.5524	1.3889
20	1.2071	1.1831	1.2071	1.4415	1.2346
21	1.2071	1.1831	1.0974	1.3306	1.2346
22	1.2071	1.0802	1.1523	1.1088	1.0802
23	1.2071	1.0802	1.0425	1.1088	.9774
24	.9979	1.0425	.9774	1.0425	1.2197
Max	1.5364	1.4918	1.262	1.6078	1.5524
Min	.7207	.823	.4938	.8779	.9425
Avg	1.1420	1.1537	.9845	1.2701	1.2154

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 201 / 11 KV NMMC WATER PUMP SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8215	.8676	.9145	.9717	
2	.7655	.7922	.8383	.9526	.7922
3	.8029	.7356	.8573	1.0669	.7167
4	.8775	.7167	.9145	1.0479	.811
5	.9709	.7545	.9526	1.0288	.9054
6	1.1576	.7922	1.086	.9907	.9997
7	.9335	.8299	.9907	1.0479	1.0751
8	1.0082	1.0562	.8954	1.086	1.0751
9	1.0642	1.094	1.086		1.1317
10	.9335	.9808	1.0288		.9997
11	.9896	.9431	.9526		1.0751
12	.8962	.9242	.9145		.9808
13	.7842	.9054	.8764		.9054
14	.6908	.8865	.8383		.9054
15		.8676	.8002	.7621	.679
16	.6908	.7922	.743	.9145	.679
17			.9717	1.0288	.9619
18				1.1812	1.2637
19				1.3336	
20	1.2323			1.2765	1.2449
21	1.0456			1.2955	
22	1.0456			1.0479	1.1128
23					.9431
24	.8501	.9149	.9619	.9526	.9335
Max	1.2323	1.094	1.086	1.3336	1.2637
Min	.6908	.7167	.743	.7621	.679
Avg	.9242	.8737	.9235	1.0580	.9615

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 202 / 11 KV TEJASWINI HOSTEL SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7947	.8402	.9055	1.0903	.8589
2	.7577	.7655	.8501	1.0719	.7655
3	.7207	.7095	.8131	1.0349	.7282
4	.7762	.7655	.7762	1.0719	.6908
5	.8316	.8029	.7947	1.0534	.7468
6	.8686	.8402	.7947	1.0349	.7842
7	.8501	.8589	.8871	1.0164	.8589
8	.924	.9522		.9979	.8962
9	.9795	1.0269	1.0164		.9335
10	1.1088	1.0829	1.0164		1.1949
11	1.0534	1.0456	1.0164		1.1016
12	.9979	1.1203	1.0164		1.0829
13	.9979	1.1949	1.0164		1.0642
14	.9979	1.251	1.0164		1.0456
15	1.0719	1.2323	1.0164	1.1643	1.0456
16	1.0719	1.1576	1.0164	1.2752	1.1389
17	1.0903		1.0164	1.2936	1.1576
18	1.2197			1.3306	1.3256
19	1.2567			1.3676	
20	1.2382			1.2197	1.1949
21	1.1827			1.1827	
22	1.0903			1.0903	1.1203
23					.9335
24	.8686	.8871	.9522	1.0903	.8871
Max	1.2567	1.251	1.0164	1.3676	1.3256
Min	.7207	.7095	.7762	.9979	.6908
Avg	.9891	.9726	.9365	1.1403	.9798



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 203 / 11 KV SANPADA INDL SEC 6 SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1334	.1698	.132	.1524
2	.1132	.1143	.1509	.1698	.1334
3	.1132	.1143	.132	.1509	.1143
4	.1132	.1143	.132	.1509	.1143
5	.132	.1334	.132	.1509	.1334
6	.1509	.1334	.132	.1698	.1334
7	.1509	.1334	.1509	.132	.1524
8	.1509	.1524	.1509	.1509	.1524
9	.1698	.1524	.132		.1715
10	.1698	.1524	.132		.1715
11	.1886	.1524	.132		.1715
12	.1698	.1334	.132		.1715
13	.1698	.1524	.1509		.1905
14	.1698	.1715	.1509		.1905
15	.1698	.1715	.1509	.1886	.1905
16	.1698	.1905	.1509	.1886	.1715
17	.1698		.1698	.1698	
18	.1698			.1698	.1715
19	.1886			.1663	
20	.1698			.1886	.1715
21	.1698			.1698	
22	.1698			.1509	.1715
23					.1524
24	.1294	.1509	.1715	.1132	.1524
Max	.1886	.1905	.1715	.1886	.1905
Min	.1132	.1143	.132	.1132	.1143
Avg	.1565	.1445	.1457	.1596	.1588

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 204 / 11 KV SEC 6 SUBSTATION SHEDDABLE URBAN  
TRANSFO Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4066	.4108	.4251	.5729	.4251
2	.3696	.3734	.3696	.6283	.3696
3	.3326	.3174	.3326	.5914	.3326
4	.3142	.2801	.2957	.6099	.3881
5	.3696	.3361	.3142	.5544	.4066
6	.4251	.3921	.3326	.5175	.4435
7	.4805	.4481	.3881	.5359	.4805
8	.5175	.4108	.4435	.5175	.4805
9	.499	.4294	.4066		.4805
10		.4108	.4066		.4805
11		.3734	.3696		.4805
12		.3921	.3511		.4435
13		.3734	.3511		.4066
14		.3921	.3326		.3696
15		.3921	.3326	.3511	.3696
16		.3921	.3511	.4066	.2957
17	.3511		.3881	.4435	.3881
18	.4251			.462	.5175
19	.5175			.499	
20	.5175			.499	.5544
21	.5729			.499	
22	.5175			.5359	.499
23					.6099
24	.4481	.4435	.4668	.5544	.4668
Max	.5729	.4481	.4668	.6283	.6099
Min	.3142	.2801	.2957	.3511	.2957
Avg	.4415	.3863	.3699	.5164	.4404

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 205 / 11 KV SAIKRIPA SEC 10 SHEDDABLE URBAN  
 SANPADA Feeder KV- 11 /  
 OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3206	.2858	.362	.2829
2	.2667	.2829	.2477	.381	.2641
3	.2477	.2452	.2477	.4001	.2263
4	.2858	.2452	.2667	.4382	.2452
5	.3239	.2829	.2667	.4001	.2829
6	.3429	.3018	.2858	.381	.3395
7	.362	.3206	.3048	.4191	.415
8	.4572	.415	.3429	.4382	.4904
9		.415	.4382		.4527
10		.3772	.4191		.415
11		.3961	.4001		.4338
12		.3584	.381		.3961
13		.3206	.3429		.3584
14		.3395	.3239		.3018
15		.2829	.3048	.3048	.2452
16		.2641	.2667	.362	.2452
17	.2477		.2667	.381	.4527
18	.3048			.4001	.547
19	.362			.4001	
20	.4191			.4191	.6036
21	.4001			.4001	
22	.4001			.381	.6036
23					.547
24	.3206	.3429	.3206	.3429	.3239
Max	.4572	.415	.4382	.4382	.6036
Min	.2477	.2452	.2477	.3048	.2263
Avg	.3364	.3242	.3173	.3889	.3851

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 206 / 11 KV SAMTA SEC 4/7 SHEDDABLE URBAN  
 SANPADA Feeder KV- 11 /  
 OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8029	.8316	.8589	.9709	.7947
2	.7468	.7947	.7842	1.0269	.7392
3	.7095	.7392	.7468	1.0642	.6653
4	.7655	.7947	.7282	1.1016	.7577
5	.8215	.8501	.7655	1.1389	.8871
6	.8962	.9055	.7842	1.1203	1.0164
7	1.1389	.961	.8775	1.1389	1.1827
8	1.1389	1.1088	1.0829	1.1576	1.1458
9		1.3121	1.1949		1.0903
10		1.2012	1.1203		1.1458
11		1.1458	1.0829		1.0903
12		1.0534	1.0456		.9979
13		1.0164	.9709		.961
14		.9979	.9335		.924
15		1.0164	.8962	.9522	.8871
16		.9425	.8215	1.0829	.8686
17	.9149		.9896	1.1203	.961
18	1.1203			1.1949	1.1827
19	1.1389			1.2883	
20	1.251			1.1576	1.2197
21	1.251			1.251	
22	1.1389			1.1203	1.1643
23					.8871
24	.8488	.8775	.9055	.9335	.8775
Max	1.251	1.3121	1.1949	1.2883	1.2197
Min	.7095	.7392	.7282	.9335	.6653
Avg	.9789	.9735	.9216	1.1071	.9748

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 208 / 11 KV LAXMI SEC10 SANPADA SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.307	1.423	1.475	1.5123	1.3769
2	1.2696	1.3676	1.4003	1.5708	1.2826
3	1.2136	1.2936	1.3256	1.6078	1.226
4	1.307	1.3306	1.2883	1.6448	1.3014
5	1.4003	1.4045	1.3256	1.6632	1.4335
6	1.5684	1.4784	1.363	1.7556	1.5466
7	1.6991	1.5708	1.4937	1.7741	1.7541
8	1.6804	1.6632	1.6991	1.8298	1.8296
9		1.7372	1.7177		1.6409
10		1.6632	1.6804		1.5278
11		1.6263	1.6057		1.3769
12		1.5524	1.4937		1.3203
13		1.386	1.4563		1.2071
14		1.2012	1.3817		1.1317
15		1.1643	1.307	1.0829	1.0751
16		1.1458	1.2136	1.2323	1.0751
17	1.0642		1.2696	1.4377	1.1883
18	1.4377			1.6057	1.5278
19	1.643			1.7177	
20	1.6804			1.7364	1.7164
21	1.6991			1.7737	
22	1.6617			1.7177	1.6787
23					1.5089
24	1.363	1.4563	1.5154	1.5123	1.4377
Max	1.6991	1.7372	1.7177	1.8298	1.8296
Min	1.0642	1.1458	1.2136	1.0829	1.0751
Avg	1.4663	1.4391	1.4451	1.5985	1.4165

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284055 / 33/11 KV Sec 14,Nerul s/stn

Feeder No / Name : 201 / 11 KV SUN HOME SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8589	.8676	.9149	.9054	.8676
2	.8215	.7922	.7842	.8299	.8299
3	.8029	.7922	.7655	.7922	.7733
4	.7655	.7733	.7282	.7545	.7545
5	.8402	.7922	.7095	.7733	.7356
6	.9709	.9619	.8402	1.0751	.811
7	1.1016	1.0185	.8775	1.226	1.094
8	1.2323	1.1694	1.0829	1.3203	
9	1.1389	1.2071	1.251	1.2637	1.2449
10	1.226	1.094	1.2136	.9997	.9997
11	.9054	1.1016	1.0562	1.0185	1.0642
12	.811	.9335	1.1317	.8865	.7282
13	.7733	.8589	.9997		.7282
14	.7733	.811	.8865	.7545	.6908
15	.7167	.7655	.8299	.6979	.6722
16	.679	.7655	.8488	.7167	.6348
17	.679	.7842	.8865	.7167	.6348
18	.8488	.8962	.9619	.9808	.8962
19	.9997	1.0642	1.1883	1.0374	1.0829
20	1.1506	1.1949	1.2071	1.0751	1.1016
21	1.2071	1.251	1.2449	1.1128	1.1949
22	1.1317	1.1763	1.1694	1.1128	.056
23	.9808	1.1016	1.0751	.9619	.924
24	.8402	.9054	.9335	1.0185	
Max	1.2323	1.251	1.251	1.3203	1.2449
Min	.679	.7655	.7095	.6979	.056
Avg	.9273	.9616	.9828	.9578	.8418

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284055 / 33/11 KV Sec 14,Nerul s/stn

Feeder No / Name : 205 / 11 KV SUBSTATION SHEDDABLE URBAN  
 TRANSFORMER S Feeder KV- 11 /  
 OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0566	.0566	.0566
2	.0566	.0377	.0566	.0566	.0566
3	.0566	.0377	.0566	.0566	.0566
4	.0566	.0366	.0566	.0566	.0566
5	.0566	.0377	.0566	.0566	.0566
6	.0566	.0566	.0566	.0566	.0566
7	.0566	.0566	.0566	.0566	.0566
8	.0566	.0377	.0566	.0754	.0566
9	.0566	.0377	.0566	.0566	.0566
10	.0566	.0377	.0566	.0566	.0566
11	.0566	.0566	.0566	.0566	.0566
12	.0566	.0566	.0566	.0566	.0554
13	.0377	.0566	.0566		.0566
14	.0566	.0566	.0566		.0566
15	.0566	.0566	.0566	.0566	.0566
16	.0566	.0566	.0566	.0566	.0566
17	.0377	.0566	.0566	.0566	.0554
18	.0377	.0566	.0566	.0566	.0566
19	.0566	.0566	.0566	.0566	.0566
20	.0566	.0566	.0566	.0566	.0566
21	.0566	.0566	.0566	.0566	.0554
22	.0566	.0566	.0754	.0566	.0566
23	.0566	.0566	.0754	.0566	.0566
24	.0566	.0566	.0566	.0566	.0566
Max	.0566	.0566	.0754	.0754	.0566
Min	.0377	.0366	.0566	.0566	.0554
Avg	.0540	.0509	.0580	.0575	.0563

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284055 / 33/11 KV Sec 14,Nerul s/stn

Feeder No / Name : 206 / 11 KV KUKSHET

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17	13-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.307	1.3957	1.4937	1.4712	1.3957	
2	1.2323	1.3014	1.4003	1.3392	1.3392	
3	1.2136	1.2826	1.2696	1.3014	1.3014	
4	1.1576	1.2449	1.2136	1.2449	1.2637	
5	1.2696	1.2637	1.1576	1.2826	1.2449	
6	1.3817	1.4335	1.3443	1.7541	1.4523	
7	1.7177	1.6409	1.6448	1.8484	1.6787	
8	1.8671	2.037	1.9035	2.1879	2.0559	
9	1.6598	1.7541	1.7924	1.7918	1.7918	
10	1.4335	1.5655	1.6263	1.5655	1.4146	
11	1.2826	1.4563	1.5684	1.3957	1.307	
12	1.2449	1.419	1.5844	1.3203	1.251	
13	1.2071	1.3443	1.4146		1.1506	
14	1.1128	1.2323	1.358	1.2637	1.1016	
15	1.094	1.2136	1.358	1.1694	1.1016	
16	1.094	1.1389	1.3203	1.1128	1.1016	
17	1.1317	1.307	1.3957	1.2637	1.1576	
18	1.3392	1.531	1.6787	1.5844	1.5684	
19	1.7918	1.9605	2.0936	1.905	1.8107	
20	1.9616	2.1879	2.2445	2.2257	1.9589	
21	1.8296	1.9418	1.9616	1.8861	1.8111	
22	1.773	1.8671	1.8484	1.7353	1.7364	1.643
23	1.6598	1.6448	1.6598	1.6032	1.5123	
24	1.3443	1.5089	1.531	1.5655	1.4335	
Max	1.9616	2.1879	2.2445	2.2257	2.0559	1.643
Min	1.094	1.1389	1.1576	1.1128	1.1016	1.643
Avg	1.4211	1.5280	1.5776	1.5573	1.4559	1.643



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284055 / 33/11 KV Sec 14,Nerul s/stn

Feeder No / Name : 207 / 11 KV AGRI KOLI SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3921	1.5466	1.8111	1.8296	1.8296
2	.3921	1.5466	1.6617	1.7353	1.773
3	.3734	1.5089	1.643	1.6787	1.6975
4	.3734	1.5089	1.6057	1.6409	1.6409
5	.4108	1.4998	1.6617	1.6598	1.6032
6	.4481	1.7541	1.8298	2.3577	1.8484
7	.5415	2.5274	2.3899	2.6595	2.4709
8	.5975	2.6029	2.2546	2.9235	2.6406
9	.547	2.2068	2.2965	2.4897	2.3954
10	2.3388	2.2068	2.3152	2.1691	2.1313
11	2.0182	2.1845	2.2445	2.2445	2.0725
12	1.9805	2.1472	2.1502	2.1691	1.9044
13	1.9993	2.0911	2.1879		1.9418
14	1.773	1.8671	1.9805	2.037	1.8298
15	1.773	1.2136	1.8484	1.8673	1.7924
16	1.7541	1.9231	1.9239	1.8107	1.7551
17	1.9427	2.0559	2.1691	2.2445	1.9231
18	2.1879	2.3339	2.4143	2.452	2.1285
19	2.4143	2.8753	2.9235	2.9801	2.6513
20	2.8292	2.8104	2.8858	2.8858	2.6139
21	2.3765	2.2965	2.5463	2.5274	2.1098
22	2.2445	2.2592	2.4897	2.3388	2.0911
23	2.3388	2.1992	2.2257	2.0748	1.9044
24	.3921	1.8861	1.885	1.9616	1.8673
Max	2.8292	2.8753	2.9235	2.9801	2.6513
Min	.3734	1.2136	1.6057	1.6409	1.6032
Avg	1.4350	2.0438	2.1393	2.2060	2.0257

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284055 / 33/11 KV Sec 14,Nerul s/stn

Feeder No / Name : 401 / 33 KV SEC 30 NERUL S/STN SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5947		.2572	.2058
2		1.4883	1.3672	.2058	.2058
3		1.4883		.2058	.2572
4		1.4352	1.3146	.2572	.2058
5		1.5415		.3086	
6		1.701	1.3672	.3086	.3086
7		1.701	1.4723	.3601	.3601
8		1.7541	1.6301	.4115	.463
9		1.9136	1.8404	.3601	.4115
10			1.8004	.3601	.3681
11		1.9456	1.9033	.3601	
12		2.1559		.3601	.3681
13			.3601	.3086	
14		1.7353	.3086	.2572	.2629
15				.2572	
16		1.5775	.2058	.2572	.2629
17			.2572	.2572	
18		2.1559		.2572	.3155
19			.3601	.3086	
20		1.9982	.3601	.3086	.3681
21			.3086	.3601	
22		1.8404	.3601	.3086	.3155
23	1.5947			.3086	
24	1.5415	1.6804	1.0517	.2572	.2572
Max	1.5947	2.1559	1.9033	.4115	.463
Min	1.5415	1.4352	.2058	.2058	.2058
Avg	1.5681	1.7475	.9569	.3001	.3085

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 201 / 11 KV SEC 24, SEC 30 STN SHEDDABLE URBAN

NERU Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3443		1.2346	1.3203
2		1.307	1.1576	1.2517	1.3375
3		1.3443		1.2003	1.3032
4		1.3443	1.0829	1.2003	1.3032
5		1.419		1.2517	1.3717
6		1.4937	1.2323	1.3546	1.4575
7		1.531	1.419	1.4746	1.5432
8		1.6057	1.5123	1.5432	1.5775
9		1.6804	1.6804	1.3889	1.406
10		1.3443	1.4403	1.2003	1.2136
11		1.2323	1.3717	1.0631	
12		1.2136		1.046	1.0082
13			1.2003	1.1145	
14		1.1016	1.1831	.9088	.9335
15			1.1831	.823	
16		.9709	.9602	.8402	.8215
17			1.0288	.8745	
18		1.2696		1.0631	1.1389
19			1.4575	1.3203	
20		1.531	1.4575	1.3375	1.419
21			1.4746	1.3546	
22		1.5123	1.4575	1.3546	1.419
23	1.4003		1.3889	1.3375	
24	1.2696	1.363	1.251	1.2003	1.3032
Max	1.4003	1.6804	1.6804	1.5432	1.5775
Min	1.2696	.9709	.9602	.823	.8215
Avg	1.3350	1.3671	1.3126	1.1974	1.2869

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 202 / 11 KV METRO,SEC 30 STN SHEDDABLE URBAN

NERUL Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1307		.12	.1029
2		.112	.112	.1029	.1029
3		.1307		.1029	.12
4		.1307	.0934	.12	.1372
5		.1307		.1029	.12
6		.112	.0934	.1029	.12
7		.1307	.0934	.12	.12
8		.1307	.1307	.12	.12
9		.1307	.1307	.0343	.12
10		.168	.12	.12	.1307
11		.112	.12	.12	
12		.1307		.12	.112
13			.12	.1029	
14		.1307	.12	.12	.112
15			.12	.12	
16		.1307	.12	.1029	.0934
17			.12	.12	
18		.112		.12	.1307
19			.12	.1029	
20		.112	.12		.1494
21			.12	.12	
22		.1494	.12	.12	.112
23	.112		.12	.12	
24	.1494	.1307	.112	.12	.12
Max	.1494	.168	.1307	.12	.1494
Min	.112	.112	.0934	.0343	.0934
Avg	.1307	.1286	.1161	.1111	.1190

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 204 / 11 KV NERUL GYMKHANA SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.056		.0686	.0686
2		.0934	.0747	.0686	.0686
3		.056		.0686	.0686
4		.056	.0747		.0686
5		.056			.0857
6			.0747	.0686	.0686
7		.0747	.0934		.0686
8		.0747	.0934		.0686
9		.0934	.112	.0686	.0686
10			.0857	.0686	.112
11		.0934	.0686	.0686	
12		.0747		.0686	.112
13			.0686	.0686	
14		.0934	.0686	.0686	.0934
15			.0686	.1029	
16		.0934	.0686	.0686	.0934
17			.0686	.0686	
18		.1307		.0857	.112
19			.0686	.0686	
20		.1307	.0686	.0686	.1307
21			.0686	.0686	
22		.0747	.0686	.0686	.112
23	.0747		.0686	.0686	
24	.0934	.056	.0934	.0686	.0686
Max	.0934	.1307	.112	.1029	.1307
Min	.0747	.056	.0686	.0686	.0686
Avg	.0841	.0817	.0767	.0712	.0864

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 205 / 11 KV SEC 14 S/S NERUL SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)
3		.0171
8		.0171
19	.0171	
Max	.0171	.0171
Min	.0171	.0171
Avg	.0171	.0171

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 206 / 11 KV SEC-50 NRI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)
4		.0171
8		.0171
19	.0171	
Max	.0171	.0171
Min	.0171	.0171
Avg	.0171	.0171

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 208 / 11 KV HAWARE Sec 28 Nerul SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2427		.2915	.2743
2		.2241	.2012	.2915	.2743
3		.2241		.3086	.2915
4		.2054	.1829	.2915	.3429
5		.2427		.3086	.3601
6		.2987	.2195	.2915	.3601
7		.3547	.2561	.3601	.3601
8		.3921	.3292	.3429	.3772
9		.3734	.3841		.3772
10		.3734	.3772	.2743	.3109
11		.3109	.3429	.2743	
12		.3841		.2401	.2561
13			.2915	.2572	
14		.2378	.2229	.1886	.2195
15			.1886	.1886	
16		.2195	.1886	.1886	.1829
17			.1886	.1886	
18		.2561		.2058	.2561
19			.2915	.2572	
20		.3109	.3258	.3086	.3292
21			.2915	.3086	
22		.2926	.3086	.2915	.2926
23	.2801		.2915	.2743	
24	.2241	.2614	.2378	.2743	.2401
Max	.2801	.3921	.3841	.3601	.3772
Min	.2241	.2054	.1829	.1886	.1829
Avg	.2521	.2891	.2695	.2699	.3003



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 401 / 33 KV SEC 11 NERUL S/STN SHEDDABLE URBAN  
Feeder KV- 33 / INCOMING

DATE	09-DEC-17	10-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
8		.0736	
9		.0736	
10			.0736
11	.0736		
14	.0736		.0736
22			.0736
Max	.0736	.0736	.0736
Min	.0736	.0736	.0736
Avg	.0736	.0736	.0736

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela  
s/s

Feeder No / Name : 201 / 11 KV RAGHULEELA NEW SHEDDABLE URBAN

FEEDER Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.6036	.4481	.7167	.3395
2	.2452	.4715	.4108	.5281	.3018
3	.2263	.3772	.3547	.3584	.2829
4	.2263	.3018	.2614	.3018	.2641
5	.2075	.2452	.2241	.2641	.2452
6	.2263	.2641	.2241	.2263	.2452
7	.2452	.2452	.2427	.2075	.2263
8	.2452	.2641	.2427	.2263	.2641
9	.3018	.3395	.3174	.3584	.3395
10	.3584	.3772	1.1576	.7167	.9896
11	1.358	1.6221	1.7541	1.6032	1.7551
12	1.3392	1.7364	1.7918	1.6975	1.6804
13	1.6409	1.9605	1.8484	1.6598	1.5123
14	1.6975	2.0165	1.8298	1.4146	1.6804
15	1.7353	2.0538	1.8484	1.6975	1.6991
16	1.7164	2.0165	1.8484	1.6975	1.7551
17	1.6975		1.8861	1.6975	1.7737
18	1.6598		1.9044	1.7918	1.7737
19	1.6975		1.8858	1.7353	1.7551
20	1.7353	2.0725	1.8861	1.7353	1.7364
21	1.773	1.531	1.8484	1.5466	
22	1.2449	1.0082	1.1763	.6224	
23	.8488	.8775	.8402	.4904	
24	.2829	.7167	.4668	.7922	.3395
Max	1.773	2.0725	1.9044	1.7918	1.7737
Min	.2075	.2452	.2241	.2075	.2263
Avg	.9572	1.0048	1.1124	1.0036	.9980

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela

s/s

Feeder No / Name : 203 / 11 KV VASHI RLY 3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075	.2263	.2241	.2452	.2263
2	.1886	.2075	.2054	.2263	.2263
3	.1886	.1886	.1867	.2075	.2075
4	.1886	.1886	.1867	.2075	.2075
5	.2075	.1886	.1867	.2263	.2263
6	.2075	.2075	.2054	.2452	.2452
7	.2263	.2263	.2241	.2641	.2263
8	.2075	.2641	.2054	.2452	.2641
9	.3018	.2829	.2241	.3395	.2641
10	.3772	.3395	.2427	.3772	.3547
11	.3961	.3206	.2452	.5281	.4108
12	.3772	.3547	.2641	.4338	.3361
13	.415	.3174	.2641	.4338	.3174
14	.415	.2987	.2452	.415	.3921
15	.3772	.3361	.2641	.4527	.4108
16	.3772	.3174	.2452	.415	.4338
17	.3772		.2641	.3772	.4338
18	.4527		.3018	.4338	.4108
19	.4715		.2987	.415	.3921
20	.3584	.3174	.2801	.4338	.3361
21	.3206	.2987	.2801	.3395	
22	.3206	.2987	.2614	.3018	
23	.2829	.2241	.2614	.3018	
24	.2263	.2641	.2427	.2452	.2263
Max	.4715	.3547	.3018	.5281	.4338
Min	.1886	.1886	.1867	.2075	.2075
Avg	.3112	.2699	.2421	.3379	.3118

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela  
s/s

Feeder No / Name : 204 / 11 KV MICROTECH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.4904	.4481	.415	.4904
2	.4527	.4527	.4108	.3772	.4904
3	.415	.415	.3734	.3772	.4715
4	.415	.3772	.3174	.415	.415
5	.4338	.3772	.3547	.3961	.4338
6	.4527	.415	.4481	.4338	.4527
7	.4904	.4338	.4668		.4527
8	.5093	.4715	.4668	.5658	.4715
9	.547	.4715	.4668	.6224	.6036
10	.6602	.5093	.4715	.6602	.6908
11	.8488	.6224	.5093	1.0185	.8775
12	.9054	.7468	.547	.9808	.9709
13	.9808		.6224	1.0751	1.0829
14	.9808	.7655	.6036	.9431	.9896
15	1.0562	.7095	.6036	1.1317	.9522
16	.9808	.6161	.5847	.9431	.8865
17	.7922		.4904	.8865	.8488
18	.7922		.5415	.7922	.8402
19	.8299		.5788	.8676	.8215
20	.8299	.6908	.6348	.7922	.8402
21	.7545	.6535	.6348	.7545	
22	.6979	.6161	.5975	.679	
23	.6602	.5975	.5975	.6224	
24	.5281	.5281	.5041	.4715	.5281
Max	1.0562	.7655	.6348	1.1317	1.0829
Min	.415	.3772	.3174	.3772	.415
Avg	.6877	.5480	.5114	.7053	.6958

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela

s/s

Feeder No / Name : 205 / 11 kv SUBSTATION TRF

SHEDDABLE URBAN

Raghuleel Feeder KV- 11 /  
OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.056	.0754	.0754
2	.0754	.0754	.0566	.0754	.0754
3	.0754	.0754	.056	.0754	.0754
4	.0754	.0754	.056	.0754	.0754
5	.0754	.0754	.056	.0754	.0754
6	.0754	.0754	.056	.0754	.0754
7	.0754	.0754	.056	.0754	.0754
8	.0754	.0754	.0747	.0754	.0754
9	.0754	.0754	.056		.0754
10	.0566	.0754	.0747	.0754	.056
11	.0754	.0754	.0566	.0754	.0747
12	.0754	.056	.0566	.0754	.0747
13	.0754	.056	.0566	.0754	.0747
14	.0754	.056	.0754	.0754	.056
15	.0754	.056	.0754	.0754	.056
16	.0754	.0747	.0566	.0754	.056
17	.0754		.0754	.0754	.0754
18	.0754		.0373	.0754	.0747
19	.0754		.0373	.0754	.0747
20	.0754	.0747	.0747	.0754	.056
21	.0754	.0747	.0747	.0754	
22	.0754	.0747	.0747	.0754	
23	.0754	.0747	.056	.0754	
24	.0754	.0754	.056	.0754	.0754
Max	.0754	.0754	.0754	.0754	.0754
Min	.0566	.056	.0373	.0754	.056
Avg	.0746	.0715	.0609	.0754	.0706

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela  
s/s

Feeder No / Name : 206 / 11 KV MAITHILLI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1694	1.226	1.2136	1.2637	1.2071
2	1.1317	1.1883	1.1576	1.1694	1.1694
3	1.094	1.1317	1.1576	1.094	1.1694
4	1.1128	1.1317	1.2136	1.1128	1.1694
5	1.1694	1.1694	1.2136	1.1694	1.2071
6	1.2071	1.226	1.251	1.2071	1.226
7	1.2637	1.2826	1.251	1.2826	1.2449
8	1.3203	1.3203	1.2696	1.358	1.3203
9	1.6598	1.3769	1.2883	1.7541	1.7353
10	1.773	1.5466	1.4563	1.8673	1.9044
11	1.9616	1.9239	1.5655	2.1125	1.9978
12	1.6409	1.8484	1.4901	2.037	1.9418
13	1.9805	1.7177	1.5089	2.0182	1.9044
14	1.9239	1.5684	1.5655	2.0559	1.8671
15	1.9427	1.475	1.5089	2.0559	1.9791
16	1.9427	1.8111	1.5089	2.037	2.0748
17	2.0182		1.5466	2.037	2.0559
18	1.9239		1.531	1.9616	1.8671
19	1.6598		1.531	1.7353	1.643
20	1.5844	1.5497	1.5123	1.5089	1.5123
21	1.4901	1.4937	1.475	1.3203	
22	1.3957	1.3817	1.363	1.3203	
23	1.2637	1.307	1.2883	1.2637	
24	1.2826	1.2449	1.2883	1.3014	1.226
Max	2.0182	1.9239	1.5655	2.1125	2.0748
Min	1.094	1.1317	1.1576	1.094	1.1694
Avg	1.5380	1.4248	1.3815	1.5851	1.5916

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela

s/s

Feeder No / Name : 207 / 11 KV FISH MARKET

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.5281	.5601	.5658	.5658
2	.4904	.4904	.4854	.547	.5281
3	.5281	.4904	.3734	.5228	.5281
4	.547	.5281	.4481	.5658	.547
5	.6036	.6036	.4854	.6036	.6036
6	.6413	.6413	.6348	.679	.6413
7	.6979	.679	.6722	.7356	.679
8	.6413	.7167	.6535	.679	.7167
9	.6413	.6413	.6348	.679	.6224
10	.6224	.6224	.6535	.6602	.5788
11	.5093	.6036	.547	.5658	.5041
12	.4715	.5228	.5847	.547	.4854
13	.4527	.5601	.5847	.5093	.4481
14	.5093	.5601	.4527	.5281	.4481
15	.4527	.5975	.547	.4527	.4294
16	.4527	.5041	.5093	.4904	.547
17	.415		.5281	.5093	.4715
18	.5658		.6348	.6036	.5975
19	.6413		.6722	.6602	.7095
20	.7167	.7655	.7468	.6979	.7282
21	.6602	.7468	.7282	.6602	
22	.6413	.6908	.7095	.6602	
23	.6413	.6348	.6348	.6224	
24	.547	.5658	.5975	.6224	.5658
Max	.7167	.7655	.7468	.7356	.7282
Min	.415	.4904	.3734	.4527	.4294
Avg	.5674	.6044	.5866	.5986	.5688

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela  
s/s

Feeder No / Name : 208 / 11 KV ORISSA BHAVAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1698	.1494	.1509	.1509
2	.1698	.1698	.1494	.132	.1509
3	.1698	.1509	.1307	.132	.1509
4	.1509	.1509	.1307	.132	.132
5	.1509	.1509	.1307	.132	.132
6	.1509	.1509	.1307	.1509	.1509
7	.1509	.1509	.1494	.1509	.132
8	.2641	.1698	.1494	.2829	.1698
9	.2263	.1698	.1494	.4338	.2641
10	.547	.415	.168	.6036	.5041
11	.5281	.4527	.2452	.6224	.5415
12	.5658	.3921	.2075	.6224	.5415
13	.5658	.3921	.2075	.6224	.5228
14	.5658	.3921	.2075	.6036	.5601
15	.5847	.4294	.2641	.6036	.5788
16	.5658	.4294	.1886	.6036	.6036
17	.4904		.1886	.6413	.5847
18	.4527		.1867	.5093	.5228
19	.3772		.1867	.415	.4108
20	.3206	.5975	.1867	.3772	.2614
21	.2641	.4854	.168	.2263	
22	.2075	.1867	.168	.1886	
23	.1886		.168	.1886	
24	.1886	.1698	.168	.1509	.1509
Max	.5847	.5975	.2641	.6413	.6036
Min	.1509	.1509	.1307	.132	.132
Avg	.3348	.2888	.1741	.3615	.3436



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela  
s/sFeeder No / Name : 209 / 11 KV CIDCO BUSINESS  
CENTER Feeder KV- 11 /  
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.0566	.056	.0943	.0943
2	.0754	.0566	.056	.0754	.0754
3	.0566	.0566	.056	.0566	.0566
4	.0377	.0566	.056	.0566	.0566
5	.0377	.0566	.056	.0566	.0566
6	.0377	.0566	.056	.0566	.0566
7	.0377	.0566	.056	.0566	.0566
8	.0566	.0566	.2054	.1886	.2075
9	.0566	.0566	.1494	.2075	.1509
10	.0566	.0566	.168	.2075	.2241
11	.0566	.0566	.2641	.2075	.2241
12	.0566	.0373	.2452	.3395	.2054
13	.0566	.0373	.2452	.2075	.2054
14	.0566	.056	.2263	.2075	
15	.0566	.2427	.2641	.2075	.2054
16	.0566	.3361	.2641	.2263	.2075
17	.0566		.2829	.1698	.2075
18	.0566		.2987	.2452	.2241
19	.0566		.2987	.2829	.2614
20	.0566	.3734	.3174	.3206	.2614
21	.0566	.3174	.3174	.2829	
22	.0566	.2987	.2987	.3018	
23	.0566	.112	.2987	.1509	
24	.1698	.0566	.056	.1509	.0943
Max	.1698	.3734	.3174	.3395	.2614
Min	.0377	.0373	.056	.0566	.0566
Avg	.0613	.1186	.1913	.1815	.1566

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada

s/stn

Feeder No / Name : 201 / 11 KV RELIANCE Sanpada

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0543	.0379	.0543	.0379	.0365
2	.0543	.0379	.0543	.0379	.0365
3	.0543	.0379	.0543	.0379	.0365
4	.0543		.0543	.0379	.0365
5	.0543		.0543	.0379	.0365
6	.0543	.0379	.0543	.0379	.0365
7	.0724	.0379	.0543	.0379	.0365
8	.0724	.0758	.0548	.0379	.0365
9	.0548	.073	.0548	.0758	.0365
10	.073	.073	.0548	.0379	.0365
11	.073	.073	.0548	.0758	.0365
12	.073	.073	.0548	.0758	.0365
13	.073	.073	.0548	.0379	
14	.073	.073	.0548	.0379	
15	.0548	.073	.0548	.0379	
16	.0569	.0724		.0379	.0362
17		.0543	.0379		.0362
18	.0379	.0543	.0379	.0569	.0362
19	.0379	.0724	.0379	.0379	.0543
20	.0379	.0543	.0379	.0379	.0543
21	.0379	.0543	.0379	.0379	.0543
22	.0379	.0543	.0379	.0365	.0543
23	.0379	.0543	.0379	.0365	.0543
24	.0543	.0379	.0543	.0379	.0362
Max	.073	.0758	.0548	.0758	.0543
Min	.0379	.0379	.0379	.0365	.0362
Avg	.0558	.0584	.0495	.0435	.0407

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada

s/stn

Feeder No / Name : 202 / 11 KV SAI PRIDE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0753	1.1191	1.012	1.2378	.9397
2	1.0911	1.1022	.9804	1.2378	.9238
3	1.0753	1.1022	.9488	1.2209	.8442
4	1.1069	1.0852	.9172	1.2209	.9238
5		1.1022	.933	1.2039	.9716
6	1.1702	1.1361	.9804	1.1869	1.0194
7	1.4074	1.2378	1.1069	1.1869	1.3061
8	1.3599	1.1191	1.1468	1.3395	1.3857
9	1.2264	1.2264	1.1946	1.6303	1.3538
10	1.4653	1.4175	1.322	1.4922	1.3538
11	1.4813	1.5768	1.545	1.2039	1.4335
12	1.2901	1.4972	1.4335	1.5091	1.3698
13	1.3061	1.3698	1.3061	1.3226	
14	1.1309	1.3698	1.2264	1.2717	
15	1.2105	1.322	1.1309	1.307	
16	1.1869	1.3283		1.2039	1.1385
17		1.3441	1.2548	1.3056	1.3441
18	1.4752	1.5181	1.4413	1.4752	1.4232
19	1.543	1.3757	1.4413	1.4074	1.3599
20	1.4243	1.3283	1.5091	1.3904	1.2809
21	1.4937	1.2967	1.4413	1.3565	1.2967
22	1.3226	1.2809	1.3735	1.2423	1.2967
23	1.3056	1.2492	1.2887	1.1149	1.2176
24	1.0753	1.1191	1.1069	1.2378	1.0034
Max	1.543	1.5768	1.545	1.6303	1.4335
Min	1.0753	1.0852	.9172	1.1149	.8442
Avg	1.2829	1.2760	1.2192	1.3044	1.1993

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada  
s/stnFeeder No / Name : 203 / 11 KV SEWERAGE TREATMENT  
PLANT Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3142	.3429	.2402	.4382	.2804
2	.3326	.362	.2218	.4382	.299
3	.3511	.3429	.2402	.4382	.3364
4	.3142	.362	.2218	.4382	.3364
5	.3326	.362	.3142	.4572	.3551
6	.2957	.4001	.3696	.4572	.3551
7	.5175	.4763	.2218	.4572	.4673
8	.5544	.4954	.3364		.299
9	.5794	.5046	.4859	.6952	.6915
10	.7663	.5046	.4486	.8192	.6355
11	.8224	.5233	.4112	.6859	.6355
12	.6728	.542	.4299	.8002	.6915
13	.6728	.4673	.4859	.9526	
14	.8411	.4486	.3925	.7621	
15	.785	.4112	.3364	.7811	
16	.7811	.462		.7811	.7577
17		.5359	.4954	.5716	.7023
18	.6668	.499	.3429	.5716	.7392
19	.5335	.4066	.3429	.5906	.6099
20	.381	.3881	.3429	.4763	.4805
21	.362	.3881	.362	.381	.3696
22	.3239	.2587	.381	.3925	.3881
23	.3429	.2772	.3429	.4112	.3696
24	.3142	.3239	.2587	.4191	.3177
Max	.8411	.542	.4954	.9526	.7577
Min	.2957	.2587	.2218	.381	.2804
Avg	.5155	.4202	.3489	.5746	.4818

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20,Sanpada  
s/stnFeeder No / Name : 204 / 11 KV PAN INDIA VASHI  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.4334	.3734	.358	.4058
2	.3921	.4334	.3547	.3392	.3881
3	.3734	.4145	.3361	.358	.3881
4	.3921	.3957	.3174	.358	.4058
5	.3547	.3957	.3174	.358	.3705
6	.3921	.3768	.3361	.3768	.3705
7	.3921	.1884	.3734	.3768	.3881
8	.4294	.4145	.3528	.4522	.4058
9	.5293	.4234	.3881	.5653	.494
10	.5998	.494	.3881	.7537	.6351
11	.6704	.5998	.4234	.8291	.7057
12	.7057	.5998	.4234	.8291	.741
13	.741	.5645	.4058	.7914	
14	.7057	.5998	.3881	.7545	
15	.7057	.5998	.4234	.7914	
16	.7914	.6348		.8668	.7842
17		.6348	.4145	.7725	.7095
18	.7537	.5975	.4145	.603	.6908
19	.6406	.5041	.4145	.6406	.6348
20	.5653	.4668	.3768	.5276	.5041
21	.4899	.4294	.3768	.5276	.4854
22	.4522	.4108	.3768	.6351	.4668
23	.4145	.4108	.3768	.4234	.4481
24	.4294	.4522	.3921	.3768	.4234
Max	.7914	.6348	.4234	.8668	.7842
Min	.3547	.1884	.3174	.3392	.3705
Avg	.5361	.4781	.3802	.5694	.5165

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada

s/stn

Feeder No / Name : 205 / 11 KV KESHAV KUNJ

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8669	.9259	.8322	.8745	.803
2	.8322	.9088	.7975	.8745	.7709
3	.8322	.9088	.7802	.8573	.7388
4	.7975	.8916	.7628	.8573	.7549
5	.8149	.8745	.7282	.8402	.7549
6	.8495	.8573	.7628	.8402	.7709
7	.9189	.823	.7282	1.046	.9315
8	.8842	.8059	.7227	.8745	.803
9	.803	.8191	.7709	.8573	.8994
10	.9315	.9958	.9315	1.1145	.9315
11	1.0118	.9958	.9476	1.1488	.9315
12	.9958	1.1243	1.06	.9774	.8994
13	.8994	1.0279	1.0279	.9945	
14	.8673	.9637	1.0279	.9431	
15	.8833	1.044	.8673	.8745	
16	.9774	1.0229		.8916	.9882
17		.9015	.9259	.9774	1.0056
18	.9259	.9709	.9945	.9945	1.0056
19	.9602	1.0576	1.0974	1.0117	1.0229
20	.9259	1.0229	.9431	1.0117	1.0056
21	.9602	.9882	.9602	.9945	1.0056
22	.9945	.9536	.9774	.9637	1.0056
23	.9259	.9189	1.0154	.803	.9015
24	.8495	1.0154	.8495	.8573	.7227
Max	1.0118	1.1243	1.0974	1.1488	1.0229
Min	.7975	.8059	.7227	.803	.7227
Avg	.9003	.9508	.8918	.9367	.8882

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20,Sanpada  
s/stnFeeder No / Name : 206 / 11 KV LADIES HOSTELL,SEC SHEDDABLE URBAN  
10,SA Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9997	1.0342	1.0374	1.2035	.9532
2	1.0185	1.0342	1.0185	1.2223	.9345
3	1.0374	1.0154	.9997	1.2223	1.0093
4	1.0562	1.0342	.9431	1.2035	1.028
5	1.0185	1.0154	.9619	1.2223	1.0466
6	1.0374	1.0154	.9808	1.2223	1.0653
7	1.4901	1.2975	1.2826	1.3211	1.327
8	1.4712	1.4667	1.4391	1.5232	1.4578
9	1.3457	1.3831	1.4204	1.4103	1.2335
10	1.1214	1.2896	1.4018	1.2411	1.1588
11	1.084	1.0466	1.1588	1.1847	.9345
12	.9532	1.3083	1.1214	1.053	.9906
13	1.0093	1.1401	.9532	.9402	
14	.9158	.9532	.9719	.9402	
15	.8597	.9345	.9719	.8838	
16	.8462	.9054		.865	.7716
17		1.1317	1.1095	1.0154	1.0185
18	1.3915	1.4146	1.4479	1.4667	1.3392
19	1.4855	1.5278	1.5796	1.4667	1.4901
20	1.4103	1.5278	1.5984	1.4291	1.5089
21	1.4667	1.5466	1.5608	1.4855	1.4146
22	1.3539	1.5089	1.5043	1.4391	1.4335
23	1.2035	1.1883	1.2411	1.1214	1.094
24	.9808	1.053	1.094	1.1847	1.0653
Max	1.4901	1.5466	1.5984	1.5232	1.5089
Min	.8462	.9054	.9431	.865	.7716
Avg	1.1546	1.1989	1.2086	1.2195	1.1559

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada  
s/stnFeeder No / Name : 207 / Sector 11 sanpada Bhoomi  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.3429	.2743	.362	.2422
2	.2743	.362	.2595	.381	.2422
3	.2915	.3429	.2422	.362	.2249
4	.3258	.3239	.2076	.362	.2595
5	.3086	.3239	.2076	.3429	.2768
6	.2915	.3048	.2249	.3239	.3114
7	.3601	.3048	.2401	.4001	.3633
8	.4287	.362	.2941	.4191	.346
9	.4498	.4498	.4498	.5906	.519
10	.5363	.5363	.4325	.724	.6574
11	.5882	.519	.519	.7049	.5882
12	.5882	.5882	.4498	.6859	.5709
13	.3806	.5363	.4498	.5906	
14	.4671	.4498	.3806	.5144	
15	.4671	.4498	.3806	.5716	
16	.5716	.3944		.5716	
17		.3601	.362	.5144	.3429
18	.5716	.4115	.4191	.5144	.3086
19	.4954	.3944	.4191	.5525	.1886
20	.4191	.3772	.4382	.381	.1715
21	.4001	.3944	.4191	.3429	.1886
22	.4191	.3086	.381	.3287	.1543
23	.3429	.3086	.362	.2941	.1543
24	.2915	.3239	.3258	.3429	.3114
Max	.5882	.5882	.519	.724	.6574
Min	.2743	.3048	.2076	.2941	.1543
Avg	.4157	.3946	.3539	.4657	.3211



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20,Sanpada  
s/stn

Feeder No / Name : 209 / Cidco Exhibition

Centre,Vashi Feeder KV- 11 /  
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724	.0732	.0724	.0549	.076
2	.0724	.0732	.076	.0732	.076
3	.0724	.0732	.076	.0732	.076
4	.0724	.0732	.076	.0732	.076
5	.0724	.0732	.076	.0732	.076
6	.0732	.0549	.076	.0549	.076
7	.0724	.0549	.0724	.0549	.076
8	.0724	.0549	.076	.0549	.076
9	.076	.057	.076	.0572	.076
10	.076	.057	.076	.0549	.076
11	.076	.057	.076	.0549	
12	.076	.057	.076	.0549	.076
13	.076	.076	.076	.0549	
14	.076	.076	.076	.0549	
15	.076	.076	.076	.0549	
16	.0732	.0724			.0543
17		.0724	.0732	.0732	.0543
18	.0732	.0724	.0732	.0732	.0543
19	.0732	.0724	.0732	.0732	.0543
20	.0732	.0724	.0732	.0732	.0543
21	.0732	.0724	.0732	.0732	.0543
22	.0732	.0724	.0732	.076	.0543
23	.0732	.0724	.0732	.076	.0543
24	.0732	.0732	.0724	.0732	.076
Max	.076	.076	.076	.076	.076
Min	.0724	.0549	.0724	.0549	.0543
Avg	.0738	.0683	.0747	.0648	.0673

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284254 / 33/33KV Sec- 20 Sanpada

Feeder No / Name : 401 / Feeder No1-33KV IC Sec14 NON SHEDDABLE EXPRESS HV FEEDERS  
Nerul Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	1.7095	2.1084	2.2794	1.8654	2.2794
Max	1.7095	2.1084	2.2794	1.8654	2.2794
Min	1.7095	2.1084	2.2794	1.8654	2.2794
Avg	1.7095	2.1084	2.2794	1.8654	2.2794

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284254 / 33/33KV Sec- 20 Sanpada

Feeder No / Name : 402 / Feeder No 2- 33KV IC NRI NON SHEDDABLE EXPRESS HV FEEDERS  
Sec 5 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	.4001	.4001	.4001	.3601	.4001
Max	.4001	.4001	.4001	.3601	.4001
Min	.4001	.4001	.4001	.3601	.4001
Avg	.4001	.4001	.4001	.3601	.4001

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&amp;M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 417 / 33 KV IC SEC 30 NERUL STN NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.1794		3.3436	3.1893
2		2.1262	2.1033	3.3951	3.2407
3		2.0199		3.3436	3.4465
4		2.073	1.893	3.5494	3.4465
5		2.2325		3.8066	3.7037
6		2.3388	1.9982	4.0124	4.0124
7		2.4983	2.3137	4.0124	4.1152
8		2.5514	2.3137	4.0638	4.1667
9		2.392	2.4188	4.0638	3.6523
10			2.572	3.6008	3.5231
11		2.0508	2.3663	3.3951	
12		2.0508		3.2407	3.1024
13			4.1152	3.3436	
14		1.7353	3.5494	2.9835	2.8921
15			3.1893	2.7778	
16		1.7353	3.2407	2.8807	2.8395
17			3.6008	3.0864	
18		2.2085		3.6008	3.786
19			4.5268	4.1667	
20		2.5766	4.3724	4.2181	4.2593
21			4.321	4.1152	
22		2.4714	4.2181	4.0124	3.9438
23	2.2857		3.858	3.5494	
24	2.073	2.2325	2.1033	3.4465	3.1893
Max	2.2857	2.5766	4.5268	4.2181	4.2593
Min	2.073	1.7353	1.893	2.7778	2.8395
Avg	2.1794	2.2043	3.1092	3.5837	3.5593

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 201 / 11 KV KL-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.46			
2		1.4415			
7				2.1807	
8				1.9959	
9			1.8111	1.7556	
10	1.5154	1.6263	1.6448	1.6263	
11	1.5524	1.4969	1.6078	1.5708	
12		1.4784	1.7002	1.5339	
13	1.4045	1.4784	1.423	1.4969	
14	1.4045		1.4045	1.386	
15	1.2382	1.3121		1.3121	
16	1.2012	1.3306	1.2936	1.2936	
17	1.2936	1.5154	1.423	1.4415	
18	1.7002	1.922	1.8111	1.8296	
19	2.1068	2.4949	2.2177	2.3285	
20	2.0698	2.2546	2.0698		
21		2.0328	1.885		
22	1.848	1.848	1.8298	1.8111	1.7187
23	1.7741	1.7741	1.8111		
24	1.5154	1.6078	1.6632	1.6078	1.4969
Max	2.1068	2.4949	2.2177	2.3285	1.7187
Min	1.2012	1.3121	1.2936	1.2936	1.4969
Avg	1.5865	1.6921	1.7064	1.6780	1.6078

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 202 / 11 KV B G SHIRKE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8149			
2		.8149			
7				.8573	
8			.8669	.8916	
9			.7975	.8059	
10	.7282	.7628	.8669	.7545	
11	.7108	.6935	.6935	.6859	
12	.7455	.7628	.6588	.6173	
13	.8149	.7975	.8322	.6539	
14	.6935	.7802	.7282	.6344	
15	.6588	.6588		.6173	
16	.6068	.6468	.6588	.583	
17		.6173	.6588	.6173	
18	.7628	.7202	.7975	.6859	
19	.7628	.7202	.7888	.7545	
20	.8322	.7545	.823		
21		.8916	.823		
22	.8322	.7888	.823	.8149	.7802
23	.8842	.7202	.7888		
24	.8149	.7975	.7545	.7716	.7108
Max	.8842	.8916	.8669	.8916	.7802
Min	.6068	.6173	.6588	.583	.7108
Avg	.7575	.7496	.7725	.7164	.7455

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 203 / 11 KV V M JOG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.262			
2		1.2269			
7				1.6651	
8			1.6827	1.7528	
9			1.7878	1.7177	
10	1.4548	1.5249	1.6476	1.4723	
11	1.2795	1.3847	1.5074	1.4022	
12	1.2445	1.2445	1.4022	1.3496	
13	1.2445	1.1919	1.2795	1.2269	
14	1.1218	1.1744	1.2094	1.1568	
15	1.0517	.6661		1.0692	
16	1.0341	1.0517	1.2094	1.0517	
17	1.0517	1.262	1.2269		
18	1.4198	1.5775	1.5424	1.4899	
19	1.6476	1.7177	1.8404	1.6827	
20	1.7002	1.7353	1.7528		
21		1.7177	1.7528		
22	1.6301	1.6126	1.7002		1.6301
23		1.5074	1.5775		
24	1.2445		1.3672	1.3847	1.3321
Max	1.7002	1.7353	1.8404	1.7528	1.6301
Min	1.0341	.6661	1.2094	1.0517	1.3321
Avg	1.3173	1.3661	1.5304	1.4170	1.4811

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 204 / 11 KV Herambha

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1576			
2		1.1016			
7				1.7177	
8				1.7177	
9			1.643	1.6804	
10	1.363	1.6804	1.5123	1.587	
11	1.363	1.3443	1.5684	1.3817	
12		1.3443	1.4937	1.251	
13	1.1763		1.363	1.1389	
14	1.0456		1.2883	1.1203	
15	1.0829	1.1763		1.0829	
16	1.0642	1.1203	1.2136	1.0719	
17	1.0829	1.1949	1.2696	1.1576	
18	1.4937	1.4003		1.4003	
19	1.5497	1.643	1.6804	1.531	
20	1.5497	1.5497	1.5684		
21		1.4937	1.531		
22	1.5123	1.475	1.4937	1.4377	1.4003
23		1.419	1.4563		
24	1.1576	1.2323	1.307	1.3443	1.2323
Max	1.5497	1.6804	1.6804	1.7177	1.4003
Min	1.0456	1.1016	1.2136	1.0719	1.2323
Avg	1.2867	1.3555	1.4563	1.3747	1.3163



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 205 / 11 KV SEC 14

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		1.2197			
7				1.6263	
8			1.5912	1.848	
9			1.7926	1.6263	
10	1.6078	1.6632	1.7926	1.5708	
11	1.5154	1.5708	1.7741	1.5154	
12	1.4784	1.6078	1.7926	1.4969	
13	1.4969	1.5708	1.6632	1.386	
14	1.3676	1.4784	1.5708	1.3491	
15	1.2567	1.3306		1.3121	
16	1.2567	1.2567	1.386	1.423	
17	1.2936	1.4969	1.5524	1.4415	
18	1.5893	1.7187	1.8296	1.6632	
19	1.8111	1.9404	1.9404	1.8111	
20	1.885	1.885	1.9959		
21		1.922	1.922		
22	1.6817	1.7741	1.848	1.8111	1.7187
23		1.6632	1.6263		
24	1.3306	1.4415	1.4784	1.4784	1.4045
Max	1.885	1.9404	1.9959	1.848	1.7187
Min	1.2567	1.2197	1.386	1.3121	1.4045
Avg	1.5054	1.5962	1.7223	1.5573	1.5616

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 206 / 11 KV STP 12 FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2772			
2		.1478			
9			.2033		
10	.2218	.2218	.2033	.0924	
11	.3142	.2957	.2033	.0924	
12		1.3121	.1109	.0924	
13	.1848	.2402	.2033	.0924	
14	.3142		.2033	.1848	
15	.2957	.1109		.0185	
16	.2033			.0924	
17	.2054		.2033	.0924	
18		.1109	.2033	.0924	
19	.3142	.1109	.2957	.0185	
20	.2218	.1109	.1867		
21		.1109	.1848		
22	.3142	.1109	.2033	.0554	.0924
23		.0924	.1109		
24	.2772	.2957	.0924	.2033	.0924
Max	.3142	1.3121	.2957	.2033	.0924
Min	.1848	.0924	.0924	.0185	.0924
Avg	.2606	.2535	.1863	.0939	.0924

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 207 / SEC-9/E FEEDER NO-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1008			
2		.0934			
7				.1307	
8			.0934	.1494	
9			.1307	.1307	
10	.1456	.1326	.1494	.1307	
11	.127	.1587	.168	.112	
12	.1867	.112	.1867	.112	
13	.1307	.1494	.168	.112	
14	.112		.1494	.112	
15	.1307	.112		.112	
16	.0934	.112	.1867	.0747	
17	.0934	.0934	.1494	.112	
18	.112	.1867	.1494	.1307	
19	.0934	.1867	.1494	.1307	
20	.1326	.1307	.168		
21		.1494	.1494		
22	.1326	.1307	.1307	.1382	.1363
23		.1307	.168		
24	.1307	.155	.1867	.1307	.1624
Max	.1867	.1867	.1867	.1494	.1624
Min	.0934	.0934	.0934	.0747	.1363
Avg	.1247	.1334	.1552	.1212	.1494

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 208 / SEC-9/E FEEDER NO-2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0635			
2		.0579			
7				.056	
8				.056	
9			.056	.056	
10	.0709	.0653	.0934	.0747	
11	.0896	.1046	.1307	.0747	
12		.0934	.1307	.0934	
13	.0747	.0934	.0934	.0934	
14	.0747		.112	.0934	
15	.056	.0934		.0747	
16	.0747	.0934	.0934	.0747	
17	.056	.0747	.0934	.0934	
18	.112	.1494	.1307	.1307	
19	2.0538	.1307	.1307	.1307	
20	.127	.1307	.1494		
21		.1307	.112		
22	.0896	.0934	.0934	.0822	.0915
23		.0747	.0747		
24	.0635	.0653	.0747	.0747	.0616
Max	2.0538	.1494	.1494	.1307	.0915
Min	.056	.0579	.056	.056	.0616
Avg	.2452	.0947	.1046	.0839	.0766

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 209 / 11KV NEW LIG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6478			
2		.6154			
7				.9069	
8				.9069	
9			.9231	.8745	
10	.7773	.8097	.8745	.7125	
11	.6802	.7611	.7449	.7125	
12		.7125	.7287	.6802	
13	.8583		.7449	.6964	
14	.8583		.6964	.664	
15	.6478	.5992		.6316	
16	.5992	.6478	.6802	.5992	
17	.8583	.7125	.7125	.6478	
18	.7287	.7773	.8421	.7773	
19	.7773	.8421	.8421	.8097	
20	.8745	.8583	.8421		
21		.8583	.8421		
22	.9069	.8421	.8421	.8745	.8907
23		.7773	.7773		
24	.6478	.7125	.6478	.6478	.6478
Max	.9069	.8583	.9231	.9069	.8907
Min	.5992	.5992	.6478	.5992	.6478
Avg	.7679	.7449	.7827	.7428	.7693

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223032 / 22/11 KV Kalmboli Steel

Market

Feeder No / Name : 201 / 11 KV STEEL CHAMBER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1303	.1412	.1289	.1213	
2	.1249	.1361	.1276	.1267	
3	.1285	.1379	.1276	.1303	
4	.1303	.1361	.1276	.1357	
5	.1267	.1343	.1276	.1376	
6	.1249	.1343	.1311	.143	.111
7	.1231	.1379	.1276	.1213	.1205
8		.1397	.1169	.1104	.0921
9	.1738	.1453	.1303	.1303	.1218
10	.2131	.2221	.1412	.2551	.2651
11	.3295	.3189	.1846	.3474	.3116
12	.3222	.3189	.1846	.3653	.3403
13	.3725	.3296	.1575	.365	.3403
14	.3689	.2977	.1376	.3544	
15	.3546	.3225	.1412	.3508	
16	.3439	.3009	.1303	.3403	
17	.3259	.2973	.1538	.3544	.4298
18	.3403	.2973	.1394	.2835	.3618
19	.2615	.24	.143	.2751	.2919
20	.2042	.197	.143	.2162	.2077
21	.1755	.1576	.1376	.1719	.1863
22	.1755	.1612	.1249	.1382	.1486
23	.1361	.1397		.1146	.1415
24	.1285	.1433	.1347	.1176	.1195
Max	.3725	.3296	.1846	.3653	.4298
Min	.1231	.1343	.1169	.1104	.0921
Avg	.2224	.2078	.1391	.2169	.2244

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 201 / 11 KV C.E. FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5154			1.643	
2	1.4415			1.5708	
3	1.4415			1.4784	
4	1.5154			1.4784	
5	1.7002			1.6632	
6	1.885			2.0328	
7	2.2177		1.7551	2.2177	
8	2.3101		2.0165	2.4025	
9	2.2177		2.1285	2.1807	.4854
10			2.3101		.4481
11			1.9589		
12			2.0328	1.8111	.4108
13		1.7741	1.848		.4481
14			1.7002		.4108
15		1.5684	1.5524	1.4045	
16		1.6263	1.6632		.4108
17		1.7002	1.7372		.4108
18			2.1437	.5914	.4854
19			2.2546		
20		2.1285	2.2916		
21		2.2405	2.2177		.4481
22		2.0165	2.0328		
23		1.9044	1.848		.4481
24	1.5708		1.6804	1.7372	.3361
Max	2.3101	2.2405	2.3101	2.4025	.4854
Min	1.4415	1.5684	1.5524	.5914	.3361
Avg	1.7815	1.8699	1.9540	1.7086	.4311

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 202 / 11 KV N.T.F.C. FEEDER NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1109			.1478	
2	.112			.1478	
3	.1109			.1478	
4	.1109			.1494	
5	.1109			.1478	
6	.112			.1494	
7	.1109		.1132	.1848	
8	.1109		.1494	.1478	
9	.1109	.1143	.1509	.1848	.1524
10		.1478	.1478		.1494
11		.1494	.1867		
12			.1478	.1848	.112
13		.112	.1848		.112
14			.1494		.112
15		.112	.1494	.1848	
16	.1494	.112	.1867		.1494
17	.1478	.1478	.1848		.112
18	.1524		.1848	.1848	
19	.1524		.1848		
20	.1143	.1494	.1848		
21	.1143	.1494	.1478		.0187
22	.1143	.112	.1848		
23	.1143	.1494	.1848		.0189
24	.112	.1143	.1509	.1867	.1524
Max	.1524	.1494	.1867	.1867	.1524
Min	.1109	.112	.1132	.1478	.0187
Avg	.1206	.1308	.1652	.1653	.1089



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 203 / SUB STATION T/F

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0185			.0187	
2	.0185			.0187	
3	.0185			.0187	
4	.0185			.0187	
5	.0185			.0187	
6	.0185			.0187	
7	.0187		.0189	.0187	
8	.0187		.0189	.0187	
9	.0187	.0191	.0189	.0187	.0191
10		.0189	.0187		.0189
11		.0189	.0189		
12			.0185	.0189	.0189
13		.0189	.0185		.0189
14			.0189		.0189
15		.0189	.0189	.0189	
16	.0189	.0189	.0189		.0187
17	.0189	.0189	.0185		.0187
18	.0191		.0185	.0189	.0189
19	.0191		.0185		
20	.0191	.0187	.0185		
21	.0191	.0189	.0185		.0189
22	.0191	.0189	.0187		
23	.0191	.0189	.0187		.0189
24	.0185	.0191	.0189	.0187	.0191
Max	.0191	.0191	.0189	.0189	.0191
Min	.0185	.0187	.0185	.0187	.0187
Avg	.0188	.0189	.0187	.0187	.0189

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 204 / 11 KV MHATMA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5708			1.7556	
2	1.4784			1.6632	
3	1.4415			1.6263	
4	1.4415			1.5708	
5	1.7556			1.848	
6	2.0328			2.3101	
7	2.3101		1.7924	2.4394	
8	2.5873		2.1658	2.5873	
9	2.4394	2.5393	2.3152	2.5873	2.3152
10		2.2405	2.4764		2.0911
11		2.0911	2.2405		
12			2.1437	1.922	
13		1.922	2.0698		1.643
14			1.7924		1.5684
15		1.643	1.6263	.7842	
16	2.2405	1.6263	1.643		1.5684
17	2.0911	1.7924	1.7741		1.4937
18	2.3152		2.2916	2.2177	1.9753
19	2.4646		2.5133	2.2177	
20	2.3152	2.4143	2.5133		
21	2.2032	2.3411	2.4394		2.268
22	2.1658	2.2405	2.2916		
23	2.0911	2.1658	2.1437		1.9753
24	1.848	1.9418	1.8671	1.922	1.7924
Max	2.5873	2.5393	2.5133	2.5873	2.3152
Min	1.4415	1.6263	1.6263	.7842	1.4937
Avg	2.0440	2.0798	2.1166	1.9608	1.8691

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 205 / 11Kv Pump P2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3306			1.5708	
2	1.3306			1.4784	
3	1.2567			1.3306	
4	1.2567			1.3306	
5	1.4784			1.6632	
6	2.0328			1.848	
7	2.1437		1.643	1.922	
8	2.2405		1.829	2.2177	
9	2.2177	2.1216	2.0911	2.0698	1.9753
10		2.1437	2.2177		1.829
11		1.9959	1.9418		
12			1.848	1.7177	1.8671
13		1.5684	1.7002		1.5684
14			1.4937		1.4266
15		1.3306	1.3306	1.3306	
16	1.9418	1.2567	1.3306		1.2437
17	1.7177	1.3306	1.3306		1.2437
18	2.0851		1.848		1.576
19	2.1216		2.0698	1.848	
20	1.829	2.1658	1.9959		
21	1.7924	1.8671	1.922		1.9753
22	1.7924	1.9418	1.922		
23	1.7558	1.7558	1.7741		1.7177
24	1.4045	1.5364	1.4632	1.6263	1.4632
Max	2.2405	2.1658	2.2177	2.2177	1.9753
Min	1.2567	1.2567	1.3306	1.3306	1.2437
Avg	1.7627	1.7512	1.7640	1.6887	1.626

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 206 / HORIZON SCHOOL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4066			.4066	
2	.3696			.3734	
3	.3696			.3361	
4	.3696			.3361	
5	.4066			.3734	
6	.4805			.4805	
7	.5544		.439	.3696	
8	.5914		.439	.6283	
9	.7023	.7167	.4755	.7762	.6584
10		.6348	.4066		.7682
11		.7095	.4066		
12			.4435	.8871	.8215
13		.7023	.4805		.8413
14			.4854		.6722
15		.6283	.5544	.8131	
16	.6348	.6348	.4854		.7095
17	.6722	.5914	.4435		.6219
18	.6413		.4435	.4854	
19	.6413		.4435		
20	.6036	.5975	.4435		
21	.5658	.5121	.4435		.4656
22	.5658	.4755	.4066		
23	.5658	.4854	.4805		.4108
24	.4435	.415	.439	.4435	.3772
Max	.7023	.7167	.5544	.8871	.8413
Min	.3696	.415	.4066	.3361	.3772
Avg	.5325	.5919	.4533	.5161	.6347

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 201 / 11 KV STATION T/F

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0549	.0566	.0566	.0549
2	.0566	.0549	.0566	.0566	.0549
3	.0566	.0549	.0566	.0566	.0549
4	.0566	.0549	.0566	.0566	.0549
5	.0566	.0549	.6224	.0566	.0549
6	.0566	.0549	.0566	.0566	.0549
7	.0566	.0549	.0566	.0566	.0549
8	.0549	.0566	.0566	.0549	.0566
9	.0549	.0566	.0566	.0549	.0566
10	.0549	.0566	.0566	.0549	.0566
11	.0549	.0566	.0566	.0549	.0566
12	.0549	.0566	.0566	.0549	
13	.0549	.0566	.0566	.0549	
14	.0549	.0566	.0566	.0549	
15	.0549	.0566	.0566	.0549	
16	.0549	.0566	.0566	.0549	
17	.0549	.0566	.0566	.0549	
18	.0549	.0566	.0566	.0549	
19	.0549	.0566	.0566	.0549	
20	.0549	.0566	.0566	.0549	
21	.0549	.0566	.0566	.0549	
22	.0549	.0566	.0566	.0549	
23	.0549	.0566	.0566	.0549	
24	.0566	.0549	.0566	.0566	.0549
Max	.0566	.0566	.6224	.0566	.0566
Min	.0549	.0549	.0566	.0549	.0549
Avg	.0555	.0560	.0802	.0555	.0555

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 203 / 11 KV JUI GAON

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8107	1.7558	1.8673	1.8484	1.6827
2	1.7353	1.6827	1.7918	1.7918	1.6461
3	1.6975	1.6827	1.773	1.773	1.6461
4	1.6975	1.6644	1.773	1.773	1.6461
5	1.7353	1.6461	1.8107	1.8107	1.6644
6	2.1502	1.8107	1.8484	2.2634	1.8107
7	2.452	2.1948	1.8861	2.3765	2.5972
8	2.524	2.7538	2.32	2.5972	2.7161
9	2.4691	2.7161	2.9047	2.5972	2.5274
10	2.4508	2.5274	2.8292	2.5606	2.4143
11	2.4326	2.4143	2.8669	2.4874	2.6217
12	2.0851	2.2634	2.6029	2.4326	
13	2.1216	2.2634	2.4143	2.1948	
14		1.9616	1.9805	2.0302	
15	1.8473	2.2822	2.3011	1.957	
16	1.8656	1.9616	1.9239	1.9387	
17	1.957	2.32	2.4143	1.829	
18	2.524	2.6029	2.4143	2.2131	
19	2.5972	2.7349	2.7538	2.4326	
20	2.6155	2.7726	2.7161	2.5423	
21	2.5972	3.0933	2.7161	2.5972	
22	2.4143	2.4143	2.4897	2.4143	
23	2.268	2.32	2.2257	2.3045	
24	1.8861	1.8656	1.9239	2.037	1.957
Max	2.6155	3.0933	2.9047	2.5972	2.7161
Min	1.6975	1.6461	1.773	1.773	1.6461
Avg	2.1710	2.2377	2.2728	2.2001	2.0775

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 204 / 11 KV SURAJ PARK FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.358	1.2803	1.3957	1.4335	1.3169
2	1.3203	1.2986	1.3769	1.3957	1.2803
3	1.3203	1.2986	1.358	1.358	1.2803
4	1.358	1.2986	1.3392	1.3769	1.2986
5	1.3769	1.3169	1.358	1.4146	1.2803
6	1.5844	1.39	1.3957	1.6598	1.4998
7	1.9993	1.829	1.6032	1.9805	1.957
8	2.1948	2.3954	2.1313	2.3411	1.9616
9	1.7193	1.9794	2.1502	2.1216	1.8107
10	1.6461	1.8107	2.0748	1.9936	1.5844
11	1.5729	1.5844	1.9993	1.8656	1.6221
12	1.5181	1.5089	1.9239	1.701	
13	1.4632	1.4712	1.7353	1.5364	
14	1.262	1.2826	1.5466	1.4266	
15	1.2254	1.4146	1.5089	1.4449	
16	1.262	1.358	1.4335	1.39	
17	1.2803	1.5278	1.5466	1.39	
18	1.7558	1.8107	1.8107	1.7924	
19	2.0119	2.0748	1.9616	1.8839	
20	1.9936	2.1125	2.037	1.9387	
21	1.957	2.0182	2.037	1.9387	
22	1.829	1.8296	1.8861	1.8107	
23	1.6095	1.7353	1.6975	1.5364	
24	1.3957	1.39	1.4335	1.5089	1.3535
Max	2.1948	2.3954	2.1502	2.3411	1.9616
Min	1.2254	1.2803	1.3392	1.358	1.2803
Avg	1.5839	1.6257	1.6975	1.6766	1.5205

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 205 / 11 KV AWAS FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3957	1.3169	1.4146	1.4901	1.4998
2	1.358	1.2803	1.3769	1.4712	1.4998
3	1.3203	1.2803	1.358	1.4335	1.4632
4	1.3203	1.2986	1.358	1.4146	1.39
5	1.3769	1.2986	1.3957	1.4712	1.4266
6	1.6598	1.39	1.4335	1.7541	1.6461
7	2.0748	1.7375	1.5466	1.9616	2.1033
8	2.1033	2.3011	2.037	2.1765	1.9239
9	1.7558	1.9239	2.1125	2.0485	1.7918
10	1.5729	1.7918	2.1125	1.957	1.6032
11	1.5181	1.6032	2.037	1.7558	1.6221
12	1.4632	1.5466	1.773	1.5912	
13	1.4449	1.3957	1.773	1.5364	
14	1.3535	1.358	1.6032	1.4266	
15	1.2803	1.4146	1.5089	1.4266	
16	1.2803	1.4901		1.4632	
17	1.3169	1.7164	1.6598	1.4998	
18	1.957	2.0182	2.1125	2.0119	
19	2.1948	2.2822	2.3577	2.1582	
20	2.1765	2.32	2.3388	2.1399	
21	2.1399	2.3223	2.3011	2.1216	
22	2.0119	2.0182	2.1125	1.9387	
23	1.6827	1.905	1.8484	1.6827	
24	1.4712	1.3169	1.4523	1.6598	1.5912
Max	2.1948	2.3223	2.3577	2.1765	2.1033
Min	1.2803	1.2803	1.358	1.4146	1.39
Avg	1.6345	1.6803	1.7836	1.7329	1.6301



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 206 / 11 KV KAMOTHE VILLAGE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7353	1.6827	1.7541	1.8107	1.4998
2	1.6975	1.6461	1.6221	1.7353	1.4998
3	1.6598	1.6461	1.6221	1.6975	1.4632
4	1.6598	1.6278	1.6598	1.6598	1.4632
5	1.6975	1.6461	1.6975	1.7353	1.4815
6	1.9616	1.7558	1.7164	2.0748	1.7558
7	2.2822	2.0851	1.905	2.2634	2.3777
8	2.4143	2.6029	2.2822	2.524	2.1125
9	2.1216	2.1125	2.452	2.3777	1.9239
10	2.1216	1.9239	2.2634	2.2131	1.7918
11	1.6461	1.773	2.1691	1.829	1.8673
12	1.5729	1.5844	1.9805	1.6461	
13	1.4998	1.5466	1.9239	1.5729	
14	1.3535	1.358	1.773	1.4998	
15	1.3169	1.5466	1.7164	1.4998	
16	1.3169	1.6032	1.6975	1.5364	
17	1.3535	1.9239	1.8107	1.5912	
18	2.2497	2.32	2.4143	2.2131	
19	2.3777	2.6783	2.6783	2.4143	
20	2.4143	2.6029	2.6406	2.4326	
21	2.3777	2.5274	2.5463	2.4326	
22	2.2497	2.3577	2.4331	2.3045	
23	2.0485	2.2068	2.1879	2.0119	
24	1.773	1.7558	1.8107	1.9239	1.5364
Max	2.4143	2.6783	2.6783	2.524	2.3777
Min	1.3169	1.358	1.6221	1.4998	1.4632
Avg	1.8709	1.9381	2.0315	1.9583	1.7311

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 208 / 11 KV O/G SPARE-8

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0732	.0754	.0754	.0732
2	.0754	.0732	.0754	.0754	.0732
3	.0754	.0732	.0754	.0566	.0503
4	.0566	.0732	.0754	.0754	.0732
5	.0754	.0732	.0754	.0754	.0732
6	.0754	.0732	.0754	.0566	.0732
7	.0754	.0732	.0754	.0754	.0732
8	.0732	.132	.0754	.0549	
9	.128	.1509	.0566	.128	
10	.128	.1509	.132	.128	
11	.128	.1509	.1132	.128	
12	.128	.1509	.1509	.128	
13	.128	.1509	.132	.128	
14	.128	.1509	.1509	.128	
15	.128	.132	.132	.128	
16	.128	.132	.132	.0128	
17	.128	.0754	.0754	.1463	
18	.1463	.1509	.1698	.1463	
19	.1463	.1509	.1509	.1463	
20	.1463	.1509	.1509	.1646	
21	.1463	.1509	.1509	.1646	
22	.1463	.1698	.1509	.1646	
23	.0732	.0754	.0754	.0914	
24	.0754	.0732	.0754	.0754	.0914
Max	.1463	.1698	.1698	.1646	.0914
Min	.0566	.0732	.0566	.0128	.0503
Avg	.1089	.1171	.1084	.1064	.0726

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 210 / SPARE OUTGOING

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	12-DEC-17
HR	Load (MW)
8	.1006
Max	.1006
Min	.1006
Avg	.1006

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 211 / BHAGWATI HEIGHTS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6979	2.1582	.7167	.7356	1.8473
2	.6602	2.1033	.7167	.7167	1.7558
3	.6413	2.1033	.6979	.6979	1.7558
4	.6413	2.1033	.6979	.6979	1.8107
5	.6413	2.1216	.6979	.6979	1.7558
6	.8299	2.3045	.7356	.8299	2.0485
7	.9997	2.6703	.7733	1.0374	2.7435
8	1.0059	2.8104	.9431	1.1157	2.8104
9	.9511	2.7915	1.1317	1.0608	2.7915
10	.9877	2.7161	1.0751	.9877	2.7161
11	2.5972	2.8104	1.0562	.9328	2.3577
12	2.524	.9242	.9997	.9145	
13	2.0485	.9054	.9808	.7682	
14	2.0119	.8299	.8865	.6584	
15	1.9936	.7733	.9054	.6584	
16	2.0119	.7733	.7733	.695	
17	2.1765	.9997	.9054	2.2131	
18	3.0178	1.094	1.1128	2.5972	
19	3.219	1.226	1.2637	2.7984	
20	3.2922	1.2071	1.2826	2.7435	
21	3.219	1.1694	1.2071	2.7435	
22	2.8532	1.0751	1.0751	2.5789	
23	2.5057	.9431	.9242	2.1216	
24	.7356	2.1948	.7356	.8299	1.9387
Max	3.2922	2.8104	1.2826	2.7984	2.8104
Min	.6413	.7733	.6979	.6584	1.7558
Avg	1.7609	1.7003	.9289	1.3263	2.1943

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 212 / SHIVSENA OFFICE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7733	.8048	.7733	.8488	.8413
2	.7545	.7682	.7545	.8299	.8048
3	.7167	.7682	.7545	.7922	.7682
4	.7167	.7865	.7733	.7733	.8048
5	.7356	.7682	.7545	.7922	
6	.9619	.8048	.8299	1.0185	.8596
7	1.226	.9328	.8488	1.1506	1.2071
8	1.3352	.9808	1.094	1.2803	.9808
9		.9431	1.226	1.2254	.9431
10	1.1888	.9242	1.4335	1.1706	.9242
11	1.134	.9054	1.3957	1.1157	1.1883
12	1.0242	.9619	1.3014	1.1157	
13	.9145	.9431	1.1883	1.0242	
14	.9145	.9997	1.0185	.9694	
15	.8962	.9619	1.0562	.9877	
16	.9145	.9997	.9808	.9145	
17	.9511		.9619	.8048	
18	1.0242		1.0185	.9877	
19	1.0608		1.1128	1.0425	
20	1.0608		1.1317	1.0059	
21	1.0242		1.1128	.9877	
22	.9694		1.0751	.9511	
23	.9145	1.0374	.9431	.8779	
24	.811	.8596	.811	.9242	.9145
Max	1.3352	1.0374	1.4335	1.2803	1.2071
Min	.7167	.7682	.7545	.7733	.7682
Avg	.9575	.8972	1.0146	.9830	.9306

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 301 / 22 KV OUTGOING FEEDER

SHEDDABLE URBAN

SPARE Feeder KV- 22 /

OUTGOING

DATE	11-DEC-17
HR	Load (MW)
19	.2926
Max	.2926
Min	.2926
Avg	.2926

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 302 / 22 KV Venkatesh Feeder

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	1.0974	1.094	1.2071	1.0974
2	1.1694		1.1317	1.1694	1.0974
3	1.1317	1.0608	1.1317	1.1317	1.134
4	1.1694	1.134	1.1317	1.1317	1.0974
5	1.1694	1.0974	1.094	1.1694	1.0608
6	1.2826	1.2437	1.1317	1.358	1.2437
7	1.5844	1.39	1.094	1.5844	1.5729
8	1.6827	1.8107	1.5466	1.7558	1.6975
9	1.5364	1.5466	1.6598	1.6827	1.4712
10	1.4266	1.5089	1.6975	1.4266	1.4335
11	1.3169		1.6598	1.3169	1.3957
12	1.1706	1.2071	1.5089	1.2437	
13	1.0974	1.2449	1.4335	1.1706	
14	1.0974	1.094	1.2071	1.134	
15	1.0242	1.1694	1.2071	1.0974	
16	1.0608	1.094	1.1694	1.0608	
17	1.0974	1.4712	1.2071	.9877	
18	1.3535	1.3957	1.4335	1.4632	
19	1.4632		1.5844	1.5364	
20	1.5364	1.6598	1.5844	1.5364	
21		1.6598	1.5844	1.5364	
22	1.4266	1.4335	1.4335	1.4632	
23	1.3535	1.3957	1.3957	1.2437	
24	1.1694	1.134	1.1694	1.2449	1.1706
Max	1.6827	1.8107	1.6975	1.7558	1.6975
Min	1.0242	1.0608	1.094	.9877	1.0608
Avg	1.2805	1.3261	1.3455	1.3188	1.2893

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 303 / 22 KV JAWAHAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5844	1.6827	1.5466	1.9239	1.5364
2	1.5466	1.5364	1.5089	1.8107	1.4632
3	1.5844	1.5364	1.5089	1.7353	1.4632
4	1.5844	1.5364	1.5466	1.8107	1.4632
5	1.5844	1.5364	1.5089	1.8861	1.4998
6	1.6598	1.5729	1.5466	1.6975	1.5364
7	1.8861	1.6095	1.8484	1.9993	1.6827
8	2.0119	1.9239	1.8484	1.8656	1.8107
9	2.1948	2.5652	2.3011	2.4508	1.6598
10	3.0727	2.9424	2.3388	3.0727	1.7353
11	2.963	3.0178	2.7161	3.1824	1.7353
12	3.0727	3.2442	2.4143	3.1459	
13	3.0727	2.8669	2.3765	3.0727	
14	3.1824	2.7915	2.7915	2.8532	
15	3.2922	3.2442	2.6406	2.8532	
16	3.1824	3.2065	2.3388	2.8898	
17	3.0727	2.7538	2.1879	2.8898	
18	2.524	2.6029	2.1879	2.5606	
19	2.1948	2.1879	2.1125	2.2314	
20	2.0485	2.037	2.037	2.1948	
21	1.9753	1.9239	1.8861	2.1216	
22	1.829	1.8861	1.8107	2.0485	
23	1.7558	1.8861	2.2634	1.8656	
24	1.5844	1.9387	1.5844	1.7353	1.6095
Max	3.2922	3.2442	2.7915	3.1824	1.8107
Min	1.5466	1.5364	1.5089	1.6975	1.4632
Avg	2.2691	2.2512	2.0355	2.3291	1.5996



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224001 / 33/11 KV Sec-27 Kharghar S/S

Feeder No / Name : 201 / 11 kv pl no.39, sec-27 SHEDDABLE URBAN  
feeder Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0171	.0171
2				.0171	
3		.0171			
4				.0171	.0171
6			.0171	.0171	.0171
7		.0171	.0171	.0171	.0171
8		.0171	.0171	.0171	.0171
9	.0171	.0171	.0171	.0171	.0171
10			.0171	.0171	
11	.0171	.0137	.0171		.0171
12	.0171	.0171	.0171	.0171	.0171
13	.0171	.0171	.0171	.0171	.0171
14	.0171	.0171	.0171	.0171	.0171
15	.0171	.0171	.0171	.0171	.0171
16	.0171	.0171	.0171	.0171	.0171
17		.0171	.0171	.0171	.0171
18	.0171	.0171	.0171	.0171	.0171
19	.0171	.0171	.0171	.0171	.0171
20	.0171	.0171	.0171	.0171	.0171
21	.0171	.0171	.0171	.0905	.0171
22	.0171	.0171	.0171	.0171	.0171
23	.0171		.0171	.0905	.0171
24		.0171		.0171	.0171
Max	.0171	.0171	.0171	.0905	.0171
Min	.0171	.0137	.0171	.0171	.0171
Avg	.0171	.0169	.0171	.0241	.0171

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224001 / 33/11 KV Sec-27 Kharghar S/S

Feeder No / Name : 207 / 11 kv Juhi developers SHEDDABLE URBAN  
 feeder Feeder KV- 11 /  
 OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.6687	.6344
3		.7202		.6344	
4					.7373
5				.7202	
6		.703	.5487		.583
7			.5144	.703	.7888
8		.8402	.5658	.7202	.6516
9		.8573	.7545		.6173
10	.6859	.8059	.7373	.6859	
11	.7202	.7545	.8402	.7373	.7202
12	.6516	.6706	.8916	.703	.6859
13	.0171	.703	.8745	.6516	.6344
14	.583	.703	.823	.6344	.583
15	.6516	.6859	.7373	.6344	.5144
16	.583	.6859	.8402	.5316	.5487
17	.7202	.7888	.823	.6344	.6687
18	.8402	.8916	.6859	.8059	.7716
19	.8573	.8916	.6859	.7373	.8916
20	.703	.8745	.7202	.8059	.7888
21	.7202	.7202	.7373	.7373	.703
22	.6687	.7373	.6173	.6344	.6859
23	.8573		.6687	.6516	.6687
24		.6687		.6173	.583
Max	.8573	.8916	.8916	.8059	.8916
Min	.0171	.6687	.5144	.5316	.5144
Avg	.6614	.7612	.7259	.6824	.6730

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224001 / 33/11 KV Sec-27 Kharghar S/S

Feeder No / Name : 208 / 11KV Station Transformer SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0171	.0171
3				.0171	.0171
5		.0171		.0171	
6			.0171	.0171	.0171
7			.0171	.0171	.0171
8		.0171	.0171	.0171	.0171
9		.0171	.0171	.0171	.0171
10	.0171		.0171	.0171	
11	.0171	.0171	.0171	.0171	.0171
12	.0171	.0171	.0171	.0171	.0171
13	.0171	.0171	.0171	.0171	.0171
14	.0171	.0171	.0171	.0171	.0171
15	.0171	.0171	.0171	.0171	.0171
16	.0171	.0171	.0171	.0171	.0171
17	.0171	.0171	.0171	.0171	
18	.0171	.0171	.0171	.0171	.0171
19	.0171	.0171	.0171	.0171	.0171
20	.0171	.0171	.0171	.0171	.0171
21	.0171	.0171	.0171	.0171	.0171
22	.0171	.0171	.0171	.0171	.0171
23	.0171		.0171	.0171	.0171
24		.0171		.0171	.0171
Max	.0171	.0171	.0171	.0171	.0171
Min	.0171	.0171	.0171	.0171	.0171
Avg	.0171	.0171	.0171	.0171	.0171

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224001 / 33/11 KV Sec-27 Kharghar S/S

Feeder No / Name : 212 / 11 kv Ramsheth thakur SHEDDABLE URBAN  
 feeder Feeder KV- 11 /  
 OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0171	.0171
3				.0171	
4		.0171			.0171
5				.0171	
6			.0171	.0171	.0171
7			.0171	.0171	.0171
8			.0171	.0171	.0171
9		.0171	.0171	.0171	.0171
10	.0171		.0171	.0171	
11	.0171	.0171	.0171	.0171	.0171
12	.0171	.0171	.0171	.0171	.0171
13	.0171	.0171	.0171	.0171	.0171
14	.0171	.0171	.0171	.0171	.0171
15	.0171	.0171	.0171	.0171	.0171
16	.0171	.0171	.0171	.0171	.0171
17	.0171	.0171	.0171	.0171	.0171
18	.0171	.0171	.0171	.0171	.0171
19	.0171	.0171	.0171	.0171	.0171
20	.0171	.0171	.0171	.0171	.0171
21	.0171	.0171	.0171	.0171	.0171
22	.0171	.0171	.0171	.0171	.0171
23			.0171	.0171	.0171
24		.0171		.0171	.0171
Max	.0171	.0171	.0171	.0171	.0171
Min	.0171	.0171	.0171	.0171	.0171
Avg	.0171	.0171	.0171	.0171	.0171

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224001 / 33/11 KV Sec-27 Kharghar S/S

Feeder No / Name : 402 / 33KV Incomer No-II

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0514	.823
3				.5658	
4					.8745
5				.6173	
6		.8745	.6687	.0514	.8745
7		.8745	.5658	.6687	.823
8		.823	.5658	.823	.823
9		.823	.7202	.823	.823
10	.823		.7716	.8745	
11	.8745	.7202	.9259	.8745	.8745
12	.823	.7716	.8745	.823	.823
13	.823	.7202	.8745	.823	.6687
14	.823	.6401	.7716	.823	.6173
15	.823	.6687	.823	.823	.6173
16	.8745	.6687	.9259	.8745	.5658
17	.8745	.823	.9259	.823	.6687
18	.8745	.8745	.7716	.8745	
19	.8745	.9259	.7202	.823	.9259
20	.823	.823	.8745	.8745	.8745
21	.823	.7202	.8745	.8745	.6687
22	.9259	.7202	.7202	.823	.823
23			.7202	.823	.6687
24		.9259		.6687	.8745
Max	.9259	.9259	.9259	.8745	.9259
Min	.823	.6401	.5658	.0514	.5658
Avg	.8507	.7881	.7830	.7318	.7743

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224008 / 33 /11 KV KHARGHAR SEC-12

S/ST

Feeder No / Name : 201 / 11 KV RAIL VIHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)
1	1.4937	1.3256
3	1.2883	
4	1.3443	
5	1.4003	
6	1.7551	
7	1.8671	
8	1.8671	
24	1.587	1.419
Max	1.8671	1.419
Min	1.2883	1.3256
Avg	1.5754	1.3723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224008 / 33 /11 KV KHARGHAR SEC-12

S/ST

Feeder No / Name : 204 / 11KV LINK LINE FEEDER

SHEDDABLE URBAN

(Vighnah Feeder KV- 11 /

OUTGOING

DATE	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)
1	1.4937	1.3256
2	1.419	
3	1.2883	
4	1.3443	
5	1.3443	
6	1.7551	
7	1.8671	
8	1.8671	
24	1.587	1.419
Max	1.8671	1.419
Min	1.2883	1.3256
Avg	1.5518	1.3723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224008 / 33 /11 KV KHARGHAR SEC-12

S/ST

Feeder No / Name : 207 / 11 KV MILLANIUM PARK  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)
1	1.0317	.9412
2	.9955	
3	.9774	
4	.9774	
5	.9955	
6	1.2308	
7	1.4842	
8	1.5181	
24	1.2308	1.0498
Max	1.5181	1.0498
Min	.9774	.9412
Avg	1.1602	.9955



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224008 / 33 /11 KV KHARGHAR SEC-12

S/ST

Feeder No / Name : 208 / SUB STATION T/F

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)
1	.0236	.0248
2	.0248	
3	.0248	
4	.0248	
6	.0236	
7	***	
8	.0124	
24	.0236	.024
Max	19.3012	.0248
Min	.0124	.024
Avg	2.4324	.0244

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 201 / Spare Link feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.086		1.086		1.086
2	.9955	1.086		1.086	
3	.905		.905		.9955
4	.905	.905		1.086	
5	.9955		.905		1.086
6		1.086		1.267	
7	1.6289		1.086		
8	1.6289	1.448		1.6289	
9	1.6289		1.448		1.448
10	1.6289	1.6289		1.6289	1.448
11	1.6289		1.8099		1.6289
12	1.448	1.448		1.6289	
13	1.448		1.448		1.267
14	1.267	1.267		1.448	
15	1.267		1.3575		1.267
16	1.267	1.3575	1.448	1.448	1.267
17	1.267	1.448	1.448		1.1765
18	1.448	1.6289	1.6289	1.448	1.6289
19	1.6289	1.8099	1.8099	1.6289	1.8099
20	1.6289	1.8099	1.8099	1.7194	1.6289
21	1.6289	1.8099	1.8099	1.7194	1.7194
22	1.6289	1.6289	1.8099	1.5384	1.5384
23	1.448	1.5384	1.448	1.448	1.448
24	1.1765	1.267	1.267	1.448	1.267
Max	1.6289	1.8099	1.8099	1.7194	1.8099
Min	.905	.905	.905	1.086	.9955
Avg	1.3732	1.4480	1.4426	1.4781	1.3947

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 202 / 11 KV PUMP HOUSE SEC 11

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.543		.543		.543
2	.4525	.543		.543	
3	.362		.4525		.4525
4	.362	.543		.543	
5	.543		.543		.543
6	.724	.543		.724	
7	.724		.724		.8145
8	.724	.724		1.086	
9	1.3575		.905		1.086
10	1.267	.905		1.086	
11	1.086		.724		.905
12	.905	.8145		1.086	
13	.905		.724		.905
14	.905	.8145		1.086	
15	.905		.724		.8145
16	.905	.543	.905	.905	.724
17	.905	.724	.905	.9955	.724
18	1.086	1.086	1.086	.9955	1.086
19	1.086	1.086	1.086	.905	.905
20	.905	.724	1.086	.724	.905
21	.905	.724	.905	.724	.724
22	.724	.724	.724	.724	.724
23	.724	.724	.724	.724	.724
24	.6335	.724	.543	.724	.6335
Max	1.3575	1.086	1.086	1.086	1.086
Min	.362	.543	.4525	.543	.4525
Avg	.8183	.7466	.7826	.8484	.7772

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 203 / 11 KV MURBI SECTOR-19

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6335		.724		.724
2	.543	.543		.543	
3	.543		.6335		.543
4	.543	.543		.543	
5	.543		.6335		.6335
6	.8145	.6335		.905	
7	1.267		.724		1.086
8	1.086	.9955		1.086	
9	.9955		.9955		1.086
10	.9955	1.086		1.086	
11	.9955		1.086		.9955
12	.8145	.9955		1.086	
13	.8145		1.086		1.0136
14	.905	.905		.905	
15	.724		.8145		.724
16	.724	.8145	.8145	.724	.8145
17	.724	.8145	.905	.8145	.724
18	.8145	.905	.905	.8145	.905
19	.905	.9955	.9955	.905	.9955
20	.9955	.9955	.9955	.9955	.9955
21	.9955	.9955	.9955	.9955	.9955
22	.9955	.905	.905	.905	.905
23	.905	.905	.905	.905	.8145
24	.724	.724	.8145	.8145	.8145
Max	1.267	1.086	1.086	1.086	1.086
Min	.543	.543	.6335	.543	.543
Avg	.8334	.8598	.8784	.8767	.8688

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 206 / 11 KV AWHO SECTOR-14

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1765		1.086		.905
2	1.086	.905		.8145	
3	.905		.905		.8145
4	.905	.724		.905	
5	.9955		.9955		.905
6	1.086	.8145		1.267	
7	1.448		1.086		1.267
8	1.267	1.1765		1.6289	
9	1.448		1.5384		1.448
10	1.448	1.448		1.5384	
11	1.448		1.8099		1.448
12	1.448	1.448		1.448	
13	1.267		1.6289		1.3575
14	1.3575	1.448		1.3575	
15	1.267		1.448		.724
16	1.1765	1.448	1.448	1.267	1.1765
17	1.267	1.448	1.6289	1.5384	1.267
18	1.5384	1.6289	1.7194	1.6289	1.5384
19	1.6289	1.7194	1.8099	1.7194	1.6289
20	1.6289	1.7194	1.8099	1.7194	1.6289
21	1.6289	1.7194	1.8099	1.6289	1.6289
22	1.6289	1.6289	1.6289	1.5384	1.448
23	1.267	1.448	1.3575	1.267	1.267
24	1.267	1.1765	1.1765	1.1765	1.086
Max	1.6289	1.7194	1.8099	1.7194	1.6289
Min	.905	.724	.905	.8145	.724
Avg	1.316	1.3688	1.4639	1.4027	1.2670

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 207 / VISHWAJYOTH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724		.6335		.6335
2	.6335	.543		.4525	
3	.6335		.543		.543
4	.6335	.543		.4525	
5	.724		.543		.6335
6	.724	.543		.8145	
7	.9955		.724		.905
8	.905	.8145		.9955	
9	.905		.905		.905
10	.905	.905		.9955	
11	.905		1.086		.905
12	.8145	.905		.905	
13	.8145		.9955		.724
14	.724	.905		.8145	
15	.724		.8145		.724
16	.724	.724	.905	.724	.6335
17	.724	.724	.905	.905	.724
18	.905	.9955	.905	.905	.8145
19	.9955	.9955	.905	.905	.905
20	.9955	.905	.905	.905	.905
21	.9955	.905	.905	.905	.905
22	.905	.905	.905	.905	.8145
23	.8145	.8145	.8145	.8145	.8145
24	.724	.8145	.724	.8145	.724
Max	.9955	.9955	1.086	.9955	.905
Min	.6335	.543	.543	.4525	.543
Avg	.8145	.8088	.8305	.8258	.7772

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 208 / 11 KV JALVAYU SECTOR-20

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8145		.8145		.8145
2	.8145	.724		.905	
3	.724		.724		.724
4	.724	.724		.905	
5	.724		.724		.8145
6	.905	.8145		1.267	
7	1.3575		1.086		.9955
8	1.1765	1.267		1.448	
9	1.267		1.267		1.086
10	1.267	1.267		1.448	
11	1.086				1.086
12	1.086	1.086		1.267	
13	1.086		1.448		.905
14	.905	1.086		1.086	
15	.905		1.086		.905
16	.905	1.086	1.086	1.086	.905
17	.905	1.086	1.267	1.086	.9955
18	1.086	1.267	1.267	1.086	1.086
19	1.267	1.267	1.448	1.267	1.267
20	1.267	1.267	1.448	1.3575	1.267
21	1.267	1.267	1.448	1.3575	1.086
22	1.267	1.1765	1.448	1.267	1.086
23	1.086	1.086	1.086	.9955	.9955
24	.905	.905	.905	1.086	.8145
Max	1.3575	1.267	1.448	1.448	1.267
Min	.724	.724	.724	.905	.724
Avg	1.0332	1.086	1.1595	1.1822	.9902

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 209 / 11 kV \sector 18

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724		.724		.6335
2	.724	.6335		.543	
3	.6335		.543		.543
4	.6335	.543		.6335	
5	.6335		.543		.724
6	.905	.724		.905	
7	1.1765		.905		.9955
8	1.086	.9955		1.1765	
9	1.086		.9955		1.086
10	1.086	.9955		1.086	
11	.9955		1.086		.9955
12	.9955	.905		.9955	
13	.8145		.9955		.8145
14	.724	.8145		.8145	
15	.8145		.8145		.6335
16	.724	.724	.905	.724	.724
17	.724	.724	.905	.905	.724
18	.905	.9955	1.086	.905	.905
19	.9955	.9955	1.086	.905	.905
20	.9955	.9955	.9955	.905	.9955
21	1.086	.9955	1.086	.905	.9955
22	1.086	.905	1.086	.905	.905
23	.9955	.9955	.9955	.905	.905
24	.8145	.905	.8145	.905	.8145
Max	1.1765	.9955	1.086	1.1765	1.086
Min	.6335	.543	.543	.543	.543
Avg	.8899	.8654	.9156	.8824	.8411



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 210 / 11 kV \ Vastuvihar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905		.0905		.0905
2	.0905	.0905		.0905	
3	.0905		.0905		.0905
4	.0905	.0905		.0905	
5	.0905		.0905		.0905
6	.0905	.0905		.0905	
7	.0905		.0905		.0905
8	.0905	.0905		.0905	
9	.0905		.0905		.0905
10	.0905	.0905		.0905	
11	.0905		.0905		.0905
12	.0905	.0905		.0905	
13	.0905		.0905		.0905
14	.0905	.0905		.0905	
15	.0905		.0905		.0905
16	.0905	.0905	.0905	.0905	.0905
17	.0905	.0905	.0905	.0905	.0905
18	.0905	.0905	.0905	.0905	
19	.0905	.0905	.0905	.0905	.0905
20	.0905	.0905	.0905	.0905	.0905
21	.0905	.0905	.0905	.0905	.0905
22	.0905	.0905	.0905	.0905	.0905
23	.0905	.0905	.0905	.0905	.0905
24	.0905	.0905	.0905	.0905	.0905
Max	.0905	.0905	.0905	.0905	.0905
Min	.0905	.0905	.0905	.0905	.0905
Avg	.0905	.0905	.0905	.0905	.0905

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 211 / 11 kv Sector 27

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181		.181		.181
2	.181	.181		.181	
3	.181		.181		.181
4	.181	.181		.181	
5	.181		.181		.181
6	.181	.181		.181	
7	.362		.1753		.181
8	.362	.2715		.2715	
9	.2715				.181
10	.2715	.2743		.2715	
11	.181		.181		.2715
12	.181	.181		.2715	
13	.2715		.181		.181
14	.2715	.181		.2715	
15	.181		.181		.181
16	.2715	.181	.2715	.181	.181
17	.2715	.181	.2715	.181	.181
18	.362	.181	.362	.181	.181
19	.362	.181	.362	.181	.181
20	.2715	.181	.2715	.181	.2715
21	.2715	.181	.2715		.2715
22	.2715	.181	.2715	.181	.181
23	.2715	.181	.2715		.181
24	.181	.2715	.181	.181	.181
Max	.362	.2743	.362	.2715	.2715
Min	.181	.181	.1753	.181	.181
Avg	.2489	.1981	.2372	.2069	.1970

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 212 / Sector-30 Owe village

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	11-DEC-17
HR	Load (MW)
17	.181
Max	.181
Min	.181
Avg	.181

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 201 / 11 kv CIDCO Sewrage Pump SHEDDABLE URBAN  
Secto Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0456	1.307	1.1203	1.1949	1.0829
2	.9709	1.2696	1.0829		1.0456
3	.9335	1.2323	1.0829	1.1576	1.0082
4	.9335	1.2136	1.0456	1.0829	1.0082
5		1.1949	1.0642		1.0082
6		1.2323	1.0456		1.1576
7		1.2323	1.1576		1.4377
8	1.251	1.2696	1.251	1.2323	1.2696
9	1.4003	1.5123	1.363	1.531	1.4377
10	1.3443	1.419	1.4003	1.8111	1.587
11	1.4563	1.5123	1.4563	1.8298	1.7737
12	1.6057	1.9791	1.6244	1.6057	1.9231
13	1.7924	2.0165	1.7551	1.9605	1.8671
14	1.7177	1.9605		1.8111	1.7737
15	1.5684	1.8111		1.7737	1.6804
16	1.419	1.7364	1.5497	1.8858	1.587
17	1.4003	1.7924	1.1763	1.4377	1.4937
18	1.643	1.6991	1.4377	1.531	1.6057
19	1.587	1.6057	1.8484	1.9044	1.9044
20	1.7177	1.9044	1.7737	1.7177	1.7737
21	1.8111	1.7177	1.7177	1.6991	1.475
22	1.475	1.587	1.587	1.475	1.1763
23	1.419	1.3817	1.419	1.2323	
24	1.1016	1.3443	1.2136	1.2696	1.1203
Max	1.8111	2.0165	1.8484	1.9605	1.9231
Min	.9335	1.1949	1.0456	1.0829	1.0082
Avg	1.4092	1.5388	1.3715	1.5572	1.4433

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 202 / 11 KV CIDCO S/STN SEC-10 SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.5601	.5601	.5601	.5228
2	.5601	.5228	.4854	.5601	.5041
3	.5228	.5228	.4854	.5601	.4854
4	.5228	.5601	.4668	.5228	.4668
5		.5975	.4668		.4668
6		.5975	.4668		.6722
7		.6348	.5975		.7468
8	.7468	.6722	.5975	.7468	.7468
9	.7282	.6535	.6722	.6348	.6722
10	.6722	.6722	.6348	.6908	.6348
11	.5975	.6535	.6722	.6348	.5601
12	.5601	.6348	.6535	.5601	.4854
13	.5228	.5975	.6161	.5228	.4854
14	.5228	.5228		.5041	.4854
15	.4854	.5041		.4854	.4668
16	.4668	.5228	.5601	.4481	.4668
17	.4481	.5228	.6161	.5228	.4854
18	.5975	.7282	.7095	.6348	.6348
19	.7095	.7468	.7655	.7095	.6535
20	.6908	.6535	.6908	.6722	.6535
21	.6535	.6722	.6908	.6535	.6348
22	.6535	.6722		.6348	.6161
23	.5975	.6722	.6535	.6348	
24	.5601	.5601	.5788	.5975	.5601
Max	.7468	.7468	.7655	.7468	.7468
Min	.4481	.5041	.4668	.4481	.4668
Avg	.5895	.6107	.6019	.5948	.5699

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 203 / 11KV CIDCO Sec-2 Kharghar SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7842	1.1203	.6722	.7842	.6722
2		1.0269	.6348	.7842	.6348
3	.7468	.9335	.6348	.7468	.6161
4	.6348	.8402		.7468	.6348
5		.7468	.6161		.6161
6		.7468	.6348		.7468
7		.7468	.5788		
8	.7842	.7282	.6535	.7468	
9	.7842	.7842	.7282	.8775	.8215
10	1.0269	1.0456	1.0082	1.1389	.9335
11	1.2136	1.3256	1.419	1.3443	1.1203
12	1.307	1.475	1.4937	1.419	1.2323
13	1.3817	1.4377	1.4937	1.4563	1.2323
14	1.3443	1.4563		1.363	1.2323
15	1.2696	1.4563		1.1763	1.2323
16	1.1763	1.3443	1.3817	1.251	1.251
17	1.2883	1.3256	1.3256	1.307	1.251
18	1.4937	1.587	1.531	1.419	1.3817
19	1.475	1.587	1.6244	1.419	1.3817
20	1.4563	1.475	1.531	1.5123	1.3443
21	1.3817	1.4937	1.5123	1.3817	1.3443
22	1.2696	1.4003	1.3443	1.1949	1.1576
23	1.2323	1.1576	1.1389	1.1203	
24	.8402	1.1949	.7655	.8402	.7842
Max	1.4937	1.587	1.6244	1.5123	1.3817
Min	.6348	.7282	.5788	.7468	.6161
Avg	1.1445	1.1848	1.0820	1.1443	1.0296

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 204 / 11 KV Prajapati S/stn Sec- SHEDDABLE URBAN  
2 kh Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8402	1.0082	.8962	.8775	.8215
2	.7842	.9709	.8589	.8402	.8215
3	.7842	.9709	.8215	.7842	.8029
4	.7468	.9709	.7842	.7842	.7842
5		1.0269	.7655		.8029
6		1.1203	.8029		.9709
7		1.1949	.9149		1.251
8	1.251	1.251	1.0829	1.2696	1.1949
9	1.3817	1.3817	1.2136	1.419	1.475
10	1.307	1.307	1.2696	1.2696	1.4003
11	1.2136	1.251	1.3443	1.2323	1.2136
12	1.1203	1.1949	1.1949	1.1576	1.0082
13	1.0456	1.1949	1.1949	1.1203	.9709
14	1.0082	1.0269		1.0642	.9709
15	.9709	.9522		.9335	.9335
16	.9335	1.0269	.9522	.9335	.9335
17	.9335	1.0456	1.0269	.9149	.9335
18	1.1389	1.2136	1.1949	1.1949	1.0642
19	1.2696	1.2323	1.2323	1.1949	1.1949
20	1.2323	1.1763	1.3256	1.2323	1.2136
21	1.2136	1.2696	1.2323	1.1949	1.2136
22	1.1389	1.1576	1.1763	1.1016	1.1576
23	1.0829	1.0269	1.0456	1.0082	
24	.8775	1.0269	.9522	.9335	.8775
Max	1.3817	1.3817	1.3443	1.419	1.475
Min	.7468	.9522	.7655	.7842	.7842
Avg	1.0607	1.1249	1.0583	1.0696	1.0439

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 205 / 11 KV Railway station

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.112	.112	.1307	.112
2	.1307	.0934	.112	.1307	.112
3	.112	.0934	.0934	.0934	.0934
4	.112	.0934	.112	.112	.112
5		.0934	.1307		.112
6		.0934	.1307		.0934
7		.0934	.112		.0747
8	.0747	.112	.0934	.0934	.112
9	.0934	.0934	.0747	.112	.0934
10	.0934	.0934	.0934	.0934	.0934
11	.0934	.0934	.0934	.112	.0934
12	.112	.112	.112	.1307	.112
13	.112	.0934	.112	.112	.112
14	.112	.1307		.112	.0934
15	.112	.1307		.1307	.0934
16	.0934	.0934	.0934	.112	.0934
17	.0934	.0747	.0747	.0934	.0934
18	.1494	.1307	.1307	.168	.1494
19	.168	.1867	.2054	.1867	.1867
20	.1867	.1867	.2054	.2054	.1867
21	.2054	.2054	.1867	.1867	.1867
22	.1867	.1867	.1867	.1867	.168
23	.1494	.168	.1494	.1494	
24	.1307	.1307	.1307	.1307	.1307
Max	.2054	.2054	.2054	.2054	.1867
Min	.0747	.0747	.0747	.0934	.0747
Avg	.1263	.1206	.1248	.1325	.1177



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 206 / SUB STATION T/F

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.0187	
2		.0187	
3		.0187	
4		.0187	
5		.0187	
6		.0187	
7		.0187	
8		.0187	
9		.0187	
10	.0187		.0187
11	.0187		.0187
12	.0187		.0187
13	.0187		.0187
14	.0187		.0187
15	.0187		.0187
16	.0187		.0187
17	.0187		.0187
18	.0187		.0187
19	.0187		.0187
20	.0187		.0187
21	.0187		
22	.0187		.0187
23	.0187		
24		.0187	
Max	.0187	.0187	.0187
Min	.0187	.0187	.0187
Avg	.0187	.0187	.0187

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 207 / 11 KV Glow Max

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.112	.0747	.0747	.0747
2	.0373	.0747	.0373	.0373	.0373
3		.0373	.0373		.0373
4	.0373	.0373	.0373	.0373	.0373
5		.0373	.0373		.0373
6		.0373	.0373		.0373
7		.0373	.0373		.0373
8	.056	.0747	.0373	.0373	.0373
9	.056	.1307	.3921	.2427	.168
10	.0934	.1867	.1867	.2427	.1867
11	.1494	.2054	.2987	.2614	.2054
12	.2054	.2801	.2427	.2801	.2241
13	.2427	.2801	.2987	.2054	.2241
14	.2427	.3361		.3174	.2054
15	.2241	.2614		.2054	.2054
16	.2241	.2614	.2054	.1867	.2054
17	.2614	.2614	.3174	.2054	.2054
18	.2614	.2241	.3361	.2614	.168
19	.2241	.2427	.2241	.2427	.2054
20	.2427	.2614	.3361	.2241	.2054
21	.2614	.2054	.2614	.2054	.2054
22	.2427	.1867	.3174	.168	.1494
23	.1867	.1494	.2054	.1307	
24	.1307	.1494	.168	.168	.112
Max	.2614	.3361	.3921	.3174	.2241
Min	.0373	.0373	.0373	.0373	.0373
Avg	.1727	.1696	.1875	.1867	.1396

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 208 / 11 KV Balaji Angan SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.307	1.4937	1.2696	1.3817	1.1576
2	1.1949	1.4563	1.2323	1.3817	1.1576
3	1.1203	1.4563	1.1949	1.3817	1.1203
4	1.1203	1.4937	1.1576	1.307	1.1203
5		1.587	1.1576		1.1203
6		1.6804	1.1949		1.531
7		1.7177	1.307		1.8671
8	1.9044	1.7551	1.5684	2.0911	1.8298
9	2.3899	2.1658	1.7551	2.2405	2.2405
10	2.3152	2.2405	1.9044	2.2779	2.2032
11	2.2405	2.3525	1.9791	2.4646	2.1472
12	2.1472	2.2405	1.7551	2.5019	2.1285
13	2.0538	2.2032	1.7551	2.1658	2.0911
14	2.0165	2.0165		2.1285	2.0538
15	1.9605	2.0165		2.1285	1.9605
16	1.9418	1.9791	1.4937	1.9791	1.8484
17	1.7551	1.6804	1.6057	1.643	1.7177
18	1.9044	1.8671	1.6804	1.9418	1.7924
19	1.8298	1.9418	1.7924	1.8298	1.8671
20	1.7737	1.8671	1.7551	1.8671	1.7924
21	1.7177	1.7551	1.7924	1.7924	1.7551
22	1.6057	1.7551	1.7177	1.643	1.6057
23	1.5684	1.5684	1.6057	1.4563	
24	1.3443	1.531	1.3817	1.3443	1.2323
Max	2.3899	2.3525	1.9791	2.5019	2.2405
Min	1.1203	1.4563	1.1576	1.307	1.1203
Avg	1.7720	1.8259	1.5480	1.8547	1.7104

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 209 / 11kV NIFT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0187	.0187		.0187
2			.0187		.0187
3		.0187	.0187		.0187
4		.0187	.0187		.0187
5		.0187	.0187		.0187
6		.0187	.0187		.0187
7		.0187	.0187		.0187
8	.0187	.0187	.0187	.0187	.0187
9	.0187	.0187	.0187	.0187	.0187
10	.0187	.0187	.0187	.0187	.0187
11	.0187	.0187		.0187	.0187
12	.0187	.0187		.0187	.0187
13	.0187	.0187		.0187	.0187
14	.0187	.0187		.0187	.0187
15	.0187	.0187		.0187	.0187
16	.0187	.0187	.0187	.0187	.0187
17	.0187	.0187		.0187	.0187
18	.0187	.0187		.0187	.0187
19	.0187	.0187	.0187	.0187	.0187
20	.0187	.0187	.0187	.0187	.0187
21	.0187	.0187		.0187	
22	.0187	.0187		.0187	.0187
23	.0187	.0187		.0187	
24	.0187	.0187	.0187	.0187	.0187
Max	.0187	.0187	.0187	.0187	.0187
Min	.0187	.0187	.0187	.0187	.0187
Avg	.0187	.0187	.0187	.0187	.0187

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 210 / 11kV outgoing feeder 10 SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0456	1.2323	1.1203	1.1576	1.1203
2	1.0082	1.1949	1.1016	1.1203	1.0829
3	.9709	1.1949	1.0456	1.0082	1.0456
4	.9335	1.1949	1.0456	1.0082	1.0269
5		1.2323	1.0829		1.0269
6		1.307	1.1389		
7		1.3443	1.1203		1.5123
8	1.5123	1.3817	1.2136	1.475	1.3443
9	1.363	1.5123	1.3817	1.3443	1.363
10	1.3443	1.2696	1.419	1.3443	1.307
11	1.307	1.2136	1.4563	1.2323	1.2136
12	1.2323	1.3443	1.4563	1.1763	1.0829
13	1.1576	1.2883	1.419	1.1203	1.0829
14	1.1203	1.1763		1.1016	1.1203
15	1.0642	1.0829		1.0829	1.1203
16		1.1949	1.1763	1.0082	1.1576
17			1.251	1.1203	1.1576
18	1.3817	1.5684	1.5684	1.363	1.251
19	1.419	1.4937	1.531	1.2696	1.3817
20	1.419	1.4937	1.4563	1.3256	1.363
21	1.419	1.419	1.531	1.3256	1.3443
22	1.363	1.3817	1.4003	1.307	1.3256
23	1.307	1.2883	1.307	1.2323	
24	1.1203	1.2696	1.2136	1.1949	1.2136
Max	1.5123	1.5684	1.5684	1.475	1.5123
Min	.9335	1.0829	1.0456	1.0082	1.0269
Avg	1.2362	1.3078	1.2925	1.2056	1.2111

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 211 / 11 KV S N Park

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6348	.6722	.6348	.7282	.6348
2	.6348	.6535	.6161	.6535	.5975
3	.5975	.6535	.5975	.5975	.5601
4	.5601	.6535	.5601		.5601
5		.7095	.5601		.5601
6		.7468	.5228		.7095
7		.7842	.5975		.8402
8	1.0082	.8402	.7282	.9896	.9896
9	.9335	.8029	.8775	1.0642	.9335
10	.8962	.8589	.7842	.9522	.8962
11	.8215	.8775	.6908	.8589	.8402
12	.7842	.8589	.7655	.8402	.7655
13	.7282	.6535	.6908	.8029	.7468
14	.7095	.6535		.7842	.7095
15	.6722	.5975		.7468	.6722
16	.6722	.6722	.6161	.7468	.6348
17	.5788	.6348	.5975	.6161	.5975
18	.6908	.7468	.7095	.7468	.7095
19	.8029	.8402	.8589	.8402	.7842
20	.8029	.8589	.8962	.8215	.8029
21	.8029	.8215	.8029	.8215	.8029
22	.7655	.8215	.7655	.7842	.8215
23	.7468	.7842	.8029	.7282	
24	.6908	.7095	.6722	.7282	.6722
Max	1.0082	.8775	.8962	1.0642	.9896
Min	.5601	.5975	.5228	.5975	.5601
Avg	.7397	.7461	.6976	.7926	.7322

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 212 / 11kV Siemens Express NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373		.0187	.0187
2			.0187	.0187
3	.0373		.0187	.0187
4	.0373			.0187
5				.0373
6				.0373
7				.056
8	.056		.2427	.2427
9	.1867		.2427	.1867
10	.1867		.1494	.1867
11	.1867		.1867	.1867
12	.2054		.1867	.2054
13	.2054		.2241	.1867
14	.1867		.2054	.1494
15	.1867		.2054	.112
16	.1867		.2054	.0934
17	.0934		.112	.0747
18	.0747		.0747	.0747
19	.0373	.0187	.056	.056
20	.0373		.0373	.0373
21	.0373	.0187	.0373	.0373
22		.0187	.0373	.0187
23		.0373	.0373	
24	.0373		.0187	.0187
Max	.2054	.0373	.2427	.2427
Min	.0373	.0187	.0187	.0187
Avg	.1120	.0234	.1158	.0901

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 213 / 11kV BPCL SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0187	.0187	.0187	.0187
2		.0187	.0187	.0187	.0187
3	.0187	.0187	.0187	.0187	.0187
4	.0187	.0187	.0187		.0187
5		.0187	.0187		.0373
6		.0187	.0187		.0373
7		.0187	.0187		.0187
8	.1494	.0373	.0373	.056	.056
9	.168	.0373	.0373	.2427	.1867
10	.1867	.056		.2241	.1867
11	.2054	.0747		.2241	.168
12	.2054	.0747		.2427	.168
13	.2054	.056		.1886	.168
14	.2241	.056		.1867	.168
15	.2241	.0747		.1867	.1494
16	.2241	.0747	.0187	.1867	.1494
17	.1867	.0747	.0187	.168	.1307
18	.0747	.0747	.0187	.0747	.056
19	.0373	.0373	.0187	.056	.0187
20		.0187	.0187	.0373	.0187
21	.0373	.0373		.0373	.0187
22	.0187	.0187	.0187	.0373	.0373
23	.0187	.0187	.0187	.0373	
24	.0187	.0187	.0187	.0187	.0187
Max	.2241	.0747	.0373	.2427	.1867
Min	.0187	.0187	.0187	.0187	.0187
Avg	.1179	.0405	.0209	.1131	.0812



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 201 / plot no 51 sec-30 feeder SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.406	1.7924	1.6975	1.6118
Max	1.406	1.7924	1.6975	1.6118
Min	1.406	1.7924	1.6975	1.6118
Avg	1.406	1.7924	1.6975	1.6118

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 202 / mass housing s/s no-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0514	.0532	.0514	.0514
Max	.0514	.0532	.0514	.0514
Min	.0514	.0532	.0514	.0514
Avg	.0514	.0532	.0514	.0514

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 203 / LIG MASS HOUSING Feder SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.2915	.3258	.3429	.3086
Max	.2915	.3258	.3429	.3086
Min	.2915	.3258	.3429	.3086
Avg	.2915	.3258	.3429	.3086

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 205 / pl no.42 &amp; 43, sec-35D

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.12	.1143	.0857	.0686
Max	.12	.1143	.0857	.0686
Min	.12	.1143	.0857	.0686
Avg	.12	.1143	.0857	.0686

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 206 / PLOT NO 53 & 54 STATUS SHEDDABLE URBAN  
VIHAR S Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.3772	.4668	.4287	.4287
Max	.3772	.4668	.4287	.4287
Min	.3772	.4668	.4287	.4287
Avg	.3772	.4668	.4287	.4287

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 207 / MASS HOUSING S/S NO.3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0686	.0754	.0686	.0686
Max	.0686	.0754	.0686	.0686
Min	.0686	.0754	.0686	.0686
Avg	.0686	.0754	.0686	.0686

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 208 / pl no.171, sec-30 feeder SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17
HR	Load (MW)
24	.1029
Max	.1029
Min	.1029
Avg	.1029

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 210 / MASS HOUSING S/S NO.4

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0686	.0905	.1029	.0857
Max	.0686	.0905	.1029	.0857
Min	.0686	.0905	.1029	.0857
Avg	.0686	.0905	.1029	.0857



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 211 / MASS HOUSING S/S NO.2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0343	.0686	.0343	.0343
Max	.0343	.0686	.0343	.0343
Min	.0343	.0686	.0343	.0343
Avg	.0343	.0686	.0343	.0343

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 212 / arihant abhilasha pl no-10

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.823	1.2071	1.1488	1.2517
Max	.823	1.2071	1.1488	1.2517
Min	.823	1.2071	1.1488	1.2517
Avg	.823	1.2071	1.1488	1.2517

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 223001 / 22/22 KV BHINGARI SWITCHING

ST

Feeder No / Name : 302 / 22 KV PANVEL-I

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.989	2.1605	2.1948	2.1948	1.989
2	1.9204	2.0576	2.0576	2.1262	1.9204
3	1.8519	1.989	1.989	2.0576	1.8519
4	1.9204	2.0576	1.9547	2.1262	1.9547
5	1.989	2.0919	1.989	2.1605	2.0233
6	2.0919	2.0919	2.0233	2.1948	2.0576
7	2.1262	2.0576	2.0233	2.1948	2.1605
8	2.332	2.2291	2.0576	2.4006	2.2634
9	2.332	2.6783	2.6406	2.8292	4.9692
10	2.5034	2.7161	2.7538	3.0178	5.3292
11	3.0521	3.5082	3.2819	3.6214	
12	2.9835	3.4705	3.5082	3.4705	
13	2.9492	3.5837	3.3196	3.3234	
14	2.9835	3.0521	3.0864	2.9835	1.2689
15	2.9835	3.0864	2.9835	3.0178	1.0974
16	2.8807	3.1207	2.8121	2.8464	1.989
17		3.0521	2.8121	2.7435	2.1605
18	3.1893	3.3951	3.0864	3.1893	2.2634
19	3.4637	3.6351	3.5665	3.4294	2.4691
20	3.4294	3.7037	3.5322	3.4637	2.4691
21	3.2922	3.5665	3.4979	3.1893	2.2291
22	2.7092	3.0178	3.0521	2.7778	2.1605
23	2.572	2.3663	2.7435	2.4348	2.0233
24	2.0576	2.2291	2.2634	2.2634	2.0576
Max	3.4637	3.7037	3.5665	3.6214	5.3292
Min	1.8519	1.989	1.9547	2.0576	1.0974
Avg	2.5914	2.7882	2.7179	2.7524	2.3194

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 223001 / 22/22 KV BHINGARI SWITCHING

ST

Feeder No / Name : 304 / 22KV GAVAN

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.9438	4.1152	3.4294	2.1948	4.7325
2	3.4294	3.2579	3.155	2.1262	4.1838
3	3.155	2.7435	3.0178	2.0576	4.1152
4	2.572	2.4691	2.7435	2.332	3.7723
5	2.5377	2.5034	2.8121	2.7092	3.4979
6	2.572	2.5377	2.7778	3.0521	3.3951
7	2.5034	2.5034	2.7778	2.9835	2.572
8	2.8121	2.6406	3.4294	5.0755	3.0178
9	3.9781	2.3411	4.7188	4.2433	3.1824
10	5.1097		2.7069	2.2314	3.0727
11	4.8697	4.0969	4.353	4.8285	5.4332
12	4.321	4.8285	4.6091	4.3896	
13	2.8807	1.6095	3.219	3.3288	
14	2.5034	2.4006	1.7833	3.1893	
15	4.6296	2.9835	3.4294	3.9781	
16	4.4925	5.3841	3.2579		
17	3.7037	4.9726	2.0919		
18	4.1495	3.6008	1.8519	4.6639	3.6008
19	3.6008	3.738	2.6063	2.572	4.1152
20	3.0178	3.6008	2.1948	2.7778	2.8464
21	5.144	4.1838	2.2977	4.4925	4.321
22	5.0412	3.7037	2.1262	4.4925	4.1152
23	2.7092	2.9492	2.2634	4.321	3.0178
24	4.4239	4.3896	3.6351	2.2634	5.0069
Max	5.144	5.3841	4.7188	5.0755	5.4332
Min	2.5034	1.6095	1.7833	2.0576	2.572
Avg	3.6708	3.3719	2.9703	3.3774	3.7777

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 223001 / 22/22 KV BHINGARI SWITCHING

ST

Feeder No / Name : 305 / 22 KV Pargaon

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.2414	5.5556	4.5268	3.3608	5.5213
2	5.1783	5.144	4.1152	3.1207	5.144
3	3.2579	4.1152	3.2579	2.915	4.7668
4	2.5377	2.7092	2.4691	3.0178	4.1495
5	2.572	2.6749	2.5377	3.1207	3.9438
6	2.5377	2.6063	2.5034	3.1893	3.6694
7	2.5034	2.572	2.4691	2.5377	2.7092
8	2.6063	2.3663	2.332	2.4006	2.8464
9	4.1838	4.792	2.7801	3.4385	4.4627
10	5.5213	5.5601	3.7677	6.2552	5.487
11	6.4472	7.6086	3.5482	6.4015	
12	6.0357	8.4865	5.743	6.7673	4.6201
13	5.6242	8.0205	4.513	7.2428	
14	2.915	5.1783	2.7435	5.2126	
15	6.7901	7.8875	4.5268	6.2071	
16			3.4637		
17	5.9328	6.2071	2.915		
18	5.727	6.653	3.2922	5.7613	4.5268
19	3.1893	3.2236	2.572	3.7037	5.4527
20	3.2236	2.9492	2.6406	3.3265	3.7037
21	3.1893	4.0124	2.4006	3.4637	5.3498
22	4.9383	5.0412	2.9492	5.2469	4.7668
23	4.2524	5.8985	3.2236	5.8985	5.3841
24	6.653	5.9671	5.1097	3.4637	5.9328
Max	6.7901	8.4865	5.743	7.2428	5.9328
Min	2.5034	2.3663	2.332	2.4006	2.7092
Avg	4.4373	5.0100	3.3500	4.3660	4.5798

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 223001 / 22/22 KV BHINGARI SWITCHING

ST

Feeder No / Name : 306 / Nere

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0864	3.2579	3.4294	3.3951	3.155
2	3.0864	3.2236	3.2579	3.1207	2.915
3	3.1207	3.0864	3.155	3.0178	3.0178
4	3.9438	4.2867	4.1152	3.2922	3.3951
5	4.7668	5.1097	4.7668	4.1152	4.1495
6	5.3155	6.2414	4.904	5.0412	4.6296
7	5.3498	5.2469	4.9383	5.5213	5.4184
8	5.487	6.0014	5.2469	5.2812	5.144
9	4.4582	4.7051	5.1532	4.9665	4.7051
10	3.738	4.369	4.6304	4.369	4.0329
11	3.3265	3.7715	4.4437	3.8089	.8215
12	3.0178	3.5848	3.6595	3.5475	.7842
13	2.8807	3.3234		3.2114	.6859
14	2.7435	2.8121	.9602	2.8121	.6859
15	2.4348	2.8121	3.5322	2.8807	.6859
16	2.6063	3.0521	3.4979	2.8464	2.8464
17	3.0178	3.4979	3.7037	3.1893	3.6008
18	4.0124	4.0466	4.1838	3.9095	4.4582
19	4.5268	4.2181	4.7668	4.3896	5.0755
20	4.3553	4.8011	4.561	4.4582	4.8011
21	4.321	4.4239	4.4582	4.2524	4.6296
22	4.1152	4.2524	4.2181	4.0124	4.1495
23	3.738	3.9781	3.8752	3.5665	3.6694
24	3.1893	3.3951	3.5322	3.5665	3.3608
Max	5.487	6.2414	5.2469	5.5213	5.4184
Min	2.4348	2.8121	.9602	2.8121	.6859
Avg	3.7766	4.0624	4.0430	3.8572	3.3674

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 223001 / 22/22 KV BHINGARI SWITCHING

ST

Feeder No / Name : 307 / Sainagar

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2634	2.332	2.332	2.4348	2.1948
2	2.2291	2.2634	2.2291	2.2291	2.1262
3	2.2291	2.2634	2.1262	2.1262	2.0576
4	2.2977	2.2977	2.1605	2.2634	2.0919
5	2.332	2.332	2.1605	2.3663	2.1948
6	2.3663	2.332	2.1948	2.4348	2.3663
7	2.3663	2.2977	2.1948	2.572	2.4691
8	2.8121	2.6406	2.4691	2.8121	2.7092
9	2.6063	2.7721	2.8753	2.95	2.7435
10	2.7435	2.9199	3.0678	2.9569	5.301
11	2.7092	2.5133	2.8166	2.5393	4.7996
12	2.2634	2.4272	2.6886	2.2916	
13	2.2977	2.2779	2.5133	2.1437	2.0233
14	2.1262	2.0919	2.2291	1.989	
15	1.9547	1.9204	2.2291	1.9204	2.2634
16	1.7147	1.989	1.989	1.9547	2.0576
17	2.0233	2.0576	2.0576	1.9547	1.989
18	2.332	2.3663	2.332	2.4006	2.332
19	2.5377	2.4691	2.6063	2.572	2.4691
20	2.5034	2.4348	2.5034	2.6063	2.4691
21	2.5377		2.4691	2.5377	2.4691
22	2.4691	2.4348	2.5034	2.4006	2.4691
23	2.5377	2.4691	2.6406	2.4348	
24	2.2977	2.4006	2.4006	2.5034	2.2634
Max	2.8121	2.9199	3.0678	2.9569	5.301
Min	1.7147	1.9204	1.989	1.9204	1.989
Avg	2.3563	2.3610	2.4079	2.3914	2.5647

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 223001 / 22/22 KV BHINGARI SWITCHING

ST

Feeder No / Name : 310 / 22 KV PANVEL-III

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2346	1.2689	1.2689	1.5775	1.2003
2	1.2003	1.2346	1.2003	1.4403	1.1317
3	1.2003	1.2346	1.166	1.3717	1.1317
4	1.2689	1.2689	1.166	1.3717	1.2003
5	1.3375	1.3032	1.2689	1.406	1.2689
6	1.3717	1.3375	1.2346	1.4746	1.3375
7	1.406	1.3375	1.2346	1.406	1.3717
8	1.406	1.4403	1.3375	1.4403	1.3717
9	1.3375	1.4712	1.4712	1.5466	1.358
10	1.2689	1.5089	1.5466	1.4998	1.3957
11	1.0974	1.4712	1.5844	1.419	1.358
12	1.166	1.4335	1.5089	1.3817	2.1502
13	1.0974	1.4335	1.3443	1.3443	2.1605
14	1.166	1.2689	1.3032	1.2689	2.0919
15	1.2003	1.3375	1.2346	1.166	2.1262
16	1.2346	1.2689	1.2689	1.166	2.0233
17	1.3032	1.3032	1.406	1.2003	2.0919
18	1.5089	1.5432	1.6118	1.4746	2.1605
19	1.6461	1.6804	1.749	1.6461	2.4348
20	1.6461	1.7147	1.6804	1.6461	2.4691
21	1.6461	1.6804	1.6461	1.6118	2.332
22	1.4403	1.5775	1.5432	1.4403	1.9547
23	1.4403	1.4403	1.4746	1.406	1.8861
24	1.2689	1.3375	1.3375	1.6461	1.2346
Max	1.6461	1.7147	1.749	1.6461	2.4691
Min	1.0974	1.2346	1.166	1.166	1.1317
Avg	1.3289	1.4123	1.3995	1.4313	1.7184



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 224004 / 33/11KV NEW PANVEL SEC-7

S/STN

Feeder No / Name : 201 / 11 kV Station Trasformer

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0191		.0191
2				.0191
6		.0191		.0191
7		.0191		.0191
8		.0191		.0191
9		.0191	.0191	
10			.0191	
11		.0191	.0191	
12		.0191	.0191	
13		.0191	.0191	
14		.0191	.0191	
15		.0191	.0191	
16	.0191		.0191	
17	.0191		.0191	
18	.0191		.0191	
19	.0191		.0191	
20	.0191		.0191	
21	.0191			
22	.0191		.0191	
23	.0191		.0191	
24		.0191		.0191
Max	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0191	.0191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 224004 / 33/11KV NEW PANVEL SEC-7

S/STN

Feeder No / Name : 205 / 11 kV Sector 8

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8764		.8192
2				.8002
6		.9907		1.1241
7		1.105		1.2765
8		1.3146		1.448
9	1.3817	1.4098	1.3527	
10			1.2574	
11		1.1622	1.1622	
12		1.0288	1.0098	
13		1.0288	.9526	
14		.9526	.8573	
15		.8764	.8002	
16	1.3717		.7621	
17	1.1622		.8573	
18	1.3908		1.1431	
19	1.4098		1.2574	
20	1.4098		1.3336	
21	1.3717			
22	1.2574		1.1812	
23	1.086		1.0669	
24		1.0098		.9335
Max	1.4098	1.4098	1.3527	1.448
Min	1.086	.8764	.7621	.8002
Avg	1.3157	1.0686	1.0710	1.0669

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 224004 / 33/11KV NEW PANVEL SEC-7

S/STN

Feeder No / Name : 206 / 11kv sect-3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1524		.1524
2				.1524
6		.1524		.1524
7		.1524		.1524
8		.1524		.1524
9	.1848	.1524	.2286	
10			.2096	
11		.2096	.1905	
12		.1905	.1905	
13		.1715	.1905	
14		.1524	.1715	
15		.1524	.1715	
16	.2667		.1524	
17	.2286		.1524	
18			.1524	
19	.2096		.1524	
20			.1905	
21	.1715			
22	.1524		.1715	
23	.1524		.1524	
24		.1524		.1524
Max	.2667	.2096	.2286	.1524
Min	.1524	.1524	.1524	.1524
Avg	.1951	.1628	.1769	.1524

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 224004 / 33/11KV NEW PANVEL SEC-7

S/STN

Feeder No / Name : 207 / 11KV SECT-5

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5906		.5525
2				.5335
6		.7049		.7621
7		.8192		.8573
8		.8954		.9335
9	.8962	1.0098	1.086	
11		1.2003	1.1622	
12		1.1622	1.2193	
13		1.0669	1.0098	
14		1.0479	1.0288	
15		.9526	.9526	
16	1.448		.9907	
17	1.3527		.9526	
18			1.0669	
19	1.2193		1.0669	
20	1.1241		.9335	
21	.9335			
22	.8954		.7621	
23	.6859		.6859	
24		.6478		.6097
Max	1.448	1.2003	1.2193	.9335
Min	.6859	.5906	.6859	.5335
Avg	1.0694	.9180	.9936	.7081

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 224004 / 33/11KV NEW PANVEL SEC-7

S/STN

Feeder No / Name : 208 / 11kv mpk

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8002		.743
2				.6859
6		.8383		1.0288
7		.8954		1.0288
8		1.0098		1.0288
9	1.0456	1.2003	1.2574	
10			1.2765	
11		1.2574	1.2003	
12		1.2003	1.0479	
13		1.2574	.9717	
14		1.0669	.9907	
15		1.105	.9145	
16	1.2193		.8764	
17	1.2955		.9526	
18			1.0669	
19	1.467		1.3146	
20	1.467		1.1812	
21	1.3908			
22	1.1431		1.0669	
23	.9907		.9145	
24		.8764		.8383
Max	1.467	1.2574	1.3146	1.0288
Min	.9907	.8002	.8764	.6859
Avg	1.2524	1.0461	1.0737	.8923

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 224004 / 33/11KV NEW PANVEL SEC-7

S/STN

Feeder No / Name : 209 / 11 KV ESRGSR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3239		.3048
2				.3048
6		.4191		.4763
7		.5525		.5716
8		.6478		.5906
9	.5544	.6478	.6478	
10			.5716	
11		.4763	.4382	
12		.5144	.4572	
13		.4572	.4191	
14		.381	.4191	
15		.3429	.3048	
16	.5716		.3048	
17	.5144		.3239	
18			.3239	
19	.5716		.3429	
20	1.3717		.4572	
21	.4382			
22	.4191		.381	
23	.381		.381	
24		.3429		.3239
Max	1.3717	.6478	.6478	.5906
Min	.381	.3239	.3048	.3048
Avg	.6028	.4642	.4123	.4287

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 224012 / 33/11 KV KALPATARU RIVERSIDE

Feeder No / Name : 201 / 11KV KALPATARU KRISHNA-1 SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0754	.0754	.0754	.0754
2	.0566	.0754	.0566	.0566	.0566
3	.0566	.0566	.0566	.0566	.0566
4	.0566	.0566	.0514	.0754	.0566
5	.0566	.0754	.0754	.0943	.0566
6	.0943	.0943	.0943	.132	.1132
7		.132	.1132	.1509	.1698
8	.1509	.1509	.132	.1509	.1698
9	.1132	.1509	.1509	.1132	.1509
10	.132	.1509	.1509	.1132	.1509
11	.132	.1509	.1509	.1132	.132
12	.132	.132	.132	.1132	.1132
13	.0943	.1132	.1132	.0754	.0943
14	.0754	.1132	.1132	.0754	.0943
15	.0754	.0943	.1132	.0754	.0754
16	.0943	.0943	.0943	.0566	.0754
17	.0754	.1132	.1132	.0754	.0943
18	.0943	.1132	.1132	.0754	.1132
19	.1132	.1132	.132	.0943	.132
20	.132	.1132	.1132	.0943	.132
21	.132	.132	.1132	.0943	.0943
22	.2772	.1132	.0943	.0943	.0943
23	.0943	.1132	.0943	.0943	.0943
24	.0754	.0943	.0943	.0754	.0754
Max	.2772	.1509	.1509	.1509	.1698
Min	.0566	.0566	.0514	.0566	.0566
Avg	.1031	.1092	.1059	.0927	.1030

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 224012 / 33/11 KV KALPATARU RIVERSIDE

Feeder No / Name : 202 / 11KV KALPATARU NARMADA-1 SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0754	.0572	.0754
2	.0572	.0572	.0566	.0572	.0566
3	.0572	.0572	.0566	.0572	.0566
4	.0572	.0572	.0566	.0762	.0566
5	.0572	.0762	.0566	.0953	.0566
6	.0953	.0762	.0754	.0953	.0754
7	.1524	.0953	.0943	.1143	.0943
8	.0953	.1143	.0754	.1143	.1132
9	.1143	.1132	.1132	.1334	.132
10	.0953	.1132	.1143	.0943	.0953
11	.0953	.1132	.1334	.0943	.0953
12	.0953	.132	.0953	.0943	.0762
13	.0762	.1132	.1143	.0943	.0762
14	.0572	.0943	.0762	.0943	.0762
15	.0572	.0943	.0572	.0754	.0762
16	.0762	.0754	.0572	.0566	.0762
17	.0572	.0754	.0953	.0754	.0762
18	.0953	.0754	.0953	.0943	.0762
19	.0762	.0754	.1143	.0943	.0953
20	.0953	.0943	.0953	.0943	.0953
21	.0953	.0943	.0762	.0943	.0762
22	.0953	.0754	.0762	.0754	.0953
23	.0762	.0754	.0762	.0754	.0762
24	.0572	.0572	.0754	.0572	
Max	.1524	.132	.1334	.1334	.132
Min	.0572	.0572	.0566	.0566	.0566
Avg	.081	.0859	.0838	.0860	.0817



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 224012 / 33/11 KV KALPATARU RIVERSIDE

Feeder No / Name : 203 / 11 KV KALPATARU KAVERI-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0686	.0686	.0857	.0686
2	.0514	.0514	.0514	.0686	.0514
3	.0514	.0514	.0514	.0514	.0514
4	.0514	.0514	.0514	.0514	.0686
5	.0514	.0686	.0686	.0686	.0686
6	.0686	.0857	.0686	.0857	.0857
7	.0857	.1029	.0686	.1029	.1029
8	.0857	.1029	.0857	.0857	.1029
9	.1029	.12	.1097	.0857	.12
10	.12	.12	.0857	.1029	.1029
11	.1543	.12	.12	.1029	.1029
12	.12	.1029	.1029	.1029	.1029
13	.0857	.1029	.0857	.1029	.0857
14	.0857	.1029	.1029	.0857	.0857
15	.0857	.0857	.0686	.1029	.0857
16	.0857	.1029	.0857	.12	.1029
17	.1029	.1372	.1029	.1029	.1029
18	.1029	.1029	.12	.0857	.1029
19	.12	.1029	.1029	.0857	.1029
20	.1029	.1029	.0857	.0857	.1029
21	.1029	.0857	.0857	.0857	.1029
22	.0857	.0857	.0857	.0857	.0857
23	.0857	.0857	.0934	.0857	.0857
24	.0857	.0857	.0857	.0857	.0686
Max	.1543	.1372	.12	.12	.12
Min	.0514	.0514	.0514	.0514	.0514
Avg	.0893	.0929	.0849	.0879	.0893

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 224012 / 33/11 KV KALPATARU RIVERSIDE

Feeder No / Name : 302 / 22KV O/g 1(Panvel 1) SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	11-DEC-17
HR	Load (MW)
8	.3048
Max	.3048
Min	.3048
Avg	.3048

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 224012 / 33/11 KV KALPATARU RIVERSIDE

Feeder No / Name : 303 / 22KV O/g 2(Panvel 2) SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2895	3.2526	2.9264	3.8775	3.1093
2	3.0308	3.0308	2.7435	3.5848	2.9264
3	2.9199	2.8829	2.7069	3.3653	2.7069
4	2.7351	2.7721	2.9264	3.219	2.7069
5	2.7351	3.0308	3.2922	3.4385	2.9264
6	3.2895	3.3265	3.658	3.7311	3.2922
7	4.1027	3.807	3.7311	4.2433	3.9872
8	4.3614	4.1027	3.8775	4.4262	4.3896
9	4.5462	4.5725	4.3896	4.4262	4.4993
10	4.9528	4.7554	4.9749	5.0114	5.0114
11	5.1006	5.1578	5.0846	5.1212	
12	5.1745	5.0846	4.9017	4.9749	
13	4.9528	4.9749	4.7188	4.9017	
14	4.6571	4.8285	4.2433	4.7554	
15	4.5831	4.7554	4.2798	4.6091	5.7065
16	4.5831	4.6091	4.0969	4.4993	5.4138
17	4.8419	4.9383	4.4262	5.1212	5.487
18	5.7289	5.8894	5.1212	5.487	5.8162
19	6.0616	6.0357	5.5236	5.8528	6.1088
20	5.8029	5.6699	5.3041	5.1212	5.7796
21	5.1745	5.3041	5.1212	4.8651	5.2309
22	4.3244	4.2798	4.2798	4.3896	4.2798
23	3.807	3.8409	3.9872	3.658	3.8043
24	3.4743	3.4004	3.4751	3.658	3.4751
Max	6.0616	6.0357	5.5236	5.8528	6.1088
Min	2.7351	2.7721	2.7069	3.219	2.7069
Avg	4.3429	4.3459	4.1579	4.4307	4.3329

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 228013 / 220/33/22 KV ONGC PANVEL

Feeder No / Name : 405 / 33KV KALPATARU INCOMING-1 NON SHEDDABLE WATER SUPPLY AND  
Feeder KV- 33 / INCOMING UTILITY

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.738	3.6854	3.411	3.9597	3.2464
2	3.4637	3.4088	3.1893	3.5734	3.3539
3	3.3539	3.2442	3.1893	3.3539	3.1345
4	3.1893	3.1345	3.3539	3.2464	3.1893
5	3.1893	3.4659	3.7951	3.5231	3.3539
6	3.8523	3.7951	4.1244	4.1289	3.8523
7	4.6251	4.2387	4.2364	4.7325	4.5702
8	4.8971	4.6251	4.401	4.8994	5.0092
9	5.1189	5.064	4.8971	4.8422	5.1166
10	5.4458	5.4927	5.336	5.5533	5.3909
11	5.5579	5.7773	5.5579	5.6653	.3429
12	5.6104	5.3224	5.3932	5.4458	.2858
13	5.3338	5.5579	4.7737	5.3338	.3429
14	5.0571	5.3338	4.6754	5.0595	.2858
15	4.8377	5.2241	4.6182	5.0046	6.102
16	4.9474	5.1143	4.4536	4.9474	5.8276
17	5.2217	5.3909	4.7303	5.6082	5.8825
18	6.0494	6.2117	5.5007	5.8276	6.102
19	6.3215	6.4883	5.9945	6.102	6.4334
20	6.1591	6.1042	5.7201	5.6082	6.2163
21	5.4984	5.7201	5.4436	5.2789	5.5533
22	4.6754	4.7851	4.6754	4.9497	4.6205
23	4.2341	4.2364	4.3438	4.1267	4.1792
24	3.9597	3.85	3.9049	4.1244	3.4659
Max	6.3215	6.4883	5.9945	6.102	6.4334
Min	3.1893	3.1345	3.1893	3.2464	.2858
Avg	4.7640	4.8030	4.5716	4.7873	3.9941

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

URAN[126]

BU 0337

Substation No/ Name :- 223033 / 22/22 KV URAN SWITCHING

Feeder No / Name : 302 / 22 KV Dronagiri

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	09-DEC-17
HR	Load (MW)
8	1.4335
Max	1.4335
Min	1.4335
Avg	1.4335

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

URAN[126]

BU 0337

Substation No/ Name :- 223033 / 22/22 KV URAN SWITCHING

Feeder No / Name : 304 / 22 KV Industrial

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	09-DEC-17
HR	Load (MW)
8	.7167
Max	.7167
Min	.7167
Avg	.7167

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641] BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 201 / 11 KV Sector - 14

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	11-DEC-17
HR	Load (MW)	Load (MW)
2	1.8673	
4	1.8296	
6	2.3577	
8	.8488	
10	2.4006	
15	2.0005	
18		.1132
20	3.0483	
24	2.2634	
Max	3.0483	.1132
Min	.8488	.1132
Avg	2.0770	.1132

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641] BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 202 / 11 KV Sector - 7

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.3772		.4904	.4527	
4	.3395	.362	.4527	.415	
6	.4904		.4527	.4715	
7			.4572		
8	.5281	.4191	.5093	.6668	.6287
10	.6668	.5658	.7922	.7049	.6478
12		.7922	.5847	.7356	.7621
13		.7733			
14			.6413	.6224	
15	.5716	.679		.5847	.5525
16			.5658	.5658	
18				.5847	
19					.7811
20	.7049	.7811	.7049		
22				.6287	
23			.6097		
24	.5093	.6097	.4904	.5847	
Max	.7049	.7922	.7922	.7356	.7811
Min	.3395	.362	.4527	.415	.5525
Avg	.5235	.6228	.5626	.5848	.6744



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641] BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 203 / 11 KV Sector - 10

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	1.6975		2.0182	2.2068	
4	1.3392	1.4861	1.8673	1.8484	
6	1.7353		1.8484	2.1313	
7			2.2257		
8	2.5274	2.0767	2.2257	2.4768	2.3434
10	2.1338	2.2445	2.452	2.3243	2.0767
12		2.3577	2.3388	2.0748	2.0005
13		2.0748		1.9805	
14			2.0936	1.9616	
15	1.5432	1.6975		1.5844	1.5432
16			1.8861	1.4901	
18				1.8107	
19					2.3434
20	2.572	2.7435	2.7625		
22				2.4958	
23			2.4768		
24	1.9805	1.9814	2.1313	2.3765	
Max	2.572	2.7435	2.7625	2.4958	2.3434
Min	1.3392	1.4861	1.8484	1.4901	1.5432
Avg	1.9411	2.0828	2.1939	2.0586	2.0614

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 204 / 11 KV Sector -15

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.3395		.4904	.4715	
4	.3395	.3429	.5281	.4338	
6	.4904		.547	.415	
7			.5716		
8	.5281	.4572	.4904	.5335	.4954
10	.5335	.5281	.6036	.6287	.4763
12		.5658	.5281	.4904	
13		.5281			
14			.4715	.4527	
15	.4382	.4904		.3584	.4572
16			.3961	.3206	
18				.5658	
19					.7621
20	.6668	.7811			
22				.5906	
23			.5906		
24	.5658	.4954	.5093	.547	
Max	.6668	.7811	.6036	.6287	.7621
Min	.3395	.3429	.3961	.3206	.4572
Avg	.4877	.5236	.5206	.484	.5478

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641] BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 205 / 11 KV Railway

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.1132	.1143	.1132	.1132	
7			.1143		
8	.1132	.1143		.1143	.1143
10	.1143	.1132		.1143	.1143
12		.1132	.1132	.1132	.1143
14				.1132	
15	.1143	.1132		.1132	.1143
16			.1132		
18				.1132	
19					.1143
20	.1143	.1143	.1143		
22				.1143	
23			.1143		
24	.1132	.1143	.1132	.1132	
Max	.1143	.1143	.1143	.1143	.1143
Min	.1132	.1132	.1132	.1132	.1143
Avg	.1138	.1138	.1137	.1136	.1143

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 206 / 11 KV Ajanta Sector -13

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.1143	.1132	.1132	
7			.1143		
8	.1132	.1143		.1143	.1143
10	.1143	.1132		.1143	.1143
12		.1132	.1132	.1132	.1143
15	.1143	.1132		.1132	.1143
16			.1132		
18				.1132	
19					.1143
20	.1143	.1143	.1143		
22				.1143	
23			.1143		
24	.1132	.1143	.1132	.1132	
Max	.1143	.1143	.1143	.1143	.1143
Min	.1132	.1132	.1132	.1132	.1143
Avg	.1139	.1138	.1137	.1136	.1143

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 207 / 11 KV Sector - 4

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.7545		.8865	.9431	
4	.6602	.724	.8488	.8676	
6	.7922		.9431	1.0374	
7			.9717		
8	1.1883	1.1622	1.0562	1.2003	1.2193
10	1.0098	1.1128		1.2384	1.105
12		1.1694	1.094	1.1317	1.086
13		1.094			
14			.9431	.9431	
15	.8764	.9054		.8865	.8764
16			.7922	.8676	
18				.9808	
19					1.1812
20	1.2384	1.3908	1.4098		
22				1.1241	
23			1.105		
24	.9054	.8764	.9808	1.0751	
Max	1.2384	1.3908	1.4098	1.2384	1.2193
Min	.6602	.724	.7922	.8676	.8764
Avg	.9282	1.0544	1.0028	1.0246	1.0936

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 208 / 11 KV Sector-8

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.6602		.8865	1.226	
4	.6979	.724	.9242	1.2449	
6	.9431		1.1694	1.4901	
7			.9526		
8	1.2637	1.2003	1.6221	1.4861	1.3908
10	1.448	1.4335	1.5655	1.5813	1.448
11		1.4335			
12		1.3957		1.6975	1.3336
13		1.3203			
14			1.5844	1.2449	
15	.9907	1.2637		1.094	1.086
16			1.2449	1.094	
18				1.1694	
19					1.3908
20	1.448	1.3908	1.6004		
22				1.3336	
23			1.3908		
24	.9808	1.0098	1.0374	1.3203	
Max	1.448	1.4335	1.6221	1.6975	1.448
Min	.6602	.724	.8865	1.094	1.086
Avg	1.0541	1.2413	1.2707	1.3318	1.3298

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641] BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 210 / 11 KV Sector-20A NG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.7167			.9619	
4	.6602	.743		.8488	
6	.9242			1.0185	
7			.9145		
8	1.1694	1.0098		1.105	1.1812
10	.9907	.9431		1.0288	.9907
12		.9431		.811	.8002
13		.8779			
14				.7167	
15	.5906	.7545		.6413	.6478
16				.6413	
18				.811	
19					.9907
20	1.0479	1.2193	1.1431		
22				1.0098	
23			1.0669		
24	.9054	.8954		1.0374	
Max	1.1694	1.2193	1.1431	1.105	1.1812
Min	.5906	.743	.9145	.6413	.6478
Avg	.8756	.9233	1.0415	.8860	.9221

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 211 / 11KV Sector-14A

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			2.452	
4	2.572		2.3388	
6			2.4709	
7		2.3053		
8	2.572		3.1121	2.8006
10	2.6029		2.8387	2.4958
12	2.452		2.6972	2.3053
13	2.5463			
14			2.3011	
15	2.1879		2.1125	2.0957
16			2.037	
18			2.1434	
19				2.8769
20	3.5437	3.3913		
22			2.8959	
23		2.8578		
24	2.4577		2.7161	
Max	3.5437	3.3913	3.1121	2.8769
Min	2.1879	2.3053	2.037	2.0957
Avg	2.6168	2.8515	2.5096	2.5149



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641] BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 213 / 11 KV Sector-20 D,DKT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.1132	.1143		.1132	
7			.1143		
8	.1132	.1143		.1143	.1143
10	.1143	.1132		.1143	.1143
12		.1132		.1132	.1143
13		.1097			
15	.1143	.1132		.1132	.1143
16				.1132	
18				.1132	
19					.1143
20	.1143	.1143	.1143		
22				.1143	
23			.1143		
24	.1132	.1143		.1132	
Max	.1143	.1143	.1143	.1143	.1143
Min	.1132	.1097	.1143	.1132	.1143
Avg	.1138	.1133	.1143	.1136	.1143

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641] BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 214 / 11 KV Sector-19,Bhoomi

SHEDDABLE URBAN

kolsa Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.9431			1.1506	
4	.8865	1.3908		1.094	
6	1.0374			1.3957	
7			1.2574		
8	1.5844	1.3908		1.7528	1.6004
10	1.3336	1.3769		1.4861	1.448
12		1.3203		1.3203	1.2003
13		1.2437		1.226	
14				1.1506	
15	1.0669	1.1317		.9619	1.0669
16				1.0185	
18				1.0185	
19					1.3717
20	1.3527	1.7718	1.7909		
22				1.3336	
23			1.3717		
24	1.0374	1.1431		1.3203	
Max	1.5844	1.7718	1.7909	1.7528	1.6004
Min	.8865	1.1317	1.2574	.9619	1.0669
Avg	1.1553	1.3461	1.4733	1.2484	1.3375

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641] BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 301 / 22KV Diva Gaon

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.8383		.9054	
7			.8383		
8		.8383		1.105	1.105
10	.8383			.8764	.8002
12		.9054		.8299	.8002
15	.6478	.9054		.7167	.724
18				.7922	
19					1.0669
20	1.0288	1.1812	1.2193		
22				1.0288	
23			.9907		
24		.8383			
Max	1.0288	1.1812	1.2193	1.105	1.105
Min	.6478	.8383	.8383	.7167	.724
Avg	.8383	.9178	1.0161	.8935	.8993

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283027 / 22/22KV Rabale MIDC Swt/stn

Feeder No / Name : 305 / NARAYAN DAIRY (R.M.U. W- SHEDDABLE FEEDER HAVING WEEKLY  
413) Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.989		2.4691	2.332	2.4006
2	1.9547		2.4006	2.1948	2.2291
3	1.8519	1.3203	2.332	2.0919	2.0576
4	1.8176		2.332	1.8861	2.0576
5	1.749		2.2634	1.8519	2.2291
6	1.749	1.8861	2.4006	1.9547	2.4006
7	1.5089		2.4691	2.1262	2.4691
8	1.5775		1.2689	2.332	2.5377
9	1.5432	3.0556	2.572	2.7092	3.0521
10		3.7037	2.8121	4.0809	3.5665
11		4.5953	3.1893	3.7037	3.9095
12	1.6975	4.2524	3.3608	4.1152	3.8409
13			2.2977	2.915	3.7723
14		4.1152	3.155	4.1152	3.7723
15	2.1502	4.1495	3.0521	4.2867	3.738
16		4.0124	2.915	3.9095	4.1152
17		4.0466	2.9835	4.5953	4.3553
18	1.8107	3.9438	2.9492	3.738	3.4979
19		3.4294	2.8807	3.4637	3.4294
20		2.9492	2.5034	3.0521	
21		2.4006	2.2977	2.4691	
22		2.8464	2.2634	2.332	
23		2.7435	2.4348	1.9204	
24	2.0576	1.8484	2.6063	2.4348	2.6406
Max	2.1502	4.5953	3.3608	4.5953	4.3553
Min	1.5089	1.3203	1.2689	1.8519	2.0576
Avg	1.8044	3.2528	2.5920	2.9421	3.1036

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283027 / 22/22KV Rabale MIDC Swt/stn

Feeder No / Name : 306 / Roshn Hotel (R.M.U. R-320) SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.406		1.0974	1.4403	1.5432
2	1.3717		1.5775	1.3717	1.3717
3	1.4403	1.3203	1.5089	1.2689	1.2003
4	1.5089		1.3717	1.2003	1.3717
5	1.3717		1.3717	1.2003	1.5432
6	1.3032	1.5466	1.5089	1.3032	1.6118
7	1.3032		1.5775	1.406	1.7147
8	1.2689		1.6118	1.4403	1.7147
9	1.2003	2.1879	1.8176	2.0576	1.7833
10		2.572	2.0919	2.4348	2.332
11		2.6063	2.3663	2.6749	2.7778
12	1.8107	2.4691	2.4348	2.6749	2.7435
13		2.2291	2.0233	2.3663	2.6063
14		2.4006	2.4691	2.7778	2.6063
15		2.6406	2.3663	2.7092	2.6063
16		2.572	2.0233	2.8464	2.6406
17		2.572	2.0233	2.3663	2.7778
18		2.5377	1.8861	2.2634	2.4691
19		2.0576	1.9204	2.1262	2.2977
20		1.8519	1.6461	1.7833	
21		1.5775	1.4746	1.6461	
22		1.5432	1.4746	1.749	
23		1.6461	1.4403	1.7147	
24	1.4746	1.8484	1.6461	1.5432	1.6118
Max	1.8107	2.6406	2.4691	2.8464	2.7778
Min	1.2003	1.3203	1.0974	1.2003	1.2003
Avg	1.4054	2.1211	1.7804	1.9319	2.0662

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283027 / 22/22KV Rabale MIDC Swt/stn

Feeder No / Name : 307 / R.M.U. R-201

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823		.7888	.6516	.6859
2	.7888		.7545	.6516	.5144
3	.7888	.3772	.6859	.5487	.3429
4	.8573		.6859	.5487	.3429
5	.7545		.6859	.5144	.5144
6	.7202	.7545	.6859	.583	.6859
7	.823		.7202	.7202	.7545
8	.7888		.7202	.823	.823
9	.8573	.6036	.5144	.7545	.6173
10		.4801	.3772	.6859	.6859
11		.5144	.4115	.7888	.7545
12	1.0562	.7545	.5487	1.1317	.8916
13		.6173	.8916	.6859	1.0288
14		.9259	.8916	.9945	1.0974
15	2.8292	.9259	.7888	1.166	1.0974
16		.9259	.7888	.823	1.0974
17		.6859	.7888	1.0974	1.0974
18	2.4143	.4801	.4115	1.0631	.6173
19		.4801	.3772	.5487	.5487
20		.3772	.3429	.4801	
21		.4115	.3429	.4115	
22		.8916	.583	.4458	
23		.8573	.7545	.823	
24	.8916	.8676	.8573	.7202	.823
Max	2.8292	.9259	.8916	1.166	1.0974
Min	.7202	.3772	.3429	.4115	.3429
Avg	1.1072	.6628	.6416	.7359	.7510

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283027 / 22/22KV Rabale MIDC Swt/stn

Feeder No / Name : 308 / TECHNOPROCESS (R.M.U. R- SHEDDABLE FEEDER HAVING WEEKLY  
260 ) Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717		1.0288	.8916	.8573
2	1.2689		.9602	.8573	.8573
3	1.2003	.3772	.9259	.823	.5144
4	1.2003		.8916	.823	.5144
5	1.0631		.8916	.7545	.6859
6		.7545	.8573	.7888	.8573
7	1.0288		.8916	.8573	1.0288
8	.9602		.8916	.9259	1.0974
9	.9602	1.2826	1.2689	1.3032	1.166
10		1.5775	1.3032	1.6461	1.7147
11		1.5775	1.3717	1.749	1.749
12	1.3203	1.3717	1.3717	1.749	1.7833
13		1.2346	1.2003	1.406	1.7147
14		1.3717	1.5089	1.749	1.6461
15	1.2071	1.6804	1.4746	1.8519	1.6118
16		1.7833	1.5089	1.8176	1.6118
17		1.5089	1.406	1.6118	1.6804
18	1.094	1.3717	1.1317	1.5775	1.5089
19		1.0288	1.2346	1.166	1.3717
20		.6859	1.0974	1.166	
21		.9602	.9945	.9602	
22		1.0631	1.0288	.9602	
23		1.0974	.9259	.823	
24	1.4403	.9808	1.0631	.9945	.9602
Max	1.4403	1.7833	1.5089	1.8519	1.7833
Min	.9602	.3772	.8573	.7545	.5144
Avg	1.1763	1.2060	1.1345	1.2189	1.2466

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 301 / 22 KV KALWA - I

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	7.3045	3.3265	5.3155	5.7613	5.6584
2	7.0988	3.155		5.5899	5.5556
3	6.7901	3.0864	5.3155	5.487	4.9726
4	6.5158	3.1893	5.2469	5.2812	4.904
5	6.3786	3.2579	5.2126	5.3155	4.8697
6	6.2414	3.5665	5.144	5.3841	4.8697
7	6.7901	3.6351	5.4527	5.487	6.5844
8	7.6132	3.9438	5.4184	5.727	6.3786
9	3.6694	3.8409	6.0014	5.9671	6.2414
10	3.4294	3.6694	6.4815	5.9671	6.5844
11	3.1207	3.2922	6.0357	6.2757	6.2414
12	2.7435	3.155	5.5556	5.9328	5.1783
13	2.6063	3.0178	5.487	5.5213	5.2812
14	2.6749	2.9835	5.6584	5.6927	5.6927
15	6.6873	2.7778	5.487	5.8299	6.7901
16	7.7504	2.915	5.4184	6.5501	6.2757
17	2.572	2.8807	5.5899	6.0357	7.0302
18	3.2579	3.3608	5.8299	7.0988	7.1674
19	3.9095	4.1838	6.4472	7.4417	7.1674
20	4.0466	4.2867	6.4815	6.6873	7.2017
21	3.9438	4.4239	6.3786	6.2414	6.3443
22	3.8409	6.7215	6.31	6.3443	6.6873
23	3.7723	6.0014	6.1728	6.2071	6.3786
24	7.6475	3.4294	5.487	5.8985	5.8299
Max	7.7504	6.7215	6.4815	7.4417	7.2017
Min	2.572	2.7778	5.144	5.2812	4.8697
Avg	5.0169	3.6708	5.7360	5.9885	6.0785



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 302 / 22 KV Airoli -1(O/G)

SHEDDABLE URBAN

Feeder KV- 22 / INCOMING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.2181	2.332	5.5899	6.5158	1.5318
2	4.1152	2.2291	5.487	6.3443	2.1948
3	4.0466	2.2291	5.3155	6.4129	2.0233
4	3.8752	1.9547	5.0755	6.5158	1.9547
5	3.7723	1.8861	5.1097	6.6873	1.9204
6	4.7325	1.989	5.3841	6.7558	2.7092
7	5.3155	2.1605	5.7613	7.1331	3.0864
8		2.1948	6.0014	8.2305	2.9835
9	5.4527	2.2634	6.7215	5.7842	3.2579
10	5.487	2.2634	7.3388	8.1276	3.3265
11	5.4527	1.7833	7.5103	8.4019	3.4979
12	5.2812	1.989	4.1152	8.0933	3.4637
13	5.2469	2.3663	6.9616	3.6008	3.4294
14	5.2812	2.2977	6.3786	3.6351	3.4979
15	5.2469	2.2977	5.9328	3.4637	3.4979
16	5.2126	2.5377	5.7613		3.4979
17	5.2812	2.6406	5.9328	3.5322	3.6694
18	6.1043	2.8121	6.8587	3.9781	3.7723
19	6.5158	3.0521	7.9561	3.9438	3.8409
20	6.5158	3.2579	8.1619	3.7037	3.738
21	2.2291	5.8299	8.2305	3.1207	3.4637
22	2.1605	7.9561	7.6475	2.8464	2.8807
23	2.0576	6.7901	7.1331	2.6406	2.7778
24	4.321	2.4006	5.7613	6.5844	2.4348
Max	6.5158	7.9561	8.2305	8.4019	3.8409
Min	2.0576	1.7833	4.1152	2.6406	1.5318
Avg	4.6923	2.8964	6.3386	5.4805	3.0188

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 303 / 22 KV Airoli - II

Feeder KV- 22 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9204	1.8519	1.8176	2.2977	1.8176
2	1.8176	1.8176	1.7147	2.2291	1.7833
3	1.7147	1.7147	1.6461	2.2977	1.7833
4	1.6461	1.749	1.6118	2.332	1.9204
5	1.9204	1.8176	1.989	2.2634	1.2803
6	2.2634	1.9204	2.2634	2.3663	1.989
7	2.4006	2.4006	2.6749	2.7435	2.6406
8	2.572	2.5377	2.8464		2.6063
9	2.572	2.7092	3.0521	2.572	2.6063
10	2.6063	2.7778	3.2236	2.4691	
11	2.1262	2.8121	3.155	2.5377	2.8464
12	1.8519	2.572	3.155	2.332	2.6749
13	1.6461	2.2977	2.7778	1.9547	2.332
14	1.7833	2.6063	2.9492	2.1262	2.4691
15	1.7147	2.6406	2.7435	1.9204	2.572
16	1.749	2.1262	2.4691		2.4348
17	1.5089	2.1262	2.4348	2.1948	2.5377
18	1.5089	2.1262	2.4006	.4458	2.332
19	1.9204	2.1948	2.4691	2.1262	2.0919
20	1.9204	2.2291	2.4691		2.1262
21	1.989	2.1605	2.332	1.8176	1.9204
22	2.0576	1.9547	2.332	2.1262	1.8519
23	2.1262	2.1948	2.5377	2.2634	1.9204
24		1.9547	1.8861	2.332	1.9204
Max	2.6063	2.8121	3.2236	2.7435	2.8464
Min	1.5089	1.7147	1.6118	.4458	1.2803
Avg	1.9711	2.2205	2.4563	2.1785	2.1938

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 304 / 22 KV Rabale MIDC

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.9438	3.2922	4.2181	3.3265	3.4294
2	3.7723	3.155	4.1152	3.155	3.4979
3	3.6694	3.0864	4.0466	3.2236	3.7037
4	3.4637	3.0178	3.9781	3.1893	4.0466
5	3.4294	2.915	4.3896	3.2579	4.0124
6	3.4979	3.0864	4.6639	3.3265	4.2867
7	3.738	3.3608		3.3608	4.4582
8	4.0124	3.8409	3.4294	3.9781	4.7325
9	5.4184	5.2126	4.4239	5.8299	5.9671
10	4.6639	6.5844	5.5899	6.9273	7.2359
11	4.9383	7.2017	5.5899	7.6132	7.6475
12	5.2126	6.7558	5.8985	7.8189	8.1276
13	4.4582	5.487	4.1495	5.7613	5.9671
14	4.9726	7.0645	5.4184	7.6818	7.5789
15	4.8697	7.1674	5.3841	7.4417	7.5789
16	4.8354	7.7846	5.3498		7.8875
17	4.4925	7.2702	4.7325	7.9561	7.1674
18	3.9095	6.5501	4.4582	6.6873	6.7901
19	3.8409	5.727	4.2867	6.07	6.1043
20	3.4979	5.3155	4.1495	5.3155	4.9383
21	3.5665	5.0412	3.8066	4.6296	4.5268
22	3.4637	4.6296	3.4294	4.2867	4.9383
23	3.5322	4.1152	3.6351	4.1838	4.0124
24	4.0809	3.3608	4.321	3.4294	3.6008
Max	5.4184	7.7846	5.8985	7.9561	8.1276
Min	3.4294	2.915	3.4294	3.155	3.4294
Avg	4.1367	5.0426	4.4984	5.1500	5.5098

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 305 / 22 KV Ghansoli

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.144	5.2126	5.3841	5.7613	5.1097
2	4.9726	5.144	5.1783	5.6584	4.9726
3	4.7325	5.0755	4.904	5.487	4.8354
4	4.561	5.3841	4.8011	5.727	4.8697
5	5.144	5.487	5.4184	5.8985	5.1097
6	6.1043	6.2757	6.1386	6.7558	6.6873
7	6.6873	6.8244	6.7215	7.5446	7.7161
8	7.6818	7.0302	6.9273	7.4074	7.5446
9	7.6818	6.8587	7.1331	7.0988	6.893
10	6.1728	6.31	7.3045	6.1728	6.1728
11	5.2469	5.6927	6.6187	5.487	5.5213
12	4.7668	5.6927	5.6584	4.9726	4.9383
13	4.4239	5.2126	5.6242	4.9726	4.6982
14	4.3896	4.904	5.3498	4.8011	4.4582
15	4.2181	4.7668	5.144	4.6296	4.3896
16	4.1495	4.904	5.144		4.4239
17	4.321	5.144	5.2812	4.6296	4.6296
18	5.3498	6.0014	6.31	6.1043	5.5556
19	6.7215	6.8587	7.4074	7.0302	6.8587
20	7.0988	7.2359	7.6475	1.3717	7.1331
21	6.893	7.6132	7.5789	6.8587	7.0988
22	6.7215	7.2017	7.2017	6.7901	6.8587
23	6.1728	6.31	6.5844	6.0014	5.9328
24	5.2469	5.3498	5.5213	5.8299	5.3841
Max	7.6818	7.6132	7.6475	7.5446	7.7161
Min	4.1495	4.7668	4.8011	1.3717	4.3896
Avg	5.6084	5.9371	6.1243	5.7822	5.7413

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 306 / 22 KV Railway -II

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.4115	.4115	.4115	.4458
2	.4115	.4115	.4115	.4115	.4115
3	.4115	.4115	.4115	.4115	.4115
4	.4115	.4115	.4115	.4115	.4115
5	.4115	.4115	.4458	.4115	.4115
6	.4115	.4115	.4458	.4115	.4115
7	.4115	.4115	.4115	.4115	.4115
8	.4115	.4115	.4115	.4115	.4115
9	.4115	.4115	.4115	.4115	.4458
10	.4115	.4115	.4115	.4458	.4115
11	.4115	.4115	3.155	.4115	.4115
12	.4115	.4115	.4115	.4115	.4115
13	.4115	.4115	.4115		.4115
14	.4458	.4115	.4115		.4115
15	.4115	.4115	.4115	.4115	.4115
16	.4115	.4115	.4115		.4115
17		.4115	.4115	.4115	2.5377
18	.4115	.4115	.4115	.4115	.4115
19	.4458	.4458	.4801	.4458	.4458
20	.4115	.4458	.4458	.4458	
21	.4115	.4458	.4458	.4458	.4458
22	.4115	.4458	.4458	.4458	.4458
23	.4115	.4458	.4115	.4458	.4458
24	.4115	.4458	.4458	.4115	.4458
Max	.4458	.4458	3.155	.4458	2.5377
Min	.4115	.4115	.4115	.4115	.4115
Avg	.4145	.4201	.5372	.4213	.5144

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 309 / 22 KV Railway -I

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6461	1.7147	1.6461	1.8176	1.7147
2	1.6118	1.6461	1.5432	1.7147	1.6461
3	1.4746	1.6118	1.4746	1.6461	1.6118
4	1.3717	1.749	1.6804	1.6118	1.5432
5	1.4403	1.8176	1.8861	1.5432	1.6118
6	1.6804	1.989	2.0576	2.0576	2.1948
7	1.9204	2.1262	2.1948	2.1948	2.4006
8	2.0919	2.1605	2.3663	2.1605	2.2977
9	1.989	2.0576	2.4006	2.2291	2.0576
10	2.0233	2.1262	2.332	2.1262	2.0576
11	1.7833	1.9204	2.2291	1.989	1.749
12	1.5089	1.7147	2.1605	1.8519	1.7833
13	1.6461	1.406	1.8176	1.6461	1.7147
14	1.4746	1.6118	1.7147	1.5432	1.4403
15	1.3717	1.5089	1.5432		1.3032
16	1.3032	1.5089	1.406		1.4403
17	1.5775	1.6804	1.6118	1.3032	1.3717
18	1.7833	1.8176	1.989	1.8176	1.7147
19	1.989	2.1262	2.1262	2.0576	2.0576
20	2.2977	2.2291	2.4691	2.1262	2.2977
21	2.1948	2.3663	2.4691	2.2634	2.2291
22	2.2291	2.2634	2.4006	2.4691	2.2634
23	2.1605	2.2291	2.5034	2.1948	2.0919
24	1.749	1.7833	1.7833	1.9204	1.8861
Max	2.2977	2.3663	2.5034	2.4691	2.4006
Min	1.3032	1.406	1.406	1.3032	1.3032
Avg	1.7633	1.8819	1.9919	1.9220	1.8533

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 311 / 22 KV Cidco II

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4746	1.5089	1.3717	1.6461	1.5432
2	1.3717	1.406	1.2689	1.6118	1.3717
3	1.3032	1.3375	1.1317	1.6804	1.3375
4	1.3032	1.2689	1.3375	1.5775	1.3032
5	1.1317	1.4403	1.4746	1.5432	1.3717
6	1.2689	1.8519	1.5775	1.4403	1.8176
7	1.5775	1.9547	1.7833	1.6118	1.3032
8	2.0576	2.0576	1.989	1.9204	2.2291
9	2.0919	1.989	1.9547	2.0919	1.3717
10	2.0576	2.0576	1.9204	1.8519	1.7833
11	1.9547	1.989	1.989	2.2634	2.0919
12	1.8176	1.8176	1.8519	1.989	1.6461
13	1.5775	1.5432	1.9547	1.8519	
14	1.6461	1.4746	1.5432	1.8519	1.8519
15	1.4403	1.5432	1.5775	1.406	1.3717
16	1.3032	1.4746	1.5432		
17	1.4403	1.4746	1.749	1.6804	1.3032
18	1.5775	1.8176	1.8519	1.7833	1.7147
19	1.8176	1.9204	2.1262	1.989	1.7833
20	1.9547	1.8861	2.1948	2.0576	2.1262
21	1.8519	1.8176	2.4691	1.8861	1.989
22	1.7833	2.1262	2.0576	2.0919	2.0576
23	1.749	2.0233	1.989	1.7833	1.9204
24	1.5432	1.5432	1.4403	1.7147	1.7147
Max	2.0919	2.1262	2.4691	2.2634	2.2291
Min	1.1317	1.2689	1.1317	1.406	1.3032
Avg	1.6290	1.7218	1.7561	1.7967	1.6820

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 312 / 22 KV Vodafone

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.3032	.9602	1.0974	.9945
2	.9602	1.0974	.9945	1.0288	1.0974
3	.9945	1.166	1.0288	.9602	1.0974
4	.9602	.9602	1.0631	1.0974	1.2346
5	.9602	.9602	1.0288	1.0288	1.2346
6	.9259	.9602	1.1317	1.0288	1.0288
7	.9945	1.0288	1.2346	.9602	.9945
8	.9259	.9945	1.1317	1.0974	1.0288
9	.9945	1.2346	1.0288	1.0288	1.0631
10	.9602	1.4403	.9602	1.0288	1.0631
11	.9602	1.0974	1.0974	1.0631	1.3032
12	.9602	1.3032	1.4746	1.0288	1.3032
13	1.2346	1.3717	1.0288		1.3032
14	.9602	1.4403	1.0288		1.3375
15	1.0974	1.3032	1.0631	1.0288	1.4746
16	1.2346	1.4403	1.0288		1.3717
17	1.406	.9945	1.166	1.0288	1.4746
18	.9945	.9945	1.3375	1.4403	1.1317
19	.9945	1.0288	1.406	1.0288	1.2346
20	1.3717	1.0288	1.0974	1.0288	1.0631
21	1.0974	.9945	1.0288	1.2346	1.0288
22	1.166	.9602	1.0288	1.0288	1.0974
23	1.2346	.9945	1.0974	.9945	1.2689
24	1.1317	1.3717	.9945	1.2689	.9945
Max	1.406	1.4403	1.4746	1.4403	1.4746
Min	.9259	.9602	.9602	.9602	.9945
Avg	1.0645	1.1445	1.1017	1.0729	1.1760



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 202 / 11 KV Reliance

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4572	.4572	.4382	.4572
2	.4191	.4572	.4382	.4382	.4572
3	.4191	.4572	.4382	.4191	.4382
4	.4572	.4572	.4382	.4191	.4382
5	.4572	.4572	.4572	.4382	.4572
6	.4763	.4954	.4954	.4572	.4572
7	.5335	.5716	.5335	.5144	.4954
8	.6859	.6668	.5525	.6097	.6287
9	.724		.5525	.7621	.6859
10	.8954	.6859	.5144	.9335	.8764
11	.9526	.724	.5144	.9526	.8764
12	.8383	.7049	.4954	.9526	.8002
13	.8002	.6478	.4763	.8573	.743
14	.8192	.6478	.4763	.8383	.8573
15	.9335	.6478	.4382	.8573	.8002
16	.8954	.6287	.4572	.8573	.9335
17	.8383	.5906	.4763	.8764	.9145
18	.8383	.6097	.5335	.8192	.8573
19	.8192	.6668	.6287	.8192	.8383
20	.6859	.6287	.5906	.7811	.7621
21	.6287	.5906	.5716	.6478	.6668
22	.5525	.5906	.5525	.5906	.6287
23	.5144	.5144	.4954	.5144	.5144
24	.4572	.4763	.4572	.4763	.4763
Max	.9526	.724	.6287	.9526	.9335
Min	.4191	.4572	.4382	.4191	.4382
Avg	.6708	.5815	.5017	.6779	.6692

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 203 / 11 KV Mastek MBP s/stn NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.381	.381	.362	.381
2	.362	.3429	.381	.3429	.362
3	.3429	.3429	.381	.3429	.362
4	.3429	.3429	.381	.3429	.362
5	.362	.3429	.381	.3429	.381
6	.381	.3429	.4001	.362	.381
7	.4763	.362	.4191	.4572	.4001
8	.743	.362	.381	.743	.6097
9	.743	.4191	.4191	.7811	.7049
10	.7621	.6668	.4001	.8002	.7621
11	.6668	.6097	.4001	.8192	.7621
12	.7621	.5144	.4191	.8192	.8002
13	.6859	.6097	.381	.8002	.724
14	.7621	.4572	.362	.8573	.7621
15	.8002	.4191	.381	.8002	.743
16	.6287	.4572	.381	.8192	.7811
17	.6859	.6668	.381	.7621	.743
18	.5716	.4572	.381	.724	.7049
19	.6859	.4382	.362	.6478	.6287
20	.5144	.4382	.4001	.6097	.5716
21	.4191	.4572	.4191	.5144	.5525
22	.4191	.4191	.381	.4572	.5144
23	.381	.4001	.381	.4382	.4382
24	.381	.4001	.381	.362	.4001
Max	.8002	.6668	.4191	.8573	.8002
Min	.3429	.3429	.362	.3429	.362
Avg	.5517	.4437	.3890	.5962	.5763

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 204 / 11 KV Hexaware MBP s/stn NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.2286	.2286	.1715	.2096
2	.1905	.1905	.2096	.1715	.1905
3	.1905	.1905	.1905	.1715	.1905
4	.1905	.1905	.1715	.1715	.1905
5	.1905	.1905	.1715	.1715	.1905
6	.1905	.1905	.1905	.2286	.2096
7	.3239	.2286	.2286	.3048	.2286
8	.381	.2667	.2286	.4763	.4382
9	.362	.2667	.2286	.4954	.4382
10	.4191	.2667	.2286	.5144	.5144
11	.4954	.2858	.2286	.4954	.4572
12	.4572	.3048	.2286	.4954	.4763
13	.4763	.3048	.2096	.5144	.4954
14	.4954	.3429	.2477	.5144	.5525
15	.4763	.3429	.2477	.5144	.4954
16	.5144	.362	.2477	.4954	.5144
17	.5144	.362	.2477	.4954	.5144
18	.4191	.3429	.2286	.4572	.381
19	.362	.3048	.2286	.4001	.3429
20	.2858	.3048	.2286	.3429	.2858
21	.2858	.2858	.2286	.3048	.2858
22		.2286	.2286	.2477	.2858
23	.2477	.2286	.2096	.2477	.2286
24	.2096	.2477	.2286	.1905	.2286
Max	.5144	.362	.2477	.5144	.5525
Min	.1905	.1905	.1715	.1715	.1905
Avg	.3429	.2691	.2215	.3580	.3477

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 205 / 11 KV Life Cycle

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3048	.3048	.3048	.3048
2	.3048	.2858	.3048	.3048	.3048
3	.3048	.2858	.2667	.3048	.2858
4	.3048	.2858	.2667	.3048	.2858
5	.3048	.2858	.2667	.3048	.2858
6	.3048	.2858	.2667	.3048	.2858
7	.3429	.2858	.2667	.3048	.3048
8	.4001	.381	.3048	.3239	.3429
9	.4572	.3429	.3239	.381	.4954
10	.4572	.4001	.3239	.4954	.4954
11	.4954	.4572	.3239	.5144	.5335
12	.4954	.4954	.3429	.5525	.5335
13	.4954	.4954	.362	.5335	.5335
14	.4763	.4763	.362	.5906	.5525
15	.5525	.5144	.362	.5906	.5716
16	.5144	.4763	.381	.5716	.5335
17	.5335	.4191	.362	.5335	.5525
18	.6287	.4763	.4191	.4954	.5525
19	.5906	.4382	.4191	.4954	.5335
20	.5716	.4954	.4954	.4954	.5335
21	.5525	.4572	.4572	.4572	.5144
22	.5144	.4763	.4572	.4382	.4763
23	.4572	.4382	.4191	.3239	.4191
24	.3239	.3239	.3048	.3048	.3239
Max	.6287	.5144	.4954	.5906	.5716
Min	.3048	.2858	.2667	.3048	.2858
Avg	.4453	.3993	.3485	.4263	.4398

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 206 / 11 KV Aptech

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.3239	.2858	.2858	.3239
2	.3239	.3048	.2858	.2858	.3048
3	.3239	.3048	.2667	.2858	.3048
4	.3239	.3048	.2667	.2858	.3048
5	.3239	.3048	.2667	.2858	.3048
6	.3239	.3048	.2667	.3048	.4001
7	.4572	.3048	.2667	.4001	.5335
8	.5906	.3048	.2477	.6668	.5525
9	.7049	.3429	.2477	.7621	.743
10	.8573	.4954	.2286	.8573	.8383
11	.8954	.6097	.3048	.9526	.9145
12	.8954	.5716	.3239	1.0288	.8954
13	.9335	.5906	.381	.9907	.9526
14	.9335	.6287	.362	1.0479	.8573
15	.9526	.6668	.362	1.0288	.9145
16	.9526	.6287	.381	.9717	.9717
17	.9145	.6097	.381	.9145	.9145
18	.7621	.4954	.362	.8383	.8002
19	.7049	.4763	.3239	.743	.7621
20	.6287	.4572	.3239	.6478	.6478
21	.4954	.4572	.3048	.5335	.5144
22	.4001	.362	.3239	.4191	.4763
23	.362	.3429	.3239	.4001	.362
24	.3429	.3429	.3239	.3048	.3239
Max	.9526	.6668	.381	1.0479	.9717
Min	.3239	.3048	.2286	.2858	.3048
Avg	.6136	.4390	.3088	.6351	.6216

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 207 / 11 KV ML Tower

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953		.0953	.0953
2	.0953	.0953	.0953	.0953	.0953
3	.0953	.0953	.0953	.0953	.0953
4	.0953	.0953	.0953	.0953	.0953
5	.0953	.0953	.0953	.0953	.0953
6	.0953	.0953	.0953	.0953	.0953
7	.0953	.0953	.0953	.0953	.0953
8	.0953	.0953	.0953	.0953	.0953
9	.0953	.0953	.0953	.0953	.0953
10	.0953	.0953	.0953	.0953	.0953
11	.0953	.0953	.0953	.0953	.0953
12	.0953	.0953	.0953	.0953	.0953
13	.0953	.0953	.0953	.0953	.0953
14	.0953	.0953	.0953	.0953	.0953
15	.0953	.0953	.0953	.0953	.0953
16	.0953	.0953	.0953	.0953	.0953
17	.0953	.0953	.0953	.0953	.0953
18	.0953	.0953	.0953	.0953	.0953
19	.0953	.0953	.0953	.0953	.0953
20	.0953	.0953	.0953	.0953	.0953
21	.0953	.0953	.0953	.0953	.0953
22	.0953	.0953	.0953	.0953	.0953
23	.0953	.0953	.0953	.0953	.0953
24	.0953	.0953	.0953	.0953	.0953
Max	.0953	.0953	.0953	.0953	.0953
Min	.0953	.0953	.0953	.0953	.0953
Avg	.0953	.0953	.0953	.0953	.0953

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 208 / 11 KV core project

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2286	.2667	.2477	.2286
2	.2286	.2286	.2477	.2286	.2286
3	.2286	.2286	.2286	.2286	.2096
4	.2286	.2286	.2286	.2286	.2096
5	.2286	.2286	.2858	.2286	.2096
6	.2286	.2286	.2858	.2477	.2286
7	.2477	.2286	.2477	.2286	.2477
8	.2858	.2286	.2477	.2286	.2286
9	.3048	.2667	.3048	.3429	.2477
10	.362	.2858	.2477	.381	.362
11	.4001	.3048	.2477	.4001	.4001
12	.381	.3048	.2286	.4191	.4191
13	.4001	.3048	.2286	.4001	.4001
14	.4191	.2858	.2477	.4001	.381
15	.4191	.2858	.2477	.4001	.4382
16	.362	.2667	.2286	.4001	.4572
17	.381	.3048	.2286	.381	.4191
18	.362	.0953	.2667	.362	.381
19	.3239	.2667	.2286	.3239	.3429
20	.2858	.2477	.2477	.2858	.3048
21	.2667	.2477	.2286	.2858	.2858
22	.2858	.2858	.2286	.2858	.2477
23	.2667	.2286	.2477	.2477	.1524
24	.2858	.2667	.2858	.2286	.2477
Max	.4191	.3048	.3048	.4191	.4572
Min	.2286	.0953	.2286	.2286	.1524
Avg	.3096	.2532	.2493	.3088	.3032

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 211 / 11 KV Rupa HT SS

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3048	.3048		.3048
2	.3048	.3048	.3048	.3048	.3048
3	.3048	.3048	.3048	.3048	.3048
4	.3048	.3048	.3048	.3048	.3048
5	.3048	.3048	.3048	.3048	.3048
6	.3048	.3048	.3048	.3048	.3048
7	.3048	.3048	.3048	.3239	.3048
8	.3239	.3048	.3048	.3429	.3048
9	.4001	.3239	.3048	.4572	.381
10	.4382	.3429	.3048	.4572	.4572
11	.4763	.381	.3048	.4763	.4763
12	.4954	.381	.3048	.4954	.4572
13	.4763	.381	.3048	.4572	.4382
14	.4763	.4001	.3048	.4763	.4954
15	.4763	.3429	.3048	.5144	.4572
16	.4191	.362	.3048	.4572	.4763
17	.4572	.3429	.3048	.4572	.4572
18	.4191	.362	.3048	.4572	.4382
19	.381	.3048	.3048	.4001	.4191
20	.3429	.3048	.3048	.381	.362
21	.3048	.3048	.3048	.381	.3239
22	.3239	.3048	.3048	.3429	.3239
23	.3048	.3048	.3048	.3048	.3048
24	.3048	.3239	.3048	.3048	.3048
Max	.4954	.4001	.3048	.5144	.4954
Min	.3048	.3048	.3048	.3048	.3048
Avg	.3731	.3294	.3048	.3918	.3755



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 212 / 11 KV Rupa SS - 3

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.4763	.4763	.4763	.4572
2	.4572	.4572	.4954	.4763	.4572
3	.4572	.4572	.4954	.4572	.4572
4	.4572	.4572	.4954	.4572	.4572
5	.4572	.4572	.4954	.4572	.4572
6	.4572	.4572	.4954	.4763	.4763
7	.4954	.4763	.4763	.4954	.4954
8	.5525	.4954	.4763	.5335	.5335
9	.5906	.5335	.4763	.6287	.6097
10	.6859	.6287	.4763	.7621	.6859
11	.7049	.5906	.4763	.743	.724
12	.6859	.6287	.4763	.7811	.7811
13	.724	.6097	.4572	.743	.743
14	.7621	.6097	.4763	.7811	.7811
15	.8573	.6097	.4572	.8002	.8192
16	.7811	.6287	.4763	.7811	.8192
17	.7049	.5906	.4954	.7621	.8002
18	.6478	.5525	.4954	.6859	.6859
19	.5906	.5335	.4763		.6478
20	.5525	.5335	.4763	.5716	.5525
21	.5335	.5144	.4763	.5335	.5144
22	.5144	.5144	.4763	.5335	.4954
23	.5144	.5144	.4763	.4763	.4954
24	.5144	.5144	.4954	.4572	.4763
Max	.8573	.6287	.4954	.8002	.8192
Min	.4572	.4572	.4572	.4572	.4572
Avg	.5906	.5350	.4811	.6030	.6009

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 213 / 11 KV Rupa SS - 4

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9717	.9717	.9526	.9526	.9717
2	.9526	.9526	.9717	.9526	.9526
3	.9526	.9526	.9717	.9335	.9526
4	.9526	.9526	.9526	.9335	.9526
5	.9526	.9526	.9526	.9335	.9526
6	.9526	.9526	.9335	.9335	.9526
7	.9717	.9717	.9526	.9526	.9717
8	1.0098	.9717	.9526	.9907	.9907
9	1.1241	.9907	.9907	1.0669	1.0479
10	1.2955	1.0669	.9717	1.2574	1.2384
11	1.3527	1.0669	.9907	1.3146	1.3527
12	1.3527	1.1431	1.0098	1.3717	1.3717
13	1.3527	1.086	1.0288	1.3527	1.3336
14	1.3717	1.086	.9907	1.3527	1.3527
15	1.3717	1.105	.9717	1.3908	1.3527
16	1.3717	1.086	.9907	1.3717	1.3717
17	1.3717	1.0669	.9717	1.3527	1.3146
18	1.2193	1.0669	.9717	1.2955	1.2765
19	1.1431	1.0288	.9717	1.1431	1.1431
20	1.0479	.9717	.9907	1.086	1.086
21	.9717	.9717	.9526	1.0288	1.0098
22	.9717	.9526	.9526	.9907	.9907
23	.9907	.9717	.9526	.9907	.9907
24	.9907	.9907	.9526	.9526	.9717
Max	1.3717	1.1431	1.0288	1.3908	1.3717
Min	.9526	.9526	.9335	.9335	.9526
Avg	1.1257	1.0137	.9709	1.1209	1.1209

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 214 / 11 KV Rupa SS - 6

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2667	.3048	.3048	.3048
2	.2286	.2286	.3048	.3048	.3048
3	.2286	.2286	.3048	.3048	.3048
4	.2286	.2286	.3048	.3048	.3048
5	.2286	.2286	.3048	.3048	.3048
6	.2286	.2286	.3048	.3048	.3048
7	.2667	.2286	.3048	.3048	.3048
8	.2667	.2667	.3048	.3048	.3048
9	.3048	.3048	.3048	.3239	.3239
10	.362	.362	.3048	.3429	.3239
11	.362	.3239	.3048	.362	.362
12	.4001	.362	.3048	.362	.4001
13	.381	.381	.3048	.381	.362
14	.381	.381	.3048	.381	.381
15	.381	.381	.3048	.362	.381
16	.362		.3048	.381	.362
17	.3239	.3429	.3048	.362	.3429
18	.3429	.3048	.3048	.3429	.3239
19	.362	.3239	.3048	.3429	.362
20	.3429	.3048	.3048	.3048	.3048
21	.3429	.3048	.3048	.3048	.3048
22	.3429	.3048	.3048	.3048	.3048
23	.3048	.3048	.3048	.3048	.3048
24	.2667	.3048	.3048	.3048	.3048
Max	.4001	.381	.3048	.381	.4001
Min	.2286	.2286	.3048	.3048	.3048
Avg	.3128	.2998	.3048	.3294	.3286

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 301 / 22 Kv O/G Indian Express NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.3772	.3772		.381
2		.3772	.3772		.381
3	.381	.3772	.3772	.3772	.381
4	.381	.3772	.3772		.381
5	.1905	.3772	.1886	.3772	.381
6	.1905	.1886	.1886	.1886	.381
7	.1905	.1886	.1886	.1886	
8	.1905	.1886	.1886	.1886	.0762
9	.1905	.1886	.1886	.1886	.0762
10	.1905	.1886		.1905	.1905
11	.1905			.1905	.1905
12	.1905		.1886	.1905	.1905
13	.1905		.1886	.1905	.1905
14	.1905		.1886	.1905	.1905
15	.1905		.1886	.1905	.1905
16	.1905		.1886	.1905	.1905
17	.1905		.1886	.1905	.1905
18	.1905		.1886	.1905	.1905
19	.1905		.1886	.1905	.1905
20	.1905		.1886	.1905	.1905
21	.1905		.1886	.1905	.1905
22			.1886	.1905	.1905
23			.1886		.1905
24	.381	.3772	.3772	.3772	.381
Max	.381	.3772	.3772	.3772	.381
Min	.1905	.1886	.1886	.1886	.0762
Avg	.2268	.2915	.2315	.2181	.2385

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 303 / 22Kv O/G Electronic Sadan NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.7545	.7545		.7621
2	.7621	.7545	.7545		.7621
3	.7621	.679	.7545	.7545	.7621
4	.7621	.679	.7545	.7545	.7621
5	.7621	.679	.7545		.7621
6	.7621	.679	.7545	.7545	.7621
7	.7621	.7545	.7545		.7621
8	1.1431	.7545	.7545	.7545	.7621
9	1.1431	.7545	.7545	.7545	1.5242
10	1.1431	.7545		1.5242	1.5242
11	1.1431	1.1317		1.5242	1.5242
12	1.1431		1.5089	1.1431	1.1431
13	1.9052		1.5089	1.1431	1.1431
14	1.1431		1.5089	1.5242	1.1431
15	1.5242		1.5089	1.5242	1.1431
16			1.1317	1.1431	1.5242
17	1.1431		1.1317	1.1431	.7621
18	1.1431		1.1317	1.1431	1.1431
19	1.1431		1.1317	1.1431	1.1431
20	1.1431		1.1317	.7621	.7621
21	1.1431		1.1317	.7621	.7621
22			.7545	.7621	.7621
23			.7545		.7621
24	.7621	.7545	.7545	.7545	.7621
Max	1.9052	1.1317	1.5089	1.5242	1.5242
Min	.7621	.679	.7545	.7545	.7621
Avg	1.0524	.7608	.9945	1.0405	.9844

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 304 / 22Kv Hindustan Platinum NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.3772		.381
2	.381	.3772		.381
3	.381	.3772		.381
4	.381	.3772	.3772	.381
5	.381	.3772		.381
6	.381	.3772	.3772	.381
7	.381	.3772		.381
8	.7621	.3772	.3772	.381
9	.7621	.3772	.3772	.7621
10	.7621		1.1431	.7621
11	1.1431		1.1431	.7621
12	1.5242	.3772	.7621	1.1431
13	.7621	.3772	1.1431	1.1431
14	.7621	.3772	1.5242	1.1431
15	1.1431	.3772	.7621	.7621
16	1.1431		1.1431	1.1431
17	.7621		.7621	.7621
18	.7621	.3772	.7621	.7621
19	.7621		.7621	.7621
20	.7621		.7621	.7621
21	.381	.3772	.5716	.7621
22			.5716	.7621
23		.3772		.7621
24	.381	.3772	.3772	.381
Max	1.5242	.3772	1.5242	1.1431
Min	.381	.3772	.3772	.381
Avg	.6928	.3772	.7610	.6827

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 306 / 22KV L&amp;T - II

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.3772		.381
2	.381	.3772		.381
3	.381	.3772		.381
4	.381		.3772	.381
5	.381			.381
6	.381		.3772	.381
7	.381			.381
8	.381		.3772	.381
9	.381		.3772	.381
10	.381		.381	.381
11	.381		.381	.381
12	.381	.3772	.381	.381
13	.381		.381	.7621
14	.7621	.3772	.381	.381
15	.381	.3772	.7621	.381
16	.381	.3772	.381	.381
17	.381		.381	.381
18	.381	.3772	.381	.7621
19	.381		.381	.381
20	.381		.381	.381
21	.381	.3772	.381	.381
22			.381	.381
23		.3772		.381
24	.381	.3772	.3772	.381
Max	.7621	.3772	.7621	.7621
Min	.381	.3772	.3772	.381
Avg	.3983	.3772	.4011	.4128

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 307 / 22 kv CTRLS

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0957	2.037		2.0576
2	2.0957	2.037		2.0576
3	2.0957	2.037	2.037	2.0576
4	2.0957			2.0576
5	2.0957			2.0576
6	2.0957		1.9993	2.0576
7	2.0957			2.0576
8	2.0957		1.9239	2.0957
9	2.21		1.9239	2.1338
10	2.21		2.2481	2.1338
11	2.21		2.2481	1.3717
12	2.1719	2.1125	2.21	1.3336
13	2.1338	2.1125	2.21	1.3336
14	2.1719	2.1502	2.21	1.3336
15	2.21	2.1125	2.21	1.3336
16	2.21			1.3336
17	2.21			1.3336
18	2.21	2.1125		2.1719
19	2.1719			2.1719
20	2.1338		1.9052	2.1338
21	2.0957	2.0748	2.0957	2.0957
22			2.0957	2.0957
23		2.0748		2.0576
24		2.0748	2.037	2.0576
Max	2.21	2.1502	2.2481	2.1719
Min	2.0957	2.037	1.9052	1.3336
Avg	2.1483	2.0851	2.0967	1.8718



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 308 / 22 kv Electronic Zone  
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9052	2.6406		1.9052
2	1.9052	2.6406		1.9052
3	1.9052	2.2634	2.2634	1.9052
4	1.9052			1.9052
5	1.9052		2.2634	1.9052
6	1.9052		2.2634	1.9052
7	1.9052			1.9052
8	3.0483		3.0178	2.2862
9	4.5725		3.7723	3.4294
10	4.9535		4.5725	4.5725
11	4.9535		4.9535	4.9535
12	4.9535	2.6406	5.3346	4.5725
13	4.5725	2.6406	4.9535	4.5725
14	4.9535	2.6406	4.9535	4.5725
15	4.5725	3.0178	4.9535	4.9535
16	4.9535		4.9535	5.3346
17	4.9535		4.9535	1.3336
18	4.1914	2.2634	4.5725	4.5725
19	3.4294		3.0483	3.0483
20	3.0483		3.0483	2.6673
21	2.6673	1.8861	3.0483	2.6673
22			2.6673	2.6673
23		2.6406		2.6673
24	2.2862	2.6406	2.2634	1.9052
Max	4.9535	3.0178	5.3346	5.3346
Min	1.9052	1.8861	2.2634	1.3336
Avg	3.4294	2.5377	3.7819	3.0880

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 310 / Systime computers EL-207 NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1886	.1886	.1905
2		.1886		.1905
3		.1886		.1905
4				.1905
5				.1905
6			.1886	.1905
7				.1905
8			.1886	.1905
9			.1886	.1905
10			.1905	.1905
11			.1905	.1905
12		.1886	.1905	.1905
13		.1886	.1905	.1905
14		.1886	.1905	.1905
15		.1886	.1905	.1905
16		.1886	.1905	.1905
17		.1886	.1905	.1905
18	.1905	.1886	.1905	.1905
19	.1905	.1886	.1905	.1905
20	.1905	.1886	.1905	.1905
21	.1905	.1886	.1905	.1905
22		.1886	.1905	.1905
23		.1886		.1905
24		.1886		.1905
Max	.1905	.1886	.1905	.1905
Min	.1905	.1886	.1886	.1905
Avg	.1905	.1886	.1901	.1905

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 203 / 11KV P/3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	1.2449	1.5089	1.3203	1.4146
2	1.0562	1.2071	1.4712	1.2826	1.3392
3	.9808	1.2071	1.4146	1.2071	1.2826
4	.9808	1.2071	1.3769	1.1694	1.2826
5	1.2071	1.3203	1.4146	1.226	1.3203
6	1.3392	1.358	1.4523	1.3203	1.3769
7	1.6787	1.6032	1.4712	1.4146	1.5466
8	1.4335	1.4335	1.4335	1.5089	1.4901
9	1.2826	1.3392	1.3957	1.3392	1.2449
10	1.1317	1.2826	1.4146	1.1883	1.1128
11	.9808	1.2071	1.3014	1.0374	.9808
12	.9431	1.1506	1.226	.9997	.9054
13	.9619	1.1317	1.2071	.9808	.8865
14	.9619	1.094	1.1506	.9431	.8299
15	.8676	.9997	1.2826	.8865	.8299
16	.8865	1.0185	1.1317	.8676	.8299
17	.9054		1.2071	.9808	.8676
18	1.1506		1.2826	1.0751	1.1317
19	1.358		1.4901	1.4146	1.3957
20	1.4335		1.5655	1.7541	1.5089
21	1.9616		2.1125	1.9427	1.9805
22	1.4712		1.5844	1.4523	1.4712
23	1.3957		1.4335		1.3769
24	1.2071	1.3203	1.5278	1.3769	1.4523
Max	1.9616	1.6032	2.1125	1.9427	1.9805
Min	.8676	.9997	1.1317	.8676	.8299
Avg	1.1961	1.2426	1.4107	1.2473	1.2441

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 204 / 11KV Mathadi HTP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0185	1.1317	1.226	1.2071	1.1883
2	.9808	1.0562	1.1317	1.1317	1.1506
3	.9431	1.0562	1.094	1.0562	1.1317
4	.9431	1.0562	1.094	1.0562	1.1317
5	1.1317	1.1694	1.1317	1.1694	1.1883
6	1.226	1.2071	1.1506	1.2826	1.2637
7	1.3203	1.3769	1.1317	1.358	1.4146
8	1.3014	1.4901	1.2826	1.4523	1.4335
9	1.3957	1.358	1.4335	1.3957	1.358
10	1.1694	1.3203	1.4146	1.2826	1.1694
11	1.1694	1.226	1.1506	1.2071	1.1128
12	1.0562	1.1883	1.1694	1.1317	1.0374
13	1.0185	1.1317	1.0562	1.0751	.9619
14	.9054	1.0751	1.1694	.9997	.8488
15	.8299	.9997	1.1317	.9431	.8676
16	.8865	1.0185	1.1317	.9054	.8676
17	.9054		1.1883	1.0751	.9054
18	1.226		1.3203	1.2071	1.1506
19	1.3957		1.4523	1.226	1.358
20	1.2826		1.4146	1.2637	1.3203
21	1.2826		1.358	1.2826	1.3203
22	1.3392		1.3392	1.2637	1.2826
23	1.2449		1.3203		1.1694
24	1.0751	1.1506	1.2826	1.2637	1.2071
Max	1.3957	1.4901	1.4523	1.4523	1.4335
Min	.8299	.9997	1.0562	.9054	.8488
Avg	1.1270	1.1772	1.2323	1.1842	1.1600

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 205 / 11KV Sector-22&amp;23

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9993	2.0748	2.0748	2.1125	2.1691
2	1.8861	1.8861	1.9805		2.1502
3	1.8861	1.8861	1.9239	1.9239	2.0748
4	1.9239	1.8861	1.9427	1.9239	2.0748
5	2.0748	1.9616	2.0182	2.0748	2.1125
6	2.1691	2.0748	2.0748	2.1502	2.1691
7	2.32	2.2445	2.1125	2.3011	2.2445
8	2.3011	2.3388	2.2822	2.4331	2.2445
9	2.3011	2.2634	2.2634	2.1879	2.1879
10	1.9993	2.1691	2.2068	1.9427	1.8296
11	1.8107	1.9427	2.037	1.773	1.6975
12	1.6975	1.8484	2.0182	1.7164	1.6598
13	1.6975	1.7918	1.8484	1.6975	1.6598
14	1.6598	1.7164	1.7918	1.6409	1.5089
15	1.5844	1.6598	1.8107	1.6221	1.4901
16	1.5844	1.6975	1.8484	1.5844	1.5089
17	1.5844		1.905	1.8296	1.5089
18	1.905		2.1879	1.9616	1.905
19	2.1125		2.32	2.0748	2.1502
20	2.1879		2.32	2.2068	2.1879
21	2.2257		2.3765	2.32	2.2634
22	2.2257		2.3577	2.2634	2.3011
23	2.2068		2.2822		2.1125
24	2.0559	2.1313	2.1691	2.2068	2.2257
Max	2.32	2.3388	2.3765	2.4331	2.3011
Min	1.5844	1.6598	1.7918	1.5844	1.4901
Avg	1.9750	1.9749	2.0897	1.9976	1.9765

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 206 / 11 KV P-2 S/S

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7167	.7545	.9431	.7922	.9431
2	.679	.679	.9242	.7167	.8865
3	.679	.679	.8865	.7167	.8488
4	.7167	.679	.8865	.7167	.8488
5	.7545	.7167	.8676	.7545	.8676
6	.7922	.7545	.8299	.7922	.8865
7	.8676	.811	.7733	.8299	.8865
8	.8676	.7922	.6979	.8676	.9054
9	.8865	.8676	.7733	.8676	.9054
10	.9997	.9242	.9619	.9431	.9808
11	1.0374	.9619	1.0185	1.0562	.9431
12	.9808	.9997	.9997	.9997	1.0185
13	.9054	1.0185	.7922	.9619	.8488
14	.8676	1.0374	.9619	.8865	.8676
15	.9431	1.0374	.9431	.9054	.8865
16	.9054	1.0562	.9431	.8865	.9054
17	.9054		.9997	.9431	.9054
18	1.0185		1.1128	1.0751	1.094
19	1.0751		1.1128	.9997	1.1694
20	1.0751		1.1694	1.0185	1.1317
21	1.0562		1.0374	1.0185	1.094
22	.9619		.9431	.9997	.9808
23	.8488		.8865		.8488
24	.7167	.7733	.9808	.8299	.9619
Max	1.0751	1.0562	1.1694	1.0751	1.1694
Min	.679	.679	.6979	.7167	.8488
Avg	.8857	.8554	.9352	.8947	.9423

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 207 / 11KV SECTOR-19

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.2075	.2075	.2263
2	.1698	.1698	.1886	.1886	.2075
3	.1698	.1509	.1886	.1886	.2075
4	.1698	.1509	.1886	.1886	.2075
5	.1886	.1698	.2263	.2263	.2452
6	.2263	.2263	.2075	.2641	.2641
7	.2641	.3018	.2263	.2829	.2829
8	.2829	.2829	.2641	.3206	.3206
9	.2829	.2641	.2452	.2829	.2641
10	.1886	.2263	.2641	.2452	.2452
11	.1698	.2263	.2641	.2075	.1698
12	.1698	.2075	.2452	.2075	.1698
13	.1509	.1886	.2263	.2075	.1698
14	.1509	.1886	.2075	.1886	.132
15	.1509	.1698	.2263	.1698	.132
16	.1509	.1698	.2263	.1509	.1509
17	.1509		.2452	.1886	.1698
18	.2452		.2452	.2075	.2075
19	.3206		.3584	.2263	.2829
20	.2829		.3018	.2263	.2829
21	.2829		.2829	.2641	.2641
22	.2641		.2641	.2829	.2641
23	.2452		.2641		.2452
24	.2075	.2075	.2075	.2263	.2452
Max	.3206	.3018	.3584	.3206	.3206
Min	.1509	.1509	.1886	.1509	.132
Avg	.2114	.2053	.2405	.2239	.2232

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 208 / 11KV BEVERLY PARK -II SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3772	.3584	.3772	.3395
2	.3395	.3395	.3395	.3395	.3206
3	.3395	.3395	.3772	.3018	.3206
4	.3772	.3395	.3772	.3018	.3395
5	.4338	.3772	.3961	.3395	.3584
6	.4904	.3772	.4338	.3772	.3772
7	.5281	.4338	.4527	.415	.3772
8	.5658	.5658	.4338	.4715	.5093
9	.6036	.415	.4904	.5093	.5847
10	.5281	.4338	.4715	.4715	.4527
11	.3772	.4904	.415	.415	.3584
12	.3772	.5093	.4715	.3961	.3772
13	.3961	.4904	.4527	.3584	.3772
14	.415	.4904	.4904	.3206	.3772
15	.415	.4715	.4715	.3206	.415
16	.3395	.4904	.4715	.3395	.3772
17	.3395		.4527	.3206	.3772
18	.3395		.3961	.3018	.3395
19	.3961		.415	.3395	.415
20	.4338		.4338	.3961	.4715
21	.4715		.415	.415	.4904
22	.415		.4338	.415	.4527
23	.4338		.415		.4715
24	.415	.415		.415	.3772
Max	.6036	.5658	.4904	.5093	.5847
Min	.3395	.3395	.3395	.3018	.3206
Avg	.4228	.4327	.4289	.3764	.4024



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 211 / 11 KVMetro Bar Sectore -15

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6975	1.7353	1.8861	1.9616	1.9427
2	1.6221	1.6975	1.8484	1.8861	1.9239
3	1.6221	1.6975	1.8296	1.8107	1.8861
4	1.6598	1.6975	1.6975	1.8107	1.9239
5	1.8107	1.7353	1.7918	1.8861	1.905
6	1.9993	1.773	1.8107	2.037	2.0559
7	2.0936	1.8673	1.8296	2.1125	2.0936
8	2.2634	2.0559	1.9427	2.2634	2.3011
9	2.2257	2.1125	1.9993	2.3011	2.1125
10	2.1125	2.0748	2.3011	2.2634	1.9616
11	2.1125	2.1125	2.452	2.2445	2.1879
12	1.8861	2.1313	2.3765	2.1691	2.1125
13	1.9616	2.0748	2.3765	2.0748	1.9616
14	1.8107	2.0559	2.3011	1.9805	1.8861
15	1.8484	1.9616	2.3011	1.9616	1.8107
16	1.8107	1.9993	2.2634	1.9239	1.8107
17	1.8861		2.2634	2.0748	1.8861
18	2.452		2.4143	2.1691	2.1879
19	2.452		2.3954	2.2257	2.452
20	2.4143		2.6783	2.2634	2.5274
21	2.2822		2.4897	2.3388	2.4709
22	2.1502		2.1691	2.1313	2.2445
23	2.0936		2.2634		1.9616
24	1.7353	1.773	2.037	2.037	2.0182
Max	2.452	2.1313	2.6783	2.3388	2.5274
Min	1.6221	1.6975	1.6975	1.8107	1.8107
Avg	2.0001	1.915	2.1549	2.0838	2.0677

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 214 / 11 KV JIMMY TOWER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	12-DEC-17
HR	Load (MW)
18	1.9052
Max	1.9052
Min	1.9052
Avg	1.9052

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283030 / 22/22KV Krishna Steel

Swt/Stn

Feeder No / Name : 301 / 22 Kv SONY DADC

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.381	.3048	.3429	.3429
2	.3429	.381	.3048	.3429	.381
3	.3429	.381	.3048	.3048	.381
4	.3429	.381	.2286	.3048	.381
5	.3429	.381	.2286	.3048	.3429
6	.3429	.3429	.2286	.3048	.3429
7	.3429	.3048	.2286	.3429	.3429
8	.3429	.3048	.2286	.3429	.3429
9	.381	.3429	.2286	.3429	.3048
10	.4191	.381	.3429	.381	.3048
11	.4572	.381	.3429	.4191	.3048
12	.4572	.381	.3429	.4572	.3048
13	.4191	.381	.3429	.4191	.3048
14	.4191	.381	.381	.4191	.3048
15	.4954	.381	.381	.4191	.3048
16	.4191	.381	.381	.4191	.3429
17	.4191	.3048	.381	.4191	.3429
18	.4191	.3048	.3429	.381	.3429
19	.381	.3048	.3429	.381	.3429
20	.381	.3048	.3429	.3429	.3429
21	.381	.3048	.3429	.3429	.3048
22	.3429	.3048	.3048	.3429	.3048
23	.3429	.3048	.3429		.3048
24	.3429	.3429	.3048	.3429	.3429
Max	.4954	.381	.381	.4572	.381
Min	.3429	.3048	.2286	.3048	.3048
Avg	.3842	.3477	.3127	.3661	.3318

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283030 / 22/22KV Krishna Steel

Swt/Stn

Feeder No / Name : 302 / 22 KV BASF

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	2.0957	1.7147	1.5242	1.5242
2	1.7147	2.0957	1.7147	1.5242	1.5242
3	1.7147	2.0957	1.7147	1.5242	1.5242
4	1.9052	2.0957	1.5242	1.5242	1.5242
5	1.9052	2.0957	1.5242	1.9052	1.5242
6	1.9052	1.829	1.5242	1.9052	1.5242
7	1.9052	2.21	1.5242	1.9052	1.6004
8	1.9052	1.4098	1.5242	1.9052	1.6385
9	1.9052	1.5242	1.5242	2.2862	1.829
10	2.2862	1.7147	1.7147	2.4768	1.7147
11	2.2862	1.7147	1.7147	2.4006	1.9052
12	2.2862	1.1431	1.5242	2.6673	1.9052
13	2.3624	1.5242	1.5242	2.4768	1.9052
14	2.553	1.5242	1.5242	2.4006	1.9052
15	2.553	1.5242	1.5242	2.0957	2.0957
16	2.2862	1.5242	1.5242	1.9052	2.0957
17	2.2862	1.9052	1.5242	2.0957	2.0957
18	2.0957	1.9052	1.5242	2.1719	2.0957
19	2.0957	1.9052	1.5242	2.0195	2.0957
20	2.0195	1.9052	1.5242	1.9814	1.7147
21	1.9052	1.9052	1.5242	1.9052	1.7147
22	1.829	1.9052	1.5242	1.7909	1.7147
23	2.0957	1.9052	1.5242	1.3717	1.7147
24	1.7147	2.0957	1.9052	1.5242	1.5242
Max	2.553	2.21	1.9052	2.6673	2.0957
Min	1.7147	1.1431	1.5242	1.3717	1.5242
Avg	2.0513	1.8147	1.5798	1.9703	1.7671

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283030 / 22/22KV Krishna Steel

Swt/Stn

Feeder No / Name : 303 / 22 KV EVEREST ANGAN

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.1914	3.6199	4.1914	3.8104	4.1914
2	3.8104	3.6199	3.8104	3.8104	4.1914
3	3.8104	3.6199	3.8104	3.4294	4.1914
4	3.8104	3.6199	3.8104	3.4294	4.1914
5	3.8104	3.6199	3.4294	3.4294	4.1914
6	3.8104	3.4294	3.4294	3.8104	4.0009
7	3.8104	3.2388	3.4294	3.8104	3.6199
8	3.8104	3.8866	3.4294	3.8104	3.8866
9	3.8104	4.1914	3.4294	4.1914	4.1152
10	3.8104	4.1914	3.8104	4.5725	4.382
11	3.6199	4.1914	3.8104	4.4963	4.382
12	3.8104	4.382	3.8104	4.5725	4.5725
13	3.5056	3.8104	3.8104	4.5725	4.382
14	3.6199	4.1914	3.8104	4.5725	4.382
15	4.1914	4.1914	4.1914	4.5725	4.5725
16	4.1914	4.1914	3.8104	4.6487	4.763
17	4.1914	4.382	3.8104	4.763	4.763
18	4.1914	4.382	3.4294	4.8773	4.5725
19	4.0009	4.382	3.4294	4.5725	4.382
20	3.8104	4.1914	3.4294	4.4963	4.382
21	3.8104	4.1914	3.6199	4.382	4.382
22	3.8104		3.6199	4.2676	4.1914
23	3.7342	4.1914	3.6199	4.1914	4.1914
24	4.1914	3.6199	4.1914	3.8104	4.1914
Max	4.1914	4.382	4.1914	4.8773	4.763
Min	3.5056	3.2388	3.4294	3.4294	3.6199
Avg	3.8818	3.9711	3.7072	4.2042	4.2946

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283030 / 22/22KV Krishna Steel

Swt/Stn

Feeder No / Name : 304 / 22 KV BHAVKALESHWAR

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2862	1.9052	2.2862	2.2862	2.2862
2	2.2862	1.9052	1.9052	2.2862	2.2862
3	2.2862	1.9052	1.9052	2.2862	2.2862
4	2.2862	1.9052	1.9052	2.2862	2.2862
5	2.2862	1.9052	1.9052	2.2862	2.2862
6	1.9052	1.9052	1.9052	2.2862	2.1338
7	1.9052	1.829	1.9052	2.2862	2.0576
8	1.9052	1.9052	1.9052	2.2862	2.2862
9	2.2862	2.4768	1.9052	2.6673	2.6673
10	2.6673	3.0483	2.6673	3.4294	3.0483
11	2.8578	3.4294	3.0483	3.5056	3.2388
12	2.7435	3.8104	3.0483	3.6199	3.4294
13	2.7435	3.4294	3.0483	3.5056	3.0483
14	2.7435	3.4294	3.0483	3.5056	3.4294
15	2.8959	3.8104	3.0483	3.5056	3.4294
16	2.8197	3.8104	3.0483	3.5056	3.8104
17	2.7435	3.8104	3.0483	3.4294	3.8104
18	2.5149	3.4294	2.6673	3.2007	3.4294
19	2.2862	3.0483	2.6673	2.8959	3.4294
20	1.9814	3.0483	2.6673	2.5911	3.0483
21	1.9052	2.6673	2.4768	2.4387	2.6673
22	1.9052	2.6673	2.4768	2.3624	2.6673
23	1.9052	2.6673	2.2862	2.2862	2.6673
24	2.2862	1.9052	2.2862	2.2862	2.2862
Max	2.8959	3.8104	3.0483	3.6199	3.8104
Min	1.9052	1.829	1.9052	2.2862	2.0576
Avg	2.3513	2.7356	2.4609	2.7927	2.8340

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283030 / 22/22KV Krishna Steel

Swt/Stn

Feeder No / Name : 305 / 22KV N0CIL RCD

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0957	2.2862	2.2862	2.2862	2.2862
2	2.0957	2.2862	2.2862	2.2862	2.2862
3	2.0957	2.2862	2.0957	2.2862	2.2862
4	2.0957	2.2862	2.0957	2.2862	2.2862
5	2.0957	2.2862	2.0957	2.0957	2.2862
6	2.0957	2.2862	2.0957	2.0957	2.4006
7	2.0957	2.21	2.0957	2.0957	2.2862
8	2.0957	2.1719	2.0957	2.0957	2.21
9	2.0957	2.1719	2.2862	2.2862	2.2862
10	2.2862	2.0957	2.2862	2.2862	2.2862
11	2.2862	2.0957	2.2862	2.2862	2.2862
12	2.21	2.0957	2.0957	2.3624	2.2862
13	2.1719	2.0957	2.0957	2.2862	2.2862
14	2.1719	2.2862	2.2862	2.2862	2.2862
15	2.1719	2.2862	2.2862	2.2862	2.2862
16	2.1719	2.2862	2.2862	2.2862	2.2862
17	2.21	2.2862	2.0957	2.2862	2.2862
18	2.2862	2.2862	2.2862	2.2862	2.2862
19	2.2862	2.2862	2.2862	2.3624	2.2862
20	2.2862	2.2862	2.2862	2.2862	2.2862
21	2.1719	2.2862	2.2862	2.2862	2.4768
22	2.1338	2.2862	2.2862	2.2862	2.4768
23	2.0957	2.2862	2.2862	2.1719	2.4768
24	2.0957	2.2862	2.2862	2.2862	2.2862
Max	2.2862	2.2862	2.2862	2.3624	2.4768
Min	2.0957	2.0957	2.0957	2.0957	2.21
Avg	2.1624	2.2418	2.2148	2.2560	2.3116

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283032 / 22/11KV Ghansoli Gharonda

S/St

Feeder No / Name : 202 / 11 KV HAWARE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5684	1.8111	1.848	1.7364	1.6448
2	1.4937	1.7741	1.7372	1.6804	1.6078
3	1.4563	1.7187	1.6632	1.587	1.5708
4	1.4563	1.6632	1.5708	1.4937	1.4784
5	1.4937	1.6263	1.6632	1.7551	1.6263
6	1.9418	1.7372	1.7737	1.8671	1.8111
7	2.4272	1.9959	1.9418	2.1285	2.1807
8	2.5019	2.3101	2.0911	2.2405	2.347
9	2.1472	2.2965	2.3525	2.4459	2.2731
10	2.1472	2.3152	2.3899	2.2405	2.1253
11	1.9978	2.1658	2.3899	2.1658	2.0351
12	1.8671	2.1472	2.3339	1.9605	1.8298
13	1.8111	2.0911	2.2032	1.922	1.8298
14	1.587	1.8298	2.0165	1.6817	1.5497
15	1.46	1.8858	1.9418	1.643	1.5497
16	1.46	1.7737	2.0165	1.5497	1.5684
17	1.5339	1.8298	2.1285	1.6991	1.7177
18	1.9231	2.0538	2.4025	2.0165	2.0911
19	2.2218	2.6513	2.6427	2.3712	2.3525
20	2.3712	2.6886	2.6981	2.5873	2.4646
21	2.4459	2.6139	2.6427	2.5133	2.4832
22	2.2361	2.3655	2.3655	2.3101	2.2779
23	2.0144	2.0328	2.1437	2.0513	1.9605
24	1.6991	1.885	1.922	1.922	1.8665
Max	2.5019	2.6886	2.6981	2.5873	2.4832
Min	1.4563	1.6263	1.5708	1.4937	1.4784
Avg	1.8859	2.0526	2.1200	1.9820	1.9267



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283032 / 22/11KV Ghansoli Gharonda

S/St

Feeder No / Name : 204 / 11 KV Severage Pump

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2452	.3361	.3018	.3018	.2987
2	.2452	.2987	.2641	.3018	.2801
3	.2829	.2987	.2641	.2641	.2801
4	.2829	.2801	.2641	.2641	.2614
5	.2829	.2801	.3018	.2829	.2801
6	.3206	.3174	.3426	.3018	.3361
7	.3961	.2987	.3772	.3018	.3734
8	.415	.2801	.415	.2829	.4294
9	.6036	.5228	.4904	.2829	.6908
10	.6224	.6161	.5847	.6224	.6161
11	.6036	.4904	.5658	.6036	.5847
12	.4338	.3395	.5658	.4715	.5658
13	.3772	.2829	.5281	.3772	.3395
14	.415	.3584	.4527	.3584	.2829
15	.3921	.2829	.3018	.3395	.2829
16	.3734	.4527	.3395	.2075	.3018
17	.4481	.2452	.3772	.3772	.3206
18	.3395	.3018	.415	.3018	.5093
19	.3206	.3772	.4338	.4108	.3772
20	.3206	.3961	.415	.4108	.415
21	.3772	.3395	.3961	.3174	.3961
22	.3174	.3961	.3961	.3734	.3395
23	.3734	.415	.3961	.2987	.3584
24	.3206	.3361	.3018	.3961	.2801
Max	.6224	.6161	.5847	.6224	.6908
Min	.2452	.2452	.2641	.2075	.2614
Avg	.3796	.3559	.3954	.3521	.3833

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283032 / 22/11KV Ghansoli Gharonda

S/St

Feeder No / Name : 205 / 11 KV Swaraj Ghansoli

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0554	.0572	.0732	.0701	.0566
2	.0554	.0572	.0549	.0526	.0566
3	.0554	.0381	.0549	.0526	.0566
4	.0554	.0381	.0549	.0526	.0566
5	.0554		.0543	.0526	.0381
6	.0554	.0381	.0543	.0532	.0572
7	.0739	.0572	.0543	.0716	.0566
8	.0739	.0572	.0724	.0924	.0754
9	.0554	.0566	.0724	.0924	.0566
10	.0747	.0754	.0905	.0924	.1132
11	.0943	.0762	.1086	.0739	.0572
12	.0754	.0914	.1086	.056	.0572
13	.0754	.1097	.1086	.0747	.0762
14	.037	.0914	.1086	.0373	.0572
15	.037	.0549	.0543	.0754	.0381
16	.0566	.0732	.0549	.0377	.0572
17	.0572	.0732	.0739	.0373	.0381
18	.0572	.0732	.112	.0943	.0953
19	.0754	.0732	.0934	.0754	.0762
20	.0754	.0732	.0934	.0754	.1143
21	.0762	.1097	.0934	.0754	.0762
22	.132	.0732	.0747	.0943	.0762
23	.0572	.0732	.0747	.0566	.0953
24	.0739	.0572	.0732	.0716	.0566
Max	.132	.1097	.112	.0943	.1143
Min	.037	.0381	.0543	.0373	.0381
Avg	.0663	.0686	.0779	.0674	.0665

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283032 / 22/11KV Ghansoli Gharonda

S/St

Feeder No / Name : 206 / 11 KV SHAKTI SEC-8

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.0566	.1494	.0566	.0377
2	.1097	.0572	.0747	.0566	.0377
3	.0549	.0572	.056	.0566	.0377
4	.0549	.0572	.056	.0566	.0377
5	.0549	.0754	.056	.0566	.0377
6	.1829	.1509	.0747	.1509	.1509
7	.2012	.1494	.1494	.1886	.1698
8	.2012	.1867	.1867	.2075	.1886
9	.2195	.1848	.2054	.2075	.1867
10	.1646	.1867	.2241	.1698	.168
11	.1848	.0934	.2427	.1698	.168
12	.1494	.0747	.2054	.168	.2054
13	.1494	.0934	.0747	.168	.2054
14	.2075	.0754	.1867	.1715	.1867
15	.1886	.0373	.0934	.0373	.1867
16	.0943	.0747	.1867	.168	.1867
17	.1886	.0566	.2054	.168	.1867
18	.2075	.056	.2241	.1867	.2054
19	.2263	.0747	.2054	.2054	.2054
20	.2263	.0747	.1867	.1867	.2054
21	.1867	.0747	.0747	.0934	.2241
22	.1867	.0747	.2054	.2075	.1867
23	.1867	.1867	.056	.0566	
24	.2012	.0566	.1867	.0566	.0566
Max	.2263	.1867	.2427	.2075	.2241
Min	.0549	.0373	.056	.0373	.0377
Avg	.1671	.0944	.1486	.1355	.1505

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283032 / 22/11KV Ghansoli Gharonda

S/St

Feeder No / Name : 207 / 11 KV Tulsi Graphics

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0381	.0572	.0381	.0381
2		.0381	.0572	.0381	.0381
3		.0381	.0572	.0381	.0381
4		.0381	.0572	.0381	.0381
5			.0572	.0381	
6	.0381	.0381	.0572	.0572	.0381
7	.0572	.0381	.0762	.0762	.0572
8	.0572	.0381	.0762	.0953	.0762
9	.0572	.0754	.0953	.1143	.0566
10	.0762	.0754	.0762	.0572	.0943
11	.0381	.0572	.0572	.0572	.0381
12	.0381	.0572	.0762	.0381	.0572
13		.0572	.0572	.0381	.0572
15	.0381	.0381	.0572	.0381	
16		.0572	.0572		
17	.0381		.0762		
18	.0762	.0572	.0762	.0566	.0762
19	.0572	.0572	.0762	.0566	.0572
20	.0381	.0572	.0762	.0377	.0572
21	.0572	.0572	.0572	.0572	.0572
22	.0566	.0572	.0572	.0381	.0572
23	.0377	.0572	.0572	.0381	.0572
24		.0377	.0572		.0381
Max	.0762	.0754	.0953	.1143	.0943
Min	.0377	.0377	.0572	.0377	.0381
Avg	.0508	.0507	.0655	.0523	.0541

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283033 / 22/22 KV Lnt Mahape Swt stn

Feeder No / Name : 301 / 22KV Mahape MIDC (O/G-I) SHEDDABLE FEEDER HAVING WEEKLY  
 Shree Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.1812	.9054	.8764	1.2449
2	1.3336	1.1431	.9054	.8383	1.1317
3	1.3336	1.105	.8676	.8383	
4	1.2955	1.1431	.8676	.8002	1.0185
5	1.2955	1.105	.8676	.8002	1.0185
6	1.2193	1.1431	.8299	.8002	.9431
7	1.1431	1.105	.8299	.8002	.8676
8	1.3336	1.0669	1.358	1.1431	1.2449
9	1.4861	1.448	1.3203	1.5242	1.5089
10		1.8107	1.4712	1.9052	
11	1.2955	1.9239	1.7528	2.2634	2.0195
12	1.7909	1.9993	1.6004	2.0748	2.1338
13	1.6766	1.8861	1.4861	1.9993	
14	1.7909	2.2634	1.6766	2.1879	2.0576
15		2.2257	1.7147	2.1502	2.1719
16		2.3388	1.7147	2.0748	
17	1.6766	2.037	1.6766	2.037	1.9433
18		1.8484	1.4098	1.9616	
19		1.4335	1.2193	1.4712	1.5242
20	1.3336	1.2449	1.0288	1.2071	1.2193
21		1.094	.9907	1.2449	1.0669
22	1.2574	1.2449	1.0288	1.358	
23	1.3336	1.094	1.0288	1.2826	1.1431
24	1.448	1.2193	.9808	.8764	1.2449
Max	1.7909	2.3388	1.7528	2.2634	2.1719
Min	1.1431	1.0669	.8299	.8002	.8676
Avg	1.4120	1.5043	1.2305	1.4381	1.4168

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283033 / 22/22 KV Lnt Mahape Swt stn

Feeder No / Name : 303 / 22KV Shil

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5716	.6439	.6097	.2651
2	.5716	.5335	.6439	.6097	.2651
3	.5716	.5716	.6439	.5716	.2651
4	.5335	.5335	.606	.5716	.2651
5	.5335	.5716		.5716	.2651
6	.5335	.5716	.6439	.5716	.2651
7	.5335	.5335	.6439	.6478	.2273
8	.6859	.5716	.4924	.6859	.2273
9	.8002	.6859	.4924	.8383	.1894
10		.6818	.5681	.9907	
11	.9526	.8333	.6478	1.0605	.3048
12	.9526	.7954	.6859	1.0605	.3048
13	.9526	.5681	.6097	1.0226	
14	.9145	.7575	1.3718	.9469	.2667
15	.9526	.6818	.6097	.909	.2667
16		.7196	.6478	1.0605	
17	.9145	.7196	.6478	.9848	.2667
18	.8764	.6818	.6478	.303	
19		.6439	.724	.303	.381
20	.6859	.7196	.6859	.3409	3.7342
21		.6439	.6859	.303	.3048
22	.6478	.6818	.6859	.303	
23	.6097	.6439	.6478	.3018	.3048
24	.5716	.6097	.606	.6478	.303
Max	.9526	.8333	1.3718	1.0605	3.7342
Min	.5335	.5335	.4924	.3018	.1894
Avg	.7183	.6469	.6644	.6757	.4564

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283033 / 22/22 KV Lnt Mahape Swt stn

Feeder No / Name : 304 / 22 Kv Ekvira

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7435	2.1338	2.7435	2.553	2.6673
2	2.7435	2.21	2.6292	2.553	2.5911
3	2.7054	1.9814		2.5149	2.4768
4	2.6673	2.2862	1.8671	2.5149	2.4768
5	2.6673	2.3243	1.9814		2.4387
6	2.6673	2.21	2.21	2.5149	2.4387
7	2.5149	2.2481	2.3624	2.4768	2.4768
8	2.3624	2.553		2.4768	2.5149
9	3.0864	4.0009		4.039	4.039
10		5.2584	3.6199	5.2965	
11	3.9628	5.6775	4.2676	5.5251	5.9061
12	4.039	6.1347	4.6487	5.9823	5.7156
13		4.5344		4.6487	
14		6.0585	4.6868	5.868	5.5632
15	3.5818	5.868	4.382	5.868	5.8299
16		5.868	4.763	5.9442	
17	3.658	5.4108	3.7723	5.5632	5.6394
18	3.315	5.1059	3.5056	4.8392	
19		4.1914	3.3913	3.6961	3.8866
20	2.5911	3.6199	3.0102	3.4675	3.5056
21		2.934	2.7054	2.9721	2.8959
22	2.3243	2.7054	2.8197	2.7816	
23	2.2862	3.0483	2.4387	2.8197	2.7054
24	2.8959	2.2862	2.8197	2.5911	2.934
Max	4.039	6.1347	4.763	5.9823	5.9061
Min	2.2862	1.9814	1.8671	2.4768	2.4387
Avg	2.9340	3.7770	3.2312	3.8916	3.6159

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 284059 / 33/11 KV Sector- 12B, K

Khaira

Feeder No / Name : 202 / 11 KV SECTOR 10 HTP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3167	2.3045	2.452	2.4326	2.4897
2	2.1357	2.2131	2.3388	2.3045	2.3765
3	1.9909	2.1582	2.2257	2.2862	2.2634
4	1.9366	2.1216	2.1502	2.1582	2.1879
5	1.9004	2.0851	2.0936	2.1765	2.0748
6	2.1719	2.2862	2.2445	2.4874	2.3765
7	2.4977	2.5606	2.4143	2.7435	2.7915
8	2.7873	2.5972	2.6406	2.7435	2.9047
9	2.7511	2.8349	2.9047	2.9264	3.0556
10	2.7252	2.8166		2.7984	2.7538
11	2.524	2.7349	1.0974	2.6783	2.4709
12	2.4691	2.7915	2.7435	2.6595	2.371
13	2.3594	2.6595	2.5606	2.3954	2.1357
14	2.2862	2.6595		2.4143	2.009
15	2.1216	2.4897	2.4326	2.2257	2.009
16	1.9936	2.452	2.396	2.1502	1.9728
17	2.0485	2.6972	2.6155	2.2068	2.1357
18	2.4874	2.999	2.9813	2.7349	2.552
19	2.8715	3.3385	3.219	3.1499	2.9683
20	2.963	3.3196	3.2007	3.2253	3.0226
21	3.0727	3.4894	3.3105	3.2819	3.0407
22	2.8635	3.263	2.8532	2.9801	2.8416
23	2.6235	3.0367	2.9264	2.7915	
24	2.4434	2.5972	2.6783	2.7069	2.5652
Max	3.0727	3.4894	3.3105	3.2819	3.0556
Min	1.9004	2.0851	1.0974	2.1502	1.9728
Avg	2.4309	2.6877	2.5672	2.6107	2.4943



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 284059 / 33/11 KV Sector- 12B, K

Khaira

Feeder No / Name : 203 / 11 KV SECTOR 9

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7741	1.7375	1.8861	1.8473	1.905
2	1.6632	1.7193	1.8107	1.7375	1.8107
3	1.5708	1.6827	1.773	1.701	1.773
4	1.5154	1.6644	1.7353	1.6827	1.7353
5	1.4784	1.6644	1.6975	1.7375	1.6975
6	1.8296	1.8839	1.7918	2.0119	2.0559
7	3.0493	2.7435	2.5652	2.9995	2.9801
8	2.5873	2.5057	2.4331	2.7069	2.7726
9	2.347	2.4326	2.452		2.4897
10	2.0668	2.2314		2.2314	2.2257
11	1.9753	2.1502	1.2071	2.0748	1.9427
12	3.5848	2.1125	1.0974	2.0559	1.7187
13	1.6827	1.9805	.8259	1.773	1.4969
14	1.4083	1.8296		1.7353	1.7187
15	1.6461	1.7541	.8059	1.6975	1.6263
16	1.6095	1.8484	.8059	1.6975	1.5524
17	1.5912	1.773	.9328	1.7164	1.6448
18	1.829	2.1125	1.0059	1.905	1.9774
19	2.268	2.5086	2.3777	2.3954	2.2916
20	2.3228	2.6595	2.4143	2.5086	2.4025
21	3.3288	3.7157	3.2556	3.4894	3.0862
22	2.268	2.5274	2.4508	2.3577	2.2361
23	2.1582	2.2634	2.3228	2.1879	
24	1.9404	1.957	2.0559	2.0302	1.9616
Max	3.5848	3.7157	3.2556	3.4894	3.0862
Min	1.4083	1.6644	.8059	1.6827	1.4969
Avg	2.0623	2.1441	1.8047	2.0991	2.0479

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 284059 / 33/11 KV Sector- 12B, K

Khaira

Feeder No / Name : 204 / 11 KV SISILY PARK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3005	.2915	.3584	.3077	.3584
2	.2846	.2915	.3395	.3077	.3395
3	.2846	.2753	.3206	.2915	.3395
4	.2688	.2753	.3206	.2915	.3206
5	.2846	.2753	.3018	.3077	.3206
6	.3005	.2753	.3395	.3239	.3395
7	.3321	.3077	.3395	.3563	.3395
8	.3321	.3401	.3584	.3401	.415
9	.2688	.3401	.3772	.3239	.3772
10	.3086	.3077		.3077	.3018
11	.3429	.3206	.3401	.3395	.3395
12	.2915	.3584	.3239	.3395	.2343
13	.3086	.3584	.3077	.3018	.2656
14	.2572	.3018		.2829	.2343
15	.2572	.3395	.3077	.3018	.2343
16	.2343	.3584	.3077	.3018	.2656
17	.25	.3395	.3401	.3018	.2812
18	.2812	.415	.3401	.3395	.2968
19	.3077	.415	.3401	.3772	.2812
20	.3077		.3725	.3961	.3125
21	.3563	.415	.3725	.415	.3125
22	.3563	.4338	.3563	.415	.3281
23	.2915	.3772	.3563	.3772	
24	.3163	.3429	.3772	.4372	.3584
Max	.3563	.4338	.3772	.4372	.415
Min	.2343	.2753	.3018	.2829	.2343
Avg	.2968	.3372	.3408	.3368	.3129

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 284059 / 33/11 KV Sector- 12B, K

Khaira

Feeder No / Name : 205 / 11 KV BHAKTI HTP 12A

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.6001	.679	.6516	.6979
2	.6001	.583	.6602	.6001	.679
3	.5658	.583	.6224	.5658	.6602
4	.5487	.5658	.6036	.5487	.6413
5	.5144	.5658	.5658	.5658	.6224
6	.6001	.6001	.6036	.6173	.6602
7	.8059	.7202	.6979	.7888	.7733
8	.703	.6516	.7356	.8059	.8299
9	.7373	.7888	.8299	.7202	.9619
10	.8238	.7716		.7716	.8676
11	.788	.8299	.9088	.7922	.7356
12	.6588	.9242	.8745	.6979	.6173
13	.6268	.7733	.8059	.679	.583
14	.6268	.7545		.6224	.5316
15	.5552	.6413	.703	.5658	.5144
16	.5316	.6602	.6687	.5847	.5144
17	.5144	.7167	.6516	.5658	.5144
18	.6001	.7733	.7545	.6413	.6344
19	.703	.8299	.8402	.8299	.7545
20	.7716	.8865	.823	.7922	.7545
21	.7373	.8488	.7545	.8488	.7373
22	.7545	.8488	.7716	.811	.7373
23	.7545	.811	.7716	.811	
24	.6516	.6516	.7167	.6859	.7167
Max	.8238	.9242	.9088	.8488	.9619
Min	.5144	.5658	.5658	.5487	.5144
Avg	.6579	.7242	.7292	.6902	.6843

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 284059 / 33/11 KV Sector- 12B, K

Khaira

Feeder No / Name : 206 / 11 KV SECTOR 8

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7842	.7499	.8299	.823	.8865
2	.7095	.7316	.7733	.8048	.8488
3	.6535	.7133	.7356	.7865	.8299
4	.6161	.6767	.6979	.7682	.7922
5	.5975	.6485	.679	.7682	.7733
6	.8215	.7362	.7167	.9145	.8865
7	1.1763	1.0608	.9431	1.134	1.1506
8	1.0829	.9877	.9997	1.1157	1.1317
9	1.0082	.9511	.9808	1.0791	1.0374
10	.823	.9511		.8962	.9619
11	.8779	.9431	.9328	.9054	.8488
12	.7499	.8676	.8779	.811	.8215
13	.7316	.8676	.9328	.8488	.7655
14	.695	.7733		.7356	.7282
15	.6219	.679	.8048	.6413	.6908
16	.6348	.7356	.7682	.6413	.7095
17	.6584	.7356	.8779	.7356	.7655
18	.8779	.8865	.9694	.8488	.9335
19	.9145	1.0185	.9877	1.0185	1.0269
20	1.0059	1.1128	1.0791	1.1128	1.0456
21	1.262	1.2826	1.2254	1.3203	1.2323
22	.9877	1.0374	1.0242	1.0562	1.0082
23	.9145	.9619	.9511	.9808	
24	.8402	.9145	.9054	.8596	.9054
Max	1.262	1.2826	1.2254	1.3203	1.2323
Min	.5975	.6485	.679	.6413	.6908
Avg	.8352	.8760	.8951	.9003	.9035

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 284059 / 33/11 KV Sector- 12B, K

Khaira

Feeder No / Name : 207 / 11 KV SHUBHAM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	1.2986	1.3769	1.39	1.3769
2	1.1888	1.262	1.3203	1.262	1.3203
3	1.0425	1.2437	1.2826	1.2254	1.2826
4	1.0242	1.1888	1.226	1.1888	1.2637
5	1.0425	1.1706	1.1883	1.1888	1.226
6	1.2437	1.2437	1.2449	1.3352	1.2826
7	1.39	1.2986	1.2637	1.4998	1.4901
8	1.4083	1.3352	1.3203	1.4632	1.3957
9	1.3535	1.4083	1.4523	1.5181	1.4901
10	1.3717	1.5546		1.4083	1.5089
11	1.39	1.4901	1.6644	1.4146	1.2826
12	1.2254	1.3957	1.5912	1.2826	1.1523
13	1.3352	1.358	1.4998	1.226	1.1523
14	1.2437	1.3957		1.226	1.1523
15	1.1523	1.2826	1.3169	1.1694	1.0425
16	1.0791	1.2449	1.2254	1.1128	.9877
17	1.0608	1.2449	1.2803	1.1694	1.0974
18	1.1523	1.3203	1.4083	1.1883	1.1706
19	1.3717	1.5278	1.5546	1.4523	1.39
20	1.4083	1.5278	1.5181	1.4146	1.4632
21	1.39	1.5466	1.5181	1.5655	1.4449
22	1.39	1.5466	1.5364	1.4901	1.4449
23	1.4815	1.5655	1.5546	1.4523	
24	1.3717	1.3717	1.4901	1.4998	1.4146
Max	1.4815	1.5655	1.6644	1.5655	1.5089
Min	1.0242	1.1706	1.1883	1.1128	.9877
Avg	1.2666	1.3676	1.4015	1.3393	1.2971

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&amp;M S/DN.[127] BU 4127

Substation No/ Name :- 283019 / 22/11KV Vashi, Sec-1 S/Stn

Feeder No / Name : 201 / 11KV VASHI PLAZA OG SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5304	.5304	.5544	.5304	.5304
2	.5121	.5121	.5175	.5175	.4938
3	.4755	.4938	.4805	.5359	.4755
4	.462	.499	.462	.5228	.462
5	.5544	.462	.4435	.5601	.4805
6	.5544	.4755	.462	.5975	.5228
7		.4755	.462	.6161	.5415
8		.5121	.499	.6161	.5788
9	.8871	.6908	.5729	.8215	.823
10	1.1462	1.0164	.7865	1.3032	1.2308
11	1.3937	1.3717	.9979	1.5729	1.5364
12	1.5364	1.4449	1.1273	1.5729	1.6278
13	1.379	1.4815	1.0903	1.5912	1.5729
14	1.3937	1.3575	1.0349	1.4661	1.448
15	1.4327	1.3169	.9328	1.4299	1.448
16	1.3969	1.3032	.9694	1.448	1.448
17	1.379	1.3352	.9145	1.4266	1.448
18	1.3611	1.3352	.9877	1.3756	1.4083
19	1.262	1.2437	1.0425	1.2803	1.2254
20	1.0791	1.1706	.9694	1.134	1.1088
21	.9328	.961	.823	.9425	.9694
22	.7133	.7762	.695	.7392	.7023
23	.6036	.5914	.567	.6036	.5853
24	.5121	.5487	.5729	.567	.5487
Max	1.5364	1.4815	1.1273	1.5912	1.6278
Min	.462	.462	.4435	.5175	.462
Avg	.9772	.9127	.7485	.9905	.9674

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&amp;M S/DN.[127] BU 4127

Substation No/ Name :- 283019 / 22/11KV Vashi, Sec-1 S/Stn

Feeder No / Name : 202 / 11KV RAILWAY QUARTERS OG SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0719	1.0719	1.1273	1.1088	1.1827
2	1.0349	1.0534	1.0829	1.0719	1.1643
3	1.0903	1.0534	1.0349	1.0164	1.1458
4	1.1088	1.1203	1.1203	1.1458	1.2136
5	1.2323	1.1763	1.1827	1.2936	1.2323
6	1.2883	1.2197	1.2012	1.3676	1.2696
7	1.3817	1.2567	1.251	1.46	1.2752
8	1.419	1.3256	1.3256	1.46	1.363
9	1.307	1.251	1.2826	1.4415	1.3203
10	1.3817	1.3957	1.3957	1.4563	1.3392
11	1.1576	1.2883	1.3014	1.4563	1.251
12	1.1576	1.2696	1.2826	1.363	1.1763
13	1.1643	1.2323	1.1763	1.3443	1.1389
14	1.0903	1.1506	1.1576	1.2883	1.1016
15	.9896	1.1949	1.094	1.1949	1.0456
16	1.0829	1.1576	1.1949	1.2567	1.1203
17	1.1458	1.2197	1.2752	1.2012	1.1458
18	1.2567	1.3306	1.4045	1.2696	1.2752
19	1.4083	1.4969	1.4969	1.4632	1.4045
20	1.5546	1.6644	1.6644	1.6278	1.6278
21	1.448	1.4415	1.4969	1.4632	1.4415
22	1.3213	1.386	1.46	1.4449	1.3676
23	1.2197	1.3121	1.386	1.3717	1.2382
24	1.0903	1.0903	1.1763	1.2567	1.1827
Max	1.5546	1.6644	1.6644	1.6278	1.6278
Min	.9896	1.0534	1.0349	1.0164	1.0456
Avg	1.2251	1.2566	1.2738	1.3260	1.2510

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&amp;M S/DN.[127] BU 4127

Substation No/ Name :- 283019 / 22/11KV Vashi, Sec-1 S/Stn

Feeder No / Name : 203 / 11KV MGM OG

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.3429	.362		.3429
2	.3292	.3429	.3429		.3239
3	.3511	.3239	.3429		.3239
4	.3326	.3239	.3048		.3048
5	.3174	.3048	.3048		.3429
6	.3734	.3395	.3239		.362
7	.4435	.3584	.362		.381
8	.499	.4338	.4191		.3239
9	.4251	.4382	.362	.4763	.4572
10	.4191	.4191	.362	.4382	.4572
11	.4338	.4954	.381	.5144	.4572
12	.362	.4382	.3429	.4382	.4572
13	.4763	.381	.3206	.5144	.4763
14	.5335	.4191	.415	.4763	.4954
15	.4382	.4001	.4572	.5335	.4763
16	.5144	.4191	.4191	.4954	.4382
17	.4763	.4763	.3429	.4382	.381
18	.4954	.5144	.381	.5335	.4382
19	.4382	.4763	.3772	.4382	.4001
20	.4001	.4191	.3429	.4763	.4382
21	.381	.4382	.3429	.4382	.4572
22		.4191	.3048	.4001	.3429
23	.381	.4001	.3429	.4191	.381
24	.3841	.3429	.381	.362	.3429
Max	.5335	.5144	.4572	.5335	.4954
Min	.3174	.3048	.3048	.362	.3048
Avg	.4161	.4028	.3599	.4620	.4001



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&amp;M S/DN.[127] BU 4127

Substation No/ Name :- 283019 / 22/11KV Vashi, Sec-1 S/Stn

Feeder No / Name : 204 / 11KV HTP ABHYUDAYA BANK OG SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6584	.6283	.6838	.5914	.5729
2	.6219	.6099	.6468	.6348	.5544
3	.6401	.5729	.6099	.6722	.5359
4	.6584	.5601	.5729	.6722	.5041
5	.6468	.5975	.5359	.6348	.5228
6	.6653	.6099	.5544	.7095	.5601
7	.6908	.6283	.5914	.6908	.5975
8	.6722	.6283	.6283	.7468	.7167
9	.7655	.7468	.6722	.8402	.7947
10	1.3352	1.1827	.8775	1.386	1.3676
11	1.8665	1.885	1.3306	2.0144	1.885
12	1.8111	1.9035	1.423	1.9404	1.848
13	1.8839	1.7187	1.2936	1.922	1.8111
14	1.7558	1.7372	1.3121	1.7926	1.7556
15	1.7558	1.8296	1.2567	1.922	1.9035
16	1.9022	1.848	1.2437	1.8473	1.8665
17	1.829	1.8656	1.3352	1.8107	1.7924
18	1.8473	1.9022	1.4083	1.8107	1.9022
19	1.8473	1.7924	1.4083	1.8107	1.7741
20	1.6632	1.5912	1.4266	1.5912	1.6827
21	1.3717	1.4449	1.2986	1.39	1.4083
22	.9877	1.0608	1.0608	.9694	.961
23	.7392	.7762	.8131	.7392	.7865
24	.6767	.6468	.7207	.7023	.6099
Max	1.9022	1.9035	1.4266	2.0144	1.9035
Min	.6219	.5601	.5359	.5914	.5041
Avg	1.2205	1.1986	.9877	1.2434	1.1964

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&amp;M S/DN.[127] BU 4127

Substation No/ Name :- 283019 / 22/11KV Vashi, Sec-1 S/Stn

Feeder No / Name : 205 / 11KV NBSA OG SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5228	.6099	.5788	.6283	.5415
2	.4854	.5914	.5601	.5914	.5041
3	.4668	.5788	.5601	.5601	.5281
4	.4854	.5415	.5415	.6348	.547
5	.5228	.5914	.6161	.6722	.5788
6	.7095	.6036	.6535	.7207	.6099
7	.7842	.6401	.6838	.7392	.6653
8	.8029	.7207	.7577	.7842	.7577
9	.6722	.679	.6413	.6161	.7282
10	.7468	.7356	.7356	.8686	.9055
11	.8402	.6979	.8029	.924	.8871
12	.7282	.7655	.8402	.9149	.9055
13	.6908	.7095	.7655	1.0269	.9979
14	.7842	.6413	.7468	.9328	.924
15	.6908	.6908	.7468	.7682	.8596
16	.7095	.6535	.6535	.7842	.7842
17	.7095	.7095	.6413	.7842	.8316
18	.7842	.7842	.8865	.8131	.7577
19	1.134	.9795	.9979	.9425	.9979
20	1.2071	1.0974	1.1523	.9979	1.0903
21	.9328	.924	.9511	.8131	.8775
22	.7682	.7947	.8316	.7095	.7095
23	.7207	.7392	.7842	.6348	.6099
24	.5415	.6283	.5975	.6348	.5601
Max	1.2071	1.0974	1.1523	1.0269	1.0903
Min	.4668	.5415	.5415	.5601	.5041
Avg	.7267	.7128	.7386	.7707	.7566

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&amp;M S/DN.[127] BU 4127

Substation No/ Name :- 283019 / 22/11KV Vashi, Sec-1 S/Stn

Feeder No / Name : 206 / 11KV SEC-6 ROW OG SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6878	.7602	.7682	.788	.7421
2	.6584	.7421	.7499	.7602	.7059
3	.6401	.7133	.7023	.7421	.695
4	.6584	.6767	.6653	.7682	.695
5	.7023	.6468	.6468	.8316	.7392
6	.7207	.6584	.6653	.8501	.7762
7	.7947	.6767	.6908	.8871	.7947
8	.8316	.7947	.7282	.8871	.8215
9	.8316	.8589	.7282	.9055	.8402
10	.7282	.8215	.8775	.8029	.7655
11	.7282	.8589	.8962	.8402	.7468
12	.7095	.8029	.7655	.7282	.6348
13	.6653	.7468	.7655	.6722	.6161
14	.6838	.6535	.6722	.6535	.5975
15	.5914	.6908	.6838	.5975	.6348
16	.6099	.6838	.6161	.5788	.5788
17	.5914	.7133	.6535	.5601	.6161
18	.6653	.7682	.8215	.6697	.6283
19	.823	.8962	.9145	.823	.823
20	.9694	.9694	.9774	.905	.905
21	.8779	.8596	.8962	.823	.8413
22	.9145	.8596	.9145	.8779	.8688
23	.8145	.8779	.8413	.823	.8145
24	.7059	.7783	.8048	.8596	.7602
Max	.9694	.9694	.9774	.9055	.905
Min	.5914	.6468	.6161	.5601	.5788
Avg	.7335	.7712	.7686	.7764	.7351

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&amp;M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 302 / 22KV JAYSYNTH O/G FEEDER SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.3395	.2743	.0854	.1524
2	.1029	.3395	.2743	.0854	.0914
3	.1029	.3395	.2439	.0926	.0914
4	.1029	.2743		.0926	.0975
5	.0297	.2743		.0793	.0975
6	.1029	.2058		.0762	.0975
7	.1029	.0926	.0381	.0789	.0975
8	.1029	.1029		.0876	.1219
9	.1097	.1097	.1158	.0991	.1219
10	.2164	.2957	.1036	.3326	.1402
11	.2481		.1006	.2622	.2984
12	.2804	.2652	.1128	.2835	.3189
13	.216	.2865	.1158	.2534	.1341
14	.2804	.3395	.1372	.3018	.1738
15	.192	.2641	.1463	.2378	.0945
16	.1646	.3018	.1402	.1585	.2366
17	.1859	.3018	.096	.1433	.1063
18	.1189	.3395	.096	.1433	.1097
19	.1715	.3395	.096	.1433	.1219
20	.2713	.3395	.096	.128	.1219
21	.2896	.3018	.096	.128	.1097
22			.096	.1372	.0975
23			.096		
24	.3395	.3018	.2926	.0854	.1524
Max	.3395	.3395	.2926	.3326	.3189
Min	.0297	.0926	.0381	.0762	.0914
Avg	.1743	.2740	.1384	.1528	.1385

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&amp;M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 303 / 22KV Akshar Feeder (Old SHEDDABLE FEEDER HAVING WEEKLY  
Phizer Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT))

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.094	1.1317	1.094	1.1317
2		1.094	1.1317	1.094	1.1317
3		1.094	1.0185	1.1317	1.1317
4		1.094		1.1317	1.1317
5		1.0185		1.094	1.1317
6		1.0185		1.094	1.1317
7		1.0185	1.094	1.1317	1.1317
8		1.1317		1.1694	1.1317
9	1.8861	1.5089	1.2449	1.5089	
10	.9431	1.7353	1.358	1.8107	1.4712
11	3.0556	1.8107	1.5089	1.9239	1.6221
12	3.131	1.9239	1.6221	2.1125	1.6598
13	2.8292	1.5844	1.3957	1.8861	1.8107
14	3.1687	1.8861	1.3957	1.9239	1.9239
15	3.6591	1.9993	1.358	2.037	1.8107
16	3.6591	1.8861	1.6975	1.9239	
17	1.2071	1.5844	1.5466	1.6598	1.358
18	1.2071	1.2449	.9054	1.5844	1.2071
19	1.094	1.0562	.9054	1.5844	.9808
20	.9054	1.0562	.9054	1.1317	.8676
21	.8676	.9054	.9431	1.1317	.8299
22			.9808	1.0562	
23			1.1317		.9054
24	2.2634	1.094	1.1317	1.1317	1.4712
Max	3.6591	1.9993	1.6975	2.1125	1.9239
Min	.8676	.9054	.9054	1.0562	.8299
Avg	2.1340	1.3563	1.2203	1.4499	1.2844

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&amp;M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 304 / 22KV NOVARTIS EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS  
 FEEDER Feeder KV- 22 / (CONTINUOUS PROCESS)(NO STAGGERING)  
 OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0457	.0381	.0244	.0533	.0381
2	.0457	.0381	.0244		.0038
3	.0457	.0343	.0244	.0533	.0549
4	.0457	.0343			
5	.0457	.0343		.0533	.0366
6	.0457	.0229		.0533	.0549
7	.0594	.1132	.0244	.0533	.0366
8	.0594	.0686		.0229	.0366
9	.0533	.0206	.0213	.0023	.0373
10	.0564	.0488	.0533	.0541	.0511
11	.0602	.0495	.0465	.0549	.0518
12	.0541	.0511	.0511	.0572	.0572
13		.0457	.048	.0556	.0549
14	.0549	.0488	.0518	.0541	.0587
15	.0526	.0457	.0533	.0511	.0488
16	.0518	.048	.0488	.0518	
17	.0549	.0351	.0541	.0518	.0495
18	.0244	.045		.0533	.0495
19	.0381	.0427	.0533	.0533	.0495
20	.0351	.0198		.0015	
21	.0366	.0198		.0533	.0495
22					.0495
23			.0533		
24	.0754	.0381	.0244	.0533	.0533
Max	.0754	.1132	.0541	.0572	.0587
Min	.0244	.0198	.0213	.0015	.0038
Avg	.0496	.0428	.0411	.0469	.0461

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&amp;M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 305 / 22KV PHIZER EXPRESS FEEDER NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061	.061	.061	
2	.061	.061	.061	
3	.061	.0754	.061	
4	.061	.061		
5	.061	.061		
6	.0686	.061		.0015
7	.0305	.0297		.0015
8	.0229	.0335		.0351
9	.0244	.032		.0404
10	.0244			
11	.0198			
21	.061	.061		
24	.061	.061	.061	
Max	.0686	.0754	.061	.0404
Min	.0198	.0297	.061	.0015
Avg	.0475	.0543	.061	.0196

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&amp;M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 306 / 22KV LUBRIZOL EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS  
 FEEDER Feeder KV- 22 / (CONTINUOUS PROCESS)(NO STAGGERING)  
 OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.6975	1.6975	1.5844
2	1.5844	1.6975	1.5844
3	1.5844	1.6975	1.5844
4	1.5844	1.6975	
5	1.5089	1.6598	
6	1.5089	1.5844	
7	1.5089	1.5089	
8	1.3957	1.6221	
9	1.3957	1.6598	
10	1.5466	1.7353	
11	1.5089	1.6975	
12	1.5844	1.773	
13	1.6598	1.7353	
14	1.773	1.7353	
15	1.8107	1.6598	
16	1.8107	1.6975	
17	1.5844	1.6598	
18	1.773	1.8107	
19	1.8107	1.8484	
20	1.8107	1.773	
21	1.7353	1.6598	
24	1.6975	1.6975	1.6221
Max	1.8107	1.8484	1.6221
Min	1.3957	1.5089	1.5844
Avg	1.6307	1.6958	1.5938



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&amp;M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 307 / 22KV NANDKAMAL EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS  
 FEEDER Feeder KV- 22 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0023	.0023	.0937	.0011	.0023
2	.0023	.0023	.0023		.0023
3	.0023	.0023	.0023		.0023
4	.0023	.0023		.0011	.0023
5	.1132	.0023			.0023
6	.0023	.0023			.1132
7	.0023	.0023	.0023		.0023
8	.0023	.0023		.0011	.0023
9	.0023	.0023	.0023	.0011	.0023
10	.0023	.0023	.0011	.0011	.0011
11	.0023	.0023	.0011	.0011	.0011
12	.0023	.0023	.0011	.0011	.0011
13	.0023	.0011	.0011	.0011	.0011
14	.1132	.0011	.0011	.0011	.0011
15	.0023	.0011	.0011	.0011	.0011
16	.0023	.0011	.0011	.0011	.0011
17	.0023	.0011	.0011	.0011	.0011
18	.0023	.0011		.0023	
19	.0023	.0011	.0011	.0023	.0114
20	.0011	.0011		.0023	
21	.0023	.0023		.0023	.0011
22			.0011	.0057	.0011
23			.0011		
24	.0023	.0023	.0023	.0011	.0937
Max	.1132	.0023	.0937	.0057	.1132
Min	.0011	.0011	.0011	.0011	.0011
Avg	.0123	.0019	.0069	.0016	.0118

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&amp;M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 308 / 22KV BALMER LAWARIE NON SHEDDABLE EXPRESS HV FEEDERS  
 EXPRESS FE Feeder KV- 22 / (CONTINUOUS PROCESS)(NO STAGGERING)  
 OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6975	1.8861	1.8861	1.773	1.9616
2	1.6975	1.8861	1.8861	1.7353	1.9616
3	1.6975	1.8861	1.8861	1.7353	.0396
4	1.5089	1.8107		1.6975	1.9993
5	1.5089	1.8107		1.6975	1.8861
6	1.5089	1.8107		1.7353	1.8861
7	1.5089	1.6221	1.3203	1.7353	1.8107
8	1.3957	1.4335		1.773	1.6598
9	1.9993	1.8107	1.7353	1.8861	1.8861
10	1.773	1.7353	2.037	1.8861	1.9993
11	1.9993	1.8861	1.8861	2.1502	1.9616
12	1.5844	1.5844	1.6598	1.8484	1.6598
13	2.1879	2.037	1.773	2.1125	1.9616
14	1.9993	2.2634	1.9239	2.2257	1.9993
15	1.6221	1.6221	1.8484	1.8861	1.5089
16	2.2634	2.0748	1.773	2.1879	1.9993
17	1.8484	1.8107	1.773	1.7353	1.5089
18	2.037	2.037	1.8107	1.8107	2.1125
19	2.1502	2.1502	1.8861	.8779	1.9616
20	1.8484	1.6975	1.8484	1.8861	1.5844
21	2.037	2.1879	1.8861	1.8861	1.8861
22			1.773	1.9616	1.9616
23			1.6221		
24	1.7353	1.9616	1.8861	1.8107	1.8861
Max	2.2634	2.2634	2.037	2.2257	2.1125
Min	1.3957	1.4335	1.3203	.8779	.0396
Avg	1.8004	1.8639	1.8050	1.8275	1.7862

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&amp;M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 309 / 22KV Zoetis Pharma (PHIZER NON SHEDDABLE EXPRESS HV FEEDERS  
EX Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3018	.3395	.3395	.3018
2	.3772	.3018	.3395	.3772	.3018
3	.3772	.3018	.3395	.3772	.3395
4	.3772	.3018		.3772	.3018
5	.3772	.3018		.415	.3018
6	.3772	.3018		.415	.3018
7	.3772	.3018	.3018	.415	
8	.3772	.3018		.5281	.4527
9	.4904	.3772		.5658	.4904
10	.4527	.4527	.3018	.5281	.5281
11	.4527	.415	.3395	.5658	.4904
12	.4904	.415	.3395	.5658	.5281
13	.5281	.415	.3018	.5658	.4904
14	.4904	.415	.3018	.5658	.4904
15	.4904	.3772	.3018	.5281	.4904
16	.4904	.3772	.3018	.5658	.4904
17	.5281	.3395	.3018	.4904	.4904
18	.4904	.3772	.3395	.4527	.4904
19	.4527	.3772	.3395	.4527	.3772
20	.3772	.3395	.3395		.3772
21	.3772	.3395	.3395	.3772	.3772
22			.3395	.3395	.415
23			.3395		
24	.3018	.3772	.3395	.3018	.3395
Max	.5281	.4527	.3395	.5658	.5281
Min	.3018	.3018	.3018	.3018	.3018
Avg	.4287	.3549	.3256	.4595	.4167

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&amp;M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 310 / 22 KV MAZDA FEEDER

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.2263	1.5844	1.5089	1.5844
2	.1509	.2263	1.6221	1.4712	.2263
3	.1509	1.5089	1.5844	1.4712	.2263
4	.1509	1.5089		1.4335	.2263
5	.1509	1.5089		1.4335	.2263
6	.2263	1.5089		1.4712	.2263
7	.2263	1.5089	1.5466	1.4712	.2263
8	.2641	1.5844		1.5844	1.0185
9	.3018	1.8861	1.773	1.8107	1.3203
10	.4527	2.0748	1.9993	1.9993	.8299
11	.5281	2.1879	2.1502	2.1502	1.6598
12	.5281	2.1125	1.773	2.1879	1.6221
13	.4527	2.0748	1.773	2.1879	1.5844
14	.415	2.1125	1.8861	2.1125	1.5089
15	.4904	2.0748	1.8484	2.1879	1.5844
16	.4904	2.1879	1.8861	2.0748	1.5844
17	.415	2.1125	1.6598	2.0748	1.5844
18	.3772	2.0748	1.8107	2.0748	1.5089
19	.3018	1.9993	1.7353	1.8861	1.3203
20	.3018	1.6598	1.6975	1.8107	1.2449
21	.2641	1.6598	1.6598	1.7353	1.094
22			1.5844	1.5089	
23			1.5089		1.0562
24	.1886	.2263	1.5089	1.5466	1.5844
Max	.5281	2.1879	2.1502	2.1879	1.6598
Min	.1509	.2263	1.5089	1.4335	.2263
Avg	.3172	1.6375	1.7296	1.7910	1.0890

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&amp;M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 311 / 22kv Everest Nivara

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3772	.4527	.4904	.5281
2		.3772	.4527	.4904	.4527
3		.3772	.4527	.4904	.4527
4		.3772			.4527
5		.3772		.4527	.3772
6		.3772		.4527	.3772
7		.3772	.4527	.4527	.3772
8		.3772		.4527	.3395
9	.415	.4527	.415	.5281	.3772
10	.5658	.5281	.4527	.4904	.5281
11	.6036	.6036	.4527	.6413	.5281
12	.5658	.5281	.4527	.6413	.4904
13	.6036	.6036	.4904	.679	.5281
14	.6036	.7167	.4904	.6413	.5658
15	.7167	.679	.4527	.7167	.5658
16	.679	.5658	.4904	.7167	.5281
17	.6413	.5658	.4904	.7167	.5658
18	.5658	.5281	.5281	.7167	.5281
19	.6036	.5281	.6036	.679	.5658
20	.5658	.4904	.6036	.679	.6036
21	.4904	.5281	.6036	.6797	.5281
22			.6036	.6036	
23			.5658		.5281
24	.5281	.4527	.4527	.5281	.5281
Max	.7167	.7167	.6036	.7167	.6036
Min	.415	.3772	.415	.4527	.3395
Avg	.5820	.4904	.4980	.5882	.4920

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&amp;M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 312 / 22kv Chunabhatti

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5658	.6413	.7545	.7167
2		.5658	.6413	.7167	.5658
3		.5658	.6413	.7167	.5658
4		.5658		.7167	.5281
5		.5658		.7545	.5281
6		.5658		.7545	.5281
7		.6036	.6413	.7545	.5281
8		.679		.7545	.679
9	.5658	.7167	.7545	.7545	.7545
10	.7167	.9054	.8676	.9054	.9054
11	.6413	.9808	.9054	.9431	.9431
12	.7167	.9808	.9808	.9431	.9054
13	.6413	.9054	.7922	.8676	.9054
14	.679	.7922	.8299	.9054	1.0185
15	.6036	.9431	.7545	.9054	.9054
16	.679	.9808	.7922	.9431	.8676
17	.6036	.8676	.7545	.8676	.9054
18	.679	.9054	.7545	.8299	.8676
19	.6413	.7922	.7167	.8299	.7545
20	.6036	.7922	.7167	1.8861	.7545
21	.6036	.7922	.679	.7545	.7545
22			.7167	.7545	.679
23			.7167		
24	.6036	.5658	.679	.7545	.7167
Max	.7167	.9808	.9808	1.8861	1.0185
Min	.5658	.5658	.6413	.7167	.5281
Avg	.6413	.7545	.7488	.8594	.7512

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&amp;M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 303 / 22KV KUKSHET FEEDER

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8215	.724	.8215	.7545	.7602
2	.8131	.8131	.7316	.7545	.7682
3	.7682	.7682	.7392	.8299	.724
4	.7392	.7164	.7682	.7922	.7087
5	.7316	.724	.724	.7545	.7087
6	.7392	.7316	.7087	.8299	.7164
7	.724	.7316	.7164	1.0185	.724
8	.7392	.7392	.724	.9808	.7964
9	.8589	.8589	.7316	1.0562	.7964
10	1.0185	1.0562	.7762	1.2071	1.1317
11	.9808	1.0185	.7545	.9431	1.2449
12	1.1317	1.094	.7922	.8916	1.1694
13	.8676	.9335	.7922	.8962	.8962
14	.9431	1.105	.8299	.9335	1.094
15	.9808	1.0185	.7545	1.0562	1.094
16	.9335	.9808	.7167	1.0185	.9808
17	.7964	1.0562	.7922	.9054	.8299
18	.724	1.0185	.7545	.724	.7922
19	.7164	.8962	.679	.7164	.7545
20	.6859	.8215	.7545	.7164	.724
21	.6859	.7842	.7167	.663	.7164
22	.7164	.7468	.679	.6859	.6859
23	.724	.7842		.7011	.7087
24	.7842	.7164	.7842	.7922	.7164
Max	1.1317	1.105	.8299	1.2071	1.2449
Min	.6859	.7164	.679	.663	.6859
Avg	.8177	.8682	.7496	.8592	.8434

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&amp;M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 304 / 22KV TATA TELE

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669	1.0669	1.0669	1.094	1.0669
2	1.0669	1.0669	1.0669	1.1317	1.0669
3	1.0288	1.0669	1.0288	1.0562	1.0669
4	1.0288	1.0288	1.0288	1.0562	1.0288
5	.9907	.9907	.9907	1.094	.9907
6	1.0288	.9907	.9907	1.2071	.9907
7	1.0288	1.0288	1.0669	1.358	1.0288
8	1.105	1.0288	.9907	1.2826	1.1431
9	1.3336	1.0669	1.0288	1.4335	1.2574
10	1.3717	1.1812	1.0669	1.3203	1.3717
11	1.4098	1.2193	1.094	1.448	1.4861
12	1.448	1.2574	1.0562	1.448	1.448
13	1.4861	1.2955	1.1317	1.4098	1.3717
14	1.4098	1.2574	1.1317	1.448	1.448
15	1.4098	1.2193	1.094	1.4098	1.4861
16	1.4098	1.2574	1.094	1.4098	1.448
17	1.3336	1.1812	1.1317	1.3717	1.3717
18	1.2955	1.1431	1.0562	1.3336	1.3336
19	1.2574	1.0669	.9808	1.2193	1.2193
20	1.1431	1.0669	.9808	1.1431	1.105
21	1.0669	1.0669	1.0562	1.0288	1.0669
22	1.0288	1.0288	1.0562	1.0669	1.0669
23	1.0288	1.0288		1.0288	1.0669
24	1.0288	1.0288	1.0288	1.0562	1.0288
Max	1.4861	1.2955	1.1317	1.448	1.4861
Min	.9907	.9907	.9808	1.0288	.9907
Avg	1.2003	1.1098	1.0530	1.2440	1.2066



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&amp;M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 305 / 22KV NANDKAMAL + HPCL NON SHEDDABLE EXPRESS HV FEEDERS  
 EXPRESS Feeder KV- 22 / (CONTINUOUS PROCESS)(NO STAGGERING)  
 OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	.9907	1.0669		1.0288
2	1.2193	.9526	1.0288	1.0185	1.0288
3	1.105	.8383	1.0288	.9808	.9526
4	1.2574	.8002	.9526	1.0562	.9907
5	1.105	.6478	.8764	1.1694	1.0669
6	1.0669	.4954	.9145	1.2826	1.0288
7	1.1431	.8383	.8764	1.3957	1.1431
8	1.3336	.9145	.8764	1.5466	1.5242
9	1.1431	.9145	.9145	1.5844	1.6004
10	1.4098	.9145	.9145	1.5089	1.6766
11	1.4861	.8383	.9054	1.5242	1.6385
12	1.6004	.8002	.9431	.9145	1.5623
13	1.4861	.5716	1.0185	.8764	1.448
14	1.448	1.1431	.9808	.7621	1.6004
15	1.4098	.9907	.9431	.8383	.9907
16	1.448	1.0669	.9054	.7621	1.2955
17	1.4861	1.0288	.9808	.724	1.448
18	1.448	1.0288	.9054	.9907	1.4861
19	1.1812	.9145	.9808	.8764	1.1812
20	1.0288	.9907	.9054	1.1812	1.0669
21	1.1431	.9526	.9808	1.105	.9526
22	.4191	.8764	.9431	1.0669	.9145
23	.4191	1.0288		1.0288	.8764
24	1.1812	.9526	.9907	.9808	1.0288
Max	1.6004	1.1431	1.0669	1.5844	1.6766
Min	.4191	.4954	.8764	.724	.8764
Avg	1.2130	.8955	.9493	1.0945	1.2305

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&amp;M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 307 / 22KV Amines

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3624	2.0576	1.0669	1.0562	.9145
2	2.3243	.8002	1.105	1.0562	2.1719
3	2.2862	.8764	1.0288	1.094	2.21
4	2.2481	.9145	1.0669	1.1317	2.2481
5	2.3624	.9145	.9907	1.094	2.21
6	2.2862	.9145	1.105	1.1694	2.2862
7	2.21	.8383	.9907	1.1317	2.1338
8	2.5911	.8764	1.1812	1.2449	1.2193
9	2.5149	1.0288	1.2574	1.2826	1.5623
10	2.553	1.105	1.448	1.2071	1.829
11	2.3624	1.448	1.3957	1.5242	1.9814
12	2.5149	1.6766	1.4335	1.3717	2.1719
13	2.4387	1.3717	1.358	1.3336	1.9814
14	2.3624	1.6004	1.2826	1.2193	2.0957
15	2.4006	1.3717	1.1694	1.448	2.0957
16	2.3243	1.3336	1.2449	1.1812	1.829
17	2.2862	1.448	1.2071	1.1431	1.9433
18	2.4768	1.448	1.1694	1.2193	1.829
19	2.3624	1.2955	1.094	1.105	1.829
20	2.2862	1.1812	1.094	1.1812	1.6004
21	2.2862	1.1431	1.0562	1.0669	1.5623
22	2.0195	1.105	1.0562	.8383	1.5623
23	2.0576	.9907		.8383	1.5242
24	2.4387	2.0957	.9907	1.0185	.8764
Max	2.5911	2.0957	1.448	1.5242	2.2862
Min	2.0195	.8002	.9907	.8383	.8764
Avg	2.3481	1.2431	1.1649	1.1649	1.8195

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&amp;M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 308 / 22KV Vishal

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.4191	.415	.381
2	.4191	.381	.4191	.4527	.3429
3	.381	.381	.381	.415	.381
4	.4191	.381	.4191	.4527	.381
5	.4191	.4191	.4572	.415	.381
6	.381	.4191	.4191	.3772	.4191
7	.4191	.381	.4191	.415	.381
8	.3429	.381	.381	.4527	.3429
9	.4191	.4191	.4191	.415	.381
10	.381	.3429	.381	.3772	.381
11	.3429	.381	.3772	.4191	.381
12	.381	.381	.415	.381	.4191
13	.381	.3429	.3772	.381	.381
14	.381	.381	.415	.381	.4191
15	.4191	.4572	.415	.4191	.381
16	.381	.381	.4527	.4191	.4191
17	.381	.381	.415	.3429	.4191
18	.4191	.4572	.3772	.381	.6478
19	.4572	.4572	.4527	.4572	.4572
20	.4191	.4954	.415	.4572	.4191
21	.4572	.4572	.4527	.4191	.381
22	.4191	.4191	.415	.4191	.4572
23	.4191	.4191		.381	.4191
24	.4191	.381	.4572	.415	.381
Max	.4572	.4954	.4572	.4572	.6478
Min	.3429	.3429	.3772	.3429	.3429
Avg	.4016	.4032	.4153	.4108	.4064

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&amp;M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 309 / 22KV R &amp; D

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.7468	.7095	.7545	.8215
2	.6348	.7842	.7468	.7167	.8215
3	.6722	.7468	.7095	.7167	.8589
4	.7095	.8215	.6722	.7922	.7842
5	.6722	.8589	.6348	.8299	.7842
6	.6722	.8589	.7095	.7545	.7842
7	.7095	.4854	.5975	.8676	.5975
8	.6348	.6348	.6348	.7922	.6722
9	.7468	.8215	.6348	.9054	.7468
10	.7468	.8589	.6722	.9808	.9335
11	.7095	.7842	.679	.9709	1.1203
12	.8215	.8962	.7545	.9335	.8962
13	.7095	.9335	.7167	1.1203	.9335
14	.6722	.8962	.8299	1.1203	.9335
15	.6348	1.0082	.7922	1.0082	.8589
16	.6348	.9335	.7545	.8589	.8215
17	.4481	.7842	.7167	.6722	.5975
18	.4481	.8589	.7545	.5601	.6878
19	.4108	.8215	.7545	.4481	.6348
20	.6348	.7842	.679	.5975	.5601
21	.5601	.8589	.6413	.5975	.5601
22	.6348	.8962	.679	.6348	.6722
23	.5975	.7468		.8589	.6348
24	.5975	.5975	.6722	.7167	.7842
Max	.8215	1.0082	.8299	1.1203	1.1203
Min	.4108	.4854	.5975	.4481	.5601
Avg	.6364	.8091	.7020	.8004	.7708

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&amp;M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 310 / 22KV Alkali Group ( Manish ) Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6766	1.5242	1.6385	1.5466	1.6004
2	1.7147	1.4861	1.6004	1.4712	1.5242
3	1.7528	1.4098	1.6766	1.4712	1.5623
4	1.6385	1.2955	1.5623	1.4335	1.4861
5	1.6004	1.2193	1.6004	1.5466	1.448
6	1.7147	1.2955	1.5242	1.6598	1.448
7	1.5242	1.1812	1.5242	1.6975	1.3717
8	1.5623	1.105	1.4098	1.7353	1.3717
9	1.5242	1.2574	1.5623	1.7353	1.3336
10	1.6004	1.6004	1.7528	1.8484	1.7147
11	1.448	1.6004	1.6975	2.1338	1.8671
12	1.4098	1.7909	1.5466	2.0957	1.9814
13	1.6766	1.8671	1.5844	1.7909	2.1338
14	1.7909	1.9433	1.4712	1.6385	2.2862
15	1.4861	1.829	1.358	2.0576	2.21
16	1.7909	1.9814	1.1694	1.829	2.3624
17	1.2955	1.6385	1.1317	2.2862	2.2481
18	1.448	1.8671	1.2071	1.5242	1.6385
19	1.105	1.3336	1.1317	1.5623	1.3717
20	1.0288	1.1431	1.2826	1.3717	1.4098
21	.9145	1.1812	1.358	1.5623	1.2574
22	.9907	1.6385	1.4335	1.2193	1.6385
23	1.4098	1.6766		1.7528	1.7909
24	1.7147	1.448	1.5623	1.6221	1.5242
Max	1.7909	1.9814	1.7528	2.2862	2.3624
Min	.9145	1.105	1.1317	1.2193	1.2574
Avg	1.4924	1.5130	1.4689	1.6913	1.6909

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&amp;M S/DN.[127] BU 4127

Substation No/ Name :- 284060 / 33/11KV Vashi, Sector- 19D

S/S

Feeder No / Name : 202 / 11 KV 'L' WING DANA MARKET

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1886	.1886	.1715	.1543
2	.1715	.1715	.1886	.1543	.1372
3	.1543	.1543	.1715	.1372	.1372
4	.1543	.1372	.1543	.1372	.1543
5	.1372	.12	.1372	.1372	.12
6	.1372	.12	.1543	.1372	.1543
7	.12	.12	.12	.1029	.1372
8	.1372		.12	.1029	.12
9	.1543	.1372	.12	.12	.1543
10	.2915	.3086	.1372	.3086	.3258
11		.4973	.1543	.5316	.5258
12		.5658	.1543	.6001	.5144
13		.5316	.1715	.5487	.5609
14	.6516	.5487	.1886	.5487	.5434
15	.6344	.583	.1543	.5658	.5487
16	.6001	.6001	.1715	.5658	.5658
17	.583	.5658	.1886	.5658	.6001
18	.583	.6001	.1886	.5658	.6001
19	.5487	.5316	.2229	.4973	.463
20	.3601	.3601	.1886	.3601	.3086
21	.2743	.2572	.1886	.2915	.2229
22	.2229	.2058	.1886	.1886	.1715
23	.2229	.1886	.1886	.1543	.1715
24	.1886	.2058	.1886	.1715	.1543
Max	.6516	.6001	.2229	.6001	.6001
Min	.12	.12	.12	.1029	.12
Avg	.3095	.3347	.1679	.3194	.3144

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&amp;M S/DN.[127] BU 4127

Substation No/ Name :- 284060 / 33/11KV Vashi, Sector- 19D

S/S

Feeder No / Name : 203 / 11 KV 'C' WING MASALA

SHEDDABLE URBAN

MARKET Feeder KV- 11 /  
OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.583	.583	.4801	.6001
2	.4458	.5658	.5316	.5316	.5316
3	.4287	.5658	.4973	.5658	.5316
4	.3772	.5144	.5144	.583	.5316
5	.3772	.5144	.5316	.6173	.5487
6	.4458	.5316	.583	.6001	.583
7	.583	.5487	.3944	.5658	.583
8	.5658	.463	.583	.6516	.6001
9	.7373	.7373	.6859	.7202	.7545
10	1.0117	.9088	.6516	1.0631	1.0117
11		1.5432	.6859	1.3032	1.2517
12		1.5432	.703	1.5089	1.5432
13		1.5432	.703	1.6118	1.6118
14		1.5089	.703	1.4575	1.3889
15	1.6804	1.5432	.6687	1.5604	1.4575
16	1.6461	1.4918	.6516	1.4403	1.6632
17	1.5432	1.4403	.4801	1.4746	1.3889
18	1.4232		.6344	1.4232	1.3375
19	1.3546	1.1488	.703	1.2689	1.2689
20		1.0974	.703	1.0974	1.0631
21	.9088	.2572	.703	.7373	.6687
22	.7545	.7545	.7202	.9088	.7202
23	.703	.703	.4801	.5144	.4973
24	.463	.6516	.6344	.4801	.6687
Max	1.6804	1.5432	.7202	1.6118	1.6632
Min	.3772	.2572	.3944	.4801	.4973
Avg	.8366	.9200	.6137	.9652	.9502

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&amp;M S/DN.[127] BU 4127

Substation No/ Name :- 284060 / 33/11KV Vashi, Sector- 19D

S/S

Feeder No / Name : 207 / 11 KV UTI SUB STATION

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4746	1.4403	1.3375	1.4575	1.4232
2	1.4575	1.406	1.3375	1.3889	1.3375
3	1.4232	1.3717		1.1317	1.2517
4	1.3546	1.3717	1.0631	1.1145	1.1488
5	1.2003	1.3717	1.0974	1.2689	1.3203
6	1.1145	1.4403	1.2003	1.3375	1.4575
7	1.8861	1.5432	1.4403	1.749	1.6118
8	1.8347	1.6289	1.6804	1.6118	1.749
9	1.8176	1.749	1.7661	1.7147	1.6632
10	1.9719	1.7147	1.6632	1.7318	1.7002
11		1.5261	1.7318	1.5432	1.5261
12		1.5261	1.1774	1.4746	1.2971
13		1.5775	1.5432	1.5089	1.3847
14	1.749	1.2517	1.4746	1.3889	1.3321
15	1.4232	1.2689	1.3375	1.3375	1.3203
16	1.3889	1.286	1.406	1.3375	1.286
17	1.5775	1.5089	1.5089	1.3375	1.286
18	1.6118	1.749	1.4746	1.6804	1.5432
19	1.7147	1.7833	1.6804	1.8004	1.7318
20	1.8176	1.869	1.6461	1.6118	1.7528
21	1.749	1.8176	1.6804	1.6289	1.6289
22	1.6118	1.7833	1.749	1.6975	1.5947
23	1.4746	1.6461	1.6118	1.6804	1.5775
24	1.5775	1.4575	1.3375	1.4403	1.5432
Max	1.9719	1.869	1.7661	1.8004	1.7528
Min	1.1145	1.2517	1.0631	1.1145	1.1488
Avg	1.5824	1.5454	1.4759	1.4989	1.4778



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&amp;M S/DN.[127] BU 4127

Substation No/ Name :- 284060 / 33/11KV Vashi, Sector- 19D

S/S

Feeder No / Name : 208 / 11 KV SUNVILL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6344	.7202	.7202	.6001
2	.6516	.6173	.583	.6687	.5316
3	.6344	.6001	.5316	.6001	.4973
4	.6001	.6173		.583	.5487
5	.6516	.6516	.6344	.6344	.6173
6	.7202	.7373	.6344	.7373	.7202
7	.8402	.8059	.6859	.9088	.8573
8	.7716	.8402	.6859	.8745	.8402
9	.9431	.9431	.8059	1.046	
10	.9602	.9602	.5258	.9774	1.0277
11		1.046	.9259	.9774	1.0288
12		.9602	.8916	.9088	.8916
13		.8916	.823	.8916	.9431
14	.8916	.7545	.7716	.703	.7888
15	.7202	.7202	.7716	.6001	.7545
16	.7373	.7202	.823	.7202	.7373
17	.7373	.8059	.8059	.7202	.7202
18	.7888	.8916	.8402	.7888	.7373
19	.9431	.8916	.9431	.8745	.8402
20	.8573	.9088	.9088	.8402	.8059
21	.8402	.8916	.8916	.823	.8402
22	1.6118	.8402	.8573	.8059	.7373
23	.7716	.8059	.8059	.7545	.7373
24	.703	.6687	.7202	.7373	.6859
Max	1.6118	1.046	.9431	1.046	1.0288
Min	.6001	.6001	.5258	.583	.4973
Avg	.8124	.8002	.7646	.7873	.7604