Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD -I S/DN[105] **BU 0990**
Substation No/ Name :- 254002 / KOLEWADI
Feeder No / Name : 201 / KIRPE **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.7373	.6249	.6859	.0343	.0343
2	.0343	.0343	.7373	.6249	.6859	.0343	.0343
3	.0343	.0343	.7716	.6249	.6859	.0343	.0343
4	.0343	.0343	.7716	.6249	.7202	.0343	.0343
5	.0343	.0343	.823	.6401	.7716	.0343	.0343
6	.0343	.0343	.8745	.7773	.8573	.0343	.0343
7	.0343	.0343	1.046	.8535	.9259	.0343	.0343
8	.0343	.0343	1.1145	.8993	.8573	.0343	.0343
9	1.0974	.8688	.0343	.0343	.0343	1.1317	1.1488
10	1.0669	1.166	.0343	.0343	.0343	1.0974	1.3717
11	1.0669	1.1831	.0343	.0343	.0343	1.5089	
12	1.0822	1.2003	.0343	.0343	.0343	1.3717	
13	1.0974	1.2174	.0343	.0343	.0343	1.2346	1.2689
14	1.1279	1.166	.0343	.0343	.0343	1.3717	1.2346
15	1.1888	1.3203	.0343	.0343	.0343	1.3717	1.2689
16	1.1888	1.3375	.0343	.0343	.0343	1.3375	1.2689
17	.0343	.0343	.0343	.0343	.0343	.0343	.0343
18	.0343	.0343	.0343	.0343	.0343	.0343	.0343
19	.0343	.0343	.0343	.0343	.0343	.0343	.0343
20	.0343	.0343	.0343	.0343	.0343	.0343	.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	.0343
22	.0343	.0343	.0343	.0343	.0343	.0343	.0343
23	.0343	.0343	.0343	.0343	.0343	.0343	.0343
24	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Max	**1.1888**	**1.3375**	**1.1145**	**.8993**	**.9259**	**1.5089**	**1.3717**
Min	**.0343**	**.0343**	**.0343**	**.0343**	**.0343**	**.0343**	**.0343**
Avg	**.3944**	**.4170**	**.3094**	**.2591**	**.2808**	**.4573**	**.3687**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD -I S/DN[105] **BU 0990**
Substation No/ Name :- 254002 / KOLEWADI
Feeder No / Name : 202 / CHACHEGAON GAOTHAN **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	.0343	.0343	.0343	.0343
2	.0343	.0343	.0343	.0343	.0343	.0343	.0343
3	.0343	.0343	.0343	.0343	.0343	.0343	.0343
4	.0343	.0343	.0343	.0343	.0343	.0343	.0343
5	.0343	.0343	.0343	.0343	.0343	.0343	.0343
6	.0343	.0343	.0343	.0343	.0343	.0343	.0343
7	.0343	.0343	.0343	.0343	.0343	.0343	.0343
8	.0343	.0343	.0343	.0343	.0343	.0343	.0343
9	.0343	.0343	.0343	.0343	.0343	.0343	.0343
10	.0343	.0343	.0343	.0343	.0343	.0343	.0343
11	.0343	.0343	.0343	.0343	.0343	.0343	
12	.0343	.0343	.0343	.0343	.0343	.0343	
13	.0343	.0343	.0343	.0343	.0343	.0343	.0343
14	.0343	.0343	.0343	.0343	.0343	.0343	.0343
15	.0343	.0343	.0343	.0343	.0343	.0343	.0343
16	.0343	.0343	.0343	.0343	.0343	.0343	.0343
17	.0343	.0343	.0343	.0343	.0343	.0343	.0343
18	.0343	.0343	.0343	.0343	.0343	.0343	.0343
19	.0343	.0343	.0343	.0343	.0343	.0343	.0343
20	.0343	.0343	.0343	.0343	.0343	.0343	.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	.0343
22	.0343	.0343	.0343	.0343	.0343	.0343	.0343
23	.0343	.0343	.0343	.0343	.0343	.0343	.0343
24	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Max	**.0343**	**.0343**	**.0343**	**.0343**	**.0343**	**.0343**	**.0343**
Min	**.0343**	**.0343**	**.0343**	**.0343**	**.0343**	**.0343**	**.0343**
Avg	**.0343**	**.0343**	**.0343**	**.0343**	**.0343**	**.0343**	**.0343**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD -I S/DN[105] **BU 0990**
Substation No/ Name :- 254002 / KOLEWADI
Feeder No / Name : 203 / DHEBEWADI **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2743	.2058	.2229	.2401	.2743	.2401
2	.2743	.2743	.2058	.2058	.2401	.2743	.2401
3	.3086	.2743	.2058	.2058	.2401	.2743	.2401
4	.3086	.2743	.2572	.2572	.3086	.3429	.2743
5	.3772	.3086	.3429	.3429	.3429	.3772	.3258
6	.4458	.4115	.4458	.4458	.4801	.4801	.4801
7	.6859	.6516	.6516	.6249	.7545	.7202	.7202
8	.6859	.6859	.6173	.6401	.6859	.7545	.7202
9	.6859	.6173	.5144	.6173	.583	.6859	.6859
10	.583	.6516	.4115	.4458	.4801	.6859	.583
11	.4801	.583	.4801	.4287	.4115	.6859	
12	.4458	.5144	.4801	.3772	.4458	.6173	
13	.4115	.4458	.3429	.3429	.4801	.4801	.3429
14	.3772	.3772	.3429	.3772	.4458	.3772	.3772
15	.4115	.4115	.3772	.4458	.4458	.5487	.4115
16	.5658	.583	.4801	.4801	.4801	.4458	.4801
17	.5658	.6516	.4973	.4458	.6173	.583	.4458
18	.583	.6516	.4801	.583	.4801	.7202	.583
19	.7926	.8916	.7773	.8916	.8573	.8573	.7888
20	.7621	.7888	.7316	.823	.823	.823	.7888
21	.6859	.6859	.6097	.7202	.7202	.6859	.7202
22	.5487	.4115	.5316	.5658	.5144	.5144	.5144
23	.3258	.2743	.3258	.3429	.3429	.3086	.3429
24	.2743	.2915	.2401	.2572	.2743	.2743	.2401
Max	**.7926**	**.8916**	**.7773**	**.8916**	**.8573**	**.8573**	**.7888**
Min	**.2743**	**.2743**	**.2058**	**.2058**	**.2401**	**.2743**	**.2401**
Avg	**.4942**	**.4994**	**.4398**	**.4621**	**.4873**	**.5330**	**.4793**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD -I S/DN[105] **BU 0990**
Substation No/ Name :- 254002 / KOLEWADI
Feeder No / Name : 204 / KOLE **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1372	.12	.12	.12	.1372	.1372
2	.1372	.1372	.12	.12	.12	.1372	.1372
3	.1372	.1372	.1372	.12	.12	.1372	.1372
4	.1372	.1372	.1543	.1372	.1543	.1715	.1715
5	.1715	.1715	.1886	.1886	.1715	.2058	.1886
6	.2401	.2229	.2229	.2058	.2572	.2572	.2401
7	.3772	.3429	.3086	.3601	.3429	.3258	.3258
8	.3086	.3601	.2743	.3601	.3601	.2743	.3258
9	.2743	.3086	.2915	.3258	.2572	.2915	.2743
10	.2743	.2915	.2401	.2743	.2401	.2229	.2058
11	.2572	.2229	.2401	.2401	.2401	.2058	
12	.2401	.2401	.2572	.2401	.2401	.2229	
13	.2401	.2401	.2572	.2401	.2058	.2058	.1715
14	.2229	.2401	.2229	.2058	.2058	.2058	.1715
15	.2401	.2058	.2229	.2058	.823	.2058	.1715
16	.2572	.2401	.1886	.1715	.1715	.1715	.2058
17	.2401	.2229	.2401	.2058	.2058	.1715	.1715
18	.2401	.2229	.1886	.1886	.2058	.2229	.2401
19	.3772	.3772	.3601	.3944	.3429	.3429	.3258
20	.3944	.3258	.3772	.3601	.3086	.3772	.2743
21	.3429	.3086	.3429	.3086	.2915	.3086	.2743
22	.2743	.2058	.2572		.2401	.2401	.2743
23	.2058	.1543	.1715	.1715	.1543	.1886	.2058
24	.1372	.1715	.12	.1372	.1372	.1372	.1372
Max	**.3944**	**.3772**	**.3772**	**.3944**	**.823**	**.3772**	**.3258**
Min	**.1372**	**.1372**	**.12**	**.12**	**.12**	**.1372**	**.1372**
Avg	**.2444**	**.2344**	**.2293**	**.2296**	**.2465**	**.2236**	**.2167**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD -I S/DN[105] **BU 0990**
Substation No/ Name :- 254002 / KOLEWADI
Feeder No / Name : 205 / CHACHEGAON AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.2743	.0343	.0343	.0343	.3944	.3258
2	.2058	.2743	.0343	.0343	.0343	.3944	.3258
3	.2058	.2743	.0343	.0343	.0343	.3944	.3258
4	.2058	.2743	.0343	.0343	.0343	.4287	.3429
5	.2743	.3086	.0343	.0343	.0343	.4287	.3772
6	.3429	.3944	.0343	.0343	.0343	.463	.4801
7	.4801	.5316	.0343	.0343	.0343	.6687	.6173
8	.0343	.6001	.0343	.0343	.0343	.6687	.6516
9	.0343	.0343	.6001	.6687	.6173	.0343	.0343
10	.0343	.0343	.6554	.8059	.6516	.0343	.0343
11	.0343	.0343	.7316	.8059	.7545	.0343	
12	.0343	.0343	.7164	.7716	.823	.0343	
13	.0343	.0343	.7468	.7716	.823	.0343	.0343
14	.0343	.0343	.7926	.7716	.823	.0343	.0343
15	.0343	.0343	.7773	.7716	.823	.0343	.0343
16	.0343	.0343	.6859	.8059	.823	.0343	.0343
17	.0343	.0343	.0343	.0343	.0343	.0343	.0343
18	.0343	.0343	.0343	.0343	.0343	.0343	.0343
19	.0343	.0343	.0343	.0343	.0343	.0343	.0343
20	.0343	.0343	.0343	.0343	.0343	.0343	.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	.0343
22	.0343	.0343	.0343	.0343	.0343	.0343	.0343
23	.0343	.0343	.0343	.0343	.0343	.0343	.0343
24	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Max	**.4801**	**.6001**	**.7926**	**.8059**	**.823**	**.6687**	**.6516**
Min	**.0343**	**.0343**	**.0343**	**.0343**	**.0343**	**.0343**	**.0343**
Avg	**.1000**	**.1450**	**.2606**	**.2801**	**.2786**	**.1829**	**.1785**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD -I S/DN[105] **BU 0990**
Substation No/ Name :- 254002 / KOLEWADI
Feeder No / Name : 206 / TALMAVALE AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.823	1.1126	1.1831	.0343	.0343
2	.0343	.0343	.8573	1.1126	1.2003	.0343	.0343
3	.0343	.0343	.8745	1.1126	1.2003	.0343	.0343
4	.0343	.0343	.8916	1.1126	1.2003	.0343	.0343
5	.0343	.0343	.9602	1.1431	1.2346	.0343	.0343
6	.0343	.0343	1.0288	1.2346	1.3032	.0343	.0343
7	.0343	.0343	1.0288	1.4632	1.4403	.0343	.0343
8	.0343	.0343	1.1488	1.5699	1.6118	.0343	.0343
9	1.9204	1.7375	.0343	.0343	.0343	2.0062	2.8807
10	1.9509	2.2119	.0343	.0343	.0343	2.7435	2.8121
11	1.9814	2.4863	.0343	.0343	.0343	3.0178	
12	2.1338	2.4006	.0343	.0343	.0343	2.8807	
13	2.21	2.3491	.0343	.0343	.0343	2.7435	2.8464
14	2.2253	2.4691	.0343	.0343	.0343	2.6063	2.7435
15	2.2405	2.0748	.0343	.0343	.0343	2.8807	2.8807
16	2.1643	2.3491	.0343	.0343	.0343	2.7435	2.8807
17	.0343	.0343	.0343	.0343	.0343	.0343	.0343
18	.0343	.0343	.0343	.0343	.0343	.0343	.0343
19	.0343	.0343	.0343	.0343	.0343	.0343	.0343
20	.0343	.0343	.0343	.0343	.0343	.0343	.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	.0343
22	.0343	.0343	.0343	.0343	.0343	.0343	.0343
23	.0343	.0343	.0343	.0343	.0343	.0343	.0343
24	.7964	.0343	.0343	.0343	.0343	.0343	.0343
Max	**2.2405**	**2.4863**	**1.1488**	**1.5699**	**1.6118**	**3.0178**	**2.8807**
Min	**.0343**	**.0343**	**.0343**	**.0343**	**.0343**	**.0343**	**.0343**
Avg	**.7557**	**.7761**	**.3401**	**.4338**	**.4551**	**.9238**	**.7997**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD -I S/DN[105] **BU 0990**
Substation No/ Name :- 254007 / UNDALE
Feeder No / Name : 201 / YELGAON **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.4854	.5144	.4915	.5658	.4854	.4458
2	.4458	.4668	.4973	.4915	.5487	.4668	.4458
3	.4458	.4481	.4801	.4915	.5316	.4481	.4458
4	.4458	.4481	.4973	.4915	.5487	.4668	.4458
5	.5144	.5601	.5487	.6226	.6859	.5601	.5144
6	.8573	.9709	.6344	.7373	.8573	.9335	.8573
7	1.1145	1.1203	.9774	1.1469	1.286	1.1949	.9602
8	.9945	1.1763	.9774	1.2616	1.2346	1.1389	1.0288
9	.7956	1.0631	.7842	.7716	.9896	1.6461	1.704
10	.8916	1.2174	.6161	.7282	.7468	1.8233	2.0919
11	.8573	1.2346	.5601	.5975	.7282	1.757	2.0919
12	.8916			.5788	.6348	1.1271	2.0576
13	.3258	.9945		.6161	.5415	1.8564	2.0576
14	.3601	1.0974	.4668	.5601	.5601	1.989	2.1091
15	1.0288	1.1145	.5487	.5228	.5788	1.9559	2.0576
16	.5144	1.1145	.5487	.5415	.5975	1.8896	2.0576
17	.4854	.6161	.6173	.5975	.6161	.5144	.6535
18	1.0082	1.0082	.9774	1.0642	.9522	.8745	1.0456
19	1.9044	1.7924	1.6289	1.7177	1.7364	1.5947	1.8111
20	1.8111	1.7364	1.5775	1.6804	1.643	1.5432	1.7551
21	1.6804	1.5123	1.3375	1.5123	1.531	1.3203	1.587
22	1.2136	1.0456	.9602	1.0829	1.1763	.9259	1.1949
23	.7282	.6161	.5487	.7282	.6722	.5658	.7655
24	.4458	.5041	.4668	.4115	.4668	.5228	.4458
Max	**1.9044**	**1.7924**	**1.6289**	**1.7177**	**1.7364**	**1.989**	**2.1091**
Min	**.3258**	**.4481**	**.4668**	**.4115**	**.4668**	**.4481**	**.4458**
Avg	**.8419**	**.9714**	**.7621**	**.8102**	**.8512**	**1.1500**	**1.2762**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD -I S/DN[105] **BU 0990**
Substation No/ Name :- 254007 / UNDALE
Feeder No / Name : 202 / YEWATI **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.6464	.3086	.3429	.3429	.788	.7537
2	.3772	.6299	.2915	.3429	.2915	.7712	.7537
3	.3772	.6299	.2743	.3429	.2915	.7545	.7537
4	.3772	.6464	.2915	.3429	.3086	.8048	.7537
5	.4458	.6962	.3258	.4115	.3944	.8383	.8192
6	.7888	1.0111	.6344	.6516	.7202	1.2742	1.5729
7	1.1317	1.2266	.8916	.9602	1.0117	1.6766	1.9662
8	1.0631	1.1437	.8402	.9259	.9774	1.6598	1.7695
9	.6344	.703	1.4754	1.5912	1.7901	.5487	.6859
10	.5487	.4973	1.6876	1.8896	2.0957	.6344	.5658
11	.4801	.4801	1.7695	2.0222	2.1795	.6173	.5144
12	.4801	.4115	1.5074	1.8564	1.9509	.6001	.2058
13	.4287	.3772	1.5729	1.9393	2.1125	.5487	.4801
14	.463	.3429	1.7695	1.8233	1.8275	.5144	.4287
15	.4458	.3429	1.7695	1.8233	1.8778	.4801	.4458
16	.4115	.3772	1.6385	1.8233	1.8945	.5487	.4458
17	.463	.4287	.4801	.5487	.4694	.5487	.4458
18	.6173	.6344	.6859	.7202	.7202	.823	.703
19	1.2003	1.166	1.1317	1.2174	1.2346	1.2346	1.2003
20	1.2174	1.1831	1.0974	1.2346	1.2517	1.2346	1.1317
21	1.1317	.9945	1.0288	1.0631	1.166	1.1317	1.0631
22	.7888	.6516	.6859	.8573	.9088	.823	.823
23	.463	.4458	.4287	.4801	.583	.5144	.5316
24	.7621	.3429	.3601	.3429	.3601	.4458	.3772
Max	**1.2174**	**1.2266**	**1.7695**	**2.0222**	**2.1795**	**1.6766**	**1.9662**
Min	**.3772**	**.3429**	**.2743**	**.3429**	**.2915**	**.4458**	**.2058**
Avg	**.6448**	**.6671**	**.9561**	**1.0647**	**1.1150**	**.8257**	**.7996**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD -I S/DN[105] **BU 0990**
Substation No/ Name :- 254007 / UNDALE
Feeder No / Name : 203 / UNDALE **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5228	1.0117	1.0159	1.1831	.5601	.5144
2	.5144	.4854	.9945	1.0277	1.166	.5415	.5144
3	.5144	.4854	.9774	1.0277	1.166	.5228	.5144
4	.5144	.5041	.9945	1.0277	1.1831	.5415	.5144
5	.6516	.5601	1.0288	1.094	1.3375	.6535	.6516
6	.8916	1.0082	1.406	1.5074	1.6461	1.0456	.8916
7	1.0288	1.2136	2.0919	2.2542	2.1434	1.1949	1.1317
8	.9945	1.0642	2.1605	2.2283	1.7147	.9896	.9602
9	1.8564	2.0576	.7842	.823	.9335	1.8176	2.7435
10	2.0748	2.452	.8215	.8029	.7842	2.6216	2.0576
11	2.1948	2.5034	.7468	.7282	.7842	2.9492	3.0178
12	2.1948	2.6063	.7468	.7095	.7095	2.982	3.0864
13	2.1948	2.5034	.6173	.7095	.7468	3.0148	3.0864
14	2.1948	2.4691	.6173	.6161	.7468	2.8837	3.1207
15	2.0748	2.5034	.6173	.6348	.7468	3.0803	2.9835
16	1.8861	2.4691	.6173	.6908	.8589	2.8837	2.915
17	.8775	.8402	.6859	.7842	.7842	.7888	.7655
18	1.0456	1.1203	.9602	1.0642	1.0829	1.0288	1.1389
19	1.5123	1.475	1.3717	1.5123	1.531	1.3717	1.4937
20	1.4563	1.4003	1.2346	1.4003	1.419	1.2346	1.3443
21	1.363	1.2136	1.1317	1.2323	1.307	1.166	1.1949
22	1.0456	.8962	.823	.9335	1.0269	.8916	1.0082
23	.6908	.6348	.5487	.7095	.7282	.6173	.7095
24	.7621	.5601	.5415	.4801	.5228	.6161	.5487
Max	**2.1948**	**2.6063**	**2.1605**	**2.2542**	**2.1434**	**3.0803**	**3.1207**
Min	**.5144**	**.4854**	**.5415**	**.4801**	**.5228**	**.5228**	**.5144**
Avg	**1.2937**	**1.3979**	**.9805**	**1.0423**	**1.0939**	**1.4999**	**1.5378**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD -I S/DN[105] **BU 0990**
Substation No/ Name :- 254009 / TAMBVE
Feeder No / Name : 201 / TAMBVE **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4632	1.4251	.2987	.2926	.2378	1.6907	1.643
2	1.4632	1.4251	.2614	.2926	.2195	1.7238	1.7551
3	1.4632	1.4251	.2614	.2926	.2195	1.7238	2.0165
4	1.4632	1.4251	.2987	.2926	.2195	1.7736	2.0911
5	1.4632	1.4754	.2987	.2926	.2926	1.8067	2.2032
6	1.6827	1.576	.5601	.5121	.4938	2.0222	2.2405
7	2.0199	1.8275	.6722	.6584	.6767	2.2874	2.6139
8	2.0485	1.8778	.5975	.439	.5487	2.0388	2.5393
9	.4481	.4854	2.0317	2.1548	2.6886	.4024	.4435
10	.4108	.3658	2.3758	2.4366	2.838	.3292	.3696
11	.3734	.3544	2.343	2.5029	2.8006	.3313	
12	.3734	.3292	2.3594	2.0222	2.7633	.3292	
13	.3734	.3658	2.2939	2.4366	2.6886	.3292	
14	.3734	.3292	2.2611	2.0222	2.6139	.3292	
15	.3734	.3292	2.2447	2.2377	2.5393	.3658	
16	.3361	.2926	2.1792	2.3594	2.4646	.3544	
17	.4108	.3734	.2926	.3658	.2987	.3734	
18	.5359	.5601	.5121	.5304	.5175	.5228	
19	.9335	.9335	.7865	.9328	.9335	.9335	1.0242
20	.9335	.8589	.7316	.823	.8589	.8589	.9511
21	.8962	.7842	.7316	.7499	.7655	.7468	.8413
22	1.2826	.6348	.6219	.6036	.6413	.6722	.7316
23	.415	.3734	.3292	.3292	.3961	.4481	.439
24	.8642	.3018	.2987	.2926	.2743	.3206	.2987
Max	**2.0485**	**1.8778**	**2.3758**	**2.5029**	**2.838**	**2.2874**	**2.6139**
Min	**.3361**	**.2926**	**.2614**	**.2926**	**.2195**	**.3206**	**.2987**
Avg	**.9334**	**.8387**	**1.0684**	**1.0780**	**1.2080**	**.9464**	**1.3876**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD -I S/DN[105] **BU 0990**
Substation No/ Name :- 254009 / TAMBVE
Feeder No / Name : 202 / SAJUR **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.1677	.056	.0732	.0732	.4144	.4854
2	.1463	.1677	.056	.0732	.0732	.4641	.4854
3	.1463	.1677	.0747	.0732	.0732	.4641	.5228
4	.1463	.1677	.0934	.0732	.0732	.4641	.5601
5	.1463	.2012	.0934	.0732	.0732	.4973	.5975
6	.2195	.218	.1494	.128	.128	.6299	.7095
7	.3292	.218	.1494	.1829	.1829	.6796	.8589
8	.3658	.2515	.168	.1829	.1646	.7293	.9709
9	.1307	.1307	.3277	.5304	.5975	.128	.1478
10	.1494	.1132	.5079	.5636	.8962	.1097	.0924
11	.1494	.1097	.5079	.6133	.8962	.1097	
12	.1494	.128	.4588	.5636	.9335	.1097	
13	.112	.1097	.5407	.7293	.8215	.1097	.1109
14	.112	.1097	.5407	.7459	.8215	.1097	.112
15	.1307	.1063	.5243	.7459	.8589	.1284	.112
16	.0934	.128	.5079	.6554	.8589	.1463	.0934
17	.1307	.112	.0183	.1097	.112	.1307	.1097
18	.1663	.1867	.1646	.1646	.1848	.168	.1829
19	.2614	.2614	.2195	.2743	.2614	.2614	.2561
20	.2614	.2241	.2195	.2561	.2427	.2241	.2561
21	.2427	.1867	.2195	.2195	.2054	.2241	.2195
22	.1886	.1494	.1829	.1646	.1886	.1867	.1835
23	.1132	.112	.0914	.0914	.1132	.112	.1063
24	.0914	.0943	.0747	.0732	.0732	.0943	.0934
Max	**.3658**	**.2614**	**.5407**	**.7459**	**.9335**	**.7293**	**.9709**
Min	**.0914**	**.0943**	**.0183**	**.0732**	**.0732**	**.0943**	**.0924**
Avg	**.1720**	**.1592**	**.2478**	**.3067**	**.3711**	**.2790**	**.3303**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD -I S/DN[105] **BU 0990**
Substation No/ Name :- 254009 / TAMBVE
Feeder No / Name : 203 / AREWADI **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.2012	.0373	.0732	.0183	.3315	.3361
2	.1829	.2012	.0373	.0732	.0183	.2984	.3734
3	.1829	.2012	.0373	.0732	.0183	.2984	.3734
4	.1829	.2012	.0373	.0732	.0183	.2984	.4481
5	.1829	.2683	.056	.0732	.0183	.3315	.4854
6	.2561	.3018	.0934	.1097	.0914	.431	.5601
7	.4755	.4359	.2241	.1829	.128	.5304	.5601
8	.439	.4862	.1307	.1463	.1463	.4973	.5601
9	.112	.112	.3932	.5138	.5975	.1097	.1109
10	.112	.0914	.5079	.5801	.7095	.0732	.0924
11	.0934	.0732	.5243	.5636	.7468	.0366	
12	.0934		.5898	.4973	.7468	.0732	
13	.0934	.0549	.639	.5801	.6348	.0366	.0739
14	.0934	.0732	.639	.5636	.6348	.0732	.0747
15	.0934	.0732	.5898	.547	.5975	.0943	.112
16	.0934		.5407	.5407	.5601	.1097	.0747
17	.112	.112	.0914	.0914	.0747	.0747	.0732
18	.1478	.1867	.1463	.128	.1478	.1494	.1829
19	.2614	.2427	.2195	.2195	.2614	.2614	
20	.3174	.2241	.2195	.2378	.2427	.2241	.2126
21	.2427	.2241	.1829	.2012	.1886	.2241	.2195
22	.1886	.1494	.1463	.1463	.1698	.1494	.1772
23	.0754	.056	.0732	.0732	.0943	.0934	.0732
24	.0732	.0566	.056	.0732	.0183	.0566	.056
Max	**.4755**	**.4862**	**.639**	**.5801**	**.7468**	**.5304**	**.5601**
Min	**.0732**	**.0549**	**.0373**	**.0732**	**.0183**	**.0366**	**.056**
Avg	**.1787**	**.1830**	**.2588**	**.2651**	**.2868**	**.2024**	**.2490**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD -I S/DN[105] BU 0990
Substation No/ Name :- 254009 / TAMBVE
Feeder No / Name : 204 / TAMBAVE LIS **PURELY LIS FEEDERS**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.2195	.0373	.2195	.1147	.128
2	.0549	.2195	.3174	.2126	.1147	.128
3	.0549	.2561	.3174	.2195	.1147	.128
4	.0366	.2561	.3174	.2195	.1147	.128
5	.0366	.2561	.3174	.2195	.1147	.128
6	.0366	.2561	.3174	.2195	.1147	.1097
7	.0366	.2561	.3174	.2195	.1147	.1097
8	.0366	.5121	.5601		.2294	.1646
9	.0373	1.0059	.852	.9511	.8589	.128
10	.0373	1.0242	.9667	.9511	.8962	.8413
11	.1494	1.0059	.9667	.9511	.8962	.9145
12	.1494	1.0242	.9175	.9328	.9054	.8596
13	.2614	1.0059	.9012	1.0425	.8962	.8596
14	.2614	1.0059	.9012	.9145	.8962	.823
15	.9709	1.0059	.8848	1.0608	.8962	.4207
16	.2614	.3795	.2458	.2785	.1494	.128
Max	**.9709**	**1.0242**	**.9667**	**1.0608**	**.9054**	**.9145**
Min	**.0366**	**.2195**	**.0373**	**.2126**	**.1147**	**.1097**
Avg	**.1548**	**.6056**	**.5711**	**.5741**	**.4642**	**.3749**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD -I S/DN[105] **BU 0990**
Substation No/ Name :- 254056 / 33/11 KV KALE
Feeder No / Name : 202 / PACHWAD **PURELY LIS FEEDERS**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.013	.0183		.8333	1.1873	.787
2	.0137	.0137	.0114	.8333	1.1873	.787
3	.0137	.0137	.0114	.8333	1.1873	.787
4	.0137	.0137	.012	.8333	1.1873	.787
5	.0137	.016	.012	.8436	1.1873	.787
6	.0145	.016	.0072	.9014	1.2018	.787
7	.4214	.7407	.0097	.9014	1.1873	.787
8	.7499	.7499	.0103	.8905	1.2018	.787
9	.7407	.7499	.0103	.9014	1.1873	.7773
10	.7499	.759	.1907	.9014	1.2176	.7773
11	.7407	.9014	.9014	1.0595	1.2176	.8025
12	.7499	.9014	.7748	1.2018	1.2176	1.0467
13	.0206	.9014	.7432	1.186	1.2176	1.1873
14	.0191	.9014	.9014	1.186	1.2018	1.2018
15	.0191	.9014	.9014	1.186	1.2018	1.2018
16	.2115	.1882	.1882	.1715	.192	.1882
Max	**.7499**	**.9014**	**.9014**	**1.2018**	**1.2176**	**1.2018**
Min	**.013**	**.0137**	**.0072**	**.1715**	**.192**	**.1882**
Avg	**.2816**	**.4866**	**.3124**	**.9165**	**1.1363**	**.8424**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD -I S/DN[105] **BU 0990**
Substation No/ Name :- 254056 / 33/11 KV KALE
Feeder No / Name : 204 / KODOLI AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5719	.6944	.0914	.0526	.064	.8796	.6562
2	.5719	.6859	.0914	.0532	.064	.9105	.9374
3	.5719	.6944	.0914	.0532	.064	.9105	.9842
4	.5719	.6944	.1109	.0543	.064	.9105	1.0311
5	.7099	.7968	.1307	.0934	.0886	1.0467	1.1248
6	.8749	.9962	.1509	.0934	.1086	1.2803	1.3283
7	1.3123	1.3923	.168	.1478	.1595	1.7532	.2572
8	1.4083	1.4706	.1294	.1646	.1463	1.5893	.2058
9	.1267	.1052	1.5708	1.749	1.8947	.1494	.1063
10	.104	.1086	2.0153	1.7814	2.3868	.1267	.1052
11	.1086	.1254	2.2211	2.4531	2.536	.0895	
12	.1075	.1075	2.2211		2.5029	.1075	
13	.1227	.0848	2.4531		2.536	.1267	.0671
14	.1075	.1075	2.4366	2.1628	2.304	.124	.0358
15	.1075	.1075	2.2874	2.4863	2.4366	.0895	.0373
16	.1029	.1075	2.2542	2.4531	2.2119	.0693	.037
17	.124	.124	.1094	.0497	.1029	.0701	.1075
18	.1578	.1433	.1227	.1372	.1387	.124	.1227
19	.1646	.1463	.1267	.1417	.1463	.128	.1294
20	.1646	.1478	.1267	.1417	.1417	.0854	.1097
21	.1646	.1294	.1267	.1267	.1254	.1254	.1097
22	.1086	.1097	.1075	.0886	.1075	.1075	.0914
23	.1086	.0905	.0701	.0709	.0867	.1254	.0905
24	.0905	.1063	.0895	.0701	.0772	.0867	.0886
Max	**1.4083**	**1.4706**	**2.4531**	**2.4863**	**2.536**	**1.7532**	**1.3283**
Min	**.0905**	**.0848**	**.0701**	**.0497**	**.064**	**.0693**	**.0358**
Avg	**.3568**	**.3865**	**.8043**	**.6648**	**.8539**	**.4590**	**.3529**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD -I S/DN[105] BU 0990
Substation No/ Name :- 254064 / 33/11 KV WING
Feeder No / Name : 201 / 11 KV Wing AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4961	.442	.0924	.052	.0943	1.094	.9259
2	.4801	.442	.0934	.0526	.0943	1.1142	.9374
3	.4801	.442	.0934	.0532	.0943	1.1469	.953
4	.4801	.442	.0934	.0532	.0943	1.166	.7202
5	.5761	.4572	.0934	.0701	.0943	1.1984	.7811
6	.7682	.5556	.112	.0876	.0943		.8065
7	.9014	.7253	.1646	.1214	.1509	1.1717	.9842
8	.7042	.6859	.1646	.1214	.1698	1.1683	.9686
9	.064	.0949	1.1431	1.3283	1.3443	.0943	.1132
10	.0648	.1017	1.3108	1.3923	1.4723	.0943	.0373
11	.0972	.0972	1.3413	1.4723	1.4403	.1132	.056
12	.0983	.0625	1.387	1.4243	1.5844	.1132	.0373
13	.0983	.0617	1.3413	1.4403	1.5844	.1132	.056
14	.0972	.0772	1.2492	1.3283	1.5203	.0943	.0373
15	.0983	.0926	1.3546	1.3923	1.4723	.0943	.056
16	.1132	.108	1.3413	1.3443	1.4403	.1132	.0747
17	.1132	.1267	.0949	.1132	.116	.1372	.0754
18	.1132	.1448	.0983	.1132	.1341	.1372	.132
19	.132	.1629	.12	.1698	.1372	.1543	.1886
20	.1509	.1629	.1254	.1509	.1543	.1372	.1509
21	.132	.1646	.1052	.1509	.1372	.1372	.132
22	.132	.1463	.104	.1132	.12	.12	.132
23	.0943	.128	.0686	.0943	.104	.1029	.1132
24	.0686	.0754	.1109	.0514	.0943	.0867	.0857
Max	**.9014**	**.7253**	**1.387**	**1.4723**	**1.5844**	**1.1984**	**.9842**
Min	**.064**	**.0617**	**.0686**	**.0514**	**.0943**	**.0867**	**.0373**
Avg	**.2731**	**.2500**	**.5085**	**.5288**	**.5726**	**.4305**	**.3564**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD -I S/DN[105] **BU 0990**
Substation No/ Name :- 254064 / 33/11 KV WING
Feeder No / Name : 202 / 11 KV Wing Gaothan **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.1844	.1646	.2427	.1543	.1989	.2033
2	.1478	.1844	.168	.2454	.1543	.1638	.1829
3	.1478	.1844	.1867	.2835	.1543	.1638	.1829
4	.1478	.1844	.1867	.3189	.1543	.1943	.1848
5	.2218	.2035	.2614	.3506	.2279	.2591	.2587
6	.3142	.3294	.3258	.3856	.3045	.3239	.3696
7	.4435	.4508	.4938	.4508	.4382	.4049	.499
8	.4066	.4458	.4525	.4334	.4748	.4161	.4805
9	.3521	.4111	.4458	.4251	.4805	.4024	.4572
10	.3887	.4359	.3978	.462	.462	.3978	.3841
11	.3563	.3887	.4096	.4251	.462	.3725	.4163
12	.3605	.3906	.3605	.4066	.4435	.3887	.4207
13	.3277	.3593	.3563	.4066	.3881	.3841	.3841
14	.3239	.3549	.2949	.3696	.3511	.3795	.3841
15	.3277	.3395	.3563		.3881	.3841	.3658
16	.3563	.3395	.3401	.3696	.3881	.3361	.4108
17	.3563	.3801	.3637	.3725	.4191	.462	.3887
18	.373	.439	.3932	.4287	.4458	.5544	.4641
19	.5028	.5611	.4115	.503	.463	.5914	.5316
20	.4908	.5249	.4477	.4681	.4801	.5359	.463
21	.4382	.4207	.3856	.3814	.4458	.462	.4382
22	.3506	.3658	.2947	.3121	.3467	.3696	.3506
23	.2401	.2534	.2743	.1844	.3121	.2587	.2401
24	.1663	.2103	.2172	.2743	.1677	.2254	.2218
Max	**.5028**	**.5611**	**.4938**	**.503**	**.4805**	**.5914**	**.5316**
Min	**.1478**	**.1844**	**.1646**	**.1844**	**.1543**	**.1638**	**.1829**
Avg	**.3204**	**.3476**	**.3329**	**.3696**	**.3544**	**.3596**	**.3618**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD -I S/DN[105] BU 0990
Substation No/ Name :- 254069 / Kalawade
Feeder No / Name : 201 / 11 KV Kasarshirambe Ag Feeder KV- 11 / OUTGOING
SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0972	.1294	.7225	.9088	.8619	.1052	.1029
2	.0972	.1109	.7316	.9259	.8951	.1052	.1029
3	.0972	.1109	.7621	.9088	.8951	.1052	.1029
4	.0972	.1109	.7621	.9259	.9779	.1052	.1029
5	.1017	.1294	.8383	.9259	1.0442	.1227	.1029
6	.12	.1494	.8688	1.226	1.1768	.1402	.1372
7	.12	.1829	1.587	1.7164	1.848	.1509	.1698
8	.1696	.181	1.848	1.8673	1.9728	.1341	.2075
9	1.3817	1.078	.1341	.1509	.1341	1.6876	2.2386
10	1.5708	1.3443	.112	.1509	.116	2.1765	2.4434
11	1.6817	1.4217	.112	.1494	.1017	2.2443	2.4714
12	1.7926	1.6129		.1052	.0838	2.2565	
13	1.8665	1.7078	.0924	.0995		2.3348	1.0164
14	1.8665	1.3283	.132	.1006		2.4143	
15	1.885	1.6484	.0943	.0934			2.2257
16	1.7741	.4334	.0943	.112	.168	1.7004	2.2443
17	.1387	.156	.0972	.1147	.1677	.1578	.1492
18	.1612	.1949	.1612	.1715	.1715	.197	.0876
19	.2218	.2172	.2241	.2149	.1991	.2378	.2195
20	.2033	.2033	.2241	.2033	.1848	.2033	.2218
21	.2033	.2054	.1867	.1867	.1848	.2033	.2054
22	.168	.1494	.1494	.168	.1478	.1478	.168
23	.1294	.128	.1294	.1294	.1075	.1294	.1307
24	.0924	.1294	.0934	.1132	.1109	.1086	.1109
Max	**1.885**	**1.7078**	**1.848**	**1.8673**	**1.9728**	**2.4143**	**2.4714**
Min	**.0924**	**.1109**	**.0924**	**.0934**	**.0838**	**.1052**	**.0876**
Avg	**.6682**	**.5443**	**.4416**	**.4862**	**.5500**	**.7464**	**.6801**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD -I S/DN[105] BU 0990
Substation No/ Name :- 254069 / Kalawade
Feeder No / Name : 202 / 11 KV Malkhed **PURELY LIS FEEDERS**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0648	.0452	.6687	.2984	.3155	1.4232
2	.0648	.0457	.7202	.2984	.3155	2.1605
3	.0648	.0457	.7373	.2984	.3856	2.1605
4	.0648	.0457	.7545	.3149	.4382	2.1434
5	.5087	.0457	.7716	.3149	.5959	2.1434
6	.8573	.6097	1.4232	.9448	1.0166	2.1434
7	1.0682	.8962	1.5844	1.2752	1.1736	2.3765
8	1.0562	1.1088	1.7918	1.5023	1.1736	2.0748
9	1.1576	1.2742	1.6032	1.3916	1.3599	2.3461
10	1.1643	1.475	1.6032	1.442	1.5364	2.0995
11	1.1643	1.4937	1.6057	1.2378	1.9909	2.1849
12	1.1643	1.4415	.298	1.1736	2.0058	2.452
13	1.1827	1.4969	1.4089	1.6263	1.9728	1.9774
14	1.1827	1.7164	1.4251	1.6095	1.7375	
15	1.2197	1.7918	1.6617	1.7353		1.1128
16	1.2567	1.8107	1.6244	1.531	.0648	1.9547
24		.1494		.1109	.0724	
Max	**1.2567**	**1.8107**	**1.7918**	**1.7353**	**2.0058**	**2.452**
Min	**.0648**	**.0452**	**.298**	**.1109**	**.0648**	**1.1128**
Avg	**.8276**	**.9113**	**1.2301**	**1.0062**	**1.0097**	**2.0502**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD -I S/DN[105] BU 0990
Substation No/ Name :- 254069 / Kalawade
Feeder No / Name : 203 / 11KV Kalawade Gaothan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.081	.0924	.0753	.0686	.0663	.0876	.0857
2	.081	.0924	.0762	.0686	.0663	.0876	.0857
3	.081	.0924	.0762	.0686	.0663	.0876	.0857
4	.081	.0924	.0762	.0686	.0663	.0876	.0857
5	.1134	.1109	.1067	.1029	.0829	.1227	.1029
6	.1457	.1494	.1219	.12	.116	.1402	.1372
7	.1526	.1646	.168	.1886	.1848	.1844	.132
8	.1677	.181	.2033	.1886	.2172	.1677	.1886
9	.168	.1406	.1509	.1509	.1341	.1475	.1254
10	.1294	.112	.1307	.132	.0995	.128	.0905
11	.1294	.0937	.1478	.1307	.1017	.1267	.1075
12	.1109	.0949	.1294	.0701	.1006	.0895	.1132
13	.1109	.0949	.1109	.0497	.1174	.1267	.1109
14	.1109	.1107	.0943	.1006	.1006	.128	.1029
15	.1294	.112	.0943	.0934		.12	.1132
16	.1294	.1214	.0943	.0934	.1307	.1134	.1448
17	.1214	.1214	.1457	.1147	.1341	.1578	.1326
18	.1791	.1772	.1791	.1886	.1886	.1791	.1578
19	.2772	.2715	.2614	.2865	.2715	.2561	.2561
20	.2587	.2402	.2427	.2402	.2218	.2402	.2402
21	.2402	.2241	.2241	.2054	.2218	.2218	.2054
22	.168	.1494	.1509	.1494	.1478	.1663	.168
23	.1109	.1097	.0924	.0924	.1254	.1109	.112
24	.0924	.0924	.0934	.0747	.0739	.0905	.0924
Max	**.2772**	**.2715**	**.2614**	**.2865**	**.2715**	**.2561**	**.2561**
Min	**.081**	**.0924**	**.0753**	**.0497**	**.0663**	**.0876**	**.0857**
Avg	**.1404**	**.1351**	**.1353**	**.1270**	**.1320**	**.1403**	**.1324**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD -I S/DN[105] **BU 0990**
Substation No/ Name :- 256005 / 110 KV KALE
Feeder No / Name : 203 / NANDGAON **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3961	.415	1.1279	1.4373	1.4883	.415	.3772
2	.3772	.415	1.1126	1.4373	1.5364	.415	.3772
3	.3772	.415	1.1265	1.4373	1.5364	.3772	.3772
4	.3961	.415	1.1111	1.4706	1.5364	.3961	.3772
5	.4715	.4904	1.1883	1.5971	1.6324	.6602	.4527
6	.6979	.7167	1.5364	1.9044	1.8461	.6979	.6413
7	.9335	.9619	2.0645	2.3644	2.3594	.9054	.7922
8	.7842	.7545	2.3482	2.5587	1.8976	.7922	.7922
9	2.0965	2.1605	.6161	.6348	.5975	2.4453	2.8487
10	2.4166	2.5926	.4481	.5228		2.9635	3.2648
11	2.7206	2.7206		.4668	.4481	2.8502	3.3684
12	2.6558	2.8647		.4668	.462	3.1417	3.1847
13	2.7686	2.7366	.499	.4854	.4435	3.1093	3.1367
14	2.8807	2.7206		.3734	.5041	3.0931	3.1093
15	2.9287	2.372	.5487	.3734	.4435	2.7368	3.0727
16	2.7846	2.5286	.5228	.4294	.4805	2.8487	3.0247
17	.499			.462	.4755	.3881	.3696
18	.6161		.7577	.6219	.6653	.5175	.5487
19	.9808	.961	.9522	.9054	.9522	.9335	.8215
20	.9709	.961	.9522	.9054	.9335	.9335	.7282
21	.9242	.8865	.8488	.811	.9335	.7733	.8299
22	.7545		.6413	.6036	.6979	.6413	.6979
23	.4904		.4338	.4715	.5093	.5093	.5658
24	.3961	.415	.4527	.3961	.415	.4338	.3961
Max	**2.9287**	**2.8647**	**2.3482**	**2.5587**	**2.3594**	**3.1417**	**3.3684**
Min	**.3772**	**.415**	**.4338**	**.3734**	**.415**	**.3772**	**.3696**
Avg	**1.3049**	**1.4252**	**.9644**	**.9640**	**.9911**	**1.3741**	**1.4231**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD -I S/DN[105] BU 0990
Substation No/ Name :- 256005 / 110 KV KALE
Feeder No / Name : 205 / RETHARE SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.4954	.679	.6979	.6979	.4572	.4382
2	.4191	.4572	.6602	.6979	.6979	.4338	.4338
3	.415	.4572	.6602	.6979	.7545	.4338	.415
4	.415	.4572	.6602	.6979	.679	.4338	.4338
5	.4763	.5716	.7167	.8192	.7621	.5144	.5144
6	.7545	.7733	.8192	1.0185	.9997	.811	.7733
7	.8962	.8676	1.1088	1.3121	1.3306	.8488	.8676
8	.8676	.811	1.2936	1.4266	1.3535	.7922	.8865
9	1.2071	1.3306	.6908	.6535	.6535	1.5043	1.8267
10	1.2382	1.5181	.5788	.6161		1.8404	1.9879
11	1.2936	1.5203		.5975	.6535	2.1209	2.0332
12	1.4083	1.4685		.5415	.5788	2.0508	2.1735
13	1.3717	1.4506	.5914	.5415	.5415	1.9281	
14	1.4083	1.4883		.5041	.5601	1.9806	2.0022
15	1.4083	1.3073	.7059	.5415	.4854	2.0157	2.1085
16	1.3717	1.3969	.6154	.6099	.5601	2.0631	2.1559
17	.5544			.6099	.961	.4805	.5175
18	.7207		.8775	.6838	.8029	.5601	.7095
19	1.1883	1.1283	1.1506	1.1317	1.1128	1.094	1.1389
20	1.1576	1.1506	1.094	1.0562	1.0751	1.094	1.0829
21	1.094	1.0185	1.0185	.9997	.9808	.9997	1.0374
22	.9054		.7922		.8299	.8488	.9431
23	.5906		.5144		.5847	.6097	.679
24	.4763	.4763	.4572	.4382	.415	.4763	.4763
Max	**1.4083**	**1.5203**	**1.2936**	**1.4266**	**1.3535**	**2.1209**	**2.1735**
Min	**.415**	**.4572**	**.4572**	**.4382**	**.415**	**.4338**	**.415**
Avg	**.9191**	**1.0072**	**.7842**	**.7679**	**.7857**	**1.0997**	**1.1146**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD -I S/DN[105] **BU 0990**
Substation No/ Name :- 256005 / 110 KV KALE
Feeder No / Name : 206 / KALE **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	.6478	1.1305	1.1961	1.1961	.6668	.679
2	.6097	.6478	1.1305	1.1961	1.1961	.6097	.6859
3	.6478	.6478	1.1305	1.1797	1.1961	.6668	.6668
4	.6668	.7049	1.1305	1.1961	1.2125	.6859	.6668
5	.811	.811	1.21	1.2763	1.326	.8488	.8192
6	1.1506	1.1883	1.4074	1.543	1.6263	1.2637	1.1694
7	1.4563	1.4146	1.8896	1.9951	2.1125	1.3769	1.4523
8	1.2323	1.2071	2.0809	2.0553	2.0809	1.3769	1.2071
9	1.9334	2.0481	.6838	.9335	.9149	2.4806	2.8346
10	2.0243	2.3703	.6838	.8029		2.7044	3.0148
11	2.1464	2.4453		.6908	.6908	2.8346	2.8509
12	2.2283	2.4129		.6653	.7023	2.9959	2.9656
13	2.2611	2.3365		.5359	.6653	2.915	1.5181
14	2.1956	2.2885		.5729	.6283	2.915	2.8182
15	2.2119	2.2245	.9391	.5544	.7095	2.9797	2.8509
16	2.1142	2.1765	.7973	.6099	.7316	2.8807	2.7854
17	.7316			.6219	.7316	.7282	.695
18	.961		1.2012	.924	1.0269	.924	1.0534
19	1.5844	1.6632	1.6057	1.5497	1.6032	1.5844	1.5655
20	1.6221	1.6221	1.587	1.5466	1.5278	1.5089	1.4523
21	1.5655	1.5278	1.4523	1.4146	1.3957	1.4523	1.4523
22	1.3014		1.094		.811	1.2449	1.3203
23	.8299		.7356		.811	.8676	.9808
24	.7167	.6859	.6413	.6036	.5847	.6979	.7356
Max	**2.2611**	**2.4453**	**2.0809**	**2.0553**	**2.1125**	**2.9959**	**3.0148**
Min	**.6097**	**.6478**	**.6413**	**.5359**	**.5847**	**.6097**	**.6668**
Avg	**1.4026**	**1.5535**	**1.1858**	**1.0756**	**1.1079**	**1.6337**	**1.5933**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD URBAN[104] **BU 0922**
Substation No/ Name :- 254001 / 33/11 KV Karad SS
Feeder No / Name : 201 / 11 KV NAGARPALIKA **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6447	.7023	.6584	.6447	.5487	.6335	.6722
2	.6089	.6584	.6584	.6089	.4755	.6219	.5601
3	.6089	.6653	.695	.6089	.4755	.6036	.5601
4	.6089	.6584	.695	.6089	.4755	.6036	.5601
5	.6089	.695	.7316	.6089	.5121	.6099	.5975
6	.6447	.7316	.7316	.6447	.5487	.8501	.7095
7	1.0029	.8501	.7316	.7522	.7316	.961	.8962
8	.9313	.961	.8779	.8238	.8779	.8596	.8962
9	.9313	.9328	.8779	.8954	.8779	.9511	.9335
10	.905	.9877	.9313	.9145	.8779	.9313	.8688
11	.9593	.9145	.9313	.8413	.9511	.9671	.8145
12	.9774	.9145	.8954	.9511	.9511	.9313	
13	.9593	.9145	.9671	.8779	.9511	.8954	
14	.9231	.8779	.8596	.8413	.8048	.8954	
15	.905	.8779	.788	.8048	.8413	.8954	.9816
16	.8779	.8413	.7522	.8048	.8413	.8596	.9593
17	.8688	.9145	.788	.8779	.8413	.9511	.8859
18	1.2071	1.2071	1.1104	1.134	1.1694	1.2936	1.0277
19	1.5746	1.4998	1.6118	1.4632	1.3969	1.6827	1.3253
20	1.448	1.5729	1.4327	1.3169	1.3756	1.4415	1.2536
21	1.2308	1.2071	1.1104	1.0608	1.1041	1.2323	1.1104
22	1.0498	.9511	1.0387	.9511	.9774	1.0242	1.0136
23	.8688	.7682	.788	.7316	.8326	.8589	.8688
24	.6805	.7059	.695	.6447	.6219	.7059	.7095
Max	**1.5746**	**1.5729**	**1.6118**	**1.4632**	**1.3969**	**1.6827**	**1.3253**
Min	**.6089**	**.6584**	**.6584**	**.6089**	**.4755**	**.6036**	**.5601**
Avg	**.9177**	**.9171**	**.8899**	**.8505**	**.8359**	**.9275**	**.8669**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD URBAN[104] **BU 0922**
Substation No/ Name :- 254001 / 33/11 KV Karad SS
Feeder No / Name : 202 / 11 KV KRISHNA GHAT **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2149	.2481	.2926	.2507	.2195	.2686	.2614
2	.2149	.2353	.2561	.2149	.1829	.2743	.2241
3	.2149	.2353	.2561	.2149	.1829	.2561	.2241
4	.2149	.2353	.3292	.2149	.1829	.2561	.2241
5	.2507	.2507	.3292	.2149	.2195	.2743	.2614
6	.2865	.3109	.3658	.2507	.2561	.3292	.3361
7	.394	.3881	.3658	.394	.3658	.4024	.4108
8	.394	.4024	.4024	.3224	.5487	.4207	.4481
9	.4298	.4251	.439	.3582	.3658	.439	.4481
10	.4477	.4755	.394	.3658	.3292	.4298	.4525
11	.4344	.4024	.394	.3658	.4024	.4298	.3761
12	.4119	.4024	.3403	.4024	.2926	.394	
13	.3582	.3658	.4298	.3658	.3658	.394	
14	.3801	.3658	.4298	.3292	.3292	.4298	
15	.3439	.3658	.3582	.2926	.3292	.3582	.5083
16	.3721	.4024	.3582	.3292	.3292	.394	.394
17	.394	.4024	.3582	.4024	.3658	.439	.3898
18	.4607	.4755	.4298	.439	.4508	.5544	.4557
19	.6268	.5853	.6447	.5487	.5959	.7682	.5316
20	.5731	.6584	.5373	.5121	.5316	.7023	.5316
21	.5138	.5121	.5014	.4024	.5959	.5601	.4908
22	.4298	.439	.4656	.4024	.443	.4481	.443
23	.3721	.3658	.3582	.3292	.3898	.3734	.3721
24	.2149	.2835	.3292	.2507	.2561	.3012	.2987
Max	**.6268**	**.6584**	**.6447**	**.5487**	**.5959**	**.7682**	**.5316**
Min	**.2149**	**.2353**	**.2561**	**.2149**	**.1829**	**.2561**	**.2241**
Avg	**.3728**	**.3847**	**.3902**	**.3406**	**.3554**	**.4124**	**.3849**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD URBAN[104] BU 0922
Substation No/ Name :- 254001 / 33/11 KV Karad SS
Feeder No / Name : 203 / 11 KV MARKET YARD SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7316	.7316	.7316	.6219	.6584	.7762	.7095
2	.7316	.695	.695	.6219	.5487	.7392	.6348
3	.7316	.7023	.6584	.6219	.5487	.7023	.6348
4	.7316	.7023	.7316	.6219	.5487	.7023	.6348
5	.7316	.7392	.7682	.6219	.6584	.7468	.7095
6	.8048	.8501	.8779	.695	.8413	.8871	.9335
7	1.0974	1.0562	1.0242	.8779	1.0974	1.0534	1.1203
8	1.0974	.9896	1.0242	.8779	1.0608	.9795	1.0456
9	1.0242	1.0374	.9877	.8779	1.0242	.9896	.9335
10	1.0534	.9145	.9877	.9145	1.0242	1.0608	1.0349
11	1.1088	.9877	1.0242	.9145	.9511	1.0974	.9145
12	1.0903	.9511	1.0242		1.0242	1.0974	
13	1.0349	.9877	1.0242	1.0608	.9145	1.0974	
14	.9979	.9511	.8048	.9145	.9877	.9511	
15	.9896	.9511	.8413	.8779	.9877	1.0242	.6283
16	.9795	.9511	.8779	.8413	.9511	1.134	1.0791
17	.9896	.9877	.8779	.8779	.9877	1.134	.9412
18	1.2986	1.2803	1.1706	1.1706	1.2894	1.39	1.1403
19	1.5546	1.4632	1.4632	1.3535	1.5565	1.6827	1.3352
20	1.4083	1.3169	1.2071	1.2803	1.39	1.4784	1.2437
21	1.1706	1.1706	1.0242	1.1706	1.2437	1.2567	1.1706
22	1.0974	1.0242	.9877	1.0242	1.1157	1.1576	1.0719
23	.8871	.8779	.7316	.8413	.9511	.9709	.924
24	.7316	.7577	.7682	.6584	.695	.8413	.7468
Max	**1.5546**	**1.4632**	**1.4632**	**1.3535**	**1.5565**	**1.6827**	**1.3352**
Min	**.7316**	**.695**	**.6584**	**.6219**	**.5487**	**.7023**	**.6283**
Avg	**1.0031**	**.9615**	**.9297**	**.8843**	**.9607**	**1.0396**	**.9327**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD URBAN[104] **BU 0922**
Substation No/ Name :- 254001 / 33/11 KV Karad SS
Feeder No / Name : 204 / 11 KV HIGH WAY **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.3361	.3292	.362	.2926	.3881	.3361
2	.2987	.2987	.2926	.3258	.2195	.3361	.2614
3	.2987	.2829	.2926	.3258	.2195	.3361	.2614
4	.2896	.2829	.3292	.3258	.2195	.3361	.2614
5	.2896	.2987	.3658	.3258	.2561	.3921	.2926
6	.3258	.3361	.4024	.362	.2926	.4294	.3361
7	.4344	.4338	.439	.4706	.4024	.4854	.3734
8	.4706	.5093	.4755	.4706	.439	.4481	.4108
9	.4344	.4527	.439	.4706	.439	.4854	.4108
10	.5121	.4755	.4706	.4755	.439	.543	.4668
11	.5914	.5487	.5068	.4755	.5121	.6154	.4668
12	.5788	.5487	.543	.5121	.5487	.5792	
13	.6099	.5487	.5792	.5121	.4755	.5792	
14	.5544	.5487	.5068	.4755	.4755	.543	
15	.5914	.5121	.5068	.4938	.439	.5792	.5544
16	.5544	.5121	.543	.4938	.4755	.543	.5175
17	.5788	.5121	.543	.4572	.4755	.5487	.5249
18	.6468	.6219	.6447	.5121	.6733	.5914	.5853
19	.7023	.6584	.6516	.6584	.7133	.6584	.6036
20	.6468	.6219	.6335	.6219	.6653	.7023	.6154
21	.5914	.5487	.543	.5853	.6219	.5228	.5068
22	.5041	.5121	.5068	.5121	.5729	.4854	.5304
23	.4668	.4024	.4525	.439	.4755	.3734	.4755
24	.3582	.3921	.3658	.3982	.3658	.3841	.3734
Max	**.7023**	**.6584**	**.6516**	**.6584**	**.7133**	**.7023**	**.6154**
Min	**.2896**	**.2829**	**.2926**	**.3258**	**.2195**	**.3361**	**.2614**
Avg	**.4856**	**.4665**	**.4734**	**.4609**	**.4462**	**.4952**	**.4364**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD URBAN[104] **BU 0922**
Substation No/ Name :- 254001 / 33/11 KV Karad SS
Feeder No / Name : 205 / 11 KV WAKHAN ROAD **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2534	.4066	.3658	.3258	.2561	.3511	.3361
2	.2172	.3881	.3292	.3258	.2195	.3326	.2987
3	.2172	.3326	.3292	.3258	.2195	.3142	.2987
4	.2172	.3326	.3292	.3258	.2195	.3142	.2987
5	.2172	.3696	.3658	.3258	.2561	.3361	.2987
6	.2534	.3921	.4024	.362	.2926	.3881	.3361
7	.362	.4668	.4755	.4525	.4024	.462	.3734
8	.5068	.4481	.4755	.4344	.4024	.5175	.3734
9	.4706	.4854	.4572	.4706	.439	.462	.2987
10	.4805	.439	.4344	.4755	.439	.4525	.2865
11	.4251	.4024	.4344	.4024	.4755	.4344	.2658
12	.4251	.439	.3982	.3658	.439	.4525	
13	.439	.4024	.362	.4024	.4024	.4344	
14	.4207	.4024	.3982	.3658	.4024	.362	
15	.4251	.4024	.362	.2561	.3658	.4344	.3086
16	.4024	.3658	.362	.3658	.4024	.4344	.2804
17	.4207	.3658	.4298	.3658	.4024	.439	.2601
18	.4938	.4755	.4706	.4024	.4938	.4805	.333
19	.6468	.5853	.5792	.5121	.6219	.6219	.4525
20	.6099	.5853	.543	.5121	.5914	.5914	.4344
21	.5914	.5487	.543	.4755	.5729	.5914	.4477
22	.5544	.5121	.5068	.439	.5415	.5601	.3982
23	.499	.4755	.4344	.3292	.4066	.4108	.3475
24	.2534	.4251	.439	.362	.2926	.3696	.3734
Max	**.6468**	**.5853**	**.5792**	**.5121**	**.6219**	**.6219**	**.4525**
Min	**.2172**	**.3326**	**.3292**	**.2561**	**.2195**	**.3142**	**.2601**
Avg	**.4084**	**.4354**	**.4261**	**.3909**	**.3982**	**.4395**	**.3381**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD URBAN[104] **BU 0922**
Substation No/ Name :- 254001 / 33/11 KV Karad SS
Feeder No / Name : 206 / 11 KV COTTAGE HOSPITAL **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.7023	.695	.8589	.6584	.7282	.7468
2	.7095	.6653	.6584	.8215	.5121	.7023	.6722
3	.7095	.6283	.6584	.8215	.5121	.7023	.6722
4	.7095	.6348	.695	.8215	.5121	.6468	.6584
5	.7095	.6722	.7316	.8215	.5487	.6468	.7468
6	.7842	.8589	.7682	.8962	.7316	.8871	.8215
7	1.0456	.9709	.8779	1.0082	.8779	1.1273	.9709
8	1.0456	1.0082	.9511	1.0829	.9877	.9979	1.0082
9	1.1949	1.1317	1.1706	1.1203	.9877	1.0829	.9709
10	1.1763	1.0974	1.2696	1.0974	1.0608	1.2696	.9425
11	1.251	1.0608	1.307	1.1888	1.0608	1.307	
12	1.2323	1.0974	1.1203	1.0791	1.0974	1.2696	
13	1.2012	1.134	1.0456	1.0059	1.0608	1.2696	
14	1.2071	.9877	.9335	1.0242	1.0242	1.0829	
15	1.2071	1.0242	1.1203	1.0608	.9511	1.1949	
16	1.1949	1.0242	1.1576	1.0059	1.0242	1.2323	
17	1.1949		1.1576	.9877	.9877	1.2071	1.4327
18	1.363	1.39	1.3443	1.2437	1.2803	1.4045	1.3937
19	1.4632	1.6095	1.5684	1.39	1.4998		1.4998
20	1.2936	1.5154	1.4937	1.2803	1.3491	1.5524	1.3169
21	1.1643	1.3169	1.307	1.0974	1.2323	1.3443	1.1888
22	1.0534	1.1706	1.2323	1.0242	1.1576	1.1576	1.0974
23	.8048	.9877	1.0082	.8779	.9709	1.0082	.961
24	.7468	.695	.7682	.8962	.7316	.7947	.8215
Max	**1.4632**	**1.6095**	**1.5684**	**1.39**	**1.4998**	**1.5524**	**1.4998**
Min	**.7095**	**.6283**	**.6584**	**.8215**	**.5121**	**.6468**	**.6584**
Avg	**1.0504**	**1.0167**	**1.0433**	**1.0213**	**.9507**	**1.0703**	**.9957**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD URBAN[104] **BU 0922**
Substation No/ Name :- 254001 / 33/11 KV Karad SS
Feeder No / Name : 207 / 11 KV EXPRESS Feeder KV- 11 / OUTGOING **NON SHEDDABLE WATER SUPPLY AND UTILITY**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.2987	.2743	.2614	.2926	.2987	.2614
2	.2149	.2987	.2561	.2614	.2926	.2801	.2987
3	.1715	.2987	.2561	.2614	.2926	.2829	.2987
4	.1715	.1629	.2561	.2614	.1829	.1698	.2987
5	.1715	.1829	.2561	.2614	.1829	.168	.2987
6	.2149	.2801	.2561	.2614	.2926	.2614	.2987
7	.2987	.2987	.2743	.2801	.2926	.2987	.2987
8	.2987	.2987	.2743	.2801	.2561	.2987	.2987
9	.2987	.2987	.2743	.2614	.2926	.2987	.2987
10	.2075	.3109	.2801	.2561	.2195	.2987	.2987
11	.3018	.2012	.1715	.1829	.3109	.2926	.2987
12	.2987	.2926	.2801	.2743	.2926	.3174	
13	.2987	.2926	.2801	.2561	.2926	.3174	
14	.2987	.128	.0914	.3109	.2926	.1715	
15	.2987	.1097	.2801	.2195	.2926	.2987	.0789
16	.2987	.1097	.2987	.128	.1829	.2987	.0777
17	.3174	.3109	.2614	.128	.2195	.2926	.1829
18	.1698	.3109	.2328	.128	.2987	.1663	.1848
19	.2829	.3109	.1715	.128	.2987	.3109	.1886
20	.3174	.3109	.2801	.2926	.2075	.3142	.181
21	.3174	.2195	.2801	.2926	.3174	.3142	.1886
22	.2987	.3109	.2801	.3109	.2987	.3174	.2987
23	.2987	.3109	.2801	.2012	.2987	.3174	.2987
24	.2987	.2987	.2926	.2614	.3109	.1886	.2054
Max	**.3174**	**.3109**	**.2987**	**.3109**	**.3174**	**.3174**	**.2987**
Min	**.1698**	**.1097**	**.0914**	**.128**	**.1829**	**.1663**	**.0777**
Avg	**.2669**	**.2603**	**.2558**	**.2400**	**.2713**	**.2739**	**.2445**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD URBAN[104] **BU 0922**
Substation No/ Name :- 254001 / 33/11 KV Karad SS
Feeder No / Name : 208 / 11 KV Chawadi Chowk **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1646	.1829	.1829	.1829	.1646	.2012	.168
2	.1646	.1829	.1829	.1829	.128	.1848	.1307
3	.1646	.1646	.1829	.1829	.128	.1663	.1307
4	.1646	.1646	.2012	.1829	.128	.1663	.1307
5	.1829	.1848	.2012	.1829	.1646	.2033	.168
6	.2195	.2033	.2195	.2012	.2012	.2402	.2054
7	.2743	.2587	.2378	.2561	.2195	.2772	.2801
8	.2743	.2587	.2561	.2743	.2743	.2957	.3174
9	.2926	.2957	.2926	.2743	.2926	.2772	.2987
10	.3326	.3658	.3292	.2743	.3292	.3658	.3142
11	.4066	.4024	.3841	.3658	.4024	.4024	.2957
12	.4066	.4024	.3475	.3841	.4024	.4024	
13	.3881	.3841	.4024	.3475	.3475	.3658	
14	.3658	.3658	.4024	.3292	.3475	.4024	
15	.3881	.3475	.3292	.3292	.3475	.4024	.3475
16	.3696	.3292	.3109	.3109	.3292	.3841	.2926
17	.4066	.3841	.3658	.3109	.3841	.3841	.2561
18	.499	.4755	.4572	.439	.4119	.499	.3109
19	.6584	.6036	.6401	.567	.5853	.6401	.3841
20	.5914	.6036	.567	.5487	.5853	.6099	.3658
21	.4207	.4207	.3841	.3841	.4024	.4294	.3475
22	.3326	.2926	.3475	.2743	.3475	.3174	.3292
23	.2587	.2561	.2195	.2378	.2587	.2614	.2926
24	.1829	.2012	.2195	.2012	.1829	.2402	.2054
Max	**.6584**	**.6036**	**.6401**	**.567**	**.5853**	**.6401**	**.3841**
Min	**.1646**	**.1646**	**.1829**	**.1829**	**.128**	**.1663**	**.1307**
Avg	**.3296**	**.3221**	**.3193**	**.3010**	**.3069**	**.3383**	**.2653**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD URBAN[104] **BU 0922**
Substation No/ Name :- 254059 / 33/11 KV Oglewadi SS
Feeder No / Name : 201 / OGALEWADI **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.5144	.4801	.5144	.463	.5144	.5144
2	.4458	.4801	.4458	.4801	.4458	.4973	.4973
3	.4458	.4801	.4458	.4801	.4458	.4973	.4801
4	.4458	.4801	.4458	.4801	.4458	.4973	.4801
5	.6859	.6516	.6516	.6173	.6516	.6173	.6001
6	.8402	.8402	.8573	.7888	.8916	.8573	.8573
7	1.1488	1.046	1.1317	1.1145	1.1317	1.2003	1.1488
8	1.0974	1.0631	1.1317	1.166	1.0802	1.1317	1.0802
9	1.0631	1.0631	.8573	1.1317	1.0802	1.0288	1.0974
10	1.0288	1.0288	1.0288	1.1145	1.0288	1.046	1.0802
11	.9945	1.0631	1.0802	1.0288	.9945	1.0288	1.0974
12	1.0117	1.046	1.1145		.9431	.9602	.9945
13	.9602	.7202	1.0631	.6687	.9602	1.1317	1.0117
14	.8916	.8573		.6344	.9088	.9774	
15	1.0802	1.0117		.6516	.9259	.9945	.9945
16	1.0117	.9945	.9088	1.0117	.8916	.9774	.9945
17	1.046	1.0117	1.0974	.9945	1.0117	1.0974	.9774
18	1.1145	1.0631	1.1145	1.0802	1.0631	1.046	1.0631
19	1.3546	1.0631	1.3203	1.2517	1.3717	1.3032	
20	1.2346	1.2517	1.2003	1.2003	1.166	1.2003	1.2174
21	1.1145	1.1145	1.1317	1.1145	1.0288	1.0974	1.1145
22	.9088	.9259	.8745	.8573	.8916	.8916	.9602
23	.6687	.6173	.6173	.6173	.6516	.6516	.6344
24	.3601	.5487	.4973	.5316	.4973	.5658	.5487
Max	**1.3546**	**1.2517**	**1.3203**	**1.2517**	**1.3717**	**1.3032**	**1.2174**
Min	**.3601**	**.4801**	**.4458**	**.4801**	**.4458**	**.4973**	**.4801**
Avg	**.8931**	**.8723**	**.8862**	**.8491**	**.8738**	**.9088**	**.8838**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD URBAN[104] **BU 0922**
Substation No/ Name :- 254059 / 33/11 KV Oglewadi SS
Feeder No / Name : 202 / SAIDAPUR **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0631	1.1145	.9945	1.046	.9945	1.1145	1.1145
2	1.0288	1.0974	.9602	1.0288	.9602	1.0631	1.0631
3	.9945	1.0802	.9259	1.0288	.9088	1.0288	1.0288
4	.9945	1.0802	.9259	1.0117	.9088	1.0288	1.0288
5	1.3717	1.3375	1.3375	1.2003	1.2003	1.286	1.2689
6	1.6461	1.6461	1.6289	1.4403	1.4575	1.8519	1.8861
7	2.2634	2.3834	2.332	2.4177	1.9204	2.6063	2.5377
8	2.4006	2.4348	2.4006	2.3663	2.1948	2.4691	2.5377
9	1.9719	2.0919	1.989	2.1605	2.1262	2.1262	2.0233
10	1.8519	1.7661	1.7147	1.8861	1.8519	1.9204	1.7833
11	1.6804	1.5947	1.5775	1.5432	1.7147	1.8861	1.6804
12	1.3717	1.4746	1.7318	1.4918	1.7661	1.4918	1.5261
13	1.3889	1.3203	1.5261	1.3717	1.6289	1.4575	1.5089
14	1.3375	1.3546	1.2346	1.286	1.4746	1.4746	1.4746
15	1.3717	1.4575	1.2689	1.3717	1.3889	1.5432	1.4403
16	1.3889	1.4575	1.2346	1.4232	1.3375	1.5261	1.3717
17	1.4746	1.4403	1.5261	1.4403	1.5089	1.5604	1.4403
18	1.749	1.6118	1.5775	1.5947	1.7147	1.7147	1.6289
19	2.1605	2.0919	2.1262	2.0576	2.1262	2.1262	2.1091
20	2.0405	2.0233	1.9547	1.9547	2.0748	2.0576	2.0405
21	1.9376	1.9547	1.8519	1.8519	1.9376	1.989	1.9547
22	1.8004	1.4232	1.6632	1.6461	1.749	1.6975	1.8347
23	1.3889	1.2346	1.286	1.2346	1.3889	1.4403	1.5089
24	1.0974	1.1488	1.0288	1.0802	1.0288	1.2003	1.2346
Max	**2.4006**	**2.4348**	**2.4006**	**2.4177**	**2.1948**	**2.6063**	**2.5377**
Min	**.9945**	**1.0802**	**.9259**	**1.0117**	**.9088**	**1.0288**	**1.0288**
Avg	**1.5739**	**1.5675**	**1.5332**	**1.5389**	**1.5568**	**1.6525**	**1.6261**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD URBAN[104] BU 0922
Substation No/ Name :- 254059 / 33/11 KV Oglewadi SS
Feeder No / Name : 203 / Surli Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	1.2689	2.4177	2.1262	.1715	.2058
2	.1543	.1543	1.2346	2.3834	2.0919	.1543	.1886
3	.1029	.1543	1.2003	2.3491	2.0919	.1543	.1886
4	.1543	.1543	1.2003	2.3834	2.0576	.1543	.1715
5	.2229	.2058	1.6289	2.6406	2.4006	.2058	.1715
6	.2743	.2915	2.0405	2.9664		.3086	.3086
7	.3086	.3258	2.452	3.0607	3.1036	.3772	.3601
8	.2572	.3601	3.2922	3.3198	3.3951	.3086	.3429
9	3.4294	3.4294		.3429	.2401	3.7209	4.4239
10	3.6694	3.9095		.3086	.2743	.7716	4.3724
11	.1715	3.7723		.2915	.2572	1.5261	
12		3.2407		.2743	.2401	3.2407	4.3038
13	3.6275	3.9095		.1715	.1886		4.441
14	3.8923	3.9438	.1715	.1543	.2229	3.4637	
15	3.5322	3.8923	.2058	.1715	.2401	4.4925	4.321
16	3.7029	3.1036	.2229	.1886	.2401	3.4465	4.2696
17	.2743	.2572	.2572	.2058	.2401	.2572	
18	.2058	.2401	.2915	.2743	.3429	.2229	
19	.3601	.2743	.3429	.2915	.3429	.3429	
20	.3258	.2915	.3086	.3086	.3601	.3429	.3601
21	.3429	.2915	.2743	.2915	.3258	.3258	.3258
22	.3086	.2743	.2743	.2743	.2915	.2915	.3258
23	.2401	.2743	.2401	.2572	.2572	.2572	.2743
24	.1886	.2229	.2401	.2229	.2401	.2229	.2229
Max	**3.8923**	**3.9438**	**3.2922**	**3.3198**	**3.3951**	**4.4925**	**4.441**
Min	**.1029**	**.1543**	**.1715**	**.1543**	**.1886**	**.1543**	**.1715**
Avg	**1.1268**	**1.3810**	**.9025**	**1.0646**	**.9379**	**1.0765**	**1.5567**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD URBAN[104] **BU 0922**
Substation No/ Name :- 254059 / 33/11 KV Oglewadi SS
Feeder No / Name : 204 / Industrial Feeder KV- 11 / OUTGOING **SHEDDABLE FEEDER HAVING WEEKLY STAGGERING (MIDC, EQUIVALENT)**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.2743	.2401	.2401	.2743	.2743	.3086
2	.2743	.2401	.2401	.2229	.2401	.2401	.2743
3	.2743	.2401	.2401	.2229	.2401	.2401	.2743
4	.2743	.2401	.2401	.2229	.2401	.2401	.2401
5	.2743	.2743	.2743	.2401	.2743	.2743	.2743
6	.3086	.3086	.2743	.2743	.2743	.3086	.2743
7	.3086	.3086	.2743	.2743	.2743	.3086	.2743
8	.3086	.3086	.3086	.2743	.3086	.3086	.2743
9	.4115	.4115	.4801	.5144	.5144	.4801	.2743
10	.5144	.4115	.5144	.4801	.5487	.5144	.2401
11	.4115	.4801	.5487	.4458	.5144	.4801	.2743
12	.3086	.3772		.3772	.4801	.4458	.3086
13	.3772	.3086		.4458	.5487	.4115	.2401
14	.4458	.4801	.4801	.4801	.6516	.4115	.2743
15	.4458	.4458	.4458	.4458	.5144	.4801	.2401
16	.5144	.3772	.4458	.4115	.5487	.6516	.2743
17	.3086	.3429	.3429	.3772	.4115	.3429	.2401
18	.2743	.3086	.3429	.3429	.4115	.3086	.2743
19	.2743	.2743	.3086	.2572	.3086	.3086	.2401
20	.2058	.2743	.2229	.2743	.2743	.3086	.2401
21	.3086	.2743	.2401	.2743	.3086	.3086	.2401
22	.2401	.2401	.2401	.2743	.2743	.2743	.2401
23	.3086	.2401	.2401	.2401	.2743	.2743	.2743
24	.3086	.3086	.2401	.2401	.2743	.3086	.3086
Max	**.5144**	**.4801**	**.5487**	**.5144**	**.6516**	**.6516**	**.3086**
Min	**.2058**	**.2401**	**.2229**	**.2229**	**.2401**	**.2401**	**.2401**
Avg	**.3329**	**.3229**	**.3266**	**.3272**	**.3744**	**.3543**	**.2658**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD URBAN[104] BU 0922
Substation No/ Name :- 254059 / 33/11 KV Oglewadi SS
Feeder No / Name : 205 / KOPARDE GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3086	.3429	.3258	.2915	.2743	.2915
2	.3258	.2915	.3258	.3086	.2743	.2572	.2743
3	.1715	.2743	.3086	.3086	.2743	.2572	.2743
4	.3086	.2743	.2915	.3086	.2743	.2572	.2743
5	.4115	.4287	.4287	.3944	.4115	.3944	.4115
6	.5144	.6516	.6516	.5144	.5487	.5658	.583
7	.6859	.703	.7373	.703	.7202	.7545	.6516
8	.7202	.6859	.6859	.7545	.6516	.703	.6173
9	.6173	.5316	.4287	.6344	.5316	.6001	.6001
10	.5316	.4973	.5144	.5658	.4115	.5144	.5144
11	.4973	.5144	.5316	.5316	.3944	.4973	.4801
12	.4801	.4801		.4973	.3772	.463	.4287
13	.4973	.4801		.4458	.4115	.4801	.4115
14	.4973	.4458		.0686	.3429	.3772	.3772
15	.4973	.463	.5316	.1029	.4287	.4287	.3601
16	.4973	.4801	.4801	.4287	.4458	.4458	.3601
17	.463	.463	.5144	.3944	.4115	.5144	.4115
18	.5658	.5487	.583	.5144	.4458	.4458	.4973
19	.7545	.6516	.7202	.7202	.703	.6859	.6344
20	.7202	.7545	.6687	.6687	.6173	.6173	.6516
21	.6516	.7202	.6173	.6173	.583	.583	.6173
22	.6001	.6173	.5144	.5316	.463	.4801	.5316
23	.4287	.4801	.4458	.3601	.3258	.3772	.4458
24	.3601	.3258	.3944	.3601	.3086	.2915	.3086
Max	**.7545**	**.7545**	**.7373**	**.7545**	**.7202**	**.7545**	**.6516**
Min	**.1715**	**.2743**	**.2915**	**.0686**	**.2743**	**.2572**	**.2743**
Avg	**.5058**	**.5030**	**.5103**	**.4608**	**.4437**	**.4694**	**.4587**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD URBAN[104] BU 0922
Substation No/ Name :- 254059 / 33/11 KV Oglewadi SS
Feeder No / Name : 206 / PARLE AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.5775	.1029	.0686	.0514	2.2891	2.1434
2	1.3375	1.5261	.1029	.0686	.0686	2.2977	2.1262
3	1.3032	1.4403	.1029	.0686	.0514	2.2977	1.8861
4	1.3032	1.4403	.1029	.0686	.0514	2.2462	2.0576
5	1.6804	1.5432	.1029	.0686	.0514	2.3834	2.2977
6	1.8519	1.7147	.1029	.0686		2.4587	2.4863
7	1.989	1.9547	.1029	.0857		2.6658	2.915
8	2.1434	1.989	1.1317	.0857	.0514	2.8807	2.8978
9	.0686	.0686		2.1534	1.0802	.0686	.0686
10	.0686	.0686		3.2579	2.4177	.0686	.0686
11	.0857	.0686		3.2236	2.8807	.0686	
12	.0857	.0686		3.2407	3.3951	.0514	.0514
13	.0857	.0686		3.3093	3.4637	.0686	.0686
14	.0857	.0686		3.3779	3.4808	.0686	.0857
15	.1029	.0857		3.3951	3.4979	.0686	.0686
16	.0857	.1029	1.989	3.1722	3.3951		.0857
17	.0857	.1029	2.6063	.0857	.1543		.1029
18	.0857	.1029	2.0576	.0857	.12	.1029	.1029
19	.0857	.1029	.12	.0857	.12	.1029	.12
20	.0857	.1029	.1029	.0857	.12	.1029	.12
21	.12	.1029	.1029	.0686	.1029	.1029	.12
22	.12	.1029	.1029	.0686	.1029	.1029	.1029
23	.12	.1029	.1029	.0686	.12	.1029	.1372
24	.0857	.12	.1029	.0857	.0686	.12	.1029
Max	**2.1434**	**1.989**	**2.6063**	**3.3951**	**3.4979**	**2.8807**	**2.915**
Min	**.0686**	**.0686**	**.1029**	**.0686**	**.0514**	**.0514**	**.0514**
Avg	**.6016**	**.6094**	**.5376**	**1.0978**	**1.1293**	**.9418**	**.8790**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD URBAN[104] **BU 0922**
Substation No/ Name :- 254059 / 33/11 KV Oglewadi SS
Feeder No / Name : 207 / 11 KV VADOLI AG **FEEDER SEPERATION/PURE AG**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0343	.5144	.7373	.5144	.0343	
2			.4801	.703	.5144	.0343	
3			.4458	.6687	.4801	.0343	
4			.4801	.6687	.4801	.0343	
5			.583	.7888	.6516	.0343	
6			.7202	.8573	.7716		
7			.9945	.9069	.8745		
8				1.0117	.9088	.0171	.0171
9	.6859	1.3889		.0343		1.0974	1.1317
10	.7716	1.085		.0343		1.1317	1.1145
11	1.0288	1.166		.0343		1.1145	1.0974
12	1.3203	1.1831		.0343		.9945	1.0631
13	1.286	1.1831		.0343		1.0117	1.0974
14	1.2517	1.166				1.1145	
15	1.2039	1.166				1.0974	1.0631
16	1.2003	.8573		.0171	.0171	1.0631	1.0802
17				.0171	.0171		
18			.0171	.0171	.0343		
19			.0343	.0171	.0343		.0343
20			.0343	.0171			
21	.0343		.0343	.0171	.0343		.0343
22	.0343		.0343	.0171	.0343		.0343
23	.0343		.0343	.0171	.0343		.0343
24	.0171	.0343		.0343	.0171	.0343	
Max	**1.3203**	**1.3889**	**.9945**	**1.0117**	**.9088**	**1.1317**	**1.1317**
Min	**.0171**	**.0343**	**.0171**	**.0171**	**.0171**	**.0171**	**.0171**
Avg	**.7390**	**.9264**	**.3390**	**.3039**	**.3386**	**.5898**	**.6501**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD URBAN[104] **BU 0922**
Substation No/ Name :- 258001 / 220/33KV Ogalewadi SS
Feeder No / Name : 403 / 33 KV KARAD TOWN **SHEDDABLE RURAL**
Feeder KV- 33 / INCOMING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2773	3.6923	3.8409	3.4385	3.2373	3.638	3.3608
2	3.1161	3.5294	3.6214	3.2773	2.6886	3.4208	3.2487
3	3.1161	3.3665	3.6763	3.2773	2.6886	3.2922	3.2487
4	3.1161	3.2579	3.8958	3.2773	2.5789	3.1824	3.2487
5	3.1161	3.4208	4.0604	3.2773	2.9081	3.2579	3.5848
6	3.4922	4.1152	4.3347	3.5997	3.6214	4.2896	3.9769
7	4.8354	4.7782	4.7188	4.513	4.5542	5.2126	5.1532
8	4.9966	4.8868	4.9383	4.7817	4.8834	4.9931	5.0412
9	5.1578	5.048	4.9931	4.9966	5.048	5.0497	4.7611
10	5.2675	5.1578	5.1578	5.1578	5.1029	5.2115	4.6696
11	5.5967	5.3224	5.3189	4.9931	5.3224	5.4801	3.5294
12	5.5418	5.2126	5.0503	4.1701	5.2675	5.4801	
13	5.487	5.3224	5.104	5.1578	5.1578	5.3727	
14	5.2675	4.9383	4.3519	4.8834	4.9383	4.8354	
15	5.2675	4.8285	4.7279	4.5542	4.8834	5.3189	3.5757
16	5.2126	4.7188	4.7817	4.4445	4.8285	5.3189	3.6923
17	5.2675	3.9506	4.8354	4.6091	4.9383	5.3772	4.9966
18	6.3649	6.4198	5.8025	5.5967	6.2443	6.3758	5.7556
19	7.7103	7.572	7.4143	6.9136	7.4932	6.5295	6.3529
20	6.9685	7.2428	6.7696	6.6941	6.733	7.3737	6.0271
21	6.0905	6.2552	5.9099	5.8162	5.9728	6.4866	5.5384
22	5.4321	5.4321	4.6205	5.2675	5.3212	5.6516	5.2126
23	4.4445	4.7737	4.4056	4.2798	4.6153	4.9291	4.5542
24	3.7609	3.8409	4.1701	3.8683	3.7311	3.8552	4.0329
Max	**7.7103**	**7.572**	**7.4143**	**6.9136**	**7.4932**	**7.3737**	**6.3529**
Min	**3.1161**	**3.2579**	**3.6214**	**3.2773**	**2.5789**	**3.1824**	**3.2487**
Avg	**4.9126**	**4.8785**	**4.8542**	**4.6185**	**4.6983**	**4.9972**	**4.4553**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD-II S/DN.[106] BU 5916
Substation No/ Name :- 254004 / MALKAPUR
Feeder No / Name : 201 / KRISHNA HOSPITAL **NON SHEDDABLE EXPRESS HV FEEDERS**
Feeder KV- 11 / OUTGOING **(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2641	.3018	.2743	.2829	.2829	.3018
2	.2401	.2641	.2641	.2743	.2829	.2829	.3018
3	.2401	.2641	.2641	.2743	.2829	.2829	.3018
4	.2401	.2641	.2641	.2743	.2829	.2829	.3018
5	.2572	.2641	.3018	.3086	.3018	.3206	.3584
6	.3429	.3584	.3395	.3429	.3395	.3772	.3961
7	.4287	.4527	.4527	.4207	.3395	.4715	.4715
8	.4801	.5093	.5281	.5144	.4527	.5281	.5658
9	.5658	.5658	.6036	.6036	.4527	.6602	.6036
10	.6224	.5847	.5658	.6979	.4338	.6979	.6413
11	.6224	.5658	.6036	.6602	.5281	.6908	
12	.6224	.6036	.5658	.6036	.4904	.6413	
13	.5281	.547	.5281	.5658	.4904	.6036	
14	.5847	.4715	.5281	.547	.4715	.547	
15	.6979	.5658	.6036	.5658	.3961	.6036	.5658
16	.6602	.547	.5847	.5281	.4715	.6036	.5281
17	.5658	.4338	.4801	.4904	.415	.547	.5144
18	.5093	.4338	.4458	.3772	.3772	.6036	.4801
19	.5281	.4904	.4115	.4527	.4338	.5281	.4115
20	.4338	.4338	.4115	.4715	.3961	.4904	.4115
21	.4527	.415	.3429	.3772	.415	.4904	.4115
22	.3961	.3584	.3429	.3395	.3772	.415	.3258
23	.3395	.3395	.3086	.3206	.3018	.3584	.2572
24	.2572	.3361	.3206	.2743	.2829	.3018	.3206
Max	**.6979**	**.6036**	**.6036**	**.6979**	**.5281**	**.6979**	**.6413**
Min	**.2401**	**.2641**	**.2641**	**.2743**	**.2829**	**.2829**	**.2572**
Avg	**.4523**	**.4305**	**.4318**	**.4400**	**.3874**	**.4838**	**.4235**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD-II S/DN.[106] **BU 5916**
Substation No/ Name :- 254004 / MALKAPUR
Feeder No / Name : 202 / MALKAPUR Gaonthan **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9259	.8962	.9054	.8573	.8029	1.0185	.9709
2	.9259	.8962	.9054	.8573	.8029	.9808	.9335
3	.9259	.8962	.9054	.8573	.8029	.9808	.9335
4	.9259	.8962	.9054	.8573	.8402	.9808	.9335
5	.9602	.9709	1.0185	1.0288	.8962	1.1317	1.0642
6	1.6461	1.2883	1.3203	1.2003	1.1203	1.358	1.3443
7	1.7147	1.7924	1.9239	1.749	1.5123	1.9616	1.8298
8	1.8176	1.7741	1.8861	1.7337	1.7372	1.9239	1.922
9	1.8861	1.8111	1.7353	1.8484	1.6827	1.8107	1.8861
10	1.6598	1.9366	1.9616	1.8107	1.6598	1.829	1.9616
11	1.9616	1.6289	1.8861	2.0936	1.6787	1.6289	
12	1.7353	1.7737	1.6409	1.773	1.6598	1.6108	
13	1.6221	1.5746	1.4523	1.8484	1.5466	1.9342	1.8861
14	1.7353	1.5384	1.4335	1.4335	1.4335	1.6476	.8299
15	1.9616	1.5927	1.5089	1.5278	1.6221	1.7737	.8299
16	1.8107	1.6032	1.6975	1.9427	1.5089	1.8804	.3018
17	1.8823	1.9616	1.7318	1.7353	1.5844	1.8267	1.1145
18	1.9728	1.8861	1.8861	1.7013	1.9239	1.9909	1.3717
19	2.0302	2.1125	1.989	2.0302	2.1125	2.1033	1.5775
20	1.9022	1.9239	2.0576	1.7924	1.9993	1.9022	1.9547
21	1.7193	1.6975	1.9547	1.5893	1.8107	1.7372	1.7147
22	1.5497	1.5089	1.6975	1.363	1.5089	1.531	1.5432
23	1.0642	1.1317	1.1831	1.0456	1.2826	1.1949	1.3203
24	.9869	.9709	1.0185	.9431	.9335	1.0562	.9671
Max	**2.0302**	**2.1125**	**2.0576**	**2.0936**	**2.1125**	**2.1033**	**1.9616**
Min	**.9259**	**.8962**	**.9054**	**.8573**	**.8029**	**.9808**	**.3018**
Avg	**1.5551**	**1.5026**	**1.5252**	**1.4841**	**1.4360**	**1.5747**	**1.3269**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD-II S/DN.[106] BU 5916
Substation No/ Name :- 254004 / MALKAPUR
Feeder No / Name : 203 / Goleshwar Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0343	.1509	.1174	.0343	.0377	.0343
2	.0514	.0343	.1509	.12	.0343	.0377	.0343
3	.0514	.0343	.1509	.1294	.0343	.0377	.0343
4	.0457	.0343	.1509	.1372	.0343	.0377	.0343
5	.0457	.0343	.1886	.1372	.0343	.0377	.0514
6	.0686	.0526	.2075	.2058	.0537	.0566	.0526
7	.1017	.0716	.2829	.2401	.0716	.0754	.0716
8	.0857	.0716	.2829	.2743	.3086	.0754	.0716
9	.3395	.4115	.0754	.0566	.2915	.415	.4527
10	.4527	.4973	.0566	.0566	.0566	.4973	.5658
11	.5281	.5197	.0566	.0566	.0754	.5144	
12	.5093	.4973	.0377	.0566	.0377	.4801	
13	.4904	.3429	.0566	.0566	.0377	.4801	.3772
14	.4904	.4115	.0377	.0377	.0566	.4973	.5658
15	.5093	.4115	.0377	.0377	.0566	.5144	.6036
16	.5093	.4338	.0377	.0377	.0377	.5144	.6036
17	.0343	.0377	.0305	.0566	.0566	.0351	.0305
18	.0537	.0566	.0343	.0514	.0566	.0537	.0381
19	.0537	.0566	.0686	.0537	.0754	.0716	.0446
20	.0537	.0754	.0686	.0716	.0566	.0716	.0678
21	.0716	.0754	.0686	.0537	.0754	.0514	.0617
22	.0343	.0566	.0514	.0537	.0566	.0537	.0457
23	.0343	.0566	.0514	.0343	.0566	.0537	.0446
24	.0532	.0343	.0377	.0457	.0343	.0377	.0537
Max	**.5281**	**.5197**	**.2829**	**.2743**	**.3086**	**.5144**	**.6036**
Min	**.0343**	**.0343**	**.0305**	**.0343**	**.0343**	**.0351**	**.0305**
Avg	**.1966**	**.1809**	**.0989**	**.0908**	**.0718**	**.1974**	**.1791**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD-II S/DN.[106] **BU 5916**
Substation No/ Name :- 254004 / MALKAPUR
Feeder No / Name : 204 / Goleshwar Gaothan **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2987	.3018	.2743	.2801	.3018	.3174
2	.2743	.2987	.3018	.2401	.2801	.3018	.3174
3	.2743	.2987	.3018	.2572	.2801	.3018	.3174
4	.2743	.2987	.3018	.2743	.2801	.3018	.3174
5	.3086	.3174	.3395	.3086	.2987	.3772	.3734
6	.4115	.5228	.4527	.4115	.4854	.5658	.5601
7	.6859	.7655	.7545	.6859	.7095	.7545	.8316
8	.6516	.6722	.679	.6344	.7023	.679	.7947
9	.6036	.5975	.6036	.5658	.6516	.6036	.6413
10	.4904	.4706	.547	.4904	.5281	.4525	.4904
11	.4904	.3982	.4715	.4527	.5281	.4344	
12	.4715	.4525	.3772	.4338	.4715	.4119	
13	.4527	.4344	.3772	.3772	.4338	.394	.3772
14	.3961	.3439	.3772	.4527	.3961	.3761	.3395
15	.3395	.3403	.3772	.3772	.415	.3761	.3772
16	.3961	.3772	.3961	.4338	.4338	.394	.3772
17	.4163	.4338	.4115	.4338	.415	.394	.3772
18	.543	.5658	.5144	.5249	.5658	.5611	.4801
19	.7499	.679	.6173	.6878	.679	.7499	.583
20	.7133	.6413	.6859	.695	.679	.7133	.6859
21	.6584	.6036	.583	.6283	.6413	.6838	.583
22	.5975	.5281	.5144	.5415	.5281	.5788	.5144
23	.3921	.3772	.4287	.3734	.415	.4294	.3772
24	.3086	.3361	.3018	.3086	.2987	.3395	.3547
Max	**.7499**	**.7655**	**.7545**	**.695**	**.7095**	**.7545**	**.8316**
Min	**.2743**	**.2987**	**.3018**	**.2401**	**.2801**	**.3018**	**.3174**
Avg	**.4656**	**.4605**	**.4590**	**.4526**	**.4748**	**.4782**	**.4722**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD-II S/DN.[106] **BU 5916**
Substation No/ Name :- 254004 / MALKAPUR
Feeder No / Name : 205 / AAGASHIVNAGAR **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.7842	.9054	.7888	.9335	.9808	.9896
2	.5144	.7842	.8676	.7888	.9335	.9431	.9896
3	.5144	.7842	.8676	.7888	.9335	.9431	.9896
4	.5144	.7842	.8676	.7888	.9335	.9431	.9896
5	.5144	.7842	.9054	.8916	.9522	.9808	1.0269
6	.9259	.9709	1.1317	.0857	1.0642	1.2071	1.2136
7	.8573	1.2883	1.4335	1.0288	1.363	1.1317	1.1949
8	1.0288	1.307	1.5089	1.0288	1.0719	1.1317	1.1827
9	1.226	1.3817	1.5844	1.094	1.0608	1.0562	1.094
10	1.2826	1.2851	1.3957	.9431	.9431	.9774	.9054
11	1.2071	1.267	1.4335	.9431	.9808	.9412	
12	.6036	1.182	.7922	1.3957	1.358	1.3969	
13	1.1317	1.1765	.7922	1.2826	1.3203	1.2894	
14	1.1694	1.1946	1.2449	1.2826	1.2826	1.379	
15	1.094	1.1403	1.2071	.8488	1.2071	1.3253	
16	1.094	1.3014	1.2449	1.2071	1.2449	1.3969	
17	1.147	1.3014	1.2003	1.2826	1.2826	1.4506	.9088
18	1.2308	1.5089	1.2689	1.4299	1.4335	1.5384	1.0288
19	1.5364	1.6598	1.3717	1.7013	1.6598	1.7924	1.0974
20	1.4449	1.6598	1.406	1.5912	1.5844	1.7193	1.166
21	1.3535	1.5089	1.3032	1.423	1.5089	1.6078	1.0288
22	1.2323	1.358	1.2003	1.3817	1.358	1.419	.8916
23	.9335	1.0562	1.1145	1.1016	1.2071	1.2136	.6859
24	.5144	.8402	.9808	.8573	.9522	1.0562	1.0642
Max	**1.5364**	**1.6598**	**1.5844**	**1.7013**	**1.6598**	**1.7924**	**1.2136**
Min	**.5144**	**.7842**	**.7922**	**.0857**	**.9335**	**.9412**	**.6859**
Avg	**.9827**	**1.1795**	**1.1678**	**1.0815**	**1.1904**	**1.2425**	**1.0249**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD-II S/DN.[106] **BU 5916**
Substation No/ Name :- 254004 / MALKAPUR
Feeder No / Name : 206 / Koyana Industrial Feeder **SHEDDABLE FEEDER HAVING WEEKLY**
Feeder KV- 11 / OUTGOING **STAGGERING (MIDC, EQUIVALENT)**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2641	.2641	.2401	.2641	.2641	.2641
2	.2229	.2641	.2641	.2401	.2263	.2641	.2641
3	.2229	.2641	.2641	.2401	.2263	.2641	.2641
4	.2229	.2641	.2452	.2401	.2263	.2452	.2452
5	.2229	.2641	.2452	.2401	.2263	.2452	.2452
6	.2229	.2641	.2263	.2401	.2452	.2452	.2641
7	.2229	.2641	.2263	.2401	.2452	.2452	.2641
8	.2229	.2641	.2641	.2572	.2452	.2641	.2641
9	.3018	.3018	.3395	.3395	.3018	.3018	.2829
10	.3395	.3018	.3395	.3772	.3018	.3395	.2829
11	.3395	.3772	.3772	.4527	.3395	.3772	
12	.3395	.3395	.3395	.3772	.3395	.3395	
13	.3395	.3395	.3018	.3395	1.5466	.3395	.2829
14		.3395	.3772	.3772	.3018	.3395	.2829
15	.3772	.3395	.415	.3772	.3018	.3395	.2641
16	.3772	.3772	.3772	.3772	.3395	.3772	.2641
17	.3395	.3395	.3086	.3395	.3018	.3395	.2572
18	.3395	.3206	.2743	.3395	.3018	.3395	.2572
19	.3018	.3584	.2572	.3018	.2829	.3395	.2572
20	.3018	.3018	.2572	.3018	.2641	.3018	.2572
21	.3018	.3206		.3018	.3018	.3018	.2743
22	.2641	.3018	.2572	.2641	.3018	.2641	.2572
23	.2641	.2641	.2572	.2641	.2641	.2641	.2572
24	.2229	.2641	.2829	.2572	.2641	.2641	.2641
Max	**.3772**	**.3772**	**.415**	**.4527**	**1.5466**	**.3772**	**.2829**
Min	**.2229**	**.2641**	**.2263**	**.2401**	**.2263**	**.2452**	**.2452**
Avg	**.2840**	**.3042**	**.2940**	**.3052**	**.3317**	**.3002**	**.2644**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD-II S/DN.[106] BU 5916
Substation No/ Name :- 254004 / MALKAPUR
Feeder No / Name : 207 / 11 KV Malkapur water works NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1494	.1509	.0171	.0732	.1509	.0747
2	.1543	.0732	.0754	.0171	.0549	.1509	.0732
3	.0171	.0358	.0377	.0171	.0549	.0566	.0549
4	.0171	.0358	.0189	.0514	.1494	.0566	.0549
5	.0171	.0732	.0189	.1543	.1494	.0754	.1494
6	.0343	.1494	.1509	.1543	.168	.1698	.1494
7	.1715	.168	.1698	.1372	.168	.1886	.2054
8	.1715	.1867	.1698	.1715	.168	.1886	.2054
9	.1886	.1867	.1698	.1886	.1867	.1886	.1886
10	.2075	.2801	.1886	.2075	.1886	.3174	.3018
11	.3018	.2801	.1886	.1886	.3206	.3326	
12	.3206	.2614	.1886	.1886	.3206	.3142	
13	.3206	.2987	.2075	.3772	.3018	.2987	.3018
14	.3206	.168	.2829	.3206	.3018	.2987	.3018
15	.3018	.2614	.3395	.3206	.3206	.2987	.3018
16	.3206	.2641	.3018	.3206	.2829	.2987	.3018
17	.3361	.3395	.2572	.3018	.3018	.2987	.2743
18	.3174	.2641	.2401	.2987	.3018	.0549	.2572
19	.2801	.3018	.2572	.2801	.3018	.168	.2427
20	.1307	.2829	.2401	.2801	.0566	.168	.2401
21	.0549	.1509	.2263	.2054	.0566	.1494	.0514
22	.168	.1886	.1715	.1494	.1509	.168	.0343
23	.1494	.1509	.1543	.0543	.1509	.1494	.0857
24	.0686	.1494	.1509		.0732	.1509	.1494
Max	**.3361**	**.3395**	**.3395**	**.3772**	**.3206**	**.3326**	**.3018**
Min	**.0171**	**.0358**	**.0189**	**.0171**	**.0549**	**.0549**	**.0343**
Avg	**.1878**	**.1958**	**.1816**	**.1914**	**.1918**	**.1955**	**.1818**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD-II S/DN.[106] **BU 5916**
Substation No/ Name :- 254004 / MALKAPUR
Feeder No / Name : 411 / EMERSON HTC 871 **SHEDDABLE FEEDER MIDC EQUIVALENT**
Feeder KV- 33 / OUTGOING **HAVING WEEKLY STAGGERING**

DATE	01-NOV-17
HR	Load (MW)
24	.1029
Max	.1029
Min	.1029
Avg	.1029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD-II S/DN.[106] **BU 5916**
Substation No/ Name :- 254004 / MALKAPUR
Feeder No / Name : 412 / EMERSON HTC 872 **SHEDDABLE FEEDER MIDC EQUIVALENT**
Feeder KV- 33 / OUTGOING **HAVING WEEKLY STAGGERING**

DATE	01-NOV-17
HR	Load (MW)
24	.1543
Max	.1543
Min	.1543
Avg	.1543

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD-II S/DN.[106] **BU 5916**
Substation No/ Name :- 254005 / MUNDHE
Feeder No / Name : 201 / Supane AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1443	1.0425	.0743	.0949	.0772	1.6872	1.6198
2	1.1591	1.0425		.0791	.0762	1.6716	1.4377
3	1.1149	1.0425	.0594	.0791	.0914	1.656	1.5306
4	1.1149	1.0715	.0602	.0949	.0914	1.656	1.5404
5	1.1589	1.0715	.0602	.0949	.0914	1.6872	1.5203
6	1.1888	1.2308	.104	.1265	.1235	1.7966	1.6796
7	1.511	1.448	.104	.1581	.1875	2.0965	2.0805
8	1.7528	1.5493	.1204	.1581	.1524	2.198	
9	.1467	.1572	1.9616	2.2405	2.1251	.1581	
10	.1189	.1286	2.2558	2.4387	2.4082	.1581	.16
11	.1337	.1143	2.4387	2.5758	1.5697	.1423	.16
12	.1467	.1286	2.4691		2.114	.1423	.125
13	.1467	.1286	1.9616		2.1251	.1581	
14	.132	.1572	2.1399	1.9372	2.4352	.1423	
15	.1189	.1406	1.813	2.1247	2.4966	.1265	
16	.1783	.125		2.0309		.1423	.144
17	.1738	.1189	.1094	.1094	.1718	.1486	.1581
18	.2027	.1467	.1406	.1372	.1406	.1635	.1581
19	.1783	.1337	.1739	.1372	.1562	.176	.208
20		.1355	.1581	.1372	.1406	.1806	.192
21	.1738	.1355	.1265	.1372	.1406	.1486	.192
22	.1593	.1189	.1107	.1219	.1094	.1505	.16
23	.1448	.0743	.0949	.0914	.1094	.1337	.1638
24	.1189	.1158	.0743	.0949	.0937	.125	.1174
Max	**1.7528**	**1.5493**	**2.4691**	**2.5758**	**2.4966**	**2.198**	**2.0805**
Min	**.1189**	**.0743**	**.0594**	**.0791**	**.0762**	**.125**	**.1174**
Avg	**.5399**	**.4816**	**.7550**	**.6909**	**.7490**	**.7019**	**.7025**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD-II S/DN.[106] BU 5916
Substation No/ Name :- 254005 / MUNDHE
Feeder No / Name : 202 / Khodashi Gaothan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6335	.5601	.5493	.5601	.4938	.5914	.6626
2	.5544	.5228	.5493	.5228	.499	.5914	.5493
3	.5359	.5041	.5194	.5415	.5359	.5914	.5373
4	.5601	.5415	.5194	.5601	.6154	.5914	.543
5	.6722	.5975	.6024	.6908	.6219	.6653	.6335
6	.8131	.9149	.8417	.8589	.8596	.9979	.9492
7	1.134	1.1576	1.1393	1.1576	1.0631	1.2936	1.1694
8	1.1523	1.2136	1.1765	1.1763	1.2178	1.251	1.1104
9	.929	1.251	1.1706	1.1273	1.1283	1.1389	1.0719
10	1.0745	1.0082	1.0136	1.0534	1.1462	1.251	.8871
11	.9922	1.1016	1.0387	.9795	.9991	1.1576	.8131
12	.8238	.9709	.7865	.7947	.9134	1.0269	.7577
13	.8238	.8589	.7865	.6838	.9745	.8589	.6468
14	.7973	.9335	.6219	.7947	.8063	.8402	.7023
15	.8326	.8402	.788	.8686	.9745	.9896	.7577
16	.9391	.9149	.9231	.8871		.9335	.8131
17	1.0349	1.0341	.9896	1.0242	1.2197	1.0985	.8962
18	1.1643	1.134	1.1389	1.2071	1.2197	1.2894	1.0456
19	1.3676	1.382	1.419	1.3306	1.423	1.3969	1.251
20		1.3112	1.3443	1.2803	1.4045	1.4352	1.2696
21	1.1273	1.0208	1.1016	1.0608	1.2197	1.0745	1.1949
22	1.2012	1.0387	1.0456	1.0164	1.1458	1.0166	1.0082
23	.924	.8869	.8402	.7762	.9425	.815	.9149
24	.6584	.6653	.6024	.6722	.6447	.7207	.6984
Max	**1.3676**	**1.382**	**1.419**	**1.3306**	**1.423**	**1.4352**	**1.2696**
Min	**.5359**	**.5041**	**.5194**	**.5228**	**.4938**	**.5914**	**.5373**
Avg	**.9020**	**.9318**	**.8962**	**.9010**	**.9595**	**.9840**	**.8701**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD-II S/DN.[106] **BU 5916**
Substation No/ Name :- 254005 / MUNDHE
Feeder No / Name : 203 / SAHYADRI HOSPITAL **NON SHEDDABLE EXPRESS HV FEEDERS**
Feeder KV- 11 / OUTGOING **(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.0754	.0716	.0754	.0739	.0754	.0905
2	.0739	.0943	.0886	.0754	.0747	.0754	.0716
3	.0716	.0943	.0895	.0754	.0739	.0754	.0886
4	.0724	.0943	.0716	.0754	.0739	.0754	.0905
5	.0924	.0943	.0724	.0754	.0732	.0943	.0724
6	.0895	.0943	.1433	.1886	.0732	.0943	.1433
7	.0549	.0754	.0709	.0943	.0554	.0754	.0716
8	.0716	.0943	.0905	.0754	.0724	.0943	.0716
9	.0709	.0943	.0905	.0943	.0709	.2641	.0754
10	.2149	.1509	.1075	.132	.1075	.1132	.2075
11	.1629	.1132	.1267	.1132	.2126	.2075	
12	.0886	.1509	.1097	.2263	.0895	.1509	
13	.1254	.1132	.1829	.0943	.1052	.1132	.1509
14	.1772	.0943	.1097	.0943	.0724	.1132	.1132
15	.1075	.2263	.0914	.0943	.0709	.1132	.1132
16	.1063	.0943	.1646	.132		.1132	.1132
17	.1698	.124	.1509	.2378	.0754	.1928	.0754
18	.1509	.1612	.0943	.0739	.0566	.1063	.0943
19	.132	.124	.1132	.0905	.2263	.1075	.0934
20		.0895	.1132	.0905	.0754	.0724	.1132
21	.1132	.0724	.0943	.1612	.0943	.0895	.0943
22	.0943	.1595	.1886	.0724	.0754	.0709	.0943
23	.0943	.0709	.0754	.0732	.0943	.1949	.0754
24	.0739	.0754	.0724	.0754	.0724	.0754	.0895
Max	**.2149**	**.2263**	**.1886**	**.2378**	**.2263**	**.2641**	**.2075**
Min	**.0549**	**.0709**	**.0709**	**.0724**	**.0554**	**.0709**	**.0716**
Avg	**.1079**	**.1096**	**.1077**	**.1080**	**.0900**	**.1149**	**.1002**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD-II S/DN.[106] BU 5916
Substation No/ Name :- 254005 / MUNDHE
Feeder No / Name : 204 / WARUNJI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1635	.1509	.0301	.0301	.0305	.3963	.5428
2	.2054	.1372	.0297	.0301	.0305	.3963	.5575
3	.2134	.1372	.0301	.0301	.0305	.3963	.5796
4	.208	.1509	.0297	.0301	.0305	.3963	.5796
5	.2134	.1509	.0293	.0301	.0305	.4115	.602
6	.2286	.2058	.0293	.0301	.0309	.4572	.6161
7	.3269	.2332	.0446	.0301	.0305	.5624	.7133
8	.381	.2058	.0446	.0452	.0457	.6171	.6308
9	.0297	.04	.4458	.431	.6241	.0452	.0625
10	.044	.0267	.6093	.5498	.7876	.0301	.0625
11	.0446	.0267	.6859	.743	.8069	.0452	.0469
12	.044	.04	.7011	.8025	.9389	.0602	.0781
13	.0594	.04	.6923	.823	.9682	.0452	
14	.0434	.04	.7011	.823	.9659	.0452	
15	.0293	.0286	.6984	.823	.9214	.0301	
16	.044	.0286	.6602	.8383		.0452	.0469
17	.0412	.0446	.0286	.0305	.0457		.0602
18	.0274	.0293	.0286	.0305	.0457	.0446	.0452
19	.0412	.044	.0301	.0305	.0305	.044	.0309
20		.0297	.0301	.0305	.0305	.044	.032
21	.0274	.0301	.0301	.0312	.0457	.0452	.0309
22	.0274	.0297	.0301	.0305	.0457	.0297	.0309
23	.0274	.0297	.0301	.0305	.0305	.0297	.0309
24	.0305	.0274	.0293	.0301	.0305	.0305	.0293
Max	**.381**	**.2332**	**.7011**	**.8383**	**.9682**	**.6171**	**.7133**
Min	**.0274**	**.0267**	**.0286**	**.0301**	**.0305**	**.0297**	**.0293**
Avg	**.1087**	**.0795**	**.2374**	**.2639**	**.2860**	**.1847**	**.2576**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD-II S/DN.[106] **BU 5916**
Substation No/ Name :- 254005 / MUNDHE
Feeder No / Name : 205 / Sangam LIS **PURELY LIS FEEDERS**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3856	.4066	.3761	.3961
2			.3856	.4066	.3801	.415
3			.3898	.4066	.3841	.415
4			.3856	.4066	.4024	.415
5			.3898	.4066	.4024	.415
6			.3761	.4066	.4024	.415
7	.0762	.1509	.3721	.4066	.3898	.3961
8	.176	.2263	.3681	.4066	.3982	.4066
9	.1928	.2218	.4024	.3961	.394	.3881
10	.197	.2402	.4066	.3961	.3898	.4066
11	.197	.4066	.3881	.415	.3856	.3881
12	.1949	.4066	.3881	.3961	.3898	.3881
13	.1928	.3881	.3761	.3961	.3898	.3881
14	.1928	.3881	.3801	.415	.3898	.3881
15	.1928	.3881	.3881	.3961	.4031	.3881
16	.1949	.3326	.3841	.3961		.3881
Max	**.197**	**.4066**	**.4066**	**.415**	**.4031**	**.415**
Min	**.0762**	**.1509**	**.3681**	**.3961**	**.3761**	**.3881**
Avg	**.1807**	**.3149**	**.3854**	**.4037**	**.3918**	**.3998**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD-II S/DN.[106] BU 5916
Substation No/ Name :- 254005 / MUNDHE
Feeder No / Name : 206 / Supane Gaothan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.2865	.2896	.2987	.2865	.3403	.3045
2	.3326	.2686	.2303	.2801	.2896	.3045	.2835
3	.3045	.2507	.2279	.2614	.3109	.2865	.2896
4	.3109	.2686	.2328	.2801	.3258	.3224	.3224
5	.362	.3224	.362	.3361	.3224	.3761	.3403
6	.4525	.591	.5373	.5415	.4961	.591	.6024
7	.7522	.7343	.7265	.8048	.8063	.6268	.8238
8	.788	.8954	.8596	.8596	.8238	.8417	.8775
9	.7442	.788	.8596	.8417	.788	.8238	.7343
10	.6379	.7087	.7796	.6805	.6733	.6516	.7343
11	.6089	.5847	.6268	.6268	.6733	.5487	.2149
12	.5258	.5087	.5552	.6805	.6447	.6173	.2865
13	.591	.5344	.5731	.6089	.6268	.5487	.1433
14	.5316	.4578	.5731	.5194	.567	.5487	.1433
15	.5249	.4578	.5258	.5552	.5493	.4973	.2149
16	.5316	.5256	.5316	.5373		.5087	.1612
17	.5373	.5847	.6036	.5847	.6626	.6024	.1696
18	.6984	.8238	.7362	.8869	.8954	.8417	.7712
19	.8775	1.0029	.9511	.9877	1.0208		1.0425
20		.8589	.8686	.8871	.9134	.9134	.9877
21	.8059	.7602	.7655	.7421	.788	.7619	.8131
22	.6626	.5552	.6348	.591	.6626	.6556	.6908
23	.4298	.3801	.4108	.4298	.5014	.4607	.5415
24	.3658	.3403	.3189	.3361	.3224	.394	.3761
Max	**.8775**	**1.0029**	**.9511**	**.9877**	**1.0208**	**.9134**	**1.0425**
Min	**.3045**	**.2507**	**.2279**	**.2614**	**.2865**	**.2865**	**.1433**
Avg	**.5524**	**.5621**	**.5742**	**.5899**	**.6065**	**.5680**	**.4946**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD-II S/DN.[106] **BU 5916**
Substation No/ Name :- 254008 / TALBID
Feeder No / Name : 201 / VAHAGAON AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6804	1.7147	.0532	.0543	.0514	2.2138	2.0243
2	1.7004	1.8861	.0532	.0543	.0514	2.2405	2.0005
3	1.6385	1.8861	.0537	.0543	.0514	2.2405	2.0243
4	1.6385	1.8778	.0532	.0543	.0514	2.2405	2.0481
5	1.7004	1.8067	.0537	.0543	.0514	2.2672	2.0005
6	1.8623	1.8067	.0532	.0543	.0686	2.3205	2.0557
7	1.9766	2.0233	.0701	.0543	.0686	2.4806	2.372
8	2.0005	1.9559	.0526	.0543	.0514	2.4215	2.372
9	.0526	.0549	2.0805	3.2217	3.0178	.0532	.0526
10	.0543	.0543	1.8519	2.8902	3.0483	.0514	.0497
11	.0543	.0543	2.8464	2.9321	3.0483	.0514	.0332
12	.0543	.0543	2.8292		2.2405	.0514	.0335
13	.0543	.0543	2.7435		2.2672	.0514	.0486
14	.0543	.0543	2.0348	2.8902	2.7673	.0514	.0492
15	.0543	.0543	2.7831	2.9321	2.8121	.0514	.0328
16	.0543	.0543	2.9504	2.9721	2.9321	.0514	.0328
17	.0543	.0532	.0514	.0526	.0526	.0514	.0509
18	.0514	.0701	.0543	.0686	.0693	.0701	.0514
19	.0693	.0701	.0543	.0686	.0857	.0867	.0686
20	.0686	.0701	.0543	.0686	.0701	.0693	.0686
21	.0514	.0693	.0543	.0686	.0532	.0701	.0686
22	.0686	.0526	.0543	.0514	.0532	.0532	.0686
23	.0732	.0532	.0543	.0514	.0526	.0532	.0514
24	.0983	.0514	.0532	.0543	.0514	.0532	.0526
Max	**2.0005**	**2.0233**	**2.9504**	**3.2217**	**3.0483**	**2.4806**	**2.372**
Min	**.0514**	**.0514**	**.0514**	**.0514**	**.0514**	**.0514**	**.0328**
Avg	**.6319**	**.6618**	**.8747**	**.8526**	**.9611**	**.8061**	**.7379**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD-II S/DN.[106] BU 5916
Substation No/ Name :- 254008 / TALBID
Feeder No / Name : 202 / Vahagaon Gaothan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2454	.2378	.2103	.181	.2378	.2481	.2481
2	.2303	.2378	.2279	.1991	.2195	.2629	.2328
3	.2629	.2926	.2658	.2172	.2378	.2454	.2328
4	.2481	.3018	.2481	.2534	.2561	.2481	.2658
5	.298	.3772	.3155	.2896	.2926	.298	.333
6	.3988	.439	.4508	.3982	.439	.4508	.4681
7	.5087	.5175	.5144	.5611	.5847	.5487	.5201
8	.5144	.5121	.4854	.5249	.5601	.5201	.5201
9	.4382	.4755	.4031	.4163	.499	.4207	.4207
10	.3982	.3801	.3658	.3155	.4508	.3326	.4024
11	.362	.3801	.3658	.3506	.4207	.4024	.4207
12	.3439	.362	.3326	.3506	.3681	.4024	.4024
13	.3077	.3258	.3326	.3012	.3506	.3292	.3841
14	.3077	.3258	.3142	.3012	.3258	.3109	.362
15	.3258	.3077	.3292	.3155	.3366	.3475	.4024
16	.3258	.3439	.3734	.3506	.3506	.3841	.4024
17	.3801	.3681	.3841	.3814	.4161	.4024	.4024
18	.4207	.3467	.5068	.5175	.5144	.4161	.4207
19	.6584	.5721	.6154	.7167	.5868	.583	.6401
20	.6036	.5144	.543	.695	.6001	.5375	.5853
21	.5487	.4508	.4706	.5359	.5201	.4908	.5228
22	.4805	.3506	.3439	.3696	.4031	.3544	.4805
23	.2926	.2454	.2172	.2743	.298	.2835	.3511
24	.2454	.2402	.2126	.181	.2378	.2481	.2481
Max	**.6584**	**.5721**	**.6154**	**.7167**	**.6001**	**.583**	**.6401**
Min	**.2303**	**.2378**	**.2103**	**.181**	**.2195**	**.2454**	**.2328**
Avg	**.3811**	**.3710**	**.3679**	**.3749**	**.3961**	**.3778**	**.4029**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD-II S/DN.[106] BU 5916
Substation No/ Name :- 254008 / TALBID
Feeder No / Name : 203 / ALFA-LAVAL **NON SHEDDABLE EXPRESS HV FEEDERS**
Feeder KV- 11 / OUTGOING **(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.003	.0027	.003	.0032	.003	.003	.003
2		.0027		.0032	.0026		
3	.003	.0027	.003	.0032	.0027	.003	.003
4		.0027		.0032	.0027		
5	.003	.0027	.003	.0032	.0027	.003	.003
6		.0027		.0032	.0027		
7	.003	.0027	.003	.0032	.0027	.003	.003
8		.0027		.0032	.0027		
9	.003	.0027	.003	.0032	.0027	.0027	.003
10	.0032	.0032	.0027	.003	.003	.0027	.0024
11	.0032	.0032	.0027			.0027	.0024
12	.0032	.0032	.0027	.003	.003	.0027	.0025
13	.0032	.0032	.0027			.0027	.0024
14	.0032	.0032	.0027	.003	.003	.0027	.0024
15	.0032	.0032	.0027	.003		.0027	.0025
16	.0032	.0032	.0027		.003	.0027	.0025
17	.0032	.003	.0027	.003		.0027	.0025
18	.0027		.0032	.0027	.003	.003	.0027
19	.0027	.003	.0032	.0027			.0027
20	.0027		.0032	.0027	.003	.003	.0027
21	.0027	.003	.0032	.0027	.003		.0027
22	.0027		.0032	.0027		.003	.0027
23	.0027	.003	.0032	.0027	.003	.003	.0027
24	.003	.0027	.003	.0032	.0027	.003	.003
Max	**.0032**	**.0032**	**.0032**	**.0032**	**.003**	**.003**	**.003**
Min	**.0027**	**.0027**	**.0027**	**.0027**	**.0026**	**.0027**	**.0024**
Avg	**.0030**	**.0029**	**.0029**	**.0030**	**.0028**	**.0029**	**.0027**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD-II S/DN.[106] **BU 5916**
Substation No/ Name :- 254008 / TALBID
Feeder No / Name : 204 / Taswade East **SHEDDABLE FEEDER HAVING WEEKLY**
Feeder KV- 11 / OUTGOING **STAGGERING (MIDC, EQUIVALENT)**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1402	.2172	.1753	.2561	.2427	.2103	.2126
2	.0886	.197	.1772	.2378	.2641	.1753	.1433
3	.0886	.2218	.1772	.2378	.2561	.1772	.1448
4	.0895	.2033	.1791	.2195	.2427	.1772	.1448
5	.0886	.2054	.1791	.2218	.2195	.1791	.1433
6	.1402	.168	.2126	.2195	.2241	.1772	.1433
7	.1417	.1646	.2126	.2195	.2263	.1772	.1433
8	.1402	.1646	.208	.2561	.2195	.1753	.1433
9	.3467	.2241	.3121	.439	.3292	.3292	.1753
10	.3292	.4344	.4251	.5487	.3121	.4805	.1181
11	.5121	.5068	.4207	.5087	.3429	.5121	.2343
12	.4435	.5068	.4108	.4854	.4409	.2378	.1509
13	.4024	.5121	.4024	.4854	.3772	.4108	.1715
14	.4481	.4805	.4805	.5426	.4115	.4024	.2267
15	.4755	.439	.4755	.5087	.4115	.439	.1486
16	.5121	.4024	.4024	.4801	.3121	.4755	.1555
17	.439	.3814	.3734	.2774	.2601	.3658	.0945
18	.3045	.2804	.4024	.2926	.2774	.3506	.1646
19	.3982	.3467	.3292	.439	.2804	.3506	.1646
20	.2715	.3506	.3292	.4024	.2601	.3544	.1646
21	.1646	.2126	.2926	.1848	.1753	.2658	.1463
22	.2772	.3155	.3658	.1886	.2774	.3506	.1478
23	.2896	.3155	.4024	.3361	.2774	.3467	.2033
24	.1753	.2195	.2658	.2926	.2614	.2103	.2835
Max	**.5121**	**.5121**	**.4805**	**.5487**	**.4409**	**.5121**	**.2835**
Min	**.0886**	**.1646**	**.1753**	**.1848**	**.1753**	**.1753**	**.0945**
Avg	**.2795**	**.3113**	**.3171**	**.3450**	**.2876**	**.3055**	**.1654**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD-II S/DN.[106] **BU 5916**
Substation No/ Name :- 254008 / TALBID
Feeder No / Name : 205 / Taswade West **SHEDDABLE FEEDER HAVING WEEKLY**
Feeder KV- 11 / OUTGOING **STAGGERING (MIDC, EQUIVALENT)**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.443	.9877	.9114	.7682	.8779	.8573	.7087
2	.3506	.9145	.8859	.7316	.9145	.631	.6379
3	.3544	.8779	.788	.695	.8589	.631	.6447
4	.3544	.8779	.7796	.6584	.8048	.6379	.6447
5	.3506	.8688	.7164	.6584	.7842	.6379	.6516
6	.3506	.567	.6089	.6036	.811	.6024	.543
7	.5258	.7316	.6661	.6036	.8215	.631	.5373
8	.6241	.7023	.7545	.6219	.8402	.6935	.5316
9	.7628	.6722	.8322	.8779	.924	.9511	.5258
10	1.0974	1.0425	1.0974	.8139	1.0059	1.1088	.4458
11	1.134	1.134	1.0974	.9496	1.0174	1.0242	.4334
12	1.2071	1.2851	1.2986	.8916	1.0852	1.0608	.3605
13	1.0349	1.2437	1.134	.8322	1.0852	1.134	.3887
14	1.2197	1.39	1.1088	1.0059	1.1401	.9511	.4024
15	1.1827	1.4266	1.1523	.9602	1.153	1.0242	.3125
16	1.2071	1.423	1.1523	1.0059	1.1736	1.134	.3563
17	1.4415	1.1096	1.0974	.9602	1.0974	1.0974	.4287
18	.961	.9114	1.0791	1.0349	1.0288	.9816	.4755
19	.9877	.7712	1.0974	1.0974	.9816	.7796	.3658
20	1.0242	.7712	1.134	1.0425	.9189	.7011	.3734
21	.8326	.7628	.695	.8131	.8413	.7087	.3734
22	1.1088	.8322	.7316	.7682	.7011	.7087	.3734
23	1.1088	.9709	.8596	.9145	.8916	.7628	.4435
24	.5258	.9979	.7712	.8048	.9709	.9015	.8322
Max	**1.4415**	**1.4266**	**1.2986**	**1.0974**	**1.1736**	**1.134**	**.8322**
Min	**.3506**	**.567**	**.6089**	**.6036**	**.7011**	**.6024**	**.3125**
Avg	**.8412**	**.9697**	**.9354**	**.8381**	**.9470**	**.8480**	**.4913**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD-II S/DN.[106] BU 5916
Substation No/ Name :- 254008 / TALBID
Feeder No / Name : 206 / 11 KV Talbid Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0526	.0514	1.1603	1.2851	1.2517	.0526	.0532
2	.0532	.0514	1.2125	1.2851	1.2689	.0532	.0532
3	.0526	.0514	1.2289	1.3032	1.3032	.0351	.0537
4	.0532	.0497	1.2146	1.3032	1.3032	.0354	.0537
5	.0532	.0514	1.2289	1.3213	1.3717	.0354	.0532
6	.0526	.0514	1.3279	1.3575	1.4232	.0526	.0532
7	.0709	.0686	1.5524	1.7013	1.6448	.0693	.0526
8	.0693	.0686	1.6518	1.8642	1.7465	.0693	.0526
9	1.6032	1.8176	.0526	.0724	.0514	1.8299	1.9595
10	1.9004	1.8099	.0514	.0693	.052	2.2291	2.0567
11	1.8642	1.8823	.0514	.0701	.003	1.9376	2.0729
12	2.0271	1.8107	.0514	.0701	.0526	2.2805	2.1548
13	2.0452	1.7926	.0686	.0709	.0526		1.5384
14	2.0814	1.8823	.0514	.0532	.052	1.989	1.7814
15	2.1357	1.8823	.0686	.0526	.052	2.1948	1.8896
16	2.1357	1.9547	.0514	.0526	.0526	1.9719	1.989
17	.0543	.0709	.0514	.0526	.0701	.0686	.0857
18	.0693	.0876	.0732	.0678	.0867	.0876	.1029
19	.1029	.0876	.0914	.0686	.1029	.104	.0857
20	.0857	.0876	.0724	.0857	.0876	.0867	.0857
21	.0857	.0867	.0724	.0857	.0709	.0876	.0857
22	.0686	.0701	.0543	.0686	.0709	.0709	.0686
23	.0514	.0709	.0543	.0514	.0526	.0532	.0686
24	.0526	.0514	.0532	.0549	.0514	.0532	.0526
Max	**2.1357**	**1.9547**	**1.6518**	**1.8642**	**1.7465**	**2.2805**	**2.1548**
Min	**.0514**	**.0497**	**.0514**	**.0514**	**.003**	**.0351**	**.0526**
Avg	**.7009**	**.6620**	**.4811**	**.5195**	**.5114**	**.6716**	**.6876**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD-II S/DN.[106] **BU 5916**
Substation No/ Name :- 254008 / TALBID
Feeder No / Name : 207 / MIDC-III **SHEDDABLE FEEDER HAVING WEEKLY**
Feeder KV- 11 / OUTGOING **STAGGERING (MIDC, EQUIVALENT)**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4557	.439	.4733	.4163	.4108	.4733	.4908
2	.443	.4338	.4607	.4024	.4481	.4607	.4961
3	.4382	.3841	.4784	.3841	.4481	.4733	.4835
4	.4252	.4024	.4908	.3841	.4668	.4908	.5014
5	.4382	.439	.4961	.4024	.4854	.5138	.4961
6	.4508	.4527	.4908	.4207	.4755	.5083	.4784
7	.4382	.439	.4557	.4207	.439	.4908	.4908
8	.4854	.5121	.5201	.5121	.4207	.5548	.443
9	.5721	.6219	.5658	.5853	.4251	.6219	.4207
10	.6584	.9328	.823	.8215	.6783	.8131	.4715
11	.8596	.9145	.9511	.8139	.8478	.9694	.3772
12	.8686	.9412	.9511	.7545	.823	.8779	.415
13	.7865	.823	.8501	.7545	.8048	.7499	.4904
14	.823	.9511	.8871	.6241	.6859	.6401	.4338
15	.8596	.7499	.9328	.78	.8886	.9055	.415
16	.8962	.8413	1.0791	.8402	.8573	.8779	.4527
17	.8596	.7202	.8413	.6068	.7282	.8413	.4904
18	.5121	.5959	.4163	.462	.5895	.5434	.3658
19	.3841	.5487	.4024	.3658	.5083	.3898	.4108
20	.3658	.4382	.3881	.3881	.4557	.4031	.3475
21	.3696	.4508	.3841	.4066	.4557	.3898	.4066
22	.4251	.4557	.4024	.4066	.4557	.4557	.4251
23	.439	.4733	.4251	.4108	.4854	.4607	.439
24	.4557	.439	.4733	.439	.4024	.4733	.4908
Max	**.8962**	**.9511**	**1.0791**	**.8402**	**.8886**	**.9694**	**.5014**
Min	**.3658**	**.3841**	**.3841**	**.3658**	**.4024**	**.3898**	**.3475**
Avg	**.5712**	**.6000**	**.6100**	**.5334**	**.5703**	**.5991**	**.4472**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD-II S/DN.[106] **BU 5916**
Substation No/ Name :- 254008 / TALBID
Feeder No / Name : 208 / MIDC- IV **SHEDDABLE FEEDER HAVING WEEKLY**
Feeder KV- 11 / OUTGOING **STAGGERING (MIDC, EQUIVALENT)**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2126	.2743	.2481	.2172	.2561	.2303	.2658
2	.2103	.2561	.2481	.1991	.2427	.2126	.2481
3	.2103	.2641	.2328	.181	.2743	.2149	.2507
4	.2126	.2829	.2481	.1829	.2801	.2126	.2534
5	.2103	.3174	.2686	.2195	.2801	.2103	.2507
6	.2303	.3109	.2835	.2561	.2743	.2279	.2835
7	.2126	.2772	.2804	.2743	.2801	.2303	.2481
8	.2279	.2561	.2454	.2012	.3292	.2454	.2328
9	.3121	.2743	.2774	.2926	.3881	.3292	.2126
10	.439	.3841	.4207	.4409	.463	.499	.2263
11	.4755	.3841	.5068	.4161	.4917	.5853	.2641
12	.439	.4755	.4435		.407	.5121	.2829
13	.3326	.3475	.4066	.3681	.3772	.439	.2263
14	.4572	.3881	.4435	.4382	.3944	.5304	.2075
15	.4755	.4207	.5121	.4973	.4287	.5601	.2263
16	.4572	.4805	.5601	.4854	.4161	.4755	.2641
17	.4207	.4161	.4938	.463	.3467	.3841	.2641
18	.3292	.3506	.3109	.4344	.2629	.2835	.2241
19	.3292	.3155	.3142	.3475	.2947	.2658	.2241
20	.3109	.2804	.2896	.2801	.3155	.1791	.2427
21	.3174	.2835	.2534	.2772	.2835	.2454	.2561
22	.2957	.2658	.2561	.2772	.2481	.2658	.2587
23	.2926	.2804	.2772	.2829	.2454	.298	.2427
24	.2126	.2715	.2481	.2378	.2743	.2303	.2658
Max	**.4755**	**.4805**	**.5601**	**.4973**	**.4917**	**.5853**	**.2835**
Min	**.2103**	**.2561**	**.2328**	**.181**	**.2427**	**.1791**	**.2075**
Avg	**.3176**	**.3274**	**.3362**	**.3161**	**.3273**	**.3278**	**.2467**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD-II S/DN.[106] **BU 5916**
Substation No/ Name :- 254008 / TALBID
Feeder No / Name : 401 / HINDUSTAN **NON SHEDDABLE EXPRESS HV FEEDERS**
Feeder KV- 33 / OUTGOING **(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0725	3.4374	3.3608	3.0178	3.1367	2.7446	3.5482
2	2.0165	3.3265	3.3608	3.0178	3.0247	2.7721	3.5482
3	2.0513	2.7938	3.0807	2.9938	3.0807	2.7721	3.6408
4	2.0725	2.9938	2.9687	2.9321	3.1367	2.8829	3.6037
5	2.1068	2.963	2.9384	3.0178	3.2487	3.1602	3.6969
6	2.1068	2.9938	2.3525	3.0727	3.4168	3.1047	3.6591
7	2.1622	3.2156	2.7721	2.963	3.4728	3.1602	3.6408
8	2.2731	2.9687	3.1602	3.4168	3.1047	3.1367	3.1047
9	3.1047	3.0807	3.0493	3.3665	3.0247	3.1824	2.2965
10	2.7446	2.5789	3.1367	2.6886	3.0247	3.0493	1.6975
11	3.1824	2.9687	3.3048	3.2156	3.0493	3.6408	1.8004
12	3.0807	3.0556	2.9081	2.8567	2.9938	3.1927	1.6827
13	3.0556	3.1276	2.8829	3.0807	3.0247		1.6301
14	3.7146	3.3608	3.3265	3.3819	3.2156	3.7311	1.6461
15	3.7529	3.4728	3.3608	3.4928	3.1602	3.8409	1.9765
16	3.8649	3.6969	3.6408	3.4168	3.271	3.6214	2.3388
17	3.4168	3.3048	3.3471	1.0082	2.6886	3.1824	2.1325
18	3.2373	3.5482	3.3471	3.2156	2.7721	3.1602	2.2965
19	3.5117	3.3819	3.4019	3.2922	2.5766	3.1927	2.1948
20	3.2922	3.5482	3.4928	3.1824	2.4646	3.271	2.1948
21	3.0247	3.3048	3.2922	3.1602	2.4949	3.2487	2.2497
22	3.3265	3.6037	3.2922	3.1047	2.5503	3.3265	2.2731
23	3.3265	3.4374	3.2156	3.2487	2.4863	3.1927	2.2731
24	2.1845	3.5117	3.3608	3.0407	3.1927	2.6326	3.1602
Max	**3.8649**	**3.6969**	**3.6408**	**3.4928**	**3.4728**	**3.8409**	**3.6969**
Min	**2.0165**	**2.5789**	**2.3525**	**1.0082**	**2.4646**	**2.6326**	**1.6301**
Avg	**2.8618**	**3.2365**	**3.1814**	**3.0493**	**2.9838**	**3.1826**	**2.5952**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD-II S/DN.[106] **BU 5916**
Substation No/ Name :- 254008 / TALBID
Feeder No / Name : 402 / 33 KV Khodashi Power plant Feeder KV- 33 / OUTGOING **NON SHEDDABLE EXPRESS HV FEEDERS (NON-CONTINOUS PROCESS)(NO STAGGERING)**

DATE	01-NOV-17
HR	Load (MW)
23	.0914
24	.1029
Max	.1029
Min	.0914
Avg	.0972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD-II S/DN.[106] **BU 5916**
Substation No/ Name :- 254067 / 11KV Tembhu Switching Station
Feeder No / Name : 201 / KARVE Ag Feeder KV- 11 / OUTGOING **SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1581	.1562	1.0059	.9374	.9511	.2103	.1852
2	.1562	.1581	.9934	.9374	1.0105	.1753	.1635
3	.16	.1581	.9783	.9374	1.0105	.1928	.1656
4	.1802	.176	.9808	.9259	1.0235	.2328	.192
5	.2229	.208	1.0364	.9877	1.0235	.3077	.2374
6	.2957	.2949	1.1265	1.2037	1.2346	.3511	.3292
7	.3326	.3841	1.3123	1.3592	1.5181	.4163	.362
8	.3258	.3658	1.5154	1.4998	1.5051	.3189	.3658
9	1.3272	1.5089	.2267	.2103	.2804	1.7901	1.7535
10	1.4815	1.7185	.1989	.2481	.208	1.9136	2.0062
11	1.5623	1.7078	.125	.1389	.2254	1.9136	2.1872
12	1.5432	1.7869	.192	.1658	.2401	1.9372	2.2184
13	1.4815	1.7185	.1875	.2401	.2372	1.9753	2.234
14	1.2803	1.7497	.192	.2103	.2012	2.037	2.1403
15	1.2963	1.6716	.2012	.2103	.2012	1.7071	2.1091
16	1.2643	1.6716	.1966	.1989	.2458	1.7238	1.6461
17	.1875	.1966	.2058	.2187	.2543	.1829	.1966
18	.2321	.25	.2195	.2035	.2883		.25
19	.2804	.2835	.2195	.2804	.3506	.2883	.2804
20	.2774	.2774	.2926	.2683	.3155	.2785	.2561
21	.2804	.2601	.2926	.2683	.3224	.2753	.2652
22	.2481	.218	.2561	.2035	.3045	.2372	.2622
23	.2149	.1943	.2149	.1966	.2686	.1806	.1852
24	.1562	.176	.1898	.2172	.192	.2481	.1806
Max	**1.5623**	**1.7869**	**1.5154**	**1.4998**	**1.5181**	**2.037**	**2.234**
Min	**.1562**	**.1562**	**.125**	**.1389**	**.192**	**.1753**	**.1635**
Avg	**.6227**	**.7204**	**.5150**	**.5112**	**.5589**	**.8215**	**.8405**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD-II S/DN.[106] **BU 5916**
Substation No/ Name :- 254067 / 11KV Tembhu Switching Station
Feeder No / Name : 202 / TEMBHU LIS **PURELY LIS FEEDERS**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1591	1.2125	.7133	1.1584	.9596	.9846
2	1.1443	1.2742	.7133	1.1294	1.086	.9859
3	1.1439	1.2308	.743	1.1145	1.1003	.9869
4	1.1145	1.2323	.7335	1.1443	1.1003	.9991
5	1.1439	1.278	.7628	1.2191	1.1888	1.0122
6	1.1439	1.3077	.7922	1.4661	1.4175	1.0551
7	1.2186	1.5804	.7727	1.4998	1.3969	1.0837
8	1.3546	1.7985	.8509	1.7459	1.5202	1.4352
9	1.6309	1.0292	1.1443	1.4784	1.8982	1.4712
10	1.6556	1.8576	.7468	1.7497	1.8519	1.5051
11	1.5804	1.9052		1.5339	1.8827	1.3117
12	1.5503		.8916	1.6204	1.8519	1.6358
13	1.6857		1.4784	1.5954	1.9444	1.3717
14	1.0837	1.0212	1.6049	1.6309	1.9599	1.3272
15	1.7375	1.0212		1.6255	1.4022	1.2963
16	.7716		.598	1.3672	1.3077	.9332
21				.3224		
Max	**1.7375**	**1.9052**	**1.6049**	**1.7497**	**1.9599**	**1.6358**
Min	**.7716**	**1.0212**	**.598**	**.3224**	**.9596**	**.9332**
Avg	**1.3199**	**1.3653**	**.8961**	**1.3765**	**1.4918**	**1.2122**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD-II S/DN.[106] **BU 5916**
Substation No/ Name :- 254067 / 11KV Tembhu Switching Station
Feeder No / Name : 206 / 11 KV Karve Gaothan **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2452	.2452	.2452	.2241	.1829	.2452	.2641
2	.2263	.2378	.2263	.2241	.1848	.2452	.2452
3	.2263	.2427	.2263	.2241	.2075	.2829	.2452
4	.2263	.2641	.2641	.2561	.2241	.3018	.2641
5	.4338	.4715	.4338	.4024	.3361	.3772	.3772
6	.7842	.8215	.7733	.7164	.7023	.7733	.7167
7	.8775	.9335	.8962	.8596	.8962	.9795	.8676
8	.6908	.7023	.7842	.8059	.8131	.7762	.6653
9	.4435	.4706	.5304	.591	.5487	.5304	.5249
10	.439	.4298	.394	.4119	.443	.4344	.4075
11	.3982	.333	.362	.3982	.4382	.3658	.3814
12	.3841	.3366	.3841	.3258	.3772	.394	.3086
13	.3224	.3403	.3641	.3224	.3224	.3582	.3189
14	.3439	.3761	.3506	.3292	.3155	.3077	.3761
15	.3258	.3544	.3403	.3439	.298	.3475	.3761
16	.3475	.3761	.3982	.3077	.3294	.3475	.3258
17	.3982	.3582	.4344	.3841	.3772	.3982	.3856
18	.5028	.5258	.5611	.5792	.4908	.4961	.567
19	.6535	.6468	.7164	.6401	.6584	.6401	.6661
20	.6348	.6099	.6089	.6468	.6036	.6099	.6556
21	.6161	.6161	.5731	.5487	.5729	.5788	.6135
22	.5175	.4854	.4887	.4572	.4805	.4668	.5316
23	.3395	.3018	.3109	.2561	.3142	.3206	.3361
24	.2452	.2641	.2427	.2241	.2033	.2614	.2641
Max	**.8775**	**.9335**	**.8962**	**.8596**	**.8962**	**.9795**	**.8676**
Min	**.2263**	**.2378**	**.2263**	**.2241**	**.1829**	**.2452**	**.2452**
Avg	**.4426**	**.4477**	**.4546**	**.4366**	**.4300**	**.4516**	**.4452**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD-II S/DN.[106] BU 5916
Substation No/ Name :- 254073 / 33/11 KV VADGAON H
Feeder No / Name : 201 / 11 KV VADGAON GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2772	.2561	.2534	.2587	.2926	.2926
2	.2743	.2801	.2561	.2534	.2587	.2926	.2743
3	.2772	.2801	.2561	.2534	.2427	.2926	.2743
4	.3511	.3547	.3142	.3292	.3395	.3881	.3475
5	.4251	.4251	.4066	.4066	.415	.499	.4435
6	.5175	.5175	.5175	.499	.5228	.5544	.5359
7	.5487	.5914	.5729	.567	.5914	.5973	.5853
8	.3721	.4298	.4344	.4163	.4298	.443	.4075
9	.3429	.3506	.3467	.3988	.3601	.3696	.3467
10	.3149	.3149	.3481	.3429	.3222	.3391	.3222
11	.3149	.2949	.2984	.2543	.3353	.2347	.3018
12	.3149	.2915	.2984	.285	.3239	.2785	.3315
13	.2949	.2753	.2321	.285	.3113	.2949	.2818
14	.2652	.2321	.2486	.2347	.2622	.285	.208
15	.2818	.2401	.2486	.1943	.2622	.2683	.2374
16	.2818	.1943	.2652	.2591	.2818	.2949	.2515
17	.2818	.213	.2591	.2652	.2818	.2984	.2622
18	.3429	.3521	.3429	.3561	.3601	.3391	.3429
19	.4119	.4298	.4298	.4525	.4252	.443	.4252
20	.4656	.4119	.4119	.4298	.4607	.4706	.4477
21	.4525	.4119	.4163	.4344	.4477	.4835	.4525
22	.439	.3761	.362	.3475	.4344	.3982	.4207
23	.3403	.3012	.2835	.2926	.3544	.3544	.3403
24	.2686	.2926	.2534	.2507	.2534	.3045	.2865
Max	**.5487**	**.5914**	**.5729**	**.567**	**.5914**	**.5973**	**.5853**
Min	**.2652**	**.1943**	**.2321**	**.1943**	**.2427**	**.2347**	**.208**
Avg	**.3523**	**.3391**	**.3358**	**.3359**	**.3556**	**.3673**	**.3508**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD-II S/DN.[106] BU 5916
Substation No/ Name :- 254073 / 33/11 KV VADGAON H
Feeder No / Name : 202 / 11 KV VADGAON AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1509	1.0155	.9842	.9374	.1698	.1509
2	.1494	.1509	.9722	.9842	.9374	.1698	.1509
3	.1494	.1509	.9722	.9842	.8951	.1509	.1509
4	.1494	.1509	.9842	.9722	.9145	.1698	.1509
5	.1494	.168	.9998	.9722	.9568	.1886	.1509
6	.168	.1848	1.0031	1.0311	.9722	.1886	.1698
7	.168	.1848	1.0936	1.1248	.9686	.2054	.1886
8	.168	.2033	1.1544	1.0936	1.0279	.2054	.168
9	1.0974	1.0936	.1294	.2012	.1886	1.1092	1.2809
10	1.0936	1.2498	.1663	.2054	.2033	1.2809	1.3757
11	1.0311	1.3279	.1886	.2241	.2075	1.3283	1.3916
12	1.078	1.3592	.2033	.1886	.2054	1.3123	1.3916
13	1.1561	1.3123	.1886	.1509	.2241	1.2018	1.3757
14	1.0936		.1698	.1886	.2054	1.2651	1.2492
15	1.1544	1.3123	.1886	.2054	.2241	1.3123	1.3283
16	1.2186	1.2654	.1698	.1867	.2241	1.2654	1.3441
17	.1509	.1629	.168	.168	.1886	.1886	.132
18		.1663	.2054	.2054	.2218	.1867	.1698
19	.1612	.181	.2054	.1886	.2012	.1886	.1698
20	.168	.1663	.1867	.1886	.1886	.1886	.1698
21	.1698	.1663	.1886	.1886	.1698	.1698	.1698
22	.1698	.1663	.1886	.1886	.1698	.1698	.1698
23	.1698	.1448	.1867	.1886	.1698	.1509	.1509
24	.1494	.1509	.1463	.1848	.1698	.1698	.1509
Max	**1.2186**	**1.3592**	**1.1544**	**1.1248**	**1.0279**	**1.3283**	**1.3916**
Min	**.1494**	**.1448**	**.1294**	**.1509**	**.1698**	**.1509**	**.132**
Avg	**.4919**	**.5030**	**.4615**	**.4666**	**.4488**	**.5390**	**.5542**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD-II S/DN.[106] BU 5916
Substation No/ Name :- 256011 / 110 KV TEMBHU
Feeder No / Name : 204 / TEMBHU Gaonthan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1646	.1772	.1463	.1463	.1463	.1646	.1646
2	.1629	.181	.1463	.1463	.1629	.1463	.1478
3	.1646	.1629	.1448	.1463	.1629	.1463	.1463
4	.1829	.1791	.1646	.1829	.1612	.1663	.1646
5	.2195	.2328	.2172	.2195	.1991	.2033	.2012
6	.3142	.4075	.394	.3224	.3721	.3475	.3982
7	.3403	.4607	.4557	.4477	.443	.4207	.4252
8	.3012	.4733	.4207	.4075	.4191	.4115	.4161
9	.3467	.3978	.3812	.4382	.4024	.3932	.3768
10	.2622	.3772	.3563	.2515	.3647	.2458	.3041
11	.3401	.2279	.2321	.2846	.2374	.3163	.2321
12	.2321	.2303	.2294	.253	.2294	.2656	.2155
13	.2267	.2303	.2486	.218	.2321	.2486	.2321
14	.2656	.2454	.2458	.2561	.2688	.3239	.2721
15	.3605	.2481	.2294	.3795	.2343	.3113	.2591
16	.3201	.3582	.3361	.3479	.3125	.3549	.2818
17	.3953	.3582	.3429	.4167	.3441	.3841	.2753
18	.4049	.3681	.4557	.4801	.4428	.3637	.3681
19	.4801	.3506	.3761	.4508	.4115	.3467	.3506
20	.463	.3366	.3582	.4031	.333	.3012	.3189
21	.3224	.3045	.3077	.3077	.3155	.2804	.3366
22	.2926	.2328	.2507	.3012	.2804	.2507	.3045
23	.2317	.1829	.181	.181	.2126	.1991	.2686
24	.2115	.1949	.1448	.1463	.1791	.1791	.1646
Max	**.4801**	**.4733**	**.4557**	**.4801**	**.443**	**.4207**	**.4252**
Min	**.1629**	**.1629**	**.1448**	**.1463**	**.1463**	**.1463**	**.1463**
Avg	**.2919**	**.2883**	**.2819**	**.2973**	**.2861**	**.2821**	**.2760**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD-II S/DN.[106] **BU 5916**
Substation No/ Name :- 256012 / 110 KV Rethare
Feeder No / Name : 201 / Rethare Gaonthan (Karkhana) Feeder KV- 11 / OUTGOING **GAOTHAN FEEDER**

DATE	01-NOV-17
HR	Load (MW)
24	.1448
Max	.1448
Min	.1448
Avg	.1448

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD-II S/DN.[106] **BU 5916**
Substation No/ Name :- 256012 / 110 KV Rethare
Feeder No / Name : 203 / RETHARE AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17
HR	Load (MW)
24	.0819
Max	.0819
Min	.0819
Avg	.0819

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD-II S/DN.[106] **BU 5916**
Substation No/ Name :- 256012 / 110 KV Rethare
Feeder No / Name : 204 / SHENOLI AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17
HR	Load (MW)
24	.3353
Max	.3353
Min	.3353
Avg	.3353

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
KARAD-II S/DN.[106] **BU 5916**
Substation No/ Name :- 256012 / 110 KV Rethare
Feeder No / Name : 209 / Rethare LIS **PURELY LIS FEEDERS**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
24	.0305
Max	.0305
Min	.0305
Avg	.0305

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
MALHAR PETH S/DN[109] **BU 5941**
Substation No/ Name :- 254022 / MALHARPETH
Feeder No / Name : 201 / MUNDHA **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.4733	.0747	.0876	.1052	.9602	
2	.3429	.4733	.0747	.0876	.1052	.9602	
3	.3429	.4733	.0747	.0876	.1052	1.0288	
4	.3429	.4733	.0747	.0876	.1052	1.0288	
5	.4115	.4733	.0739	.0876	.1052	1.0288	
6	.4973	.631	.0739	.0876	.1052	1.046	
7	.6859	1.0288	.0914	.1029	.12	1.2346	.503
8	1.0631	1.0974	.0914	.0857	.1543	1.5261	.503
9	.0732	.0701	1.773	1.4918	1.7071	.1029	.0514
10	.1097	.0934	1.9547	1.3717	1.9357	.1029	.0857
11	.112		1.8176	1.9204	1.8595	.0857	.0857
12	.1097	.0934	1.8176	2.1262	1.7985	.0857	.0686
13	.0934	.0747	1.749	2.1605	1.4937	.1029	.0686
14	.0747	.0747	1.749	1.989	1.6004	.0343	.0686
15	.056	.0747	1.7147	1.8861	1.6461	.0514	.0686
16	.0934	.0747	1.5432	1.8519	1.7071	.0514	1.046
17	.0934	.0747	.0514	.12	.0914	.061	1.0631
18	.1029	.0934	.0526	.1578	.12	.061	.0934
19	.1052	.0934	.0876	.1578	.0857	.061	.112
20	.1052	.0934	.0876	.1578	.1029	.0762	.0934
21	.1052	.0934	.0876	.1402	.1029	.0762	.0934
22	.0876	.0747	.0876	.1402	.1029	.0762	.0934
23	.0876	.0747	.0876	.1402	.1029	.0762	.0934
24	.2838	.0876	.0747	.0876	.1227	.1029	.0762
Max	**1.0631**	**1.0974**	**1.9547**	**2.1605**	**1.9357**	**1.5261**	**1.0631**
Min	**.056**	**.0701**	**.0514**	**.0857**	**.0857**	**.0343**	**.0514**
Avg	**.2356**	**.2767**	**.6402**	**.6922**	**.6452**	**.4176**	**.2371**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
MALHAR PETH S/DN[109] **BU 5941**
Substation No/ Name :- 254022 / MALHARPETH
Feeder No / Name : 202 / LIS **FEEDER SEPERATION/PURE AG**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.056	.0876	.0876		
2			.0549	.0876	.0876		
3			.056	.0876	.0876		
4			.056	.0876	.0876		
5			.056	.0876	.0876		
6			.056	.0876	.0876		
7			.0549	.12	.12		
8			.1097	.1372	.1372		
9	.0732	.0701				.1372	.1886
10	.1097	.112				.1543	.2572
11	.112	.112				.2401	.1886
12	.112	.112				.2401	.2058
13	.0747	.112				.2058	.2058
14	.0747	.112				.2058	.2058
15	.056	.0934				.1886	.2058
16	.0747	.0934				.1886	.2058
24	.1029						
Max	**.112**	**.112**	**.1097**	**.1372**	**.1372**	**.2401**	**.2572**
Min	**.056**	**.0701**	**.0549**	**.0876**	**.0876**	**.1372**	**.1886**
Avg	**.0878**	**.1021**	**.0624**	**.0979**	**.0979**	**.1951**	**.2079**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
MALHAR PETH S/DN[109] BU 5941
Substation No/ Name :- 254022 / MALHARPETH
Feeder No / Name : 203 / GANDHITEKADI GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
24	.0171
Max	.0171
Min	.0171
Avg	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
MALHAR PETH S/DN[109] BU 5941
Substation No/ Name :- 254022 / MALHARPETH
Feeder No / Name : 204 / MARALI GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1753	.2054	.1753	.1753	.1715	.2058
2	.1715	.1753	.2054	.1753	.1753	.1715	.2058
3	.1715	.1753	.2054	.1753	.1753	.1715	.2058
4	.1715	.1753	.2054	.1753	.1753	.2058	.2058
5	.2401	.1753	.2801	.2629	.2103	.2743	.2743
6	.3258	.3086	.4481	.3856	.3506	.3944	.3429
7	.3772	.4458	.5601	.463	.4458	.4115	.4801
8	.4801	.463	.4938	.4801	.4801	.463	.4973
9	.439	.4287	.4525	.3658	.4115	.4115	.4287
10	.3841	.439	.3772	.3353	.3944	.3921	.3772
11	.4024	.4207	.3772	.3429	.3601	.3429	.3429
12	.4207	.3841	.3429	.3429	.3772	.3429	.3429
13	.4207	.3658	.2229	.3429	.3772	.3772	.3429
14	.4207	.3658	.3086	.3086	.3601	.3601	.3048
15	.4024	.3658	.3086	.2743	.3601	.3601	.3258
16	.3658	.3841	.3258	.3086	.3772	.3772	.3429
17	.4481	.4024	.3429	.3772	.3944	.4115	.3601
18	.5144	.5487	.463	.4382	.4801	.463	.5041
19	.631	.6767	.631	.6661	.5487	.583	.6767
20	.631	.5853	.631	.631	.6344	.6516	.6036
21	.5959	.5121	.5258	.4908	.5144	.4973	.5121
22	.4207	.4108	.3681	.3681	.4115	.3944	.4207
23	.2454	.3361	.3155	.2279	.2572	.2572	.3658
24	.1715	.1928	.2054	.1753	.1753	.2058	.2058
Max	**.631**	**.6767**	**.631**	**.6661**	**.6344**	**.6516**	**.6767**
Min	**.1715**	**.1753**	**.2054**	**.1753**	**.1753**	**.1715**	**.2058**
Avg	**.3760**	**.3714**	**.3668**	**.3454**	**.3592**	**.3621**	**.3698**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
MALHAR PETH S/DN[109] BU 5941
Substation No/ Name :- 254022 / MALHARPETH
Feeder No / Name : 205 / 11 KV Gandhi Tekdi Ag Feeder KV- 11 / OUTGOING SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER

DATE	01-NOV-17
HR	Load (MW)
24	.0343
Max	.0343
Min	.0343
Avg	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
MALHAR PETH S/DN[109] BU 5941
Substation No/ Name :- 254022 / MALHARPETH
Feeder No / Name : 206 / SOMAIDEVI LIS EXPRESS FEEDER Feeder KV- 11 / OUTGOING

PURELY LIS FEEDERS

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0351	.0187			.0343
2		.0351	.0187			.0343
3		.0351	.0187			.0343
4		.0351	.0187			.0343
5		.0351	.0187			.0343
6		.0351	.0373			.0343
7		.0351	.0373			.0343
8		.0686	.0373	.2058	.3429	.3601
9	.2561	.1543	.2054	.2229	.3658	.3601
10	.3109	.168	.1886	.2229	.3658	.3601
11	.3292	.0934	.1886	.2401	.381	.3601
12	.3475	.0747	.1715	.2401	.381	.3601
13	.0914	.0747	.0686	.2401	.4115	.3601
14	.0732	.0747	.1372	.2401	.3353	.3601
15	.0732	.0747	.1543	.2401	.3201	.3601
16		.0187	.1543	.2401	.3201	.2229
Max	**.3475**	**.168**	**.2054**	**.2401**	**.4115**	**.3601**
Min	**.0732**	**.0187**	**.0187**	**.2058**	**.3201**	**.0343**
Avg	**.2116**	**.0655**	**.0921**	**.2325**	**.3582**	**.2090**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
MALHAR PETH S/DN[109] BU 5941
Substation No/ Name :- 254025 / 33/11 KV DHEBEWADI
Feeder No / Name : 201 / 11 KV Kalgaon Gaothan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1294	.1147	.12	.1107	.1341	.1578	.1402
2	.1086	.1147	.12	.1107	.1341	.1578	.1402
3	.1075	.1254	.12	.1107	.1174	.1578	.1402
4	.1307	.1254	.12	.1107	.1174	.1227	.1402
5	.1478	.1433	.1372	.1311	.1387	.1417	.181
6	.2218	.2378	.2772	.2328	.2378	.2772	.2561
7	.4298	.4251	.4435	.4119	.4572	.4435	.4435
8	.5041	.439	.439	.4119	.4525	.4755	.439
9	.3921	.3982	.362	.394	.3982	.3761	.3582
10	.362	.3045	.3189	.3258	.3582	.298	.3155
11	.3012	.2686	.2629	.2865	.2896	.3155	
12	.2804	.197	.2774	.2427	.2534	.218	
13	.2279	.197	.2103	.2172	.2172	.2035	
14	.2279	.1629	.1753	.197	.2172	.1526	.208
15	.2481	.1629	.1543	.1991	.2172	.1357	.2254
16	.2481	.1715	.1886	.2172	.2353	.1823	.2254
17		.2561	.253	.2774	.2715	.2543	.2427
18		.4298	.3294	.3086	.3772	.3506	.298
19		.6099	.567	.5853	.6099	.6099	.5359
20		.5544	.5175	.5304	.5175	.5175	.5175
21		.4435	.4024	.439	.4207	.4251	.4251
22		.3077	.2427	.2804	.2658	.2658	.3077
23	.2033	.1802	.1907	.16	.1802	.1619	.208
24	.1294	.1311	.1524	.1269	.1189	.156	.1235
Max	**.5041**	**.6099**	**.567**	**.5853**	**.6099**	**.6099**	**.5359**
Min	**.1075**	**.1147**	**.12**	**.1107**	**.1174**	**.1227**	**.1235**
Avg	**.2445**	**.2709**	**.2659**	**.2674**	**.2807**	**.2732**	**.2796**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
MALHAR PETH S/DN[109] BU 5941
Substation No/ Name :- 254025 / 33/11 KV DHEBEWADI
Feeder No / Name : 202 / 11 KV Jinti Gaothan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0819	.1029	.0791	.0838	.0876	.0701
2	.0934	.0655	.0857	.0791	.0838	.0876	.0701
3	.0924	.0716	.0857	.0791	.0838	.0876	.0701
4	.0934	.0716	.0857	.0791	.0838	.0876	.0701
5	.0934	.0716	.0857	.0819	.0867	.0886	.0905
6	.0914	.128	.1086	.1075	.1097	.1478	.1097
7	.2241	.2218	.2218	.2149	.2012	.2218	.2402
8	.2218	.2195	.1829	.2149	.2353	.2378	.2378
9	.1629	.1829	.1448	.1595	.181	.1791	.1791
10	.1448	.1433	.1063	.124	.1578	.1402	.1402
11	.124	.1254	.0701	.104	.1417	.1402	
12	.1052	.1254	.1214	.1772	.1402	.1341	
13	.0701	.1075	.1052	.1052	.1372	.1017	
14		.1086	.1052	.1052	.1187	.1017	.1214
15	.0886	.1448	.12	.1075	.1187	.0848	.1214
16	.248	.1372		.1448	.1227	.1326	.104
17	.2804	.1463	.1581	.1823	.1509	.1526	.1387
18	.319	.1791	.156	.1715	.2058	.1753	.2103
19	.5974	.4804	.2926	.3292	.2957	.2772	.3142
20	.6348	.2402	.2957	.2926	.2772	.2587	.2957
21	.5174	.2033	.128	.2743	.2561	.2402	.2587
22	.4024	.1448	.156	.1753	.1772	.1772	.1991
23	.1214	.1147	.1214	.112	.1147	.1134	.1387
24	.0905	.0983	.1067	.1974	.1189	.1214	.0926
Max	**.6348**	**.4804**	**.2957**	**.3292**	**.2957**	**.2772**	**.3142**
Min	**.0701**	**.0655**	**.0701**	**.0791**	**.0838**	**.0848**	**.0701**
Avg	**.2135**	**.1506**	**.1368**	**.1541**	**.1534**	**.1490**	**.1558**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
MALHAR PETH S/DN[109] **BU 5941**
Substation No/ Name :- 254025 / 33/11 KV DHEBEWADI
Feeder No / Name : 203 / SANBUR **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1294	.1147	.12	.1107	.1341	.1227	.1402
2	.1307	.1147	.12	.1107	.1341	.1227	.1402
3	.1307	.1254	.12	.1107	.1341	.1227	.1402
4	.1478	.1254	.12	.1265	.1341	.1402	.1402
5	.1848	.1433	.1372	.1475	.1734	.1595	.181
6	.2772	.2743	.2772	.2686	.2743	.2772	.2743
7	.4668	.462	.4805	.4477	.4572	.4805	.462
8	.4435	.439	.439	.4477	.4344	.4755	.439
9	.3326	.362	.3801	.394	.362	.394	.3582
10	.3077	.3582	.3012	.3403	.3439	.3155	.2804
11	.2658	.2865	.2629	.2865	.2658	.2454	
12	.2279	.2686	.1907	.2353	.2454	.218	
13	.1928	.2507	.1753	.181	.1829	.2035	
14	.1928	.181	.1753	.1629	.181	.1696	.2427
15	.2103	.181	.1886	.1612	.181	.1526	.208
16	.2126		.1715		.2378	.1658	.1907
17	.2804	.2195	.2214	.3077	.2561	.2035	.2254
18	.3544	.2686	.2774	.3601	.3258	.3155	.298
19	.6161	.5729	.567	.5853	.5729	.5359	.5359
20	.4668	.499	.4805	.4938	.499	.499	.4805
21	.4251	.4251	.4024	.4207	.4207	.4251	.4435
22	.2743	.2715	.2427	.2629	.2481	.2743	.3258
23	.156	.1311	.1734	.144	.1475	.1457	.1907
24	.1267	.1147	.1067	.0987	.1189	.1387	.1235
Max	**.6161**	**.5729**	**.567**	**.5853**	**.5729**	**.5359**	**.5359**
Min	**.1267**	**.1147**	**.1067**	**.0987**	**.1189**	**.1227**	**.1235**
Avg	**.2731**	**.2691**	**.2555**	**.2698**	**.2694**	**.2626**	**.2772**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
MALHAR PETH S/DN[109] BU 5941
Substation No/ Name :- 254025 / 33/11 KV DHEBEWADI
Feeder No / Name : 204 / TALMAVALE GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1475	.1372	.1265	.1677	.1402	.1578
2	.168	.1475	.1372	.1265	.1677	.1402	.1578
3	.168	.1612	.1372	.1265	.1677	.1402	.1578
4	.1848	.1612	.1372	.1265	.1677	.1402	.1578
5	.2218	.1791	.1715	.1966	.1907	.1772	.1991
6	.2987	.3109	.3326	.2507	.2926	.3696	.3475
7	.5175	.4805	.462	.3224	.5121	.5304	.5359
8	.5415	.5121	.5121	.3582	.5611	.5487	.6036
9	.3921	.4706	.4525	.3258	.4887	.4477	.4835
10	.3077	.4298	.4252	.3258	.4477	.3856	.3856
11	.3544	.3224	.3506	.3814	.3761	.2804	.3856
12	.3155	.3224	.3467	.3761	.362		
13	.2804	.3224	.2629	.181	.3258	.3222	
14	.2629	.2896	.2454	.3077	.2926	.3222	.3294
15	.1949	.2534	.2743	.3258	.3109	.3391	.3294
16	.2835	.2572	.2915	.362	.3174	.2984	.3121
17		.3109	.253	.3506	.3109	.3391	.3121
18		.5014	.3641	.3944	.3944	.3856	.3506
19		.5914	.439	.5853	.5544	.5729	.5729
20		.5175	.462	.5121	.499	.5544	.5175
21		.4435	.3658	.4572	.4207	.4435	.4435
22		.3077	.2601	.3155	.3189	.3189	.362
23	.2218	.1802	.1907	.176	.1966	.2105	.2427
24	.181	.1475	.1372	.1269	.1486	.1734	.1543
Max	**.5415**	**.5914**	**.5121**	**.5853**	**.5611**	**.5729**	**.6036**
Min	**.168**	**.1475**	**.1372**	**.1265**	**.1486**	**.1402**	**.1543**
Avg	**.2823**	**.3237**	**.2978**	**.2974**	**.333**	**.3296**	**.3408**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
MALHAR PETH S/DN[109] **BU 5941**
Substation No/ Name :- 254025 / 33/11 KV DHEBEWADI
Feeder No / Name : 205 / Sanbur Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0316	.0335		
2				.0316	.0335		
3				.0316	.0335		
4				.0316	.0335		
5				.0492	.052		
6				.0537	.0732		
7			.037	.0716	.1097		
8			.0366	.0716	.0905		
9	.0514	.0724				.1433	.2686
10	.0724	.0895				.1578	.298
11	.0709	.0895				.1928	
12	.0701	.0895				.218	
13	.0701	.0895				.1526	
14	.0701	.0905				.1526	
15	.0709	.0905				.2204	.2254
16	.0532					.2321	.2601
23			.1387				
Max	**.0724**	**.0905**	**.1387**	**.0716**	**.1097**	**.2321**	**.298**
Min	**.0514**	**.0724**	**.0366**	**.0316**	**.0335**	**.1433**	**.2254**
Avg	**.0661**	**.0873**	**.0708**	**.0466**	**.0574**	**.1837**	**.2630**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
MALHAR PETH S/DN[109] BU 5941
Substation No/ Name :- 254025 / 33/11 KV DHEBEWADI
Feeder No / Name : 206 / 11 KV Kalgaon Ag FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0328	.0328				.0351	.0526
2	.0324	.0328				.0351	.0526
3	.0335	.0358				.0351	.0526
4	.0343	.0358				.0701	.0526
5	.0503	.0358				.0709	.0543
6	.0514	.0549				.1109	.0914
7	.0514					.1294	.1478
8	.0335					.128	.1463
9			.0724	.12	.1448		
10			.1063	.1341	.1829		
11			.0876	.1372	.2401		
12			.104	.1844	.2572		
13			.1402	.1372	.2439		
14			.1402	.1067	.2439		
15			.1543	.1543	.2439		
16			.1372	.1505	.2408		
Max	**.0514**	**.0549**	**.1543**	**.1844**	**.2572**	**.1294**	**.1478**
Min	**.0324**	**.0328**	**.0724**	**.1067**	**.1448**	**.0351**	**.0526**
Avg	**.0400**	**.0380**	**.1178**	**.1406**	**.2247**	**.0768**	**.0813**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
MALHAR PETH S/DN[109] BU 5941
Substation No/ Name :- 254077 / 33/11 KV Marul Haveli
Feeder No / Name : 201 / 11 KV Nawadi Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0914	.0305	.0305	.0305	.2743	.2134
2	.0914	.0914	.0305	.0305	.0305	.2743	.1981
3	.0762	.0914	.0305	.0305	.0305	.3048	.1981
4	.1067	.1067	.0305	.0305	.0305	.3048	.2439
5	.1219	.1219	.0305	.0305	.0305	.3353	.3048
6	.1524	.1524	.0305	.0457	.0305	.3506	.4161
7	.2743	.2439	.0305	.0457	.0305	.4268	.5028
8	.2743	.2896	.0305	.0305	.0305	.503	.503
9	.0305	.0305	.3353	.442	.442	.0457	.0305
10	.0305	.0305	.4725	.4572	.6249	.0305	.0305
11	.0305	.0305	.5182	.5182	.6859	.0305	.0305
12	.0305	.0305	.4877	.6097	.7011	.0305	.0305
13	.0305	.0305	.5487	.5792	.7164	.0305	.0305
14	.0305	.0305	.5792	.4877	.6554	.0305	.0305
15	.0305	.0305	.4877	.5182	.6706	.0305	.0305
16	.0305	.0305	.5182	.381	.6706	.0305	.0305
17	.0305	.0305	.061	.0305	.0305	.0305	.0457
18	.0305	.0305	.0457	.0457	.0457	.0457	.061
19	.0305	.0305	.0457	.0457	.0457	.061	.061
20	.0305	.0305	.0457	.0457	.0457	.061	.061
21	.0457	.0457	.0457	.0457	.0457	.0457	.061
22	.0457	.0457	.0305	.0457	.0457	.0457	.061
23	.0457	.0457	.0457	.0457	.0457	.061	.061
24	.0457	.0457	.0457	.0457	.0457	.0457	.061
Max	**.2743**	**.2896**	**.5792**	**.6097**	**.7164**	**.503**	**.503**
Min	**.0305**	**.0305**	**.0305**	**.0305**	**.0305**	**.0305**	**.0305**
Avg	**.0724**	**.0724**	**.1899**	**.1924**	**.2401**	**.1429**	**.1374**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
MALHAR PETH S/DN[109] BU 5941
Substation No/ Name :- 254077 / 33/11 KV Marul Haveli
Feeder No / Name : 202 / 11 KV Marul Gaonthan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1578	.1578	.1753	.1402	.1402	.1753	.1753
2	.1578	.1578	.1578	.1402	.1402	.1578	.1578
3	.1578	.1578	.1578	.1402	.1402	.1578	.1578
4	.1928	.1928	.1753	.1578	.1578	.1753	.1753
5	.2629	.2629	.2103	.2103	.2103	.2454	.2629
6	.3506	.3506	.333	.3155	.298	.4031	.4031
7	.4733	.5258	.4557	.4382	.4733	.4557	.4733
8	.4557	.4557	.4908	.4382	.4908	.4382	.4207
9	.3506	.3856	.4031	.4031	.3856	.3681	.3681
10	.298	.3506	.333	.298	.3506	.2439	.3155
11	.3155	.2804	.2804	.298	.2629	.2279	.2804
12	.2629	.2629	.0876	.2804	.2629	.2279	.2454
13	.2629	.2454	.0876	.2454	.2454	.2103	.2279
14	.2279	.2454	.2629	.2103	.2454	.2279	.2279
15	.2279	.2454	.2103	.2279	.2279	.2279	.1928
16	.2629	.2629	.2279		.2279	.2454	.2454
17	.2629	.2804	.2629	.2804	.2454	.2629	.2454
18	.4031	.4382	.3681	.3856	.3681	.4908	.3506
19	.6135	.5959	.5784	.5609	.5784	.6135	.5609
20	.5959	.5784	.5258	.5609	.5434	.5434	.4908
21	.5258	.5083	.4557	.4733	.4733	.4908	.4557
22	.4031	.3856	.3155	.3506	.3506	.3506	.3681
23	.2279	.2629	.1753	.1928	.2454	.2279	.2454
24	.1753	.1753	.1753	.1402	.1402	.1928	.1753
Max	**.6135**	**.5959**	**.5784**	**.5609**	**.5784**	**.6135**	**.5609**
Min	**.1578**	**.1578**	**.0876**	**.1402**	**.1402**	**.1578**	**.1578**
Avg	**.3177**	**.3235**	**.2877**	**.2995**	**.3002**	**.3067**	**.3009**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
MALHAR PETH S/DN[109] BU 5941
Substation No/ Name :- 254077 / 33/11 KV Marul Haveli
Feeder No / Name : 203 / 11 kv Divashi AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0693	.0693	.0693	.0693	.0693	.0693	.0693
2	.0693	.0693	.0693	.0693	.0693	.0693	.0693
3	.0693	.0693	.0693	.0693	.0693	.0693	.0693
4	.0693	.0693	.0693	.0693	.0693	.0693	.0693
5	.0693	.0693	.0693	.0693	.0693	.0693	.0693
6	.0693	.0693	.0693	.0867	.0867	.0693	.0693
7	.0693	.0693	.0867	.104	.1214	.0693	.0693
8	.0693	.0693	.104	.104	.1387	.0693	.0693
9	.7282	1.0749	.0693	.0693	.0693	1.1269	.1387
10	.4161	1.2656	.0693	.0693	.0693	1.0974	.208
11	.3814	1.3003	.0693	.0693	.0693	1.3003	.208
12	.8322	1.3003	.0701	.0693	.0693	1.3176	.2427
13	.4334	1.2656	.0693	.0693	.0693	.9362	.2427
14	.8322	1.283	.0693	.0693	.0693	.9015	.2774
15	.9015	1.2656	.0693	.0693	.0693	.9362	.2254
16	.1907	1.2656	.0693		.0693	.8842	.2427
17	.0693	.0693	.0693	.0693	.0693	.0693	.0693
18	.0693		.0693	.0693	.0693	.0693	.0693
19	.0693	.0693	.0693	.0693	.0693	.0693	.0693
20	.0693	.0693	.0693	.0693	.0693	.0693	.0693
21	.0693	.0693	.0693	.0693	.0693	.0693	.0693
22	.0693	.0693	.0693	.0693	.0693	.0693	.0693
23	.0693	.0693	.0693	.0693	.0693	.0693	.0693
24	.0693	.0693	.0693	.0693	.0693	.0693	.0693
Max	**.9015**	**1.3003**	**.104**	**.104**	**.1387**	**1.3176**	**.2774**
Min	**.0693**	**.0693**	**.0693**	**.0693**	**.0693**	**.0693**	**.0693**
Avg	**.2427**	**.4809**	**.0715**	**.0731**	**.0751**	**.4004**	**.1206**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
MALHAR PETH S/DN[109] BU 5941
Substation No/ Name :- 258015 / 220/33 KV MALHARPETH
Feeder No / Name : 400 / AUXILLORY SUPPY
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
24	.0343
Max	.0343
Min	.0343
Avg	.0343

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
PATAN S/DN.[112] **BU 5959**
Substation No/ Name :- 254021 / PATAN
Feeder No / Name : 201 / 11 KV Mandure Gaothan **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1612	.1463			.1433		.1448
2	.1433	.1448			.1433		.1448
3	.1433	.1463			.1433		.1448
4	.1433	.1463			.1448		.1448
5	.1791	.2172			.1772		.2172
6	.2328	.2957			.2614		.2534
7	.3045	.3734			.3361		.3258
8	.3224	.4108			.3258		.362
9	.2865	.3696			.3224		.3982
10	.2865	.2957			.2481		.3258
11	.2507	.2218			.2481		.2534
12	.2149	.2012			.2303		.1991
13	.2149	.2012			.1949		.1991
14	.2149	.1829			.1907		.181
15		.2012			.2427		.181
16		.2378			.2254		.2353
17		.1294			.2601		.2896
18	.394	.1663	.4207		.4161	.4252	.5304
19		.5544	.6201	.6089	.5228		.6584
20		.6161	.5914		.6348		.543
21		.5544	.5228		.5601		.5544
22		.3142	.3696		.3511		.4755
23		.2172	.2195				.2743
24	.1663	.1829			.1448		.181
Max	**.394**	**.6161**	**.6201**	**.6089**	**.6348**	**.4252**	**.6584**
Min	**.1433**	**.1294**	**.2195**	**.6089**	**.1433**	**.4252**	**.1448**
Avg	**.2287**	**.2720**	**.4574**	**.6089**	**.2812**	**.4252**	**.3007**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
PATAN S/DN.[112] **BU 5959**
Substation No/ Name :- 254021 / PATAN
Feeder No / Name : 202 / LIS **FEEDER SEPERATION/PURE AG**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	05-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0297			.0343
2	.0343	.0297			.0339
3	.0343	.0297			.0339
4	.0343	.0297			.0339
5	.0343	.0297			.0686
6	.0343	.061			.1017
7	.0343	.0625			.1696
8	.0343				.1696
9			.0602	.0655	
10			.0633	.1311	
11			.0983	.1638	
12			.0995	.1966	
13			.0983	.1966	
14			.1109	.1943	
15			.0983	.112	
16			.0983	.1107	
24		.0297			
Max	**.0343**	**.0625**	**.1109**	**.1966**	**.1696**
Min	**.0343**	**.0297**	**.0602**	**.0655**	**.0339**
Avg	**.0343**	**.0377**	**.0909**	**.1463**	**.0807**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
PATAN S/DN.[112] **BU 5959**
Substation No/ Name :- 254021 / PATAN
Feeder No / Name : 203 / ADUL **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4298	.4066	.4755		.4066		.4706
2	.4298	.4024	.4525		.3658		.4298
3	.4298	.4024	.3721		.3696		.4298
4	.4656	.4755	.3898		.3658		.4298
5	.5373	.5853	.4252		.5121		.5068
6	.6805	.8589	.7468		.7023		.6805
7	.9313	1.0082	.823		.9709		1.0029
8	.8596	.9709	.9709		.924		.9671
9	.8954	.8131	.8688		.7762		.8954
10	.8954	.7602	.6379		.6283		.8596
11	.8596	.7796	.6653		.6584		.7442
12	.8238	.8859	.6379		.6805		.6379
13	.7522	.6733	.6447		.7164		.6024
14	.6089	.6379	.6283		.7164		.567
15		.6201	.6219		.6697		.567
16		.691	.6024		.7442		.7796
17		.8063	.7023		.8505		.8505
18	.8238	.9335	.8589		.9568	1.0029	.3189
19		1.0642	1.1203	1.1104	1.0277		1.2323
20		1.0829	1.0456		1.0829		1.0903
21			.924		.8589		.9877
22		.7023	.7023		.7095		.8779
23		.6468	.5373				.6468
24	.4481	.4435	.5487		.4066		.5068
Max	**.9313**	**1.0829**	**1.1203**	**1.1104**	**1.0829**	**1.0029**	**1.2323**
Min	**.4298**	**.4024**	**.3721**	**1.1104**	**.3658**	**1.0029**	**.3189**
Avg	**.6794**	**.7239**	**.6834**	**1.1104**	**.7000**	**1.0029**	**.7117**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
PATAN S/DN.[112] **BU 5959**
Substation No/ Name :- 254021 / PATAN
Feeder No / Name : 204 / HELWAK **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2507	.2218			.2865		.3224
2	.2507	.2195			.2507		.2896
3	.2507	.2195			.2507		.2896
4	.2865	.2195			.2507		.2896
5	.3224	.2926			.3258		.3258
6	.4656	.4435			.4805		.394
7	.6447	.6653			.6348		.6805
8	.6805	.7023			.6722		.724
9	.6805	.7392			.6219		.6584
10	.6805	.6219			.6154		.5792
11	.6805	.5316	.4755		.543		.543
12		.4607			.4961		.4656
13		.394			.443		.394
14					.4207		.3439
15		.5138	.5228		.4908		.362
16		.4706	.5304		.5609		.4252
17		.5138	.5373		.6201		.4607
18	.788	.6878	.6036		.7619	.8238	
19		.8688	1.0425	1.0387	.8682		1.0608
20		.9522	.9335		.961		.9877
21		.7842	.7947		.8131		.9149
22		.5544	.5316		.5014		.6468
23		.3052	.3582				.4755
24	.2614	.2561			.2896		.3582
Max	**.788**	**.9522**	**1.0425**	**1.0387**	**.961**	**.8238**	**1.0608**
Min	**.2507**	**.2195**	**.3582**	**1.0387**	**.2507**	**.8238**	**.2896**
Avg	**.4802**	**.5060**	**.6330**	**1.0387**	**.5287**	**.8238**	**.5214**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
PATAN S/DN.[112] **BU 5959**
Substation No/ Name :- 254021 / PATAN
Feeder No / Name : 205 / MIDC **SHEDDABLE FEEDER HAVING WEEKLY**
Feeder KV- 11 / OUTGOING **STAGGERING (MIDC, EQUIVALENT)**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1448	.2987		.2218		.1772
2	.1715	.1463			.1829		.1791
3	.1715	.1448	.1829		.1829		.1791
4	.1715	.1448			.1829		.1791
5	.1715	.181	.1753		.181		.1791
6	.2229	.2126	.1829		.2172		.2172
7	.2229	.2481	.2195		.2218		.2561
8	.2058	.2126	.2279		.2561		.2534
9	.2401	.2149	.2835		.2987		.2507
10	.3155	.3292	.4344		.4024		.2865
11	.394	.4435	.4298		.4805		.3189
12	.4656	.4435	.4481		.4706		.3189
13	.5014	.4435	.4252		.4835		.3189
14	.4298	.4435	.394		.4835		
15		.2957	.3544		.3658		.1928
16		.2772	.2481		.2926		.1949
17		.2172	.2218		.2427		
18	.2149	.2218	.2012		.1715	.2149	.1949
19		.208	.1612	.2149	.1772		.1991
20		.1734			.1772		.197
21		.2012	.1791		.2126		.1949
22		.2587	.2149		.2774		.2481
23		.2614	.2587				.2743
24	.2926	.1448	.2987		.2427		.2835
Max	**.5014**	**.4435**	**.4481**	**.2149**	**.4835**	**.2149**	**.3189**
Min	**.1715**	**.1448**	**.1612**	**.2149**	**.1715**	**.2149**	**.1772**
Avg	**.2727**	**.2505**	**.2781**	**.2149**	**.2794**	**.2149**	**.2315**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
PATAN S/DN.[112] **BU 5959**
Substation No/ Name :- 254021 / PATAN
Feeder No / Name : 206 / 11 KV Mandure Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0335	.0366	.0373		.037		.1715
2	.0335	.0366	.037		.037		.1715
3	.0335	.0366	.0354		.037		.1372
4	.0335	.0362	.0354		.037		.1372
5	.0335	.0362	.0366		.037		.1715
6	.0343	.0366	.0366		.0366		.3052
7	.0343	.0366	.0354		.0373		.3052
8	.0335	.0366	.0339		.0377		.3391
9	.0114	.037	.0655		.0373		.0373
10	.0114	.037	.0724		.2957		.0373
11	.0114	.037	.0655		.132		.0373
12	.0114	.0377	.0316				.0373
13	.0114	.0377	.0328		.2772		.0373
14	.0114	.0373	.0332		.2172		.0373
15		.0373	.0332		.3439		.0373
16		.0373	.0328		.3582		.0373
17		.0362	.0354		.0377		.0373
18	.0152	.0377	.6767		.0377	.0038	.0328
19		.0362	.0354	.0076	.0377		.0347
20		.0373	.0366		.0377		.0354
21		.0373	.0347		.0377		.0343
22		.0373	.0366		.0377		.0347
23		.0373	.0366				.0339
24	.3109	.0362	.0377		.0377		.0373
Max	**.3109**	**.0377**	**.6767**	**.0076**	**.3582**	**.0038**	**.3391**
Min	**.0114**	**.0362**	**.0316**	**.0076**	**.0366**	**.0038**	**.0328**
Avg	**.0415**	**.0369**	**.0660**	**.0076**	**.101**	**.0038**	**.0966**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
PATAN S/DN.[112] **BU 5959**
Substation No/ Name :- 254021 / PATAN
Feeder No / Name : 207 / 11 KV Helwak Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0114	.0343	.0373		.0305		.0373
2	.0114	.0305	.0328		.0305		.0373
3	.0114				.0305		.0373
4	.0114	.0305	.0328		.0305		.0373
5	.0114	.0312	.0332		.0312		.0373
6	.0114		.0328		.0648		.0373
7	.0114	.0324	.0328		.0648		.0373
8	.0114		.0297		.0655		.0373
9	.0343	.0324	.0328		.0316		.0343
10	.0343	.0335	.0339		.032		.0347
11	.0343	.0343	.0339		.0309		.0701
12		.0838			.0358		.1029
13		.1006			.0362		.0686
14		.1006			.0354		.0686
15		.0838			.0354		.0686
16		.104			.0354		.0701
17		.0377			.0354		.0373
18	.0152	.0377	.0366		.032	.0091	.0366
19		.0377	.0362	.0076	.0305		.0354
20		.0377	.0354		.0282		.0354
21		.0377	.0354		.0286		.0343
22		.0377	.0362		.0286		.0354
23		.0377	.0358				.0343
24	.0114	.0343	.0328		.0305		.0373
Max	**.0343**	**.104**	**.0373**	**.0076**	**.0655**	**.0091**	**.1029**
Min	**.0114**	**.0305**	**.0297**	**.0076**	**.0282**	**.0091**	**.0343**
Avg	**.0170**	**.0491**	**.0341**	**.0076**	**.0363**	**.0091**	**.0459**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
PATAN S/DN.[112] **BU 5959**
Substation No/ Name :- 254021 / PATAN
Feeder No / Name : 208 / Patan Urban **SHEDDABLE URBAN**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3045	.3734	.2686		.3292		.362
2	.2865	.3734	.2743		.2926		.3258
3	.2865	.3696	.2172		.2926		.3258
4	.2865	.3658	.2195		.2926		.362
5	.3224	.4344	.2772		.362		.439
6		.5228	.4755		.3696		.5853
7	.6805	.6722			.7095		.7964
8	.6626	.7095	.6878		.6722		.6878
9	.6089	.6584	.5611		.5731		.5853
10	.5731	.5544	.5316		.6283		.5068
11	.5373	.5121	.5121		.5175		.5068
12	.5014	.4344	.4755		.4755		.4887
13	.5014	.4298	.4706		.4572		.4344
14	.4656	.4119	.4607		.4572		.3982
15		.4298	.4706		.439		.3982
16		.394	.4607		.5014		.4706
17		.5014	.5373		.5014		.5487
18	.6089	.7095			.7392	.7964	.7545
19		.6878	.8048	.7522	.7392		.8413
20		.7059	.7392		.7655		.7762
21		.5792	.6653		.6653		.691
22		.5228	.4961		.5487		.5792
23		.3801	.394				.4344
24	.3174	.4108	.2926		.3292		.362
Max	**.6805**	**.7095**	**.8048**	**.7522**	**.7655**	**.7964**	**.8413**
Min	**.2865**	**.3658**	**.2172**	**.7522**	**.2926**	**.7964**	**.3258**
Avg	**.4629**	**.5060**	**.4678**	**.7522**	**.5069**	**.7964**	**.5275**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
PATAN S/DN.[112] **BU 5959**
Substation No/ Name :- 254024 / RASATI
Feeder No / Name : 201 / Rasati Gaothan **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0648	.0518	.072	.061	.061	.0629	.0488
2	.0663	.0518	.072	.0594	.0625	.021	.0472
3	.0678	.0518	.0472	.0594	.064	.0465	.0472
4	.0693	.0518	.0732	.061	.0655	.0572	.0488
5	.1052	.061	.0903	.0671	.1006	.1006	.0526
6	.1063	.1006	.0926	.0709	.1017	.1006	.0846
7	.1448	.1433	.1433	.1086	.1029	.1734	.1753
8	.1463	.1791	.1387	.1109	.1734	.1696	.1772
9	.1417	.1402	.1387	.1075	.1341	.1357	.096
10	.1235	.1006	.0972	.1052	.0995	.1219	.096
11	.096	.0983	.0914	.0701	.0972	.0937	.0857
12	.096	.0983	.0869	.0926	.1265	.0869	.0857
13	.096	.0937	.096	.1265	.1219	.0869	.0823
14	.096	.0914	.0892	.0995	.0937	.0892	.0823
15	.096	.096	.096	.0949	.0914	.0892	.0846
16	.096	.0869	.096	.0949	.1204	.0892	.096
17	.1006	.096	.1311	.0972	.1235	.0892	.0903
18	.1372	.1372	.1341	.1326	.1357	.1619	.1341
19	.2561	.2195	.2172	.2481	.2507	.2195	.2587
20	.2195	.2172		.2149	.2481	.2195	.2195
21	.1791	.181		.1772		.1772	.2172
22	.1417	.128	.1075	.1638	.1715	.1402	.1372
23	.0892	.0834	.1029	.0789	.1219	.0892	.0937
24	.0556	.0777	.072	.0625	.0457	.0629	.0777
Max	**.2561**	**.2195**	**.2172**	**.2481**	**.2507**	**.2195**	**.2587**
Min	**.0556**	**.0518**	**.0472**	**.0594**	**.0457**	**.021**	**.0472**
Avg	**.1163**	**.1099**	**.1039**	**.1069**	**.1180**	**.1118**	**.1091**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
PATAN S/DN.[112] **BU 5959**
Substation No/ Name :- 254024 / RASATI
Feeder No / Name : 202 / KOYANA **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1158	.0777	.0674	.0503	.0914	.0953	.0594
2	.088	.0686	.0663	.0472	.0743	.0762	.0594
3	.0903	.0709	.0652	.0472	.0789	.096	.0594
4	.0914		.0652	.0518	.08	.072	.0617
5	.1235		.0823	.0823	.0823	.1128	.0754
6	.125		.1341	.0914	.1143	.1189	.1052
7	.128	.1372	.1387	.1052	.1219	.1357	.16
8	.1357	.1372	.1341	.1372	.1638	.1235	.1562
9	.0926	.1006	.1341	.1387	.1006	.1543	.125
10	.0983	.0937	.0949	.1357	.0995	.0869	
11	.0633	.0914	.0926	.0686	.0686	.0903	
12	.0949	.0903	.0903	.0983	.0655	.0892	
13	.125	.0914	.0914	.096	.0949	.0892	.1067
14	.0937	.0937	.0914	.0633	.0983	.0869	.1021
15	.0937	.0972	.0914	.0625	.128	.0869	.1143
16	.125	.0926	.0937	.0678	.1235	.1128	.0975
17	.1265	.096	.1219	.1296	.141	.1036	.0899
18	.1619	.1311	.1524	.16	.1829	.1429	.1623
19	.2865	.2534	.2507	.2454	.2743	.2401	.2401
20	.2896	.2481	.2507	.2454	.2374	.2427	.2374
21	.2454	.2103	.2103	.2035	.1966	.1966	.2294
22	.1734	.1524	.1658	.1562	.1524	.1486	.1806
23	.1276	.1067	.1219	.096	.0991	.1067	.0945
24	.0899	.0945	.0899	.0777	.0838	.0953	.0617
Max	**.2896**	**.2534**	**.2507**	**.2454**	**.2743**	**.2427**	**.2401**
Min	**.0633**	**.0686**	**.0652**	**.0472**	**.0655**	**.072**	**.0594**
Avg	**.1327**	**.1207**	**.1207**	**.1107**	**.1231**	**.1210**	**.1228**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
PATAN S/DN.[112] **BU 5959**
Substation No/ Name :- 254024 / RASATI
Feeder No / Name : 203 / Rasati Ag Feeder KV- 11 / OUTGOING **SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER**

DATE	07-NOV-17
HR	Load (MW)
10	.1143
11	.0823
12	.1097
Max	.1143
Min	.0823
Avg	.1021

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
UMBRAJ S/DN.[108] **BU 5932**
Substation No/ Name :- 254003 / UMBRAJ
Feeder No / Name : 201 / CHAFAL **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0686	.0686	.0686	.0686	.0686	.0686
2	.0857	.0514	.0686	.0686	.0686	.0686	.0686
3	.0857	.0514	.0686	.0686	.0686	.0686	.0686
4	.0857	.0514	.0686	.0686	.0686	.0686	.0686
5	.0857	.0686	.0686	.0686	.0686	.0686	.0686
6	.12	.1029	.1029	.1029	.12	.12	.1029
7	.1543	.1543	.1715	.1715	.1715	.1715	.1543
8	.1715	.1886	.1886	.2058	.2058	.1886	.1543
9	.1715	.1715	.1715	.1886	.1543	.1886	.1715
10	.1715	.1402	.1715	.1372	.1372	.1543	.1543
11	.1402	.1227	.1372	.1509	.1463	.1372	.12
12	.1063	.1227	.1372	.1463	.1463	.1372	.12
13	.1052	.1227	.12	.1463	.1463	.12	.12
14	.1052	.1227	.12	.128	.128	.12	.1029
15	.1052	.1227	.12	.1097		.12	.1029
16	.1052	.1402	.12	.1097	.1463	.12	
17	.1402	.1372	.12	.1372	.12	.1372	.1543
18	.1372	.1372	.1715	.2058	.1372	.2058	.2058
19	.2401	.2401	.2229	.2401	.2229	.2229	.2058
20	.2058	.2058	.1886	.2058	.2058	.2058	.1886
21	.1715	.1715	.1715	.1886	.1715	.1715	.12
22	.1543	.1372	.12	.1372	.1372	.1543	.1372
23	.1029	.1029	.1029	.1029	.1029	.1372	.1029
24	.0857	.0857	.0686	.0857	.0857	.1029	.1029
Max	**.2401**	**.2401**	**.2229**	**.2401**	**.2229**	**.2229**	**.2058**
Min	**.0857**	**.0514**	**.0686**	**.0686**	**.0686**	**.0686**	**.0686**
Avg	**.1301**	**.1258**	**.1279**	**.1351**	**.1317**	**.1358**	**.1245**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
UMBRAJ S/DN.[108] **BU 5932**
Substation No/ Name :- 254003 / UMBRAJ
Feeder No / Name : 202 / MASUR **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5487	.5144	.4801	.4801	.5144	.5144
2	.5144	.5144	.5144	.4801	.4801	.4973	.5144
3	.5144	.5144	.5144	.4801	.4801	.4973	.5144
4	.5144	.5144	.5144	.5144	.4801	.5144	.5144
5	.5144	.5487	.5144	.5316	.5144	.5487	.5487
6	.6859	.7545	.6859	.6687	.6516	.823	.7202
7	1.0288	1.0288	.9945	.9945	.9259	1.0974	1.0631
8	.9602	1.0288	.9602	1.0288	1.0288	.9602	1.0288
9	.823	.9602	.8573	.9945	.8573	.9602	.8916
10	.7888	.9431	.8573	.8916	.8916	.9945	.8916
11	.8413	.823	.7888	.7888	.8413	.823	.7373
12	.8063	.823	.7202	.8063	.823	.823	.6859
13	.7362	.7545	.6859	.7362	.6584	.7888	.6859
14	.7362	.7202	.6173	.8413	.6584	.7202	.6516
15	.8413	.7202	.5144	.7011	.6767	.7716	.6173
16	.8063	.7373	.5487	.7362	.7682	.8573	.6859
17	.7011	.823	.7888	.7202	.823	.8916	.823
18	.9259	1.0288	.7202	.9259	1.0288	1.0631	1.0288
19	1.3032	1.2346	1.3032	1.166	1.2346	1.2346	1.2689
20	1.166	1.0974	1.166	1.0974	1.1488	1.1317	1.0631
21	1.0974	.8916	.9602	.9259	1.0288	1.0288	1.0288
22	.8916	.8573	.823	.8573	.8916	.8916	.9602
23	.7202	.6859	.6516	.6173	.6859	.6859	.703
24	.5487	.6173	.5487	.5316	.5487	.6173	.6173
Max	**1.3032**	**1.2346**	**1.3032**	**1.166**	**1.2346**	**1.2346**	**1.2689**
Min	**.5144**	**.5144**	**.5144**	**.4801**	**.4801**	**.4973**	**.5144**
Avg	**.7909**	**.7988**	**.7402**	**.7715**	**.7753**	**.8223**	**.7816**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
UMBRAJ S/DN.[108] **BU 5932**
Substation No/ Name :- 254003 / UMBRAJ
Feeder No / Name : 203 / PAL **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.6859	1.0288	1.0802		1.2346	1.166
2	.6516	.7202	1.0288	1.0631		1.2517	1.2003
3	.6516	.7202	1.0288	1.0631		1.2517	1.2003
4	.6516	.703	1.0288	1.046		1.2517	1.2003
5	.6516	.7373	1.0288	1.046		1.3032	1.2003
6	.6859	.823	1.0631	1.0974		1.3717	1.3032
7	.8916	.9431	1.166	1.2174		1.3717	1.4575
8	.9945	1.0631	1.2346	1.2517		1.5775	1.5089
9	.6516	1.1317	1.0974	1.7147	1.8004	1.4403	1.9719
10	1.0631	1.2003	1.3717	1.8861	1.9719	2.0233	1.1145
11	1.0288	1.2003	1.5432	1.9719	2.0919	2.0233	2.2977
12	1.0288	1.3717	1.7147	1.7147	1.8004	2.2291	2.4006
13	1.0288	1.2003	1.5432	1.989	1.8861	2.2634	2.4006
14	1.1145	1.3717	1.5432	1.9719	2.0919	2.1605	1.2346
15	1.0631	1.4575	1.7147	2.0576	2.0919	2.0919	2.2291
16	1.1145	1.406	1.7147	1.9719	2.0233	1.5775	1.9204
17	.0943	.0857	.0686	.0343	.1029	.0343	.12
18	.1029	.1029	.0857	.0857	.1029	.0343	.12
19	.1029	.0857	.0857	.0857	.1029	.1029	.12
20	.0686	.0857	.0857	.0857	.0857	.1029	.12
21	.0686	.0857	.0686	.0857	.0857	.1029	.1029
22	.0686	.0686	.0686	.0686	.0686	.0686	.0857
23	.0343	.0343	.0514	.0343	.0343	.0343	.0343
24	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Max	**1.1145**	**1.4575**	**1.7147**	**2.0576**	**2.0919**	**2.2634**	**2.4006**
Min	**.0343**	**.0343**	**.0343**	**.0343**	**.0343**	**.0343**	**.0343**
Avg	**.6041**	**.7216**	**.8916**	**1.0274**	**1.0234**	**1.1224**	**1.1060**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
UMBRAJ S/DN.[108] **BU 5932**
Substation No/ Name :- 254003 / UMBRAJ
Feeder No / Name : 204 / PERLE **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2058	.2058	.1715	.1715	.2058	.2058
2	.1715	.1886	.2058	.1715	.1715	.2058	.2058
3	.1715	.1715	.2058	.1715	.1715	.2572	.2058
4	.1715	.1715	.2058	.1886	.1715	.2058	.2058
5	.2058	.2058	.2401	.2401	.2401	.2401	.2401
6	.4115	.4115	.3772	.4115	.3772	.4458	.4458
7	.583	.583	.583	.6173	.5487	.6173	.5487
8	.5487	.5658	.583	.583	.5144	.5658	.583
9	.4115	.4287	.3772	.4458	.3772	.4287	.4458
10	.4115	.3856	.3429	.3944	.3429	.3429	.3772
11	.3856	.3506	.3429	.3582	.3658	.3429	.3086
12	.3506	.3506	.3086	.3582	.3658	.3086	.2743
13	.3506	.3155	.3086	.2865	.3292	.2743	.2743
14	.3189	.2804	.2743	.2865	.2926	.2743	.2743
15	.3506	.3506	.2743	.2865	.2926	.2743	.2743
16	.3856	.3506	.0343	.3582	.2926	.3086	.2743
17	.3506	.3429	.3772	.3086	.3772	.3086	.3429
18	.4115	.3772	.4801	.4801	.4115	.4801	.4115
19	.6344	.6173	.6173	.6173	.6344	.6173	.6173
20	.5658	.5144	.5487	.5144	.5658	.5144	.5658
21	.5144	.4801	.4801	.4458	.4801	.4801	.4973
22	.4115	.3772	.3601	.3429	.3944	.3772	.4115
23	.3086	.2401	.2572	.2401	.2743	.2743	.1829
24	.2058	.2229	.2058	.2058	.2058	.2229	.2401
Max	**.6344**	**.6173**	**.6173**	**.6173**	**.6344**	**.6173**	**.6173**
Min	**.1715**	**.1715**	**.0343**	**.1715**	**.1715**	**.2058**	**.1829**
Avg	**.3668**	**.3537**	**.3415**	**.3535**	**.3487**	**.3572**	**.3506**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
UMBRAJ S/DN.[108] **BU 5932**
Substation No/ Name :- 254003 / UMBRAJ
Feeder No / Name : 205 / VARADE **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0343	.8916	.8745	.9431	.0343	.0343
2	.0686	.0343	.8916	.8745	.9259	.0343	.0343
3	.0686	.0343	.8916	.8745	.9259	.0343	.0343
4	.0686	.0343	.8916	.8745	.9259	.0343	.0343
5	.0686	.0514	.8916	.8745	.9259	.0343	.0686
6	.0686	.0686	.9259	.9088	.9602	.0343	.0686
7	.0686	.0857	1.1145	1.0117	.9945	.0686	.0857
8	.0857	.0857	1.2003	1.1317	1.0974	.0686	.0857
9	.9602	1.1831	.0343	.1029	.0857	1.2003	1.5432
10	1.0974	1.3032	.0686	.1029	.0686	1.5947	1.6289
11	1.166	1.286	.1372	.1132	.0732	1.7147	1.5432
12	1.1145	1.286	.12	.1132	.0914	1.7147	1.5432
13	1.0974	1.3717	.12	.1509	.0914	1.7147	1.5432
14	1.1145	1.3717	.1029	.1509	.0914	1.7147	1.7147
15	1.1145	1.286	.1029	.1509	.0914	1.7147	1.7147
16	1.1145	1.286	.1029	.1132	.1097	1.7147	1.6289
17	.1132	.12	.1029	.1029	.1029	.1372	.1029
18	.0857	.1029	.12	.0857	.1372	.1543	.1029
19	.0857	.0343	.0857	.0686	.0686	.1372	.12
20	.0686	.0343	.0686	.0857	.0686	.1372	.1029
21	.0686	.0343	.0686	.0343	.0514	.1372	.1029
22	.0857	.0343	.0686	.0343	.0686	.12	.1029
23	.0686	.0343	.1029	.0343	.0514	.0686	.1029
24	.0686	.0686	.0343	.0686	.0343	.0343	.0686
Max	**1.166**	**1.3717**	**1.2003**	**1.1317**	**1.0974**	**1.7147**	**1.7147**
Min	**.0686**	**.0343**	**.0343**	**.0343**	**.0343**	**.0343**	**.0343**
Avg	**.4162**	**.4694**	**.3808**	**.3724**	**.3744**	**.5980**	**.5880**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
UMBRAJ S/DN.[108] **BU 5932**
Substation No/ Name :- 254003 / UMBRAJ
Feeder No / Name : 206 / CHAFAL AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.7202	.0343	.0686	.0686	.9945	1.2003
2	.6516	.7202	.0343	.0686	.0686	.9945	1.2689
3	.6516	.7202	.0343	.0686	.0686	.9945	1.2689
4	.6516	.7202	.0343	.0686	.0686	.9945	1.2689
5	.6516	.7373	.0343	.0686	.0686	.9945	1.2689
6	.7716	.8402	.0686	.1029	.1029	1.1317	1.3375
7	1.0631	.9945	.1029	.12	.1372	1.4232	1.6461
8	1.1317	1.0288	.1029	.12	.12	1.5432	1.6118
9	.1372	.0857	1.0631	1.4746	1.6461	.12	.12
10	.1029	.132	1.3375	1.9376	1.8176	.1029	.12
11	.1132	.0943	1.6289	1.8004	1.9547	.0686	.1372
12	.1132	.0943	1.7147	1.9204	2.0576	.0686	.1372
13	.1132	.0943	1.7147	1.9204	.1829	.1029	.12
14	.0943	.0943	1.6289	1.989	.1829	.1029	.1029
15	.0943	.0943	1.3717	1.9719		.1029	.1029
16	.0943	.0943	1.7147	1.9719	1.0288	.1029	.1029
17	.0943	.12	.12	.12	.0686	.1372	.1029
18	.12	.1372	.12	.12	.1372	.1543	.1372
19	.12	.12	.1372	.1372	.1372	.1543	.1372
20	.12	.12	.1372	.12	.12	.1372	.12
21	.12	.0857	.12	.12	.12	.1543	.12
22	.1029	.0857	.1029	.12	.1029	.1372	.1029
23	.0686	.0514	.0857	.0857	.0857	.12	.1029
24	.12	.0686	.0343	.0857	.0857	.0857	.1029
Max	**1.1317**	**1.0288**	**1.7147**	**1.989**	**2.0576**	**1.5432**	**1.6461**
Min	**.0686**	**.0514**	**.0343**	**.0686**	**.0686**	**.0686**	**.1029**
Avg	**.3314**	**.3356**	**.5616**	**.6909**	**.4535**	**.4551**	**.5309**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
UMBRAJ S/DN.[108] **BU 5932**
Substation No/ Name :- 254003 / UMBRAJ
Feeder No / Name : 401 / UMESHWAR LIS **PURELY LIS FEEDERS**
Feeder KV- 33 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0514	.0514	.0514	.2058	.2572
2	.0514	.0514	.0514	.0514	.2058	.2572
3	.0514	.0514	.0514	.0514	.5144	.2572
4	.0514	.0514	.0514	.1029	.5144	.2572
5	.2058	.0514	.0514	.9774	1.6975	1.5432
6	.9259	.0514	.0514	1.5947	1.6975	1.5432
7	.8745	.0514	.0514	1.749	1.6975	1.5432
8	.8745	.0514	.0514	1.749	1.6975	1.5432
9	.8745	.0514	.7202	1.749	1.6975	1.5432
10		.0514	1.0802	1.8004	1.6461	.5144
11	.7202	.2572	1.1831	1.8004	1.6975	.9259
12	.8745	.0514	1.2346	1.8004	1.6975	2.4691
13	.8745	.0514	1.8004	1.8004	1.6461	2.0576
14	.9259	.0514	1.8519	1.8004	1.6461	1.2346
15	.9259	.0514	1.8004	1.8004	1.6461	1.2346
16	.0514	.0514	.2572	.5658	.2572	.2572
23	1.7146					
Max	**1.7146**	**.2572**	**1.8519**	**1.8004**	**1.6975**	**2.4691**
Min	**.0514**	**.0514**	**.0514**	**.0514**	**.2058**	**.2572**
Avg	**.6280**	**.0643**	**.6462**	**1.2153**	**1.2603**	**1.0899**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
UMBRAJ S/DN.[108] **BU 5932**
Substation No/ Name :- 254006 / MASUR
Feeder No / Name : 201 / shamgaon Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7373	.6062	.0152	.0147	.0181	1.012	1.0442
2	.7042	.5992	.0156	.0149	.0179	1.0242	1.0608
3	.7209	.5967	.016	.0149	.0173	1.0242	1.0608
4	.7293	.5668	.0162	.0152	.0171	1.0242	1.0608
5	.8048	.6554	.0171	.0152	.0179	1.1203	1.1603
6	.8383	.7127	.0175	.0162	.0171	1.166	1.1934
7	.8718	.8619	.0177	.0168	.0171	1.2146	1.2763
8	.8785	.9069	.0175	.0181	.0181	1.1498	1.1683
9	.017	.0168	1.0562	1.2308	1.2597	.0166	.0164
10	.0162			1.4586	1.3592	.0171	.0158
11	.0162			1.5249	1.6263	.017	
12	.0154	.0152		1.0688	1.4083	.0162	
13	.0154	.0143		1.1869	1.4922	.017	
14	.017	.0097	1.2955	1.3108	1.5546	.0154	.0162
15	.0154	.0154	1.2955	1.4922	1.4413	.0154	.017
16	.017	.0149	1.3117	1.2955	1.4575		.0152
17	.0168	.0145	.0156	.0162	.0173		.0173
18	.0171	.0143	.0164	.0181	.0168	.0158	.0162
19	.0166	.0177	.0181	.0181	.0171	.0171	.0171
20	.0162	.0171	.0173	.0173	.0173	.0168	.0152
21	.0154	.0168	.0168	.0171	.017	.0168	.0162
22	.0158	.0164	.0168	.0183	.0168	.0164	.0164
23	.0156	.0158	.0152	.0179	.0166	1.3056	.0158
24	.0128	.0152	.0149	.0147	.0181	.0158	.0166
Max	**.8785**	**.9069**	**1.3117**	**1.5249**	**1.6263**	**1.3056**	**1.2763**
Min	**.0128**	**.0097**	**.0149**	**.0147**	**.0166**	**.0154**	**.0152**
Avg	**.2725**	**.2600**	**.2611**	**.4513**	**.4949**	**.4661**	**.4398**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
UMBRAJ S/DN.[108] **BU 5932**
Substation No/ Name :- 254006 / MASUR
Feeder No / Name : 202 / Helgaon Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061	.0724	1.2125	1.1984	1.3717	.0579	.0625
2	.0663	.0747	1.1843	1.1984	1.3565	.0594	.064
3	.0686	.0724	1.1843	1.1279	1.2955	.0663	.0671
4	.0693	.0724	1.1984	1.3108	1.3272	.0655	.0671
5	.0701	.0732	1.3765	1.5729	1.4752	.0655	.0686
6	.0724	.0739	1.4746	1.6324	1.576	.0663	.0701
7	.0724	.0724	1.5912	1.7368	1.861	.0663	.0701
8	.0686	.0655	1.8143	1.9376	1.8945	.0655	.0572
9	1.6787	1.6956	.0686	.0594	.0693	2.079	2.2045
10	1.9448	2.1152		.0655	.0701	2.2969	2.73
11	1.8947			.0617	.0678	2.4615	
12	2.1052	2.1963		.0511	.0724	2.6621	
13	2.1538	2.037		.0472	.0701	2.9673	
14	2.146	2.2969	.0472	.0465	.0648	2.4813	2.3137
15	2.2382	2.3908	.0457	.0472	.0396	2.8464	2.713
16	2.0317	2.4646	.0419	.0488	.0396		2.8487
17	.0693	.0587	.0648	.0533	.0625		.0693
18	.0594	.0587	.0686	.0602	.0602	.0594	.0579
19	.0693	.0179	.0716	.0701	.0633	.061	.0655
20	.0671	.0686	.0693	.0678	.0648	.0587	.0617
21	.0648	.0671	.0655	.0633	.0301	.0556	.0602
22	.0678	.0655	.0602	.0617	.0602	.0587	.0678
23	.0693	.0648	.0594	.0549	.0587	.0556	.061
24	.0518	.0671	.0617	.0541	.0526	.0572	.061
Max	**2.2382**	**2.4646**	**1.8143**	**1.9376**	**1.8945**	**2.9673**	**2.8487**
Min	**.0518**	**.0179**	**.0419**	**.0465**	**.0301**	**.0556**	**.0572**
Avg	**.7192**	**.7062**	**.5880**	**.5262**	**.5460**	**.8506**	**.6591**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
UMBRAJ S/DN.[108] **BU 5932**
Substation No/ Name :- 254006 / MASUR
Feeder No / Name : 203 / KONEGAON **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7186	.7625	.0354	.0537	.0543	2.1719	1.9204
2	.7625	.7449	.0358	.0543	.0549	2.1033	1.8991
3	.7712	.7545	.0362	.0543	.0537	2.0576	2.0348
4	.7099	.7459	.0351	.0543	.0532	2.0119	1.9989
5	.8288	.7865	.0339	.0537	.0554	2.0222	2.0243
6	.8642	.8718	.0351	.0537	.0543	2.0005	2.0243
7	.9393	1.0202	.0358	.0537	.0716	2.0165	2.0399
8	1.0322	1.0753	.0362	.0543	.0701	2.0485	2.0873
9	.0362	.0303	1.0974	1.065	2.2024	.0358	.037
10	.0173	.0181		2.0891	2.13	.081	.037
11	.0716				2.0005	.128	
12	.0724	.0724		1.7976	2.1925	.0549	
13	.0678	.0724		2.1376	2.1125	.0332	
14	.0509	.0351	1.749	2.0466	2.1605	.0154	.0118
15	.0886	.0168	1.7814	2.1765	2.2634	.0164	.0118
16	.081		1.6248	2.0309	2.323		.0625
17	.0509	.0145	.0486	.0732	.0324		.1086
18	.0526	.0156	.0139	.0154	.0332	.0362	.1086
19	.0532	.0358	.0716	.0895	.0354	.037	.0914
20	.0526	.0362	.0543	.0724	.0358	.0377	.0724
21	.0351	.0362	.0537	.0724	.0362	.0377	.0709
22	.0175	.0362	.0543	.0724	.0358	.0377	.0732
23	.0175	.0358	.0537	.0543	.0351	.0377	.0732
24	.0305	.0133	.0354	.0537	.052	.0358	.0347
Max	**1.0322**	**1.0753**	**1.7814**	**2.1765**	**2.323**	**2.1719**	**2.0873**
Min	**.0173**	**.0133**	**.0139**	**.0154**	**.0324**	**.0154**	**.0118**
Avg	**.3093**	**.3287**	**.3461**	**.6208**	**.7562**	**.7753**	**.8011**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
UMBRAJ S/DN.[108] **BU 5932**
Substation No/ Name :- 254006 / MASUR
Feeder No / Name : 204 / Shahapur Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0156			
2			.0158			
3			.0152	.0149		
4			.0162	.0149		
5			.0158	.0152		
6			.0156	.0152		
7			.0154	.0152		
8			.016	.0156		
9					.0147	.0147
10	.0131	.0166			.0126	.0151
11	.0152				.0152	
12	.0156	.016			.0152	
13	.0151	.0162			.0114	
14	.0152	.016			.0149	.0149
15	.0114	.0162			.0149	.0135
16	.0164	.016				.0126
Max	**.0164**	**.0166**	**.0162**	**.0156**	**.0152**	**.0151**
Min	**.0114**	**.016**	**.0152**	**.0149**	**.0114**	**.0126**
Avg	**.0146**	**.0162**	**.0157**	**.0152**	**.0141**	**.0142**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
UMBRAJ S/DN.[108] **BU 5932**
Substation No/ Name :- 254006 / MASUR
Feeder No / Name : 205 / MASUR VILLAGE **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2865	.2263	.2263	.2254	.2667	.2641
2	.2641	.2896	.2263	.2263	.2303	.2667	.2641
3	.2641	.2774	.2263	.2263	.2229	.2667	.2641
4	.2641	.2926	.2263	.2263	.2402	.2667	.2641
5	.3772	.3326	.415	.3395	.2987	.5335	.3772
6	.4527	.3841	.4904	.4481	.3439	.5716	.5281
7	.5281	.5731	.5281	.6036	.5658	.5975	.5658
8	.5601	.6584	.5601	.6413	.6413	.5975	.6348
9	.5281	.5611	.5175	.4755	.5121	.4656	.4805
10	.4481	.5281		.4344	.5014	.4706	.4344
11	.4344			.439	.4755	.4435	
12	.4435	.4706		.3898	.4706	.4435	
13	.4435	.4435		.3582	.4108	.3982	
14	.439	.4024	.3658	.394	.3982	.4706	.362
15	.3982	.4435	.4706	.4344	.4024	.4024	.3292
16	.4024	.4706	.3326	.4706	.3982		.3658
17	.4344	.5316	.4252	.439	.4024		.3582
18	.3692	.6154	.567	.543	.6154	.6024	.4706
19	.7602	.7842	.6722	.6878	.7095	.7095	.7023
20	.6878	.679	.6036	.6224	.6036	.6413	.6036
21	.6413	.5281	.4904	.547	.5658	.5658	.5658
22	.5304	.4527	.4527	.4481	.415	.4904	.5281
23	.3801	.3048	.3395	.3506	.381	.3395	.3772
24	.2667	.3258	.2286	.2263	.2353	.2667	.2667
Max	**.7602**	**.7842**	**.6722**	**.6878**	**.7095**	**.7095**	**.7023**
Min	**.2641**	**.2774**	**.2263**	**.2263**	**.2229**	**.2667**	**.2641**
Avg	**.4409**	**.4624**	**.4182**	**.4249**	**.4277**	**.4580**	**.4289**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
UMBRAJ S/DN.[108] **BU 5932**
Substation No/ Name :- 254006 / MASUR
Feeder No / Name : 206 / Kalgaon Vlg **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.1829	.1867	.1867	.2103	.2149	.2263
2	.2263	.181	.1867	.1867	.2149	.2149	.2263
3	.2263	.1791	.1867	.1867	.2172	.2149	.2263
4	.2263	.1829	.1867	.1867	.2195	.2149	.2263
5	.3772	.2241	.2801	.1867	.2218	.394	.3772
6	.415	.2641	.3361	.2218	.2614	.4207	.415
7	.4527	.4481	.4108	.4435	.3544	.439	.4527
8	.4435	.4435	.3658	.4344	.4344	.4607	.4428
9	.3292	.3658	.3121	.2591	.3544	.3391	.3018
10	.2507	.2561		.2591	.2915	.2713	.2401
11	.2591			.2347	.2591	.2622	
12	.2534	.2507		.2347	.2652	.2347	
13	.2507	.2374		.2294	.253	.2622	
14	.2481	.2743	.2149	.2267	.2591	.2401	.2743
15	.2507	.2058	.2683	.2622	.253	.2035	.2622
16	.2865	.2126	.2652	.2347	.2187		.3086
17	.2591	.192	.2622	.208	.2401		.2713
18	.3467	.2481	.3814	.3155	.4298	.3544	.3898
19	.5281	.4706	.5175	.5121	.5068	.5487	.6335
20	.5281	.5175	.5175	.5175	.4854	.4805	.4805
21	.4904	.4066	.4435	.4108	.0518	.4108	.4481
22	.3658	.2926	.3258	.3326	.3326	.3326	.3658
23	.2427	.2149	.2172	.2774	.2561	.2172	.2534
24	.2012	.1848	.1753	.1772	.1791	.2149	.2126
Max	**.5281**	**.5175**	**.5175**	**.5175**	**.5068**	**.5487**	**.6335**
Min	**.2012**	**.1791**	**.1753**	**.1772**	**.0518**	**.2035**	**.2126**
Avg	**.3202**	**.2798**	**.3020**	**.2802**	**.2821**	**.3157**	**.3350**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
UMBRAJ S/DN.[108] **BU 5932**
Substation No/ Name :- 254006 / MASUR
Feeder No / Name : 207 / Satyam Express **NON SHEDDABLE EXPRESS HV FEEDERS**
Feeder KV- 11 / OUTGOING **(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.1132		.0324
2					.0572		.0332
3					.0566		.0328
4					.0566		.032
5					.0572		.0312
6					.0566		.0328
7					.0366		.0332
8					.0181		.032
9				.0086	.0381	.0351	.0362
10					.0572	.0171	.0351
11	.0114				.0572		
12	.013				.2858	.0343	
13	.0093				.4382	.0171	
14			.017		.4572	.0396	.0086
15	.0084		.009		.1334	.381	.0086
16			.0097		.0086		.0366
17							.0173
18		.0191			.0156	.0335	.0339
19	.0187	.0189	.0095		.0135	.0566	.0373
20	.0181	.0191	.0095	.0084	.0126	.0566	.0377
21				.0189	.0143	.0566	.0377
22	.0189			.0189		.0328	.0324
23				.0732		.0347	.0335
24					.1109		.0335
Max	**.0189**	**.0191**	**.017**	**.0732**	**.4572**	**.381**	**.0377**
Min	**.0084**	**.0189**	**.009**	**.0084**	**.0086**	**.0171**	**.0086**
Avg	**.0140**	**.0190**	**.0109**	**.0256**	**.0997**	**.0663**	**.0309**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
UMBRAJ S/DN.[108] **BU 5932**
Substation No/ Name :- 254006 / MASUR
Feeder No / Name : 208 / kharade ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0701	.0693	.6642	.6401	.6706	.0533	.0663
2	.0617	.0514	.6962	.6802	.6554	.0549	.0663
3	.0663	.0537	.7122	.7042	.6783	.0549	.064
4	.0701	.0543	.6562	.7545	.6478	.0556	.0625
5	.0709	.0526	.7459	.7287	.7122	.0572	.0655
6	.0362	.0543	.7362	.8097	.7956	.061	.0648
7	.037	.0537	.7499	.9054	.8745	.0271	.0648
8	.0373	.0457	.8124	.9172	.9105	.0465	.08
9	.6478	1.0486	.0229	.0686	.0591	1.3435	1.9109
10		1.0802		.0472	.0389	1.7436	2.1795
11	.9054			.0472	.0594	1.8461	
12	.6859	1.1012		.0457	.0686	1.9109	
13	.9835	1.1203		.0457	.0594	2.1026	
14	.9717	1.1012	.0116	.0465	.0419	2.0081	1.8461
15	.9717	1.1469		.046	.0419	2.0119	2.0008
16	.9717	1.1797	.0114	.0914	.0404		2.0576
17	.0335	.0495	.0114	.0389	.0229		.0442
18	.0678		.0271	.0617	.0457	.0278	.061
19	.0625	.0587	.061	.0781	.072	.0511	.0617
20	.0732	.0533	.061	.0772	.0541	.0693	.0572
21	.0541	.0518	.0549	.104	.0518	.0556	.0587
22	.061	.0541	.0579	.1086	.0541	.0549	.0602
23	.0625	.0579	.0587	.1097	.0526	.0564	.0572
24	.0617	.0594	.0541	.0594	.1052	.0533	.0572
Max	**.9835**	**1.1797**	**.8124**	**.9172**	**.9105**	**2.1026**	**2.1795**
Min	**.0335**	**.0457**	**.0114**	**.0389**	**.0229**	**.0271**	**.0442**
Avg	**.3071**	**.3908**	**.3266**	**.3007**	**.2839**	**.6248**	**.5232**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
UMBRAJ S/DN.[108] **BU 5932**
Substation No/ Name :- 254023 / TARALE
Feeder No / Name : 201 / BAMBAWADE **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1402	.1578	.1402	.1578	.1578	.1595	.1227
2	.1402	.1402	.1402	.1578	.1578	.1595	.1227
3	.1402	.1402	.1402	.1578	.1578	.1772	.1227
4	.1578	.1402	.1578	.1578	.1578	.1772	.1402
5	.2103	.1578	.1753	.1578	.2103	.1928	.1578
6	.3155	.2454	.2454	.2804	.3155	.333	.3155
7	.5258	.4733	.5083	.4908	.4733	.4908	.5258
8	.4733	.5083	.5258	.4733	.5083	.4382	.5434
9	.3506	.4557	.4382	.4031	.4733	.4733	.4733
10	.2804	.3506	.3681	.333	.3856	.3856	.3681
11	.2629	.2279	.3506	.2629	.3155	.298	.333
12	.2454	.1753	.2804	.2629	.2629	.2804	.2804
13	.2279	.2279	.2454	.2103	.2629	.1928	.2629
14	.2804	.2103	.2629	.1578	.2629	.2279	.2454
15	.2454	.2279	.2454	.2279	.2804	.2279	.2279
16	.2629	.2279	.2629	.1753	.2804	.2804	.2629
17	.298	.2804	.3155	.2629	.3155	.333	.3155
18	.4207	.4382	.4207	.3681	.4557	.4382	.3506
19	.6661	.631	.631	.5609	.6485	.5784	.4908
20	.631	.5959	.5959	.5258	.631	.5959	.4557
21	.5434	.5258	.4908	.5258	.5434	.5083	.4207
22	.3856	.3155	.3506	.3506	.3506	.3506	.3506
23	.2103	.1928	.2103	.2103	.2454	.1928	.2279
24	.1402	.1753	.1402	.1578	.1753	.1753	.1753
Max	**.6661**	**.631**	**.631**	**.5609**	**.6485**	**.5959**	**.5434**
Min	**.1402**	**.1402**	**.1402**	**.1578**	**.1578**	**.1595**	**.1227**
Avg	**.3148**	**.3009**	**.3184**	**.2929**	**.3345**	**.3195**	**.3038**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
UMBRAJ S/DN.[108] **BU 5932**
Substation No/ Name :- 254023 / TARALE
Feeder No / Name : 202 / TARALE -VG- **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1402	.1402	.1227	.1227	.1402	.1417	.1227
2	.1402	.1402	.1227	.1227	.1402	.1417	.1227
3	.1402	.1402	.1227	.1227	.1402	.1417	.1227
4	.1578	.1402	.1402	.1227	.1402	.1417	.1227
5	.1753	.1402	.1578	.1227	.1753	.1417	.1402
6	.2103	.1753	.1753	.1402	.2804	.2454	.2103
7	.3506	.2804	.333	.3155	.3506	.3506	.3506
8	.333	.2804	.3506	.3856	.3506	.3155	.3506
9	.2629	.2103	.2629	.3155	.3155	.2804	.2804
10	.2629	.2103		.2804	.298	.2103	.2103
11	.2279	.1753	.2454	.2804	.2629	.1753	.1753
12	.2103	.1402	.2103	.2103	.2279	.2454	.1402
13	.1753	.1402	.1753	.2103	.2103	.1753	.1402
14	.1928	.1402	.1402	.1753	.2454	.1402	.1402
15	.2279	.1402	.1402	.1753	.2103	.1753	.1402
16	.1928	.1402	.1402	.1753	.2279	.1753	.1402
17	.1753	.2454	.2103	.2804	.2804	.2629	.2804
18	.2804	.3155	.2454	.3155	.3506	.298	.333
19	.3856	.3856	.3506	.4207	.3856	.4207	.4207
20	.3506	.333	.3856	.3856	.3681	.4031	.3856
21	.3506	.2804	.3155	.3506	.3155	.3155	.2804
22	.2454	.2103	.2103	.3155	.2804	.2279	.2103
23	.1753	.1402	.1402	.1753	.1753	.1402	.1402
24	.1402	.1753	.1402	.1402	.1402	.1402	.1402
Max	**.3856**	**.3856**	**.3856**	**.4207**	**.3856**	**.4207**	**.4207**
Min	**.1402**	**.1402**	**.1227**	**.1227**	**.1402**	**.1402**	**.1227**
Avg	**.2293**	**.2008**	**.2103**	**.2359**	**.2505**	**.2253**	**.2125**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
UMBRAJ S/DN.[108] **BU 5932**
Substation No/ Name :- 254023 / TARALE
Feeder No / Name : 203 / DUSALE **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0701	.0701	.0701	.0701	.0701		.0701
2	.0701	.0701	.0701	.0701	.0701	.0709	.0701
3	.0701	.0701	.0701	.0701	.0701	.0709	.0701
4	.0701	.0701	.0701	.0701	.0701	.0709	.0701
5	.0701	.0701	.0701	.0701	.0876	.0709	.0701
6	.0876	.0701	.0876	.0701	.1052	.1052	.0701
7	.1402	.1052	.1402	.1402	.1227	.1052	.1402
8	.1227	.1052	.1402	.1402	.1227	.1052	.1227
9	.1227	.1052	.1052	.1052	.1227	.1052	.1227
10	.1052	.1052	.1052	.1052	.1052	.1052	.1052
11	.1052	.0701	.1052	.1052	.1052	.1052	.1052
12	.0876	.1052	.0876	.1052	.1052	.0701	.0701
13	.0701	.0701	.0701	.1052	.0701	.0701	.0701
14	.0701	.0701	.0701	.0701	.0701	.0701	.0701
15	.0701	.0701	.0701	.0701	.0701	.0701	.0701
16	.0701	.0701	.0701		.0876	.0876	.0701
17	.0701	.0701	.0701	.0701	.0701	.0876	.0876
18	.1052	.1052	.0701	.0876	.1052	.1052	.1227
19	.1402	.1578	.1402	.1227	.1402	.1402	.1402
20	.1402	.1578	.1753	.1402	.1402	.1402	.1402
21	.1402	.1227	.1402	.1402	.1402	.1227	.1227
22	.1052	.0876	.1052	.1227	.1402	.0876	.1052
23	.1052	.0701	.0701	.0876	.0701	.0701	.0876
24	.0701	.0701	.1227		.0701	.0701	.0701
Max	**.1402**	**.1578**	**.1753**	**.1402**	**.1402**	**.1402**	**.1402**
Min	**.0701**	**.0701**	**.0701**	**.0701**	**.0701**	**.0701**	**.0701**
Avg	**.0949**	**.0891**	**.0957**	**.0972**	**.0971**	**.0916**	**.0935**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
UMBRAJ S/DN.[108] **BU 5932**
Substation No/ Name :- 254023 / TARALE
Feeder No / Name : 204 / BAMBAWADE AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3978	.3563	.3239		
2			.3978	.3401	.3239		
3			.4144	.3401	.3239		
4			.4144	.3401	.3239		
5			.4475	.3401	.3239		
6			.4475	.3401	.3239		
7			.5304	.421	.3563		
8			.5801	.4696	.4858		
9	.4973	.6154				.5506	.8288
10	.5304	.7287				.6154	1.0688
11	.6464	.7287				1.0526	1.1822
12	.6464	.8764				1.004	1.2793
13	.7293	.8583				1.0202	1.2631
14	.7625	.7611				1.1336	1.3279
15	.7459	.7773				1.0364	1.4089
16	.7625	.7935				1.1498	1.3603
Max	**.7625**	**.8764**	**.5801**	**.4696**	**.4858**	**1.1498**	**1.4089**
Min	**.4973**	**.6154**	**.3978**	**.3401**	**.3239**	**.5506**	**.8288**
Avg	**.6651**	**.7674**	**.4537**	**.3684**	**.3482**	**.9453**	**1.2149**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
UMBRAJ S/DN.[108] **BU 5932**
Substation No/ Name :- 254023 / TARALE
Feeder No / Name : 205 / TARALE -AG- **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8288	.8356				1.3927	1.2597
2	.8288	.852				1.4089	1.2431
3	.7956	.8684				1.4251	1.2431
4	.7956	.8848				1.4251	1.2597
5	.7956	.9012				1.4413	1.2597
6	.7956	.9175				1.4737	1.3094
7	.9945	1.1633				1.6032	1.5249
8	.9945	1.1961					1.5083
9				1.1822	1.5546		
10			.1943	1.5708	1.7404		
11			.2105	1.8461	2.1548		
12			.2105	2.0405	2.2211		
13			1.2955	2.1214	2.2377		
14			1.4251	2.1214	2.0553		
15			1.4251	1.8947	2.2874		
16			1.3765	1.7976	2.1879		
Max	**.9945**	**1.1961**	**1.4251**	**2.1214**	**2.2874**	**1.6032**	**1.5249**
Min	**.7956**	**.8356**	**.1943**	**1.1822**	**1.5546**	**1.3927**	**1.2431**
Avg	**.8536**	**.9524**	**.8768**	**1.8218**	**2.0549**	**1.4529**	**1.3260**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
UMBRAJ S/DN.[108] **BU 5932**
Substation No/ Name :- 254055 / 33/11 Pal
Feeder No / Name : 201 / 11kv CHORE VILLEGE **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.3361	.4066	.3429	.362	.4108	.439
2	.2614	.2987	.3696	.3429	.394	.4108	.3982
3	.2641	.2987	.3696	.3772	.4706	.4481	.4298
4	.2641	.3361	.3696	.4801	.4435	.4481	.5068
5	.2829	.5228	.4251	.6173	.5068	.4854	.5853
6	.5716	.5975	.5544	.3086	.6089	.5975	.6878
7	.7167	.7468	.8501	.823	.7602	.7095	.8779
8	.7167	.7842	.7023	.7202	.7316	.7842	.8048
9	.7095	.7468	.6653	.7545	.7964	.7095	.695
10	.8215	.7095	.6653	.7888	.695	.7095	.5121
11	.6722	.6283	.583	.6584	.8215	.7316	.5144
12	.6348	.6283	.5487	.6516	.6722	.724	.4801
13	.6348	.4805	.5144	.5068	.6348	.5731	.4287
14	.6036	.4805	.5487	.6584	.6722	.5068	.4115
15	.6348	.5914	.5487	.6219	.7095	.7316	.4115
16	.6348	.5544	.5144	.6516	.6722	.724	.4287
17	.6348	.7023	.6516	.5853	.6722	.7964	.4801
18	.7468	.8316	.823	.905	.7468	.7682	.5487
19	.8589	.9055	.9602	1.0029	.9335	.8688	.8573
20	1.0082	.8501	.8916	.9145	1.0082	.8048	.8916
21	.8962	.7023	.7888	.7316	.8962	.7964	.7202
22	.6348	.5914	.6859	.7316	.7095	.7316	.5487
23	.3734	.462	.5144	.5792	.4854	.695	.5144
24	.2402	.3734	.4066	.3086	.3658	.4481	.439
Max	**1.0082**	**.9055**	**.9602**	**1.0029**	**1.0082**	**.8688**	**.8916**
Min	**.2402**	**.2987**	**.3696**	**.3086**	**.362**	**.4108**	**.3982**
Avg	**.5866**	**.5900**	**.5982**	**.6276**	**.6570**	**.6506**	**.5672**

 Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
UMBRAJ S/DN.[108] **BU 5932**
Substation No/ Name :- 254055 / 33/11 Pal
Feeder No / Name : 202 / 11kv VADGAON AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.6226	.032	.0686	.029	.6554	1.0562
2	.6478	.6299	.032	.0343	.029	.6859	.9172
3	.6478	.6962	.032	.0343	.029	.6962	.9568
4	.6401	.7209	.032	.0343	.0293	.7537	.9998
5	.6401	.7449	.032	.0686	.0282	.8951	.9374
6	.6722	.7773	.032	.0686	.0278	.9503	1.012
7	.8322	.852	.032	.0686	.0297	1.004	1.1069
8	.8002	.8848	.032	.0686	.029	1.094	1.142
9	.032	.0343	.9282	1.2003	1.0437	.0343	.0297
10	.032	.0343	1.0242	1.2689	1.2018	.0343	.0278
11	.0343	.032	1.0631	1.0753	1.0814	.0278	.0686
12	.0343	.032	1.0288	1.1728	1.1142	.0297	.0686
13	.0343	.048	1.0288	1.1702	1.1603		.0686
14	.0343	.048	1.0631	1.1248	1.2452		.0686
15	.0343	.048	1.0631	1.1069	1.2929		.0686
16	.0343	.048	1.0631	1.0936	1.2929	.0274	.0686
17	.0343	.032	.0686	.029	.0343	.0278	.0686
18	.0343	.032	.0686	.0286	.0343	.0324	.0686
19	.0343	.032	.0686	.0278	.0343	.0332	.0686
20	.0343	.0324	.0686	.0282	.0343	.0301	.0686
21	.0343	.032	.0686	.0282	.0229	.0301	.0686
22	.0343	.032	.0686	.029	.0343	.0332	.0686
23	.0343	.032	.0686	.0282	.0343	.032	.0686
24	.0305	.0343	.032	.0686	.0278	.0343	.0324
Max	**.8322**	**.8848**	**1.0631**	**1.2689**	**1.2929**	**1.094**	**1.142**
Min	**.0305**	**.032**	**.032**	**.0278**	**.0229**	**.0274**	**.0278**
Avg	**.2516**	**.2713**	**.3763**	**.4136**	**.4133**	**.3401**	**.3796**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
UMBRAJ S/DN.[108] **BU 5932**
Substation No/ Name :- 254055 / 33/11 Pal
Feeder No / Name : 203 / 11kv SHIRGAON AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.096	.1029	1.9433	2.0576	1.6324	.0686	.0594
2	.096	.1029	1.9433	2.0576	1.7078	.0686	.0579
3	.096	.1029	1.9433	2.0576	1.781	.0686	.0594
4	.096	.1029	1.9433	2.1262	1.7711	.0686	.0587
5	.096	.1029	1.9595	2.1605	1.8435	.1029	.0564
6	.112	.1029	2.0081	2.2977	2.0241	.1029	.0572
7	.128	.1029	2.1376	2.2291	2.1445	.1029	.0914
8	.0983	.1029	1.9433	2.2291	2.0622	.1029	.0602
9	2.34	2.5232	.0972	.0686	.0587	2.2939	1.6762
10	2.5774	2.8182	.0648	.0686	.0278	2.7854	3.0247
11	2.7206	.5087	.0686	.0564	.0343	1.7185	3.3608
12	2.7199	.2591	.0686	.0602	.0343	2.9096	3.3951
13	2.7199	2.5911	.0686	.0602	.0686	2.8086	3.3951
14	2.7846	2.8178	.0686	.0587		2.7808	3.2922
15	2.6871	2.7206	.0686	.0556	.0686	2.7469	3.2579
16	2.6543	2.7044	.0686	.0594	.1029	2.8746	3.0864
17	.1029	.0848	.0686	.0293	.1029	.0914	.1029
18	.1029	.0848	.0686	.0594	.1052	.061	.1029
19		.0819	.1029	.0579	.1029	.0655	.1029
20	.0686	.081	.1029	.0602	.1029	.0655	.1029
21	.1029	.0819	.1029	.0602	.1029	.0602	.1029
22	.1029	.0983	.1029	.061	.1029	.0686	.1029
23	.1086	.0983	.1029	.0602	.1029	.0655	.0686
24	.0772	.1086	.0972	.0686	.0594	.112	.0602
Max	**2.7846**	**2.8182**	**2.1376**	**2.2977**	**2.1445**	**2.9096**	**3.3951**
Min	**.0686**	**.081**	**.0648**	**.0293**	**.0278**	**.0602**	**.0564**
Avg	**.9864**	**.7702**	**.7143**	**.7567**	**.7019**	**.9248**	**1.0723**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
UMBRAJ S/DN.[108] **BU 5932**
Substation No/ Name :- 254055 / 33/11 Pal
Feeder No / Name : 204 / 11 KV khandoba Express Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS (CONTINOUS PROCESS)(NO STAGGERING)

DATE	02-NOV-17	06-NOV-17
HR	Load (MW)	Load (MW)
14	1.5242	
21		.0686
Max	1.5242	.0686
Min	1.5242	.0686
Avg	1.5242	.0686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
UMBRAJ S/DN.[108] **BU 5932**
Substation No/ Name :- 254065 / 33/11 kv urul
Feeder No / Name : 201 / Charegaon AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.9602	.0747	.0747	.0934	1.1145	.9602
2	.6516	.823	.0747	.0747	.0747	1.1145	.9602
3	.6859	.8048	.056	.0747	.0747	1.1361	.9945
4	.6859	.8383	.056	.0747	.0747	1.1361	.9945
5	.823	.9556	.056	.0747	.0934	1.1869	1.0288
6	.8916	.9835	.0934	.1307	.1307	1.2209	1.0513
7	.9259	1.0852	.1494	.1494	.1867		1.2717
8	.9602	1.1191	.112	.1867	.1867	1.1022	1.3565
9	.1494	.112	1.2174		1.5947	.1307	.168
10	.1494	.112	1.5592	1.7604	1.6263	.1307	.168
11	.1494	.0943		1.576	1.8442	.1307	.112
12	.1494	.0943	.096	1.6095	1.8442	.1307	.112
13	.1494	.0377	.128	1.643	1.7604	.1307	.112
14	.1307	.0377	.4001	1.643	1.6263	.1307	.1494
15	.112	.0377	1.3927	1.358	1.6263	.112	.1494
16	.112	.1307	1.4251	1.3546	1.4251	.112	.1307
17	.112	.1494	.1296	.112	.112	.112	.168
18	.1494	.1307	.1494	.1307	.112	.168	.1494
19	.1494	.112	.1494	.1494	.1307	.168	.1494
20	.1494	.1307	.1494	.1494	.1307	.168	.1307
21	.1307	.112	.1307	.1307	.112	.1494	.1307
22	.112	.0934	.112	.112	.112	.1307	.0934
23	.0934	.0934	.0747	.0934	.0934	.0934	.0747
24	.0747	.0747	.0747	.0747	.0934	.0747	.0747
Max	**.9602**	**1.1191**	**1.5592**	**1.7604**	**1.8442**	**1.2209**	**1.3565**
Min	**.0747**	**.0377**	**.056**	**.0747**	**.0747**	**.0747**	**.0747**
Avg	**.3479**	**.3801**	**.3418**	**.5538**	**.6316**	**.4384**	**.4454**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
UMBRAJ S/DN.[108] **BU 5932**
Substation No/ Name :- 254065 / 33/11 kv urul
Feeder No / Name : 202 / charegaon vlg **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3109	.2865	.3077	.2743	.2743	.3045	.2865
2	.2926	.2686	.2896	.2743	.2743	.3045	.2865
3	.2926	.2686	.2896	.2743	.2743	.2865	.2865
4	.2743	.3045	.2896	.2743	.2926	.2865	.3224
5	.2926	.3582	.3582	.3658	.3292	.3582	.3582
6	.4887	.4298	.4656	.4572	.543	.5014	.4706
7	.7343	.7602	.7522	.7316	.8059	.7602	.7602
8	.8238	.8507	.7522	.7522	.6805	.8059	.8326
9	.6089	.6516	.591	.591		.6516	.6516
10	.6268	.543	.5194	.5316	.128	.5792	.5792
11	.5014	.394	.4298	.4835	.6154	.5068	.4706
12	.394	.3224	.4207	.4656	.5731	.4525	.4525
13	.3258	.2865	.3856	.3582	.5373	.4344	.3841
14	.3258	.2865	.3155	.3258	.3761	.3982	.3658
15	.3258	.2896	.3506	.3439	.3761	.394	.3658
16	.3439	.3582	.3155	.362	.394	.4119	.3801
17	.362	.4477	.4733	.5611	.543	.4298	.4344
18	.6089	.6878	.6135	.7964	.7602	.591	.5973
19	.8954	.9231	.9134	.8775	.905	.8954	.8417
20	.905	.8688	.8238	.7701	.905	.8954	.7701
21	.7602	.724	.7059	.6626	.724	.7522	.7164
22	.543	.5249	.4887	.4656	.6516	.6805	.5249
23	.4656	.3801	.3439	.362	.4344	.4656	.3982
24	.3109	.2865	.3077	.2715	.2926	.3077	.3045
Max	**.905**	**.9231**	**.9134**	**.8775**	**.905**	**.8954**	**.8417**
Min	**.2743**	**.2686**	**.2896**	**.2715**	**.128**	**.2865**	**.2865**
Avg	**.4922**	**.4792**	**.4793**	**.4847**	**.5083**	**.5189**	**.4934**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
UMBRAJ S/DN.[108] **BU 5932**
Substation No/ Name :- 254065 / 33/11 kv urul
Feeder No / Name : 203 / Mazgaon Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0373	.7716	.7202	.6859	.0373	.0373
2	.0377	.0373	.7716	.7202	.7202	.0373	.0373
3	.0377	.0373	.7716	.7202	.7202	.0373	.0373
4	.0377	.0373	.7716	.7202	.7545	.0373	.0373
5	.0377	.0373	.823	.7202	.823	.0373	.0373
6	.0377	.0373	.8573	.7888	.8573	.0373	.0373
7	.0377	.0373	1.0117	.9259	.9431	.0377	.0373
8	.0377	.0373	1.046	.9088	.9945	.0377	.0373
9	1.1401	1.0631	.0373	.056	.0377	1.3375	1.7465
10	1.1233	1.166	.0373	.056	.0377	1.3717	1.8652
11	1.1736	1.2574	.0373	.056	.0377	1.5261	1.9839
12	1.2574	1.1904	.0373	.056	.0373	1.7804	1.933
13	1.358	1.358	.056	.056	.0373	1.8652	1.933
14	1.3413	1.3413	.0747	.056	.0373	1.8442	1.9669
15	1.2574	1.3077	.056	.0377	.0373	1.7604	1.9161
16	1.2266	1.2407	.0747	.0377	.0373	1.7072	1.7635
17	.0377	.0373	.056	.0377	.056	.056	.0377
18	.0377	.0566	.0373	.0373	.0373	.056	.056
19	.0373	.0566	.0377	.056	.0373	.056	.056
20	.0373	.0377	.0377	.0373	.0373	.056	.056
21	.0373	.0377	.0377	.0373	.0373	.0747	.056
22	.0373	.0377	.0377	.0373	.0373	.056	.056
23	.0373	.0373	.0377	.0373	.0373	.0373	.056
24	.0377	.0373	.0373	.0377	.0377	.0373	.0373
Max	**1.358**	**1.358**	**1.046**	**.9259**	**.9945**	**1.8652**	**1.9839**
Min	**.0373**	**.0373**	**.0373**	**.0373**	**.0373**	**.0373**	**.0373**
Avg	**.4366**	**.4401**	**.3148**	**.2897**	**.2965**	**.5801**	**.6591**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
UMBRAJ S/DN.[108] **BU 5932**
Substation No/ Name :- 254066 / Shahapur
Feeder No / Name : 201 / Shahapur Vlg **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.4001	.2286	.2286	.2286	.2286
2	.3429	.3429	.381	.2286	.2286	.2286	.2286
3	.3429	.3429	.381	.2858	.2286	.2667	.2286
4	.381	.381	.4191	.381	.2286	.3429	.2477
5	.4382	.4572	.4954	.4572	.2667	.4191	.2667
6	.6668	.6859	.7842	.4954	.381	.4954	.5144
7	.7282	.8029	.8413	.6908	.6161		.6722
8	.6584	.7095	.6154	.6036	.5729	.5729	.5487
9	.6878	.3881	.6154	.5068	.4706	.4755	.4525
10	.3921	.4706	.4163	.4207	.362	.3761	.298
11	.439	.3982	.362	.362	.3258	.2774	.2804
12	.3696	.4706	.3292	.362	.298	.2454	.2427
13	.3174	.4344	.3292	.2926	.2572	.2454	.2229
14	.5228	.5249	.3077	.2601	.2804	.2454	.2279
15	.2743	.5611	.3292	.2427	.2804	.2454	.2279
16	.5601	.362	.3109	.2427	.2804	.2865	.2658
17	.5121	.5258	.3881	.3224	.3292	.333	.2658
18	.6099	.6805	.462	.499	.5304	.4572	.4075
19	.9709	.9511	.7392	.7392	.7316	.7468	.7133
20	.8402	.9149	.6468	.7095	.0572	.6668	.6099
21	.8002	.8002	.6161	.6348	.5788	.5525	.5228
22	.6478	.6859	.5281	.5041	.4527	.4382	.4668
23	.4382	.4763	.381	.3239	.3429	.2858	.2858
24	.362	.381	.4191	.2667	.2477		.2477
Max	**.9709**	**.9511**	**.8413**	**.7392**	**.7316**	**.7468**	**.7133**
Min	**.2743**	**.3429**	**.3077**	**.2286**	**.0572**	**.2286**	**.2229**
Avg	**.5269**	**.5455**	**.4791**	**.4192**	**.3574**	**.3833**	**.3614**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
UMBRAJ S/DN.[108] **BU 5932**
Substation No/ Name :- 254066 / Shahapur
Feeder No / Name : 202 / Shahapur Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.945	.8951	.1143	.0572	.0762	.7164	1.2186
2	.945	.8535	.1143	.0572	.0762	.7621	1.1873
3	.9145	.823	.1143	.0572	.0762	.8333	1.1561
4	.884	.8078	.1143	.0762	.0762	.8488	1.1248
5	.884	.8333	.1143	.0762	.0953	.8905	1.1092
6	.884	.8642	.0953	.0762	.0762	.9217	1.1561
7	1.0669	.9962	.1334	.0953	.1143		1.2498
8	1.0974	.9602	.0953	.0953	.1143	1.1702	1.2193
9	.0953	.0762	1.2498	1.4232	1.4074	.0762	.0572
10	.0953	.0381	1.3904	1.6876	1.5779	.0953	.0762
11	.0572	.0381	1.439	1.1126	1.531	.0572	.0572
12	.0953	.0762	1.4198	1.4327	1.5432	.0953	.0762
13	.0953	.0762	1.406	1.5203	1.5242	.0762	.0953
14	.0953	.1143	1.4074	1.4373	1.4937	.0762	.0953
15	.0953	.0953	1.3748	1.406	1.4784	.0762	.0572
16	.0762	.0953	1.3592	1.2803	1.4022	.0572	.0762
17	.0572	.1143	.0572	.0953	.0762	.0953	.0953
18	.1143	.1143	.0572	.0762	.0572	.0953	.0953
19	.1143	.0953	.0572	.0762	.0572	.0762	.1334
20	.0953	.0953	.0572	.0572	.0572	.0762	.0953
21	.0953	.0953	.0762	.0762	.0572	.0762	.0953
22	.1143	.0953	.0572	.0762	.0762	.0762	.0953
23	.0953	.0953	.0572	.0762	.0762	.0762	.0762
24	.0762	.0762	.1143	.0572	.0762		.0762
Max	**1.0974**	**.9962**	**1.439**	**1.6876**	**1.5779**	**1.1702**	**1.2498**
Min	**.0572**	**.0381**	**.0572**	**.0572**	**.0572**	**.0572**	**.0572**
Avg	**.3787**	**.3510**	**.5198**	**.5201**	**.5499**	**.3329**	**.4489**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
KARAD DIVISION[512]
UMBRAJ S/DN.[108] **BU 5932**
Substation No/ Name :- 254066 / Shahapur
Feeder No / Name : 203 / Riswad Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0572	.9998	.9877	1.0526	.0762	.0762
2	.0762	.0572	1.0155	1.078	1.0279	.0762	.0762
3	.0762	.0572	1.0155	1.1248	1.0437	.0762	.0762
4	.0762	.0572	1.0311	1.1574	1.0883	.0953	.0762
5	.0762	.0572	1.0467	1.1883	1.1683	.0953	.0762
6	.1143	.0762	1.142	1.2186	1.2334	.0953	.0953
7	.1143	.0953	1.5699	1.692	1.704		.0762
8	.1143	.0953	1.5394	1.7166	1.7859	.1143	.0762
9	1.656	1.8679	.0953	.1334	.0953	1.9766	1.2186
10	2.0317	2.2725	.1143	.0953	.1143	2.0891	.7773
11	2.13	2.3903	.1143	.1143	.0953	2.5888	2.2939
12	2.1792	2.2653	.1143	.0953	.0953	2.9338	2.7349
13	2.4291	2.3746	.0953	.0953	.0953	2.2447	2.7515
14	2.42	2.4074	.0953	.0953	.0953	2.4905	2.6052
15	2.4531	2.4074	.1143	.0953	.0953	2.8178	2.4577
16	2.2611	2.2994	.1143	.0953	.0953	2.7018	2.4577
17	.1143	.0953	.1143	.0762	.0953	.0953	.0572
18	.1334	.1334	.1143	.1334	.0953	.1334	.0953
19	.0953	.0953	.0762	.1143	.0953	.1143	.0953
20	.0953	.1143	.0762	.0953	.0953	.1143	.0953
21	.0953	.1143	.0762	.0953	.0953	.0953	.0953
22	.0762	.0953	.0762	.0953	.0953	.0953	.0762
23	.0762	.0953	.0762	.0762	.0953	.0953	.0762
24	.0762	.0572	.0953	.0762	.0953		.0762
Max	**2.4531**	**2.4074**	**1.5699**	**1.7166**	**1.7859**	**2.9338**	**2.7515**
Min	**.0762**	**.0572**	**.0762**	**.0762**	**.0953**	**.0762**	**.0572**
Avg	**.7936**	**.8183**	**.4551**	**.4894**	**.4853**	**.9643**	**.7747**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
KHANDALA S/DN.[819] BU 4819
Substation No/ Name :- 254045 / 33/22 KV SHINDEWADI
Feeder No / Name : 301 / 22 KV WING GAO SHEDDABLE RURAL
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.1494	.1494	.1494	.1494	.181	.1494
2	.1848	.1494	.1867	.1494	.1867	.1448	.1494
3	.1848	.1494	.1494	.1494	.1867	.1448	.1494
4	.1848	.2241	.1494	.1494	.1494	.1448	.1494
5	.1848	.1867	.1867	.1867	.1494	.1448	.1867
6	.2218	.2218	.2241	.2614	.1867	.181	.1867
7	.2957	.2987	.2587	.3292	.2987	.2865	.3734
8	.4066	.3361	.3696	.3326	.3734	.3696	.4066
9	.3696	.3734	.3326	.3734	.4344	.4066	.3734
10	.3734	.2987	.4108	.3734	.4066	.3734	.3734
11	.4481	.4108	.3734	.3734	.4066	.4481	.4108
12	.4481	.3734	.4108	.3734	.4066	.4481	.3734
13	.4481	.3734	.4108	.3361	.362	.4481	.3361
14	.4108	.4481	.4481	.3734	.3696	.3734	.3734
15	.4108	.4108	.3734	.3734	.1478	.4481	.3734
16	.4108	.4108	.4481	.3361	.1848	.4854	.3734
17	.4481	.3734	.4066		.2957	.4854	.4481
18	.4435	.3734	.4435	.2987	.3696	.2987	.4108
19	.4435	.3734	.4108	.3734	.4066	.4481	.4108
20	.4066	.3734	.4108	.3361	.2957	.4066	.4481
21	.3326	.2957	.3734	.2987	.2896	.3361	.3361
22	.2587	.2614	.2987	.2614	.2896	.181	.2987
23	.1478	.1867	.1829	.1494	.1848	.1478	.2241
24	.1848	.1478	.1494	.1478	.1494	.181	.1478
Max	**.4481**	**.4481**	**.4481**	**.3734**	**.4344**	**.4854**	**.4481**
Min	**.1478**	**.1478**	**.1494**	**.1478**	**.1478**	**.1448**	**.1478**
Avg	**.3264**	**.3000**	**.3149**	**.2820**	**.2783**	**.3131**	**.3110**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
KHANDALA S/DN.[819] BU 4819
Substation No/ Name :- 254045 / 33/22 KV SHINDEWADI
Feeder No / Name : 302 / 22 KV SHINDEWADI GAO SHEDDABLE RURAL
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1109	.1494	.112	.1494	.1867	.1086	.1494
2	.1109	.112	.112	.0747	.1494	.1086	.112
3	.1109	.0747	.112	.1494	.1494	.0724	.0747
4	.1109	.1494	.0747	.112	.1867	.1086	.1494
5	.1109	.112	.112	.1494	.1494	.1086	.1494
6	.1478	.1478	.1494	.1494	.1494	.1448	.1494
7	.1848	.2241	.1848	.1867	.1867	.1791	.1494
8	.1848	.1494	.1848	.2241	.1867	.1478	.1848
9	.1848	.1494	.1848	.2241	.1448	.1848	.1867
10	.1867	.1867	.1848	.1867	.2218	.1494	.2241
11	.1867	.1494	.1867	.1867	.2587	.1494	.2241
12	.1867	.1494	.1867	.1867	.1848	.1867	.2241
13	.2241	.1494	.1867	.2241	.181	.1867	.1867
14	.1867	.1494	.1867	.1867	.1848	.2241	.2241
15	.1494	.1867	.2241	.2241	.1848	.2241	.1867
16	.2614	.1867	.1867	.2241	.1848	.1867	.2241
17	.2241	.1867	.1848	.2241	.2218	.2241	.1867
18	.2218	.2241	.2587	.1867	.2218	.2241	.2241
19	.2587	.2241	.2987	.2241	.2587	.2614	.2241
20	.2957	.2614	.2241	.1867	.1848	.1848	.2241
21	.2218	.1848	.1867	.2241	.181	.1867	.1867
22	.1848	.1867	.1867	.1867	.1448	.1448	.1867
23	.1109	.1494	.1463	.1867	.1478	.1478	.1867
24	.1478	.1109	.1494	.1478	.1494	.1086	.1478
Max	**.2957**	**.2614**	**.2987**	**.2241**	**.2587**	**.2614**	**.2241**
Min	**.1109**	**.0747**	**.0747**	**.0747**	**.1448**	**.0724**	**.0747**
Avg	**.1793**	**.1648**	**.1752**	**.1836**	**.1833**	**.1647**	**.1819**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
KHANDALA S/DN.[819] BU 4819
Substation No/ Name :- 254045 / 33/22 KV SHINDEWADI
Feeder No / Name : 303 / 22 KV INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4784	1.9791	1.6804	1.531	1.8671	1.7737	1.531
2	1.4045	1.9044	1.643	1.7551	1.7924	1.7013	1.6804
3	1.4415	1.7924	1.7177	1.7924	1.7551	1.5565	1.7551
4	1.4415	1.4563	1.6057	1.8671	1.7177	1.5927	1.643
5	1.4045	1.419	1.531	1.7177	1.7177	1.5927	1.6804
6	1.4045	1.5893	1.643	1.4937	1.6804	1.6289	1.5684
7	1.5154	1.6804	1.7372	1.6461	1.4937	1.576	1.3443
8	1.5154	2.0538	1.9589	2.2546	1.531	1.8111	1.4045
9	2.1437	2.4646	2.1807	2.3152	1.9547		1.4937
10	2.5766	2.8006	2.5503	2.3525	2.2177	2.3899	2.0911
11	3.062	2.8753	2.9874	2.2405	2.1807	2.838	2.0165
12	2.5019	2.6139	2.2032	2.2779	1.9959	2.6139	2.0911
13	2.5393	2.1658	2.2405	2.3152	1.9185	2.5393	.7468
14	2.5766	2.6886	2.3525	2.5019	2.2916	2.3899	1.0829
15	2.8006	2.3525	2.5393	2.5019	2.1807	2.4272	1.9791
16	2.2405	2.6139	2.5766	2.5019	1.9589	2.3899	2.2405
17	2.2405	2.4272	2.4025	1.9791	1.7372	2.2779	1.419
18	2.2546	2.5393	1.8111	2.2405	1.9959	2.2405	1.4563
19	1.922	2.0165	1.8671	2.1658	1.7741	1.9791	1.2696
20	1.922	1.8671	1.7177	2.2405	1.848	1.7741	1.2323
21	1.848	2.0328	1.8298	1.6804	1.6289	1.531	1.531
22	2.0698	1.6804	1.5684	2.1658	1.9909	1.6289	1.2323
23	1.6632	1.6804	1.5364	1.8671	1.6632	1.7002	1.3443
24	1.4799	1.848	1.7551	1.6632	1.8671	1.7375	1.6632
Max	**3.062**	**2.8753**	**2.9874**	**2.5019**	**2.2916**	**2.838**	**2.2405**
Min	**1.4045**	**1.419**	**1.531**	**1.4937**	**1.4937**	**1.531**	**.7468**
Avg	**1.9770**	**2.1059**	**1.9848**	**2.0445**	**1.8650**	**1.9865**	**1.5624**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
KHANDALA S/DN.[819] BU 4819
Substation No/ Name :- 254045 / 33/22 KV SHINDEWADI
Feeder No / Name : 304 / 22 KV TUBE EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 22 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8501	1.2323	.8589	.8962	.7468	.6516	.8962
2	.7023	1.1203	.8962	.9709	.7842	.6516	.7468
3	.7762	1.0829	.8215	1.7177	.7468	.6516	1.0456
4	.7392	1.0456	.7095	.5975	.6722	.6154	.9335
5	.6653	.7095	.7842	1.7177	.7468	.6516	.6348
6	.924	1.1088	.8589	1.307	.6722	.6154	.5975
7	.6283	.7468	.6283	.7682	.6722	.6089	.6722
8	.7023	.8215	.8501	.8131	.6722	.8501	.8215
9	.8131	.7842	.6283	.8215	.6154	.7762	.7468
10	1.0456	1.1576	.9979	.7842	.6283	.8215	1.2323
11	.9709	.9335	1.3443	.8215	.6283	.7842	.8215
12	.7842	.6348	.8215	.8215	.6653	.6722	.7095
13	1.0829	1.0082	.8589	.8589	.6516	.8962	.9709
14	1.3443	1.1949	1.2696	1.3443	.6653	.8215	.8589
15	.6348	.6348	.8215	.6722	.6283	.6348	.6348
16	.5975	.9709	.8215	.6348	.6653	.9709	.9335
17	.8215	.7468	.6283	.8962	.6283	.8962	.7842
18	1.4784	1.0456	1.1088	.7095	.6283	.9335	.6348
19	.8871	1.0456	1.1949	.7468	.6283	1.0829	1.0082
20	1.1576	.9335	.7468	.7842	.6283	.5914	.7468
21	1.1458	.8501	1.2323	1.1203	.6154	.7468	.7095
22	1.2567	.8589	1.7177	.8962	.6154	.5792	.6348
23		.6722	.7682	.6722	.6653	.6653	.6722
24	.6653	.6653	.8589	1.1827	.7468	.6516	.8131
Max	**1.4784**	**1.2323**	**1.7177**	**1.7177**	**.7842**	**1.0829**	**1.2323**
Min	**.5975**	**.6348**	**.6283**	**.5975**	**.6154**	**.5792**	**.5975**
Avg	**.8988**	**.9169**	**.9261**	**.9398**	**.6674**	**.7425**	**.8025**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
KHANDALA S/DN.[819] BU 4819
Substation No/ Name :- 254045 / 33/22 KV SHINDEWADI
Feeder No / Name : 402 / 33 KV GODREJ EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5524	1.8484	1.4003	1.5123	1.1763	.2715	1.5684
2	1.7187	1.7924	1.5123	1.4003	1.3443	.3801	1.6804
3	1.7741	1.6804	1.5684	1.4563	1.2883	.4887	1.7364
4	1.6632	1.6244	1.5123	1.3443	1.3443	.4887	1.7924
5	1.6078	1.5684	1.5684	1.5684	1.4563	.8145	1.6244
6	1.7741	1.6078	1.4003	1.5123	1.5123	.543	1.7364
7	1.1088	1.1763	1.1088	1.0974	.9522	.6984	1.1203
8	1.885	2.0725	1.885	1.6632	.5601	1.7187	1.9404
9	1.885	1.8484	2.0513	1.6804	.3801	1.7741	1.7364
10	1.7924	1.7924	1.9404	1.7364	.3881	1.8484	1.9605
11	1.5684	2.0725	1.7924	1.5684	.4435	1.7364	1.9044
12	1.7924	1.6244	1.5123	1.7364	.3881	1.5684	1.5684
13	1.7364	1.7924	1.6244	1.6244	.4887	1.5123	1.5123
14	1.9044	1.7364	1.8484	1.6244	.4435	1.6804	1.4563
15	2.0165	1.7364	1.4003	1.9044	.3326	1.7924	1.9044
16	1.6244	1.2883	1.4003	.9522	.2772	1.8484	1.4003
17	1.4003	1.4003	1.1643	.9522	.2218	1.3443	1.1763
18	1.2197	1.0082	1.2752	.8962	.2218	1.0642	.8962
19	.9425	1.1203	1.0082	.8962	.2218	1.1763	.7282
20	.9425	.7842	.9522	.9522	.2218	.8871	.8402
21	.8871	.9979	.9522	.8402	.2172	.8962	.8402
22	1.0534	.9522	1.0082	.8962	.2172	.9231	1.0082
23	1.5524	1.4003	1.5364	1.4003	.2218	.9979	1.0082
24	1.386	1.6078	1.3443	1.4969	1.1225	.2172	1.386
Max	**2.0165**	**2.0725**	**2.0513**	**1.9044**	**1.5123**	**1.8484**	**1.9605**
Min	**.8871**	**.7842**	**.9522**	**.8402**	**.2172**	**.2172**	**.7282**
Avg	**1.5328**	**1.5222**	**1.4486**	**1.3630**	**.6434**	**1.1113**	**1.4386**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
KHANDALA S/DN.[819] BU 4819
Substation No/ Name :- 254045 / 33/22 KV SHINDEWADI
Feeder No / Name : 403 / 33 KV SUSSEN ASIA EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4969	1.5123	1.5123	1.1763	1.2323	.9425	1.4003
2	1.386	1.5684	1.2883	1.2323	1.2323	.8688	1.4563
3	1.5524	1.6244	1.1203	1.1203	1.2883	.8145	1.1203
4	1.4969	1.2323	1.4003	1.4003	1.2883	.9231	1.2323
5	1.386	1.3443	1.4563	1.4563	1.2323	.8145	1.4003
6	1.386	1.3306	1.4003	1.2883	1.2883	.8688	1.4563
7	1.5524	1.5123	1.5524	1.4815	1.2883	1.3432	1.5123
8	1.4969	1.4563	1.6078	1.6078	1.3443	1.5524	1.6078
9	1.5524	1.5123	1.386	1.5123	1.1946	1.5524	1.5123
10	1.7924	1.6244	1.6632	1.5684	1.1643	1.6244	1.6244
11	1.5123	1.4563	1.4003	1.4563	1.386	1.4003	1.5684
12	1.5684	1.5123	1.4003	1.4003	.7762	1.5684	1.6244
13	1.6804	1.5684	1.4563	1.5123	1.2489	1.6244	1.6804
14	1.7924	1.6804	1.5123	1.4563	1.1088	1.6804	1.6244
15	1.4003	1.4003	1.1203	1.5123	.9979	1.4003	1.4003
16	1.7924	1.6244	1.5123	1.5684	1.1643	1.7924	1.4563
17	1.7364	1.5684	1.6078	1.5684	.9979	1.6804	1.6804
18	1.7187	1.6244	1.7741	1.5123	1.0534	1.6804	1.6244
19	1.5524	1.6804	1.6804	1.6244	1.1088	1.7364	1.6804
20	1.2197	1.4003	1.2883	1.4563	.9425	1.4415	1.4563
21	1.5524	1.6078	1.6804	1.5123	1.0317	1.4563	1.5123
22	1.4415	1.5684	1.4563	1.5123	.9774	1.3575	1.5123
23	1.2197	1.2883	1.4266	1.3443	.9425	1.4415	1.4003
24	1.6078	1.6078	1.4003	1.386	1.2323	.9231	1.5524
Max	**1.7924**	**1.6804**	**1.7741**	**1.6244**	**1.386**	**1.7924**	**1.6804**
Min	**1.2197**	**1.2323**	**1.1203**	**1.1203**	**.7762**	**.8145**	**1.1203**
Avg	**1.5372**	**1.5127**	**1.4626**	**1.4444**	**1.1467**	**1.3537**	**1.5040**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
KHANDALA S/DN.[819] BU 4819
Substation No/ Name :- 254045 / 33/22 KV SHINDEWADI
Feeder No / Name : 404 / 33 KV UMICORE EXPRESS
Feeder KV- 33 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1663	.168	.2241	.112	.168	.1086	.168
2	.2218	.112	.168	.168	.168	.1086	.168
3	.1663	.168	.2241	.112	.168	.1086	.168
4	.1663	.168	.2241	.168	.168	.1086	.112
5	.1663	.2241	.168	.168	.2241	.1086	.168
6	.2218	.1663	.2241	.168	.2241	.1629	.168
7	.1663	.168	.1663	.1097	.112	.1612	.168
8	.1663	.2241	.1663	.1109	.112	.1109	.1663
9	.3881	.3361	.2772	.4481	.1086	.5544	.168
10	.5041	.2241	.3881	.2801	.1109	.2241	.8962
11	1.4563	.3361	.3361		.1109	.2801	.7842
12	.3921	.4481	.3361	.4481	.1109	.3361	.3361
13	.2241	2.3525	.4481	.2241	.1629	.7842	.3921
14	.3361	.3361	.3361	.3361	.1109	.7842	.3361
15	.2241	.3921	.8962	.5601	.1109	.7282	.4481
16	.3361	.3361	.3361	.4481	.1109	.2801	.3361
17	.168	.4481	.2218	.6722	.1109	.7842	.3921
18	.2241	2.8006	.1663	.6161	.2218	.6722	.4481
19	.168	.2801	.2241	.168	.1109	.2241	.3361
20	.1663	.168	.168	.2241	.1109	.1663	.3361
21	.1663	.2772	.168	.168	.1086	.2241	.2241
22	.2218	.168	.168	.168	.1086	.1629	.2801
23	.2772	.168	.2195	.1629	.1109	.1663	.2241
24	.2218	.1663	.168	.1109	.168	.1086	.1663
Max	**1.4563**	**2.8006**	**.8962**	**.6722**	**.2241**	**.7842**	**.8962**
Min	**.1663**	**.112**	**.1663**	**.1097**	**.1086**	**.1086**	**.112**
Avg	**.2882**	**.4432**	**.2676**	**.2675**	**.1388**	**.3108**	**.3079**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
KHANDALA S/DN.[819] BU 4819
Substation No/ Name :- 254052 / 33/22 KV MHAVASHI
Feeder No / Name : 301 / 22 KV AHIRE AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.1494	.7545	.9259	.9671	.0686	.0732
2	.1029	.1494	.6859	1.2003	1.2269	.0686	.0732
3	.0686	.1494	.6859	1.2003	1.3176	.0686	.0732
4	.1029	.1494	.6859	1.4746	1.491	.0686	.0732
5	.0686	.112	.7545	1.6118	1.6644	.0686	.0732
6	.0686	.1494	.823	1.6804	1.749	.0686	.0732
7	.1494	.1494	1.0288	2.0233	2.2885	.0686	.0732
8	.1494	.112	.9945	2.2291	2.2539	.0686	.0754
9	2.0911	1.8519	.1029	.0754	.0754	2.2539	2.2539
10	2.9127	1.3032	.0686	.0754	.0686	2.3926	2.5941
11	2.8006	1.3032	.1029	.0754	.0686	2.9473	2.8746
12	3.0994	1.406	.1372	.0754	.0686	2.878	2.2977
13	2.9874	1.3717	.1029	.0754	.0686	3.0167	2.8464
14	3.0247	1.4403	.1372	.0754	.0686	2.0805	2.9492
15	2.7633	1.4403	.0686	.0754	.0686	2.6749	3.0864
16	2.8006	1.3717	.1029	.0754	.0686	2.9473	3.0178
17	.1494	.0686	.1029	.0754	.0686	.0754	.1029
18	.112	.0686	.1715	.0754	.0686	.0754	.0686
19	.1494	.0686	.1372	.0754	.0686	.0754	.1715
20	.1494	.0686	.1715	.0754	.0686	.0754	.1372
21	.1494	.0686	.1372	.0754	.0686	.0754	.1372
22	.1494	.0686	.1372	.0754	.0686	.0754	.0686
23	.1494	.0686	.1029	.0754	.0686	.0754	.1029
24	.0686	.1494	.0686	.0686	.0754	.0686	.0754
Max	**3.0994**	**1.8519**	**1.0288**	**2.2291**	**2.2885**	**3.0167**	**3.0864**
Min	**.0686**	**.0686**	**.0686**	**.0686**	**.0686**	**.0686**	**.0686**
Avg	**1.0140**	**.5516**	**.3444**	**.5644**	**.5862**	**.9307**	**.9738**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
KHANDALA S/DN.[819] BU 4819
Substation No/ Name :- 254052 / 33/22 KV MHAVASHI
Feeder No / Name : 302 / 22 KV KHANDALA GAO GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	1.1203	.8573	.8573	.9412	.6173	.8688
2	.6516	1.1576	.8573	.8573	.9145	.6173	.7964
3	.6859	1.1949	.7888	1.0288	.8688	.583	.6805
4	.9259	1.1203	.7545	1.0288	.8596	.5487	.6805
5	1.0974	1.1576	.7545	.9259	1.1222	.6516	.7164
6	1.2689	1.3443	1.0288	1.1317	1.267	.8916	.9671
7	1.3032	1.3817	1.9204	1.2346	1.3611	1.3717	1.267
8	2.0919	2.3152	1.6461	1.5775	1.2536	1.2003	1.1946
9	1.7177	1.3032	1.3375	1.419	1.1462	1.307	1.3032
10	1.4937	1.406	.8916	1.2696	.9945	1.0608	1.0498
11	1.6057	1.1317	.7202	.924	.7545	1.0136	.8688
12	1.4937	.9259	.823	1.0829	.7888	.6154	.5487
13	1.2323	.8573	1.2689	1.4937	.5487	.6516	.6859
14	.8215	.9259	.7888	1.307	.6173	.8326	.6859
15	1.0456	1.166	1.0288	1.3817	.6173	.6805	.7202
16	1.1576	1.2346	1.1317	.9979	.5487	.7164	.6859
17	1.4563	1.3375	1.2346	.9709	.6516	.7164	.8916
18	1.4563	1.6804	1.2003	1.7741	.7888	.9465	1.0631
19	1.3443	1.2689	1.2346	1.5684	1.0974	1.2536	1.2346
20	1.3817	1.6118	1.2346	1.7924	1.0974	1.1946	1.3032
21	1.3443	1.406	1.0631	1.1203	.9602	1.1218	1.2003
22	1.1203	.9259	1.0288	1.0456	.8573	1.0608	1.0288
23	1.1949	.8916	1.0288	1.0082	.6859	.9774	.7202
24	.9602	1.2323	.8916	.7545	.9774	.6859	.9412
Max	**2.0919**	**2.3152**	**1.9204**	**1.7924**	**1.3611**	**1.3717**	**1.3032**
Min	**.6516**	**.8573**	**.7202**	**.7545**	**.5487**	**.5487**	**.5487**
Avg	**1.2336**	**1.2540**	**1.0631**	**1.1897**	**.905**	**.8882**	**.9209**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
KHANDALA S/DN.[819] BU 4819
Substation No/ Name :- 254052 / 33/22 KV MHAVASHI
Feeder No / Name : 303 / 22 KV AHIRE GAO GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.406	1.6804	1.7833	1.4746	1.7013	1.3032	1.4373
2	1.406	1.6804	1.7833	1.4746	1.5402	1.2346	1.5074
3	1.3717	1.643	1.8519	1.6118	1.5043	1.2346	1.6476
4	1.4403	1.8671	1.9204	1.5089	1.448	1.2689	1.8229
5	1.4403	1.9791	1.989	1.749	1.5402	1.5089	1.9071
6	1.6118	2.2032	1.8176	1.8519	1.6118	1.3032	1.283
7	1.2003	2.0911	2.2291	1.9547	1.5775	1.7147	1.8625
8	1.2003	2.0165	1.7147	1.989	1.4327	1.4403	1.1946
9	1.8671	1.749	2.1605	2.0538	1.3672	2.3529	1.2178
10	1.1949	1.7833	1.5089	1.7177	1.5775	1.9281	1.086
11	1.6057	2.0576	2.572	1.9418	1.4403	2.2436	1.3756
12	1.6804	1.9547	2.3663	1.9044	1.8861	1.893	.9945
13	1.7177	1.749	1.8519	2.3152	1.749	1.8073	1.0288
14	1.8671	2.0576	1.8861	2.1357	1.6461	1.4327	1.0974
15	2.0165	1.7833	2.1262	2.0633	1.5089	2.2885	1.2003
16	1.7924	1.989	2.2977	2.0119	1.5089	1.8983	1.2689
17	1.8671	2.0576	2.1605	1.6632	1.2689	1.9281	1.2003
18	1.9791	2.0576	2.0576	2.1357	1.2346	2.1849	1.2003
19	2.2405	2.0233	2.1605	2.3899	1.3717	1.8625	1.2346
20	1.9044	2.0919	1.989	2.1849	1.2689	1.9185	1.1317
21	1.9791	2.0919	2.1948	2.2565	1.2003	1.8229	1.2689
22	1.9791	2.0576	2.0576	2.1132	1.0631	1.7551	1.0631
23	1.7551	1.8861	1.9547	1.9071	1.4746	1.6655	.9259
24	1.3032	1.9791	1.9204	1.4403	1.6991	1.3717	1.6289
Max	**2.2405**	**2.2032**	**2.572**	**2.3899**	**1.8861**	**2.3529**	**1.9071**
Min	**1.1949**	**1.643**	**1.5089**	**1.4403**	**1.0631**	**1.2346**	**.9259**
Avg	**1.6594**	**1.9387**	**2.0148**	**1.9104**	**1.4842**	**1.7234**	**1.3161**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
KHANDALA S/DN.[819] BU 4819
Substation No/ Name :- 254052 / 33/22 KV MHAVASHI
Feeder No / Name : 304 / 22 KV TBK EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 22 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2241	.1715	.1715	.181	.0686	.1417
2	.2058	.2241	.1715	.1715	.181	.0686	.1417
3	.2058	.1867	.1715	.1715	.181	.0686	.1417
4	.1715	.1867	.1715	.1715	.181	.0686	.1433
5	.1715	.2241	.1715	.2058	.181	.0686	.1448
6	.1715	.1867	.1715	.2058	.181	.0686	.1433
7	.1029	.1494	.1715	.1372	.181	.0686	.1417
8	.1029	.1867	.1372	.1029	.1439	.1029	.1086
9	.1494	.2058	.2058	.1867	.181	.2534	.2172
10	.1867	.2743	.2401	.2614	.1372	.2534	.2126
11	.1494	.2058	.2401	.2241	.1372	.2896	.2172
12	.1867	.1715	.1715	.2241	.1372	.181	.1715
13	.1867	.2058	.2058	.2614	.1372	.2149	.2058
14	.1867	.2401	.2058	.2614	.1372	.2507	.2058
15	.2241	.1715	.2058	.2241	.1029	.2507	.2058
16	.2241	.2058	.2401	.2241	.1029	.2561	.1715
17	.2241	.2058	.1715	.2987	.0686	.2126	.2058
18	.1867	.2401	.2058	.2614	.0686	.2149	.2058
19	.2241	.2058	.2058	.2614	.0686	.2103	.1715
20	.2241	.1715	.1715	.2241	.0686	.1433	.2058
21	.1867	.2058	.2058	.2241	.0686	.1791	.1715
22	.2241	.2401	.2058	.1791	.0686	.1791	.2058
23	.2241	.1715	.2058	.181	.0686	.181	.1715
24	.2058	.2241	.1715	.1372	.181	.0686	.1791
Max	**.2241**	**.2743**	**.2401**	**.2987**	**.181**	**.2896**	**.2172**
Min	**.1029**	**.1494**	**.1372**	**.1029**	**.0686**	**.0686**	**.1086**
Avg	**.1888**	**.2047**	**.1915**	**.2072**	**.1310**	**.1634**	**.1763**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
KHANDALA S/DN.[819] BU 4819
Substation No/ Name :- 254052 / 33/22 KV MHAVASHI
Feeder No / Name : 305 / 22 KV HITECH EXPRESS
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2614	.3086	.3772	.394	.3429	.4252
2	.2401	.2614	.3086	.3772	.394	.3086	.4252
3	.2401	.2614	.3086	.3429	.4298	.3429	.4961
4	.2401	.2987	.3429	.3429	.4298	.3429	.4607
5	.2401	.2987	.3429	.4115	.5014	.4115	.5068
6	.2743	.3361	.4115	.4458	.5014	.4115	.362
7	.3086	.3361	.3086	.4801	.4854	.3772	.4024
8	.2743	.0747	.3429	.2743	.4344	.3429	.362
9	.3361	.3086	.3429	.3734	.3224	.4298	.3189
10	.2987	.3429	.4115	.2987	.4115	.5373	.3982
11	.4108	.3772	.4801	.3361	.3429	.5121	.4344
12	.3734	.4458	.2743	.4481	.4115	.5068	.4115
13	.2987	.3772	.3429	.2987	.3429	.3582	.3772
14	.3361	.3772	.3429	.3734	.3429	.362	.3772
15	.3361	.3429	.3429	.3734	.3429	.362	.4115
16	.3734	.3086	.3429	.3734	.4115	.362	.3772
17	.4481	.3086	.4458	.2987	.3086	.3155	.3429
18	.3361	.3429	.3772	.2241	.3772	.3582	.3429
19	.4108	.3429	.3086	.4481	.3429	.362	.3772
20	.3361	.3429	.4115	.5228	.3429	.2896	.3772
21	.2987	.3086	.3772	.5228	.3772	.4298	.3772
22	.2987	.3086	.3772	.4344	.3772	.394	.4801
23	.2987	.3429	.4458	.394	.3772	.362	.4115
24	.2058	.2987	.3086	.3086	.4298	.3429	.362
Max	**.4481**	**.4458**	**.4801**	**.5228**	**.5014**	**.5373**	**.5068**
Min	**.2058**	**.0747**	**.2743**	**.2241**	**.3086**	**.2896**	**.3189**
Avg	**.3120**	**.3169**	**.3586**	**.3784**	**.3930**	**.3819**	**.4007**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
KHANDALA S/DN.[819] BU 4819
Substation No/ Name :- 254052 / 33/22 KV MHAVASHI
Feeder No / Name : 306 / 22 KV MOLD TECH NON EXP NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 22 / OUTGOING (NON-CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-NOV-17
HR	Load (MW)
24	.0754
Max	.0754
Min	.0754
Avg	.0754

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
KHANDALA S/DN.[819] BU 4819
Substation No/ Name :- 254052 / 33/22 KV MHAVASHI
Feeder No / Name : 401 / 33 KV PANACHE EXPRESS
Feeder KV- 33 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2801	.2058	.3086	.2149	.1029	.2126
2	.2058	.2801	.2058	.3086	.2241	.1029	.2126
3	.2058	.3361	.2058	.3086	.2241	.1543	.2126
4	.2058	.3361	.2058	.3086	.1629	.1543	.2126
5	.2058	.2801	.2058	.3086	.1612	.1543	.1612
6	.2058	.2801	.2572	.3601	.1629	.1543	.1595
7	.2058	.3361	.2572	.3601	.2241	.1543	.2172
8	.2058	.3361	.2572	.3086	.168	.1543	.2195
9	.2801	.2572	.2058	.3921	.168	.3361	.2715
10	.3921	.3086	.3086	.3361	.1029	.2801	.1629
11	.4481	.3601	.2572	.3921	.1543	.2686	.2172
12	.3921	.3601	.2058	.2801	.1543	.3258	.2058
13	.3921	.3086	.2058	.2241	.1029	.3224	.2058
14	.3921	.2572	.3086	.2801	.1543	.2715	.2058
15	.5041	.2058	.2572	.3921	.1543	.3721	.2058
16	.4481	.2058	.2058	.3361	.1543	.2715	.2058
17	.4481	.2058	.1543	.3361	.1029	.2172	.2058
18	.5041	.2058	.2058	.3921	.1029	.1612	.2058
19	.4481	.2572	.2572	.2241	.1543	.2149	.1543
20	.3921	.2058	.2058	.2801	.1543	.2149	.1543
21	.3921	.1029	.2572	.3361	.1543	.2149	.1543
22	.4481	.2058	.2572	.2801	.1543	.2103	.2572
23	.3921	.2058	.2572	.2801	.1029	.2172	.2058
24	.2058	.3361	.2058	.3601	.2715	.1029	.2172
Max	**.5041**	**.3601**	**.3086**	**.3921**	**.2715**	**.3721**	**.2715**
Min	**.2058**	**.1029**	**.1543**	**.2241**	**.1029**	**.1029**	**.1543**
Avg	**.3386**	**.2689**	**.2315**	**.3206**	**.1619**	**.2139**	**.2018**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
KHANDALA S/DN.[819] BU 4819
Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV
Feeder No / Name : 301 / 22 KV WAI INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-NOV-17
HR	Load (MW)
24	.3772
Max	.3772
Min	.3772
Avg	.3772

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
KHANDALA S/DN.[819] **BU 4819**
Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV
Feeder No / Name : 302 / 22 KV KHANDALA AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 22 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17
HR	Load (MW)
24	1.5089
Max	1.5089
Min	1.5089
Avg	1.5089

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
KHANDALA S/DN.[819] BU 4819
Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV
Feeder No / Name : 303 / 22 KV SHIRWAL INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-NOV-17
HR	Load (MW)
24	3.6969
Max	3.6969
Min	3.6969
Avg	3.6969

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
KHANDALA S/DN.[819] BU 4819
Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV
Feeder No / Name : 304 / 22 KV SHIRWAL GAO SHEDDABLE URBAN
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
24	.8676
Max	.8676
Min	.8676
Avg	.8676

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
KHANDALA S/DN.[819] BU 4819
Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV
Feeder No / Name : 305 / 22 KV LAWKIM EXPRESS
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
24	.8299
Max	.8299
Min	.8299
Avg	.8299

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
KHANDALA S/DN.[819] BU 4819
Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV
Feeder No / Name : 306 / 22 KV BHADE AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17
HR	Load (MW)
24	.3772
Max	.3772
Min	.3772
Avg	.3772

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
KHANDALA S/DN.[819] BU 4819
Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV
Feeder No / Name : 307 / 22 KV JAWALE GAO GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
24	.7545
Max	.7545
Min	.7545
Avg	.7545

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
KHANDALA S/DN.[819] BU 4819
Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV
Feeder No / Name : 308 / 22 KV WATHAR COLONY GAO GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
24	1.1693
Max	1.1693
Min	1.1693
Avg	1.1693

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
KHANDALA S/DN.[819] BU 4819
Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV
Feeder No / Name : 309 / EHV AUXILARY SUPPLY
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
24	.0377
Max	.0377
Min	.0377
Avg	.0377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
KHANDALA S/DN.[819] BU 4819
Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV
Feeder No / Name : 401 / 33 KV SHINDEWADI I/C
Feeder KV- 33 / INCOMING

DATE	01-NOV-17
HR	Load (MW)
24	.0566
Max	.0566
Min	.0566
Avg	.0566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
KHANDALA S/DN.[819] BU 4819
Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV
Feeder No / Name : 402 / 33 KV CAPSUL EXPRESS
Feeder KV- 33 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
24	2.1502
Max	2.1502
Min	2.1502
Avg	2.1502

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
KHANDALA S/DN.[819] BU 4819
Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV
Feeder No / Name : 403 / 33 KV MHAVASHI I/C
Feeder KV- 33 / INCOMING

DATE	01-NOV-17
HR	Load (MW)
24	.0566
Max	.0566
Min	.0566
Avg	.0566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
KHANDALA S/DN.[819] BU 4819
Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV
Feeder No / Name : 404 / 33 KV ASIAN PAINT EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-NOV-17
HR	Load (MW)
24	1.3014
Max	1.3014
Min	1.3014
Avg	1.3014

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
KHANDALA S/DN.[819] BU 4819
Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV
Feeder No / Name : 405 / 33 KV THERMAX EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-NOV-17
HR	Load (MW)
24	.1698
Max	.1698
Min	.1698
Avg	.1698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
KHANDALA S/DN.[819] BU 4819
Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV
Feeder No / Name : 407 / 33 KV DATWYLER PHARMA EXPRESS Feeder KV- 33 / OUTGOING NON SHEDDABLE EXPRESS HV FEEDERS (CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-NOV-17
HR	Load (MW)
24	.4527
Max	.4527
Min	.4527
Avg	.4527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
KHANDALA S/DN.[819] BU 4819
Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV
Feeder No / Name : 408 / 33 KV FINOLEX EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-NOV-17
HR	Load (MW)
24	.1698
Max	.1698
Min	.1698
Avg	.1698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
KHANDALA S/DN.[819] BU 4819
Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV
Feeder No / Name : 409 / 33 KV KSB EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-NOV-17
HR	Load (MW)
24	.5658
Max	.5658
Min	.5658
Avg	.5658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
KHANDALA S/DN.[819] BU 4819
Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV
Feeder No / Name : 709 / 132/11 KV NIPRO EHV EXPRESS Feeder KV- 132 / OUTGOING NON SHEDDABLE EHV INDUSTRIAL FEEDERS (CONTINOUS PROCESS)(NO STAGGERING

DATE	01-NOV-17
HR	Load (MW)
24	2.2634
Max	2.2634
Min	2.2634
Avg	2.2634

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
LONAND[115] **BU 5983**
Substation No/ Name :- 253003 / 22 KV MIDC SWITCHING STATION
Feeder No / Name : 301 / 22 KV MUKUND EXPRESS **NON SHEDDABLE EXPRESS HV FEEDERS**
Feeder KV- 22 / OUTGOING **(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	01-NOV-17	02-NOV-17	03-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4108	.3772	.5281
2	.4108	.415	.4527
3	.3734	.4904	.4527
4	.3734	.3772	.4527
5	.2561	.4527	.5281
6	.3734	.3772	.5658
7	.2149	.3772	.3395
8	.2957	.5281	.415
9	.2987	.5281	.4904
10	.3395	.415	.3361
11	.3018	.5975	
12	.3018	.415	
13	.3395	.415	
14	.2641	.4527	
15	.415	.3395	
16	.2641	.3395	
17	.2641	.2641	
18		.3395	
19	.3395	.3772	
20	.3018	.3395	
21	.2641	.4904	
22	.4527	.5658	
23	.3772	.5281	
24	.8002	.415	.5281
Max	**.8002**	**.5975**	**.5658**
Min	**.2149**	**.2641**	**.3361**
Avg	**.3492**	**.4257**	**.4627**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
LONAND[115] BU 5983
Substation No/ Name :- 253003 / 22 KV MIDC SWITCHING STATION
Feeder No / Name : 302 / 22 KV ANDHURI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.7357	3.6054	.2926	.2987	.3395	4.3724	5.168
2	3.8013	3.637	.2561	.2987	.3395	4.34	5.0926
3	3.8013	3.7769	.2987	.2987	.3395	4.3724	5.168
4	3.9323	3.8089	.2926	.3361	.3395	4.4696	5.2812
5	4.0634	4.0486	.3696	.3734	.3395	4.6533	5.4698
6	4.4239	4.3583	.4024	.3734	.4527	4.8171	5.7339
7	4.9726	4.1289	.4527	.4481	.5281	5.6687	6.4883
8	5.0389	4.7188	.3658	.4108	.4527	5.2378	6.5638
9	.3361	.2987	4.4566	5.0793	6.6015	.3018	.3018
10	.3018	.2926	5.9339	7.2805	6.8621	.0377	.2926
11	.3018	.2561	6.0665	7.9218	7.492	.0377	.2957
12	.2641	.2195	6.166	8.1104	7.4257	.0366	.3018
13	.2641	.2561	6.4312	7.8841	6.9616	.0366	.2641
14	.2241		6.0665	7.9595	7.0942	.2926	.2641
15	.2241	.1829	6.2654	8.1859	6.3573	.2561	.2641
16	.2641	.2561	5.7019	7.5823	6.4228	.2926	.2641
17	.2263	.2926	.2614	.2641	.2987	.3395	.2641
18		.2926	.2987	.415	.4527	.3395	.3361
19	.415	.4024	.4481	.4527	.4904	.4904	.4481
20	.4527	.4024	.4108	.415	.4527	.5658	.4481
21	.3772	.3658	.2561	.415	.415	.4527	.4481
22	.3772	.3292	.3361	.3772	.3772	.3772	.3734
23	.3772	.3018	.3326	.3772	.3772	.3395	.3734
24	.3361	.3395	.2926	.2987	.3395	.3772	.3395
Max	**5.0389**	**4.7188**	**6.4312**	**8.1859**	**7.492**	**5.6687**	**6.5638**
Min	**.2241**	**.1829**	**.2561**	**.2641**	**.2987**	**.0366**	**.2641**
Avg	**1.6744**	**1.5900**	**2.1856**	**2.7440**	**2.5647**	**1.7710**	**2.0935**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
LONAND[115] BU 5983
Substation No/ Name :- 253003 / 22 KV MIDC SWITCHING STATION
Feeder No / Name : 303 / 22 KV LONAND MIDC SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7177	1.2803	1.5089	1.4937	1.8107	1.6804	1.7353
2	1.5684	1.3169	1.5844	1.3817	1.9616	1.5565	1.773
3	1.4937	1.3535	1.4335	1.419	1.9239	1.6461	1.6975
4	1.419	1.3169	1.3203	1.4937	1.9616	1.5729	1.7353
5	1.3443	1.2308	1.4335	1.5684	2.037	1.5203	1.7353
6	1.531	1.2536	1.4335	1.531	1.5844	1.5203	1.6975
7	1.2323	1.2536	1.358	1.4937	1.4335	1.5729	1.6975
8	1.1576	1.448	1.5844	1.4937	1.4335	1.9993	1.8107
9	1.419	2.037	1.6263	1.9418	1.6221	1.5524	1.8484
10	1.6598	1.9993	1.8298	1.773	1.4118	2.3765	1.9616
11	1.773	2.1125	1.7551	2.1125	1.4842	2.2634	1.9993
12	1.6975	2.037	1.643	2.1502	1.4842	2.3011	1.9239
13	1.6598	1.9239	1.7177	2.1125	1.6095	2.1879	1.8107
14	1.6598	2.0119	1.5684	2.1125	1.7551	2.2634	2.2257
15	1.5844	2.1068	1.6057	2.1879	1.5729	2.1879	2.1879
16	1.531	1.5844	1.6804	1.9993	1.448	2.2634	2.0748
17	1.4712	1.358	1.6804	1.9616	1.5565	2.1125	1.9239
18		1.5684	1.7177	1.8484	1.4415	2.0748	2.0911
19	1.307	1.3957	1.6057	1.9616	1.4632	2.1879	1.9418
20	1.2323	1.4335	1.6057	1.8107	1.3032	1.9993	1.9418
21	1.2197	1.5466	1.4563	1.8484	1.3756	1.8861	1.7551
22	1.3443	1.4335	1.3817	1.8107	1.448	1.8107	1.643
23	1.4712	1.4335	1.419	1.8107	1.5729	1.7353	1.5684
24	1.7551	1.5466	1.4045	1.4563	1.7353	1.6804	1.7353
Max	**1.773**	**2.1125**	**1.8298**	**2.1879**	**2.037**	**2.3765**	**2.2257**
Min	**1.1576**	**1.2308**	**1.3203**	**1.3817**	**1.3032**	**1.5203**	**1.5684**
Avg	**1.4891**	**1.5826**	**1.5564**	**1.7822**	**1.6013**	**1.9147**	**1.8548**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
LONAND[115] BU 5983
Substation No/ Name :- 253003 / 22 KV MIDC SWITCHING STATION
Feeder No / Name : 304 / 22 KV KHED GAOTHAN GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.415	.3292	.3734	.3395	.415	.3772
2	.3734	.4108	.3361	.3734	.3395	.415	.3772
3	.4481	.4481	.3734	.3734	.3772	.415	.3772
4	.4481	.4904	.3696	.4481	.415	.4527	.415
5	.5975	.6413	.5601	.6722	.5658	.5658	.7167
6	.7842	.9054	.7762	.8215	.8299	.8676	.8299
7	1.0082	1.0185	.8779	1.0082	.9431	1.0562	1.0562
8	.7842	.8299	.6653	.8215	.9054	.8299	.8299
9	.6722	.6413	.5281	.6722	.679	.679	.5658
10	.5658	.5175	.4481	.5281	.5658	.5281	.4066
11	.4527	.4435	.3326	.4904		.4435	.3658
12	.415	.415	.4108	.4527	.415	.4527	.3772
13	.3395	.3696	.3734	.415	.4527	.3772	.3772
14	.3772	.3696	.4108	.415	.4904	.4066	.3696
15	.415	.4066	.3361	.3772	.4527	.4435	.3772
16	.415	.2957	.4108	.4527	.4904		.3772
17	.4904	.4435	.4481	.4904	.5281	.4805	.415
18		.5658	.5228	.679	.6036	.6036	.5975
19	.8299	.7392	.8589	.8299	.8676	.8299	.8962
20	.7545	.7023	.7468	.7922	.7167	.7922	.8215
21	.679	.5544	.6722	.6413	.679	.679	.6722
22	.5658	.4527	.5228	.4904	.5658	.4904	.5228
23	.4904	.3696	.4481	.415	.4527	.415	.3658
24	.3734	.4527	.3326	.3734	.3395	.415	.3772
Max	**1.0082**	**1.0185**	**.8779**	**1.0082**	**.9431**	**1.0562**	**1.0562**
Min	**.3395**	**.2957**	**.3292**	**.3734**	**.3395**	**.3772**	**.3658**
Avg	**.5501**	**.5374**	**.5038**	**.5586**	**.5658**	**.5675**	**.5360**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
LONAND[115] **BU 5983**
Substation No/ Name :- 258003 / 220/132 KV LONAND
Feeder No / Name : 300 / Auxilliary Supply
Feeder KV- 0 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
24	.0377
Max	.0377
Min	.0377
Avg	.0377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
LONAND[115] **BU 5983**
Substation No/ Name :- 258003 / 220/132 KV LONAND
Feeder No / Name : 301 / 22 KV PADEGAON GAOTHAN **GAOTHAN FEEDER**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
24	.4527
Max	.4527
Min	.4527
Avg	.4527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
LONAND[115] **BU 5983**
Substation No/ Name :- 258003 / 220/132 KV LONAND
Feeder No / Name : 302 / 22KV LONAND URBAN **SHEDDABLE URBAN**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
24	1.2003
Max	1.2003
Min	1.2003
Avg	1.2003

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
LONAND[115] **BU 5983**
Substation No/ Name :- 258003 / 220/132 KV LONAND
Feeder No / Name : 303 / 22KV TARADGAON AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 22 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17
HR	Load (MW)
24	.3772
Max	.3772
Min	.3772
Avg	.3772

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
LONAND[115] **BU 5983**
Substation No/ Name :- 258003 / 220/132 KV LONAND
Feeder No / Name : 304 / 22 KV TAMBAVE AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 22 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17
HR	Load (MW)
24	.3086
Max	.3086
Min	.3086
Avg	.3086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
LONAND[115] **BU 5983**
Substation No/ Name :- 258003 / 220/132 KV LONAND
Feeder No / Name : 306 / 22/22 Nira switching I/c Feede Feeder KV- 22 / INCOMING

DATE	01-NOV-17
HR	Load (MW)
24	.5487
Max	.5487
Min	.5487
Avg	.5487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
LONAND[115] **BU 5983**
Substation No/ Name :- 258003 / 220/132 KV LONAND
Feeder No / Name : 307 / 22KV TARADGAON GAOTHAN **GAOTHAN FEEDER**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
24	.9602
Max	.9602
Min	.9602
Avg	.9602

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
LONAND[115] **BU 5983**
Substation No/ Name :- 258003 / 220/132 KV LONAND
Feeder No / Name : 308 / MIDC CIRCUIT-I **SHEDDABLE FEEDER HAVING WEEKLY**
Feeder KV- 22 / OUTGOING **STAGGERING (MIDC, EQUIVALENT)**

DATE	01-NOV-17
HR	Load (MW)
24	4.1495
Max	4.1495
Min	4.1495
Avg	4.1495

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
LONAND[115] **BU 5983**
Substation No/ Name :- 258003 / 220/132 KV LONAND
Feeder No / Name : 310 / 22 KV Hingangoan Ag. SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17
HR	Load (MW)
24	.3429
Max	.3429
Min	.3429
Avg	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
LONAND[115] **BU 5983**
Substation No/ Name :- 258003 / 220/132 KV LONAND
Feeder No / Name : 801 / SONA ALLOYS **NON SHEDDABLE EHV INDUSTRIAL FEEDERS**
Feeder KV- 220 / OUTGOING **(CONTINOUS PROCESS)(NO STAGGERING**

DATE	01-NOV-17
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN (U)[114] **BU 5975**
Substation No/ Name :- 254061 / 33/22 KV SOMANTHALI
Feeder No / Name : 301 / 22 KV SOMANTHALI GAVTHAN **GAOTHAN FEEDER**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.5144	.4458	.3086	.6097	.6173	.6173
2	.3772	.5144	.4458	.2401	.6097	.6516	.5487
3	.3772	.5144	.4458	.2401	.5716	.6173	.5144
4	.4115	.5144	.5144	.2743	.6097	.6173	.5144
5	.4115	.5487	.583	.2743	.6097	.6173	.5144
6	.4801	.583	.6173	.3429	.6859	.6173	.3772
7	.4801	.6516	.6859	.4115	.7621	.7202	.6516
8	.3772	.583	.4115	.3772	.724	.6859	.583
9	.4115	.5487	.4458	.5144	.6859	.6859	.6173
10	.2058	.583	.4191	.5487	.6478	.7202	.7202
11	.5144	.583		.5487	.6516	.7621	.4801
12	.5144	.5144	.4954	.6516	.583	.6859	.7202
13	.5144	.4801	.381	.5487	.5487	.6478	.5144
14	.5144	.4801	.3429	.6173	.5144	.6097	.5144
15	.4801		.3429	.5487	.5487	.6097	.583
16	.5144	.4801	.5335	.583	.5487	.6478	.5487
17	.4801	.5144	.4191	.583	.583	.6097	.5144
18	.4801	.6859	.4191	.6173	.6173	.5335	.724
19		.7545	.4115	.8002	.6173	.583	
20		.6516	.4115	.7621	.7202	.6516	.7621
21		.6516	.583	.8002	.7545	.6859	.8002
22		.583	.5487		.7202	.6859	.7621
23	.583	.5487	.3429	.6859	.583	.6173	.6859
24	.4115	.5144	.5144	.3086	.6097	.6516	.5487
Max	**.583**	**.7545**	**.6859**	**.8002**	**.7621**	**.7621**	**.8002**
Min	**.2058**	**.4801**	**.3429**	**.2401**	**.5144**	**.5335**	**.3772**
Avg	**.4458**	**.5651**	**.4678**	**.5038**	**.6299**	**.6472**	**.6007**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN (U)[114] **BU 5975**
Substation No/ Name :- 254061 / 33/22 KV SOMANTHALI
Feeder No / Name : 302 / 22 KV KAMBALESHWAR **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 22 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4746	1.4403	.1715	.2058	.1905	1.8176	1.6461
2	1.4746	1.4403	.1715	.1715	.1905	1.8176	1.6461
3	1.6118	1.4403	.1715	.1715	.1905	1.8176	1.6461
4	1.7147	1.4403	.2743	.2058	.2286	1.8861	1.6804
5	1.7833	1.5775	.3429	.2743	.2667	1.989	1.7833
6	1.8861	1.8176	.4115	.3429	.381	2.1605	
7	1.9204	2.1262	.4115	.3772	.4191	2.4691	2.1948
8	2.0576	2.1948	.0686	.3429	.381	2.4006	2.332
9	.2058	.2058	1.989	2.2634	2.3243	.2058	.2058
10	.2058	.2058	2.6292	2.7092	3.1626	.2058	.2058
11	.2058	.2058	3.0102	2.6749	2.915	.1905	
12	.1372	.1715	3.0483	2.8464	2.2291	.1905	.1715
13	.1372	.1715	3.0483	2.8464	2.7435	.1905	.1715
14	.1372	.1372	3.0102	2.6406	2.7435		.1715
15	.1372	.1715	2.934	2.7435	2.8121		.2058
16	.1715	.1715	3.0483	2.7435	2.6406	.2286	.2058
17	.1715	.2058	.1905	.1715	.1715	.2286	.2058
18	.2401	.2743	.2286	.2743	.2743	.3048	.2667
19		.3429	.3429	.381	.3429	.3772	
20		.0686	.3429	.3429	.3086	.3429	.381
21		.3086	.2743	.3048	.2743	.2743	.3429
22		.2058	.2401	.2667	.2401	.2401	.2667
23	.1715	.2058	.2058	.2286	.1715	.2058	.2667
24	.1715	.1715	.1715	.2058	.1905	.1715	.1715
Max	**2.0576**	**2.1948**	**3.0483**	**2.8464**	**3.1626**	**2.4691**	**2.332**
Min	**.1372**	**.0686**	**.0686**	**.1715**	**.1715**	**.1715**	**.1715**
Avg	**.8008**	**.6959**	**1.1141**	**1.0723**	**1.0747**	**.8961**	**.7699**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN (U)[114] **BU 5975**
Substation No/ Name :- 254061 / 33/22 KV SOMANTHALI
Feeder No / Name : 303 / 22 KV SASTEWADI **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 22 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.3086	.9602	1.3032	1.448	.2743	.2743
2	.2743	.3086	1.2346	1.2346	1.448	.2743	.2743
3	.2743	.3086	1.6461	1.166	1.448	.2743	.2743
4	.3429	.3429	2.0576	1.2346	1.5242	.2743	.2743
5	.4801	.4115	2.1948	1.4403	1.7528	.4115	.3429
6	.5487	.5487	2.4691	1.7833	2.2481	.5487	.5144
7	.583	.6173	2.6063	2.5377	3.0483	.5487	.583
8	.5144	.5144	2.0576	2.8464	3.3532	.5144	.4801
9	2.2977	1.5432	.3772	.3086	.4191	2.4006	2.6406
10	2.8121	1.3717	.4191	.3429	.3429	3.2236	3.4294
11	2.7778	2.1262	.3429	.3086	.3086	4.0009	3.7723
12	2.9835	.8573	.3048	.2743	.3429	4.1914	3.9095
13	2.9492	2.8807	.3048	.3086	.2743	4.2295	3.7723
14	2.9492	3.2579	.3048	.2743	.3086	4.039	3.7723
15	3.0521	3.0864	.3048	.2743	.2401	4.2295	3.7037
16	2.915	3.0864	.3048	.2401	.3429	4.2295	3.5322
17	.3086		.381		.4115	.3048	.3086
18	.4115	.5144	.4572		.4115	.4191	.4572
19		.583	.583	.6478	.5487	.583	
20		.5487	.5487	.6097	.5144	.583	.6097
21		.4801	.4801	.5335	.4801	.4801	.5335
22		.3429	.3772	.4191	.4115	.3772	.4572
23	.3429	.3086	.3429	.3429	.1715	.3086	.381
24	.3086	.3086	.3086	.2743	.3048	.2743	.3086
Max	**3.0521**	**3.2579**	**2.6063**	**2.8464**	**3.3532**	**4.2295**	**3.9095**
Min	**.2743**	**.3086**	**.3048**	**.2401**	**.1715**	**.2743**	**.2743**
Avg	**1.3700**	**1.0720**	**.8903**	**.8502**	**.921**	**1.5414**	**1.5046**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN (U)[114] **BU 5975**
Substation No/ Name :- 254061 / 33/22 KV SOMANTHALI
Feeder No / Name : 304 / 22 KV SANGAVI **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 22 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2346	.2058	.1372	.1524	1.3032	1.2346
2		1.2346	.1372	.1372	.1524	1.3032	1.2346
3		1.2346	.1372	.1372	.1905	1.3032	1.3032
4		1.2346	.2058	.2058	.1905	1.4403	1.4403
5		1.3717	.2743	.3429	.2667	1.5775	1.6461
6		1.7833	.4115	.4115	.4191	1.9204	1.9204
7		2.2634	.4801	.4801	.5335	2.4006	2.4691
8	2.1948	2.2977	.4115	.4801	.4572	2.5377	2.5377
9	.2743	.2743	1.7833	2.0576	2.3624	.2743	.3429
10	.2058	.2401	2.5911	2.7435	3.0483	.2401	.2058
11	.2743	.2058	2.934	2.9492	3.0178	.2286	.2058
12	.2058	.2058	2.8959	3.0864	3.0864	.1905	.2058
13	.2058	.1372	3.0483	2.1262	2.4691	.1524	.2058
14	.1372	.1372	3.0864	2.7435	2.7435	.1524	.1372
15	.1372	.1372	3.2388	2.8121	2.7435	.1905	
16	.0343	.2058	3.2007	2.1262	2.332	.2286	
17	.2058	.2058	.2286		.2743	.2667	
18	.2743	.3429	.3429	.3429	.2743	.2667	.4954
19		.3429	.3429	.4572	.3429	.4115	
20		.0686	.3429	.3429	.3086	.3429	.4572
21		.2743	.2743	.2667	.2743	.2743	.3429
22		.2058	.2058	.2286	.2058	.2058	.3048
23	.2058	.2058	.2058	.1524	.1715	.2058	.2286
24	.2058	.2058	.2058	.2058	.1524	.1715	.2058
Max	**2.1948**	**2.2977**	**3.2388**	**3.0864**	**3.0864**	**2.5377**	**2.5377**
Min	**.0343**	**.0686**	**.1372**	**.1372**	**.1524**	**.1524**	**.1372**
Avg	**.3509**	**.6687**	**1.1330**	**1.0858**	**1.0904**	**.7329**	**.8562**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN (U)[114] **BU 5975**
Substation No/ Name :- 254061 / 33/22 KV SOMANTHALI
Feeder No / Name : 305 / 22 KV SOMANTHALI AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 22 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	.2058	.823	.9602	.9526	.2401	.2058
2	1.166	.2058	.9602	.9602	.9526	.2401	.2743
3	1.3032	.2058	1.3032	.9602	.9907	.2401	.2743
4	1.4403	.2743	1.4403	1.0974	1.0669	.2743	.2743
5	1.6461	.3429	1.7147	1.2346	1.2193	.3429	.3429
6	1.7147	.4458	1.8519	1.4403	1.6004	.4458	.4801
7	1.8519	.5487	1.989	1.8519	2.0576	.5144	.4801
8	.4801	.4801	1.9204	2.0576	2.0957	.5144	.4801
9	1.7147	1.5775	.3429	.3429	.4191	1.4403	1.6461
10	2.0576	1.989	.381	.3429	.3429	1.989	1.8519
11	1.9204	2.0576		.3086	.2743	2.1338	2.0576
12	2.0576	2.0576	.2667	.2401	.2743	2.2481	2.0576
13	2.0576	.2743	.2667	.1372	.2058	2.3624	1.7833
14	1.3717		.3048	.2401	.2058	2.2862	1.7833
15	1.8519		.2667	.2401	.2743	2.3243	1.8519
16	1.9204	1.7833	.3429	.2401	.2743	2.3243	1.8519
17	.2743	.2743	.3429	.3086	.2743	.3048	.2743
18	.3429	.4801	.4572	.3772	.3429	.4191	.381
19		.4115	.4801	.4954	.4458	.4801	
20		.4115	.4801		.4115	.4801	.4572
21		.3429	.4115	.3429	.3429	.3429	.381
22		.2743	.3429	.2667	.3086	.2743	.3048
23	.2401	.2058	.2743	.2286	.2401	.2058	.2667
24	.2743	.2058	.2058	.2743	.1905	.2401	.2058
Max	**2.0576**	**2.0576**	**1.989**	**2.0576**	**2.0957**	**2.3624**	**2.0576**
Min	**.2401**	**.2058**	**.2058**	**.1372**	**.1905**	**.2058**	**.2058**
Avg	**1.3392**	**.6843**	**.7465**	**.6499**	**.6568**	**.9445**	**.8681**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN (U)[114] **BU 5975**
Substation No/ Name :- 254061 / 33/22 KV SOMANTHALI
Feeder No / Name : 306 / 22 KV somawar peth **SHEDDABLE URBAN**
Feeder KV- 22 / OUTGOING

DATE	02-NOV-17	03-NOV-17	04-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)
10		.0762	
12		.0381	
18	.2743		
19			.0381
23			.0381
Max	.2743	.0762	.0381
Min	.2743	.0381	.0381
Avg	.2743	.0572	.0381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN (U)[114] **BU 5975**
Substation No/ Name :- 254061 / 33/22 KV SOMANTHALI
Feeder No / Name : 401 / 33KV Maharashtra Food **NON SHEDDABLE EXPRESS HV FEEDERS**
Feeder KV- 33 / OUTGOING **(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2058	.3601	.1029	.3429	.3086	.3086
2	.2572	.2572	.3601	.1029	.3429	.3086	.3086
3	.2572	.2572	.3601	.1029	.3429	.3086	.2572
4	.1543	.2058	.3601	.1029	.3429	.2572	.2572
5	.1543	.2058	.3086	.1029	.3429	.2058	.3086
6	.1543	.2572	.3086	.1029	.2858	.2058	.2058
7	.1543	.1543	.3086	.1029	.1715	.1543	.1543
8	.1029	.2058	.2572	.1029	.2286	.3086	.1543
9	.2058	.1543	.2572	.3086	.3429	.3086	.2572
10	.1543	.2572	.3429	.1543	.2286	.3086	.2058
11	.2058	.2572	.2858	.1543	.3086	.2286	.1543
12	.1543	.3601	.2858	.2058	.3086	.2286	.2058
13	.2058	.2058	.1143	.2572	.2058	.1143	.1543
14	.1543	.1543	.1143	.1543	.3086	.1715	.1543
15	.2572	.2058	.1143	.1543	.3086	.1143	.1543
16	.2572	.4115	.3429	.2058	.2572	.1715	.2058
17	.1543	.2572	.1143	.3086	.2572	.3429	.2058
18	.2058	.2058	.1143	.2829	.2058	.1715	.1715
19		.2572	.1029	.2858	.2058	.1543	
20		.2572	.1029	.1715	.1543	.3086	.2858
21		.2572	.1543	.1715	.2572	.2058	.1715
22		.2058	.2572	.4001	.1543	.3601	.4001
23	.3086	.3086	.1029	.4001	.2572	.4115	.3429
24	.2058	.2058	.3601	.1029	.4001	.2572	.3086
Max	**.3086**	**.4115**	**.3601**	**.4001**	**.4001**	**.4115**	**.4001**
Min	**.1029**	**.1543**	**.1029**	**.1029**	**.1543**	**.1143**	**.1543**
Avg	**.1955**	**.2379**	**.2412**	**.1892**	**.2734**	**.2465**	**.2319**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] **BU 5967**
Substation No/ Name :- 254043 / SURAWADI
Feeder No / Name : 301 / SAKHARWADI AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 22 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17
HR	Load (MW)
23	.4115
24	2.6749
Max	2.6749
Min	.4115
Avg	1.5432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] **BU 5967**
Substation No/ Name :- 254043 / SURAWADI
Feeder No / Name : 303 / NIMBHORE AG FEEDER **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 22 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17
HR	Load (MW)
24	3.2922
Max	3.2922
Min	3.2922
Avg	3.2922

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] **BU 5967**
Substation No/ Name :- 254043 / SURAWADI
Feeder No / Name : 304 / WATHAR -NIMBLAK- AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17
HR	Load (MW)
24	2.2291
Max	2.2291
Min	2.2291
Avg	2.2291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] BU 5967
Substation No/ Name :- 254043 / SURAWADI
Feeder No / Name : 305 / SWARAJ EXPRESS **NON SHEDDABLE EXPRESS HV FEEDERS**
Feeder KV- 22 / OUTGOING **(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.5716	.5335	.5335	.6097	.4954	.5716
2	.6859	.724	.5335	.4572	.6097	.4954	.6859
3	.6097	.6859	.5716	.3048	.6859	.5335	.6097
4	.5144	.4191	.5335	.2667	.6859	.5335	
5	.5335	.3048	.4954	.2667	.724	.5716	
6	.5487	.2667	.4954	.2667	.7621	.5716	
7	.6097	.2667	.4572	.3048	.6859	.6478	
8	.6097	.381	.381	.3048	.724	.6478	
9	.4572	.2667	.6097	.381	.6859	.724	
10	.6097	.4954	.6478	.4572	.7621	.6478	
11	.6859	.6097	.6478	.5335	.8002	.8764	
12	.8383	.6097	.5716	.4572	.7621	.8764	
13	.9145	.724	.724	.381	.7621	.8764	
14	.8002	.8002	.6478	.6859	.7621	.8383	
15	.8002	1.1431	.6478	.8383	.4191	.8383	
16	.9145	.8002	.6859	.8002	.4191	.8383	
17	.8002	.6859	.6478	.8764	.381	.8002	
18	.8002	.5716	.8002	.7621	.2667	.6097	
19	.8002	.6097	.7621	.724	.3048	.6478	
20	.6478	.5716	.8002	.7621	.4191	.381	
21	.7621	.8383	.7621	.6859	.4572	.3048	
22	.7621	.7621	.724	.6097	.4572	.2286	
23	.7621	.5716	.7621	.6097	.4954	.2667	
24	.724	.5716		.6097	.6859	.4954	.2667
Max	**.9145**	**1.1431**	**.8002**	**.8764**	**.8002**	**.8764**	**.6859**
Min	**.4572**	**.2667**	**.381**	**.2667**	**.2667**	**.2286**	**.2667**
Avg	**.7032**	**.5938**	**.6279**	**.5366**	**.5970**	**.6144**	**.5335**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] BU 5967
Substation No/ Name :- 254043 / SURAWADI
Feeder No / Name : 307 / 22 KV SAKHARWADI GAOTHAN GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.5716	.6097	.5487	.6097	.5716	.6859
2	.6097	.5335	.5335	.4801	.6097	.6097	.5716
3	.6478	.6097	.5335	.4801	.5716	.6859	.6097
4	.724	.724	.5716	.5144	.6859	.6859	.6097
5	.8383	.9145	.6859	.6516	.8383	.8002	.8002
6	1.0288	1.2955	.8383	.9259	1.0669	.9526	1.0288
7	1.1431	1.2955	1.0669	1.0631	1.1812	1.0288	1.2193
8	.9145	1.1812	.8002	.9259	1.105	.9907	1.2574
9	.8764	.8916	.6859	.9907	.9907	.9526	.8916
10	.8002	.823	.5487	.9526	.9907	.8383	.8916
11	.8383	.6516	.6516	.8764	.9145	.724	.823
12	.724	.7202	.583	.724	.8383	.8383	.6859
13	.6097	.583	.5487	.8002	.7621	.6859	.6173
14	.6478	.583	.583	.7621	.7621	.6859	.6859
15	.6478	.5144		.8002	.8383	.7621	.6859
16	.8002	.5487	.5144	.8002	.8764	.8383	.4458
17	.9907	.6859	.6859	.9526	.9145	.8002	.823
18	1.0669	.7888	.8573	1.0669	1.105	.9907	.8573
19	1.3717	1.0288	1.0974	1.2193	1.2193	1.1812	1.0631
20	1.2193	1.0288	.9602	1.0669	1.1431	1.0669	.9945
21	1.1431	1.0669	.9259	1.1431	1.0288	1.0288	.9602
22	1.0288	.9526	.8573	.9907	.9145	1.0288	.9602
23	.724	.8383	.6516	.8002	.8002	.8764	.7888
24	1.0562	.6097	.724	.6516	.6859	.5716	.8002
Max	**1.3717**	**1.2955**	**1.0974**	**1.2193**	**1.2193**	**1.1812**	**1.2574**
Min	**.6097**	**.5144**	**.5144**	**.4801**	**.5716**	**.5716**	**.4458**
Avg	**.8775**	**.8100**	**.7180**	**.8411**	**.8939**	**.8415**	**.8232**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] BU 5967
Substation No/ Name :- 254043 / SURAWADI
Feeder No / Name : 308 / 22 KV NANDAL GAONTHAN GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
24	1.8107
Max	1.8107
Min	1.8107
Avg	1.8107

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] BU 5967
Substation No/ Name :- 254043 / SURAWADI
Feeder No / Name : 309 / 22 KV NIMBHORE GAONTHAN GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
24	3.2065
Max	3.2065
Min	3.2065
Avg	3.2065

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] BU 5967
Substation No/ Name :- 254043 / SURAWADI
Feeder No / Name : 403 / cummines india limited NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	.3429	.3429	.4001	.3429	.2286	.2858
2	.4001	.3429	.3429	.3429	.3429	.2286	.3429
3	.4001	.3429	.3429	.3429	.3429	.2286	.3429
4	.4001	.3429	.3429	.3429	.3429	.2858	.2858
5	.4001	.3429	.3429	.4001	.3429	.3429	.2858
6	.4001	.4572	.4572	.4572	.3429	.4572	.3429
7	.4572	.5144	.5716	.6287	.3429	.4001	.4572
8	.5144	.5144	.5144	.5716	.3429	.4572	.4572
9	.6287	.6287	.5716	.5716	.3429	.5716	.6287
10	.8002	.6859	.6287	.743	.3429	.6859	.8002
11	.743	.8002	.8002	.8573	.3429	.6859	.6859
12	.6859	.743	.743	.743	.3429	.6287	.6859
13	.743	.8002	.9145	.6287	.3429	.5716	.6859
14	.743	.743	.743	.743	.2858	.6859	.6859
15	.6859	.8002		.6859	.2858	.6287	.743
16	.6859	.8002	.743	.8002	.2858	.743	.6287
17	.6859	.743	.743	.6859	.2858	.6859	.5716
18	.5716	.6287	.5716	.6287	.2858	.4001	.6859
19	.5144	.6287	.6859	.6859	.2858	.5716	.5716
20	.4001	.6287	.6287	.5716	.2858	.4572	.5144
21	.4572	.5716	.5144	.6859	.2858	.5144	.5144
22	.4572	.4572	.4572	.5144	.2286	.4572	.5144
23	.4001	.4001	.4001	.4001	.2286	.2858	.4001
24	.4572	.4001	.4001	.4001	.4001	.2286	.3429
Max	**.8002**	**.8002**	**.9145**	**.8573**	**.4001**	**.743**	**.8002**
Min	**.4001**	**.3429**	**.3429**	**.3429**	**.2286**	**.2286**	**.2858**
Avg	**.5430**	**.5692**	**.5566**	**.5763**	**.3167**	**.4763**	**.5192**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] BU 5967
Substation No/ Name :- 254043 / SURAWADI
Feeder No / Name : 404 / tata cumines ltd **NON SHEDDABLE EXPRESS HV FEEDERS**
Feeder KV- 33 / OUTGOING **(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.8002	1.0288	1.2003	1.2574	.2286	1.2574
2	.6859	.8573	1.0288	1.0288	1.086	.2286	1.1431
3	.743	.8573	.9717	1.0288	1.086	.2286	1.3146
4	.6859	.8002	.9145	1.2003	1.0288	.2286	1.2574
5	.6859	.8573	1.1431	1.3146	1.0288	.3429	1.3717
6	.8002	1.2003	1.2574	1.3146	1.0288	1.0288	1.2003
7	.9717	1.2574	1.3717	1.4861	.8573	1.2574	1.2003
8	.8573	1.3717	1.3146	1.2574	.8002	1.2003	1.2003
9	.9145	1.7718	1.4289	1.3146	.8573	1.1431	1.1431
10	.8573	1.6004	1.2574	1.3717	.8573	1.5432	1.6575
11	1.1431	1.6004	1.6004	1.5432	.8573	1.6004	1.6575
12	1.3717	1.6575	1.6004	1.6004	.9717	1.6575	1.6575
13	1.3146	1.6004	1.6004	1.6004	1.1431	1.4861	1.6575
14	1.3717	1.6004	1.7147	1.4861	.4001	1.4861	1.7147
15	1.3717	1.6004		1.7147	.743	1.6575	1.7147
16	1.4289	1.6575	1.6575	1.6575	.8002	1.6004	1.6004
17	1.3717	1.6004	1.6575	1.4861	.9717	1.6575	1.6004
18	1.3717	1.5432	1.7147	1.6004	.8002	1.6575	1.6575
19	1.2003	1.6004	1.7147	1.5432	.5144	1.6575	1.6004
20	1.086	1.6575	1.7147	1.4861	.5144	1.6004	1.6004
21	.9145	1.6575	1.6575	1.5432	.4001	1.5432	1.6004
22	.8573	1.4861	1.2574	1.4289	.2858	1.6004	1.6575
23	.9145	1.2574	1.3717	1.2003	.2858	1.6004	1.4861
24	.743	.8573	1.2003	1.3146	1.3146	.2286	1.086
Max	**1.4289**	**1.7718**	**1.7147**	**1.7147**	**1.3146**	**1.6575**	**1.7147**
Min	**.6859**	**.8002**	**.9145**	**1.0288**	**.2858**	**.2286**	**1.086**
Avg	**1.0145**	**1.3646**	**1.3991**	**1.4051**	**.8288**	**1.1860**	**1.4599**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] **BU 5967**
Substation No/ Name :- 254046 / 33/22 KV BARAD
Feeder No / Name : 301 / 22KV BARAD AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 22 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4335	1.4335	.1886	.1886	.2263	1.2826	1.5089
2	1.5844	1.5089	.1886	.1886	.2263	1.2449	1.5089
3	1.8107	1.6975	.1886	.1886	.2263	1.2449	1.8484
4	1.9616	1.9993	.1509	.2263	.2641	1.5466	2.1125
5	2.4143	2.2634	.2263	.2641	.2641	1.9616	2.3765
6	2.6406	2.5652	.2263	.2641	.3395	2.2634	2.9047
7	3.2819	3.0556	.3018	.3018	.415	2.7915	3.3196
8	2.5652	2.5274	.2263	.2641	.3018	2.452	2.7161
9	.1886	.2641	2.0748	2.0748	1.1317	.2263	.1886
10	.2263	.1886	3.0556	2.9424	3.546	.1886	.1886
11	.1886	.1509		2.5652	3.6969	.1509	.1886
12	.1886	.1509	1.6221	3.8477	3.3573	.1886	.1886
13	.1886	.1886	2.2634	3.9986	3.7723	.1509	.1509
14	.1886	.1886	1.2826	3.6969	3.81	.1509	.1509
15	.1886	.1886	3.5082	3.9609	3.81	.1509	.1509
16	.1509	.1886	3.6214	3.81	3.4328	.1509	.1509
17	.1886	.1886	.1132	.1509	.1886	.1886	.1886
18	.3395	.2263	.1509	.3772	.2263	.2263	.3018
19	.3772	.3018	.3018	.415	.3395	.2263	.415
20	.3395		.3018	.415	.3395	.2263	.3772
21	.3395	.3018	.2641	.3395	.3018	.2263	.3395
22	.3018	.2263	.2263	.3018	.2641	.1886	.3018
23	2.7161	.1886	.1886	.2641	.2641	.1886	.2641
24	2.6406	.2641	.1886	.1886	.2641	.2641	.1886
Max	**3.2819**	**3.0556**	**3.6214**	**3.9986**	**3.81**	**2.7915**	**3.3196**
Min	**.1509**	**.1509**	**.1132**	**.1509**	**.1886**	**.1509**	**.1509**
Avg	**1.1018**	**.8807**	**.9070**	**1.3015**	**1.2920**	**.7450**	**.9179**

 Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] **BU 5967**
Substation No/ Name :- 254046 / 33/22 KV BARAD
Feeder No / Name : 302 / MUNJAWADI AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 22 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0933	3.0556	.415	.3772	.3772	2.8292	2.8669
2	3.1687	3.131	.415	.3772	.3395	2.7915	3.0178
3	3.3573	3.2065	.4527	.3772	.3772	2.7915	3.0933
4	3.4705	3.3196	.4527	.5658	.4904	2.8669	3.3196
5	3.4705		.7167	.679	.6413	3.0933	3.6214
6	1.9616	2.2257	.8299	.8299	.7922	3.3196	3.81
7	3.9986	2.6783	.9431	.9808	.9808	4.1495	4.6022
8	4.9417	2.5652	.7922	.7922	.8299	4.0364	4.3759
9	.6036	.4527	4.1495	4.5268	4.3004	.5281	.5658
10	.5281		5.6207	5.7716	5.9225	.4527	.4904
11	.3772	.4527	5.8471	6.0357	6.1111	.415	.3772
12	.3395	.3772	6.0357	6.1866	4.6399	.3018	.3018
13	.3395	.3395	6.1488	5.8848	4.904	.2641	.3395
14	.3395	.3395	6.1488	5.8848	5.8471	.2641	.3018
15	.3395	.3772	5.8848	5.6962	5.583	.3395	.3395
16	.2641	.415	6.1488	5.4698	5.6584	.3772	.3772
17	.3018	.415	.3772	.3395	.3772	.3772	.4527
18	.6036	.6413	.5658	.5658	.6036	.5658	.5281
19	.7922	.7922	.7922	.8299	.7922	.7167	.7922
20	.679	.679	.679	.7922	.679	.6413	.679
21	.6036		.5658	.6413	.5658	.5658	.6036
22	.5281	.4904	.4527	.4904	.4904	.4527	.415
23	.415	.415	.415	.415	.4527	.3772	.3772
24	5.6584	.415	.415	.3772	.415	.415	.3772
Max	**5.6584**	**3.3196**	**6.1488**	**6.1866**	**6.1111**	**4.1495**	**4.6022**
Min	**.2641**	**.3395**	**.3772**	**.3395**	**.3395**	**.2641**	**.3018**
Avg	**1.6740**	**1.2754**	**2.3027**	**2.2870**	**2.1738**	**1.3722**	**1.5011**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] **BU 5967**
Substation No/ Name :- 254046 / 33/22 KV BARAD
Feeder No / Name : 303 / ANDHRUD AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 22 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.5281	2.2257	1.9239	2.3765	.5658	.6036
2	.5658	.5281	2.2257	1.9239	2.3765	.5658	.5281
3	.6036	.5281	2.2257	1.8861	2.6029	.5658	.5281
4	.679	.6413	2.1879	2.1879	2.8292	.7545	.7167
5	.8299	.7922	2.5274	2.9047	3.2819	.9054	.9431
6	1.094	1.0185	2.8669	3.5082	3.81	1.0562	1.1317
7	1.0562	1.0185	3.2065	4.0741	4.6776	.9808	1.1317
8	.7922	.8299	2.8669	4.225	4.5645	.7922	.8676
9		1.358	.5658	.6036	.679	2.6029	3.8477
10	4.5645	3.5837	.2263	.4904	.6413	2.037	5.2812
11	4.8285	5.3567	.2263	.2641	.415	4.8663	5.4698
12	4.489	5.0549	.2263	.2263	.415	5.6207	5.2812
13		5.3567	.1886	.3395	.415		4.3381
14	5.0172	5.1303			.3772	5.0172	4.8285
15	5.3567	4.6399			.415	5.6962	
16	3.6591	4.8285	.2263	.5658	.3772	2.0748	5.3944
17	.3772	.3018	.2641	.4527	.415	.1886	
18	.7167	.679	.7922	.6413	.5281	.3395	
19	.9431	.9054	.9808	1.0185	.7545	.9808	.9431
20	.7922	.8299	.8676	.8779	.7545	.8676	.8676
21	.7167		.7167	.7167	.679	.7545	.7545
22	.6413	.4904	.6413	.679	.6036	.6413	.6036
23	.5658	.6036	.6036	.6413	.5658	.6413	.5658
24	3.3951	.5658	.5658	.5658	.6036	.5658	.6413
Max	**5.3567**	**5.3567**	**3.2065**	**4.225**	**4.6776**	**5.6962**	**5.4698**
Min	**.3772**	**.3018**	**.1886**	**.2263**	**.3772**	**.1886**	**.5281**
Avg	**1.9204**	**1.9813**	**1.2466**	**1.3962**	**1.4649**	**1.6992**	**2.1556**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] **BU 5967**
Substation No/ Name :- 254046 / 33/22 KV BARAD
Feeder No / Name : 304 / Barad Gaonthan **GAOTHAN FEEDER**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.4904	.4527		.4527	.5281	.4904
2	.4904	.4904	.4527		.415	.5281	.4904
3	.4904	.4904	.4527		.4904	.5281	.6413
4	.5281	.5658	.4904		.5281	.7545	.7545
5	.8299	.7922	.7922		.679	.9054	.9054
6	1.094	1.1317	.9054		1.0185	1.094	1.094
7	1.0562	1.094	1.094		1.1694	1.0562	1.2071
8	.9054	.8676	.9054		.9808	.9054	.8676
9	.679	.7167	.679		.7545	.679	.679
10	.5281	.6413	.6036		.6413	.5658	.5281
11	.4904	.5658	.415		.6036	.4904	.4904
12	.5281	.5281			.5658	.5281	.4527
13	.415	.4527			.5281	.4904	.4527
14	.4904	.3772			.4904	.4527	.415
15	.4904	.4904			.4904	.4904	.3772
16	.4527	.4904			.5658	.5658	.4904
17	.6036	.5658			.5658	.5658	.5281
18		.7545		1.1694	.7545	.7167	.7922
19	.9054	1.0185		1.2071	1.0185	1.0562	.9808
20	1.0562			1.0562	.9054	.9431	.9431
21	.8676	.9054		.8676	.8299	.8676	.8299
22	.7545	.6036		.4904	.679	.7167	.679
23	.6036	.4904		.5658	.6036	.5658	.5658
24	.5281	.5281	.4527		.4904	.5281	.5281
Max	**1.094**	**1.1317**	**1.094**	**1.2071**	**1.1694**	**1.094**	**1.2071**
Min	**.415**	**.3772**	**.415**	**.4904**	**.415**	**.4527**	**.3772**
Avg	**.6643**	**.6544**	**.6413**	**.8928**	**.6759**	**.6884**	**.6743**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] BU 5967
Substation No/ Name :- 254046 / 33/22 KV BARAD
Feeder No / Name : 305 / 22 KV GUNAWARE GAOTHAN GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.4527	.4527	.4527	.4527	.4527	.4527
2	.4527	.4527	.415	.4527	.415	.4527	.4527
3	.4904	.4527	.415	.4527	.4527	.4527	.4527
4	.5281	.5281	.5658	.5658	.5658	.6036	.7167
5	.679	.7545	.8299	.8299	.7545	.8299	.8299
6	.9054	1.0185	.9054	1.0185	.9431	1.0185	.9808
7	1.094	1.094	1.1317	1.1317	1.1694	1.094	1.1694
8	.9431	.8676	.9054	.9431	.9431	.9054	.9431
9	.7545	.7167	.679	.7167	.7922	.679	.7545
10	.6036		.5281	.5658	.6036	.5281	.4904
11	.6413	.5658	.5281	.5281	.5658	.5281	.4904
12	.5658	.4527	.415	.4904	.5281		.4527
13	.4527	.4527	.2641	.3772	.415	.415	.415
14	.3772	.4904	.2263	.3018	.415	.3772	.3772
15	.4527	.4527	.3395	.3395	.4527		.3772
16	.4527	.4527	.415	.415	.415		.4527
17	.6036	.6413	.4904	.5658	.5281	.4904	.5658
18	.8676	.7545	.7545	.7167	.7167	.7167	.7922
19	.9431	.9808	.9431	1.0185	.9431	.9808	.9431
20	.8676	.8299	.8299	.8299	.8676	.8676	.9054
21	.7545	.6413	.7167	.7167	.7167	.7167	.7167
22	.6036	.5658	.5658	.5658	.5658	.5658	.6036
23	.4904	.4904	.5281	.4527	.4904	.4904	.5281
24	.4904	.4904	.4527	.4527	.4527	.4527	.4527
Max	**1.094**	**1.094**	**1.1317**	**1.1317**	**1.1694**	**1.094**	**1.1694**
Min	**.3772**	**.4527**	**.2263**	**.3018**	**.415**	**.3772**	**.3772**
Avg	**.6444**	**.6347**	**.5957**	**.6209**	**.6319**	**.6485**	**.6382**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] BU 5967
Substation No/ Name :- 254046 / 33/22 KV BARAD
Feeder No / Name : 306 / 22 KV RAJURI GAONTHAN GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1509	.1132	.1132	.1132	.1132	.1132
2	.1132	.1509	.1132	.1132	.1132	.1132	.1132
3	.1132	.1509	.1132	.1132	.1132	.1132	.1132
4	.1132	.1509	.1132	.1132	.1509	.1132	.1132
5	.1886	.1886	.1509	.1509	.1886	.1886	.1509
6	.2641	.2641	.1886	.2263	.2641	.2641	.1886
7	.2641	.2641	.2641	.3018	.2641	.2263	.1886
8	.3018	.2263	.2263	.2263	.2641	.1886	.1509
9	.1886	.1509	.1886	.1886	.2263	.1132	.0754
10	.1886	.1509	.1509	.1509	.1886	.1509	.1509
11	.1886	.1509	.1509	.1509	.1886	.1886	.1509
12	.1886	.0377	.1509	.1509	.1886	.1509	.1509
13	.1886	.1132		.1509	.1509	.1132	.1132
14	.1509			.1509	.1509	.0754	.1132
15	.1886	.1132		.1509	.1509	.0754	
16	.1509	.1509	.1509	.1509	.1132	.1132	.1509
17	.1509	.1509		.1509	.1509	.1509	.1886
18	.2263	.1509	.2263	.1886	.1886	.1509	.1886
19	.1886	.1886	.2641	.2263	.1886	.1886	.2641
20	.2263	.1509	.2641	.2263	.1509	.1509	.2641
21	.1886		.2263	.1886	.1509	.1509	.1886
22	.1509	.1509	.1886	.1509	.1509	.1132	.1509
23	.1509	.1509	.1509	.1509	.1132	.1132	.1509
24	.1509	.1509	.1132	.1132	.1132	.1132	.1132
Max	**.3018**	**.2641**	**.2641**	**.3018**	**.2641**	**.2641**	**.2641**
Min	**.1132**	**.0377**	**.1132**	**.1132**	**.1132**	**.0754**	**.0754**
Avg	**.1808**	**.1595**	**.1754**	**.1666**	**.1682**	**.1430**	**.1542**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] **BU 5967**
Substation No/ Name :- 254046 / 33/22 KV BARAD
Feeder No / Name : 307 / 22 KV Nimblak AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 22 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1509	1.358	1.5089	1.6598	.1509	.1132
2	.1886	.1509	1.358	1.5089	1.6598	.1509	.1132
3	.1886	.1132	1.358	1.5089	1.6975	.1509	.1509
4	.1886	.1509	1.3957	1.6598	1.7353	.1509	.1886
5	.2263	.1886	1.5089	1.8107	1.9239	.1886	.1886
6	.2641	.2641	1.6598	1.9239	2.1125	.2641	.2641
7	.3018	.3018	1.8484	2.2634	2.4897	.3018	.3018
8	.2641	.2641	1.9993	2.2257	2.1879	.2641	.2263
9	2.5274	2.1125	.1886	.2263	.1886	2.1125	2.0748
10	2.5652	2.2634	.1886	.1886	.1509	2.9801	2.9047
11	3.0178	2.6406	.1509	.1509	.1132	3.3196	3.2819
12	3.0933	2.4897	.1509	.0377	.1132	3.3573	2.9424
13	2.7538	2.6783	.1509	.0377	.1509	3.1687	3.0178
14	2.6783	2.5652	.1509	.0377	.1132	3.2442	3.0178
15	2.8292	2.6029	.1509	.0377	.1132	3.3196	2.5652
16	2.5274	2.3765	.1509	.0377	.1132	2.9424	2.7161
17	.1509	.1509	.1886	.0377	.1886	.1886	.1132
18	.2263	.1886	.2263	.2641	.2263	.2263	.1886
19	.2641	.2263	.2641	.3018	.3018	.2263	.2263
20	.2263	.1886	.2263	.2263	.2263	.2263	.2263
21	.1886		.1886	.1886	.1886	.1886	.1886
22	.1886	.1509	.1509	.1886	.1509	.1509	.1509
23	.1509	.1509	.1509	.1886	.1509	.1132	.1509
24	3.9609	.1509	.1509	.1132	.1509	.1509	.1132
Max	**3.9609**	**2.6783**	**1.9993**	**2.2634**	**2.4897**	**3.3573**	**3.2819**
Min	**.1509**	**.1132**	**.1509**	**.0377**	**.1132**	**.1132**	**.1132**
Avg	**1.2150**	**.9792**	**.6381**	**.6947**	**.7545**	**1.1474**	**1.0594**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] BU 5967
Substation No/ Name :- 254047 / KAPASHI
Feeder No / Name : 301 / ADARKI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0366	.3772	.3605	.4858	.0686	.0366
2	.0686	.0366	.3772	.426	.5182	.0686	.0366
3	.0686	.0366	.3772	.426	.5182	.0686	.0366
4	.0686	.0366	.4115	.426	.5182	.0686	.0366
5	.0686	.0732	.4458	.4915	.583	.0686	.0732
6	.0686	.0732	.5487	.6226	.6802	.1029	.0732
7	.1029	.1097	.823	1.0159	1.004	.1029	.1097
8	.0686	.1097	.9945	1.1797	1.0688	.1029	.1097
9	.7888	.7888	.0686	.0732	.0648	1.0288	.9175
10	.9503	.9945	.0732	.0732	.0686	1.5089	1.406
11	1.0814	1.1317	.0366	.0366	.0686	1.6712	1.7147
12	1.0814	1.2346	.0732	.0366	.0686	1.278	1.8861
13	1.1142	1.2346	.0366	.0366	.0686	1.5223	1.749
14	1.1797	1.2346	.0732	.0366	.0686	1.749	1.7833
15	1.2452	1.2689	.0732	.0366	.0686	1.6518	1.7833
16	1.2452	1.2689	.0732	.0366	.0686	1.6518	1.749
17	.0732	.0686	.1097	.0732	.0686	.0366	.0686
18	.0732	.0457	.1097	.1097	.0686	.0732	.1029
19	.1097	.1029	.1097	.1097	.1372	.1097	.1372
20	.1097	.1029	.1097	.1097	.1029	.1097	.1029
21	.1097	.0686	.1097	.0732	.1029	.1097	.0686
22	.0732	.0686	.0732	.0732	.1029	.0732	.0686
23	.0732	.0686	.0732	.0732	.0686	.0732	.0686
24	.0686	.0366	.0686	.0366	.0366	.0686	.0366
Max	**1.2452**	**1.2689**	**.9945**	**1.1797**	**1.0688**	**1.749**	**1.8861**
Min	**.0686**	**.0366**	**.0366**	**.0366**	**.0366**	**.0366**	**.0366**
Avg	**.4150**	**.4263**	**.2344**	**.2489**	**.2754**	**.5570**	**.5898**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] BU 5967
Substation No/ Name :- 254047 / KAPASHI
Feeder No / Name : 302 / BIBI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2984	.0034	.0037	.0037	.3772	.426
2	.3086	.3315	.0034	.0037	.0037	.3772	.4588
3	.3086	.3315	.0034	.0037	.0037	.3772	.4588
4	.3086	.3315	.0034	.0037	.0037	.3772	.4588
5	.3429	.3647	.0034	.0037	.0037	.4458	.5243
6	.4801	.4641	.0034	.0037	.0037	.5487	.6554
7	.3086	.663	.0034	.0037	.0037	.823	.9503
8	.3086	.6962	.0034	.0037	.0037	.8573	.7865
9	.0034	.0034	.5144	.5898	.6554	.0034	.0037
10	.0037	.0034	.8848	1.0159	1.0631	.0034	.0023
11	.0037	.0034	1.0486	1.1469	1.2689	.0037	.0034
12	.0037	.0034	.7537	1.1336	.9602	.0037	.0034
13	.0037		.4588	1.2308	1.2689	.0037	.0034
14	.0037		.9503	1.0688	1.2689	.0037	.0034
15	.0037		.9831	1.0364	1.2003	.0037	.0034
16	.0037		1.0486	1.1012	1.3032	.0037	.0034
17	.0037	.0034	.0037	.0037	.0034	.0037	.0034
18		.0034	.0037	.0037	.0034	.0037	.0034
19	.0037	.0034	.0037	.0037	.0034	.0037	.0034
20	.0037	.0034	.0037	.0037	.0034	.0037	
21	.0037	.0034	.0037	.0037	.0034	.0037	
22	.0037	.0034	.0037	.0037	.0034	.0037	
23	.0037	.0034	.0037	.0037	.0034	.0037	
24	.0034	.0037	.0034	.0037	.0037	.0034	.0037
Max	**.4801**	**.6962**	**1.0486**	**1.2308**	**1.3032**	**.8573**	**.9503**
Min	**.0034**	**.0034**	**.0034**	**.0037**	**.0034**	**.0034**	**.0023**
Avg	**.1172**	**.1761**	**.2791**	**.3493**	**.3769**	**.1767**	**.2380**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] BU 5967
Substation No/ Name :- 254047 / KAPASHI
Feeder No / Name : 303 / MULIKWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.1341	.0034	.0037	.0037	.2743	.3315
2	.2058	.1341	.0034	.0037	.0037	.2743	.3647
3	.2058	.1341	.0034	.0037	.0037	.2743	.3647
4	.2058	.1341	.0034	.0037	.0037	.2743	.3647
5	.2058	.1677	.0034	.0037	.0037	.3086	.431
6	.2401	.2347	.0034	.0037	.0037	.3772	.4973
7	.3429	.3688	.0034	.0037	.0037	.5487	.5967
8	.3086	.4024	.0034	.0037	.0037	.583	.663
9	.0034	.0034	.3429	.3315	.4973	.0034	.0037
10	.0037	.0034	.4973	.5967	.7202	.0034	.0034
11	.0037	.0034	.5636	.6882	.9259	.0037	.0034
12	.0037	.0034	.5967	.6882	.9945	.0037	.0034
13	.0037	.0034	.6299	.6882	.9602	.0037	.0034
14	.0037	.0034	.6299	.6882	.8573	.0037	.0034
15	.0037	.0034	.663	.7865	.9259	.0037	.0034
16	.0037	.0034	.6299	.7209	.8573	.0037	.0034
17	.0037	.0034	.0037	.0037	.0034	.0037	.0034
18	.0037	.0034	.0037	.0037	.0034	.0037	.0034
19	.0037	.0034	.0037	.0037	.0034	.0037	.0034
20	.0037	.0034	.0037	.0037	.0034	.0037	
21	.0037	.0034	.0037	.0037	.0034	3.3981	
22	.0037	.0034	.0037	.0037	.0034	.0037	
23	.0037	.0034	.0037	.0037	.0034	.0037	
24	.0034	.0037	.0034	.0037	.0037	.0034	.0037
Max	**.3429**	**.4024**	**.663**	**.7865**	**.9945**	**3.3981**	**.663**
Min	**.0034**	**.0034**	**.0034**	**.0037**	**.0034**	**.0034**	**.0034**
Avg	**.0825**	**.0735**	**.1921**	**.2187**	**.2832**	**.2653**	**.1828**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] BU 5967
Substation No/ Name :- 254047 / KAPASHI
Feeder No / Name : 304 / ADARKI GOANTHAN GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
24	1.0562
Max	1.0562
Min	1.0562
Avg	1.0562

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] BU 5967
Substation No/ Name :- 254047 / KAPASHI
Feeder No / Name : 305 / BIBI GAOTHAN GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1791	.1372	.1075	.1075	.1029	.1075
2	.1715	.1433	.1372	.1075	.1075	.1029	.1075
3	.1715	.1433	.1372	.1075	.1075	.1029	.1075
4	.1715	.1433	.1372	.1075	.1075	.1029	.1075
5	.1372	.1791	.1372	.1075	.1075	.1029	.1075
6	.1715	.1791	.2058	.1433	.1433	.1715	.1433
7	.2058	.2149	.2058	.2172	.2149	.2058	.1791
8	.2058	.1791	.2058	.2149	.2149	.2743	.2507
9	.4115	.3086	.3086	.2865	.2507	.2401	.2149
10	.3582	1.5089	.3814	.3224	.1715	.1372	.3429
11	.3582	.3086	.5373	.5731	.1715	.4298	.3772
12	.4298	.3772	.4298	.4298	.2743	.5731	
13	.5014	.3086	.3224	.2865	.2058	.4298	.0686
14	.4298	.3086	.4298	.3224	.2401	.394	.0343
15	.2865	.3772	.4656	.3582	.2058	.4656	.0343
16	.4656	.3772	.4656	.4298	.1715	.4298	.2743
17	.4298	.2743	.394	.394	.1372	.2865	.3772
18	.1791	.1715	.2149	.2149	.1372	.1433	.2743
19	.2507	.2058	.3224	.2865	.2058	.2149	.2401
20	.2149	.2058	.2865	.2507	.1715	.2149	.2743
21	.2149	.2058	.2507	.2507	.1372	.1791	.2743
22	.2149	.2058	.2149	.1433	.1372	.1433	.16
23	.8299	.1715	.1433	.1433	.1029	.1433	.2058
24	.8299	.1791	.1372	.1075	.1075	.1029	.1075
Max	**.8299**	**1.5089**	**.5373**	**.5731**	**.2743**	**.5731**	**.3772**
Min	**.1372**	**.1433**	**.1372**	**.1075**	**.1029**	**.1029**	**.0343**
Avg	**.3255**	**.2857**	**.2753**	**.2464**	**.1641**	**.2372**	**.1900**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] BU 5967
Substation No/ Name :- 254047 / KAPASHI
Feeder No / Name : 306 / Siddhivinayak Bio-Energy NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 22 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0034	.0037	.0034	.0037	.0037	.0034	.0037
2	.0034	.0037	.0034	.0037	.0037	.0034	.0037
3	.0034	.0037	.0034	.0037	.0037	.0034	.0037
4	.0034	.0037	.0034	.0037	.0037	.0034	.0037
5	.0034	.0037	.0034	.0037	.0037	.0034	.0037
6	.0034	.0037	.0034	.0037	.0037	.0034	.0037
7	.0034	.0037	.0034	.0037	.0037	.0034	.0037
8	.0034	.0037	.0034	.0037	.0037	.0034	.0037
9	.0034	.0034	.0034	.0037	.0037	.0034	.0037
10	.0037	.0034	.0037	.0037	.0034	.0034	.0034
11	.0037	.0034	.0037	.0037	.0034	.0037	.0034
12	.0037	.0034	.0037	.0037	.0034	.0037	.0034
13	.0037	.0034	.0037	.0037	.0034	.0037	.0034
14	.0037	.0034	.0037	.0037	.0034	.0037	.0034
15	.0037	.0034	.0037	.0037	.0034	.0037	.0034
16	.0037	.0034	.0037	.0037	.0034	.0037	.0034
17	.0037	.0034	.0037	.0037	.0034	.0035	.0034
18	.0037	.0034	.0037	.0037	.0034	.0037	.0034
19	.0037	.0034	.0037	.0037	.0034	.0037	.0034
20	.0037	.0034	.0037	.0037	.0034	.0037	.0034
21	.0037	.0034	.0037	.0037	.0034	.0037	.0034
22	.0037	.0034	.0037	.0037	.0034	.0037	
23	.0073	.0034	.0037	.0037	.0034	.0037	
24	.0034	.0037	.0034	.0037	.0037	.0034	.0037
Max	**.0073**	**.0037**	**.0037**	**.0037**	**.0037**	**.0037**	**.0037**
Min	**.0034**	**.0034**	**.0034**	**.0037**	**.0034**	**.0034**	**.0034**
Avg	**.0037**	**.0035**	**.0036**	**.0037**	**.0035**	**.0036**	**.0035**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] **BU 5967**
Substation No/ Name :- 254048 / BEDAKEWASTI
Feeder No / Name : 301 / GOKHALI AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 22 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17
HR	Load (MW)
24	2.0748
Max	2.0748
Min	2.0748
Avg	2.0748

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] **BU 5967**
Substation No/ Name :- 254048 / BEDAKEWASTI
Feeder No / Name : 302 / ASU AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 22 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.6956	.202		.1829	1.6918	
2		1.7299	.1981		.1867	1.6842	
3		1.749	.1905		.1753	1.688	
4		1.7604	.2362		.1677	1.6956	
5		1.9128	.2896		.1867	1.989	
6		2.1529	.4268		.1905	2.3243	
7		2.7206	.5068		.442	2.6901	
8		2.774			.3163	2.8616	
9		.2324				.2553	
10		.1524			2.6901	.2553	
11	.16	.1448		2.6825	3.1779		.1867
12	.1219	.141		3.3951	3.0826		.16
13	.1334	.1486		3.4179	2.9683		.1715
14	.1638			3.6427	3.3036		.1753
15	.1372	.1677		3.4217	3.3265		.1638
16	.1372			3.3608	3.0826		.202
17	.1524	.221		.2096			.2134
18	.2439	.2667		.2858	.3658		.2401
19	.2858	.3467		.3582	.1677		.3429
20	.2858	.2934		.3239	.3277		.3125
21	.2553	.2743		.282	.301		.2972
22	.2362	.2401		.2667	.2705		.2477
23	.1981	.2362		.2401			.2401
24	2.2634	.1867	.2286		.2172	.2477	
Max	**2.2634**	**2.774**	**.5068**	**3.6427**	**3.3265**	**2.8616**	**.3429**
Min	**.1219**	**.141**	**.1905**	**.2096**	**.1677**	**.2477**	**.16**
Avg	**.3410**	**.8885**	**.2848**	**1.6836**	**1.1966**	**1.5803**	**.2272**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] BU 5967
Substation No/ Name :- 254048 / BEDAKEWASTI
Feeder No / Name : 303 / 22 KV GOKHALI GAOTHAN GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
23	.415
Max	.415
Min	.415
Avg	.415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] BU 5967
Substation No/ Name :- 254048 / BEDAKEWASTI
Feeder No / Name : 304 / 22 KV ASU GAOTHAN GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1791	.1753		.1638	.1905	
2		.1753	.1753		.1677	.1905	
3		.1715	.1753		.1677	.1715	
4		.1943	.2248		.2134	.2134	
5		.2248	.2934		.2782	.3125	
6		.4191	.3887		.3925	.3887	
7		.4763	.5068		.4763		
8		.3696			.3925		
9		.2362			.3925		
10		.2439			.3048		
11	.2286	.2324		.2858	.2286		.2134
12	.2324	.2172		.1981	.1562		.1791
13	.1943	.1677		.1829	.1677		.1448
14	.1562			.1715	.1715		.16
15	.1562	.2743		.1981	.202		.1943
16	.221	.301		.2477	.221		.1943
17	.2782			.3048	.3734		.2667
18	.3239	.423		.3391	.3544		.3048
19	.4534	.4534		.4458	.3544		.3696
20	.3734	.3925		.3658	.3086		.4039
21	.3582	.3201		.3277	.2667		.3506
22	.282	.2553		.2858			.301
23	.1981	.2553		.2401			.221
24		.2248	.1791		.1677	.1943	
Max	**.4534**	**.4763**	**.5068**	**.4458**	**.4763**	**.3887**	**.4039**
Min	**.1562**	**.1677**	**.1753**	**.1715**	**.1562**	**.1715**	**.1448**
Avg	**.2658**	**.2821**	**.2648**	**.2764**	**.2692**	**.2373**	**.2541**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] **BU 5967**
Substation No/ Name :- 254048 / BEDAKEWASTI
Feeder No / Name : 305 / 22 KV Sarade AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 22 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17
HR	Load (MW)
24	2.2634
Max	2.2634
Min	2.2634
Avg	2.2634

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] **BU 5967**
Substation No/ Name :- 254051 / WAKHARI
Feeder No / Name : 301 / Wathar- N Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 22 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0038	.0038	.4527	.4805	.4954		
2	.0038	.0038	.4904	.4805	.4954		
3	.0038	.0038	.4527	.5544	.5716		
4	.0038	.0038	.5281	.5914	.6097		
5	.0038	.0038	.6036	.6584	.7621		
6	.0038	.0038	.7545	.9145	1.0288		
7	.0038		1.358	1.3306	1.2574		
8	.0038		1.3203	1.3443	1.3957	.0038	
9	.5658	.9145	.0377	.0038	.0038	1.2449	1.2449
10	1.094	1.2071		.0038	.0038		1.9616
11	1.1317	1.3957			.0038	1.8484	2.1948
12	1.3203	1.358		.0038	.0038	1.8484	2.1216
13	1.358	1.0562	.0038	.0038	.0038	1.8107	2.0633
14	1.4335	1.4335	.0038	.0038	.0038	1.6975	2.2177
15	1.0669	1.6975	.0038	.0038	.0038	1.6975	2.1948
16	1.448	1.5466	.0038	.0038	.0038	1.8861	2.2916
17	.0038	1.3957	.0038	.0038	.0038	.2641	.0038
18	.0038		.0038	.0038	.0038		.0038
19	.0038		.0038	.0038	.0038		.0038
20	.0038		.0038	.0038	.0038		.0038
21	.0038		.0038	.0038	.0038		.0038
22	.0038		.0038	.0038	.0038		.0038
23	.0038		.0038	.0038	.0038		.0038
24	.0038	.0038	.0377	.0038	.0038		
Max	**1.448**	**1.6975**	**1.358**	**1.3443**	**1.3957**	**1.8861**	**2.2916**
Min	**.0038**	**.0038**	**.0038**	**.0038**	**.0038**	**.0038**	**.0038**
Avg	**.3950**	**.7520**	**.2894**	**.2788**	**.2782**	**1.3668**	**1.0878**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] BU 5967
Substation No/ Name :- 254051 / WAKHARI
Feeder No / Name : 302 / Upalwe Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2574	.1524	.3018	.2957	.3048		
2	1.2574	.1524	.3018	.2957	.3048		
3	1.2574	.2667	.3772	.2957	.3048		
4	1.3336	.6097		.2957	.4572		
5	1.4861	.6097	.5281	.439	.724		
6	1.6221	.4572	.679	.7316	.8002		
7	2.2257	.4954	.7545	.7392	.8002		
8	1.9239	1.829	.5658	.6722		2.2257	
9	.415		1.3957	1.6598	2.21	.415	.3772
10	.3395	.1905	1.6221	2.7538	3.0178		.3018
11	.3018	.1509	2.7915	3.131	3.0178		.2561
12	.3018	.1509	2.6029	3.2065	1.7353	.2263	.2534
13	.3018		2.6406	3.0556	2.8292	.2263	.2172
14	.2641		2.9424	3.131	3.0178	.2263	.2218
15	.1905	.1132	2.6783	3.131	1.773		.3292
16	.3048	.2641	2.7538	3.131	2.8669	.2263	.3326
17	.2667	.3018	.1509	.2641		.2641	.3395
18	.4191		.2641	.5658			.5281
19			.7545	.8002	.724		.7167
20			.415	.7621	.724		.8002
21	.1905		.415	.6097	.4954		.6478
22	.1905		.415	.4954	.5335		.4904
23			.3395	.381	.4527		.4904
24	.381	.1143	.3018	.3395	.381		
Max	**2.2257**	**1.829**	**2.9424**	**3.2065**	**3.0178**	**2.2257**	**.8002**
Min	**.1905**	**.1132**	**.1509**	**.2641**	**.3048**	**.2263**	**.2172**
Avg	**.7729**	**.3905**	**1.1301**	**1.2993**	**1.3083**	**.5443**	**.4202**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] BU 5967
Substation No/ Name :- 254051 / WAKHARI
Feeder No / Name : 303 / Tathawada Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 22 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2286	.5281	.9979	1.0288		
2	.2286	.2286	.5281	.9979	1.0288		
3	.2286	.2286	.5281	1.0349	1.0669		
4	.2286	.2667		1.0349	1.105		
5	.2641	.2667		1.2071	1.2574		
6	.415	.4954		1.39	1.4861		
7	.5658	.5335		1.7372	1.6385		
8	.415	.4191		1.419	1.6766	.415	
9	1.2071	1.2574	.2641	.3018	.3048	1.4712	1.5466
10	1.3957	.3048	.2263	.2263			1.6598
11	1.5089	1.2071	.1886		.2263	2.1879	1.9022
12	1.5844	1.8107		.2263	.2263	2.2257	1.9753
13	1.6598	1.8484		.2263	.2641	2.1879	2.0995
14	1.6598	1.9616	.1886	.2263	.2263	2.0748	2.3285
15	1.7147	1.094	.2263	.1886	.2263	2.2634	2.268
16	1.829		.2263	.1509	.3018	2.4143	
17	.2286		.2641	.2263	.3018	.1886	.1509
18	.3048		.3395	.3048	.381		.3018
19	.4191		.4904	.4572	.5335		.3772
20	.4191		.3395	.381	.4954		.381
21	.381		.3395	.3429	.4191		.381
22	.3048		.3018	.2667	.381		.3395
23			.2641	.2667	.3429		.3018
24	.2286	.2286	.2263	.2641	.2286		
Max	**1.829**	**1.9616**	**.5281**	**1.7372**	**1.6766**	**2.4143**	**2.3285**
Min	**.2286**	**.2286**	**.1886**	**.1509**	**.2263**	**.1886**	**.1509**
Avg	**.7574**	**.7737**	**.3217**	**.6033**	**.6586**	**1.7143**	**1.1438**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] **BU 5967**
Substation No/ Name :- 254051 / WAKHARI
Feeder No / Name : 304 / Wathar-N Gaonthan **GAOTHAN FEEDER**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1524	.1509	.1478	.1524		
2	.1905		.1509	.1478	.1524		
3	.1905		.1509	.1478	.1524		
4	.1905		.1509	.1478	.1905		
5	.2286	.1524	.1886	.1829	.2286		
6	.2641	.1905	.2641	.2218	.2286		
7	.3395	.2667	.3018	.2957	.3048		
8	.3048	.2667	.2641	.2614	.2667	.1886	
9		.2286	.1886	.2263	.2263	.2263	.1886
10		.2667	.1886	.2641	.2263		.1509
11	.2263	.1132	.1886	.2263	.2263	.1886	.2195
12	.2263	.1132	.1509	.1886	.2263	.1886	.1829
13	.2263	.1509	.1509	.1886	.1886	.1886	.1448
14	.1509	.1509	.1509	.1886	.2263	.1886	.1478
15	.1905	.1509	.1886	.1886		.2263	.1829
16	.1905	.1509	.1509	.1886	.1509	.2263	.1478
17	.1524	.1886	.1509	.2263	.2641	.2263	.1886
18	.1905		.2641	.2667	.1905		.2263
19	.2667		.3395	.381	.3429		.3772
20	.2667		.3395	.381	.3048		.3429
21	.3048		.3018	.2667	.3048		.3048
22	.2667		.1886	.2286	.1905		.2263
23			.1886	.1905	.1524		.1886
24	.1905	.1524	.1509	.1886	.1524		
Max	**.3395**	**.2667**	**.3395**	**.381**	**.3429**	**.2263**	**.3772**
Min	**.1509**	**.1132**	**.1509**	**.1478**	**.1509**	**.1886**	**.1448**
Avg	**.2261**	**.1797**	**.2043**	**.2226**	**.2196**	**.2054**	**.2147**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] BU 5967
Substation No/ Name :- 254051 / WAKHARI
Feeder No / Name : 305 / Upalawe Gaonthan GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0754	.0739	.0762		
2	.0762	.0762	.0754	.0739	.0762		
3	.0762	.0762	.0754	.0739	.0762		
4	.0762	.0762	.0754	.0739	.0762		
5	.0762	.0762	.1132	.0732	.1143		
6	.1143	.1143	.1132	.1463	.1143		
7	.1509	.1524	.1132	.1478	.1524		
8	.1132	.1143		.1494	.1524	.1509	
9	.1886	.0762	.0754	.1132	.0762	.0754	.1132
10	.1509	.1132	.0754	.1132	.0762		.1132
11	.1132	.1509	.0754	.1132	.0754	.1509	.1097
12	.1132	.1132	.1132	.0754	.0754	.1509	.1097
13	.1509	.1509	.0754	.0754	.0754	.1509	.1448
14	.1132	.1509	.0754	.0754	.0754	.1132	.0739
15	.0762	.1509	.0754	.0754	.0754	.1132	.1463
16	.1524	.1509	.0754	.0754	.0754	.1132	
17	.1143	.1509	.0754	.1132		.1132	.1132
18	.1143		.0754	.1143			.0754
19	.1524		.1132	.1524	.1524		.1132
20	.1143		.1132	.1524	.1143		.1524
21	.1143		.1132	.1143	.1143		.1143
22	.1143		.0754	.0762	.0762		.0754
23	.1143		.0754	.0762	.0762		.0754
24	.7545	.0762	.0754	.0754	.0762		
Max	**.7545**	**.1524**	**.1132**	**.1524**	**.1524**	**.1509**	**.1524**
Min	**.0762**	**.0762**	**.0754**	**.0732**	**.0754**	**.0754**	**.0739**
Avg	**.1421**	**.1137**	**.0869**	**.1001**	**.0933**	**.1258**	**.1093**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] BU 5967
Substation No/ Name :- 254051 / WAKHARI
Feeder No / Name : 306 / Tathawada Gaonthan GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1143	.1132	.1109	.1143		
2	.1143	.1143	.1132	.0739	.1143		
3	.1143	.1143	.1132	.0739	.1143		
4	.1143	.1143	.1886	.0739	.1143		
5	.1905	.1143	.1886	.1829	.1524		
6	.2286	.1905	.3018	.2926	.2286		
7	.3048	.3048		.2957	.2667		
8	.2641	.2286	.2641	.2614	.2667	.2263	
9	.1886	.1524	.1132	.1886	.1886	.1886	.1132
10	.1132	.1132	.1132	.1509	.1886		.1132
11	.1132	.1132	.1132	.1132	.1509	.1132	.0732
12	.1132	.1132	.0754	.0754	.1132	.1132	.0732
13	.1132	.1132		.0754	.1132	.0754	.0724
14	.0754	.1132	.0754	.0754	.1132	.0754	.0739
15	.0762	.1132	.0754	.0754	.1132	.0754	.0732
16	.1143		.0754	.0754	.1132	.0754	
17	.1143		.1132	.1132	.1132	.0754	.1132
18	.2286		.1509	.1905	.1524		.1509
19	.2667		.2263	.2667	.2667		.2641
20	.2667		.1886	.2286	.2286		.2286
21	.2286		.1886	.1905	.1905		.2286
22	.1524		.1886	.1905	.1905		.1509
23	.1524		.1509	.1143	.1524		.1509
24	.8299	.1524	.1132	.1132	.1143		
Max	**.8299**	**.3048**	**.3018**	**.2957**	**.2667**	**.2263**	**.2641**
Min	**.0754**	**.1132**	**.0754**	**.0739**	**.1132**	**.0754**	**.0724**
Avg	**.1913**	**.1425**	**.1475**	**.1501**	**.1614**	**.1131**	**.1343**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] **BU 5967**
Substation No/ Name :- 254058 / 33/22 KV Saskal
Feeder No / Name : 301 / 22 Kv Giravi Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 22 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17
HR	Load (MW)
24	2.452
Max	2.452
Min	2.452
Avg	2.452

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] **BU 5967**
Substation No/ Name :- 254058 / 33/22 KV Saskal
Feeder No / Name : 302 / 22 Kv Vinchurni Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 22 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17
HR	Load (MW)
24	2.0748
Max	2.0748
Min	2.0748
Avg	2.0748

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] **BU 5967**
Substation No/ Name :- 254058 / 33/22 KV Saskal
Feeder No / Name : 303 / 22 Kv Giravi Gaothan **GAOTHAN FEEDER**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
24	.7545
Max	.7545
Min	.7545
Avg	.7545

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] **BU 5967**
Substation No/ Name :- 254058 / 33/22 KV Saskal
Feeder No / Name : 304 / 22 KV Wadale AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 22 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	.7316	.2561	.2507	.2587	1.1431	1.1317
2	1.2193	.9877	.2561	.2587	.2587	1.2955	1.2826
3	1.448	1.2437	.2561	.2534	.2587	1.3717	1.4335
4	1.6004	1.4632	.2926	.2507	.2957	1.6004	1.6598
5	1.829	1.7558	.2926	.2926	.3696	1.9052	2.1502
6	2.0195	1.9022	.439	.4755	.5175	2.0957	2.452
7	2.7054	2.5972	.5914	.5853	.6283	2.8578	3.131
8	2.8197	2.4874	.4481	.5487	.5544	2.8959	3.0556
9	.4191	.2926	2.2546	1.9753	2.5133	.4191	.4527
10	.4024	.2614	2.9047		3.3913	.3395	.3326
11	.4024	.2195	3.2065	3.2487	3.5056	.3772	.2957
12	.3292	.2534	3.2065	3.2114	3.5437	.3395	.2957
13	.2926	.2957	3.3196	3.1047	3.6199	.0377	
14	.2561	.2926	3.3951	2.95	3.658	.3018	
15	.2561	.2896	3.131	3.1367	3.5056	.3395	
16	.2561	.2926	3.1687	3.062	3.4294	.3772	
17	.2561	.3292	.3018	.3292	.2667	.3772	.3696
18	.3658	.3658	.3658	.3292	.4572	.3772	.5175
19	.5121	.439	.5544	.4435	.5335	.5658	.5853
20	.4755	.439	.4024	.5175	.4954	.5281	.5544
21	.439	.4024	.3772	.4805	.4191	.4527	.4805
22	.3658	.3658	.3658	.4066	.381	.415	.3696
23	.3292	.2926	.2926	.2957	.3429	.3395	.3326
24	.3048	.2926	.2926	.2587	.2587	.3429	.3395
Max	**2.8197**	**2.5972**	**3.3951**	**3.2487**	**3.658**	**2.8959**	**3.131**
Min	**.2561**	**.2195**	**.2561**	**.2507**	**.2587**	**.0377**	**.2957**
Avg	**.8456**	**.7622**	**1.2655**	**1.1594**	**1.3943**	**.8790**	**1.0611**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] **BU 5967**
Substation No/ Name :- 254058 / 33/22 KV Saskal
Feeder No / Name : 305 / 22 KV Dudhebavi AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 22 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17
HR	Load (MW)
24	2.452
Max	2.452
Min	2.452
Avg	2.452

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] **BU 5967**
Substation No/ Name :- 254058 / 33/22 KV Saskal
Feeder No / Name : 306 / 22 KV Dudhebavi Gaonthan **GAOTHAN FEEDER**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1463	.1463	.1478	.112	.1524	.1509
2	.1524	.1829	.112	.1478	.1109	.1524	.1509
3	.1905	.1829	.1097	.1478	.1109	.1905	.1509
4	.2286	.2195	.1109	.1478	.1478	.2286	.1886
5	.2667	.2561	.1867	.1848	.2218	.2667	.2263
6	.3048	.2926	.2957	.2587	.2957	.3048	.3018
7	.381	.3658	.3734	.3224	.3696	.3429	.3772
8	.3048	.2561	.2218	.2587	.2587	.3048	.3395
9	.2286	.2195	.1848	.1867	.1848	.2286	.2263
10	.1829	.1829	.1886	.1848	.2286	.1509	.1848
11	.1829	.1463		.1478	.1905	.1509	.1478
12	.2195		.1509	.1478	.1905	.1509	
13	.1829		.1509	.1463	.1905	.1509	
14	.1463		.1509	.1463	.1905	.1509	
15	.1463		.1509	.1478	.1905	.1509	
16	.1829		.1132	.1478	.1905	.1132	
17	.1829	.2195	.1509	.1463	.1524	.1886	.2587
18	.2561	.2926	.1848	.2195	.3048	.1886	.3326
19	.3292	.3292	.3326	.3292	.3429	.3018	.3734
20	.2926	.3292	.2957	.2957	.3048	.3018	.3326
21	.2561	.2926	.2218	.2218	.2667	.2641	.2561
22	.1829	.2195	.1848	.1829	.2286	.1886	.2218
23	.1463	.1829	.1478	.1478	.1905	.1509	.1848
24	.679	.1463	.1463	.1494	.1448	.1524	.1509
Max	**.679**	**.3658**	**.3734**	**.3292**	**.3696**	**.3429**	**.3772**
Min	**.1463**	**.1463**	**.1097**	**.1463**	**.1109**	**.1132**	**.1478**
Avg	**.2408**	**.2349**	**.1875**	**.1902**	**.2133**	**.2053**	**.2398**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] **BU 5967**
Substation No/ Name :- 254074 / 33/22 KV Rajale
Feeder No / Name : 301 / JANAI AG **FEEDER SEPERATION/PURE AG**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4074	1.5086	.2182	.1728	.1943	1.626	1.6319
2	1.3748	1.5244	.2119	.1728	.1879	1.6388	1.6066
3	1.3654	1.5339	.2151	.176	.1846	1.722	1.6161
4	1.4435	1.6193	.234	.1792	.1911	1.8788	1.6382
5	1.6265	1.73	.2593	.2177	.285	1.9364	1.6857
6	1.7747	1.9071	.3985	.3393	.3498	2.3109	2.0652
7	2.2559	2.3973	.4681		.447	2.567	2.5238
8	2.184	1.9608	.3985	.3841	.4081	2.5862	2.5712
9	.25	.3239	2.7462	2.1029	2.1247	.2785	.2849
10	.2437		2.7462	2.7958	2.6688	.2048	.2497
11	.2468	.2498	2.8871	3.1025	2.9473		.2241
12	.2531	.2151	3.0151	2.859	2.4745	.1664	.144
13	.25	.1866	2.3525	2.7199	2.8308	.2177	.192
14	.2404	.2112	2.7334	2.7641	2.9441	.16	.1814
15	.2343	.2656	2.7846	2.6471	2.9473	.1632	.1879
16	.1961	.2309	2.5734	2.8306	2.5295	.1632	.2138
17	.2404	.2309	.192	.2305	.2689	.1613	.2202
18	.2878	.3416	.2689	.3329	.3457	.2751	.3304
19	.37	.3858	.3169	.3854	.3553	.3289	.353
20	.3265	.3384	.2945	.3239	.3073	.2815	.3142
21	.3005	.3233	.2433	.2656	.2785	.2657	.3045
22	.2404	.2561	.208	.2526	.2241	.2119	.2785
23	.2277	.2404	.1856	.204	.2112	.1771	.2364
24	.2048	.1834	.2214	.1664	.1943	.2048	.1803
Max	**2.2559**	**2.3973**	**3.0151**	**3.1025**	**2.9473**	**2.5862**	**2.5712**
Min	**.1961**	**.1834**	**.1856**	**.1664**	**.1846**	**.16**	**.144**
Avg	**.7310**	**.7898**	**1.0905**	**1.1141**	**1.0792**	**.8490**	**.8014**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] **BU 5967**
Substation No/ Name :- 254074 / 33/22 KV Rajale
Feeder No / Name : 302 / SATE PHATTA AG **FEEDER SEPERATION/PURE AG**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2092	.1814	1.1725	1.219	1.1174	.2235	.1717
2	.2172	.1781	1.1854	1.2256	1.1012	.2267	.1652
3	.2305	.1846	1.1951	1.2178	1.1239	.2332	.1619
4	.2913	.2008	1.2048	1.2372	1.1401	.2656	.1717
5	.3361	.298	1.247	1.302	1.2599	.3077	.1943
6	.4518	.3757	1.3765	1.451	1.3409	.3951	.3368
7	.5106	.3951	1.7101		1.6	.434	.4146
8	.3772	.3304	1.7101	1.7393	1.6421	.3692	.3498
9	1.8994	1.8631	.2202	.2753	.2462	1.4746	1.2988
10	2.1896	1.9072	.2429	.2462	.2397	1.5795	1.7433
11	2.2575	2.1792	.2462	.2235	.2332		1.8613
12		2.0972	.2008	.2202	.1781	2.2611	1.5533
13	2.3139	2.1071		.2267	.1781	2.1595	1.6909
14	2.3266	2.1183		.2008	.1587	2.1759	1.881
15	2.3061	2.0793	.1457			2.2119	1.9596
16	2.0534	2.0776	.1749		.149	2.2119	2.1398
17	.2073	.1522	.2397	.2163	.2202	.1393	.1704
18	.2753	.2721	.3109	.3048	.2591	.23	.2064
19	.3368	.3401	.3498	.3637	.3563	.2753	.308
20	.285	.298	.3466	.3211	.285	.2105	
21	.2526	.2556	.272	.2753	.2591	.2073	.2458
22	.2364	.2228	.2556	.2556	.2202	.1943	.2294
23	.2267	.2138	.2228	.2294	.2267	.1814	.213
24	.1943	.1879	.2073	.2032	.2228	.2202	.1684
Max	**2.3266**	**2.1792**	**1.7101**	**1.7393**	**1.6421**	**2.2611**	**2.1398**
Min	**.1943**	**.1522**	**.1457**	**.2008**	**.149**	**.1393**	**.1619**
Avg	**.8689**	**.8548**	**.6471**	**.6169**	**.5982**	**.7908**	**.7668**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] BU 5967
Substation No/ Name :- 254074 / 33/22 KV Rajale
Feeder No / Name : 303 / RAJALE GAON GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2301	.2075	.2091	.2112	.1924	.2128	.1979
2	.2263	.215	.2203	.2112	.1886	.2166	.1942
3	.2439	.2339	.2241	.2112	.1924	.2241	.1867
4	.2591	.3169	.2353	.2339	.215	.2315	.2054
5	.3315	.4074	.2465	.2905	.2754	.2726	.2353
6	.4153	.43	.3958	.3621	.4036	.3286	.3921
7	.4611	.4451	.3479		.4564	.3921	.4556
8	.3433	.3282	.3211	.3885	.3584	.3846	.4108
9	.3131	.2913	.3018	.3398	.3093	.249	.2689
10	.2829	.298	.2339	.2577	.3206	.2339	.2452
11	.2527	.2377	.2075	.183	.2942		.2112
12		.215	.1999	.1568	.2565	.1848	.1773
13	.2301	.2128	.1811	.1606	.2112	.1622	.1698
14	.215	.1848	.1509	.1643	.1698	.1886	.1962
15	.2054	.2203	.1735		.166	.1962	.1886
16	.1848	.2414	.1735	.1904	.1735	.1962	
17	.2452	.2942	.2339		.1698	.1531	.2527
18	.3169	.3025	.2791	.3546	.3206	.3099	.332
19	.3999	.3622	.4036	.381	.3772	.3921	.3848
20	.381	.3435	.381	.3999	.351	.3473	.3584
21	.3471	.3249	.3018	.3282	.3398	.3137	.3282
22	.2791	.2867	.2641	.2641	.2801	.2577	.3206
23	.2339	.2339	.2339	.215	.2465	.1961	.2716
24	.2278	.215	.2188	.2075	.1962	.2166	.1739
Max	**.4611**	**.4451**	**.4036**	**.3999**	**.4564**	**.3921**	**.4556**
Min	**.1848**	**.1848**	**.1509**	**.1568**	**.166**	**.1531**	**.1698**
Avg	**.2881**	**.2853**	**.2558**	**.2625**	**.2694**	**.2548**	**.2677**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] BU 5967
Substation No/ Name :- 258024 / 220 kv surawadi EHV
Feeder No / Name : 400 / Auxilary Supply
Feeder KV- 33 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
24	4.2438
Max	4.2438
Min	4.2438
Avg	4.2438

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] **BU 5967**
Substation No/ Name :- 258024 / 220 kv surawadi EHV
Feeder No / Name : 402 / 33 kv tata cumines ltd **NON SHEDDABLE EXPRESS HV FEEDERS**
Feeder KV- 33 / OUTGOING **(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	01-NOV-17
HR	Load (MW)
24	2.7161
Max	2.7161
Min	2.7161
Avg	2.7161

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] **BU 5967**
Substation No/ Name :- 258024 / 220 kv surawadi EHV
Feeder No / Name : 405 / 33 kv cummins india ltd **NON SHEDDABLE EXPRESS HV FEEDERS**
Feeder KV- 33 / OUTGOING **(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	01-NOV-17
HR	Load (MW)
23	2.2634
Max	2.2634
Min	2.2634
Avg	2.2634

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] **BU 5967**
Substation No/ Name :- 258024 / 220 kv surawadi EHV
Feeder No / Name : 406 / 33 KV CUMMINES Technology indi Feeder KV- 33 / OUTGOING **NON SHEDDABLE EXPRESS HV FEEDERS (CONTINOUS PROCESS)(NO STAGGERING)**

DATE	01-NOV-17
HR	Load (MW)
24	1.9805
Max	1.9805
Min	1.9805
Avg	1.9805

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] **BU 5967**
Substation No/ Name :- 258024 / 220 kv surawadi EHV
Feeder No / Name : 701 / 132 KV Sharayu Agro Industries Feeder KV- 132 / OUTGOING **NON SHEDDABLE EXPRESS HV FEEDERS (CONTINOUS PROCESS)(NO STAGGERING)**

DATE	01-NOV-17
HR	Load (MW)
24	10.1852
Max	10.1852
Min	10.1852
Avg	10.1852

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
PHALTAN DIVISION[513]
PHALTAN[113] **BU 5967**
Substation No/ Name :- 258024 / 220 kv surawadi EHV
Feeder No / Name : 801 / SWARAJ INDIA AGRO LTD CO-GEN Feeder KV- 220 / OUTGOING NON SHEDDABLE EXPRESS HV FEEDERS (CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-NOV-17
HR	Load (MW)
24	18.107
Max	18.107
Min	18.107
Avg	18.107

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
KOREGAON[119] **BU 0949**
Substation No/ Name :- 254013 / KORAGAON
Feeder No / Name : 201 / KATHAPUR AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2346	1.0974	.0572	.0457	.0381	1.4937	1.7318
2	1.2174	1.0669	.0381	.0457	.0381	1.4784	1.7147
3	1.2003	1.0364	.0572	.0457	.0381	1.4784	1.6632
4	1.1831	1.0364	.0381	.0457	.0381	1.4784	1.6461
5	1.2003	.9907	.0572	.0457	.0381	1.448	1.6461
6	1.2346	1.0212	.0572	.0457	.0381	1.448	1.6461
7	1.3717	1.1431		.0457	.0572	1.7223	1.6461
8	.0572	.0457	1.1469	1.6461	1.6057	.0457	.0514
9	.0572	.0572	1.4632	2.0317	1.7071	.0514	.0457
10	.0572	.0572	1.9052	2.1136	2.2405	.0514	.0457
11	.0572	.0572	1.9509	2.2119	2.1643	.0514	.0457
12	.0572	.0572	1.9509	2.3758	2.0424	.0514	.0457
13	.0572	.0381	1.9052	2.2283	1.9052	.0514	.0457
14		.0572	1.7985	2.3102	2.0119	.0514	.0457
15		.0381	1.7223	2.1792	2.0576	.0514	.0457
16	.0381	.0572	.0457	.0381	.0457	.0514	.0457
17	.061	.0572	.0457	.0381	.0457	.0514	.0457
18	.061	.0572	.0457	.0381		.0514	.0457
19	.061	.0572	.0457	.0381	.061	.0514	.061
20	.061	.0572	.0457	.0572	.061	.0686	.061
21	.061	.0572	.0457	.0381	.0457	.0686	.0152
22	.061	.0572	.0457	.0332	.0457	.0686	.061
23	.061	.0572	.0457	.0332	.0457	.0686	.061
24	1.6575	1.1279	.0497	.0457	.0332		1.7147
Max	**1.6575**	**1.1431**	**1.9509**	**2.3758**	**2.2405**	**1.7223**	**1.7318**
Min	**.0381**	**.0381**	**.0381**	**.0332**	**.0332**	**.0457**	**.0152**
Avg	**.5049**	**.3911**	**.6332**	**.7407**	**.7132**	**.4971**	**.5907**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
KOREGAON[119] **BU 0949**
Substation No/ Name :- 254013 / KORAGAON
Feeder No / Name : 202 / EKAMBE -SANGVI- AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0305	.112	1.4937	.6554	.0305	.0686
2	.0686	.0305	1.829	1.4937	.7537	.0305	.0686
3	.0686	.0305	1.5402	1.4632	.7865	.0305	.0514
4	.0686	.0305	1.6057	1.448	.852	.0305	.0514
5	.0686	.0305	1.6385	1.4175	1.2125	.0305	.0514
6	.0686	.0305	1.6549	1.6766	1.6221	.0457	.0514
7	.0686		1.9989	1.8595	1.9989	.061	.0686
8	1.95	2.0576	.0572	.061	.061	1.6766	2.0919
9	2.4741	2.4905	.0457	.0762	.061	2.5549	2.2558
10	2.3758	2.4741	.0305	.0381	.061	2.7263	
11	2.2775	2.556		.0572	.0457	2.8807	2.3777
12	2.1792	2.3758	.0305	.0381	.0457	2.8121	2.4082
13	2.5888	2.6052	.0305	.0381	.0457	2.8121	2.0729
14		2.4413	.0305	.0381	.0457	2.7435	2.0881
15		2.2939	.0305	.0381	.0457	2.692	2.1033
16	.1143	.0381	.0305	.0381	.0457	.0686	.0457
17	.0457	.0191	.0305	.0381	.0457	.0686	.0457
18	.0305	.0572	.0305	.0572		.0686	.061
19	.0305	.0572	.0457	.0572	.061	.0686	.061
20	.0457	.0572	.0457	.0572	.061	.0686	.061
21	.0457	.0572	.0457	.0572	.061	.0686	.061
22	.0457	.0572	.0457	.0474	.0457	.0686	.061
23	.0305	.0572	.0457	.0474	.0457	.0686	.061
24		.0305	1.5497	1.5242	1.5497		.0686
Max	**2.5888**	**2.6052**	**1.9989**	**1.8595**	**1.9989**	**2.8807**	**2.4082**
Min	**.0305**	**.0191**	**.0305**	**.0381**	**.0457**	**.0305**	**.0457**
Avg	**.7007**	**.8656**	**.5437**	**.5484**	**.4438**	**.9437**	**.7102**

 Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
KOREGAON[119] **BU 0949**
Substation No/ Name :- 254013 / KORAGAON
Feeder No / Name : 203 / MIDC **SHEDDABLE FEEDER HAVING WEEKLY**
Feeder KV- 11 / OUTGOING **STAGGERING (MIDC, EQUIVALENT)**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0183	.0514	.056	.0514	.0373		.0366
2	.0183	.0171	.056	.0343	.0373		.0343
3	.0366	.0171	.0328	.0343	.0373	.0343	.0183
4	.0366	.0171	.0373	.0343	.0373	.0343	.0183
5	.0366	.0343	.056	.0343	.056	.0343	.0366
6	.0366	.0686	.0747	.0514	.0373	.0343	.0366
7	.0366	.0686	.056	.0514	.056	.0343	.0366
8	.0373	.0857	.056	.0514	.0514	.0514	.0549
9	.0747	.0747	.0686	.056	.0686	.0366	.0343
10	.056	.056	.0686	.056	.0514	.0549	.0343
11	.056	.112	.0514	.0934	.0857	.0914	.0514
12	.056	.0934	.0514	.0747	.0857	.1097	.0343
13	.0747	.112	.0686	.056	.0686	.0914	.0343
14		.2614	.0857	.0747	.0686	.0732	.0343
15		.0747	.0686	.0747	.0514	.0732	.0343
16	.112	.112	.0686	.112	.0514	.0732	.0343
17	.0343	.112	.0514	.056	.0514	.0914	.0343
18	.0514	.0747	.0686	.0934		.0732	.0343
19	.0514	.0934	.0686	.0747	.0171	.0732	.0343
20	.0343	.112	.0857	.112	.0514	.0732	.0343
21	.0514	.112	.0686	.056	.0343	.0549	.0343
22	.0514	.056	.0514	.0373	.0343	.0732	.0343
23	.0514	.056	.0514	.0373	.0514	.0549	.0343
24	.0171	.0514	.0373	.0343	.0373		.0366
Max	**.112**	**.2614**	**.0857**	**.112**	**.0857**	**.1097**	**.0549**
Min	**.0171**	**.0171**	**.0328**	**.0343**	**.0171**	**.0343**	**.0183**
Avg	**.0468**	**.0802**	**.0600**	**.0601**	**.0504**	**.0629**	**.0350**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
KOREGAON[119] **BU 0949**
Substation No/ Name :- 254013 / KORAGAON
Feeder No / Name : 204 / EKAMBE -SANGVI- VLG **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012	.1715	.2054	.1715	.1867	.1886	.2012
2	.2012	.1543	.2241	.1543	.1867	.1715	.1829
3	.1829	.1543	.2614	.1543	.168	.1715	.1463
4	.1829	.1372	.2987	.1543	.168	.1543	.1646
5	.2561	.2058	.3734	.2058	.3361	.2743	.2561
6	.4207	.3944	.4668	.3772	.5041	.4458	.439
7		.5658	.5975	.5316	.5601	.5658	.6219
8	.5228	.4458	.5415	.4973	.3944	.463	.4755
9	.4294	.3734	.3772	.4668	.3944	.439	.3601
10	.3734	.2427	.3258	.2987	.2743	.2926	.3086
11	.3361	.2427	.2743	.2614	.2401	.2195	.2572
12	.2054	.2241	.2229	.2241	.2058	.2012	.2401
13	.2054	.2801	.1886	.2427	.2229	.2012	.2401
14		.2614	.1886	.2054	.1886	.2378	.2229
15		.2427	.2229	.2054	.2058	.2743	.1886
16	.112	.2614	.2229	.2241	.2915	.2378	.1886
17	.2058	.2241	.2572	.2054	.3429	.2926	.2401
18	.3772	.4108	.3601	.3361		.4572	.463
19	.583	.5601	.463	.5041	.5316	.5853	.4801
20	.5144	.4668	.4287	.4668	.5316	.5487	.4801
21	.4115	.4294	.3601		.4287	.4938	.4458
22	.3258	.3547	.2743	.3361	.3258	.3841	.3944
23	.4116	.2241	.2229	.2241	.2229	.2561	.2572
24	.2195	.1886	.2054	.1886	.1867		.2195
Max	**.583**	**.5658**	**.5975**	**.5316**	**.5601**	**.5853**	**.6219**
Min	**.112**	**.1372**	**.1886**	**.1543**	**.168**	**.1543**	**.1463**
Avg	**.3180**	**.3007**	**.3152**	**.2885**	**.3086**	**.3285**	**.3114**

 Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
KOREGAON[119] **BU 0949**
Substation No/ Name :- 254013 / KORAGAON
Feeder No / Name : 205 / 11KV KATAPUR GAOTHAN **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926	.2743	.3174	.2572	.3361	.3086	.3292
2	.3109	.2572	.2987	.2401	.2987	.2915	.2926
3	.2926	.2401	.2614	.2229	.2614	.2743	.2561
4	.2743	.2401	.2241	.2229	.3361	.2401	.2743
5	.5304	.463	.5975	.4973	.3734	.3772	.4755
6	.7316	.6516	.7842	.7202	.7095	.7373	.7682
7	.9145	.8402	.9335	.8916	.9335	.9088	.9145
8	.8029	.6516	.8029	.7373	.8059	.703	.7682
9	.6535	.6535	.4973	.6908	.7545	.4938	.6001
10	.6535	.5601	.463	.3361	.6173	.5487	.463
11	.5228	.3174	.4287	.3734	.5144	.4755	.4115
12	.4854	.4668	.3772	.3361	.463	.4572	.3772
13	.4668	.4668	.3429	.2987	.3944	.439	.3772
14	.4668	.4294	.3429	.4294	.3429	.4207	.3601
15	.4294	.4108	.3601	.4294	.3258	.4207	.3429
16	.2614	.4854	.4115		.4287	.439	.3601
17	.3258	.5041	.4973	.5601	.4801	.5487	.3944
18	.3429	.7095	.6859	.7468		.7499	.6173
19	.583	.9149	.823	.9522	.7888	.9328	.823
20	.823	.7842	.6687	.8029	.7373	.823	.6687
21	.6859	.6535	.6001		.6344	.7499	.6173
22	.5487	.4481	.4287	.5975	.583	.6584	.5316
23	.3601	.3734	.3258	.7468	.4115	.3658	.3772
24	.807	.3086	.3174	.2915	.3361	.3429	.3475
Max	**.9145**	**.9149**	**.9335**	**.9522**	**.9335**	**.9328**	**.9145**
Min	**.2614**	**.2401**	**.2241**	**.2229**	**.2614**	**.2401**	**.2561**
Avg	**.5236**	**.5044**	**.4913**	**.5173**	**.5159**	**.5295**	**.4895**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
KOREGAON[119] **BU 0949**
Substation No/ Name :- 254013 / KORAGAON
Feeder No / Name : 206 / Shirambe-Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.869	.5487	.0381	.0305	.0572	1.5546	1.8347
2	1.9033	.5335	.0381	.0305	.0572	1.5242	1.8004
3	1.8861	.5335	.0381	.0305	.0381	1.5242	1.8176
4	1.8519	.4877	.0381	.0305	.0381	1.4937	1.8004
5	1.8347	.4572	.0762	.0305	.0953	1.4937	1.8347
6	1.8347	.5792	.0953	.0305	.0953	1.4784	1.8861
7	1.989	.7316	.1143	.0305	.0953	1.6613	1.9719
8	.0381	.0152	1.6057	1.9052	1.8747	.0305	.0514
9	.0381	.0191	1.9509	2.556	2.3472	.0343	.0457
10	.0373	.0381	1.3565	.2675	2.332	.0343	.0305
11	.0373	.0381	2.1795	2.5069	2.3624	.0514	.0305
12	.0381	.0762	2.271	2.2939	2.3624	.0343	.0152
13	.0381	.0953	2.0576	2.2119	2.1643	.0343	.0152
14	.0381	.0381	2.0576	2.4413	2.1338	.0343	.0152
15	.0381	.0381	2.1643	2.3758	2.0271	.0343	.0152
16	.0572	.0381	.0457	.0191	.0305	.0514	.0152
17	.0457	.0572	.0305	.0381	.0305	.0514	.0305
18	.0457	.0572	.0305	.0381		.0514	.0457
19	.0457	.0572	.0457	.0381	.0152	.0514	.0457
20	.0305	.0762	.0457	.0572	.0152	.0343	.0457
21	.0152	.0762	.0305		.0152	.0343	.0305
22	.0152	.0572	.0305	.0492	.0152	.0343	.0305
23	.0152	.0572	.0305	.0492	.0152	.0343	.0305
24	1.8861	.5487	.0328	.0305	.0492	1.5851	1.8176
Max	**1.989**	**.7316**	**2.271**	**2.556**	**2.3624**	**1.6613**	**1.9719**
Min	**.0152**	**.0152**	**.0305**	**.0191**	**.0152**	**.0305**	**.0152**
Avg	**.6512**	**.2190**	**.6835**	**.7431**	**.7942**	**.5394**	**.6357**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
KOREGAON[119] **BU 0949**
Substation No/ Name :- 254013 / KORAGAON
Feeder No / Name : 301 / 22 kv market yard **SHEDDABLE URBAN**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
24	1.6126
Max	1.6126
Min	1.6126
Avg	1.6126

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
KOREGAON[119] BU 0949
Substation No/ Name :- 254062 / 33/11KV WADACHIWADI S/STN
Feeder No / Name : 201 / 11KV CHIMANGAON GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3403	.4477	.543	.3582	.4119	.4344	.5493
2	.394	.5014	.543	.3658	.4119	.4344	.5847
3	.4477	.5014		.3761	.4835	.4344	.6379
4	.4784	.5373	.5973	.5316	.5552	.4525	.7087
5	.567	.6268	.6447	.6201	.6626	.5249	.7442
6	.6733	.7522	.7343	.7265	.7701	.5611	.815
7	.8505	1.1462	.8954	1.0099	.985	.7602	.9922
8	.6733	.8954	.9671	.6733	.8775	.985	.7619
9	.7087	.8596	.9036	.8775	.8417	.8859	
10		.7964	.8682	.8059	.7421	.815	.8954
11	.4298	.7602	.7087	.7164	.6878	.7087	.7701
12	.4477	.724	.5316	.7343	.6268	.6733	.6626
13	.4656	.724	.394	.5373	.6089	.6201	.6447
14	.5373	.6697	.4477	.5014	.591	.5138	.6268
15	.5731	.724	.6733	.4835	.6447	.2328	
16	.6089	.7964	.6556	.6089	.788	.3224	
17	.6984	.8326	.7619	.788	.8775	.4961	
18	.8238	.8775	.8859	.8954	.9568	.6733	.8417
19	.8417	.9492	.9745	.8954	1.0387	.9922	.9134
20	.8596	.9955	.9745	.8954		.8859	1.0208
21	.8775	.8954	.7973	.8954		.7087	.8417
22	.4298	.6805	.6201	.7701		.6201	.7522
23	.4835	1.1462	.4298	.5014		.5138	.591
24	1.0288	.4477	.5249	.394	.4298	.4706	.5316
Max	**1.0288**	**1.1462**	**.9745**	**1.0099**	**1.0387**	**.9922**	**1.0208**
Min	**.3403**	**.4477**	**.394**	**.3582**	**.4119**	**.2328**	**.5316**
Avg	**.6191**	**.7620**	**.6990**	**.6651**	**.6996**	**.6133**	**.7443**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
KOREGAON[119] **BU 0949**
Substation No/ Name :- 254062 / 33/11KV WADACHIWADI S/STN
Feeder No / Name : 202 / 11 KV CHIMANGAON AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.595	1.5261	.1086	.0914	.0934	1.5223	1.5249
2	1.5257	1.4746	.1086	.0914	.112		1.5775
3	1.5604	1.4918	.1097	.1097	.1307	1.5203	1.5775
4	1.5777	1.4575	.1097	.128	.112	1.5402	1.595
5	1.5777	1.4918	.1086	.128	.1307	1.576	1.595
6	1.595	1.5432	.1086	.1448	.0934	1.576	1.6126
7	1.647	1.7147	.1097	.1629	.112	1.6301	1.7684
8	.128	.1307	1.7193	1.6126	2.0576	.1267	.1448
9	.0914	.112	2.0285	1.9204	2.1262	.1097	
10	.0934	.1097	1.9765	2.1776	2.2857	.0914	.0934
11	.0934	.1097	2.0458	2.1948	2.3211	.1097	.112
12	.1307	.1097	2.1672	2.1434	2.3034	.128	.0934
13	.112	.1097	2.0805	2.2634	2.2744	.1097	.0934
14	.112	.1097	1.8551	2.2291	2.1794	.0914	.0747
15	.112	.1097	1.8204	2.1605	2.2325	.1097	
16	.112	.1097	.128	.056	.1086	.1463	
17	.112	.1097	.1097	.0747	.1086	.128	
18	.112	.1097	.0914	.056		.128	.112
19	.0934	.1097	.1097	.0747	.1086	.1097	.1075
20	.0934	.1097	.1097	.0934		.128	.1307
21	.112	.1097	.0914	.1307		.1097	.112
22	.0934	.1097	.1097	.112		.128	.112
23	.0934		.1097	.112		.1463	.1307
24	1.6126	1.3889	.1086	.0914	.0934	1.5746	1.5775
Max	**1.647**	**1.7147**	**2.1672**	**2.2634**	**2.3211**	**1.6301**	**1.7684**
Min	**.0914**	**.1097**	**.0914**	**.056**	**.0934**	**.0914**	**.0747**
Avg	**.5994**	**.5981**	**.7260**	**.7650**	**.9991**	**.5583**	**.7073**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
KOREGAON[119] BU 0949
Substation No/ Name :- 254062 / 33/11KV WADACHIWADI S/STN
Feeder No / Name : 203 / 11 KV Khed Gaothan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3582	.5014	.5068	.3582	.3761	.3982	.394
2	.3582	.5228	.5068	.3403	.394	.394	.394
3	.3761	.5194	.543	.4119	.4835	.3982	.4298
4	.4119	.5731	.543	.5138	.5731	.4344	.5014
5	.4835	.7164	.543	.6024	.6805	.4887	.6024
6	.5316	.7522	.5973	.6733	.7522	.5611	.6733
7	.8939	.9492	.8507	.9214	.9313	.8869	.929
8	.9391	.9492	.985	.9745	1.0208	.8059	.9214
9	.8328	.8775	.8859	.8238	.8596	.7087	
10	.7164	.7701	.7265	.7522	.7164	.5847	.6089
11	.6626	.6697	.7619	.6268	.6024	.6024	.5731
12	.6089	.6154		.5373	.567	.5847	.5552
13	.5552	.5973		.5373	.5792	.6024	.5552
14	.5014	.5611		.5373	.5552	.6024	.5552
15	.4656	.5552	.6201	.5373	.6268	.4961	.5731
16	.4477	.5611	.5847	.5731	.7059	.567	.5731
17	.5373	.6154	.6733	.6535	.724	.6201	.591
18	.591	.6697	.7265	.6626	.724	.691	.7164
19	.6089	.7701	.8505	.6268	.7701	.815	.7522
20	.6447	.8238	.8859	.6268		.7619	.788
21	.6805	.7164	.7973	.6089		.6733	.7522
22	.5014	.6268	.6201	.5194		.4835	.6984
23	.5552		.4119	.4119		.3761	.4298
24	.3403	.5373	.5249	.394	.3582	.3801	.3582
Max	**.9391**	**.9492**	**.985**	**.9745**	**1.0208**	**.8869**	**.929**
Min	**.3403**	**.5014**	**.4119**	**.3403**	**.3582**	**.3761**	**.3582**
Avg	**.5668**	**.6718**	**.6736**	**.5927**	**.6500**	**.5799**	**.6054**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
KOREGAON[119] **BU 0949**
Substation No/ Name :- 254062 / 33/11KV WADACHIWADI S/STN
Feeder No / Name : 204 / 11 KV Khed Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.262	1.166	.1097	.0739	.0747	1.7013	1.5074
2	1.262	1.166	.1086	.0914	.0934	1.7375	1.5249
3	1.3146	1.2003	.1097	.0914	.0934	1.7372	1.5424
4	1.3672	1.2689	.1086	.1097	.112	1.6832	1.5775
5	1.3847	1.2689	.1086	.1097	.0934	1.7364	1.6126
6	1.4198	1.406	.1086	.0914	.0934	1.7896	1.6651
7	1.7002	1.4746	.1097	.1097	.112	1.9936	1.8031
8	.0914	.0934	1.3073	1.6301	1.5261	.1075	.0914
9	.0739	.0373	1.8031	1.869	2.0405	.1097	
10	.056	.0366	1.9418	1.9033	2.2502	.0914	.0747
11	.056	.0366	2.1672	1.869	2.3034	.0739	.0747
12	.056	.0366	2.2712	2.3663	2.3388	.037	.0747
13	.0716	.0366	2.3752	2.2462	2.3565	.0739	.0747
14	.0716	.0362	2.2365	2.3148	2.3743	.0739	.0747
15	.0716	.1097	2.3059	2.1605	2.4977	.0554	.0747
16	.0747	.1086	.1097	.0686	.1097	.0739	.0747
17	.0747	.1097	.128	.0343	.1086	.0739	.112
18	.0934	.1097	.0914	.0934	.1086	.0739	.0934
19	.0934	.1097	.0914	.0934	.1086	.0739	.0934
20	.0934	.1097	.0914	.0934		.1097	.0934
21	.0934	.1097	.0914	.0934		.0914	.0934
22	.0747	.1097	.0914	.0934		.0739	.0934
23	.0747		.0914	.0747		.0739	.0934
24	1.3146	1.1488	.1097	.0739	.0747	1.7372	1.5424
Max	**1.7002**	**1.4746**	**2.3752**	**2.3663**	**2.4977**	**1.9936**	**1.8031**
Min	**.056**	**.0362**	**.0914**	**.0343**	**.0747**	**.037**	**.0747**
Avg	**.5102**	**.4908**	**.7528**	**.7398**	**.9435**	**.6410**	**.6114**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
KOREGAON[119] **BU 0949**
Substation No/ Name :- 254062 / 33/11KV WADACHIWADI S/STN
Feeder No / Name : 205 / 11KV Shendurjane AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0747	1.5746	1.5424	1.8861	.0732	.0914
2	.0914	.0934	1.6118	1.5775	1.8861	.0732	.1097
3	.1097	.0934	1.5939	1.56	2.0062	.0724	.0914
4	.1097	.0747	1.6476	1.6651	2.0233	.0724	.1097
5	.1097	.0747	1.7372	1.9071	2.1091	.0732	.1097
6	.1097	.0747	2.0416	2.2539	2.2291	.0724	.1097
7	.0914	.0747	2.6684	2.7046	2.692	.0724	.0914
8	1.5424	1.7147	.0724	.1097	.0934	1.8625	2.1152
9	2.3926	2.4177	.0914	.0934	.056	2.774	
10	2.6235	2.8475	.1097	.0747	.0724	3.3981	2.6063
11	2.6749	3.1184	.0914	.0934	.0724	3.4501	3.2579
12	2.7949	3.0476	.1097	.0747	.0724	3.5021	3.4122
13	2.0062	3.0121	.0914	.0747	.0732	3.1207	3.4294
14	2.1948	2.959		.0747	.0724	2.4446	3.4808
15	2.2634	2.6223	.0914	.056	.0724	3.1034	3.6694
16	.0747	.5493	.0914	.0747	.0732	.1097	.0373
17	.0747	.0732	.1097	.056	.1086	.1097	.0747
18	.0747	.0732	.0914	.0747	.1086	.1097	.0747
19	2.6749	.0724	.1097	.0747	.1086	.0914	.056
20	.0747	.0724	.0914	.0747		.1097	.056
21	.0747	.0732	.1097	.0747		.1097	.056
22	.056	.0732	.0914	.0747		.0914	.056
23	.056		.0914	.056		.0914	.0747
24	.0914	.056	1.3611	1.5074	1.8519	.0724	.0914
Max	**2.7949**	**3.1184**	**2.6684**	**2.7046**	**2.692**	**3.5021**	**3.6694**
Min	**.056**	**.056**	**.0724**	**.056**	**.056**	**.0724**	**.0373**
Avg	**.9357**	**1.0149**	**.6817**	**.6637**	**.8834**	**1.0442**	**1.0113**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
KOREGAON[119] **BU 0949**
Substation No/ Name :- 254062 / 33/11KV WADACHIWADI S/STN
Feeder No / Name : 206 / 11KV Bhatamwadi AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0739	.0934	.9412	.9214	1.1145	.1097	.0914
2	.0739	.0934	.8954	.8859	1.166	.1097	.0914
3	.0914	.112	.9313	.9391	1.0974	.1097	.1097
4	.1097	.112	.9671	1.0099	1.1462	.1097	.1097
5	.0914	.1307	1.0317	1.0631	1.2003	.1097	.1097
6	.0914	.1307	1.2178	.037	1.2517	.1097	.1097
7	.1097	.1494	1.4148	.037	1.5775	.1097	.1097
8	1.1694	1.166	.1097	.0554	.1307	1.3394	1.262
9	1.6126	1.6804	.1097	.0373	.112	1.4899	
10	1.8004	1.949	.0739	.0373	.1097	1.7528	1.8861
11	1.7661	2.073	.0739	.0373	.1097	1.9071	1.9719
12	1.869	1.9845	.0739	.0373	.1075	1.9938	2.0062
13	1.8176	1.9909	.0739	.056	.0732	1.9071	.056
14	1.5775	1.8959	.0914	.0934	.1086	1.6476	1.7318
15	1.7318	1.9313	.0914	.1307	.1086	2.0111	
16	.112	.1086	.1097	.1307	.1075	.0914	
17	.112	.1097	.1097	.112	.1097	.1097	
18	.1307	.1097	.0914	.112	.1097	.128	.112
19	.0934	.128	.128	.1307	.1086	.128	.1307
20	.112	.1097	.1097	.1307		.1097	.1494
21	.112	.128	.1097	.1307		.0914	.1307
22	.0934	.128	.1097	.1307		.1097	.1307
23	.0934		.1097	.0934		.0914	.112
24	.0739	.0934	.8869	.8859	1.046	.1097	.0914
Max	**1.869**	**2.073**	**1.4148**	**1.0631**	**1.5775**	**2.0111**	**2.0062**
Min	**.0739**	**.0934**	**.0739**	**.037**	**.0732**	**.0914**	**.056**
Avg	**.6216**	**.7134**	**.4109**	**.3015**	**.5448**	**.6577**	**.5251**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
RAHIMATPUR S/DN.[831] BU 4831
Substation No/ Name :- 254011 / TARGAON
Feeder No / Name : 201 / TARAGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1886	.6325	.7537	.7907	.1867	.1698
2	.1698	.1886	.6325	.7537	.7907	.1867	.1698
3	.1698	.1698	.6167	.7537	.7907	.1867	.1698
4	.1698	.1886	.6167	.7865	.8162	.2054	.1698
5	.2075	.1886	.6958	.8684	.8907	.2427	.2263
6	.2641	.2452	.8259	.9667	1.0082	.2801	.3206
7	.4338	.4338	1.166	1.065	1.1523	.4294	.4338
8	.4902	.8684	.3206	.3174	.3584	1.1401	1.5844
9	.5921	1.0402	.2427	.2427	.3018	1.4563	1.7204
10	.5601	1.1363	.2263	.2054	.1886	1.8351	1.9826
11	.9555	1.1227	.0171	.1867	.2075	1.6057	
12	1.004	1.0753	.0171	.2054	.2427	1.6804	2.13
13	.9172	.8539	.0171	.2241	.2054	1.7328	2.0645
14	.9962	1.1843	.0171	.2241	.2241	1.7328	2.13
15	1.0279	1.2003	.3361	.1867	.2427	1.8023	2.13
16	.2641	.2263	.3326	.2241	.2054	.2587	.1886
17	.3206	.2614	.2987	.2218	.2241	.2241	.2033
18	.3584	.3206	.3361	.3206	.2801	.2427	.2801
19	.6036	.5847	.4294	.5658	.4108	.5847	.547
20	.5093	.547	.5228	.5658	.5228	.5658	.5281
21	.4715	.4904	.4668	.4715	.4668	.5093	.4904
22	.415	.3239	.3547	.3395	.3547	.3961	.3961
23	.2452	.2286	.2241	.2075	.2241	.2263	.2452
24	.1698	.1886	.6483	.7537	.8065	.1867	.1886
Max	**1.0279**	**1.2003**	**1.166**	**1.065**	**1.1523**	**1.8351**	**2.13**
Min	**.1698**	**.1698**	**.0171**	**.1867**	**.1886**	**.1867**	**.1698**
Avg	**.4786**	**.5523**	**.4164**	**.4754**	**.4878**	**.7457**	**.8030**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
RAHIMATPUR S/DN.[831] BU 4831
Substation No/ Name :- 254011 / TARGAON
Feeder No / Name : 202 / KIROLI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.4641	.1509	.1463	.132	1.3108	1.3283
2	.4481	.4588	.132	.1463	.132	1.3108	1.3279
3	.9282	.4752	.132	.1463	.132	1.3108	1.3279
4	.4481	.4752	.132	.1463	.132	1.3108	1.3279
5	.4534	.5243	.1698	.1829	.1509	1.4091	1.3765
6	.5243	.5898	.3018	.3292	.2829	1.4746	1.5238
7	.7045	.7373	.547	.4572	.4715	1.6712	1.704
8	.4338	.4715	.7701	1.3108	1.6244	.3734	.4338
9	.3395	.3206	1.1043	1.5238	2.0885	.3206	.2829
10	.2263	.2263	1.4582	1.7204	2.1051	.2452	.1698
11	.2452	.1509	1.5546	1.7204	2.0222	.1886	
12	.2452	.2075	1.5684	1.7532	2.1963	.1698	.1698
13	.1886	.2075	1.5893		2.1963	.2263	.1886
14	.1886	.2075	.4001	1.7859	2.2801	.1886	.1886
15	.2075	.2075	1.2483	1.9006	2.1628	.2075	.2263
16	.2263	.1886	1.3123	.2054	.2054	.168	.2075
17	.2641	.1132	.2054	.3258	.2054	.2241	.1829
18	.3206	.1698	.3361	.3584	.2614	.3174	.3361
19	.5093	.5281	.4668	.5281	.3547	.4904	.5281
20	.5093	.4527	.4481	.5093	.4481	.4527	.4904
21	.4527	.4715	.3921	.4338	.4108	.4338	.4715
22	.3772	.3429	.2987	.3206	.3174	.3584	.3961
23	.1509	.2096	.1494	.1886	.168	.2263	.2263
24	.4641	.4641	.1509	.1494	.132	1.278	1.3283
Max	**.9282**	**.7373**	**1.5893**	**1.9006**	**2.2801**	**1.6712**	**1.704**
Min	**.1509**	**.1132**	**.132**	**.1463**	**.132**	**.168**	**.1698**
Avg	**.3877**	**.3610**	**.6258**	**.7082**	**.8588**	**.6528**	**.6845**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
RAHIMATPUR S/DN.[831] BU 4831
Substation No/ Name :- 254011 / TARGAON
Feeder No / Name : 203 / WATHAR SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3206	.3584	1.5415	1.8484	1.6078	.5041	.3584
2	.3206	.3395	1.5257	1.6766	1.6078	.4668	.3584
3	.3206	.3395	1.5089	1.6933	1.6078	.4668	.3584
4	.3206	.3772	1.5089	1.6933	1.6409	.4668	.3584
5	.3961	.4715	1.6078	1.7269	1.7269	.5975	.4338
6	.679	.679	1.7436	1.8107	1.8564	.6348	.6979
7	.8488	.8299	1.9281	1.8778	1.9334	.9149	.9054
8	1.6078	2.037	.7922	.7209	.9242	1.6956	2.1216
9	1.8442	1.9616	.6283	.7282	.7545	1.9725	2.4034
10	2.0957	2.1963	.4668	.5975	.7356	1.9448	2.5857
11	2.1795	2.2708	.4755	.5415	.5847	1.861	
12	2.1628	2.4366	.462	.5228	.5228	2.0056	2.6355
13	2.0056	2.3703	.462	.5041	.5228	2.1714	2.6355
14	2.0885	2.2969	.4805	.4854	.6348	2.1879	2.6355
15	2.0719	2.2634	.462	.4108	.6348	2.1714	2.6355
16	.5281	.5658	.499	.4108	.5788	.4435	
17	.547	.547	.5359	.5544	.6161	.5228	.5121
18	.6602	.679	.7095	.7095	.7095	.6535	.6468
19	1.0185	.9808	1.0642	1.1317	1.1389	1.094	.9808
20	.9997	.9997	1.0456	1.094	1.1576	1.0374	.9431
21	.8865	.9054	.9149	1.0185	1.1203	.9242	.8488
22	.7545	.6602	.7655	.8488	.9896	.7733	.679
23	.4338	.4338	.5601	.5281	.7282	.4904	.5093
24	.3395	.3584	1.5415	1.8484	1.6057	.5601	.3772
Max	**2.1795**	**2.4366**	**1.9281**	**1.8778**	**1.9334**	**2.1879**	**2.6355**
Min	**.3206**	**.3395**	**.462**	**.4108**	**.5228**	**.4435**	**.3584**
Avg	**1.0596**	**1.1399**	**.9679**	**1.0409**	**1.0808**	**1.1067**	**1.2100**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
RAHIMATPUR S/DN.[831] **BU 4831**
Substation No/ Name :- 254011 / TARGAON
Feeder No / Name : 204 / ARVI **SINGLE PHASING**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5257	1.5565	.2641	.2241	.2263	1.5074	1.8945
2	1.4922	1.6057	.2452	.2241	.2263	1.5074	1.8778
3	1.1736	1.6057	.2452	.2054	.2263	1.5074	1.861
4	1.1736	1.6057	.2452	.2427	.2452	1.5074	1.861
5	1.2742	1.7695	.3206	.2801	.2829	1.6221	1.9839
6	1.5091	1.8679	.4715	.5228	.4715	1.7859	2.2382
7	1.8442	1.9662	.6036	.6161	.5658	1.9006	2.1704
8	.415	.5079	1.6787	.7468	1.8176	.426	.547
9	.4338	.3961	2.146	2.3899	2.4926	.3584	.4715
10	.3395	.2829		2.5766	2.696	.2075	.3206
11	.2452	.2829	2.0957	2.2634	2.3807	.2452	.2452
12	.3018	.3018	2.3304	2.1795	1.9839	.2829	.2641
13	.3206	.3206	2.2131	2.2634	2.4247	.3206	.2641
14	.3018	.2829	2.3205	2.1628	2.6791	.2829	.2829
15	.2829	.2829	2.4646	2.5149	2.3908	.2829	.3018
16	.3206	.2829	.2987	.2801	.3174	.2641	.3018
17	.3961	.3395	.2987	.3018	.3361	.2801	.3174
18	.4715	.4527	.4481	.4715	.3734	.4294	.4527
19	.7545	.7545	.7282	.679	.6908	.7545	.7167
20		.7167	.6348	.6979	.6535	.7356	.6979
21	.6036	.6224	.5601	.6036	.5601	.6413	.6602
22	.5093	.4338	.4481	.4338	.4481	.5093	.5093
23	.3018	.3018	.2801	.2641	.2987	.3018	.3206
24	1.56	1.5565	.2641	.2263	.2452	1.3927	1.7436
Max	**1.8442**	**1.9662**	**2.4646**	**2.5766**	**2.696**	**1.9006**	**2.2382**
Min	**.2452**	**.2829**	**.2452**	**.2054**	**.2263**	**.2075**	**.2452**
Avg	**.7631**	**.8373**	**.9394**	**.9738**	**1.0430**	**.7939**	**.9293**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
RAHIMATPUR S/DN.[831] BU 4831
Substation No/ Name :- 254011 / TARGAON
Feeder No / Name : 205 / PWW EXPRESS NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191		.0191		.0191		.0191
2	.0191		.0191		.0191		.0191
3	.0191		.0191		.0191		.0191
4	.0191		.0191		.0191		.0191
5	.0191		.0191		.0191		.0191
6	.0191		.0191		.0191		.0191
7	.0191	.0189	.0191		.0191	.0189	.0191
8	.0191	.0189	.0191		.0191	.0189	.0191
9	.0191	.0191	.0191		.0191	.0191	
10	.0191	.0191	.0191		.0191	.0191	
11	.0191	.0191	.0191		.0191	.0191	
12	.0191	.0191	.0191		.0191	.0191	
13	.0191	.0191	.0191		.0191	.0191	
14	.0191	.0191	.0191		.0191	.0191	
15	.0191	.0191	.0191		.0191	.0191	
16	.0191	.0191	.0191		.0191	.0191	
17		.0191		.0191		.0191	.0191
18		.0191		.0191		.0191	.0191
19		.0191		.0191		.0191	.0191
20				.0191		.0191	.0191
21		.0191		.0191		.0191	.0191
22		.0191		.0191	.0187	.0191	.0191
23		.0191		.0191		.0191	.0191
24	.0686	.0189	.0191	.0189	.0191	.0189	.0191
Max	**.0686**	**.0191**	**.0191**	**.0191**	**.0191**	**.0191**	**.0191**
Min	**.0191**	**.0189**	**.0191**	**.0189**	**.0187**	**.0189**	**.0191**
Avg	**.0220**	**.0191**	**.0191**	**.0191**	**.0191**	**.0191**	**.0191**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
RAHIMATPUR S/DN.[831] BU 4831
Substation No/ Name :- 254012 / RAHIMATPUR
Feeder No / Name : 201 / PIMPARI **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.08	.0633	1.3443	1.704	1.9433	.0678	.0791
2	.061	.0648	1.3443	1.6518	1.9559	.0671	.0633
3	.0602	.0625	1.3603	1.6324	2.0008	.0678	.064
4	.0602	.064	1.3603	1.7166	1.8976	.0686	.064
5	.061	.0655	1.4083	1.7814	2.17	.0686	.0648
6	.0617	.0671	1.7652	1.8679	2.4034	.0686	.081
7	.0781	.0972	1.8785	2.0153	2.6452	.0857	.0983
8	1.9109	1.7924	.0655	.0819	.0655	1.9719	2.2611
9	2.556	2.3278	.0648	.08	.0648	2.8121	3.0312
10	2.6707	2.7349	.0648	.064	.064	3.1131	3.4899
11	2.5465	2.8178	.096	.0625	.0678	2.9329	3.2733
12	2.7206	2.6543	.096	.048	.0648	3.5719	2.8807
13	2.7965	2.6216	.08	.0655	.0678	3.3891	3.1714
14	2.8509	2.7854	.081	.08	.0503	3.4808	3.5269
15	2.753	2.4615	.0655	.0655	.0503	3.514	3.2421
16	.2881	.0671	.0972	.0848	.0671	.0655	
17	.0486	.0686	.0648	.116	.0648	.0655	
18	.0829	.0848	.08	.0633	.0671	.0655	
19	.1017	.0857	.08	.0663	.0857	.081	
20	.1147	.0838	.096	.0791	.0848	.0972	
21	.0791	.0671	.1142	.0819	.0848	.0983	
22	.0819	.0671	.0972	.0949	.0701	.081	
23	.1107	.0671	.096	.0829	.0693	.0972	.124
24	.0772	.096	1.3443	1.7368	1.8976	.0686	.096
Max	**2.8509**	**2.8178**	**1.8785**	**2.0153**	**2.6452**	**3.5719**	**3.5269**
Min	**.0486**	**.0625**	**.0648**	**.048**	**.0503**	**.0655**	**.0633**
Avg	**.9272**	**.8903**	**.5477**	**.6385**	**.7501**	**1.0833**	**1.5065**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
RAHIMATPUR S/DN.[831] BU 4831
Substation No/ Name :- 254012 / RAHIMATPUR
Feeder No / Name : 202 / BRAMHAPURI SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.4481	.4706	.4066	.3881	.4344	.4435
2	.4108	.4733	.4706	.4024	.3961	.4344	.4024
3	.4251	.4733	.4656	.4024	.4075	.439	.4024
4	.4805	.5373	.4706	.4344	.4572	.4298	.4344
5	.5601	.5853	.5014	.5487	.7888	.4887	.5175
6	.7468	.7095	.7316	.7207	.8059	.7964	.5788
7	.8871	.823	.8779	.8402	.7947	.9694	.8029
8	.8686	.7888	.8326	.8316	.7087	.8688	.7577
9	.823	.7964	.7522	.7682	.3881	.7964	.6767
10	.7316	.695	.724	.7421	.7865	.7164	.5973
11	.724	.6878	.7059	.6201	.6697	.7059	.6024
12		.6516	.5552	.5731	.6379	.7133	.6089
13	.6733	.6805	.5373	.5914	.4298	.7133	.6036
14	.7133	.6805	.5138	.547	.6154	.6516	.6468
15		.6516	.5316	.5258	.6154	.5792	.4908
16	.691	.6516	.5973	.5973	.543	.6089	.4477
17	.5175	.5373	.6089	.5487	.543	.591	.5121
18	.8764	.724	.8326	.7421	.724	.7783	.6556
19	1.0679	.9511	1.0974	.9114	.9511	.9593	.9412
20	.9877	.905	1.0164	.8596	.8688	.9055	.8328
21	.9391	.7964	.9242	.7619	.8326	.8676	.7712
22	.7964	.6878	.679	.5731	.8048	.7167	.7133
23	.4784	.5068	.5658	.4557	.5792	.5847	.5434
24	.4527	.4344	.4706	.4294	.3801	.439	.4481
Max	**1.0679**	**.9511**	**1.0974**	**.9114**	**.9511**	**.9694**	**.9412**
Min	**.4108**	**.4344**	**.4656**	**.4024**	**.3801**	**.4298**	**.4024**
Avg	**.6939**	**.6615**	**.6639**	**.6181**	**.6299**	**.6745**	**.6013**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
RAHIMATPUR S/DN.[831] BU 4831
Substation No/ Name :- 254012 / RAHIMATPUR
Feeder No / Name : 203 / SAP SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9393	1.1191	.0686	.0537	.0497	1.4403	1.2955
2	.9069	1.004	.0686	.0537	.0486	1.4403	1.2955
3	.8962	.933	.0678	.0549	.0474	1.4403	1.2963
4	.9172	1.0688	.0678	.0549	.0463	1.4403	1.3603
5	.9602	1.1934	.0678	.056	.0486	1.4575	1.4251
6	1.166	1.3283	.0678	.0549	.0663	1.5223	1.5402
7	1.4255	1.5912	.0686	.0724	.0678	1.7814	1.5402
8	.0724	.0648	.8962	1.3108	1.4529	.0655	.0678
9	.056	.0633	1.8023	1.704		.0655	.0709
10	.056	.0469	1.9334	2.0972		.0663	.0526
11	.0532	.0503	1.9989	2.2929		.0671	.0537
12	.0543		1.6221			.0686	.0549
13		.0503	2.13	2.1026	2.13	.0701	.0554
14		.0671	2.0972	2.489	2.556	.0532	.0526
15		.0686	2.0317	2.19	2.4577	.0526	.0732
16		.0678	.0655	.0554	1.873	.052	
17		.0671	.0678	.0543	2.0809	.0532	
18		.0663	.0709	.0701	1.8785	.0532	
19		.0838	.0709	.0739	.0857	.0693	
20	.0671	.0838	.0709	.0701	.0857	.0709	
21	.0791	.0678	.0709	.0895	.0838	.0709	
22	.0663	.0671	.0709	.0701	.0686	.0724	
23	.0791	.0678	.0716	.0732	.0693	.0732	.0709
24	.9393	1.1142	.0686	.0709	.0509	1.4232	1.3435
Max	**1.4255**	**1.5912**	**2.13**	**2.489**	**2.556**	**1.7814**	**1.5402**
Min	**.0532**	**.0469**	**.0655**	**.0537**	**.0463**	**.052**	**.0526**
Avg	**.5138**	**.4493**	**.6507**	**.6615**	**.7624**	**.5404**	**.6852**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
RAHIMATPUR S/DN.[831] BU 4831
Substation No/ Name :- 254012 / RAHIMATPUR
Feeder No / Name : 204 / SASURVE SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0474	.0486	.7907	.7682	.815	.0509	.0316
2	.0309	.0497	.8002	.7682	.8326	.0457	.0312
3	.0305	.0324	.8097	.7935	.8501	.0514	.0312
4	.0305	.0335	.8002	.8259	.9054	.0514	.0312
5	.0301	.0312	.8421	.8421	.8871	.0514	.0316
6	.0457	.048	.9393	.8848	.905	.0514	.048
7	.0463	.0492	.9922	.9831	.9214	.0509	.048
8	1.1174	.7907	.0486	.0655	.0549	.7682	1.2944
9	1.3279	.9995	.0503	.064	.0543	.9393	1.6876
10	1.5546	1.2967	.0503	.048	.056	1.4419	1.7204
11	1.5181	1.4419	.048	.0469	.0514	1.4419	1.4373
12		1.2742	.048	.064	.0514	1.4746	1.5813
13	1.326	1.1984	.048	.0492	.0503	1.5074	1.3108
14	1.2967	1.3108	.0474	.0509	.0503	1.5565	1.286
15		1.2631	.048	.0526	.0509	1.6057	1.4022
16	1.2929	.0509	.0486	.0543	.0503	.0492	.0724
17	1.0936	.0514	.048	.0532	.0503	.048	.0739
18	.0663	.0514	.0474	.0701	.0497	.0474	.0701
19	.0791	.0671	.0633	.0905	.0509	.0633	.0739
20	.081	.0503	.064	.0886	.0503	.0474	.0886
21	.0633	.0503	.064	.0724	.0503	.048	.0732
22	.064	.0509	.0633	.0709	.0503	.0486	.0709
23	.0469	.0503	.064	.0701	.0514	.0469	.0724
24	.8097	.0633	.8322	.7935	.8145	.0503	.0486
Max	**1.5546**	**1.4419**	**.9922**	**.9831**	**.9214**	**1.6057**	**1.7204**
Min	**.0301**	**.0312**	**.0474**	**.0469**	**.0497**	**.0457**	**.0312**
Avg	**.5454**	**.4314**	**.3191**	**.3196**	**.3231**	**.4807**	**.5257**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
RAHIMATPUR S/DN.[831] BU 4831
Substation No/ Name :- 254012 / RAHIMATPUR
Feeder No / Name : 205 / VELU GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1294	.1254	.1132	.1052	.1075	.1132
2	.132	.1227	.124	.1132	.1075	.1086	.1132
3	.132	.1254	.124	.132	.1097	.1063	.1132
4	.1509	.1463	.1433	.1886	.1494	.1075	.1509
5	.1886	.1867	.1791	.2263	.1753	.1267	.1886
6	.2829	.2401	.2896	.2829	.2507	.2534	.2829
7	.3921	.3125	.3801	.3361	.3658	.394	.415
8	.3734	.3277	.2926	.3547	.3189	.3366	.3921
9	.2957	.3353	.2561	.2772	.2926	.2534	.2957
10	.2195	.2458	.2195	.2561	.1949	.2534	.2926
11	.1753	.2303	.1612	.1928	.1791	.2195	.1402
12	.1433	.2507	.1417	.1949	.1629	.2012	.2328
13	.1063	.2328	.1254	.1612	.1417	.2033	.0914
14	.1267	.2172	.1254	.1307	.124	.128	.1928
15	.1254	.1791	.124	.1387	.1433	.1267	.2149
16	.1402	.1612	.1753	.2126	.1433	.1254	
17	.1829	.1629	.1402	.1734	.197	.181	
18	.2629	.2534	.2353	.2303	.2534	.3142	
19	.499	.3982	.4207	.4572	.4163	.4294	
20	.4938	.362	.3547	.4108	.362	.3961	
21	.443	.3258	.3206	.3189	.3258	.3395	
22	.3439	.2534	.2263	.2218	.181	.2452	
23	.1417	.3258	.1509	.1227	.1267	.1509	.1402
24	.132	.1267	.1448	.1132	.1075	.1086	.132
Max	**.499**	**.3982**	**.4207**	**.4572**	**.4163**	**.4294**	**.415**
Min	**.1063**	**.1227**	**.124**	**.1132**	**.1052**	**.1063**	**.0914**
Avg	**.2340**	**.2355**	**.2075**	**.2233**	**.2056**	**.2174**	**.2060**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
RAHIMATPUR S/DN.[831] BU 4831
Substation No/ Name :- 254012 / RAHIMATPUR
Feeder No / Name : 206 / 11KV Dhamner Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2483	1.2498	.0503	.0274	.0549	1.6762	1.5565
2	1.2483		.0497	.0297	.056	1.6964	1.5238
3	1.2308		.0503	.0366	.0526	1.6842	1.4899
4	1.2289	1.1736	.0503	.0305	.0358	1.6842	1.4723
5	1.278	1.2616	.0503	.032	.0366	1.6842	1.5056
6		1.2323	.0503	.0328	.056	1.7166	1.5402
7	.3479	1.247	.0503	.0339	.0701	1.7368	1.6712
8		.0474	1.278	1.7859	1.9342	.0587	.0305
9		.0648	1.8679	1.9989		.0587	.0337
10		.0497	1.8023	2.2119		.0587	.0309
11		.0457	2.0317	2.2245		.0297	
12		.0503	1.9006	1.7465		.0305	
13		.0503	2.0317	2.1498	2.3922	.0229	
14			1.9989	2.2386	2.3594	.0282	
15			1.9826	2.2131	2.42	.0297	
16			.0314	.0739	2.2348	.0312	.048
17		.0509	.0495	.0532	2.1052	.0354	.0492
18	.0781	.0686	.0381	.0724	1.9757	.0366	.0469
19	.0819	.0671	.0486	.0709	.0671	.0332	.0791
20	.0791	.0671	.0457	.0732	.0594	.0291	.0625
21	.0983	.0594	.041	.0701	.0594	.0351	.0633
22	.0633	.0671	.0372	.0914	.0452	.0305	.0497
23	.0655	.0587	.0314	.0701	.0463	.04	.0625
24	1.2955	1.2643	.0503	.0305	.0716	1.6964	1.5729
Max	**1.2955**	**1.2643**	**2.0317**	**2.2386**	**2.42**	**1.7368**	**1.6712**
Min	**.0633**	**.0457**	**.0314**	**.0274**	**.0358**	**.0229**	**.0305**
Avg	**.6418**	**.4303**	**.6508**	**.7249**	**.8066**	**.5901**	**.6784**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
RAHIMATPUR S/DN.[831] BU 4831
Substation No/ Name :- 254081 / 33/11 KV Sasurve
Feeder No / Name : 201 / 11 KV Dughi AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
24	.9145
Max	.9145
Min	.9145
Avg	.9145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA (U)[117] **BU 0914**
Substation No/ Name :- 253001 / 22/22 KV POWAINAKA SWIT. STN
Feeder No / Name : 301 / 22KV RAJWADA **SHEDDABLE URBAN**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1949	1.5089	1.419	1.3443	1.1576	1.3817	1.3443
2	1.1949	1.6221	1.419	1.3443	1.1203	1.3443	1.1949
3	1.1949	1.8861	1.3443	1.3203	1.1203	1.1949	1.1949
4	1.1949	1.4712	1.3443	1.4335	1.1203	1.1949	1.1949
5	1.4335	1.4335	1.3443	1.4335	1.4335	1.3443	1.2323
6	2.1879	1.9239	2.1125	1.8484	2.037	1.9616	1.9616
7	2.6783	2.7161	2.8292	2.4143	2.452	2.7538	2.7161
8	2.9801	2.9127	3.0933	2.8292	2.6406	2.9424	2.9801
9	2.7915	2.7721	2.8292	2.2779	2.7633	2.6406	2.7161
10	2.5019	2.3285	2.4143	2.3899	2.5019	2.4272	2.5652
11	2.3285	2.2916	2.3765	2.2779	2.3899	2.3899	3.6961
12	2.2177	2.1216	2.1948	2.0328	2.1068	2.1807	3.2442
13	2.1068	2.0851	2.0485	1.8671	2.0698	2.1807	2.5133
14	2.0698	1.829	1.9418	1.6804	1.8111	1.9387	1.8111
15	1.9589	1.8111	1.8671	1.6598	1.7741	1.9387	3.5482
16	1.8671	1.7924	1.7741	1.9418	1.6632	1.922	2.1807
17	2.1879	2.0698	1.885		2.2177	2.1068	2.1132
18	2.6406	2.9938	2.5503	2.6139	2.8753	2.9569	4.489
19	3.5101	3.3981	3.2861	3.062	3.3573	3.4374	5.2652
20	3.2819	3.1367	2.9874	2.8753	3.0994	3.0994	4.8918
21		2.7633	2.726	2.5133	2.7538	2.726	4.3317
22	2.452	2.3899	2.2779	2.1437	2.3899	2.3525	3.7342
23	2.4272	1.7551	1.7924	2.2634	1.8671	1.8298	2.9874
24	1.3817	1.4335	1.4937	1.3443	1.2936	1.531	1.419
Max	**3.5101**	**3.3981**	**3.2861**	**3.062**	**3.3573**	**3.4374**	**5.2652**
Min	**1.1949**	**1.4335**	**1.3443**	**1.3203**	**1.1203**	**1.1949**	**1.1949**
Avg	**2.1645**	**2.1853**	**2.1396**	**2.0396**	**2.0840**	**2.1573**	**2.7219**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA (U)[117] BU 0914
Substation No/ Name :- 253001 / 22/22 KV POWAINAKA SWIT. STN
Feeder No / Name : 302 / 22KV SANGAM NAGAR SHEDDABLE URBAN
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8299	.9054	.9054	1.0562	.7545	.8299	.8299
2	.8299	.9808	.8299	1.0562	.7545	.8299	1.5089
3	.8299	1.0562	.7545	.9054	.7545	.7545	.7545
4	.8676	1.1317	.7545	.9054	.7545	.7922	.7545
5	.9808	1.1317	.7922	.9431	.9431	.7922	.8299
6	1.1317	1.1694	1.0185	.9431	1.0562	.9808	.9808
7	1.2071		1.2449	1.1317	1.1694	1.2449	1.2449
8	1.2449	1.2449	1.3203	1.2071	1.1694	1.358	1.3957
9	1.358	1.358	1.5089	1.1317	1.2826	1.358	1.3957
10	1.5089	1.5089	1.5844	1.2449	1.2071	1.5684	1.1317
11	1.5844	1.5466	1.5844	1.3203	1.2071	1.643	
12	1.5844	1.5466	1.5089	.9808	1.094	1.5893	
13	1.5466	1.5466			1.094	1.7372	
14	1.5089	1.4712		1.1317	.9808	1.5466	
15	1.4335	1.3957	1.5089	1.1317	.9808	1.5089	
16	1.4712	1.4335	1.4712	1.094	.9808	1.5844	
17	1.5466	1.4712	1.4335	1.2449	1.1317	1.5844	
18	1.4712	1.5466	1.4712	1.358	1.2449	1.6057	1.9616
19	1.4712	1.6221	1.5466	1.4335	1.4335	1.643	1.9616
20	1.5466	1.4335	1.4335	1.3957	1.3203	1.4712	1.6975
21		1.3203	1.2826	1.2826	1.2826	1.3203	1.5089
22	1.6598	1.2071	1.1694	1.1317	1.1576	1.2071	1.3203
23		.9808	.9808	.9431	.9808	.9808	1.1317
24	.8676	.9054	.9054	1.1317	.8299	.9054	.8299
Max	**1.6598**	**1.6221**	**1.5844**	**1.4335**	**1.4335**	**1.7372**	**1.9616**
Min	**.8299**	**.9054**	**.7545**	**.9054**	**.7545**	**.7545**	**.7545**
Avg	**1.2946**	**1.3006**	**1.2277**	**1.1350**	**1.0652**	**1.2848**	**1.2493**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA (U)[117] **BU 0914**
Substation No/ Name :- 253001 / 22/22 KV POWAINAKA SWIT. STN
Feeder No / Name : 303 / 22 KV GOLIBAR **SHEDDABLE URBAN**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8589	.8676	.8962	.8962	.8215	.8589	.8962
2	.8215	.9054	.8589	.8962	.8215	.8589	.8962
3	.8215	.8676	.8589	.8676	.8215	.8215	.8589
4	.8215	.7545	.8589	.9431	.8215	.8215	.8962
5	1.0562	.9054	.8962	.9335	1.0456	.8962	.9709
6	1.4335	1.4712	1.2826	1.0829	1.358	1.2071	1.2449
7	1.6975	1.7551	1.773	1.5684	1.6221	2.0748	2.0748
8	1.8861	1.8671	1.9616	1.8484	1.8484	1.9239	2.1125
9	1.6975	1.7924	1.6975	1.5089	1.7551	1.6975	1.8107
10	1.5466	1.5684	1.4563	1.5844		1.419	1.5089
11	1.4784	1.5154	1.4563	1.4712	1.4937	1.419	
12	1.3676	1.2936	1.2803	1.358	1.3676	1.3676	
13	1.2567	1.2567	1.2071	1.3957	1.2197	1.2567	
14	1.2197	1.1827	1.1949	1.0185	1.1088	1.2197	
15	1.1576	1.1827	1.1203	1.0185	1.1088	1.1827	1.8107
16	1.2323	1.1458	1.1088	1.0185	1.0719	1.2197	1.4563
17	1.307	1.1458	1.1827	1.1317	1.2323	1.3306	1.3535
18	2.1502	1.7372	1.5524	1.5684	1.4712	1.7193	1.5729
19		2.0538	1.9589	1.9044	1.9616	2.0698	2.1285
20	2.037	1.9418	1.9044	1.8298	1.8861	1.9044	1.9791
21		1.7551	1.7551	1.6632	1.7353	1.7177	1.8671
22	1.6221	1.531	1.4937	1.4045	1.4937	1.4937	1.643
23		1.1576	1.1949	1.1088	1.1576	1.1949	1.307
24	.9709	.8676	.9709	.8962	.8871	.9335	.9709
Max	**2.1502**	**2.0538**	**1.9616**	**1.9044**	**1.9616**	**2.0748**	**2.1285**
Min	**.8215**	**.7545**	**.8589**	**.8676**	**.8215**	**.8215**	**.8589**
Avg	**1.3543**	**1.3551**	**1.3300**	**1.2882**	**1.3092**	**1.3587**	**1.4680**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA (U)[117] **BU 0914**
Substation No/ Name :- 253001 / 22/22 KV POWAINAKA SWIT. STN
Feeder No / Name : 304 / 22KV CIVIL HOSPITAL **NON SHEDDABLE EXPRESS HV FEEDERS**
Feeder KV- 22 / OUTGOING **(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0381	.0381	.0381	.0381	.0381
2	.0381	.0381	.0381	.0381	.0381	.0381	.0381
3	.0381	.0762	.0381	.0381	.0381	.0381	.0381
4	.0762	.0762	.0381	.0381	.0381	.0381	.0381
5	.0762	.0762	.0381	.0381	.0381	.0381	.0381
6	.0762	.0762	.0381	.0381	.0381	.0381	.0762
7	.0381	.0762	.0381	.0381	.0381	.0762	.0381
8	.0762	.0762	.0762	.0381	.0762	.0381	.0762
9	.0762	.0762	.0762	.0754	.0762	.0762	.0762
10	.0762	.0762	.0762	.0762	.0762	.0762	.0762
11	.0762	.0762	.0762	.0762	.0381	.0762	.0762
12	.0762	.0762	.0762	.0762	.0381	.0762	.0762
13	.0381	.0762	.0762	.0762	.0381	.0762	.0762
14	.0762	.0762	.1143	.0762	.0381	.0762	.0762
15	.0762	.0381	.1143	.0762	.0381	.0762	.0381
16	.0762	.0762	.0762	.0762	.0381	.0762	.0762
17	.0762	.0381	.0381	.0762	.0762	.0762	.0381
18	.0762	.0381	.0381	.0762	.0762	.0381	.0381
19	.0762	.0381	.0381	.0381	.0762	.0381	.0381
20	.0754	.0762	.0762	.0762	.0762	.0381	.0762
21		.0762	.0381	.0762	.0762	.0762	.0762
22	.0381	.0381	.0381	.0381	.0381	.0762	.0381
23		.0381	.0381	.0381	.0381	.0381	.0381
24	.0762	.0381	.0381	.0381	.0381	.0381	.0381
Max	**.0762**	**.0762**	**.1143**	**.0762**	**.0762**	**.0762**	**.0762**
Min	**.0381**	**.0381**	**.0381**	**.0381**	**.0381**	**.0381**	**.0381**
Avg	**.0658**	**.0619**	**.0572**	**.0571**	**.0508**	**.0572**	**.0556**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA (U)[117] **BU 0914**
Substation No/ Name :- 254010 / 33/22 KV OLD MIDC SS
Feeder No / Name : 301 / 22KV OLD MIDC **SHEDDABLE FEEDER HAVING WEEKLY**
Feeder KV- 22 / OUTGOING **STAGGERING (MIDC, EQUIVALENT)**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2972	.5144	.5316	.5316	.5601	.5548	.5014
2	.2934	.5609	.5373	.4908	.5544	.583	.5121
3	.3384	.5609	.5258	.4557	.543	.583	.543
4	.3963	.6024	.5487	.4908	.5373	.6241	.5201
5	.4108	.6089	.4854	.4854	.5853	.6241	.5373
6	.4999	.6089	.407	.4854	.6219	.6173	.5609
7	.5967	.4744	.4534	.426	.6805	.583	.5765
8	.3628	.4641	.3704	.426	.5731	.5895	.4687
9	.695	.7545	1.0185	.6722	.9054	.8676	.3772
10	.8299	.9054	1.2071	.7545	1.094	.9431	.4344
11	.8764	3.7346	.9808	.8676	.9808	1.2071	.4801
12	1.0562	1.1317	.9808	1.094	1.1317	1.1317	.4656
13	.8676	1.0562	.7922	1.0185	.7922	.9808	.4298
14	.9808	1.0562	1.1317	.9431	.9808	.9808	.394
15	1.1317	1.2826	1.2071	1.1694	.9808	1.0185	.3521
16	1.094	1.1694	1.1694	.9808	1.0185	1.094	.3521
17	.8676	.8676	.9054	.8676	.8299	.8383	.3887
18	.7392	1.2071	.7922	.7922	.6283	.8676	.421
19	.5601	.7167		.7922	.6722	.8676	.3018
20	.5853	.6036	.6036	.5658	.4656	.7167	.3018
21	.4508	.5658	.4904	.679	.543	.679	.431
22	.5373	.5087	.4508	.5601	.5014	.679	.431
23	.4557	.4557	.4252	.543	.5853	.5914	.4409
24	.3612	.503	.5548	.5316	.5792	.5609	.6283
Max	**1.1317**	**3.7346**	**1.2071**	**1.1694**	**1.1317**	**1.2071**	**.6283**
Min	**.2934**	**.4557**	**.3704**	**.426**	**.4656**	**.5548**	**.3018**
Avg	**.6368**	**.8714**	**.7204**	**.6926**	**.7227**	**.7826**	**.4521**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA (U)[117] **BU 0914**
Substation No/ Name :- 254010 / 33/22 KV OLD MIDC SS
Feeder No / Name : 302 / 22 KV KARMVEER NAGAR **SHEDDABLE URBAN**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6348	.7468	.7167	.7095	.6348	.679	.7023
2	.7392	.7545	.6722	.679	.6413	.6722	.7023
3	.7842	.7922	.7023	.679	.6722	.6722	.7095
4	.8962	.8676	.7842	.7167	.7095	.7922	.8299
5	1.1949	.9431	.9808	.8299	.7468	.9431	1.0562
6	1.6263	1.1317	1.094	.9808	.9808	1.2071	1.2323
7	1.8671	1.8861	1.9616	1.6975	1.6975	1.9993	.7095
8	1.8107	1.8484	1.8861	1.9616	1.8861	1.8861	2.0165
9	1.5089	1.4712	1.5466	1.6804	1.4712	1.4335	1.531
10	1.2323	1.0562	1.2071	1.4563	1.2826	1.2071	1.3032
11	.9808	.9054	.9808	.9979	1.094	.9808	.9335
12	.9431	.9808	.9054	.961	1.0185	.8299	.8299
13	.8299	.8676	.7545	.8501		.9054	.7922
14	.8299	.8676	.7545	.7392	.9431	.8676	.7545
15	.7922	.7922	.7167	.7392	.8299	.8299	.7167
16	.7545	.8299	.7545	.7842	.8676	.8676	.7545
17	.8676	.9054	.8299	.8299	.9431	1.0082	.8299
18	1.3203	1.2071	1.1694	1.1317	1.2449	1.4335	1.2071
19	1.6975	1.6975	1.6598	1.5844	1.6221	1.8107	1.5466
20	1.7353	1.5844	1.5844	1.4712	1.5844	1.7353	1.5089
21	1.5089	1.4712	1.4335	1.419	1.4712	1.5089	.3361
22	1.2696	1.2826	1.2449	1.1694	1.2826	1.3203	1.1317
23	1.0082	.8962	.8962	.8299	.9431	1.3203	1.0562
24	.7468	.7095	.6722	.7095	.6413	.7167	.7468
Max	**1.8671**	**1.8861**	**1.9616**	**1.9616**	**1.8861**	**1.9993**	**2.0165**
Min	**.6348**	**.7095**	**.6722**	**.679**	**.6348**	**.6722**	**.3361**
Avg	**1.1491**	**1.1040**	**1.0795**	**1.0670**	**1.0960**	**1.1511**	**.9974**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA (U)[117] **BU 0914**
Substation No/ Name :- 254010 / 33/22 KV OLD MIDC SS
Feeder No / Name : 303 / 22KV MAHARASHTRA SCOOTERS SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5201	1.5089	1.6804	1.5466	1.5844	1.5089	1.5844
2	.5487	1.4712	1.7002	1.5844	1.6598	1.5844	1.4937
3	.5335	1.4712	1.6804	1.5844	1.6221	1.6598	1.419
4	.5441	1.5466	1.643	1.6221	1.5844	1.6221	1.358
5	.5201	1.5089	1.6263	1.6221	1.5684	1.6598	1.3443
6	.5361	1.5089	1.643	1.6221	1.5844	1.6598	1.3443
7	.5533	1.4712	1.7353	1.6221	1.6975	1.4335	1.5844
8	1.3676	1.5844	1.3957	1.5844	1.358	1.5844	1.4118
9	1.6598	1.9616	1.8484	1.9616	1.8484	2.0748	.5361
10	1.9616	1.9616	1.9993	2.1502	2.037	2.037	.5441
11	1.9993	2.3011	1.9993	2.2634	2.1125	2.4143	.5716
12	1.9993	2.0748	2.0748	2.037	1.9616	2.1502	.4706
13	1.773	1.7353	1.8107	1.8484	1.6598	1.9616	.4733
14	2.2257	2.1502	2.1502	2.0748	2.0748	2.2634	.4801
15	1.9616	2.1125	2.0748	2.0748	1.9239	2.2257	.6661
16	1.8861	2.1125	1.8861	1.8107	1.3203	2.037	.4961
17	1.9239	2.0748	1.8484	1.307	1.9239	2.0748	.3829
18	2.037	1.9993	1.9993	.9054	1.9239	2.0576	.4108
19	2.037	1.773	1.7353	1.8107	1.773	1.8107	.4557
20	1.8484	1.6598	1.8484	1.6598	1.4335	1.6975	.4321
21	1.7353	1.6975	1.8107	1.6975	1.5466	1.8107	.3361
22	1.6598	1.7551	1.6975	1.5844	1.6221	1.8861	.381
23	1.6975	1.8671	1.773	1.7909	1.5089	1.5844	.4039
24	.5921	1.5089	1.6598	1.5089	1.531	1.5089	1.3957
Max	**2.2257**	**2.3011**	**2.1502**	**2.2634**	**2.1125**	**2.4143**	**1.5844**
Min	**.5201**	**1.4712**	**1.3957**	**.9054**	**1.3203**	**1.4335**	**.3361**
Avg	**1.4217**	**1.7840**	**1.8050**	**1.7197**	**1.7025**	**1.8461**	**.8323**

 Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA (U)[117] **BU 0914**
Substation No/ Name :- 254010 / 33/22 KV OLD MIDC SS
Feeder No / Name : 304 / 22KV DOBURG **SHEDDABLE FEEDER HAVING WEEKLY**
Feeder KV- 22 / OUTGOING **STAGGERING (MIDC, EQUIVALENT)**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7924	3.3951	3.062	3.2442	2.0911	2.3388	3.6214
2	1.6975	3.2819	3.062	3.3196	2.1658	2.4897	3.546
3	1.6221	3.2065	3.2065	3.0933	2.1502	2.5652	3.5082
4	1.6804	2.9424	3.2442	2.9424	2.1125	2.5652	3.4705
5	1.773	2.7161	3.2065	2.7161	2.1879	2.6406	3.4705
6	1.8298	2.6029	3.3196	2.6029	2.2634	2.6406	3.3951
7	1.885	2.6783	2.9047	3.546	2.7915	2.3765	3.3196
8	2.1285	2.5274	2.3765	2.2257	3.0178	2.452	1.6975
9	1.9418	4.1872	2.7161	2.452	4.0741	2.3765	1.3957
10	1.8671	4.6776	4.3381	4.6776	4.1495	3.4328	1.4335
11	2.5652	3.8855	4.0364	5.0549	3.9986	4.1118	1.4712
12	4.1872	4.5268	5.0172	4.6776	3.7346	4.1118	1.4335
13	2.8292	4.3004	3.4705	3.7346	4.225	3.546	1.3203
14	3.9986	4.489	3.6969	4.0741	3.8477	3.6591	1.2449
15	4.1495	4.4513	4.8285	4.1118	4.7154	3.81	1.1694
16	3.5837	3.2442	3.8855	4.4136	4.3381	3.3653	1.1694
17	3.4328	3.5837	4.3004	4.1495	3.1687	3.2442	1.3203
18	3.3573	4.0364	3.8855	3.3573	3.0178	2.1502	1.3203
19	2.6783	2.1125	2.8292	3.3951	2.9047	2.0748	1.3203
20	3.3573	3.2819	2.6783	3.0933	2.452	3.3951	1.3203
21	2.6783	3.3196	2.4897	3.2442	2.4897	3.0933	1.3203
22	3.2065	2.6783	2.5274	2.6783	2.4143	2.9047	1.2826
23	3.3573	3.6214	3.546	3.6214	2.5274	2.8669	1.2826
24	1.2071	3.3951	2.8292	3.2065	2.037	2.2257	2.0748
Max	**4.1872**	**4.6776**	**5.0172**	**5.0549**	**4.7154**	**4.1118**	**3.6214**
Min	**1.2071**	**2.1125**	**2.3765**	**2.2257**	**2.037**	**2.0748**	**1.1694**
Avg	**2.6169**	**3.4642**	**3.3940**	**3.4847**	**3.0365**	**2.9349**	**1.9962**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA (U)[117] **BU 0914**
Substation No/ Name :- 254033 / 33/22 KV KARANJE SS
Feeder No / Name : 301 / 22KV KARANJE MIDC **SHEDDABLE FEEDER HAVING WEEKLY**
Feeder KV- 22 / OUTGOING **STAGGERING (MIDC, EQUIVALENT)**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2743	.2957	.2587	.2926	.2743	.2957
2	.1715	.2743	.2587	.2587	.2926	.2743	.2957
3	.1715	.2743	.2957	.2587	.2926	.2743	.2957
4	.1715	.2401	.2587	.2587	.2926	.2743	.2957
5	.1715	.2401	.2587	.2587	.2926	.2743	.2957
6	.1715	.2401	.2507	.2587	.2926	.2743	.2957
7	.2058	.2401	.2957	.2587	.3292	.2743	.2587
8	.2401	.2743	.2926	.2957	.3292	.2743	.2587
9	.2401	.3696	.3696	.3292	.3429	.3086	.2218
10	.2401	.3696	.2957	.362	.3429	.4115	
11	.2743	.4481	.2957	.439	.4115	.4801	
12	.3429	.362	.2957	.4024	.4115	.4458	
13	.3429	.3658	.3326	.3982	.4115	.4115	
14	.3429	.2987	.3696	.3982	.4115	.4115	
15		.3734	.3696	.4066		.4115	
16	.3429	.3734	.2957	.3658		.3429	
17	.4115	.3982	.4066	.4527	.3772	.4066	
18	.4115	.3734	.3696	.4755	.3772	.4066	
19	.3429	.3658	.3696	.4527	.4458	.4066	
20	.3086	.2926	.3326	.3292	.3086	.2957	
21	.3086	.3292	.2957	.3292	.3086	.3326	.1478
22		.3292	.2957	.3292	.2401	.2957	.1463
23	.2743	.2926	.2587			.2957	.1463
24	.1715	.2743	.2926	.2587	.2561	.2743	.2957
Max	**.4115**	**.4481**	**.4066**	**.4755**	**.4458**	**.4801**	**.2957**
Min	**.1715**	**.2401**	**.2507**	**.2587**	**.2401**	**.2743**	**.1463**
Avg	**.2650**	**.3197**	**.3105**	**.3407**	**.3362**	**.3388**	**.2500**

 Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA (U)[117] **BU 0914**
Substation No/ Name :- 254033 / 33/22 KV KARANJE SS
Feeder No / Name : 302 / 22KV PRATAPGANJ PETH **SHEDDABLE URBAN**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9602	.9259	.9511	.961	.9145	.7545	1.1088
2	.9602	.9259	.9979	.961	.9877	.7545	1.0719
3	.9602	.9259	.9877	.961	.9877	.7545	1.0719
4	1.0631	1.0288	2.1216	.961	.9877	.7545	1.0719
5	1.2346	1.2003	1.0242	1.1088	1.0242	.9602	1.0719
6	1.4746	1.3717	1.4632	1.4415	1.3535	1.0974	1.7741
7	1.7147	1.8519	1.9909	2.0328	1.9022	1.8519	2.2177
8	2.0233	2.0576	2.1948	2.2177	2.1948	2.0576	2.1807
9	1.8861	2.0485	2.0328	1.9909	1.9547	1.8861	1.7924
10	1.7833	1.7551	1.4415	1.848	1.7833	1.5432	
11	1.7147	1.39	1.4045	1.5729	1.5089	1.3375	
12	1.5432	1.3169	1.3676	1.448	1.4403	1.2003	
13	1.2346	1.1706	1.3306	1.448	1.4403	1.2003	
14	1.0974	1.2696	1.2936	1.2437	1.3717	1.2003	
15		.8871	1.2567	1.2071		1.2003	
16	1.0288	1.267	1.1827	1.2803		1.2003	
17	1.2346	1.3676	1.3676	1.4266	1.3032	1.4784	
18	1.3717	1.5893	2.1437	1.7558	1.3717	2.1807	
19	2.2291	2.4143	2.4025	2.3777	2.1262	2.3655	
20	2.2291	2.3411	2.2916	2.3655	2.1605	2.2546	
21	2.0576	2.1216	2.1068	2.1216	2.1262	2.1807	
22		1.848	1.7002	1.922	1.7833	1.7741	
23	1.3717	1.3169	1.2197			1.2197	
24	1.0288	1.0288	1.0242	.961	.9877	.9259	1.1088
Max	**2.2291**	**2.4143**	**2.4025**	**2.3777**	**2.1948**	**2.3655**	**2.2177**
Min	**.9602**	**.8871**	**.9511**	**.961**	**.9145**	**.7545**	**1.0719**
Avg	**1.4637**	**1.4759**	**1.5541**	**1.5484**	**1.5100**	**1.4222**	**1.4470**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA (U)[117] **BU 0914**
Substation No/ Name :- 254033 / 33/22 KV KARANJE SS
Feeder No / Name : 303 / 22KV SUSHAMA **SHEDDABLE URBAN**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.3429	.3658	.2957	.3658	.3429	.4066
2	.3772	.3429	.3658	.2957	.3292	.3429	.4066
3	.3772	.3429	.3658	.2957	.3292	.3429	.4066
4	.4458	.3429	.3658	.2957	.3292	.3429	.4066
5	.5144	.3429	.3696	.3696	.3292	.4801	.4066
6	.583	.583	.5487	.5175	.439	.6173	.7392
7	.6859	.823	.9145	.7762	.7316	.823	.961
8	.8573	.9259	.961	.924	.9145	.8916	.9979
9	.7202	.7602	.7023	.7964	.7545	.7888	.8048
10	.6859	.7316	.5914	.7392	.6859	.7202	
11	.6173	.6219	.5914	.6653	.6516	.6516	
12	.6173	.5975	.6283	.6283	.583	.583	
13	.6173	.5068	.5175	.5792	.5487	.5144	
14	.583	.5121	.4805	.5914	.5144	.5144	
15		.5121	.5175	.5121		.5144	
16	.6173	.5853	.5175	.5487		.583	
17	.6173	.6584	.5175	.5853	.5487	.5544	
18	.6859	.7316	.7023	.6219	.6173	.7762	
19	.823	.8779	.7762	.7682	.7202	.7762	
20	.7545	.8048	.7023	.695	.6516	.7392	
21	.6859	.695	.5914	.7023	.6173	.7023	
22		.6219	.5175	.5853	.5144	.5544	
23	.4801	.439	.4066			.4435	
24	.4115	.4115	.3696	.3326	.3658	.3429	.4066
Max	**.8573**	**.9259**	**.961**	**.924**	**.9145**	**.8916**	**.9979**
Min	**.3772**	**.3429**	**.3658**	**.2957**	**.3292**	**.3429**	**.4066**
Avg	**.5986**	**.5881**	**.5578**	**.5705**	**.5496**	**.5809**	**.5943**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA (U)[117] **BU 0914**
Substation No/ Name :- 254033 / 33/22 KV KARANJE SS
Feeder No / Name : 304 / 22 KV MANGALWAR TALE **SHEDDABLE URBAN**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.0288	1.0242	.924	.9877	.9602	1.1088
2	.9602	1.0288	1.0349	.924	.9877	.9602	1.1088
3	.9602	1.0288	1.0608	.924	.9979	.9602	1.1088
4	1.0974	1.3032	1.0608	.961	.9877	1.0288	1.1088
5	1.2346	1.3717	1.0608	1.1088	.9877	1.0974	1.1088
6	1.6804	1.5432	1.5364	1.5524	1.4266	1.5089	1.848
7	1.8861	1.7833	1.9959	1.8111	1.7375	1.8519	2.2177
8	1.989	1.9547	2.0995	2.0698	1.9022	2.0576	2.4394
9	1.9204	1.9753	1.9589	2.0851	1.989	1.989	
10	1.8519	1.7924	1.922	2.0119	1.8519	1.8861	
11	1.7147	2.0119	1.885	1.8099	1.8861	1.8519	
12	1.7147	1.829	1.848	1.6461	1.8519		
13	1.6804	1.7924	2.2546	1.5203	1.8519	1.8176	
14	1.5432	1.829	1.6632	1.4118	1.7833	1.7833	
15		1.7924	1.5524	1.3535		1.6118	
16	1.5089	1.5729	1.6263	1.39		1.5432	.6584
17	1.6118	1.6827	1.7002	1.6461	1.5775	1.848	.6584
18	2.0576	2.3045	2.7351	1.9022	1.7833	2.7721	1.848
19	2.7092	2.809	2.7351	2.5133	2.572	2.7721	3.4385
20	2.572	2.6337	2.5133	2.268	2.4691	2.5133	3.4751
21	2.4006	2.1807	2.0328	1.9959	2.4006	2.0698	2.9569
22		1.7924	1.6632	1.7558	1.7147	1.7002	2.5873
23	1.4403	1.3535	1.2936			1.2936	1.9387
24	1.0631	1.0288	1.0719	1.0349	1.0242	.9602	1.1458
Max	**2.7092**	**2.809**	**2.7351**	**2.5133**	**2.572**	**2.7721**	**3.4751**
Min	**.9602**	**1.0288**	**1.0242**	**.924**	**.9877**	**.9602**	**.6584**
Avg	**1.6648**	**1.7260**	**1.7220**	**1.5922**	**1.6557**	**1.6886**	**1.8092**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA (U)[117] **BU 0914**
Substation No/ Name :- 254033 / 33/22 KV KARANJE SS
Feeder No / Name : 305 / 22 KV S. T. STAND **SHEDDABLE URBAN**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9259	1.0288	.9511	.8501	.9511	.7545	1.1088
2	.8916	1.0288	.961	.8501	.905	.7545	1.1088
3	.8916	1.0288	.9877	.8501	.905	.823	1.0719
4	.9945	1.2003	.9877	.8501	.9511	.8916	1.0719
5	1.2003	1.3717	1.0242	.961	.9511	1.0288	1.0719
6	1.4403	1.5432	1.3169	1.3306	1.2803	1.3717	1.7741
7	1.7147	1.7147	2.0485	1.885	1.829	1.749	2.0698
8	1.8519	1.8519	2.1216	2.0328	1.9022	1.5432	2.1068
9	1.6804	1.7924	1.848	1.922	1.5432	2.0576	1.8656
10	1.3717	1.7193	1.6263	1.6651	1.3717	1.7147	
11	1.3032	1.7193	1.5524	1.6289	1.5089	1.5432	
12	1.2346	1.6289	1.4045	1.4998	1.3717	1.3717	
13	1.3717	1.5729	1.4045	1.4632	1.3717	1.3717	
14	1.2346	1.4632	1.4045	1.3394	1.2346	1.3717	
15		1.4266		1.3169		1.3717	
16	1.2346	1.4266	1.3306	1.267		1.3717	
17	1.406	1.4998	1.4045	1.3535	1.3717	1.5893	
18	1.5432	1.9022	2.1437	1.6461	1.4403	2.2916	
19	2.1948	2.3285	2.0698	2.0851	1.989	2.2546	
20	1.989	2.1807	1.9589	1.9387	1.8861	2.0698	
21	1.7147	1.9387	1.7741	1.7558	1.7833	1.922	
22		1.6827	1.5154	1.6095	1.5432	1.5893	
23	1.3032	1.2803	1.1827			1.2197	
24	.9945	1.0288	.9877	.961	.9511	.9465	1.1088
Max	**2.1948**	**2.3285**	**2.1437**	**2.0851**	**1.989**	**2.2916**	**2.1068**
Min	**.8916**	**1.0288**	**.9511**	**.8501**	**.905**	**.7545**	**1.0719**
Avg	**1.3858**	**1.5566**	**1.4785**	**1.4375**	**1.3829**	**1.4572**	**1.4358**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA (U)[117] **BU 0914**
Substation No/ Name :- 254033 / 33/22 KV KARANJE SS
Feeder No / Name : 403 / 33 KV MEDHA OUTGOING NON SHEDDABLE EHV INDUSTRIAL FEEDERS
Feeder KV- 33 / INCOMING (CONTINOUS PROCESS)(NO STAGGERING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6584	.9259	.9328	4.1581	4.1581	1.0288	1.1088
2	.463	.9259	1.4815	4.2135	3.786	1.0288	1.1643
3	.4115	1.0288	1.6461	4.2135	3.8409	1.0288	1.1643
4	.4115	1.5432	1.5364	4.3244	4.1152	1.2346	1.2197
5	.5144	2.3148	1.9753	4.768	3.9506	1.4403	1.7741
6	.6173	3.0864	1.5364	2.9938	2.0302	1.5432	3.3265
7	2.8292	4.1667	1.4815	.6099	.7133	1.6461	3.7146
8	3.8066	5.1955	2.5789	2.7166	2.7721	3.4465	7.4846
9	4.3724	5.5418	2.7166	3.2373	3.0864	6.1214	
10	2.6749	5.6573	1.7741	4.561	4.3724	5.9156	
11	4.0124	4.9383	1.6632	5.647	5.5556	4.9383	
12	3.6008	4.3347	1.386	6.3758	5.2469	4.8868	
13	3.4979	3.2373	2.2177	3.6923	5.9671	4.8868	
14	3.3436	1.1643	2.5503	1.8107	5.7099	4.7325	4.3896
15		4.0604	2.4394	6.5844		5.2984	4.9897
16	2.3663	4.3347	1.7187	4.7737		3.5494	4.8788
17	2.8807	2.8532	2.2177	2.2177	1.286	3.3265	4.225
18	2.7778	3.8409	1.2197	1.885	3.1379	4.6016	1.9204
19	3.858	4.3799	1.2197	1.3169	3.7551	4.1581	2.2177
20	3.7037	3.9363	3.0493	.5487	3.1893	3.4374	2.384
21	3.1379	2.6886	3.2156	2.1399	2.9321	1.9404	2.3594
22		2.1399	3.6037	2.3594	1.5947	.499	1.7187
23	2.3148	1.262	3.9918			1.2197	1.9204
24	.7716	.823	.7207	4.1581	4.0055	.5144	1.2197
Max	**4.3724**	**5.6573**	**3.9918**	**6.5844**	**5.9671**	**6.1214**	**7.4846**
Min	**.4115**	**.823**	**.7207**	**.5487**	**.7133**	**.499**	**1.1088**
Avg	**2.4102**	**3.0992**	**2.0364**	**3.4481**	**3.5812**	**3.0176**	**2.7990**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA (U)[117] **BU 0914**
Substation No/ Name :- 254071 / 33/22 KV SADAR BAZAR
Feeder No / Name : 301 / 22 KV PIRWADI **SHEDDABLE URBAN**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5121	.5487	.439	.4755	.4755	.5121	.5121
2	.4755	.5487	.4755	.439	.4755	.5121	.5121
3	.4755	.5487	.4755	.439	.4755	.5487	.5121
4	.5121	.5853	.4755	.439	.6219	.5487	.5121
5	.5853	.6584	.6584	.4755	.695	1.0974	.5121
6	.7682	.7316	.7316	.695	.7682		.8048
7	1.134	1.2071	1.0608	.9511	.8779	1.1706	1.2437
8	1.0242	1.1706	1.0974	1.1706	1.0974	1.134	1.2437
9	1.0608	1.134	1.0974	1.0974		.9877	1.0974
10	.9145	.9511	.9877	.9877	1.0242	.9145	.9511
11	.8413	.8413	.8413	.8779	.9145	.8779	
12	.8413	.7682	.7682	.7682	.7682	.7316	
13	.7316	.7316	.7682	.7316	.695	.7682	
14	.7682	.7316	.7316	.6584	.695	.7316	
15	.7316	.695	.695	.5853	.6584	.7316	
16	.695	.7316	.6584	.6584	.6219	.695	
17	.7316	.7316	.695	.7316	.695	.7316	.9877
18	1.0242	.9145	.8779	.9511	.8048	1.0242	1.0608
19	1.0974	1.0608	1.1706	1.134	1.0608	1.1706	1.1706
20	1.134	1.0608	1.0974	.9511	1.0608	1.0608	1.1694
21	1.0974	1.0974	.9877	.9145	.9877	1.0608	1.0974
22	.9511	.8413	.8413	.8413	.8779	.6584	1.0185
23	.7682	.7316	.695	.6219	.6584	.5487	.7922
24	.5853	.5853	.5487	.4755	.4755	.5121	.5487
Max	**1.134**	**1.2071**	**1.1706**	**1.1706**	**1.0974**	**1.1706**	**1.2437**
Min	**.4755**	**.5487**	**.439**	**.439**	**.4755**	**.5121**	**.5121**
Avg	**.8109**	**.8170**	**.7865**	**.7529**	**.7602**	**.8143**	**.8748**

 Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA (U)[117] **BU 0914**
Substation No/ Name :- 254071 / 33/22 KV SADAR BAZAR
Feeder No / Name : 302 / 22 KV SADAR BAZAR **SHEDDABLE URBAN**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6584	.695	.6584	.6219	.6219	.6219	.6219
2	.6024	.6219	.5853	.6219	.6219	.6219	.6219
3	.6584	.6219	.5853	.5853	.6584	.6219	.5853
4	.6584	.6584	.5853	.5853	.6584	.6584	.5853
5	.7316	.7316	.7316	.6219	.7682	.8048	.695
6	.8779	.8413	.8779	.8048	.8779	1.0608	.9145
7	1.3169	.1317	1.39	1.1706	1.0242	1.39	1.4632
8	1.3535	1.3112	1.3535	1.3169	1.2803	1.4266	1.4266
9	1.2437	1.2803	1.2803	1.3535		1.2437	1.2437
10	1.0608	1.0974	1.0974	1.134	1.134	1.0242	1.0242
11	.9511	.9145	.9145	.9511	1.0242	.9877	.8048
12	.7682	.7316	.8048	.8413	.9145	.9145	
13	1.0608	.6584	.7316	.7316	.7682	.7682	
14	.7316	.6219	.7316	.6584	.7316	.7682	1.0242
15	.7316	.6219	.695	.6584	.7316	.7682	.7682
16	.7682	.7682	.695	.7316	.695	.8048	.6584
17	.8779	.8413	.7316	.695		.8779	.8048
18	.7682	.9877	1.0608	1.0608	.9511	1.1706	2.6337
19	.9145	1.3169	1.2803	1.2437	1.2803	1.39	5.1212
20	.9511	1.3169	1.2437	1.0974	1.2803	1.3535	4.7154
21	1.2803	1.2437	1.2071	1.0974	.8048	1.2437	4.3004
22	1.0608	.9511	1.0974	1.0608	1.0608	.9511	3.6946
23	.8413	.8779	.8413	.8048	.8048	.6584	2.9801
24	.7316	.695	.695	.6584	.6219	.6584	.6219
Max	**1.3535**	**1.3169**	**1.39**	**1.3535**	**1.2803**	**1.4266**	**5.1212**
Min	**.6024**	**.1317**	**.5853**	**.5853**	**.6219**	**.6219**	**.5853**
Avg	**.9000**	**.8557**	**.9114**	**.8795**	**.8779**	**.9496**	**1.6959**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA (U)[117] **BU 0914**
Substation No/ Name :- 256016 / 220/132/33/22 KV NEW MIDC SS
Feeder No / Name : 302 / 22 KV POWAI NAKA NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 22 / OUTGOING UTILITY

DATE	01-NOV-17
HR	Load (MW)
24	2.1502
Max	2.1502
Min	2.1502
Avg	2.1502

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA (U)[117] **BU 0914**
Substation No/ Name :- 256016 / 220/132/33/22 KV NEW MIDC SS
Feeder No / Name : 303 / 22 KV RADHAKRISHNA SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-NOV-17
HR	Load (MW)
24	1.4335
Max	1.4335
Min	1.4335
Avg	1.4335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA (U)[117] **BU 0914**
Substation No/ Name :- 256016 / 220/132/33/22 KV NEW MIDC SS
Feeder No / Name : 304 / 22KV ARISTOCRAT SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-NOV-17
HR	Load (MW)
24	1.8861
Max	1.8861
Min	1.8861
Avg	1.8861

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA (U)[117] **BU 0914**
Substation No/ Name :- 256016 / 220/132/33/22 KV NEW MIDC SS
Feeder No / Name : 305 / 22KV OKASA PHARMA NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 22 / OUTGOING (NON-CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-NOV-17
HR	Load (MW)
24	.415
Max	.415
Min	.415
Avg	.415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA (U)[117] **BU 0914**
Substation No/ Name :- 256016 / 220/132/33/22 KV NEW MIDC SS
Feeder No / Name : 402 / 33KV SIDDHIVINAYAK SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 33 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-NOV-17
HR	Load (MW)
24	1.9805
Max	1.9805
Min	1.9805
Avg	1.9805

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA (U)[117] **BU 0914**
Substation No/ Name :- 256016 / 220/132/33/22 KV NEW MIDC SS
Feeder No / Name : 406 / 33 KV COOPER Feeder KV- 33 / OUTGOING NON SHEDDABLE EXPRESS HV FEEDERS (NON-CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-NOV-17
HR	Load (MW)
24	.9054
Max	.9054
Min	.9054
Avg	.9054

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA (U)[117] **BU 0914**
Substation No/ Name :- 256016 / 220/132/33/22 KV NEW MIDC SS
Feeder No / Name : 412 / 33 KV BHIMESHWARI Feeder KV- 33 / OUTGOING NON SHEDDABLE EXPRESS HV FEEDERS (NON-CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-NOV-17
HR	Load (MW)
24	3.7346
Max	3.7346
Min	3.7346
Avg	3.7346

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] BU 0931
Substation No/ Name :- 254014 / PARALI
Feeder No / Name : 201 / PARALI-SATARA GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698		.1715	.1494	.1698	.168	.1715
2	.1509	.168	.1715	.132		.168	.1715
3	.1509	.168	.1715	.132	.1509	.1509	.1715
4	.1698	.168	.1715	.1307	.1698	.1509	.1715
5	.1698	.1867	.2058	.168	.1886	.1886	.2572
6	.3018	.2801	.2572	.2801	.3018	.3174	.3429
7	.5359	.5601	.4287	.462	.4805	.499	.5144
8	.5175	.5228	.4287	.462	.5544	.499	.5144
9	1.6804	.4854	.4668	.4755	.5658	.4294	.3174
10	.3772	.4435	.4066	.499	.4287	.4251	.3174
11	.3772	.3475	.3982	.168	.4287	.3658	.2427
12	.3772	.2896	.3292	.3734	.3772	.2926	.2054
13	.3772	.3077	.3142	.3361	.3772	.2772	.168
14		.2926	.2957	.2801	.3772	.2561	
15	.3772	.2402	.2743	.2987	.3772	.2195	.2241
16		.2572	.2743	.3174		.2195	.2427
17	.4572	.2915	.3142	.3734		.2572	.2427
18	.3734	.4801	.3511	.3361		.3772	.3658
19	.5975	.5144	.5544	.6401		.4287	.6838
20	.5601	.5144	.5729	.5853		.5144	.5601
21	.5228	.463	.4854	.5487		.5144	.5415
22	.3921	.3429	.3734	.3881		.3772	.4668
23		.2572	.2241	.2427			.2801
24	.0686	.1867	.1715	.168	.1886		.1715
Max	**1.6804**	**.5601**	**.5729**	**.6401**	**.5658**	**.5144**	**.6838**
Min	**.0686**	**.168**	**.1715**	**.1307**	**.1509**	**.1509**	**.168**
Avg	**.4145**	**.3377**	**.3255**	**.3311**	**.3424**	**.3226**	**.3193**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] **BU 0931**
Substation No/ Name :- 254014 / PARALI
Feeder No / Name : 202 / THOSEGHAR **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17
HR	Load (MW)	Load (MW)
24	.0686	.0686
Max	.0686	.0686
Min	.0686	.0686
Avg	.0686	.0686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] BU 0931
Substation No/ Name :- 254014 / PARALI
Feeder No / Name : 203 / Nitral Gaonthan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189		.0189	.0187	.0171
2	.0189		.0189	.0189	.0171
3			.0189	.0189	
4	.0189		.0189	.0189	.0343
5	.0189		.0377	.0377	.0343
6	.0566		.0566	.056	.0514
7	.112		.0934	.0747	.0686
8	.0934	.0747		.0934	.0686
9	.0514	.0747	.0686	.056	.0747
10	.0343	.0373	.0343	.056	.056
11	.0343	.0373	.0343	.037	.0373
12	.0343	.0187	.0343	.037	.0373
13	.0343	.0187	.0343	.037	.0373
14	.0343	.0187	.0343	.0373	.0187
15	.0343	.0187	.0343	.0373	.0187
16		.0373		.0187	.0373
17	.0373	.0187		.0171	.0373
18		.0754		.0514	.0566
19		.1132		.0857	.1132
20		.0943		.0857	.0934
21		.0754		.0857	.0747
22		.0566		.0686	.056
23		.0377			.0373
24	.0189		.0189	.0187	.0171
Max	**.112**	**.1132**	**.0934**	**.0934**	**.1132**
Min	**.0189**	**.0187**	**.0189**	**.0171**	**.0171**
Avg	**.0407**	**.0505**	**.0371**	**.0464**	**.0476**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] BU 0931
Substation No/ Name :- 254014 / PARALI
Feeder No / Name : 204 / PARALI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3429	.2949	.2543		
2			.3429	.2688	.2572		
3			.3429	.2721	.2401		
4			.3429	.2949	.2401		
5			.3429	.2915	.2743		
6			.3429	.3149	.3391		
7			.3429	.3725	.3856		
8	.0686						.4287
9	.1372					.5258	.8316
10	.2058	.3391				.788	.8413
11	.2058	.502				.7373	.929
12	.2058	.5243				.7865	.9465
13	.2058	.506				.7537	.9816
14		.5344				.7865	1.0056
15	.1715	.5571				.7373	.9774
23		.0686					
24	.0686		.1715	.2818	.2713		
Max	**.2058**	**.5571**	**.3429**	**.3725**	**.3856**	**.788**	**1.0056**
Min	**.0686**	**.0686**	**.1715**	**.2688**	**.2401**	**.5258**	**.4287**
Avg	**.1586**	**.4331**	**.3215**	**.2989**	**.2828**	**.7307**	**.8677**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] BU 0931
Substation No/ Name :- 254016 / ANGAPUR
Feeder No / Name : 201 / 11 KV ANGAPUR AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0672	.0732	1.7166		1.6196	.076	.0672
2	.0635	.0702	1.7237		1.61	.076	.0628
3	.0635	.0665	1.7204		1.5716	.0695	.0635
4	.0597	.0702	1.7271		1.5588	.0724	.0665
5	.0597	.0776	1.7205		1.5364	.0833	.0709
6	.0822	.0887	1.704		1.53	.0905	.0961
7	.0934	.0887	1.8154		1.626	.0995	.0784
8	1.9396	1.9694				1.6648	2.2152
9	2.1247	2.3493				2.2277	
10	2.2542					2.4902	
11	2.3514	2.3791				2.535	
12	2.3125	2.556				2.3365	
13	2.2725	2.4874				2.3301	
14	2.3299	2.4162	.1214	.0336	.0768	2.4518	
15	2.2476	2.3922	.1251	.1331	.1024	2.3942	
16		2.2213	.1456	.1171	.0951		
17				.1083	.0977		
18				.0859	.1086		
19				.0822	.105		
20				.0747	.1014		
21				.0822	.0905		
22	.1628	.0672		.0709	.0905	.1046	.1755
23	.0841	.0702		.0635	.0869	.0709	.1046
24	.0709	.0747	1.7499		1.6452	.0778	.0709
Max	**2.3514**	**2.556**	**1.8154**	**.1331**	**1.6452**	**2.535**	**2.2152**
Min	**.0597**	**.0665**	**.1214**	**.0336**	**.0768**	**.0695**	**.0628**
Avg	**1.0355**	**1.0843**	**1.2972**	**.0852**	**.7585**	**1.0695**	**.2792**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] BU 0931
Substation No/ Name :- 254016 / ANGAPUR
Feeder No / Name : 202 / 11 KV ANGAPUR GAVTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1317	.1419	.1643		.1646	.1353	.1531
2	.1317	.1419	.1531		.161	.1303	.1531
3	.1353	.1382	.1494		.1536	.1267	.1494
4	.139	.1456	.1456		.161	.1536	.1568
5	.139	.1643	.1792		.1646	.1846	.1643
6	.2668	.2926	.278		.2919	.3204	.2926
7	.4477	.4426	.4463		.471	.4452	.4792
8	.3653	.4207	.406		.4513	.4471	.4324
9	.295	.2901	.308	.3137	.3547	.283	
10	.2726		.2707	.2763	.3249	.2268	
11	.2278	.2113	.2048	.2315	.2539	.2012	
12	.168	.2305	.1975	.2054	.1979	.1884	
13	.1568	.1975	.1884	.1979	.1792	.1719	
14	.127	.1829		.2016	.1718	.1975	
15	.1419	.1866	.1463	.1979	.1867	.1902	
16	.2241	.1939	.1866	.1942	.2203	.2239	
17	.2203	.2128		.139	.2643	.1718	.2195
18	.3788	.2402		.308	.3113	.3137	.3331
19	.4109	.3548		.3761	.3837	.3621	.394
20	.3585	.3585		.351	.333	.3841	.3653
21	.3054	.3018		.308	.2842	.3398	.3188
22	.2624	.2465		.2561	.219	.2726	.2865
23	.1755	.1904		.1738	.1882	.1904	.2048
24	.1353	.1456	.168		.1683	.139	.1568
Max	**.4477**	**.4426**	**.4463**	**.3761**	**.471**	**.4471**	**.4792**
Min	**.127**	**.1382**	**.1456**	**.139**	**.1536**	**.1267**	**.1494**
Avg	**.2340**	**.2361**	**.2245**	**.2487**	**.2525**	**.2417**	**.2662**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] BU 0931
Substation No/ Name :- 254016 / ANGAPUR
Feeder No / Name : 204 / 11 KV JIHE GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1353	.1494	.1344		.1317	.1484	.1494
2	.128	.1419	.1307		.128	.1463	.1419
3	.1317	.1307	.1307		.1427	.1412	.1307
4	.1536	.1344	.1382		.1536	.1611	.1419
5	.1683	.1606	.1606		.1756	.2085	.168
6	.2817	.2994	.2957		.289	.3077	.3179
7	.462	.4609	.4719		.4585	.4489	.4755
8	.4047	.4066	.3695		.4083	.3475	.3881
9	.3179	.3152	.3116	.3211	.3361	.2758	
10	.2772	.2451	.2794	.2987	.3025	.2722	
11	.2661	.2378	.2451	.2465	.295	.2686	
12	.278	.2378		.239	.2427	.2722	
13	.2735	.2085		.2465	.2577	.2305	
14	.2278	.2048	.2414	.2278	.2465	.2231	
15	.2241	.2012	.2268	.2203	.2587	.2122	
16	.2502	.2085	.2231	.2241	.2278	.2543	
17	.267	.2195		.2722	.2896	.2241	.2085
18	.414	.3363		.3116	.3731	.3512	.278
19	.503	.4719		.4943	.4829	.4597	.4191
20	.3987	.4207		.4549	.438	.4316	.4047
21	.3363	.3695		.351	.3747	.3658	.3295
22	.3216	.2743		.2758	.286	.289	.3152
23	.1922	.1942		.1975	.2063	.1904	.1902
24	.0686	.1531	.1344		.1353	.152	.1531
Max	**.503**	**.4719**	**.4719**	**.4943**	**.4829**	**.4597**	**.4755**
Min	**.0686**	**.1307**	**.1307**	**.1975**	**.128**	**.1412**	**.1307**
Avg	**.2701**	**.2576**	**.2329**	**.2921**	**.2767**	**.2659**	**.2632**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] BU 0931
Substation No/ Name :- 254016 / ANGAPUR
Feeder No / Name : 205 / 11 KV VIJAY NAGAR AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9044	.8518				1.337	1.1368
2	.9012	.8453				1.3141	1.1731
3	.9077	.852				1.2518	1.1863
4	.9143	.852				1.2452	1.1934
5	.9175	.8749				1.2682	1.1994
6	.941	.9044				1.2729	1.2125
7	.9506	.9307				1.2988	1.2564
8			.9624		1.6484		
9			1.3827	1.7269	1.7736		
10			1.3763	1.8089	2.0186		
11			1.6708	1.8711	2.0081		
12			1.5428	1.8845	2.071		
13			1.7316	1.7106	1.9694		
14			1.6196	1.8465	1.7401		
15			1.6292	1.8299	1.8564		
24	.8898					1.3567	1.1012
Max	**.9506**	**.9307**	**1.7316**	**1.8845**	**2.071**	**1.3567**	**1.2564**
Min	**.8898**	**.8453**	**.9624**	**1.7106**	**1.6484**	**1.2452**	**1.1012**
Avg	**.9158**	**.8730**	**1.4894**	**1.8112**	**1.8857**	**1.2931**	**1.1824**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] BU 0931
Substation No/ Name :- 254016 / ANGAPUR
Feeder No / Name : 206 / Tasgaon Ag Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.4194	.0373		.0411	.7439	.8651
2	.4733	.4177	.0336		.0373	.6882	.852
3	.463	.4091	.0336		.0336	.6325	.8291
4	.4664	.4024	.0299		.0373	.6423	.8288
5	.4698	.4057	.0336		.0373	.6783	.8321
6	.4595	.4111	.0476		.0411	.7226	.9116
7	.559	.462	.048		.0448	.8684	1.0194
8			.3113		.9733		
9			.4981	.968	1.1468		
10			.7996	1.1142	1.2059		
11			.7209	1.219	1.2474		
12			.7298	1.1469	1.3304		
13			.9026	1.2059	.9054		
14	.0411	.0336	.8642	1.1501	.9044	.0411	
15	.0448	.0373	.8514	1.1267	1.1666	.0448	
16	.0523	.0411				.0448	
17	.0523	.0336				.0373	.0485
18	.056	.0299				.0299	.0485
19	.0549	.0407				.0336	.0448
20	.0512	.037				.0336	.0448
21	.0523	.0411				.0476	.0485
22	.0485	.0373		.0411		.0336	.0448
23	.0402	.0336		.0411	.0507	.0373	.0411
24	.4835	.4293	.0411		.0411	.7816	.8881
Max	**.559**	**.462**	**.9026**	**1.219**	**1.3304**	**.8684**	**1.0194**
Min	**.0402**	**.0299**	**.0299**	**.0411**	**.0336**	**.0299**	**.0411**
Avg	**.2416**	**.2068**	**.3739**	**.8903**	**.5438**	**.3412**	**.4898**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] BU 0931
Substation No/ Name :- 254017 / SHENDRE
Feeder No / Name : 201 / 11 KV VALASE AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0171	.3429	.4287	.6001	.0171	.0171
2	.0171	.0171	.3601	.5144	.583	.0171	.0171
3	.0171	.0171	.3601	.5144	.583	.0171	.0171
4	.0171	.0171	.3772	.5487	.583	.0171	.0171
5	.0171	.0171	.3772	.583	.4801	.0171	.0171
6	.0171	.0171	.3772	.6173	.4973	.0171	.0171
7	.0171	.0171	.3944	.7545	.7202	.0171	.0171
8	.7202	.0857				.8916	.7888
9	.7888	.4801				.9945	.9774
10	.8402	.5144				1.1317	.9431
11	.8916	.5316				1.1317	1.0288
12	.8745	.5487				1.1317	1.1145
13	.9431	.5487				.9431	1.1488
14	.9602	.5316		.0171	.0171	1.2517	1.2346
15	.9774	.5316		.0171	.0171	1.286	1.1317
16				.0171	.0171		
17				.0171	.0171		
18				.0171	.0171		
19				.0171	.0171		
20				.0171	.0171		
21				.0171	.0171		
22	.0171			.0171	.0171	.0171	.0171
23	.0171			.0171	.0171	.0171	.0171
24	.0171	.0171	.3429	.3429	.6001	.0171	.0171
Max	**.9774**	**.5487**	**.3944**	**.7545**	**.7202**	**1.286**	**1.2346**
Min	**.0171**	**.0171**	**.3429**	**.0171**	**.0171**	**.0171**	**.0171**
Avg	**.4206**	**.2443**	**.3665**	**.2486**	**.2677**	**.4963**	**.4744**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] **BU 0931**
Substation No/ Name :- 254017 / SHENDRE
Feeder No / Name : 203 / SUGARMILL **SHEDDABLE FEEDER HAVING WEEKLY**
Feeder KV- 11 / OUTGOING **STAGGERING (MIDC, EQUIVALENT)**

DATE	01-NOV-17
HR	Load (MW)
24	.0686
Max	.0686
Min	.0686
Avg	.0686

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] **BU 0931**
Substation No/ Name :- 254017 / SHENDRE
Feeder No / Name : 204 / 11 KV SHENDRE-VECHALE AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.3375	.0686	.0514	.0514	1.749	1.6975
2	1.3717	1.3717	.0686	.0514	.0514	1.8347	1.6804
3	1.406	1.406	.0686	.0514	.0514	1.8861	1.6975
4	1.4575	1.4746	.0686	.0514	.0514	1.9376	1.6975
5	1.5089	1.5432	.0686	.0514	.0514	1.9719	1.7661
6	1.5775	1.5775	.0514	.0514	.0514	1.9547	1.7833
7	1.5947	1.3203	.0514	.0514	.0514	1.9719	1.989
8			1.9204	2.0062	1.9719		
9			2.0748	2.2291	2.0919		
10			2.3663	2.2634	2.4006		
11			2.1091	2.4348	2.7092		
12			.9088	2.5206	2.6578		
13			.9774	2.4863	2.5549		
14	.0514	.0514		2.4006	2.7435	.0343	.1029
15	.0514	.0514	2.0919	2.3834	2.6406	.0343	.1029
16	.0686					.0343	.0686
17	.0514	.0514				.0343	.0686
18	.0514					.0686	.0686
19	.0514					.0686	.0686
20	.0514					.0686	.0686
21	.0514					.0514	.0686
22	.0514			.0514	.0514	.0514	.0686
23	.0514			.0514	.0514	.0514	.0686
24	1.3375	1.3203	.0514	.0514	.0514	1.6632	1.6975
Max	**1.5947**	**1.5775**	**2.3663**	**2.5206**	**2.7435**	**1.9719**	**1.989**
Min	**.0514**	**.0514**	**.0514**	**.0514**	**.0514**	**.0343**	**.0686**
Avg	**.6754**	**1.0459**	**.8631**	**1.0688**	**1.1269**	**.8592**	**.8202**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] BU 0931
Substation No/ Name :- 254017 / SHENDRE
Feeder No / Name : 205 / VALASE (GAONTHAN) GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.1886	.2915	.2743	.2401	.2401	.1715
2	.2743	.1886	.2915	.2401	.1543	.2572	.1543
3	.3086	.2058	.3086	.2572	.1543	.2743	.1543
4	.3429	.2401	.3086	.3086	.1543	.3086	.1029
5	.3601	.3086	.3258	.3429	.1715	.3429	.1372
6	.3944		.3772	.3772	.3258	.3772	.2229
7	.463	.4973	.4458	.463	.4458	.4287	.4287
8	.463	.5144	.3944	.3944	.4458	.3772	.3772
9	.4458	.463	.3258	.3429	.4115	.3429	.2401
10	.3944	.3601	.3772	.3772	.3601	.3601	.3601
11	.3772	.3601	.3944	.3258	.3944	.3601	.3772
12	.3429	.3601	.3944	.3086	.3258	.3429	.4115
13	.2743	.3601	.3086	.2915	.3429	.3429	.0686
14	.2743	.3086	.3086	.2915	.2915	.3258	.2743
15	.2743	.3086	.3086	.2915	.3258	.2915	.3258
16	.2058	.3258	.3258	.3086	.3086	.3258	.3258
17	.3258	.3772		.3601	.3258	.3258	.3944
18	.3944			.4115	.3429	.4115	.4115
19	.5144			.5144	.3601	.5316	.4287
20	.4801			.4801	.3772	.4801	.4458
21	.4458			.463	.3772	.4458	.3944
22	.3772			.3429	.3429	.3772	.3429
23	.2401			.2743	.2915	.2401	.2915
24	.2401	.2058	.2743	.3086	.2229	.2401	.2229
Max	**.5144**	**.5144**	**.4458**	**.5144**	**.4458**	**.5316**	**.4458**
Min	**.2058**	**.1886**	**.2743**	**.2401**	**.1543**	**.2401**	**.0686**
Avg	**.3522**	**.3278**	**.3389**	**.3479**	**.3122**	**.3479**	**.2944**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] **BU 0931**
Substation No/ Name :- 254017 / SHENDRE
Feeder No / Name : 206 / 11 KV SHENDRE GAONTHAN **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
24	.1372
Max	.1372
Min	.1372
Avg	.1372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] **BU 0931**
Substation No/ Name :- 254017 / SHENDRE
Feeder No / Name : 401 / 33 KV AJINKYATARA SUTGIRANI EX Feeder KV- 33 / OUTGOING **NON SHEDDABLE EXPRESS HV FEEDERS (NON-CONTINOUS PROCESS)(NO STAGGERING)**

DATE	01-NOV-17
HR	Load (MW)
24	.2058
Max	.2058
Min	.2058
Avg	.2058

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] **BU 0931**
Substation No/ Name :- 254035 / WADHE
Feeder No / Name : 302 / LIMB **SHEDDABLE FEEDER HAVING WEEKLY**
Feeder KV- 22 / OUTGOING **STAGGERING (MIDC, EQUIVALENT)**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.4298	.4854	.4481	.4108	.415	.4481
2	.2987	.4066	.4481	.415	.4108	.415	.4481
3	.2957	.4066	.4481	.415	.4108	.415	.4108
4	.2957	.4066	.4481	.4108	.4108	.415	.4108
5	.3326	.4066	.4481	.4108	.4435	.4108	.4481
6	.3734	.4435	.4481	.4024	.4435	.415	.4481
7	.3734	.4435	.4481	.5228	.5175	.5228	.5228
8	.3734	.4805	.5228	.5228	.5228	.5281	.4854
9	.7095	.5487	.6348	.6653	.7095	.5975	.4435
10	.9709	.8048	1.0829	.9335	.9335	1.1576	.4066
11	1.3443	1.1222	1.2323	1.1576	1.2696	1.1088	.4066
12	1.0082	.9145	.9709	.961	1.1576	1.2567	.4066
13	1.1203	.9511	1.1203	1.1458	1.1949	1.0456	.3326
14	1.0082	.7316	1.0456	1.0349	1.1203	1.0719	.3696
15	1.0829	1.2437	1.2323	1.0349	1.2323	1.1203	.3696
16	1.0829	1.0242	.7842	1.0719	.9709	1.1576	.3326
17	1.2197	.9335	1.1949	1.1576	1.0082	1.1203	.2987
18	.6653	.6722	.7316	.5601	.6413	.7842	.2987
19	.5975	.5228	.5121	.4805	.5658	.5601	.3361
20	.5175	.5228	.4805	.4805	.5228	.5228	.2987
21	.5175	.5228	.4755	.4854	.5281	.5228	.3361
22	.4805	.5228	.4755	.4481	.4904	.4854	.2987
23	.4805	.4481	.4904	.4481	.4527	.4854	.3361
24	.548	.4435	.4854	.4904	.4481	.4527	.4854
Max	**1.3443**	**1.2437**	**1.2323**	**1.1576**	**1.2696**	**1.2567**	**.5228**
Min	**.2957**	**.4066**	**.4481**	**.4024**	**.4108**	**.4108**	**.2987**
Avg	**.6680**	**.6397**	**.6936**	**.6710**	**.7007**	**.7078**	**.3908**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] **BU 0931**
Substation No/ Name :- 254035 / WADHE
Feeder No / Name : 303 / 22 KV VARYE MIX **SHEDDABLE RURAL**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5609	.4344	.6661	.7167	.6661	.6413	.6661
2	.5316	.4024	.5959	.6413	.6379	.6413	.6661
3	.5258	.4024	.5959	.6413	.631	.6413	.6661
4	.5316	.4024	.5959	.6348	.6379	.6413	.6661
5	.6379	.5068	.7011	.7842	.6661	.7095	.7712
6	.9816	.7602	.9816	.9877	.9922	1.0082	1.2536
7	1.5592	1.086	1.5043	1.7177	1.5074	1.5684	1.7909
8	1.4529	1.1946	1.6476	1.8671	1.8427	1.773	1.97
9	1.576	1.1706		1.7737	1.8625	1.5592	1.9547
10	1.3969	1.0974		1.7013	1.9342	1.4373	1.3756
11	1.182	.8413		1.3756	1.8625	1.1694	1.5927
12	1.182	1.0974		1.4842	1.8983	1.5775	1.4118
13	1.1462	1.0242		1.448	1.7193	1.6126	1.0498
14	1.0387	.9774		1.448	1.8267	1.5592	.6878
15	.9313	1.0242	1.134	1.086	1.8625	1.5424	.905
16	.9671	1.0242	1.1568	1.4842	1.7909	1.5947	1.3032
17	1.1946	1.0745	1.262	1.5947	1.9616	1.6118	1.4022
18	1.267	1.6118	1.6095	1.6476	1.531	1.8267	1.7718
19	1.448	1.7193	1.9387	1.858	1.7353	1.8625	1.8229
20	1.3394	1.6476	1.7193	1.6476	1.643	1.7551	1.6126
21	.9774	1.4327	1.4266	1.4373	1.0185	1.5402	1.5074
22	.7602	1.2178	1.2071	1.2269	1.0185	1.2894	1.1919
23	.543	.8954	.9808	.8859	.7922	.9709	.9816
24	.6379	.4344	.6661	.7922	.7442	.679	.7522
Max	**1.576**	**1.7193**	**1.9387**	**1.8671**	**1.9616**	**1.8625**	**1.97**
Min	**.5258**	**.4024**	**.5959**	**.6348**	**.631**	**.6413**	**.6661**
Avg	**1.0154**	**.9783**	**1.1327**	**1.2868**	**1.3659**	**1.3005**	**1.2406**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] BU 0931
Substation No/ Name :- 254035 / WADHE
Feeder No / Name : 304 / 22 KV RAMNAGAR AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2321	.3647	.1193		.0663	.9816	.6859
2	.1966	.1989	.1061		.0663	.8688	.6859
3	.1989	.1989	.1061		.0663	.8779	.6516
4	.2035	.1989	.1061		.0663	.8779	.6371
5	.2321	.3647	.1127		.0663	.8688	.6706
6	.2321	.4641	.1193		.0663	.8596	.8573
7	.3315	.5636	.1193	.1085	.0663	1.0985	1.1317
8				.4557	.6962		
9			.663	.78	1.1218		
10			.8619	.8139	1.1919		
11			.9282	.8478	1.3672		
12			.8951	.9496	1.3321		
13				1.0174	1.2269		
14	.0796	.1376	.9282	1.0513		.0663	.0663
15	.0796	.1326	.9945	1.0159	.7545	.0995	
16	.0796	.118					.0696
17	.0729	.126				.0995	.0663
18	.0862	.1326				.1193	.0663
19	.0862	.1392				.126	.0995
20	.0995	.126				.126	.0663
21	.1061	.126				.1193	.0663
22	.0995	.126		.0995	.1276	.1193	.0995
23	.1392	.1193	.0678		.1276	.1127	.0663
24	.2321	.3647	.126		.0663	.9816	
Max	**.3315**	**.5636**	**.9945**	**1.0513**	**1.3672**	**1.0985**	**1.1317**
Min	**.0729**	**.118**	**.0678**	**.0995**	**.0663**	**.0663**	**.0663**
Avg	**.1549**	**.2223**	**.4169**	**.7140**	**.4986**	**.4943**	**.3742**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] BU 0931
Substation No/ Name :- 254035 / WADHE
Feeder No / Name : 305 / WADHE AG 22KV SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	02-NOV-17
HR	Load (MW)
24	.1372
Max	.1372
Min	.1372
Avg	.1372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] **BU 0931**
Substation No/ Name :- 254036 / VENEGAON
Feeder No / Name : 201 / KOPARDE **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.9602	.8402	.7773		
2			.9602	.823	.7865		
3			.9602	.8059	.7773		
4			.9602	.8059	.7682		
5			.9602	.8059	.7682		
6			.9602	.823	.7773		
7			.9602	.823	.8322		
8	.823	.9145				.9877	1.2003
9	.9431	.9774				1.2003	1.448
10	1.0802	1.046				1.2689	1.6476
11	1.0974	1.0631					1.5939
12	1.0974	1.1317				1.3032	1.8858
13	1.0974	1.166				1.5089	1.8671
14	1.1145	1.1317				1.5432	1.829
15	1.1641	1.166				1.5089	1.8671
24			.9602	.8402	.7773		
Max	**1.1641**	**1.166**	**.9602**	**.8402**	**.8322**	**1.5432**	**1.8858**
Min	**.823**	**.9145**	**.9602**	**.8059**	**.7682**	**.9877**	**1.2003**
Avg	**1.0521**	**1.0746**	**.9602**	**.8209**	**.7830**	**1.3316**	**1.6674**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] BU 0931
Substation No/ Name :- 254036 / VENEGAON
Feeder No / Name : 202 / VENEGAON GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1829	.181	.1715	.1867	.1829	.181
2	.1715	.1829	.181	.1715	.1867	.1829	.1772
3	.1715	.1829	.1791	.1715	.1867	.1829	.1753
4	.1715	.1829	.2149	.1886	.1867	.1829	.1928
5	.3086	.2561	.2686	.2743	.2987	.2561	.2507
6	.4458	.439	.4572	.4115	.4854	.5121	.4572
7	.6687	.7316	.7133	.6344	.6722	.6584	.7133
8	.583	.5853	.6219	.5487	.6219	.5853	.6154
9	.4835	.4973	.4755	.439	.5068	.4287	.5014
10	.3582	.3429	.3395	.2926	.3841	.3258	.3109
11	.2865	.2743	.2507	.2561	.3109	.2401	.2507
12	.2454	.2572	.2481		.2715	.2401	.2715
13	.2481	.2743	.2103	.2195	.2507		.2715
14	.2481	.2401	.2103	.2195	.2507	.2572	.2896
15	.2507	.2401	.2454	.2195	.2534	.2743	.2534
16	.2926	.2401	.2126	.2195	.2743	.2915	.2561
17	.2926	.2915	.3086	.2835	.2926	.3077	.2572
18	.3658	.4525	.463	.4252	.439	.439	.4287
19	.6584	.6219	.6001	.6447	.5853	.6219	.6173
20	.6219	.6154	.583	.5914		.5792	.5487
21	.5121	.543	.463	.5175		.543	.5144
22		.4024	.3601	.3696		.3982	.4287
23		.2715	.2058	.2241		.2743	.2743
24	.1886	.2195	.2012	.1715	.1867	.1829	.2172
Max	**.6687**	**.7316**	**.7133**	**.6447**	**.6722**	**.6584**	**.7133**
Min	**.1715**	**.1829**	**.1791**	**.1715**	**.1867**	**.1829**	**.1753**
Avg	**.3520**	**.3553**	**.3414**	**.3333**	**.3416**	**.3542**	**.3523**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] BU 0931
Substation No/ Name :- 254036 / VENEGAON
Feeder No / Name : 203 / NANDGAON SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	1.0242	.0362	.0343	.0377	1.6461	1.9605
2	.823	1.0242	.0366	.0343	.0377	1.6461	1.9791
3	.7888	1.0242	.0183	.0343	.0377	1.6644	1.9791
4	.7888	1.0242	.0183	.0343	.0377	1.6461	1.9387
5	.8916	1.0242	.0183	.0343	.0377	1.6644	2.0119
6	.9602	1.0242	.0183	.0343	.0377	1.9022	2.0851
7	1.0288	1.0974	.0366	.0343	.0189	2.0485	2.2405
8			.7935	1.5775	1.6842		
9			1.576	2.1948	2.3411		
10			2.037	2.5606	2.9127		
11			2.1125		2.9081		
12			2.2405	2.5606	2.8959		
13			2.1658	2.5606	2.8715		
14	.0179	.0171	1.9433	2.5606	2.8349	.0171	.0181
15	.0189	.0171	1.9845	2.5606	2.5882	.0171	.0373
16	.0358	.0171				.0171	.0362
17	.0366	.0171				.0183	.0343
18	.0366	.0373				.0366	.0343
19	.0366	.0362				.0362	.0343
20	.0366	.0366				.0366	.0343
21	.0366	.0373				.0362	.0343
22		.0373	.0171	.0189		.0362	.0343
23		.0362	.0343			.0366	.0343
24	.7545	1.0242	.0366	.0343	.0377	1.6461	1.9204
Max	**1.0288**	**1.0974**	**2.2405**	**2.5606**	**2.9127**	**2.0485**	**2.2405**
Min	**.0179**	**.0171**	**.0171**	**.0189**	**.0189**	**.0171**	**.0181**
Avg	**.4446**	**.4753**	**.8402**	**1.0543**	**1.3325**	**.7862**	**.9137**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] **BU 0931**
Substation No/ Name :- 254036 / VENEGAON
Feeder No / Name : 204 / KHODAD AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17
HR	Load (MW)	Load (MW)
24	.0686	.0686
Max	.0686	.0686
Min	.0686	.0686
Avg	.0686	.0686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] BU 0931
Substation No/ Name :- 254037 / NIGADI
Feeder No / Name : 201 / 11 KV DEGAON AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0373	.4572	.4329	.4287	.037	.037
2	.0373	.0373	.4572	.4268	.4115	.037	.0549
3	.0373	.0373	.4607	.4268	.4058	.0373	.037
4	.037	.0373	.4401	.4268	.4058	.0373	.0366
5	.037	.0373	.4548	.4268	.4193	.037	.0366
6	.037	.0373	.4633	.4329	.4715	.0747	.0532
7	.056	.0373	.4793	.514	.5213	.056	.0554
8	.2	.5556				.4816	.823
9	.2679	.6405				.8916	1.0936
10	.4904	.727				.7868	1.3435
11	.4904	.7169				1.0136	1.5524
12	.6226	.7575				1.2809	1.5655
13	.6087	.7575				1.3279	1.2963
14	.6628	.7956	.0351	.0554	.0549	1.1405	1.439
15	.6722	.751	.0343	.0537	.0739	1.142	1.5043
16			.0347	.0716	.0739		
17			.0358	.0543	.0747		
18			.0549	.052	.0366		
19			.0739	.0554	.0554		
20			.0934	.0549	.0366		
21			.0747	.0549	.0362		
22	.0362	.0316	.0747	.0554	.0366	.0854	.0532
23	.0358	.0747	.056	.0566	.0549	.0532	.056
24	.0377	.0373	.4904	.4329	.4344	.037	.0554
Max	**.6722**	**.7956**	**.4904**	**.514**	**.5213**	**1.3279**	**1.5655**
Min	**.0358**	**.0316**	**.0343**	**.052**	**.0362**	**.037**	**.0366**
Avg	**.2447**	**.3392**	**.2373**	**.2269**	**.224**	**.4754**	**.6163**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] BU 0931
Substation No/ Name :- 254037 / NIGADI
Feeder No / Name : 202 / VARNE AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3906	.3932	.0747	.0747	.0943	.4801	.4999
2	.3704	.3725	.0747	.0747	.0943	.4801	.4744
3	.3704	.3563	.0747	.0747	.0943	.4586	.4961
4	.3704	.3521	.0754	.0747	.0943	.4531	.4687
5	.3906	.3605	.0747	.0747	.1132	.4531	.4481
6	.427	.3841	.0924	.0934	.132	.5155	.5868
7	.5937	.5376	.1494	.1663	.1307	.578	.8124
8			.4321	.3048	.3549		
9			.7125	.6483	.8002		
10			.9393	.7449	.3841		
11		.0724	.7907	.8642	.8539		
12			.8259	.8951	.9122		
13			.8124	.8356	.8539		
14	.1463	.112	.8065	.6299	.7935	.1494	.1698
15	.1848	.1307	.8223	.4586	.7865	.2054	.2075
16	.2012	.1494				.2218	.2075
17	.2195	.1494				.1646	.2033
18	.1848	.168				.2033	.2452
19	.1867	.168				.1698	.1886
20	.1886	.1886				.1886	.1886
21	.1886	.1132				.1698	.2075
22	.1509	.1132	.0747	.0924	.112	.132	.2054
23	.1509	.0754	.0747	.0943	.0934	.1307	.168
24	.381	.4144	.0747	.0747	.0943	.4858	.4902
Max	**.5937**	**.5376**	**.9393**	**.8951**	**.9122**	**.578**	**.8124**
Min	**.1463**	**.0724**	**.0747**	**.0747**	**.0934**	**.1307**	**.168**
Avg	**.2831**	**.2427**	**.3879**	**.3487**	**.3773**	**.3133**	**.3482**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] BU 0931
Substation No/ Name :- 254037 / NIGADI
Feeder No / Name : 203 / DEGAON GAONTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.2054	.1848	.2033	.2033	.1867	.2012
2	.168	.1867	.181	.1848	.1848	.1886	.1646
3	.168	.1867	.1646	.1848	.1848	.1698	.1629
4	.1848	.1867	.1829	.1848	.1848	.1886	.1829
5	.2957	.2241	.2033	.2957	.2587	.2241	.2033
6	.4024	.4294	.2926	.4294	.3734	.4854	.4344
7	.5853	.6224	.6036	.6036	.5544	.6348	.5609
8	.5304	.5658	.591	.5359	.5487	.5788	.5375
9	.4656	.4481	.4755	.4835	.443	.4066	.4108
10	.2774	.333	.394	.4435	.4075	.3403	.3155
11	.2915	.3601	.3189	.4024	.362	.2926	.3155
12	.2543	.3121	.3155	.3439	.3045	.197	.3045
13	.3189	.2601	.3366	.362	.3121	.2126	.3189
14	.2481	.2629	.3045	.3582	.3366	.2149	.3155
15	.2686	.2629	.3012	.362	.3403	.1949	.3366
16	.2149	.2658	.2865	.3801	.333	.3224	.3544
17	.3258	.298	.3366	.3801	.3721	.3403	.3294
18	.394	.4066	.4344	.4163	.4252	.4119	.3761
19	.6161	.6161	.6468	.6535	.5601	.567	.5914
20	.5975	.5729	.6468	.5914	.5788	.5359	.5359
21	.5359	.5415	.5788	.5415	.5228	.4938	.5415
22	.4066	.4294	.4854	.4294	.4108	.3761	.4108
23	.2614	.2534	.2987	.2801	.2614	.2865	.2614
24	.2553	.2054	.2012	.2241	.2241	.1867	.2353
Max	**.6161**	**.6224**	**.6468**	**.6535**	**.5788**	**.6348**	**.5914**
Min	**.168**	**.1867**	**.1646**	**.1848**	**.1848**	**.1698**	**.1629**
Avg	**.3432**	**.3515**	**.3652**	**.3864**	**.3620**	**.3348**	**.3501**

 Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] **BU 0931**
Substation No/ Name :- 254037 / NIGADI
Feeder No / Name : 204 / 11 KV CHINCHNER GAVTHAN **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.056	.0373	.0554	.0747	.0739	.0549
2	.056	.0554	.037	.037	.0747	.0739	.0554
3	.056	.0554	.0554	.037	.0566	.0554	.0739
4	.0739	.0549	.0747	.037	.0566	.0554	.0549
5	.0924	.0724	.0739	.0739	.1109	.0924	.0732
6	.1463	.1294	.1307	.1478	.1494	.1494	.1294
7	.2195	.2033	.2054	.2033	.1848	.2241	.1867
8	.1663	.1848	.1991	.1663	.1646	.1663	.1848
9	.128	.1478	.0914	.128	.1433	.1254	.1254
10	.1267	.1463	.0895	.1612	.1629	.1543	.124
11	.1075	.0724	.0857	.0895	.1463	.1387	.0886
12	.1063	.0716	.0876	.0905	.1029	.1029	.0709
13	.0886	.0716	.0886	.0185	.1063	.1029	.0351
14	.0709	.0537	.0895	.0732	.1214	.0867	.0526
15	.0709	.0709	.0886	.0716	.1017	.1052	.0709
16	.1075	.0537	.0724	.0716	.0857	.0709	.0867
17	.1075	.0716	.0724	.0905	.104	.0886	.0876
18	.1227	.1052	.0914	.1463	.1075	.124	.1086
19	.1991	.1646	.1663	.1848	.1848	.1478	.1829
20	.2012	.1478	.1663	.1848	.168	.1478	.1829
21	.1663	.1307	.1294	.1478	.1463	.1478	.1494
22	.112	.112	.1109	.1294	.1267	.1109	.1307
23	.0747	.0739	.0739	.0934	.0914	.0924	.0747
24	.056	.056	.0373	.0554	.0747	.0739	.0732
Max	**.2195**	**.2033**	**.2054**	**.2033**	**.1848**	**.2241**	**.1867**
Min	**.056**	**.0537**	**.037**	**.0185**	**.0566**	**.0554**	**.0351**
Avg	**.1130**	**.0984**	**.0981**	**.1039**	**.1186**	**.1130**	**.1024**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] BU 0931
Substation No/ Name :- 254037 / NIGADI
Feeder No / Name : 205 / 11KV VARNE GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.0739	.1086	.1109	.1109	.1075	.1463
2	.112	.0739	.1109	.1109	.1109	.1086	.1086
3	.112	.0747	.1097	.1109	.1109	.0905	.1097
4	.1294	.0739	.1097	.1109	.1294	.0905	.1086
5	.1478	.0934	.1075	.1478	.1663	.128	.1097
6	.1829	.168	.1663	.2218	.2402	.2218	.2507
7	.3475	.2801	.3921	.3696	.3475	.2957	.3696
8	.2926	.2012	.3258	.2772	.3475	.2926	.3475
9	.2896	.2378		.3077	.2835	.2353	.2254
10	.1753	.2303	.2149	.2229	.1753	.1823	.1734
11	.1734	.1907	.1387	.1886	.1791	.1372	.1677
12	.1715	.1907	.2103	.1543	.156	.1526	.1696
13	.1612	.1753	.1949	.12	.1402	.12	.1341
14	.1433	.1417	.1791	.1387	.1402	.1387	.1526
15	.1629	.1417	.1595	.1311	.1526	.1387	.1357
16	.1433	.124	.1448	.1326	.1696	.1612	.1543
17	.1595	.1433	.1791	.1991	.2058	.1802	.1753
18	.2103	.2058	.2353	.2561	.2401	.2543	.2686
19	.2772	.2743	.3696	.3326	.3077	.3366	.3292
20	.2743	.2715	.2957	.3109	.2743	.2896	.3142
21	.2218	.2353	.2801	.2587	.2195	.2743	.2772
22	.2033	.1991	.2054	.2218	.1629	.2012	.2427
23	.1109	.128	.112	.1307	.128	.1629	.1494
24	.112	.0739	.1097	.112	.112	.1075	.1646
Max	**.3475**	**.2801**	**.3921**	**.3696**	**.3475**	**.3366**	**.3696**
Min	**.1109**	**.0739**	**.1075**	**.1109**	**.1109**	**.0905**	**.1086**
Avg	**.1844**	**.1668**	**.1939**	**.1949**	**.1921**	**.1837**	**.1994**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] BU 0931
Substation No/ Name :- 254068 / BHATMARALI
Feeder No / Name : 201 / 11 kv BHATMARALI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.3353	.0381	.0343	.0343	.6516	.7621
2	.2401	.2812	.0381	.0343	.0343	.5693	.724
3	.2401	.2881	.0381	.0343	.0343	.5535	.7049
4	.3772	.3258	.0381	.0343	.0343	.5535	.7049
5	.4287	.3281	.0381	.0343	.0343	.6081	.7621
6	.463	.5281	.0572	.0343	.0343	.7186	.8954
7	.583	.6836	.0572	.0343	.0343	.9374	1.1241
8			.4763	.6687	.5658		
9			.7716	1.0454	1.2003		
10			.8573	1.0688	1.4098		
11			1.166	1.2517	1.4861		
12			1.1317	1.2176	1.2574		
13			1.2003	1.2803	1.4289		
14	.0381	.0343	1.2689	1.0978	1.448	.0514	
15	.0381	.0343	1.1317	1.1797	1.5051	.0343	.0312
16	.0381	.0343				.0343	.0354
17	.0335	.0381				.0381	.0343
18	.0316	.0572				.0572	.0343
19	.0469	.0572				.0572	.0343
20	.048	.0572				.0572	.0343
21	.0492	.0572				.0572	.0343
22	.0328	.0572	.0343		.048	.0572	.0343
23	.0328	.0572	.0343	.0514	.0335	.0572	.0343
24	.2572	.3605	.0381	.0343	.0343	.6718	.7621
Max	**.583**	**.6836**	**1.2689**	**1.2803**	**1.5051**	**.9374**	**1.1241**
Min	**.0316**	**.0343**	**.0343**	**.0343**	**.0335**	**.0343**	**.0312**
Avg	**.1798**	**.2008**	**.4675**	**.5374**	**.5921**	**.3203**	**.3968**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] BU 0931
Substation No/ Name :- 254068 / BHATMARALI
Feeder No / Name : 202 / 11 KV KUSAVADE GAVTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1629	.1524	.1543	.1543	.1612	.1905
2	.1372	.1578	.1524	.1543	.1543	.1578	.1715
3	.1372	.1417	.1524	.1372	.1372	.1433	.1524
4	.1372	.1402	.1524	.1715	.1715	.1402	.1524
5	.2229	.2149	.2286	.2572	.1715	.2454	.2286
6	.3772	.2629	.381	.3086	.2229	.394	.3239
7	.3944	.439	.4763	.4287	.4287	.4298	.4763
8	.4115	.4207	.4191	.3086	.3429	.4207	.381
9	.362	.3086	.2401	.3366	.381	.3258	.3292
10	.2858	.2401	.2401	.3258	.3048	.2572	.2686
11	.3239	.2229	.2743	.2303	.2858	.2743	.2715
12	.2667	.2229	.2572	.2561	.2667	.2743	.1772
13	.2667	.1715	.2743	.2172	.3429	.2572	
14	.2286	.2058	.2743	.2686	.381	.2572	
15	.2667	.2229	.2743	.2686	.3429	.2401	.2835
16	.2858	.1543	.2915	.2012	.1905	.1886	.2715
17	.2481	.2667	.2743	.2401	.3109	.2286	.2572
18	.3292	.3048	.3086	.3429	.3155	.3048	.2743
19	.4805	.4954	.463	.463	.5014	.5335	.3086
20	.4656	.4954	.4287	.4973	.4572	.5335	.3258
21	.4207	.4572	.4115	.3772	.4031	.4954	.3429
22	.3109	.3429	.3174	.3258	.2804	.3048	.2915
23	.181	.1905	.2229	.2058	.1578	.2477	.2915
24	.2058	.1612	.1524	.1372	.1372	.1646	.2096
Max	**.4805**	**.4954**	**.4763**	**.4973**	**.5014**	**.5335**	**.4763**
Min	**.1372**	**.1402**	**.1524**	**.1372**	**.1372**	**.1402**	**.1524**
Avg	**.2875**	**.2668**	**.2841**	**.2756**	**.2851**	**.2908**	**.2718**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] BU 0931
Substation No/ Name :- 254068 / BHATMARALI
Feeder No / Name : 203 / 11 kv PADALI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0791	1.1622	.9945	1.0631	.08	.0953
2	.0514	.081	1.105	.9431	1.0288	.08	.0953
3	.0514	.0655	1.086	.9088	1.1145	.0857	.0953
4	.0514	.0625	1.105	.9259	1.2003	.0781	.0953
5	.0857	.0886	1.1431	.8916	1.2174	.0857	.0953
6	.0686	.0819	1.1622	.8916	1.2517	.0781	.0953
7	.0514	.0983	1.3336	1.3375	1.286	.125	.0953
8	.0343	1.0437				1.0364	1.7194
9		1.3546				1.406	1.7652
10	1.448	1.5775				1.5604	2.073
11	1.4861	1.5775				1.8861	1.7859
12	1.6004	1.6289				1.9719	1.656
13	1.6194	1.6118				1.9719	
14	1.6575	1.5432	.0343	.0838	.0953	2.0062	
15	1.7718	1.6057	.0343	.0983	.0953	1.9719	1.6762
16			.0343	.0983	.0953		
17			.0343	.1372	.0857		
18			.0343	.12	.1147		
19			.0343	.12	.112		
20			.0343	.0343	.1174		
21			.0343	.0514	.0937		
22	.0838	.0953	.0343	.0514	.0972	.0953	.0343
23	.0857	.0953	.0343	.0514	.1029	.0953	.0514
24	.0343	.0791	1.1431	1.0631	1.046	.0838	.0953
Max	**1.7718**	**1.6289**	**1.3336**	**1.3375**	**1.286**	**2.0062**	**2.073**
Min	**.0343**	**.0625**	**.0343**	**.0343**	**.0857**	**.0781**	**.0343**
Avg	**.6019**	**.7094**	**.5324**	**.4890**	**.5676**	**.8165**	**.7202**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] BU 0931
Substation No/ Name :- 254068 / BHATMARALI
Feeder No / Name : 204 / 11 KV NINAM GAVTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1578	.1524	.1372	.1372	.1753	.1715
2	.1543	.1433	.1524	.1543	.2058	.1595	.1524
3	.1372	.1417	.1524	.1543	.1543	.1629	.1524
4	.1372	.1595	.1524	.1715	.1543	.1772	.1524
5	.2058	.2454	.2096	.2572	.1715	.2658	.2286
6	.2572	.3366	.381	.3086	.2058	.3506	.4001
7	.4801	.4961	.5906	.4973	.4801	.567	.6287
8	.4287	.543	.4763	.4287	.3601	.5138	.4572
9	.5716	.583	.5658	.5493	.3048	.6001	.3403
10	.5716	.583	.5487	.6089	.381	.3601	.3155
11	.381	.5144	.5487	.4755	.3048	.3258	.2195
12	.4763	.5487	.5487	.4075	.6287	.2915	.1991
13	.4572	.3944	.3601	.4031	.6668	.4115	
14	.381	.3429	.2572	.4207	.4954	.3944	
15	.3048	.3429	.3772	.5853	.6478	.3429	.2328
16	.381	.2401	.3772	.1928	.2096	.1886	.3077
17	.2279	.5906	.3944	.5144	.6516	.4001	.2915
18	.3439	.4191	.2743	.463	.4031	.4001	.2572
19	.5194	.5335	.4458	.4973	.4805	.5335	.2401
20	.4733	.5144	.3944	.4801	.443	.5335	.2229
21	.4344	.4572	.3086	.3772	.3681	.4954	.2572
22	.3403	.3239	.2743	.2743	.3292	.3048	.3258
23	.2149	.2096	.1715	.2058	.2149	.2096	.3086
24	.1715	.1612	.1524	.12	.12	.1829	.1715
Max	**.5716**	**.5906**	**.5906**	**.6089**	**.6668**	**.6001**	**.6287**
Min	**.1372**	**.1417**	**.1524**	**.12**	**.12**	**.1595**	**.1524**
Avg	**.3426**	**.3743**	**.3444**	**.3618**	**.3549**	**.3478**	**.2742**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] BU 0931
Substation No/ Name :- 256008 / 110 KV ATIT
Feeder No / Name : 201 / 11 KV KHOJEWADI SINGLE PH. SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
24	.0686
Max	.0686
Min	.0686
Avg	.0686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] BU 0931
Substation No/ Name :- 256008 / 110 KV ATIT
Feeder No / Name : 202 / 11 KV SATARA SINGLE PH. SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
24	.0686
Max	.0686
Min	.0686
Avg	.0686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] BU 0931
Substation No/ Name :- 256008 / 110 KV ATIT
Feeder No / Name : 203 / 11 KV UMBRAJ SINGLE PH. SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
24	.0686
Max	.0686
Min	.0686
Avg	.0686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] **BU 0931**
Substation No/ Name :- 256008 / 110 KV ATIT
Feeder No / Name : 204 / 11 KV KAY PULP **NON SHEDDABLE EXPRESS HV FEEDERS**
Feeder KV- 11 / OUTGOING **(NON-CONTINOUS PROCESS)(NO STAGGERING)**

DATE	01-NOV-17
HR	Load (MW)
24	.0686
Max	.0686
Min	.0686
Avg	.0686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] **BU 0931**
Substation No/ Name :- 256008 / 110 KV ATIT
Feeder No / Name : 403 / 33 KV KIRLOSKAR EXPRESS Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS (NON-CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-NOV-17
HR	Load (MW)
24	.4116
Max	.4116
Min	.4116
Avg	.4116

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
SATARA[118] **BU 0931**
Substation No/ Name :- 256008 / 110 KV ATIT
Feeder No / Name : 408 / 33 KV SHAHU LIS **PURELY LIS FEEDERS**
Feeder KV- 33 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
24	.2058
Max	.2058
Min	.2058
Avg	.2058

 Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
WATHAR[123] **BU 0981**
Substation No/ Name :- 254034 / PIMPODA
Feeder No / Name : 301 / PIMPODE Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 22 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.192		1.0242	1.1069		
2	.16		.9602	1.1069		
3	.16		.9602	1.1069		
4	.16		.9831	1.2334		
5	.192		1.0242	1.3283		
6	.2561		1.2163	1.5813		
7	.2561		1.6644	2.0873		
8	1.1843		.128	.1898		
9	1.8442		.16	.1581		
10	2.0317	.192	.1581	.1898	2.6749	2.6886
11	2.0317	.192			3.1367	3.0087
12	2.2283	.192	.1265		2.9492	3.1047
13	2.13	.192	.1265		3.3951	3.1367
14	2.1956	.16	.128		3.2236	3.1047
15	2.2283	.16	.1581		3.2236	2.7526
16		.16	.1265		.2401	.3521
17		.1943	.16		.2058	.192
18	.1638	.192	.16		.1715	.192
19		.192	.16		.2401	.2561
20		.192	.1581			.2241
21		.1638	.1898			.2241
22		.1638	.1898			.192
23		.1311	.1898			.16
24	.192		1.0242	1.0437		
Max	**2.2283**	**.1943**	**1.6644**	**2.0873**	**3.3951**	**3.1367**
Min	**.16**	**.1311**	**.1265**	**.1581**	**.1715**	**.16**
Avg	**1.0357**	**.1769**	**.4859**	**1.0120**	**1.9461**	**1.3992**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
WATHAR[123] BU 0981
Substation No/ Name :- 254034 / PIMPODA
Feeder No / Name : 302 / 22KV PIMPODE GAOTHAN GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219		.1791		
2	.1219		.1791		
3	.1219		.1791		
4	.1581		.2149		
5	.2214		.2149		
6	.4428		.4656		
7	.4744		.5731		
8	.4111		.5373		
9	.4915		.5731		
10	.3772	.2126	.3582	.3429	
11		.2835			
12		.2481			
13		.2481			
14		.2481			
15		.2481			
16		.3898			
17		.4607		.6173	.3361
18		.4607		.5144	.4108
19		.6379		.5487	.5975
20		.567			.5975
21		.4607			.4108
22		.3544			.4108
23		.2481			.2241
24	.1524		.1772		
Max	**.4915**	**.6379**	**.5731**	**.6173**	**.5975**
Min	**.1219**	**.2126**	**.1772**	**.3429**	**.2241**
Avg	**.2813**	**.3620**	**.3320**	**.5058**	**.4268**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
WATHAR[123] BU 0981
Substation No/ Name :- 254034 / PIMPODA
Feeder No / Name : 303 / SONKE GAOTHAN GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905		.1867	.1905		
2	.1905		.1867	.1905		
3	.1905		.1867	.1905		
4	.2286		.1867	.2286		
5	.3048		.2987	.2641		
6	.5658		.4481	.4481		
7	.6722		.6722	.6722		
8	.6348		.6348	.6348		
9	.4108		.5228	.5228		
10	.3658	.3734	.3658	.4108	.3429	.2614
11	.2561	.2987	.3658		.2743	.2614
12	.2241	.1867	.2218		.2743	.2241
13	.2195	.1867	.2241		.2401	.1867
14	.1638	.1494	.1494		.2401	.2241
15	.1867	.1494	.1867		.2401	.2241
16		.1494	.1867		.2058	.2241
17		.2614	.2987		.2743	.2614
18		.3734	.3734		.4115	.4481
19		.5228	.5975		.5487	.5975
20		.4854	.5228			.5228
21		.4108	.4481			.5228
22		.2987	.2987			.3734
23		.1638	.2263			.2241
24	.1905		.1867	.1905		
Max	**.6722**	**.5228**	**.6722**	**.6722**	**.5487**	**.5975**
Min	**.1638**	**.1494**	**.1494**	**.1905**	**.2058**	**.1867**
Avg	**.3122**	**.2864**	**.3323**	**.3585**	**.3052**	**.3254**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
WATHAR[123] BU 0981
Substation No/ Name :- 254034 / PIMPODA
Feeder No / Name : 304 / 22 KV SONAKE AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478		.2949	.1677		
2	.583		.2294	.1509		
3	.583		.2294	.1509		
4	.583		.2294	.1509		
5	.7125		.3277	.1677		
6	1.0364		.3932	.2012		
7	1.2308		.426	.2347		
8	.3239		.7865	.503		
9	.25		1.0814	.8718		
10	.0983	1.1843		1.0059	.2058	.3052
11	.0983	1.5364	.9831		.2401	.2622
12	.0983	1.3108	.8684		.2401	.2949
13	.0983	1.3108	1.1142		.3429	.3277
14	.0983	1.2125	1.1961		.3429	.3605
15	.0983	1.2452			.3086	.3521
16		.3277	1.0395		.3429	.3605
17		.3605	.8886		.3772	.3605
18		.3932	.2012		.4115	.3932
19		.3932	.2012		.4801	
20		.3277	.1677			.426
21		.3277	.218			.426
22		.3277	.1844			.3932
23		.2949	.1677			.3605
24	1.5242		.2949	.1677		
Max	**1.5242**	**1.5364**	**1.1961**	**1.0059**	**.4801**	**.426**
Min	**.0983**	**.2949**	**.1677**	**.1509**	**.2058**	**.2622**
Avg	**.5040**	**.7538**	**.5238**	**.3429**	**.3292**	**.3556**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
WATHAR[123] BU 0981
Substation No/ Name :- 254034 / PIMPODA
Feeder No / Name : 305 / 22 KV WATHAR (GAOTHAN) GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975		.2241	.2987		
2	.5601		.2241	.3361		
3	.5601		.2241	.3361		
4	.5228		.2241	.3734		
5	.5975		.3734	.5228		
6	.6348		.4854	.4481		
7	.7468		.7842	.7095		
8	.7095		.7095	.6722		
9	.6413		.5601	.5975		
10	.439	.3734	.4481	.5601	.4458	.3734
11	.4755	.3734	.5975		.3429	.4854
12	.5853	.3734	.6348		.3772	.6722
13	.3292	.3361	.6348		.3772	.5601
14	.3292	.3361	.3361		.3429	.3734
15	.6219	.3361	.2987		.2743	.2987
16		.3361	.2987		.3772	.6722
17		.3361	.4854		.4115	
18		.5228	.5975		.5144	.6348
19		.7095	.6722		.6173	.7842
20		.5975	.6348			.6722
21		.5228	.5228			.5601
22		.4108	.7095			.4481
23		.2614	.5975			.3734
24	.5601		.2241	.2241		
Max	**.7468**	**.7095**	**.7842**	**.7095**	**.6173**	**.7842**
Min	**.3292**	**.2614**	**.2241**	**.2241**	**.2743**	**.2987**
Avg	**.5569**	**.4161**	**.4792**	**.4617**	**.4081**	**.5314**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
WATHAR[123] BU 0981
Substation No/ Name :- 254034 / PIMPODA
Feeder No / Name : 306 / 22 KV WATHAR AG SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1357		.9831	1.3413		
2	.1357		.9175	1.2742		
3	.1357		.9175	1.2742		
4	.1696		.9175	1.2742		
5	.2035		1.0486	1.3413		
6	.3391		1.3108	1.5424		
7	.373		1.8351	1.9448		
8	1.2887		.2294	.3018		
9	1.8652		.2294	.2347		
10	2.0972	.1966	.2012	.2012	2.332	2.3594
11	1.8351	.1311	.1677		2.6749	2.6216
12	2.2283	.1311	.1677		2.8121	2.4905
13	2.0972	.1311	.1341		3.0178	2.6216
14	2.2283		.1677		3.0521	2.6216
15	1.9662	.1311	.1677		3.0864	2.4905
16		.1311	.1677		.2058	.1966
17		.1311	.1677		.2401	
18		.1966	.2012		.2743	.2294
19		.2294	.2347		.2743	.2949
20		.2294	.2347			.2294
21		.1966	.2347			.1966
22		.1638	.1677			.1966
23		.1311	.1341			.128
24	.1696		.9831	1.3748		
Max	**2.2283**	**.2294**	**1.8351**	**1.9448**	**3.0864**	**2.6216**
Min	**.1357**	**.1311**	**.1341**	**.2012**	**.2058**	**.128**
Avg	**1.0793**	**.1639**	**.4967**	**1.1004**	**1.7970**	**1.2828**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
WATHAR[123] BU 0981
Substation No/ Name :- 254034 / PIMPODA
Feeder No / Name : 307 / 22 KV Nandwal AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2881		.0038	.0038		
2	.2561		.0038	.0038		
3	.2561		.0038	.0038		
4	.2561		.0038	.0038		
5	.2881		.0038	.0038		
6	.4801		.0038	.0038		
7	.5441		.0038	.0038		
8	.0038		.426	.5182		
9	.0038		.7209	1.094		
10		.7537	.6722	.9717	.0034	.0038
11		.7865	.8322		.0034	.0038
12		.8848	.8642		.0034	.0038
13		.9175	1.0242		.0034	.0038
14		1.0159			.0034	.0038
15		1.0159	.5761		.0034	.0038
16		.0038	.0038		.0034	.0038
17		.0038	.0038		.0034	.0038
18		.0038	.0038		.0034	.0038
19		.0038	.0038		.0034	.0038
20		.0038	.0038			.0038
21		.0038	.0038			.0038
22		.0038	.0038			.0038
23		.0038	.0038			.0038
24	.2675		.0038	.0038		
Max	**.5441**	**1.0159**	**1.0242**	**1.094**	**.0034**	**.0038**
Min	**.0038**	**.0038**	**.0038**	**.0038**	**.0034**	**.0038**
Avg	**.2644**	**.3861**	**.2251**	**.2377**	**.0034**	**.0038**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
WATHAR[123] BU 0981
Substation No/ Name :- 254070 / 22 KV Switching Station Satara
Feeder No / Name : 301 / 22KV Koregaon Feeder KV- 22 / OUTGOING **SHEDDABLE URBAN**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3086	.2743		.2743	.3429	.2743
2	.3048	.2743	.3086		.2743	.3429	.2743
3	.3048	.3086	.2743		.3658	.3772	.3086
4	.4268	.2743	.3086		.4572	.3429	.2743
5	.5487	.3429	.4458		.5792	.5144	.4458
6	.6706	.7202	.6859		.7316	.8573	.6859
7	.8535	.8916	1.0631		.8535	.9602	1.0974
8	.884	.8573	.9602		.945	1.0288	1.0288
9	.9602	.583		.7926	.9602	.823	.7316
10	.6516	.583		.6401	.6859	.6516	.6401
11	.6173	.5487		.5792	.6859	.5487	.5487
12	.5487	.4115		.5487	.6173	.4801	.5182
13	.5144	.3772		.5182	.6173	.4458	.3963
14	.4115	.4115		.4572	.5144	.3772	.4268
15	.4115	.3429		.4268	.4801	.4801	.3658
16	2.0043	.4115		.4877	.5487	.5487	.3963
17	.5487	.5144		.5182	.6859	.583	.4268
18	.8916	.6173		.6097	.7545	.6516	.6401
19	.9945	.9259			.8916	.9259	.7926
20	.9602	.823		.7011	.823	.823	.7316
21	.8573	.7202		.6097	.7545	.6516	.6706
22	.6173	.6173		.4877	.6859	.5487	.6097
23	.3772	.4115		.3353	.4115	.4115	.4572
24	.3048	.3429	.3429		.2743	.3429	.3429
Max	**2.0043**	**.9259**	**1.0631**	**.7926**	**.9602**	**1.0288**	**1.0974**
Min	**.3048**	**.2743**	**.2743**	**.3353**	**.2743**	**.3429**	**.2743**
Avg	**.6654**	**.5258**	**.5182**	**.5509**	**.6197**	**.5858**	**.5452**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
WATHAR[123] BU 0981
Substation No/ Name :- 254070 / 22 KV Switching Station Satara
Feeder No / Name : 303 / 22 KV DEURGAOTHAN GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.2401	.1715		.1524	.1715	.1715
2	.1829	.2401	.1715		.1524	.1715	.1715
3	.1829	.2058	.1715		.1524	.2058	.1715
4	.2743	.2058	.1715		.2134	.1715	.2058
5	.3658	.2743	.2743		.2743	.2743	.2743
6	.4572	.4115	.4115		.3963	.4115	.4458
7	.5792	.5144	.6173		.4877	.4801	.6516
8	.4877	.5144	.5487		.5487	.5487	.6173
9	.3429	.4115		.4268	.583	.4115	.4268
10	.3086	.3429		.3658	.5144	.3429	.3353
11	.2743	.2401		.2439	.3429	.2401	.3048
12	.2743	.2401		.2134	.3429	.2058	.2743
13	.2401	.2401		.1829	.2743	.2058	.2134
14	.2058	.2058		.1829	.2743	.2058	.2134
15	.2058	.2058		.2134	.2743	.2401	.2134
16	.2058	.2058		.2439	.2743	.2401	.2134
17	.2743	.2401		.2439	.3086	.2743	.2439
18	.4115	.3086		.2439	.3429	.4458	.3658
19	.583	.583			.5487	.6173	.4877
20	.5144	.4801		.4572	.4801	.5144	.4268
21	.4801	.4115		.3963	.4115	.4458	.3963
22	.4115	.3429		.3048	.3429	.3772	.3353
23	.2401	.2058		.2134	.2058	.2058	.2134
24	.1829	.2058	.2058		.1829	.2058	.1715
Max	**.583**	**.583**	**.6173**	**.4572**	**.583**	**.6173**	**.6516**
Min	**.1829**	**.2058**	**.1715**	**.1829**	**.1524**	**.1715**	**.1715**
Avg	**.3278**	**.3115**	**.3048**	**.2809**	**.3367**	**.3172**	**.3144**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
WATHAR[123] BU 0981
Substation No/ Name :- 254070 / 22 KV Switching Station Satara
Feeder No / Name : 304 / 22KV KINHAI GAOTHAN GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2743	.2401		.3353	.2743	.2401
2	.2743	.2401	.2743		.3353	.2743	.2401
3	.2743	.2401	.2401		.3353	.2743	.2743
4	.3658	.2401	.2743		.4572	.2743	.2401
5	.4572	.3429	.3429		.6097	.3086	.3429
6	.6097	.6173	.583		.823	.6859	.6516
7	.823	.6859	.9259		.9755	.7545	.9602
8	.7926	.823	.7545		.8535	.8916	.8573
9	.8573	.5487		.7316	.8573	.7202	.6097
10	.6859	.5487		.6097	.7545	.6173	.5792
11	.583	.3772		.5487	.6859	.4801	.4877
12	.5144			.3658	.5487	.4115	.4877
13	.3429	.4115		.4268	.4115	.4458	.4268
14	.3772	.4458		.4572	.3429	.3429	.3658
15	.3429	.3429		.4572	.3429	.3772	.3963
16	.3772	.3429		.4572	.4115	.3772	.4268
17	.4801	.4801		.5182	.5487	.5144	.4572
18	.6859	.6173		.5792	.6173	.6173	.5792
19	.9259	.823		.823	.9602	.8916	.7621
20	.8573	.7545		.7621	.7888	.7888	.7011
21	.5144	.6516		.7011	.6859	.6173	.6097
22	.3772	.583		.6097	.6173	.5144	.4877
23	.3429	.3429		.3963	.3772	.3772	.3353
24	.3048	.2743	.3086		.3658	.3086	.2743
Max	**.9259**	**.823**	**.9259**	**.823**	**.9755**	**.8916**	**.9602**
Min	**.2743**	**.2401**	**.2401**	**.3658**	**.3353**	**.2743**	**.2401**
Avg	**.5184**	**.4786**	**.4382**	**.5629**	**.5851**	**.5058**	**.4914**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
WATHAR[123] BU 0981
Substation No/ Name :- 256002 / 110 KV SATARA-ROAD
Feeder No / Name : 301 / WATHAR i.e. 22KV KINHAI SEPARATED AG FEEDERS HAVING SPECIAL AG. Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
13		.0343			.1029	
24	3.914	3.9438	.1372	.0625	4.4582	4.8697
Max	**3.914**	**3.9438**	**.1372**	**.0625**	**4.4582**	**4.8697**
Min	**3.914**	**.0343**	**.1372**	**.0625**	**.1029**	**4.8697**
Avg	**3.914**	**1.9891**	**.1372**	**.0625**	**2.2806**	**4.8697**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
WATHAR[123] BU 0981
Substation No/ Name :- 256002 / 110 KV SATARA-ROAD
Feeder No / Name : 303 / 22 KV COOPER SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-NOV-17	02-NOV-17	03-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
13		.583			1.749	
24	.8048	.6173	1.7147	.6706	1.5089	1.2689
Max	.8048	.6173	1.7147	.6706	1.749	1.2689
Min	.8048	.583	1.7147	.6706	1.5089	1.2689
Avg	.8048	.6002	1.7147	.6706	1.6290	1.2689

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
WATHAR[123] BU 0981
Substation No/ Name :- 256002 / 110 KV SATARA-ROAD
Feeder No / Name : 304 / 22KV BHUINJ i.e. 22KV SEPARATED AG FEEDERS HAVING SPECIAL DEUR AG Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
13		8.6763			8.9506	
24	.1463	.2058	4.6982	2.0778	.1715	.1715
Max	.1463	8.6763	4.6982	2.0778	8.9506	.1715
Min	.1463	.2058	4.6982	2.0778	.1715	.1715
Avg	.1463	4.4411	4.6982	2.0778	4.5611	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
WATHAR[123] BU 0981
Substation No/ Name :- 256002 / 110 KV SATARA-ROAD
Feeder No / Name : 400 / AUXILIARY FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
24	.1905
Max	.1905
Min	.1905
Avg	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
SATARA DIVISION[516]
WATHAR[123] BU 0981
Substation No/ Name :- 256002 / 110 KV SATARA-ROAD
Feeder No / Name : 407 / 33KV VASANA **PURELY LIS FEEDERS**
Feeder KV- 33 / OUTGOING

DATE	02-NOV-17	06-NOV-17
HR	Load (MW)	Load (MW)
13	.1029	.1029
Max	.1029	.1029
Min	.1029	.1029
Avg	.1029	.1029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
AUNDH[571] **BU 6912**
Substation No/ Name :- 254026 / 33/22/11 KV Bhosare
Feeder No / Name : 201 / 11 KV Aundh Gaothan **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0543	.0566	.0381	.0543		.056	.0381
2	.0537	.0566	.0373	.0537		.056	.0381
3	.0543	.0566	.0377	.0532		.0566	.0377
4	.0549	.056	.0762	.0343		.0566	.0381
5	.0716	.056	.0747	.0537		.0566	.0739
6	.1086	.0747	.0943	.0914		.0739	.0934
7	.1097	.1109	.132	.1097		.1109	.0943
8	.1109	.112	.0934	.1109		.0747	.0754
9	.0732	.0566	.0754	.0914		.056	.0554
10	.0566	.056		.0747		.056	.0366
11	.056	.0995		.0543		.0377	
12	.0554	.3506				.0373	
13	.0554	.503			.1307	.0377	
14	.056	.0366			.112	.056	
15	.056	.0543			.1109	.037	
16	.056	.0362			.0747	.0347	
17	.0566	.0886			.0747	.0514	
18	.0747	.0905			.1307	.1097	
19	.112	.1494			.168	.1663	
20	.132	.1307			.1494	.1294	
21	.112	.112			.1307	.1109	
22	.0754	.0934			.0934	.0762	
23	.0566	.0762			.0754	.0566	
24	.6516	.0566	.0566	.0549		.0566	.0373
Max	**.6516**	**.503**	**.132**	**.1109**	**.168**	**.1663**	**.0943**
Min	**.0537**	**.0362**	**.0373**	**.0343**	**.0747**	**.0347**	**.0366**
Avg	**.0981**	**.1071**	**.0716**	**.0697**	**.1137**	**.0688**	**.0562**

 Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
AUNDH[571] **BU 6912**
Substation No/ Name :- 254026 / 33/22/11 KV Bhosare
Feeder No / Name : 202 / 11 KV Aundh AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.0377	.0377	.0324		.0377	.0373
2	.0297	.0377	.0914	.2286		.0377	.0381
3	.0286	.0377	.0937	.3086		.0377	.0381
4	.0286	.0377	.104	.3163		.0377	.037
5	.029	.0377	.1974	.3906		.0377	.0549
6	.0423	.0566	.2195	.4801		.056	.0452
7	.0434	.0739	.2591	.5535		.0739	.0566
8	.0434	.0566	.2526	.6097		.0747	.056
9	.0301	.0377	.2439	.643		.0566	.0452
10	.3429	.2378		.0347		.6371	.5502
11	.4715	.3462		.0347		.7225	
12	.4778					.7343	
13	.4904				.0747	.759	
14	.4923	.5792			.3858	.7407	
15	.4572	.5944			.4934	.7562	
16	.5357	.5268			.0566	.4167	
17	.5068	.4607			.0566	.3668	
18	.0566	.0509			.0754	.0514	
19	.0754	.052			.0566	.052	
20	.0566	.0514			.0566	.0514	
21	.0566	.0497			.0566	.0514	
22	.0566	.0373			.0566	.0543	
23	.0566	.0381			.0566	.0549	
24	.5668	.0377	.0377	.0332		.0377	.0566
Max	**.5668**	**.5944**	**.2591**	**.643**	**.4934**	**.759**	**.5502**
Min	**.0286**	**.0373**	**.0377**	**.0324**	**.0566**	**.0377**	**.037**
Avg	**.2086**	**.1580**	**.1537**	**.3055**	**.1296**	**.2473**	**.0923**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
AUNDH[571] **BU 6912**
Substation No/ Name :- 254026 / 33/22/11 KV Bhosare
Feeder No / Name : 303 / BHOSARE AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 22 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0716	.0754	.0747	.0716	.0747	.0754	.0754
2	.0732	.0754	.2187	.3429	.4858	.0754	.0754
3	.0732	.0754	.2134	.4458	.4687	.0754	.0762
4	.0716	.0754	.3125	.503	.4687	.0754	.0747
5	.0701	.0754	.3125	.8288	.6249	.0754	.0754
6	.0709	.0754	.3841	.9069	.9145	.0754	.0747
7	.0716	.0754	.4687	.9945	1.0669	.0754	.0762
8	.0716	.0747		1.2003	.0747	.0747	.1132
9	.0732	.0754	.4801	1.2003		.0747	.0762
10	1.2003	1.1336		.0747		.3239	1.2803
11	1.2955	1.4403				.2812	
12	1.2803	1.3927				.3201	
13	1.3108	1.5623		.0747	.0754	1.5623	
14	1.4918	1.5364			.0754	1.6964	
15	1.4575	1.6194		.0747	.0747	1.8122	
16	1.4403	1.5364		.0747		1.7604	
17	1.1069	1.3123		.0747	.0747	1.8435	
18	.0747	.0754		.0747	.0754	.0747	
19	.0754	.112		.0747	.0747	.1132	
20	.0754	.1132		.0747	.0747	.0747	
21	.0754	.0754		.0747	.0747	.0762	
22	.0754	.0747		.0747	.0754	.0747	
23	.0754	.0747		.0747	.0754	.0754	
24	2.2996	.0754	.0754	.0701	.0747	.0754	.0754
Max	**2.2996**	**1.6194**	**.4801**	**1.2003**	**1.0669**	**1.8435**	**1.2803**
Min	**.0701**	**.0747**	**.0747**	**.0701**	**.0747**	**.0747**	**.0747**
Avg	**.5826**	**.5338**	**.2822**	**.3517**	**.2634**	**.4517**	**.1885**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
AUNDH[571] **BU 6912**
Substation No/ Name :- 254026 / 33/22/11 KV Bhosare
Feeder No / Name : 304 / BHOSARE GAONTHAN **GAOTHAN FEEDER**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.3018	.381	.2507	.3018	.3018	.3772
2	.2534	.3018	.3772	.2481	.2987	.2987	.3772
3	.2534	.3018	.3734	.2454	.3018	.2987	.381
4	.0716	.3395	.4572	.2507	.2987	.3018	.5544
5	.2507	.3734	.4527	.2896	.3734	.3395	.7316
6		.5601		.5121	.679	.5601	.8215
7		.8131	.3734	.6447	.7468	.7392	.8299
8	.6516	.5601		.6584	.5601	.6722	.9431
9	.5014	.5658	.7468	.5373	.7545	.5601	
10	.4298	.4481		.4481	.5487		.5601
11	.3696	.4904			.4207		
12	.3696	.3734			.3772		
13	.3696	.3696		.4481	.3772	.5228	
14	.3326	.3734		.3734	.3772	.4904	
15	.3734	.3772		.3734	.3734	.4481	
16	.3734	.4108		.3734		.415	
17	.3734	.4527		.3734	.3734	.4481	
18	.5601	.5228		.4481	.5601	.5544	
19	.679	.8299		.7468	.6722	.8299	
20	.5601	.7468		.7316	.5601	.7468	
21	.5601	.6036		.6653	.5658	.6859	
22	.4527	.5281		.5601	.4527	.5658	
23	.3772	.5228		.3734	.3772	.4572	
24	2.2996	.3772	.4572	.2534	.3018	.3772	.3734
Max	**2.2996**	**.8299**	**.7468**	**.7468**	**.7545**	**.8299**	**.9431**
Min	**.0716**	**.3018**	**.3734**	**.2454**	**.2987**	**.2987**	**.3734**
Avg	**.4872**	**.4810**	**.4524**	**.4457**	**.4632**	**.5054**	**.5949**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
AUNDH[571] **BU 6912**
Substation No/ Name :- 254026 / 33/22/11 KV Bhosare
Feeder No / Name : 305 / KHATAV GAOTHAN **GAOTHAN FEEDER**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2835	.3018	.3018	.3582	.3018	.3048	.3048
2	.2804	.3018	.3048	.362	.3018	.3018	.3018
3	.2865	.3018	.2987	.3658	.3018	.3018	.3734
4	.2835	.3429	.3772	.0434	.2987	.3018	.381
5	.3582	.415	.5716	.5068	.3658	.381	.5658
6	.5068	.6097	.8215	.6584	.7468	.6859	.6859
7	.6584	.9054	.8962	.7392	.9431	.9808	.7468
8	.8954	.8299	.7545	.8048	.8299	.8215	
9	.724	.6348	.6722	.724	.7545	.6722	.8299
10	.5487	.5601		.5228	.5544	.5175	.5228
11	.4435	.3696		.4481	.4805	.4435	
12	.4108	.4481			.4435	.4435	
13	.3734	.3772		.4481	.415	.3696	
14	.3734	.3696		.4481		.3696	
15	.3395	.3696		.4481	.3734	.3734	
16	.3772	.3772		.4481	.3696	.4435	
17	.4706	.4481		.4481	.4481	.4481	
18	.6283	.6036		.5601	.5853	.6722	
19	.8299	.9709		.9335	.8962	.8962	
20	.7922	.8299		.8589	.8589	.8299	
21	.7545	.6036		.7468	.7167	.7468	
22	.5716	.5228		.5228	.5658	.679	
23	.381	.4527		.3734	.4527	.4572	
24	2.1053	.3395	.381	.3658	.3018	.3429	.3048
Max	**2.1053**	**.9709**	**.8962**	**.9335**	**.9431**	**.9808**	**.8299**
Min	**.2804**	**.3018**	**.2987**	**.0434**	**.2987**	**.3018**	**.3018**
Avg	**.5699**	**.5119**	**.5380**	**.5276**	**.5350**	**.5327**	**.5017**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
AUNDH[571] **BU 6912**
Substation No/ Name :- 254026 / 33/22/11 KV Bhosare
Feeder No / Name : 306 / KHATAV AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 22 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0701	.0754	.0747	.0709	.0747	.0754	.0754
2	2.0576	1.6446	.0754	.0716	.0747	2.0729	2.5911
3	2.0576	1.7924	.0747	.0701	.0732	1.9608	2.7206
4	2.2043	1.7924	.0762	.0716	.0747	1.9845	2.9492
5	3.3532	2.0729	.0754	.0724	.0747	2.1872	4.1438
6	.381	2.2024	.0762	.1139	.0754	2.7526	4.409
7	4.4582	3.3813	.0762	.1063	.0754	3.9781	4.9154
8	4.9021	3.8668	.0762	.0701	.0747	4.4239	5.3041
9	3.3532	3.408	.0754	.0709		4.4277	4.9394
10	.0701	.0747		3.9323		.0754	.0762
11	.0754	.0762		4.5877		.0762	
12	.0747	.0762				.0754	
13	.0747	.0762		.0747	5.1383	.0754	
14	.0747	.0754		.0747		.0754	
15	.0747	.0754		.0747	5.9671	.0747	
16	.0754	.0754		.0747		.0754	
17	.0754	.1143		.0747	4.6411	.0762	
18	.0747	.1132		.0747	2.5606	.0762	
19	.0747			.0747	2.7526	.1143	
20	.0747			.0732	2.7831	.1143	
21	.0754	.0762		.0747	.0754	.0754	
22	.0754	.0754		.0747	.0754	.0747	
23	.0754	.0747		.0732	.0754	.0762	
24	3.077	.0754	.0762	.0716	.0747	.0754	.0754
Max	**4.9021**	**3.8668**	**.0762**	**4.5877**	**5.9671**	**4.4277**	**5.3041**
Min	**.0701**	**.0747**	**.0747**	**.0701**	**.0732**	**.0747**	**.0754**
Avg	**1.1233**	**.9680**	**.0757**	**.4404**	**1.3745**	**1.0447**	**2.9272**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
AUNDH[571] **BU 6912**
Substation No/ Name :- 254053 / 33/22 KV Pusesavali
Feeder No / Name : 301 / 22 KV R Kurle AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 22 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1132	.1132	.1132	.1132	.1509	.1132
2	.1132		1.5729	1.2452	1.3435	.1509	.1132
3	.1132	.1132	1.5729	1.2452	1.3435	.1509	.1132
4		.1097	1.5402	1.2955	1.3108	.1509	.1132
5		.1132	1.5729	1.2955	1.3763	.2241	.1509
6	.1886	.1886	1.6057	1.4746	1.5402	.2987	.1886
7		.3395	1.9006	1.8351	1.9334	.3734	.3395
8		.2641	1.9006	1.9989	2.0972	.3395	.3018
9	.2263	.1886	1.8351	1.9662	1.9989	.1132	.1867
10	2.2024	2.0405	.1509	.2241	.1509	2.1052	2.1956
11	2.3266	2.2672	.0754	.0754	.1509	2.2024	2.332
12	2.5232	2.2672	.1509	.1509	.1509	2.1052	2.7206
13	2.7526	2.6558	.1886	.1867	.1509	2.6558	2.7206
14	2.7526	2.2348	.1509	.1867	.1509	2.7854	2.7206
15	2.7199	2.3644	.1509	.1867	.1509	2.4939	2.8502
16	2.6871	2.5587	.2263	.2241	.1886	2.6558	2.6882
17	2.4249	2.4939	.1509	.1886	.1509	2.3644	2.5911
18	.1509	.0754		.2263	.2614	.1509	.2263
19	.2263	.2263	.2263	.2641	.2614	.2263	.2263
20	.2263	.1886	.2263	.2641	.2241	.2263	.2641
21	.1886	.1886	.1886	.2641	.2241	.2263	.2641
22	.1509	.1509	.1509	.1886	.1867	.1886	.1886
23	.1509	.1509	.1132	.1509	.1509	.1509	.1886
24	.9717	.1132	.1132	.1132	.1509	.1509	.1132
Max	**2.7526**	**2.6558**	**1.9006**	**1.9989**	**2.0972**	**2.7854**	**2.8502**
Min	**.1132**	**.0754**	**.0754**	**.0754**	**.1132**	**.1132**	**.1132**
Avg	**1.1605**	**.9307**	**.6903**	**.6402**	**.6567**	**.9434**	**.9963**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
AUNDH[571] **BU 6912**
Substation No/ Name :- 254053 / 33/22 KV Pusesavali
Feeder No / Name : 302 / 22 KV Pusesavali Gaothan **GAOTHAN FEEDER**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.3018	.3018	.2641	.2641	.2614	.3018
2	.2263		.3018	.2641	.2641	.2614	.3018
3	.2263	.3018	.3018	.2641	.2641	.2614	.3018
4	.2263	.3018	.3018	.2641	.2641	.2614	.3018
5	.3018	.3772	.3395	.3395	.3772	.3734	.3772
6	.5658	.6413	.5281	.5281	.5658	.5601	.6036
7	.7545	.9054	.8962	.7922	.9431	.924	.8589
8	.7167	.8048	.7922	.679	.8215	.7762	.7167
9	.6036	.6036	.6413	.679	.6413	.6036	.5228
10	.4527	.5281	.5658	.5228	.6036	.6036	.5601
11		.5281	.5281	.4481	.6413	.4904	.4854
12	.4904	.4904	.5281	.5228	.5281	.3772	.4481
13	.4527	.4527	.4527	.4854	.5281	.415	.4481
14	.4527	.4527	.5658	.4854	.4904	.4527	.4481
15	.4904	.4904	.3772	.4854	.5281	.4904	.4108
16	.5121	.4527	.4527	.4854	.4904	.415	.4481
17	.5658	.4904	.415	.4527	.4108	.4904	.4854
18	.6036	.6036	.5658	.5658	.5228	.6036	.5281
19	.7922	.7922	.7167	.8299	.7095	.7167	.7545
20	.7545	.7167	.679	.6413	.7095	.679	.7468
21	.7545	.6348	.6413	.6413	.6348	.679	.679
22	.5658	.4904	.4527	.4904	.5228	.5658	.5281
23	.415	.415	.3772	.3772	.3734	.415	.3395
24	1.1336	.3018	.3018	.3018	.2641	.2987	.3018
Max	**1.1336**	**.9054**	**.8962**	**.8299**	**.9431**	**.924**	**.8589**
Min	**.2263**	**.3018**	**.3018**	**.2641**	**.2641**	**.2614**	**.3018**
Avg	**.5341**	**.5251**	**.5010**	**.4921**	**.5151**	**.4990**	**.4958**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
AUNDH[571] **BU 6912**
Substation No/ Name :- 254053 / 33/22 KV Pusesavali
Feeder No / Name : 303 / 22 KV Vadgaon AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 22 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1509	.1886	.2263	.2241	.2263
2	2.0081		.1509	.1886	.2263	2.7526	2.5232
3	2.0317	2.7854	.1509	.1886	.2195	2.7199	2.556
4	2.0317	2.7854	.1509	.1886	.2263	2.7199	2.6216
5	2.0972	2.9492	.1886	.2263	.2263	2.7854	2.7199
6	2.2611	3.3097	.2263	.2641	.2641	2.9492	3.1459
7		4.26	.415	.3772	.415	3.3036	3.4979
8		4.4239	.3772	.3772	.3772	3.3036	3.8013
9		3.2114	.3018	.1509	.2263	3.4332	3.7894
10	.1509	.2263	4.26	4.2105	4.1457	.3018	.2987
11	.1509	.2263	4.3256	3.8866	4.5992	.1886	.2987
12	.1509		4.6315	4.2753	5.1174	.2641	.2241
13	.1509		4.923	3.0445	5.1821	.3018	.2241
14	.1886		4.5992	4.7611	4.7935	.3018	.0377
15	.1886	.1886	4.5344		4.6639	.3018	.0377
16	.2263	.2641	4.923		4.6963	.3395	.0377
17	.2641	.2641	4.5344	3.8996	4.5668	.3772	.2614
18	.3018	.1886	.0754		.2987	.3018	.3395
19	.3018	.3018	.3395	.3395	.3361	.3772	.3395
20	.3018	.3018	.3395	.3395	.3361	.3018	.3018
21	.3018	.3018	.3772	.3018	.3361	.3018	.2641
22	.2641	.2641	.2641	.2641	.2614	.2641	.2641
23	.2263	.2263	.2263	.2263	.2614	.2641	
24	1.1336	.1886	.1886	.2263	.2263	.2241	.2263
Max	**2.2611**	**4.4239**	**4.923**	**4.7611**	**5.1821**	**3.4332**	**3.8013**
Min	**.1509**	**.1886**	**.0754**	**.1509**	**.2195**	**.1886**	**.0377**
Avg	**.7105**	**1.3428**	**1.6939**	**1.3298**	**1.7595**	**1.1918**	**1.2190**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
AUNDH[571] **BU 6912**
Substation No/ Name :- 254053 / 33/22 KV Pusesavali
Feeder No / Name : 304 / 22 KV Pusesavali AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 22 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366	.0377	.0377	.0754	.0377	.0377	.0377
2	.0377		1.1469	1.0814	1.2125	.0377	.0377
3	.0377	.0377	1.1469	1.0814	1.2125	.0377	.0377
4	.0377	.0377	1.1142	1.1142	1.2308	.0754	.0377
5	.0732	.0377	1.1469	1.1142	1.2955	.1132	.0754
6	.1509	.1132	1.1797	1.2452	1.4746	.1509	.1509
7	.1886	.1509	1.3603	1.3435	1.9662	.1867	.2641
8	.1132	.1509	1.5729	1.7695	2.0972	.1886	.1886
9	.0754	.1132	1.6385	1.7368	1.5729	.1132	.1132
10	1.6057	1.6712	.1132	.1132	.0754	2.0081	2.0729
11	1.9006	2.0405	.0754	.0754	.0754	1.9433	1.704
12	2.0645	2.0081	.0377	.0754	.0754	2.2024	1.8679
13	2.0317	2.2024	.0377	.0754	.0377	2.1052	1.9989
14	2.0972	2.0729	.0377	.1132	.0377	2.1052	2.3644
15	2.0972	1.9433	.0377	.1132	.0377	2.2672	2.4291
16	2.2283	1.9757	.0377	.1132	.0377	2.2024	2.3644
17	1.8351	1.9109	.0377	.0754	.0377	2.2024	2.4939
18	.1132	.1132	.0754	.0754	.0754	.0754	.1509
19	.1509	.1132	.1132	.0754	.0754	.0754	.1132
20	.1509	.1132	.1132	.1132	.0754	.0754	.1132
21	.1132	.1132	.1132	.1132	.0754	.0754	.1132
22	.0754	.0754	.1132	.1132	.0754	.0754	.1132
23	.0754	.0754	.0754	.0754	.0377	.0754	.0754
24	.0377	.0377	.0377	.0754	.0377	.0377	.0377
Max	**2.2283**	**2.2024**	**1.6385**	**1.7695**	**2.0972**	**2.2672**	**2.4939**
Min	**.0366**	**.0377**	**.0377**	**.0754**	**.0377**	**.0377**	**.0377**
Avg	**.722**	**.7454**	**.4750**	**.4982**	**.5403**	**.7695**	**.7898**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
AUNDH[571] **BU 6912**
Substation No/ Name :- 254053 / 33/22 KV Pusesavali
Feeder No / Name : 305 / 22 KV R Kurle Gaothan **GAOTHAN FEEDER**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
24	1.1336
Max	1.1336
Min	1.1336
Avg	1.1336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
AUNDH[571] **BU 6912**
Substation No/ Name :- 254053 / 33/22 KV Pusesavali
Feeder No / Name : 306 / 22 KV Vadgaon Gaothan **GAOTHAN FEEDER**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1132	.1132	.1132	.1132	.1132	.1132
2	.1132		.1132	.1132	.1132	.1132	.1132
3	.1132	.1097	.1132	.1132	.1132	.1132	.1132
4	.1132	.1132	.1132	.1132	.1132	.1132	.1132
5	.1509	.1132	.1509	.1132	.1509	.1886	.1509
6	.2195	.1886	.1829	.1509	.2263	.2614	.2263
7	.3018	.3018	.3018	.3018	.3395	.3361	.3395
8	.2641	.2641	.2641	.2263	.3018	.2641	.2641
9	.1509	.1886	.1886	.2263	.1886	.2263	.1867
10	.1509	.1509	.1886	.1509	.1509	.1509	.1509
11	.1132	.1509	.1509	.1132	.1132	.1132	.1132
12	.1132	.1132	.1132	.1132	.1132	.1132	.1132
13	.1132	.1132	.1509	.1132	.1132	.1132	.0754
14	.1132	.1132	.1132	.1132	.1509	.1132	.0754
15	.1132	.1132			.1132	.1132	.0754
16	.1132	.1132	.1132		.1132	.1132	.0754
17	.1509	.1132	.1509	.1132	.1509	.1509	.1132
18	.1886	.1509	.1509		.2241	.2263	.1886
19	.3395	.3018	.2641	.3395	.2614	.3395	.3018
20	.3395	.2641	.2641	.3395	.2987	.3018	.3018
21	.3018	.2263	.2263	.3018	.2614	.3018	.2641
22	.2263	.1886	.1886	.2263	.2241	.2263	.2263
23	.1509	.1509	.1509	.1509	.1867	.1509	.1509
24	1.1336	.1132	.1132	.1132	.1132	.1132	.1132
Max	**1.1336**	**.3018**	**.3018**	**.3395**	**.3395**	**.3395**	**.3395**
Min	**.1132**	**.1097**	**.1132**	**.1132**	**.1132**	**.1132**	**.0754**
Avg	**.2167**	**.1639**	**.1687**	**.1743**	**.1770**	**.1821**	**.1650**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
AUNDH[571] **BU 6912**
Substation No/ Name :- 254063 / 33/11 KV Gopuj SubStation
Feeder No / Name : 201 / Ladegaon High School Gaothan Feeder KV- 11 / OUTGOING **GAOTHAN FEEDER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.056	.0549	.056	.056	.056	.0566
2	.0566	.0566	.056	.056	.0566	.0566	.0566
3	.0566	.0566	.056	.056	.0566	.0566	.0566
4	.0566	.0754	.056	.056	.0566	.0566	.0566
5	.0754	.0747	.056	.0747	.0754	.056	.0754
6	.0943	.0934	.0739	.0747	.0943	.0739	.0924
7	.112	.132	.0747	.112	.112	.112	.1097
8	.1109	.0754	.1109	.112	.0914	.112	.0914
9	.0732	.0754	.0747	.0747	.0724	.0914	.0724
10	.0739	.0747	.0747	.0739	.0709	.0739	.0549
11	.0554	.0747	.056	.0724	.0716	.0905	.0549
12	.0554	.0747	.0747	.0732	.0724	.0709	.0549
13	.037	.0747	.112	.0549	.0732	.0724	.0549
14	.037	.056	.0566	.0554	.0732	.0543	.0549
15	.0554	.056	.056	.0554	.0732	.0543	.0549
16	.0554	.056	.056	.0554	.0732	.0724	.0732
17		.0747	.0754	.0549	.0739	.0724	.0732
18		.0914	.056	.1086	.112	.1097	.0914
19	.1886	.1294	.1307	.1448	.1307	.1448	.1097
20	.1509	.1494	.1307	.1463	.1509	.1646	.0732
21	.1509	.1307	.112	.1267	.132	.1463	.1097
22	.0943	.1109	.0747	.1097	.112	.1109	
23	.0747	.0747	.0747	.0549	.0747	.056	
24	.5668	.056	.056	.056	.056	.0566	.056
Max	**.5668**	**.1494**	**.1307**	**.1463**	**.1509**	**.1646**	**.1097**
Min	**.037**	**.056**	**.0549**	**.0549**	**.056**	**.0543**	**.0549**
Avg	**.1040**	**.0825**	**.0754**	**.0798**	**.0842**	**.0842**	**.0720**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
AUNDH[571] **BU 6912**
Substation No/ Name :- 254063 / 33/11 KV Gopuj SubStation
Feeder No / Name : 202 / 11 KV Yeliv AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0732	.0716	.0732	.0914	.0953
2	.0762	.0762	.6401	.6325	.6802	.0739	.0762
3	.0572	.0572		.5937	.7116	.0732	.0762
4	.0572	.0566	.578	.5792	.7287	.0747	.0762
5	.0762	.0754	.5639	.8124	.852	.0934	.0953
6	.0953	.0762	.5937	1.1385	1.0486	.1109	.1143
7	.1143	.1143	.6203	1.2955	1.1336	.1097	.1307
8	.0953	.0943	.7145	1.3916	1.2651	.1097	.1109
9	.1307	.1132	.7049	1.3599		.0924	.1109
10	.8482	1.0715	.0914	.0905		1.2483	1.186
11	1.078	1.2289	.0914	.0943		1.6518	1.5844
12	.2187	1.438	.0914		.0914	1.8515	1.5623
13	.3005	1.5718	.0732		.0914	1.9433	1.6604
14	.3125	1.419	.0914		.0924	1.9109	1.8185
15	1.1544	1.4003	.0914		.0934	1.9433	1.7711
16		1.5085	.1097		.0934	1.9271	1.7185
17		1.3466	.0914		.1109	1.6385	1.6309
18	.0572	.0732	.1097		.1294	.1267	.0953
19	.0572	.0732	.1463		.1307	.128	.1132
20	.0953	.0914	.1097		.1307	.1294	.1132
21	.0953	.0914	.128		.112	.1109	.0943
22	.0754	.0732	.128		.112	.112	.0943
23	.0762	.0732	.0914	.0905	.0934	.112	.0953
24	1.1336	.0754	.0739	.0895	.0724	.0934	.0953
Max	**1.1544**	**1.5718**	**.7145**	**1.3916**	**1.2651**	**1.9433**	**1.8185**
Min	**.0572**	**.0566**	**.0732**	**.0716**	**.0724**	**.0732**	**.0762**
Avg	**.2855**	**.5115**	**.2612**	**.6338**	**.3736**	**.6565**	**.6050**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
AUNDH[571] **BU 6912**
Substation No/ Name :- 254063 / 33/11 KV Gopuj SubStation
Feeder No / Name : 204 / Trimali Gaothan **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1886	.1509	.1698	.1524	.1509	.1494
2	.1524	.1715	.1509	.1494	.1524	.1509	.1524
3	.1524	.1524	.1509	.1509	.1524	.1509	.1524
4	.1524	.1509	.1509	.1509	.1524	.1509	.1524
5	.2096	.2075	.1886	.2263	.2096	.2075	.0191
6	.3239	.3239	.2801	.3142	.3048	.2801	.3174
7	.4001	.3961	.3881	.3772	.362	.3696	.3841
8	.3361	.381	.3547	.3921	.3292	.3292	.3258
9	.3511	.3048	.3361	.3361	.362	.3658	.3292
10	.3174	.2829	.2772	.2772	.2896	.2427	.3077
11	.3174	.3174	.3142	.2715	.3109	.2772	.3077
12	.2054	.2801	.2772	.2926	.2743	.2743	.2378
13	.2241	.1886	.1848	.2402	.2033	.2534	.2012
14	.168	.2263	.1663	.1663	.1867	.2172	.2195
15	.2075	.2829	.2033	.2012	.2195	.2378	.2195
16	.2075	.2801	.2033	.2743	.2218	.2378	.2263
17	.2263	.2801	.2033	.2534	.2241	.2715	.2195
18	.3206	.3174	.2957	.2561	.2614	.2926	.2743
19	.4527	.4904	.4805	.3841	.4251	.4525	.439
20	.4527	.4715	.4435	.439	.4294	.439	.439
21	.3961	.3561	.3696	.3696	.3772	.3475	.3658
22	.3018	.3018	.2957	.2987	.2987	.2957	.3292
23	.2452	.2075	.2218	.2054	.2263	.2054	.2561
24	.5668	.2263	.1886	.1848	.1698	.1886	.168
Max	**.5668**	**.4904**	**.4805**	**.439**	**.4294**	**.4525**	**.439**
Min	**.1524**	**.1509**	**.1509**	**.1494**	**.1524**	**.1509**	**.0191**
Avg	**.2858**	**.2828**	**.2615**	**.2659**	**.2623**	**.2662**	**.2580**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
AUNDH[571] **BU 6912**
Substation No/ Name :- 254063 / 33/11 KV Gopuj SubStation
Feeder No / Name : 205 / 11 KV Karkhana AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0754	.0732	.0754	.0934	.0747	.0754
2	.0754	.0754	.5761	.6325	.8223	.0747	.0754
3	.0754	.0754	.5281	.5535	.8802	.0747	.0754
4	.0754	.0747	.5407	.5535	.8907	.0747	.0754
5	.0943	.0934	.5312	.8124	1.0526	.0934	.1132
6	.1509	.1478	.6539	1.2186	1.3123	.1494	.1848
7	.2075	.2012	.8688	1.3599	1.5339	.1829	.2195
8	.1478	.1646	.9002	1.4685	1.6604	.2172	.1829
9	.0914	.0914	.8688	1.2498	1.5061	.1433	.1463
10	1.1069	1.2289	.1075	.181	.1063	1.1203	1.4864
11	1.5935	1.4098	.1433	.1097	.1097	1.6194	1.3441
12	1.3599	1.3817	.0716	.0732	.0914	1.3765	1.5023
13	1.5154	1.6432	.1075	.0905	.0914	2.0005	1.5655
14	1.8185	1.3611	.1109	.1086	.0924	2.0805	1.8278
15	1.781	1.3535	.0924	.0914	.0934	2.0557	1.7966
16	1.5813	1.4335	.0739	.1097	.0934	1.9845	1.7869
17		1.4098	.0747	.1075	.128	1.9109	1.7869
18			.1509	.1267	.1848	.12	.1698
19	.1698	.1463	.1698	.181	.1867	.1578	.1509
20	.1698	.1463	.1698	.1829	.168	.1595	.132
21	.1509	.1294	.1509	.1463	.168	.1433	.1132
22	.1132	.112	.1132	.1478	.112	.1097	.0934
23	.0943	.0934	.0943	.1294	.0934	.0934	.0934
24	1.1336	.0754	.0739	.0754	.0934	.0934	.0934
Max	**1.8185**	**1.6432**	**.9002**	**1.4685**	**1.6604**	**2.0805**	**1.8278**
Min	**.0747**	**.0747**	**.0716**	**.0732**	**.0914**	**.0747**	**.0754**
Avg	**.6173**	**.5619**	**.3019**	**.4077**	**.4818**	**.6713**	**.6288**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
AUNDH[571] **BU 6912**
Substation No/ Name :- 254063 / 33/11 KV Gopuj SubStation
Feeder No / Name : 206 / 11 KV Kharsinge AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0377	.0554	.0554	.0377	.056	.0373
2	.1296	.1265	.0549	.0554	.0377	.1943	.2429
3	.1619	.125	.0549	.0549	.0377	.1943	.2429
4	.16	.1581	.0554	.0549	.0377	.1966	.2294
5	.208	.2056	.0554	.0739	.0377	.213	.2949
6	.4428	.4268	.0747	.0747	.056	.2241	.5281
7	.5535	.5498	.1307	.0943	.0747	.3048	.68
8	.5441	.5468	.0924	.112	.0739	.3864	.7432
9	.4858	.2134	.0934	.0373	.0732	.4801	.6483
10	.0532	.0549	.4801	.6009	.5218	.0549	.0543
11	.0532	.0554	.6642	.6325	.7362	.0543	.0543
12	.0354	.0549	.7274	.6802	.7701	.0549	.0543
13	.0351	.0554	.759	.6964	.8322	.0549	.0543
14	.0347	.056	.6859	.7042	.8962	.0549	.0724
15	.0347	.056	.6173	.664	.8539	.0549	.0724
16	.052	.056	.4374	.6062	.7876	.0724	.0732
17	.0532	.0747	.4268	.664	.6805	.0543	.0732
18	.0566	.0747	.0554	.0532	.0732	.0732	.0934
19	.1132	.1307	.0739	.0724	.112	.0914	.112
20	.1132	.112	.0739	.0914	.112	.0914	.0934
21	.0943	.1132	.0739	.0732	.0934	.0739	.0934
22	.0754	.0747	.0554	.0554	.0747	.056	
23	.0747	.0566	.0554	.056	.056	.0373	
24	.4858	.056	.056	.0554	.0373	.056	.0373
Max	**.5535**	**.5498**	**.759**	**.7042**	**.8962**	**.4801**	**.7432**
Min	**.0347**	**.0377**	**.0549**	**.0373**	**.0373**	**.0373**	**.0373**
Avg	**.1703**	**.1446**	**.2462**	**.2633**	**.2960**	**.1327**	**.2084**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
AUNDH[571] **BU 6912**
Substation No/ Name :- 257020 / 132/33 KV EHV Aundh
Feeder No / Name : 400 / Auxilliary Supply
Feeder KV- 33 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
24	1.7004
Max	1.7004
Min	1.7004
Avg	1.7004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
AUNDH[571] **BU 6912**
Substation No/ Name :- 257020 / 132/33 KV EHV Aundh
Feeder No / Name : 407 / 33 KV Haranai Express FDR NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-NOV-17
HR	Load (MW)
24	1.7004
Max	1.7004
Min	1.7004
Avg	1.7004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
AUNDH[571] **BU 6912**
Substation No/ Name :- 257020 / 132/33 KV EHV Aundh
Feeder No / Name : 702 / 132 KV GPSL Gopuj CO Gen NON SHEDDABLE EHV INDUSTRIAL FEEDERS
Feeder KV- 132 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING

DATE	01-NOV-17
HR	Load (MW)
24	6.8016
Max	6.8016
Min	6.8016
Avg	6.8016

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] **BU 5991**
Substation No/ Name :- 254029 / 33/11 KV SHENAWADI
Feeder No / Name : 201 / 11 KV VAR-MALAWADI AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724	.0554	.0543	.0549	.0554	.0543	.0732
2	.3018	.2126	.0549	.0549	.0554	.2572	.4694
3	.3353	.3155	.0543	.0549	.0554	.3429	.503
4	.3647	.3772	.0549	.0724	.0554	.5087	.57
5	.4024	.4917	.0732	.0724	.0554	.5658	.5967
6	.431	.5533	.1086	.1086	.1109	.6203	.7625
7	.7042	.6706	.0905	.1267	.1294	.7712	.9614
8	.7042	.5801	.0724	.0914	.0739	.7712	.8383
9	.6882	.5426	.0543	.0739	.0549	.7712	.7712
10	.1612	.0362	.4359	.4801	.5316	.0543	.0362
11	.0554	.0366	.6706	.7209	.8139	.0362	.0362
12	.0554	.0366	.7956	.7625	.9556	.0366	.0362
13	.0554	.0362	.8619	.8356	.9835	.0362	.0366
14	.0554	.0362	.8848	.9012	.8648	.0362	.0366
15	.037	.0549	.7625	.9175	.8886	.0366	.0362
16	.0554	.0362	.8288	.8619	.9054	.0362	.0362
17	.0924	.0366	.8288	.7701	.8478	.0549	.0362
18	.0924	.0724	.0724	.037	.0362	.0914	.0905
19	.1294	.1097	.1086	.1109	.1086	.1097	.1267
20	.1109	.1097	.1097	.0924	.1086	.1086	.1086
21	.0924	.0724	.0905	.0924	.0905	.1097	.0905
22	.0739	.0732	.0732	.0739	.0549	.0732	.0724
23	.0739	.0549	.0549	.0554	.0543	.0732	.0724
24	.0724	.0739	.0549	.0549	.0554	.0543	.0732
Max	**.7042**	**.6706**	**.8848**	**.9175**	**.9835**	**.7712**	**.9614**
Min	**.037**	**.0362**	**.0543**	**.037**	**.0362**	**.0362**	**.0362**
Avg	**.2174**	**.1948**	**.3021**	**.3115**	**.3311**	**.2338**	**.2696**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] **BU 5991**
Substation No/ Name :- 254029 / 33/11 KV SHENAWADI
Feeder No / Name : 202 / 11 KV SHENAWADI AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.3881	.362	.362	.3511	.362	.3658
2	.3658	.3696	.5658	.503	.5487	.362	.362
3	.3982	.3881	.7202	.7377	.6344	.4024	.4024
4	.4706	.4066	.8573	.8951	.8139	.4344	.4706
5	.5731	.462	.9156	1.0059	1.1568	.4706	.5068
6	.6805	.6767	1.1736	1.4586	1.6095	.6697	.7602
7	.7964	.8779	2.0454	1.9784	2.3472	.7042	.7522
8	.5853	.5487	2.0119	1.6766	2.3868	.5611	.5792
9	.4024	.4887	1.6766	1.3108	2.0576	.5249	.3982
10	1.1961	1.933	.3582	.1294	.3439	1.9784	2.5149
11	1.9393	2.34	.2507	.0924		2.4863	.5935
12	2.3137	2.5484	.2715	.0924	.3258	2.7854	.4801
13	2.2213	2.3807	.2534	.0924	.3658	3.0148	.4973
14	2.3908	2.4143		.0924	.3077	.6706	1.9448
15	2.3472	2.4478	.2353		.3077	.8383	2.8509
16		2.2721	.2507	.4024	.3292	.7377	3.0001
17	1.8233	1.9669	.2743	.4938	.3475	.8619	2.9835
18	.5304	.5249	.5121	.6401	.4755	.543	.4755
19	.7316	.7602	.7316	.823	.7783	.7602	.724
20	.7316	.6516	.6516	.7499	.7316	.7316	.7059
21	.6219	.543	.5792	.6219	.5611	.6219	.5792
22	.499	.4525	.4344	.4572	.4525	.4938	.4887
23	.4435	.3982	.3658	.4024	.3658	.3658	.3982
24	.4024	.3881	.362	.362	.3696	.362	.3658
Max	**2.3908**	**2.5484**	**2.0454**	**1.9784**	**2.3868**	**3.0148**	**3.0001**
Min	**.362**	**.3696**	**.2353**	**.0924**	**.3077**	**.362**	**.362**
Avg	**.9925**	**1.1095**	**.6895**	**.6687**	**.7812**	**.9060**	**.9667**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] BU 5991
Substation No/ Name :- 254029 / 33/11 KV SHENAWADI
Feeder No / Name : 203 / 11 KV VAR-MALAWADI GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0739	.0924	.0554	.0747	.0739	.0747	.0924
2	.0739	.0924	.0554	.0739	.0739	.0747	.0924
3	.0739	.0924	.056	.0739	.0739	.0739	.0914
4	.0914	.0924	.0554	.0739	.0739	.0924	.1097
5	.1097	.1109	.0739	.0732	.0924	.0924	.1448
6	.128	.1294	.1109	.1097	.1109	.1294	.1629
7	.128	.1109	.0924	.1463	.1294	.1109	.1433
8	.0914	.1109	.0554	.0924	.1109	.0914	.1097
9	.0739	.0739	.0549	.0739	.0739	.0732	.1109
10	.0739	.0554	.0543	.0739	.056	.0549	.0732
11	.0554		.0724	.0739	.0554		.0739
12	.0554		.0543	.0739	.0549	.0543	.0554
13	.0554		.0543	.0554		.0549	.0554
14		.0549	.0362	.0554	.0554	.0724	.0554
15		.0732	.0366	.0554	.0549	.0724	.0554
16		.0739	.0366	.0554	.0554	.0905	.0554
17		.0739	.0549	.0554	.0739	.0724	.0554
18	.0739	.1478	.1086	.0924	.0924	.1097	.1109
19	.1109	.1478	.1463	.1478	.1494	.1646	.1463
20	.1478	.1109	.1478	.1478	.1294	.1663	.1478
21	.1294	.0914	.1294	.1294	.1109	.1478	.1097
22	.1109	.0924	.0914	.1109	.0934	.1109	.0924
23	.1109	.0747	.0739	.0924	.0747	.1109	.0914
24	.0739	.0924	.0566	.0739	.0739	.0747	.0934
Max	**.1478**	**.1478**	**.1478**	**.1478**	**.1494**	**.1663**	**.1629**
Min	**.0554**	**.0549**	**.0362**	**.0554**	**.0549**	**.0543**	**.0554**
Avg	**.0921**	**.0950**	**.0735**	**.0869**	**.0845**	**.0943**	**.0970**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] BU 5991
Substation No/ Name :- 254029 / 33/11 KV SHENAWADI
Feeder No / Name : 204 / 11 KV SHENAWADI GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0739	.0739	.0747	.056	.0739	.0747	.0739
2	.0739	.0739	.0747	.056	.0739	.0747	.0739
3	.0914	.0739	.0739	.0739	.0739	.0747	.0732
4	.128	.0739	.0747	.0924	.0739	.0924	.0914
5	.1646	.1109	.1478	.1109	.1097	.1109	.1086
6	.181	.1848	.2012	.1829	.1646	.1663	.181
7	.2378	.2378	.1646	.2378	.2195	.2012	.2172
8	.1646	.1463	.1478	.2195	.2012	.1663	.1829
9	.1463	.1478	.1097	.1646	.1646	.1463	.1478
10	.128	.1478	.0905	.1463	.1646	.1448	.1663
11	.1097	.1463	.0732	.1097		.1463	.1294
12	.1097	.1646	.1097	.1097	.1109	.1267	.1109
13	.1097	.1646	.1086	.0924	.1109	.1267	.0924
14	.0914	.1463		.0914	.0924	.1267	.0924
15	.0914	.128	.0905		.1294	.0732	.0924
16		.1463	.1086	.0739	.1109	.1267	.1294
17	.0914	.1663	.1097	.1097	.1294	.1463	.1109
18	.128	.1848	.2012	.1463	.1109	.128	.1663
19	.2218	.2012	.2195	.1829	.2012	.2012	.1829
20	.1848	.1829	.1663	.1829	.1829	.1848	.1663
21	.1663	.1646	.1463	.1463	.128	.1478	.1478
22	.1294	.1294	.0924	.1109	.1109	.1109	.1109
23	.1109	.112	.0739	.0924	.0934	.0924	.0934
24	.0739	.0924	.0934	.0747	.0739	.0747	.0747
Max	**.2378**	**.2378**	**.2195**	**.2378**	**.2195**	**.2012**	**.2172**
Min	**.0739**	**.0739**	**.0732**	**.056**	**.0739**	**.0732**	**.0732**
Avg	**.1308**	**.1417**	**.1197**	**.1245**	**.1263**	**.1277**	**.1257**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] **BU 5991**
Substation No/ Name :- 254029 / 33/11 KV SHENAWADI
Feeder No / Name : 205 / 11 KV Jambhulni Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4706	.4435	.4572	.4755	.1663	.4525	.3982
2	.4694	.4908	.4344	.4755	.1478	.6859	.7042
3	.4694	.5201	.4525	.4706	.1478	.8573	.9054
4	.4973	.6001	.4435	.4755	.1663	.8987	1.0608
5	.6706	.8059	.4706	.5068	.1848	1.0513	1.326
6	.9282	.7545	.5121	.5068	.2926	1.2407	1.8023
7	1.4586	1.4922	.5068	.5068	.2926	1.989	2.13
8	1.4918	1.5775	.4706	.4755	.2378	2.146	2.0885
9	1.3226	1.358	.4344	.439	.2195	1.989	1.7436
10	.4572	.4525	.9054		1.5939	.4344	.2172
11	.462		1.5581		2.2721		.2172
12	.4572		1.8023		2.2131	.4344	.2743
13	.462		1.9662	1.5074	2.3807	.4755	.2534
14		.4344	1.9559	2.1628	1.861	.4344	.2534
15		.4344	1.6598	2.556	2.5194	.3258	.2534
16		.4344	1.7238	2.3102	2.2801	.362	.3292
17			1.6766	2.3594	2.2043	.3982	.3982
18	.4435		.362	.2378	.439	.362	.543
19	.5175	.4344	.4755	.3475	.5068	.4525	.5973
20	.499	.4525	.4706	.3109	.4887	.4344	.7762
21	.4805	.4525	.4706	.2743	.4706	.4024	.724
22	.4805	.4572	.4755	.2195	.4706	.3658	.6878
23	.462	.4525	.4755	.2033	.4525	.3292	.6767
24	.4755	.462	.4525	.4755	.1848	.4525	.3292
Max	**1.4918**	**1.5775**	**1.9662**	**2.556**	**2.5194**	**2.146**	**2.13**
Min	**.4435**	**.4344**	**.362**	**.2033**	**.1478**	**.3258**	**.2172**
Avg	**.6488**	**.6584**	**.8589**	**.8236**	**.9247**	**.7380**	**.7787**

 Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] **BU 5991**
Substation No/ Name :- 254030 / 33/11 KV MHASWAD
Feeder No / Name : 201 / 11 KV DEVAPUR AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3292	.2915	.3012	.2743	.3109	.2915
2	.3086	.3292	1.1145	.5853	1.6289	.3109	.2743
3	.3086	.3475	1.166	1.7741	1.6804	.3475	.3086
4	.3086	.3841	1.2003	2.1216	1.6804	.3475	.3772
5	.4115	.4755	1.3717	2.4874	1.8861	.439	.4458
6	.5144	.6401	1.3717	2.8532	2.6406	.5487	.5144
7	.6001	.7133	1.9204	3.4385	3.5665	.6767	.5658
8	.4287	.5304	.2641	3.8043	3.6694	.5121	.463
9	.2915	.4115	1.8861	2.9492	3.0864	.4115	
10	2.6063	1.7833	.2743	.2572	.2743	2.0576	
11	3.1036	2.8635	.1646	.1886	.2401	3.4294	4.0809
12	3.5322	3.4808	.2012	.2229	.2401	3.4294	
13	3.4637	3.7209	.2195	.1715	.2401	4.3038	3.6866
14	3.2922	3.618	.2378	.2058	.2058	4.201	4.0981
15	3.3608	3.4294	.2195	.2058	.2401	4.4582	4.201
16	3.155	3.2922	.2378	.2229	.2743	4.4239	3.9952
17		2.8464	.2835	.2743	.2012	3.8237	4.0466
18		.2915	.3801	.3429	.3841		.3429
19	.5121	.5487	.5552	.583	.5487	.4801	
20	.4755	.5144	.5194	.4801	.4572	.4458	.4287
21	.4207	.4287	.4477	.4287	.4024	.3772	.3772
22	.3841	.3429	.4119	.3429	.3475	.3258	.3772
23	.3658	.3086	.3189	.3258	.3109		.3429
24	.2915	.3475	.2915	.3189	.2743	.3109	.3086
Max	**3.5322**	**3.7209**	**1.9204**	**3.8043**	**3.6694**	**4.4582**	**4.201**
Min	**.2915**	**.2915**	**.1646**	**.1715**	**.2012**	**.3109**	**.2743**
Avg	**1.2929**	**1.3324**	**.6396**	**1.0369**	**1.0314**	**1.6351**	**1.4763**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] **BU 5991**
Substation No/ Name :- 254030 / 33/11 KV MHASWAD
Feeder No / Name : 202 / 11 KV DHULDEV AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.3658	.463	.2328	.3772	.3109	.3086
2	.5144	.5434	.463	.2303	.3429	1.2309	1.3032
3	.5487	.5721	.463	.2303	.3429	1.1789	1.5432
4	.5487	.5721	.463	.2658	.3429	1.2656	1.8347
5	.5487	.6068	.463	.3012	.3772	1.5261	2.0576
6	.6001	.6588	.463	.3366	.4115	1.869	2.2634
7	.6859	.7373	.5658	.3544	.4115	2.1948	2.3834
8	.6001	.7888	.583	.3761	.3429	2.1434	2.4691
9	.5487	.7202	.6767	.2743	.2915	2.1948	2.3148
10	.2058	.2401	1.2346	2.1605	2.4006	.1715	.1646
11	.2058	.3429	2.4863	2.692	2.9321	.2401	.2378
12	.3258	.5658	2.5206	2.8635	2.6406	.2572	
13	.3601	.6001	2.7606	2.3148	2.7606	.2058	.2378
14	.3944	.6001	3.1893	2.8292	3.0693	.2058	.3658
15	.3429	.6001	3.035	3.0178	3.155	.2229	.3658
16	.2743	.6173	3.0178	3.155	3.1207	.2229	.3841
17	.3109	.6344	2.9081	3.2236		.3429	.3429
18	.3292	.6344	.2303	.2915	.3292	.3772	.3772
19	.4572	.5487	.3761	.4115	.3658	.4287	
20	.4572	.5144	.3898	.4115	.3658	.4115	.3429
21	.439	.5144	.3761	.3772	.3475	.3429	.3772
22	.4024	.5144	.3544	.3772	.3475	.3258	.3772
23	.3841	.5144	.2481	.3772	.3292		.3429
24	.2743	.3658	.4801	.2481	.3772	.3292	.3086
Max	**.6859**	**.7888**	**3.1893**	**3.2236**	**3.155**	**2.1948**	**2.4691**
Min	**.2058**	**.2401**	**.2303**	**.2303**	**.2915**	**.1715**	**.1646**
Avg	**.4166**	**.5572**	**1.1754**	**1.1397**	**1.1209**	**.7826**	**.9410**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] BU 5991
Substation No/ Name :- 254030 / 33/11 KV MHASWAD
Feeder No / Name : 203 / 11 kv Devapur Gaothan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0732	.0857	.0905	.0857	.0914	.0686
2	.0857	.0732	.0857	.0716	.0857	.0914	.0686
3	.0857	.0914	.0857	.0716	.0857	.0914	.0686
4	.0857	.1097	.1029	.0914	.0857	.1097	.0686
5	.0857	.128	.1029	.0914	.1029	.1097	.12
6	.12	.1646	.1029	.1086	.12	.1646	.1372
7	.1372	.1646	.12	.1448	.1715	.2012	.1715
8	.1029	.128		.1086	.1372	.1829	.1372
9	.1029	.0686	.1097	.0686	.1372	.12	.0914
10	.0857	.0514	.0914	.0343	.1372	.1029	.128
11	.1029	.0343	.0914	.0857	.1029	.1029	.1097
12	.0514	.0686	.0914	.0857	.1029	.0857	
13	.0343	.0686	.0914	.0686	.1029	.0857	.0914
14	.0343	.0686	.0914	.0686	.1029	.0857	.0914
15	.0514	.0857	.0373	.0857	.1029	.0857	.0914
16	.0343	.0857	.0373	.1029	.1029	.0686	.1097
17	.0373	.1029	.0905	.12	.0732	.0343	.0857
18	.0732	.12	.1267	.12	.128	.1029	.1029
19	.1829	.1372	.1267	.1372	.1829	.1543	
20	.1646	.1372	.1448	.1715	.1646	.1372	.1372
21	.1463	.1543	.1448	.1543	.128	.12	.1029
22	.128	.1372	.1267	.12	.1097	.1029	.1029
23	.1097	.12	.1086		.0914		.1029
24	.0686	.0914	.0857	.1086	.0857	.0914	.0857
Max	**.1829**	**.1646**	**.1448**	**.1715**	**.1829**	**.2012**	**.1715**
Min	**.0343**	**.0343**	**.0373**	**.0343**	**.0732**	**.0343**	**.0686**
Avg	**.0915**	**.1027**	**.0992**	**.1004**	**.1137**	**.1097**	**.1033**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] **BU 5991**
Substation No/ Name :- 254030 / 33/11 KV MHASWAD
Feeder No / Name : 204 / 11 kv Dhuldeo Gaothan **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1646	.1715	.1629	.1372	.1463	.1372
2	.1372	.1646	.1715	.1448	.1372	.1463	.1372
3	.1372	.1463	.1715	.1267	.1372	.128	.1372
4	.1372	.1463	.1715	.181	.1372	.128	.1372
5	.1886	.2195	.2229	.2172	.1543	.1646	.1715
6	.2058	.2743	.2572	.2534	.1715	.2195	.2229
7	.2572	.1829	.1886	.2172	.2572	.2561	.2572
8	.2229	.3475	.1543	.2172	.2401	.2195	.2743
9	.1372	.1029	.1646	.1543	.2401	.1543	.2012
10	.12	.0857	.1646	.1543	.2058	.1029	.1372
11	.12	.12	.1463	.12	.1543	.1543	.1463
12	.12	.1715	.128	.12	.12	.1372	
13	.12	.1543	.128	.1029	.12	.1372	.0732
14	.0762	.0857	.1463	.12	.1029	.1372	.1097
15	.0686	.12	.1097	.0857	.1029	.1372	.128
16	.0857	.12	.1097	.1029	.1372	.1372	.0914
17	.1097	.12	.0905	.1372		.1372	.1029
18	.1463	.1886	.1267	.1372	.1829	.1715	.1029
19	.2561	.2229	.2172	.3086	.2195	.2229	
20	.2743	.2229	.1991	.2229	.2195	.1886	.2401
21	.2743	.2229	.181	.2229	.2195	.2229	.2058
22	.2378		.2172	.2058	.2012	.2229	.1372
23	.2012	.1372	.181	.1715	.1829		.1372
24	.1715	.1829	.1372	.1629	.1372	.1646	.1715
Max	**.2743**	**.3475**	**.2572**	**.3086**	**.2572**	**.2561**	**.2743**
Min	**.0686**	**.0857**	**.0905**	**.0857**	**.1029**	**.1029**	**.0732**
Avg	**.1650**	**.1697**	**.1648**	**.1687**	**.1703**	**.1668**	**.1572**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] BU 5991
Substation No/ Name :- 254030 / 33/11 KV MHASWAD
Feeder No / Name : 205 / 11 KV Mhaswad (U) Gavthan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.6154	.5658	.5359	.5487	.5611	.5487
2	.5487	.6401	.5658	.5121	.5487	.5611	.5316
3	.5487	.6335	.583	.5175	.5658	.5611	.5316
4	.6001	.7059	.583	.6401	.6001	.7059	.6859
5	.7202	.8688	.7202	.7682	.6859	.7964	.8573
6	.8573	.9774	.9259	.9145	.7888	.9593	.9602
7	1.0631	1.1403	.9945	1.1157	1.046	1.1584	1.1831
8	.9088	.9955	.9431	1.0791	1.0631	1.0679	1.0288
9	.7373	.7545	.8145	.823	.8916	.7888	.8688
10	.6687	.583	.7964	.7373	.823	.583	.7602
11	.6173	.6859	.6697	.6859	.7716	.7716	
12	.7202	.7373	.7421	.5658	.7545	.6859	
13	.6001	.6344		.7888	.703	.7373	.7421
14	.6516	.6344	.5249	.6859	.7373	.6859	.7682
15	.6687	.7888	.4706	.7716	.703	.6859	.7783
16	.6859	.7888	.5611	.6687	.7373	.6859	.905
17	.7059	.8402		.7373	.905	.7202	.823
18	.7964	.8916	.6584	.8916	.9955	.9088	.9431
19		1.1488	1.2197	1.0974	1.2127	.1372	
20	1.2489	1.2003	1.0791	1.0117	1.1403	1.0288	1.0288
21	1.0136	.9602	1.0059	.8573	.9774	.9088	.8916
22	.9511	.8573	.823	.7716	.8326	.7373	.8059
23	.8507	.6859	.6036	.6859	.6697		.7202
24	.5658	.8145	.5658	.5729	.5658	.6154	.6173
Max	**1.2489**	**1.2003**	**1.2197**	**1.1157**	**1.2127**	**1.1584**	**1.1831**
Min	**.5487**	**.583**	**.4706**	**.5121**	**.5487**	**.1372**	**.5316**
Avg	**.7512**	**.8160**	**.7462**	**.7682**	**.8028**	**.7414**	**.8086**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] **BU 5991**
Substation No/ Name :- 254041 / 33/11 KV VADJAL
Feeder No / Name : 201 / 11 KV KUKUDWAD AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	06-NOV-17
HR	Load (MW)
9	.8322
10	.0537
11	.0543
24	.0543
Max	.8322
Min	.0537
Avg	.2486

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] **BU 5991**
Substation No/ Name :- 254041 / 33/11 KV VADJAL
Feeder No / Name : 202 / 11 kv Kukudwad gaothan **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	06-NOV-17
HR	Load (MW)	Load (MW)
9		.2195
10		.1448
11		.1097
24	.1311	.1448
Max	.1311	.2195
Min	.1311	.1097
Avg	.1311	.1547

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] **BU 5991**
Substation No/ Name :- 254041 / 33/11 KV VADJAL
Feeder No / Name : 203 / 11 kv Diwad gaothan **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	06-NOV-17
HR	Load (MW)	Load (MW)
9		.1829
10		.1109
11		.128
24	.1311	.1109
Max	.1311	.1829
Min	.1311	.1109
Avg	.1311	.1332

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] **BU 5991**
Substation No/ Name :- 254041 / 33/11 KV VADJAL
Feeder No / Name : 204 / 11 KV DIWAD AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	04-NOV-17	06-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)
2		.3121	
4		.3041	
6		.6299	
8		1.1934	
9			.2587
10			1.2407
11			1.5912
24	.2458	.2229	.1433
Max	**.2458**	**1.1934**	**1.5912**
Min	**.2458**	**.2229**	**.1433**
Avg	**.2458**	**.5325**	**.8085**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] **BU 5991**
Substation No/ Name :- 254041 / 33/11 KV VADJAL
Feeder No / Name : 205 / 11 kv Naravane Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	06-NOV-17
HR	Load (MW)	Load (MW)
9		.3795
10		.0693
11		.125
24	.2286	.0686
Max	.2286	.3795
Min	.2286	.0686
Avg	.2286	.1606

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] **BU 5991**
Substation No/ Name :- 254041 / 33/11 KV VADJAL
Feeder No / Name : 206 / 11 KV NARAWANE GAVTHAN **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	06-NOV-17
HR	Load (MW)	Load (MW)
9		.0995
10		.0857
11		.1147
24	.2572	.0111
Max	.2572	.1147
Min	.2572	.0111
Avg	.2572	.0778

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] **BU 5991**
Substation No/ Name :- 254042 / 33/22 KV SHINGANAPUR
Feeder No / Name : 301 / 22 KV SHINGANAPUR AG (SHINGNA Feeder KV- 22 / OUTGOING **SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1524	.1524	.1509	.1341	.1509	.2286
2	.852	.6584	.1509	.1509	.1341	.5243	1.0814
3	.9175	.8383	.1478	.1509	.1677	.5243	1.1469
4	.9602	1.1401	.3018	.2263	.2035	.5967	1.2452
5	1.073	1.5581	.4481	.3018	.2652	.6962	1.6057
6	1.3904	1.7772	.6097	.4572	.3887	.9175	2.2996
7	2.6155	2.7808	.7762		.4428	1.1469	2.7206
8	2.8502	2.9843	.5281	.4572	.2915	1.326	3.0121
9	2.3137	2.5194	.3856	.3395	.16	1.1271	2.4291
10	.2263	.1478	2.7526	2.3868	2.0972	.1524	.3018
11	.1494	.1509	2.6216	2.7846	3.0803	.1524	.4024
12	.1402	.1478	2.6871	3.0849	3.2819	.1524	.5243
13	.1524	.1494	2.6216	3.083	3.315	.0754	.4012
14	.1524	.1509	2.5263	3.1824	3.2487	.0754	.3704
15	.1478	.1509	2.5911	1.7695	3.2819	.0762	.3704
16	.1524	.1494	2.8509	3.1161	2.9165	.0762	.3704
17	.1524	.1509	2.5232	2.9172	.8288	.1886	.3704
18	.2241	.1478	.2949	.3052	.1509	.2641	.463
19	.5281	.5914	.439	.3567	.3018	.4904	.439
20	.4904	.5281	.4656	.2896	.3018	.3772	1.0242
21	.4572	.4527	.439	.2778	.2667	.3048	.4481
22	.2667	.4108	.2263	.2846	.1886	.2286	.3734
23	.1905	.4527	.1509	.1638	.1509	.2286	.3841
24	.1886	.1524	.1524	.1509	.1357	.1509	.2286
Max	**2.8502**	**2.9843**	**2.8509**	**3.1824**	**3.315**	**1.326**	**3.0121**
Min	**.1402**	**.1478**	**.1478**	**.1509**	**.1341**	**.0754**	**.2286**
Avg	**.6992**	**.7643**	**1.1185**	**1.1473**	**1.0723**	**.4168**	**.9267**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] BU 5991
Substation No/ Name :- 254042 / 33/22 KV SHINGANAPUR
Feeder No / Name : 302 / 22 KV MARDI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1509	.1494	.3704	.1494	.1509	.1886
2	.1494	.1494	.2926	.3125	.6104	.1509	.1509
3	.1509	.1509	.3544	.3704	.8048	.1509	.1509
4	.2263	.1509	.4908	.5693	1.0059	.1905	.1905
5	.2987	.1886	.6173	.852	1.1012	.2641	.2641
6	.415	.3429	.7545	1.0852	1.6095	.4527	.4572
7	.4527	.4572	1.0395	2.1879	2.1879	.4954	.4954
8	.2987	.3429	1.1469	2.1879	2.1628	.4527	.3772
9	.2241	.2667	1.0486	1.5546	1.9662	.2241	.2641
10	.7773	1.1203	.1509	.1867	.1524	1.6385	1.704
11	1.4091	.2743	.1463	.1509	.1509	2.3594	.3749
12	.4801	.4572	.1463	.1494	.1387	2.2542	.5624
13	1.5729	.4687	.1433	.1478	.1387	2.7846	2.4905
14	1.8461	.6958	.1372	.1448	.1402	2.652	2.8509
15		2.2672	.1372	.1494	.1402	2.7846	2.9172
16	1.9109	2.2939	.1372	.1478	.1417	2.7526	2.6216
17	1.5623	1.8343	.1372	.1494	.1417	2.3922	1.9662
18	.2263	.2263	.2263	.1478	.2263	.1886	.1509
19	.3429	.3048	.3048	.3048	.3772	.3772	.2263
20	.3048	.2667	.3018	.2667	.3395	.3395	.3772
21	.2667	.1905	.2263	.2286	.2641	.2641	.2667
22	.1905	.1886	.2263	.1524	.1867	.2263	.2667
23	.1524	.1524	.1886	.1509	.1509	.1886	.2263
24	.1494	.1524	.1524	.1494	.1509	.1509	.1886
Max	**1.9109**	**2.2939**	**1.1469**	**2.1879**	**2.1879**	**2.7846**	**2.9172**
Min	**.1494**	**.1494**	**.1372**	**.1448**	**.1387**	**.1509**	**.1509**
Avg	**.5894**	**.5456**	**.3607**	**.5049**	**.6016**	**.9952**	**.8221**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] BU 5991
Substation No/ Name :- 254042 / 33/22 KV SHINGANAPUR
Feeder No / Name : 303 / 11 KV SHINGANAPUR GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.1086	.1086	.1086	.1086	.1097	.1097
2	.1109	.0905	.1086	.1494	.1086	.1097	.1097
3	.128	.1267	.1267	.1494	.1448	.128	.128
4	.128	.1448	.1629	.1867	.181	.1463	.1463
5	.1646	.181	.2172	.2241	.2378	.2012	.1829
6	.2772	.2534	.2534	.3018	.2896	.2926	.2743
7	.3326	.3077	.362		.3109	.3475	.2926
8	.2743	.2715	.2896	.2829	.2561	.2561	.2561
9	.2195	.1991	.2172	.3174	.2172	.2561	.2378
10	.2195	.181	.1991	.2987	.3077	.2896	.2172
11	.2195	.181	.1991	.2241	.2353	.1629	.2303
12	.2172	.181	.181	.2241	.2172	.2534	.2126
13	.1629	.1991	.1991	.1791	.1629	.181	.2294
14	.1629	.181	.2172	.1448	.1991	.1629	.192
15	.2172	.1629	.2534	.1629	.181	.1991	.1581
16	.2172	.1448	.2715	.1267	.1991	.2715	.1581
17	.2353	.1629	.2686	.1829	.1448	.2353	.1463
18	.2172	.2172	.2353	.2353	.2743	.2743	.2035
19	.3439	.3258	.3142	.3439	.2926	.3292	.3475
20	.2715	.2896	.2772	.3258	.2896	.2926	.3142
21	.2353	.2534	.2743	.2534	.2534	.2561	.2427
22	.181	.1629	.2218	.1991	.181	.1646	.1867
23	.1448	.1267	.1867	.1448	.1448	.1463	.1494
24	.128	.1267	.1086	.1867	.1267	.1267	.128
Max	**.3439**	**.3258**	**.362**	**.3439**	**.3109**	**.3475**	**.3475**
Min	**.1097**	**.0905**	**.1086**	**.1086**	**.1086**	**.1097**	**.1097**
Avg	**.2049**	**.1908**	**.2189**	**.2153**	**.2110**	**.2164**	**.2022**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] BU 5991
Substation No/ Name :- 254042 / 33/22 KV SHINGANAPUR
Feeder No / Name : 304 / 22 KV MARDI GAONTHAN GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2667	.2667	.2286	.2286	.2667	.2286
2	.2667	.3048	.2667	.2286	.1905	.2667	.2286
3	.3048	.3429	.3048	.3018	.2286	.3048	.2667
4	.3429	.4191	.381	.381	.3429	.3429	.3429
5	.5335	.4954	.5335	.4572	.4954	.5335	.5335
6	.8764	.8002	.8002	.724	.8002	.8764	.8002
7	.9145	.9907	.8383		.8383	.8764	.8764
8	.6478	.7621	.6478	.8002	.6478	.6859	.724
9	.4572	.6097	.5716	.4904	.4191	.5335	.4572
10	.3048	.381	.3048	.415	.381	.381	.381
11	.2667	.3048	.3048	.1524	.3048	.3048	.3048
12	.2667	.3048	.2667	.3429	.3429	.2667	.1132
13	.2286	.3048	.2286	.3048	.2667	.2667	.2286
14	.2667	.2667	.2286	.3048	.1524	.3048	.2286
15	.3048	.2667	.2286	.3048	.1905	.3429	.2286
16	.2667	.2667	.2286	.3429	.1905	.3048	.2667
17	.2667	.3048	.1143	.3429	.4191	.1905	.381
18	.4954	.4954	.4527	.1143	.4954	.3429	.1143
19	.8002	.7621	.7545	.6478	.7621	.4954	.6478
20	.6859	.6478	.6036	.6097	.6859	.6478	.724
21	.5335	.5335	.4527	.4954	.5335	.4954	.6097
22	.381	.4191	.3772	.381	.381	.3429	.415
23	.3048	.3048	.2641	.2667	.3048	.3048	.3048
24	.2667	.2667	.2667	.2286	.2286	.2667	.2667
Max	**.9145**	**.9907**	**.8383**	**.8002**	**.8383**	**.8764**	**.8764**
Min	**.2286**	**.2667**	**.1143**	**.1143**	**.1524**	**.1905**	**.1132**
Avg	**.4271**	**.4509**	**.4036**	**.3855**	**.4096**	**.4144**	**.4030**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] **BU 5991**
Substation No/ Name :- 254044 / 33/22 KV ANDHALI
Feeder No / Name : 301 / 22 KV PARKANDI AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 22 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2263	.1509	.2286	.2263	.2263	.2263
2	1.0059	.407	.1886	.2263	.2263	.5426	.8718
3	.9831	.4748	.1886	.2263	.2263	.5765	1.0174
4	.9282	.8139	.2263	.3018	.3018	.7377	1.1401
5	1.1869	1.0364	.2987	.381	.3772	.9282	1.6575
6	1.6461	1.7147	.4527	.6478	.679	1.326	2.1765
7	2.3472	2.713	.6722	.6859	.7545	1.3923	2.9165
8	2.332	2.4813	.4527	.4572	.4527		3.0849
9	2.0119	2.0119	.3018	.2286	.3018		2.4813
10	.1509	.1509	2.2939	2.2939	2.7199	.1905	.2263
11	.0747	.0747	2.6871		2.9096	.1524	.0754
12	.0739	.0754	2.8166		3.8226	.112	.0754
13	.0739	.1509	2.8166	3.219	3.8226	.112	.1509
14	.1509	.0754	2.8502	2.8837	3.315	.1524	.1509
15	.0754	.1509	1.4373	3.3333	3.0803	.112	.1509
16	.2263	.0754	2.8182	3.3813	3.0498	.1905	.1509
17	.1509	.1886	2.4249	3.0803	2.9172	.1867	.2263
18	.2263	.1886	.3361	.3018	.2987	.2218	.3018
19	.5281	.4904	.5281	.5281	.4527	.4527	.5281
20	.5281	.4527	.5281	.4527	.4904	.4904	.4527
21	.4527	.4527	.3048	.4527	.3772	.4191	.4527
22	.3772	.2614	.2667	.3772	.2987	.3048	.3772
23	.2263	.2263	.2263	.2263	.2614	.2286	.2263
24	.3018	.2263	.1886	.2263	.2263	.2263	.2263
Max	**2.3472**	**2.713**	**2.8502**	**3.3813**	**3.8226**	**1.3923**	**3.0849**
Min	**.0739**	**.0747**	**.1509**	**.2263**	**.2263**	**.112**	**.0754**
Avg	**.6785**	**.6300**	**1.0607**	**1.0973**	**1.3162**	**.4219**	**.8060**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] BU 5991
Substation No/ Name :- 254044 / 33/22 KV ANDHALI
Feeder No / Name : 302 / 22 KV BHANDAWALI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.2263	.2263	.1848	.2263	.1886	.1402
2	.1867	.2241	.4024	.2103	.2926	.1886	.1417
3	.1829	.2263	.4694	.2481	.2865	.1886	.1402
4	.1829	.2263	.4973	.3582	.4207	.2263	.1311
5	.3018	.2195	.663	.4908	.6859	.2614	.2172
6	.3734	.3734	.9054	.7712	1.0517	.3772	.4108
7	.4108	.4527	1.0608	1.6095	1.989	.3361	.4904
8	.3395	.3772	1.3592	1.5249	2.146		.2587
9	.2241	.2263	1.0852	1.5249	1.8778		1.9448
10	1.2209	1.4918	.181	.0716	.1829	1.7901	1.9448
11	1.6095	1.8351	.1029	.0732	.1886	2.5149	2.1628
12	1.8519	2.0405	.2195	.0747	.1509	2.713	2.6825
13	1.2071	2.1376	.1478	.1402	.1509	2.8166	2.556
14	1.8991	2.0645	.1063	.1463	.1509	1.3108	2.713
15	1.8778	2.1376	.0663	.1433	.1509	2.6155	2.5484
16	1.8107	2.2131	.1433	.2195	.1886	2.5484	2.4143
17	1.2597	1.8564	.1448	.2241	.1886	2.2024	2.3472
18	.3018	.2987	.3429	.3018	.2987	.3048	.3018
19	.4527	.415	.4572	.4527	.4527	.415	.4527
20	.4527	.3772	.4191	.4527	.415	.415	.3772
21	.3772	.3361	.3018	.3772	.3361	.3395	.3018
22	.3018	.2614	.2263	.3018	.2614	.2641	.3018
23	.2263	.2263	.1886	.2263	.2263	.1867	.2263
24	.1867	.2263	.1886	.1867	.2263	.1886	.1867
Max	**1.8991**	**2.2131**	**1.3592**	**1.6095**	**2.146**	**2.8166**	**2.713**
Min	**.1829**	**.2195**	**.0663**	**.0716**	**.1509**	**.1867**	**.1311**
Avg	**.7260**	**.8529**	**.4127**	**.4298**	**.5227**	**1.0178**	**1.0580**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] BU 5991
Substation No/ Name :- 254044 / 33/22 KV ANDHALI
Feeder No / Name : 303 / 22 KV MALAWADI GAVTHAN GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.1132	.0754	.0724	.1132	.0747	.0709
2	.0747	.1132	.0747	.0724	.1132	.0754	.0732
3	.0732	.112	.0747	.0732	.1132	.0754	.0754
4	.0747	.112	.1109	.0716	.112	.0754	.0693
5	.1109	.1052	.112	.1063	.1097	.1109	.1075
6	.1494	.1867	.1494	.1402	.2263	.1494	.2667
7	.2286	.2263	.2263	.1867	.2263	.1109	.2263
8	.2241	.2263	.2263	.1509	.1886		.1509
9	.1109	.1509	.112	.1509	.1132		.112
10	.112	.1109	.1132	.1867	.1109	.1509	.1509
11	.1132	.1109	.0754	.1494	.1109	.1448	.1509
12	.1509	.0747	.1143	.1132	.1494	.1867	.1509
13	.1509	.1494	.1417	.1132	.1494	.1509	.1509
14	.1509	.1109	.0754	.112	.0732	.0709	.1132
15	.1509	.0732	.0762	.1132	.112	.0754	.1132
16	.1132	.0754	.0762		.1494	.0747	.1132
17	.1509	.1109	.1478	.1509	.1494	.1132	.1132
18	.1509	.1494	.4066	.1509	.1886	.2172	.2241
19	.2263	.2263	.2263	.1886	.3018	.2614	.2263
20	.1886	.1886	.1886	.1886	.1886	.1886	.1867
21	.1886	.1886	.1433	.1509	.1886	.1509	.1886
22	.1509	.1109	.1867	.1509	.1494	.1524	.1509
23	.1132	.0732	.112	.1132	.1109	.1132	.1132
24	.0754	.1132	.0747	.0732	.1132	.1109	.0754
Max	**.2286**	**.2263**	**.4066**	**.1886**	**.3018**	**.2614**	**.2667**
Min	**.0732**	**.0732**	**.0747**	**.0716**	**.0732**	**.0709**	**.0693**
Avg	**.1378**	**.1338**	**.1383**	**.1295**	**.1484**	**.1288**	**.1406**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] BU 5991
Substation No/ Name :- 254044 / 33/22 KV ANDHALI
Feeder No / Name : 304 / 22 KV KULAKJAI GAVTHAN GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
23	.5144						
24	.0754	.1109	.0747	.0747	.0739	.0732	.0732
Max	.5144	.1109	.0747	.0747	.0739	.0732	.0732
Min	.0754	.1109	.0747	.0747	.0739	.0732	.0732
Avg	.2949	.1109	.0747	.0747	.0739	.0732	.0732

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] **BU 5991**
Substation No/ Name :- 254044 / 33/22 KV ANDHALI
Feeder No / Name : 306 / 22 KV TONDALE AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 22 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2241	.2263	.2263	.2195	.2614	.2263
2	1.0059	1.0059	.2263	.2263	.2218	1.1736	1.5729
3	1.0486	1.3565	.2614	.2263	.2241	1.4083	1.8442
4	1.6244	1.5729	.3361	.3018	.2987	1.6575	2.9165
5	1.9448	2.3472	.3772	.3395	.3658	1.9989	2.8837
6	2.4646	2.7515	.5658	.6859	.6653	2.2283	2.3807
7	3.2526	2.2939	.724	.8002	.695	.7625	2.6852
8	2.9127	2.7161	.5658	.6478	.5544		2.7846
9	2.2466	2.3922	.3772	.3395	.4755		2.2466
10	.2987	.2263	2.8166	2.6852	3.0247	.3395	.1848
11	.1867		2.7854		2.753	.2263	.2241
12	.2218	.2641	1.2071		2.3868	.2263	.1886
13	.1867	.1886	2.8178	2.9447	2.4577	.2263	.1494
14	.2218	.1886	2.7526	2.5309	2.3644	.2263	.2241
15	.2241	.1886	2.7831	2.652	2.5301	.2263	.3326
16	.2218	.2263	2.9504	2.6543	2.0645	.3018	.2561
17	.2241	.2641	2.6543	2.5286	2.7515	.3395	.2587
18	.3696	.3772	.4527	.2926	.4527	.1109	.0747
19	.5601	.5601	.6097	.1109	.5658	.6478	.4755
20	.5487	.5281	.6097	.5601	.5658	.5716	.5975
21	.4435	.4527	.415	.4481	.4904	.5335	.5121
22	.2987	.2987	.3395	.3734	.3772	.3772	.4066
23	.2587	.2641	.2641	.2587	.2987	.3018	.3361
24	.8192	.2241	.2263	.2641	.2241	.2587	.2641
Max	**3.2526**	**2.7515**	**2.9504**	**2.9447**	**3.0247**	**2.2283**	**2.9165**
Min	**.1867**	**.1886**	**.2263**	**.1109**	**.2195**	**.1109**	**.0747**
Avg	**.9104**	**.9092**	**1.1394**	**1.0044**	**1.1261**	**.6547**	**1.0011**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] **BU 5991**
Substation No/ Name :- 254060 / 33/11 KV PALASHI
Feeder No / Name : 201 / 11 KV PALASHI AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2865		.2896	.2865	.2926	.2715	.3224
2	.4694		.1254	.2865	.2561	.2896	.3224
3	.503		.1433	.3258	.3292	.3077	.362
4	.7042		.2507	.4024	.3658	.3403	.4344
5	1.1142		.5194	.5068	.4706	.4835	.543
6	1.3441		.6805	.5792	.6447	.6733	.6447
7	1.7604		.7712	.7602	.7011	.6836	.7164
8	1.7284		.5959	.6089	.5792	.5548	.6089
9	1.4403		.4784	.4656	.3749	.3944	.4298
10	.208		1.5074	1.7901	1.9372	2.0957	1.8564
11	.1433	.2279	1.9433	2.0309	1.9685	2.713	2.2466
12	.1448	.1402	2.0405	1.9685		2.5194	2.4143
13	.1448	.1417	1.6964	1.3123	.1791	2.4577	2.364
14	.1448	.1227	1.9433	2.1872	.181	2.3644	2.2298
15	.181	.1715	2.0405	1.8747	.1402	2.3805	2.2969
16	.1829	.12	1.9204	1.8435	.1402	2.2405	2.1125
17	.1829	.208	1.9204	1.9685	.2601	2.1445	1.861
18	.3258	.3856	.2804	.3155	.333	.1417	.1227
19	.5068	.5721	.4908	.5731	.5258	.4656	.4961
20	.5068	.4733	.4607	.4344	.4607	.394	.4298
21	.3982	.4298	.3898	.3982	.3898	.3582	.394
22	.362	.3801	.3189	.3258	.3224	.3224	.3403
23		.362	.3189	.2926	.3045	.3224	.3077
24	.2865		.3258	.3224		.3045	.3224
Max	**1.7604**	**.5721**	**2.0405**	**2.1872**	**1.9685**	**2.713**	**2.4143**
Min	**.1433**	**.12**	**.1254**	**.2865**	**.1402**	**.1417**	**.1227**
Avg	**.5682**	**.2873**	**.8938**	**.9108**	**.5071**	**1.0510**	**1.0074**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] BU 5991
Substation No/ Name :- 254060 / 33/11 KV PALASHI
Feeder No / Name : 202 / 11 KV DHAMANI Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2896		.2507	.2149	.2926	.2715	.2865
2	.2926		.6226	.5533	.6371	.5898	.7293
3	.3292		.6554	.6299	.5365	.6554	.7956
4	.4024		.6882	.7956	.8951	.7373	.9831
5	.4706		.8029	.9831	1.2407	.8848	1.4419
6	.5487		1.0277	1.3763	1.4899	1.21	1.6518
7	.6154		1.1271	1.5546	1.8564	1.6933	.426
8	.4298		1.2929	1.8564	1.9757	1.9113	.426
9	.3898		1.21	1.7284	1.8027	1.7772	.5182
10	1.7772		.1886	.2427	.1791	.2321	.0358
11	1.8122	2.1382	.2103	.2149	.2534	.2103	.0173
12	1.8435	2.1795	.1753	.1448	.2507	.1772	.1753
13	1.8435	2.0957	.1753	.1448	.57	.1772	.1949
14	2.1872	1.9281	.1772	.1829	.6371	.2126	.2103
15	2.0934		.1772	.2195	.7956	.2835	.2629
16	1.9685	2.079	.2126	.2561	.9282	.2835	.2454
17	1.906	1.8442	.2126	.2561	1.1603	.3189	.2629
18	.3506	.3506	.2835	.3982	.4115	.4252	.3544
19	.4908	.4252	.3898	.5068	.4458	.394	.4835
20	.4656	.3721	.3544	.439	.5609	.3582	.4656
21	.3982	.3224	.2865	.4024	.333	.3224	.3801
22	.3658	.2865	.2865	.3292	.3224	.2865	.3439
23		.2686	.2507	.2926	.2896	.2865	.3077
24	.2896		.2507	.2149		.181	.2865
Max	**2.1872**	**2.1795**	**1.2929**	**1.8564**	**1.9757**	**1.9113**	**1.6518**
Min	**.2896**	**.2686**	**.1753**	**.1448**	**.1791**	**.1772**	**.0173**
Avg	**.9374**	**1.1908**	**.4712**	**.5807**	**.7767**	**.5783**	**.4702**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] BU 5991
Substation No/ Name :- 254060 / 33/11 KV PALASHI
Feeder No / Name : 203 / 11 KV GONDAWALE GAONTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3109		.2614	.2926	.3109	.2957	.3077
2	.2957		.2614	.2957	.2926	.2801	.2896
3	.3584		.2427	.3361	.2926	.3174	.2561
4	.4108		.3361	.415	.3292	.3361	.3511
5	.5228		.4805	.4904	.4525	.4854	.4435
6	.6838		.6767	.6099	.6268	.6838	.6099
7	.6767		.7421	.7207	.6089	.7577	.7023
8	.5304		.6036	.6584	.543	.5853	.6099
9	.4525		.4835	.543	.4706	.4706	.4755
10	.4119		.3544	.362		.3658	.3547
11	.3077	.2715	.3366	.2534	.3077	.3109	.2629
12	.2534	.2686	.2658	.2743	.3045	.2715	.2804
13	.2378	.2328	.2686	.1829	.2534	.2149	.2481
14	.2378	.1949	.2353	.2012	.2172	.2328	.2481
15	.3292		.2507	.2195	.2328	.2328	.2804
16	.3292	.2454	.2686	.2378	.2686	.2686	.2454
17	.3292	.3189	.2658	.3109	.2658	.3582	.3721
18	.4344	.439	.4119	.4706	.5014	.4656	.5373
19	.6335	.6626	.6447	.6335	.6447	.591	.6805
20	.5792	.6154	.6516	.6154	.5194	.5249	.6516
21	.5068	.5194	.5249	.5611		.4344	.5611
22		.439	.3841	.4572	.3475	.362	.4755
23		.3921	.3292	.3292	.3174	.3258	.3696
24	.3109		.3361	.2926		.3174	.2896
Max	**.6838**	**.6626**	**.7421**	**.7207**	**.6447**	**.7577**	**.7023**
Min	**.2378**	**.1949**	**.2353**	**.1829**	**.2172**	**.2149**	**.2454**
Avg	**.4156**	**.3833**	**.4007**	**.4068**	**.3861**	**.3954**	**.4126**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] **BU 5991**
Substation No/ Name :- 254060 / 33/11 KV PALASHI
Feeder No / Name : 204 / 11 kv Mhaswad Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1086		.0895	.0716	.0732	.1086	.0716
2	.1075		.3441	.4694	.2683	.6226	.0716
3	.1086		.3605	.503	.2683	.0895	.0724
4	.1097		.3605	.4973	.4694	.0895	.0724
5	.1463		.4096	.5304		.1075	.1086
6	.1433		.4588	.5571		.1417	.1075
7	.1433		.5898	.8421		.1949	.1433
8	.1433		.7865			.1753	.1433
9	.1075		.663			.1372	.1075
10	.7377		.0701			1.3426	1.1271
11	1.4251	1.3592	.0701			1.2125	1.7101
12	1.4251	1.326	.0709		.0347	1.4419	1.6095
13	1.4251	1.4083	.0709		.0716	1.6194	1.6766
14	1.2955	1.3748	.0709	.0732	.181	1.5546	1.8778
15	1.166		.0701	.0724	.1402	1.0364	2.0454
16	.6478	1.1934	.0709	.0732	.1417	1.2209	1.6575
17	.7449	1.0111		.0549	.1387	1.2597	1.6575
18	.1052	.104	.0709	.1463	.1772	.1075	.1417
19	.1791	.1402	.1772	.1829	.1949	.1433	.2126
20	.1791	.1734	.1417	.1829	.1791	.1433	.2126
21	.181	.1753	.1417	.1463	.1772	.1433	.1791
22	.1463	.1254	.1417	.1463	.1254	.1075	.1629
23		.1254	.1075	.0732	.1075	.1075	.1448
24	.1086		.1086	.0716		.1075	.0716
Max	**1.4251**	**1.4083**	**.7865**	**.8421**	**.4694**	**1.6194**	**2.0454**
Min	**.1052**	**.104**	**.0701**	**.0549**	**.0347**	**.0895**	**.0716**
Avg	**.4732**	**.7097**	**.2368**	**.2608**	**.1718**	**.5506**	**.6410**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] BU 5991
Substation No/ Name :- 254060 / 33/11 KV PALASHI
Feeder No / Name : 205 / 11 KV Gondawale Ag Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1433		.1612	.1791	.1829	.1612	.1433
2	.6371				.1829	.7625	.7712
3	.663					.7956	.8288
4	.7209					.7865	.9503
5	.9503					.8951	1.0814
6	1.0364					1.1271	1.3927
7	1.3123					1.4419	1.9845
8	1.3765		.2279	.1029	.2926	1.4754	1.8244
9	1.2163		.1949	.2103	.2195	1.4083	1.7284
10	.1052		.7865	1.7238	1.5935	.1402	.1052
11	.0716	.0876	1.4419	1.8747	1.8122	.1063	.1017
12	.1086	.0886	1.0688	1.781		.1063	.12
13	.0724	.0876	1.749	1.656	1.8122	.1063	.0693
14	.1097	.0701	1.749	1.781	1.9372	.0886	.1052
15	.1097	.0876	1.8138	2.0309	1.9227	.1063	.1052
16	.1463	.1227	1.9334	1.8747	2.079	.1063	.1227
17	.1463	.1417	1.8138		1.8778	.1417	.1417
18	.1829	.2303	.2103	.2865	.2229	.2126	.2629
19	.2561	.2865	.2804	.2534	.2254	.2126	.2629
20	.2195	.2481	.2126	.2561	.2279	.2126	.2865
21	.2195	.2328	.2126		.2279	.1772	.2353
22	.1829	.2149	.1772	.2195	.1791	.1772	.1991
23		.197	.1791	.1829	.1612	.1772	.181
24	.1791		.1791	.1791		.1612	.1433
Max	**1.3765**	**.2865**	**1.9334**	**2.0309**	**2.079**	**1.4754**	**1.9845**
Min	**.0716**	**.0701**	**.1612**	**.1029**	**.1612**	**.0886**	**.0693**
Avg	**.4420**	**.1612**	**.7995**	**.9120**	**.8916**	**.4619**	**.5478**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] BU 5991
Substation No/ Name :- 254072 / 33/11 KV PINGALI
Feeder No / Name : 201 / 11 KV PINGALI GAONTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1204	.125	.1254	.1254	
2		.1311	.12	.1254	.1267	
3		.1387	.1052	.1267	.1307	
4		.1595	.1267	.1267	.1294	
5		.1829	.1848	.1663	.1494	
6		.3361	.3361	.3077	.3109	
7		.4481	.4481	.394	.5304	
8			.4435	.3511	.3475	
9		.2481	.3189	.2957	.3475	
10	.1791	.197	.2454	.181	.2103	.1595
11	.1433	.1063	.1417	.1387		.124
12	.1063	.1387	.1174	.124		.1063
13	.104	.12	.1341	.124		.1029
14	.1075	.12	.1134	.1029		.104
15	.1402	.1526	.1134	.1029		.124
16	.1052	.1357	.1174	.1734		.1214
17	.1326	.1357	.1543	.2012		.1715
18	.2294	.2155	.2429	.2401		.2429
19	.3155	.3544	.3681	.3898		.3814
20	.3641	.3366	.3403	.3366		.3429
21	.3121	.3121	.3012	.3224		.2883
22	.1943	.2012	.2328	.2534		.216
23	.1614	.1614	.1791	.181		.1623
24	.1254	.1353	.1391	.1629	.1629	
Max	**.3641**	**.4481**	**.4481**	**.394**	**.5304**	**.3814**
Min	**.104**	**.1063**	**.1052**	**.1029**	**.1254**	**.1029**
Avg	**.1814**	**.1995**	**.2145**	**.2106**	**.2337**	**.1891**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] **BU 5991**
Substation No/ Name :- 254072 / 33/11 KV PINGALI
Feeder No / Name : 202 / 11 KV KIRAKSAL AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1107	.116	.2347	.3277	
2		.1029	.2172	.2881	.421	
3		.0905	.2572	.2778	.4111	
4		.1097	.2984	.3395	.506	
5		.1663	.3161	.4531	.6327	
6		.2829	.4752	.7209	.8592	
7		.3018	.7701	1.2929	.1067	
8		.2241	.8097	1.4089	.0619	
9		.1448	.6958	1.2289		
10	.8002	1.1822	.1097		.1227	1.8073
11	1.4403	.8259	.0914	.0895		1.7976
12	1.5074	1.2651	.0857	.0905		1.9433
13	1.4255	1.6194	.0857	.0716		2.3266
14	1.5402	1.6356	.0838	.0693		2.3266
15	1.4251	1.6842				2.3266
16	1.4575	1.5223				2.2119
17	1.2029	1.3283		.112		
18	.1235	.1296		.125		
19	.1928	.1791	.2058	.197		.2103
20	.2103	.197	.2103	.197		.2454
21	.1907	.1791	.1949	.1991		.2126
22	.1526	.1543	.181	.1629		.1658
23	.1204	.132	.181	.1433		.1341
24	.096	.1082	.1219	.1372	.1433	
Max	**1.5402**	**1.6842**	**.8097**	**1.4089**	**.8592**	**2.3266**
Min	**.096**	**.0905**	**.0838**	**.0693**	**.0619**	**.1341**
Avg	**.7924**	**.5698**	**.2753**	**.3733**	**.3592**	**1.3090**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] **BU 5991**
Substation No/ Name :- 254072 / 33/11 KV PINGALI
Feeder No / Name : 203 / 11 KV PINGALI AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0185	.0189	.0189	.0183	
2		.0343	.0191	.0189	.0189	
3		.0663	.0191	.0187	.0187	
4		.0648	.0191	.0187	.0187	
5		.0926	.0191	.0189	.0189	
6		.1296	.0191	.0377	.0373	
7		.2321	.0191	.0373	.037	
8		.208	.0189	.0377	.0189	
9		.1852	.0189	.0183	.0189	
10	.0187	.0183	.1619		.1718	.0168
11	.0187	.0189		.2429		.0187
12	.0191	.0189	.2343	.2591		.0191
13	.0189	.0189	.2187	.2214		.0191
14	.0189	.0189	.2469	.2721		.0191
15	.0189	.0187	.2343	.2688		.0191
16	.0189	.0189	.2372	.2881		.0191
17	.0183	.0187	.192	.1406		
18	.0187	.0189	.0183	.0189		.0191
19	.0189	.0189	.0366	.0377		.0175
20	.0187	.0189	.0373	.0185		.0189
21	.0189	.0187	.0183	.0187		.0189
22	.0189	.0187	.0183	.0183		.0189
23	.0187	.0187	.0181	.0183		.0189
24	.0187	.0185	.0187	.0181	.0181	
Max	**.0191**	**.2321**	**.2469**	**.2881**	**.1718**	**.0191**
Min	**.0183**	**.0183**	**.0181**	**.0181**	**.0181**	**.0168**
Avg	**.0188**	**.0547**	**.0810**	**.0899**	**.0360**	**.0187**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] **BU 5991**
Substation No/ Name :- 254072 / 33/11 KV PINGALI
Feeder No / Name : 401 / 33 KV MANDESHI SOOT GIRNI SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 33 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7356	.8488	.8871	.9054	
2		.7922	.8488	.8488	.9054	
3		.8488	.9054	.9054	.8488	
4		.8488	.9054	.9054	.9054	
5		.9054	.9054	.7922	.9054	
6		.7922	.9054	.8488	1.0082	
7		.9619	.9054	.8962	.9425	
8		.8488	.8488	.8962	1.0185	
9		.7356	.9054	.7133	.8488	
10	.8402	.7356	.9054	.8871	.9054	.9619
11	.8488	.8488		1.0185		.9619
12	.8488	.8488	.8488	1.0082		.9619
13	.9619	.8488	.8962	.9425		.9054
14	.9054	.8488	.9619	.9054		.9054
15	.8488	.8488	.9619	.9619		.9054
16	.8488	.9054	.9619	1.0082		.9619
17	.9619	.9054	.9425	.8962		.9054
18	.7922	.7356	.9054	.7922		.9054
19	.8488	.7356	.7922	.7922		.8488
20	.8488	.7922	.8962	.7842		.8488
21	.8488	.7356	.8402	.8962		.7356
22	.8488	.7922	.8871	.8488		.7356
23	.7356	.8488	.8871	.8488		.7356
24	.8402	.823	.8488	.9054	.8488	
Max	**.9619**	**.9619**	**.9619**	**1.0185**	**1.0185**	**.9619**
Min	**.7356**	**.7356**	**.7922**	**.7133**	**.8488**	**.7356**
Avg	**.8552**	**.8218**	**.8919**	**.8829**	**.9130**	**.8771**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] **BU 5991**
Substation No/ Name :- 254075 / 33/11 KV RANJANI
Feeder No / Name : 201 / 11 kv Waki Varkute Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0549	.0187	.0914	.0362	.0187	.0366
2	.0566	.056	.1107	.1109	.1147	.0373	.0373
3	.0754	.0566	.1326	.1629	.1372	.0373	.0373
4	.0754	.0566	.12	.1772	.1781	.0566	.0566
5	.0754	.0747	.1372	.2103	.2429	.0566	.0566
6	.112	.0934	.1372	.2279	.2915	.0747	.0754
7	.1132	.112	.208	.5138	.5407	.0754	.0943
8	.0747	.0934	.2949	.6226	.6316	.0758	.0549
9	.0754	.0566	.2949	.4321	.6009	.0566	.0373
10	.3201		.0754	.0754	.0354	.5761	.5571
11	.4858		.0566	.0554	.0554	.9069	.8785
12	.5535	.6642	.0747	.056	.0554	1.0155	.9717
13	.6019	.7042	.0566	.0747	.0554	.9181	.8802
14	.5693	.7116	.0537	.0549		1.0364	.8802
15	.5556	.6874	.0173	.0554	.0709	.953	1.0526
16	.4999	.578	.0358	.0377	.0179	.8383	1.004
17	.463	.503	.0732	.0354	.0566	.8749	.8583
18	.056	.0532	.0549	.0362	.0373	.052	.0377
19	.0739	.0732	.0739	.0686	.0754	.0739	.0554
20	.0934	.0747	.0739	.0554	.0724	.0732	.0701
21	.0905	.0554	.0543	.0693	.056	.056	.0554
22	.0732	.037	.0549	.0351	.0366	.0373	.0366
23	.0549	.0373	.0537	.0358	.037	.037	.037
24	.056	.0554	.0185	.0526	.0366	.0187	.0362
Max	**.6019**	**.7116**	**.2949**	**.6226**	**.6316**	**1.0364**	**1.0526**
Min	**.0549**	**.037**	**.0173**	**.0351**	**.0179**	**.0187**	**.0362**
Avg	**.2192**	**.2222**	**.0951**	**.1395**	**.1510**	**.3315**	**.3291**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] BU 5991
Substation No/ Name :- 254075 / 33/11 KV RANJANI
Feeder No / Name : 202 / 11 KV Waki Varkute Gaothan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0867	.0914	.0876	.0747	.0905	.0914
2	.1109	.0905	.0934	.0886	.0934	.1097	.1109
3	.0934	.0924	.0943	.1075	.0747	.0914	.0914
4	.1132	.112	.1132	.1097	.0934	.1132	.1109
5	.1698	.1509	.1509	.1494	.1307	.132	.1478
6	.2427	.1867	.2452	.168	.2054	.2263	.2263
7	.2427	.2054	.2614	.1867	.2241	.2427	.2427
8	.1848	.168	.1848	.1663	.1646	.1463	.1867
9	.112	.112	.128	.1307	.1227	.0914	.1075
10	.0724		.0905	.1075	.0732	.0905	.0867
11	.0724		.0886	.0701	.0549	.0732	.0526
12	.0549	.0617	.0701	.0709	.052	.0701	.0343
13	.0532	.0655	.0486	.0514		.0509	.048
14	.0532	.0503	.048	.0367	.0347	.0514	.0309
15	.0709	.0625	.0474	.0362	.0354	.0509	.0514
16	.0532	.0503	.0655	.0343	.0686	.0514	
17	.0716		.081	.0648	.0819	.0753	.0686
18	.1097	.1029	.0914	.0972	.0876	.1052	.1254
19	.2033	.1829	.1578	.1991	.2033	.2195	.1991
20	.2241	.1848	.1829	.1829	.168	.1848	.1991
21	.2218	.1629	.1448	.1294	.1463	.1629	.1829
22	.1629	.1254	.1267	.1075	.1097	.1097	.1097
23	.1052	.1097	.1075	.0886	.1052	.1086	.1086
24	.0914	.1029	.0886	.0876	.0709	.0876	.0905
Max	**.2427**	**.2054**	**.2614**	**.1991**	**.2241**	**.2427**	**.2427**
Min	**.0532**	**.0503**	**.0474**	**.0343**	**.0347**	**.0509**	**.0309**
Avg	**.1242**	**.1174**	**.1168**	**.1066**	**.1076**	**.1140**	**.1175**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] **BU 5991**
Substation No/ Name :- 254075 / 33/11 KV RANJANI
Feeder No / Name : 203 / 11 KV Ranjani Ag **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2427	.2715	.2241	.2534	.2829	.2772	.2743
2	.6413	.4144	.2452	.3292	.2641	.4458	.4534
3	.6447	.4534	.2641	.3326	.2641	.8939	.6464
4	.6344	.759	.3395	.499	.3206	.8669	.7969
5	.9816	.9217	.4904	.7095	.4904	1.0402	1.0117
6	1.4255	.9414	.9619	.7545	.8676	1.4198	1.6644
7	.7202	1.3916	.9619	.8215	.9808	2.0111	.5668
8	1.0576	1.8821	.6036	.7023	.6908	1.3003	.5571
9	.7716	1.5023	.3584	.5228	.5544	1.2174	1.153
10	.2241		.9054	1.757	1.0814	.3361	.2772
11	.168		1.3117	1.1069	1.1174	.2772	.1829
12	.1109	.1829	1.8275	1.2793	2.5484	.2241	.1991
13	.1267	.1448	2.0553	2.3975	1.0688	.2033	.1646
14	.1294	.1867	.4268	.9503	1.1174	.1848	.2033
15	.1448	.1612	.1852	1.004	1.6244	.2149	.1629
16	.1829	.1867	.4801	1.0526	1.6575	.1928	.1715
17	.2534	.2328	1.5364	.933	1.4746	.2572	.2427
18	.462	.3841	.3856	.2126	.4024	.4572	.4805
19	.6838		.5792	.7842	.5788	.7095	.7282
20	.6348	.6722	.4938	.6161	.5729	.5853	.5729
21	.4755	.4481	.4251	.4938	.4481	.4435	.462
22	.3841	.4108	.2926	.3547	.3511	.3326	.3086
23	.3258	.3361	.2507	.4854	.2896	.2987	.2987
24	.2427	.2926	.2427	.2507	.2772	.2926	.2772
Max	**1.4255**	**1.8821**	**2.0553**	**2.3975**	**2.5484**	**2.0111**	**1.6644**
Min	**.1109**	**.1448**	**.1852**	**.2126**	**.2641**	**.1848**	**.1629**
Avg	**.4862**	**.5798**	**.6603**	**.7751**	**.8052**	**.6034**	**.4940**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] **BU 5991**
Substation No/ Name :- 257006 / 132/33/22 KV DAHIWADI
Feeder No / Name : 301 / 22 KV DAHIWADI **GAOTHAN FEEDER**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
24	.439
Max	.439
Min	.439
Avg	.439

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] **BU 5991**
Substation No/ Name :- 257006 / 132/33/22 KV DAHIWADI
Feeder No / Name : 302 / 22 KV BIDAL AG (DAHIWADI) SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17
HR	Load (MW)
24	1.8351
Max	1.8351
Min	1.8351
Avg	1.8351

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] **BU 5991**
Substation No/ Name :- 257006 / 132/33/22 KV DAHIWADI
Feeder No / Name : 303 / 22 KV SHINGANAPUR AG (DAHIWADI Feeder KV- 22 / OUTGOING **SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER**

DATE	01-NOV-17
HR	Load (MW)
24	.8478
Max	.8478
Min	.8478
Avg	.8478

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] **BU 5991**
Substation No/ Name :- 257006 / 132/33/22 KV DAHIWADI
Feeder No / Name : 304 / 22 KV MOGARALE AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17
HR	Load (MW)
24	1.6385
Max	1.6385
Min	1.6385
Avg	1.6385

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] **BU 5991**
Substation No/ Name :- 257006 / 132/33/22 KV DAHIWADI
Feeder No / Name : 305 / 22 KV DEVAPUR AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17
HR	Load (MW)
24	.8192
Max	.8192
Min	.8192
Avg	.8192

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] **BU 5991**
Substation No/ Name :- 257006 / 132/33/22 KV DAHIWADI
Feeder No / Name : 306 / 22 KV MHASWAD GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
24	.4915
Max	.4915
Min	.4915
Avg	.4915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
DAHIWADI[116] BU 5991
Substation No/ Name :- 257006 / 132/33/22 KV DAHIWADI
Feeder No / Name : 406 / TATA Power Palsawade
Feeder KV- 33 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
18	.503
Max	.503
Min	.503
Avg	.503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
KHATAV S/DN.[830] **BU 4830**
Substation No/ Name :- 254028 / BUDH
Feeder No / Name : 201 / 11 KV LALGUN AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 11 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0343	.0343	.0366	.0754	.0351	.0377
2	.0373	.0343	.3277	.6167	.6562	.0343	.037
3	.037	.0343	.6062	.6783	.6722	.0351	.0377
4	.0373	.0343	.6371	.6097	.6483	.0358	.0373
5	.0377	.0343	.7042	.9335	.8065	.0343	.0373
6	.0377	.0343	.9088	1.0111	.9878	.0351	.0373
7	.0373	.0343	1.4255	1.5074	1.6221		.0339
8	.0377	.0343	1.7772	1.8299	1.9006	.0343	.0373
9	.0377	.0343	1.6118	1.3108	1.6484	.0351	
10	1.6712	1.7368	.0351	.0754	.0754	1.9826	2.0481
11	1.9719	2.0119	.0347	.0747	.0377	2.1628	2.3703
12	2.0348	2.0062	.0339	.0747	.0366	1.5592	2.5526
13	2.1434	2.0153	.0347	.0747	.0351	2.4813	2.4531
14	2.2805	2.0287	.0373	.0754	.0358	2.4905	2.1714
15	1.8861	1.8515	.0373	.0754	.0366	2.3137	2.364
16	1.989	1.9113	.0366	.0747	.0373	2.3537	2.4697
17	1.9033	1.7695	.0343	.0747	.0366	2.1125	2.2542
18	.0339	.0335	.0373	.0747	.0351	.0377	.0747
19	.0335	.0343	.0373	.0754	.0358	.0366	.0747
20	.0335	.0351	.037	.0754	.0366	.0373	.0747
21	.0339	.0358	.0373	.0754	.0351	.0377	.0747
22	.0343	.0351	.0366	.0754	.0343	.0366	.076
23	.0343	.0358	.0366	.0754	.0351	.037	.0754
24	.0366	.0343	.0351	.0366	.0754	.0358	.0373
Max	**2.2805**	**2.0287**	**1.7772**	**1.8299**	**1.9006**	**2.4905**	**2.5526**
Min	**.0335**	**.0335**	**.0339**	**.0366**	**.0343**	**.0343**	**.0339**
Avg	**.6857**	**.6618**	**.3572**	**.4009**	**.4015**	**.7824**	**.8464**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
KHATAV S/DN.[830] BU 4830
Substation No/ Name :- 254028 / BUDH
Feeder No / Name : 202 / 11 KV MANJARWADI GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.2058	.1646	.1886	.1886	.1791	.2012
2	.2033	.2035	.1753	.1867	.1698	.1715	.1848
3	.1829	.2543	.1715	.1848	.1698	.1715	.1886
4	.1829	.3429	.1753	.1829	.1698	.1791	.2218
5	.3206	.4287	.2507	.3174	.6097	.2926	.2987
6	.5228	.5144	.4938	.5041	.5281	.4733	.5601
7	.6535	.5426	.6161	.6219	.6722		.6401
8	.5228	.4801	.5487	.567	.5914	.5144	.5228
9	.5228	.4115	.5228	.5788	.5175	.4733	
10	.4668	.3511	.4527	.4298	.4607	.3582	.2801
11	.3429	.3361	.4108	.4252	.4207	.3174	.2587
12	.3086	.3109	.3734	.3658	.3224	.2801	.2452
13	.2743	.2054	.2957	.3439	.298	.2427	.2427
14	.2572	.2561	.2987	.3511	.3045	.2427	.2241
15	.3086	.2427	.3109	.2772	.2926	.2801	.2195
16	.3086	.2926	.3361	.3511	.3547	.2987	.2402
17	.3601	.3361	.4207	.3841	.3475	.3584	.2957
18	.3429	.4527	.4715	.4938	.4668	.4294	.3921
19	.4287	.6584	.7282	.7023	.6767	.6535	.6602
20	.5144	.6268	.6283	.6838	.6535	.6224	.6838
21	.5487	.5083	.5316	.5975	.5014	.5415	.5847
22	.3429	.3403	.3547	.4435	.3856	.3584	.4294
23	.2572	.2561	.2561	.2772	.2743	.2801	.2957
24	.2241	.2058	.2241	.2402	.2402	.2279	.2218
Max	**.6535**	**.6584**	**.7282**	**.7023**	**.6767**	**.6535**	**.6838**
Min	**.1829**	**.2035**	**.1646**	**.1829**	**.1698**	**.1715**	**.1848**
Avg	**.3577**	**.3651**	**.3838**	**.4041**	**.4007**	**.3455**	**.3518**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
KHATAV S/DN.[830] BU 4830
Substation No/ Name :- 254028 / BUDH
Feeder No / Name : 204 / 11 kv Mol Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061	.1715	.0351	.0328	.0486	.0366	.0686
2	.12	.2515	.0343	.0305	.0486	.1966	.1311
3	.1311	.4748	.0343	.0328	.0486	.192	.3149
4	.1219	.4239	.0351	.0305	.0486	.1966	.3841
5	.2347	.5144	.0526	.0457	.0503	.3353	.4254
6	.4588	.7716	.0716	.0716	.0732	.5144	.7773
7	1.0486	.788	.0701	.0724	.0747		1.291
8	1.0202	1.0117	.0537	.0486	.0549	.8192	.6718
9	.7701	.7716	.0351	.0655	.0554		
10	.0514	.0469	1.1469	1.278	1.1012	.0526	
11	.0514	.048	1.4089	1.6095	1.7939		
12	.0514	.0983	1.1305	1.5565	1.8347		
13	.0514	.0503	.8059	1.7404	1.9006	.0509	
14	.0514	.0492	1.8442	1.9113	1.6095	.0514	
15	.0343	.0503	1.7736	1.6766	1.8347		.0543
16	.0343	.0514	1.7238	1.576	1.7368	.0655	.0347
17	.0343	.0526	1.4091	1.278	1.3077	.0857	.0549
18	.0343	.0537	.0587	.0602	.0514		.1063
19	.0343	.0701	.0686	.0633	.0526	.0709	.0886
20	.0343	.0895	.0732	.0633	.0716	.0686	.0867
21	.0686	.0701	.0579	.0663	.0526	.0701	.0678
22	.0686	.0716	.0434	.0492	.0514	.0594	.061
23	.0686	.0526	.0429	.0429	.0526	.0446	.0686
24	.0549	.0686	.0537	.0423	.0514	.0537	.0446
Max	**1.0486**	**1.0117**	**1.8442**	**1.9113**	**1.9006**	**.8192**	**1.291**
Min	**.0343**	**.0469**	**.0343**	**.0305**	**.0486**	**.0366**	**.0347**
Avg	**.1954**	**.2543**	**.5026**	**.5602**	**.5836**	**.1647**	**.2629**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
KHATAV S/DN.[830] BU 4830
Substation No/ Name :- 254028 / BUDH
Feeder No / Name : 205 / 11 KV BUDH AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366	.1715	.0358	.0497	.0509	.0358	.0549
2	.1829	.2515	.0351	.0514	.0492	.1966	.2218
3	.2058	.3391	.0343	.0526	.0486	.192	.3277
4	.1886	.4917	.0351	.052	.0497	.192	.3353
5	.2949	.5935	.0537	.0509	.0514	.3277	.4475
6	.4578	.8478	.0701	.0914	.0716	.4527	.7202
7	1.0802	1.0898	.0686	.0934	.0934		1.2597
8	1.1797	1.17	.0526	.0732	.0747	.7865	1.3056
9	1.1105	.9774	.0514	.0543	.0934	1.0562	
10	.0497	.0332	1.065	.9995	1.1203	.0343	.0514
11	.0503	.0335	1.5257	1.278	1.6575	.0503	.0732
12	.0509	.0343	.4694	1.3441	1.4922	.0526	.0732
13	.0514	.0526	1.5089	1.5074	1.6221	.0549	.0762
14	.0514	.0537	1.3435	1.861	1.5927	.0514	.0739
15	.0514	.0549	1.7368	1.8564	1.5402	.0503	.0739
16	.0514	.056	1.6549	1.3923	1.4754	.056	.0747
17	.0857	.0549	1.3748	1.2944	1.3889	.0554	.0549
18	.0671	.0716	.0747	.0554	.0526	.0543	.0754
19	.0678	.0701	.0914	.0724	.0716	.0732	.0934
20	.0678	.0716	.0924	.0537	.0549	.0724	.0914
21	.0678	.0526	.0747	.0543	.0554	.0747	.0914
22	.0686	.0537	.0549	.0532	.0526	.056	.0724
23	.0686	.0549	.0554	.0526	.0343	.056	.0724
24	.0343	.0686	.0526	.0549	.0526	.0351	.056
Max	**1.1797**	**1.17**	**1.7368**	**1.861**	**1.6575**	**1.0562**	**1.3056**
Min	**.0343**	**.0332**	**.0343**	**.0497**	**.0343**	**.0343**	**.0514**
Avg	**.2342**	**.2812**	**.4838**	**.5208**	**.5353**	**.1768**	**.2512**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
KHATAV S/DN.[830] BU 4830
Substation No/ Name :- 254028 / BUDH
Feeder No / Name : 303 / Budh Gaothan GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1372	.0747	.0747	.0739	.0686	.0754
2	.1109	.2058	.0732	.0747	.0732	.0701	.0747
3	.112	.2058	.0716	.0739	.0739	.0716	.0754
4	.112	.2743	.0701	.0747	.0739	.0732	.0739
5	.1509	.3429	.2149	.1867	.1494	.2103	.1829
6	.3734	.3429	.3582	.3734	.2667	.3582	.3772
7	.4481	.3429	.4207	.4115	.4481		.4344
8	.3734	.2743	.3582	.3018	.4108	.2926	.3734
9	.2614	.2058	.2926	.3734	.2987	.2987	
10	.2614	.1494	.2241	.2241	.2218	.2263	.2241
11	.2926	.1509	.2218	.1478	.2241	.2241	.2218
12	.2926	.1463	.1867	.1478	.1463	.2241	.2241
13	.2103	.1494	.1109	.0762	.1494	.1886	.1867
14	.2103	.0754	.1494	.0762	.0732	.1509	.0754
15	.2103	.0747	.1494	.0754	.0747	.112	.0754
16	.2103	.0754	.112	.0754	.1509	.1494	.0754
17	.2103	.1463	.1494	.1478	.1463	.1494	.1494
18	.2743	.2241	.2614	.2195	.2241	.2641	.2241
19	.3429	.3658	.4108	.3696	.3772	.3734	.3772
20	.4115	.3734	.4108	.3395	.3292	.3292	.3395
21	.4115	.3018	.3361	.3048	.2926	.2743	.3429
22	.3429	.2195	.2561	.2667	.2103	.2241	.2284
23	.2058	.1494	.1478	.1509	.1372	.1478	.1905
24	.1097	.1372	.0732	.1097	.0747	.0701	.1109
Max	**.4481**	**.3734**	**.4207**	**.4115**	**.4481**	**.3734**	**.4344**
Min	**.1097**	**.0747**	**.0701**	**.0739**	**.0732**	**.0686**	**.0739**
Avg	**.2521**	**.2113**	**.2139**	**.1948**	**.1959**	**.1979**	**.2049**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
KHATAV S/DN.[830] BU 4830
Substation No/ Name :- 254028 / BUDH
Feeder No / Name : 305 / 22 KV KATEWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0686	.0716	.0747	.0747	.0701	.0754
2	.0739	.0686	.6554	1.1797	1.2407	.0686	.0739
3	.0747	.0686	1.2125	1.1934	1.2407	.0701	.0747
4	.0747	.0686	1.2742	1.2742	1.2407	.0686	.0747
5	.0747	.0686	1.3108	1.3413	1.2452	.0701	.0754
6	.0732	.0686	1.5089	1.5729	1.4083	.0716	.0747
7	.0732	.0686	1.9204	2.0317	1.9227		.0678
8	.0724	.0686	2.0317	2.3137	2.0553	.0732	.0754
9	.0747	.0686	1.3748	1.6956	1.9334	.0747	
10	2.0885	1.989	.0686	.0732	.0739	2.3922	2.5232
11	2.3739	2.4905	.0693	.0724	.0686	2.6543	3.0178
12	2.6825	2.7161	.0335	.0724	.0701	2.9492	3.0514
13	2.6406	2.7526	.0701	.0716	.0686	3.0182	3.152
14	2.4006	2.8502	.0686	.0693	.0701	3.1855	2.8166
15	1.989	2.6216	.0377	.0716	.0716	3.0514	3.0849
16	1.5089	2.6155	.0373	.0709	.0701	3.1855	2.8502
17	1.8861	2.5034	.0366	.0716	.0686	2.8502	2.6852
18	.0686	.0701	.0747	.0747	.0701	.0732	.0716
19	.0678	.0686	.0747	.1494	.0716	.0732	.0724
20	.0671	.0701	.0747	.1509	.0732	.0754	.0724
21	.0678	.0716	.0747	.1509	.0701	.0747	.0732
22	.0686	.0701	.0732	.0747	.0686	.0754	.0724
23	.0686	.0716	.0739	.0747	.0701	.0739	.0693
24	.0732	.0686	.0701	.0747	.0747	.0716	.0739
Max	**2.6825**	**2.8502**	**2.0317**	**2.3137**	**2.0553**	**3.1855**	**3.152**
Min	**.0671**	**.0686**	**.0335**	**.0693**	**.0686**	**.0686**	**.0678**
Avg	**.7799**	**.9020**	**.5124**	**.5833**	**.5592**	**1.0596**	**1.0556**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
KHATAV S/DN.[830] BU 4830
Substation No/ Name :- 254054 / 33/22 KV Shindewadi (Katgun)
Feeder No / Name : 201 / 11 KV Pusegaon gaothan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3547	.3547	.3547	.3361	.3361	.3921	.3734
2	.3547	.3547	.3547	.3361	.3361	.3921	.3921
3	.3547	.3547	.3547	.3361	.3361	.3921	.4108
4	.3547	.3547	.3734	.3361	.3361	.4108	.4294
5	.4108	.3921	.3921	.3734	.3734	.6348	.4854
6	.7655	.7842	.8215	.7095	.6908	.8589	.8402
7	1.1576	1.0829	1.1389	1.0456	1.0082	1.2323	1.2136
8	1.0642	.9709	1.0456	1.0082		.9896	1.0456
9	.9149	.9522	.8775	.8589	.8775	.9335	.8215
10	.7655	.8215	.7842	.7655	.9335	.8402	.7842
11	.7095	.7842	.7468	1.0082	.8775	.7655	.7468
12	.6722	.7468	.6908		.7842	.7468	.8029
13	.6348	.7655	.6348	.7468	.6535	.7282	.6908
14	.6908	.5975	.6161	.6908	.6535	.5788	.6535
15	.6722	.5788	.6161	.6535	.6908	.6535	.6722
16	.6722	.6348	.6722	.7282	.6908	.6722	.7468
17	.7095	.7095	.7468	.6908	.8215	.7468	.7655
18	.8589	.7655	.9335	1.0082	.8775	.9709	.9149
19	1.0642	1.1576	1.0456	1.1203	1.1203	1.0829	1.0642
20	.9709	.9709	.9522	1.0082	1.0082	.9896	.9896
21	.8029	.8775	.8402	.8402	.8589	.8589	.8962
22	.6722	.7095	.6535	.7095	.7468	.6908	.7842
23	.4481	.5788	.5788	.4294	.5975	.5228	.5228
24	.3734		.3921	.3734	.3734	.4108	.4481
Max	**1.1576**	**1.1576**	**1.1389**	**1.1203**	**1.1203**	**1.2323**	**1.2136**
Min	**.3547**	**.3547**	**.3547**	**.3361**	**.3361**	**.3921**	**.3734**
Avg	**.6854**	**.7087**	**.6924**	**.7006**	**.6949**	**.7290**	**.7289**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
KHATAV S/DN.[830] BU 4830
Substation No/ Name :- 254054 / 33/22 KV Shindewadi (Katgun)
Feeder No / Name : 202 / 11 KV PUSEGAON AG SEPARATED AG FEEDERS HAVING SPECIAL Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0156	.0625	.016	.016	.016	.016	.016
2	.5468	.6093	.016	.016	.016	.7042	.8002
3	.5468	.6093	.016	.016	.016	.7042	.8322
4	.5624	.6093	.016	.016	.016	.7202	.8642
5	.578	.6093	.016	.016	.016	.7842	.9282
6	.7968	.8749	.016	.016	.032	1.0722	1.2803
7	1.2186	1.1405	.016	.016	.016	1.3443	1.4563
8	1.3279	1.2186	.016	.016	.016	1.3443	1.6004
9	1.3279	1.1363	.016	.016		1.4243	1.5364
10	.0156	.016	1.0562	1.2963		.016	.0164
11	.0156	.016	1.4723			.016	.0164
12	.0156	.016	1.4563			.016	.016
13	.0156	.016	1.5844		1.3603	.016	.016
14	.0156	.016	1.6004		1.8084		.016
15	.0156	.016	1.7124		1.8884		.016
16	.0156	.016	1.7604		1.8404		.016
17	.0156	.016	1.5203		1.7124	.016	.016
18	.0312	.016	.016	.032	1.4403	.016	.016
19	.0469	.032	.032	.048	1.1043	.032	.016
20	.0469	.032	.032	.048	1.1043	.032	.032
21	.0625	.032	.016	.048		.032	.032
22		.032	.016	.032	.016	.016	.016
23	.0781	.016	.016	.016	.016	.016	.016
24	.0156	.0469	.016	.016	.016	.016	.016
Max	**1.3279**	**1.2186**	**1.7604**	**1.2963**	**1.8884**	**1.4243**	**1.6004**
Min	**.0156**	**.016**	**.016**	**.016**	**.016**	**.016**	**.016**
Avg	**.3186**	**.3002**	**.5188**	**.0988**	**.6553**	**.3978**	**.3995**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
KHATAV S/DN.[830] BU 4830
Substation No/ Name :- 254054 / 33/22 KV Shindewadi (Katgun)
Feeder No / Name : 203 / 11 KV VARDHANGAD AG Feeder KV- 11 / OUTGOING SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0158	.0633	.0166	.0166	.0166	.0166	.0166
2	.0158	.0633	.5304	.6133	.0166	.0166	.0166
3	.0158	.0633	.5636	.6133	.0166	.0166	.0166
4	.0158	.0633	.5967	.6299	.0166	.0166	.0166
5	.0158	.0633	.6299	.6464	.0166	.0166	.0166
6	.0158	.0633	.7625	.8453	.0332	.0166	.0166
7	1.2809	.0158	1.094	1.2597	.0166	.0166	.0166
8	.0158	.0158	1.3426	1.3592		.0166	.0187
9	.0158	.0166	.9116	1.2431		.0166	.0166
10	.9488	1.0774	.0166	.0166		1.6409	1.4918
11	1.1702	1.1934	.0166			2.0885	1.8945
12		1.2597	.0166			2.1879	1.9685
13	1.4074	1.4089	.0166	.0166	.0166	2.1548	1.6164
14	1.4706	1.3757	.0166	.0166	.0166	1.6244	1.8724
15	1.4548	1.4752	.0166	.0166	.0166	1.9725	1.9364
16	1.4548	1.4918	.0166	.0166	.0166	1.873	1.9227
17	1.2334	1.4089	.0166	.0166	.0166	1.5746	1.5912
18	.0633	.0166	.0166	.0332	.0166	.0663	
19	.0633	.0332	.0332	.0663	.0332	.0829	.0166
20	.0633	.0332	.0332	.0663	.0497	.0995	.0332
21	.0791	.0332	.0166	.0497	.0497	.0663	.0332
22	.0791	.0332	.0166	.0332	.0166	.0332	.0166
23	.1265	.032	.0166	.0166	.0166	.0166	.0166
24	.0158	.0671	.0166	.0166	.0166	.0166	.0166
Max	**1.4706**	**1.4918**	**1.3426**	**1.3592**	**.0497**	**2.1879**	**1.9685**
Min	**.0158**	**.0158**	**.0166**	**.0166**	**.0166**	**.0166**	**.0166**
Avg	**.4799**	**.4736**	**.2804**	**.3458**	**.0218**	**.6520**	**.6338**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
KHATAV S/DN.[830] BU 4830
Substation No/ Name :- 254054 / 33/22 KV Shindewadi (Katgun)
Feeder No / Name : 301 / 22 KV Nidhal GAOTHAN GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0754	.0377	.0377	.0377	.0377	.0377
2	.0377	.0754	.0377	.0377	.0377	.0377	.0377
3	.0377	.0754	.0377	.0377	.0377	.0377	.0377
4	.0377	.0754	.0377	.0377	.0377	.0377	.0377
5	.1132	.1132	.0754	.0377	.0754	.0754	.0377
6	.1132	1.6598	.1509	.0754	.1509	.1509	.1132
7	.1509	.1509	.1886		.1509	.1509	.1886
8	.1132	.1132	.1509			.1509	.1886
9	.1132	.1132	.1132		.1132	.1132	.1132
10	.0754	.0754	.1132	.0377	.1132	.0754	.0754
11	.0754	.0754	.0377	.0377	.0754	.0754	.0754
12		.0754	.0754		.0754	.0754	.0754
13	.0377	.0754	.0377	.0377	.0754	.0754	.0377
14	.0377	.0754	.0754	.1132	.0754	.0377	.0377
15	.0377	.0754	.0754		.0754	.0377	.0377
16	.0377	.0754	.0754	.1132	.0754	.0754	.0754
17	.0754	.0754	.1132	.0754	.0754	.0754	.0754
18	.1132	.1132	.1132		.1132	.1132	.1132
19	.1509	.1509	.1886	.1886	.1886	.1886	.1509
20	.1886	.1132	.1509	.1509	.1509	.1509	.1509
21	.1132	.1132	.1132	.1132	.1132	.1132	.1132
22	.1132	.0754	.1132	.1132	.0754	.1132	.0754
23	.0754	.0377	.0754	.0754	.0377	.0754	.0754
24	.0754	.0754	.0377	.0377	.0377	.0377	.0377
Max	**.1886**	**1.6598**	**.1886**	**.1886**	**.1886**	**.1886**	**.1886**
Min	**.0377**	**.0377**	**.0377**	**.0377**	**.0377**	**.0377**	**.0377**
Avg	**.0853**	**.1556**	**.0927**	**.0754**	**.0869**	**.0880**	**.0833**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
KHATAV S/DN.[830] **BU 4830**
Substation No/ Name :- 254054 / 33/22 KV Shindewadi (Katgun)
Feeder No / Name : 302 / 22 KV DARUJ AG SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2263	.2263	.1886	.3772	.2641	.2263
2	1.0974	1.0486	.2263	.1886	.3772	1.5581	1.6004
3	1.073	1.0486	.2263	.1886	.3772	1.5581	1.6644
4	1.1065	1.0486	.2263	.1886	.3772	1.5912	1.7284
5	1.4091	1.1142	.2641	.1886	.415	1.6907	1.8343
6	1.6057	1.5074	.3395	.2641	.4904	2.0222	2.2497
7	2.0805	2.2405	.3772	.3772	.5658	2.6882	2.2809
8	2.2725	.2881	.3018	.415		2.7206	2.8746
9	1.6644	2.0165	.2641	.3772		2.7854	2.6871
10	.2641	.3018	2.1445	2.2217		.3018	.3018
11	.3018	.3018	2.2725			.3395	.3395
12		.2641	2.8487			.3018	.2641
13	.2641	.2641	2.4326		2.3644	.2641	.2641
14	.3018	.2641	2.4646		2.5911	.2641	.3018
15	.3018	.3018	2.6886		2.6235	.3018	.2641
16	.3395	.3018	3.0087		3.6599	.3772	.2263
17	.3018	.1509	2.7846		3.3036	.3395	.2641
18	.2641	.2263	.3018	.5658	2.6882	.3772	.3772
19	.415	.3772	.415	.5658	2.3644	.4904	.4904
20	.415	.3772	.3772	.5281	2.1052	.4527	.4527
21	.3395	.3395	.3395	.5281	.4527	.415	.415
22	.3018	.3018	.3018	.4904	.3395	.3772	.3395
23	.2263	.2641	.2263	.3772	.3018	.3018	.2641
24	.2263	.1509	.2263	.2263	.3772	.2641	.2641
Max	**2.2725**	**2.2405**	**3.0087**	**2.2217**	**3.6599**	**2.7854**	**2.8746**
Min	**.2263**	**.1509**	**.2263**	**.1886**	**.3018**	**.2641**	**.2263**
Avg	**.7304**	**.6136**	**1.0535**	**.4635**	**1.3764**	**.9186**	**.9156**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
KHATAV S/DN.[830] BU 4830
Substation No/ Name :- 254054 / 33/22 KV Shindewadi (Katgun)
Feeder No / Name : 303 / 22 KV Nidhal AG Feeder KV- 22 / OUTGOING SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1132	.0754	.0754	.0754	.0754	.1509
2	.1132	.0754	.5281	.5144	.0754	.0754	.1509
3	.1132	.0754	.5658	.5144	.0754	.0754	.1509
4	.1132	.0754	.5487	.4801	.0754	.0754	.1509
5	.1132	.1132	.5365	.5426	.1132	.1132	.1509
6	.1886	.1509	.7042	.7865	.1509	.1509	.1886
7	.1509	.1509	1.0437	1.1843	.1886	.1509	.1509
8	.1509	.1132	1.2651	1.4083		.1132	.1132
9	.0754	.1509	.9172	1.2163		.1132	.1132
10	1.0242	1.1203	.0754	.0754		1.6712	1.5402
11	1.3123	1.5364	.0754			2.1628	1.9334
12		1.5043	.0754			2.1956	2.0972
13	1.5684	1.6004	.0754	.0754	.0754	2.2611	1.9334
14	1.5684	1.6004	.0754	.0754	.0754	2.0972	2.0972
15	1.5364	1.5684	.0754	.1886	.1132	2.2283	1.8351
16	1.5364	1.5364	.0754	.1132	.0754	2.1956	1.8679
17	1.2803	1.3763	.1132	.0754	.1132	1.7368	1.7695
18	.1886	.1132	.0754	.1132	.1132	.1132	
19	.1886	.1509	.1509	.1509	.1509	.1509	.1886
20	.1886	.1509	.1132	.1132	.1509	.1509	.1886
21	.1886	.1509	.1509	.1132	.1509	.1509	.1886
22	.1509	.1132	.0754	.1132	.1132	.1509	.1509
23	.1509	.0754	.0754	.1132	.0754	.1509	.1509
24	.1132	.1132	.0754	.0754	.0754	.0754	.1509
Max	**1.5684**	**1.6004**	**1.2651**	**1.4083**	**.1886**	**2.2611**	**2.0972**
Min	**.0754**	**.0754**	**.0754**	**.0754**	**.0754**	**.0754**	**.1132**
Avg	**.5273**	**.5720**	**.3143**	**.369**	**.1072**	**.7681**	**.7571**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] BU 5924
Substation No/ Name :- 254027 / VADUJ
Feeder No / Name : 201 / GOPUJ AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.0572	.0572	.1905	.1524	.0572	.1905
2	.6554	.7373	.0572			.5735	.7865
3	.6882	.7701	.0572			.6226	1.1142
4	.6882	.8192	.0572			.7045	
5	.8848	.9339	.0572			.852	1.1142
6	1.0159	1.0486	.1334	.1905	.2286	.9667	1.1797
7	1.6385	1.5565	.2286	.3429	.2667	1.4091	1.6385
8	1.4091	1.704	.1715	.3048	.2667	1.5238	
9		1.4419	.1143	.2286		1.5074	.9339
10	.1334	.1143	1.7368	1.5729	1.3435	.0953	.1143
11	.1143	.0953	2.0153	1.9334	1.8842	.0953	.0572
12	.0762	.0762	1.9006	1.6876	1.9662	.0953	.0762
13	.1143	.0953	1.8351	1.5565		.0762	.0953
14	.0762	.0953	1.7859	1.5238		.0762	.0953
15	.0953	.0762	1.7368	1.6549		.1143	.0953
16	.0953	.0953	1.7695	1.5238		.1143	.1143
17	.1143	.0953	1.6385	1.4746		.1905	.1334
18	.1143	.0953	.1905			.2286	
19	.1524	.1143				.2667	.1334
20	.1334	.0953	.2286			.2667	.1143
21	.0953	.0953				.3048	.0953
22	.0762	.0762			.0762	.2286	.0762
23	.0572				.0762	.1905	.0572
24	.1905	.0572	.0572			.0572	.1905
Max	**1.6385**	**1.704**	**2.0153**	**1.9334**	**1.9662**	**1.5238**	**1.6385**
Min	**.0572**	**.0572**	**.0572**	**.1905**	**.0762**	**.0572**	**.0572**
Avg	**.3830**	**.4498**	**.7914**	**1.0911**	**.6956**	**.4424**	**.4003**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] BU 5924
Substation No/ Name :- 254027 / VADUJ
Feeder No / Name : 202 / VADUJ AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1524	.1905		.1524	.1524	.1905
2	.5243	.3605	.1715			.4096	.6554
3	.5898	.3932	.1715			.3932	.6882
4	.5898	.426	.1715			.3932	.7209
5	.6226	.5243	.2096			.4096	.9175
6	.6882	.6554	.2667	.2286	.2286	.5735	1.0814
7	1.1142	1.2452	.4382	.381	.381	.852	1.3763
8	1.3435	1.2289	.2667	.381		.9175	
9	.5735	1.1633	.2286	.3048		.852	.7701
10	.2286	.2286	.9503	1.1961	1.2125	.1715	.3239
11	.2096	.2286	1.3272	1.491	1.2289	.1715	.2096
12	.1524	.2477	1.3108	1.4746	1.278	.1905	.2477
13	.1524	.2286	1.4091	1.1797		.2286	.2096
14	.1715	.1905	1.5402	1.2289			.1905
15	.1905	.1905	1.3599	1.3435			.2096
16	.2096	.1905	1.3272	1.3435		.2477	
17	.2477	.2286	1.4091	1.3763		.2286	
18	.2858	.2858	.1905			.3429	.2858
19	.362	.381				.381	.3048
20	.3429	.3429	.2667			.381	.2858
21	.3048	.3048				.381	.2667
22	.2477	.2667		.1905	.2096	.3048	.2286
23	.1905				.1715	.2286	.1905
24	.1905	.1524	.1905			.1524	.2286
Max	**1.3435**	**1.2452**	**1.5402**	**1.491**	**1.278**	**.9175**	**1.3763**
Min	**.1524**	**.1524**	**.1715**	**.1905**	**.1524**	**.1524**	**.1905**
Avg	**.4051**	**.4181**	**.6698**	**.9323**	**.6078**	**.3801**	**.4563**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] **BU 5924**
Substation No/ Name :- 254027 / VADUJ
Feeder No / Name : 203 / WATER SUPPLY **NON SHEDDABLE WATER SUPPLY AND UTILITY**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0655	.0492	.0492		.1147	.0492	.1147
2	.0655	.1147	.1147			.1147	.1147
3	.0655	.1147	.1147			.1147	.1147
4	.0655	.1147	.1147			.1147	.1147
5	.0655	.1147	.0492			.1147	.1147
6	.1638	.1638	.1638	.1638	.1638	.1638	.1147
7	.1638	.1638	.1638	.1638	.1802	.1638	.1638
8		.1638	.1638	.1147	.1802	.1638	
9	.1638	.1638	.1638	.1638		.1638	.1638
10	.1147	.1638	.1638	.1638	.1147	.1638	.1638
11	.1638	.1638	.1638	.1638	.1147	.1638	.1638
12	.1638	.1638	.1638	.0983	.0983	.1638	.1638
13	.1147	.0983	.1638	.0492		.1638	.1638
14	.1147	.0983	.1638	.0492		.1638	.0983
15	.1638	.1638	.1147	.1638		.1638	.1638
16	.0492	.1638	.1638	.1638		.1638	.1638
17	.1638	.1638	.1638	.1638		.1638	.1638
18	.1638	.1802	.1638			.1638	.1638
19	.1638	.1802				.1638	.1638
20	.1638	.1638	.1638			.1638	.1638
21	.1147	.1147				.1638	.1638
22	.0492	.1147			.1147	.1147	.1147
23	.0492				.1147	.1147	.0492
24	.0655	.0492	.0492			.0492	.1147
Max	**.1638**	**.1802**	**.1638**	**.1638**	**.1802**	**.1638**	**.1638**
Min	**.0492**	**.0492**	**.0492**	**.0492**	**.0983**	**.0492**	**.0492**
Avg	**.1147**	**.1368**	**.1368**	**.1352**	**.1329**	**.1420**	**.1389**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] BU 5924
Substation No/ Name :- 254027 / VADUJ
Feeder No / Name : 204 / VADUJ GAONTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5068	.4938	.4887		.4755	.4887	.6219
2	.5068	.4525	.4706			.4706	.5068
3	.5068	.4525	.4706			.4706	.5068
4	.5487	.4706	.4706			.4887	.5792
5	.6584	.5068	.5068			.5249	.695
6	.7682	.6697	.6878	.695	.695	.8507	.8048
7	1.134	1.0498	1.1403	1.0608	1.0974	1.1946	1.267
8		1.086	1.1403	1.0974		1.2127	
9	.9412	.9412	.9412	.9774		.9774	1.086
10	.905	.905	.8688	.8869	.9877	.905	.905
11	.8688	.8326	.8688	.8688	.9511	.905	.8326
12	.7964	.905	.7602	.7964	.8962	.8688	.8326
13	.724	.7602	.724	.724		.905	.7964
14	.7602	.7602	.6878	.7059		.788	.724
15	.7964	.724	.724	.7059		.788	.7602
16	.7964	.7602	.7602	.7421		.8596	.7964
17	.8869	.8326	.8048	.7602		.9511	.8145
18	.9774	1.0136	1.0242			1.2308	1.0498
19	1.2127	1.2851				1.3169	1.2127
20	1.1584	1.1041	1.0608			1.3032	1.1222
21	1.0498	1.0136				1.267	1.0136
22	.8869	.8688		.8413	.8869	1.2437	.8869
23	.6878				.6697	.695	.7059
24	.5121	.5487	.6154			.5792	.6219
Max	**1.2127**	**1.2851**	**1.1403**	**1.0974**	**1.0974**	**1.3169**	**1.267**
Min	**.5068**	**.4525**	**.4706**	**.695**	**.4755**	**.4706**	**.5068**
Avg	**.8083**	**.8016**	**.7608**	**.8355**	**.8324**	**.8869**	**.8323**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] BU 5924
Substation No/ Name :- 254027 / VADUJ
Feeder No / Name : 205 / GOPUJ GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0543	.0732	.0724		.0543	.0724	.0724
2	.0543	.0732	.0724			.0724	.0724
3	.0543	.0732	.0724			.0724	.0732
4	.0549	.0732	.0724			.0724	.0724
5	.0914	.0914	.0905			.0905	.0914
6	.0905	.1463	.1267	.1086	.0905	.1448	.1097
7	.1463	.2195	.181	.1463	.1463	.1991	.181
8		.1646	.1448	.1267		.1448	
9	.0732	.128	.1448	.1086		.1086	.0739
10	.0554	.0914	.0905	.0724	.0732	.1086	.0934
11	.0924	.1294	.1086	.1267	.0732	.128	.1109
12	.0934	.1109	.1448	.1267	.0914	.1478	.0924
13	.1109	.1109		.1267		.1494	.0747
14	.0747	.1109	.1448	.1267		.1307	.0739
15	.1109	.1109	.1267	.1448		.112	.0747
16	.0739	.1294	.1086	.0905		.0934	.112
17	.0739	.0732	.1086	.0724		.1448	.0914
18	.0914	.0732	.1267			.1463	.1097
19	.1646	.1829				.1848	.1646
20	.1646	.2012	.1448			.1829	.1646
21	.1646	.1646				.181	.128
22	.1829	.1463			.1463	.1463	.1463
23	.1463				.1463		.128
24	.0732	.0914	.0905			.0905	.0724
Max	**.1829**	**.2195**	**.181**	**.1463**	**.1463**	**.1991**	**.181**
Min	**.0543**	**.0732**	**.0724**	**.0724**	**.0543**	**.0724**	**.0724**
Avg	**.0997**	**.1204**	**.1143**	**.1148**	**.1027**	**.1271**	**.1036**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] BU 5924
Substation No/ Name :- 254027 / VADUJ
Feeder No / Name : 206 / 11KV KUMTHE AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1143	.1143	.1524	.1905	.1334	.1524
2	.1524	.1143	.6554			.1334	.1524
3	.1524	.1143	.6882			.1334	.1524
4	.1524	.1143	.7373			.1334	.1334
5	.381	.1905	.8192			.1715	.1334
6	.1905	.2858	.852	1.3108	.2286	.2858	.1905
7	.3048	.362	1.2616	1.9662	.6882	.4001	
8	.2667	.3429	1.3108	1.9989	1.6385	.3048	
9	.2477	.2477	1.2616	2.0317		.2667	.2477
10	1.4419	1.6712	.2096	.1524	.2286	2.0195	2.1136
11	1.9989	2.0153	.1334	.1905	.1905	1.5402	2.3922
12	2.13	2.3266	.1334	.1715	.1715	2.4249	4.8826
13	2.3266	2.3266	.1334	.1715		2.7526	2.8346
14	2.1628	2.3594	.1715	.1905		1.6712	2.7199
15	2.2611	2.4413	.0953	.1905		1.8351	2.3922
16	2.2611	2.3266	.1334	.1715		1.5402	2.3266
17	2.1464	1.9989	.2286	.1905		1.278	2.2775
18	.2477	.1905	.1905			.2667	.2286
19	.3429	.2667				.3048	.3048
20	.3048	.2477	.2286			.3429	.2858
21	.2477	.2096				.3048	.2477
22	.2286	.1715			.1905	.2667	.2286
23	.1715				.1524	.2286	.1715
24	.1905	.1334	.1143			.1334	.1905
Max	**2.3266**	**2.4413**	**1.3108**	**2.0317**	**1.6385**	**2.7526**	**4.8826**
Min	**.1524**	**.1143**	**.0953**	**.1524**	**.1524**	**.1334**	**.1334**
Avg	**.8526**	**.8944**	**.4736**	**.6838**	**.4088**	**.7863**	**1.1254**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] BU 5924
Substation No/ Name :- 254038 / KATARKHATAV
Feeder No / Name : 201 / 11 KV BANPURI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3546	.1334	.1905		.1524	.2286
2		1.3546	.1334	.1905			1.5432
3	1.3889	1.3546	.1334	.1905			1.5775
4		1.3546	.1334	.1905			1.5775
5		1.5432	.1905	.1905			1.6118
6	1.6118	1.6632	.2477	.0762			1.8861
7		1.7318	.3429	.2667			2.0748
8	1.8347	1.8519	.3429	.3048	.381		2.0919
9	1.869	1.8004	.2477	.2096	.3239	1.6804	2.0748
10	.2096	.2286	2.0748		1.8861	.2858	.2286
11	.2096	.1905	2.5206	2.4006	2.2977	.2477	.2477
12	.1905		2.4348		2.1776	.2477	.2096
13	.1905		2.4863		2.0576	.2477	.1905
14			2.4177		.6485	.2286	.1905
15	.1715		2.4177		2.1091	.2096	.1715
16	.2096		2.4177		2.1091	.2096	.1905
17	.1905		2.2119		1.9547	.2096	.2286
18	.2286		.2477		.2667	.2858	.2096
19	.2286		.3429		.2858	.3048	.2667
20	.2286		.3239		.2667	.3048	.2667
21	.1905		.3048		.2286	.2858	.2286
22	.1905		.2477		.1905	.2477	.1905
23	.1524	.1715	.2096		.1905	.2477	.1715
24	.1715	.1524	.1524	.2096	.1715	.1715	.2286
Max	**1.869**	**1.8519**	**2.5206**	**2.4006**	**2.2977**	**1.6804**	**2.0919**
Min	**.1524**	**.1524**	**.1334**	**.0762**	**.1715**	**.1524**	**.1715**
Avg	**.5259**	**1.1348**	**.9465**	**.4018**	**1.0321**	**.3275**	**.7452**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] BU 5924
Substation No/ Name :- 254038 / KATARKHATAV
Feeder No / Name : 203 / 11 KV Palasgaon Ag Feeder KV- 11 / OUTGOING
SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1143	.1715		.1143	.1524
2			.2103	.3429		.1143	.1524
3	.1524		.2103	.3429		.1143	.1524
4			.2804	.4458		.1143	.1524
5			.3856	.703		.1905	.1905
6	.362		.5721	.9259		.2477	.2858
7			.5201	.9602		.5335	.4191
8	.4954		.463	.9602	1.1831	.4763	.4572
9	.3239			.823	.3601	.362	.3429
10	.5144		.2667		.0381	.3801	.9526
11	.6687		.1905	.2667	.2477	1.1218	1.2003
12	.7373		.1334		.2286	1.0974	1.4175
13	.8059		.1334		.1715	1.1317	1.4706
14	.8059		.1143		.1715	1.3546	1.3889
15	.8745		.1334		.1143	1.3032	1.4403
16	.8745		.1334		.1334	1.3717	1.4575
17	.7373		.1524		.1715	1.2517	1.2346
18	.2286		.2096		.2667	.2667	.2477
19	.381		.4191		.381	.362	.3239
20	.3429		.381		.3239	.3239	.2858
21	.2667		.3239		.2477	.2667	.2286
22	.1905		.2286		.1905	.2096	.2096
23	.1334	.1334	.1715		.1334	.1905	.1524
24	.1524	.1143	.1334	.1715	.1143	.1334	.1715
Max	**.8745**	**.1334**	**.5721**	**.9602**	**1.1831**	**1.3717**	**1.4706**
Min	**.1334**	**.1143**	**.1143**	**.1715**	**.0381**	**.1143**	**.1524**
Avg	**.4762**	**.1239**	**.2557**	**.5558**	**.2634**	**.5430**	**.6036**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] BU 5924
Substation No/ Name :- 254038 / KATARKHATAV
Feeder No / Name : 301 / PIMPRI GAOTHAN GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1524			.1524	.1143
2			.1524			.1524	.1143
3	.1905		.1143			.1524	.1143
4			.1143			.1524	.1143
5			.2286			.1524	.1143
6	.2286		.2667			.1905	.1524
7			.2667			.3048	.1524
8	.2286		.2667		.2667	.2667	.2286
9	.1905		.1905		.1905	.2286	.1524
10	.1905		.1905		.1524	.1905	.1524
11	.1143		.1524	.2286	.1905	.1905	.1494
12	.1524		.1524		.1905	.1524	.1372
13	.1524		.1524		.1905	.1524	.1372
14	.1524		.1524		.1905	.1143	.1524
15	.1524		.1524		.1905	.1143	.1524
16	.1524		.1524		.1905	.1143	.1524
17	.1524		.1143		.1905	.1143	.1524
18	.1524		.1524		.2286	.1143	.1524
19	.2286		.2286		.3048	.2286	.2286
20	.2286		.1524		.2667	.1524	.2286
21	.1524		.1524		.2286	.1524	.1524
22	.1524		.1524		.2286	.1524	.1524
23	.1524	.1905	.1143		.1905	.1524	.1143
24	.1524	.1143	.1905		.1524	.1524	.1143
Max	**.2286**	**.1905**	**.2667**	**.2286**	**.3048**	**.3048**	**.2286**
Min	**.1143**	**.1143**	**.1143**	**.2286**	**.1524**	**.1143**	**.1143**
Avg	**.1725**	**.1524**	**.1715**	**.2286**	**.2084**	**.1667**	**.1494**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] **BU 5924**
Substation No/ Name :- 254038 / KATARKHATAV
Feeder No / Name : 302 / ENKUL GAOTHAN **GAOTHAN FEEDER**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1143			.1143	.1143
2						.1143	.1143
3	.1524		.1143			.1143	.1143
4			.1143			.1143	.1143
5			.1143			.1143	.1143
6	.1524		.1524			.1524	.1524
7			.1905			.2667	.1524
8	.2286		.1524		.1905	.1905	.1524
9	.1905		.1143		.2286	.1524	.1524
10	.1524		.2286		.2286	.1524	.2286
11	.2286		.1524	.1905	.1524	.1905	.2286
12	.1524		.1524		.1524	.2286	.1524
13	.1524		.1143		.1524	.1143	.1524
14	.1143		.1143		.1524	.1524	.2286
15	.1143		.1143		.1524	.1524	.2286
16	.1524		.1143		.1524	.1143	.2286
17	.2286		.1524		.1143	.1524	.1524
18	.1143		.1143		.1524	.1524	.1143
19	.1524		.1524		.1905	.1524	.1524
20	.1524		.1143		.1905	.1524	.1524
21	.1143		.1143		.1524	.1143	.1143
22	.1143		.1143		.1143	.1143	.1143
23	.1143	.1143	.1143		.1143	.1143	.1143
24	.1524	.1143	.1143		.1524	.1143	.1143
Max	**.2286**	**.1143**	**.2286**	**.1905**	**.2286**	**.2667**	**.2286**
Min	**.1143**	**.1143**	**.1143**	**.1905**	**.1143**	**.1143**	**.1143**
Avg	**.1544**	**.1143**	**.1325**	**.1905**	**.1614**	**.1461**	**.1524**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] BU 5924
Substation No/ Name :- 254038 / KATARKHATAV
Feeder No / Name : 303 / MANDVE GAOTHAN GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0762		.1143	
2			.0762		.1143	.1143
3	.1905		.0762		.1143	.1143
4			.0762		.1143	.1143
5			.1143		.1143	.1143
6	.1524		.1143		.1143	.1143
7					.1524	.1524
8	.1524		.1143	.2286	.1143	.1524
9	.2286		.1143	.1905	.1143	.1143
10	.1905			.1524	.1143	.1143
11	.1143			.1143	.1143	.1132
12	.1143		.1143	.1143	.1143	.1143
13	.1143		.1143	.1143	.1143	.1143
14	.1143		.1143	.1143	.1143	.1143
15	.1143		.1143	.1143	.1143	.1143
16	.1143		.1143	.1143	.1143	.1143
17	.1143		.1143	.1143	.1143	.1143
18	.1143		.1143	.1143	.1143	.1143
19	.1143		.1143	.1143	.1143	.1143
20	.1143		.1143	.1143	.1143	.1143
21	.1143		.1143	.1143	.1143	.1143
22	.1143		.1143	.1143	.1143	.1143
23	.1143	.1143	.1143	.1143	.1143	.1143
24	.1524	.1143	.1143	.1905	.1143	
Max	**.2286**	**.1143**	**.1143**	**.2286**	**.1524**	**.1524**
Min	**.1143**	**.1143**	**.0762**	**.1143**	**.1143**	**.1132**
Avg	**.1344**	**.1143**	**.1070**	**.1322**	**.1159**	**.1177**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] **BU 5924**
Substation No/ Name :- 254038 / KATARKHATAV
Feeder No / Name : 306 / 22 KV Bombale AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 22 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2667			.3048	.3048
2			.3856			.3048	.3048
3	.2667		.3982			.3048	.3048
4			.3982			.3048	.3048
5			.3856			.4572	.381
6	.5335		.5959			.6859	.4572
7						.8383	.5335
8	.6097		.6859		1.9204	.6478	.6097
9	.5335		.6173		1.6461	.4191	.3429
10	.7545				.4572	1.7147	1.9052
11	1.6461		.2286	.2667	.3429	2.1262	2.0241
12	1.6461		.3048		.3429	2.4006	2.1971
13	1.7147		.2667		.3048	2.4006	2.0576
14	1.8519		.1905		.3048	2.4348	2.2634
15	1.166				.3048	2.4691	2.2634
16	1.7147				.3048	2.332	2.4006
17	1.3032				.1905	2.0576	2.0576
18	.381				.5335	.3429	.4572
19	.6097		.6097		.6097	.6097	.6097
20	.5335		.5335		.5716	.6097	.5716
21	.4572		.4572		.5335	.5335	.4954
22	.381		.381		.4191	.381	.381
23	.2286	.2667	.3048		.3429	.3429	.3048
24	.2667	.2286	.2667		.2286	.3048	.3048
Max	**1.8519**	**.2667**	**.6859**	**.2667**	**1.9204**	**2.4691**	**2.4006**
Min	**.2286**	**.2286**	**.1905**	**.2667**	**.1905**	**.3048**	**.3048**
Avg	**.8736**	**.2477**	**.4043**	**.2667**	**.5505**	**1.0553**	**.9932**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] BU 5924
Substation No/ Name :- 254039 / NIMSOD
Feeder No / Name : 201 / AMBAWADE AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0663	.0663	.0995	.0983	.0663	.0663	.0995
2	.7701	.6478	.6154	.0819	.0663	.116	.7935
3	.7865	.7209	.6154	.0829	.0663	.0678	.7935
4	.7373	.8192	.6154	.0829	.0663	.0829	.7935
5	.8029	.8745	.6478	.0995	.0829	.1006	.8583
6	1.0526	1.0526	.8583	.1326	.0983	.1326	1.3765
7	1.1984	1.5497	1.3117	.1638	.1326	.1989	1.9595
8	1.7204	1.6004	1.4575	.1638	.1677	.1966	1.9919
9	1.6712	1.5223	1.6518	.1296	.1326	.1658	1.7328
10	.1492	.0995	1.4575	1.3117	1.8023	.0995	.1658
11	.1341	.1326	1.7924		2.1956	.0995	.1658
12	.0995	.1326	1.8084		2.2672	.0995	.1492
13	.0983	.1326	1.6804		2.2725		.1326
14		.0995	1.5203	1.5546	2.0729		.1311
15	.1311	.0995	1.7814	1.6032	2.2405	.0995	.1311
16	.1326	.0995	1.7004	1.4899	2.1862		.1311
17	.1658	.1526	1.587	1.4413	2.1052	.0995	.1802
18	.1326	.1341	.1823	.0829	.1326	.1658	.1638
19	.1658	.1658	.2486	.116	.1658	.1492	.1638
20	.1658	.1492	.1326	.0829	.1341	.116	.1475
21	.1326	.1492	.1311	.0995	.116	.1492	.1311
22	.1147	.1492	.1311	.0663	.116	.1326	.1326
23	.0995	.1326	.1147	.0663	.0983	.1326	.0995
24	.0663	.0829	.1326	.0983	.0663	.0671	.0995
Max	**1.7204**	**1.6004**	**1.8084**	**1.6032**	**2.2725**	**.1989**	**1.9919**
Min	**.0663**	**.0663**	**.0995**	**.0663**	**.0663**	**.0663**	**.0995**
Avg	**.4606**	**.4485**	**.9281**	**.4309**	**.7855**	**.1208**	**.5218**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] BU 5924
Substation No/ Name :- 254039 / NIMSOD
Feeder No / Name : 204 / 11 KV MORALE GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0526	.0351	.0351	.0351	.0354	.0351	.0351
2	.0351	.0354	.0351	.0351	.0354	.0351	.0351
3	.0351	.0358	.0351	.0351	.0343	.0351	.0351
4	.0351	.0358	.0351	.0351	.0351	.0354	.0351
5	.0532	.0532	.0351	.0701	.0532	.0526	.0351
6	.0701	.0876	.0701	.1052	.0537	.0709	.0701
7	.1402	.1578	.1402	.1578	.1402	.1402	.1402
8	.1052	.0701	.1052	.1052	.1402	.0701	.1227
9	.0876	.0701	.1052	.0701	.1063	.0701	.0701
10	.0701	.0701	.0351	.0701	.0701	.0526	.0351
11	.0526	.0351	.0351	.0526	.0354	.0351	.0351
12	.0351	.0351	.0351	.0526	.0351	.0351	.0351
13	.0362	.0351	.0351		.0354		.0351
14		.0351	.0351	.0526	.0351		.0351
15	.0351	.0351	.0351	.0351	.0351	.0351	.0351
16	.0351	.0351	.0351	.0526	.0351		.0351
17	.0351	.0351	.0351	.0526	.0709	.0351	.0351
18	.0701	.0351	.0526	.0701	.0701	.0701	.0701
19	.0709	.1052	.1052	.0701	.1402	.1052	.1402
20	.1052	.1052	.1227	.1227	.1052	.1052	.1227
21	.0701	.1052	.1052	.1052	.0876	.1052	.0876
22	.0701	.0701	.0876	.0701	.0709	.0701	.0701
23	.0532	.0701	.0351	.0526	.0526	.0351	.0351
24	.0526	.0351	.0351	.0351	.0351	.0351	.0351
Max	**.1402**	**.1578**	**.1402**	**.1578**	**.1402**	**.1402**	**.1402**
Min	**.0351**	**.0351**	**.0351**	**.0351**	**.0343**	**.0351**	**.0351**
Avg	**.0611**	**.0593**	**.0592**	**.0671**	**.0645**	**.0602**	**.0592**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] BU 5924
Substation No/ Name :- 254039 / NIMSOD
Feeder No / Name : 207 / 11 KV Goregaon (N) AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1658	.1492	.1638	.1147	.116	.1326	.1658
2	.1326	.1326	.1638	1.6804	1.3272	1.3279	.1658
3	.1326	.1017	.1638	1.6804	1.3108	1.3443	.1658
4	.116	.1357	.1966	1.6324	1.2793	1.5203	.1658
5	.1147	.1658	.1966	1.6518	1.5384	1.7814	.1989
6	.1989	.2486	.2622	1.8623	1.7814	2.0005	.2984
7	.2652	.431	.3932	2.4646	1.9433	2.4615	.3647
8	.3932	.3647	.4096	2.4006	2.5911	2.4646	.0663
9	.3149	.1326	.3113	2.3365	2.3967	2.5263	.0663
10	1.9662	2.2348	.3113	.1134	.1823	2.2996	.0663
11	2.2725	2.4777	.2294	.1658	.1658	2.8664	2.7854
12	2.2996	2.4615	.213	.1823	.1658	2.834	3.0121
13	2.5911	2.6558	.1966	.1658	.1677		2.9635
14		2.7692	.1638	.1823	.1844		3.1367
15	2.7206	2.7854	.1802	.1989	.2155	2.7854	2.9607
16	2.6558	2.8178	.1802	.1989	.1989		2.9447
17	2.6235	2.5911	.1802	.2155	.2515	2.7206	2.8487
18	.2321	.2267	.2321	.2321	.2486	.2486	.192
19	.2622		.2486	.2984	.2486	.2818	.3041
20	.2321	.2622	.2155	.1989	.2321	.2652	.2753
21	.1989	.2622	.1989	.1492	.2155	.2652	.213
22	.2012	.2294	.1638	.1326	.2012	.2321	.1966
23	.1658	.1966	.1475	.1326	.1658	.1989	.1802
24	.1658	.1658	.1802	.1311	.116	.1326	.1658
Max	**2.7206**	**2.8178**	**.4096**	**2.4646**	**2.5911**	**2.8664**	**3.1367**
Min	**.1147**	**.1017**	**.1475**	**.1134**	**.116**	**.1326**	**.0663**
Avg	**.8879**	**1.0434**	**.2209**	**.7717**	**.7185**	**1.4614**	**.9960**

 Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] **BU 5924**
Substation No/ Name :- 254039 / NIMSOD
Feeder No / Name : 302 / MHASURNE AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 22 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1509	.1132	.1509	.1132	.1132	.1509
2	1.0608	1.0364	1.0608	.1509	.1132	.1132	1.1065
3	1.1271	1.1012	1.0608	.1132	.1132	.1132	1.1065
4	1.0159	1.2163	1.0608	.1132	.1509	.1509	1.1065
5	1.2452	1.2803	1.1271	.1886	.1509	.1509	1.1934
6	1.5729	1.4723	1.1797	.3395	.1886	.2641	1.4918
7	2.2283	2.0405	1.6907	.415	.2641	.3772	2.1628
8	2.2939	2.0729	1.3923	.3772	.415	.3018	2.2672
9	1.9757	1.9845	1.5912	.415	.3772	.2263	2.0081
10	.2263	.2263	1.9006	1.5074	1.8461		.3018
11	.3018	.3018	1.7695	1.8138	2.2085	.1509	.3018
12	.3395	.3018	1.8138	1.6842	2.332	.1886	.2641
13	.2263	.2641	1.749	2.0405	2.4291		.2641
14	.2641	.2263	1.6324	2.1052	2.4905		.3018
15	.2641	.1886	1.6004	2.2996	2.2672	.2263	.3018
16	.2641	.2263	1.5364	2.17	2.0729		.3018
17	.3018	.2263	1.4575	1.9757	2.0729	.1886	.3018
18	.3018	.2641	.2263	.2641	.2641	.2641	.3018
19	.3772	.3018	.3018	.3018	.2641	.3018	.3018
20	.3018	.1886	.2641	.2641	.2641	.2641	.3395
21	.3018	.2263	.2263	.2263	.2263	.2263	.2641
22	.2263	.1509	.1886	.1886	.2263	.1886	.1886
23	.1886	.1509	.1886	.1509	.1886	.1509	.1509
24	.1509	.1509	.1509	.1509	.1509	.1509	.1509
Max	**2.2939**	**2.0729**	**1.9006**	**2.2996**	**2.4905**	**.3772**	**2.2672**
Min	**.1509**	**.1509**	**.1132**	**.1132**	**.1132**	**.1132**	**.1509**
Avg	**.6961**	**.6563**	**1.0535**	**.8086**	**.8829**	**.2056**	**.6929**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] BU 5924
Substation No/ Name :- 254039 / NIMSOD
Feeder No / Name : 303 / NIMSOD AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1509	.0754	.1132	.0754	.0754	.2263
2	.1509	.1509	.0754	.7625	.663	.2321	.2263
3	.1509	.1509	.0754	.7625	.8421	.2294	.2263
4	.1509	.1509	.0754	.7625	.9717	.2267	.2263
5	.2263	.2263	.0754	.7865	1.0486	.2949	.2641
6	.2641	.3018		.7865	1.1984	.3277	.3395
7	.5281	.4904	.2263	1.1469	1.3279	.4858	.4904
8	.4527	.4527		1.3435	1.1336	.4534	.415
9	.3395	.3772		1.2452	1.166	.8421	.3395
10	1.5402	1.2452			.2263		1.9433
11	2.13	2.2542	.1886		.1509	1.5546	2.5911
12	2.332	2.5232	.2641		.1509	2.2024	1.6194
13	2.4646	2.5606	.2263		.1509		1.7166
14	2.1376	2.5606	.1886		.1509		1.8138
15	2.5606	2.4006	.1509	.1886	.1509	2.2939	1.749
16	2.3967	2.0557		.2263	.2263		1.9204
17	2.3045	2.0241		.2263	.2263	2.2672	1.7284
18	.3018	.1886		.1509	.1132	.3018	.1509
19	.3772	.3395	.1509	.1886	.1132	.3772	.1886
20	.3018		.1886	.1509	.1132	.3395	.2263
21	.3018		.1886	.1132	.1132	.3395	.1886
22	.2641	.1132	.1509	.1132	.1132	.2641	.1509
23	.2263	.1132	.1509	.1132	.0754	.2641	.1132
24	.1509	.1509	.0754	.1132	.0754	.0754	.2263
Max	**2.5606**	**2.5606**	**.2641**	**1.3435**	**1.3279**	**2.2939**	**2.5911**
Min	**.1509**	**.1132**	**.0754**	**.1132**	**.0754**	**.0754**	**.1132**
Avg	**.9252**	**.9537**	**.1487**	**.4891**	**.4407**	**.6724**	**.7950**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] **BU 5924**
Substation No/ Name :- 254039 / NIMSOD
Feeder No / Name : 305 / SHIRASWADI GAOTHAN **GAOTHAN FEEDER**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.0754	.0754	.0754	.0754	.0754
2	.0754	.0754	.0754	.0754	.0754	.0754	.0754
3	.0754	.0754	.0754	.0754	.0754	.0754	.0754
4	.0754	.0754	.0754	.0754	.0754	.0754	.0754
5	.0754	.1132	.0754	.0754	.0754	.1132	.0754
6	.1509	.1509	.0754	.1509	.0754	.1509	.1509
7	.1886	.2263	.2263	.2641	.1509	.2641	.1886
8	.2641	.1886	.1886	.2263	.1886	.2263	.1509
9	.2263	.1509	.0754	.1509	.1509	.1509	.1886
10	.1509	.1132	.0754	.0754	.0754	.1132	.0754
11	.1132	.0754	.0754	.0754	.1509	.0754	.0754
12	.0754	.0754	.0754	.0754	.1132	.0754	.0754
13	.0754	.0754	.0754	.0754	.1132		.0754
14	.0754	.0754	.0754	.0754	.0754		.0754
15	.0754	.0754	.0754	.0754	.0754	.0754	.0754
16	.0754	.0754	.0754	.0754	.0754		.0754
17	.0754	.0754	.1132	.1509	.0754	.0754	.0754
18	.1132	.1886	.1886	.1509	.1509	.1886	.0754
19	.2263	.2263	.2641	.2641	.2263	.2263	.2641
20	.1886	.1886	.2641	.2263	.2263	.1886	.2263
21	.1509	.1509	.1886	.1886	.1886	.1509	.1886
22	.1132	.1509	.1509	.0754	.1509	.1509	.1509
23	.0754	.0754	.0754	.0754	.1132	.0754	.0754
24	.0754	.0754	.0754	.0754	.0754	.0754	.0754
Max	**.2641**	**.2263**	**.2641**	**.2641**	**.2263**	**.2641**	**.2641**
Min	**.0754**	**.0754**	**.0754**	**.0754**	**.0754**	**.0754**	**.0754**
Avg	**.1194**	**.1179**	**.1163**	**.121**	**.1179**	**.1275**	**.1131**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] BU 5924
Substation No/ Name :- 254039 / NIMSOD
Feeder No / Name : 306 / PUNWADI GAOTHAN GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1886	.1886	.1886	.1886	.1509
2	.1886	.1886	.1886	.1886	.1886	.1886	.1509
3	.2263	.1886	.1886	.1886	.1509	.1509	.1509
4	.1886	.1886	.2641	.1886	.1509	.1886	.1509
5	.2641	.3018	.3395	.3018	.2263	.2641	.2641
6	.3772	.4527	.4527	.415	.2641	.5281	.415
7	.5658	.679	.679	.5658	.3772	.6036	.6036
8	.5281	.5658	.6036	.4904	.5281	.5658	.4904
9	.3772	.4527	.4527	.3772	.3772	.3772	.3772
10	.3018	.3772	.3772	.3018	.3772	.3018	.3018
11	.2641	.3018	.3395	.3018	.2641	.3018	.2641
12	.2263	.2263	.3018	.3018	.2263	.2263	.2641
13	.2263	.1509	.3018	.2263	.2263		.2641
14	.2263	.0754	.2641	.1886	.2263		.2263
15	.2263	.0754	.2641	.1886	.2263	.2263	.2263
16	.2263	.0754	.3018	.2263	.2263		.2263
17	.2263	.0754	.3018	.2641	.2641	.2263	.2641
18	.3018	.1886	.3772	.3018	.3018	.3395	.3772
19	.5281	.3395	.5281	.4904	.5281	.4904	.5281
20	.4527	.3395	.4527	.4527	.4527	.415	.4904
21	.3772	.3395	.3772	.415	.3772	.3395	.3772
22	.3018	.3018	.3018	.3018	.3018	.3018	.3018
23	.2641	.3018	.2641	.2263	.2641	.2641	.2263
24	.1886	.2263	.2263	.2263	.1886	.2263	.1886
Max	**.5658**	**.679**	**.679**	**.5658**	**.5281**	**.6036**	**.6036**
Min	**.1886**	**.0754**	**.1886**	**.1886**	**.1509**	**.1509**	**.1509**
Avg	**.3018**	**.2751**	**.3474**	**.3049**	**.2876**	**.3197**	**.3034**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] BU 5924
Substation No/ Name :- 254040 / 33/22 KV VIKHALE
Feeder No / Name : 301 / PACHWAD GAOTHAN GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754		.0377	.0754	.0754	.1132	
2	.0762		.0377	.0754	.0739	.0754	
3	.0754		.0377	.0377	.0747	.0754	
4	.0754		.0754	.0377	.0754	.0754	
5	.1132		.1132	.0754	.1143	.1132	
6	.1886		.1509	.1132	.1524	.1509	
7	.2263		.1886	.2263	.2263	.1886	.2263
8	.1494		.1886	.1867	.1886	.1867	.1509
9	.112		.1132	.1478	.1509	.1463	.1132
10	.1097	.1132	.1109	.0732	.112	.1132	.1109
11	.0739	.1132	.1097	.1109	.0754	.0754	.1132
12	.0747	.0754	.0754	.1109	.1132	.0377	.0747
13	.0739	.0754	.0724	.0732	.0747	.0377	.0754
14	.0754	.0754	.1017	.0747	.0373	.0754	.0747
15	.0754	.0377	.1132	.0732	.0377	.0754	.0354
16	.0762	.0377	.1132	.0747	.0754	.0377	.0754
17	.0709	.0377	.1132	.0747	.1086	.0377	.0724
18	.1109	.1132	.112	.1848	.1494	.1132	.1463
19	.1886	.1886	.1867	.1867	.1886	.1886	.2241
20	.1886	.1886	.1867	.1886	.1886	.1886	.1886
21	.1509	.1509	.1886	.1494	.1886	.1509	.1867
22	.1132	.0754	.1509	.1132	.1132	.1132	.1132
23		.0754	.1132	.0747	.1132	.0754	.0754
24	.0762		.0377	.0754	.0739	.1132	.0754
Max	**.2263**	**.1886**	**.1886**	**.2263**	**.2263**	**.1886**	**.2263**
Min	**.0709**	**.0377**	**.0377**	**.0377**	**.0373**	**.0377**	**.0354**
Avg	**.1109**	**.0970**	**.1137**	**.1089**	**.1159**	**.1066**	**.1185**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] BU 5924
Substation No/ Name :- 254040 / 33/22 KV VIKHALE
Feeder No / Name : 302 / PADAL GAOTHAN GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377		.0377	.0377	.0754	.0754	
2	.0377		.0754	.0377	.0739		
3	.0377		.1132	.0377	.0754	.0754	
4	.0754		.1509	.0754	.0754	.0754	
5	.1509		.1886	.1509	.1143	.0754	
6	.1886		.1886	.2263	.1905	.1132	
7	.2641		.2263		.2641	.3018	.2263
8	.1524		.1509	.1905	.2263	.2263	.1886
9	.1905		.1132	.1886	.1509	.1509	.1509
10	.1109	.1132	.112	.0747	.1132	.1132	.1132
11	.0754	.0754	.0754	.0754	.0754	.0754	.0754
12	.0351	.0377	.0354	.0351	.0754	.0377	.0754
13	.0377	.0377	.0739	.0377	.0762	.0377	.0747
14	.0362	.0377	.0354	.0366	.0762	.0377	.037
15	.0377	.0377	.0377	.0354	.0754	.0754	.0754
16		.0377	.0754	.0739	.1143	.0377	.0754
17	.0747	.0754	.0377	.0754	.1132	.0754	.0724
18	.1132	.1132	.1132	.1886	.1905	.1132	.0754
19	.1886	.1886	.1905	.1886	.2263	.1509	.2218
20	.1905	.1886	.1509	.1509	.1886	.1509	.1509
21	.1509	.1132	.1509	.1509	.1494	.1509	.1509
22	.1132	.0754	.1132	.1132	.1132	.1132	.1132
23		.0377	.1132	.0754	.0754	.0754	.1143
24	.0754		.0377	.0709	.0754	.0754	.0754
Max	**.2641**	**.1886**	**.2263**	**.2263**	**.2641**	**.3018**	**.2263**
Min	**.0351**	**.0377**	**.0354**	**.0351**	**.0739**	**.0377**	**.037**
Avg	**.1079**	**.0835**	**.1082**	**.1012**	**.1243**	**.1050**	**.1148**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] BU 5924
Substation No/ Name :- 254040 / 33/22 KV VIKHALE
Feeder No / Name : 303 / KALEDHON GAOTHAN GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132		.1132	.1063	.1132	.1478	
2	.1143		.1132	.1132	.1132	.1132	
3	.1132		.1509	.1132	.1132	.1143	
4	.1132		.1886	.1132	.1143	.1132	
5	.1886		.2263	.1524	.1848	.1886	
6	.2263		.2641	.2263	.2667	.2667	
7	.3048		.3018	.3018	.3018	.3429	.2641
8	.2286		.2641	.2263	.3018	.2667	.2263
9	.2286		.2263	.1772	.2641	.2241	
10	.1867	.1509	.1886	.1509	.1509	.1886	.1494
11	.112	.1132	.1509	.1509	.1132	.1132	.1109
12	.112	.1132	.1509	.1109	.0709	.1132	.1143
13	.1524	.1132	.1905	.1509	.112	.1132	.1086
14	.096	.1132	.1417	.1052	.1132	.1132	.112
15	.1132	.1132	.1509	.1132	.1132	.0754	.1417
16	.1143	.1132	.1433	.1524	.1509	.0754	.1132
17	.1509	.1509	.1132	.1132	.1463	.1509	.1494
18	.1886	.2263	.2286	.2263	.2263	.2641	.2241
19	.2263	.3018	.2286	.2263	.2286	.3018	.2641
20	.2286	.2641	.2667	.1886	.2263	.2641	.2641
21	.1905	.2263	.2286	.1905	.2286	.2263	.1886
22	.1886	.1886	.1886	.1524	.1524	.1886	.1886
23		.1132	.1509	.1075	.1143	.1509	.1886
24	.088		.1132	.1052	.112	.1063	.1132
Max	**.3048**	**.3018**	**.3018**	**.3018**	**.3018**	**.3429**	**.2641**
Min	**.088**	**.1132**	**.1132**	**.1052**	**.0709**	**.0754**	**.1086**
Avg	**.1643**	**.1644**	**.1868**	**.1573**	**.1680**	**.1759**	**.1718**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] BU 5924
Substation No/ Name :- 254040 / 33/22 KV VIKHALE
Feeder No / Name : 304 / STATIONERY POINT **NON SHEDDABLE EXPRESS HV FEEDERS**
Feeder KV- 22 / OUTGOING **(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377		.0754	.0377	.0754	.1509	
2	.0377		.0754	.0377	.0754	.1509	
3	.0377		.0377	.0377	.0754	.1509	
4	.0377		.0377	.0377	.0754	.1509	
5	.0377		.0754	.0377	.0377	.1132	
6	.0377		.0754	.0377	.0377	.0754	
7	.0377		.0754	.0377	.0377	.0377	
8	.0377		.0754	.0377	.0377	.0754	.0377
9	.0754		.0754	.0377	.0754	.1509	
10	.1132	.0754	.0754	.0377	.1509	.2263	.0377
11	.1132	.0754	.0377	.0377	.1509	.3018	.0377
12	.1132	.0754	.0377	.0377		.3395	.0377
13	.1132	.0754	.0377	.0377	.0377	.1886	.0377
14	.1132	.0754	.0377	.0377	.0377	.1132	.0377
15	.1132	.0754	.0377	.0377	.0754	.1132	.0377
16	.1132	.0754	.0377	.0377	.1509	.1132	.0377
17		.1132	.0377	.1509	.1509	.1132	.0377
18	.1509	.1132	.0377	.1509	.3018	.1509	.0377
19	.1132	.0754	.0377	.1132	.1509	.1509	.0377
20	.1132	.0754	.0377	.1509	.1509	.1509	.0377
21	.1509	.0754	.0377	.1132	.2263	.1509	.0377
22	.1132	.0754	.0377	.1132	.2263	.1132	.0377
23		.0754	.0377	.0754	.1886	.1132	.0377
24	.0377		.0754	.0377	.1132	.1509	.1132
Max	**.1509**	**.1132**	**.0754**	**.1509**	**.3018**	**.3395**	**.1132**
Min	**.0377**	**.0754**	**.0377**	**.0377**	**.0377**	**.0377**	**.0377**
Avg	**.0840**	**.0808**	**.0518**	**.0629**	**.1148**	**.1478**	**.0424**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] BU 5924
Substation No/ Name :- 254040 / 33/22 KV VIKHALE
Feeder No / Name : 305 / GHARUDI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263		.1886	.2263	.1886	.2263	
2	.3734		.2263	.2263	.1886	.3734	
3	.5228		.2641	.2263	.1886	.4435	
4	.7392		.3395	.2641	.2263	.5914	
5	1.0242		.415	.3772	.3395	.7316	
6	1.4403		.4904	.4904	.4904	1.134	
7	1.6842		.679	.6413	.679	1.1919	1.5364
8	1.7185		.5281	.5281	.5281	1.406	2.3777
9	.924		.4904	.4527	.4527	1.2269	1.5364
10	.2641	.3395	1.6651	1.3611	1.3756	.3395	.3018
11	.2263	.3018	2.1262	1.8861	1.3169	.3395	.3018
12	.3395	.2641	1.8427	1.9559	2.2634	.3395	.2641
13	.2641	.2641	2.0332	2.1445	2.2801	.3018	.2641
14	.2641	.2263	2.1948	2.0934	2.2192	.2641	.2641
15	.2641	.1886	2.3061	1.989	2.2801	.2641	.2641
16	.1886	.2263	2.3061	2.2874	2.2291	.2641	.3018
17	.2263	.2641	1.8073	1.8991	2.1033	.2641	
18	.3018	.3395	.415	.3772	.4527	.4904	
19	.4904	.4904	.5281	.4904	.4904	.4904	.4904
20	.4904	.4527	.4904	.4527	.4527	.4527	.415
21	.415	.3395	.4527	.415	.3772	.3395	.415
22	.3395	.2263	.3772	.3018	.3018	.2641	.3395
23		.1886	.3018	.2641	.2641	.2263	.2641
24	.2641		.1886	.2263	.2263	.2263	.1886
Max	**1.7185**	**.4904**	**2.3061**	**2.2874**	**2.2801**	**1.406**	**2.3777**
Min	**.1886**	**.1886**	**.1886**	**.2263**	**.1886**	**.2263**	**.1886**
Avg	**.5648**	**.2937**	**.9440**	**.8990**	**.9131**	**.5080**	**.5953**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] BU 5924
Substation No/ Name :- 254040 / 33/22 KV VIKHALE
Feeder No / Name : 306 / KANERWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263		.2263	.2641	.2263	.2263	
2	.1886		.2561	.4481	.2957	.2263	
3	.1886		.2561	.5228	.2957	.2263	
4	.1886		.2534	.7468	.2957	.2641	
5	.2263		.3258	.8871	.3696	.3395	
6	.0754		.5792	1.0719	.8596	.4527	
7	.6413		.9145	1.4118	1.406	.7167	.6413
8	.5658		.9511	1.5238	1.4754	.5281	.4904
9	.3772		.9145	1.3756	1.3226	.415	
10	.8501	1.1088	.3018	.3018	.3772	1.4632	1.2536
11	1.1222	1.4632	.2641	.2263	.3395	1.7193	1.8652
12	1.2071	1.5203	.2641	.3018	.3018	1.6461	1.8176
13	1.2269	1.5203	.2641	.3018	.3395	1.8823	1.8564
14	1.2689	1.5203	.2263	.2641	.3018	1.9909	1.8564
15	1.2689	1.448	.2641	.2263	.2641	2.0271	1.8229
16	.2641	1.5927	.3018	.3018	.3395	1.9909	1.7551
17	1.1919	1.5203	.2263	.3018	.3018	1.7193	1.576
18	.2641	.3395	.3395	.4904	.6036	.3395	.2641
19	.4527	.415	.4527	.5658	.6036	.415	.4904
20	.415		.4527	.5281	.4527	.3772	.3772
21	.3772	.415	.3772	.3772	.3772	.3018	.3772
22	.3018	.3018	.3395	.3395	.3018	.2641	.3395
23		.2641	.3018	.2641	.2641	.2263	.2641
24	2.3167		.2263	.2641	.2641	.2641	.1886
Max	**2.3167**	**1.5927**	**.9511**	**1.5238**	**1.4754**	**2.0271**	**1.8652**
Min	**.0754**	**.2641**	**.2263**	**.2263**	**.2263**	**.2263**	**.1886**
Avg	**.6611**	**1.0330**	**.3866**	**.5545**	**.4991**	**.8343**	**1.0139**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] **BU 5924**
Substation No/ Name :- 254040 / 33/22 KV VIKHALE
Feeder No / Name : 307 / VIKHALE AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 22 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132		.1132	.0754	.1132	.1132	
2	.1132		.1448	.1494	.2587	.1132	
3	.1132		.1448	.1494	.2587	.1132	
4	.1132		.1791	.2241	.2587	.1132	
5	.1886		.2507	.3696	.3292	.1509	
6	.2263		.3582	.5121	.4755	.2263	
7	.2641		.4344	.6878	.7362	.3018	
8	.2263		.4706	.7164	.8916	.3018	.1886
9	.2263		.4706	.5121	.7362	.2263	.3018
10	.4854	.695	.1509	.1132	.1886	1.1222	.8048
11	.695	.8688	.1132	.1132	.1132	1.267	1.0517
12	.7316	.8954	.1132		.1132	1.2308	1.2483
13	.7964	.8954	.1132	.1132	.1132	1.2178	1.0974
14	.8954	.8596	.1132	.1132	.1132		1.0513
15	.8954	.6805	.0754	.1132	.1509	1.182	1.0277
16	.5487	.788	.0754	.1132	.1886	1.0029	.9313
17	.6447	.6447	.1132	.1132	.1509	.9922	.9568
18	.1509	.1509	.1132	.1886	.1886	.1886	.1509
19	.1886	.2263	.1886	.1886	.2263	.1886	.1886
20	.1509	.1886	.1886	.1886	.2263	.1886	.1509
21	.1509	.1132	.1886	.1509	.1886	.1509	.1509
22	.1132	.1132	.1509	.1132	.1509	.1132	.1132
23		.1132	.1132	.1132	.1132	.1132	.1132
24	.1132		.1132	.0754	.1132	.1132	.1132
Max	**.8954**	**.8954**	**.4706**	**.7164**	**.8916**	**1.267**	**1.2483**
Min	**.1132**	**.1132**	**.0754**	**.0754**	**.1132**	**.1132**	**.1132**
Avg	**.3541**	**.5166**	**.1871**	**.2264**	**.2665**	**.4666**	**.5671**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] BU 5924
Substation No/ Name :- 254076 / 33/11 KV Mandave S/S
Feeder No / Name : 201 / 11 KV MANADVE AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1075	.1075	.0857	.0943	.0995	.0995	.1006
2	.1791	.1612	.0857	.0943	.0995	.1658	.2012
3	.3582	.2149	.0857	.1132	.0995	.1658	.3018
4	.6626	.2686	.1029	.1132	.0995	.1658	.4527
5	.8059	.3403	.1715	.2075	.116	.2486	.7712
6	1.0208	.5373	.2915	.3395	.2652	.3978	.8886
7	1.1104	1.2357	.4115	.4338	.3978	.7127	1.3916
8	1.0745	1.2715	.3601	.3772	.3647	.8383	1.6263
9	.985	1.0924	.156	.2075	.2818	.8215	1.3413
10	.1433	.1612	.7733		.8951	.1174	.1341
11		.1372	1.2449	.1715	1.3757	.0838	.1006
12		.0857	1.3957	1.3904	1.5083	.0838	.0671
13	.0895	.0686	1.4146	1.3735	1.5746	.0671	.0838
14	.0895	.0693	1.4712	1.2378	1.6575		.0838
15	.0716	.0686	1.3957	1.4922	1.5912		.0671
16	.0895	.0857	1.2826	1.3735	1.4918	.0671	.0671
17	.1433	.1029	1.1506	1.17	1.3757	.1174	.0838
18	.2328	.1543	.1698	.1526	.1492	.1677	.1509
19	.3045	.2572	.2075	.2984	.2652	.2683	.2683
20	.2686	.2401	.2452	.2486	.2155	.2347	.2515
21	.2328	.1886	.1886	.1823	.1823	.1844	.1844
22	.1612	.1543	.132	.1492	.1326	.1677	.1677
23	.1254	.12	.1132	.0995	.116	.1341	.1341
24	.1075	.1075	.0857	.0943	.0995	.0995	.1006
Max	**1.1104**	**1.2715**	**1.4712**	**1.4922**	**1.6575**	**.8383**	**1.6263**
Min	**.0716**	**.0686**	**.0857**	**.0943**	**.0995**	**.0671**	**.0671**
Avg	**.3802**	**.3013**	**.5426**	**.4963**	**.6022**	**.2459**	**.3758**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] BU 5924
Substation No/ Name :- 254076 / 33/11 KV Mandave S/S
Feeder No / Name : 202 / 11 KV SATEWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0762	.0572	.0943	.0762	.0762	.0754
2	.0732	.0762	.6097	.7733	.5716	.0762	.0566
3	.0754	.0572	.6097	.7545	.5716	.0762	.0566
4	.0754	.0762	.6097	.8676	.6287	.0762	.0754
5	.1132	.1143	.6478	1.358	.8002	.0953	.1132
6	.1698	.1715	.724	1.5089	1.0098	.1715	.1886
7	.2075	.2096	.8954	1.5844	1.6385	.2286	.2075
8	.1646	.1905	1.0288	1.4712	1.7528	.1905	.1886
9	.1132	.1715	.9145	1.2071	1.4289	.0953	.1334
10	1.1812	1.1431	.0762		.1143	1.448	1.4098
11	1.5623	1.5242	.0566	.1715	.0572	1.7353	1.8671
12	1.7718	1.8099	.0566	.0572	.0762	1.9805	1.9052
13	1.8099	1.829	.0566	.0572	.0381	1.9805	1.9052
14	1.8861	1.6004	.0566	.0762	.0572		1.0098
15	1.7528	1.6385	.0566	.0762	.0572	1.9616	1.7718
16	1.6385	1.6766	.0566	.0762	.0762	2.0748	1.9243
17		1.6575	.0754	.0762	.0762	1.4146	1.9624
18	.1334	.0953		.0762	.1143	.0943	.0762
19	.1524	.1524	.1132	.1524	.1715	.1509	.1143
20	.1524	.1715	.1509	.1715	.1334	.132	.1334
21	.1334	.1334	.1509	.1524	.1143	.1132	.1334
22	.1143	.1143	.132	.1143	.0953	.1132	.0953
23	.0953	.0953	.1132	.0953	.0762	.0943	.0953
24	.0943	.0762	.0762	.0943	.0953	.0762	.0754
Max	**1.8861**	**1.829**	**1.0288**	**1.5844**	**1.7528**	**2.0748**	**1.9624**
Min	**.0732**	**.0572**	**.0566**	**.0572**	**.0381**	**.0762**	**.0566**
Avg	**.5898**	**.6192**	**.3185**	**.4811**	**.4096**	**.6285**	**.6489**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] BU 5924
Substation No/ Name :- 254076 / 33/11 KV Mandave S/S
Feeder No / Name : 203 / 11 KV PEDGAON GAVTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0191	.0191	.0189	.0191	.0191	.0189
2	.0377	.0191	.0191	.0189	.0191	.0191	.0189
3	.0377	.0191	.0191		.0191	.0191	.0189
4	.0377	.0191	.0191	.0189	.0191	.0191	.0377
5	.0566	.0381	.0381	.0377	.0191	.0572	.0566
6	.0754	.0762	.0572	.0566	.0762	.0953	.0754
7	.0943	.0762	.0953	.0943	.0762	.0762	.0754
8	.0754	.0572	.0762	.0754	.0762	.0762	.0943
9	.0566	.0572	.0381	.0754	.0572	.0572	.0572
10	.0381	.0381	.0381		.0381	.0381	.0381
11	.0381	.0191	.0377	.0381	.0381	.0189	.0191
12	.0191	.0191	.0377	.0191	.0381	.0189	.0191
13	.0191	.0191	.0377	.0191	.0191	.0189	.0191
14	.0191	.0191	.0377	.0191	.0191	.0189	.0191
15	.0191	.0191	.0189	.0381	.0191	.0189	.0191
16	.0191	.0191	.0189	.0191	.0191	.0189	.0191
17	.0381	.0191	.0189	.0191	.0191	.0189	.0191
18	.0381	.0381	.0189	.0381	.0381	.0377	.0381
19	.0762	.0762	.0566	.0572	.0762	.0754	.0572
20	.0572	.0762	.0566	.0572	.0572	.0754	.0572
21	.0572	.0572	.0566	.0572	.0572	.0566	.0572
22	.0381	.0381	.0377	.0381	.0381	.0566	.0381
23	.0381	.0381	.0189	.0191	.0381	.0377	.0381
24	.0377	.0191	.0191	.0189	.0191	.0191	.0189
Max	**.0943**	**.0762**	**.0953**	**.0943**	**.0762**	**.0953**	**.0943**
Min	**.0191**	**.0191**	**.0189**	**.0189**	**.0191**	**.0189**	**.0189**
Avg	**.0442**	**.0373**	**.0371**	**.0388**	**.0381**	**.0403**	**.0387**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] BU 5924
Substation No/ Name :- 254076 / 33/11 KV Mandave S/S
Feeder No / Name : 204 / 11 KV TADAWALE GAVTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0373	.0377	.0377	.0377	.0377	.0377
2	.0377	.0373	.0377	.0377	.0377	.0377	.0377
3	.0377	.0373	.0377	.0377	.0377	.0377	.0377
4	.0566	.0373	.0377	.0377	.0377	.0377	.0566
5	.0566	.056	.0566	.0566	.0566	.0566	.0754
6	.0943	.0934	.0754	.0943	.0566	.0754	.0943
7	.1132	.0934	.1132	.1132	.132	.0943	.0943
8	.0943	.0747	.0754	.1132	.1132	.0754	.0754
9	.0566	.0754	.0572	.0754	.0943	.0566	.0566
10	.056	.0566	.0566		.0566	.0566	.0566
11	.056	.0566	.0754	.0566	.0566	.0566	.0377
12	.056	.0566	.0566	.0566	.0566	.0754	.0566
13	.0373	.0566	.0377	.0754	.0566	.0566	.0754
14	.056	.056	.0377	.0566	.0566	.0377	.0566
15	.0747	.0566	.0377	.0566	.0943	.0566	.0566
16	.056	.0566	.0377	.0566	.0754	.0943	.0566
17	.0747	.0566		.0566	.0566	.0943	.0566
18	.0934	.0747	.0377	.0754	.0754	.1132	.0566
19	.0934	.0943	.0943	.0943	.0943	.132	.0943
20	.0747	.0943	.0943	.0943	.0754	.1132	.0943
21	.0934	.0943	.0943	.0943	.0943	.0943	.0943
22	.0747	.0754	.0754	.0754	.0754	.0943	.0754
23	.056	.0566	.0566	.0566	.0566	.0566	.0566
24	.0377	.0373	.0377	.0377	.0566	.0377	.0377
Max	**.1132**	**.0943**	**.1132**	**.1132**	**.132**	**.132**	**.0943**
Min	**.0373**	**.0373**	**.0377**	**.0377**	**.0377**	**.0377**	**.0377**
Avg	**.0656**	**.0634**	**.0591**	**.0672**	**.0684**	**.0699**	**.0637**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] BU 5924
Substation No/ Name :- 254076 / 33/11 KV Mandave S/S
Feeder No / Name : 205 / 11 KV HINGANE AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061	.061	.0474	.0633	.0633	.0633	.0633
2	.0914	.0914	.0474	.0474	.0633	.1423	.0949
3	.0914	.1067	.0474	.0474	.0633	.1423	.0949
4	.1524	.1524	.0474	.0474	.0633	.1423	.1581
5	.2439	.1981	.0474	.0633	.0633	.1581	.2214
6	.3048	.3506	.0474	.0791	.0633	.1739	.2846
7	.381	.5182	.0949	.0949	.1107	.2846	.4902
8	.5335	.5487	.0949	.1265	.1265	.4111	.5376
9	.5639	.4687	.0791	.0949	.1107	.3479	.506
10	.061	.0781	.3163		.3637	.0633	.0791
11	.061	.0469	.506	.5376	.4902	.0474	.0633
12	.0457	.0469	.5376	.5851	.5218	.0474	.0633
13	.061	.0469	.5376	.5376	.6325	.0474	.0633
14	.061	.0463	.5535	.5535	.6325	.0474	.0633
15	.061	.0469	.5535	.6483	.6325	.0633	.0474
16	.0457	.0469	.5218	.5535	.5851	.0633	.0633
17	.061	.0469	.506	.5218		.0633	.0791
18	.0762	.0617	.0791	.0949	.0791	.0633	.0949
19	.0914	.0937	.0949	.1265	.1107	.0949	.1107
20	.0914	.0949	.1107	.1107	.0949	.0949	.1107
21	.0914	.0949	.1067	.1107	.0949	.1132	.0949
22	.0762	.0791	.0914	.0791	.1107	.0791	.0791
23	.061	.0791	.0943	.0829	.0791	.0633	.0791
24	.061	.061	.0633	.0633	.0633	.0633	.0633
Max	**.5639**	**.5487**	**.5535**	**.6483**	**.6325**	**.4111**	**.5376**
Min	**.0457**	**.0463**	**.0474**	**.0474**	**.0633**	**.0474**	**.0474**
Avg	**.1429**	**.1444**	**.2178**	**.2291**	**.2269**	**.1200**	**.1502**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] BU 5924
Substation No/ Name :- 254080 / 33/ 11 KV Dhondewadi
Feeder No / Name : 201 / 11 KV Anphale AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1017	.1029	.1017	.1017	.0678	.1017	.1017
2	.0848	.1029	.3391	.3391	.3561	.0848	.1017
3	.0848	.1029	.407	.3561	.373	.0848	.1017
4	.0857	.1029	.4748	.407	.373	.1017	.1017
5	.1029	.1372	.5596	.4748	.5087	.1187	.1187
6	.1715	.2058	.6274	.6952	.8139	.1526	.1696
7	.2229	.3258	.8478	1.0343	1.3565	.2543	.2374
8	.2058	.2572	.8817	1.1191	1.543	.2543	.2543
9	.1372	.2229	.9156	.9835	1.2717	.1865	.2713
10	.463	.8402	.1865	.0848	.1017	.9665	1.3904
11	.6859	1.2209	.1526	.1187	.1187	1.3056	1.5261
12	.7373	1.7126	.1187	.1696	.1526	1.4922	1.6108
13	.7545	1.7126	.1017	.1865	.1357	1.6108	1.6278
14		1.5261	.0848	.1865	.1357	1.6787	1.6278
15	1.166	1.5261	.1187	.2035	.1357	1.56	1.6278
16	1.286	1.4752	.1357	.2035	.1526	1.5939	1.6278
17	1.166	1.3735	.1526	.2035	.1357	1.1191	
18		.1696	.1865	.2035	.1526	.2035	.1357
19	.2058	.2204	.2035	.2035	.1865	.2374	.1526
20	.2058	.2035	.2204	.2035	.1696	.2374	.1696
21	.1715	.1865	.2035	.1696	.1696	.1696	.1696
22	.1543	.1357	.1357	.1357	.1357	.1526	.1357
23	.1543	.1017	.1187	.1017	.1017	.1357	.1017
24	.1017	.1029	.1017	.1017	.0678	.1017	.1017
Max	**1.286**	**1.7126**	**.9156**	**1.1191**	**1.543**	**1.6787**	**1.6278**
Min	**.0848**	**.1017**	**.0848**	**.0848**	**.0678**	**.0848**	**.1017**
Avg	**.3841**	**.5862**	**.3073**	**.3328**	**.3632**	**.5793**	**.5854**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] BU 5924
Substation No/ Name :- 254080 / 33/ 11 KV Dhondewadi
Feeder No / Name : 202 / 11 kv Anphale Gaothan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	.0189	.0377	.0189		.0377
2	.0377	.0377	.0189	.0377	.0189		.0377
3	.0377	.0377	.0189	.0377	.0189		.0377
4	.0377	.0377	.0377	.0377	.0189		.0377
5	.0377	.0377	.0754	.0377	.0189		.0377
6	.0754	.0754	.1132	.0566	.0566	.0754	.0377
7	.1132	.1132	.1132	.0754	.0943	.0943	.0943
8	.0943	.0943	.0754	.0754	.0943	.0754	.0754
9	.0377	.0566	.0189	.0377	.0566	.0754	.0566
10	.0377		.0377	.0189	.0189	.0189	.0377
11	.0189		.0189	.0189	.0189	.0377	.0377
12	.0189	.0189	.0377	.0189	.0189	.0377	.0377
13	.0189	.0189	.0377	.0189	.0189	.0377	.0189
14	.0189	.0189	.0377	.0189	.0377	.0377	.0189
15	.0189	.0189	.0377	.0189	.0377	.0377	.0377
16	.0189	.0189	.0377	.0377	.0377	.0377	.0566
17	.0189	.0377	.0377	.0377	.0566	.0377	.0377
18	.0189	.0566	.0377	.0377	.0754	.0566	.0754
19	.0566	.0943	.0754	.0377	.0943	.0754	.0943
20	.0754	.0754	.0754	.0566	.0754	.0566	.0943
21	.0754	.0566	.0566	.0566	.0566	.0566	.0754
22	.0566	.0377	.0377	.0377	.0377	.0566	.0566
23	.0377	.0189	.0377	.0189	.0189	.0566	.0377
24	.0377	.0377	.0189	.0377	.0189	.0189	.0377
Max	**.1132**	**.1132**	**.1132**	**.0754**	**.0943**	**.0943**	**.0943**
Min	**.0189**	**.0189**	**.0189**	**.0189**	**.0189**	**.0189**	**.0189**
Avg	**.0432**	**.0472**	**.0464**	**.0377**	**.0425**	**.0516**	**.0503**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] BU 5924
Substation No/ Name :- 254080 / 33/ 11 KV Dhondewadi
Feeder No / Name : 203 / 11 KV Dhondewadi AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0655	.081	.0819	.0655	.0848	.0829	.0655
2	.1802	.2915	.0983	.0655	.0848	.2458	.2622
3	.2785	.2915	.0819	.0655	.0848	.2949	.2949
4	.3077	.3077	.0983	.0655	.0848	.3441	.3605
5	.3887	.3563	.1311	.0819	.1526	.426	.4588
6	.664	.583	.1966	.1147	.1526	.5898	.6554
7	.9069	.9878	.2294	.1966	.1696	.7045	1.0322
8	.9878	.9393	.1966	.1966	.1865	.7537	1.065
9	.8097	.9069	.1475	.1475	.1696	.6554	1.0322
10	.1134	.1134	.9503	.7209	1.0004	.1311	.0983
11	.0972	.0983	1.0978	.9995	1.0852	.0983	.0655
12	.0972	.0983	1.2125	1.2887	1.1361	.0983	.0655
13	.0972	.0983	1.1797	1.3927	1.3056	.0819	.0983
14	.0972	.1147	1.1633	1.3435	1.2548	.0819	.0983
15	.0972	.0983	1.2125	1.2431	1.2209	.0983	.1311
16	.0972	.0983	1.2616	1.1105	1.1869	.1147	.1311
17	.0972	.1147	1.1469	.8951	.7291	.1311	.1311
18	.0972	.1638	.1475	.1326	.1017	.1311	.1638
19	.1658	.1475	.1475	.1492	.1357	.1638	.1638
20	.1457	.1475	.1311	.1492	.1017	.1638	.1966
21	.1457	.1311	.1311	.1492	.0848	.1311	.1311
22	.0972	.0983	.0983	.0995	.0678	.0983	.0983
23	.081	.0819	.0819	.0995	.0678	.0819	.0655
24	.0655	.081	.0819	.0655	.0848	.0678	.0655
Max	**.9878**	**.9878**	**1.2616**	**1.3927**	**1.3056**	**.7537**	**1.065**
Min	**.0655**	**.081**	**.0819**	**.0655**	**.0678**	**.0678**	**.0655**
Avg	**.2575**	**.2679**	**.4711**	**.4516**	**.4472**	**.2404**	**.2888**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] BU 5924
Substation No/ Name :- 254080 / 33/ 11 KV Dhondewadi
Feeder No / Name : 204 / 11 KV Dhondewadi Gaothan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0934	.0747	.0747	.112	.0747	.0934
2	.0762	.0934	.0747	.0747	.112	.0747	.0934
3	.0762	.0934	.0747	.0747	.112	.0747	.0934
4	.0953	.0934	.112	.0934	.112	.0747	.112
5	.1143	.112	.1867	.112	.112	.112	.1494
6	.2286	.1867	.3174	.1867	.2427	.1867	.2427
7	.362	.3361	.3547	.2801	.2614	.3361	.3734
8	.2641	.2241	.2427	.2614	.2614	.2241	.2987
9	.1886	.168	.112	.056	.168	.1867	.2241
10	.132	.1494	.112	.0934	.1307	.112	.1494
11	.0943	.1307	.0934	.1307	.112	.112	.112
12	.0943	.0934	.0934	.112	.112	.112	.112
13	.0943	.0747	.112	.112	.0934	.0934	.112
14	.0943	.056	.0747	.112	.0934	.0747	.112
15	.0943	.0934	.0747	.112	.0934	.0747	.112
16	.0943	.0747	.0747	.112	.112	.0747	.112
17	.0943	.0934	.112	.1494	.1307	.112	.112
18	.0934	.1494	.1494	.168	.1494	.1867	.1867
19	.2452	.2427	.1867	.1867	.2614	.2801	.2241
20	.2452	.2241	.2427	.2241	.2241	.2987	.2427
21	.2263	.1867	.2241	.2241	.2054	.2241	.2427
22	.0943	.112	.1494	.1867	.1494	.1867	.1867
23	.0943	.0747	.112	.112	.112	.1307	.112
24	.0934	.0934	.0747	.0747	.112	.0747	.0934
Max	**.362**	**.3361**	**.3547**	**.2801**	**.2614**	**.3361**	**.3734**
Min	**.0762**	**.056**	**.0747**	**.056**	**.0934**	**.0747**	**.0934**
Avg	**.1402**	**.1354**	**.1431**	**.1385**	**.1494**	**.1455**	**.1626**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] **BU 5924**
Substation No/ Name :- 256007 / 110 KV MAYANI
Feeder No / Name : 301 / KATARKHATAV AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 22 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17
HR	Load (MW)
24	.1829
Max	.1829
Min	.1829
Avg	.1829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] BU 5924
Substation No/ Name :- 256007 / 110 KV MAYANI
Feeder No / Name : 302 / PUSESAVALI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17
HR	Load (MW)
24	.2439
Max	.2439
Min	.2439
Avg	.2439

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
VADUJ DIVISION[520]
VADUJ[107] **BU 5924**
Substation No/ Name :- 256007 / 110 KV MAYANI
Feeder No / Name : 303 / MAYANI GAOTHAN **GAOTHAN FEEDER**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
23	1.9052
24	1.2193
Max	1.9052
Min	1.2193
Avg	1.5623

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
MAHABALESHWAR S/DN. 15[835] BU 4835
Substation No/ Name :- 254031 / MAHABALESHWAR
Feeder No / Name : 301 / MAHABALESHWAR **SHEDDABLE URBAN**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002	.7621	1.1317	.9526	.9526	.8383	.8002
2	.7621	.7621	1.0669	.9145	.7922	.7621	.7621
3	.7621	.6859	1.0562	.7621	.8002	.7621	.7545
4	.8383	.6859	1.0669	.7621	.8002	.8002	.7545
5	.9526	.8002	1.1317	.8383	.9145	.8383	.8676
6	.9907	.9526	1.358	.9145	1.1431	.9526	.9431
7	1.3336	1.3336	2.0195	1.2955	1.5242	1.2193	1.3336
8	1.7147	1.6385	2.3388	1.4098	2.037	1.7147	1.6598
9	1.6766	1.7147	1.3336	1.4098	1.6975	1.6004	1.6598
10	1.4861	1.5242	1.3336		1.6975	1.5242	1.4098
11	1.3336	1.3203	1.2955	1.3203	1.6385	1.3957	1.2955
12	1.1431	1.2826	1.1812	1.0185	1.6004	1.2955	1.1431
13	1.1431	1.2071	1.1812	1.1694	1.4098	1.1812	1.105
14	1.0288	.9808	1.1431	1.3336	1.2574	1.1431	
15	.9526	.9431	1.1812	1.3203	1.2193	1.1431	
16	1.0288	1.105	1.2955	1.3957	.9526	1.1812	
17	1.1431	1.094	1.2193	1.3203	1.3336	1.2955	2.2481
18	1.5242	1.5466	1.6004	1.5089	1.6385	1.5623	1.7528
19	1.7528	1.7147	1.8671	2.037	1.9052	1.8107	1.9433
20	1.7147	1.6975	1.7528	1.9052	1.7147	1.6598	1.7909
21	1.5242	1.6004	1.6004	1.773	1.6385	1.5466	1.7528
22	1.3336	1.3717	1.4861	1.6598	1.448	1.3203	1.3717
23	1.105	1.105	1.1431	1.3203	1.2955	1.0669	1.1812
24	.8764	.9145	1.3336	1.0669	1.0562	.9145	.9145
Max	**1.7528**	**1.7147**	**2.3388**	**2.037**	**2.037**	**1.8107**	**2.2481**
Min	**.7621**	**.6859**	**1.0562**	**.7621**	**.7922**	**.7621**	**.7545**
Avg	**1.2050**	**1.1976**	**1.3799**	**1.2786**	**1.3528**	**1.2304**	**1.3069**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
MAHABALESHWAR S/DN. 15[835] BU 4835
Substation No/ Name :- 254031 / MAHABALESHWAR
Feeder No / Name : 302 / Moleshwar **SHEDDABLE URBAN**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0754	.0762	.0762	.0762	.0754
2	.0762	.0762	.0754	.0762	.0762	.0762	.0754
3	.0762	.0762	.0754	.0762	.0762	.0762	.0754
4	.0762	.0762	.0762	.0762	.0762	.0762	.0754
5	.0762	.0762	.0754	.0762	.0762	.0762	.0754
6	.0762	.0762	.0754	.0762	.0762	.1143	.0762
7	.2286	.1905	.1905	.1524	.2263	.1905	.1905
8	.2286	.2667	.2641	.3048	.3018	.2667	.2667
9	.2667	.3048	.2667	.3018	.2641	.3048	.3018
10	.2667	.3048	.1905	.1132	.2286	.2286	.1886
11	.2667	.2263	.1524	.1905	.2286	.2286	.1905
12	.1905	.1905	.1524	.1509	.1905	.1524	.1143
13	.1905	.1905	.1143	.0754	.1905	.0762	.0762
14	.1143	.1524	.0762	.0762	.1524	.0762	.0762
15	.0762	.1905	.0762	.0762	.1524	.0762	.0762
16	.0762	.1905	.1905	.0762	.1143	.1524	.0762
17	.2286	.2286	.1905	.0762	.2286	.1509	.1905
18	.2286	.2987	.2286	.2286	.2667	.1905	.2667
19	.2667	.3395	.2667	.3018	.2286	.2263	.3048
20	.2667	.3048	.2286	.2667	.2286	.2263	.2286
21	.2286	.1886	.1905	.2286	.2286	.1886	.1905
22	.1524	.0762	.1143	.0754	.1905	.1509	.1143
23	.1143	.0754	.0762	.0754	.1143	.0754	.0762
24	.0762	.0762	.0754	.0762	.0754	.0762	.0754
Max	**.2667**	**.3395**	**.2667**	**.3048**	**.3018**	**.3048**	**.3048**
Min	**.0762**	**.0754**	**.0754**	**.0754**	**.0754**	**.0754**	**.0754**
Avg	**.1635**	**.1772**	**.1457**	**.1377**	**.1695**	**.1472**	**.1441**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
MAHABALESHWAR S/DN. 15[835] BU 4835
Substation No/ Name :- 254031 / MAHABALESHWAR
Feeder No / Name : 303 / Metgutad **SHEDDABLE URBAN**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.5716	.6036	.7621	.8002	.6859	.7545
2	.4954	.5716	.6097	.6478	.6859	.6097	.6859
3	.4572	.5335	.5658	.6097	.6097	.5716	.6036
4	.5335	.5335	.5658	.5716	.6097	.5716	.6097
5	.6097	.5716	.5658	.6097	.6859	.5716	.6097
6	.6859	.6097	.6859	.7621	.7621	.5716	.7621
7	.9526	.9145	.9907	1.0288	1.0669	.9526	.9808
8	1.2955	1.1431	1.1431	1.2955	1.2826	1.2193	1.2071
9	1.1812	1.1431	1.0288	1.3336	1.3717	1.1431	1.1694
10	1.1812	1.0669	.9145	1.2955	1.2826	1.1431	1.2193
11	.9907	.4191	.9526	1.2574	1.2193	.9526	.9145
12	.9526	.9054	.9526	.7621	1.0288	.9526	.8764
13	.9526	.9145	.724	1.105	.9526	.9145	.5716
14	.7621	.9054	.5716	.7545	.724	.6478	.5335
15		.7545	.6478	.7545	.724	.724	.6478
16	.381	.7545	.5335	.8002	.7621	.724	.6478
17	.381	.7545	.8002	.8383	.7621	.7621	.6859
18	.8764	.9054	.9526	1.0185	1.0669	.9054	.9145
19		.8002	.9145	1.1317	.9526	1.0185	.9526
20	.9145	.8764	.8002	.9808	.9526	.8676	.8383
21	.8002	.8764	.7621	.9054	.7621	.7545	.7621
22	.724	.724	.7621	.7545	.7621	.679	.724
23	.5716	.8002	.9145	.9431	.7621	.8002	.5716
24	.4954	.4572	.679	.8383	.7545	.7621	.7167
Max	**1.2955**	**1.1431**	**1.1431**	**1.3336**	**1.3717**	**1.2193**	**1.2193**
Min	**.381**	**.4191**	**.5335**	**.5716**	**.6097**	**.5716**	**.5335**
Avg	**.7604**	**.7711**	**.7767**	**.9067**	**.8893**	**.8127**	**.7900**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
MAHABALESHWAR S/DN. 15[835] BU 4835
Substation No/ Name :- 254031 / MAHABALESHWAR
Feeder No / Name : 304 / Venna Lake **SHEDDABLE URBAN**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5716		.6859	.7922	.6097	.6036
2	.5716	.5716		.5716	.679	.5716	.5281
3	.5335	.5716		.5335	.5716	.5335	.5335
4	.5716	.5716		.5335	.5716	.5335	.5335
5	.6097	.6097		.6478	.5716	.5716	.5716
6	.6097	.6859		.8002	.6097	.5716	.6097
7	.8002	.8383		.8383	.9526	.7621	.7545
8	.9145	.9526		.9907	1.1317	.9526	.9145
9	.9526	.9526	.9808	1.1431	1.1812	.9526	.9054
10	.9526	.9526	1.0288	1.094	1.1431	.9526	.9054
11	.8764	.9709	.9526	.9431	1.1431	.9526	.8383
12	.9526	.9431	.9526	.9431	1.0669	.9526	.8002
13	.9145	.9526	.9145	.9526	.9526	.9145	.8002
14	.7621	.8002	.9145	.9431	.9526	.8002	.7621
15	.7621	.7545	.8383	.9054	.8383	.8002	.724
16	.7621	.7922	.8383	.9526	.9526	.7545	.6478
17	.8383	.7545	.8383	.9907	.8383	.7621	.724
18	.9526	1.1431	1.1431	1.094	1.0288	.9431	.9526
19	1.2955	1.2826	1.4098	1.2826	1.2955	1.2574	1.2574
20	1.2955	1.2826	1.3717	1.4098	1.2574	1.2071	1.2574
21	1.2574	1.2323	1.3336	1.4335	1.2574	1.1812	1.105
22	1.0669	1.0288	1.1431	1.2071	1.0669	.9526	.9526
23	.7621		.9145	.8002	.7621	.724	.724
24	.6097	.6097		.7621	.9054	.6478	.6036
Max	**1.2955**	**1.2826**	**1.4098**	**1.4335**	**1.2955**	**1.2574**	**1.2574**
Min	**.5335**	**.5716**	**.8383**	**.5335**	**.5716**	**.5335**	**.5281**
Avg	**.8415**	**.8620**	**1.0383**	**.9358**	**.9384**	**.8276**	**.7920**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
MAHABALESHWAR S/DN. 15[835] BU 4835
Substation No/ Name :- 254031 / MAHABALESHWAR
Feeder No / Name : 305 / Bramha Corp Hotels & Resorts Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS (CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3429	.2667	.3429	.3429	.2667	.2667
2	.2667	.3048	.2667	.3048	.3429	.2667	.2667
3	.2667	.3048	.3048	.3048	.3048	.2286	.3048
4	.3048	.2667	.2667	.3048	.2667	.2667	.3048
5	.3048	.3048	.2667	.3048	.2667	.2667	.2667
6	.3048	.3048	.3048	.3048	.3429	.3048	.2667
7	.3429	.2667	.3048	.3429	.2667	.3429	.2667
8	.3048	.3048	.3048	.4191	.3048	.3048	.3048
9	.3429	.3048	.3429	.4572	.4954	.381	.3429
10	.3429	.381	.3429	.4191	.4572	.3429	.2667
11	.381		.381	.5335	.4191		.3429
12	.3429		.381	.4572	.381		.4191
13	.381		.381	.4954	.4191		.3048
14	.3048		.381	.4954	.4954		.3429
15	.1905		.4191	.5335	.4572		.3429
16	.381		.4191	.4572	.4191		.3429
17	.381		.4191	.3429	.4191		.3429
18	.381		.4572	.4954	.381		.3429
19	.4191		.4954	.5335	.4191		.4191
20	.4191		.5335	.4954	.4572		.4191
21	.381		.4191	.5335	.381		.381
22	.3429		.4191	.5335	.381		.3429
23	.3429		.3429	.4572	.3048		.3048
24	.3048	.3048	.2286	.3429	.381	.2667	.3048
Max	**.4191**	**.381**	**.5335**	**.5335**	**.4954**	**.381**	**.4191**
Min	**.1905**	**.2667**	**.2286**	**.3048**	**.2667**	**.2286**	**.2667**
Avg	**.3350**	**.3083**	**.3604**	**.4255**	**.3794**	**.2944**	**.3254**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
MEDHA[122] BU 0965
Substation No/ Name :- 254032 / MEDHA
Feeder No / Name : 303 / TAPOLA SHEDDABLE URBAN
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1509	.1494	.1132	.1509	.1524	.1132
2	.1143	.1524	.1509	.1143	.1509	.1509	.1132
3	.1143	.1524	.1509	.1143	.1524	.1524	.1143
4	.1509	.1867	.1524	.1143	.1524	.1494	.1143
5	.1509	.1886	.1905	.1132	.2263	.1886	
6	.1867	.2614	.2614	.1509	.2987	.2263	.1509
7	.2957	.3734	.2614	.2614	.3361	.3772	.2218
8	.3292	.3395	.2587	.2614	.3734	.3696	.3326
9	.3018	.3361	.2957	.1829	.2987	.3326	.2587
10	.2241	.2957	.2218	.1109	.3018	.2561	.3292
11	.2263	.2218	.1848	.1109	.2241	.2587	.2957
12	.2286	.1478	.1478	.1867	.1132	.1848	.2195
13	.1886	.1478	.1478	.1867	.1509	.2218	.1829
14	.1886	.1494	.2195	.1867	.2263	.1848	.1448
15	.1867	.1867	.2218	.1867	.1886	.1829	.1829
16	.1886	.1867	.2195	.1867	.2641	.2218	.1829
17	.2641	.2241	.2218	.2241	.3018	.2218	.2195
18	.3395	.2614	.3326	.3361	.381	.3696	.2957
19	.6413	.5975	.5914	.5175	.5281	.5914	.6348
20	.5975	.4854	.5228	.4435	.5658	.5175	.5601
21	.5281	.4108	.3361	.3734	.4481	.4108	.4481
22	.381	.2241	.2263	.2987	.3395	.2614	.2987
23	.2641	.1867	.1509	.1494	.1905	.1886	.1829
24	.1494	.1905	.1494	.1132	.1494		.1132
Max	**.6413**	**.5975**	**.5914**	**.5175**	**.5658**	**.5914**	**.6348**
Min	**.1132**	**.1478**	**.1478**	**.1109**	**.1132**	**.1494**	**.1132**
Avg	**.2647**	**.2524**	**.2402**	**.2099**	**.2714**	**.2683**	**.2483**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
MEDHA[122] BU 0965
Substation No/ Name :- 254032 / MEDHA
Feeder No / Name : 304 / KELGHAR SHEDDABLE URBAN
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1494	.1494	.1524	.1509	.1509	.1509
2	.1524	.1478	.1509	.1524	.1509	.1478	.1524
3	.1143	.1509	.1509	.1524	.1524	.1478	.1524
4	.1509	.1494	.1524	.1524	.2286	.1463	.1509
5	.1886	.1509	.2286	.1509	.2286	.1478	.1886
6	.2241	.2241	.2987	.1886	.2987	.2218	.2241
7	.3734	.4066	.2987	.3734	.3734	.3696	.4066
8	.5121	.5121	.4435	.5228	.5228	.439	.5487
9	.4344	.4706	.4435	.439	.5975	.4435	.5175
10	.4024	.3696	.4435	.2957	.5121	.4481	.5068
11	.362	.3696	.4066	.2218		.4108	.2957
12	.3361	.037	.2957	.2987	.4066	.3734	.3658
13	.2561	.2218	.2926	.2987	.362	.2926	.439
14	.2195	.2987	.2587	.2987	.2587	.2195	.362
15	.2534	.2987	.2957	.2987	.2587	.2926	.2926
16	.2614	.2987	.2926	.0373	.2926	.2957	.3292
17	.4904	.3734	.4066	.0373	.4854	.3696	.4435
18	.5853	.5228	.5175	.6722	.6348	.5121	.5601
19	.6653	.6722		.6653	.6584	.7392	.7095
20	.6219	.6722	.6722	.5914	.679	.6653	.5975
21	.5601	.4481	.4854	.5228	.5853	.5228	.5228
22	.3734	.2987	.3772	.2987	.4108	.3734	.3658
23	.2641	.1494	.2263	.2241	.2641	.2263	.2561
24	.1509	.1509	.1494	.1509	.1494	.1867	.1509
Max	**.6653**	**.6722**	**.6722**	**.6722**	**.679**	**.7392**	**.7095**
Min	**.1143**	**.037**	**.1494**	**.0373**	**.1494**	**.1463**	**.1509**
Avg	**.3377**	**.3143**	**.3233**	**.2999**	**.3766**	**.3393**	**.3621**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
MEDHA[122] BU 0965
Substation No/ Name :- 254032 / MEDHA
Feeder No / Name : 305 / NIZARE SHEDDABLE URBAN
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1132	.112	.1143	.1132	.1132	.1132
2	.1132	.0739	.1132	.1143	.1132	.0754	.1132
3	.1143	.0747	.1132	.1143	.1143	.0747	.0754
4	.1143	.0747	.1143	.1143	.1143	.1109	.1132
5	.1509	.1132	.1905	.1132	.1509	.1132	.1509
6	.1494	.1509	.2241	.1509	.2241	.1509	.1494
7	.2587	.2587	.2614	.2263	.2614	.2614	.2957
8	.2957	.4435	.2587	.2957	.2614	.2587	.3326
9	.2926	.2195	.2587	.2195	.2614	.2218	.2587
10	.2218	.1848	.1848	.1478	.2587	.1848	.2195
11	.1478	.1848	.1478	.1478	.2218	.1848	.1829
12	.1509	.1848	.1463	.1867	.1867	.1478	.1478
13	.1478	.2218	.1463	.1867	.1829	.1829	.1829
14	.1478	.1867	.1829	.1494	.1848	.1848	.1448
15	.1829	.1867	.1478	.1494	.2218	.1478	.1829
16	.1494	.2241	.1478	.1494	.1848	.1829	.1829
17	.1509	.2241	.1478	.1867	.1886	.1848	.2195
18	.2218	.2614	.2957	.2614	.2641	.2587	.2957
19	.4108	.4481	.4108	.4066	.3326	.4066	.4108
20	.3326	.3734	.3326	.3326	.3772	.4066	.3734
21	.3018	.2987	.2614	.2987	.4435	.3361	.3361
22	.2286	.2241	.2263	.2241	.2263	.1867	.2614
23	.1886	.1494	.1509	.1494	.1132	.1509	.1463
24	.1132	.1132	.112	.1132	.112		.1132
Max	**.4108**	**.4481**	**.4108**	**.4066**	**.4435**	**.4066**	**.4108**
Min	**.1132**	**.0739**	**.112**	**.1132**	**.112**	**.0747**	**.0754**
Avg	**.1958**	**.2079**	**.1953**	**.1897**	**.2131**	**.1968**	**.2084**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
MEDHA[122] BU 0965
Substation No/ Name :- 254032 / MEDHA
Feeder No / Name : 306 / BHANANG SHEDDABLE URBAN
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1509	.1494	.1509	.1509	.1905	.1886
2	.1132	.1509	.1509	.1524	.1509	.1524	.1886
3	.1143	.1494	.1509	.1143	.1524	.1509	.1509
4	.1905	.1494	.1524	.1524	.2286	.1478	.1509
5	.2263	.1524	.2286	.1524	.3018	.1886	.1867
6	.2614	.2263	.2987	.1905	.3361	.2263	.2614
7	.4066	.3696	.3734	.3734	.3361	.4108	.4435
8	.4066	.4435	.4435	.4108	.4481	.4805	.4805
9	.439	.4024	.4066	.2926	.4108	.4024	.4805
10	.4066	.4066	.3696	.3696	.4066	.4066	.439
11	.3696	.3326	.4066	.4066	.4805	.4066	.4755
12	.3395	.3326	.2926	.3361	.3361	.4066	.439
13	.3326	.2957	.1478	.3361	.4024	.4024	.2926
14	.3326	.2987	.1478	.2987	.3326	.4024	.2896
15	.2926	.2987	.2957	.3734	.4066	.4066	.3326
16	.2987	.2614	.2926	.3734	.3696	.4024	.3292
17	.4527	.2987	.3326	.3734	.3361	.4066	.3292
18	.3696	.3734	.3696	.4108	.4527	.4066	.3696
19	.4854	.4481		.4805	.3696	.5544	.5228
20	.4066	.4108	.4066	.4066	.415	.5175	.4481
21	.3772	.3734	.3361	.3734	.3696	.4108	.3734
22	.3048	.2614	.2641	.2987	.3018	.3361	.2987
23	.2263	.1867	.1886	.1494	.1886	.1886	.2195
24	.1886	.1886	.1494	.1509	.1494		
Max	**.4854**	**.4481**	**.4435**	**.4805**	**.4805**	**.5544**	**.5228**
Min	**.1132**	**.1494**	**.1478**	**.1143**	**.1494**	**.1478**	**.1509**
Avg	**.3122**	**.2901**	**.2763**	**.2970**	**.3264**	**.3480**	**.3344**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
MEDHA[122] BU 0965
Substation No/ Name :- 254050 / TAPOLA
Feeder No / Name : 301 / GOGAVE SHEDDABLE URBAN
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0686	.0381		.061	.0686	.0724
2	.0724	.061	.0381	.0457	.061	.0648	.0648
3	.0686	.0495	.0686	.0419	.0572	.0572	.061
4	.0724	.061	.0724	.0495	.0572	.0686	.0724
5	.08	.0762	.0762	.0572	.0762	.08	.0762
6	.0876	.0724	.0838	.061	.0838	.08	.08
7	.1029	.1067	.1067	.0648	.0914	.1257	.1105
8	.1181	.1257	.1486	.1181	.1448	.1524	.1219
9	.1257	.1181	.0648	.0724	.1524	.1448	.141
10	.1105	.0953	.1257	.0914	.1448	.1029	.141
11	.0914	.0914	.08	.0686	.0381	.0762	.1372
12	.0914	.0648	.061	.061	.0381	.1029	.1219
13	.0724	.0686	.0724	.0572	.0381	.1219	.0914
14	.0762	.0724	.08	.061	.0381	.1257	.0991
15	.0838	.08	.08	.0686		.0838	.0991
16	.0648	.08	.0762	.0762	.0686	.0953	.0914
17	.0876	.1067	.0648	.1181	.0914	.1257	.1029
18	.1372	.1143	.08	.1029	.16	.1372	.1219
19	.2058	.2058	.221	.1981	.1638	.1867	.1867
20	.1753	.1753	.1791	.1791	.1524	.1524	.1524
21	.1524	.1448	.1334	.1372	.1219	.1372	.1448
22	.1181	.0914	.0953	.1143	.1029	.0991	.1296
23	.0762	.061	.0686	.0953	.0762	.08	.0724
24	.0838	.0762	.0381	.0572	.0724	.0648	.08
Max	**.2058**	**.2058**	**.221**	**.1981**	**.1638**	**.1867**	**.1867**
Min	**.0648**	**.0495**	**.0381**	**.0419**	**.0381**	**.0572**	**.061**
Avg	**.1013**	**.0945**	**.0897**	**.0868**	**.0909**	**.1056**	**.1072**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
MEDHA[122] BU 0965
Substation No/ Name :- 254050 / TAPOLA
Feeder No / Name : 302 / SHINDI SHEDDABLE URBAN
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724		.0724	.0572	.0686	.0762	.0724
2	.0648	.0572	.0686	.0495	.0686	.0686	.0648
3	.0686	.0457	.061	.0457	.0648	.061	.0686
4	.0762	.0648	.0724	.0533	.061	.0648	.0724
5	.0876		.0876	.0572	.0838	.0724	.0953
6	.0953	.0953	.1067	.061	.0953	.0914	.1105
7	.1181	.1105	.1067	.0838	.1105	.1143	.1143
8	.1143	.1143		.1105	.1296		.1067
9	.1257	.0953	.0914	.0762	.1105	.1067	.1181
10	.0876	.1067	.0762	.0838	.1029	.1105	.1067
11	.08	.0762			.0762	.0953	.08
12	.0724	.0762	.08	.0838	.0724	.08	.0381
13	.08	.0724	.0686	.0838	.0953	.08	.0381
14	.0724	.0876	.0648	.0762	.0838	.08	.0381
15	.0724	.0914	.0648	.0914		.0762	.0381
16	.0648	.0876	.0724	.0724	.0838	.0762	.0381
17	.0991	.0914	.0838	.0953	.0838	.08	.0381
18	.1105	.1143	.1029	.1219	.1257	.1029	.0381
19	.2515	.2286	.2058	.2286	.2324	.2324	.2553
20	.2324	.2134	.1905	.2058	.2058	.1981	.2439
21	.1981	.1677	.1486	.1677	.1753	.1791	.1867
22	.1486	.1181	.1105	.1257	.1296	.1143	.1029
23	.0991	.0838	.0838	.0876	.0914	.1067	.1638
24	.0762	.0724		.0686	.08	.08	.0648
Max	**.2515**	**.2286**	**.2058**	**.2286**	**.2324**	**.2324**	**.2553**
Min	**.0648**	**.0457**	**.061**	**.0457**	**.061**	**.061**	**.0381**
Avg	**.1070**	**.1032**	**.0962**	**.0951**	**.1057**	**.1020**	**.0956**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
MEDHA[122] BU 0965
Substation No/ Name :- 254057 / SONGAON
Feeder No / Name : 301 / ANEWADI GAONTHAN GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.2195	.2926	.3429	.2286	.3292	.3292
2	.2926	.2195	.2926	.3048	.1905	.3292	.2926
3	.2926	.2195	.3292	.3048	.1905	.3292	.2926
4	.3292	.2195	.3658	.2667	.1905	.3292	.3292
5	.4024	.2195	.4024	.3048	.3048	.3292	.4024
6	.5121	.439	.5121	.4481	.4572	.439	.5121
7	.6219	.6584	.6584	.6584	.6283	.6379	.6219
8	.5853	.6584	.6584	.6584	.5914	.6584	.6219
9	.5487	.5487	.4755	.6219	.6089	.6219	.6219
10	.5014	.5014	.4298	.5373	.5373	.6089	.5731
11	.3582	.4656	.4298	.4656	.5014	.5373	
12	.3582	.394	.3224	.394	.4656	.4298	
13	.2865	.3582		.3224	.4298	.4656	
14	.3224	.3582		.3582	.4656	.4298	
15	.3582	.3582	.394	.3224	.4656	.4298	
16	.2865	.3582	.3224	.394	.4298	.4656	
17	.3582	.3582	.4298	.4298	.5014	.3582	
18	.5121	.5121	.5914	.5544	.6584	.6219	
19	.6584	.5853	.8131	.7682	.6584	.7316	
20	.6584	.695	.7023	.7682	.695	.6584	
21	.6584	.6219	.6283	.6653	.5487	.6584	.6283
22	.4755	.5121	.4854	.4854	.439	.4755	.5601
23	.3292	.3292	.4191	.3734	.3658	.3658	.4481
24	.2926	.2195	.2926	.3429	.3048	.3292	.2926
Max	**.6584**	**.695**	**.8131**	**.7682**	**.695**	**.7316**	**.6283**
Min	**.2195**	**.2195**	**.2926**	**.2667**	**.1905**	**.3292**	**.2926**
Avg	**.4258**	**.4179**	**.4658**	**.4622**	**.4524**	**.4820**	**.4661**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
MEDHA[122] BU 0965
Substation No/ Name :- 254057 / SONGAON
Feeder No / Name : 302 / ANEWADI AGRICULTURE SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.1097	.1029	.0716	.1075	1.134	1.166
2	.5144	.1097	.1029	.0716	.1075	1.134	1.2346
3	.5487	.1097	.1029	.0716	.1075	1.134	1.2346
4	.5487	.1097	.1029	.0716	.1075	1.134	1.2689
5	.6173	.1097	.1029	.0716	.1075	1.1706	1.2887
6	.7545	.1829	.1029	.0716	.1433	1.3577	1.3077
7	.1029	.1829	.1715	.1433	.2149	.2263	.2058
8	.9602	1.2803	1.3032	1.4685	.1791	.1829	.1715
9	1.2548	1.4685	1.4746		.1791	.1463	.1372
10	1.3904	1.6118	1.7193	1.7193		.1433	.1433
11	1.4685	1.6476	1.8267	1.7551	.1075	.1075	
12	1.5043	1.6834		1.8267	.1075	.1433	
13	1.3611	1.4685		1.8625	.1433	.1433	
14	1.3969	1.6834	1.7551	1.7909	.1433	.1075	
15	1.5043	1.0387	2.0774	1.7551	.1433	.1075	
16	.1075	1.2536	1.2894		.1075	.1433	.1075
17	.1075	.1075	.1075		.1075	.1433	.1791
18	.1463	.1029	.1143	.1524	.1097	.1372	
19	.1463	.1029	.1524	.1905	.1886	.1372	.2286
20	.1463	.1372	.1524	.1905	.1829	.1715	.1905
21	.1509	.1372	.1524	.1524	.1886	.1715	.1905
22	.1463	.1372	.1143	.1524	.1886	.1372	.1905
23	.1509	.1029	.0762	.1143	1.0608	1.0974	.9877
24	.5144	.1097	.0686	.0716	.1075	1.134	1.166
Max	**1.5043**	**1.6834**	**2.0774**	**1.8625**	**1.0608**	**1.3577**	**1.3077**
Min	**.1029**	**.1029**	**.0686**	**.0716**	**.1075**	**.1075**	**.1075**
Avg	**.6691**	**.6245**	**.5988**	**.6560**	**.1800**	**.4852**	**.6333**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
MEDHA[122] BU 0965
Substation No/ Name :- 254057 / SONGAON
Feeder No / Name : 303 / Kudal Gaonthan GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5853	.5487	.5121	.4805	.5014	.5487	.5121
2	.5853	.5487	.5121	.4805	.4656	.5487	.5853
3	.6584	.5487	.5853	.4481	.4656	.5487	.6584
4	.6584	.5487	.6584	.5121	.4656	.5487	.7316
5	.8048	.7316	.8048	.5853	.5731	.6219	.8779
6	1.0242	.9511	1.0242	.8596	.8954	.9145	1.0242
7	1.39	1.2803	1.3169	1.2178	1.2894	1.2437	1.2803
8	1.39	1.3169	1.39	1.2536	1.3611	1.2803	1.3535
9	1.2803		1.2803	1.2536	1.3253	1.2803	1.134
10	1.1706	1.1104	1.1104	1.2536	1.2536	1.2894	1.0387
11	1.0387	1.0745	.6447	.788	1.182	1.2536	
12	1.0029	.9313	.7522	.9313	1.0029	.8954	
13	1.0029	1.0029	.8596	.9313	1.0387	.8596	
14	.7522	.9313	.9313		.9671	.9313	.8596
15	.8954	.8954	1.0387	1.0387	.9671	.9313	.9671
16	.8954	1.0387	.8596	1.0387	1.0029	1.0387	.9671
17	1.0745	1.0029	1.1104	1.182	.8596	1.0745	.7522
18	1.2071	1.1706	1.3466	1.382	1.3535	1.2071	.8596
19	1.2437	1.2803	1.4723	1.5424	1.3535	1.39	1.5947
20	1.2803	1.39	1.3672	1.5074	1.2803	1.39	1.448
21	1.2071	1.2437	1.182	1.2308	1.0974	1.1706	1.3394
22	.9511	.9877	.9774	.9671	1.0242	.9145	1.0608
23	.7316	.6219	.6584	.695	.6219	.6219	.8131
24	.6219	.5853	.5487	.5175	.5373	.5487	.5487
Max	**1.39**	**1.39**	**1.4723**	**1.5424**	**1.3611**	**1.39**	**1.5947**
Min	**.5853**	**.5487**	**.5121**	**.4481**	**.4656**	**.5487**	**.5121**
Avg	**.9772**	**.9453**	**.9560**	**.9607**	**.9535**	**.9605**	**.9717**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
MEDHA[122] BU 0965
Substation No/ Name :- 254057 / SONGAON
Feeder No / Name : 304 / KUDAL AGRICULTURE SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.9511	1.0288	.8238	.0716	.0754	.0686
2	.0686	.9511	1.0288	.7164	.0716	.0732	.0686
3	.0686	.9511	1.0631	.7164	.0716	.0732	.0686
4	.0686	.9511	1.0631	.7164	.0716	.0732	.0686
5	.0686	.9511	1.0974	.788	.0716	.0732	.0686
6	.1029	.9511	1.0974	.9671	.0716	.0732	.0686
7	.1029	.0732	.1029	.0716	.0716	.0754	.0686
8	.1029	.0754	.1029	1.0745	1.0974	1.9022	2.1948
9	.1029	.0754	.0686	1.5043	1.9342	2.4874	2.4691
10	.1029	.0716	.0716	1.8983	1.8625	2.5072	.7164
11	.0716	.0716	.0716	2.0774	2.5072	1.3611	
12	.0716	.0716		2.0774	2.6505	1.7909	
13	.0716	.0716		2.0774	2.8654	2.6505	
14	.0716	.0716			2.8654	2.6505	2.6505
15	.0716	.0716	.0716	2.1491	2.6863	2.758	3.0445
16	.0716	.0716	.0716	2.0774	.0716	.0716	2.7938
17	.0716	.0716	.0716	.0716	.0716	.0716	2.5072
18	.0754	.0686	.0762	.0762	.0732	.0686	.0762
19	.0732	.0686	.0762	.0762	.0754	.0686	.0762
20	.0732	.1029	.0762	.0762	.0732	.0686	.0762
21	.0754	.1029	.0762	.0762		.1029	.0762
22	.0754	.1029	.0762	.0762	.0754	.0686	.0762
23	.7316	1.0288	.8048	.0762	.0754	.0686	.0762
24	.0686	.9511	1.0288	.9313	.0716	.0754	.0686
Max	**.7316**	**1.0288**	**1.0974**	**2.1491**	**2.8654**	**2.758**	**3.0445**
Min	**.0686**	**.0686**	**.0686**	**.0716**	**.0716**	**.0686**	**.0686**
Avg	**.1055**	**.3721**	**.4393**	**.9215**	**.8503**	**.8037**	**.8277**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
MEDHA[122] BU 0965
Substation No/ Name :- 254057 / SONGAON
Feeder No / Name : 305 / KARHAR SHEDDABLE URBAN
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.1829	.2195	.2286	.1905	.1829	.2195
2	.1829	.1829	.2195	.1905	.1905	.1829	.1829
3	.2195	.1829	.2926	.1905	.1905	.1829	.2195
4	.2926	.1829	.3292	.1905	.1905	.1829	.3292
5	.3292	.3292	.3658	.2667	.2667	.1829	.4024
6	.3658	.3292	.439	.3429	.381	.3658	.5121
7	.4024	.3292	.4755	.5175	.4854	.5487	.5487
8	.5121	.5487	.5121	.5544	.6348	.6584	.6219
9	.5121	.5853	.4755	.5175	.6089	.7522	.6219
10	.5487	.5731	.4298	.5014	.6447	.7522	.6447
11	.5014	.5373	.4298	.5731	.6805	.6447	
12	.4344	.5373	.3582	.5014	.7522	.7522	
13	.4656		.394	.4656	.6805	.6447	
14	.4298	.4656	.4656	.4656	.6447	.5731	.5731
15	.4656	.4298	.4656	.5014		.6805	
16	.4298	.5373	.4298	.6805	.5014	.6805	.6805
17	.5373	.5731	.6089	.4298	.6805	.8238	.7164
18	.5853	.7316	.8048	.9671	.8413	.9145	.9774
19	.6584	.6584	.8413	.8954	.7682	.9145	.8779
20	.7316	.6219	.7392	.7316		.7682	.7023
21		.5121	.6653	.6219	.7167	.6219	.7023
22	.4755	.439	.4108	.4854	.5487	.4755	.5975
23	.3658	.2926	.3048	.3734	.3292	.3292	.3772
24	.2195	.1829	.1829	.2667	.3048	.3292	.2195
Max	**.7316**	**.7316**	**.8413**	**.9671**	**.8413**	**.9145**	**.9774**
Min	**.1829**	**.1829**	**.1829**	**.1905**	**.1905**	**.1829**	**.1829**
Avg	**.4298**	**.4324**	**.4525**	**.4775**	**.5106**	**.5477**	**.5363**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
PACHGANI[120] BU 0973
Substation No/ Name :- 254049 / 33/22 KV PANCHGANI
Feeder No / Name : 301 / 22 KV BHILAR SHEDDABLE RURAL
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.4801	.4024	.415	.4854	.4527	.415
2	.3326	.4801	.4108	.415	.4024	.3772	.3772
3	.3326	.4458	.415	.415	.4066	.3772	.3772
4	.3326	.4458	.415	.4191	.4066	.3772	.3772
5	.3696	.4458	.4108	.4527	.4066	.3734	.4191
6	.4854	.7545	.5853	.6413	.4854	.4755	.4904
7	.9979	.9945	1.1706	1.307	1.1706	1.0974	1.1949
8	1.3756	1.6461	1.6095	1.8484	1.701	1.5364	1.7177
9	1.701	1.9071	1.858	2.0911	1.8229	1.7193	1.9044
10	1.2346	1.7528	1.0288	1.7924	1.8861	1.6991	1.134
11	1.2003	1.5775	.8916	1.6827	1.7551	1.4563	1.39
12	1.2003	1.3321	.823	1.4632	1.643	1.4022	1.3611
13	1.0288	1.2971	.5487	1.39	1.5684	.6024	1.3535
14	1.0288	1.1218		1.2803	.6722	.8063	.7316
15	.8573			1.2757	1.2323	.7712	.7316
16	.9945		1.4403	1.39	1.4563	.7888	
17		1.4746	1.9239	1.0277	1.8107	1.3032	1.5043
18	1.406	1.8656	1.8298	1.595	1.6827	1.4712	1.6118
19	1.3375	1.4632	1.4563	1.5565	1.3112	1.3443	1.448
20	1.166	1.2437	1.2696	1.3676	1.182	1.1949	1.2071
21	.9945	1.0974	1.0082	1.0082	.9774	.924	.961
22	.8573	.7316	.7842	.8589	.7682	.7545	.7762
23	.6516	.5544	.5281	.6348	.5281	.4904	.4108
24	.4115	.5144	.4481	.4904	.5228	.4527	.415
Max	**1.701**	**1.9071**	**1.9239**	**2.0911**	**1.8861**	**1.7193**	**1.9044**
Min	**.3326**	**.4458**	**.4024**	**.415**	**.4024**	**.3734**	**.3772**
Avg	**.8987**	**1.0739**	**.9663**	**1.1174**	**1.0952**	**.9270**	**.9700**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
PACHGANI[120] BU 0973
Substation No/ Name :- 254049 / 33/22 KV PANCHGANI
Feeder No / Name : 302 / PACHGANI CITY SHEDDABLE URBAN
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.9602	.7975	.8676	.924	.7712	.8676
2	.7468	.8916	.8413	.8299	.7762	.7011	.8299
3	.7468	.8573	.8413	.8299	.7762	.7316	.7545
4	.7392	.8573	.815	.8383	.8131	.7087	.7545
5	.7762	.8573	.8413	.8676	.924	.7682	.7922
6	1.0349	1.0631	1.0974	1.1317	1.0456	1.0387	1.1694
7	1.4335	1.3032	1.4998	1.6221	1.3817	1.5729	1.7147
8	1.5684	1.3375	1.4632	1.7177	1.6057	1.448	1.6057
9	1.4937	1.4563	1.5364	1.6057	1.531	1.39	1.531
10	1.5775	1.3535	1.5432	1.5729	1.6804	1.3306	
11	1.4746	1.39	1.3717	1.3169	1.531	1.3169	
12	1.4746	1.2048	1.3032	1.3169	1.4335	1.2437	
13	1.3375	1.1104	1.2346	1.1462	1.2696	1.1584	
14	.9259	.9774	1.166	1.1706	1.1203	1.0136	
15	1.2003	1.0745	.9945	1.1706	1.1458	1.0974	1.0745
16	1.166	1.0745	1.0631	1.134	1.1694	1.1104	
17	1.2689	1.0631	1.2323	1.2437	1.1949	1.1104	1.2437
18	1.406	1.3169	1.4563	1.3466	1.4998	1.2323	1.6118
19	1.7147	1.6095	1.7177	1.6289	1.6301	1.4563	1.7013
20	1.6118	1.4632	1.6221	1.6651	1.5402	1.6057	1.6834
21	1.5432	1.39	1.5089	1.448	1.3969	1.4712	1.5043
22	1.406	1.2071	1.3203	1.3611	1.2757	1.2696	1.3253
23	1.2346	1.0242	1.1949	1.2048	1.0631	1.0185	1.0867
24	.8573	1.0631	.7888	.9431	.9362	.8764	.9465
Max	**1.7147**	**1.6095**	**1.7177**	**1.7177**	**1.6804**	**1.6057**	**1.7147**
Min	**.7392**	**.8573**	**.7888**	**.8299**	**.7762**	**.7011**	**.7545**
Avg	**1.2286**	**1.1628**	**1.2188**	**1.2492**	**1.2360**	**1.1434**	**1.2332**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
PACHGANI[120] BU 0973
Substation No/ Name :- 254049 / 33/22 KV PANCHGANI
Feeder No / Name : 303 / WATER SUPPLY SHEDDABLE RURAL
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.1029	.112	.1132	.0739	.1132	.1143
2	.0747	.1029	.112	.0754	.0747	.0754	.0754
3	.0754	.0686	.0754	.0762	.0754	.0754	.0754
4	.0754	.0686	.0732	.0754	.0747	.0754	.0762
5	.0747	.0686	.0732	.1132	.112	.0747	.1132
6	.1509	.1715	.2218	.2241	.112	.2957	.2614
7	.3018	.2401	.2896	.3361	.3395	.3658	.3734
8	.3696	.2743	.362	.4108	.4481	.4024	.3734
9	.3696	.2957	.3292	.4527	.3658	.3658	.3696
10	.2058	.2987	.2743	.3582	.3429	.3326	.2195
11	.2058	.2614	.2401	.3155	.3361	.2926	.2195
12	.1715	.2195	.2058	.3292	.3361	.2241	.1829
13	.1715	.2454	.2058	.2561	.3326	.2614	.181
14	.2058	.2172	.1715	.2126	.2641	.1867	.1848
15	.1715	.2507	.2058	.2481	.2614	.2614	.1829
16	.1372	.2507	.2058	.3292	.2987	.2534	
17	.2058	.3086	.3361	.3506	.3361	.3155	.2561
18	.3086	.3292	.3772	.3506	.3658	.3361	.4115
19	.2058	.3292	.3734	.3734	.3189	.3772	.3361
20	.2743	.3658	.3361	.3395	.3155	.2987	.3395
21	.2401	.2926	.2614	.3018	.2835	.2614	.2641
22	.2058	.2241	.2263	.2641	.2172	.2263	.2263
23	.1029	.1463	.1494	.1867	.3429	.1509	.112
24	.1029	.1029	.1097	.1132	.1132	.112	.1143
Max	**.3696**	**.3658**	**.3772**	**.4527**	**.4481**	**.4024**	**.4115**
Min	**.0747**	**.0686**	**.0732**	**.0754**	**.0739**	**.0747**	**.0754**
Avg	**.1868**	**.2181**	**.2220**	**.2586**	**.2559**	**.2389**	**.2201**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
WAI[121] **BU 0957**
Substation No/ Name :- 254018 / 33/22 KV VELE S/STN
Feeder No / Name : 301 / SURUR AG **SEPARATED AG FEEDERS HAVING SPECIAL**
Feeder KV- 22 / OUTGOING **DESIGN TRANSFORMER**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3201	.3086	.0377	.0377	.0377	.0377	.4481
2	.3048	.3086	.0377	.0377	.0377	.0377	.4481
3	.3163	.3048	.0377	.0377	.0377	.0377	.4641
4	.4428	.3163	.0377	.0377	.0377	.0377	.4973
5	.6173	.3521	.0377	.0377	.0377	.0377	.5506
6	.679	.3887	.0377	.0377	.0377	.0377	.6554
7	.0377	.0377	.0377	.0377	.0377	.0377	.0377
8	.0377	.759	.5693	1.0364	1.1012	.0754	.0377
9	.0377	.5182	1.2071	1.4586	1.2308	.0754	.0377
10	.0377	.7125	1.2018	1.5074	1.5729	.0377	
11	.0377	1.1142	1.3443	1.6244	1.6385	.0377	
12	.0377	1.0608		1.4586	1.4419	.0377	
13	.0377	1.2597	1.1728	1.4403	1.5546	.0377	.0377
14	.0377	1.1797	.4534	1.6712	1.704	.0377	.0377
15	.0377	1.1142	1.326	1.5729	1.6194	.0377	.0377
16	.0377	.0377	.0377	.0377	.0377	.0377	.0377
17	.0377	.0377	.0377	.0377	.0377	.0377	
18	.0377	.0377	.0377	.0754	.0377	.0377	
19	.0377	.0754	.0377	.0377	.0754	.0377	.0377
20	.0377	.0754	.0377	.0754	.0754	.0377	.0377
21	.0377	.0754	.0377	.0377	.0754	.0377	
22	.0377	.0377	.0377	.0377	.0377	.0377	
23	.3048	.0377	.0377	.0377	.0377	.463	.4374
24	.3086	.3125	.0377	.0377	.0377	.0377	.4801
Max	**.679**	**1.2597**	**1.3443**	**1.6712**	**1.704**	**.463**	**.6554**
Min	**.0377**	**.0377**	**.0377**	**.0377**	**.0377**	**.0377**	**.0377**
Avg	**.1624**	**.4359**	**.3425**	**.5187**	**.5242**	**.0586**	**.2541**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
WAI[121] BU 0957
Substation No/ Name :- 254018 / 33/22 KV VELE S/STN
Feeder No / Name : 302 / NEW KENJAL AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	.0377	.3163	.4428	.4999	.0377
2	.0377	.0377	.0377	.3086	.4481	.506	.0377
3	.0377	.0377	.0377	.3125	.4588	.4999	.0377
4	.0377	.0377	.0377	.3201	.5182	.506	.0377
5	.0377	.0377	.0377	.3887	.5506	.5121	.0377
6	.0377	.0377	.0377	.5898	.6882	.5898	.0377
7	.0377	.0377	.0377	.0377	.0377	.0377	.0377
8	.5898	.8223	.0377	.0377	.0377	1.2071	1.2452
9	.8855	1.166	.0377	.0377	.0377	1.5729	1.1336
10	.9488	.4534	.0377	.0377	.0377	1.6385	
11	1.1142	1.4419	.0377	.0377	.0377	1.6057	
12	.9175	1.6575	.0377	.0377	.0377	1.4586	
13	1.166	.9945	.0377	.0377	.0377	1.6712	1.2308
14	1.2163	1.5729	.0377	.0377	.0377	1.6221	1.3443
15	1.3108	1.704	.0377	.0377	.0377	1.6221	1.4419
16	.0377	.0377	.0377	.0377	.0377	.0377	1.3443
17	.0377	.0377	.0377	.0377	.0377	.0377	.0377
18	.0377	.0377	.0377	.0754	.0377	.0377	.0377
19	.0377	.0377	.0754	.0377	.0377	.0377	.0377
20	.0377	.0754	.0754	.0377	.0377	.0377	.0377
21	.0377	.0754	.0754	.0377	.0377	.0377	.0377
22	.0377	.0377	.0754	.0377	.0377	.0377	.0377
23	.0377	.0377	.3086	.4012	.4268	.0377	.0377
24	.0377	.0377	.0377	.3125	.4428	.4938	.0377
Max	**1.3108**	**1.704**	**.3086**	**.5898**	**.6882**	**1.6712**	**1.4419**
Min	**.0377**	**.0377**	**.0377**	**.0377**	**.0377**	**.0377**	**.0377**
Avg	**.3647**	**.4371**	**.0553**	**.1496**	**.1908**	**.6810**	**.3955**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
WAI[121] **BU 0957**
Substation No/ Name :- 254018 / 33/22 KV VELE S/STN
Feeder No / Name : 303 / NEW KENJAL GAOTHAN **GAOTHAN FEEDER**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1509	.1509	.1509	.1509	.1886	.1509
2	.1509	.1509	.1509	.1509	.1509	.1509	.1509
3	.1509	.1509	.1509	.1509	.1509	.1509	.1509
4	.1509	.1886	.1509	.1886	.1509	.1886	.1886
5	.2263	.2263	.1886	.1886	.1886	.2263	.2263
6	.3018	.3018	.2641	.2263	.2263	.2641	.2641
7	.3395	.3018	.3395	.3018	.3395	.3395	.3018
8	.3018	.3018	.2641	.3018	.3018	.3018	.3395
9	.4527	.415	.415	.3772	.3395	.4904	.2641
10	.3018	.3772	.415	.3772	.3395	.415	
11	.3772	.3395	.3018	.3772	.3772	.3018	
12	.3395	.3395	.2263	.3018	.3018	.2641	
13	.1509	.1509	.1509	.1886	.2641	.1509	.1509
14	.1509	.3018	.1509	.2641	.2263	.3018	.1509
15	.2263	.3018	.3018	.3395	.3395	.2641	.1509
16	.1886	.2641	.3018	.3395	.1509	.2641	.1509
17	.3395	.3395	.1509	.2263	.3018	.2641	.1509
18	.2263	.2641	.2641	.2263	.2263	.3018	.2263
19	.3395	.3395	.3395	.3395	.3395	.3395	.3772
20	.3395	.3395	.3395	.3395	.3395	.3395	.3395
21	.3018	.3018	.3395	.3018	.3018	.3018	.3018
22	.2641	.2641	.2641	.2641	.2641	.2641	.2641
23	.1886	.1509	.1886	.1886	.1886	.1886	.1886
24	.1509	.1886	.1509	.1886	.1886	.1886	.1886
Max	**.4527**	**.415**	**.415**	**.3772**	**.3772**	**.4904**	**.3772**
Min	**.1509**	**.1509**	**.1509**	**.1509**	**.1509**	**.1509**	**.1509**
Avg	**.2546**	**.2688**	**.2484**	**.2625**	**.2562**	**.2688**	**.2227**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
WAI[121] BU 0957
Substation No/ Name :- 254018 / 33/22 KV VELE S/STN
Feeder No / Name : 304 / SURUR GAOTHAN GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1886	.1509	.1509	.1886	.1886
2	.1509	.1886	.1509	.1509	.1509	.1509	.1509
3	.1509	.1886	.1509	.1509	.1509	.1509	.1509
4	.1509	.1886	.1886	.1509	.1509	.1886	.1886
5	.1886	.2263	.2263	.1886	.1886	.2263	.2263
6	.2641	.2641	.3018	.2263	.2263	.2641	.2641
7	.3772	.3018	.3772	.3772	.3018	.3772	.3395
8	.415	.415	.415	.415	.4527	.415	.415
9	.3018	.3018	.3395	.3772	.3772	.3772	.3018
10	.3018	.3395	.3018	.3772	.3772	.3772	
11	.3018	.3018	.3018	.3018	.3395	.3395	
12	.3018	.3018	.3018	.2641	.3018	.2641	
13	.1886	.3018	.2641	.2641	.3018	.2641	.3395
14	.1886	.2641	.2641	.2641	.3018	.2641	.3018
15	.2263	.2263	.2641	.2263	.3018	.3018	.3018
16	.2641	.2641	.2641	.3018	.2641	.3018	.2641
17	.2641	.3018	.2641	.3018	.2641	.3018	.2641
18	.3772	.3395	.3395	.3395	.3395	.3772	.3395
19	.4527	.4527	.4904	.4904	.4904		.4904
20	.415	.4904	.4527	.4904	.4527	.4527	.4527
21	.415	.3772	.415	.415	.415	.4527	.4527
22	.3395	.3395	.3395	.3395	.3395	.3772	.3772
23	.2641	.2641	.2641	.3018	.3018	.3018	.2641
24	.2263	.2263	.1886	.1886	.2263	.1886	.2263
Max	**.4527**	**.4904**	**.4904**	**.4904**	**.4904**	**.4527**	**.4904**
Min	**.1509**	**.1886**	**.1509**	**.1509**	**.1509**	**.1509**	**.1509**
Avg	**.2798**	**.2939**	**.2939**	**.2939**	**.2986**	**.3001**	**.3000**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
WAI[121] BU 0957
Substation No/ Name :- 254018 / 33/22 KV VELE S/STN
Feeder No / Name : 305 / OZARDE GAOTHAN GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1886	.1886	.1886	.2263	.2263
2	.1509	.1886	.1886	.1886	.1886	.1886	.1886
3	.1509	.1886	.1886	.1886	.1886	.1886	.1886
4	.2641	.2263	.1886	.2263	.1886	.2263	.1886
5	.3772	.3395	.2641	.3395	.2641	.3395	.3018
6	.5281	.4527	.415	.415	.415	.4527	.4904
7	.5658	.6036	.6413	.5658	.6413	.679	.679
8	.6036	.6413		.6413	.6413	.6413	.6413
9	.4904	.4904	.2641	.5281	.5281	.4904	.5281
10	.415	.415	.2263	.3772	.4904	.4527	
11	.4527	.415	.3018	.3018	.415	.3772	
12	.3395	.3395	.2641	.2263	.3772	.3395	
13	.3018	.3395	.2263	.3018	.3772	.3772	.4527
14	.3395	.3018		.3018	.415	.3395	.415
15	.3772	.3018	.415	.3018	.3772	.3395	.415
16	.415	.3772	.415	.3018	.4527	.3772	.415
17	.4527	.4527	.3772	.3772	.415	.415	.4527
18	.5281	.5658	.4904	.4904	.4904	.5658	.5281
19	.6413	.679	.5658	.679	.6413	.679	.679
20	.5658	.6036	.5281	.5658	.6036	.6036	.5658
21	.4904	.4527	.4904	.4904	.4904	.5281	.5658
22	.3772	.3395	.415	.3772	.415	.3772	.4527
23	.2263	.2263	.3018	.2263	.2641	.2641	.3018
24	.1886	.1886	.1886	.2263	.2263	.2263	.2263
Max	**.6413**	**.679**	**.6413**	**.679**	**.6413**	**.679**	**.679**
Min	**.1509**	**.1886**	**.1886**	**.1886**	**.1886**	**.1886**	**.1886**
Avg	**.3929**	**.3882**	**.3429**	**.3678**	**.4040**	**.4039**	**.4239**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
WAI[121] **BU 0957**
Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN
Feeder No / Name : 201 / 11 KV WAI MIDC SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5655	1.3717	1.467	1.3336	1.2637	1.2955	1.3336
2	1.4712	1.3336	1.4098	1.3146	1.2071	1.2955	1.1812
3	1.3957	1.2765	1.4098	1.2955	1.1506	1.2384	1.105
4	1.2826	1.2384	1.3527	1.2193	1.0751	1.2384	1.1431
5	1.094	1.1431	1.2765	1.1431	1.0562	1.1622	1.2574
6	1.1694	1.1812	1.2765	1.1622	1.1128	1.1622	1.4289
7	1.1317	1.2193	1.3336	1.3336	1.2071	1.2765	1.3336
8	1.6409	1.7337	1.3717	1.8099	1.5466	1.6766	1.3336
9	2.2862	2.191	2.4387	2.3765	2.2862	1.9052	1.1431
10	2.8769	2.4196	2.5149	2.6029	2.4958	2.4768	1.1431
11	2.3815	2.572	3.0293	2.9047	2.3815	2.7625	1.0479
12	2.1148	2.8006	2.5149	2.7538	2.4196	2.9531	.9526
13	1.9243	2.572	2.4577	2.8292	2.3434	2.8578	.9526
14	2.7625	2.4768	2.8769	3.0744	2.4196	2.7625	.9907
15	2.7244	2.3815	2.8006	3.0178	2.6482	2.6673	.8573
16	2.572	2.2862	2.3434	2.9235	2.4196	2.5911	.9526
17	2.4768	2.2862	2.3243	2.7538	2.1148	2.191	1.0669
18	2.3815	2.4196	1.9624	2.0936	2.0386	2.0005	1.105
19	1.9814	2.2862	1.5432	1.6221	1.6194	2.0957	1.1431
20	1.8099	2.0005	1.5813	1.6221	1.3336	1.9052	1.1431
21	1.448	1.7337	1.3717	1.5844	1.4098	1.4098	1.0479
22	2.0005	1.5623	1.4098	1.7541	1.3336	1.3336	.9526
23	1.6194	1.5051	1.3527	1.4901	1.3336	1.3336	.9526
24	1.4146	1.4098	1.5051	1.3336	1.3203		1.4289
Max	**2.8769**	**2.8006**	**3.0293**	**3.0744**	**2.6482**	**2.9531**	**1.4289**
Min	**1.094**	**1.1431**	**1.2765**	**1.1431**	**1.0562**	**1.1622**	**.8573**
Avg	**1.8969**	**1.8917**	**1.8719**	**1.9729**	**1.7307**	**1.8953**	**1.1249**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
WAI[121] BU 0957
Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN
Feeder No / Name : 203 / 11 KV WAI NAGARPALIKA PWW NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0791	.0753	.0602	.0753	.0791	.0602	.0762
2	.0633	.0602	.0602	.0602	.0633	.0602	.0762
3	.0633	.0602	.0602	.0602	.0633	.0602	.0762
4	.0791	.0753	.0602	.0753	.0791	.0602	.0762
5	.0791	.0753	.0753	.0753	.0791	.0753	.0953
6	.0791	.0753	.0753	.0753	.0791	.0753	.0953
7	.0791	.0753	.0753	.0753	.0791	.0753	.0953
8	.0791	.0602	.0753	.0753	.0791	.0753	.0953
9	.0753	.0753	.0753	.0791	.0762	.0953	.0953
10	.0602	.0753	.0753	.0633	.0753	.0953	.0953
11	.0602	.0753	.0753	.0791	.0753	.0953	.0953
12	.0602	.0753	.0602	.0791	.0753	.0953	.0953
13	.0753	.0753		.0791	.0753	.0953	.0953
14	.0753	.0753	.0753	.0791	.0753	.0953	.0953
15	.0602	.0753	.0753	.0791	.0753	.0953	.0953
16	.0753	.0602	.0753	.0791	.0753	.0953	.0953
17	.0753	.0602	.0753	.0791	.0753	.0953	.0953
18	.0753	.0753	.0753	.0791	.0753	.0953	.0953
19	.0753	.0602	.0753	.0791	.0753	.0953	.0953
20	.0753	.0753	.0753	.0791	.0753	.0953	.0953
21	.0602	.0753	.0753	.0791	.0602	.0953	.0953
22	.0753	.0753	.0753	.0791	.0753	.0953	.0953
23	.0753	.0753	.0753	.0791	.0753	.0953	.0953
24	.0791	.0753	.0753	.0753	.0791	.0753	.0953
Max	**.0791**	**.0753**	**.0753**	**.0791**	**.0791**	**.0953**	**.0953**
Min	**.0602**	**.0602**	**.0602**	**.0602**	**.0602**	**.0602**	**.0762**
Avg	**.0723**	**.0715**	**.0720**	**.0758**	**.0748**	**.0853**	**.0921**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
WAI[121] **BU 0957**
Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN
Feeder No / Name : 204 / 11 KV MAPRO **NON SHEDDABLE EXPRESS HV FEEDERS**
Feeder KV- 11 / OUTGOING **(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1715	.1715	.1334	.2075	.1715	.1524
2	.1886	.1524	.1715	.1143	.2075	.1715	.1524
3	.1886	.1524	.1524	.1143	.2075	.1715	.1524
4	.1886	.1715	.1524	.1334	.2075	.1715	.1524
5	.1886	.1905	.1905	.1334	.1886	.1715	.1715
6	.1886	.2286	.1905	.1524	.2075	.1715	.1905
7	.1698	.2096	.2667	.2096	.2263	.1905	.2286
8	.1509	.2286	.2667	.2667	.2829	.2858	.1143
9	.0953	.4191	.381	.2829	.381	.2858	.0572
10	.0762	.4954	.3239	.3018	.381	.4191	.0572
11	.0953	.5716	.2858	.3206	.3239	.5335	
12	.1524	.5716	.2667	.2829	.3048	.5716	.0953
13	.1715	.2858	.2286	.2075	.3048	.5716	.0953
14	.1143	.381	.2286	.2641	.3048	.5335	.0953
15	.1143	.4572	.4191	.415	.362	.5335	.0953
16	.1524	.4191	.4191	.415	.3429	.5144	.1143
17	.1905	.381	.4382	.415	.3048	.381	.1524
18	.2096	.4763	.3429	.3395	.4382	.3239	.1524
19	.2286	.3048	.3048	.3018	.3429	.3429	.1905
20	.1905	.2667	.2477	.2452	.3048	.2286	.1905
21	.1715	.2286	.2096	.2829	.2286	.2096	.1905
22	.1715	.2286	.3429	.2263	.2286	.1905	.1715
23	.1905	.1905	.1715	.1886	.1905	.1905	.1524
24	.2075	.1905	.1905	.1334	.2263	.1905	.1905
Max	**.2286**	**.5716**	**.4382**	**.415**	**.4382**	**.5716**	**.2286**
Min	**.0762**	**.1524**	**.1524**	**.1143**	**.1886**	**.1715**	**.0572**
Avg	**.1660**	**.3072**	**.2651**	**.245**	**.2794**	**.3136**	**.1441**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
WAI[121] **BU 0957**
Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN
Feeder No / Name : 205 / 11 KV MANDHARDEV GAOTHAN **GAOTHAN FEEDER**
Feeder KV- 11 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1646	.1478	.1478	.1478	.1646	.1663	.1524
2	.1646	.1294	.1478	.1294	.1646	.1663	.1524
3	.1646	.1294	.1663	.1478	.1646	.1663	.1524
4	.1646	.1848	.1663	.1848	.1646	.1715	.1524
5	.2378	.2402	.1848	.2402	.1829	.1848	.2286
6	.3292	.3696	.2218	.3881	.2743	.2402	.2477
7	.4755	.499	.3696	.5175	.4572	.4435	.2286
8	.4755	.499	.462	.5175	.4938	.4805	.3429
9	.3696	.4066	.3696	.4024	.4251	.381	.4001
10	.2858	.3326	.2402	.3292	.3326	.3048	.381
11	.2477	.2402	.2402	.2926	.3142	.2286	
12	.2286	.2218	.1848	.2012	.2772	.1905	.1143
13	.2096	.2218	.3142	.2012	.2218	.1905	.1524
14	.1715	.1848	.1109	.2012	.2218	.2096	.1524
15	.2286	.1848	.1663	.1829	.2033	.2096	.1524
16	.3048	.1848	.1848	.2012	.2218	.2286	.1905
17	.381	.2218	.2402	.2743	.2218	.2858	.3048
18	.4954	.2772	.3696	.4024	.3696	.3239	.381
19	.5525	.5175	.5359	.4755	.4805	.3429	.4572
20	.5144	.4435	.4805	.4755	.4435	.3429	.4572
21	.3881	.3696	.4066	.439	.4066	.3239	.381
22	.2957	.3326	.2957	.2926	.3696	.2286	.3048
23	.1905	.2218	.1848	.1829	.2033	.1905	.2096
24	.1646	.1478	.1848	.1478	.1646	.1848	.1524
Max	**.5525**	**.5175**	**.5359**	**.5175**	**.4938**	**.4805**	**.4572**
Min	**.1646**	**.1294**	**.1109**	**.1294**	**.1646**	**.1663**	**.1143**
Avg	**.3002**	**.2795**	**.2656**	**.2906**	**.2893**	**.2577**	**.2543**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
WAI[121] BU 0957
Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN
Feeder No / Name : 302 / 22 KV MENAWALI GAOTHAN GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.3696	.3696	.2957	.3658	.4066	.381
2	.3292	.3326	.3696	.2957	.3658	.3696	.3048
3	.3292	.3696	.3326	.3326	.3658	.3696	.3048
4	.3292	.4435	.3326	.3696	.3658	.4066	.3429
5	.3658	.5175	.3696	.5175	.4024	.4435	.4572
6	.5487	.6283	.5175	.6283	.5487	.5544	.6097
7	.9511	.961	.924	.961	.9877	.961	.9907
8	1.0608	1.0349	.8871	1.0349	1.134	1.1088	1.0669
9	.9526	.961	.8871	1.0242	1.1088	.9907	1.0288
10	.9145	.8871	.7023	.8779	.9979	.8383	
11	.7621	.8131	.8131	.695	.8871	.7621	
12	.6859	.7762	.5544	.5853	.7392	.6859	
13	.5914	.6653	.6653	.5853	.6283	.6478	.8383
14	.5914	.5544	.5914	.5121	.6653	.6097	.8764
15	.5544	.6283	.5544	.5853	.6283	.6097	.6859
16	.7392	.6283	.6283	.5853	.6283	.6478	.7621
17	.8871	.6283	.7392		.6653	.7621	.9907
18	1.1458	.924	.961	.9145	.8871	.9907	1.2193
19	1.4784	1.4784	1.4784	1.5729	1.5154	1.4098	1.448
20	1.4045	1.4045	1.3676	1.39	1.4045	1.3717	1.4098
21	1.1088	1.1458	.9031	1.1706	1.2197	1.2193	1.1431
22	.8131	.961	.6622	.8779	.961	.9907	1.0288
23	.4805	.5914	.4435		.5914	.7621	.6859
24	.3658	.4066	.4435	.3326	.4024	.4435	.4572
Max	**1.4784**	**1.4784**	**1.4784**	**1.5729**	**1.5154**	**1.4098**	**1.448**
Min	**.3292**	**.3326**	**.3326**	**.2957**	**.3658**	**.3696**	**.3048**
Avg	**.7383**	**.7546**	**.6874**	**.7338**	**.7694**	**.7651**	**.8111**

Date:- 05-02-18

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
WAI[121] **BU 0957**
Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN
Feeder No / Name : 303 / 22 KV PASARNI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6733	.4961	.1433	.1063	.1063	.1075	1.1431
2	.6733	.4961	.1433	.1063	.1063	.1075	1.1431
3	.6024	.4961		.1063	.1063	.1433	1.1431
4	.6024	.4961	.1433	.1063	.1063	.1433	1.1812
5	.6024	.567	.1791	.1063	.1063	.1791	1.2193
6	.7087	.6024	.1791	.1417	.1417	.1791	1.2574
7	.1063		.2149	.1417	.1417	.1791	.0762
8	.1063	1.0277	1.1462	1.2048	1.7718	.1433	.1524
9	.1063	1.5043	1.8781	1.5947	2.3282	.1524	.1524
10	.1417	1.7193	2.268	1.4883	2.5789	.1143	
11	.1417	2.1132	2.1616	1.8427	2.5789	.1143	
12	.1417	2.1491	1.5238	1.4175	2.6147	.1143	
13	.1417	1.9342		1.2403	2.7938	.1143	.0762
14	.1417	1.8983	1.701	1.949	2.7938	.1143	.0762
15	.1417	2.0058	2.1262	2.4806	2.758	.1143	.0762
16	.1417	.1433	.1417	1.5947	.1433	.1143	.0762
17	.1417	.1433	.1417		.1433	.1143	.1524
18	.1417	.1433	.1417	.1063	.1433	.1143	.1524
19	.1417	.1433	.1417	.1417	.1791	.1524	.1524
20	.1417	.1791	.2126	.1417	.1791	.1524	.1524
21	.1417	.1433	.1772	.1463	.1791	.1524	.1524
22	.1417	.1433	.1772	.1063	.1433	.1524	.1524
23	.5316	.1433	.1772	.1063	.1433	1.2193	.8002
24	.7087	.567	.1433	.3612	.1063	.1433	1.3336
Max	**.7087**	**2.1491**	**2.268**	**2.4806**	**2.7938**	**1.2193**	**1.3336**
Min	**.1063**	**.1433**	**.1417**	**.1063**	**.1063**	**.1075**	**.0762**
Avg	**.3027**	**.8372**	**.6937**	**.7277**	**.9330**	**.1806**	**.5153**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
WAI[121] BU 0957
Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN
Feeder No / Name : 401 / 33 KV PACHGANI
Feeder KV- 33 / INCOMING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2226	1.4289	1.6004	1.3717	1.382	1.3717	1.1431
2	1.1694	1.3146	1.4861	1.2574	1.382	1.2574	1.1431
3	1.1694	1.2574	1.3717	1.2574	1.3289	1.2574	1.1431
4	1.1163	1.2574	1.3717	1.4861	1.3289	1.3717	1.2003
5	1.1163	1.3717	1.6004	1.6004	1.3289	1.4861	1.4861
6	1.6478	1.8861	1.829	1.8861	1.5947	1.7147	1.7718
7	2.392	3.0293	2.5149	2.8006	2.6046	2.8006	2.9721
8	3.1893	3.8295	3.4865	3.658	3.5614	3.4294	3.4294
9	3.5437	3.5437	3.6008	3.6145	3.9438	3.315	3.6008
10	3.658	3.4294	3.4294	3.5082	3.9438	3.315	
11	3.315	3.2007	2.9721	3.2425	3.7151	3.4294	
12	2.9721	3.1436	2.915	3.1361	3.6008	3.2007	
13	2.6292	2.915	1.3717	2.7641	3.0864	3.0864	
14	2.5149	2.4006	1.9433	2.5514	2.4006	2.0576	
15	2.5149	1.3146	1.3717	2.7109	2.5149	2.2862	
16	2.7435	1.4289	2.8578	2.6046	2.915	2.4577	
17	2.8578	3.0293	3.2007	2.7109	3.4865	2.8578	
18	2.915	2.1719	3.3722	3.1893	3.7151	3.6008	1.7147
19	3.658	3.6008	3.3722	3.3488	3.7151	3.7723	3.7723
20	3.315	3.1436	3.2007	3.1361	3.315	2.9721	3.5437
21	2.8578	2.7435	2.6863	2.5514	2.8006	2.6292	2.8578
22	2.3434	2.2291	2.1719	2.2325	2.4006	2.2862	2.3434
23	1.829	1.829	1.7718	1.8073	1.829	1.829	1.8861
24	1.3289	1.5432	1.7147	1.4289	1.0631	1.4289	1.5432
Max	**3.658**	**3.8295**	**3.6008**	**3.658**	**3.9438**	**3.7723**	**3.7723**
Min	**1.1163**	**1.2574**	**1.3717**	**1.2574**	**1.0631**	**1.2574**	**1.1431**
Avg	**2.4175**	**2.3767**	**2.3839**	**2.4940**	**2.6232**	**2.4672**	**2.2219**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
WAI[121] BU 0957
Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN
Feeder No / Name : 402 / 33 KV GARWARE NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9805	2.6863	2.8578	3.2007	3.1121	3.0864	2.8578
2	1.9805	2.6292	2.8578	3.2007	3.0556	3.0864	2.7435
3	2.037	2.572	2.7435	3.2007	3.1121	3.0864	2.7435
4	1.9805	2.6292	2.7435	3.315	3.0556	2.9721	2.8578
5	2.0936	2.7435	2.8578	3.315	2.999	2.9721	3.0864
6	2.1502	2.8006	2.8578	3.315	3.1687	2.9721	3.4294
7	2.2634	2.572	2.6292	2.8006	3.1121	3.2579	3.2007
8	2.4897	2.8578	3.0293	3.315	3.0556	3.315	3.315
9	2.7435	3.0864	3.4294	3.2819	3.315	3.4294	3.315
10	3.2007	3.2007	2.6292	3.7912	2.9721	3.4294	3.4294
11	3.1436	3.315	3.0864	3.3951	3.3722	3.315	3.5437
12	3.2007	3.0293	2.8578	3.2253	3.3722	3.5437	3.5437
13	3.0293	3.0293	2.9721	3.1687	3.4294	3.4294	3.6008
14	3.2007	3.2579	3.3722	3.3951	3.4865	3.7151	3.4294
15	3.2579	3.2579	3.658	3.678	3.5437	3.8295	3.7151
16	3.0864	3.1436	3.658	3.3951	3.1436	3.7723	3.7723
17	2.9721	3.1436	3.7723	3.5648	3.1436	3.5437	3.5437
18	2.915	3.1436	2.4577	3.2253	3.4294	3.3722	3.5437
19	2.8578	3.1436	3.1436	3.5082	3.0864	3.4294	3.4294
20	2.8578	3.0864	3.1436	3.0556	3.3722	3.2007	3.315
21	2.8006	3.0864	3.1436	3.3385	3.1436	2.915	3.2007
22	3.1436	3.0293	3.1436	3.4517	3.3722	2.8578	3.2579
23	2.7435	2.9721	2.9721	3.1687	3.2579	2.9721	3.0293
24	1.9805	2.6863	2.9721	3.315	3.2253	2.9721	3.0293
Max	**3.2579**	**3.315**	**3.7723**	**3.7912**	**3.5437**	**3.8295**	**3.7723**
Min	**1.9805**	**2.572**	**2.4577**	**2.8006**	**2.9721**	**2.8578**	**2.7435**
Avg	**2.6712**	**2.9626**	**3.0412**	**3.3175**	**3.2223**	**3.2698**	**3.2889**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
WAI[121] BU 0957
Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN
Feeder No / Name : 404 / 33 KV ATHARVA NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.5648	4.7439	4.0009	4.0009	4.2438	3.315	2.8578
2	4.0741	4.5725	2.572	3.658	4.0741	3.2007	3.315
3	4.3004	4.2295	4.6868	3.315	3.8477	3.2007	3.7723
4	3.9609	3.3722	3.0864	3.4865	3.678	3.4294	3.4294
5	4.1872	2.7435	3.7151	3.3722	3.4517	3.658	4.0009
6	4.8097	2.1148	2.5149	2.4577	3.1687	4.9726	3.7723
7	3.2253	3.658	2.915	3.4294	6.1677	2.2291	2.0576
8	.8488	3.4294	1.3717	.8573	2.0936	1.3717	1.7147
9	5.0297	4.2867	4.6296	4.9794	6.0014	2.0576	1.8861
10	5.144	5.8299	5.144	2.4897	4.5725	2.9721	3.4294
11	5.4298	5.4298	4.8011	.9619	5.2584	3.7723	4.3439
12	5.7156	4.4582	4.8583	1.3014	6.2872	4.4582	4.6868
13	5.7728	2.0576	5.0297	3.1687	5.7156	4.0009	5.487
14	3.8866	4.8011	4.4582	3.5648	3.0293	2.8578	4.0009
15	5.0869	4.0009	4.4582	4.6965	5.0297	.6859	1.4861
16	4.6868	5.2584	5.2584	5.6019	4.5153	4.0009	3.4294
17	4.2867	6.2872	2.0576	4.0175	3.658	2.8578	4.1152
18	4.5153	5.2584	4.8011	5.3189	3.2007	2.1719	4.0009
19	4.1152	2.2862	2.915	4.7531	1.9433	4.0009	3.9438
20	.8002	3.2579	2.915	.9619	2.0576	4.1152	4.0009
21	1.7147	3.5437	3.1436	3.4517	4.5153	4.401	2.0576
22	3.2579	1.7718	4.0009	3.2253	5.4298	3.4294	1.6004
23	5.3727	3.7151	4.4582	2.0936	1.3717	2.8578	4.2867
24	4.5268	4.1152	3.5437	4.4582	4.4136	3.3722	3.2579
Max	**5.7728**	**6.2872**	**5.2584**	**5.6019**	**6.2872**	**4.9726**	**5.487**
Min	**.8002**	**1.7718**	**1.3717**	**.8573**	**1.3717**	**.6859**	**1.4861**
Avg	**4.0964**	**3.9676**	**3.8056**	**3.3176**	**4.0719**	**3.2245**	**3.3722**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
WAI[121] BU 0957
Substation No/ Name :- 254020 / 33/22 KV JAMB S/STN
Feeder No / Name : 301 / BHUINJ AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	2.7435	2.7435	2.2862	.1524	.1143	.2286
2	.1143	2.6673	2.6673	2.2481	.2286	.1143	.1905
3	.1143	2.5911	2.5911	2.21	.1524	.1143	.1905
4	.1905	2.6292	2.4387	2.21	.1905	.1143	.1905
5	.2667	2.7435	2.4387	2.2862	.1905	.1524	.1905
6	.2667	3.3913	2.5911	2.4006	.2286	.1905	.1905
7	.2667	.1143	.2286	.1143	.2286	.1905	.2286
8	.2286	.1143	.1905	3.0102	3.5719	4.1914	3.8485
9	.1905	.1143	.1524	3.658	4.0809	4.4201	4.5725
10	.1905	.1524	.1143	2.9492	4.763		.3429
11	.1524	.1905	.0762	3.5391	4.5725	4.4963	
12	.1143	.1905	.1524	3.5951	4.1914	4.7249	3.9628
13	.1143	.0762	.1143	3.5303	4.4963	4.4201	4.0009
14	.1143	.1143	.1143	3.5627	4.2676	4.382	4.1533
15	.1143	.1143	.1143	3.5063	4.1152	4.1533	3.9628
16	.1143	.2286	.0762	.3429	.1143	.1143	.1143
17	.1143	.1143	.1143	.2667	.1143	.2286	.1143
18	.1905	.2286	.1143	.3048	.3048	2.7054	.1524
19	.1905	.2667	.1524	.3429	.3429	.1905	.1905
20	.2286	.2667	.1524	.3429	.2667	.3048	.1905
21	.1905	.2286	.1143	.3048	.2286	.3048	.1905
22	1.8107	.2286	.1143	.3048	.2286	.3048	.1905
23	2.9721	2.7435	2.2481	.1905	.1143	.3048	.1524
24	.2286	2.8959	2.7816	2.2862	.1524	.1143	.2667
Max	**2.9721**	**3.3913**	**2.7816**	**3.658**	**4.763**	**4.7249**	**4.5725**
Min	**.1143**	**.0762**	**.0762**	**.1143**	**.1143**	**.1143**	**.1143**
Avg	**.3612**	**1.0479**	**.9415**	**1.9080**	**1.5541**	**1.5805**	**1.2094**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
WAI[121] BU 0957
Substation No/ Name :- 254020 / 33/22 KV JAMB S/STN
Feeder No / Name : 302 / JAMB AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	1.4861	1.3717	1.1812	.0381	.0762	.0381
2	.0381	1.448	1.2955	1.1812	.0381	.0762	.0381
3	.0381	1.5242	1.2574	1.1431	.0381	.1143	.0381
4	.0381	1.6004	1.2574	1.1431	.0381	.1524	.0381
5	.0381	1.7528	1.2574	1.1812	.0381	.1524	.0381
6	.0381	1.829	1.3336	1.2193	.0381	.1905	.0381
7	.0381	.1143	.0381	.0762	.0762	.1905	.0381
8	.0381	.0381	.0381	1.7147	1.749	2.0957	2.1338
9	.0381	.0381	.0381	1.829	2.1628	2.4006	2.3243
10	.0381	.0381	.0381	1.576	2.5911	2.3243	2.1719
11	.0381	.0381	.0381	2.0081	2.5911	2.4006	2.2862
12	.0381	.0381	.0381	1.9334	2.6292	2.4006	2.3243
13	.0762	.0381	.0381	1.9006	2.5911	2.5149	2.1338
14	.0762	.0381	.0381	1.8351	2.4768	2.2862	2.0195
15	.0381	.0381	.0381	1.9334	2.2862	2.1338	1.9814
16	.0381	.0381	.0381	.0762	.1143	.0381	.0762
17	.0762	.0381	.0381		.1143	.0381	.0381
18	.0762	.0381	.0381		.1905	.0381	.0381
19	.1524	.0381	.0381	.0762	.1905	.0381	.0762
20	.1905	.0381	.0381	.0762	.1905	.0381	.0762
21	.1905	.0381	.0381	.0762	.1905	.0381	.0762
22	.1905	.0381	.0381	.0762	.1905	.0381	.0762
23	1.6004	1.3717	1.1812	.0381	.0762	.0381	.0381
24	.0381	1.5242	1.448	1.1812	.0381	.0762	.0381
Max	**1.6004**	**1.829**	**1.448**	**2.0081**	**2.6292**	**2.5149**	**2.3243**
Min	**.0381**	**.0381**	**.0381**	**.0381**	**.0381**	**.0381**	**.0381**
Avg	**.1334**	**.5509**	**.4588**	**1.0662**	**.8616**	**.8288**	**.7573**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
WAI[121] BU 0957
Substation No/ Name :- 254020 / 33/22 KV JAMB S/STN
Feeder No / Name : 303 / BHUINJ GAOTHAN GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.3429	.3429	.3048	.381	.381
2	.3048	.3429	.3429	.3429	.3048	.3429	.381
3	.3048	.381	.3429	.3429	.3048	.3429	.381
4	.3429	.4572	.3429	.3429	.381	.3429	.381
5	.3658	.5335	.381	.381	.4024	.381	.381
6	.5121	.6097	.5335	.4954	.4755	.6097	.5716
7	.7682	.7621	.8002	.7621	.7682	.8002	.8383
8	.7682	.7621	.7621	.8002	.7682	.8002	.8002
9	.6584	.6097	.6478	.724	.695	.6097	.6097
10	.4572	.5335	.5716	.5121	.6097	.5716	.4954
11	.4954	.6097	.4954	.5487	.4954	.6097	.4954
12	.4191	.6097	.4954	.5487	.381	.5716	.4954
13	.4191	.4191	.4572	.4024	.4572	.4572	.381
14	.3048	.381	.381	.439	.381	.5335	.3429
15	.3429	.3429	.4572	.439	.4191	.5335	.2667
16	.3048	.4572	.5335	.439	.4191	.4954	.4191
17	.2667	.5335	.5716	.4755	.4191	.4572	.4191
18	.3429	.6478	.6478	.5487	.4954	.7621	.6097
19	.9145	.8383	.8002	.7522	.8764	.8764	.8383
20	.9526	.7621	.724	.7316	.7621	.7621	.7621
21	.5716	.6859	.724	.6219	.6097	.6478	.6859
22	.5335	.5716	.5335	.5853	.5716	.6097	.6097
23	.4954	.4191	.4572	.439	.4954	.4954	.4191
24	.3429	.381	.3429	.3429	.3429	.381	.381
Max	**.9526**	**.8383**	**.8002**	**.8002**	**.8764**	**.8764**	**.8383**
Min	**.2667**	**.3429**	**.3429**	**.3429**	**.3048**	**.3429**	**.2667**
Avg	**.4805**	**.5414**	**.5287**	**.5150**	**.5058**	**.5573**	**.5144**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
WAI[121] BU 0957
Substation No/ Name :- 254020 / 33/22 KV JAMB S/STN
Feeder No / Name : 304 / JAMB GAOTHAN GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.4572	.3048	.2667	.2667	.3429	.3048
2	.2667	.381	.2667	.3048	.2667	.3048	.2667
3	.3048	.381	.2667	.2667	.2667	.3048	.2667
4	.3048	.381	.3429	.2667	.3048	.3429	.3429
5	.3658	.4954	.381	.381	.381	.4572	.381
6	.5853	.724	.6478	.5335	.439	.6097	.5335
7	.8238	.8383	.8383	.8002	.7316	.7621	.7621
8	.695	.7621	.7621	.6859	.695	.6859	.6097
9	.6219	.6478	.724	.5716	.6219	.5335	.5335
10	.6859	.724	.5335	.6584	.6478	.5335	.381
11	.6859	.6478	.4191	.4755	.6478	.5335	.381
12	.6478	.6859	.4954	.5853		.5335	.3429
13	.6859	.6478	.381	.6219	.5335	.5335	.3048
14	.6097	.6097	.4954	.5121	.5335	.5716	.3429
15	.6097	.6097	.5716	.5121	.4954	.6097	.3429
16	.6097	.6859	.4572	.4755	.4954	.381	.3429
17	.6097	.5716	.5335	.5487	.6859	.6478	.381
18	.6478	.7621	.6097	.695	.7621	.724	.5716
19	.8383	1.105	.8002	.8954	.9526	.8764	.724
20	1.0669	.9526	.6859	.8596	.7621	.8764	.724
21		.724	.6478	.5487	.6097	.724	.6097
22	.6097	.4954	.4954	.4755	.4191	.4572	.4954
23	.5716	.3429	.381	.3429	.381	.3429	.3429
24	.3048	.4954	.3048	.2667	.3048	.381	.3048
Max	**1.0669**	**1.105**	**.8383**	**.8954**	**.9526**	**.8764**	**.7621**
Min	**.2667**	**.3429**	**.2667**	**.2667**	**.2667**	**.3048**	**.2667**
Avg	**.5851**	**.6303**	**.5144**	**.5229**	**.5306**	**.5446**	**.4414**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
WAI[121] BU 0957
Substation No/ Name :- 254020 / 33/22 KV JAMB S/STN
Feeder No / Name : 305 / 22 KV KHADAKI AG FEEDER SEPERATION/PURE AG
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17	02-NOV-17	03-NOV-17	04-NOV-17	05-NOV-17	06-NOV-17	07-NOV-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.0762	.1143	.1143	1.8107	1.6766	1.9814
2	.0762	.0762	.0762	.0762	1.7772	1.6004	1.9052
3	.0762	.0762	.0762	.0762	1.56	1.5242	1.8671
4	.0762	.0762	.0762	.0762	1.6278	1.6766	1.8671
5	.1143	.1143	.1143	.0762	1.6956	1.9052	1.8671
6	.1524	.0762	.1143	.1143	1.8442	2.1338	1.9814
7	.1905	2.8197	.1905	.1905	.2286	.1143	.2667
8	2.146	2.934	2.934	.1524	.2667	.1143	2.5911
9	2.4577	3.4294	3.5056	.1905	.1524	.0762	2.8578
10	3.0864	3.5056	3.4294	.0762	.1524	.1143	3.2388
11	3.3532	3.4675	3.315	.1143	.1524	.1143	3.2769
12	3.2007	3.2388	3.5056	.0762	.1143	.1905	3.315
13	3.3532	3.2769	3.1626	.1143	.1143	.1143	3.2388
14	3.2388	3.2388	3.0864	.1524	.0762	.1524	3.2769
15	3.2007	1.5242	3.0864	.1524	.0762	.0762	2.9721
16	.0381	.0381	.0762	.1143	.0762	.1143	.1524
17	.0381	.0762	.1143	.1524	.1524	.1524	.1524
18	.0381	.1143	.1143	.2286	.1905	.2286	.1905
19	.0762	.1524	.1905	.2667	.1905	.2667	.2286
20	.1905	.1143	.1905		.1905	.2667	.1905
21	.1905	.1143	.1524	.2667	.1905	.2286	.2286
22	.1905	.1143	.1143	.2286	.1905	.1905	.2286
23	.1905	.1143	.1143	1.7772	1.7528	1.9433	.1143
24	.0762	.1143	.1143	.1143	1.8107	1.7147	2.0957
Max	**3.3532**	**3.5056**	**3.5056**	**1.7772**	**1.8442**	**2.1338**	**3.315**
Min	**.0381**	**.0381**	**.0762**	**.0762**	**.0762**	**.0762**	**.1143**
Avg	**1.0777**	**1.2034**	**1.1653**	**.2131**	**.6831**	**.6954**	**1.6702**

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
WAI[121] **BU 0957**
Substation No/ Name :- 257014 / 132/33/22 KV WAI S/STN
Feeder No / Name : 302 / 22 KV COLLEGE ROAD **SHEDDABLE URBAN**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
24	3.6969
Max	3.6969
Min	3.6969
Avg	3.6969

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
WAI[121] BU 0957
Substation No/ Name :- 257014 / 132/33/22 KV WAI S/STN
Feeder No / Name : 303 / 22 KV BAVDHAN AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17
HR	Load (MW)
24	3.6969
Max	3.6969
Min	3.6969
Avg	3.6969

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
WAI[121] **BU 0957**
Substation No/ Name :- 257014 / 132/33/22 KV WAI S/STN
Feeder No / Name : 304 / 22 KV WAI CITY **SHEDDABLE URBAN**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
24	3.2819
Max	3.2819
Min	3.2819
Avg	3.2819

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
WAI[121] BU 0957
Substation No/ Name :- 257014 / 132/33/22 KV WAI S/STN
Feeder No / Name : 305 / 22 KV KENJAL AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-NOV-17
HR	Load (MW)
24	2.9424
Max	2.9424
Min	2.9424
Avg	2.9424

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
WAI[121] **BU 0957**
Substation No/ Name :- 257014 / 132/33/22 KV WAI S/STN
Feeder No / Name : 306 / 22 KV BAVDHAN GAOTHAN **GAOTHAN FEEDER**
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
24	2.6029
Max	2.6029
Min	2.6029
Avg	2.6029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
WAI[121] BU 0957
Substation No/ Name :- 257014 / 132/33/22 KV WAI S/STN
Feeder No / Name : 307 / 22 KV SHAHABAUG GAOTHAN GAOTHAN FEEDER
Feeder KV- 22 / OUTGOING

DATE	01-NOV-17
HR	Load (MW)
24	2.9047
Max	2.9047
Min	2.9047
Avg	2.9047

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
WAI[121] BU 0957
Substation No/ Name :- 257014 / 132/33/22 KV WAI S/STN
Feeder No / Name : 402 / 33 KV MIDC NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 33 / INCOMING UTILITY

DATE	01-NOV-17
HR	Load (MW)
24	7.7521
Max	7.7521
Min	7.7521
Avg	7.7521

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
WAI[121] **BU 0957**
Substation No/ Name :- 257014 / 132/33/22 KV WAI S/STN
Feeder No / Name : 404 / 33 KV WAI-VELE **SHEDDABLE RURAL**
Feeder KV- 33 / INCOMING

DATE	01-NOV-17
HR	Load (MW)
24	14.9383
Max	14.9383
Min	14.9383
Avg	14.9383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-NOV-17 and 07-NOV-17

BARAMATI ZONE[052]
SATARA CIRCLE[575]
WAI DIVISION[700]
WAI[121] BU 0957
Substation No/ Name :- 257014 / 132/33/22 KV WAI S/STN
Feeder No / Name : 702 / Kisanveer Sakhar Karkhana NON SHEDDABLE EHV INDUSTRIAL FEEDERS Bhui Feeder KV- 132 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING

DATE	01-NOV-17
HR	Load (MW)
24	21.5021
Max	21.5021
Min	21.5021
Avg	21.5021