

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334012 / KOTHALI

Feeder No / Name : 201 / Pawala

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.2891		1.9404	2.0165	2.0725	2.2032
16	1.7737	.3978	.9745	1.1744	1.0631	.8745
24	2.5873	2.6797	2.5206	2.5873		2.6242
<b>Max</b>	<b>2.5873</b>	<b>2.6797</b>	<b>2.5206</b>	<b>2.5873</b>	<b>2.0725</b>	<b>2.6242</b>
<b>Min</b>	<b>1.7737</b>	<b>.3978</b>	<b>.9745</b>	<b>1.1744</b>	<b>1.0631</b>	<b>.8745</b>
<b>Avg</b>	<b>2.2167</b>	<b>1.5388</b>	<b>1.8118</b>	<b>1.9261</b>	<b>1.5678</b>	<b>1.9006</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334012 / KOTHALI

Feeder No / Name : 202 / Vyhur

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.0119			.9335	1.2449	.9242	1.6057
16	1.1389	1.3306	.7461	.9214	1.0923	.4252	.4973
24	1.6804		1.6991	1.5844	1.531		1.6617
Max	2.0119	1.3306	1.6991	1.5844	1.531	.9242	1.6617
Min	1.1389	1.3306	.7461	.9214	1.0923	.4252	.4973
Avg	1.6104	1.3306	1.2226	1.1464	1.2894	.6747	1.2549

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334012 / KOTHALI

Feeder No / Name : 203 / Wadzakan

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.3443			.8063	.8745		
16	2.0119	1.0111	.6805	1.2826	1.2449	1.1389	
24	1.7741		1.4563	1.6617	1.6991		1.4003
Max	2.0119	1.0111	1.4563	1.6617	1.6991	1.1389	1.4003
Min	1.3443	1.0111	.6805	.8063	.8745	1.1389	1.4003
Avg	1.7101	1.0111	1.0684	1.2502	1.2728	1.1389	1.4003

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334027 / ASHTE

Feeder No / Name : 201 / THANEPADA AG

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	24-JUN-17	25-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.274	.3597	.2569	.2912
20			.0856		.0854
24	.0855	.2227	.1199	.0856	.1028
Max	.0855	.274	.3597	.2569	.2912
Min	.0855	.2227	.0856	.0856	.0854
Avg	.0855	.2484	.1884	.1713	.1598

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334027 / ASHTE

Feeder No / Name : 202 / Sutarpada AG

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	27-JUN-17
HR	Load (MW)
8	.137
24	.0343
Max	.137
Min	.0343
Avg	.0857

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334027 / ASHTE

Feeder No / Name : 203 / Nandarkheda AG  
Feeder KV- 11 / OUTGOING

Sheddable Rural/Mix Feeder

DATE	24-JUN-17	25-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
8	.0856	.3597	.3083
24	.2227	.2227	.1199
Max	.2227	.3597	.3083
Min	.0856	.2227	.1199
Avg	.1542	.2912	.2141

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334027 / ASHTE

Feeder No / Name : 204 / Ashta Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	24-JUN-17	25-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.2743	.2561	.2195	.2561
12			.128	.1097	.1463
16			.1646	.1829	.1646
20		.2743	.2378		.2926
24	.1829	.1829	.1646	.1646	.1829
Max	.1829	.2743	.2561	.2195	.2926
Min	.1829	.1829	.128	.1097	.1463
Avg	.1829	.2438	.1902	.1692	.2085

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334027 / ASHTE

Feeder No / Name : 205 / Sutarpada Gaothan  
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	22-JUN-17	24-JUN-17	25-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.2195	.1829	.2012	.2195	.2012
12			.0914	.0914	.1463
16		.1829	.1463	.2012	.1646
20		.2926	.2926		.2926
24	.2012	.2012	.2012	.2378	.2012
<b>Max</b>	<b>.2195</b>	<b>.2926</b>	<b>.2926</b>	<b>.2378</b>	<b>.2926</b>
<b>Min</b>	<b>.2012</b>	<b>.1829</b>	<b>.0914</b>	<b>.0914</b>	<b>.1463</b>
<b>Avg</b>	<b>.2104</b>	<b>.2149</b>	<b>.1865</b>	<b>.1875</b>	<b>.2012</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334027 / ASHTE

Feeder No / Name : 206 / Shrirampur Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	24-JUN-17	25-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.4938	.439	.4024	.4572
12			.3109	.2743	.2926
16		.4572	.3841	.4024	.3658
20		.5481	.4938		.5121
24	.4024	.4207	.3841	.4024	.4024
<b>Max</b>	<b>.4024</b>	<b>.5481</b>	<b>.4938</b>	<b>.4024</b>	<b>.5121</b>
<b>Min</b>	<b>.4024</b>	<b>.4207</b>	<b>.3109</b>	<b>.2743</b>	<b>.2926</b>
<b>Avg</b>	<b>.4024</b>	<b>.4800</b>	<b>.4024</b>	<b>.3704</b>	<b>.4060</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334027 / ASHTE

Feeder No / Name : 207 / 11 KV Waghale AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	24-JUN-17	25-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12			.1713	.0685
16		.1884	.2398	.2569
24	.5138			
Max	.5138	.1884	.2398	.2569
Min	.5138	.1884	.1713	.0685
Avg	.5138	.1884	.2056	.1627

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334027 / ASHTE

Feeder No / Name : 208 / NDBR Muncipal Water supply Only one consumerof WW with HT-IV  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	24-JUN-17	25-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.0366	.0732	.0366	.0732
12			.0366	.0183	.0366
16		.0183	.0183	.0549	.0366
20		.0732	.0732		.0732
24	.0183				.0183
Max	.0183	.0732	.0732	.0549	.0732
Min	.0183	.0183	.0183	.0183	.0183
Avg	.0183	.0427	.0503	.0366	.0476

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334027 / ASHTE

Feeder No / Name : 209 / Bandharpada Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	24-JUN-17	25-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12			.0856	.1028	.0685
16		.0513	.1028	.0685	.0856
24	.7194				
Max	.7194	.0513	.1028	.1028	.0856
Min	.7194	.0513	.0856	.0685	.0685
Avg	.7194	.0513	.0942	.0857	.0771

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334034 / 33/11 KV KARANKHEDA Sub Stn

Feeder No / Name : 201 / Pachorabari Ag Ag dominated/Pure Ag  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0724	.1494	.0975	.0975
2				.0724	.1494	.0975	.0975
3				.0724	.1402	.0945	.0945
4				.0724	.1189	.093	.093
5				.0716	.1189	.1219	.1238
6			.2149	.0716	.1555	.1486	.1555
7			.2149	.1433	.3384	.2553	.2743
8			.2149	.1433	.2667	.2553	.3155
11	1.0288						
12	.9145	.2591					
13	.8002	.2629					
14	.7682	.2042					
15	.6935	.2164					
16	.8459	.1981					
17		.1417					
18		.1417					
23					.1463	.0991	
24				.1829	.1257	.0975	.0991
Max	1.0288	.2629	.2149	.1829	.3384	.2553	.3155
Min	.6935	.1417	.2149	.0716	.1189	.093	.093
Avg	.8419	.2034	.2149	.1003	.1709	.1360	.1501

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334034 / 33/11 KV KARANKHEDA Sub Stn

Feeder No / Name : 202 / Lonkheda Ag Ag dominated/Pure Ag  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0724	.0476	.0857	.1524
2				.0724	.0476	.0857	.1524
3				.0724	.0476	.0524	.1524
4				.0724	.0476	.0476	.1524
5				.0716	.0476	.0572	.1524
6				.0895	.0762	.0667	.1758
7				.1254	.1677	.1048	.2782
8				.2149	.0953	.0953	.2364
10			.1791				
11			.1791				
12	.8505	.4287					
13	.8802	.3286					
14	.4801	.4904					
15	.6401	.5569	.1433				
16	.7068	.5005	.1402				
17		.5639					
18		.5005					
23					.0476	.1524	
24				.1829	.0476	.1109	.1524
Max	.8802	.5639	.1791	.2149	.1677	.1524	.2782
Min	.4801	.3286	.1402	.0716	.0476	.0476	.1524
Avg	.7115	.4814	.1604	.1082	.0672	.0859	.1783

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334034 / 33/11 KV KARANKHEDA Sub Stn

Feeder No / Name : 203 / Jamboli single phase Single Phasing Feeders  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9762	.9717	.724	.7964	.9795	1.0269	1.0269
2	.9686	.9831			.9795	1.0269	1.0269
3	.9842	.9831		.8326	.961	1.0269	1.0269
4	1.0437	1.0159	.6447		1.0164	1.0164	1.0269
5	1.1203	1.004		.9671	1.0456	1.0829	1.1016
6	1.1469			.8596	1.0456	1.1389	1.1389
7	1.1702			.8596	.8962	.8871	.9149
8	1.1279			.7164	.7655	.8131	.8029
9	.6219				.7392	.7947	.7842
10	.5487			.6283	.7207	.7762	
11	.5359			.5376	.5898	.7116	.5316
12	.5175			.5601	.6874		
13	.5544	.7133	.3582	.5535	.6401		.4961
14	.6036	.7133	.6089		.6249	.7522	
15	.6468	.7207	.6447		.6562	.4586	
16	.5914	.8048		.4961	.5441	.4696	
17		.8501	.631	.502	.583	.4424	.4298
18		.8871	.6024	.4534		.4748	.543
19		.9795	.6089	.8962	.961	.9522	.5792
20		1.2012		1.1088	1.2136	1.0164	.6283
21		1.2197		1.1643	1.2323	1.0164	.961
22		1.1643		1.1088		1.1016	1.0719
23	1.0486				1.0456	1.0456	
24	.9804	.9922		.8779	.9795	1.0269	1.0269
Max	1.1702	1.2197	.724	1.1643	1.2323	1.1389	1.1389
Min	.5175	.7133	.3582	.4534	.5441	.4424	.4298
Avg	.8437	.9503	.6029	.7733	.8594	.8663	.8399

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334034 / 33/11 KV KARANKHEDA Sub Stn

Feeder No / Name : 204 / Nalve Gavthan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5544	.5487		.5068
2	.5544	.5487		.5068
3	.5544	.5914		.5068
4	.5914	.6468		.5792
5	.7577	.7207		.7164
6	.924			
7	.7207			
8	.5487			
9	.4784			
10	.4801			.6299
11	.4115			
12	.3467	.5765		
13		.5426		
14		.4908	.5014	
15		.703	.4656	
16	.4681	.6001		
17		.6135	.4557	
18		.6201	.4961	
19		.5847	.5731	
20		.6697		
21	.5731	.7133		
22	.6805	.6401		
23	.6154			
24	.5544	.5973		.6219
Max	.924	.7207	.5731	.7164
Min	.3467	.4908	.4557	.5068
Avg	.5773	.6122	.4984	.5811

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219]

BU 5517

Substation No/ Name :- 334034 / 33/11 KV KARANKHEDA Sub Stn

Feeder No / Name : 205 / Narayanpur Gavthan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3841	.3658	.2715	.2534	.9055		.9425
2	.3841	.3658		.2534	.9055		.9425
3	.3658	.3696		.2534	.924		.961
4	.3841	.3881		.2686	.961		1.0349
5	.3841	.4024		.2865	1.1576		1.1273
6	.4344		.2686	.2865	1.3306		1.2197
7	.362			.3045	1.0349		.9694
8	.3224		.2481	.2865	.8048		.7701
9	.298			.2507	.7164	.9922	.7164
10	.2835		.2507	.1928	.7164	.9465	
11				.197	.6447	.8238	.7442
12	.2804	.2126	.197	.2149	.6626		
13	.2804	.2103		.2279	.6335		.7265
14	.2686	.1791	.2149		.788	.7888	
15	.2686	.2254	.197		.8059	.7265	
16	.2915	.2543		.9602	.8589	.7888	
17	.2743	.2947	.2804	1.0576	.9593	.9465	.8954
18	.2753	.3121	.2328	1.0867		.985	.905
19	.3018	.3155	.3224	.9745	.9412	1.0029	1.0136
20		.362		1.086	1.0719	1.0534	1.1088
21	.4252	.3841		1.0608	1.0903	.9979	1.1088
22	.4119	.3475		1.0242		1.0349	1.0349
23	.4024					.961	
24	.3841	.3841		.2743	.9055		.9425
Max	.4344	.4024	.3224	1.0867	1.3306	1.0534	1.2197
Min	.2686	.1791	.197	.1928	.6335	.7265	.7164
Avg	.3394	.3161	.2483	.5143	.8961	.9268	.9535

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334035 / 33/11 KV Palashi Sub Stn

Feeder No / Name : 201 / Dhamdai Gavthan Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7				.583	.7023	.7577	.7207
8		.7023		.5487	.6838	.7023	.5914
12	.6283	.2743	.4115	.5175	.499	.4251	.4251
16	.4435	.5316	.4801	.5544	.5175	.499	
19	.5544		.7392	.7392	.7207	.5544	
23	.5914		.5544	.5914	.5914	.5729	.6099
24	.5729	.5914	.583	.583	.5729	.5914	.5544
Max	.6283	.7023	.7392	.7392	.7207	.7577	.7207
Min	.4435	.2743	.4115	.5175	.499	.4251	.4251
Avg	.5581	.5249	.5536	.5882	.6125	.5861	.5803

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334035 / 33/11 KV Palashi Sub Stn

Feeder No / Name : 202 / Pathrai Ag Ag dominated/Pure Ag  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	1.2289	1.2289					
8	1.2003	1.1288					
11				.3144	.4001		.2143
12			.3506	.3144	.3572		.2143
13						.2286	
14						.2858	
16			.3048	.2572	.3572	.2143	.2143
17				.2	.2858		
18			.2572				.2
19						.2429	
23	.6287						
24	.6573	.643	.5144				
Max	1.2289	1.2289	.5144	.3144	.4001	.2858	.2143
Min	.6287	.643	.2572	.2	.2858	.2143	.2
Avg	.9288	1.0002	.3568	.2715	.3501	.2429	.2107

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334035 / 33/11 KV Palashi Sub Stn

Feeder No / Name : 203 / Rajive Soot Girani SHEDDABLE FEEDER HAVING WEEKLY  
 Industrial Feeder KV- 11 / STAGGERING (MIDC, EQUIVALENT)  
 OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.1463	.2012			.1463	.128	.128
8	.1097	.2012			.1463	.1097	.128
12	.1463	.1886		.1097	.1463	.1646	.128
16	.128	.1526	.1372	.2378	.1097	.128	.128
19	.1829		.1097	.2012	.128	.1463	.128
23	.1463			.1646	.128	.128	.1097
24	.1097	.1463	.1543		.1463	.128	.1097
Max	.1829	.2012	.1543	.2378	.1463	.1646	.128
Min	.1097	.1463	.1097	.1097	.1097	.1097	.1097
Avg	.1385	.1780	.1337	.1783	.1358	.1332	.1228

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334047 / Chaupale s/s

Feeder No / Name : 201 / BHONE AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1981	.1372	.1219		.2915
2			.2134	.1372	.1524		.2896
3			.2591	.1372	.1829		.2439
4			.2229	.1372	.2439		.2286
5			.2572	.1829	.2743		.1677
6			.2286	.2439	.3048		.1829
7			.2591	.2743	.3963	.3258	.2743
8			.2743	.3048	.2591	.2743	.2439
9						.2286	
11	1.0364	.4115				.3963	
12	1.0669	.3658					
13	.9907	.3772					
14		.3353					
15		.3658					
16		.3353					
17		.4725					
18		.381					
19	.6859						
20	.7011						
21	.5944						
23		.2134	.1204	.1219		.1524	.1054
24			.2134	.1355	.1219		.2286
Max	1.0669	.4725	.2743	.3048	.3963	.3963	.2915
Min	.5944	.2134	.1204	.1219	.1219	.1524	.1054
Avg	.8459	.3620	.2247	.1812	.2286	.2755	.2256

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334047 / Chaupale s/s

Feeder No / Name : 202 / WAVAD AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.6401					
2	.5792	.6859					
3	.6097	.5335					
4	.6859	.5487					
5	.7621	.5487					
6	.9145						
7	1.0364						
8	.7888						
11			.301	.1981	.2896	.2439	.2107
12			.3612	.1829	.2896	.2439	.2107
13		.3353	.3161		.2896		.2107
14			.2408		.2896		.1505
15			.301		.3048		.1204
16			.3161		.2896		.1204
17			.3612		.2743		.0602
18			.3475	.6097	.1981	.16	
19				.1219		.1734	
20				.0762		.16	
21				.0762			
22				.0762		.0934	
23	.5335						
24	.4877	.6097					
Max	1.0364	.6859	.3612	.6097	.3048	.2439	.2107
Min	.4877	.3353	.2408	.0762	.1981	.0934	.0602
Avg	.6947	.5574	.3181	.1916	.2782	.1791	.1548

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334047 / Chaupale s/s

Feeder No / Name : 203 / CHOUPALE GAVTHAN FEEDER

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.4877	.583	.4961	.4115	.4877	.442
2	.583	.4725		.5121	.583	.5182	.463
3	.6516	.5335		.5138	.6516	.5944	.4115
4	.6687	.5639		.5138	.7545	.6097	.4287
5	.7888	.5792		.567	.823	.6249	.5944
6	.9259			.8596	.8916	.7202	1.0802
7	.8059			.7682	.7545	.6859	.7545
8	.5792			.695	.5487	.5792	.6173
9	.5487		.2915	.5853	.5335	.4268	
10	.4877			.4725	.4877		.583
11	.442		.567		.381	.5144	.439
12	.4115		.5853	.4572	.3658	.463	.439
13	.4572				.3658		.439
14		.6173		.5487	.381		.4207
15		.5944	.2012	.503	.3963		.439
16		.6516	.4572	.4572	.442	.583	.439
17		.6097	.6219	.4725	.583	.5658	.5853
18	.6249	.7716	.6516	.6249	.5487	.7545	.7133
19	.7926	.8573	.8779	.7011	.6097	.8573	.7133
20	.7773	.9088	.8962	.6554	.6249	.7373	.695
21	.6859	.8059		.6097	.5182		.6767
22	.5639	.5792		.4115		.5316	.6036
23	.5335	.583	.5121	.381	.4877	.5316	.5304
24	.4801	.4877	.583	.5121	.4115	.4725	.5144
Max	.9259	.9088	.8962	.8596	.8916	.8573	1.0802
Min	.4115	.4725	.2012	.381	.3658	.4268	.4115
Avg	.6161	.6315	.5690	.5599	.5459	.5925	.5662

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R2[573] BU 5584

Substation No/ Name :- 334004 / KHONDAMALI

Feeder No / Name : 202 / LIS - II  
Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.9808		.463		
3				.5218			.3041
4						.4755	
6				.4534		.535	.3201
7					.6203	.571	
8				.3725	.6539	.5944	.2846
12	2.0809	1.382					
13		1.2037					
16		1.5752					
17	2.0005						
23							.2683
24			1.07	.3637	.4681	.4755	.3041
Max	2.0809	1.5752	1.07	.5218	.6539	.5944	.3201
Min	2.0005	1.2037	.9808	.3637	.463	.4755	.2683
Avg	2.0407	1.3870	1.0254	.4279	.5513	.5303	.2962

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R2[573] BU 5584

Substation No/ Name :- 334004 / KHONDAMALI

Feeder No / Name : 203 / KOPARLI  
Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	2.1125	1.861					
6	3.1786						
7		2.9767					
8	2.5396	2.3967					
11			.8322			1.0562	
12				1.0322	1.6358	.8421	1.0395
14				.9602			
16			1.1683	.8718	1.382		.7537
17			1.2163				
18						.5668	
23	2.2298						
24	2.0622	1.9616					
Max	3.1786	2.9767	1.2163	1.0322	1.6358	1.0562	1.0395
Min	2.0622	1.861	.8322	.8718	1.382	.5668	.7537
Avg	2.4245	2.299	1.0723	.9547	1.5089	.8217	.8966

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R2[573] BU 5584

Substation No/ Name :- 334004 / KHONDAMALI

Feeder No / Name : 205 / 11 Kv. Khondamali Gaothan  
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2					.8954		
3	1.0136	1.0029		1.0029			1.0745
4						.362	
5			.8048				
6	1.7002			1.848		.5853	1.8671
7		1.2757	.8048		1.262	1.2567	
8	1.3169	1.2757		1.3169	1.2178	.9412	1.4045
9				1.2437			1.2437
11	.9114		.9313			1.0974	
12		.9511	.9412	.8596	.5792	1.0745	.8596
14				.8505			
16		1.0974			1.086	.8688	
17	.6379		1.2437				
18						1.6263	
20	1.5424	1.5684		1.6827	1.4784		1.5947
21			1.3169			1.5364	
23	1.0029						.9671
24	1.0029	.9214	1.0136	1.0029	.9313	.2926	1.0974
Max	1.7002	1.5684	1.3169	1.848	1.4784	1.6263	1.8671
Min	.6379	.9214	.8048	.8505	.5792	.2926	.8596
Avg	1.1410	1.1561	1.0080	1.2259	1.0643	.9641	1.2636

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R2[573] BU 5584

Substation No/ Name :- 334004 / KHONDAMALI

Feeder No / Name : 206 / 11 Kv. Vikharan Gaothan  
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2					.439		
3	.4298	.4344		.4298			.4706
4			.4344			.6154	
6	1.0719			1.0349		1.1203	1.0829
7		.8596	.8413		.6878	.8131	
8	.8501	.7796		.7316	.6516	.6878	.6584
9				.5487			.6219
11			.394			.5487	
12	.4607	.439	.394	.4298	.4706	.2865	.3982
14				.4298			
16		.4706	.4656	.4656	.4344	.4298	.4706
17	.4961		.4706				
18						.7392	
20	.8939	.9335		.9134	.8131		.8596
21			.6219			.6584	
23	.4706						.4706
24	.4298	.4344	.4344	.4298	.4344	.5068	.4706
Max	1.0719	.9335	.8413	1.0349	.8131	1.1203	1.0829
Min	.4298	.4344	.394	.4298	.4344	.2865	.3982
Avg	.6379	.6216	.5070	.6015	.5616	.6406	.6115

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R2[573] BU 5584

Substation No/ Name :- 334011 / 33/11 KV RANALA

Feeder No / Name : 201 / SHANIMANDAL

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.5487	.6348	.6224	.5144	.3361	.3206	.5144
8	.9831	1.0082	.7545	.9088	.6348	.5658	.6859
12		1.0374	.6001	.4854		.3658	.3734
16		1.1506	.6173	.4108	.5093	.4207	.4108
20	1.2323	.9242	.6859	.5415	.4527	.4755	.5788
24	.6001	.6348	.4904	.439	.3734	.3206	.3544
Max	1.2323	1.1506	.7545	.9088	.6348	.5658	.6859
Min	.5487	.6348	.4904	.4108	.3361	.3206	.3544
Avg	.8411	.8983	.6284	.5500	.4613	.4115	.4863

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R2[573] BU 5584

Substation No/ Name :- 334011 / 33/11 KV RANALA

Feeder No / Name : 202 / Akrale Ag Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.5144	.5975					
7	.3544						
8	.9831						
12			.3721	.4108	.5658	.3658	.4854
16			.4607		.4904	.3189	.2987
24	.3658	.5601	.2263				
Max	.9831	.5975	.4607	.4108	.5658	.3658	.4854
Min	.3544	.5601	.2263	.4108	.4904	.3189	.2987
Avg	.5544	.5788	.3530	.4108	.5281	.3424	.3921

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R2[573] BU 5584

Substation No/ Name :- 334011 / 33/11 KV RANALA

Feeder No / Name : 203 / 11 KV Akrale Gaothan

Gaothan Feeder

Feeder Feeder KV- 11 /  
OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.7716		.9145	.6859	.8048	.7682	.8916
7		.7392					
8	.9831	.9877	1.1949	1.065	1.0608	1.0456	1.0059
12	.724	.6154	.5316	.695	.695	.5658	.6722
16	.8048	.724	.6859		.6878	.5658	.8048
20	1.4632	1.419	1.0974	1.4632	1.2696	1.065	1.2567
24	.6859	.6584	.724	.7202	.7316	.724	.6859
Max	1.4632	1.419	1.1949	1.4632	1.2696	1.065	1.2567
Min	.6859	.6154	.5316	.6859	.6878	.5658	.6722
Avg	.9054	.8573	.8581	.9259	.8749	.7891	.8862

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R2[573] BU 5584

Substation No/ Name :- 334011 / 33/11 KV RANALA

Feeder No / Name : 204 / Nimbhel Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	25-JUN-17	26-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4			.1932	
8			.3269	
12	.8322			
16	.6539			.1783
20		.2526		.1486
24			.208	
<b>Max</b>	<b>.8322</b>	<b>.2526</b>	<b>.3269</b>	<b>.1783</b>
<b>Min</b>	<b>.6539</b>	<b>.2526</b>	<b>.1932</b>	<b>.1486</b>
<b>Avg</b>	<b>.7431</b>	<b>.2526</b>	<b>.2427</b>	<b>.1635</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R2[573] BU 5584

Substation No/ Name :- 334011 / 33/11 KV RANALA

Feeder No / Name : 205 / Nimbhel Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.1463	.1307		.1097	.112	.1307	.1829
8	.1509	.1867	.1867	.1307	.168	.168	.2054
12	.112	.0934	.112	.0934	.112	.112	.0747
16	.1494	.0934	.0943	.0934	.1307	.112	.112
20	.2427	.2054	.1829	.1867	.112	.1848	.2054
24	.0943	.0934	.0934	.1132	.0934	.0934	.0943
Max	.2427	.2054	.1867	.1867	.168	.1848	.2054
Min	.0943	.0934	.0934	.0934	.0934	.0934	.0747
Avg	.1493	.1338	.1339	.1212	.1214	.1335	.1458

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R2[573] BU 5584

Substation No/ Name :- 334021 / KOPARLI

Feeder No / Name : 202 / Hatmohida Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	23-JUN-17
HR	Load (MW)
6	1.7814
8	1.768
<b>Max</b>	<b>1.7814</b>
<b>Min</b>	<b>1.768</b>
<b>Avg</b>	<b>1.7747</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R2[573] BU 5584

Substation No/ Name :- 334021 / KOPARLI

Feeder No / Name : 203 / 11 Kv. Bahyane Gaothan  
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	23-JUN-17
HR	Load (MW)
6	.7716
8	.583
<b>Max</b>	<b>.7716</b>
<b>Min</b>	<b>.583</b>
<b>Avg</b>	<b>.6773</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R2[573] BU 5584

Substation No/ Name :- 334021 / KOPARLI

Feeder No / Name : 204 / 11 Kv. Arale Gaothan  
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	23-JUN-17
HR	Load (MW)
6	.2401
8	.1372
<b>Max</b>	<b>.2401</b>
<b>Min</b>	<b>.1372</b>
<b>Avg</b>	<b>.1887</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R2[573] BU 5584

Substation No/ Name :- 334021 / KOPARLI

Feeder No / Name : 205 / New Arale Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	23-JUN-17
HR	Load (MW)
6	1.3765
8	1.448
<b>Max</b>	<b>1.448</b>
<b>Min</b>	<b>1.3765</b>
<b>Avg</b>	<b>1.4123</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R2[573] BU 5584

Substation No/ Name :- 334044 / 33/11 KV SHANIMANDAL

Feeder No / Name : 201 / 11 KV AKHATWADE MIX Sheddable Rural/Mix Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.7362					
3				.7011			
5						.6588	
6		1.3272		.8842	.8383		
7	1.5424	1.4899					
8	1.869	1.2269	.7619	.7421		.6878	.6447
9	1.9662					.631	
10		1.3443		.5407			
11	1.7814	1.0883			.4696		
12	1.6194		.39	.3978		.4527	.5426
13					.3768		
14							.4534
15		1.1498					
16	1.6518	1.2323	.4024		.503	.6068	.5636
17		1.1984		.5087			.547
19				.7373			
20	1.0682	1.0576	.724	.6241	.691	.591	.7602
21		.8745			.5316		
23		.547			.3467		
24		.7628		.5144	.3294		.3641
Max	1.9662	1.4899	.7619	.8842	.8383	.6878	.7602
Min	1.0682	.547	.39	.3978	.3294	.4527	.3641
Avg	1.6426	1.0796	.5696	.6278	.5108	.6047	.5537

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R2[573] BU 5584

Substation No/ Name :- 970002 / 132KV DONDAICHA

Feeder No / Name : 202 / 11KV SHANIMANDAL FEEDER  
Feeder KV- 11 / OUTGOING

Sheddable Rural/Mix Feeder

DATE	26-JUN-17
HR	Load (MW)
8	.6626
Max	.6626
Min	.6626
Avg	.6626

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-U[220] BU 0591

Substation No/ Name :- 334001 / 33/11 KV NEHARU NAGAR SS

Feeder No / Name : 202 / NANDURBAR Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.8267			
2						1.9342	
6				1.9163		2.0058	2.1765
9						1.8642	1.8267
10	2.1312						
12				2.009	2.1357	2.0271	2.2443
15	2.6684						
17						1.7193	
18		2.4714	2.0814	1.9387	1.9845		
20		2.6505	2.364	2.1399		2.4356	
24			2.1491			1.9342	
Max	2.6684	2.6505	2.364	2.1399	2.1357	2.4356	2.2443
Min	2.1312	2.4714	2.0814	1.8267	1.9845	1.7193	1.8267
Avg	2.3998	2.5610	2.1982	1.9661	2.0601	1.9886	2.0825

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-U[220] BU 0591

Substation No/ Name :- 334001 / 33/11 KV NEHARU NAGAR SS

Feeder No / Name : 203 / ZARALI Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.5043			
2						1.5043	
6				1.6834		1.7193	1.701
9						1.6278	1.5546
10	1.7013						
12				1.4899	1.5775	1.4842	1.5203
15	1.773						
18	1.7918	1.6476	1.3969	1.3169	1.4883		
20	1.9547	1.9185	1.7013	1.5729		1.4148	
24			1.6834			1.5203	
<b>Max</b>	<b>1.9547</b>	<b>1.9185</b>	<b>1.7013</b>	<b>1.6834</b>	<b>1.5775</b>	<b>1.7193</b>	<b>1.701</b>
<b>Min</b>	<b>1.7013</b>	<b>1.6476</b>	<b>1.3969</b>	<b>1.3169</b>	<b>1.4883</b>	<b>1.4148</b>	<b>1.5203</b>
<b>Avg</b>	<b>1.8052</b>	<b>1.7831</b>	<b>1.5939</b>	<b>1.5135</b>	<b>1.5329</b>	<b>1.5451</b>	<b>1.5920</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-U[220] BU 0591

Substation No/ Name :- 334001 / 33/11 KV NEHARU NAGAR SS

Feeder No / Name : 204 / B & C FEEDER Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.0136			
2						.8954	
6				.9313		.9492	1.1203
9						1.0349	.9877
10	1.1999						
12				.961	.9979	.8596	.9877
15	1.1999						
17						.7701	
18	1.134	1.0059	.9511	.8775	.9511		
20	1.3032	1.2803	1.1888	1.0719		1.1104	
24			1.1641			.9313	
Max	1.3032	1.2803	1.1888	1.0719	.9979	1.1104	1.1203
Min	1.134	1.0059	.9511	.8775	.9511	.7701	.9877
Avg	1.2093	1.1431	1.1013	.9711	.9745	.9358	1.0319

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-U[220] BU 0591

Substation No/ Name :- 334001 / 33/11 KV NEHARU NAGAR SS

Feeder No / Name : 205 / Panchayat Samiti Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.8596			
2						.7964	
6				.8145			.9465
9						.8686	1.0164
10	1.0029						
12				.9036	1.0059	1.0059	1.2803
16	1.1999						
17						.8417	
18	1.0242	1.1523	1.0425	.8501	.985		
20	1.2803	1.3717	1.2254	1.1088		.9671	
24			.985			.8596	
<b>Max</b>	<b>1.2803</b>	<b>1.3717</b>	<b>1.2254</b>	<b>1.1088</b>	<b>1.0059</b>	<b>1.0059</b>	<b>1.2803</b>
<b>Min</b>	<b>1.0029</b>	<b>1.1523</b>	<b>.985</b>	<b>.8145</b>	<b>.985</b>	<b>.7964</b>	<b>.9465</b>
<b>Avg</b>	<b>1.1268</b>	<b>1.262</b>	<b>1.0843</b>	<b>.9073</b>	<b>.9955</b>	<b>.8899</b>	<b>1.0811</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-U[220] BU 0591

Substation No/ Name :- 334001 / 33/11 KV NEHARU NAGAR SS

Feeder No / Name : 206 / Water Supply

EHV Express Water works

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1441			
2						.1218	
6				.1469		.1397	.1379
9						.1276	.1471
10	.19						
12				.1361	.0627	.1875	.2197
15	.2239						
17						.1164	
18	.1666	.1471	.0771	.0752			
20	.1069	.0771	.1223	.1325		.0806	
24			.0985			.1039	
Max	.2239	.1471	.1223	.1469	.0627	.1875	.2197
Min	.1069	.0771	.0771	.0752	.0627	.0806	.1379
Avg	.1719	.1121	.0993	.1270	.0627	.1254	.1682

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-U[220] BU 0591

Substation No/ Name :- 334001 / 33/11 KV NEHARU NAGAR SS

Feeder No / Name : 209 / 11 KV ITI Express Feeder Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0036			
2						.0036	
6				.0036		.0036	.003
9						.0036	.0035
12				.0014	.0045	.0105	.0175
17						.0072	
18	.0071	.007	.0035	.0035	.0043		
20	.0053	.0035	.0035	.0053		.0054	
24			.0036			.0036	
Max	.0071	.007	.0036	.0053	.0045	.0105	.0175
Min	.0053	.0035	.0035	.0014	.0043	.0036	.003
Avg	.0062	.0053	.0035	.0035	.0044	.0054	.008

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-U[220] BU 0591

Substation No/ Name :- 334001 / 33/11 KV NEHARU NAGAR SS

Feeder No / Name : 210 / 11 Kv Shirishkumar Mehta Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.6089			
2						.6447	
6				.8059		.9313	.7964
9						.6036	.6335
10	.636						
12				.5853	.4755	.5068	
13							.5611
15	.693						
17						.4656	
18	.6154		.5249	.5914	.5792		
20	.6516	.7421	.7059	.6767		.6268	
24			.6447			.6447	
Max	.693	.7421	.7059	.8059	.5792	.9313	.7964
Min	.6154	.7421	.5249	.5853	.4755	.4656	.5611
Avg	.649	.7421	.6252	.6536	.5274	.6319	.6637

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-U[220] BU 0591

Substation No/ Name :- 334036 / 33/11 KV EKTA NAGAR SS

Feeder No / Name : 201 / 11 KV Kanyadan Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.6516	.7442	.5853	.5068	.7442	.4908	.5731
16	.8145	.6859		.5609	.5014	.4908	.5959
24	.9214	1.0208	.905	.6447	.6805	.6447	.6516
Max	.9214	1.0208	.905	.6447	.7442	.6447	.6516
Min	.6516	.6859	.5853	.5068	.5014	.4908	.5731
Avg	.7958	.8170	.7452	.5708	.6420	.5421	.6069

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-U[220] BU 0591

Substation No/ Name :- 334036 / 33/11 KV EKTA NAGAR SS

Feeder No / Name : 202 / 11 KV Sindhi Colony Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.6556	.703	.6767	.6805	.631	.6379	.6767
16	.7522	.7265	.5014	.6626	.6447	.6584	.6089
24	1.0974	1.1041	.9511	.7783	.7164	.7701	.695
Max	1.0974	1.1041	.9511	.7783	.7164	.7701	.695
Min	.6556	.703	.5014	.6626	.631	.6379	.6089
Avg	.8351	.8445	.7097	.7071	.6640	.6888	.6602

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-U[220] BU 0591

Substation No/ Name :- 334036 / 33/11 KV EKTA NAGAR SS

Feeder No / Name : 203 / 11 KV Namskar Colony Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.8238	.7545	.6516	.7087	.6135	.6805	.6556
16	.8669	.5487	.4887	.5375	.6626	.5493	.6001
24	.9694	.9877	.8962	.724	.6516	.7316	.6805
Max	.9694	.9877	.8962	.724	.6626	.7316	.6805
Min	.8238	.5487	.4887	.5375	.6135	.5493	.6001
Avg	.8867	.7636	.6788	.6567	.6426	.6538	.6454

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334003 / VISARWADI

Feeder No / Name : 201 / MORKARANJA

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	26-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)
12		.6478
16	.6802	.4858
<b>Max</b>	<b>.6802</b>	<b>.6478</b>
<b>Min</b>	<b>.6802</b>	<b>.4858</b>
<b>Avg</b>	<b>.6802</b>	<b>.5668</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334003 / VISARWADI

Feeder No / Name : 202 / KADWAN

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	24-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.8907		.4858	.8097
12	1.4575			.6859	
16				.6859	
24			.4372	.3887	.4049
Max	1.4575	.8907	.4372	.6859	.8097
Min	1.4575	.8907	.4372	.3887	.4049
Avg	1.4575	.8907	.4372	.5616	.6073

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334003 / VISARWADI

Feeder No / Name : 203 / CHINCHPADA

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.4049		.6478	.8097
16			.8907	
24		.3401	.2753	.4049
Max	.4049	.3401	.8907	.8097
Min	.4049	.3401	.2753	.4049
Avg	.4049	.3401	.6046	.6073

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334003 / VISARWADI

Feeder No / Name : 204 / Chitvi

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.6194		.9717			
8	1.6194	1.3765				
12			.4858	.6478		.8097
16					.5668	.4858
24	1.3765		.6478	.6478		
Max	1.6194	1.3765	.9717	.6478	.5668	.8097
Min	1.3765	1.3765	.4858	.6478	.5668	.4858
Avg	1.5384	1.3765	.7018	.6478	.5668	.6478

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334003 / VISARWADI

Feeder No / Name : 205 / VADKUT

Feeder KV- 11 / OUTGOING

Sheddable Rural/Mix Feeder

DATE	22-JUN-17	26-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
8			.6478
12	1.7004		
16	1.2146		
24		.1619	.4858
Max	1.7004	.1619	.6478
Min	1.2146	.1619	.4858
Avg	1.4575	.1619	.5668

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334003 / VISARWADI

Feeder No / Name : 206 / morkaranja gavthan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.6478	.7287	.4858			
8				.4858	.5668	.4858
12			.3239	.4858	.5668	.5182
16			.3239	.5668	.4858	.4858
20		.5668	.4858	.5668		.5344
24	.7287	.6478	.4049		.5668	.4049
<b>Max</b>	<b>.7287</b>	<b>.7287</b>	<b>.4858</b>	<b>.5668</b>	<b>.5668</b>	<b>.5344</b>
<b>Min</b>	<b>.6478</b>	<b>.5668</b>	<b>.3239</b>	<b>.4858</b>	<b>.4858</b>	<b>.4049</b>
<b>Avg</b>	<b>.6883</b>	<b>.6478</b>	<b>.4049</b>	<b>.5263</b>	<b>.5466</b>	<b>.4858</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334003 / VISARWADI

Feeder No / Name : 207 / Visarwadi gavthan  
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
8	.6478	.8097	.6478
12	.6478	.7287	.7287
16	.6478	.7287	.7287
20	.7287		.7773
24		.6478	.6478
<b>Max</b>	<b>.7287</b>	<b>.8097</b>	<b>.7773</b>
<b>Min</b>	<b>.6478</b>	<b>.6478</b>	<b>.6478</b>
<b>Avg</b>	<b>.6680</b>	<b>.7287</b>	<b>.7061</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334003 / VISARWADI

Feeder No / Name : 208 / chitvi gavthan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	24-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.7287	.7287			
8			.6478	.7773	.7287
12		.5668	.6154	.5668	.7287
16			.6478	.6478	.7287
20	.6478	.7287	.7287		.8097
24	.8097	.5668		.6478	.6478
<b>Max</b>	<b>.8097</b>	<b>.7287</b>	<b>.7287</b>	<b>.7773</b>	<b>.8097</b>
<b>Min</b>	<b>.6478</b>	<b>.5668</b>	<b>.6154</b>	<b>.5668</b>	<b>.6478</b>
<b>Avg</b>	<b>.7287</b>	<b>.6478</b>	<b>.6599</b>	<b>.6599</b>	<b>.7287</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334003 / VISARWADI

Feeder No / Name : 209 / chinchpada gavthan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	24-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.6478				
8			.6478	.6478	.7287
12		.4858	.4858	.6478	.7287
16	.6478	.4858	.5668	.6478	.7287
20	.7287	.7287	.4858		.6802
24	.7287	.5668		.5668	.5668
<b>Max</b>	<b>.7287</b>	<b>.7287</b>	<b>.6478</b>	<b>.6478</b>	<b>.7287</b>
<b>Min</b>	<b>.6478</b>	<b>.4858</b>	<b>.4858</b>	<b>.5668</b>	<b>.5668</b>
<b>Avg</b>	<b>.6883</b>	<b>.5668</b>	<b>.5466</b>	<b>.6276</b>	<b>.6866</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334003 / VISARWADI

Feeder No / Name : 210 / HALDANI AG FEEDER  
Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	26-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)
12		.4858
16	.6478	.4858
24	.6478	
Max	.6478	.4858
Min	.6478	.4858
Avg	.6478	.4858

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334006 / NAVAPUR

Feeder No / Name : 201 / NAVAPUR Light Bazar Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	2.0538	2.1098	2.0165	1.7177	1.8671	1.5497	1.4022
8	2.0538	2.0351	1.9044		1.8671		1.8671
12	2.0165	1.9978	1.7551	1.8298		2.0538	1.9231
16	1.9791	2.1658	1.7177	1.7924	1.4563	1.7551	1.4022
20	2.1472	2.3152	1.9231	1.9044	2.2405	1.9418	
24	2.2779	1.9418	2.1098	1.8111	1.8671	1.8484	1.7737
Max	2.2779	2.3152	2.1098	1.9044	2.2405	2.0538	1.9231
Min	1.9791	1.9418	1.7177	1.7177	1.4563	1.5497	1.4022
Avg	2.0881	2.0943	1.9044	1.8111	1.8596	1.8298	1.6737

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334006 / NAVAPUR

Feeder No / Name : 203 / NAVAGAON

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4			.5335	.3048	.3048	.3048
8			1.0669	.6097	.6706	.7621
12		.945				
16		.7316				
20	1.0669					
24			.5335	.2743	.2896	.3048
Max	1.0669	.945	1.0669	.6097	.6706	.7621
Min	1.0669	.7316	.5335	.2743	.2896	.3048
Avg	1.0669	.8383	.7113	.3963	.4217	.4572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334006 / NAVAPUR

Feeder No / Name : 204 / prabhakar colony

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.8215	.8402	.5601	.5228	.9496	1.1629	.9496
8	1.0082	.9335	.5601	.4481	.9496	1.0852	1.0852
12	.8215	.5228	.4481	.5601	.442	1.0173	.8817
16		.5601	.5041	.4854	.9496	1.0173	.8817
20	.9149	.8215	.5975	.5601	1.0852	1.153	.5601
23						.4268	
24	.8215	.8215	.6348	.4268	1.1629	.9545	.9496
Max	1.0082	.9335	.6348	.5601	1.1629	1.1629	1.0852
Min	.8215	.5228	.4481	.4268	.442	.4268	.5601
Avg	.8775	.7499	.5508	.5006	.9232	.9739	.8847

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334006 / NAVAPUR

Feeder No / Name : 205 / nawagoan gauthan

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.8962	.8775		.8029	.7712	.7095	.6661
12			.6348				
16			.6722	.7095	.4908	.631	.6135
20	.8962	1.0642	.7842	.8215	.8238	.7712	.6661
24	.8962	.9149	.9335	.7468	.7712	.7537	.6661
<b>Max</b>	<b>.8962</b>	<b>1.0642</b>	<b>.9335</b>	<b>.8215</b>	<b>.8238</b>	<b>.7712</b>	<b>.6661</b>
<b>Min</b>	<b>.8962</b>	<b>.8775</b>	<b>.6348</b>	<b>.7095</b>	<b>.4908</b>	<b>.631</b>	<b>.6135</b>
<b>Avg</b>	<b>.8962</b>	<b>.9522</b>	<b>.7562</b>	<b>.7702</b>	<b>.7143</b>	<b>.7164</b>	<b>.6530</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334006 / NAVAPUR

Feeder No / Name : 207 / SAVARAT AG FEEDER

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.0974	.9755				
8	1.1584	1.2955				
12			.7011		.4572	.7926
16			.5487		.5487	.7316
23			.7011			
24	1.0059	.9602	.4572	.6859		
Max	1.1584	1.2955	.7011	.6859	.5487	.7926
Min	1.0059	.9602	.4572	.6859	.4572	.7316
Avg	1.0872	1.0771	.6020	.6859	.5030	.7621

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334006 / NAVAPUR

Feeder No / Name : 208 / 11 KV Kumbharwada U Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.307	1.2696	1.1203	.9709	1.0456	.8775	.9709
8	1.307	1.4003	1.1949	1.1949		1.1576	1.307
12	1.5497		1.1576	1.307			1.1389
16	1.531	1.419	1.0829	1.0082	1.1203	1.1949	1.1949
20	1.4377	1.4937	1.1576	1.1576	1.0642	1.0456	
24	1.3443	1.307	1.2323	.9522	.9709	.9149	1.0082
Max	1.5497	1.4937	1.2323	1.307	1.1203	1.1949	1.307
Min	1.307	1.2696	1.0829	.9522	.9709	.8775	.9709
Avg	1.4128	1.3779	1.1576	1.0985	1.0503	1.0381	1.1240

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334019 / KHANDBARA

Feeder No / Name : 202 / 11 KV MOGRANI AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	25-JUN-17
HR	Load (MW)	Load (MW)
1	.7621	
2	.7621	
18		.2286
24	.6706	
Max	.7621	.2286
Min	.6706	.2286
Avg	.7316	.2286

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334019 / KHANDBARA

Feeder No / Name : 203 / 11 KV BARDIPADA MIX Sheddable Rural/Mix Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.5182	.5182	.3963	
2	.381	.5182	.4877	.3963	.3353
24	.4268	.6097	.5792	.3658	
Max	.4268	.6097	.5792	.3963	.3353
Min	.381	.5182	.4877	.3658	.3353
Avg	.3963	.5487	.5284	.3861	.3353

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334019 / KHANDBARA

Feeder No / Name : 204 / 11 KV MOGRANI GAVTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4572	.4877	.4268			
2	.4572	.4572	.4572	.4268			
5				.4572	.4268	.3658	.4268
23				.4877			
24	.4572	.4572	.4572	.3963			
Max	.4572	.4572	.4877	.4877	.4268	.3658	.4268
Min	.4572	.4572	.4572	.3963	.4268	.3658	.4268
Avg	.4572	.4572	.4674	.4390	.4268	.3658	.4268

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334019 / KHANDBARA

Feeder No / Name : 207 / 11 KV SHRAWANI GAVTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.3048	.3353	.3048			
2	.3353	.3353	.3506	.3048			
5				.4458	.3353	.3353	.3353
24	.3353	.3353	.3658	.2743			
Max	.3353	.3353	.3658	.4458	.3353	.3353	.3353
Min	.3353	.3048	.3353	.2743	.3353	.3353	.3353
Avg	.3353	.3251	.3506	.3324	.3353	.3353	.3353

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334023 / RAIPUR

Feeder No / Name : 201 / NAVAPUR AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.2742	.1677			
8	1.073	.1905			
16			.1677	.1174	.503
24	.8886	.0838	.5935		
Max	1.2742	.1905	.5935	.1174	.503
Min	.8886	.0838	.1677	.1174	.503
Avg	1.0786	.1473	.3806	.1174	.503

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334023 / RAIPUR

Feeder No / Name : 202 / UKALPANI AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.1401	1.0395			
8	1.5089				
12				.1341	.3521
16			.3521	.1006	
24	.788	.9389	.4748		
Max	1.5089	1.0395	.4748	.1341	.3521
Min	.788	.9389	.3521	.1006	.3521
Avg	1.1457	.9892	.4135	.1174	.3521

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334023 / RAIPUR

Feeder No / Name : 203 / CHAUKI

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4				.1677	.1677
8			.1865	.4024	.4527
12	1.5089				
16	1.7101	.4917			
24				.1677	.1174
<b>Max</b>	<b>1.7101</b>	<b>.4917</b>	<b>.1865</b>	<b>.4024</b>	<b>.4527</b>
<b>Min</b>	<b>1.5089</b>	<b>.4917</b>	<b>.1865</b>	<b>.1677</b>	<b>.1174</b>
<b>Avg</b>	<b>1.6095</b>	<b>.4917</b>	<b>.1865</b>	<b>.2459</b>	<b>.2459</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334023 / RAIPUR

Feeder No / Name : 204 / NAVAPUR GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.3506	.4382		.3506	.2629	
16	.3506	.2629	.2804	.3012		.2629
20	.4557	.2629	.3856	.3155		.3506
24	.298	.4382		.3856	.2629	
Max	.4557	.4382	.3856	.3856	.2629	.3506
Min	.298	.2629	.2804	.3012	.2629	.2629
Avg	.3637	.3506	.333	.3382	.2629	.3068

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334023 / RAIPUR

Feeder No / Name : 205 / UKALAPANI GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.2629	.4382		.3506	.2629	
16	.3506	.2629	.298	.2804		.2629
20	.4557	.2629	.3856	.3155		.3506
24	.3155	.4382	.2629	.3856	.2454	
Max	.4557	.4382	.3856	.3856	.2629	.3506
Min	.2629	.2629	.2629	.2804	.2454	.2629
Avg	.3462	.3506	.3155	.3330	.2542	.3068

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334023 / RAIPUR

Feeder No / Name : 206 / MORTHUWA AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	25-JUN-17	26-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4			.1677	.1006
8			.4024	.3353
12	.8383	.4239		
16	1.2574	.5596		
24			.1006	.1006
Max	1.2574	.5596	.4024	.3353
Min	.8383	.4239	.1006	.1006
Avg	1.0479	.4918	.2236	.1788

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334029 / BILBARA

Feeder No / Name : 203 / dokare gavthan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	1.1458	1.1088		1.2567	.9425	.9979
11	.6805	.5552		.7522	.7442	
15			.6733			
16				.7602	.9412	
18		.8596				
19			.9877			
20	1.1584			1.0974	.9328	
24	1.1088	1.1088	1.1088	1.0903	1.0719	.9335
Max	1.1584	1.1088	1.1088	1.2567	1.0719	.9979
Min	.6805	.5552	.6733	.7522	.7442	.9335
Avg	1.0234	.9081	.9233	.9914	.9265	.9657

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334029 / BILBARA

Feeder No / Name : 205 / 11KV KELPADA FEEDER

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	1.2955	1.0669			
11			.1467	.2743	.2134
16				.1677	.3048
24	.9907	.7621			
Max	1.2955	1.0669	.1467	.2743	.3048
Min	.9907	.7621	.1467	.1677	.2134
Avg	1.1431	.9145	.1467	.221	.2591

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334029 / BILBARA

Feeder No / Name : 206 / 11 KV New Dokare AG Feeder Ag dominated/Pure Ag  
Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6			.4515	.381	.5182
8		.4268			
18	.4694				
24		.2347	.2675	.2675	.2347
Max	.4694	.4268	.4515	.381	.5182
Min	.4694	.2347	.2675	.2675	.2347
Avg	.4694	.3308	.3595	.3243	.3765

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334043 / NAVAPUR MIDC 33/11 KV Sstn

Feeder No / Name : 201 / 11 kv shaym sunder

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.9259	
4						.9088	
5	1.2346	1.166		.7964			
8	1.6632	1.6975		.7011		1.5947	1.6804
12	1.5432				1.286	1.5089	1.7318
16	1.6461	1.5432	.5144		1.5604	1.5089	1.749
20	1.4403	1.2517	1.0802		1.1488	1.3717	1.2346
23			.7545				1.3213
24	1.3375		1.0631	.7888	1.0631		1.3375
Max	1.6632	1.6975	1.0802	.7964	1.5604	1.5947	1.749
Min	1.2346	1.166	.5144	.7011	1.0631	.9088	1.2346
Avg	1.4775	1.4146	.8531	.7621	1.2646	1.3032	1.5091

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334043 / NAVAPUR MIDC 33/11 KV Sstn

Feeder No / Name : 202 / 11 kv kolda Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5				.4525			
8				.4287			.5144
12		.823				.3772	
16	2.5892	1.1488			.6859	.4115	
18	1.8347						
20			.463				
23			.4287				.2715
24			.4801	.3429			.2058
Max	2.5892	1.1488	.4801	.4525	.6859	.4115	.5144
Min	1.8347	.823	.4287	.3429	.6859	.3772	.2058
Avg	2.2120	.9859	.4573	.4080	.6859	.3944	.3306

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334043 / NAVAPUR MIDC 33/11 KV Sstn

Feeder No / Name : 204 / RTO EXPRESS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.0514	
4						.0343	
5	.0514	.0686	.0514	.0362			
8	.0343	.0171	.0181	.0351		.0343	.0171
12	.0171	.0343	.0175		.0171	.0343	.0343
16	.0343	.0343	.0171		.0343	.0343	.0171
20	.0514	.0514	.0514		.0514	.0514	.0514
23			.0514				.0543
24	.0514		.0514	.0514	.0514		.0514
Max	.0514	.0686	.0514	.0514	.0514	.0514	.0543
Min	.0171	.0171	.0171	.0351	.0171	.0343	.0171
Avg	.0400	.0411	.0369	.0409	.0386	.04	.0376

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334043 / NAVAPUR MIDC 33/11 KV Sstn

Feeder No / Name : 205 / Wadkut Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.5487	
4						.5487	
5	.6173	.6173		.4525			
8				.3681			
16	.4458	.4801			.463	.4287	.3601
20	.6173	.583	.5316		.5144	.6173	.6173
23			.5144				.6335
24	.6344		.6516	.4458	.5487		.6001
Max	.6344	.6173	.6516	.4525	.5487	.6173	.6335
Min	.4458	.4801	.5144	.3681	.463	.4287	.3601
Avg	.5787	.5601	.5659	.4221	.5087	.5359	.5528

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334043 / NAVAPUR MIDC 33/11 KV Sstn

Feeder No / Name : 206 / AGRASEN IND Express SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.0514	
4						.0514	
5	.0514	.0686	.0362	.0343			
8	.0857	.0857	.0686	.0701		.1029	.1029
12	.0514	.0857	.0857		.0686	.0686	.1029
16	.1029	.0857	.1029		.1029	.1029	.12
20	.1029	.0686	.0686		.0686	.0686	.1029
23			.0343				.0686
24	.0857		.0343	.0343	.0514		.0686
Max	.1029	.0857	.1029	.0701	.1029	.1029	.12
Min	.0514	.0686	.0343	.0343	.0514	.0514	.0686
Avg	.08	.0789	.0615	.0462	.0729	.0743	.0943

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334043 / NAVAPUR MIDC 33/11 KV Sstn

Feeder No / Name : 207 / 11 Kv Chokhawala

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.1029	
4						.1029	
5	.2572	.2572	.181	.1448			
8	.2572	.2743	.2229	.1402		.12	.1715
12	.2229		.3258		.2229	.1029	.3086
16	.3772	.2401	.3086		.2058	.2572	.3086
20	.2401	.2229	.2058		.1372	.1715	.0543
23			.1715				.181
24	.2572		.2229	.2229	.1715		.2229
Max	.3772	.2743	.3258	.2229	.2229	.2572	.3086
Min	.2229	.2229	.1715	.1402	.1372	.1029	.0543
Avg	.2686	.2486	.2341	.1693	.1844	.1429	.2078

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334046 / 33 KV KHATGAON SUB STATION

Feeder No / Name : 201 / 11 KV KHATGAON MIX FEEDER Sheddable Rural/Mix Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17
HR	Load (MW)
1	.9145
16	.8326
20	1.2197
24	1.1523
Max	1.2197
Min	.8326
Avg	1.0298

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334046 / 33 KV KHATGAON SUB STATION

Feeder No / Name : 202 / 11 KV KHADAKI MIX FEEDER Sheddable Rural/Mix Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17
HR	Load (MW)
8	1.2936
10	1.2382
<b>Max</b>	<b>1.2936</b>
<b>Min</b>	<b>1.2382</b>
<b>Avg</b>	<b>1.2659</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

AKKALKUWA S/DN.[837] BU 4837

Substation No/ Name :- 334026 / KHAPAR

Feeder No / Name : 201 / 11KV RAISINGPUR AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1562					
2	.1562					
3	.1562					
4	.1562	.1562				
5	.1562					
6	.2343					
7	.2343					
8	.2343	.0695				
11			.0781	.0791	.0781	.0495
12			.0781	.0791	.0791	.0486
13			.0781	.0781	.0781	.0486
14			.0781	.0781	.0781	.0486
15				.0772	.0781	.0429
16				.0762	.0781	.04
17				.0743	.0781	.04
18					.0781	.0352
23		.1562				
24		.1486				
Max	.2343	.1562	.0781	.0791	.0791	.0495
Min	.1562	.0695	.0781	.0743	.0781	.0352
Avg	.1855	.1326	.0781	.0774	.0782	.0442

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

AKKALKUWA S/DN.[837] BU 4837

Substation No/ Name :- 334026 / KHAPAR

Feeder No / Name : 202 / 11KV NAVAPADA AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0781
2				.0781
3				.0781
4			.0705	.0781
5				.0781
6				.0781
8			.0619	.1562
11	.1562			
18	.1562			
23		.0714	.0781	
24			.0781	.0781
Max	.1562	.0714	.0781	.1562
Min	.1562	.0714	.0619	.0781
Avg	.1562	.0714	.0722	.0879

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

AKKALKUWA S/DN.[837] BU 4837

Substation No/ Name :- 334026 / KHAPAR

Feeder No / Name : 203 / 11KV KHAPAR AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086					
2	.3086					
3	.3086					
4	.463	.2972				
5	.463					
6	.463					
7	.6173					
8	.6173					
11			.0781		.0781	.0991
12			.0781	.1543	.0781	.0972
13			.0781	.1543	.0781	.0972
14			.0781	.1486	.0781	.0914
15				.0743	.1562	
16				.0743	.0781	
17				.0714	.1562	.08
18					.1562	.0686
23		.1562				
24	.3086	.3125				
Max	.6173	.3125	.0781	.1543	.1562	.0991
Min	.3086	.1562	.0781	.0714	.0781	.0686
Avg	.4287	.2553	.0781	.1129	.1074	.0889

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

AKKALKUWA S/DN.[837] BU 4837

Substation No/ Name :- 334026 / KHAPAR

Feeder No / Name : 204 / 11KV KHAPAR GAONTHAN  
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3201				.3041		.3094
2	.3254				.2987		.3041
3	.3094				.2987		.2934
4	.2987	.2778		.2881	.2934	.2778	.2827
5	.3041				.3094		.2881
6	.3201				.3147		.3254
7	.2934				.3467		
8	.2614	.2932		.2778	.3041	.2881	.3094
9		.2721		.2667	.2984	.3041	.2881
10		.2827		.2987	.2675	.2667	.2778
11		.2614		.2721	.2507	.2934	.2623
12		.2614		.2721	.2418	.2774	.2521
13		.2454		.2561	.2366	.2721	.2469
14		.2614		.2614	.2263	.2667	.2572
15		.2561			.2469	.2401	.2366
16		.2667			.2418	.2507	.2623
17		.2561			.2675	.2401	.2726
18		.3094				.2881	.3035
19		.3201		.3948	.3035	.3307	.3241
20		.3521		.3628	.3447	.3681	.3549
21		.3628		.3681		.3521	
22		.3307		.3307		.3307	
23		.2987		.3094	.3086	.3094	
24	.2987	.3138	.3189	.3189	.2881	.2675	.2934
Max	.3254	.3628	.3189	.3948	.3467	.3681	.3549
Min	.2614	.2454	.3189	.2561	.2263	.2401	.2366
Avg	.3035	.2901	.3189	.3056	.2853	.2902	.2872

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

AKKALKUWA S/DN.[837] BU 4837

Substation No/ Name :- 334026 / KHAPAR

Feeder No / Name : 205 / 11KV NAVAPADA GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2075		.2263
2				.1949		.2138
3				.1823		.2075
4	.2138		.1823	.1886	.2138	.2012
5				.2138		.2075
6				.2012		.2263
7				.1823		
8	.1823		.176	.176	.2075	.176
9	.1886		.1635	.176	.1572	.1698
10	.1823		.1698	.176	.1446	.1635
11	.1572		.1572	.1698	.088	.1635
12			.1823	.176	.0189	.1823
13	.0251		.176		.0251	.1635
14	.0377		.1572		.0251	.1572
15	.0377				.1698	.1823
16				.176	.176	.176
17				.1509	.1635	.1635
18	.1446				.176	.1823
19	.1509			.2326	.2012	.2326
20	.176		.2389	.2578	.8383	.2578
21	.2263		.2578		.2641	
22	.2138		.2263		.2263	
23	.2012		.2452	.2452	.2263	
24	.2641	.2452	.2201	.2138	.2389	.2201
Max	.2641	.2452	.2578	.2578	.8383	.2578
Min	.0251	.2452	.1572	.1509	.0189	.1572
Avg	.1601	.2452	.1964	.1956	.1978	.1937

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

AKKALKUWA S/DN.[837] BU 4837

Substation No/ Name :- 334026 / KHAPAR

Feeder No / Name : 206 / 11KV RAISINGPUR GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381				.4382		.4382
2	.3239				.362		.4001
3	.3429				.362		.381
4	.2858	.3429		.3429	.3429	.3429	.4001
5	.381				.362		.362
6	.4954				.4572		.5335
7	.4001				.381		
8	.4001			.3429	.3239	.3429	.362
9		.381		.2858	.3239	.2858	.3429
10		.3429		.3239	.3239	.2286	.2858
11		.381			.2858	.2477	.2858
12		.3239		.3429	.3048	.2858	.2667
13				.362	.2477	.362	.2667
14				.362	.2477	.3429	.3048
15						.3048	.2667
16					.2667	.362	.3048
17						.4001	.3239
18						.381	.4191
19		.4382		.4191	.4954	.4001	.5335
20		.5335		.4572	.5525	.5335	.5525
21		.5525		.4382		.5335	
22		.5525		.4382		.4954	
23		.4954		.4191	.4382	.4954	
24	.4382	.4763	.4382	.4382	.4001	.4572	.4763
Max	.4954	.5525	.4382	.4572	.5525	.5335	.5525
Min	.2858	.3239	.4382	.2858	.2477	.2286	.2667
Avg	.3832	.4382	.4382	.3825	.3640	.3779	.3753

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

AKKALKUWA S/DN.[837] BU 4837

Substation No/ Name :- 334026 / KHAPAR

Feeder No / Name : 207 / 11KV PORAMBI AG

Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
3			.0686
4		.0714	.0686
5			.0619
6			.0619
8		.0648	.0648
23	.0686		
24		.0791	
<b>Max</b>	<b>.0686</b>	<b>.0791</b>	<b>.0686</b>
<b>Min</b>	<b>.0686</b>	<b>.0648</b>	<b>.0619</b>
<b>Avg</b>	<b>.0686</b>	<b>.0718</b>	<b>.0652</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

AKKALKUWA S/DN.[837] BU 4837

Substation No/ Name :- 334026 / KHAPAR

Feeder No / Name : 208 / 11KV MORMBA AG

Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	25-JUN-17	26-JUN-17	27-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.0781	
2		.0781	
3		.0781	
4	.0781	.0781	.0743
5		.0781	
6		.0781	
7		.0781	
8	.0743	.0781	.0743
23			.0781
24		.0781	.0762
<b>Max</b>	<b>.0781</b>	<b>.0781</b>	<b>.0781</b>
<b>Min</b>	<b>.0743</b>	<b>.0781</b>	<b>.0743</b>
<b>Avg</b>	<b>.0762</b>	<b>.0781</b>	<b>.0757</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

AKKALKUWA S/DN.[837] BU 4837

Substation No/ Name :- 334030 / HORAFALI

Feeder No / Name : 202 / 11KV HORAFALI

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.8573	.6859
2				.9431	.7716
3				.8573	.9431
4				1.0288	.9431
5				.9431	.9431
6				1.0288	1.0288
7				1.0288	
8				1.0288	1.0288
19	.5144				
20	.6859	.9431			
21	.5144	.8573	.7716	.8573	
22	.5144		.7716	.8573	
23	.5144		.8573	.7716	
24		.5144		.8573	.7716
Max	.6859	.9431	.8573	1.0288	1.0288
Min	.5144	.5144	.7716	.7716	.6859
Avg	.5487	.7716	.8002	.9216	.8895

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

DHADGAON S/DN.[838] BU 4838

Substation No/ Name :- 334017 / 33/11KV Dhadgaon

Feeder No / Name : 201 / 11KV Dhadgaon

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.0876		
8				.7316
12	.0895	.6401		
16			.6554	
18	.0914	.6554		
24	.0724	.0762		.6401
<b>Max</b>	<b>.0914</b>	<b>.6554</b>	<b>.6554</b>	<b>.7316</b>
<b>Min</b>	<b>.0724</b>	<b>.0762</b>	<b>.6554</b>	<b>.6401</b>
<b>Avg</b>	<b>.0844</b>	<b>.3648</b>	<b>.6554</b>	<b>.6859</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

DHADGAON S/DN.[838] BU 4838

Substation No/ Name :- 334017 / 33/11KV Dhadgaon

Feeder No / Name : 202 / 11KV Chulwad

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.2896	.3658
12	.0362			
16			.3201	
18	.0476	.381		
24	.0362		.3201	.2896
Max	.0476	.381	.3201	.3658
Min	.0362	.381	.2896	.2896
Avg	.04	.381	.3099	.3277

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

DHADGAON S/DN.[838] BU 4838

Substation No/ Name :- 334017 / 33/11KV Dhadgaon

Feeder No / Name : 203 / 11 kv Surwani

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.0267		
8			.2134	
12		.1981		
16				.1677
18	.0438	.2286		
24	.0286	.0248	.2439	.2286
Max	.0438	.2286	.2439	.2286
Min	.0286	.0248	.2134	.1677
Avg	.0362	.1196	.2287	.1982

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

DHADGAON S/DN.[838] BU 4838

Substation No/ Name :- 334017 / 33/11KV Dhadgaon

Feeder No / Name : 204 / 11KV Son feeder

Feeder KV- 11 / OUTGOING

Sheddable Rural/Mix Feeder

DATE	25-JUN-17	26-JUN-17	27-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
8			.2439
12	.0686	.1829	
16			.1829
18	.0438	.1981	
24	.0324		.2439
<b>Max</b>	<b>.0686</b>	<b>.1981</b>	<b>.2439</b>
<b>Min</b>	<b>.0324</b>	<b>.1829</b>	<b>.1829</b>
<b>Avg</b>	<b>.0483</b>	<b>.1905</b>	<b>.2236</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

DHADGAON S/DN.[838] BU 4838

Substation No/ Name :- 334017 / 33/11KV Dhadgaon

Feeder No / Name : 205 / 11KV Rajbardi feeder Sheddable Rural/Mix Feeder  
Feeder KV- 11 / OUTGOING

DATE	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.0438		
8				.3963
12	.0457			
14		.3963		
16			.2439	
18	.0457			
24	.04	.0343		.2896
Max	.0457	.3963	.2439	.3963
Min	.04	.0343	.2439	.2896
Avg	.0438	.1581	.2439	.3430

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

DHADGAON S/DN.[838] BU 4838

Substation No/ Name :- 334017 / 33/11KV Dhadgaon

Feeder No / Name : 206 / 11 KV GOVT ITI EXPRESS

HV Express Feeder

FEEDER Feeder KV- 11 / OUTGOING

DATE	26-JUN-17
HR	Load (MW)
18	.0152
Max	.0152
Min	.0152
Avg	.0152

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

DHADGAON S/DN.[838] BU 4838

Substation No/ Name :- 334017 / 33/11KV Dhadgaon

Feeder No / Name : 207 / 11 KV UMRANI

Feeder KV- 11 / OUTGOING

Sheddable Rural/Mix Feeder

DATE	25-JUN-17	26-JUN-17	27-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
6		.0248	
8			.2439
12		.2134	
16			.2286
18	.0362	.2134	
24		.0191	.1829
<b>Max</b>	<b>.0362</b>	<b>.2134</b>	<b>.2439</b>
<b>Min</b>	<b>.0362</b>	<b>.0191</b>	<b>.1829</b>
<b>Avg</b>	<b>.0362</b>	<b>.1177</b>	<b>.2185</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

DHADGAON S/DN.[838] BU 4838

Substation No/ Name :- 334031 / 33/11KV Kakarda

Feeder No / Name : 201 / 11KV Kakarda feeder

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.2328	.2328		.0716	.1075	.1433	.2328
8		.2149		.0716	.1433	.1433	.2507
12	.2865	.2507		.0716	.1433	.1075	.1791
16		.2149			.1433	.1075	.1791
20	.2865	.3403	.0537		.1433	.2686	.0716
23	.394						
24	.2507	.197	.0716	.0716	.1075	.1075	.2149
Max	.394	.3403	.0716	.0716	.1433	.2686	.2507
Min	.2328	.197	.0537	.0716	.1075	.1075	.0716
Avg	.2901	.2418	.0627	.0716	.1314	.1463	.1880

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

DHADGAON S/DN.[838] BU 4838

Substation No/ Name :- 334031 / 33/11KV Kakarda

Feeder No / Name : 202 / 11KV Ghatali Feeder  
Feeder KV- 11 / OUTGOING

Sheddable Rural/Mix Feeder

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.1254	.1254			.2865	.2149	.1433
8	.1254	.1254			.2865	.2328	.1433
12	.1791	.1612		.1433	.2149	.2507	.1433
16		.1612			.3582	.1075	.1075
20	.2149	.1254		.2865	.2865	.197	.197
24	.1612	.1612	.0716		.1612	.1791	.1433
Max	.2149	.1612	.0716	.2865	.3582	.2507	.197
Min	.1254	.1254	.0716	.1433	.1612	.1075	.1075
Avg	.1612	.1433	.0716	.2149	.2656	.197	.1463

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334005 / MANDANA

Feeder No / Name : 202 / 11KV MANDANA GAOTHAN  
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.1715	.1715	.1715	.1715	.1715	.1715
2	.2058	.1715	.1715	.1715	.1715	.1715	.1715
3	.2572	.2058	.2229	.2058	.2058	.2229	.2229
4	.3429	.2058	.2743	.2572	.2572	.2915	.2915
5	.463	.2572	.463	.3086	.4115	.4115	.3772
6	.4801	.4801	.583	.4801	.5144	.4458	.4801
7	.4115	.4115	.5316	.5144	.4115	.3601	.3429
8	.4115	.3772	.3429	.4458	.3429	.2743	.2743
9	.3772	.3772	.3086	.3086	.2915	.2401	.2401
10	.3429	.2743	.3086		.3429	.1715	.2058
11		.2401	.2743		.2572	.1715	.1886
12		.1715	.2401		.2058	.1372	.1715
13			.1886		.2058	.1029	.1372
14		.2058	.2058	.3429	.1715	.12	.1372
15	.2743	.1886	.2572	.2058	.1715	.1543	
16	.2401	.2058		.3086	.2401	.12	
17	.2743	.2743	.3086	.3086	.2572	.1715	
18	.3086	.3429	.4115	.3086	.2743	.1715	
19	.4458	.4115	.4458	.3772	.3601	.2401	
20	.4458	.3086	.3086	.3258	.3429	.3086	.3601
21	.2915	.2743	.2743	.2915	.2915	.2401	.3086
22	.2058	.2401	.2401	.2058	.2743	.2058	.2743
23	.1886	.2058	.2229	.2058	.2058	.1715	.2229
24	.1372	.1715	.2058	.1886	.1715	.1524	.1715
Max	.4801	.4801	.583	.5144	.5144	.4458	.4801
Min	.1372	.1715	.1715	.1715	.1715	.1029	.1372
Avg	.3155	.2684	.3027	.2966	.2729	.2178	.2500

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334005 / MANDANA

Feeder No / Name : 203 / 11KV BHONGRA AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.6706	.7621		.381
2				.6706	.7621		.381
3				.6554	.8383		.3506
4				.6401	.884		.3048
5				.6401	.945		.3048
6				.7926	.9755		.3658
7				.8535	.9907		.5182
8				.823	1.0212	.3353	.6097
11		1.2498	1.1888				
12		1.2803	1.1736				
13			1.1736				
14		.9907	1.2346				
15	1.3413	1.0364	1.1126				
16	1.3413	1.1888					
17	1.2651	1.3375	.9145				
18	1.1584	1.3375	.823				
23			.6401	.2058	.2896	.4572	.3048
24				.6554	.6859	.3506	.4572
Max	1.3413	1.3375	1.2346	.8535	1.0212	.4572	.6097
Min	1.1584	.9907	.6401	.2058	.2896	.3353	.3048
Avg	1.2765	1.203	1.0326	.6607	.8154	.3810	.3978

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334009 / MHASAWAD

Feeder No / Name : 201 / 11KV MHASAWAD AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4			.823	.7926	.945	.9907
8			.9907	1.0364	1.4022	1.2955
11	1.9966	1.8138				
15	2.0729	1.6461				
18	2.0119	1.6461				
24			.823	.9145	.945	.9755
<b>Max</b>	<b>2.0729</b>	<b>1.8138</b>	<b>.9907</b>	<b>1.0364</b>	<b>1.4022</b>	<b>1.2955</b>
<b>Min</b>	<b>1.9966</b>	<b>1.6461</b>	<b>.823</b>	<b>.7926</b>	<b>.945</b>	<b>.9755</b>
<b>Avg</b>	<b>2.0271</b>	<b>1.702</b>	<b>.8789</b>	<b>.9145</b>	<b>1.0974</b>	<b>1.0872</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334009 / MHASAWAD

Feeder No / Name : 202 / 11KV SULWADE ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.7071	1.6309	1.4175				
8	1.768	1.7375	1.2955				
11				1.1431	1.2193	1.5242	1.2346
14				1.0669			
15					1.3108	1.4784	1.5242
18				.945	1.3717		
24	1.6918	1.5851	1.7833				
Max	1.768	1.7375	1.7833	1.1431	1.3717	1.5242	1.5242
Min	1.6918	1.5851	1.2955	.945	1.2193	1.4784	1.2346
Avg	1.7223	1.6512	1.4988	1.0517	1.3006	1.5013	1.3794

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334009 / MHASAWAD

Feeder No / Name : 203 / Amoda ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	2.2862	1.829					
8	2.2862	2.2862					
11				.884	.7926	1.3717	.8535
15				.9145	1.3717	1.6461	1.89
18				.7621	1.3717	.6859	1.6918
24	2.2862	2.1643	2.21				
Max	2.2862	2.2862	2.21	.9145	1.3717	1.6461	1.89
Min	2.2862	1.829	2.21	.7621	.7926	.6859	.8535
Avg	2.2862	2.0932	2.21	.8535	1.1787	1.2346	1.4784

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334009 / MHASAWAD

Feeder No / Name : 205 / 11KV NAVALPUR AG.

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4				1.8747	1.6461	1.8747
8				***	1.829	2.1033
11	2.7435	1.5089				
15		2.6978				
18	.6859	2.652	1.1431			
22			1.89			
24				1.8595	1.7985	1.829
Max	2.7435	2.6978	1.89	21.0486	1.829	2.1033
Min	.6859	1.5089	1.1431	1.8595	1.6461	1.829
Avg	1.7147	2.2862	1.5166	8.2609	1.7579	1.9357

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334009 / MHASAWAD

Feeder No / Name : 206 / 11KV NAVALPUR GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.1524	.1524	.1219	.1067	.1219	.1219	.1372
8	.1677	.1524	.1677	.0914	.1372	.1372	.1715
11	.1219	.1067		.1372	.1372	.12	.1372
15	.1219	.1067		.1067	.1219	.12	.1067
18	.1677	.1677		.1372	.1524	.1715	.1067
21		.1372				.1543	.1829
22				.1067	.1219		
24	.1372	.1219	.1219	.1715	.1219	.1219	.12
Max	.1677	.1677	.1677	.1715	.1524	.1715	.1829
Min	.1219	.1067	.1219	.0914	.1219	.12	.1067
Avg	.1448	.135	.1372	.1225	.1306	.1353	.1375

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334009 / MHASAWAD

Feeder No / Name : 207 / 11KV MHASAWAD GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.5182	.4572	.4572	.5792	.5487	.5487	.6859
8	.442	.4572	.4725	.5182	.5335	.5182	.6859
11	.5182	.4725		.4572	.4572		.5335
14				.3963			
15	.5944	.381			.1219	.4801	.4877
18	.5487	.503		.5792	.5792	.6344	.4572
21		.4572				.6859	.4877
22				.4572	.4877		
24	.4115	.4115	.442	.5144	.4268	.4572	.5144
Max	.5944	.503	.4725	.5792	.5792	.6859	.6859
Min	.4115	.381	.442	.3963	.1219	.4572	.4572
Avg	.5055	.4485	.4572	.5002	.4507	.5541	.5503

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334009 / MHASAWAD

Feeder No / Name : 208 / 11KV DARA AG.

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	2.7435	1.829	1.6766				
8	2.1033	2.1491	1.5089				
11				1.5242	.503	1.326	1.3717
13				1.5242			
15					.9145	1.4175	
18				.4572	1.0669	1.4175	
24	2.5149	2.0119	1.829				
Max	2.7435	2.1491	1.829	1.5242	1.0669	1.4175	1.3717
Min	2.1033	1.829	1.5089	.4572	.503	1.326	1.3717
Avg	2.4539	1.9967	1.6715	1.1685	.8281	1.387	1.3717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334009 / MHASAWAD

Feeder No / Name : 209 / 11KV DARA GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.4115	.4268	.4268	.4287	.4268	.4268	.463
8	.5182	.5639	.3963	.4973	.4572	.503	.463
11		.5182		.3963	.3658	.3772	.3963
15	.3963			.4572	.3658	.3944	.3048
18	.4572	.4877		.5182	.5335	.4458	.3353
21		.442				.5487	.3658
22				.4572	.4877		
24	.4268	.4572	.442	.4287	.4268	.4572	.463
Max	.5182	.5639	.442	.5182	.5335	.5487	.463
Min	.3963	.4268	.3963	.3963	.3658	.3772	.3048
Avg	.442	.4826	.4217	.4548	.4377	.4504	.3987

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334014 / 33/11KV Holmohida S/S

Feeder No / Name : 203 / 11KV BHAGAPUR AG Ag dominated/Pure Ag  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4					1.406	1.9509
7						1.9509
8				1.8861	1.7147	
10						2.0309
12	2.4499	2.3472				
16	2.5789	1.9814				
20			1.0477			
24					1.5775	1.89
Max	2.5789	2.3472	1.0477	1.8861	1.7147	2.0309
Min	2.4499	1.9814	1.0477	1.8861	1.406	1.89
Avg	2.5144	2.1643	1.0477	1.8861	1.5661	1.9557

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334020 / KUDAWAD

Feeder No / Name : 201 / 11KV LACHORA AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.3717				
8	1.448				
12			.7926	.5792	.7926
24	1.4175	1.6766			
Max	1.448	1.6766	.7926	.5792	.7926
Min	1.3717	1.6766	.7926	.5792	.7926
Avg	1.4124	1.6766	.7926	.5792	.7926

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334020 / KUDAWAD

Feeder No / Name : 202 / 11KV KUDAWAD AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4				.4877	.442
7			.4572		
8				.4572	
12		1.829			
15	2.4387				
16		1.9204			
24				.4572	.381
Max	2.4387	1.9204	.4572	.4877	.442
Min	2.4387	1.829	.4572	.4572	.381
Avg	2.4387	1.8747	.4572	.4674	.4115

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334020 / KUDAWAD

Feeder No / Name : 204 / 11KV KUDAWAD GAOTHAN  
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.1715				.1543	.1715
7					.1372		
8		.1372				.1543	
12		.1886		.12	.1543	.12	
15	.1886						
16		.1886				.0857	
20	.2401	.2401			.1886	.2058	
24		.1715	.1715		.1372	.1543	.1543
Max	.2401	.2401	.1715	.12	.1886	.2058	.1715
Min	.1886	.1372	.1715	.12	.1372	.0857	.1543
Avg	.2144	.1829	.1715	.12	.1543	.1457	.1629

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334020 / KUDAWAD

Feeder No / Name : 205 / 11 KV PADALDA AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	24-JUN-17	25-JUN-17	27-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.768			
8	1.7985			
12			1.6309	1.0212
24	1.829	1.8442		
<b>Max</b>	<b>1.829</b>	<b>1.8442</b>	<b>1.6309</b>	<b>1.0212</b>
<b>Min</b>	<b>1.768</b>	<b>1.8442</b>	<b>1.6309</b>	<b>1.0212</b>
<b>Avg</b>	<b>1.7985</b>	<b>1.8442</b>	<b>1.6309</b>	<b>1.0212</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334020 / KUDAWAD

Feeder No / Name : 206 / 11 KV BHUTE AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4				1.2346	1.2346
7			.8078		
8				1.4784	
12	2.8502	2.6673			
15	3.0483				
16		2.5453			
24			.8383	1.0059	1.2193
<b>Max</b>	<b>3.0483</b>	<b>2.6673</b>	<b>.8383</b>	<b>1.4784</b>	<b>1.2346</b>
<b>Min</b>	<b>2.8502</b>	<b>2.5453</b>	<b>.8078</b>	<b>1.0059</b>	<b>1.2193</b>
<b>Avg</b>	<b>2.9493</b>	<b>2.6063</b>	<b>.8231</b>	<b>1.2396</b>	<b>1.2270</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334020 / KUDAWAD

Feeder No / Name : 208 / padalda gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.3429				.2229	.3429
7					.4458		
8		.4115				.3258	
12		.2915		.3429	.2572	.2229	
15	.3086						
16		.3086					
20	.4973	.4115			.3944	.463	
24		.3429	.3429		.3258	.2572	.3429
Max	.4973	.4115	.3429	.3429	.4458	.463	.3429
Min	.3086	.2915	.3429	.3429	.2572	.2229	.3429
Avg	.4030	.3515	.3429	.3429	.3558	.2984	.3429

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334028 / 33/11 KV Sultanpur

Feeder No / Name : 201 / 11KV SULTANPUR AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	26-JUN-17	27-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	3.1093	3.0807		
6	3.1459	2.9973		
12			.2667	2.7166
16				2.5688
18			.2191	
<b>Max</b>	<b>3.1459</b>	<b>3.0807</b>	<b>.2667</b>	<b>2.7166</b>
<b>Min</b>	<b>3.1093</b>	<b>2.9973</b>	<b>.2191</b>	<b>2.5688</b>
<b>Avg</b>	<b>3.1276</b>	<b>3.039</b>	<b>.2429</b>	<b>2.6427</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334028 / 33/11 KV Sultanpur

Feeder No / Name : 202 / 11KV SULTANPUR GAOTHAN  
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	22-JUN-17	23-JUN-17	26-JUN-17	27-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.5792	.7133		
6	.7362	.8238		
8				.0762
9		.7499		
10				.08
12	.5083			.6468
16	.6335			.7783
18		.0819	.1029	
Max	.7362	.8238	.1029	.7783
Min	.5083	.0819	.1029	.0762
Avg	.6143	.5922	.1029	.3953

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334028 / 33/11 KV Sultanpur

Feeder No / Name : 203 / 11KV RAIKHED AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	27-JUN-17
HR	Load (MW)	Load (MW)
6		.1905
8		.2477
18	.3239	
Max	.3239	.2477
Min	.3239	.1905
Avg	.3239	.2191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334028 / 33/11 KV Sultanpur

Feeder No / Name : 204 / 11 KV RAIKHED GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	26-JUN-17	27-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.3439	.3801		
6	.4706	.4784		.04
8				.0419
9		.4668		
12	.2743		.0305	.2772
16				.3077
18		.0343	.0419	
Max	.4706	.4784	.0419	.3077
Min	.2743	.0343	.0305	.04
Avg	.3629	.3399	.0362	.1667

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334028 / 33/11 KV Sultanpur

Feeder No / Name : 205 / 11 KV KHARGAON AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	26-JUN-17	27-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	3.6199	3.8624		
6	4.0143	3.8862		
16				1.6655
18			.2324	
<b>Max</b>	<b>4.0143</b>	<b>3.8862</b>	<b>.2324</b>	<b>1.6655</b>
<b>Min</b>	<b>3.6199</b>	<b>3.8624</b>	<b>.2324</b>	<b>1.6655</b>
<b>Avg</b>	<b>3.8171</b>	<b>3.8743</b>	<b>.2324</b>	<b>1.6655</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334028 / 33/11 KV Sultanpur

Feeder No / Name : 206 / 11 KV BRAMHANPURI GAOTHAN Gaothan Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.2534				
6		.3258			.0343
8					.0267
9	.2172	.2172			
10		.2172			
12	.1991			.0229	
13	.3258		.2195		
16					.1791
18		.0267		.0248	
<b>Max</b>	<b>.3258</b>	<b>.3258</b>	<b>.2195</b>	<b>.0248</b>	<b>.1791</b>
<b>Min</b>	<b>.1991</b>	<b>.0267</b>	<b>.2195</b>	<b>.0229</b>	<b>.0267</b>
<b>Avg</b>	<b>.2489</b>	<b>.1967</b>	<b>.2195</b>	<b>.0239</b>	<b>.0800</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334037 / SAVAKHEDA

Feeder No / Name : 201 / 11KV SAVAKHEDA GAONTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.3258	.3258	.4801	.3772	.4115	.4115	.3086
8	.5144	.583	.5658	.5658	.6173	.6001	.5658
12	.3944	.3258	.3601	.463	.3601	.3086	.2915
16	.5487	.3944	.4115	.3772	.4801	.3772	
20	.4458	.4801	.5316	.5144	.6516	.5144	.5144
24	.3086	.3086	.3086	.3601	.3086	.3086	.3086
Max	.5487	.583	.5658	.5658	.6516	.6001	.5658
Min	.3086	.3086	.3086	.3601	.3086	.3086	.2915
Avg	.4230	.4030	.4430	.4430	.4715	.4201	.3978

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334037 / SAVAKHEDA

Feeder No / Name : 204 / 11 KV LOHARA AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.0364	1.0364	1.2193				
8	1.4327	1.387					
12				1.2346	.8078	.945	1.0059
16				.9145	1.0822	.8535	
18				.9145	.9907	.7621	
24	.9907	1.2193	1.2193				
Max	1.4327	1.387	1.2193	1.2346	1.0822	.945	1.0059
Min	.9907	1.0364	1.2193	.9145	.8078	.7621	1.0059
Avg	1.1533	1.2142	1.2193	1.0212	.9602	.8535	1.0059

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334042 / ISLAMPUR

Feeder No / Name : 201 / 11KV ISLAMPUR GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3			.5144				
4	.583	.5144		.5144	.4801	.5144	.5487
8		.6001		.4115	.5144	.5316	.583
12		.5144	.6173	.5144	.4458	.5316	.4973
16		.5487	.6173	.5144	.5658		.4973
18			.6687				
20		.6516			.6859	.7202	
24	.5487	.5144	.6173			.6859	.5144
Max	.583	.6516	.6687	.5144	.6859	.7202	.583
Min	.5487	.5144	.5144	.4115	.4458	.5144	.4973
Avg	.5659	.5573	.607	.4887	.5384	.5967	.5281

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334042 / ISLAMPUR

Feeder No / Name : 202 / 11KV ISLAMPUR AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	24-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	2.1643	1.8138	.7926	
16	1.8747	1.8138		
24				.7621
Max	2.1643	1.8138	.7926	.7621
Min	1.8747	1.8138	.7926	.7621
Avg	2.0195	1.8138	.7926	.7621

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334042 / ISLAMPUR

Feeder No / Name : 203 / 11KV AMBAPUR AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3			.5335		
4	.6706	.6401			
8		.8535			
12				.2896	.3658
16					.2439
24	.5639	.5182	.4877		
<b>Max</b>	<b>.6706</b>	<b>.8535</b>	<b>.5335</b>	<b>.2896</b>	<b>.3658</b>
<b>Min</b>	<b>.5639</b>	<b>.5182</b>	<b>.4877</b>	<b>.2896</b>	<b>.2439</b>
<b>Avg</b>	<b>.6173</b>	<b>.6706</b>	<b>.5106</b>	<b>.2896</b>	<b>.3049</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334042 / ISLAMPUR

Feeder No / Name : 204 / 11KV RANIPUR AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3			.6706			
4	.945	.8535				
8		.884				
12				.1372	.3658	.2439
16				.3658		.1219
24	.7621	.6097	.6097			
Max	.945	.884	.6706	.3658	.3658	.2439
Min	.7621	.6097	.6097	.1372	.3658	.1219
Avg	.8536	.7824	.6402	.2515	.3658	.1829

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334010 / SARANGKHEDA

Feeder No / Name : 201 / 11KV PUSNAD

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.7116	.6836	.6554	.8916	.7888	.8745	.4706
8				1.166	1.0288	.823	.8962
12	3.155	1.749					
16	2.1262	1.8519					
19			.9717				
20	.8145	.7537		.8097	.7888	.6733	.583
24	.463	.567	.6249	.8745	.583	.7716	.5014
Max	3.155	1.8519	.9717	1.166	1.0288	.8745	.8962
Min	.463	.567	.6249	.8097	.583	.6733	.4706
Avg	1.4541	1.1210	.7507	.9355	.7974	.7856	.6128

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334010 / SARANGKHEDA

Feeder No / Name : 202 / 11KV KALAMBU

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.1888	.9877	.9846	.4001	.6687		.3898
8	1.326	1.1157	.8429				
12					.7655	.463	
13				.7935			.5487
16				.6405	.7002	.5258	.5487
19			.5155				
20	.5373	.4641		.4572	.362	.5316	.4877
24	1.1439	1.2851	1.0974	.3563	.7468		.443
Max	1.326	1.2851	1.0974	.7935	.7655	.5316	.5487
Min	.5373	.4641	.5155	.3563	.362	.463	.3898
Avg	1.049	.9632	.8601	.5295	.6486	.5068	.4836

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334010 / SARANGKHEDA

Feeder No / Name : 203 / 11KV VARUL KANADI

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.7773	.5068	.3418				
8	.8579	.439	.3593				
12					.2717	.1943	
13							.2439
16				.3048	.2972	.2804	.2743
24	.7282	.3506	.2896				
Max	.8579	.5068	.3593	.3048	.2972	.2804	.2743
Min	.7282	.3506	.2896	.3048	.2717	.1943	.2439
Avg	.7878	.4321	.3302	.3048	.2845	.2374	.2591

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334010 / SARANGKHEDA

Feeder No / Name : 204 / 11KV BILADI

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.1823	.1463	.1311	.1334	.2667		.1646
8	.2294	.2801		.1905	.2286	.1905	.2195
12	.1928	.1543			.1715		
13				.1715			.1219
16	.1772	.1715		.1905	.2286	.1753	.1715
19			.2785				
20	.2534	.2294		.2667	.2667	.2126	.1715
24	.0819	.1267	.125	.0953	.1334		.1254
Max	.2534	.2801	.2785	.2667	.2667	.2126	.2195
Min	.0819	.1267	.125	.0953	.1334	.1753	.1219
Avg	.1862	.1847	.1782	.1747	.2159	.1928	.1624

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334010 / SARANGKHEDA

Feeder No / Name : 205 / 11KV KURHAWAD

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4			1.4148	1.6975	1.6289	1.0164
8			1.6651	1.749	1.5604	1.2696
12	2.1384	2.6063				
16	2.4629	2.572				
24			1.3032	1.6804	1.6289	1.0498
<b>Max</b>	<b>2.4629</b>	<b>2.6063</b>	<b>1.6651</b>	<b>1.749</b>	<b>1.6289</b>	<b>1.2696</b>
<b>Min</b>	<b>2.1384</b>	<b>2.572</b>	<b>1.3032</b>	<b>1.6804</b>	<b>1.5604</b>	<b>1.0164</b>
<b>Avg</b>	<b>2.3007</b>	<b>2.5892</b>	<b>1.4610</b>	<b>1.7090</b>	<b>1.6061</b>	<b>1.1119</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334010 / SARANGKHEDA

Feeder No / Name : 206 / 11KV LIS-II

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.1509	.0362	.0381	.1334	.2286	.1143	.0716
8	.1143	.1463	.0762	.1143	.2667	.1334	.1629
12	.2126	.2058			.2477	.1524	.1029
13				.1905			
16	.3077	.1372		.2286	.0953	.0876	.1372
19			.2641				
20	.1646	.1132		.1715		.1595	.1029
24	.1334	.0526	.0377	.1524	.1715	.1143	.0716
Max	.3077	.2058	.2641	.2286	.2667	.1595	.1629
Min	.1143	.0362	.0377	.1143	.0953	.0876	.0716
Avg	.1806	.1152	.1040	.1651	.2020	.1269	.1082

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334010 / SARANGKHEDA

Feeder No / Name : 207 / 11KV SARANGKHEDA

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.6874	.823	.6836	.679	.703	.6401	.2801
8	.8993	1.3676	1.0364	.8749	.8025	.7968	.3658
11				.9686			
12	.964	.2629			.8162	.7968	
16		.2629			.8025		.2058
19			1.1294				
20	1.0498	.8333		.953	.7926		.3372
23	.8682						
24	.5693	.695	.5556	.5182	.5401	.4877	.6036
<b>Max</b>	<b>1.0498</b>	<b>1.3676</b>	<b>1.1294</b>	<b>.9686</b>	<b>.8162</b>	<b>.7968</b>	<b>.6036</b>
<b>Min</b>	<b>.5693</b>	<b>.2629</b>	<b>.5556</b>	<b>.5182</b>	<b>.5401</b>	<b>.4877</b>	<b>.2058</b>
<b>Avg</b>	<b>.8397</b>	<b>.7075</b>	<b>.8513</b>	<b>.7987</b>	<b>.7428</b>	<b>.6804</b>	<b>.3585</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334015 / PARIVARDHA

Feeder No / Name : 202 / 11KV TARHADI AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	26-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.0857	
9	2.4006	2.4006	.0857	.6859
10	2.4006	1.7147		
12		1.6289		
13		1.7147		
<b>Max</b>	<b>2.4006</b>	<b>2.4006</b>	<b>.0857</b>	<b>.6859</b>
<b>Min</b>	<b>2.4006</b>	<b>1.6289</b>	<b>.0857</b>	<b>.6859</b>
<b>Avg</b>	<b>2.4006</b>	<b>1.8647</b>	<b>.0857</b>	<b>.6859</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334015 / PARIVARDHA

Feeder No / Name : 203 / 11KV PARIVARDHA GAONTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3				.4287	.5144	.5144
6				.8573	.8573	.8573
8				.8145		
9	.6859	.6859	.9955	.8145		.543
10	.6859		.905	.724		
11			.724	.543		
12		.5144	.6335	.543		
13		.4287	.543			
23					.5144	
24			.6335	.543		.5144
Max	.6859	.6859	.9955	.8573	.8573	.8573
Min	.6859	.4287	.543	.4287	.5144	.5144
Avg	.6859	.543	.7391	.6585	.6287	.6073

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334015 / PARIVARDHA

Feeder No / Name : 205 / SONAWAL AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	25-JUN-17	26-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
24	.8573	.5144	.5144
Max	.8573	.5144	.5144
Min	.8573	.5144	.5144
Avg	.8573	.5144	.5144

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334015 / PARIVARDHA

Feeder No / Name : 206 / VELHAWAD AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
14	1.9719	.5144	
15		.5144	
19			.6001
Max	1.9719	.5144	.6001
Min	1.9719	.5144	.6001
Avg	1.9719	.5144	.6001

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334022 / PRAKASHA

Feeder No / Name : 201 / 11KV Tarhawad Ag Feeder  
Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	22-JUN-17	23-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
4			.2372
8			.2812
12	1.829	1.9814	
16	1.9509	1.9052	
19	1.89	1.829	
24			.3201
<b>Max</b>	<b>1.9509</b>	<b>1.9814</b>	<b>.3201</b>
<b>Min</b>	<b>1.829</b>	<b>1.829</b>	<b>.2372</b>
<b>Avg</b>	<b>1.8900</b>	<b>1.9052</b>	<b>.2795</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334022 / PRAKASHA

Feeder No / Name : 202 / 11KV Express prakasha  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0857		.1067		
2					.12		
3				.1067	.12		
4	.0857	.1067			.0914	.0914	.0343
5					.0914		
6				.0762	.1029		
7		.0762		.061	.0686		
8	.0514	.061		.0686	.0686	.0686	.0171
9				.0914			.0152
10	.1219		.1219	.0914	.1219		.0152
11				.1029			.0305
12	.0305	.12		.3963	.1067	.0343	.061
13				.0914			.0686
14				.0914			.0686
15				.1029			.0457
16	.1067	.0857		.0914	.1067		.0457
17				.1029			.1067
18				.0914	.0914	.0343	.12
19		.0857		.0914			.1372
20	.1067			.1029			.1219
21				.0914			.1219
24	.1029	.1067	.1029		.061	.1067	.0514
Max	.1219	.12	.1219	.3963	.1219	.1067	.1372
Min	.0305	.061	.0857	.061	.061	.0343	.0152
Avg	.0865	.0917	.1035	.1089	.0967	.0671	.0663

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334022 / PRAKASHA

Feeder No / Name : 203 / 11KV PRAKASHA GAONTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4801		.3353		
2					.3963		
3				.5487	.5144		
4	.4801	.4877			.4572	.4572	.5144
5					.5182		
6				.6706	.6516		
7		.5182		.5487	.583		
8	.4801	.4572		.5144	.5487	.5144	.5144
9				.4572			.4572
10	.4268		.6097	.4801	.4268		.4458
11				.4268			.3963
12	.4572	.4458		.4458	.3963	.4115	.4458
13				.4268			.3658
14				.5144			.4458
15				.4877			.4458
16	.5487	.5144		.4877	.4572		.3658
17				.4572			.4801
18				.5487	.4572	.5144	.4572
19		.583		.5144			.5182
20	.5487			.5182			.5639
21				.4877			.4877
24	.5144	.4572	.4801		.3353		.4115
Max	.5487	.583	.6097	.6706	.6516	.5144	.5639
Min	.4268	.4458	.4801	.4268	.3353	.4115	.3658
Avg	.4937	.4948	.5233	.5021	.4675	.4744	.4572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334022 / PRAKASHA

Feeder No / Name : 204 / 11 KV PRAKASHA AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.1279				
4	1.2498	1.2041					
8	1.2346	1.2193					
11				.0914			
12				.1029	.0914	.0648	.0305
13				.0914			.0343
14				.1219			.0305
15				.1219			.0343
16				.1372			
17				.0914			.0305
18				.1029	.0914	.0328	.0305
24	1.2186	1.1888	1.1561				
Max	1.2498	1.2193	1.1561	.1372	.0914	.0648	.0343
Min	1.2186	1.1888	1.1279	.0914	.0914	.0328	.0305
Avg	1.2343	1.2041	1.142	.1076	.0914	.0488	.0318

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334038 / SASDE

Feeder No / Name : 201 / 11KV SHELTI

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6			1.2003				
16		1.2003		.6874	.9962	.5144	.4572
20	2.3148				1.0437		
24	1.713	2.0309			.5093	.6325	.5144
Max	2.3148	2.0309	1.2003	.6874	1.0437	.6325	.5144
Min	1.713	1.2003	1.2003	.6874	.5093	.5144	.4572
Avg	2.0139	1.6156	1.2003	.6874	.8497	.5735	.4858

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334038 / SASDE

Feeder No / Name : 202 / 11KV TEMBHA AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4						.703	
8	1.7593	1.8364	1.0669	1.0494	.5864	.6874	.4572
Max	1.7593	1.8364	1.0669	1.0494	.5864	.703	.4572
Min	1.7593	1.8364	1.0669	1.0494	.5864	.6874	.4572
Avg	1.7593	1.8364	1.0669	1.0494	.5864	.6952	.4572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334038 / SASDE

Feeder No / Name : 203 / 11KV VARUL KANADI AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.5864					
8	.8539		.3048	.0772	.0791	.0791	.0762
12					.2372		
24	.8333	.4999	.4572				
Max	.8539	.5864	.4572	.0772	.2372	.0791	.0762
Min	.8333	.4999	.3048	.0772	.0791	.0791	.0762
Avg	.8436	.5432	.381	.0772	.1582	.0791	.0762

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334038 / SASDE

Feeder No / Name : 204 / BAMKHEDA AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4					.5155	
8	1.2186		.4999	.7811	.6718	.4572
16		.8573				
Max	1.2186	.8573	.4999	.7811	.6718	.4572
Min	1.2186	.8573	.4999	.7811	.5155	.4572
Avg	1.2186	.8573	.4999	.7811	.5937	.4572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334038 / SASDE

Feeder No / Name : 205 / 11 KV KANADI

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16		.7716	.3593	.6718	.2572	.2743
20	1.1574			.5155		
24	1.1248	1.0031		.1875	.3005	.3429
Max	1.1574	1.0031	.3593	.6718	.3005	.3429
Min	1.1248	.7716	.3593	.1875	.2572	.2743
Avg	1.1411	.8874	.3593	.4583	.2789	.3086

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334045 / 33/11 KV SHAHADA URBAN

SUBSTAT

Feeder No / Name : 201 / 11 KV OUTGOING VIKAS

Urban/Sheddable Urban Feeder

FEEDER Feeder KV- 11 /

OUTGOING

DATE	22-JUN-17	23-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	3.083			
7				2.7042
8	2.6578			2.4714
10	2.8475			
13			2.6147	
16	4.4235			
19	3.725			
21	3.6176			
24	3.5151	3.6892		
Max	4.4235	3.6892	2.6147	2.7042
Min	2.6578	3.6892	2.6147	2.4714
Avg	3.4099	3.6892	2.6147	2.5878

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334045 / 33/11 KV SHAHADA URBAN

SUBSTAT

Feeder No / Name : 202 / 11 KV OUTGOING KUKDEL

Urban/Sheddable Urban Feeder

FEEDER Feeder KV- 11 /

OUTGOING

DATE	22-JUN-17	23-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.4529			
7				1.4883
8	1.4232			1.4706
10	1.576			
13			1.4529	
16	2.0022			
19	1.9136			
21	1.1694			
24	1.5592	1.6832		
Max	2.0022	1.6832	1.4529	1.4883
Min	1.1694	1.6832	1.4529	1.4706
Avg	1.5852	1.6832	1.4529	1.4795

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334045 / 33/11 KV SHAHADA URBAN

SUBSTAT

Feeder No / Name : 203 / 11 KV OUTGOING MALONI

Urban/Sheddable Urban Feeder

FEEDER Feeder KV- 11 /

OUTGOING

DATE	22-JUN-17	23-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.5947			
8	1.8959			1.6108
10	1.9728			
13			1.6651	
16	2.3891			
19	2.2445			
21	2.3529			
24	1.8004	2.0452		
<b>Max</b>	<b>2.3891</b>	<b>2.0452</b>	<b>1.6651</b>	<b>1.6108</b>
<b>Min</b>	<b>1.5947</b>	<b>2.0452</b>	<b>1.6651</b>	<b>1.6108</b>
<b>Avg</b>	<b>2.0358</b>	<b>2.0452</b>	<b>1.6651</b>	<b>1.6108</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334045 / 33/11 KV SHAHADA URBAN

SUBSTAT

Feeder No / Name : 401 / 33 KV RAPDRP SHAHADA

DIVISION FEEDER

INCOMER-I Feeder KV- 33 /

INCOMING

DATE	22-JUN-17	23-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	3.9335			
7				4.2444
8	4.3056			4.1872
10	4.7279			
11	4.9383			
13			4.137	
16	6.3935			
19	5.5876			
21	4.7279			
24		5.3189		
<b>Max</b>	<b>6.3935</b>	<b>5.3189</b>	<b>4.137</b>	<b>4.2444</b>
<b>Min</b>	<b>3.9335</b>	<b>5.3189</b>	<b>4.137</b>	<b>4.1872</b>
<b>Avg</b>	<b>4.9449</b>	<b>5.3189</b>	<b>4.137</b>	<b>4.2158</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334045 / 33/11 KV SHAHADA URBAN

SUBSTAT

Feeder No / Name : 402 / 33 KV RAPDRP SHAHADA

Urban/Sheddable Urban Feeder

INCOMER-I Feeder KV- 33 /

INCOMING

DATE	22-JUN-17	23-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.4352			
7				1.8107
8	1.8519			1.6975
10	2.037			
11	1.749			
13			1.6975	
16	2.4897			
19	2.2634			
21	2.4897			
24		2.1502		
<b>Max</b>	<b>2.4897</b>	<b>2.1502</b>	<b>1.6975</b>	<b>1.8107</b>
<b>Min</b>	<b>1.4352</b>	<b>2.1502</b>	<b>1.6975</b>	<b>1.6975</b>
<b>Avg</b>	<b>2.0451</b>	<b>2.1502</b>	<b>1.6975</b>	<b>1.7541</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334048 / 33/11 Kv Tikhora subStation

Feeder No / Name : 201 / Tihora Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6				.4115		
8					.3544	.3429
18	1.0802	1.1488	.9774			
Max	1.0802	1.1488	.9774	.4115	.3544	.3429
Min	1.0802	1.1488	.9774	.4115	.3544	.3429
Avg	1.0802	1.1488	.9774	.4115	.3544	.3429

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334048 / 33/11 Kv Tikhora subStation

Feeder No / Name : 202 / Mohida Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6					.9088		
8						1.0631	.9774
18	1.6975	1.749	1.3203	1.166			
23				1.0288			
Max	1.6975	1.749	1.3203	1.166	.9088	1.0631	.9774
Min	1.6975	1.749	1.3203	1.0288	.9088	1.0631	.9774
Avg	1.6975	1.749	1.3203	1.0974	.9088	1.0631	.9774

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334002 / TALODA

Feeder No / Name : 201 / 11KV TALODA TOWN

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3529	2.5339	2.3529	2.3529	1.9909	2.1719	1.9909
2	2.3529	2.5339		2.3529	1.9909	2.1719	1.9909
3	2.3529	2.5339		2.3529	1.9909	2.1719	1.9909
4	2.3529	2.5339		2.3529	2.1719	2.3529	2.3529
5	2.3529	2.7149			2.3529	2.7149	2.7149
6	2.8959	2.8959	2.7149	2.8959	2.5339	3.0769	3.0769
7	2.7149	2.7149	2.7149	2.7149		2.5339	3.0769
8	2.5339	2.7149	2.3529	2.7149		2.5339	3.2579
9	2.7149	2.7149	2.7149	2.7149	2.7149	2.5339	2.8959
10	2.7149	2.7149	2.7149	2.5339	2.5339	2.5339	2.7149
11	2.5339	2.5339		2.5339	2.5339	2.1719	2.3529
12	2.3529	2.3529		2.1719	2.1719		2.1719
13		2.3529	2.7149	2.1719	1.9909	2.1719	2.1719
14	1.9909		2.1719	1.9909	1.9909	1.9909	1.9909
15	2.8959	1.086	2.1719	1.9909	.905	2.1719	1.9909
16	2.7149	2.5339	2.1719	1.9909	.905	1.9909	
17	2.5339	2.5339	2.1719	1.9909	2.3529	2.3529	
18	2.5339	2.5339	2.3529	1.267	2.3529	1.267	
19	2.7149	2.7149		2.5339	2.7149	2.7149	3.4389
20	2.8959	3.0769	2.8959	2.5339	2.7149	2.8959	3.2579
21	2.7149	2.7149		2.5339	1.267	2.5339	3.2579
22	2.5339	2.5339	2.3529	2.3529	2.1719	2.5339	2.8959
23		2.3529	2.3529		2.1719	2.3529	2.5339
24	2.3529	2.5339	2.1795	2.3529	1.9909		2.1719
Max	2.8959	3.0769	2.8959	2.8959	2.7149	3.0769	3.4389
Min	1.9909	1.086	2.1719	1.267	.905	1.267	1.9909
Avg	2.5504	2.5418	2.4439	2.3365	2.1143	2.3611	2.5856

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334002 / TALODA

Feeder No / Name : 202 / 11KV TALAVA AG-I

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1619		1.5089
2				.181		1.5089
3				.1619	1.6289	1.5089
4				.362	1.6289	1.5089
5				.181	1.6289	1.5089
6				.1619	1.6289	1.5089
7					1.8099	1.5089
8					1.7814	1.5089
11		4.1629				
12	1.3413	3.8561				
13		3.8561	.503			
14	2.0119		.503			
15	2.3472	3.6885	2.1795			
16	2.3472	3.5208	2.3472			
17	2.2672	3.5627	2.4291			
18	3.2388	3.2388	2.4291			
23					1.6766	1.3413
24				.362		1.6766
Max	3.2388	4.1629	2.4291	.362	1.8099	1.6766
Min	1.3413	3.2388	.503	.1619	1.6289	1.3413
Avg	2.2589	3.6980	1.7318	.2245	1.6834	1.5089

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334002 / TALODA

Feeder No / Name : 203 / 11KV TALAVA AG-II

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.267	1.086					
2	1.267	1.086					
3	1.267	1.086					
4	.362	1.086					
5	1.267	1.086					
6	1.267	1.086					
7	.724	1.086					
8	.543	1.086					
11					.6706	.6478	.6478
12					.6706	.6478	.6478
13				.6706	.6706	.6478	.6478
14				.6706	.6706	.6478	.6478
15				.6706	.6706	.6478	.6478
16				.6706	.6706		
17				.6478	.6478		
18				.6478	.6478	.6478	
24	1.1336	1.086	.724				
Max	1.267	1.086	.724	.6706	.6706	.6478	.6478
Min	.362	1.086	.724	.6478	.6478	.6478	.6478
Avg	1.0108	1.086	.724	.663	.6649	.6478	.6478

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334002 / TALODA

Feeder No / Name : 204 / 11KV CHINODA AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0769						
2	3.0769	2.8959					
3	3.0769	2.8959					
4	3.0769						
5	3.0769	2.8959					
6	3.2579	3.0769					
7	3.2579	3.2579					
8	3.2579	3.2579					
11					2.0119	2.1052	1.9433
12				1.8442	2.1795	2.2672	2.1052
13				2.0119	2.0119	2.1052	2.1052
14				1.8442	2.1795	2.1052	2.1052
15				1.8442	2.1795	2.1052	1.7814
16				1.8442	2.3472	2.1052	
17				1.7814	2.2672	2.1052	
18				1.7814	2.2672	1.9433	
23		2.7149					
24	3.0769	2.8959	2.7149				
Max	3.2579	3.2579	2.7149	2.0119	2.3472	2.2672	2.1052
Min	3.0769	2.7149	2.7149	1.7814	2.0119	1.9433	1.7814
Avg	3.1372	2.9864	2.7149	1.8502	2.1805	2.1052	2.0081

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334002 / TALODA

Feeder No / Name : 205 / 11KV TALODA GROUP AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0769	3.0769					
2	3.0769	3.0769					
3	3.0769	3.0769					
4	3.0769	3.0769					
5	3.0769	3.0769					
6	3.4389	3.0769					
7	3.4389	3.2579					
8	3.4389	3.2579					
11				1.8442	2.3472	2.2672	2.1052
12				2.0119	2.3472		2.5339
13				2.0119	2.3472	2.2672	2.3529
14				2.0119	2.3472	2.2672	1.2955
15				2.0119	2.3472	2.2672	1.9433
16				2.0119	2.3472		
17				1.7814	2.2672		
18				1.7814	2.2672	.3239	
23		2.7149					
24	3.2579	3.0769	2.7149				
Max	3.4389	3.2579	2.7149	2.0119	2.3472	2.2672	2.5339
Min	3.0769	2.7149	2.7149	1.7814	2.2672	.3239	1.2955
Avg	3.2177	3.0769	2.7149	1.9333	2.3272	1.8785	2.0462

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334002 / TALODA

Feeder No / Name : 206 / 11KV AMLAD AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	26-JUN-17	27-JUN-17
HR	Load (MW)	Load (MW)
1		2.2672
2		2.2672
3		2.1052
4		2.1052
5		2.1052
6		2.1052
7		2.5339
8		2.7149
23	2.4291	
24		2.4291
<b>Max</b>	<b>2.4291</b>	<b>2.7149</b>
<b>Min</b>	<b>2.4291</b>	<b>2.1052</b>
<b>Avg</b>	<b>2.4291</b>	<b>2.2926</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334002 / TALODA

Feeder No / Name : 207 / 11KV AMLAD GAONTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.362		.362	.362	.362	.181
2	.362	.362		.362	.362	.362	.181
3	1.267	.362		.362		.362	.181
4	.362	.362		.362	.362	.362	.181
5	.543	.543		.543	.543	.362	.362
6		.724		.724	.724	.724	.543
7	.724	.724		.724		.724	.543
8	.543	.543				.543	.362
9		.181	.181	.362	.362	.362	.362
10		.181		.181	.362	.362	.362
11	.181	.181		.181	.181	.362	.362
12	.181	.181	.181	.181	.181	.362	.362
13		.181	.181	.181	.181	.181	.362
14	.181		.181	.181	.181	.181	
15	.181	.181	.181	.181	.181		
16	.181	.181	.181	.181	.181	.362	
17	.362	.362	.362	.362	.362	.362	
18	.362	.362	.362	.362	.362	.362	
19	.543	.362		.543	.724	.543	.543
20	.543	.543	.543	.543	.724	.543	.724
21	.362	.543	.543	.362	.543	.362	.724
22	.362	.362	.362	.362	.362	.362	.543
23		.362	.362			.181	.181
24	.3239	.362	.362		.362	.362	.181
Max	1.267	.724	.543	.724	.724	.724	.724
Min	.181	.181	.181	.181	.181	.181	.181
Avg	.4172	.3699	.3063	.362	.3801	.3935	.3811

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334024 / SOMAVAL

Feeder No / Name : 201 / 11KV AMONI AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1643	1.9814	.9145				
2	2.7054	1.9814	.9145				
3	2.7054	2.0576	.6097				
4	2.7054	2.0576	.4572				
5	2.1795	1.9052	.4572				
6		1.6766	.3048				
7	2.4082	1.7528					
8	2.3624	1.768					
11					.6401	.7926	.7773
12					.7011	.8535	.8078
13				.4572	.7926		.9145
14					.823		.9602
15					.8688		
18				.4115		.6859	
24	2.7435						
Max	2.7435	2.0576	.9145	.4572	.8688	.8535	.9602
Min	2.1643	1.6766	.3048	.4115	.6401	.6859	.7773
Avg	2.4968	1.8976	.6097	.4344	.7651	.7773	.8650

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334024 / SOMAVAL

Feeder No / Name : 202 / 11KV BEDAPADA AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.2193
2		1.0669		1.3748
3				1.2803
4		1.0669		1.2955
5				1.3108
6		1.3336		
7		1.1279	1.3108	1.3717
8		1.2346		
11	2.6825			
12	2.8502			
13	2.5301			
14	1.9966			
18	1.387			
23		1.1431		
Max	2.8502	1.3336	1.3108	1.3748
Min	1.387	1.0669	1.3108	1.2193
Avg	2.2893	1.1622	1.3108	1.3087

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334024 / SOMAVAL

Feeder No / Name : 203 / 11KV SHIRVE AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	1.3717	.3048				
2	1.2193	1.3717	.3048				
3	1.2193	1.448	.381				
4	1.2955	1.448	.381				
5	1.2955	1.3717	.4572				
6		1.2193					
7	1.9814	1.0669					
8	1.829	1.2193	.6097				
11				.4572	.381	.4572	.4572
12					.4572	.5335	.4572
13				.4572	.4572		.4572
14					.4572		.6097
15					.4572		
18				.4268		.5335	
24	1.5242						
Max	1.9814	1.448	.6097	.4572	.4572	.5335	.6097
Min	1.2193	1.0669	.3048	.4268	.381	.4572	.4572
Avg	1.4479	1.3146	.4064	.4471	.4420	.5081	.4953

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334024 / SOMAVAL

Feeder No / Name : 204 / 11KV NARMADANAGAR GAONTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.1812				1.2193
2	1.1622	1.1431		1.105		1.1431
3	1.1622	1.1431				1.1431
4	1.1622	1.1431		1.0669		
5	1.1622					
6	1.2574			1.105		.9907
7	1.1431			1.105	1.2574	.9526
8				.9907		1.1812
9				1.0098		
10			.8764	.8573		
11			.8002	.8573	.8764	
12				.8573	.8383	
13		1.0479	.8002	.8573		
14		.6478		.8954		
16		.8573				
17		1.0288		1.3527		
18		1.1812	.9907		1.105	
19		1.1812	1.105		1.1431	
20		1.448			1.4861	
21	1.2574	1.3717	1.1431			
22	1.2955	1.3336	1.1431			
23			1.1431	1.3717		
24	1.1431					
Max	1.2955	1.448	1.1431	1.3717	1.4861	1.2193
Min	1.1431	.6478	.8002	.8573	.8383	.9526
Avg	1.1888	1.1314	1.0002	1.0332	1.1177	1.105

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334024 / SOMAVAL

Feeder No / Name : 205 / 11KV NARMADANAGAR AG  
Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	22-JUN-17	23-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2743
2				.2743
3				.3048
4				.3353
5				.3353
6				.3658
7			.0762	.3658
11	1.9814	1.829		
12	2.4387	1.9814		
14		1.3717		
15	2.4387	1.3717		
16	2.5911			
17	2.5911	.6097		
18	2.5911	.6097		
Max	2.5911	1.9814	.0762	.3658
Min	1.9814	.6097	.0762	.2743
Avg	2.4387	1.2955	.0762	.3222

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334024 / SOMAVAL

Feeder No / Name : 206 / 11KV AMONI GAONTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8764					.9526
2	.8573			1.105		.9145
3	.8573					.8764
4	.8573	.8573		1.0288		.8764
5	.8573	.8383				.8383
6	.9145	.8383		.9724		.8764
7	.8573	.8383		1.0288	.9526	.8383
8		.8383		.8764		
9		.8383		.8573		
10		.8383	.8002	.8383		
11			.7621	.724	.724	
12		.6478		.7811	.6287	
13			.8002	.8383		
14				.8192		
15				.8573		
17				1.0288		
18			1.1431		.9907	
19		1.3908	1.1812		.8764	
20	.9907				1.2193	
21	1.0669	1.2955	1.2193			
22	1.0669	1.2955	1.1431			
23		1.3717		1.0669		
24	.8764					
Max	1.0669	1.3908	1.2193	1.105	1.2193	.9526
Min	.8573	.6478	.7621	.724	.6287	.8383
Avg	.9162	.9907	1.0070	.9159	.8986	.8818

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334040 / Pratappur Substation

Feeder No / Name : 201 / 11KV PRATAPPUR AG  
Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	22-JUN-17	23-JUN-17	26-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1	4.353	4.4262	
3		4.353	
4	4.1701	4.353	
6	4.2067		
8	4.353	4.0604	1.6358
24	4.4723	3.914	
<b>Max</b>	<b>4.4723</b>	<b>4.4262</b>	<b>1.6358</b>
<b>Min</b>	<b>4.1701</b>	<b>3.914</b>	<b>1.6358</b>
<b>Avg</b>	<b>4.3110</b>	<b>4.2213</b>	<b>1.6358</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334040 / Pratappur Substation

Feeder No / Name : 202 / 11KV PRATAPPUR GAONTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.462			.462			
4	.4066				.4321		
5				.499			
6	.6283						.7392
8		.6283		.3704			
10						.6653	
11							.499
12				.4475	.3858		
15			.4207				
16	.5359	.4435				.4066	
17			.4251				
18				.4475	.5864		.499
20			.499				
24	.5359	.5914	.3881	.3858		.5914	.6283
Max	.6283	.6283	.499	.499	.5864	.6653	.7392
Min	.4066	.4435	.3881	.3704	.3858	.4066	.499
Avg	.5137	.5544	.4332	.4354	.4681	.5544	.5914

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334040 / Pratappur Substation

Feeder No / Name : 204 / 11KV RANIPUR AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11		1.6827	1.0974			.4755	.7392
12	1.7193				.3395		
14		1.4998					.6584
15	1.7372	1.4784				.6584	
16			1.0242				
17			.9511				
18	1.6263	1.3535		.3395	.4012	.6584	.0732
Max	1.7372	1.6827	1.0974	.3395	.4012	.6584	.7392
Min	1.6263	1.3535	.9511	.3395	.3395	.4755	.0732
Avg	1.6943	1.5036	1.0242	.3395	.3704	.5974	.4903

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334040 / Pratappur Substation

Feeder No / Name : 205 / 11 KV Ranzani Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4066			.5914			
4	.4066				.463		
5				.5175			
6	.5544						.7762
8		.4805		.1852			
9			.5914				
10						.6653	
11							.5175
12	.6283				.463		
13			.4066				
16	.5914	.5914		.5864		.5175	
17			.5175				
18					.5247		.6283
24	.6283	.5914	.5914	.463		.5914	.6283
Max	.6283	.5914	.5914	.5914	.5247	.6653	.7762
Min	.4066	.4805	.4066	.1852	.463	.5175	.5175
Avg	.5359	.5544	.5267	.4687	.4836	.5914	.6376