

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074004 / 33 KV BULDANA

Feeder No / Name : 201 / 11KV BULDANA - I SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.3772	.4344	.4287	.4973
2	.4287	.3772	.4344	.4287	.4801
3	.4115	.4115	.4344	.4458	.4801
4	.4115	.4458	.4706	.4801	.5144
5	.4801	.5144	.5068	.5144	.5144
6	.5487	.5487	.543	.5487	.583
7	.6859	.703	.6516	.8402	.7202
8	.6859	.7545	.7602	.703	.8059
9	.7202	.6859	.7602	.6859	.7202
10	.7602	.6516	.6859	.6173	.6859
11	.724	.6173	.6173	.6173	.703
12	.6878	.6173	.6173	.6173	.6173
13	.724	.5316	.5487	.6173	.6173
14	.6154	.5487	.4801	.583	.583
15	.6154	.5487	.4801	.583	.6001
16	.6516	.583	.5316	.6173	.6173
17	.6878	.583	.5487	.6516	.6344
18	.8326	.8326	.703	.8326	.8688
19	.8048	.7964	.703	.7545	.8688
20	.7964	.7964	.703	.7716	.8326
21	.724	.6516	.6516	.7373	.724
22	.6154	.4706	.6173	.6344	.5792
23	.5144	.5068	.5487	.4973	.4706
24	.4801	.4458	.4706	.4801	.4973
Max	.8326	.8326	.7602	.8402	.8688
Min	.4115	.3772	.4344	.4287	.4706
Avg	.6272	.5833	.5793	.6120	.6340

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074004 / 33 KV BULDANA

Feeder No / Name : 202 / 11 KV BULDANA - II SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.1886	.2195	.2229	.2229
2	.2058	.1886	.2195	.2058	.2229
3	.2058	.2401	.2195	.2058	.2229
4	.2058	.2572	.2195	.2058	.2401
5	.2058	.2572	.2195	.2229	.2401
6	.2401	.2743	.2561	.2229	.2572
7	.2743	.4287	.2926	.2915	.2743
8	.3086	.4115	.3292	.3429	.3086
9	.3601	.3772	.3292	.3429	.3258
10	.439	.3772	.3429	.3429	.3429
11	.4024	.3772	.3086	.4115	.4973
12	.4024	.3429	.3086	.3429	.3772
13	.439	.4115	.2743	.3601	.4115
14	.4024	.3772	.2401	.3601	.3429
15	.4024	.3429	.2401	.3429	.3429
16	.4024	.3601	.2743	.3772	.4115
17	.4755	.4115	.2915	.4115	.4801
18	.4755	.4024	.3601	.4755	.5121
19	.439	.4024	.3772	.4115	.4755
20	.4024	.3658	.3772	.3601	.4024
21	.3292	.3292	.3429	.3258	.3292
22	.2926	.2926	.2915	.2743	.3109
23	.2401	.2561	.2229	.2572	.2561
24	.2229	.1886	.2378	.2401	.2229
Max	.4755	.4287	.3772	.4755	.5121
Min	.2058	.1886	.2195	.2058	.2229
Avg	.3325	.3275	.2831	.3149	.3346

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074004 / 33 KV BULDANA

Feeder No / Name : 203 / 11 KV Town-III

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2134	.1981	.1981	.2134	.2134
2	.1829	.1981	.1981	.2134	.2134
3	.1829	.2286	.1981	.2439	.2134
4	.1829	.2439	.2378	.3048	.2134
5	.2439	.3048	.1981	.3353	.2743
6	.2439	.3506	.2439	.3506	.3048
7	.4268	.4572	.3658	.4725	.4572
8	.4268	.4268	.4268	.4877	.4572
9	.4268	.4268	.4268	.4268	.4572
10	.3963		.3963	.3963	
11	.3353	.3201	.3658	.3353	.3506
12	.2439	.2439	.3201	.3048	.3048
13	.2439	.2743	.2591	.2743	.2439
14	.2439	.3048	.2439	.2439	.2439
15	.2134	.3201	.2439	.2134	.2439
16	.2439	.2896	.2439	.2896	.2591
17	.2743	.3048	.2896	.2896	.2896
18	.3658	.4268	.3353	.381	.3963
19	.3658	.3658	.3506	.3353	.3963
20	.3658	.3658	.3658	.381	.3658
21	.3353	.3353	.3353	.3658	.3353
22	.2743	.2743	.3048	.2896	.2743
23	.2591	.2439	.2286	.2572	.2439
24	.2134	.2134	.1981	.2286	.2134
Max	.4268	.4572	.4268	.4877	.4572
Min	.1829	.1981	.1981	.2134	.2134
Avg	.2877	.3095	.2906	.3181	.3028

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074004 / 33 KV BULDANA

Feeder No / Name : 204 / 11 KV KOLWAD G

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2572	.2587	.2058	.1715
2	.2401	.2572	.2587	.2229	.1715
3	.2401	.3258	.2587	.2743	.2058
4	.2401	.4458	.3326	.3086	.3086
5	.4458	.5144	.4066	.4458	.3429
6	.583	.6001	.6099	.5316	.5144
7	.703	.7716	.7392	.7373	.6001
8	.6173	.6859	.7023	.703	.5487
9	.583	.5316	.6838	.6001	.4801
10	.5175		.5144	.463	
11	.4805	.4801	.4287	.3601	.463
12	.462	.463	.3944	.3429	.4287
13	.4066	.4287	.4458	.3086	.3601
14	.3696	.4287	.2229	.2915	.3429
15	.3326	.4115	.2572	.3086	.3601
16	.4066	.4287	.3086	.3772	.3429
17	.4066	.3429	.4115	.3772	.4115
18	.6099	.6283	.4973	.6283	.6838
19	.5544	.5544	.463	.5144	.6283
20	.4805	.4805	.3944	.4115	.462
21	.3881	.3511	.3429	.3429	.4066
22	.3326	.3142	.2572	.2743	.3326
23	.2572	.2772	.2229		.3142
24	.2572	.2572	.2587	.2058	.1715
Max	.703	.7716	.7392	.7373	.6838
Min	.2401	.2572	.2229	.2058	.1715
Avg	.4231	.4450	.4029	.4016	.3936

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074004 / 33 KV BULDANA

Feeder No / Name : 209 / 11 KV Ekta Nagar SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.4287	.4572	.3772	.4287
2	.4287	.4287	.4572	.3944	.4287
3	.4115	.5144	.4572	.4458	.4287
4	.4115	.5487	.4755	.4801	.5144
5	.4801	.6001	.4755	.5487	.5487
6	.6344	.6687	.567	.6001	.6001
7	.8059	.823	.7682	.823	.9431
8	.823	.7373	1.0242	.823	.8916
9	.823	.823	.8596	.8059	.7545
10	.7316	.6859	.7373	.6687	.6516
11	.6401	.6001	.5658	.5316	.5658
12	.5544	.5658	.6001	.5144	.463
13	.5121	.4973	.4973	.4801	.4287
14	.4938	.4973	.463	.4287	.4115
15	.4938	.4801	.4115	.4287	.4115
16	.4938	.4801	.4801	.4458	.463
17	.4938	.5316	.5658	.5144	.5487
18	.9328	.8048	.703	.7499	.8779
19	.9145	.8596	.7202	.7202	.8779
20	.8779	.823	.7545	.7545	.8779
21	.7682	.7499	.6516	.703	.7316
22	.695	.6584	.583	.6001	.6401
23	.5144	.5487	.4801	.4801	.5304
24	.4458	.4458	.4755	.4115	.4287
Max	.9328	.8596	1.0242	.823	.9431
Min	.4115	.4287	.4115	.3772	.4115
Avg	.6170	.6167	.5929	.5721	.6020

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074012 / 33/11 KV D'SHEWALI

Feeder No / Name : 201 / 11KV DONGAR SHEOLI AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	1.2967	1.6766	.0857	.0671
2	2.2291	1.3592	1.6766	.0857	.0492
3	1.829	1.4842	1.8861	.0857	.0497
4	2.0576	1.7185	1.7147	.0857	.0503
5	1.7147	1.8747	1.2003	.0857	.0663
6	1.9357	1.5432	1.3717	.0686	.0819
7	1.6289	1.7394	1.0669	.0686	.0829
8	.0686	.0671	.0686	.0686	.0663
9	.0671	.0655	.0686		.0671
10	.0663	.0686	.0686	1.7185	2.4006
11	.0678	.0686	.0686	2.0557	3.1722
12	.0514	.0857	.0686	2.5777	3.3436
13		.0686	.0686	2.8902	3.0007
14		.061	.0686	2.9321	3.2579
15	.0671	.061	.0514	2.963	3.2579
16	.0497	.0686	.0514	2.9321	3.0864
17	.0503	.0514	.0514	2.5934	2.7435
18	.0671	.0514	.0686	.5138	.0857
19	.0655	.0514	.0857	.6268	.1029
20	.0671	.0686	.0857	.6733	.0686
21	.0655	2.0576	.0857	.0671	.0686
22	.0497	2.0576	.0857	.0503	.0686
23	.0497	1.8861	.0857	.0492	
24	1.6766	1.2651	1.5242	.0857	.0655
Max	2.2291	2.0576	1.8861	2.963	3.3436
Min	.0497	.0514	.0514	.0492	.0492
Avg	.7265	.7967	.5520	1.0158	1.1002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074012 / 33/11 KV D'SHEWALI

Feeder No / Name : 203 / 11KV SHELSUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1341	.12		1.5497
2	.1029	.116	.0686	1.2003	1.5623
3	.1372	.1147	.0857	1.2174	1.6716
4	.1372	.1457	.0686	1.2346	1.7966
5		.1658	.0686	1.3032	1.9372
6	.1372	.1475	.0857	1.4746	1.8827
7	.1543	.1844	.0686	1.6289	2.0466
8	.2058	.1966	.1543	.1715	.1677
9	.1638	.1475	.1219	.1715	.1802
10	1.5971	1.7147	2.0748	.1677	.2058
11	2.0622	2.4006	2.3663	.1492	.1715
12	1.9814	2.572	2.1948	.1311	.1715
13	1.9814	2.572	2.572	.1509	.1715
14	2.572	2.572	2.2634	.1475	.1372
15	2.2653	2.4006	2.0576	.1781	.1372
16	2.2138	2.4006	1.989	.1638	.1372
17	1.9766	2.0576	1.8176	.1638	.1372
18		.0686	.1886	.1989	.2058
19	.1638	.0514	.2058	.2012	.2401
20	.1341	.0686	.2058	.213	.2058
21	.1492	.0857	.2058	.1509	2.0576
22	.1457	.0686	1.2003	1.4232	2.0576
23	.1638	.0686	1.2346	1.5023	
24	.1372	.1311	.1219	1.2517	
Max	2.572	2.572	2.572	1.6289	2.0576
Min	.1029	.0514	.0686	.1311	.1372
Avg	.8509	.8577	.8975	.6346	.8559

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074012 / 33/11 KV D'SHEWALI

Feeder No / Name : 204 / 11 KV D SHEWALI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3012	.3086	.3045	.3045
2	.3429	.3366	.3429	.3045	.3366
3	.3429	.4207	.3429	.3045	.4252
4	.3772	.5258	.4287	.3224	.5083
5	.4458	.691	.4287	.4477	.6588
6	.7545	.8238	.6859	.7522	.7888
7	.9431	1.046	.9259	1.0029	.9114
8	.8916	.9536	.8916	.9134	.8859
9	.7537	.7442	.823	.6024	.7442
10	.6024	.5144	.591	.5373	.5658
11	.3898	.3772	.5194	.3544	.3944
12	.3772	.3429	.4119	.2835	.3086
13	.3258	.3506	.3761	.2658	.2915
14	.3086	.3086	.3403	.285	.2572
15	.3506	.3429	.3582	.3155	.3086
16	.3681	.3772	.3761	.3189	.3772
17	.4784	.4458	.4656	.3898	
18	.5731	.7202	.6805		.7202
19	.7087	.6001	.6984		.6687
20	.567	.4572	.5373		.5487
21	.4733	.4458	.4298	.4382	.5144
22	.4161	.3772	.3582	.3506	.3772
23	.3544	.3429	.3224	.3189	
24	.3086	.2686	.3086	.3045	.2686
Max	.9431	1.046	.9259	1.0029	.9114
Min	.3086	.2686	.3086	.2658	.2572
Avg	.4915	.5048	.498	.4341	.5075

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074015 / 33 KV S/STN. HATEDI

Feeder No / Name : 201 / 11KV NANDRAKOLI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2254	2.8166	2.146	2.332	.1357
2	.2601	2.7149	.3395	2.2805	2.1795
3	.3121	.3395	.3772	2.2291	2.0957
4	.3814	.415	.415	2.1434	2.0119
5				2.1216	2.2634
6				2.2939	2.431
7				2.4905	2.431
8				2.5396	2.431
9				2.7362	2.5987
10				2.6216	2.6216
11				2.5987	2.3594
12	3.2693	2.9492	2.8509		
13	3.0178	3.2769	3.0803		
14	3.1017	3.0476			
15	2.6825	2.556			
18	2.8502	2.7831			
19	.5658	.6413	.463	.4748	.6413
20	.3772	.415	.3772	.3391	.415
21	.3018	.3772	.3086	.2035	
22	.2263	.2641	.2915	.1865	.2263
23	.2263	.2263	.2743	.1696	.1886
24	.208	2.8959	2.2611	2.2977	.1696
Max	3.2693	3.2769	3.0803	2.7362	2.6216
Min	.208	.2263	.2743	.1696	.1357
Avg	1.2004	1.7146	1.0987	1.7681	1.5750

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074015 / 33 KV S/STN. HATEDI

Feeder No / Name : 203 / 11KV KOLWAD SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6241	.5792	.6413	.4115	.373
2	.6588	.6413	.7167	.4801	.4239
3	.7282	.7922	.7922	.583	.5087
4	.8322	.9431	.9054	.6516	.6274
5	2.1795	2.1365	2.079		
6	2.431	2.2043	2.2291		
7	2.5987	2.2131	2.2634		
8	2.6825	2.1795	2.3472		
9	2.7664	2.0885	2.3137		
10	2.6825	2.1125	2.3205		
11	2.2634	2.1548	2.0972		
12				2.3472	2.1548
13				2.431	
14				2.431	2.3868
15				2.431	2.6852
16				2.1795	2.3868
17				2.1672	2.3868
18				2.0119	2.3205
19	1.5466	1.5844	1.3717	1.3226	1.6221
20	1.1694	1.1694	1.0288	1.0513	1.2826
21	1.0185	.9808	.8916	.9156	1.0185
22	.7545	.7545	.5144	.4748	.5281
23	.679	.679	.4115	.4239	.4527
24	.6068	.6036	.6413	.4115	.3561
Max	2.7664	2.2131	2.3472	2.431	2.6852
Min	.6068	.5792	.4115	.4115	.3561
Avg	1.5425	1.4010	1.3862	1.3367	1.3446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074015 / 33 KV S/STN. HATEDI

Feeder No / Name : 205 / AMBHODA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2427	.2641	.2641	.2572	.2883
2	.2774	.3018	.3018	.3086	.3391
3	.3121	.3772	.3772	.3772	.4239
4	.3641	.4527	.415	.5144	.5256
5	1.6766	1.8991	2.0576		
6	1.7604	2.1026	2.2977		
7	2.3472	2.2801	2.5484		
8	2.5149	2.5484	2.42		
9	2.431	2.6189	2.3205		
10	2.2634	2.3205	2.0645		
11	2.2634	2.4143	1.9227		
12				2.431	2.7515
13				2.7664	2.6852
14				2.6825	2.652
15				2.7664	2.5857
16				2.3472	2.1548
17				2.5139	2.0885
18				2.0119	1.9559
19	.7545	.7545	.6516	.6783	.7922
20	.5658	.5281	.5144	.4409	.5658
21	.415	.415	.3429	.373	.4904
22	.3395	.3018	.3086	.3052	.3395
23	.3018	.2641	.2743	.2543	.3018
24	.2601	.2641	.2641	.2572	.2543
Max	2.5149	2.6189	2.5484	2.7664	2.7515
Min	.2427	.2641	.2641	.2543	.2543
Avg	1.1229	1.1828	1.1380	1.2521	1.2467

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074030 / 33KV PADALI

Feeder No / Name : 201 / 11KV PADALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.197	.2743	.1966	1.3611	1.4746
2	.197	.2743	.1989	1.3611	1.4575
3	.197	.2743	.1311	1.3611	1.4091
4		.2743	.1296	1.2536	1.3592
5		.2743	.1619	1.2894	1.3108
6		.2572	.2105	1.1462	1.1797
7			.1638	1.1999	1.1603
12	1.406	2.4006	2.5072		
13	2.2291	2.4291	2.6863		
14	2.692	2.3868	2.5431		
15	2.5034	2.3594	2.3282		
16	2.4006	2.1052	2.2207		
17	2.0576	1.9433	1.97		
18	.2572	.2294	.2507	.2458	.2401
19	.2572	.2321	.2686	.2458	.2572
20	.2915	.2267	.2686	.2629	.2572
21	.2572	.2458	.2328	.2321	.2743
22	.2572	.2103	1.3969	1.5402	1.8004
23	.2915	.1943	1.3253	1.5402	1.8004
24	.197	.2743	.1966	1.2894	1.4746
Max	2.692	2.4291	2.6863	1.5402	1.8004
Min	.197	.1943	.1296	.2321	.2401
Avg	.9805	.8877	.9694	1.0235	1.1040

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074030 / 33KV PADALI

Feeder No / Name : 202 / 11KV DAHID AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0358	.0343	.0324	1.3611	1.6194
2	.0358	.0343	.0324	1.3611	1.7166
3	.0358	.0343	.0328	1.3611	1.6712
4	.0358	.0343	.0324	1.3253	1.6907
5	.0358	.0343	.0324	1.3253	1.6057
6	.0358	.0343	.0328	1.2536	1.5546
7	.0358		.0324	1.3432	1.4091
10	1.8861	1.9433	2.0058		
11	2.2291	2.1052	2.2207		
12	2.2291	2.3266	2.5072		
13	2.0576	1.9433	2.3282		
16		2.2672	2.3282		
17	2.4006	2.1052	2.0058		
18	.0514	.0324	.0537	.0492	.0514
19	.0514	.0492	.0537	.0486	.0514
20	.0343	.0486	.0537	.0492	.0514
21	.0343	.0486	.0358	.0492	.0514
22	.0343	.0492	1.4685	1.8351	1.8004
23	.0343	.0324	1.3969	1.757	1.8004
24	.0358	.0343	.0328	1.3253	1.6712
Max	2.4006	2.3266	2.5072	1.8351	1.8004
Min	.0343	.0324	.0324	.0486	.0514
Avg	.5963	.6943	.8359	1.0317	1.1961

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074030 / 33KV PADALI

Feeder No / Name : 204 / 11 KV DAHID GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4					.1097
5		.1372			
7	.2172		.1753	.1448	.1187
11				.0678	
12	.0686	.0678	.0724	.0701	.0686
13				.0724	
14		.0648			
15			.0724		
16		.0914			
18	.12				
19					.1372
21			.1086		
24	.0724	.0686	.0678	.0724	.0732
Max	.2172	.1372	.1753	.1448	.1372
Min	.0686	.0648	.0678	.0678	.0686
Avg	.1196	.0860	.0993	.0855	.1015

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074030 / 33KV PADALI

Feeder No / Name : 205 / 11KV DEULGHAT GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2896	.2915	.2715	.2715	.2896
2	.2896	.3086	.2715	.2715	.2896
3	.3258	.3086	.2772	.2715	.2896
4	.362	.3429	.3224	.3077	.3258
5	.4706	.4115	.3582	.3982	.4066
6	.5792	.5316	.5792	.5068	.4706
7	.7059	.6344	.724	.6335	.6878
8	.6173	.5792	.6283	.6219	.6653
9	.6173	.5121	.543	.5175	.5316
10	.6001	.5121	.5068	.4706	.463
11	.4458	.3734	.4706	.3982	.4115
12	.5144	.3326	.362	.4108	.3601
13	.4458	.3658	.362	.362	.2915
14	.3258	.3258	.3258	.3734	.3258
15	.2572	.3258	.3077	.3258	.2572
16	.2915	.3696	.362	.3658	.3086
17	.4287	.4525	.362	.3658	.4287
18	.5144	.5853	.543	.5068	.6001
19	.5487	.5792	.543	.5601	.5658
20	.4287	.4755	.4344	.4525	.4287
21	.3944	.4294	.3801	.3982	.3772
22	.3601	.3658	.362	.3696	.3086
23	.3258	.2896	.3077	.3326	.2915
24	.2896	.2915	.2772	.2715	.2957
Max	.7059	.6344	.724	.6335	.6878
Min	.2572	.2896	.2715	.2715	.2572
Avg	.4345	.4164	.4117	.4068	.4029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074030 / 33KV PADALI

Feeder No / Name : 206 / 11 KV PADALI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0271	1.7147	1.7002	.2172	.1829
2	2.0271	1.7147	1.829	.2172	.1829
3	2.0995	1.6804	1.8099	.2172	.181
4	2.1176	1.7661	1.8461	.2896	.2896
5	2.1357	1.9033	1.885	.4344	.2915
6	2.1357	2.1434	2.2443	.6516	.567
7	2.2443	2.2462	2.4977	.7059	.724
8	.5144	.5506	.7316	.567	.5544
9	.4287	.5068	.5792	.4706	.5487
10	.3086	.2172	.3982	.2172	.2915
11	.2229	.1867	.3258	.181	.2058
12	.1715	.1448	.2172	1.9909	2.1091
13	.1543	.1463	.181	2.4025	2.2462
14	.1886	.1296	.181	2.0995	2.0405
15	.1715	.1463	.181	1.9662	1.8004
16	.2058	.181	.2172	2.2081	2.0062
17	.2572	.2534	.3258	2.3339	1.9719
18	.5144	.5487	.5792	.543	.463
19	.4801	.4706	.543	.5121	.463
20	.3429	.5068	.4706	.2715	.3086
21	.2572	.5853	.3258	.2614	.2572
22	.2401	1.0682	.2715	.181	.2058
23	.2229	1.2803	.2353	.181	.1715
24	1.9185	1.6118	1.6827	.2172	.1791
Max	2.2443	2.2462	2.4977	2.4025	2.2462
Min	.1543	.1296	.181	.181	.1715
Avg	.8911	.9043	.8858	.8057	.7601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074047 / 33 /11 KV GANESH NAGAR

Feeder No / Name : 201 / 11 KV Market

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5068	.5544	.5853	.4287	.5068
2	.4706	.5487	.5487	.4287	.4887
3	.4706	.5304	.5121	.4287	.4706
4	.5068	.5359	.4755	.4287	.4706
5	.543	.5304	.6584	.463	.543
6	.7783	.7316	.7316	.6516	.724
7	.8869	.9328	.8779	.9088	.9593
8	.9774	.9145	.9896	1.0288	1.0136
9	1.1222	.8962	1.0242	1.0498	1.0136
10	.9593	.8779	.9259	.9774	.9593
11	.9511	.9511	.8745	.9412	.961
12	1.0059	.8779	.7888	.8326	.8962
13	1.0349	.8048	.7888	.7783	.7577
14	.7682	.7682	.7202	.6516	.6697
15	.6036	.7316	.6687	.6878	.7023
16	.6401	.7316	.6344	.6516	.6653
17	.7865	.7316	.703	.7421	.7421
18	.9774	.9877	.8916	.9955	1.0136
19	1.0242	1.0242	.9259	.9774	1.0136
20	.8596		.823	.905	.7499
21	.7762	.7682	.703	.7964	.7392
22	.695	.7468	.6173	.6697	.6767
23	.6283	.6722	.5144	.6154	.6099
24	.543	.567	.6173	.463	.543
Max	1.1222	1.0242	1.0242	1.0498	1.0136
Min	.4706	.5304	.4755	.4287	.4706
Avg	.7715	.7572	.7333	.7292	.7454

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074047 / 33 /11 KV GANESH NAGAR

Feeder No / Name : 202 / 11 KV Ganesh Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.543	.6219	.6584	.5144	.6154
2	.5068	.6099	.6401	.5144	.543
3	.5068	.5853	.5853	.5144	.543
4	.543	.5853	.5487	.5144	.543
5	.5973	.6036	.6401	.5487	.7602
6	.8145	.7392	.7316	.6344	.8326
7	1.1946	1.0349	.9145	.8573	1.1222
8	1.1584	.9511	1.0242	.9431	1.1765
9	.905	.9694	1.0242	.9593	1.0136
10	.8869	.9055	.823	.8869	.905
11	.7682	.823	.7716	.7602	.823
12	.7682	.8779	.7202	.7602	.7343
13	.823	.8048	.6516	.7964	.6878
14	.7964	.8413	.6001	.6697	.6219
15	.7499	.8779	.6001	.724	.6767
16	.7682	.8779	.6516	.7421	.823
17	.7682	.8413	.7202	.8145	.7964
18	.9511	1.0608	.8745	.9593	.9774
19	1.0242	1.134	.8916	1.086	1.0349
20	.9511	1.0608	.8402	.9955	.9328
21	.924	.9877	.8573	.9231	.8413
22	.823	.8413	.7545	.8145	.7316
23	.695	.7316	.6859	.7602	.6283
24	.6154	.6401	.695	.5487	.6878
Max	1.1946	1.134	1.0242	1.086	1.1765
Min	.5068	.5853	.5487	.5144	.543
Avg	.7951	.8336	.7460	.7601	.7938

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074047 / 33 /11 KV GANESH NAGAR

Feeder No / Name : 203 / 11 KV JAISTAMB-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.1829	.2195	.1715	.181
2	.1629	.1629	.1829	.1543	.1629
3	.1629	.1646	.1829	.1543	.1629
4	.181	.1829	.1829	.1543	.1629
5	.1991	.1829	.2195	.1715	.1991
6	.2534	.2378	.2561	.2229	.2534
7	.3982	.3109	.3292	.2743	.3982
8	.3982		.3292	.3086	.3439
9	.3982	.2926	.2926	.3077	.2896
10	.3439	.2561	.2743	.3258	.2534
11	.3292	.2561	.2572	.2172	.2195
12	.2561	.2561	.2401	.2353	.2743
13	.2587	.2561	.2572	.2353	.2195
14	.2195	.2378	.2229	.2172	.2195
15	.2012	.2195	.2058	.2172	.2012
16	.2012	.2561	.2058	.2172	.1829
17	.2378	.2195	.2401	.2172	.2353
18	.2896	.2926	.2743	.2172	.2896
19	.3109	.3292	.2915	.2896	.2926
20	.2926	.3292	.3086	.2715	.2926
21	.2743	.2926	.2572	.2534	.2561
22	.2561	.2743	.2229	.2353	.2378
23	.2195	.2195	.2058	.2172	.2012
24	.1991	.2012	.2195	.1715	.1991
Max	.3982	.3292	.3292	.3258	.3982
Min	.1629	.1629	.1829	.1543	.1629
Avg	.2594	.2441	.2449	.2274	.2387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074047 / 33 /11 KV GANESH NAGAR

Feeder No / Name : 204 / 11 kv Hanwatkhed Feeder SHEDDABLE RURAL
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0724	.1463	.0686	.0543
2	.0514	.0905	.1463	.0686	.0514
3	.0514	.0914	.1463	.0686	.0543
4	.0686	.0732	.1829	.0686	.0724
5	.0857	.0914	.1829	.0857	.0905
6	.0857	.0905	.1829	.0857	.0905
7	.0857	.0549	.1829	.1029	.0905
8	.0857	.0732	.1829	.1029	.0686
9	.0857	.0914	.1829	.0905	.0905
10	.0857	.1097	.1029	.0905	.1086
11	.1097	.2012	.0857	.0905	.0732
12	.1097	.2195	.1029	.0905	
13	.1097	.2195	.1029	.0857	.0549
14	.1086	.2012	.1029	.0905	.0732
15	.0732	.1829	.1029	.1086	.0914
16	.0732	.2012	.1029	.1086	.1097
17	.0732	.2054	.1029	.1086	.0857
18	.1097	.2012	.0686	.0686	.0905
19	.1097	.1829	.0686	.0857	.0914
20	.1086	.1829	.0686	.0857	.0914
21	.1097	.168	.0686	.0857	.0732
22	.0914	.168	.0686	.0857	.0905
23	.0914	.1494	.0686	.0905	.0914
24	.0686	.0914	.1463	.0686	.0686
Max	.1097	.2195	.1829	.1086	.1097
Min	.0514	.0549	.0686	.0686	.0514
Avg	.0868	.1422	.1208	.0869	.0807

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074047 / 33 /11 KV GANESH NAGAR

Feeder No / Name : 205 / 11 kv Balaji Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)
5		.1991
10	.3439	
Max	.3439	.1991
Min	.3439	.1991
Avg	.3439	.1991

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074074 / 33KV Sakhali Sub Station

Feeder No / Name : 201 / 11 KV Sakhali GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3429	.3429	.3429	.3429
2	.3944	.3429	.3429	.3429	.3429
3	.3944	.3429	.3429	.3429	.3429
4	.3772	.3772	.4115	.3772	.3772
5	.4115	.8573	.6516	.6001	.5658
6	.9602	1.046	.9259	1.166	1.1145
7	1.3717	1.3546	1.3375	1.4918	1.3375
8	1.2346	1.166	1.3032	1.3375	1.3032
9	1.0631	.9602	1.0631	1.166	1.0974
10	.703	.6859	.823	.7202	.7545
11	.5144	.4458	.5658	.4801	.5487
12	.4801	.4115	.4458	.4115	.4458
13	.4287	.3772	.4115	.3429	.3086
14	.3772	.4458	.3944	.3429	.3429
15	.3772	.4115	.3772	.3429	.3772
16	.4287	.4801	.5144	.4458	.4458
17	.583	.6859	.6516	.583	.6516
18	1.0288	1.0288	.9945	.9431	.9945
19	1.046	.9945	.9945	1.0117	.9602
20	.7716	.7545	.8573	.7545	.7545
21	.6001	.583	.6001	.583	.583
22	.4287	.4458	.4458	.4287	.4458
23	.3772	.3772	.3772	.3601	.3772
24	.3772	.3429	.3772	.3429	.3429
Max	1.3717	1.3546	1.3375	1.4918	1.3375
Min	.3772	.3429	.3429	.3429	.3086
Avg	.6294	.6359	.6480	.6359	.6316

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074074 / 33KV Sakhali Sub Station

Feeder No / Name : 202 / Sakhali Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7888	.8573	.7202	.1029	.0686
2	.823	.8573	.7202	.1029	.0686
3	.8573	.8573	.7202	.1029	.0686
4	.8573	.9431	.7545	.1029	.0686
5	.8916	1.0288	.8573	.1029	.0686
6	.9431	1.1831	1.0288	.1029	.0686
7	1.1145	1.1831	1.0288	.1029	.0686
10				.7888	.8573
11				1.406	1.5432
12				1.5432	1.7147
13				1.7833	1.8519
14				1.8176	1.8519
15				1.8519	1.406
16				1.749	1.4746
17				1.5775	1.3032
19	.1372	.1029	.1372	.0857	.1029
20	.1372	.1029	.1372	.0857	.1029
21	.1372	.1029	.1372	.0857	.1029
22	.1029	.6173	.1029	.0686	.0686
23	.1029	.6859	.1029	.0686	.0686
24	.7716	.823	.6859	.1029	.0686
Max	1.1145	1.1831	1.0288	1.8519	1.8519
Min	.1029	.1029	.1029	.0686	.0686
Avg	.5896	.7188	.5487	.6540	.6189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074074 / 33KV Sakhali Sub Station

Feeder No / Name : 203 / SHIRPUR AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0686	.0686	.8573	1.286
2	.0686	.0686	.0686	.8573	1.2003
3	.0686	.0686	.0686	.7716	1.1145
4	.0686	.0686	.0686	.7716	1.1145
5	.2401	.0686	.0686	.7202	1.1145
6	.0686	.0686	.0686	.6859	1.1145
7	.0686	.0686	.0686	.6859	1.2003
8		.1372			
10	1.2346	1.3717	1.2346		
11	1.5432	1.7147	1.4918		
12	1.9204	1.9204	1.989		
13	1.8347	2.0233	1.9204		
14	1.989		1.8176		
15	1.8861	1.9204	1.8519		
16	1.7147	1.7833	1.8861		
17	1.5432	1.5775	1.4746		
19	.0686	.0686	.1029	.0686	.0686
20	.0686	.0686	.0686	.0686	.0686
21	.0686	.0686	.0686	.0686	.0686
22	.0686	.0686	.9259	1.4403	1.4403
23	.0686	.0686	.8916	1.3717	1.3375
24	.0686	.0686	.0686	.8916	1.3717
Max	1.989	2.0233	1.989	1.4403	1.4403
Min	.0686	.0686	.0686	.0686	.0686
Avg	.7014	.6353	.7749	.7122	.9615

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074085 / Bhadola

Feeder No / Name : 201 / Bhadola gaathan

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3423	.3292	.3429	.3361	.3395
2	.3398	.3292	.3429	.3292	.3423
3	.3402	.3292	.3429	.3109	.3423
4	.3402	.3292	.3429	.3292	.3395
5	.378	.3475	.381	.3547	.3395
6	.5664	.5304	.5716	.4207	.5658
7	.7356	.695	.7621	.6161	.6845
8	.9054	.823	.8383	.7655	.1327
9	1.0829	1.0242	.9526	.9896	.9867
10	1.134	1.1812	.7133	.9887	1.0479
11	1.1016	1.0479	.8779	.9697	
12	.6401	.9907	.9145	.9798	.9526
13	1.0242	1.0479	.8215	1.0353	1.0479
14	.9877	1.0098	.7865	.9788	1.0669
15	.9694	.9907	.7499	.8471	.9526
16	.9511	1.0288	.8316	.9412	.9145
17	1.0059	.9907	.8962	.9619	.8383
18	.8596	1.0098	.7682	.9412	.8002
19	.7133	.8573	.7133	.6655	.724
20	.5853	.724	.6401	.6602	.6668
21	.5121	.5716	.5415	.6602	
22	.4024	.4572	.4251	.4373	
23	.3658	.381	.3292	.3803	
24	.3395	.3292	.3429	.3326	.3423
Max	1.134	1.1812	.9526	1.0353	1.0669
Min	.3395	.3292	.3292	.3109	.1327
Avg	.6926	.7231	.6345	.6763	.6713

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074085 / Bhadola

Feeder No / Name : 202 / Bhadola Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1521	.1334	.1334	.759	1.1385
2	.1521	.1143	.1334	.7401	1.1374
3	.1509	.1143	.1334	.7021	1.1385
4	.1509	.1143	.1334	.7021	1.1374
5	.1521	.1334	.1334	.7401	1.1789
6	.1509		.1334	.797	1.2359
7	.1509	.1334	.1334	.8349	1.308
8	.1509	.1334	.1334	.1331	.132
9	.1334	.1334	.1334	.1327	.1139
10	.9717	.9717	.1331	.1328	.1143
11	1.5051	1.7147	1.6542	.1327	.1143
12	1.7147	1.848		.1318	.1143
13	1.7528	1.9052	1.8063		.1143
14	1.7718	1.9433	1.7837		.1143
15	1.6956	1.8099	1.8253		.1143
16	1.5623	1.7147	1.7846		.1143
17	1.3527	1.5242	1.6319	.1882	.1334
18	.1715	.1334	.1331	.1694	.1334
19	.1524	.1334	.1331	.1901	.1334
20	.1334	.1334	.1331	.1886	.1334
21	.1334	.1334	.1517	.1698	
22	.1334	.1334	.6072	1.1789	
23	.1334	.1334	.7211	1.1765	
24	.1518	.1334	.1334	.7583	1.1374
Max	1.7718	1.9433	1.8253	1.1789	1.308
Min	.1334	.1143	.1331	.1318	.1139
Avg	.6117	.6685	.6014	.4979	.5234

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074089 / Maintenance Unit Sub-station

Feeder No / Name : 201 / Shivshankar Nagar SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6268	.7545	.6859	.7468	.6447
2	.6268	.7167	.6859	.7655	.6447
3	.6268	.7545	.703	.7468	.6805
4	.6268	.7922	.7373	.7842	.7522
5	.7164	.8299	.8059	.8589	.8238
6	.8954	.8676	.8059	.9335	.8954
7	.9671	1.0374	.8059	1.0082	.9671
8	1.0566	1.094	.9431	1.0082	1.0387
9	1.0269	.8573	.9088	.8238	.9431
10	.8962	.7888	.9335	.7164	.9054
11	.8215	.7545	.8215	.7164	.811
12	.8215	.7202	.7468	.6805	.7922
13	.7842	.6859	.7095	.6805	.7545
14	.7468	.6859	.7095	.6805	.7167
15	.7468	.6516	.6908	.6626	.679
16	.7095	.6516	.6722	.7095	.7095
17	.7468	.6516	.7095	.7468	.7468
18	.8215	.6687	.8402	.8402	.8402
19	.9335	.7202	.8573	.8402	.9335
20	.9808	.7202	1.0082	.8589	.9522
21	.9808	.7373	.9335	.8589	
22	.9054	.7545	.811	.7164	
23	.8299	.7373	.7468	.6805	
24	.6805	.7545	.703	.7095	.6447
Max	1.0566	1.094	1.0082	1.0082	1.0387
Min	.6268	.6516	.6722	.6626	.6447
Avg	.8156	.7661	.7906	.7822	.8036

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074089 / Maintenance Unit Sub-station

Feeder No / Name : 202 / Bhagirath SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0716	.0747	.0686	.0739	.0716
2	.0716	.0747	.0686	.0739	.0716
3	.0716	.0747		.0739	.0716
4	.1075	.0747	.0857	.0739	.1075
5	.1075	.0934	.12	.0924	.1075
6	.1075	.112	.12	.1109	.1075
7	.1254	.112	.12	.1478	.1254
8	.1075	.1029	.12	.1109	.1075
9	.1254	.12	.12	.0895	.112
10	.1254	.12	.1109	.0716	.1307
11	.1433	.12	.0924	.0716	.1307
12	.1433	.1029	.0924	.1075	.1307
13	.1433	.1029	.0924	.1254	.112
14	.1433	.0857	.0924	.1075	.112
15	.1075	.0857	.0924	.1075	.112
16	.1075	.0857	.0924	.0895	.1075
17	.1254	.0857	.0924	.0716	.1075
18	.1254	.0857	.1294	.1075	.1075
19	.1075	.0857	.1294	.1075	.1075
20	.0934	.0857	.1294	.0716	.0895
21	.0934	.0857	.1294	.0716	
22	.0934	.0857	.1294	.0716	
23	.0747	.0857	.1109	.0716	
24	.0895	.0747	.0686	.1109	.0716
Max	.1433	.12	.1294	.1478	.1307
Min	.0716	.0747	.0686	.0716	.0716
Avg	.1088	.0924	.1047	.0922	.1048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074089 / Maintenance Unit Sub-station

Feeder No / Name : 205 / SAV AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7013	1.5432	1.5546	.1067	.1075
2	1.7372	1.5432	1.5546	.1067	.1075
3	1.7909	1.3889	1.7833	.1067	.1075
4	1.7909	1.5432	1.6461	.1219	.1075
5	1.97	1.6975	1.6461	.1372	.1433
6	2.0595	1.9753	1.8519	.1219	.1433
7	2.1312	1.8519	1.869	.1372	.1791
8	.197	.2058	.1372	.1524	.1543
9		.1886	.1372	2.8654	.1543
10		.1524	.1372	3.2236	2.1605
11		.1524	.1219	3.546	2.4691
12		.1067	.1219	3.8146	2.7778
13		.1067	.1219	3.94	2.9321
14	.1433	.1067	.1219		2.9012
15	.1307	.0914	.1219	3.528	2.7778
16	.1254	.1219	.1219	3.1878	.8954
17	.1433	.1219	.1372	2.7221	.8954
18	.1791	.1219	.1638	.1612	.1612
19	.1791	.1372	.1372	.1612	.1791
20	.1235	.1524	.1219	.197	.1612
21	.1235	.1372	.1067	.197	
22	.1235	1.166	.1067	.1433	
23	.1235	1.5432	.1067	.1433	
24	1.6118	1.6975	1.749	.1067	.1075
Max	2.1312	1.9753	1.869	3.94	2.9321
Min	.1235	.0914	.1067	.1067	.1075
Avg	.8624	.7439	.6532	1.2577	.9344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074089 / Maintenance Unit Sub-station

Feeder No / Name : 206 / Yelgaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1791	.1581	.1715	.1311	.1254
2	.1791	.1581	.1715	.1475	.1254
3	.1791	.1898	.2058	.1638	.1254
4	.2149	.1898	.2058	.1638	.2686
5	.2507	.2214	.2401	.1966	.2865
6	.2865	.2214	.2572	.2294	.3224
7	.3045	.253	.2743	.2622	.3403
8	.3403	.3086	.2229	.2622	.3045
9		.2743	.1886	.2149	.1898
10	.2865	.2743	.1638	.1791	.1898
11	.2507	.2401	.1475	.1612	.1581
12	.1791	.2401	.1311	.1254	.1581
13	.1791	.2058	.1147	.1433	.1265
14	.1433	.1715	.1147	.1433	.1265
15	.1254	.1543	.1311	.1433	.1265
16	.1254	.1543	.1311	.1433	.1254
17	.1433	.1372	.1311	.2149	.1254
18	.1791	.1715	.1966	.2328	.197
19	.2507	.1543	.2294	.197	.2686
20	.2056	.1715	.1638	.197	.2328
21	.1739	.1715	.1475	.1791	
22	.1581	.1372	.1147	.1433	
23	.1581	.1372	.1311	.1433	
24	.1791	.1581	.1372	.1311	.1254
Max	.3403	.3086	.2743	.2622	.3403
Min	.1254	.1372	.1147	.1254	.1254
Avg	.2031	.1939	.1718	.1770	.1928

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074093 / Sagwan Sub-station

Feeder No / Name : 201 / 11 kv Indira Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17	13-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2172		.1629	.1646		
2	.2241		.1629	.1646		
3	.2353		.1629	.1463		
4	.2353		.1629	.1463		
5	.2534		.181	.1829		
6	.2534		.1991	.2896		
7	.3439		.2896	.3801		
8			.362	.3841		
9			.362	.3292		
10	.3109	.2715		.3077	.2561	
11	.2743	.2534		.2896	.2378	
12		.2353		.2353	.2195	
13		.2172		.2353	.2012	
14		.2172		.2353	.1848	
15	.3292	.2172		.2172	.1478	
16	.2743	.2172			.2012	
17		.2534	.2378		.2353	
18	.3258	.3258	.3109		.3077	
19	.3258	.3077	.3142		.2896	
20	.3258	.2715	.2926		.2715	
21	.3258	.2534	.2561		.2715	
22	.2534	.2353	.2195			
23			.2012			
24	.2172		.181	.1829		.1991
Max	.3439	.3258	.362	.3841	.3077	.1991
Min	.2172	.2172	.1629	.1463	.1478	.1991
Avg	.2779	.2520	.2387	.2432	.2353	.1991

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074093 / Sagwan Sub-station

Feeder No / Name : 202 / 11 kv Ram Nagar Feeder SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0171	.0181	.0183	.0171
2	.0181	.0171	.0181	.0183	.0171
3	.0181	.0171	.0181	.0183	.0171
4	.0181	.0171	.0181	.0183	.0171
5	.0181	.0171	.0018	.0183	.0171
6	.0181	.0171	.0181	.0362	.0171
7	.0181	.0171	.0181	.0366	.0171
8		.0171	.0181	.0362	.0343
9		.0171	.0181	.0362	
10	.0366	.0181	.0343	.0362	.0362
11	.0366	.0181	.0171	.0362	.0366
12	.0183	.0181	.0171	.0181	.0181
13	.0183	.0181	.0171	.0181	.0183
14	.0185	.0181	.0171	.0181	
15	.0183	.0362	.0171	.0362	.0366
16	.0183	.0362	.0171	.0343	.0366
17	.0181	.0181	.0366	.0343	.0362
18	.0181	.0181	.0185	.0514	.0362
19	.0181	.0181	.0183	.0514	.0181
20	.0181	.0181	.0183	.0343	.0181
21	.0181	.0181	.0183	.0343	.0181
22	.0181	.0181	.0183	.0343	
23	.0171		.0183	.0343	
24	.0191	.0171	.0181	.0183	.0171
Max	.0366	.0362	.0366	.0514	.0366
Min	.0171	.0171	.0018	.0181	.0171
Avg	.0199	.0192	.0187	.0303	.0240

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074093 / Sagwan Sub-station

Feeder No / Name : 205 / JAMBHRUN AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0543	.0343	.0343	.8583	1.3717
2	.0543	.0343	.0343	.8322	1.4575
3	.0543	.0343	.0343	.8642	1.4575
4	.0724	.0343	.0343	.9069	1.4575
5	.0724	.0343	.0514	.9878	1.5432
6	.0724	.0857	.0686	1.0242	1.5432
7	.0905	.12	.0686	1.0883	1.7147
8		.0686	.0686	.0655	.0686
9		.0686	.0543	.0655	
10	.9717	2.009	1.3717	.0514	.0492
11	1.6644	2.2443	1.989	.0343	.0497
12	1.8404	2.2262	1.9204	.0343	.0492
13	1.9364	2.2081	1.9204	.0343	.0663
14	1.6324	2.2262	1.8861	.0343	.0503
15	1.6804	2.2443	1.9204	.0343	.0492
16	1.9204		1.8861		.0492
17	2.2624	1.9719	1.7284	.0686	.0171
18	.2353	.2401	.0655	.0857	.0686
19	.0905	.0686	.0663	.0857	.0686
20	.0724	.0686	.0663	1.5432	.0514
21	.0543	.0514	.0671	1.4403	.0514
22	.1057	.0343	.8002	1.4746	
23	.0343		.8322	1.4746	
24	.0724	.0343	.0343	.8259	1.2003
Max	2.2624	2.2443	1.989	1.5432	1.7147
Min	.0343	.0343	.0343	.0343	.0171
Avg	.6838	.7337	.7085	.6050	.5921

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

BULDANA SUB-DN[285] BU 2852

Substation No/ Name :- 074093 / Sagwan Sub-station

Feeder No / Name : 206 / 11 kv Ajijpur AG Feeder FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3032	1.4746	1.5604	.0686	.0686
2	1.3394	1.4403	1.5604	.0509	.0686
3	1.3394	1.4403	1.5775	.0686	.0686
4	1.4118	1.4403	1.5775	.0663	.0686
5	1.448	1.4746	1.6289	.116	.0686
6	1.7194	1.5432	1.6289	.1509	.0686
7	1.7375	1.6632	1.6289	.1475	.0686
8		.1372	.1715	.1696	.1715
9		.1372	.1715	.1492	
10	.1326	.1448	.1372		1.7444
11	.1492	.1629	.1372	1.9376	2.2405
12	.1526	.1629	.1372	2.4863	2.7686
13	.1886	.1629	.1372	2.6578	2.7515
14	.2058		.1715	2.7435	2.5766
15	.1677	.2353	.1715	2.7435	2.7206
16	.12	.1991	.1715	2.5377	2.0805
17	.181	.2058	.1715	2.4006	2.2291
18	.181	.1543	.1677	.1372	
19	.1448	.1372	.2058	.1372	
20	.1267	.1372	.1372	.1372	
21	.1086	.1029	.1029	.1372	
22	.1086	1.286	.1029	.0857	
23	.0857		.0857	.0857	
24	1.1946	1.4746	1.5432	.0686	.0857
Max	1.7375	1.6632	1.6289	2.7435	2.7686
Min	.0857	.1029	.0857	.0509	.0686
Avg	.6157	.6962	.6286	.8384	1.1676

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074001 / 33/11 KV AMDAPUR

Feeder No / Name : 201 / 11 KV AMDAPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.7716	.6859	1.0288	.7716
2	.6859	.8573	.5144	1.0288	.6859
3	.5144	.8573	.5144	1.0288	.6859
4	.5144	.9431	.4287	1.0288	.5144
5	.4287	1.0288	.3429	1.0288	.5144
6	.4287	1.0288	.3429	1.0288	.3429
12	2.572	1.2003	2.572	1.2003	2.572
13	2.572	1.286	2.7435	1.3717	2.7435
14	2.2291	1.2003	2.2291	1.3717	2.8292
15	2.4006	1.3717	2.4006	1.2003	2.572
16	2.4006	1.2003	1.8861	1.0288	2.2291
17	1.9719	.8573	1.8861	.9431	1.8861
18	1.8861	.8573	1.5432	.6859	1.5432
23	.6859	.7716	1.1145	.7716	
24	.7716	.6859	.7716	1.0288	.7716
Max	2.572	1.3717	2.7435	1.3717	2.8292
Min	.4287	.6859	.3429	.6859	.3429
Avg	1.3832	.9945	1.3317	1.0517	1.4758

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074001 / 33/11 KV AMDAPUR

Feeder No / Name : 202 / 11 KV MANGRUL AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	08-DEC-17	09-DEC-17
HR	Load (MW)	Load (MW)
1		.6001
2		.6001
3		.6001
4		.6001
5		.6001
6		.6001
23	.6001	
24		.6001
Max	.6001	.6001
Min	.6001	.6001
Avg	.6001	.6001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074001 / 33/11 KV AMDAPUR

Feeder No / Name : 203 / 11 KV UNDRI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.7716	1.2003	.6859	1.2003
2	.8573	.7716	1.0288	.6859	1.2003
3	.8573	.7716	1.0288	.6859	1.0288
4	.6859	.7716	.9431	.6859	1.0288
5	.6859	.7716	.9431	.6859	1.0288
6	.6859	.7716	.8573	.6859	1.0288
12	1.8861	2.2291	2.0576	1.7147	1.8861
13	2.2291	1.3717	1.8861		1.5432
14	1.8861	1.3717	1.8861		1.2003
15	1.8861	1.3717	1.8861	1.2003	1.7147
16	1.8861	1.3717	1.4575	1.5432	1.8861
17	1.5432	1.3717	1.3717	1.2003	1.7147
18	1.3717	1.7147	1.0288	2.0576	1.3717
23	.7716	1.2003	.6859	1.3717	
24	1.1145	.7716	1.2003	.6859	1.3717
Max	2.2291	2.2291	2.0576	2.0576	1.8861
Min	.6859	.7716	.6859	.6859	1.0288
Avg	1.2803	1.1603	1.2974	1.0684	1.3717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074001 / 33/11 KV AMDAPUR

Feeder No / Name : 204 / 11 KV AMDAPUR GFFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4115		.4287
2		.4115		.4287
3		.4115		.4287
4		.4801		.5144
5		.6859		.7716
6		1.1145		.9431
7		1.4575	1.3717	1.3717
8	1.286	1.2003	1.2003	1.3717
9	1.0288	1.0288	1.1145	
10	1.0288		.8573	
11	.8573		.6001	
12	.5144		.5144	
13	.4287		.4287	
14	.3429		.3429	
15	.3429		.3429	
16	.5144		.4287	
17	.6173		.6001	
18	1.2003		.9431	
19	1.1145		1.0288	
20	.8573		.8573	
21	.6859		.6001	
22	.5144		.5144	
23	.4287		.4287	
24		.4115		.4287
Max	1.286	1.4575	1.3717	1.3717
Min	.3429	.4115	.3429	.4287
Avg	.7352	.7613	.7161	.7430

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074001 / 33/11 KV AMDAPUR

Feeder No / Name : 206 / 11 KV UNDRI GFFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6859	.6001	.6859	.6859
2	.6859	.6516	.6001	.6859	.6859
3	.6859	.6516	.6859	.6859	.7716
4	.8573	.6859	.7716	.7716	.8573
5	.9431	.8573	.8573	.9431	.9431
6	1.0288	1.0288	1.0288	1.0288	1.1145
7	1.3717	1.3717	1.5432	1.3717	1.3717
8	1.286	1.2003	1.4575	1.3717	1.4575
9	1.2003	1.1145	1.2003	1.286	1.2003
10	1.2003	.9431	1.0288	1.0288	.8573
11	1.0288	.6859	.7716	.7716	.6001
12	.6859	.6001	.6859	.5144	.5144
13	.6859	.5144	.6001	.5144	.5144
14	.6001	.6001	.5144		.6001
15	.5144	.6859	.5144	.6859	.6859
16	.5487	.6859	.7716	.6859	.6859
17	.8573	.8573	.9431	.9431	.8573
18	1.3717	1.286	1.2003	1.3717	1.2003
19	1.3717	1.286	1.2003	1.3717	1.4575
20	1.2003	1.2003	1.0288	1.286	1.1145
21	1.0288	.9431	1.0288	1.0288	.9431
22	.8573	.7716	.6859	.8573	
23	.7202	.6859	.6859	.7716	
24	.7716	.6859	.6859	.6859	.6859
Max	1.3717	1.3717	1.5432	1.3717	1.4575
Min	.5144	.5144	.5144	.5144	.5144
Avg	.9245	.8616	.8788	.9282	.9002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074013 / 33/11 KV EKLARA

Feeder No / Name : 201 / 11 KV BORGAON 1PH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4419	1.3748	1.4419	.2263	.2263
2	1.4754	1.4251	1.4419	.2263	.2641
3	1.5089	1.4251	1.4419	.2641	.2829
4	1.6095	1.4754	1.4419	.3018	.3395
5	1.7695	1.5089	1.4754	.4191	.4715
6	1.8351	1.5424	1.5402	.7545	.6602
7	1.6766	1.4251	1.5074	.8676	.7545
8	.5281	.3353	.4572	.7922	.7167
9	.3772	.4715	.4904	.679	
10	.2263		.3018	2.0119	
11	.1132		.1886	2.2131	
12	.1509		.1905	2.2131	
13	.1886	.1509	.1509	2.2801	
14	.2263	.1524	.1886	2.1795	
15	.3018	.1886	.2263	2.1795	
16	.3018	.2263	.2641	2.0957	
17	.4715	.381	.3018	1.7604	
18	.5281	.5658	.4904	.3018	
19	.4715	.5335	.5658	.3395	
20	.3772	.4572	.5281	.3658	
21	.3018	.3018	.3772	.3772	
22	.2641	1.4754	.3395	.3018	
23	.2263	1.4754	.2641	.2829	
24	1.4419	1.3413	1.4419	.2641	.2263
Max	1.8351	1.5424	1.5402	2.2801	.7545
Min	.1132	.1509	.1509	.2263	.2263
Avg	.7422	.8682	.7107	.9874	.438

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074013 / 33/11 KV EKLARA

Feeder No / Name : 202 / 11 KV BHORSHI 1PH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1886	.1524	1.3748	1.5089
2	.1886		.1524	1.3108	1.3413
3	.1886	.2263	.1886	1.3748	1.3413
4	.2286	.2641	.2263	1.3763	1.1736
5	.3018	.3395	.2641	1.4419	1.0059
6	.4904	.4527	.3772	1.5257	.9221
7	.4572	.5281	.5716	1.4754	.8886
8	.381		.5281	.415	.3395
9	.3018	.3772	.415	.3395	.3018
10	1.9113	1.5927	1.8442	.1886	
11		2.2131	2.0454	.1509	
12	2.0454	2.2939	2.3594	.0943	
13	2.0957	2.4905	2.4577	.1132	
14	2.1795	2.3922	2.2939	.1886	
15	2.1795	2.3594	2.2611	.1886	
16	2.3472	2.3807	2.1956		
17	1.7604	2.1795	1.8778	.1509	
18	.4527	.4715	.3395	.1886	
19	.3772	.415	.3395	.2829	
20	.3395	.3395	.3429	.2263	
21	.2263	.3018	.2641	.2263	
22	.1886	.2641	1.3077	1.95	
23	.1509	.1524	1.3916	1.6617	
24	.2263	.1509	.1509	1.3748	1.5927
Max	2.3472	2.4905	2.4577	1.95	1.5927
Min	.1509	.1509	.1509	.0943	.3018
Avg	.8352	1.0170	1.0145	.7661	1.0416

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074013 / 33/11 KV EKLARA

Feeder No / Name : 203 / 11 KV EKLARA 1PH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2742	1.5089	1.2071	.9259	.5658
2	1.2742		1.2071	.9602	.5658
3	1.3077	1.5089	1.2407	.9602	.6602
4	1.5089	1.5927	1.2452	1.0288	.7545
5	1.8442	1.6766	1.8023	1.2003	.8488
6	2.1628	2.0287	1.8351	1.3077	.9431
7	2.1628	1.8778	1.7695		1.0374
8	1.5089	1.0374	1.4403	1.7772	1.1694
9	1.2689	1.2071	1.406	1.6598	1.1694
10	.9808	.811	1.0631	1.6766	
11	.8383	.6859	.9602	1.9281	
12	.7545	.5487	.8573	2.0119	
13	.503	.5487	.823	2.1795	
14	.4694	.503	.823	2.1795	
15	.5281	.5144	.823	2.2131	
16	.4904	.6516	.8383	2.2801	
17	.8865	.7202	.9259	2.146	
18	1.1317	1.406	1.3375	1.5089	
19	1.1317	1.4746	1.3375	1.226	
20	1.094	1.3717	1.2003	1.094	
21	1.0374	1.0059	1.0288	1.0562	
22	.9431	1.1736	1.0288	.7545	
23	.7545	1.2407	.9945	.7167	
24	1.2407	1.5089	1.2689	.9259	.5847
Max	2.1628	2.0287	1.8351	2.2801	1.1694
Min	.4694	.503	.823	.7167	.5658
Avg	1.1290	1.1567	1.1860	1.4660	.8299

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074013 / 33/11 KV EKLARA

Feeder No / Name : 204 / 11 kV KOLARA 1PH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.4715	.3772	.7377	.8886
2	.4115	.415	.3429	.7712	.9389
3	.4458	.4527	.3772	.7712	1.0898
4	.4801	.5658	.4115	.8048	1.2071
5	.5487	.7167	.5487	.8718	1.2574
6	.7888	.9054	.9602	1.0395	1.4251
7	.8916	.9054	.9945	1.0395	1.643
8	.8063	.9431	.8573	.7545	.6602
9	.7011	.9808	.7362	.6413	.7545
10	1.3413	1.2574	1.6095	.5281	
11	1.6598	1.643	1.7772	.4904	
12	1.7604	1.8442	1.7695	.3018	
13	1.7772	1.9281	1.7695	.2829	
14	1.8107	1.9113	1.9006	.2263	
15	1.7436	1.8351	1.6385	.2641	
16	1.7604	1.5729	1.5402	.2829	
17	1.2574	1.3435	1.4255	.4527	
18	.7209	.6173	.6173	.5658	
19	.7922	.7202	.6516	.7545	
20	.7922	.6661	.6173	.8488	
21	.7545	.5487	.5144	.6036	
22	.6602	.4207	.7377	.9556	
23	.5281	.3772	.7377	.9221	
24	.4458	.5281	.3772	.7377	.8886
Max	1.8107	1.9281	1.9006	1.0395	1.643
Min	.4115	.3772	.3429	.2263	.6602
Avg	.9704	.9821	.9704	.6520	1.0753

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074025 / 33/11 KV MERA KH

Feeder No / Name : 201 / 11 KV ANDHERA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.0288	1.0608
2			1.0288	
3			1.0117	1.0242
4			1.0631	1.0608
5			1.0631	
6			1.0802	1.0608
7			1.1145	1.0242
9	1.4198	1.5043		
10	1.4373	1.5581		
11	1.5249	1.6297		
12	1.5775	1.3375		
13	1.56	1.3375		
14	1.5249	1.3717		
15	1.4022	1.3889		
22		1.0802	1.1888	
23		1.0288	1.134	
24			1.0631	1.0974
Max	1.5775	1.6297	1.1888	1.0974
Min	1.4022	1.0288	1.0117	1.0242
Avg	1.4924	1.3596	1.0776	1.0547

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074025 / 33/11 KV MERA KH

Feeder No / Name : 202 / 11 KV ANTRI KH. AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0745	1.0498	.8954	
2	1.0745		.8596	
3	.985	1.0242	.8059	
4	1.2178	1.2308	.788	
5	.8954	1.39	1.0745	
6	.8954		1.3969	
7	.8954	1.3535	1.3432	
13				1.5089
14				1.286
15				1.3203
16				1.0802
17				.8413
24	.1075	1.0608	.9313	
Max	1.2178	1.39	1.3969	1.5089
Min	.1075	1.0242	.788	.8413
Avg	.8932	1.1849	1.0119	1.2073

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074025 / 33/11 KV MERA KH

Feeder No / Name : 204 / 11 KV ANTRI KH GFFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2686	.2743	.2865	.2915	.3109
2	.2629	.2743	.2865	.3086	.3109
3	.2686	.2743	.3224	.3429	.3292
4	.5373	.6584	.5373	.4973	.3292
5	1.2536	1.1946	.985	.8916	.5853
6	1.4327	1.4266	1.2536	1.286	1.0608
7	1.6118	1.4815	1.3253	1.4403	1.3717
8		1.2986	1.2894	1.2346	1.2437
9	1.0692	1.0974	1.1462	1.0288	1.0974
10	.7888			1.2174	
11	.7011		.8238	1.5261	
12	.5316		.463	1.5947	
13	.4252		.4115	.3429	
14	.2835		.2915	.3429	
15	.3366		.2915	.3601	
16	.3721		.4115	.4287	
17	1.0242		.8573	.9145	
18	1.1157		.9774	1.0974	
19	.8962		.8745	.695	
20	.6219		.6001	.695	
21	.5853		.4458	.439	
22	.3292		.3258	.3292	
23	.3109		.3086	.3109	
24	.2865	.2926	.3224	.2915	.3109
Max	1.6118	1.4815	1.3253	1.5947	1.3717
Min	.2629	.2743	.2865	.2915	.3109
Avg	.6658	.8273	.6451	.7461	.695

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074025 / 33/11 KV MERA KH

Feeder No / Name : 205 / 11 KV BHAROSA GFFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2686	.3077	.3045	.3086	.3109
2	.2686	.2896	.2865	.2915	.3109
3	.2686	.2896	.2865	.3086	.3292
4	.5373	.5792	.591	.6001	.6401
5	1.2536	1.2308	1.2536	1.1488	1.2254
6	1.4022	1.4632	1.4864	1.406	1.4998
7	1.5947	1.6278	1.576	1.5432	1.6461
8		1.4083	1.6118	1.3889	1.39
9	1.6124		1.2536	1.1488	1.134
10	.8764		.591		
11	.4607		.4298	.463	
12	.3898		.3601	.3086	
13	.3544		.3429	.2743	
14	.3189		.3258	.2743	
15	.3189		.3601	.3429	
16	.5493		.5487	.4973	
17	1.134		.9774	1.0242	
18	1.4083		1.2174	1.4266	
19	1.0242		1.0288	1.134	
20	.6584		.6516	.9145	
21	.5121		.4801	.439	
22	.3658		.3429		
23	.3292		.3258	.3658	
24	.3045	.3109	.3224	.3086	.3109
Max	1.6124	1.6278	1.6118	1.5432	1.6461
Min	.2686	.2896	.2865	.2743	.3109
Avg	.7048	.8341	.7064	.7235	.8797

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074025 / 33/11 KV MERA KH

Feeder No / Name : 206 / 11 KV DEULGAON GHUBE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4115	.4207
2			.4115	
3			.4458	.415
4			.463	
5			.9259	.5121
6			.4287	.6219
7			.463	.5853
9	.6733	1.0208		
10	.8764	.9671		
11	.9114	.9313		
12	.9816	.9602		
13	1.0166	1.0117		
14	1.0341	.9945		
15	.9465	.9259		
22		.3944	.5121	
23		.3772	.4755	
24			.3944	.439
Max	1.0341	1.0208	.9259	.6219
Min	.6733	.3772	.3944	.415
Avg	.9200	.8426	.4931	.499

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074063 / 33/11 KV CHIKHLI

Feeder No / Name : 201 / 11 KV RAUT WADI (TOWN)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2286		.2587	.2477
2		.2667		.2427	.2286
3		.3048		.2378	.2858
4		.3048		.2957	.3048
5		.3239		.3326	.3429
6		.4382	.3292	.3696	.381
7		.5525	.4251		.4954
8		.4191	.5544	.499	.5716
9		.4191	.4887	.4294	.5335
10	.4382	.4191	.439		.4382
11	.381	.3439	.4066		
12	.3429	.3077	.3696	.2896	
13	.3048	.2534	.3511	.2858	
14	.2667	.2534	.3326	.2858	
15	.2858	.2743	.3547	.2667	
16	.3239	.3258	.3326	.2667	
17	.3429	.3292	.3881	.3239	
18	.4572	.4572		.4191	
19	.4954	.462	.4435	.4382	
20	.4763		.4207	.4382	
21	.4382		.3881	.4191	
22		.3696	.3292	.362	
23	.3239	.2926		.3048	
24		.2858	.2561	.2772	.2858
Max	.4954	.5525	.5544	.499	.5716
Min	.2667	.2286	.2561	.2378	.2286
Avg	.3752	.3469	.3888	.3354	.3741

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074063 / 33/11 KV CHIKHLI

Feeder No / Name : 202 / 11 KV RAIPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1719			
2	2.1529			
3	2.2291			
4	2.2672			
5	2.3243			
6	2.3434	2.1795		
7	2.4577	2.1963		
10				2.0576
12			2.7999	
13			3.315	
14			3.3722	
15			3.315	
16			3.2579	
17			3.1626	
22	1.7269			
23	1.9113			
24	2.21	2.0454		
Max	2.4577	2.1963	3.3722	2.0576
Min	1.7269	2.0454	2.7999	2.0576
Avg	2.1795	2.1404	3.2038	2.0576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074063 / 33/11 KV CHIKHLI

Feeder No / Name : 203 / 11 KV SHEL SOOR GFFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.743			.6859
2		.8192		.6838	.743
3		.9335		.6838	.8383
4		1.0288		.7842	.9717
5		1.1431		.924	1.2003
6		1.3908	1.4563	1.134	1.4289
7		1.8099	1.8111	1.5154	1.6385
8		1.8099	1.8298	1.4784	1.5623
9		.9335	1.0082	.9795	1.4289
10	1.2765	.7811	1.2197		1.2193
11	1.1431	.6099	1.1458		
12	1.0669	.5175	1.0425	1.3756	
13	1.0479	1.0903	.9795	1.3908	
14	1.0479	1.1088	.9522	1.3336	
15	1.0669	1.1273	.9694	1.2955	
16	1.0288		1.0349	1.3717	
17	1.2003	1.1643	1.0059	1.4289	
18	.8954		1.2752	1.5242	
19	1.3908	1.419	1.1949	.9717	
20	1.2574		.9511	1.1622	
21	1.2193		.8048	1.0098	
22		.9795	.7023	.8764	
23	.9335	.9055	.6653	.7811	
24		.7811	.8326	.6468	.724
Max	1.3908	1.8099	1.8298	1.5242	1.6385
Min	.8954	.5175	.6653	.6468	.6859
Avg	1.1211	1.0548	1.0990	1.1120	1.1310

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074063 / 33/11 KV CHIKHLI

Feeder No / Name : 204 / 11 KV SAKEGAON GFFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1905		.1663	.1905
2		.2286		.168	.2477
3		.2667		.1867	.3429
4		.3429		.2561	.4001
5		.4382		.3547	.4763
6		.5906	.5175	.5228	.5525
7		.724	.7095	.7207	.7621
8		.6097	.6468	.6219	.5525
9		.4763	.5249	.5359	.4763
10	.3239	.4001	.3982		.4572
11	.2286	.2534	.2587		
12	.2096	.2172	.2328	.1991	
13	.1715	.1448	.2033	.1905	
14	.1905	.1629	.1867	.1905	
15	.1715	.181	.1848	.1715	
16	.2096	.1991	.1829	.1905	
17	.3429	.3109	.2587	.3048	
18	.5525	.4572		.5335	
19	.5144	.462	.4481	.5335	
20	.381		.3142	.381	
21	.2667		.2402	.3048	
22		.2172	.1848	.2477	
23	.2096	.181	.1646	.2096	
24		.2096			
Max	.5525	.724	.7095	.7207	.7621
Min	.1715	.1448	.1646	.1663	.1905
Avg	.2902	.3302	.3327	.3329	.4458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074063 / 33/11 KV CHIKHLI

Feeder No / Name : 206 / 11 KV SHEL SOOR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.1469	1.9052
2				1.1768	1.8861
3				1.1961	1.8099
4				1.2452	1.848
5				1.326	1.8861
6				1.3094	1.9243
7				1.5051	2.0195
10	1.829		1.9393		
11	2.3624		2.3102		
12	2.5911	2.3868	2.4697		
13	2.7435	2.652	2.5692		
14	2.7625	2.6189	2.4905		
15	2.6863	2.5857			
16	2.5911	2.3868	2.3644		
17	2.3053		2.0222		
22				2.0195	
23			1.1934	2.0767	
24				1.2431	2.0576
Max	2.7625	2.652	2.5692	2.0767	2.0576
Min	1.829	2.3868	1.1934	1.1469	1.8099
Avg	2.4839	2.5260	2.1699	1.4245	1.9171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074080 / 33/11 KV MURADPUR

Feeder No / Name : 201 / 11 KV MURADPUR GFFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)
14		.2321
15	.213	
16	.2984	
Max	.2984	.2321
Min	.213	.2321
Avg	.2557	.2321

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074080 / 33/11 KV MURADPUR

Feeder No / Name : 202 / 11 KV YEOTA AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	12-DEC-17
HR	Load (MW)
14	.7922
Max	.7922
Min	.7922
Avg	.7922

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074080 / 33/11 KV MURADPUR

Feeder No / Name : 203 / 11 KV BHALGAON AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	08-DEC-17
HR	Load (MW)
15	.9957
Max	.9957
Min	.9957
Avg	.9957

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074081 / 33/11 KV MANGRUL (Nanghare)

Feeder No / Name : 201 / 11 KV WARKHED AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4746		1.5089		1.4232
2	1.4746		1.4746		1.4232
3	1.4403		1.4403		1.3375
4	1.4232		1.4403		1.3375
5	1.4232		1.4403		1.3375
6	1.4232		1.4403		1.3717
7		1.9547		1.6975	
8		1.989			
9		1.989		1.9376	
10		2.0919			
11		2.0233		1.9204	
12		1.9719		1.8004	
13		1.989		1.6289	
14		1.8004		1.5432	
23		1.5947		1.3375	
24	1.5432		1.5775		1.4403
Max	1.5432	2.0919	1.5775	1.9376	1.4403
Min	1.4232	1.5947	1.4403	1.3375	1.3375
Avg	1.4575	1.9338	1.4746	1.6951	1.3816

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074081 / 33/11 KV MANGRUL (Nanghare)

Feeder No / Name : 202 / 11 KV MANGRUL GFFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.4801	.4287	.3944	.3944
2	.4458	.4801	.4287	.4287	.3944
3	.4801	.6173	.4801	.4801	.4458
4	.583		.6001	.6687	.6516
5	.8059		.7373	1.0288	1.4403
6	1.3032		1.2003	1.2003	1.4403
7	1.6461	1.5947	1.5775	1.6118	1.6289
8	1.4746	1.6289	1.5261		1.4232
9	1.286	1.2346	1.2174	1.286	1.1317
10	.823	.9431	.9431	.9431	.9431
11	.6859	.703	.7545	.8573	.703
12	.5144	.4973	.5144	.4973	.4973
13	.4801	.3944	.4115	.4287	.3944
14	.4458	.4287	.3944	.3772	.4287
15	.3772	.4115	.4115	.4287	.4287
16	.583	.5658	.5144		.463
17	.8745	.8059	.6859		.7202
18	1.1831	1.1831	.9088	.8745	1.0288
19	.9259	1.0288	1.0117	.8573	1.0117
20	.6173	.7373	.7202	.823	.6859
21	.5658	.583	.5144	.5144	.5487
22	.4973	.4801	.463	.4973	.463
23	.4458	.4287	.3772	.4115	
24	.4458	.4458	.4287	.3944	.4115
Max	1.6461	1.6289	1.5775	1.6118	1.6289
Min	.3772	.3944	.3772	.3772	.3944
Avg	.7473	.7463	.7187	.7145	.7686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074081 / 33/11 KV MANGRUL (Nanghare)

Feeder No / Name : 203 / 11 KV DONGERGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.7661		1.7661	
2		1.7661		1.7661	
3		1.7318		1.7147	
4		1.749		1.6975	
5		1.7833		1.6632	
6		1.8176		1.5947	
7	1.989		2.0233		1.8176
8	2.1262		2.2291		2.1434
9	2.1948		2.452		2.5206
10	2.0233		2.1948		2.452
11	2.0233		2.2119		2.2634
12	2.2805		2.3663		1.9376
13	1.9547		2.0748		1.9376
14	1.9204		1.9719		1.8176
23	1.7833		1.7833		
24		1.7833		1.7661	
Max	2.2805	1.8176	2.452	1.7661	2.5206
Min	1.7833	1.7318	1.7833	1.5947	1.8176
Avg	2.0328	1.7710	2.1453	1.7098	2.1112

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074081 / 33/11 KV MANGRUL (Nanghare)

Feeder No / Name : 204 / 11 KV ISOLI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8573		.823	
2		.7888		.823	
3		.7888		.823	
4		.7888		.823	
5		.7202		.823	
6		.6859		.823	
7	1.3889		.8916		1.0288
8	1.7318		1.406		1.5089
9	1.9204		1.5432		1.749
10	1.8176		2.0233		2.0405
11	1.8519		1.3375		1.6632
12	1.8519		2.0233		1.5432
13	1.7147		1.7833		1.3889
14	1.5432		1.4232		1.3032
23	.8745		.8745		
24		.8573			
Max	1.9204	.8573	2.0233	.823	2.0405
Min	.8745	.6859	.8745	.823	1.0288
Avg	1.6328	.7839	1.4784	.823	1.5282

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074081 / 33/11 KV MANGRUL (Nanghare)

Feeder No / Name : 205 / 11 KV DAHIGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173		.6173		.583
2	.6001		.5658		.6173
3	.6001		.5658		.583
4	.6001		.5658		.3887
5	.6001		.5658		.583
6	.6173		.583		.583
7		1.0288		.7202	
8		1.0631			
9		1.2346		1.1831	
10		1.3032		1.3032	
11		1.286		1.3032	
12		1.2689		1.0631	
13		.9259		1.0288	
14		.9602		.9259	
23		.7202		.583	
24	.6516		.6859		.583
Max	.6516	1.3032	.6859	1.3032	.6173
Min	.6001	.7202	.5658	.583	.3887
Avg	.6124	1.0879	.5928	1.0138	.5601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074081 / 33/11 KV MANGRUL (Nanghare)

Feeder No / Name : 206 / 11 KV NAIGON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2401	.2229	.2229	.2229
2	.2572		.2229	.2401	.2229
3	.3258		.2572	.2743	.2401
4	.3944		.3772	.3429	.2743
5	.4801		.4458	.4801	.4458
6	.4973		.4973	.5144	
9				.5144	
11	.2401	.2915	.2229	.2058	.2401
12	.1372	.2058	.1715	.1372	.0686
13	.1029	.1886	.1543	.1372	.0514
14	.1029	.1372	.1372	1.9204	.12
15	2.0576	2.0919	1.749	1.9204	2.1262
16	2.1605	2.2462	1.9719		2.0062
17	2.1605	2.1776	1.9547		2.1262
18	2.0576	1.989	1.989	1.7147	1.9376
19	1.9204	1.8519	1.9204	1.749	1.9719
20	1.8519	1.7147	1.7833	1.7833	1.749
21	1.8176	1.6461	1.7147	1.5775	1.6632
22	1.7833		1.5775	1.5775	1.6461
23	.2743	.2401	.2229	.2229	
24	.2572	.2401	.2229	.2229	.2229
Max	2.1605	2.2462	1.989	1.9204	2.1262
Min	.1029	.1372	.1372	.1372	.0514
Avg	.9568	1.0901	.8908	.8294	.9631

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074082 / 33/11 KV MIDC CHIKHLI

Feeder No / Name : 201 / 11 KV MIDC FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5544	.499	.4066	.7762	.5914
2	.5729	.4435	.4066	.7577	.5544
3	.5729	.4435	.4251	.7762	.5544
4	.5729	.4435	.4251	.7577	.5729
5	.5975	.499	.4251	.7762	.6099
6	.7762	.499	.4435	.8131	.7762
7	.9055	.5544	.4435	.7207	.9425
8	.7207	.6653	.4435	.7207	.7762
9	.6838	.499	.4251	.2402	.7762
10	1.0349		.6468	.3696	.6653
11	1.2752	.6653	1.1458	.9425	1.0903
12	1.0534	.7023	1.0164	.7207	1.1088
13	1.3306	.6283	1.0164	.6283	1.2382
14	1.1643	.6468	.961	.6099	.8871
15	.9134	.6468	.8131	.6653	1.1273
16	1.1088	.5544	.8316	.5544	.9979
17	1.1643	.5544	.7392	.5544	1.2012
18	1.1088	.4805	1.0164	.924	1.1088
19	.9425	.3696	.8501	.9425	.8871
20	.924	.3326	.7762	.7762	.8316
21	.8779	.4805	.6838	.691	.7023
22	.6653	.4435	.7762		
23	.6468	.4066	.5914	.6653	
24	.5359	.5544	.4066	.7762	.6099
Max	1.3306	.7023	1.1458	.9425	1.2382
Min	.5359	.3326	.4066	.2402	.5544
Avg	.8626	.5223	.6715	.7026	.8459

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074082 / 33/11 KV MIDC CHIKHLI

Feeder No / Name : 202 / 11 KV SAILANINAGAR TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5487	.5853	.5544	.6401
2	.5304	.4938	.6036	.5487	.567
3	.5304	.4938	.6036	.5487	.5487
4	.5487	.4938	.6036	.5487	.5304
5	.6401	.5487	.6219	.6401	.5487
6	.7682	.6584	.6401	.7682	.9328
7	.9877	.9328	.9145	1.0974	1.0425
8	1.0608	1.0974	1.0242	1.0974	1.1523
9	1.0242	1.0425	1.0974	1.0608	1.0425
10	.9694	1.0425	1.0791	.9145	.9877
11	.9328	1.0791	.9145	.9328	.9511
12	.9328	.9328	.823	.8779	.9145
13	.9328	.8779	.823	.9328	.8596
14	.9145	.8596	.823	.8779	.8596
15	.823	.823	.7499	.823	.8413
16	.9877	.8962	.7865	.9328	.8596
17	.9877	.9877	.8596	1.0425	.9877
18	1.3169	1.1523	1.0242	1.0242	1.2071
19	1.262	1.1888	.9877	1.0974	1.134
20	1.0425	1.0608	.9328	.9877	1.0059
21	.9877	.9328	.8779	.9328	.9145
22	.8779	.8048	.7499	.7865	
23	.8596	.695	.6584	.7133	
24	.567	.567	.5853	.567	.6584
Max	1.3169	1.1888	1.0974	1.0974	1.2071
Min	.5304	.4938	.5853	.5487	.5304
Avg	.8764	.8421	.8070	.8461	.8721

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074082 / 33/11 KV MIDC CHIKHLI

Feeder No / Name : 203 / 11 KV KHANDALA AG

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.4372	.4481	.4161	.421
2	.4801	.3887	.4641	.4001	.4062
3	.4801	.3887	.4641	.4321	.3887
4	.4801	.3401	.4801	.4321	.3887
5	.5121	.3401	.5441	.4481	.4372
6	.5761	.3887	.6081	.4961	.7287
7	.6562	.583	.6401	.8162	.7773
8	.7522	.6802	.9122	.8642	.8745
9	.8162	.7287	.9602	.9602	.8259
10	.6562	.9717	.9762	.9602	.9717
11	.8259	.9602	1.0883	.9717	1.0883
12	.9717	1.0242	1.2163	1.0688	.9602
13	1.166	1.2963	1.2323	1.004	1.1203
14	1.2308	1.3123	1.3123	1.0688	1.2483
15	1.166	1.3283	1.2803	1.0688	1.2003
16	1.1174	1.2323	1.2803	1.0688	1.1843
17	1.0688	1.1523	1.1523	.9231	1.1523
18	.9231	.9282	.9602	.8097	.8802
19	.7773	.8162	.8162	.8259	.8002
20	.5992	.7362	.6722	.7287	.6882
21	.5344	.5761	.5121	.6802	.5601
22	.4858	.5121	.4321	.5992	
23	.4696	.4801	.4481	.583	
24	.4481	.4696	.4481	.4161	.4372
Max	1.2308	1.3283	1.3123	1.0688	1.2483
Min	.4481	.3401	.4321	.4001	.3887
Avg	.7364	.7530	.8062	.7518	.7973

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074083 / 33/11 KV SAWANA (WALTI)

Feeder No / Name : 201 / 11 KV SAWANA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.6783	.945
2				.6687	.945
3				.7029	.9145
4				.6897	.8993
5				.7074	.9414
6				.7289	.9913
7				.7718	.9938
10	1.0145	1.2559	1.3474		
11	1.4636		1.5185		
12	1.5167	.1265	1.545		
13	1.5364	.1583	1.4715		
14	1.4706	1.4742	1.5466		
15	1.4198	1.6188	1.444		
16	1.3203	1.5089	1.3684		
17	1.2059	.0903	1.192		
22			.6816	1.0454	1.1221
23			.6932	1.0963	1.0936
24				.6783	.9145
Max	1.5364	1.6188	1.5466	1.0963	1.1221
Min	1.0145	.0903	.6816	.6687	.8993
Avg	1.3685	.8904	1.2808	.7768	.9761

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074083 / 33/11 KV SAWANA (WALTI)

Feeder No / Name : 202 / 11 KV WALTI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2041	1.3992	1.2315		
2	1.1978	1.4026	1.2041		
3	1.2269	1.4217	1.189		
4	1.25	1.439	1.2071		
5	1.2546	1.4564	1.2492		
6	1.3263	1.4969	1.2346		
7	1.4199	1.25	1.3108		
10				1.4842	1.5504
11				2.2967	2.1376
12				2.5126	2.331
13				2.434	2.4166
14				2.4499	2.2749
15				2.4558	
16				2.2874	1.9997
17				2.0161	1.9292
22		1.1531			
23		1.2209			
24	1.1918	1.3717	1.2436		
Max	1.4199	1.4969	1.3108	2.5126	2.4166
Min	1.1918	1.1531	1.189	1.4842	1.5504
Avg	1.2589	1.3612	1.2337	2.2421	2.0913

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074083 / 33/11 KV SAWANA (WALTI)

Feeder No / Name : 203 / 11 KV SAWANA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2659	.2282	.2277	.2472	.2282
2	.2474	.2282	.2469	.2279	.2282
3	.2472	.2343	.2659	.2469	.2472
4	.2852	.3423	.2852	.2852	.3042
5	.3993	.4183	.3803	.3788	.4187
6		.6655	.5888	.5093	.6655
7	.8366	.8746	.8176	.756	.8729
8	.7567	.7014	.7757	.7371	.816
9	.7356	.6237	.606	.6608	.7189
10	.4711	.4154	.4914	.4904	.5098
11	.3388	.303	.3409	.3197	.3024
12	.2829	.2083	.2266	.2075	.2231
13	.3018	.2087	.2402	.188	.2241
14	.2261	.1867	.2445	.1879	.2066
15	.2824	.1863	.1651	.1687	.2073
16	.2641	.2445	.2641	.206	.2447
17	.3361	.3772	.3727	.3206	.3395
18	.5601	.6387	.5835	.5818	.6426
19	.567		.6205	.6958	.6452
20	.4545	.4725	.4545		.5687
21	.3419	.4166	.3791	.3977	.3795
22	.3036	.303		.3042	
23	.2662	.2643		.2474	
24	.2659	.2282	.2467	.2284	.2284
Max	.8366	.8746	.8176	.756	.8729
Min	.2261	.1863	.1651	.1687	.2066
Avg	.3929	.3813	.4011	.3736	.4192

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074084 / 33/11 KV CHANDHAI (BHOKER)

Feeder No / Name : 201 / 11 KV GODHARI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	10-DEC-17
HR	Load (MW)
24	.0187
Max	.0187
Min	.0187
Avg	.0187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074084 / 33/11 KV CHANDHAI (BHOKER)

Feeder No / Name : 202 / 11 KV CHANGHI GFFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054		.2241	.2241	.1867
2	.2054		.2427	.2241	.2054
3	.2241		.2614	.2614	.2241
4	.2987		.3174	.3174	.4108
5	.5228		.4294	.4066	.5041
6	.5788		.5788	.5788	.5601
7	.6908		.7095	.6908	.6908
8	.5975		.6161	.6908	.6161
9	.4668		.4854	.5281	.5041
10		.2801	.2829	.3361	.2772
11		.168	.2054	.2218	.1829
12		.168	.168	.1829	.1646
13		.168	.1494	.1463	.1463
14		.1886	.1307	.1829	.1448
15		.168	.168	.1629	.1629
16		.2241	.2241	.181	.2195
17		.3174	.2987	.2743	.3142
18		.4854	.4715	.4435	.5228
19		.4668	.5228	.4668	.4904
20		.3547	.3921	.3361	.3772
21		.2987	.2987	.2801	
22		.2452	.2614	.2241	
23		.2452	.2452	.1867	
24	.2054		.2241	.2263	.1867
Max	.6908	.4854	.7095	.6908	.6908
Min	.2054	.168	.1307	.1463	.1448
Avg	.3996	.2699	.3295	.3239	.3377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

CHIKHLI[286]

BU 2861

Substation No/ Name :- 074084 / 33/11 KV CHANDHAI (BHOKER)

Feeder No / Name : 203 / 11 KV BHOKER AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5181	1.4575	1.8484	1.0642	1.1203
2	1.5364	1.4723	1.8671	1.1016	1.0437
3	1.5684	1.5242	1.8671	1.1203	1.1336
4	1.6324	1.7394	1.9605	1.1203	1.2163
5	1.7814	1.8185	2.0911	1.1694	1.2654
6	1.9433	1.906	2.2032	1.2323	1.3283
7	2.0165		2.1472	1.2696	1.3923
10	1.0936	.9922		1.9978	1.6004
11	1.4232	1.643		2.372	2.3045
12	1.9231	1.8298		2.5286	2.5587
13	1.7394	1.8858	.6348	2.4006	2.4646
14	1.8122	1.363		2.359	2.4006
15	1.5623	1.7737		2.3278	2.2672
16	1.3603	1.363	1.7551	2.2138	2.17
17	1.2037	1.531	2.3388	2.1862	2.1052
22		1.5684	1.0456	1.1203	
23		1.6804	1.0642	1.1984	
24	1.4548	1.4232	1.7551	.9709	1.1702
Max	2.0165	1.906	2.3388	2.5286	2.5587
Min	1.0936	.9922	.6348	.9709	1.0437
Avg	1.5981	1.5866	1.7368	1.6530	1.7213

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074002 / 33 KV ANDERA

Feeder No / Name : 201 / 11 KV ANDERA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.7716	.8573	.8573	.6001
2	.7716	.7716	.8573	.8573	.6001
3	.8573	.7716	.8573	.8573	.6001
4	.8573	.7716	.8573	.8573	.6859
5	1.0288	1.0288	.9431	1.0288	.7716
6		1.2003	1.0288	1.2003	.9431
7		1.2003	1.0288	1.2003	.9431
8		.8573	.8573	.8573	.8573
9		.7716		.8573	.6859
10		.7716		.8573	.8573
11	.8573	.7716	.8573	1.0288	1.2003
12	.8573	.8573	.9431	1.1145	1.2003
13	.9431	1.0288	1.0288	1.286	1.2003
14	.9431	1.0288	1.0288	1.3717	1.286
15	.9431	.9431	1.0288	1.2003	1.2003
16	.9431	.8573	1.0288	1.2003	1.0288
17	1.0288	.8573	1.0631	1.0288	1.286
18	.9431		1.0288	.8573	1.0288
19	.8573	1.0288	.8573	.8573	1.0288
20	.8573	.8573	.6859	.6859	.8573
21	.6859	.6859	.6859	.6859	.6859
22	.6001	.6001	.6001	.6001	.5144
23	.6001	.5144	.6001	.6001	.5144
24		.7716	.8573	.8573	.6001
Max	1.0288	1.2003	1.0631	1.3717	1.286
Min	.6001	.5144	.6001	.6001	.5144
Avg	.8526	.8573	.8901	.9502	.8823

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074008 / 33 KV DEULGAON RAJA

Feeder No / Name : 201 / 11 KV DRAJA TOWN-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0117	.9339	.8688	.7773	.9326
2	1.0117	.9831	.884	.7621	1.0004
3	.1029	.0686	.884	.5525	1.0059
4	1.0174	5.5708	.884	.7621	1.17
5	1.1831	1.0486	.8993	.7621	1.17
6	1.1305	1.1544	.9297	.9145	1.475
7	1.2289		1.1431	1.2193	1.4586
8	1.4251	1.1405	1.2498		1.5223
9	1.2498	1.0911	1.3108		1.3565
10	1.1431	1.1305	1.2452		1.2803
11	1.0364	1.1469	1.1469		1.1736
12	1.0669	1.0486	1.1174		1.1584
13	1.0059	1.0814	1.17		1.1431
14	.9755	1.0814	1.1022		.9907
15	.9145	1.1142	1.1022		.9755
16	.9602	1.0364	1.2041		.9755
17		1.1584			1.0911
18		1.2193	1.3717		1.4706
19		1.1736	1.2803		1.3916
20		1.0517	1.1126		
21		.9755	.8993	1.17	
22		.8688	.8383	1.1022	
24	.9465	.9339	.8688	.7926	.9326
Max	1.4251	5.5708	1.3717	1.2193	1.5223
Min	.1029	.0686	.8383	.5525	.9326
Avg	1.0241	1.2278	1.0688	.8815	1.1837

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074008 / 33 KV DEULGAON RAJA

Feeder No / Name : 203 / 11 KV DRJA TOWN-2

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5041	.4481	.3963	.3963	
2	.5041	.4481	.3963	.3963	.5415
3	.5415	.4481	.3963	.3963	.5415
4	.5975	.5415	.4268	.3963	.5415
5	.7468	.5792	.4572	.3963	.7282
6	.8215		.5335	.6097	.9149
7	.8402	.724	.7926	.7468	.9896
8	1.0317	.7842	.884		.9326
9	.0762	.8962	1.0425		.8535
10	.7316	.8589	1.0608		.823
11	.7164	.8413	.7602		.7468
12	.6859	.8215	.7655		.823
13	.7011	.8215	.7655		.8688
14	.7011	.7842	.8215		.8383
15	.7164	.6952	.8215		.823
16	.7164	.6706	.7468		.823
17		.6859	.8078		.9335
18		.6859	.7316		.8413
19		.6097	.6401		.703
20		.5487	.5639	.2477	
21		.5182	.4725	.6036	
22		.4115	.4115	.2477	
24	.5041	.4481	.3963	.4115	.5041
Max	1.0317	.8962	1.0608	.7468	.9896
Min	.0762	.4115	.3963	.2477	.5041
Avg	.6551	.6487	.6561	.4408	.7774

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074008 / 33 KV DEULGAON RAJA

Feeder No / Name : 204 / 11 KV JUMDA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.1905	.1067	.2134	.2286
2	.2286	.1905	.1067	.2347	.2096
3	.1905	.1905	.1067	.2134	.2096
4	.1905	.2096	.0914	.2134	.1905
5	.2096		.0914	.2134	.2286
6	.2096	.2096	.0914	.2286	.2286
7	.2096	.1715	.1372	.1981	.2286
8	.2096		.1677		.2096
9	.1372	.1143	.1715		.1524
10	.1524	.1143	.1715		.2286
11	.2286	.1143	.1715		.2134
12	.2286	.0953			.2286
13	.2286	.0953			.2591
14	.2286	.1143	.3048		.2896
15	.2286	.1143	.3048		.2591
16	.2286	.1067	.2439		.2591
17		.1067	.2134		.3429
18		.061	.2591		.3429
19		.1067	.2439		.3239
20		.1067	.2134		
21		.1067	.2439		
22		.1067	.2134		
24	.2286		.1067	.2134	.2286
Max	.2286	.2096	.3048	.2347	.3429
Min	.1372	.061	.0914	.1981	.1524
Avg	.2098	.1313	.1791	.2161	.2431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074078 / 33 KV Shelgaon Atol

Feeder No / Name : 201 / 11KV SHELGAON ATOL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1341	.1372	.1029	.1341	.1372
2	.1341	.1372	.1029	.1341	.1715
3	.1341	.1715	.1029	.1341	.1715
4	.1677	.2401	.1029	.1341	.2401
5	.2515	.3086	.1715	.2012	.3086
6	.3018	.3944	.2229	.285	.3772
7	.3018	.3086	.2743	.3521	.4287
8	.3185	.2229	.2572	.3185	.3772
9	.2515	.1886	.2401	.285	.3086
10	.2012	.1372	.2401	.2012	.1715
11	.12	.0857	.2012	.1372	.1029
12		.0857	.1509	.0857	
13			.1006	.0686	.0857
14		.12	.0838	.0857	.0857
15	.1715		.2012	.2572	.1886
16	.2572	.2572	.2515	.2743	.2058
17	.3258	.2743	.3018	.3429	.2572
18	.3086	.3086	.3353	.3944	.3429
19	.3429	.3258	.3353	.3601	.3429
20	.2915	.2572	.2515	.2915	.3086
21	.2058	.2058	.1677	.2058	.1886
22	.1372	.1543	.1341	.1715	.1543
23	.1543	.1372	.1341	.1372	
24	.1341	.1372	.12	.1341	.1372
Max	.3429	.3944	.3353	.3944	.4287
Min	.12	.0857	.0838	.0686	.0857
Avg	.2212	.2089	.1911	.2136	.2315

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074078 / 33 KV Shelgaon Atol

Feeder No / Name : 202 / 11KV AMONA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1341	.1543	.12	.1174	.823
2	.1341	.1543	.12	.1174	.823
3	.1341	.1715	.12	.1174	.823
4	.1677	.2572	.12	.2012	.823
5	.2515	.3258	.2058	.2683	.8402
6	.3353	.3944	.2743	.3185	.8573
7	1.1401	1.1488	1.0974	.3688	.3258
8	1.1736	1.166	1.0631	.3353	.3772
9	1.0898	1.0974	1.0802	.3353	.3772
10	.9724	1.0631	1.1145	.2683	.2915
11	.9259	.9259	1.0059	.2058	.2572
12	.8916	.8916	.9221	.1886	.1715
13	.9774	.8573	.8383	.2401	.1543
14	.823	.8402	.7545	.1886	.1543
15	.1543	.1372	.1677	.2229	.1715
16	.2058	.1886	.1677	.2229	.1715
17	.2743	.1886	.1509	.2401	.2058
18	.3086	.2058		.3772	.3086
19	.2743	.2743		.3086	.3258
20	.2401	.2401	.2012	.2572	.3429
21	.2058	.2058	.1509	.2229	.2058
22	.1715	.1372	.1174	.2058	.1715
23	.1543	.1372	.1174	.8059	
24	.1341	.1543	.1372	.1174	.823
Max	1.1736	1.166	1.1145	.8059	.8573
Min	.1341	.1372	.1174	.1174	.1543
Avg	.4697	.4715	.4567	.2605	.4272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074078 / 33 KV Shelgaon Atol

Feeder No / Name : 203 / 11 KV ISRUL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677	.1715		.1677	.1715
2	.1677	.1715	.1543	.1341	.1715
3	.1677	.1715	.1372	.1341	.1715
4	.1677	.2058	.1372	.1341	.2058
5	.2515	.2572	.2058	.1341	.2743
6	.3018	.3258	.2915	.1677	.3086
7	.2683	.3086	.2743	.2012	.3086
8	.2347	.2743	.2401	.1677	.2915
9	.1677	.2743	.1715	.1677	.2229
10	.1174	.2229	.1543	.1174	.2058
11	.1372	.1372	.1341	.1029	.12
12	.1029	.12	.1341		.1029
13	.12		.1341	.0857	.1029
14	.1372	.1372	.1509	.1029	.12
15	.7888	.7202	.7545	.6859	.703
16	.9259	.7716	.7545	.823	.7545
17	.8573	.6001	.7545	.823	.7373
18	.6687	.5487	.6539	.7202	.7202
19	.5658	.5487	.5533	.583	.6516
20	.6516	.5144	.503	.5144	.6001
21	.4801	.4801	.4694	.4287	.4801
22	.4287	.3601	.4359	.4115	.3772
23	.1886	.1715	.2012	.1715	
24	.1677	.1715	.1715	.1677	.1715
Max	.9259	.7716	.7545	.823	.7545
Min	.1029	.12	.1341	.0857	.1029
Avg	.3430	.3332	.3292	.3107	.3467

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074078 / 33 KV Shelgaon Atol

Feeder No / Name : 204 / 11 KV ANCHARWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2574	1.286	1.3375	1.1736	.2572
2	1.2574	1.2003	1.2689	1.1736	.2572
3	1.2574	1.2003	1.2346	1.1736	.2572
4	1.2574	1.1145	1.2346	1.1736	.2572
5	1.2574	1.0288	1.286	1.1736	.3086
6	1.291	.9602	1.3375	1.2407	.3429
7	.4024	.3429	.3772	1.2742	1.5432
8		.3086	.3086	1.3413	1.8519
9		.2572		1.4251	1.8176
10		.2401	.2058	1.5089	1.749
11		.2058	.2012	1.3717	1.8176
12	.1543	.1715	.1844	1.4746	1.749
13	.1543		.1677	1.6289	1.6975
14	.1715	.1715		1.4232	1.6118
15	.2058	.2058	.2515	.2058	.2058
16	.2058	.2401	.285	.2401	.2058
17	.2743	.2572	.3185	.2915	.2743
18	.4287	.3086	.2347	.4115	.3601
19	.3944	.3772	.2683	.3944	.3772
20	.3601	.3429	.3185	.3429	.3429
21	.3429	.3086	.285	.3258	.3086
22	.2743	.2743	.2683	.2915	.2743
23	1.3203	1.3717	1.2407	.2572	
24	1.2574	1.3203	1.3717	1.2071	.2572
Max	1.3203	1.3717	1.3717	1.6289	1.8519
Min	.1543	.1715	.1677	.2058	.2058
Avg	.6762	.5867	.6357	.9385	.7880

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074095 / 33 kv Isrul

Feeder No / Name : 201 / Irul

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	1.1488	1.2003	.3429	
2	1.1317	1.1831	1.2003	.3086	
3	1.1145	1.2003	1.2346	.3258	
4	1.1317	1.2346	1.2174	.3258	
5	1.1488	1.2689	1.2003	.3429	
6	1.1831	1.3032	1.1488	.3086	
7	1.1831	1.3203	1.166	.3429	
8	.3601	.3429	.4115	.1886	
9	.3086	.3601	.3429	.2229	
10	.2915	.2401	.2229	1.1317	
11	.2229	.2401	.2572	1.3546	.7202
12	.2572	.2401	.3772	1.6632	.9431
13			.3258	1.6975	.9088
14	.2229	.2401	.3429	1.6461	1.6632
15	.2229	.2743	.3429	1.406	1.7661
16	.2743	.2915	.3429	1.3889	1.8004
17	.2572	.3258	.4115	1.4746	1.166
18	.3944	.4458	.4287	.3601	.2572
19	.4115	.3601	.4801	.3601	.3429
20	.3258	.3601	.4287	.3086	.3429
21	.3086	.3086	.3944	.2915	.3086
22	.2572	.2401	.3601	.2915	.2401
23	.2915	.2572	.3429		.2915
24	1.1145	1.1145	1.2174	.3258	
Max	1.1831	1.3203	1.2346	1.6975	1.8004
Min	.2229	.2401	.2229	.1886	.2401
Avg	.5875	.6218	.6416	.7134	.827

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287] BU 2879

Substation No/ Name :- 074095 / 33 kv Isrul

Feeder No / Name : 202 / Dodra SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3944	.3772	.3086	1.2689	1.406
2	.4287	.3601	.2915	1.2517	1.4232
3	.4458	.3944	.2915	1.286	1.3889
4	.4287	.4287	.2743	1.2517	1.3717
5	.463	.463	.3944	1.3375	1.4403
6	.5144	.5144	.4801	1.3889	1.4575
7	.5487	.4287	.5316	1.4403	1.4746
8	.4854	.4458	.4801	.5144	.4801
9	.4115		.4287	.4458	.463
10	1.2003	1.4403	1.286	.3772	.3429
11	1.6118	1.7147	1.7318		.3772
12	1.8004	1.9033	1.9547		.3944
13	2.0062	2.0748	1.9547	.3944	.5144
14	2.0405	2.0062	1.8519	.4801	.463
15	1.9547	1.989	1.9376	.3601	.1448
16	1.8519	1.869	1.9033	.3944	.4801
17	1.7833	2.0062	1.7147	.4458	.5658
18	.5144	.4458	.4458	.5316	.4801
19	.5144	.4287	.5487	.5144	.4115
20	.4287	.3772	.4287	.3601	.4115
21	.3944	.3601	.3772	.3258	.3086
22	.2401	.3258	.3601	.2572	.2401
23	.3772	.3086	.3601	.2743	.2229
24	.3772	.3772	.2915	1.2003	1.4403
Max	2.0405	2.0748	1.9547	1.4403	1.4746
Min	.2401	.3086	.2743	.2572	.1448
Avg	.8840	.9147	.8595	.7319	.7376

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074101 / 33 KV Narayankhed

Feeder No / Name : 201 / Naryankhed Gawthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012	.2012	.1829	.1829	.2012
2	.2195	.2218	.1829	.1829	.2012
3	.2218	.2195	.2012	.2012	.2033
4	.3696	.3658	.3658	.3326	.4066
5	.5304	.5359	.4805	.5121	.5359
6	.7392	.7207	.7577	.7133	.6878
7	.924	.9709	.8686	.8596	.8688
8	.8048	.8215	.7947	.7964	.8507
9	.6767	.6908	.7392	.6878	
10	.4163	.4251	.4805	.5194	.5121
11	.2172	.2402	.2926	.2353	.2926
12	.1646	.1848	.2378	.1646	.1829
13	.1463	.1663	.1829	.1646	.1867
14	.128	.1867	.1448	.1829	.1494
15	.168	.1867	.1629	.1829	.1494
16	.1867	.2427	.197		.2427
17	.3696	.3696	.3582	.4251	.462
18	.6468	.7577	.6516	.6653	.7023
19	.6468	.7023	.724	.6468	.7023
20	.3511	.4066	.4572	.3696	.4435
21	.2772	.3109	.3292	.2402	.2561
22	.2218	.2378	.2195	.2218	.2378
23	.2218	.2195	.2218	.2195	
24	.2033	.2033	.2012	.2033	.2012
Max	.924	.9709	.8686	.8596	.8688
Min	.128	.1663	.1448	.1646	.1494
Avg	.3772	.3995	.3931	.3874	.3944

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074101 / 33 KV Narayankhed

Feeder No / Name : 202 / Nimgaon Guru Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366	.0366	.0366	.0366	.0366
2	.0366	.0366	.0366	.0366	.0366
3	.037	.0366	.0366	.037	.037
4	.037	.0366	.0366	.037	.037
5	.0549	.037	.037		.0554
6	.0739	.0554	.0554	.0732	.0724
7	.5914	.6161	.5175		
8	.695	.8589	.7762		
9	.8048	.9522	.8131		
10	.8326	.9055	.8686		
11	.8326	1.0164	.8413		
12	.823	.9795	.9145		
13	.823	.9979	.7316		
14	.6767	.8029	.6878		
15				1.134	1.1949
16				1.1706	1.0082
17				1.0349	1.0534
18				.8501	.961
19	.0739	.0739	.0724	.6838	.7947
20	.0554	.037	.0549	.7023	.7023
21	.037	.0366	.0366	.6653	.695
22	.037	.0366	.0366	.6468	.6584
23	.037	.0366	.037	.0366	
24	.037	.037	.0366	.037	.0366
Max	.8326	1.0164	.9145	1.1706	1.1949
Min	.0366	.0366	.0366	.0366	.0366
Avg	.3316	.3813	.3332	.4788	.4920

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

D'RAJA SUB-DN[287]

BU 2879

Substation No/ Name :- 074101 / 33 KV Narayankhed

Feeder No / Name : 203 / 11 kv Digras Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7				.6219	.8326
8				.7783	.9593
9				1.0136	
10				1.0745	1.2254
11				1.1584	1.2437
12				1.0608	1.262
13				1.2437	1.2136
14				1.134	1.1949
15	1.531	1.475	1.3032		
16	1.531	1.475	1.2536		
17	1.1827	1.0719	1.1283		
18	.8131	.9795	.8869		
19	.7947	.8686	.7964		
20	.7947	.8501	.7865		
21	.7577	.8048	.7682		
22	.7392	.7865	.7499		
Max	1.531	1.475	1.3032	1.2437	1.262
Min	.7392	.7865	.7499	.6219	.8326
Avg	1.0180	1.0389	.9591	1.0107	1.1331

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074010 / 33KV S/S DHAD

Feeder No / Name : 201 / 11KV DHAD GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4634	.4444	.4449	.4078	.4264
2	.4634	.4444	.4449	.4264	.4264
3	.4634	.537	.482	.4634	.4449
4	.6488	.6667	.5932	.5747	.5191
5	.9269	.963	.8157	.8342	.7415
6	1.2049	1.2037	1.0937	1.1308	1.0381
7	1.5015	1.3519	1.3347	1.3162	1.4459
8	1.4645	1.1481	1.2606	1.1493	1.3532
9	1.3903	1.0556	1.001	.9083	.9269
10	1.1493	.8889	.8898	.8157	.8342
11	.963	.7786	.7963	.5191	.7044
12	.8148	.7044	.7044	.6303	.6117
13	.6667	.6303	.5005	.5932	.5561
14	.5926	.6117	.5005	.5932	.5191
15	.5741	.5932	.5005	.4634	.5376
16	.5556	.6303	.6488	.5932	.5561
17	.8704	.7415	.76	.7786	.7415
18	1.2037	1.1493	1.0937	1.1123	1.1123
19	1.0926	1.0196	1.001	1.001	1.0566
20	.7963	.7415	.7971	.8157	.7415
21	.6296	.6488	.6117	.6674	.6117
22	.537	.5747	.5376	.5561	.482
23	.4815	.482	.4264	.482	.4264
24	.482	.4259	.4449	.4078	.4449
Max	1.5015	1.3519	1.3347	1.3162	1.4459
Min	.4634	.4259	.4264	.4078	.4264
Avg	.8307	.7681	.7368	.7183	.7191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074010 / 33KV S/S DHAD

Feeder No / Name : 202 / 11KV DHAD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.3596	.3615	.3051	
2	.2881	.4011	.3472	.3051	
3	.3018	.415	.3472	.319	
4	.3155	.4288	.3611	.3467	
5	.3429	.4426	.375	.4161	
6	.3978	.4426	.3889	.43	.0278
7	.4527	.4564	.4028	.2913	.0417
8	.0416	.0277	.0278	.0277	.0417
9	.0277	.0277	.0278	.0278	.0279
10	.0277	.0277	.0278	.2222	.3506
11	.0277			.4167	.5328
12				.5563	.5749
13				.5563	.5609
14		.0278		.5563	.5328
15				.5146	.5328
16				.5007	.5188
17	.0277	.0277		.4451	.4499
18	.0277	.0277	.0277	.0417	.0423
19	.0277	.0277	.0277	.0278	.0282
20		.0277	.0277	.0278	.0282
21		.0277	.0277	.0278	.0282
22		.0277	.2913	.0278	
23		.0278	.3051	.0278	
24	.2614	.332	.3333	.3051	
Max	.4527	.4564	.4028	.5563	.5749
Min	.0277	.0277	.0277	.0277	.0278
Avg	.1895	.1886	.2181	.2801	.2700

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074010 / 33KV S/S DHAD

Feeder No / Name : 206 / 11KV KARDI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2407	.9043	1.6059	.8048	1.7711
2	1.2742	.9881	1.6393	.8886	1.8379
3	1.3413	1.1555	1.6728	1.073	1.8379
4	1.4251	1.4737	1.84	1.4754	1.9215
5	1.5927	1.6244	2.0933	1.6263	2.091
6	1.8945	1.7919	2.2608	1.7772	2.1913
7	2.0287	1.6747	2.3948	1.8107	2.4088
8	1.055	.8373	.9881	.9892	.9367
9			.8048	.7209	.7026
10		1.5072	1.0898	1.7772	1.1375
11	1.6747	2.1795	1.1233	2.1244	1.8379
12	1.6321	2.146	2.0287	2.275	2.0862
13	1.8924	.3688	1.9616	2.1746	1.8359
14	1.7752	2.4478	1.9113	2.3586	1.7858
15	1.6914	2.4813	2.1293	2.2415	1.5688
16	1.6244	2.4478	2.0119	2.1913	1.4687
17	1.7752	2.3753	1.6598	2.3419	1.5021
18	.8708	.8698	.8048	.7018	.7677
19	.8206	.8029	.788	.6349	.751
20	.5861	.5687	.6036	.5514	.4506
21	.4187	.4684	.4191	.401	.3505
22	.3517	.3847	.8718	1.3367	.701
23	.3014	.3346	.8215	1.6709	.8011
24	1.1736	.8038	1.5389	.7545	1.7377
Max	2.0287	2.4813	2.3948	2.3586	2.4088
Min	.3014	.3346	.4191	.401	.3505
Avg	1.2928	1.3320	1.4610	1.4459	1.4367

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074034 / 33KV S/S RAYPUR

Feeder No / Name : 201 / 11 KV PANGRI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	08-DEC-17
HR	Load (MW)
8	.061
9	.061
10	1.0212
11	1.0974
12	1.6804
13	1.6975
14	1.5775
15	1.5261
16	1.5089
17	1.326
Max	1.6975
Min	.061
Avg	1.1557

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074034 / 33KV S/S RAYPUR

Feeder No / Name : 203 / 11KV SAILANI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	08-DEC-17
HR	Load (MW)
1	1.3375
2	1.3375
3	1.3717
4	1.2955
5	1.4022
6	1.5699
7	1.768
8	.1524
9	.1524
10	.1524
11	.1372
12	.1543
13	.1543
14	.1543
15	.1715
16	.1886
17	.1715
18	.1543
19	.1543
20	.1372
21	.1372
22	.1372
23	.1372
24	1.2689
Max	1.768
Min	.1372
Avg	.5749

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074034 / 33KV S/S RAYPUR

Feeder No / Name : 205 / 11 KV SAILANI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17
HR	Load (MW)
1	.3086
2	.3258
3	.3601
4	.5144
5	.6516
6	.8402
7	1.0802
8	.8745
9	.8402
10	.5658
11	.5658
12	.3944
13	.3772
14	.3601
15	.4115
16	.463
17	.6859
18	.8745
19	.7545
20	.6173
21	.4287
22	.3429
23	.3086
24	.3086
Max	1.0802
Min	.3086
Avg	.5523

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074056 / 33KV S/S DHAMANGAON DEO

Feeder No / Name : 202 / 11 KV DHAMANGAON AG

FEEDER SEPERATION/PURE AG

FEEDER Feeder KV- 11 /
OUTGOING

DATE	09-DEC-17
HR	Load (MW)
12	1.9524
16	1.9498
17	1.7444
18	.5658
19	.583
20	.4287
21	.3772
22	.3429
23	.3086
Max	1.9524
Min	.3086
Avg	.9170

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074056 / 33KV S/S DHAMANGAON DEO

Feeder No / Name : 203 / 11 KV MASRUL AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	09-DEC-17
HR	Load (MW)
16	.0663
17	.0663
18	.0686
19	.0857
20	.0514
21	.0514
22	.0514
23	.0514
Max	.0857
Min	.0514
Avg	.0616

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074056 / 33KV S/S DHAMANGAON DEO

Feeder No / Name : 204 / 11 KV DOMRUL AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	09-DEC-17
HR	Load (MW)
12	1.5364
16	1.4243
17	1.2323
18	.0857
19	.0686
20	.0686
21	.0686
22	.0514
23	.0514
Max	1.5364
Min	.0514
Avg	.5097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074056 / 33KV S/S DHAMANGAON DEO

Feeder No / Name : 205 / 11 KV JANUNA AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	09-DEC-17
HR	Load (MW)
21	.1029
22	.1029
23	.1029
Max	.1029
Min	.1029
Avg	.1029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074071 / 33/11KV S/S chandol

Feeder No / Name : 201 / GFSS CHANDOL

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	10-DEC-17
HR	Load (MW)
21	.0747
Max	.0747
Min	.0747
Avg	.0747

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074071 / 33/11KV S/S chandol

Feeder No / Name : 202 / Chandol AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3189	.333	.3361	.8215	.9054
2	.3366	.3506	.3361	.8215	.9054
3	.3761	.4075	.3361	.8215	.9389
4	.4477	.4607	.3361	.8215	1.094
5	.6447	.6268	.7392	1.1203	1.3916
6	.985	.9568	.924	1.4784	1.5424
7	1.1584	1.0808	1.1088	1.5708	1.7532
8	1.0136	.9568	.924	1.0719	1.0829
9	.7973	.7522	.8871	.7392	.8962
10	1.1336		1.4045	.5914	.6348
11	1.247	1.5524	1.6632	.4435	.4668
12	1.5546	1.6632	1.5524		.3734
13	1.6712	1.6632	1.5524		.3361
14	1.5061	1.6632	1.5524	.4294	.3734
15	1.4575	1.5524	1.5524	.3921	.3361
16	1.5384	1.6632	1.5524		.3547
17	1.4575	1.6632	1.6263	.6908	.6348
18	.8328	.8501	.8402	.9522	.8871
19	.7619	.7392	.8215	.8589	.8501
20	.567	.5544	.5601	.6413	.6161
21	.4784	.4668	.5601	.5228	.5415
22	.3898	.3734	.7468	.8718	1.1904
23	.3544	.3734		.9054	
24	.3189	.3366	.3361	.8215	.8718
Max	1.6712	1.6632	1.6632	1.5708	1.7532
Min	.3189	.333	.3361	.3921	.3361
Avg	.8895	.9148	.9673	.8280	.8251

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074071 / 33/11KV S/S chandol

Feeder No / Name : 203 / Bhadgaon AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2163	1.3603	1.4937	.1307	.0934
2	1.2643	1.3927	1.4937	.1307	.0934
3	1.2963	1.4251	1.4937	.1307	.0934
4	1.3441	1.4575	1.4937	.1307	.0934
5	1.4083	1.4737	1.4784	.1307	.0934
6	1.5061	1.491	1.6632	.1294	.1307
7	1.5546	1.5083	1.848	.1478	.1494
8	.1372	.1372	.1294	.1294	.1307
9	.1372	.104	.1294	.1294	.1307
10	.12		.1109	1.2936	1.291
11	.12	.1294	.0924	2.4025	1.8442
12	.12	.1109	.0924	2.2558	2.146
13	.1372	.1109	.1109	2.3975	2.079
14	.1029	.1109	.1109	2.2211	1.989
15	.1052	.1494	.1109	2.0885	1.8442
16	.1214	.1478	.1294	1.8275	1.643
17	.12	.1663	.1478	1.7695	1.4419
18	.1543	.2218	.1867	.1494	.112
19	.12	.1848	.1867	.1307	.1307
20	.0857	.1663	.1867	.1307	.112
21	.1029	.1867	.168	.1307	.0934
22	.12	.1494	.1307	.0943	.0747
23	.1029	.1494		.0943	
24	1.166	1.3272	1.4003	.1307	.0934
Max	1.5546	1.5083	1.848	2.4025	2.146
Min	.0857	.104	.0924	.0943	.0747
Avg	.5276	.5940	.6256	.7628	.6914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074071 / 33/11KV S/S chandol

Feeder No / Name : 204 / Saoli GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362	.0366	.0373	.0373	.0377
2	.0366	.0366	.0373	.0747	.0377
3	.0549	.0362	.0373	.0747	.0566
4	.0724	.0724	.0373	.0747	.0747
5	.1097	.0905	.1109	.112	.0934
6	.1629	.1448	.1478	.1294	.1494
7	.1629	.1448	.1478	.1294	.1307
8	.0914	.0905	.1109	.0924	.112
9	.0724	.0362	.0554	.0739	.056
10	.0185		.037	.0554	.056
11	.0185	.037	.037	.037	.0189
12	.0362	.037	.037	.0343	.0189
13	.0366	.037	.037	.0377	.0189
14		.037	.037	.0189	.0189
15	.0185	.037	.037	.0189	.0189
16	.0366	.037	.037	.0377	.0377
17	.0549	.037	.037	.0747	.0566
18	.0914	.0924	.0934	.0943	.0754
19	.0914	.0924		.0754	.0754
20	.0543	.0554	.0747	.0566	.0373
21	.0543	.0373	.0747	.0377	.0373
22	.0366	.0373	.056	.0377	.0377
23	.0362	.0373		.0377	
24	.0362	.0362	.0373	.0373	.0377
Max	.1629	.1448	.1478	.1294	.1494
Min	.0185	.0362	.037	.0189	.0189
Avg	.0617	.0581	.0616	.0621	.0563

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074071 / 33/11KV S/S chandol

Feeder No / Name : 205 / 11 KV SAWALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8259	1.0364	.9709	.0934	.0747
2	.8482	1.0814	.9709	.0934	.0747
3	.9878	1.085	.9709	.0934	.0747
4	1.0402	1.085	.9709	.0934	.0747
5	1.1012	1.1142	1.1203	.0934	.0747
6	1.0688	1.166	1.1088	.1294	.0934
7	1.166	1.0526	1.2936	.1294	.1307
8	.1372	.1372	.0924	.1294	.1494
9	.1214	.1052	.1478	.1294	.1307
10	.0686		.0924	1.1104	1.0395
11	.0686	.0924	.0924	1.7372	1.5257
12	.0686	.0924	.0924	1.6613	1.358
13	.0686	.0739	.0739	1.8896	1.576
14	.0686	.0739	.0739	1.7939	1.5927
15	.0693	.0924	.0739	1.7436	1.4251
16	.0686	.0924	.0739	1.5746	1.358
17	.0857	.0924	.0739	1.5257	1.291
18	.12	.0739		.0943	.1307
19	.12	.0739	.0934	.1307	.112
20	.0857	.0739	.112	.112	.1307
21	.0857	.112	.112	.1307	.112
22	.0857	.112	.0934	.1132	.0747
23	.0686	.112		.1132	
24	.7362	1.004	.9709	.0934	.0943
Max	1.166	1.166	1.2936	1.8896	1.5927
Min	.0686	.0739	.0739	.0934	.0747
Avg	.3819	.4363	.4398	.6170	.5521

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

DHAD S/DN.[668]

BU 4668

Substation No/ Name :- 074071 / 33/11KV S/S chandol

Feeder No / Name : 206 / 11 KV DHANGARPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0351	.0526	.0373	.7468	.8718
2	.0351	.0526	.0373	.7468	.8718
3	.0351	.0526		.7468	.8383
4	.0354	.0709	.0373	.7468	.8215
5	.0709	.0886	.0373	.7468	.8215
6	.1063	.1052	.1478	.7468	.8785
7	.124	.1227	.1478	.7392	.9116
8	.0701	.12	.1109	.1109	.112
9	.0876	.104	.1109	.0739	.112
10	.7611		.924	.0739	.0747
11	1.0202	1.2936	1.2197	.0739	.0747
12	1.1961	1.2936	1.2936	.0343	.056
13	1.2146	1.3676	1.2936	.0373	.056
14	1.2289	1.3676	1.2936	.056	.056
15	1.085	1.386	1.2197	.0566	.056
16	1.0722	1.1458	1.1827	.0566	.056
17	.9878	1.1458	1.1088	.0566	.0747
18	.1029	.0924	.0934	.0934	.112
19	.0857	.0739	.0934	.112	.0934
20	.0857	.0554	.0747	.0747	.0747
21	.0514	.056	.0747	.0747	.0747
22	.0514	.056	.7468	.8383	.7209
23	.0514	.056		.8383	
24	.0351	.0526	.0373	.7468	.8383
Max	1.2289	1.386	1.2936	.8383	.9116
Min	.0351	.0526	.0373	.0343	.056
Avg	.4012	.4440	.5147	.3595	.3764

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074035 / 33KV SAKHARKHERDA

Feeder No / Name : 201 / 11KV SAKHARKHERDA AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3963			
2		.7888			
3		.7888			
4		.8573			
5		1.166			
6		1.7436			
7		2.2043			
8		1.0059			.9145
9		1.0212			
10		.8535	.7316		
11	1.3717		1.0669		
12			1.0974		
13	1.3717		1.1584		
14	1.1888		1.0669	1.0059	
15	1.0669				
16	1.0059		.884		
17	.8535		.7926		
18	.7011		.5944		
20	.6554				
21	.4877				
23	.4268			.4572	
24		.4268			
Max	1.3717	2.2043	1.1584	1.0059	.9145
Min	.4268	.3963	.5944	.4572	.9145
Avg	.9130	1.0230	.9240	.7316	.9145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074035 / 33KV SAKHARKHERDA

Feeder No / Name : 202 / 11KV SHENDURJAN AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3				.061	
6				.0914	
7				.1219	.2743
10	.1829	.1524	.2134		
11	.2134		.3048		
12			.3353		
13	.2439		.3658		
14	.2743	.3658	.3048		
15	.2439				
16	.2743		.2134		
17	.2439		.2134		
18		.2743			
22		.3658	.1677		
23			.1219	.1524	
24				.1219	
Max	.2743	.3658	.3658	.1524	.2743
Min	.1829	.1524	.1219	.061	.2743
Avg	.2395	.2896	.2489	.1097	.2743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074035 / 33KV SAKHARKHERDA

Feeder No / Name : 203 / 11KV TANDULWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.3658			
3				.3353
4	.3048			
5	.3658			
6	.4877			.4572
7	.6401			.5944
8	.7011			.6706
9	.7468			.8383
10	.5792			.5792
14		.8383		
18		.5182		
19			.6554	
20			.6097	
21			.5487	
22			.4877	
24	.442			.4268
Max	.7468	.8383	.6554	.8383
Min	.3048	.5182	.4877	.3353
Avg	.5148	.6783	.5754	.5574

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074035 / 33KV SAKHARKHERDA

Feeder No / Name : 205 / 11 KV SOOTGIRANI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	11-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.3048	
2	.3048	.3048	
3		.3353	
4	.4572		
5	.5792	.4572	
6	.6706	.5182	
7	.7011	.5487	
10			.3353
14			.7926
18			.6706
24	.3658	.3048	
Max	.7011	.5487	.7926
Min	.3048	.3048	.3353
Avg	.5131	.3963	.5995

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074035 / 33KV SAKHARKHERDA

Feeder No / Name : 206 / 11KV SHENDURJAN GFSS
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715			
2	.1715	.1715			
3		.1524		.1715	
4	.2401	.2401			
5	.4115	.3429			
6	.6173	.5487		.4801	
7	.7373	.6516		.7545	
8	.6859	.6344		.6859	.6097
9	.6173	.5487		.6516	
10	.3601	.463	.3601	.4115	
11	.2229		.2743		
12			.2058		
13	.1543		.1715		
14	.1372	.1372	.1543		
15	.1715				
16	.2058		.1886		
17	.3086		.3258		
18	.6001	.3658	.583		
19			.4801		
20	.3772		.3601		
21	.2743	.2591	.2915		
22	.2229		.2401		
23	.2058			.1524	
24	.1715	.1715		.1715	
Max	.7373	.6516	.583	.7545	.6097
Min	.1372	.1372	.1543	.1524	.6097
Avg	.3447	.3470	.3029	.4349	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074035 / 33KV SAKHARKHERDA

Feeder No / Name : 207 / 11 KV SAKHARKHERDA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7888			
2	.823	.7888			
3				.9259	
4	1.3032				
5	1.7147				
6	2.1262			2.1262	
7	2.572			2.3834	
8	2.3834	2.0119		2.2291	1.9814
9	2.0062	1.8442		2.0748	
10	1.5261	1.3375	1.3032	1.5261	
11	1.0631		1.1145		
12			.9602		
13	.9259		.823		
14	.9259	.7773	.823		
15	.9431				
16	1.0631		.9602		
17	1.3889		1.1831		
18	1.9204	1.7985	1.8519		
19			1.7661		
20	1.5432		1.4403		
21	1.3032	1.0364	1.1317		
22	.9259		.8745		
23	.823			.7011	
24	.7716	.7888		.7545	
Max	2.572	2.0119	1.8519	2.3834	1.9814
Min	.7716	.7773	.823	.7011	1.9814
Avg	1.4026	1.2414	1.1860	1.5901	1.9814

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074038 / 33KV S. RAJA S/S

Feeder No / Name : 201 / 11KV SINDAKHEDRAJA AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.8926		.733	
10	.9785		.9055	
11	1.0413		.8707	
12	1.1038		.8697	
13	1.1129		.8743	
14	1.0738		.9088	
15	.9459		.9107	
16	.8441		.7602	
17		1.4022		1.3032
18		.9424		.9774
19		.6193		.6516
20		.5155		.543
21		.3521		.4887
22		.3313		.4344
23		.3265		.3801
Max	1.1129	1.4022	.9107	1.3032
Min	.8441	.3265	.733	.3801
Avg	.9991	.6413	.8541	.6826

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074038 / 33KV S. RAJA S/S

Feeder No / Name : 202 / 11KV SAWKHED AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2786			.3134
2		.2786			.3134
3		.2438			.2786
4		.2438			.2786
5		.2786			.2438
6		.3134			.2786
7		.9055			.4876
8		.9055			.8707
9			.8533		
10			1.3931		
11			1.3583		
12			1.2886		
13			1.2538		
14			1.2015		
15			1.0796		
16			.9926		
17	1.6369			1.4627	
18	1.3234			1.1145	
19	1.2189			.9055	
20				.6269	
21	.5921			.4876	
22	.5224			.4179	
23	.4179			.3483	
24		.3483			.3134
Max	1.6369	.9055	1.3931	1.4627	.8707
Min	.4179	.2438	.8533	.3483	.2438
Avg	.9519	.4218	1.1776	.7662	.3753

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074038 / 33KV S. RAJA S/S

Feeder No / Name : 204 / 11KV SINDKHED GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	12-DEC-17
HR	Load (MW)
13	1.1946
14	1.1403
15	1.2894
16	1.2894
17	1.2894
18	1.4506
19	1.3969
20	1.1946
21	.9774
22	.7602
Max	1.4506
Min	.7602
Avg	1.1983

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074057 / 33 /11 KV MALKAPUR PANGRA

Feeder No / Name : 201 / 11KV MALKAPUR PANGRA AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9259	.703	1.0288	.7545	.12
2	.9431	.7202	1.0288	.7716	.12
3	1.0631	.7716	1.1145	.8059	.1543
4	1.2003	1.0288	1.1831	.8402	.1715
5	1.3546	1.286	1.286	.9259	.2058
6	1.4403	1.4232	1.3375	1.0117	.2229
7	1.4918	1.406	1.406	.9945	
10				.703	.8059
11					.9774
12				1.6804	1.2174
13				1.8347	1.5775
14				1.4403	1.3203
15				1.4575	1.5604
16				1.4575	1.5947
17				1.2517	1.3717
20	.12	.1543	.1543	.1715	.12
21	.12	.1715	.1543	.1543	.1029
22	.12	.1372	.1543	.1372	.1029
23	.1029	.1372	.1372	.1372	.0857
24	.9259	.9259	1.0117	.7545	.1307
Max	1.4918	1.4232	1.406	1.8347	1.5947
Min	.1029	.1372	.1372	.1372	.0857
Avg	.8173	.7387	.8330	.9097	.6296

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074057 / 33 /11 KV MALKAPUR PANGRA

Feeder No / Name : 202 / 11 KV MALKAPUR GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.2915	.2743	.2572	.2572
2	.3258	.2915	.2743	.2572	.2572
3	.3601	.3086	.3086	.3086	.2915
4	.5658	.463	.4801	.4801	.5144
5	.7716	.703	.7373	.6687	.823
6	1.0802	.9259	.9774	.9774	1.046
10	.6173	.6173	.6344	.7373	.6859
11	.5144	.463	.4458	.463	.4458
12	.3601	.3258	.3772	.3944	.3429
13	.3258	.3086	.3258	.3601	.3086
14	.3086	.3429	.2743	.3258	.2915
15	.3086	.3086	.2401	.3258	.3258
16	.3258	.3944	.3944	.3772	.3944
17	.5144	.6001	.4973	.5316	.4973
18	.8916	.7716	.8573	.8916	.8745
19	.7373	.7888	.7888	.7716	.7545
20	.5144	.5316	.5316	.5144	.5316
21	.4287	.4458	.4115	.4458	.4115
22	.3601	.3601	.3429	.3429	.3258
23	.3086	.3361	.2743	.2915	.2915
24	.3258	.2915	.2743	.2572	.2572
Max	1.0802	.9259	.9774	.9774	1.046
Min	.3086	.2915	.2401	.2572	.2572
Avg	.4891	.4700	.4630	.4752	.4728

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074057 / 33 /11 KV MALKAPUR PANGRA

Feeder No / Name : 203 / 11 KV WAGHALA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1543	.1715	.1543	.1372
2	.12	.1543	.1715	.1543	.1372
3	.1543	.1715	.2058	.1886	.1715
4	.2915	.2401	.3258	.2743	.3258
5	.3944	.3258	.3772	.4458	.463
6	.4458	.4287	.463	.5487	.5487
10	.2401	.2572	.3086	.3258	.3086
11	.1372	.1715	.1715	.2058	.2058
12	.1372	.1372	.1543	.1715	.1886
13	.0857	.1372	.1372	.1543	.12
14	.1029	.1372	.0857	.1715	.1029
15	.12	.1715	.0857	.1543	.1372
16	.1886	.1886	.12	.1886	.2401
17	.2401	.2743	.2401	.3258	.3429
18	.463	.4801	.4115	.463	.5144
19	.3944	.4115	.4801	.4458	.4287
20	.2743	.3174	.3086	.3086	.2915
21	.1886	.2401	.2401	.2058	.2229
22	.1715	.1886	.2058	.1543	.1886
23	.1543	.1715	.1715	.1372	.1715
24	.12	.1543	.1715	.1543	.4973
Max	.463	.4801	.4801	.5487	.5487
Min	.0857	.1372	.0857	.1372	.1029
Avg	.2164	.2339	.2384	.2539	.2735

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074057 / 33 /11 KV MALKAPUR PANGRA

Feeder No / Name : 204 / 11 KV WAGHALA AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.4973
2				.4973
3				.5316
4				.6001
5				.6687
6				.703
7				.6344
10	.4115	.4287	.4115	
11	.7202	.7888	.6344	
12	.8402	.9431	.8402	
13	.7373	.9602	.8573	
14	.7202	.9088	.7373	
15	.6859	.7716	.6516	
16	.7716	.6859	.6344	
17	.6001	.583	.583	
23		.1715		
24				.4973
Max	.8402	.9602	.8573	.703
Min	.4115	.1715	.4115	.4973
Avg	.6859	.6935	.6687	.5787

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074090 / 33/11 KV Rumhana

Feeder No / Name : 201 / 11KV RUMHANA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1494	.1494	.1494	.1867
2	.1494	.1494	.1494	.1494	.1867
3	.2427	.2054	.2241	.168	.2241
4	.3547	.3361	.3734	.3174	.3174
5	.5601	.6348	.5788	.6348	.6161
9	.5601	.6348	.5041	.7095	.6908
10	.3547	.4294	.3921	.5415	.3921
11	.2241	.2987	.2427	.3361	.2241
12	.1307	.2241	.1867	.1867	.168
13	.1307	.168	.1494	.168	
14	.1494	.168	.1494	.168	
15	.1494	.2054	.168	.1372	
16	.2054	.2614	.1867	.2054	
17	.3921	.3921	.2987	.3734	
18	.5415	.5228	.4854	.5601	
19	.5415	.5415	.4854	.5041	
20	.3547	.3921	.3734	.4668	
21	.2987	.3361	.3361	.3361	
22	.2427	.2987	.2241	.2427	
23	.1867	.1494	.168		
24	.1494	.1494	.1494	.1494	.168
Max	.5601	.6348	.5788	.7095	.6908
Min	.1307	.1494	.1494	.1372	.168
Avg	.2890	.3165	.2845	.3252	.3174

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074090 / 33/11 KV Rumhana

Feeder No / Name : 202 / 11KV CHANGEFAL AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3704	.4475
2				.3704	.5401
3				.4012	.7253
4				.4321	.7407
5				.4321	.7716
6				.463	.8488
7				.4938	.9259
10	.6944	.6327	.6019		
11	1.1111	1.0957	.9722		
12	1.2963	1.2654	1.2346		
13	1.142	1.4506	1.2037		
14	1.3117	1.3117	1.142		
15	1.2037	1.3117	1.0802		
16	1.0648	1.1111	1.0185		
17	.9722	.9722	.8951		
24				.3086	.3241
Max	1.3117	1.4506	1.2346	.4938	.9259
Min	.6944	.6327	.6019	.3086	.3241
Avg	1.0995	1.1439	1.0185	.4090	.6655

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074096 / 33/11 KV SHENDURJAN

Feeder No / Name : 201 / 11KV JAGDARI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3988	.463	.4854	.463	.3988
2	.4508	.5487	.5601	.463	.4161
3	.4801	.7202	.8215	.5658	.4854
4	.6173	.9602	1.0829	.823	.6173
5	.8139	1.0974	1.419	1.0288	.8916
6	1.153	1.4403	1.587	1.4918	1.3395
7	1.358	1.4232	1.7551	1.6461	1.6095
8	1.4922	1.3889	1.7737	1.6118	1.576
9	1.4251	1.286	1.7364	1.4918	1.5424
10	1.0174	1.0974	1.4937	1.166	1.1317
11	.8916	1.0642	1.0288	.5487	
12		1.0269	1.0117	1.0343	
13	.8745	1.0269	.9088	.9665	
14		1.0082	.8573	.8987	
15		.9522	.9088	.8648	
16	1.0288	1.1203	.9774	.9835	
17	1.3203	1.3817	.9602	1.153	
18	1.5432	1.643	1.4746	1.4586	
19	1.3889	1.5123	1.3203	1.3916	
20	1.2346	1.307	1.1317	.9259	
21	.6173	.6722	.6344	.6762	
22	.5144	.5228	.583	.4973	
23	.4287	.4854	.5144	.4287	
24	.3988	.4115	.4668	.463	.4161
Max	1.5432	1.643	1.7737	1.6461	1.6095
Min	.3988	.4115	.4668	.4287	.3988
Avg	.9261	1.0233	1.0622	.9601	.9477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074096 / 33/11 KV SHENDURJAN

Feeder No / Name : 202 / 11KV JAGDARI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3277	.3963			
2	.3277	.4572	.3734		
3	.3441	.4877	.3734		
4	.3605	.4877	.4108		
5	.4424	.5487			
6	.502	.6097	.5601		
7	.5668	.5792	.6348		
10				.3201	.4024
11				.7287	
12				.9762	
13				1.0402	
14				.9602	
15				.8745	
16				.8583	
17				.6478	
24	.3277	.3048	.3734		
Max	.5668	.6097	.6348	1.0402	.4024
Min	.3277	.3048	.3734	.3201	.4024
Avg	.3999	.4839	.4543	.8008	.4024

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

BULDHANA DIVISION[613]

SHINDKHED S/DN.[974] BU 0974

Substation No/ Name :- 074096 / 33/11 KV SHENDURJAN

Feeder No / Name : 203 / 11KV NAGZARI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2743	.4475
2				.2743	.4475
3				.2743	.4475
4				.2743	.4973
5				.2896	.5079
6				.2896	.5407
7				.2896	.5898
10	.4475	.4572	.5601		
11	.5639	.8029	.7545		
12		1.0456	.8573		
13	8.2	1.1389	.7621		
14	.8078	1.0642	.9145		
15	.7316	.9896	.9145		
16	.6554	.9522	.7773		
17	.6097	.6348	.6401		
22			.381	.4024	
23			.381	.3856	
24				.2743	.4144
Max	8.2	1.1389	.9145	.4024	.5898
Min	.4475	.4572	.381	.2743	.4144
Avg	1.7166	.8857	.6942	.3028	.4866

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074017 / 33/11KV HIWARKHED SS

Feeder No / Name : 201 / 11KV GERU MATARGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7164	1.0631			
2	.6878	.9945			
3	.6878	.9602			
4	.724	1.0288			
5	.7602	1.0631			
6		1.0974			
7		1.166			
8		1.166			
9		1.0631			
10			.5258	.9465	.8238
11			1.262	1.0867	1.1568
12			1.4723	1.3112	1.2971
13			1.4723	1.2971	1.262
14			1.5074	1.0867	1.262
15			1.4723	1.1568	1.1218
16			1.1919	.9465	.964
17			1.166	1.1568	.8764
24	.724	1.0288			
Max	.7602	1.166	1.5074	1.3112	1.2971
Min	.6878	.9602	.5258	.9465	.8238
Avg	.7167	1.0631	1.2588	1.1235	1.0955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074017 / 33/11KV HIWARKHED SS

Feeder No / Name : 202 / 11 KV ATALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0168
2					.0168
3					.0168
4					.0168
5			.0168		.0343
6			.0168		.0343
7			.0168		.0343
8			.0168	.0343	.0514
9			.032	.0343	.064
10	.032				
11	.0469	.048			
12	.064	.064			
13	.048	.0457			
14	.048	.0457			
15	.032	.0446			
16	.0457	.0446			
17	.0446	.0503			
24					.0168
Max	.064	.064	.032	.0343	.064
Min	.032	.0446	.0168	.0343	.0168
Avg	.0452	.0490	.0198	.0343	.0302

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074017 / 33/11KV HIWARKHED SS

Feeder No / Name : 203 / 11KV LOKHANDA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.216	.16	.6478	.6097	.5243
2	.2134	.16	.6478	.5487	.5365
3	.2187	.16	.6554	.5487	.5571
4	.216	.1867	.6802	.7316	.6371
5	.2469	.2134	.7042	.7621	.6882
6	.2778	.2401	.7865	.7926	.7865
7	.3125	.2401	.8097	.8535	.8745
8	.3125	.2401	.8421	.8535	1.0486
9	.3125	.2401	.9114	.8535	1.1218
10	1.1568	.7964	.1783	.1738	.1738
11	1.0867	1.0517	.1486	.1303	.1303
12	1.4022	1.3146	.1303	.1128	.1158
13	1.4022	1.2269	.1158	.1158	.1158
14	1.2971	1.3321	.1158	.1158	.1158
15	1.1218	1.3321	.1143	.1158	.1158
16	1.0867	1.262	.1303	.1448	.1448
17	.9465	1.1336	.2134	.1738	.141
18	.2743	.25	.2439	.25	.2538
19	.2743	.2743	.2743	.2812	.282
20	.2743	.3086	.2743	.2812	.2538
21	.2743	.2778	.2743	.2812	.2317
22	.2134	.2812	.2743	.25	.2027
23	.2134	.2187	.2439	.25	.1738
24	.25	.1867	.6154	.5792	.5182
Max	1.4022	1.3321	.9114	.8535	1.1218
Min	.2134	.16	.1143	.1128	.1158
Avg	.5667	.5453	.4180	.4087	.4060

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074017 / 33/11KV HIWARKHED SS

Feeder No / Name : 205 / 11 KV GERU MATARGAON GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2614	.2534	.2614	.2172
2	.2561		.2195	.2241	.2195
3	.2534	.2614	.2195	.2241	.2195
4	.2561	.2614	.2195	.2241	.2195
5	.2926	.2987	.2378	.2987	.2561
6	.3292	.3361	.3109	.3361	.3292
7	.4024	.3734	.4024	.3361	.3658
8	.3658	.4108	.4024	.4108	.4207
9	.3292	.3734	.3734	.3547	.3734
10	.2987	.2987	.3361	.2987	.3361
11	.2614	.2241	.2987	.2614	.2614
12	.1867	.1867	.2614	.2614	.2241
13	.1867	.1867	.2241	.1867	.1867
14	.1867	.1867	.1867	.1867	.1867
15	.1867	.1867	.1867	.1867	.1867
16	.2241	.1867	.1867	.1867	.1867
17	.2427	.2172	.2241	.1867	.1867
18	.2614	.2926	.2987	.2561	.4108
19	.3361	.3658	.3361	.3258	.4108
20	.3361	.3658	.3734	.3658	.3734
21	.3361	.3292	.3734	.3658	.3361
22	.3361	.2926	.3361	.2926	.2987
23	.2987	.2561	.2987	.2561	.2614
24	.2926		.2561	.2614	.2561
Max	.4024	.4108	.4024	.4108	.4207
Min	.1867	.1867	.1867	.1867	.1867
Avg	.2807	.2796	.2840	.2729	.2801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074022 / 33/11 KV KOLORI

Feeder No / Name : 201 / 11 KV KOLORI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1543	.4024	.3772	.3772
2	.1543	.1543	.3658	.3429	.3429
3	.1543	.1372	.3292	.3429	.3429
4	.1715	.1372	.2926	.3086	.3772
5	.1715	.1543	.3292	.3086	.3944
6	.1886	.1886	.3658	.3429	.3944
7	.1886	.1886	.4024	.3772	.463
8	.1715	.1543	.4024	.4458	.4973
9	.1543	.1543	.4024	.5144	.5144
10	.4801	.5144	.1463	.1543	.1029
11	.583	.5853	.1372	.0857	.0914
12	.6516	.6036	.12	.1029	.0732
13	.6859	.6036	.12	.1029	.0732
14	.583	.5853	.1372	.1029	.0914
15	.4801	.5853	.1372	.0857	.1097
16	.5144	.567	.12	.1029	.1097
17	.4801	.5853	.1372	.0857	.128
18	.1715	.2012	.1715	.1715	.128
19	.2058	.2058	.2195	.1886	.2195
20	.2058	.2195	.2058	.1886	.1463
21	.1886	.2012	.1886	.1715	.2195
22	.1715	.2012	.1715	.1543	.2012
23	.1715	.1829	.1715	.1543	
24	.1543	.1543	.4024	.3772	.3944
Max	.6859	.6036	.4024	.5144	.5144
Min	.1372	.1372	.12	.0857	.0732
Avg	.3008	.3091	.2449	.2329	.2518

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074022 / 33/11 KV KOLORI

Feeder No / Name : 202 / 11 KV JAWALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.6516	.4024	.3429	.2743
2	.6001	.583	.3658	.3429	.2743
3	.583	.5487	.3658	.3429	.2915
4	.6516	.5658	.3658	.3601	.3086
5	.7202	.6001	.4024	.3772	.3601
6	.4458	.6344	.439	.4115	.4115
7	.4801	.6344	.439	.3944	.4458
8	.3772	.6173	.4207	.3601	.4115
9	.3429	.6001	.3658	.3429	.3429
10	.2743	.2915	.8573	.7545	.6859
11	.2401	.2743	.8916	.6859	.7316
12	.2058	.2378	.9602	.6859	.695
13	.1677	.2378	.8916	.6859	.695
14	.1886	.2195	.8573	.6344	.6584
15	.1886	.2195	.6859	.6859	.7316
16	.2058	.2378	.7888	.6859	.7865
17	.2229	.3475	.6859	.1543	.9145
18	.3601	.4207	.3601	.3429	.4207
19	.4458	.4755	.4755	.4115	.5121
20	.4458		.4287	.4115	.4755
21	.4287	.439	.3944		.439
22	.9259	.4207	.3601	.3429	.4024
23	.823	.4207	.3601	.3086	
24	.6516	.6859	.4024	.3601	.2915
Max	.9259	.6859	.9602	.7545	.9145
Min	.1677	.2195	.3601	.1543	.2743
Avg	.4414	.4506	.5403	.4533	.5026

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074022 / 33/11 KV KOLORI

Feeder No / Name : 203 / 11 KV CHITODA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.2915	.1097	.0857	.0857
2	.2915	.2743	.0914	.0857	.0686
3	.2743	.2572	.0914	.0857	.0857
4	.3086	.2401	.0914	.1029	.0857
5	.3429	.2572	.1097	.1029	.1029
6	.1029	.2743	.1097	.12	.1029
7	.12	.2743	.1097	.1029	.1029
8	.1029	.2743	.1097	.1029	.1029
9	.0857	.2743	.0914	.0857	.0857
10	.0686	.0686	.3658	.6859	.4572
11	.0686	.0732	.4801	.823	.9511
12	.0686	.0732	.5144	.1372	.9877
13	.0686	.0732	.5144	.12	.9145
14	.0686	.0732	.4801		.6584
15	.0686	.0732	.4458	.7716	.8048
16	.0686	.0732	.4801	.7888	.8048
17	.0857	.0549	.4801	.823	.7865
18	.1029	.128	.1372	.1029	.128
19	.1372	.1646	.1463	.1372	.1463
20		.1646	.1372	.1372	.1463
21	.1372	.1463	.12	.12	.128
22	.3944	.128	.1029	.1029	.128
23	.3601	.128	.1029	.0857	
24	.3429	.3258	.1097	.0857	.0857
Max	.3944	.3258	.5144	.823	.9877
Min	.0686	.0549	.0914	.0857	.0686
Avg	.1730	.1736	.2305	.2520	.3457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074022 / 33/11 KV KOLORI

Feeder No / Name : 204 / 11 KV SHAHEEN FROZON NON SHEDDABLE EXPRESS HV FEEDERS
 EXPRESS Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0366	.0343	.0343
2	.0343	.0343	.0366	.0343	.0343
3	.0343	.0343	.0366	.0343	.0343
4	.0343	.0343	.0366	.0343	.0343
5	.0343	.0343	.0366	.0343	.0343
6	.0343	.0343	.0366	.0343	.0343
7	.0343	.0343	.0366	.0343	.0343
8	.0343	.0343	.0366	.0343	.0343
9	.0343	.0343	.0366	.0343	.0343
10	.0343	.0343	.0366	.0343	.0343
11	.0343	.0366	.0343	.0343	.0366
12	.0343	.0366	.0343	.0343	.0366
13	.0343	.0366	.0343	.0343	.0366
14	.0343	.0366	.0343	.0343	.0366
15	.0343	.0366	.0343	.0343	.0366
16	.0343	.0366	.0343	.0343	.0366
17	.0343	.0366	.0343	.0343	.0366
18	.0343	.0366	.0343	.0343	.0366
19	.0343	.0366	.0366	.0343	.0366
20	.0343	.0366	.0343	.0343	.0366
21	.0343	.0366	.0343	.0343	.0366
22	.0343	.0366	.0343	.0343	.0366
23	.0343	.0366	.0343	.0343	
24	.0343	.0366		.0343	.0343
Max	.0343	.0366	.0366	.0343	.0366
Min	.0343	.0343	.0343	.0343	.0343
Avg	.0343	.0356	.0354	.0343	.0355

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074022 / 33/11 KV KOLORI

Feeder No / Name : 205 / 11 KV TEMBHURNA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2058	.2926	.2572	.2572
2	.2229	.2229	.2561	.2572	.2572
3	.2229	.2401	.2561	.2401	.2401
4	.2572	.2401	.2195	.2401	.2401
5	.2572	.2572	.2195	.2572	.3086
6	.2401	.2572	.2195	.2743	.3429
7	.2915	.2229	.2195	.2572	.3772
8	.2229	.2058	.2195	.2572	.3944
9	.2229	.1886	.2561	.2401	.3944
10	.2401	.2743	.1646	.1715	.1715
11	.2743	.4024	.1543	.1372	
12	.3086	.4207	.1543		
13	.3086	.4024	.1372		.1463
14	.2743	.5853	.1372	.12	.128
15	.2743	.3841	.1372	.12	.128
16	.2915	.3841	.1372	.1372	.128
17	.2743	.439	.1372	.1372	.1463
18	.2229	.2743	.2058	.2229	.2743
19	.2915	.3109	.2926	.2743	.3109
20	.2743	.2743	.2743	.2743	.3109
21	.2572	.2743	.2572	.2572	.2926
22	.2572	.2743	.2229	.2229	.2926
23	.2401	.3292	.2058	.2058	
24	.2401	.2229	.2926	.2743	.2743
Max	.3086	.5853	.2926	.2743	.3944
Min	.2229	.1886	.1372	.12	.128
Avg	.2579	.3039	.2112	.2198	.2579

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074024 / 33/11 KV MATARGAON

Feeder No / Name : 201 / 11 KV MATARGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362	.056	1.6118	1.7177	1.5181
2	.0362	.0373	1.6118	1.6804	1.5364
3	.0373	.056	1.6461	1.643	1.4842
4	.037	.0373	1.5775	1.5497	1.5203
5	.0543	.056	1.5432	1.531	1.5384
6	.0543	.0373	1.5432	1.6057	1.5729
7	.0514	.056	1.5432	1.6057	1.5729
8	.0514	.056	1.5947	1.6804	1.5364
9	.0343	.0373	1.5775	1.6991	1.4632
10	2.2032	1.9376			
11	2.1845	2.2291			
12	2.1658	2.2977	1.6118		
13	2.2405	2.1434	1.6461		
14	2.2032	2.0405	1.5775		
15	2.1285	1.9719	1.5432		
16	2.1098	1.8861	1.5992	.0343	.0343
17	2.1658	1.9033	1.5805	.1029	.1029
18			1.7441	.1372	.3086
19			.1494	.1372	.1372
20			.1086	.1372	.1372
21			.1307	.1698	.1372
22			.1307	.168	.12
23			.112	.1372	.0857
24	.0343	.056	1.6118	1.7177	1.6078
Max	2.2405	2.2977	1.7441	1.7177	1.6078
Min	.0343	.0373	.1086	.0343	.0343
Avg	.9904	.9386	1.2634	.9697	.9119

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074024 / 33/11 KV MATARGAON

Feeder No / Name : 202 / 11 KV JALAMB AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.4108		.0934	.0914
2	.5415	.3921		.112	.0914
3	.5079	.3734		.0934	.0914
4	.5068	.5041		.0747	.1097
5	.4525	.5228		.0934	.0914
6		.5601		.0747	.1086
7		.5601		.0934	.128
8		.5975		.0934	.1097
9		.6722		.0934	.1097
10			1.1763	.6219	.5487
11			1.2696	.9522	.823
12	.112		1.2696	.9335	.8573
13	.0934		1.1203	.8413	.7888
14	.112		.9335	.7964	.6516
15	.1307		.8215	.724	.7202
16	.112		.5601	.6878	.6859
17	.1307	.0514	.4481	.6767	.583
18	.1307	.1029			
19	.112	.1029			
20	.0747	.0857			
21	.112	.0857			
22	.1307	.0857			
23	.112	.0857			
24	.5658	.3734		.0934	.1086
Max	.5658	.6722	1.2696	.9522	.8573
Min	.0747	.0514	.4481	.0747	.0914
Avg	.2481	.3274	.9499	.3972	.3721

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074024 / 33/11 KV MATARGAON

Feeder No / Name : 203 / 11 KV JALAMB GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4668	.4287	.4108	
2		.4481	.4287	.3921	
3		.4854	.4458	.4294	
4		.5228	.4801	.3734	
5		.5228	.5144	.5228	
6		.5228	.6516	.6348	
7		.5601	.6516	.7468	
8		.5975	.6516	.6722	
9		.6161	.5658	.5788	
10	.5041	.5144	.3734		.4287
11	.4481	.4287	.3361		.3772
12	.5228	.3944	.3174		.3772
13	.4854	.3944	.3361		.3429
14	.5041	.3772	.2614		.2572
15	.4854	.3772	.3801		.6859
16	.4481	.4458	.4108		.6173
17	.5228	.6859	.5601		.7202
18	.7468	.7202	.6722		.6173
19	.8962	.7716	.7059		
20	.7842	.6344	.7095		
21	.7095	.583	.5788		.5144
22	.5788	.5144	.5228		
23	.5228	.4801	.4294		
24		.4854	.4287	.3734	
Max	.8962	.7716	.7095	.7468	.7202
Min	.4481	.3772	.2614	.3734	.2572
Avg	.5828	.5229	.4934	.5135	.4938

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074024 / 33/11 KV MATARGAON

Feeder No / Name : 204 / 11 KV MATARGAON GFSS
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2172	.2241	.2058	.2054	.181
2	.2353	.2241	.2058	.2241	.168
3	.2241	.2427	.2058	.2241	.168
4	.1991	.2241	.2229	.2241	.1829
5	.1943	.2427	.2401	.2801	.1829
6	.2427	.2614	.2572	.2614	.2195
7	.2915	.2987	.2743	.2987	.2743
8	.3077	.2801	.2401	.2801	.2561
9	.2804	.2241	.2229	.2614	.2378
10	.2427	.2229	.2241	.2058	.2229
11	.2054	.1715	.2241	.1829	.1715
12	.2241	.1715	.1867	.1867	.1715
13	.2241	.1715	.1867	.1715	.1715
14	.2241	.1543	.1867	.1829	.1886
15	.2427	.2058	.168	.181	
16	.2241	.2058	.2241	.1991	.1715
17	.2427	.2058	.2241	.2195	.2401
18	.2987	.3429	.2987	.3174	.2743
19	.3547	.3429	.2987	.3086	.3258
20	.3361	.3086	.2987	.2743	.2915
21	.3361	.2572	.2614	.2614	.2401
22	.2614	.2401	.2241	.2378	.2229
23	.2427	.2229	.2054	.2195	.2058
24	.2452	.2241	.2058	.2054	.1829
Max	.3547	.3429	.2987	.3174	.3258
Min	.1943	.1543	.168	.1715	.168
Avg	.2540	.2362	.2288	.2339	.2153

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074024 / 33/11 KV MATARGAON

Feeder No / Name : 205 / 11 KV BHASTAN GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2772	.2801	.2572	.2427	.2195
2	.3018	.2614	.2572	.2241	.1991
3	.2801	.2614	.2572	.2241	.2054
4	.2926	.2801	.2572	.2427	.2218
5	.2987	.2801	.2743	.2614	.2218
6	.3174	.2614	.2743	.2987	.2772
7	.3077	.2987	.2743	.3361	.3292
8	.2534	.2801	.2572	.2614	.2926
9	.2241	.2054	.2058	.2427	.2561
10	.2241	.1886	.2241	.1829	.2058
11	.2427	.1715	.2054	.1646	.1543
12	.2241	.1543	.1867	.1646	.1543
13	.2241	.1543	.1867	.1646	.1372
14	.2427	.1372	.2054	.1463	.1372
15	.2427	.1715	.1867	.1494	.1543
16	.2614	.1715	.2614	.1629	.1543
17	.2987		.3361	.2241	.2058
18	.3361	.3772	.3734	.3921	.3086
19	.3734	.4287	.3361	.4024	.4108
20	.3734	.3944	.3361	.3547	.3921
21	.3361	.3601	.2987	.3109	.3429
22	.3174	.3086	.2801	.2801	.1715
23	.2353	.2915	.2614	.2561	.2401
24	.3018	.2614	.2572	.2427	.2195
Max	.3734	.4287	.3734	.4024	.4108
Min	.2241	.1372	.1867	.1463	.1372
Avg	.2828	.2600	.2604	.2472	.2338

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074032 / 33 KV PIMPALGAON RAJA

Feeder No / Name : 200 / 11 KV WASADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.105	.6859	.1524	.1524	.1905
2	1.0669	.6859	.1143	.1524	.1905
3	1.0669	.7621	.1143	.1524	.1905
4	1.0669	.7621	.1143	.1524	.1905
5	1.0669	.7621	.1524	.1524	.1905
6		.9145	.1524	.1524	.1905
7		.9145	.1524	.1524	.1905
8		.9907	.1524	.1524	.1905
9		.9907	.1524	.1524	.1905
10				1.1812	1.3336
11			2.4768	2.1338	2.0195
12	.1524		2.2862	2.2481	1.9814
13	.1524		2.21	2.1338	1.9052
14	.1524		2.0957	2.0957	1.829
15	.1524		1.9433	1.829	1.7528
16	.1524		1.9052	1.829	1.7528
17			1.829	1.7909	1.4861
18	.1524				
19	.1524	.1905			
20	.1524	.1905			
21	.1524	.1905			
22	.1524	.1524			
23	.1524	.1524			
24	1.1431	.6859	.1524	.1524	.1905
Max	1.1431	.9907	2.4768	2.2481	2.0195
Min	.1524	.1524	.1143	.1524	.1905
Avg	.4819	.6020	.9503	.9314	.8870

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074032 / 33 KV PIMPALGAON RAJA

Feeder No / Name : 201 / 11 KV BHALEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2286	.0381	.0381	.0381
2	.3429	.2286	.0381	.0381	.0381
3	.3429	.2286	.0381	.0381	.0381
4	.3048	.2286	.0381	.0381	.0381
5	.3048	.2667	.0381	.0381	.0381
6		.2667	.0381	.0381	.0381
7	.3048	.381	.0381	.0381	.0381
8		.381	.0381	.0381	.0381
9		.381	.0381	.0381	.0381
10				.4572	.381
11	.3048		.9145	.8383	.8002
12	.0381		.9526	.9145	.9145
13	.0381		.9145	.9145	.9145
14	.0381		.8764	.8764	.8002
15	.0381		.8764	.7621	.7621
16	.0381	.0381	.8764	.724	.7621
17	.0381	.0381	.8383	.6097	.6859
18	.0381	.0381			
19	.0381	.0381			
20	.0381	.0381			
21	.0381	.0381			
22	.0381	.0381			
23	.0381	.0381			
24	.381	.2286	.0381		.0381
Max	.381	.381	.9526	.9145	.9145
Min	.0381	.0381	.0381	.0381	.0381
Avg	.1543	.1736	.3900	.3788	.3556

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074032 / 33 KV PIMPALGAON RAJA

Feeder No / Name : 202 / 11 KV PIMPALGAON RAJA AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.0762	.3429	.3429	.4572
2	.1143	.0762	.3429	.3429	.4572
3	.1143	.0762	.381	.3048	.4572
4	.1143	.0762	.381	.3048	.4954
5	.1143	.0762	.381	.381	.5335
6	.1143	.0762	.381	.4954	.5716
7	.1143	.0762	.4572	.6478	.6859
8	.0762	.0762	.4954	.8764	.7621
9	.0762	.0762	.6478	1.0288	.9145
10	.724	.5335			
11	1.4861	1.105			
12	1.6766	1.2574			
13	1.6385	1.5242			
14	1.5623	1.5242			
15	1.448	1.4098			
16	1.4098	1.2574	.1143	.0762	.1143
17	1.2955	1.105	.1143	.1143	.1143
18			.1143	.1143	.1143
19			.1143	.1143	.1143
20			.1143	.1143	.1143
21			.1143	.1143	.1143
22			.1143	.1143	.1143
23			.1143	.1143	.1143
24	.1143	.0762	.3429	.381	.381
Max	1.6766	1.5242	.6478	1.0288	.9145
Min	.0762	.0762	.1143	.0762	.1143
Avg	.6838	.5821	.2815	.3323	.3683

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074032 / 33 KV PIMPALGAON RAJA

Feeder No / Name : 204 / 11 KV TANDULWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1143	.4954	.5335	.5335
2	.1143	.1143	.5335	.4954	.5335
3	.1143	.1143	.5335	.4954	.5335
4	.1143	.1143	.5716	.5335	.6478
5	.1143	.1143	.6478	.5716	.7621
6	.1143	.1143	.6859	.6859	.8383
7	.1143	.1143	.724	.9145	.9526
8	.1143	.1143	.8383	1.2193	1.105
9	.1143	.1143	.9526	1.1812	1.3717
10	.7621	.6859			
11	1.5623	1.5242		.381	
12	1.7528	1.6385		.381	
13	1.5623	1.6766			
14	1.4861	1.6385			
15	1.4098	1.5623			
16	1.448	1.3336	.1143	.1143	.0762
17	1.2193	1.2193	.1143	.1143	.1143
18			.1143	.1143	.1143
19			.1143	.1143	.1143
20			.1143	.1143	.1143
21			.1143	.1143	.0762
22			.1143	.1143	.0762
23			.1143	.1143	.0762
24	.1143	.1143	.4954	.5335	.4572
Max	1.7528	1.6766	.9526	1.2193	1.3717
Min	.1143	.1143	.1143	.1143	.0762
Avg	.6859	.6901	.4107	.4420	.4721

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074032 / 33 KV PIMPALGAON RAJA

Feeder No / Name : 205 / 11 KV PIMPALGAON RAJA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.4954	.3429	.3429	.381
2	.4954	.4954	.3429	.3048	.381
3	.4954	.4572	.3429	.3048	.381
4	.4954	.4572	.381	.3429	.381
5	.4954	.4572	.381	.381	.4191
6	.5335	.4954	.381	.4191	.5335
7	.5335	.5716	.4572	.4572	.5335
8	.4954	.5335	.381	.4191	.4572
9	.4954	.4954	.3429	.4191	.4191
10	.4572	.4954		.381	.381
11	.4191	.3429	.381		.381
12	.4191	.381	.4191		.3429
13	.4191	.3429	.4191	.4191	.3429
14	.4191	.3429	.4191	.4191	.3429
15	.4191	.381	.4191	.4191	.3429
16	.4572		.4191	.4191	.381
17	.5335		.4954	.4572	.4191
18	.5716	.5335	.5335	.5716	.6478
19	.724	.6478	.6859	.7621	.6478
20	.6859	.6478	.6478	.724	.5716
21	.6478	.5335	.5716	.6478	.5335
22	.6478	.4572	.4572	.5716	.4572
23	.6097	.381	.381	.4954	.4191
24	.5335	.5716	.3429	.3429	.4191
Max	.724	.6478	.6859	.7621	.6478
Min	.4191	.3429	.3429	.3048	.3429
Avg	.5208	.4780	.4324	.4555	.4382

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074032 / 33 KV PIMPALGAON RAJA

Feeder No / Name : 207 / 11 KV WASADI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2667	.1905	.1524	.1905
2	.2286	.2667	.1905	.1524	.1905
3	.2286	.2667	.1905	.1524	.1905
4	.2286	.2667	.2286	.1905	.1905
5	.2667	.2667	.2667	.2286	.1905
6	.3048	.3048	.3048	.2667	.3048
7	.3048	.3048	.3048	.3048	.3429
8	.2286	.1905	.2667	.2286	.2667
9	.2286	.1905	.2286	.2286	.1905
10	.1905	.1524		.1905	.1905
11	.1524	.1524	.1524	.1524	.1143
12	.1524	.1524	.1524	.1524	.1143
13	.1524	.1524	.1524	.1524	.1143
14	.1524	.1524	.1524	.1524	.1524
15	.1524	.1524	.1524	.1524	.1143
16	.1524	.1905	.1524	.1524	.1524
17	.1905	.2286	.1905	.1905	.1905
18	.3048	.3429	.2667	.3429	.3048
19	.381	.381	.381	.4191	.3429
20	.3048	.3048	.3429		.3429
21	.3048		.2667	.3048	.3048
22	.3048	.2667	.2667	.2667	.2667
23	.2667		.2286	.2667	.2286
24	.2667	.2667	.2286	.1905	.2286
Max	.381	.381	.381	.4191	.3429
Min	.1524	.1524	.1524	.1524	.1143
Avg	.2365	.2373	.2286	.2170	.2175

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074032 / 33 KV PIMPALGAON RAJA

Feeder No / Name : 208 / JALKA BHADANG EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0381	.0381	.0381
2	.0381	.0381	.0381	.0381	.0381
3	.0381	.0381	.0381	.0381	.0381
4	.0381	.0381	.0381	.0381	.0381
5	.0381	.0381	.0381	.0381	.0381
6	.0381	.0381	.0381	.0381	.0381
7	.0381	.0381	.0381	.0381	.0381
8	.0381	.0381	.0381	.0381	.0381
9	.0381	.0381	.0381	.0381	.0381
10	.0381	.0381		.0381	.0381
11	.0381	.0381	.0381	.0381	.0381
12	.0381	.0381	.0381	.0381	.0381
13	.0381	.0381	.0381	.0381	.0381
14	.0381	.0381	.0381	.0381	.0381
15	.0381	.0381	.0381	.0381	.0381
16	.0381	.0381	.0381	.0381	.0381
17	.0381	.0381	.0381	.0381	.0381
18	.0381	.0381	.0381	.0381	.0381
19	.0381	.0381	.0381	.0381	.0381
20	.0381		.0381	.0381	.0381
21	.0381		.0381	.0381	.0381
22	.0381	.0381	.0381	.0381	.0381
23	.0381	.0381	.0381	.0381	.0381
24	.0381	.0381	.0381	.0381	.0381
Max	.0381	.0381	.0381	.0381	.0381
Min	.0381	.0381	.0381	.0381	.0381
Avg	.0381	.0381	.0381	.0381	.0381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074032 / 33 KV PIMPALGAON RAJA

Feeder No / Name : 209 / 11 KV TANDULWADI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1524	.1524	.1143
2	.1524	.1524	.1524	.1143	.1143
3	.1524	.1524	.1524	.1143	.1143
4	.1524	.1524	.1143	.1524	.1524
5	.1905	.1524	.1524	.1524	.1524
6	.2286	.1905	.1524	.1905	.1524
7	.2286	.2286	.2667	.2286	.2286
8	.2286	.2286	.2286	.1905	.2286
9	.2286	.1905	.2286	.1905	.1905
10	.1524	.1524		.1143	.1524
11	.1524	.1524	.1524	.1524	.1143
12	.1143	.1524	.1524	.1524	.1143
13	.1143	.1143	.1524	.1524	.1143
14	.1143	.1143	.1143	.1524	.1143
15	.1143	.1143	.1143	.1524	.1143
16	.1524	.1143	.1143	.1524	.1524
17	.1905	.1524	.1524	.1524	.1905
18	.2667	.2667	.2286	.2286	.2667
19	.2667	.2667	.3048	.2667	.2667
20	.2286	.2286	.2667	.2286	.2286
21	.1905	.2286	.2286	.1905	.2286
22	.1905	.1905	.1905	.1905	.1905
23	.1905	.1524	.1524	.1905	.1524
24	.1905	.1524	.1524	.1524	.1524
Max	.2667	.2667	.3048	.2667	.2667
Min	.1143	.1143	.1143	.1143	.1143
Avg	.1810	.1730	.1772	.1715	.1667

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074069 / 33 KV ROHANA

Feeder No / Name : 201 / 11 KV ROHANA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.8002	.9069
2				.8002	.9231
3				.7621	.9231
4				.7621	.9231
5				.6859	.9717
6				.6478	.9488
7				.6478	.9804
8				.724	1.0822
9				.8764	.9755
10		1.3336	1.085		
11		1.5813	1.3413		
12		1.829	1.4175		
13		1.5242	1.387		
14	1.6078	1.7147	1.326		
15	1.6244	1.5051	1.2955		
16	1.5415	1.5051	1.2041		
17	1.6194	1.2452	1.5051		
24				.8002	.9069
Max	1.6244	1.829	1.5051	.8764	1.0822
Min	1.5415	1.2452	1.085	.6478	.9069
Avg	1.5983	1.5298	1.3202	.7507	.9542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074069 / 33 KV ROHANA

Feeder No / Name : 202 / 11 KV WARNA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3239	.2401	.3048	.381
2	.3048	.3239	.2229	.2858	.4001
3	.3048	.3239	.2229	.2858	.4001
4	.3048	.3239	.2229	.2858	.4572
5	.3429	.3429	.3601	.3239	.4954
6	.4954	.4954	.4115	.4954	.4973
7	.5525	.5335	.4973	.5525	.5487
8	.5906	.6287	.5144	.6668	.6344
9	.6097	.6097	.5487	.6668	.6371
10	.5487	.6097	.5658	.6668	.6173
11		.6859	.6001		.7621
12	.3258	.743	.6173	.6287	.5525
13	.4458	.8002	.6344	.583	.6539
14	.583	.8002	.6001	.7209	.6706
15	.6344	.7811	.583	.7712	.6203
16	.6344	.8192	.6173	.7712	.5365
17	.724	.6859	.7049	.7042	.57
18	.4763	.4801	.7049	.7122	.4287
19	.4572	.5144	.6859	.6001	.3944
20	.3429	.2915	.4763	.4961	.3258
21	.381	.3086	.4001	.4572	.3258
22	.3429	.2743	.381	.4382	.3086
23	.3429	.2572	.3429	.381	.2915
24	.3239	.3239	.2667	.3048	.381
Max	.724	.8192	.7049	.7712	.7621
Min	.3048	.2572	.2229	.2858	.2915
Avg	.4510	.5117	.4759	.5262	.4954

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074069 / 33 KV ROHANA

Feeder No / Name : 203 / 11 KV DIWTHANA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905			.2096	.1677
2	.1905			.2096	.1844
3	.1905			.1905	.1844
4	.1715			.1524	.1844
5	.1715			.1524	.218
6				.1524	.2515
7				.1905	.285
8				.1715	.3688
9				.2667	.4144
10		.1905	.1715		
11		.3239	.2572		
12		.3429	.3772		
13		.4001	.3856		
14		.4001	.3688		
15		.362	.3429		
16		.362	.3601		
17		.2915	.381		
24	.1905			.2096	.1715
Max	.1905	.4001	.3856	.2667	.4144
Min	.1715	.1905	.1715	.1524	.1677
Avg	.1842	.3341	.3305	.1905	.2430

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074069 / 33 KV ROHANA

Feeder No / Name : 204 / 11 KV NIMKAWALA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.4572	.2915		
2	.381	.4572	.2743		
3	.381	.4572	.2743		
4	.381	.4572	.2743		
5	.381	.4572	.2915		
6		.4001	.3086		
7		.362	.4287		
8		.4382	.5144		
9		.4572	.4858		
10				.5335	.5182
11				.8573	.6802
12				.8954	.7287
13				.7116	.7611
14				.7432	.7449
15				.6642	.6964
16		.1524		.6401	.7611
17				.6483	.7125
24	.4191	.4572	.3086		
Max	.4191	.4572	.5144	.8954	.7611
Min	.381	.1524	.2743	.5335	.5182
Avg	.3937	.4139	.3452	.7117	.7004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074069 / 33 KV ROHANA

Feeder No / Name : 205 / 11 KV ROHANA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1143	.1524	.1143	.1334
2	.0953	.1143	.1334	.1143	.1334
3	.0953	.1143	.1334	.0953	.1334
4	.0953	.1143	.1334	.0953	.1334
5	.1334	.1524	.1524	.1334	.1524
6	.2096	.1715	.1715	.1905	.1905
7	.2286	.1715	.1905	.2096	.2286
8	.2286	.1905	.1715	.1905	.2096
9	.1715	.1905	.2286	.2096	.2096
10	.1905	.1715	.1905	.1524	.2096
11		.1715	.1715	.1143	.1143
12	.1334	.1524	.1524	.1524	.0953
13		.1524	.1524	.1524	.1715
14		.1524	.1715	.1334	.1341
15		.1715	.1524	.1524	.1174
16	.1715	.1524	.1524	.1524	.1134
17	.1715	.1715	.1715	.1715	.1619
18	.2477	.2477	.2286	.2286	.2286
19	.2477	.2286	.2477	.2477	.2477
20	.2096	.2096	.2096	.2096	.2096
21	.1715	.1905	.1715	.1905	.1905
22	.1524	.1715	.1524	.1715	.1715
23	.1143	.1715	.1334	.1334	.1715
24	.1334	.1143	.1524	.1143	.1334
Max	.2477	.2477	.2477	.2477	.2477
Min	.0953	.1143	.1334	.0953	.0953
Avg	.1658	.1651	.1699	.1596	.1664

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074099 / 33/11 kV Dhorapgaon

(Bhalegaon

Feeder No / Name : 201 / 11 KV KALEGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5868	.567			
2	.5868	.567			
3	.602	.567			
4	.5719	.567			
5	.5719	.6024			
6		.6415			
7		.6762			
8		.8505			
9		.7619			
10			.571	.7011	.7716
11			1.0936	1.1269	1.2003
12			1.3443	1.3003	1.3717
13			1.3283	1.3523	1.4232
14			1.1717	1.3003	1.286
15			1.1265	1.1694	1.2003
16			1.2029	1.0808	1.166
17			1.0494	.7087	1.1145
24	.5868	.567			
Max	.602	.8505	1.3443	1.3523	1.4232
Min	.5719	.567	.571	.7011	.7716
Avg	.5844	.6368	1.1110	1.0925	1.1917

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074099 / 33/11 kV Dhorapgaon

(Bhalegaon

Feeder No / Name : 202 / 11 KV DHORAPGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	12-DEC-17
HR	Load (MW)
3	.1524
Max	.1524
Min	.1524
Avg	.1524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074099 / 33/11 kV Dhorapgaon

(Bhalegaon

Feeder No / Name : 203 / 11 KV DHORAPGAON GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.2641	.2572	.2452	.2452
2	.2829	.2641	.2572	.2452	.2452
3	.2829	.2641	.2572	.2452	.2452
4	.2829	.2641	.2572	.2452	.2452
5	.2829	.2641	.3086	.2452	.2452
6	.3395	.3361	.3772	.3206	.3174
7	.415	.3174	.4115	.4527	.4338
8	.415	.3734		.3584	.3772
9	.3326	.3547	.3429	.3395	.3086
10	.2829	.2572	.3018	.2987	.2572
11	.2263	.2229	.2641	.2241	.1886
12	.2263			.1867	.1886
13	.2263	.2058	.2263	.2075	.1715
14	.1698	.1886	.2241	.1886	.1715
15	.2263	.2058	.2241	.1886	.1715
16	.2263	.2229	.2614	.1886	.1886
17	.2829	.2572	.3326	.2452	.2058
18	.415	.4115	.4435	.4338	.3601
19	.4527	.4287	.4668	.4715	.3944
20	.3961	.3772	.3772		.3601
21	.3584	.3429	.3395	.3584	.3086
22	.3206	.3086	.2829	.2829	.2743
23	.2829	.2572	.2641	.2641	.2572
24	.2829	.2641	.2572	.2452	.2452
Max	.4527	.4287	.4668	.4715	.4338
Min	.1698	.1886	.2241	.1867	.1715
Avg	.3038	.2892	.3061	.2818	.2669

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074103 / 33/11 kV Palshi

Feeder No / Name : 201 / 11 KV AMBIKAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.7545	.5792	.5144	.543
2	.6516	.7373	.5788	.4973	.543
3	.6516	.6859	.6348	.4973	.543
4	.6516	.6859	.5973	.5144	.543
5	.6859	.7202	.6161	.5487	.543
6	.6173	.7716	.6722	.6173	.6516
7	.7716	.823	.7762	.7888	.8145
8	.7373	.703	.7947	.7373	.7602
9	.6516	.703	.7468	.7202	.724
10	.6173	.6001	.7716	.6344	.8507
11	.583	.5975	.9774	.8869	.8413
12	.5658	.5487	1.0631	1.0679	1.0631
13	.5316	.5544	.9602	1.0679	.823
14	.5144	.567	1.0288	1.0498	.9522
15	.5144	.5792	.9774		1.0082
16	.5316	.5975	.9602	1.0498	.9511
17	.6001	.6219	.9259	1.0317	.9145
18	.7545	.6908	.6516	.724	.7499
19	.7373	.6584	.6859	.724	
20	.6859	.7282	.6344	.6697	
21	.6001	.6878	.6173	.5973	
22	.6516	.6722	.5487	.5792	
23	.6687	.6535	.5144	.5792	
24	.6859	.7716	.5975	.5144	.5792
Max	.7716	.823	1.0631	1.0679	1.0631
Min	.5144	.5487	.5144	.4973	.543
Avg	.6380	.6714	.7463	.7223	.7578

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074103 / 33/11 kV Palshi

Feeder No / Name : 202 / 11 KV PALSHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.3772	.1463	.1886	.1991
2	.2915	.3772	.168	.1886	.1991
3	.2915	.3772	.1463	.1886	.1991
4	.2915	.3429	.168	.1886	.1991
5	.2915	.2743	.1829	.1886	.1991
6	.2229	.2915	.1867	.2229	.2715
7	.2058	.2743	.1829	.2743	.3077
8	.1886	.2229	.168	.3086	.2896
9	.1886	.2401	.1829	.2229	.2534
10	.1372	.1715	.2743	.1715	.362
11	.12	.1848	.4458	.362	.439
12	.1372	.1307	.5144	.4887	.5304
13	.1543		.5487	.543	.443
14	.1543	.112	.4801	.5068	.439
15	.1715	.1086	.4458	.4525	.4572
16	.1715	.112	.4801	.4525	
17	.1543	.1448	.4287	.4344	.3658
18	.2401	.1848	.2058	.2353	.7265
19	.2743	.1867	.2401	.181	
20	.2743	.2012	.2401	.2715	
21	.2743	.181	.2229	.2534	
22	.2915	.1829	.2058	.2172	
23	.2915	.1848	.2058	.2172	
24	.4115	.3944	.1629	.1886	.2172
Max	.4115	.3944	.5487	.543	.7265
Min	.12	.1086	.1463	.1715	.1991
Avg	.2301	.2286	.2764	.2895	.3388

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON(R) S/DN[291] BU 2917

Substation No/ Name :- 074103 / 33/11 kV Palshi

Feeder No / Name : 203 / 11 KV KADMAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1543	.181	.1715	.181
2	.12	.1543	.1829	.1715	.181
3	.12	.1543	.1867	.1715	.181
4	.12	.1715	.1478	.1543	.181
5	.12	.1715	.1494	.1543	.181
6	.1372	.1715	.1629	.1715	.2534
7	.1543	.1372	.1867	.2058	.1991
8	.1543	.12	.1867	.1543	.181
9	.1372	.12	.168	.1543	.1086
10	.12	.12	.1029	.0857	.0724
11	.12	.1267	.1715	.1448	.128
12	.12	.1307	.2058	.1629	.3292
13	.12	.1267	.2229	.181	.1463
14	.1029	.128	.1715	.1629	.1463
15	.1029	.1307	.12	.1267	.1097
16	.12	.128	.12	.1267	.1097
17	.1029	.128	.1543	.1448	.1595
18	.1543	.1867	.1543	.1991	.1829
19	.1886	.1867	.2058	.2172	
20	.1886	.2172	.2058	.2172	
21	.2058	.2241	.1886	.2172	
22	.1886	.1829	.1715	.1991	
23	.1715	.1867	.1715	.1991	
24	.1372	.1715	.1867	.1715	.1991
Max	.2058	.2241	.2229	.2172	.3292
Min	.1029	.12	.1029	.0857	.0724
Avg	.1386	.1554	.1711	.1694	.1700

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074026 / 33 kv MIDC Khamgaon s/s

Feeder No / Name : 201 / 11 kv Vardhan

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859		.4572	.724	1.0288
2	.6859		.4572		1.0288
3	.6859		.4572		1.0288
4	.6859		.4572		1.0288
5	.6859		.4572		1.0288
6	.724		.5426		1.0288
7	.724		.5487		1.0288
8	.6859		.5609	.7621	.9907
9	.7621		.631	.8383	1.1812
10	.8002		.8383	.9709	1.3717
11	.8383		.9145	.9511	1.3717
12	.8764		.8764	.9709	1.3336
13	.9526		.8764	1.0456	1.3336
14	.8383		.8764	1.0608	1.3336
15	.9526		.8764	1.1694	1.3717
16	.8383		.9145	1.1317	1.3717
17	.8002		.9145	1.1694	1.2955
18	.8383		.9526	1.2193	1.2826
19		.6935	.8383	1.2193	1.2071
20		.5761	.7621	1.0669	1.0242
21		.5441	.6859	1.0669	.9511
22		.4572	.6478	1.0669	.9877
23		.5121	.6859	1.0669	.9877
24	.6859		.5182	.724	1.0288
Max	.9526	.6935	.9526	1.2193	1.3717
Min	.6859	.4572	.4572	.724	.9511
Avg	.7761	.5566	.6978	1.0125	1.1511

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074026 / 33 kv MIDC Khamgaon s/s

Feeder No / Name : 202 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429		.415		.3429
2	.3429		.4904		.3429
3	.3429		.4527		.3429
4	.3429		.4527		.3429
5	.3429		.4527		.3429
6	.3429		.4527		.3429
7	.381		.4527		.4191
8	.381		.4527	.4572	.4191
9	.6097		.6036	.381	.724
10	.7049		.6478	.5658	.6859
11	.6859		.6859	.4755	.6859
12	.6859		.6478	.5121	.724
13	.6859		.6287		.7621
14	.7621		.6478	.4904	.8002
15	.724		.7049	.4904	.7621
16	.743		.724	.4805	.724
17	.7621		.6859	.4755	.724
18	.724	.679	.6859	.5335	.6733
19		.679	.6668	.4954	.6733
20		.6413	.6859	.4954	.6379
21			.5716	.4572	.4607
22		.4527	.4572	.381	.4706
23		.415	.4572	.3429	
24	.3429		.415	.4572	.3429
Max	.7621	.679	.724	.5658	.8002
Min	.3429	.415	.415	.3429	.3429
Avg	.5395	.5734	.5641	.4682	.5542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074026 / 33 kv MIDC Khamgaon s/s

Feeder No / Name : 203 / 11 kv Khamgaon Syntex NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335		.4961		.4954
2	.5335		.4481		.4954
3	.5335		.4481		.4954
4	.5335		.4481		.4954
5	.5335		.4481		.4954
6	.5716		.4481		.4954
7	.5716		.4481		.4954
8	.6097		.5975	.4572	.381
9	.6859		.5975	.4954	.6097
10	.724		.6097	.431	.7621
11	.724		.6478	.4973	.7621
12	.743		.6097	.503	.7811
13	.6859		.6097	.4694	.8002
14	.6478		.6097	.4908	.8192
15	.6478		.6287	.5373	.7621
16	.6668		.6478	.5258	.724
17	.6478		.5716	.5087	.8192
18	.6478	.6036	.5525	.5716	.724
19		.6036	.4191	.5716	.7602
20		.5609	.4382	.5716	.6154
21		.5544	.4191	.5716	.6154
22			.4191	.5716	.5792
23		.421	.4191	.5335	.5487
24	.5335		.4481	.4191	.4954
Max	.743	.6036	.6478	.5716	.8192
Min	.5335	.421	.4191	.4191	.381
Avg	.6197	.5487	.5179	.5133	.6261

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074026 / 33 kv MIDC Khamgaon s/s

Feeder No / Name : 204 / 11 kv Federation

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669		.8642	1.1812	1.1812
2	1.0288		.8962		1.1812
3	1.0288		.8962		1.1812
4	1.0288		.8962		1.1812
5	1.0288		.8962		1.1812
6	1.0669		.8962		1.2574
7	1.105		.9122		1.3336
8	1.2193		1.1218	1.1812	1.2955
9	1.5242		1.4548	1.1431	1.5242
10	1.7528		1.829	1.1706	1.6766
11	1.6004		1.8671	.9328	1.6766
12	1.5242		1.7147	1.0517	1.6956
13	1.448		1.6385	.9877	1.7528
14	1.6575		1.7528	1.0791	1.829
15	1.6956		1.9052	1.0791	1.7528
16	1.7718		1.8099	1.0242	1.7147
17	1.7528		1.7147	1.2269	1.829
18	1.7147	1.4784	1.6385	.9907	1.4118
19		1.4784	1.4861	.9526	1.3394
20		1.1706	1.2384	.9907	1.182
21		1.0425	1.2193	.9907	1.1283
22		1.0341	1.2193	1.105	1.1283
23		1.0341	1.2193	1.1812	1.0682
24	1.0669		1.0341		1.1812
Max	1.7718	1.4784	1.9052	1.2269	1.829
Min	1.0288	1.0341	.8642	.9328	1.0682
Avg	1.3727	1.2064	1.3384	1.0746	1.4035

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074026 / 33 kv MIDC Khamgaon s/s

Feeder No / Name : 205 / 11 kv Industrial

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191		.3696		.4191
2	.4191		.4066		.4191
3	.4191		.3696		.4191
4	.4191		.3696		.4191
5	.4191		.3696		.4191
6	.4191		.3696		.4572
7	.4191		.3696		.4572
8	.4572		.3696	.4572	.381
9	.4572		.3696	.4954	.4191
10	.5335		.4572	.3582	.381
11	.5716		.5335	.5014	.4191
12	.5716		.4954	.4527	.4572
13	.4954		.4954	.4835	.4572
14	.5335		.4954	.3982	.4954
15	.4954		.4954	.4344	.4954
16	.5335		.5335	.4527	.5335
17	.5335		.4954	.4904	.5335
18		.3734	.4572	.4572	.2926
19		.4481	.4191	.4572	.3292
20		.4066	.381	.4572	.2926
21		.2267	.4191	.4191	.3734
22		.3563	.4572	.4191	.3658
23		.3201	.4191	.4191	.3772
24	.4191		.3696	.4191	.4191
Max	.5716	.4481	.5335	.5014	.5335
Min	.4191	.2267	.3696	.3582	.2926
Avg	.4742	.3552	.4286	.4454	.4180

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074026 / 33 kv MIDC Khamgaon s/s

Feeder No / Name : 206 / 11 KV SUTALA BK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048		.2534		.3048
2	.3048		.2534		.3048
3	.3048		.2454		.3048
4	.3048		.2454		.3048
5	.3048		.2454		.381
6	.3429		.2896		.4572
7	.4191		.3982		.4954
8	.4572		.5068	.4572	.5335
9	.4572		.4706	.4954	.5335
10	.381		.4572	.4805	.4954
11	.381		.4001	.3696	.381
12	.3429		.381	.3696	.362
13	.381		.3048	.3326	.3429
14	.3429		.3048	.3696	.3048
15	.2667		.3048	.3696	.3429
16			.3239	.362	.4001
17			.4191	.3696	.4191
18	.6478	.5068	.4382	.4954	
19		.5068	.4572	.5716	.5121
20		1.2382	.4382	.4954	.4755
21		.4435	.381	.381	.439
22		.362	.3429	.381	.4024
23		.2957	.2667	.3429	.3395
24	.3048		.2896	.2286	.3048
Max	.6478	1.2382	.5068	.5716	.5335
Min	.2667	.2957	.2454	.2286	.3048
Avg	.3676	.5588	.3507	.4042	.3974

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074026 / 33 kv MIDC Khamgaon s/s

Feeder No / Name : 401 / 33 kv HLL Stand by NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147		1.6575		.9145
2	1.7147		1.5432		.9145
3	1.7147		1.4861		.9145
4	1.7147		1.4861		.9145
5	1.6004		1.4861		.9145
6	1.6004		1.4861		1.0288
7	1.4861		1.4861		1.2574
8	1.6004		1.4861	1.3717	1.4861
9	1.7147		1.4861	1.0288	1.2574
10	1.7147		1.4861	1.0288	1.3717
11	1.6004		1.6004	.9717	1.3717
12	1.6004		1.6004		1.4289
13	1.7147		1.6004	.9717	1.4289
14	1.5432		1.4861		1.4289
15	1.4861		1.3717	1.0288	.5716
16	1.6575		1.6004	1.2574	1.4861
17	1.7147		1.6004	1.1431	1.4861
18	1.829	1.6004	1.6004	1.2574	
19		1.7147	1.4861	1.1431	1.6004
20		1.6004	1.3717	1.1431	1.6004
21		1.6575	1.3717	1.1431	1.4861
22		1.5432	1.3717	1.0288	1.4861
23		1.4861	1.4861	.9145	
24	1.7147		1.6004	1.6004	.9145
Max	1.829	1.7147	1.6575	1.6004	1.6004
Min	1.4861	1.4861	1.3717	.9145	.5716
Avg	1.6545	1.6004	1.5099	1.1355	1.2393

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074048 / 33 kv Sajjanpuri s/s

Feeder No / Name : 201 / 11 kv Ghatpuri

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2743	.2572	.2401	.2401
2	.2743	.2743	.2572	.2401	.2401
3	.2743	.2743	.2572	.2401	.2401
4	.3086	.2743	.2572	.2572	.2401
5	.3086	.3086	.2572	.2915	.3086
6	.3429	.3429	.2743	.3429	.3429
7	.4115	.3944	.3601	.3772	.3944
8	.3429	.4115	.4115	.4115	.3944
9	.4458	.4287	.4287	.4801	.463
10	.4287	.4287	.3772	.4458	.4115
11		.3944	.3772	.4115	.4115
12	.4287	.4287	.3601	.3772	.3772
13	.4287	.4115	.3258	.3601	.3772
14	.4287	.3944	.2915	.3601	.4115
15		.4287	.3429	.3601	.4115
16	.4458	.463	.3772	.3601	.3772
17	.3429	.3944	.3772	.3772	.3772
18	.4115	.4287	.3772	.3944	.4115
19	.463	.4287	.3772	.4115	.4115
20	.4973	.4287	.3772	.3944	.4115
21	.3429	.3772	.3601	.3772	.4115
22	.3086	.3601	.3258	.3429	.3429
23	.3429	.2915	.2572	.2743	
24	.2743	.2743	.2743	.2401	.2401
Max	.4973	.463	.4287	.4801	.463
Min	.2743	.2743	.2572	.2401	.2401
Avg	.3694	.3715	.3308	.3487	.3586

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074048 / 33 kv Sajanjuri s/s

Feeder No / Name : 203 / 11 kv Sajanjuri

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.1715	.1886	.1715	.2401
2	.2058	.1715	.1886	.1715	.2401
3	.2058	.1715	.1886	.1886	.2401
4	.2058	.1715	.2058	.2058	.2401
5	.2401	.2058	.2401	.2058	.2401
6	.2743	.2401	.2572	.2401	.2401
7	.3429	.3086	.3086	.2743	.3086
8	.2743	.3086	.2401	.2743	.3086
9	.2743	.2743	.2229	.3086	.3086
10	.2743	.2915	.2229	.2915	.2743
11		.2743	.2058	.2915	.3086
12	.2572	.2572	.2058		.2743
13	.2572	.2572	.2058	.2229	.2401
14	.2401	.2572	.2229	.2401	.2058
15	.2401	.2401	.2401	.2401	.2058
16	.2401	.2401	.2743	.2743	.2058
17	.2743	.2743	.2915	.2915	.2743
18	.2915	.2572	.3086	.3086	.3086
19	.3086	.2743	.2743	.3086	.3086
20	.2401	.2401	.2401	.2401	.2743
21	.2229	.2401	.2058	.2401	.2401
22	.2229	.2058	.2058	.2401	.2401
23	.2058	.1886	.1886	.2401	
24	.2058	.1715	.1715	.1715	.2401
Max	.3429	.3086	.3086	.3086	.3086
Min	.2058	.1715	.1715	.1715	.2058
Avg	.2483	.2372	.2293	.2453	.2594

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074048 / 33 kv Sajanjuri s/s

Feeder No / Name : 409 / 33 kv Rohana

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9259			1.2346	1.6461
2	.9259	.7716	.9259	1.2346	1.6461
3	.823	.7716	.8745	1.286	1.6461
4	.823	.7716	.8745	1.286	1.6461
5	.7202	.7716	.8745	1.286	1.6461
6	.6173	.823	1.0802	1.286	1.6461
7	.7202	.9259	1.1317	1.3889	2.0062
8	.7202	1.0802	1.1831	1.5432	2.0576
9	.7202	1.1317	1.2346	1.8004	2.2634
10	1.8004	1.9547	2.0576	1.2346	1.3375
11		2.4177	2.5206	1.286	1.4403
12	2.0062	2.7263	2.6235	1.3375	1.3375
13	2.1605	2.4177	2.6235	1.4403	1.5432
14	2.2634	2.6749	2.572	1.5432	1.6461
15	2.3148	2.4691	2.4691	1.6461	
16	2.2119	2.4691	2.4177	1.6461	1.4403
17	2.1605	2.4177	2.3663	1.5432	1.4403
18	.7202	.7202	.823	.7716	.6687
19	.6687	.6687	.6687	.7202	.6173
20	.463	.5144	.5658	1.3375	.5144
21		.463	.5144		.5144
22	.4115	.6173	.4115		.4115
23	.4115	.6687	.4115		
24	.9259	.7716	1.1317	1.286	1.5432
Max	2.3148	2.7263	2.6235	1.8004	2.2634
Min	.4115	.463	.4115	.7202	.4115
Avg	1.1597	1.3486	1.4068	1.3399	1.3936

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074076 / 33 KV RUSHI SANKUL S/S

Feeder No / Name : 201 / 11 kv Industrial

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	1.0669	1.0288	1.0669	1.0669
2	.9526	1.0669	1.0288	1.0288	1.0288
3	.9526	1.105	1.0288	.9907	1.0288
4	.9526	1.105	1.0288	.9907	.9907
5	.9526	1.0669	1.0288	1.105	1.0288
6	1.0669	1.0288	1.0288	1.0669	1.0669
7	1.0669	1.0288	.8764	.9526	1.1431
8	1.1431	1.3717	.9145	1.1431	1.2193
9	1.5242	1.5242	1.3717	1.3336	1.448
10	1.7147	1.5623	1.2955	1.5242	1.4098
11	1.7147	1.5242	.9907	1.5242	1.6956
12	1.6004	1.5623	1.1812	1.3336	1.5278
13	1.4861	1.5242	1.2765	1.448	1.1883
14	1.5242	1.5623	1.3146	1.4098	1.448
15	1.5242	1.5242	1.4098	1.2955	1.5051
16	1.5242	1.4861	1.4098	1.4098	1.4861
17	1.5242	1.5623	1.4098	1.4861	1.448
18	1.6766	1.5623	1.448	1.4861	1.448
19	1.5623	1.5623	1.4861	1.4861	1.5242
20	1.3717	1.3717	1.1812	1.5242	1.448
21	1.105	.9907	1.2574	1.1431	1.0288
22	1.1431	.9526	1.0288	1.0669	
23	1.0669	.9526	.9907	1.0669	
24	.9907	1.0288	.9526	1.0669	1.0669
Max	1.7147	1.5623	1.4861	1.5242	1.6956
Min	.9526	.9526	.8764	.9526	.9907
Avg	1.2971	1.2955	1.1653	1.2479	1.2839

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074076 / 33 KV RUSHI SANKUL S/S

Feeder No / Name : 202 / 11 kv Januna

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.104	.1478	.1478	.104	.128
2	.104	.1478	.1478	.104	.128
3	.104	.1478	.1478	.1214	.1463
4	.104	.1494	.1478	.104	.1463
5	.104	.1663	.1478	.104	.1463
6	.1387	.1663	.1663	.104	.1829
7	.1387	.1663	.1848	.104	.2195
8	.1734	.2033	.2218	.156	.2561
9	.2427	.2957	.2195	.2587	.1772
10	.1734	.1848	.1991	.2772	.1753
11	.1734	.3121	.1734	.1848	.1417
12	.1734	.1734	.1734	.1478	.1417
13	.1663	.3814	.1907	.1663	.3155
14	.1663	.3814	.1734	.1478	.1402
15	.2218	.3814	.1928	.1663	.2149
16	.2402	.1734	.1629	.1848	.362
17	.2772	.1734	.156	.1402	.2957
18	.2587	.1907	.156	.1387	.2957
19	.2218	.1734	.156	.2103	.2033
20	.2033	.1734	.156	.1578	.1848
21	.1848	.1848	.1734	.1417	.1663
22	.1848	.1867	.1214	.1417	
23	.1663	.1663	.1214	.1463	
24	.104	.1478	.1478	.104	.0146
Max	.2772	.3814	.2218	.2772	.362
Min	.104	.1478	.1214	.104	.0146
Avg	.1721	.2073	.1660	.1507	.1901

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074076 / 33 KV RUSHI SANKUL S/S

Feeder No / Name : 203 / 11 kv Omkareshwar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3921	.3734	.3734	.3395	.3361
2	.3734	.3734	.3547	.3395	.3361
3	.3734	.3547	.3734	.3206	.3361
4	.3734	.3547	.3547	.3018	.4108
5	.3921	.4108	.3921	.3584	.4668
6	.5281	.5228	.4481	.4715	.5415
7	.679	.6722	.6722	.679	.6908
8	.7733	.6348	.7095	.6602	.6535
9	.7545	.6161	.6722	.6348	.6535
10	.7167	.5415	.6036	.5975	.6468
11	.6979	.5281	.5788	.5228	.5228
12	.679	.4715	.5068	.4854	.4715
13	.5975	.4715	.4715	.4481	.4294
14	.4481	.4294	.415	.4294	.4108
15	.3547	.4108	.3547	.3547	.3658
16	.4108	.4108	.4108	.4481	.4481
17	.4668	.4715	.4668	.4854	.4481
18	.5601	.6036	.5847	.6348	.6348
19	.5415	.5847	.5847	.5415	.6161
20	.5415	.5281	.5281	.4854	.5415
21	.5228	.5041	.4715	.462	.4854
22	.4854	.5041	.4338	.4338	
23	.4294	.5041	.3772	.3921	
24	.3961	.3734	.3734	.3206	.3361
Max	.7733	.6722	.7095	.679	.6908
Min	.3547	.3547	.3547	.3018	.3361
Avg	.5203	.4854	.4797	.4645	.4901

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 074076 / 33 KV RUSHI SANKUL S/S

Feeder No / Name : 407 / 33 KV HIVARKHED NON SHEDDABLE WATER SUPPLY AND
 Feeder KV- 33 / INCOMING UTILITY

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.0832	4.5668	3.7071	4.0832	3.546
2	3.9758	4.513	3.7071	4.1907	3.4385
3	3.9758	4.4593	3.5997	4.1907	3.6534
4	3.9758	4.3519	3.6534	4.2444	5.2115
5	4.1907	4.7817	3.9758	4.6205	5.4801
6	4.5668	5.8025	5.2652	5.3727	5.8025
7	6.5547	6.0711	6.3397	5.8025	7.0919
8	6.9845	6.5009	7.0919	6.4472	7.4143
9	6.8233	6.3935	7.4143	6.3397	8.059
10	6.9845	5.8025	7.2531	5.9637	7.2531
11	6.8233	5.8025	6.6084	5.8025	6.8039
12	7.0919	5.1578	7.3068	5.3189	5.8025
13	6.9307	5.0503	6.7158	4.9429	5.5338
14	6.286	4.2444	3.8683	3.3311	1.9342
15	4.1907	4.4056	4.0832	3.8683	3.9758
16	4.6742	4.4593	4.137	2.3102	2.7938
17	4.7279	4.7279	4.6205	1.6118	3.2773
18	4.5668	4.2981	4.2981	4.2219	4.2981
19	4.513	4.0832	4.2981	4.5668	4.2981
20	3.922		3.7071	3.7071	3.5997
21	3.3848	3.2236	3.2773	3.3311	3.2773
22	3.1699	3.4922	2.9012	3.0087	
23	4.1907	3.6534	4.0295	3.4385	
24	4.0832	4.6742	3.8146	4.137	3.5997
Max	7.0919	6.5009	7.4143	6.4472	8.059
Min	3.1699	3.2236	2.9012	1.6118	1.9342
Avg	5.0279	4.8050	4.8197	4.3688	4.8248

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 077003 / 132 kv Khamgaon s/s

Feeder No / Name : 201 / 11 kv Town-I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	11-DEC-17
HR	Load (MW)
21	.0103
Max	.0103
Min	.0103
Avg	.0103

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 077003 / 132 kv Khamgaon s/s

Feeder No / Name : 404 / 33 kv MIDC NON SHEDDABLE WATER SUPPLY AND
 Feeder KV- 33 / INCOMING UTILITY

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.5725		4.9154		4.8011
2	4.4582		5.0297		4.8011
3	4.4582		4.9154		4.8011
4	4.3439		4.9154		4.8011
5	4.3439		4.9154		4.9154
6	4.4582		4.9154		5.144
7	4.6868		4.9154		5.3727
8	5.0297		5.2584	5.0297	5.6013
9	6.0585		5.9442	5.144	6.1728
10	6.6873		6.4015	5.144	6.8016
11	6.4586		6.6873	5.144	6.7444
12	6.4015		6.4015	5.9442	6.8587
13	6.4015		6.23	5.0297	6.9159
14	6.4015		6.23	4.9154	7.0873
15	6.3443		6.3443	5.2584	7.0302
16	6.2872		6.6301	5.487	7.0302
17	6.2872		6.4586	5.6013	7.1445
18	6.973	6.6301	6.4015	5.8299	7.2017
19		6.2872	5.8299	5.8299	6.8587
20		6.0585	5.3727	5.6013	6.1728
21		5.487	5.2584	5.144	5.9442
22		5.2584	5.2584	5.144	5.6013
23		4.9154	5.144	4.8011	5.6013
24	4.5725		5.0297	5.144	4.8011
Max	6.973	6.6301	6.6873	5.9442	7.2017
Min	4.3439	4.9154	4.9154	4.8011	4.8011
Avg	5.5381	5.7728	5.6418	5.3054	6.0085

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 077003 / 132 kv Khamgaon s/s

Feeder No / Name : 407 / 33 kv Chikhali

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.7716	6.394	5.3755	5.7716	5.2092
2	5.6019	6.3375	5.3755	5.9414	5.1532
3	5.6019	6.3375	5.2624	5.8848	5.1532
4	5.6019	6.1677	5.3189	5.8848	6.6655
5	5.8282	6.677	5.715	6.4506	7.3937
6	6.5072	7.8087	7.1296	7.2994	7.7858
7	9.2798	8.2613	8.2613	7.9218	9.3542
8	9.2798	8.9403	9.1101	8.7706	9.7462
9	9.6194	9.0535	9.5473	8.8838	10.371
10	9.7891	8.2613	6.0271	8.4311	8.9723
11	9.6759	8.3745	8.0361	8.2047	9.1764
12	9.7891	7.6955	9.2307	7.5257	7.8732
13	9.4496	7.5823	8.6334	7.2428	7.3303
14	8.714	6.677	5.647	5.4321	3.9758
15	6.394	6.7335	5.9791	5.6584	5.9728
16	7.0165	6.677	6.0271	4.2438	5.104
17	7.0731	7.1862	6.7901	3.638	5.5453
18	7.1296	6.8467	6.6204	6.2986	6.6204
19	6.9599	6.5638	6.677	6.733	6.7901
20	6.1677	5.8848	5.6019	5.8099	5.8848
21	5.3189	4.9794	4.8663	5.0497	5.1492
22	5.036	5.2624	4.4136	4.6153	
23	5.998	5.4321	5.715	5.1532	
24	5.7716	6.5072	5.4887	5.8282	5.2092
Max	9.7891	9.0535	9.5473	8.8838	10.371
Min	5.036	4.9794	4.4136	3.638	3.9758
Avg	7.2239	6.9434	6.5354	6.3614	6.8380

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

KHAMGAON[290] BU 1406

Substation No/ Name :- 077003 / 132 kv Khamgaon s/s

Feeder No / Name : 408 / 33 kv Sajanjuri

Feeder KV- 33 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0257	.0257	.0257	.0309	.0412
2	.0257	.0257	.0257	.036	.0412
3	.0257	.0257	.0309	.036	.0463
4	.0257	.0257	.0309	.036	.0514
5	.0257	.0257	.036	.0412	.0514
6	.0463	.0309	.036	.0412	.0566
7	.0309	.036	.0412	.0463	.0617
8	.0309	.036	.0412	.0514	.072
9	.036	.036	.036	.0463	.072
10	.0463	.0566	.0463	.0463	.036
11		.0669	.0566	.0412	.0412
12	.072	.072	.0566	.0412	.036
13	.072	.072	.0566	.0412	.036
14	.072	.0669	.0566	.0412	.036
15	.0669	.0669	.0514	.0412	.036
16	.0669	.0669	.0514	.0463	.036
17	.0617	.0669	.0309	.0463	.0412
18	.0309	.0309	.0309	.0412	.0309
19	.0309	.0257	.0257	.036	.0309
20	.0257	.0257	.0206	.0309	.0257
21	.0257	.0257	.0206	.0309	.0257
22	.0257	.0206	.0206	.0309	.0206
23	.0257	.0206	.0206	.0412	
24	.0257	.0257	.0206	.0309	.0412
Max	.072	.072	.0566	.0514	.072
Min	.0257	.0206	.0206	.0309	.0206
Avg	.0400	.0407	.0362	.0397	.0421

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074023 / 33 KV LONAR

Feeder No / Name : 201 / 11KV Lonar Water Supply SHEDDABLE URBAN
Feeder Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5525	.4382	.4763	.5716	.4954
2	.5335	.4763	.4763	.5525	.4191
3	.4954	.5335	.4954	.5335	.4572
4	.5335	.5335	.5335	.6097	.5525
5	.5716	.5716	.6097	.743	.8383
6	.743	.8573	.9145	.9335	.9907
7	1.2193	1.1812	1.2955	1.2574	1.2574
8	1.2384	1.0479	1.0288	1.3336	1.1812
9	1.2193	.9145	1.0479	1.2955	1.1431
10	1.1622	.9907	.7811	1.1431	1.0288
11	.9907	.7811	.7049	1.0479	.9907
12	1.0098	.8383	.6668	.9717	.8192
13	.9335	.743	.7621	.9145	.7811
14	.724	.8002	.8383	.8383	.7049
15	.7049	.8192	.7811	.743	.7049
16	.8192	.8002	.8573	.8383	.7811
17	.6478	.8192	.9335	.9145	.9145
18	.9526	1.1431	1.0098	.9907	1.0479
19	.9145	1.0288	.9335	1.1241	.9526
20	.6478	.6478	.8573	.9907	.7049
21	.5906	.743	.7621	.8002	.6859
22	.5335	.6668	.724	.7621	.5144
23	.4191	.5716	.6668	.6478	
24	.6097	.4191	.5335	.5906	.5525
Max	1.2384	1.1812	1.2955	1.3336	1.2574
Min	.4191	.4191	.4763	.5335	.4191
Avg	.7819	.7653	.7788	.8812	.8051

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074023 / 33 KV LONAR

Feeder No / Name : 202 / 11KV Shara AG Feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7625	1.9433	2.0005	1.9052	2.191
2	2.6863	1.9814	2.0576	1.7147	2.0957
3	2.572	1.9243	2.1338	1.6956	1.9814
4	2.2862	2.0957	2.0957	1.6385	1.9624
5	2.4387	2.0576	2.0576	1.4861	2.0576
6	2.572	2.0005	2.0957	1.4289	2.0957
7	2.6673	2.0957	2.0005	1.5242	2.191
8				1.9052	2.3243
9				2.1148	2.4006
10				2.3624	2.191
11				2.6292	2.0957
12				2.6673	2.0767
13				2.572	2.1338
14				2.191	2.1148
15				1.9052	1.9814
16	3.2769	3.7151	3.6199		
17	3.3341	3.1055	3.4675		
18	3.1245	3.2388	3.1436		
19	2.572	2.5339	2.8578		
20	2.4577	2.5339	2.6863		
21	2.553	2.553	2.5149		
22	2.3815	2.4577	2.4387		
23			2.3815		
24	2.4958	1.7337	1.8671	2.2862	2.2862
Max	3.3341	3.7151	3.6199	2.6673	2.4006
Min	2.2862	1.7337	1.8671	1.4289	1.9624
Avg	2.6787	2.3980	2.4637	2.0017	2.1362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074023 / 33 KV LONAR

Feeder No / Name : 203 / 11 KV Hirdav AG Feeder
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	08-DEC-17	09-DEC-17	10-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.4954
2			.4954
3			.5525
4			.5716
5			.9145
6			1.1431
16		.4382	
17	.6478	.6097	
18		1.1431	
19		.9526	
20		.724	
21	.5716	.5906	
22	.5335	.5716	
23	.4763	.5716	
24			.5335
Max	.6478	1.1431	1.1431
Min	.4763	.4382	.4954
Avg	.5573	.7002	.6723

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074023 / 33 KV LONAR

Feeder No / Name : 204 / 11Kv Shara GFSS Feeder
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.4572	.381
2				.4191	.3429
3				.381	.362
4				.3429	.4572
5				.5525	1.1431
6				.9335	1.2003
10	.724	.6287	.6859	.6478	.6478
11	.5906	.3429	.4763	.6097	.5716
12	.4382	.362	.4191	.5716	.4191
13	.4191	.381	.381	.4954	.4191
14	.362	.381	.362	.5335	.381
15	.3429	.4191	.3429	.4001	.381
16				.4572	.4763
17				.5716	.5906
18				.7621	.9526
19				.9907	.9526
20				.8002	.6478
21				.7621	.6097
22			.5525	.5906	.4954
23			.5335	.5525	
24				.4572	.4191
Max	.724	.6287	.6859	.9907	1.2003
Min	.3429	.3429	.3429	.3429	.3429
Avg	.4795	.4191	.4692	.5852	.5925

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074023 / 33 KV LONAR

Feeder No / Name : 205 / 11 kv Pangra AG Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.6766	1.5623	1.6194		
9	1.4289	1.6385	1.7718		
10	1.7147	1.6385	1.8671		
11	1.4289	1.6385	1.7337		
12	1.4289	1.5432			
13	1.448	1.6575	1.7718		
14	1.5242	1.7528	1.7909		
15	1.6194	1.467	1.7147		
16				1.829	1.7909
17				1.9052	1.7528
18				1.8099	1.7147
19				1.7147	1.7147
20				1.8671	1.6194
21				1.8861	1.5813
22				1.848	1.5623
23				1.829	
Max	1.7147	1.7528	1.8671	1.9052	1.7909
Min	1.4289	1.467	1.6194	1.7147	1.5623
Avg	1.5337	1.6123	1.7528	1.8361	1.6766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074023 / 33 KV LONAR

Feeder No / Name : 206 / 11 kv Lonar Bus Stand

SHEDDABLE URBAN

Feeder Feeder KV- 11 /
OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.4763	.4763	.5906	.5335
2	.4954	.4954	.4572	.5716	.4954
3	.5144	.5144	.4572	.5525	.4763
4	.5525	.5716	.5716	.6859	.5335
5	.5716	.8573	.8573	.8764	.6478
6	.8002		1.0098	1.0669	1.1812
7	1.4861	1.467	1.3717		1.5051
8	1.5242	1.4289	1.4098	1.5432	1.467
9	1.4098	1.2574	1.3717	1.3717	1.4098
10	1.2955	1.1812	1.2765	1.2193	1.0669
11	.9907	.9717	1.2003	.9907	1.0479
12	1.1622	.9717	1.1431	.8383	.9145
13	.9907	.9526	.9907	.8002	.8383
14	.9145	.9526	.9526	.8002	.8002
15	.9145	.9907	.8954	.7811	.9335
16	1.0098	1.0288	.9717	.8764	.9717
17	1.1812	1.0479	.9907	.9526	1.0479
18	1.2384	1.2955	1.105	1.1241	1.2574
19	1.2003	1.1622	1.1812	1.2193	1.105
20	1.0098	.9717	1.0669	1.1431	
21	.8002	.8383	.9526	.9907	.724
22	.6859	.6478	.8383	.8002	.6859
23	.5716	.5335	.724	.6097	
24	.5906	.5525	.5144	.6097	.5525
Max	1.5242	1.467	1.4098	1.5432	1.5051
Min	.4954	.4763	.4572	.5525	.4763
Avg	.9352	.9203	.9494	.9137	.9180

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074033 / 33 KV PIMPRI KHANDARE

Feeder No / Name : 201 / BIBI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.4973	.4801	.3772	.3086
2	.3429	.5144	.5144	.3772	.3086
3	.3429	.6687	.6001	.3772	.3086
4	.4115	.8059	.6859	.3772	
5	.583	.8745	.8573	.3772	.583
6	.9259	.9602	1.0288	.6516	.8916
7	1.2346	1.3032	1.2003	.6859	1.2003
8	1.1317	1.2003	1.2346	1.0974	1.0974
9	1.0288	1.0288	.6859	1.0288	1.1317
10		.703	.5144	.823	.8745
11		.5316	.463	.5487	.5658
12		.463	.4115	.4115	.4973
13	.5144	.4115	.3944	.4115	.2915
14	.3086	.3601	.4287	.3086	.3258
15	.3944	.3429	.4801	.3429	.3429
16	.4801	.4458	.5144	.3429	.4801
17	.6344	.6344	.5487	.583	.5658
18	1.0288	1.0117	1.0288	.9602	.9088
19	.9431	.9774	1.1831	.8916	
20	.8745	.583	1.1145	.3772	
21	.7545	.5144	.7716	.4801	
22	.5144	.4115	.4458		
24	.3429	.4973	.4287	.3944	.8402
Max	1.2346	1.3032	1.2346	1.0974	1.2003
Min	.3086	.3429	.3944	.3086	.2915
Avg	.6567	.6844	.6963	.5557	.6401

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074033 / 33 KV PIMPRI KHANDARE

Feeder No / Name : 205 / 11 kv M.Pangra GFSS Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.1029	.1715	.0686	.0686
2	.0686	.1543	.2058		.0686
3	.0686	.2058	.2572	.0686	.0686
4	.2401	.3258	.3429	.0686	.0686
5	.3086	.463	.4801	.0686	.3086
6	.5144	.5487	.583	.0686	.4115
7	.4801		.6859	.2743	.3086
8	.4801	.4973	.6859	.3429	.3429
9	.4973	.4115	.5144	.3086	.3944
10		.2229	.3429	.1715	.3429
11	.2915	.1543	.1715	.0686	.2572
12	.1029	.1029	.12	.0686	.1029
13	.1543	.0857	.12	.0686	.1029
14	.0686	.0686	.1029	.0686	.1029
15	.1029	.1029	.1029	.0686	.1029
16	.4458	.12	.1372	.1372	.2058
17	.7545	.2743	.1715	.2058	.2915
18	.4973	.463	.3429	.4801	.4973
19	.5316	.3944	.5144	.3772	
20	.4973	.2229	.3429	.2401	
21	.3429	.1372	.2572	.1372	
22	.1372	.12	.1029	.1029	
23			.1029		
24	.0686	.1029	.1372	.0857	.0686
Max	.7545	.5487	.6859	.4801	.4973
Min	.0686	.0686	.1029	.0686	.0686
Avg	.3055	.2401	.2915	.1613	.2166

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074033 / 33 KV PIMPRI KHANDARE

Feeder No / Name : 206 / 11 KV BIBI FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171		.0171	.0171	.0171
2	.0171		.0171	.0171	.0171
3	.0171		.0171	.0171	.0171
4	.0171		.0171	.0171	.0171
5	.0171		.0171	.0171	.0171
6	.0171		.0171	.0171	.0171
7	.7545	.5658	.6344	1.0288	.6859
8	1.1317	1.0288		.9088	1.0288
9	1.1145	1.2003	1.0288	1.0288	.9088
10		.8573	.9774	.0857	.9259
11	.7716	.7373	.9431	.5144	.7716
19	.7202	.5658	.6516	.5487	
20	.7202	.5144	.6859	.5144	
21	.6859	.463	.6001	.4801	
22	.5144	.4115	.463	.4115	
23			.0171		
24	.0171		.0171	.0171	.0171
Max	1.1317	1.2003	1.0288	1.0288	1.0288
Min	.0171	.4115	.0171	.0171	.0171
Avg	.4355	.7049	.3826	.3526	.3701

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074049 / 33 KV TITVI SUB STN

Feeder No / Name : 201 / 11 KV PANGRA-TITVI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.4481	.362	1.0642	.9335
2	.4294	.5228	.4763	1.0269	1.0082
3	.5228	.6535	.6478	1.0269	1.0642
4	.5975	.7282	.7621	1.0456	1.1576
5	.6722	.7655	.7811	1.0642	1.1763
6	.7282	.8589	.8764	1.1016	1.1949
7		.2801			
8		.3547			
9		.5335		.6161	
10	.6161	1.2955	.7095	.5041	.6722
11	.5415	.9717	.5788		.5041
12	.5228	1.105	.5228	.4854	.4854
13	.6161	1.1431	.5415	.5228	.4854
14	.5788	1.105	.5415	.5228	.4668
15	1.2696	.5335	.5228	.5415	.5601
16	1.3256	.5716	.5041	.5415	.5601
17	1.3443	.6287	.6348	.6535	.7095
18	1.1389	.7811	.8215	.7468	.8029
19	1.1576	.5716	.7095	.6908	.6722
20	.8029	.5716	.6722	.5601	
21	.7095	.4954	.5601	.4481	
22	.6722	.4191	.3921	.4108	
23	.4481	.362		1.0082	
24	.3734	.4294	.362	1.1389	.9522
Max	1.3443	1.2955	.8764	1.1389	1.1949
Min	.3734	.2801	.362	.4108	.4668
Avg	.7371	.6721	.5989	.7486	.7886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074049 / 33 KV TITVI SUB STN

Feeder No / Name : 204 / 11 KV DHAD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7			.4763		.4108
8	1.0642		.6478		.5228
9	1.0456		.6722		.6161
10	1.0829		.6535		.7842
11	1.0456				.7095
12	1.0642		.7842		.6722
13	1.0269		.7655		.7095
14	.8962		.7468		.5975
15		1.1622		1.0082	
16		1.1622		.8029	
17		1.0098		.8029	
18		.7049		.6535	
19		.6097		.5601	
20		.6097		.5228	
21		.5525		.4668	
22		.5525		.4294	
Max	1.0829	1.1622	.7842	1.0082	.7842
Min	.8962	.5525	.4763	.4294	.4108
Avg	1.0322	.7954	.6780	.6558	.6278

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074049 / 33 KV TITVI SUB STN

Feeder No / Name : 205 / 11 KV GOTHRA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7282	.7621		
2		.7095	.724		
3		.6535	.6859		
4		.6535	.5716		
5		.5601	.5144		
6		.5975	.4954		
7				.6161	
8				.7468	
9				.8215	
10				.9149	
11			.7468	.8589	
12			.7842	.8402	
13				.8589	
14				.7655	
15			1.1016		1.4563
16			.9149		1.419
17			1.0269		1.1389
18			.8962		.8775
19			.7655		.7282
20			.7468		
21			.7095		
22			.6161		
23	.7655	.8383			
24		.7282	.8383		
Max	.7655	.8383	1.1016	.9149	1.4563
Min	.7655	.5601	.4954	.6161	.7282
Avg	.7655	.6836	.7588	.8029	1.1240

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074049 / 33 KV TITVI SUB STN

Feeder No / Name : 206 / 11 KV PANGRA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.2801	.2286	.2241	.2427
2	.3547	.3361	.2477	.2614	.3174
3	.3734	.3734	.2667	.2987	.3547
4	.3921	.3734	.3048	.3734	.3921
5	.4294	.3921	.3429	.4108	.4294
6	.4668	.4294	.4001	.4481	.4481
10	.3734	.2477	.3174	.2987	.2054
11	.3174	.2858	.2801	.2427	.1494
12	.2987	.2858	.2614	.2241	.1307
13	.3361	.2477	.2427	.0934	.1307
14	.2987	.2858	.2427	.112	.112
15	.3174	.2858	.2614	.1097	.1307
16	.3361	.2858	.2801	.1494	.1307
17	.3921	.362	.2801	.2054	
18	.4294	.4191	.3361	.2801	.3174
19	.3734	.3429	.3174	.3174	.2987
20	.3174	.3239	.2987	.2427	
21	.3174	.2477	.2614	.2614	
22	.2801	.2477	.2241	.2241	
23	.2427	.2096		.2241	
24	.3361	.2427	.2096	.2054	.2054
Max	.4668	.4294	.4001	.4481	.4481
Min	.2427	.2096	.2096	.0934	.112
Avg	.3485	.3097	.2802	.2480	.2497

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074050 / 33/11 KV SULTANPUR SS

Feeder No / Name : 201 / 11 KV Chincholi AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.905	.0857	.0514	.0572
2	1.0288	.9526	.0857	.0514	.0572
3	1.0288	.9335	.0857	.0514	.0572
4	1.0288	.9907			
5	1.1145	.9907			
6	1.286	.9907			
7	1.286	1.0631			
8				1.1431	1.086
9				1.1431	1.2193
10				1.2384	1.2384
11				1.2955	1.3717
12				1.3908	1.4289
13				1.3336	1.267
14				1.4289	1.2955
15				1.1431	1.3336
16		2.2291	1.8861		
17		1.8176	1.6289		
18	.0572	1.5089	1.286	.0762	.0572
19		.9602	1.0288	.0572	
20	.0762	.9431	.8573	.0572	.0732
21	.0754	.8916	.7716	.0572	.0754
22	.0543	.7888	.6859	.0572	.0732
23	.0732	.6859	.6001	.0572	.0953
24	1.0802	1.0974	.0686	.0514	
Max	1.286	2.2291	1.8861	1.4289	1.4289
Min	.0543	.6859	.0686	.0514	.0572
Avg	.7091	1.1093	.7559	.5936	.6741

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074050 / 33/11 KV SULTANPUR SS

Feeder No / Name : 204 / 11kv ChincholiBore GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5335	.4801	.4458	.4763
2	.5144	.5525	.4801	.4287	.4954
3	.5144		.5487	.4287	.5335
4	.6859	.6097	.583	.5144	.724
5	1.0288	1.0288	.9431	.8573	1.105
6	1.4575	1.3336	1.286	1.0288	1.5051
7	1.6289	1.406	1.5775	1.0288	1.829
8	1.4575	1.0288	1.3717	.9526	1.467
9	1.2346	1.2346	1.166	.8573	1.3908
10	.9602	.9602	.9945	1.1431	1.105
11	.8764	.7888	.7716	.7049	.8002
12	1.1812	.7202	.463	.5906	.6668
13	.6859	.6687	.463	.4954	.6859
14	.6097	.6173	.463	.4954	.6478
15	.6287	.5658	.4801	.5144	.6859
16	.724	.7202	.6344	.5716	.7621
17	.9145	.9431	.8573	.8383	.9526
18		1.0631	1.2003	1.2574	1.1622
19		1.3032	1.1145	1.1241	
20	.7621	.9431	1.0288	.9145	1.105
21	.6097	.7202	.6516	.6859	.8002
22	.5716	.5658	.5144	.5525	.7621
23	.5335	.4801	.463	.5144	.5716
24	.5144	.5335	.463	.4458	.4763
Max	1.6289	1.406	1.5775	1.2574	1.829
Min	.5144	.4801	.463	.4287	.4763
Avg	.8458	.8400	.7916	.7246	.9004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074050 / 33/11 KV SULTANPUR SS

Feeder No / Name : 207 / DAM AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4115	.3429	
2		.4115	.3429	
3		.3772	.3429	
4		.3429		
5		.3772		
6		.3258		
7		.3429		
8	.2572			
9	.3429			
10	.3429			
11	.3429			
12	.362			
13	.333			
14	.3429			
15	.3077			
16			.5906	.4763
17			.7049	.543
18			.6097	.3982
19			.5525	
20			.5335	.2743
21			.4763	.2667
22			.4572	.2378
23			.4191	.2286
24		.4115	.3429	
Max	.362	.4115	.7049	.543
Min	.2572	.3258	.3429	.2286
Avg	.3289	.3751	.4763	.3464

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074050 / 33/11 KV SULTANPUR SS

Feeder No / Name : 208 / 11 KV BORKHEDI DHARAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2667	.2401	.2572	.3429
2	.3429	.2477	.2743	.2572	.381
3	.3429	.2667		.2572	.4572
4	.3772	.3048	.4801	.4287	.5335
5	.6001	.5335	.703	.6001	.6859
6	.7716	.7621	.8573	.7716	.8383
7	.7716	.6687	.7545	.7716	1.086
8	.6859	.6859	.7888	.7621	.9526
9	.6001	.5487	.6001	.6668	.6859
10	.4287	.5144	.4458	.4763	.6036
11	.2896	.4115	.2915	.4001	.2667
12	.2286	.4115	.2572	.3429	.2286
13	.2286	.3772	.2572	.362	.2477
14	.2286	.3429	.2572	.362	.2477
15	.2477	.3772	.2572	.381	.2667
16	.2667	.4115	.2572	.3429	.3429
17		.5144	.3429	.4572	.4763
18		.5487	.5144	.9335	.6097
19		.583	.6001	.9145	
20	.4954	.5144	.5144	.6478	.5335
21	.4572	.4115	.3772	.5335	.4954
22	.3048	.3429	.3429	.4572	.362
23	.2667	.3086	.2915	.4001	.2667
24	.3429	.2667	.2743	.2572	.3429
Max	.7716	.7621	.8573	.9335	1.086
Min	.2286	.2477	.2401	.2572	.2286
Avg	.4105	.4426	.4339	.5017	.4893

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074053 / 33/11KV HIRDAV

Feeder No / Name : 205 / GAYKHED GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	.5144	.4382	.381	.5335
2	.362	.5716	.5144	.4572	.5716
3	.362	.7049	.6097	.5716	.6859
4	.6859	1.2384	.7621	.9145	.8954
5	1.1241	1.2955	.9335	1.0288	1.1241
6	1.4861	1.3336	1.0669	1.4861	1.4861
7	1.7147	1.448	1.2384	1.2193	1.7528
8	1.5051	1.4098	1.3336	1.2384	
9	1.3336	1.2955	1.2384	1.2384	1.4289
10	.8764	.9335	.9335	.8002	.9907
11	.5335	.5716	.724	.6287	.5716
12	.4763	.4382	.5525	.6478	.5716
13	.4191	.4572	.4763	.381	.5144
14	.4001	.5144	.4572	.4001	.4763
15	.4382	.5716	.4572	.4191	.4382
16	.5525	.6287	.4763	.5906	.5335
17	.9907	.7621	.5144	.743	
18	1.3336	.9907	.743	.9335	1.0288
19	1.1812	.9526	.743	1.1241	1.1622
20	1.1431	.8573	1.086	.9907	1.086
21	1.0669	.7621	.8764	.8764	.9145
22	.7049	.5716	.6478	.6478	.6859
23	.4763	.4191	.381	.5716	.381
24	.4191	.4954	.381	.3429	.4954
Max	1.7147	1.448	1.3336	1.4861	1.7528
Min	.362	.4191	.381	.3429	.381
Avg	.8327	.8224	.7327	.7764	.8331

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074053 / 33/11KV HIRDAV

Feeder No / Name : 206 / 11 KV DABHA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.3429	.724		
2	.4572	.6859	.7621		
3	.5716	.7621	.9526		
4	.6287	.7049	1.0669		
5	.7049	.9145	1.1431		
6	.9145	1.0669	1.1812		
7	.9907	.9526	.7621		
8				.7621	.6478
9				.9145	1.105
10				.9145	.9526
11				.9526	.9907
12				1.086	.9907
13				1.2193	.8764
14				1.086	.8764
15				.9145	.8764
16			1.4098		
17			1.4098		
18			1.2955		
19			1.2955		
20			1.0288		
21			.6478		
22			.6478		
23			.6097		
24	.3429	.381	.6859		
Max	.9907	1.0669	1.4098	1.2193	1.105
Min	.3429	.3429	.6097	.7621	.6478
Avg	.6287	.7264	.9764	.9812	.9145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074067 / 33 kv Kingaon Jattu ss

Feeder No / Name : 201 / 11 KV Kingaon Jattu Gfss

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953	.0953	.0953
2	.1143	.1143	.0953	.0953	.0953
3	.1524	.1143	.0953	.0953	.0953
4	.1715	.1334	.1905	.1334	.1143
5	.1905	.2286	.2286	.2096	.1905
6	.3048		.2477	.2667	.2667
10	.2096	.2286	.2096	.2286	
11	.1143	.1524	.1334	.1524	
12	.1334	.1143	.0953	.1143	
13	.1334	.1143	.0953	.1334	
14	.1524	.1334	.0953	.1524	
15	.1334	.0762	.0953	.0953	
16	.1524	.1524	.1524	.1524	
17	.1905	.1905	.1143	.1334	
18	.3048	.1905	.2286	.2667	
19	.2667	.2096	.1715	.2096	
20	.2477	.1334	.1334	.1524	
21	.2286	.1143	.1143	.1334	
22	.1905	.1143	.1143	.1143	
23	.0762	.0953	.0953	.1143	
24	.0762	.0762	.0953	.0953	.0953
Max	.3048	.2286	.2477	.2667	.2667
Min	.0762	.0762	.0953	.0953	.0953
Avg	.1733	.1391	.1379	.1497	.1361

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074067 / 33 kv Kingaon Jattu ss

Feeder No / Name : 202 / 11 kv Bhumrala feeder

SHEDDABLE RURAL

(Mix) Feeder KV- 11 /
OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6859	.724	.7049	.5716
2	.724	.724	.724	.7049	.5716
3	.8954	.7049	.724	.6859	.5716
4	.8764	.724	.724	.724	.6097
5	.9145	.7621	.8573	.743	.6859
6	.8954	.8764	.8573	.7621	.7811
10		1.3146		1.2003	
11		1.3146		1.086	
12		1.3336		1.3336	
13				1.4098	
14		1.2003		1.1622	
15	1.2955		1.5432		
16	1.2765		1.4289		
17	1.3146		1.3527		
18	1.3336		1.3336		
19	1.2955	1.2003	1.2574	1.2384	
20	1.2765	1.1431	.9907	1.1431	
21	1.0098	1.086	.8764	1.0669	
22	1.0288	.9526	.8002	.8573	
23	.9145	.8573	.743	.7811	
24	.7621	.7049	.7621	.7049	.5906
Max	1.3336	1.3336	1.5432	1.4098	.7811
Min	.6859	.6859	.724	.6859	.5716
Avg	1.0312	.9740	.9812	.9593	.6260

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074067 / 33 kv Kingaon Jattu ss

Feeder No / Name : 203 / 11 KV Kingaon Jattu AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.3239	.1905	.2667	.2286
2	.4954	.3048	.1905	.2667	.2286
3	.2286	.3239	.1905	.2667	.2286
4	.2096	.3429	.1905	.2858	.2477
5	.2477	.3429	.2286	.3048	.2667
6	.2477	.3429	.2858	.3239	.2858
10	1.2765		.8764		
11	1.2765		.8573		
12			1.0669		
13	.9526		1.0669		
14	.9145		.7621		
15		1.3336		1.1812	
16		1.3336		1.2765	
17		1.1622		1.0098	
18		.7811		.7811	
19	.7621	.5525	.6859	.5525	
20	.724	.4763	.5716	.4382	
21	.381	.381	.4954	.4001	
22	.3429	.3239	.3429	.3429	
23	.3239	.2477	.3048	.3429	
24	.2477	.3429	.2477	.2858	.2286
Max	1.2765	1.3336	1.0669	1.2765	.2858
Min	.2096	.2477	.1905	.2667	.2286
Avg	.5537	.5573	.5032	.5204	.2449

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074088 / 33 KV Deulgaon Kundpal

Feeder No / Name : 201 / 11 kv Deulgaon AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.3889	1.5089
2				1.3546	1.4586
3				1.3546	1.4419
4				1.3757	1.4922
5				1.5238	1.3916
6				1.4582	1.326
7	2.1719	1.9814			
8	2.2291	1.9433			
9	2.2862	2.2291			
10	2.3624	2.3053			
11	2.3815	2.0081			
12	2.4196	1.9685			
13	2.1529	1.8724			
14	1.8099	1.749			
23			1.4251	1.4918	
24				1.4754	1.5424
Max	2.4196	2.3053	1.4251	1.5238	1.5424
Min	1.8099	1.749	1.4251	1.3546	1.326
Avg	2.2267	2.0071	1.4251	1.4279	1.4517

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074088 / 33 KV Deulgaon Kundpal

Feeder No / Name : 202 / 11 KV AJISPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2672	2.21	1.491		
2	2.1719	2.1719	1.4582		
3	2.1338	2.1338	1.3927		
4	2.0386	1.9814	1.4419		
5	1.9433	2.0767	1.5893		
6	1.9052	1.9814	1.6356		
7			1.668	1.7368	1.5592
8			1.7204	1.8515	1.873
9			1.9989	2.0119	
10			1.9826	2.0553	
11			1.9498	1.9826	2.0553
12			1.8515	1.8679	
13			1.8442	1.9448	
14			1.7604	1.6766	
23	1.9814	1.5223			
24	2.3624	2.1719	1.5729		
Max	2.3624	2.21	1.9989	2.0553	2.0553
Min	1.9052	1.5223	1.3927	1.6766	1.5592
Avg	2.1005	2.0312	1.6905	1.8909	1.8292

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

LONAR S/DN.[551] BU 4551

Substation No/ Name :- 074088 / 33 KV Deulgaon Kundpal

Feeder No / Name : 203 / 11 KV DEULGAON GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.3439	.3584	.3361
2	.4001		.3439	.3584	.3361
3	.4382	.4001	.362	.3395	.3547
4	.5525	.6478	.7059	.7922	.7947
5	1.2193	1.2193	1.1765	1.2254	1.2382
6	1.3336	1.2955	1.2489	1.2437	1.1643
10	.4763	.8002	.7207	.8316	.7842
11	.4382	.4207	.499	.4668	.5228
12	.4191	.3506	.3734	.3326	
13	.4001	.298	.3547	.3142	
14	.381	.2804	.3547	.3142	
15	.362	.298	.3734	.3696	
16	.5525	.3721	.4108	.4805	
17	.7049	.6733	.4904		
18	.8764	.8682	.9896	.5975	
19	.9907	.7973	.8865	.8775	
20	.7811	.5316	.5847	.6722	
21	.6478	.4784	.5093	.5415	
22	.4763	.3898	.3961	.3921	
23	.4191	.3721	.3772	.3547	
24	.4001	.381	.362	.3584	.3547
Max	1.3336	1.2955	1.2489	1.2437	1.2382
Min	.362	.2804	.3439	.3142	.3361
Avg	.6024	.5628	.5649	.5611	.6540

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074011 / 33/11 KV DONGAON

Feeder No / Name : 201 / 11 KV DONGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.3146
2				1.2955
3				1.3336
4				1.3908
5				1.4098
6				1.3527
7				1.3717
8				1.3336
9				1.2765
10	1.4083	1.2883	1.0974	
11	1.8473	2.2361	1.6095	
12	2.0302	2.0957	1.6827	
13	2.0302	2.4006	1.6461	
14	1.7558	1.6956	1.6095	
15	1.6827	1.6385	1.5729	
16		1.5813	1.4815	
17	1.5181	1.6956	1.4266	
24				1.2384
Max	2.0302	2.4006	1.6827	1.4098
Min	1.4083	1.2883	1.0974	1.2384
Avg	1.7532	1.8290	1.5158	1.3317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074011 / 33/11 KV DONGAON

Feeder No / Name : 202 / 11 KV PANGARKHED AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	08-DEC-17
HR	Load (MW)
8	2.3266
Max	2.3266
Min	2.3266
Avg	2.3266

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074011 / 33/11 KV DONGAON

Feeder No / Name : 204 / 11 KV DONGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8775	.7964	.8192	.8215	.8002
2	.8589	.823	.8954	.8402	.8573
3	.8775	.8962	1.0288	.8589	.8954
4	1.3443	1.3352	1.448	1.4563	1.105
5	1.643	1.6278	1.6766	1.7177	1.2384
6	1.9605	2.0119	2.2291	1.9605	1.9433
7	2.3525	2.2262	2.4006	2.4646	2.3434
8	1.9044	2.0485	2.1719	1.8298	2.21
9	1.8298	1.5181	2.0005	1.8298	1.9433
10	1.6461	1.39	1.9044	1.7147	1.363
11	1.1946		1.643	1.448	1.2696
12	1.1706	1.1128	1.307	1.2384	1.1203
13		1.0288	1.1576	1.0098	1.0082
14	1.0425	1.0098	1.0082	.9145	.9522
15	.9694	.9717	1.1203	1.086	.9709
16	.9877	1.0669	1.1949	1.3336	1.2696
17	1.1584	1.2384	1.4563	1.3908	1.4937
18	1.7013	1.848	1.7924	1.848	1.7924
19	1.6289	1.8107	1.6804	1.5813	1.6804
20	1.4266	1.448	1.4563		1.419
21	1.1222	1.2765	1.0829	1.3908	1.1949
22	.9979	1.2003	.9709	.9145	1.0829
23	.9231	.8764	.823	.8573	.9709
24	.9335	.8326	.8573	.7716	.8192
Max	2.3525	2.2262	2.4006	2.4646	2.3434
Min	.8589	.7964	.8192	.7716	.8002
Avg	1.3283	1.3215	1.4219	1.3599	1.3226

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074011 / 33/11 KV DONGAON

Feeder No / Name : 205 / 11 KV PANGARKHED GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)
1	.5658	.5281
2	.5281	.5093
3	.5658	
4	.9054	
5	1.094	
6	1.3769	
7	1.3203	
8	1.2449	
9	.9431	
10	.8686	
11	.7947	
12	.6805	
13	.5914	
14	.5359	
24	.6036	.5658
Max	1.3769	.5658
Min	.5281	.5093
Avg	.8413	.5344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074016 / 33KV HIVARA ASHRAM

Feeder No / Name : 201 / 11KV Deulgaon Mali AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4086	2.1628	2.17		
2	2.4086	2.13			
3	2.2939	2.1879	2.17		
4	2.1956	2.1548	2.17		
5	2.13	2.1548	2.17		
6		2.13	2.2211		
7		2.1548	2.1548		
8		2.146	2.2708		
9		2.0222	2.2708		
10				2.3205	2.5526
11				2.7846	3.152
12				2.8509	3.0178
13				2.6825	2.8178
14				2.7328	2.7349
15				2.7161	2.7846
16				2.7161	2.7183
17				2.4059	2.6871
24	2.4249	2.1628	2.1628		
Max	2.4249	2.1879	2.2708	2.8509	3.152
Min	2.13	2.0222	2.1548	2.3205	2.5526
Avg	2.3103	2.1406	2.1956	2.6512	2.8081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074016 / 33KV HIVARA ASHRAM

Feeder No / Name : 202 / 11 KV LAWALA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.9755	.5944
2				.9755	.5944
3				.9602	.6019
4				.9722	.6097
5				.9686	.6327
6				.9842	.6642
8				1.1012	.7655
9				1.166	.7562
10	1.5729	1.4575	1.4899		
11	1.873	1.7368	1.8023		
12	1.7901		1.8623		
13	1.9006	1.8947	1.8785		
14	1.989	1.9433	1.8461		
15	1.8679	1.9433			
16	1.8842	1.8947	1.7814		
17	1.8842	1.7814	1.6484		
24					.5792
Max	1.989	1.9433	1.8785	1.166	.7655
Min	1.5729	1.4575	1.4899	.9602	.5792
Avg	1.8452	1.8074	1.7584	1.0129	.6442

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074016 / 33KV HIVARA ASHRAM

Feeder No / Name : 203 / 11 KV PENTAKALI EXPRESS NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1109	.2614	.2452	.2286	.2641
2	.1086	.2587	.2452	.2286	.2641
3	.1086	.2587	.2452	.2286	.2641
4	.1086	.2987	.2452	.2286	.2829
5	.4668	.4668	.2427	.2286	.2829
6	.4854	.5359	.5601	.4108	.5281
7	.5093	.5281	.5658	.4904	
8	.5041	.5228		.5041	.4904
9	.5175	.5228	.5658	.2667	.4805
10	.5544	.5175	.5228	.5281	.5093
11		.5415	.4854	.5281	.5228
12	.5415	.5415	.4854	.5281	.5228
13	.5228	.5415	.4854	.5281	.5041
14	.5228	.5228	.0934	.4904	.1509
15	.4668	.5228	.0934	.4854	.1509
16	.4854	.5281	.1905	.2263	.3018
17	.4854	.5228	.1905	.5228	.3018
18	.462	.4854	.2096	.2561	.5228
19		.4854	.4294	.4435	.4938
20	.462	.2263	.3734	.4435	.4887
21	.462	.2241	.4108	.4572	.4887
22	.2378	.2241	.2054	.2614	.2743
23	.2427	.2241	.2054	.2452	.2987
24	.112	.2641	.2452		.2641
Max	.5544	.5415	.5658	.5281	.5281
Min	.1086	.2241	.0934	.2263	.1509
Avg	.3853	.4177	.3279	.3808	.3762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074016 / 33KV HIVARA ASHRAM

Feeder No / Name : 204 / 11 KV LAVALA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3174	.3511	.3018	.2987	.2957
2	.3174	.3361	.3018	.2801	.2957
3	.3361	.3326	.3018	.2801	.2957
4	.3734	.3361	.3206	.3584	.6348
5	.6099	.6535	.5658	.6036	.6348
6	.8962	.9431	.9431	.8402	.9522
7	1.0269	1.1317	1.0751	1.0642	
8	1.1949	.8589		.9795	.9335
9	.9709	.8215	.9619	1.0082	.8589
10	.6161	.6468	.8402	.7468	.6348
11	.4066	.5068	.4938	.5975	.4668
12	.3898	.3982	.4163	.5975	.3109
13	.4161	.3258	.3544	.2926	.3403
14	.3898	.3366	.3366		.2835
15	.4656	.333	.3366	.3292	.394
16	.4706	.5083	.3582		.4344
17	.724	.5611	.5068	.7392	.6099
18	.9511	.9328	.7316	.9709	.8686
19		.8316	.7762	.8029	.7762
20	.5792	.5853	.5544	.5975	.6219
21	.4572	.4572	.4066	.4938	.4938
22	.3982	.3841	.3326	.439	.3881
23	.362	.3696	.2957	.3475	.3326
24	.3174	.3292	.3018		.3326
Max	1.1949	1.1317	1.0751	1.0642	.9522
Min	.3174	.3258	.2957	.2801	.2835
Avg	.5646	.5530	.5136	.6032	.5300

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074020 / 33/11 KV JANEFAL

Feeder No / Name : 204 / 11 KV DEULGAON SAKARSHA GAOTHAN FEEDER
GAOTHA Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4024	.4938		.3658
2		.439	.4938		.3658
3		.4024	.5304		.4024
4		.439	.6584		.439
5		.5853	.7682		.5853
6		.9145	.8779	.8048	.8048
7	.9145	.9877	.9694	1.0242	1.0608
8	.7621	.9511	1.0608		1.0242
9	.7621		.9145	1.0608	.8779
10		.8048	.8596	.8048	.695
11	.6584	.7316	.5853		
12	.5853	.6219	.5853		
13	.6584	.5853	.4755		
14	.6584	.6219	.5121	.6219	.6584
15	.695	.6401	.5853	.5853	.6219
16	.695	.6219	.5853		.5853
17	.7316	.7499	.7316	.7316	.6584
18	.9511	.9694	.9877	.8413	.8596
19	.8413	.9511	.9145	.9145	.9511
20	.6584	.8779	.6584	.7682	.8413
21		.6219		.5853	.6584
22		.5487		.5121	.5853
23		.4755			.4755
24	.381	.439	.4572	.4024	.3658
Max	.9511	.9877	1.0608	1.0608	1.0608
Min	.381	.4024	.4572	.4024	.3658
Avg	.7109	.6688	.7002	.7429	.6610

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074020 / 33/11 KV JANEFAL

Feeder No / Name : 206 / 11 KV HIWARA KD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4024	.4024		.3658
2		.3658	.4207		.3292
3		.4024	.4207		.3658
4		.439	.4755		.4024
5		.6219	.5853		.5853
6		.9511	.823	.8048	.8779
7	1.0669	1.0974	.8962	1.0974	1.0974
8	.9145	1.0242	.8596		1.0974
9	.9907		.7316	.9511	1.0242
10		.7316	.5853	.7316	.7682
11	.6584	.5487	.6584		
12	.5121	.4938	.5121		
13	.5487	.4755	.439		
14	.5121	.4938	.4755	.5121	.5304
15	.5487	.4755	.5121	.5601	.5121
16	.5487	.5121	.5121		.5121
17	.7316	.695		.7682	.5853
18	.9145	.8962	.8048	.9145	
19	.9145	.8779	.8413	.8779	.8596
20	.695	.7316	.6584	.7316	.7682
21		.5853		.5853	.567
22		.4572		.4755	.5121
23		.4207			.4207
24	.381	.4024	.4024	.3658	.3658
Max	1.0669	1.0974	.8962	1.0974	1.0974
Min	.381	.3658	.4024	.3658	.3292
Avg	.7098	.6131	.6008	.7212	.6273

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074045 / 33/11 KV LONIGAWALI

Feeder No / Name : 203 / 11 KV BHIWAPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	1.2483	1.5604	.8669	.9709
11	1.595	1.7337	1.3176	1.2136
12	1.7684	1.8724	1.5257	1.4563
13	1.9071	1.8724	1.7337	1.5604
14	2.0805	1.7337	1.595	1.387
15	1.7337	1.6991	1.4563	1.387
16	1.8031	1.5604	1.387	1.387
17	1.4217	1.2136	1.2483	1.387
Max	2.0805	1.8724	1.7337	1.5604
Min	1.2483	1.2136	.8669	.9709
Avg	1.6947	1.6557	1.3913	1.3437

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074045 / 33/11 KV LONIGAWALI

Feeder No / Name : 206 / 11 KV GHATBORI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5201	1.3003	.5548	.4854
2	.4854	1.2136	.5201	.5201
3	.5201	1.1269	.5548	.5548
4	.6068	1.0402	.6068	.6588
5	.7802	1.2136	.6935	.6935
6	.8669	1.387	.9015	.8669
7	1.0402	1.7337	1.0749	1.0402
8	1.0056	1.387	1.2136	1.1269
9	.8669	1.2483	1.2483	1.1789
10	.6935	1.1789	1.1096	1.2136
11	.5548	1.1096	1.1096	1.1443
12	1.387	1.0402	1.1096	1.0402
13	1.387	1.1096	1.0402	.9709
14	1.387	1.0402	1.0056	.8322
15	1.2136	1.0749	.9709	.8669
16	.8669	1.0402	1.1789	.9709
17	1.2136	1.0749	1.1096	1.2136
18	1.1789	1.0749	1.2136	1.0402
19	1.2136	1.0402	1.0402	.8669
20	1.387	.8669	.8669	.8322
21	1.4737	.8322	.6935	
22	1.387	.6935	.5201	
23	1.387	.6068	.5201	
24	.5201	1.387	.6068	.5201
Max	1.4737	1.7337	1.2483	1.2136
Min	.4854	.6068	.5201	.4854
Avg	.9976	1.1175	.8943	.8875

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074062 / 33/11 KV DEULGAON MALI

Feeder No / Name : 201 / 11 KV NAGZARI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	10-DEC-17
HR	Load (MW)	Load (MW)
9	1.8461	
10	1.9547	
12		1.6118
13		1.6118
14		1.5364
15		1.5203
16		1.4685
18		1.3575
19		1.182
20		1.1283
21		1.0745
22		.9671
23		.8145
Max	1.9547	1.6118
Min	1.8461	.8145
Avg	1.9004	1.2975

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074062 / 33/11 KV DEULGAON MALI

Feeder No / Name : 202 / 11 KV NAGZARI GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.2241	.2263	.1829	.1867
2	.2263	.2054	.2263	.1829	.168
3	.2378	.2427	.2075	.1829	.2241
4	.2926	.3734	.3361	.2926	.2427
5	.3658	.4108	.4481	.3658	.2614
6	.6401	.6767	.4668	.6767	.5415
7	.7316	.6401	.5228	.6584	.7499
8	.7316	.6219	.5601	.695	.6219
9	.6036	.4108			
10	.3841	.3547		.4938	.5228
11	.2427	.3361	.2926	.3174	.4108
12	.2241	.3174	.2926	.1494	.3174
13	.1867	.2054	.2926		.1867
14	.1867	.1867	.2926		
15		.2801	.2378		
16		.2427	.2926	.1867	
17		.3921	.4024	.3174	
18		.5788	.6401	.5228	
19		.4108	.4572	.5041	
20	.3921	.3361	.4024	.3174	
21	.3361		.3109	.2614	
22	.2987	.2614	.2378	.2241	
23	.2987	.2614	.2195	.1867	
24	.2561	.2614	.2263	.2195	.1867
Max	.7316	.6767	.6401	.695	.7499
Min	.1867	.1867	.2075	.1494	.168
Avg	.3608	.3579	.3451	.3469	.3554

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074062 / 33/11 KV DEULGAON MALI

Feeder No / Name : 203 / 11 KV WARUDI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-DEC-17	10-DEC-17	11-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2743		.3109
2	.2743		.3109
3	.3109		.3109
4	.3658		.3658
5	.4024		.4024
6	.7499		.9694
7	.9145		.9877
8	.8962		.9328
9	.8779		.8779
10	.6401		.6401
11		.4938	
12		.3658	
13		.3658	
14		.3658	
15		.4755	
16		.4572	
17		1.3032	
18		.7316	
19		.6401	
20		.5487	
21		.4572	
22		.3658	
23		.3292	
24	.2926		.3292
Max	.9145	1.3032	.9877
Min	.2743	.3292	.3109
Avg	.5454	.5307	.5853

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074062 / 33/11 KV DEULGAON MALI

Feeder No / Name : 204 / 11 KV WARUDI AG

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8688	.823	.9431	.8596	
2	.8145	.823	.9431	.8596	
3	.8145	.823	.9431	.9134	
4	.8145	.8745	.9709	.8059	
5	.7602	.9259	.9709	.8059	
6	.7602	.9259	.9522	.8596	
7				.8059	
8				.8775	
9				1.0745	
10				1.182	.823
11				1.1145	
12				1.1317	1.251
13				1.0802	1.4003
14				1.0288	
15				.8745	
16				.7716	
17				.7202	
23	.9259		.9335		
24	.8688	.9259	.9808	.8059	
Max	.9259	.9259	.9808	1.182	1.4003
Min	.7602	.823	.9335	.7202	.823
Avg	.8284	.8745	.9547	.9206	1.1581

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074070 / 33 KV UKALI

Feeder No / Name : 202 / 11 KV BORI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6194	1.5242	1.576	1.8023	1.906
2	1.6194	1.5089	1.576	1.7814	1.9997
3	1.6194	1.4937	1.4327	1.7604	2.0309
4	1.5565	1.4632	1.2407	1.9204	1.9997
5	1.4746	1.4632	1.1843	2.1052	2.0309
6			1.1203	2.0805	2.0309
7			1.2209	2.0805	2.0466
8			1.1043	2.0805	1.7029
9			1.2071	2.0243	1.7654
10	2.0005	1.9814	1.3413	1.4413	1.406
11	2.2862	2.4006	1.6194	1.6461	1.7101
12	2.3472	2.3685	1.6194	1.5394	1.8107
13	2.3015	2.4006	1.3108	1.6461	1.7436
14	2.2862	2.5484	1.1469	1.5851	1.7772
15	2.2862	2.4646	1.1736	1.6309	1.6804
16	2.2253	2.8117	1.2717	1.4937	1.6484
17	2.1491	2.3807	1.3565	1.4784	1.6766
22	1.6004	1.643			
23	1.5242	1.5364			
24	1.6194	1.4937	1.7909	1.6194	1.7985
Max	2.3472	2.8117	1.7909	2.1052	2.0466
Min	1.4746	1.4632	1.1043	1.4413	1.406
Avg	1.9072	1.9677	1.3496	1.7620	1.8203

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074070 / 33 KV UKALI

Feeder No / Name : 203 / 11 KV UKALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.543	.6602	.6154	.6335	.6602
2	.543	.6602	.6805	.543	.3772
3	.543	.7167	.724	.543	.6602
4	1.0631	1.4146	.7343	.905	.9054
5	1.2269	1.848	1.6651	1.4899	1.1128
6	1.6289	1.9774	1.7551	1.6289	1.2826
7	1.7147	1.9404	1.5043	1.9669	1.8484
8	1.6956	1.6632	1.7551	1.7147	1.9616
9	1.5432	1.4335	1.4327	1.7147	1.6409
10	1.2403	1.1694	1.2894	1.2269	1.1317
11	.7922	.9134			.9671
12	.6979	.6089			.5601
13	.7545		.6335	.8488	.6089
14	.7545	.5596	.6335	.6979	.5731
15	.7356	.5373	.6335	.7545	.6089
16	.9997	.6089	.905	.9054	.7964
17	1.2071	.5373	1.1393	1.1317	1.4022
18	1.6244	1.5203	1.5432	1.5893	1.7193
19	1.4003	1.3611	1.6289	1.6975	1.4685
20	1.2826	1.4327	1.4737	1.1317	.8417
21	.9808	.8596	1.0517	.7922	.8596
22	.8488	.7522	.8954		.8775
23	.7356	.7164	.724	.679	
24	.543	.7356	.6805	.6335	.6224
Max	1.7147	1.9774	1.7551	1.9669	1.9616
Min	.543	.5373	.6154	.543	.3772
Avg	1.0458	1.0707	1.0954	1.1061	1.0212

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074070 / 33 KV UKALI

Feeder No / Name : 204 / 11 KV EXPRESS FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.1509	.1075	.0934	.1334
2	.181	.1509	.1254	.0934	.1334
3	.181	.1509	.1791	.0934	.1334
4	.181	.1509	.197	.0934	.1334
5	.181	.1143	.1509	.0934	.1143
6	.1267	.1143	.1494	.0934	.1143
7	.0924	.0953	.1612	.0934	.1143
8	.181	.0953	.1254	.1294	.1143
9	.181	.1143	.1494	.1294	.1143
10	.2172	.1509	.1494	.1294	.1143
11	.2452	.1254	.1294	.1509	.1006
12	.1886	.1433	.1294	.1698	.1494
13	.132	.1075	.1294	.1143	.112
14	.1132	.0905	.1294	.1509	.0934
15	.1132	.1075	.1294	.1509	.0671
16	.1143	.0905	.0924	.1698	.0747
17	.1143	.1433	.0924	.1698	.0895
18	.0953	.2149	.0924	.1698	.0716
19	.0953	.1494	.1294	.1334	.0934
20	.1143	.1612	.1294	.1334	.0716
21	.0953	.2126	.0934	.1334	.0934
22	.1334	.1867	.0934	.1143	.1075
23	.1524	.1494	.1307	.1143	
24	.1294	.1509	.1509	.1294	.1143
Max	.2452	.2149	.197	.1698	.1494
Min	.0924	.0905	.0924	.0934	.0671
Avg	.1475	.1384	.1311	.1269	.1069

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074094 / 33 KV KALAMBESHWAR

Feeder No / Name : 201 / 11 KV KALAMBESHWAR

GAOTHAN FEEDER

GAONTHAN Feeder KV- 11 /
OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.543	.4207	.218	.3898	.3315
2	.5487	.4161	.2321	.3856	.3353
3	.5487	.4161		.3856	.3647
4	.6401	.4334	.2984	.3856	.4096
5	.724	.5548	.3315	.5959	.5668
6	.7701	.8063	.5441	.7796	
7	.8954	.8063	.6325	.815	
8	.9412	.8596	.5182	.7712	
9	.8954		.5668	.7796	.7186
10	.6062	.3277	.4641	.631	.7362
11		.2486	.4508	.4858	
12	.4508	.1677	.4334	.2515	
13	.3814	.1677	.4382		
14	.4161	.1677	.4525		.4334
15	.4161	.1844	.4706		.5201
16	.4508	.2155	.5068	.1677	.5721
17	.5548	.2984	.5548		.6173
18	.7602	.426	.7282		.7362
19	.724	.4096	.724		.7682
20	.5853	.3605	.5853	.6081	.5973
21	.5068	.2984	.4755		
22	.4207	.2486	.4344	.4858	.4938
23	.4207	.2347	.3814	.3932	
24	.543	.4344	.218	.3898	.3647
Max	.9412	.8596	.7282	.815	.7682
Min	.3814	.1677	.218	.1677	.3315
Avg	.5975	.3871	.4635	.5118	.5354

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074094 / 33 KV KALAMBESHWAR

Feeder No / Name : 202 / 11 KV KALAMBESHWAR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1728	1.0402	.9023	
2		1.1728	1.0269	.9145	
3		1.1728	1.0856	.9389	
4		1.1728	1.1431	.9267	
5		1.2346	1.1431	.9633	
6			1.1717	.9389	
7			1.086	1.0802	
8			1.0856	1.358	
9			1.1145	1.358	
10				1.0311	1.4098
14				1.5508	1.6461
15					1.9471
16					1.6918
17					1.669
22	1.1728				
23	1.1873				
24		1.1728	1.0402	.8951	
Max	1.1873	1.2346	1.1717	1.5508	1.9471
Min	1.1728	1.1728	1.0269	.8951	1.4098
Avg	1.1801	1.1831	1.0937	1.0715	1.6728

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074094 / 33 KV KALAMBESHWAR

Feeder No / Name : 203 / 11 KV KASARKHED AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4793			.5601
2	.4793			.5601
3	.4793			.4801
4	.4729			.4858
5	.4793			.4858
6	.4729			.5668
9				.5441
10	.3525	.6241	.4858	
11	.6173	.6173	.7099	
12	.6173	.6481	.7099	
13	.7099	.6874	.7099	
14	.7099	.703	.7186	
15	.7186	.7125	.7186	
16	.7099	.6874	.7499	
17	.7099	.7287	.7099	
22	.423			
23	.4512			
24	.4793			.6249
Max	.7186	.7287	.7499	.6249
Min	.3525	.6173	.4858	.4801
Avg	.5507	.6761	.6891	.5385

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074097 / 33/11 KV PIMPALGAON UNDA

Feeder No / Name : 203 / 11 KV PIMPALGAON UNDA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1713			1.2323	1.1635
2	.1713			1.1949	1.1403
3	.1713			1.1949	1.1229
4	.2855			1.1576	1.1549
5	.4378			1.1576	1.1323
6	.6662			1.1949	1.0779
7	.8565			1.1949	1.0738
8	.7994			1.1949	1.0738
9	.7613			1.1949	.9865
10	1.6939	1.3409	1.2389		
11	1.6804	1.5704	1.7737	1.2323	
12	1.6804	1.5264	1.8671		
13		1.5118	1.8671		
14	1.8671	1.6961	1.7924		
15	1.9044	1.7264	1.7924		
16	1.6804	1.6202	1.6804		
17	1.4937	1.5529	1.6057		
24	.1903				1.1293
Max	1.9044	1.7264	1.8671	1.2323	1.1635
Min	.1713	1.3409	1.2389	1.1576	.9865
Avg	.9712	1.5681	1.7022	1.1949	1.1055

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074098 / 33/11 KV BHALEGAON (PACHALA)

Feeder No / Name : 201 / 11 KV BHALEGAON GAONTHAN GAONTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	09-DEC-17	10-DEC-17	11-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
2		.1715	.1715
3			.1715
4		.3429	
5			.3429
6		.4115	.4801
7			.6173
8		.3429	.5487
9			.5487
10	.3772	.2572	.3429
12		.1886	.2229
13		.1715	.2401
14		.1715	.2401
15		.1715	.2743
16		.2058	.3086
17		.3429	.3601
18		.4801	
19		.4801	
20		.3772	
21		.1715	
22		.1715	
23		.1372	
24		.1715	.1372
Max	.3772	.4801	.6173
Min	.3772	.1372	.1372
Avg	.3772	.2648	.3338

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074098 / 33/11 KV BHALEGAON (PACHALA)

Feeder No / Name : 202 / 11 KV BHALEGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	10-DEC-17	11-DEC-17
HR	Load (MW)	Load (MW)
2	1.7833	
4	1.7833	
9	1.8004	
10		1.8861
11		1.9052
12		1.9966
13		2.0576
14		2.21
15		2.1186
16		2.0576
17		1.9814
24	1.7833	
Max	1.8004	2.21
Min	1.7833	1.8861
Avg	1.7876	2.0266

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

MEHEKAR[294] BU 2941

Substation No/ Name :- 074098 / 33/11 KV BHALEGAON (PACHALA)

Feeder No / Name : 203 / 11 KV PACHALA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	09-DEC-17	10-DEC-17	11-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
2			.8916
4			.9602
5			.7545
6			.7202
7			.6859
8			.6859
9		1.2003	.6173
10	.8688	1.2003	
11		1.1317	
12		1.1317	
13		1.1317	
14		1.0631	
15		1.0288	
16		1.0288	
17		.9602	
24			.823
Max	.8688	1.2003	.9602
Min	.8688	.9602	.6173
Avg	.8688	1.0974	.7673

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAMPUR S/DN.[809] BU 4809

Substation No/ Name :- 074040 / 33/11 KV TUNKI S/STN

Feeder No / Name : 202 / 11 KV TUNKI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2481	2.0957			
2	2.1719	2.0957			
3	2.1338	2.0576			
4	2.1338	2.1338			
5	2.0195	2.1338			
6		2.1719			
7		2.1338			
8		2.2291			
9		2.2862			
10			2.1719	2.553	2.5149
11			2.8578	2.7816	3.0483
12			3.0102	3.1626	3.1055
13			2.9721	3.1436	3.2388
14			2.9721		3.1055
15			2.7435	2.8197	2.8769
16				2.8959	2.9912
17			2.553	2.8578	2.6673
24	2.21	2.2481			
Max	2.2481	2.2862	3.0102	3.1626	3.2388
Min	2.0195	2.0576	2.1719	2.553	2.5149
Avg	2.1529	2.1586	2.7544	2.8877	2.9436

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAMPUR S/DN.[809] BU 4809

Substation No/ Name :- 074040 / 33/11 KV TUNKI S/STN

Feeder No / Name : 203 / 11 KV BAWANBIR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669	.7621			
2	.9526	.724			
3	.9526	.724			
4	1.0288	.7621			
5	1.0669	.8002			
6		.8002			
7		1.0098			
8		1.0288			
9		.9717			
10			1.2193	1.1812	1.1431
11			1.848	1.7147	1.448
12			1.4861	1.3336	1.4098
13			1.2193	1.1812	1.105
14			1.1431	1.0669	.9526
15			1.1431	1.0669	1.0288
16			1.1431	1.1812	1.0669
17			1.1812	1.1431	1.0288
24	1.105	.8002			
Max	1.105	1.0288	1.848	1.7147	1.448
Min	.9526	.724	1.1431	1.0669	.9526
Avg	1.0288	.8383	1.2979	1.2336	1.1479

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAMPUR S/DN.[809] BU 4809

Substation No/ Name :- 074040 / 33/11 KV TUNKI S/STN

Feeder No / Name : 204 / 11 KV WASADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	.9145	.9526	1.0669	1.2955
2	1.1812	.8764	1.0479	1.0669	1.3336
3	1.1431	.8764	1.0669	1.1431	1.3336
4	1.105	.9145	1.105	1.1431	1.2955
5	1.0669	1.0479	1.1431	1.8099	1.3336
6		1.086	1.2003	1.8099	1.4098
7		1.2003	1.448	1.8861	1.7909
8		1.2003	1.5051	1.9624	1.8671
9		1.2193	1.4098	1.9814	1.7718
11	2.6292	2.3624	1.7147	1.8671	1.5623
12	2.9912	2.8006	1.9052	1.848	1.8861
13	2.915	2.7435	1.9814	1.7528	1.9052
14	2.8197	2.6863	2.0195	1.829	1.6766
15	2.6673	2.572	1.9624	2.0195	1.6766
16	2.4577	2.191	1.8861	1.9433	1.7909
17	2.4387	2.0957	1.9052	1.848	1.6575
24	1.2384	.9335	.9526	.9907	.9907
Max	2.9912	2.8006	2.0195	2.0195	1.9052
Min	1.0669	.8764	.9526	.9907	.9907
Avg	1.9902	1.6306	1.4827	1.6452	1.5634

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAMPUR S/DN.[809] BU 4809

Substation No/ Name :- 074040 / 33/11 KV TUNKI S/STN

Feeder No / Name : 205 / 11 KV TUNKI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5335	.5144	.4763	.4572
2	.5144	.5144	.5144	.4763	.4572
3	.5144	.5144	.4954	.4954	.4572
4	.5335	.4954	.4954	.8002	.4763
5	.724	.724	.5525		.5716
6	.8764	.8764	.8383		.6859
7	1.1431	1.0288	1.0669	1.0669	.9907
8		1.0479	1.0288	.8573	.8764
9	.6859	.8573		.8764	.8002
10	.8383	.724	.8383	.724	.724
11	.6668	.6668	.6668	.5335	.6478
12	.5716	.6097	.6097	.5335	.5525
13	.6287	.5906	.4954	.4954	.4954
14	.5335	.5716	.4954	.4954	.4954
15	.5144	.5716	.4954	.4954	.4572
16	.5335	.5906	.4954	.4954	.4954
17	.6859	.6478	.6097	.5335	.5716
18	.8764	.9526	.8383	.8383	.8383
19	.9145		.9145	.9145	.9145
20	.7621	.7621	.7621	.8002	.8002
21		.6668	.6478	.6859	.724
22	.724	.6097	.5716	.6097	.6097
23	.5716	.5525	.5335	.5335	.5335
24	.5335	.5335	.5335	.4954	.4954
Max	1.1431	1.0479	1.0669	1.0669	.9907
Min	.5144	.4954	.4954	.4763	.4572
Avg	.6755	.6801	.6528	.6469	.6303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAMPUR S/DN.[809] BU 4809

Substation No/ Name :- 074041 / 33/11 KV WARWAT BAKAL S/STN

Feeder No / Name : 201 / 11 kv Warwat Bakal AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.307	1.0288		
2	1.307	1.0288		
3	1.307	.9945		
4	1.3443	.9602		
5	1.3443	.5487		
6	1.0456	.6516		
7	1.0456	.8059		
8	1.0456	.703		
9	1.0456	1.3717		
10		1.3889		1.1576
11				1.4377
12				1.2136
13				1.0456
14				1.0269
15			1.0269	.9709
16			1.0829	1.0269
17	.583		1.2003	1.0269
18	.8573			
19	.823			
20	.7545			
21	.6859			
22	.6173			
23	.6224			
24	1.307	.9259		
Max	1.3443	1.3889	1.2003	1.4377
Min	.583	.5487	1.0269	.9709
Avg	1.0025	.9462	1.1034	1.1133

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074041 / 33/11 KV WARWAT BAKAL S/STN

Feeder No / Name : 202 / 11kv wankhed ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0911	1.0974	2.0576	1.1145	2.0576
2	2.0538	1.0974	1.8861	1.1145	1.8861
3	2.0538	1.0288	1.7147	1.0974	1.8861
4	2.0165	1.0288	1.6289	1.1145	1.8861
5	2.0165	.9602	1.6289	1.1317	1.8861
6		.9602	1.8004	.9945	1.8861
7		.9602	1.8004	1.2003	1.6804
8		.9602	1.6289	.9431	1.8861
9		.9602	1.6289	.8573	1.7833
10	1.0456		1.286		
11	1.166	2.572	1.1949	2.838	1.0288
12	1.1145	2.6578	1.3817	2.726	1.1145
13	.7087	2.572	1.1949	2.838	1.1145
14	1.0631	2.2291	1.1949	2.5393	1.0288
15	.9945	2.3148	1.3443	2.726	1.1145
16	1.0288	2.2291	1.3443	2.726	1.2003
17	1.0631	2.2291	1.3443	2.2405	1.1145
23		2.1434			
24	2.0911	1.0974		1.166	2.0576
Max	2.0911	2.6578	2.0576	2.838	2.0576
Min	.7087	.9602	1.1949	.8573	1.0288
Avg	1.4648	1.6166	1.5329	1.7275	1.5654

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074041 / 33/11 KV WARWAT BAKAL S/STN

Feeder No / Name : 203 / 11kv KAKANWADA AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8298	1.8519	1.3203	1.869	1.1317
2	1.8111	1.8519	1.3375	1.8519	1.166
3	1.7737	1.8519	1.286	1.8347	1.2003
4	1.7737	1.8519	1.286	1.8347	1.2003
5	1.587	1.6461	1.286	1.8519	1.2689
6		1.6804	1.3717	1.8176	1.3717
7		1.6632	1.3203	1.9204	1.5432
8		1.6118	1.2517	1.6975	1.6804
9		1.6118	1.3203	1.6289	1.5947
10	1.8671	1.8176	1.8004	1.5684	1.9719
11	2.1948	2.4863	2.3712	2.5393	2.4006
12	2.1434	2.4177	2.3712	2.6326	2.3148
13	2.2462	2.3148	2.3899	2.5206	2.4863
14	2.2634	2.0576	2.2032	2.2779	2.4863
15	2.4348	2.1434	2.3339	2.3339	2.4863
16	2.4006	2.0576	2.5393	2.2032	2.4006
17	2.1434	1.8861	2.5393	2.2218	2.2291
23		1.3717			
24	1.4563	1.8347		1.8861	1.1317
Max	2.4348	2.4863	2.5393	2.6326	2.4863
Min	1.4563	1.3717	1.2517	1.5684	1.1317
Avg	1.9947	1.8952	1.7840	2.0272	1.7814

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074041 / 33/11 KV WARWAT BAKAL S/STN

Feeder No / Name : 206 / 11 kv WANKHED GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.2401	.2058	.2058	.1715
2	.2987	.2401		.2058	.1715
3	.2987	.2401	.2058	.2058	.2058
4	.3361	.2401	.2401	.2058	.2058
5	.3361	.2401	.2401	.2401	.2058
6	.3361	.3086	.3086	.2401	.3086
7	.3361	.4115	.3429	.2743	.3086
8	.3361	.3086	.3086	.2401	.3429
9	.3361	.2743	.3086	.2401	
10	.2987	.2401	.2572	.2241	.2229
11	.2058	.2058	.1867	.2241	.2058
12	.2058	.1886	.1867	.2241	.1715
13	.2058	.2058	.1867	.2241	.1715
14	.2058	.2058	.1867	.1494	.2058
15	.2058	.2058	.1867	.1867	.2058
16	.2058	.2058	.1867	.2241	.1886
17		.2229	.2241	.2241	.2058
18	.3772	.3429	.2743	.3734	.3086
19	.3772	.4115	.3772	.3086	.3944
20	.3772	.3429	.3086	.2572	.3086
21	.3429	.3086	.2743	.2572	.2743
22	.3086	.2401	.2401	.2058	.2229
23	.2572	.2058	.2401		.2058
24	.2987	.2401		.2229	.1715
Max	.3772	.4115	.3772	.3734	.3944
Min	.2058	.1886	.1867	.1494	.1715
Avg	.2950	.2615	.2489	.2332	.2341

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAMPUR S/DN.[809] BU 4809

Substation No/ Name :- 074058 / 33/11 KV SANGRAMPUR S/STN

Feeder No / Name : 201 / 11 kV PALSHI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6584	.9709		.5121	1.0829
2	.695	.9149		.5487	1.1203
3	.7095	.8775		.5601	1.1576
4	.7762	.8775		.5853	1.1203
5	.7682	.8962		.5975	1.1576
6	1.0185	.9709		.7842	1.307
7	.9877	1.0082		.7842	1.4003
8	1.0974	1.0269		.9709	1.419
9	.9511	1.0456		.9335	1.6244
10	1.5684	1.0642		1.5684	1.6057
11	1.7551	1.0082		2.2405	1.531
12	2.0911	.7842		2.1658	
13	2.2032			1.6461	
14	2.2405			1.7924	
15	2.0911		1.5364	1.8858	
16	1.9978		1.4937	1.9418	
17	1.5684		1.9022	1.7924	
18	1.166		.6348	.7842	
19	1.0829		.6348	.6722	
20	1.0829		.5975	.5975	
21	1.0456		.5487	.5788	
22	1.0456		.5601	.5228	
23	1.0269		.5228	.4854	
24	.6584	.9522	.5258	.5121	1.0456
Max	2.2405	1.0642	1.9022	2.2405	1.6244
Min	.6584	.7842	.5228	.4854	1.0456
Avg	1.2619	.9536	.8957	1.0609	1.2976

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074058 / 33/11 KV SANGRAPUR S/STN

Feeder No / Name : 202 / 11 KV BODKHA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.1867		.2614	.2427
2	.3658	.168		.2987	
3	.3734	.168		.2926	.2054
4	.3734	.1867		.2987	.2054
5	.3658	.2241		.3292	.2241
6	.3772			.3326	.2987
7	.3658	.5228		.3361	.3361
8	.2926	.5415		.2987	.3734
9	.2926	.4108		.2614	.4108
10	.5853	.2801		.3361	.3361
11	.4854	.2241		.3292	.2987
12	.5601	.2054		.4108	
13	.5601			.3361	
14	.5228			.3361	
15	.5228		.2926	.3734	
16	.4294		.2614	.3921	
17	.3921		.4024	.3521	
18	.3921		.4108	.3547	
19	.3921		.4108	.3361	
20	.3734		.2987	.3174	
21	.2987		.2835	.3174	
22	.2614		.2987	.2801	
23	.2054		.2614	.2614	
24	.3292	.1867		.2561	.2427
Max	.5853	.5415	.4108	.4108	.4108
Min	.2054	.168	.2614	.2561	.2054
Avg	.3936	.2754	.3245	.3208	.2886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAMPUR S/DN.[809] BU 4809

Substation No/ Name :- 074058 / 33/11 KV SANGRAMPUR S/STN

Feeder No / Name : 203 / 11 KV NIWANA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6584	.4108		.8048	.3547
2	.7023	.4481		.7842	.3734
3	.7023	.4481		.7842	.4108
4	.7682	.4668		.7842	.3734
5	.7682	.4668		.8413	.4481
6	.8131			.8589	.5914
7	.8048	.8589		.8501	.6722
8	.8779	.9335		.9511	.6535
9	.9511	.7095		.9145	.8589
10	1.358	.6348		.8215	.8402
11	1.307	.6348		1.3443	
12	1.251	.6722		1.0608	
13	1.0456			.7164	
14	.7842				
15	.7468		.8779	.7842	
16	.7655		.7023	.8029	
17	.8775		.9335	.8402	
18	.4481		.9145		
19	.5228		.7095	.7842	
20	.5228		.7095	.7282	
21	.5601		.8589	.6908	
22	.4854		.8589	.5975	
23	.4481		.8215	.5041	
24	.6584	.3921	.5028	.8131	.3174
Max	1.358	.9335	.9335	1.3443	.8589
Min	.4481	.3921	.5028	.5041	.3174
Avg	.7845	.5897	.7889	.8210	.5358

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAMPUR S/DN.[809] BU 4809

Substation No/ Name :- 074058 / 33/11 KV SANGRAMPUR S/STN

Feeder No / Name : 204 / 11KV SANGRAMPUR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.2987		.3361	.2987
2	.3696	.2987		.3734	.2801
3		.2614		.3734	.2987
4	.2926	.2614		.4024	.2987
5	.2926	.2614		.4108	.3174
6	.4527			.4108	.3547
7	.4527	.2987		.4108	
8		.3174		.3734	.4108
9	.3734	.3547		.4481	.4294
10	.4108	.3734		.3361	.3734
11	.3361	.3361		.3734	
12	.3361	.2054		.2926	
13	.3547			.2561	
14	.3361			.2614	
15	.3361		.8779	.2427	
16	.3174		.3361	.2427	
17	.3547		.3696	.3174	
18	.3734		.3734	.2915	
19	.4108		.4108	.4108	
20	.4294		.3734	.4108	
21	.3772		.2987	.3734	
22	.3734		.2987	.3361	
23	.3547		.3361	.2987	
24	.3658			.3361	.2801
Max	.4527	.3734	.8779	.4481	.4294
Min	.2926	.2054	.2987	.2427	.2801
Avg	.3666	.2970	.4083	.3466	.3342

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074059 / 33/11 KV SONALA S/STN

Feeder No / Name : 202 / 11 KV SONALA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0457		.0305	.0305	1.2193
2	.0457		.0305	.0305	1.1888
3	.0457			.0305	1.1888
4	.0457		.0305	.0305	1.1888
5	.0457		.0305	.0305	1.1584
6	.0305		.0305	.0305	1.1584
7	.0305				1.1584
8	.0305				1.0974
9	.0305				1.0669
10	1.1439	1.1439	1.2193		
11	1.1439	1.278	1.2803		
12	1.4266	1.3077	1.3717		
13	1.3847	1.2944	1.3717		
14	1.3717	1.2643	1.3108		
15	1.3077	1.3108	1.3108		
16	1.2483	1.2803	1.2193		
17	1.2483	1.2193	1.1584		
18		.0305	.0305	.0457	
19		.0305	.0305	.0457	
20		.0305	.0305	.0457	
21		.0305	.0305	.0457	
22		.0305	.0305	.0457	
23		.0305	.0305	.0457	
24	.0457		.0305	.0305	1.2193
Max	1.4266	1.3108	1.3717	.0457	1.2193
Min	.0305	.0305	.0305	.0305	1.0669
Avg	.5929	.7344	.5304	.0375	1.1645

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074059 / 33/11 KV SONALA S/STN

Feeder No / Name : 204 / 11 KV PALSODA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7011	.4161	.6401	.6097	.0305
2	.6706	.4214	.6706	.6097	.0305
3	.6401	.442	.6706	.6097	.0305
4	.6401	.4214	.7316	.5487	.0305
5	.5792	.4572	.7621	.4572	.0305
6		.4816	.7621	.4572	.0305
7		.602	.7926	.3963	
8		.743	.7926	.4877	
9		.6923	.7926	.6097	
10				.6706	.7926
11				.7011	.9145
12				.7011	.823
13				.7011	.7621
14				.6401	.6706
15				.5792	.6097
16				.7316	.7621
17				.7621	
18			.0305	.0305	
19			.0305	.0305	
20			.0305	.0305	
21			.0305	.0305	
22			.0305	.0305	
23		.0305	.0305	.0305	
24	.7011	.4572	.6401	.6401	.0305
Max	.7011	.743	.7926	.7621	.9145
Min	.5792	.0305	.0305	.0305	.0305
Avg	.6554	.4695	.4649	.4623	.3963

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAMPUR S/DN.[809] BU 4809

Substation No/ Name :- 074059 / 33/11 KV SONALA S/STN

Feeder No / Name : 206 / 11 KV WARKHED AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3472	2.3929	2.4684	2.2862	2.1033
2	2.4082	2.3182	2.4996	2.2862	2.1033
3	2.4082	2.3472	2.4387	2.2862	2.0729
4	2.3472	2.2577	2.4691	2.1948	2.0424
5	2.3167	2.3015	2.5301	2.1948	1.9814
6	.061	2.3167	2.5453	2.1948	1.9814
7	.061	2.2862	2.5453	2.1338	1.89
8	.061	2.2577	2.6092	2.1948	1.829
9	.061	2.1975	2.625	2.1948	1.829
10	.6401	1.829	2.6882	2.3122	2.2253
11		2.1373	2.7199	2.372	2.6978
12	2.4996	2.2558	2.4387	2.4985	2.6825
13	2.4691	2.1975		2.625	2.6978
14	2.4074	2.1643	2.5286	2.6558	2.6368
15	1.5051	2.1975	2.4371	2.6558	2.5911
16	2.3777	2.3931	2.4966	2.713	2.5911
17	2.3777	2.3781	2.4006	2.5149	
18	2.1696	.2286	.3361	.2743	
19		.2286	.3361	.2743	
20		.2439	.3361	.2743	
21		.2439	.3142	.2743	
22		.2439	.3142	.2591	
23		.2286	.3326	.2591	
24	2.3472	2.348	2.4082	2.4082	2.1186
Max	2.4996	2.3931	2.7199	2.713	2.6978
Min	.061	.2286	.3142	.2591	1.829
Avg	1.7147	1.7497	1.9486	1.8474	2.2396

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAMPUR S/DN.[809] BU 4809

Substation No/ Name :- 074064 / 33/11 KV PATURDA S/STN

Feeder No / Name : 201 / 11 KV DEULGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.6802			
2	.6249	.6802	.7209		
3	.6249	.6478	.7291		
4	.6325	.6964	.7455		
5	.6554	.6478	.6706		
6		.6478	.7461		
7		.664	.5087		
8		.6478	.5721		
9		.664	.5784		
10			.6316	.6154	.502
11			.6478	.8097	.8097
12			.8259	.9069	.6478
13			.7935	.7287	.9555
14			.7935	.6478	.788
15			.9069	.7287	.6097
16			.7935	.7287	.5792
17			.7449	.6802	.5944
24	.6478	.6478	.5847		
Max	.6554	.6964	.9069	.9069	.9555
Min	.6249	.6478	.5087	.6154	.502
Avg	.6389	.6624	.7055	.7308	.6858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074064 / 33/11 KV PATURDA S/STN

Feeder No / Name : 202 / 11KV PATURDA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4706	.4344	.439	.3506	.3258
2	.4706	.4344	.439	.3506	.3258
3	.4706	.4706	.4344	.3681	.3801
4	.3801	.4706	.4887	.3681	.4163
5	.4938	.543	.5487	.3506	.4344
6	.724	.5611		.4207	.543
7	.8326	.7602	.6036	.5959	.543
8	.7964	.6154	.6584	.6661	.543
9	.7602	.5792	.695	.6135	.543
10	.695	.4344	.6485	.7011	.4163
11	.567	.4887	.631	.6135	.4525
12	.5014	.4525	.5258	.4908	.3439
13	.4835	.5121	.5434	.543	.3077
14	.5373	.567	.5083	.543	.2402
15	.5552	.5487	.4908	.543	.6283
16		.5792	.5083	.543	.6447
17	.543	.6219	.4908	.5611	.6653
18	.7602	.7316	.6661	.7783	.8871
19	.8507		.6836	.7783	.7947
20	.724		.5784	.6516	.7392
21	.6516	.6154	.5258	.5792	.5914
22	.5973	.5487	.4207	.4344	.5175
23	.543	.439	.4031	.3801	.4668
24	.5068	.4706		.3681	.362
Max	.8507	.7602	.695	.7783	.8871
Min	.3801	.4344	.4031	.3506	.2402
Avg	.6050	.5399	.5423	.5247	.5047

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAMPUR S/DN.[809] BU 4809

Substation No/ Name :- 074064 / 33/11 KV PATURDA S/STN

Feeder No / Name : 203 / 11 KV KODRI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6859	.7287
2			.6859	.7287
3			.6554	.7287
4			.6554	.6706
5			.6401	.7287
6			.6401	.7287
7			.6401	.7287
8			.6554	.7287
9			.6859	.6478
10		.9069		
11		1.1336		
12	.6478	1.085		
13	.8583			
14	.9069			
15	.8907			
16	.8907			
17	.9231			
24			.7164	.664
Max	.9231	1.1336	.7164	.7287
Min	.6478	.9069	.6401	.6478
Avg	.8529	1.0418	.6661	.7083

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAMPUR S/DN.[809] BU 4809

Substation No/ Name :- 074064 / 33/11 KV PATURDA S/STN

Feeder No / Name : 204 / 11 KV KAVTHAL AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	08-DEC-17	09-DEC-17	11-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.9503
2			.9503
3			.9831
4			.9831
5			.9831
6			1.0159
7			.9503
8			.7865
9			.7537
10	.9503	.9717	
11	1.1789	1.1498	
12	1.1012	1.1984	
13	1.1012	1.283	
14	1.085	1.283	
15	1.1174	1.283	
16	1.1336	1.2269	
17	1.1498	1.2048	
24			.9831
Max	1.1789	1.283	1.0159
Min	.9503	.9717	.7537
Avg	1.1022	1.2001	.9339

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SANGRAPUR S/DN.[809] BU 4809

Substation No/ Name :- 074064 / 33/11 KV PATURDA S/STN

Feeder No / Name : 205 / 11KV KAWTHAL GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.3582	.3506	.2926	.3224
2	.362	.3582	.3506	.2926	.3224
3	.362	.3582	.3544	.3109	.2686
4	.3544	.394	.3982	.3109	.2686
5	.3681	.4119	.4382	.3292	.3403
6	.4557	.4835	.4607	.439	.4656
7	.5792	.6089		.6036	.4477
8	.5258	.5014	.4557	.567	.5014
9	.4252	.4656	.4784	.5487	.5552
10	.3982	.4298	.439	.3475	.4656
11	.3681	.3582	.3658	.3658	.4656
12	.3582	.3045	.3292	.3109	.362
13	.3224	.2804		.3045	.3045
14	.3045	.2658	.2743	.2429	.3077
15	.2507	.2658	.2926	.3045	.3077
16	.3258	.2896	.2926	.3224	.3658
17	.4163	.3189	.3658	.3403	.3439
18	.5552	.5792	.5304	.5373	.6036
19	.5552	.5973	.6036	.5731	.5487
20	.5373	.4607	.4938	.4656	.4938
21	.4477	.4075	.4207	.4477	.4755
22	.4477	.3721	.3658	.3045	.4066
23	.4119	.3366	.3292	.3224	.3734
24	.3856	.3582	.333	.3109	.3224
Max	.5792	.6089	.6036	.6036	.6036
Min	.2507	.2658	.2743	.2429	.2686
Avg	.4116	.3985	.3965	.3831	.4016

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074037 / 33/11 KV SHEGAON R & M

S/Stn

Feeder No / Name : 201 / 11KV TOWN I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8589	.7468	.8215	.7468	.7468
2	.8589	.7468	.8215	.7468	.7468
3	.8589	.7468	.8215	.7842	.7468
4	.8589	.7468	.8215	.7842	.7468
5	.8962	.8962	.8962	.8215	.7468
6	1.0829	1.0456	.9709	.9335	.8215
7	1.1576	1.1949	1.1576	1.2323	1.0456
8	1.4563	1.1949	1.3443	1.3443	1.1203
9	1.3443	1.307	1.4937	1.2696	1.1576
10	1.3817	1.3817	1.4563	1.3443	1.1203
11	1.2696	1.3817	1.3443	1.2696	1.0456
12	1.2323	1.307	1.1949	1.1949	1.0456
13	1.1203	1.1576	.9709	1.1203	.8215
14	.9709	1.2323	.9709	1.1203	.8962
15	1.2323	1.0829	1.1949	1.1203	.9709
16	1.307	1.0829	1.307	1.2696	.9709
17	1.1949	1.3443	1.307	.9709	1.0456
18	1.4937	1.643	1.419	1.2696	1.2696
19	1.5684	1.6057	1.531	1.3443	1.2696
20	1.3443	1.4563	1.3443	1.2696	1.1949
21		1.1949	1.0829	1.0456	1.0829
22	1.1203	1.1203	.9335	.9709	1.0456
23	.9709	.9709	.8962	.7468	.9335
24	.8589	.8215	.8962	.8215	.8215
Max	1.5684	1.643	1.531	1.3443	1.2696
Min	.8589	.7468	.8215	.7468	.7468
Avg	1.1495	1.1420	1.1249	1.0642	.9756

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074037 / 33/11 KV SHEGAON R & M

S/Stn

Feeder No / Name : 202 / 11KV TOWN II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1576	1.1576	1.1203	1.0829	.9709
2	1.1576	1.1576	1.1203	1.0829	.9709
3	1.1576	1.1576	1.1203	1.0829	.9709
4	1.1576	1.1576	1.1203	1.0829	.9709
5	1.1576	1.1576	1.1576	1.1203	.9709
6	1.2696	1.2696	1.1949	1.3817	1.1203
7	1.531	1.531	1.3817	1.3817	1.3443
8	1.5684	1.419	1.4563	1.307	1.3443
9	1.5684	1.3817	1.419	1.3443	1.419
10	1.419	1.307	1.419	1.2696	1.2696
11	1.3443	1.2323	1.3443	1.1949	1.1949
12	1.2696	1.2323	1.1949	1.1203	1.1576
13	1.2696	1.1576	1.1949	.9709	1.0456
14	1.2696	1.1576	1.1203	.9709	1.0456
15	1.1203	1.0829	1.0456	.9709	1.0082
16	1.0456	1.0829	1.0829	.9709	.9709
17	1.1576	1.1576	1.0829	1.1203	1.0456
18	1.7177	1.7924	1.531	1.4937	1.5684
19	1.7551	1.7924	1.6057	1.531	1.643
20	1.6057	1.643	1.6057	1.419	1.5684
21	1.5684	1.643	1.3817	1.4937	1.4937
22	1.4563	1.4563	1.307	1.3443	1.419
23	1.2696	1.2696	1.2696	1.1576	1.2323
24	1.1576	1.1949	1.1949	1.1949	.9709
Max	1.7551	1.7924	1.6057	1.531	1.643
Min	1.0456	1.0829	1.0456	.9709	.9709
Avg	1.3396	1.3163	1.2696	1.2121	1.1965

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074037 / 33/11 KV SHEGAON R & M

S/Stn

Feeder No / Name : 203 / 11 KV ALASNA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL

DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0332	.0332	.0162		.0166
2	.0332	.0332	.0162		.0166
3	.0332	.0332	.0162		.0166
4	.0332	.0332	.0162		.0166
5	.0332	.0663	.0162		.0166
6		.0663	.0162	.0166	.0166
7		.0663	.0162	.0166	
8		.0995	.0162	.0166	
9		.0663	.0166	.0162	
10			.0663	.0648	.0648
11			.0663	.1296	.0648
12	.0162	.0166	.1326	.1296	.1296
13	.0162	.0166	.0995	.1296	.0648
14	.0162	.0166	.1326	.0648	.0648
15	.0162	.0166	.0995	.0972	.0648
16	.0166	.0162	.0995	.0663	.0648
17	.0166	.0162	.0995	.0995	.0972
18	.0187	.0162			
19	.0166	.0162			
20	.0166	.0162		.0166	.0162
21		.0162		.0166	.0162
22				.0166	.0162
23				.0166	.0162
24	.0332	.0332	.0162		.0166
Max	.0332	.0995	.1326	.1296	.1296
Min	.0162	.0162	.0162	.0162	.0162
Avg	.0233	.0347	.0532	.0571	.0419

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074037 / 33/11 KV SHEGAON R & M

S/Stn

Feeder No / Name : 204 / 11KV INDUSTRIAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2321	.2321	.2321	.2652	.2321
2	.2321	.2321	.2321	.2652	.2321
3	.2321	.2321	.2321	.2652	.2321
4	.1989	.2321	.2321	.2321	.1989
5	.1989	.1989	.2321	.2321	.1989
6	.1989	.1989	.1989	.2321	.1989
7	.1658	.1658	.1326	.2321	.1989
8	.1989	.1326	.0995	.2321	.1989
9	.1326	.2652	.1658	.1326	.1658
10	.2321	.2652	.1658	.1989	.1326
11	.2984	.2984	.1989	.1989	.0995
12	.3978	.2652	.1326	.1989	.0332
13	.2321	.2321	.1658	.1989	.1326
14	.1494	.1658	.1658	.1326	.0332
15	.2321	.3315	.2321	.1989	.1326
16	.3978	.3647	.1658	.3647	.1326
17	.431	.4641	.2652	.2984	.1989
18	.3647	.431	.2984	.2984	.0995
19	.431	.3315	.3978	.3315	.0663
20	.4641	.3315	.2984	.3315	.0663
21	.2652	.2321	.1989		.1658
22	.1989	.2321	.2321	.2652	.2652
23	.1989	.2321	.2321	.2321	.1989
24	.1989	.1658	.1658	.1989	.1326
Max	.4641	.4641	.3978	.3647	.2652
Min	.1326	.1326	.0995	.1326	.0332
Avg	.2618	.2597	.2114	.2407	.1561

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074037 / 33/11 KV SHEGAON R & M

S/Stn

Feeder No / Name : 205 / ALASNA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9709	.8962	.8962	.7842	.7842
2	.9709	.8962	.8962	.7842	.7842
3	.9709	.8962	.8962	.7842	.7842
4	.9709	.8962	.8962	.7842	.7842
5	1.0456	.8962	1.0082	.7842	.7842
6	1.2323	1.1949	1.1576	1.0082	1.1203
7	1.3817	1.419	1.3443	1.307	1.3443
8	1.2696	1.1949	1.2696	1.307	1.2696
9	1.0829	1.0082	1.1949	1.1949	1.0829
10	1.0456	.8589	.9709	1.1203	.9709
11	.8215	.7468	.8215	.8962	.8962
12	.7468	.6722	.7095	.7468	.5601
13	.7468	.5975	.7095	.5975	.5601
14	.5975	.6722	.7095	.5975	.5975
15	.5975	.7095	.6722	.5975	.5975
16	.7095	.7095	.5601	.5975	.5975
17	.7468	.7842	.7842	.6722	.6722
18	1.3443	1.3443	1.2323	1.2696	1.2696
19	1.4937	1.4937	1.3443	1.3443	1.3443
20	1.419	1.419	1.2696	1.1949	1.307
21	1.2696	1.2696	1.0829	1.1203	1.1949
22	1.1203	1.1576	.9335	.9709	1.1203
23	1.0456	1.0456	.8589	.8962	.9709
24	.9709	.9709	.9709	.8962	.8215
Max	1.4937	1.4937	1.3443	1.3443	1.3443
Min	.5975	.5975	.5601	.5975	.5601
Avg	1.0238	.9896	.9662	.9273	.9258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074037 / 33/11 KV SHEGAON R & M

S/Stn

Feeder No / Name : 206 / 11 KV ENGG COLLEGE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.6722	.6413	.5975	.7095
2	.7468	.6722	.6413	.5975	.7095
3	.7468	.6722	.6413	.5975	.7095
4	.7095	.6722	.6413	.5975	.7095
5	.7095	.6722	.6413	.5975	.7095
6	.7095	.7095	.6413	.5975	.7468
7	.8589	.8215	.679	.7842	.9709
8	1.0082	.8215	.9054	.7842	.8215
9	.9054	.8589	.8215	.8215	.7545
10	.7545	.6722	.8215	.8215	.6036
11	.679	.6722	.7095	.7468	.6036
12	.6036	.6348	.7095	.7468	.6036
13	.6036	.5601	.7095	.5975	.5658
14	.6036	.5601	.7095	.5228	.5658
15	.6036	.6348	.7095	.5228	.4527
16	.7095	.679	.6722	.6348	.5228
17	.7468	.7167	.7095	.7095	.5228
18	.9709	.9054	.8589	1.0456	.5975
19	1.0456	1.0185	.9335	.9709	.8215
20	1.0829	.9808	.8215	.8962	.7468
21		.7545	.7468	.7468	.7468
22	.8215	.7545	.7095	.8962	.7545
23	.7468	.7167	.7095	.7468	.6036
24	.7468	.7095	.679	.6722	.7095
Max	1.0829	1.0185	.9335	1.0456	.9709
Min	.6036	.5601	.6413	.5228	.4527
Avg	.7765	.7309	.7276	.7188	.6776

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074052 / 33/11 KV SHEGAON ANAND-SAGAR

S

Feeder No / Name : 201 / 11 KV ANAND SAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0934	.112		.1109
2	.0943	.0934	.112	.112	.0924
3	.0943	.0934	.112	.112	.0934
4	.0943	.0934	.0934	.112	.0934
5	.0943	.112	.112	.112	.1109
6	.0943	.112	.1494	.1307	.112
7	.1132	.112	.1494	.168	.1307
8	.112	.1307	.1494	.1494	.1848
9	.112	.1494	.1494	.1494	.1494
10	.1867	.1867	.1867	.2241	.2241
11	.2241	.2033	.2614	.2987	.2241
12	.1867	.1848	.2427	.1867	.2054
13	.1494		.2054	.1867	.2241
14	.1494	.168	.2241	.2241	.2241
15	.1494	.168	.2614	.2402	.1867
16	.1867	.2241	.2427	.2402	.2241
17	.1867	.1494	.2241	.2241	.1867
18	.2561	.3734	.2614	.2987	.2987
19	.2241	.2957	.3174	.3142	.2241
20	.1867	.1848	.1867	.2033	.1867
21	.1494	.1294	.1307	.168	.1307
22	.112	.112	.112	.1463	.1307
23	.112	.1307	.112	.1478	.112
24	.112	.0934	.112	.112	.1109
Max	.2561	.3734	.3174	.3142	.2987
Min	.0934	.0934	.0934	.112	.0924
Avg	.1447	.1562	.1758	.1852	.1655

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074052 / 33/11 KV SHEGAON ANAND-SAGAR

S

Feeder No / Name : 202 / 11KV Nagzari AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8351	.5735	.1823	.3277	.3185
2	1.8896	.5735	.213	.3277	.2984
3	1.8233	.5735	.2294	.3113	.3113
4	1.8778	.5571	.2347	.3113	.2785
5	1.7772	.5571	.2543	.3113	.2949
6		.5506	.2804	.2949	.3149
7		.5506	.298	.2949	
8		.5182	.2658	.2785	
9		1.6956	.218	.2591	
10			1.6787	1.7541	1.6108
11			2.7073	2.2177	1.8652
12	.1296	1.3491	2.2611	2.1765	1.8991
13	.2915	1.4784	2.13	2.0328	1.7804
14	.3125	1.3817		2.1068	1.704
15	.3277	1.3443	2.2119	2.0698	1.8652
16	.3593	1.1869	2.13	2.0883	1.8023
17	.4687		2.0317	2.1253	1.8442
18	.4218				
19	.4588	.1829	.0655		
20	.4424	.2683	.1966	.2033	.1696
21	.4096	.3277	.2785	.2622	.3605
22	.2915		.2881	.2984	.3605
23			.2785	.3277	.4294
24	1.873	.5735	.1619	.3401	.3185
Max	1.8896	1.6956	2.7073	2.2177	1.8991
Min	.1296	.1829	.0655	.2033	.1696
Avg	.8817	.7913	.8453	.9418	.9382

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074052 / 33/11 KV SHEGAON ANAND-SAGAR

S

Feeder No / Name : 203 / 11 KV GM MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3696	.3734	.462	.3174	.3142
2	.3511	.3361	.462	.3174	.3326
3	.3511	.3361	.4435	.2987	.2957
4	.3326	.3361	.4435	.2987	.2957
5	.3511	.3734	.4251	.2987	.3142
6	.3511	.3734	.4066	.3361	.3142
7	.3326	.3921	.3881	.3734	.3696
8	.4251	.3361	.4805	.4108	.4066
9	.3696	.3734	.462	.3921	.3881
10	.3734	.3881	.4251	.3511	.3361
11	.3734	.3881	.3563	.3696	.3734
12	.3361	.3696	.3361	.3142	.3734
13	.2987	.3511	.3174	.2218	.3361
14	.2801	.3361	.3547	.2772	.2987
15	.2801	.3174	.3174	.2772	.3395
16	.2987	.2987	.2801	.3511	.2614
17	.3361	.3361	.3174	.2772	.3361
18	.4715	.5093	.4108	.4066	.4294
19	.5041	.5544	.5041	.462	.5228
20	.5228	.5544	.4668	.4435	.4668
21	.4668	.5359	.4854	.4435	.4854
22	.4668	.5544	.4108	.4251	.4481
23	.4294	.5544	.3547	.3511	.4108
24	.3696	.3734	.4805	.3174	.3142
Max	.5228	.5544	.5041	.462	.5228
Min	.2801	.2987	.2801	.2218	.2614
Avg	.3767	.4021	.4080	.3472	.3651

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074052 / 33/11 KV SHEGAON ANAND-SAGAR

S

Feeder No / Name : 204 / 11KV CHINCHOLI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1928	.1638	.9593	.8848	.8785
2	.2103	.1875	.9231	.8848	.8951
3	.2103	.1829	.9412	.8848	.852
4	.2804	.2056	.9231	.9012	.8684
5	.2103	.213	.9492	.9012	.9282
6	.2103	.2294	.9313	1.0642	1.0322
7	.2481	.2343	.9568	1.1389	1.2452
8	.2629	.2949	1.0029	1.0486	1.2793
9	.2804	.2622	1.0498	1.0978	1.1401
10	1.1191	1.2574		.128	
11	1.0174	1.3245		.2218	
12	1.153	1.1273	.2054	.1848	
13	1.1869	1.3491	.1867	.2402	
14	1.1869	1.1888	.2241	.2561	
15	1.1469	1.307	.2241	.2402	
16	1.153	1.2971	.3174	.3142	
17	1.1191	1.0802	.2801	.3142	.1829
18			.2614	.2957	.2134
19			.2427	.2743	.2343
20			.2801	.2378	.2134
21			.213	.2204	.2458
22		.1829	.2054	.2172	.2622
23		.181	.1867	.2328	.3605
24	.1848	.1562	.9412	1.0082	1.0277
Max	1.1869	1.3491	1.0498	1.1389	1.2793
Min	.1848	.1562	.1867	.128	.1829
Avg	.6318	.6213	.5639	.5497	.6976

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074052 / 33/11 KV SHEGAON ANAND-SAGAR

S

Feeder No / Name : 205 / 11KV NAGZRI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2033	.168	.1848	.112	.1663
2	.2033	.168	.1663	.112	.1478
3	.1848	.168	.1848	.112	.1478
4	.1848	.1867	.1663	.1307	.1663
5	.2033	.2241	.1848	.1307	.1848
6	.2218	.2427	.2218	.1494	.2218
7	.2402	.2614	.2587	.2241	.2402
8	.2033	.1867	.2402	.168	.2218
9	.1663	.168	.1848	.1494	.2033
10	.1494	.1109	.1848	.1109	.168
11	.1307	.0924	.1267		.1307
12	.112	.0934	.1307		.0934
13	.0934	.0934	.112	.1478	.0934
14	.0934	.112		.1294	.0934
15	.0934	.112		.1109	.0943
16	.0934	.0934		.1109	.112
17	.112	.112		.1478	.1307
18	.2427	.2427		.2218	.2241
19	.2801	.2587	.1307	.2772	.2427
20	.2427	.2402	.168	.2402	.2241
21	.2241	.2218	.1698	.2218	.2241
22	.2054	.2033	.1494	.1829	.1867
23	.1867	.1848	.1307	.1848	.168
24	.2033	.168	.1848	.112	.1663
Max	.2801	.2614	.2587	.2772	.2427
Min	.0934	.0924	.112	.1109	.0934
Avg	.1781	.1714	.1726	.1585	.1688

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074077 / 33/11 KV SHEGAON RAPDRP

S/STN.

Feeder No / Name : 202 / LOHARA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926	.2801	.2815	.2614	.2801
2	.2772	.2614	.2815	.2241	.2801
3	.2772	.2614	.3003	.2241	.2987
4	.2772	.2801	.3003	.2241	.2987
5	.2772	.2987	.3003	.2614	.3174
6	.4066	.3881	.3566	.3547	.3584
7	.5121	.499	.5067	.5041	.4481
8	.3584	.5544	.5067	.4294	.4481
9	.4129	.4294	.4572	.4129	.3841
10	.4316	.3326	.4024	.4129	.4344
11	.4316		.3544	.3566	.3258
12	.3753	.3696	.3012		.3439
13	.3941	.3511	.3681	.3378	.3439
14	.3378	.2987	.3045	.2627	.3439
15	.3378	.2987	.3258	.244	.3326
16	.3566	.3174	.3403	.3378	.3292
17	.3582	.3566		.3944	.3566
18	.4108	.5067	.5041	.5121	.4316
19	.4338	.5255	.4294	.462	.4504
20	.3961	.4129	.3921	.3584	.3753
21	.3584	.3941		.3395	.3753
22	.3361	.319	.3361	.3018	.319
23	.3174	.319	.2801	.2829	
24	.3142	.2801	.319	.2614	.2801
Max	.5121	.5544	.5067	.5121	.4504
Min	.2772	.2614	.2801	.2241	.2801
Avg	.3617	.3624	.3613	.3374	.3546

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

KHAMGAON CONSTRUCTION DIV[614]

SHEGAON S/DN.[528] BU 5282

Substation No/ Name :- 074077 / 33/11 KV SHEGAON RAPDRP

S/STN.

Feeder No / Name : 203 / 11KV Janori Ag fdr

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			2.1581	2.4646	2.0858
2			2.0831	2.4272	2.0858
3			2.1206		2.0458
4			1.9705		2.0508
5			2.1581		2.0683
6			1.9705		2.0908
7			2.0268		2.1672
8			2.008		1.9313
9			1.7737		1.7909
10	2.0831	2.0911			1.8427
11	2.4208	2.5393			1.576
12	2.4021	2.7073			1.5939
13	2.9275	2.838			1.5592
14	2.3833	2.8753			1.5927
15	2.8554	2.7446			
16	2.7211	2.6699			
17	2.1538				
24			2.1956	2.1845	2.1616
Max	2.9275	2.8753	2.1956	2.4646	2.1672
Min	2.0831	2.0911	1.7737	2.1845	1.5592
Avg	2.4934	2.6379	2.0465	2.3588	1.9095

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074018 / 33 KV JALGAON JAMOD S/S

Feeder No / Name : 201 / 11 KV JALGAON AG FEEDER FEEDER SEPERATION/PURE AG
 Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1509
2				.1509
3				.1509
4				.1509
5				.1698
6				.2075
7				.6224
8				.7922
9		.2926	.2195	
10	.7316	.695	.5853	
11	.695	.5853	.6584	
12	.6401	.5304	.6401	
13	.5487	.439	.5304	
14	.5121	.4024	.4207	
15	.4887	.4525	.4525	
16	.543	.4163	.3982	
23			.1509	
24		.8238		.1509
Max	.7316	.8238	.6584	.7922
Min	.4887	.2926	.1509	.1509
Avg	.5942	.5153	.4507	.2829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074018 / 33 KV JALGAON JAMOD S/S

Feeder No / Name : 202 / 11 KV SOOTGIRNI EXPRESS SHEDDABLE FEEDER HAVING WEEKLY
FEEDER Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4298	.4298	.439	.4527	.4715
2	.4298	.4298	.439	.4338	.4715
3	.4298	.4298	.439	.4338	.4715
4	.4298	.4298	.439	.4338	.4715
5	.4298	.4298	.439	.4527	.4715
6	.4656	.4298	.439	.4715	.4904
7	.5014	.4298	.439	.4904	.4715
8		.4298	.439	.5041	.4527
9	.5975	.4854	.5228	.5601	.4481
10	.6348	.4668	.5975	.5601	.4294
11	.5975	.4668	.5601	.5601	.4294
12	.5601	.4481	.5228	.5601	.4481
13	.5228	.4854	.4854	.5228	.4668
14	.5041	.4854	.4854	.4854	.4481
15	.5228	.4668	.5041	.4668	.439
16	.4294	.5228	.4854	.4854	.439
17	.4294	.5228	.4668	.5228	.439
18	.4668	.5228	.4668	.4668	.4298
19	.4668	.4668	.4668	.4668	.439
20	.4668	.4668	.4854	.4668	.439
21	.4668	.4668	.4668	.4668	.439
22	.4668	.4298	.4668	.4668	.4298
23	.4298	.4298	.4338	.4527	.4207
24	.439	.439	.439	.4715	.4715
Max	.6348	.5228	.5975	.5601	.4904
Min	.4294	.4298	.4338	.4338	.4207
Avg	.4834	.4588	.4737	.4856	.4512

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074018 / 33 KV JALGAON JAMOD S/S

Feeder No / Name : 203 / 11 KV JALGAON SUNGAON AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	11-DEC-17
HR	Load (MW)
22	.4668
Max	.4668
Min	.4668
Avg	.4668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074018 / 33 KV JALGAON JAMOD S/S

Feeder No / Name : 204 / 11 KV ASALGAON AG FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1433		.0716	.1509	
2	.1433		.0716	.1509	
3	.1433		.0716	.132	
4	.1433		.0716	.132	
5	.2149		.1075	.1698	
6	.2149		.1433	.2075	
7	.5014		.5014	.4338	
8			.6089	.5601	
9		.3841			.2926
10		.5853			.6219
11		.7316			.5487
12		.5304			.6535
13		.3475			.439
14		.2987			.3475
15		.362			.3224
16		.362			.3224
23			.168		.0175
24			.0716	.1698	
Max	.5014	.7316	.6089	.5601	.6535
Min	.1433	.2987	.0716	.132	.0175
Avg	.2149	.4502	.1887	.2341	.3962

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074018 / 33 KV JALGAON JAMOD S/S

Feeder No / Name : 205 / 11 KV JALGAON TOWN-2

GAOTHAN FEEDER

GAOTHAN F Feeder KV- 11 /
OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
15	.4251	.4066		.4251
16	.4251	.4251		.4066
17	.5175	.4805		.499
18	.8316	.7023	1.0719	.7392
19	.7947	.7392	.8871	.7762
20	.7762	.7023	.7392	.7023
21	.6468	.6468	.5544	.5914
22	.6099		.5175	.5729
Max	.8316	.7392	1.0719	.7762
Min	.4251	.4066	.5175	.4066
Avg	.6284	.5861	.7540	.5891

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074018 / 33 KV JALGAON JAMOD S/S

Feeder No / Name : 206 / 11 KV JALGAON TOWN-1

GAOTHAN FEEDER

GAOTHAN F Feeder KV- 11 /
OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8238	.7522	.8238	.7545	.7733
2	.8238	.7522	.8238	.7356	.7545
3	.8238	.7522	.8238	.7356	.7545
4	.8596	.8238	.8596	.7545	.7545
5	1.1104	1.0029	.9313	.8488	.9054
6	1.2178	1.0745	.9671	1.0751	1.2449
7	1.4327	1.2536	1.2178	1.3392	1.5089
8		1.2536	1.2894	1.3443	1.3769
9	1.4003	1.251	1.2696	1.2696	1.2696
10	1.3443	1.1203	1.1949	1.0829	1.0456
11	1.1949	1.0082	1.0829	.9335	.9896
12	1.1203		.9335	.8962	.9335
13	1.0082		.8402	.7865	.8775
14	.8775		.8402	.7468	.8589
15	.8316		.8131	.7392	.7522
16	.9055	1.5893	.8131	.8501	.8238
17	.961	1.2012	.924	.924	.9313
18	1.3306	1.3306	1.2936	1.2197	1.1104
19	1.2936	1.386	1.3306	1.2936	1.2894
20	1.2012	1.2567	1.1827	1.2567	1.182
21	1.0719	1.1458	.8871		1.0745
22	.961	1.0387	.8871	.9979	.9671
23	.8238	.8596	.8676	.8488	.8413
24	.8238	.7522		.7545	.7733
Max	1.4327	1.5893	1.3306	1.3443	1.5089
Min	.8238	.7522	.8131	.7356	.7522
Avg	1.0540	1.0802	.9955	.9647	.9914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074018 / 33 KV JALGAON JAMOD S/S

Feeder No / Name : 207 / 11 KV UMAPUR AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1075	.2865	.1075	.0943	.2075
2	.1075	.2865	.1075	.0943	.2075
3	.1075	.2865	.1075	.0934	.4715
4	.1075	.394	.1433	.0943	.2641
5	.1433	.5373	.1433	.1132	.3018
6	.1433	.5373	.1433	.1132	.3772
7	.1791	1.0745	.2507	.1886	.7922
8		1.2536	.3582	.3292	.7922
9	.3109	.2926	.439	.3475	.1646
10	1.2437	.5121	1.3535	1.0608	.4024
11	.9511	.5487	1.2437	1.134	.3292
12	.9145	.439	.9328	.7316	.3174
13	.8596	.3292	.8596	.6584	.4108
14	.695	.3734	.695	.5487	.3109
15	.543	.2534	.6335	.543	.394
16	.8145	.2353	.5973	.543	.394
23		.1075	.0943	.2829	.1402
24			.1075	.0934	.2075
Max	1.2437	1.2536	1.3535	1.134	.7922
Min	.1075	.1075	.0943	.0934	.1402
Avg	.4819	.4557	.4621	.3924	.3603

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074019 / 33 KV JAMOD S/S

Feeder No / Name : 201 / 11 KV JAMOD AG FEEDER
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1096	.4161	1.1317	.2883	1.1736
2	1.1096	.4161	1.1317	.2713	1.1869
3	1.1096	.4161	1.1317	.2713	1.0059
4	1.1789	.4508	1.0974	.2713	.9945
5	1.3003	.6588	1.17		1.2574
6	1.595	.9015	1.5261		1.4752
7	1.6817	.9362	1.8991		1.861
8	2.3232	.8495	1.8861		1.7532
9	2.2672	1.5257	1.3176		2.5312
10	2.2801	1.6108	1.4043		2.826
11	2.1879	1.9559	1.4737		2.6873
12	2.079	2.0119	1.3003		2.5312
13	1.6956	2.0748	1.0749	.9156	2.4619
14	1.2689	1.8991	.7975	1.2803	2.1152
15	1.2548	1.7939	.6935	1.2887	1.9938
16	1.291	1.7736	.8149	1.1401	2.0805
17	1.0174		1.4922	2.0622	1.7337
18	.9745	2.2634	1.2742	2.5987	1.6644
19	.7973	2.146	1.5083	2.1795	1.2136
20	.7602	1.7295	1.6108	1.9839	.7802
21	.6335	1.286	1.5261	1.7126	.6762
22	.5853	1.4413	1.4413	1.4752	
23	.4294	1.2717	.3361	1.2717	
24			1.1317	.3174	1.1603
Max	2.3232	2.2634	1.8991	2.5987	2.826
Min	.4294	.4161	.3361	.2713	.6762
Avg	1.3448	1.3559	1.2571	1.2080	1.6892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074019 / 33 KV JAMOD S/S

Feeder No / Name : 202 / 11 KV SUNGAON AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4161	.5895	.4641	.5935	.2374
2	.4161	.5895	.4807	.5935	.2347
3	.4161	.5895	.4973	.5935	.2321
4	.4854	.6241	.4973	.5935	.2683
5	.5375	.6588	.4973		.3239
6	.5721	.6935	.547		.6539
7		.6415	.7127		.7042
8		.6935	.9614		.7611
9		.6935	1.1096		2.2192
10		1.2431	1.543		2.0805
11		1.3565	2.0978		2.2539
12		1.8482	1.9938		1.9418
13		1.8233	1.8724	.9282	1.647
14		1.5432	1.7857	1.757	1.4563
15	1.2717	1.0608	1.439	1.6842	1.4217
16	1.6575	1.1401	1.4043	1.4918	1.3696
19	.8619				
20	.7956				
21	.7127				
23		.4641	.6796	.2652	
24			.4641	.6299	.2347
Max	1.6575	1.8482	2.0978	1.757	2.2539
Min	.4161	.4641	.4641	.2652	.2321
Avg	.7402	.9560	1.0582	.9130	1.0612

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074019 / 33 KV JAMOD S/S

Feeder No / Name : 205 / 11 KV KARMODA GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1433	.1433	.1867	.2035	.1357
2	.1433	.1433	.1867	.2035	.1372
3	.1433	.1433	.168	.2035	.1357
4	.0716	.1433	.168	.2035	.1372
5	.1433	.1612	.2241		.1715
6	.1791	.1791	.2241		.2058
7	.2149	.2149	.3174		.2012
8	.2507	.2507	.2241		.2058
9	.2058	.2149			
10	.2058	.2058	.1791		.1791
11	.2035	.2058	.1612		.1433
12	.1715	.1696	.1433		.1433
13	.1715	.1696	.1254	.0343	.1254
14	.1715	.1372	.1254	.1372	.1254
15	.1715	.1372	.1433	.1677	.1433
16	.1478	.1341	.1433	.1715	.1433
17		.2218	.2587	.2402	.1791
18		.2614	.2614	.2587	.2149
19	.2614	.2801	.3361	.2614	.2507
20	.2241	.2614	.2987	.2427	.2149
21	.168	.2241	.2614	.2054	.1791
22	.168	.2241	.2614	.2054	
23		.2054	.2427	.1867	
24			.2054	.2241	.1372
Max	.2614	.2801	.3361	.2614	.2507
Min	.0716	.1341	.1254	.0343	.1254
Avg	.1780	.1927	.2107	.1968	.1671

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074051 / 33 KV MADAKHED S/S

Feeder No / Name : 201 / 11 KV RUDHANA FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3429	.1478	.1829	.2378
2	.3734	.3429	.1478	.2218	.2743
3	.3734	.3429	.1478	.2402	.2926
4	.3734	.362	.128	.2218	.2743
5	.5041	.362	.1848	.2402	.2561
6	.6535	.381	.2772	.2402	.2195
7	.7468	.381	.4066		.2743
8	1.1523	.381	.499	.9511	.2926
9	.2641	.4805	.2772	.2195	.3292
10	.2641	.5914	.2012	.2378	.5487
11	.2858	.7392	.1829	.2218	.6224
12	.3048	.7392	.1646	.1867	.5487
13	.2858		.1478	.1494	.4755
14	.2667		.1294	.168	.543
15	.3048	.6468	.1478	.1829	.5973
16	.3239	.6468	.1663	.1829	.6516
17	.3239		.1848	.2241	.2801
18	.3429	.3696	.2195	.2218	.3772
19	.3429	.1829	.2378	.2772	.415
20		.2195	.3475	.3696	.415
21	.3429	.2218	.3696	.4066	.3734
22	.3429		.3292	.3511	.3395
23	.362	.1463	.3109	.3292	
24	.3547	.362	.1646	.2195	.3292
Max	1.1523	.7392	.499	.9511	.6516
Min	.2641	.1463	.128	.1494	.2195
Avg	.4027	.4121	.2300	.2716	.3899

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074051 / 33 KV MADAKHED S/S

Feeder No / Name : 202 / 11 KV WADSINGHI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9335	.8954	.9145	.7316	.823
2	.924	.9145	.9145	.7865	.8048
3	1.0719	.8764	.961	.8779	.7865
4	1.0974	.8954		.905	.7682
5	1.2308	.9145	1.0719	1.0059	.7316
6	1.5927	.9335	1.1827	1.1403	.695
7	1.7551	.9526	1.5154	2.2986	.6653
8		.9526	1.4415	2.524	.695
9	.7023		.9055	.695	.8779
10	.6838	1.1458	.5304	.6584	1.8461
11	.8383	1.1458	.5487	.6036	1.6651
12	.8573		.4938	.5304	1.2308
13	.9526		.5121	.5853	.9774
14	.9907		.5304	.5121	1.1706
15	1.0288	1.4784	.5487	.5487	1.4327
16	1.0479	1.5893	.6036	.5914	1.576
17	1.0288		.6584	.6036	.8131
18	1.0669	1.2936	.7316	.695	.9335
19	.9907	1.1088	.823	.8779	1.0829
20	.9526	1.0608	.8779	.905	1.0829
21	.9145	.9979	.9145	.8688	
22	.9335		.8596	.8413	.8589
23	.9335	1.0164	.823	.823	
24	.8686	.9145	1.1273	.6516	.8048
Max	1.7551	1.5893	1.5154	2.524	1.8461
Min	.6838	.8764	.4938	.5121	.6653
Avg	1.0172	1.0603	.8474	.8859	1.0146

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074072 / 33 KV ASLGAON S/S

Feeder No / Name : 201 / 11 KV DHANORA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5335	.5335	.4382	.4763
2	.5335	.5335	.4954	.4191	.4763
3	.5335		.4382	.4191	.4763
4	.4954		.4382	.4191	.4763
5	.5144	.5335	.4572	.4572	.4763
6	.6668	.6668	.6478	.4572	.6478
7	.8383	.7811	.8002	.8299	.6478
8	.6602	.6478	.6668	.6979	.6602
9	.5316	.5658	.5487	.5487	.6413
10	.4973	.4338	.5487	.4973	.5788
11	.4115	.4481	.463	.4287	.5847
12	.3601	.3921	.3944	.3429	.415
13	.3429	.3921	.3429	.3429	.4108
14	.3601	.4481	.3258	.3258	.3961
15	.3429	.5658	.3772	.3258	.362
16	.3772	.4481	.3601	.3429	.415
17	.4835	.4887	.443	.4477	.5194
18	.7947	.7577	.7577	.7468	.8029
19	.8215	.7733	.6979	.7655	.7922
20	.7167	.7167	.679	.6859	.7167
21	.679	.6602	.6036	.6413	.679
22	.6413	.6224		.5658	.6036
23	.5716	.5716	.4763	.4954	.5144
24	.5716	.5335	.5144	.4382	.4763
Max	.8383	.7811	.8002	.8299	.8029
Min	.3429	.3921	.3258	.3258	.362
Avg	.5549	.5688	.5222	.5033	.5519

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074072 / 33 KV ASLGAON S/S

Feeder No / Name : 204 / 11 KV MAHULI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3963		.4115	.4115	
2	.3963		.381	.381	
3	.4012		.3658	.381	
4	.4268		.3612	.381	
5	.4572		.4214	.381	
6	.4902		.4843	.6104	
7	.5719		.602	.6706	
8	.8124		.7625	.7625	
9		.5281			.1143
10		.7573			.6573
11		.7775			.7095
12		.7859			.9054
13		.7573			.6222
14		.6716			.5716
15		.4458			.5851
16		.6287			.68
23		.3658	.3963		.3572
24			.4115	.4115	
Max	.8124	.7859	.7625	.7625	.9054
Min	.3963	.3658	.3612	.381	.1143
Avg	.4940	.6353	.4598	.4878	.5781

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074105 / 33/11 KV UMAPUR

Feeder No / Name : 201 / 11 KV UMAPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2936			1.2883	
2	1.307			1.3817	
3	1.4712			1.4045	
4	1.4415			1.419	
5	1.4937			1.531	
6	1.5154			1.6975	
7	1.7177			2.0165	
8	1.9044			2.1658	
9		1.1728			1.3889
10		1.6129			2.0748
11		1.8299			1.9376
12		.8383			1.5813
13		.8383			1.8501
14		.823			1.7394
15		.8383			1.8185
16		.8383			1.7553
23			1.2323		
24				1.2883	
Max	1.9044	1.8299	1.2323	2.1658	2.0748
Min	1.2936	.823	1.2323	1.2883	1.3889
Avg	1.5181	1.0990	1.2323	1.5770	1.7682

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074105 / 33/11 KV UMAPUR

Feeder No / Name : 202 / 11 KV KAHUPATTA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108		.1829	.3361	
2	.4108		.1753	.3326	
3	.4108		.1753	.3734	
4	.4481		.1829	.3696	
5	.4481		.1981	.4066	
6	.4481		.2058	.4108	
7	.4481		.1981	.4715	
8	.4344		.2134	.5228	
9		.3506			.3772
10		.5506			.5658
11		.6154			.6859
12		.3048			.578
13		.3048			.6019
14		.2591			.6167
15		.2743			.5535
16		.2743			.5218
23			.3547		
24				.3395	
Max	.4481	.6154	.3547	.5228	.6859
Min	.4108	.2591	.1753	.3326	.3772
Avg	.4324	.3667	.2096	.3959	.5626

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074105 / 33/11 KV UMAPUR

Feeder No / Name : 203 / 11 KV HANWATKHED AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3395			.8573
2		.4218			.823
3		.506			.823
4		.5535			.8745
5		.6642			.8916
6		.7116			.9088
7		1.0526			1.1317
8		1.1336			1.2003
9	.8215		.3658	.2241	
10	1.2696		.6097	1.5466	
11	1.4937		.7011	1.4918	
12	1.3279		1.7924	1.4575	
13	1.2631		1.6598	1.4746	
14	1.1843		1.6057	1.4403	
15	1.186		1.5893	1.3717	
16	1.1544		1.531	1.286	
17				1.0802	
24					.8573
Max	1.4937	1.1336	1.7924	1.5466	1.2003
Min	.8215	.3395	.3658	.2241	.823
Avg	1.2126	.6729	1.2319	1.2636	.9297

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

JALGAON JALMOD SDIV[293] BU 2933

Substation No/ Name :- 074105 / 33/11 KV UMAPUR

Feeder No / Name : 204 / 11 KV UMAPUR GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.3155	.1524	.2987	.2915
2	.3361	.2947	.1372	.2987	.2915
3	.3395	.2572	.1296	.3018	.3086
4	.3395	.2804	.1372	.2957	.3429
5	.3772	.2947	.16	.3361	.3772
6	.3734	.3012	.1981	.3395	.4287
7	.6348	.3982	.2134	.5228	.5316
8	.4435	.439	.1981	.4854	.4287
9	.4668	.4525	.2134	.2987	.4287
10	.5041	.4525	.2058	.5228	.3772
11	.4108	.3898	.2134	.4801	.3086
12	.3721	.1677	.4481	.4287	.3681
13	.3898	.16	.4108	.3944	.3681
14	.3856	.16	.3734	.3772	.3856
15	.3814	.1981	.4108	.3429	.3544
16	.4252	.1981	.4854	.4287	.3544
17	.4801	.1829	.5601	.5144	.3887
18	.5175	.1981	.5601	.5487	.4755
19	.5175	.2134	.5281	.4287	.5175
20	.4706	.1981	.4066	.3772	.3982
21	.4344	.1981	.4481	.3601	.3544
22	.3898	.1905	.3772	.3429	.333
23	.3544	.16	.3174	.1715	
24	.3734	.3544	.1524	.2987	.3086
Max	.6348	.4525	.5601	.5487	.5316
Min	.3361	.16	.1296	.1715	.2915
Avg	.4189	.2690	.3099	.3831	.3792

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074006 / 33 KV DATALA S/S

Feeder No / Name : 201 / 11 KV DATALA (SINGLE PHASE) Feeder KV- 11 / OUTGOING SINGLE PHASING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6859	.5906	.5144	.6287
2	.6097	.6859	.5906	.5335	.6097
3	.6097	.6668	.5716	.5335	.6097
4	.6287	.6859	.5716	.5525	.6287
5	.6668	.743	.6097	.6668	.743
6	.8764	.9145	.7621	.9145	.9717
7	1.2193	1.2003	1.1241	1.1431	1.1812
8	1.2193	.9145	1.3908	1.3527	.9145
9	.8383	.724	.9335	.724	.7049
10	.6097	1.3527	.724	.5716	1.2765
11	.5716	1.4289	.6287	.5716	1.467
12	.5525	1.467	.5335	.5525	1.4289
13	.5716	1.4289	.5335	.5335	.9907
14	.6097	1.3527	.5525	.5144	.9907
15	.5716	1.2955	.6097	.5144	.9907
16	.6097	1.1622	.6478	.5144	.9145
17	.6097	.6478	.5716	.5716	.5525
18	.8573	.9145	.8954	.9145	.8764
19	1.0669	1.0669	.9526	1.0669	1.0098
20	1.0479	1.0098	.9335	1.0288	1.0479
21	1.0288	.8954	.8002	.8764	.8954
22	.8954	.743	.7049	.7621	.8002
23	.7621	.5716	.5335	.6859	.5144
24	.7621	.724	.5716	.5144	.6287
Max	1.2193	1.467	1.3908	1.3527	1.467
Min	.5525	.5716	.5335	.5144	.5144
Avg	.7669	.9701	.7224	.7137	.8907

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074006 / 33 KV DATALA S/S

Feeder No / Name : 202 / 11 KV UMALI (SINGAL SINGLE PHASING
 PHASING) Feeder KV- 11 /
 OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.724	.6478	.5716	.5144
2	.6859	.7621	.6287	.5525	.4954
3	.6859	.7621	.6287	.5525	.4954
4	.6859	.8192	.6478	.5906	.5335
5	.724	.9335	.6859	.6287	.6478
6	1.0669	1.0669	.9145	.7621	.8954
7	1.1812	1.5813	1.105	1.0479	1.3527
8	1.0288	1.6194	.9907	.9717	1.6004
9	.6859	.7049	.9907	.743	.7621
10	1.9052	.5906	1.9243	1.448	.6478
11		.5716	1.9624	1.7337	
12	2.0767	.5335	1.9814	1.7718	
13	1.7147	.4954	1.8099	1.7147	.4001
14	1.2574	.4763	1.6956	1.5813	.4763
15	1.6385	.4954	1.6004	1.5623	.4954
16	1.6385	.5716	1.5813	1.5432	.5144
17	.5525	.6668	.5144	.5525	.5335
18	.8192	.8764	.8764	.8573	.8383
19	1.0098	1.0098	.8954	.9907	.9717
20	.9717	.9526	.8954	.9335	.9335
21	.9145	.9145	.7621	.8764	.8192
22	.8002	.743	.7049	.743	.743
23	.724	.6859	.6097	.5335	.6287
24	.724	.6859	.6668	.5716	.5144
Max	2.0767	1.6194	1.9814	1.7718	1.6004
Min	.5525	.4763	.5144	.5335	.4001
Avg	1.0512	.8018	1.0717	.9931	.7188

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074006 / 33 KV DATALA S/S

Feeder No / Name : 203 / 11 KV NIMBARI (SINGAL SINGLE PHASING
 PHASING) Feeder KV- 11 /
 OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.1132	.6668	.6602	.1143
2	.6097	.1132	.6478	.6413	.0953
3	.6097	.0943	.6478	.6413	.0953
4	.6097	.0943	.6668	.7545	.1334
5	.6668	.132	.743	.8488	.1524
6	.8002	.1698	.8002	.8488	.2286
7	.8954	.2075	.9717	.9242	.2286
8	.9907	.132	1.086	.9808	.1334
9	.1143	.8002	.1143	.1143	.7733
10	.0953	1.0288	.1143	.0762	.9526
11	.0953	1.1812	.1143	.0762	1.1883
12	.0762	1.2765	.0953	.0762	1.2071
13	.0762	1.2384	.0953	.0762	1.226
14	.0762	1.2003	.0953	.0762	1.2574
15	.0754	1.1431	.0762	.0762	1.2574
16	.0754	1.105	.0953	.0762	1.1128
17	.0943	.0953	.1143	.0953	.0754
18	.1509	.1715	.1524	.1905	.1509
19	.1886	.1905	.1715	.1905	.1698
20	.1698	.1715	.1524	.1715	.1698
21	.1509	.1715	.132	.1524	.1509
22	.1509	.1524	.1132	.1334	.132
23	.132	.6668	.6602	.1143	.679
24	.1524	.132	.6668	.6602	.1143
Max	.9907	1.2765	1.086	.9808	1.2574
Min	.0754	.0943	.0762	.0762	.0754
Avg	.3194	.4909	.3831	.3607	.4916

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074006 / 33 KV DATALA S/S

Feeder No / Name : 204 / 11 KV AKSHAY (EXPRESS) SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.2452	.1715	.2075	.2477
2	.2096	.2263	.1715	.1886	.2477
3	.2096	.2263	.1715	.1886	.2477
4	.2096	.2452	.1715	.1886	.2667
5	.2096	.2641	.1905	.2075	.2667
6	.1905	.2641	.1905	.2075	.2667
7	.1905	.2829	.2096	.2075	.2667
8	.2477	.2641	.2477	.2263	.2667
9	.5525	.3048	.5716	.362	.547
10	.6287	.381	.5335	.381	.6602
11	.5906	.381	.5335	.381	.6602
12	.5716	.381	.5144	.381	.6413
13	.5716	.381	.5335	.381	.6036
14	.5716	.362	.5716	.381	.6097
15	.547	.3429	.5144	.4191	.6097
16	.5093	.2477	.5144	.4191	.6224
17	.3584	.1524	.362	.3429	.4527
18	.3206	.2477	.3429	.3429	.3395
19	.3206	.1524	.3239	.3239	.3206
20	.3206	.1334	.3239	.2667	.3206
21	.3395	.1524	.2829	.2667	.3395
22	.3206	.1524	.1886	.2667	.3772
23	.2263	.1905	.2075	.2667	.2641
24	.2286	.2452	.1905	.2075	.2477
Max	.6287	.381	.5716	.4191	.6602
Min	.1905	.1334	.1715	.1886	.2477
Avg	.3606	.2594	.3347	.2921	.4039

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074006 / 33 KV DATALA S/S

Feeder No / Name : 205 / 11 KV JAMBHULDHABA (SINGAL SINGLE PHASING
PHA Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.2858	.4572	.4001	.2667
2	.4191	.2858	.4382	.4001	.2477
3	.4191	.2667	.4382	.4191	.2477
4	.4191	.2858	.4572	.4382	.2667
5	.4572	.3239	.4763	.4763	.3429
6	.5716	.381	.5144	.5144	.5335
7	.6478	.4763	.6287	.5716	.5335
8	.7049	.3239	.6478	.6287	.362
9	.2858	.4572	.3048	.2667	.4572
10	.2477	.6859	.2667	.2286	.7049
11	.2477	.7049	.2667	.2286	.7049
12	.2477	.724	.2667	.2477	.6478
13	.2667	.6859	.2667	.2286	.5906
14	.2858	.6668	.2667	.2286	.6668
15	.3048	.6668	.2858	.2286	.743
16	.3048	.6478	.2858	.2858	.6668
17	.3048	.2286	.2286	.2477	.2667
18	.381	.4001	.4191	.4191	.4001
19	.4763	.4954	.4763	.4954	.4191
20	.4572	.4763	.4572	.4763	.4572
21	.4572	.4382	.381	.4191	.381
22	.362	.381	.3239	.3429	.3429
23	.3239	.4572	.4382	.2858	.4191
24	.3239	.3048	.4572	.4191	.2667
Max	.7049	.724	.6478	.6287	.743
Min	.2477	.2286	.2286	.2286	.2477
Avg	.3890	.4604	.3937	.3707	.4556

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074007 / 33 KV DASARKHED S/S

Feeder No / Name : 201 / 11 KV RAMTHAM AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1186	1.6194	1.2936	1.4737	1.1869
2	2.1033	1.8623	1.2936	1.4899	1.1603
3	2.0729	1.9595	1.267	1.4899	1.1603
4	2.0576	2.0729	1.267	1.4899	1.1603
5	2.1033	2.0309	1.267	1.5223	1.1736
6	2.1643	2.17	1.2403	1.587	1.1736
7	2.2862	2.2996	1.2536	1.6194	1.1736
8	2.2862	2.3967	1.307	1.6842	1.1069
9	1.7814	1.8461	1.9204	2.4615	1.9814
10	1.9757	2.0081	2.1862	.9602	2.652
11	1.9757	2.0405	2.2672	.9869	2.713
12	2.0081		1.6518	.9869	2.7435
13	1.9757	2.0243	3.0121	.9869	2.753
14	1.9919	2.0729	2.9797	.9869	2.8826
15	1.9757	2.1052	2.9473	2.4006	2.753
16	1.9919	2.0081	2.915	2.4006	2.5911
17	.0648	.081	.0648	1.307	.0972
18	.0648	.0762	.0648	1.2403	.0648
19	.0972	.0914	.081	1.2003	.081
20	.081	.0914	.0648	.0762	
21	.0648	.0762	.0648	.0762	
22	.0648	.061	.0648	.0762	
23	.0648	1.2936	1.3765	1.1736	
24	.0762	.0648	1.2936	1.4575	1.1736
Max	2.2862	2.3967	3.0121	2.4615	2.8826
Min	.0648	.061	.0648	.0762	.0648
Avg	1.3936	1.4066	1.3810	1.2973	1.5891

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074007 / 33 KV DASARKHED S/S

Feeder No / Name : 205 / 11 KV RANTHAM GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1619	1.5337	.181	.9755
2	.1219	.1619	1.5337	.181	.9602
3	.1524	.1781	1.5337	.181	.945
4	.2134	.2429	1.547	.181	.9907
5	.2591	.4534	1.547	.2534	.9907
6	.3201	.4372	1.5737	.4344	.9069
7	.3963	.4534	1.9204	.543	1.0269
8	.3963	.3887	1.6404	.4344	1.0669
9	1.5432	1.8623	.3353	.3401	.3353
10	2.1605	2.0243	.3239	.2743	.2743
11	2.1776	2.1948	.2915	.2439	.2429
12	2.2119	2.17	.2429	.2286	.1943
13	2.0729	2.4072	.2267		.2105
14	2.1605	2.2977	.2105		.2105
15	2.1262	2.3148	.2591		.2429
16	2.0919	2.2291	.2591	.2896	.2591
17	.362	.3258	.3239	.3353	.3401
18	.421	.3201	.3563	.381	.4534
19	.4534	.381	.4525	.4115	.421
20	.421		.3982	.3048	
21	.3239	.3048	.3258	.2286	
22	.2105	.1981	.2715	.1981	
23	.1943	1.5546	.1715	.945	
24	.1372	.1781	1.4803	.181	.9755
Max	2.2119	2.4072	1.9204	.945	1.0669
Min	.1219	.1619	.1715	.181	.1943
Avg	.8777	1.0104	.7816	.3215	.6011

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074007 / 33 KV DASARKHED S/S

Feeder No / Name : 207 / 11 KV DUPESHWAR W/S NON SHEDDABLE WATER SUPPLY AND
EXPRESS. Feeder KV- 11 / UTILITY
OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0972			
2			.0762		
3			.0762		
4			.0762		
5			.0762		
6	.0762		.0762	.081	.0762
7	.0762	.081	.0762	.0972	.0762
8	.0762	.081	.0762	.081	.0762
9	.0857	.081	.0762	.081	.0762
10	.081	.081	.081	.0762	.0762
11	.0857	.081	.081	.0762	.0762
12	.0857	.081	.081	.0762	.0762
13	.081	.081	.081	.0762	.081
14	.081	.081	.081	.0762	.081
15	.081	.081	.081	.0762	.081
16	.081	.081	.081	.0762	.081
17	.081	.0972	.081	.0914	.0972
18	.0972	.0914	.081	.0914	.0972
19	.0972	.0914	.0972	.0914	.0972
20	.0972	.0914	.0972	.0762	
21	.0972	.0914	.0972	.0914	
22	.0972	.0914	.0972	.0914	
23	.0972	.0914	.0972	.0914	
24		.0972	.0762		
Max	.0972	.0972	.0972	.0972	.0972
Min	.0762	.081	.0762	.0762	.0762
Avg	.0864	.0868	.0826	.0832	.0821

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074007 / 33 KV DASARKHED S/S

Feeder No / Name : 409 / 33 KV BIRLA COTSAN EXP NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0119	2.1862	2.0119	2.2634	1.8747
2	1.8747	2.1862	2.0576	2.2119	1.9662
3	1.9662	2.1376	2.0119	2.2119	2.0119
4	2.0119	2.1376	1.9662	2.1605	2.0119
5	2.0576	2.2348	1.9662	2.1605	2.0576
6	2.1033	2.2348	2.0119	2.2119	2.0119
7	2.0576	2.0891	2.0576	2.3663	1.9662
8	1.9204	2.0891	1.829	2.1605	1.7833
9	2.2634	2.1376	1.829	2.1605	2.1862
10	2.2119	1.8947	2.1862		2.0405
11	2.1605	2.0405	2.1376		1.9433
12	2.3148	2.1862	2.0891		2.0405
13	2.1605	2.2634	2.2348		1.9919
14	2.2119	2.2634	2.332		2.0891
15	2.2634	2.1862	2.1862	1.5546	2.1376
16	2.3148	2.2119	1.9919	1.829	2.0405
17	2.2119	2.2634	2.2348	1.8747	2.1376
18	2.1376	1.9662	2.3148	1.9204	2.2348
19	2.1376	1.8747	2.0062	2.0119	1.9919
20	1.8947	1.9204	1.9547	1.9662	
21	2.0405	1.9662	2.0062	1.829	
22	1.9433	1.8747	2.0576	1.8747	
23	1.9433	1.8747	2.1605	1.9662	
24	2.0576	2.0405	1.9662	2.3148	1.9204
Max	2.3148	2.2634	2.332	2.3663	2.2348
Min	1.8747	1.8747	1.829	1.5546	1.7833
Avg	2.0946	2.0942	2.0667	2.0552	2.0219

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074046 / 33 KV MALKAPUR S/S

Feeder No / Name : 201 / 11 KV HARIKIRAN MLK SHEDDABLE URBAN
 SDN(2887) Feeder KV- 11 /
 OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0207	.0189	.0171	.0189	.0207
2	.0207	.0189	.0171	.0189	.0207
3	.0207	.0189	.0171	.0191	.0207
4	.0207	.0189	.0171	.021	.0207
5	.0207	.0207	.0171	.0229	.0207
6	.0264	.0264	.0229	.0248	.0261
7	.0283	.0302	.0283	.0321	.0317
8	.0321	.034	.0283	.0302	.0321
9	.0321	.0296	.0299	.0317	.0277
10	.0299	.0296	.028	.0277	.028
11	.0277	.0296	.028	.0259	.028
12	.0277	.0311	.0259	.0238	.0274
13	.0277	.0277	.0259	.0238	.0256
14	.0259	.0277	.024	.0235	.024
15	.0259	.0277	.024	.024	.0277
16	.0277	.0261	.0222	.024	.0274
17	.0293	.0274	.0277	.0274	.0274
18	.037	.0351	.0317	.0351	.0355
19	.0355	.0355	.0302	.0336	.0333
20	.0317	.0317		.0317	.0317
21	.0299	.0277	.028	.0277	.028
22	.028	.0245	.0261	.024	.0243
23	.0264	.021	.0226	.0203	.0207
24	.0205	.0207	.0171	.0189	.0207
Max	.037	.0355	.0317	.0351	.0355
Min	.0205	.0189	.0171	.0189	.0207
Avg	.0272	.0267	.0242	.0255	.0263

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074046 / 33 KV MALKAPUR S/S

Feeder No / Name : 202 / 11 KV PRASHANT NAGAR MLK SHEDDABLE URBAN
SDN(2 Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0131	.0132	.0132	.0171	.0113
2	.0131	.0113	.0132	.0152	.0113
3	.0131	.0113	.0132	.0152	.0113
4	.0131	.0113	.0132	.0171	.0113
5	.0131	.0113	.0132	.0171	.0113
6	.0168	.0132	.017	.0171	.0151
7	.0168	.0151	.0224	.021	.0207
8	.0168	.017	.0245	.0191	.0207
9	.0168	.0168	.0205	.0171	.0151
10	.0166	.0203	.0205	.0131	.017
11	.0185	.0201		.0112	.017
12	.0185	.0201	.0168	.0111	.0132
13	.0166	.0133	.0168	.0092	.0132
14	.0129	.0133	.0149	.0092	.0132
15	.0112	.0133	.0149	.0093	.0113
16	.0112	.0133	.0149	.0093	.0113
17	.0131	.0199	.0201	.0111	.0128
18	.0187	.0185	.017	.0148	.0166
19	.017	.0187	.017		.0166
20	.0151	.0151	.0151	.0149	.0187
21	.017	.0205	.0205	.0149	.0187
22	.0151	.017	.0189	.0131	.0187
23	.0132	.0151	.0189	.0112	.017
24	.0131	.0132	.0132	.017	.0112
Max	.0187	.0205	.0245	.021	.0207
Min	.0112	.0113	.0132	.0092	.0112
Avg	.0150	.0155	.0170	.0141	.0148

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074046 / 33 KV MALKAPUR S/S

Feeder No / Name : 203 / 11 KV WATER FILTTER EXP NON SHEDDABLE WATER SUPPLY AND
MLK S Feeder KV- 11 / OUTGOING UTILITY

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0074	.0132	.0453	.0114	.0129
2	.0074	.0132	.0113	.0114	.0129
3	.0074	.0453	.0113	.0133	.0129
4	.0074	.0453	.0472	.0133	.0127
5	.0074	.0434	.0434	.0133	.0127
6	.0074	.0113	.0113	.0448	.0161
7	.0467	.0113	.0453	.0448	.0512
8	.0467	.049	.0547	.0536	.0457
9	.0467	.0425	.056	.053	.0421
10	.048	.0517	.0591	.0536	.0499
11	.0517	.053	.0257	.0573	.048
12	.0536	.0517	.0425	.0585	.048
13	.0149	.053	.0425	.0512	.0476
14	.0517	.0536	.0425	.0439	.0444
15	.048	.0444	.0425	.0259	.0444
16	.0517	.0444	.0103	.0444	.0444
17	.0536	.053	.0462	.0421	.0402
18	.0536	.0517	.0457	.0494	.0425
19	.056	.0541	.0444	.0549	.0517
20	.0113	.0504	.0476	.0501	.0504
21	.0448	.0517	.0439	.043	.0448
22	.0448	.0523	.0439	.0494	.0504
23	.0434	.0547	.0133	.0494	.0448
24	.0075	.0472	.0472	.0133	.0129
Max	.056	.0547	.0591	.0585	.0517
Min	.0074	.0113	.0103	.0114	.0127
Avg	.0341	.0434	.0385	.0394	.0368

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074046 / 33 KV MALKAPUR S/S

Feeder No / Name : 401 / 33 kv incommer APDRP
Feeder KV- 33 / INCOMINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0336	.034	.034	.0392	.034
2	.0336	.034	.034	.0392	.034
3	.0336	.034	.034	.0396	.034
4	.0336	.034	.034	.0396	.034
5	.0336	.034	.034	.0453	.034
6	.0448	.0396	.0396	.0453	.0396
7	.0448	.0453	.0504	.0566	.0566
8	.0504	.0509	.056	.0509	.056
9	.0504	.0499	.0554	.0504	.0444
10	.0494	.0549	.0494	.0444	.0499
11	.0489	.0543	.0274	.0388	.0499
12	.0489	.0543	.0434	.0384	.0439
13	.0434	.0444	.0434	.0329	.0439
14	.0384	.0444	.038	.0329	.0388
15	.0384	.0444	.038	.0333	.0384
16	.0388	.0448	.0384	.0333	.0439
17	.0434	.0484	.0489	.0384	.0434
18	.0554	.0549	.0499	.0494	.0549
19	.056	.0554	.0504	.0329	.0549
20	.0504	.0504	.0504	.0504	.0499
21	.0504	.0499	.0494	.0444	.0444
22	.0448	.0448	.0444	.0392	.0444
23	.0392	.0396	.0392	.0336	.0392
24	.0336	.034	.034	.0392	.034
Max	.056	.0554	.056	.0566	.0566
Min	.0336	.034	.0274	.0329	.034
Avg	.0432	.0448	.0423	.0412	.0434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074054 / 33 KV BELAD S/S

Feeder No / Name : 201 / 11 KV ANKUR INDUSTRIAL
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	.9145	.6668	.8059	.4954
2	.9526	.9145	.6668	.7545	.4954
3	.9526	.8383	.6668	.7716	.5335
4	.9526	.8383	.6478	.7545	.5144
5	.9526	.8764	.6859	.7373	.5335
6	.9526	.9335	.7621	.6859	.5716
7	.9145	.9526	.8573	.6173	.5906
8	.8764	.9526	.9717	.4973	.5716
9	1.1831	1.3336	.9907	.5525	.9259
10	1.2003	1.4289	1.0479	.5525	1.166
11	1.1831	1.3336	1.0288	.5144	1.1317
12	1.0974	1.3336	.9602	.4763	1.0802
13	1.0288	1.3336	.9602	.4763	.9945
14	.9602	1.3336	1.0288	.4763	1.1145
15	1.1831	1.4861	.9774	.4572	1.0974
16	1.2517	1.3336	1.0288	.4763	1.2955
17	1.3336	1.1431	1.0802	.4572	1.2384
18	.6097	1.2193	.7202	.4572	1.1431
19	.9526	1.1812	.7373	.5144	1.1812
20	1.0288	1.0669	.6859		1.2003
21	1.0288	.9145	.7716	.4572	1.2003
22	1.0098	.9526	.8402	.4954	1.2193
23	.9526	.8764	.8059	.4954	
24	.9526	.9145	.6859	.823	.4954
Max	1.3336	1.4861	1.0802	.823	1.2955
Min	.6097	.8383	.6478	.4572	.4954
Avg	1.0193	1.1002	.8448	.5785	.9039

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074054 / 33 KV BELAD S/S

Feeder No / Name : 202 / 11 KV GHIRNI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.2667	.0953	.0686	.4763
2		.3048	.0953	.0686	.4763
3	.0953	.3048	.0953	.0686	.4763
4	.0953	.3429	.0953	.0686	.5716
5	.1143	.5716	.1143	.0857	.5716
6	.1143	.7621	.1334	.0857	.5716
7	.0953	.8383	.1334	.1029	.7049
8	.0953	.8954	.1524	.1029	.9526
9	.4973		.9526	.2286	
10	.9602		.9526	.7468	
11	1.0117		1.1431	.7164	
12	.9945		1.0288	.7926	
13	.9602		1.0288	.7621	
14	.9431		.9774	.7773	
15	.8573	.0762	.9259	.7011	.0686
16	.9088	.0762	.9088	.7468	.0953
17	.0953	.0953	.0514	.0762	.0953
18	.1143	.1524	.0857	.1334	.1334
19	.0953	.1334	.1029	.1143	.1334
20	.0953	.1334	.1029	.0953	.1143
21	.0953	.1143	.0857	.0953	.1143
22	.0762	.0953	.0857	.0953	.0953
23	.0762	.0953	.0686	.2858	
24	.0953	.0762	.0953	.0686	.381
Max	1.0117	.8954	1.1431	.7926	.9526
Min	.0762	.0762	.0514	.0686	.0686
Avg	.3731	.2964	.3963	.2953	.3548

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074054 / 33 KV BELAD S/S

Feeder No / Name : 203 / 11 KV GHIRNI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2477	.2286	.2401	.381
2	.2858	.2667	.2096	.2572	.381
3	.2858	.2667	.1905	.2058	.381
4	.2858	.2667	.1905	.2058	.3429
5	.3048	.2858	.2286	.2572	.3048
6	.3239	.3048	.2743	.2915	.3048
7	.3429	.2858	.3086	.2743	.2477
8	.3048	.3048	.3429	.3086	.2286
9	.2401	.3239	.3429	.2743	.2058
10	.2743	.3048	.3429	.2572	.2743
11	.2572	.2667	.2858	.2477	.2572
12	.2401	.2477	.2401	.2096	.2743
13	.2401	.2096	.2401	.1334	.2572
14	.2229	.1905	.2401	.1334	.2229
15	.2229	.2477	.1715	.2572	.2401
16	.2572	.2477	.1886	.2743	.2572
17	.3048	.3086	.2229	.362	.2401
18	.362	.3772	.3258	.4572	.3772
19	.3429	.3601	.3429	.381	.3429
20	.3048	.3429	.3258	.3429	.3086
21	.2858	.3086	.3086	.3429	.2572
22	.2667	.2743	.2572	.381	.2477
23	.2667	.2572	.2058	.3429	
24	.2858	.2477	.2477	.2058	.3239
Max	.362	.3772	.3429	.4572	.381
Min	.2229	.1905	.1715	.1334	.2058
Avg	.2831	.2810	.2609	.2768	.2895

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074054 / 33 KV BELAD S/S

Feeder No / Name : 204 / 11 KV Waghul Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.0762	.4115	.463	.0953
2	.5716	.0762	.4115	.4458	.0953
3	.5716	.0762	.4115	.463	.0953
4	.6097	.0953	.4115	.5144	.0953
5	.6859	.0953	.503	.6173	.0762
6	.9526	.0953	.5944	.823	.0762
7	1.2955	.1143	.9602	.9602	.0762
8	1.7147	.1143	1.2498	1.1145	.0953
9		.8573			.5658
10		1.4289			1.4746
11		1.5242			1.6289
12		1.6385			1.6975
13		1.7147			1.4746
14		1.7147			1.3889
15	.0857	1.6004	.0686	.1905	1.1488
16	.1029	1.6766	.0857	.0953	1.2193
17	.1143		.1029	.1143	
18	.1143		.1029	.4954	
19			.1029	.0953	
20	.1143		.0857	.0953	
21	.0953		.0857	.0953	
22	.0762		.0857	.0953	
23	.0762	.3658	.4115	.0953	
24		.0762	.2572	.4115	.0953
Max	1.7147	1.7147	1.2498	1.1145	1.6975
Min	.0762	.0762	.0686	.0953	.0762
Avg	.4845	.7411	.3523	.3992	.6705

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074091 / 33 KV SALIPURA SUB STATION

Feeder No / Name : 201 / 11KV SHIVAJI NAGAR MLK SHEDDABLE URBAN
SDN(288 Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5359	.5359	.5544	.439	.5175
2	.5359	.5359	.5544	.439	.5175
3	.5304		.7392	.4344	.5175
4	.5304	.5359	.7577	.439	.5175
5	.5853	.5914	.7762	.4755	.5544
6	.7316	.7392	.8316	.6335	.6653
7	.823	.8131	.8316	.7316	.9425
8	.8779	.7577	.8316	.724	.8131
9	.8131	.6468	.7499	.6283	.7207
10	.7577	.5914	.6219	.5914	.6653
11	.8131	.5729	.7316		.6099
12	.8316	.5544	.6767	.6283	.6283
13	.8686	.5729	.5121	.499	.5544
14	.5729	.499	.4938	.4805	.5359
15	.5544	.6099	.499	.462	.4805
16	.5544	.5914	.567	.4805	.5359
17	.5914	.6283	.6036	.5544	.6468
18	.8501	.8871	.7947	.7577	.8316
19	.8871	.8131	.7682	.7947	.924
20	.7947	.7392	.7316	.7392	.7207
21	.7762	.7207	.695	.7207	.6697
22	.7392	.7392	.6036	.6653	.6468
23	.6653	.6468	.567	.5914	
24	.567	.5729	.5544	.4572	.5175
Max	.8871	.8871	.8316	.7947	.9425
Min	.5304	.499	.4938	.4344	.4805
Avg	.6995	.6476	.6686	.5812	.6406

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074091 / 33 KV SALIPURA SUB STATION

Feeder No / Name : 202 / 11 KV MANGAL GATE MLK SHEDDABLE URBAN
 SDN(2887 Feeder KV- 11 /
 OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4887	.4887	.5068	.3982	.4887
2	.4706	.4706	.5068	.3982	.4887
3	.4706	.4706	.5249	.3982	.4887
4	.4706	.4706	.543	.3982	.4887
5	.5068	.5068	.5792	.4163	.5611
6	.5611	.5611	.6154	.5373	.6516
7	.724	.6697	.6335	.6878	.7783
8	.7602	.7059	.7602	.7421	.724
9	.724	.6516	.724	.6154	.6516
10	.7059	.6154	.6697	.5792	.6154
11	.6697	.6154	.6878	.5068	.5792
12	.6335	.6154	.6878	.6154	.5611
13	.6878	.6154	.4887	.5068	.5611
14	.5249	.6878	.4706	.5068	.543
15	.5068	.5611	.4706	.5068	.5249
16	.5068	.5611	.5068	.5249	.543
17	.5792	.5973	.543	.5792	.5792
18	.7964	.8145	.7682	.6878	.7421
19	.8145	.724	.724	.724	.8326
20	.7602	.724	.6878	.724	.6878
21	.724	.6516	.6516	.7059	.6697
22	.6878	.6516	.5973	.6335	.6335
23	.6154	.543	.543	.5792	
24	.5249	.5249	.5068	.4525	.5068
Max	.8145	.8145	.7682	.7421	.8326
Min	.4706	.4706	.4706	.3982	.4887
Avg	.6214	.6041	.5999	.5594	.6044

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074091 / 33 KV SALIPURA SUB STATION

Feeder No / Name : 203 / 11 KV YASHODHAM MLK SHEDDABLE URBAN
 SDN(2887) Feeder KV- 11 /
 OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.1991	.2172	.181	.2172
2	.181	.1991	.2172	.181	.2172
3	.181	.1991	.2353	.181	.2172
4	.181	.1991	.2534	.181	.2172
5	.2172	.2353	.3258	.2172	.2534
6	.2715	.3258	.3982	.2686	.2896
7	.3801	.4887	.3982	.4344	.4163
8	.4163	.4525	.4887	.4706	.4344
9	.3982	.4344	.543	.4525	.3982
10	.362	.3982	.5249	.4344	.3258
11	.362	.3801	.4706	.3982	.3077
12	.3801	.3982	.3982	.3077	.3077
13	.3801	.3982	.362	.2896	.2715
14	.3077	.3439	.2896	.2896	.2353
15	.3077	.3258	.3258	.2896	.2534
16	.3077	.3258	.362	.3439	.2715
17	.362	.362	.3982	.362	.2715
18	.4344	.3982	.4344	.3982	.362
19	.4344	.3258	.4163	.3439	.3801
20	.3801	.3077	.362	.3439	.362
21	.3439	.2896	.3258	.3439	.3077
22	.3077	.2896	.2715	.2896	.2896
23	.2534	.2534	.2353	.2534	
24	.2172	.2172	.2172	.2172	.2172
Max	.4344	.4887	.543	.4706	.4344
Min	.181	.1991	.2172	.181	.2172
Avg	.3145	.3228	.3530	.3114	.2967

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074091 / 33 KV SALIPURA SUB STATION

Feeder No / Name : 401 / 33 kv Incomer Salipura MLK NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 33 / INCOMING UTILITY

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3306	1.3032	1.3169	1.0974	1.3032
2	1.3169	1.3032	1.3169	1.0974	1.3032
3	1.3169	1.3032	1.4266	1.0974	1.3032
4	1.3169	1.3032	1.5364	1.0974	1.3032
5	1.4266	1.4118	1.6461	1.2071	1.5203
6	1.7558	1.7375	1.6461	1.5203	1.8461
7	2.0851	2.0633	1.6461	1.9753	2.2262
8	2.1948	2.009	2.1948	2.0633	2.1176
9	2.0633	1.9204	2.0851	1.7918	1.9547
10	1.9004	1.7558	1.9753	1.7375	1.5364
11	1.9004	1.6461	2.0851	.9774	1.6461
12	1.9004	1.6461	1.8656	1.6832	1.5364
13	2.009	1.6461	1.4815	1.4118	1.4266
14	1.5203	1.6461	1.4266	1.4118	1.3169
15	1.5203	1.5364	1.4266	1.3575	1.3169
16	1.5203	1.5364	1.4815	1.4118	1.3169
17	1.5746	1.6289	1.6461	1.5203	1.6461
18	2.1719	2.1948	2.1399	2.009	1.9753
19	2.2262	1.9753	2.0851	2.009	2.1948
20	2.0633	1.8656	1.9753	1.9547	1.8656
21	1.9547	1.7558	1.7558	1.8461	1.7558
22	1.7918	1.7558	1.5912	1.6289	1.6461
23	1.6289	1.4266	1.3717	1.4661	
24	1.4266	1.4118	1.3169	1.2071	1.3032
Max	2.2262	2.1948	2.1948	2.0633	2.2262
Min	1.3169	1.3032	1.3169	.9774	1.3032
Avg	1.7465	1.6576	1.6850	1.5242	1.6244

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074100 / 33KV JAMBHULDHABA SUBSTATION

Feeder No / Name : 202 / 11 KV LONWADI SINGLE PHASING
 FEEDER(SINGLE PH Feeder KV- 11 /
 OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.1886	.4572	.5335	.112
2	.5716	.1886	.5144	.5335	.112
3	.5716	.1886	.5144	.5525	.112
4	.6097	.1886	.5144	.5525	.112
5	.6859	.2075	.6173	.5525	.1494
6	.8002	.2263	.6097	.5716	.2427
7	.9526	.1886	.7316	.8002	
8	.9069	.1698	.823	.8764	
9	.1132	.3658	.1143	.1029	
10	.0943	.9602	.1143	.0686	
11	.0754	.9297	.0953	.0514	
12	.0754	.884	.0762	.0514	
13	.0754	.7773	.0762	.0343	1.1843
14	.0747	.884	.0762	.0514	1.1523
15	.0747	.9145	.0762	.0686	1.1203
16	.0747	.8535	.0762	.0686	1.0402
17	.1132	.0857	.1143	.1029	.1478
18	.1509	.1715	.1524	.1372	.1867
19	.1886	.2229	.2667	.2058	.1867
20	.2075	.2229	.2286	.2229	.2263
21	.2427	.2229	.1905	.2058	.2452
22	.2263	.2058	.1715	.1715	
23	.2075	.4572	.5525	.1715	
24	.2096	.2075	.5144	.5335	.1372
Max	.9526	.9602	.823	.8764	1.1843
Min	.0747	.0857	.0762	.0343	.112
Avg	.3265	.413	.3199	.3009	.4042

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074100 / 33KV JAMBHULDHABA SUBSTATION

Feeder No / Name : 203 / 11 KV KHAMKHED SINGLE PHASING
 FEEDER(SINGLE P Feeder KV- 11 /
 OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0943	.0514	.0572	.0747
2	.0572	.0943	.0514	.0572	.0747
3	.0572	.0943	.0514	.0572	.0747
4	.0762	.0943	.0686	.0572	.0747
5	.0762	.1132	.0914	.0572	.112
6	.0762	.1698	.1219	.0762	.1494
7	.0953	.1886	.1219	.1143	
8	.1457	.1132	.1524	.1905	
9	.0754	.0686	.1143	.0686	
10	.0754	.1886	.0762	.0686	
11	.0754	.1524	.0762	.0514	
12	.0566	.1219	.0572	.0514	
13	.0566	.1219	.0572	.0343	.2401
14	.056	.1219	.0572	.0514	.2401
15	.0747	.1372	.0572	.0686	.2241
16	.0934	.1219	.0572	.0686	.192
17	.0943	.0857	.0762	.0686	.0934
18	.132	.1372	.0953	.1029	.1307
19	.1509	.1372		.1372	.168
20	.1509	.1372	.1524	.1372	.1698
21	.1494	.12	.1334	.1372	.132
22	.132	.1029	.1143	.1029	
23	.1132	.0686	.0572	.1029	
24	.1143	.1132	.0514	.0572	.0686
Max	.1509	.1886	.1524	.1905	.2401
Min	.056	.0686	.0514	.0343	.0686
Avg	.0934	.1208	.0845	.0823	.1387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MALKAPUR S/DN.[288] BU 2887

Substation No/ Name :- 074100 / 33KV JAMBHULDHABA SUBSTATION

Feeder No / Name : 401 / 33 KV INCOMER TO NON SHEDDABLE WATER SUPPLY AND
 JAMBHULDHABA Feeder KV- 33 / UTILITY
 INCOMING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5887	.1629	.4572	.6001	.1086
2	.623	.1575	.4572	.6059	.1086
3	.6287	.1575	.571	.6059	.1195
4	.6802	.1536	.5075	.6059	.1303
5	.7716	.2195	.6127	.6059	.19
6	.8573	.2634	.5624	.6287	.2335
7	1.0517	.2743	.9208	.9202	
8	1.2217	.1811	1.0151	1.1145	
9	.1412	.6842	.16	.1286	
10	.0823	1.2294	.1086	.1132	
11	.0768	1.1385	.0972	.0772	
12	.076	1.1065	.0857	.0669	
13	.0814	1.0105	.0857	.0823	1.39
14	.0814	1.0517	.0914	.0874	1.3717
15	.0977	1.1157	.0914	.0823	1.2529
16	.1086	1.0471	.0972	.0926	1.2346
17	.1086	.1097	.1315	.1132	.1303
18	.1738	.1698	.1543	.1903	.1846
19	.2063	.2006	.2401	.216	.2335
20	.2063	.1955	.2058	.2006	.2085
21	.203	.1698	.1658	.1749	.1866
22	.2009	.144	.1429	.1337	
23	.1955	.5761	.6059	.1132	
24	.1486	.19	.5144	.6001	.1029
Max	1.2217	1.2294	1.0151	1.1145	1.39
Min	.076	.1097	.0857	.0669	.1029
Avg	.3588	.4879	.3367	.3400	.4491

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074021 / 33 KV SUB STATION KINHOLA

Feeder No / Name : 201 / 11 KV TAPOWAN AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3391			.3052	
2	.3429		.4108	.3391	
3	.3391		.4435	.407	
4	.3391		.4435	.407	
5	.0339		.3734	.407	
6	.3391		.2587	.407	
7	.4409		.3961	.407	
8	.4409		.5175	.407	
9					.7392
10					.7392
11		.9979			.8501
12		1.0164			.9425
13		.961			.8962
14		.8316			.7023
15		.7842			.7392
16		.7095			.6653
23		.2241	.2743		
24			.3361	.3052	
Max	.4409	1.0164	.5175	.407	.9425
Min	.0339	.2241	.2587	.3052	.6653
Avg	.3269	.7892	.3838	.3768	.7843

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074021 / 33 KV SUB STATION KINHOLA

Feeder No / Name : 202 / 11 kv panhera ag feeder SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1017	.5228	.0924	.0848	.0848
2	.1017	.7023	.0924	.0848	.0848
3	.1017	.7842	.0934	.0848	.0848
4	.1017	.8871	.0924	.0678	.0848
5	.1017	.9979	.0924	.0678	.0848
6	.1017	1.0349	.0924	.0678	.0848
7		1.2567			1.0174
8		1.419			1.2378
9	.8478	.5175	.8871	1.3565	
10	1.0174		.8139	1.3565	
11	2.0119		.9496	1.4582	
12	2.3411		.9496	1.5261	
13	2.4394		.9835	1.5261	
14	2.4764		1.0174	1.5261	
15	2.4874		1.0174	1.5261	
16	2.0328		.8478	1.5261	
19	.1478	.0924			.112
20	.1663	.0934	.0848	.0848	.1109
21	.1494	.0934	.1017	.0848	.1307
22	.1494	.0934	.0848	.0848	.1307
23	.1494	.0924	.0848	.0848	
24	.1017	.1494	.0934	.0848	.0848
Max	2.4874	1.419	1.0174	1.5261	1.2378
Min	.1017	.0924	.0848	.0678	.0848
Avg	.8564	.5825	.4459	.6676	.2564

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074021 / 33 KV SUB STATION KINHOLA

Feeder No / Name : 203 / 11 kv D,badhe ag feeder SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6783	.5914	.8131	.6783	.6783
2	.6783	.5914	.8131	.78	.7122
3	.6783	.5914	.7762	.8139	.7122
4	.6783	.6283	.7842	.8478	.7461
5	.6783	.5914	.7655	.8478	.7461
6	.6783	.6348	.7392	.8478	.7461
7	.6104	.7167	.7468	.8478	.6783
8	.6783	.8215	1.0829	.8478	.8478
9	1.0174	1.0562	1.1949	1.0174	1.0174
10	1.0174	1.1203	1.0852	1.1869	1.1088
11	1.3306	1.3676	1.0852	1.1869	1.3676
12	1.4415	1.4937	1.0852	1.1869	1.4784
13	1.3306	1.4563	1.0852	1.3565	1.5524
14	1.2567	1.4937	1.0852	1.3565	1.4937
15	1.3306	1.3306	1.0852	1.2887	
16	1.419	1.2696	1.0852	1.2887	1.2567
17	1.2696	1.0456	1.0852	1.2887	1.0164
18	.9979	.8962	.9496	1.1869	.7762
19	.924	.6722	.9156	1.0174	.7023
20	.8215	.6722	.8478	1.0174	.6653
21	.7762	.6722	.763	.9496	.5914
22		.6722	.6783	.6104	.5914
23	.6722	.8131	.6783	.6783	
24	.6783		.7762	.6783	.6783
Max	1.4415	1.4937	1.1949	1.3565	1.5524
Min	.6104	.5914	.6783	.6104	.5914
Avg	.9410	.9217	.9169	.9919	.9165

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074021 / 33 KV SUB STATION KINHOLA

Feeder No / Name : 204 / 11 kv D,Badhe GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.407	.4904	.4854	.4748	.5087
2	.5087	.4914	.4854	.5087	.5426
3	.6104	.4904	.4854	.6104	.5426
4	.78	.5658	.5281	.6783	.6104
5	.9496	.8215	.7922	.78	.6783
6	1.1191	.9997	1.0185	.8478	.9496
7	1.0852	1.0185	1.226	.8817	1.0852
8	1.0174	1.0562	1.094	.9156	.9156
9	.8478	.8589	.8775	.8139	.7461
10	.7122	.7499	.6783	.7122	.7392
11	.7167	.7167	.6783	.6104	.6653
12	.7167	.5228	.6104		.5175
13	1.2449	.4854	.5765	.5087	.4805
14	.6979	.5788	.4917	.4748	.4854
15	.6584	.5658	.5087	.5087	.5281
16	.6348	.5847	.5087	.5426	.5544
17	.7545	.7655	.5087	.6783	.6722
18	1.0751	.8215	.5087	.9835	1.0082
19	.9808	1.0082	.4748	1.1191	1.094
20	.7468	.8962	.6443	1.0174	.8676
21	.6722	.7468	.6443	.8478	.7095
22	.6535	.679	.4578	.5596	
23	.5601	.6036	.4748	.5087	
24	.4409	.5281	.5281	.4801	.4748
Max	1.2449	1.0562	1.226	1.1191	1.094
Min	.407	.4854	.4578	.4748	.4748
Avg	.7746	.7102	.6369	.6984	.6989

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074021 / 33 KV SUB STATION KINHOLA

Feeder No / Name : 205 / 11 KV PANHERA GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3391	.2641	.2641	.2374	.2713
2	.4409	.2641	.3018	.3391	.3391
3	.5087	.3018	.3018	.4409	.407
4	.6104	.3772	.3395	.5087	.4748
5	.7461	.5281	.5228	.5765	.5765
6	.7461	.7167	.6979	.6104	.6443
7	.7461	.679	.8215	.6783	.6443
8	.6443	.6036	.7468	.6783	.6443
9	.5087	.4854	.5975	.5087	.4904
10	.4409		.5087	.407	.3772
11	.2641	.2987	.4409	.407	.3361
12	.2427	.2614	.407	.4409	.2241
13		.2641	.407	.4748	.2075
14	.2614	.2614	.407	.4748	.2263
15	.2987	.2378	.407	.4409	.2263
16	.3361	.2452	.3391	.4409	.3395
17	.3772	.4904	.407	.5087	.4481
18	.5847	.5281	.407	.5765	.5975
19	.5658	.5281	.4748	.6104	.5601
20	.3361	.4854	.4748	.5765	.5228
21	.3018	.415	.407	.4748	.3361
22	.2987	.3018	.2374	.2713	.2801
23	.2641	.3018	.3052	.3391	
24	.2713	.2641	.2614	.2374	.2374
Max	.7461	.7167	.8215	.6783	.6443
Min	.2427	.2378	.2374	.2374	.2075
Avg	.4406	.3958	.4369	.4691	.4092

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074021 / 33 KV SUB STATION KINHOLA

Feeder No / Name : 206 / 11 Kv Tapowan Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 /
OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1357	.1509	.1509	.1357	.1357
2	.1696	.1509	.1509	.1696	.1696
3	.2035	.1698	.1494	.1696	.2035
4	.2713	.1886	.1886	.2374	.2035
5	.3052	.2987	.3018	.2713	.2035
6	.3391	.415	.3772	.2374	.1696
7	.3391	.4338	.4854	.2035	.1696
8	.3052	.3772	.4481	.1696	.1696
9	.2713	.2614	.2987	.1696	.1357
10	.2035	.2241	.2374	.1357	.1509
11	.1886	.1867	.2035	.1357	.1494
12	.1509	.1494	.1696	.1357	.112
13	.1494	.1494	.1696	.1357	.112
14	.132	.1311	.1696	.1357	.112
15	.132	.1307	.1357	.1357	.1307
16	.1494	.1509	.1357	.1357	.1494
17	.1886	.1886	.1357	.1357	.1698
18	.2263	.2641	.1696	.1696	.3361
19	.3395	.3018	.2035	.2035	.3361
20	.2241	.3018	.2374	.2374	.3361
21	.1886	.2641	.1696	.2035	.2241
22	.1867	.1886	.1017	.1696	.1886
23	.1886	.1886	.1357	.1357	
24	.1357	.1509	.1509	.1357	.1357
Max	.3395	.4338	.4854	.2713	.3361
Min	.132	.1307	.1017	.1357	.112
Avg	.2135	.2257	.2115	.1710	.1827

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074027 / 33 KV SUB STATION MOTALA

Feeder No / Name : 201 / 11 KV NALGANAGA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	1.6289	.0187	.0514	.6859
2	.0171	1.6632	.0187	.0514	.6516
3	.0171	1.5775	.0187	.0514	.6687
4	.0171	1.6804	.0187	.0514	.6687
5	.0171	1.7833	.0187	.0514	.7373
6	.0171	1.9204	.0187	.0514	.8745
7		2.0576			1.0631
8		2.1948			1.286
9	2.0576		1.9281	2.0233	
10	2.3122		2.5377	2.2611	
11	2.4371		2.6063	2.4215	
12	2.4215		2.8807	2.3746	
13	2.4844		2.6749	2.3434	
14	2.4387		2.6235	2.3205	
15	2.4966		2.4348	2.2725	
16	2.2725		2.452	2.3365	
19	.0514	.0187	.0514	.0514	.0187
20	.0514		.0514	.0171	
21	.0343	.0187	.0514	.0171	
22	.0343		.0514	.0171	.0187
23	.0343	.0187	.0509	.6859	.0187
24	.0171	.0343		.0514	.7202
Max	2.4966	2.1948	2.8807	2.4215	1.286
Min	.0171	.0187	.0187	.0171	.0187
Avg	.9623	1.2164	1.0793	.9751	.6177

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074027 / 33 KV SUB STATION MOTALA

Feeder No / Name : 203 / 11 KV RAJUR AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8916	.0343	.8573	.8573	.0171
2	.8916	.0343	.8573	.8573	.0171
3	.8916	.0171	.8573	.8573	.0171
4	.9259	.0171	.8573	.8916	.0171
5	.9259	.0171	.8817	.9259	.0171
6	.9602	.0171	.8718	.9259	.0171
7	1.2346		1.1736	1.0974	
8	1.2174		1.358	1.3375	
9		.9259			.9945
10		1.3375			1.4575
11		1.5261			1.6461
12		1.406			1.5775
13		1.5089			1.5432
14		1.6118			1.5432
15		1.5089			1.406
16		1.3717			1.3717
19	.0343	.0373	.0343	.0343	.0373
20	.0343	.0373	.0514	.0343	
21	.0343	.0373	.0514	.0343	
22	.0343	.0373	.0514	.0171	
23	.0343	.8402	.7888	.0171	.7888
24	.0343	.0343	.8402	.8573	.0171
Max	1.2346	1.6118	1.358	1.3375	1.6461
Min	.0343	.0171	.0343	.0171	.0171
Avg	.5818	.6179	.6808	.6246	.7344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074027 / 33 KV SUB STATION MOTALA

Feeder No / Name : 204 / 11 KV TARAPUR GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.1372	.056	.0343	.0857
2	.0686	.1372	.056	.0343	.0857
3	.0686	.1372	.056	.0343	.0857
4	.0686	.1715	.056	.0514	.12
5	.0686	.2058	.056	.0686	.1715
6	.1029	.2401	.0747	.0686	.2401
7	.0514	.2572	.0747	.0514	.3086
8	.0514	.4115	.056	.0343	.4287
9	.0343	.0343	.0373	.0343	.0343
10	.0187	.0171	.0343	.0373	.0171
11	.0187	.0171	.0171	.0373	.0171
12	.0187	.0171	.4801	.0187	.0171
13	.0187	.0171	.4973	.0187	.0171
14	.0187	.0171	.463	.0187	.0171
15	.0187	.0171	.4973	.0187	.0171
16	.0373	.0171	.4287	.0373	.0171
17	.0373	.0343	.0343	.0373	.0343
18	.0686	.056	.0514	.0514	.056
19	.0857	.0747	.0686	.0686	.0739
20	.0686	.0747	.0514	.0857	.0739
21	.0686	.0747	.0514	.0857	.0739
22	.0686	.0747	.0514	.0686	.056
23	.0686	.056	.0514	.12	.056
24	.0686	.0514	.056	.0514	.0857
Max	.1029	.4115	.4973	.12	.4287
Min	.0187	.0171	.0171	.0187	.0171
Avg	.0528	.0978	.1399	.0486	.0912

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074027 / 33 KV SUB STATION MOTALA

Feeder No / Name : 205 / 11 KV NALGANGAPUR GAOTHAN GAOTHAN FEEDER
FEED Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.4115	.5487	.2401	.2401
2	.4458	.4115	.5487	.2401	.2401
3	.4458	.4287	.5487	.2401	.2572
4	.4287	.4801	.5853	.3772	.3086
5	.4287	.5658	.6584	.3944	.3601
6	.4973	.6344	.7522	.3944	.4287
7	.5658	.7373	.8505	.4801	.4973
8	.6001	.5658	.7522	.4458	.4973
9	.583	.5658	.7164	.463	.4801
10	.5853	.6001	.4973	.5121	.463
11	.6219	.6687	.5316	.3841	
12	.6219	.6344	.5316	.5487	
13	.5853	.6516	.3601	.5121	
14	.5487	.6173	.3601	.3658	
15	.5853	.6001	.3601	.3658	
16	.6036	.5658	.4115	.439	
17	.4024	.4801	.4115	.4207	
18	.4801	.5487	.3601	.4115	
19	.4287	.6036	.3772		
20	.3944	.5121	.2743	.4458	
21	.4287		.3258	.4115	
22	.463	.5853	.463	.3772	
23	.463	.567	.2743	.3086	
24	.3601	.4287	.5487	.2572	.2743
Max	.6219	.7373	.8505	.5487	.4973
Min	.3601	.4115	.2743	.2401	.2401
Avg	.5006	.5593	.5020	.3928	.3679

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074027 / 33 KV SUB STATION MOTALA

Feeder No / Name : 206 / 11 KV RAJUR GAOTHAN FEEDER GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1029	.1294	.1029	.1029
2	.12	.1029	.1294	.1029	.1029
3	.12	.1029	.1109	.1029	.1029
4	.1372	.1372	.1109	.1372	.1372
5	.1372	.2058	.1294	.1715	.1715
6	.2401	.2572	.2378	.1886	.2229
7	.2572	.2915	.2896	.2915	.2915
8	.2572	.2401	.2378	.2743	.2743
9	.2058	.2229	.2561	.2572	.2401
10	.1829	.2229	.1886	.1478	.1543
11	.0924	.12	.12	.1478	.12
12	.1109	.1543	.1543	.1478	.1029
13	.1294	.1543	.1543	.1294	.1886
14	.1478		.1372	.1109	.1886
15	.1294	.1715	.1886	.0924	.12
16	.1478	.1372	.1372	.1478	.1372
17	.2195	.2058	.1715	.2378	.2229
18	.2915	.2743	.2229	.2743	.2743
19	.2572	.2561	.2058	.2401	.2561
20	.2058	.2012	.1715	.1715	.1829
21	.1886	.1829	.1543	.1543	.1646
22	.1543	.1478	.12	.1372	.1463
23	.1372	.1294	.1029	.12	.1294
24	.12	.1029	.1109	.1029	.1029
Max	.2915	.2915	.2896	.2915	.2915
Min	.0924	.1029	.1029	.0924	.1029
Avg	.1712	.1793	.1655	.1663	.1724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074027 / 33 KV SUB STATION MOTALA

Feeder No / Name : 208 / 11 KV MOTALA TOWN FEEDER GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.3601	.3658	.3429	.3429
2	.3601	.3772	.3658	.3429	.3429
3	.3601	.3772	.3292	.3429	.3601
4	.3944	.4801	.3292	.3772	.3944
5	.3944	.5487	.3544	.4458	.463
6	.5316	.6173	.4755	.5144	.5316
7	.6516	.6859	.7164	.6859	.6173
8	.703	.5487	.7164	.703	.6344
9	.7716	.4973	.7522	.6516	.5658
10	1.0498	.1543	.9774	.9214	.463
11	1.0745	.4801	1.0117	.9568	.4458
12	1.0985	.4973		.9036	.4973
13	1.1919	.4973		.8859	.4973
14	1.0517		.6687	.8059	.4458
15	1.0277	.5316	.5144	.8059	.4458
16	.9671	.5487	.4973	.8505	.4973
17	.4755	.5487	.4801	.439	.6001
18	.6001	.7164	.6344	.6001	.7164
19	.6173	.6878	.5658		.6584
20	.5316		.4973		.5853
21	.5144		.4973		.4938
22	.4801	.4755	.4115		.4572
23	.4115	.4207	.3601	.3944	.4024
24	.3772	.3772	.4024	.3258	.3601
Max	1.1919	.7164	1.0117	.9568	.7164
Min	.3601	.1543	.3292	.3258	.3429
Avg	.6665	.4966	.5420	.6148	.4924

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074036 / 33 KV SUBSTATION SAWARGAON

Feeder No / Name : 201 / 11 KV MAKODI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.5487	.0343	.0343	.5144
2	.0343	.7202	.0343	.0343	.4801
3	.0343	.7373	.0343	.0343	.463
4	.0343	.6859	.0343	.0343	.4458
5	.0343	.6859	.0343	.0343	.4287
6	.0343	.5487	.0343	.0343	.1715
7		.5316			.3429
8		.5144			.3429
9	.3944		.4801	.3772	
10	.6687		.5487	.583	
11	.6687		.583	.5658	
12	.703		.5487	.583	
13	.6516		.6173	.4973	
14	.583		.5144	.4973	
15	.5316		.5316	.5658	
16			.6516	.5487	
19	.0343	.0343	.0343	.0343	
20	.0343	.0343	.0343	.0343	
21	.0343	.0343	.0343	.0343	
22	.0343	.0343	.0343	.0343	
23	.0343	.0343	.0343	.5144	
24	.0343		.0343	.5144	
Max	.703	.7373	.6516	.583	.5144
Min	.0343	.0343	.0343	.0343	.1715
Avg	.2428	.3957	.2444	.2795	.3987

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074036 / 33 KV SUBSTATION SAWARGAON

Feeder No / Name : 202 / 11 KV P. DEVI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.0343	.2743	.4287	.0343
2	.6859	.0343	.2743	.2743	.0343
3	.6516	.0343	.2743	.3086	.0343
4	.6173	.0343	.3086	.3086	.0343
5	.583	.0343	.3429	.3429	.0343
6	.5144	.0343	.3772	.6859	.0343
7	.6001		.6001	.6516	
8	.7202		.6859	.7373	
9		.6516			.4801
10		.6687			.5487
11		.6687			
12		.7716			
13		.7545			
14		.6687			
15		.6859			
16		.6173			
19	.0343	.0343	.0343	.0343	
20	.0343	.0343	.0343	.0343	
21	.0343	.0343	.0343	.0343	
22	.0343	.0343	.0343	.0343	
23	.0343	.0343	.5144	.0343	
24	.0343		.5658	.0343	
Max	.7202	.7716	.6859	.7373	.5487
Min	.0343	.0343	.0343	.0343	.0343
Avg	.3674	.3086	.3111	.2817	.1543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074036 / 33 KV SUBSTATION SAWARGAON

Feeder No / Name : 203 / 11 KV S.BAZAR AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.0343	1.0631	.6859	.0343
2	.823	.0343	1.1317	1.0288	.0343
3	1.0288	.0343	1.1317	.6859	.0343
4	1.0631	.0343	1.2346	.6516	.0343
5	.7202	.0343	1.406	.7202	.0343
6	.8573	.0343	1.4575	1.0631	.0343
7	1.3032		1.8861	1.2003	
8	1.3717		2.0919	1.406	
9		1.0288			.6859
10		1.3717			
11		1.7147			1.8861
12		2.1434			1.9204
13		2.1434			1.8861
14		2.0576			1.8861
15		2.0576			1.7147
16		2.0576			1.6461
19	.0343	.0343	.0343	.0343	
20	.0343	.0343	.0343	.0343	
21	.0343	.0343	.0343	.0343	
22	.0343	.0343	.0343	.0343	
23	.0343	.7545	.7716	.0343	
24	.0343		.7202	.0343	
Max	1.3717	2.1434	2.0919	1.406	1.9204
Min	.0343	.0343	.0343	.0343	.0343
Avg	.5695	.8249	.9308	.5463	.9101

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074036 / 33 KV SUBSTATION SAWARGAON

Feeder No / Name : 204 / 11 KV Nipana Ag Feeder FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.5487	.0343	.0343	.463
2	.0343	.5658	.0343	.0343	.4973
3	.0343		.0343	.0343	.5316
4	.0343	.583	.0343	.0343	.4801
5	.0343	.4973	.0343	.0343	.4458
6	.0343	.6001	.0343	.0343	.3944
7		.4458			.4287
8		.4458			.4287
9			.7545	.4115	
10			.6687	.6173	
11	.6001		.6516	.4973	
12	.583		.6859	.5658	
13	.583		.6859	.5487	
14	.583		.583	.583	
15	.583		.6173	.5487	
16	.5487		.4801	.5487	
19		.0343	.0343	.0343	
20	.0343	.0343	.0343	.0343	
21	.0343	.0343	.0343	.0343	
22	.0343	.0343	.0343	.0343	
23	.0343	.0343	.0343	.3944	
24	.0343		.0343	.4287	
Max	.6001	.6001	.7545	.6173	.5316
Min	.0343	.0343	.0343	.0343	.3944
Avg	.2269	.3215	.2769	.2744	.4587

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074036 / 33 KV SUBSTATION SAWARGAON

Feeder No / Name : 205 / 11 kv Nipana GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1543	.1372	.1029	.1715
2	.1029	.1543	.1372	.1029	.1886
3	.1029	.1715	.1372	.0857	.2058
4	.12	.1715	.1372	.0857	.2058
5	.1372	.1886	.1543	.1372	.2229
6	.1715	.2229	.2229	.1715	.2401
7	.2401	.1886	.2229	.2058	.1886
8		.1886	.1886	.1715	.1886
9	.4287	.1372	.1715	.1372	.12
10	.5658	.1029	.1372	.1029	.12
11	.0857	.1029	.1029	.0857	.12
12	.0857	.0857	.1029	.0686	.0857
13	.0857	.1029	.0857	.0686	.0857
14	.0857	.1029		.0686	.0857
15	.0857	.1029	.1029	.1029	.1029
16	.12	.1029	.1029	.12	.12
17	.1372	.1029	.12	.1029	.1372
18	.1372	.12	.1715	.1372	
19	.1715	.1715	.2401	.1886	
20	.1715	.2058	.2058		
21	.1543	.1715	.1543	.1715	
22	.1543	.1543	.12	.1715	
23	.1372	.1543	.1029	.1715	
24	.1543		.12	.1715	
Max	.5658	.2229	.2401	.2058	.2401
Min	.0857	.0857	.0857	.0686	.0857
Avg	.1633	.1461	.1469	.1275	.1523

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074036 / 33 KV SUBSTATION SAWARGAON

Feeder No / Name : 206 / 11 kv P.Devi GFSS GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5316	.5144	.3944	.3772	
2	.6001	.5316	.3944	.3429	
3	.5487	.5487	.4801	.3429	
4	.5144	.5658	.6687	.4115	
5	.5144	.583	.7888	.5144	
6	.6859	.6001	.823	.583	
7	.823	.3429	.6859	.6173	.5144
8	.8916	.3429	.5487	.5487	.3772
9	.5144	.1715	.4801	.583	.4458
10	.4115	.1715	.4458	.5144	.3429
11	.3429	.1715	.4115	.4973	
12		.3086	.4115	.4973	
13		.3086	.3429	.5144	
14	.2058	.3429	.3772	.5144	
15	.2401	.3429	.3258	.5487	
16	.2401		.4115	.5487	
17	.2572	.4801	.5144	.5144	
18	.2572	.6173	.583	.4801	
19	.2572	.7202	.6859	.4458	
20	.2401	.823	.7716	.4801	
21	.2058	.6173	.6001	.4801	
22	.2058	.4801	.6344	.4458	
23	.1715	.4458	.5144	.4287	
24	.1715		.4801	.4115	
Max	.8916	.823	.823	.6173	.5144
Min	.1715	.1715	.3258	.3429	.3429
Avg	.4014	.4559	.5323	.4851	.4201

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074036 / 33 KV SUBSTATION SAWARGAON

Feeder No / Name : 207 / 11 kv S.Bazar GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1543	.1372	.1029	.1715
2	.1029	.1715	.1372	.1029	.1543
3	.1029	.1886	.1372	.12	.1543
4	.12	.2058	.2058	.12	.1886
5	.1543	.2229	.2743	.1372	.2058
6	.2058	.2572	.2572	.2058	.2229
7	.2915	.2058	.2401	.2572	.1886
8	.2229	.2058	.2058	.1886	.1886
9	.2058	.1029	.1715	.1543	.1543
10	.1372	.1029	.1715	.12	.1372
11		.1029	.1029	.1029	.1372
12		.12	.1029	.1029	.1029
13		.1029	.12	.1029	.1029
14		.1029	.12	.1029	.1029
15	.12	.12	.1029	.12	.1372
16	.12	.1543	.1372	.12	.1372
17	.1886	.1715		.1372	.1543
18	.1886	.2058	.1886	.1372	
19	.2058	.2401	.2229	.1543	
20	.1886	.1715	.2058	.1886	
21	.1543	.1715	.1543	.1715	
22	.1543	.1372	.12	.1715	
23	.1543	.1372	.1029	.1715	
24	.1543	.1543	.12		
Max	.2915	.2572	.2743	.2572	.2229
Min	.1029	.1029	.1029	.1029	.1029
Avg	.1646	.1629	.1625	.1431	.1553

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074036 / 33 KV SUBSTATION SAWARGAON

Feeder No / Name : 208 / 11 kv makodi gfss

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1543	.1372	.1543	.1715
2	.1715	.1886	.1372	.1372	.1543
3	.1543	.2058	.1372	.1372	.1715
4	.1372	.2229	.1715	.1715	.2058
5	.2058	.2401	.2229	.2058	.2401
6	.2572	.2743	.3429	.3429	.2743
7	.3601	.2743	.3772	.3772	.2743
8	.2915	.2743	.2743	.3086	.2743
9	.2229		.2401	.2058	.1372
10	.1715		.2058	.1715	.1372
11	.1372	.1372	.1372	.1372	.1372
12	.1372	.1372	.1543	.1372	.1543
13	.1372	.1372	.1543	.1372	.1372
14	.12		.1372	.1372	.1372
15	.1372	.2058	.1372	.2058	.1715
16	.2058	.2058	.1543	.1372	.1715
17	.2058	.2743	.2058	.1715	.2058
18	.2058	.2401	.3086	.1715	
19	.2743	.2401	.3429	.2058	.2058
20	.2743	.2058	.1715	.2058	.2058
21	.2058	.1715	.2229	.2058	.2058
22	.2058	.1715	.1715	.2058	.2058
23	.1543	.1715	.12	.1715	.1715
24	.1543		.1372	.1715	.1715
Max	.3601	.2743	.3772	.3772	.2743
Min	.12	.1372	.12	.1372	.1372
Avg	.1958	.2066	.2001	.1922	.1879

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074060 / 33 KV Pophli S/S

Feeder No / Name : 201 / 11 KV Pophli AG Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0978		.9116	1.0974	
2	1.0978		.9116	1.0802	
3	1.0978		.9116	1.0802	
4	1.0978		.9116	1.0802	
5	1.1305		.9448	1.1145	
6	1.166		.9667	1.1488	
7	1.1498		.9878	1.166	
8		1.3375	1.085		1.0978
9		1.4413	1.247		1.247
10		1.4251	1.3717		1.3413
11		1.4575	1.3717		1.3916
12		1.4563	1.3032		1.4754
13		1.4251	1.3032		1.4251
14		1.3279	1.286		1.3748
15		1.2597	1.2346		1.291
16	1.4403	1.3279		1.5061	1.291
17	1.4922	1.3927		1.5061	1.3375
18	1.4413	1.2793		1.3279	1.286
19	1.3735	1.2125		1.2944	1.2174
20	1.3375	1.1934		1.1797	1.2003
21	1.2689	1.1633		1.1469	1.2003
22	1.2003	1.1797		1.1469	1.166
23	1.166	1.1797		1.1142	1.1317
24	1.0978		.9116	1.0974	
Max	1.4922	1.4575	1.3717	1.5061	1.4754
Min	1.0978	1.1633	.9116	1.0802	1.0978
Avg	1.2285	1.3162	1.1037	1.1929	1.2796

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074060 / 33 KV Pophli S/S

Feeder No / Name : 202 / wadi ag feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0886			.1227	
2	.0886			.1227	
3	.0886			.1052	
4	.1052			.1052	
5	.1227			.1227	
6	.124			.208	
7	.1907			.208	
8			.298		
9			.3429		
10			.4854		
11			.4161		
12			.3641		
13			.3641		
14			.3294		
15			.2947		
16		.3467			.463
17		.3988			.4161
18		.3121			.3988
19		.298			.3641
20		.2629			.3467
21		.2629			.3467
22		.2629			.298
23		.2629			.2629
24	.0886			.1387	
Max	.1907	.3988	.4854	.208	.463
Min	.0886	.2629	.2947	.1052	.2629
Avg	.1121	.3009	.3618	.1417	.3620

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074060 / 33 KV Pophli S/S

Feeder No / Name : 203 / 11 kv Pophli Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 /
OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1433	.1448	.1448	.128	.1267
2	.1433	.1267	.1448	.1097	.1267
3	.1254	.1267	.128	.1097	.1086
4	.1612	.1629	.1463	.1463	.1267
5	.2149	.2534	.1991	.2534	.2149
6	.3366	.3439	.2865	.3077	.3045
7	.3681	.3801	.3506	.3439	.4031
8	.3012	.3077	.3012	.2896	.298
9	.2126	.1629	.2481	.2353	.2126
10	.1448	.1595	.1629	.1629	.1629
11	.1086	.1417	.1267	.1086	.1086
12	.1086	.1075	.0905	.0905	.0905
13	.1086	.1063	.0724	.0905	.0724
14	.0905	.1075	.0905	.0905	.0905
15	.0905	.1075	.0905	.0905	.0905
16	.1086	.1075	.1267	.1086	
17	.1629	.1448	.1267	.1646	.1267
18	.2534	.2686	.2534	.2896	.2534
19	.3077	.3045	.3077	.2715	.2896
20	.2353	.2218	.2353	.2218	.2534
21	.1629	.1991	.181	.2033	.1991
22	.1448	.1646	.1448	.168	.1629
23	.1448	.1478	.1267	.1509	.1463
24	.1448	.1448	.1478	.1267	.1448
Max	.3681	.3801	.3506	.3439	.4031
Min	.0905	.1063	.0724	.0905	.0724
Avg	.1801	.1851	.1764	.1776	.1788

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074060 / 33 KV Pophli S/S

Feeder No / Name : 204 / 11 Kv Ghoogali Ag Feeder FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0867			.0905
2		.0701			.0895
3		.0701			.0905
4		.0701			.0895
5		.104			.0895
6		.1387			.0895
7		.1907			.1595
8	.1227			.1402	
9	.2279			.156	
10	.3814			.2572	
11				.2572	
12	.3688			.2229	
13	.3521			.3772	
14	.3521			.3772	
15	.3294			.3086	
16			.4854		
17			.4508		
18			.3641		
19			.2947		
20			.2601		
21			.2254		
22			.1734		
23			.1402		
24		.0867			.0895
Max	.3814	.1907	.4854	.3772	.1595
Min	.1227	.0701	.1402	.1402	.0895
Avg	.3049	.1021	.2993	.2621	.0985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074061 / 33 kv Kothali Substation

Feeder No / Name : 201 / 11 kv Kothali Ag Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.086	.0724	.9774	1.1765	
2	1.086	.0724	.9945	1.1765	
3	1.0974		1.0288	1.1765	
4	1.086	.0724	1.0288	1.1765	
5	1.086	.0724	1.0631	1.1765	
6	1.267	.0724	1.166	1.267	
7	1.4842		1.5089	1.5384	
8	1.8099		1.6461	1.8099	
9		1.086			1.086
10		1.6804			1.6461
11		2.2291			2.1605
12		2.572			2.2462
13		2.4691			1.6804
14		2.2291			1.9204
15		1.9547	.0191		2.0062
16		1.8861			1.5947
19	.0724	.0686	.0724	.0724	.0686
20	.0724	.0686	.0724	.0724	.0686
21	.0724	.0686	.0724	.0724	.0686
22	.0724	.0686	.0724	.0724	.0686
23	.0724	1.0974	1.1222	.0724	.9602
24	.0754	.0724	.9945	1.1765	.0724
Max	1.8099	2.572	1.6461	1.8099	2.2462
Min	.0724	.0686	.0191	.0724	.0686
Avg	.7457	.9428	.7893	.8597	1.1177

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074061 / 33 kv Kothali Substation

Feeder No / Name : 202 / 11 kv Kothali GFSS Feeder GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362	.362	.3429	.362	.362
2	.3982	.362	.3429	.362	.362
3	.3982	.362	.3429	.362	.362
4	.3982	.3982	.3429	.362	.362
5	.4344	.3982	.3601	.362	.3982
6	.4706	.4344	.4801	.543	.543
7	.6335	.6516	.5144	.6135	.6697
8	.543	.4706	.4458	.543	.4706
9	.4572	.4344	.4572	.4001	.362
10	.3429	.2915	.381	.362	.3086
11	.3429	.2743	.3429	.362	.1715
12	.3429	.2915	.3429	.3239	.2229
13		.2915	.3429	.3239	.2058
14	.3429	.2915	.3239	.3429	.2743
15	.362	.2915	.3239	.381	.3086
16	.4163	.3429	.381	.4001	.3772
17	.5068	.463	.4763	.5335	.4458
18	.5792	.5487	.5068	.6154	.5316
19	.5973	.6001	.6154	.543	.5144
20	.543	.5487	.543	.5068	.4458
21	.5068	.4801	.4887	.3982	.4801
22	.4344	.4115	.3982	.362	.4115
23	.3982	.3601	.362	.362	.3772
24	.3982	.362	.3601	.362	.362
Max	.6335	.6516	.6154	.6154	.6697
Min	.0362	.2743	.3239	.3239	.1715
Avg	.4297	.4051	.4091	.4203	.3887

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074061 / 33 kv Kothali Substation

Feeder No / Name : 203 / 11 kv ramgaon ag feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1448	.1267	.1543	.1267	.3982
2	.1448	.1267	.1715	.1267	.3982
3	.1448	.1267	.1372	.1267	.3982
4	.1448	.181	.12	.1267	.4525
5	.1448	.362	.1372	.1267	.4525
6	.1448	.4887	.1372	.1448	.4525
7	.2534	.7421	.1886	.1991	.6154
8	.4163	1.0374	.3772	.2896	.8507
9	.4801	.1267	.4801	.4915	.2715
10	.5121	.3772	.9998	.8124	.2915
11	1.0623	.5487	1.2811	.9374	.3429
12	1.2498	.4801	1.4022	1.0936	.4287
13	1.4022	.5144	1.3413	1.0936	.3429
14	1.2811	.4801	1.2651	1.0311	.3086
15	1.267	.3772	1.0623	.9488	.2743
16	1.1041	.3429	.9374	.8855	.2743
19	.1448	.0103	.1448	.1448	.1029
20	.1267	.1029	.1448	.1267	.12
21	.1267	.1029	.1086	.1267	
22	.1267	.1029	.1086	.1267	
23	.1086	.1715	.1086	.3982	.1543
24	.1086	.1086	.1543	.1267	.3982
Max	1.4022	1.0374	1.4022	1.0936	.8507
Min	.1086	.0103	.1086	.1267	.1029
Avg	.4836	.3199	.4983	.4369	.3664

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074061 / 33 kv Kothali Substation

Feeder No / Name : 204 / 11 Kv Shirva AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	09-DEC-17
HR	Load (MW)
20	.1029
Max	.1029
Min	.1029
Avg	.1029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289]

BU 2895

Substation No/ Name :- 074087 / 33 KV WADJI SUB STATION

Feeder No / Name : 201 / 11 KV Harankhed Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.3856	.0343	.0351	.4344
2	.0457	.3856	.0343	.0351	.4344
3	.0305	.4382	.0343	.0351	.4225
4	.0305	.4557	.0343	.0351	.4344
5	.0305	.4557	.0343	.0351	.4344
6	.0305	.4908	.0343	.0351	.4344
7		.5609			.6516
8		.7186			.724
9	.3048		.4973	.4908	
10	.6344		.7537	.6154	
11	.7716		.7712	.724	
12	.7545		.7362	.6878	
13	.7888		.6485	.6878	
14	.7716		.6485	.6154	
15	.7202		.6661	.6516	
16	.7373		.7011	.724	
20	.0351	.0343	.0354	.0362	.0362
21	.0351	.0343	.0354	.0362	.0362
22	.0351	.0343	.0351	.0362	
23	.0351	.0343	.0351	.3801	
24	.0305	.0351	.0343	.0351	.4344
Max	.7888	.7186	.7712	.724	.724
Min	.0305	.0343	.0343	.0351	.0362
Avg	.3080	.3126	.3055	.3122	.4070

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074087 / 33 KV WADJI SUB STATION

Feeder No / Name : 202 / 11 KV Wadji GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1067	.1578	.1029	.1227	.1086
2	.1067	.1578	.1029	.1227	.1036
3	.1372	.1578	.1029	.1402	.1086
4	.1524	.1753	.1372	.1578	.1036
5	.2134	.2804	.2743	.2629	.181
6	.2439	.333	.3429	.3506	.3258
7	.2896	.333	.3258	.3506	.3258
8	.2134	.2279	.2229	.2629	.2534
9	.1829	.1578	.1886	.1578	.181
10	.1715	.1029	.1753	.1086	.1086
11	.1372	.12	.1402	.1086	.1086
12	.1372	.12	.1402	.0724	.1086
13	.12	.1029	.1227	.1086	.1086
14	.1372	.1372	.1402	.1448	.1448
15	.12	.1372	.1227	.1448	.1384
16	.1372	.1543	.1227	.1448	.2353
17	.1753	.2058	.1949	.1448	.2438
18	.2279	.2572	.2835	.1812	.2534
19	.2103	.2401	.2126	.2172	
20	.1753	.1715	.1772	.2896	.2172
21	.1753	.1715	.1417	.2534	.1448
22	.1578	.12	.1227	.1448	
23	.1578	.1029	.1227	.1086	
24	.1067	.1578	.1029	.1227	.1086
Max	.2896	.333	.3429	.3506	.3258
Min	.1067	.1029	.1029	.0724	.1036
Avg	.1664	.1784	.1718	.1760	.1720

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074087 / 33 KV WADJI SUB STATION

Feeder No / Name : 203 / 11 KV Malegaon Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.0351	1.2346	1.262	.0362
2	1.1279	.0351	1.286	1.262	.0362
3	1.1888	.0351	1.286	1.262	.0362
4	1.2193	.0351	1.286	1.3146	.0343
5	1.2346	.0351	1.3375	1.3146	.0362
6	1.2193	.0351	1.3546	1.3672	.0362
7	1.2803		1.5604	1.5424	
8	1.4937		1.4746	1.6651	
9		1.4548			1.6651
10		1.7833			1.7905
11		1.749			1.9728
12		1.8004			1.9909
13		1.8004			1.9909
14		1.6804			1.8099
15		1.7661			1.6289
16		1.749			1.6289
20	.0351	.0343	.0354		.0362
21	.0351	.0343	.0354	.0362	.0362
22	.0351	.0343	.0351	.0362	
23	.0351	1.2003	1.1919	.0362	
24	.0305	.0351	1.2003	1.2269	.0362
Max	1.4937	1.8004	1.5604	1.6651	1.9909
Min	.0305	.0343	.0351	.0362	.0343
Avg	.7576	.8070	1.0244	1.0271	.8707

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074104 / 33/11 KV Waghjal Murti Sub

Sta

Feeder No / Name : 201 / 11 KV Takali Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086		.3772	.3361	
2	.3086		.4115	.3361	
3	.3086		.5144	.3361	
4	.3429		.5144	.3361	
5	.4115		.5144	.3361	
6	.4458		.6173	.5601	
7	.7545		.6859	1.0829	
8	.8573		.7545	1.307	
9		.4744			
10		.9175			
11		1.0814			
12		1.1797			
13		1.1797			
14		1.1336			
15		1.2125			
16		1.1797			
23		.3429	.2949		.2743
24			.3429	.2949	
Max	.8573	1.2125	.7545	1.307	.2743
Min	.3086	.3429	.2949	.2949	.2743
Avg	.4672	.9668	.5027	.5473	.2743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074104 / 33/11 KV Waghjal Murti Sub

Sta

Feeder No / Name : 202 / 11 KV Rohinkhed Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6554		
2		.6554		
3		.8383		
4		1.1736		
5		1.1736		
6		1.2125		
7		1.2018		
8		1.2651		
9	1.1317		1.5432	1.1702
10	1.6118		1.6804	1.531
11	2.0576		1.7147	1.9204
12	1.9204		2.0576	1.989
13	1.9204		2.0576	1.9547
14	1.8861		1.9204	1.8861
15	1.9204		1.8176	1.749
16	1.7147		1.8519	1.749
Max	2.0576	1.2651	2.0576	1.989
Min	1.1317	.6554	1.5432	1.1702
Avg	1.7704	1.0220	1.8304	1.7437

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074104 / 33/11 KV Waghjal Murti Sub
StaFeeder No / Name : 203 / 11 KV Rohinkhed Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2241	.2401	.2241
2	.2058	.2614		.2241
3	.2058	.2614	.2743	.2241
4	.2401	.2987	.2743	.2241
5	.3429	.3361	.3086	.2241
6	.4115	.3734	.4458	.4108
7	.5487	.4481	.4458	.6348
8	.583	.5228	.5144	.5975
9	.5144	.4481	.4458	.5228
10	.3772	.3734	.3772	.3361
11	.3429	.2987	.2743	.2401
12	.2743	.2241	.2401	.2401
13	.2401	.1867	.2058	.2058
14	.2401	.1867	.2058	.2058
15	.2401	.2614	.2058	.2058
16	.2743	.2614	.2401	.2058
17	.3086	.3361	.3429	.3086
18	.5228	.5601	.4458	.5144
19	.3734	.4801	.5601	
20	.3734	.4115	.4108	
21	.3361	.3429	.4108	
22	.2987	.2401	.2241	
23	.2614	.2401	.2241	
24	.2058	.2241	.2401	.2241
Max	.583	.5601	.5601	.6348
Min	.2058	.1867	.2058	.2058
Avg	.3303	.3251	.3286	.3144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

MOTALA S. DN.[289] BU 2895

Substation No/ Name :- 074104 / 33/11 KV Waghjal Murti Sub
StaFeeder No / Name : 204 / 11 KV Takali Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3734	.3772	.3734
2	.3086	.3734	.4115	.3734
3	.3086	.4108	.4115	.3734
4	.3429	.4108	.4115	.3734
5	.4115	.4481	.4115	.3734
6	.5144	.4854	.5144	.5601
7	.6173	.5228	.5487	.7023
8	.583	.5601	.583	.6283
9	.4801	.4854	.5144	.5601
10	.4115	.4108	.5144	.4481
11	.3086	.2987	.3429	.2743
12	.3429	.2987	.3086	.2401
13	.2743	.2987	.2743	.2401
14	.2401	.2614	.2401	.2401
15	.2401	.2987	.2401	.2401
16	.3086	.3361	.3086	.2743
17	.4115	.4108	.3772	.4115
18	.6722	.7095	.583	.6173
19	.4108	.5144	.5975	
20	.4854	.4801	.4854	
21	.4481	.3772	.4108	
22	.4108	.3772	.3734	
23	.4108	.3772	.3734	
24	.3086	.3734	.3772	.3734
Max	.6722	.7095	.5975	.7023
Min	.2401	.2614	.2401	.2401
Avg	.3983	.4122	.4163	.4041

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292] BU 2925

Substation No/ Name :- 074005 / 33 kv Chandur s/s

Feeder No / Name : 202 / 11 kv Chandur Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5729	1.5729	1.4255	.0381	.0762
2	1.5729	1.5729	1.4419	.0381	.0762
3	1.5729	1.5729	1.4419	.0381	.0762
4	1.5729	1.5729	1.4419	.0381	.0762
5	1.6385	1.6057	1.4255	.0381	.0762
6	1.757	1.6907	1.4746	.0381	.0762
7	1.757	1.9448	1.6194	.0381	.0762
8	1.757	2.1795	1.6194	.0762	.0762
9				1.4746	1.97
10				2.2291	2.4188
11				2.1795	2.6292
12				2.1365	2.4539
13				2.2131	2.2786
14				2.1795	2.2786
15			.0762	2.1795	2.2786
16	.0762		.0762	2.2466	2.3487
17	.0762	.0762	.0762		
18		.0762	.0762		
19		.0762	.0762		
20		.0762	.0762		
21	.0762	.0762	.0762		
22	.0762	.0762	.0762		
23	.0762	1.326	.0762	.0762	.0762
24	.0762	.0762	1.3592	.0762	.0762
Max	1.757	2.1795	1.6194	2.2466	2.6292
Min	.0762	.0762	.0762	.0381	.0762
Avg	.9756	.9732	.7742	.9630	1.0788

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292] BU 2925

Substation No/ Name :- 074005 / 33 kv Chandur s/s

Feeder No / Name : 203 / 11 kv Chandur Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.4572	.4191	.362	.4191
2	.4954	.4572	.4191	.362	.4191
3	.4954	.4572	.4191	.362	.4191
4	.4954	.4572	.4191	.362	.4191
5	.5335	.4954	.4191	.362	.4954
6	.6478	.6859	.4191	.4344	.6478
7	.7842	.7095	.6859	.724	.7468
8	.6722	.6722	.7392	.6516	.7095
9	.6722	.5792	.7095	.5914	.5914
10	.5914	.543	.5914	.4805	.5914
11	.5175	.4706	.5792	.4191	.4481
12	.5175	.4344	.5014	.4108	.4435
13	.5175	.4344	.3982	.381	.4435
14	.4481	.4344	.4024	.3658	.4435
15	.4024	.3982	.4024	.3658	.4435
16	.4435	.3982	.4024	.4066	.4435
17	.5373	.5544	.6154	.439	.5175
18	.8048	.695	.6154	.6722	.695
19	.7762	.7023	.724	.6722	.7468
20	.6722	.6722	.6878	.6348	.6348
21	.6478	.6097	.543	.5601	.5716
22	.5716	.5716	.4344	.4954	.4954
23	.4954	.4954	.3982	.4191	.4572
24	.4954	.4572	.4572	.362	.4191
Max	.8048	.7095	.7392	.724	.7468
Min	.4024	.3982	.3982	.362	.4191
Avg	.5721	.5351	.5168	.4707	.5276

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292] BU 2925

Substation No/ Name :- 074005 / 33 kv Chandur s/s

Feeder No / Name : 204 / 11 kv Wadner Gaothan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.5716	.4954	.7964	.9922
2	.6097	.4954	.4954	.7964	.9922
3	.6097	.4954	.4954	.7964	.9922
4	.6097	.4954	.4954	.7964	.9922
5	.6478	.5716	.4954	.8688	1.0277
6	.7621	.724	.6859	1.0136	1.0867
7	.8002	.8002	.7621	1.3756	1.5775
8	.724	.6097	.724	1.4118	1.5261
9	1.2403	1.1946	1.1869	.4954	.5544
10	1.5432	1.448	1.4083	.4572	.6283
11	1.5432	1.7013	1.4586	.4191	.5544
12	1.5947	1.5203	1.4091	.4572	.5175
13	1.595	1.5203	1.3279	.381	.4435
14	1.3413	1.3394	1.2498	.4572	.4435
15	1.4083	1.3032	1.1934	.4954	.4435
16	1.5424	1.4118	1.1603	.5175	.5175
17	.4435	.4805	.362	.5544	.5914
18	.8589	.7095	.543	.8215	.7842
19	.7842	.7095	.6516	.8589	.8589
20	.6722	.6722	.6516	.8215	.7842
21	.7095	.6859	.543	.7468	.6478
22	.6859	.5716	.4706	.6283	.6097
23	.5716	.5335	.8326	1.0631	1.0517
24	.6097	.5335	.4954	.7964	.9816
Max	1.595	1.7013	1.4586	1.4118	1.5775
Min	.4435	.4805	.362	.381	.4435
Avg	.9382	.8791	.8164	.7428	.8166

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292] BU 2925

Substation No/ Name :- 074005 / 33 kv Chandur s/s

Feeder No / Name : 205 / 11 KV JEEGAON AG FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2439	.7225
2				.7011	.7225
3				.7011	.7225
4				.7011	.7225
5				.7011	.7225
6				.7316	.7225
7				.7621	.7621
8				.7316	.8025
9	.7042	.7926	.7811		
10	.8322	.8535	.8951		
11	.9393	.9145	1.012		
12	.9717	1.086	1.0311		
13	.9488	.9145	.9374		
14	.8855	.9145	.9877		
15	.9488	1.1222	.9374		
16	.8962	.884	.9488		
23			.7011	.7499	.5418
24				.7011	.7499
Max	.9717	1.1222	1.0311	.7621	.8025
Min	.7042	.7926	.7011	.2439	.5418
Avg	.8908	.9352	.9146	.6725	.7191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074014 / 33 kv Fuly s/s

Feeder No / Name : 201 / 11 kv Takarkhed Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353		.4854	.4858	.0671
2	.4024		.4694	.4858	.0671
3	.4024		.5228	.5182	.0671
4	.4359		.5601	.5182	.0671
5	.6036		.5975	.5668	.0671
6	.7209		.7095	.7773	
7	.9012		.8775	.9231	
8	1.073		1.0642	1.1498	
9					.8029
10		1.0395			1.004
11		1.3748			1.1012
12		.9556			1.2323
13		.9892			1.1043
14		1.0059			1.0883
15		1.0395			1.1012
16		1.0852			1.085
19	.0486		.0486		
20	.0648	.056	.0648	.0671	.0671
21	.0648	.056	.0648	.0671	.0671
22	.0648	.056	.0648	.0671	.0671
23	.0648	.3174	.2267	.0671	.4641
24	.0671		.4854	.2267	.0671
Max	1.073	1.3748	1.0642	1.1498	1.2323
Min	.0486	.056	.0486	.0671	.0671
Avg	.3750	.7250	.4458	.4554	.5326

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292] BU 2925

Substation No/ Name :- 074014 / 33 kv Fuly s/s

Feeder No / Name : 202 / 11 kv Fuly Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0503		.0373	.0324	.639
2	.0503		.0377	.0324	.639
3	.0503		.056	.0324	.639
4	.0503		.0566	.0324	.6882
5	.0503		.0566	.0324	.6882
6					.7209
7					.9442
8					1.3123
9	.6958		.9149	.6802	
10	1.4413		1.4243	.9804	
11	1.5546		1.6964	1.186	
12	1.5708		1.7284	1.439	
13	1.4563		1.6324	1.4706	
14	1.3763		1.5684		
15	1.3123		1.5043	1.2334	
16	1.2793		1.4563	.9804	
19	.0324		.0324		
20	.0324	.056	.0324	.0503	.0503
21	.0324	.056	.0324	.0671	.0503
22	.0324	.056	.0324	.0503	.0503
23	.0324	.056	.0324	.6133	.0503
24	.0503		.056	.0324	.6316
Max	1.5708	.056	1.7284	1.4706	1.3123
Min	.0324	.056	.0324	.0324	.0503
Avg	.5869	.056	.6520	.5262	.5464

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074014 / 33 kv Fuly s/s

Feeder No / Name : 203 / 11 kv Shemba Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012		.1307	.1619	.1844
2	.2012		.1307	.1619	.1844
3	.2012		.1494	.1619	.1844
4	.2012		.1494	.1619	.2012
5	.2515		.168	.1943	.3018
6	.2683		.1867	.2591	.3688
7	.3277		.2427	.2915	.6203
8	.285		.2614	.2429	.7209
9	.3441		.3921	.3887	.2683
10	.6154	.1867	.6154	.4915	.1457
11	.6478	.1307	.7287	.6062	.1296
12	.7537	.1307	.7611	.6154	.1134
13	.7125	.1132	.7449	.639	.1134
14	.6802	.132	.7125		.1134
15	.6802	.1307	.6802	.6226	.1296
16	.664	.1494	.5992	.6062	.1457
17	.1619	.1494		.0983	.1781
18	.2753	.2427	.2429	.213	.285
19	.2591	.2801	.2915	.2486	.2515
20	.2429	.2801	.2591	.2347	.218
21	.2105	.2427	.2267	.2012	.1844
22	.1943	.1867	.1943	.1844	.1509
23	.1943	.1307	.1619	.1844	.1677
24	.2012		.1307		.1844
Max	.7537	.2801	.7611	.639	.7209
Min	.1619	.1132	.1307	.0983	.1134
Avg	.3656	.1776	.3548	.3168	.2311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074014 / 33 kv Fuly s/s

Feeder No / Name : 205 / 11 kv Fuly Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686		.0566	.0655	.0686
2	.0686		.0566	.0655	.0686
3	.0686		.0566	.0655	.0686
4	.0686		.0566	.0655	.0686
5	.0857		.0754	.0655	.0686
6	.0857		.0943	.0819	.0686
7	.0857		.0934	.0655	.0686
8	.0671		.0943	.0655	.0671
9	.0671		.0754	.0655	.0671
10	.0655	.0754	.0655	.0671	.0655
11	.0655	.0754	.0655	.0671	.0655
12	.0655	.0754	.0655	.0671	.0655
13	.0655	.0566	.0655	.0671	.0655
14	.0655	.0566	.0655		.0655
15	.0655	.0566	.0655	.0671	.0655
16		.0754	.0655	.0671	.0655
17	.0655	.0754		.0671	.0655
18	.0819	.0943	.0655	.0838	.0857
19	.0983	.0943	.0819	.1017	.1029
20	.0819	.1132	.0983	.1029	.0686
21	.0819	.0943	.0819	.0857	.0686
22	.0819	.0943	.0655	.0686	.0686
23	.0655	.0754	.0655	.0686	.0686
24	.0686		.0754	.0655	.0686
Max	.0983	.1132	.0983	.1029	.1029
Min	.0655	.0566	.0566	.0655	.0655
Avg	.0732	.0795	.0718	.0718	.0696

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074014 / 33 kv Fuly s/s

Feeder No / Name : 206 / 11 kv Shemba Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058		.1307	.1311	.1543
2	.2058		.1307	.1311	.1543
3	.2058		.1307	.1311	.1543
4	.2058		.1494	.1638	.1715
5	.2401		.1494	.213	.2058
6	.2743		.1867	.213	.2401
7	.2883		.2241	.2458	.2683
8	.2515		.2614	.1966	.2347
9	.1677		.2054	.1638	.1677
10	.1147	.1494	.1147	.1509	.1311
11	.1147	.112	.1147	.1341	.1147
12	.1147	.1307	.1147	.1174	.1147
13	.1147	.132	.1147	.0983	.1147
14	.1147	.1307	.1147		.1147
15	.1147	.1132	.1147	.1174	.1311
16	.1147	.1509	.1311	.1341	.1311
17	.1475	.1696		.1509	.1638
18	.2458	.2241	.1802	.218	.2401
19	.2622	.2427	.2458	.2543	.2572
20	.2622	.2614	.2294	.2401	.2572
21	.2458	.2427	.213	.2058	.2058
22	.2294	.1867	.1638	.1715	.1715
23	.1966	.168	.1311	.1543	.1543
24	.2058		.1307	.1311	.1543
Max	.2883	.2614	.2614	.2543	.2683
Min	.1147	.112	.1147	.0983	.1147
Avg	.1935	.1724	.1601	.1682	.1753

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292] BU 2925

Substation No/ Name :- 074028 / 33 kv Naigaon s/s

Feeder No / Name : 201 / 11 kv Kolasar Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.8402	.9431
2		.0343		.8573	.9259
3		.0343		.8573	.9431
4		.0343		.8745	.9774
5				1.0117	1.0288
6				1.1145	1.0974
7				1.2174	1.3717
8				1.3717	1.4575
9		1.1317			
10	1.286				
11	1.5604		1.5261		
12	1.406		1.5089		
13	1.5604		1.4575		
14	1.6118		1.3717		
15	1.5261		1.4403		
16	1.4918		1.4746		
19	.0686		.0686	.0686	
20	.0686		.0686	.0686	
21	.0686		.0686	.0686	
22	.0686			.0686	
23	.0514			.8745	
24		.0514		.8059	.9088
Max	1.6118	1.1317	1.5261	1.3717	1.4575
Min	.0514	.0343	.0686	.0686	.9088
Avg	.8974	.2572	.9983	.7214	1.0726

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074028 / 33 kv Naigaon s/s

Feeder No / Name : 202 / 11 kv Naigaon Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1886		.0343	.0343
2		.2058		.0343	.0343
3		.2058		.0343	.0343
4		.2229		.0343	.0343
5		.2572			
6		.3258			
7		.3601			
8		.583			
9				.2572	.3086
10				.3944	
11				.3601	
12				.3772	
13				.3601	
14				.3772	
15				.3601	
16				.3429	
19	.0514		.0686	.0514	
20	.0686		.0686	.0514	
21	.0686		.0514	.0514	
22	.0686			.0343	
23	.0514			.0343	
24		.0514		.0343	.0343
Max	.0686	.583	.0686	.3944	.3086
Min	.0514	.0514	.0514	.0343	.0343
Avg	.0617	.2667	.0629	.1791	.0800

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074028 / 33 kv Naigaon s/s

Feeder No / Name : 203 / 11 kv Naigaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0857		.0686	.0686
2		.0686		.0686	.0514
3		.0686		.0686	.0514
4		.0686		.0686	.0686
5		.0686		.0686	.1029
6		.0857		.0857	.12
7		.0857		.0857	.0857
8		.0686		.0857	.0857
9		.0686		.1029	.0857
10	.0514			.0686	
11	.0514		.0686	.0514	
12	.0514		.0514	.0514	
13	.0514		.0686	.0514	
14	.0686		.0686	.0514	
15	.0686		.0686	.0686	
16	.0686		.0686	.0686	
17	.0686		.0857	.0686	
18	.12		.12	.1029	
19	.12		.12	.12	
20	.12		.12	.12	
21	.12		.1029	.1029	
22	.12			.0857	
23	.1029			.0686	
24		.0857		.0857	.0514
Max	.12	.0857	.12	.12	.12
Min	.0514	.0686	.0514	.0514	.0514
Avg	.0845	.0754	.0857	.0779	.0771

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074028 / 33 kv Naigaon s/s

Feeder No / Name : 204 / 11 kv Kolasar Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2401		.2058	.1886
2		.2229		.2058	.2058
3		.2229		.1886	.1886
4		.2229		.2058	.2229
5		.2572		.2229	.2572
6		.2915		.2572	.2915
7		.3429		.3258	.3258
8		.2915		.2743	.3086
9		.2743		.2401	.2572
10	.2572			.2058	
11	.2229		.2401	.2229	
12	.2058		.2229	.2058	
13	.2229		.2058	.1886	
14	.2229		.2058	.1886	
15	.2401		.2229	.1886	
16	.2058		.2401	.1715	
17	.2401		.2915	.2229	
18	.4287		.3601	.3601	
19	.4458		.4287	.4458	
20	.4115		.3944		
21	.3772		.3086	.3258	
22	.3258			.2401	
23	.2743			.2058	
24		.2401		.2229	.1886
Max	.4458	.3429	.4287	.4458	.3258
Min	.2058	.2229	.2058	.1715	.1886
Avg	.2915	.2606	.2837	.2401	.2435

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292] BU 2925

Substation No/ Name :- 074028 / 33 kv Naigaon s/s

Feeder No / Name : 205 / 11 KV SHELGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7888		.12	.1029
2		.8059		.12	.1029
3		.8402		.12	.1029
4		.8745		.12	.1029
5		1.0117			
6		1.3203			
7		1.5947			
8		1.6975			
9				1.166	1.2689
10				1.5947	
11				1.749	
12				1.5947	
13				1.5604	
14				1.4575	
15				1.4403	
16				1.4575	
19	.1372		.1372	.12	
20	.1543		.1543	.1372	
21	.1543		.1543	.0686	
22	.1543			.12	
23	.1372			.1029	
24		.1372		.12	.1029
Max	.1543	1.6975	.1543	1.749	1.2689
Min	.1372	.1372	.1372	.0686	.1029
Avg	.1475	1.0079	.1486	.7316	.2972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292] BU 2925

Substation No/ Name :- 074029 / 33 kv Nandura s/s

Feeder No / Name : 201 / 11 kv Town SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7682	.7545	.6516	.7682	.7468
2	.8048	.7545	.6516	.7842	.7468
3	.8131	.823	.6516	.7316	.7392
4	.823	.8916	.6859	.724	.7392
5	.8501	.9945	.6859	.8316	.8779
6	1.0164	1.0288	.8573	.924	1.0242
7	1.1458	1.2003	1.0631	1.0349	1.1949
8	1.3306		1.0974	1.2803	1.3443
9	1.0974	1.1088	1.1203	1.1576	1.1888
10	1.0719	1.0349	1.1203	1.0349	1.0242
11	1.0974	1.0242	.9709	.9709	1.0059
12	1.0974	1.0349	.9335	.924	.9511
13	.823	1.0242	.8962	.8962	.9145
14	.7926	.9709	.8589	.8871	.7095
15	.7926	.9511	.8048	.9335	.7392
16	.7316	.9709	.8215	.9335	.961
17	.823	.8573	1.0974	.9709	1.1203
18	.8573	.823	1.1888	1.1949	1.1949
19	.9259	.8573	1.1458	1.1949	1.2696
20	.9259	.8916	1.1088	1.1088	1.3443
21	.8916	.9945	1.0242	1.0456	1.1203
22	.8916	.9945	.924	.961	
23	.823	.6859	.823	.8962	
24	.7682	.7545		.7392	.7468
Max	1.3306	1.2003	1.1888	1.2803	1.3443
Min	.7316	.6859	.6516	.724	.7095
Avg	.9151	.9316	.9210	.9553	.9865

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292] BU 2925

Substation No/ Name :- 074029 / 33 kv Nandura s/s

Feeder No / Name : 202 / 11 kv Dairy

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7164			.7682
2	.7602			.7762
3	.7762			.7468
4	.8048			.7842
5	.8316			.7682
6	.9979			
7	1.1088			
8	1.2197			
9	1.2012			
10	1.2197			
11	1.1888			
12	1.1827			
17			1.0242	
18			1.1827	
19		1.1203	1.1458	
20			1.1458	
21			1.0059	
22			.924	
23			.823	
24	.7392		.6516	.7392
Max	1.2197	1.1203	1.1827	.7842
Min	.7164	1.1203	.6516	.7392
Avg	.9806	1.1203	.9879	.7638

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292] BU 2925

Substation No/ Name :- 074029 / 33 kv Nandura s/s

Feeder No / Name : 203 / 11 kv Rural Ag Feeder FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.056			.0867
2		.056			.0867
3		.056			.0876
4		.056			.0876
5		.0747			.0867
6		.0747			.104
7		.0747			.0848
8					.1029
9	.0347		.0549	.0747	
10	.0549		.0549	.0533	
11	.0693		.0533	.0533	
12	.0526		.0533	.0533	
13	.056		.0533		
14	.056		.0533		
15	.056		.0533		
16	.056		.0533	.0533	
23				.0857	
24					.0857
Max	.0693	.0747	.0549	.0857	.104
Min	.0347	.056	.0533	.0533	.0848
Avg	.0544	.0640	.0537	.0623	.0903

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292] BU 2925

Substation No/ Name :- 074029 / 33 kv Nandura s/s

Feeder No / Name : 204 / 11 kv Nandura Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4481			.5201
2		.5228			.5201
3		.5228			.5258
4		.5975			.5258
5		.7095			.5201
6		.7468			.5201
7		.7468			.6173
8					.6241
9	.3506		.4664	.5068	
10	.4382		.1947	.5735	
11	.7011		.5868	.5735	
12	.8779		.5601	.5601	
13			.5335	.5601	
14			.5068	.5601	
15	.6097		.4934	.5868	
16	.5182		.7207	.5601	
23				.4458	
24					.6241
Max	.8779	.7468	.7207	.5868	.6241
Min	.3506	.4481	.1947	.4458	.5201
Avg	.5826	.6135	.5078	.5474	.5553

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074029 / 33 kv Nandura s/s

Feeder No / Name : 205 / JALAGAON ROAD FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1494	.1494	.1829	.7468
2	.1867	.1494	.1494	.1848	.7468
3	.1829	.1494	.1494	.1829	.7468
4	.1829	.1867	.1494	.1848	.7392
5	.1848	.1867	.1867	.1848	.8131
6	.1848	.2241	.1867	.1829	.9145
7	.1848	.2987	.2614	1.0974	1.3817
8	.2218	.1494	.2987	1.1888	1.419
9	.3292	.2641	.5174	1.1827	1.3717
10	.3292	.3696	.5174	1.1458	1.307
11	.3658	.4108	.3326	1.1203	1.2567
12	.3292	.3326		1.0719	1.2012
13	.3361	.3658	.3734	1.0719	1.2803
14	.3361	.3292	.3734	1.0829	1.3169
15	.2987	.3658	.3361	1.0349	1.3535
16	.1829	.3658	.3326	1.0349	1.3717
17	.2241	.3734	.2561	1.1203	1.4563
18	.2614	.3361	.2926	1.307	1.6804
19	.2987	.3361	.2926	1.3817	1.5893
20	.3361	.2987	.2926	1.3817	1.4415
21	.3361	.2987	.2561	1.1203	1.2437
22	.2614	.2241	.2561	1.0456	
23	.2241	.1867		.8676	
24	.2241	.1867	.1867	.2427	.7545
Max	.3658	.4108	.5174	1.3817	1.6804
Min	.1829	.1494	.1494	.1829	.7392
Avg	.2577	.2724	.2794	.8584	1.1878

From 08-DEC-17 and 14-DEC-17

**Feeder No / Name : 401 / 33KV MAIN INCOMMER FEEDER NON SHEDDABLE WATER SUPPLY AND
TO N Feeder KV- 33 / INCOMING UTILITY**

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.1267	4.369	5.1532	5.1578	3.7609
2	4.1907	4.0329	5.1532	4.5462	3.7071
3	4.6571	4.5931	5.4893	4.6091	3.9729
4	4.2981	5.6013	5.6013	4.7188	4.0832
5	4.4525	5.6013	6.1614	5.1006	4.3439
6	5.9414	6.1614	6.7215	4.7051	4.6696
7	6.8959	6.7215	7.2817	6.2809	6.0174
8	7.2817		7.2817	6.8416	6.2574
9	4.2353	5.4687			5.5876
10	6.3626	7.1136			5.9934
11	5.2058	7.5057			6.749
12	6.9176	7.2628			6.6655
13	6.7215	6.7776			6.2734
14	6.9456	6.5535			6.2094
15	6.4415	6.8193			6.3855
16	6.4975	2.7469		6.2094	6.5421
17	5.6013	3.6969	4.9429	2.7641	
18	4.481	3.8089	3.8552	3.3608	
19	4.369	3.8089	3.786	3.8089	
20	3.8089	4.369	4.1027	3.4728	
21	3.4728	4.481	3.1493	3.0807	
22	3.8089	5.3772	2.9127	2.6886	
23	3.4979	3.8649	5.1006	4.0929	
24	2.4691		5.1532	4.6091	3.774
Max	7.2817	7.5057	7.2817	6.8416	6.749
Min	2.4691	2.7469	2.9127	2.6886	3.7071
Avg	5.1117	5.3062	5.1154	4.4734	5.3525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074029 / 33 kv Nandura s/s

Feeder No / Name : 402 / 33 KV Outgoing fdr

Feeder KV- 33 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9447			3.4374	1.9982
2				3.1161	2.0576
3	3.155			3.3265	1.9982
4				3.5482	2.2325
5	3.6037			3.4374	2.3137
6	3.6808			3.4374	2.4451
7	4.1267			4.3004	2.9647
8	4.5268			4.4056	2.8995
9	1.5775	3.1687			3.4208
10	3.2922	4.8663			3.678
11	1.9982	5.2092			4.4993
12	3.7551	4.8731			4.5268
13		4.6399			4.181
14		4.4702			4.3244
15		4.8097			4.4702
16		.7682			4.2135
17			3.0178	.8505	
18			1.3969	.8962	
19				1.4563	
20			1.4969	1.2323	
21			1.2071	1.2323	
22			1.1203	1.0185	
23			3.1699	2.0805	
24	1.0208		3.6214	3.2487	2.0805
Max	4.5268	5.2092	3.6214	4.4056	4.5268
Min	1.0208	.7682	1.1203	.8505	1.9982
Avg	3.0620	4.1007	2.1472	2.5640	3.1944

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292] BU 2925

Substation No/ Name :- 074042 / 33 kv Sujatpur s/s

Feeder No / Name : 201 / 11 kv Chikhali Ag
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.056	.2724		.056
2		.056	.2724		.056
3		.056	.3191		.0373
4		.056	.322		.0373
5		.056	.3521		.0373
6		.0373	.3772		.0373
7			.3715		
9					.373
10		.3772			.3772
11		.3963			.3963
12		.415			.4087
13		.4024			.3715
14		.3772			.3839
15		.3772			.4024
16		.3772			.4085
19	.0747	.0495		.0747	.0377
20	.0747	.0377		.0747	.0377
21	.0747			.0747	.0377
22	.056	.0377		.056	
23	.056	.2477		.056	
24		.056	.2477		.056
Max	.0747	.415	.3772	.0747	.4087
Min	.056	.0373	.2477	.056	.0373
Avg	.0672	.1927	.3168	.0672	.1973

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292] BU 2925

Substation No/ Name :- 074042 / 33 kv Sujatpur s/s

Feeder No / Name : 202 / 11 kv Amboda Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4748			.4694
2		.5426			.4694
3		.4973			.4694
4		.503			.4641
5		.5365			.4862
6		.6299			.5636
7		.6962			.6796
8		.779			.6962
9	.5316		.4287	.3856	
10	.8215		1.5547	.8192	
11	.8684		1.6872	.8029	
12	.9282		1.6872	.8288	
13	.852		1.605	.8215	
14	.8453		1.4815	.7537	
15	.7625		1.4507	.7293	
16	.7956		1.5181	.779	
23				.3856	
24					.4527
Max	.9282	.779	1.6872	.8288	.6962
Min	.5316	.4748	.4287	.3856	.4527
Avg	.8006	.5824	1.4266	.7006	.5278

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074042 / 33 kv Sujatpur s/s

Feeder No / Name : 203 / 11 kv Amboda Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1267	.1372	.0754	.1109	.1214
2	.128	.1029	.0743	.1109	.104
3	.1294	.1052	.0743	.1109	.1029
4	.1294	.104	.0754	.1097	.1052
5	.128	.12	.0991	.1097	.1402
6	.1433	.12	.1036	.1254	.1543
7		.1214	.0894	.1629	.156
8	.1227	.1214	.0743	.1578	.1372
9	.128	.0857	.1115	.1267	.12
10	.1052	.0619	.1402	.1214	.0629
11	.0876	.0629	.1227	.1029	.0629
12	.0876	.0495	.1052	.0848	.0383
13	.0876	.0638	.1052	.0867	.0503
14	.0693	.0619	.0905	.0857	.0503
15	.0867	.0629	.0886	.0876	.0629
16	.0867	.0629	.0876	.1029	.0743
17	.1052	.0619	.0895	.1214	.0754
18	.1928	.1149	.2012	.1543	.1006
19	.1886	.1425	.2033	.1715	.1149
20	.1734	.1257	.1829	.1715	.1296
21	.1734	.1257	.1663	.1715	.1132
22	.1715	.1006	.1494	.1734	
23	.1715	.1036	.1307	.156	
24	.1494	.1578	.0743	.1294	.1578
Max	.1928	.1578	.2033	.1734	.1578
Min	.0693	.0495	.0743	.0848	.0383
Avg	.1292	.0990	.1131	.1269	.1016

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074042 / 33 kv Sujatpur s/s

Feeder No / Name : 204 / 11 kv Industrial feeder

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0259	.0259	.0377	.0259	
2	.0255	.0248	.0372	.0255	
3	.0255	.0255	.0377	.0255	
4	.0259	.0263	.0377	.0255	
5	.0259	.0263	.0377	.0255	
6	.0259	.0259	.0251	.0255	
7		.0255	.0251		
8	.013	.0267	.0251		
9	.0255	.0251	.0126		
10	.0274	.0126	.0255		
11	.0263	.0124	.0366		
12	.0263	.0126	.0236		
13	.0248		.0244		
14	.0244		.0255		
15	.0248		.0255		.0124
16	.0248	.0124	.0244		.0251
17	.0255		.0255		.0251
18	.0263		.0259		.0255
19	.0251		.0244		
20	.0255		.0255		.0248
21	.0255	.0251			.0259
22	.0267	.0251	.0255		
23	.0259	.0251	.0255		
24	.0251	.0251	.0251	.0244	
Max	.0274	.0267	.0377	.0259	.0259
Min	.013	.0124	.0126	.0244	.0124
Avg	.0251	.0225	.0278	.0254	.0231

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292] BU 2925

Substation No/ Name :- 074042 / 33 kv Sujatpur s/s

Feeder No / Name : 205 / 11 kv Chikhali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0846	.0812	.0754	.0549	.0549
2	.0846	.08	.0754	.0549	.0549
3	.0705	.0812	.0629	.0541	.0541
4	.0695	.0823	.0629	.0541	.0556
5	.0686	.08	.0619	.0541	.0686
6	.0686	.0934	.0495	.0541	.0823
7		.1082	.0495	.0541	.0812
8	.0934	.1082	.0629	.08	.0812
9	.1113	.0934	.088	.1067	.0934
10	.1372	.0991	.1097	.0812	.1509
11	.2	.1257	.1113	.0947	.0991
12	.1867	.1486	.1235	.1067	.1257
13	.2029	.1257	.1113	.1067	.1383
14	.2134	.088	.1097	.092	.1509
15	.2	.1006	.1235	.08	.1532
16	.2029	.1006	.1252	.0686	.1532
17	.1217	.1257	.1692	.0823	.1915
18	.08	.0907	.1509	.1269	.1132
19	.1334	.1036	.0947	.1097	.1006
20	.1646	.1132	.0823	.0823	.0754
21	.1082	.1257	.0823		.0754
22	.096	.1257	.0541		
23	.0947	.1132	.0541		
24	.0974	.0934	.0991	.0549	.0667
Max	.2134	.1486	.1692	.1269	.1915
Min	.0686	.08	.0495	.0541	.0541
Avg	.1257	.1036	.0912	.0787	.1009

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074066 / 33 kv Mahalungi s/s

Feeder No / Name : 201 / 11 kv Maha Gfss

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17	14-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	.0165	.1646	.1494	.1307	
2	.168	.0146	.1663	.1494	.1307	
3	.1494	.0146	.1463	.1307	.112	
4	.1494	.0183	.1463	.1494	.112	
5	.1494	.0219	.1463	.1494	.1494	
6	.1867	.0256	.1646	.168	.168	
7	.1867	.0201	.1829	.1867	.1494	
8	.1494	.0421	.1646	.168	.1307	
9	.1307	.1478	.1307	.1463	.0128	
10	.1307	.128	.1307	.128	.0128	
11	.112	.1294	.1307	.1463	.0128	
12	.1307	.1109	.1307	.1494	.0113	
13	.1307	.1109	.112		.011	
14	.1307	.1294	.112	.1478	.0128	
15	.112	.128	.112	.1294	.0128	
16		.128	.1307	.1294	.0128	
17	.0183	.2218	.2054	.2241	.0219	.1867
18	.0293	.2926	.2614	.2614	.0293	.2427
19	.0293	.2772	.2801	.2614	.0311	.2801
20	.0256	.2402	.2987	.2614	.0256	.2801
21	.0219	.2378	.2801	.2241	.0165	.2427
22	.0201	.2033	.2054	.2054	.0128	.2054
23	.0183	.1829	.168	.168		.168
24	.1867	.0146	.1663	.1494	.1494	
Max	.1867	.2926	.2987	.2614	.168	.2801
Min	.0183	.0146	.112	.128	.011	.168
Avg	.1102	.1190	.1724	.1732	.0639	.2294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074066 / 33 kv Mahalungi s/s

Feeder No / Name : 202 / 11 kv Maha Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17	14-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0351	.0219	.0549	.0373	.2229	
2	.0351	.0219	.0549	.0373	.2058	
3	.0351	.0238	.0366	.0373	.2229	
4	.0351	.0238	.0549	.0373	.2229	
5	.0351	.0256	.0366	.0373	.2401	
6		.0293		.0373	.2543	
7		.0421			.4694	
8		.0622			.503	
9	.3734		.2401	.3734		
10	.5975		.57	.4755		
11	.6348		.6371	.5853		
12	.6535		.5197	.5853		
13	.6722		.503	.6036		
14	.6348		.4694	.5975		
15	.5975		.4527	.5228		
16			.4668	.4854		
19	.0055	.0366	.0373	.0526	.0055	.0526
20	.0055	.0549	.0373	.0526	.0055	.0526
21	.0055	.0543	.0373	.0526	.0055	.0351
22	.0055	.0366	.0373	.0526	.0055	.0351
23	.0055	.0549	.0373	.1886		.0351
24	.0351	.0055	.0549	.0373	.1886	
Max	.6722	.0622	.6371	.6036	.503	.0526
Min	.0055	.0055	.0366	.0373	.0055	.0351
Avg	.2445	.0352	.2283	.2444	.1963	.0421

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292] BU 2925

Substation No/ Name :- 074066 / 33 kv Mahalungi s/s

Feeder No / Name : 203 / 11 kv Tarw Gfss

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17	14-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	.0165	.1848	.1494	.1494	
2	.168	.0165	.1848	.1307	.1307	
3	.1494	.0165	.1848	.1494	.1307	
4	.1494	.0183	.1646	.168	.1494	
5	.168	.0219	.1646	.168	.1867	
6	.2427	.0256	.2033	.2427	.2427	
7	.2614	.0274	.2195	.2801	.2427	
8	.2054	.0201	.2402	.2614	.2427	
9	.1867	.2033	.2241	.2561	.0238	
10	.168	.2033	.2614	.2402	.0219	
11	.1494	.1848	.1494	.2195	.0165	
12	.1494	.1478	.1307	.1848	.0146	
13	.168	.1109	.1494	.1663	.0183	
14	.168	.1294	.1867	.1848	.0219	
15	.1867	.1478	.2241	.2218	.0183	
16	.168	.1478	.2054	.2402	.0165	
17	.0219	.2218	.2241	.2427	.0201	.1494
18	.0293	.2957	.2801	.2801	.0238	.2614
19	.0293	.2957	.2614	.2801	.0238	.2427
20	.0256	.2772	.2614	.2801	.0201	.2427
21	.0238	.2195	.2427	.2241	.0165	.2241
22	.0219	.2033	.2427	.2054	.0128	.1867
23	.0219	.1848	.2054	.168		.168
24	.1867	.1867	.1848	.1494	.1494	
Max	.2614	.2957	.2801	.2801	.2427	.2614
Min	.0219	.0165	.1307	.1307	.0128	.1494
Avg	.1340	.1384	.2075	.2122	.0823	.2107

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074066 / 33 kv Mahalungi s/s

Feeder No / Name : 204 / 11 kv Tarwadi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17	14-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.0091	.2926	.2987	.1052	
2	.3772	.0091	.2957	.2987	.0876	
3	.4031	.0091	.3174	.3361	.0876	
4	.3772	.0091	.3174	.3361	.0876	
5	.3944	.0091	.3326	.3734	.0876	
6	.3772		.4294	.5041		
7	.9221		.823	.9335		
8	1.0395		1.2696	1.1576		
9		1.0269			.0439	
10		1.1576			.0896	
11		1.3443			.0951	
12		1.4815			.1244	
13		1.6244			.1171	
14		1.4045			.1097	
15		1.2567			.1097	
16		.8686			.1116	
19	.011	.112	.112	.0876	.011	.0876
20	.011	.112	.112	.0876	.011	.0876
21	.011	.112	.0934	.1052	.011	.0934
22	.011	.1109	.0934	.1052	.011	.0876
23	.011	.2987	.1494	.1052		.1715
24	.0876	.0091	.2801	.2987	.1402	
Max	1.0395	1.6244	1.2696	1.1576	.1402	.1715
Min	.011	.0091	.0934	.0876	.011	.0876
Avg	.3126	.5771	.3513	.3591	.0801	.1055

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074073 / 33 kv Nimgaon s/s

Feeder No / Name : 201 / 11 kv Alampur Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0185	.7926	.9175	.5944	.9362
2	.8421	.8749	.8848	.6097	.9313
3	.8421		.8848	.6097	.9412
4	.8745	.8749	.9175	.7011	.8954
5	.8745	.9374	.9503	.823	.905
6	.9069	1.0311	.9831	.823	.9774
7	.7773	1.0936	1.0814	.7926	1.086
8	.9393	1.1248	1.1142	.9374	1.182
9	.9717		1.3717	1.2125	.7773
10	1.2308	1.0669	1.4563	1.4091	.9717
11	1.5729	1.1888	1.3992	1.5402	1.1012
12	1.6385	1.2803	1.5158	1.5729	1.1984
13	1.704	1.2498	1.3717	1.6057	1.1012
14	1.6385	1.2955	1.4861	1.5402	1.0364
15	1.6712	1.2955	1.4861	1.5402	.945
16	1.6057		1.4403	1.5074	1.0669
23		.9831	.6097	.9362	
24		.631	.9503	.6401	.9362
Max	1.704	1.2955	1.5158	1.6057	1.1984
Min	.7773	.631	.6097	.5944	.7773
Avg	1.1943	1.0480	1.1567	1.0775	.9993

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292]

BU 2925

Substation No/ Name :- 074073 / 33 kv Nimgaon s/s

Feeder No / Name : 203 / 11 kv Nimgaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7922	.679	.6226	.5658	.6154
2	.7545	.679	.5898	.5658	.6283
3	.6413	.679	.5571	.5658	.6089
4	.679	.679	.5571	.6413	.5959
5	.679	.7167	.5898	.7545	.7164
6	.9054	.7922	.6554	.7545	.7602
7	.9808	.9431	.8192	.9054	.8954
8	.8676	.8676	.8192	.9054	.8326
9	.6554	.8299	.7922	.7209	.8299
10	.5898	.679	.7545	.6154	.5658
11	.5506	.6413	.7167	.5182	.6413
12	.4915	.6036	.6602	.426	.5281
13	.5243	.6413	.6036	.4588	.5658
14	.4915	.6036	.6036	.426	.5658
15	.5243	.6413	.6036	.4588	.6413
16	.5898		.5658	.4588	.6036
17	.8299	.7537	.7545	.6935	.7167
18	1.2826	1.0486	.9808	.9568	.8299
19	1.2071	1.0814	1.1317	1.0387	1.2449
20	1.094	.9175	.9808	.8596	1.0185
21	.7545		.8676	.8501	.8299
22	.8299	.8192	.8299	.7167	.7545
23	.7545	.7209	.7545	.6722	
24	.9054	.7167	.6554	.679	.6447
Max	1.2826	1.0814	1.1317	1.0387	1.2449
Min	.4915	.6036	.5571	.426	.5281
Avg	.7656	.7606	.7277	.6753	.7232

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-DEC-17 and 14-DEC-17

AKOLA ZONE[062]

BULDHANA CIRCLE[615]

MALKAPUR DIVISION[615]

NANDURA S/DN.[292] BU 2925

Substation No/ Name :- 074073 / 33 kv Nimgaon s/s

Feeder No / Name : 204 / 11 kv Nimgaon Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-DEC-17	09-DEC-17	10-DEC-17	11-DEC-17	12-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4937		1.9334	1.6049	
2	1.5242		1.8679	1.5158	
3	1.7071		1.8023	1.4861	
4	1.6461		1.7368	1.6156	
5	1.5242		1.7368	1.5851	
6	1.5546		1.8023	1.5851	
7	1.7071		1.9334	1.6941	
8	1.768		1.9662	1.6004	
9		1.6766			1.5242
10		1.89			1.8595
11		1.9509			1.9814
12		1.89			1.8595
13		1.9509			1.829
14		1.7071			2.1948
15		1.89			1.8595
16					1.768
23		1.9989	1.5242		
24			1.9662	1.5158	
Max	1.768	1.9989	1.9662	1.6941	2.1948
Min	1.4937	1.6766	1.5242	1.4861	1.5242
Avg	1.6156	1.8693	1.8270	1.5781	1.8595