

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054007 / 33/11KV S/S AMBAJOGAI

Feeder No / Name : 201 / 11 KV HOSPITAL FEEDER Only one consumer of WW with HT-IV
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2401	.2229		.2401	.2743
2			.2401	.2229		.2401	.2572
3			.2401	.2229		.2401	.2572
4			.2572	.2229		.2572	.2743
5			.2915	.2229		.2743	.2743
6			.3086	.2572		.2915	.3086
7			.3258	.3258	.3429	.3258	.3601
8			.3258	.3086	.3258	.3772	.3772
9	.4115	.2915		.3944	.3944		
10	.3601	.3258		.3944	.3944		.3944
11	.3258	.3258	.2572	.3429	.3429	.3429	
12	.3601	.2915		.2915	.2591		
13	.3429	.2915		.2572	.2572		.3258
14	.2743	.2401	.2401	.2572	.2572		
15	.2743	.2743		.1886	.2572	.2572	.2743
16	.2743	.2401		.2229	.2401	.2401	.2743
17		.2743	.2743		.2572		.3258
18		.2743		.2572	.2572	.3258	.3429
19		.2743			.2743	.3086	.3086
20		.2915		.2743	.3258	.3601	.3429
21		.2915	.2915		.3086		.3086
22		.3086			.2915		.2915
23			.2572				
24			.2401	.2401	.2401	.2572	.3086
Max	.4115	.3258	.3258	.3944	.3944	.3772	.3944
Min	.2743	.2401	.2401	.1886	.2401	.2401	.2572
Avg	.3279	.2854	.2707	.2698	.2956	.2892	.3095

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054007 / 33/11KV S/S AMBAJOGAI

Feeder No / Name : 202 / 11 KV YOGESHWARI FEEDER

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6859	.8916		.823	.7545
2			.6859	.8916		.823	.7545
3			.823	.823		.823	.7545
4			.8916	.823		.8916	.823
5			.9602	.8916		.9602	.8916
6			1.0631	.9602		1.0288	.9945
7			1.0974	.9602	1.0974	1.0974	1.0288
8			1.0288	1.0288	1.0974	1.0288	1.0288
9	.9602	.8916		1.0974	1.0631		
10	.8573	.823		1.0974	.9602		.8916
11	.8573	.8916	.8916	.8573	.8916	.7202	
12	.8573	.823		.8916	.823		
13	.8573	1.1145		.8573	.823		.823
14	.823	.8573	.8916	.8916	.7888	1.0974	
15	.8916			1.0288	.7888	.9602	.823
16	1.0288			.823	.7888	.8916	.8916
17			.823		.8573		.8573
18		1.166		.9602	.8573	.4115	.9602
19		1.166			1.0288	1.2346	1.0288
20		1.2346		1.2346	1.0288	1.286	1.166
21		1.166	.9602		1.0288		1.0974
22					1.0288		1.0288
23			1.0288				
24			.7545	.8916	.8916	.823	.823
Max	1.0288	1.2346	1.0974	1.2346	1.0974	1.286	1.166
Min	.823	.823	.6859	.823	.7888	.4115	.7545
Avg	.8916	1.0134	.8990	.9421	.9320	.9313	.9169

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054007 / 33/11KV S/S AMBAJOGAI

Feeder No / Name : 205 / 11 KV MOREWADI-SAIGAON- Urban/Sheddable Urban Feeder
FEEDER Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.2346	1.0974		1.0974	1.0974
2			1.2346	1.0974		1.0974	1.0974
3			1.2346	1.0974		1.0974	1.0974
4			1.2346	1.0974		1.166	1.166
5			1.3375	1.166		1.2346	1.3717
6			1.5089	1.2346		1.3717	1.5089
7			1.6461	1.4403	2.1948	1.6461	1.7833
8			1.5775	1.6461	2.1262	1.6461	1.8519
9	1.6461	1.5089		1.4403	1.8519		
10	1.5089	1.4403		1.4403	1.5775		1.5089
11	1.4403	1.3717	1.4403	1.5089	1.3717	1.4403	
12	1.4403	1.3717		1.5089	1.166	1.3717	
13	1.6461	1.4403		1.4403	1.2346	1.3032	1.2346
14	1.4403	1.4403	1.4403	1.3717	1.166	1.3032	
15	1.4403	1.166		1.2346	1.166	1.166	1.166
16	1.4403	1.166		1.4403	1.2346	1.3375	1.3032
17		1.5089	1.5089		1.3717		1.3717
18		1.6461		1.5089	1.3032	1.5089	1.3717
19		1.7147			1.4403	1.6461	1.7147
20		1.7147		1.6461	1.5089	1.7147	1.8861
21		1.6461	1.5089		1.3717		1.6461
22		1.4403			1.3717		1.5089
23			1.2346				
24			1.3032	1.166	1.3717	1.166	1.3032
Max	1.6461	1.7147	1.6461	1.6461	2.1948	1.7147	1.8861
Min	1.4403	1.166	1.2346	1.0974	1.166	1.0974	1.0974
Avg	1.5003	1.4697	1.3889	1.3465	1.4605	1.3508	1.4205

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054007 / 33/11KV S/S AMBAJOGAI

Feeder No / Name : 207 / 11 KV SHIVAJI CHOWK FEEDER Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6859	.6173		.6173	.6173
2			.6859	.6173		.6173	.6173
3			.6859	.6173		.6173	.6173
4			.6859	.6173		.6859	.6859
5			.7545	.6173		.6859	.6859
6			.7545	.6859		.7545	.7545
7			.7545	.823	.9602	.823	.8916
8			.7545	.823	.9602	.823	.823
9	.823			.823	.8916		
10	.8402	1.0288		.823	.823		.8916
11	.8916		.7545	.7545	.7545	.823	
12	.823	.9602		.7545	.6859	.7545	
13	.7545	.9602		.823	.6173	.7545	.7545
14	.8916	.823	.9602	.823	.6173	.7545	
15	.8916	.823		.7545	.6173	.7545	.7545
16	.8916	.823		.6859	.6173	.7545	.823
17		.6859	.823		.6859		.823
18		.7545		.8916	.7716	.823	.8916
19		1.0288			.8916	1.0288	1.0288
20		1.0974		.9602	.8916	1.0288	1.0288
21		.9602	.9602		.823		.8916
22		.7545			.7545		.8573
23			.6859				
24			.6859	.6516	.7545	.6173	.6173
Max	.8916	1.0974	.9602	.9602	.9602	1.0288	1.0288
Min	.7545	.6859	.6859	.6173	.6173	.6173	.6173
Avg	.8509	.8916	.7594	.7454	.7716	.7621	.7924

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054007 / 33/11KV S/S AMBAJOGAI

Feeder No / Name : 209 / 11KV GFSS JOGAIWADI

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1143	.1143		.1524	.1905
2			.1143	.1143		.1524	.1905
3			.1143	.1143		.1905	.1905
4			.1143	.1143		.2286	.1905
5			.1524	.1143		.2286	.1905
6			.1905	.1524		.1905	.1524
7			.1905	.1524	.1524	.3048	.2667
8			.1905	.1524	.1524	.2286	.2286
9	.2096	.1905		.1524	.1524		
10	.1905	.1524		.1524	.1905		.2286
11	.2286	.1524	.1905	.2286		.3048	
12	.2286	.1334		.2286		.2667	
13	.1715	.1524		.1905	.2286	.2667	.2286
14	.1524	.1524	.1905	.1905	.2286	.2286	
15	.1524	.1524		.1905	.1905	.1905	.2286
16	.1524	.1143		.1524	.2286	.1905	.2286
17		.1905	.1524		.2286		.1905
18		.1143		.1524	.2286	.2286	.2286
19		.1524			.2286	.1524	.2286
20		.1905		.1524	.3048	.2286	.1715
21		.1905	.1524		.2286		.1905
22		.1905			.2286		.1905
23			.1524				
24			.1143	.1143	.1524	.1905	.1905
Max	.2286	.1905	.1905	.2286	.3048	.3048	.2667
Min	.1524	.1143	.1143	.1143	.1524	.1524	.1524
Avg	.1858	.1592	.1524	.1544	.2083	.2180	.2055

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054014 / 33 KV BARDAPUR

Feeder No / Name : 201 / 11 KV MORWAD

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1871	.1494	.136	.1833	.2083	.225	.2675
2	.1852	.1495	.136	.1852	.2083	.211	.2827
3	.1842	.1485	.1393	.1871	.1974	.1696	.3082
4	.2259	.1667	.1848	.2273	.1867	.1632	.322
5	.2268	.1859	.1768	.2277	.1948	.1314	.208
6	.2279	.1871	.2154	.2279	.1807	.1082	.223
7	.1901	.1711	.2227	.2268	.1311	.1471	.2206
8		.1706	.1898	.1871	.1814	.1902	.1734
9	.1497	.189	.189		.1097	.3173	.2241
10		.1893	.1126	.013	.1135	.1367	.1137
11	.3085	.1814	.1362	.0704	.1117	.1504	.1135
12	.2785	.1324	.1078	.1452	.1119	.1108	.1123
13	.2835	.1756	.2363	.2591	.1124	.106	.0751
14	.2798	.2145	.2239	.4115	.1133	.1131	.0758
15	.2465	.2219	.3264	.4841	.1129	.1102	.0756
16	.4824	.2454	.1291	.519	.1123	.1478	.0754
17	.2657	.1623	.2417	.3793	.148	.1459	.0718
18		.1278	.1102	.141	.1468	.1459	.1506
19	.1472	.1463	.1507	.1475	.148	.1871	.1886
20	.1662	.2222	.2245	.1848			.189
21		.1859	.1898	.1892	.2071	.2609	.1867
22		.1871	.1509	.1888		.2254	.189
23		.1507	.189	.2282		.1414	.189
24	.0842	.1871		.1852	.2282	.2273	.1356
Max	.4824	.2454	.3264	.519	.2282	.3173	.322
Min	.0842	.1278	.1078	.013	.1097	.106	.0718
Avg	.2289	.1770	.1791	.2260	.1555	.1683	.1738

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054014 / 33 KV BARDAPUR

Feeder No / Name : 202 / 11 KV BARDAPUR

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3532	.3211	.3297	.4172	.3361	.2092	.3731
2	.3612	.3206	.2843	.4036	.3772	.206	.3704
3	.3902	.3158	.2734	.3944	.3624	.2358	.3493
4	.4085	.5607	.2849	.3269	.3919	.2564	.3368
5	.4271	.3512	.3094	.3475	.3814	.2726	.324
6	.4351	.3426	.3384	.3426	.3919	.269	.2041
7	.3896	.2913	.3719	.3744	.3471	.3029	.1808
8		.2957	.3509	.3384	.4559	.3009	.1337
9	.3371	.3254	.3595		.0988	.4437	.2401
10	.2412	.2341	.3246	.2804	.3004	.2466	.321
11	.2408	.2473	.3772	.3586	.3004	.2561	.3141
12	.2731	.3448		.4211	.3086	.3068	.3109
13		.4022	.1595	.4028	.2507	.2615	.3192
14	.3636	.4632	.4758	.317	.305	.3068	.2591
15	.4929	.4845	.3803	.3542	.2787	.2968	.2622
16		.4929	.3969	.3831	.2657	.2859	.29
17	.4755	.0878	.2635	.3715	.3344	.3388	.3201
18	.5281	.4713	.535	.5578	.399	.3671	.3745
19		.4911	.5053	.4113	.4131	.4437	.4066
20	.4904	.5935	.5617	.4184			.4223
21		.5274	.4832	.3882	.3971	.4691	.4403
22		.488	.472	.3893		.4273	.4348
23		.4396	.4609	.3027		.4104	.3647
24	.3509	.3532		.3887	.3027	.2204	.4536
Max	.5281	.5935	.5617	.5578	.4559	.4691	.4536
Min	.2408	.0878	.1595	.2804	.0988	.206	.1337
Avg	.3858	.3852	.3772	.3778	.3333	.3102	.3252

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054014 / 33 KV BARDAPUR

Feeder No / Name : 203 / 11 KV JAWALGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1126	.1107	.0944	.1378	.0854	.0735	.1308
2	.1152	.1099	.1244	.1396	.0835	.086	.1333
3	.1171		.1207	.1494	.0871	.0887	.1833
4	.1375	.1259	.1269	.1698	.0934	.1173	.2457
5	.1509	.1752	.1379	.1734	.088	.1452	.255
6	.2085	.1773	.1585	.1994	.0566	.1539	.3086
7	.1948	.1658	.1786	.1994	.0154	.0944	.3835
8		.1492	.1673	.1707	.3905	.2406	.3921
9	.155	.1468	.1905		.2122	.1095	.4146
10		.1021	.1317	.1174	.0859	.0628	.0871
11	.3259	.29	.4005	.2138	.0711	.0776	.0796
12		.4057	.3601	.3576	.0668	.0652	.08
13	.4064	.439	.3626	.2987	.0817	.0604	.0601
14	.2246	.4403	.3371	.2954	.0781		.0668
15	.1307	.2221	.3765	.2789	.0658	.0489	.0669
16	.1851	.2661	.3418	.249	.0695	.054	.068
17	.1749	.0805	.2779	.2149	.0758	.0579	.068
18	.085	.061	.0969	.0937	.0793	.0434	.1126
19		.1201	.1293	.1075	.1104	.068	.1296
20	.13	.1486	.1494	.1406			.128
21		.1324	.16	.1392	.152		.1265
22		.1158	.1406	.1437			.1265
23		.1011	.1481	.0796			.112
24	.1335	.1232	.1046	.1357	.0796	.0726	.0926
Max	.4064	.4403	.4005	.3576	.3905	.2406	.4146
Min	.085	.061	.0944	.0796	.0154	.0434	.0601
Avg	.1757	.1830	.2007	.1828	.1013	.0905	.1605

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054020 / 33 KV GHATNANDUR

Feeder No / Name : 201 / 11 KV P00S

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	22-JUN-17	27-JUN-17
HR	Load (MW)	Load (MW)
1	.7773	1.267
2	.823	1.3717
3	.9602	1.5546
4	1.1431	1.848
5	1.2651	2.0698
6	1.3923	2.2405
7	1.5023	2.2405
8	1.5123	
9	1.3998	
10	1.2197	1.3032
11	1.0608	1.1431
12	.5411	
13	.8048	1.848
14	.8413	
15	.9145	
16	.961	
17	1.2382	
18	1.46	
24	.767	1.267
Max	1.5123	2.2405
Min	.5411	1.1431
Avg	1.0834	1.6503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054020 / 33 KV GHATNANDUR

Feeder No / Name : 202 / 11 KV GHATNANDUR

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	22-JUN-17	27-JUN-17
HR	Load (MW)	Load (MW)
1	1.1088	.6859
2	1.1458	.7716
3	1.1203	
4	1.1888	.6588
5	1.2197	.7011
6	1.2826	.7011
7	1.3443	.7011
8	1.1576	.7087
9	1.0719	.663
10	.4344	.724
11	.4607	.8413
12	.4908	
13	.4409	.8669
14	.4854	
15	.5014	
16	.3544	
17	.5218	
18	1.0924	
24	1.0534	.5426
Max	1.3443	.8669
Min	.3544	.5426
Avg	.8671	.7138

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054020 / 33 KV GHATNANDUR

Feeder No / Name : 203 / 11 KV HATOLA

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	22-JUN-17	27-JUN-17
HR	Load (MW)	Load (MW)
1	.583	.5487
2	.5895	.6344
3	.7011	.724
4	.8859	.8173
5	.985	.9145
6	1.0349	1.0031
7	1.2382	1.0031
8	1.0059	.9659
9	.823	.8688
10	.6287	1.0059
11	.6767	.39
12	.744	
13	.8067	
14	.7649	
15	.7649	
16	.8573	
17	.8322	
18	.7202	
24	.5959	.4268
Max	1.2382	1.0059
Min	.583	.39
Avg	.802	.7752

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054031 / 33 KV DHANORA S/S

Feeder No / Name : 201 / 11 KV RADI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10		.1372	.125		.1235	.1852	.1505
11	.2241	.2056	.1562	.3005	.1852	.1505	.1829
12	.2241	.2372		.2846	.216	.1551	.1852
13	.1875	.25	.2187		.2469	.141	
14	.216	.2623	.25	.2343	.1562		
15	.2187	.2286	.25	.1875	.1875	.141	.3292
16	.2187	.2107	.25	.16	.2187	.1692	.2743
17	.2469	.1829		.1619	.1562	.1692	.3841
Max	.2469	.2623	.25	.3005	.2469	.1852	.3841
Min	.1875	.1372	.125	.16	.1235	.141	.1505
Avg	.2194	.2143	.2083	.2215	.1863	.1587	.2510

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054031 / 33 KV DHANORA S/S

Feeder No / Name : 202 / 11 KV AKOLA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667		.2858	.3429	.2667	.2286	.2667
2	.2858		.3239	.3326	.2858	.381	.2858
3	.3429		.3429	.3696	.3429	.381	.3048
4	.4191		.4191	.381	.4191	.381	.381
5	.5144		.4954	.4191	.5335	.5335	.5335
10	.3113		.16		.1989	.216	.3113
11	.3437		.2881	.2652	.2652	.3441	.381
12	.3201	.3605	.3521	.2984	.2984	.192	.3201
13	.3125	.2949	.3201	.2915	.2984		.2881
14	.3125	.2591	.3201	.2561	.2321	.2561	.2949
15	.3437	.1638	.2561	.2401	.2294	.2187	.2949
16	.3437	.1966	.2214		.2949	.1677	.3932
17	.4374	.2429	.2214	.1943	.2949	.2915	.3932
18	.3048	.2477	.3048	.2477		.2477	
19		.4191		.381		.4382	
20		.5335		.4954		.5335	
21		.5335		.4763		.5335	
22		.4572		.4382		.381	
23		.3429		.3429			
24	.3048		.3048	.3429	.3048	.2667	.2858
Max	.5144	.5335	.4954	.4954	.5335	.5335	.5335
Min	.2667	.1638	.16	.1943	.1989	.1677	.2667
Avg	.3442	.3376	.3077	.3397	.3046	.3329	.3382

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054031 / 33 KV DHANORA S/S

Feeder No / Name : 203 / 11 KV MAMDAPUR PATODA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7922		.7733	.7392	.7545	.7392	.6979
2	.8299		.7922	.7392	.7733	.7392	.7356
3	.8488		.8488	.924	.8676	.7392	.7545
4	.9431		.9054	1.0349	.9808	.8501	.8299
5	1.1883		1.1694	1.0719	1.1317	.961	1.0185
10	.8029	.4687	.4999		.2949	.3749	.3521
11	.8718	.6478	.506	.7373	.4915	.4321	.3841
12	1.0059	.7373	.4744	.6882	.5243	.301	.3841
13	1.1065	.6154	.4999	.6249	.583		.4161
14	1.1736	.5121	.5376	.5468	.5243		.4801
15	1.3077	.5601	.6009	.4687			.5761
16	1.278	.664	.5693				.5121
17	.9069	.6882	.4744			.3506	.5761
18	.5914	.7023	.6653	.7207		.5304	
19		.8775		.9997		.9335	
20				1.2637		1.2826	
21		1.1506		1.1317		1.1883	
22		.9997		.9619		.9431	
23		.8488		.8488			
24	.7545		.7545	.7392	.7545	.7392	.7167
Max	1.3077	1.1506	1.1694	1.2637	1.1317	1.2826	1.0185
Min	.5914	.4687	.4744	.4687	.2949	.301	.3521
Avg	.9601	.7287	.6714	.8377	.6982	.7403	.6024

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054046 / 33 KV APEGAON

Feeder No / Name : 201 / 11 KV APEGAON

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0743			.0743			.0743
2	.0743	.0742		.0743		.0742	.0743
3	.0743			.0743			.0743
4	.0743	.0742		.0743		.0742	.0743
5	.0743			.0743			.0743
6	.0743	.0742		.0743			.0743
7	.0743			.0743			.0743
8	.0743	.0742		.0743		.0742	.0743
9	.0743			.0743			.0743
10	.7423	.7423		.4644		.7423	.5573
11	.7423			.5573	.7423	.743	.5573
12	.7438	.5573		.6687	.7423	.743	.6501
13	.7438			.6687	.7423	.743	.6501
14	.7438	.4644	.3715	.5944	.7423	.743	.743
15	.7438		.4644	.5573	.7423	.743	.743
16	.7438				.7423	.743	.7453
17	.7438		.743		.7423	.743	.743
18	.0744		.0743		.0742	.0743	.0743
19			.0743			.0743	.0743
20	.0744		.0743			.0743	.0743
21	.0742		.0743		.0742	.0743	.0743
22			.0743			.0743	.0743
23	.0742		.0743		.0742	.0743	
24	.0743	.0742		.0743		.0742	.0743
Max	.7438	.7423	.743	.6687	.7423	.743	.7453
Min	.0742	.0742	.0743	.0743	.0742	.0742	.0743
Avg	.3176	.2669	.2250	.2659	.5419	.3714	.2828

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054046 / 33 KV APEGAON

Feeder No / Name : 202 / 11 KV TATBORGAN

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0607			.0607			.6074
2	.0607	.0601		.0607		.0601	.0607
3	.0607			.0607			.0607
4	.0607			.0607			.0607
5	.0607			.0607		.0601	.0607
6	.0607	.0601		.0607			.0607
7	.0607			.0607			.0607
8	.0607	.0601		.0607			.0607
9	.0607			.0607			.0607
10	.6005	.6005		.4555		.6005	.4859
11	.6005	.4555		.5466	.6005	.6074	.6074
12		.3796		.6074	.6005	.6074	.6074
13	.6005			.6074	.6005		.6833
14				.6074	.6005	.6074	.6833
15	.6005		.3796	.6074	.6005	.6074	.7592
16	.6005				.6005	.6074	.8351
17	.6005		.6074		.6005	.6074	.9111
18	.0601		.0607		.6005	.0607	.0607
19	.0601		.0607			.0607	.0607
20	.0601		.0607			.0607	.0607
21	.0601		.0607		.0601	.0607	.0607
22			.0607			.0607	.0607
23	.0601		.0607		.0601	.0607	.0607
24	.0607	.0601		.0607		.0601	.6074
Max	.6005	.6005	.6074	.6074	.6005	.6074	.9111
Min	.0601	.0601	.0607	.0607	.0601	.0601	.0607
Avg	.2148	.2394	.1689	.2524	.4924	.2993	.3182

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054046 / 33 KV APEGAON

Feeder No / Name : 203 / 11KV GFSS APEGAON

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1547	.062	.1547	.1547	.1547	.1537	.1547
2	.1547	.062	.1547	.1547	.1547	.1537	.1547
3	.1547	.062	.1547	.1547	.1547		.1547
4	.1547	.062	.1856	.1856	.1547	.1532	.1547
5	.1856	.1555	.1863	.1856	.1856	.1537	.1856
6	.2166	.1866	.2166	.2166	.2475	.1845	.2166
7	.2475	.2177	.2166	.2166	.2475	.2152	.2475
8	.2475	.2177	.2321	.2321	.2166	.2152	.2166
9	.2166	.2177	.1856	.2321	.1856	.1845	.1856
10	.1551	.1555	.1547	.1547	.1547	.1537	.1547
11	.1241		.1238	.1547	.1241	.1547	.1547
12	.0775	.1238	.1238	.1547	.093	.1547	.1238
13	.0775		.0928	.1238	.0775	.1547	.1238
14	.0775	.0928	.0928	.1238	.0775	.0928	.0928
15	.0775		.0774	.0928	.0775	.0928	.0928
16	.0775			.1238	.0775	.0928	.0928
17	.0775		.0928	.0774	.1241	.1238	.0928
18	.0775	.1547	.1238	.1547	.1551	.1547	.1238
19	.1241	.1856	.1547	.1856		.2166	.1547
20	.2171	.1856	.1856	.2475	.216	.2475	.1856
21	.2171	.2166	.1856	.2475		.2166	.2166
22	.1861	.2166	.2166	.2166		.1856	.2166
23	.1551	.1856	.2166	.1856	.1537	.1547	.1856
24	.1547	.1551	.1547	.1856	.1547	.1537	.1547
Max	.2475	.2177	.2321	.2475	.2475	.2475	.2475
Min	.0775	.062	.0774	.0774	.0775	.0928	.0928
Avg	.1504	.1534	.1601	.1734	.1518	.1636	.1599

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054064 / 33 KV SAIGAON

Feeder No / Name : 201 / 11 KV SAIGAON FEEDER
Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3045		.2926	.3582	.3658		.2743
2	.3045		.2926	.3506	.3658		.2743
3	.3045		.2743	.3506	.4024		.2743
4	.362		.2926	.3429	.439		.3155
5	.362		.2926	.3429	.439		.3155
6	.3258		.2926	.3155	.5121		.4024
7	.3475	.3292	.3109	.3403	.7865		.439
8	.439	.3841	.439	.3544		.5487	.5121
9	.4207	.3841	.3658	.4075	.695	.5487	.5175
10	.1989	.1989	.213	.2984	.1823	.1658	.1981
11	.2155	.2652	.218	.2652		.2374	.2155
12	.2321	.2486	.2294	.2652	.1989	.2204	
13	.2155	.2652	.1966	.2652	.2652		.1658
14		.1989	.2012	.2486		.176	.1658
15		.2321	.2321	.2321		.1898	.1823
16	.2155	.2321	.2294	.2321	.1989	.192	
17		.2652	.2883	.2652	.2486	.2743	.1658
18	.5853	.5487	.5068	.5853		.4607	
19	.4024	.4572	.3801	.439	.439	.4706	.3292
20	.4572	.4938	.4344	.4755	.4572	.4656	.3658
21	.4572		.4525	.439		.443	.3841
22			.3801	.4572		.3506	.3658
23		.3292	.3658			.3121	
24	.3045		.3109	.3582	.3658		.2743
Max	.5853	.5487	.5068	.5853	.7865	.5487	.5175
Min	.1989	.1989	.1966	.2321	.1823	.1658	.1658
Avg	.3397	.3222	.3122	.3474	.3976	.3370	.3069

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054064 / 33 KV SAIGAON

Feeder No / Name : 202 / 11 KV SUGAON FEEDER
Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263		.2075	.2075	.2075		.2075
2	.2263			.2075	.1886		.2075
3	.2263			.2075	.2075		.2075
4	.2263		.2263	.2075	.2263		.2263
5	.2263		.2452	.2263	.2641		.2263
6	.2829		.2829	.2641	.2829		.3018
7	.1886	.2263	.1509	.1886	.2641		.2263
8	.1509	.2263	.2263	.1886	.2263	.1886	.1509
9	.132	.132	.1509	.1698	.0943		.132
10	.1829	.2439	.1829	.1677	.1524	.1829	.1829
11	.2134	.2591	.1829	.2134		.2134	.2134
12	.2134	.2134	.2439		.2134	.2439	
13	.2134	.2286	.2286	.3048	.2743		.1829
14		.2286	.2896	.2439		.2134	.2591
15		.2134	.2896	.1829		.2286	.2591
16	.2134	.2134	.2896	.1829	.2439	.1372	
17		.1981	.2743	.1829	.2439	.2439	.3353
18	.1132	.132	.112	.0943		.112	
19	.1509	.1509	.132	.1509	.1509	.1886	.1509
20	.2452		.1886	.2263	.2075	.2452	.2452
21			.2452	.2263		.2075	.2263
22		.2452	.2263	.2263		.2075	.2075
23		.2263	.2263			.2075	
24	.2263		.2263	.2075	.2075		.2075
Max	.2829	.2591	.2896	.3048	.2829	.2452	.3353
Min	.1132	.132	.112	.0943	.0943	.112	.132
Avg	.2032	.2092	.2195	.2035	.2150	.2014	.2178

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054064 / 33 KV SAIGAON

Feeder No / Name : 203 / 11 KV POKHARI FEEDER
Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4525		.4024	.439			.3801
2	.4525		.4024	.439	.439		.3801
3	.4525			.439	.4572		.3801
4	.4938		.5121	.4525	.4755		.462
5	.5304		.5487	.5068	.5121		.499
6	.6401		.6584	.6401	.6036		.6099
7	.7316	.6584	.6036	.6584	.695		.7947
8	.6767	.6219	.5853	.695		.7316	.7762
9	.1886	.567	.6036	.6401	.7316	.6584	.5914
10	.3005	.2688	.4475	.5121	.3005	.3005	.5441
11	.3479	.4001	.5376	.5693		.4372	.5535
12	.3005	.4696	.5121	.6167	.2846	.4218	
13	.3795	.421	.4475	.4801	.506		.5376
14		.4161	.4586	.4428			.5218
15		.4161	.4784	.4481			.4744
16	.506		.503	.4586	.506	.4586	
17		.5761	.5401	.5693	.506	.4428	.5376
18	.6401	.5121	.4887	.5853		.4938	
19	.6036	.6219	.5121	.5853	.5487	.5121	.4572
20	.7499	.695	.6154	.5853	.6401	.6584	.5304
21			.6219	.567		.5304	.5121
22		.5487	.567	.5121		.4887	.439
23		.4572	.4938			.4344	
24	.4525		.3658	.439	.4024		.3801
Max	.7499	.695	.6584	.695	.7316	.7316	.7947
Min	.1886	.2688	.3658	.439	.2846	.3005	.3801
Avg	.4944	.51	.5177	.5340	.5072	.5053	.5181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054064 / 33 KV SAIGAON

Feeder No / Name : 204 / Dudhdairy Express

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0036		.0037	.0036			.0036
2	.0036			.0036	.0037		.0036
3	.0036		.0037	.0036	.0036		.0036
4	.0036		.0036	.0036	.0037		.0036
5	.0036		.0037	.0036	.0036		.0036
6	.0036		.0037	.0036	.0036		.0036
7	.0036	.0036	.0036	.0036	.0036		.0036
8	.0036	.0036	.0036	.0036	.0036	.0362	.0036
9	.0036	.0036	.0036	.0036	.0036	.0362	.0362
10	.0036	.0036	.0036	.0036	.0036	.0366	.0362
11	.0036	.0362	.0036	.0037		.0036	.0362
12	.0036	.0537	.0036	.0036	.0036	.0362	
13	.0362	.0543	.0036	.0036	.0036		.0362
14		.0724	.0036	.0036		.0362	.0362
15		.0543	.0036	.0036		.0362	.0362
16	.0543	.0549	.0036	.0036	.0036	.0362	
17		.0036	.0036	.0036	.0036	.0362	.0362
18	.0543	.0036	.0036	.0036		.0362	
19	.0362	.0036	.0036	.0036	.0032	.0362	.0362
20	.0036		.0036	.0036	.0036	.0036	.0036
21			.0036	.0037		.0036	.0036
22		.0036	.0036	.0036		.0036	.0036
23		.0036	.0036			.0036	
24	.0036		.0036	.0036	.0036		.0036
Max	.0543	.0724	.0037	.0037	.0037	.0366	.0362
Min	.0036	.0036	.0036	.0036	.0032	.0036	.0036
Avg	.0129	.0239	.0036	.0036	.0036	.0254	.0166

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054067 / 33/11 KV PATHAN MANDVA

Feeder No / Name : 201 / 11 KV NAGAZARI

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1576	1.1949	1.1203	1.0829	1.1203	1.1016
2		1.1203	1.1949	1.1203	1.0456	1.1203	1.0829
3		1.1203	1.1949	1.1203	1.1203	1.1203	1.0082
4		1.2696	1.2696	1.1203	1.307	1.1203	1.1203
5		1.419	1.3443	1.1949	1.5466	1.1203	1.4563
6		1.6032	1.6598	1.5089	1.7164	1.5844	1.6598
7		1.6057	1.643	1.5684	1.7364	1.7177	1.7177
8	1.5497	1.587	1.643	1.643	1.6804	1.643	1.6804
9		1.2696			1.643	1.423	
10		1.1706			1.2567		
11		1.086			1.2437	1.134	
12		1.086			1.1584	1.0029	
13		1.086			1.086	1.0029	
14		1.0136			1.0029	.9231	
15		.9055			1.0029	1.0059	
16		1.086			1.086	1.086	
17		1.1584	.691	1.3756	1.1584	1.1765	1.0029
18		1.2308	.6447	1.4842	1.1584	1.3032	1.2178
19	1.5927	1.4632	1.6263	1.4784	1.2437	1.5497	1.7375
20	1.7177	1.4632	1.4937	1.531	1.4784	1.587	1.5524
21		1.4937	1.419	1.4563	1.419	1.419	1.419
22	1.363	1.419	1.3443	1.3443	1.3443	1.307	1.2696
23	1.2696	1.3443	1.2696	2.4646	1.2696	1.2323	1.2696
24	1.2323	1.1949	1.2696	1.2696	1.1203	1.1949	1.1389
Max	1.7177	1.6057	1.6598	2.4646	1.7364	1.7177	1.7375
Min	1.2323	.9055	.6447	1.1203	1.0029	.9231	1.0029
Avg	1.4542	1.2647	1.3064	1.4250	1.2878	1.2563	1.3397

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054067 / 33/11 KV PATHAN MANDVA

Feeder No / Name : 202 / 11 KV RAVIVAR PETH FEEDER Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7602	.724	.724	.7442	.8048	.7087
2		.7602	.724	.724	.7442	.6584	.7087
3		.8048	.724	.724	.7964	.6584	.7602
4		.8413	.7964	.724	.9145	.788	.7964
5		.8871	.8688	.7964	1.0719	.788	.8871
6		.961	.961	.8779	1.1763	1.0349	.961
7		.961	.961	.8871	1.1576	.961	1.0349
8	.961	.9145	.9511	.8871	1.1576	.961	.9709
9		.905			.961	.8688	
10		.7164			.7964		
11		.7087			.788	.7442	
12		.7087			.7712	.695	
13		.7087			.7164	.6859	
14		.6379			.6379	.6588	
15		.6379			.6379	.6516	
16		.6556			.6379	.631	
17		.7087	.788	.7087	.7087	.7202	.5895
18		.788	.9412	.8842	.7796	.823	.7087
19	.9671	.9412	.9412	.9214	.8413	1.0029	.9214
20	1.0029	.9511	1.0136	1.0317	.9313	1.0208	.9313
21	.8775	.9313	1.0136	.9774	.9412	1.0208	.9412
22	.8859	.8688	.8688	.8954	.8779	.9492	.8688
23	.8688	.7964	.7964	.8596	.8779	.815	.8048
24	.8326	.7602	.724	.7964	.7619	.8048	.7087
Max	1.0029	.961	1.0136	1.0317	1.1763	1.0349	1.0349
Min	.8326	.6379	.724	.7087	.6379	.631	.5895
Avg	.9137	.8048	.8623	.8387	.8512	.8151	.8314

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054067 / 33/11 KV PATHAN MANDVA

Feeder No / Name : 203 / 11 KV MUKUNDRAJ FEEDER Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8131	.7762	.7964	.9145	.8131	.7499
2		.7762	.7762	.724	.9145	.7392	.7316
3		.7762	.7762	.724	.961	.7392	.7762
4		.8215	.8131	.724	.9709	.7392	.8131
5		.8402	.8131	.8779	1.1203	.8048	.8589
6		.8589	.8131	.8871	1.2136	.9709	.9335
7		.9335	.8215	.8871	1.3443	1.0456	.9522
8	.961	.9055		.961	1.3817	1.0349	1.0642
9		.8501			1.2696	.9979	
10		.8871			.961		
11		.8048			.961		
12		.8779			.8688	.9412	
13		.9511			.8596	.8775	
14		.8779			.7796		
15		.8326			.788	.8869	
16		.9511			.8688	.8869	
17		1.0242	1.0679	1.0242	.8688	.9412	.7964
18		1.1584	1.2308	1.2437	.9412	1.0136	.8688
19		1.1584	1.3032	1.1222	1.0242	1.2567	1.2308
20	1.2437	1.1584	1.1584	1.1643	1.0349	1.2197	1.1584
21	1.2012	1.1088	1.0136	1.0719	1.0349	1.0425	1.0242
22	.9145	.9511	.9412	1.0242	.8871	.9877	.9511
23	.8779	.8779	.8688	.9877	.8871	.8779	.8779
24	.924	.8501	.8131	.7964	.9511	.8871	.7682
Max	1.2437	1.1584	1.3032	1.2437	1.3817	1.2567	1.2308
Min	.8779	.7762	.7762	.724	.7796	.7392	.7316
Avg	1.0204	.9185	.9324	.9385	.9919	.9383	.9097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054067 / 33/11 KV PATHAN MANDVA

Feeder No / Name : 204 / 11KV KALWATI

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0762	.0076	.0076	.1174	.1052	.1174
2		.0762	.0076	.0076	.1174	.1052	.1174
3		.0762	.0076	.0076	.1341	.1372	.1341
4		.0762	.0076	.0076	.1357	.1357	.1677
5		.0953	.0076	.0076	.2058	.1311	.2012
6		.0953	.0747	.0747	.2229	.2012	.218
7		.1143	.0739	.0747	.2401	.2012	.2374
8	.0953	.0953	.0747	.0076	.2204	.2012	.2374
9		.0057			.1696	.1677	
10		.0983			.0229		
11		.0983			.0057	.0381	
12		.0983			.0057	.0381	
13		.0995			.0057	.0381	
14		.0995			.0057	.0381	
15		.0926			.0076	.0381	
16		.125			.0076	.0381	
17		.1265	.1619	.1296	.0076	.0572	.037
18		.0076	.0076	.0572	.0076	.0762	.0554
19	.0572	.0076	.0076	.0953	.0747	.0762	.0554
20	.0762	.0076	.0076	.0953	.0747	.0934	.0747
21	.0762	.0076	.0076	.0953	.0076	.0953	.0747
22	.0747	.0076	.0076		.0076	.0762	.0747
23	.0762	.0076	.0076	.0762	.0076	.0762	.0747
24	.0762	.0762	.0076	.0076	.0983	.1097	.116
Max	.0953	.1265	.1619	.1296	.2401	.2012	.2374
Min	.0572	.0057	.0076	.0076	.0057	.0381	.037
Avg	.076	.0696	.0298	.0501	.0796	.0989	.1246

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054067 / 33/11 KV PATHAN MANDVA

Feeder No / Name : 205 / 11 KV WATER SUPPLY EXPRESS Only one consumer of WW with HT-IV

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
6		.0633	
7		.0648	
8	.0633	.0625	
9		.0633	
10		.064	
11		.0648	
12		.0655	
13		.0655	
14		.0655	
15		.0633	
16		.0633	
17		.0633	.064
18			.064
19	.0625	.0648	
20		.0648	
Max	.0633	.0655	.064
Min	.0625	.0625	.064
Avg	.0629	.0642	.064

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054067 / 33/11 KV PATHAN MANDVA

Feeder No / Name : 404 / 33 KV DAWAKHANA

HV Group Express Feeder

Feeder KV- 33 / INCOMING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8596	.8596	.8596	.8596	.8596	.7522
2		.8596	.8596	.8596	.9671	.8596	.7522
3		.9671	.8596	.8596	1.1283	.8059	.8596
4		1.0745	.9134	.9671	1.1283	.8059	.9671
5		1.1283	.9671	1.0208	1.2357	.8596	1.0208
6		1.1283	1.2894	1.2357	1.5581	1.182	1.0745
7		1.2894	1.3432	1.2894	1.773	1.3432	1.3969
8	1.3969	1.3969	1.5581	1.5581	1.6655	1.4506	1.2894
9		1.3432			1.7193	1.0745	
10		1.0745			1.182		
11		.9671			1.0745	.8596	
12		.9134			.9671	.7522	
13		.8596			.9671	.7522	
14		.9134			.9671	.8059	
15		.7522			.9671	.8059	
16		.8596			1.0208	.8596	
17		.9134	1.0208		1.0745		1.0208
18		1.0208		1.182	1.0745	1.0208	1.0745
19	1.2894	1.2357	1.182	1.1283	1.0745	1.2894	1.1283
20	1.5043	1.3432	1.2894	1.2894	1.182	1.182	1.182
21	1.0208	1.1283	1.182	1.1283	1.0745	.9671	1.1283
22	.9671	1.0208	1.0745	1.0745	1.0208	.9671	1.0745
23	.9671	.9671	1.0208	.9671	.9671	.9671	.9671
24	1.0208	.8596	.8596	.9134	.8596	.8596	.7522
Max	1.5043	1.3969	1.5581	1.5581	1.773	1.4506	1.3969
Min	.9671	.7522	.8596	.8596	.8596	.7522	.7522
Avg	1.1666	1.0365	1.0853	1.0889	1.1462	.9695	1.0275

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054100 / Girwali 33/11 kkv

Feeder No / Name : 201 / Warwati

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.3048	
3						.4572
4					.381	
6	.5335				.4572	.5335
14			.2896			
20		.3048		.381		
23			.2591			.4001
24	.381			.2286	.3048	.4572
Max	.5335	.3048	.2896	.381	.4572	.5335
Min	.381	.3048	.2591	.2286	.3048	.4001
Avg	.4573	.3048	.2744	.3048	.3620	.462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054100 / Girwali 33/11 kkv

Feeder No / Name : 202 / Express Water Supply
Feeder KV- 11 / OUTGOING

Only one consumer of WW with HT-IV

DATE	25-JUN-17	26-JUN-17	27-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
3		.1509	
5		.1509	
6		.1509	
12			.16
16	.1509		.12
20	.1509		
24		.1509	
Max	.1509	.1509	.16
Min	.1509	.1509	.12
Avg	.1509	.1509	.14

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054100 / Girwali 33/11 kkv

Feeder No / Name : 203 / Girwali

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.3334		
3			.2			.3334
4				.3734		
6	.3334		.2667	.4572		.4268
12						.4134
13		.2401				
16		.2134				.3334
19					.2934	
20						.3467
23		.3334				.4001
24	.16		.2	.3334		.3334
Max	.3334	.3334	.2667	.4572	.2934	.4268
Min	.16	.2134	.2	.3334	.2934	.3334
Avg	.2467	.2623	.2222	.3744	.2934	.3696

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054100 / Girwali 33/11 kkv

Feeder No / Name : 204 / Warwati GFSS

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2					.021		
3			.021				.021
4				.0314	.0314		
6	.0503		.0503		.048		.0503
8				.0457			
10			.021				
12				.021			.0457
13		.0191					
14			.021				
16		.021		.021			.0457
20		.0419		.0503			
22			.0457			.0314	
23		.021					.0457
24	.021		.021	.021	.021		.021
Max	.0503	.0419	.0503	.0503	.048	.0314	.0503
Min	.021	.0191	.021	.021	.021	.0314	.021
Avg	.0357	.0258	.03	.0317	.0304	.0314	.0382

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054100 / Girwali 33/11 kkv

Feeder No / Name : 205 / T V center

Only one consumer of WW with HT-IV

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.0381		
3			.0381			.0381
4				.0572		
6	.0381		.0572	.0762		.0572
12						.0762
16		.0762				.0762
20		.0762				.0762
22					.0762	
23		.0762				
24	.0762		.0762	.0762		.0762
Max	.0762	.0762	.0762	.0762	.0762	.0762
Min	.0381	.0762	.0381	.0381	.0762	.0381
Avg	.0572	.0762	.0572	.0619	.0762	.0667

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054106 / DONGAR PIMPALA 33/11 KV

Feeder No / Name : 201 / 11 kv sonawala

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0226		.0189	.034	.0189	.0189	.0189
2	.0302		.0189	.0358	.0189	.0189	.0189
3	.0321		.0189	.0358	.0189	.0189	.0189
4	.034		.0189	.0358	.0189	.0189	.0189
5	.034		.0189	.0358	.0189	.0189	.0189
6	.0283		.0189	.0377	.0189	.0377	.0377
7	.0321		.0189	.0302	.0189	.0189	.0189
8	.0321		.0189		.0189	.0189	.0189
9	.0189		.0189		.0264	.0189	.0189
10			.6602	.8299	.7111	.63	.547
11	.9619		.7545	1.1317	.5923	.6451	.679
12			.9808		.5923	.8714	.6979
13			.9431	1.1883	.6337		.9431
14			.9808	.9054	.9336	.9582	.9431
15	1.0374	.8488	.9808	.8676	.9016	1.0185	.9431
16	1.1694	.5093	.9431	.7922	.8714	.9846	.9054
17		.0377	.7828		.9242		.9638
18	.0189	.0189			.0189	.0189	.0245
19	.0189	.0189	.0226	.0189	.0189	.0189	.0226
20		.0189	.034	.0189	.0377	.0189	.034
21	.0189		.0321	.0189	.0377		.0358
22			.0302				.0358
23			.0321		.0189		.0377
24			.034			.0189	.0245
Max	1.1694	.8488	.9808	1.1883	.9336	1.0185	.9638
Min	.0189	.0189	.0189	.0189	.0189	.0189	.0189
Avg	.2326	.2421	.3209	.3761	.2941	.2828	.2928

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054106 / DONGAR PIMPALA 33/11 KV

Feeder No / Name : 203 / 11 KV D.PIMPALA GFSS

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1566	.0754	.1294	.1377	.0739	.1307	.1109
2	.1566	.0754	.1294	.1377	.0739	.1307	.1109
3	.1867	.0754	.1494	.1377	.0739	.132	.112
4	.1924	.0754	.1494	.1547	.1132	.132	.1307
5	.2188	.0754	.1886	.1886	.1307	.1698	.1494
6	.2991	.1132	.2829	.2773	.2195	.2829	.2452
7	.298	.0943	.2075	.2697	.2241	.2829	.3018
8	.239	.0943	.1698		.1848	.2641	.2195
9	.2054	.132	.0943		.1415	.161	.1867
10			.0924	.132	.0961	.1189	.0934
11	.1448		.0934	.1132	.0949	.1427	.0716
12			.0747		.0811	.0702	.0716
13			.0739	.0943	.0811		.0716
14			.0934	.0934	.0721	.0713	.0895
15	.1294	.0943	.0934	.0943	.0906	.0688	.0895
16	.0924	.1509	.112	.0754	.1035	.1024	.0905
17		.1494	.1245		.1109	.1294	.111
18	.1791	.1294	.1526		.1448	.1578	.1307
19	.2149	.1494	.2236	.132	.181	.1629	.1397
20		.2452	.2334	.1886	.2402	.2328	.1683
21	.0943		.1755	.1698	.1829		.1848
22			.1547				.1904
23	.0754		.1566		.1463		.1718
24		.0754	.1358			.1307	.1566
Max	.2991	.2452	.2829	.2773	.2402	.2829	.3018
Min	.0754	.0754	.0739	.0754	.0721	.0688	.0716
Avg	.1802	.1128	.1454	.1498	.1300	.1537	.1416

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054133 / 33/11KV DAWAKHANA S/S

Feeder No / Name : 201 / 11KV KRANTI NAGAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7554	.8089	.7922	.8106	.959	.9027	.8106
2	.7369	.7722	.7922		.9212	.8106	.7738
3	.7738	.7722	.7922	.7738	.9193	.7738	.7369
4	1.0317	.8089	.829	.8106	.8825	.9212	.829
5	1.0501	.8843	.9027	.8843	1.0296	1.0133	.9212
6	1.0317	1.0501	1.0686	1.0501	1.2502	1.1054	1.0317
7	1.1422	1.1619	1.2159	1.1607	1.6045	1.1975	1.0133
8	1.1422	1.1619	1.1607	1.2344	1.6414	1.2528	1.2344
9	.9949	1.0512	1.1238	1.1803	1.6045	.9949	1.1619
10	.9396	.8659	.9027	1.1434	1.1791	.958	.959
11	.7922	.7738			.8475	.9212	.9037
12	.8483	.6632	.8843	.8852	.8475	.829	.8843
13	.7746	.7922	.7369	.8668	.829	.6817	
14	.7193	.8106	.7922	.793	.829	.7001	
15	.9037	.7001	.7369	.8668	.8106	.7001	.6632
16	.8659	.7369		.959	.7738	.7369	.7738
17	1.1054	.7922	.958	1.0697	.8106		.8659
18	1.1422	.9949	1.0501	1.0881	.829	1.0133	.9396
19	1.1054	1.0501	1.1238	1.1065	.9396	1.1238	1.1238
20	1.5107	1.1422	1.1791	1.1803	1.1054	1.1975	1.1422
21	1.1054	1.1054	1.1422	1.1065	1.0133	1.0133	1.0686
22	.9212	.9764	.958	1.0512	.9212		.9212
23	.8475	.8659	.8843	.9959	.0553	.7738	.8106
24	.8106	.8098	.7922	.8106	.959	.9212	.7554
Max	1.5107	1.1619	1.2159	1.2344	1.6414	1.2528	1.2344
Min	.7193	.6632	.7369	.7738	.0553	.6817	.6632
Avg	.9605	.8980	.9463	.9922	.9818	.9337	.9238

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054133 / 33/11KV DAWAKHANA S/S

Feeder No / Name : 202 / 11KV DAGADWADI GFSS

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0661	.0492	.0496	.0826	.0492	.1652	.033
2	.0661	.0328	.0496	.1321	.0494	.1982	.033
3	.0496	.0328	.0496	.0991	.0494	.1982	.0496
4	.1321	.0328	.0496	.0826	.0659	.2643	.1321
5	.0826	.0492	.0496	.1321	.0989	.2478	.0991
6	.0661	.0656	.2147	.1652	.165	.2643	.0661
7	.0826	.0656	.1982	.1817	.1984	.2808	.0921
8	.0496	.0984	.2147	.1487	.1654	.1982	.0661
9	.0493	.2646	.1998	.0496	.2481	.1998	.033
10	.0989	.1652	.1652	.1648	.0661	.1652	.033
11	.1813	.1982	.2478	.1323	.0661	.1156	.0659
12	.1984	.1982	.1487	.1984	.0661	.05	
13	.2315	.0661	.2478	.0496	.0496	.033	
14	.1982	.0496	.2313	.1987	.0496	.0333	
15	.132	.0991	.2478	.1661	.0826	.1499	.0661
16	.2637	.1652		.2326	.1817	.0333	.2147
17	.2472	.1982	.1321	.2489	.1156		.2313
18	.0989	.1817	.0496		.1982	.0333	.1487
19	.1318	.0991		.0331	.0661	.0333	.1156
20	.0659	.1487	.2313	.0827	.1652	.0333	.0826
21	.0492	.0496	.2313	.0494	.1487	.033	.0826
22	.0492	.0496	.1652	.0494	.1487	.0661	.0496
23	.0492	.0496	.1817	.0492	.1487	.0329	.0494
24	.0661	.0492	.0496	.1652	.0492	.1487	.033
Max	.2637	.2646	.2478	.2489	.2481	.2808	.2313
Min	.0492	.0328	.0496	.0331	.0492	.0329	.033
Avg	.1127	.1024	.1548	.1258	.1122	.1295	.0846

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054133 / 33/11KV DAWAKHANA S/S

Feeder No / Name : 203 / 11 KV KURUNWADI AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0826	.0983	.0656	.1312	.0983	.164	.1021
2	.1312	.0984	.0656	.1312	.0983	.164	.1321
3	.1476	.0983	.0656	.164	.0983	.1968	.1156
4	.164	.1147	.0656	.2132	.1315	.2625	.1148
5	.1968	.1476	.0656	.2461	.1648	.2461	.1148
6	.2461	.1968	.1312	.3117	.1978	.2789	.1312
7	.2132	.2472	.2789	.3138	.2472	.1982	.1476
8	.3117	.1483	.3117	.2789	.1978		.1476
9	.1978	.2142	.1968	.2297	.0989	.0984	.0814
10	.0824	.1968	.0656	.0824	.0656	.1312	.0819
11	.0659	.0656	.082	.0659	.1804	.1148	.0659
12	.0494	.082	.0656	.0659	.164	.1312	
13	.0659	.0656	.0656	.0659	.1476	.1476	
14	.0659	.0656	.082	.099	.1312	.1476	
15	.0659	.0656	.0984	.0659	.1312	.1476	.1813
16	.0659	.0984		.0824	.164	.164	.0824
17	.0989	.0984	.1148	.0659	.2132	.0984	.1648
18	.1318	.1312		.1813	.082	.1476	.1318
19	.1483	.164	.164	.1648	.164	.1312	.1318
20	.1483	.1476	.164	.1483	.1476	.1476	.1318
21	.1147	.1312	.1476	.1318		.1148	.1318
22	.1147	.1312	.1312	.1147	.1476	.1148	.1154
23	.1147	.1148	.1312	.0983	.1476	.1156	.1147
24	.0656	.0983	.0984	.1312	.0983	.0991	
Max	.3117	.2472	.3117	.3138	.2472	.2789	.1813
Min	.0494	.0656	.0656	.0659	.0656	.0984	.0659
Avg	.1287	.1258	.1208	.1493	.1442	.1549	.1210

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054141 / PATTIWADGAON SUBSTATION

Feeder No / Name : 201 / MURTI FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0876			.0876	.0876		.1052
2	.0876			.0876	.0876		.1052
3	.1227			.1227			.1402
4	.1578			.1578			.1402
5	.1753		.1753	.1753			.2103
6	.2804			.2454			.2454
10	.1402	.2103	.1753	.1052			.1402
11	.0175			.1402	.1052	.1753	.1402
12	.2454	.2103		.1402	.1052	.1402	.1402
13	.1928					.1402	.1052
14	.2103		.1402	.1227		.1052	.1052
15			.1052	.1052		.1052	.1402
16			.1052	.1052		.1052	.1402
17			.1227	.1227			
18			.1052	.1052		.1052	.0701
19			.0701	.2279			.1402
20				.2103			.1052
21			.1753	.1402			.1402
22			.1402	.1227			.1402
23			.1052	.1052			.1052
24	.0876	.1227	.1052	.0876	.0876	.1052	.0876
Max	.2804	.2103	.1753	.2454	.1052	.1753	.2454
Min	.0175	.1227	.0701	.0876	.0876	.1052	.0701
Avg	.1504	.1811	.1271	.1358	.0946	.1227	.1323

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054141 / PATTIWADGAON SUBSTATION

Feeder No / Name : 202 / PATTIWADGAON FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3185			.285	.285		.3185
2	.3185			.3018	.3185		.3353
3	.3688			.3353			.3353
4	.4359			.4024			.4024
5	.5197		.4527	.4527			.4527
6	.57			.4527			.503
10	.3521	.2515	.2515	.2347			.285
11	.3856			.218	.2515	.2515	.3185
12	.4191			.2515	.218	.2515	.3018
13						.218	.2683
14	.3353		.2515	.2012		.2515	.285
15			.2347	.2012		.2515	.2683
16			.2347	.1844		.2683	.285
17			.218	.1677			
18			.218	.285		.3018	.1844
19			.3185	.4527			.3018
20			.4024	.3688			.3353
21			.4359	.4191			.4694
22			.3856	.3856			.3856
23			.3185	.3185			.3688
24	.3185	.285	.3185	.285	.285	.4862	.3185
Max	.57	.285	.4527	.4527	.3185	.4862	.503
Min	.3185	.2515	.218	.1677	.218	.218	.1844
Avg	.3947	.2683	.3108	.3102	.2716	.2850	.3361

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054141 / PATTIWADGAON SUBSTATION

Feeder No / Name : 203 / BHABALGAON FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3185			.285	.3018		.285
2	.3185			.3185	.3353		.3185
3	.3521			.3688			.3521
4	.4191			.4527			.4191
5	.4359		.57	.4862			.6371
6	.6539			.7209			.6874
10	.3521	.4527	.3353	.2347			.4862
11	.3856	.5533		.3856	.2515	.3185	.503
12	.4024			.3185	.2683	.3185	
13	.3688					.3353	.3856
14	.3185		.3688			.3353	.4024
15			.3856			.3856	.4359
16			.3688			.3521	.4694
17			.3353	.4359			
18			.2347	.2347		.285	.285
19			.4024	.57			.3521
20			.503	.5197			.4191
21			.5365	.4359			.4527
22			.4024	.4024			.3521
23			.3185	.3353			.3353
24	.3353	.4359	.3688	.285	.3018	.3353	.3018
Max	.6539	.5533	.57	.7209	.3353	.3856	.6874
Min	.3185	.4359	.2347	.2347	.2515	.285	.285
Avg	.3884	.4806	.3946	.3994	.2917	.3332	.4147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054005 / 33/11 KV DHARUR

Feeder No / Name : 204 / EXPRESS JINING

HV Non-Express Feeder

Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	24-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0076		.0038	.0152
2		.0076		.0038	
3		.0076		.0038	
4		.0076		.0038	
5	.0152	.0076		.0038	
6	.0305	.0076		.0038	
7		.0076			
9		.0305			
12	.0171				
16	.0305				
17	.0076		.0114		.0305
18	.0076		.0114		
19	.0076		.0076		
20	.0076		.0076		
21			.0076		
22			.0076		
23			.0038		
24		.0076		.0038	.0152
Max	.0305	.0305	.0114	.0038	.0305
Min	.0076	.0076	.0038	.0038	.0152
Avg	.0155	.0101	.0081	.0038	.0203

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054005 / 33/11 KV DHARUR

Feeder No / Name : 205 / GFSS Avargaon
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	23-JUN-17	24-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715		.0034	.2058
2		.1905		.3201	.1715
3		.1619		.3658	
4		.2096		.4687	
5		.2858		.5373	
6		.3429		.6668	
7		.4115			
9		.2743			
16	.3601				
17	.2382		.4687		.3086
18	.3201		.4572		
19	.3887		.4572		
20	.3429				
21	.2477		.4572		
22	.2382		.4344		
23	.2191		.2858		
24		.2		.2572	.2401
Max	.3887	.4115	.4687	.6668	.3086
Min	.2191	.1619	.2858	.0034	.1715
Avg	.2944	.2498	.4268	.3742	.2315

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054005 / 33/11 KV DHARUR

Feeder No / Name : 207 / Gopalpur Ag
Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	24-JUN-17	27-JUN-17
HR	Load (MW)	Load (MW)
1	.0152	.0152
2	.0229	.0191
3	.0286	.0152
4	.0229	.04
5	.0343	.0343
6	.0857	.0343
7	.0686	
9	.2591	
24	.0114	.04
Max	.2591	.04
Min	.0114	.0152
Avg	.0610	.0283

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054005 / 33/11 KV DHARUR

Feeder No / Name : 208 / 11 Kv Dharur Urban
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	23-JUN-17	24-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8269		.7602	.9145
2		.8669		.8002	1.0288
3		.9202		.7735	
4		1.1126		1.1584	
5	1.3889	1.3889		1.2803	
6	1.3889	1.4918		1.5775	
7		1.6461			
9		1.2689			
12	1.046				
16	1.2517				
17	1.4575		1.0669		1.0631
18	1.5089		1.1584		
19	1.5775		1.4575		
20	1.5432		1.5089		
21	1.4575		1.3546		
22	1.1584		1.0669		
23	1.0669		.9907		
24	1.0802	1.0212		.8993	1.0631
Max	1.5775	1.6461	1.5089	1.5775	1.0631
Min	1.046	.8269	.9907	.7602	.9145
Avg	1.3271	1.1715	1.2291	1.0356	1.0174

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744]

BU 4744

Substation No/ Name :- 054017 / 33 KV. ADAS S/S

Feeder No / Name : 202 / 11 KV. KHODAS FEEDER
Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.571	.5698	.571	.5698	.3803	.3803	.3803
2	.571	.5698	.571	.5698	.3803	.3803	.3803
3	.7613	.5698	.571	.5698	.3803		.3803
4	.7613	.5698	.571	.5698	.3803	.5704	.3803
5	.7613	.5698	.571	.5704	.3803	.5704	.3803
6	.9516	.6648	.7613	.5704	.5704	.571	.5704
7	.9516	.7598	.571	.7606	.5704	.5704	.5704
8	.7613	.6648	.571	.7606	.5704	.5704	.5704
9	.7613	.3799	.9516	.8556	.3803	.3803	.3803
10	.3807	.3799	.3807	.3803	.3803	.5704	.5704
11	.3799		.3807	.3803	.571	.5704	.5704
12	.3799		.3807	.3803	.5704	.5704	.6655
13	.3799	.3799	.1903	.3803	.5704	.5704	.6655
14	.2849	.3807	.1903	.2852	.5704	.5704	.6655
15	.2849	.3799	.1903	.2852	.5704	.5704	.5704
16	.2849	.3799	.1903	.2852	.5704	.5704	.5704
17	.3799	.3807	.1899	.2852	.5704	.5704	.5704
18	.3799	.3807		.3803	.5704	.3803	.3803
19	.3799	.571	.3799	.3803	.5704	.3803	.3803
20	.5698		.4749	.5704	.5704	.5704	.1901
21	.5698	.571	.5698	.5704	.3803	.5704	.1901
22	.4749	.3807	.3799	.3803	.3803	.3803	.1901
23	.3799		.3799	.3803	.3803	.3803	.1901
24	.3807	.5698	.571	.5698	.3803	.3803	.3803
Max	.9516	.7598	.9516	.8556	.571	.571	.6655
Min	.2849	.3799	.1899	.2852	.3803	.3803	.1901
Avg	.5309	.5036	.4591	.4871	.4833	.5043	.4476

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744]

BU 4744

Substation No/ Name :- 054017 / 33 KV. ADAS S/S

Feeder No / Name : 203 / 11 KV ASARDON FEEDER
Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1656	.2486	.1658	.1658	.3315	.3315	.3315
2	.1656	.2486	.1658	.1658	.3315	.3315	.3315
3	.1656	.2486	.1658	.1658	.3315	.3315	.3315
4	.3311	.2486	.3315	.1658	.3315	.4973	.3315
5	.3311	.3315	.4973	.1658	.3315	.4973	.3315
6	.4967	.3315	.4973	.3315	.3315	.4973	.4973
7	.4967	.4973	.4973	.4973	.4973		.4973
8	.4967	.4144	.3315	.4973	.4973	.4973	.4973
9	.3311	.3315	.1656	.3315	.3315	.4973	.3315
10	.3311	.3315	.3315	.3315	.1658	.1658	.1658
11	.3315		.1658	.3315	.1658	.1658	.1658
12	.3315	.3315	.1658	.3315	.1658	.1658	.1658
13	.3315	.3315	.3315	.3315	.1658	.1658	.1658
14	.3315	.3315	.3315	.3315	.1658	.1658	.1658
15	.3315	.4973	.3315	.3315	.1658	.1658	.1658
16	.3315	.4973	.3315	.3315	.1658	.1658	.1658
17	.3315	.4973	.3315	.3315	.1658	.1658	.1658
18	.2486	.3315		.3315	.1658	.1658	.1658
19	.2486	.4973	.4144	.3315	.4973	.3315	.3315
20	.4973	.4973	.4973	.3315		.4973	.4973
21	.4973	.4973	.4973	.4973	.4973	.4973	.4144
22	.3315	.2486	.3315	.3315	.3315	.3315	.3315
23	.2486	.2486	.1658	.1658	.1658	.1658	.1658
24	.1656	.1658	.1658	.1658	.3315	.3315	.3315
Max	.4973	.4973	.4973	.4973	.4973	.4973	.4973
Min	.1656	.1658	.1656	.1658	.1658	.1658	.1658
Avg	.3279	.3567	.3135	.3039	.2883	.3099	.2935

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054063 / 33/11 KV HOAL S/S

Feeder No / Name : 202 / LADEGAON

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	25-JUN-17
HR	Load (MW)
12	.3429
Max	.3429
Min	.3429
Avg	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744]

BU 4744

Substation No/ Name :- 054113 / 33KV ASARDOH S/stn

Feeder No / Name : 201 / Morphali

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.2743	.2439	.2915	.2743	.2439
2	.0762	.0762	.3048	.2743	.3429		.2591
3	.0762	.0762	.3658	.3048	.3601	.2743	.2591
4	.0762	.0953	.4268	.3658	.3601	.3048	.3201
5	.0953	.1143	.4572	.4268	.3429	.3201	.3506
6	.1143	.1334	.4877	.4572	.4458	.4268	.4268
7	.1143	.1143	.5335	.442	.5487	.4877	.4115
8	.0953	.0953	.4877	.4268	.57	.4268	.3353
9	.0572	.061	.4268	.3563	.3963	.3048	.3401
10	.0762	.0305	.2743	.3563		.1219	
11	.1219			.3401	.1981	.1067	.1334
12	.1524			.3688	.1829	.1067	.1334
13	.1524	.1829	.3048	.3725	.1829	.1372	.1334
14	.1067	.2134	.3048	.3401	.1524	.1219	.1143
15	.1219	.1829	.3201	.3077	.1524	.1372	.1143
16	.1219	.1524	.3201	.3401	.1524	.1524	.1334
17	.1219	.1829	.2743				.1143
18	.0572	.0305				.1829	
19	.0762	.2743	.2439		.2096	.2134	.4001
20		.3353	.3506		.4001	.2286	.4382
21	.0953	.3048	.2896	.4001	.3429	.2591	.381
22	.0953	.2743	.2591	.3429	.2477	.2286	.3429
23	.0953	.2439	1.0974	.2858	.2477	.2134	.3239
24	.0953	.2743		.2286	.2401	.2439	.2286
Max	.1524	.3353	1.0974	.4572	.57	.4877	.4382
Min	.0572	.0305	.2439	.2286	.1524	.1067	.1143
Avg	.0996	.1611	.3902	.3490	.3032	.2397	.2699

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054113 / 33KV ASARDOH S/stn

Feeder No / Name : 202 / Asardoha

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	22-JUN-17	23-JUN-17
HR	Load (MW)	Load (MW)
1	.1543	.1677
2	.1543	.1677
3	.1715	.1981
4	.2683	.2743
5	.3521	.3201
6	.3856	.3048
7	.4372	.3353
8	.4024	.3506
9	.3048	.3658
10	.2096	.1524
11	.1524	
12	.1334	
13	.1334	
14	.1334	
15	.1334	
16	.1334	
17	.1524	
18	.2096	
19	.2667	
20	.4572	
21	.4001	
22	.362	
23	.2858	
24	.1372	.1677
Max	.4572	.3658
Min	.1334	.1524
Avg	.2471	.2550

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744]

BU 4744

Substation No/ Name :- 054113 / 33KV ASARDOH S/stn

Feeder No / Name : 203 / Rui dharur

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2667	.1829	.2858	.1543	.1372	.1372
2	.2477	.2667	.1524	.2667	.1543		.1372
3	.2667	.3239	.2439	.3048	.1715	.1829	.1677
4	.2858	.4382	.3048	.3429	.1886	.1829	.1981
5	.381	.4572	.3353	.4001	.1886	.1981	.2134
6	.4001	.4954	.3658	.4572	.1715	.2286	.2286
7	.4382	.4763	.3506	.4382	.2058	.2591	.2439
8	.4191	.4001	.3353	.4382	.1886	.2286	.2591
9	.2858	.2743	.2286	.3429	.1372	.1524	.2591
10	.2286	.2134	.1067	.1509		.1334	
11	.2286			.1844		.1143	.0762
12	.2134			.2347	.1905	.0953	.1143
13	.2134	.1829	.2286	.218	.1715	.1143	.0953
14	.2286	.2134	.2439	.1844	.1334	.1143	.0953
15	.2286	.2134	.2591	.218	.1905	.1143	.1334
16	.2591	.1524	.2439	.2347	.2096	.1334	.1334
17	.2286	.1219	.1829		.2858	.2096	.1715
18	.2858	.1829			.3239	.2858	
19	.3429	.2439	.4382		.4001	.4191	.4001
20	.4001	.2743	.4191	.3429	.4763	.4191	.4191
21	.3239	.2743	.4001	.3048	.381	.3429	.4001
22	.3239	.2439	.362	.2858	.3048	.3048	.362
23	.3048	.2134	.3239	.2667	.2858	.2667	.3239
24	.2667	.2134		.2858	.1886	.1372	.1524
Max	.4382	.4954	.4382	.4572	.4763	.4191	.4191
Min	.2134	.1219	.1067	.1509	.1334	.0953	.0762
Avg	.2945	.2792	.2854	.2947	.2319	.2076	.2146

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054002 / 33KV KAIJ

Feeder No / Name : 201 / Town-I

Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	23-JUN-17	24-JUN-17	25-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
9	1.1715		
10		1.0796	
13			1.0445
Max	1.1715	1.0796	1.0445
Min	1.1715	1.0796	1.0445
Avg	1.1715	1.0796	1.0445

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054002 / 33KV KAIJ

Feeder No / Name : 202 / Tambva

Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	23-JUN-17	24-JUN-17
HR	Load (MW)	Load (MW)
9	.439	
10		.4572
Max	.439	.4572
Min	.439	.4572
Avg	.439	.4572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054002 / 33KV KAIJ

Feeder No / Name : 204 / Massajog Ag

Feeder KV- 11 / OUTGOING

AG Feeder with SDT

DATE	23-JUN-17
HR	Load (MW)
9	.0721
Max	.0721
Min	.0721
Avg	.0721

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054002 / 33KV KAIJ

Feeder No / Name : 205 / Town-II

Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	23-JUN-17	24-JUN-17	25-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
9	1.6665		
10		1.3825	
13			1.7044
Max	1.6665	1.3825	1.7044
Min	1.6665	1.3825	1.7044
Avg	1.6665	1.3825	1.7044

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054002 / 33KV KAIJ

Feeder No / Name : 206 / Water supply
Feeder KV- 11 / OUTGOING

Only one consumer of WW with HT-IV

DATE	23-JUN-17	24-JUN-17
HR	Load (MW)	Load (MW)
9	.072	
10		.1663
Max	.072	.1663
Min	.072	.1663
Avg	.072	.1663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054002 / 33KV KAIJ

Feeder No / Name : 207 / GFS sonijawalla

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	24-JUN-17
HR	Load (MW)	Load (MW)
9	.2261	
10		.1486
Max	.2261	.1486
Min	.2261	.1486
Avg	.2261	.1486

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054002 / 33KV KAIJ

Feeder No / Name : 208 / GFS Tambva

Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	23-JUN-17	24-JUN-17
HR	Load (MW)	Load (MW)
9	.2738	
10		.2029
Max	.2738	.2029
Min	.2738	.2029
Avg	.2738	.2029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054015 / 33KV BANSAROLA

Feeder No / Name : 201 / Bansarola

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.8871				1.0349
9							.7392
10			.301	.381	.4214		
14						.4054	
15				.4268			
20			1.0642	.9709			
24	.5975	.5601	.5975	.5415	.5658		.5658
Max	.5975	.5601	1.0642	.9709	.5658	.4054	1.0349
Min	.5975	.5601	.301	.381	.4214	.4054	.5658
Avg	.5975	.5601	.7125	.5801	.4936	.4054	.7800

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054015 / 33KV BANSAROLA

Feeder No / Name : 202 / Isthal

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.9031				.9145
9							.9686
10			.2804	.3429	.3121		
14						.1417	
15				.2035			
20			.4115	.3721			
24	.3822	.6097	.3913	.5247	.4016		.4081
Max	.3822	.6097	.9031	.5247	.4016	.1417	.9686
Min	.3822	.6097	.2804	.2035	.3121	.1417	.4081
Avg	.3822	.6097	.4966	.3608	.3569	.1417	.7637

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054015 / 33KV BANSAROLA

Feeder No / Name : 203 / Kaudgaon

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.2987				.381
9							.2614
10			.2241	.2012	.1905		
14						.0724	
15				.1143			
20			.4212	.3887			
24	.3201	.2629	.2835	.2766	.2683		.2683
Max	.3201	.2629	.4212	.3887	.2683	.0724	.381
Min	.3201	.2629	.2241	.1143	.1905	.0724	.2614
Avg	.3201	.2629	.3069	.2452	.2294	.0724	.3036

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054015 / 33KV BANSAROLA

Feeder No / Name : 204 / Jawallban

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.1886			.4481
9					.3749
10				.1524	
15			.3479		
20		.1132	.1509		
24	.0762	.0747	.0762	.1353	.1353
Max	.0762	.1886	.3479	.1524	.4481
Min	.0762	.0747	.0762	.1353	.1353
Avg	.0762	.1255	.1917	.1439	.3194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054015 / 33KV BANSAROLA

Feeder No / Name : 205 / Awasgaon

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.4904			.9831
9						.9488
10					.2286	
15				1.166		
20			.547	.4527		
24	.2987	.3048	.2858	.3048	.4458	.4458
Max	.2987	.3048	.547	1.166	.4458	.9831
Min	.2987	.3048	.2858	.3048	.2286	.4458
Avg	.2987	.3048	.4411	.6412	.3372	.7926

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054015 / 33KV BANSAROLA

Feeder No / Name : 206 / Borisavargaon

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.7186				.4527
9							.3048
10			.2641	.2614	.4458	.3572	
14						.7225	
15				.3048			
20			.4904	.4527			
24	.3841	.6401	.3567	.5401	.381	.2858	.381
Max	.3841	.6401	.7186	.5401	.4458	.7225	.4527
Min	.3841	.6401	.2641	.2614	.381	.2858	.3048
Avg	.3841	.6401	.4575	.3898	.4134	.4552	.3795

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425]

BU 2577

Substation No/ Name :- 054040 / YUSUFWADGAON

Feeder No / Name : 201 / Yusufwadgaon

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096		.1781	.216	.2134	.1627	.3035
2	.2096	.2481	.1781	.216	.2134	.16	.3035
3	.2096	.2401	.1781	.216	.2241	.2058	.3035
4	.2469	.2366	.1783	.2378	.2241	.2473	.3315
5	.2774	.2524	.2332	.3567	.2347	.2698	.3978
6	.3231	.4359	.3304	.4359	.3086	.326	.4496
7	.4241	.4161	.3963	.4557	.3597	.4649	
8	.3837	.3837	.3635	.3938	.3822		
9	.3292	.3704		.3426	.3149	.4496	
10	.3909	.3414		.3982			
11		.4191	.1859	.3982			
12	.3414	.4191		.4127	.2835	.2324	
13	.4344			.431	.1829	.1989	
14	.4752			.4199	.1859	.16	
15	.4752			.4159	.1768	.1572	
16	.4401	.1677		.4344	.1879	.1543	
17	.3948			.4001			
18	.21	.2042		.2715			
19	.2389	.2585		.3094	.2858		
20	.4054	.3094		.3692	.4018		
21	.3978			.2881			
22	.2923			.2347			
23		.1886		.2241	.1768		
24	.2134		.1781	.216	.2134	.1395	.2858
Max	.4752	.4359	.3963	.4557	.4018	.4649	.4496
Min	.2096	.1677	.1781	.216	.1768	.1395	.2858
Avg	.3329	.3057	.24	.3372	.2539	.2377	.3393

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425]

BU 2577

Substation No/ Name :- 054040 / YUSUFWADGAON

Feeder No / Name : 202 / Sadola

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0627		.0537	.0583	.0663	.0674	.1181
2	.0613	.0573	.0537	.0583	.0995	.0899	.1181
3	.0613	.0573	.0671	.0583	.0995	.0995	.1181
4	.0789	.0716	.0754	.0667	.1124	.1195	.1257
5	.0943	.0823	.1094	.0823	.1236	.128	.1372
6	.0857	.0686	.1172	.0895	.128	.128	.144
7	.0701	.0701	.0671	.0895	.1387	.1572	
8	.0613	.0613	.0587	.0653	.1337	.16	
9	.0991	.0838		.0657	.1337	.144	
10	.0894	.1238		.0657			
11	.0867	.1181	.0991	.092			
12	.096	.1299		.1115	.0137	.0171	
13	.0867			.1278	.0217	.0152	
14	.0991				.021	.0152	
15	.1115				.0206	.0152	
16	.1219	.108			.021	.0152	
17	.1219						
18	.0423	.0594		.0762			
19	.0579	.0627		.0657	.024		
20	.0762	.088		.052	.0471		
21	.0686			.0267			
22	.0547			.0171			
23		.0587		.0152	.0274		
24	.0613		.0537	.0583	.0995	.0674	.144
Max	.1219	.1299	.1172	.1278	.1387	.16	.144
Min	.0423	.0573	.0537	.0152	.0137	.0152	.1181
Avg	.0804	.0813	.0755	.0671	.0740	.0826	.1293

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054043 / 33/11 KV H.PIMPRI SS

Feeder No / Name : 202 / Borgaon AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17
HR	Load (MW)	Load (MW)
6	5.0401	4.9882
7		5.9408
9	2.0368	
24	2.4161	1.8671
Max	5.0401	5.9408
Min	2.0368	1.8671
Avg	3.1643	4.2654

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054043 / 33/11 KV H.PIMPRI SS

Feeder No / Name : 204 / GFSS H.pimpri
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	22-JUN-17	23-JUN-17
HR	Load (MW)	Load (MW)
6	.5658	
7		.5658
9	.5601	
10		.462
24	.3734	.5601
Max	.5658	.5658
Min	.3734	.462
Avg	.4998	.5293

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054043 / 33/11 KV H.PIMPRI SS

Feeder No / Name : 205 / 11 KV Borgaon GFSS
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	22-JUN-17	23-JUN-17
HR	Load (MW)	Load (MW)
6	.7164	
7		.7164
9	.5544	
10		.5544
24	.1829	.6401
Max	.7164	.7164
Min	.1829	.5544
Avg	.4846	.6370

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054079 / MASSAJOG

Feeder No / Name : 201 / Massajog

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.8478	.9012	
9	.4915				
11		.5668		.5668	.663
15			.3953		
19			.6478		
21	.8029				
22			.7287		
Max	.8029	.5668	.8478	.9012	.663
Min	.4915	.5668	.3953	.5668	.663
Avg	.6472	.5668	.6549	.734	.663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054079 / MASSAJOG

Feeder No / Name : 202 / Sangvi

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.6859	.5601		
9	.4744					
11		.3239		.2429		
15			.3239		.2486	.3239
16						.3315
19			.4801			
21	.4902					
22			.4973			
Max	.4902	.3239	.6859	.5601	.2486	.3315
Min	.4744	.3239	.3239	.2429	.2486	.3239
Avg	.4823	.3239	.4968	.4015	.2486	.3277

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054079 / MASSAJOG

Feeder No / Name : 203 / SHINDE

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.4287	.2372		
9	.2429					
11		.08		.081		
15			.2458		.2258	.3353
16						.2429
19			.3277			
21	.3077					
22			.4096			
Max	.3077	.08	.4287	.2372	.2258	.3353
Min	.2429	.08	.2458	.081	.2258	.2429
Avg	.2753	.08	.3530	.1591	.2258	.2891

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425]

BU 2577

Substation No/ Name :- 054132 / 33KV Devgoan

Feeder No / Name : 201 / Devgaon

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2622	.1966		.2785	.1638	
2	.2785	.2294		.2622	.1966	
3	.2622	.2294		.2785	.2294	
4	.2949	.2622		.2622	.2622	
5	.4915	.2949		.426	.3605	
6	.5898	.5571		.5243	.4915	
7	.6554	.4588		.6554	.2949	
8	.6554	.2622		.5898	.3277	
9	.6882	.2294		.4915	.1638	
10	.5243	.1966	.2622		.1311	
11	.426	.1311	.1966	.0655		
12	.0655		.2294	.1311		.1638
13	.1311		.2949	.1311		.3277
14	.1311		.3277	.1638		.1966
15			.1638	.3277		.2949
16	.0983		.2622	.1638		.2622
17	.1311			.2294		.2949
18	.1638		.2294	.1638		.3277
19	.2622		.2294	.0655		.3605
20	.426		.426	.0983		.426
21	.2622		.3605	.2622		.3277
22	.1966		.3277	.2294		.2949
23	.2294		.2949	.1966		.2785
24	.1966			.1638		
Max	.6882	.5571	.426	.6554	.4915	.426
Min	.0655	.1311	.1638	.0655	.1311	.1638
Avg	.3227	.2771	.2773	.2678	.2622	.2963

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425]

BU 2577

Substation No/ Name :- 054132 / 33KV Devgoan

Feeder No / Name : 202 / Limbachiwadi

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0297	.0594		.0594	.0594	
2	.0297	.0594		.0594	.0297	
3	.0297	.0594		.0594	.0594	
4	.0297	.0892		.0594	.0297	
5	.0297	.1189		.0594	.0892	
6	.0892	.2378		.1189	.208	
7	.1783	.208		.1783	.1783	
8	.1486	.1783		.2378	.208	
9	.0892	.1486		.1486	.0892	
10	.0594	.1783	.0892	.0892	.1189	.1189
11	.0594	.1486	.0892	.0892		.1189
12	.1189		.0297	.0297		
13	.1189		.0297	.0297		
14			.0297			
15	.1486		.0297	.0297		
16	.1783		.0297	.0297		
17			.0297			
18	.1783		.0297	.0297		.0297
19	.1486		.0892	.0297		.0594
20	.1486		.1189	.0594		.1189
21	.0892		.0892	.0892		.1189
22	.0594		.0594	.0892		.0892
23	.0594		.0594	.0594		.0594
24	.0594			.0594		
Max	.1783	.2378	.1189	.2378	.208	.1189
Min	.0297	.0594	.0297	.0297	.0297	.0297
Avg	.0946	.1351	.0573	.0770	.1070	.0892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425]

BU 2577

Substation No/ Name :- 054132 / 33KV Devgoan

Feeder No / Name : 203 / Dahiphal

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0995	.0995		.0995	.0995	
2	.0995	.0995		.0995	.0995	
3	.116	.1326		.0995	.1326	
4	.0995	.1326		.0995	.1326	
5	.0995	.1658		.1326	.1326	
6	.1326	.1658		.1658	.0995	
7	.1326	.1658		.1658	.1658	
8	.0995	.1989		.1989	.1658	
9	.0995	.1326		.1658	.1658	
10	.0995	.1326	.1658	.1326	.1658	.1658
11	.0995	.1658	.0995	.1326		.1326
12	.0995		.0663	.0332		
13	.1326		.0663	.0663		
14	.1658		.0663	.0332		
15	.1326		.0663	.0332		
16	.1658			.0332		
17	.1989		.0663	.0332		
18			.0663	.0332		.0663
19	.1326		.0995	.0332		.1326
20	.0663		.1658	.1326		.1658
21	.0995		.1658	.0995		.1658
22	.0995		.1658	.0995		.1658
23	.0995		.1326	.0995		.1326
24	.0995			.0995		
Max	.1989	.1989	.1658	.1989	.1658	.1658
Min	.0663	.0995	.0663	.0332	.0995	.0663
Avg	.1161	.1447	.1071	.0967	.1360	.1409

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054136 / 33 KV Waghebabulgaon

Feeder No / Name : 202 / Bandewadi

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	26-JUN-17
HR	Load (MW)
12	.2126
13	.1928
16	.2353
Max	.2353
Min	.1928
Avg	.2136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425]

BU 2577

Substation No/ Name :- 054149 / 33/11 KV SALEGAON S/Stn

Feeder No / Name : 201 / salegaon gfss

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3				.1867	.1734		
4			.1509				
5					.2812		
6				.3048			
7					.4382		
8	.3898				.4115		
9			.2439	.2401	.3048	.3544	.2835
10				.1734	.2134		
12			.1334	.1467			.1067
15			.1334	.1334			
16							.1372
18			.192	.1734			
21					.2835		
23		.1372		.16			
24			.1372	.1334	.1334	.1417	.1772
Max	.3898	.1372	.2439	.3048	.4382	.3544	.2835
Min	.3898	.1372	.1334	.1334	.1334	.1417	.1067
Avg	.3898	.1372	.1651	.1835	.2799	.2481	.1762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054149 / 33/11 KV SALEGAON S/Stn

Feeder No / Name : 202 / Ganji AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3				.1334			
5	.25						
6				.16			
8	.4062						
9		.3281	.2667	.1867			
10					.16	.1829	
12							.2439
16							.2591
17					.1219		
24	.25	.2187	.1334	.0667			
Max	.4062	.3281	.2667	.1867	.16	.1829	.2591
Min	.25	.2187	.1334	.0667	.1219	.1829	.2439
Avg	.3021	.2734	.2001	.1367	.1410	.1829	.2515

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054149 / 33/11 KV SALEGAON S/Stn

Feeder No / Name : 203 / Salegaon AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3				.2812		
6				.3125		
8				.3321		
9				.2667	.5468	.4961
10	.3334	.2667	.1334			
12		.4668	.4001			
15		.4268	.3467			
17	.3734	.3601	.2812			
24				.1334	.2187	
Max	.3734	.4668	.4001	.3321	.5468	.4961
Min	.3334	.2667	.1334	.1334	.2187	.4961
Avg	.3534	.3801	.2904	.2652	.3828	.4961

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054154 / 33/11 KV KANADI MALI S/Stn

Feeder No / Name : 201 / Kandi Mali GFSS

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	28-JUN-17
HR	Load (MW)
10	.1715
Max	.1715
Min	.1715
Avg	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054154 / 33/11 KV KANADI MALI S/Stn

Feeder No / Name : 203 / kandi Mali AG Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	28-JUN-17
HR	Load (MW)
24	.4801
Max	.4801
Min	.4801
Avg	.4801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

MAJALGAON S/DN.[423] BU 2593

Substation No/ Name :- 054001 / 33 KV MAJALGAON s/stn

Feeder No / Name : 202 / 11KV GANGAMASALA

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	24-JUN-17	26-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.3239			
24		.6764	.2016	.2454
Max	.3239	.6764	.2016	.2454
Min	.3239	.6764	.2016	.2454
Avg	.3239	.6764	.2016	.2454

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

MAJALGAON S/DN.[423] BU 2593

Substation No/ Name :- 054001 / 33 KV MAJALGAON s/stn

Feeder No / Name : 205 / 11 KV Express

HV Non-Express Feeder

Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	24-JUN-17	25-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.0381			
23			.0296	
24		.0148		.056
Max	.0381	.0148	.0296	.056
Min	.0381	.0148	.0296	.056
Avg	.0381	.0148	.0296	.056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

MAJALGAON S/DN.[423] BU 2593

Substation No/ Name :- 054001 / 33 KV MAJALGAON s/stn

Feeder No / Name : 208 / 11 KV Manjarth GFSS
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	24-JUN-17	26-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
6		1.2186	
24	.9808		1.2071
Max	.9808	1.2186	1.2071
Min	.9808	1.2186	1.2071
Avg	.9808	1.2186	1.2071

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

MAJALGAON S/DN.[423] BU 2593

Substation No/ Name :- 054102 / 33/11 KV Kesapuri

Feeder No / Name : 201 / 11 KV Sadolla

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0213	.0213	.0229	.0213
2	.02	.0244		.0305
3	.0213	.0183		.0343
4	.0206	.0248		.0412
5	.0274	.0305	.0229	.0587
6	.0427	.0412		.0587
7	.0274	.0389		.0686
8	.0069	.032		.0686
9			.0629	.0514
24	.0213	.0213	.0152	.0257
Max	.0427	.0412	.0629	.0686
Min	.0069	.0183	.0152	.0213
Avg	.0232	.0281	.0310	.0459

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

MAJALGAON S/DN.[423] BU 2593

Substation No/ Name :- 054102 / 33/11 KV Kesapuri

Feeder No / Name : 206 / Govindwadi GFSS

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8177	.4993	.7468	.873	.8138
2	.8398	.5034	.7468	.9145	.9194
3	.9145	.5677	.823	.945	1.1406
4	.9755	.4949	.884	.9328	1.3683
5	1.0883	.9682	1.166	1.0136	1.2026
6	1.0883	1.0376	1.2689	1.07	1.3312
7	1.1469	1.283	1.4403	1.2018	1.3501
8	1.2742	1.204	1.2003	1.2163	1.2711
9	1.1523		1.166	1.2879	
10	1.048	.884	1.1142	1.1786	
11	1.085	.6935	1.073	.9877	
12	.9973	.6935	1.1203	.932	
13	.8999	.6935	1.1004	.8413	
14	.8928	.7202	1.1584	.9465	
15	.9088	.7468	1.2041	1.1103	
16	1.0546	.7468	1.2498	1.2136	
17	1.0322	.8002	1.1591		
18	1.1453	.9069	1.0292	1.2928	
19		1.0974		1.3911	
20				1.3347	
21	.6899			1.1392	
22	.567			1.0069	
23	.5034			1.0248	
24	1.1584	.5178	.7468	1.0105	.8519
Max	1.2742	1.283	1.4403	1.3911	1.3683
Min	.5034	.4949	.7468	.8413	.8138
Avg	.9673	.7926	1.0735	1.0811	1.1388

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

MAJALGAON S/DN.[423] BU 2593

Substation No/ Name :- 054134 / 33 KV MANUR DEVI S/stn

Feeder No / Name : 201 / MANJRATH AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	27-JUN-17
HR	Load (MW)
10	.0149
12	.0743
Max	.0743
Min	.0149
Avg	.0446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

MAJALGAON S/DN.[423] BU 2593

Substation No/ Name :- 054134 / 33 KV MANUR DEVI S/stn

Feeder No / Name : 202 / NAGADGAON AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
9		.4409	.5944
13	.5792		
14	.6401		
15	.6173		
16	.4938		
Max	.6401	.4409	.5944
Min	.4938	.4409	.5944
Avg	.5826	.4409	.5944

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

MAJALGAON S/DN.[423] BU 2593

Substation No/ Name :- 054135 / 33KV GANGAMASLA S/stn

Feeder No / Name : 201 / GANGAMASLA AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3025		.3193	.3193	.3865	.5875	.7562
2	.3025		.3697	.3361	.5377	.6714	.8234
3	.2857		.3025	.3529	.5881	.6714	.857
4	.3361		.3361	.3697	.3361	.6714	.9578
5	.3697		.3193	.4201	.4537	.7553	.9242
6	.4033		.3529	.4873	.7898	.8392	1.0418
7	.4705		.4705	.4705	1.5292	1.3092	1.1595
8	.5377		.5881	.5209		1.2924	1.1763
9		.4033	.5713	.5041	1.5123	1.2924	1.1931
10		1.1091	1.2267	1.0443			.3193
11		1.4619	1.6468	1.9115			
12		1.6804	1.8484	2.0837			
13		1.5628	1.7476	2.1005			
14		1.63	1.6804	2.0165			
15		1.3443	1.546	1.8484			
16		1.4619	1.5123				
17		1.4451	1.4787				
19			1.6804				
24	.3025		.3025	.3025	.3865	.3357	.7226
Max	.5377	1.6804	1.8484	2.1005	1.5292	1.3092	1.1931
Min	.2857	.4033	.3025	.3025	.3361	.3357	.3193
Avg	.3678	1.3443	.9631	.9430	.7244	.8426	.9028

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

MAJALGAON S/DN.[423] BU 2593

Substation No/ Name :- 054135 / 33KV GANGAMASLA S/stn

Feeder No / Name : 203 / GANGAMASLA GAOTHAN
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.2199	1.0608	1.062	1.062	1.0608
2	.9735		1.273	1.0255	.9735	1.062	1.1492
3	.9912		1.326	.9547	1.0089	1.1328	1.1846
4	1.3274		1.4144	.9901	1.062	1.1505	1.4144
5	1.4159		1.4498	1.2553	1.0443	1.4159	1.326
6	1.5044		1.4321	1.5735	1.062	1.4159	1.5735
7	1.6637		1.3437	1.5912	1.3451	1.4513	1.6796
8	1.5752		1.2907	1.6089	1.3628	1.4159	1.0785
9	1.0974	1.0255	1.273	1.3437	1.2213	1.2567	1.1315
10		.9194	1.1139				.9901
11		.8663	1.0431	1.0797			.8487
12		.884	1.0608	1.0266			
13		.7426	.9901	1.0089			
14		.884	.9724	1.062			
15		1.0078	.9724	1.0974		1.0962	
16		1.0785	1.0078	1.0974		.8487	
17		1.1139	.9901	1.0974		.884	
18		1.1846	1.2199	1.2036		.9371	
19		1.273	1.326	1.3628		1.0078	
20		1.326	1.5028	1.5929		.9724	
21		1.1492	1.2553	1.4159		1.0255	1.3791
22		1.2199	1.2023	1.1505		1.0608	1.0431
23			1.1315	1.062		1.0078	1.0608
24	1.0974		1.1492	1.0962	1.0974	1.062	.9724
Max	1.6637	1.326	1.5028	1.6089	1.3628	1.4513	1.6796
Min	.9735	.7426	.9724	.9547	.9735	.8487	.8487
Avg	1.2940	1.0482	1.2067	1.2068	1.1239	1.1192	1.1928

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054042 / 33/11 KV OPH PARLI S/S

Feeder No / Name : 201 / 11kv CHANDAPUR AG
Feeder KV- 11 / OUTGOING

AG Feeder with SDT

DATE	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.0642	
6				.0653	
8				.0642	
9	.0191				
10		.0951		.0963	
11	.1427	.0951			
13	.1427	.1107		.1932	
14	.1581				
15	.1581	.0953			
17		.1254			
18			.0481		
19					.0321
20			.0652		
22					.0642
24				.0634	
Max	.1581	.1254	.0652	.1932	.0642
Min	.0191	.0951	.0481	.0634	.0321
Avg	.1241	.1043	.0567	.0911	.0482

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054042 / 33/11 KV OPH PARLI S/S

Feeder No / Name : 202 / 11 KV GANESHPAR FEEDER Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2					1.4717		
6					1.7409		
7						1.7375	
8					1.7947		
9		1.6691			2.0101		
10			1.7947		2.046		
11		1.9383	1.8844				
13		1.9342	1.8446		1.5793		
14		1.705					
15		1.7851	1.8306				
17	2.0814		1.9185				
18				1.8844			
19							1.9742
20				1.9203			2.0639
22							1.5614
24					1.687		
Max	2.0814	1.9383	1.9185	1.9203	2.046	1.7375	2.0639
Min	2.0814	1.6691	1.7947	1.8844	1.4717	1.7375	1.5614
Avg	2.0814	1.8063	1.8546	1.9024	1.7614	1.7375	1.8665

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054042 / 33/11 KV OPH PARLI S/S

Feeder No / Name : 204 / 11 KV GFSS CHANDAPUR
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2					.205	
6					.1831	
8					.1622	
9		.2373			.2231	
10			.0565		.1296	
11		.1957	.0364			
13		.1497	.1335		.1636	
14		.1332				
15		.1378	.1595			
17	.1086		.2534			
18				.214		
19						.1175
20				.2041		.1511
22						.1684
24					.2231	
Max	.1086	.2373	.2534	.214	.2231	.1684
Min	.1086	.1332	.0364	.2041	.1296	.1175
Avg	.1086	.1707	.1279	.2091	.1842	.1457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054042 / 33/11 KV OPH PARLI S/S

Feeder No / Name : 205 / 11 KV Kalratri Devi Feeder Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2					1.1779		
6					1.6512		
7						1.6289	
8					1.9877		
9		1.4723			1.9378		
10			1.4723		1.4906		
11		1.3251	1.3251				
13		1.1043	1.1779		1.0328		
14		1.1535					
15		1.1779	1.1043				
17	1.3969		1.4842				
18				1.5778			
19							1.4617
20				1.5778			1.5364
22							1.3251
24					1.2476		
Max	1.3969	1.4723	1.4842	1.5778	1.9877	1.6289	1.5364
Min	1.3969	1.1043	1.1043	1.5778	1.0328	1.6289	1.3251
Avg	1.3969	1.2466	1.3128	1.5778	1.5037	1.6289	1.4411

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054048 / 33/11 KV NATHRA S/S

Feeder No / Name : 201 / 11 KV PANGRI FEEDER

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8745	.1296	.417			.0834	
2	.9182		.417		.091	.0834	
3	.9474		.4518			.0834	
4	1.166	.0926	.4865	.091			
5	1.2097		.5908				
6	1.2972		.695				
7	1.4138		.7993				
8	1.4575		.278	1.6739			
9	1.6504		.8519	1.7831			
10		.963		1.6739	1.3117		1.5003
11		.963			1.6178		1.8338
12		1.1481			1.7198		1.1669
13					1.5158		.8335
14							1.3184
15					1.4429		1.8128
16					1.3846		1.8458
17					1.3117		1.4832
18			.091		.0583		.0659
19		.0348			.0729		.0824
20				.091	.0824		.0659
21		.0869			.0729		
22		.0869			.0729		.0659
23		.0869	.091	.091	.0729		1.5003
24	.8453		.3649		.091	.0729	
Max	1.6504	1.1481	.8519	1.7831	1.7198	.0834	1.8458
Min	.8453	.0348	.091	.091	.0583	.0729	.0659
Avg	1.178	.3991	.4612	.9007	.7279	.0808	1.0442

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054048 / 33/11 KV NATHRA S/S

Feeder No / Name : 203 / 11 KV GFSS Nathra Feeder

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2407					.1481	
2	.2407					.1667	
3	.2963	.0925				.2593	
4	.4074			.2225	.1854	.4074	
5	.4815					.5556	
6	.5741	.222	.5735		.5561		
7	.6481		.4995		.4634		
8	.5926		.481	.7415			
9	.4815		.481	.5561	.5191		
10		.1295	.222	.3151			.3704
11		.074		.2225			
12		.074		.2225	.2222		.2778
13		.074		.1854	.1852		.1667
14		.074		.1854	.1667		.1667
15		.074			.1667		.1667
16			.1854	.2039	.1852		.2037
17		.185			.2222		.2407
18			.3151		.2778		.2778
19		.481		.3708	.3148		.4444
20		.481	.4078	.3337	.3148		.3519
21		.6401			.2963		.3148
22					.2593		.2778
23			.2225	.1854	.2222		.2037
24	.2407	.1295		.1483	.1298	.1481	
Max	.6481	.6401	.5735	.7415	.5561	.5556	.4444
Min	.2407	.074	.1854	.1483	.1298	.1481	.1667
Avg	.4204	.2100	.3764	.2995	.2757	.2809	.2664

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054048 / 33/11 KV NATHRA S/S

Feeder No / Name : 204 / 11 KV Pangri GFSS Feeder

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6628		.4444			.4166	
2	.5538		.4444			.4545	
3	.7575	.444	.4444			.4924	
4	1.0037		.5926	.5556	.7407	.7196	
5	1.2878		1			.8996	
6	1.3256	.999	1.1111	1.1111	1.2222		
7	1.3635		1.0741				
8	1.0794		.962	1.2037	1.1852		
9	.9658			1.1667	.7778		
10		.814	.74	.8889	.7575		.6628
11		.518		.6481	.6439		.5303
12		.481		.5926	.606		.4734
13		.481		.5185	.5871		.3977
14		.4995		.5185			.3977
15					.5303		.4734
16		.518	.7037	.4815	.5681		.5303
17					.6628		.5871
18		.7407			.6628		.6439
19		.8519		1.037	.7007		.7954
20		1.0926	.9259	.963	.7575		.909
21		.7407			.7764		.8522
22		.5556			.7196		.6818
23		.4444	.5556	.5556	.5492		.5303
24	.6628	.444	.444	.4444	.5	.4166	
Max	1.3635	1.0926	1.1111	1.2037	1.2222	.8996	.909
Min	.5538	.444	.444	.4444	.5	.4166	.3977
Avg	.9663	.6416	.7263	.7632	.7193	.5666	.6047

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054048 / 33/11 KV NATHRA S/S

Feeder No / Name : 205 / Wadkhel AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.0337	
2						.0337	
3	.0169	.0168	.0155			.0337	
4					.0161	.0337	
5						.0337	
6						.0337	
7						.0337	
8					.0323	.0169	
9					.0323		
10		.0155	.0155	.0161			
11		.0155					
12		.2475					
13		.0168					
14		.0168					
15		.0168					
16		.0168	.0161				
17		.0155					
18		.0155			.0169		.0169
19		.0168					
20		.0168			.0169		
21							.0169
22					.0169		
23		.0155	.0161				
24	.0169	.0168	.0155	.0161	.0161	.0337	
Max	.0169	.2475	.0161	.0161	.0323	.0337	.0169
Min	.0169	.0155	.0155	.0161	.0161	.0169	.0169
Avg	.0169	.0328	.0157	.0161	.0211	.0318	.0169

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054048 / 33/11 KV NATHRA S/S

Feeder No / Name : 206 / Pimpalgaon GFSS

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1384		.1829			.1211	
2	.173		.1829			.1557	
3	.2076	.148	.2195			.2595	
4	.2768		.2926	.1831	.2746	.346	
5	.3287		.3658			.4498	
6	.3806	.222	.3292	.3296	.476		
7	.3806		.2926				
8	.3806		.2561	.3296	.4028	.2595	
9		.2195	.2561	.2929	.4028		
10		.222	.1829	.2197	.2595		.2422
11		.148		.2197	.173		.1903
12		.1097	.1099	.2197	.1384		.1384
13		.1048		.1831	.1384		.1038
14		.1048		.1465	.1211		.1038
15		.1048			.1384		.1384
16		.1048	.1099	.1282	.173		.1384
17		.1097			.173		.1384
18		.1097			.2076		.1384
19		.1829		.3113	.2422		.173
20		.3658	.2929	.2929	.2595		.3793
21		.2561			.2422		.2941
22		.2195			.2076		.2249
23		.1829	.1465	.2197	.173		.173
24	.1384	.1463	.1829	.1465	.1831	.1384	
Max	.3806	.3658	.3658	.3296	.476	.4498	.3793
Min	.1384	.1048	.1099	.1282	.1211	.1211	.1038
Avg	.2672	.1701	.2268	.2302	.2309	.2471	.1840

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054048 / 33/11 KV NATHRA S/S

Feeder No / Name : 207 / Pimpalgaon AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1457					.5068	
2	.1749					.5321	
3	.2332	.0838	.1676	.16		.5448	
4					.7466	.5701	
5						.6081	
6					.8888	.6461	
7						.9375	
8					1.1021	1.0262	
9					1.0665		
10		.5726	.8938	1.1021			
11		1.0613		1.2798			.8016
12		1.0893		1.2798			.8745
13		1.1451		1.3865			
14		1.2289		1.4576			
15		1.2289					
16		1.2289	1.1554	1.2798			
17		1.2848					
18		.1117	.1422		.1267		.0729
19		.1397		.1422	.1267		.1161
20			.1778		.1014		.1749
21		.1676			.1014		.1749
22					.1014		.1457
23		.1397	.16	.1778	.0887		.1161
24	.1457	.0698	.1397	.1244	.7466	.5068	
Max	.2332	1.2848	1.1554	1.4576	1.1021	1.0262	.8745
Min	.1457	.0698	.1397	.1244	.0887	.5068	.0729
Avg	.1749	.6823	.4052	.839	.4724	.6532	.3096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054065 / 33/11 KV DAUTPUR S/S

Feeder No / Name : 203 / 11 KV Wadgaon

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.4085	.2263
2						.3628	.2553
3						.4275	.2761
4						.4146	.3067
5						.4938	.2743
6						.5639	.3185
7						.6859	.3418
8						.7133	.3102
9							.3338
10	.888	.9031	.5281	.5135	.4633		
11	1.2346	.9511	.5721		.5944		
12	1.358	.8322	.6081				
13	1.2498		.5146		.695		
14	1.3077		.5075		.6455		
15	1.2346				.8109		
16	1.2643		.6371		.7727		
17	1.3748	.535	.5647				
18	.8048						
24						.3647	.2591
Max	1.3748	.9511	.6371	.5135	.8109	.7133	.3418
Min	.8048	.535	.5075	.5135	.4633	.3628	.2263
Avg	1.1907	.8054	.5617	.5135	.6636	.4928	.2902

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054065 / 33/11 KV DAUTPUR S/S

Feeder No / Name : 204 / 11 KV GFSS Dautpur

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3961	.4108	.4108	.3734		.4481	.4481
2	.3961	.3734	.5228	.3734		.4108	.4854
3	.3921	.4108	.5975	.3734		.4854	.4854
4	.3921	.4481	.6348	.3734		.4108	.5601
5	.6348	.6722	.6908	.5228		.5228	.6348
6	.8402	.7468	.7468	.6348		.6535	.6908
7	.8589	.679	.6348	.7468		.7468	.7282
8	.7842	.7095	.6535	.6535		.7282	.6348
9	1.0829	.5415	.6161	.7468			.5601
10	.8215	.6161	.5975	.6348	.6348		.8215
11		.6348	.7655	.5601	.4481	.5601	.7468
12	.8962	.6161	.9149		.8215	.5415	.8589
13	.6722	.5788	.5041		.5601	.5415	.7095
14	.7468	.4481	.4854		.6348	.3547	
15	.2987	.6535	.6348		.6722	.4294	.9149
16	.6722	.5228	.5601		.7468	.7282	.7842
17	.6722	.6722	.6535		.8215		
18	.6535	.5601	.7095		.7468	.7468	.7468
19		.6722	.7468		.6722	.5975	.8589
20	.7095	.6348	.6348		.5601	.6722	.6722
21	.6348	.4854	.5601		.5228	.5975	.5228
22	.5601	.4108	.4481		.4481		.4294
23	.4481	.4108	.4481		.4294	.4481	.4108
24	.3921	.4294	.3921	.3734		.4108	.4481
Max	1.0829	.7468	.9149	.7468	.8215	.7468	.9149
Min	.2987	.3734	.3921	.3734	.4294	.3547	.4108
Avg	.6343	.5558	.6068	.5306	.6228	.5517	.6433

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054065 / 33/11 KV DAUTPUR S/S

Feeder No / Name : 205 / 11 kv GFSS Wadgaon
Dadahari Feeder KV- 11 /
OUTGOING

Gaothan Feeder

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2641	.3018	.3206		.3018	.415
2	.3018	.2829	.3395	.3018		.2641	.4527
3	.3018	.2641	.3772	.3018		.3018	.5658
4	.3018	.2263	.4527	.3018		.3772	.6413
5	.4338	.3772	.5281	.3961		.4527	.7167
6	.6979	.5281		.6979		.6036	.7545
7	.7733	.8299	.7922	.811		.7167	.8676
8	.679	.5658	.679	.7356		.7922	.8299
9	.547	.4527	.5847	.6413			.6224
10		.3018	.3584	.4527	.3584		.4338
11	.2829	.2263	.3018		.4527	.3206	.3206
12	.2641	.3018	.2641		.3395	.2829	.2829
13	.2829		.2641		.3018	.2641	.2641
14	.2641		.2641		.3772	.2452	.2641
15	.2829				.3395	.2829	.3206
16	.3395		.3584		.3961	.3206	.3395
17	.3772		.4715				
18	.415	.4527	.4338		.3395	.5847	.4715
19		.6036	.4527		.4527	.547	.3961
20	.4527	.5847	.5658		.5281	.4715	.6413
21	.3772	.415	.4527		.3772	.3584	.4338
22	.3018	.3206	.3772		.3395		.3584
23	.2641	.3018	.3584		.3018	.3018	.3018
24	.3395	.2641	.2829	.3206		.3018	.2829
Max	.7733	.8299	.7922	.811	.5281	.7922	.8676
Min	.2641	.2263	.2641	.3018	.3018	.2452	.2641
Avg	.3901	.3981	.4210	.4801	.3772	.4046	.4773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054119 / 33/11 KV ACHARYA TAKLI

Feeder No / Name : 201 / A.Takali

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9831	.9511	.9831	1.4922	.4268	.4748	.4115
2	.9831	.9511	1.1142	1.4922	.4268	.4801	.3963
3	.9831	.9511	1.1469	1.5939	.442	.4801	.3963
4	1.2289	1.1765	1.3927	1.7635	.4725	.5144	.381
5	1.3108	1.3432	1.4746	1.933	.4877	.583	.3658
6	1.5893	1.7909	1.4746	2.0008	.5182	.5658	.3658
7	1.7814	1.8861	1.8004	2.0348	.5335	.5144	.4268
8	2.0405	1.9719	1.8652	2.0856	.5182	.4973	.3658
9		2.0814	1.6956		.3963	.3201	.3353
10	1.7528	1.7814	1.6956		.3222	.2743	.3429
11	.3475	.2984	.407		1.8991	1.6156	1.3643
12	.3511	.2818	.3052		1.9669		1.4685
13	.3403	.3149			2.0008	1.7223	1.6289
14	.3086	.2785		.2286	2.0008		1.6289
15	.3155	.2818		.2896	1.9669	1.4784	1.6461
16	.3326	.2785		.2896	1.8652	1.5851	1.6461
17	.3801	.2984		.2896	1.7635		1.448
18	.4572	.3315			1.6617		1.448
19	.4525	.5571	.407	.5335	.5765		.3429
20		.5571	.4748	.4725	.5765		.5144
21	.6089		.4917	.4572	.5087	.5182	.5144
22	.5548		.4748	.4572	.4748	.4725	.5144
23	.5434		.4578	.4268	.4748	.442	.4382
24	.4096	.5601		.4578	.4268	.4748	.4268
Max	2.0405	2.0814	1.8652	2.0856	2.0008	1.7223	1.6461
Min	.3086	.2785	.3052	.2286	.3222	.2743	.3353
Avg	.8207	.9011	1.0389	1.0166	.9461	.7230	.7841

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054119 / 33/11 KV ACHARYA TAKLI

Feeder No / Name : 202 / kandi

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0503	.0686	.0503	.0678	.0914	.1017	.1372
2	.0503	.0701	.0671	.0678	.1067	.1017	.1524
3	.0503	.0732	.0671	.0678	.1067	.1372	.1372
4	.0503	.0701	.0838	.0678	.1219	.1372	.1372
5	.0671	.0686	.0838	.1187	.1219	.1372	.1372
6	.0671		.0838	.12	.1219	.1696	.1372
7	.0671		.0678	.1357	.1372	.3052	.1981
8			.0678	.1526	.1829	.373	
9			.0678		.2134	.3048	
10			.0678		.2035	.2743	
11			.3052		.0678	.0457	
12		.4641	.3391		.0678		
13		.4641	.3222	.3048	.0678	.0457	
14		.4641	.373	.3506	.0678		
15		.3978	.373	.3506	.0678	.0457	
16		.3978	.3052	.2591	.0678	.0457	
17		.4144	.3052	.3048	.0848		
18		.3812	.2543		.0848	.0457	
19		.1326	.0678	.1524	.1187	.0914	
20		.1174	.1029	.0457	.1187	.1219	
21		.0671	.1029	.0914	.0857	.1067	
22		.0671	.0686	.0914	.0857	.0762	
23			.0678	.0762	.0686	.061	
24	.0335	.0686	.0671	.0678	.0762	.0686	.061
Max	.0671	.4641	.373	.3506	.2134	.373	.1981
Min	.0335	.0671	.0503	.0457	.0678	.0457	.061
Avg	.0545	.2228	.1567	.1523	.1057	.1332	.1372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054119 / 33/11 KV ACHARYA TAKLI

Feeder No / Name : 203 / Kaudgaon

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2984	.2743	.373			
2	.2984	.2743	.373			
3	.2984	.2926	.373			
4	.2984	.3292	.407			
5	.3315	.3582	.407			
6	.4096	.3506	.4748			
7	.5079	.3429	.4748			
8	.5487	.3944	.4917			
9	.5316	.4287				
11				.3391	.3201	.4382
12				.373		.4382
13				.39	.3506	.3544
14				.39		.3544
15				.3772		.3544
16				.407		.3582
17				.373		.3544
18				.3391		.3544
Max	.5487	.4287	.4917	.407	.3506	.4382
Min	.2984	.2743	.373	.3391	.3201	.3544
Avg	.3914	.3384	.4218	.3736	.3354	.3758

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054137 / 33/11 KV KALRATRI PARLI S/S

Feeder No / Name : 202 / 11 KV KASARWADI FEEDER

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0926			.0733	.0914	.0716	
2	.0926			.0733	.0914	.0718	
3	.1109			.0922	.0912	.0721	
10	.4759		.2397	.1343	.2119	.1872	.1739
11	.7459		.2222	.1979	.1883	.2131	.1683
12	.7263	.3539	.2219	.1982	.107	.2349	.1815
13	.7392	.3521	.2294	.2		.244	.1818
14	.7521	.3521	.2469	.2112	.2283	.2294	.1872
15	.7468	.2926	.2237	.2134	.2264	.2421	.2079
16	.7621	.3127	.2149	.214	.2455	.2407	.2088
17		.3439	.1955	.2256	.2787		.2137
18	.0729	.0766	.0732	.0938	.0732		.0425
19	.0743	.0736	.1107	.0909	.0738		.0932
20		.0744	.1097	.112	.0741		.112
21			.0879	.1119			.0914
22			.0921	.1109			.0726
23		.0687	.092	.0903	.0716		.0724
24	.0932			.0735	.0917	.0715	
Max	.7621	.3539	.2469	.2256	.2787	.244	.2137
Min	.0729	.0687	.0732	.0733	.0716	.0715	.0425
Avg	.4219	.2301	.1686	.1398	.1430	.1708	.1434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563]

BU 5631

Substation No/ Name :- 054090 / 33 KV S/S LAUL

Feeder No / Name : 201 / 11 Kv Laul

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3563	.3725	.381		.4161	.3858
2	.3277	.3521	.3612		.4268	.4108
3	.1219	.3281	.3353		.3963	.423
4	.3481	.4607	.3506		.4062	.5075
5	.4239	.4334	.3506		.4374	.587
6	.4508	.4854	.3658		.4428	.5792
7	.4382	.4239	.3567		.3311	.5898
8		.3601	.2606		.463	.4572
9	.1833	.2785	.2235		.4214	.4586
10	.3201			.1166		.2439
11	.3841	.2477		.2134	.1555	
12	.2743	.2808		.2134		
13	.2561	.2782		.1829		
14		.3292		.2688		
15		.3475		.2778	.2606	
16	.2934	.381		.253	.2715	
17	.3201	.362			.3286	
18	.3734	.381		.3429		
19	.4115	.4012		.2926		
20	.4877	.4801		.2591	.4527	
21	.506	.4961		.421	.4218	.4409
22	.4801	.4534		.4062	.3913	.463
23	.3163	.4161		.3749	.3763	.4458
24	.3681	.4049	.3963		.4054	.362
Max	.506	.4961	.3963	.421	.463	.5898
Min	.1219	.2477	.2235	.1166	.1555	.2439
Avg	.3544	.3806	.3382	.2787	.3780	.4539

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563]

BU 5631

Substation No/ Name :- 054090 / 33 KV S/S LAUL

Feeder No / Name : 202 / 11 Kv Pathrud

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3429	.2772		.3258	.3224
2		.4239	.2772		.2926	.3012
3		.503	.3361		.2957	.3475
4		.6562	.3734		.2812	.3734
5		.602	.4527		.3734	.3841
6		.6241	.5093		.4527	.4066
7		.6447	.4294		.3772	.3584
8		.7385	.3584		.3395	.2829
9		.7385	.3361		.2218	.2926
10	.2481	.1578				.8623
11	.2561	.1612			.5784	1.1431
12	.1991	.1417			.9869	
13	.2033	.1417		.9846	.9602	
14	.2058	.1578		1.057	.9469	
15		.1991		.743	.9063	
16		.2054		.7145	1.0151	
17	.2454	.2012			.9604	
18	.2347	.2715		.2035	.2591	
19	.2915	.3801				
20	.3761	.3982		.3224	.4207	
21	.3841	.362		.3582	.4024	
22	.2686	.3475		.3582	.3224	.8387
23	.2534	.3292		.3582	.3224	1.2178
24		.2957	.2957		.3258	.3511
Max	.3841	.7385	.5093	1.057	1.0151	1.2178
Min	.1991	.1417	.2772	.2035	.2218	.2829
Avg	.2639	.3760	.3646	.5666	.5167	.5344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563]

BU 5631

Substation No/ Name :- 054090 / 33 KV S/S LAUL

Feeder No / Name : 203 / 11 Kv Pardi Mategaon
Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	23-JUN-17	24-JUN-17	25-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2743	.2606	.3485
2			.2953	.2515	.4024
3			.2835	.4066	.4087
4			.3001	.2926	.3603
5			.3001	.2953	.3829
6			.3001	.2905	.3734
7			.3064	.3574	.3812
8			.3944	.4024	.4338
9			.3574	.3521	.4146
10	.3658				
11	.3361				
12	.3544				
13	.3603	.3628			
14	.3372	.3447			
15	.3041	.3647			
16	.2984	.3704			
17	.3094	.3647			
24			.2873	.3315	.3692
Max	.3658	.3704	.3944	.4066	.4338
Min	.2984	.3447	.2743	.2515	.3485
Avg	.3332	.3615	.3099	.3241	.3875

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563]

BU 5631

Substation No/ Name :- 054130 / 33 KV Kuppa Sub-station

Feeder No / Name : 201 / 11kv kuppa

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5533		.4973	.5693	.6249	.4344	.3795
2	.5868		.4973	.5693	.6562	.4344	.3795
3	.5868		.4973	.6009	.6562	.4706	.4111
4	.6706		.5304	.6325	.6874	.543	.506
5	.8383		.5967	.7907	.7186	.724	.6958
6	.8383		.663	.8855	.7186	1.0136	.8223
7	1.0059		.8619	.9172	.8436	1.0136	.8539
8	1.0059		.663	.8855	.8749	.8145	.759
9	1.0562		.7293	1.0936	.8124	.6878	.5693
10	.4374	.2896	.3795	.3749	.4706		.6874
11	.3437	.3258	.3795	.2812	.3258	.506	.7499
12	.3125	.3258	.3163	.2812	.362	.5376	.7499
13		.2896	.3163	.2812	.2715	.5376	.8749
14		.3258	.3163	.2812	.2896	.6642	.8749
15	.3125	.3258	.3479	.3125	.2896	.759	.9061
16	.3125		.3795	.3437	.362	.7907	.9061
17	.3437	.543	.4744	.4687	.4706	.8539	.8124
18	.6562	.6878	.5376	.5624	.543	.3479	.4374
19		.6878	.5693	.5937	.5792	.6009	.6249
20			.57	.6562	.6878	.6325	.5937
21		.8145	.4744	.5624	.6154	.5693	.4999
22		.5792	.4111	.4687	.5068	.4744	.4374
23		.4706	.3795	.4062	.4706	.4111	.3749
24	.5533		.431	.5376	.5937	.4344	.3795
Max	1.0562	.8145	.8619	1.0936	.8749	1.0136	.9061
Min	.3125	.2896	.3163	.2812	.2715	.3479	.3749
Avg	.6126	.4721	.4925	.5565	.5596	.6198	.6369

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563]

BU 5631

Substation No/ Name :- 054130 / 33 KV Kuppa Sub-station

Feeder No / Name : 202 / 11KV UPALI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0848		.1448	.1296	.1311	1.6575	1.5223
2	.0848		.1448	.1296	.1311	1.6575	1.5223
3	.0848		.1448	.1619	.1966	1.6575	1.6194
4	.1696		.181	.2267	.1966	1.7404	1.6194
5	.2458		.4344	.3239	.3277	1.8233	1.7814
6	.3391		.5068	.3887	.4588	1.9227	1.8138
7	.2683		.362	.2591	.3277	2.1216	2.2024
8	.2515		.2896	.1943	.2622	2.1879	2.2672
9			.2172	.1311	.1311	1.8564	1.9433
10	1.5074		1.4575	1.4419	1.7238		.0655
11	1.9662	.1326	1.5223	1.704	2.0553	.0648	
12	2.2283	.1989	1.6194	1.9662	2.1879	.0648	
13	2.3594	.1989	1.749	2.1628	2.2542	.0648	
14	2.4249	.1989	1.7814	2.1628	2.3868	.0648	
15	2.3594	.1989	1.7814	2.0972	2.3868	.0648	.0655
16	2.3594	.1989	1.8138	2.0972	2.2542	.0648	.0655
17	2.3594	.1989	1.7814		2.1879	.0648	.0655
18		.0543	.1296		.0724	.0648	.1311
19		.3258	.1943		.2172	.1943	.2622
20			.1943	.2622	.2896	.2591	.2622
21		.4344	.1619	.1966	.2172	.1943	.2622
22		.2172	.1296	.1966	.181	.1619	.1311
23		.1448	.1296	.1311	.1448	.1296	.1311
24	.1341		.1448	.1296	.1311	1.5912	1.4575
Max	2.4249	.4344	1.8138	2.1628	2.3868	2.1879	2.2672
Min	.0848	.0543	.1296	.1296	.0724	.0648	.0655
Avg	1.1310	.2085	.7090	.7854	.8689	.8554	.9595

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563]

BU 5631

Substation No/ Name :- 054130 / 33 KV Kuppa Sub-station

Feeder No / Name : 203 / 11KV RAJEWADI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5735		.663	.6706	.6371	.8326	.7377
2	.5735		.663	.6706	.7042	.8326	.7377
3	.6554		.663	.8048	.7377	.905	.8048
4	.9831		.7956	.8383	.8048	1.0136	.9724
5	.9831		.8619	1.1401	.8718	1.1765	1.0898
6	1.1469		1.0774	1.3413	1.0395		
7	1.3108		1.1603	1.4083	1.1401		
8	1.3413		.9945	1.3413	1.0059	1.086	1.1401
9	1.2574		.9116	1.3077	1.0059	.905	.7377
10	.2683	.543	.3018	.4694	.5068		.7712
11	.3018	.5068	.3353	.503	.5068	.9724	.9724
12		.4706	.4359		.3982	1.073	1.1065
13		.4706	.4359		.4525	1.1401	1.073
14		.4706	.4359			1.1401	1.0395
15	.3688	.4706	.4694	.503		.6706	1.073
16	.3688	.5068	.503	.503		.9724	1.0059
17	.4694	.5068	.6371	.6371	.6516	.9054	1.073
18	.7377	.7602	.7042	.7712	.724	.6036	.6036
19		.9412	.9054	.9724	.9774	.9054	.9054
20			1.1065	1.0395	1.1222	.9724	1.1736
21		1.1584	1.0059	.9389	1.0136	.4694	1.073
22		1.0136	.8718	.8383	.905	.8048	.9724
23		.905	.8048	.7712	.8688	.7377	.8718
24	.5533		.5801	.6371	.6036	.8326	.7377
Max	1.3413	1.1584	1.1603	1.4083	1.1401	1.1765	1.1736
Min	.2683	.4706	.3018	.4694	.3982	.4694	.6036
Avg	.7433	.6711	.7218	.8622	.7942	.9024	.9396

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

ASHTI (R) S/DN[415] BU 2551

Substation No/ Name :- 054027 / 33/11 KV. S/S DHANORA

Feeder No / Name : 201 / 11 KV. KADA FEEDER

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	22-JUN-17
HR	Load (MW)
17	.3239
18	.3429
19	.6287
Max	.6287
Min	.3239
Avg	.4318

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

ASHTI (R) S/DN[415] BU 2551

Substation No/ Name :- 054097 / 33/11 KV. S/S PIMPALA

Feeder No / Name : 201 / 11 KV. PIMPALA

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	23-JUN-17
HR	Load (MW)
16	1.2193
Max	1.2193
Min	1.2193
Avg	1.2193

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

ASHTI (R) S/DN[415] BU 2551

Substation No/ Name :- 054120 / Ashti

Feeder No / Name : 201 / Ashti Urban

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.105	1.1431	1.105	1.105	1.105	.9907	1.0479
2	1.1431	1.1431	1.105	1.105	1.0669	1.0288	1.0288
3	1.1431	1.1431	1.1431	1.1431	1.086	.9717	1.0288
4	1.3146	1.1812	1.3717	1.2384	1.086	1.0098	1.0669
5	1.3717	1.3146	1.3527	1.2955	1.6956	1.3146	1.4861
6	1.5813	1.6575	1.7337	1.6004	1.8671	1.5242	1.7528
7	2.1148	2.0195	2.0386	1.8099	2.0957	1.8671	2.0576
8	2.0386	1.8861	1.9624	1.7909	2.1529	2.1529	2.0576
9	1.7337	1.8099	1.9433	1.8861	1.9814	2.0386	1.8099
10	1.6194	1.6956	1.6385	1.6956	1.5432	1.8671	1.6575
11	1.467	1.3717	1.5242	1.5051	1.4289	1.6956	
12	1.4289		1.467	1.467	1.3527	1.3717	
13	1.3717		1.4861	1.4289		1.3146	
14	1.2384		1.1241	1.4098	1.1622	1.1812	
15	1.2765	1.2193	1.2193	1.2193	1.086	1.0669	
16		1.1431	1.2955	1.3908	1.105	1.1812	1.1812
17	1.448	1.3336	1.3908	1.448	1.2003	1.3336	1.4861
18	1.6385	1.448	1.5242	1.5242	1.4861	1.4289	
19	1.7147	1.5242	1.6385	1.6385	1.5813	1.7147	1.6194
20	1.8671	1.6956	1.7718	1.848	1.8099		1.9052
21	1.7528	1.6956	1.5242	1.6194	1.5051	1.5623	1.6385
22		1.3717	1.2384	1.3908	1.3717	1.3336	
23	1.2384	1.2003	1.1812	1.2955	1.3717	1.1431	1.2003
24	1.1431	1.1241	1.1431	1.1241	1.1431	1.0479	1.0479
Max	2.1148	2.0195	2.0386	1.8861	2.1529	2.1529	2.0576
Min	1.105	1.1241	1.105	1.105	1.0669	.9717	1.0288
Avg	1.4887	1.4343	1.4551	1.4575	1.4471	1.3974	1.4749

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

ASHTI (R) S/DN[415]

BU 2551

Substation No/ Name :- 054124 / TAKALI AMIYA

Feeder No / Name : 201 / 11 TAKALI AMIYA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4915	.6554	.5735	.6554	.7373	.4973	.5735
2	.4915	.5801	.4915	.5735	.7373	.4973	.5735
3	.4801	.4973	.4973	.4973	.9012	.6401	.663
4					.9945	.8192	1.0774
5					1.065	.9831	1.5927
6					1.065	1.6575	1.6004
7					1.3108	1.989	1.7814
8					1.5565	1.9281	1.8842
9						1.8233	1.7204
10	.8192	.8288	.8192	1.1022			
11	.9831	1.326	1.326	1.1469			
12	1.1469	1.3927	1.5089	1.1603			
13	1.326	1.3927	1.4403	1.1736			
14	1.326	1.3413	1.2651	1.1603			
15	1.2574	1.2574	1.2346	1.2431			
16	1.1736	1.2574	1.3603	1.2289	.3201	.3201	.3239
17	1.065	1.1603	1.2803	1.2431	.4973	.4001	.4096
18	.5801	.7459	.7202	.5144	.7459	.6554	.4239
19	.8288	.9503	.9831	.7716	.9012	.9831	.5087
20	.9602	.9831	.9831	1.0288	.9282	1.0277	1.0513
21	.9602	1.0059	.9116	.9431	.9602	.9831	1.0059
22	.7907	.9221	.8288	.8573	.7907	.9724	.9221
23	.703	.8002	.7202	.7716	.6478	.703	.7459
24	.5801	.6173	.6401	.6401	.6554	.4915	.5601
Max	1.326	1.3927	1.5089	1.2431	1.5565	1.989	1.8842
Min	.4801	.4973	.4915	.4973	.3201	.3201	.3239
Avg	.8869	.9841	.9769	.9284	.8714	.9651	.9677

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

ASHTI (R) S/DN[415]

BU 2551

Substation No/ Name :- 054124 / TAKALI AMIYA

Feeder No / Name : 202 / 11 KV CHOBHA NIMGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4096	.5087	.4915	.4001	.3429	.3201	.3315
2	.4915	.4915	.4915	.4001	.3429	.3201	.3315
3	.663	.4973	.4973	.4744	.4287	.3163	.3688
4	.8288	.463	.4915	.4744			
5	.8288	.5868	.5601	.6249			
6	.9602	.9602	.9488	.8002			
7	1.0802	1.1203	1.2498	1.1203			
8	1.3117	1.186	1.3279	1.1336			
9	1.3117	1.1069	1.2003				
10					.8573	.8002	.9717
11					1.0402	1.2803	.9717
12					1.387	1.4746	1.1203
13					.7716	1.4746	1.2289
14					1.2146	1.4403	1.2289
15					1.2955	1.2498	1.2289
16	.1734	.1715	.1638	.1715	1.3279	1.2498	1.2431
17	.1791	.2543	.2572	.1715	1.2803	1.0802	1.326
18	.3429	.3429	.3429	.1696	.2401	.3125	.4239
19	.6001	.503	.503	.3391	.4049	.4687	.4239
20	.5735	.5801	.5868	.4239	.5668	.5601	.503
21	.4973	.4915	.5801	.5087	.5735	.4915	.4096
22	.4915	.4801	.4973	.4239	.4915	.4915	.4144
23	.4191	.4049	.4687	.3391	.3906	.4144	.4144
24	.4096	.5087	.4858	.3906	.3429	.3086	.3353
Max	1.3117	1.186	1.3279	1.1336	1.387	1.4746	1.326
Min	.1734	.1715	.1638	.1696	.2401	.3086	.3315
Avg	.6429	.5921	.6191	.4921	.7388	.7808	.7375

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

ASHTI (R) S/DN[415] BU 2551

Substation No/ Name :- 054126 / 33/11 KV WAHIRA SUB STATION

Feeder No / Name : 201 / 11 KV NIMGAON BODKHA Single Phasing Feeders
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4096		.4096		.3277
2	.3605		.4096		.3605
3	.4915		.3768		.4096
10		.9012		.8192	
11		.9831		.9012	
12		1.065		.9831	
13		1.1469		1.065	
14		1.1797		1.065	
15		1.2289		1.1469	
16		1.2289		1.2289	
17		1.278		1.3108	
18		.3277		.3277	
19		.4096		.3605	
20		.4915		.4096	
21		.4424		.3768	
22		.4096		.4096	
23		.3768		.3277	
24	.4096		.3768		.3277
Max	.4915	1.278	.4096	1.3108	.4096
Min	.3605	.3277	.3768	.3277	.3277
Avg	.4178	.8192	.3932	.7666	.3564

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

ASHTI (R) S/DN[415] BU 2551

Substation No/ Name :- 054126 / 33/11 KV WAHIRA SUB STATION

Feeder No / Name : 202 / 11 KV WAHIRA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239		.3239		.2915
2	.3239		.2915		.3239
3	.4049		.2429		.3239
10		.8907		.7287	
11		.9393		.8097	
12		.9717			
13		1.0526		.9717	
14		1.1336		.9717	
15		1.166		1.0364	
16		1.2146		1.0688	
17		1.2308		1.1336	
18		.8097		.3239	
19		.3239		.3563	
20		.3239		.3725	
21		.3239		.3563	
22		.3239		.3239	
23		.3239		.3239	
24	.3239		.3239		.2915
Max	.4049	1.2308	.3239	1.1336	.3239
Min	.3239	.3239	.2429	.3239	.2915
Avg	.3442	.7878	.2956	.6752	.3077

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

ASHTI (R) S/DN[415] BU 2551

Substation No/ Name :- 054127 / 33/11 KV DAULAWADGAON SUB

STAT

Feeder No / Name : 201 / 11 KV SALEWADGAON
Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.6154	.6478	.4372	.4534	.3887
12			.1619			
16	.2591			.4372	.5992	
20			.3077			
24	.2267	.5506		.4372	.3401	.4049
Max	.2591	.6154	.6478	.4372	.5992	.4049
Min	.2267	.5506	.1619	.4372	.3401	.3887
Avg	.2429	.583	.3725	.4372	.4642	.3968

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

ASHTI (R) S/DN[415] BU 2551

Substation No/ Name :- 054127 / 33/11 KV DAULAWADGAON SUB

STAT

Feeder No / Name : 202 / 11 KV DAULAWADGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.7712	.5365	.6371	.4694	.57
12			.2683			
16	.3018			.2515	.3353	
20			.6036			
24	.2515	.2683		.4862	.4694	.3688
Max	.3018	.7712	.6036	.6371	.4694	.57
Min	.2515	.2683	.2683	.2515	.3353	.3688
Avg	.2767	.5198	.4695	.4583	.4247	.4694

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVISION[251]

ASHTI (R) S/DN[415] BU 2551

Substation No/ Name :- 054127 / 33/11 KV DAULAWADGAON SUB

STAT

Feeder No / Name : 203 / 11 KV PIMPALGAON GHAT

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.4428	.3321		.4902	.8065
12			.506			
16	.5376				.1898	
24	.4111	.4111		.4902	.3321	.3795
Max	.5376	.4428	.506	.4902	.4902	.8065
Min	.4111	.4111	.3321	.4902	.1898	.3795
Avg	.4744	.4270	.4191	.4902	.3374	.593

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

ASHTI (R) S/DN[415] BU 2551

Substation No/ Name :- 055001 / pargaon jogeshwari

Feeder No / Name : 201 / Takalsingh

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.743	.7811	.9526	.4763	.4001	.4191	.4191
2	.7621	.8383	.9907	.4763	.4191	.4382	.4572
3	.9145	.9717	1.2765	.4763	.4763	.5144	.5335
4	.9717	1.1241	1.4289	.5716	.5525	.6287	.6478
5	1.0288	1.3336	1.5432	.6668	.6478	.8573	.8764
6		1.5051	1.7147	.8383	.8573	.9717	.9335
7	1.4861	1.5623	1.9052				
8	1.2384	1.4098	***				
9				1.5242	1.4289	1.6194	1.6956
10				1.4289	1.4861	1.6194	1.8099
11				1.467	1.2384	1.467	1.5242
12				1.5432	1.2765	1.4098	
13				1.5813	1.3527	1.5432	
14				1.6004	1.3336	1.4861	
15				1.6385	1.3146	1.5051	
16					.8002	.5525	.8573
17		.362	.5716				
18		.4001	.6097				
19		.5144	.6668				
20	.5716	.7049	.6668	.7811	.743	.4763	.1905
21	.5335	.5525	.5716	.6478	.6287	.5144	.2858
22	.4382	.5144	.5716	.5716	.5525	.5335	.1334
23	.4191	.4572	.5335	.5144	.4954	.4572	.1334
24	.4382	.4001	.4954		.4382	.4382	.4382
Max	1.4861	1.5623	14.3462	1.6385	1.4861	1.6194	1.8099
Min	.4191	.362	.4954	.4763	.4001	.4191	.1334
Avg	.7954	.8395	1.8028	.9885	.8654	.9185	.7291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054050 / 33/11 KV. MALIVES S/S, BEED

Feeder No / Name : 201 / 11 KV. TILAK ROAD FEEDER Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.4632	1.4506		1.3169	1.3169
2			1.4045	1.4148		1.2536	1.2536
3			1.3676	1.3611		1.267	1.2308
4			1.3394	1.3253		1.2308	1.2308
5	1.3611	1.4685	1.3394	1.2715	1.3432	1.2437	1.2437
6	1.4864	1.6118	1.4632	1.3611	1.576	1.4632	1.5927
7	1.5581	1.6297	1.5364	1.4327	1.5402	1.5729	1.6461
8	1.6476	1.5581	1.5364	1.5402	1.7013	1.6461	1.6827
9	1.647	1.829	1.5939	1.6095	1.6297		1.5939
10	1.7013	2.0851	1.7193	1.7013	1.6118		1.6834
11	2.009	1.9387	1.7909	1.8111	1.7193	1.8267	1.6118
12	1.8099	1.8111	1.773	1.829	1.8088	1.8625	1.7372
13	2.0995	1.829	1.7372	1.9022	1.6834		1.7193
14	2.3167	1.8461	1.7909	1.8656	1.6118	1.7013	1.6834
15	2.371	1.8461	1.8625	1.848	1.6118	1.7193	1.7194
16	2.3045	2.0119	1.9163		1.5402	1.8804	1.6834
17		1.9547	1.9728	1.7737	1.6832	1.7737	1.6834
18	2.2862	1.9547	2.0995	1.8823	1.7918	1.8823	1.9521
19	2.3777	1.9728	2.1538	1.9366	2.009	2.009	2.0416
20	2.5972	2.1357	2.2081		2.2081	2.3167	2.0058
21	2.3529	2.0814	2.0633	2.0995	1.9547	2.0995	1.97
22	2.2081	1.9909	1.9521	1.8267	1.7924		1.7551
23	1.7372	1.4998	1.6118	1.7193	1.5203		
24	1.7372	1.7013	1.4998	1.4864	1.6476	1.3717	1.39
Max	2.5972	2.1357	2.2081	2.0995	2.2081	2.3167	2.0416
Min	1.3611	1.4685	1.3394	1.2715	1.3432	1.2308	1.2308
Avg	1.9794	1.8378	1.7165	1.6568	1.6992	1.6546	1.6273

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054050 / 33/11 KV. MALIVES S/S, BEED

Feeder No / Name : 202 / 11 KV. JALNA ROAD FEEDER Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6878	.6653		.6089	.6401
2			.6447	.6468		.567	.6089
3			.6516	.6468		.5792	.5731
4			.6805	.6348		.5853	.5731
5	.6626	.6135	.695	.6283	.5975	.6036	.5792
6	.7011	.6556	.695	.6653	.6348	.724	.695
7	.7421	.7087	.724	.6722	.6535	.7522	.8048
8	.7087	.691	.7316	.7282	.7095	.7682	.823
9	.724	.7682	.7468	.724	.7392		.7421
10	.7682	.7602	.7499	.7316	.7023		.7164
11	.8048	.7865	.7499	.6878	.7577	.7499	.6878
12	.8048	.7964	.7421	.6516	.6838	.7316	.6556
13	.7316	.7964	.7682	.6379	.695	.7164	.6805
14	.8048	.8413	.7421	.6401	.5175	.6379	.6984
15	.9145	.8688	.7865	.6219	.6653	.6556	.695
16	.8326	.8413	.7316		.7316		.7059
17		.7682	.724	.5792	.5121	.724	.6697
18	.8507	.724	.7602	.6154	.724	.7602	.788
19	.905	.724	.8145	.6878	.7964	.8779	.8145
20	.9313	.8326	.8413		.8326	.8688	.7783
21	.9412	.8326	.7964	.724	.8326	.8688	.7499
22	.8779	.8048	.7682	.7392	.7964		.7499
23	.8063	.7602	.7392	.7577	.6584		
24	.8238	.7796	.6878	.6653	.7207	.6516	.6697
Max	.9412	.8688	.8413	.7577	.8326	.8779	.823
Min	.6626	.6135	.6447	.5792	.5121	.567	.5731
Avg	.8072	.7677	.7358	.6705	.6980	.7069	.7000

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054050 / 33/11 KV. MALIVES S/S, BEED

Feeder No / Name : 203 / 11 KV MONDHA ROAD FEEDER Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5014	.5121		.4706	.5068
2			.4656	.4706		.443	.4755
3			.4755	.4706		.4525	.4706
4			.4656	.4572		.4477	.4755
5	.5487	.4706	.5014	.4572	.4938	.4706	.4706
6	.6283	.6099	.6154	.5544	.6348	.6154	.6154
7	.6653		.6089	.5729	.6348	.6219	.6516
8	.5544	.5175	.5853	.5975	.6348	.5853	.6401
9	.5487	.5487	.4805	.5487	.5487		.499
10	.5121	.543	.4755	.5487	.5487		
11	.5121	.5304	.4572	.5373	.5304	.5121	.5068
12	.4938	.5121	.4572	.5068	.5121		.5487
13	.439	.5121	.4755	.5121	.4706	.4938	.5014
14	.5121	.4887	.4887	.4706	.439	.4481	.4706
15	.6154	.5121	.4755	.4706	.4938	.4344	.4572
16	.5853	.5121	.4572		.5487	.4572	.4706
17	.5792	.5121	.439	.4344	.5121	.4656	.4938
18	.5487	.5121	.4887	.4706	.543	.5014	.567
19	.695	.5487	.6154	.5792	.6516	.5973	.6036
20	.7682	.6219	.6219		.6516	.6584	.567
21	.6516	.5611	.567	.543	.5792	.5611	.5487
22	.6154		.5487	.5249	.543		.5304
23	.6036		.5304	.5068	.5068		
24	.5487	.5853	.5068	.5068	.4706	.4961	.543
Max	.7682	.6219	.6219	.5975	.6516	.6584	.6516
Min	.439	.4706	.439	.4344	.439	.4344	.4572
Avg	.5813	.5352	.5127	.5115	.5474	.5122	.5279

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVISION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054050 / 33/11 KV. MALIVES S/S, BEED

Feeder No / Name : 204 / 11KV VIJAY TALKIES

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.8688	.8131		.8048	.8326
2			.8779	.8131		.7964	.788
3			.8413	.7392		.788	.8326
4			.8779	.8131		.8326	.8779
5	.961		.8779	.8871	1.3306	.8688	.9145
6	.961		.9145	.8871	1.6263	.9877	1.0608
7	1.0349		.9412	.961	1.7741	1.0719	1.2936
8	1.0349	1.4045	.9877	1.0349	1.7741		1.2803
9	1.2437	1.3169	1.1088	1.1222	1.4784		1.3443
10	1.3169	1.2803	1.1088	1.0974	1.3306		1.3817
11	1.1706	1.2071	1.086	1.1088	.9709	1.3676	1.2936
12	1.134	2.1948	1.0349	1.134	1.0719	1.1949	1.1088
13	1.0974	2.2314	.961	1.0719	.8871	.961	.961
14	1.0242	2.0851	.8871	.9511	.8871	.8871	.8131
15	1.0974	2.0119	1.0349	.9145	.924	.924	.8131
16	1.0242	1.0974	1.1088		.8871		.8131
17		1.2803	1.2071	1.3169	.9145	.9412	.8871
18	1.5729	1.2803	1.267	1.3169	1.0136	1.1584	1.1088
19	1.3535	1.0974	1.1946	1.2437	1.0974	1.3169	1.1827
20	1.3535	1.1706	1.0974		1.2071	1.3169	1.1827
21	1.2437	1.134	1.0498	1.267	1.0608	1.1706	1.1088
22	1.2071	1.0974	.961	1.2567	1.0608		1.1088
23	2.3655	1.0136	.8871	1.2567	.9511		
24	.961	2.2916	.905	.8131	1.1088	.8413	.8238
Max	2.3655	2.2916	1.267	1.3169	1.7741	1.3676	1.3817
Min	.961	1.0136	.8413	.7392	.8871	.788	.788
Avg	1.2188	1.4820	1.0036	1.0373	1.1678	1.0128	1.0353

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054050 / 33/11 KV. MALIVES S/S, BEED

Feeder No / Name : 205 / 11 KV Jillha Parishad Urban/Sheddable Urban Feeder
 Feeder Feeder KV- 11 /
 OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.2894	1.267		1.1584	1.1523
2			1.2803	1.2308		1.1403	1.134
3			1.2803	1.1946		1.1041	1.134
4			1.267	1.1584		1.1523	1.1706
5	1.3032	1.267	1.2757	1.086	1.267	1.1765	1.2071
6	1.5565	1.5203	1.4529	1.1946	1.448	1.39	1.4632
7	1.4842	1.4118	1.4998	1.267	1.4842	1.4842	1.4998
8	1.3032	1.267	1.39	1.3032	1.448	1.4632	1.4266
9	1.2308	1.2803	1.1403	1.2936	1.4118	1.2071	1.1827
10	1.2308	1.3535	1.1403	1.2437	1.086	1.1222	1.2197
11		1.267	1.1222	1.2048	1.134	1.1706	1.1088
12		1.3169	1.0498	1.2071	1.2071	1.134	.9511
13	1.267	1.4632	1.0136	1.1706	.9774	1.0974	1.0242
14	1.3394	1.3717		1.1888	.9511	1.086	1.0974
15	1.3394	1.3535	1.267	1.1706	.9877	1.134	1.0242
16	1.2803	1.3169	1.1584		1.0242		1.0974
17	1.3535	1.3394	1.1222	1.1584	1.086	1.1946	1.1222
18	1.5364	1.3032	1.1946	1.1946	1.0498	1.267	1.3032
19	1.5364	1.3032	1.3756	1.267	1.2308	1.3032	1.3032
20	1.7193	1.5565	1.5203		1.448	1.4842	1.3756
21	1.6827	1.5565	1.5203	1.5203	1.4118	1.4842	1.448
22	1.576		1.4661	1.4299	1.3394		1.4118
23	1.6289		1.3756	1.3575	1.2437		
24	1.448	1.5384	1.3253	1.267	1.3032	1.1765	1.1888
Max	1.7193	1.5565	1.5203	1.5203	1.4842	1.4842	1.4998
Min	1.2308	1.267	1.0136	1.086	.9511	1.086	.9511
Avg	1.4342	1.3770	1.2838	1.2443	1.2270	1.2348	1.2194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVISION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054061 / 33/11 KV. DHANORA ROAD S/S

Feeder No / Name : 202 / 11 KV. NAGAR ROAD FEEDER Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.8507			.7964	
2			.8326			.8688	
3			.7421			.7602	
4			.905			.7602	
5			.905			.8507	
6			.9412			.9774	
7			1.0498			.9231	
8			1.086			1.1765	1.0029
9	1.0498			1.1222			
10	.905			1.0136			
11	.7964			.9412			
12	.7964						
13	.8507			.8145			
14	.8326			.8145			
15	.905			.8145			
16	.9412			.8145			
17		.4344	.9231		.7421		
18		.5792			.7783		
19		.8507			.905		
20		1.1222			1.1222		
21		1.0498			1.0679		
22		1.0679			1.0498		
23		.9955			.905		
24			.8688			.8326	
Max	1.0498	1.1222	1.086	1.1222	1.1222	1.1765	1.0029
Min	.7964	.4344	.7421	.8145	.7421	.7602	1.0029
Avg	.8846	.8714	.9104	.905	.9386	.8829	1.0029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVISION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054061 / 33/11 KV. DHANORA ROAD S/S

Feeder No / Name : 203 / 11 KV. PALWAN FEEDER
Feeder KV- 11 / OUTGOING

AG Feeder with SDT

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0762			
2			.0762			
3			.0838			
4			.0838			
5			.0991			
6			.1372			
7			.1067			
8			.1067			.0189
9	.0572			.1448		
10	.06			.0648		
11	.1524			.061		
12	.0838					
13				.0533		
14	.08			.0533		
15	.08			.0495		
16	.08			.0495		
17		.0381	.0057		.061	
18		.0533			.0686	
19		.0457			.0991	
20		.0686			.1143	
21		.0991			.1067	
22		.0914			.0991	
23		.0838			.0762	
24			.0838			
Max	.1524	.0991	.1372	.1448	.1143	.0189
Min	.0572	.0381	.0057	.0495	.061	.0189
Avg	.0848	.0686	.0859	.0680	.0893	.0189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVISION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054061 / 33/11 KV. DHANORA ROAD S/S

Feeder No / Name : 204 / 11 kv Express Civil
hospital F Feeder KV- 11 /
OUTGOING

HV Express Feeder

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0543			.0543	
2			.0543			.0543	
3			.0543			.0543	
4			.0543			.0543	
5			.0543			.0543	
6			.0543			.0543	
7			.0543			.0543	
8			.0543			.0543	.037
9	.0724			.0543			
10	.0905			.0543			
11	.1086			.0543			
12	.0905			.0543			
13	.0905			.0543			
14	.0724			.0543			
15	.0905			.0543			
16	.0724			.0543			
17		.0724	.056		.0543		
18		.0543			.0543		
19		.0543			.0543		
20		.0543			.0543		
21		.0724			.0543		
22		.0543			.0543		
23		.0543			.0543		
24			.0543			.0543	
Max	.1086	.0724	.056	.0543	.0543	.0543	.037
Min	.0724	.0543	.0543	.0543	.0543	.0543	.037
Avg	.0860	.0595	.0545	.0543	.0543	.0543	.037

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVISION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054061 / 33/11 KV. DHANORA ROAD S/S

Feeder No / Name : 205 / 11 KV BALEPEER FEEDER Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.3032			
2			1.1946			
3			1.267			
4			1.7013			
5			1.7194			
6			1.5384			
7			1.7737			
8			1.8099			1.9909
9	1.6289			1.9185		
10	1.5023			1.7375		
11	1.267			1.6289		
12	1.1946			1.5203		
13	1.267			1.4118		
14	1.448			1.3756		
15	1.5927			1.3394		
16	1.6289			1.448		
17		1.5565	1.5927		1.2308	
18		1.5203			1.3394	
19		1.4842			1.5203	
20		1.5565			1.8461	
21		1.6651			1.6289	
22		1.5203			1.5203	
23		1.4842			1.3756	
24			1.4118			
Max	1.6289	1.6651	1.8099	1.9185	1.8461	1.9909
Min	1.1946	1.4842	1.1946	1.3394	1.2308	1.9909
Avg	1.4412	1.5410	1.5312	1.5475	1.4945	1.9909

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054061 / 33/11 KV. DHANORA ROAD S/S

Feeder No / Name : 206 / 11KV COLLECTOR OFFICE

HV Express Feeder

EXPRESS Feeder KV- 11 /

OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0187			.0187	
2			.0187			.0187	
3			.0187			.0187	
4			.0187			.0187	
5			.0187			.0187	
6			.0187			.0187	
7			.0187			.0187	
8			.0187			.0187	.0191
9	.0187			.0187			
10	.056			.0187			
11	.1494			.0187			
12	.1494			.0187			
13	.1448			.0187			
14	.1307			.0187			
15	.1307			.0187			
16	.1629			.0187			
17		.0187	.0191		.0187		
18		.0187			.0187		
19		.0187			.0187		
20		.0187			.0187		
21		.0187			.0187		
22		.0187			.0187		
23		.0187			.0181		
24			.0187			.0187	
Max	.1629	.0187	.0191	.0187	.0187	.0187	.0191
Min	.0187	.0187	.0187	.0187	.0181	.0187	.0191
Avg	.1178	.0187	.0187	.0187	.0186	.0187	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054061 / 33/11 KV. DHANORA ROAD S/S

Feeder No / Name : 207 / 11 KV Natyagruh feeder Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.6289			1.448	
2			1.4661			1.4118	
3			1.448			1.4299	
4			1.4842			1.4118	
5			1.5384			1.4661	
6			1.647			1.8099	
7			1.8461			1.8823	
8			1.8461			1.7918	1.8656
9	1.9004			1.7556			
10	1.7194			1.7375			
11	1.5746			1.7194			
12	1.1765			1.5565			
13	1.7013			1.5927			
14	1.6651			1.5384			
15	1.7013			1.448			
16	1.7194			1.448			
17		1.7194	1.5912		1.4299		
18		1.7013			1.5565		
19		1.7375					
20		2.009			1.9909		
21		2.1357			1.9728		
22		1.9366			1.9366		
23		1.7918			1.7375		
24			1.6651			1.5746	
Max	1.9004	2.1357	1.8461	1.7556	1.9909	1.8823	1.8656
Min	1.1765	1.7013	1.448	1.448	1.4299	1.4118	1.8656
Avg	1.6448	1.8616	1.6161	1.5995	1.7707	1.5807	1.8656

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054082 / 33/11 KV. MIDC S/S, BEED

Feeder No / Name : 201 / 11 KV. GORE FEEDER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.2572	.2743	.2743	.2401	.4115
2	.3429	.3258	.2229		.2743	.2229	.3772
3	.3601	.3086	.2229	.2572	.2743	.2229	.4115
4	.3772	.3086	.2229	.2572	.3086	.2229	.4115
5	.3772	.3086	.2229	.2572	.3086	.2229	.4287
6	.3944	.3429	.2915	.2572	.3086	.2915	.4458
7	.4287	.3601	.2401	.2572	.2915	.3258	.3601
8	.4287	.3258	.2229	.2915	.3429	.3772	.3258
9	.4115	.463	.2572	.3086	.3772	.4287	.2915
10	.4115	.6173	.3086	.4115	.3772	.6516	.2058
11	.4458	.5487	.5144	.3772	.4115	.6001	.2058
12	.4458		.5658	.4287	.4801		.2229
13	.463		.3944	.5144	.5316	.5144	.2229
14	.463	.5316	.5144		.4115	.4801	
15	.463	.5487	.4801	.3429	.4115	.4801	
16	.4287	.4973	.4458	.3429	.463	.5658	
17	.3944	.463	.4458	.3772	.4801	.583	.2229
18	.4458	.4801	.4115	.4458	.463	.5487	.2401
19	.463	.4973	.3772	.3944	.4115	.5316	.2229
20	.3258	.4458	.3429	.3601	.3429	.4801	.1715
21	.3944	.2915	.2915	.3258	.3086		.1715
22	.3429	.2915	.3429	.3086	.3086		.1943
23	.3429	.2743	.3258	.3086	.3086	.4115	.2572
24	.3772	.3429	.2572	.3086	.3086	.2401	.5658
Max	.463	.6173	.5658	.5144	.5316	.6516	.5658
Min	.3258	.2743	.2229	.2572	.2743	.2229	.1715
Avg	.4030	.4053	.3408	.3367	.3658	.4115	.3032

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054082 / 33/11 KV. MIDC S/S, BEED

Feeder No / Name : 202 / 11 KV. N.K. FEEDER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2439	.1886	.2401	.2286	.2286	.2572	.3048
2	.2439	.1886	.2401		.2286	.2572	.2743
3	.2743	.1715	.2572	.2572	.2286	.2743	.2743
4	.3048	.1715	.2743	.2439	.2439	.2743	.2743
5	.3048	.1715	.2743	.3048	.2743	.3086	.3048
6	.3353	.2401	.2401	.3048	.3048	.3086	.3772
7	.3658	.2743	.2058	.3048	.3658	.3772	.3963
8	.3048	.2743	.2743	.3048	.3658	.3086	.3658
9	.3506	.2743	.3086		.2743	.1981	
10	.3506	.5144	.3429	.2439	.2743	.2439	.2286
11	.3506	.4801	.4801	.2134	.3086		.1372
12	.2743	.4801	.4268	.2743	.2743		.1067
13	.3658	.4458	.3048	.3353	.2743		.1067
14	.3658	.3086	.3048		.2743	.2439	
15	.3353	.3772	.3048	.3658	.2401	.2743	
16	.3506	.4115	.3048	.3353	.3086	.3353	
17	.7773	.3772	.3048	.3201	.2401	.3963	.1067
18	.2743	.3772	.3353	.1829	.2401	.3429	
19	.2401	.2229	.3658	.1829	.2229	.2439	.1524
20	.2058	.2058	.3658	.2439	.2915	.3201	.1829
21	.1715	.1886	.3658	.1829	.2743		.1829
22	.1715	.1886	.3048	.2439	.2743		.2439
23	.2058	.2058	.3048	.2439	.2743	.3201	.2743
24	.2439	.2401	.2401	.2439	.2439	.2572	.3506
Max	.7773	.5144	.4801	.3658	.3658	.3963	.3963
Min	.1715	.1715	.2058	.1829	.2229	.1981	.1067
Avg	.3088	.2908	.3071	.2648	.2721	.2917	.2445

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054082 / 33/11 KV. MIDC S/S, BEED

Feeder No / Name : 203 / 11KV POLYTECHNIC COLLEGE Ag dominated/Pure Ag
feede Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1067	.1886	.1715	.1886	.1067	.1715	.1715
2	.1067	.1886	.1715		.0667	.1715	.1886
3	.1067	.1886	.1715	.1715	.1067	.1715	.1886
4	.1372	.1886	.1886	.1886	.1524	.1886	.1715
5	.1829	.2058	.1886	.2058	.1524	.1886	.2058
6	.2591	.2743	.3086	.2743	.1829	.3086	.2229
7	.3048	.3258	.3429	.2915	.2743	.2401	.1715
8	.1981	.3086	.3086	.3258	.1829	.2058	.2058
9	.2743	.2743	.3086	.2743	.1886		.1524
10	.2058	.1715	.2743	.1981	.1886		.1067
11	.1543	.1372	.2743	.1524	.1886		.1677
12	.1715	.1029	.1543	.1219	.1543		.1219
13	.12	.1372	.1886	.0914	.1715		.1219
14	.1372	.1543	.1543		.1543	.0914	
15	.1372	.2229	.1372	.2134	.1543	.0914	
16	.1372	.2058	.1543	.1829	.1715	.0914	
17	.1372	.2229	.1715	.1829	.1715	.1524	.1372
18	.2229	.2743	.2058	.2286	.2058	.1829	.2134
19	.2401	.2229	.2572	.1524	.1372	.1677	.1524
20	.3086	.2401	.2401	.2286	.2743	.2591	.1524
21	.2401	.2058	.2058	.1981	.2401		.1524
22	.2058		.1886	.1677	.1886		.1219
23	.1886	.1886		.1524	.1715	.1781	.1219
24	.1067	.1886	.1715	.1715	.1067	.1715	.1911
Max	.3086	.3258	.3429	.3258	.2743	.3086	.2229
Min	.1067	.1029	.1372	.0914	.0667	.0914	.1067
Avg	.1829	.2095	.2147	.1983	.1705	.1784	.1638

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054082 / 33/11 KV. MIDC S/S, BEED

Feeder No / Name : 204 / 11 KV BAHIRWADI FEEDER

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6706	.6097	.6097	.6097	.6706	.6097
2	.6859	.6706	.6097		.6859	.6097	.5792
3	.7621	.6706	.7202	.6859	.7621	.6097	.5792
4	.8383	.7011	.7545	.6859	.8383	.7316	.6097
5	.9145	.823	.7316	.6097		.884	.7621
6	1.0669	1.0288	.9755	.7621	.9907	1.1888	1.0974
7	.9755	1.0364	1.0974	1.0364	1.0669	1.1584	1.2193
8	.9145	.9755	1.0364	1.0974	1.1431	1.1584	1.0974
9	.884	.9145	.9145	.945	.9145		.8383
10	.7316	.823	.7621	.8535	.7926		.7011
11	.6249	.6706	.1372	.7621	.7926		.5487
12	.6173		.3048	.6097	.6706		.5944
13	.6097		.6401	.5182	.5792		.5487
14	.6097	.6706	.6097		.5487	.5792	
15	.6097	.6097	.6097	.6097	.5487	.5944	
16	.6401	.6097	.6097	.6097	.6097	.6097	
17	.6706	.6097	.7545	.6706	.6097	.6097	.6706
18	.7926	.7316	.7316	.7926	.6706	.7316	.8535
19		.7926	.7926	.8535	.8688	.8535	.8535
20	.9145	.8535	.7621	.945	.9145	.9755	1.0669
21	.7926	.823	.7621	.7926	.8535		.9907
22	.7316	.7621	.6097	.7316	.7621	.7621	.7926
23	.6706	.7164	.6859	.6859	.7621	.7621	.7621
24	.6859	.6706	.6097	.6097	.6401	.6706	.6097
Max	1.0669	1.0364	1.0974	1.0974	1.1431	1.1888	1.2193
Min	.6097	.6097	.1372	.5182	.5487	.5792	.5487
Avg	.7578	.7652	.7013	.7489	.7667	.7866	.7802

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054082 / 33/11 KV. MIDC S/S, BEED

Feeder No / Name : 205 / 11 KV MAULI FEEDER

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.3772	.3429	.3429	.3429	.3258	.3772
2	.4287	.3772	.3429		.3429	.3258	.3772
3	.4458	.3772	.3429	.3772	.3856	.3086	.3944
4	.4801	.3944	.3772	.4115	.4115	.3258	.4115
5	.5144	.4115	.3944	.4115	.4115	.3429	.4458
6	.5493	.4801	.4115	.4458	.463	.3601	.4973
7	.5487	.4973	.4458	.4801	.4458	.4458	.5487
8	.6001	.463	.4287	.5144	.5316	.4801	.5316
9	.5316	.6516	.4287	.4725	.5144		.5144
10	.5144	.4801	.4115	.4801	.4458		
11	.4973	.5144	.4572	.4458	.4458		
12	.5316	.463	.12	.463	.4287		.3772
13	.583	.463	.4973	.463	.4115		.3429
14	.463	.4287	.5316		.3944	.4458	
15	.463	.3772	.4973		.3429	.4458	
16		.2229	.4801	.3429	.3601	.4801	
17	.4973	.3601	.4801	.5144	.3086	.4801	.3429
18	.4973	.3429	.4973	.4458	.2915	.4801	.463
19	.583	.3772	.4973	.3772	.3772	.3086	.4801
20	.5144	.3772	.4287	.3944	.3772	.4458	.4801
21	.4287	.3429	.3944	.3944	.3772	.4458	.4801
22	.3944	.3429	.4115	.3601	.3772	.4458	.4458
23	.3772	.3429	.3772	.3601	.3772	.4115	.4287
24	.4287	.3772	.3429	.3772	.3601	.3258	.3944
Max	.6001	.6516	.5316	.5144	.5316	.4801	.5487
Min	.3772	.2229	.12	.3429	.2915	.3086	.3429
Avg	.4913	.4101	.4141	.4226	.3969	.4016	.4386

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054125 / 33/11 KV JALANA ROAD S/STN

Feeder No / Name : 201 / 11 KV WASANWADI AG FEEDER Ag dominated/Pure Ag
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0532	.0686			.0514	.0514	
2	.0532	.0514			.0514	.0514	
3		.0686			.0686	.0686	
4	.0532	.0857			.0686	.0514	
5	.0532	.1029	.0895		.1029	.0857	
6	.1772	.1715			.1372	.12	
7	.1949				.1715	.1715	.1791
8	.1949		.1254				.2149
9	.1772	.1772	.12	.0709			.1543
10	.1417	.124	.1029	.0709	.124	.1063	.12
11	.1063	.1063	.0857	.0709		.0886	.1029
12		.1063	.0686	.0709		.1063	.0686
13	.1063	.1063	.0686	.0532	.0532	.0886	.0857
14	.1063	.1063	.0514	.0532			.0857
15	.0709	.0886	.0514	.0732	.0709	.0532	.0857
16	.1097	.0709		.0549	.0532	.0724	.0686
17	.12		.0709		.0514	.0716	.124
18	.1372		.0886		.0171	.1086	.1417
19	.1372		.1063		.0686	.1086	.1595
20	.1372		.1063		.0857	.1086	.1949
21	.12		.0886		.0857	.1097	.1417
22	.0857						.124
23	.0857						.1063
24	.0532	.0686	.0716		.0686	.0514	.0716
Max	.1949	.1772	.1254	.0732	.1715	.1715	.2149
Min	.0532	.0514	.0514	.0532	.0171	.0514	.0686
Avg	.1125	.1002	.0864	.0648	.0782	.0881	.1238

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054125 / 33/11 KV JALANA ROAD S/STN

Feeder No / Name : 202 / 11 KV SHANTAI FEEDER Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.567	.6219			.4755	.567	
2	.567	.6219			.4755	.567	
3	.5493	.567			.439	.5487	
4	.5316	.5487			.4938	.5487	
5	.5316	.567	.5194		.5121	.567	
6	.6201	.5853			.5853	.6036	
7	.6556				.6584	.7133	.6984
8	.691		.5731				.6626
9	.6584	.6024	.567	.5853			.6219
10	.6584	.6556	.567	.5487	.567	.5847	.6036
11	.6219	.6024	.5853	.5487		.5138	.6036
12		.7087	.6219	.5487			.567
13	.5853	.5847	.6767	.5487	.4784	.567	.5121
14	.5853	.567	.7133	.5316		.6024	.5121
15	.6584	.6379	.7133	.5121	.443	.567	.4938
16	.6584	.6201		.4024	.4784	.5121	.5121
17	.6584		.6201		.4938	.5853	.5316
18	.7133		.5847		.5304	.5853	.5847
19	.7499		.5493		.567		.5847
20	.7133		.6024		.6219		.6201
21	.695		.5847		.6401	.543	.6024
22	.6584						.567
23	.6584						.5316
24	.6024	.6401	.5194		.4938	.6036	.4835
Max	.7499	.7087	.7133	.5853	.6584	.7133	.6984
Min	.5316	.5487	.5194	.4024	.439	.5121	.4835
Avg	.6343	.6087	.5998	.5283	.5267	.5753	.5718

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054125 / 33/11 KV JALANA ROAD S/STN

Feeder No / Name : 203 / 11KV Ambika Nagar feeder Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8427	1.701			1.4815	1.4632	
2	1.8604	1.7193			1.4632	1.4449	
3	1.7541	1.6644			1.4998	1.4449	
4	1.7187	1.6278			1.4449	1.4815	
5	1.6832	1.6461	1.6476		1.4815	1.4998	
6	2.0022	2.0119			1.7193	1.7193	
7	1.949				2.1216	2.1033	1.8088
8	1.8781		1.8267				1.6118
9	1.829	1.825	1.701	1.8656			1.5546
10	1.7558	1.7718	1.6278	1.829	1.6301	1.5769	1.4998
11	1.6827	1.701	1.6461	1.7558		1.4706	1.5181
12		1.5592	1.6644	1.7193		1.5238	1.4998
13	1.6461	1.5947	1.6461	1.6827	1.5415	.1595	1.4632
14	1.6095	1.701	1.6095	1.6461		1.6832	1.4266
15	2.0485	1.6124	1.6278	1.5238	1.4706	1.5415	1.5546
16	1.8823	1.825		1.5364	1.5061	1.6827	1.4632
17	1.9753		1.7541		1.5729	1.7193	1.5415
18	1.8656		1.8781		1.6278	1.6827	1.7364
19	2.1582		1.8604		1.7558		1.8781
20	2.4143		2.1262		2.0302	2.1216	2.0199
21	2.2497		2.0022		1.9936	2.0119	1.9845
22	2.1216						1.949
23	1.9022						1.8604
24	2.0376	1.7924	1.6834		1.5729	1.6095	1.5402
Max	2.4143	2.0119	2.1262	1.8656	2.1216	2.1216	2.0199
Min	1.6095	1.5592	1.6095	1.5238	1.4449	.1595	1.4266
Avg	1.9073	1.7169	1.7534	1.6948	1.6420	1.5758	1.6617

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVISION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054125 / 33/11 KV JALANA ROAD S/STN

Feeder No / Name : 204 / 11 KV Vitthal Mandir Urban/Sheddable Urban Feeder
Feeder Feeder KV- 11 /
OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2658	.2534			.1991	.181	
2	.2481	.2172			.1991	.1991	
3	.2481	.2378			.181	.1991	
4	.2658	.2353			.181	.181	
5	.2658	.2353	.2149		.181	.1991	
6	.3012	.2896			.2172	.2353	
7	.3012				.2534	.2715	.3045
8	.2835		.2507				.2507
9	.2561	.2658	.2353	.2195			.2172
10	.2378	.2303	.2353	.1829	.2303	.1949	.2172
11	.2195	.2126	.1991	.2195		.1772	.181
12		.1949	.181	.2195		.1595	.181
13	.1829	.1949	.2172	.2195	.2126	.1772	.181
14		.1949	.2172	.1829		.1772	.181
15	.2561	.2126	.2172		.1772		.181
16	.2126	.2126		.1829	.1772	.2012	.181
17	.2534		.1949		.181	.2012	.2126
18	.2534		.1949		.1991	.2378	.2303
19	.2715		.2481		.2353	.2561	.2303
20	.2896		.2835		.2715	.2926	.2658
21	.3258		.2481		.2715	.2561	.2658
22	.3077						.2126
23	.3077						.1772
24	.2835	.2715	.2507		.2172	.2172	.2328
Max	.3258	.2896	.2835	.2195	.2715	.2926	.3045
Min	.1829	.1949	.181	.1829	.1772	.1595	.1772
Avg	.2653	.2306	.2259	.2038	.2109	.2113	.2168

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVISION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054125 / 33/11 KV JALANA ROAD S/STN

Feeder No / Name : 205 / 11 kv Jain Patra Feeder Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1772	.1629			.0724	.1267	
2	.1595	.181			.0724	.1086	
3	.1417	.1629			.0905	.1086	
4	.124	.1629			.0905	.1086	
5	.124	.181	.1612		.1086	.1267	
6	.2303	.2172			.181	.181	
7	.2658				.2353	.2353	.2507
8	.3189		.1791				.2328
9	.2896		.181	.2353			.1991
10	.2534	.1772	.1629	.2172	.2303	.2481	.181
11	.2534	.2658	.181	.2172		.2303	.181
12		.1949	.2172	.2172		.2481	.181
13	.2534	.2126	.181	.181	.1417	.2126	.181
14	.2353	.1772	.1448	.181		.1949	.181
15	.2172	.1595	.1448	.1829	.2126	.1949	.181
16	.2126	.1772		.1772	.2303	.2172	.1991
17	.3258		.1772		.2353	.181	.1772
18	.2896		.2126		.2353	.1991	.2658
19	.2715		.2303		.2353	.2172	.2303
20	.2534		.2303		.2172	.2534	.2658
21	.2534		.1417		.2172	.2378	.2481
22	.2353						.2126
23	.2172						.2126
24	.2126	.1991	.1254		.0905	.1629	.1254
Max	.3258	.2658	.2303	.2353	.2353	.2534	.2658
Min	.124	.1595	.1254	.1772	.0724	.1086	.1254
Avg	.2311	.1880	.1780	.2011	.1704	.1897	.2059

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 057002 / 132/11 KV S/S, BEED

Feeder No / Name : 201 / 11 KV BARSHI NAKA FEEDER Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	24-JUN-17	25-JUN-17
HR	Load (MW)	Load (MW)
9	2.758	6.2502
10	2.6505	5.8025
11	2.6787	5.3906
12	2.733	3.9041
13		4.8712
14		4.7279
15		4.5668
16		4.6921
Max	2.758	6.2502
Min	2.6505	3.9041
Avg	2.7051	5.0257

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVISION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 057002 / 132/11 KV S/S, BEED

Feeder No / Name : 407 / 33 KV Incomer JALNA ROAD Station Trasformer Feeder
Feeder KV- 33 / INCOMING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	8.8769	8.626		7.0016	7.3377	
2	8.6643	8.3076		6.9456	7.2817	
3	8.0796	8.2899		7.0016	7.2817	
4	8.0796	8.1779		7.0016	7.2817	
5	7.9733	8.4019	7.8978	7.3377	7.54	
6	9.9932	10.0823		8.6488	8.7043	
7	10.0995			10.5864	10.6447	.038
8	10.0995		.038			8.9186
9		9.3021				7.7366
10		8.8769		8.239	8.1327	7.9012
11		8.6643			7.4417	8.6334
12		8.2922			6.1128	7.4389
13		.7973	8.2202	7.2822	7.9201	7.2217
14		8.239	8.1447		7.9733	7.0382
15		8.1327	8.1127	7.1228	7.0696	7.4389
16		10.3121		7.3354		7.2217
17	10.0412		8.4517	7.468		7.7606
18	9.8217		8.8769	7.7646		8.8769
19	10.9219		8.9832	8.6146		9.249
20	11.4678		10.0463	9.6108		10.0995
21	10.974		9.1958	9.6571		9.7274
22	10.2606					9.1958
23	9.6108					8.3848
24	9.5679	9.1301	8.0361	7.8418	8.1219	7.3605
Max	11.4678	10.3121	10.0463	10.5864	10.6447	10.0995
Min	7.9733	.7973	.038	6.9456	6.1128	.038
Avg	9.6582	8.2422	7.8185	7.9682	7.7746	7.7912

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 057002 / 132/11 KV S/S, BEED

Feeder No / Name : 408 / 33 KV Incomer MALIVES

Urban/Sheddable Urban Feeder

Feeder KV- 33 / INCOMING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			4.8868	5.2126		4.3439	4.4525
2			4.6205	5.104		4.1907	4.3439
3			4.513	5.104		4.1461	4.2798
4			4.5713	4.9954		4.2798	4.3896
5	5.5384	5.4298	4.7782	4.9954	5.2126	4.3439	4.4993
6	5.647	4.7782	5.2126	4.9954	6.19	5.2675	5.487
7	5.8642	4.6696	5.2652	5.3212	6.9502	5.5384	5.8642
8	5.5384	5.8642	5.2675	5.5384	6.9502	5.5967	5.9259
9	5.5384	5.7556	5.2126	5.3212	6.5158		5.4298
10	5.7556	5.9728	5.3212	5.3772	5.7556		5.104
11	4.4525	5.8025	5.4298	5.487	5.3212	5.647	4.8868
12	4.3439	6.6941	5.3212	5.2652	5.4298	5.3212	5.2126
13	4.9954	6.7696	5.2126	5.4298	4.9954	5.2126	4.9954
14	6.19	6.6941	4.1267	5.0503	4.8868	4.8868	4.8868
15	6.5158	6.6941	5.647	4.9429	4.8868	4.9954	4.7782
16	6.2552	5.695	5.7556		4.7782	5.2126	4.8868
17	6.3649	5.9728	5.8642	5.4298	4.8868	5.3212	5.104
18	6.6621	5.7556	5.9728	5.647	5.3212	5.647	5.8642
19	6.7696	5.7556	6.4072	5.8642	5.9728	6.19	6.4072
20	7.4623	6.6244	6.5158		6.5158	6.733	6.19
21	7.0233	6.5158	6.19	6.19	6.0814	6.4072	5.9728
22	6.5844		5.9728	5.9728	5.5384		5.8642
23	7.3846		5.3212	5.7556	5.0503		
24	5.8642	7.276	5.048	5.2126	5.5384	4.561	4.6696
Max	7.4623	7.276	6.5158	6.19	6.9502	6.733	6.4072
Min	4.3439	4.6696	4.1267	4.9429	4.7782	4.1461	4.2798
Avg	6.0375	6.0400	5.3514	5.3733	5.6389	5.1921	5.1954

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054003 / 33/11 KV. CHOUSALA

Feeder No / Name : 201 / 11 KV. CHOUSALA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2953		.3544	.2362	.2353	.3096	.2362
2	.3544	.4268	.4725	.2477	.3481	.3715	.4954
3	.4725	.4649	.6287	.4954	.4649	.4334	.4954
4	.743	.6001		.5906	.6811	.4954	.6192
5		.7926	.743	.7087	.7316	.5201	.6811
6	.8049	.8977	.7678	.8269	.9297	.9288	.5001
10	.5906		.743	.6142	.7202		.743
11	.4681	.1486		.6341		.5959	.1739
12	.4458	.1181	.6573	.5552			
13	.4252	.4954	.6859	.3361		.5087	.4954
14	.3307		.5868	.2848	.2858	.4191	.2717
15	.3961	.5077	.4664	.4081			
16	.3887	.4954	.4134	.3841			
17	.0994		.4252	.5077	.4334		
18				.5521	.4134		
19	.4607	.4954		.2881		.3715	.3715
20	.4921	.5077		.3662	.4134	.3715	.3544
21	.43	.5077		.3658	.4706	.3715	.3544
22	.3841	.4334		.2641		.322	.3715
23	.3426	.3344		.2521		.2599	
24	.2953	.3292	.3544	.2477	.2477	.2724	.3544
Max	.8049	.8977	.7678	.8269	.9297	.9288	.743
Min	.0994	.1181	.3544	.2362	.2353	.2599	.1739
Avg	.4326	.4722	.5614	.4365	.4904	.4368	.4345

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054003 / 33/11 KV. CHOUSALA

Feeder No / Name : 202 / 11 KV. SULTANPUR

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3544		.3544	.3544	.2705	.3715	.3715
2	.3715	.0457	.3715	.3544	.2934	.4744	.3715
3	.3715	.0495	.3544	.3544	.2896	.4334	.3715
4		.0229	.3544	.3544	.2934	.3544	.3801
5		.0823	.4725	.4725	.381	.3544	.4572
6	.7678	.0867	.6811	.5316	.4687	.4954	.5573
7				.5316	.4744		
8	.6241			.5316	.463		.4954
9	.5944			.5906	.3906		.4954
10			1.1869	.2953			.3715
11	.8916		1.2717			.3887	.1524
12	.8916		1.3413				
13	.7202	.7087	1.3565				
14	.7316	.7087			.2286		
15	.9145	.743	1.2574				
16	.9031	.7087	.8269		.2953		
17	.4954	.7087	.8269		.3544		.3715
18	.0762	.4134		.0648	.4134		.4954
19	.0572	.4954		.1143	.5316	.4954	.4954
20	.1429	.6497			.5316		.4954
21	.1067	.4954		.0869	.2601	.4954	.4134
22	.1067	.4706	.3715	.0857		.3544	.3544
23	.0823	.3715		.0724		.3544	
24	.3715	.0572	.3544	.3544	.2591	.3715	.3715
Max	.9145	.743	1.3565	.5906	.5316	.4954	.5573
Min	.0572	.0229	.3544	.0648	.2286	.3544	.1524
Avg	.4788	.4011	.7588	.3218	.3646	.4119	.4130

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054003 / 33/11 KV. CHOUSALA

Feeder No / Name : 203 / 11 KV. S. BORGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2953	.189	.12	.1238	.1238
2		.322	.3544	.1858	.1143	.1858	.1772
3	.3715	.3487	.3715	.1772	.168	.1915	.1772
4		.4201	.3544	.08	.2126	.2382	.2362
5		.5449	.3544	.2477	.3429	.583	.3544
6	.743	.6497	.4725	.3096	.4752	.5573	.483
7	.7678		.6192	.4334	.5114		.4954
8	.756	.9829	.7087	.3544	.4572		.3544
9	.7324	.9063	.9069	.3096			.2477
10		.2008	.2353		.2481		.1181
11		.1181	.2073			.7545	.2362
12	.189	.1181		.6584			.3715
13	.1981	.1181	.1238	.7438			.3715
14	.1654	.1238	.1296	.4512	.1905		.3544
15	.1627	.1858		.5853	.2353		.3715
16		.1772	.1181	.5041			.3715
17		.1772	.1181	.5944	.2244		.3715
18		.2362		.192	.2477		.1238
19					.2477		.2362
20		.2953		.442	.0854	.2477	.2362
21		.2953		.4633	.2362	.2477	.2599
22		.2362	.2477	.2521		.2362	.2362
23	.2195	.189		.1859		.1181	
24	.2953	.3467	.3096		.16	.1181	.1238
Max	.7678	.9829	.9069	.7438	.5114	.7545	.4954
Min	.1627	.1181	.1181	.08	.0854	.1181	.1181
Avg	.4182	.3330	.3486	.3680	.2516	.3002	.2796

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054003 / 33/11 KV. CHOUSALA

Feeder No / Name : 204 / 11 KV. HINGNI FEEDER
Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0945	.2953	.0743	.2477	.1181
2		.1029	.096	.2477	.0697	.2477	.1743
3	.1858	.108	.0945	.2477	.0686	.2477	
4		.1181	.1181	.2362	.0697	.2477	.1086
5		.216	.1772	.2477	.1278	.2953	.2362
6	.2362	.2881	.2008	.2477	.2008	.2953	.2629
7	.2126	.3001	.1715	.2477	.2953		.2724
8	.2353	.2926	.1981	.2126	.3121		.2477
9	.2126	.1772	.2126	.2126	.4068		.2477
10	.2281			.0591	.2763		.1772
11	.415	.1181	.1677			.0743	
12	.4649	.1772	.6036	.0059			
13	.4801	.4334	.3932	.0697			.0945
14	.4649	.4134	.5087		.1524		.0591
15	.4489	.4954	.3688	.0686	.2601		.0619
16	.2362	.4725		.0697			.0619
17	.3467		.2477	.1143	.2362		.1238
18	.093	.0591		.12	.2362		.1238
19	.1772				.1772		.1858
20		.1981			.1772	.1858	.1981
21		.1772		.0945	.1417	.1858	.189
22		.1181	.1115	.1029		.2008	.1772
23	.1012	.1063		.0945		.0945	
24	.1238	.0975	.0945	.0488	.0674	.1772	.1143
Max	.4801	.4954	.6036	.2953	.4068	.2953	.2724
Min	.093	.0591	.0945	.0059	.0674	.0743	.0591
Avg	.2743	.2235	.227	.1522	.1861	.2083	.1617

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054003 / 33/11 KV. CHOUSALA

Feeder No / Name : 205 / 11 KV ANJANWATI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1772	.1238	.12	.1181	.1181
2	.1772	.462	.2953	.1181	.1181	.1181	.1238
3		.4668	.3096	.1772	.12	.1143	.1886
4	.1191	.4715	.2953	.1572	.1162	.1238	.1
5	.3096	.7164		.2229	.2286	.12	.2229
6		.905	.2953	.2229	.281	.1296	.3096
7	.2953	.9335		.2362	.2905		.2477
8	.3887	1.1088		.2362	.2286		
9	.3603	.9945		.1181	.2543		.2477
10	.2521	.1162	.2374	.2953	.4973		.1181
11	.12		.1296	.9145		.6783	.3096
12	.1238		.1578	.9259			.3096
13	.1257	.1181		.9031			.2953
14	.1238	.1181		.5716	.3144		.3096
15	.1334	.1238		.5411			.322
16	.1353	.1238		.5335	.3662		.2953
17	.1858			.7716	.3662		.3096
18	.2143				.1772		.1238
19	.2366			.1315	.1772	.1858	.2477
20				.1829	.2362		.2362
21		.1858		.1772	.1772	.1858	.2362
22		.1772	.1181	.1829		.1238	.2362
23	.1743	.1772		.1238		.1181	
24	.2126	.4572	.1858	.1238	.1162	.1238	.1238
Max	.3887	1.1088	.3096	.9259	.4973	.6783	.322
Min	.1191	.1162	.1181	.1181	.1162	.1143	.1
Avg	.2049	.4503	.2201	.3474	.2325	.1783	.2287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054003 / 33/11 KV. CHOUSALA

Feeder No / Name : 206 / 11 KV Palsingan

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.096	.0945			.1858	.1296
2	.1772	.0914	.0945			.1858	.1238
3		.096	.1181			.1858	.1858
4	.2477	.0945	.1772			.1515	.1858
5		.1417				.2126	.1715
6	.2599	.2073	.1858			.2362	.1829
7	.2362	.189	.1772			.1715	
8	.2641	.1981	.1772		.1658		.1772
9	.2073	.1486		.1858			.1858
10	.2092		.1341	.1772			.1858
11	.096	.1181	.1696	.0093			.1181
12	.0581	.1772	.1677				
13	.1162	.1772	.1696				.0945
14	.1257	.1858	.1677				.0648
15	.1219	.2362		.0581			.0648
16	.0975	.2477					.0619
17	.1362		.1772				.1238
18	.0572	.0867	.1181	.093			.1238
19	.1143	.1772					.1858
20		.1772			.1772	.1858	.1772
21		.1772			.1858	.1858	.1772
22		.1181					.1772
23	.096	.0945				.1181	
24	.1238	.084	.0945			.1238	.1238
Max	.2641	.2477	.1858	.1858	.1858	.2362	.1858
Min	.0572	.084	.0945	.0093	.1658	.1181	.0619
Avg	.1525	.1509	.1482	.1047	.1763	.1766	.1439

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054009 / 33 KV. S/S NATHPUR

Feeder No / Name : 201 / 11KV RANJEGAON

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	24-JUN-17
HR	Load (MW)
11	.6882
Max	.6882
Min	.6882
Avg	.6882

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054009 / 33 KV. S/S NATHPUR

Feeder No / Name : 202 / 11 KV. NATHAPUR

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	24-JUN-17
HR	Load (MW)
11	.1715
Max	.1715
Min	.1715
Avg	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054009 / 33 KV. S/S NATHPUR

Feeder No / Name : 204 / 11 KV. RAMPURI FEEDER
Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	24-JUN-17
HR	Load (MW)
12	.426
Max	.426
Min	.426
Avg	.426

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054009 / 33 KV. S/S NATHPUR

Feeder No / Name : 205 / 11 KV. GUNDA FEEDER

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	24-JUN-17
HR	Load (MW)
11	.2401
Max	.2401
Min	.2401
Avg	.2401

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054016 / 33/11 KV, YALLAMB GHAT

Feeder No / Name : 203 / 11 kv. TANDELWADI

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4						.1105	
5						.0819	
6				.2103		.2934	
7				.2298	.4374	.4633	.3125
8				.3521		.3666	
9				.2599	.3932		.3563
10		.1562					
11			.1738				
16	.4858						
17			.2008				
18	.0492			.0328	.0191		.0381
19	.0526	.0343	.0572		.0381		.0381
20					.0762		.0953
21			.0572				
24		.0492	.0509		.1966	.1086	.1619
Max	.4858	.1562	.2008	.3521	.4374	.4633	.3563
Min	.0492	.0343	.0509	.0328	.0191	.0819	.0381
Avg	.1959	.0799	.1080	.2170	.1934	.2374	.1670

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054016 / 33/11 KV, YALLAMB GHAT

Feeder No / Name : 204 / 11 KV W. BHABHULGAON

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4						.0427	
5						.0503	
6				.0949		.1143	
7				.0705	.1619	.0972	.1802
8				.0903		.1372	
9				.1067	.1619		.1296
10		.1052	.0465				
11			.096				
16	.1875						
17			.0827				
18	.0701			.0732	.0225		.0339
19	.0701	.0554	.0554		.0549		.0362
20					.0747		.0747
21			.0537				
24		.0343	.0526		.0594	.0412	.0514
Max	.1875	.1052	.096	.1067	.1619	.1372	.1802
Min	.0701	.0343	.0465	.0705	.0225	.0412	.0339
Avg	.1092	.0650	.0645	.0871	.0892	.0805	.0843

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054016 / 33/11 KV, YALLAMB GHAT

Feeder No / Name : 205 / 11 KV. CHAKARWADI

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.4268	.703	.4531			
8	.6554	.5937				
9	.6706		.4843			
10					.3506	
11				.3281	.4725	.4268
13						.3658
15				.2858	.5487	
16					.5944	
17				.2858		
24		.3906	.3155			
Max	.6706	.703	.4843	.3281	.5944	.4268
Min	.4268	.3906	.3155	.2858	.3506	.3658
Avg	.5843	.5624	.4176	.2999	.4916	.3963

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054016 / 33/11 KV, YALLAMB GHAT

Feeder No / Name : 208 / 11 KV. KAREGAVAN FEEDER -

Gaothan Feeder

G- Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4						.3001	
5						.5716	
6				.8192		.8002	
7	.7621	.7701	.5344	.7049	.4534	.9526	.6316
8	.7049	.7449		.6287		.5361	
9	.5144		.2947		.3239		.3563
10			.2286				
11			.1715	.2591			.1334
13							.2286
15				.1134			
17				.1781			
18				.2622			
19	.407	.2785	.5144		.4212		
20					.7049		.7621
21			.362				
24		.2267	.1475		.1638		.7621
Max	.7621	.7701	.5344	.8192	.7049	.9526	.7621
Min	.407	.2267	.1475	.1134	.1638	.3001	.1334
Avg	.5971	.5051	.3219	.4237	.4134	.6321	.4790

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054016 / 33/11 KV, YALLAMB GHAT

Feeder No / Name : 209 / 11 KV. YELLAMB GHAT -G- Gaathan Feeder
FEEDER Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4						.5249	
5						.7655	
6				.8962		.8589	
7	1.0456	.7282	.7888	.8962	.8764	.9709	.724
8	.8131	.7011		.8215		.8686	
9	.695		.407	.7468	.5992		.7011
10		.2172			.5175		
11			.3761	.2804	.2865		.3224
12					.2534		
13							.2774
15				.2204	.3155		
16	.2883				.3467		
17			.439	.2883			.3544
18	.4161			.4854	.3814		.4887
19	.407	.5609	.5914		.5792		.6584
20					.7947		.7947
21			.3658				
24		.298	.2254		.3077	.2896	.3052
Max	1.0456	.7282	.7888	.8962	.8764	.9709	.7947
Min	.2883	.2172	.2254	.2204	.2534	.2896	.2774
Avg	.6109	.5011	.4562	.5794	.4780	.7131	.5140

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054016 / 33/11 KV, YALLAMB GHAT

Feeder No / Name : 210 / 11KV NEKN00R -G-FEEDER

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4						.8059	
5						.9313	
6				.9134		1.0029	
7	.9391	.8326	.8326	1.0745	1.3575	1.0208	1.1222
8	.9391	.8688		1.0566		1.0924	
9	1.134		.9231		1.267		1.0679
10		.7964	.8859		.9313		
11			.7796	1.1222	.788		.8596
12					.6447		
13							.6447
14					.6089		
15				.8596	.6089		
16	.9231				.6626		
17			1.0208	1.1403			.6805
18	1.0498			1.0679	.8775		.8238
19	.905	.905	1.0208		1.0745		
20					1.1462		1.1999
21			.9671				
24		.6626	.6516		.905	.7164	1.1999
Max	1.134	.905	1.0208	1.1403	1.3575	1.0924	1.1999
Min	.905	.6626	.6516	.8596	.6089	.7164	.6447
Avg	.9817	.8131	.8852	1.0335	.9060	.9283	.9498

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054036 / 33/11 KV. PIMPALNER S/S

Feeder No / Name : 201 / 11 KV. TADSONA FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4557	.5243	.6401	1.5432	1.5565	
2		.4557	.5243	.6401		1.5927	
3		.4557	.5571	.7042		1.6118	
4		.4557	.5898	.7682		1.7193	
5		.4961	.6554	.8002		1.7718	
6		.4961	.7865	.8322		1.9136	
7	1.3717	.4908	.7537	.9602	1.9719	1.7551	1.7147
8	1.5432	.4557	.7209	.8749	1.7147	1.5402	1.4575
9	1.1736		.6882	.8025	1.3717	1.182	
10	1.2536		.8501	.2572	.8764	1.262	.7621
11			.9145		.8916	1.2003	.743
12			.8871		.6706		.3048
13	1.1706		.924	.8573	.8048	.7716	.6706
14	1.1706		.8871	.9259	.8383	.823	.7926
15	1.0974		.8871		.9945		.7926
16	1.134	.3429	.924		1.1271	.8916	.8124
17	1.2437	.3429	1.0608		1.1736		.9374
18	1.3535		1.2323		.9877	.9431	1.1946
19		1.166	1.4937		1.4632		1.5043
20		1.5775	1.7924	1.8861	1.8099		1.7909
21	.8954	1.5432	1.4784		1.8099	1.4575	1.6118
22	.8596	1.4403			1.6118		1.5402
23	.7164	1.2346	.6443		1.6118		1.5203
24		.5144	.5243			1.5565	1.3717
Max	1.5432	1.5775	1.7924	1.8861	1.9719	1.9136	1.7909
Min	.7164	.3429	.5243	.2572	.6706	.7716	.3048
Avg	1.1526	.7452	.8826	.8422	1.2929	1.3852	1.1483

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054036 / 33/11 KV. PIMPALNER S/S

Feeder No / Name : 202 / 11 KV. GHATSAWALI FEEDER
Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3292	.2229	.3429	.5144	.4458	
2		.3658	.2229	.3772		.4458	
3		.3841	.2401	.4287		.4801	
4		.4382	.3086	.5144		.5144	
5		.543	.4115	.6001		.5487	
6		.6401	.4801	.6516		.5868	
7	.6001	.6838	.4801	.6173	.6859	.8573	.7716
8	.4287	.5487	.583	.5144	.8573	1.0631	1.0288
9	.3658	.4572	.5487	.3772	.7888	1.0867	.9945
10		.7011		.6001	.3292	.2229	.1772
11	.9431				.2195	.1715	.1478
12	1.1145				.2195		.1478
13	.9774		.3563	.6859	.1646	.1357	.1294
14	1.0056		.6802		.1646	.2155	.1294
15	1.0402		.6478		.1848		.1294
16	1.0056		.6316	.3772	.2218	.3258	.1294
17			.5992		.2218		.1478
18	.2896		.3258	.2572	.2772		.2772
19			.3772		.4572		.4024
20	.5068	.583	.4973	.6859	.5487		.5487
21	.3982	.5144	.4287		.439	.5487	.4755
22	.3658	.3429	.3772		.3841		.4024
23	.3292	.2229	.3258		.3292		.3696
24		.3292	.2229			.4458	.4287
Max	1.1145	.7011	.6802	.6859	.8573	1.0867	1.0288
Min	.2896	.2229	.2229	.2572	.1646	.1357	.1294
Avg	.6693	.4722	.4270	.5022	.3893	.5059	.3799

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054036 / 33/11 KV. PIMPALNER S/S

Feeder No / Name : 203 / 11KV GUNDHA NEW FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1663	.1715	.3734	.4287	.3506	
2		.1663	.1715	.4108		.3506	
3		.1848	.1715	.4108		.3506	
4		.2033	.1715	.4481		.3856	
5		.2218	.2058	.5228		.4207	
6		.2587	.3086	.7095		.4908	
7	.4458	.2587	.4458	.5228	.463	.5609	.5144
8	.3086	.2218	.3772	.5041	.4287	.631	.6859
9	.2772			.4668	.3429	.5609	.7202
10	.2804	.3544		.3391	.2218	.2218	.1848
11	.3506		.3403		.1848		.1494
12	.4908		.394				.1494
13	.5258		.2957	.3944		.218	.1478
14	.4908		.3511	.4458	.1494	.2321	.1307
15	.4908		.3511		.1867		.1307
16	.4207		.3511	.3772	.1867	.2058	.1307
17			.2587		.1867		.1307
18	.1478		.2987	.3258	.1867	.2713	.168
19		.2401	.2987		.2772		.2587
20	.2561	.2401	.3361	.6859	.3696		.5914
21	.1829	.2058	.3361		.3696	.6173	.462
22	.1848	.1715	.3361		.3326		.4066
23	.1663	.1715	.3361		.2957		.4066
24		.1663	.1715			.3506	.3429
Max	.5258	.3544	.4458	.7095	.463	.631	.7202
Min	.1478	.1663	.1715	.3258	.1494	.2058	.1307
Avg	.3346	.2154	.2945	.4625	.2882	.3887	.3173

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054053 / 33/11 KV. S/S SHIVNI

Feeder No / Name : 201 / 11 kv Shivni feeder

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1419	.1242	.0998	.1296	.1366	.1419	.1296
2	.1425	.1366	.1277	.1296	.1366	.1414	.1555
3	.1555	.1739	.1425	.1555	.1366	.171	.1814
4	.1696	.1988	.1507	.2073	.1491	.1854	.2332
5	.1722	.2236	.1589	.2332	.1739	.2394	.2591
6	.1987	.2484	.1862	.298	.2484	.3059	.3109
7	.266	.2609	.1827	.285	.2733	.3177	.2721
8	.1995	.2733	.1862	.2202	.2484	.2383	.2332
9	.1862	.2484	.1827		.1566	.2073	.1943
10	.0665	.087	.0907	.1555	.1324	.1036	.1555
11	.0745	.1064	.0777	.1242	.1596	.1555	.1739
12	.0745	.0855	.0777	.1366	.1703	.1555	.1863
13	.0745	.0852	.0777	.1491	.171	.1555	.1739
14	.0745	.0783	.0648	.1242	.1589	.1684	.1491
15	.0745	.0798	.0648	.1118	.1425	.1684	.1617
16	.0745	.0783	.0777	.1242	.1324	.1425	.1493
17	.0994	.1192	.1036	.1242	.1414	.1814	.1493
18	.1242	.1566	.1555	.0994	.0794	.1036	.0995
19		.1958	.2073	.1739	.1044	.2073	.1493
20	.1491	.1986	.2073	.1991	.2394	.2332	.1988
21	.1615	.1979	.1814	.1988	.1838	.1943	.1739
22	.1739	.1703	.1814	.1739	.1596	.1555	.1491
23	.1491	.1457	.1555	.1491	.1463	.1555	.1242
24	.1419	.1242	.099	.1296	.1366	.1419	.1296
Max	.266	.2733	.2073	.298	.2733	.3177	.3109
Min	.0665	.0783	.0648	.0994	.0794	.1036	.0995
Avg	.1367	.1582	.1350	.1666	.1632	.1821	.1789

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054053 / 33/11 KV. S/S SHIVNI

Feeder No / Name : 202 / 11 MOCHI PIMPALGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5148	.5237	.3414	.5182	.5243	.6206	.4534
2	.5841	.5892	.3961	.5182	.491	.6502	.5506
3	.6375	.5892	.4371	.6154	.491	.6863	.583
4	.6842	.6546	.4681	.6478	.491	.7562	.6154
5	.7906	.7856	.5057	.7287	.5237	.7616	.7287
6	.8761	.7856	.5476	.8421	.5237	.8183	.8421
7	1.0221	.851	.5219	.7773	.5237	.6874	.6802
8	.9126	.851	.5475	.583	.5237	.5892	.583
9	.9221	.7201	.491		.5111		.4534
10	.2555	.1964	.2267	.3239	.4371		.3887
11	.2283	.2555		.4566	.7301	.6802	.5892
12	.1957	.2738		.4582	.7666	.7287	.6874
13	.1491	.2574		.4566	.7666	.7287	.6546
14	.1957	.2283		.4893	.7746	.7449	.4582
15	.2128	.2728		.5219	.7666	.6802	.6554
16	.2291	.2619	.2915	.5892	.7673	.6478	.7209
17	.2291	.341	.2915	.5219	.7301	.7287	.7209
18	.2619	.4321	.5182	.2609	.2881	.3239	.3277
19		.5476	.5182	.491	.4614	***	.491
20	.5219	.6481	.583	.5892	.6936	.7287	.6546
21	.6546	.6321	.583	.6546	.6753	.6802	.7201
22	.6546	.5941	.5506	.6546	.6481	.583	.6219
23	.5892	.5487	.5506	.5892	.6206	.4858	.5892
24	.4045	.424	.365	.5182	.5564	.6206	.4534
Max	1.0221	.851	.583	.8421	.7746	40.3074	.8421
Min	.1491	.1964	.2267	.2609	.2881	.3239	.3277
Avg	.5098	.5110	.4597	.5568	.5952	2.4654	.5926

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054053 / 33/11 KV. S/S SHIVNI

Feeder No / Name : 203 / 11 KV Indestrial feeder

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0184	.0182	.018	.0543	.0549	.0182	.0362
2	.0184	.0182	.018	.0543	.0549	.0183	.0181
3	.0183	.0182	.0182	.0543	.0549	.0183	.0181
4	.018	.0182	.0183	.0543	.0549	.0166	.0181
5	.0181	.0182	.018	.0543	.0549	.0166	.0181
6	.0183	.0182	.018	.0543	.0549	.0164	.0181
7	.0184	.0182	.0171	.0362	.0549	.0171	.0181
8	.0183	.0182	.0182	.0543	.0366	.0171	.0181
9	.0183	.0182	.018		.0365		.0181
10	.0184	.0182	.0362	.362	.0364		.0181
11	.0365	.0184	.0181	.0547	.0548	.0362	.0182
12	.0365	.0184	.0362	.0547	.0546	.0362	.0182
13		.0183	.0362	.0547	.0548	.0543	.0182
14		.018	.0362	.0547	.0512	.0543	.0182
15	.0365	.0169	.0362	.0547	.0512	.0543	.0182
16	.0365	.018	.0362	.0547	.0548	.0543	.0182
17	.0182	.018	.0362	.0547	.036	.0543	.0182
18	.0182	.0183	.0362	.0365	.0365	.0362	.0182
19		.0181	.0362	.0366	.0183	.0362	.0182
20		.018	.0362	.0552	.0166	.0362	.0182
21	.0182	.0182	.0543	.0549	.0182	.0362	.0182
22	.0182	.0181	.0543	.0549	.0181	.0362	.0182
23	.0182	.0184	.0543	.0549	.0182	.0362	.0182
24	.0184	.0182	.0181	.0543	.0549	.018	.0362
Max	.0365	.0184	.0543	.362	.0549	.0543	.0362
Min	.018	.0169	.0171	.0362	.0166	.0164	.0181
Avg	.0219	.0181	.0301	.0656	.043	.0326	.0197

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054053 / 33/11 KV. S/S SHIVNI

Feeder No / Name : 204 / 11 kv Borfadi feeder

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5401	.0368	.1142	.3258	.4412	.3414	.3544
2	.5418	.0368	.1144	.362	.4412	.3923	.4252
3	.6375	.0368	.1158	.3982	.5148	.4566	.5316
4	.7673	.0368	.1195	.4706	.5883	.5988	.6201
5	.8897	.0368	.1364	.4706	.5883	.6523	.7087
6	1.1425	.0368	.1366	.6154	.6619	.8023	.7973
7	1.0983	.0368	.0853	.5506	.7538	.7991	1.0099
8	.8194	.0368	.0815	.6104	.8048	.851	.9835
9		.0368	.0815		.6828		.8648
10	.5761	.0368	.0724	.3391	.3414		.3544
11	.5883	.054	.0724	.2942	.2902	.2374	.2942
12	.636	.0682	.0724	.2942		.2543	.2942
13	.6986	.5057	.0724	.2758	.2966	.2543	.239
14		.5115	.0543	.3125	.3414	.3052	.2206
15	.6986	.2481	.0543	.3493	.2936	.3052	.2574
16	.7722		.724	.3677	.2731	.3391	.3125
17	.8825		.724	.3861	.2772	.373	.3677
18	.4596		.6878	.4045	.3109	.407	.4596
19			.724	.5883	.6126	.5935	.7722
20	.6619		.6878	.6619	.8644	.9326	.8089
21		.1468	.0543	.6619		.7442	.7354
22	.0735	.1536	.5792	.6251		.567	.6067
23	.0735	.1318	.5068	.5883	.5219	.5316	.5516
24	.4967	.0552	.1142	.3258	.3677	.2483	.3189
Max	1.1425	.5115	.724	.6619	.8644	.9326	1.0099
Min	.0735	.0368	.0543	.2758	.2731	.2374	.2206
Avg	.6527	.1180	.2577	.4469	.4890	.4994	.5370

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054058 / 33/11 KV. MANJARSUMBA

Feeder No / Name : 204 / 11 kv Karchundi

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0972	.0972
8	.7293			
9	.663			
10	.663			
11			.16	.3315
12		.1943		.2915
13				.2915
14		.1943	.2401	.3239
16		.192		.3315
17		.16	.192	.5801
18				.4973
19		.096	.16	.1658
21		.096	.128	
23		.0972	.096	
Max	.7293	.1943	.2401	.5801
Min	.663	.096	.096	.0972
Avg	.6851	.1471	.1533	.3234

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054058 / 33/11 KV. MANJARSUMBA

Feeder No / Name : 205 / 11 kv Morgaon

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.4096	.4096
4				.5735	.5668
7					.8097
8				.8192	
9				.9012	
10	.583	.3277			
11	.5668				
12	.6478				
13	.6478	.5735			
14	.6478				
16			.1638		.6478
17			.2294	.2458	.7287
18					.4858
19				.3277	
20			.3277		
21			.2458	.3277	
23			.2458	.3277	
Max	.6478	.5735	.3277	.9012	.8097
Min	.5668	.3277	.1638	.2458	.4096
Avg	.6186	.4506	.2425	.4916	.6081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054058 / 33/11 KV. MANJARSUMBA

Feeder No / Name : 206 / 11 kv Manjarsumba gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1829	.181
4				.2172	
7					.2686
8	.362			.2715	.2172
9	.3258			.3224	
10	.2896	.2149			.2172
11	.2715			.2715	.181
12	.181		.181		.181
13	.2172	.2686			.2172
14	.181		.2172	.2149	
16			.181		
17			.2172	.2149	.1448
18					.181
19			.2172	.2686	.181
21			.2715	.2715	
23			.181	.2172	
Max	.362	.2686	.2715	.3224	.2686
Min	.181	.2149	.181	.1829	.1448
Avg	.2612	.2418	.2094	.2453	.197

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054059 / 33/11 KV. S/S/ MHALASJAWALA

Feeder No / Name : 203 / 11KV MHALASJAWALA -G-
FEEDER Feeder KV- 11 /
OUTGOING

Gaothan Feeder

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1107	.1087	.1134	.1334	.1524	.1288	.1103
2	.1134	.1219	.1094	.1334	.1905	.1256	.1289
3	.096	.1216	.1235	.1334	.2477	.1219	.1357
4	.1219	.1463	.1189	.1715	.3048	.1368	.1859
5	.1783	.2054	.1219	.2096	.3048	.1818	.2225
6	.2715	.2487	.1486	.2477	.3239	.3177	.2545
7	.1886	.2445	.1947	.2858	.3239	.2219	.2105
8	.1555	.1733		.2286	.3048	.1655	.2858
9	.2096	.1457	.1166	.1467		.1353	.1715
10	.1524	.1143	.0897	.1235	.1524	.104	.1143
11		.1143	.0729	.1027	.0953	.061	.1143
12	.1524	.1143	.0732	.088	.0953	.0625	.1143
13	.1524	.1334	.0874	.0724	.1143	.0633	.1143
14	.1715	.1334	.0878	.0743	.0953	.0667	.1143
15	.1524		.0866	.0743	.0953	.0657	.1143
16	.1524		.0599	.0743			.1143
17			.1143	.072	.0887	.0754	.1189
18	.1728	.1372	.1524	.0889	.0889	.0648	.1094
19		.1524	.1524	.1331	.1444	.208	.1509
20	.1733	.1635	.2096	.1589	.1733	.1981	.1509
21	.1346	.1372	.2286	.1317	.1433	.1677	.1036
22	.1242	.125	.1524	.0914	.1015		
23	.1171	.1219	.1334	.1011	.105	.1155	.125
24	.0949	.1083	.1134	.1334	.1334	.1078	.1024
Max	.2715	.2487	.2286	.2858	.3239	.3177	.2858
Min	.0949	.1083	.0599	.072	.0887	.061	.1024
Avg	.1522	.1463	.1244	.1338	.1718	.1316	.1464

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054081 / 33/11 KV. RAJURI (N) S/S

Feeder No / Name : 204 / 11KV Rajuri-Gaonthan
Feeder KV- 11 / OUTGOING

Gaonthan Feeder

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.4967						
8	.5847	.4666	.5847			.5719	.7842
11		.2286					
12	.2143						
13						.2107	
15				.2195			
16	.2143	.3018			.2641	.2641	
20						.4999	
Max	.5847	.4666	.5847	.2195	.2641	.5719	.7842
Min	.2143	.2286	.5847	.2195	.2641	.2107	.7842
Avg	.3775	.3323	.5847	.2195	.2641	.3867	.7842

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054103 / 33/11 KV NALWANDI SUB-

STATION

Feeder No / Name : 201 / 11 KV Nalwandi (New)

Single Phasing Feeders

Feeder Feeder KV- 11 /
OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4374		.4428	.4744	.5693		.4131
2	.4999		.4111		.5693	.506	.506
3	.6874		.4111	.5693	.5693	.506	.5693
4	.7499		.4111	.5693	.6325	.5376	.6958
5	.8436		.3795	.6009	.6958	.5376	.759
6	.9374		.3795	.6325	.8223	.5693	.8223
7	1.0623		.3795	.6325	.9488	.5693	.8855
8	1.1248		.4428	.6009	.9488	.506	.6958
9	1.0623		.4428	.5624	.759	.3749	.5693
10	.3749		.3159	.5693	.506	.3795	.4454
11	.3749		.3723	.4428	.5693	.3795	
12	.3749		.3147	.4428		.3163	
13	.3749	.5624	.2833		.3163	.3795	
14	.3749	.4374	.3147	.506	.6009	.4428	.4131
15	.3749		.3163	.4428	.6325	.4428	.4767
16	.4374		.4467	.506	.6325	.5693	.5079
17	.5624	.3749	.6701	.5693	.6325	.4428	.5079
18	.4999	.3749	.6325	.6325	.506	.4428	.3174
19		.4062		.5693	.5693	.4428	.3809
20		.3749	.759	.6325		.6958	.5079
21			.6958	.6958	.6642	.5693	.5713
22		.3437	.7274	.6325	.7274	.5693	.6031
23		.4218	.5693	.6325		.506	.5079
24	.3749		.4531	.4467	.6958	.6325	.4428
Max	1.1248	.5624	.759	.6958	.9488	.6958	.8855
Min	.3749	.3437	.2833	.4428	.3163	.3163	.3174
Avg	.6068	.4120	.4596	.5620	.6461	.4921	.5523

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054103 / 33/11 KV NALWANDI SUB-

STATION

Feeder No / Name : 202 / 11 KV Jarud

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4415		.5359	.5584	.4435	.4805	.4435
2	.5914		.5359		.5175	.4805	.4435
3	.6653		.5914	.5584	.5175	.5175	.5175
4	.6653		.5914	.4467	.5175	.5544	.5175
5	.6653		.6283	.4467	.5914	.6653	.5914
6	.8131		.6283	.4467	.6653	.7392	.6653
7	.8871		.6653	.4467	.6653	.7762	.961
8	.8131		.6653	.3723	.7392	.7762	.8131
9	.6653		.7023	.3696	.5175	.6653	.7392
10	.5175		.2978	.2218	.4435	.3696	.3727
11	.6653		.2978	.2218	.4435	.3696	.3727
12	.6653		.2234	.2218		.3696	.3727
13	.5914		.2234		.3696	.3696	.2981
14	.5175		.1861	.2957	.4435	.2957	.3727
15	.4435		.335	.2957	.4435	.3696	.3354
16	.5175	.5175	.2846	.2957	.4805	.3696	.2981
17	.5175	.5175	.253	.5175	.5175	.4435	.4472
18	.4435	.5175	.0372	.5175	.5175	.5175	.5212
19		.4805	.5956	.5914	.7392	.5914	.5212
20		.4805	.5956	.7392		.8131	.7446
21			.5212	.8871	.8501	.8871	
22		.4435	.5956	.8131	.7762	.8131	.7073
23			.5212	.7392	.7392	.6653	.6701
24	.5914	.4805	.5398	.4428	.4435	.4435	.4467
Max	1.4415	.5175	.7023	.8871	.8501	.8871	.961
Min	.4435	.4435	.0372	.2218	.3696	.2957	.2981
Avg	.6673	.4911	.4605	.4748	.5628	.5560	.5292

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054123 / 33/11KV PIMPALWADI S/Sn

Feeder No / Name : 201 / 11 KV DOKEWADA TALAV

Single Phasing Feeders

FEEDER Feeder KV- 11 /
OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8048	.8413	.6859	.7545	.298	.2883	.3189
2	.8383	.8589	.7202	.7545	.298	.2713	.3189
3	.8886	.8764	.7202	.7545	.3155	.2713	.3544
4	.9614	.8939	.7716	.8048	.3155	.3052	.3721
5	1.0442	.9816	.8573	.8718	.333	.3561	.3898
6	1.094	1.2971	.9774	.9282	.333		.4075
7	1.3272	1.5249	1.3203	1.0395	.3506	.2713	.1417
8	1.5893	1.5424	1.3717	1.0395	.3155	.2543	.2658
9	1.3923	1.5074	1.2003	1.0227	.2103		
10	.1578	.1543	.1677	.1402	1.0852		1.3748
11	.1052	.1402	.1677	.1578	1.4255	1.5775	1.5927
12	.1227	.1052	.1677	.1578	1.5581	1.595	
13	.1227		.1677	.1578	1.5083		1.9281
14	.1227	.1227	.1509	.1578	1.442		1.8275
15	.1227	.1402	.1526	.1578	1.442		1.6933
16		.1402	.1677	.1402	1.2431		1.6095
17				.1402	1.2597	1.5074	1.5257
18	.1753	.1753	.2683	.1753	.2035	.1949	.2012
19	.2804	.2454	.3353	.2454	.2204	.2658	.2347
20	.298	.298	.3353	.3856	.2572	.3544	.3688
21	.3155	.2804	.3185	.3506	.3222	.3898	.3521
22	.298	.2454	.2683	.333	.3222	.3544	.3353
23	.2804	.2103	.2515	.3155	.3222	.3189	.3018
24	.7712	.8063	.6661	.7377	.3155	.2883	.3189
Max	1.5893	1.5424	1.3717	1.0395	1.5581	1.595	1.9281
Min	.1052	.1052	.1509	.1402	.2035	.1949	.1417
Avg	.5960	.6085	.5309	.4884	.6540	.5214	.7379

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054123 / 33/11KV PIMPALWADI S/Sn

Feeder No / Name : 202 / 11 KV BHALWANI FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2652	.1823	.2347	.7625	.763	.7293
2	.2229	.2652	.1823	.218	.779	.8048	.7459
3	.2229	.2652	.1823	.218	.7956	.8619	.7459
4	.2572	.2818	.1989	.2204	.8122	.9282	.7956
5	.2915	.3315	.2321	.2401	.8619	1.1105	.8619
6	.3258	.3647	.2652	.2743	.9779		1.1105
7	.3429	.3647	.2486	.285	1.2431	1.3426	1.4586
8	.2743	.3149		.2515	1.1105	1.4918	1.5249
9	.2743	.2818	.2012	.2515	1.1603		
10	1.5912	1.7269		.9282	.2058		
11	2.0885		.9892	.9945	.1543		
12	2.1051	1.491	1.0227	.9282	.1372	.116	
13	2.1382	1.9725	1.0395	.8951	.1372		.1174
14	2.0388	2.0317	.8383	.8785	.1029		.1174
15	1.9559	1.9334	.8886	.8619	.12		.1174
16		1.9334		.8122	.12		.1174
17				.7956	.1372	.128	.1174
18	.1658	.2486	.2012	.0829	.1715	.1492	.1341
19	.3315	.2515	.2347	.1989	.2229	.1823	.1509
20	.3647	.2683	.2515	.3315	.2743	.2652	.2347
21	.3315	.2515	.2347	.2984	.2743	.2486	.2515
22	.2984	.2155	.2401	.2486	.2743	.2321	.2515
23	.2818	.1989	.2401	.2486	.2401	.2321	.2401
24	.2229	.2652	.1823	.2401	.663	.7373	.7127
Max	2.1382	2.0317	1.0395	.9945	1.2431	1.4918	1.5249
Min	.1658	.1989	.1823	.0829	.1029	.116	.1174
Avg	.7431	.7056	.4028	.4557	.4891	.5996	.5268

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054123 / 33/11KV PIMPALWADI S/Sn

Feeder No / Name : 203 / 11 KV PIMPALWADI

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0526	.0434	.0434	.0343	.0434	.0526	.0434
2	.0526	.0434	.0434	.0351	.0434	.0526	.0434
3	.0526	.0434	.0434	.0351	.0434	.0526	.0434
4	.0701	.0724	.0579	.0347	.0434	.0701	.0579
5	.0876	.0869	.0724	.0526	.0579	.1402	.0724
6	.1402	.1158	.1014	.1029	.0869		.1014
7	.1227	.1303	.1158	.0686	.1158	.1402	.1448
8	.1052	.1014		.1029	.0869	.1227	.1158
9	.0701	.0869	.1014	.1029	.0869		
10	.0579	.0579	.0509	.0579	.0701		.0693
11	.0434	.0434	.0343	.0579	.0526		.0343
12	.0434	.0434	.0347	.0434	.0526	.0434	
13	.0434	.029	.0175	.029	.0351		.052
14	.029	.029	.0177	.029	.0351		
15	.029	.029	.0177	.029	.0351		.0343
16		.0434		.0434	.0351		.0347
17				.0434	.0351	.0579	.0514
18	.0579	.0263	.052	.0724	.0876	.0724	.0867
19	.0869	.0579	.0838	.0724	.1052	.1158	.0686
20	.1014	.0579	.0678	.0869	.1052	.1303	.1029
21	.0724	.0434	.0686	.0579	.0701	.0724	.0867
22	.0579	.0434	.052	.0579	.0526	.0579	.0526
23	.0434	.0434	.0351	.0579	.0526	.0434	.0526
24	.0526	.0434	.0434	.0351	.0434	.0526	.0434
Max	.1402	.1303	.1158	.1029	.1158	.1402	.1448
Min	.029	.0263	.0175	.029	.0351	.0434	.0343
Avg	.0669	.0572	.0550	.0559	.0615	.0798	.0663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054145 / 33/11 KV KUKKADGAON S/Stn

Feeder No / Name : 201 / 11 kv Kukkadgaon

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112		.1638	.213	.2241	.1638	.1638
2	.112		.1638	.213	.2241	.2458	.1966
3	.112		.1638	.2294	.2241	.2458	.1966
4	.128		.1638	.2458	.2561	.2458	.2294
5	.16		.2458	.2949	.3041	.3277	.2622
6	.2881		.1638	.3277	.4481	.3277	.2949
7	.2401		.1638	.3605	.3841	.2458	.3277
8	.2401		.1638	.3277	.3521	.1638	.213
9	.2241	.1638	.1638	.2294	.2721	.1638	.1802
10	.096	.1638	.1638	.0819		.1638	.1638
11	.16	.1638	.1311	.16	.1966	.1475	
12	.192	.1638	.1147	.128	.2294	.1475	.0983
13	.1943	.1638	.1311	.128	.2458		.1147
14	.1966	.1638	.0983	.208	.1638	.1475	.1638
15	.1966	.1638	.1147	.128	.1638	.1475	.1638
16	.2294	.1638	.1475	.128		.1638	.1966
17	.213	.1638	.1638	.16	.1638	.1802	.213
18		.2458	.0983	.208	.2458	.1147	
19		.2458	.1638	.2721	.2458	.1311	
20		.2458	.1966	.3201	.2458	.1638	.3605
21		.2458	.213	.2721	.2785	.1802	
22		.2458	.2294	.2721	.2949	.1966	
23		.1638	.2294	.2401	.2458	.1966	
24	.112		.1638	.2294	.2241	.2458	.1638
Max	.2881	.2458	.2458	.3605	.4481	.3277	.3605
Min	.096	.1638	.0983	.0819	.1638	.1147	.0983
Avg	.1781	.1911	.1631	.2241	.2560	.1938	.2057

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054145 / 33/11 KV KUKKADGAON S/Stn

Feeder No / Name : 202 / 11 kv Wadgaon Gunda Single Phasing Feeders
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17
HR	Load (MW)	Load (MW)
1	.3521	.3521
2	.3521	.3521
3	.3521	.3201
4	.3681	.3521
5	.4001	.3521
6	.5281	.3841
7	.4801	.3841
8	.3681	
9	.3681	
10	.2401	
16	.5121	
18	.3521	
20	.3201	
21	.3521	
22	.4161	
23	.3841	
24	.3521	.3681
Max	.5281	.3841
Min	.2401	.3201
Avg	.3822	.3581

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054145 / 33/11 KV KUKKADGAON S/Stn

Feeder No / Name : 203 / 11 KV Rakshasbhuvan feeder Single Phasing Feeders
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3856	.4359	.2458	.1966	.2347	.2458	.4024
2	.3856	.4024	.2458	.1638	.2347	.2458	.4024
3	.3856	.3688	.2458	.2241	.2347	.2458	.4024
4	.4527	.4694	.3277	.2622	.2515	.3277	.4694
5	.5533	.57	.3277	.2458	.2683	.3277	.4694
6	.7042	.7545	.4915	.2294	.3856	.3277	.503
7	.6203	.7042	.3277	.213	.4359	.4096	.5533
8	.4862	.5868	.3277	.2458	.4191	.4096	.6036
9	.3353	.5868	.2458	.213	.3521	.4096	.4694
10	.218	.1844	.1638	.1638		.1638	.1844
11		.1638	.1966	.1341	.2458	.2012	
12		.1638	.1966	.0671	.213	.2012	
13		.1638	.2294	.218	.1966	.218	
14		.1638	.1966	.2347	.1638	.2012	
15		.2458	.2294	.2347	.1966	.218	
16	.4527	.2458	.1966	.2515	.213	.2515	
17	.4359	.2543	.213	.2515		.2515	
18	.4024	.3277	.2294	.3018	.1638	.3018	
19		.3277	.2458	.3688	.1638	.3353	
20	.5868	.3277	.2458	.503	.1638	.3688	.4096
21	.5533	.3277	.3441	.503	.2458	.4359	
22	.5197	.2458	.3605	.4527	.2458	.4862	
23	.4694	.2458	.3768	.4024	.3277	.4694	
24	.3856	.4359	.2458	.1966	.2347	.2458	.4359
Max	.7042	.7545	.4915	.503	.4359	.4862	.6036
Min	.218	.1638	.1638	.0671	.1638	.1638	.1844
Avg	.4629	.3626	.2690	.2616	.2541	.3041	.4421

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054152 / 33/11 KV SAKSHAL PIMPRI

S/Stn

Feeder No / Name : 203 / Sakshal pimri gavthan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	25-JUN-17
HR	Load (MW)
10	.1896
Max	.1896
Min	.1896
Avg	.1896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054164 / 33/11 KV SHIRAS PARGAON

Feeder No / Name : 201 / 11 Kv Dagdi Shahajanpur

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.1772	
2		.2126	
3		.2126	
4		.1772	
5		.2303	
6		.3189	.3887
7		.3544	.4096
8		.3898	.2915
9			.2286
10			.2031
11		.1619	.1898
12		.1619	
13	.0743		.0286
14	.0743		.0251
15	.0867		.0124
16	.088		.0126
17	.1772		
18	.1753	.0362	
19	.2303	.0724	
23		.2353	
24		.1772	.1943
Max	.2303	.3898	.4096
Min	.0743	.0362	.0124
Avg	.1294	.2084	.1804

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054164 / 33/11 KV SHIRAS PARGAON

Feeder No / Name : 202 / 11 Kv Pargaon AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.0126	
2		.0126	
3		.0126	
4		.0126	
5		.0126	
6		.0126	.0181
7		.0126	.0181
8		.0126	.0181
9			.0133
10			.0133
11		.181	.0135
12		.0177	
13	.0177		.0133
14	.0183		.0229
15	.0181		.0124
16	.0183		.0251
17	.0126	.0162	
18	.0124	.0162	
19	.0126	.0164	
23		.0162	
24		.0126	.0181
Max	.0183	.181	.0251
Min	.0124	.0126	.0124
Avg	.0157	.0251	.0169

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054164 / 33/11 KV SHIRAS PARGAON

Feeder No / Name : 203 / 11 kv Pargaon G

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.1886	.1619
2		.1734	.1457
3		.1387	
4		.1387	
5		.1387	
6		.156	.2105
7		.1734	.2429
8		.1734	.2896
9			.1429
10			.141
11		.181	.1623
12		.1739	
13	.1267		.0987
14	.128		.1257
15	.128		.1509
16	.1829		.1486
17	.1734	.2172	
18	.208	.1629	
19	.2254	.2458	
23		.181	
24		.1715	.1619
Max	.2254	.2458	.2896
Min	.1267	.1387	.0987
Avg	.1675	.1743	.1679

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054012 / 33/11 KV. UMAPUR S/S

Feeder No / Name : 201 / 11 KV. UMAPUR FEEDER
Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024	.3921	.439			.4481	.4207
2	.4572	.4481	.4024	.3921	.462	.4854	.3658
3	.499	.5041	.4163			.5228	.3881
4	.7167	.7095	.5121	.4805	.499	.6348	.5175
5	.9808	1.0082	.6653			.8962	.8029
6	1.2071	1.1949	.924	.9055	.8779	1.1763	1.226
7	1.1506	1.2323	1.1506			1.3443	1.2826
8	1.1506	1.1389	1.1203	1.0059	1.0974	1.2323	1.1949
9	1.0185	1.0456	.924				.8029
10	.7733	.7468	.6653	.695	.5853	.7655	.7095
11	.5228		.6099	.6468		.6468	
12	.439		.5175	.6099	.4854	.5914	.4251
13			.4435	.5914	.4854	.4805	.3881
14	.5228	.5544			.4668	.4572	
15	.5975	.5175		.462	.4481	.439	.4805
16		.5914		.499	.4854	.4435	.5359
17		.6653			.5975	.5975	.5853
18	1.0829	.8029	.8871	.8413	.7095	.8029	.695
19	1.0082				.8589	1.1016	.8962
20	.8962	1.0269	.8779	.9511	.056	.9896	.9511
21	.6722		.6099	.7865	.6722	.7577	.695
22	.5975	.6348		.6767	.5975	.6036	.499
23	.4481	.4938	.462	.5729	.4481	.4938	.4435
24	.4207	.4108	.4572	.4251	.499	.4108	.439
Max	1.2071	1.2323	1.1506	1.0059	1.0974	1.3443	1.2826
Min	.4024	.3921	.4024	.3921	.056	.4108	.3658
Avg	.7411	.7431	.6714	.6589	.5740	.7096	.6702

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054012 / 33/11 KV. UMAPUR S/S

Feeder No / Name : 202 / 11 KV. DEVPIMPRI FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3052	.2683			.1905	.1905
2	.4191	.407	.3856	.156	.2477	.2286	.1905
3	.4694	.4748	.4359		.3429	.3048	.2477
4	.5365	.5765	.5426	.2279	.362	.3429	.3429
5	.6371	.6443	.6783				
6	.7545	.7122	.7291	.5375			
7	.5197	.8139	.763				
8	.4191	.7461	.5935	.5596			
9							.4024
10					.5375	.3561	.4694
11						.3856	
12					.4578	.4191	
13					.4917		.6104
14					.5256	.4475	
15	.1334	.1524			.5087	.4862	.5721
16		.2477	.1143	.1524	.4917	.4862	.6024
17		.3429					
18		.362	.1905	.2477			
19		.381	.2858		.2286	.4001	.4001
20		.4001		.4572	.3048	.381	.4763
21		.2477	.3048	.381	.3239	.3429	.4001
22		.2286		.3239		.3048	.3048
23	.2286	.2286	.2477	.2477	.2477	.2667	.2477
24	.2286	.2286	.2096	.2096	.2096	.2035	.2477
Max	.7545	.8139	.763	.5596	.5375	.4862	.6104
Min	.1334	.1524	.1143	.1524	.2096	.1905	.1905
Avg	.4225	.4166	.4106	.3182	.3772	.3467	.3803

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054012 / 33/11 KV. UMAPUR S/S

Feeder No / Name : 203 / 11 KV. KHALEGAON FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0762	.0572			.0509	.0869
2	.0953	.0762	.0572	.0572	.0274	.0509	.0977
3	.0762	.0762	.0762			.0678	.1195
4	.0762	.0762	.0762	.0762	.0591	.0678	.1437
5	.0762	.1143	.1143			.0848	.1658
6	.0762	.1524	.1334	.0762	.084	.1187	.1989
7	.0762	.1905	.1143			.1696	.1911
8	.0762	.2096	.0572	.0762	.0709	.1696	.1955
9	.0762	.1143	.0762				
10	.0762	.0762		.0572			
15					.0572	.0762	.0572
16					.0572	.0762	.0572
17		.0652			.0572	.1143	
18	.2035	.0869	.0606	.101	.0762	.1524	.0762
19	.1696	.1086			.0762	.2286	
20	.1696	.0977	.072	.1012	.0953	.1905	.1334
21	.1357	.0884	.0591	.084	.1143	.1334	
22	.0848	.076			.0953	.0953	.0953
23	.0509	.076	.0526	.06	.0953	.0953	.0953
24	.0194	.0509	.0652	.0526	.0526	.0953	.0953
Max	.2035	.2096	.1334	.1012	.1143	.2286	.1989
Min	.0194	.0509	.0526	.0526	.0274	.0509	.0572
Avg	.0961	.1007	.0766	.0742	.0727	.1132	.1206

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054012 / 33/11 KV. UMAPUR S/S

Feeder No / Name : 204 / 11 KV. MALEGAON FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762				.0762	.0572
2	.0762	.0762		.0762	.0572	.0762	.0572
3	.0762	.0762				.0762	.0762
4	.0762	.0953		.0762	.0762	.0762	.0762
5						.0762	.0762
6					.0953	.0762	.0953
7						.0381	.0762
8					.0762	.0572	.0572
9		.5765		.4755			.0572
10	.5525	.5256			.0762		.0762
11	.6859	.8029					
12	.6859	.8962	.5418				
13	.5426	1.1694	.3041				
14	.5935						
15	.5765						
16			.4252	.4633			
17					.8139	1.46	.9717
18				.4967	1.0004	1.363	.9179
19	.0762		.1143		.8139	.9335	.8642
20	.0762		.1143	.1143	.7122	.9896	.8368
21	.0762		.0762		.4239	.8131	.8345
22	.0762			.0953	.4409	.7095	.8318
23	.0762		.0762	.0762	.4578	.7095	.8067
24	.0762	.0762		.0762	.0762	.407	.7095
Max	.6859	1.1694	.5418	.4967	1.0004	1.46	.9717
Min	.0762	.0762	.0762	.0762	.0572	.0381	.0572
Avg	.2749	.4371	.2360	.2167	.3939	.4961	.4155

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054035 / 33/11 KV. SIRASMARG S/S

Feeder No / Name : 201 / 11 KV. SIRASMARG FEEDER

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1372			.1296	.1372	.1029	.1543
4	.1372			.1619	.1372	.1372	.1543
6	.1715			.2267	.1715	.2743	.2058
8	.2058			.0972	.2743	.3086	.2572
9					.2134		
10	.0972		.1296	.1029	.1619		.1619
11	.0972		.0972			.1372	
12					.1296	.1372	.0972
13	.081		.081	.1029		.1372	
14				.1029	.0972		.0972
15	.1134		.0648	.1029			
16					.0972		
17			.1619	.1372			
18		.2229		.1372			.1296
19			.2591	.1715		.1715	
20		.2401		.2229	.1943	.2401	.2915
21		.2229	.1457	.1829		.2058	
22		.2058		.1715		.1715	.1296
23				.1543		.1715	
24	.1372			.1296	.1372	.1029	.1543
Max	.2058	.2401	.2591	.2267	.2743	.3086	.2915
Min	.081	.2058	.0648	.0972	.0972	.1029	.0972
Avg	.1309	.2229	.1342	.1459	.1592	.1768	.1666

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054035 / 33/11 KV. SIRASMARG S/S

Feeder No / Name : 202 / 11 KV. UKHADPIMPRI FEEDER Single Phasing Feeders
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.2439			.2591	.1524	.1372	.1219
4	.2439			.2591	.1524	.2591	.1219
6	.3048			.4858	.1677	.3963	.3201
8	.5639			.4534		.3239	.5487
9					.3658		
10	.2267		.2591	.3048	.1619		.1524
11	.421		.3401			.2286	
12				.2134	.1296	.1067	.1219
13	.4534		.2267	.1981		.1067	
14				.1829	.1296		.1094
15	.4696		.2267	.1829			
16					.1296		
17			.1943	.1524			
18				.1372			.1562
19				.2286		.3201	
20		.3048		.4268	.5182	.4572	.502
21		.3048	.3563	.381		.3658	
22		.2439		.3201		.3506	.2915
23				.2743		.3944	
24	.2439			.2591	.1524	.1296	.1219
Max	.5639	.3048	.3563	.4858	.5182	.4572	.5487
Min	.2267	.2439	.1943	.1372	.1296	.1067	.1094
Avg	.3523	.2845	.2672	.2776	.2060	.2751	.2334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054035 / 33/11 KV. SIRASMARG S/S

Feeder No / Name : 203 / 11 KV. SHAJANPIMPRI FEEDER Single Phasing Feeders
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1829				.1524	.0972	.1715
4	.2058				.1715	.1619	.1715
6	.2058				.3086	.2743	.3086
8	.2058				.4287	.3077	.3429
9					.3429		
10	.1943		.1619		.1296		.0065
11	.3125		.1619			.1372	
12					.0972	.1543	.0648
13	.2753					.1543	
14				.1029	.0972		.0648
15	.2267		.2429	.1067			
16					.0972		
17			.2267	.1372			
18		.1715		.1981			.0972
19				.2134		.1524	
20		.2572		.2134	.3018	.2229	.2591
21		.2401		.2229			
22		.2229		.2058		.2058	.2267
23				.1886		.2058	
24	.2058				.1524	.0972	.1524
Max	.3125	.2572	.2429	.2229	.4287	.3077	.3429
Min	.1829	.1715	.1619	.1029	.0972	.0972	.0065
Avg	.2239	.2229	.1984	.1766	.2072	.1809	.1696

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054035 / 33/11 KV. SIRASMARG S/S

Feeder No / Name : 204 / 11 KV. TAKALGAVAN FEEDER Single Phasing Feeders
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1219			.1619	.1372		.1524
4	.1219			.2591	.1372		.1524
6	.1219			.3239	.1524		.2134
8	.1829			.2915	.1829		.2743
9				.2591	.1829		
10	.1619		.1296	.1524	.2591		.3239
11	.1619		.1296			.2134	
12				.1372	.3239	.3353	.4049
13	.1457		.1296			.3048	
14					.421		.3239
15	.1296		.1134				
16					.3887		
17			.1134				
18							.1134
19			.2591	.1829		.2134	
20		.2286		.2134	.2591	.2286	.2915
21		.2134	.2267	.1981		.1981	
22		.1981		.1829		.1829	.2591
23				.1524		.1829	
24	.1219			.1619	.1372		.1524
Max	.1829	.2286	.2591	.3239	.421	.3353	.4049
Min	.1219	.1981	.1134	.1372	.1372	.1829	.1134
Avg	.1411	.2134	.1573	.2059	.2347	.2324	.2420

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054035 / 33/11 KV. SIRASMARG S/S

Feeder No / Name : 205 / 11 KV TARTEWADI FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1029			.0972	.0857	.1029	.1029
4	.1029			.0972	.0857	.1086	.1029
6	.1715			.1619	.2058	.2401	.1715
8	.4458			.2105	.2743	.2267	.2286
9					.2286		
10	.0972		.0972	.0914	.1619		.2591
11	.0972		.0972			.2401	
12					.1943	.2286	.3725
13	.0972					.2058	
14				.1029	.1943		.3239
15	.0972		.0972	.0914			
16					.2105		
17			.1134	.0762			
18		.0857		.0914			.0972
19			.1619	.1067		.1067	
20		.1372		.1372	.1781	.1219	.1943
21		.12	.1296	.12		.1029	
22		.1029		.1067		.1029	.0972
23				.1029		.1029	.0972
24	.1029			.0972	.0857	.1029	.0914
Max	.4458	.1372	.1619	.2105	.2743	.2401	.3725
Min	.0972	.0857	.0972	.0762	.0857	.1029	.0914
Avg	.1461	.1115	.1161	.1127	.1732	.1533	.1782

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054035 / 33/11 KV. SIRASMARG S/S

Feeder No / Name : 206 / 11 KV. TANDALWADI FEEDER Single Phasing Feeders
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.0686			.0648	.0514	.0648	.0514
4	.1029			.0972	.0514	.0972	.0686
6	.463			.1619	.0857	.1296	.0762
8	.4801			.2591	.1029	.1296	.1029
9					.0857		
10	.0648		.0671	.0857			.1619
11	.0648		.0648		.1619	.1715	
12					.1943	.1715	.2591
13	.0648					.1715	
14				.0514	.25		.2267
15	.0648		.0648	.0514			
16					.2753		
17			.081	.0514			
18		.0686		.0686			.0648
19			.0972	.0914		.0914	
20		.1029		.1067	.0972	.1029	.0972
21		.1029	.0972	.1029		.0686	
22		.0686		.0857		.0686	.0648
23				.0514		.0686	
24	.0686			.0648	.0514	.0655	.0514
Max	.4801	.1029	.0972	.2591	.2753	.1715	.2591
Min	.0648	.0686	.0648	.0514	.0514	.0648	.0514
Avg	.1603	.0858	.0787	.0930	.1279	.1078	.1114

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054085 / 33/11KV DHONDRAI S/S

Feeder No / Name : 201 / 11KV RAJPIMPRI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.362	.5228	.4527	.4298	.3658	.5228
2	.4481	.394	.4854	.4854	.4656	.362	.5068
3	.439	.4481	.5228	.4854	.4607	.4435	.5281
4	.4435	.3696	.5175	.5175			.5175
5	.439	.5121	.5121	.5281			
6	.5792	.567	.5487	.5601			
7	.6584	.5792	.5914	.5544			
8		.5014	.5853	.5121		.1463	
9					.2865	.2195	.5175
10					.2172	.2957	.5121
11					.1448	.3189	.4801
12					.1463	.394	.4458
13					.1494	.439	.3814
14					.2195	.439	.3155
15		.2481	.2103	.2149		.5175	.2804
16		.2865	.2454	.2126	.2896	.4805	.2774
17		.3224	.2957	.362			
18	.2126	.3544	.3174	.3544	.1463		
19	.3856	.394	.2614	.2865	.2926	.439	.679
20	.4252	.4481	.2957	.3582	.5792	.4435	.6413
21	.4607	.4435	.3326	.4961	.5853	.5014	.5658
22	.4706	.4805	.3326	.4961	.5121	.5014	.5281
23	.3856	.4755	.415	.4557	.4344	.5121	.4904
24	.3734	.3544	.5121	.5281	.4207	.3658	.5175
Max	.6584	.5792	.5914	.5601	.5853	.5175	.679
Min	.2126	.2481	.2103	.2126	.1448	.1463	.2774
Avg	.4353	.4189	.4169	.4367	.34	.3992	.4838

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054085 / 33/11KV DHONDRAI S/S

Feeder No / Name : 202 / 11KV DHONDRAI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8962	.8688	.5975	.6413	.8954	.8779	.5228
2	1.0456	.8954	.5601	.5975	.8413	.8688	.5975
3	1.0242	1.0082	.5975	.5975	.8328	1.0349	.6413
4		1.1458	.5914	.6283	.8859	1.0136	.6283
5		1.2437	.6219	.6413	1.0029	1.1706	.6584
6					1.1218	1.1584	.6653
7					1.0277	.9511	.6722
8	.5853				.9114	.9511	.679
9	.7087	.815	.7964		.7164	.6584	.5914
10	.8505	.7164	.8413			.5914	.6219
11	.9313	.7602	.9465	.724			
12	.8505	.7522	1.0288	.8596			
13	.8238	.7796	1.0402	.8505			
14	.7964	.8596	.9709	.8688			
15	.7522	.8505	.8669	.9313			
16			.7087	.8859	.2926		
17					.8048	.8413	.905
18					.7316	.8688	1.1203
19		.3224			.8779	.8048	1.1203
20	1.0631	.4854	.5914	1.0745	.8688	.8871	1.094
21	1.0517	.5914	.6283	1.1104	.8779	.8688	1.0562
22	1.0136	.6283	.6283	1.0166	.8048	.8238	1.0185
23	.9465	.6219	.679	.9816	.6516	.8413	.9431
24	.8962	.8505		.679	.8764	.6584	.7762
Max	1.0631	1.2437	1.0402	1.1104	1.1218	1.1706	1.1203
Min	.5853	.3224	.5601	.5975	.2926	.5914	.5228
Avg	.8897	.7886	.7468	.8180	.8346	.8817	.7951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054085 / 33/11KV DHONDRAI S/S

Feeder No / Name : 204 / 11 KV MAHALAXMI INDESTRIAL SHEDDABLE FEEDER HAVING WEEKLY
FEE Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.362	.5121	.0754	.1433	.1097	.112
2	.1494	.3582	.5975	.112	.1578	.1086	.112
3	.1463	.3921	.6348	.112	.1595	.1109	.1132
4	.1478	.3696	.6653	.1109	.1417	.1086	.1109
5	.1463	.3658	.695	.1132	.1254	.1463	.0732
6	.1448	.3544	.4024	.112	.1402	.1448	.1109
7	.1463	.362	.3696	.1109	.1772	.1463	.112
8	.1463	.1433	.2926	.1097	.1402	.1463	.1509
9	.1448	.1417	.1052	.0747	.1254	.2561	.1097
10	.1063	.1433	.0732	.3395	.1448	.3326	.1097
11	.1433	.1086		.181	.1448	.4961	.1063
12	.1063	.2149	.2743	.1433	.1463	.4961	.1402
13	.2149	.2481	.2454	.124	.1494	.5731	.1387
14	.2896	.2507	.2601	.1448	.1463	.6219	.1433
15	.3189	.3189	.2835	.1612		.6283	.1387
16		.3582	.3189	.2481	.1463	.6283	.1433
17		.3582	.3326	.362	.1463	.6219	.1448
18	.2804	.3189	.3206	.2126	.1097	.6516	.1494
19	.1753	.3224	.2614	.3155	.1463	.6219	.1509
20	.3189	.4108	.1109	.1612	.1448	.1448	.1509
21	.3506	.4435	.3326	.1612	.1463	.1075	.1509
22	.362	.4435	.0739	.1063	.1463	.1097	.1509
23	.3856	.439	.0754	.1052	.1086	.1097	.1509
24	.1494	.362	.4755	.0754	.1227	.1463	.1109
Max	.3856	.4435	.695	.362	.1772	.6516	.1509
Min	.1063	.1086	.0732	.0747	.1086	.1075	.0732
Avg	.2056	.3163	.3353	.1572	.1417	.3153	.1285

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054150 / 33/11 KV Jategaon S/Stn

Feeder No / Name : 201 / 11 KV JATEGAON FEEDER
Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	22-JUN-17	23-JUN-17	24-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
3			.7461
4	.9362		
6			.9389
7	.9602		1.0056
9			1.0174
10	.6447		
13		.4681	
24	.7362		.583
Max	.9602	.4681	1.0174
Min	.6447	.4681	.583
Avg	.8193	.4681	.8582

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054150 / 33/11 KV Jategaon S/Stn

Feeder No / Name : 202 / 11 KV MARPHALA FEEDER
Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	22-JUN-17	23-JUN-17	24-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
3			.5201
4	.6613		
7	.7373		.6241
9			.9362
10	.5895		
12		.2601	
13		.2774	
24	.2743		.4458
Max	.7373	.2774	.9362
Min	.2743	.2601	.4458
Avg	.5656	.2688	.6316

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054150 / 33/11 KV Jategaon S/Stn

Feeder No / Name : 203 / 11 KV BHEND TAKALI FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
3			.3277
4	.5304		
6			.4161
7	.7865		.4508
9			.6274
10	.6783		
12		.2713	
13		.3399	
24	.3222		.3052
Max	.7865	.3399	.6274
Min	.3222	.2713	.3052
Avg	.5794	.3056	.4254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054008 / 33/11 KV. PATODA S/S

Feeder No / Name : 201 / 11 KV. PATODA FEEDER
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		1.7337	1.5249	1.4022	1.7147	1.4899	1.5257
7	1.7661		1.6804		1.9204		1.8347
8	1.6632	1.4175	1.6804	1.6126	2.0119	1.7878	1.7661
9	1.4548	1.3672	1.5089	1.5947	1.6632	1.5432	1.6289
10	1.2269	1.3146	1.262			1.3146	
11	1.2269	1.2048		1.3672	1.0288	1.1744	1.0402
12						1.0277	
13		1.0277	1.0631	1.2269	.8916	1.0099	.8916
14		1.0099	1.0056	1.0867	.964	.9745	.7802
15	.9536	.9214	.964	1.0631	.9114	.8859	
16	1.1568	1.0985		1.1163		.8859	.8916
17		1.2269		1.1919	.964	1.0099	
18	1.4217	1.262	1.2003	1.262	1.1393	1.0631	
19	1.4022	1.262	1.2346	1.2269		1.2795	
20		1.406		1.335		1.4563	1.387
21			1.1393	1.2269	1.2003	1.3146	
22		1.0867		1.0867			
24	.8859		.8859		.8859		.7973
Max	1.7661	1.7337	1.6804	1.6126	2.0119	1.7878	1.8347
Min	.8859	.9214	.8859	1.0631	.8859	.8859	.7802
Avg	1.3158	1.2385	1.2625	1.2714	1.2746	1.2145	1.2543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054008 / 33/11 KV. PATODA S/S

Feeder No / Name : 203 / 11 KV. MAJARSUMBHA FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		1.262	1.3146	1.1096			
7	1.0631		1.2445				
8	1.0454	1.1919	1.1517				
9		.9774	.9214		1.3717		
10		1.0166	.7796			.8505	
11	.7108	.7265			.8413		.6661
12						.7087	
13		.5847	.4854	.6379	.6241	.6556	.4115
14		.443	.4334	.443	.5784	.5493	.5548
15	.6241	.6024	.4287	.567	.5548	.443	
16	.583			.7973		.4961	.5548
17		.5493		.8505	.5487	.567	
18	.9709	.8505	1.0517	1.0099	.7442	1.0808	
19	1.387	1.1517	1.3717			1.2971	
20		1.4043				1.5604	1.7528
21			1.2795		1.3146	1.335	
22		1.1043					
24	.5847		.7265		.6024		1.0099
Max	1.387	1.4043	1.3717	1.1096	1.3717	1.5604	1.7528
Min	.583	.443	.4287	.443	.5487	.443	.4115
Avg	.8711	.9127	.9324	.7736	.7978	.8676	.8250

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054008 / 33/11 KV. PATODA S/S

Feeder No / Name : 204 / 11 KV. TALE PIMPALGAON

Single Phasing Feeders

FEEDER Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6				1.2445	.8859	.8764	.6024
7	1.262				.8859		.4961
8					.8505	.7712	.4961
9	1.2048				.6201	.5316	.4961
10	.6201	.7011	.567			.3944	
11	.631	.5138		.4252	.4115	.2835	.3467
12						.2835	
13		.4252	.5487	.5316	.2601	.2507	.2279
14		.3544	.4287	.4784	.333	.2835	
15	.208	.4252	.4557	.3544	.2915	.2865	
16	.3155			.4252		.2865	.2804
17		.4961		.5138	.4115	.4252	
18	.5548	.567	.8149	.567	.6001	.4607	
19	1.0402	.815	.9602	.8505		.9391	
20		1.2269		1.1568		1.1218	.8495
21			.7712	.8505	.7545	.7796	
22		.7973		.7265			
24	.6379		.6556		.4252		.4607
Max	1.262	1.2269	.9602	1.2445	.8859	1.1218	.8495
Min	.208	.3544	.4287	.3544	.2601	.2507	.2279
Avg	.7194	.6322	.6503	.6770	.5608	.5316	.4729

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054008 / 33/11 KV. PATODA S/S

Feeder No / Name : 205 / Rural Hospital Patoda

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.0857	.0185	.0857	.0185	.0857	.0185
7	.0185		.0185		.0185		.0187
8	.0187	.0857	.0185	.0857	.0185	.0867	.0187
9	.0185	.0857	.0187	.0857	.0185	.0867	.0187
10	.0185	.0876	.0187			.0857	
11	.0857	.0187		.0187	.0867	.0187	.0857
12						.0187	
13		.0187	.0867	.0187	.0857	.0187	.0857
14		.0189	.4287	.0187	.0867	.0187	.0867
15	.0867	.0187	.0857	.0187	.0857	.0189	
16	.0876	.0187		.0187		.0187	.0867
17		.0187		.0187	.0876	.0187	
18	.0867	.0185	.0857	.0185	.0857	.0187	
19	.0867	.0185	.0867	.0185		.0187	
20		.0183		.0185		.0187	.0867
21			.0857	.0185	.0857	.0187	
22		.0185		.0185			
24	.0183		.0187		.0187		.0187
Max	.0876	.0876	.4287	.0857	.0876	.0867	.0867
Min	.0183	.0183	.0185	.0185	.0185	.0187	.0185
Avg	.0526	.0379	.0809	.0330	.0580	.0367	.0525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054008 / 33/11 KV. PATODA S/S

Feeder No / Name : 206 / MAHASANGVI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6			.6379	.5658	.3045	.3988	.443
7	.443		.4961		.3721		.5138
8	.443		.3224		.3721	.4854	.443
9	.3366		.2686		.3366	.4161	.4252
10	.2507	.3294	.2686			.2401	
11	.2743	.3898			.1734		.2103
12						.1629	
13		.3544	.3294	.2686	.1402	.1086	.1402
14		.3721	.3429	.2686	.1214	.1448	.1214
15	.2774	.3366	.2915	.2865	.1387	.1612	
16	.2774			.2686		.1448	.1372
17		.2658		.1267	.1543	.1629	
18	.208	.2865	.2229	.181	.1715	.197	
19	.3467	.3366	.3601	.2328		.3403	
20		.4961				.443	.5144
21			.3856	.443	.3944	.3898	
22		.3898		.3544			
24	.2865		.3045		.1791		.2328
Max	.443	.4961	.6379	.5658	.3944	.4854	.5144
Min	.208	.2658	.2229	.1267	.1214	.1086	.1214
Avg	.3144	.3557	.3525	.2996	.2382	.2711	.3181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054044 / 33/11 KV. KUSLAMB S/S

Feeder No / Name : 201 / 11 KV. KUSLAMB FEEDER
Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	27-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.7545	.6859		.8573	.5658
17		.6859			
21			.463		
24					.4287
Max	.7545	.6859	.463	.8573	.5658
Min	.7545	.6859	.463	.8573	.4287
Avg	.7545	.6859	.463	.8573	.4973

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054044 / 33/11 KV. KUSLAMB S/S

Feeder No / Name : 202 / 11 KV. SAUTADA FEEDER
Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.5658	.5144	.6001	.6859	.3429	.463	
9							.3944
17		.2572					
21			.6173				
24						.2572	
Max	.5658	.5144	.6173	.6859	.3429	.463	.3944
Min	.5658	.2572	.6001	.6859	.3429	.2572	.3944
Avg	.5658	.3858	.6087	.6859	.3429	.3601	.3944

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054044 / 33/11 KV. KUSLAMB S/S

Feeder No / Name : 203 / 11 KV. SUPPA FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.1886	.2058	.1543	.1372	.12	.2058	
9							.1372
17		.0514					
21			.1543				
24						.0857	
Max	.1886	.2058	.1543	.1372	.12	.2058	.1372
Min	.1886	.0514	.1543	.1372	.12	.0857	.1372
Avg	.1886	.1286	.1543	.1372	.12	.1458	.1372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416]

BU 2526

Substation No/ Name :- 054057 / 33/11 KV ROHATWADI

Feeder No / Name : 201 / 11 KV NAIGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3429	.3601	.3772	.2286	.2286	.1829
2	.4115	.3429	.3258	.4458	.2286	.2286	.1829
3	.4801	.4115	.4458	.5487	.2286	.2743	.1829
4	.6173	.6859	.6859	.7202	.2286	.3353	.1829
5	.823	.9602	.9431	.9259		.4268	.4268
6					.4877	.7316	.6097
7					.6097	.4877	.6097
8					.5487	.7316	.6097
9					.4877	.4877	.5792
10	.4268	.1829	.3048				
11	.3963	.3048	.3353	.3963			
12	.3048	.4268		.4268			
13	.2743	.3963	.3048	.3963			
14	.3048	.3658	.1981	.3658			
15	.2743		.2286	.2439			
16			.3048	.3048	.4115	.2743	.1715
17	.3048	.3048			.4458	.4115	.5144
18		.5144		.5144	.5144	.5487	.703
19		.6859	.6859	.6859	.8745	.8916	.823
20		.6859	.8916	.9945	.9602	.9945	1.0631
21	.7202	.4801	.823	.6859	.6859	.6516	.6516
22	.4973	.5144	.5487	.5487		.5487	.3772
23	.4115	.4115	.4115	.4458	.4458	.4458	.3429
24	.3429	.3601	.3772	.4115	.2286	.2134	.2134
Max	.823	.9602	.9431	.9945	.9602	.9945	1.0631
Min	.2743	.1829	.1981	.2439	.2286	.2134	.1715
Avg	.4354	.4654	.4809	.5244	.4759	.4951	.4682

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054057 / 33/11 KV ROHATWADI

Feeder No / Name : 202 / 11 KV ROHATWADI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3353	.2439		.6173	.6001	.583
2	.3353	.3658	.2743		.6173	.6516	.583
3	.3658	.3963	.3048		.6516	.6859	.6516
4	.3963	.4268	.3658		.6859	.8573	.7888
5	.4877	.5335	.4572		1.0288	1.0802	1.0288
6	.6097	.7316	.6401				
7	.6706	.9145	.5335				
8	.6097	.7926	.5487				
9	.5487	.7316	.4572				
10					.3658	.4115	
11					.4572	.3963	.4268
12					.4268		.3658
13					.4572	.3658	.3353
14					.4268	.3658	.3353
15					.3963	.3353	.3353
16	.4801	.3429	.4115	.3429	.3353	.3658	.4115
17	.5144				.3658	.3658	.3658
18	.6859			.6173	.6001	.4801	.6859
19	1.0288	.4801	.6173	1.0974	.9602	.8573	.9602
20	1.2174	.5144	1.2689	1.3375	1.0974	1.0974	1.2346
21	.9945	.3772	1.0974	1.1145	.823	.8573	.9602
22	.7202	.3772	.8916	.8916		.7202	.7888
23	.6859	.3429	.6859	.6859	.6516	.6173	.6516
24	.3048	.3048	.2286	.2743	.6516	.5487	.583
Max	1.2174	.9145	1.2689	1.3375	1.0974	1.0974	1.2346
Min	.3048	.3048	.2286	.2743	.3353	.3353	.3353
Avg	.6089	.4980	.5642	.7952	.6114	.6137	.6355

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054057 / 33/11 KV ROHATWADI

Feeder No / Name : 203 / 11 KV DOMRI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3086	.3429	.3086	.2572	.1829	.1829
2	.2743	.3258	.3429	.3086	.2286	.1829	.1829
3	.2743	.4115	.4287	.4115	.2286	.2134	.2401
4	.5144	.583	.583	.6001	.2439	.2439	
5	.823	.823	.703	.823	.3048	.2591	.4268
6					.4801	.4877	.6097
7					.5487	.5792	.7316
8					.5487	.5792	.7926
9					.5487	.5792	.6097
10	.2439	.2743	.2743				
11	.3048	.3353	.3048	.3963			
12	.2134	.3658	.3048	.3963		.3658	
13	.2439	.3963	.3353	.3353			
14	.2439	.3658	.2134				
15	.2286	.3658	.3353	.2439			
16	.2439	.2439	.3353	.2439	.2401	.2401	.1715
17	.2743	.2286	.2286		.3086	.3086	.2058
18	.2743	.3429	.4458	.3086	.3601	.3772	.3772
19	.4801	.4801	.6859	.4115	.583	.4801	.4801
20	.7888	.7545	.7716	.6001	.7888	.823	.9259
21	.5487	.5487	.6173	.6173	.5144	.4801	.5144
22	.4458	.3944	.4115	.4458			.3429
23	.3429	.3429	.3772	.3429	.2915	.3429	.3429
24	.3429	.3086	.3258	.3258	.2286	.1829	.2058
Max	.823	.823	.7716	.823	.7888	.823	.9259
Min	.2134	.2286	.2134	.2439	.2286	.1829	.1715
Avg	.3707	.4100	.4184	.4188	.3944	.3838	.4319

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054069 / 33/11 KV. DONGARKINNI S/S

Feeder No / Name : 201 / 11 KV. NALWANDI FEEDER

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	28-JUN-17
HR	Load (MW)
1	.3734
10	.2241
18	.1867
Max	.3734
Min	.1867
Avg	.2614

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054069 / 33/11 KV. DONGARKINNI S/S

Feeder No / Name : 202 / 11 KV. DONGARKINHI FEEDER

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	28-JUN-17
HR	Load (MW)
1	.4668
10	.0934
18	.0566
Max	.4668
Min	.0566
Avg	.2056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054069 / 33/11 KV. DONGARKINNI S/S

Feeder No / Name : 203 / 11 KV. JATNANDUR FEEDER

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	28-JUN-17
HR	Load (MW)
1	.1867
10	.3467
Max	.3467
Min	.1867
Avg	.2667

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416]

BU 2526

Substation No/ Name :- 054096 / 33/11 KV. DASKHED S/S

Feeder No / Name : 201 / 11 KV. DASKHED FEEDER

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0399	.0221	.0463	.0376	.009	.0179	.0114
2	.0399	.0225	.0463	.0386		.0179	.0114
3	.0399	.0232	.0579	.0386	.0093	.0179	.0114
4	.0399	.024	.0579	.0386	.0093	.0179	.0114
5	.0399	.0366	.0927	.0376	.0093	.0179	.0114
6	.0532	.0556	.1622	.0514	.0093	.0179	.0114
7	.0665	.0619	.139	.0514	.0093	.0179	.0114
8	.0553	.0591	.1158	.0772	.009	.0179	.0114
9	.0663	.0469	.1043	.0772	.009		.0114
10	.0179	.0094	.0116	.0114	.0179		.0229
11	.0179	.0094	.0186	.0114	.0381	.0229	.0229
12	.0179	.0094	.0186	.0114	.0366	.0229	.024
13	.0179	.0094	.0186	.0114	.0328	.0229	.0354
14	.0179	.0094	.0186	.0095	.0257	.0229	.0171
15	.0179	.0094	.0186	.0112	.0419		.0229
16	.0179	.0094	.0186	.0112	.0381	.0229	.0225
17	.0179	.0094	.0186	.0101	.0351	.0457	.0257
18	.0179	.0094	.0186	.0112	.0177	.0114	.0114
19	.0179	.0094	.0186	.0112		.0114	.0107
20	.0179	.0094	.0186	.0112		.0114	.0114
21	.0179	.0094	.0186	.0112		.0114	.0114
22	.0179	.0094	.0186	.0112		.0114	.0114
23	.0179	.0094	.0186	.0112	.0179	.0114	
24	.0399	.0232	.0462	.0348	.0112	.0179	.0114
Max	.0665	.0619	.1622	.0772	.0419	.0457	.0354
Min	.0179	.0094	.0116	.0095	.009	.0114	.0107
Avg	.0305	.0211	.0468	.0266	.0203	.0186	.0158

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054096 / 33/11 KV. DASKHED S/S

Feeder No / Name : 203 / Pachangri Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.076	.0827
2					.076	.0945
3					.076	.1181
4					.0869	.1417
5					.0977	.1181
6					.0977	.0827
7					.1086	.1063
8					.1086	.1181
9				.1086		.1181
10	.1086	.1235	.072			
11	.1086	.1543	.1029			
12	.1195	.1337	.1235			
13	.1086	.1646	.1543			
14	.1086	.1646	.1629			
15	.0869	.1235	.1308			
16		.1337	.1269			
17	.1195	.0823	.1057			
24					.0869	.0514
Max	.1195	.1646	.1629	.1086	.1086	.1417
Min	.0869	.0823	.072	.1086	.076	.0514
Avg	.1086	.1350	.1224	.1086	.0905	.1032

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054096 / 33/11 KV. DASKHED S/S

Feeder No / Name : 204 / Pachangri Gav

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1095	.0905	.0911	.0911	.0905	.1075	.112
2	.1095	.0905	.0911	.0911	.0905	.1075	.112
3	.1095	.0905	.1093	.1093	.1086	.1075	.1307
4	.1095	.1267	.1275	.1457	.1448	.1254	.1867
5	.146	.3155	.1457	.2186	.2172	.1791	.2241
6	.1825	.4525	.1821	.3278	.3077	.3582	.3734
7	.219	.362	.1821	.3643	.362	.3224	.3174
8	.3715	.3258	.1821	.3643	.3077	.2507	.2614
9	.1858	.2188	.1457	.2186	.1448		.2241
10	.1075	.1276		.1448	.1086		.112
11	.0716		.0911	.1086	.0895		.0543
12	.0724		.0729	.0724	.0895	.0724	
13	.0724		.0729		.0716		.0362
14	.0724	.1094	.0729	.0543		.0724	.1629
15	.0724	.1094	.1093	.0457	.0716		.0543
16	.0362	.1276	.1093	.061	.0362	.0905	.0543
17	.0724	.1094	.1093		.0895	.0905	.056
18	.1267	.1094	.1093	.1494	.1254	.181	.1267
19		.1823	.1457	.181		.2172	.1448
20		.237	.1457	.2353		.1629	.3077
21		.1276	.1093	.1012		.1267	.2241
22		.0912	.1093	.1086		.1086	.0743
23	.1086	.0729	.0911	.1448	.1075	.1086	.1086
24	.1095	.0905	.0729	.0911	.0762	.1075	.1086
Max	.3715	.4525	.1821	.3643	.362	.3582	.3734
Min	.0362	.0729	.0729	.0457	.0362	.0724	.0362
Avg	.1232	.1699	.1164	.1559	.1389	.1525	.1551

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054096 / 33/11 KV. DASKHED S/S

Feeder No / Name : 205 / Vaidyakini Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.138	.1524	.1991	.1994			
2	.138	.1524	.2298	.1994			
3	.138	.1524	.2298	.2301			
4	.1534	.1524	.2604	.2761			
5	.184	.1677	.291	.3067			
6	.2147	.1829		.4141			
7	.2147	.2286		.4908			
8	.2298	.2286		.4908			
9	.2298	.1539		.5061			
10					.3258		.2591
11					.3963		.2743
12					.3658	.3201	.3353
13					.2286		.3353
14					.2743	.442	.2743
15					.2896	.4268	.2896
16		.3079				.2286	.3048
17			.4141		.2896	.2591	.3439
24	.138	.1524	.1838	.1994			
Max	.2298	.3079	.4141	.5061	.3963	.442	.3439
Min	.138	.1524	.1838	.1994	.2286	.2286	.2591
Avg	.1778	.1847	.2583	.3313	.31	.3353	.3021

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416]

BU 2526

Substation No/ Name :- 054096 / 33/11 KV. DASKHED S/S

Feeder No / Name : 206 / Vaidyakini Gav

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0728	.0543	.0761	.0182	.0179	.0181	.0166
2	.0728	.0543	.0761	.0182	.0181	.0181	.0166
3	.0728	.0543	.0761	.0182	.0181	.0181	.0166
4	.0728	.0362	.0951	.0182	.0179	.0181	.0166
5	.091	.0181	.0951	.0182	.0181	.0181	.0166
6	.1092	.0181	.1141	.0182	.0181	.0181	.0166
7	.0546	.0181	.0951	.0182	.0181	.0181	.0166
8	.0729	.1086	.057	.0182	.0181	.0181	.0166
9	.0728	.0182	.038	.0182	.0179		.0166
10	.0543	.0364	.038	.0181	.0181		
11	.0181	.0364	.038	.0181	.0181	.0189	
12	.0181	.0364	.0364	.0181	.0181	.0189	
13	.0181	.0546	.0364	.0189	.0181	.0189	
14	.0724	.0729		.0189	.0181	.0189	.0179
15	.0181	.0546		.0179	.0181	.0189	.0168
16	.0362	.0546	.0364	.0179		.0189	.017
17		.0364	.0364		.0181	.0189	.0181
18	.0181	.1275	.0182		.0181	.0189	.0181
19		.1093	.0182	.0362		.0189	.0179
20		.0911	.0182	.0362		.0189	.0181
21		.0729	.0182	.0181		.0189	.0181
22		.0911	.0182	.0179		.0189	.0181
23	.0543	.0911	.0182	.0181	.0181	.0189	.0181
24	.0728	.0543	.0761	.0182	.0181	.0181	.0189
Max	.1092	.1275	.1141	.0362	.0181	.0189	.0189
Min	.0181	.0181	.0182	.0179	.0179	.0181	.0166
Avg	.0564	.0583	.0513	.0198	.0181	.0186	.0173

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054013 / 33 KV RAIMOHA

Feeder No / Name : 201 / 11 KV AMALNER

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	22-JUN-17
HR	Load (MW)
10	.2229
11	.1783
Max	.2229
Min	.1783
Avg	.2006

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054013 / 33 KV RAIMOHA

Feeder No / Name : 202 / SHIRUR AG

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	22-JUN-17
HR	Load (MW)
10	.0351
Max	.0351
Min	.0351
Avg	.0351

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054013 / 33 KV RAIMOHA

Feeder No / Name : 203 / 11KV KHOKARMOHA

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	22-JUN-17
HR	Load (MW)
11	.0732
Max	.0732
Min	.0732
Avg	.0732

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054013 / 33 KV RAIMOHA

Feeder No / Name : 205 / 11 KV RAIMOHA

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	22-JUN-17
HR	Load (MW)
10	.3086
11	.2658
Max	.3086
Min	.2658
Avg	.2872

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054024 / 33/11 KV. BR. YALLAM S/S

Feeder No / Name : 201 / 11 KV SHIRUR URBAN

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.1829	.0448	.9431	.2353	.068	.9945
2	1.0117	.1658	.0707	1.0117	.2717	.0533	1.0631
3	1.0631	.2058	.1349	1.0288	.1911	.1012	1.0974
4	1.2003	.3286	.1943	1.0631	.3286	.1858	1.0802
5	1.5432	.3982	.2429	1.3717	.4161	.3077	1.2003
6	1.6632	.4887	.373	1.6461	.6022	.3898	1.6289
7	1.8347	.5171	.443	1.7318	.558	.5868	1.989
8	1.6289	.2724	.499	1.749	.5121	.535	1.5432
9	1.7661	.1732	.4207	1.5432		.3475	1.7318
10	1.6632		.1619	1.3717	.1296	.0949	
11	.0133	.045	1.1488			1.3717	
12	.0133	.0892	.8573	.0743	.1235	.9945	
13	.0116		.9088	.0419	.1235	.9259	.0143
14	.0236		.8745	.0419	.1212	.8916	.0267
15	.0488	.109	.9774	.021	.0572	1.0288	.0267
16	.144	.0747	1.0288	.0103	.0562	1.6632	.048
17	.0857	.1124	1.0974	.0229	.0128	1.6804	.0429
18	.128	.176	1.1317	.0251	.0974	1.1831	
19	.1663	.3077	1.2003	.0518	.2006	1.6289	.0754
20	.4031	.2957	1.286		.2591	1.8176	.0867
21	.3258	.2	1.1831	.4115	.1353	1.2003	.1143
22	.2785	.0975	.8573	.4119	.0774	1.1488	.0526
23	.0251	.0734	.8916	.3688	.1189	1.0288	.0377
24	1.046	.2073	.0486	.9088		.1143	1.0117
Max	1.8347	.5171	1.286	1.749	.6022	1.8176	1.989
Min	.0116	.045	.0448	.0103	.0128	.0533	.0143
Avg	.7096	.2153	.6699	.7205	.2204	.8062	.6933

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054024 / 33/11 KV. BR. YALLAM S/S

Feeder No / Name : 203 / 11 KV RALESANGAVI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.5525		.4191
2	.5716		.5144
3	.5335		.5906
4	.5335		.7621
5	.6287		.8192
6	.6478		.8954
7	.6287		.9717
8	.6668		1.1241
9	.6097		.9145
10	.7621		.381
11			.3429
12			.3048
13			.2572
14		.362	.3086
15	.3239	.5335	.381
16	.3429	.3429	.3429
17	.3239		.3048
18	.4572		
19	.5144	.4001	
20		.5716	
21		.4954	
22		.4572	
23		.4382	
24	.4191		.3239
Max	.7621	.5716	1.1241
Min	.3239	.3429	.2572
Avg	.5323	.4501	.5532

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054024 / 33/11 KV. BR. YALLAM S/S

Feeder No / Name : 205 / 11Kv sawargaon

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.1646	.1231	.2572	.12	.2591	.3258
2	.3772	.1665	.12	.2915	.1231	.3102	.3258
3	.3601	.192	.1086	.3086	.1372	.3239	.3429
4	.3429	.1981	.1174	.3429	.184	.3601	.2915
5	.463	.1593	.1191	.4115	.2195	.3835	.3086
6	.5144	.1797	.1132	.5144	.1981	.3934	.3772
7	.5316	.2972	.1158	.4801	.2524	.4268	.6687
8	.5487	.2561	.0587	.3601	.2726	.4218	.6859
9	.2915	.2286	.076			.439	.7888
10	.3601		.3429	.3601		.0854	
11	.3292	.298	.4115			.2058	
12	.2561	.2841	.4801	.2481		.12	
13	.1981		.3429	.2892		.1029	
14	.2858	.2498	.3086			.1029	.0655
15	.3155	.1951	.3601			.0857	.0549
16	.3155	.2715	.2915	.3734		.1029	.0613
17	.3334	.2195	.3086	.3239		.12	.0655
18	.0238	.1429	.4115	.1772		.1029	.0964
19	.0886	.2136	.4115	.2023	.0762	.4115	.1334
20	.0975	.2469	.3772		.1095	.5144	.1715
21	.1555	.176	.3944	.1829	.1086	.4115	.2286
22	.1557	.1818	.3258	.1654	.1029	.3944	.2172
23	.1846	.1086	.2401	.1174	.1027	.3086	.1955
24	.3258	.1981	.1229	.2572	.0975	.1739	.2743
Max	.5487	.298	.4801	.5144	.2726	.5144	.7888
Min	.0238	.1086	.0587	.1174	.0762	.0854	.0549
Avg	.3006	.2104	.2534	.2981	.1503	.2734	.2840

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054051 / 33 KV PIMPLNER

Feeder No / Name : 201 / PIMPALNER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4939		.2422		.6778		1.0027
2	.4753				.7253		1.3216
3	.4563				.7567		1.3365
4	.5118				.8021		1.3713
5	.4939	.4545			.8332	.8249	1.4219
6	.6072	.7583	.6452	.872	.8642	1.1232	1.3859
7	.7	.6432	.5486	.6243	.8941	1.2149	1.3075
8		.6054	.3226		1.0471	1.1331	.787
9		.5303	.3799	.5103	1.1683	1.1856	1.3576
10	.4325	.5674	.3219		.5276	.9974	.5567
11	.7225		.7792	.8342	.2841	.225	.4091
12	.6922			.8962	.2277		.2804
13	.6264	.6866		.8591	.189	.1896	.3027
14	.6958			.8697	.1698	.1882	.2829
15	.5915	.7219		.8401	.2081	.2056	.2643
16	.6371	.8411	.8401	.7248	.227	.2275	.3015
17	.6546	.8452		.6318	.2454		.3385
18	.2275	.77		.3788	.3306	.2254	.4625
19	.2824	.3945	.3949	.5308	.3749	.4879	.5169
20				.5624	.5647	.6742	.4884
21	.4677		.429	.499	.5281	.6781	.4362
22			.3116	.463		.6605	.4185
23				.4449	.2625		.4007
24	.6316	.2595		.2427	.5928	.407	.5765
Max	.7225	.8452	.8401	.8962	1.1683	1.2149	1.4219
Min	.2275	.2595	.2422	.2427	.1698	.1882	.2643
Avg	.5474	.6214	.4741	.6344	.5435	.6264	.7220

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054054 / 33 KV KHALAPURI

Feeder No / Name : 201 / Khalapuri Agri

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2902		.2743	.2439	.4316		.3601
2	.2911		.3086	.2743	.4321		.3772
3	.3461		.3429	.3048	.4406		.4458
4	.717		.4115	.3353	.8274		.7202
5	.7506		.4801	.3658	.8659		.823
6	.7733		.583	.4572	.9195		.9259
7	.5975		.6516	.5182	.9431		.9602
8	.5067		.583	.4115	.8654		.9774
9	.477		.4801	.381	.7749		.7716
10		.4458	.4877	.5185		.3429	.2286
11		.5144	.583	.4202		.2572	.1981
12		.5144	.5316	.4027		.3429	
13		.5487	.5144	.3856		.2401	.1524
14		.4973	.5144	.4396		.2058	.1524
15		.4801	.4973	.4924		.2229	.1524
16			.4801	.5111		.2058	.1524
17		.4458		.5287		.1715	.1981
18		.3429		.3165		.2229	.3048
19		.3772	.3658	.3525		.3086	.3506
20		.3601	.3353	.3881		.5144	.3963
21		.3772	.3048	.3761		.4458	.3658
22		.3429	.2743	.3582		.3772	.3353
23		.3086	.2439	.3251		.3429	.3201
24	.2911		.2743	.2439	.4316		.3772
Max	.7733	.5487	.6516	.5287	.9431	.5144	.9774
Min	.2902	.3086	.2439	.2439	.4316	.1715	.1524
Avg	.5041	.4273	.4328	.3896	.6932	.3001	.4368

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054115 / manoor

Feeder No / Name : 202 / Loni

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4908	.443	.2286	.1905	.1905
2			.4525	.443	.2286	.1905	.1905
3			.5316	.443	.3429	.1905	.1905
4			.6081		.381	.2858	.1905
5			.5868	.5258	.4572	.3429	.1905
6			.6405	.631	.4572	.4763	.381
7			.7049	.6588	.2858	.381	.4763
8	1.0395	.4382	.6687	.7108	.2858	.2858	.381
9	.2286	.1905	.2858	.1524	.7956		.2858
10	.1905	.0572	.1334	.1524	.8619	.6335	.1905
11	.1334	1.3908	1.5813	.1524	.8802	.7537	.8802
12	.1334	.0953	.1524	.1905	.9145	.7373	.8383
13	.1715		.1524	.1905	.9221	.7045	.9259
14	.0762	.1524	.1334	.1905	.8059	.7125	.9393
15	.0762	.1905	.1334	.1905	.7716	.6802	.8478
16	.1143	.0953	.1334	.1905	.8718	.8097	.7888
17	.2858	.1334	.1905	.2286	.2858	.2096	.8551
18	.381	.1715	.3429	.2667	.2858	.2286	.8551
19	.5335	.2477	.4191	.381	.381	.3429	.1905
20	.4572	.362	.381	.4572	.4763	.3048	.2858
21	.381	.4763	.2667	.4191	.4763	.3048	.4763
22	.3429	.3429	.1524	.4001	.381	.2858	.4191
23	.2477	.2667	.1143	.3048	.381	.2667	.2858
24			.2477	.2286	.3048	.2858	.2667
Max	1.0395	1.3908	1.5813	.7108	.9221	.8097	.9393
Min	.0762	.0572	.1143	.1524	.2286	.1905	.1905
Avg	.2995	.3074	.396	.3457	.5193	.4176	.4801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUN-17 and 28-JUN-17

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054115 / manoor

Feeder No / Name : 203 / TEMBHURNI FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2858	.2286	.2286	.2286	.2858
2			.1905	.2667	.1905	.2858	.381
3			.2858	.2667	.1905	.2286	.2858
4			.381	.2858	.3429	.3429	.381
5			.6668	.4763	.381	.381	.4763
6			.9145	.5716	.6097	.5716	.6097
7			.8573	.6097	.6859	.6668	.5716
8	.5335	.5716	.7621	.5716	.5716	.5716	.4763
9	.8402	1.1431	1.1003	.9962	.4572	.4191	.381
10	1.0002	.9602	1.0822	1.065	.381	.3048	
11	.8573	1.0526	1.0669	1.1174	.3429	.2667	1.0395
12	.9736	.9875	***	1.1336	.381	.1905	.9835
13	.8669		.9907	1.1336	.1905	.1905	1.0526
14	.953	1.0669	.9488	1.1012	.2858	.1715	.9945
15	.9054	1.0883	.8573	1.1142		.1715	.9907
16	.9145	1.0898	.823	1.1142		.2096	1.0513
17	.2858	.1715	.3048	.3429		1.0385	1.0364
18	.4191	.2096	.3048	.3429	1.0957	1.0848	.1905
19	.5335	.5716	.4572	.4954	1.1831	1.1294	.4763
20	.5716	.6668	.4954	.5716	1.278	1.1003	.6668
21	.4763	.5906	.5716	.381	1.2039	1.1003	.5716
22	.381	.5335	.4763	.3429	1.1574	1.1003	.5335
23	.2667	.2667	.2667	.2858	1.166	1.0709	.381
24			.2667	.2477	.2477	1.1401	.2858
Max	1.0002	1.1431	10.41	1.1336	1.278	1.1401	1.0526
Min	.2667	.1715	.1905	.2286	.1905	.1715	.1905
Avg	.6737	.7314	1.0319	.6276	.5986	.5819	.6132