

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CAMP S/DN.[306] BU 0306

Substation No/ Name :- 034013 / 33/11 KV SARFAPUR SUBSTATION

Feeder No / Name : 201 / 11 KV SHIRAJGAON AG FEEDER AG Feeder with SDT  
Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	24-JUN-17	25-JUN-17	27-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0753			
2	.0753			
3	.0753			
4	.0753			
5	.1505			
6	.1505		.0857	
7	.1696	.1696	.0857	
8	.1696		.0857	
9	.1696		.0857	
10				.0524
11				.0524
12				.0524
13				.0524
14				.0524
15				.0524
16				.0524
24	.0753			
Max	.1696	.1696	.0857	.0524
Min	.0753	.1696	.0857	.0524
Avg	.1186	.1696	.0857	.0524

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CAMP S/DN.[306] BU 0306

Substation No/ Name :- 034013 / 33/11 KV SARFAPUR SUBSTATION

Feeder No / Name : 203 / 11KV KARAJGAON GAOTHAN

Gaothan Feeder

FEEDER Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.394	.394		.6516	.4656		.543
2	.394	.394		.583	.4656	.2572	.543
3	.394	.394		.724	.4656	.2572	.543
4	.394	.394		.724	.4656	.2572	.5068
5	.394	.394		.6878	.4298	.2572	.4887
6	.394	.3582		.6516	.4298	.2858	.4344
7		.3292		.6878	.394		.4344
8	.394	.3292		.724	.394	.3144	.4344
9	.3582	.3292		.724	.3582	.3144	.6154
10	.3582	.3658		.724	.3582	.3144	.6878
11	.3582	.3658		.7964	.2686	.3144	.2926
12	.3582	.3658		.7964	.2865	.2286	.2926
13	.3224	.3658		.7964	.2865	.2286	.2926
14	.3582	.3658		.4525	.2865	.2286	.2926
15	.394	.3658		.3982	.2865	.2572	.3292
16	.3582	.3292		.3982	.2865	.2572	.2195
17	.3224	.2561		.362	.2149		.2561
18		.2743		.3582	.2507		.2561
19	.3582	.2743		.4344	.2865		.3292
20	.3582	.3292		.543	.2865		.3658
21	.3582	.362		.543	.3224		.3658
22	.394	.362		.543	.3224		.3658
23	.394	.362		.543	.3224		.3658
24	.3982	.394	.362	.8145	.543	.3224	.5487
Max	.3982	.394	.362	.8145	.543	.3224	.6878
Min	.3224	.2561	.362	.3582	.2149	.2286	.2195
Avg	.3730	.3522	.362	.6109	.3532	.2730	.4085

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CAMP S/DN.[306] BU 0306

Substation No/ Name :- 034013 / 33/11 KV SARFAPUR SUBSTATION

Feeder No / Name : 204 / 11 KV DEURWAD AG FEEDER AG Feeder with SDT  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4687			.125	
2		.4801			.125	
3		.4801			.125	
4		.4801			.125	
5		.4801			.125	
6		.6401		.5144	.125	
7		.663		.5144	.125	
8		.8288			.125	
9		.8288		.3429	.125	
10	1.1203		.9717			.1619
11	1.1203		.9717			.1619
12	1.1203		.9717			.1619
13	.9602		.9717			.101
14	1.0402		.9717			.1619
15	1.0402		.9717			.1619
16	1.0155		.9717			.1619
17	.9374		.9717			
24					.1134	
Max	1.1203	.8288	.9717	.5144	.125	.1619
Min	.9374	.4687	.9717	.3429	.1134	.101
Avg	1.0443	.5944	.9717	.4572	.1238	.1532

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CAMP S/DN.[306] BU 0306

Substation No/ Name :- 034013 / 33/11 KV SARFAPUR SUBSTATION

Feeder No / Name : 205 / 11KV RATANPUR AG FEEDER AG Feeder with SDT  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7459				.0166	.0476	.0678
2	.7459				.0166	.0476	.0678
3	.8288				.0166	.0476	.0678
4	.8288				.0166	.0476	.0678
5	.8288				.0166	.0476	.0678
6	.9116				.0166	.0476	.1006
7	.9945				.0332	.0953	.1006
8	.9945				.0332	.0953	.1006
9	.9945				.0332	.0953	.1006
10		.9945		.1638	.2984		.1326
11		1.6385		.1638	.2984		.1658
12		1.6385		.2294	.1658		.1658
13		1.6385		.2294	.1658		.1658
14		1.4746		.2294	.1658		.1658
15		1.4746		5.3727	.1658		.1658
16		1.3108		.1629	.1658		.1658
17		1.3108			.1658		.1658
18				.0332			
24	.7373		.6706		.0164	.0829	.0678
Max	.9945	1.6385	.6706	5.3727	.2984	.0953	.1658
Min	.7373	.9945	.6706	.0332	.0164	.0476	.0678
Avg	.8611	1.4351	.6706	.8231	.1004	.0654	.1168

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CAMP S/DN.[306] BU 0306

Substation No/ Name :- 034013 / 33/11 KV SARFAPUR SUBSTATION

Feeder No / Name : 206 / 11 KV LAKHANWADI AG AG Feeder with SDT  
 FEEDER Feeder KV- 11 /  
 OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8061	.8429				.0286	.4144
2	1.8061	.8429				.0286	.4144
3	1.8061	.8429				.0286	.4144
4	1.8061	.8429				.0286	.4144
5	1.8061	.9031				.0286	.4144
6	1.8061	.9031		.6478		.0286	.4973
7	1.8061	1.094		.6802		.0286	.5801
8	1.8061	1.094		.8097		.0286	.5967
9	1.2041	1.0608		.8097	.0753	.0286	.5967
10	1.2041			.8097	1.6556	.4001	.9945
11	1.1439	1.8461		1.6194	1.6556	.3572	1.0277
12	1.1138	2.2348		1.6194	1.5051	.3572	1.2266
13	1.2041	2.0729		1.6194	1.5051	.3572	1.326
14		1.8785		1.6194	.0301	.3572	1.3592
15	1.2041	1.8623		1.6194	.0301	.4287	1.3923
16	1.2041	1.9109		1.6194	.0602	.4287	1.3923
17	.7526	1.9433		1.6766	.0602		
18							1.0608
20						.0286	
23		1.7368					
24	1.9204	.8429	1.7368			.0301	.4144
Max	1.9204	2.2348	1.7368	1.6766	1.6556	.4287	1.3923
Min	.7526	.8429	1.7368	.6478	.0301	.0286	.4144
Avg	1.4941	1.3753	1.7368	1.2625	.7308	.1668	.8076

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CAMP S/DN.[306] BU 0306

Substation No/ Name :- 034013 / 33/11 KV SARFAPUR SUBSTATION

Feeder No / Name : 207 / 11 KV KURHA GAOTHAN FEEDER Gaothan Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3311	.301	.3429	.2149	.3612		
2	.3311	.301	.3429	.2149	.3612	.2401	
3	.3311	.301	.3429	.2149	.3311		
4	.3311	.301	.3429	.2149	.3311		
5	.301	.301	.3429	.2149	.3311		
6	.2709	.1505	.3086	.2149	.301		
7	.2709	.181	.2743	.2149	.301		
8	.2258	.1448	.2401	.2149	.2709		
9	.2258	.1448	.2229	.2149	.2559		
10	.2408	.1448	.1715	.2149	.2559		.2149
11	.2408	.1448	.1715	.2149	.2408		.181
12	.1806	.181	.1715	.2149	.1204		.181
13	.1505	.2481	.1715	.2149	.1204		.181
14	.1505	.2481	.1715	.394	.1204		.2172
15	.1505	.2481		.3582	.1204		.2172
16	.1505	.2328	.1715	.2865	.1204		.2172
17	.1505	.2172	.1715	.2865	.1204		.181
18	.1806	.181	.1715	.3224	.1505		.181
19	.2107	.2481	.1715	.3582	.1806		.2658
20	.2408	.3467	.1715	.4298	.2408	.2401	.3467
21	.2709	.3814	.1715	.4656	.2709		.3641
22	.2709	.3814	.2058	.4656	.2709		.3641
23	.301	.3641	.2058	.4656	.2709		.3641
24	.4477		.3467	.2058	.4298	.2709	
Max	.4477	.3814	.3467	.4656	.4298	.2709	.3641
Min	.1505	.1448	.1715	.2058	.1204	.2401	.181
Avg	.2482	.2476	.2350	.2847	.2449	.2504	.2483

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CAMP S/DN.[306] BU 0306

Substation No/ Name :- 034038 / 33/11 KV KHARPI SUBSTATION

Feeder No / Name : 201 / 11 KV INDUSTRIAL FEEDER HV Non-Express Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0343	.0343	.0514	.0514	.0514	.0686
2	.0686	.0343	.0343	.0514	.0514	.0514	.0686
3	.0686	.0343	.0343	.0514	.0514	.0514	.0686
4	.0686	.0343	.0343	.0514	.0514	.0514	.0686
5	.0686	.0343	.0343	.0514	.0514	.0514	.0686
6	.0686	.0343	.0343	.0514	.0514	.0514	.0686
7	.0686	.0343	.0343	.0514	.0514	.0514	.0686
8	.0686	.0343	.0686	.0857	.0514	.0514	.0686
9	.0343	.0343	.0686	.0857	.0514		.0686
10	.0343	.0343	.1029	.1029	.0514		.0686
11	.0343	.0514	.1029	.1029	.0514	.0686	.0686
12	.0343	.0514	.1029	.1715	.0514	.0686	.1029
13	.0343	.0514	.1029		.0514	.1029	.1029
14	.0343	.0514	.1029	.0857	.0514	.1372	.1029
15	.0343	.0343	.1029	.0857	.0514	.1029	.1029
16	.0343	.0343	.1029	.0686	.0514	.1029	.1029
17	.0343	.0343	.1029	.0686	.0514	.1029	.1029
18	.0343	.0343	.1029	.0514	.0686	.1029	.1029
19	.0343	.0343	.1029	.0857	.0686	.1029	.1029
20	.0343	.0343	.1029	.0857	.0514	.1029	.1029
21	.0343	.0343	.1029	.0686	.0514	.1029	.1029
22		.0343	.0514	.0686	.0514		.1029
23	.0343	.0343	.0514	.0514	.0514	.1029	.1029
24	.0686	.0343	.0343	.0514	.0686	.0514	.0686
Max	.0686	.0514	.1029	.1715	.0686	.1372	.1029
Min	.0343	.0343	.0343	.0514	.0514	.0514	.0686
Avg	.0477	.0372	.0729	.0730	.0536	.0792	.0858

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CAMP S/DN.[306] BU 0306

Substation No/ Name :- 034038 / 33/11 KV KHARPI SUBSTATION

Feeder No / Name : 203 / 11 KV SALEPUR AG FEEDER AG Feeder with SDT  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	1.2003	.6001	1.2003	1.0288	.2058	.5144
2	1.5432	1.2003	.6001	1.2003	1.0288	.1372	.5144
3	1.5432	1.2003	.6001	1.2003	.9431	.1372	.5144
4	1.5432	1.2003	.6001	1.2003	.9431	.1029	.5144
5	1.5432	1.2003	.6001	1.2003	.9945	.1372	.5144
6	1.5775	1.3375	.6001	1.2003	1.0631	.2058	.6859
7	1.7318	1.6289	1.3375	1.2003	1.3375	.3429	.9431
8	1.8519	2.0233	1.3032	1.4575	1.3717	.4801	.8745
9	1.7318	1.8519	1.6804	1.4575	1.406	.583	1.1831
10	1.5089	1.5089	1.7833	.9774	.8573		.823
11	1.6804	1.8004	2.1262	1.1488	.9259	.8745	1.0974
12	1.9033	1.8004	1.9547	1.286	.9431	.9602	1.166
13	1.8519	1.8004	1.9547	1.2346	.9431	.9259	1.1145
14	1.8519	1.3717	1.9547	.9431	.8573	.8916	1.0974
15	1.8176	1.5089	1.9547		.8573	.8573	1.1145
16	1.6118	1.6804	1.9547	.2572	.6859	1.0288	1.2174
17	1.6461	1.6804	1.9547	.3429	.6001	.9259	1.2689
24	1.5432	1.1488	.6001	1.2003	.9945	.2401	.5144
Max	1.9033	2.0233	2.1262	1.4575	1.406	1.0288	1.2689
Min	1.5089	1.1488	.6001	.2572	.6001	.1029	.5144
Avg	1.6680	1.5080	1.3422	1.1004	.9878	.5316	.8707



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CAMP S/DN.[306] BU 0306

Substation No/ Name :- 034038 / 33/11 KV KHARPI SUBSTATION

Feeder No / Name : 204 / 11 KV BAHIRAM AG FEEDER AG Feeder with SDT  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.406		.9431			.1886	
2	1.406		.9431			.1715	
3	1.406		.9431			.1715	
4	1.406		.9431			.1543	
5	1.406		.9431			.1543	
6	1.406		1.3032			.1715	
7	1.4575		1.5432			.3086	
8	1.4575		1.5432			.3429	
9	1.5604		1.6975			.3429	
10		1.6804		.7888	.6001	.1543	.823
11		1.9719		.9945	.6859		.7716
12		1.9719		.7716	.6001		.823
13		1.9719		.6859	.6516		.7716
14		1.0802		.6516	.3772		.7716
15		1.286		.6001	.4115		.7545
16		1.6461		.5658	.3429		.7202
17		1.6461		.5144	.2572		.6516
24	1.4403		.9431			.2058	
Max	1.5604	1.9719	1.6975	.9945	.6859	.3429	.823
Min	1.406	1.0802	.9431	.5144	.2572	.1543	.6516
Avg	1.4352	1.6568	1.1746	.6966	.4908	.2151	.7609

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CAMP S/DN.[306] BU 0306

Substation No/ Name :- 034038 / 33/11 KV KHARPI SUBSTATION

Feeder No / Name : 205 / 11 KV KHARPI GAOTHAN

Gaothan Feeder

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.4115	.4115	.5144	.3772	.3258	.4115
2	.4458	.4115	.4115	.5144	.3772	.3086	.3772
3	.4115	.4115	.4115	.5144	.3429	.3086	.3772
4	.4115	.4115	.4115	1.2003	.3429	.3086	.3772
5	.4115	.4115	.4115	.4801	.3772	.3258	.3772
6	.3772	.4115	.3429	.4115	.3944		.3944
7	.3429	.4287	.3429	.3429	.3601		.3772
8	.4115	.3258	.3429	.3772	.3429		.3944
9	.4115	.4115	.3429	1.4575	.4115		.3601
10	.4287	.4115	.4287	.3429	.3772	.3086	.3429
11	.4115	.3429	.4287	.3429	.3429	.3772	.3429
12	.463	.3429	.3772	.3601	.3601	.3086	.3429
13	.4287	.3429	.3772	.3429	.3772	.3086	.3429
14	.4115	.2572	.3772	.3429	.3429	.3429	.3429
15	.4115	.2572	.3772	.3429	.3429	.3601	.3429
16	.4458	.3944	.3772	.3772	.3086	.3429	.3429
17	.4115	.4458	.3772	.3772	.2743	.3258	.3429
18	.3944	.4973	.3258	.4287	.3601	.3086	.3258
19	.4287	.4973	.3258	.463	.3944	.4115	.4115
20	.5144	.4973	.4801	.5144	.4115	.4801	.4801
21	.4973	.4973	.4801	.4801	.3944	.4801	.4801
22		.4973	.5144	.4801	.3772		.463
23	.4801	.4973	.5144	.4287	.3429	.4287	.4458
24	.4458	.4458	.4115	.5144	.4115	.3429	.4115
Max	.5144	.4973	.5144	1.4575	.4115	.4801	.4801
Min	.3429	.2572	.3258	.3429	.2743	.3086	.3258
Avg	.4279	.4108	.4001	.4980	.3644	.3528	.3836

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CAMP S/DN.[306] BU 0306

Substation No/ Name :- 034038 / 33/11 KV KHARPI SUBSTATION

Feeder No / Name : 206 / 11 KV MUKTAGIRI FEEDER SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1372	.1543	.12	.1543		.12
2	.1715	.1372	.1543	.12	.1543		.1029
3	.1715	.1372	.1543	.12	.1372		.1029
4	.1715	.1372	.1543	.12	.1372		.1029
5	.1715	.1372	.1543	.12	.1372		.1029
6	.1715	.1372	.1543	.12	.1372		.12
7	.1886	.1715	.1715	.1886	.1543		.12
8	.1886	.2401	.1715	.1372	.1715		.12
9	.2229	.2743	.2058	.1372	.2058		.1372
10	.2572	.2572	.2572	.1886	.1372		.2229
11	.2743	.2401	.2572	.2229	.2058	.1372	.2401
12	.2401	.2401	.2229	.1715	.1715	.1372	
13	.2743	.2401	.2229	.1715	.1715	.1543	
14	.2572	.2401	.2229	.1715	.1372	.1372	
15	.2401	.1715	.2229	.1715	.1372	.1543	
16	.2401	.2058	.2229	.1715	.1372	.1372	.1886
17	.2401	.2058	.2229	.1715	.1372	.1543	.2401
18	.2572	.1715	.1886	.1886	.12	.1715	.2058
19	.1886	.1715	.1886	.1715	.1543	.1715	.1543
20	.1715	.1715	.1886	.1715	.1372	.1372	.1372
21	.1372	.1715	.1886	.2058	.1372		.1029
22		.1715	.12	.1886	.1372		.1029
23	.1372	.1715	.12	.1715	.12	.12	.1029
24	.1715	.1372	.1543	.12	.1715	.1029	.12
Max	.2743	.2743	.2572	.2229	.2058	.1715	.2401
Min	.1372	.1372	.12	.12	.12	.1029	.1029
Avg	.2050	.1865	.1865	.1600	.1501	.1429	.1423

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CAMP S/DN.[306] BU 0306

Substation No/ Name :- 034040 / 33 KV TONDGAON

Feeder No / Name : 201 / 11KV Tondgaon

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4575	1.6632	1.3889	1.3546		1.3032	1.286
2	1.3717	1.6289	1.3717	1.3375	1.2689	1.286	1.286
3	1.3375	1.5947	1.406	1.3546	1.286	1.2689	1.2689
4	1.3375	1.5775	1.406	1.3375	1.286	1.2517	1.2346
5	1.286	1.2003		1.3032	1.2346	.5144	1.2174
6	1.286	1.3032		1.166	1.1831	.583	1.2174
7	.6516	.9259		.8402	.9602	.6516	1.2003
8	.9945	.8573	2.0919		.8402	.6687	
9	2.1262	.8745	2.4691	.8402	.8402	.6687	.8059
10	2.3834	.8573	2.7263	.8573			.8059
11	2.4863	.8916	2.6406		.9774	.7202	.6344
12	2.3491	.9774	2.5549	.9774	.9088	.6516	
13	1.1145	2.4691		2.0919	1.749	.4687	1.3546
14	1.1831		1.1317	2.3148	1.2174	.7202	1.4575
15		2.4006	1.166	2.2291	.9945	.7202	1.4746
16	.9945	2.4006	1.1317	2.1776	.9088	.6859	1.4746
17	.9431	2.4006	.9945	2.0576	.7888	.6859	1.6118
18	.7716	2.3834	.7545	1.9376	.6859	.6344	1.6461
19	.8745		.8573		.703	.7545	1.5604
20	1.2346	2.4177	1.3203	1.6804	.7373	1.2174	1.4575
21	1.4575	2.332	1.4403		1.3375		1.406
22		2.2977	1.4403	1.3375			
23	1.7833	2.1434	1.4232	1.3375	1.3546	1.2346	1.3717
24	1.4575	1.6975	2.0576	1.3546	1.286	1.3203	.8573
Max	2.4863	2.4691	2.7263	2.3148	1.749	1.3203	1.6461
Min	.6516	.8573	.7545	.8402	.6859	.4687	.6344
Avg	1.4037	1.6952	1.5886	1.4944	1.0737	.8576	1.2680

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CAMP S/DN.[306] BU 0306

Substation No/ Name :- 034040 / 33 KV TONDGAON

Feeder No / Name : 202 / 11 KV Talegaon

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.7545	.8916	.823	.7888	.703	.6859
2	.7716	.7202	.8916	.8402	.7888	.6859	.6173
3	.6859	.7888	.8916	.8402	.8059	.6859	.6173
4	.6859	.7888	.8916	.823	.8059	.6859	.5144
5	.6516	1.7147		2.0233	1.3375	.6516	.4973
6	.6516	1.989		2.0233	1.3889	.6173	.4973
7	.5658	2.1091		2.2977	1.3032	.583	.5144
8	.5658	2.0748	.6001			.4973	
9	.5487	2.9835	.6001	2.7606	1.3203	.4801	.6344
10	.4801	3.0178	.6001	2.9664	1.3546		.6344
11	.3601	3.0864			1.4746	.4287	.6516
12	.583	3.035		2.6749		.4287	.6687
13		.6344		.3429	.4287	.4458	.463
14	2.8121		3.2236	.6516	.4458	.4458	
15	2.5206	.7202	3.0521	.583	.463	.4458	.4801
16	2.7435	.7202	2.8121	.5316	.4801	.4287	.4801
17	2.692	.6687	2.7263	.583	.4973	.4287	.463
18	2.8292	.6344	2.7263	.6173	.5316	.4115	.463
19	2.8292		2.5377		.6344	.4801	.6173
20	2.8292	.9259	2.5034	.8059	.703	.5144	.7545
21	2.7435	.9259	2.3663		.7202		.8402
22		.9259	2.2977	.823			.8059
23	.7888	.7888	.9774	.823	.703	.6859	.7888
24	.8402	.7545	.8916	.8402	.823	.703	.6859
Max	2.8292	3.0864	3.2236	2.9664	1.4746	.703	.8402
Min	.3601	.6344	.6001	.3429	.4287	.4115	.463
Avg	1.4068	1.3983	1.7490	1.2337	.8476	.5446	.6079

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CAMP S/DN.[306] BU 0306

Substation No/ Name :- 034040 / 33 KV TONDGAON

Feeder No / Name : 203 / 11KV Bhugaon

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8916	2.915	.8573	.8916	.8916	.8059	.7716
2		2.8292	.8745	.8916	.9088	.7716	.6859
3	.823	2.7435	.8745	.8745	.8916	.7716	.6859
4	.7716	2.5892	.8745	.8745	.8916	.8059	.5144
5	.6859	.6001		.8573	.8573	.3429	.4458
6	.6516	.6516			.7202	.3944	.3601
7	.463	.463		.463	.5316	.4458	.3429
8	.4287	.4115	3.0178		.463	.5144	
9	.3944	.2572	3.5322		.4801	.5658	.3772
10	.4115	.2572	3.2236		.4458		.3772
11	.3944		3.275		.2743	.583	.3429
12		.583	3.0864	2.2291	.5144	.583	.3944
13	.703	2.9664		2.8635	1.2003	.3944	1.6975
14			.7716	3.275	1.046	.3086	1.8347
15	.703	3.0521	.7373	1.9719	.9602	.3086	1.7147
16	.5316	3.1893	.6859		.8402	.2743	1.6461
17	.463	3.1893			.6344	.2229	1.749
18	.4458	2.9664		.7202	.583	.2401	1.9547
19	.3601		.5316		.5658	.5658	2.0748
20	.8402	2.8807	.8745	.9431	.6001	.8059	2.2805
21	.9088	2.8807	.9259		.8916		.9259
22		3.1207	.9602	.9259			.9088
23	2.8121	2.7435	.9431	.9088	.8573	.823	.8916
24	.9431	2.915	2.6578	.9259	.9088	.8059	.8059
Max	2.8121	3.1893	3.5322	3.275	1.2003	.823	2.2805
Min	.3601	.2572	.5316	.463	.2743	.2229	.3429
Avg	.7313	2.1050	1.5947	1.3077	.7373	.5397	1.0340

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CAMP S/DN.[306] BU 0306

Substation No/ Name :- 034040 / 33 KV TONDGAON

Feeder No / Name : 204 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343		.1372				.0343
2	.0343		.1715				.0343
3			.1715				.0343
4			.1715				.0343
7	.0686				.0686		
8	.12		.1372		.0686		
9	.12		.1029				.0171
10	.2572	.1886	.1372	.2058			.0171
11	.2401	.1219	.1372				.0343
12	.3086	.2229	.2229	.1715			.3601
13		.1372		.1715		.0686	.3086
14	.2743		.2229	.2743		.0686	.3601
15	.2229	.2058	.2401	.2229		.0686	
16	.3086	.2058	.2229	.2229		.1029	.3086
17	.3429	.2058	.2229	.2058		.1029	.2572
18	.3086	.2058	.1715	.2058		.1372	.2401
19	.1543		.1372			.1372	.2058
20	.1543	.1372	.1372	.1372		.1372	.2401
21		.0857					
22		.12		.0343			
23		.1029		.0343		.0686	
24	.0343		.1372		.0343		.0686
Max	.3429	.2229	.2401	.2743	.0686	.1372	.3601
Min	.0343	.0857	.1029	.0343	.0343	.0686	.0171
Avg	.1865	.1616	.1695	.1715	.0572	.0991	.1597

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CAMP S/DN.[306] BU 0306

Substation No/ Name :- 034040 / 33 KV TONDGAON

Feeder No / Name : 205 / 11 KV Belaj

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.6001	.6001	.6001	.583	.5316	.4458
2	.5144	.6001	.6001	.6001	.5487	.5144	.4458
3		.583	.6001	.6001	.583	.5144	.4458
4	.4458	.583	.6001	.6001	.583	.4973	.3772
5	.4458	1.2003		1.3717	.5487	.4287	.3772
6	.4458	1.286		1.3889	.583	.3429	.3258
7	.3258	1.4232		1.7147	.583	.3086	.3086
8	.3086	1.7147	.2401		.6344	.2743	
9	.2572	2.0233	.2401	1.8519	.6687	.2401	.6516
10	.2743	2.0576	.2743	2.0919	.6344		.7202
11	.3086	2.0233	.3429	2.0919	.5658	.2058	.9259
12	.3258	1.9547	.2915	2.0576	.5658	.2229	.9602
13				.4458	.2915	.2572	.2743
14	2.2805		2.2119	.2915	.2915	.2743	.3086
15	2.0576	.4801	2.2462	.1886	.2915	.2743	.3086
16	2.0919		2.1262	.2229	.3086	.4287	.3086
17	2.1262		1.9547	.2229	.3086	.4287	.2572
18	1.989	.2915	.2572	.2058	.2058	.4287	.2572
19	2.0405		1.6461			.5658	.3772
20	1.9719	.5487	1.7318	.5487	.4801	.5316	
21	1.749	.6344	1.6118		.5144		.6001
22		.6344	1.5775	.6001			.6001
23	.6173	.6173	.6344	.6173	.5316	.5144	.583
24	.6001	.6001	.6001	.6173	.6001	.5316	.4973
Max	2.2805	2.0576	2.2462	2.0919	.6687	.5658	.9602
Min	.2572	.2915	.2401	.1886	.2058	.2058	.2572
Avg	1.0370	1.0450	1.0194	.9014	.4957	.3960	.4707



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CAMP S/DN.[306] BU 0306

Substation No/ Name :- 034040 / 33 KV TONDGAON

Feeder No / Name : 206 / 11 KV Narayanpur Ag  
Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.9774		.2058
2				.9602		.2058
3				.9431		.2058
4				.9431		.2058
5		.6859		.9431		.2058
6		.7373		.9431		.2058
7		.9431		1.0631		.2058
8		1.0974				
9		1.1831		1.3203		.6173
10		1.2346		1.3546	.6173	.6173
11		1.166		1.3546	.9259	.8916
12		1.1488			.9088	.8573
13					.8745	.9431
14	1.2174				.5487	.9945
15					.5144	1.0117
16	1.0288				.463	1.0288
17	1.0288		1.406	.6859	.3429	1.0974
18	1.1488		1.406	.6687		
19	1.0974		1.5261			
20	1.0631		1.2174	.6344		
21			1.2174			
22			1.166	.5144		
23			.9602			
24				.9945		.0457
Max	1.2174	1.2346	1.5261	1.3546	.9259	1.0974
Min	1.0288	.6859	.9602	.5144	.3429	.0457
Avg	1.0974	1.0245	1.2713	.9534	.6494	.5615

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CAMP S/DN.[306] BU 0306

Substation No/ Name :- 034051 / 33 KV Narsari

Feeder No / Name : 203 / 11 KV Bihali

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5487	.5375	.5144	.5487	.5144	.5144
2	.5144	.5144	.5144	.5144	.5316	.5144	.5144
3	.5144	.5144	.5144	.4801	.5316	.4801	.5144
4	.5144	.5144	.5144	.4801	.5316	.4801	.5144
5	.4801	.5144	.4801	.4801	.5144	.4801	.5144
6	.4458	.463	.4287	.4458	.4801	.463	.5144
7	.4115	.3944	.4115	.4115	.4287	.4458	.4458
8	.4115	.3772	.3856	.3944	.3944	.4287	.3601
9	.3429	.3601	.3391	.3429	.3258	.3601	.3601
10	.9602	.5992	.5304	.703	.6562	.4458	.5144
11	1.1174	.9614	1.0442	.8907	.8259	.583	.8573
12	1.1174	.8192	1.1831	.8962	.7888	.5144	.8619
13	1.1203	.9614	1.2346	.8962	.7716	.5144	.8453
14	1.0364	.8619	1.166	.8097	.6687	.5144	.779
15	.9717	.8745	1.1488	.664	.7202	.5144	.7956
16	.9172	.9779	1.166	.7125	.7202	.5144	.8288
17	.9717	.9448	1.0631	.7449	.6001	.5144	.6554
18	.2915	.3521		.4287	.4458	.3429	.3315
19	.463	.5144	.3944	.5316	.4973	.4801	.4578
20	.583	.6588	.6344	.6516	.6173	.5658	.6274
21	.6173	.6274	.6516	.6516	.6173	.5658	.6068
22	.6173	.6415	.6173	.583	.6173	.5658	.6415
23	.583	.5721	.583	.583	.2401	.5658	.6068
24	.5658	.5487	.5256	.5487	.5487	.5487	.5658
Max	1.1203	.9779	1.2346	.8962	.8259	.583	.8619
Min	.2915	.3521	.3391	.3429	.2401	.3429	.3315
Avg	.6715	.6298	.6986	.5983	.5676	.4965	.5928

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CAMP S/DN.[306] BU 0306

Substation No/ Name :- 034051 / 33 KV Narsari

Feeder No / Name : 205 / 11 kv Gaurkheda (G)

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2743	.3086	.1715	.2401	.1715	.1715
2	.2743	.2743	.2915	.1715	.2229	.1715	.1715
3	.2743	.2743	.2915	.1715	.2058	.1715	.1715
4	.2401	.2743	.298	.1543	.2058	.1715	.1715
5	.2058	.2743	.2713	.1543	.2058	.1715	.1715
6	.2058	.2401	.2229	.2058	.2401	.1543	.1715
7	.2401	.2743	.2254	.2401	.2058	.1715	.1715
8	.2058		.2401	.1886	.1715	.1543	.1715
9	.2401	.2229	.3052	.1886	.1372	.1543	.1715
10	.3429	.2743	.3315	.1543	.1886	.1372	.1372
11	.3429	.2652	.3315	.2229	.1372	.12	.1029
12	.2401	.2321	.3258	.2229	.12	.1029	.116
13	.2572	.2515	.3258	.2058	.1029	.1029	.1006
14	.3086	.2321	.3086	.1886	.1029	.1029	.1326
15	.3086	.2486	.2229	.1886	.1372	.1029	.116
16	.2743	.2155	.2572	.1372	.1029	.1029	.0995
17	.2915	.1989	.2401	.1715	.1029	.1372	.0983
18	.2572	.2614	.2058	.1372	.1029	.1372	.0995
19	.2572	.2401	.1543	.1715	.12	.1372	.1187
20	.2572	.3121	.2058	.2058	.1715	.1715	.2035
21	.2572	.2915	.2058	.2229	.1886	.1715	.1734
22	.2229	.2915	.2058	.2401	.1886	.1715	.208
23	.2915	.3121	.2058	.2572	.1886	.1715	.208
24	.3429	.2915	.3086	.2058	.2401	.1886	.1715
Max	.3429	.3121	.3315	.2572	.2401	.1886	.208
Min	.2058	.1989	.1543	.1372	.1029	.1029	.0983
Avg	.2672	.2621	.2621	.1908	.1679	.1479	.1512

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CAMP S/DN.[306] BU 0306

Substation No/ Name :- 034051 / 33 KV Narsari

Feeder No / Name : 206 / 11 kv Narsary AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3725	.2035	.4115	.1134	.12	.0857
2	.3772	.3725	.2058	.4115	.1134	.12	.0857
3	.3429	.3725	.2035	.4115	.1134	.12	.0857
4	.3429	.3725	.2229	.4115	.1134	.1029	.0857
5	.2743	.3725	.2401	.4115	.1134	.1029	.0857
6	.2743		.2401	.3429	.1134	.0857	.0857
7	.2743	.6478	.2947	.4115	.1943	.1029	.1372
8	.2743	.7287	.3467	.5144	.2915	.12	.1886
9	.2743	.6802	.3222	.4801	.3201	.1029	.2401
10	.6516	.1296	.6796	.2058	.1619	.2058	.0686
11	.7611	.2818	.8619	.1619	.2105	.2058	.2058
12	.7682	.2652	.8916	.192	.2401	.2058	.2652
13	.7773	.2984	.823	.208	.2401	.2058	.3149
14	.703	.3149	.8916	.1781	.2572	.2058	.2881
15	.7125	.2818	.2572	.1781	.2401	.2058	.2984
16	.3725	.2881	.3429	.1562	.2058	.2058	.3149
17		.3149	.823	.1619	.1715	.2229	.2294
18	.0509	.0373	.0343	.0343	.0343	.0171	.0503
19	.0514	.0343	.0514	.0343	.0343	.0114	.0254
20	.0514	.0347	.0343	.0343	.0343	.0343	.0339
21	.0514	.0347	.0343	.0343	.0343	.0343	.0347
22	.0686	.0347	.0343	.0343	.0343	.0343	.0347
23	.0686	.052	.0343	.0343	.0514	.0343	.0347
24	.4115	.3725	.1715	.4801	.12	.0514	.0857
Max	.7773	.7287	.8916	.5144	.3201	.2229	.3149
Min	.0509	.0343	.0343	.0343	.0343	.0114	.0254
Avg	.3614	.2910	.3435	.2473	.1482	.1191	.1402

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CAMP S/DN.[306] BU 0306

Substation No/ Name :- 034056 / 33 kv shirajgaon

Feeder No / Name : 201 / 11 KV Shirajgaon Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717		1.4299	1.2003	1.3203	1.2048	1.2489
2	1.3375	1.4175	1.4118	1.2003	1.3375	1.2048	1.2489
3	1.286	1.382	1.4118	1.2003	1.3203	1.1694	1.2127
4	1.286	1.3289	1.3756	1.1145	1.3203	1.1517	1.2308
5	1.286	1.2403	1.3575	1.1145	1.3203	1.1517	1.2127
6	1.0288	1.2048	1.3213	1.0288	1.2003	1.1163	1.1946
7	1.0288	1.0808	1.1946	.9431	1.046	1.0099	1.0679
8	.7716	.9745	1.0679	.8573	.9945	.8859	.9412
9	.6859	.9391	.9774	.7716	.9774	.8505	.9231
10	.9431	.9745	.9412	.6859	.8573		.8869
11	1.0277	1.0136	.9431	.8573	.8775	.6154	.9412
12	1.1871	1.1403	.7716	.9088	.9214	.7468	.8402
13	1.2403	1.2127	1.166	1.0802	.8682		.9945
14	1.382	1.2489	1.286	1.1831	.8859	.8688	1.0288
15	1.382	1.2308	1.286	.9774	.8682	.9412	1.0631
16	1.1871	1.1403	1.2003	1.0288	.8505	.4163	.9602
17	1.0985	.9955	1.1145	.9945	.9214	.3801	.8059
18	1.0099	1.1222	1.286	1.0802	.9568	.4481	.9945
19	1.0631	1.2127	1.4575	1.2003	.9922	.5068	1.2003
20	1.3466	1.448	1.4575	1.406	1.1163	1.4661	1.2689
21	1.4175	1.5023	1.4575	1.3717	1.1694	1.3575	1.3032
22	1.4706	1.4661	1.4918	1.406	1.2403	1.3394	1.3375
23	1.5061	1.448	1.3717	1.406	1.2403	1.3213	1.3375
24	1.4403	1.4706	1.4299	1.286	1.3375	1.2048	1.2851
Max	1.5061	1.5023	1.4918	1.406	1.3375	1.4661	1.3375
Min	.6859	.9391	.7716	.6859	.8505	.3801	.8059
Avg	1.1993	1.2258	1.2587	1.0960	1.0808	.9708	1.1054

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CAMP S/DN.[306] BU 0306

Substation No/ Name :- 034056 / 33 kv shirajgaon

Feeder No / Name : 202 / 11 KV Pala AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3429	.1372		.0514
2				.3429	.1029		.0514
3				.3429	.1029		.0514
4				.3429	.0857		.0514
5				.4287	.0857		.0686
6				.4287	.1029		.0686
7		.0857		.4287	.12		.0857
8		.1543		.4287	.1886		.1029
9		.1227		.3429	.2229		.0686
10	.8573		.1372				
11	.9945		.5144			.0686	
12	.9774		.7716				
13	1.2003		1.0288				
14	.9774		1.2003			.0857	
15	.9088		1.2003			.0686	
16	.8745		1.2003			.0686	
17			1.1145			.0686	
24		.583		.3429	.2058		.0686
Max	1.2003	.583	1.2003	.4287	.2229	.0857	.1029
Min	.8573	.0857	.1372	.3429	.0857	.0686	.0514
Avg	.9700	.2364	.8959	.3772	.1355	.0720	.0669

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CAMP S/DN.[306] BU 0306

Substation No/ Name :- 034056 / 33 kv shirajgaon

Feeder No / Name : 205 / 11 KV Angatpur AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.0802	.7716	.1886	.1052	.0686
2		.964	1.1145	.7716	.1886	.1052	.0514
3		.9465	1.1145	.7716	.1715	.0876	.0343
4		.9114	1.166	.7716	.1715	.0876	.0857
5		.9816	1.2346	.6001	.1715	.0876	.0857
6		.964	1.2689	.5144	.1886	.0876	.0857
7	.2572	1.4022	1.5432	.4287	.2058	.1052	.1029
8	.2572	1.5424	1.7661	.4287	.2058	.1417	.1372
9	.6859	1.4232	1.7661	.4287	.2058	.12	.2058
10	1.1145	1.3321	1.3889		.2229		.1715
11	1.5249	1.3032	1.5432	.4801	.1753	.1543	.1715
12	1.4548	1.6804	1.5432	.4458	.2279		.2229
13	1.4198	1.7833	1.4575	.4287	.1928		.2058
14	1.4899	1.749	1.4575	.4287	.1928	.1543	.2572
15	1.4198	1.6975	1.4575	.2572	.1052	.1543	.3086
16	1.3672	1.6632	1.4575	.2572	.0876	.12	.3086
17		1.6289	1.3717	.2572	.1402	.0857	.2743
24	.7716	.964	1.0288	.9431	.1886	.1227	.1029
Max	1.5249	1.7833	1.7661	.9431	.2279	.1543	.3086
Min	.2572	.9114	1.0288	.2572	.0876	.0857	.0343
Avg	1.0693	1.3492	1.3756	.5285	.1795	.1146	.1600

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CITY SUB-DN[307] BU 3077

Substation No/ Name :- 034015 / 33KV RASEGAON

Feeder No / Name : 203 / 11KV Kakad AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9602	1.0288	1.7187	1.3226	.724	.4382	.6001
2	.9602	1.0174	1.6827	1.286	.7421	.4382	.6001
3	.9431	1.0288	1.6476	1.286	.724	.4207	.6001
4	.9259	1.0288	1.6126	1.2717	.7421	.4207	.5935
5	.8573	1.0288	1.595	1.2346	.724	.4908	.5487
6	1.0288	1.0288	1.5775	1.2003	.7842	.4557	.463
7	.9326	1.1145	1.7177	1.1145	.905	.4382	.5144
8	1.0288	1.2887	1.8229	1.2346	1.0288	.5609	.6859
9	1.8519	1.3032	1.9281	.6001	1.086	.5959	.8916
10	.823	1.749	1.4723	1.749	1.3717	.4733	1.3717
11	1.3717	1.8229	1.4403	1.9204	1.3496	.4908	1.2003
12	1.4403	1.858	1.6289	1.9204	1.262	.6036	1.0288
13	1.3717	1.8404	1.4575	1.9204	1.2094		1.7147
14	1.286	1.8229	1.4575	1.8861	1.0166	.6173	1.5775
15	1.3032	1.8404	1.4413	1.7147	.6836	.679	1.7833
16	1.3032	1.9004	1.5261		.8764	.6344	1.8004
17		1.7528	1.4575	.7621	.7888	.6443	1.8004
18			.0187			.0189	
19	.0189		.0189			.0189	
20	.0189		.0175			.0189	
21	.0189		.0189	.0175		.0189	
22	.0189		.0189	.0175			
23			.0189	.0191		.0189	.0191
24	.8916	1.1145	1.5775	1.3375	.7421	.4557	.6173
Max	1.8519	1.9004	1.9281	1.9204	1.3717	.679	1.8004
Min	.0189	1.0174	.0175	.0175	.6836	.0189	.0191
Avg	.9217	1.4205	1.2031	1.1908	.9311	.4069	.9690



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CITY SUB-DN[307] BU 3077

Substation No/ Name :- 034015 / 33KV RASEGAON

Feeder No / Name : 204 / 11KV Yeota gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1509	.1402	.1509	.1524	.1227	.132
2	.1509	.1509	.1402	.1509	.1524	.1227	.132
3	.1509	.1509	.1402	.1509	.1334	.1227	.132
4	.1509	.1509	.1227	.1494	.1334	.1227	.132
5	.132	.1494	.1052	.1494	.1334	.1052	.132
6	.1132	.1132	.1052	.112	.1143	.1052	.1132
7	.0943	.1132	.0876	.1132	.0953	.0876	.0943
8	.0943	.1132	.1052	.1132	.0953	.0876	.0943
9	.0943	.1132	.0876	.0943	.1132	.0876	.0943
10	.0943	.1132	.1052	.1132	.1132	.0876	.0934
11	.0754	.1052	.1132	.1143	.1052	.0934	.0943
12	.0943	.0876	.112	.1143	.0876	.0943	.0943
13	.1132	.1227	.132	.132	.0876		.0943
14	.132	.1227	.1494	.1334	.0876	.0943	.1143
15	.132	.1227	.1509	.1334	.0876	.0934	.1143
16	.132	.1227	.132		.0876	.0943	.1143
17		.1052	.112	.0953	.1052	.0943	.0943
18	.0943	.0876	.0934	.0876	.1052	.0943	
19	.1132	.0876	.1132	.1143	.1227	.1132	
20	.1509	.1578	.1509	.1715	.1402	.1509	.1698
21		.1578	.1509	.1905	.1402	.1698	.1715
22	.1698	.1227	.1698	.1905	.1402	.1509	.1715
23	.1698	.1578	.1698	.1905	.1402	.1509	.1715
24	.1509	.168	.1402	.1494	.1905	.1227	.1509
Max	.1698	.168	.1698	.1905	.1905	.1698	.1715
Min	.0754	.0876	.0876	.0876	.0876	.0876	.0934
Avg	.1252	.1270	.1262	.1354	.1193	.1117	.1229

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CITY SUB-DN[307] BU 3077

Substation No/ Name :- 034015 / 33KV RASEGAON

Feeder No / Name : 205 / 11 SURWADA AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9326		1.1145	.9231		.1886
2		.9221		1.1022	.9231		.1886
3		1.4754		1.1145	.905		.1886
4		.9326		1.0898	.905		.1886
5		.9431		1.0974	.9231		.1886
6		.9835		1.1361	.9412		.2058
7		1.1191		1.286	1.0136		.2374
8		1.4575		1.3375	.9431		.2401
9		1.3717		1.406	1.0288		.4287
10	1.1145		1.4723			.2454	
11	1.3717		1.5432			.2058	
12	1.3717		1.6289			.2035	
13	1.286		1.4575				
14	1.286		1.4918			.2035	
15	1.286		1.5432			.2058	
16	1.286		1.6289			.2058	
17	1.286		.3429			.2058	
24		.9431		1.1361	.905		.1886
Max	1.3717	1.4754	1.6289	1.406	1.0288	.2454	.4287
Min	1.1145	.9221	.3429	1.0898	.905	.2035	.1886
Avg	1.2860	1.1081	1.3886	1.1820	.9411	.2108	.2244

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CITY SUB-DN[307] BU 3077

Substation No/ Name :- 034015 / 33KV RASEGAON

Feeder No / Name : 206 / 11 KV Rasegaon gaothan  
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2696	1.1949	1.1744	1.251	1.0288	.9465	.9431
2	1.2696	1.2071	1.1393	1.251	1.0185	.9465	.9431
3	1.251	1.1949	1.1393	1.2323	1.0185	.8764	.9431
4	1.2323	1.1576	1.0692	1.2323	.9997	.8764	.9431
5	1.1883	1.1317	.9816	1.1576	.9997	.8413	.9054
6	.9431	.9808	.9114	.9522	.9431	.7888	.8299
7	.8402	.811	.7712	.7922	.7922	.6485	.7167
8	.7922		.7186	.811	.743	.5784	.679
9	.8215	.5658	.7712	.7733	.8192	.5068	
10	.8402	.5601	.7783	.8488	.7545	.4557	
11	.9431	.5083	.8402	.9717	.7186	.4904	.7545
12	1.0185	.631	.9808	.9619	.6485	.3772	.7545
13	1.1389	.7362	1.1317	1.1622	.5609		.7733
14	1.1317	1.0692	1.2071	1.2384	.5083	.5658	.7545
15	1.226	1.0166	1.1949	1.2193	.6836	.5281	.9242
16	1.0456	.9816	1.1203	1.1218		.6602	.679
17	.8589	.8939	.9431	.7811	.2454	.6413	.6036
18	.8488	.8238	.6535	.8002	.6024	.6602	.5609
19	.8299	.8238	.8589	.8488	.6661	.7922	
20	1.1694	1.1043	1.1763	1.1431	.8063	1.0269	1.1128
21	1.251	1.262	1.2696	1.2955	.8238	1.0374	1.094
22	1.2136	1.2971	1.3203		1.0166	1.0185	1.1431
23	1.2323	1.2094	1.3203	1.1812	.9816	.9997	1.2574
24	1.307	1.1763	1.1568	1.2696	1.1506	.9465	.9619
Max	1.307	1.2971	1.3203	1.2955	1.1506	1.0374	1.2574
Min	.7922	.5083	.6535	.7733	.2454	.3772	.5609
Avg	1.0693	.9712	1.0262	1.0564	.8056	.7482	.8703

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CITY SUB-DN[307] BU 3077

Substation No/ Name :- 034015 / 33KV RASEGAON

Feeder No / Name : 207 / 11KV ESEGAON AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6289		1.5775			.1578	
2	1.5927		1.5775			.1578	
3	1.5592		1.6126			.1578	
4	1.5947		1.5775			.1753	
5	1.5775		1.4899			.1753	
6	1.4575		1.4198			.1753	
7	1.5775		1.5424			.1578	
8	1.6108		1.5424			.1753	
9	1.7147		1.6301			.1928	
10		1.5432		1.7147	1.0288		.7716
11		1.6476		1.8861	1.0517		1.2003
12		1.8404		1.7147	1.0692		1.3003
13		1.5775		1.8004	.7011		1.387
14		1.7703		1.7147	.5434		1.2003
15		1.7878		1.7147	.4207		1.2003
16		1.8054			.4031		1.3717
17		1.8229		1.2003	.3155		1.3717
19				.0191			
24	1.6289		1.4451			.1578	
Max	1.7147	1.8404	1.6301	1.8861	1.0692	.1928	1.387
Min	1.4575	1.5432	1.4198	.0191	.3155	.1578	.7716
Avg	1.5942	1.7244	1.5415	1.4706	.6917	.1683	1.2254

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CITY SUB-DN[307] BU 3077

Substation No/ Name :- 034016 / 33KV ASEGAON

Feeder No / Name : 201 / 11 KV Asegaon Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0288		1.5432	.6097	.0381	.8573
2		1.0288		1.5432	.6401	.0381	.8573
3		1.2003	2.5911	1.5432	.6401	.0381	.8573
4		1.2003	2.5911	1.5432	.6554	.0381	.6859
5		1.2003	2.5911	1.5432	.6554	.0381	.6859
6		1.3717	2.4387	1.6118	.6859	.0381	.6859
7		1.3717	2.7435	1.6461	.6859	.0381	1.2003
8	1.8861	1.3717	2.8959	1.6975	.6097	.0762	1.0288
9	1.8861	1.2003	2.8959	1.8004	.4572	.0762	1.2003
10	1.0669	2.5339	1.2193	3.7723	1.5242		.1715
11	1.3717	2.8959	1.6804	3.5056	1.5242		.5144
12	1.0669	2.5911	1.7147	2.6673			.7202
13	1.0669	2.5911	1.8176	2.6673			.823
14	1.2193	2.5911	1.8004	2.6673		.6859	.8573
15	1.2193	2.7435	1.7147	2.6673		.8573	1.0974
16		3.0864	1.8004			.1715	1.0974
17		2.7435	1.7147	1.829		.1715	1.2346
18	1.0669			1.829			
19	1.0669					.8573	
24	3.2579	1.0288		1.5432	.6097	.0381	.8573
Max	3.2579	3.0864	2.8959	3.7723	1.5242	.8573	1.2346
Min	1.0669	1.0288	1.2193	1.5432	.4572	.0381	.1715
Avg	1.4704	1.8766	2.1473	2.0900	.7748	.2134	.8573

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CITY SUB-DN[307] BU 3077

Substation No/ Name :- 034016 / 33KV ASEGAON

Feeder No / Name : 202 / 11 KV Sawalapur Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5775	2.1338	1.4327	2.7435	1.6766	.2401	.5144
2	1.5432	2.1338	1.4327	2.7435	1.6766	.2401	.5144
3	1.5432	2.1338	1.4327	2.7435	1.6766	.2401	.5487
4	1.4918	2.2862	1.3717	2.7435	1.7528	.2401	.583
5	1.4746	2.2862	1.3717	2.7435	1.7833	.2401	.6173
6	1.4746	2.2862	1.2955	2.7435	1.7833	.2401	.6859
7	1.6461	2.4082	1.4937	2.7435	1.7833	.2401	.6859
8	1.8004	2.4082	1.6309	3.0007	1.8442	.2401	1.0117
9	1.8861	2.3472	1.6766	3.0007	1.8442	.2401	1.0288
10	2.5911	1.7071	2.4387		1.1431		.5144
11	2.8959	1.7071	2.8121	.8688	1.1431		.5144
12	2.5606	1.6766	3.1207	1.6766	1.2003		.7202
13	2.7435	1.5851	3.0521	1.829			.7716
14	2.7435	1.829	2.915	1.829		.3429	.7716
15	2.7435	1.829	3.155	1.829		.0343	1.0288
16	2.4844	1.9204	3.1722	1.0669	.2401	.0343	1.166
17	2.4844	1.5242	3.1722	1.0669	.2401	.6001	1.2346
18				1.0669			
24	1.5947	2.1338	1.4327	2.7435	1.5242	.2401	.4973
Max	2.8959	2.4082	3.1722	3.0007	1.8442	.6001	1.2346
Min	1.4746	1.5242	1.2955	.8688	.2401	.0343	.4973
Avg	2.0711	2.0187	2.1338	2.1768	1.4208	.2438	.7449

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CITY SUB-DN[307] BU 3077

Substation No/ Name :- 034016 / 33KV ASEGAON

Feeder No / Name : 205 / 11KV ASEGAON(GAOTHAN)  
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	22-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.166		.9602
2	1.166		.9602
3	1.1831		.9088
4	1.0288		.8573
5	.9774		.8573
6	.8916		.823
7	.9774		.6344
8	.7373		1.0117
9	.7373		.5658
10			.9774
11			1.0631
15		1.0288	
16		1.0288	
17		.9431	
18		.9774	
19		1.0802	
20		1.3375	
21		1.0288	
22		.9945	
23		.9945	
24	1.2003		.9774
Max	1.2003	1.3375	1.0631
Min	.7373	.9431	.5658
Avg	1.0065	1.0460	.8831

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CITY SUB-DN[307] BU 3077

Substation No/ Name :- 034034 / 33 KV ASADPUR

Feeder No / Name : 201 / 11 Kv Asadpur AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0667	.4001	.04	.0533		
2		.0667	.4001	.04	.0533		
3		.0667	.4001	.04	.0533		
4		.0667	.4001	.04	.0533		
5		.08	.4001	.04	.0533		
6		.08	.4001	.04	.0533		
7		.08	.4534	.0533	.0533		
8		.08	.5068	.0533	.0533		.0133
9		.0934	.5068	.04	.04		.0133
10	.1067		.0533		.4801	.0533	
11	.1067		.0533		.4801	.0533	
12	.1067		.0533		.4268	.0533	
13	.1067		.0533		.2667	.0533	
14	.1334				.2667	.0533	
15	.1334				.2134	.0533	
16	.1334		.0533		.2134	.04	
17	.1467		.0533		.2134	.04	
24	.0533		.04	.0533	.2401		
Max	.1467	.0934	.5068	.0533	.4801	.0533	.0133
Min	.0533	.0667	.04	.04	.04	.04	.0133
Avg	.1141	.0756	.2642	.0440	.1815	.0500	.0133



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CITY SUB-DN[307] BU 3077

Substation No/ Name :- 034034 / 33 KV ASADPUR

Feeder No / Name : 202 / 11 KV Wadgaon

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2134	
2				.16	
3				.1867	
4				.1867	
5	.4801			.2134	
6				.2134	
7				.1334	
8				.1334	
9	.5868			.16	
10		.5335	.4801		.4001
11		.5601	.4801		.5335
12		.5601	.4877		.5601
13		.5601			.5868
14		.5601			.6135
15		.6401			.5601
16		.5335			.5601
17		.4801			.5868
24					.5068
Max	.5868	.6401	.4877	.2134	.6135
Min	.4801	.4801	.4801	.1334	.4001
Avg	.5335	.5535	.4826	.1778	.5453

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CITY SUB-DN[307] BU 3077

Substation No/ Name :- 034034 / 33 KV ASADPUR

Feeder No / Name : 205 / 11 Kv Asadpur Gaonthan  
Feeder KV- 11 / OUTGOING

Gaonthan Feeder

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.8535			.5335	.5601	
2	.6401	.8535	.8535		.5335	.6135	
3	.6401	.8535	.8535		.5335	.5868	
4	.6401	.8535	.8535		.5335	.6001	
5	.6401	.7316	.7621		.5335	.5601	
6	.6401	.6097	.6554		.5335	.4801	
7	.4268	.5182	.5792		.4801	.3734	
8	.4268	.4725	.5182		.4801	.2667	
9	.4268	.4572	.503		.4877	.2667	.4268
10	.4572	.6097	.5792	.4001	.4268	.3201	.5335
11	.5639	.6097	.6097	.4134	.4001	.3201	
12	.6401	.6097	.6401	.4134	.4268	.3201	
13	.6859	.6097	.6706	.5868		.3201	
14	.6401	.6401	.6859	.6401	.2667	.3201	
15	.6401	.6097	.6859	.6401		.3201	
16	.6249			.5335	.061		
17	.5182	.3201	.5944		.4268		
18	.6097	.5792	.6097	.3201	.4801		
19	.7011	.7316	.7316				
20	.7926	.823	.7621				
21	.7926	.8535	.7773				
22	.8535	.884					
23	.884	.8535	.8535				
24	.884	.8535		.5335		.5335	
Max	.884	.884	.8535	.6401	.5335	.6135	.5335
Min	.4268	.3201	.503	.3201	.061	.2667	.4268
Avg	.6420	.6865	.6889	.4979	.4461	.4226	.4802

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CITY SUB-DN[307] BU 3077

Substation No/ Name :- 034048 / 33 KV Parasapur

Feeder No / Name : 201 / tawlar

Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	27-JUN-17
HR	Load (MW)
9	1.7528
Max	1.7528
Min	1.7528
Avg	1.7528

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CITY SUB-DN[307] BU 3077

Substation No/ Name :- 034048 / 33 KV Parasapur

Feeder No / Name : 202 / gaothan parsapur

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4373	.7602	1.8296	.6661	.7522	.7888	.6722
2	1.5074	.7602	1.848	.5959	.7522	.7888	.6535
3	1.5775	.7602	1.8484	.5959	.7522	.8413	.5975
4	1.7177	.7602	1.7924	.5258	.7522	.8413	.5601
5	1.7528	.6516	1.7737	.5609	.7164	.8764	.5601
6	1.7878	.6154	1.7924	.631	.6447	.8764	.5975
7	1.858	.543	1.6804	.4031	.5731	.929	.3292
8	1.9993	.5121	1.9044	.4557	.5487	.8764	.5788
9	1.9427	.4755	1.9387	.4557	.5487	.8764	.5601
10	.1753	1.3375	.7133	1.8054	1.166		1.5912
11	.1052	1.6766	.8299	2.1033	.8916	.5959	1.5729
12	.1227	1.7101	.6602	2.1559		.5258	1.7375
13	.2561	1.9204	.7545	2.1795	1.0517	.5415	1.6095
14	.5487	1.6461	.7712	2.1795	1.262	.6161	1.6095
15		1.7193	.7537	.5853	1.0166	.5975	1.6766
16	.3658	1.2803	.6485	1.1317	1.2795	.6161	1.6766
17	.6089	1.9387	.6661	1.0974	1.3146	.6908	1.5424
18		.7095	.6661	.5487	.5609	.5415	.5853
19	.0754	.6908	.7362	.5487	.5784	.6722	.6584
20	.8954	.8402	.8238	.7682	.7011	.8029	.7316
21	.8954	.8589	.8413	.8048	.6836	.7468	.7682
22	.8954	.8962	.8589	.8048	.6836	.7468	.8048
23	.8417	.8029	.8238	.7522	.6135	.7282	.8048
24	1.3672	.7522	1.8671	.6661	.7522	.7362	.6722
Max	1.9993	1.9387	1.9387	2.1795	1.3146	.929	1.7375
Min	.0754	.4755	.6485	.4031	.5487	.5258	.3292
Avg	1.0334	1.0258	1.2009	.9592	.8085	.7327	.9646

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CITY SUB-DN[307] BU 3077

Substation No/ Name :- 034048 / 33 KV Parasapur

Feeder No / Name : 203 / wadgaon ( F )

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6661	.8596	.6535	.1052	.8916	.2454	.2614
2	.7362	.8596	.6348	.1052	.8916	.2804	.2614
3	.8413	.8596	.6468	.1402	.8916	.2804	.2614
4	.964	.8596	.6535	.1402	.8916	.3155	.2427
5	1.0517	.8596	.6653	.1402	.8916	.3856	.2427
6	1.0867	.8954	.6653	.1402	.9602	.4557	.2614
7		.9465	.8589	.1402	1.0631	.5258	.3292
8		.9816	1.0242	1.1919	1.166	.5959	.3734
9	.0754	.9816	1.0425	1.4723	1.1317	.5609	.3361
10	1.6221		1.2437	1.6827	.823		.8962
11	1.5074		1.5844	2.0683	.9259	.1402	1.0974
12	1.5074	.2926	1.6598	1.9982		.1402	1.2803
13	1.4754		1.6598	1.7436	.8413	.2987	1.1317
14	1.4746		1.6126	1.6766	.8413	.3361	1.166
15	.9945	.9145	1.6476	.8916	.8413	.3177	1.2003
16	1.0277	1.0242	1.4723	.823	.8413	.3361	1.2346
17	.9945	1.0288	1.4723		.7011	.3174	1.166
24	.6661	.8596	.6535	.1052	.9114	.2454	.2561
<b>Max</b>	<b>1.6221</b>	<b>1.0288</b>	<b>1.6598</b>	<b>2.0683</b>	<b>1.166</b>	<b>.5959</b>	<b>1.2803</b>
<b>Min</b>	<b>.0754</b>	<b>.2926</b>	<b>.6348</b>	<b>.1052</b>	<b>.7011</b>	<b>.1402</b>	<b>.2427</b>
<b>Avg</b>	<b>1.0432</b>	<b>.8731</b>	<b>1.1028</b>	<b>.8568</b>	<b>.9121</b>	<b>.3398</b>	<b>.6666</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CITY SUB-DN[307] BU 3077

Substation No/ Name :- 034048 / 33 KV Parasapur

Feeder No / Name : 205 / PACHAMBA

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4207	.2926		.0747
2			.5258	.2926		.0747
3			.5959	.2926		.0747
4			.6661	.2926		.0747
5			.7011	.2926		.0747
6			.7186	.2926		.0747
7			.8413	.4024		.112
8			.9991	.4908		.1646
9		.2926	1.0166	.4656		.168
10	.9145	.2987			.0876	
11	.964	.4338			.1402	
12	1.0517	.4527			.1402	
13	.9945	.4207				
14	.9389	.4557				
15		.4557				
16		.4733				
17		.7712			.112	
18		.6135				
19		.6485				
20		.6485				
21		.631				
22		.6485				
23		.6661				
24			.4908	.2865		.0732
Max	1.0517	.7712	1.0166	.4908	.1402	.168
Min	.9145	.2926	.4207	.2865	.0876	.0732
Avg	.9727	.5274	.6976	.3401	.12	.0966

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR CITY SUB-DN[307] BU 3077

Substation No/ Name :- 034048 / 33 KV Parasapur

Feeder No / Name : 206 / KHANJMANAGAR

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6878		.9114	.7362		.4938
2		.6878		.9465	.7362		.4755
3		.6878		1.0517	.7362		.4755
4		.6878		1.1919	.7362		.4938
5		.724		1.2269	.7362		.5121
6		.7602		1.262	.7362		.5487
7		.8764		1.4548	.8916		.6401
8		.9816		1.6301	1.0974		.8048
9		1.0288		1.5249	1.1317		.7865
10			1.4083				
11	1.8229		1.6787			.5258	
12	1.9281		1.7353			.5609	
13	1.6712		1.7541			.6348	
14	1.5424		1.6827			.5975	
15			1.5424			.5975	
16			1.4899			.5601	
17	.9054		1.4373			.6908	
24		.6878		.8413	.7362		.4938
Max	1.9281	1.0288	1.7541	1.6301	1.1317	.6908	.8048
Min	.9054	.6878	1.4083	.8413	.7362	.5258	.4755
Avg	1.574	.781	1.5911	1.2042	.8274	.5953	.5725

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR II S/DN.[767] BU 4767

Substation No/ Name :- 034078 / 33 KV PARATWADA SUBSTATION

Feeder No / Name : 211 / CIVIL LINE Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3673	.3265	.3265	.299	.2566
2		.3482	.3265	.3268	.2963	.2433
3		.3515	.3087	.3087	.2799	.2605
4		.3333	.2908	.3083	.2761	.2428
5		.3406	.2908	.309	.2569	.2205
6		.2803	.2542	.2729	.2236	.2207
7		.2746	.236	.2368	.2205	.2633
8		.2566	.2177	.1816	.2081	.2079
9		.2583	.2179	.2183	.2079	.2251
10		.2617	.2542	.2545	.2441	.243
11		.2978	.2721	.255	.207	.2425
12		.3161	.2723	.3096	.2264	.2534
13		.3334	.3268	.2365	.221	.2482
14		.336	.2177	.2001	.2012	.2211
15		.3514	.2179	.1999	.2228	.2249
16			.236	.2368	.2183	.2438
17		.398	.2721	.2181	.2361	.2684
18		.3159	.2542	.2183	.2374	.2826
19		.2773	.2545	.2363	.2402	.2662
20		.3299	.2911	.2726	.2446	.2749
21	.3162	.2958	.2545	.2368	.2384	.2767
22	.3138	.3008	.2726	.2735	.2598	.2815
23	.3808	.3338	.3093	.2726	.2787	.3181
24		.3704	.3511	.3268	.2729	.2591
Max	.3808	.398	.3511	.3268	.299	.3181
Min	.3138	.2566	.2177	.1816	.2012	.2079
Avg	.3369	.3187	.2719	.2598	.2424	.2519



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR II S/DN.[767] BU 4767

Substation No/ Name :- 034078 / 33 KV PARATWADA SUBSTATION

Feeder No / Name : 212 / WAGHAMATA Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4389	.4353	.4371	.3639	.3708
2		.4439	.4361	.4362	.3536	.3519
3		.4462	.3986	.4367	.3683	.3288
4		.424	.3995	.4003	.3504	.2971
5		.4285	.3963	.4003	.3522	.3696
6		.424	.38	.3994	.3701	.3302
7		.3482	.3326	.3813	.3519	.3144
8		.3526	.3197	.3809	.3334	.3175
9		.3337	.2928	.2908	.2772	.298
10		.3302	.2928	.2545	.2946	.3486
11		.3841	.3126	.3461	.3144	.2958
12	.4199	.3863	.3861	.309	.2808	.3173
13	.4035	.3719	.3496	.2905	.2418	.2956
14	.3863	.388	.3537	.2726	.2587	.3144
15	.399	.2919	.3467	.2911	.2583	.3316
16	.3841	.3859	.3452	.2729	.2811	.3162
17	.389	.3906	.3374	.2914	.2893	.3116
18	.4059	.3726	.3518	.3087	.2943	.3319
19	.4384	.2781	.3537	.3643	.3867	.4062
20	.4613	.2844	.4299	.3813	.3867	.4338
21	.4488	.4471	.4253	.3821	.3559	.3879
22	.4718	.4366	.42	.3994	.3485	.414
23	.4617	.4783	.4088	.4003	.3877	.4222
24		.4366		.4415	.3639	.3671
Max	.4718	.4783	.4361	.4415	.3877	.4338
Min	.3841	.2781	.2928	.2545	.2418	.2956
Avg	.4225	.3876	.3698	.3570	.3277	.3447

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR II S/DN.[767] BU 4767

Substation No/ Name :- 034078 / 33 KV PARATWADA SUBSTATION

Feeder No / Name : 213 / JAYASTAMBH Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3123	.3265	.3994	.2814	.2808
2		.3141	.2908	.399	.2823	.2641
3		.3026	.2908	.3809	.2527	.2428
4		.2922	.2905	.3994	.2628	.2645
5		.2872	.2905	.3628	.2641	.2464
6		.2763	.2726	.2723	.2583	.2569
7		.2379	.236	.2547	.2446	.2243
8		.2409	.2545	.2363	.2163	.2052
9		.2464	.236	.236	.221	.2084
10		.2767	.2911	.2363	.2564	.2821
11		.4402	.4185	.3457	.3675	1.0433
12	.6634	.5042	.4918	.3821	.4426	1.1265
13	.5926	.5491	.4913	.3635	.3703	1.0978
14	.5852	.5449	.51	.3635	.3865	1.1288
15	.6264	.5849	.51	.3813	.3719	1.2119
16	.6333	.5549	.4907	.418	.4052	
17	.6033	.5719	.4736	.4185	.3744	1.3385
18	.5594	.5356	.5276	.418	.3673	1.263
19	.6309	.5889	.5652	.4913	.4767	1.4073
20	.6595	.6755	.6193	.51	.4753	1.4984
21	.5938	.6026	.5816	.4731	.3194	1.4447
22	.4983	.4983	.51	.3453	.3139	1.2878
23	.4059	.3883	.4736	.2908	.2811	1.2163
24		.3809	.3326	.3999	.2732	.2826
Max	.6634	.6755	.6193	.51	.4767	1.4984
Min	.4059	.2379	.236	.236	.2163	.2052
Avg	.5877	.4253	.4073	.3658	.3236	.7749

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR II S/DN.[767] BU 4767

Substation No/ Name :- 034078 / 33 KV PARATWADA SUBSTATION

Feeder No / Name : 214 / BAITUL ROAD Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3532	1.3646	1.3711	1.1812	1.1396
2		1.2666	1.366	1.3557	1.1979	1.1211
3		1.2976	1.3675	1.369	1.1957	1.1002
4		1.2702	1.2723	1.3371	1.1451	1.0822
5		1.2263	1.1814	1.3072	1.1517	1.1211
6		1.1366	1.1814	1.2603	1.1078	1.1008
7		1.0828	1.1293	1.2281	1.0717	1.1086
8		1.084	1.0553	.9896	1.0291	1.0586
9		.995	1.0382	1.0078	.9217	1.0392
10		1.0437	1.036	.9105	1.0022	
11		1.0699	1.0917	1.0241	.9745	
12	1.3141	1.1157	1.1293	1.0064	1.0111	
13	1.3159	1.2437	1.1463	.9167	.9735	
14	1.2729	1.1526	1.0928	.9533	.9645	
15	1.2759	1.2124	.9815	.9217	.983	
16	1.2503	1.2666	1.0894	.9947	.8749	
17	1.2648	1.2137	1.1122	.9685	.9089	
18	1.2029	1.001	1.2385	1.0153	1.0789	
19	1.3391	1.1359	1.2398	1.1187	1.1944	
20	1.3618	1.4232	1.3114	1.1826	1.2276	
21	1.3723	1.3547	1.3114	1.1616	1.1366	
22	1.4006	1.4142	1.3114	1.1976	1.1917	
23	1.4611	1.3872	1.3842	1.2391	1.1935	
24		1.4414	1.3983	1.3842	1.1804	1.1487
Max	1.4611	1.4414	1.3983	1.3842	1.2276	1.1487
Min	1.2029	.995	.9815	.9105	.8749	1.0392
Avg	1.3193	1.2162	1.2013	1.1342	1.0791	1.1020

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR II S/DN.[767] BU 4767

Substation No/ Name :- 034081 / 33/11 KV SULTANPURA

SUBSTATION

Feeder No / Name : 201 / 11 KV ACHALPUR TOWN NO. 2 Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5746	1.5203	1.6244	1.5203	1.4842	1.307	1.2308
2	1.5565	1.4842	1.6244	1.5203		1.307	1.2127
3	1.5565	1.4842	1.5684	1.5023	1.4661	1.2696	1.1765
4	1.5384	1.4118	1.5684	1.4842	1.448	1.2136	1.1222
5	1.448	1.3032	1.3443	1.4118	1.4118	1.1389	1.1222
6	1.3394	1.2308	1.2883	1.2489	1.267	1.0456	1.086
7	1.1946	1.1041	1.1576	1.1041	1.1946	1.0082	.9774
8	1.1041	1.0679	1.0829	1.0136	1.2127	.9335	.905
9	1.0679	1.0136	1.0642	1.0136	1.086	.8775	.8145
10	1.1222	1.0317	1.0829	1.0498	1.0317	.8775	.8507
11	1.1403	1.0829	1.1222	1.086	1.0456	.8145	.8326
12	1.1946	1.1576	1.1403	1.1946	1.0082	.7059	.9412
13	1.267	1.17	1.1765	1.2851	.9896	.8145	.9412
14	1.3213	1.2323	1.267	1.267	.9522	.8507	.9955
15	1.3756	1.2883	1.2851	1.1403	.9522	.8507	1.0317
16	1.0317	1.2883	1.267	1.1222	.9522	.8507	1.0679
17	1.2127	1.1763	1.2489	1.086	.9149	.8507	.9955
18	1.1041	1.1763	1.086	1.1041	.9896	.8869	.9774
19	1.2308	1.251	1.1403	1.2489	1.1389	1.0498	1.0136
20	1.3756		1.3937	1.3937	1.2323	1.267	1.267
21	1.4118	1.5123	1.448	1.4299	1.251	1.267	1.3756
22	1.5023	1.5497	1.5023	1.4661	1.307	1.2308	1.4661
23	1.5384	1.643	1.5565	1.5203	1.3256	1.2489	1.4661
24	1.6289	1.5023	1.6244	1.5565	1.5023	1.307	1.2308
Max	1.6289	1.643	1.6244	1.5565	1.5023	1.307	1.4661
Min	1.0317	1.0136	1.0642	1.0136	.9149	.7059	.8145
Avg	1.3266	1.2905	1.3193	1.2821	1.1810	1.0406	1.0875

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR II S/DN.[767] BU 4767

Substation No/ Name :- 034081 / 33/11 KV SULTANPURA

SUBSTATION

Feeder No / Name : 202 / 11 KV ACHALPUR TOWN NO. 1 Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3756	1.3032	1.419	1.4118	1.3575	1.1576	1.1765
2	1.3575	1.267	1.4003	1.4118	1.3394	1.1576	1.1946
3	1.3394	1.267	1.4003	1.3756	1.3032	1.1203	1.1765
4	1.3394	1.2308	1.307	1.3394	1.3213	1.1389	1.086
5	1.2851	1.1765	1.2136	1.2308	1.3394	1.1203	1.086
6	1.2127	1.1584	1.1576	1.1403	1.2489	1.0082	1.0317
7	1.086	1.0317	1.1203	1.0317	1.1584	1.0456	.9955
8	1.0498	.9774	.9709	.9412	1.086	.8962	.8869
9	.905	.905	.8962	.9412	1.0136	.8215	.8326
10	.8688	.905	.8962	.9412	.905		.7964
11	.905	.9709	.905	.9774	.8962	.7602	.8326
12	.905	1.1576	.905	1.0136	.8589	.7602	.8326
13	1.086	1.1576	.9774	1.086	.8402	.7602	.8326
14	1.1222	1.1203	1.086	1.0136	.8589	.6878	.8688
15	1.1222	1.1203	1.086	.9955	.8589	.7602	.905
16	1.0136		1.086	.9593	.8589	.724	.905
17	1.0136	1.0456	1.0498	.9231	.8589	.724	.8145
18	.9774	1.0082	.9412	.9412	.8589	.7964	.8326
19	1.0679	1.0829	1.0136	1.086	1.0829	.905	.9774
20	1.2127		1.2489	1.1946	1.1203	1.1403	1.1403
21	1.0136	1.2696	1.2308	1.1946	1.1389	1.086	1.1946
22	1.267	1.3817	1.3032	1.267	1.1576	1.086	1.267
23	1.3575	1.419	1.4118	1.3756	1.3256	1.3032	1.267
24	1.4299	1.3032	1.419	1.3756	1.3394	1.1949	1.3032
<b>Max</b>	<b>1.4299</b>	<b>1.419</b>	<b>1.419</b>	<b>1.4118</b>	<b>1.3575</b>	<b>1.3032</b>	<b>1.3032</b>
<b>Min</b>	<b>.8688</b>	<b>.905</b>	<b>.8962</b>	<b>.9231</b>	<b>.8402</b>	<b>.6878</b>	<b>.7964</b>
<b>Avg</b>	<b>1.1380</b>	<b>1.1481</b>	<b>1.1435</b>	<b>1.1320</b>	<b>1.0886</b>	<b>.9632</b>	<b>1.0098</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ACHALPUR II S/DN.[767] BU 4767

Substation No/ Name :- 034081 / 33/11 KV SULTANPURA

SUBSTATION

Feeder No / Name : 204 / 11 KV NIJAMPUR AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	25-JUN-17	26-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6842	1.749		.2267
2	1.6518	1.7328		.2105
3	1.668	1.7652		.2105
4	1.749	1.6518		.2105
5	1.7814	1.7166		.2429
6	1.4737	1.7814		.2915
7	1.6194	1.7976		.3125
8	1.8138	1.8947		.3887
9	1.9271	2.1376		.4858
10	1.8623	2.2186	.4534	.502
11	2.0005	2.2348	.5441	.5973
12	1.9845	2.2672		.8322
13	2.0965	2.3482		.8962
14	1.9204	2.1862	.3521	1.4083
15	1.8084	2.1862	.3521	1.3763
16			.3681	1.7764
17	2.1125	.4696	.3201	1.8884
24	1.7166	1.7166		.2267
Max	2.1125	2.3482	.5441	1.8884
Min	1.4737	.4696	.3201	.2105
Avg	1.8159	1.8738	.3983	.6713

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ANJANGAON SUB-DN[304] BU 1627

Substation No/ Name :- 034009 / 33KV PATHROT

Feeder No / Name : 201 / 11 KV PATHROT [AG]

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	26-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.4939		2.4249
2		2.4939		2.4249
3		2.4939		2.4249
4		2.5587		2.5232
5		2.6235		2.6216
6		2.7044		2.769
7		2.753		2.9001
8		2.9473		2.9492
9		2.8178		2.9312
10			2.2939	
11	3.7031			
12	3.65			
13	3.5791			
14	3.6145			
15	3.5437		3.621	
16	3.3665		3.898	
17	3.3311		3.7209	
23			2.0567	
24		2.4939		2.2939
Max	3.7031	2.9473	3.898	2.9492
Min	3.3311	2.4939	2.0567	2.2939
Avg	3.5411	2.6380	3.1181	2.6263

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ANJANGAON SUB-DN[304] BU 1627

Substation No/ Name :- 034009 / 33KV PATHROT

Feeder No / Name : 202 / 11 KV SHINDI [AG]

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7814		1.9334			
2	2.0243		1.9334			
3	1.9433		1.9334			
4	1.9433					
5	2.0243		1.9334			
6	1.7101					
7	1.7101		1.9662			
8	1.7101		2.4086			
9	1.7101		2.0317			
10		2.0972			2.2043	
11		2.3739			2.3834	
12		2.1464		1.6385	2.2939	
13		2.1628		1.9989		.5731
14		2.1628		2.2611		.5959
15		2.1628		2.2611		.6447
16		2.1792		1.7619		
17		2.1628		1.6842		
24	1.7814		1.9334			
Max	2.0243	2.3739	2.4086	2.2611	2.3834	.6447
Min	1.7101	2.0972	1.9334	1.6385	2.2043	.5731
Avg	1.8338	2.1810	2.0092	1.9343	2.2939	.6046



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ANJANGAON SUB-DN[304] BU 1627

Substation No/ Name :- 034009 / 33KV PATHROT

Feeder No / Name : 204 / 11 KV PARSAPUR [AG]

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1401			1.2597		.2218
2		1.1736			1.2452		.2195
3		1.1736			1.2452		.2195
4		1.1736			1.278		.2378
5		1.2407			1.2944		.2378
6		1.3077			1.2944		.2378
7		1.3245			1.2944		.2378
8		.4207			1.491		
9		1.4586		1.6057	1.4746		.2926
10			1.3599			.2172	
11	1.4769					.2353	.2743
12	1.4769						
13	1.3611					.1402	
14	1.2178					.1227	
15	1.3611					.1052	
16	1.5947		1.448			.1509	
17	1.3032		1.419			.017	
23			1.3763				
24		1.1401		1.1469	1.2597		.2218
Max	1.5947	1.4586	1.448	1.6057	1.491	.2353	.2926
Min	1.2178	.4207	1.3599	1.1469	1.2452	.017	.2195
Avg	1.3988	1.1553	1.4008	1.3763	1.3137	.1412	.2401

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ANJANGAON SUB-DN[304] BU 1627

Substation No/ Name :- 034009 / 33KV PATHROT

Feeder No / Name : 205 / 11 KV SHAHANUR [EXPRESS] HV Non-Express Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0019				.0019
2			.0019				.0019
3			.0019				.0019
4		.0019	.0019				.0019
5			.0019				.0019
6	.0019	.0019	.0019				.0019
7	.0019		.0019				.0019
8	.0019		.0019				.0019
9	.0019	.0019			.0038		.0019
10	.0019		.0019	.0019	.0038		.0019
11	.0019	.0019			.0038		.0019
12	.0019				.0038		
13	.0019						
14	.0019						
15	.0019			.0019			
16	.0019		.0019	.0019			
17	.0019		.0019	.0019			
18			.0019	.0019		.0019	
19		.0019	.0019	.0019		.0019	.0019
20		.0019	.0019	.0019		.0019	.0019
21		.0019	.0019			.0019	.0019
22		.0019				.0019	.0019
23		.0019	.0017			.0019	.0019
24	.0018	.0019	.0019		.0019		.0019
Max	.0019	.0019	.0019	.0019	.0038	.0019	.0019
Min	.0018	.0019	.0017	.0019	.0019	.0019	.0019
Avg	.0019	.0019	.0019	.0019	.0034	.0019	.0019

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ANJANGAON SUB-DN[304] BU 1627

Substation No/ Name :- 034009 / 33KV PATHROT

Feeder No / Name : 206 / 11 KV PATHROT [G]

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5775	1.576		1.5775	1.262	1.2003
2		1.5775	1.5581				1.2003
3		1.56	1.5581				1.2003
4		1.5257	1.5581				1.2003
5		1.4217	1.576		1.4022		1.2003
6	1.5415	1.3672	1.379				1.166
7	1.2403	1.2269	1.2715				1.1488
8	1.2403	1.2445	1.2536		1.3496		1.1145
9	1.2403	1.2445			1.3146		1.1145
10	1.2403	1.2445	1.2269	1.1022	1.2445		1.046
11	1.258	1.2269			1.2795	1.1393	1.1568
12	1.3466			1.3847			1.0517
13	1.382			1.3847		1.2971	.9114
14	1.382			1.3847		1.1568	.9465
15				1.3146		1.0679	.9816
16	1.3466		1.3466	1.3112			.964
17	1.3466		1.3112	1.2403	1.0692		.964
18	1.2971	1.2269	1.382	1.382	1.2445	1.3112	1.0341
19	1.2971	1.3321	1.4352	1.5592		1.4175	1.3289
20	1.5424	1.576	1.701	1.6655		1.5384	1.4706
21	1.6651	1.5939	1.7187	1.6476		1.448	1.5061
22	1.6301	1.5939	1.4419	1.6476		1.3756	1.4883
23	1.5775	1.576	1.4419	1.5775		1.2934	1.4175
24		1.5775	1.576		1.5775	1.2971	1.2445
Max	1.6651	1.5939	1.7187	1.6655	1.5775	1.5384	1.5061
Min	1.2403	1.2269	1.2269	1.1022	1.0692	1.0679	.9114
Avg	1.3867	1.4274	1.4618	1.4309	1.3399	1.3004	1.1691

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ANJANGAON SUB-DN[304] BU 1627

Substation No/ Name :- 034029 / 33 KV BHANDARAJ

Feeder No / Name : 201 / 11 KV SATEGAON [G]  
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5043			1.4685	1.1584	1.1393	1.0745
2	1.4685			1.4327	1.1431	1.0749	1.0745
3	1.4327		1.1022	1.3969	1.1431	1.0174	1.0387
4	1.4327			1.3611	1.1431	.8669	1.0029
5	1.3432			1.3432	1.0974	.8139	1.0029
6	1.1641		.9431	1.1283	1.1317	.8139	.8954
7	.788		.8764	.8596	.8383	.7802	.7701
8	.8059		.7202	.8059	.7926		.7343
9	.788		.7455	.788	.7316	.5258	.7164
10	.8059		.9156	.8059	.8078		.7164
11	.8596		.9015	.9134	.7926	.3506	.724
12		.8764	.9362		.6661	.7164	.6554
13		.8718	1.0387	1.0288		.7164	
14		.9015	1.0387	.945	.6588	.7164	.8535
15			1.0745	.9907	.7802	.7164	.7926
16		.9326	.985	.8383	.6935	.7164	.8535
17		.8526	.8954	.6859		.7164	.6554
18		.8413	.8596	.7621	.763	.8417	.9755
19		.8322	1.1462	.945	1.0517	.8954	
20			1.3432	1.1431	1.2346	1.0745	.9907
21			1.4327	1.0669		1.182	1.1431
22			1.5043	.9755		1.1462	1.1431
23			1.5223	1.2193		1.0745	1.1431
24	1.5223		1.387	1.5043	1.1584	1.1919	1.0745
Max	1.5223	.9326	1.5223	1.5043	1.2346	1.1919	1.1431
Min	.788	.8322	.7202	.6859	.6588	.3506	.6554
Avg	1.1596	.8726	1.0684	1.0612	.9361	.8676	.9105

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ANJANGAON SUB-DN[304] BU 1627

Substation No/ Name :- 034029 / 33 KV BHANDARAJ

Feeder No / Name : 202 / 11 KV SATEGAON [AG]

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3375			1.4861	1.9814	.3506	1.1888
2	1.3375			1.4861	1.9814	.3429	1.2631
3				1.4861	2.0119		1.1888
4				1.4861	2.0119		1.1888
5				1.6347	2.0424		1.1888
6	1.4118		1.6956	1.9319		.373	1.3375
7	1.4861		1.8652	2.3282		.4239	1.4861
8	1.5604		2.0348	2.364	2.1033	.4681	1.8576
9	1.5604		2.0348	1.9616	2.0424	.3988	1.9319
10	2.0062		2.4272	2.2386	1.9814		.4904
11	2.0062		2.6006	2.3282	2.0119	2.1434	.5647
12		1.8442	2.3148	1.9814	1.8652	1.9319	
13		2.0957	2.3034	1.9814		2.0062	.5487
14		1.95	2.3034	2.0119	.3429	2.0062	.6097
15			2.2291	2.0576	.7282	1.9319	.6097
16		2.1219	2.2291	2.0729	.9536	1.9319	.6554
17		2.0348	2.2291	2.0424		2.0062	.6401
22			1.4861	2.0424		1.3375	.5335
23			1.4861			1.1888	.5487
24	1.4861		1.5261	1.5432	1.9814	.5201	1.1888
Max	2.0062	2.1219	2.6006	2.364	2.1033	2.1434	1.9319
Min	1.3375	1.8442	1.4861	1.4861	.3429	.3429	.4904
Avg	1.5769	2.0093	2.0510	1.9192	1.7171	1.2101	1.0011

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ANJANGAON SUB-DN[304] BU 1627

Substation No/ Name :- 034029 / 33 KV BHANDARAJ

Feeder No / Name : 204 / 11 KV NIMKHED [AG]

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.5373
2							.4477
3	1.2536		1.5261	1.0402		.5144	.4477
4	1.0745			1.0745		.5201	.5373
5	1.0745			1.0745	.6097	.5201	.5373
6	1.2536		1.5261	1.0745	.6097	.5935	.5373
7	1.6118		1.5604	1.4327	.9145	.6935	.5373
8	1.6118		1.8652	1.6118	1.0669	.6859	.7164
9	1.7909		1.8652	1.6118	.9145	.6859	.7164
10	1.2536		1.9071	2.1491	1.829		.7164
11	1.2536		2.3739	2.1491	1.829		.7164
12		1.8652	2.3739	2.1338	2.0348	.5373	
13						.5373	.6097
14						.5373	
15			1.97	1.829	.4854	.5373	.4572
16		1.8652	1.97	1.829	.6859	.5373	.6097
17		1.8882	1.8804	1.5242		.5373	.6097
18		1.8652	1.7909	1.5242	.5201	.5014	.6097
19		1.7337	1.7909	1.5242	.5258	.4477	
22			1.2536			.5373	
23			1.2536	.9145		.5373	
24	1.4327		1.3565	1.0745		.5487	.5373
Max	1.7909	1.8882	2.3739	2.1491	2.0348	.6935	.7164
Min	1.0745	1.7337	1.2536	.9145	.4854	.4477	.4477
Avg	1.3611	1.8435	1.7665	1.5042	1.0021	.5561	.5812

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ANJANGAON SUB-DN[304] BU 1627

Substation No/ Name :- 034029 / 33 KV BHANDARAJ

Feeder No / Name : 206 / 11 KV CHAUSALA [G]

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5014			.5014	.4572	.3086	.394
2	.5014			.5014	.4572	.3086	.394
3	.5014		.3814	.5014	.442	.2401	.394
4	.4656			.5014	.442	.2454	.3761
5	.4656			.4656	.442	.2401	.3582
6	.4298		.3506	.4477	.4115	.2374	.3582
7	.2686		.3121	.3224	.2439	.2572	.3403
8	.2865		.2713	.2865	.2591	.2743	.2865
9	.3045		.3052	.3045	.2896	.2454	.2721
10	.2865		.3294	.3045	.2896		.3045
11	.3224		.3121	.3224	.3048	.208	.2507
12		.373	.3052	.3601	.3155	.2686	
13		.4409	.4119	.4115		.3045	.2134
14		.4409	.4477	.3506		.2865	.3201
15			.4298		.2629	.3045	.2743
16		.4115	.4119	.3353	.2401	.3045	.2591
17		.3649	.3224	.3048		.2865	.2439
18		.3467	.3224	.2896	.2774	.2865	.2134
19		.3121	1.0745	.3353	.3856	.3045	
20			.4477	.4572	.407	.3761	.4268
21			.5014	.4877		.4119	.4268
22			.5373	.4877		.4298	.4268
23			.5373	.4877		.394	.381
24	.5373		.5201	.5373	.4572	.3988	.394
Max	.5373	.4409	1.0745	.5373	.4572	.4298	.4268
Min	.2686	.3121	.2713	.2865	.2401	.208	.2134
Avg	.4059	.3843	.4266	.4045	.3547	.3009	.3322

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ANJANGAON SUB-DN[304] BU 1627

Substation No/ Name :- 034029 / 33 KV BHANDARAJ

Feeder No / Name : 207 / 11 KV LAKHAD OLD [AG]

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1888					.3467	
2	1.1591					.3506	
3	1.1591		1.3596			.3506	
4	1.1591					.3772	
5	1.1294					.3772	
6	1.2186		1.3565			.39	
7	1.278		1.4563			.3988	
8	1.3375		1.4737			.4801	
9	1.3523		1.4737			.5144	
13		1.7635		1.4937			
14		1.7295		1.5089			
15				1.4937			1.0059
16		1.6108		1.4022	.6241		1.0212
17		1.647		1.387			1.2193
18		1.6956		1.3717			1.0059
19		1.6644		1.2651	.4508		
Max	1.3523	1.7635	1.4737	1.5089	.6241	.5144	1.2193
Min	1.1294	1.6108	1.3565	1.2651	.4508	.3467	1.0059
Avg	1.2202	1.6851	1.4240	1.4175	.5375	.3984	1.0631



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ANJANGAON SUB-DN[304] BU 1627

Substation No/ Name :- 034029 / 33 KV BHANDARAJ

Feeder No / Name : 208 / 11 KV BHANDARAJ [AG]

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4915			.6554		.3601	.6554
2	.4915			.6554		.3601	.6554
3	.4915		.5144	.6554		.3601	.6554
4	.4915			.6554		.3601	.6554
5	.6226			.7209		.3467	.7373
6	.4915		.5548	.7209	.6401	.3467	.7373
7	.5571		.6104	.7865		.3944	.7865
8	.5571		.6588	.7865		.4854	.7865
9	.5571		.6173	.7865		.4854	.7865
13		.6104	.8192			.7373	
14		.6104	.8192		.4801	.7373	
15			.8192		.583	.7373	
16		.5765	.8192		.583	.7373	
17		.6104	.7701			.7373	
18		.6104	.7373		.4908	.7373	
19		.6104	.7373		.4557	.7373	
24							.6554
Max	.6226	.6104	.8192	.7865	.6401	.7373	.7865
Min	.4915	.5765	.5144	.6554	.4557	.3467	.6554
Avg	.5279	.6048	.7064	.7137	.5388	.5413	.7111

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ANJANGAON SUB-DN[304] BU 1627

Substation No/ Name :- 034053 / 33 KV KAPUSTALANI

Feeder No / Name : 201 / 11 KV KAPUSTALNI [AG]

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9922	.6401	.9134	.6805	.4557	.5487	.4755
2	.9465	.6401	.8954	.6878	.4557	.5487	.4755
3	.9816	.6401	.8596	.6268	.4607	.5487	.4572
4	.964	.6401	.8596	.6268	.4607	.5487	.4572
5	.9114	.6401	.8417	.6089	.4961	.5487	.439
6	.8589	.6036	.8238	.5973	.5316	.5304	.439
7	.9922	.7316	.8238	.6268	.5258	.5121	.439
8	.9991	.7316	.8954	.6805	.5609	.5487	.4572
9	.9816	.7316	.9492	.6984	.6068	.5487	.4755
10	.6661	1.0059	.8238		.9465	.499	.8596
11	.7712	1.0059	.788	.591	1.0056		1.0208
12	.8048	.9671	.7973	.5784	1.0498	.5121	.9671
13	.8048	.9492	.7973	1.0341	.8507	.4938	.9231
14	.7316		.7522	.964	.8413	.5304	.9231
15	.7316		.8059	1.0517	.8413	.5853	1.0029
16	.7316	.9671	.8059	1.0288	.823	.5121	.9492
17	.7316	.9671	.7133	1.0517	.8048	.4755	.9774
19		.9671					
20		.9671					
24	.9816	.7316	.9313	.7059	.4607	.439	.4938
Max	.9991	1.0059	.9492	1.0517	1.0498	.5853	1.0208
Min	.6661	.6036	.7133	.5784	.4557	.439	.439
Avg	.8657	.8071	.8376	.7553	.6765	.5253	.6796

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ANJANGAON SUB-DN[304] BU 1627

Substation No/ Name :- 034053 / 33 KV KAPUSTALANI

Feeder No / Name : 204 / 11 KV KAPUSTALANI [G]

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5249	1.4506	1.4883	1.4899	1.4217	1.086	1.2178
2	1.4918	1.3611	1.4373	1.4899	.9362	1.086	1.2178
3	1.4737	1.3253	1.4529	1.4373	.9362		1.1694
4	1.4899	1.086		1.4175	.9465		1.134
5	1.4022	1.0498	1.3289	1.3289	.8764		1.0985
6	1.2403	1.0498	1.134	1.0808	.8505		1.0387
7	1.2357	1.0317	1.0208	1.0631	1.2136		.985
8	1.1919	1.086	1.1765	1.0808	1.262		1.1462
9	1.3176	1.086	1.3289	1.3432	1.2309		1.1871
10	.6836	1.3073	1.1163	1.1694	1.286		1.182
11	.6836	1.3969	1.2403	1.0985	1.3321		1.2269
12	.5544	1.2403	1.2934	1.5238	1.3611	1.1462	1.2403
13	.5544	1.6476	1.3289	1.6124	1.3611	1.182	1.2308
14	1.3756	1.6651	1.5775	1.6118	.9145	1.2403	1.3213
15	1.3611	1.5775	1.6301	1.0631	.9511	1.2048	1.5043
16	1.4327	1.0517	1.1104	.929	1.0974	1.1517	1.4175
17	1.379	1.5769	.8954	1.2795	1.267	1.0387	1.379
18	1.2536	1.3998	1.3289	1.382	1.134	1.2048	.724
19	1.2536		1.4706	1.4022	1.1523	1.2934	1.5947
20	1.5223	1.7002	1.5424	1.5947	1.3032	1.4373	1.7164
21	1.5223	1.6827	1.6991	1.5775	1.1403	1.3112	1.6478
22	1.4864	1.6126	1.7164	1.5604	1.1584	1.2757	1.5581
23	1.4685	1.5424	1.56	1.4918	1.1222	1.2403	1.382
24	1.5083	1.4685	1.5074	1.4899	1.4232	1.086	1.2403
Max	1.5249	1.7002	1.7164	1.6124	1.4232	1.4373	1.7164
Min	.5544	1.0317	.8954	.929	.8505	1.0387	.724
Avg	1.2670	1.3650	1.3646	1.3549	1.1532	1.1990	1.2733

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ANJANGAON SUB-DN[304] BU 1627

Substation No/ Name :- 034055 / 33 KV KAKADA

Feeder No / Name : 202 / 11 KV KUSHTA [AG]

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7537		.9214			.3475	
2	.7537		.9214			.3475	
3	.7537		.9214			.3475	
4	.7537		.9134				
5	.7537		.9134			.2743	
6	.7362		.9134			.2743	
7	.8764		1.0029			.2195	
8	.8589		1.0808			.2561	
9	.9114		1.0631			.543	
10				1.0692	1.1763		.3582
11		1.1949		.964	1.1949		.4298
12		1.0985		.9522	.7973		.7655
13		.9671		.9709	.543		.7282
14		.9214		1.1763	.5973		.7468
15		.9568			.543		.7095
16		.9568			.5249		.7282
17		.9922			.4251		.7468
20	.0572						
24	.7888		.9214			.3475	
Max	.9114	1.1949	1.0808	1.1763	1.1949	.543	.7655
Min	.0572	.9214	.9134	.9522	.4251	.2195	.3582
Avg	.7270	1.0125	.9573	1.0265	.7252	.3286	.6516

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ANJANGAON SUB-DN[304] BU 1627

Substation No/ Name :- 034055 / 33 KV KAKADA

Feeder No / Name : 203 / 11 KV KOLHA [AG]

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0974		1.1443			.7455
2		1.0974		1.1443			.7455
3		1.0974		1.1443	.5601		.7455
4		1.0974		1.1443	.5601		.7455
5		1.0974		1.1443	.5601		.7455
6		1.1888		1.1789	.7468		.7455
7		1.2936		1.1789	.8402		.8495
8		1.3306		.9362	.8775		.9189
9		1.307		1.0749	.7468		
10	.9882		1.1919				
11			1.2269			.695	
12	1.0923		1.2656			.7011	
13	1.3817		1.387				
14	1.3817		1.4043			.7186	
15	1.3443		1.1269			.7628	
16	1.307		1.1269			.7802	
17	1.2696		1.1616			.7975	
20				.1524			
24		1.1088		1.1789			.7802
Max	1.3817	1.3306	1.4043	1.1789	.8775	.7975	.9189
Min	.9882	1.0974	1.1269	.1524	.5601	.695	.7455
Avg	1.2521	1.1716	1.2364	1.0383	.6988	.7425	.7802

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ANJANGAON SUB-DN[304] BU 1627

Substation No/ Name :- 034063 / 33 KV KARALA

Feeder No / Name : 202 / 11 KV KARLA [G]

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.631	.5487	.6226	.6335	.5487	.5981	.5603
2	.631	.5487	.6203	.6135	.5487	.5975	.5448
3	.631	.5487	.6234	.5959	.5335	.5828	.5292
4	.631	.5487	.6023	.5959	.5335	.5316	.5127
5	.631	.5335	.517	.5609	.5335	.528	.4693
6	.5083	.4268	.4566	.4382	.4268	.4887	.4556
7	.4344	.3353	.3973	.333	.3506	.3747	.2976
8	.3506	.3048	.3742	.3155	.2743	.3768	.3205
9	.3681	.3201	.3245		.3048	.3289	.2932
10	.4031	.3201	.3403		.3048	.3258	.3132
11	.3506	.2884	.4031		.3205	.2819	.3258
12	.3963	.4067	.4207	.3658	.3208	.2503	
13	.4572	.4704	.4908	.4572	.3756	.4933	
14	.4877	.4849	.5434	.4725	.4347	.4698	
15	.503	.4887	.5258	.4877	.5097		
16	.4115	.4755	.5258	.3963	.4072	.4111	
17	.381	.3777	.4382	.2896	.402	.3529	
18	.2896	.3542	.333	.3506	.439	.35	
19		.3795	.4207	.4115	.5207	.3925	
20	.503	.5569	.5959	.5335	.5864	.5115	
21	.5335	.6331	.6135	.5639	.6139	.5538	
22	.5487	.6026	.6135	.5792		.5871	
23	.5487	.6257	.6135	.5792	.5919	.5519	
24	.631	.5639	.6196	.6135	.5487	.5908	.5525
Max	.631	.6331	.6234	.6335	.6139	.5981	.5603
Min	.2896	.2884	.3245	.2896	.2743	.2503	.2932
Avg	.4896	.4643	.5015	.4851	.4535	.4578	.4312

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ANJANGAON SUB-DN[304] BU 1627

Substation No/ Name :- 034063 / 33 KV KARALA

Feeder No / Name : 203 / 11 KV KARLA [AG]

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0332		1.6188		1.1478	
2	1.8138		1.6188		1.1279	
3	1.7814		1.6129		1.099	
4	1.6842		1.7022		1.0965	
5	1.5546		1.6565		1.1256	
9	1.7814		1.8232		1.3781	
10		1.768				1.4721
11		1.7945		1.9548		1.8176
12		1.4851		1.9571		
13		1.8816		2.0361		
14		1.9083		1.7709		
18		1.9641		1.8896		
19		1.9139		1.7646		
22		1.6378				
23		1.6641		1.0713		
24	2.0683		1.6089		1.118	
Max	2.0683	1.9641	1.8232	2.0361	1.3781	1.8176
Min	1.5546	1.4851	1.6089	1.0713	1.0965	1.4721
Avg	1.8167	1.7797	1.6630	1.7778	1.1561	1.6449

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ANJANGAON SUB-DN[304] BU 1627

Substation No/ Name :- 034063 / 33 KV KARALA

Feeder No / Name : 204 / 11 KV TURKHED [AG]

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.4022		1.749	1.4022		1.1206
2		1.4022		1.7166	1.4022		1.0895
6		1.3108		1.5546	1.4327		1.0303
7		1.5546		1.749	1.4632		1.1902
8		1.6766		1.9109	1.6766		1.3459
9		1.768			1.5851		1.4335
10	1.7814		1.8564		1.9814	1.238	
11	1.8595		2.0405			1.4095	
12	1.768		2.0729	1.89		1.3765	
13	1.7985		2.1376	1.9814			
14	1.9509		2.2024	1.8595		1.4721	
18			1.9433	1.768		1.54	
19			1.8138	1.768		1.5071	
22	1.4632		1.7814	1.3717		1.2394	
23	1.4632		1.7814	1.3717		1.1687	
24		1.4327		1.749	1.3717		1.1376
Max	1.9509	1.768	2.2024	1.9814	1.9814	1.54	1.4335
Min	1.4632	1.3108	1.7814	1.3717	1.3717	1.1687	1.0303
Avg	1.7264	1.5067	1.9589	1.7261	1.5394	1.3689	1.1925



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ANJANGAON SUB-DN[304] BU 1627

Substation No/ Name :- 034074 / 33 KV ANJANGAON

Feeder No / Name : 201 / 11 KV NAUGAJJI

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6653	.6653	.6348	.6722	.6653	.6161	.5975
2	.6468	.6838	.6348	.6722	.6468	.5975	.5601
3	.7577	.7207	.6348	.7095	.7207	.5975	.5601
4	.7762	.7392	.6535	.7655	.7207	.5975	.5788
5	.7392	.6653	.6722	.5415	.7207	.6348	.5975
6	.6653	.6283	.6535	.5228	.8316	.6535	.5788
7	.6468	.6099	.5975	.5041	.7762	.6722	.5975
8	.6468	.5914	.6348	.4854	.6653	.5975	.5601
9	.5914	.6099	.5975	.4251	.5175		.5415
10	.6283	.4805	.5601	.4435			
11	.5729	.6161	.5788	.4805		.4668	.5544
12	.5914	.5975	.5601		.3921	.4668	.5175
13	.6099	.5975	.5228	.462	.3921	.4108	.4805
14	.5914	.5228	.5601	.4435	.3734	.3921	.2957
15	.6283	.5228	.5415	.4435	.4294	.3921	
16	.6838	.5975	.5788	.4435	.4066	.4108	.4435
17		.6348	.6348			.4481	.3696
18	.7392	.6535	.6348			.5041	.4805
19	.6099	.6722	.6722	.5175		.5788	.5228
20	.6468	.6722	.6722	.3326	.6535	.6535	.5601
21		.5975	.6161	.5544	.5601	.5601	.6348
22	.6283	.6722	.6348	.499	.6348	.5228	.6722
23	.6653	.7095	.6722	.6468	.6161	.5788	.6722
24	.7023	.6653	.6348	.6722	.6653	.6161	.5788
Max	.7762	.7392	.6722	.7655	.8316	.6722	.6722
Min	.5729	.4805	.5228	.3326	.3734	.3921	.2957
Avg	.6561	.6302	.6161	.5351	.5994	.5440	.5434

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ANJANGAON SUB-DN[304] BU 1627

Substation No/ Name :- 034074 / 33 KV ANJANGAON

Feeder No / Name : 202 / 11 KV VIHIGAON [G]

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6838	.7023	.8131	.7762	.7392	.5914	.6468
2	.7023	.7023	.7947	.7392	.7023	.5914	.6468
3	.7392	.6653	.7947	.7762	.7392	.5729	.6468
4	.7762	.7023	.7947	.7947	.7577	.6099	.6283
5	.7762	.6838	.7762	.7207	.7762	.5914	.5914
6	.6283	.6283	.7023	.6838	.5914	.5544	.5175
7	.6283	.5914	.5914	.5729	.5544	.5175	.4805
8	.5729	.5544	.6653	.5544	.5544	.4251	.4805
9	.3142	.5914	.5914	.5729	.5544		.5729
10	.3511	.5914	.6099	.5914			.4066
11	.3326	.5914	.6468	.6653		.5175	.5175
12	.6838	.7023	.5729	.6653	.4066		.5544
13	.7762	.6838	.6283	.6838	.462		.6099
14	.7762	.6653	.6283	.7392		.4805	.6468
15	.7947	.7023	.6468	.7577		.5914	.6468
16	.7577	.6838	.6468	.6283		.4435	.5359
17		.6468	.5729	.6653	.5544	.4435	.5544
18	.5914	.6283	.4805	.6468	.499		.5729
19	.6468	.5914	.499	.6468	.5914	.6468	.6653
20	.7947	.7762	.6653	.7762	.6099	.7577	.7392
21	.7023	.8316	.8131	.8131	.6468	.6838	.7762
22	.7023	.8131	.7947	.8131	.6468	.6653	.8029
23	.7392	.7023	.7947	.7762	.6468	.6653	.7842
24	.7023	.7023	.8131	.7762	.7577	.6283	.7023
Max	.7947	.8316	.8131	.8131	.7762	.7577	.8029
Min	.3142	.5544	.4805	.5544	.4066	.4251	.4066
Avg	.6597	.6722	.6807	.7015	.6206	.5778	.6136

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ANJANGAON SUB-DN[304] BU 1627

Substation No/ Name :- 034074 / 33 KV ANJANGAON

Feeder No / Name : 203 / 11 KV GADGE BABA

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3306	1.2936	1.2696	1.2752	1.2197	1.1576	1.1088
2	1.2936	1.2936	1.251	1.2752	1.1643	1.1576	1.1088
3	1.2936	1.2567	1.251	1.2752	1.1643	1.1203	1.0719
4	1.2567	1.2752	1.2136	1.2752	1.2012	1.1016	1.0719
5	1.2382	1.1458	1.1763	1.1643	1.2197	1.0829	1.0719
6	1.1458	.961	1.0829	1.0719	1.2197	1.0082	1.0534
7	1.0903	1.0349	.9709	.961	1.1458	1.0082	.9795
8	1.0164	.9795	.9709	.9425	1.2197	.9709	.9055
9	.9055	.9425		.9425	1.0349		.9055
10	.9795	.9055	.8871	.961			.8501
11	1.0164		.9425	.9979	.9522	.7762	.7207
12	.9979		.9979	1.0164	.8589	.7762	.8686
13	1.0903	1.3256	1.0349	1.0349	.8215	.7577	.8686
14	1.1827	1.2323	1.1458	1.1458	.8589	.8686	.924
15	1.2197	1.2323	1.2012	1.1643	.9522	.924	
16	1.1827	1.2323	1.2012	1.1273	.8962	.8871	1.0903
17		1.1203	1.2012	1.0164	.8589	.924	.9795
18	1.1458	1.1576	1.0349	1.1643	.8589	.9795	.9425
19	1.0349	1.0829	1.0719	1.0719	.9149	1.0349	1.0719
20	1.2012	1.307	1.2567	1.2197	1.1949	1.1827	1.1827
21	1.2197	1.2696	1.2752	1.2752	1.1389	1.1088	1.1458
22	1.2567	1.307	1.2382	1.3121	1.1576	1.0349	1.1389
23	1.3121	1.3817	1.2936	1.3491	1.2136	1.1088	1.1827
24	1.3676	1.3121	1.307	1.2752	1.3306	1.1949	1.1273
Max	1.3676	1.3817	1.307	1.3491	1.3306	1.1949	1.1827
Min	.9055	.9055	.8871	.9425	.8215	.7577	.7207
Avg	1.1643	1.1840	1.1424	1.1381	1.0695	1.0075	1.0161

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ANJANGAON SUB-DN[304] BU 1627

Substation No/ Name :- 034074 / 33 KV ANJANGAON

Feeder No / Name : 205 / 11 KV SHIKSHAK COLONY Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3121	1.3121	1.2323	1.2936	1.2936	1.0349	1.0534
2	1.2567	1.2936	1.2323	1.2936	1.2567	1.0082	1.0164
3	1.2567	1.2936	1.2136	1.2567	1.2012	1.0082	1.0164
4	1.2382	1.2382	1.2136	1.2382	1.1827	9.7276	1.0164
5	1.2197	1.1458	1.1763	1.1827	1.1827	1.0082	.9979
6	1.0903	.9979	1.0082	1.0349	1.0719	.9335	.8871
7	.9979	.8501	.8962	.9425	1.0349	.7842	.8501
8	.8686	.7947	.8589	.8501	.9979	.7655	.7947
9	.924	.8131	.7762	.8686	.8131		.8131
10	.924	.8871	.924	.8686	.8029		.7947
11	.8316	.9896	.9425	.9288	.8962	.924	.7577
12	.9795	1.0829	.924	.9425		.7392	.7947
13	1.0719	1.1203	1.0164	1.0719	.8962	.7762	.8131
14	1.1827	1.0829	1.0719	1.1088	.7842	.7762	.8316
15	1.1643	1.1389	1.2382	1.1273	.8589	.8131	.8871
16	1.0534	1.1763	1.2197	1.0903	.8589		.8686
17		1.1576	1.1088	.9979	.8215		.8686
18	1.0903	1.0829	1.0534	1.0349	.8589		.8501
19	.9979	1.0456	1.0349	1.0534	.9335	1.2382	.924
20	1.1088	1.1949	1.1827	1.2012	.9896	1.2567	1.0456
21	1.1458	1.2323	1.2197	1.2197	.9709	1.1088	1.1576
22	1.2197	1.2696	1.2567	1.2197		1.0534	1.1389
23	1.2936	1.3443	1.3491	1.3306	1.0829	1.1088	1.1949
24	1.3306	1.3121	1.307	1.3121	1.3121	1.0642	1.0534
Max	1.3306	1.3443	1.3491	1.3306	1.3121	9.7276	1.1949
Min	.8316	.7947	.7762	.8501	.7842	.7392	.7577
Avg	1.1112	1.1190	1.1024	1.1029	1.0046	1.4278	.9344

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

ANJANGAON SUB-DN[304] BU 1627

Substation No/ Name :- 034074 / 33 KV ANJANGAON

Feeder No / Name : 206 / 11 KV DEONATH

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3121	1.2936	1.4784	1.4415	1.3121	1.1273	1.1088
2	1.2752	1.2936	1.4415	1.4784	1.2936	1.1088	1.1088
3	1.2752	1.2936	1.4415	1.4784	1.2567	1.1088	1.0719
4	1.2936	1.2567	1.4003	1.423	1.2567	1.0903	1.0719
5	1.2752	1.2012	1.3491	1.3491	1.2567	1.1088	1.0719
6	1.1088	1.1088	1.0719	1.2567	1.3306	.9979	.9425
7	1.1273	1.0534	1.1827	1.1827	1.1827	.9795	.9795
8	1.1827	.9795	1.1458	1.1643	1.3676	.8686	.924
9	.9425	.8871	.9979	.924	.9979		.8316
10	.8871	.8501	1.0164	1.0534	.8686		.8501
11	.8871	.8871	.9425	1.0719	.8501	.8316	.7762
12	.9425	.9709	.924	1.0534	.7023	.7392	.8316
13	.9979	.9979	.9979	.9425	.7023	.7207	.8686
14	1.0719	.9795	***	1.1273	.7207	.7762	.7947
15	1.1273	1.1949	1.0903	1.2197	.8501	.7762	.8686
16	1.1273	1.2197	1.1273	1.2382	.8501	.8871	.924
17		1.0903	1.0903	1.1088	.8501	.9055	.8686
18	1.0164	1.0642	.8871	1.1827		.8871	.8501
19	.924	1.0642	.9055	1.1643	.8871	1.0164	1.0082
20	1.1458	1.2936	1.1458	1.2567	1.0164	1.2567	1.1763
21	1.1827	1.1827	1.1827	1.2936	1.0719	1.1643	1.1763
22	1.2382	1.4784	1.2382	1.2752	1.1458	1.1827	1.2696
23	1.3121	1.5154	1.4415	1.4784	1.1827	1.1088	1.419
24	1.3676	1.3121	1.5154	1.3121	1.4969	1.1458	1.0903
Max	1.3676	1.5154	10.1827	1.4784	1.4969	1.2567	1.419
Min	.8871	.8501	.8871	.924	.7023	.7207	.7762
Avg	1.1313	1.1445	1.5499	1.2282	1.0630	.9904	.9951

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

CHIKHALDARA S/Dn[847] BU 4847

Substation No/ Name :- 034008 / 33 KV CHIKHALDARA

Feeder No / Name : 205 / 11 KV Chikhaldara Town Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.2096	.2987	.3239	.3239	.2096	.2241
2	.3048	.2096	.2987	.3239	.3239	.1905	.2241
3	.3048	.1715	.2987	.3239	.3239	.2096	.2054
4	.2858	.1715	.2801	.3429	.3239	.1715	.2054
5	.2858	.1715	.2801	.3429	.3048	.1715	.2241
6	.2858	.2286	.2801	.362	.3048	.1905	.2614
7	.2667	.2667	.2614	.362	.381	.2477	.2801
8	.2667	.3048	.2614	.362	.4191	.2858	.3361
9	.2667	.362	.2614	.362	.4763	.3429	.2987
10	.2667	.3239	.2614	.3429	.362	.3048	.3361
11	.2477	.2987	.2614	.3429	.3239	.2477	.3048
12	.2858	.2614	.2667	.3429	.2667	.2427	.2667
13	.3048	.2801	.2858	.3048	.2286	.2427	.3048
14	.3429	.2614	.2858	.2477	.2286	.2427	.2858
15	.3048	.2427	.2858	.2477	.2286	.2427	.2667
16	.2667	.2241	.2858	.2477	.2096	.2241	.2096
17	.2667	.2054	.2858	.2477	.2286	.2427	.2096
18	.2286	.2054	.2858	.2477	.2477	.2096	.2477
19	.3048	.2427	.2858	.2858	.2667	.2667	.2858
20	.3239	.2801	.2858	.381	.3048	.3429	.3239
21	.2858	.2801	.2858	.362	.2858	.2987	.3048
22	.2667	.2987	.2858	.3429	.2858	.2801	.3048
23	.2667	.2987	.3048	.3429	.2667	.2614	.2858
24	.2858	.2286	.2987	.3048	.3429	.2477	.2241
Max	.3429	.362	.3048	.381	.4763	.3429	.3361
Min	.2286	.1715	.2614	.2477	.2096	.1715	.2054
Avg	.2842	.2512	.2822	.3207	.3024	.2465	.2675

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

CHIKHALDARA S/Dn[847] BU 4847

Substation No/ Name :- 034008 / 33 KV CHIKHALDARA

Feeder No / Name : 206 / 11 KV Salona

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1886	.1844	.1543	.1886	.1372	.1677
2	.1543	.1715	.1844	.1543	.1886	.12	.1677
3	.1543	.1715	.1677	.1543	.1715	.12	.1677
4	.1372	.1543	.1677	.1372	.1715	.1029	.1509
5	.1372	.1543	.1677	.1372	.1543	.1029	.1509
6	.1372	.1886	.1509	.1372	.1543	.1372	.1509
7	.12	.2058	.1509	.1372	.1715	.1715	.2012
8	.12	.1886	.1509	.1372	.1543	.1543	.1677
9	.12	.1886	.1509	.1372	.1543	.1372	.1341
10	.1029	.1029	.1174	.12	.12	.1029	.1174
11	.1372	.1174	.1006	.1029	.1543	.0514	.1372
12	.12	.1509	.1029	.1029	.1372	.1174	.1543
13	.12	.1006	.12	.1372	.0857	.1341	.12
14	.1372	.1006	.12	.1029	.1029	.1174	.12
15	.1029	.1006	.12	.0514	.1372	.1006	.1372
16	.0343	.1006	.12	.12	.12	.1509	.1029
17	.0343	.1174	.1886	.2058	.1543	.1509	.12
18	.0343	.1174	.1715	.1886	.1886	.1543	.1372
19	.1372	.1509	.1543	.2743	.1886	.1886	.1886
20	.1543	.1844	.1543	.2229	.2058	.2572	.2229
21	.1886	.1844	.1372	.2229	.1715	.1844	.2401
22	.1753	.2012	.1372	.2229	.1543	.1844	.2058
23	.2058	.2012	.1543	.2058	.1543	.1844	.1715
24	.1543	.1886	.1677	.1543	.1886	.1543	.1677
Max	.2058	.2058	.1886	.2743	.2058	.2572	.2401
Min	.0343	.1006	.1006	.0514	.0857	.0514	.1029
Avg	.1280	.1555	.1476	.1550	.1572	.1424	.1584

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

CHIKHALDARA S/Dn[847] BU 4847

Substation No/ Name :- 034008 / 33 KV CHIKHALDARA

Feeder No / Name : 207 / 11 KV Mozari

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9114	.7362	.823	1.0517	.8413	.7362	.8059
2	.8764	.7186	.7716	1.0341	.8413	.7186	.7716
3	.8764	.7011	.7716	1.0166	.8238	.7011	.7716
4	.8589	.7186	.7373	.964	.8238	.6661	
5	.8589	.7362	.6859	.964	.8238	.6836	.7888
6	.8589	.8063	.7716	.9465	.8063	.7186	.7888
7	.8413	.8589	.8573	.9465	.8764	.8063	.8059
8	.8413	.8939	.8916	.9465	.7888	.6135	.7545
9	.8413	.8764	.9259	.9465	.7011	.5784	.7545
10	.7537	.7888	.8916	.9114	.631	.5083	.7373
11	.8238	.7537	.8573	.9114	.6485	.4031	.7362
12	.8939	.7202	.8764	.9114		.4458	.7712
13	.8764	.7888	.8764	.8764	.4908	.463	.8413
14	.7362	.7545	.8764	.8764	.4733	.463	.8063
15	.5784	.7202	.8764		.4557	.5487	.7712
16	.7011	.6859	.8764	.3506	.5959	.5658	.7362
17	.8063	.6516	.929	.7186	.8238	.6173	.8589
18	.8939	.6344	.964	.929	.8764	.7712	.964
19	.9816	.8402	.9816	.929	.8413	.8939	1.0517
20	.9465	1.0117	.9816	.964	.8589	.9465	1.0166
21	.9114	1.0288	1.0166	.8939	.8413	.8745	.9991
22	.8413	1.0802	1.0517	.8764	.8063	.8573	.9465
23	.7712	1.0117	1.0867	.8589	.7712	.823	.8764
24	.929	.7537	.8402	1.0517	.8589	.7362	.8059
Max	.9816	1.0802	1.0867	1.0517	.8764	.9465	1.0517
Min	.5784	.6344	.6859	.3506	.4557	.4031	.7362
Avg	.8421	.8029	.8841	.9076	.7522	.6725	.8331



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

CHIKHALDARA S/Dn[847] BU 4847

Substation No/ Name :- 034033 / 33 KV DHAMANGAON

Feeder No / Name : 209 / 11 KV Dhamangaon Gadhi

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11	1.2803	1.2289	1.3123	1.6244	1.0402	.3953	.5243
12	1.4083	1.3927	1.3603	1.6712	1.0402	.3953	.663
13	1.4723	1.4746	1.2003	1.9062	.8802		.7373
14		1.2452	1.406	.9945	.7202	.5468	
15	1.3441	1.2289	1.5623	1.0774	.4801	.5535	.763
16	1.2651		1.5546	1.0774	.4801	.5468	.6783
17	1.2651	1.3763	1.6194	1.2289	.4481	.5468	.6443
18	1.2651	1.2289		1.1469	.4001	.5468	.7122
19				.9945	.4001		
Max	1.4723	1.4746	1.6194	1.9062	1.0402	.5535	.763
Min	1.2651	1.2289	1.2003	.9945	.4001	.3953	.5243
Avg	1.3286	1.3108	1.4307	1.3024	.6544	.5045	.6746

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

CHIKHALDARA S/Dn[847] BU 4847

Substation No/ Name :- 034033 / 33 KV DHAMANGAON

Feeder No / Name : 210 / 11 KV Hanvatkheda Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.4207	.439	.3696	.439	.2926	.3142
2	.3292	.439	.439	.3696	.439	.2926	.3142
3	.3292	.439	.439	.3696	.439	.3109	.3109
4	.3696	.439	.439	.3734	.439	.3109	.3142
5	.3292	.4207	.439	.3734	.439	.3292	.3326
6	.2926	.4024	.4024	.2957	.4024	.3292	.2957
7	.2926	.3292	.3658	.2926	.3658	.3292	.2926
8	.2378	.3292	.3292	.2926	.3658	.2743	.2195
9	.2378	.2926	.3292	.2561	.3658	.2378	.2195
10	.3109	.3292	.2926	.2926	.3292	.2378	.2195
11	.3292	.2926	.2195	.2926	.2561	.2218	.2195
12	.3292	.3292	.2926	.2926	.2378		.2561
13	.3109	.3658	.2743	.2926	.2195		.2743
14		.3658	.3109	.2743	.2378	.1486	.2926
15	.3292	.3658	.2926	.2926	.2561	.2195	.2926
16	.3292	.3292	.2715	.2743	.2561	.1646	.2743
17	.3109	.2926	.2743	.2743	.2743	.1829	.2926
18	.3109	.3292	.2926	.3292	.2926	.1848	.2926
19	.2561	.3658	.2957	.3658	.3109	.2218	.3109
20	.3658	.4024	.3696	.4572	.2378	.3696	.4024
21	.4024	.439	.4108	.4572	.2743		.439
22	.439	.4572	.4066	.439			.439
23	.4207	.439	.4066	.439	.2926	.3696	.439
24	.3292	.4207	.439	.3696	.439	.2926	.3142
Max	.439	.4572	.439	.4572	.439	.3696	.439
Min	.2378	.2926	.2195	.2561	.2195	.1486	.2195
Avg	.3270	.3765	.3530	.3390	.3308	.2660	.3072

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

CHIKHALDARA S/Dn[847] BU 4847

Substation No/ Name :- 034033 / 33 KV DHAMANGAON

Feeder No / Name : 211 / 11 KV Hanvatkheda Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	1.0105	.7335	.9374	.8802	.3749	.2201	.2743
10	1.0364	.7335	1.0467	.9536	.3749	.2494	.3018
11	.9536	.7811	.9755	.9374	.3227	.2317	.4687
12	.8802	.7811	.9907	.9374	.2934		.4374
13	.8383	.7499	.8269	.9061	.2641		.4588
14	.823	.7186	.9214	.8592	.2641	.176	.4588
15	.7621	.703	.9214	.4374	.2641	.192	.4588
16	.6097	.6249	.8802	.3125	.2347	.176	.3932
20				.4572			
Max	1.0364	.7811	1.0467	.9536	.3749	.2494	.4687
Min	.6097	.6249	.8269	.3125	.2347	.176	.2743
Avg	.8642	.7282	.9375	.7423	.2991	.2075	.4065

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

CHIKHALDARA S/Dn[847] BU 4847

Substation No/ Name :- 034033 / 33 KV DHAMANGAON

Feeder No / Name : 212 / 11 KV Wazzar

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.226	.9335	.9012	1.1203	.7373	1.2403	1.0374
2	1.226	.9335	.9012	1.1203	.7373	1.2403	1.0374
3	1.226	.9335	.9012	1.1203	.7459	1.2403	1.0374
4	1.226	.8402	.9012	1.1203	.7459	1.2226	1.0374
5	1.226	.8488	.7373	1.1203	.7459	1.2226	1.0269
6	1.1317	.8402	.6554	1.307	.6962	1.2403	1.0642
7	.9808	.7468	.7377	1.0269	1.0774	1.0631	.5658
8	.811	.7545	.6706	.9335	.9945	.9745	.6535
9	.7545	.7392	.6371	.7095	.9221	.8859	.5228
10	.7545	.7468	.6226	.5121	.8619	.8859	.4668
11	1.949	1.8023	1.8004	1.9662	1.2403	.5548	1.1022
12	2.5692		2.4863	2.1879	1.1517		1.2071
13	2.6216	1.9662	2.5377	2.2377	1.0631		1.3077
14	2.6216	1.8842	2.4863	.9012	.9745	.9114	.9221
15	2.4577	1.9334	2.4006	.9221	.8859	.8413	
16	2.2939	1.8747	2.489	1.3413	.8859	.9114	1.0898
17	2.2119	1.8842	2.5415	1.3413	.7973	.8859	1.073
18	2.13	1.7404	.8078	1.1736	.7087	.8859	.9221
19	.5316	1.0059	.8488		.6201	.7545	.9221
20	.8488	1.3108	1.1506	.7545	1.2048	1.0374	1.1736
21	.9054	1.3927	1.1317	.8192	1.2757		1.2071
22	.9054	1.3927	1.2012	.8192			1.2574
23	.9431	1.065	1.1203	.8192	1.2403	1.0269	1.2574
24	1.226	.924	1.065	1.1203	.7373	1.2403	1.0374
Max	2.6216	1.9662	2.5415	2.2377	1.2757	1.2403	1.3077
Min	.5316	.7392	.6226	.5121	.6201	.5548	.4668
Avg	1.4491	1.2388	1.3222	1.1519	.9152	1.0133	.9969

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

DARYAPUR SUB-DN[305] BU 1635

Substation No/ Name :- 034010 / 33 KV DARYAPUR

Feeder No / Name : 201 / 11 KV Daryapur Rural  
Feeder KV- 11 / OUTGOING

Sheddable Rural/Mix Feeder

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.475	1.2803	1.4998	1.531	1.3169	1.2012	1.1203
2	1.4415	1.0608	1.4969	1.4937	1.2071	1.2012	1.1203
3	1.4415	.9877	1.4815	1.4377	1.134	1.1643	1.1088
4	1.4003	.9511	1.4266	1.4003	1.0974	1.1203	1.1088
5	1.307	.7316	1.3306	1.307	1.0242	1.0829	1.0082
6	1.1203	.695	1.0242	1.0642	.9694	.9335	.8686
7	.8501	.6584	.8316	.8215	.8413	.7282	.7392
8	.9522	.7865	1.1576	1.0829	1.1706	.7842	.8589
9	1.0059	.6653	1.2071	1.251	1.3256	.8029	.8962
10	1.0534	1.0164	1.2437	1.262	1.2136	.8215	.8962
11		1.1389	1.3352	1.3676	1.0082	.8215	.3475
12	1.2936	1.2197	1.4266	1.4937	1.0534	.8215	1.0059
13	1.4632	1.4377	1.5729	1.5524	1.2696	.6348	1.1157
14	1.6095	1.5123	1.0059	1.6263	1.2696	.7842	1.0608
15	1.5546	.6584	1.251	1.701	1.3352	1.0082	.9335
16	1.2986	.8779	.0747	1.6278	1.0903	.6722	.9896
17	1.134	1.1706	.9709		.9896	1.1016	.9149
18	1.0425	1.1706	1.2323	.6767	.9328	1.0534	1.0642
19	1.0608	1.2637	1.3443	.9511	1.0425		1.2136
20	1.5181	1.6644	1.7924	1.3352	1.2382	.0739	1.5123
21	1.5364	1.701	1.7364	1.3535	1.2752	.5359	1.3443
22		1.7187	1.7551	1.4632	1.2986	.8962	1.4377
23	1.4998	1.6278	1.6244	1.4083	1.251	1.0642	1.3817
24	1.475	1.4449	1.5546	1.5684	1.39	1.2012	1.1203
Max	1.6095	1.7187	1.7924	1.701	1.39	1.2012	1.5123
Min	.8501	.6584	.0747	.6767	.8413	.0739	.3475
Avg	1.2970	1.1433	1.3073	1.3381	1.1560	.8917	1.0486

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

DARYAPUR SUB-DN[305] BU 1635

Substation No/ Name :- 034010 / 33 KV DARYAPUR

Feeder No / Name : 202 / 11 KV Ramtirth

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8413	.4755	.5729	.6468	.5853	.5788	.4435
2	.8413	.439	.5544	.6161	.5853	.5544	.439
3	.8326	.439	.5601	.5788	.5121	.5487	.4344
4	.8048	.439	.5228	.5601	.5121	.5175	.4207
5	.724	.439	.4854	.5601	.4755	.5228	.3841
6	.6036	.439	.462	.5041	.4755	.4805	.3475
7	.7133	.3475	.4294	.4668	.4572	.3696	.2715
8	.8779	.4024	.462	.4668	.4755	.4668	.2378
9	1.0608	.5228	.5121	.6036	.6219	.5359	.2743
10	1.1088	.5041	.567	.6468	.6036	.5788	.2743
11		.5415	.6036	.7392	.6516	.5415	.2926
12	.9511	.5601	.6219	.8029	.6219	.5788	.3475
13	.9328	.6348		.8962	.6767	.7095	
14	1.1706	.5601	.2743	.924	.5853	.6767	.3841
15	1.1523	.5853	.6722	.9145	.7316	.6767	.4251
16	1.1523	.6099	.7282	.9145	.6401	.6584	.4481
17	1.0608	.5487	.6722	.7865	.6099	.6154	.4108
18	.7682	.0189	.6161	.7133	.5175	.6036	.4668
19			.6722	.695	.6036	.4525	.5601
20	.5304	.3292	.8215	.6401	.6401	.4887	.6908
21	.5853	.7762	.8215	.6036	.6468	.462	.6908
22		.7023	.7468	.6401	.6219	.4572	.6653
23	.5487	.5975	.7282	.6219	.5914	.439	.6535
24	.8326	.5304	.567	.6722	.6219	.5788	.439
Max	1.1706	.7762	.8215	.924	.7316	.7095	.6908
Min	.5304	.0189	.2743	.4668	.4572	.3696	.2378
Avg	.8616	.4975	.5945	.6756	.5860	.5455	.4349

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

DARYAPUR SUB-DN[305] BU 1635

Substation No/ Name :- 034010 / 33 KV DARYAPUR

Feeder No / Name : 203 / 11 KV Daryapur town  
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1845	1.7924	2.0538	2.0538	1.7924	1.848	1.6817
2	2.1622	1.6461	2.0328	1.9978	1.7558	1.8298	1.6991
3	2.1845	1.6095	1.9959	1.9044	1.7558	1.7556	1.6817
4	2.0538	1.6095	1.9605	1.8671	1.7193	1.7372	1.6057
5	1.848	1.5912	1.6804	1.8298	1.6827	1.6804	1.4937
6	1.6804	1.5912	1.6057	1.5497	1.6827	1.5339	1.4784
7	1.419	1.3535	1.4045	1.307	1.5912	1.2382	1.363
8	1.363	1.4083	1.2752	1.4377	1.5546	1.251	1.3256
9	1.1888	1.2696	1.262	1.2382	1.3256	1.1576	1.2071
10	1.2437	1.419	1.2803	1.3121	1.251	1.1576	1.2254
11		1.4563	1.2803	1.4377	1.307	1.1763	1.2254
12	1.9204	1.531	1.4449	1.5123	1.0903	1.1763	1.2071
13	1.701	1.6617	1.4998	1.6057	1.4377	.2801	
14	1.7741	1.7551	1.6095	1.6991	1.4969	.3361	1.3535
15	1.8839	1.6817	1.587	1.7193	1.5684	.3174	1.0829
16	1.9022	1.701	1.6617	1.701	1.4083	.2987	1.1203
17	1.6827	1.6244	1.6057	1.5729	1.3717	.2987	.9709
18	1.5912	1.5729	1.475	1.5546	1.4415	.8316	1.419
19	1.5912	1.5546	1.4937	1.829	1.5729	1.5524	1.6057
20	1.7558	1.9387	1.7924	1.8656	1.6644	1.6617	1.8111
21	1.8656	1.9418	1.8484	1.8839	1.7375	1.643	1.8671
22		2.0302	2.0165	1.9936	1.922	1.6263	1.9978
23	2.0485	2.1845	2.1472	2.0302	1.9035	1.6617	1.9978
24	2.1845	2.0119	2.0883	2.1098	1.9204	1.848	1.6991
Max	2.1845	2.1845	2.1472	2.1098	1.922	1.848	1.9978
Min	1.1888	1.2696	1.262	1.2382	1.0903	.2801	.9709
Avg	1.7831	1.6640	1.6709	1.7088	1.5814	1.2457	1.4834

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

DARYAPUR SUB-DN[305] BU 1635

Substation No/ Name :- 034010 / 33 KV DARYAPUR

Feeder No / Name : 204 / 11KV Sootgirani  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0924	.0549	.0554	.112	.1097	.1132	.0554
2	.112	.0549	.0549	.112	.0732	.0934	.0554
3	.1109	.0549	.056	.112	.0732	.0914	.0554
4	.0934	.0549	.0549	.112	.0732	.0934	.0554
5	.1294	.0549	.0549	.112	.0732	.112	.0554
6	.1109	.0549	.0554	.112	.1097	.112	.056
7	.2402	.0366	.1829	.112	.1097	.112	.056
8	.2957	.0914	.1646	.112	.1097	.2033	.1848
9	.3658	.2033	.1829	.1294	.1109	.2427	.2926
10	.3841	.2772	.2012	.1294	.1294	.2987	.3109
11		.2402	.2561	.132	.1109	.2987	.2926
12	.2743	.2427	.2561	.1494	.1109	.2801	.2926
13	.2743	.1867	.2012	.1478	.1109	.2987	
14	.2561	.2427	.2561	.1494	.1307	.2033	.3475
15	.2561	.0732	.2801	.128	.1307	.1848	.2427
16	.2378	.2378	.1867	.128	.1294	.2033	.2614
17	.1829	.2561	.168	.128	.1109	.1867	.2614
18	.0549	.1463	.1867	.128	.1097	.1294	.1494
19	.0366	.2587	.2241	.1097	.1109	.1867	.1867
20	.0549	.2195	.1494	.1097	.112	.0747	.1307
21	.0549	.0554	.112	.1097	.1109	.056	.056
22		.0549	.112	.128	.112	.056	.056
23	.0366	.0549	.112	.1097	.1109	.0554	.056
24	.0924	.0549	.056	.112	.128	.1109	.0554
Max	.3841	.2772	.2801	.1494	.1307	.2987	.3475
Min	.0366	.0366	.0549	.1097	.0732	.0554	.0554
Avg	.1703	.1359	.1508	.1218	.1084	.1582	.1550



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

DARYAPUR SUB-DN[305] BU 1635

Substation No/ Name :- 034011 / 33 KV YEODA

Feeder No / Name : 208 / 11 KV Ramagad

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9979	1.0164	.9145	.9979	1.0242	.9979	.8871
2	.9511	1.0164	.9145	1.0059	1.0059	.961	.8871
3	.9979	1.0164	.7682	.9877	1.0059	.961	.8871
4	1.0349	1.0164	.7682	.9511	1.0059	.9145	.8316
5	1.0534	.924	.8316	.9145	.9795	.9145	.8316
6	.823	.7762	.8316	.8316	.8501	.8316	.7392
7	.6401	.6099	.6468	.6401	.6468	.6335	.6468
8	.6219	.5175	.5544	.5487	.5544	.543	.5544
9	.5487	.499	.5544	.5487	.5544	.5068	.499
10	.5175	.5175	.5544	.543	.5544	.4755	.4435
11	.5544	.5175	.5544	.6468	.5487	.4805	.4251
12	.6099	.6838	.6036	.7316	.6335	.462	.462
13	.6838	.7316	.6767	.7682	.6401	.462	.462
14	.7762	.6468	.7316	.7865	.6516	.5544	.5175
15	.7392	.1886	.5487	.823	.6584	.5914	.5544
16	.7392	.6468	.7316	.823	.6584	.5175	.5544
17	.6468	.6468	.6468	.6468	.5544	.462	.462
18	.5544	.5544	.5487	.6468	.5544	.462	.462
19	.6468	.6401	.5544	.7682	.7392	.7392	.7392
20	.924	.9145	.5544	.905	.924	.8316	.924
21	.924	.9955	.7392	1.0059	1.0164	.8316	.9979
22	1.0534	1.086	1.1088	1.0608	1.0164	.924	1.0164
23	1.0534	1.0059	1.1088	1.0425	1.0164	.924	1.1088
24	1.0059	1.0719	1.0059	1.0164	1.0242	1.0164	.924
Max	1.0534	1.086	1.1088	1.0608	1.0242	1.0164	1.1088
Min	.5175	.1886	.5487	.543	.5487	.462	.4251
Avg	.7957	.7600	.7272	.8184	.7841	.7082	.7007

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

DARYAPUR SUB-DN[305] BU 1635

Substation No/ Name :- 034011 / 33 KV YEODA

Feeder No / Name : 209 / 11KV Yeoda

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9204	1.848	1.9204	1.9605	1.9204	1.829	1.6632
2	1.9022	1.848	1.9204	1.9404	1.829	1.8111	1.6632
3	1.9404	1.848	1.829	1.922	1.5708	1.829	1.6632
4	1.9589	1.8111	1.7375	1.848	1.3306	1.8296	1.6632
5	1.9959	1.8111	1.6632	1.848	1.2936	1.848	1.6632
6	1.7556	1.6263	1.6632	1.6461	1.2803	1.6804	1.6632
7	1.4998	1.3121	1.4784	1.2936	1.1088	1.448	1.4784
8	1.3169	1.2936	1.2936	1.2803	1.4632	1.3575	1.386
9	1.2803	1.2936	1.2936	1.2803	1.386	1.1403	1.2012
10	1.2936	1.3491	1.386	1.2936	1.2936	1.267	1.2012
11	1.2936	1.2936	1.2936	1.4784	1.3575	1.2012	1.2382
12	1.386	1.386	1.3169	1.4998	1.4118	1.2012	1.2936
13	1.5339	1.4632	1.4998	1.5546	1.3717	1.1088	1.2936
14	1.6632		1.6461	1.5912	1.3717	1.2012	1.4784
15	1.6632	1.386	1.6461	1.6461	1.5546	1.2936	1.386
16	1.6632	1.386	1.6461	1.5546	1.4784	1.2012	1.2936
17	1.1088	1.386	1.2803	1.386	1.2936	1.1088	1.1088
18	1.2936	1.2936	1.2936	1.2012	1.386	1.1088	1.2012
19		1.3717	1.4003	1.5546	1.5708	1.4784	1.4784
20	1.848	1.829	1.829	1.8099	1.848	1.7556	.924
21	1.848	1.9004	1.848	1.9204	1.848	1.5708	1.9774
22	1.922	1.9909	2.0328	2.0119	2.0328	1.6632	2.0328
23	1.9589	1.9909	2.0328	2.0119	1.9404	1.848	2.0328
24	1.9404	1.9035	2.0119	2.0328	2.0119	1.848	1.6632
Max	1.9959	1.9909	2.0328	2.0328	2.0328	1.848	2.0328
Min	1.1088	1.2936	1.2803	1.2012	1.1088	1.1088	.924
Avg	1.6516	1.5922	1.6234	1.6486	1.5397	1.4845	1.4853

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

DARYAPUR SUB-DN[305] BU 1635

Substation No/ Name :- 034011 / 33 KV YEODA

Feeder No / Name : 210 / 11 KV Umari

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.462	.462	.4572	.5175	.4938	.4572	.4066
2	.439	.462	.4572	.5121	.4572	.4435	.4066
3	.4572	.462	.4207	.499	.4572	.4251	.4066
4	.4755	.462	.4207	.4755	.4805	.4251	.3696
5	.4755	.4435	.3881	.4805	.4805	.4108	.3696
6	.4024	.5175	.3881	.4024	.4066	.3881	.3326
7	.3109	.2957	.3142	.3292	.3696	.3077	.2957
8	.3109	.3142	.3326	.3258	.3696	.2865	.3326
9	.3258	.3142	.2957	.3077	.3696	.2896	.3326
10	.3142	.2957	.3326	.3077	.3696	.2896	.3142
11	.2772	.3142	.3142	.3511	.3658	.2957	.2957
12	.2402	.3326	.3077	.3881	.3439	.2957	.3326
13	.2402	.3658	.3801	.4207	.3439	.2957	.3696
14	.3881	.3881	.4024	.4207	.3077	.2772	.3696
15	.3696	.3326	.3801	.4207	.4525	.3326	.3511
16	.3326	.3881	.3841	.3511	.3511	.3511	.3511
17	.2957	.3696	.3511	.3326	.2772	.2772	.2957
18	.2957	.2402		.3142	.3511	.2957	.2772
19	.3142	.3292	.3475	.3658	.3696	.2402	.3881
20	.4066	.4755	.4755	.4525	.439	.4435	.4435
21	.4435	.439	.5359	.4572	.462	.3696	.5175
22	.4805	.4938	.5175	.5304	.4805	.4435	.4805
23	.4805	.4938	.5544	.5121	.4805	.4435	.499
24	.4805	.4805	.4938	.5175	.4938	.462	.4251
Max	.4805	.5175	.5544	.5304	.4938	.462	.5175
Min	.2402	.2402	.2957	.3077	.2772	.2402	.2772
Avg	.3758	.3947	.4022	.4163	.4072	.3561	.3735

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

DARYAPUR SUB-DN[305] BU 1635

Substation No/ Name :- 034012 / 33KV KHOLAPUR

Feeder No / Name : 205 / 11 KV Wathoda AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.6584	1.5546	.7392
2					.6584	1.5546	.7392
3					.7682	1.5242	.7392
4					.8779	1.4632	.7392
5					.8779	.6097	.7392
6					.8779	.6097	.7392
7					.9511	.6097	.7392
8					.9328	.6097	.7392
9					.9511	.6097	.7392
10	.7392	.9877	.9145				
11	.8779	1.134	1.1088				
12	1.0974	.9145					
13	1.0974	.9907	1.1088				
14	1.0974	.9907	1.1088	1.2437			
15	1.1706	.9907		1.39			
16	1.1706	.9907	1.1088	1.39			
17	1.1706	.9907	1.1088				
24					.6584	.5335	.7392
Max	1.1706	1.134	1.1088	1.39	.9511	1.5546	.7392
Min	.7392	.9145	.9145	1.2437	.6584	.5335	.7392
Avg	1.0526	.9987	1.0764	1.3412	.8212	.9679	.7392

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

DARYAPUR SUB-DN[305] BU 1635

Substation No/ Name :- 034012 / 33KV KHOLAPUR

Feeder No / Name : 206 / 11 KV Kholapur

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1807	1.9387	1.6766	2.1437	1.9753	1.5546	1.8665
2	2.1437	1.7193	1.6004	2.1437	1.8656	1.5546	1.848
3	2.0328	1.6827	1.6004	2.1068	1.8656	1.5242	1.7926
4	1.9404	1.6095	1.5546	2.0328	1.9387	1.4632	1.6632
5	1.848	1.6095	1.4937	1.848	1.9022	1.3717	1.5893
6	1.7926	1.5364	1.4632	1.7741	1.9022	1.2803	1.4784
7	1.4969	1.4998	1.406	1.4415	1.9022	1.1584	1.4969
8	1.386	1.3535	1.1431	1.3491	1.6827	1.0669	1.4045
9	1.4415	1.3717	1.0822	1.39	1.6095	1.1279	1.3352
10	1.2382	1.3535	1.0669	1.4449	1.326	1.0974	1.3352
11	1.2254	1.3535	1.386	1.4998	1.0669	1.1827	1.1888
12	1.3169	1.1279		1.4815	1.1279	1.0719	1.2071
13	1.4632	1.2193	1.6632	1.4815		.9979	1.3352
14	1.7558	1.4022	1.6632	1.5729	1.0974	1.0164	1.3169
15	1.9387	1.387	1.7002	1.7924	1.1126	1.0534	1.3717
16	1.8656	1.326	1.6448	1.5546	.9755	1.0164	1.4083
17	1.7375	1.2498	1.5154		1.1126		1.4266
18	1.5912	1.1888	1.5524	1.4266	1.1431		1.4998
19	1.4266	1.2346	1.6263	1.7741	1.3565	1.5708	1.5729
20	2.1582	1.5546	2.1068	2.0119	1.6156	2.0513	2.0302
21	2.1582	1.829	2.1068	2.0851	1.6766	1.9035	2.0485
22	2.1765	1.89	2.2177	2.0851	1.6918	1.9035	2.0485
23	2.1948	1.5546	2.2177	2.1216	1.6461	1.922	2.1216
24	2.1992	2.1399	1.7833	2.1437	2.0668	1.6004	1.8665
Max	2.1992	2.1399	2.2177	2.1437	2.0668	2.0513	2.1216
Min	1.2254	1.1279	1.0669	1.3491	.9755	.9979	1.1888
Avg	1.7795	1.5055	1.6205	1.7698	1.5504	1.3859	1.5939

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

DARYAPUR SUB-DN[305] BU 1635

Substation No/ Name :- 034012 / 33KV KHOLAPUR

Feeder No / Name : 207 / 11 KV Kholapur w/w Sheddable Rural/Mix Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7207	.5731	.5487	.7207	.6447	.5144	.5729
2	.7023	.5373	.5144	.6838	.6447	.4572	.5544
3	.7023	.5014	.5144	.6283	.5014	.5144	.5544
4	.6653	.5014	.5144	.5544	.4656	.5144	.4805
5	.6283	.5014	.4801	.5175	.4656	.463	.4435
6	.5544	.5014	.4801	.499	.4656	.4115	.3696
7	.3696	.5014	.4458	.4805	.394	.3429	.3881
8	.3696	.394	.3944	.3881	.394	.3258	.3696
9	.3881	.394	.3601	.4477	.4298	.3258	.3582
10	.4251	.4119	.3772	.3761	.3944	.3258	.3582
11	.3761	.394	.4435	.4656	.4115	.2957	.3403
12	.5014	.4115		.4835	.4115	.3142	.3403
13	.5373	.463	.5359	.4835	.3772	.3142	.394
14	.5373	.583	.5729	.5373	.4115	.3142	.4656
15	.5373	.463	.462	.5373	1.3203	.2957	.4298
16	.5373	.4973	.499	.4298	.3601		.4656
17	.5014	.463	.4805		.3772	.3881	.2686
18	.394	.4115	.3696	.1433	.3944	.3696	.3582
19	.3582	.4115	.499	.197	.4287	.4435	.4298
20	.591	.6516	.7023	.2865	.5658	.5175	.6447
21	.6984	.6687	.7023	.6447	.6001	.499	.6805
22	.7164	.703	.7207	.6447	.6173	.5914	.695
23	.695	.703	.7577	.6626	.6173	.5544	.6767
24	.7207	.6626	.6516	.7023	.6447	.583	.5729
Max	.7207	.703	.7577	.7207	1.3203	.5914	.695
Min	.3582	.394	.3601	.1433	.3601	.2957	.2686
Avg	.5511	.5127	.5229	.5006	.5141	.4207	.4671

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

DARYAPUR SUB-DN[305] BU 1635

Substation No/ Name :- 034012 / 33KV KHOLAPUR

Feeder No / Name : 208 / 11 KV Khalkoni

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1109	.1132	.1029	.1109	.1132	.0857	.0924
2	.1109	.1132	.1029	.1109	.1132	.0857	.0924
3	.1109	.0754	.1029	.0924	.0754	.0857	.0924
4	.0924	.0754	.1029	.0924	.0754	.0857	.0739
5	.0924	.0754	.0857	.0739	.0754	.0857	.0739
6	.0739	.0189	.0686	.0739	.0189	.0686	.0739
7	.0185	.0189	.0171	.0185	.0189	.0171	.0739
8	.0185	.0189	.0171	.0185	.0189	.0171	.0185
9	.0185	.0189	.0171	.0189	.0189	.0171	.0189
10	.0185	.0189	.0171	.0189	.0171	.0171	.0189
11	.0189	.0189	.0185	.0189	.0171	.0185	.0189
12	.0189	.0171		.0189	.0171	.0185	.0189
13	.0189	.0171	.0185	.0189	.0171	.0185	.0189
14	.0189	.0171	.0739	.0183	.0171	.0185	.0189
15	.0189	.0171	.0739	.0189	.0171	.0185	.0189
16	.0189	.0171	.0185	.0189	.0171	.0185	.0189
17	.0183	.0171	.0185		.0171	.0185	.0189
18	.0189	.0171	.0185	.0189	.0171	.0185	.0189
19	.0189	.0171	.0185	.0754	.0171	.0185	.0189
20	.0943	.0686	.0924	.0754	.0686	.0739	.0943
21	.1132	.1029	.1109	.1132	.1029	.0739	.1132
22	.1132	.1029	.1109	.1132	.1029	.0739	.1132
23	.1132	.1029	.1109	.1132	.0857	.0739	.1132
24	.1109	.1132	.1029	.1109	.1132	.0857	.0924
Max	.1132	.1132	.1109	.1132	.1132	.0857	.1132
Min	.0183	.0171	.0171	.0183	.0171	.0171	.0185
Avg	.0575	.0497	.0618	.0592	.0489	.0464	.0552

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

DARYAPUR SUB-DN[305] BU 1635

Substation No/ Name :- 034012 / 33KV KHOLAPUR

Feeder No / Name : 209 / kholapur ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4066	.3658					
2	.4066	.5121					
3	.3696	.5121					
4	.3696	.5853					
5	.3696	.6584					
6	.3696	.6584					
7	.3696	.6584					
8	.3696	.6584	.3048				
9	.3696	.6584	.3048				
10			.3048		.3048	.3048	.3658
11			.3696	.695	.3048	.3696	.3658
12				.7682	.3048	.3696	.3658
13				.7682			
14				.7682		.3696	
15				.7682	.3048	.3696	
16				.7682	.3048	.3696	
17					.3048	.3696	.3658
18					.3048		.3658
19					.3048		.3658
20							.3658
21							.3658
23							.2926
24	.3696	.3658					
Max	.4066	.6584	.3696	.7682	.3048	.3696	.3658
Min	.3696	.3658	.3048	.695	.3048	.3048	.2926
Avg	.377	.5633	.321	.756	.3048	.3603	.3577



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

DARYAPUR SUB-DN[305] BU 1635

Substation No/ Name :- 034054 / Nimbhari

Feeder No / Name : 211 / 11 KV Kumbhargaoon

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1222	1.1145	1.0631	1.1706	.9602	.961
2		1.086	1.0631	1.0631	1.134	.9431	.961
3		1.0974	1.0288	1.0631	1.1576	.9259	
4		1.0974	.9945	1.134	1.1317	.8916	
5		.924	.9602	1.0631	.9431	.8573	
6		.7468	.8573	1.1222	.8316	.7888	
7		.7167	.7202	.7202	.8215	.6173	
8		.8589	.7202	.7373	.8589	.6859	.8871
9	.779	.9593	.8059	.6859	.8962	.6687	.8686
10	.7956	.9259	.8059	.7202	.9328		
11	.9145	.8745	.8573		.8402	.7545	
12	.9619	.9259	.8573	.8779	.0686	.7762	.7545
13	1.0456	.9602	.8573	.9328	.7202	.8131	.7545
14	1.0679	1.046	.9945	1.2254	.7202	.8686	.9259
15	1.0317	.9088		1.2308	.7545	.924	1.0608
16	1.0242	.9259	.9945	1.0136	.6859		1.0608
17	.7655	.7888	.8916	.9145	.8402		.8621
18	.8402	.7202	.7545	.924	.8059		.8916
19	.381	.8573	.583	1.0349	.8573		.9602
20	.8596	1.0974	1.2689	1.2489	1.0288		1.2003
21	1.1949	1.2174	1.3032	1.2696	1.046		1.2003
22	1.2574	1.2517	1.3032	1.251	1.0288		1.2003
23	1.1949	1.1831	1.2003	1.1888	1.0117	1.0164	1.2803
24		1.1763	1.0631	1.1458	1.1949	.9774	.9795
Max	1.2574	1.2517	1.3032	1.2696	1.1949	1.0164	1.2803
Min	.381	.7167	.583	.6859	.0686	.6173	.7545
Avg	.9409	.9778	.9565	1.0274	.8951	.8418	.9888

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

DARYAPUR SUB-DN[305] BU 1635

Substation No/ Name :- 034054 / Nimbhari

Feeder No / Name : 212 / 11 KV MURHA

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					1.4449		1.3306
2					1.4083		1.3306
3					1.4377		
4					1.39		
5					1.3575		
6					1.4083		
7					1.4377		
8					1.5384		1.386
9					1.5546	.6173	1.4045
10	1.4586	.7888	1.6289	1.4403			
11	1.7013	1.6118	1.6804	1.6827		1.286	
12	1.6278	1.5947	1.6804	1.6108		1.3306	
13	1.6644	1.5775	1.6804	1.7556		1.386	
14	1.5912	1.5089	1.6118	1.647		1.423	
15	1.647	1.4232	1.6118	1.6448			
16	1.7002	1.5947	1.6118				
17	1.6289	1.6461	1.5089	.8596			
24			1.5432		1.4449		
Max	1.7013	1.6461	1.6804	1.7556	1.5546	1.423	1.4045
Min	1.4586	.7888	1.5089	.8596	1.3575	.6173	1.3306
Avg	1.6274	1.4682	1.6175	1.5201	1.4422	1.2086	1.3629

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

DARYAPUR SUB-DN[305] BU 1635

Substation No/ Name :- 034054 / Nimbhari

Feeder No / Name : 213 / CHINCHOLI GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4854	.463	.5121	.462	.4115	.4251
2		.4668	.4458	.5121	.462	.4115	.4066
3		.4572	.4458	.5121	.462	.3944	
4		.4572	.4287	.5121	.439	.3944	
5		.4251	.4458	.5121	.4338	.3944	
6		.4191	.4115	.5121	.3696	.3772	
7		.4001	.3258	.3658	.3772	.3429	
8		.3584	.3429	.3544	.4001	.3258	.3696
9	.3109	.3547	.3258	.3658	.362	.2915	.3511
10	.3292	.3601	.3658	.3658	.3584		
11	.3475	.3086	.3292	.3696	.3258	.2572	.3292
12	.4251	.3772	.3292	.4108	.3086	.3326	.3292
13	.4294	.3772	.3292	.4294	.3086	.3142	.3658
14	.4251	.3944	.439	.4572	.3258	.3326	.3658
15	.4525	.3601	.439	.4572	.3601		.3658
16	.4294	.3601	.439	.3982	.2915		.3658
17	.4001	.3258	.3292	.3048	.3258		.3292
18	.3239	.3086	.2926	.2858	.3429		.3658
19	.381	.3086	.3292	.4066	.3601		.4024
20	.5281	.3944	.439	.5228	.4458		.5121
21	.5415	.4458	.5487	.5068	.4287		
22	.5415	.4973	.5487	.5121	.4458		.5121
23	.5335	.4801	.5487	.4755	.4115	.4435	.5121
24		.5144	.5121	.5068	.462	.4115	.4251
Max	.5415	.5144	.5487	.5228	.462	.4435	.5121
Min	.3109	.3086	.2926	.2858	.2915	.2572	.3292
Avg	.4266	.4015	.4106	.4403	.3862	.3623	.3960

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

DARYAPUR SUB-DN[305] BU 1635

Substation No/ Name :- 034077 / 33/11 KV GAIWADI SUBSTATION

Feeder No / Name : 214 / 11 KV SAI NAGAR Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1313	1.9753	2.0328	2.037		1.848	1.6221
2	2.1313	1.8656	2.0328	2.037		1.848	1.6221
3	2.1313	1.848	1.9959	2.037		1.8111	1.6221
4	2.1313	1.7556	1.9589	2.037		1.7372	1.6221
5	2.0748	1.7372	1.7926	1.8861		1.5893	1.5089
6	1.8861	1.4784	1.5154	1.5089		1.4415	1.4712
7	1.3957	1.3121	1.3306	1.2826		1.2382	1.1694
8	1.2826	1.2382	1.1458	1.2826		1.1273	1.094
9	1.2071	1.1827	1.0534	1.1694		1.0349	1.0562
10	1.1694	1.1458	1.1458	1.1317		1.0903	.9997
11	1.2197	1.2567	1.2826		1.1458	.9997	
12	1.2936	1.2752	1.2637		1.1827	1.0374	
13	1.386	1.4415	1.4146		1.2567	1.094	
14	1.5154	1.5708	1.5844		1.2689	1.6598	
15	1.6632	1.6448	1.5278		1.4045	1.7541	
16	1.7187	1.6078	1.5655		1.3306	1.7353	
17	1.423	1.423	1.3957		1.2382	1.6221	
18	1.2567	1.2567	1.2826		1.3306	1.1317	
19	1.4045	1.3491	1.3203		1.4045	1.3203	
20	1.7926	1.7187	1.6409		1.5893	1.5089	
21	1.8111	1.8111	1.7353		1.7002	1.5089	
22	1.9404	1.9959	1.9239		1.848	1.5844	
23	2.0513	2.1253	2.0936		1.9035	1.6598	
24	2.1691	2.0328	2.0698	2.0748		1.848	1.6221
Max	2.1691	2.1253	2.0936	2.0748	1.9035	1.848	1.6221
Min	1.1694	1.1458	1.0534	1.1317	1.1458	.9997	.9997
Avg	1.6744	1.5853	1.5877	1.6804	1.4310	1.4679	1.4009

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

DARYAPUR SUB-DN[305] BU 1635

Substation No/ Name :- 034077 / 33/11 KV GAIWADI SUBSTATION

Feeder No / Name : 215 / 11 KV TAKALI Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6979	.5729	.6653	.679		.4435	.415
2	.6979	.5359	.6653	.679		.4435	.415
3	.6979	.5544	.6653	.679		.4435	.415
4	.6979	.5175	.6653	.679		.4435	.415
5	.6602	.5544	.6099	.5658		.4435	.3772
6	.6413	.5175	.5175	.5281		.4066	.3395
7	.5658	.4435	.5544	.4904		.3881	.3018
8	.5847	.5544	.6099	.5658		.4251	.2452
9	.7167	.6283	.7577	.7545			.2641
10	.7167	.7023	.8871	.8299		.4435	.2452
11	.7392	.7762	.8299		.6653	.6224	
12	.7207	.8131	.7733		.7762	.7167	
13	.7023	.8686	.8676		.9055	.7733	
14	.7392		.8676		.8871	.811	
15	.8131	.3881	.811		.5544	.7922	
16	.7947	.5175	.8299		.5914	.7545	
17	.7392	.7207	.8676		.7577	.679	
18	.7392	.5914	.7922		.7762	.6224	
19	.6099	.7762	.8299		.8131	.6036	
20	.7392	.961	.9997		.8131	.5281	
21	.7392	.9425	.9997		.6653	.415	
22	.6838	.8686	.7922		.5544	.4338	
23	.6838	.6838	.7167		.4805	.4338	
24	.6979	.5914	.7023	.679		.4435	.415
Max	.8131	.961	.9997	.8299	.9055	.811	.415
Min	.5658	.3881	.5175	.4904	.4805	.3881	.2452
Avg	.7008	.6557	.7616	.6481	.7108	.5439	.3498

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

DARYAPUR SUB-DN[305] BU 1635

Substation No/ Name :- 034077 / 33/11 KV GAIWADI SUBSTATION

Feeder No / Name : 402 / 33 KV Daryapur Main

DIVISION FEEDER

Incomer Feeder KV- 33 /  
INCOMING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9424	2.524	2.6337	2.6595		2.2497	2.0936
2	2.8292	2.4143	2.6337	2.6595		2.2497	2.0936
3	2.8292	2.3045	2.6337	2.6595		2.1948	2.0936
4	2.8292	2.2497	2.5789	2.6595		2.1399	2.037
5	2.7161	2.3045	2.3594	2.4331		1.9753	1.8673
6	2.5463	2.0851	2.0302	2.037		1.8107	1.8107
7	2.037	1.7558	1.8656	1.8107		1.5912	1.5278
8	1.9805	1.8107	1.701	1.8673		1.5364	1.4146
9	1.9805	1.9204	1.8107	1.9805		.9877	1.4146
10	1.9805	2.0302	2.0302	2.037		1.5364	1.3014
11	2.0851	2.0302	2.0936		1.8107	1.6975	
12	2.0851	2.0302	2.0936		1.9204	1.8107	
13	2.1399	2.2497	2.32		2.0851	1.8673	
14	2.3045	1.5364	2.4897		2.1948	2.5463	
15	2.5789	2.0302	2.32		1.9204	2.6029	
16	2.524	2.1399	2.4331		1.9204	2.4897	
17	2.1948	2.1399	2.2634		1.9753	2.2634	
18	2.0302	1.8656	2.0936		2.0851	1.7541	
19	2.0851	2.0851	2.1502		2.1948	1.8107	
20	2.524	2.6886	2.6595		2.3594	2.037	
21	2.5789	2.6886	2.7726		2.3045	1.9239	
22	2.6886	2.7984	2.7726		2.3594	2.0936	
23	2.7984	2.7435	2.7726		2.3594	2.1502	
24	2.999	2.6886	2.7435	2.7161		2.2497	1.8673
Max	2.999	2.7984	2.7726	2.7161	2.3594	2.6029	2.0936
Min	1.9805	1.5364	1.701	1.8107	1.8107	.9877	1.3014
Avg	2.4286	2.2131	2.3440	2.3200	2.1146	1.9820	1.7747

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

DARYAPUR SUB-DN[305] BU 1635

Substation No/ Name :- 037019 / 132 KV Daryapur

Feeder No / Name : 401 / 33 KV Daryapur

LT LIS Feeder

Feeder KV- 33 / INCOMING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	3.4374	2.6886	2.8172	2.9321	3.1824	2.7149	2.5503
Max	3.4374	2.6886	2.8172	2.9321	3.1824	2.7149	2.5503
Min	3.4374	2.6886	2.8172	2.9321	3.1824	2.7149	2.5503
Avg	3.4374	2.6886	2.8172	2.9321	3.1824	2.7149	2.5503

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

DARYAPUR SUB-DN[305] BU 1635

Substation No/ Name :- 037019 / 132 KV Daryapur

Feeder No / Name : 402 / 33 KV Yeoda

LT LIS Feeder

Feeder KV- 33 / INCOMING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.3045	2.1948	2.2262	2.3525	2.524	.9231	2.2177
Max	2.3045	2.1948	2.2262	2.3525	2.524	.9231	2.2177
Min	2.3045	2.1948	2.2262	2.3525	2.524	.9231	2.2177
Avg	2.3045	2.1948	2.2262	2.3525	2.524	.9231	2.2177



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

DARYAPUR SUB-DN[305] BU 1635

Substation No/ Name :- 037019 / 132 KV Daryapur

Feeder No / Name : 403 / 33 KV Kumbhargaoan  
Feeder KV- 33 / INCOMING

LT LIS Feeder

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.2197	1.2071	1.0517	1.2757	2.7984	1.086	2.4949
Max	1.2197	1.2071	1.0517	1.2757	2.7984	1.086	2.4949
Min	1.2197	1.2071	1.0517	1.2757	2.7984	1.086	2.4949
Avg	1.2197	1.2071	1.0517	1.2757	2.7984	1.086	2.4949

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

DARYAPUR SUB-DN[305] BU 1635

Substation No/ Name :- 037019 / 132 KV Daryapur

Feeder No / Name : 404 / 33 KV Kholapur

LT LIS Feeder

Feeder KV- 33 / INCOMING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	3.6591	3.4019	3.6534	3.1927	4.4993	3.3122	3.3819
Max	3.6591	3.4019	3.6534	3.1927	4.4993	3.3122	3.3819
Min	3.6591	3.4019	3.6534	3.1927	4.4993	3.3122	3.3819
Avg	3.6591	3.4019	3.6534	3.1927	4.4993	3.3122	3.3819

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

DHARNI S/DN.[308]

BU 3085

Substation No/ Name :- 034007 / 33 KV DABAKA

Feeder No / Name : 213 / 11 KV Susarda

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.8059	.823				
2				.8059	.5487	.6859	.6859
3	.823	.7716	.7888				
4				.823	.6173	.6516	.6859
5	.7888	.7373	.7716				
6				.8916	.6859	.703	.7373
7	.823	.7545	.7202				
8				.9774	.7545	.8059	.7373
9	.8573	.823	.703				
10				.9602	.7545	.7373	.8916
11		.8059	.6859				
12		.8059		.9431	.7888	.7545	.823
13			.823				
14				.9088	.7545	.6173	.7545
15			.8402				
16		.583		.9088	.7373	.7716	.7888
17			.7888				
18		.7716		.8745	.8573	.8745	
19			.9431				
20	.7888	.8573			.8402	.9088	
21			.9945	.6516	.823	.8059	.8745
22		.823					
23		.7888		.7545			
24	.7716	.7545	.7716	.7716	.7373	.7545	.7202
Max	.8573	.8573	.9945	.9774	.8573	.9088	.8916
Min	.7716	.583	.6859	.6516	.5487	.6173	.6859
Avg	.8157	.7756	.8045	.8559	.7416	.7559	.7699

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

DHARNI S/DN.[308]

BU 3085

Substation No/ Name :- 034007 / 33 KV DABAKA

Feeder No / Name : 214 / 11 KV Chendu

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.6173		.5487	
2	.7545	.5487	.583		.2743		
3				.583	.2743	.5144	.4801
4	.7202	.5487	.4801				
5				.583	.2743	.4458	.4458
6	.6859	.5144	.4115				
7				.6173	.2743	.4801	.4115
8	.7202	.583	.4458				
9					.2401	.4458	.3429
10		.6173	.3429	.3429			
11				.3086	.2401	.3429	.2401
12		.6173	.3772				
13				.1372	.3429	.6516	.2743
14			.3772				
15				.1372	.3772	.2058	.2743
16		.2743	.3429				.2743
17				.1715	.4115	.4801	
18		.6859	.5487				
19					.5487	.7888	
20	.6859	.7545	.6859				
21			.7202	.3429	.6859	.7888	.583
22		.7888					
23		.7545		.4115			
24	.7888	.5487	.7202	.583	.4115	.583	.5144
Max	.7888	.7888	.7202	.6173	.6859	.7888	.583
Min	.6859	.2743	.3429	.1372	.2401	.2058	.2401
Avg	.7259	.6030	.5030	.4030	.3629	.5230	.3841

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

DHARNI S/DN.[308]

BU 3085

Substation No/ Name :- 034014 / 33 KV DHARNI

Feeder No / Name : 201 / 11 KV Dharni

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.6385	1.576		1.5242	
2			1.6004	1.5223		1.5242	
3			1.5242	1.5223		1.5242	
4			1.4861	1.5043		1.4861	
5			1.448	1.5223		1.448	
6			1.4861	1.5043		1.4289	
7			1.5051			1.5623	
8	1.4232	1.3889	1.4098	1.5043		1.467	
9			1.5813	1.4864		1.4861	
10			1.6004	1.6832			1.5089
11			1.5746	1.7924			
12			1.6289	1.7375			
13		1.6766	1.6832	1.7918			
14		1.6194	1.6289	1.7918			
15		1.6004	1.6651	1.8461			
16		1.6004	1.6289	1.7375	1.8861		
17		1.5432	1.6095	1.7194	1.6766		
18		1.467	1.5912	1.6108	1.7909		
19		1.4861	1.6095	1.7375	1.829		
20		1.7718	1.7551		1.9243		
21			1.773		1.848		
22		1.7147	1.7193		1.7528		
23		1.6766	1.6834		1.6004		
24	1.5775	1.4575	1.6575	1.5947		1.5623	
Max	1.5775	1.7718	1.773	1.8461	1.9243	1.5623	1.5089
Min	1.4232	1.3889	1.4098	1.4864	1.6004	1.4289	1.5089
Avg	1.5004	1.5836	1.6037	1.6413	1.7885	1.5013	1.5089

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

DHARNI S/DN.[308]

BU 3085

Substation No/ Name :- 034014 / 33 KV DHARNI

Feeder No / Name : 203 / 11 KV SHIRPUR

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1222	1.3336	1.3643		.9526	
2	1.086	1.2574	1.3611		.9526	
3	1.086	1.2574	1.3432		.9526	
4	1.1584	1.2574	1.3432		.9526	
5	1.1584	1.3336	1.4685		.9526	
6	1.1946	1.3336	1.5947		1.0288	
7	1.3717	1.5242	1.7528		1.2574	
8	1.5203	1.5623	1.893		1.3336	
9	1.6461	1.5242	1.9071		1.2955	
10	2.2443	1.5242				1.6461
11	1.3394	1.5424	1.7194			
12	1.3756	1.5604	2.2081			
13	.7621	1.595	1.8099	1.2193		
14	.8002	1.7337	2.0995	1.2955		
15	.8383	1.5424	1.9547	1.2574		
16	.9145	1.6297	2.1719	1.2574		
17	.9526	1.6297	2.1719	1.2193		
18	.9526		2.1719	1.1812		
19		1.7337	1.9547	1.2574		
20	1.6385	1.8347		1.1431		
21		1.7337	.6516	.9907		
22	1.448	1.6124	.724	.9907		
23	1.3717	1.5223	.6154	.9526		
24	1.0974	1.3336	1.4022		.9145	
Max	2.2443	1.8347	2.2081	1.2955	1.3336	1.6461
Min	.7621	1.2574	.6154	.9526	.9145	1.6461
Avg	1.2309	1.5179	1.6220	1.1604	1.0593	1.6461

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

DHARNI S/DN.[308]

BU 3085

Substation No/ Name :- 034014 / 33 KV DHARNI

Feeder No / Name : 204 / 11 KV KALPI

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5716	.362	.7468	1.1431	
2			.5716	.362	.7468	1.1431	
3			.5716	.362	.724	1.1431	
4			.5716	.362	.724	1.1431	
5			.5716	.362	.7602	1.3336	
6			.5716	.4887	.7602	1.3336	
7			.6668	.5792	.7602	1.3336	
8	.6859	.1715	.7621	.543	.8688	1.3336	
9			.7621	.4163	.8688	1.1431	
10			.6668	.6878	1.3336		.6516
11			.443		1.3336		
12			.443				
13		.5716	.5258		1.2384		
14		.5716	.4075		1.1431		
15		.5716	.394		1.0479		
16		.5716	.4477		1.0479		
17		.5716	.6485		1.0479		
18		.5716	.3898		1.2384		
19		.6668	.443		1.4289		
20		.5716	.6661		1.5242		
21			.4784		1.3336		
22		.5716	.443		1.2384		
23		.5716	.443		1.1431		
24	.4287	.1715	.5716	.4163	.6335	1.1431	
Max	.6859	.6668	.7621	.6878	1.5242	1.3336	.6516
Min	.4287	.1715	.3898	.362	.6335	1.1431	.6516
Avg	.5573	.5129	.5430	.4492	1.0301	1.2193	.6516

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

DHARNI S/DN.[308]

BU 3085

Substation No/ Name :- 034014 / 33 KV DHARNI

Feeder No / Name : 205 / 11 kv Bairagad

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5716	.7442		.7621	
2				.7087		.7621	
3				.6733		.7621	
4				.6733		.7621	
5				.7087		.8573	
6			.1905	.7087		.8573	
7			.1905	.8505		1.0479	
8		.8573	.1905	.964		1.1431	
9			.6668	1.0517		1.2384	
10			.7621		.9335		.6516
11			.8764		1.1431		
12			.7537	1.1222			
13		.7621	.9114	1.1765	.9526		
14		.5716	.964	.9955	.9526		
15		.5716	.8764	.9955	1.1431		
16		.5716	.7888	.9955	.9526		
17		.6668		.9955	1.1431		
18		.6668	.8413	1.086	1.1431		
19		.8573	.8238	1.1765	1.1431		
20		.8573	.964		1.1431		
21			.929	.7602	1.0479		
22		.7621	.9114	.724	.9526		
23		.6668	.8413	.724	.7621		
24	.8059	.6001	.5716	.7973		.7621	
Max	.8059	.8573	.964	1.1765	1.1431	1.2384	.6516
Min	.8059	.5716	.1905	.6733	.7621	.7621	.6516
Avg	.8059	.7010	.7171	.8872	1.0317	.8955	.6516



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

DHARNI S/DN.[308]

BU 3085

Substation No/ Name :- 034062 / 33kv kadhav s.s

Feeder No / Name : 206 / 11KV PATIYA

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.703	.3772	.394	.4161	.4115	.4161	.3814
2	.7802	.4681	.3898	.3944	.4508	.4207	.3898
3	.7802	.4115	.3898	.3944	.567	.4252	.3982
4	.7545	.5028	.362	.4557	.5434	.4298	.3856
5	.7545	.4115	.4163	.5316		.4344	.394
6	.6687	.7802	.4298	.5083		.5144	.4681
7	.7108	.6859	.3761	.6805		.5201	.3898
8	.8764	.7975	.4938	.8145		.5258	.4681
9	.7802	.7202	.4207	.8413		.5493	.5138
10	.8322	.7108	.3944	.6516	.4344	.5373	.4344
11	.6687	.7455	.4115	.7362	.7522	.2715	.5784
12		.7455	.4508	.7712	.6626	.4115	.5014
13	.6173	.5144	.4733	.815	.631	.5375	.4334
14	.9189		.4508	.7282	.5249	.5434	.6344
15	.8842		.4334	.7282	.7421	.5609	.5959
16	.7628		.4161	.7537	.724	.5552	.5316
17	.7108		.5784	.7888	.7316	.4854	.5493
18	.3944	.4458	.5784	.463	.7499	.0354	.5609
19	.3944	.5144		.7186	.7499	.0362	.5487
20	.463	.4801			.4706	.3506	.5201
21	.4287	.4287		.4161	.4706	.3582	.5959
22	.4115	.4458		.3772	.4298	.4161	.5028
23	.3944	.3772		.4334	.3681	.4252	
24	.4287	.3944	.4119	.3944	.3944		.3982
Max	.9189	.7975	.5784	.8413	.7522	.5609	.6344
Min	.3944	.3772	.362	.3772	.3681	.0354	.3814
Avg	.6573	.5479	.4353	.6005	.5689	.4244	.4858

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

DHARNI S/DN.[308]

BU 3085

Substation No/ Name :- 034062 / 33kv kadhav s.s

Feeder No / Name : 207 / 11KV HARISAL

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8402	.8669	.8954	.8764	.7716	1.0402	.8669
2	.9536	.8322	.8505	.8589	.7545	1.0517	.8859
3	.9536	.8059	.8328	.7488	.7975	1.0631	.905
4	1.0517	.7716	.8507	.7802	.8413	1.0745	.8764
5	1.1043	.8322	.8326	.8413	.8859	1.086	.8954
6	1.1919	.9536	.8596	.9391	.8859	.9431	.9362
7	1.3643	1.1919	.8775	1.0099	1.1104	1.0402	1.0985
8	1.3289	1.3321	.9145	1.0924	1.1283	1.0867	1.3003
9	1.2757	1.1789	.8413	1.0745	1.1584	1.0985	.7619
10	1.262	1.1568	.9036	.964	1.086	1.134	1.1946
11	1.2269	1.1744	.8149	1.0985	1.0745	1.2357	
12	.9536	1.1393	.8322	1.0985	.9671	1.086	1.1104
13	.9362	.7716	.7888	1.1462		1.1488	1.1269
14	.7716	.6859	.8859	1.0277	.8869	1.0402	.9774
15	.7888	.5144	.8413	1.1104	.8869	.9816	1.0692
16	.7888	.4973	.8859	1.0454	.9955	1.0277	1.166
17	1.0923	.7282	.6516	.964	1.1888	.8495	1.2048
18	.7202	.6859		.9391	1.262	1.0277	1.3321
19	.7888	.9015		1.1283	1.262	1.0498	1.3032
20	.9536	1.0056			1.1765	1.0517	1.2483
21	1.0229	1.0056		1.0631	1.1584	1.0745	1.1218
22	.9882	.9882		1.0631	1.0745	.9882	1.0576
23	.9259	.8916		.9991	.8764	.9391	
24	.9536	.8842	.8954	.9114	.9114		.9231
Max	1.3643	1.3321	.9145	1.1462	1.262	1.2357	1.3321
Min	.7202	.4973	.6516	.7488	.7545	.8495	.7619
Avg	1.0099	.9082	.8475	.9904	1.0061	1.0486	1.0619

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

DHARNI S/DN.[308]

BU 3085

Substation No/ Name :- 034082 / GONDWADI (KALAMKHAR)

Feeder No / Name : 208 / 11 KV BHOKARBARDI

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	25-JUN-17	27-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	.5571	.2439		.5658
24	.5316	.1829	.4877	
Max	.5571	.2439	.4877	.5658
Min	.5316	.1829	.4877	.5658
Avg	.5444	.2134	.4877	.5658

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

ACHALPUR DIVISION[623]

DHARNI S/DN.[308]

BU 3085

Substation No/ Name :- 034082 / GONDWADI (KALAMKHAR)

Feeder No / Name : 209 / 11 KV KALAMKHAR

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	25-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
12	.8951	.6249	
24	.7545	.4877	.6706
Max	.8951	.6249	.6706
Min	.7545	.4877	.6706
Avg	.8248	.5563	.6706

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

AMRAVATI (R) SUB-DN[298] BU 2984

Substation No/ Name :- 034003 / 33KV S/S MAHULI

Feeder No / Name : 201 / 11 KV DAWARGAON GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6722	.5914	.7468	.6584	.6219	.6348	.6089
2	.6348	.5914	.7468	.6584	.6219	.6348	.6089
3	.6348	.5914	.7095	.6584	.6219	.5975	.6089
4	.6348	.5487	.7095	.6584	.5853	.5975	.567
5	.5975	.5487	.6722	.5487	.5853	.5544	.5316
6	.4854	.4755	.5415	.5121	.5487	.4805	.4207
7	.4066	.4706	.4298	.394	.5121	.4298	.3856
8	.3658	.4706	.3982	.3582	.4755	.3856	.4298
9	.3982	.439	.3856	.4115	.4755		.4298
10	.3982	.439	.3155	.4115	.439		.4024
11	.3982	.3801	.4024	.4801	.4344	.3658	.3658
12	.543	.3801	.5487	.5144	.4706	.3292	.3658
13	.5487	.5373	.4755	.5144	.5068	.3292	.3658
14	.5487	.5373		.5316	.4207	.4024	.3292
15	.5487	.4066		.5144	.3086	.362	.3292
16	.5601	.4784	.6219	.4115	.3086	.3258	.3292
17	.5601	.4298	.6219	.3429	.3681	.362	.3292
18	.4108	.3856	.4024	.4458	.4108	.5487	.439
19	.4854	.5175	.6584	.4801	.4668	.5487	.4938
20	.5914	.6838	.695	.5144	.5228	.5487	.7133
21	.5914	.7842	.695	.5487	.6722	.567	.695
22	.5914	.7842	.6584	.6584	.6722	.6219	.695
23	.5914	.7655	.6584	.6516	.6535	.6219	.6584
24	.6722	.5914	.7468	.583		.6348	.6219
Max	.6722	.7842	.7468	.6584	.6722	.6348	.7133
Min	.3658	.3801	.3155	.3429	.3086	.3258	.3292
Avg	.5362	.5345	.5836	.5192	.5088	.4947	.4885

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

AMRAVATI (R) SUB-DN[298] BU 2984

Substation No/ Name :- 034003 / 33KV S/S MAHULI

Feeder No / Name : 202 / 11 KV YAWALI AG FEEDER

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3814	.1524	.0381	.0366	.0381	.3353
2		.3814	.1524	.0381	.0366	.0381	.3353
3			.1524	.0381	.0366	.0381	.3201
4			.1524	.0381	.0377	.0381	.3201
5			.2134	.0381	.0377	.0381	.3437
6			.2286		.0377	.0381	.4374
7			.3658	.4515			.3125
8			.4961	.5719			.4588
9	.5335	.0762	.5155	.6935			.5571
10		.373	.5312	1.3946	.7545		.1696
11	.3391	.3963	.5441	.8596	.6401	.1638	.583
12	.373	.3963	.5441	.8596	.5376	.1509	.583
13	.4641	.3185	.5441	.8596	.6718	.1677	.6173
14				.8954	.6796	.1341	.6584
15	.3315	.3311	.6401	.3658	.5138	.2149	.6173
16	.3018	.3963	.6554	.3658	.4973	.2865	.6173
17	.3018	.4064	.6554	.3658	.4049	.1791	.6173
18	.0762		.0566	.4024	.0762	.0762	
19	.0762	.0381	.0229	.4024	.0762	.0762	.0381
20	.0762	.0381	.0572	.4024	.0762	.0762	.0381
21	.0762	.0381	.0572	.3658	.0381	.4024	.0381
22	.0762	.0381	.0381	.3292	.0381	.2926	.0381
23	.0762	.0381	.0381	.3292	.0762	.2926	.0381
24	.4096	.208	.1337	.0366		.0381	.3734
Max	.5335	.4064	.6554	1.3946	.7545	.4024	.6584
Min	.0762	.0381	.0229	.0366	.0366	.0381	.0381
Avg	.2508	.2410	.3021	.4409	.2652	.1390	.3673

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

AMRAVATI (R) SUB-DN[298] BU 2984

Substation No/ Name :- 034003 / 33KV S/S MAHULI

Feeder No / Name : 203 / 11 KV MAHULI AG FEEDER

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2652	.0381	.0762	.0377	.0377		.2561
2	.2652	.0381	.0762	.0377	.0377		.2561
3	.2652	.0381	.0762	.0377	.0377		.2561
4	.2652	.0381	.0762	.0377	.0377		.2561
5	.2652	.0381	.0762	.0377	.0566		.3125
6	.2949	.0381	.0762	.0566	.0566		.3437
7	.2949	.0381	.0381	.0566	.0566		.3437
8	.2883	.0381		.0566	.0377		.426
9	.2883	.0381	.0191	.0566	.0377		.4915
10	.3052	.3018	.3906	.3658	.0377		
11	.4409	.3906	.4572	.6081	.0381		.1143
12	.2374	.3906	.5487	.6081	.0381	.0381	.1143
13	.1677	.4572	.5487	.6401	.0381	.0381	.1143
14	.2683	.4784	.5487	.6722	.0381	.0381	.1143
15		.4784	.5487	.6401	.0381	.0381	.1143
16	.2713	.4666	.0914	.6401		.0381	.1524
17	.2713	.4365	.5487	.5243	.0381	.0381	.1715
18	.0381	.0572	.0566	.0328	.0381	.0381	.1143
19	.0381	.0572	.0377	.0328	.0381	.0381	.1524
20	.0381	.0762	.0754	.0328	.0381	.0381	.1715
21	.0381	.0762	.0754	.0328	.0381	.0381	.1698
22	.0381	.0762	.0754	.0381	.0381	.0381	.1698
23	.0381	.0762	.0754	.0381	.0381	.0381	.1698
24	.2652	.0381	.0762	.0381			.3395
Max	.4409	.4784	.5487	.6722	.0566	.0381	.4915
Min	.0381	.0381	.0191	.0328	.0377	.0381	.1143
Avg	.2151	.1750	.2030	.2233	.0405	.0381	.2228

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

AMRAVATI (R) SUB-DN[298] BU 2984

Substation No/ Name :- 034003 / 33KV S/S MAHULI

Feeder No / Name : 204 / 11 KV M.I.D.C. FEEDER  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2195	.4108	.2926	.1463	.0617	.2195
2		.2195	.4108	.2926	.1463	.0617	.2926
3		.2195	.4108	.2926	.1463	.0617	.2926
4		.1829	.4108	.1829	.1463	.0617	.2926
5		.181	.181	.1463	.1097	.0926	.2103
6		.1086	.1227	.0943	.1097	.0617	.1753
7		.1086	.1006	.1132	.1097	.0617	.1753
8		.1086	.0724	.1132	.1772	.0309	.2172
9	.0747	.1075	.1254	.1132	.1829	.1132	.2172
10	.1494	.1075		.1132	.1463	.2033	.1086
11		.1734		.112	.1463	.1848	.2534
12		.1734	.1463	.112	.1646	.1417	.181
13		.1052		.0934	.1187		.2534
14		.1448	.1097	.0934	.124		.2715
15	.2241	.1886	.1097	.0934	.1886	.2896	.2534
16	.1829	.2075	.1463	.0373		.2896	.2534
17	.1829	.1463	.1463	.0747	.168	.2896	.181
18	.1829	.1094	.1829	.0747	.0671	.2926	.3658
19	.1478	.0549	.1097	.0747	.0671	.2561	.5144
20	.1478	.0926	.1097	.0934		.2195	.3292
21	.1478	.0924	.1097	.0934	.0617	.181	.2561
22	.1478	.0924	.1097	.0934	.0617	.1829	.2561
23	.1478	.3696	.1097	.0934	.0617	.1829	.2195
24	.0743	.1478	.415	.0934		.0617	.1097
Max	.2241	.3696	.415	.2926	.1886	.2926	.5144
Min	.0743	.0549	.0724	.0373	.0617	.0309	.1086
Avg	.1509	.1526	.1929	.1244	.1262	.1537	.2458



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

AMRAVATI (R) SUB-DN[298] BU 2984

Substation No/ Name :- 034003 / 33KV S/S MAHULI

Feeder No / Name : 205 / 11 KV MAHULI GAOTHAN  
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	1.2437	1.3169	1.39	1.39	1.2254	1.1946
2	1.262	1.2437	1.3169	1.39	1.3535	1.2254	1.1946
3	1.262	1.2437	1.2437	1.3535	1.3535	1.1706	1.1946
4	1.2437	1.2567	1.2437	1.3535	1.3535	1.1706	1.1946
5	1.2437	1.1088	1.2567	1.3169	1.2803	1.1458	1.0974
6	1.0242	1.0349	1.0425	1.1706	1.2254	1.0903	1.0608
7	.9877	1.0349	1.0208	1.0974	1.2071	.9511	.9511
8	.905	.8501	.9214	.9511	1.1706	.9694	.9877
9	.8238	.8413	.9671	1.0242	1.1157	.8596	.9877
10	.788	.8779	1.0029	1.0242	.9511	.8417	.9774
11		.8589	1.0029	1.1203	.9511	.7964	.9145
12		.8589	1.0029	1.1949	1.3112	.724	.9511
13		.9114	1.0745	1.2323	.8859	.7602	.9877
14	.9774	.4908		1.251	.9391	.7964	.9877
15	1.0498	.6661	.8596	1.251	.6733	.788	.9145
16	1.0242	1.1283	1.0745	1.0642	.6733	.788	.9145
17	.9145	1.0985	.1463	.8962	.9231	.7522	.7865
18	.8779	.9391	.9313	.9335	.9511	.8688	.9145
19	1.0608	1.0277	.9877	1.0082	.9694	.9412	.9694
20	1.0974	1.267	1.0242	1.307	.9877	1.0136	1.134
21	1.2071	1.3717	.6584	1.3443	1.2254	1.1222	1.1706
22	1.2437	1.3717	1.2803	1.3443	1.2254	1.2071	1.2071
23	1.2308	1.3535	1.39	1.419	1.2254	1.2071	1.2437
24	1.3535	1.2308	1.3169	1.419		1.2254	1.2071
Max	1.3535	1.3717	1.39	1.419	1.39	1.2254	1.2437
Min	.788	.4908	.1463	.8962	.6733	.724	.7865
Avg	1.0885	1.0546	1.0470	1.2024	1.1018	.9850	1.0476

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

AMRAVATI (R) SUB-DN[298] BU 2984

Substation No/ Name :- 034003 / 33KV S/S MAHULI

Feeder No / Name : 206 / 11 KV DAWARGAON AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	24-JUN-17
HR	Load (MW)
21	.6584
Max	.6584
Min	.6584
Avg	.6584

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

AMRAVATI (R) SUB-DN[298] BU 2984

Substation No/ Name :- 034032 / 33 KV S/S MARDI

Feeder No / Name : 202 / 11 KV MARDI

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	22-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)
1	.3201	
14		.2743
15		.2515
16		.2743
17		.2743
18		.2515
19		.3429
20		.3658
21		.3544
22		.3429
23		.3429
24	.3658	
<b>Max</b>	<b>.3658</b>	<b>.3658</b>
<b>Min</b>	<b>.3201</b>	<b>.2515</b>
<b>Avg</b>	<b>.3430</b>	<b>.3075</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

AMRAVATI (R) SUB-DN[298] BU 2984

Substation No/ Name :- 034032 / 33 KV S/S MARDI

Feeder No / Name : 203 / 11 KV VIRGAVHAN

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1105	.1063	.076	.0914		.1349	.0995
2		.1063	.0543	.0914		.1349	.096
3		.1063	.0442	.0914		.1349	.0995
4		.1063	.0442	.0914		.1349	
5		.1063	.0553	.0914		.1124	
6		.0945	.0663	.0914		.0674	
7		.0945	.0553	.0914		.0787	
8		.0709	.0553	.1029		.045	
9		.1536	.0663	.0914		.045	
10		.1124	.0827	.1029			.064
11		.1105	.0709	.1486			.0686
12		.1547	.0827	.1372			.0686
13		.1349	.0914	.1486			.0914
14			.08	.1486		.0553	.0572
15	.1181		.0914	.16		.0553	.0686
16	.1063		.08	.1486		.0533	.0686
17	.1299		.0686			.064	.0686
18	.1181		.0686		.0553	.0854	.0686
19	.1181	.1216	.0914		.0442	.0995	.0572
20	.1063	.1326	.0914		.0884	.0899	.0914
21	.0945	.076	.0914		.0995	.0884	.0914
22	.1063	.0884	.0914		.1012	.0838	.0914
23	.1181	.0869	.0914		.1012	.1012	.0914
24	.1105	.1063	.0869	.0914		.1124	.096
Max	.1299	.1547	.0914	.16	.1012	.1349	.0995
Min	.0945	.0709	.0442	.0914	.0442	.045	.0572
Avg	.1124	.1089	.0741	.1129	.0816	.0888	.0799

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

AMRAVATI (R) SUB-DN[298] BU 2984

Substation No/ Name :- 034032 / 33 KV S/S MARDI

Feeder No / Name : 205 / 11 KV Industrial Feedr SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1677	.1781	.2286		.2743
2		.1677	.1781	.2134		.2743
3		.1677	.1781	.2286		.2743
4		.1677	.1943	.2134		.2801
5		.1677	.1619	.2286		.2561
6		.1981	.1619	.1981		.2561
7		.1829	.1619	.1981		.2172
8		.2134	.1619	.2134		.2172
9		.2134	.1296	.2134	.0781	.2561
10		.2812	.2134	.1677		.3077
11		.3281	.2134	.1524	.3841	.3048
12		.3125	.3353	.1829	.3801	.3048
13		.3239	.2743	.1219		.3048
14			.3353	.1524	.2561	.1829
15	.1677		.3658	.1677	.1494	.2743
16	.2286		.2134	.1524	.2926	.2896
17	.2134		.2286		.3258	.2743
18	.2134		.2134		.3109	.2134
19	.1829		.2134		.2743	.2286
20	.1677	.1562	.2134		.2534	.2286
21	.2743	.1562	.2134		.2743	.2286
22	.1829	.1562	.2134		.2614	.2286
23	.1829	.0156	.2134		.2561	.2134
24	.1718	.1677	.1781	.2134		.2743
Max	.2743	.3281	.3658	.2286	.3841	.3077
Min	.1524	.0156	.1296	.1219	.0781	.1829
Avg	.1944	.1969	.2143	.1910	.2690	.2569

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

AMARAVATI (R) SUB-DN[298] BU 2984

Substation No/ Name :- 034050 / 33 KV SHIRALA SUB - STATION

Feeder No / Name : 201 / 11 KV SHIRALA FEEDER Sheddable Rural/Mix Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8954	.905	.9568	.8688	.7537	.8059
2	.9774	.8954	.8869	.9114	.8688	.7619	.8145
3		.8596	.8688	.9214	.8238	.7442	.8145
4		.7522	.8507	.9214	.8238	.7442	.8059
5		.7164	.8048	.8954	.7964	.631	.788
6		.6733		.8505	.7522	.5258	.6878
7		.6805	.7545	.8238	.724	.5258	.6805
8		.788	.8669	1.0631	.905	.4706	
9		.8596	1.0277	1.0166	.9774	.5014	.3403
10	.788	.8954	1.0288	1.1222	.8688	.5731	.9214
11	.788	.8745		1.0745	.6379	.543	.9816
12	.788	.9362	1.0517	1.2308	.631	.4908	.9313
13	.8596	.9945	1.0749	1.267	.4557	.4835	1.0029
14	.8954	.9774	.7362	1.2308	.631	.4607	1.1694
15		.9774	.8859	1.1946	.6661	.4784	1.0985
16		.9088	1.1218	1.3032	.7796	.5316	1.2403
17		.9259	1.0867	1.3394	1.0867	.7545	1.0277
18	.7442	.8916	.8859	.5792	1.0867	.5935	.7712
19	.788	.9724	.9465	.6516	1.134	.9496	
20	.9568		1.0867	.6516	.6661	1.0749	1.0867
21	.9922	1.1283	1.0631	.8688	.7011	1.0166	1.1218
22	.9313	1.0387	.9922	.9412	.7712	.9214	1.0867
23	.9214	.9412	.9214	.905	.7796	.8417	.9816
24	1.086	.8859	.9511	.9465	.8688	.7619	.8238
Max	1.086	1.1283	1.1218	1.3394	1.134	1.0749	1.2403
Min	.7442	.6733	.7362	.5792	.4557	.4607	.3403
Avg	.8859	.8899	.9454	.9861	.8044	.6722	.9083

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

AMRAVATI (R) SUB-DN[298] BU 2984

Substation No/ Name :- 034050 / 33 KV SHIRALA SUB - STATION

Feeder No / Name : 203 / 11 KV ROHANKHEDA FEEDER

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0745	1.1157	1.2269	.9412	.7628	.8402
2	.3982	1.0277	1.0974	1.2403	.9412	.7712	.8402
3		.9922	1.0679	1.2048	.905	.7362	.8402
4		.9816	1.0608	1.1568	.8954	.7362	.8316
5		.9568	1.0425	1.1443	.8596	.6733	.8316
6		.8859		1.134	.7522	.5959	.7282
7		1.0277	1.0749	1.1568	.6447	.5258	.6878
8		1.0985	1.3253	1.1443	.905	.543	
9		1.2178	.3658	1.3717	1.086	.5068	.8149
10	1.6118	1.2894	.3109	1.6118	1.0136	.543	.8063
11	1.4327	1.17	1.6827	1.3611	1.0517	.5068	.7712
12	1.5043	.3801	1.6827	1.3969	1.0749	.5083	.788
13	1.4327	.4298	1.6126	1.448	.6733	.5434	.8596
14	1.4327	1.1869	1.6476	1.576	.7975	.5068	.8505
15		.4525	1.5775	1.448	.7362		.9816
16		1.0802	1.382		.7011	.5373	.9922
17		1.3226	1.5238			.4031	.9114
18	1.3176	1.3565	1.5074			.703	.9568
19	1.1218	1.286	1.5257	.2534		.9036	1.0631
20	1.3112		1.4217	.9774	.7362	.9816	1.1919
21	1.2757	.5895	1.2971	.9774	.8505	.961	1.134
22	1.2757	1.3575	1.2971	.9774	.8063	.7468	1.0745
23	1.0985	1.2437	1.1568	.9671	.7712	.8589	.9922
24	1.2536	1.0517	1.1946	1.2269	.9412	.7712	.8215
Max	1.6118	1.3575	1.6827	1.6118	1.086	.9816	1.1919
Min	.3982	.3801	.3109	.2534	.6447	.4031	.6878
Avg	1.2667	1.0200	1.2596	1.1905	.8611	.6663	.8961

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

AMRAVATI (R) SUB-DN[298] BU 2984

Substation No/ Name :- 034050 / 33 KV SHIRALA SUB - STATION

Feeder No / Name : 204 / DEVARA DEVARI AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.7449
2							.7449
3							.7449
4							.7449
5							.7125
6							.7449
7							.7773
9			1.3603				
10		1.3763	1.7166				
11	.8962	1.7166	1.6194				
12	.4481	1.6518	1.6004				
13	.4481	1.7924			.8745		
14	.6478	.7125			.9717		
15		.8097		.0972	.9922		
16		1.0688	1.7814				
17	1.1203	.9393	1.2308				
18	1.1385	1.166	1.3279				
19	1.0753		1.3123				
20	.032						
21	.032						
22	.032						
23						.6478	
24							.7449
Max	1.1385	1.7924	1.7814	.0972	.9922	.6478	.7773
Min	.032	.7125	1.2308	.0972	.8745	.6478	.7125
Avg	.5870	1.2482	1.4936	.0972	.9461	.6478	.7449



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

AMRAVATI (R) SUB-DN[298] BU 2984

Substation No/ Name :- 034057 / 33 KV NANDGAONPETH S/S.

Feeder No / Name : 202 / 11 KV NANDGAONPETH MIDC SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0019	.0019	.0019	.0019	.0019	.0019
2	.0019	.0019	.0019	.0019	.0019	.0019	.0019
3		.0019	.0019	.0019	.0019	.0019	.0019
4		.0019	.0019	.0019	.0019	.0019	.0019
5		.0019	.0019	.0019	.0019	.0019	.0019
6		.0019	.0019	.0019	.0019	.0019	.0019
7		.0019	.0019	.0019	.0019	.0019	.0019
8		.0019	.0019	.0019	.0019	.0019	.0019
9	.0264	.0019	.0019	.0019	.0019		.0019
10	.0283	.0019	.0019	.0019	.0019		.0019
11	.0299		.0019	.0019	.0019	.0019	.0019
12	.0373	.0019	.0019		.0019	.0019	.0019
13	.0019	.0019	.0019	.0019	.0019	.0019	.0019
14	.0019	.0019	.0019	.0019	.0019	.0019	.0019
15	.0019	.0019	.0019	.0019	.0019	.0019	.0019
16	.0019	.0019	.0019	.0019	.0019	.0019	
17	.0019	.0019	.0019		.0038	.0019	.0019
18	.0019	.0019	.0019	.0019	.0038	.0019	.0019
19	.0019	.0019	.0019	.0019	.0019	.0019	.0019
20	.0019	.0019	.0019	.0019	.0019	.0019	.0019
21	.0019	.0019	.0019	.0019	.0019	.0019	.0019
22	.0019	.0019	.0019	.0019	.0019	.0019	.0019
23	.0038	.0019	.0038	.0019	.0019	.0019	.0019
24	.0019	.0019	.0019	.0019	.0019	.0019	.0019
Max	.0373	.0019	.0038	.0019	.0038	.0019	.0019
Min	.0019	.0019	.0019	.0019	.0019	.0019	.0019
Avg	.0087	.0019	.0020	.0019	.0021	.0019	.0019

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

AMRAVATI (R) SUB-DN[298] BU 2984

Substation No/ Name :- 034057 / 33 KV NANDGAONPETH S/S.

Feeder No / Name : 203 / 11 kv Shevati Gaothan Sheddable Rural/Mix Feeder  
feeder Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0355	.0381	.0392	.034	.0302	.0229
2		.0355	.0381	.0392	.034	.0283	.0229
3		.0355	.0381	.0373	.034	.0283	.0229
4		.0355	.0362	.036	.034	.0283	.0229
5		.0355	.0343	.0373	.0321	.0283	.0229
6		.0355	.034	.0373	.034	.0283	.0226
7		.0355	.0321	.0355	.0336	.0283	.0226
8		.0317	.0336	.0317	.0321	.0283	.0226
9		.0355	.0317	.0299	.0283		.0226
10		.0373	.0317	.0355	.0283		.0226
11		.0377	.0302	.0299	.0302	.0264	.0224
12		.0355	.0317	.0317	.028	.0243	.0224
13	.0317	.0396	.0336	.0333	.0245	.0224	.0317
14	.0411	.0358	.028	.0333	.0283	.0224	.028
15	.0392	.0336	.0317	.0333	.0283	.0243	.028
16	.0411	.0317	.0317	.0226	.0299	.028	.028
17	.0411	.0321	.028		.0261	.0224	.0299
18	.0299	.0355	.0299	.0224	.0261	.0283	.0299
19	.028	.0299	.0333	.0321	.0283	.0336	.0336
20	.0373	.0355	.0355	.0355	.034	.0358	.0355
21	.0392	.0373	.0355	.0355	.0321	.034	.0373
22	.0392	.0392	.0373	.0373	.0336	.0224	.0336
23	.0373	.0392	.0373	.0355	.0317	.0224	.0355
24	.0343	.0373	.0355	.0373	.034	.0321	.0229
Max	.0411	.0396	.0381	.0392	.034	.0358	.0373
Min	.028	.0299	.028	.0224	.0245	.0224	.0224
Avg	.0366	.0355	.0336	.0339	.0308	.0276	.0269

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

AMRAVATI (R) SUB-DN[298] BU 2984

Substation No/ Name :- 034057 / 33 KV NANDGAONPETH S/S.

Feeder No / Name : 206 / 11 KV KATHORA AG FEEDER Ag dominated/Pure Ag  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0031	.0015	.0029
2					.0031	.0015	.0029
3					.0031	.0015	.0029
4					.0031	.0015	.0029
5					.0031	.0015	.0029
6					.0047	.0015	.0046
7					.0046	.0015	.0047
8					.0047	.003	.0062
9					.0047		.0031
10	.0141	.0158	.016	.0192			
11	.0154	.0197	.0215	.0201			
12	.0166	.036	.0158	.0203			
13	.0188	.0332	.017	.0203			
14	.0185	.0162	.0109	.0172			
15	.0156	.0113	.016	.0156			
16	.0156	.0113	.016	.0156			
17	.016	.0131	.017	.0094			
24					.0031	.0015	.0029
Max	.0188	.036	.0215	.0203	.0047	.003	.0062
Min	.0141	.0113	.0109	.0094	.0031	.0015	.0029
Avg	.0163	.0196	.0163	.0172	.0037	.0017	.0036

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

AMRAVATI (R) SUB-DN[298] BU 2984

Substation No/ Name :- 034080 / 33 KV TEXTILE ZONE 1

NANDGAONP

Feeder No / Name : 201 / 11KV SHYAM INDOFAB

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7842	.7842	.0173	1.1203	.9335	.9054	.0223
2		.7468	.0173	1.0829	.7842	.7922	.0223
3	.7468	.6348	.0173	1.0829	.6722	.7545	.0086
4	.7468	.5601	.0175	1.0456	.6036	.6413	.0087
5	.7095	.6161	.0156	1.0456	.6348	.5658	.0257
6	.6722	.6722	.0156	1.0082	.6161	.5658	.0223
7	.6348	.7095	.0156	1.0829	.679	.6036	.0223
8	.5975	.7468	.0206	1.1203	.7167	.6348	.0223
9	.5601	.7655	.0225	.9054	.8029	.6722	.024
10	.7095	.8029	.026	.9709	.7468		.0243
11	.7545	.0208	1.1203	.9335	1.0562	.024	.0257
12	.7602	.0208	1.0829	.8589		.0257	.024
13	.7468	.024	1.0829	.8215		.0257	.0257
14	.8215	.0206	1.0456	.8962		.0274	.0274
15	.7842	.0223	.9709	.9335		.0274	.0291
16	.8589	.0243		.8589		.0274	.0295
17	.7468	.0243	1.0082	.8962		.0291	.0274
18	.7842	.0243	1.0456	.8402	.3361	.0274	.0257
19	.7468	.0243	1.0456	.9335	.3018	.0291	.024
20	.811	.026	1.1576	.8589	.2263	.0295	.024
21	.8589	.026	1.1576	1.0082	.2263	.0295	.0257
22	.7842	.0243	1.1763	.9335	.2075	.0274	.0257
23	.8775	.0208	1.1203	1.0082	.6413	.0274	.0257
24	.7842	.7545	.0208	1.1203	1.0269	.7545	.0257
Max	.8775	.8029	1.1763	1.1203	1.0562	.9054	.0295
Min	.5601	.0206	.0156	.8215	.2075	.024	.0086
Avg	.7514	.3373	.5748	.9736	.6229	.3151	.0237

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

AMRAVATI (R) SUB-DN[298] BU 2984

Substation No/ Name :- 034080 / 33 KV TEXTILE ZONE 1

NANDGAONP

Feeder No / Name : 202 / 11 KV VHM FEEDER

SHEDDABLE FEEDER HAVING WEEKLY

Feeder KV- 11 / OUTGOING

STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3734	.0052	.4854	.4108	.2075	.0154
2	.3361	.3734	.0069	.4854	.4108	.1867	.0156
3	.3361	.3734	.0069	.5228	.3734	.1867	.0154
4	.2987	.3361	.0052	.5228	.3361	.1886	.0154
5	.2987	.3734	.0052	.4481	.2987	.2263	.0154
6	.2987	.3921	.0052	.4481	.2987	.2427	.0137
7	.3734	.2241	.0052	.5228	.3361	.3395	.0137
8	.4481	.3361	.0104	.5975	.2241	.2641	.0137
9	.7095	.4854	.0121	.5228	.1307	.2987	.0154
10	.7468	.4481	.0139	.6348	.132		.0154
11	.7468	.012	.5601	.5975	.1494	.0137	.0156
12	.6722	.0121	.5601	.6722		.014	.0154
13	.5975	.0137	.5975	.7468		.0154	.0154
14	.6722	.0139	.6036	.7655		.0154	.0156
15	.6348	.0139	.5601	.8215		.0154	.0156
16	.7095	.0154	.5975	.7468		.0154	.0193
17	.6722	.0156	.5601	.6348		.0161	.0173
18	.7095	.0121	.5975	.5601	.132	.0137	.0154
19	.679	.012	.5975	.5228	.132	.0139	.0137
20	.5601	.0088	.5601	.5601	.1509	.0137	.012
21	.4904	.0088	.5601	.5228	.1509	.0139	.012
22	.415	.0087	.5228	.4854	.1509	.0137	.012
23	.3921	.0086	.4854	.4668	.1886	.0139	.0103
24	.3734	.4108	.0087	.5228	.4481	.2075	.0137
Max	.7468	.4854	.6036	.8215	.4481	.3395	.0193
Min	.2987	.0086	.0052	.4481	.1307	.0137	.0103
Avg	.5227	.1784	.3103	.5757	.2475	.1103	.0147

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

AMRAVATI (R) SUB-DN[298] BU 2984

Substation No/ Name :- 034080 / 33 KV TEXTILE ZONE 1

NANDGAONP

Feeder No / Name : 203 / 11 KV WATER WORKS MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	23-JUN-17	24-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0017		.0017
2		.0017		.0017
3		.0017		.0017
4		.0017		.0017
5		.0017		.0017
6		.0017		.0017
7		.0017		.0017
8		.0017		.0017
9		.0017		.0017
10		.0017		.0017
11	.0017		.0017	.0017
12	.0017		.0017	.0017
13	.0017		.0017	.0017
14	.0017		.0017	.0017
15	.0017		.0017	.0017
16	.0017		.0017	.0017
17	.0017		.0017	.0017
18	.0017		.0017	.0017
19	.0017		.0017	.0017
20	.0017		.0017	.0017
21	.0017		.0017	.0017
22	.0017		.0017	.0017
23	.0017		.0017	.0017
24		.0017		.0017
Max	.0017	.0017	.0017	.0017
Min	.0017	.0017	.0017	.0017
Avg	.0017	.0017	.0017	.0017

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

AMRAVATI (R) SUB-DN[298] BU 2984

Substation No/ Name :- 034080 / 33 KV TEXTILE ZONE 1

NANDGAONP

Feeder No / Name : 401 / 33 KV Golden Fibres LLP

HV Express Feeder

(Siyar Feeder KV- 33 / OUTGOING)

DATE	23-JUN-17	24-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.021		.0257
2		.026		.0257
3		.0263		.0257
4		.026		.026
5		.026		.0257
6		.026		.0257
7		.026		.0257
8		.026		.0257
9		.026		.0257
10		.0208		.0257
11	.0257		.0257	.0257
12	.026		.0257	.0257
13	.0257		.0257	.026
14	.0257		.0257	.0257
15	.026		.026	.0257
16	.0257		.0257	.0257
17	.026		.0257	.026
18	.0263		.0257	.026
19	.021		.0257	.0257
20	.0208		.0257	.026
21	.0208		.0257	.0257
22	.026		.026	.0257
23	.026		.0257	.026
24		.026		.026
Max	.0263	.0263	.026	.026
Min	.0208	.0208	.0257	.0257
Avg	.0247	.0251	.0257	.0258

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

AMRAVATI (R) SUB-DN[298] BU 2984

Substation No/ Name :- 034087 / SURYALAXMI MIDC

Feeder No / Name : 401 / SURYALAXMI EXPRESS

HV Express Feeder

Feeder KV- 33 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4086	2.4646	2.4646	2.3525	2.4086	2.2405	2.2405
2	2.2405	2.4646	2.4646	2.2405	2.4086	2.2405	2.2405
3	2.2405	2.4646	2.4646	2.2405	2.4086	2.2405	2.2405
4	2.1845	2.4646	2.4646	2.2405	2.4086	2.2405	2.2405
5	2.1845	2.4646	2.4086	2.2965	2.4086	2.3525	2.2405
6	2.2965	2.4646	2.4086	2.3525	2.4086	2.3525	2.4646
7	2.2965	2.4646	2.4646	2.2965	2.5206	2.4646	2.4646
8	2.2965	2.4646	2.4646	2.3525	2.5206	2.5766	2.4646
9	2.2965	2.4646	2.4646	2.2965	2.5206	2.5766	2.4646
10	2.4086	2.5766	2.4646	2.1845	2.4646	2.3525	2.5766
11	2.4646	2.3525	2.4086	2.2405	2.3525	2.2965	2.5766
12	2.4646	2.3525	2.4086	2.2405	2.4646	2.2965	2.5206
13		2.3525	2.4646	2.2405	2.3525	2.2965	2.4086
14		2.5206	2.3525	2.4646	2.3525	2.2965	2.4086
15		2.5206	2.3525	2.4646	2.3525	2.2965	2.4646
16		2.5206	2.3525	2.3525	2.2405	2.2965	2.4646
17		2.5206	2.4086	2.2405	2.2405	2.2965	2.4646
18	2.4646	2.2405	2.4086	2.2405	2.2405	1.5684	2.4646
19	2.4646	1.7924	2.2965	2.1285	2.2405	1.5684	2.4646
20	2.4646	2.2405	2.2965	1.9044	2.2405	1.5684	2.4646
21	2.4646	2.2405	2.2405	1.6804	2.2405	1.5684	2.4646
22	2.4646	2.2405	2.2405	2.3525	2.2405	2.4086	2.4646
23	2.4646	2.2405	2.3525	2.3525	2.2405	2.4086	2.5766
24	2.4086	2.4646	2.4646	2.3525	2.4086	2.2405	2.2405
Max	2.4646	2.5766	2.4646	2.4646	2.5206	2.5766	2.5766
Min	2.1845	1.7924	2.2405	1.6804	2.2405	1.5684	2.2405
Avg	2.3673	2.3899	2.3992	2.2545	2.3619	2.2102	2.4202



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

BADNERA SUB-DN.[303] BU 1678

Substation No/ Name :- 034027 / 33KV BADNERA RURAL

Feeder No / Name : 201 / 11 kv HT

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3086	.3258	.3086	.2915		.3801
2		.2915	.3258	.3258	.2915		.3841
3	.2743	.2915	.3258	.3258	.2915		.3658
4	.2915	.2915	.3258	.3258	.2915		.3658
5	.3258	.2915	.3258	.3258	.2915		.3658
6	.3086	.2743	.3258	.3258	.3258		.3658
7	.2915	.2915	.3258	.3258	.2915		.3801
8	.2915	.2915	.3429	.3601	.2915		.3801
9	.2896	.3258	.362	.3475	.3174	.3429	.4287
10	.3982	.362	.4525	.4024	.3361		.463
11	.4344		.4835	.4344	.3174	.4115	.5316
12	.3982	.4344	.4525	.4835	.3361	.5487	.583
13	.3982	.3982	.4525	.4835	.3326	.4801	.5144
14	.4344	.3856	.4115	.4706	.2743	.463	.4458
15	.4344	.4382	.4161	.4525	.2883	.5144	.5316
16		.3681	.4458	.4706	.2915	.5144	.5493
17		.4031	.4458	.4115	.2915	.4801	.5014
18	.3772	.5373	.3772	.3429	.2915	.5487	.4344
19	.3429	.3582	.3429	.3086	.2915	.5144	.4344
20	.3086	.3761	.4115	.3086	.2713	.4801	.3982
21	.3086	.3429	.3429	.3086	.2713		.3841
22	.3258	.3258	.3429	.2915			.3841
23	.3258	.3258	.3258	.2915	.3258	.3801	.3841
24	.3086	.3258	.3258	.3086	.2915		.3841
Max	.4344	.5373	.4835	.4835	.3361	.5487	.583
Min	.2743	.2743	.3258	.2915	.2713	.3429	.3658
Avg	.3417	.3495	.3756	.3642	.2998	.4732	.4308

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

BADNERA SUB-DN.[303] BU 1678

Substation No/ Name :- 034027 / 33KV BADNERA RURAL

Feeder No / Name : 202 / 11 kv anjangaon bari

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143		.0953	.0762	.1075		.0876
2	.1334		.0953	.0762	.1029		.0857
3	.1334		.0953	.0762	.1029		.0857
4	.1334		.0953	.0762	.1029		.0857
5	.1334		.0953	.0762	.12		.1029
6	.1143		.0762	.0572	.1457		.1029
7	.1143		.0762	.0762	.1781		.1341
8	.0953		.0762	.0762	.1781		.1509
9	.0943		.0754	.0566	.2012	.1448	.1543
10	.2515			.4534	.0566		.0381
11	.285		.3932	.5182	.0566	.0543	.0377
12	.2683	.0838	.3605	.426	.0566	.0543	.0381
13	.2347	.1638	.3018	.3932	.0754	.0358	.0381
14	.12	.2401	.3506	.3277	.0526	.0351	.0381
15	.12	.2058	.3429	.285	.0543	.0343	.0566
16		.2328	.362	.3605	.0724	.0351	.0566
17		.3224	.3982	.3467	.0701	.0362	.0566
18	.0905	.0895	.0686	.0724	.0724	.0686	.0566
19	.0701	.0895	.0693	.0905		.0724	.0754
20		.0914	.0701	.0905		.0724	.0754
21		.1143	.0701	.0905			.0943
22		.0953	.0762	.0953			.0943
23		.0953	.0762	.0953		.0754	.0943
24	.0953		.0953	.0762	.1029		.0876
Max	.285	.3224	.3982	.5182	.2012	.1448	.1543
Min	.0701	.0838	.0686	.0566	.0526	.0343	.0377
Avg	.1445	.152	.1659	.1820	.1005	.0599	.0803

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

BADNERA SUB-DN.[303] BU 1678

Substation No/ Name :- 034027 / 33KV BADNERA RURAL

Feeder No / Name : 203 / 11 kv loni

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1619	.1067		.1619			.0754
2	.1029	.1134		.1619			.0754
3	.0686	.0648		.1619			.0754
4	.081	.081		.1457			.0754
5	.0914	.1134		.1372			.0566
6	.1619	.1457		.3353			.0566
7	.2294	.3077		.1457		.0572	.0566
8	.2591	.4049		.583		.0572	.0566
9	.3018	.2743	.2012	.4858			.0572
10		.0754	.2294	.0377			.1619
11		.1715		.0377	.2515	.1753	.2949
12		.0566		.0754	.2591	.181	.3077
13		.0566		.0754	.2458	.1715	.2591
14			.3506	.0566	.2401	.1715	.3401
15			.0686	.0566	.181	.2058	.2785
16			.0716	.0377	.1715	.1753	.2683
17			.0724		.1715	.2172	.2515
18			.0724		.0724	.0686	.0377
19			.0724		.0724	.0724	.0566
20			.0701		.0905	.0724	.0754
21		.0572	.0701		.0905		.0754
22			.0762				.0754
23			.0762		.0762	.0754	.0754
24	.1829	.1219		.1619			.0754
Max	.3018	.4049	.3506	.583	.2591	.2172	.3401
Min	.0686	.0566	.0686	.0377	.0724	.0572	.0377
Avg	.1641	.1434	.1193	.1681	.1602	.1308	.1341

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

BADNERA SUB-DN.[303] BU 1678

Substation No/ Name :- 034027 / 33KV BADNERA RURAL

Feeder No / Name : 204 / 11 kv Nandgaon kh

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1905			
2				.2096			
3				.2096			
4				.2096			
5				.2096			
6				.1905			
7				.1715			.0514
8				.2096			.0857
9				.2241			.1781
10		.3353	.5243	.9175			.0762
11	.1372		.6554	1.2452	.1372	.0724	.0572
12		.4024	.8192	1.1142	.1715	.0724	.0762
13	.1677	.4096	.7865	1.0059	.1132	.1629	.0762
14	.3688	.4115	.7545	.9724	.1448	.2229	.0762
15	.5533		.7545	.9389	.1578	.1029	.0377
16		.1433	.905	.9831	.1629	.0905	.0377
17	.5548	.4733	.9114	.9259		.0724	
18			.1791	.1715		.1448	.0377
19			.1791			.1629	.0377
20			.1753			.1448	.0377
21			.1402				.0377
22			.2096				.0566
23			.2096				.0566
24				.2096			
Max	.5548	.4733	.9114	1.2452	.1715	.2229	.1781
Min	.1372	.1433	.1402	.1715	.1132	.0724	.0377
Avg	.3564	.3626	.5146	.5426	.1479	.1249	.0635

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

BADNERA SUB-DN.[303] BU 1678

Substation No/ Name :- 034027 / 33KV BADNERA RURAL

Feeder No / Name : 205 / 11KV SAONER

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.7095	.7282	.7468	.7468	.6283	.6283
2		.7095	.7282	.7468	.7468	.6348	.6283
3	.2241	.7095	.7095	.7095	.7468	.6348	.6283
4	.1886	.7095	.7095	.7095	.7282	.6161	.5914
5	.2075	.6348	.7095	.6908	.7095	.5788	.5544
6	.1698	.5415	.5601	.5415	.5601	.4854	.5175
7	.1307	.3982	.4525	.4572	.4294	.4108	.1307
8	.168	.3982	.4525	.4163	.3881	.3361	.3174
9	.168	.4294	.4854	.4854	.3734		.3801
10	.1132	.4481	.4854	.4854	.3921		.3403
11	.1509	.4287	.4854	.5228	.3921	.3258	.3582
12		.5175	.5175	.5729	.4294	.362	.394
13	.5914	.5914	.6099	.5729	.4294	.3429	.3326
14	.6283	.5014	.6173	.5914	.4207	.3429	.3511
15	.695		.6516	.5914	.4115	.3429	.3734
16	.6661	.5014	.6089	.5914	.3982	.362	.4294
17	.5959	.4835	.5144	.4207	.3772	.362	.4108
18	.5487	.4557	.5792	.4801	.4344	.5144	.3174
19	.3658	.5258	.5373	.5144	.5083	.5487	.5359
20	.583	.6836	.631	.583	.5068	.5144	.6283
21	.6805	.7392	.5959	.6878	.4706		.695
22	.7655	.7762	.7733	.7842	.6413		.7316
23	.7655	.7655	.7733	.7842	.6602	.6283	.7316
24	.7655	.7095	.7392	.7468	.7468	.6283	.6283
Max	.7655	.7762	.7733	.7842	.7468	.6348	.7316
Min	.1132	.3982	.4525	.4163	.3734	.3258	.1307
Avg	.4509	.5812	.6106	.6014	.5270	.4800	.4848

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

BADNERA SUB-DN.[303] BU 1678

Substation No/ Name :- 034027 / 33KV BADNERA RURAL

Feeder No / Name : 206 / 11KV MORGAON

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3174	.3361	.2987	.3547	.2987	.2987	.2402
2	.2987	.3174	.2987	.3547	.3361	.2801	.2402
3	.3239	.2987	.2987	.3547	.3361		.2402
4	.3174	.2987	.2801	.3547	.3361		.2402
5	.2801	.2987	.2801	.3547	.3361		.2402
6	.2402	.2402	.2218	.2772	.2614		.2241
7	.1848	.2149	.1753	.2715	.1646		.1867
8	.1848	.2507	.1578	.2629	.1629		.1867
9	.2054	.2427	.1867	.2614	.168		.1753
10	.2054	.2054	.1867	.2427	.1867		.1928
11	.2054		.2427	.2427	.1867	.1402	.1772
12	.2054	.2054	.2241	.2957	.168		.1791
13	.2587	.2402	.2241	.2957	.168		.1433
14	.2772	.3109	.2058	.3142	.1578	.1543	.1848
15	.2427		.2058	.3326	.1543	.1543	.1867
16	.2172	.2195	.2103	.2957	.1372		.2054
17	.1734	.2561	.2172	.4161	.1715	.1052	.1494
18	.181	.2149	.2507	.3429	.1991	.2804	.2427
19	.2534	.3045	.2629	.3429	.2353	.2804	.2402
20	.3506	.3224	.3506	.3258	.2172	.2401	.2772
21	.3582	.4108	.3506	.2896	.2896	.2772	.3142
22	.3547	.3361	.3658	.3547	.3174	.2772	.3142
23	.3174	.3174	.3696	.3361	.3361	.2587	.2957
24	.3361	.3361	.2987	.3547	.2987	.2987	.2402
Max	.3582	.4108	.3696	.4161	.3361	.2987	.3142
Min	.1734	.2054	.1578	.2427	.1372	.1052	.1433
Avg	.2621	.2808	.2568	.3179	.2343	.2343	.2215

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

BADNERA SUB-DN.[303] BU 1678

Substation No/ Name :- 034027 / 33KV BADNERA RURAL

Feeder No / Name : 404 / 33KV BHASKAR

HV Express Feeder

Feeder KV- 33 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.0914	.0857	.0857	.0457	.0686	.0514
2		.1029	.0914	.0857	.0572	.0686	.0514
3		.08	.0857	.0857	.0572	.0629	.0457
4		.0857	.0914	.0857	.0514	.0629	.04
5		.0743	.0857	.0857	.0514	.0572	.0343
6		.0572	.08	.0743	.0286	.04	.0343
7		.0686	.0743	.0743	.0229	.0229	.0343
8		.0686	.08	.0743	.0343	.0572	.0514
9		.0572	.08	.08	.0457		.04
10		.0972	.08	.08	.0343		.0686
11			.0743	.0629	.04	.0743	.0629
12		.1715	.0743	.0686	.0343	.0686	.0857
13		.08	.0629	.0743	.0457	.0686	.0514
14		.0645	.0743	.08	.0257	.0743	.04
15		.0645	.08	.0857	.0686	.08	.04
16		.0537	.0629	.1029	.0572	.0857	.04
17		.0698	.0686	.0914	.0686	.0857	.08
18		.0645	.0857	.0514	.08	.08	.0686
19		.0752	.08	.0572	.0686	.08	.0857
20	.0914	.0913	.0857	.0572	.0686	.0857	.08
21	.0686	.0914	.0857	.0457	.0686	.0629	.0857
22	.084	.0914	.0857	.0514	.0629	.0629	.0857
23	.1086	.0914	.0857	.0514	.0686	.0572	.0629
24	.1886	.08	.0857	.0857	.0514		.0514
Max	.1886	.1715	.0914	.1029	.08	.0857	.0857
Min	.0686	.0537	.0629	.0457	.0229	.0229	.0343
Avg	.1216	.0814	.0802	.0741	.0516	.0670	.0571

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

BADNERA SUB-DN.[303] BU 1678

Substation No/ Name :- 034027 / 33KV BADNERA RURAL

Feeder No / Name : 405 / 33 Kv LONI TAKALI

EHV Non-Express Feeder

Feeder KV- 33 / INCOMING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3937	1.668	1.6916	1.7741	1.3331	1.2659	1.1303
2		1.0059	1.7032	1.763	1.3219	1.2547	1.1193
3		1.2883	1.6919	1.6854	1.2995	1.2435	1.0974
4		1.602	1.6632	1.658	1.2883	1.2323	1.0974
5		1.5628	1.6862	1.6356	1.2827	1.2231	1.0754
6		1.5034	1.5123	1.5967	1.2562	1.1656	1.0425
7		1.3466	1.6244	1.5413	1.2117	1.0185	.9438
8		1.3241	1.4975	1.5583	1.1088	.9602	.8121
9		1.2923	1.4443	1.4552	1.0535		.8288
10		1.7407	2.1502	2.5309	1.0535		.8459
11			1.9959	2.7778	1.2291	.7613	.8459
12		2.0524	2.356	2.6132	1.3357	.7922	.9717
13		1.9667	2.5	2.6187	1.2894	.5761	.6401
14		1.965	1.1523	2.5556	.7099	.4938	.6287
15		1.7284	1.0288	1.7945	.6415	.9156	.9438
16		1.1358	2.0679	2.356	.7099	.5469	.9328
17		1.4712	2.1914	2.1139	.4627	.3576	.8094
18		.8939	1.0622	.7819	.9671	.8128	.6431
19	.9241	1.1463	1.0622	.7716	1.0288	1.07	.856
20	1.2725	1.3889	1.286	1.0597	1.2305	1.2963	1.2923
21	1.2449	1.4399	1.2449	1.1626	.6516	1.2597	1.4335
22	1.4376	1.5348	1.4675	1.2435	1.3331	1.2489	1.4552
23	1.4339	1.4787	1.4787	1.2099	1.2995	1.1837	1.39
24	1.4304	1.69	1.7476	1.8074	1.3555		1.1413
Max	1.4376	2.0524	2.5	2.7778	1.3555	1.2963	1.4552
Min	.9241	.8939	1.0288	.7716	.4627	.3576	.6287
Avg	1.3053	1.4881	1.6378	1.7527	1.1022	.9847	.9990



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

BADNERA SUB-DN.[303] BU 1678

Substation No/ Name :- 034060 / 33 KV ANJANGAON BARI S/S

Feeder No / Name : 202 / 11 KV New A'Bari (G)

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8605	.8642	.7458	.8282	.8642	.8596	.7118
2	.8462	.8642	.7458	.8282	.8642	.8605	.7118
3	.8102	.8642	.7103	.793	.8642	.8247	.7118
4	.8102	.8102	.6057	.7209	.7202	.8247	.6031
5	.7209	.6842	.5327	.6488	.6301	.8059	.5138
6	.5941	.5761	.4972	.5948	.5761	.644	.5149
7	.4321	.4141	.4262	.4506	.4321	.5188	.4262
8	.3593	.4321	.7458	.3965	.4141	.5014	.4084
9	.4851	.4681	.4252	.3965	.4681		.4262
10	.5401	.5761	.7103	.5407	.4861		.3574
11	.6842	.5706	.6128	.8102	.4477	.3729	.3248
12	.7538	.5682	.5767	.8102	.4841	.3388	.3608
13	.7538	.7458	.6128	.8642	.5384		.3608
14	.7897	.7693	.7209	.9002	.5731	.4805	.4511
15	.7922	.657	.7209	.9002	.4666		.433
16	.6121	.5719	.7209	.6662	.4141	.4449	.433
17	.7382	.5694	.6669	.6121	.4123	.354	.3969
18	.4501	.4252	.4686	.6121	.5558	.3574	.433
19	.682	.4961	.6849	.6121	.7171	.6037	.5948
20	.7742	.586	.757	.7562	.8417	.7103	.6842
21	.8973	.657	.8642	.8102	.8775	.7103	.757
22	.8822	.7103	.8642	.8642	.8794	.7087	.7922
23	.8822	.8042	.8651	.8822	.8973	.6747	.8102
24	.8785	.8642	.805	.8642	.8822	.8973	.7103
Max	.8973	.8642	.8651	.9002	.8973	.8973	.8102
Min	.3593	.4141	.4252	.3965	.4123	.3388	.3248
Avg	.7096	.6479	.6702	.7151	.6378	.6247	.5386

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

BADNERA SUB-DN.[303] BU 1678

Substation No/ Name :- 034060 / 33 KV ANJANGAON BARI S/S

Feeder No / Name : 203 / 11 KV Arhad (G)

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1457	.168	.1578	.1433	.168		.1227
2	.146	.168	.1402	.1433	.1646		.12
3	.1275	.168	.1402	.1254	.1646		.124
4	.1278	.1463	.1417	.1254	.1463		.124
5	.1275	.128	.1227	.1075	.128		.124
6	.1094	.0914	.1063	.1075	.08		.0857
7	.0903	.0732	.0709	.0895	.0914		.0701
8	.0908	.0876	.1063	.0895	.0914		.0709
9	.0729	.0857	.1052	.0895	.0914		.0876
10	.0911	.0876	.0876		.1097		.0709
11	.0876	.1052	.0716	.0351	.0909		.0716
12	.0876	.0897	.0716	.0351	.0726		.0895
13	.1052	.1	.0716	.1052			.0895
14	.1227	.1227	.1075	.1227			.0895
15	.1267	.1227	.0895	.1227			.0895
16	.1227	.1214	.1254	.0876			.0895
17	.1086	.0701	.1075			.0701	.0895
18	.0905	.0693	.0716			.0686	.0716
19	.112	.104	.1063			.124	.1075
20	.1307	.1578	.1417	.168		.1433	.1254
21	.168	.1578	.1595	.1867		.1372	.1433
22	.168	.1776	.1595	.1829		.1372	.1612
23	.168	.1598	.1595	.1867		.12	.1612
24	.1997	.168	.1595	.1417	.1867		.124
Max	.1997	.1776	.1595	.1867	.1867	.1433	.1612
Min	.0729	.0693	.0709	.0351	.0726	.0686	.0701
Avg	.1220	.1221	.1159	.1198	.1220	.1143	.1043

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

BADNERA SUB-DN.[303] BU 1678

Substation No/ Name :- 034060 / 33 KV ANJANGAON BARI S/S

Feeder No / Name : 204 / 11 KV SATARGAON (Ag) Ag dominated/Pure Ag  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.0297
2						.1
3						.0596
4						.0892
5						.104
6						.0892
7						.1047
8					.0732	.0743
9					.6202	.4012
10			.6241	.8278	.6438	.431
11	.8397		.7252	.8903	.515	
12	.7627		.7705	.8818		
13	.7142	.5982	.7856	.8701		
14	.6559	.5982	.6497	.6438		
15	.6413	.535	.6194	.5706		
16	.6533		.6043	.6877		
17	.7901		.7101			
18		.1189				
19		.4012				
24						.0295
Max	.8397	.5982	.7856	.8903	.6438	.431
Min	.6413	.1189	.6043	.5706	.0732	.0295
Avg	.7225	.4503	.6861	.7674	.4631	.1375

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

BADNERA SUB-DN.[303] BU 1678

Substation No/ Name :- 034060 / 33 KV ANJANGAON BARI S/S

Feeder No / Name : 401 / 33 Kv MALKHED FEEDER

EHV Non-Express Feeder

Feeder KV- 33 / INCOMING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9392	2.1308	1.2922	2.1216	1.2785	1.336	1.2922
2	2.6749	2.1308	1.7339	2.1216	1.2785	1.2812	1.2881
3	2.7226	2.1308	1.6084	2.1239	1.1187	1.2798	1.2894
4	2.5597	2.0242	1.5123	1.9115	1.1187	1.2291	1.1343
5	2.3997	1.9177	1.2908	1.8053	1.0654	1.2291	1.1259
6	1.0154	1.8644	1.2881	1.8053	1.0121	1.1757	1.0208
7	1.4979	1.971	1.4537	1.9115	.799	1.0154	.9114
8	1.6049	2.0242	1.5548	2.1239	.9056	1.0121	.9588
9	1.7654	2.2373	1.4383	2.2301	.6925		.9671
10	1.0165	1.9177	1.2213	1.9115	1.5981		1.6655
11	1.0154	1.9921	1.4867	2.184	1.5011	1.2357	1.6443
12	1.0121	2.1445	1.8584	.7682	1.5514	1.1795	1.8564
13	1.0654	1.9921	2.1239	1.9456	1.3403		1.8564
14	.4794	1.1379	2.0708	2.0242	.963	1.4537	2.4929
15	2.1308	1.0745	2.0177	1.5981	.9619	1.5581	2.546
16	2.3439	.9681	1.9115	1.1187	.4815	1.5597	2.4929
17	2.2373	.8615	2.0708	.8523	1.1757	1.5075	2.4399
18	2.3439	.8615	1.2213		.7482	1.3969	2.0134
19	2.1308	1.0654	1.9625	.586	.8016	1.4506	1.9604
20	1.8644	1.2423	1.9115	.6392	1.4444	1.5614	2.1193
21	1.9177	1.2383	1.9115	1.1719	1.4963	1.5548	2.1193
22	1.9177	1.346	1.8584	1.2252	1.4444	1.1795	2.2783
23	2.0242	1.2922	1.8034	1.2785	1.5995	1.4506	2.1723
24	3.1996	2.1308	1.2881	2.2277	1.4383	1.4979	1.4043
Max	3.1996	2.2373	2.1239	2.2301	1.5995	1.5614	2.546
Min	.4794	.8615	1.2213	.586	.4815	1.0121	.9114
Avg	1.9116	1.6540	1.6621	1.6385	1.1589	1.3402	1.7104

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

BADNERA SUB-DN.[303] BU 1678

Substation No/ Name :- 034061 / 33 KV LONI S/STN

Feeder No / Name : 201 / 11 KV WATPUR GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6548	.6174	.6174	.6548	.6174	.5987	.5613
2	.6548	.6174	.6174	.6548	.6174	.5987	.5613
3	.6548	.6548	.5987	.6548	.6174	.5987	.5613
4	.6548	.6548	.5613	.6548	.6174	.5987	.5613
5	.5613	.6548	.5613	.5613	.6174	.5613	.5239
6	.449	.5613	.5239	.4677	.5613	.5051	.5051
7	.3555	.4303	.4677	.4303	.4303	.449	.449
8	.3555	.3555	.2993	.4116	.4303	.3742	.2993
9	.3742	.3555	.3742	.3929	.2993	.3368	.2993
10	.3555	.3555	.3742	.3929	.2432	.2806	.2993
11	.3742		.4116	.4303	.3742	.2806	.3368
12		.4303	.449	.449	.4303	.2619	.3181
13	.4864	.4677	.4677	.449	.449		
14		.4864	.4303	.449	.449		
15	.5239	.4864	.4303	.4303	.4677	.3368	.2993
16	.5613	.449	.3742	.4677	.4677	.2993	.3555
17	.5613	.3929	.3742	.4116	.4864	.3181	.2993
18	.5613	.449	.5613		.5051	.3929	.3742
19	.3742	.5613	.7109	.3555	.5613	.449	.5051
20	.5613	.6922	.7297	.5426	.6548	.6548	.6174
21	.6174	.6361	.6922	.6174	.6548	.6548	.6548
22	.6361	.6922	.6922	.6174	.6548	.5987	.6548
23	.6361	.6735	.6735	.6174	.6361	.5613	.6174
24	.7109	.6361	.6548	.6735	.6174	.6174	.5613
Max	.7109	.6922	.7297	.6735	.6548	.6548	.6548
Min	.3555	.3555	.2993	.3555	.2432	.2619	.2993
Avg	.5307	.5352	.5270	.5125	.5192	.4694	.4643

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

BADNERA SUB-DN.[303] BU 1678

Substation No/ Name :- 034061 / 33 KV LONI S/STN

Feeder No / Name : 202 / 11 KV LONI G

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8165	.7794	.7794	.7794	.7794	.668	.6495
2	.8165		.7794	.7794	.7794	.668	.6495
3	.7423	.7608	.7794	.7794	.7794	.668	.6495
4	.7423	.7608	.7052	.7794	.7794	.668	.6495
5	.7052	.7423	.668	.7423	.7794	.6495	.5938
6	.668	.6495	.6309	.7052	.7794	.6124	.5753
7	.6309	.5938	.5938	.668	.668	.6124	.5567
8	.6124	.501	.5753	.6309	.668	.5567	.501
9	.6124	.4639	.6124	.6495	.6124	.4825	.2598
10	.6124	.5938	.6124	.6309	.5567	.6309	.5196
11	.6495		.6495	.7052	.5938	.2598	.2598
12	.6309	.6309	.668	.668	.5938	.5938	.5196
13	.668	.668	.668	.668	.6124	.5567	.5196
14	.6866	.6866	.6124	.668	.5938	.5381	.5381
15	.6866	.334	.5753	.668	.4825	.5567	.5196
16	.668	.2969	.6495	.6309	.4825		.4639
17	.6495	.2969	.6309		.501		.4268
18	.5938	.6866	.668	.2969	.6124	.5567	.2227
19	.3897	.668	.7423	.5753	.7052	.7423	.2598
20	.7052	.7979	.835	.7423	.7423	.7052	.835
21	.7794	.8165	.835	.7979		.7052	.8165
22	.7979	.835	.8165	.7979	.7052	.668	.8165
23	.7979	.8165	.8165	.7979	.7237	.6495	.7608
24	.835	.7794	.7979	.7979	.7794	.7237	.6495
Max	.835	.835	.835	.7979	.7794	.7423	.835
Min	.3897	.2969	.5753	.2969	.4825	.2598	.2227
Avg	.6874	.6436	.6959	.6939	.6656	.6124	.5505

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

BADNERA SUB-DN.[303] BU 1678

Substation No/ Name :- 034061 / 33 KV LONI S/STN

Feeder No / Name : 203 / 11 KV FULAMALA AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.0327	.0327
2						.0327	.0327
3					.0163	.0327	
4					.0163	.0327	.0327
5					.0163	.0371	.0327
6					.0163	.0327	.0327
7					.0163	.0327	.0327
8					.0163	.0327	.0327
9						.0327	.0327
10	.6048	.8337	1.177	1.4548			
11	.9318		1.0625	1.7164			
12		1.2169	1.3077	1.5529			
13	.9808	.7846	1.3568	1.5366			
14		.8991	1.3568	1.5529			
15	.8664	.8827		1.1606			
16	1.0952	.3269	1.3077	1.3077			
17	1.0135	.7193	1.3241				
Max	1.0952	1.2169	1.3568	1.7164	.0163	.0371	.0327
Min	.6048	.3269	1.0625	1.1606	.0163	.0327	.0327
Avg	.9154	.8090	1.2704	1.4688	.0163	.0332	.0327

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

BADNERA SUB-DN.[303] BU 1678

Substation No/ Name :- 034061 / 33 KV LONI S/STN

Feeder No / Name : 204 / 11 KV HIWARA (AG)

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2341	.2466	.2429	.1248		
2	.2341	.2466	.2591	.1248		
3	.2185	.2466	.2591	.1248		
4	.2185	.2774	.2591	.1248		
5	.3423	.3083	.2915	.1248		
6	.3433	.3237	.4049	.1248		
7	.3901	.4778	.4858	.1404		
8	.4057	.4007	.5182	.2185		
9	.4057	.4162	.4534	.2591		
10				.3077	.0156	.078
11				.3239	.0156	.1079
12				.3563	.0156	.0925
13				.3239	.0624	.078
14					.078	.078
15				.0324	.0624	.0936
16				.0324	.0624	.0936
17					.0624	.078
24	.1872	.2466	.2591	.1248		
Max	.4057	.4778	.5182	.3563	.078	.1079
Min	.1872	.2466	.2429	.0324	.0156	.078
Avg	.2980	.3191	.3433	.1793	.0468	.0875



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

BADNERA SUB-DN.[303] BU 1678

Substation No/ Name :- 034061 / 33 KV LONI S/STN

Feeder No / Name : 205 / 11 KV Shiva-Bio chem

HV Express Feeder

Express F Feeder KV- 11 /

OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.038	.019	.0191	.019	.0191	.019
2	.0381	.038	.019	.0191	.019	.0191	.019
3	.0381	.038	.019	.0191	.019	.0191	.019
4	.0381	.038	.019	.0191	.019	.0191	.019
5	.0381	.038	.019	.0191	.019	.0191	.019
6	.0381	.038	.019	.0191	.019	.0191	.019
7	.0381	.038	.019	.0191	.0191	.0191	.019
8	.0381	.038	.019	.0191	.0191	.0191	.019
9	.1143	.019	.038	.0381	.0191	.0191	.019
10	.038	.038	.057	.038	.0191	.038	.019
11	.038		.0381	.057	.0191	.019	.0857
12	.019	.038	.0381	.038	.0191	.019	.019
13	.019		.0381	.038	.0191	.019	.038
14	.057	.038	.0381	.038	.0191	.019	.038
15	.0951	.038	.0381	.038	.0191	.019	.038
16	.1711	.019	.0381	.038	.0191	.019	.038
17	.1711	.019	.0191	.019	.0191	.019	.038
18	.1711	.019	.0191	.019	.0191	.019	.038
19	.1521	.019	.0191	.019	.0191	.019	.038
20	.038	.019	.0191	.019	.0191	.019	.038
21	.038	.019	.0191	.019	.0191	.019	.038
22	.038	.019	.0191	.019	.0191	.0187	.038
23	.038	.019	.0191	.019	.0191	.019	.019
24	.0381	.038	.019	.0191	.019	.0191	.019
Max	.1711	.038	.057	.057	.0191	.038	.0857
Min	.019	.019	.019	.019	.019	.0187	.019
Avg	.0642	.0302	.0262	.0262	.0191	.0198	.0297

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

BHATKULI SUB-DN.[790] BU 4790

Substation No/ Name :- 034006 / 33 KV BHATKULI

Feeder No / Name : 201 / 11 KV SAYAT FEEDER

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.3944	.4115	.4287	.4115	.4801	.4115
2	.4115	.3772	.4115	.4287	.4115	.4801	.4115
3	.3944	.3772	.3772	.4287	.4115	.4458	.3772
4	.3772	.3772	.3772	.4287	.3944	.4115	.3772
5	.3772	.3601	.3429	.4115	.3944	.4287	.3429
6	.3258	.3429	.3601	.3772	.3258	.3944	.3429
7	.3258	.3086	.2801	.2915	.2058	.3258	.3086
8	.2743	.0274	.2743	.2915	.3258	.3086	.3258
9	.0171	.2743	.2572	.3086	.3429		.3258
10	.2572	.2572	.2229	.3086	.2572		.3086
11	.2572	.2572	.2229	.3429	.2915	.2572	.2572
12	.2743	.2743		.3429	.3086	.2229	.2572
13	.2915	.2743	.3258	.3429	.3258	.2401	.2743
14	.3086	.2915		.3429	.3258	.2572	.3258
15	.3258		.1543	.3258	.3258	.2743	.3258
16	.3086	.2915	.1372	.3258	.3429	.2572	.3086
17	.2743	.2229		.2229		.2743	.2743
18	.2401	.2401	.3429	.3086		.3258	.2572
19	.2401	.3429	.3772	.3772		.3429	.3429
20	.3429	.4115	.4287	.3772		.3772	.463
21	.4287	.4287	.463	.4115		.4115	
22	.4287	.4458	.463	.4115	.4801	.4458	
23	.4287	.4287	.463	.463	.4458	.4287	
24	.4115	.4115	.4287	.463	.4115	.4801	.4115
Max	.4287	.4458	.463	.463	.4801	.4801	.463
Min	.0171	.0274	.1372	.2229	.2058	.2229	.2572
Avg	.3222	.3225	.3391	.3651	.3547	.3577	.3348

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

BHATKULI SUB-DN.[790] BU 4790

Substation No/ Name :- 034006 / 33 KV BHATKULI

Feeder No / Name : 202 / 11 KV Ganojadevi

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743		.2572	.3429	.2743	.2058	.2229
2	.2572		.2572	.3429	.2743	.2058	.2229
3	.2572		.2743	.3429	.2572	.1715	.2058
4	.2401		.2058	.3429	.2572	.1715	.2058
5	.2229		.1886	.3086	.2743	.1372	.1886
6	.1886		.2058	.2572	.2229	.1372	.1886
7	.2401	.1715	.2561	.2572	.2058	.1886	.1715
8	.2743	.1543	.2915	.2401	.1886	.1715	.2058
9	.2743	.2058	.2743	.3086	.2743		.2058
10	.2572	.2401	.2572	.3429	.2915		.0206
11	.0257	.2743		.3944	.2915	.2575	.2572
12	.2572	.3086		.3772	.3086	.2058	.3086
13		.3086		.3772	.2743	.2058	.3429
14		.3258	.0343	.3772	.2915	.1886	.3429
15				.4115	.1715	.2058	.3258
16	.3258			.3944	.2058	.2058	.3258
17	.1715			.1715	.3086	.2229	.3429
18	.1715			.2743	.2915	.2229	.2401
19	.1372	.3086	.2401	.2915	.3658	.2401	.3258
20	.1372	.3429	.4287	.2229	.4854	.2401	.3429
21	.2572	.3429	.4287	.3429	.5068	.2401	
22	.2572	.3086	.3429	.2572	.2401	.2572	
23	.2572	.3086	.3429	.2572	.2229	.2229	
24	.2915	.2401	.2743	.3429	.2572	.2229	.2229
Max	.3258	.3429	.4287	.4115	.5068	.2575	.3429
Min	.0257	.1543	.0343	.1715	.1715	.1372	.0206
Avg	.2274	.2743	.2682	.3158	.2809	.2058	.2484

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

BHATKULI SUB-DN.[790] BU 4790

Substation No/ Name :- 034006 / 33 KV BHATKULI

Feeder No / Name : 203 / 11 KV NIMBHA

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7202	.7545	.7716	.703	.6173	.6001
2	.7545	.7202	.8048	.6859	.6859	.583	.6001
3	.7373	.6859	.7842	.6516	.6859	.583	.583
4	.703	.6173	.6859	.6173	.0514	.5487	.583
5	.6859	.583	.6173	.6173	.0514	.583	.5487
6	.6687	.5658	.6001	.5144	.6001	.5316	.5144
7	.5316	.6001	.6173	.463	.5144	.4801	.4973
8	.6344	.6344	.6516	.5316	.5487	.4115	.583
9	.6859	.6001	.6001		.6001	.4458	.6001
10	.0514	.6173	.4801	.7202	.6344	.4801	.6001
11	.6859	.6859	.5144	.8402	.6687	.463	.6516
12	.6859	.7888		.823	.703	.0446	.6516
13	.703	.7716	.6516	.9088	.6859	.4458	.6173
14	.7202	.823	.6516	.9774	.6344	.4287	.6344
15	.7373		.7373	.8916	.703	.4287	.6344
16	.7202	.3944	.7202	.8573	.6516	.4801	.5144
17	.703	.7202	.8059	.3258	.6173	.5144	.6001
18	.5487	.7202	.7716	.5487	.6344	.5658	.4973
19	.4458	.7716	.7545	.6173	.6859	.703	.6173
20	.5487	.8402	.6516	.703	.823	.6859	.8059
21	.7373	.823	.8402	.703	.6344	.6516	
22	.7545	.7888	.8402	.703	.6516	.6859	
23	.0754	.7716	.8402	.703	.6878	.6344	
24	.7545	.7373	.7716	.8059	.703	.6516	.6173
Max	.7545	.8402	.8402	.9774	.823	.703	.8059
Min	.0514	.3944	.4801	.3258	.0514	.0446	.4973
Avg	.6262	.6948	.7020	.6948	.6066	.5270	.5977

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

BHATKULI SUB-DN.[790] BU 4790

Substation No/ Name :- 034006 / 33 KV BHATKULI

Feeder No / Name : 204 / 11 kv bhatkuli

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.4801	.5144	.4801	.4458	.3429	.3429
2	.4458	.463	.5144	.4801	.4458	.3429	.3429
3	.4287	.4458	.4801	.4801	.4287	.3429	.3258
4	.4115	.4458	.4801	.4801	.4287	.3601	.3258
5	.4115	.4287	.4458	.463	.4458	.3429	.3086
6	.3772	.4115	.3944	.4287	.4287	.3601	.3086
7	.3429	.3429	.3772	.3429	.3258	.3086	.2915
8	.3086	.3086	.3429	.3258	.3258	.2743	
9	.2915	.3258	.3429	.3429	.3086		.2743
10	.2915	.3429	.3086	.4115	.3086		.2572
11		.3772	.3086	.3429	.3086	.2572	.2743
12	.3772	.4287		.3429	.2743	.2401	
13	.4115	.4287	.4115	.3944	.2915	.2401	.3429
14	.4458	.4458	.4458	.4458	.2915	.2572	.3429
15	.463	.4287	.4287	.4287	.3429	.2572	.4458
16	.4287	.4115	.4287	.4287	.3429	.2743	.3258
17	.3944	.4115	.3944	.0171	.3258	.2915	.3258
18	.3429	.3258	.4287	.0171	.3772	.3258	.3258
19	.2743	.3772	.3944	.0171	.4481	.3772	.3772
20	.2401	.5144	.4973	.4973	.4755	.3772	.4287
21	.4973	.5853	.5316	.5144	.4115	.3601	
22	.4973	.6161	.5316	.4801	.4115	.3772	
23	.4973	.5792	.5316	.4801	.4115	.3772	
24	.463	.4801	.5316	.5144	.463	.3772	.3429
Max	.4973	.6161	.5316	.5144	.4755	.3772	.4458
Min	.2401	.3086	.3086	.0171	.2743	.2401	.2572
Avg	.3951	.4336	.4376	.3815	.3778	.3211	.3321

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

BHATKULI SUB-DN.[790] BU 4790

Substation No/ Name :- 034025 / 33 KV WALGAON S/STN

Feeder No / Name : 201 / 11 KV WALGAON FEEDER

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	1.1622	1.2384	1.2003	1.1812	1.0288	1.0098
2	1.2193	1.1241	1.2384	1.1812	1.1812	.9907	1.0098
3	1.1431	1.1241	1.2193	1.1812	1.1812	.9526	.9907
4	1.1431	1.086	1.2384	1.1622	1.1812	.9526	.9907
5	1.0669	1.0669	1.1431	1.1431	1.1431	.9526	.9717
6	.9717	.9526	1.0288	1.0098	1.086	.9526	.9526
7	.8764	.8383	.9145	.8573	1.0288	.8383	.8192
8	.8573	.8002	.8002	.8002	1.105	.7811	.8002
9	.8573	.8573	.8383	.8192	1.0479	.8192	.7811
10	.9145	.9335	.9145	.9335	.9145		.8192
11	.9526	.9907	.9335	.9717	.9526	.8573	.8002
12	.9907	.9717	.9335	.8954	.9145	.743	.8002
13	1.0098	.9335	.9335	.8764	.8383	.724	.7621
14	1.0479	.9526	.9335	.9335	.7811	.6859	.724
15	1.0669	1.0098	.9907	1.0479	.8383		.7621
16	1.086	.8764	1.0098	.9526	.8764	.8192	.7621
17	1.0098	.9335	.9907	.9717	.8573	.8002	.7811
18	.9717	.8764	.9145	.9907	.9335	.9717	.8192
19	.9526	1.0098	.9145	1.1431	.9717	1.1431	.9717
20	1.086	1.1622	1.1812	1.2003	1.1241	1.105	.9526
21	1.086	1.2193	1.1812	1.2003	1.1241	1.0288	1.1431
22	1.2003	1.2384	1.2003	1.2193	1.1241	1.0098	1.1622
23	1.2003	1.2384	1.2384	1.2574	1.0669	1.0098	1.1241
24	1.2193	1.1812	1.2384	1.2193	1.2193	1.0669	1.0098
Max	1.2193	1.2384	1.2384	1.2574	1.2193	1.1431	1.1622
Min	.8573	.8002	.8002	.8002	.7811	.6859	.724
Avg	1.0479	1.0225	1.0487	1.0487	1.0280	.9197	.9050

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

BHATKULI SUB-DN.[790] BU 4790

Substation No/ Name :- 034025 / 33 KV WALGAON S/STN

Feeder No / Name : 202 / 11 KV ASHTI FEEDER

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0191	.0762	.0762	.0572	.0762	.0953
2	.0381	.0191	.0762	.0762	.0572	.0762	.0953
3	.0381	.0191	.0762	.0762	.0572	.0762	.0762
4	.0381	.0191	.0762	.0953	.0572	.0572	.0762
5	.0381	.0191	.0572	.0953	.0381	.0572	.0572
6	.0381	.0191	.0762	.0953	.0381	.0572	.0572
7	.0381	.0191	.0572	.0762	.0381	.0381	.0381
8	.0381	.0953	.0762	.0953	.1334	.0572	.0572
9	.0953	.0762	.0953	.1334	.1143	.0381	.0572
10	.0953	.0762	.0762	.1715	.1334		.0381
11	.0762	.0953		.1905		.0572	.0381
12	.0762	.0953	.0762			.0381	.0762
13	.0762	.0953	.0953	.2477		.0381	.1143
14	.0953	.0762	.0953	.1905		.0381	.1715
15	.0762	.1143	.0762	.2096	.0381	.0572	.1715
16	.0381	.1143	.0381	.1524	.0381	.0762	.1715
17	.1143	.1143	.0762	.0762	.0762	.0762	.1905
18	.0572	.1143	.1143	.0762	.0953	.0762	.1524
19	.0381	.0762		.0572	.0953	.0572	.2096
20	.0381	.1524	.1143	.0572	.0953	.0762	.1905
21	.0381	.0953	.0762	.0762	.0762	.0762	.1524
22	.0381	.0762	.1143	.0572	.0762	.0953	.1905
23	.0381	.0762	.0762	.0572	.0762	.0953	.1715
24	.0381	.0381	.0762	.0762	.0572	.0762	.0953
Max	.1143	.1524	.1143	.2477	.1334	.0953	.2096
Min	.0381	.0191	.0381	.0572	.0381	.0381	.0381
Avg	.0556	.0715	.0805	.1094	.0724	.0638	.1143

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

BHATKULI SUB-DN.[790] BU 4790

Substation No/ Name :- 034025 / 33 KV WALGAON S/STN

Feeder No / Name : 203 / 11 KV KAMUNJA FEEDER Sheddable Rural/Mix Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.086	.9145	.8002	.8954	.724	.6478	.6478
2	1.086	.9145	.7811	.8954	.9145	.6097	.6478
3	1.0669	.8954	.7811	.8764	.8764	.6097	.6478
4	1.0479	.8954	.7811	.8764	.6859	.5716	.6287
5	.7621	.9145	.7621	.8764	.6478	.5716	.6287
6	.724	.9145	.6859	.8573	.5906	.5525	.5906
7	.8002	.9526	.6287	.8764	.5144	.4954	.4954
8	.8192	.9717	.6287	.8764	.4763	.4191	.4382
9	.9717	1.086	.724	.8573	.4572	.4382	.4572
10	1.0098	1.0288	.6859	.8573	.4763		.4572
11	.5144	.9717	.7621	.6859	.4382	.381	.4001
12	.4954	.4191	.7811	.8573	.4191	.381	.5144
13	.5716	.4763	.8002	.9145	.4191	.362	.5335
14	.5335		.7621	.9335	.381	.381	.4954
15	.5335	.743	.724	.8764	.4191	.362	.4954
16	.5716	.0953	.8383	.9335	.4572	.362	.5144
17	1.1241	.5525	.8764		.4763	.381	.5335
18	1.105	.5525	.8383		.4763	.4191	.4954
19	1.0098	.6859	.8764	.3048	.5525	.5525	.6859
20	1.1622	.8383	.9145	.6478	.6668	.6668	.8192
21	1.1241	.7621	.8954	.7621	.7049	.6478	.8192
22	1.0098	.8192	.9335	.7621	.7049	.6668	.7621
23	.9335	.8192	.8383	.743	.6859	.6478	.743
24	1.086	.9335	.8002	.8954	.724	.6478	.6478
Max	1.1622	1.086	.9335	.9335	.9145	.6668	.8192
Min	.4954	.0953	.6287	.3048	.381	.362	.4001
Avg	.8812	.7894	.7875	.8210	.5787	.5119	.5874



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

BHATKULI SUB-DN.[790] BU 4790

Substation No/ Name :- 034025 / 33 KV WALGAON S/STN

Feeder No / Name : 204 / 11 KV NAYA AKOLA FEEDER Sheddable Rural/Mix Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.1524	.2096	.1905	.1524	.1143	.1143
2	.1905	.1334	.1905	.1905	.1524	.1143	.1143
3	.1905	.1334	.1905	.1715	.1524	.1143	.1143
4	.1715	.1334	.1905	.1524	.1334	.0953	.1143
5	.1334	.1334	.1524	.1524	.1334	.0953	.1143
6	.0953	.0953	.1143	.1143	.1143	.0953	.1143
7	.1143	.0953	.1143	.0953	.1143	.0572	.0572
8	.1524	.1143	.1715	.1715	.1143	.0762	.0762
9	.1524	.1905	.2096	.2286	.1143	.0762	.0762
10	.1905	.1905	.1524	.2858	.1905		.0572
11	.1905	.1334	.2096	.2477	.2096	.0762	.0572
12	.1715		.2286	.2096	.1905	.0762	.0762
13	.2477	.2286	.2286	.1905	.1524		.0762
14	.2858	.3048	.2477	.1715	.0762	.0762	.0953
15	.2286	.1715	.2286	.2477	.0762	.0762	.0953
16	.1715	.2096	.2286	.0953	.0762	.0762	.1143
17	.1715	.2286	.2286	.0953	.0762	.0762	.1143
18	.1715	.1715	.2286	.0953	.0762	.0953	.0953
19	.1334	.2096	.2096	.1524	.0953	.1143	.1334
20	.2096	.2477	.1905	.1524	.1143	.1334	.1524
21	.1715		.2667	.1524	.1143	.1334	.1334
22	.1524	.2096	.2096	.1524	.1143	.1143	.1334
23	.1524	.2096	.1905	.1524	.1143	.1143	.1334
24	.2096	.1524	.2096	.1905	.1524	.1143	.1143
Max	.2858	.3048	.2667	.2858	.2096	.1334	.1524
Min	.0953	.0953	.1143	.0953	.0762	.0572	.0572
Avg	.1778	.1749	.2000	.1691	.1254	.0961	.1032

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

BHATKULI SUB-DN.[790] BU 4790

Substation No/ Name :- 034025 / 33 KV WALGAON S/STN

Feeder No / Name : 205 / 11 kv New Khartalegaon Sheddable Rural/Mix Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669	.9907	1.0288	.9717	.9145	.8002	.8192
2	1.0669	.9717	1.0288	.9526	.9145	.7621	.8002
3	1.0479	.9717	1.0288	.9526	.8764	.724	.8192
4	1.0098	.9335	1.0098	.9145	.8383	.6859	.8002
5	.9335	.8764	.9526	.8954	.7621	.6668	.8192
6	.6859	.743	.7811	.7049	.724	.6668	.743
7	.5525	.5906	.5335	.5716	.5716	.4763	.4572
8	.5335	.5335	.4763	.5335	.5716	.4382	.4191
9			.5335	.5335	.4763	.381	.4382
10			.4954	.5525	.4572		.4001
11			.5144	.5906	.3429	.381	.381
12			.5906	.6859	.381	.362	.4001
13			.362	.724	.4191	.4191	.4191
14	.8764	.8192	.381	.7621	.4763	.381	.4382
15	.8383	.5716	.743	.743	.5335	.4001	.4382
16	.8573	.6478	.4763	.6668	.4954	.4001	.4191
17	.724	.6097	.4572	.4191	.5335	.362	.4191
18	.6287	.3429	.6097	.4954	.4954	.4954	.4572
19	.7049	.6859	.6668	.724	.6097	.6097	.7049
20	.9145	.9526	.8954	.8573	.7811	.8002	.8192
21	.9717	.9907	.9335	.9526	.8383	.8002	.8764
22	1.0479	1.0479	.9717	.9717	.8954	.7811	.9335
23	1.0288	1.0479	.9907	.9717	.8383	.8192	.9335
24	1.0669	1.0098	1.0479	.9907	.9526	.8383	.8192
Max	1.0669	1.0479	1.0479	.9907	.9526	.8383	.9335
Min	.5335	.3429	.362	.4191	.3429	.362	.381
Avg	.8714	.8072	.7295	.7557	.6541	.5848	.6239

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

BHATKULI SUB-DN.[790] BU 4790

Substation No/ Name :- 034025 / 33 KV WALGAON S/STN

Feeder No / Name : 206 / TAKARKHEDA GAOTHAN FEEDER Gaothan Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.9335	1.0479	.9907	.9145	.7621	.7621
2	.9526	.8954	1.0288	.9907	.9145	.7621	.7621
3		.8954	1.0288	.9717	.8764	.724	.7621
4		.8573	1.0479	.9526	.8764	.6859	.743
5		.8383	.9526	.9145	.8002	.6478	.743
6		.724	.8002	.724	.7049	.6478	.743
7		.5525	.5906	.6097	.6287	.5335	.5144
8		.5525	.5335	.5144	.5716	.4763	.4572
9		.5335	.5525	.5525	.6097	.4572	.4572
10		.4954	.1524	.5716	.5335		.4382
11		.5335	.5335	.6097	.5525		.4001
12	.0762	.5716	.5525	.6097	.4954		.4191
13	.7049	.6097	.6478	.6287			.4572
14	.6859	.6859	.743	.743		.4001	.4763
15	.8383	.6668	.6859	.4191	.5144	.4763	.4763
16	.7811	.6478	.6478	.4954	.4954	.4382	.4572
17	.7049	.5525	.6097	.5144	.5144	.362	.4382
18	.5906		.5144	.5335	.4954	.4763	.4191
19	.6097		.5906	.724	.5906	.6287	.5525
20	.8383	.9526	.8573	.8764	.7811	.7811	.8002
21	.9335	1.0098	.9145	.9335	.8002	.8002	.8192
22	1.0288	1.0669	1.0098	.9526	.8383	.7811	.8383
23	.9717	1.0669	1.0098	.9526	.8192	.7811	.8573
24	1.0288	.9526	1.0479	1.0098	.9526	.8002	.7621
Max	1.0288	1.0669	1.0479	1.0098	.9526	.8002	.8573
Min	.0762	.4954	.1524	.4191	.4954	.362	.4001
Avg	.7849	.7543	.7542	.7415	.6945	.6211	.6065

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

CHANDUR RLY SUB-DN.[300] BU 3000

Substation No/ Name :- 034004 / 33KV GHUIKHED SUBSTATION

Feeder No / Name : 201 / 11 KV GHUIKHED FEEDER

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3012		.3018	.3898	.3366		.2667
2			.3048	.3721	.3366		.2667
3	.2915		.3048	.3721	.3366		.2667
4	.2743		.3018	.3189	.3366		.2667
5	.2743		.2561	.3189	.3189		.2427
6	.2743		.2303	.2835	.3189		.2378
7	.2372		.1966	.2658	.2658		.1829
8	.2458		.213	.3189	.3601		.1638
9	.3768		.2622	.3721	.4287		.1429
10	.3605	.2667	.3224	.4075	.4801		.1677
11	.3277	.2241	.3224	.4075	.4904		.1677
12	.3005	.2195	.3582	.4607	.5087		.1772
13	.3953	.2458	.3721	.1886	.39		.2303
14	.4111	.2785	.443	.5138			.2126
15	.3913	.2785	.4607	.5493		.2096	.2126
16	.333	.1886	.4607	.4075		.2286	.1772
17	.3715	.1802	.3721	.4961		.1905	.1772
18	.3864	.2012	.4252	.2835		.2286	.1772
19		.2075	.4252	.3898			.2303
20		.3174	.4784	.4075			.2835
21		.3018	.4607	.4252		.2987	.2835
22		.3395	.4252	.4075		.2987	.298
23		.3174	.3898	.3898		.2858	.3012
24	.3544		.3239	.4075	.3721		.2858
Max	.4111	.3395	.4784	.5493	.5087	.2987	.3012
Min	.2372	.1802	.1966	.1886	.2658	.1905	.1429
Avg	.3282	.2548	.3505	.3814	.3772	.2486	.2258

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

CHANDUR RLY SUB-DN.[300] BU 3000

Substation No/ Name :- 034004 / 33KV GHUIKHED SUBSTATION

Feeder No / Name : 202 / 11 KV JAWALA AG FEEDER

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0709		.0343	.0876	.1417		.1067
2			.0354	.0876	.1417		.1067
3			.0354	.0876	.1417		.1067
4					.1417		.1067
5					.2658		.0914
6					.3366		.0914
7			.0949	.3506	.5138		.1054
8	.0514		.1372	.5083	.7442		.1808
9	.4115		.2134	.6661	.7045		.2172
10	.3864	.0171	.3681	.7796	.6062		
11	.3909	.1311	.5258	.7087	.3765		
12	.333	.1966	.4733	.6556	.4489		
13	.3755	.2688	.5258	.6024	.3765		
14	.3755	.3201	.5959	.5847			
15	.4199	.2972	.5434	.5658			
16	.459		.5258	.5316			
17	.5424	.3048	.5434	.6556		.1829	
18	.4778	.3163	.4733			.1981	
19		.0171	.3856	.2303		.2012	
20		.0857	.3155	.2481		.0857	.0701
21		.0886	.298	.2126		.1029	.0701
22		.0362	.2804	.0886		.0838	.0701
23		.0362	.2454	.0886		.0857	.0701
24	.0709		.0343	.0876	.1595		.1067
Max	.5424	.3201	.5959	.7796	.7442	.2012	.2172
Min	.0514	.0171	.0343	.0876	.1417	.0838	.0701
Avg	.3358	.1628	.3183	.3914	.3642	.1343	.1072

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

CHANDUR RLY SUB-DN.[300] BU 3000

Substation No/ Name :- 034004 / 33KV GHUIKHED SUBSTATION

Feeder No / Name : 203 / 11KV BAGGI FEEDER

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3544		.1966	.2507	.1543		.0543
2			.2058	.2507	.1595		.0532
3			.2058	.2328	.1417		.0543
4			.1886	.2328	.124		.0543
5			.1677	.2149	.124		.0343
6			.1311	.197	.1949		.0339
7					.2303		
8					.2126		
9					.2229		
10	.2012		.1612	.2481	.2743		.0633
11	.3311	.112	.1075	.3189	.301		.0362
12	.3269	.1475		.3189			.0537
13	.3269	.1147	.1075	.0514	.2972		.0537
14	.3715	.1581	.1075	.3898			.0537
15	.3765	.1739	.0537	.3544		.0671	.0537
16	.4923		.1075	.3544		.0514	.0537
17	.3864	.1311	.2507	.2835		.0532	.0358
18	.3715	.0848	.2149	.1949		.0886	.0537
19		.0343	.2454	.1949		.1063	.0895
20		.1372	.3045	.2658		.1063	.0716
21		.1372	.3045	.2658		.0886	.1075
22		.2229	.3045	.2658		.1086	.1075
23		.2481	.2658	.2572		.0709	.1075
24	.3721		.2374	.2507	.2658		.0857
Max	.4923	.2481	.3045	.3898	.301	.1086	.1075
Min	.2012	.0343	.0537	.0514	.124	.0514	.0339
Avg	.3555	.1418	.1934	.2568	.2079	.0823	.0624

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

CHANDUR RLY SUB-DN.[300] BU 3000

Substation No/ Name :- 034004 / 33KV GHUIKHED SUBSTATION

Feeder No / Name : 204 / 11 KV RAJURA GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	28-JUN-17
HR	Load (MW)
14	.3898
Max	.3898
Min	.3898
Avg	.3898

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

CHANDUR RLY SUB-DN.[300] BU 3000

Substation No/ Name :- 034031 / 33 KV MALKHED

Feeder No / Name : 201 / 11 KV Pardi AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.016	.0162	.0162
2					.016	.0162	.0162
3					.016	.0162	.0162
4					.016	.0324	.0162
5					.016	.0162	.0162
6					.016	.0162	.0162
7					.016	.0162	.0162
8					.016	.0162	.0162
9					.032	.0162	.0162
10	.0324	.0486	.0324	.048			
11	.0324	.0486	.0324	.048			
12	.0324	.0486	.0324	.048			
13	.0486	.0486	.0324	.048			
14	.0486	.0486	.0324	.048			
15	.0486	.0162	.0324	.048			
16	.0486	.0162	.0324	.048			
17	.0486	.0324	.0324	.048			
23	.0514						
24					.016	.0162	.0162
Max	.0514	.0486	.0324	.048	.032	.0324	.0162
Min	.0324	.0162	.0324	.048	.016	.0162	.0162
Avg	.0435	.0385	.0324	.048	.0176	.0178	.0162



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

CHANDUR RLY SUB-DN.[300] BU 3000

Substation No/ Name :- 034031 / 33 KV MALKHED

Feeder No / Name : 202 / 11 Kv MALKHED

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6935	.724	.543	.7316	.7164	.5316	.5487
2	.6935	.724	.543	.7316	.7164	.5316	.5487
3	.6859	.724	.3658	.7316	.7164	.5258	.543
4	.6001	.724	.3658	.724	.7164	.5258	.5373
5	.5868	.7011	.3658	.724	.7164	.3467	.5373
6	.2058	.5258	.3658	.5258	.4973	.3429	.5316
7	.4973	.5144	.3582	.5144	.4973	.3391	.5144
8	.4973	.4915	.3467	.663	.4973	.3856	.503
9	.4973	.4973		.663	.4973	.3391	.5144
10	.4973	.4973	.5258	.663	.4973	.3315	.4973
11	.4973	.4915	.5316	.663	.3277	.3277	.503
12	.4973	.503	.5201	.663	.4973	.2972	
13	.4973	.5087	.6859	.663	.503	.3048	.4915
14		.5144	.6859	.663	.4973	.3353	.4858
15	.4973	.4858	.6859	.663	.503	.3277	.5144
16	.663	.4858	.6706	.663	.4973	.3353	.5087
17	.6478	.3429	.6706	.663	.3391	.5144	.5144
18	.4858	.5144	.663	.6706	.3429	.503	.5087
19	.4801	.7011	.6554	.503	.5258	.5144	.5201
20	.5487	.7164	.7011	.6706	.3506	.7011	.7164
21	.724	.543	.7164	.7316	.3544	.7011	.7087
22		.543	.7164	.7316	.5373	.5258	.7011
23	.2058	.543	.724	.7164	.5316	.543	.6935
24	.7087	.724	.5487	.724	.7164	.5373	.5487
Max	.724	.724	.724	.7316	.7164	.7011	.7164
Min	.2058	.3429	.3467	.503	.3277	.2972	.4858
Avg	.5413	.5725	.5633	.6692	.5247	.4445	.5518

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

CHANDUR RLY SUB-DN.[300] BU 3000

Substation No/ Name :- 034031 / 33 KV MALKHED

Feeder No / Name : 203 / 11 KV KAWATHA AG FEEDER

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.463	.2572	.1448	.3048	.0191	.0191	.0191
2	.4515	.2572	.1448	.3048	.0191	.0191	.0191
3	.4816	.2972	.1448	.2972	.0191	.0381	.0191
4	.4999	.2972	.141	.2934	.0191	.0191	.0191
5	.4744	.2972	.141	.2858	.0191	.0191	.0191
6	.463	.2858	.1353	.2858	.0191	.0191	.0191
7	.463	.2972	.282	.4458	.0191	.0191	.0191
8	.5868	.4401	.4344	.6097	.0191	.0191	.0191
9	.5868	.2896	.2896	.6097	.0191	.0191	.0191
10	.0191	.0191		.0191	.4973		.2858
11	.0191	.0191		.0191	.4641	.0457	.2858
12	.0191	.0191		.0191	.6097	.024	.2934
13	.0191	.0191		.0191	.0903	.0259	.301
14	.0191	.0191	.0191	.0191	.0305	.0229	.2934
15	.0191	.0191	.0191	.0191	.3086	.0229	.2934
16	.0191	.0191	.0191	.0191		.0229	.3269
17	.0191	.0191	.0191	.0191	.1505	.0229	.301
18	.0191	.0191	.0191	.0191	.0381	.0191	.0191
19	.0191	.0191	.0191	.0191	.0191	.0191	.0191
20	.0191	.0191	.0191	.0191	.0381	.0191	.0381
21	.0381	.0191	.0191	.0191	.0381	.0191	.0191
22		.0191	.0191	.0191	.0191		.0191
23	.1886	.0191	.0191	.0191	.0191	.0191	.0191
24	.4515	.3772	.1448	.3048	.0191	.0191	.0191
Max	.5868	.4401	.4344	.6097	.6097	.0457	.3269
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.2330	.1401	.1097	.1671	.1093	.0224	.1127

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

CHANDUR RLY SUB-DN.[300] BU 3000

Substation No/ Name :- 034031 / 33 KV MALKHED

Feeder No / Name : 205 / 11 KV KAWTHA GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5068	.4525	.4706	.5068	.4525	.4525	.4163
2	.4706	.4525	.4706	.5068	.4525	.4344	.4163
3	.4887	.4525	.4706	.4887	.4525	.4163	.3982
4	.4706	.4525	.4344	.4887	.4525	.362	.3982
5	.3801	.362	.4344	.4706	.4525	.362	.3982
6	.3439	.3258	.362	.3258	.4163	.3258	.3077
7	.2896	.2715	.3258	.3077	.2534	.2715	.2715
8	.2715	.2172	.3077	.2896	.2896	.2534	.2353
9	.2896	.2534	.2896	.3258	.2896	.2715	.2896
10	.2715	.2534	.2534	.3077	.2896		.2715
11	.2896	.2534	.3077	.362	.3982	.1629	.2534
12	.1886	.362	.3439	.362	.3077	.181	.2896
13	.2896	.362	.3982	.362	.362	.181	.2715
14	.4344	.3801	.3982	.362	.362	.181	.3439
15	.1886	.3439	.3982	.362	.362	.0724	
16	.5068	.3077	.362	.362	.3439		.3258
17	.4525	.2534	.2896	.362	.2715	.3077	.2896
18	.362	.2896	.2896	.362		.2715	.3439
19	.3439	.4344	.3077			.2896	.3258
20	.4344	.4344	.4525		.4887	.4525	.362
21	.4706	.4887	.4706	.5249	.4525	.4525	.5068
22		.5068	.4706	.5249	.4706	.1629	.4706
23	.1886	.5068	.4887	.5249	.4525	.4525	.4344
24	.5249	.5068	.4887	.5068	.5249	.4706	.4163
Max	.5249	.5068	.4887	.5249	.5249	.4706	.5068
Min	.1886	.2172	.2534	.2896	.2534	.0724	.2353
Avg	.3677	.3718	.3869	.4089	.3908	.3085	.3494

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

CHANDUR RLY SUB-DN.[300] BU 3000

Substation No/ Name :- 034070 / 33 KV CHANDUR (RLY) SUB STN

Feeder No / Name : 201 / 11KV CHANDUR RLY URBAN Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6392	1.5203	1.448	1.4842	1.4586	1.3032	1.1851
2	1.6028	1.5203	1.448	1.4842	1.4222	1.267	1.1487
3	1.5482	1.448	1.4118	1.3756	1.3675	1.267	1.1122
4	1.4935	1.267	1.4118	1.267	1.3128	1.2308	1.094
5	1.366	1.267	1.3756	1.267	1.2581	1.086	1.094
6	1.2034	1.086	1.1222	1.1403	1.1487	1.0136	1.021
7	.9663	1.0136	1.0136	.9955	1.021	.905	.8205
8	.9299	.9412	.9231	.9412	.9299	.7964	.8569
9	.9116	.9774	.9593		.9481	.8145	
10	.9481	1.0317	.8869	1.021	.9663		.8934
11	1.0498	1.1222	.9593	1.094	.9774		.9299
12	1.1946	1.1584	1.086	1.1122	1.0136		.9481
13	1.3032	1.1765	1.1203	1.2034	1.0498		1.094
14	1.3756	1.2308	1.1403	1.2763	1.086	1.0028	1.094
15	1.448	1.2308	1.086	1.3128	1.086	1.021	1.1304
16	1.4118	1.1222	1.0498	1.2216	1.0136	.9846	1.094
17	1.3032	1.0498	1.0136	1.0393	.9475	.9299	.9846
18	1.1584	1.086	1.0136	1.1487	1.0498	.9846	.9774
19	1.267	1.1041	1.2308	1.2945	1.1041	1.1851	1.1584
20	1.5203	1.3756	1.3575	1.4222	1.267	1.3857	1.3575
21	1.5565	1.4299	1.3756	1.5316	1.3032	1.3128	1.5565
22		1.5203	1.5565	1.6227	1.3756	1.2763	1.5023
23	1.6289	1.5023	1.5203	1.5498	1.3756	1.2581	1.448
24	1.6757	1.6289	1.4842	1.5203	1.4951	1.3394	1.2034
Max	1.6757	1.6289	1.5565	1.6227	1.4951	1.3857	1.5565
Min	.9116	.9412	.8869	.9412	.9299	.7964	.8205
Avg	1.3262	1.2421	1.2081	1.2750	1.1657	1.1182	1.1176

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

CHANDUR RLY SUB-DN.[300] BU 3000

Substation No/ Name :- 034070 / 33 KV CHANDUR (RLY) SUB STN

Feeder No / Name : 202 / 11KV KURHA FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8688	.381	.6331	.6241	.7124	.4448	.5218
2		.381	.5979	.6241	.7116	.4448	.5044
3		.3353	.5979	.5895	.695	.4106	.487
4			.5627	.5201	.6746	.4106	.487
5			.5627	.5201	.6081	.3764	.5218
6			.4572	.4854	.5734	.3251	.4175
7			.4448	.5375	.4518	.2908	.2572
8			.4106	.5201	.1738	.2908	.3131
9	.6075			.8149	.2259	.2737	
10	.6769	.6762		.973	.2433		.3653
11	.6935	.7528		.9383	.2395		.3653
12	.6935	.7186	.3467	1.0078	.479		.3131
13	.6935	.7015	.6935	.9546	.6672		.1913
14	.7628	.5817	.8495	.9904	.5988	.2058	.2435
15	.8322	.7357	.8238	.1886	.5133	.3128	.2087
16	.8322		.7282	.9372		.3475	.2087
17	.8669		.6935	.781		.3996	.2261
18	.1886	.0171	.7455		.2395	.3475	.3814
19	.6935	.4448	.7975	.2951	.3593	.4865	.4508
20	.6935	.6145	.7802	.5728	.4106	.5386	.5721
21	.6588	.6672	.1715	.8505	.4277	.5386	.6415
22		.6843	.6935	.8505	.479	.5566	.5895
23	.6935	.4115	.6935	.781	.479	.556	.5548
24	.8688	.5275	.4924	.6241	.7471	.4448	.5392
Max	.8688	.7528	.8495	1.0078	.7471	.5566	.6415
Min	.1886	.0171	.1715	.1886	.1738	.2058	.1913
Avg	.7078	.5394	.6084	.6948	.4868	.4001	.4070

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

CHANDUR RLY SUB-DN.[300] BU 3000

Substation No/ Name :- 034070 / 33 KV CHANDUR (RLY) SUB STN

Feeder No / Name : 203 / 11 KV SATEFAL FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5274	.5087	.3021	.3052	.2393	.3021	.3426
2	.4939	.5087	.3021	.3052	.2222	.2686	.3426
3		.5087	.2686	.3052	.2224		.3254
4		.4748	.2686	.2713	.2053		.3258
5		.4748	.2686	.2374	.2053		.3429
6		.4409	.2014	.2374	.2053		.2743
7		.373	.1678	.2035	.1882		.2058
8	.3062	.3561	.1511	.2035	.2053	.0336	.1886
9	.3913	.3052	.1846	.1357	.2566	.0839	
10	.4423	.2543	.1696	.1882	.2566	.0839	.1715
11	.4917	.1846	.1696	.2734	.2853		.1886
12	.4748	.2014	.1865	.3247	.2686		.1715
13	.4409	.2014	.2374	.3247	.2518		.2743
14	.407	.235	.2543	.3251	.2518	.2051	.2401
15	.3052	.2518	.2543	.3418	.2518	.2053	.2401
16	.373	.235	.2374	.3418	.1343	.2566	.2572
17	.407	.2182	.2374	.2905	.1007	.2737	.2743
18	.1029	.235	.2543		.1678	.2908	.2743
19	.2713	.2518	.1029	.3247	.235	.3422	.3601
20		.3021	.39	.2563	.235	.4619	.4409
21	.2035	.3357	.1029	.2734	.235	.4106	.4578
22		.3525	.407	.2905	.3357	.3939	.4409
23	.4409	.3525	.0377	.2563	.3357	.3764	.4409
24	.6125	.5087	.3357	.373	1.4014	.3021	.3597
Max	.6125	.5087	.407	.373	1.4014	.4619	.4578
Min	.1029	.1846	.0377	.1357	.1007	.0336	.1715
Avg	.3936	.3363	.2288	.2778	.2790	.2682	.3017

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

CHANDUR RLY SUB-DN.[300] BU 3000

Substation No/ Name :- 034070 / 33 KV CHANDUR (RLY) SUB STN

Feeder No / Name : 204 / 11 KV MANJARKHED FEEDER Single Phasing Feeders  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7194	.4557	.4742	.5792	.4396	.3726	.3701
2		.4557	.4742	.5609	.4049	.3726	.3525
3		.4557	.4404	.543	.4049	.3726	.3348
4		.4557	.4404	.4908	.3873	.3387	.3525
5		.4557	.4404	.4908	.3873	.3387	.3701
6	.4572	.4207	.4065	.4908	.4225	.3218	.3525
7	.4396	.4207	.3726	.4733	.3873	.2032	.2996
8	.4045	.3856	.3726	.5609	.4049	.2032	.3348
9	.4748	.4557	.4065	.6661	.4225	.2371	
10	.5275	.5959	.4404	.7386	.4577		.3525
11	.5258	.5928	.5434	.8792	.4742		.3877
12	.7011	.6097	.6135	.8968	.4912		.423
13	.7362	.6267	.6135	.8968	.1536		.423
14	.724	.5759	.5784	.8764	.4742	.2112	.3701
15	.1578	.542	.5784	.8617	.4742	.282	.4582
16	.7011	.4742	.5609	.7913	.3387	.3172	.4406
17	.6661	.3557	.5792	.6682	.1715	.2289	.4053
18	.5609	.4065	.5258		.2879	.2291	.4298
19	.5609	.4404	.5609		.271	.3172	.4298
20	.5258	.4404	.5434	.4396	.3726	.3877	.5258
21	.4908	.4573	.547	.4748	.3896	.4053	.5609
22		.4912	.5609	.4924	.4065	.4053	.5258
23	.4908	.4742	.5258	.4572	.4065	.4053	.5258
24	.7026	.4557	.4742	.631	.4572	.3726	.3877
Max	.7362	.6267	.6135	.8968	.4912	.4053	.5609
Min	.1578	.3557	.3726	.4396	.1536	.2032	.2996
Avg	.5562	.4792	.5031	.6345	.3870	.3161	.4093

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

CHANDUR RLY SUB-DN.[300] BU 3000

Substation No/ Name :- 034070 / 33 KV CHANDUR (RLY) SUB STN

Feeder No / Name : 205 / 11KV DHANORA FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2509	.1989	.1707	.1658	.1675	.1536	.1344
2	.2175	.1989	.1707	.1658	.1507	.1536	.137
3	.2175	.1658	.1707	.1658	.1507	.1536	.1344
4	.2007	.1658	.1536	.1492	.1507	.1366	.1512
5	.2007	.1326	.1536	.1492	.134	.1366	.1512
6	.2007	.1326	.1195	.1326	.1341	.1195	.1344
7	.184	.0995	.1024	.0995	.1174	.1024	.1008
8	.2509	.0829	.0854	.0829	.1006	.0854	.084
9	.3342	.0829	.1024	.116	.1006	.0854	
10	.4177	.0995	.1024	.1004	.1509		.084
11	.431	.1024	.116	.134	.1195		.084
12	.431	.1195	.0829	.1842	.1536		.1176
13	.431	.1366	.0995	.2177	.1707		.1176
14	.431	.1195	.0995	.2055	.1707	.0838	.1176
15	.431	.1024	.0995	.2055	.1536	.1007	.1344
16	.3647	.1372	.0829	.1675	.1024	.1175	.1176
17	.6299	.1543	.0995	.3182	.1024	.0839	.0672
18	.5304	.1024	.116	.134	.1024	.1007	.1006
19	.2321	.1195	.1326	.1507	.1366	.1175	.1174
20	.2321	.1707	.1658	.1842	.1707	.1846	.1823
21	.1658	.1878	.1823	.201	.1878	.1846	.2012
22		.1878	.1823	.201	.1707	.1846	.2012
23	.1658	.1878	.0829	.1842	.1707	.168	.1677
24	.3011	.1989	.1878	.1658	.1675	.1536	.1512
Max	.6299	.1989	.1878	.3182	.1878	.1846	.2012
Min	.1658	.0829	.0829	.0829	.1006	.0838	.0672
Avg	.3153	.1411	.1275	.1659	.1432	.1303	.1300



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

CHANDUR RLY SUB-DN.[300] BU 3000

Substation No/ Name :- 034070 / 33 KV CHANDUR (RLY) SUB STN

Feeder No / Name : 207 / 11 WATER WORKS EXPRESS Only one consumer of WW with HT-IV  
FEEDER Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0486	.0648	.3086	.081	.0648	.0171	.0469
2	.0324	.0648	.3086	.0648	.0648	.0171	.0486
3	.0648	.0648	.0686	.0648	.081	.0171	.0648
4	.0857	.0972	.0857	.0648	.081	.0171	.081
5	.12	.0972	.0857	.096	.1134	.0171	.0509
6	.0972	.0972	.1029	.096	.1134	.0171	.0857
7	.1475	.1134	.12	.0937	.081	.0171	.0469
8	.0625	.1134	.12	.096	.1094	.0343	.0156
9	.0983	.1134	.1029	.081	.1107	.0343	
10	.0914	.1296	.12	.1134	.061	.0171	.0143
11	.0686	.0857	.1296	.081	.1029		.0181
12	.1029	.0857	.0972	.1134	.1029		.0339
13	.1029	.0857	.0972	.1134	.0514		.0343
14	.096	.0857	.081	.081	.1372	.0648	.0343
15	.096	.0857	.0972	.0335	.1372	.0838	.0509
16	.0648	.0857	.1134	.061	.0514	.1107	.0343
17	.081	.0514	.1134	.0914	.0514	.1094	.0171
18	.081	.0857	.0972	.08		.0937	.0328
19	.064	.12	.1134	.0949	.0514	.112	.0328
20	.0648	.12	.1134	.0983	.0514	.081	.0671
21	.0648	.1372	.081	.0972	.0343	.0648	.0648
22	.1017	.12	.081	.0926	.1029		.0671
23	.0972	.1029	.081	.081	.0171	.0362	.0655
24	.0486	.0648	.1029	.081	.0648	.0171	.0185
Max	.1475	.1372	.3086	.1134	.1372	.112	.0857
Min	.0324	.0514	.0686	.0335	.0171	.0171	.0143
Avg	.0826	.0947	.1176	.0855	.0799	.0489	.0446

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

CHANDUR RLY SUB-DN.[300] BU 3000

Substation No/ Name :- 034086 / 33 KV RAJURA SUB STATION

Feeder No / Name : 201 / 11 KV RAJURA GAOTHAN NEW

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2896	.3326	.3258	.3077	.3224		.2715
2	.2534	.3292	.3258	.3077	.3224		.2715
3	.1991	.3045	.3258	.3077	.3224	.6697	.2715
4	.2896	.2957	.3258	.3077	.3045	.6767	.2715
5	.2896	.2926	.3077	.2896	.2865	.5611	.2715
6	.2172	.2353	.2534	.2715	.2686	.5249	.2715
7	.181	.2353	.2172	.2353	.2353	.4163	.1267
8	.1991	.2195	.2172	.2172	.2507	.4163	.1629
9	.2172	.1991	.1991	.1991	.2686		
10	.2534	.181		.2534	.2507		
11	.2507	.181		.2896	.2534	.2896	
12	.2328	.2172		.2926	.2715		
13	.2686	.2715		.3109	.3077	.3982	
14	.3224	.2715	.2896	.3475	.3077	.4163	
15	.3224		.181	.3109	.181	.181	.2328
16	.3045	.1267	.2534	.2926	.1991	.181	.2149
17	.2507	.2172	.2534	.2561	.181	.0857	.2149
18	.1791	.2172	.2353	.1829	.2172	.1448	.197
19		.2353	.2715	.2743		.2172	.2507
20		.3439	.3258	.3761		.3077	.3582
21	.4251	.3439	.3439	.3582	.6154	.3077	.3439
22	.4207	.3292	.3258	.3403		.3258	.3258
23	.3326	.3077	.3258	.3403	.8688	.2715	.3258
24	.3439	.3292	.3258	.3258	.3224	.1991	.2896
Max	.4251	.3439	.3439	.3761	.8688	.6767	.3582
Min	.1791	.1267	.181	.1829	.181	.0857	.1267
Avg	.2747	.2616	.2815	.2915	.3123	.3469	.2596

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

CHANDUR RLY SUB-DN.[300] BU 3000

Substation No/ Name :- 034086 / 33 KV RAJURA SUB STATION

Feeder No / Name : 202 / 11 KV BORI GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.3109	.2896	.2926	.3258		.2353
2		.2896	.2896	.2926	.3224		.2353
3		.3077	.2896	.2926	.3045	.2561	.2353
4		.2896	.2715	.2561	.3045	.2534	.2353
5		.2896	.2534	.2195	.2686	.2534	.2353
6		.2172	.1463	.2012	.197	.181	.1991
7		.1629	.1267	.1646	.1791	.1463	.1267
8		.1267	.128	.1829	.1791		.1086
9	.0366	.181	.1267	.1829	.1612		
10	.0914	.1448		.2012	.1612		
11	.2149	.181		.2149	.1829	.1086	
12	.2328	.181	.1829	.2378	.1829	.1086	
13	.2686	.2172	.2195	.2561	.1646	.1086	
14	.2865	.2353	.2378	.2926	.1463	.1267	.197
15	.2865	.1991	.0366	.2743		.1267	.197
16	.2686	.1991	.1829	.2195	.128	.1086	.197
17	.2172	.1629	.1829	.1829	.128	.1267	.1433
18	.181	.1629	.2926	.2012	.1448	.1086	.1791
19	.1791	.2172	.2195	.2149	.1267	.2172	.0287
20		.2896	.0514	.3045	.2534	.3077	.3439
21	.2926	.3077	.3109	.3224	.2926	.3077	.3439
22	.3292	.3077	.3292	.3582	.0686	.3077	.3439
23	.3109	.2896	.3292	.3403	.3109	.2715	.3439
24	.3292	.3292	.2926	.3292	.3224	.2561	.2715
Max	.3292	.3292	.3292	.3582	.3258	.3077	.3439
Min	.0366	.1267	.0366	.1646	.0686	.1086	.0287
Avg	.2235	.2333	.2177	.2515	.2111	.1937	.2211

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

DHAMANGAON SUB-DN.[299] BU 2992

Substation No/ Name :- 034005 / 33 KV MANGRUL SUB STN

Feeder No / Name : 201 / 11 kv Nimboli G

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.4763	.4001	.4382	.4191	.381	.3239
2	.1905	.4572	.381	.4382	.4382	.362	.3239
3	.1905	.4572	.381	.4191	.362	.362	.3048
4	.2096	.4001	.362	.4001	.3239	.362	.3048
5		.4001	.2667	.381	.2667	.3429	.2858
6		.2667	.2286	.2477	.2477	.2667	.2667
7		.2286	.1524	.2096	.2286	.1905	.2286
8		.1905	.1905	.1715	.2096	.2096	.1715
9		.2286	.2096	.2096	.2096	.2096	.1715
10	.2477	.2096	.2096	.2096	.2096	.2096	.1905
11	.2096	.2096	.1524	.2096	.2286	.2096	.1334
12	.2858	.2286	.1905	.2286	.2286	.4287	.1334
13	.2667	.2477	.2667	.2286	.2477	.1905	.2096
14	.2667	.2477	.2858	.2858		.2096	.2096
15	.2858	.2286	.3239	.3239		.2286	.2096
16	.3429	.1524	.2858	.2858		.2096	.2286
17	.3048	.1715	.2667	.2286	.2096	.2096	.1715
18	.2096	.2286	.2477	.2667	.2477	.2096	.4287
19	.3048	.3048	.3048	.3429	.2858	.3429	.3239
20	.381	.4001	.4191	.381	.3429	.4191	.381
21	.4572	.4191	.4382	.4954	.381	.4001	.4382
22	.4763	.4191	.4763	.4763		.362	.4382
23	.4763	.4191	.4572	.4763	.4001	.3429	.4382
24	.4382	.4763	.4001	.4382	.4763	.381	.3429
Max	.4763	.4763	.4763	.4954	.4763	.4287	.4382
Min	.1905	.1524	.1524	.1715	.2096	.1905	.1334
Avg	.3118	.3112	.3040	.3247	.2982	.2933	.2775

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

DHAMANGAON SUB-DN.[299] BU 2992

Substation No/ Name :- 034005 / 33 KV MANGRUL SUB STN

Feeder No / Name : 202 / 11 kv Mangrul G

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6287	.5716	.5335	.5716	.5335	.4572	.5335
2	.3048	.5525	.5335	.5716	.5335	.4382	.5144
3	.3429	.5525	.4954	.5716	.4954	.4382	.4763
4	.3429	.5144	.4763	.5335	.4954	.4382	.4572
5	.381	.4954	.4382	.4954	.4763	.4191	.4191
6	.381	.362	.381	.381	.4572	.3429	.362
7	.3048	.2858	.2858	.362	.5335	.2477	.3048
8	.3429	.2477	.3048	.4001	.6287	.2477	.2477
9	.3429	.2858	.3048	.4572	.6478	.2667	.2477
10	.362	.2858	.3239	.5335	.5906	.2477	.2477
11	.4001	.3239	.362	.5335	.6859	.2286	.2858
12	.5335	.4001	.4191	.5716	.7049	.6001	.2858
13	.5525	.381	.4572	.6287	.743	.2667	.3429
14	.5144	.362	.4954	.6478		.2858	.362
15	.6478	.4001	.5716	.6478		.2858	.381
16	.6287	.3239	.5144	.5906		.3239	.381
17	.5335	.3239	.5335	.5906		.3048	.362
18	.381	.3429	.4572	.4763	.3048	.3048	.362
19	.4382	.4191	.4572	.5144	.362	.4191	.5335
20	.4572	.4763	.4763	.5716	.362	.4954	.5335
21	.4954	.5144	.4763	.5906	.4572	.5144	.5335
22	.5716	.5335	.5906	.6097		.5335	.5716
23	.5144	.5525	.5906	.6097	.4572	.5335	.5716
24	.7049	.5716	.5525	.5716	.5716	.4572	.5335
Max	.7049	.5716	.5906	.6478	.743	.6001	.5716
Min	.3048	.2477	.2858	.362	.3048	.2286	.2477
Avg	.4628	.4199	.4596	.543	.5284	.3791	.4104

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

DHAMANGAON SUB-DN.[299] BU 2992

Substation No/ Name :- 034005 / 33 KV MANGRUL SUB STN

Feeder No / Name : 203 / 11 KV KHANAPUR AG AG Feeder with SDT  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3336	.381	.0191				
2		.362	.0191				
3		.362	.0191				
4		.3429	.0191				
5		.362	.0191				
6		.3239		.0953			
7		.3048		.1334			
8		.3239	.0381	.1334			
9	.1905		.0572	.6097			
10	.3429	.362	.1524	.5144	1.0479		
11	.4191	.4572		.5335	1.086	.0191	.0381
12	.9145	.4763			1.0288	.0343	.0381
13	1.0288	.4382		.8764	.9717		.0381
14	1.086	.381		.9145			.0762
15	1.1431	.4763		.9335			
16	1.2193	.2667		.9335			
17	1.3527			.9145			.0953
18	.8764			.8764		.0381	.0343
19	.7049			.8002			
20				.7621			
23	.381						
24	1.3717	.381					
Max	1.3717	.4763	.1524	.9335	1.086	.0381	.0953
Min	.1905	.2667	.0191	.0953	.9717	.0191	.0343
Avg	.8832	.3751	.0429	.6451	1.0336	.0305	.0534

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

DHAMANGAON SUB-DN.[299] BU 2992

Substation No/ Name :- 034005 / 33 KV MANGRUL SUB STN

Feeder No / Name : 204 / 11 KV DIGHI

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.4382	.4191	.4191	.381	.3429	.3429
2		.4382	.4001	.4191	.381	.3429	.3429
3		.4382	.381	.4191	.3429	.3429	.3239
4		.4191	.381	.4191	.3429	.3429	.3239
5		.4001	.362	.4001	.3429	.3429	.3239
6		.2858	.3429	.381	.3239	.3239	.3239
7		.2667	.3239	.362	.3239	.2477	.3048
8		.2667	.3239	.3429	.3429	.2477	.2858
9	.1715	.3048	.3239	.3429	.362	.2286	.2477
10	.2667	.3048	.2858	.2858	.2667	.1905	.2096
11	.3239	.3429	.381	.3429	.2858	.1715	.2096
12	.3429	.2858	.3429		.362	.2572	.1905
13	.3048	.2858	.3239	.381	.362	.2096	.2286
14	.4001	.2858	.362	.4001		.2096	.2286
15	.4001	.3239	.4001	.4191		.2096	.2286
16	.4382	.3239	.4191	.3048	.1905	.1905	.2286
17	.362	.2667	.2096	.2667	.2096	.2286	.1905
18	.3239	.3239	.3239	.2572	.2096	.2858	.2858
19	.2477	.381	.4382		.2667	.3429	.3429
20	.2096	.4382	.4954	.4287	.3429	.381	.4191
21	.3048	.4763	.4763	.5906	.3429	.4001	.4572
22	.4191	.4954	.4572	.5335		.362	.4382
23	.4763	.4382	.4191	.4191	.3429	.3429	.4191
24	.5144	.4382	.4191	.4191	.381	.3429	.3429
Max	.5144	.4954	.4954	.5906	.381	.4001	.4572
Min	.1715	.2667	.2096	.2572	.1905	.1715	.1905
Avg	.3519	.3612	.3755	.3888	.3193	.2870	.3016

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

DHAMANGAON SUB-DN.[299] BU 2992

Substation No/ Name :- 034005 / 33 KV MANGRUL SUB STN

Feeder No / Name : 205 / 11 KV NIMBOLI AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.1905		.0953
2					.1905		.0953
3					.1905		.0953
4					.2096		.0762
5					.2286		.0381
6					.2286		.0191
7					.3239		.0572
8					.4001		.0572
9					.362		.0953
10	.0953	.0953	.1143	.2667			
11	.1524	.0762	.1334	.381			
12	.1524	.1715	.1334	.381		.0343	
13	.1715	.1524	.1143	.2667			
14	.2286	.0953	.1334	.2858			
15	.1524	.0953	.1334	.2858			
16	.2477	.0762	.1715	.3239			
17	.2858	.0572	.1524	.3239			
18						.0572	
19						.0572	
20						.0381	
21						.1143	
22						.1143	
23						.0953	
24					.1905	.0572	.0953
Max	.2858	.1715	.1715	.381	.4001	.1143	.0953
Min	.0953	.0572	.1143	.2667	.1905	.0343	.0191
Avg	.1858	.1024	.1358	.3144	.2515	.0710	.0724



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

DHAMANGAON SUB-DN.[299] BU 2992

Substation No/ Name :- 034005 / 33 KV MANGRUL SUB STN

Feeder No / Name : 206 / 11 KV ZADGAON FEEDER

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.3048	.4191	.2096	.1334
2		.1715	.3048	.381	.1905	.1334
3		.1715	.3048	.381	.1905	.1334
4		.1715	.3048	.362	.1905	.1524
5		.1524	.2858	.3429	.1905	.1524
6		.1524	.2858	.3048	.1715	.1715
7		.1334	.2286	.3048	.1334	.1524
8		.1524	.3429	.2477	.1524	.1334
9		.1524	.4382	.2477	.1524	.1524
10		.1715	.4763	.3048	.1334	.1524
11		.1524	.5144	.3048	.1905	.1524
12		.1715	.5716	.2858	.4287	.1524
13		.1905	.6097	.1905	.1715	.1905
14		.2096	.6287		.1715	.1905
15		.2477	.6287		.1524	.1905
16	.1524	.2477	.5335	.1715	.1524	.1715
17	.1334	.3048	.5335	.1524	.1524	.1334
18	.1334	.3429	.5525	.1715	.1524	.1715
19	.1715	.3239	.5335	.1905	.2667	.2096
20	.1905	.362	.5335	.1905	.1524	.2286
21	.1905	.362	.4954	.2096	.1334	.2477
22	.1905	.3429	.4763		.1334	.2477
23	.1905	.3239	.4572	.2096	.1334	.2477
24		.1905	.3048	.4191	.2096	.1334
Max	.1905	.362	.6287	.4191	.4287	.2477
Min	.1334	.1334	.2286	.1524	.1334	.1334
Avg	.1691	.2239	.4438	.2758	.1798	.1723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

DHAMANGAON SUB-DN.[299] BU 2992

Substation No/ Name :- 034026 / 33 KV DEOGAON

Feeder No / Name : 201 / Dhamangaon 11 KV

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372		.0457	.0514	.1029	.0457	.0762
2			.0457	.0514	.1029	.0514	.0762
3			.0457	.0514	.1029	.0686	.0762
4			.0457	.0514	.1029	.0514	.061
5			.0457	.0343	.1029	.0457	.061
6			.0457	.0343	.0914	.0514	.061
7			.0457	.0343	.1219	.0514	.061
8	.0343		.0457		.1219	.0457	.0343
9	.0857		.0457	.1715	.1219		.0457
10	.0343	.061	.0305	.2572	.4287		.0457
11	.2439	.0857	.0343	.3086	.4877		.0914
12	.4287	.0857	.0343	.3086	.4877		.1029
13	.3658	.0762	.0343	.3086	.3048		.1029
14	.442	.0762	.0343	.0857		.0457	.0914
15	.5792	.0457	.0343	.3086		.0457	.12
16	.5639	.0762	.0857	.3086		.0457	.0914
17	.7164	.061	.0686	.3086		.0457	.0914
18	.0914	.061	.0514	.3086		.0343	.0514
19		.0914	.0514	.2743		.061	.061
20		.0457	.1029	.2229		.0857	.0914
21		.0457	.1029	.0857		.0762	.0914
22		.0457	.1029	.0857		.0762	.0914
23		.0457	.1029	.12	.0514	.0762	.1029
24	.1715		.0457	.1029	.12	.0762	.0762
Max	.7164	.0914	.1029	.3086	.4877	.0857	.12
Min	.0343	.0457	.0305	.0343	.0514	.0343	.0343
Avg	.2996	.0645	.0553	.1685	.1901	.0568	.0773

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

DHAMANGAON SUB-DN.[299] BU 2992

Substation No/ Name :- 034026 / 33 KV DEOGAON

Feeder No / Name : 202 / 11 KV TALEGAON

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	.1372	.6687	.9145	.9526	.6516	.5487
2		.1715	.6859	.9145	.9335	.6516	.5487
3		.2743	.6687	.9145	.9145	.6516	.5487
4		.3429		.9145	.8764	.6173	.5487
5		.4458		.7621	.8002	.583	.5316
6		.3944	.0857	.6478	.6478	.4801	.4115
7		.3258	.4287	.5144	.5487	.4115	.3601
8	.0953	.3086	.3601	.4191	.4458	.3772	.3048
9	.5716	.2915	.4115	.4382	.4115	.3772	.3772
10	.5716	.3258	.4115	.4763	.4458	.3772	.3772
11	.5144	.3086	.5144	.5335	.4115	.3429	.3086
12	.5487	.0686	.5525	.5335	.4287	.3429	.3258
13	.6173	.1029	.6478	.5525	.4287	.3429	.3601
14	.703	.0686	.6478	.5716		.3601	.4115
15	.7202	.0686	.6859	.5716		.4287	.4458
16	.4287	.3429	.6287	.5906	.3429	.5316	.3772
17	.6173	.5487	.6097	.6097	.3944	.4287	.3772
18	.5144	.4973	.4382	.5716	.4287	.4115	.4287
19		.5144	.6287	.5716	.5316	.4458	.5487
20		.6859	.8573	.8573	.6859	.6173	.7373
21		.7202	.9145	.9145	.7202	.6173	.7888
22	.1372	.6687	.9907	.9907	.7373	.6516	.823
23	.1372	.703	.9907	1.0098	.6859	.6344	.8192
24	1.0288	.1372	.6516	.9526	.9907	.6859	.583
Max	1.0288	.7202	.9907	1.0098	.9907	.6859	.823
Min	.0953	.0686	.0857	.4191	.3429	.3429	.3048
Avg	.5464	.3522	.6127	.6978	.6256	.5008	.4955

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

DHAMANGAON SUB-DN.[299] BU 2992

Substation No/ Name :- 034026 / 33 KV DEOGAON

Feeder No / Name : 203 / 11 kv Borgaon

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3772	.3429	.3429	.3429	.1886	.3258
2	.3239	.3772	.3429	.3429	.3429	.1886	.3258
3	.3239	.3772	.3258	.3429	.3429	.1715	.3258
4		.3772	.3086	.3429	.3429		.3258
5	.3239	.3429	.2915	.3048	.3048		.2572
6	.3048	.2743	.2743	.2286	.2477		.2401
7	.2286	.2229	.2058	.2667	.1372	.2058	.2229
8	.1905	.1715	.1886	.1905	.1372	.2229	.1067
9	.1715	.1886	.2058	.1905	.1372	.1886	.0514
10	.1886	.1886	.2058	.2286	.3086	.2572	.0514
11	.1886	.2229	.2286	.3048	.0857	.1886	.1029
12	.1372	.2401	.2096	.2667	.1372	.1372	.0857
13	.2401	.2058	.1905	.2667	.1543	.1029	.1029
14	.2915	.1715	.1905	.2286		.1372	.0857
15	.3258	.1886	.2096	.2286	.1715	.2058	.1029
16	.3258	.1886	.2286	.2096	.1029	.1372	.1029
17	.2743	.1543	.2286	.1905	.1886	.1372	.1029
18	.2401	.12	.1143	.1905	.2058	.2401	.1029
19		.1715	.2286	.2667	.3601	.3086	.1543
20	.2743	.3944	.3429	.3429	.3601	.3772	.2058
21	.3086	.3772	.3429	.381	.3601	.3772	.2058
22	.4115	.3944	.3429	.3429	.3772	.3601	.2058
23	.3772	.3944	.3429	.3239	.3429	.3429	.381
24	.381	.3772	.3772	.3239	.3429	.3429	.3429
Max	.4115	.3944	.3772	.381	.3772	.3772	.381
Min	.1372	.12	.1143	.1905	.0857	.1029	.0514
Avg	.2807	.2708	.2612	.2770	.2536	.2294	.1882

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

DHAMANGAON SUB-DN.[299] BU 2992

Substation No/ Name :- 034026 / 33 KV DEOGAON

Feeder No / Name : 204 / 11KV TALEGAON AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0171			.0152	
2		.0171	.0171		.0171	
3		.0171	.0171		.0152	
4		.0171	.0171		.0171	
5		.0171	.0171		.0171	
6		.0171	.0171		.0171	
7		.0171			.0171	
8		.0171	.0171		.0171	
9		.0171				
10		.0171		.0171		
11	.0171	.0171		.0171		
12	.0171	.0171		.0171		.0171
13	.0171	.0171		.0171		.0171
14	.0171	.0171		.0171	.0152	.0171
15	.0171	.0171		.0171		.0171
16	.0171	.0171		.0171		.0171
17	.0171	.0171		.0171		.0171
18	.0171	.0171				.0171
19	.0171					.0152
20	.0171					.0152
21	.0171	.0171				.0152
22	.0171	.0171				.0152
23	.0171			.0171		
24		.0171			.0171	
Max	.0171	.0171	.0171	.0171	.0171	.0171
Min	.0171	.0171	.0171	.0171	.0152	.0152
Avg	.0171	.0171	.0171	.0171	.0165	.0164

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

DHAMANGAON SUB-DN.[299] BU 2992

Substation No/ Name :- 034035 / 33 KV ANJANSINGHI

Feeder No / Name : 201 / 11 KV ANJANSIGI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6668	.6097	.4572	.4382	.4382	.4191	.4572
2	.6478	.6097	.4572	.4382	.4382	.4191	.4572
3	.6097		.4191	.4382	.381	.4191	.4191
4	.6097		.4191	.4191	.381	.381	.4191
5	.5716		.381	.4191	.3048	.3239	.4191
6	.5335		.3239	.381	.3048	.3048	.3048
7	.5716		.3048	.3429	.2858	.2286	.2858
8	.4954	.1524	.2858	.2667	.3048	.2286	.2477
9		.3048	.2667	.2286	.3048	.2286	.2477
10	.4001	.3944	.2858	.2667	.3429	.2667	.2858
11	.381		.3048	.2286	.3429	.2667	.3429
12	.4001		.3048	.3429	.3239	.4191	.362
13	.4191		.3429	.362	.381	.381	.381
14		.6097	.3429	.4572		.2058	.3239
15	.6173	.5716	.362	.4572		.3048	.3048
16	.9335		.3429	.3429		.2858	.2667
17	.7049		.2286	.2858	.3048	.2667	.2477
18	.6859		.2286	.3048	.2667	.2858	.2477
19	.6097	.381	.2667	.3429	.4287	.2667	.2667
20	.6097	.4572	.2858	.381	.3429	.381	.2858
21	.6097	.4763	.4191	.4572	.4191	.4191	.2858
22	.6097	.4763	.4763	.4572	.4191	.4191	.3429
23	.6097	.4572	.4763	.4382	.4191	.4191	.362
24	.6668	.6097	.4572	.4572	.4382	.4191	.4382
Max	.9335	.6097	.4763	.4572	.4382	.4191	.4572
Min	.381	.1524	.2286	.2286	.2667	.2058	.2477
Avg	.5892	.47	.3516	.3731	.3606	.3316	.3334

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

DHAMANGAON SUB-DN.[299] BU 2992

Substation No/ Name :- 034035 / 33 KV ANJANSINGHI

Feeder No / Name : 202 / 11 kv Dhakulgaon

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	.6478	.5716	.5906	.6097	.6478	.6668
2		.3048	.5716	.5716	.6097	.6097	.6478
3		.3048	.5335	.5716	.6097	.6097	.6478
4		.3048	.4954	.5335	.5716	.5716	.5716
5	.9145	.3048	.4572	.4954	.4954	.5335	.9602
6	.8573	.3048	.4191	.4001	.4572	.4191	.4763
7	.6668	.1524	.3048	.3429	.4191	.381	.4191
8		.1524	.3048	.362	.4001	.1905	.381
9	.8573	.4572	.3048	.4191	.3048	.3429	.3429
10	.9526	.4572	.3429	.4572	.4382	.3429	.362
11	.6097	.4763	.4382	.4954	.4763	.381	.362
12	.6859		.4382	.4191	.4572	.4191	.4382
13	.6668		.4382	.4382	.5335	.4572	.4191
14		.4001	.4572	.7049		.4382	.381
15	1.2003	.4001	.4572	.724		.4572	.4191
16	1.1812		.4763	.5716	.4572	.4572	.381
17	1.2384		.381	.4572		.4191	.3429
18	.7621	.3239	.381		.1334	.4382	.3239
19	.7621	.4572	.3048	.3429	.381	.4191	.4954
20	.6859	.5335		.5716	.5335	.5716	.6097
21	.7621	.5716		.7621	.6668	.6478	.6668
22	.7049	.6097		.7621	.6859	.7049	.724
23	.6859	.6097	.5716	.6859	.6478	.7049	.743
24	1.1431	.6478	.5906	.6097	.6097	.6478	.6668
Max	1.2384	.6478	.5906	.7621	.6859	.7049	.9602
Min	.6097	.1524	.3048	.3429	.1334	.1905	.3239
Avg	.8573	.4210	.44	.5343	.4999	.4922	.5187

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

DHAMANGAON SUB-DN.[299] BU 2992

Substation No/ Name :- 034035 / 33 KV ANJANSINGHI

Feeder No / Name : 203 / 11kv pimpalkhuta

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.4191	.2858	.3048	.3429	.3048	.3239
2			.2858	.3048	.3429	.3048	.3239
3	.4287		.2667	.2667	.3048	.3048	.3601
4	.3944		.2286	.2667	.3048	.2858	.3048
5			.2286	.2477	.2667	.2667	.2858
6			.1905	.2286	.2286	.2286	.2858
7		.2096	.1334	.2286	.1905	.1905	.3048
8	.1905	.1905	.1524	.1905	.1715	.1715	.3048
9	.3048	.2096	.1524	.1905	.1905	.1524	.3239
10	.4191	.2286	.2286	.2096	.2096	.1905	.3429
11	.4382	.2286	.2286	.2286		.2477	.2858
12	.4572	.1905		.2667		.2096	.2286
13	.4954	.2286	.2477	.2858		.2096	.2477
14		.2286	.2667	.2667		.1905	
15	.4763	.2096	.2667	.2667	.1905	.2286	.2096
16	.4954	.4287	.2477	.2667	.2286	.2096	.2667
17	.5716	.1905	.1905	.2096	.2286	.1905	.2858
18	.4382	.1905	.1905	.1715	.2286	.1905	.2858
19	.4001	.2096	.2858	.2096	.2667	.2286	.2477
20	.4191	.2667	.3048	.2477	.3429	.2858	.3429
21	.381	.2858	.2858	.362	.3239	.3239	.381
22	.4001	.3048	.2858	.381	.3239	.3239	.381
23	.4382	.3048	.3048	.3429	.3239	.3048	.381
24	.4954	.4191	.2858	.3048	.3429	.3048	.3048
Max	.5716	.4287	.3048	.381	.3429	.3239	.381
Min	.1905	.1905	.1334	.1715	.1715	.1524	.2096
Avg	.4304	.2602	.2410	.2604	.2677	.2437	.3047



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

DHAMANGAON SUB-DN.[299] BU 2992

Substation No/ Name :- 034035 / 33 KV ANJANSINGHI

Feeder No / Name : 204 / 11KV DURGAWADA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.3048	.1905	.2096	.2096	.1524	.1715
2	.381	.1524	.1905	.2096	.2096	.1524	.1715
3	.3429	.1524	.1905	.1905	.2096	.1524	.1715
4	.3429	.1524	.1715	.1905	.2096	.1334	.1524
5	.3429	.1524	.1715	.1715	.1905	.1334	.1524
6	.381	.1524	.1715	.1524	.1715	.1334	.1524
7	.362	.1143	.1334	.1334	.1334	.1143	.1524
8	.4191	.0762	.0953	.1143	.1143	.1143	.1524
9	.4572	.2058	.0953	.1143	.1524	.1143	.1334
10	.5335		.0762	.1524	.2286	.1334	.1905
11	.5335		.2286	.1143	.2858	.1334	.1905
12	.5144		.381	.1524	.2858	.1334	.1715
13	.5335		.3429	.1334	.3429	.2286	.2096
14			.3048	.1524		.2477	.2286
15	.4954		.3048	.1524		.2286	.3429
16	.5335		.2667	.1334		.1905	.1905
17	.381		.1905	.1143	.1715	.1905	.1905
18	.3048		.1715	.1143	.1715	.1905	.1905
19	.3429	.1715	.1905	.1524	.1715	.1715	.1905
20	.381	.1905	.2286	.1905	.1715	.1715	.2096
21	.3086	.2096	.2286	.2096	.1715	.1715	.2096
22	.2058	.2096	.2096	.2096	.3601	.1715	.1905
23	.3048	.2096	.2096	.2096	.1905	.1715	.1905
24	.4382	.3048	.1905	.2096	.2096	.1715	.1905
Max	.5335	.3048	.381	.2096	.3601	.2477	.3429
Min	.2058	.0762	.0762	.1143	.1143	.1143	.1334
Avg	.4026	.1839	.2056	.1619	.2077	.1627	.1873

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

DHAMANGAON SUB-DN.[299] BU 2992

Substation No/ Name :- 034035 / 33 KV ANJANSINGHI

Feeder No / Name : 205 / 11 kv Express feeder water HV Group Express Feeder  
wor Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.0953	.1143	.1143	.1143	.1143	.1143
2	.1143	.0953	.1143	.1143	.1143	.1143	.1143
3	.1143	.0953	.1143	.1143	.1143	.1143	.1143
4	.1143	.0953	.1143	.1143	.1143	.1143	.1143
5	.1143	.0953	.1143	.1143	.1143	.1143	.1143
6	.1143	.0953	.1143	.1143	.1143	.1143	.1143
7	.1143	.0953	.1143	.1143	.1143	.1143	.1143
8	.1143	.0953	.1143	.1143	.1143	.1143	.1143
9	.1143	.0953	.1143	.1143	.1143	.1143	.1143
10	.1143	.1143	.0343	.1143	.1143	.1143	.1143
11	.1143	.1143	.1143	.1143	.1143	.1143	.1143
12	.1143	.1143	.0343	.1143	.1143	.1143	.1143
13	.1143	.1143	.1143	.0343	.1143	.1143	.1143
14	.1143	.1143	.1143	.1143		.1143	.1143
15	.1143	.1143	.1143	.1143	.1143	.1143	.1143
16	.1143	.1143	.1143	.1143	.1143	.1143	.1143
17	.1143	.1143	.1143	.1143	.1143	.1143	.1143
18	.1143	.1143			.1143		.1143
22	.0953		.1143	.1143	.1143	.1143	.1143
23	.0953	.1143	.1143	.1143	.1143	.1143	.0343
24	.1143	.0953	.1143	.1143	.1143	.1143	.1143
Max	.1143	.1143	.1143	.1143	.1143	.1143	.1143
Min	.0953	.0953	.0343	.0343	.1143	.1143	.0343
Avg	.1125	.1048	.1063	.1103	.1143	.1143	.1105

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

DHAMANGAON SUB-DN.[299] BU 2992

Substation No/ Name :- 034064 / 33 KV OLD DMN SUB STN

Feeder No / Name : 201 / 11 KV WAGHOLI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3125	.3429	.2713	.2949	.3005	.1509	.1509
2	.2915	.3429	.2713	.2949	.3005	.1509	.1509
3	.2591	.3429	.2683	.2949	.3005	.1509	.1509
4	.2591	.3429	.2683	.2949	.3005	.1509	.1341
5	.2267	.3258	.2515	.2785	.2688	.1509	.1341
6	.2214	.2058	.1823	.2105	.2321	.1509	.1341
7	.1739	.1509	.1219	.1457	.1543	.1509	
8	.1635	.1341	.1219	.128	.1389		
9	.1429	.1638	.1219		.1524		
10	.1252	.1698	.1372		.1372		
11	.2921	.1389	.1219	.1429	.2743		
12	.3338	.1355	.1235	.176	.2408		
13	.306	.1337	.1265	.1593	.2591		.1235
14			.1326	.2143	.1829		
15	.3715	.1311	.1423	.2	.1372		
16	.3666	.1296	.144	.2			
17	.3666	.1265		.1593		.1389	
18	.4371	.1219		.132		.1219	
19	.192	.1581	.1326	.2012		.1296	.1423
20	.2256	.2486	.1658	.285	.1341	.1658	.1823
21	.3185	.2652	.3077	.2896	.1543	.1475	.1823
22	.3353	.285	.3361	.3321		.1875	.1844
23	.3353	.3018	.3201	.3163	.4287	.1802	.2984
24	.3121	.3185	.2683	.3077	.3163	.1509	.1475
Max	.4371	.3429	.3361	.3321	.4287	.1875	.2984
Min	.1252	.1219	.1219	.128	.1341	.1219	.1235
Avg	.2769	.2181	.1972	.2299	.2323	.1519	.1627

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

DHAMANGAON SUB-DN.[299] BU 2992

Substation No/ Name :- 034064 / 33 KV OLD DMN SUB STN

Feeder No / Name : 202 / 11 KV DMN OLD

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9061	.8573	.6783	.7701	.7907	.6706	.5868
2	.7773	.8573	.6783	.7701	.7748	.6539	.5868
3	.7773	.8402	.6706	.7373	.7748	.6371	.5868
4	.7287	.7545	.6706	.7209	.7432	.6371	.5868
5	.7287	.7373	.6539	.7045	.6958	.6203	.5868
6	.664	.583	.5304	.5992	.6299	.57	.503
7	.5535	.503	.4268	.4858	.5093	.4578	.4534
8	.3864	.4359	.4268	.4321	.5247		.4218
9	.4287	.5571	.4572	.506	.6554	.5992	.3353
10	.612	.4784	.4572	.4287	.5639		.4458
11	.7093	.6327	.5944	.4715	.5639	.4428	.3749
12	.7371	.587	.5401	.7188	.5418	.4161	
13	.7928	.3864	.5535	.6661	.5792	.3841	.5093
14			.5801	.743	.5182	.421	.5201
15	.8002	.3932	.68	.7573	.4877	.4801	.5864
16	.8459	.4049	.6562	.7002	.4572	.4214	.6401
17	.8741	.4111	.4801	.5792	.4862	.463	.6636
18	.7895	.4877	.4167	.4841	.503	.3506	.5182
19	.5761	.5218	.547	.5868	.6068	.4534	.5218
20	.6062	.663	.6962	.7545	.6706	.6962	.7459
21	.8048	.7127	.7449	.7468	.7373	.7701	.779
22	.8383	.7545	.7842	.7748		.6718	.8383
23	.8718	.7545	.7522	.7748		.6554	.8122
24	.8916	.8383	.7209	.7773	.7907	.6706	.5898
Max	.9061	.8573	.7842	.7773	.7907	.7701	.8383
Min	.3864	.3864	.4167	.4287	.4572	.3506	.3353
Avg	.7261	.6153	.5999	.6537	.6184	.5519	.5736

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

DHAMANGAON SUB-DN.[299] BU 2992

Substation No/ Name :- 034064 / 33 KV OLD DMN SUB STN

Feeder No / Name : 203 / 11 KV VIRUL

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3906	.2401	.2035	.3932	.3479	.2515	.2012
2		.2401	.2035	.3932	.3163	.2515	.2012
3		.2401	.2012	.3932	.3163	.2515	.2012
4			.2012	.3768	.3163	.2347	.2012
5			.1844	.3605	.2846	.2347	.2012
6			.1326	.2267	.1823	.2012	.1509
7			.1219	.1457	.108	.1696	.1134
8			.1219	.096	.0926	.1311	.125
9			.1219	.1265	.1219	.1296	.1219
10		.0309	.1372	.2286	.1219		
11	.4868		.1372	.2429	.1981	.1423	
12	.5007	.2408	.1698	.3227	.301	.128	
13	.5007		.1898	.2317	.1372	.2561	
14			.1658	.2286	.1067	.2429	
15			.1581	.3144	.0457	.176	.1852
16		.0162	.16	.3144	.0305	.1806	.2134
17		.1739	.16	.2462	.0335	.1852	.2006
18	.3666	.1677	.1852	.176	.0335	.1677	.1524
19	.3704	.2056	.2155	.1844	.0347	.1619	.1581
20	.282	.2321	.2155	.218	.2515	.2155	.2155
21	.2683	.2486	.3887	.381	.1886	.2294	.2321
22	.218	.2515	.4001	.3795		.2031	.2347
23	.2515	.218	.4001	.3637	.4287	.213	.3978
24	.3864	.2347	.218	.3887	.3637	.2683	.1966
Max	.5007	.2515	.4001	.3932	.4287	.2683	.3978
Min	.218	.0162	.1219	.096	.0305	.128	.1134
Avg	.3656	.1957	.1997	.2805	.1896	.2011	.1949

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

DHAMANGAON SUB-DN.[299] BU 2992

Substation No/ Name :- 034064 / 33 KV OLD DMN SUB STN

Feeder No / Name : 204 / 11 KV DABHADA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.1086	.056	.168	.1417	.0554	.0914
2		.1086	.056	.168	.1417	.0554	.0914
3	.0747	.1086	.056	.168	.1417	.0554	.0914
4	.0747	.1086	.056	.1494	.1417	.0554	.0914
5	.0747	.0867	.056	.1494	.1417	.0554	.0914
6	.056	.052	.056	.0934	.0829	.037	.0549
7	.056	.0514	.056	.056	.0492	.037	.0537
8	.0373	.0514	.056	.056	.0686	.0373	.0543
9	.0362	.0514	.056	.056	.061	.0351	.0358
10	.0503		.056	.056	.0671		.0526
11	.3311				.2134	.0354	.0509
12	.3864	.1067	.2427		.1806	.0339	.0514
13	.3715	.108	.052		.1829	.0328	.0532
14		.108	.0895	.1875	.1829	.0339	.0532
15	.3429	.0509	.0693	.1718		.0526	.0532
16	.3086		.0686	.1718		.0514	.0532
17	.3666		.064	.1593	.052	.0339	.0514
18	.3913	.0343	.0514	.132	.0503	.0509	.0503
19		.0377	.0532	.0867	.052	.0532	.0924
20	.0857	.0566	.0914	.1214	.0503	.0886	.1307
21	.1006	.056	.1494	.1417	.056	.1086	.1494
22	.1063	.056	.168	.1417		.0905	.1494
23	.1063	.056	.168	.1417	.4287	.0905	.1494
24	.1402	.1063	.056	.168	.1417	.056	.0914
Max	.3913	.1086	.2427	.1875	.4287	.1086	.1494
Min	.0362	.0343	.0514	.056	.0492	.0328	.0358
Avg	.1735	.0752	.0819	.1307	.1251	.0537	.0787

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

DHAMANGAON SUB-DN.[299] BU 2992

Substation No/ Name :- 034064 / 33 KV OLD DMN SUB STN

Feeder No / Name : 205 / 11 kv Express feeder water HV Group Express Feeder  
wor Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0328	.036	.0356	.036	.0316	.0352	.0335
2		.036	.0356	.036	.0332	.0352	.0335
3	.0324		.0352	.036	.0332	.0352	.0335
4	.0324		.0352		.0332	.0352	.0335
5	.034	.036	.0352	.0328	.0332	.0352	.0335
6	.034	.0348	.0365	.0324	.0348	.0335	.0352
7	.0332	.0369	.032	.034	.0324	.0335	.0356
8	.0312	.0369	.032		.034		.0312
9			.0305	.0332	.0335	.034	.0335
10	.0292	.0324	.0305	.03	.032		.0312
11	.0292	.0324	.032	.0314	.032		.0328
12	.0278	.0316		.0308	.0301	.0332	.0279
13	.0278	.0327	.0348	.0304	.032	.0336	.0293
14			.0365	.03	.032	.034	.0282
15		.0343	.0348	.03	.032	.0336	.034
16	.031	.0343	.0336	.0286			.0335
17		.0343			.0352		.034
18		.0343					
22						.0312	
23	.0369	.0335	.0336	.0332	.0343	.0328	.0348
24	.0312	.0369	.0352	.0324	.0316	.0352	.0328
Max	.0369	.0369	.0365	.036	.0352	.0352	.0356
Min	.0278	.0316	.0305	.0286	.0301	.0312	.0279
Avg	.0317	.0346	.0340	.0323	.0328	.0340	.0327

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

DHAMANGAON SUB-DN.[299] BU 2992

Substation No/ Name :- 034068 / 33 KV SUB STATION NARGAWANDI

Feeder No / Name : 201 / Mangrul 11 KV

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1063	.0537	.0537	.0709	.0895	.0537	.0537
2		.0537	.0537	.0709	.0895	.0537	.0537
3	.0532	.0537	.0537	.0709	.0895	.0537	.0537
4	.0532	.0537	.0537	.0709	.0895	.0537	.0537
5	.0532	.0537	.0537	.0709	.0716	.0537	.0537
6	.0532	.0537	.0537	.0709	.0716	.0537	.052
7	.0532	.0716	.0716	.0709	.0716	.0716	.0537
8	.0532	.0716	.1075	.0709	.0716	.0716	.1075
9	.0532	.0537	.1075	.0709	.0716	.0716	.1075
10	.0532	.0716	.1075	.0709	.0716	.0537	.1075
11	.0716	.0716	.1063	.0895	.0716	.052	.1063
12	.0716	.0716	.1063	.0716	.0895	.0716	.0532
13	.0716	.0716	.1417	.0716	.0537	.0716	.0532
14	.0716	.052	.0532	.0716		.0716	.0709
15	.0537	.0716	.0532	.0716	.0537	.0716	.0709
16	.0716	.0716	.0886	.0716	.0537	.0716	.0709
17	.0716	.0716	.0709	.0895	.0537	.0716	.0709
18	.0537	.0716	.0709	.0716	.0537	.0716	.0709
19	.0537	.0716	.1063	.0716	.0537	.0716	.0354
20	.0537	.0537	.0886	.0895	.0716	.0716	.0354
21	.0537	.0537	.0886	.0716	.0716	.0716	.0354
22	.0537	.0537	.0886	.0895	.0716		.0354
23	.0537	.0537	.0886	.0895	.0537	.0716	.0709
24	.124	.0537	.0537	.0709	.0895	.0537	.0537
Max	.124	.0716	.1417	.0895	.0895	.0716	.1075
Min	.0532	.052	.0532	.0709	.0537	.052	.0354
Avg	.0635	.0618	.0801	.0750	.0708	.0645	.0638



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

DHAMANGAON SUB-DN.[299] BU 2992

Substation No/ Name :- 034068 / 33 KV SUB STATION NARGAWANDI

Feeder No / Name : 202 / Dhamangon Town 11 KV Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5606	2.2314	1.8656	2.0485	2.1948	1.6278	1.7558
2	2.524	2.1948	1.829	2.0119	2.1216	1.6095	1.6827
3	2.268	2.1948	1.7558	1.9753	2.0485	1.6787	1.0288
4	1.9022	2.1582	1.6827	1.829	1.9753	1.5546	1.6461
5	1.8839	1.9022	1.6095	1.7375	1.8656	1.5546	1.6095
6	1.829	1.7193	1.4632	1.7375	1.7558	1.4632	1.5729
7	1.6095	1.4998	1.3535	1.4266	1.6461	1.3169	1.4266
8	1.5729	1.4266	1.5364	1.5364	1.4632	1.2071	1.4266
9	1.6095	1.39	1.4632	1.4632	1.39	1.2803	1.4266
10	1.5546	1.3717	1.4998	1.5364	1.4998	1.2803	1.4632
11	1.7193	1.5364	1.4998	1.6095	1.6461	1.2803	1.2803
12	1.7375	1.5364	1.4632	1.6827	1.7193	1.2437	1.3169
13	2.0485	1.6461	1.5546	1.7193	1.7193	1.2437	1.39
14	2.1948	1.4998	1.7741	1.8656		1.2437	1.5729
15	2.3411	1.4266	1.829	1.829	.439	1.2437	1.6095
16	2.3411	1.3169	1.7924	1.7193	1.39	1.3169	1.5729
17	2.1582	1.2437	1.6461	1.7375	1.3717	1.39	1.6095
18	1.7558	1.3169	1.5364	.0377	1.3535	1.39	1.5364
19	1.8473	1.4266	1.7193	1.829	1.5546	1.6095	1.7193
20	1.8656	1.7193	1.9204	1.9753	1.6461	1.9387	1.9753
21	1.9387	1.6827	1.9022	2.0119	1.7375	1.9387	2.0302
22	2.268	1.829	2.0302	2.1948	1.829		2.1216
23	2.3777	1.9387	2.1948	2.3045	1.829	1.9022	2.0851
24	2.5972	2.3045	1.9022	2.1033	2.268	1.6827	1.829
Max	2.5972	2.3045	2.1948	2.3045	2.268	1.9387	2.1216
Min	1.5546	1.2437	1.3535	.0377	.439	1.2071	1.0288
Avg	2.0210	1.6880	1.7010	1.7467	1.6723	1.4781	1.6120

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

DHAMANGAON SUB-DN.[299] BU 2992

Substation No/ Name :- 034068 / 33 KV SUB STATION NARGAWANDI

Feeder No / Name : 203 / Chincholi 11 KV

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6935	.4508	.4458	.5201	.5201	.3988	.4458
2		.4334	.4115	.5201	.4854	.3988	.4115
3		.4508	.463	.5201	.4854	.3467	.4115
4			.3772	.5201	.4854	.3467	.3772
5			.3429	.4508	.4508	.3814	.3772
6			.3429	.3814	.4334		.3429
7	.3467	.2774	.2401	.3121	.4508		.2401
8	.4161	.2601	.2401	.2774	.3121	.0347	.1715
9	.4854	.2229	.2401	.3121	.3121	.0693	.1715
10	.5201	.2572	.2058	.3772	.5548		.2058
11	.5201	.2743	.2401	.4334	.6935		.2427
12	.5375	.2743	.2572	.4854	.5548		.2774
13	.5548	.3429	.2743	.4854	.5201		.2254
14	.6415		.3086	.5895			.3121
15	.6241	.1029	.3429	.5548			.2774
16	.6241	.2572	.3601	.5895		.0514	.2774
17		.2572	.3086	.5201		.3772	
18	.5201	.3086	.3086	.4854		.4458	.2774
19	.4854	.3429	.3814	.4854		.4801	.3814
20		.4458	.5201	.5895		.4801	.4508
21		.4801	.5548	.5548	.3641	.5144	.4681
22	.3988	.5601	.5721	.5895	.4508	.5144	.4681
23	.4508	.4801	.5548	.5548	.4854	.4801	.4681
24	.7282	.4508	.4458	.5201	.5201	.4508	.4458
Max	.7282	.5601	.5721	.5895	.6935	.5144	.4681
Min	.3467	.1029	.2058	.2774	.3121	.0347	.1715
Avg	.5342	.3465	.3641	.4845	.4752	.3607	.3360

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

DHAMANGAON SUB-DN.[299] BU 2992

Substation No/ Name :- 034068 / 33 KV SUB STATION NARGAWANDI

Feeder No / Name : 204 / Talegaon 11 KV

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6104	.407	.3391	.3772	.3391	.3052	.3391
2		.407	.3391	.3772	.3391	.3052	.3052
3	.4748		.3052	.3772	.3391	.3052	.2713
4	.4409		.2713	.3772	.3391	.2883	.2713
5	.407		.2713	.3429	.3222	.2543	.2374
6	.3561		.2713	.2743	.3052	.2374	.2374
7	.2515	.2035	.1696	.2058	.3391	.1696	.1526
8	.2515	.2204	.1696	.2058	.373	.1865	.1696
9	.3018	.2035	.2035	.2401	.4748	.2035	.1696
10	.3688	.2035	.2035	.3052	.5087		.1696
11	.4409	.2035	.2035	.4409	.4409	.1526	.1357
12	.373	.6001	.2035	.4409	.6104	.1696	.1187
13	.39	.2374	.2713	.4748	.6001	.1017	.1357
14	.2035	.2035	.2713	.5087	.4748	.1017	.1865
15	.4409	.2035	.3052	.5087		.1357	.2035
16	.4748	.2035	.3052	.5087	.1865	.1357	.1696
17		.2713	.2035	.4409	.1865	.1357	.1696
18	.3391	.2204	.2035	.3391	.1696	.2204	.1696
19	.39	.2035	.2713	.3391		.2713	.2713
20	.39	.3391	.407	.407		.373	.373
21	.39	.3391	.4409	.373	.3391	.3391	.373
22	.4239	.373	.373	.4409	.373	.3391	.373
23	.4239	.3391	.373	.373	.3561	.3391	.373
24	.6104	.407	.3391	.3772	.373	.3391	.3391
Max	.6104	.6001	.4409	.5087	.6104	.373	.373
Min	.2035	.2035	.1696	.2058	.1696	.1017	.1187
Avg	.3979	.2894	.2798	.3773	.3709	.2352	.2381

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

DHAMANGAON SUB-DN.[299] BU 2992

Substation No/ Name :- 034068 / 33 KV SUB STATION NARGAWANDI

Feeder No / Name : 205 / Jawahar Sootgirni Feeder HV Express Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.448	1.6787	1.4712	1.4335	1.4712	1.3014	1.358
2	1.4289	1.6975	1.5089	1.4335	1.5278	1.3203	1.3957
3	1.448	1.7164	1.4335	1.4146	1.5089	1.358	1.3203
4	1.4289	1.6598	1.3957	1.4901	1.4712	1.3957	1.2826
5	1.448	1.6221	1.4712	1.4712	1.4901	1.3957	1.358
6	1.5432	1.5278	1.4335	1.3014	1.5089	1.4523	1.3203
7	1.5242	1.4523	1.3203	1.3957	1.4712	1.226	1.358
8	1.4098	1.4146	1.3203	1.6598	1.5089	.8676	1.4523
9	1.2574	1.4712	1.2071	1.2449	1.1694	1.1694	1.5089
10	1.1431	1.4712	1.3203	1.5278	1.5089	1.2826	1.1317
11	1.2071	1.3203	1.358	1.358	1.5466	1.226	1.4815
12	1.3769	1.358	1.4523	1.4335	1.3392	1.2826	1.2826
13	1.3203	1.3957	1.4335	1.4712	1.4146	1.3203	1.4712
14	1.4335	1.3203	1.4335	1.5466	1.3203	1.2449	1.5466
15	1.4901	1.2826	1.2826	1.5089	1.1506	1.358	1.4146
16	1.2071	1.3203	1.4523	1.4146	1.3203	1.3203	1.4632
17		1.3203	1.6598	1.4523	1.4523	1.358	1.3014
18	1.1694	1.5278	1.1694	1.4335	1.3203	1.3769	1.5655
19	1.4146	1.5089	1.4712	1.4335	1.3769	1.1694	1.5089
20	1.3957	1.3769	1.6598	1.4146	1.4146	1.3392	1.5278
21	1.4901	1.5655	1.3957	1.5089	1.4335	1.3203	1.4146
22	1.4712	1.3957	1.6409	1.5089	1.3769		1.2071
23	1.2826	1.4335	1.3014	1.4712	1.358	1.3203	1.5844
24	1.4335	1.6598	1.3957	1.3957	1.5089	1.3203	1.358
Max	1.5432	1.7164	1.6598	1.6598	1.5466	1.4523	1.5844
Min	1.1431	1.2826	1.1694	1.2449	1.1506	.8676	1.1317
Avg	1.3814	1.4791	1.4162	1.4468	1.4154	1.2924	1.4006

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

DHAMANGAON SUB-DN.[299] BU 2992

Substation No/ Name :- 034068 / 33 KV SUB STATION NARGAWANDI

Feeder No / Name : 206 / MIDC Dhamangaon Rly

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1063	.0886	.0532	.0709	.1063	.0532	.0532
2	.1063	.1063	.0532	.0709	.1063	.0532	.0532
3	.1063	.0709	.0532	.0709	.1063	.0532	.0532
4	.0886	.0709	.0532	.0709	.1063	.0709	.0532
5	.0709	.1063	.0532	.0709	.1063	.0709	.0532
6	.0709	.1063	.0532	.0709	.1063	.0354	.0532
7	.0709	.0354	.0709	.1063	.1417	.0709	.0532
8	.1063	.0532	.1063	.0886	.1772	.0709	.1063
9	.2126	.0532	.1063	.1063	.1417	.0709	.1417
10	.2126	.0709	.0709	.124	.1417	.0709	.1595
11	.1949	.0709	.1417	.124	.1417	.0886	.1772
12	.2126	.0709	.1417	.124	.0532	.0532	.1772
13	.1949	.1075	.0709	.124	.1063	.0532	.1772
14	.1949	.0857	.1063	.0886	.1063	.0537	
15	.2481	.0532	.1063	.1063	.1417	.0532	
16	.2481	.0354	.0886	.0886	.0886	.0532	
17	.2481	.0354	.1063	.0886	.0886	.0532	.0354
18	.1417	.0532	.1063	.0886	.0709	.0532	.0532
19	.0886	.0709	.124	.1063	.0709	.0532	.0709
20	.1063	.0709	.0886	.1063	.0886	.0532	.0709
21	.1063	.0709	.0886	.1063	.1063	.0532	.0709
22	.1063	.0709	.0886	.1097	.0709		.0709
23	.0886	.0709	.0886	.1063	.1063	.0532	.0709
24	.1063	.1063	.0532	.0709	.1063	.0709	.0532
Max	.2481	.1075	.1417	.124	.1772	.0886	.1772
Min	.0709	.0354	.0532	.0709	.0532	.0354	.0354
Avg	.1432	.0723	.0864	.0954	.1078	.0594	.0861

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

NANDGAON KH SUB-DN[302] BU 1686

Substation No/ Name :- 034028 / 33 KV. NANDGAON KH. SUB STN.

Feeder No / Name : 201 / 11 KV TOWN FEEDER

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.448	1.1222	1.1584	1.3336	1.267	1.1812	1.0136
2	1.3336	1.1222	1.086	1.3336	1.267	1.1431	.9774
3	1.2193	1.086	1.086	1.3336	1.2308	1.1431	.9774
4	1.1431	1.086	1.086	1.2955	1.2308	1.105	.9774
5	1.105	1.086	1.086	1.1431	1.1584	1.105	.9774
6	.9526	.8688	.905	.9907	1.086	.8764	.8326
7	.724	.724	.724	.9526	1.0498	.7621	.724
8	.7621	.724	.5792	.9526	1.0136	.6859	.6878
9	.8383	.7602	.6878	.9907	1.0136		.724
10	.8326	.7602	.8326	.9526	.9145		.7964
11	.9412	.7964	1.0669	.9412	.8002	.8383	.724
12	.9412	.7602	1.1431	1.0136	.8383		.6516
13	1.086	.7964	1.1812	1.0498	.8383		.8688
14	1.1584	.9412	.9526	1.1584	.9526	.6878	.9774
15	1.1222	.9774	.9526	1.1584	.9145	.724	.9412
16	1.086	.8326	.9907	1.1222	.9145	.724	.7964
17		.905	.9526	.9412	.8383	.7602	.7602
18		.9412	.9907	.9412	.9145	.6878	.8326
19		.9774	1.2193	1.0136	.9907	.9412	.9774
20		1.1584	1.4861	1.086	1.1431	1.0498	1.1584
21		1.267	1.448	1.1222	1.1812	1.1222	1.1946
22		1.3032	1.4098	1.1946	1.1812	1.086	1.2308
23	1.1584	1.3032	1.4098	1.267	1.1812	1.086	1.1946
24	1.448	1.1222	1.267	1.3336	1.3032	1.1431	1.0136
Max	1.448	1.3032	1.4861	1.3336	1.3032	1.1812	1.2308
Min	.724	.724	.5792	.9412	.8002	.6859	.6516
Avg	1.0722	.9759	1.0709	1.1092	1.0510	.9426	.9171

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

NANDGAON KH SUB-DN[302] BU 1686

Substation No/ Name :- 034028 / 33 KV. NANDGAON KH. SUB STN.

Feeder No / Name : 202 / 11 KV SHIVANI

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0625	.08	.0343	.1875		.032
2	.0343	.0625	.032	.0381	.1875		.032
3	.0343	.0625	.032	.0381	.1875		.032
4		.0625	.032	.0377	.1875		.032
5	.0343	.0625	.032	.0343	.1943		.032
6	.0381	.0625	.032	.0381	.2267		.064
7	.0343	.0625	.032	.0343	.3563		.096
8	.0343	.0625	.032	.0343	.3749		.064
9	.0343	.0625	.032	.0381	.3437		.192
10	.1875	.1562	.192	.3429	.0171		.032
11	.2187	.2561	.3086	.3749	.0171		.0297
12		.2241	.3429	.3749	.0171		.0286
13	.1875	.2241	.3429	.3563	.0171		.0137
14	.1562	.2534	.2743	.3437	.0191	.032	.0143
15	.25	.2241	.3086	.3563	.0171	.032	.0143
16	.3125	.192	.2401	.3437	.0171	.032	.0297
17		.192	.3048	.3125	.0171	.032	.0312
18		.032	.0381	.0312	.0171	.032	.0143
19		.032	.0343	.0312	.0171	.032	.0143
20		.032	.0343	.0312	.0171	.032	.0143
21		.032	.0343	.0312		.032	.0143
22		.032	.0343	.0312	.0343	.032	.0143
23	.0625	.032	.0343	.0312	.0343	.032	.0149
24	.0343	.0625	.032	.0343	.1875	.0686	.032
Max	.3125	.2561	.3429	.3749	.3749	.0686	.192
Min	.0343	.032	.032	.0312	.0171	.032	.0137
Avg	.1055	.1058	.1205	.1398	.1170	.0353	.0370

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

NANDGAON KH SUB-DN[302] BU 1686

Substation No/ Name :- 034028 / 33 KV. NANDGAON KH. SUB STN.

Feeder No / Name : 203 / 11 kV Rampur Feeder

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.0328
2							.0328
3							.0328
4							.0328
5							.0328
6							.0328
7					.0648		.0328
8					.2267		.0328
9					.1875		.0655
10		.0972	.1311	.0381	.2401		
11	.0324	.1638	.2058	.3437	.2401		
12	.2591	.2294	.2401	.2812	.2401		
13	.2187	.2622	.2058	.2915	.2401		
14	.1296	.2622	.2058	.2187	.2286		
15	.1875	.2622		.25	.1715		
16	.1875	.1966	.0762	.2812			
17		.1966	.2743	.2812			
18			.2401			.0655	
19			.2401			.0328	
20			.1372			.0328	
21						.0328	
22						.0328	
23						.0328	
24							.0328
Max	.2591	.2622	.2743	.3437	.2401	.0655	.0655
Min	.0324	.0972	.0762	.0381	.0648	.0328	.0328
Avg	.1691	.2088	.1957	.2482	.2044	.0383	.0361



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

NANDGAON KH SUB-DN[302] BU 1686

Substation No/ Name :- 034028 / 33 KV. NANDGAON KH. SUB STN.

Feeder No / Name : 204 / SHIONI GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4382	.3734	.3772	.4191	.4527	.4191	.415
2	.4191	.3734	.3772	.4191	.4115	.4191	.415
3	.381	.3734	.3772	.4191	.4527	.4191	.415
4	.381	.3734	.3772	.381	.4481	.4191	.415
5	.381	.3734	.3772	.3429	.4481	.4191	.415
6	.3429	.2987	.2263	.2286	.3361	.3429	.3018
7	.1524	.1494	.1886	.1524	.1867	.1524	.1509
8	.1524	.112	.1886	.1524	.1867	.1524	.1448
9	.2286	.1867	.2896	.3048	.3258		.3018
10	.2614	.1867	.2534	.2286	.3429		.3018
11	.2987	.3018	.2286	.3361	.3429	.2667	.2987
12	.2987	.3395	.2667	.3361	.3429		.2987
13	.2987	.3395	.3048	.4108	.3429		.2987
14	.2987	.3772	.3048	.3734	.2667	.3018	.3361
15	.3734	.362	.3048	.3734	.2286	.3018	.3361
16	.3734	.3258	.2286	.3734	.2286	.3395	.2987
17	.2987	.2641	.2286	.2987	.2286	.3018	.3361
18	.2614	.2263	.1905	.1867	.2286	.2641	.3361
19	.2241	.2641	.1905	.2241	.2667	.2263	.2614
20	.2896	.3018	.3048	.2987	.2667	.3018	.3361
21	.3734	.415	.4191	.4481	.4191	.4527	.4481
22	.4108	.415	.381	.4481	.4191	.4527	.3982
23	.4108	.415	.4191	.4854	.4191	.3772	.4108
24	.4191	.3734	.3772	.4191	.4481	.4191	.415
Max	.4382	.415	.4191	.4854	.4527	.4527	.4481
Min	.1524	.112	.1886	.1524	.1867	.1524	.1448
Avg	.3236	.3134	.2992	.3358	.3350	.3374	.3369

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

NANDGAON KH SUB-DN[302] BU 1686

Substation No/ Name :- 034028 / 33 KV. NANDGAON KH. SUB STN.

Feeder No / Name : 205 / Shirpur Goathan

Goathan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.1086	.1086	.1143	.0362	.0762	.0724
2	.0762	.1086	.1086	.1143	.0362	.0762	.0724
3	.0762	.112	.1086	.1143	.0362	.0762	.0724
4	.0381	.1086	.1086	.0762	.0362	.0762	.0724
5	.0381	.1086	.1086	.0762	.0362	.0762	.0724
6	.0381	.0905	.0724	.0762	.0362	.0762	.0724
7	.0762	.0724	.0724	.0762	.0724	.1143	.0724
8	.0381	.0724	.0724	.0762	.0762	.1143	.1086
9	.0762	.0724	.0724	.0762	.0762		.0724
10	.0362	.0724	.0724	.0762	.0762		.0724
11	.0362	.0724	.0762	.0724	.0762	.0381	.0724
12	.0312	.0724	.1143	.0724	.0762		.0724
13	.0724	.0724	.1143	.1086	.0762		.0724
14	.0724	.0724	.0381	.1086	.0762	.0362	.0724
15	.0724	.0724		.1086	.1143	.0362	.0724
16	.0724	.0724	.0381	.0724		.0362	.0724
17		.0362	.0381	.0724		.0362	.0724
18		.0724	.0381	.0724	.0381	.0362	.0724
19		.0724	.0381		.0381	.0362	.1086
20	.0724	.1086	.0762	.0362		.1086	.1086
21	.0724	.1086	.1143	.0362	.1143	.1086	.0724
22	.1086	.1086	.1143	.0362	.0762	.1086	.0724
23	.1086	.1086	.1143	.0362	.0762	.1086	.0724
24	.0762	.1086	.1086	.0762	.0362	.0762	.0724
Max	.1086	.112	.1143	.1143	.1143	.1143	.1086
Min	.0312	.0362	.0381	.0362	.0362	.0362	.0724
Avg	.0650	.0869	.0838	.0776	.0627	.0726	.0769

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

NANDGAON KH SUB-DN[302] BU 1686

Substation No/ Name :- 034028 / 33 KV. NANDGAON KH. SUB STN.

Feeder No / Name : 206 / Mokhad Ag feeder

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143		.081	.2477	.0181		.0648
2	.0381		.081	.2477	.0181		.0648
3			.081	.2477	.0181		.0648
4			.081	.2286	.0175		.0648
5			.081	.2286	.0175		.0648
6			.0972	.2477	.0175		.0324
7			.1296	.3048	.0181		.0324
8			.1619	.362	.0543		.0324
9			.2591	.381	.0543		.0324
10			.0486	.1524	.0572		.1781
11		.0324	.1524	.1086	.4191	.0953	.2534
12	.1619	.0486	.1524		.4572		.2103
13	.2915	.0486	.1524		.4572		.2279
14	.2591	.0486	.1143	.0724	.381	.0754	.2454
15	.2267	.0486	.1715	.1267	.381	.0972	.2804
16	.2591	.0486	.0762	.1406	.381	.1134	.298
17	.2591	.0377	.0762	.0724		.1134	.3281
18	.3149	.0648	.0762			.1296	.0701
19	.2427	.1296	.0762			.132	.0469
20		.0972	.1143			.0324	.0469
21		.0486	.1143	.0181		.0324	.0526
22		.0486	.1143	.0162		.0324	.0526
23		.0486	.1143	.0162		.0324	.0526
24	.1143		.081	.2477	.0175		.0324
Max	.3149	.1296	.2591	.381	.4572	.132	.3281
Min	.0381	.0324	.0486	.0162	.0175	.0324	.0324
Avg	.2074	.0577	.1120	.1825	.1638	.0805	.1179

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

NANDGAON KH SUB-DN[302] BU 1686

Substation No/ Name :- 034028 / 33 KV. NANDGAON KH. SUB STN.

Feeder No / Name : 207 / 11KV DHANORA FEEDER Ag dominated/Pure Ag  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.25		.5144			
2	.6859	.25		.5716			
3				.5144			
4				.5144			
5				.5144			
6				.6173			
7	.1372		.1341	.8916			
8	.2743		.2683	1.0288			
9	.5487	.6249	.8048	1.166			
10	.4687	.7499	.5365				.6036
11		.8048	.6859		.4115	.3429	.7499
12		.8048	.9259		.6173		.6249
13	.5624	.8048	.8573		.7545		.7499
14	.7125	.8048	.8573		.8916	.2683	.6874
15	.7499	.8048	.9526		.7545	.2683	.6249
16	.6874		.9526			.4024	.6874
17	.7499		1.1431			.4024	.5624
18						.3353	
19						.3353	
24	.6173	.25		.5487			
Max	.7499	.8048	1.1431	1.166	.8916	.4024	.7499
Min	.1372	.25	.1341	.5144	.4115	.2683	.5624
Avg	.5676	.6149	.7380	.6882	.6859	.3364	.6613

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

NANDGAON KH SUB-DN[302] BU 1686

Substation No/ Name :- 034030 / 33 KV PAPAL SUB-STATION

Feeder No / Name : 201 / 11 KV PAPAL FEEDER

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4191	.4763	.1334	.381		.3239
2	.4572	.4191	.4191	.1524	.381		.3239
3		.4191	.381	.1334	.381		.3239
4	.4954	.4572	.3429	.1715	.4001		.3239
5	.4954	.4954	.3048	.1524	.4382		.3239
6	.5335	.4954	.362	.1715	.4763		.3239
7	.7811	.0191	.2667	.6287	.743		.381
8	.6859	.0191	.5144	1.0479	.8383		.6859
9	.5906	.0381	.8764	.7621	.7621		.743
10		1.2193	1.2384	1.467	.0191	.2286	.381
11	.6668	1.2955	1.5813	1.4289	.0191	.1715	.4382
12	.9526	.8383	.8573	.724	.4572	.2096	.3239
13	.8383	.5906	.7621	.7811		.2286	.3239
14	.724	.743	.724	.8383	.4763	.4572	.3429
15	.6859	.6097	.7621	.8192		.5144	.362
16	.6668	.6478	.7621	.7621		.5716	.362
17	.7621	.7811	.8383	.6859	.381	.3429	.4382
18	.0381	.0191	.0381		.3429	.0572	.1143
19		.0572	.0572	.0191	.2477	.0572	.1334
20	.0381	.0572	.0191	.0191	.0572	.0572	.1334
21	.0381	.0572	.0381	.0191	.0572	.0572	.1334
22	.1143	.0572		.0191	.0572	.0953	.1334
23	.0953	.0381	.0381	.0191	.0572	.0953	.1334
24	.4572	.381	.4572	.1143	.362	.0191	.2858
Max	.9526	1.2955	1.5813	1.467	.8383	.5716	.743
Min	.0381	.0191	.0191	.0191	.0191	.0191	.1143
Avg	.5035	.4239	.5268	.4813	.3493	.2109	.3247

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

NANDGAON KH SUB-DN[302] BU 1686

Substation No/ Name :- 034030 / 33 KV PAPAL SUB-STATION

Feeder No / Name : 203 / 11 KV PIMPALGAON FEEDER

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0762	.0762	.0572	.0762	.0572	.0762
2	.0381	.0762	.0572	.0381	.0762	.0572	.0762
3		.0762	.0572	.0191	.0762	.0572	.0572
4		.0762	.0381	.0191	.0762	.0572	.0572
5		.0762	.0572	.0381	.0762	.0572	.0572
6		.0762	.0572	.0381	.0572	.0572	.0572
7		.0762	.0572	.0381	.0572	.0572	.0381
8		.0762	.0381	.0381	.0572	.0191	.0381
9		.0953	.0381	.0381	.0381	.0381	.0381
10		.0572	.0191	.0191	.0381	.0191	.0381
11		.0191	.0191	.0191	.0381	.0191	.0381
12		.0381	.0381	.0381	.0381	.0381	.0381
13	.0762		.0191	.0572		.0381	.0381
14	.0762	.0191	.0191	.0572	.0381	.0572	.0381
15	.0762	.0191	.0191	.0572	.0381	.0381	.0572
16	.0762	.0191	.0381	.0572	.0381	.0381	.0381
17	.0572	.0191	.0191	.0381	.0381	.0381	.0191
18	.0572	.0381	.0191	.0381	.0381	.0191	.0381
19		.0381	.0381	.0572	.0381	.0191	.0572
20		.0762	.0572	.0762	.0572	.0762	.0572
21		.0762	.0381	.0762	.0572	.0762	.0762
22	.0762	.0762	.0381	.0762	.0762	.0762	.0762
23	.0762	.0762	.0381	.0762	.0381	.0762	.0762
24	.0762	.0762	.0762	.0572	.0762	.0381	.0762
Max	.0762	.0953	.0762	.0762	.0762	.0762	.0762
Min	.0381	.0191	.0191	.0191	.0381	.0191	.0191
Avg	.0676	.0588	.0405	.0469	.0538	.0469	.0524

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

NANDGAON KH SUB-DN[302] BU 1686

Substation No/ Name :- 034030 / 33 KV PAPAL SUB-STATION

Feeder No / Name : 204 / papad gaathan feeder

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.4382	.4191	.4191	.4191	.4382	.4001
2	.4001	.4191	.381	.381	.4191	.4191	.4001
3		.4191	.4191	.362	.4191	.4191	.381
4	.381	.4191	.3429	.3239	.381	.4191	.381
5	.381	.381	.3239	.3048	.3429	.381	.381
6	.4001	.3429	.3048	.3429	.3239	.3239	.3239
7	.3239	.3048	.3048	.3048	.2286	.3048	.3048
8	.2667	.2858	.2477	.2667	.2477	.2667	.2477
9	.2858	.2477	.3048	.2858	.2667	.2667	.2858
10		.2286	.3239	.2858	.2286	.2477	.2477
11	.3239	.2477	.3239	.3048	.2286	.2477	.2096
12	.3239	.2858	.3239	.3048	.1905	.2286	.2096
13	.381	.3048	.3429	.3429		.2096	.2286
14	.381	.3429	.3048	.362	.3048	.2096	.2667
15	.3239	.3429	.2667	.362	.2858	.1905	.2667
16	.3239	.3239	.2858	.3429	.4572	.2096	.2477
17	.3048	.2477	.2858	.3239	.3239	.2477	.2096
18	.2858	.2667	.3048	.3048	.3048	.2096	.2477
19	.2667	.3239	.2667	.381	.362	.3048	.3048
20	.4382	.4382	.4382	.4763	.4382	.4191	.4191
21	.4572	.4763	.4572	.4572	.4572	.4001	.4382
22	.4954	.4954	.4763	.4763	.4572	.4191	.4763
23	.4763	.4954	.4572	.4572	.4382	.4191	.4382
24	.4572	.4382	.4572	.4382	.4382	.4382	.4001
Max	.4954	.4954	.4763	.4763	.4572	.4382	.4763
Min	.2667	.2286	.2477	.2667	.1905	.1905	.2096
Avg	.3680	.3548	.3485	.3588	.3462	.3183	.3215

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

NANDGAON KH SUB-DN[302] BU 1686

Substation No/ Name :- 034030 / 33 KV PAPAL SUB-STATION

Feeder No / Name : 205 / 11KV Kajana Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6668	.7049	.6668	.6859	.8383	.743	.6859
2	.6287	.7049	.7049	.6097	.8383	.743	.6859
3		.7049	.4191	.5716	.8192		.6478
4		.6859	.2286	.6287	.8192		.6478
5		.5716	.1524	.5716	.7621		.6097
6		.4572	.1715	.6097	.6287		.6097
7		.3239	.1334	.4572	.4572	.1524	.4572
8	.1524	.2477	.1143	.4763	.4954	.1143	.4191
9	.1524	.2477	.4382	.4572	.4382	.1143	.4382
10			.4191	.4954	.4382	.381	.4191
11	.3048	.0953	.1334	.4763	.5144	.3239	.362
12	.6287	.362	.3429	.5716	.5335	.381	.4001
13	.6668	.381	.6859	.6287		.381	.4191
14	.6859	.4382	.6478	.6668	.381	.381	.4382
15	.6668	.4191	.6097	.6478	.3048	.4001	.4572
16	.6097	.0953	.6287	.5716	.4572	.362	.4191
17	.5335	.5525	.5525	.4572	.0953	.4382	.4001
18	.4382	.5525	.5335	.362	.3239	.4572	.4001
19		.6097	.5525	.6097	.5525	.5335	.6287
20	.4191	.743	.7811	.724	.6287	.724	.7621
21	.6287	.7621	.8002	.8573	.7049	.7621	.8002
22	.6859	.7621	.8002	.8383	.743	.724	.8192
23	.7049	.743	.7811	.8383	.743	.724	.7811
24	.724	.724	.7049	.7621	.8383	.743	.6859
Max	.724	.7621	.8002	.8573	.8383	.7621	.8192
Min	.1524	.0953	.1143	.362	.0953	.1143	.362
Avg	.5469	.5169	.5001	.6073	.5807	.4792	.5581



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

NANDGAON KH SUB-DN[302] BU 1686

Substation No/ Name :- 034058 / 33/11 s/s MANGRUL CHAWHALA

Feeder No / Name : 201 / Mangrul Chawhala

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.4001	.4191	.4191	.4572		.381
2	.3429	.4001	.4001	.381	.4382	.1905	.362
3	.381	.381	.4001	.381	.4382	.2477	.362
4	.3429	.381	.381	.3429	.4191	.2477	.3429
5	.3048	.3429	.381	.3429	.3239	.2096	.3429
6	.2667	.3048	.2858	.3048	.3239	.2096	.3048
7	.1715	.1905	.2477	.2858	.3048	.1524	.2477
8	.2286	.2286	.2477	.2477	.3239	.2286	.2667
9	.2667	.2667	.2858	.3048	.3239	.2096	.3048
10	.2477	.2286	.3048	.381	.3239	.2667	.2667
11	.2858	.381	.3429	.4001	.3239	.2477	.2286
12	.2667	.362	.381	.4001	.3239	.2477	.2477
13	.381	.4001	.362	.4191	.3048	.2667	.2858
14	.4382	.4572	.3239	.4001	.2667	.2477	.2667
15	.4382	.4382	.2286	.381	.2858	.2477	.2477
16	.4572	.4001	.2286	.4382	.2858	.2667	.2667
17	.362	.381	.381	.4191	.3239	.2477	.2667
18	.3239	.381	.362	.4001	.2667	.3048	.3239
19		.362	.381	.381	.4001	.3429	.381
20	.2477	.4572	.5144	.4954	.4572	.4572	.4191
21	.2096	.4763	.4954	.4763	.4382	.4763	.4763
22		.4763	.4954	.4954	.4382	.4382	.4763
23	.4191	.4382	.4763	.4572	.4191	.4001	.4572
24	.4572	.4001	.4191	.4572	.4382	.381	.381
Max	.4572	.4763	.5144	.4954	.4572	.4763	.4763
Min	.1715	.1905	.2286	.2477	.2667	.1524	.2286
Avg	.3299	.3723	.3644	.3921	.3604	.2841	.3294

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

NANDGAON KH SUB-DN[302] BU 1686

Substation No/ Name :- 034058 / 33/11 s/s MANGRUL CHAWHALA

Feeder No / Name : 202 / Salod

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.5716	.5144	.4954	.4954		.4572
2	.4191	.5716	.5144	.4954	.4954		.4382
3		.5716	.4954	.4572	.4954		.4382
4		.5335	.4954	.4572	.4954		.4191
5		.5335	.4763	.4191	.4763		.4001
6		.4572	.4001	.381	.4001		.381
7		.362	.3239	.2858	.3429		.3239
8	.2286	.3048	.2858	.3048	.3429		.3048
9	.4001	.4001	.3239	.2667	.4001	.1905	.362
10	.362	.362	.3239	.3429	.381	.3239	.2477
11	.381	.362	.3048	.3048	.3429	.3239	.2667
12	.3429	.3239	.4191	.4191	.3239	.2858	.2667
13	.381	.362	.381	.362	.3239	.2858	.3048
14	.5335	.4572	.381	.381	.3239	.2667	
15	.5144	.4572	.362	.4382	.3239	.2667	.2858
16	.4382	.4001	.3048	.362	.2858	.2858	.3048
17	.362	.4382	.3429	.3429	.3239	.2858	.2858
18	.3048	.3239	.3048	.3239	.362	.3048	.3429
19	.3429		.4191	.4001	.4001	.381	.4001
20	.3429		.5144	.5335	.4954	.4763	.4954
21	.5716	.5906	.5144	.5335	.5335	.4763	.5335
22		.5906	.5525	.6478	.5144	.4763	.5335
23	.5716	.5525	.5525	.6287	.4954	.4954	.5144
24	.4954	.5716	.5335	.5144	.5906	.4763	.4572
Max	.5716	.5906	.5525	.6478	.5906	.4954	.5335
Min	.2286	.3048	.2858	.2667	.2858	.1905	.2477
Avg	.4138	.4590	.4183	.4207	.4152	.3501	.3810

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

NANDGAON KH SUB-DN[302] BU 1686

Substation No/ Name :- 034058 / 33/11 s/s MANGRUL CHAWHALA

Feeder No / Name : 203 / Veni Ganeshpur

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.2858		.0953
2					.2858		.0953
3					.2858		.1143
4					.2858		.1143
5					.381		.1143
6					.4001		.1143
7					.4572		.1334
8					.5335		.2096
9					.4572		.2667
10	.0191	.4572	.5716	.5716			
11	.3048	.4763	.5906	.6478		.0381	
12	.4763	.4382	.5144	.5716		.0953	
13	.5144	.4572	.4572	.5335		.1524	
14	.381	.381	.4572	.4763		.1524	
15	.4191	.4191	.4191	.4763		.1524	
16	.4191		.381	.4572		.1715	
17	.4191		.381	.4954			
18		.381					
19		.2858					
24					.2667	.1715	.0953
Max	.5144	.4763	.5906	.6478	.5335	.1715	.2667
Min	.0191	.2858	.381	.4572	.2667	.0381	.0953
Avg	.3691	.4120	.4715	.5287	.3639	.1334	.1353

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

TIWASA SUB-DN.[301] BU 1694

Substation No/ Name :- 034001 / 33 KV TIWASA SUB STATION

Feeder No / Name : 201 / 11 KV MOZARI - I AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7			.2286			
8			.2134			
9		.1067	.3048			
10					.1132	.1595
11				.0324	.1132	.1989
12	.1524			.6009	.1132	.0381
13				.6167	.1067	
14					.1219	.2317
15					.1372	.192
16				.1296	.1067	.2896
17				.1457	.1219	.3338
22						.1524
Max	.1524	.1067	.3048	.6167	.1372	.3338
Min	.1524	.1067	.2134	.0324	.1067	.0381
Avg	.1524	.1067	.2489	.3051	.1168	.1995

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

TIWASA SUB-DN.[301] BU 1694

Substation No/ Name :- 034001 / 33 KV TIWASA SUB STATION

Feeder No / Name : 202 / 11 KV TIWASA Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3146	1.3032	1.0498	1.0867	1.3032	.9955	.9145
2	1.3466	1.3032	1.0498	1.0517	1.3032	.9412	.8688
3	1.3112	1.3575	1.0059	1.0517	1.3032	.9593	.8688
4	1.2536		.9412	1.0166	1.3032	.9412	.8048
5	1.1517		.9145	.9922	1.2851	.905	.8048
6	1.0745		.823	.9114	1.2851	.8145	.7682
7	1.0985		.7865	.8589	1.3756	.7421	.7733
8	1.1218		.8145	.8764	1.448	.6878	.6401
9	1.0867		.823	1.0517	1.4118	.6401	.7499
10	.9922		1.2437	1.1919	1.5203	.5853	.6516
11	1.0974		1.1393	1.262	1.4022	.6219	.6878
12	1.448		.8413	1.3321	1.4022	.6584	.8063
13	1.4842		1.0867	1.448	1.2757	.6413	.8413
14	1.5203		1.0454	1.5203		.6401	.9114
15	1.4723		1.0166	1.448	.8063	.6401	.8326
16	1.4723		.9922	1.5203	.7537	.724	.8954
17	1.4373	.9328	.9214	1.4118	.7011	.6089	.8326
18	1.4022	.8962	.985	1.3756	.7712	.724	.8596
19	1.3672	.9694	1.1462	1.3672	.8505	.7964	1.0029
20	1.4899	1.1584	1.2048	1.4022	.9465	1.0608	1.1765
21	1.448	1.1946	1.1517	1.4022	.9991	1.0608	1.2308
22	1.4118	1.182	1.2178	1.4022		1.0498	1.267
23	1.3756	1.1919	1.2178	1.4118	.724	.9816	1.267
24	1.5203	1.3575	1.0608	1.1568	1.3032	1.0136	.9511
Max	1.5203	1.3575	1.2437	1.5203	1.5203	1.0608	1.267
Min	.9922	.8962	.7865	.8589	.7011	.5853	.6401
Avg	1.3208	1.1679	1.0200	1.2312	1.1579	.8097	.8920

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

TIWASA SUB-DN.[301] BU 1694

Substation No/ Name :- 034001 / 33 KV TIWASA SUB STATION

Feeder No / Name : 203 / 11 KV SATARGAON GT

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.394	.3982	.3658	.4163	.4024	.362	.3292
2	.3582	.3982	.3658	.439	.4024	.362	.3292
3	.362	.3801	.3292	.4207	.4024	.3258	.3142
4	.362	.3801	.3292	.3982	.4024	.3258	.2926
5	.3224	.362	.2926	.4024	.3982	.2896	.2218
6	.2686	.3258	.2195	.2743	.3658	.2715	.2012
7	.2534	.2896	.2012	.2195	.2195	.2172	.2012
8	.2328		.2378	.1448	.2561	.1991	.2012
9	.2149		.2195	.1629	.2743	.2195	.2743
10	.2328	.2715	.2561	.2534	.2743	.2195	.2561
11	.2926	.1829	.2658	.3077	.3258	.2033	.2195
12	.3292	.3258	.2835	.3109	.2896	.1829	.2481
13	.2926	.3292	.3189	.2926	.2353	.2378	.2454
14	.2926	.3475	.3403	.3841	.2353	.2378	.2587
15	.2896	.3292	.3582	.3658	.2353	.2561	.2801
16	.3258	.3109	.3582	.3841	.2172	.2378	.2715
17	.2896	.2926	.2715	.2926		.2378	.2715
18	.2896	.2561	.3258	.2926	.2534	.2743	.2534
19	.3439	.3109	.3582	.3292	.3077	.3292	.362
20	.3982	.4207	.4344	.4572	.362	.4207	.3801
21	.4024	.4207	.362	.4572	.3982	.3475	.4344
22	.4024	.462	.4344	.4938	.3982	.4024	.4024
23	.3841	.4251	.4525	.439	.362	.3841	.4163
24	.4344	.3982	.3658	.4344	.4024	.3982	.3547
Max	.4344	.462	.4525	.4938	.4024	.4207	.4344
Min	.2149	.1829	.2012	.1448	.2172	.1829	.2012
Avg	.3237	.3462	.3228	.3489	.3226	.2892	.2925

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

TIWASA SUB-DN.[301] BU 1694

Substation No/ Name :- 034001 / 33 KV TIWASA SUB STATION

Feeder No / Name : 204 / 11 KV VARKHED AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2896	.2149	.2343	.4191	.1086	.1578
2	.2241	.3077	.2126	.253	.4191	.1086	.1578
3	.2105	.3077	.2743	.2656	.4191	.0905	.1772
4	.2105	.3258	.2429	.2688	.4191	.0905	.1772
5	.2267	.2896	.2753	.2846	.4191	.0905	.2601
6	.2429	.2534	.2846	.2968	.5335	.0905	.2846
7	.2753	.2715	.2915	.3749	.7773		.3321
8	.2915	.2012	.3239	.3749	1.1431		.3241
9	.3077	.2743	.4024	.3749	1.1431		.4572
10	.0191	.7602	.0191	.0381	.4191		.0914
11		.7011	.0191	.1898	.3749		.1492
12	.0191	.6859	.0191	.2622			.1492
13	.0152	.9145		.3277	.3593		.1143
14	.0191	.9602		.4694			.1158
15	.0181	.9145	.3582	.6287	.1781		.1097
16	.0181	.884		.4572			.1505
17	.0181		.0381	.724	.0972		.1692
18	.0181	.1698	.0381	.0762	.0381	.0572	.0747
19	.0181	.0754	.0381	.0762	.0762	.0762	.1524
20	.0181	.0191	.0381	.1143	.0953	.0934	.1097
21		.0191	.0381	.1143	.0953	.0924	.1143
22		.0191	.0381	.1143	.0762		.1494
23		.0191	.0381	.1143	.0732	.1143	.1448
24	.2561	.2896	.1966	.2591	.3277	.1086	.1526
Max	.3077	.9602	.4024	.724	1.1431	.1143	.4572
Min	.0152	.0191	.0191	.0381	.0381	.0572	.0747
Avg	.1277	.3892	.1620	.2789	.3763	.0934	.1781

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

TIWASA SUB-DN.[301] BU 1694

Substation No/ Name :- 034001 / 33 KV TIWASA SUB STATION

Feeder No / Name : 205 / 11 KV SATARGAON AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.0724	.0953
2		.0724	.0953
3		.0724	.0953
4		.543	.0953
5		.5792	.0762
6		.6154	.0762
7		.6154	.0762
8		.5144	.0572
9		.4801	.0762
10	.6249	.2896	.7164
11	.6097	.567	.7186
12	.7316	.5611	.6958
13	.7011	.5487	.6958
14	.6097	.5121	.68
15	.7362	.381	.6249
16	.7712	.3277	.6009
17	.7011	.4858	.8002
18	.0351	.1132	.0762
19	.0526	.0943	.0953
20	.0526	.0762	
21	.0762	.0754	
22	.0762	.0943	
23	.0762	.0953	
24	.0762	.056	.0953
Max	.7712	.6154	.8002
Min	.0351	.056	.0572
Avg	.3954	.3268	.3271



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

TIWASA SUB-DN.[301] BU 1694

Substation No/ Name :- 034001 / 33 KV TIWASA SUB STATION

Feeder No / Name : 206 / 11 KV BHARWADI GT

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4527	.4668	.4294	.4481	.6413	.5853
2		.4527	.4108	.4294	.4481	.6036	.5487
3	.0943	.4338	.4108	.415	.4481	.6036	.5487
4	.1132	.415	.3734	.4294	.4481	.5658	.5121
5	.1132	.415	.3734	.4294	.4294	.5281	.5121
6	.1132	.3961	.3361	.3361	.4108	.4715	.4887
7	.1132	.3772	.3361	.3361	.3361	.4715	.4938
8	.1132	.3361	.3174	.3547	.3174	.4715	.499
9	.2241	.3361	.3361	.4108	.3361	.439	.439
10	.3547	.3772	.1829	.4108	.1867	.4207	.4572
11	.4108	.2896	.3361	.4108	.3361	.4066	.2031
12	.3734	.3475	.3174	.3547	.3734	.4024	.4024
13	.4108	.3658	.4294	.3361	.2801	.3841	.439
14	.4294	.3841	.4668	.4481		.4207	.4525
15	.3772	.3658	.4294	.3921	.2241	.4572	.4755
16	.3772	.3361	.4108	.4108	.2241	.439	.439
17	.3772	.3109	.4108	.2987	.1867	.439	.3734
18	.3772	.2743	.4294	.2987	.1867	.4854	.3696
19	.415	.3361	.4294	.3547	.4108	.5788	.4435
20	.4904	.4207	.4108	.4481	.5601	.724	.7545
21	.4904	.4435	.4481	.4481	.6348	.724	.7392
22	.4904	.4755	.4481	.4668	.6535		.8029
23	.4715	.4854	.4481	.4854	.6602	.7282	.7922
24	.5041	.4527	.4668	.4294	.4481	.6602	.5853
Max	.5041	.4854	.4668	.4854	.6602	.7282	.8029
Min	.0943	.2743	.1829	.2987	.1867	.3841	.2031
Avg	.3288	.3867	.3927	.3985	.3908	.5246	.5149

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

TIWASA SUB-DN.[301] BU 1694

Substation No/ Name :- 034002 / 33 KV KURHA SUB-STATION

Feeder No / Name : 201 / 11 KV ANJANWATI GT

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.9511	.0732	.9145	.8962	.8048	.7499
2	.9145	.9511	.8779	.9145	.8962	.8048	.7499
3	.9145	.9511	.8779	.9145	.8962	.8048	.7499
4	.7316	.9511	.8779	.9145	.8962	.8048	.7499
5	.7133	.9145	.8816	.823	.8596	.7316	.7316
6	.6767	.823	.6584	.7316	.8048	.7133	.6584
7	.6036	.6219	.6219	.6584	.6767	.6767	.6036
8	.5304	.6224	.6036	.6219	.6767	.567	.6219
9	.5973	.6036	.5487	.5611	.6722	.6219	.5973
10	.5975	.5853	.6219	.5792	.6722	.6154	.6878
11	.6535	.6979	.6154	.7095	.6908	.5792	.6722
12	.7468	.7545	.6722	.6722	.6908	.5792	.6348
13	.8402	.7316	.7095	.7842	.7095	.543	.5975
14	.8589	.7316	.7468	.7842	.6722	.5068	.5975
15	.8215	.7316	.7468	.8215	.6348	.543	.6348
16	.8215	.695	.7468	.7842	.6161	.543	.6722
17	.8589	.695	.7095	.7468	.6348	.5601	.6722
18	.7095	.7316	.8215	.7468	.6908	.6348	.6653
19	.7468	.7682	.8589	.7842	.7468	.8589	.7392
20	.9335	.9054	.9335	.8215	.7842	.8962	.8501
21		.8779	.9709	.9335	.8215	.8779	.8871
22		.8779	.9412	.9709	.8402	.8215	.9709
23	1.0082	.9145	.905	.9145	.8589	.8215	.8962
24	.9145	.9808	.8779	.9145	.8962	.8048	.7499
Max	1.0082	.9808	.9709	.9709	.8962	.8962	.9709
Min	.5304	.5853	.0732	.5611	.6161	.5068	.5973
Avg	.7776	.7945	.7458	.7926	.7598	.6965	.7142

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

TIWASA SUB-DN.[301] BU 1694

Substation No/ Name :- 034002 / 33 KV KURHA SUB-STATION

Feeder No / Name : 202 / 11 KV VARHA AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2172	.1132	.0377	.0732		.0366	.0377
2	.2172		.0377	.0732		.0366	.0377
3	.2172		.5281	.0732		.0377	.0377
4	.2172		.0377	.0732		.0377	.0377
5	.181		.0377	.1097		.0377	.0189
6	.1448		.0377	.1463		.0377	.0189
7	.2715		.0377	.1646	.0189	.0377	.0189
8	.3584		.0377	.2926	.0189	.0381	.1097
9	.2743	.0191	.0373		.0191	.0381	.0191
10	.0381	.0189	.0191		.3353		.1029
11	.0191	.0189	.0191		.503	.0191	.2012
12	.0191	.0189	.0191		.5967	.0191	.218
13	.0191	.0189	.0191		.5967	.0183	.1844
14	.0191	.0189	.0191		.5801	.0732	.1844
15	.0191	.0189	.0191		.4807	.0732	.1341
16	.0191	.0189	.0191		.3315	.0914	.0671
17	.0191		.0191		.2321	.1006	.0671
18	.0191	.0754	.0191		.0191	.0191	.0377
19	.0191	.0189	.0191		.0191	.0381	.0377
20	.0381	.0189	.0191		.0381	.0381	.0377
21	.0381	.0189	.0191		.0381	.0381	.0377
22		.0189	.0191		.0381	.0381	.0381
23	.0381	.0189	.0191		.0381	.0381	.0381
24	.2172	.1097	.0377	.0754		.0377	.0377
Max	.3584	.1132	.5281	.2926	.5967	.1006	.218
Min	.0191	.0189	.0191	.0732	.0189	.0183	.0189
Avg	.1148	.0340	.0473	.1202	.2296	.0426	.0733

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

TIWASA SUB-DN.[301] BU 1694

Substation No/ Name :- 034002 / 33 KV KURHA SUB-STATION

Feeder No / Name : 203 / 11 KV KAUDNYAPUR AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0754		.0189	.1448		.0377
2	.0377	.0754		.0189	.1448	.0377	.0377
3	.0377	.0377		.0189	.1448		.0377
4	.0377	.0377		.0189	.1448		.0377
5	.0377	.0377		.0189	.1463		.0377
6	.0377	.0377		.0183	.1646		.0377
7	.0377	.0189		.0189	.3841		.0566
8	.0377	.0189		.0189	.3475		.1829
9	.0377	.0189		.0191	.3932		.1341
10	1.4091	.2829	.1829	.218	.0381		.0381
11	1.5565	.2263	.2195	.2818	.0381		.0381
12	***	.1886	.2012	.2818	.0381	.0381	.0381
13	1.2125	.1886	.2012	.2652	.0381	.0381	.0373
14	1.1797	.2263	.1677	.2652	.0381	.0381	.0381
15	1.0159	.1886	.1989	.2347	.0381	.0381	.0381
16	1.065	.1509	.1989	.2652	.0381	.0381	.0381
17	1.1469		.1326	.2984	.0381	.0381	
18	.0381		.0381	.0381	.0381	.0381	
19	.0381		.0381	.0381	.0381	.0381	.0754
20	.0381		.0191	.0381	.0381	.0191	.0754
21			.0191	.0572	.0381	.0381	.0754
22			.0191	.056	.0381	.0381	.0381
23	.0762		.0191	.0566	.0381	.0381	.0381
24	.0377	.0754		.0189	.1448		.0377
Max	14.2547	.2829	.2195	.2984	.3932	.0381	.1829
Min	.0377	.0189	.0191	.0183	.0381	.0191	.0373
Avg	1.0640	.1109	.1183	.1076	.1122	.0366	.0548

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

TIWASA SUB-DN.[301] BU 1694

Substation No/ Name :- 034002 / 33 KV KURHA SUB-STATION

Feeder No / Name : 204 / 11 KV KURHA AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.1463	.1509	.1132	.0377	.0566	.0377
2	.0754	.1463	.1132	.1132	.0366	.0549	.0377
3	.0754	.1509	.1132	.1132	.0377	.0549	.0377
4	.0754	.1463	.1132	.1132	.0377	.0549	.0377
5	.0754	.1463	.0943	.1509	.0377	.0366	.0377
6	.0754	.1646	.0943	.181	.0366	.0366	.0377
7	.0572	.1646	.1132	.1991	.0377	.0366	.0377
8	.2263	.2012	.0754	.2534	.0377	.0377	.0377
9	.2353	.1829	.0732	.2743	.0381	.0366	.0381
10	.0381	.0189	.0381	.0191	.116	.0572	.1029
11	.0381	.0189	.0381	.0191	.1341	.0701	.1006
12	.0381	.0189	.0381	.0191		.1052	.1006
13	.0381	.0189	.0381	.0191	.1006	.0701	.0671
14	.0381	.0189	.0381	.0191	.1174	.0701	.1006
15	.0381	.0189	.0381	.0191	.1174	.0876	.1006
16	.0381	.0189	.0381	.0191	.0838	.0876	.1006
17	.0381	.0189	.0381	.0191	.0671	.1006	.1006
18	.0381	.0189	.0572	.0191	.0381	.0381	.0377
19	.0381	.0189	.0572	.0381	.0381	.0381	.0566
20	.0572	.0189	.0572	.0381	.0572	.0381	.0566
21	.0572	.0189	.0572	.0572		.0381	.056
22		.0189	.0572	.0572	.0572	.0381	.0572
23	.0572	.0189	.0572	.0566	.0572	.0381	.0572
24	.0754	.1463	.1509	.1132	.0377	.0566	.0377
Max	.2353	.2012	.1509	.2743	.1341	.1052	.1029
Min	.0381	.0189	.0381	.0191	.0366	.0366	.0377
Avg	.0695	.0775	.0725	.0852	.0618	.0558	.0613

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

TIWASA SUB-DN.[301] BU 1694

Substation No/ Name :- 034002 / 33 KV KURHA SUB-STATION

Feeder No / Name : 205 / 11 KV VARHA GT

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5121	.4938	.4715	.4572	.5121	.439	.4207
2	.5121	.4938	.4572	.4572	.5121	.439	.4207
3	.5121	.4938	.4572	.4572	.5121	.439	.4207
4	.5281	.4938	.4207	.4572	.5121	.3658	.4207
5	.3772	.439	.3772	.4207	.439	.2561	.3658
6	.3292	.3475	.3018	.3772	.2926	.2378	.3109
7	.2926	.2641	.2452	.2452	.2195	.2378	.2378
8	.2452	.2263	.2263	.2263	.1829	.2263	.2195
9	.2926	.3018	.2195	.2172	.2241	.2561	.2172
10	.2987	.2987	.2378	.2195	.2427	.2012	.1448
11	.3174	.3174	.2195		.2614	.1463	.1494
12	.2987	.3361	.2614	.3174	.3174	.1629	.1494
13	.2987	.3734	.2987	.3734	.3361	.1646	.1494
14	.3361	.3174	.3361	.3734	.3174	.1829	.2614
15	.4108	.2614	.2987	.3921	.2987	.1829	.2614
16	.2987	.2614	.2987	.3547	.2427	.1991	.2801
17	.3361	.2987	.2614	.2614	.2614	.1867	.2801
18	.3361	.2987	.3361	.2614	.2614	.2241	.2402
19	.2987	.4481	.3734	.2987	.2987	.4481	.2957
20	.4481	.4668	.5228	.4294	.3734	.4954	.4481
21		.4854	.5228	.5228		.4344	.4805
22		.5228	.5068	.5601	.4294	.4294	.5228
23	.5228	.4668	.439	.5093	.4481	.4108	.4854
24	.5281	.5093	.4572	.4572	.5121	.439	.4207
Max	.5281	.5228	.5228	.5601	.5121	.4954	.5228
Min	.2452	.2263	.2195	.2172	.1829	.1463	.1448
Avg	.3786	.3840	.3561	.3759	.3481	.3002	.3168

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

TIWASA SUB-DN.[301] BU 1694

Substation No/ Name :- 034002 / 33 KV KURHA SUB-STATION

Feeder No / Name : 206 / 11KV KAUNDANYAPUR GT  
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5121	.4527	.4755	.5304	.4207	.3841
2	.5487	.5121	.4527	.4755	.5304	.4207	.3841
3	.5487	.5121	.4527	.4755	.5304	.4207	.3841
4	.5121	.5121	.4527	.4755	.5304	.3841	.3841
5	.4572	.4572	.4527	.439	.4755	.3658	.3841
6	.3475	.3772	.4527	.3841	.439	.3292	.3658
7	.3475	.2743	.4338	.3475	.439	.2926	.3109
8	.3206	.2641	.3961	.3658	.4024	.2743	.3475
9	.4024	.3292	.439	.3801	.3734	.2926	.3258
10	.4294	.3361	.4024	.3982	.3547	.3077	.2896
11	.4481	.3547	.3982	.3361	.3174	.3258	.2801
12	.4108	.3734	.4108	.3734	.3734	.362	.2614
13	.4481	.3734	.4108	.4294	.3921	.3258	.2801
14	.4668	.4108	.4481	.4294	.3921	.3077	.2987
15	.5041	.3734	.4108	.4481	.3734	.3077	.2987
16	.4854	.3734	.3734	.4294	.3734	.298	.2987
17	.4481	.4108	.3734	.4108	.2987	.3361	
18	.3734	.3734	.4108	.4108		.3361	
19	.3734	.3734	.4481	.2987		.5228	.462
20	.5975	.4481	.4854	.5601		.5601	.4435
21		.4854	.5228	.5975		.5487	.4854
22		.4668	.543	.6348	.4294	.4481	.5228
23	.5601	.4854	.5068	.5304	.4481	.4108	.5041
24	.5487	.5121	.4527	.4755	.5304	.4207	.3841
Max	.5975	.5121	.543	.6348	.5304	.5601	.5228
Min	.3206	.2641	.3734	.2987	.2987	.2743	.2614
Avg	.4603	.4125	.4409	.4409	.4267	.3758	.3673

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

TIWASA SUB-DN.[301] BU 1694

Substation No/ Name :- 034065 / 33 KV MOZARI SUB-STATION

Feeder No / Name : 203 / 11 KV SHIVANGAON GT

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6173	.6173	.6733	.5973	.6516
2	.4801	.583	.583	.6173	.6733	.5792	.6344
3	.5144	.5658	.583	.6001	.6485	.5611	.6001
4	.4801	.5316	.5487	.5144	.5959	.543	.5658
5	.4458	.5144	.5144	.4801	.5316	.5068	.5144
6	.4287	.463	.463	.4287	.4733	.4525	.4458
7	.3258	.3429	.3772	.3772	.3366	.3544	.3258
8	.2743	.3258	.3429	.3258	.3721	.3506	.3258
9	.2915		.3086	.3429	.333	.3439	.583
10	.3086	.7716	.7888	1.1488	.3506		.2572
11	.7888		.9602	1.3847	.2835	.2915	.2572
12	.7888	.823	1.0288	.4252	.3681	.2572	.2658
13	.9088	.9088	1.0631	1.5061	.3856	.2572	.2658
14	.9774	.9602	1.1145	1.4723	.3982	.2743	.3506
15	1.0288	.9602	1.1317	1.4899	.3681	.3429	.3856
16	1.1317	.8573	1.0974	1.3847	.3681	.3086	.4382
17	1.2174	.8059	1.046	1.134	.3544	.2743	.3506
18	.2915	.4115	.3086	.3681	.3721	.2572	.4382
19	.4668	.4458	.4801	.5138	.5068	.4287	.4908
20	.6173	.583	.5144	.6485	.5973	.583	.6379
21	.6173	.6001	.6516	.631	.5959	.5658	.6379
22		.6516	.6859	.6836		.5487	.6733
23	.6516	.6516	.6516	.6836	.5847	.5487	.6556
24	1.6804	.6001	.6516	.6173	.6836	.5784	.6001
Max	1.6804	.9602	1.1317	1.5061	.6836	.5973	.6733
Min	.2743	.3258	.3086	.3258	.2835	.2572	.2572
Avg	.6689	.6361	.6880	.7665	.4719	.4263	.4730



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

TIWASA SUB-DN.[301] BU 1694

Substation No/ Name :- 034065 / 33 KV MOZARI SUB-STATION

Feeder No / Name : 205 / MALEGAON DHOTRA

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6859	1.0288	.8505	.0175	.0514
2		.3944	.7202	1.0631	.8505	.0175	.0514
3		.3772	.7202	1.0631	.8764	.0175	.0514
4		.3772	.7545	1.1145	.8764	.0175	.0514
5		.3772	.823	1.166	.9114	.0175	.0514
6		.3944	.8745	1.2517	.9816		
7		.6687	1.2689	1.406	1.2094		
8		.7716	1.3889	1.8347	1.6827		
9		.7888	1.4403	1.8176	1.7528		
10					1.5947		.8059
11					1.5592	.0514	.9774
12					1.448	.1543	.929
13					1.3321	.1715	
14	.1372				1.3321	.2229	1.0341
15					1.1919	.2401	1.0341
16						.3258	1.0517
17						.3772	1.0867
18	.0514	.12	.0857	.1052	.0175	.0514	.0701
19	.0514	.12	.0857	.0886	.0181	.0514	.0701
20		.12	.0857	.0876	.0181	.0514	.0701
21		.12	.0686	.0876	.0175	.0514	.0701
22		.1029	.0686	.0876		.0514	.0709
23	.0514	.12	.0686	.0876	.0175	.0514	.0701
24	.1029	.4115	.6859	1.0288	.7888	.0175	.0514
Max	.1372	.7888	1.4403	1.8347	1.7528	.3772	1.0867
Min	.0514	.1029	.0686	.0876	.0175	.0175	.0514
Avg	.0789	.3509	.6141	.8324	.9203	.1030	.4026

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

TIWASA SUB-DN.[301] BU 1694

Substation No/ Name :- 034065 / 33 KV MOZARI SUB-STATION

Feeder No / Name : 206 / DASTEKADI GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1145	1.0802	.9945	1.0867	.8939	.8573
2		1.1145	1.0802	.9945	1.0867	.8939	.8573
3	.8916	1.0974	1.0288	.9602	1.0985	.8764	.823
4	.9945	1.0631	.9945	.8573	1.0166	.8764	.7888
5	.9602	.8573	.9602	.7716	.9955	.8063	.7716
6	.8573	.7373	.7888	.6859	.7362	.7186	.7202
7	.6001	.6344	.6516	.6001	.6836	.631	.5487
8	.5316	.583	.6516	.5144	.4908	.5959	.583
9	.6001	.5658	.583	.6173	.929	.5959	.6001
10	.6173	.6173	.6001	.6344	.5959		.583
11	.703		.6344	.7186	.6485	.5316	.5144
12	.7373	.7202	.6859	.7888	.7186	.4973	.5609
13	.823	.7716	.7202	.8238	.7186	.5144	.5784
14	.9088	.823	.7716		.6836	.5658	.7087
15	.9602	.8059	.7373	.8238	.6836	.6344	.7796
16	.8573	.7716	.7202	.7888	.6485	.6173	.8063
17	.7373	.6516	.6344	.6379	.6556	.5487	.6836
18	.6516	.6173	.7202	.6485	.6024	.5316	.7362
19	.7202	.6859	.7716	.8328	.6836	.7202	.8238
20	.9431	.9259	.7888	.9816	.8688	.9259	.964
21		.9088	1.0802	1.0517	.8939	.9431	1.0631
22		1.0802	1.046	1.1393		.9259	1.1043
23	1.1488	1.1145	.9945	1.1393	.9465	.9259	1.1218
24	1.2003	1.1317	1.1145	.9945	1.1393	.929	.8916
Max	1.2003	1.1317	1.1145	1.1393	1.1393	.9431	1.1218
Min	.5316	.5658	.583	.5144	.4908	.4973	.5144
Avg	.8222	.8432	.8266	.8261	.8092	.7261	.7696

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

TIWASA SUB-DN.[301] BU 1694

Substation No/ Name :- 034085 / 33 KV WARKHED SUB-STATION

Feeder No / Name : 201 / 11 KV NIMBHORA AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.314	.314	.2187	.157		
2	.314	.314	.2187	.157		
3	.3297	.314	.6562	.157		
4	.3297	.2512	.1875	.1413		
5	.3454	.2512	.2187	.1413		
6	.314	.2512	.2031	.157		
7	.3768	.3297	.2812	.1413		
8	.4239	.3925	.2812	.157		
9	.3611	.3925	.3281	.157		
10					.314	
11						.0314
12						.0942
13					.2826	.0785
14						.0785
15						.0942
16						.0942
17						.1099
24	.314	.314	.2187	.1727		
Max	.4239	.3925	.6562	.1727	.314	.1099
Min	.314	.2512	.1875	.1413	.2826	.0314
Avg	.3423	.3124	.2812	.1539	.2983	.0830

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

TIWASA SUB-DN.[301] BU 1694

Substation No/ Name :- 034085 / 33 KV WARKHED SUB-STATION

Feeder No / Name : 202 / 11 KV DHAMANTRI AG Ag dominated/Pure Ag  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4641	.3249	.216	.1238		
2	.4641	.3249	.216	.1238		
3	.4486	.3094	.1852			
4	.4486	.263	.1852	.1083		
5	.4486	.263	.216	.1083		
6	.4332	.263	.2315	.1083		
7	.3403	.3868	.3086	.0774		
8	.3713	.4177	.3086	.0619		
9	.4022	.4796	.2778	.0464		
10					.2475	
11					.2939	
12						.0619
13						.0619
14						.0464
15						.0464
16						.0464
17						.0155
24	.4641	.3249	.216	.1392		
Max	.4641	.4796	.3086	.1392	.2939	.0619
Min	.3403	.263	.1852	.0464	.2475	.0155
Avg	.4285	.3357	.2361	.0997	.2707	.0464

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI CONSTRUCTION DN[622]

TIWASA SUB-DN.[301] BU 1694

Substation No/ Name :- 034085 / 33 KV WARKHED SUB-STATION

Feeder No / Name : 203 / 11KV BHARASAWADI GT FEEDER

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	26-JUN-17
HR	Load (MW)
9	.1905
10	.1905
11	.1715
12	.1905
13	.1905
<b>Max</b>	<b>.1905</b>
<b>Min</b>	<b>.1715</b>
<b>Avg</b>	<b>.1867</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. I S/DN.[295] BU 4295

Substation No/ Name :- 034042 / 33 KV Navsari S/Stn

Feeder No / Name : 205 / New Cotton Market

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.3429	1.2003		1.2003	.8916	.7888
2	1.286	.3086	1.166	1.2003	1.166	.8573	.7888
3		.3086	1.1145	1.166	1.1145	.8573	.7888
4		.3086	1.0802	1.1317	1.0974	.8573	.7545
5		.2743	1.0974	1.0974	1.0974	.8573	.7202
6		.2572	.7888	.8402	.7888	.7373	.6859
7	.3258	.2572	.7545	.7716	.7716	.703	.6687
8	.3429	.2058	.7202	.703	.7202	.6516	.6516
9	.2401	.2058	.7202	.6687	.7202	.583	.583
10		.2058	.7373	.6687	.6859	.583	.583
11	.2743	.1886	.7373	.703	.6516	.5487	.5658
12	.2572	.1886	.7373	.7716	.6516	.5144	.5658
13	.2401	.1886	.7373	.8059	.6516	.5144	.5658
14	.2987	.1886	.7373	.8745	.6516	.5487	.5487
15	.2987	.7842	.8962	.9945	.7842	.5975	.583
16	.2801	.8402	.9335	.9774	.8215	.5975	.583
17	.2801	.8215	.9709	.9602	.8589	.6161	.6344
18	.2987	.7842	.9709	.6859	.8589	.6722	.6859
19	.2987	1.0082	.8962	.8916	.8962	.7842	.7202
20	.2801	1.0269	.8962	.9602	.9335	.8589	.8573
21	.2987	1.0456	.8962	.9602	.9335	.8962	.9431
22	.3258	1.1317	1.0974	1.1317			.9774
23	.3429	1.2346	1.2517	1.2517	1.0117	.8573	1.0802
24	.4115	.3429	1.2003	.5975	1.2174	.9259	.8059
Max	1.286	1.2346	1.2517	1.2517	1.2174	.9259	1.0802
Min	.2401	.1886	.7202	.5975	.6516	.5144	.5487
Avg	.3584	.5187	.9308	.9049	.8819	.7179	.7137

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. I S/DN.[295] BU 4295

Substation No/ Name :- 034042 / 33 KV Navsari S/Stn

Feeder No / Name : 206 / Vidyut Nagar

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	1.1145	1.0802		1.0802	.823	.7373
2	1.0288	1.0802	1.0288	1.0974	1.0288	.823	.7202
3	.9945	1.0631	.9945	1.0631	.9945	.7888	.7202
4	.9431	1.0288	.9602	1.0288	.9602	.7202	.6859
5	.8402	.9945	.9431	.9945	.9431	.7202	.6516
6	.4973	.7202	.6687	.703	.6687	.6001	.5658
7	.6516	.6859	.6344	.6516	.6516	.583	.5144
8	.6001	.6344	.583	.6001	.6001	.5144	.4973
9	.6001	.6344	.583	.6173	.6173	.5144	.4973
10	.6001	.6344	.6001	.6173	.6173	.5144	.4973
11	.6001	.6344	.6173	.6001	.6173	.5144	.4973
12	.6344	.6516	.6173	.6173	.6173	.5144	.5144
13	.703	.6859	.6859	.6516	.583	.5144	.5144
14	.8029	.703	.6859	.7202	.583	.5316	.5316
15	.7842	.7468	.8215	.823	.6722	.5788	.5487
16	.7842	.7095	.8589	.8059	.7095	.5788	.5487
17	.7842	.6908	.8775	.7888	.7468	.5788	.5658
18	.8402	.6722	.8402	.6687	.7468	.6348	.6173
19	.8962	.7468	.8402	.703	.8215	.7095	.9259
20	.9335	1.0456	.8962	.8573	.8402	.8029	.823
21	.9335	.9149	.8962	.8745	.8402	.8215	.823
22	1.0288	1.0117	.9774	1.046			.8745
23	1.0974	1.1145	1.1145	1.166	.8916	.7545	.9602
24	1.2174	1.166	1.1145	1.1317	1.1145	.8573	.7545
Max	1.2174	1.166	1.1145	1.166	1.1145	.8573	.9602
Min	.4973	.6344	.583	.6001	.583	.5144	.4973
Avg	.8332	.8368	.8300	.8186	.7802	.6519	.6494

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. I S/DN.[295] BU 4295

Substation No/ Name :- 034042 / 33 KV Navsari S/Stn

Feeder No / Name : 207 / 11 kv Navodai

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1145	1.0288	1.0288		1.0288	.823	.8059
2	1.0802	.9945	.9945	1.0802	.9945	.823	.7888
3	1.0631	.9602	.9602	1.0288	.9602	.823	.7716
4	1.046	.9431	.9259	.9945	.9259	.7716	.7716
5	1.046	.9259	.8916	.9602	.8916	.7716	.7716
6	.9774	.8745	.8402	.8916	.8402	.7202	.7373
7	.8402	.8573	.8059	.823	.823	.6859	.6859
8	.823	.7716	.7716	.7716	.8059	.6001	.6344
9	.7373	.7888	.7716	.7716	.7545	.6516	.6516
10	.7716	.7888	.7545		.6859	.6516	.6516
11	.8059	.8059	.7888	.7888	.6859		.6687
12	.823	.8059	.7888	.8059	.6859	.7716	.6687
13	.8402	.823	.823	.8402	.6173	.6859	.6687
14	.9335	.823	.823	.8402	.6173	.5658	.6516
15	.9709	.8589	.9335	.8402	.6722	.5975	.6859
16	.9896	.8589	.9335	.8402	.6722	.5601	.6859
17	1.0082	.8962	.9709	.823	.2427	.5601	.6859
18	1.0082	.8962	.9709	.7202	.2614	.6348	.6859
19	1.0269	.9709	.8402	.7888	.7842	.7842	.7202
20	1.0269	1.0269	.9522	.6859	.8402	.8402	.8916
21	.3734	1.0456	.9709	.7716	.8402	.8589	.9431
22	1.0117	1.0288	1.0288	.9945			.9945
23	1.0974	1.046	1.1145	1.046	.8916	.823	1.0288
24	1.1831	1.0802	1.0631	1.1145	1.0631	.8573	.8059
Max	1.1831	1.0802	1.1145	1.1145	1.0631	.8589	1.0288
Min	.3734	.7716	.7545	.6859	.2427	.5601	.6344
Avg	.9416	.9125	.9061	.8737	.7646	.7210	.7523



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. I S/DN.[295] BU 4295

Substation No/ Name :- 034042 / 33 KV Navsari S/Stn

Feeder No / Name : 211 / 11 KV SAURABH FEEDAR Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.7202	.6859		.6859	.583	.4973
2	.703	.6859	.6516	.7202	.6516	.5658	.4801
3	.6516	.6859	.6173		.6173	.5487	.4801
4	.6173	.6516	.6001	.6516	.6001	.5144	.4458
5	.5487	.6173	.5658	.6173	.583	.5144	.4287
6	.4973	.4801	.4458	.463	.4801	.4458	.3944
7	.463	.4287	.4287	.4458	.4458	.4115	.3944
8	.4287	.4287	.4115	.4287	.4115	.3772	.3944
9	.3772	.4287	.4115	.3944	.4115	.3772	.3772
10	.3944	.4287	.4115	.4115	.3772	.3429	.3772
11	.3944	.4287	.4287	.4287	.3772	.3429	.3601
12	.4287	.4458	.4287	.4458	.3944	.3429	.3772
13	.4801	.4801	.4287	.4801	.3944	.3429	.3772
14	.5601	.4973	.4287	.5487	.3944	.3258	.3772
15	.5788	.5601	.5601	.5487	.4481	.3734	.3772
16	.5788	.5415	.5601	.5487	.4481	.4108	.3772
17	.5601	.5228	.5975	.5487	.4668	.4481	.3944
18	.5975	.5228	.5975	.5144	.5041	.5228	.3944
19	.6161	.5601	.4668	.4973	.5041	.5041	.4115
20	.6161	.5975	.5975	.5316	.5415	.5228	.5144
21	.6348	.6535	.6161	.5487	.5415	.5228	.5487
22	.6859	.6687	.6859	.703			.583
23	.7545	.7545	.7716	.7545	.6001	.5144	.6687
24	.8059	.7545	.7373	.7545	.7373	.583	.4973
Max	.8059	.7545	.7716	.7545	.7373	.583	.6687
Min	.3772	.4287	.4115	.3944	.3772	.3258	.3601
Avg	.5727	.5643	.5473	.5448	.5050	.4538	.4387

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. I S/DN.[295] BU 4295

Substation No/ Name :- 034042 / 33 KV Navsari S/Stn

Feeder No / Name : 212 / maharshi

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343		.0514	.0514	.0343
2	.0343	.0343	.0343	.0343	.0514	.0514	.0343
3	.0343	.0343	.0343	.0343	.0343	.0514	.0343
4	.0343	.0343	.0343	.0343	.0343	.0514	.0343
5	.0343	.0343	.0343	.0343	.0343	.0514	.0343
6	.0343	.0343	.0343	.0343	.0343	.0514	.0343
7	.0343	.0343	.0343	.0343	.0343	.0514	.0343
8	.0343	.0514	.0343	.0514	.0343	.0514	.0514
9	.0686	.0514	.0343	.0686	.0343	.0514	.0514
10	.0857	.0514	.0343	.0686	.0343	.0514	.0514
11	.1029	.0514	.0343	.0686	.0343	.0514	.0514
12	.0857	.0514	.0343	.0686	.0343	.0514	.0343
13	.0514	.0514	.0343	.0514		.0514	.0343
14	.0747	.0514	.0343	.0514		.0343	.0343
15	.056	.056	.056	.0514	.0373	.0373	.0343
16	.0747	.056	.0747	.0514	.0187	.0373	.0343
17	.0747	.0373	.0747	.0514	.0187	.056	.0343
18	.056	.0373	.0747	.0171	.0373	.056	.0343
19	.056		.0747	.0171	.0373	.056	.0343
20	.056	.056	.0747	.0514	.0373	.056	.0514
21	.056	.056	.0747	.0514	.0373	.0747	.0686
22	.0514	.0514	.0514	.0514			.0514
23	.0514	.0514	.0514	.0514	.0514	.0514	.0514
24	.0343	.0514	.0514	.0343	.0514	.0514	.0343
Max	.1029	.056	.0747	.0686	.0514	.0747	.0686
Min	.0343	.0343	.0343	.0171	.0187	.0343	.0343
Avg	.0546	.0458	.0474	.0462	.0368	.0512	.0407

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. I S/DN.[295] BU 4295

Substation No/ Name :- 034042 / 33 KV Navsari S/Stn

Feeder No / Name : 213 / Rangoli

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.3086		.3086	.2229	.2229
2	.3086	.3086	.3086	.3086	.3086	.2229	.2229
3	.2401	.2915	.2743	.2743	.3086	.2058	.2058
4	.2401	.2915	.2743	.2743	.2743	.2058	.2058
5	.2401	.2743	.2572	.2572	.2572	.1886	.1715
6	.2058	.2229	.2058	.2229	.2058	.1715	.1715
7	.1886	.2058	.2058	.2058	.2058	.1715	.1715
8	.1715	.1886	.1715	.1715	.1886	.1543	.1543
9	.1543	.1886	.1715	.1543	.1886	.1543	.1543
10	.1543	.1886	.1715	.1543	.1715	.1543	.1543
11	.1715	.1715	.1715	.1715	.1715		.1543
12	.1715	.1715	.1715	.1715	.1715	.1372	.1543
13	.1886	.1715	.1886	.2058	.1715	.1372	.1543
14	.2054	.1715	.1886	.2401	.1715	.1372	.1543
15	.2241	.2054	.1867	.2401	.1867	.1494	.1543
16	.2241	.2054	.1307	.2401	.1867	.1494	.1543
17	.2241	.1867	.1867	.2401	.2054	.1867	.1543
18	.2241	.5228	.1867	.1715	.2054	.1867	.1715
19	.2241	.1867	.1867		.2054	.2054	.1715
20	.2241	.2054	.2427		.2241	.2241	.2058
21	.2241	.2427	.2614	.2743	.2054	.2241	.2401
22	.3086	.2915	.2915	.3258			.2572
23	.3429	.2915	.3258	.3086	.2572	.2229	.2915
24	.3429	.3429	.3258	.3258	.3258	.2401	.2229
Max	.3429	.5228	.3258	.3258	.3258	.2401	.2915
Min	.1543	.1715	.1307	.1543	.1715	.1372	.1543
Avg	.2311	.2446	.2248	.2352	.2220	.1842	.1865

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. I S/DN.[295] BU 4295

Substation No/ Name :- 034042 / 33 KV Navsari S/Stn

Feeder No / Name : 401 / 33 KV WALGAON O/G FROM 33 HV Non-Express Feeder  
KV E Feeder KV- 33 / INCOMING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.858	3.9095	3.9609		3.8066	3.3951	3.2407
2	2.8807	3.8066	3.9095	3.858	3.7037	3.3951	3.1893
3	2.8292	3.7037	3.858	3.7551	3.6008	3.3436	3.1893
4	2.8292	3.6008	3.7551	3.6008	3.6008	3.0864	3.0864
5	2.8807	3.4979	3.6008	3.6008	3.4979	3.0864	2.9835
6	2.572	3.3436	3.1379	3.2922	3.1893	2.8292	2.8292
7	2.3148	2.7778	2.6235	3.0864	2.7263	2.6235	2.572
8	1.8519	2.9321	2.6749	2.9321	2.8292	2.2119	2.2119
9	2.0062	2.7778	2.572	3.2407	2.6749	1.9547	2.1605
10	2.0062	2.7778	2.4691	3.1893	2.572	1.8519	2.1605
11	1.9033	2.4691	2.6749	3.2407	2.3663	1.749	2.1091
12	2.1091	2.6749	2.7778	3.2922	2.0576	1.4918	2.2634
13	2.4177	2.7778	2.9835	3.6523	1.5432	1.4918	2.2634
14	3.6408	2.8292	2.9835	3.6523	1.5432	1.286	2.3663
15	3.7529	3.0807		3.6008	2.2405	1.6804	2.3663
16	3.9209	3.0247	3.3608	3.2407	2.5206	1.9605	2.4177
17	4.0329	2.5206	3.1927	3.1893	2.4086	2.2405	2.4177
18	4.201	2.1285	3.3608	1.5432	2.3525	2.8006	2.6749
19	4.369	3.3608	3.5288	2.9835	3.0807	2.8006	3.0864
20	4.481	3.3608	4.481	3.5494	3.6969	3.7529	3.7037
21	4.7611	4.8731	4.481	3.858	3.6969	3.6408	3.8066
22	4.321	4.2181	4.321	4.0124		3.2922	3.858
23	4.1152	4.1667	4.1667	3.9609	3.5494	3.2922	3.7551
24	4.0638	4.0124	4.0638	4.0124	3.858	3.4465	3.2407
Max	4.7611	4.8731	4.481	4.0124	3.858	3.7529	3.858
Min	1.8519	2.1285	2.4691	1.5432	1.5432	1.286	2.1091
Avg	3.2549	3.2760	3.4321	3.4062	2.9181	2.6127	2.8314

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. I S/DN.[295] BU 4295

Substation No/ Name :- 034044 / 33 KV WADALI SUB STATION

Feeder No / Name : 201 / University HV Group Express Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.2614	.2427	.2614	.2614	.2801	.2427
2	.2987	.2614	.2427	.2427	.2614	.2801	.2427
3	.2987	.2614	.2614	.2427	.2614	.2801	.2427
4	.2987	.2614	.2427	.2241	.2614	.2427	.2427
5	.2801	.2614	.2427	.2241	.2801	.2427	.2427
6	.2987	.2614	.2614	.2241	.2801	.2427	.2427
7	.2801	.2614	.2614	.2241	.2801	.2241	.2427
8	.2801	.2614	.2987	.2427	.2427	.2241	.2241
9	.3361	.2801	.2957	.2614	.2801	.2241	.2614
10	.3547	.3258	.3696	.2801	.2801	.2801	.2614
11	.4481	.4527	.4251	.2801	.3174	.3921	.4108
12	.5228	.5601	.4435	.3361	.3734	.4481	.4481
13	.5601	.5601	.4251	.3734	.3734	.4481	.4854
14	.5601	.5415	.4435	.3921	.3547	.3734	.4854
15	.5975		.3881	.3547	.2987	.3921	.4854
16	.5975		.3734	.2987	.2614	.4481	.4668
17	.5975	.4481	.3361	.2427	.1886	.4294	.4481
18	.5975	.3734	.2801	.2987	.1867	.2987	.3361
19	.2987	.2987	.2801	.2801	.2614	.2801	.2801
20	.2987	.2987		.2801	.2987	.2614	.2987
21	.2987	.2987	.3361	.2987	.2987	.2987	.2801
22	.2987	.2987	.2987	.2987		.2987	.2801
23	.2801	.2987	.2614	.2987	.2987	.2987	.2801
24	.3174	.2614	.2614	.2614	.2614	.2427	.2427
Max	.5975	.5601	.4435	.3921	.3734	.4481	.4854
Min	.2801	.2614	.2427	.2241	.1867	.2241	.2241
Avg	.3874	.3358	.3162	.2801	.2810	.3096	.3197

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. I S/DN.[295] BU 4295

Substation No/ Name :- 034044 / 33 KV WADALI SUB STATION

Feeder No / Name : 202 / S.R.P.F.

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0242	.8962	.9145	.8501	.8402	.7468	.7095
2	.9694	.8962	.8779	.8048	.8402	.7468	.7095
3	.9145	.8962	.8596	.7316	.8402	.7468	.7095
4	.8779	.8962	.823	.7316	.8402	.7468	.7095
5	.8048	.8402	.8048	.695	.7468	.7468	.7095
6	.7316	.8402	.7682	.695	.7468	.6535	.6535
7	.6767	.6722	.6584	.6584	.6722	.5975	.6535
8	.695	.5975	.6584	.6653	.5975	.5601	.5601
9	.6036	.5975	.6099	.6653	.6283	.5601	.5853
10	.6219	.6516	.6219	.7316	.5729	.5014	.5853
11	.7316	.6335	.6584	.9145	.5914	.5014	.5601
12	.695	.6584	.6036	.6584	.5729	.5487	.5175
13	.695	.695	.6468	.6767	.5544	.5121	.5121
14	.7316	.7682	.6653	.7316	.5914	.4755	.5175
15	.7392		.6584	.7265	.5914	.4755	.6099
16	.8215		.7316	.7023	.5853	.5175	.5853
17	.7095	.7392	.7468	.6283	.6219	.5359	.5853
18	.6348	.695	.6722	.6653	.5853	.5544	.6401
19	.6908	.8048	.5914	.7392	.6283	.6036	.6767
20	.6908	.823		.7392	.6653	.6838	.7499
21	.8962	.8048	.7468	.7392	.6584	.6838	.8048
22	.9335	.9328	.8871	.9335		.7468	.8048
23	.9709	.9511	.8779	.9335	.7842	.7468	.8779
24	1.0242	.9335	.9145	.8779	.8962	.7655	.7095
Max	1.0242	.9511	.9145	.9335	.8962	.7655	.8779
Min	.6036	.5975	.5914	.6283	.5544	.4755	.5121
Avg	.7868	.7829	.7390	.7456	.6805	.6232	.6557

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. I S/DN.[295] BU 4295

Substation No/ Name :- 034044 / 33 KV WADALI SUB STATION

Feeder No / Name : 203 / Andha Vidyalaya

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7865	.7842	.7682	.7316	.7468	.6535	.5975
2	.7499	.7842	.7682	.695	.7468	.6535	.5975
3	.7133	.7842	.7499	.6584	.7468	.6535	.5975
4	.7316	.7842	.7499	.6219	.7468	.6535	.5975
5	.7316	.7842	.7316	.6348	.7468	.6535	.5975
6	.6036	.7468	.6584	.6219	.7468	.5601	.5601
7	.567	.6348	.5487	.5853	.6722	.5041	.4668
8	.5487	.5601	.5304	.5487	.6722	.5041	.4481
9	.5487	.5601	.5487	.5121	.5914	.4668	.4435
10	.5853	.5792	.567	.567	.5544	.4805	.462
11	.5121	.5068	.5487	.567	.5853	.462	.4435
12	.5544	.5487	.567	.6036	.499	.462	.462
13	.5914	.5853	.5487	.6401	.5121	.4435	.4572
14	.6653	.6219	.5853	.6584	.5544	.4066	.4572
15	.6584		.4755	.6584	.5544	.439	.4805
16	.7468		.5487	.6401	.5487	.4805	.4938
17	.7095	.6348	.5853	.6283	.5487	.499	.5121
18	.6535	.6584	.6468	.6838	.5544	.5175	.5304
19	.5975	.7392	.6584	.7207	.5914	.6283	.6219
20	.5975	.7316	.7316	.7762	.6653	.6468	.7133
21	.7468	.7316	.695	.7577	.6653	.6468	.7316
22	.8215	.7865	.7316	.8029		.6535	.7316
23	.8402	.7682	.7316	.8215	.6908	.6535	.7499
24	.8596	.7842	.8048	.7316	.8215	.6722	.6348
Max	.8596	.7865	.8048	.8215	.8215	.6722	.7499
Min	.5121	.5068	.4755	.5121	.499	.4066	.4435
Avg	.6717	.6863	.645	.6611	.6418	.5581	.5578

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. I S/DN.[295] BU 4295

Substation No/ Name :- 034044 / 33 KV WADALI SUB STATION

Feeder No / Name : 204 / CIRCUIT HOUSE

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6057	1.6057	1.475	1.4003	1.4003	1.1203	1.0269
2	1.4937	1.6057	1.4377	1.307	1.4003	1.1203	1.0269
3	1.4563	1.6057	1.4003	1.2136	1.4003	1.1203	1.0269
4	1.4003	1.6057	1.2323	1.1203	1.4003	1.1203	1.0269
5	1.3256	1.6057	1.2323	1.0829	1.4003	1.1203	1.0269
6	1.1576	1.4003	1.1576	1.0456	1.1203	1.0269	.8589
7	1.0456	1.0082	.9522	.8962	1.1203	.9335	.8215
8	.9709	.9335	.8962	.8962	.8962	.8962	.8215
9	.9335	.9709	.9149	.8962	.8589	.8402	.924
10	.961	1.0164	.8871	.9522	.8589	.8131	.8871
11	1.0242	1.1088	.9055	.9709	.8962	.8871	.8962
12	1.1088	1.1389	.9522	.9709	.7842	.8871	.8871
13	1.1827	1.2323	.9425	1.0456	.8029	.8131	.8962
14	1.2567	1.2883	.961	1.1203	.8589	.8871	.8871
15	1.3169		1.0903	1.1389	.8589	.8215	.9709
16	1.307		1.1827	1.1016	.8589	.9335	1.0456
17	1.2696	1.3443	1.1458	.9335	.8131	.9522	.9896
18	1.1203	1.0974	1.0082	.9522	.8131	.8589	.8962
19	1.0269	1.1949	.961	1.0456	.8962	.9335	1.0642
20	1.2136	1.2696		1.1576	1.0456	1.0829	1.1576
21	1.3443	1.1949	1.1827	1.2696	1.0456	1.0829	1.1763
22	1.4937	1.4563	1.3443	1.4003		1.1576	1.2696
23	1.587	1.5123	1.4563	1.4377	1.2323	1.1576	1.363
24	1.7177	1.6057	1.531	1.4937	1.4563	1.1949	1.094
Max	1.7177	1.6057	1.531	1.4937	1.4563	1.1949	1.363
Min	.9335	.9335	.8871	.8962	.7842	.8131	.8215
Avg	1.2633	1.3092	1.1413	1.1187	1.0530	.9901	1.0017



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. I S/DN.[295] BU 4295

Substation No/ Name :- 034044 / 33 KV WADALI SUB STATION

Feeder No / Name : 205 / 11 KV PRASHANT NAGER Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1888	1.2323	1.1523	1.1203	1.0829	1.0456	.9335
2	1.1523	1.2323	1.134	1.0829	1.0829	1.0456	.9335
3	1.134	1.2323	1.134	1.0456	1.0829	1.0456	.9335
4	1.0974	1.2323	1.0791	1.0082	1.0829	1.0456	.9335
5	1.0425	1.2323	1.0608	.9709	1.0829	.9335	.9335
6	.9877	1.1203	1.0059	.9709	.9335	.8402	.8402
7	.7682	.8215	.8048	.8215	.8589	.7842	.7468
8	.7316	.7468	.7133	.7842	.7842	.7842	.6535
9	.695	.7468	.7499	.7468	.7577	.6722	.6468
10	.7095	.8316	.7499	.7133	.7577	.695	.6468
11	.7468	.8316	.8131	.823	.7316	.5914	.6283
12		.7947	.8048	.8048	.7499	.5975	.5975
13		.7865	.8413	.9145	.8131	.5975	.6653
14		.8871	.8413	.9511	.7392	.6348	.6653
15	.961		.8413	1.0059	.7392	.6348	.7392
16	.9709		.8501	.8871	.7316	.6653	.7499
17	.8402	.7468	.8131		.7392	.6653	.695
18	.8402	.8131	.8501	.924	.7468	.6653	.7133
19	.8402	.961	.8589	.8501	.8131	.7762	.8596
20	.9709	.9709		.8501	.961	.9979	1.0608
21	1.1203	1.1949	1.0349	.8501	.9709	1.0164	
22	1.2696	1.2803	1.1949	.8589		1.0456	1.1706
23	1.307	1.2308	1.1706	.9335	1.0829	1.0082	1.1523
24	1.262	1.2323	1.1888	1.1706	.9335	1.0456	.9709
Max	1.307	1.2803	1.1949	1.1706	1.0829	1.0456	1.1706
Min	.695	.7468	.7133	.7133	.7316	.5914	.5975
Avg	.9827	1.0072	.9429	.9169	.8808	.8264	.8204

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. I S/DN.[295] BU 4295

Substation No/ Name :- 034044 / 33 KV WADALI SUB STATION

Feeder No / Name : 402 / 33 KV I/C VIDYUT BHAVAN HV Non-Express Feeder  
Feeder KV- 33 / INCOMING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		5.7133	5.5736	5.6013	5.7133	4.7611	4.201
2		5.7133	5.5229	5.4893	5.7133	4.7611	4.201
3		5.7133	5.1795	4.7611	5.7133	4.7611	4.201
4		5.7133	4.8466	4.481	5.6013	4.7611	4.201
5		5.6013	4.6259	4.201	5.0412	4.7611	4.201
6		4.7611	4.0013	4.0889	4.7611	4.201	3.9209
7		3.9209	3.5504	3.8089	4.0329	3.6408	3.4728
8		3.8089	3.3779	3.7529	3.6969	3.6408	3.3608
9	3.8322	4.0329	3.2579	3.6969	3.6408	3.6408	3.4728
10	3.9209	4.3958	3.7609	3.8886	3.5848	3.8089	3.8089
11	4.313	4.6823	3.7609	4.0013	3.6037	3.9769	3.9209
12		5.072	3.9918	4.283	3.6591	3.9769	4.0889
13		5.2411	4.0604	4.3958	3.77	3.9769	4.313
14		5.4047	4.3896	4.7902	4.145	4.201	4.369
15	5.8814		4.4993	5.1232	3.9918	4.0329	4.481
16	5.8814		5.1532	4.4353	4.201	4.2135	4.6775
17	5.4893	3.9209	4.8731	4.0472	3.9769	4.269	4.513
18	4.8731	4.7051	4.537	4.3244	3.6969	4.0472	4.2267
19	4.6491	5.0412	4.481	3.6037	4.481	4.4907	4.5085
20	5.0412	5.0972		4.0329	4.537	4.6571	5.0106
21	5.4893		4.9851	4.0472	4.7051	4.7051	5.072
22	5.4893	5.4665	5.3212	5.6013		4.369	5.0669
23	5.9934	5.8046	5.5441	5.8253	4.8171	4.481	5.4102
24		5.7133	5.6356	5.5996	5.998	4.7611	4.313
Max	5.9934	5.8046	5.6356	5.8253	5.998	4.7611	5.4102
Min	3.8322	3.8089	3.2579	3.6037	3.5848	3.6408	3.3608
Avg	5.0711	5.0249	4.5621	4.4950	4.4818	4.2873	4.2922

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. I S/DN.[295] BU 4295

Substation No/ Name :- 034044 / 33 KV WADALI SUB STATION

Feeder No / Name : 404 / 33 KV I/C to Congress

HV Non-Express Feeder

Nagar SS Feeder KV- 33 /

INCOMING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0288	1.9605	1.9161	1.9044	1.9605	1.6804	1.4563
2	1.9725	1.9605	1.9161	1.8484	1.9605	1.6804	1.4563
3	1.8579	1.9605	1.8579	1.7924	1.9605	1.6804	1.4563
4	1.8016	1.9605	1.689	1.6804	1.9605	1.6804	1.4563
5	1.6924	1.7924	1.5764	1.6804	1.9605	1.6804	1.4563
6	1.4653	1.6804	1.578	1.6244	1.9605	1.4563	1.3443
7	1.3512	1.4563	1.4103	1.5123	1.6804	1.3443	1.2323
8	1.3525	1.3443	1.2398	1.4563	1.4563	1.3443	1.2323
9	1.2386	1.2883	1.0425	1.3443	1.3443	1.2323	1.0642
10	1.3443	1.3539	1.2071	.6205	1.2323	1.1763	1.0642
11	1.3443	1.2949	1.2071	.6199	1.3443	1.1763	1.1203
12		1.5201	1.2752	.6756	1.3306	1.0642	1.2323
13		1.4638	1.3306	1.6907	1.4003	1.1203	1.1763
14		1.5201	1.386	1.6907	1.4003	1.1203	1.1763
15	1.6607		1.4969	1.7453	1.4003	1.1203	1.1763
16	1.7924		1.5123	1.5123	1.4003	1.2323	1.1835
17	1.7924	1.9044	1.5684	1.4563	1.4003	1.2323	1.2962
18	1.6804	1.7364	1.3667	1.5684	1.3443	1.2883	1.2398
19	1.6244	1.7364	1.4563	1.6244	1.4563	1.4003	1.4075
20	1.9605	1.8484		1.8484	1.6244	1.5684	1.6907
21	2.0165	1.9044	1.8484	1.885	1.6804	1.5524	1.747
22	2.0165	1.9725	1.9044	1.9605		1.6804	1.8034
23	2.0165	2.0288	1.9605	1.9605	1.7364	1.5684	1.747
24	2.0873	1.9605	1.9161	1.9605	1.9605	1.6804	1.4563
Max	2.0873	2.0288	1.9605	1.9605	1.9605	1.6804	1.8034
Min	1.2386	1.2883	1.0425	.6199	1.2323	1.0642	1.0642
Avg	1.7189	1.7113	1.5505	1.5693	1.6067	1.4067	1.3613

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. I S/DN.[295] BU 4295

Substation No/ Name :- 034045 / 33 KV VIDYUT BHAVAN

Feeder No / Name : 203 / CAMP AMT U1

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.7762	.7865	.7762	.7316			
7					.6653		
8						.6602	.6413
Max	.7762	.7865	.7762	.7316	.6653	.6602	.6413
Min	.7762	.7865	.7762	.7316	.6653	.6602	.6413
Avg	.7762	.7865	.7762	.7316	.6653	.6602	.6413

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. I S/DN.[295] BU 4295

Substation No/ Name :- 034045 / 33 KV VIDYUT BHAVAN

Feeder No / Name : 204 / Hospital feeder

HV Group Express Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.128	.128	.128	.128			
7					.1294		
8						.1463	.1132
Max	.128	.128	.128	.128	.1294	.1463	.1132
Min	.128	.128	.128	.128	.1294	.1463	.1132
Avg	.128	.128	.128	.128	.1294	.1463	.1132

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. I S/DN.[295] BU 4295

Substation No/ Name :- 034045 / 33 KV VIDYUT BHAVAN

Feeder No / Name : 205 / RUKHMINI NAGAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	1.5089	1.6975	1.3957	1.3769			
7					1.3203		
8						1.1706	1.2323
Max	1.5089	1.6975	1.3957	1.3769	1.3203	1.1706	1.2323
Min	1.5089	1.6975	1.3957	1.3769	1.3203	1.1706	1.2323
Avg	1.5089	1.6975	1.3957	1.3769	1.3203	1.1706	1.2323

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. I S/DN.[295] BU 4295

Substation No/ Name :- 034045 / 33 KV VIDYUT BHAVAN

Feeder No / Name : 206 / 11 kv SHYAM NAGAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	1.2048	1.258	1.5023	1.4685			
7					1.3769		
8						1.2567	1.2323
<b>Max</b>	<b>1.2048</b>	<b>1.258</b>	<b>1.5023</b>	<b>1.4685</b>	<b>1.3769</b>	<b>1.2567</b>	<b>1.2323</b>
<b>Min</b>	<b>1.2048</b>	<b>1.258</b>	<b>1.5023</b>	<b>1.4685</b>	<b>1.3769</b>	<b>1.2567</b>	<b>1.2323</b>
<b>Avg</b>	<b>1.2048</b>	<b>1.258</b>	<b>1.5023</b>	<b>1.4685</b>	<b>1.3769</b>	<b>1.2567</b>	<b>1.2323</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. I S/DN.[295] BU 4295

Substation No/ Name :- 034059 / 33 KV OLD POWER HOUSE

Feeder No / Name : 201 / LIC

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	.132	.1132	.1307	.1307	.112	.1132
2	.1494	.1109	.1132	.112	.1494	.0934	.1109
3	.1307	.1132	.112	.0934	.1494	.0934	.1109
4	.112	.1132	.112	1.251	.1867	.0934	.1132
5	.112	.1509	.112	.0934	.1867	.0934	.1478
6	.168	.1698	.168	.112	.168	.1494	.1848
7	.168	.1698	.168	.0934	.1494	.1494	.1848
8	.168	.1509	.1509	.0934	.1494	.1307	.1463
9	.1663	.1698	.168	.0934	.1509	.1307	.1848
10	.1867	.2054	.1867	.112	.1433		.168
11	.2427	.2427	.2427	.112	.1698	.2054	.2241
12	.2427	.2614	.2427	.1307	.1698	.2427	
13	.2427	.2614	.2614	.0934	.1886	.2054	.168
14	.2241	.2427	.2427	.112	.1509	.168	.168
15	.2614	.2241	.2054	.112	.1698	.1867	.1867
16	.2427	.1867	.2054	.0934	.3547	.168	.168
17	.2075	.1867	.112	.0934	.112	.1509	.1867
18	.1886	.1307	.112	.0934	.0934	.1698	.1307
19	.0943	.1307	.112	.0934	.0934	.1132	.112
20	.0943	.1307	.112	.112	.112	.1109	.112
21	.1132	.1494	.1307	.1132	.0934	.1109	.112
22	.132	.112	.1494	.132	.112		.1307
23	.132	.112	.1307	.112	.112	.1132	.1307
24	.1307	.132	.1109	.1307	.112	.112	.1109
Max	.2614	.2614	.2614	1.251	.3547	.2427	.2241
Min	.0943	.1109	.1109	.0934	.0934	.0934	.1109
Avg	.1699	.1662	.1573	.1549	.1503	.1410	.1481



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. I S/DN.[295] BU 4295

Substation No/ Name :- 034059 / 33 KV OLD POWER HOUSE

Feeder No / Name : 202 / RAILWAY STATION AMT U1 Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6348	.6224	.5601	.5975	.5415	.4854	.3395
2	.5601	.6036	.5228	.5601	.5228	.4481	.3326
3	.5228	.5658	.4854	.5228	.5041	.4108	.3326
4	.4854	.1132	.4668	.5041	.4854	.4294	.3142
5	.3734	.4904	.4668	.5041	.5041	.4108	.4024
6	.4854	.4715	.4294	.4481	.4294	.4108	.4435
7	.5041	.4904	.4294	.3734	.4481	.3921	.4715
8	.5041	.4904	.4294		.4668	.3921	.4066
9	.5041	.4904	.4481	.4668	.4075	.5041	.462
10	.5601	.5975	.5228	.4481	.4908		.4854
11	.6722	.6348	.5601	.4668	.5658	.5601	.5228
12	.7282		.6161	.5041	.6036	.6348	
13	.7468	.7468	.6535	.5228	.6224	.5788	.6348
14	.8029	.7655	.7468	.5601	.6036	.5788	.6161
15	.8215	.7842	.7282	.5975	.6224	.5601	
16	.8402	.7095	.7468	.5601	1.2136	.6161	.6535
17	.8865	.6722	.7842	.5415	.5975	.679	.6908
18	.8488	.7468	.7468	.5041	.5788	.6979	.6348
19	.811	.7655	.6722	.5228	.6161	.7356	.7207
20	.7922	.811	.6722	.5788	.6161	.7392	.7655
21	.7356	.6908	.6722	.5601	.5601	.6099	.7095
22	.8676	.6722	.6161	.6224			.6348
23	.6979	.5601	.6161	.5601	.5415	.3961	.6161
24	.6908	.7922	.5788		.5847	.5228	.499
Max	.8865	.811	.7842	.6224	1.2136	.7392	.7655
Min	.3734	.1132	.4294	.3734	.4075	.3921	.3142
Avg	.6699	.6212	.5905	.5239	.5707	.5360	.5313

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. I S/DN.[295] BU 4295

Substation No/ Name :- 034059 / 33 KV OLD POWER HOUSE

Feeder No / Name : 203 / CHOUDHARI CHOUCK Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975	.5658	.5041	.5601	.5228	.4481	.415
2	.5601	.547	.4854	.5228	.4854	.4108	.415
3	.5601	.5093	.4854	.4854	.4435	.3734	.4066
4	.5228	.4715	.4715	.4668	.4294	.3734	.4066
5	.4854	.4715	.4108	.4668	.4481	.3734	.4066
6	.4668	.4527	.3921	.4668	.4294	.3921	.4066
7	.4668	.4527	.3961	.4108	.3921	.3734	.4207
8	.3547	.415	.3921	.3734	.3734	.3547	.3696
9	.3734	.415	.4108	.3547	.3582	.3921	.3696
10	.4108	.5228	.4481	.4108	.3898		.4108
11	.6908	.7095	.4854	.4668	.4338	.5415	.6348
12	.9522	.8402	.7468	.4854	.6413	.6161	.7095
13	.9335	.8775	.8029	.5041	.6602	.7655	.7655
14	.9522	.9709	.9149	.5228	.7733	.7655	.7095
15	1.0269	1.0082	.8962	.6161	.7922	.7468	
16		.8962	.9335	.5975	.7842	.7655	.7842
17	1.0374	.8402	.8962	.5601	.7655	.8865	.7655
18	1.0374	.9335	.8402	.4294	.6908	.8865	.8215
19	.9431	.9997	.7655	.4527	.7655	.8676	.8501
20	.9242	1.0269	.7468	.5788	.6908	.8676	.8029
21	.7733	.7842	.7655	.5601	.5975	.6468	.7282
22	1.0374	.6348	.6348	.6161	.5601		.6161
23	.6413	.5788	.6161	.5601	.5415	.5093	.6348
24	.6161	.6036	.5228	.5788	.5415	.4668	.4251
Max	1.0374	1.0269	.9335	.6161	.7922	.8865	.8501
Min	.3547	.415	.3921	.3547	.3582	.3547	.3696
Avg	.7115	.6886	.6235	.5020	.5629	.5829	.5772

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. I S/DN.[295] BU 4295

Substation No/ Name :- 034059 / 33 KV OLD POWER HOUSE

Feeder No / Name : 204 / H T Feeder

HV Group Express Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	.132	.1494	.1494	.1494	.168	.132
2	.112	.132	.1494	.1494	.1494	.168	.1294
3	.112	.132	.1509	.1494	.1494	.1494	.1294
4	.112	.132	.1494	.1307	.1494	.1494	.1294
5	.168	.132	.1494	.1494	.1494	.1494	.1294
6	.168	.1509	.1494	.1494	.1307	.1494	.1478
7	.1867	.1509	.1698	.1494	.1494	.1494	.1478
8	.1867	.1698	.1867	.168	.168	.1494	.1478
9	.2987	.1698	.1867	.168	.1791	.2801	.2218
10	.2987	.3921	.2427	.2241	.2353		.112
11	.3547	.4294	.2987	.2054	.2452	.3174	.3174
12	.3734	.3921	.2987	.2241	.2452	.3361	.2987
13	.3174	.3734	.3142	.2241	.2263	1.2883	.3361
14	.3361	.4108	.2427	.2427	.2263	.2614	.2987
15	.2614	.3881	.2241	.2427	.2218	.2427	
16		.3174	.2241	.2054	.2054	.2054	.2427
17	.2263	.2987	.2241	.1867	.168	.2263	.2427
18	.2075	.2427	.1867	.1698	.168	.2263	.2427
19	.2263	.2427	.1867	.1698	.168	.2075	.1848
20	.2075	.2241	.1867	.1494	.168	.2033	.1867
21	.2075	.168	.1867	.1494	.168	.1478	.168
22	.1698	.2054	.2054	.1509	.168	.1886	.1848
23	.1509	.1867	.168	.1494	.168	.1509	.168
24	.168	.1509	.1867	.168	.1494	.168	.1478
Max	.3734	.4294	.3142	.2427	.2452	1.2883	.3361
Min	.112	.132	.1494	.1307	.1307	.1478	.112
Avg	.2182	.2385	.2007	.1760	.1794	.2471	.1933

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. I S/DN.[295] BU 4295

Substation No/ Name :- 034059 / 33 KV OLD POWER HOUSE

Feeder No / Name : 207 / Shrikrushna Peth Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5041	.4338	.4108	.4108	.3734	.3734	.3206
2	.4668	.415	.3921	.3734	.3921	.3361	.3142
3	.4294	.3961	.3734	.3921	.3921	.2987	.3142
4	.3921	.3772	.3547	.4108	.3547	.2987	.3142
5	.3547	.3395	.3547	.3734	.3361	.2987	.3142
6	.3361	.3206	.3547	.3174	.3174	.2987	.3142
7	.2987	.3206	.3361	.3174	.2801	.2987	.3206
8	.3734	.3584	.2987	.2614	.2987	.3174	.3511
9	.3734	.3772	.3174	.2801	.3206	.2987	.3696
10	.3921	.3921	.3734	.2987	.3206		.3734
11	.4854	.4668	.4108	.2987	.3395	.4294	.4108
12	.5041	.5415	.4481	.3361	.3395	.4481	
13	.5228	.5788	.4294	.3361	.3584	.4668	.4854
14	.5415	.5788	.4481	.3174	.3772	.4294	.4481
15	.6161	.5601	.4854	.4108	.3961	.4108	
16	.6161	.4854	.4668	.3734	.3547	.4294	.4668
17	.5281	.4715	.4108	.3734	.3174	.3772	.4481
18	.5093	.4338	.4108	.2987	.3174	.3772	.4108
19	.415	.4481	.4108	.3361	.3361	.3961	.4481
20	.3961	.4854	.4108	.3921	.3734	.3961	.4294
21	.4904	1.1576	.4108	.3734	.3734	.3696	.4481
22	.4904	.4668	.4294	.4294		.3772	.4294
23	.4904	.3921	.4854	.4108	.3921	.3881	.4294
24	.4854	.4527	.4108	.4294	.4527	.3734	.3584
Max	.6161	1.1576	.4854	.4294	.4527	.4668	.4854
Min	.2987	.3206	.2987	.2614	.2801	.2987	.3142
Avg	.4588	.4687	.4014	.3563	.3528	.3690	.3872

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. I S/DN.[295] BU 4295

Substation No/ Name :- 034059 / 33 KV OLD POWER HOUSE

Feeder No / Name : 209 / Morabag Feeder

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.3584	.4294	.3734	.3361	.3174	.2829
2	.3361	.3584	.4294	.3734	.3174	.2987	.2957
3	.2987	.3772	.4108	.3734	.3361	.2987	.3142
4	.2801	.415	.3921	.3921	.3547	.2987	.3696
5	.3361	.5093	.3921	.4481	.3734	.3734	.415
6	.3547	.547	.4108	.4481	.3921	.4854	.4251
7	.3547	.547	.4294	.4854	.3361	.5228	.4435
8	.3547	.4527	.4481	.4294	.3174	.3734	.4066
9	.4108	.4527	.4715	.4294	.2715	.3174	.462
10	.4481	.6348	.7095	.4481	.2896		.5228
11	.5228	.6348	.7468	.4668	.3772	.5041	.5975
12	.6161	.7282	.5788	.5228	.4904	.5601	
13	.5975	.7468	.5975	.4854	.5281	.4668	.5975
14	.5788	.5975	.5228	.5041	.4904	.4481	.4668
15	.5975	.5975	.6908	.3921	.5093	.4108	
16	.2452	.6161	.7842	.3361	.4481	.5041	.5041
17	.2641	.5228	.7095	.3547	.4294	.3961	.5041
18	.2641	.5415	.5601	.3734	.2801	.415	.5228
19	.4527	.5601	.3547	.4108	.2987	.4715	.5041
20	.415	.4294	.3734	.2801	.3174	.4715	.4435
21	.3395	.4668	.3547	.2641	.3734	.4251	.3921
22	.3395	.4481	.3734	.3547	.3361	.3206	.3734
23	.3395	.3921	.3734	.3361	.3174	.3142	.3547
24	.3547		.4108	.3734	.3547	.3734	.2957
Max	.6161	.7468	.7842	.5228	.5281	.5601	.5975
Min	.2452	.3584	.3547	.2641	.2715	.2987	.2829
Avg	.3932	.5189	.4981	.4023	.3698	.4073	.4315

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. I S/DN.[295] BU 4295

Substation No/ Name :- 034059 / 33 KV OLD POWER HOUSE

Feeder No / Name : 404 / 33 KV O/G RAHATGAON

EHV Non-Express Feeder

Feeder KV- 33 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.3961	.3361	.3921	.3921	.3921	.3395
2	.4481	.3961	.3395	.3361	.3921	.3921	.3292
3	.4481	.3961	.3361	.3361	.3921	.3361	.3395
4	.3361	.3961	.3361	.3361	.3921	.3361	.3326
5	.3361	.3395	.3361	.3361	.3921	.3361	.3326
6	.3361	.3395	.3361	.3361	.3361	.3361	.3326
7	.3361	.3395	.3361	.3361	.3361		.3326
8	.3361	.2829	.2801	.2801	.3361	.2801	.3395
9	.3361	.3395	.2801	.2801	.3395	.3361	.3326
10	.3361	.3361	.3361	.3361	.3395		.5041
11	.3921	.3361	.3361	.3361	.3395	.3361	.6722
12	.3921	.3361	.3361	.3361	.3395	.3361	.5041
13	.3921	.3361	.3361	.3361	.3395	.3361	.5658
14	.3921	.3361	.3361	.3361	.3395	.3361	.6161
15	.4481	.3361	.3361	.3361	.3395	.3361	
16	.3921	.3395	.3361	.3361	.3361	.3361	.6161
17	.3961	.3361	.3361	.3361	.3361	.3395	.6161
18	.3961	.3361	.3361	.3395	.3361	.3395	.5601
19	.3395	.2801	.3361	.3361	.3361	.3395	.6161
20	.3395	.3361	.3361	.3361	.3361	.3961	.5601
21	.3961		.3921	.3361	.3361	.3961	.6161
22	.3961	.3921	.3921	.3361	.3361	.3961	.6161
23	.3961	.3921	.3921	.3361	.3921	.3326	.6161
24		.4527	.3921	.3921	.3921	.3361	.3395
Max	.4481	.4527	.3921	.3921	.3921	.3961	.6722
Min	.3361	.2801	.2801	.2801	.3361	.2801	.3292
Avg	.3811	.3525	.3409	.3362	.3534	.3471	.4795

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. I S/DN.[295] BU 4295

Substation No/ Name :- 034076 / 33 KV RAHATGAON

Feeder No / Name : 202 / 11 KV KANTA NAGAR  
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9		.2033	.0914	.1829	.1646	.2012	.2149
10	.1829						
Max	.1829	.2033	.0914	.1829	.1646	.2012	.2149
Min	.1829	.2033	.0914	.1829	.1646	.2012	.2149
Avg	.1829	.2033	.0914	.1829	.1646	.2012	.2149

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. I S/DN.[295] BU 4295

Substation No/ Name :- 034076 / 33 KV RAHATGAON

Feeder No / Name : 203 / 11 KV GITTI KHADAN

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9		.0191	.0381	.0381	.0381	.0381	.0381
10	.0381						
Max	.0381	.0191	.0381	.0381	.0381	.0381	.0381
Min	.0381	.0191	.0381	.0381	.0381	.0381	.0381
Avg	.0381	.0191	.0381	.0381	.0381	.0381	.0381



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. I S/DN.[295] BU 4295

Substation No/ Name :- 034083 / 33 KV Congress Nagar S/Stn

Feeder No / Name : 201 / 11 KV CONGRESS NAGAR Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.8131	.7762	.7762	.7762			
8					.7655	.7095	
9							.5788
Max	.8131	.7762	.7762	.7762	.7655	.7095	.5788
Min	.8131	.7762	.7762	.7762	.7655	.7095	.5788
Avg	.8131	.7762	.7762	.7762	.7655	.7095	.5788

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. I S/DN.[295] BU 4295

Substation No/ Name :- 034083 / 33 KV Congress Nagar S/Stn

Feeder No / Name : 202 / 11 KV CHAPARASHIPURA Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.6335	.6335	.5792	.5973			
8					.6099	.5228	
9							.4481
Max	.6335	.6335	.5792	.5973	.6099	.5228	.4481
Min	.6335	.6335	.5792	.5973	.6099	.5228	.4481
Avg	.6335	.6335	.5792	.5973	.6099	.5228	.4481

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. I S/DN.[295] BU 4295

Substation No/ Name :- 034083 / 33 KV Congress Nagar S/Stn

Feeder No / Name : 203 / 11 KV CP OFFICE Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.0191	.0189	.0191	.0191			
8					.0187	.0381	
9							.0189
Max	.0191	.0189	.0191	.0191	.0187	.0381	.0189
Min	.0191	.0189	.0191	.0191	.0187	.0381	.0189
Avg	.0191	.0189	.0191	.0191	.0187	.0381	.0189

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. II S/DN.[296] BU 4296

Substation No/ Name :- 034046 / 33KV HANUMAN NAGAR

Feeder No / Name : 201 / BUDHWARA

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1765	1.134	1.1157	1.1643	1.0498	.9425	
2	1.0974	1.0974	1.0974	1.1088	.9955	.8686	
3	1.0608	1.0349	1.0242	1.0719	.9877	.8501	
4	1.0242	.961	.9511	.9877	.9511	.8131	
5	.961	.8962	.9145	.9145	.9328	.7499	
6	.9145	.8596	.8507	.8596	.8596	.7207	
7	.905	.8779	.8688	.8413	.8413	.7499	
8	.8145	.823	.8145	.823	.8596	.7682	
9	.8326	.8413	.7964		.8779	.7499	
10							.7468
11						.7282	.6908
12						.7095	.6908
13						.6722	.7282
14						.6908	.7282
15	.9979		.9055	.9709	.8029	.6722	
16	.9709		.924	.8316	.7842	.7282	
17	.7655		.8871	.8501	.7577	.7095	
18	.7468		.8501	.7947	.7577	.7468	
19	.961	.8596	.8501	.9335	.8402	.8589	
20	.9335	.9877	.961	1.0082	.9242	.9335	
21	.9795	1.0164	.9979	1.0082	.9149		
22		1.1088	1.0164	1.0534	.924		
23	1.1458	1.1643	1.0974	1.1458	.961		
24	1.2071	1.1643	1.1458	1.1706	1.1088	.9425	
Max	1.2071	1.1643	1.1458	1.1706	1.1088	.9425	.7468
Min	.7468	.823	.7964	.7947	.7577	.6722	.6908
Avg	.9719	.9884	.9510	.9743	.9016	.7803	.7170

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. II S/DN.[296] BU 4296

Substation No/ Name :- 034046 / 33KV HANUMAN NAGAR

Feeder No / Name : 202 / BHAJI BAZAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3491	1.2437	1.2936	1.3169	1.3443	1.0608	
2	1.2382	1.2071	1.2567	1.2803	1.3306	1.0242	
3	1.2012	1.1888	1.2012	1.2437	1.307	1.0059	
4	1.1643	1.1706	1.134	1.1706	1.2567	1.0059	
5	1.1157	1.134	1.0974	1.134	1.2197	.9877	
6	1.0679	1.0425	1.0791	1.0608	1.3256	.9328	
7	1.0317	1.0242	1.0498	1.0791	1.5893	.961	
8	1.0498	1.0059	1.0425	1.0719	1.6804	.9795	
9	1.086	1.0317	1.1157		1.3676	1.0164	
10							1.1016
11						1.0642	1.0456
12						1.0082	1.0456
13						.9896	.9896
14						.8589	.9709
15	1.251		1.0642	1.1763	1.0082	.8029	
16	1.3256		1.1389	1.1389	1.0269	.7842	
17	1.2323		1.1949	1.2136	1.0082	.8501	
18	1.363		1.251	1.1949	1.0642	1.0082	
19	1.363	1.3032	1.307	1.2883	1.1016	1.0829	
20	1.3817	1.3535	1.419	1.419	1.1576	1.1389	
21	1.2883	1.1888	1.2752	1.3256	1.0642		
22		1.2803	1.2382	1.3306	1.0719		
23	1.2803	1.2986	1.3169	1.3121	1.0974		
24	1.3491	1.2437	1.3169	1.1706	1.3306	1.0791	
Max	1.3817	1.3535	1.419	1.419	1.6804	1.1389	1.1016
Min	1.0317	1.0059	1.0425	1.0608	1.0082	.7842	.9709
Avg	1.2299	1.1811	1.1996	1.2182	1.2291	.9821	1.0307

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. II S/DN.[296] BU 4296

Substation No/ Name :- 034046 / 33KV HANUMAN NAGAR

Feeder No / Name : 203 / LONTEK

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.4527	.415	.4481	.4338	.3772	
2	.4338	.415	.415	.4481	.415	.3772	
3	.415	.415	.3961	.4294	.415	.3772	
4	.415	.415	.3841	.4294	.415	.3772	
5	.415	.415	.3961	.4294	.415	.3772	
6	.4715	.4904	.3961	.4904	.3018	.4338	
7	.4527	.4715	.3658	.4435	.3206	.415	
8	.3658	.4163	.3658	.3982	.4294	.3361	
9	.3582	.4298	.3841		.4435	.3174	
10							.3772
11						.3511	.4481
12						.3142	.4108
13						.3511	.4108
14						.2987	.3174
15	.4251		.2801	.3361	.3547	.2427	
16	.4854		.4108	.4108	.4066	.3734	
17	.3174		.4481	.4108	.3547	.2987	
18	.4108		.4481	.3395	.4108	.4294	
19	.3921	.3361	.3734	.3921	.3734	.3511	
20	.4294	.3961	.4294	.2614	.3961	.3921	
21	.4294	.415	.4338	.4108	.3734		
22		.415	.4527	.4338	.3961		
23	.4904	.415	.4527	.4338	.3961		
24	.4668	.4527	.3961	.4207	.4338	.3772	
Max	.4904	.4904	.4527	.4904	.4435	.4338	.4481
Min	.3174	.3361	.2801	.2614	.3018	.2427	.3174
Avg	.4237	.4234	.4023	.4092	.3939	.3584	.3929

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. II S/DN.[296] BU 4296

Substation No/ Name :- 034046 / 33KV HANUMAN NAGAR

Feeder No / Name : 204 / PAKI PURA

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3169	1.262	1.2567	1.2437	1.2437	1.0608	
2	1.134	1.2437	1.1706	1.1888	1.2254	1.0059	
3	1.0974	1.1888	1.1706	1.1706	1.2012	.9877	
4	1.0608	1.1523	1.134	1.134	1.1706	.9511	
5	1.0242	1.0608	1.0974	1.0974	1.134	.9145	
6	.9694	1.0498	1.0608	1.0608	1.2071	.8962	
7	.9671	.9955	1.0242	1.0242	1.3169	.8779	
8	.9313	.9593	.9694	.9694	1.3676	.8962	
9	.9492	1.0242	1.0425		1.2254	.9145	
10							.961
11						.9522	.9795
12							.9522
13						.9425	.8775
14						.8501	.9335
15	1.1827		1.0719	1.1273	1.0164	.7762	
16	1.1576		1.0456	1.1016	.9425	.7762	
17	1.2136		1.0349	1.0903	.9522	.7577	
18	1.1827			1.1827	.9335	.8962	
19	1.2197	1.0791	1.1317	1.1643	.9425	1.0269	
20	1.2012	1.2254	1.2012	1.2012	1.0642	1.0719	
21	1.1643	1.1523	1.134	1.2012	1.0349		
22		1.2437	1.226	1.262	1.0425		
23	1.2254	1.262	1.2936	1.2803	1.0974		
24	1.3306	1.2437	1.2437	1.2986	1.2883	1.0608	
Max	1.3306	1.262	1.2936	1.2986	1.3676	1.0719	.9795
Min	.9313	.9593	.9694	.9694	.9335	.7577	.8775
Avg	1.1293	1.1428	1.1283	1.1555	1.1266	.9271	.9407

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. II S/DN.[296] BU 4296

Substation No/ Name :- 034046 / 33KV HANUMAN NAGAR

Feeder No / Name : 205 / NEW TAJ

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3169	1.2254	1.2437	1.2803	1.2437	1.0534	
2	1.2437	1.2254	1.2071	1.2437	1.1888	1.0164	
3	1.2071	1.2071	1.1888	1.2254	1.2012	1.0059	
4	1.2071	1.1888	1.1523	1.1888	1.2071	.9877	
5	1.134	1.1706	1.1523	1.1706	1.2437	1.0059	
6	1.0791	1.1273	1.1157	1.1458	1.3169	.9979	
7	1.0425	1.0903	1.1088	1.0534	1.5546	.9328	
8	1.0608	1.0534	1.0534	1.0791	1.7177	.9709	
9	1.0791	1.1088	1.1088		1.307	1.0269	
10							1.0374
11						1.0185	.9997
12						.9431	.9808
13						.8676	.8962
14						.7922	
15	1.1883		1.0185	1.1506	.9997	.811	
16	1.358		1.1317	1.226	1.0185	.7733	
17	1.4146		1.2071	1.2449	1.0562	.811	
18	1.3392		1.2637	1.3392	1.0562	.9808	
19	1.3957	1.2803	1.3769	1.3203	1.1883	1.094	
20	1.4901	1.39	1.3957	1.4146	1.1883	1.1506	
21	1.3392	1.2567	1.2012	1.2449	1.0751		
22		1.2752	1.262	1.2936	1.0719		
23	1.2752	1.2936	1.2437	1.2752	1.0791		
24	1.363	1.2437	1.2567	1.3169	1.262	1.0608	
Max	1.4901	1.39	1.3957	1.4146	1.7177	1.1506	1.0374
Min	1.0425	1.0534	1.0185	1.0534	.9997	.7733	.8962
Avg	1.2519	1.2091	1.1941	1.2341	1.2093	.9650	.9785



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. II S/DN.[296] BU 4296

Substation No/ Name :- 034046 / 33KV HANUMAN NAGAR

Feeder No / Name : 206 / 11KV Ambadevi Feeder

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6535	.6036	.5975	.6348	.6413	.4668	
2	.5975	.5658	.5601	.5975	.5658	.4481	
3	.5601	.5658	.5281	.5601	.5658	.4527	
4	.5121	.5281	.5093	.5228	.5281	.4338	
5	.4668	.4715	.4904	.5281	.4904	.4338	
6	.4668	.4715	.4715	.4904	.4715	.3961	
7	.4294	.4338	.4527	.4338	.4338	.3734	
8	.4854	.4527	.4527	.4527	.4527	.3961	
9	.4854	.4527	.4715		.4904	.415	
10							.5121
11						.7947	.6036
12						.9328	.8779
13						.9979	1.0642
14						.9694	1.1016
15	1.3491		1.2254	.9511	1.0791	1.0164	
16	1.3443		1.2071	.8596	1.0608	1.0242	
17	1.2803		1.2254	.8048	1.0425	1.0425	
18	1.1888		1.1888	.6767	.9694	1.0425	
19	1.2254	1.2696	1.2254	.8779	1.0425	1.134	
20	1.3169	1.3817	1.3535	.8779	1.1157	1.1523	
21	1.2254	1.307	1.3443	.9511	1.0791		
22		1.0456	1.0829	.9149	.8215		
23	.7545	.7842	.8402	.8215	.6036		
24	.6722	.5853	.6219	.6584	.6979	.4904	
Max	1.3491	1.3817	1.3535	.9511	1.1157	1.1523	1.1016
Min	.4294	.4338	.4527	.4338	.4338	.3734	.5121
Avg	.8341	.7279	.8341	.7008	.7448	.7206	.8319

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. II S/DN.[296] BU 4296

Substation No/ Name :- 034046 / 33KV HANUMAN NAGAR

Feeder No / Name : 207 / 11 KV GADGADESHWER

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4805	.4572	.462	.4805	.462	.4066	
2	.462	.439	.4435	.462	.462	.3881	
3	.4435	.439	.4435	.462	.4527	.3881	
4	.4435	.4207	.4251	.439	.4527	.3658	
5	.4066	.4024	.4024	.4207	.415	.3475	
6	.3658	.3658	.3658	.3658	.3734	.3292	
7	.3258	.3361	.3109	.3326	.3326	.3109	
8	.3077	.3292	.3109	.3109	.2957	.2743	
9	.3077	.3109	.3109		.3142	.2772	
10							.2829
11						.2452	2.4331
12						.2452	.2075
13						.2263	.2241
14						.2263	.2263
15	.3584		.3395	.3961	.3018	.2263	
16	.3772		.3584	.3584	.3206	.2641	
17	.3772		.3584	.3206	.3018	.2641	
18	.3206		.3584	.3206	.3206	.2614	
19	.3018	.3109	.2987	.3395	.3395	.3018	
20	.3584	.3881	.3961	.3961	.3584	.3961	
21	.4338	.4066	.3881	.4338	.3772		
22		.4435	.439	.4572	.4066		
23	.4938	.4805	.5041	.4755	.4207		
24	.4938	.4755	.4755	.4755	.4854	.4024	
Max	.4938	.4805	.5041	.4805	.4854	.4066	2.4331
Min	.3018	.3109	.2987	.3109	.2957	.2263	.2075
Avg	.3921	.4004	.3890	.4026	.3786	.3073	.6748

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. II S/DN.[296] BU 4296

Substation No/ Name :- 034046 / 33KV HANUMAN NAGAR

Feeder No / Name : 208 / 11 KV MAHAJANPURA

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.499	.4755	.4755	.4755	.499	.4251	
2	.4805	.4755	.4755	.4805	.4805	.4066	
3	.4805	.4572	.4572	.4572	.4755	.4066	
4	.4572	.439	.439	.4572	.4572	.3841	
5	.439	.4207	.439	.439	.439	.3658	
6	.4207	.4207	.4207	.4207	.4207	.3292	
7	.362	.3734	.3881	.3881	.3734	.3292	
8	.362	.3658	.3475	.3658	.3511	.3109	
9	.3439	.3475	.3475		.3475	.3292	
10							.3206
11						.2829	.2829
12						.2641	.2452
13						.2452	.2614
14						.2452	.2641
15	.3772		.3772	.3961	.3395	.2641	
16	.3174		.3772	.3772	.3206	.2641	
17	.3584		.3584	.3584	.3206	.2829	
18	.3206		.3584	.3961	.3206	.2829	
19	.3206	.3292	.3395	.3772	.3584	.3206	
20	.415	.4207	.415	.4338	.415	.3772	
21	.4338	.439	.4251	.4904	.415		
22		.4755	.4572	.5121	.4435		
23	.5121	.5121	.462	.5121	.439		
24	.5121	.4938	.4938	.4938	.5121	.439	
Max	.5121	.5121	.4938	.5121	.5121	.439	.3206
Min	.3174	.3292	.3395	.3584	.3206	.2452	.2452
Avg	.4118	.4297	.4134	.4351	.4067	.3277	.2748

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. IIIS/DN.[297] BU 4297

Substation No/ Name :- 034041 / 33KV AKOLI S/S AMRAVATI

Feeder No / Name : 201 / SAI NAGAR Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1437	2.0538	1.8427	1.949	1.8671	.8048	.7682
2	2.0698	1.8296	1.8642	1.8625	1.7924	.7762	.7682
3	2.0144	1.7924	1.7918	1.773	1.7002	.7577	.7499
4	1.7741	1.7551	1.5565	1.5581	1.6632	.7392	.695
5	1.6632	1.386	1.3937	1.1946	1.587	.6838	.6584
6	1.5154	.9896	1.2715	1.182	1.4377	.6283	.6219
7	1.251	1.2012	1.1393	1.1462	1.2136	.5914	.5487
8	1.2136	1.1576	1.1694	1.182	1.2883	.5068	.5914
9	1.307	1.182	1.2567	1.2536	1.0642	.5487	.5487
10	1.3643	1.3969		1.4299		.5493	
11	1.448	1.4685	1.475	1.4661	1.3611	.4656	.547
12	1.5939	1.5769	1.6244	1.4661	1.2894	.4887	.4668
13	1.5947	1.6297	1.6804	2.0698	1.3432		.5228
14	1.7737	1.8099	1.7364	1.8671	1.4864	.4706	.5415
15	1.9978		1.7909	1.6991	1.4864	.462	
16	2.2032	1.8298	1.8267	1.8671	1.5043	.4938	.6036
17		1.7924	1.8446	1.6244	1.3969	.5249	.5914
18	1.7177	1.6617	1.6834	1.7541	1.4266	.5792	.5544
19	2.5393	1.6827	1.7013	1.7737		.5973	.6283
20	1.848	1.9418	1.8088	1.9605	.6036	.7682	.7865
21		2.0538	1.8267	1.9805	.6099	.7316	.7947
22	2.0328	2.0953	2.0416	2.1125		.7392	.8871
23	2.2731	2.0953	2.2207	2.1845	.8871	.8048	.961
24	2.3655	2.0452		2.1132	2.1285	.8501	.7701
Max	2.5393	2.0953	2.2207	2.1845	2.1285	.8501	.961
Min	1.2136	.9896	1.1393	1.1462	.6036	.462	.4668
Avg	1.8047	1.6707	1.6612	1.6862	1.3875	.6331	.6639

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. IIIS/DN.[297] BU 4297

Substation No/ Name :- 034041 / 33KV AKOLI S/S AMRAVATI

Feeder No / Name : 202 / RAVI NAGAR Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5423	2.4272	2.3411	2.364	2.3577	1.8839	1.8099
2	2.3529	2.3101	2.2386	2.2565	2.2405	1.7558	1.8107
3	2.2131	2.2405	2.1948	2.1491	2.1658	1.7558	1.7924
4	2.1948	2.1437	2.0119	2.0633	2.3655	1.6461	1.6827
5	2.1582	2.1068	1.9387	1.8267	2.2177	1.5912	1.6095
6	1.829	1.6448	1.701	1.6651	2.1098	1.5364	1.4449
7	1.4842	1.531	1.4815	1.4352	1.9605	1.4632	1.2803
8	1.39	1.4377	1.39	1.379	1.4563	1.2437	1.3169
9	1.4266	1.3253	1.3937	1.4506	1.419	1.3169	1.2254
10	1.885	1.3253	1.4003	1.3306	1.3611	1.3306	1.1949
11	1.9204	1.4327	1.3306	1.3394	1.3253	1.2071	1.1576
12	1.9035		1.4712	1.4118	1.3432	1.1946	
13	1.8656	1.4352	1.4784	1.5364	1.3756		1.2936
14	2.3594	1.5023	1.6244	1.7741	1.4327	1.1706	1.2696
15		1.7375	1.5939	1.848	1.4506	1.1157	
16	2.4646	1.5364	1.7193	1.6804	1.5402	1.262	1.3352
17		1.5364	1.6297	1.531	1.3611	1.1765	1.3535
18	1.5893	1.4327	1.5043	1.643		1.2803	1.3535
19	2.4646	1.6297	1.6118	1.7737	1.5939	1.5912	1.5729
20	1.9418	2.0538	1.8983	2.0748	1.848		1.829
21		2.0883	1.9342	2.2032	1.8656		1.9753
22	2.3525	2.268	2.2565	2.4646		.8596	2.1033
23	2.6139	2.5606	2.4714	2.5503	2.1033	1.829	2.3045
24	2.7252	2.524		2.5431	2.4646	1.9936	1.6095
Max	2.7252	2.5606	2.4714	2.5503	2.4646	1.9936	2.3045
Min	1.39	1.3253	1.3306	1.3306	1.3253	.8596	1.1576
Avg	2.0799	1.8361	1.7659	1.8456	1.789	1.4383	1.5602

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. IIIS/DN.[297] BU 4297

Substation No/ Name :- 034041 / 33KV AKOLI S/S AMRAVATI

Feeder No / Name : 203 / 11 Kv SATURNA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7356	.7499	.7316	.7362	.6838	.6036	.5487
2	.6584	.7316	.6348	.7087	.6468	.5658	.5121
3	.6413	.6516	.5973	.6447	.6161	.4904	.4755
4	.547	.5973	.5544	.5014	.5544	.4527	.4755
5	.4904	.5914	.5487	.5068	.5228	.415	.4572
6	.4715	.4755	.4572	.4656	.5041	.3961	.4572
7	.4572	.4938	.4755	.4706	.4805	.3961	.5121
8	.5041	.6348	.4755	.5552	.4668	.3361	.5121
9	.4163	.6516	1.2696	.5373	.439	.5228	.4755
10	.6335	.8417	1.3817	.724	.4298	.5611	.6161
11	.6653	.9313	1.475	.7421	.4525	.7023	.6161
12	.8507	.8859	.9896	.8145	.4477	.7602	.6838
13	.8413	.8328	.9055	.8501	.394		.6348
14	.7602	.8779	.8686	.8299	.4298	.5304	.6161
15		.9145	.9922	.8962	.4344	.5792	
16	.905	.9054	.9492	.9425	.4207	.5853	.7577
17		.9431	.8238	.7468	.4251	.6335	.7133
18	.7095	.7545	.6697	.7842	.4481	.6036	.6401
19	.6161	.6584	.6447	.5914	.4251	.543	.6161
20	.6036	.679	.5973		.439	.5487	.5544
21		.5415	.591	.5228	.4755	.4572	.4854
22	.6161	.5729	.6984	.6468		.439	.5415
23	.7842	.6219	.7164	.7282	.547	.5487	.6348
24	.9055	.6697		.788	.7207	.5658	.5487
Max	.9055	.9431	1.475	.9425	.7207	.7602	.7577
Min	.4163	.4755	.4572	.4656	.394	.3361	.4572
Avg	.6578	.717	.7847	.6841	.4958	.5320	.5689

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. IIIS/DN.[297] BU 4297

Substation No/ Name :- 034041 / 33KV AKOLI S/S AMRAVATI

Feeder No / Name : 204 / 11 KV AKOLI AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0354	.0343	.0343	.0362	.0343	.017	.0366
2	.0347	.0343	.0343	.0362	.0171	.017	.0366
3	.0354	.0343	.0339	.0354	.0145	.0166	.0362
4	.0354	.0343	.0343	.0532	.0162	.017	.0366
5	.0354	.0332	.0509	.0716	.0162	.0166	.0366
6	.0354	.0554	.0509	.0716	.0162	.0166	.0362
7		.0686	.0514	.0716	.0162	.0166	.0549
8	.0347	.0686	.0514	.1063	.0579	.0171	.0549
9	.0514	.0537	.0857	.1075	.0724	.0343	.0724
10	.0724	.1254		.0857	.0716	.0343	.081
11	.0549	.1075	.1109	.0857	.1075	.0343	.0829
12	.1372	.0886	.1029	.0724	.0724	.0366	
13	.1029	.1063	.1029	.0914	.0716		.056
14	.1029	.104	.1029	.0886	.0716	.0366	.0343
15	.0857	.0857	.1086	.0857	.0716	.0366	.0701
16	.0857	.0671	.1075	.0924	.0716	.0366	.0514
17		.1006	.1075	.0857	.0716	.0366	.0693
18	.1029	.0663	.1075	.0857		.0747	.0693
19	.1372	.0663	.1075	.0335	.0366	.0543	.0867
20	.124	.0701	.0716	.0343	.0366		.0554
21		.0554	.0532	.0343	.037		.052
22	.1063	.0686	.0532	.0354		.0543	.0347
23	.0343	.0514	.0537	.0343	.017	.0549	.0347
24		.0343		.0179	.0343	.017	.0549
Max	.1372	.1254	.1109	.1075	.1075	.0747	.0867
Min	.0343	.0332	.0339	.0179	.0145	.0166	.0343
Avg	.0722	.0673	.0735	.0647	.0469	.0322	.0536

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. IIIS/DN.[297] BU 4297

Substation No/ Name :- 034041 / 33KV AKOLI S/S AMRAVATI

Feeder No / Name : 205 / DATTA VIHAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0349	.9795	.8962	.8954	.9335	.7762	.7865
2	.9511	.924	.8779	.8596	.8871	.7392	.7865
3	.8871	.8775	.8413	.8238	.8589	.7207	.7783
4	.8501	.8402	.8048	.788	.8131	.7023	.6584
5	.8131	.8501	.7682	.7522	.7655	.6653	.6036
6	.7392	.6722	.6219	.6878	.7392	.6283	.5487
7	.6653	.5914	.6219	.5731	.5975	.6283	.5853
8	.6401	.6161	.5792	.6089	.6283	.6283	.5853
9	.6584	.6268	.5973	.6335	.6348	.5914	.6767
10	1.6095	.6984	.6283	.7207	.6984	.5973	.7682
11	1.6461	.7442	.6838	.724	.7343	.5611	.7468
12	1.829	.7701	.6653	.7421	.7964	.5792	.823
13	1.8656	.8059	.7095	.8501			.7842
14	2.268	.8779	.7655	1.2197	.7602	.567	.7762
15	2.4025	.9145	.8326	.8775	.7164	.6401	.9511
16	2.6513	.8048	.8417		.7522	.695	.7577
17		.7865	.8328	.7468	.6089	.695	.811
18	.3734	.6516	.7522	.7282		.7095	.7499
19	.3734	.7421	.8059	.924	.7655	.8779	.8779
20	.9055	.8131	.8596	.8215	.8871	.8779	.9979
21		.924	.9671	.9149	.8413	.8413	.8596
22	.9709	.9145	.8954	1.1203		.8507	1.0059
23	1.0719	1.086	.9568	1.0456	.8686	.7682	1.0791
24	1.2012	.9877		.9492	1.2883	.8131	.7865
Max	2.6513	1.086	.9671	1.2197	1.2883	.8779	1.0791
Min	.3734	.5914	.5792	.5731	.5975	.5611	.5487
Avg	1.2003	.8125	.7741	.8264	.7893	.7023	.7827



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. IIIS/DN.[297] BU 4297

Substation No/ Name :- 034041 / 33KV AKOLI S/S AMRAVATI

Feeder No / Name : 206 / 11 Kv MHADA FEEDER Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1734	.1097	.1715	.1791	.1848	.1052	.1097
2	.1772	.1294	.1715	.1791	.1663	.1052	.1097
3	.156	.1663	.1696	.1791	.1646	.1227	.1097
4	.156	.1663	.1543	.1612	.1494	.2629	.1097
5	.1387	.1463	.1372	.1448	.1109	.1402	.1097
6	.12	.1478	.1543	.1433	.1109	.12	.128
7	.1029	.1478	.1372	.1254	.1097	.0857	.1478
8	.1029	.1494	.1372	.1254	.1029	.12	.1463
9	.12	.1402	.1372	.1086	.128	.12	.128
10	.12	.1254	.1494	.1029	.1448	.1402	.0732
11	.12	.124	.0924		.1254	.1029	.0857
12	.1029	.1075	.0747	.1029	.1267	.1086	.056
13	.1029	.1254	.1109	.1029	.1254		.0686
14	.1372	.12	.1097	.1402	.1075	.0914	.1063
15		.12	.1075	.112	.1433	.1086	.1029
16	.1029	.0663	.1086	.112	.1254	.1097	.0857
17		.0995	.1267	.1478	.1267	.0914	.0848
18	.1029	.0819	.1254	.112		.0914	.1017
19	.0934	.0983	.1075	.1341	.124	.2195	.1017
20	.1417	.1017	.1433	.1267	.128	.128	.0905
21		.0972	.1612	.1097	.1448	.128	.1357
22	.1829	.1017	.1267	.1848		.1463	.1029
23	.1848	.1696	.1433	.168	.1402	.1267	.1543
24	.1734	.1715		.1791	.168	.1402	.1086
Max	.1848	.1715	.1715	.1848	.1848	.2629	.1543
Min	.0934	.0663	.0747	.1029	.1029	.0857	.056
Avg	.1339	.1256	.1329	.1383	.1344	.1267	.1066

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. IIIS/DN.[297] BU 4297

Substation No/ Name :- 034041 / 33KV AKOLI S/S AMRAVATI

Feeder No / Name : 207 / 11 Kv KALIMATA FEEDER Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.3109	.2896	.3224	.3734	.3174	.3109
2	.3174	.3174	.3109	.3224	.2772	.2987	.3109
3	.2987	.3142	.3475	.3224	.2587	.2801	.3109
4	.3361	.3142	.3258	.2865	.2957	.2801	.2926
5	.2987	.2614	.2715	.2865	.2743	.2614	.2743
6	.2614	.2614	.2534	.2481	.2561	.2614	.2561
7	.2241	.2427	.2172	.2149	.2195	.2614	.2012
8	.2614	.2218	.2149	.2686	.2058	.2054	.1463
9	.1867	.3582	.3292	.2686	.3734	.2987	.2378
10	.2012	.4252	.2957	.3077	.394	.2715	.2572
11	.2195	.4298	.3734	.3109	.3077	.3696	.2915
12	.3109	.3898	.4668	.2926	.362	.3801	.1478
13	.3077	.333	.4435	.2926	.4119		.823
14	.3077	.4108	.4108	.3982	.2507	.2561	.2195
15	.3361	.4854	.4477	.4294	.2507	.2926	.3734
16	.3734	.3544		.3921	.3045	.3475	.2987
17		.4607	.5552		.3045	.2743	.4251
18	.3475	.4344		.3109		.2743	.4435
19	.3696	.4108	.4656	.3584	.4572	.4207	.4251
20	.3395	.4854	.4961	.3772	.4755	.3658	.3961
21		.4344	.3224	.462	.3658	.3658	.3142
22	.3547	.4024	.394	.3734		.2926	.3547
23	.3696	.3658	.362	.3174	.4108	.2743	.3547
24	.3547	.3109		.3582	.3174	.3361	.2896
Max	.3734	.4854	.5552	.462	.4755	.4207	.823
Min	.1867	.2218	.2149	.2149	.2058	.2054	.1463
Avg	.3051	.3640	.3616	.3270	.3249	.3037	.3231

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. IIIS/DN.[297] BU 4297

Substation No/ Name :- 034079 / 33 KV MIDC

Feeder No / Name : 204 / EKVIRADEVI

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		1.6004			1.4403	1.5051	1.3717
8	1.5604			1.5432			
12				1.7337			
14		2.2672					
15						1.6004	
16				2.0195			
18	2.0195	1.9243					
20		2.2862	2.21	2.1148			
21	2.3243						
22	2.572		2.3815	2.4387			
24	3.0483	2.5911		2.4177	2.5158		1.8347
Max	3.0483	2.5911	2.3815	2.4387	2.5158	1.6004	1.8347
Min	1.5604	1.6004	2.21	1.5432	1.4403	1.5051	1.3717
Avg	2.3049	2.1338	2.2958	2.0446	1.9781	1.5528	1.6032

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. IIIS/DN.[297] BU 4297

Substation No/ Name :- 034079 / 33 KV MIDC

Feeder No / Name : 205 / DASTUR NAGAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		.9145			.7888	.8573	.7716
8	.4908			.8383			
12				.9145			
14		.9335					.743
15						.6859	
16				.9717			
18	.8192	.8192					
20		1.1431	1.0479	1.105			
21	1.1431						
22	1.3146		1.3146	1.2955			
24	1.6575	1.467		1.286	1.3112		.9602
Max	1.6575	1.467	1.3146	1.2955	1.3112	.8573	.9602
Min	.4908	.8192	1.0479	.8383	.7888	.6859	.743
Avg	1.0850	1.0555	1.1813	1.0685	1.05	.7716	.8249

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. IIIS/DN.[297] BU 4297

Substation No/ Name :- 034079 / 33 KV MIDC

Feeder No / Name : 206 / GOPAL NAGAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		.6668			.6024	.5716	.5138
8	.5658			.6287			
12				.6859			
14							.6097
15						.4954	
16				.7049			
18	.6287	.6287					
20		.8954	.8002	.8764			
21	.9145						
22	1.0288		.9526	.9907			
24	1.1241	1.0669		.9088	.9088		.703
Max	1.1241	1.0669	.9526	.9907	.9088	.5716	.703
Min	.5658	.6287	.8002	.6287	.6024	.4954	.5138
Avg	.8524	.8145	.8764	.7992	.7556	.5335	.6088

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. IIIS/DN.[297] BU 4297

Substation No/ Name :- 034079 / 33 KV MIDC

Feeder No / Name : 208 / 11 KV Rajapeth

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		1.8671			1.5947	1.6575	1.5415
8	1.5947						
12				1.9624			
14		2.1148					1.7147
15						1.5623	
16				2.1338			
18	2.0005	1.9243					
20		2.3815	2.2862	2.3243			
21	2.4768						
22	2.6673		2.553	2.6482			
24	3.0864	2.9912		2.5892	2.5034		1.9547
Max	3.0864	2.9912	2.553	2.6482	2.5034	1.6575	1.9547
Min	1.5947	1.8671	2.2862	1.9624	1.5947	1.5623	1.5415
Avg	2.3651	2.2558	2.4196	2.3316	2.0491	1.6099	1.7370

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. IIIS/DN.[297] BU 4297

Substation No/ Name :- 034079 / 33 KV MIDC

Feeder No / Name : 209 / 11 KV Yashoda nagar

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		1.6385			1.4575	1.5242	1.4175
8	1.4661						
12				1.6194			
14		1.7528					1.4289
15						1.2193	
16				1.8671			
18	1.5813	1.4289					
20		2.1148	2.0386	2.0195			
21	2.2291						
22	2.5149		2.3434	2.4958			
24	2.8197	2.5911		2.2805	2.371		1.7194
Max	2.8197	2.5911	2.3434	2.4958	2.371	1.5242	1.7194
Min	1.4661	1.4289	2.0386	1.6194	1.4575	1.2193	1.4175
Avg	2.1222	1.9052	2.191	2.0565	1.9143	1.3718	1.5219

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. IIIS/DN.[297] BU 4297

Substation No/ Name :- 034079 / 33 KV MIDC

Feeder No / Name : 210 / 11 KV Bhuvaneshwary  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		.362			.2915	.4001	.3429
8	.3012						
12				.8573			
14		.4572					.4763
15						.724	
16				.8383			
18	.4763	.6287					
20		.362	.362	.4763			
21	.3239						
22	.3239		.3429	.4191			
24	.3429	.3239		.3086	.4163		.4115
Max	.4763	.6287	.362	.8573	.4163	.724	.4763
Min	.3012	.3239	.3429	.3086	.2915	.4001	.3429
Avg	.3536	.4268	.3525	.5799	.3539	.5621	.4102



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. IIIS/DN.[297] BU 4297

Substation No/ Name :- 034079 / 33 KV MIDC

Feeder No / Name : 211 / MIDC-I ( NEW )

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		1.5051			1.3032	1.3527	1.2174
8	1.3375			1.5051			
12				1.5242			
14		1.6194					1.2384
15						1.1622	
16				1.8671			
18	1.6194	1.4861					
20		1.8861	1.829	2.0195			
21	1.9433						
22	2.2291		2.0005	2.2672			
24	2.8769	2.572		2.2805	2.2502		1.6832
Max	2.8769	2.572	2.0005	2.2805	2.2502	1.3527	1.6832
Min	1.3375	1.4861	1.829	1.5051	1.3032	1.1622	1.2174
Avg	2.0012	1.8137	1.9148	1.9106	1.7767	1.2575	1.3797

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. IIIS/DN.[297] BU 4297

Substation No/ Name :- 034079 / 33 KV MIDC

Feeder No / Name : 212 / MIDC-II ( NEW )

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		1.2574			1.0288	1.0098	1.046
8	1.086			1.2765			
12				2.1338			
14		1.7337					1.9052
15						1.829	
16				2.4196			
18	2.0195	1.9433					
20		1.448	1.5051	1.4861			
21	1.2003						
22	1.1241		1.3146	1.3908			
24	1.3527	1.1622		1.406	1.4661		1.3643
Max	2.0195	1.9433	1.5051	2.4196	1.4661	1.829	1.9052
Min	1.086	1.1622	1.3146	1.2765	1.0288	1.0098	1.046
Avg	1.3565	1.5089	1.4099	1.6855	1.2475	1.4194	1.4385

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. IIIS/DN.[297] BU 4297

Substation No/ Name :- 034079 / 33 KV MIDC

Feeder No / Name : 213 / MIDC-III ( NEW )

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		1.829			1.6804	1.6766	1.4918
8	1.5947			1.7909			
12				1.848			
14		2.4577					1.7147
15						1.5051	
16				2.2481			
18	1.9433	1.8671					
20		2.4006	2.3243	2.3815			
21	2.572						
22	2.8006		2.6101	2.7435			
24	3.4865	3.2579		2.8807	2.8172		1.989
Max	3.4865	3.2579	2.6101	2.8807	2.8172	1.6766	1.989
Min	1.5947	1.829	2.3243	1.7909	1.6804	1.5051	1.4918
Avg	2.4794	2.3625	2.4672	2.3155	2.2488	1.5909	1.7318

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. IIIS/DN.[297] BU 4297

Substation No/ Name :- 038012 / 220KV KONDESHWAR S/S

Feeder No / Name : 201 / 11 KV MADHAVI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-17	23-JUN-17	25-JUN-17	26-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.2003	1.2346	1.4289	1.286	1.2689
Max	1.2003	1.2346	1.4289	1.286	1.2689
Min	1.2003	1.2346	1.4289	1.286	1.2689
Avg	1.2003	1.2346	1.4289	1.286	1.2689

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. IIIS/DN.[297] BU 4297

Substation No/ Name :- 038012 / 220KV KONDESHWAR S/S

Feeder No / Name : 202 / KRISHIDEV

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	25-JUN-17	26-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.4973	.5144	.5716	.5144	.1372
Max	.4973	.5144	.5716	.5144	.1372
Min	.4973	.5144	.5716	.5144	.1372
Avg	.4973	.5144	.5716	.5144	.1372

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. IIIS/DN.[297] BU 4297

Substation No/ Name :- 038012 / 220KV KONDESHWAR S/S

Feeder No / Name : 203 / BADNERA OT

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	25-JUN-17	26-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.749	1.9204	1.9814	1.7833	1.1317
Max	1.749	1.9204	1.9814	1.7833	1.1317
Min	1.749	1.9204	1.9814	1.7833	1.1317
Avg	1.749	1.9204	1.9814	1.7833	1.1317

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

AMARAVATI URBAN DIVSION[161]

AMRAVATI U. IIIS/DN.[297] BU 4297

Substation No/ Name :- 038012 / 220KV KONDESHWAR S/S

Feeder No / Name : 204 / BADNERA NT

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	25-JUN-17	26-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.1372	.1372	.1524	.1372	.1372
Max	.1372	.1372	.1524	.1372	.1372
Min	.1372	.1372	.1524	.1372	.1372
Avg	.1372	.1372	.1524	.1372	.1372

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

CHANDUR BAZAR[311]

BU 1643

Substation No/ Name :- 034037 / 33KV GHATLADKI

Feeder No / Name : 201 / 11KV GHATLADKI

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5144	.2401				
2	.5658	.5144	.2401				
3	.6173	.5144	.2572				
4	.6173	.5487	.2572				
5	.6859	.3772	.3086				
6	.7545	.6001	.3601				
7	.8916	.7716	.3772				
8	.9431	1.0288	.3772				
9	.9774	1.046	.4287				
10				.6859	.6001		.7716
11				.8402	.7202		.703
12				.8573	.9088	.7545	.6859
13				.8573	.8745	.7545	.6859
14				.8402	.7202	.1372	.7202
15				.823	.2058	.1372	.7202
16				.823	.1543	.1372	.7373
17				.8402	.12	.1372	.7716
24	.4287	.463	.2401				
Max	.9774	1.046	.4287	.8573	.9088	.7545	.7716
Min	.4287	.3772	.2401	.6859	.12	.1372	.6859
Avg	.6996	.6379	.3087	.8209	.5380	.3430	.7245



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

CHANDUR BAZAR[311]

BU 1643

Substation No/ Name :- 034037 / 33KV GHATLADKI

Feeder No / Name : 202 / 11KV BRAMHANWADA THADI

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2401	.2401	.2401
2				.2401	.2401	.2229
3				.2572	.2572	.2058
4				.2915	.2572	.2401
5				.3258	.3258	.2743
6				.3772	.4287	.3258
7				.4801	.5144	
8				.5487	.583	
9				.6001	.5487	.0343
10	.3429	.7202	.3772			
11	.5316	.5487	.3601			
12	.4973	.463	.3258			
13	.1715	.4115	.3258			
14	.3772	.4287	.3086			
15	.4115	.2401	.2743			
16	.4115	.0686	.2743			
17	.4115		.2743			
24				.2401	.2058	.2401
Max	.5316	.7202	.3772	.6001	.583	.3258
Min	.1715	.0686	.2743	.2401	.2058	.0343
Avg	.3944	.4115	.3151	.3601	.3601	.2229

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

CHANDUR BAZAR[311]

BU 1643

Substation No/ Name :- 034037 / 33KV GHATLADKI

Feeder No / Name : 203 / 11KV VISHROLI

Only one consumer of WW with HT-IV

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0223	.0206	.0171	.0206	.024	.024	.012
2	.0223	.0206	.0171	.0206	.024	.024	.0137
3	.024	.0206	.0154	.0189	.0206	.0206	.0137
4	.0223	.0206	.0154	.0189	.0206	.0206	.0137
5	.0206	.0171	.0171	.0171	.0154	.024	.0154
6	.0206	.0154	.0206	.0171	.012	.0206	.0154
7	.012	.0137	.0206	.012	.012		.0051
8	.0154	.012	.0171	.012	.0086		.012
9	.0171	.0171	.0154	.0103	.0086		.0103
10	.0171	.0154	.0206	.012	.0103		.0051
11	.0171	.0154	.0103	.0137	.012	.012	.0086
12	.0171	.0171	.0206	.0137	.0103	.0171	.012
13	.0171	.0154	.0171	.0103	.0103	.0171	.0086
14	.0137	.0086	.0171	.0103	.0103	.0103	.0103
15	.0154	.0171	.0171	.0137	.0103	.0103	.012
16	.0154	.0154	.0171	.0206	.0103	.012	.0103
17	.0171	.0086	.0206	.0137	.0154	.012	.0206
18	.0154	.0103	.0206	.0154	.0171	.0137	.012
19	.0206	.0103	.0206	.0171		.0206	.0137
20	.0206	.012	.0223	.0171		.0171	.0154
21	.0206	.0206	.024	.0171		.0206	.0154
22		.0206	.024	.0206	.0154	.0309	.0206
23	.024	.0171	.024	.0206	.0154	.012	.0206
24	.024	.024	.012	.0206	.0171	.012	.012
Max	.024	.024	.024	.0206	.024	.0309	.0206
Min	.012	.0086	.0103	.0103	.0086	.0103	.0051
Avg	.0188	.0161	.0185	.016	.0143	.0176	.0129

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

CHANDUR BAZAR[311]

BU 1643

Substation No/ Name :- 034037 / 33KV GHATLADKI

Feeder No / Name : 204 / BRAMHANWADA THADI -  
GAOTHAN- Feeder KV- 11 /  
OUTGOING

Gaothan Feeder

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.8573	.7545	.9259	.9259	.823	.823
2	.7888	.8573	.7202	.8916	.9259	.7888	.7888
3	.7545	.823	.6859	.8916	.8916	.7888	.7545
4	.703	.823	.6859	.8745	.8916	.7545	.7373
5	.6687	.8059	.7202	.7716	.8573	.7202	.7202
6	.6173	.6687	.6687	.7202	.703	.703	.7373
7	.5487	.6173	.6687	.6687	.7545		.6516
8	.5658	.583	.6516	.6516	.8402		.6687
9	.5487	.583	.6516	.6344	.7716		.6344
10	.5316	.6001	.0206	.6687	.703		.6516
11	.3772	.6173	.6516	.6687	.6516	.5487	.5658
12	.6173	.6687	.6859	.6516	.6173	.3772	.5658
13	.6344	.6687	.7202	.7202	.583	.583	.6344
14	.7202	.6859	.7373	.7202	.5487	.6344	.6859
15	.7202	.6687	.7545	.7202	.5487	.6173	.6859
16	.703	.6516	.7202	.703	.583	.6001	.6516
17	.6859	.6344	.6859	.6344	.5487	.5658	.583
18	.6173	.6344	.703	.7716	.583	.583	.583
19	.6344	.6516	.7202	.7545		.703	.6859
20	.6859	.7888	.8573	.8916	.7202	.8573	.8059
21	.8402	.8745	.8402	.9259	.7545	.823	.8059
22		.8745	.8745	.9259	.7716	.8402	.8402
23	.8916	.8573	.8916	.9259	.7716	.823	.8402
24	.8916	.8916	.8573	.9431	.9431	.823	.8402
Max	.8916	.8916	.8916	.9431	.9431	.8573	.8402
Min	.3772	.583	.0206	.6344	.5487	.3772	.5658
Avg	.6784	.7244	.7053	.7773	.7343	.6979	.7059

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

CHANDUR BAZAR[311]

BU 1643

Substation No/ Name :- 034037 / 33KV GHATLADKI

Feeder No / Name : 205 / 11KV GHATLADKI GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7888	.7716	.8573	.7373	.7545	.7545	.703
2	.7545	.7716	.823	.7373	.7545	.7545	.6516
3	.6859	.7545	.823	.7202	.7373	.7202	.6859
4	.6859	.7545	.7202	.6859	.7373	.6859	.6859
5	.6173	.7202	.6859	.6859	.7202	.6173	.6516
6	.6001	.6173	.6173	.6173	.7202	.583	.6173
7	.583	.583	.5487	.5658	.6516		.703
8	.5487	.5487	.5487	.5144	.583		.6344
9	.5144	.5144	.5487	.463	.5487		.5487
10	.5658	.4801	.6344	.4287	.5144	.4458	.4973
11	.6173	.5144	.6001	.4287	.5144	.3772	.463
12	.6173	.6173	.5144	.4458	.4801	.3944	.4287
13	.6344	.5487	.5487	.6173	.4973	.3944	.4801
14	.6687	.6173	.6001	.6173	.4115	.4115	.463
15	.6859	.4973	.6173	.6001	.4458	.3772	.4801
16	.6001	.4287	.6173	.583	.4115	.3258	.463
17	.6687	.4287	.6001	.583	.4801	.3772	.463
18	.4973	.583	.583	.7202	.5487	.6173	.5144
19	.6687	.6344	.6859	.6859	.6173	.6173	.7202
20	.823	.7888	.7202	.7545	.6516	.7716	.7545
21	.7888	.823	.7202	.7716	.6687	.7373	.7716
22		.8402	.7545	.823	.703	.7716	.7545
23	.7888	.8059	.7716	.7716	.6687	.7373	.7373
24	.823	.7888	.7545	.7545	.7545	.6173	.6859
Max	.823	.8402	.8573	.823	.7545	.7716	.7716
Min	.4973	.4287	.5144	.4287	.4115	.3258	.4287
Avg	.6620	.6430	.6623	.6380	.6073	.5756	.6066

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

CHANDUR BAZAR[311]

BU 1643

Substation No/ Name :- 034037 / 33KV GHATLADKI

Feeder No / Name : 206 / Redwa Ag Feeder

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3944	.4115	.2058				
2	.3944	.4287	.2058				
3	.4115	.4287	.2229				
4	.4115	.4458	.2058				
5	.5144	.4458	.2401				
6	.6859	.4287	.2743				
7	.7545	.6687	.2915				
8	.8059	.7202	.3086				
9	.8402	.7202	.3601				
10				.2572	.2058	.2058	.1372
11				.3429	.2401	.2058	
12				.3601	.3086	.0343	
13				.3429	.3429	.0343	
14				.4115	.2058	.0343	.12
15				.3429		.0343	.1029
16				.3086		.0343	.1029
17				.3429		.0343	.1029
24	.3772	.4287	.2058				
Max	.8402	.7202	.3601	.4115	.3429	.2058	.1372
Min	.3772	.4115	.2058	.2572	.2058	.0343	.1029
Avg	.5590	.5127	.2521	.3386	.2606	.0772	.1132

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

CHANDUR BAZAR[311]

BU 1643

Substation No/ Name :- 034043 / 33KV JAWALA

Feeder No / Name : 201 / 11KV THUGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3466		
2		1.3466		
3		1.3289		
4		1.3112		
5		1.2757		
6		1.258		.4344
7		1.4175		.3658
8		1.5061		.2926
9		1.4352	.2481	.2896
10		1.4529	.3391	.6104
11	.3721	1.4883	.362	.7087
12	.3189		.362	.7619
13	.3544			.6733
14	.3366		.362	.8682
15	.3366		.3222	.8859
16	.3366			.7796
17	.3544		.3988	.8859
18	.3721		.3292	.3189
19	.4075		.4755	.4075
20	.5493		.543	.5493
21	.5847		.5792	.5316
22	.5847			.5316
23	.567			.5316
24		1.3466		
Max	.5847	1.5061	.5792	.8859
Min	.3189	1.258	.2481	.2896
Avg	.4211	1.3761	.3928	.5793

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

CHANDUR BAZAR[311]

BU 1643

Substation No/ Name :- 034043 / 33KV JAWALA

Feeder No / Name : 202 / 11KV HAIDATPUR

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1638		
2		.1475		
3		.1475		
4		.1311		
5		.1311		
6		.1147		.7545
7		.0655		1.0227
8		.0655		1.1603
9		.0655	.7373	1.2431
10		.0655	.1063	.0732
11	.639	.0655	.0914	.0655
12	.6226		.0732	.0655
13	.5571			.0819
14	.6226		.0732	.0819
15	.5898		.0914	
16	.5735		.0732	.0819
17	.5079		.0732	.0655
18	.0819		.0914	.0655
19	.0983		.1097	.0983
20	.1638		.1463	.1311
21	.1475		.1463	.1475
22	.1638			.1638
23	.1638			.1638
24		.1638		
Max	.639	.1638	.7373	1.2431
Min	.0819	.0655	.0732	.0655
Avg	.3794	.1106	.1511	.3215

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

CHANDUR BAZAR[311]

BU 1643

Substation No/ Name :- 034043 / 33KV JAWALA

Feeder No / Name : 203 / 11KV NIMBHORA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4001		
2		.4001		
3		.3841		
4		.3841		
5		.4001		
6		.4161		.128
7		.5441		.0914
8		.5441		.0732
9		.6722	.08	.0732
10		.8002	.3201	.3944
11	.08	.8322	.2715	.5281
12	.096		.2353	.5281
13	.112			.5441
14	.112		.2534	.5281
15	.096		.2401	.5441
16	.08		.2743	.6401
17	.08		.2743	.6562
18	.096		.1097	.08
19	.096		.1463	.112
20	.16		.2012	.176
21	.2241		.2195	.192
22	.144			.2241
23	.208			.208
24		.4001		
Max	.2241	.8322	.3201	.6562
Min	.08	.3841	.08	.0732
Avg	.1219	.5148	.2188	.3178



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

CHANDUR BAZAR[311]

BU 1643

Substation No/ Name :- 034043 / 33KV JAWALA

Feeder No / Name : 204 / 11 KV TALWEL (33 KV  
JAWALA) Feeder KV- 11 /  
OUTGOING

Single Phasing Feeders

DATE	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8779		
2		.8779		
3		.8413		
4		.8048		
5		.7499		
6		.6401		.763
7		.4805		.8718
8		.439		1.0059
9		.4207	.8383	1.0277
10		.4755	.2263	.3734
11	1.5565	.4854	.2801	.2715
12	1.4563		.3547	.3292
13	1.3923			.3258
14	1.3441		.3361	.3582
15	1.3279		.3361	.4572
16	1.2308		.2801	.5068
17	1.004		.2241	.3801
18			.4108	.3511
19	.5487		.5544	.5544
20	.7316		.6722	.7602
21	1.0425		.7095	.8048
22	.9145			.8869
23	.905			.9145
24		.8962		
Max	1.5565	.8962	.8383	1.0277
Min	.5487	.4207	.2241	.2715
Avg	1.1212	.6658	.4352	.6079

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

CHANDUR BAZAR[311]

BU 1643

Substation No/ Name :- 034043 / 33KV JAWALA

Feeder No / Name : 205 / 11KV JAWALA NEW

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8619		
2		.8453		
3		.8192		
4		.8192		
5		.8192		
6		.8029		.2801
7		1.0526		.1867
8		1.1822		.168
9		1.3123	.132	.1867
10		1.0242		1.3748
11	.0724	.9922	1.166	1.7236
12	.2896		1.4575	1.6446
13	.2743			1.3916
14	.3077		1.4582	1.5497
15	.2715		1.4752	1.692
16	.2896		1.6244	1.692
17	.2378		1.6385	1.8138
18	.2561		.2427	.1867
19	.2772		.2801	.2402
20	.3439		.3361	.3511
21	.4024		.3734	.3658
22	.4163			.4066
23	.3982			.4251
24		.8817		
Max	.4163	1.3123	1.6385	1.8138
Min	.0724	.8029	.132	.168
Avg	.2952	.9511	.9258	.8711

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

CHANDUR BAZAR[311]

BU 1643

Substation No/ Name :- 034043 / 33KV JAWALA

Feeder No / Name : 206 / 11KV KURAL NEW

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5853		
2		.5853		
3		.567		
4		.5487		
5		.5121		
6		.4572		.9389
7		.3921		1.0898
8		.2926		1.1904
9		.3439	1.004	1.2763
10		.3439		.3361
11	2.2885	.3429	.3361	.2715
12	2.0645		.2987	.2926
13	2.0165			.362
14	2.1125		.2801	.3982
15	1.9433		.3547	.439
16	1.9685		.3361	.4024
17	1.9364		.2987	.3366
18	.3658		.3921	.2926
19	.3921		.4108	.8048
20	.543		.5975	.8048
21	.5973		.6348	.5914
22	.6268			.6697
23	.6219			.6154
24		.5973		
Max	2.2885	.5973	1.004	1.2763
Min	.3658	.2926	.2801	.2715
Avg	1.3444	.4640	.4494	.6174

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

CHANDUR BAZAR[311]

BU 1643

Substation No/ Name :- 034052 / 33 KV MADHAN

Feeder No / Name : 201 / 11 KV MADHAN GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2353	.2454	.2534	.2195	.2454	.1886	.1991
2	.2353	.2279	.2534	.2195	.2454	.1886	.1991
3	.2353	.2279	.2534	.2012	.2279	.1886	.1991
4	.2353	.2279	.2534	.2012	.2279	.1886	.181
5	.2195	.2279	.2378	.2075	.2279	.1886	.181
6	.1829	.1753	.2012	.1646	.1578	.1543	.1646
7	.1646	.1402	.1646	.128	.1578	.1372	.1463
8	.1372	.1402	.1646	.128	.1402	.1372	.128
9	.128	.1578	.1829	.128	.1052	.12	.1463
10	.1294	.1578	.1646	.128	.1402	.12	.1097
11	.7537	.1578	.1886	.1227	.1372	.1294	.128
12	1.2269	.1991	.1829	.1578	.1543	.1109	.128
13	1.5074	.2172	.2378	.1753	.1372	.128	.1463
14	1.2094	.2012	.2378	.1928	.0934	.1463	.1646
15	1.4198	.1829	.2195	.1578	.12	.1463	.1646
16	.964	.1829	.1829	.1402	.12	.1463	.1646
17	.8855	.1478	.1463	.1236	.1029	.128	.128
18	.1227	.1646	.1463	.1402	.12	.128	.128
19	.1402	.2012	.1463	.1402	.12	.1646	.1463
20	.1928	.2686	.1829	.1928	.1886	.2172	.2195
21	.1928	.2686	.2012	.2279	.2058	.1991	.2378
22	.2372	.2686	.2012	.2279	.2058	.2172	.2378
23	.2372	.2715	.2195	.2454	.2058	.2172	.2378
24	.2715	.2454	.2686	.2195	.2454	.2058	.1991
Max	1.5074	.2715	.2686	.2454	.2454	.2172	.2378
Min	.1227	.1402	.1463	.1227	.0934	.1109	.1097
Avg	.4693	.2044	.2038	.1746	.1680	.1623	.1702

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

CHANDUR BAZAR[311]

BU 1643

Substation No/ Name :- 034052 / 33 KV MADHAN

Feeder No / Name : 202 / 11 KV B'THADI AG/MADHAN

Ag dominated/Pure Ag

S/S Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.096	.0457	.0554
2				.0949	.0457	.0554
3				.1107	.0457	.0554
4				.1107	.0457	.0739
5				.1107	.0457	.0924
6				.2214	.0457	.1109
7				.3479	.0762	.2012
8				.3795	.061	.2328
9					.0914	.2686
10	.2915	.4111	.037			
11	.4207	.4428	.2294			
12	.4111	.4801				
13	.4428	.5144				
14	.4111	.4458	.5571			
15	.4428	.4801	.5898	.3048		
16	.4111	.5144	.6226			
17	.4428		.5571			
24				.096	.0457	.0554
Max	.4428	.5144	.6226	.3795	.0914	.2686
Min	.2915	.4111	.037	.0949	.0457	.0554
Avg	.4092	.4698	.4322	.1873	.0549	.1201

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

CHANDUR BAZAR[311]

BU 1643

Substation No/ Name :- 034052 / 33 KV MADHAN

Feeder No / Name : 203 / 11 KV BRAMHANWADA PATHAK

Ag dominated/Pure Ag

AG Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3479	.4115				
2		.3479	.4115				
3		.3605	.4115				
4		.3479	.3944				
5		.3321	.4458				
6		.4111	.4801				
7		.5693	.6299				
8		.7274	.7701				
9	.181	.7274	.7701				
10				.6718			.2743
11				.7116	.4801	.1629	.3277
12				.8223	.4801	.1267	.3441
13				.7748	.4268	.1448	.3277
14				.7274	.2934	.1629	.2949
15				.4744	.2667	.1629	.3113
16				.4744		.181	.3932
17				.4744		.1991	.3277
24	.2328	.3479					
Max	.2328	.7274	.7701	.8223	.4801	.1991	.3932
Min	.181	.3321	.3944	.4744	.2667	.1267	.2743
Avg	.2069	.4519	.5250	.6414	.3894	.1629	.3251

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI I S/DN[313]

BU 1660

Substation No/ Name :- 034018 / 33KV ASTEGAON

Feeder No / Name : 201 / 11KV Khanapur AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.2347		.2012
2					.2347		.2012
3					.2347		.2012
4					.2347		.2012
5					.2347		.2012
6					.2012		.2012
7							.3856
8					.2347		.4191
9					.5365	.0503	.3688
10			.8383			.0503	
11	.1006		.8718			.0503	
12	.3185	.6539	.8718			.0503	
13	.3353	.6539	.8886				
14	.1174	.1677	.6874	.1389			
15	.6036	.6371	.6874				
16	.5868	.6203	.6874	.218			
17	.7209	.6371	.7042	.5365			
24					.2347		.1844
Max	.7209	.6539	.8886	.5365	.5365	.0503	.4191
Min	.1006	.1677	.6874	.1389	.2012	.0503	.1844
Avg	.3976	.5617	.7796	.2978	.2645	.0503	.2565

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI I S/DN[313]

BU 1660

Substation No/ Name :- 034018 / 33KV ASTEGAON

Feeder No / Name : 202 / 11KV TARODA (KHED) AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4969	1.3426				
2	1.4969	1.3426				
3	1.4969	1.3426				
4	1.4815	1.3426				
5	1.4815	1.3889				
6	1.4815	1.4661				
7	1.7593	1.5895				
8	1.821	1.8519				
9	1.8056	1.6821				
10			1.7284	1.7438		1.4969
11			2.1451	2.1605	.6636	1.713
12			***	1.9444		1.7747
13			1.7284	1.8364		1.821
14				1.5741	1.4661	1.8056
15				1.5123	1.5586	1.7593
16				1.0802	1.5432	1.821
17					1.5123	1.8982
24	1.5586	1.3426				
Max	1.821	1.8519	47.3457	2.1605	1.5586	1.8982
Min	1.4815	1.3426	1.7284	1.0802	.6636	1.4969
Avg	1.5880	1.4692	13.2369	1.6931	1.3488	1.7612



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI I S/DN[313]

BU 1660

Substation No/ Name :- 034018 / 33KV ASTEGAON

Feeder No / Name : 203 / 11KV Ambada AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5117	.1505				
2	.4666	.1505				
3		.1505				
4		.1505				
5		.1505				
6	.4515	.1806				
7	.8579	.2408				
8	.9783	.301				
9	.9633	.7676				
10			.9482	1.0686		.6622
11			1.2041	1.1138		.7827
12			1.0987	1.1439	.4365	.8429
13			1.0536	.9934	.4515	.8128
14				.7225	.4515	.8278
15				.6622	.4515	.888
16					.4365	.8278
17					.4365	.7827
24	.5418	.1505				
Max	.9783	.7676	1.2041	1.1439	.4515	.888
Min	.4515	.1505	.9482	.6622	.4365	.6622
Avg	.6816	.2393	1.0762	.9507	.444	.8034

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI I S/DN[313]

BU 1660

Substation No/ Name :- 034018 / 33KV ASTEGAON

Feeder No / Name : 204 / KHED GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7783	.7783	.7783	.7602	.6516	.6878
2		.7602	.7783	.7783	.7602	.6335	.6878
3		.7602	.7783	.7783	.7602	.6335	.6878
4		.724	.7783	.7783	.7602	.6335	.6516
5		.6516	.7602	.7059	.7602	.6335	.543
6		.5792	.5973	.5249	.5973	.5068	.4706
7		.4344	.4163	.3982	.4344	.362	.4344
8		.3982	.362	.3982	.3982	.3439	.3841
9		.2715	.4163	.3982	.3982	.3077	.3258
10		.3982	.3801	.3801	.362	.3258	.3077
11	.3982	.4163	.4344	.4525	.3801	.2715	.3258
12	.5068	.4706	.4163	.4887	.4163	.3258	.362
13	.5068	.4887	.543	.5068	.4525	.3801	.4344
14	.6335	.4887	.5249	.5973	.3612	.4344	.5249
15	.6697	.4887	.4887		.3982	.4344	.5249
16	.6516	.5068	.4163	.5249	.3801	.3982	.4887
17	.4525	.4344	.4163	.4344	.3801	.362	.3439
18	.362	.4344	.4344	.4525	.3801	.3982	.2534
19	.4525	.543	.5792	.5792	.4525	.5068	.4887
20	.6878	.7602	.6962	.7421	.6516	.6697	.6516
21	.7783	.7964	.7964	.7421	.6154	.724	.8145
22	.8507	.8145	.7964	.724	.6335	.724	.7783
23	.8145	.6944	.7964	.8145	.6878	.724	
24		.7964	.7783	.7783	.7602	.6878	.6878
Max	.8507	.8145	.7964	.8145	.7602	.724	.8145
Min	.362	.2715	.362	.3801	.3612	.2715	.2534
Avg	.5973	.5787	.5901	.5981	.5392	.5030	.5156

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI I S/DN[313]

BU 1660

Substation No/ Name :- 034018 / 33KV ASTEGAON

Feeder No / Name : 205 / 11KV AMBADA GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7133	.6401	.6584	.6036	.4938	.6036
2		.7133	.6401	.6584	.6036	.4938	.6036
3		.6584	.6401	.6584	.6036	.4938	.6036
4		.6401	.6401	.6584	.6036	.4938	.6036
5		.6401	.6401	.5853	.6036	.4938	.5853
6		.6036	.5853	.5121	.4938	.3841	.4938
7		.4755	.4755	.439	.5121	.3841	.4024
8		.4572	.4572	.4207	.439	.3841	.3658
9		.4755	.439	.439	.439	.3292	.4207
10		.4572	.4024	.439	.3658	.2743	.4024
11	.4755	.4938	.439	.4024	.3658	.2378	.4207
12	.439	.4938	.4572	.4207	.4207	.2378	.4024
13	.4755	.5487	.4755	.4755	.4024	.2743	.439
14	.5304	.4938	.5121	.4938	.3658	.2926	.3658
15	.6036	.4938	.5121		.3658	.2926	.4024
16	.6219	.4755	.5121	.4755	.3658	.2926	.4207
17	.4207	.439	.4938	.4024	.3475	.2926	.3658
18	.4024	.4938	.5121	.5121	.3841		.439
19	.5121	.5304	.567	.5121	.439	.5487	.4938
20	.6219	.6401	.6219	.6036	.6219	.6036	1.1523
21	.6584	.6584	.6401	.6401	.5487	.6401	.6401
22	.7316	.6584	.6401	.7133	.6036	.6401	.6767
23	.7133	.6584	.6584	.7682	.5487	.6401	.6767
24		.7133	.6401	.6584	.6036	.4938	.6219
Max	.7316	.7133	.6584	.7682	.6219	.6401	1.1523
Min	.4024	.439	.4024	.4024	.3475	.2378	.3658
Avg	.5543	.5677	.5517	.5455	.4855	.4222	.5251

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI I S/DN[313]

BU 1660

Substation No/ Name :- 034018 / 33KV ASTEGAON

Feeder No / Name : 206 / 11 KV UTKHED AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.1658	.0995	.1989
2					.1658	.0995	.1989
3					.1658	.0995	.2155
4					.1658	.0995	.2155
5					.1658	.0995	.2155
6					.2155	.0995	.2155
7					.4973	.1658	.3315
8						.2486	.431
9					.5636	.3315	.4641
10		.431	.4144				
11	.6299	.5801	.3647				
12	.4144	.4475	.3647				
13			.3812				
14	.0332	.3647	.3812	.3481			
15	.0829		.3812	.5304			
16	.116	.1989	.3978	.4807			
17		.2818	.4144	.4807			
18	.3978						
19	.3812						
20	.3315						
21	.2652						
24					.1658	.116	.1989
Max	.6299	.5801	.4144	.5304	.5636	.3315	.4641
Min	.0332	.1989	.3647	.3481	.1658	.0995	.1989
Avg	.2947	.384	.3875	.4600	.2524	.1459	.2685

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI I S/DN[313]

BU 1660

Substation No/ Name :- 034020 / 33KV HIWARKHED

Feeder No / Name : 201 / 11KV DAPORI AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2218	.181	.1052
2				.2218	.181	.1052
3				.2218	.181	.1052
4				.2218	.181	.1063
5				.2402	.1629	.1063
6				.2587	.1991	.1402
7				.3475	.1991	.1578
8				.4706	.181	.1578
9				.4887	.181	.1402
10	.0747	.5144	.4115			
11	.5144	.6173	.4961			
12	.5316	.5658	.5434			
13	.583	.5658	.543			
14	.5487	.3601	.4344			
15	.5144	.3601	.3881			
16	.5144	.3772	.3658			
17	.4656	.3772	.3696			
24				.1848	.181	.1227
Max	.583	.6173	.5434	.4887	.1991	.1578
Min	.0747	.3601	.3658	.1848	.1629	.1052
Avg	.4684	.4672	.4440	.2878	.1828	.1247

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI I S/DN[313]

BU 1660

Substation No/ Name :- 034020 / 33KV HIWARKHED

Feeder No / Name : 202 / 11KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1307	.1448	.1509	.1494	.1448	.1509
2	.132	.1307	.1448	.1509	.1494	.1448	.1509
3	.132	.1307	.1448	.1509	.1307	.1448	.1509
4	.132	.1307	.1448	.132	.1267	.1448	.1509
5	.132	.1307	.1448	.132	.1494	.1448	.1509
6	.1109	.1307	.1267	.0886	.1307	.0905	.132
7	.0914	.1307	.1267	.0914	.1494	.0905	.0886
8	.0886	.112	.0905	.0886	.0934	.0905	.0886
9	.0876	.0934	.0905	.0886	.0934	.0905	.0686
10	.0876	.0934	.0905	.0886	.0747		.0886
11	.0934	.0905	.0686	.0747	.0724	.0701	.0934
12	.0747	.0724	.0686	.0747	.0724	.0701	.0934
13		.1267	.0701	.0934	.0724	.0701	.0934
14		.1267	.0701	.0934	.0724	.0701	.0934
15		.1267	.0886	.0934	.0724	.0701	.0934
16		.0905	.0886	.0747	.0724	.0701	.0747
17		.0724	.0701	.0747	.0724	.0886	.0934
18		.0724	.0701			.0886	.0934
19	.0934	.0905	.0886	.0934	.0905	.0886	.0934
20	.112	.0905	.0886	.0934	.0905	.0886	.0934
21	.1307	.1086	.0886	.0934	.0905	.0886	.0934
22	.1307	.1086	.1307	.1307	.0905	.1307	.0934
23	.1307	.1448	.1509	.1494	.1448	.1509	.1307
24	.1307	.1307	.1267	.1509	.1494	.1448	.1509
Max	.132	.1448	.1509	.1509	.1494	.1509	.1509
Min	.0747	.0724	.0686	.0747	.0724	.0701	.0686
Avg	.1124	.1111	.1049	.1066	.1048	.1033	.1085

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI I S/DN[313]

BU 1660

Substation No/ Name :- 034020 / 33KV HIWARKHED

Feeder No / Name : 203 / 11KV BOPOLWADI AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.0934	.1086	.0953	.3658	.2172	.12
2	.1905	.0934	.1086	.0953	.3475	.2172	.12
3	.1334	.0934	.1086	.0953	.3658	.181	.1029
4	.1143	.0747	.1086		.3475	.2172	.1029
5	.0953	.0934	.1086	.0953	.3292	.181	.1029
6		.0905	.1086		.3658	.1991	.1372
7					.3982	.1991	.12
8					.4525	.181	.1543
9					.5068	.181	.1543
10	.9054	.8507	.583	.6706			
11	1.182	.9831	.6859	.6935			
12	1.2403	1.0159	.6344	.6733			
13	1.2048	.9282	.6516	.6379			
14	1.1283	.9282	.583	.543			
15	1.0745	.9116	.5487	.5258			
16	.9313	.631	.5658	.5792			
17	.9313	.6516	.4973	.5068			
18	.0566		.0762		.0905	.0762	.0754
19	.0747	.0905	.0762	.0934	.0905	.0762	.0943
20	.0934	.1086	.0953	.0934	.0905	.0953	.0943
21	.0934		.0953	.0934	.0905	.0953	.0943
22	.0934		.0953	.0934	.0905	.1143	.0943
23	.0934	.1086	.0953	.0934	.0905	.0953	.0943
24	.2096	.0934	.0905	.0953	.3658	.2172	.1029
Max	1.2403	1.0159	.6859	.6935	.5068	.2172	.1543
Min	.0566	.0747	.0762	.0934	.0905	.0762	.0754
Avg	.5028	.4356	.2869	.3208	.2742	.1590	.1103

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI I S/DN[313]

BU 1660

Substation No/ Name :- 034020 / 33KV HIWARKHED

Feeder No / Name : 204 / 11KV HIWERKHED -GAOTHAN-

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6767	.6516	.5658	.6401	.6154	.5144	.5914
2	.6767	.6584	.5658	.6401	.6154	.543	.5914
3	.6584	.6219	.5487	.6401	.6154	.5144	.5729
4	.6584	.6219	.5609	.6401	.5973	.463	.5544
5	.6401	.5853	.5487	.6401	.6154	.4801	.5544
6	.567	.5487	.5258	.5853	.5973	.4458	.5853
7	.543	.439	.362	.543	.5304	.463	.4572
8	.4525	.443	.4382	.4887	.4755	.4115	.4755
9	1.0679	.4024	.3761	.4344	.439	.3982	.4344
10	.4163	.439	.3258	.4163	.4207		.3439
11	.4207	.4656	.362	.439	.3761	.3801	.3292
12	.4938	.4458	.394	.4755	.3801	.3258	.3841
13	.5304	.5316	.543	.5121	.394	.3982	.3658
14	.5847	.463	.4706	.4207	.3429	.4344	.4207
15	.5853	.394	.4344	.4572	.3506	.3258	.4572
16	.3841	.3582	.3982	.439	.2896	.2715	.439
17	.3292	.3761	.4163	.4024	.2896	.3292	.3841
18	.3696	.3506	.4163		.3077	.362	.4207
19	.4207	.4207	.4572	.4572	.4207	.4344	.4938
20	.5487	.591	.6036	.5487	.4908	.5487	.5611
21	.6219	.5316	.6036	.6036	.4908	.567	.5792
22	.6697	.5316	.6584	.6584	.4733	.6219	.5973
23	.6878	.5959	.6584	.6584	.5434	.6036	.6154
24	.7133	.6697	.583	.6584	.6335	.5434	.6099
Max	1.0679	.6697	.6584	.6584	.6335	.6219	.6154
Min	.3292	.3506	.3258	.4024	.2896	.2715	.3292
Avg	.5715	.5057	.4924	.5391	.4710	.4513	.4924



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI I S/DN[313]

BU 1660

Substation No/ Name :- 034020 / 33KV HIWARKHED

Feeder No / Name : 205 / 11 KV DAPORI -GAOTHAN-  
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2772	.2957	.2715	.2772	.2772	.2353	.2587
2	.2772	.2957	.2715	.2772	.2772	.2353	.2587
3	.2772	.2772	.2715	.2772	.2587	.2353	.2587
4	.2772	.2587	.2715	.2587	.2772	.2172	.2402
5	.2772	.2587	.2534	.2587	.2587	.1991	.2402
6	.2195	.2218	.1991	.2012	.2402	.1448	.2033
7	.1629	.1663	.1448	.1448	.1663	.1448	.1463
8	.1267	.1307	.1448	.1629	.1494	.1267	.1463
9	.1086	.1307	.1629	.181	.1663	.1448	.1448
10	.181	.1494	.1448	.1629	.1494		.1448
11	.1848	.1629	.1629	.1848	.1448	.1267	.1494
12	.2033	.181	.1433	.1612	.181	.1448	.1494
13	.2218	.2353	.1629	.2218	.1629	.1629	.1494
14	.2587	.2534	.1267	.2218	.1448	.1629	.1867
15	.2218	.181	.1448	.2218	.1448	.1629	.2054
16	.1663	.1629	.1448	.2033	.1448	.1267	.1848
17	.1307	.1629	.1267	.1663	.0724	.1097	.168
18	.1494	.1629	.1086			.1612	.168
19	.112	.1629	.2012	.1848	.1991	.1629	.2218
20	.2587	.2715	.2561	.2587	.2172	.2378	.2218
21	.2957	.2715	.2743	.2587	.2172	.2378	.2402
22	.3109	.2715	.2926	.2957	.2172	.2743	.2587
23	.3109	.2715	.2772	.2957	.2353	.2561	.2772
24	.3292	.2957	.2686	.2957	.2957	.2353	.2587
Max	.3292	.2957	.2926	.2957	.2957	.2743	.2772
Min	.1086	.1307	.1086	.1448	.0724	.1097	.1448
Avg	.2225	.2180	.2011	.2249	.1999	.1846	.2034

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI I S/DN[313]

BU 1660

Substation No/ Name :- 034020 / 33KV HIWARKHED

Feeder No / Name : 206 / 11KV HIWARKHED AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8507	.5487	.6706			
2			.5609	.6706			
3		.8145	.5487	.6706			
4		.8145	.583	.6706			
5		.8326	.583	.6874			
6		.8688	.6859	.8718			
7		.9313	.9259	1.073			
8		1.1462	1.0608	1.2266			
9	.9892	1.1104	1.0608	1.21			
10					1.134		.2743
11					1.1797		.2926
12					1.2125		.3475
13					1.1142	.2683	.3109
14					.583	.2347	.3292
15						.2347	.2743
16						.218	.3109
17						.2058	.3077
24		.8688	.583	.6706			
Max	.9892	1.1462	1.0608	1.2266	1.2125	.2683	.3475
Min	.9892	.8145	.5487	.6706	.583	.2058	.2743
Avg	.9892	.9153	.7141	.8422	1.0447	.2323	.3059

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI I S/DN[313]

BU 1660

Substation No/ Name :- 034067 / 33 KV MORSHI

Feeder No / Name : 201 / 11 KV SIMBHORA ROAD

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.6878	.6089	.6219	.6154	.4706	.543
2	.6516	.6516	.5792	.5853	.5792	.4706	.543
3	.5792	.6154	.5068	.5487	.543	.4344	.543
4	.543	.6154	.4755	.5121	.5068	.4344	.4525
5	.5068	.543	.439	.4755	.4755	.3982	.4525
6	.4344	.4344	.4163	.3658	.3982	.362	.362
7	.362	.362	.3258	.3292	.3258	.2896	.2896
8	.2896	.2896	.2534	.2926	.2804	.2534	.2715
9	.2715	.3077	.2715	.2561	.2896	.2534	.2534
10	.2896	.3258	.2715	.3658	.2896	.2534	.2378
11	.3258	.3258	.2926	.3258	.2896	.2534	.2743
12	.3439	.3258	.3292	.3258	.3258	.2534	.2926
13	.3982	.362	.3658	.3982	.2896	.2534	.2926
14	.4706	.4163	.3658	.3982	.2896	.2534	.3292
15	.4706	.4344	.4024	.3801	.2896	.2715	.3292
16	.4706	.3439	.4024	.362	.2896	.2715	.3292
17	.3982	.3258	.3658	.3258	.2534	.2715	.3109
18	.362	.3077	.3475	.2896	.2534	.2896	.2926
19	.3258	.3439	.4024	.362	.3258	.3077	.3292
20	.4706	.4344	.439	.4706	.362	.4525	.4755
21	.5792	.5068	.5121	.4706	.3982	.4706	.5121
22	.6154	.5973	.5853	.5792	.4706	.5068	.5853
23	.6878	.6154	.6219	.6154	.4706	.5611	.6219
24	.6878	.6878	.6154	.6219	.4706		.543
Max	.6878	.6878	.6219	.6219	.6154	.5611	.6219
Min	.2715	.2896	.2534	.2561	.2534	.2534	.2378
Avg	.4661	.4525	.4248	.4283	.3784	.3494	.3944

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI I S/DN[313]

BU 1660

Substation No/ Name :- 034067 / 33 KV MORSHI

Feeder No / Name : 202 / 11 KV FAUJI COLONY

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9231	.9955	.905	.9145	.905	.724	.7602
2	.8688	.905	.8326	.8596	.8507	.6516	.7602
3	.8326	.905	.8048	.823	.8145	.6516	.7783
4	.7602	.8326	.724	.7316	.724	.6154	.724
5	.724	.724	.6878	.6584	.6878	.5792	.6516
6	.6516	.6154	.6335	.5487	.6154	.543	.543
7	.5068	.5068	.4887	.4755	.543	.4706	.4887
8	.4344	.4344	.4706	.4755	.439	.4344	.4706
9	.4344	.543	.4525	.4755	.4887	.4344	.4525
10	.4344	.543	.543	.5853	.5249	.362	.5487
11	.5068	.543	.567	.6154	.543	.3982	.3841
12	.5611	.5792	.6219	.6154	.5792	.4525	.5487
13	.6516	.6516	.6584		.6154	.4887	.6036
14	.724	.7421	.695		.5792	.4938	.6584
15	.7602	.7602	.7682		.5792	.4755	.695
16	.7783	.6516	.695	.6878	.5792	.4706	.6219
17	.6878	.5792	.5487	.5611	.543	.4344	.5853
18	.6516	.5973	.5487	.5068	.5068		.5853
19	.6154	.6335	.695	.6154	.5792	.5249	.6219
20	.8326	.8326	.8048	.7964	.724	.7421	.823
21	.8326	.905	.8779	.8326	.724	.7964	.9145
22	.905	.8507	.8779	.8688	.6878	.8326	.8779
23	.9774	.905	.9511	.905	.7602	.8507	.9145
24	1.0136	.9774	.905	.9145	.7602		.8145
Max	1.0136	.9955	.9511	.9145	.905	.8507	.9145
Min	.4344	.4344	.4525	.4755	.439	.362	.3841
Avg	.7112	.7172	.6982	.6889	.6397	.5648	.6594

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI I S/DN[313]

BU 1660

Substation No/ Name :- 034067 / 33 KV MORSHI

Feeder No / Name : 203 / 11 KV RAMJI BABA

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1584	1.267	1.1584	1.2803	1.1462	.9774	1.086
2	1.086	1.267	1.086	1.2071	1.1222	.9774	1.0136
3	1.0498	1.1584	1.0498	1.134	1.086	.9412	1.0136
4	1.0136	1.086	1.0136	1.0608	1.086	.905	1.0136
5	.9412	1.086	.9774	1.0242	1.086	.8326	.9774
6	.8869	.9412	.905	.9145	1.0136	.7964	.8688
7	.7783	.8326	.7602	.8048	.8326	.724	.7059
8	.6516	.6878	.6516	.6584	.724	.6154	.6516
9	.6154	.724	.6335	.6584	.724	.5792	.6154
10	.724	.7421	.6878	.7316	.6697	.6154	.695
11	.7602	.8326		.7964	.6516	.6516	.695
12		.905		.7964	.6878	.6697	.7682
13	.8688	.9774	.9511	.9412	.7602	.724	.8048
14	.9412	1.0317	.9511	.9412	.7602	.7602	.8779
15	.9593	1.0498	.9877	.905	.724	.724	.9145
16	.9774	.8507	.9511	.905		.6878	.8779
17	.8145	.7964		.8145	.3258	.6697	.8048
18	.8145	.724	.8413	.7602	.6516	.724	.7682
19	.8326	.8507	1.0059	.9412	.7602	.8688	.9145
20	1.0498	1.0498	1.0974	1.0136	.9412	1.0498	1.0608
21	1.086	1.0498	1.134	1.086	.9412	1.0498	1.0974
22	1.1584	1.1222	1.1706	1.1403	.9774	1.0498	1.1523
23	1.1946	1.1946	1.2803	1.1946	1.0136	1.086	1.1888
24	1.3032		1.1946	1.2803	1.0136		1.086
Max	1.3032	1.267	1.2803	1.2803	1.1462	1.086	1.1888
Min	.6154	.6878	.6335	.6584	.3258	.5792	.6154
Avg	.9420	.9664	.9756	.9579	.8565	.8121	.9022

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI I S/DN[313]

BU 1660

Substation No/ Name :- 034067 / 33 KV MORSHI

Feeder No / Name : 204 / 11 KV TAJ COLONY

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9774	.9774	.9412	.9511	.9412	.724	.8326
2	.9412	.905	.905	.9145	.9412	.6878	.8145
3	.8688	.905	.8413	.9145	.905	.6516	.8145
4	.8688	.8688	.7964	.8596	.905	.6516	.7602
5	.8326	.7964	.7964	.7865	.7964	.6154	.724
6	.7602	.724	.724	.7316	.7011	.5792	.6516
7	.6516	.6154	.6516	.6219	.6154	.543	.543
8	.543	.543	.543	.5487	.543	.4706	.4887
9	.5068	.5249		.5121	.543	.4344	.4344
10	.4887	.5068		.5853	.4887	.4344	.4938
11	.543	.5792	.695	.6154	.543	.4706	.5121
12		.6516	.6219	.6335	.543	.5068	.5487
13	.6516	.724	.6219	.7421	.5792	.543	.5853
14	.7602	.7602	.5487	.6878	.5792	.6154	.6219
15	.7783	.724	.7316	.6516	.543	.6154	.6401
16		.6516	.695	.6697	.543	.5792	.6219
17	.6878	.6154	.695	.5973	.5068	.5611	.6036
18	.6516	.6154	.6219	.5792	.5068	.543	.5487
19	.6154	.7602	.8048	.7602	.6516	.6878	.7316
20	1.0136	.8326	.8048	.8326	.724	.8507	.8596
21	.905	.8326	.8779	.8326	.724	.8326	.8596
22	.9412	.8869	.8779	.8869	.7602	.8326	.8779
23	.9774	.9412	.9511	.905	.7602	.8688	.9145
24	1.0136	.9774	.9412	.9511	.7602		.8507
Max	1.0136	.9774	.9511	.9511	.9412	.8688	.9145
Min	.4887	.5068	.543	.5121	.4887	.4344	.4344
Avg	.7717	.7466	.7585	.7405	.6710	.6217	.6806

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI I S/DN[313]

BU 1660

Substation No/ Name :- 034067 / 33 KV MORSHI

Feeder No / Name : 205 / PARDI GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1629	.1448	.1629	.1646	.1629	.1629	.1448
2	.1448	.1448	.1448	.1646	.1629	.1629	.1448
3	.1448	.1448	.1448	.1463	.1629	.1448	.1267
4	.1267	.1448	.1075	.1463	.1629	.1448	.1267
5	.1267	.1448	.1086	.1463	.1448	.1448	.1267
6	.1086	.1086	.1075	.128	.1448	.1267	.1086
7	.1086	.1086	.0905	.1097	.1086	.0905	.0905
8	.0905	.1086	.1086	.0732	.1086	.0905	.0905
9	.0905	.1086	.1086	.1097	.1086	.0905	.1086
10	.0905	.1086	.1086	.1097	.0905	.0724	.0914
11	.1086	.1086	.1097	.1086	.0905	.0724	.0732
12	.1086	.1086	.1097	.1097	.1086	.0905	.0914
13	.1267	.1086	.128	.1448	.1086	.0905	.1097
14	.1267	.1086	.1097	.1267	.1086	.0716	.0732
15	.1086	.1086	.1097	.1086	.1086	.0543	.0914
16	.0905	.0905	.0732	.0905	.0724	.0543	.1097
17	.0724	.0905	.0914	.0905	.0362	.0181	.0914
18	.0905	.0905	.1097	.1086	.0724	.0362	.0914
19	.1086	.0905	.1097	.1267	.1086	.0724	.0914
20	.1448	.1448	.1463	.1629	.1448	.1448	.1463
21	.1448	.1448	.1646	.1629	.1267	.1629	.1646
22	.1448	.1612	.1646	.181	.1629	.1448	.1646
23	.1629	.1629	.1463	.181	.1629	.1448	.1646
24	.1629	.1629	.1646	.1646	.1629		.1448
Max	.1629	.1629	.1646	.181	.1629	.1629	.1646
Min	.0724	.0905	.0732	.0732	.0362	.0181	.0732
Avg	.1207	.1229	.1221	.1319	.1222	.1038	.1153

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI I S/DN[313] BU 1660

Substation No/ Name :- 037018 / 132KV MORSHI

Feeder No / Name : 201 / 11TALANI AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)
12	.3086	.5144
16	.2572	
<b>Max</b>	<b>.3086</b>	<b>.5144</b>
<b>Min</b>	<b>.2572</b>	<b>.5144</b>
<b>Avg</b>	<b>.2829</b>	<b>.5144</b>



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI I S/DN[313] BU 1660

Substation No/ Name :- 037018 / 132KV MORSHI

Feeder No / Name : 202 / 11KV TOWN-II AG  
Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	22-JUN-17	23-JUN-17
HR	Load (MW)	Load (MW)
12		.7202
16	.8402	
17		.5316
Max	.8402	.7202
Min	.8402	.5316
Avg	.8402	.6259

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI I S/DN[313] BU 1660

Substation No/ Name :- 037018 / 132KV MORSHI

Feeder No / Name : 203 / 11KV MORSHI RURAL  
Feeder KV- 11 / OUTGOING

AG Feeder with SDT

DATE	22-JUN-17	23-JUN-17
HR	Load (MW)	Load (MW)
12	1.4746	.7888
16	.823	
17		.9945
Max	1.4746	.9945
Min	.823	.7888
Avg	1.1488	.8917

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI I S/DN[313] BU 1660

Substation No/ Name :- 037018 / 132KV MORSHI

Feeder No / Name : 204 / 11 KV NASITPUR AG  
Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)
12	.0171	1.4918
16	.6859	
<b>Max</b>	<b>.6859</b>	<b>1.4918</b>
<b>Min</b>	<b>.0171</b>	<b>1.4918</b>
<b>Avg</b>	<b>.3515</b>	<b>1.4918</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI I S/DN[313] BU 1660

Substation No/ Name :- 037018 / 132KV MORSHI

Feeder No / Name : 205 / 11KV PIMPALKHUTA  
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	22-JUN-17	23-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12		.5249	.3258	.3982
16	.4887			
17		.362	.3801	
Max	.4887	.5249	.3801	.3982
Min	.4887	.362	.3258	.3982
Avg	.4887	.4435	.3530	.3982

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI I S/DN[313] BU 1660

Substation No/ Name :- 037018 / 132KV MORSHI

Feeder No / Name : 206 / 11KV UPPAR WARDHA Only one consumer of WW with HT-IV

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	.1991	.1629	.1448	.181
16	.181		.1629	
17		.1629	.1629	
Max	.1991	.1629	.1629	.181
Min	.181	.1629	.1448	.181
Avg	.1901	.1629	.1569	.181

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI I S/DN[313] BU 1660

Substation No/ Name :- 037018 / 132KV MORSHI

Feeder No / Name : 401 / 33KV MORSHI

Urban/Sheddable Urban Feeder

Feeder KV- 33 / INCOMING

DATE	25-JUN-17
HR	Load (MW)
24	3.8272
Max	3.8272
Min	3.8272
Avg	3.8272

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI II S/DN.[760] BU 4760

Substation No/ Name :- 034022 / 33KV LEHEGAON

Feeder No / Name : 201 / 11KV SAWARKHED AG AG Feeder with SDT  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3277	.6767	.4024	.1715
2				.3563	.6767	.3658	.1677
3				.3563	.4652	.3658	.1844
4				.421	.7316	.4024	.1844
5				.583	.8596	.3395	.1844
6				.7125	1.0242	.2641	.2012
7				.905	1.0669	.2641	.8383
8				1.1584	1.2809	.724	.5365
9				1.3032	1.2803	.8688	1.0898
10	.181	.6097					
11	.3361	.7545	1.358				
12	.3239	.6036	1.448				
13	.3125	.2561	1.0364				
14	.3521	.6219	1.0364				
15	.3841	.5853	1.1012				
16	.4024	.6584	.5506				
17	.3658	.8048	1.1012				
21			.0381				
22		.0381	.0381				
23			.0381				
24				.0972	.6219	.4527	.1619
Max	.4024	.8048	1.448	1.3032	1.2809	.8688	1.0898
Min	.181	.0381	.0381	.0972	.4652	.2641	.1619
Avg	.3322	.5480	.7746	.6221	.8684	.4450	.3720

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI II S/DN.[760] BU 4760

Substation No/ Name :- 034022 / 33KV LEHEGAON

Feeder No / Name : 202 / 11KV DHAMANGAON AG AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.4207	.2263	.4115
2					.4207	.2641	.4525
3					.4207	.3018	.4477
4					.4572	.3395	.4477
5					.4755	.3658	.4477
6				.2915	.5487	.4527	.4557
7				.4344	.6401	.4527	.7716
8				.724	.8482	.5792	1.0288
9				.8916	.9717	.724	.8718
10	.4344	.3353	.8383				
11	.3841	.7712	.9389				
12	.2241	.7682	1.0136				
13	.3841	.6036	.9717				
14	.3521	.5853	.9717				
15	.3521	.3658	.8421				
16	.439	.5658	1.1203				
17	.439	.5853	.7655				
20	.0377			.0381			
21	.0377	.0381	.0381	.0377			.0191
22			.0381	.0381		.0381	
23		.0381	.0381	.0381			
24					.3658	.1463	.3887
Max	.439	.7712	1.1203	.8916	.9717	.724	1.0288
Min	.0377	.0381	.0381	.0377	.3658	.0381	.0191
Avg	.3084	.4657	.6888	.3117	.5569	.3537	.5221



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI II S/DN.[760] BU 4760

Substation No/ Name :- 034022 / 33KV LEHEGAON

Feeder No / Name : 203 / 11KV NERPINGALAI AG AG Feeder with SDT  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0648	.0366	.1677				
2	1.4899	.0366	.1677				
3	.0648	.0366	.1677				
4	.0486	.0366	.1677				
5	.0486	.0366	.1844				
6	.0486	.0366	.2012				
7	.0324	.0732	.4694				
8		.0747	.4191				
9		.0895	.426				
10				.2896	.2439	.1448	.3292
11				.3048	.362	.1341	.3437
12				.3048	.2172	.2012	.3353
13				.2743	.2896	.1619	.3841
14				.2743	.2534	.1296	.3201
15				.2469	.2172	.1943	.3281
16				.2439	.2172	.2267	.3437
17				.25	.1463	.1943	.4904
20				.0191		.0381	.0381
21				.0191		.0381	.0377
22			.0381			.0381	
23			.0381	.0191			
24	.3563	.0366	.1619				
Max	1.4899	.0895	.4694	.3048	.362	.2267	.4904
Min	.0324	.0366	.0381	.0191	.1463	.0381	.0377
Avg	.2693	.0494	.2174	.2042	.2434	.1365	.2950

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI II S/DN.[760] BU 4760

Substation No/ Name :- 034022 / 33KV LEHEGAON

Feeder No / Name : 204 / 11KV SHIRKHEG AG AG Feeder with SDT  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0162	.1463	.1097				
2	.0162	.1463	.0732				
3	.0162	.072	.0732				
4	.0162		.0732				
5	.0162		.0732				
6	.0162		.0732				
7	.1943		.1372				
8	.2172	.0754	.1715				
9	.2172	.0747	.5365				
10				.724	.7164	.0724	.6371
11				.8002	.7964	.3506	.4031
12				.7042	.7964	.5258	.7011
13				.5864	.6878	.421	.631
14				.5312	.6516	.5228	.5609
15				.4999	.6154	.3563	.5731
16				.5121	.362	.4481	.5959
17				.6097	.0754	.4534	.7712
20	.0566			.0381			.0191
21	.0377	.0328	.0381	.0377			.0191
22	.0381	.0324	.0381			.0381	
23		.0381	.0381	.0191			
24	.0324	.1509	.0972				
Max	.2172	.1509	.5365	.8002	.7964	.5258	.7712
Min	.0162	.0324	.0381	.0191	.0754	.0381	.0191
Avg	.0685	.0854	.1179	.4602	.5877	.3543	.4912

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI II S/DN.[760] BU 4760

Substation No/ Name :- 034022 / 33KV LEHEGAON

Feeder No / Name : 205 / 11KV RAJURWADI AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0162						
2	.0162	.0126	.0191				
3	.0162	.0189	.0191				
4	.0162	.0183	.0191				
5	.0162	.0183	.0191				
6	.0162	.0183	.0191				
7	.0162	.0189	.0191				
8	.0181		.0191				
9	.0181		.0189				
10				.0181	.0164	.0181	.0189
11				.0189	.0181	.0189	.017
12				.0191	.0181	.0189	.0171
13				.0189	.0181	.0187	.0171
14				.0189	.0181	.0162	.0189
15				.0189	.0181	.0162	
16				.0189		.0162	.0187
17				.0189		.0162	.017
24		.0189	.0162				
Max	.0181	.0189	.0191	.0191	.0181	.0189	.0189
Min	.0162	.0126	.0162	.0181	.0164	.0162	.017
Avg	.0166	.0177	.0188	.0188	.0178	.0174	.0178

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI II S/DN.[760] BU 4760

Substation No/ Name :- 034022 / 33KV LEHEGAON

Feeder No / Name : 206 / 11KV DHAMANGAON gaothan Gaothan Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8589	.7682	.8299	.8215	.8048	.6584	.7167
2	.8215	.7682	.8299	.8215	.8048	.6584	.7167
3	.8215	.7682	.7922	.8215	.8048	.6584	.7167
4	.7842	.6767	.7545	.7842	.7316	.6219	.679
5	.7842	.6219	.7095	.7468	.4652	.6219	.679
6	.5601	.5487	.6348	.5601	.5853	.5658	.5601
7	.4108	.4024	.6089	.4458	.5359	.4024	.4435
8	.3772	.4108	.5487	.4115	.462	.3772	.4066
9	.4801	.5975	.5316	.4801	.6468	.3772	.5914
10	.4801	.5175	.5316	.4801	.5544	.3772	.4904
11	.5544	.5194	.567	.5914	.5487	.3224	.5175
12	.5914	.5853	.6516	.7316	.583	.4024	.4435
13	.5544	.695	.7468	.7316	.6173	.4108	.5544
14	.6219	.5658	.7842	.8779	.5487	.5228	.5175
15	.6584	.5487	1.3817	.695	.4115	.5228	.5487
16	.5853	.5121	.7468	.5914	.5316	.4854	.3658
17	.4527	.4755	.5975	.5228	.415	.4481	.5175
18	.439	.5121	.5228	.5601	.1097	.5175	.4024
19	.5788	.4435	.5228	.6722	.2263	.5601	.5975
20	.7577	.7392	.7468	.823	.5487	.7655	.7545
21	.7762	.9054	.7922	.7842		.7468	.7842
22	.8413	.8779	.8589	.8048		.7468	.7316
23	.8048	.7468	.8589	.8048	.7316	.7468	.7356
24	.8589	.7682	.8676	.8215	.8048	.679	.7468
Max	.8589	.9054	1.3817	.8779	.8048	.7655	.7842
Min	.3772	.4024	.5228	.4115	.1097	.3224	.3658
Avg	.6439	.6240	.7257	.6827	.5669	.5498	.5924

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI II S/DN.[760] BU 4760

Substation No/ Name :- 034022 / 33KV LEHEGAON

Feeder No / Name : 207 / 11KV NERPINGLAI GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.9511	.9619	.9335	.8779	.823	.7922
2	.056	.9431	.9335	.9335	.8779	.823	.7545
3	.056	.9145	.8962	.9335	.8779	.7922	.7468
4	.0037	.8413	.8962	.8962	.8779	.7316	.7468
5	.0373	.7682	.8589	.7842	.7499	.6219	.7095
6	.0187	.6767	.6722	.6001	.6584	.5487	.5914
7	.0187	.5853	.5121	.4287	.5729	.4755	.462
8	.0171	.5041	.4298	.4458	.5359	.4115	.4887
9	.0171	.5041	.4961	.463	.499	.4115	.4119
10	.0171	.5359	.4961	.4801	.4805		.4298
11	.0191	.5731	.5258	.6036	.4458	.4668	.4435
12	.0377	.6219	.583	.6584	.5316	.4525	.499
13		.695	.7468	.6219	.583	.4854	.7023
14		.7682	.8215	.7865	.583	.5601	.6283
15	.0377	.7682	.8402	.7577	.5487	.5601	.6401
16	.7682	.7316	.8029	.6653	.4973	.5228	.6036
17	.5658	.5121	.6161	.5601	.4755	.4668	.499
18	.5304	.5853	.6722	.5788	.4207	.4668	.4207
19	.5601	.5729	.6722	.6535	.5121	.5601	.5415
20	.7207	.7392	.7842	.7865	.5847	.7655	.7316
21	.8316	.8775	.8215	.8775		.7842	.8402
22	.9149		.9149	.9511		.8299	.8962
23	1.0059		.9335	.9694	.823	.8029	.9145
24	.1494	.6036	.9522	.9149	.9145	.8488	.7842
Max	1.0059	.9511	.9619	.9694	.9145	.8488	.9145
Min	.0037	.5041	.4298	.4287	.4207	.4115	.4119
Avg	.2927	.6942	.7433	.7202	.6331	.6179	.6366

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI II S/DN.[760] BU 4760

Substation No/ Name :- 034022 / 33KV LEHEGAON

Feeder No / Name : 208 / Nimbhi Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7842	.7316	.8299	.7842	.7316	.679	.7922
2	.7842	.7316	.8215	.7842	.7316	.6584	.7545
3	.7468	.695	.8299	.7468	.503	.679	.7545
4	.7468	.6219	.7922	.7468	.6584	.6584	.7167
5	.6722	.6219	.8215	.7095	.6584	.5853	.679
6	.5788	.5853	.7095	.5788	.415	.5304	.6224
7	.4854	.4024	.5014	.4115	.499	.4938	.4481
8	.3944	.3734	.394	.4115	.462	.3772	.4024
9	.4115	.4481	.6024	.3772	.4251	.3772	.4163
10	.4115	.4066	.4607	.2058	.4066	.3429	.4527
11	.4251	.4298	.567	.2772	.5144	.3403	.4435
12	.6653	.4527	.6001	.5853	.6001	.415	.4805
13	.7316	.5853	.7655	.823	.4801	.3921	.6401
14	.7133	.6401	.8402	.7316	.5487	.4108	.6099
15	.695	.6767	.6535	.7207	.5487	.3921	.7316
16	.4715	.5487	.5975	.7023	.3258	.4108	.5853
17	.2452	.4572	.5975	.4854		.3734	.4435
18	.4207	.4207	.3734	.5601	.4024	.5041	.4938
19		.462	.5975	.6161	.439	.5041	.5788
20	.7577	.8131	.7842	.9511	.695	.7865	.8299
21	.8501	.7655	.7842	.8215		.8299	.8962
22	.8413	.8215	.9522	.8779		.8215	.9145
23	.7865	.7655	.7842	.7865	.7356	.8029	.8962
24	.8589	.7316	.8029	.7655	.7316	.6979	.7842
Max	.8589	.8215	.9522	.9511	.7356	.8299	.9145
Min	.2452	.3734	.3734	.2058	.3258	.3403	.4024
Avg	.6295	.5912	.6860	.6442	.5482	.5443	.6403

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI II S/DN.[760] BU 4760

Substation No/ Name :- 034022 / 33KV LEHEGAON

Feeder No / Name : 209 / SAWARKHED GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3475	.3772	.3361	.3292	.2012	.3395
2	.3734	.3475	.3584	.3361	.3292	.2926	.3206
3	.3734	.3292	.3584	.3361	.3109	.2926	.3206
4	.2987	.3109	.3395	.3361	.3109	.2926	.3018
5	.7842	.2743	.3018	.2987	.2743	.2561	.3018
6	.2427	.2561	.3018	.2801	.2561	.2195	.2829
7	.1509	.2195	.1698	.1715	.2218	.2195	.1698
8		.1867		.2058	.2033	.2058	.2218
9		.2241	.2126	.1715	.1848	.2058	.1612
10		.2218	.1949	.2401	.2033	.1715	.1646
11		.2149	.1772	.2957	.1715	.1772	.1848
12		.2012	.1715	.2772	.2058	.1595	.1848
13	.2957	.2561	.2614	.2378	.1715	.1867	.2561
14	.3326	.3292	.8402	.2587	.2401	.168	.2218
15	.3292	.18	.3547	.3142	.2401	.1867	.2195
16	.3292	.2926	.2801	.2033	.1715	.2054	.2195
17	.2195	.2195	.2241	.1867	.1886	.2054	.2218
18	.1829	.2263	.1867	.2054	.2195	.2033	.1829
19	.2241	.1848	.3361	.2801	.2263	.2054	.2427
20	.4066	.3881	.2987	.3395	.3018	.2987	.3292
21	.4066	.3734	.3361	.3734		.2987	.3734
22	.3658	.4108	.3547	.3658		.2987	.3658
23	.415	.3734	.3361	.3772	.3018	.2987	.3292
24	.3734	.3475	.3772	.3361	.3395	.3018	.3361
Max	.7842	.4108	.8402	.3772	.3395	.3018	.3734
Min	.1509	.18	.1698	.1715	.1715	.1595	.1612
Avg	.3409	.2798	.3108	.2818	.2455	.2313	.2605

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI II S/DN.[760] BU 4760

Substation No/ Name :- 034049 / 33 KV RAJURWADI

Feeder No / Name : 201 / 11 KV KAWATHAL AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0876	.061				
2	.0876	.0457				
3		.061				
4		.0762				
5		.0914				
6		.1372				
7		.2439				
8		.3048				
9		.3201				
10			.1677	.12	.0526	.1372
11			.1867	.298	.0762	.1829
12			.1734	.2804	.0914	.1981
13			.16	.2629	.061	.2401
14			.1734	.2103	.061	.2286
15			.12	.1753	.0914	.2134
16			.1734		.0762	.2286
17			.16	.0537	.0914	.2591
24	.1227	.061				
Max	.1227	.3201	.1867	.298	.0914	.2591
Min	.0876	.0457	.12	.0537	.0526	.1372
Avg	.0993	.1402	.1643	.2001	.0752	.211



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI II S/DN.[760] BU 4760

Substation No/ Name :- 034049 / 33 KV RAJURWADI

Feeder No / Name : 202 / 11 KV Rajurwadi Gaothan  
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	.2743	.2572	.2401	.2401	.2378	.2229
2	1.2003	.2378	.2572		.2401	.2378	.2229
3	1.1317	.2195	.2572		.2229	.2353	.2229
4	1.0288	.2195	.2572	.2229	.2058	.2353	.2058
5	.9602	.1848	.2229	.2229	.1886	.2172	.1715
6	.8916	.1848	.1715	.1543	.1715	.1629	.1543
7	.6859	.1494	.1372	.12	.1543	.1463	.1372
8	.7373	.1463	.1372	.1372	.1372	.128	.12
9	.7202	.1463	.12	.1543	.1372	.128	.12
10	.6154	.1097	.12	.1543	.12	.1097	.1029
11	.6584	.12	.1372	.12	.1448	.0857	.1029
12	.7499	.1372	.1372	.12	.1417	.1029	.1029
13	.8869	.1543	.1543	.1543	.1646	.1029	.12
14	.9511	.1715	.1886	.1886	.1629	.1029	.12
15	1.0059	.1715	.2058	.1715	.128	.1029	.1372
16	.181	.1372	.1715	.1372	.1063	.1029	.1372
17	.1097		.1543	.1029	.128	.0857	.12
18	.1097	.12	.1543	.12	.128	.1029	.1029
19	.128	.1372	.1715	.1715	.1629	.2058	.1543
20	.2195	.2058		.2401	.2172	.2229	.2058
21	.2561	.2561	.2058	.2572	.2353	.2229	.2401
22	.2896	.2572	.2401	.2743	.2353	.2229	.2401
23	.2896	.2572	.2572	.2743	.2378	.2229	.2401
24	.5335	.2715	.2572	.2401	.2572	.2378	.2229
Max	1.3717	.2743	.2572	.2743	.2572	.2378	.2401
Min	.1097	.1097	.12	.1029	.1063	.0857	.1029
Avg	.6547	.1856	.1901	.1808	.1778	.1651	.1636

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

MORSHI II S/DN.[760] BU 4760

Substation No/ Name :- 034049 / 33 KV RAJURWADI

Feeder No / Name : 203 / 11 KV Shirilas Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	27-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.061	
2				.061	
3				.061	
4				.061	
5				.061	
6				.0762	
7				.0762	
8				.0914	.0175
9				.061	.0183
10		.0351	.0914		
11	.0358	.0152	.0914		
12	.0181	.0305	.0457		
13	.0175		.0762		
14	.0179		.0762		
15	.0179		.0762		
16	.0351		.061		
17	.0351				
24				.061	
Max	.0358	.0351	.0914	.0914	.0183
Min	.0175	.0152	.0457	.061	.0175
Avg	.0253	.0269	.0740	.0671	.0179

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

SHENDURGANAGHAT S/DN[312] BU 1651

Substation No/ Name :- 034023 / 33KV SHE'GHAT

Feeder No / Name : 201 / 11KV PUSALA AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.3353	.3944	.4382
2					.3521	.3429	.4382
3					.3521	.3429	.4382
4					.3688	.2572	.4382
5					.3856	.2572	.4382
6					.4024	.3944	.4382
7					.4024	.4115	.4382
8					.4024	.4115	.4382
9					.3856	.4115	.4382
10	.4862		.4382				
11			.4251				
12		.4382	.4251				
13	.3601	.4382	.4251				
14	.4287	.4382	.4251	.1341			
15	.4287	.4382	.4251	.0503			
16	.4287	.4382	.4066	.0335			
17	.4115	.4382	.4066	.0335			
24					.3353	.3944	.4382
Max	.4862	.4382	.4382	.1341	.4024	.4115	.4382
Min	.3601	.4382	.4066	.0335	.3353	.2572	.4382
Avg	.4240	.4382	.4221	.0629	.3722	.3618	.4382

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

SHENDURGANAGHAT S/DN[312] BU 1651

Substation No/ Name :- 034023 / 33KV SHE'GHAT

Feeder No / Name : 202 / 11KV JAMTALAO -AG-

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0671	.0953	.0191				
2	.0671	.0953	.0191				
3	.0671	.0953	.0191				
4	.0671	.0953	.0191				
5	.0671	.0953	.0191				
6	.0838		.0191				
7	.1006		.0572				
8	.1006		.0381				
9	.1006		.0572				
10				.0747	.0503	.0543	.0381
11				.0671	.0716	.0381	.0189
12				.0671	.0537	.0381	.0189
13				.0503	.0537	.0191	.0189
14					.0362	.0191	.0189
15					.0181	.0191	.0189
16					.0181		.0189
17					.0181		.0189
24	.0838	.0724	.0191				
Max	.1006	.0953	.0572	.0747	.0716	.0543	.0381
Min	.0671	.0724	.0191	.0503	.0181	.0191	.0189
Avg	.0805	.0915	.0286	.0648	.0400	.0313	.0213

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

SHENDURGANAGHAT S/DN[312] BU 1651

Substation No/ Name :- 034023 / 33KV SHE'GHAT

Feeder No / Name : 203 / 11KV SATNOOR AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3688	.3048	.1524				
2	.3688	.3048	.1524				
3	.3856	.3048	.1524				
4	.3856	.3429	.1524				
5	.4024	.362	.1524				
6	.4191		.1715				
7	.503		.1905				
8	.4694		.1905				
9	.5365		.2286				
10				.2587	.2012	.1372	.1143
11				.218	.2058	.1715	.112
12				.218	.1886	.1524	.112
13				.218	.2058	.1524	.112
14					.1928	.1524	.112
15					.0181	.1524	.112
16					.0181		.112
17					.0181		.112
24	.3353	.2743	.1524				
Max	.5365	.362	.2286	.2587	.2058	.1715	.1143
Min	.3353	.2743	.1524	.218	.0181	.1372	.112
Avg	.4175	.3156	.1696	.2282	.1311	.1531	.1123

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

SHENDURGANAGHAT S/DN[312] BU 1651

Substation No/ Name :- 034023 / 33KV SHE'GHAT

Feeder No / Name : 204 / 11KV SH'GHAT URBAN  
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5684	1.4861	1.3908	1.4175	1.3817	1.0517	1.1812
2	1.4937	1.448	1.3717	1.3969	1.2071	.964	1.1812
3	1.419	1.448	1.3527	1.2894	1.307	.8859	1.1622
4	1.307	1.2955	1.3527	1.2357	1.2883	.8505	1.1622
5	1.2323	1.1431	1.3146	1.1765	1.2696	.8238	1.1622
6	1.1203		1.0669	1.1041	1.2323	.788	.9907
7	.9149		.8573	.8688	1.0642	.6697	.8764
8	.7468		.7811	.7783	.8775	.6089	.743
9	.8215		.7621	.7783	.7095	.6154	.7811
10	.8215		.7621	.8145	.7655	.6154	.743
11	.7716		.7964	.8589	.7164	.7049	.695
12	.8402	1.2193		.9522	.7343	.8002	
13	.8745	1.1241	.9412	.8962	.7011	.8002	.8326
14	1.1488	1.1622	1.0745	.9522	.8059	.8383	.8869
15	1.1317	1.2003	1.0745	.9522	.7087	.8383	.8326
16	.8916	.9907	1.0136	.8402	.6135		.8507
17	.7373	.9145	.9593	.8589	.6485		.7783
18	.8402	.9145	.9412	.9149	.7362	.8764	1.086
19	.8745	1.0288	1.1041	1.0269	.8238	1.105	.905
20	1.1145	1.3146	1.3032	1.1949	.8939	1.1812	1.0745
21	1.166	1.2574	1.3432	1.251		1.2003	1.0745
22	1.166	1.3717	1.379	1.3817		1.2193	1.1104
23	1.3717	1.448	1.4148	1.4937	1.1043	1.2193	1.1462
24	1.6804	1.3546	1.4289	1.4506	1.4563	1.1393	1.2003
Max	1.6804	1.4861	1.4289	1.4937	1.4563	1.2193	1.2003
Min	.7373	.9145	.7621	.7783	.6135	.6089	.695
Avg	1.0856	1.2290	1.1211	1.0785	.9566	.8998	.9764

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

SHENDURGANAGHAT S/DN[312] BU 1651

Substation No/ Name :- 034023 / 33KV SHE'GHAT

Feeder No / Name : 205 / 11KV WATER FILTER

Only one consumer of WW with HT-IV

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0191	.0191	.0189	.0187	.0191	.0191
2	.0187	.0191	.0191	.0189	.0187	.0191	.0191
3	.0187	.0191	.0191	.0189	.0187	.0191	.0191
4	.0187	.0191	.0191	.0189	.0187	.0191	.0191
5	.0187	.0191	.0191	.0189	.0187	.0191	.0191
6	.0187		.0191	.0189	.0187	.0191	.0191
7	.0187		.0191	.0189	.0187	.0191	.0191
8	.0187		.0191	.0189	.0187	.0191	.0191
9	.0187		.0191	.0189	.0187	.0191	.0191
10	.0187		.0191	.0189	.0187	.0191	.0189
11	.0191		.0189	.0187	.0191	.0191	.0189
12	.0191	.0191	.0189	.0187	.0191	.0191	.0189
13	.0191	.0191	.0189	.0187	.0191	.0191	.0189
14	.0191	.0191	.0189	.0187	.0191	.0191	.0189
15	.0191	.0191	.0189	.0187	.0191	.0191	.0189
16	.0191	.0191	.0189	.0187	.0191		.0189
17	.0191	.0191	.0189	.0187	.0191		.0189
18	.0191	.0191	.0189	.0187	.0191	.0191	.0189
19	.0191	.0191	.0189	.0187	.0191	.0191	.0189
20	.0191	.0191	.0189	.0187	.0191	.0191	.0189
21	.0191	.0191	.0189	.0187		.0191	.0189
22	.0191	.0191	.0189	.0187		.0191	.0189
23	.0191	.0191	.0189	.0187	.0191	.0191	.0189
24	.0187	.0191	.0191	.0189	.0187	.0191	.0191
Max	.0191	.0191	.0191	.0189	.0191	.0191	.0191
Min	.0187	.0191	.0189	.0187	.0187	.0191	.0189
Avg	.0189	.0191	.0190	.0188	.0189	.0191	.0190

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

SHENDURGANAGHAT S/DN[312] BU 1651

Substation No/ Name :- 034023 / 33KV SHE'GHAT

Feeder No / Name : 206 / 11 KV Tiwsa Ghat

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.1905	.1905	.2054	.2054	.1448	.1524
2	.2054	.1905	.1905	.2033	.1867	.1448	.1524
3	.1867	.1715	.1905	.1867	.1867	.1448	.1524
4	.1867	.1715	.1715	.1867	.168	.1448	.1524
5	.168	.1524	.1715	.168	.168	.1448	.1524
6	.1494		.1524	.1494	.1494	.1267	.1334
7	.1307		.1334	.1307	.1307	.1267	
8	.112		.1334	.1307	.112	.1086	
9	.112		.1143	.112	.0934	.1267	
10	.112		.0953	.1307	.112	.1267	
11	.1086		.112	.112	.1086	.1143	.112
12	.1267		.112	.056	.0905	.0953	.112
13	.1267	.1524	.1307	.0187	.1086	.0953	.112
14	.1629	.1524	.1494	.0187	.1086	.1143	.112
15	.1448	.1524	.1494	.1307	.1086	.0953	.1307
16	.1448	.1524	.1494	.112	.0905		.1307
17		.0953	.1307	.112	.0905		.1307
18	.1086	.1143	.112	.1494	.1086	.0762	.1307
19	.1267	.0191	.168	.1494	.1267	.1524	.1307
20	.181	.1905	.1867	.168	.1448	.1905	.1494
21	.1629	.1715	.1867	.168		.1715	.1494
22	.1629	.1905	.2033	.1867		.1715	.1494
23	.181	.1905	.2033	.2054	.1629	.1524	.1494
24	.2241	.181	.1905	.2033	.2054	.1629	.1524
Max	.2241	.1905	.2033	.2054	.2054	.1905	.1524
Min	.1086	.0191	.0953	.0187	.0905	.0762	.112
Avg	.1535	.1552	.1553	.1414	.1348	.1332	.1373



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

SHENDURGANAGHAT S/DN[312] BU 1651

Substation No/ Name :- 034023 / 33KV SHE'GHAT

Feeder No / Name : 207 / 11KV JAMTALAO -GAOTHAN- Only one consumerof WW with HT-IV  
Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0191	.0191	.0189	.0187	.0191	.0191
2	.0187	.0191	.0191	.0189	.0187	.0191	.0191
3	.0187	.0191	.0191	.0189	.0187	.0191	.0191
4	.0187	.0191	.0191	.0189	.0187	.0191	.0191
5	.0187	.0191	.0191	.0189	.0187	.0191	.0191
6	.0187		.0191	.0189	.0187	.0191	.0191
7	.0187		.0191	.0189	.0187	.0191	.0191
8	.0187		.0191	.0189	.0187	.0191	.0191
9	.0187		.0191	.0189	.0373	.0191	.0191
10	.0373		.0191	.0189	.0373	.0191	.0191
11	.0381		.0189	.0187	.0191	.0191	.0189
12	.0191	.0191	.0189	.0187	.0191	.0191	.0189
13	.0191	.0191	.0189	.0187	.0191	.0191	.0189
14	.0191	.0191	.0189	.0187	.0381	.0191	.0189
15	.0191	.0191	.0189	.0187	.0191	.0191	.0189
16	.0191	.0191	.0189	.0187	.0191		.0189
17	.0191	.0191	.0189	.0187	.0191		.0189
18	.0191	.0191	.0189	.0187	.0191	.0191	.0189
19	.0191	.0191	.0189	.0187	.0191	.0191	.0189
20	.0191	.0191	.0183	.0187	.0191	.0191	.0189
21	.0191	.0191	.0189	.0187		.0191	.0189
22	.0191	.0191	.0189	.0187		.0191	.0189
23	.0191	.0191	.0189	.0187	.0191	.0191	.0189
24	.0187	.0191	.0191	.0189	.0187	.0191	.0191
Max	.0381	.0191	.0191	.0189	.0381	.0191	.0191
Min	.0187	.0191	.0183	.0187	.0187	.0191	.0189
Avg	.0205	.0191	.0190	.0188	.0215	.0191	.0190

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

SHENDURGANAGHAT S/DN[312] BU 1651

Substation No/ Name :- 034023 / 33KV SHE'GHAT

Feeder No / Name : 208 / 11 KV Satnoor-Gaothan-  
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.1334	.1334	.1307	.1307	.1086	.0953
2	.1307	.1334	.1334	.1307	.1307	.1086	.0953
3	.1307	.1334	.1334	.1307	.1307	.1086	.0953
4	.1307	.1334	.1334	.1307	.1307	.1086	.0953
5	.1307	.1334	.1334	.1307	.1307	.1086	.0953
6	.112		.1334	.1307	.1494	.1086	.0953
7	.112		.1334	.112	.1307	.1086	.1334
8	.112		.1334	.0934	.1307	.1086	.1334
9	.0187		.1143	.0934	.1307	.0905	.1334
10	.112		.1143	.0934	.0934	.0905	.1143
11	.1086		.112	.112	.0724		.0934
12	.1086	.1143	.112	.112	.0724	.0762	.0934
13	.1086	.1143	.112	.112	.0724	.0953	.0934
14	.1267	.0953	.112	.0934	.1086	.0953	.0934
15	.1086	.0953	.112	.0747	.0905	.0762	.0934
16	.0905	.0762	.112	.0747	.0905		.0934
17	.0724	.0953	.0934	.112	.0905		.0934
18	.1086	.1143	.0934	.112	.0905	.0762	.0189
19	.1086	.1143	.112	.1307	.1086	.1334	.0934
20	.1267	.1524	.1494	.1307	.1086	.1524	.0934
21	.1267	.1524	.1494	.1307		.1524	.0934
22	.1267	.1334	.1307	.1307		.1334	.0934
23	.1267	.1334	.1307	.1307	.1629	.1143	.0934
24	.1494	.1267	.1334	.1307	.1307	.1267	.1143
Max	.1494	.1524	.1494	.1307	.1629	.1524	.1334
Min	.0187	.0762	.0934	.0747	.0724	.0762	.0189
Avg	.1132	.1214	.1233	.1151	.1130	.1086	.0975

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

SHENDURGANAGHAT S/DN[312] BU 1651

Substation No/ Name :- 034036 / 33KV PUSALA

Feeder No / Name : 201 / 11KV PUSALA GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5144	.4954	.5335	.4954	.4382	.4382
2	.5716	.5144	.4954	.5335	.4954	.4191	.4382
3	.5716	.5144	.4763	.5335	.4954	.4191	.4382
4	.5335	.5144	.4572	.4954	.4763	.381	.4191
5	.4572	.4954	.381	.4572	.4572	.3429	.381
6	.381	.362	.3429	.381	.381	.3048	.3239
7	.3429	.2858	.2477	.3048	.3048	.2667	.2667
8	.2477	.2477	.3048	.2667	.2286	.2286	.2286
9	.3239		.3048	.2858	.2667	.2286	.2667
10	.3048	.2858	.3239	.3239	.2858	.3048	.2286
11	.2858		.381	.4001	.3429	.2286	.2667
12	.3429	.381	.381	.381	.3048	.2858	.2667
13	.4001	.4191	.381	.362	.3048	.3239	.3048
14	.4001	.4572	.4191	.4382	.3048	.2667	.3429
15	.5335	.4001	.4763	.381	.2667	.2286	.3239
16	.4763	.381	.4191	.3048	.3048	.2096	.2858
17	.3429	.3239	.381	.3239	.2667	.2286	.3048
18	.362	.381	.4191	.3429	.3239	.2858	.3429
19	.381	.381	.362	.381	.3239	.3429	.362
20	.4572	.4572	.4954	.4191	.4001	.4191	.381
21		.4572	.4954	.4572	.4001	.4191	.4001
22	.5335	.5144	.5525	.4954	.4382	.4382	.4382
23	.5335	.5144	.5525	.4954	.4382	.4382	.4191
24	.5716	.5144	.4954	.5335	.4954	.4382	.4382
Max	.5716	.5144	.5525	.5335	.4954	.4382	.4382
Min	.2477	.2477	.2477	.2667	.2286	.2096	.2286
Avg	.4316	.4235	.4183	.4096	.3667	.3286	.3461

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

SHENDURGANAGHAT S/DN[312] BU 1651

Substation No/ Name :- 034036 / 33KV PUSALA

Feeder No / Name : 202 / 11KV URAD AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1905	.1524				
2	.1715	.1905	.1524				
3	.1715	.1905	.1905				
4	.1715	.1905	.1905				
5	.1715	.1905	.2286				
6	.1905	.1715	.2286				
7	.2286		.2286				
8	.3048	.0191	.2286				
9	.2667		.2477				
10					.381	.1715	.0191
11				.4001	.4572	.3429	.0191
12				.4001	.4001	.381	.0191
13				.4191	.4001	.3048	.0191
14				.4191	.381	.0762	.0191
15				.381		.0381	.0191
16				.381	.1524	.0191	.0191
17					.1524	.0191	
24	.1715		.1524				
Max	.3048	.1905	.2477	.4191	.4572	.381	.0191
Min	.1715	.0191	.1524	.381	.1524	.0191	.0191
Avg	.2020	.1633	.2000	.4001	.3320	.1691	.0191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

SHENDURGANAGHAT S/DN[312] BU 1651

Substation No/ Name :- 034036 / 33KV PUSALA

Feeder No / Name : 203 / 11KV LINGA AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0381		.0191	.0191	.0381
2	.0381	.0381	.0381		.0191	.0191	.0381
3	.0381	.0381	.0191		.0191	.0191	.0381
4	.0381	.0381	.0191		.0191	.0191	.0381
5	.0381	.0381	.0191		.0191	.0381	.0381
6	.0381	.0381	.0381		.0191	.0381	.0381
7	.0381	.0381	.0191		.0381	.0191	.0381
8	.0572	.0381	.0381		.0381	.0191	.0381
9	.0381		.0381		.0572	.0191	.0381
10	.0572	.0762	.0381		.0381	.0191	.0381
11	.0572		.0953		.0191	.0191	.0191
12	.0953		.0762		.0191	.0572	
13	.0572	.0762	.1143	.0191	.0191	.0381	
14	.0953	.0572	.1143	.0381	.0191		.0762
15	.0953	.0572	.1334	.0381			
16	.0953	.0572	.1143	.0381	.0191	.0381	
17		.0381	.1334	.0381	.0381	.0381	
18	.0381	.0191	.0572	.0381	.0572	.0381	
19	.0381	.0381	.0572	.0381	.0381	.0381	
20	.0381	.0381	.0572	.0381	.0381	.0381	
21	.0381	.0381	.0572	.0191	.0381	.0381	
22	.0381	.0381	.0572	.0191	.0381	.0381	
23	.0381	.0381	.0381	.0191	.0381	.0381	
24	.0572	.0381	.0381		.0191	.0381	.0381
Max	.0953	.0762	.1334	.0381	.0572	.0572	.0762
Min	.0381	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0522	.0436	.0604	.0312	.0298	.0312	.0396

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

SHENDURGANAGHAT S/DN[312] BU 1651

Substation No/ Name :- 034036 / 33KV PUSALA

Feeder No / Name : 204 / 11KV URAD GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2477	.2286	.2286	.2096	.1905	.2096
2	.2286	.2477	.2286	.2286	.2096	.1905	.2096
3	.2286	.2477	.2286	.2286	.2096	.1905	.2096
4	.2096	.2477	.1905	.2096	.1905	.1524	.1905
5	.1905	.2286	.1905	.1905	.1905	.1524	.1715
6	.1334	.1715	.1524	.1524	.1524	.1143	.1334
7	.1524	.1143	.1143	.0953	.1334	.0953	.0953
8	.1334	.1334	.1524	.1524	.1334	.0953	.1334
9	.1524		.1524	.1524	.1524	.0953	.1143
10	.1334	.1524	.1524		.1524	.0762	.0953
11	.1143		.1524	.1905	.1334	.0953	.0572
12	.1524	.0953	.1524	.1715	.0953	.0953	.1143
13	.1524	.1143	.1715	.1334	.1143	.0762	.1334
14	.1905	.1143	.1715	.1334	.1143	.1143	.0953
15	.1524	.1143	.1715	.1334	.1143	.1143	.0953
16	.1524	.0953	.1715	.0953	.0762	.0953	
17	.1334	.0762	.1715	.1143	.0762	.1143	
18	.1334	.0953	.1334	.1334	.0953	.1334	
19	.1715	.1334	.1715	.1715	.1334	.1715	.1334
20	.2477	.2096	.2477	.1905	.1905	.1905	.1715
21	.2286	.2096	.2477	.2096	.2096	.2096	.1715
22	.2667	.2286	.2477	.2286	.1905	.2096	.1715
23	.2477	.2286	.2477	.2096	.1905	.2096	.1715
24	.2286	.2477	.2096	.2286	.2096	.1905	.2096
Max	.2667	.2477	.2477	.2286	.2096	.2096	.2096
Min	.1143	.0762	.1143	.0953	.0762	.0762	.0572
Avg	.1818	.1706	.1858	.1731	.1532	.1405	.147

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

SHENDURGANAGHAT S/DN[312] BU 1651

Substation No/ Name :- 034036 / 33KV PUSALA

Feeder No / Name : 205 / 11 KV PUSLA AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0762	.1143	.1334	.1143	.0953
2	.0572	.0572	.0762	.1143	.1334	.1143	.0953
3	.0572	.0572	.0381	.1143	.1334	.1524	.0953
4	.0572	.0572	.0381	.1524	.1334	.1524	.0953
5	.0572	.0572	.0762	.1905	.1334	.1524	.0953
6				.381	.1334	.1715	.0953
7				.1905	.1334	.1715	.1143
8				.2858	.1715	.1524	.0953
9				.2858	.1524	.1524	.1143
10	.3048	.1524	.1715				
11	.2477		.2286				
12	.2286	.1524	.1905				
13	.2858	.1524	.2286				
14	.2477	.1524	.2286				
15	.2477	.1524	.2286				
16	.1715	.1715	.1715				
17		.1715	.1905				
18	.0381	.0381	.0381	.0381			
19	.0572	.0572	.0572	.0572		.0381	
20	.0762	.0572	.0572	.0572	.0572	.0381	.0381
21	.0572	.0572	.0572	.0572	.0572	.0381	.0381
22	.0572	.0572	.0572	.0572	.0572	.0381	.0381
23	.0572	.0762	.0953	.0572	.0381	.0381	.0381
24	.0572	.0572	.0762	.0953	.1334	.1143	.0953
Max	.3048	.1715	.2286	.381	.1715	.1715	.1143
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.1274	.0943	.1191	.1405	.1143	.1092	.0817

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

SHENDURGANAGHAT S/DN[312] BU 1651

Substation No/ Name :- 034036 / 33KV PUSALA

Feeder No / Name : 206 / 11 kv Linga Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1143	.0953	.1143	.0953	.0953	.0762
2		.1143	.0953	.1143	.0953	.0953	.0762
3		.1143	.0953	.1143	.0953	.0762	.0762
4		.0953	.0762	.1143	.0953	.0762	.0762
5		.0953	.0762	.0953	.0953	.0762	.0762
6		.0762	.0572	.0762	.0762	.0572	.0762
7			.0572	.0572	.0572	.0572	.0572
8			.0381	.0572	.0572	.0572	.0381
9			.0572	.0572	.0572	.0381	.0381
10	.0572	.0191	.0381	.0572	.0572	.0381	.0381
11	.0762		.0572	.0572	.0572	.0191	.0381
12	.0762		.0572	.0572	.0572	.0381	.0381
13	.0762	.0381	.0762	.0572	.0381	.0381	
14	.0762	.0572	.0762	.0572	.0381		.0381
15	.0572	.0572	.0762	.0381			.0381
16	.0572	.0572	.0572	.0381			.0381
17		.0381	.0572	.0572			.0381
18	.0572	.0381	.0572	.0572		.0381	.0381
19	.0762	.0762	.0572	.0572		.0762	.0762
20	.0953	.0953	.1143	.0953	.0953	.0953	
21	.1143	.1143	.1143	.1143	.0953	.0953	.0953
22	.1143	.1143	.1143	.1143	.0953	.0953	.0953
23	.1143	.1143	.1143	.1143	.0953	.0953	.1143
24	.0953	.0953	.0953	.1143	.0953	.0953	.0762
Max	.1143	.1143	.1143	.1143	.0953	.0953	.1143
Min	.0572	.0191	.0381	.0381	.0381	.0191	.0381
Avg	.0817	.0802	.0754	.0786	.0762	.0677	.0615



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

SHENDURGANAGHAT S/DN[312] BU 1651

Substation No/ Name :- 034047 / 33 TEMBHURKHEDA

Feeder No / Name : 201 / 11 KV TEMBHURKHEDA GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5906	.5335	.5335	.5716	.4954	.4763
2		.5906	.5335	.5335	.5716	.4954	.4763
3		.5335	.5335	1.5623	.5716	.4954	.4572
4		.5335	.5335	.5335	.5716	.4954	.4572
5		.5335	.4763	.5335	.5335	.4572	.4572
6		.4954	.3982	.4382	.4572	.4001	.4572
7		.3429	.3475	.381	.381	.362	.3239
8	.1905	.3048	.2858	.3239	.3239	.3239	.3048
9		.3048	.2804	.3048	.3048	.3048	.2534
10	.3239	.2858	.3048	.3239	.3048	.3048	.2454
11	.3239	.3429	.3429	.3429	.3239	.3048	.2477
12	.4382	.3429	.3429	.381	.3429	.3048	.2858
13	.4572	.4001	.381	.362	.3239	.2096	.2667
14	.4382	.4572	.4191	.381	.3239	.2172	.2667
15	.4763	.3841	.4382	.3048	.3048	.2096	.3048
16	.381	.2926	.381	.3048	.3048	.2286	.3048
17	.3048	.2926	.3048	.3048	.2667	.3048	.2858
18	.3429	.3429	.3429	.3239	.3048	.3048	.2858
19	.381	.362	.4191	.4191	.381	.381	.2858
20	.5144	.5144	.4572	.4954	.4763	.4572	.381
21		.5525	.5716	.5144	.4954	.4954	.4001
22		.5716	.6287	.5716	.4954	.5144	.5144
23	.6097	.5525	.6287	.5716	.5144	.4706	.4954
24	.6287	.5335		.6097	.5716	.4954	
Max	.6287	.5906	.6287	1.5623	.5716	.5144	.5144
Min	.1905	.2858	.2804	.3048	.2667	.2096	.2454
Avg	.4151	.4357	.4298	.4731	.4176	.3764	.3580

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

SHENDURGANAGHAT S/DN[312] BU 1651

Substation No/ Name :- 034047 / 33 TEMBHURKHEDA

Feeder No / Name : 202 / 11 KV TEMBHURKHEDA AG  
Feeder KV- 11 / OUTGOING

AG Feeder with SDT

DATE	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4382	.381	.381			
2	.4382	.381	.381			
3	.4382	.381	.381			
4	.4191	.381	.381			
5	.4191	.381	.381			
6	.4572	.381	.4001			
7	.5335	.4001	.4954			
8	.4763	.4572	.5335			
9	.4763	.0171	.5716			
10			.4572	.4763	.4191	.362
11			.4763	.5716	.4572	.4001
12			.4572	.5144	.4572	.4191
13			.4763	.5144	.4163	.381
14			.4572	.4954	.4207	.4191
15			.4572	.4572	.4382	.4191
16			.5335	.4572	.4572	.4191
17			.4572	.4572	.381	.4191
24	.4001		.381			
Max	.5335	.4572	.5716	.5716	.4572	.4191
Min	.4001	.0171	.381	.4572	.381	.362
Avg	.4496	.3512	.4477	.4930	.4309	.4048

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

SHENDURGANAGHAT S/DN[312] BU 1651

Substation No/ Name :- 034047 / 33 TEMBHURKHEDA

Feeder No / Name : 203 / 11 KV GHAVANKUND AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286			.1905	.0953	.0762
2	.2286			.1905	.0953	.0762
3	.2286			.1905	.0953	.0762
4	.1905			.1905	.0953	.0762
5	.1715			.1905	.0953	.0762
6	.1715			.1905	.0953	.0762
7	.2096			.2096	.1143	.1143
8	.2667			.2286	.1143	.1334
9	.2286			.2286	.1524	.1097
10	.2667	.2667	.2715			
11	.362	.2477	.2858			
12	.2667	.2286	.2858			
13	.2667	.2195	.2858			
14	.2667	.2195	.2667			
15	.2096	.2012	.2667			
16	.2477	.181	.2667			
17	.2477	.2378	.3048			
24	.2286			.1524	.0953	
Max	.362	.2667	.3048	.2286	.1524	.1334
Min	.1715	.181	.2667	.1524	.0953	.0762
Avg	.2381	.2253	.2792	.1962	.1048	.0905

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

WARUD (I)[309]

BU 3093

Substation No/ Name :- 034017 / 33KV RAJURA BZR

Feeder No / Name : 201 / 11KV RAJURA BZR AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2401	.08	.1334	.1467		
2		.2134	.08	.1334	.1467		
3		.2134	.08	.1334	.1467		
4		.2	.08	.1334	.1467		
5		.2667	.08	.1334	.1467		
6		.2801	.08	.2267	.12		
7		.2801	.08	.3601	.1467		
8		.3201	.12	.3467	.16		
9		.2	.1334	.4134	.12		
10	.4801				.2667		.1067
11	.6135				.2267		.1734
12	.5201				.16		.2
13	.4401				.1334		.0934
14					.0934		.0934
15					.0667		.0934
16					.0667		.0934
17					.0667	.1734	.0934
24		.2534	.08	.1334	.1467		
Max	.6135	.3201	.1334	.4134	.2667	.1734	.2
Min	.4401	.2	.08	.1334	.0667	.1734	.0934
Avg	.5135	.2467	.0893	.2147	.1393	.1734	.1184

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

WARUD (I)[309]

BU 3093

Substation No/ Name :- 034017 / 33KV RAJURA BZR

Feeder No / Name : 202 / 11KV HATURNA OLD AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934				.0934		.04
2	.08				.0934		
3	.0934				.0934		
4	.1067				.0934		
5	.1334				.0934		
6	.1734				.08		
7	.2934				.0934		.04
8	.3734				.08		.0667
9	.3734				.12	.0934	.0934
10	.3601	.2	.16	.3467			
11	.3467	.2934	.2134	.3601			
12	.2934	.2934	.1867	.3868			
13	.2667	.2667	.2134				
14	.2534	.2401	.2134				
15	.2401	.2	.1867				
16	.3067	.1334	.2134				
17			.2534				
24	.08				.0934		.0533
Max	.3734	.2934	.2534	.3868	.12	.0934	.0934
Min	.08	.1334	.16	.3467	.08	.0934	.04
Avg	.2275	.2324	.2051	.3645	.0934	.0934	.0587

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

WARUD (I)[309]

BU 3093

Substation No/ Name :- 034017 / 33KV RAJURA BZR

Feeder No / Name : 203 / 11KV PAWANI AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1734		.0934	.12		
2		.16		.0934	.12		
3		.1734		.0934	.12		
4		.1867		.0934	.12		
5		.16		.0934	.12		
6		.1734		.12	.1334		
7		.1467		.2401	.16		
8		.16	.04	.3067	.1067		
9		.1734	.1334	.4268	.2		
10	.4401				.2534		.1467
11	.4401				.2401		.1067
12	.4134				.2667		.0934
13	.3734				.2667		.12
14					.1334	.12	.0934
15					.1334		.0934
16					.1334		.0934
17					.1334	.0934	
24		.1867		.0934	.12		
Max	.4401	.1867	.1334	.4268	.2667	.12	.1467
Min	.3734	.1467	.04	.0934	.1067	.0934	.0934
Avg	.4168	.1694	.0867	.1654	.1600	.1067	.1067

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

WARUD (I)[309]

BU 3093

Substation No/ Name :- 034017 / 33KV RAJURA BZR

Feeder No / Name : 204 / 11KV Rajura Gaothan Feeder

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2058	.2058	.2058	.1886	.1715	.1715
2	.2229	.2058	.2058	.2058	.1886	.1715	.1543
3	.2058	.1715	.2058	.2058	.1886	.1715	.1715
4	.2229	.1886	.2058	.2058	.1886	.1715	.1715
5	.1886	.1715	.1715	.2058	.1886	.1715	.1543
6	.1715	.1543	.0857	.1715	.1543	.12	.1372
7	.1372	.1029	.0857	.12	.1372	.12	.1029
8	.1372	.1029	.1029	.12	.12	.12	.1029
9	.12	.0857	.12	.1029	.12	.1029	.1029
10	.1029	.12	.12	.12	.1029		.1029
11	.12	.1543	.1029	.12	.1029		.0857
12	.1372	.1543	.1372	.12	.12		.1029
13	.1715	.1543	.1372	.0857	.12		.12
14	.1886	.1543	.1372	.0514	.12		.12
15	.1715	.1372	.1372	.12	.0857		.12
16	.1543	.1029	.1029	.12	.0857		.12
17		.1029	.1372	.12	.0857	.1029	.1029
18	.12	.12	.1372	.1029	.12	.12	.1029
19	.1543	.1372	.1715	.12	.1372	.1543	.1029
20	.2058	.2058	.2058	.1543	.1715	.1715	.12
21	.2229	.2058	.2229	.1886	.1715	.1715	.1543
22	.2229	.2058	.2401	.1886	.1715	.1715	.1715
23	.2229	.2058	.2229	.1886	.1715	.1715	.1715
24	.2229	.2058	.2058	.2058	.1886	.1715	.1715
Max	.2229	.2058	.2401	.2058	.1886	.1715	.1715
Min	.1029	.0857	.0857	.0514	.0857	.1029	.0857
Avg	.1759	.1565	.1586	.1479	.1429	.1503	.1308

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

WARUD (I)[309]

BU 3093

Substation No/ Name :- 034017 / 33KV RAJURA BZR

Feeder No / Name : 205 / 11KV Pawani Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.3772	.3944	.4287	.3772	.3429	.3429
2	.4287	.3429	.3944	.4287	.3772	.3429	.3086
3	.4458	.3429	.3944	.4287	.3772	.3429	.3429
4	.3944	.3086	.3429	.4287	.3772	.3429	.3258
5	.3429	.3086	.3429	.4287	.3772	.3086	.2915
6	.3258	.2915	.3086	.3429	.3258	.2572	.2572
7	.2229	.2058	.2058	.2229	.2229	.2058	.1886
8	.2058	.1886	.2058	.1886	.2058		.1715
9	.1715	.2058	.3258	.1715	.1886	.1715	.1886
10	.2058	.1715	.2058	.1372	.2058		.1715
11	.1543	.2058	.1886	.2058	.1715	.1715	.1715
12	.1715	.2058	.2229	.2401	.2058	.1543	.1715
13	.2743	.2058	.2915	.2058	.2058	.1715	.1715
14	.3086	.2058	.3258	.2058	.2058	.1715	.1886
15	.3086	.1715	.3258	.2401	.1715		.1886
16	.2743		.2743	.1886	.1715		.1715
17		.1543	.2229	.1886	.1715	.1543	.12
18	.1543	.1715	.2058	.2058	.1715	.1715	.12
19	.1886	.1886	.2229	.2572	.1715	.2401	
20	.3601	.3944	.3772	.3601	.3086	.3258	
21	.3944	.3944	.4115	.3944	.3429	.3429	
22	.4287	.3944	.4287	.3944	.3429	.3258	
23	.4287	.3944	.4287	.3944	.3429	.3258	
24	.4458	.4115	.3944	.4287	.3772	.3429	.3429
Max	.4458	.4115	.4287	.4287	.3772	.3429	.3429
Min	.1543	.1543	.1886	.1372	.1715	.1543	.12
Avg	.3079	.2714	.3101	.2965	.2665	.2606	.2229



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

WARUD (I)[309]

BU 3093

Substation No/ Name :- 034017 / 33KV RAJURA BZR

Feeder No / Name : 206 / 11KV HATURNA GAOTHAN  
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2572	.2058	.2572	.2229	.2229	.2058
2	.2401	.2401	.2058	.2572	.2229	.2229	.1886
3	.2572	.2572	.2058	.2572	.2229	.2229	.2058
4	.2058	.2058	.2058	.2572	.2229	.2058	.1715
5	.2058	.1886	.1715	.2572	.2229	.1715	.1715
6	.1715	.1715	.0857	.1886	.1886	.1543	.1543
7	.1372	.12	.0857	.1715	.1029	.1372	.1029
8	.1029	.1029	.1029	.1372	.1029	.1372	.1029
9	.1372	.12	.12	.12	.1029	.12	.1029
10	.1372	.12	.12	.1543	.1029		.0857
11	.1715	.1372	.0686	.1029	.1029	.0857	.0857
12	.1886	.1372	.1372	.1886	.1715	.12	.1029
13	.2058	.1372	.1372	.1886	.1715	.1029	.12
14	.2401	.1372	.1715	.1029	.1715	.1029	.1372
15	.2229	.1372	.1543	.12	.12		.1372
16	.1715	.1029	.1372	.1372	.12		.12
17		.1029	.12	.12	.12	.1372	.12
18	.12	.1029		.12	.12	.12	
19	.12	.1372		.1886	.2058	.1715	.12
20	.2401	.2058	.2743	.2229	.2401	.2058	.1886
21	.2572	.2058	.2915	.2401	.2401	.2229	.2058
22	.2743	.2058	.2401	.2401	.2401	.2058	.2058
23	.2743	.2058	.2572	.2229	.2401	.2058	.2058
24	.2743	.2572	.2058	.2572	.2229	.2229	.2058
Max	.2743	.2572	.2915	.2572	.2401	.2229	.2058
Min	.1029	.1029	.0686	.1029	.1029	.0857	.0857
Avg	.2006	.1665	.1684	.1879	.1751	.1666	.1499

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

WARUD (I)[309]

BU 3093

Substation No/ Name :- 034024 / 33KV CHANDAS WATHODA

Feeder No / Name : 201 / Shekapur Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4163	.3801	.362	.3982	.3801	.3258	.3258
2	.4163	.3801	.362	.3982	.3801	.3086	.3258
3	.4163		.362	.3801	.3801	.2915	.3258
4	.3982	.362	.333	.3801	.362	.3077	.3258
5	.3258	.2534	.3258	.2896	.2896	.2743	.2715
6	.2896	.2534	.2534	.2896	.2534	.2172	.2353
7	.2353	.181	.181	.2172	.2172	.2172	.2172
8	.2172	.1629	.181	.2172	.2172	.2172	.2172
9	.2353	.1629	.2172	.2172	.1991	.2353	.2172
10	.2353	.2172	.2353	.2534	.181	.181	.1991
11	.1991	.2172	.2534	.2534	.181	.1991	.181
12	.2534	.2353	.2534	.2534	.2172	.181	.181
13	.2896	.2534	.2896	.2715	.2172	.181	.181
14	.2896	.2896	.3077	.2534	.181	.181	.181
15	.2353	.2534	.2591	.2534	.1629	.2172	.1991
16	.2353	.1991	.2534	.1991	.2172	.1753	.3258
17		.181	.1991	.181	.1629	.1991	.1629
18	.181	.1991	.2172	.2172	.181	.1991	.1991
19	.2534	.2534	.2353	.2896	.2172	.2534	.1781
20	.3982	.3801	.362	.3439	.3077	.3258	.2534
21	.3801	.3982	.3982	.362	.3077	.362	.2534
22	.3982	.3801	.2972	.3982		.3258	.3077
23	.3982	.3801	.4163	.3982	.3258	.3258	.298
24	.4163	.3801	.362	.3982	.3801	.3258	.3258
Max	.4163	.3982	.4163	.3982	.3801	.362	.3258
Min	.181	.1629	.181	.181	.1629	.1753	.1629
Avg	.3093	.2762	.2882	.2964	.2573	.2511	.2453

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

WARUD (I)[309]

BU 3093

Substation No/ Name :- 034024 / 33KV CHANDAS WATHODA

Feeder No / Name : 202 / Dhaga Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0686	.0671	.0671			
2		.0686	.0671	.0671			
3		.0686	.0671	.0503			
4		.0686	.0671	.0335			
5		.0686	.0671	.0503			
6		.0686	.0671	.0671			
7		.0857	.0671	.0671			
8		.0686	.0671	.0838			
9		.061	.1006	.1341			
10	.1174				.12		.0503
11	.1174				.0154	.0335	.0503
12	.1006				.1029	.0671	.0503
13	.1341				.1029	.0503	.0503
14				.1029	.0686	.0503	.0503
15				.1006	.0181	.0503	.0503
16				.1174	.0181	.0503	.0373
17				.1006	.0671	.0503	
19							.0335
24		.0686	.0671	.0671			
Max	.1341	.0857	.1006	.1341	.12	.0671	.0503
Min	.1006	.061	.0671	.0335	.0154	.0335	.0335
Avg	.1174	.0696	.0705	.0792	.0641	.0503	.0466

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

WARUD (I)[309]

BU 3093

Substation No/ Name :- 034024 / 33KV CHANDAS WATHODA

Feeder No / Name : 203 / Shekapur Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.116				.0995	.0838	.0663
2	.116				.0995	.0838	.0663
3	.116				.0995	.0838	.0497
4	.116				.116	.0838	.0497
5	.0977				.0995	.0857	.0497
6	.1492				.0995	.0838	.0497
7	.1326				.1326	.1006	.0497
8	.1326				.1658	.1006	.0663
9	.1823				.12		.0829
10		.061	.1094	.2229			
11		.0762	.1006	.2229			
12			.0838	.2743			
13		.0838	.0762	.0857			
14	.1326	.061	.0762				
15	.1029	.0686	.0838				
16	.1029	.0514	.1134				
17		.0686	.1296				
24	.116		.0191	.0191	.0995	.0838	.0663
Max	.1823	.0838	.1296	.2743	.1658	.1006	.0829
Min	.0977	.0514	.0191	.0191	.0995	.0838	.0497
Avg	.1241	.0672	.0880	.1650	.1131	.0877	.0597

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

WARUD (I)[309]

BU 3093

Substation No/ Name :- 034039 / 33KV GADEGAON

Feeder No / Name : 201 / 11KV WAGHAL GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4463	.4641	.3772	.3749	.3574	.3217	.3574
2	.4463	.4641	.3772	.357	.3574	.3217	.3574
3	.4284	.4641	.3772	.357	.3574	.3217	.3395
4	.4284	.4284	.3429	.3213	.3574	.3217	.3395
5	.4284	.357	.3086	.2499	.3574	.2681	.3213
6	.357	.3035	.2743	.2499	.3038	.2144	.2678
7	.2678	.2678	.2058	.1964	.2502	.1608	.2142
8	.2321	.2678	.1886	.1966	.2502	.1787	.2505
9	.2856	.2678	.1886	.2323	.2859	.2144	.2505
10	.2499	.2678	.1886	.1966	.2502	.1608	.2147
11	.2321	.2856	.1964	.2502	.2681	.1966	.2058
12	.1607	.3086		.2859	.3038	.2144	.2229
13	.2678	.3772	.2856	.2681	.2502	.2323	.2572
14	.4106	.3429	.2678		.2144	.2859	.2572
15	.4106	.3772	.357	.0894		.2502	.2915
16	.3392	.2401	.3035	.2681	.1072	.2681	.2743
17	.2321	.2401	.2856	.2502	.1072	.2681	.2572
18	.2678	.2401	.2856	.3038		.2681	.2401
19	.2856	.2743	.3392	.3574	.2859	.3217	.2572
20	.4284	.3944	.3927	.3574	.3395	.3932	.3086
21	.482	.4115	.4284	.3574	.3574	.3932	.3086
22	.482	.3944	.4284	.3932	.3395	.3932	.3258
23	.482	.4115	.4106	.3753	.3395	.3753	.3086
24	.4998	.482	.3944	.3749	.3753	.3395	.3753
Max	.4998	.482	.4284	.3932	.3753	.3932	.3753
Min	.1607	.2401	.1886	.0894	.1072	.1608	.2058
Avg	.3563	.3472	.3132	.2897	.2916	.2785	.2835

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

WARUD (I)[309]

BU 3093

Substation No/ Name :- 034039 / 33KV GADEGAON

Feeder No / Name : 202 / 11KV HATURNA NEW AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2918	.1829	.184	.0767		
2	.2918	.1829	.184	.0767		
3	.2918	.1829	.184	.0767		
4	.2918	.1829	.184	.0767		
5	.2918	.1829	.2147	.0767		
6	.2918	.1219	.2454	.1072		
7	.2918	.0914	.2764	.1072		
8		.1067	.2918	.1836		
9		.1524	.3374	.2142		
10				.1836		.0458
11				.1836	.0459	.0457
12				.2295	.0306	.0457
13				.2448	.0306	.0457
14				.0918		.0457
15				.0918	.0306	.0457
16				.0918	.0306	.0457
17				.0918	.0306	.061
24	.2907	.1829	.1687	.0767		
Max	.2918	.1829	.3374	.2448	.0459	.061
Min	.2907	.0914	.1687	.0767	.0306	.0457
Avg	.2917	.1570	.2270	.1267	.0332	.0476

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

WARUD (I)[309]

BU 3093

Substation No/ Name :- 034039 / 33KV GADEGAON

Feeder No / Name : 203 / 11KV NANDGAON AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2414					.0688
2	.2414					.0688
3	.2414					.0688
4	.2414					.0688
5	.2414					.0688
6	.3219					.0825
7	.5223					.0825
8	.6706					.1236
9	.7532				.1238	.0962
10	.7014	.4371	.0533	.4801		
11	.744	.5198	.0685	.5761		
12	.7305	.5335		.5769		
13	.6899	.4268		.5495		
14	.6763	.4401	.1644			
15	.683	.4001	.2469			
16	.7084		.2881	.0687		
17		.0667	.2881	.1513		
24	.2414					.0687
Max	.7532	.5335	.2881	.5769	.1238	.1236
Min	.2414	.0667	.0533	.0687	.1238	.0687
Avg	.5088	.4034	.1849	.4004	.1238	.0798

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

WARUD (I)[309]

BU 3093

Substation No/ Name :- 034066 / 33 KV WARUD

Feeder No / Name : 201 / 11 KV WARUD TOWN 1

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9404	1.6461	1.5364	1.7375	1.5181	1.2437	1.2254
2	1.7926	1.6095	1.4842	1.6832	1.448	1.2071	1.2197
3	1.7556	1.5729	1.4632	1.6461	1.4632	1.1946	1.1827
4	1.7556	1.5154	1.4266	1.5565	1.4118	1.1584	1.1643
5	1.6632	1.4415	1.3575	1.5203	1.3352	1.1523	1.1088
6	1.4937	1.1389	1.1827	1.267	1.1643	1.0679	1.1016
7	1.3443		1.0498	1.1888	1.1041	1.0059	.9795
8	1.2136	1.3256	.9593	1.0317	1.0425	.9231	.9335
9	1.0164	1.1883	.961	1.0349	1.0164	.9511	1.1088
10	1.0903	1.0791	.9511	1.0534	.9694	.9425	
11	1.134	1.1128	1.0791	1.2254	.9877	.9145	
12	1.1584	1.134	1.1523	1.262	1.0317	.9511	
13	1.3169	1.2071	1.1946	1.1946	1.0974	.9955	1.3213
14	1.4083	1.2826	1.3213	1.1041	1.0498	.9774	1.1403
15	1.448	1.3392	1.3394	1.1643	.9231	.9694	1.1584
16	1.3032		1.307	1.0679	.9145	.9694	1.1584
17	1.0082	.9709	1.1949	1.0642	.8962	.9412	1.1273
18	.9896	1.1576	1.2136	1.0269	.9149	1.0208	1.1273
19	1.1949	1.4415	1.3491	1.2323	1.1088	1.086	1.1458
20	1.46	1.5524	1.5154	1.3306	1.1643	1.267	1.1458
21	1.4784	1.5154	1.5524	1.3676	1.2012	1.267	1.0974
22		1.4784	1.6263	1.423	1.2197	1.3352	1.1523
23	1.829	1.6095	1.829	1.5729	1.3352	1.39	1.3352
24	1.9959	1.7193	1.5565	1.7556	1.5223	1.267	1.2254
Max	1.9959	1.7193	1.829	1.7556	1.5223	1.39	1.3352
Min	.9896	.9709	.9511	1.0269	.8962	.9145	.9335
Avg	1.4257	1.3654	1.3168	1.3130	1.1600	1.0916	1.1504



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

WARUD (I)[309]

BU 3093

Substation No/ Name :- 034066 / 33 KV WARUD

Feeder No / Name : 202 / 11 KV WARUD TOWN 2

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6263	1.5912	1.3032	1.5203	1.379	1.1584	1.262
2	1.6263	1.5729	1.2715	1.5043	1.3756	1.1584	1.2382
3	1.6078	1.5546	1.2894	1.4685	1.3756	1.1462	1.2197
4	1.5708	1.4998	1.3032	1.3432	1.3394	1.1104	1.2012
5	1.4784	1.46	1.2308	1.3073	1.3253	1.1104	1.1827
6	1.363	1.1016	1.086	1.1517	1.3032	1.0317	1.1458
7	1.251		.9694	1.0099	1.2308	.9877	1.0534
8	1.0269	1.0269	.905	.9955	1.1765	.905	1.0164
9	.9979	1.0374	.9425	1.0164	1.1273	.9425	.9979
10	1.1643	1.1317	1.0791	1.1273	.9877	1.0534	.9795
11	1.2197	1.1506	1.0608	1.086	.9694	1.0317	.823
12	1.3169	1.1883	1.1403	1.2254	.9412	1.0136	.8688
13	1.39	1.2071	1.1706	1.0498	.9145	1.0136	1.0059
14	1.4449	1.3014	1.2127	1.0498	.9511	1.0425	.9328
15	1.4118	1.3203	1.2071	1.0608	.8507	.8779	.9412
16	1.3169	.4527	1.3256	1.0791	.7499	.9593	.9877
17	1.1016	1.1389	1.1949	1.0269	.7842	.9955	.8871
18	1.1949	1.2136	1.2323	1.1576	.7655	1.0029	.7282
19	1.2136	1.3121	1.2197	1.2136	.9425	1.0745	.7947
20	1.3491	1.5524	1.386	1.2752	1.0349	1.1765	.8501
21	1.4415	1.3121	1.3306	1.3306	1.1643	1.2254	1.134
22		1.2936	1.4969	1.3676	1.1827	1.2803	1.2197
23	1.5364	1.3032	1.3611	1.3611	1.267	1.1888	1.1523
24	1.885	1.6095	1.3032	1.5927	1.3937	1.1765	1.262
Max	1.885	1.6095	1.4969	1.5927	1.3937	1.2803	1.262
Min	.9979	.4527	.905	.9955	.7499	.8779	.7282
Avg	1.3711	1.2753	1.2092	1.2217	1.1055	1.0693	1.0368

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

WARUD (I)[309]

BU 3093

Substation No/ Name :- 034066 / 33 KV WARUD

Feeder No / Name : 203 / 11 KV WARUD WATER WORKS Only one consumer of WW with HT-IV

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.056	.0377	.056	.0373	.056	.0189
2	.056	.0566	.0377	.0377	.0373	.0373	.0189
3	.0187	.0189	.0187	.0373	.0189	.0377	.0189
4	.0189	.0189	.0187	.0187	.0187	.0187	.0377
5	.0189	.0377	.0187	.0377	.0187	.0187	.0377
6	.0377	.0377	.0187	.0373	.0377	.0554	.0377
7	.0566	.0189	.0377	.0377	.0187	.0187	.0566
8	.0566	.0377	.0189	.0187	.0187	.0187	.0566
9	.0189	.0377	.0566	.0377	.0377	.0189	.0377
10	.0189	.0566	.0189	.0189	.0377	.0566	.0189
11	.0373	.0377	.0189	.0189	.0189	.0566	.0373
12	.0187	.0566	.0373	.0377	.0187	.0377	.0189
13	.056	.0566	.0566	.0373	.056	.0187	.0377
14	.0189	.0189	.0187	.0189	.056	.0187	.0189
15	.0377	.0566	.056	.0373	.0189	.0566	.056
16	.0189		.0566	.0189	.056	.0566	.0373
17	.0566	.0189	.0566	.0189	.0189	.056	.0189
18	.0189	.0189	.0189	.0377	.0566	.056	.0566
19	.0189	.0189	.0566	.0566	.0189	.0566	.0189
20	.0189	.0189	.0189	.0187	.0373	.0373	.0189
21	.0187	.0189	.0189	.0189	.0187	.0187	.0189
22		.0189	.0189	.0187	.0187	.0189	.0189
23	.0187	.0187	.0189	.0189	.0566	.0187	.0566
24	.056	.0187	.056	.056	.0373	.056	.0566
Max	.0566	.0566	.0566	.0566	.0566	.0566	.0566
Min	.0187	.0187	.0187	.0187	.0187	.0187	.0189
Avg	.0319	.0328	.0329	.0313	.0320	.0375	.0338

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

WARUD (I)[309]

BU 3093

Substation No/ Name :- 034066 / 33 KV WARUD

Feeder No / Name : 204 / 11 KV WARUD TOWN 3

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1273	1.2012	1.0608	1.1765	1.0498	.8869	.9425
2	1.1088	1.1706	1.0136	1.1403	1.0608	.8779	.924
3	1.0903	1.1643	1.0242	1.0974	1.0136	.8688	.8871
4	1.0534	1.1273	1.0059	1.0974	1.0136	.8507	.8501
5	1.0164	1.0903	.9511	1.0608	.9955	.8413	.8501
6	.8962		.8686	.9593	.9425	.7783	.8402
7	.8215		.7682	.8596	.8871	.7499	.7577
8	.7468		.7499	.7783	.823	.695	.7392
9	.6653	.7167	.7577	.8131	.8131	.7392	.7207
10		1.0185	.7947	.8501	.7207	.7947	.7762
11	1.2382	1.0562	.8779	.924	.8316	.8871	.7947
12	1.1765	1.1694	.9694	.9412	.8413	.8688	.8779
13	1.2254	1.2071	1.0425	1.0059	.8596	.9145	.8779
14	1.262	1.2637	1.0679	.8596	.9694	.9328	.9231
15	1.262	1.2071	1.1157	.9593	.8048	.9412	.9511
16	1.1706	.9054	1.0269	.8688	.7499	.8962	.9511
17	.9709	.9149	.9709	.8402	.7922	.8596	.961
18	.9522	.9896	.9896	.8775	.8029	.9328	.9522
19	1.0456	1.0903	1.1088	1.0642	.9149	.9511	.924
20	1.1643	1.2382	1.2197	1.1273	.961	1.0208	.9149
21	1.1827	1.2012	1.2382	1.1273	.961	1.0164	.9055
22		1.1643	1.2382	1.1088	.924	.9425	.8871
23	1.2803	1.0974	1.2254	1.134	.9145	.9145	.9055
24	1.3491	1.2437	1.0745	1.2127	1.1041	.9145	.9425
Max	1.3491	1.2637	1.2382	1.2127	1.1041	1.0208	.961
Min	.6653	.7167	.7499	.7783	.7207	.695	.7207
Avg	1.0821	1.1065	1.0067	.9952	.9063	.8781	.8773

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

WARUD (I)[309]

BU 3093

Substation No/ Name :- 034066 / 33 KV WARUD

Feeder No / Name : 205 / 11KV WATHODA GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5228	.7095	.5847	.7164	.4344	.5316	.5975
2	.5228	.7023	.5847	.6878	.4163	.5316	.5975
3	.5228	.7095	.5609	.695	.4163	.4961	.5729
4	.5228	.6908	.5434	.7316	.4344	.4908	.5788
5	.4854	.6908	.5316	.6556	.4344	.4908	.5601
6	.415	.4481	.4508	.5194	.3326	.3944	.5175
7	.2452	.2054	.2172	.3258	.2534	.2378	.2801
8	.2075	.2614	.2172	.2835	.197	.2149	.2241
9	.2957	.3206	.3881	.4435	.3881	.3142	.4435
10	.4572	.3395	.4066	.462	.3696	.3326	.3142
11	.4805	.3961	.3142	.4805	.3881	.3142	.2957
12	.3841	.439	.3511	.4938	.3658	.3658	.3109
13	.4207	.5281	.4938	.3142	.2715	.3511	.3658
14	.439	.547	.5121	.2743	.4525	.3292	.3696
15	.5914	.5121	.5121	.3109	.2353	.3658	.3142
16	.5487	.3584	.5658	.3109	.2218	.2033	.4525
17	.4527		.5093	.2829	.2452	.2353	.2614
18	.2829		.5093	.2641	.2641	.2149	.2452
19	.3018	.4294	.5228	.4904	.4668	.4144	.2614
20	.4904	.6161	.6348	.4108	.4854	.543	.2614
21	.6161	.6535	.6535	.4251	.5228	.5258	.3547
22	.6653	.5658	.7655	.4668	.5041	.4251	.4108
23	.7095	.5847	.7164	.4525	.5316	.5975	.4108
24	.5415	.7655	.6219	.7316	.4344	.5792	.5975
Max	.7095	.7655	.7655	.7316	.5316	.5975	.5975
Min	.2075	.2054	.2172	.2641	.197	.2033	.2241
Avg	.4634	.5215	.5070	.4679	.3777	.3958	.3999

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

WARUD (I)[309]

BU 3093

Substation No/ Name :- 034089 / 33/11 KV Dhaga (Amner)

Feeder No / Name : 201 / EKDHARA AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1383	.1698			
2		.1257	.1509			
3		.1276	.1698			
4		.1276	.1698			
5		.1404	.1886			
6		.184	.2075			
7			.3584			
8			.3395			
9		.0556	.3584			
10	.3755			.2892	.1715	
11	.3814			.4115	.2075	.0267
12	.3715			.4115		
13	.3864			.3429	.1132	.0333
14			.2503	.0686		.0781
15			.2667	.0686		.0171
16			.2134			
17			.184			.0107
Max	.3864	.184	.3584	.4115	.2075	.0781
Min	.3715	.0556	.1509	.0686	.1132	.0107
Avg	.3787	.1285	.2329	.2654	.1641	.0332

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

WARUD (I)[309]

BU 3093

Substation No/ Name :- 034089 / 33/11 KV Dhaga (Amner)

Feeder No / Name : 202 / GHORAD AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1006				.0732
2	.1021				.0732
3	.088				.543
4	.088				.061
5	.0991				.0732
6	.1257				.0686
7	.1659				.1149
8	.1659				.1943
9	.1734				.2103
10		.1296	.1372	.3206	
11		.1715	.2641	.2	
12		.1715	.2641	.192	
13		.1372	.2263	.1646	
14	.1334	.1372	.2263		
15	.1372	.1372	.2075		
16	.12	.1372	.2075		
17	.1646	.1543	.2641		
24	.1113				.0591
Max	.1734	.1715	.2641	.3206	.543
Min	.088	.1296	.1372	.1646	.0591
Avg	.1268	.1470	.2246	.2193	.1471

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

WARUD (I)[309]

BU 3093

Substation No/ Name :- 034089 / 33/11 KV Dhaga (Amner)

Feeder No / Name : 203 / AMNER GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5853	.5487	.5144	.5658	.567	.463	.4527
2	.5792	.543	.5144	.5658	.5487	.463	.4715
3	.543	.5249	.5144	.5847	.5487	.4458	.4572
4	.543	.5249	.4801	.5658	.543	.4458	.4715
5	.543	.5121	.4801	.5658	.5249	.4287	.4527
6	.439	.4572	.4287	.5281	.4344	.3944	.4715
7	.3544	.2743	.3258	.3772	.3982	.3258	.3772
8	.3544	.3258	.3601	.3292	.3761	.3086	.3841
9	.3506	.362	.3429	.3961	.3761	.3429	.3772
10	.3755	.3801	.3772	.4338	.3258	.2915	.3206
11	.3403	.3772	.3961	.3982	.3429	.2743	.2865
12	.394	.3772	.415	.3982	.3772		
13	.3403	.4287	.4527	.4706	.3601	.3018	.2804
14	.4477	.4287	.4338	.4344	.2572	.2452	.2629
15	.4477	.3944	.4715	.362	.2058	.2263	.2629
16	.394	.3086	.4527	.2865	.2058	.2263	.2328
17	.3045	.2572	.3772	.2686	.2572	.2641	.2454
18	.2896	.2401	.3018	.3224	.2915	.2641	.2534
19	.3439	.3086	.3292	.3841	.3772	.3395	.2507
20	.4525	.4973	.547	.4938	.4287	.4527	.3658
21	.543	.5316	.5847	.5487	.4287	.4715	.439
22	.5611	.5487	.5847	.567	.4287	.4527	.4755
23	.5611	.5487	.5847	.567	.4287	.4527	.462
24		.5316		.5847	.5611	.463	.4527
Max	.5853	.5487	.5847	.5847	.567	.4715	.4755
Min	.2896	.2401	.3018	.2686	.2058	.2263	.2328
Avg	.4386	.4263	.4465	.4583	.3997	.3628	.3698

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

WARUD (I)[309]

BU 3093

Substation No/ Name :- 037017 / 132KV WARUD

Feeder No / Name : 205 / 11 KV MILL AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	23-JUN-17
HR	Load (MW)
15	.8299
Max	.8299
Min	.8299
Avg	.8299



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

WARUD II S/DN[310]

BU 3107

Substation No/ Name :- 034019 / BENODA SUBSTATION

Feeder No / Name : 201 / 11 KV BARGAON Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191				
2	.0191	.0191	.0191				
3	.0191	.0191	.0191				
4	.0191	.0191	.0191				
5	.0191		.0191				
6	.0191		.0191				
7	.0381	.0381	.0191				
8	.0953	.0381	.0191				
9	.0953	.0572	.0191				
10				.0191	.0191		.0381
11				.0191	.0381	.0191	.0381
12				.0381	.0381	.0191	.0381
13					.0381	.0191	.0381
14					.0381	.0191	.0381
15				.0191	.0191	.0381	.0381
16				.0191	.0191	.0572	.0381
17				.0191	.0191	.0572	.0381
20							.3429
21							.4191
22							.4001
24	.0191	.0191	.0191				
Max	.0953	.0572	.0191	.0381	.0381	.0572	.4191
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0381
Avg	.0362	.0286	.0191	.0223	.0286	.0327	.1334

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

WARUD II S/DN[310]

BU 3107

Substation No/ Name :- 034019 / BENODA SUBSTATION

Feeder No / Name : 202 / 11 KV BENODA Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0381	.0191	.0191	.0762
2				.0381	.0191	.0191	.0762
3				.0572	.0191	.0191	.0762
4				.0953	.0191	.0191	.0762
5				.1143	.0191	.0191	.0762
6				.0953	.0191	.0191	.0762
7				.0953	.0191	.0191	.0762
8				.0953	.0191		.1334
9				.0762	.1905		.1524
10		.0191	.1524				
11	.1143	.0191	.2096				
12	.0953	.0191	.2477				
13	.0762	.0191	.2286				
14	.0953	.0191	.2286				
15	.0191	.0191	.1905				
16	.0191	.0191	.1715				
17	.0191		.1715				
18	.0191	.0381					
19	.0191	.0953					
20		.0191					
21		.0762					
24				.2286	.0191	.0191	.0762
Max	.1143	.0953	.2477	.2286	.1905	.0191	.1524
Min	.0191	.0191	.1524	.0381	.0191	.0191	.0762
Avg	.0530	.0329	.2001	.0934	.0362	.0191	.0895

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

WARUD II S/DN[310]

BU 3107

Substation No/ Name :- 034019 / BENODA SUBSTATION

Feeder No / Name : 203 / 11 KV JARUD-AG-

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.9526	.9526	.9526	1.0098
2				.9526	.9526	.9526	1.0098
3				.9526	.9526	.9526	1.0098
4				.9526	.9526	.9526	1.0288
5				.9526	.9526	.9526	1.0288
6				.9145	.9526	.9907	1.0098
7				.8573	.9335	.9526	1.0098
8				.8764	.8954	.9717	.9907
9				.8764	.9145	1.0098	.9907
10	1.0098	.8573	.9526				
11	1.105	.8192	.9526				
12	1.0098	.8192	.9717				
13	.9526	.8192	.9907				
14	.8764		.9717				
15	.8764	.9145	.9717				
16	.8573	.9526	.9717				
17	.8573		.9526				
24				.9526	.9526	.9717	1.0098
Max	1.105	.9526	.9907	.9526	.9526	1.0098	1.0288
Min	.8573	.8192	.9526	.8573	.8954	.9526	.9907
Avg	.9431	.8637	.9669	.9240	.9412	.9660	1.0098

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

WARUD II S/DN[310]

BU 3107

Substation No/ Name :- 034019 / BENODA SUBSTATION

Feeder No / Name : 204 / 11 KV ISSAMBRI Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1905	.1524				
2		.1905	.1524				
3		.1905	.1524	.1524			
4		.1905	.1524				
5		.2667	.1905				
6		.362	.2096				
7		.4191	.2096				
8		.3048	.1905				
9		.2286	.2096				
10				.2286	.3429	.1905	.1905
11				.3048	.4001	.2286	.1905
12				.362	.4001	.2667	.1905
13					.381	.1905	.1905
14					.3429	.1524	.2286
15				.2667	.2286	.2096	.2286
16				.2858	.2286	.1905	.2667
17				.1905	.1905	.1334	.2286
24	.2286	.1905	.1524				
Max	.2286	.4191	.2096	.362	.4001	.2667	.2667
Min	.2286	.1905	.1524	.1524	.1905	.1334	.1905
Avg	.2286	.2534	.1772	.2558	.3143	.1953	.2143

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

WARUD II S/DN[310]

BU 3107

Substation No/ Name :- 034019 / BENODA SUBSTATION

Feeder No / Name : 205 / 11KV JARUD-GAOTHAN-

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0288	1.0288	.9907	.9526	.7621	.8002
2		1.0098	.9526	.9907	.9145	.6859	.8002
3		1.0479	.9526	.9526	.9145	.6859	.8002
4		.9335	.8002	.8954	.8383	.6859	.7811
5		.8383	.724	.8383	.7621	.6859	.7811
6		.6859	.5906	.6668	.6859	.6478	.6668
7		.5906	.4572	.5335	.5335	.4191	.5144
8		.4763	.4191	.4763	.4763	.381	.4763
9		.4572	.4763	.4572	.4191	.4191	.4572
10		.5335	.5525	.4954	.4382	.4382	.5716
11		.6668	.6478	.5716	.4572	.4763	.4954
12	.5906	.743	.6668	.7049	.4572	.381	.4572
13	.6668	.8383	.6859	.6859	.5716	.5335	.4954
14	.743	.8764	.7049	.6097	.6668	.6668	.4954
15	.9335	.743	.743	.5335	.4763	.6097	.4954
16	.6097	.5906	.6097	.4763	.4572	.5144	.5525
17	.5525		.6097	.4001	.4572	.4572	.4954
18	.6097	.4763	.6287		.5335	.4572	.5335
19	.6859	.7049	.6478	.5906	.6097	.5716	
20	.7811	.7811	.7811	.7049	.7621	.6668	.3429
21	.8764	.8002	.8573		.6859	.724	.6097
22	.9907	.8192	.9526		.7621	.743	
23	1.0098	.9526	1.0288	.9907	.7621	.7811	.6859
24	1.105	1.0288	1.0669	1.0098	.9526	.7811	.8002
Max	1.105	1.0479	1.0669	1.0098	.9526	.7811	.8002
Min	.5525	.4572	.4191	.4001	.4191	.381	.3429
Avg	.7811	.7662	.7327	.6940	.6478	.5906	.5958

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

WARUD II S/DN[310]

BU 3107

Substation No/ Name :- 034019 / BENODA SUBSTATION

Feeder No / Name : 206 / 11KV BENODA GAOTHAN FEEDER

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5335	.4572	.5335	.4763	.4191	.4382
2	.5716	.5335	.4572	.5335	.4763	.381	.4382
3	.5716	.5144	.4382	.5144	.4763	.381	.4191
4	.4763	.4763	.4191	.4954	.4763	.381	.4191
5	.4572		.381	.4763	.4191	.381	.4001
6	.4382		.3429	.362	.381	.362	.3429
7	.3429	.3429	.2858	.2858	.2667	.2858	.2667
8	.2858	.2667	.2286	.2667	.2667	.2477	.2477
9	.2667	.2858	.2858	.2858	.2477	.2667	.2858
10	.2858	.2667	.2667	.3048	.2286	.2858	.2477
11	.3048	.2858	.2858	.3239	.2477	.3239	.2667
12	.3048	.3048	.2858	.3429	.2858	.2858	.2858
13	.362	.362	.3048	.3239	.2858	.2858	.2858
14	.4191	.4572	.3239	.3429	.3048	.3048	.3048
15	.4763	.4001	.362	.3429	.3048	.3048	.3048
16	.381	.2667	.3239	.3429	.2858	.3048	.3048
17	.3239	.2477	.3239	.2858	.2667	.3048	.3048
18	.3429	.2858	.3429	.3239	.2858	.3239	.381
19	.381	.362	.362	.362	.3239	.4001	
20	.4572	.4763	.4382	.4763	.4191	.4191	
21	.5144	.4572	.4954	.4763	.4191	.4572	
22		.4572	.5144	.4763	.4191	.4572	
23	.5525	.4572	.5335	.5144	.4191	.4382	
24	.5716	.5525	.4572	.5335	.5144	.4191	.4382
Max	.5716	.5525	.5335	.5335	.5144	.4572	.4382
Min	.2667	.2477	.2286	.2667	.2286	.2477	.2477
Avg	.4200	.3906	.3715	.3969	.3540	.3509	.3359

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

WARUD II S/DN[310]

BU 3107

Substation No/ Name :- 034019 / BENODA SUBSTATION

Feeder No / Name : 207 / Jarud Water Supply

LT WW Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191	.0191	.0191	.0191
2	.0191	.0191	.0191	.0191	.0191	.0191	.0191
3	.0191	.0191	.0191	.0191	.0191	.0191	.0191
4	.0191	.0191	.0191	.0191	.0191	.0191	.0191
5	.0191	.0191	.0191	.0191	.0191	.0191	.0191
6	.0191	.0191	.0191	.0191	.0191	.0191	.0191
7	.0191		.0191	.0191	.0191	.0191	.0191
8	.0191	.0191	.0191	.0191	.0191	.0191	.0191
9	.0191	.0191	.0191	.0191	.0191	.0191	.0191
10	.0191	.0191	.0191	.0191	.0191	.0191	
11	.0191	.0191	.0191	.0191	.0191	.0191	.0191
12	.0191	.0191	.0191	.0191	.0191	.0191	.0191
13	.0191	.0191	.0191	.0191	.0191	.0191	.0191
14	.0191	.0191	.0191	.0191	.0191	.0191	.0191
15	.0191	.0191	.0191	.0191	.0191	.0191	.0191
16	.0191	.0191	.0191	.0191	.0191	.0191	.0191
17	.0191		.0191	.0191	.0191	.0191	.0191
18	.0191	.0191	.0191	.0191	.0191	.0191	.0191
19	.0191	.0191	.0191	.0191	.0191	.0191	.0191
20	.0191	.0191	.0191	.0191	.0191	.0191	.0191
21		.0191	.0191	.0191	.0191	.0191	.0191
22	.0191	.0191	.0191	.0191	.0191	.0191	.0191
23	.0191	.0191	.0191	.0191	.0191	.0191	.0191
24	.0191		.0191	.0191	.0191	.0191	.0191
Max	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0191	.0191	.0191	.0191	.0191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUN-17 and 28-JUN-17

AMARAVATI ZONE[061]

AMARAVATI CIRCLE[620]

MURSHI DIVSION[624]

WARUD II S/DN[310]

BU 3107

Substation No/ Name :- 034019 / BENODA SUBSTATION

Feeder No / Name : 208 / PALSONA AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUN-17	23-JUN-17	24-JUN-17	25-JUN-17	26-JUN-17	27-JUN-17	28-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.381	.381				
2	.3048	.381	.381				
3	.3048	.381	.381				
4	.3048	.381	.381				
5	.3048	.381	.381				
6	.3048	.381	.381				
7	.3429	.381	.381				
8	.381	.381	.381				
9	.381	.4001	.4001				
10				.381	.362	.362	
11				.381	.381	.381	.3429
12				.4001	.381	.4001	.3048
13					.362	.4001	.3048
14					.3429	.4191	.3048
15				.381	.381	.381	.3429
16				.381	.381	.381	.4191
17				.362	.381	.4191	.381
24	.3048	.381	.381				
Max	.381	.4001	.4001	.4001	.381	.4191	.4191
Min	.3048	.381	.381	.362	.3429	.362	.3048
Avg	.3239	.3829	.3829	.3810	.3715	.3929	.3429