

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134003 / AMBAD

Feeder No / Name : 201 / TOWN I

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.7621	.7621	.2858	.6097	.7621	.3429
2	.381	.7621	.7621	.2858	.6097	.7621	.4763
3	.4287	.6097	.7621	.381	.6097	.7621	.4763
4	.4763	.6097	.9145	.381	.6097	.9145	.4572
5	.5716	.6097	.9145	.3334	.7621	.9145	.381
6	.5716	.7621	.9145	.2858	.7621	.9145	.4572
7	.4763	.7621	.7621	.381	.7621	.9145	.381
8	.381	.7621	.7621	.381	.7621	.9145	.381
9	.4763	.7621	.2286	.7621	.7621	.4763	.4763
10	.7621	.7621	.381	.7621	.7621	.4763	.7621
11	.7621	.7621	.4763	.7621	.7621	.4763	.7621
12	.7621	.7621	.4763	.7621	.7621	.381	.7621
13	.7621	.7621	.381	.7621	.7621	.381	.7621
14	.7621	.7621	.4763	.6097	.7621	.381	.6097
15	.7621	.7621	.381	.6097	.7621	.381	.6097
16	.7621	.9145	.4763	.7621	.7621	.4763	.7621
17	.7621	.9145	.6859	.8383	.7621	.4763	.7621
18	.7621	.9145	.6668	.9145	.7621	.5716	.9145
19	.9145	.9145	.9335	.9145	.7621		.9145
20	.9145	.7621	.5716	.9145	.7621	.5716	.9145
21	.9145	.7621	.381	.9145	.7621	.5716	.7621
22	.9145	.7621		.9145	.7621	.4763	.7621
23	.7621	.8097		.9145	.7621	.381	.6097
24	.2858	.7621	.7621	.2858	.9145	.7621	.381
Max	.9145	.9145	.9335	.9145	.9145	.9145	.9145
Min	.2858	.6097	.2286	.2858	.6097	.381	.3429
Avg	.6545	.7704	.6287	.6299	.7431	.6130	.6200

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134003 / AMBAD

Feeder No / Name : 202 / TOWN2

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.9145	.9145	.4763	.7621	.9145	.5716
2	.381	.9145	.9145	.5716	.7621	.9145	.5716
3	.381	.9145	.9145	.5716	.7621	.9145	.8002
4	.4572	.9145	1.0669	.6668	.7621	.9145	.6668
5	.5716	.9145	1.0669	.6668	.9145	.9145	
6	.4763	.9145	1.0669	.6668	.9145	1.0669	.5716
7	.5716	1.0669	.9145	.6668	.9907	1.0669	.5716
8	.5716	1.0669	.9145	.6668	.9907	1.0669	.5716
9	.6668	1.0669	.381	1.0669	.9145	.381	.5716
10	.9145	1.0669	.5716	1.0669	.9145	.8002	
11	.9145	1.0669	.6668	.9145	.9145	.5716	.9145
12	.9145	.9145	.7621	.9145	.9145	.6192	.9145
13	.9145	.9145	.5716	.9145	.9145	.8383	.9145
14	.9145	.9145	.6192	.9145	.9145	.5716	.7621
15	.9145	.9145	.5716	.9145	.9145	.5716	.7621
16	.9907	.9145	.6859	.9145	.9145	.5716	.7621
17	1.0669	1.0669	.5716	.9145	.9145	.4763	.9145
18	1.0669	1.0669	.4763	.6668	.9145	.4954	.9145
19	1.0669	1.0669	.5335	1.0669	.9145		.9145
20	1.0669	.9145	.5716	1.1431	.9145	.6668	.9145
21	1.0669	.9145	.6859	1.1431	1.0669		.9145
22	1.0669	.9145		1.0669	1.0669		.9145
23	1.0669	.7621		.9907	.9145		.9145
24	.4572	1.0669	.9145	.4763	.9145	.9145	.4763
Max	1.0669	1.0669	1.0669	1.1431	1.0669	1.0669	.9145
Min	.381	.7621	.381	.4763	.7621	.381	.4763
Avg	.7859	.9653	.7435	.8351	.9082	.7626	.7638

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134003 / AMBAD

Feeder No / Name : 203 / BORI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	.9145	.9145		.2858	.6097	.381
2	1.467	1.0669	.9145		.2858	.6097	.2858
3	1.7337	1.2193	1.0669		.2858	.381	.2858
4	2.1338	1.2193	1.2193		.2858	.6097	.381
5	1.7337	1.2193	1.3717		.2858	.6097	.381
6	1.1431	1.3717	1.3717			.6097	.3429
7	1.5242	1.5242	1.3717			.6097	.1143
8		1.5242	1.3717				.2286
9	.9335	1.5242				.3048	
10	.0953	.6097	.1143		.9145	.6001	.7621
11	.1905	.6097	.2858		.9145	.8573	.7621
12	.1905	.6097	.1905			.7621	.7621
13	.1905	.6097	.1905			.4763	.7621
14	.1905	.6097	.1429		.9145	.381	.7621
15	.1905	.6097	.2858		.9145	.5716	.7621
16		.6097	.2286		.9145	.6097	.7621
17	.1981	.6097	.2858		.9145	.8002	.7621
18	.2858	.6097		.2858	.6097	.3048	
19	.2858	.6097		.2858	.6097	.2286	.3334
20	.2858	.6097		.2858	.6097	.2858	.2858
21	.2858	.6097	.1524	.2858	.6097	.381	.2858
22	.2858	.6097		.2858	.6097	.2858	.2858
23	.2858	.6097		.2858	.6097	.4572	.2858
24	.9335	.9145	.9145	.4572	.2858	.6097	.2858
Max	2.1338	1.5242	1.3717	.4572	.9145	.8573	.7621
Min	.0953	.6097	.1143	.2858	.2858	.2286	.1143
Avg	.7174	.8764	.6885	.3103	.6033	.5198	.4663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134003 / AMBAD

Feeder No / Name : 204 / GOLAPANGRI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.2858	.6097		.6097	.6097	.7621
2	.1143	.2858	.6097		.6097	.6097	.9145
3	.1524	.2858	.6097		.6097	.6097	.5335
4	.1524	.2858	.6097		.6097	.6097	.7621
5	.1524	.2858	.6097		.7621	.6097	.9145
6	.2286	.4763	.6097		.7621	.6097	.7621
7	.381	.4763	.6097		.7621	.6097	.5716
8	.4763	.381			.7621	.9145	.6001
9	.4763	.6097	.381		.7621	.8002	.4572
10	1.2193	.9145	1.2193		.6097		.1981
11	1.2193	1.2193	.8097		.6097		.1905
12	1.2193	1.3717	1.2955		.6097		
13	1.2193	1.3717	1.2193		.6097		
14	1.2193	1.3717	.8573		.6097		
15	1.2193	1.3717		.7621	.6097		
16	1.2193	1.2193	.381	.7621	.6097		
17	1.2193	1.2193	.5716	.7621	.6097		.1905
18	.2858	.6097	.3429	.4572	.6097		
19	.381	.6097		.2858	.6401		.2858
20	.381	.6097		.2858	.6097		.2858
21	.381	.6097	.1429	.2858	.6097	.1905	.2858
22	.381	.6097		.2858	.6097	.2858	.2858
23	.381	.6097		.2858	.9145	.2858	.2858
24	.1524	.2858	.6097		.6097	.6097	.8002
Max	1.2193	1.3717	1.2955	.7621	.9145	.9145	.9145
Min	.1143	.2858	.1429	.2858	.6097	.1905	.1905
Avg	.5977	.7240	.6721	.4636	.6554	.5657	.5048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134003 / AMBAD

Feeder No / Name : 205 / SHAHAPUR

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6668		.9145		.4572	.7621	.2382
2	1.467		1.0669		.4572	.7621	.2858
3	1.9814		1.0669		.4572	.7621	.2858
4	1.9814		1.2193		.4572	.7621	.2382
5	1.6671		1.3717		.5716	.7621	.2858
6	1.6004		1.3717		.5716	.7621	.2858
7	1.2003		1.3717		.5716	.7621	
8			1.3717		.5716	.7621	
9	1.2003		.1905		.7621	.381	
10	.0953		.1905		.9145	.6668	
11	.0953		.1429		.9145	.8002	.7621
12		1.2193	.2286			.6668	.7621
13		.3048	.2382			.7621	.7621
14		.3048	.1905				.7621
15		.3048	.1429			.4572	
16		.3048	.1905	.6859	.9145	.6859	.7621
17		.3048	.2382	.6859	.9145	.381	.7621
18	.4572		.2382	.5716	.7621	.2858	.5144
19	.6859			.5716	.7621	.1905	.5144
20	.6859			.5716	.7621	.2382	.5144
21	.6859			.4572		.1905	.5144
22				.4572	.7621	.3429	.5144
23		.7621		.4572	.7621	.2858	.4572
24	.7621		.9145		.4572	.7621	.2858
Max	1.9814	1.2193	1.3717	.6859	.9145	.8002	.7621
Min	.0953	.3048	.1429	.4572	.4572	.1905	.2382
Avg	1.0155	.5008	.6663	.5573	.6738	.5736	.5004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134003 / AMBAD

Feeder No / Name : 206 / WATER SUPPLY

HV Non-Express Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2286	.3048	.0953	.1524	.3048	.1905
2	.1429	.1524	.3048	.1429	.1543	.3048	.3429
3	.1143	.1524	.3048	.1715	.1524	.3048	.3429
4	.1429	.1524	.3048	.2	1.6156	.3048	.2858
5	.1429	.1524	.3048	.0953	.1524	.3048	.1905
6	.1905	.2286	.3048	.1143	.2286	.3048	.2858
7	.1905	.2286	.3048	.1334	.2286	.3048	.2858
8	.1429	.2286	.3048	.1143	.2286	.3048	.1429
9	.1429	.3048	.1905	.2286	.3048	.2382	.1429
10	.2286	.3048	.2382	.2286	.3048	.2382	.2286
11	.2286	.3048	.2286		.3048	.1429	.2286
12	.2286	.3048	.1429	.2286	.3048	.1524	.2286
13	.2286	.3048	.1905	.2286	.3048	.1429	.2286
14	.2286	.3048	.1905	.2286	.3048	.1429	.2286
15	.2286	.3048	.1429	.2286	.3048	.2286	.2286
16	.2286	.3048	.1429	.2286	.3048	.1429	.2286
17	.2286	.3048	.1429	.2286	.3048	.1905	.2286
18	.2286	.3048	.1905	.2329	.3048	.2382	.2286
19	.2286	.3048	.2286	.2286	.3048	.1429	.2286
20	.2286	.3048		.2286	.3048	.1143	.2286
21	.2286	.3048	.2286	.2286	.3048	.1715	.2286
22	.2286	.3048		.2286	.3048	.0857	.2286
23	.2286	.3048		.1524	.3048	.2286	.1524
24	.1905	.2286	.3048		.1524	.3048	.2286
Max	.2286	.3048	.3048	.2329	1.6156	.3048	.3429
Min	.1143	.1524	.1429	.0953	.1524	.0857	.1429
Avg	.1996	.2635	.2381	.1907	.3182	.2227	.2318

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134003 / AMBAD

Feeder No / Name : 207 / TOWN NO-3

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.4572	.4572	.2858	.4572	.4572	.3429
2	.4287	.4572	.4572	.2382	.4572	.4572	.2858
3	.4763	.4572	.4572	.3429	.4572	.503	.2382
4	.4001	.4572	.6097	.3429	.4572	.4572	.2382
5	.2667	.4572	.6097	.2667	.4572	.6097	.2286
6	.3429	.4572	.6097	.1905	.4572	.7316	.1905
7	.2858	.4572	.4572	.3429	.381	.4572	.2382
8	.2858	.4572	.4572	.2382	.381	.6097	.2382
9	.2382	.4572	.1905	.381	.4572	.1905	.2382
10	.5335	.4572	.3334	.381	.4572	.1905	.4572
11	.5335	.4572	.3429	.381	.4572	.3334	.5792
12	.5335	.4572	.3334	.381	.4572	.2858	.4572
13	.5335	.4572	.2858	.381	.4572	.2858	.4572
14	.5335	.4572	.3334	.381	.4572	.2382	.4572
15		.4572	.381	.381	.4572	.3334	.4572
16	.5335	.4572	.3334	.381	.4572	.2858	
17	.5335	.4572	.381	.381		.381	.4572
18	.5335	.5335	.4763	.4572	.4572	.2858	
19	.5335	.5335	.4763	.5335	.4572		.6001
20	.5335	.4572	.2858	.5335	.6097	.381	.5335
21	.5335	.4572	.2858	.5335	.6097	.2858	.5335
22	.5335	.4572		.5335	.6097	.3334	.5335
23	.4572	.4572		.4572	.6097	.4001	.4572
24	.2858	.4572	.4572	.2858	.4572	.4572	.2858
Max	.5335	.5335	.6097	.5335	.6097	.7316	.6001
Min	.2382	.4572	.1905	.1905	.381	.1905	.1905
Avg	.4477	.4636	.4096	.3755	.4771	.3892	.3866

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 201 / TAKA AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	.6097	.3429	.0381	.3429	
11	.6097	.4572	.1143	.3239	
12	.6097	.5144	.1905		
13	.5716	.4001	.2286		
14	.5716	.3429	.2667	.3429	
15	.5716	.3429	.2667	.4001	.2667
16	.5335	.3048	.3048		.2477
17	.5335	.2667	.2667		.2286
Max	.6097	.5144	.3048	.4001	.2667
Min	.5335	.2667	.0381	.3239	.2286
Avg	.5764	.3715	.2096	.3525	.2477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 202 / NALEWADI GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3048	.381	.2286	.2667
2	.3429	.3048	.381	.2286	.2667
3	.381	.3429	.4572	.2667	.3239
4	.4191	.381	.5335	.3429	.362
5	.5335	.4572	.6097	.381	.4763
6	.6478	.5335	.6859	.4191	.5525
7	.724	.5716	.6859	.4191	.6859
8	.4572	.4954	.5335	.381	.724
9	.381	.381	.4572	.3429	.4572
10	.3429	.3048	.4191	.2667	.362
11	.3048	.2858	.3429	.2858	.3429
12	.2667	.2286	.3048	.2667	.3239
13	.2667	.2286	.3048	.2477	.2477
14	.2477	.2286	.3048	.2667	.2096
15	.2477	.2096	.3048	.2858	.2286
16	.3429	.2286	.3429	.2667	.2286
17	.4572	.2858	.3429	.2667	.3048
18	.5335	.3429	.381	.3239	.4954
19	.5716		.4572	.362	.6478
20			.4191	.4001	.6859
21			.381	.4572	.5525
22			.3429	.3239	.4572
23			.2286	.2858	.362
24	.6859	.3048	.2286	.2286	.2667
Max	.724	.5716	.6859	.4572	.724
Min	.2477	.2096	.2286	.2286	.2096
Avg	.4249	.3379	.4096	.3143	.4096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 203 / GONDI GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	05-JUN-17	06-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.3429	.5335	.3429
2	.4572	.3429	.5335	.3429
3	.5335	.381	.5335	.3429
4	.6097	.381	.5716	.4572
5	.724	.4191	.6097	.5716
6	.7621	.4572	.6859	.6478
7	.7621	.4572	.6859	
8	.6859	.4572	.6097	
9	.6478	.4191	.5335	
10	.5716	.381	.4191	
11	.5335	.3429	.381	
12	.4954	.3239	.381	
13	.4954	.2858	.3429	
14	.4191	.2477	.3429	
15	.4191	.2477	.3429	
16	.4954	.2477	.3429	
17	.5716	.362	.381	
18	.6478	.4954	.381	
19	.6859		.4572	
20	.5716	.4954	.4572	
21	.5335		.4191	
22	.4763		.381	
23			.381	
24	.3429		.381	
Max	.7621	.4954	.6859	.6478
Min	.3429	.2477	.3429	.3429
Avg	.5592	.3730	.462	.4509

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 204 / SHAHAGAD AG AG Feeder with SDT
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.1143	.0381	.0191	.0572
2	.3048	.1143	.0381	.0191	.0572
3	.3429	.1524	.0381	.0381	.0572
4	.381	.1524	.0381		.0572
5	.381	.1524	.0762	.0572	.0762
6	.4191	.2286	.0953	.0572	.0762
7	.4191	.381	.1143	.0572	.0953
8	.4191	.3429	.1143	.0762	.1143
9	.4191	.2858	.1143	.0762	.1143
10	1.0479	1.0669		.2858	.4763
11	1.0479	1.086		.5525	.5906
12	1.0479	1.0288	.381	.5335	.6097
13	1.0288	1.0288	.5335	.5525	.6097
14	1.0288	.9717	.5335	.5144	.5716
15	1.0288	.9526	.4954	.5144	.5716
16	.9526	.9145	.3048	.5335	.5335
17	.8383	.8764	.2667	.5716	.5144
18	.0191		.0191	.0191	
19	.0191			.0381	
20	.0191			.0381	
21	.0191			.0191	
22	.0191			.0191	
23	.0191		.0191	.0191	
24	.5525			.0191	.0572
Max	1.0479	1.086	.5335	.5716	.6097
Min	.0191	.1143	.0191	.0191	.0572
Avg	.5033	.5794	.1894	.2013	.2911

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 205 / SHAHAPUR AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	05-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
10	1.8099		
11	1.8671		
12	1.9052		.4191
13	1.9433		.5716
14	1.9814	1.5432	.7621
15	1.9433	1.6575	.8383
16	1.8099	1.7147	.8383
17	1.7528	1.7337	.8383
Max	1.9814	1.7337	.8383
Min	1.7528	1.5432	.4191
Avg	1.8766	1.6623	.7113

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 206 / SHAHAPUR GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.4572	.5716		.4382
2	.4954	.4572	.5716		.4382
3	.5335	.5335	.5716		.4572
4	.6097	.6478	.6097		.5525
5	.7621	.7621	.6478		.8002
6	1.0288	.9526	.7621		.9717
7	1.086	.9907	.7621		1.105
8	.8764	.8764	.6859		1.0479
9	.7621	.7621	.6478		.7811
10				.6478	.5716
11			.5716	.5525	.4572
12					.4382
13	.5335				.4001
14	.5335	.4763		.4382	.4001
15	.5144	.4954	.4572	.4572	.4572
16	.6478	.5525	.4954	.4954	.4763
17	.7621	.6097	.6097	.5906	.5335
18	.8383	.8192	.6859	.743	.6478
19	.9145		.724	.8764	.9335
20			.6859	.9145	.9717
21		.9335	.6478	.7049	.8764
22		.8573	.5716	.5906	.743
23		.6478		.5144	.5716
24		.4572			.4572
Max	1.086	.9907	.7621	.9145	1.105
Min	.4954	.4572	.4572	.4382	.4001
Avg	.7121	.6827	.6266	.6271	.6470

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 207 / GONDI AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	05-JUN-17	06-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.7621	.0381	
2	.8383	.0381	
3	.8573	.0381	
4		.0762	.5335
5		.0762	.6859
6		.0762	.8192
7		.0762	
8	.5716	.0762	
9	.724	.3429	
Max	.8573	.3429	.8192
Min	.5716	.0381	.5335
Avg	.7507	.0931	.6795

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 208 / DONGAON AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.381		
2	.381		.1715
3	.4572		.1715
4	.4954		.1905
5	.5335		.2286
6	.6097	.2858	.2477
7	.6478	.2858	
8	.6097	.5335	.2667
9	.5716	.5335	.2858
Max	.6478	.5335	.2858
Min	.381	.2858	.1715
Avg	.5208	.4097	.2232

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 210 / p.sirasgaon (Ag)

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2384	.381		.724
2	1.3336	.381		.743
3	1.4098	.6097	.6097	.9335
4	1.448	.6668	.6859	.9717
5	1.5242	.6478	.8383	1.0288
6	1.6004	.8383	.8764	1.105
7	1.6194	1.3336	.8764	1.2193
8	1.5242	1.5242	.9145	1.3146
9	1.4098	1.5242	.9145	1.0288
24				.6478
Max	1.6194	1.5242	.9145	1.3146
Min	1.2384	.381	.6097	.6478
Avg	1.4564	.8785	.8165	.9717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 212 / Baraswda (G)

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2286	.1905	.1715	.1143
2	.1905	.2286	.1905	.1715	.1143
3	.2286	.2286	.2286	.1715	.1334
4	.2286	.2667	.2286	.1905	.1334
5	.2667	.2667	.2667	.2286	.1905
6	.3048	.3048	.3048	.2667	.2096
7	.3048	.3048	.3048	.2667	.2667
8	.2286	.3048	.2667	.2667	.3048
9	.2286	.2286	.2286	.2286	.2667
10	.9907	.7621	.1905	.1905	.1524
11	1.1431	1.0288	.1905	.1524	.1334
12	1.2193	1.2765	.1715	.0953	.1334
13	1.1812	1.2193	.1524	.0953	.2477
14	1.1431	1.2003	.1524	.0953	.2477
15	1.105	1.1812	.1524	.3429	.2667
16	.9907	1.1622	.1524	.3239	.2667
17	.9145	1.105	.1524	.2858	.2858
18	.2286	.2286	.1715	.3048	
19	.3048		.2286	.3048	
20	.2667		.2286	.2667	
21	.2667		.1905	.1905	
22	.2286		.1905	.1715	
23	.2286		.1715	.1334	
24	.2286		.1715	.1715	.1143
Max	1.2193	1.2765	.3048	.3429	.3048
Min	.1905	.2286	.1524	.0953	.1143
Avg	.5255	.6403	.2032	.2120	.1990

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134026 / JAMKHED

Feeder No / Name : 201 / JAMKHED

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.8573	.6859		.7716	.5144	.8573
2	.8573	.8573	.6859		.7716	.5144	.8573
3	.8573	.8573	.6859		.7716	.5144	.8573
4	1.1145	1.0288	.6859		.7716	.5144	1.0288
5	1.286	1.1145	.7716		.8573	.6001	1.2003
6	1.4232	1.286	1.0288		1.0288	.6859	1.3717
7					1.286		
10	1.286				1.0288		1.0974
11	1.3546	1.0288	.9774		1.286	.8573	
12	1.3375	1.2003	.9602		1.2003		1.0288
13	1.2003	1.2003	1.0631	1.2003	1.2003	.7716	1.0974
14	1.166	1.2003	1.1831	1.2003	1.1145	.8573	.9945
15	1.166	1.2003	1.166	1.2003	1.1145	.9431	.8573
16	1.2517	1.2003	1.0288	1.2003	1.1145	1.1145	
17	1.1831	1.2003	1.046	1.2003	1.0288	1.2689	1.0288
18	1.046	1.2003		1.1145			.9602
19				1.0288	.6859	1.2174	1.1145
20	1.2003			1.0288	.8573	1.3889	1.1831
21	1.2174			.8573			
22	.9774	.6859		.8573	.5144		.9088
23	.9602	.6859		.8573	.5144	.8573	.823
24	.823	.8573	.6859		.8573	.5144	.8059
Max	1.4232	1.286	1.1831	1.2003	1.286	1.3889	1.3717
Min	.823	.6859	.6859	.8573	.5144	.5144	.8059
Avg	1.1283	1.0389	.9039	1.0678	.9388	.8209	1.0040

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134026 / JAMKHED

Feeder No / Name : 202 / ROHILAGAD

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.7716	.8573		1.0288		.5144
2	.7716	.7716	.8573		1.0288		.5144
3	.7716	.8573	.8573		1.0288		.5144
4	.8573	.9431	.9431		1.0288		.6859
5	.9431	1.0288	1.0288		1.0288		.7716
6	1.0974	1.1145	1.3717		1.0288		.9431
7		1.5089	1.5432		1.3717	.6859	1.2003
8		1.286			1.3717	.6859	
9		1.0974			1.3717	.8573	
10	1.3889	1.2003				.9945	
11	1.5775	1.286	.9431				
12	1.5432	1.286	1.1145				.8402
13	1.4575	1.286	1.0974	.7716	.6859	.7202	
14	1.3889	1.286	.9945	.8573	.6859	.7716	.8059
15	1.406	1.286	.9774	.8573	.6859	.7716	.7716
16	1.4575	1.286	.9259	.9431	.6859	.7716	.9945
17	1.2346	1.286	1.1145	.9431	.6859	.823	
18	1.0631	1.0288		.9431	.6859		1.3375
19	1.3717			1.0288	.6859		1.1831
20	1.3203			1.4575	.6859	1.3889	1.2003
21	1.1488	1.1145		1.3717			1.0288
22	.8745	1.0288		1.3717	.6859		.8573
23	.823	1.0288		1.2003		.8573	.7716
24	.7888	.7716	.8573		1.0288		.5144
Max	1.5775	1.5089	1.5432	1.4575	1.3717	1.3889	1.3375
Min	.7716	.7716	.8573	.7716	.6859	.6859	.5144
Avg	1.1456	1.1161	1.0322	1.0678	.9205	.8480	.8583

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134026 / JAMKHED

Feeder No / Name : 203 / NANDI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.6859	.6859		.3429	.3429	.2743
2	.8573	.6859	.6859		.3429	.3429	.2743
3	.8573	.8573	.6859		.3429	.3429	.3429
4	1.0288	1.0288	.7716		.3429	.4287	.4287
5	1.1145	1.1145	.8573		.3429	.5144	.5144
6	1.3546	1.2346	1.0288		.5144	.6859	.6859
7	1.5261	1.3375	1.0288		.3429	.6859	.8402
8	1.6118	1.3546	1.2003			.5144	.7373
9	1.3203	1.2003	1.3717				.6859
10	.3601	.3429	.3429			.5658	
11	.3258	.3429	.3086			.583	.7888
12	.3258	.3429	.2572			.7545	.8402
13	.3258	.3429		.6001	.8573		.8916
14	.2743	.3429	.3429	.6859	.8573	.7545	
15	.2743	.3429	.3429	.6859	.8573	.7373	.7716
16	.3086	.3429	.3429	.6859	.8573		.8402
17	.3601	.3429	.3601	.6859		.8916	.7716
18	.4458	.3429		.6859	.8573	.4801	.5658
19	.4458			.6859	.8573	.6001	.6344
20	.4973			.5144	.6859	.5487	.4973
21	.4801	.6001		.4287	.3429		.3944
22	.463	.6001		.4287	.3429		.3429
23	.4287	.5144		.3429	.3429		.3258
24	.7373	.6173	.6859		.3429	.3429	.2743
Max	1.6118	1.3546	1.3717	.6859	.8573	.8916	.8916
Min	.2743	.3429	.2572	.3429	.3429	.3429	.2743
Avg	.6873	.6781	.6647	.5846	.5430	.5620	.5783

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134039 / CHINCHKHED

Feeder No / Name : 201 / CHINCHKHED AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
13	.6097
24	.4572
Max	.6097
Min	.4572
Avg	.5335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134039 / CHINCHKHED

Feeder No / Name : 202 / SIRNER GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0381	.1715		.0572	.0286	.1715
2	.0572	.0286	.1715		.0572	.0286	.2572
3	.0572	.0191	.1715		.0572	.0286	.3429
4	.0572	.0191	.1715		.0572	.0381	.2572
5	.0572	.0286	.2572		.0857	.0476	.3429
6	.1143	.0476	.2572		.1143	.0476	.3429
7	.1143	.0381	.3429		.1143	.0476	.4287
8	.0857	.0762	.3429		.0857	.0381	.2572
9		.0762	.2572		.0572	.0286	.1715
10		.1715	.1715		.0572	.0286	.0857
11	.0572	.1715	.1715		.0572	.1715	.1715
12	.0572	.1715	.1715		.0572	.1715	.1715
13	.0572	.1715	.1715	.0572	.0572	.1715	.1715
14	.0572	.1715	.1715	.0572	.0572	.0857	.1715
15	.0572	.1715	.1715	.0572	.0572	.0857	.1715
16	.0572	.1715	.1715		.0572	.1715	.1715
17	.0572	.1715	.1715	.0572	.0572	.1715	.2572
18	.1143	.1715		.0572	.0286	.1715	.2572
19	.1524			.1143	.0381	.3429	.3429
20	.0286			.0857	.0191	.3429	.2572
21	.0762	.2572		.0572	.0191	.3429	.2572
22	.0191	.1715		.1905	.0191	.1715	.1715
23	.0191	.1715		.0572	.0191	.3429	.1715
24				.0572		.0381	.2572
Max	.1524	.2572	.3429	.1905	.1143	.3429	.4287
Min	.0191	.0191	.1715	.0572	.0191	.0286	.0857
Avg	.0672	.1198	.2068	.0771	.0559	.1310	.2358

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134039 / CHINCHKHED

Feeder No / Name : 203 / SHIRNER AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	.1143	.6097				.2286
2	1.1431	.5716	.6097				.381
3	1.1431	.4572	.6097				.1524
4	.3429	.4572	.7621				
5	1.3336	.2286	.7621				
6	1.3336	.4572	.7621				
7	1.8099	.1334	.9145				
8	1.8099	.1524	1.2193				
9	1.7147	1.2193	1.0669				
10							.4572
11					1.1431		.4572
12					1.1431		.5335
13					1.3336	.4572	.5335
14					1.3336	.4572	.6097
15					1.3336	.4572	.6001
16					1.5242		.5335
17					1.5242	.381	.6097
19				.381			
20	.0762			.2858	.2286	.1524	.2286
21	.0286	.2572		.2858		.1524	.1524
22	.0286	.2286				.1524	.2286
23	.2572	.2286				.1524	.2286
24		1.0288	.6097				.1524
Max	1.8099	1.2193	1.2193	.381	1.5242	.4572	.6097
Min	.0286	.1143	.6097	.2858	.2286	.1524	.1524
Avg	.9357	.4257	.7926	.3175	1.1955	.2953	.3804

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134039 / CHINCHKHED

Feeder No / Name : 204 / CHINCHKHED GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.6001	.1715		.5144	.5144	.6859
2	.5144	.6859	.2572		.5144	.5144	.7716
3	.5144	.6859	.2572		.5144	.5144	.8573
4	.5144	.8573	.3429		.5144	.7716	1.0288
5	.6859	.8573	.3429		.8573	.8573	1.2003
6	1.0288	1.2003	.5144		1.3717	1.1145	1.2003
7	1.0288	1.0288	.3429		1.2003		1.0288
8	.8573	1.0288			.8573	.6859	.8573
9	.6859	.8573			.6859	.6001	.8573
10		.7716			.5144	.6859	.5144
11	.5144	.5144			.5144	.5144	.5144
12	.5144	.5144			.5144	.4287	.5144
13	.5144	.3429		.5144	.5144	.3429	.5144
14	.5144	.3429	.5144	.5144	.5144	.3429	.5144
15	.5144	.3429	.5144	.5144	.5144	.3429	.5144
16	.5144	.6001		.5144	.5144		.5144
17	.5144	.6859		.5144	.5144	.5144	.5144
18	.5144	.8573		.6859		.6859	.6859
19	.8573			.8573	.8573	.8573	.8573
20	1.0288			.8573	.9431	.6859	.8573
21	.6859			.6859	.5144	.6859	.6859
22	.6001	.1715		.5144	.5144	.6859	.5144
23	.5144	.1715		.5144	.5144	.6859	.5144
24		.5144		.5144		.4287	.6859
Max	1.0288	1.2003	.5144	.8573	1.3717	1.1145	1.2003
Min	.5144	.1715	.1715	.5144	.5144	.3429	.5144
Avg	.643	.6491	.3620	.6001	.6586	.6118	.7252

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134048 / TADHADGAON

Feeder No / Name : 201 / TADHADGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.5144	.5144	.3429	.3429	.4287	.5144
2	.6001	.5144	.5144	.3429	.3429	.3429	.5144
3	.5144	.5144	.5144	.3429	.3429	.3429	.6001
4	.5144	.5144	.6001	.4287	.3429	.4287	.6859
5	.5144	.3429	.6001	.5144	.4287	.5144	
6	.5144	.1886	.6859	.6001	.463	.5487	.6859
7	.2058	.1715	.2058	.4973	.4973	.6859	.6859
8	.1886	.1715	.2058	.5144	.5144	.6859	.6859
9	.1905	.1715	.2058	.5144	.5144	.6859	.6001
10	.6859	.5144	.703	.1029	.12	.1372	.1715
11	.6859	.5144	.7716	.0686	.12	.0857	.1372
12	.6859	.6859	.7716	.0686	.12	.0857	.1543
13	.6859	.6859	.7716	.0686		.0857	.1029
14	.6859	.6859	.703	.0857		.0857	.1029
15	.6859	.6859	.703	.0857			.1029
16	.6859	.703	.6859		.1524		.1029
17	.6001	.6516	.12	.1372	.1029	.0857	.12
18	.1372	.1372		.2058	.1715	.12	.1543
19	.3772	.3429	.3429	.4973	.3429	.1715	.5144
20	.7716	.6859	.3429	.4287	.3429	.3429	.6344
21	.6859	.6859	.3429	.4287	.4287	.3429	.6001
22	.5144	.6859		.4287	.4287	.3429	.5144
23	.5144	.6001	.3429	.3944	.3429	.3429	.5144
24	1.4137	.6001	.5144	.3429	.3429	.4287	.3429
Max	1.4137	.703	.7716	.6001	.5144	.6859	.6859
Min	.1372	.1372	.12	.0686	.1029	.0857	.1029
Avg	.5691	.4987	.5074	.3236	.3241	.3328	.4018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134048 / TADHADGAON

Feeder No / Name : 202 / PANGERKHEDA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573		.4116		.5144		.6859
2	1.0288		.4116		.5144		.6859
3	1.0288		.4116		.5144		.6859
4	1.3717		.4116		.5144		.6859
5	1.3717		.4116		.6001		
6	1.5432		.4116		.6344		
7	1.9204	.0686			.6687		
8	1.8861	.0686					
9	1.7147	.0686					
10	.5316				1.8518		
11	.3429				2.0576		
12	.3429		1.0288		2.0576		.7716
13			1.0288			.8573	1.0288
14		.0686	1.2003	.9145	2.5378	.9431	1.0288
15		.0857	1.2003	.9145	2.7434		1.0288
16		.0686	.9907	.8573		.6859	1.0288
17		.1029	.5487	.8573		1.0288	.9145
18		.1029		.6001	.6858	.3429	.5335
19				.6001	1.0632		.6859
20				.6001	1.2002	.5144	.7373
21					1.2002		.6859
22		.1029			.6001	.5144	.6859
23		.1029		.5487	1.2002	.5144	.6097
24	1.6118		.4116		.5144		.6001
Max	1.9204	.1029	1.2003	.9145	2.7434	1.0288	1.0288
Min	.3429	.0686	.4116	.5487	.5144	.3429	.5335
Avg	1.1963	.0840	.6830	.7366	1.1407	.6752	.7696

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134048 / TADHADGAON

Feeder No / Name : 203 / RUI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.9526			.5144	1.0288	.5144
2	.6859	.7621			.5144	1.0288	.5144
3	.6859	.6859			.5144	1.0288	.5144
4	.6859	.7621			.6001	1.1145	.5144
5	.8573	.6001			.6859	1.2003	
6	.5144	.5144			.7716	1.2003	
7	.4801	.463			1.286	1.4575	
8	.4801	.2229			.8573	1.5604	
9	.4458	.2229			.2401		
10	1.5432				.2401		
11	2.0576	1.3717		.6859	.1715		
12	1.7147	1.0288		.7621	.1715	.1715	
13	1.7147	1.0288		1.0059			
14	1.7147	1.0288		.2286	.2058		
15	1.7147	.8573		.2058	.2058		
16	1.8004	.9431		.1886	.2058		
17	1.6289	1.0288	.6859	.2572	.2058		
18	.3429	.2743		.4287			
19	.9431	.4287	.5144	.6001	.9602	.7621	
20	1.2517		.5144		.9431		.9259
21	1.3336		.5144		1.0117		.8573
22	1.1431				.9259	.3429	.8573
23	.8573				.8402	.3429	.6859
24	.7888	.8573			.5144	.7716	.3429
Max	2.0576	1.3717	.6859	1.0059	1.286	1.5604	.9259
Min	.3429	.2229	.5144	.1886	.1715	.1715	.3429
Avg	1.0863	.7386	.5573	.4848	.5721	.9239	.6363

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134049 / SHAHAGAD

Feeder No / Name : 201 / WATER SUPPLY

LT WW Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0175				.0351	.0351	.0171
2	.0175				.0351	.0351	.0171
3	.0175				.0351	.0351	.0171
4	.0175				.0354	.0351	.0171
5	.0351				.0354	.0351	.0343
6	.0351			.0171	.0354	.0351	.0343
7	.0351			.0171	.0354	.0351	.0343
8	.0351			.0171	.0354	.0351	
9				.0343	.0351	.0351	.0343
10	.0526			.0171	.0351	.0351	.0686
11	.0526				.0354	.0701	.0686
12	.0701	.0171	.0514	.0701	.0351	.0701	.0343
13	.0701	.0171		.0701	.0351	.0747	.056
14	.0701	.0187		.0701	.0351	.0747	.0747
15	.0701	.0171		.0701	.0701		.0747
16	.0709	.0514		.0701	.0701	.0747	.0686
17	.0526	.0514		.0701	.0701	.0686	.0686
18	.0532	.0343		.0709	.0701		.0686
19	.0351			.0709	.0701	.0343	.0686
20	.0351			.0709		.0343	.0171
21				.0709	.0354	.0171	.0171
22				.0177	.0354	.0171	.0171
23	.0175			.0175	.0351	.0171	.0171
24	.0701				.0177	.0354	.0171
Max	.0709	.0514	.0514	.0709	.0701	.0747	.0747
Min	.0175	.0171	.0514	.0171	.0177	.0171	.0171
Avg	.0443	.0296	.0514	.0495	.0421	.0427	.0410

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134049 / SHAHAGAD

Feeder No / Name : 202 / PATHARWALA - AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
10	.6097		
11	.6401	.9665	
12	.6554	1.0288	.823
13	.6401	1.0288	
14	.6249	.9945	
15	.6401	.9602	
16		.9945	
17	.7926	.9945	
Max	.7926	1.0288	.823
Min	.6097	.9602	.823
Avg	.6576	.9954	.823

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134049 / SHAHAGAD

Feeder No / Name : 203 / S.PIMPLEGON AG 1

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	04-JUN-17	05-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1524	.3772
2				.1524	.3772
3				.1677	.3772
4				.1677	.3772
5				.1829	.3944
6				.1981	.4287
7				.1981	.4458
8				.1829	
9				.1677	.6687
10		2.1605			
11	2.3624	2.1948			
12	2.3167	2.3148			
13	2.3472	2.332			
14	2.3167	2.332			
15	2.21	2.4006			
16	2.2405	2.2291	.1524		
17	2.2862	1.8861	.1524		
24				.1524	.3772
Max	2.3624	2.4006	.1524	.1981	.6687
Min	2.21	1.8861	.1524	.1524	.3772
Avg	2.2971	2.2312	.1524	.1722	.4248

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134049 / SHAHAGAD

Feeder No / Name : 204 / GINING

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1294	.0185	.0171			.0185	.0171
2	.1294	.0185	.0171			.0185	.0171
3	.1294	.0175	.0171			.0185	.0171
4	.1294	.0185	.0171			.0185	.0171
5	.1294	.0185	.0171			.0185	.0171
6	.1478	.0185	.0171			.0185	.0171
7	.1478	.0185	.0171			.0185	.0171
8	.0185	.0185	.0171			.0924	
9	.0185	.1478	.0171			.0924	.0754
10	.0185	.0187	.0171			.1294	.1698
11	.0185	.0171	.0171			.1478	.12
12	.0185	.0171	.0171	.1294	.0185	.1509	.1543
13	.0185	.0171		.1294	.1478	.132	.12
14	.0185	.0171		.1294	.1478	.0171	
15	.0185	.0171		.1294	.1478		
16	.0185	.0171			.1478	.0171	.0686
17	.0185	.0171			.1478	.0171	.0171
18	.0185	.0171					.1029
19	.0185				.1478	.0171	.12
20	.0185				.1254	.0171	.1029
21						.0171	
22					.0185	.0171	.1029
23	.0185	.0171			.0185	.0171	.1029
24	.1294	.0185	.0171			.0185	.0171
Max	.1478	.1478	.0171	.1294	.1478	.1509	.1698
Min	.0185	.0171	.0171	.1294	.0185	.0171	.0171
Avg	.0605	.0243	.0171	.1294	.1068	.0468	.0697

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134049 / SHAHAGAD

Feeder No / Name : 205 / PATHARWALA(GAOTHAN)

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1753	.1753	.1867		.1753		.1867
2	.1753	.1753	.1867		.1753		.1715
3	.1753	.1753	.1867		.1753		.2058
4	.2103	.2103	.2614		.2103		.2058
5	.333	.2454	.3547		.298		.2401
6	.3366	.2804	.4108		.3506		.2743
7	.3856	.3506	.4854		.3898		.3772
8	.3681	.3856	.4668		.3544		
9	.3506	.4031	.4481		.3155		.3258
10		.3547	.2987		.298		.2401
11	.2279	.2401			.2804		.1867
12	.2218	.2058	.112		.2454		.1029
13	.1753	.1715					.112
14	.1753	.1867				.112	.112
15	.1753	.2054			.1753		.0747
16		.2614			.2103	.1494	.0857
17	.2629	.2987			.2454	.2054	.2915
18	.3856	.3547					.2743
19	.4557			.4252	.3155	.4854	
20	.3506			.3898	.3544	.3772	.3772
21				.3326		.3258	.2743
22				.2957		.2743	.2427
23	.2629	.2614		.2587		.2614	.2427
24	.2279	.1753	.2241		.2218		.2241
Max	.4557	.4031	.4854	.4252	.3898	.4854	.3772
Min	.1753	.1715	.112	.2587	.1753	.112	.0747
Avg	.2716	.2559	.3018	.3404	.2662	.2739	.2195

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134049 / SHAHAGAD

Feeder No / Name : 206 / MAHAKALA AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	03-JUN-17	04-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.5639			
3	.6097			
4	.6401			
5	.6859			
6	.7316			
7	.7926			
8	.8078			
9	.8535	.4588		
13				.1715
14				.2743
15			.1524	.4115
16				.4115
17				.4115
24	.5335			
Max	.8535	.4588	.1524	.4115
Min	.5335	.4588	.1524	.1715
Avg	.6910	.4588	.1524	.3361

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134049 / SHAHAGAD

Feeder No / Name : 207 / SHAHAGAD GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0985		.9945		1.1517	.9568	.9709
2	1.0985		1.0288		1.1517	.9465	1.0082
3	1.1163		1.0288		1.1694	.964	1.0829
4	1.2403		1.0631		1.2048	.9816	1.1949
5	1.3289		1.166		1.267	1.0166	1.1317
6	1.382		1.2003	1.3032	1.2757	1.0517	1.307
7	1.4175		1.2689	1.2689	1.3466	1.1218	1.2346
8	1.4529		1.3717	1.1145	1.4175	1.1568	
9	1.4175			1.0631	1.3146	1.1517	1.307
10	1.3146		1.2346	1.0288	1.262	1.2012	1.307
11			1.1317		.1524		1.2696
12			1.1317	1.2048	1.1517	1.307	.9945
13	1.4175	1.0288		1.1517	1.0867	1.307	
14		1.166		1.1517	1.0517	1.0829	
15	1.2971	1.2003		1.134	1.0631		1.0829
16	1.3466				1.2403	1.166	1.0974
17		1.3375		1.0631		1.307	1.2696
18	1.5061	1.4403		1.1393	1.3289		1.166
19	1.5238			1.3466	1.2403	1.3032	1.307
20	1.4529			1.4175	1.3321	1.2346	1.1317
21				1.3643		1.2696	1.0288
22				1.3289	1.0631	1.2323	1.0829
23		1.2003		1.2403	1.0517	1.1949	.9945
24	1.134		1.0288		1.1694		1.0288
Max	1.5238	1.4403	1.3717	1.4175	1.4175	1.307	1.307
Min	1.0985	1.0288	.9945	1.0288	.1524	.9465	.9709
Avg	1.3262	1.2289	1.1374	1.2075	1.1587	1.1477	1.1428

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134052 / SUKHAPURI

Feeder No / Name : 201 / SUKHAPURI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	02-JUN-17	03-JUN-17	04-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.362		
3		.362		
4		.362		
5		.362		
6		.362		
7		.6335		
8		.724		
9		.6335		
11				.6335
12	1.4251	.6335		.4525
13	1.4251	.8059		.4525
14	1.4251	.8954		.4525
15	1.2574	.8954	.3734	.4525
16	1.4251	.8954	.5544	
17	1.1736	.9745		
18	.6335			.543
19	.6335			.4525
20	.543			.543
21	.4525			.4525
22	.5068			.4525
23	.362			.4525
24		.4525		
Max	1.4251	.9745	.5544	.6335
Min	.362	.362	.3734	.4525
Avg	.9386	.6236	.4639	.4854

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134052 / SUKHAPURI

Feeder No / Name : 202 / BELGAON

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	02-JUN-17	03-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.724	
2		.724	
3		.724	
4		.724	
5		.8059	
6		.724	
7		.8954	
8		.724	
9		.8059	
10		.362	
11		.2715	.543
12	.2715	.2715	.4525
13	.181	.2715	.543
14		.2715	.4525
15	.2715	.2715	.4525
16	.181	.2715	.4525
17	.362	.362	.4525
18	.6335		
19	.6335		.543
20			.6335
21	.4525		.4525
22	.543		.362
23	.543		.362
24		.6335	
Max	.6335	.8954	.6335
Min	.181	.2715	.362
Avg	.4073	.5465	.4751

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134052 / SUKHAPURI

Feeder No / Name : 203 / WADIKALYA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	02-JUN-17	03-JUN-17	04-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.362		
2		.362		
3		.362		
4		.4525		
5		.4525		
6		.4525		
7		.543		
8		.543		
9		.6335		
10		.181		
11		.181		.362
12	.181	.0924		.362
13	.0924	.0905		
14	.0924	.0924		
15	.0924	.181	.0934	.362
16	.181	.181	.0934	.543
17	.181	.0924		
18	.4525		.1867	.362
19				.543
20				.543
21				.4525
22	.2715			.4525
23	.2715			.4525
24		.362		
Max	.4525	.6335	.1867	.543
Min	.0924	.0905	.0934	.362
Avg	.2017	.3120	.1245	.4435

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134053 / GONDI

Feeder No / Name : 201 / HASNAPUR AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0848			.0267
2	.0848			.0267
3	.1006			.0267
4				.0305
5				.0305
6				.0267
7				.0286
10	.8848	.5335		
11	.9907			
12		.8383		
13	1.1431	.9907		
14	.9907			
15		.0914		
16	.9907			
17	.9907			
18	.0762			.0678
19			.0339	.0848
20	.0762		.0339	.1017
21	.0762		.0339	.1017
22			.0339	.1017
23	.0762		.0339	.0848
24	.0848			.0339
Max	1.1431	.9907	.0339	.1017
Min	.0762	.0914	.0339	.0267
Avg	.4750	.6135	.0339	.0552

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134053 / GONDI

Feeder No / Name : 202 / GHUNGARDE HADGAON AG AG Feeder with SDT
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)
1	.2515	
2	.2683	
3	.2683	
4	.285	
5	.2984	
6	.3315	
7	.3688	
8	.3768	
9	.3768	
16		.0678
17		.0678
24	.2374	
Max	.3768	.0678
Min	.2374	.0678
Avg	.3063	.0678

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134053 / GONDI

Feeder No / Name : 203 / GONDI AG AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.0152			.0152
2	.3647				.0152
3	.3978	.0152			.0143
4	.431				
5	.4641	.3353			
6	.4641	.381			
7	.5304	.381			
8	.5407	.4877			
9	.5243				
13					.1341
14					.1677
15					.1677
16					.2012
17					.2012
18	.0015				.0168
19			.0015	.017	.0335
20	.0152			.017	.0339
21				.017	.0339
22				.017	.0339
23				.017	.0339
24	.3353	.0015			.017
Max	.5407	.4877	.0015	.017	.2012
Min	.0015	.0015	.0015	.017	.0143
Avg	.3670	.2310	.0015	.017	.0746

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134053 / GONDI

Feeder No / Name : 204 / KARNJALA AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17
HR	Load (MW)	Load (MW)
10	.9995	.7621
11	1.1431	
12		.9145
13	.1143	1.0669
14	.0991	
15		.9907
16	1.0669	
24	.6097	
Max	1.1431	1.0669
Min	.0991	.7621
Avg	.6721	.9336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134054 / EKLAHARA

Feeder No / Name : 201 / KARANJALA AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	03-JUN-17	05-JUN-17	06-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0914		
2		.0924		
3		.0924		
4		.112		
5		.1384		
6		.1478		
7		.1848		
8		.2743	.2218	
9		.2801	.2195	
24	.6097	.0924		.0346
Max	.6097	.2801	.2218	.0346
Min	.6097	.0914	.2195	.0346
Avg	.6097	.1506	.2207	.0346

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134054 / EKLAHARA

Feeder No / Name : 202 / BHARDI AG
Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	01-JUN-17	03-JUN-17
HR	Load (MW)	Load (MW)
1		.663
2		.9326
6		.6783
7		.9326
8		.9116
9		.9326
24	.6097	.5935
Max	.6097	.9326
Min	.6097	.5935
Avg	.6097	.8063

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134054 / EKLAHARA

Feeder No / Name : 203 / EKLAHARA AG.

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	03-JUN-17
HR	Load (MW)	Load (MW)
10		.7459
11		.8288
12		.4572
13		.6783
20	.8383	
Max	.8383	.8288
Min	.8383	.4572
Avg	.8383	.6776

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134054 / EKLHARA

Feeder No / Name : 204 / EAKLAHARA GACTHAN
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	03-JUN-17	05-JUN-17	06-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1463		
2	.1494		
3	.1478		
4	.1478		
5	.0168		
9	.0914		
10	.0934		
11	.0934		
12	.3361		
13	.3361		
19		.6348	
23		.4481	
24	.168	.2987	.4152
Max	.3361	.6348	.4152
Min	.0168	.2987	.4152
Avg	.1570	.4605	.4152

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134055 / SHEVGA

Feeder No / Name : 201 / HARATHKHEDA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.5716	.6668		.381	.4763	.381
2	.7621	.5716	.6668		.381	.4763	.381
3	.7621	.5716	.6668		.381	.4763	.381
4	.7621	.6668	.7621		.4763	.4763	.381
5	.7621	.6668	.7621		.5716	.5716	.5716
6	.9526	.7621	.8573		.7621	.6668	.7621
7	1.0479	.8573	.9526		.6668	.6668	.6668
8	1.0479	.8573	.9526		.5716	.5716	
9	1.0479	.9526	.9526		.5716	.4763	
10	.381	.381	.381		.4763	.5716	
11	.381	.381	.381		.5716		
12	.381	.381	.381		.5716	.5716	
13	.2858	.381	.381	.2858	.5716	.5716	
14	.2858	.381		.2858	.5716	.5716	
15	.2858	.2858	.2858	.2858	.5716	.5716	
16	.381	.2858	.2858	.381	.5716	.5716	
17	.2858	.2858	.2858	.381	.5716	.5716	
18	.4763	.381		.4763	.4763	.381	
19	.381	.4763		.4763	.5716	.4763	.4763
20	.381	.5716		.6668		.5716	.4763
21	.5716	.381		.4763	.4763	.4763	.5716
22	.381	.381		.4763	.381	.381	.4763
23	.381	.381		.381	.381	.381	.381
24	.5716	.5716	.5716		.381	.4763	.381
Max	1.0479	.9526	.9526	.6668	.7621	.6668	.7621
Min	.2858	.2858	.2858	.2858	.381	.381	.381
Avg	.5716	.5160	.5996	.4157	.5177	.5219	.4836

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134055 / SHEVGA

Feeder No / Name : 202 / SHEVGA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.4763	.5716		.381	.381	.381
2	.4763	.4763	.5716		.381	.381	.381
3	.4763	.4763	.5716		.381	.381	.381
4	.4763	.4763	.5716		.4763	.4763	.381
5	.5716	.6668	.6668		.5716	.5716	.5716
6	.8573	.7621	.4763		.5716	.5716	.7621
7	1.1431	.9526	1.0479		.5716	.5716	.6668
8	1.1431	1.0479	1.0479		.5716	.5716	
9	.9526	1.1431	1.0479			.381	
10	.381		.381			.5716	
11	.381	.381	.381		.8573	.7621	
12	.381	.381	.381		.8573	.7621	
13	.381		.381	.381	.7621	.7621	
14	.2858	.381		.381	.7621	.7621	
15	.2858	.381	.2858	.381	.6668	.6668	
16	.381	.381	.381	.381	.6668	.6668	
17	.381	.381	.2858	.4763	.8573	.5716	
18	.4763	.4763		.4763	.4763		
19	.5716	.5716		.5716	.5716	.4763	.6668
20	.5716	.5716		.6668		.5716	.5716
21	.5716	.381		.4763	.4763	.4763	.5716
22	.381	.381		.4763	.4763	.381	.4763
23	.381	.381		.381	.381	.381	.381
24	.4763	.381	.4763		.381	.381	.381
Max	1.1431	1.1431	1.0479	.6668	.8573	.7621	.7621
Min	.2858	.381	.2858	.381	.381	.381	.381
Avg	.5358	.5412	.5604	.4590	.5761	.5426	.5056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134055 / SHEVGA

Feeder No / Name : 203 / DHANGAR PIMPRI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.381		.5716	.4763	.4763
2	.381	.381	.381		.5716	.4763	.4763
3	.381	.381	.381		.5716	.4763	.5716
4	.381	.381	.4763		.5716	.4763	.5716
5	.381	.4763	.4763		.5716	.4763	.5716
6	.5716	.5716	.5716		.6668	.5716	.7621
7	.4763	.5716	.5716		.7621	.6668	.7621
8	.4763	.4763	.5716		.7621	.6668	
9	.4763	.4763	.4763		.7621	.6668	
10	1.3336	1.1431	1.3336		.381		
11	1.4289	1.5242	1.5242			.2858	
12	1.5242	1.3336	1.6194			.2858	
13	1.6194		1.5242	1.4289	.381	.2858	
14	1.5242	1.5242		1.5242	.381	.2858	
15	1.5242	1.4289	.8573	1.4289	.2858	.2858	
16	1.5242	1.5242		.6668	.2858	.2858	
17	.8573	1.5242		.7621	.2858	.2858	
18	.381	.381		.4763	.381	.2858	
19	.4763	.5716		.4763	.4763	.4763	.4763
20	.4763	.4763		.5716		.4763	.5716
21	.4763	.381		.4763	.4763	.4763	.5716
22	.381	.381		.4763	.381	.381	.381
23	.381	.381		.381	.381	.381	.381
24	.381	.381	.381		.5716	.4763	.4763
Max	1.6194	1.5242	1.6194	1.5242	.7621	.6668	.7621
Min	.381	.381	.381	.381	.2858	.2858	.381
Avg	.7581	.7414	.7684	.7881	.4990	.4307	.5423

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134072 / KARJAT

Feeder No / Name : 201 / 11 KV KARJAT-BHAYGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.7621	.7621		.4763		.381
2	.8573	.7621	.7621		.4763		.381
3	.7621	.7621	.7621		.4763		.381
4	.9526	.7621	.8573		.4763		.381
5	1.1431	.8383	.9526		.5716		.381
6	1.3336	1.0669	1.1431		.5716		.4763
7	1.6194	1.2498	.7621		.4763		.4763
8	1.6194	1.2803	1.3336		.4763		.4763
9		1.1888	1.5242		.4763		.381
10	.381	.381	.381		.6668		.7621
11	.381	.4763	.381			.6401	.9526
12	.3429	.4763	.381			.6859	1.1431
13	.3429	.4763	.3239	.7621		.7621	1.1431
14	.3429	.4763	.3239	.5716			1.4289
15	.3429	.381		.5716		.8573	1.4289
16	.381	.381		.5716		.5335	1.3336
17	.4191	.4763		.5716		.9907	1.3336
18	.4763	.4763		.4763		.381	.5716
19	.6668	.4763		.5716		.6668	.6668
20	.7621			.5716		.724	.5716
21	.724	.4763		.5716		.6097	.5716
22	.6668	.4763		.4763		.5716	.5716
23	.6859	.4763		.4763		.5716	.5716
24	.6859	.8573	.7621		.4763		.4763
Max	1.6194	1.2803	1.5242	.7621	.6668	.9907	1.4289
Min	.3429	.381	.3239	.4763	.4763	.381	.381
Avg	.7281	.6711	.7608	.5629	.5109	.6662	.7184

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134072 / KARJAT

Feeder No / Name : 202 / 11 KV KARJAT-A

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.381	.2858
2					.381	.2858
3					.381	.2858
4					.381	.2858
5					.381	.2858
6					.4763	
7					.4763	.4763
8					.4763	.4763
9					.5716	.381
10	.4763	.4763	.4763			
11	.381	.5716	.4763			
12	.4001	.5716	.4763			
13	.381	.5716	.381	.381		
14	.3429	.5716	.4763	.4763		
15	.3429	.5716		.4763		
16	.4191	.4763		.4763		
17	.4763	.5716		.5716		
23	.6859					
24	.6859				.381	.381
Max	.6859	.5716	.4763	.5716	.5716	.4763
Min	.3429	.4763	.381	.381	.381	.2858
Avg	.4591	.5478	.4572	.4763	.4287	.3493

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134072 / KARJAT

Feeder No / Name : 203 / 11 KV DHANGAR PIMPALGAON Single Phasing Feeders
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.381		.5716		.381
2	.381	.381	.381		.5716		.381
3	.381	.381	.381		.5716		.381
4	.381	.4191	.381		.5716		.381
5	.4191	.4191	.381		.6668		.381
6	.4763	.4763	.4763				.4763
7	.4763	.4763	.381		.7621		.6668
8	.381	.4572	.381		.7621		.6668
9		.381	.381		.8573		
10	.6668	.6668	.6668		.381		.1905
11	.5716	.8573					.381
12	.5335	.8573	.6668			.1905	.381
13	.5335	.8573	.381			.1905	.381
14	.4763	.7621	.381				.381
15	.4954	.6668		.7621		.2286	.381
16	.6097	.6668		.7621		.2286	.381
17	.6668	.6668		.7621		.2858	.381
18	.3429	.381		.381		.381	.381
19	.381	.381		.4763		.4763	.4763
20	.4763			.4763		.4763	.4763
21	.4763	.381		.4763		.4191	
22	.4191	.381		.381		.381	.4763
23	.381	.381		.381		.381	.381
24	.6859	.381			.5716		.4763
Max	.6859	.8573	.6668	.7621	.8573	.4763	.6668
Min	.3429	.381	.381	.381	.381	.1905	.1905
Avg	.4779	.5243	.4323	.5398	.6287	.3308	.4200

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134074 / Chandanapuri

Feeder No / Name : 201 / CHANDANAPURI GAOTHAN
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3361	.3361		.3429	.3429	.743
2	.381	.3361			.381	.381	.7621
3	.4382	.4108			.381	.381	.7621
4	.5716	.5601	.4854		.4001	.5335	.8192
5	.6859	.7095	.6722		.5716	.724	.8764
6	.8002	.8962	.8589		.6859	.9907	.9335
7	.8573	.8589	.8029		.743	.9145	1.0098
8	.1905		.7095		.8383	.8002	.7621
9	.7049	.5601	.6348		.8002	.6668	.7621
10	.4668	.5601	.5601		.5335	.6097	.5335
11	.2987	.3361	.3361		.362	.5335	.4481
12	.2987	.2957	.3361		.362	.6097	.3734
13	.3361	.2987	.2987		.3429	.4954	.2896
14	.3361	.2987		.3048	.381	.4572	.2801
15	.3734	.3361	.2987	.3239	.4001		.2801
16	.3734	.3734	.3734	.362	.381	.381	.2987
17	.4668	.4854	.4706	.4382	.6097	.5335	.2987
18	.6722	.5228		.5716	.743	.724	.6348
19	.7468		.7095	.6668	.8002	.8002	.8215
20	.6154		.6722	.5716		.724	.6722
21	.4481	.4108	.7095	.6859		.5716	.4668
22	.4108	.3734		.6097		.4382	.415
23	.3734	.3734		.4191	.362	.381	.4108
24	.3239	.5228	.3361		.3048	.3429	.743
Max	.8573	.8962	.8589	.6859	.8383	.9907	1.0098
Min	.1905	.2957	.2987	.3048	.3048	.3429	.2801
Avg	.4797	.4693	.5334	.4954	.5108	.5798	.5999

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134074 / Chandanapuri

Feeder No / Name : 202 / BHAMBERI-AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1812			.4191		.6478
2	1.2384			.4382		.724
3	1.2574			.4954		.7621
4	1.2955			.5716		.8002
5	1.3717			.6287		.7621
6	1.448			.6859	.5144	.8383
7	1.1241	.3647	.663	.724	.6097	.8002
8	1.1812	.5243	.663	.743	.6859	.8573
9	1.2384	.4588	.6882	.7621	.7811	.8573
24	1.1431			.5525		.6097
Max	1.448	.5243	.6882	.7621	.7811	.8573
Min	1.1241	.3647	.663	.4191	.5144	.6097
Avg	1.2479	.4493	.6714	.6021	.6478	.7659

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134074 / Chandanapuri

Feeder No / Name : 203 / CHURMAPURI-AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.2486		.2286		.2286
2	.4191	.2801		.2477		.2667
3	.4572	.2622		.3048		.2858
4	.4191	.3361		.362		.3239
5	.4763	.3315		.4382		.2858
6	.4572	.3315		.381	.3239	.2667
7	.4191	.426	.2321	.4001	.362	.3048
8	.4954	.4144	.2984	.4191	.3429	
9	.4763	.3277	.2984	.362	.362	
17			.1524			
24	.381	.2486		.1715		
Max	.4954	.426	.2984	.4382	.362	.3239
Min	.381	.2486	.1524	.1715	.3239	.2286
Avg	.4420	.3207	.2453	.3315	.3477	.2803

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134009 / GHANSAWANGI

Feeder No / Name : 201 / 11KV BOLEGAON FDR

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.6859	.6859	.381	.5144	.5144	.5144
2	.7621	.6859	.6859	.381	.5144	.5144	.5144
3	.7621	.6859	.6859	.381	.5144	.5144	.5144
4	.7621	.6859	.6859	.381	.5144	.5144	.5144
5	.7621	.6859	.8573	.381	.5144	.6859	.6859
6	.9526	.8573	.8573	.5716	.6859	.6859	.6859
7	.9526	.8573	.8573	.5716	.5144	.8573	.6859
8	.9526		.6859	.381	.6859	1.0288	.8573
9	.7621		.5144	.381	.6859	1.0288	.8573
10	.8573	.8573	1.3717		.5144	.5144	.6859
11	1.0288		1.3717	.362	.5144	.3429	.381
12	.8573		1.0288	.5144	.3429		.381
13	.8573	.8573	1.3717	.5144	.3429		.381
14	.8573		1.3717	.5144	.3429		.2858
15	.6859	.8573	1.3717	.5144	.3429	.3429	.381
16	.8573	.8573	1.5432	.5144	.3429	.3429	.381
17	.8573	.8573	1.3717	.5144	.3429	.3429	.5716
18	.8573	.6859		.5716	.5144	.5144	.5716
19	.8573	.8573		.9526	.6859	.6859	.9526
20	.8573	.8573		.9526	.6859	.8573	.9526
21	.8573	.8573	.7621	.7621	.6859	.6859	.7621
22	.6859	.6859	.7621	.7621	.5144	.6859	.7621
23	.6859	.6859	.7621	.7621	.5144	.6859	.7621
24	.7621	.6859	.6859	.381	.5144	.5144	.6859
Max	1.0288	.8573	1.5432	.9526	.6859	1.0288	.9526
Min	.6859	.6859	.5144	.362	.3429	.3429	.2858
Avg	.8272	.7761	.9662	.5392	.5144	.6124	.6136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134009 / GHANSAWANGI

Feeder No / Name : 202 / 11KV MCHINCHOLI FDR Single Phasing Feeders
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	1.5432	1.3717	1.0288	.9526	.8573	.8573
2	1.5432	1.5432	1.3717	1.0288	.9526	.8573	.8573
3	1.5432		1.3717	.5716	.9526	.8573	.8573
4	1.7147		1.3717	.5716	.9526	.8573	.8573
5	1.7147	1.5432	1.3717	.5716	.9526	1.0288	1.0288
6	2.2291	1.8861	2.0576	1.3717	1.0479	1.2003	1.2003
7	2.572	2.4006	2.4006	1.3717	1.1431	1.2003	1.2003
8	2.572	2.4006	2.572	1.3717		1.0288	
9	2.4006	.8573	2.2291	1.2003		1.0288	1.0288
10	.6859	.6859	.9526	.7621	1.0288	1.3717	1.2003
11	.6859	.6859	.7621	.8573	1.2003	1.5432	1.6194
12	.6859	.6859	.7621	.7621	1.3717		1.7147
13	.5144	.6859	.7621	.6668	2.2291		1.9052
14	.6859	.6859	.7621	.6668	2.2291		1.9052
15	.6859	.6859	.7621	.7621	1.7147	1.7147	1.7147
16	.6859	.6859	.8573	.6668	1.7147	1.7147	1.7147
17	.6859	.6859		.7621	1.7147	1.7147	1.8099
18	.6859	.8573		.9526	.8573	.8573	.7621
19		1.2003		.9526	1.0288	1.0288	1.1431
20	1.2003	1.0288	1.1431	1.1431	1.2003	1.2003	1.2384
21	1.2003	1.0288	1.1431	1.1431	1.2003	.6859	1.1431
22	1.2003		.9526	.9526	.8573	.8573	.9526
23	1.2003	1.0288	.9526	.9526	.5144	.8573	.7621
24	1.5432	1.2003	1.3717	.9431	.9526	.8573	.8573
Max	2.572	2.4006	2.572	1.3717	2.2291	1.7147	1.9052
Min	.5144	.6859	.7621	.5716	.5144	.6859	.7621
Avg	1.3121	1.1431	1.3001	.9181	1.2167	1.1104	1.2317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134009 / GHANSAWANGI

Feeder No / Name : 203 / 11KV GHANSAWANGI FDR Single Phasing Feeders
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.6859	.6859	.6668	.7716	.6859	.6859
2	.7621	.6859	.6859	.6668	.7716	.6859	.6859
3	.7621	.6859	.6859	.6668	.7716	.6859	.6859
4	.7621	.6859	.6859	.6668	.8573	.6859	.6859
5	.7621	.6859	.8573	.7621	.8573	.8573	.8573
6	2.2291	.8573	.8573	.9526	1.0288	1.2003	1.0288
7	.9526	.8573	1.0288	.9526	1.286	1.3717	1.0288
8	1.1431	.8573	1.0288	.9526	1.4575	1.3717	
9	.9526	.8573	.8573	.8573	1.3717	1.3717	1.2003
10	.8573	.8573	1.2003	.8573	1.2003		1.0288
11		1.7147	1.3717	.8573	1.2003		.8573
12	1.0288	1.7147	1.4575	.9431	1.0288		.7621
13	1.7147	1.5432	1.3717	1.0288	1.2003		.7621
14	1.7147	1.5432	1.3717	1.0288	1.2003		.7621
15	1.7147	1.5432	1.3717	1.0288	1.2003	1.2003	.7621
16	1.7147	1.5432	1.286	1.0288	1.2003	1.2003	.7621
17	1.7147	1.5432		.9431	1.2003	1.2003	.9526
18	.8573	.8573	.9526	1.1431	1.2003		1.1431
19	1.0288	.8573	.9526	.8573	1.2003	1.2003	.9526
20	1.0288	.8573	.9526	.9526	.12	1.2003	1.2384
21	1.0288	.8573	.9526	.8573	1.0288	1.0288	1.1431
22	.8573	.6859	.7621	.7621	.8573	1.0288	.9526
23	.8573	.6859	.6668	.5716	.8573	.8573	.7621
24		.6859	.6859	.6668	.6859	.8573	.8573
Max	2.2291	1.7147	1.4575	1.1431	1.4575	1.3717	1.2384
Min	.7621	.6859	.6668	.5716	.12	.6859	.6859
Avg	1.1457	1.0145	.9882	.8613	1.0231	1.0383	.8938

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134009 / GHANSAWANGI

Feeder No / Name : 204 / 11KV TANUWADI FDR
Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.0857	.6859	.6859	.381	.3429	.3429
2	.8573	.0857	.6859	.6859	.381	.3429	.3429
3	.8573	.0857	.6859	.6859	.381	.3429	.3429
4	.8573	.0857	.6859	.381	.381	.3429	.3429
5	.8573	.0857	.8573	.6859	.381	.5144	.5144
6	1.0288	.1715	.8573	.8573	.5716	.5144	.5144
7	1.0288	.1715	1.0288	.8573	.5716	.5144	
8	1.0288	.6859	1.0288	1.0288	.5716	.5144	.3429
9	1.0288	.6859	1.0288	1.0288	.381	.5144	.3429
10	.3429	.6859		.5716	.6859	.6859	.6859
11	.3429	.5144		.381	.6859	.6859	.9526
12	.3429	.5144	.381	.381	.6859		.9526
13	.3429	.5144	.381	.381	.6859		1.1431
14	.3429	.5144	.381	.381	.6859		.9526
15	.3429	.3429	.381		.6859	.6859	.9526
16	.3429	.3429	.381	.381	.6859	.6859	.9526
17	.3429	.5144		.381	.6859	.6859	.9526
18	.5144	.5144		.381	.3429	.3429	.5716
19	.5144	.5144		.381	.5144	.5144	.7621
20	.5144	.5144		.381	.5144	.5144	.7621
21		.5144	.381	.381	.5144	.5144	.5716
22		.5144	.381	.381	.3429	.3429	.5716
23	.1715	.5144	.381	.381	.3429	.3429	.5716
24	.6859	.0171	.6859	.5144	.381	.3429	.3429
Max	1.0288	.6859	1.0288	1.0288	.6859	.6859	1.1431
Min	.1715	.0171	.381	.381	.3429	.3429	.3429
Avg	.6157	.3829	.6266	.5459	.5184	.4899	.6428

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134009 / GHANSAWANGI

Feeder No / Name : 205 / 11 KV BOLEGAON 2

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.6859	.6859	.381	.5144	.5144	.5144
2	.5716	.6859	.6859	.381	.0514	.5144	.5144
3	.5716	.6859	.6859	.381	.5144	.5144	.5144
4	.5716	.6859	.6859	.381	.5144	.6859	.5144
5	.7621	.6859	.8573	.5716	.5144	.6859	.5144
6	.9526	.8573	.8573	.9526	.6859	.6859	.5144
7	.9526	.8573	.8573	.9526	.6859	.6859	.5144
8	.5716	.6859		.8573	.6859	.8573	.5144
9	.381	.6859	.5144	.7621	.6859	.8573	.6859
10	.6859	.8573	.6001	.5144	.5144	.5144	.5144
11	.8573	.8573		.5144	.5144		.2858
12	.6001	.8573	.6859	.5144	.3429	.3429	.2858
13	.6859	.8573	.6859	.5144	.3429	.3429	.2858
14	.5144	.8573	.6001	.5144	.3429	.3429	.2858
15	.5144	.8573	.6001	.5144	.3429	.3429	.2858
16	.6859	.6859	.6859	.5144	.3429	.3429	.381
17	.6859	.6859		.5144	.3429	.3429	.5716
18	.5144	.6859		.5716	.5144	.5144	.5716
19	.8573	.8573	.8573	.6668	.6859	.6859	.9526
20	.8573	.8573	.5716	.7621	.6859	.8573	.9526
21	.6859	.8573	.5716	.5716	.6859	.6859	.7621
22	.6859	.6859	.5716	.5716	.5144	.6859	.5716
23	.6859	.6859	.4763	.4763	.5144	.6859	.5716
24	.381	.6859	.6859	.381	.5144	.5144	.5144
Max	.9526	.8573	.8573	.9526	.6859	.8573	.9526
Min	.381	.6859	.4763	.381	.0514	.3429	.2858
Avg	.6585	.7645	.6711	.5724	.5023	.5740	.5247

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 201 / 11KV R.U.GAON-AG FDR
Feeder KV- 11 / OUTGOING

AG Feeder with SDT

DATE	01-JUN-17	03-JUN-17	06-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.1431	.8573	
2	1.1431	1.1431	
3	1.2384	1.1431	
4	1.3336	1.3336	
5	1.5623	1.4289	
6	1.6385	1.6004	
7	1.8671	1.4861	
8	1.7147	1.4289	
9	1.6004	1.1431	
12			.3048
13			.9526
14			1.2193
15			.9526
16			.9145
17			.7621
24	.5716	.7621	
Max	1.8671	1.6004	1.2193
Min	.5716	.7621	.3048
Avg	1.3813	1.2327	.8510

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 202 / 11KV PANEWADI-AG FDR Ag dominated/Pure Ag
Feeder KV- 11 / OUTGOING

DATE	02-JUN-17	04-JUN-17	05-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.381	.1905
2			.381	.1905
3			.4191	.1905
4			.5335	.1905
5			.5716	.1524
6			.6097	.1905
7			.3429	
8			.6668	.1905
9			.6668	
14		.381		
15		.8002		
16	.7621	.7049		
17	.8383	.6668		
24			.381	.1905
Max	.8383	.8002	.6668	.1905
Min	.7621	.381	.3429	.1524
Avg	.8002	.6382	.4953	.1857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 203 / 11KVTALEGOAN-AG FDR
Feeder KV- 11 / OUTGOING

AG Feeder with SDT

DATE	01-JUN-17	03-JUN-17	06-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.7621	
2	.7621	.9526	
3	.8573	.9526	
4	.9526	1.1431	
5	1.0479	1.3336	
6	1.2765	1.4289	
7	1.6385	1.6385	
8	1.6194	1.6194	
9	1.3908	1.5432	
16			.5906
17			.7621
18			.8192
19			.6668
20			.5716
24	.7621	.6668	
Max	1.6385	1.6385	.8192
Min	.7621	.6668	.5716
Avg	1.1452	1.2041	.6821

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 204 / 11KV SHINDEWADGAON-AG AG Feeder with SDT
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	04-JUN-17	05-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.381	.2858
2				.381	.2858
3				.381	.2858
4				.381	.2858
5				.381	.2667
6				.381	.2858
7				.381	.4382
8				.4191	
9				.4572	
10	.743				
11		.9145			
12		.4572			
13		.8002			
14		.8573	.362		
15		.6287	.7049		
16		.5716	.4572		
17		.6097	.5716		
24				.381	
Max	.743	.9145	.7049	.4572	.4382
Min	.743	.4572	.362	.381	.2667
Avg	.743	.6913	.5239	.3924	.3048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 205 / RUGAON GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239		.381		.5335		.4763
2	.3429		.381		.5716		.4191
3	.3239		.4191		.6859		.4191
4	.4954		.5716		.724		.4572
5	.6097		.6097		.8002		.4954
6	.6478		.6287		.7621		.381
7	.6097		.4572		.6287		
8	.6287		.4191		.7621		
9	.5525		.4382		.5906		
10	.5144				.4954		
11		.5335					
12		.4572				.4191	
13		.4382				.381	
14		.4191		.0191		.4572	
15		.381		.0572		.4763	
16		.4191				.4954	
17		.381				.5335	
18		.5906				.6097	
19		.6478		.7811		.6668	
20		.5716		.8002		.724	
21		.4572		.7621		.6668	
22		.381		.6668		.6097	
23		.4191		.5716		.4763	
24	.3429		.381		.4191		.4191
Max	.6478	.6478	.6287	.8002	.8002	.724	.4954
Min	.3239	.381	.381	.0191	.4191	.381	.381
Avg	.4902	.4690	.4687	.5226	.6339	.5430	.4382

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 206 / SHINDEWADGAON GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144		.4763		.5716		.4763
2	.4572		.5716		.5716		.4763
3	.4954		.5716		.6097		.5716
4	.5716		.5716		.6478		.6668
5	.6668		.6668		.6859		.8192
6	.7621		.8002		.7621		.7621
7	.6668		.7621		.8192		.7811
8	.7049		.6668		.6668		.7811
9	.6478		.6668		.6478		
10	.5716				.4001		
11		.4191				.381	
12		.362				.4572	
13		.381				.4382	
14		.3429		.381		.4382	
15		.4191		.5144		.4191	
16		.381		.5335		.4382	
17		.362		.4954		.5716	
18		.4763		.4763		.6478	
19		.8002		.4763		.6668	
20		.7621		.7811		.6668	
21		.724		.7621			
22		.6668		.6668			
23		.4191		.5716		.5335	
24	.4572		.4191		.5335		.4763
Max	.7621	.8002	.8002	.7811	.8192	.6668	.8192
Min	.4572	.3429	.4191	.381	.4001	.381	.4763
Avg	.5923	.5012	.6173	.5659	.6287	.5144	.6456

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 207 / TALEGAON GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286		.2858		.3048		.2858
2	.2286		.2858		.3429		.3048
3	.2858		.381		.381		.381
4	.4191		.4191		.4763		.381
5	.4763		.4572		.5335		.4001
6	.5144		.4763		.5335		.4763
7	.4572		.4191		.381		
8	.4572		.381		.2858		.4763
9	.4382		.4382		.2477		
10	.3239				.2286		
11		.2477					
12		.2858					
13		.2477					
14		.2286		.2477			
15		.1905		.2477			
16		.1905		.2477			
17		.3239		.2858		.1905	
18		.4191		.3429		.3429	
19		.5144		.4191		.381	
20		.4572		.4382		.6097	
21		.381		.4191		.6097	
22		.3048		.381		.5716	
23		.3048		.2858		.381	
24	.2286		.2858		.2286		.3429
Max	.5144	.5144	.4763	.4382	.5335	.6097	.4763
Min	.2286	.1905	.2858	.2477	.2286	.1905	.2858
Avg	.3689	.3151	.3829	.3315	.3585	.4409	.3810

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 208 / PANEWADI GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905		.1905		.2858		.2858
2	.1905		.1905		.2858		.2858
3	.1905		.2286		.2286		.2858
4	.2286		.2286		.3429		.2858
5	.2667		.2858		.381		.3429
6	.3429		.3429		.381		.381
7	.3239		.381		.2477		.4001
8	.3048		.3048		.2286		
9	.2858		.2667		.1715		
10	.2858				.1905		
11		.2858				.1905	
12		.2096				.1905	
13		.2286				.1905	
14		.2096		.1905		.1715	
15		.1905		.3048		.1905	
16		.2286		.2096		.1905	
17		.2477		.2286		.1905	
18		.1905		.3239		.2667	
19		.362		.4191		.3048	
20		.3429		.4382		.4001	
21		.2858		.381		.381	
22						.362	
23		.2477		.2858		.2858	
24	.2286		.2286		.2858		.2858
Max	.3429	.362	.381	.4382	.381	.4001	.4001
Min	.1905	.1905	.1905	.1905	.1715	.1715	.2858
Avg	.2581	.2524	.2648	.3091	.2754	.2550	.3191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 209 / 11KV EXPRESS FEEDER UTTARA HV Non-Express Feeder
FOO Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191		.0191		.0191		.0191
2	.0191		.0191		.0191		.0191
3	.0191		.0191		.0191		.0191
4	.0191		.0191		.0191		.0191
5	.0191		.0191		.0191		.0191
6	.0191		.0191		.0191		.0191
7	.0191		.0191		.0191		.0191
8	.0191		.0191		.0191		
9	.0191		.0191		.0191		
10	.0191				.0191		
11		.0191				.0191	
12		.0191				.0191	
13		.0191				.0191	
14		.0191		.0191		.0191	
15		.0191		.0191		.0191	
16		.0191		.0191		.0191	
17		.0191					
18		.0191					
19		.0191		.0191		.0191	
20		.0191		.0191		.0191	
21		.0191		.0191		.0191	
22		.0191		.0191		.0191	
23		.0191		.0191		.0191	
24	.0191		.0191		.0191		.0191
Max	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0191	.0191	.0191	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134016 / KUMBHAR PIMPALGAON

Feeder No / Name : 201 / 11KV RAJA TAKALI-AG FDR AG Feeder with SDT
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	03-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.6097	
4				.6097	
5				.6859	
6				.6859	
7				.6859	
8				.6859	
11	1.9338	1.5337			
12	1.9605	2.2291			
13	2.0405	2.1434			
14		1.869			
15	2.0005	1.9719	.5144		
16	2.1472	1.2003			
17	2.1472		.6001		
23					.6859
24				.5335	
Max	2.1472	2.2291	.6001	.6859	.6859
Min	1.9338	1.2003	.5144	.5335	.6859
Avg	2.0383	1.8246	.5573	.6424	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134016 / KUMBHAR PIMPALGAON

Feeder No / Name : 202 / JAMB-AG AG Feeder with SDT
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0479		.9526		
2	1.0479		.9526		
3	1.0479		1.0479		
4	1.0479		1.0479		
5	1.0479		1.1431		
6	1.1431		1.1431		
7	1.1431		1.2384		
8	1.2384		1.3336		
9	1.2384		1.3336		
10					.5716
11					.4287
12		.6668			
13		.9526			.5144
14				.3429	.4287
15				.3944	.5144
16				.5144	.3429
17				.381	.3429
20	.6097				
24	.7621		.7621		
Max	1.2384	.9526	1.3336	.5144	.5716
Min	.6097	.6668	.7621	.3429	.3429
Avg	1.0340	.8097	1.0955	.4082	.4491

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134016 / KUMBHAR PIMPALGAON

Feeder No / Name : 203 / 11KV MURTI-AG FDR AG Feeder with SDT
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.1905
2					.381
3					.4763
4					.5716
10	.7621		.7621		
11	.7621		.6859		
12	.7735		.7716		
13	.7621		.8402		
14	.7621		.7545		
15	.8383	.9526	.6859		
16	.7926		.7621	.381	
17	.8078			.381	
24					.1905
Max	.8383	.9526	.8402	.381	.5716
Min	.7621	.9526	.6859	.381	.1905
Avg	.7826	.9526	.7518	.381	.3620

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134016 / KUMBHAR PIMPALGAON

Feeder No / Name : 204 / KPGAON -AG Ag dominated/Pure Ag
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	03-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905			
2	.1905	.1905			
3	.1905	.2858			
4	.2858	.2858			
5	.2858	.2858			
6	.2858	.381			
7	.4763	.381			
8	.5716	.381			
9	.5716	.4763			
10				.1905	
11		.4287			
13			.0381		.2572
14			.0381		.2572
15			.0381		.3429
16			.0381		.3429
17			.0381		.3429
24	.1905	.1905			
Max	.5716	.4763	.0381	.1905	.3429
Min	.1905	.1905	.0381	.1905	.2572
Avg	.3239	.3161	.0381	.1905	.3086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134016 / KUMBHAR PIMPALGAON

Feeder No / Name : 205 / K.P.TOWN GTN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	.6097
Max	.6097
Min	.6097
Avg	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134016 / KUMBHAR PIMPALGAON

Feeder No / Name : 206 / RAJATAKLI- GAONTHAN Gaothan Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763		.5716		.5716	.3429	.5716
2	.4763		.5716		.5716	.3429	.6668
3	.4763		.6668			.3429	.6668
4	.5716		.7621		.6668	.5144	.7621
5	.6668		.8573		.7621	.5335	
6	.8573		.7621		.7621	.6859	
7	.7621		.5716		.6668	.6859	
8			.6668		.5716	.6001	
9			.6668			.4287	
10			.5716			.381	
11	.381		.4287			.381	
12	.3944		.3429			.381	
13	.3086		.3944		.3429	.381	
14	.3429		.3601		.3429	.381	
15	.3429	.5716	.3429		.4287	.381	
16	.3086	.5716	.3048		.4287	.2858	
17	.3944				.3772	.2858	.5144
18	.5144	.5716			.4287	.2858	
19	.6001	.7621			.5144	.5716	.5144
20	.6097	.6668		.5716	.6001	.7621	.6859
21		.6668		.5716	.5144	.6668	.6097
22		.5716		.6668	.4287	.5716	.6097
23		.5716		.5716	.4287	.5716	.4572
24	.4763		.4763			.3429	.4763
Max	.8573	.7621	.8573	.6668	.7621	.7621	.7621
Min	.3086	.5716	.3048	.5716	.3429	.2858	.4572
Avg	.4978	.6192	.5481	.5954	.5227	.4628	.5941

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134016 / KUMBHAR PIMPALGAON

Feeder No / Name : 207 / 11KV JAMB- GAOTHAN Gaothan Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716		.5716		.5716	.4287	.5716
2	.5716		.6668		.5716	.4287	.5716
3	.5716		.6668		.6668	.4287	.6668
4	.5716		.7621		.6668	.5144	.6668
5	.8573		.8573		.7621	.5335	.7621
6	.8573		.7621		.8573	.5335	.6668
7	.7621		.6668		.7621	.5335	.6668
8	.5716		.6668		.6668	.5144	.5716
9	.5716		.6668		.5716		.4763
10	.5144		.5716		.4763		.381
11	.4287		.4287		.4287		.3429
12	.3429	.4763	.4287		.3429		.2915
13	.3944	.5144	.3601				.2915
14	.4287	.5716	.3429		.3429		.2915
15	.3429	.5716	.3429		.3429		.2915
16	.4287	.5716	.381		.3429	.4382	.3429
17	.4801	.5335			.3601	.381	.3429
18	.5144	.5716			.4287	.4763	.3429
19	.5335	.6668		.5716	.6001	.5716	.6001
20	.6001	.6668		.5716	.5335	.6668	.5335
21		.5716		.6668	.6001	.5716	.5144
22		.5716		.6668	.5144	.5716	.5144
23		.5716		.5716	.5144	.5716	.4287
24	.4763		.4763		.5716	.4287	.4763
Max	.8573	.6668	.8573	.6668	.8573	.6668	.7621
Min	.3429	.4763	.3429	.5716	.3429	.381	.2915
Avg	.5424	.5716	.5658	.6097	.5433	.5055	.4836

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134016 / KUMBHAR PIMPALGAON

Feeder No / Name : 208 / 11KV MURTY-GAOTHAN Gaothan Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381		.4763		.5716	.4287	.4763
2	.381		.5716		.5716	.4287	.4763
3	.381		.6668		.6668	.4287	.5716
4	.5716		.7621			.5144	.6668
5	.6668		.8573			.6097	.6668
6	.8573		.7621			.6859	.7621
7	.7621		.5716			.6097	.6668
8			.6668				.5716
9					.4763		.4763
10						.381	.381
11	.3429		.4287				.3429
12	.2572		.3429		.4287		.2572
13	.3086		.3258			.381	
14	.2572		.3086			.381	.2058
15	.2572		.3429		.4287	.3429	.2058
16	.2743		.3429		.4382	.381	.2572
17	.3258				.3944	.381	.3429
18	.3429				.4287	.381	
19	.5144	.6859			.4287	.381	
20	.5144	.5716		.5716	.6097	.6668	
21		.5716			.5144	.5716	.3429
22		.4763			.5144	.5716	.3429
23		.4763		.5716	.5144	.5716	.2572
24	.381		.381		.4763	.4287	.381
Max	.8573	.6859	.8573	.5716	.6668	.6859	.7621
Min	.2572	.4763	.3086	.5716	.3944	.3429	.2058
Avg	.4320	.5563	.5205	.5716	.4975	.4763	.4326

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134016 / KUMBHAR PIMPALGAON

Feeder No / Name : 209 / 11KV SINDHKHED-GAOTHAN Gaothan Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716		.5716		.4287	.5716
2	.5716		.5716		.4287	.5716
3	.5716		.6668		.4287	.5716
4	.5716		.6668		.4287	.6668
5	.6668		.8573		.5335	.7621
6	.6668		.7621		.6097	.8573
7	.7621		.7621		.4572	.7621
8	.6668		.6668		.5144	.6668
9	.6859		.5716			.6859
10	.6859		.5716			
11	.3429		.4287			.3429
12	.2743	.381	.4287		.5716	.2572
13	.2572	.381	.3601			.2572
14	.2572	.4763	.3258		.5716	
15	.2572	.4763	.3429		.463	.2572
16	.2915	.5716	.5144		.381	.3429
17	.3601				.381	.3429
18	.5335			.4287	.4763	.5144
19	.6097	.7621		.6001	.5716	.6001
20	.6097	.6668		.6097	.8383	.5335
21	.7621	.6668		.6001	.5716	.5335
22		.5716		.5144	.5716	.5144
23		.5716		.5144	.5716	.4287
24	.5716		.4763		.4287	.4763
Max	.7621	.7621	.8573	.6097	.8383	.8573
Min	.2572	.381	.3258	.4287	.381	.2572
Avg	.5249	.5525	.5615	.5446	.5114	.5235

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134016 / KUMBHAR PIMPALGAON

Feeder No / Name : 210 / 11KV SAMRUDDHI EXPRESS
FEEDER Feeder KV- 11 / OUTGOING

HV Non-Express Feeder

DATE	01-JUN-17	05-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
7			.0191
8			.0191
9			.0381
10			.0191
11	.0191		.0381
14		.1715	.0191
15		.1715	.0191
16		.1715	.0343
17		.1715	.0381
18		.1715	.0381
19			.0381
20			.0381
21			.0381
22			.0381
23			.0381
Max	.0191	.1715	.0381
Min	.0191	.1715	.0191
Avg	.0191	.1715	.0315

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134027 / TIRTHPURI

Feeder No / Name : 201 / RAMASGAON AG Ag dominated/Pure Ag
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6385	.1143	.724			
2	1.6385	.1143	.724			
3	1.6385	.1143	.724			
4	1.7147	.1524	.743			
5		.1524	.7811			
6		.1524	.8383			
7		.2286	.8764			
8		.2286	.9526			
9		.2477	1.0098			
10					.5335	
11					.5335	
12					.6097	
13					.6859	.9145
14					.5906	.8192
15					.6097	.6097
16				.5144	.5906	.6478
17				.4763	.6478	.7049
24	2.1338	.1524	.7621			
Max	2.1338	.2477	1.0098	.5144	.6859	.9145
Min	1.6385	.1143	.724	.4763	.5335	.6097
Avg	1.7528	.1657	.8135	.4954	.6002	.7392

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134027 / TIRTHPURI

Feeder No / Name : 202 / 11KV KANDARI AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	03-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1338	1.7147			
2	2.1338	1.7147			
3	2.2481	1.7147			
4	2.2862	1.7528			
5	2.3243	1.8861			
6	2.4006	2.0005			
7	2.4387	2.1719			
8	2.553	2.2481			
9	2.7054	2.3053			
10			.5335		
11			.5906		
12			.8192		
13			.8954		
14			.9717		
15			.9907		.6668
16			1.0098	1.6575	1.6194
17			.9907		1.7909
24	1.829	1.7147			
Max	2.7054	2.3053	1.0098	1.6575	1.7909
Min	1.829	1.7147	.5335	1.6575	.6668
Avg	2.3053	1.9224	.8502	1.6575	1.3590

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134027 / TIRTHPURI

Feeder No / Name : 203 / BHAIGAVHAN-AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134027 / TIRTHPURI

Feeder No / Name : 204 / 11KV Industrial FDR BALAJI HV Non-Express Feeder
OIL Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0572	.0953		.0953	.0572	.0762
2	.0572	.0381	.1143		.0953	.0762	.0762
3	.0572	.0381	.0953		.0953	.0953	.0953
4	.0762	.0572	.0762		.1143	.0953	.1143
5	.0953	.0381	.0953		.0953	.0762	.0953
6	.0953	.0572	.1143		.0953	.0572	
7	.1143	.1143	.0953		.0953	.0762	
8	.1143	.0381	.0953		.1143	.0572	
9	.1524	.0953	.0953		.0953	.0762	
10	.1334	.0572	.1524		.0762	.2096	
11	.1524	.1334	.1334		.0762	.1524	
12	.1334	.1143	.1143		.0572	.1143	
13	.1524	.1715	.1334		.2477	.1143	.0572
14	.1143	.1905	.1524		.2096	.2286	.0953
15	.0953	.1905	.1524		.2858	.1524	.2096
16	.0953	.1905	.3429		.3048	.2858	.2667
17	.1334	.2096	.362	.0762	.2286	.1905	.2477
18	.1143	.2477		.0762	.2286	.2096	.1905
19	.0762	.1143		.0953	.1905	.1905	.1334
20	.0572	.0762		.1524	.0953	.1715	.1143
21	.0762	.0762		.1143	.1143	.0762	.0953
22	.0953	.0953		.0953	.0953	.0762	.0762
23	.0572	.0762		.1143	.0572	.0572	.0762
24	.0572	.0762	.0762		.1334	.0762	.0762
Max	.1524	.2477	.362	.1524	.3048	.2858	.2667
Min	.0572	.0381	.0762	.0762	.0572	.0572	.0572
Avg	.1000	.1064	.1387	.1034	.1374	.1238	.1233

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134027 / TIRTHPURI

Feeder No / Name : 205 / Kandhari GTN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134027 / TIRTHPURI

Feeder No / Name : 206 / BHAIGAVHAN-GAOTHAN
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	01-JUN-17
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134027 / TIRTHPURI

Feeder No / Name : 207 / 11KV Tirthpuri Gaothan FDR Gaothan Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.8383	.7049		.724	.7621	.6859
2	.7049	.8192	.724		.7621	.7811	.6859
3	.7049	.8383	.8002		.8192	.8192	.724
4	.7621	.8383	.9145		.8573	.9335	.9145
5	1.0288	.8383	1.0288		.9907	1.105	1.0288
6	1.1812	1.105	1.2384		1.2955	1.2384	
7	1.1431	1.2384	1.2765		1.2955	1.3336	
8	1.2574	1.1431	1.0098		.9202	1.1812	
9	1.1431	1.0669	.9335		1.105	1.086	
10	1.086		.8764		1.0288	.9335	
11	.9907	1.086	.8383		.8954	.7621	
12	.9335	.8192	.8192		.7811	.6859	
13	.8573	.9335	.8192		.7811	.6287	.8573
14	.8002	.8764	.8573		.7621		.8764
15	.8002	.8383	.8383		.724		.9145
16	.8954	.8573	.8764		.743	.8383	.8954
17	.9335	.9145	.9526	1.0669	.8192	.8764	.9145
18	1.1241	1.1241		1.105	.9717	1.0288	1.105
19	1.1431	1.2955		1.2955	1.086	1.3146	1.3527
20	1.0288	1.0288		1.3527	1.1812	1.2193	1.2193
21	.9145	.9717		1.1812	1.0669	1.0288	.9907
22	.8573	.8764	.8954	.9145	.8192	.8002	.8383
23	.8192	.7621	.8002	.7621	.7811	.7621	.8002
24	1.2193	.8002	.6859		.724	.743	.7811
Max	1.2574	1.2955	1.2765	1.3527	1.2955	1.3336	1.3527
Min	.7049	.7621	.6859	.7621	.724	.6287	.6859
Avg	.9605	.9526	.8945	1.0968	.9139	.9483	.9167

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134056 / DEODI HADGAON

Feeder No / Name : 201 / 11KV Deodi Hadgaon SP FDR Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3506	.3239	.4024	.3887	.4287	.3429	.4801
2	.3506	.3239	.4024	.3563	.4287	.3772	.5144
3	.3856	.2915	.9779	.2915	.5144	.4115	.6001
4	.4207	.3239	1.0608	.3887	.5144	.4287	.6001
5	.4908	.3239	.4641	.4858	.6859	.5144	
6	.5487	.4115	.4973	.3887	.6859	.823	.6516
7	.5258	.421	.5182	.5182	.7202	.8573	.6859
8	.4908	.421	.4858	.5182	.6859	.8573	.6859
9	.4298	.3563	.4858	.4858	.4801	.8916	.4801
10	.7362	.6478	.6478	.4049	.5144	.3772	.4287
11	1.0517	.583	.7125	.6001	.5144	.3429	
12	.8764	.8097	.7449	.6173	.5144	.3086	.4115
13	.8745	.7449	.7125	.6173	.5144	.3086	.3086
14	.583	.6802	.6802	.6001	.5144	.2915	.2572
15	.6802	.6478	.6802	.6001	.4115	.3086	.2572
16	.7773	.583	.7449	.6001	.4115	.3086	.2743
17	.7449	.3887		.6344	.4115	.3429	.3086
18	.4858	.4534		.3772	.4801	.4115	.3258
19	.5668	.421	.4858	.4287	.5144	.4287	.4287
20	.4858	.4696	.3725	.4287	.5144	.4458	.4287
21	.502	.5487	.3887	.4287	.5144	.4287	.5144
22	.4534	.4858	.421	.4287	.5144	.4287	.4801
23	.3887	.3887	.463	.4287	.4801	.4287	.4801
24		.3563	.3887	.3887	.4115	.3429	.4801
Max	1.0517	.8097	1.0608	.6344	.7202	.8916	.6859
Min	.3506	.2915	.3725	.2915	.4115	.2915	.2572
Avg	.5739	.4752	.5790	.4752	.5158	.4587	.4583

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134056 / DEODI HADGAON

Feeder No / Name : 202 / 11KV Dhakefal SP FDR
Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5258	.4801	.4801		.4287	.5144	.3429
2	.5609	.5144	.5487		.4287	.5144	.3429
3	.5959	.5144	.583		.4287	.5487	.3429
4		.5144	.583		.4287	.5487	.3772
5		.5144	.6299		.4287	.5487	
6		.6001	1.1469		.4287	.6001	.3429
7		.7545	1.2003		.5144	.6516	.3429
8	.9465	.8573	.9374		.5144	.6859	.3086
9	.9114	.7202	.8916		.4801	.6859	.3772
10	.4207	.2401	.4115		.4801	.6516	.4115
11	.4207	.4115	.5144	.3429	.4801	.6859	
12	.3155	.3429	.5144	.3429	.4801	.6859	.4287
13	.2915	.3429	.6173	.3429	.4801	.7202	.3086
14	.4801	.3429	.583	.4287	.4801	.7202	.3086
15	.5144	.3429	.6173	.4287	.5144	.6859	.2572
16	.2058	.5144	.6001	.4287		1.4746	.2572
17	.5144	.6173		.4115	.6001	.6173	.3086
18	.6001	.6859		.3772	.5144	.5487	.3086
19	.6516	.7888		.4115	.5487	.5144	.3429
20	.6516	.6859		.4287	.5487	.5144	.4287
21	.6516	.6173		.4287	.5487	.5144	.4287
22		.5487			.5144	.5144	.4287
23	.5487	.5144		.4287	.5144	.5144	.4287
24		.5144	.4207	.2058	.4287	.5144	.3429
Max	.9465	.8573	1.2003	.4287	.6001	1.4746	.4287
Min	.2058	.2401	.4115	.2058	.4287	.5144	.2572
Avg	.5448	.5408	.6635	.3851	.4876	.6323	.3531

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134056 / DEODI HADGAON

Feeder No / Name : 203 / 11KV Avalgaon AG FDR
Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.3086	.3086	.1715
2					.3086	.3086	.2058
3					.3429	.3086	.2058
4					.3429	.3429	.2058
5					.3429	.3429	
6					.4115	.3429	
7					.4801	.4801	
8					.5316	.5144	
9					.5144	.583	
10	.4908		.5001	.2286			
11	.6661		.5716	.4115			
12	.6661	.3429	.5716	.5144			
13	.5144	.5921	.5216	.3429			
14	.4287	.5144	.5144	.3429			
15	.4287	.4512	.4793	.3429			
16	.4715	.4793	.5001	.3429			
17	.5357	.5639		.3429			
24					.1715	.12	.1715
Max	.6661	.5921	.5716	.5144	.5316	.583	.2058
Min	.4287	.3429	.4793	.2286	.1715	.12	.1715
Avg	.5253	.4906	.5227	.3586	.3755	.3652	.1921

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134066 / SADEGAON

Feeder No / Name : 201 / 11 KV SADEGAON AG FDR

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.166		1.1488			
2	1.2346		1.2003			
3	1.2689		1.2689			
4	1.3375		1.3032			
5	1.406		1.3375			
6	1.4403	1.3375	1.3717			
7	1.3108	1.4232	1.3717			
8	1.4575	1.406				
9	1.2498		1.3375			
10						.4001
11						.4763
12						.6287
13				.0514	.7621	.6287
14				.0514	.8573	.5716
15				.0686	.9526	
16				.0686	.7716	
17				.0514	.7716	
24	1.0974		1.1317	.1524		
Max	1.4575	1.4232	1.3717	.1524	.9526	.6287
Min	1.0974	1.3375	1.1317	.0514	.7621	.4001
Avg	1.2969	1.3889	1.2746	.0740	.8230	.5411

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134066 / SADEGAON

Feeder No / Name : 202 / 11KV Sadegaon Gaothan

Gaothan Feeder

FEEDER Feeder KV- 11 /
OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772		.3944			.4458	.4382
2	.3772		.4115		.3048	.4801	.4763
3	.4458		.4801		.3239	.4801	
4	.4973		.5487		.362	.5487	.5716
5	.6173		.6687		.4001	.6516	.6287
6	.823		.7545		.4954	.6344	.6668
7	.6401		.6859		.5335	.6173	.6668
8	.5792				.362	.5316	.5716
9	.4115				.2915	.4287	.381
10	.3353						.3048
11	.3601						.1886
12	.3086						.2667
13	.2915				.1543	.2858	.2858
14	.2401					.2858	.2858
15	.2401					.2858	
16			.4287		.4458	.2572	
17	.3429		.4287		.5487	.2572	
18	.5316			.3429		.3429	
19	.6173	.5658		.3772		.4115	
20	.7202	.5144					
21	.583	.4801		.463			
22		.4115			.4115		
23		.3772			.4458		
24	.4115		.3944		.3048	.4287	.381
Max	.823	.5658	.7545	.463	.5487	.6516	.6668
Min	.2401	.3772	.3944	.3429	.1543	.2572	.1886
Avg	.4643	.4698	.5196	.3944	.3846	.4337	.4367

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134066 / SADEGAON

Feeder No / Name : 203 / 11KV Gangachincholi AG Ag dominated/Pure Ag

FEEDER Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.5487	.9145
2				.583	.9145
3				.6173	.7621
4				.6516	.7621
5				.7202	.7811
6				.703	.9145
7				.4287	
8				.4973	
9				.5316	
10	1.5242	1.4403	1.5261		
11	1.7833	1.6461	1.5432		
12	1.8176	1.6632	1.5775		
13	1.8004	1.5775	1.6289		
14	1.7661	1.5947	1.6289		
15	1.7833	1.6118	1.6289		
16		1.5775	1.6289		
17	1.7147		1.5432		
24				.4973	.9145
Max	1.8176	1.6632	1.6289	.7202	.9145
Min	1.5242	1.4403	1.5261	.4287	.7621
Avg	1.7414	1.5873	1.5882	.5779	.8519

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134068 / 33KV S/S SINDKHED

Feeder No / Name : 201 / Limboni Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2					.1905
3					.1715
4					.1524
5					.1524
8					.1905
10	.8907		.7287		.2667
11	.9717		.8097		.2486
12	1.0526		.8097		
13		.3239	.9526		
14	.7287	.4049	.9526	.1905	
15	.7287	.4049	.9526	.2667	
16	.8097	.4049	.9526		
17	.4858	.4049	.8573		
Max	1.0526	.4049	.9526	.2667	.2667
Min	.4858	.3239	.7287	.1905	.1524
Avg	.8097	.3887	.8770	.2286	.1961

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134068 / 33KV S/S SINDKHED

Feeder No / Name : 202 / Sindkhed Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4858					
2	.4858					
3	.5668					
4	.6478					
5	.7287					
6	.8097					
7	.8907					
8	.9717					
9	1.0526					
10				.2286	.2286	.1524
11		.9717		.2286	.3048	.2486
12				.2286	.3429	.2486
13				.2286	.381	.2486
14				.2286	.1715	
15				.2286	.1905	
16					.2286	.4973
17					.2667	.4973
20			.1143			
24	.4858					
Max	1.0526	.9717	.1143	.2286	.381	.4973
Min	.4858	.9717	.1143	.2286	.1715	.1524
Avg	.7125	.9717	.1143	.2286	.2643	.3155

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134069 / 33 kv Banegaon

Feeder No / Name : 201 / 11 kv Banegaon Ag
Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	01-JUN-17	02-JUN-17	03-JUN-17	05-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2125		1.1469	
2	1.2125		1.1469	
3	1.4091		1.1797	
4	1.4582		1.2597	
5	1.6057		1.2929	
6	1.7695		1.3923	
7	1.8023	1.643	1.4091	
8	1.8351	1.8233	1.5402	
9	1.8023	1.6575	1.4746	
13				1.1469
14				1.2929
15				1.3413
16				1.3757
24	1.2125		1.1271	
Max	1.8351	1.8233	1.5402	1.3757
Min	1.2125	1.643	1.1271	1.1469
Avg	1.5320	1.7079	1.2969	1.2892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134069 / 33 kv Banegaon

Feeder No / Name : 202 / 11 kv Bhogaon Ag

Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	01-JUN-17	02-JUN-17
HR	Load (MW)	Load (MW)
10	1.3108	1.1797
11	1.4419	1.2597
12	1.4586	1.2929
13	1.4586	1.326
14	1.4419	1.326
15	1.4091	1.2929
16	1.4091	1.2929
17	1.3763	1.2266
Max	1.4586	1.326
Min	1.3108	1.1797
Avg	1.4133	1.2746

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134069 / 33 kv Banegaon

Feeder No / Name : 203 / 11 kv banegaon Gaonthan Gaonthan Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2294		.1658		.2058	.1658
2	.2294		.1658		.1886	.1658
3	.2622		.1658		.1715	.1658
4	.2949		.1658			.1492
5	.3441		.2321		.1715	.2683
6	.3932		.2984		.3429	.3315
7	.3932	.3978	.2652		.3772	.4144
8	.3605	.3647	.3441		.3258	
9	.3277	.3978	.3277			
10	.2622	.2652			.1658	
11	.1638	.2321	.2321		.1658	
12	.1658	.1989	.1989			
13	.1658	.1658	.1658		.1475	
14	.1638	.1492	.1638			
15	.1638	.1492	.1658		.1677	
16	.1802	.1326	.1326	.2321		
17	.213	.1989	.1326	.2486	.2486	
18	.3277			.2652	.2652	
19	.4024	.3018		.3429	.3481	
20	.3315	.2652		.3601	.3018	
21	.2652	.2321		.2743	.2683	
22	.1989	.1989		.2401	.2347	
23		.1989			.2012	
24	.2294		.1658		.2058	.1677
Max	.4024	.3978	.3441	.3601	.3772	.4144
Min	.1638	.1326	.1326	.2321	.1475	.1492
Avg	.2638	.2406	.2052	.2805	.2370	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134073 / 33kv SHIVANGAON S/S

Feeder No / Name : 201 / 11KV Shivangaon AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
23	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134073 / 33kv SHIVANGAON S/S

Feeder No / Name : 202 / 11KV SPARE(Gunj) AG

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	1.829
Max	1.829
Min	1.829
Avg	1.829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134085 / ANTERWALI TEMBHI

Feeder No / Name : 201 / 11KV ANTARWALI -T AG FDR Ag dominated/Pure Ag
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	06-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242		1.3336	
2	1.4861		1.3717	
3	1.4098		1.3527	
4	1.2955		1.3717	
5	1.4861		1.3146	
6	1.5242		1.2574	
7	1.6766		1.4098	
8	1.7147		1.467	
9	1.6194	.381	1.5813	
11				.5144
14				.9431
15				.9431
16				1.1145
17				1.286
24	1.448		1.3336	
Max	1.7147	.381	1.5813	1.286
Min	1.2955	.381	1.2574	.5144
Avg	1.5185	.381	1.3793	.9602

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134085 / ANTERWALI TEMBHI

Feeder No / Name : 202 / 11KV MANGRUL AG FDR Ag dominated/Pure Ag
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.7362		.6859
2				.7362	.7202	.2058
3				.7011	.7373	.823
4				.7011	.7716	.7716
5				.7888	.823	.8573
6				.8573		
7				.8916	.7373	
8				.9259	.8573	
9				.9602	.8573	
10	1.2574					
11	1.4289		1.2384			
12	1.4861	1.1812	1.1145			
13	1.5432	1.4098	1.2003			
14	1.5242	1.3336	1.0288			
15	1.5432	1.2574	1.0974			
16	1.5242	1.2955	1.0288			
17	1.5623	1.3336				
24				.8238		
Max	1.5623	1.4098	1.2384	.9602	.8573	.8573
Min	1.2574	1.1812	1.0288	.7011	.7202	.2058
Avg	1.4837	1.3019	1.1180	.8122	.7863	.6687

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134085 / ANTERWALI TEMBHI

Feeder No / Name : 204 / 11KV EXPRESS FDR MANGRUL HV Non-Express Feeder
BARRA Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191		.0191		.0171
2	.0191		.0191		
3	.0191		.0191		
4	.0191		.0191		
5	.0191		.0191		
6	.0191		.0191		
7	.0191		.0191		
8	.0191		.0191		
9	.0191	.0191	.0191		
10	.0191	.0191	.0191		
11	.0191		.0191		
12	.0191	.0191	.0171		
13	.0191	.0191	.0171		
14	.0191	.0191	.0171		
15	.0191	.0191	.0171		.0171
16	.0191	.0191	.0171	.0171	.0171
17	.0191	.0191		.0171	.0171
18	.0191	.0191		.0171	.0171
19	.0191	.0191		.0171	
20	.0191	.0191		.0171	
21	.0191	.0191		.0171	
22		.0191			
23		.0191		.0171	.0171
24	.0191		.0191		.0171
Max	.0191	.0191	.0191	.0171	.0171
Min	.0191	.0191	.0171	.0171	.0171
Avg	.0191	.0191	.0185	.0171	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134085 / ANTERWALI TEMBHI

Feeder No / Name : 205 / 11KV Antarwali-T Gaothan Gaothan Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002		.7621		.6661		.6516
2	.7621		.7621		.6661		.6859
3	.7621		.8383		.5959	.6173	
4	.9145		.9145		.5609	.6859	.7716
5	1.2955		1.2574		.5258	.8573	.8573
6	1.3717		1.3336		.8573	1.1145	
7	1.3336		1.2193		1.1317	1.1831	
8	1.1812		1.2955		1.0631	1.2003	
9	.0191	.5525	1.0288		.9259		
10	.743	.743	.7049		.6859		
11	.7621	.8383	.5906				
12	.6859	.724			.5083	.6344	
13	.6859	.6859	.583				
14	.6287	.6478	.583		.5658	.6344	.6516
15	.6668	.6668	.583		.583	.6344	
16	.724	.7049	.6173			.6687	.6859
17	.8383	.8573				.7373	.7888
18	1.0479	1.0669			.823	.823	.9259
19	1.2765	1.1622		.5487		1.166	1.1831
20	1.2955	1.1241		1.166	1.3203	1.2003	1.1831
21	.9717	.8954		.9114		.8573	1.2003
22		.7621		.8063		.7545	1.0288
23		.7621		.7362		.6516	.6859
24	.9145		.743		.631		.6859
Max	1.3717	1.1622	1.3336	1.166	1.3203	1.2003	1.2003
Min	.0191	.5525	.583	.5487	.5083	.6173	.6516
Avg	.8946	.8129	.8635	.8337	.7569	.8483	.8561

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134085 / ANTERWALI TEMBHI

Feeder No / Name : 206 / 11KV Mangrul Gaothan Gaothan Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477		.1905		.2454		.2229
2	.2286		.2096		.2103		.2058
3	.2286		.2096		.2103		.1886
4	.2858		.2667		.2279	.3086	
5	.381		.3429		.2454	.3429	.2401
6	.4572		.381		.3086	.3429	
7	.4191		.3048		.3429	.3601	
8			.2477		.3429	.3086	
9		.2477	.1905		.3429	.2401	
10	.2477	.2096			.2401	.1886	
11	.2286		.1905		.1886	.1886	
12	.1905	.1715	.1715		.2103	.1715	
13	.2096	.2096	.1715		.1928		
14	.1905	.1905	.1715		.1715		.2058
15	.1905	.0191	.1715		.1886		
16	.1905	.2096	.1715				.2229
17	.2286	.2286				.2058	.5144
18	.2858				.2572	.2229	.2401
19	.4572	.2667	.2401	.3772	.3258	.3601	.3429
20	.3239	.3048		.3772	.4115	.3086	.3258
21	.2858	.2667		.3155		.2915	.2743
22		.2477		.2454		.2058	.2229
23		.2286		.2454		.2058	
24	.2667		.2096		.2454		.1886
Max	.4572	.3048	.381	.3772	.4115	.3601	.5144
Min	.1905	.0191	.1715	.2454	.1715	.1715	.1886
Avg	.2772	.2154	.2259	.3121	.2583	.2658	.2612

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134086 / 33 KV RANJANI SUB STATION

Feeder No / Name : 201 / 11 KV RANJANI GAOTHAN Gaothan Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.583	.703	.4287	.823	.5144	.6516	.6859
2	.6173	.7202	.5316	.7716	.5144	.6687	.6859
3	.6173	.6859	.583	.7888	.583	.6516	.7888
4	.6516	.7545	.6516	.7545	.6173	.6516	.823
5	.703	.7716	.703	.7716	.7202	.6173	.823
6	.7545	.7888	.7716	.8402	.823	.823	.8745
7	.823	.823	.823	.8916	.8573	.9431	.8916
8	.8745	.8745	.9774	.9431	1.0288	.8916	.8573
9	1.0974	.7202	.9945	.7373	.9945	.7202	
10	.7545	.7373	.6344	.7716	.6173	.583	.5487
11	.6859		.5487		.5316	.583	.5144
12	.6859	.6516			.4973	.5658	.5487
13		.6516	.6516	.6859	.5487		
14	.6516	.5316		.6516	.5144	.4287	.4458
15	.6173	.6516	.7888	.6173	.4973		.4801
16		.6859	.823	.6859	.7888	.6344	.4973
17		.8402	.8745	.6859	.8916	.703	.6173
18	.8059	.8059	.9259	.7888	.9259	1.0288	.6859
19	.8573	.7716	.9431	.8916	.9431	1.0288	.7202
20	.823	.6516	.8916	.8573	.8745	.7716	.703
21	.8059	.583	.8573	.6687	.7202	.823	.5658
22	.7888	.5144	.823	.583	.6687	.8573	.583
23	.6687	.5144	.8402	.5487	.6516	.6859	.6001
24	.583	.6687	.4287	.8402	.5144	.6859	.6001
Max	1.0974	.8745	.9945	.9431	1.0288	1.0288	.8916
Min	.583	.5144	.4287	.5487	.4973	.4287	.4458
Avg	.7357	.7000	.7498	.7545	.7016	.7272	.6609

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134086 / 33 KV RANJANI SUB STATION

Feeder No / Name : 202 / 11 KV RANJANI AG FDR AG Feeder with SDT
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.0514	.0114	.0514	.0514			
3	.0686	.0857	.0857	.0076			
4	.0686	.0857	.0857	.1029			
5	.0857	.12	.0857	.12			
6	.0857	.1029	.1029	.0857			
7	.1029	.12	.1372	.0857			
8	.1715	.1543	.1543	.0857			
9	.1543	.1543	.1372	.1029			
10					.12	.1029	.0514
11	.0017				.1543		.1029
12					.1886	.12	.12
13					.1715	.1543	.12
14					.1543	.1715	.1029
15					.1372	.1372	.1029
16					.1543	.1886	.0857
17					.1372	.1543	.1029
Max	.1715	.1543	.1543	.12	.1886	.1886	.12
Min	.0017	.0114	.0514	.0076	.12	.1029	.0514
Avg	.0878	.1043	.1050	.0802	.1522	.1470	.0986

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134086 / 33 KV RANJANI SUB STATION

Feeder No / Name : 203 / 11 KV KRISHNAPUR AG Ag dominated/Pure Ag
 FEEDER Feeder KV- 11 /
 OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2					.1219	.3086	.1219
3					.1524	.3429	.1372
4					.1524		
5					.1829	.3772	.1829
6					.2743	.3601	.1829
7					.381	.3086	.1829
8					.3963	.4287	.2591
9						.4115	.2134
10	.4572		.3353	.2401			
11	.0743	.4268	.442	.3201			
12	.6516	.3353	.5487	.3201			
13	.5487	.2743	.583	.3353			
14	.5487	.3963	.4458	.3048			
15	.4973	.442	.4458	.3048			
16	.5487		.3086	.2896			
17	.6344	.3353	.3601				
Max	.6516	.442	.583	.3353	.3963	.4287	.2591
Min	.0743	.2743	.3086	.2401	.1219	.3086	.1219
Avg	.4951	.3683	.4337	.3021	.2373	.3625	.1829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134086 / 33 KV RANJANI SUB STATION

Feeder No / Name : 204 / 11 KV CHITRAWADGAON AG. Ag dominated/Pure Ag
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1524	.6001	.1677				
3	.1524	.6173	.1829				
4	.1677	.6516	.2743				
5	.2591	.6687	.3353				
6	.3506	.6173	.3963				
7	.5182	.6516	.4268				
8		.6687	.503	.5487			
9	.4268	.5316	.4877	.5487			
10					.4973	.463	.3086
11					.5316	.5792	.3601
12					.5658	.4877	.3772
13					.5487	.4877	.4115
14					.4973	.4268	.463
15					.4287		.4973
16					.463	.3658	.5144
17						.3658	.4572
Max	.5182	.6687	.503	.5487	.5658	.5792	.5144
Min	.1524	.5316	.1677	.5487	.4287	.3658	.3086
Avg	.2896	.6259	.3468	.5487	.5046	.4537	.4237

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134086 / 33 KV RANJANI SUB STATION

Feeder No / Name : 205 / 11 KV EXPRESS FEEDER SHEDDABLE FEEDER HAVING WEEKLY
 Ranjani Feeder KV- 11 / STAGGERING (MIDC, EQUIVALENT)
 OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.0191	.0229				
10	.0191	.0023			.0191	
11		.021			.0002	.021
12	.0019	.0343				.0152
13	.0019	.0305				
14	.0017		.0171	.0191		
15	.0019			.0191		
16	.0002			.0191		
17	.0027			.0191		
18	.0027			.0152		
19	.0021			.0152		
20	.0002			.021		
21				.0191		
22				.0191		.0152
Max	.0191	.0343	.0171	.021	.0191	.021
Min	.0002	.0023	.0171	.0152	.0002	.0152
Avg	.0049	.0222	.0171	.0184	.0097	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134086 / 33 KV RANJANI SUB STATION

Feeder No / Name : 206 / PARADGAON GFS.

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12		.0857			
2	.12		.0857			
3	.1543		.0857			
4	.1543		.0857			
5	.1715		.1029			
6	.2058		.1029			
7	.2058		.1372			
8	.1886		.0857			
9	.0857		.0686			
10	.1029		.0514		.12	
11	.0857		.0514		.0686	
12	.1029				.0857	
13	.0857		.0514		.0857	
14	.0095		.0514		.12	
15	.0686		.0514		.0762	
16	.12		.0857		.0762	
17	.1029	.0514	.0857			.0686
18	.0095	.1029				.0857
19	.12	.12		.0171		.1029
20	.1524	.12				.1029
21	.12	.1372				.0857
22	.0095	.1029				.0857
23	.1029	.0857				.0857
24	.1029		.0857			
Max	.2058	.1372	.1372	.0171	.12	.1029
Min	.0095	.0514	.0514	.0171	.0686	.0686
Avg	.1126	.1029	.0797	.0171	.0903	.0882

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION

Feeder No / Name : 201 / 11KV BORGAON GAOTHAN Gaothan Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1319	.1888	.1886	.1884	.1696	.2075	.188
2	.1319	.1888	.1886	.1884	.1696	.2075	.188
3	.1319	.1888	.1886	.1884	.1696	.2075	.188
4	.1322	.2266	.2263	.1884	.1884	.2263	.2068
5	.189	.2643	.2641	.2638	.3012	.2641	.2633
6	.2268	.2832	.3584	.2826	.4145	.4715	.4889
7	.2462	.2643	.2829	.2826		.415	.4518
8	.227	.2077	.3584	.245	.3012	.3584	.3576
9	.2079		.2829	.245	.2824	.2829	.3388
10	.1507	.1133	.1698	.2261	.1694	.2075	.2447
11	.1131		.1507	.1884	.1694	.1696	.1698
12			.1696		.1132	.1507	.1509
13	.1319		.1319			.1504	.132
14	.0942		.1319			.1316	.1132
15	.1131		.1507	.1506		.1316	.1129
16	.1131	.1888	.1506			.1316	.1129
17	.151	.1699	.1506	.2073	.1698		.1694
18	.1699	.2266	.2073	.2073	.2075		.1882
19	.2286	.321	.2261	.3012	.3395	.3009	.3388
20	.2266		.245	.3203	.3048	.3949	.2824
21	.2266	.2832	.245	.3009	.2452	.3392	.2824
22	.1888	.2077	.1884	.2068	.2263	.2261	.2259
23	.1888	.1699	.2073	.2071	.2075	.2068	.2071
24	.1318	.1888	.1888	.1884	.1694	.2075	.188
Max	.2462	.321	.3584	.3203	.4145	.4715	.4889
Min	.0942	.1133	.1319	.1506	.1132	.1316	.1129
Avg	.1675	.2166	.2105	.2289	.2273	.2450	.2329

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION

Feeder No / Name : 202 / 11 KV KANDARI GAOTHAN Gaothan Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3239	.3048	.1143	.1143	.1143	.1143
2	.3048	.3239	.3048	.1143	.1143	.1143	.1143
3	.3048	.3239	.3048	.1143	.1143	.1334	.1143
4	.3048	.381	.3429	.0953	.1143	.1334	.1143
5	.3239	.4382	.4001		.1334	.1524	.1334
6	.3239	.3048	.3429				.1334
7	.2858	.2667	.3048				
8	.2477	.2286	.2667		.1143		
9	.381				.0953		
10	.2858	.2477	.2858		.1143	.1334	.0762
11	.2858	.2667	.2477		.1143		.0953
12	.2477	.2477	.2477		.0953	.1143	.0953
13	.2286	.2477	.2286		.1143	.0953	.0953
14	.2667		.2286		.1143	.0953	.0953
15	.2667		.2667		.1143	.1143	.0953
16	.2858		.1905		.1143	.1143	.0953
17	.3239	.3239			.1334	.1143	.1143
18	.2286	.2477			.1143	.0953	.0953
19		.3048				.1143	
20	.4191	.3429		.1143	.1143		.0953
21	.4001	.4001		.1524	.0762	.1334	.0953
22	.362	.362		.1715	.1143	.1334	.1334
23	.3429	.3239	.1143	.1524	.1334	.1334	
24	.3048	.3239	.3048	.1143	.1143	.1143	.1334
Max	.4191	.4382	.4001	.1715	.1334	.1524	.1334
Min	.2286	.2286	.1143	.0953	.0762	.0953	.0762
Avg	.3057	.3115	.2757	.1270	.1134	.1196	.1073

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION

Feeder No / Name : 203 / 11 KV BORGAON AG AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.109	.0778	.0623	.0778	.0623	.0467	.0623
2	.109	.0778	.0623	.0778	.0623	.0467	.0467
3	.109	.0934	.0623	.0778	.0623	.0467	.0467
4	.1245	.0934	.0623	.0778			
5	.1401	.109	.1245	.0934			
6	.2024	.249	.1868	.0934			
7	.1868	.3424	.2957	.0934			
8	.2024	.3891	.2179	.109			
9	.2802		.1712				
10					.2179	.1712	.1245
11					.2335	.249	.2335
12					.3113	.249	.249
13					.2802	.249	.249
14					.249	.2335	.249
15				.0311	.1868	.2335	.249
16	.0311	.0311	.0467		.1245	.249	.1557
17	.0623	.0623	.0467	.0623	.249	.2006	.2957
18	.0778	.0311	.0467	.0467	.0467	.0623	.0623
19		.0467	.0623	.0623	.0778	.0623	.0623
20	.0467		.0623	.0778	.0778	.0778	.0467
21	.0467	.0623	.0623	.0623	.0572	.0623	.0467
22	.0467	.0623	.0623	.0623	.0467	.0623	.0467
23	.0467	.0623	.0467	.0645	.0467	.0623	.0467
24	.109	.0778	.0623	.0778	.0623	.0467	.0623
Max	.2802	.3891	.2957	.109	.3113	.249	.2957
Min	.0311	.0311	.0467	.0311	.0467	.0467	.0467
Avg	.1136	.1167	.0969	.0734	.1364	.1339	.1297

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION

Feeder No / Name : 204 / 11 KV KANDARI AG AG Feeder with SDT
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.1296	.1334
2					.1265	.1334
3					.1235	.3086
4					.1505	.1509
5					.176	.1646
6					.2372	.2679
7					.2035	.2606
8					.2713	.2606
9					.2012	.1692
10	.3525	.3704	.3429			
11	.5144	.4527	.3041			
12		.3549	.3081			
13	.3199	.2724	.2896			
14	.2681	.2601	.2751			
15	.3111	.2515	.2896	.1593		
16	.3812	.2673				
17	.4075	.2324		.1646		
24	1.3717				.1326	.1257
Max	1.3717	.4527	.3429	.1646	.2713	.3086
Min	.2681	.2324	.2751	.1593	.1235	.1257
Avg	.4908	.3077	.3016	.1620	.1752	.1975

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION

Feeder No / Name : 205 / 11 KV PANGRA AG Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.112	.064	.064			
2	.112	.112	.064	.0762			
3	.112	.112	.064	.064			
4	.16	.112	.064	.064			
5	.192	.1334	.064				
6	.2561	.2401	.176				
7	.4001	.2881	.2561	.064			
8	.3201	.144	.2401				
9	.3041		.2401	.112			
10					.2241	.192	
11					.2561		.2241
12					.3521		.192
13					.4001	.2241	.176
14					.3201	.192	.16
15					.2401	.208	.16
16					.192	.208	.16
17			.128		.192	.192	.176
19				.128			
24	.9145	.128	.064				.096
Max	.9145	.2881	.2561	.128	.4001	.2241	.2241
Min	.112	.112	.064	.064	.192	.192	.096
Avg	.2883	.1535	.1295	.0817	.2721	.2027	.1680

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION

Feeder No / Name : 206 / 11 KV Maherjawla gothan Gaathan Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.2096	.1905	.1524	.2096	.2858	.1905
2	.2096	.2096	.1905	.1524	.2096	.3048	.1905
3	.2096	.2096	.1905	.1524	.2096	.3239	.1905
4	.2286	.2667	.4191	.1524	.2286	.3429	.2286
5	.2667	.3239	.2858	.1715	.3048	.381	.3048
6	.381	.4572	.4763	.3239	.5144	.4191	.4763
7	.4763	.4954	.3239	.4382		.5335	.4763
8	.4572	.381	.3239	.4191	.4954	.4572	.4763
9	.2858	.2667	.3048	.381	.3048	.3429	.3239
10	.2096	.2096	.1905	.2096	.1715	.2096	.2667
11	.1524	.1524	.1715	.1715	.1715	.1524	.1715
12	.1524	.1524	.1715	.1715	.1524	.1524	.1143
13	.1524	.1715	.1524	.1524	.1524	.1524	
14	.1715	.1715	.1524	.1524	.1524	.1524	
15	.1524	.1715	.1715	.1905	.1524	.1715	.1524
16	.1905	.1905	.1715		.1905	.1715	.1524
17	.3048	.3048	.1715	.2667	.2477	.2286	.2096
18	.4001	.4001	.4382	.362	.381	.3048	.362
19	.381	.4001	.4382	.4382	.4763	.3429	.3429
20	.3048	.3239	.2286	.362	.3429	.3429	.3429
21	.2667	.2477		.3048	.3239	.2667	.2858
22	.2286	.2286	.1715	.2477	.3048	.2286	.2477
23	.2286	.2286	.1524	.2477	.2667	.2096	.2286
24	.2096	.2096	.1905	.1524	.2096	.3048	.1905
Max	.4763	.4954	.4763	.4382	.5144	.5335	.4763
Min	.1524	.1524	.1524	.1524	.1524	.1524	.1143
Avg	.2596	.2659	.2468	.2510	.2684	.2826	.2693

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION

Feeder No / Name : 207 / 11 KV MASHEGAON AG FEEDER Ag dominated/Pure Ag
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0463	.0617
2				.0463	.0463
3				.0463	.0463
4				.0463	
5				.0463	.0463
6				.0463	
7				.0463	
10	.1543		.2315		
11	.3086		.2469		
12			.2469		
13	.2623		.1852		
14	.2006		.1852		
15	.2006		.2469		
16	.216	.2315			
17	.1698	.2778			
24				.0463	.0617
Max	.3086	.2778	.2469	.0463	.0617
Min	.1543	.2315	.1852	.0463	.0463
Avg	.2160	.2547	.2238	.0463	.0525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134088 / 33kv BOR-RANJANI

Feeder No / Name : 201 / 11 KV PARADGAON AG Ag dominated/Pure Ag
 FEEDER Feeder KV- 11 /
 OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2591					
2	.2915	.3239	.3239			
3	.2915	.4534	.3563			
4	.2753	.5668	.4534			
5	.3563	.6478	.4858			
6	.583	.7125	.4858			
7	.6478	.8097	.5668			
8	.7449	.7287	.6154			
9	.4372	.6964	.4049			
10				.3239	.3239	.2429
11				.5182	.4049	
12				.6478	.5506	.2915
13				.6802	.6154	.3239
14				.7287	.6478	.3239
15				.6478	.6478	.4049
16				.5668	.6802	.4534
17				.5506	.6154	.5182
Max	.7449	.8097	.6154	.7287	.6802	.5182
Min	.2591	.3239	.3239	.3239	.3239	.2429
Avg	.4318	.6174	.4615	.583	.5608	.3655

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134088 / 33kv BOR-RANJANI

Feeder No / Name : 202 / YEOLA GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.3734	.3734	.3361	.3361	.3361	.3361
2	.3511	.3734	.3734	.2801	.3734	.3361	.2801
3	.3881	.4481	.4108	.2801	.3734	.3734	.3734
4	.4251	.4108	.3734	.2987	.4108	.4108	.3361
5	.4668	.4668	.4668	.2614	.3734	.4108	.3361
6	.5788	.5041	.4854	.2801	.3734	.4668	
7	.6099	.5228	.5228	.2801	.3734	.3734	
8	.4805	.4668	.5228	.2801	.3361	.3429	
9	.5041	.4108	.4668	.2987	.3361	.3361	
10	.2614	.3921	.3734	.2987	.2801	.2801	
11	.2801	.3361	.3734	.2801	.2801	.2801	
12	.2427	.3361	.3361	.2427	.2427	.2427	.3734
13	.3361	.3174	.2427	.2427	.2614	.2801	.3361
14	.3361	.2987	.3361	.2801	.2614	.3361	.3361
15	.4668	.3361	.3547	.2987	.3361	.3361	.2801
16	.5228	.3734	.3734	.2987	.3734	.3734	.3361
17	.5975	.4108	.4108	.3361	.4108	.4108	.3734
18	.5975	.5228	.4108	.3734	.5228	.5228	.5228
19	.6348	.5975	.4668	.4108	.5975	.5601	.6535
20	.5601	.3734	.5228	.4668	.4668		.5975
21	.5228	.4668	.4108	.4854			.5601
22	.4668	.4668	.4668	.4108		.4108	.5601
23	.4668	.4108		.4108	.3734	.4108	.5228
24	.3361	.4108	.3734	.3361	.4668	.3361	.3734
Max	.6348	.5975	.5228	.4854	.5975	.5601	.6535
Min	.2427	.2987	.2427	.2427	.2427	.2427	.2801
Avg	.4487	.4178	.4108	.3236	.3709	.3712	.4160

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134088 / 33kv BOR-RANJANI

Feeder No / Name : 203 / 11 KV BOR RANJANI AG Ag dominated/Pure Ag

FEEDER Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.3239	.2429
2					.2915	.3239	.2429
3					.4108	.3239	.2915
4					.4049	.3239	.3239
5					.4049	.4049	.3239
6					.4534	.3887	
7					.4858	.421	
8					.4049	.4858	
9					.4858	.4858	
10	.3563	.5344	.2915	.3563			
11	.4858	.6348	.3239	.4534			
12	.5668	.6535	.5668	.4858			
13	.6154	.5344	.5668	.5182			
14	.7287	.6348	.6154	.5668			
15	.6802	.5668	.5668	.5668			
16	.6154	.5668	.5182	.6154			
17	.5344	.4858	.4858	.4534			
24						.2915	.2429
Max	.7287	.6535	.6154	.6154	.4858	.4858	.3239
Min	.3563	.4858	.2915	.3563	.2915	.2915	.2429
Avg	.5729	.5764	.4919	.5020	.4178	.3773	.278

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134012 / MANTHA

Feeder No / Name : 201 / TALNI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9945	.5144	1.0288	.2743	.9259	.9259	1.2003
2	.9602	.6001	1.3717		.9945	.9945	1.166
3	.9602	.6001	1.5432		1.0288	1.0974	1.1831
4	.9259	.6001	1.5432				
5	.8573	.6859	1.7147				
6	.8573	1.0974	1.7147				
7	.8573	1.7147	1.8176	.5144		1.0974	
8	.9602	1.8519	1.749	.5144			
9	1.5775	1.7833		.6859			
10					1.0288	.6859	.583
11					1.1145	.6859	.9259
12					1.2003	.6859	.9602
13						.823	.8916
14					1.2003		.8573
15					1.3717	1.0631	.8916
16	1.5432	.7545	1.0288	1.0288	1.3717	1.0288	.9259
17	1.3717			1.0974		1.0288	.9602
18	1.2003	1.3717				.9259	1.1317
19	1.3717	1.3717	.6859		1.3375	1.2689	1.2689
20		1.4403	.583	1.4403	1.3032	1.5089	1.5089
21	1.3717	1.4746	.5487	1.406	1.2003	1.4746	1.4746
22	1.5432	1.3717	.5144	1.4403	1.166	1.5089	1.406
23		.9945	.4458	1.2003	1.1317	1.3717	1.3546
24	.9602	.5144	.9259	.2743	.8916	.9259	1.3032
Max	1.5775	1.8519	1.8176	1.4403	1.3717	1.5089	1.5089
Min	.8573	.5144	.4458	.2743	.8916	.6859	.583
Avg	1.1445	1.1024	1.1477	.8979	1.1511	1.0612	1.1107

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134012 / MANTHA

Feeder No / Name : 202 / IDOLI (ARDA)

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715		.1543	.1029	.2058	.1886	
2	.2058	.1372	.1543	.1029	.2401	.2058	.1543
3	.2058	.3429	.1543	.1029	.2743	.2401	.1715
4	.2743	.3772	.1543	.1372			
5	.3086	.4115	.2058	.2058			
6	.3772	.3944	.2401	.2572			
7	.4458	.4801	.2743	.2572			
8	.3429	.4801	.3086	.2743			
9	.2401	.4458	.2572	.2743			
10					.1715	.2572	.1543
11					.1715	.2401	.1715
12					.1715	.2401	.1886
13					.2058	.2401	.2058
14					.2229	.1715	
15					.2229	.1029	
16	.1715	.1886	.1543	.2743	.2572	.1372	
17	.1715			.3086		.1029	.1715
18	.2058	.1029	.1715			.1029	.2229
19	.2229	.1029	.1715		.2572	.1715	.2058
20	.2401	.1715	.1886	.2401	.2743	.2058	.2229
21	.2572	.2401	.2058	.2229	.2401	.2401	.2401
22		.1715	.2058	.2058	.2229	.2058	.2058
23		.1715	.1372	.1886	.2058	.1715	.1886
24	.1372	.1543	.1543	.1029	.1715	.1715	.1543
Max	.4458	.4801	.3086	.3086	.2743	.2572	.2401
Min	.1372	.1029	.1372	.1029	.1715	.1029	.1543
Avg	.2486	.2733	.1937	.2036	.2197	.1886	.1899

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134012 / MANTHA

Feeder No / Name : 203 / PATHODA (HEALS)

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.2058	.6859		.5144	.2401	.463
2	.4973	.2401	.6859		.5487	.2572	.4458
3	.5144	.2743	.6859		.583	.2743	.4801
4					.6516	.2915	.4458
5					.6859	.3429	.4458
6					.7202		
7					.7716		
8					.7202		.3429
9					.4115	.4801	.3772
10	.6516		.6001	.3429		.4801	
11	.6173		.5487	.4115			
12	.6173	.6859	.4801	.4458			
13	.583	.7373	.5144	.463			
14	.5487	.6859	.5144	.4115			
15		.6001	.5144	.4287			
16	.6001	.583	.5487	.5144	.3772	.4458	.4458
17	.6859			.5487		.5144	.5487
18	.7202		.5144			.5487	.6173
19	.703	.583	.583		.4458	.6687	.583
20		.583	.5487	.6859	.3429	.7545	.6173
21	.7888	.6001	.5144	.8573	.3086	.6859	.6001
22		.5487	.5487	1.0631	.2743	.6516	.5658
23		.5144	.5144	.9259	.2401	.5144	.5144
24	.5487	.2058	.5144	.4801	.463	.2401	.4973
Max	.7888	.7373	.6859	1.0631	.7716	.7545	.6173
Min	.4973	.2058	.4801	.3429	.2401	.2401	.3429
Avg	.6136	.5034	.5598	.5830	.5037	.4619	.4994

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134012 / MANTHA

Feeder No / Name : 204 / AMBHODA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9945	.9431	1.1145		.583	.4115	.6173
2	.9945	.9259	1.1145		1.1145	.3772	.5487
3	.9602	.9259	1.1145		.6516	.3429	.5144
4					.6859	.3086	.583
5					.6516	.3429	
6					.6516	.3429	
7					.6173	.3086	
8					.6859	.3429	.3429
9					.7202	.2743	.4115
10	.7888	.583	.7545	.5144			
11	.7545	.5316	.703	.6173			
12	.7202	.6001	.703	.6859			
13	.6859	.6344	.6344	.6173			
14	.6859	.583	.6001	.5144			
15		.6173	.6001	.2401			
16	.7716	.6173	.6173	.6859	.6516	.3429	.3429
17	.8573	.6173		.823			.1715
18	1.0288	1.0288	.6516			.6516	.2743
19	1.0631	1.0288	.7545		.583	.7888	.823
20		1.2003	.8573	1.3375	.5144	.8573	.9945
21	.9602	1.2346	.9602	1.2689	.4801	.7888	.8916
22		1.2003	1.0288	1.2003	.4115		.8573
23		1.166	1.0631	1.0288	.3429	.6859	.823
24	1.0288	.9431	1.1488	1.0288	.583	.3772	.6516
Max	1.0631	1.2346	1.1488	1.3375	1.1145	.8573	.9945
Min	.6859	.5316	.6001	.2401	.3429	.2743	.1715
Avg	.8782	.8545	.8482	.8125	.6205	.4715	.5898

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134012 / MANTHA

Feeder No / Name : 205 / MANTHA TOWN-1

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1372	.12	.1029	.1372	.1029	.1029
2	.1029	.12	.12	.1029	.12	.1029	.1029
3	.1029	.12	.1029	.1029	.12	.1029	.0857
4	.1029	.12	.1029	.1029	.1029	.1029	.0857
5	.0857	.12	.1029	.1029	.1029	.1029	.0857
6	.0857	.12	.1029	.1029	.12	.1029	.0857
7	.1029	.12	.1029	.1029	.12	.1029	.1029
8	.1029	.1029	.1029	.1029	.12	.12	.1029
9	.12	.12	.1372	.12	.1029	.12	.1029
10	.1372		.1372	.12	.1029	.12	.12
11	.1372	.1543	.1543	.12	.12	.12	.12
12	.1543		.1715	.1029	.12	.1029	.1372
13	.1543	.1543	.1543	.1029	.1372	.1029	.1543
14	.1543		.1543	.12	.1372	.1372	.1372
15	.1715	.1715	.1543	.12	.1372	.1715	.1372
16	.1715	.1715	.1715	.12	.1372	.1715	.1543
17	.1715			.1372		.1715	.1543
18	.1715		.1715			.1715	.1543
19	.1715	.1543	.1543		.1372	.1543	.1715
20	.1543	.1543	.1543	.1372	.1372	.1372	.1372
21	.1372	.1543	.1543	.1372	.1372	.1372	.12
22		.1372	.1372	.1372	.1372	.12	.1029
23		.12	.1372	.1372	.1372	.1029	.1029
24	.12	.1372	.12	.12	.1372	.1029	.1029
Max	.1715	.1715	.1715	.1372	.1372	.1715	.1715
Min	.0857	.1029	.1029	.1029	.1029	.1029	.0857
Avg	.1333	.1363	.1357	.1161	.1255	.1243	.1193

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134012 / MANTHA

Feeder No / Name : 206 / INDUSTRIAL FEEDER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1029	.0343	.0343	.1029	.0686	.0343
2	.1372	.1029	.0343	.0343	.1029	.0686	.0343
3	.1029	.1715	.0343	.0343	.0686	.0686	.0343
4	.1029	.1715	.0343	.0343	.0686	.0343	.0343
5	.0686	.1715	.0343	.0343		.0686	.0343
6	.0343	.0686	.0343	.0343	.0343	.0686	.0686
7	.0343	.0343	.0343	.0343	.0343	.0686	.0686
8	.0343	.0343	.0343		.0343	.0686	.0686
9	.0343	.0343		.0343	.0343	.0686	.0686
10	.1372	.0343	.0343	.0343	.1372	.0686	.0686
11	.0686	.0343	.1029	.0343	.1715	.0686	.0686
12	.0343	.0343	.0686	.1029	.2058	.0686	.1029
13	.0343	.0343	.3086	.1372	.2058		.1372
14	.0343	.0343	.0686	.1543	.1715		.1029
15	.2058	.0343	.0686	.1715	.1715	.1372	.1029
16	.1715	.0343	.0686	.1886	.1715	.1372	.0686
17	.1372			.2058		.1029	.0686
18	.1372	.0343	.0686			.1029	.0686
19	.0343	.0343	.0686		.1029	.0686	.0686
20	.1372	.0343	.0686	.1372	.0686	.0343	.0686
21	.1372	.0343	.0343	.12	.0686	.0343	.0686
22		.0343	.0343	.1029	.0686	.0686	.0686
23		.0343	.0343	.1029	.0686		.0686
24	.1372	.1372	.0343	.0343	.1029	.0686	.0343
Max	.2058	.1715	.3086	.2058	.2058	.1372	.1372
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.0951	.0641	.0608	.0857	.1045	.0735	.0672

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134012 / MANTHA

Feeder No / Name : 207 / MANTHA TOWN-II

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.4746	1.3717	1.2003	1.4403	1.2689	1.3032
2	1.3375	1.4746	1.286	1.2003	1.4403	1.3032	1.3375
3	1.3546	.9602	1.2346	1.2003	1.4746	1.2689	1.406
4	1.3717	1.5261	1.286	1.286	1.4746	1.2689	1.4746
5	1.3717	1.5432	1.286	1.3717	1.4403	1.2346	
6	1.406	1.5089	1.286	1.3717	1.406	1.2003	1.5089
7	1.406	1.4403	1.3032	1.3717	1.406	1.3032	1.5432
8	1.3717	1.4403	1.3375	1.286	1.3717	1.3375	1.406
9	1.3717	1.406	1.2003	1.2346	1.2346	1.3375	1.3375
10	1.3032	1.4403	1.2689	1.3032	1.286		1.3032
11	1.3717	1.5089	1.3717	1.3375	1.3717	1.1145	1.2689
12	1.4403	1.3717	1.2689	1.3717	1.3717	1.0288	1.3032
13	1.5432	1.3032	1.2346	1.406	1.3717	.7716	1.2689
14	1.5432	1.3375	1.3717	1.3717	1.3717	.8916	1.2346
15	1.4403	1.406	1.4575	1.3717	1.3717	.9602	1.2346
16	1.406	1.4403	1.5432	1.5089	1.5432	1.0631	1.2689
17	1.4403			1.6118		1.3032	1.3032
18	1.4403	1.7147	1.5775			1.5432	1.3717
19	1.5089	1.7147	1.5432		1.5089	1.6461	1.4403
20	1.6118	1.6804	1.5089	1.3375	1.5432	1.5775	1.5432
21	1.6461	1.6461	1.5089	1.4746	1.5089	1.4746	1.6118
22		1.5775	1.4746	1.5775	1.3717	1.406	1.5432
23		1.5432	1.4403	1.5432	1.2003	1.3717	1.4746
24	1.406	1.4746	1.4403	1.3717	1.4403	1.2689	1.3032
Max	1.6461	1.7147	1.5775	1.6118	1.5432	1.6461	1.6118
Min	1.3032	.9602	1.2003	1.2003	1.2003	.7716	1.2346
Avg	1.4302	1.4754	1.3740	1.3686	1.4068	1.2584	1.3822

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134020 / DAHIPHAL KHANDARE

Feeder No / Name : 202 / DAHIFAL

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.5658	.6173		.4115		.3429
2	.7545	.5658	.6173		.463		.3429
3	.7716	.5658	.6687		.5658		.3429
4	.7716	.6173	.7202		.6173		
5	.7716	.6173	.7716		.7716		
6	.7716	.6687	.823		.9259		
7	.7716	.7716	.823		.8745		.2058
8	.5144	.6859	.7545		.823		.4287
9	.5658		.5658				.4287
10		.5487	.5487		.5658		.4287
11	.6687	.6173	.6173		.583		.4287
12	.6687	.6173	.6173	.5144	.5144	.2401	.3429
13	.6687	.5144	.5658		.5144	.2401	.2572
14	.6173		.5144	.5144	.5144	.2401	.2058
15	.6173	.5658	.5144		.3429	.2401	.2401
16	.5144	.6173	.5144	.6173	.3429	.2401	.2401
17	.5144	.6173	.5144	.6859	.3429	.2743	.3086
18	.6173	.6173		.7202		.3429	.3429
19	.823	.6687		.7545		.3429	.3429
20	.8916	.7202		.823		.3429	.4287
21	.6687	.823		.7202		.3429	.4458
22	.6173	.7716		.6687		.3429	.3944
23	.6173	.6859		.5658		.3429	.3944
24	.7545	.5658	.6173		.4115		.3429
Max	.8916	.823	.823	.823	.9259	.3429	.4458
Min	.5144	.5144	.5144	.5144	.3429	.2401	.2058
Avg	.6829	.6368	.6325	.6584	.5638	.2944	.3446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134020 / DAHIPHAL KHANDARE

Feeder No / Name : 203 / KOKARSHA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229		.1543	.2058	.2401	.1029	.1372
2	.2229		.1543	.2058	.2572	.1029	.1372
3	.2572		.1543	.2572	.2572	.1029	.1372
4	.2572		.2058	.2572	.3086	.1029	.1372
5	.2572		.2401	.3086	.3086		.1372
6	.2572		.2743	.3086	.3258	.1543	.1372
7	.2572		.2743	.2743	.3086	.1715	.1372
8	.2058	.2058	.3601	.2572	.2572	.1715	
9	.2058	.2058	.2401	.2058	.2058		
10	.2058	.2229	.1886	.1543	.2743	.1029	
11	.1715	.2058	.1715	.1543	.2743	.1029	
12	.1715	.1543	.1715	.1543		.1029	
13	.1715	.1372	.1543	.1543		.1029	
14	.1715	.1029	.1543			.1029	
15	.1543	.1029	.1372			.1029	
16	.1715	.12	.1372	.2058		.1029	
17	.1715	.2401	.1886	.2743	.1715	.1543	
18	.2058	.2229		.2743		.1715	.1715
19	.2743	.2743	.2229	.2743		.1715	.1715
20	.3086	.3086	.2572	.2915	.1715	.1372	.1715
21	.2743	.3086	.2401	.2743	.1715	.1372	.1715
22	.2743	.2743	.2401	.2743	.1715	.1372	.1715
23	.2743	.2401	.2058	.2401	.1715	.1372	.1715
24	.1715	.2058	.1543	.2058	.2401	.1715	.1372
Max	.3086	.3086	.3601	.3086	.3258	.1715	.1715
Min	.1543	.1029	.1372	.1543	.1715	.1029	.1372
Avg	.2215	.2078	.2035	.2369	.2421	.1294	.1519

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134020 / DAHIPHAL KHANDARE

Feeder No / Name : 204 / PEWA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.6687	.6173		.463		.3429
2	.4458	.6687	.6173		.463		.1715
3	.4287	.6859	.6173		.5144		
4	.4287	.7202	.6687		.6173		
5	.4287	.7202	.6687		.6687		
6	.4287	.7202	.7202		.6687		
7	.3429	.823	.7202		.7202		
8	.3429	.7202	.6344	.8745	.6173		
9	.3429	.6173		.7202	.4115		
10	.5144	.5658	.4115	.4115	.5658		
11	.5658	.6173	.4115	.463	.5144		
12	.5316	.6173	.4115	.5144	.5144		
13	.5144	.5144	.4115		.5144		
14	.5144	.5144	.4115	.5144	.5144		
15	.463	.5658	.463	.5316	.5144	.3429	
16	.6173	.6173	.5144	.6687	.5144	.3429	.4287
17	.7202		.823	.6859		.3429	.4801
18	.7202		.9259	.823		.4287	.5144
19	.8745	.823	.8745	.8916		.4287	.5144
20	.9774	.9088	.8573	.9774		.4287	.4973
21	.823	.823		.823		.4287	.5144
22	.7716	.7202		.7202		.4287	.5144
23	.7202	.6687		.6687		.3429	.5144
24	.4287	.6687	.6687		.463		.3429
Max	.9774	.9088	.9259	.9774	.7202	.4287	.5144
Min	.3429	.5144	.4115	.4115	.4115	.3429	.1715
Avg	.5573	.6804	.6224	.6859	.5447	.3906	.4396

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134023 / WATUR

Feeder No / Name : 201 / LAWANI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2347	.3018	.3429	.2452	
2			.2155	.3018	.3467	.2075	
3			.2294	.3018	.3641	.1886	
4			.2486	.2829	.3429	.1886	
5			.2622	.3018	.3561	.1886	
6			.2561	.3584	.4239	.2452	
7			.1389	.3395	.4801	.2452	
8				.3018	.5316		
9				.2641	.5316		
10				.3841	.2263		
11	.5596			.4656	.2241		
12		.5596		.4409			
13		.4115		.4578			
14	.4748		.3353	.463			
15		.3429		.4287			
16	.4359		.3429	.4287			.3704
17	.3222		.3429	.4161	.2801		
18	.3258	.2543	.2641	.2641			
19		.2256	.2829	.3206			
20		.2469	.2829	.3584			
21				.3395			
22	.2721		.3018	.3206			
23			.2641	.2801	.2452		
24	.3921		.2155	.2452	.2883	.2452	.2012
Max	.5596	.5596	.3429	.4656	.5316	.2452	.3704
Min	.2721	.2256	.1389	.2452	.2241	.1886	.2012
Avg	.3975	.3401	.2636	.3486	.3560	.2193	.2858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134023 / WATUR

Feeder No / Name : 202 / PANGARI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0168			
2			.0181			
3			.0309			
4			.016			
5			.0339			
6			.0154			
8		.0373	.0171		.0189	
9					.0187	.0191
11	.0187			.0187		
12		.0187		.0183		
13		.0187				
14	.0187		.0187			
15				.0185		
16	.0339			.0183		.0181
17	.037			.0179		
18	.0373					
19		.0366				
20		.0366				
22	.0362					
24	.0191		.0191			.0181
Max	.0373	.0373	.0339	.0187	.0189	.0191
Min	.0187	.0187	.0154	.0179	.0187	.0181
Avg	.0287	.0296	.0207	.0183	.0188	.0184

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134023 / WATUR

Feeder No / Name : 203 / Dahifal

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.5384	.5121	.7468	.7095	
2			1.5083	.5228	.7282	.6908	
3			1.3272	.5175	.7282	.6722	
4			1.2963	.5544	.7095	.7095	
5			1.3603	.6722	.7095	.7095	
6			1.3603	.6722	.6722	.7095	
7			1.6461	.7095	.6722	.7282	
8		.506		.7842	.6722	.6722	
9				1.17	.6722	.6535	
10				1.3565	1.1142	.8619	
11	.5281				1.094		
12		.0747					
13		.0187		.5975		1.1934	
14	.5601		.0373	.6224			
15		.0373		.679	1.1174	1.1683	
16	.5975		.056	.7356		1.1498	.7935
17	.7468		.056	.7468	1.0442		
18	1.0456	.5914	.6722	.7468	.6722	.7468	
19		.5853	.7095	.7655			
20		.7975	.7468	.8029	.7468		
21			.7468	.7468	.7095		
22	.9835		.7282	.7282	.7095		
23			.7282	.7282	.7095		
24	1.0164		.8951	.5121	.7167	.7095	.6704
Max	1.0456	.7975	1.6461	1.3565	1.1174	1.1934	.7935
Min	.5281	.0187	.0373	.5121	.6722	.6535	.6704
Avg	.7826	.3730	.9066	.7220	.7866	.8056	.7320

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134023 / WATUR

Feeder No / Name : 204 / SHESH NARYAN

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0286		
2			.029		
3			.0141		
4			.0271		
5			.0312		
6			.016		
7			.0271		
9					.0114
11	.0135			.0131	
12				.0133	
14	.0135				
16	.0137				.0162
17	.0137			.0137	
18	.0078				
19		.0143			
20		.0324			
22	.0141				
24	.0135		.0429		.0232
Max	.0141	.0324	.0429	.0137	.0232
Min	.0078	.0143	.0141	.0131	.0114
Avg	.0128	.0234	.027	.0134	.0169

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134023 / WATUR

Feeder No / Name : 205 / WAJODA EXPRESS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.016	.0107	.0122	
2			.0154	.0111	.0122	
3			.0162		.0122	
4			.016	.0111	.0122	
5			.032	.0111		
6				.0111		
8		.032				
10				.0122	.0122	
11				.0122		
12				.0122		
13				.0122		
14	.0162			.012		
15				.0122		
16				.0122		.0168
17	.0162			.0122		
18			.0111	.012		
19			.0111	.012		
20		.0162	.0111	.012		
21			.0111	.0122		
22			.0111	.0122		
23			.0111	.0122		
24	.0162		.032		.0122	.016
Max	.0162	.032	.032	.0122	.0122	.0168
Min	.0162	.0162	.0111	.0107	.0122	.016
Avg	.0162	.0241	.0162	.0118	.0122	.0164

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134023 / WATUR

Feeder No / Name : 206 / wadhona

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					1.5893	1.6263	
2					1.5893	1.6263	
3					1.5893	1.5893	
4					1.6078	1.6448	
5					1.6078	1.6632	
6					1.6817	1.8111	
7				2.3908	1.6817	1.7926	
8		3.3653		2.4756	1.6632	1.7741	
9				2.6452	1.6632	1.6817	
10				2.6452	2.2891	2.1262	
11	1.3256				2.5652		
12				1.6817			
13		1.9404		1.6817		2.2634	
14	1.4661		1.8671	1.6448			
15		1.4937		1.6448	2.73	2.332	
16	1.3565		2.0538	1.6632		2.2891	.4578
17	1.6289		2.2032	1.7002	2.5692		
18		1.8298	1.6078	1.7002	1.6817	2.5579	
19		1.701	1.6448	1.7177	1.6817		
20		2.2081	1.7187	1.7187	1.6632		
21			1.7187	1.7187	1.6632		
22	1.6804		1.7002	1.7002	1.6448		
23			1.7002	1.7002	1.6448		
24	.8316	.8316	2.146	.2204	1.6632	1.6263	1.9244
Max	1.6804	3.3653	2.2032	2.6452	2.73	2.5579	1.9244
Min	.8316	.8316	1.6078	.2204	1.5893	1.5893	.4578
Avg	1.3815	1.9100	1.8361	1.8029	1.8235	1.8936	1.1911

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134057 / 33/11 KV IDOLI SSTN

Feeder No / Name : 202 / PATODA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4298	.5792	.543	.4344	.4119	.5373	.6154
2	.4557	.6878	.5792	.4706	.4477	.4961	.6516
3	.4908	.6516	.6722	.5121	.4607	.5138	
4	.4119	.724	.6024	.5601	.5316	.5014	
5	.4207	.724	.543	.5853	.567	.4835	
6	.4024	.6878	.543	.6161	.5731	.5014	
7	.4298	.7059	.4706	.4755	.5847	.5014	
8	.4755	.8962	.5258		.6379	.5083	.5068
9	.4656	.8326	.5959		.6805	.5373	.362
10	.905	.823	.6241	.5959	.4477	.3582	1.086
11	1.0029	.7602	.5959	.7628	.3544	.3403	1.0317
12	.9412	.7964	.5731	.6935	.3898	.2835	.9774
13	.8688	.9055	.5959	.6733	.394	.2835	.362
14	.8048	.8059	.5853	.6201	.3258	.2896	.3439
15	.7602	.6344	.6241	.5487	.4119	.2896	.3258
16	.8688	.823	.583	.6805	.4298	.3258	
17	.8869		.583	.591	.3898	.3258	.3982
18	.724		.5487	.5373	.4656	.3439	.4344
19	.724	.5144	.5144	.4835	.5014	.3982	.5249
20	.6697	.5487	.583	.6201	.4835	.4344	.1267
21	.6878	.6173	.5658	.543	.5014	.4706	.1086
22	.6697	.3429	.5144	.3898	.4961	.4706	
23	.6154	.3086	.4458	.4119	.5138	.6516	.2896
24	.4163	.5658	.3856	.4287	.4075	.5316	
Max	1.0029	.9055	.6722	.7628	.6805	.6516	1.086
Min	.4024	.3086	.3856	.3898	.3258	.2835	.1086
Avg	.6470	.6789	.5582	.5561	.4753	.4324	.5091

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134057 / 33/11 KV IDOLI SSTN

Feeder No / Name : 203 / IDOLI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1222	1.448	.2103		.9922	.8954	1.3032
2	1.086	1.448	.1867		.9671	.8954	
3	.543	1.4299	.1867		.8859	.8775	
4		1.4449	.2241		.8328	.8682	
5		1.448	.2614		.8238	.8505	
6		1.6289	.2587		.7973	.8859	
7		1.9909	.1867		.8859	.9313	
8	.6878	.8688	.2507		1.1871	.9745	
9	.3582	.8326	.2614	.2835	1.3998	1.0029	1.3575
10	1.182	.8326	.2865	.1772	1.6834	1.6476	1.086
11	1.2308	1.2803	.2507				1.0317
12	1.1222	1.267	.2987			2.0022	.9877
13	1.086	1.2851	.3361			2.2857	1.1222
14	1.0498	1.1831	.2865			2.1491	1.086
15	1.0029	1.2517	.3361			2.2497	1.1041
16	.9774	1.3717	.583			2.1491	1.086
17	.8507		.6173			1.9909	
18	.8779		.6516			.905	
19	.8326	.703	.6859	1.1145	.8417	1.0136	1.267
20	.8507	.6516	.8573	1.2178	.8682	1.1222	.8145
21	.8688	.6344	.8402	1.0745	.8682	1.3394	.9877
22	1.2308	.6001	.7202	.8682	.9412	1.5912	.9412
23	1.086	.6001	.6859	.9568	.9412	1.267	.905
24	1.3969	1.3375	.1867		.9922	.8573	1.3213
Max	1.3969	1.9909	.8573	1.2178	1.6834	2.2857	1.3575
Min	.3582	.6001	.1867	.1772	.7973	.8505	.8145
Avg	.9721	1.1608	.4021	.8132	.9943	1.3370	1.0934

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134070 / Talni

Feeder No / Name : 201 / 11 KV DEVTHANA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5144	.5487	.4973	.3258		.3086
2	.5144	.5316	.5487	.4973	.3429		.3258
3	.5316	.5487	.5658	.5487	.3601		.3429
4	.5658	.6516	.5658	.5487	.4115		.3601
5	.6173	.7202	.703	.6001	.5487		.3944
6	.5144	.7716	.6516	.6173	.5487		.4287
7	.6687	.6687	.6173	.6859	.463		.4458
8	.703	.6173	.583	.6687	.4458		.4973
9	.703	.6001	.4973		.5144		.4115
10	.3258	.3429	.2743		.5487	.5144	.463
11	.3258	.4115	.2572	.3086	.5487	.4801	.5144
12	.2915	.2572		.3086	.583	.5144	.3772
13		.2743	.2915	.3429	.6001	.463	.3944
14		.2572	.3258	.3601	.6173	.4973	.4115
15		.2229	.3429	.3429	.5658	.5144	.4458
16			.3601	.3601	.6001	.4973	.463
17		.3601	.3429	.4115		.3772	.4287
18	.3772	.3772	.3772	.463		.3944	.463
19	.5316	.3601	.3944	.6859		.4801	.4801
20	.5144	.3772	.4287	.4973		.463	.4801
21	.4458	.3429	.3772	.4458		.4287	.4115
22	.3944	.3601	.3429	.4287		.3944	.3601
23	.3944	.3429	.2915	.3944		.3429	.3258
24	.5144	.5144	.4973	.4458	.3429		.3429
Max	.703	.7716	.703	.6859	.6173	.5144	.5144
Min	.2915	.2229	.2572	.3086	.3258	.3429	.3086
Avg	.4973	.4533	.4428	.4754	.4922	.4544	.4115

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134070 / Talni

Feeder No / Name : 203 / 11 KV TALNI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4973	.5144	.6173	.4801	.6173	.583	.4287
2	.4801	.5144	.6344	.5144	.6173		.463
3	.4973	.5316	.6173	.5144	.6516		.5144
4	.5487	.6173	.6173	.6173	.703		.5658
5	.6687	.6516	.6516	.6173	.8059		.6344
6	.7202	.7202	.7202	.6859	.8402	.6516	.6687
7	.6859	.5658	.6859	.7202	.7545	.6687	.703
8	.6516	.4458	.6859	.5487	.583	.6859	.7545
9	.4458	.4458	.5144	.4458	.6173	.583	.5144
10	.5144	.4801	.5144	.5144	.3086	.2743	.4115
11	.5144		.4973	.5316	.3429	.3429	.4287
12	.4115	.4973	.4973	.5144	.3429	.3258	.4458
13	.4801	.5144	.4801	.5144	.3772	.2572	.4458
14	.4973	.4458	.4801	.4115	.4115	.2743	.4801
15	.5487	.5144	.5487	.4458	.3772	.3086	.4973
16	.6173		.5658	.5487	.4287	.2915	.5316
17	.6516	.4801	.6173	.5487	.4458	.3258	.5658
18	.6344	.6173	.6516	.6001		.3601	.6001
19	.6516	.703	.6344	.6859	.6859	.5144	.7545
20	.6173	.6859	.6001	.6173		.6173	.703
21	.5658	.6516	.5487	.583		.5658	.5658
22	.5487	.583	.5316	.5658		.5316	.5316
23	.5144	.5658	.4801	.5144	.5658	.4801	.5144
24	.4973	.4801	.5487	.4458	.5487	.5658	.463
Max	.7202	.7202	.7202	.7202	.8402	.6859	.7545
Min	.4115	.4458	.4801	.4115	.3086	.2572	.4115
Avg	.5609	.5557	.5809	.5494	.5513	.4604	.5494

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134071 / pangari gosavi

Feeder No / Name : 201 / pangari 11 kv

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	01-JUN-17	02-JUN-17
HR	Load (MW)	Load (MW)
1	.1614	.3239
2	.176	.3239
3	.176	.3563
24	.1486	.208
Max	.176	.3563
Min	.1486	.208
Avg	.1655	.3030

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134071 / pangari gosavi

Feeder No / Name : 202 / wai

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	01-JUN-17	02-JUN-17
HR	Load (MW)	Load (MW)
1	.0743	.0486
2	.0673	.0972
3	.0587	.081
4	.0587	.0663
5	.0892	
6	.128	
7	.1187	
8	.104	
9	.104	
24	.0848	.081
Max	.128	.0972
Min	.0587	.0486
Avg	.0888	.0748

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134071 / pangari gosavi

Feeder No / Name : 203 / 11 kv kathala feeder
Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	01-JUN-17	02-JUN-17
HR	Load (MW)	Load (MW)
1	.3521	.1492
2	.3201	.2429
3	.3658	.1943
24	.4409	
Max	.4409	.2429
Min	.3201	.1492
Avg	.3697	.1955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134004 / 33/11 KV PARTUR

Feeder No / Name : 201 / TOWN-1

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1622	1.0288	1.1203	.9945	1.105	1.0082	1.105
2	1.1622	1.0288	1.1203		1.105	1.0082	1.105
3	1.1622	1.0288	1.1203	.9774	1.105	1.0456	1.1431
4	1.2003	1.0288	1.1203	1.0288	1.105	1.1203	1.1812
5	1.2003	1.0631	1.1576	.9431	1.1812	1.1576	
6	1.2193	1.1145	1.251	.9088	1.2193	1.0082	
7	1.3908	1.2689	1.3817	1.0631	1.4098	1.1203	
8	1.3908	1.2346	1.419	1.2696	1.5051	1.1949	
9	1.2384	1.3817	1.3817		1.2003	1.2384	
10	1.0456	1.3443	1.307	1.4937	1.166	1.0479	1.2689
11	1.1949	1.2696	1.1431		1.0974	1.1431	1.2346
12	1.1203	1.1949		1.3443	.9602		1.0117
13	1.1016	1.0829	1.2384	1.2323	.9259	1.1431	.9259
14	1.0829	1.0829	1.2193	1.1949	.8573	1.1622	.9088
15	1.1203	1.0829	1.2955	1.0829	.9945	1.2384	.8059
16	1.166	1.251	1.3336	1.2696	1.2323	1.1431	1.166
17	1.3375	1.6057	1.2346	1.2384		1.2384	1.3546
18	1.5604		1.286	1.1431	1.7551	1.1431	1.3032
19	1.4232	1.6804	1.2346	1.2384	1.4937	1.1812	1.2689
20	1.3375	1.5684	1.3032	1.1431	1.307	1.1431	1.3546
21	1.2174	1.4937	1.2346	1.2384	1.1949	1.0479	1.1317
22	1.166	1.307	1.0802	1.1431	1.1576	1.1431	1.0974
23	1.0802	1.226	1.046	1.2384	1.1203		1.046
24	1.1622	1.0288	1.1203	.9945	1.1812	1.0456	1.105
Max	1.5604	1.6804	1.419	1.4937	1.7551	1.2384	1.3546
Min	1.0456	1.0288	1.046	.9088	.8573	1.0082	.8059
Avg	1.2184	1.2346	1.2239	1.1514	1.1904	1.1237	1.1325

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134004 / 33/11 KV PARTUR

Feeder No / Name : 202 / TOWN-II

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8861	1.8176	1.7833	1.6804	1.7147	1.8671	
2	1.8004	1.7661	1.7833	1.6461	1.6975	1.8671	
3	1.7147	1.749	1.7147	1.5775	1.6461	1.8671	
4	1.7147	1.7833	1.6461	1.5775	1.6461	1.9044	
5	1.749	1.7833	1.6804	1.6118	1.6461	1.7924	
6	1.7661	1.8004	1.7147	1.6289	1.6632	1.8298	
7	1.8519	1.8176	1.7833	1.6975	1.7661	1.9418	
8	1.8004	1.8519	1.8519	1.8671	1.8861	1.9791	
9	1.8861	1.8519	1.7147		1.8111	1.8099	1.4575
10	1.8861	1.7833	1.7147	2.2032	1.9044	1.9243	1.3375
11	1.8861	1.8861	1.6804	1.9605	1.9605	2.0005	1.2346
12	1.9547	1.8861	1.8004	1.9044	1.9791		1.8347
13	1.9204	1.8519	1.7147	1.8671	1.8671	1.8099	1.7661
14	1.9204	1.8861	1.6289	1.9044		1.9433	1.6975
15	1.9547	1.8861	1.749		2.3152	2.0005	1.7147
16	1.989	1.989	1.8004	2.1285	2.3152	1.8671	1.9204
17	2.0576	2.1262	1.7833	2.0957	2.2405	1.9433	1.749
18	2.1948	1.5432	1.8004	2.0005	2.2405	1.7147	1.8176
19	2.1605	1.9719	1.8004	1.8671	2.0538	2.0005	1.7661
20	2.1948	2.1776	1.8861	1.8099	2.1285	1.8099	2.0576
21	2.0748	2.1948	1.8861	1.8671	2.1285	1.8671	1.8519
22	2.0576	2.0233	1.8176	1.8099	2.0911	1.8671	1.8176
23	1.9376	1.9547	1.8176	1.9719	2.0538		1.7318
24	1.8861	1.869	1.8519	1.7147	1.8176	1.9791	
Max	2.1948	2.1948	1.8861	2.2032	2.3152	2.0005	2.0576
Min	1.7147	1.5432	1.6289	1.5775	1.6461	1.7147	1.2346
Avg	1.9269	1.8854	1.7668	1.8360	1.9379	1.8903	1.7170

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134004 / 33/11 KV PARTUR

Feeder No / Name : 203 / SAIBABA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.4863	1.749	2.5911		2.3663	
2		2.6063	1.749			2.4348	
3		2.6578	1.7833			2.5377	
4		2.7435	1.8861			2.6155	
5		2.915	2.0233				
6		3.0693	2.4006				
7		1.0288	1.5432	1.0669		1.166	
8		1.1317	1.3717	1.3375		1.5775	
9	1.8861	1.4918	1.4403		1.3889	1.7147	.4458
10	1.7436	1.4746	.5335	1.2003	1.406	1.6289	.6344
11		1.4403	.5144	1.3203	1.406	1.7147	.6687
12		1.406		1.3032	.4382		.8059
13	1.8519	1.3717	1.0288	1.2346	.0495	1.1431	.7888
14	1.5089	2.13	1.3717	2.0119		1.2384	.8059
15		2.1956	1.5432	2.0119	1.1488	1.1431	.9717
16	1.286	2.2939	1.6289	1.5775	1.1145	1.2384	.4572
17	1.3032	2.3266	1.2003	1.5432	1.2346	1.3336	.743
18	1.3375	.9526	1.2346	1.8861	1.4403	1.4289	1.6194
19	1.2689	1.2193	1.0974	1.8004	1.2003	1.5242	1.9052
20	3.1893	1.9719		2.2862	1.4403	2.2862	2.6101
21	2.8464	1.8519	2.6673	2.0957	1.406	2.3815	2.6863
22	2.4006	1.8519	2.5911	2.2862	1.3717	2.4768	2.572
23	1.2003	1.8519	2.6482		1.3032		2.4196
24		2.553	1.749	2.6292		2.1605	
Max	3.1893	3.0693	2.6673	2.6292	1.4403	2.6155	2.6863
Min	1.2003	.9526	.5144	1.0669	.0495	1.1431	.4458
Avg	1.8186	1.9592	1.6252	1.7754	1.1677	1.8055	1.3423

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134004 / 33/11 KV PARTUR

Feeder No / Name : 204 / KAWAJAWALA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.6516	.394	.1715	.6478	.724	.381
2	.5487	.6516	.394		.6859	.724	.3429
3	.6173	.6516	.394		.7621	.724	.381
4	.6516	.6516	.4298		.7621	.8002	.4191
5	.6859	.6516	.5014		.8002	.8764	
6	.7202	.6687	.6626		.8002	.8764	
7	1.0117	.8402	.6661		.381	.6097	
8	.7888	.9259	.7202		.5335	.5335	
9	1.1431	.823	.7202			.381	
10	.4001	.2096	.1524		.7362	1.0288	
11	.381	.3429	.381		.8589	1.2003	
12	.381	.381			.9991		
13	.4001	.4191	.4191		.9945	1.0288	
14	.4001	.4191	.4763		.9088	1.2003	
15	.4382	.4191	.4191		.9088	1.2384	
16	.4382	.4191	.4763		1.0974	1.0288	
17	.4763	.4572	.381	.381	1.1317	1.2003	
18	.5716		.4191	.3429	.381	.381	
19	.4572			.4763	.381	.4191	.5144
20	.8764		.7811	.5335	.6668	.381	.3429
21	.8002	.6097	.724	.4191	.8002	.4763	.3048
22	.724	.6859	.6478	.381	.7621	.4191	.2858
23	.6478	.6287	.6287	.724	.6859		.2858
24	.5144	.6516	.394	.1715	.6097	.6859	.7049
Max	1.1431	.9259	.7811	.724	1.1317	1.2384	.7049
Min	.381	.2096	.1524	.1715	.381	.381	.2858
Avg	.6078	.5790	.5083	.4001	.7520	.7699	.3963

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134004 / 33/11 KV PARTUR

Feeder No / Name : 205 / ANANDWADI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	1.0479	1.0288	.9907	.7545	.8063	1.0288
2	1.5623	1.0479	1.0288		.7888	.8063	1.1145
3	1.5242	1.0479	1.0288		.7888	.8063	1.2003
4	1.5242	1.105	1.1241		.823	.8764	
5	1.5242	1.1812	1.1812		.8916	.9536	
6	1.5623	1.3336	1.2955		1.0117	1.1488	
7	1.2955	1.2384	1.3336		1.2346	1.4083	
8	1.4289	1.2003	1.3336		1.3717	1.5424	
9	1.2384	.9907	1.105		1.3375	1.5432	
10	1.5089	1.2346	1.0974		1.0288	.7621	
11	1.576	1.5089	1.5432		1.0669	.9526	
12	.7522	1.4746			1.0288		
13	1.5775	1.4232	1.5432	1.0631	1.0288	.9526	
14	1.5089	1.4403	1.4575	1.166	1.0479	.7621	
15	1.4232	1.0631	1.5089	1.2071	1.0098	.8573	
16	1.576	1.4232	1.5432	1.2346	1.0288	.9526	1.2003
17	1.6975	1.5089		1.3717	1.105	.7621	.6668
18	.9088		1.0479	1.1431		.7621	1.1431
19	1.2384	1.2765	1.2765	1.2384	1.2955	.9145	1.467
20	1.2955	1.467	1.3146	1.1431	1.4098	1.1431	1.467
21	1.2574	1.3717	1.3336	1.2384	1.3336	1.2384	1.4098
22	1.2193	1.2955	1.1622	1.1812	1.2955	1.2384	1.3336
23		1.2193	1.105	1.2955	1.2193		1.2003
24	1.7147	1.0479	1.0288	1.105	.7202	.7362	.5658
Max	1.7147	1.5089	1.5432	1.3717	1.4098	1.5432	1.467
Min	.7522	.9907	1.0288	.9907	.7202	.7362	.5658
Avg	1.4187	1.2586	1.2464	1.1829	1.0705	.9966	1.1498

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134004 / 33/11 KV PARTUR

Feeder No / Name : 206 / INDUSTRIAL
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0895	.1029	.1052	.0857	.1143	.1052	.1075
2	.0895	.1029	.1052	.0857	.1143	.1052	.1075
3	.0895	.1029	.1052		.1143	.1052	.1075
4	.0895	.1029	.1052	.0857	.1143	.1052	.1075
5	.0895	.1029	.0876	.0857	.1143	.1052	.1075
6	.0895	.0857	.0876	.0857	.1143	.1052	.1143
7	.0895	.0857	.0876	.0857	.1075	.1052	.1143
8	.0895	.0857	.0857	.0857	.1075	.12	.1075
9	.1143	.1052	.1052		.0876	.0953	.1029
10	.0701	.0876	.1052	.1052	.0876	.0953	.0857
11	.1715	.1052	.0953	.0876	.1052	.1143	.1029
12	.1029	.1052		.1029	.1227		.1029
13	.1029	.0876	.1143	.1029	.1052	.0953	.1029
14	.1029	.0876	.0953	.1029	.0876	.1143	
15	.0876	.0876	.0953	.1029	.0876	.0953	
16	.1029	.0876	.1143	.1029	.1227	.1334	.0514
17	.1029	.0876	.0857	.0953	.1052	.1143	.0686
18	.1029	.0876	.0857	.1143	.1052	.0953	.0686
19	.1029	.0876	.0857	.0953	.1052	.1143	.0686
20	.0857	.1052	.1029	.1143	.1052	.0953	.1029
21	.1029	.1052	.1029	.0953	.1052	.1143	.1029
22	.1029	.1052	.0857	.0953	.1052	.0953	.0857
23	.1029	.1052	.0857	.0895	.1052		.0857
24	.0895	.1029	.1052	.0857	.1075	.1052	.1075
Max	.1715	.1052	.1143	.1143	.1227	.1334	.1143
Min	.0701	.0857	.0857	.0857	.0876	.0953	.0514
Avg	.0985	.0963	.0971	.0951	.1063	.1061	.0960

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134004 / 33/11 KV PARTUR

Feeder No / Name : 207 / 11 KV AMBA FEEDER
Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	01-JUN-17	03-JUN-17	04-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.8745	.7202		
2	.7545	.8745			
3	.7545	.8745			
4	.7888	.8745			
5	.823	.8916			
6	.8402	.9088			
7	1.0802	1.0974			
8	1.0802	1.2071			
9	1.2003	1.2071			
10				1.0288	.6173
11				1.1145	.6344
12					.2915
13					.3086
14					.3086
15					.3258
16					.6001
17				1.1431	.5316
18				1.1145	
19				1.2003	
24	.7545	.8745	.703		
Max	1.2003	1.2071	.7202	1.2003	.6344
Min	.7545	.8745	.703	1.0288	.2915
Avg	.8831	.9685	.7116	1.1202	.4522

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134004 / 33/11 KV PARTUR

Feeder No / Name : 208 / 11KV water supply express Sheddable Rural/Mix Feeder
feed Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0537	.0514	.0537	.0343	.0358	.0537	.0537
2	.0537	.0514	.0537	.0343	.0381	.0537	.0537
3	.0537	.0514	.0537	.0343	.0381	.0537	.0537
4	.0537	.0514	.0537	.0343	.0381	.0537	.0179
5	.0358	.0514	.0537	.0343	.0191	.0537	.0179
6	.0358	.0343	.0537	.0343	.0191	.0537	.0716
7	.0895	.0686	.0895	.0857	.0537	.0895	.0716
8	.1254	.1372	.1433	.0895	.1075	.0895	.0716
9	.0953	.1402	.1433		.1075	.1143	.1029
10	.1433	.1402	.1578	.1433	.1075	.1334	.1372
11	.1402	.1402	.1334	.1612	.0895	.1143	.12
12	.1433	.1402		.1254	.0537		.0857
13	.12	.1402	.0953	.1254	.0716	.0953	.0343
14	.1254	.1417	.1143	.1254	.0895	.1334	.0343
15	.1254	.0358	.1334	.1254	.0543	.1143	.0343
16	.1433	.124	.0953	.1254	.0543	.1143	.0514
17	.12	.1417	.12	.1143	.0543	.0953	.12
18	.12	.1227	.12	.0953	.1075	.1143	.12
19	.0514	.0716	.1372	.1143	.1254	.0953	.1372
20	.0686	.0537	.0343	.0953	.0537	.0572	.0514
21	.0686	.0537	.0171	.1143	.0537	.0762	.0343
22	.0686	.0537	.0343	.0572	.0716	.1143	.0343
23	.0686	.0537	.0343	.0537	.0537		.0514
24	.0537	.0514	.0537	.0343	.0358	.0537	.0572
Max	.1433	.1417	.1578	.1612	.1254	.1334	.1372
Min	.0358	.0343	.0171	.0343	.0191	.0537	.0179
Avg	.0899	.0876	.0860	.0866	.0639	.0876	.0674

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134010 / 33/11 Kv ASHTI

Feeder No / Name : 201 / ASHATI TOWN

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7202	.7373	.7202	.6516	.7545	.6859	.823
2	.7545	.7545	.6859	.583	.6859	.703	.8573
3	.7716	.7716	.7202	.6516	.7202	.7202	.8916
4	.823	.8059	.703	.6859	.7716	.7545	
5	.823	.8916	.7202	.703	.7716	.7202	.8916
6	.8573	.8402	.823	.6687	.7373	.7888	.9431
7	.8916	.9945	.8916	.6001	.8059	.8573	.9945
8	.9259	1.046	.8573	.6859	.7545	.823	.9259
9	.8745	.8402	.8059		.703	.8059	.8745
10	.823	.8573	.7545	.7202	.6859	.703	.8745
11	.8573	.8059	.7888	.6687	.6001	.7202	.8402
12	.7716	.7888	.8059	.6516		.7545	
13	.823		.7545			.7202	.7545
14	.8573	.6859	.7202		.8745	.7545	.7888
15	.8573	.8059	.7373		.8916	.7716	.8745
16	.8745	.8916		.8573	.9259	.823	.8573
17	.9602	.9774		.8402	.9602	.8745	
18	.9945	.8916	.9945	.8573	.9774	.8916	.8745
19	1.0288	.8916	.9945	.9774	.9945	.9259	.9088
20	.9945	.9431	.8916	.9945	.9431	.9945	.9945
21	.9259	.7202	.8402	.9431		.8402	.8745
22	.9088	.7888	.7716	.8059		.7888	.8573
23	.823	.7716		.823	.7716	.7716	.7373
24	.7716	.7373	.7888	.6516	.7545	.7202	.7545
Max	1.0288	1.046	.9945	.9945	.9945	.9945	.9945
Min	.7202	.6859	.6859	.583	.6001	.6859	.7373
Avg	.8630	.8365	.7986	.7510	.8042	.7880	.8663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134010 / 33/11 Kv ASHTI

Feeder No / Name : 202 / KARALA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823		.7316	.6859	.9774	.8916	.8573
2	.7926		.7621	.703	.8916	.8573	.823
3	.9945		.8573	.5144	.8573	.8916	.823
4	1.0288		.7926	.4115	.9945	.9259	
5	.945		.8383	.4287	1.0288		
6	.9755		1.1431	.4115	1.1145		
7	1.1736		1.3413				
8	1.2346		1.3717			.7716	
9	1.1431		.945		.5144	.7545	
10	.7202		.6344		.2286	.4287	
11	.6859		.6859		.2743	.6687	
12	.6344	.9907	.6687		.7316	.8688	
13	.6859	1.2193	.7202	.1886	.7316	.8078	
14	.6173	.5316	.6859	.6344	.823	.9431	
15	.703	.6001	.6516	.703	.8916	.884	
16	.6859	.7545		.6516	.7621	.9602	.5335
17	.823	.8573		.8059	.8383	.9259	
18	.7888	.9774	1.1317	.823	.8573	.823	.8745
19		1.0288	1.1317	.9774	.9774	.8916	.9259
20	1.0631	1.1145	.9431	1.0288	1.0802	1.0288	1.0802
21	1.0974	1.0974		1.046		1.0631	1.0288
22	1.0631	1.0288	.7373	1.046		.0171	.9945
23	.8745	.9431		1.0288	.9431	.4973	.9774
24	1.0288		.6859	.6859	1.0288	.9259	.8573
Max	1.2346	1.2193	1.3717	1.046	1.1145	1.0631	1.0802
Min	.6173	.5316	.6344	.1886	.2286	.0171	.5335
Avg	.8949	.9286	.8730	.7097	.8273	.8013	.8887

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134010 / 33/11 Kv ASHTI

Feeder No / Name : 203 / WAHEGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2041		.9907		.2229	.823	1.1145
2	1.3413		1.0364		.2401	.7716	1.1145
3	1.4022		1.0974		.2915	.7545	1.0974
4	1.7223		1.1888		.3429	.7202	
5	1.8138		1.3108		.3601	.9259	
6	2.1338		1.3717		.3772	.9945	
7	2.1338				.3086	1.0631	
8	2.2405				.1715	.823	
9	1.9052	1.1584			.2058	.8059	
10	.9088	1.6004	1.8747			.8573	
11	.9945	1.5242	1.7071			.7621	
12	.9945	1.0631	1.6309		.1524	.7621	.1677
13	.9945	1.0802	1.166		.1715	.8573	.4801
14	.9945	1.1145	1.2003		.1543	.6859	.5792
15		1.1145	1.166		.1715	.583	.5792
16	.9774	1.0802			.2058	.6173	.4725
17	1.1145	1.0631				.6516	.5182
18	1.3032	1.2003		.1372	.3772	.6516	
19		1.2003		.1886	.5487	1.0288	.7888
20	1.2003	1.2003		.2058	.5144	1.1145	.7716
21	1.5432	1.166		.2229		1.0974	.8573
22	1.5089	1.166	.8402	.2058	.9259	1.1831	.9431
23		1.1145		.2229	.8916	1.2003	1.1145
24			.9145		.9602	.8573	1.166
Max	2.2405	1.6004	1.8747	.2229	.9602	1.2003	1.166
Min	.9088	1.0631	.8402	.1372	.1524	.583	.1677
Avg	1.4216	1.1897	1.2497	.1972	.3797	.8580	.7843

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134010 / 33/11 Kv ASHTI

Feeder No / Name : 205 / RAIGWAN

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.5487	.7716	.7716	.8993	.6859	.884
2	.8916	.6344	.7202	.7545	.9145	.7468	.8993
3	.9431	.6859	.7716	.583	.945	.8383	.945
4	.9259	.823	.9431	.583	.9755	.9145	
5	.9259	.9774	1.0288	.6173	1.0059	.9145	
6	.9431	.9259	1.1488	.6516	.9907	1.2193	
7	.8402	.8573	.9774	.6859	1.2193	1.448	
8	.7716	.7373	.8573	.7716	1.2346	1.5242	
9	.6516		.7716	.7716	1.0974	1.448	.5335
10	2.0119		1.5242	.8688	.6344	.583	.5335
11	2.2253	1.6766	1.6766	.9297		.6516	.6516
12	2.1643	1.829	1.8138	1.0669	.6344	.6001	.3201
13	1.9814	1.7985	1.829	1.0974	.6344	.4458	.3429
14	1.9814	1.3413	1.6613	1.0822	.6173	.4458	.5144
15	1.7223	1.448	1.6004	.9297	.6001	.463	.5487
16	1.7985	1.5089		.9907	.583	.4973	.583
17	1.7985	1.4937		1.2193	.583	.5487	
18	.6859	.6173	.8573	.703	.5658	.6516	.703
19	1.0631	.823	.9907	.9945		.8573	.9774
20	1.0288	1.0631	.8916	.9774	1.0974	.9431	.9774
21	1.0117	.9945	.9431	.9602		.9774	.8916
22	.9602	.9431	.8402	.9774		.8916	.8573
23	.5487	.8916		.9431	.823	.8402	.6859
24	1.0631	.4973	.7888	.7888	.8535	.6097	.823
Max	2.2253	1.829	1.829	1.2193	1.2346	1.5242	.9774
Min	.5487	.4973	.7202	.583	.5658	.4458	.3201
Avg	1.2415	1.0507	1.1146	.8633	.8454	.8227	.7040

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134010 / 33/11 Kv ASHTI

Feeder No / Name : 206 / 11KV BHAGAWANNAGAR FEEDER Single Phasing Feeders
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219	.0762	.0305	.0343	.0514	.0171	.0343
2	.1524	.0914	.0305	.0343	.0514	.0171	.0343
3	.1829	.0914	.0457	.0343	.0686	.0152	.0343
4	.2134	.0914	.0457	.0514	.0686	.0171	
5	.2439	.1067	.0457	.0514	.0686	.0171	
6	.2743	.1067	.1067	.0686	.0686	.0171	
7	.3048	.1524	.1677	.061	.0686	.0171	
8	.3658	.1981	.1372			.0171	
9	.3353	.1677	.1524	.0857		.0171	
10					.1067	.1524	
11					.1829	.1829	
12					.1981	.2439	
13					.1981	.2439	.0762
14					.1981	.2439	.0914
15					.1829	.2286	.061
16					.1372	.2439	.0914
17					.1677	.2743	.1067
18						.0191	.12
19		.0343		.0171			.1029
20	.0171	.0514	.0381	.0343	.0171	.0191	.0343
21	.0171	.0343	.0343	.0514		.0191	.0343
22	.0171	.0343	.0514	.0686	.0343		.0514
23	.0171	.0343		.0686	.0343	.0343	.0686
24	.0171	.0762	.0305	.0514	.0686	.0171	.0343
Max	.3658	.1981	.1677	.0857	.1981	.2743	.12
Min	.0171	.0343	.0305	.0171	.0171	.0152	.0343
Avg	.1629	.0898	.0705	.0509	.1038	.0943	.0650

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134017 / 33/11 Kv SATONA

Feeder No / Name : 201 / MAPEGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3077	1.2742	1.1736	.57	.5868	.57
2		1.4083	1.291	1.1736	.5365	.5868	.503
3		1.5424	1.3245	1.2071	.57	.6036	.4694
4		1.8107	1.3916	1.2239	.6371	.6203	.5868
5		1.8945	1.4754	1.2574	.6706	.6706	.57
6		1.9281	1.5927	1.5089	.9221	.8048	.5533
7		1.9784	1.7436	1.8442	.6203	.8383	.5365
8		1.9448	1.7772	1.7604	.7377	.788	.503
9		1.9113	1.6766	1.6095	.6036	.57	.4527
10		.4024	.4694	.4359	1.2574	1.1401	.7712
11		.4191	.3688	.3185	1.4251	1.3077	.9389
12		.4191	.4024	.3688	1.3916	1.3245	1.1401
13	.4694	.4191	.4191	.3856	1.3413	1.3748	1.2742
14		.4191	.4527	.4024	1.3413	1.4083	1.2407
15		.4359	.4694	.4191	1.4251	1.4419	1.2742
16	.4359	.4694	.4694	.4694	1.4754		1.358
17	.4694	.503	.4862	.5365	1.4419	1.4251	1.3077
18	.57	.6036	.5197	.4527	.4191	.4359	.57
19	.6706	.6706	.6203	.5868	.503	.4527	.6539
20	.57	.6874	.6706	.7377	.5868	.5365	.5868
21	.5868	.6371	.6203	.6706	.6036	.57	.5365
22	.5365	.6036	.5868	.5533	.6036	.503	.503
23	.503	.57	.5533	.5365	.5868	.5365	.4694
24	1.3375	1.073	1.2239	.9221	.5533	.5868	.5365
Max	1.3375	1.9784	1.7772	1.8442	1.4754	1.4419	1.358
Min	.4359	.4024	.3688	.3185	.4191	.4359	.4527
Avg	.6149	1.0024	.9116	.8564	.8676	.831	.7461

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134017 / 33/11 Kv SATONA

Feeder No / Name : 202 / SATONA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7712	.8048	.7545	.8718	.788	.7545
2		.788	.8215	.4694	.9054	.8048	.6706
3		.8215	.8718	.6706	.9389	.8048	.7042
4		.8551	.9221	.7042	1.0059	.8383	.7377
5		.8886	.9724	.9221	1.0395	.8718	.788
6		.9054	1.0059	.9221	1.0395	1.0227	.7712
7		.9221	1.0227	.9724	1.0562	1.0898	.7209
8		.8383	.9892	.9389	1.073	1.0898	.7545
9		.8383	.8048	.6371	1.0059	.9389	.6706
10		1.073	.9054	.4694	.7377	.6706	.6706
11		1.0395	.8383	.8886	.7042	.7042	.6371
12		1.0227	.9892	.9892	.6706	.6371	.5868
13	.9556	1.0059	1.0059	1.0395	.6539	.6706	.6874
14	.9892	.9724	.9724	.9389	.6874	.6874	.7042
15		.9724	1.0227	1.0395	.7377	.7042	.6706
16	.788	1.0395	.9724	1.0059	.7712	.7545	.6874
17	.8048	.8048	.9221	1.0562	.8551	.788	.7209
18	.8383	.8718	.9389	.9054	.9054	.7545	.7545
19	.9054	.9556	.9389	.8383	1.073	.7042	.788
20	.9221	.9221	1.0059	1.0395	1.0898	.7209	.8551
21	.8718	.8718	.9389	.9724	.9221	.7042	.7545
22	.8383	.8383	.8718	.8383	.8551	.7209	.6706
23	.8048	.8048	.8383	.8048	.788	.7042	.7042
24	1.286	.8048	.8048	.7377	.8383	.7545	.6706
Max	1.286	1.073	1.0227	1.0562	1.0898	1.0898	.8551
Min	.788	.7712	.8048	.4694	.6539	.6371	.5868
Avg	.9095	.9012	.9242	.8565	.8844	.7887	.7139

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134017 / 33/11 Kv SATONA

Feeder No / Name : 203 / SHELGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7042	.6036	.6706	.7042	.7545	.57
2		.7209	.6036	.6036	.7377	.7042	.6371
3		.8048	.6371	.5533	.7712	.7377	.6783
4		.7712	.6539	.6036	.8048	.7545	.6068
5		.7545	.6874	.6371	.7712	.7545	.5935
6		.7042	.7042	.6371	.5868	.8551	.6104
7		.6874	.7209	.7545	.7712	.8886	.6443
8		.7042	.7545	.6539	.8048	.8886	.5868
9		.6706	.6371	.5868	.7377	.9556	.57
10		1.073	.9556	.4694	.503	.4694	.6371
11		1.1401	1.1568	.9389	.503	.4862	.6706
12		1.1401	1.1904	.9221	.4862	.5365	.6371
13	1.1401	1.0898	1.1233	.8718	.4862	.57	.6706
14	1.1904	1.073	1.1736	.8383	.503	.5075	.5868
15		1.0059	1.1065	.7377	.503	.4359	.6706
16	1.1401	1.0227	.9556	.7545	.503	.4862	.6371
17	1.0059	.8718	.9221	.8718	.5868	.5533	.6203
18		.6371	.5868	.4694	.6371	.57	
19	.57	.7209	.6371	.5868	.6874	.5868	
20	.8048	.7545	.8215	.9221	.7545	.57	.6706
21	.788	.7209	.7377	.8048	.7712	.5365	.6203
22	.7209	.6874	.7042	.7042	.7209	.5533	.6371
23	.6706	.6539	.7042	.6539	.6706	.5365	.7042
24	1.3889	.6371	.6371	.6371	.6706	.7042	.5365
Max	1.3889	1.1401	1.1904	.9389	.8048	.9556	.7042
Min	.57	.6371	.5868	.4694	.4862	.4359	.5365
Avg	.9420	.8229	.8090	.7035	.6532	.6415	.6271

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134017 / 33/11 Kv SATONA

Feeder No / Name : 204 / INDUSTRIAL
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17	02-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
7		.1341	
17			.1341
24	1.1145		
Max	1.1145	.1341	.1341
Min	1.1145	.1341	.1341
Avg	1.1145	.1341	.1341

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134017 / 33/11 Kv SATONA

Feeder No / Name : 205 / DEVLA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1677	.1677	.2012	.7545	.788	.3018
2		.1844	.1677	.218	.788	.8048	.4527
3		.1844	.1844	.2012	.9221	.8383	.4527
4		.1677	.1844	.2347	1.0059	.8718	.57
5		.2012	.2347	.2683	1.0898	.8886	.503
6		.2347	.2683	.3018	.9221		.4694
7		.3018	.3018	.3018	.9221		.4862
8		.2347	.285	.2515	.9389		.503
9		.2012	.2347	.2012	1.0059		.3688
10		.8551	.7377	.7377	.1677	.1509	.1006
11		1.1401	.9389	.9892	.1677	.1006	.1174
12		1.1233	1.0898	1.1065	.1341	.0838	.1006
13	.9389	1.0898	1.1401	1.1736	.1341	.0671	.1006
14	.9724	1.0898	1.1736	1.2071	.1174	.0838	.0838
15		1.073	1.1401	1.0562	.1174	.1006	.1174
16	.9221	1.1065	.9724	1.1065	.1174	.1174	.1174
17	.8718	.8551	.9389	1.073	.1341	.1174	.1006
18	.1677	.1677	.1677	.1677	.1677	.1341	.1677
19	.2012	.218	.2347	.2347	.2012	.1677	.218
20	.1677	.2012	.218	.2515	.2347	.218	.1677
21	.1844	.218	.2012	.2515	.2012	.1677	.1341
22	.1677	.2012	.2012	.2347	.1677	.1844	.1174
23	.1677	.1844	.2012	.1677	.1509	.1677	.1006
24	1.286	.2012	.1677	.1677	.6706	.7377	.3391
Max	1.286	1.1401	1.1736	1.2071	1.0898	.8886	.57
Min	.1677	.1677	.1677	.1677	.1174	.0671	.0838
Avg	.5498	.4834	.4813	.5044	.4681	.3395	.2579

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134017 / 33/11 Kv SATONA

Feeder No / Name : 206 / DEVLTA WATER SUPPLY
Feeder KV- 11 / OUTGOING

Only one consumer of WW with HT-IV

DATE	01-JUN-17	02-JUN-17
HR	Load (MW)	Load (MW)
5		.0168
24	1.0136	
Max	1.0136	.0168
Min	1.0136	.0168
Avg	1.0136	.0168

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134017 / 33/11 Kv SATONA

Feeder No / Name : 207 / Express Kedarwakdi
Feeder KV- 11 / OUTGOING

HV Express Feeder

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1006	.1174	.1174	.1174	.1006	.1006
2		.1174	.1174	.1006	.1341	.1174	.1006
3		.1174	.1341	.0838	.1174	.1174	.1174
4		.1174	.1006	.0671	.1341	.1174	.1174
5		.1174	.1006	.1006	.1174	.1341	.1174
6		.1006	.1006	.1174	.1006	.1341	.1174
7		.1174	.1006	.1341	.1341	.1341	
8		.1174	.1174	.1341	.1341	.1341	.1006
9			.1341	.1509	.1509	.1174	.1174
10			.1174	.1677	.1174	.1341	.1006
11		.0914	.1341	.1677	.1341	.1006	.1174
12		.1174	.1509	.1509	.1341	.1174	.1174
13	.1006	.1174	.1341	.1509	.1341	.1006	.1174
14	.1174	.1006	.1174	.1341	.1174	.1174	
15		.1006	.1341	.1174	.1174	.1174	.1174
16	.1006	.1174	.1509	.1174	.1341	.1006	.1174
17	.1174	.1006	.1341	.1341	.1341	.1341	.1006
18	.1174	.1006	.1509	.1006	.1341	.1174	.1174
19	.1174	.1174	.1341	.1174	.1341	.1174	.1341
20	.1174	.1006	.1341	.1341	.1174	.1341	.1006
21	.1174	.1174	.1174	.1174	.1174	.1341	.1174
22	.1006	.1174	.1341		.1006	.1174	.1006
23	.1174	.1174	.1174	.1174	.1006	.1174	.1174
24	1.4403	.1174	.1006	.1006	.1006	.1174	.1174
Max	1.4403	.1174	.1509	.1677	.1509	.1341	.1341
Min	.1006	.0914	.1006	.0671	.1006	.1006	.1006
Avg	.2331	.1109	.1244	.1232	.1237	.1202	.1128

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134017 / 33/11 Kv SATONA

Feeder No / Name : 208 / 11 KV IRREGATION EXPRESS HV LIS Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0168	.0168	.0168	.0168	.0168	.0168
2		.0168	.0168	.0168	.0168	.0168	.0168
3		.0168	.0168	.0168	.0168	.0168	.0168
4		.0168	.0168		.0168	.0168	.0168
5		.0168	.0168	.0168	.0168	.0168	.0168
6		.0168	.0168	.0168	.0168	.0168	.0168
7		.0168	.0168	.0168	.0168	.0168	.0168
8		.0168	.0168	.0168	.0168	.0168	.0168
9		.0168	.0168	.0168	.0168	.0168	.0168
10		.0168	.0168	.0168	.0168	.0168	.0168
11		.0168	.0168	.0168	.0168	.0168	.0168
12		.0168	.0168	.0168	.0168	.0168	.0168
13	.0168	.0168	.0168	.0168	.0168	.0168	.017
14	.0168	.0168	.0168	.0168	.0168	.0168	.0168
15	.0168	.0168	.0168	.0168	.0168	.0168	.0168
16	.0168	.0168	.0168	.0168	.0168	.0168	.0168
17	.0168	.0168	.0168	.0168	.0168	.0168	.017
18	.0168	.0168	.0168	.0168	.0168	.0168	.0168
19	.0168	.0168	.0168	.0168	.0168	.0168	.0168
20	.0168	.0168	.0168	.0168	.0168	.0168	.0168
21	.0168	.0168	.0168	.0168	.0168	.0168	.0168
22	.0168	.0168	.0168	.0168	.0168	.0168	.0168
23	.0168	.0168	.0168	.0168	.0168	.0168	.0168
24	1.1831	.0168	.0168	.0168	.0168	.0168	.0168
Max	1.1831	.0168	.0168	.0168	.0168	.0168	.017
Min	.0168	.0168	.0168	.0168	.0168	.0168	.0168
Avg	.1140	.0168	.0168	.0168	.0168	.0168	.0168

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134031 / 33/11 KV SHRISHTI

Feeder No / Name : 201 / SHRISHTI AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.2743	.2469
10	.7099	.5792	.6097				
11	.7562	.6859	.6249				
12	.6636	.6706	.6401	.5335			
13	.5864	.6554	.6097	.5182			
14	.5556	.6097	.5487	.5182			
15	.5401	.5792	.5182	.503			
16	.5401	.5639		.4725			
17	.5864	.442		.4572			
18					.5487	.6944	
19					.5182	.8192	
20					.3658	.6097	
21					.3506	.463	
22					.3353	.4321	
23					.3201	.3704	
24						.3201	.3241
Max	.7562	.6859	.6401	.5335	.5487	.8192	.3241
Min	.5401	.442	.5182	.4572	.3201	.2743	.2469
Avg	.6173	.5982	.5919	.5004	.4065	.4979	.2855

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134031 / 33/11 KV SHRISHTI

Feeder No / Name : 202 / PATODA Ag AG Feeder with SDT
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	06-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669		1.1431	
2				.7099
3				.7407
4				.7099
5				.7099
6				.9568
7				1.2809
8				1.2809
9				1.2654
18	1.6461	1.5242		
19	1.7071			
20	1.448	1.7071		
21	1.3108	1.6309		
22	1.1279	1.5089		
23		1.3717		
24	1.0974		1.2041	
Max	1.7071	1.7071	1.2041	1.2809
Min	1.0669	1.3717	1.1431	.7099
Avg	1.3435	1.5486	1.1736	.9568

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134031 / 33/11 KV SHRISHTI

Feeder No / Name : 203 / DATHANA Gao Gaothan Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	.4001	.381	.4001	.4382	.4954	.4001
2	.4001	.4001	.381	.381	.4382	.4572	
3	.4191	.4001	.4001	.381	.4572	.4572	
4	.4572	.4572	.4763	.4954	.5335	.5335	
5	.4954	.5906	.5525	.5335	.6097	.6287	
6	.5716	.724	.6097	.5906	.6859	.8383	
7	.5906	.5906	.6478	.6097	.7049	.8002	
8	.5716	.5144	.5906	.5525	.4572	.5716	
9	.5716	.4382	.4382	.4954	.4382	.4954	
10	.4572	.381	.3239		.381	.4382	
11	.3429	.3429	.2858	.2286		.3429	
12	.3429	.362	.2667	.2477	.2858	.2858	
13	.3429	.4191	.2667	.2477	.2858	.3048	
14	.3429	.4572	.2858	.2667	.3048	.3239	
15	.362	.4572	.3239	.2667	.3239	.3048	
16	.381	.4572		.3429	.3239	.3048	
17	.4001		.362	.362	.362	.3239	
18	.4001		.5335	.4191	.4191	.3429	
19	.6097		.5525	.5525		.5335	
20	.6097	.5335	.5335	.6287	.7049	.6668	
21	.5335	.4382	.4954	.6097	.6097	.5906	
22	.4763	.4001	.4001	.4191	.5144	.4954	
23	.4001	.381	.4001	.4001	.5144	.4572	
24	.381	.4001	.381	.4001	.4191	.4954	.4191
Max	.6097	.724	.6478	.6287	.7049	.8383	.4191
Min	.3429	.3429	.2667	.2286	.2858	.2858	.4001
Avg	.4525	.4545	.4299	.4274	.4642	.4787	.4096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134031 / 33/11 KV SHRISHTI

Feeder No / Name : 204 / YENORA Gao Gaothan Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2858	.2572	.2858	.2915	.2858	.2858
2	.2401	.2858	.2572	.2477	.3086	.2858	
3	.2401	.2858	.3258	.2858	.3086	.3048	
4	.2572	.3429	.3258	.362	.3772	.362	
5	.3429	.4382	.3944	.4001	.4458	.4954	
6	.3772	.5144	.3772	.2858	.4801	.5906	
7	.3944	.4572	.3944	.2858	.4973	.5335	
8	.3944	.381	.3944	.2858	.4191	.4382	
9	.3944	.2858	.2743	.2858	.381	.2858	
10	.3429	.2572	.2858	.2229	.362	.2477	
11	.2286	.2058	.2477	.2058		.2286	
12	.2286	.2572	.2096	.2229		.1905	
13	.2096	.2743	.2096	.2229	.2667	.1905	
14	.2096	.2915	.2096	.2229	.2477	.1715	
15	.1905	.2915	.2286	.2401	.2667	.1905	
16	.2477	.2915		.2572	.2858	.2096	
17	.3048	.3086	.3048	.2743	.2477	.2286	
18	.381	.3429	.362	.3258	.381	.2667	
19	.4191		.381	.3772	.4001	.381	
20	.4191	.3772	.3429		.4001	.381	
21	.381	.3429	.3239	.3258	.3429	.3429	
22	.3239	.2572	.2858	.2743	.3048	.3239	
23	.2477	.2229	.2858	.2401	.3048	.2858	
24	.2401	.2858	.2572	.2858	.2915	.2858	.2858
Max	.4191	.5144	.3944	.4001	.4973	.5906	.2858
Min	.1905	.2058	.2096	.2058	.2477	.1715	.2858
Avg	.3030	.3167	.3015	.2792	.3460	.3128	.2858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134031 / 33/11 KV SHRISHTI

Feeder No / Name : 205 / Ashti Water Supply Only one consumer of WW with HT-IV
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191		.0191		.0191	.0191	
2	.0191		.0191		.0191	.0191	
3	.0191		.0191		.0191	.0191	
4	.0191		.0191		.0191	.0191	
5	.0191	.0191	.0191		.0191	.0191	
6	.0191	.0191	.0191		.0191	.0191	
7	.0191		.0191	.0191	.0191	.0191	
8	.0191	.0191	.0191	.0191	.0191	.0191	
9	.0191	.0191	.0191	.0191	.0191	.0191	
10	.0191	.0191	.0191	.0191	.0191	.0191	
11	.0191	.0191	.0191	.0191		.0191	
12	.0191	.0191	.0191	.0191			
13		.0191	.0191	.0191			
14		.0191	.0191	.0191			
15	.0191	.0191		.0191			
16	.0191	.0191		.0191	.0191	.0191	
17	.0191	.0191		.0191	.0191	.0191	
18	.0191	.0191		.0191		.0191	
19	.0191	.0191		.0191		.0191	
20	.0191	.0191		.0191	.0191	.0191	
21	.0191	.0191		.0191	.0191	.0191	
22	.0191	.0191		.0191	.0191	.0191	
23	.0191	.0191		.0191	.0191	.0191	
24	.0191		.0191		.0191	.0191	.0191
Max	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0191	.0191	.0191	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134031 / 33/11 KV SHRISHTI

Feeder No / Name : 206 / 11KV HATDI AG FEEDER
Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	01-JUN-17
HR	Load (MW)
24	1.3375
Max	1.3375
Min	1.3375
Avg	1.3375

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134058 / 33KV/11KV LONI SUBSATION

Feeder No / Name : 201 / LONI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429		.2915		.2559	.2515	.3772
2	.2915		.2915		.3048	.3391	.4287
3	.3239		.3647	.2058	.3395	.3353	.3944
4	.3563		.4191	.1715	.4191	.3052	
5	.4049		.4862	.2401	.4763	.4748	.3429
6	.4534		.4694	.2572	.4111	.5784	.3429
7	.4694		.4534	.2058	.4111	.503	.4458
8	.4534		.1905	.1715	.4268	.57	.463
9			.1905		.4111	.503	.1372
10	.3688		.9012	.5487	.1905	.1905	.12
11	1.8023		1.1469		.1905		.1524
12	1.8023		1.3108	.2439	.1905	.1715	
13	1.6385	.4191	1.2289	.427	.1905	.1372	.1905
14	1.4746	.7209		.3086		.1372	.1905
15	1.3927	1.2239	.9831	.3658	.1524	.1372	.1905
16		1.3748	.6859	.381	.1905	.12	.1905
17		1.5089		.4321	.1905	.1372	.1905
18	.2401	.1905	.3429		.2286	.1372	.1905
19	.4801	.2683	.4287	.1905	.4191	.1715	.1905
20	.463	.3563	.4801	.1905	.4191	.2743	.3239
21	.4287	.421	.4287	.2858	.4748	.2572	.4763
22	.3772	.4481	.3944	.2667	.5087	.2229	.5335
23		.4144	.3429	.2477	.4049	.2058	.5716
24	.3239		.3887	.2258		.3391	.4096
Max	1.8023	1.5089	1.3108	.5487	.5087	.5784	.5716
Min	.2401	.1905	.1905	.1715	.1524	.12	.12
Avg	.6944	.6678	.5555	.2824	.3276	.2826	.3115

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134058 / 33KV/11KV LONI SUBSATION

Feeder No / Name : 202 / CHANGATPURI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0395		1.0898		.6097	.6287	.5144
2	1.0562		1.1568		.5716	.6859	.4287
3	1.0898		1.1401		.5716	.724	.463
4	1.153		1.2239		.6478	.7621	
5	1.1736		1.2407		.6859	.8192	.4287
6	1.2071		1.1568		.7621	.8383	.6859
7	1.2239		1.2955		.8192		.9088
8	1.2071		1.2955		.7049		.7716
9	1.3245		1.1736		.5906		.7373
10	.724		.3772		.2652		.3772
11	.4801		.4287		.5868	.9012	.3963
12	.4115	.5335	.3944		.9054	1.065	.6097
13	.4458	.6097	.4458		1.2071	1.1633	.7611
14	.4115	.5716	.463		1.2039	1.2003	.7287
15	.4458	.6287		.5525	1.1736	1.1305	.6554
16	.4458	.5716	.3944	.6097	1.2239	1.1633	.7011
17	.4801	.5525		.6478	1.2574	1.1469	.7621
18	.5658	.6668	.8059	.6859	.6668	.6001	.7621
19	.7888	.8002	.7716	.8002	.7621	.7716	.6859
20	.6859	.7811	.8059	.8573	.7042	.9431	.724
21	.6001	.7811		.7811	.8764	.8059	.743
22	.3429	.7049		.7621	.7621	.7373	.7621
23	.3429	.724		.724	.724	.6859	.724
24	.9221		.7545	.6668		.6668	.6001
Max	1.3245	.8002	1.2955	.8573	1.2574	1.2003	.9088
Min	.3429	.5335	.3772	.5525	.2652	.6001	.3772
Avg	.7737	.6605	.8639	.7087	.7949	.8720	.6492

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134058 / 33KV/11KV LONI SUBSATION

Feeder No / Name : 203 / 11kv Golegaon

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17
HR	Load (MW)
24	1.4575
Max	1.4575
Min	1.4575
Avg	1.4575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134061 / 33/11 KHANDAVI SUBSTATION

Feeder No / Name : 201 / TAKALI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1524	.1067		.1715	.2401	.2572
2		.1524	.1067		.1715	.2401	.2572
3		.1524	.1067		.1715	.2229	.2572
4		.2286	.1219		.1715	.2401	.2572
5		.2286	.1543		.2058	.2572	.2572
6		.3201	.2591		.2058	.2915	.2572
7		.381	.3658		.2058	.3258	.2743
8		.4115	.381		.2401	.2915	.2229
9		.442	.381		.2401	.2229	.1886
10		.1543	.1372		.2134	.1677	.061
11		.1543	.0857		.2286	.1981	.0914
12		.1543	.0857		.2439		.1067
13		.1543			.2134	.1981	.1067
14		.1543	.1886	.1715	.1981	.2058	.1067
15		.1715	.1715		.1829	.1829	.1219
16		.1886	.1886	.1715	.2134	.1677	.1524
17	.2229	.2058	.1715	.1543	.2286	.1981	.1677
18	.1715	.2058	.2229	.1715	.1886	.1715	.12
19	.2743	.3258	.2401	.2229	.2401	.2401	
20	.3429	.2743	.2743	.3258	.3258	.3258	.2058
21	.2743	.2743		.2915	.2572	.3086	
22	.2743	.2401	.1715	.2915	.2401	.2743	.1715
23	.2572	.2229	.1715	.2572	.2229	.2572	.1715
24		.1524	.1219	.0857	.1715	.2229	.2401
Max	.3429	.442	.381	.3258	.3258	.3258	.2743
Min	.1715	.1524	.0857	.0857	.1715	.1677	.061
Avg	.2596	.2293	.1916	.2143	.2147	.2370	.1842

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134061 / 33/11 KHANDAVI SUBSTATION

Feeder No / Name : 202 / KHANDVI Single Phasing Feeders
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7716	.8402	.8573	.3048	.3048	.2743
2		.7888	.823		.3048	.3201	.2743
3		.7716	.823	.9259	.3048	.3353	.2743
4		1.0288	.8573	.8916	.4572	.3658	.2134
5		1.2003	1.0117	.9602	.4572	.3963	.2134
6		1.3032	1.2003	1.166	.4572	.4268	.1981
7		1.2003	1.1317	1.1145	.4572	.5335	.2896
8		.823	.8573	.9259	.381	.5487	.2591
9		.7545	.7373	.7373	.3658	.4725	.3048
10		.3353	.3353	.2591	.5487	.5316	.5658
11		.4877	.5487	.3048	.5144	.4801	.5144
12		.4725	.4877	.3048	.442		.463
13		.3963		.3048	.6001	.4973	.463
14		.3353	.3963	.381	.583	.5487	.463
15		.3506	.3048		.5487	.5487	.4973
16	.6706	.381	.2896	.381	.6173	.5316	.5144
17	.7316	.4572	.2743	.4268	.5658	.5144	.5316
18	.7202	.7373	.7545	.7716	.6173	.6001	.6001
19	.9088	.9945	.8573	.823	.9431	.7545	
20	1.0802	.9602	.9945	1.0802	.9602	.9431	1.0631
21	.9774	.9431		.9774	.9774	.9431	
22	.9774	.9259	.8916	.9774	.9259	.9259	.8573
23	.9431	.8916	.8573	.9431	.8573	.8745	.7716
24		.9431	.8573	.8059	.3048	.2743	.2743
Max	1.0802	1.3032	1.2003	1.166	.9774	.9431	1.0631
Min	.6706	.3353	.2743	.2591	.3048	.2743	.1981
Avg	.8762	.7606	.7332	.7418	.5623	.5509	.4491

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134061 / 33/11 KHANDAVI SUBSTATION

Feeder No / Name : 203 / USMANPUR Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.6766	1.4632	1.5432	.1715	.2743	.2743
2		1.6766	1.4937		.1715	.2286	.2572
3		1.829	1.6309	1.4918	.1715	.2286	.2743
4		2.1338	1.6766	1.2498	.2572	.2743	
5		2.1338	1.6766	1.5089	.2572	.3086	
6		2.2862	1.9509	1.5775	.2572	.3429	
7		2.2862	2.2862	1.4937	.3429	.4801	
8		2.2862	2.1948	1.5242	.3429	.463	
9		2.5606	2.21	1.829	.3944	.3429	.4287
10		.3086	.2572	.2229	1.6766	1.7071	1.4784
11		.2572	.2058	.2229	2.3624	2.0424	1.5851
12		.2401	.1372	.2229	2.4082		1.7528
13		.2401		.2229	2.3624	2.0881	1.768
14		.2058	.1886	.2401	2.332	2.4006	1.8138
15		.2058	.2401		2.2862	2.1643	1.829
16	.3258	.2229	.2743	.2401	1.8442	2.1948	1.8442
17	.2915	.2401	.3086	.2401	2.0271	2.2558	1.8138
18	.3086	.3258	.3429	.3429	.2572	.2572	.2229
19	.4973	.3944	.3772	.3429	.3258	.4115	
20	.4458	.3601	.3429	.3944	.3601	.4115	.4287
21	.3429	.3429		.2915	.3258		
22	.3429	.2743	.2915	.2915	.3086		.3258
23	.3429	.2572	.2915	.2572	.2743	.3258	.2915
24		1.6766	1.3717		.2572	.2743	.2743
Max	.4973	2.5606	2.2862	1.829	2.4082	2.4006	1.8442
Min	.2915	.2058	.1372	.2229	.1715	.2286	.2229
Avg	.3622	1.0175	.9642	.7500	.9073	.9275	.9802

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 201 / TOWN

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.8573	.7716		.6859
2	.7716	.8573	.6859		.6859
3	.7716	.8573	.6859		.6859
4	.7716	.8573	.7716		.7716
5	.8573	.8573	.8573		.8573
6	.8573	.8573	.8573		.8573
7	.8573	.9431	.8573		.8573
8	.8573	1.0288	.8573		
9	.8573	.8573			
10	.9431				
11	.9431				
12	.9431		.6859	1.0288	.8573
13	.9431		.8573	1.0288	.8573
14	.9431		.9431	1.0288	.8573
15	.9431			1.0288	.8573
16	1.1145			1.0288	1.0288
17	1.1145			1.0288	1.0288
18	.9431			1.0288	.8573
19	.9431			1.0288	.8573
20	.9431			1.0288	.9431
21	.9431			1.0288	.9431
22	.8573			.9431	.9431
23	.8573			.9431	.8573
24	.8573	.8573	.8573		.7716
Max	1.1145	1.0288	.9431	1.0288	1.0288
Min	.6859	.8573	.6859	.9431	.6859
Avg	.8966	.8830	.8073	1.0145	.8530

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 202 / RAMKHEDA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	05-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6859		
2	.6859	.6097		
3	.6097	.6097		
4	.9145	.6097		
5	1.5432	.7621		
6	1.4575	1.4575		
7	1.3717	1.448		
8	1.3717	1.5432		
9	1.2003	1.286		
10	.7716			
11	.6859			
12	.6859			
13	.6859			.3429
14	.6859			.3429
15	.6859			.2572
16	.6859			.2572
17	.6859			.5144
18	.8573			.5144
19	1.286			.6859
20	.9145			.7716
21	.9145			.6859
22	1.0288			.5144
23	.8573			.5144
24	.8573	.8573	.8573	
Max	1.5432	1.5432	.8573	.7716
Min	.6097	.6097	.8573	.2572
Avg	.9220	.9869	.8573	.4910

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 203 / AMBADGAON-AG

Feeder KV- 11 / OUTGOING

AG Feeder with SDT

DATE	01-JUN-17	05-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.3429
2			.3429
3			.4287
4			.5144
5			.7716
6			.8573
11	.1715		
12	.1715		
13	.2572		
14	.2572		
15	.2572		
16	.2572		
17	.2572		
24		.2572	.3429
Max	.2572	.2572	.8573
Min	.1715	.2572	.3429
Avg	.2327	.2572	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 204 / KUSALI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.8573	.8573		.9431
2	.5335	.8573	.7716		.9431
3	.6859	.8573	.9431		1.0288
4	.8573	.8573	.8573		1.2003
5	1.0288	.8573			1.3717
6	1.1145	1.0288			1.3717
7	1.1145	1.2003			1.286
8	1.1145	1.2003			1.2003
9	.9431	1.0288			.5144
10	.7621			.6001	
11	.7621			.5144	.3429
12	.6097			.5144	
13	.5335			.4287	.3429
14	.6097			.5144	
15	.6859			.6001	
16	.6097			.6001	
17	.6859			.7716	.8573
18	.7621			1.0288	1.0288
19	.9907			1.0288	1.2003
20	.9907			1.1145	1.3717
21	1.1145			1.1145	1.2003
22	.8573			1.0288	1.0288
23	.8573			.9431	1.0288
24	.5144	.7621	1.0288		.9431
Max	1.1145	1.2003	1.0288	1.1145	1.3717
Min	.4572	.7621	.7716	.4287	.3429
Avg	.7998	.9507	.8916	.7716	1.0108

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 205 / ROHANGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3048			.2572
2	.381	.3429			.2572
3	.381	.3429			.2572
4	.381	.3429			.3429
5	.4572	.4287			.4287
6	.5144	.6859			.5144
7	.5144	.6001			.5144
8	.4572	.6001			
9	.5144	.3429			
10	.5144				
11	.4287				.4287
12	.4287				
13	.4287			.3429	.3429
14	.4287			.3429	.3429
15	.3429			.3429	.3429
16	.5144			.3429	.2572
17	.4287			.3429	.3429
18	.5144			.3429	.3429
19	.5335			.3429	.5144
20	.4572			.3429	.6001
21	.4572			.3429	.3429
22	.5144			.3429	.3429
23	.4287			.2572	.2572
24	.3429	.3429	.2572		.2572
Max	.5335	.6859	.2572	.3429	.6001
Min	.3048	.3048	.2572	.2572	.2572
Avg	.4445	.4334	.2572	.3351	.3644

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 206 / AMBADGAON (G)
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	01-JUN-17	02-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715		
2	.1715	.1715		
3	.1715	.1715		.1372
4	.2572	.1715		
5	.3429	.1715		
6	.3429	.4287		
7	.3429	.3429		.3429
8	.2572	.3429		.3429
9	.2572	.1715		.3429
10	.2572		.1715	.3429
11	.1715		.1715	
12	.1715		.1715	.3429
13	.1715		.1715	.3429
14	.1715		.1715	.3429
15	.1715		.1715	.3429
16	.1715		.1715	.3429
17	.1715		.1715	.3429
18	.1715		.2572	.2572
19	.2572		.2572	.3429
20	.1715		.2572	.3429
21	.1715		.1715	.2572
22	.1715		.1715	.2572
23	.1715		.1715	.1715
24	.1715	.1715		.4287
Max	.3429	.4287	.2572	.4287
Min	.1715	.1715	.1715	.1372
Avg	.2108	.2315	.1899	.3124

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 207 / WARUDI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.6859			.3429
2	.5335	.6097			.3429
3	.5335	.6097			.3429
4	.6859	.6859			.4287
5	.8383	.7621			.6001
6	.9145	.9907			.6859
7	.9145	.9431			.6001
8	.9145	1.0288			.5144
9	.9145	.7716		.5144	.3429
10	.5144			.4287	.3429
11	.5144			.4287	.3429
12	.5144			.5144	.5144
13	.4287			.5144	.5144
14	.4287			.5144	.5144
15	.4287			.5144	
16	.4287			.5144	.6859
17	.4287			.6859	1.0288
18	.6097			.8573	1.3717
19	.9145			.8573	1.5432
20	.7621			1.0288	1.5432
21	.8573			1.0288	.8573
22	.7716			.9431	.6859
23	.6859			.7716	.5144
24	.5144	.6859	.2572		.3429
Max	.9145	1.0288	.2572	1.0288	1.5432
Min	.4287	.6097	.2572	.4287	.3429
Avg	.6462	.7773	.2572	.6744	.6523

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 208 / COTTEX GINNING
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	07-JUN-17
HR	Load (MW)
24	.0857
Max	.0857
Min	.0857
Avg	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 209 / BAGADIYA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17	02-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715			.1715
2	.1715	.1715			.1715
3	.1715	.1715			.1715
4	.1715	.1715			.1715
5	.1715	.1715			.1715
6	.1715	.1715			.1715
7	.1715	.1715			.1715
8	.1715	.1715			.1715
9	.2572	.1715		.1715	.1715
10	.3429			.1715	.1715
11	.3429			.2572	.1715
12				.3429	.1715
13				.4287	.2572
14				.3429	.2572
15	.2572			.3429	.2572
16	.2572			.2572	.2572
17	.2572			.2572	.2572
18	.1715			.2572	.2572
19	.1715			.2572	.1715
20	.1715			.3429	.1715
21	.1715			.4287	.1715
22	.1715			.4287	.1715
23	.1715			.3429	.1715
24	.1715	.1715	.1715		.1715
Max	.3429	.1715	.1715	.4287	.2572
Min	.1715	.1715	.1715	.1715	.1715
Avg	.2041	.1715	.1715	.3086	.1929

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013430 / 33KV DABHADI

Feeder No / Name : 201 / DABHADI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6783	.6135	.6201	.6401	.5487	.6268	.4973
2	.7042	.6135	.6201	.7023	.6447	.6268	.4973
3	.7291	.6135	.6201	.823	.631	.6268	.57
4	.8478	.6135	.6201	.9145	.663	.6201	.6036
5	1.1065	.6935	.7802	1.4003	.663	.7973	.6783
6	1.4089	.9431	1.0288	1.6632	1.2407	.8573	1.1736
7	1.3272	1.0288	1.1317	1.0974	1.2431	1.0174	1.065
8	1.2929	.9536	1.1736	1.4632	1.3927	1.1022	.4915
9	1.0898	.8669	1.0174	1.1576	1.0898	1.0288	
10	.9431	.8573	.6706	.823	.6859	.9221	.9054
11	.9431	.9221	.6783	.924	.6201	.8478	.6882
12	.8669	.7716	.57	.8316	.5258	.6706	.6962
13	.7282	.7716	.6001	.8779	.5258	.4973	.6962
14	.7362	.7087	.6516	.6468	.5258	.6554	.6299
15	.6935	.7087	.6687	.6401		.6226	.57
16	.6935	.8669	.6687	.7392		.3481	.4915
17	.6935	.6859	.763	.8962	.6201	.4694	.8785
18	.5258	.6001	1.4003	1.1088		1.1022	.9831
19	.7545	.7716	1.4003	1.2803		1.2239	1.2071
20	1.0059	.6836	1.1203	1.386		1.4413	1.2266
21	.8573	.691	.924	1.2012		1.0277	.9724
22	.8573	.6379	.6535	.9335		.8192	.8288
23	.7802	.6201	.5914	.823	.7164	.6554	.6706
24	.6706	.6935	.6201	.5914	.5544	.6935	.4973
Max	1.4089	1.0288	1.4003	1.6632	1.3927	1.4413	1.2266
Min	.5258	.6001	.57	.5914	.5258	.3481	.4915
Avg	.8723	.7471	.8164	.9819	.7583	.8042	.7617

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013430 / 33KV DABHADI

Feeder No / Name : 202 / CHIKHALI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5544	.691	.6379	.763	.5601		.6722
2	.5601	.691	.6447	.7545	.6722		
3	.5373	.691	.6984	.7716	.8316		.7842
4	.7087	.7265	.6762	.8402	.8871		.8871
5	.9568	.7108	.8322	1.0174	.9425		.9979
6	1.182	.823	1.1831	1.4586			
7	1.1694	1.2174		1.5261			
8	1.1568	1.0059		1.3146			
9	.8453	.9665		1.0288			
10	.4161			.5601	.8745	.5601	
11	.3761	.4161		.3921	.8745	.5601	
12	.3761			.3361	.6687	.4858	.3978
13	.3761			.3326	.6687	.4744	.3932
14	.3761	.4207	.7468	.3292	.6173	.4687	.3932
15	.4252		.5544	.3292	.6173	.3841	.3978
16	.4252	.4835	.5601	.3881	.6173	.4858	.4527
17	.4252	.5316	1.0974	.4481	.3498	.5155	.6316
18	.5201	.5316	1.6804	.5544	.543	.5601	.5601
19	.823	.6762	1.6804	.8402		.8402	.9522
20	.9774	.6836	1.386	.9522		.9522	1.0082
21	.7802	.691	1.1203	.8871		.8962	.8962
22	.7802	.6379	.8402	.7842		.7842	.7842
23	.6762	.6379	.7392	.6722		.6722	.7282
24	.5544	.6836	.6379	.7545	.6099		.6653
Max	1.182	1.2174	1.6804	1.5261	.9425	.9522	1.0082
Min	.3761	.4161	.5544	.3292	.3498	.3841	.3932
Avg	.6658	.6958	.9244	.7515	.6890	.6171	.6825

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013438 / 33KV NANEGAON

Feeder No / Name : 201 / NANEGAON-AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0924	.0924	.0739	.12	.0943	.1132
2	.0686	.0924	.0924	.0739	.1372	.1132	.1132
3	.0686	.0739	.0739	.0924	.1372	.0943	.0943
4					.1372	.1132	.1132
5					.1715	.1132	.132
6					.2058	.1886	.1509
7					.3086	.2829	.3018
8					.3086	.3018	.2829
9					.3086	.2641	.2263
10	.2587	.2402	.0924				
11	.2772	.2772					
12	.2957	.2772					
13	.2772	.2218					
14	.2587	.2402		.1715			
15	.2772	.2402		.1715			***
16	.3142	.2587	.2218	.2058	.0566	.0566	.0924
17	.2772	.2772	.2772	.2058		.0566	.0739
18	.1109	.1109	.1109	.0514		.0754	.0924
19	.1109	.1109	.1109	.0686		.0754	.0924
20	.1294	.0924	.1109	.0686		.0754	.1109
21	.1109	.0924	.0934	.0686	.0754	.0943	1.1088
22	.0924	.0924	.0924	.0686	.0943	.0943	.0739
23	.0924	.0924	.0924	.0686	.0943	.0754	.0739
24	.0686	.0924	.0924	.0924	.12	.0754	.1132
Max	.3142	.2772	.2772	.2058	.3086	.3018	19.052
Min	.0686	.0739	.0739	.0514	.0566	.0566	.0739
Avg	.1754	.1653	.1195	.1058	.1625	.1247	1.1796

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013438 / 33KV NANEGAON

Feeder No / Name : 202 / NANEGAON (G)

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0739	.0924	.0739	.0857	.0754	.0943
2	.0686	.0924	.0924	.0739	.0686	.0754	.0943
3	.0686	.0924	.0924	.0924	.0686	.0754	.0943
4	.0686	.0739	.0739	.1109	.0857	.0943	.1132
5	.0857	.0739	.0924	.1478	.12	.1132	.1132
6	.1372	.1109	.1294	.1848	.1715	.1132	.132
7	.12	.1478	.1478	.1478	.1372	.1509	.1509
8	.12	.1478	.1663	.1294	.0857	.1132	.1509
9	.0857	.0924	.1478	.1294	.12	.132	.1132
10	.0924	.0924	.0924		.0754	.0943	.0924
11	.0924	.0924	.1109		.0566		.0924
12	.0924	.0924	.0924		.0566		.0924
13	.0739	.0924	.0924		.0566		.0924
14	.0739		.0924	.0686	.0566	.0566	.0934
15	.0924	.0924	.0739	.0857	.0566	.0754	.0739
16	.1109	.0924	.0934	.0857	.0566	.0566	.0739
17	.0739	.1109	.1109	.0857		.0754	.0739
18	.1109	.1109	.1109	.1029		.0943	.1109
19	.1294	.1294	.1294	.1029		.132	.1294
20	.1478	.1294	.1478	.1029		.1132	.1478
21	.1109	.1109	.1109	.0857	.0943	.1132	.1294
22	.0924	.1109	.0924	.0857	.1132	.0943	.0924
23	.0924	.0924	.0924	.0857	.0943	.0943	.0924
24	.0857	.0739	.0924	.0924	.0857	.0943	.0943
Max	.1478	.1478	.1663	.1848	.1715	.1509	.1509
Min	.0686	.0739	.0739	.0686	.0566	.0566	.0739
Avg	.0963	.1012	.1071	.1037	.0873	.0970	.1057

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013438 / 33KV NANEGAON

Feeder No / Name : 203 / SAIGAON

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2218	.1848	.1478			
2	.1715	.2587	.2218	.0924			
3	.1715	.2587	.2218	.0924			
4	.1715	.2772	.2427	.1109			
5	.2058	.2957	.2587	.1109			
6	.2743	.3142	.2772	.1109			
7	.4287	.2772	3.1417	.1294			
8	.2572	.3326	.2957	.0924			
9	.2058	.2218	.2772	.1109			
10					.0943	.1886	.0739
11					.0943	.2452	.0924
12						.2075	.0924
13					.1132	.2075	.112
14					.0943	.0566	.0924
15					.0943		.1294
16					.1698	.2075	.1109
17					.2829	.1886	.1294
24	.1372	.1848	.1848	.1848			
Max	.4287	.3326	3.1417	.1848	.2829	.2452	.1294
Min	.1372	.1848	.1848	.0924	.0943	.0566	.0739
Avg	.2195	.2643	.5306	.1183	.1347	.1859	.1041

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013441 / 33 KV SHELGAON

Feeder No / Name : 201 / SHELGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	1.2803	1.1088	1.1317	.6554	.2429	.9955
2	1.0974	1.2803	1.2012		.6554	.3277	1.0745
3	1.0974	1.3717	1.2803		.6554	.2486	1.1641
4	1.3717	1.3575	1.2936		.7373	.3315	1.1641
5	1.4632	1.448	1.4632		.7373	.3353	1.1641
6		1.4632			.7373	.4144	1.1517
7		1.4632			1.2289	.4096	
8					1.4746	.503	
9				.823	1.1469	.9221	
10	1.1469	1.1736		.905	.924	1.1203	.5601
11	1.3108	1.326	.724	1.0526	.924	.9335	.7316
12	1.3108	1.2431	.724	1.065	.823	.8488	.6401
13	1.2289	.8383	.8059	.9831	.823		.9145
14	1.2289	1.2431	.8059	.9831	.823	.9431	.0914
15	1.1469	1.1736		.9831	.924	.9431	.7316
16	1.2289	1.1603	1.0631	.9831	1.0164	1.0269	
17	1.065	1.0898	.8954	1.065	1.1088	1.0374	.9145
18	1.4632	1.1088			1.2936	1.307	1.2803
19	1.4632	1.4784	1.4937	1.2536	1.1088	1.307	1.4632
20	1.4632	1.448	1.4146	1.448		1.4937	1.4632
21	1.3717	1.448	1.307	1.448	1.2536	1.4003	1.267
22	1.2803	1.3717	1.1203	1.267	.5544	1.307	1.267
23	1.2803	1.2936	1.1317		.6401	1.1203	1.2803
24	1.0974	1.2803	1.2012	1.1317	.6554	.2429	.9335
Max	1.4632	1.4784	1.4937	1.448	1.4746	1.4937	1.4632
Min	1.065	.8383	.724	.823	.5544	.2429	.0914
Avg	1.2607	1.2882	1.1196	1.1015	.9087	.8159	1.0126

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013441 / 33 KV SHELGAON

Feeder No / Name : 202 / RAJEWADI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.6554	.4973	.7392	.7316		.7468
2	.5487	.7373	.5868	.7316	.7316		.8488
3	.5487	.7373	.503	.905	.9145		.9335
4	.8097	.7287	.5868	.905	.9831		1.0269
5	1.1469	.8097		1.0745	1.065		1.0269
6	1.3108	1.2003		1.2403	1.4632		
7	.9831	1.406		1.4022	.9831		
8	1.6194	1.3765			1.0974		
9	1.3108	1.186		1.2136	.9145		
10	.4915	.7316		.7468	1.0402		.5544
11	.4572	.7316		.4572	1.2003		.4096
12	.4572	.5544		.4572	1.1336		.3239
13	.4572	.6468			1.2289	.7316	.4915
14	.4572	.6468			1.1603	.8145	.4915
15	.4572	.6468	.7468		1.0402		.5487
16	.6335	.7392	.7468		.9945	.905	
17	.7316	.8316	.7468		.6706		
18	.9145	.8316		.823			
19	1.0974	1.2012	1.4937	1.267	.8316		.9145
20	1.1888	1.2936	1.3203	1.3575		1.4003	1.0974
21	1.0974	1.1088	1.3203	1.2803		1.2136	1.0974
22	.9145	.924	1.1317	1.0974		1.0374	.9145
23	.9145	.924	.9431	.9145		.8488	.9145
24	.5487	.7316	.503	.5544	.8192		.9335
Max	1.6194	1.406	1.4937	1.4022	1.4632	1.4003	1.0974
Min	.4572	.5544	.4973	.4572	.6706	.7316	.3239
Avg	.8186	.8909	.8559	.9537	1.0002	.9930	.7808

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013441 / 33 KV SHELGAON

Feeder No / Name : 203 / BAJARANG CRUSHER FEEDER HV Non-Express Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0183	.0189	.0189	.0189	.0189	.0189
2	.0189	.0183	.0189	.0189	.0189	.0189	.0189
3	.0189	.0175	.0189	.0189	.0189	.0189	.0189
4	.0189	.0177	.0189	.0189	.0189	.0189	.0189
5	.0189	.0183	.0189	.0189	.0189	.0189	.0189
6	.0189	.0183	.0189	.0189	.0189	.0189	.0189
7	.0189	.0183	.0189	.0189	.0189	.0189	.0189
8	.0189	.0183	.0189	.0189	.0377	.0189	.0189
9	.0189	.0183	.0189	.0189	.0566	.0189	.0189
10	.056	.0181	.0189	.0189	.0189	.0189	.0189
11	.0373	.0183	.056	.0377	.0566	.0189	.0377
12	.0189	.0362	.0189	.0377	.1494	.0747	.0747
13	.0177	.0934	.0189	.0754	.0566	.0189	.0189
14	.0532	.0189	.056	.0754	.0377	.0377	.0189
15	.0709	.056	.1494	.0747	.0754	.0747	.0754
16	.0532	.0934	.0189	.0747	.0189	.0747	
17	.0354	.056	.1307	.0747	.0189	.0934	.0377
18	.0366	.056		.0934	.0934	.0373	.0189
19	.0366	.0189	.056	.0747	.0377	.0189	.0377
20	.0366	.0189	.0189	.0187	.0189	.0189	.0189
21	.0183	.0189	.0189	.0189	.0189	.0189	.0189
22	.0183	.0189	.0189	.0189	.0189	.0189	.0189
23	.0183	.0189	.0189	.0189	.0189	.0189	.0189
24	.0189	.0183	.0189	.0189	.0189	.0189	.0189
Max	.0709	.0934	.1494	.0934	.1494	.0934	.0754
Min	.0177	.0175	.0189	.0187	.0189	.0189	.0189
Avg	.0290	.0301	.0343	.0376	.0369	.0305	.0262

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013445 / 33 KV KANDARI

Feeder No / Name : 201 / KANDARI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.1734	.2801	.3772	.2772		.2686
2	.2801	.1753	.3696	.3772	.2801		.2715
3	.3696	.2658	.4572		.2801		.2715
4	.4572	.2658	.5544		.3696		.3582
5	.5487	.4477		.5658	.462		.5316
6	.6401	.5373	.724	.7545	.5487		.7087
7	.724	.7011		.6602	.5487		
8	.724	.7164		.5544	.462		
9	.5544	.6602		.462	.3696		
10	.2829	.2801	.3467	.3734	.443		
11	.1886	.2772	.3506	.462	.4382	.2686	
12	.1886		.4031	.4572	.4477	.3582	
13	.2829	.2801	.4525	.4572	.4477	.3544	
14	.2829	.2772	.4525	.3696	.5373	.3582	
15	.2829	.1867	.4163	.3582	.5068	.2772	.1715
16	.2829	.1867	.4075		.5068	.2686	
17	.3772	.2772	.4477	.4572	.4887	.2686	
18	.4715	.3696	.3772	.3734	.3772	.3696	
19	.5658	.4572	.5658	.462		.462	
20	.5658	.462	.5658	.6401		.5544	
21	.4715	.462	.4715	.462		.462	
22	.3772	.3696	.3772	.462		.3734	
23	.3395	.3734	.3772	.3734		.2801	
24	.2715	.1715	.2801	.3772	.2801		.2686
Max	.724	.7164	.724	.7545	.5487	.5544	.7087
Min	.1886	.1715	.2801	.3582	.2772	.2686	.1715
Avg	.4087	.3641	.4339	.4684	.4248	.3581	.3563

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013445 / 33 KV KANDARI

Feeder No / Name : 202 / KHADAKWADI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.381	.462	.3048	.5258		.462
2	.3696	.381	.5487	.3858	.5144		.5487
3	.3696	.381	.6401	.3906	.5144		.5487
4	.4572	.381		.4744	.6783		.905
5	.5487	.6668		.6401	.9326		.9955
6	.5487	.9526		.9831	1.2289		.462
7	.6401	.7621		1.3108	1.5384		
8	.4715	.6668		1.4746	1.6004		
9	.462	.5716	.2801		1.3765	.2286	
10	.9374	.8069	.381	.3696	.2858	.1848	
11	1.1336	1.0136	.1905	.1886	.2858		
12	1.3108			.1886	.381		.381
13	1.2289	.9869		.1867	.381		.381
14	1.1469	.6668	.381	.3696	.381		.381
15	.9831	.7049	.381	.3734	.381	.2686	.0953
16	.9945	.7049	.381	.3696	.381	.3696	
17	.8097	.7049	.381	.3734		.3696	
18	.5716	.5544	.4763	.4668		.462	
19	.7621	.5601		.5487		.5487	
20	.6668	.462	.7621	.5601		.462	
21	.5716	.3734	.4763	.4668		.462	
22	.4763	.3696	.381	.3734		.3734	
23	.381	.2801	.381	.3696		.3734	
24	.2772	.381	.3525	.3048	.4515		.462
Max	1.3108	1.0136	.7621	1.4746	1.6004	.5487	.9955
Min	.2772	.2801	.1905	.1867	.2858	.1848	.0953
Avg	.6833	.5962	.4285	.4989	.6963	.3730	.5111

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013445 / 33 KV KANDARI

Feeder No / Name : 203 / WALHA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669	1.0669	.5487	.5716	.5544		.0943
2	1.1145	1.0936	.6401	.5716	.5487		.0943
3	1.2308	1.2651	.6401	.6668	.5544		.0943
4	1.3756	1.2803	.7316	.7621	.6401		.0934
5	1.4098	1.4575		.9526	.823		.0943
6	1.5718	1.6766		1.1431	.9145		.1867
7	1.6651	1.8442	1.1765	.9526	.9955		.1867
8	1.4098	2.0119	1.1888	.7621	.9145		.1867
9	1.3394	1.6766	.905	.5716	.7468		.1867
10	.5716	.5544		1.0574	1.3117		
11	.4763		1.1336	1.166	1.406		
12	.4763		1.2955	1.6004	1.6004		
13	.4763		1.3108	1.2689	1.1336		
14	.4763	.4572	1.3108	1.1822	1.4746		.3048
15	.4763	.4572	1.3108	1.2803	1.4746		.3858
16	.5716	.543	1.3927	1.4575	1.4746		.381
17	.6668	.6335	1.4918	1.5384	1.5565		
18	.7621	.7316	.7621	.5544	.7621		
19	.8573	.8402		.7316			
20	.7621	.7392	.9526	1.0269		.0934	
21	.6668	.7392	.7621	.7392		.0934	
22	.5716	.6401	.6668	.6401		.0934	
23	.5716	.6401	.5716	.5487		.0943	
24	1.0402	1.0802	.5544	.5716	.5601		.0943
Max	1.6651	2.0119	1.4918	1.6004	1.6004	.0943	.3858
Min	.4763	.4572	.5487	.5487	.5487	.0934	.0934
Avg	.9003	1.0204	.9673	.9299	1.0235	.0936	.1833

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013445 / 33 KV KANDARI

Feeder No / Name : 204 / UJJAINPURI FEEDER
Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.3772	.2743	.1734	.2686		.2715
2	.2801	.3772	.2772	.1753	.3582		.2686
3	.3696	.4715	.3658	.1772	.3544		.2715
4	.462	.4715	.3696	.1791	.4287		.3582
5	.5487	.5658		.362	.5144		.4477
6	.6401	.7545	.3696	.4525	.5144		.5316
7	.6335	.6602		.4525	.5935		
8	.462	.5658	.3696	.6335	.5935		
9	.462	.4715	.2772		.6135	.3467	
10	.3506	.3696	.2829	.4668	.3772	.3696	
11	.443	.462	.1886	.3696	.2829	.2743	
12	.4477		.1886	.3696	.2829	.2801	
13	.4525	.3658	.1886	.3696	.2829	.1886	
14	.4525	.4572	.1886	.2801	.2829	.1886	
15	.4525	.3658	.1886	.3734	.2829	.1886	
16	.4477	.3696	.2263	.3696	.2829	.1867	
17	.4572	.3696	.3772	.4572	.3772	.2801	
18	.4715	.2772	.3772	.462	.3772	.2801	
19	.5658	.4572	.6602	.5487		.3696	
20	.5658	.462	.5658	.7316			
21	.4715	.462	.5658	.4572			
22	.3772	.3696	.4715	.5487		.462	
23	.3772	.3734	.3772	.3696		.3734	
24	.3696	.3772	.2743	.2829	.2629		.2801
Max	.6401	.7545	.6602	.7316	.6135	.462	.5316
Min	.2801	.2772	.1886	.1734	.2629	.1867	.2686
Avg	.4517	.4458	.3375	.3940	.3858	.2914	.3470

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134002 / BHOKARADAN 33 KV

Feeder No / Name : 201 / TADEGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	1.2003	.3429		1.0288		1.1145
2	.6001	1.2003	.3429		1.0288		1.1145
3	.6001	1.2003	.5144		1.0288		1.1145
4	.7716	1.2003	.6859		1.2003		1.2003
5	1.2003	1.286	.6859		1.3717		1.6289
6	1.5432	1.3717	.6859		1.5432		
7	1.5432	1.4575	.8573		1.3717		
8	1.5432	1.3717	.8573		1.3717	.3429	
9	.9431	1.2003	.4287	.3429	1.2003	.3429	
10	.8573	.8573	.4287	.3429	.8573	.3429	
11	.8573	.6859	.5144	.3429	1.0288	.4287	
12		.6859	.5144	.3429	1.0288	.5144	
13			.5144	.3429	.8573	.5144	
14			.5144		.8573	.5144	.6859
15				.5144	.8573	.6001	.6859
16			.7716	.6001	.8573	.6859	.6859
17				.6859	.8573	.8573	.6859
18				.6859	.8573	.6859	.6859
19		.8573		.8573	.8573	1.286	.6859
20	1.286	.8573		1.0288	1.0288	1.6289	.6859
21	1.2003	.6859		1.0288		1.4575	.6859
22	1.1145	.6859		1.0288		1.286	.6859
23	1.0288	.6859		1.0288		1.2003	.6859
24	.6001	.6859	.6859				1.1145
Max	1.5432	1.4575	.8573	1.0288	1.5432	1.6289	1.6289
Min	.6001	.6859	.3429	.3429	.8573	.3429	.6859
Avg	1.0181	1.0098	.5841	.6552	1.0545	.7930	.8841

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134002 / BHOKARADAN 33 KV

Feeder No / Name : 202 / BHOKARDAN TOWN

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	1.6289	1.2003	1.4575	1.7147	1.3717	1.5432
2	1.7147	1.6289	1.2003	1.4575	1.7147	1.2003	1.5432
3	1.7147	1.6289	1.3717	1.4575	1.7147	1.3717	1.5432
4	1.7147	1.6289	1.3717	1.4575	1.7147	1.3717	1.5432
5	1.7147	1.7147	1.5432	1.5432	1.7147	1.3717	1.5432
6	1.7147	1.8004	1.5432	1.6289	1.7147	1.5432	1.5432
7	1.7147	1.8004	1.7147	1.6289	1.7147	1.7147	1.6289
8	1.7147	1.8004	1.8861	1.5432	1.7147	1.8861	1.6289
9	1.6289	1.7147	1.6289	1.5432	1.5432	1.8861	1.6289
10		1.7147	1.7147	1.5432	1.5432		1.4575
11	1.8861	1.5432	1.6289	1.6289	1.5432		1.4575
12	1.8861		1.7147	1.6289		2.1434	1.5432
13	1.8861	1.5432	1.8004	1.6289	1.8861	1.8861	1.5432
14	1.7147		1.8004	1.7147	1.7147	1.6289	1.6289
15	1.7147		1.8004	1.8861	1.7147	1.8004	1.6289
16	1.7147	1.5432	1.8861	1.8861	1.7147	1.8861	1.6289
17	1.7147	1.5432		2.0576	1.7147	1.9719	1.6289
18	1.7147	1.5432	1.8861	2.0576	1.7147	1.9719	1.6289
19	1.7147	1.8861	1.7147	2.0576	1.7147	1.8861	1.6289
20	1.8861	1.8861	1.7147	1.8861	1.7147	1.9719	1.6289
21	1.8861	1.7147	1.7147	1.7147	1.5432	1.8861	1.6289
22	1.8861	1.5432	1.5432	1.7147	1.3717	1.7147	1.6289
23	1.8004	1.3717	1.5432	1.7147	1.3717	1.7147	1.6289
24	1.7147	1.6289	1.2003	1.4575		1.2003	1.5432
Max	1.8861	1.8861	1.8861	2.0576	1.8861	2.1434	1.6289
Min	1.6289	1.3717	1.2003	1.4575	1.3717	1.2003	1.4575
Avg	1.7594	1.6575	1.6140	1.6789	1.6601	1.6991	1.5825

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134002 / BHOKARADAN 33 KV

Feeder No / Name : 203 / Sipora BZ

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.2003	.8573		1.0288		.8573
2	1.1431	1.2003	.8573		1.0288		.8573
3	1.1431	1.2003	1.0288		1.0288		.8573
4	1.3336	1.2003	1.0288		1.2003		.8573
5	1.5242	1.286	1.2003		1.3717		.8573
6	1.7147	1.3717	1.2003		1.3717		1.0288
7	1.5242	1.4575	1.3717		1.3717		1.1145
8	1.1431	1.1145	1.3717		1.3717		
9	.6859	1.0288	1.0288		1.2003	.2572	
10		.8573	.8573		.8573		
11		.8573	.8573			.3429	.3429
12	1.0288	.6859				.4287	.3429
13		.8573				.5144	.5144
14						.7716	.5144
15				.8573	.8573	.7716	.5144
16		.8573		1.0288	.8573	.7716	.5144
17		.8573		1.0288	.8573	.8573	.5144
18		.8573		1.0288	.8573	1.2003	.5144
19		1.2003		1.1145	1.0288	1.6289	.5144
20	1.4575	1.3717		1.0288	.6859	.8573	.5144
21	1.4575	1.3717		1.0288	.6859	1.0288	.5144
22	1.3717	1.2003		1.0288		1.3717	
23	1.3717	.8573		1.0288		1.2003	.5144
24	1.1431	1.2003	.8573				.8573
Max	1.7147	1.4575	1.3717	1.1145	1.3717	1.6289	1.1145
Min	.6859	.6859	.8573	.8573	.6859	.2572	.3429
Avg	1.2790	1.0950	1.0431	1.0193	1.0389	.8573	.6558

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134002 / BHOKARADAN 33 KV

Feeder No / Name : 204 / Malkapur

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5144	.1715	.2572	.2572	.1715	.2572
2	.5716	.5144	.1715	.2572	.2572	.1715	.2572
3	.5716	.5144	.1715	.2572	.2572	.1715	.2572
4	.7621	.6001	.3429	.2572	.3429		.2572
5	1.0479	.7716	.3429	.3429	.4287		.2572
6	1.1431	1.1145	.3429	.4287	.5144		.2572
7	1.1431	.8573	.5144	.5144	.5144		.3429
8	1.1431	.8573	.5144	.5144	.5144		.3429
9	.6001	.6859	.4287		.5144	.3429	.2572
10		.5144	.2572		.3429		.2572
11		.5144	.3429		.3429	.3429	.3429
12	.3429	.5144				.3429	.3429
13		.4287			.2572	.3429	.3429
14					.1715	.2572	
15				.5144	.1715	.4287	.2572
16		.3429		.5144	.1715	.4287	.2572
17		.3429		.5144	.1715	.5144	.2572
18		.3429		.5144	.1715	.6859	.2572
19		.5144		.5144	.2572	.9431	.2572
20	.6859	.3429		.4287	.1715	1.0288	.2572
21	.6859	.2572		.4287	.1715	.8573	.2572
22	.6001	.1715		.3429	.1715	.6859	.2572
23	.5144	.1715		.3429	.1715	.6001	.2572
24	.5716	.5144	.1715	.2572		.1715	.2572
Max	1.1431	1.1145	.5144	.5144	.5144	1.0288	.3429
Min	.3429	.1715	.1715	.2572	.1715	.1715	.2572
Avg	.7303	.5183	.3144	.4001	.2884	.4715	.2758

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134002 / BHOKARADAN 33 KV

Feeder No / Name : 205 / Fattepur

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2572	.3429		.2572	.3429	.6001
2	.2572	.2572	.3429		.2572	.3429	.6001
3	.2572	.2572	.5144		.3429	.3429	.6001
4	.3429	.2572	.6859		.3429	.3429	.6001
5	.5144	.4287	.6859		.3429	.5144	.6001
6	.8573	.6001	.8573		.3429	.5144	.6859
7	.8573	.7716	1.0288		.5144	.6859	.8573
8	.6859	.6859	1.0288		.6859	.8573	1.2003
9	.6001	.5144	.6859			.5144	.8573
10	.5144	.5144	.3429		.5144	.2572	.6859
11	.5144	.5144	.5144		.6859	.2572	.5144
12	.4287		.5144			.2572	.5144
13	.3429		.4287		.5144	.2572	.3429
14	.3429		.4287		.5144	.3429	.3429
15	.3429		.5144		.5144	.3429	.3429
16	.3429		.5144	.3429	.5144	.3429	.3429
17	.5144	.5144		.3429	.3429	.4287	.3429
18	.8573	.5144		.3429	.3429	.5144	.3429
19	1.0288	.8573		.3429	.3429	.6859	.3429
20	.6859	.8573		.3429	.5144	1.0288	.4287
21	.6859	.8573		.3429	.3429	.8573	.5144
22	.6001	.6859		.3429	.3429	.6001	.5144
23	.6001	.5144		.3429	.1715	.6001	.5144
24	.2572	.2572	.3429			.1715	.6001
Max	1.0288	.8573	1.0288	.3429	.6859	1.0288	1.2003
Min	.2572	.2572	.3429	.3429	.1715	.1715	.3429
Avg	.5287	.5324	.5749	.3429	.4164	.4751	.5537

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134002 / BHOKARADAN 33 KV

Feeder No / Name : 207 / Perjapur

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2572	.1715	.2572	.2572	.1715	.2572
2	.2858	.2572	.1715	.2572	.2572	.1715	.2572
3	.2858	.2572	.3429	.2572	.2572		.2572
4	.2858	.2572	.3429	.2572	.2572		.2572
5	.381	.3429	.5144	.3429	.3429		.2572
6	.381	.4287	.5144	.5144	.3429		.2572
7	.381	.4287	.5144	.5144	.3429		.3429
8	.2858	.4287	.5144	.5144	.3429	.3429	.5144
9	.2572	.3429	.4287	.5716	.3429	.3429	.3429
10	.2572	.5144	.3429		.3429	.3429	.2572
11	.2572	.5144	.1715			.3429	.2572
12	.2572	.5144	.2572			.3429	.2572
13	.2572	.4287	.2572		.2572		.2572
14	.2572		.2572		.1715		.2572
15	.2572		.3429	.2858	.1715	.2572	.2572
16	.2572	.4287	.3429	.2858	.1715	.2572	.2572
17	.2572	.5144		.2858	.1715	.2572	.2572
18	.2572	.5144	.3429	.2572		.2572	.2572
19	.2572	.5144	.4287	.2572		.5144	.2572
20	.4287	.5144	.5144	.2572	.1715	.5144	.2572
21	.3429	.3429	.4287	.2572	.1715	.4287	.2572
22	.2572	.3429	.3429	.2572	.1715	.3429	.2572
23	.2572	.1715	.3429	.2572	.1715	.2572	.2572
24	.2858	.2572	.1715	.3429		.1715	.2572
Max	.4287	.5144	.5144	.5716	.3429	.5144	.5144
Min	.2572	.1715	.1715	.2572	.1715	.1715	.2572
Avg	.2905	.3897	.3504	.3279	.2482	.3127	.2751

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134006 / 33 KV RAJUR

Feeder No / Name : 201 / KHAMKHEDA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715	.2858	.381		.1905
2	.1715	.1715	.2572	.2858	.381		.1905
3	.2572	.1715	.2572	.2858	.4763		.2858
4	.3429	.1715	.3429		.5716		.381
5	.4287	.1715	.4287		.6668		.4763
6	.5144	.3429	.5144		.7621		.4763
7	.5316	.5144	.6859		.6859		
8	.5658	.5144	.5144		.4763		
9	.6001	.4287	.3944		.362		
10			.381		.2667		
11			.2858	.381	.3429	.2858	
12			.2286	.1905	.4287	.3429	
13			.1905	.2858	.5144	.5144	
14	.3429		.2286	.381	.5487	.6001	.381
15	.381		.1905	.4001	.4801	.4287	.381
16	.2667		.1905	.3239	.3429	.3429	
17	.1905	.1905		.2858	.3429	.3601	
18	.2858			.4001		.4763	
19	.381	.6859		.4763		.6478	.1905
20	.381	.5716		.5716		.6859	.381
21	.381	.381	.1905	.6668		.6287	.381
22	.381	.2667	.1905	.5906		.5716	.1905
23	.381	.2286	.1905	.5716		.381	.1905
24	.1715	.1715	.1715	.2858	.4763		.2858
Max	.6001	.6859	.6859	.6668	.7621	.6859	.4763
Min	.1715	.1715	.1715	.1905	.2667	.2858	.1905
Avg	.3564	.3221	.3003	.3923	.4726	.4820	.3130

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134006 / 33 KV RAJUR

Feeder No / Name : 202 / Chandai Th

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.381	.4763	.381	.3429	.3429	.5144
2	.4763	.381	.4763	.381	.3429	.3429	.5144
3	.5716	.381	.5716	.381	.5144	.3429	.6001
4	.5716	.381	.7621	.381	.5144	.3429	.6516
5	.6668	.381	.9526	.381	.6001	.3429	.6859
6	.7621	.5716	1.1431	.381	.6859	.3429	.6173
7	.8573	.7621		.381	.9088	.5144	.6001
8	.7811	.9526	.5144	.5716	.8573	.5144	.5144
9	.5716	.7621	.4572	.4763	.9088	.2858	.5716
10	.5658	.7716	.6859	.6859		.2858	.381
11	.7716	.8573	.6001	.823		.2286	.1905
12	.8916	.7202	.7716	.5144		.1905	.1905
13	.6859	.6516	.8573	.6001		.2096	.2858
14	.9431	.6859	.6001	.7202		.2286	.2858
15	1.046	.9431	.4687	.823		.1905	.2858
16	.9602	.8745		.6001	.1905	.1905	.3239
17	.6859	.8573	.7716	.6687	.1905	.2096	.3429
18	.5716	.4191	.381	.5487	.1905	.381	.381
19	.381	.5525	.381	.4763	.1905	.8002	.381
20	.381	.5335	.381	.5716		.7621	.381
21	.381	.5144	.381	.6097		.7621	.381
22	.381	.4954	.381	.4954	.1905	.5716	.381
23	.381	.4763	.381	.4763	.1905	.381	.381
24	.4763	.381	.4763	.381	.3429	.1905	.3429
Max	1.046	.9526	1.1431	.823	.9088	.8002	.6859
Min	.381	.381	.381	.381	.1905	.1905	.1905
Avg	.6349	.6120	.5851	.5296	.4476	.3731	.4244

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134006 / 33 KV RAJUR

Feeder No / Name : 203 / Rajur Town

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.6859	.3658	.381	.3429	.3429	.3658
2	.3658	.3429	.3658	.381	.3429	.3429	.3658
3	.4207	.3429	.4572	.381	.4287	.3429	.4024
4	.4572	.3429	.4938	.381	.5144	.3429	.4572
5	.5487	.3429	.5487	.381	.5658	.3429	.5487
6	.567	.5144	.567	.381	.5144	.5144	.5853
7	.5487	.5144	.5121	.5716	.5144	.5144	.4938
8	.5487	.5144	.5121	.5716	.463	.5144	.4954
9	.5121	.5144	.4755	.4287	.4115	.5144	.4763
10	.4938	.3772	.439	.3772	.3772	.5144	.4572
11	.4801	.4115	.3772	.5487	.3429	.463	
12	.3601	.3601	.3601	.3772	.3601		
13	.4287	.4287	.3429		.3429		.4001
14	.4115	.3772	.4287	.3429	.3772		.381
15	.5144	.3772	.3086	.4287	.4287	.3429	.4191
16	.5487	.463	.2572	.4115	.4115	.463	.4763
17	.3944	.3429	.7202	.5144		.4287	
18	.5144	.4024	.2858	.5487	.3429	.463	.381
19	.5144	.4207	.381	.5487	.3429	.5144	.381
20	.5144	.4572	.381	.5144	.3429	.4973	.381
21	.3429	.4938	.381	.4973	.3429	.463	.381
22	.3429	.4572	.381	.4458	.3429	.4287	.381
23	.3429	.4572	.381	.4287	.3429	.3772	.381
24	.4024	.3429	.3658	.381	.3772	.3429	.4024
Max	.567	.6859	.7202	.5716	.5658	.5144	.5853
Min	.3429	.3429	.2572	.3429	.3429	.3429	.3658
Avg	.4559	.4285	.4204	.4445	.3988	.4319	.4292

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134006 / 33 KV RAJUR

Feeder No / Name : 204 / LONGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.381	.381	.5716	.3429	.5144	.3429
2	.2286	.381	.381	.5716	.3429	.3429	.3429
3	.2858	.381	.4763	.5716	.4287	.3429	.4287
4	.3429	.381	.5716	.5716	.5144	.3429	.5144
5	.381	.5716	1.0479	.5716	.5144	.3429	.6001
6	.4763	.8573	1.1431	.7621	.6173	.5144	.6859
7	.4382	.8573	1.0479	.7621	.6344	.5144	
8	.4191	.8573	.7621		.6001	.5144	
9	.381	.8573	.5906	.5716	.5316		.5716
10	.2401	.8573	.4287	.6001	.381		.3048
11	.3429	.8916	.5144	.7202	.2858		.3239
12	.5487	.703	.5487	.6516	.381		.381
13	.5144	.6173	.4287	.6001	.4763	.2858	.4191
14	.6001	.6001	.5316	.6859	.4572	.1905	.2286
15	.5487	.6859	.3601	.703	.4191	.2286	.2858
16	.5487	.7202	.4458	.5487	.4001	.2667	.2667
17	.6001	.8573	.5144	.5144	.381	.3239	.2477
18	.7621	.5716	.7621	.5144	.5716	.381	.5716
19	.7621	.7811	.7621	.5716	.5716	.6668	.5716
20	.5716	.7621		.6668	.5716	.8002	.7621
21	.381	.6668	.5716	.7049	.7621	.7621	.7621
22	.381	.5716	.5716	.5906	.5716	.5716	.7621
23	.381	.4763	.5716	.5716	.5716	.4763	.7621
24	.2286	.381	.381	.5716	.3429	.5144	.3429
Max	.7621	.8916	1.1431	.7621	.7621	.8002	.7621
Min	.2286	.381	.3601	.5144	.2858	.1905	.2286
Avg	.4414	.6528	.5997	.6161	.4863	.4449	.4763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134006 / 33 KV RAJUR

Feeder No / Name : 205 / TAPOWAN

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2572	.2572	.2572	.381	.2858	.4763
2	.2058	.2572	.2572	.3429	.381	.2858	.4763
3	.2572	.2572	.3429	.3429	.4763	.2858	.5716
4	.3429	.2572	.4287	.5144	.6668	.2858	.6668
5	.4287	.4287	.5144	.5144	.9526	.2858	.8573
6	.463	.4287	.5144	.5144	1.0479	.2858	1.086
7	.4801	.4287	.4115	.5144	.9335	.5716	.9526
8	.4287	.5144	.4287	.5144	.6668	.5716	.7621
9	.3772	.5144	.4115	.5487	.5525		.4763
10	.2858	.4763		.4763	.4287		.2667
11	.381	.381		.381	.3429		.381
12	.3429	.3429		.2858	.4287	.3429	.4763
13	.381	.2858		.3429		.4287	.6097
14	.4191	.3429		.381	.3429	.5144	.5716
15	.4763	.3239	.1905	.4191	.5487	.5487	.6668
16	.381	.2667	.2286	.3429	.5144	.6001	.6097
17	.2858	.2858	.2096	.3429	.3429	.6859	.724
18	.381	.5716	.381	.5906	.381	.4763	.381
19	.381	.6287	.381	.6097	.381	.6668	.5716
20	.381	.5716	.381	.6668		.724	.381
21	.381	.5525	.381	.6668		.6668	.381
22	.381	.5335	.381	.6097	.2858	.6287	.381
23	.381	.4763	.381	.5716	.2858	.5716	.381
24	.2401	.2572	.2572	.2858	.381	.2858	.4763
Max	.4801	.6287	.5144	.6668	1.0479	.724	1.086
Min	.2058	.2572	.1905	.2572	.2858	.2858	.2667
Avg	.3612	.4017	.3547	.4599	.5106	.4761	.566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134006 / 33 KV RAJUR

Feeder No / Name : 206 / CHANDAI EKKO

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715	.1715	.2858	.1905	.1905
2	.1715	.1715	.2572	.1715	.2858	.1905	.1905
3	.2058	.1715	.2572	.1715	.3429	.1905	.381
4	.2572	.1715	.3429	.1715	.381	.381	.5716
5	.3429	.4287	.4287	.3429	.6287	.5716	.6668
6	.4287	.4287	.4973	.3429	.743	.5716	.8002
7	.5144	.4287	.4801	.5144	.724	.7621	.6668
8	.5316	.4287	.3772	.5144	.5716	.7621	.5716
9	.6001	.4287	.2743	.4801	.381	.5716	.1905
10	.1334	.381		.1905	.3429	.5144	.1905
11	.1334	.3429		.2286	.4287	.4287	.2286
12	.1715	.1905		.2096	.3601	.3429	.2858
13	.1905	.2286		.1905	.3772	.3601	.2858
14	.2286	.1905		.1905	.4287	.3772	.2858
15	.2096	.2096	.2858	.2286	.4115	.3772	.381
16	.2858	.2477	.2667	.1905	.3601	.3601	.381
17	.3429	.1905	.2286	.1905	.3429	.2858	.5335
18	.381	.3429	.2858	.381		.381	.381
19	.381	.4191	.2858	.4763		.4763	.381
20	.381	.381	.2858	.4572		.4763	.381
21	.381	.3048	.2858	.4191		.381	.381
22	.381	.2667	.2858	.362		.381	.381
23	.381	.2286	.2858	.3048		.3429	.1905
24	.2058	.1715	.1715	.1905	.2858		.2858
Max	.6001	.4287	.4973	.5144	.743	.7621	.8002
Min	.1334	.1715	.1715	.1715	.2858	.1905	.1905
Avg	.3088	.2886	.3028	.2955	.4268	.4207	.3826

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134006 / 33 KV RAJUR

Feeder No / Name : 207 / AT&T TOWER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0829	.0829	.0829	.0953	.0829	.0829	.0829
2	.0829	.0829	.0829	.0953	.0829	.0829	.0762
3	.0829	.0829	.0829	.0953	.0829	.0829	.0762
4	.0829	.0829	.0829	.0953	.0829	.0829	.0829
5	.0829	.0829	.0829	.0953	.0829	.0829	.0829
6	.0829	.0829	.0829	.0953	.0829	.0829	.0829
7	.0829	.0829	.0829	.0953	.0829	.0829	.0829
8	.0829	.0829	.0829	.0953	.0829	.0829	.0829
9	.0829	.0829	.0829	.0829	.0829	.0829	.0829
10	.0829	.0829	.0829	.0829	.0829	.0829	.0829
11	.0829	.0829	.0829	.0829	.0829	.0829	.0829
12	.0829	.0829	.0829	.0829	.0829	.0829	.0829
13	.0829	.0829	.0829	.0829	.1326	.0829	.0829
14	.0924	.0829	.0829	.0829	.0829	.0829	.0953
15	.0829	.0829	.0829	.0829	.0829	.0829	.0953
16	.0829	.0829	.0829	.0829	.0829	.0838	.0953
17	.0829	.0829	.0829	.0829	.0829	.0829	.0953
18	.0829	.0829	.0953	.0829	.0829	.0829	.0953
19	.0829	.0829	.0953	.0829	.0829	.0829	.0953
20	.0829	.0829		.0829	.0829	.0829	.0953
21	.0829	.0762		.0829	.0829	.0829	.0953
22	.0829	.0829	.0953	.0829	.0829	.0829	.0953
23	.0829	.0829	.0953	.0829	.0829	.0829	.0953
24	.0829	.0924	.0829	.0953	.0829	.0829	.0829
Max	.0924	.0924	.0953	.0953	.1326	.0838	.0953
Min	.0829	.0762	.0829	.0829	.0829	.0829	.0762
Avg	.0833	.0830	.0852	.0876	.0850	.0829	.0875

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134008 / ANWA 33 KV S/S

Feeder No / Name : 201 / ANWA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	1.0974	1.086	1.0745	1.1203	1.0974	1.086
2	.3658	1.0974	1.086	1.0745	.9145	1.0974	1.086
3	.3391	1.0974	1.2536	1.0745	.9145	1.0974	1.086
4	.5601	1.0974	1.4022	1.0745	1.0136	1.2803	1.2536
5	.5487	1.267	1.5604	1.0745	1.3032	1.4632	1.4022
6	.8573	1.387	1.7147	1.7147	1.8652	1.5604	1.5604
7	.6935	1.7147	1.4022	1.4022			1.5604
8	.6859						
9	.7316						
10	.7316	.905	.8954	.5373	.5601	.5658	.5487
11		.905	.8954	.3506	.3772	.3772	.5487
12	.7316	.724	.7164	.6859	.3772	.5601	.5487
13	.7316	.7316	.7316	.5144	.3772	.5601	.5487
14	.7316	.7316	.7164	.4096	.3772	.5601	.5487
15	.905	.7468	.7164	.3277	.3772	.5601	.5487
16	.905	.7468	.7164	.3277	.3772	.5601	.5487
17	1.0974	.9145	.7164	.5087	.3772	.7468	.5487
18	1.3717	1.2536		1.0288	1.1317	1.086	1.0745
19	1.3717	1.5604	1.0745	1.6804	1.2803	1.4937	1.4022
20	1.3717	1.5604	1.448	1.307	1.3717	1.5604	1.5432
21	1.2803	1.2536	1.4022	1.4937	1.2803	1.4327	1.2003
22	1.0974	1.2536	1.0745	1.307		1.2536	1.0288
23	1.0974	1.086	1.0745	1.1203		1.086	1.0745
24	.2601	1.0974	1.086	.8954	1.1203	1.0974	1.086
Max	1.3717	1.7147	1.7147	1.7147	1.8652	1.5604	1.5604
Min	.2572	.724	.7164	.3277	.3772	.3772	.5487
Avg	.8141	1.1013	1.0842	.9538	.8693	1.0046	.9924

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134008 / ANWA 33 KV S/S

Feeder No / Name : 202 / JALGAON SAPKAL

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.3772	.3772		.1715		.3772
2	.4287	.3772	.3772		.3467		.3772
3	.4382	.3772	.3772		.3429		.5601
4	.4239	.3772	.5658		.4572		.7468
5	.5144	.5601	.5658		.6097		.9145
6	1.0288	.5601	.7468		.8573		
7		.5601	.9145		.8573		
8		.5601	.9145	.905	1.0288	.3772	
9	.3772	.5601	.7468		.6859		
10	.3772	.5601	.7164		.5601	.3772	.3658
11	.3772	.5601			.3772	.3772	.3658
12	.3772	.5601			.3772	.3772	.3658
13	.3772	.3772	.7164	.1867	.3772	.3772	.3658
14	.3772	.3772	.7164	.4287	.3772	.3734	.3658
15	.3772		.7164	.4334	.3772	.3734	.1829
16	.5601		.7164	.4334	.3772	.3772	.1829
17	.7316	.5658	.7164	.4287	.3772	.5601	.5487
18	.9145	.7468		.5201	.3772	.7468	.724
19	.9145	.9145			.5601	.7468	.7316
20	.7468	.9145		.7545	.905	.7468	.905
21	.5601	.7468		.9431		.7468	.7164
22	.5601	.7468		.9431		.7468	.7164
23	.5601	.3734		.7468		.5601	.7392
24	.4572	.3772	.3772		.1829		.3772
Max	1.0288	.9145	.9145	.9431	1.0288	.7468	.9145
Min	.3772	.3734	.3772	.1867	.1715	.3734	.1829
Avg	.5426	.5514	.6413	.6112	.5040	.5243	.5315

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134008 / ANWA 33 KV S/S

Feeder No / Name : 203 / WAKDI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1791	.5601	.7468	.924	.5601	.5601	.9145
2	.1715	.5601	.7468	.8954	.5487	.5601	.5658
3	.1715	.5601	.7468	1.0745	.5144	.5601	.5658
4	.3429	.5601	.9145	1.0745	.6859	.7316	.7468
5	.4572	.9335	1.086	1.0745	.9145	1.086	.9145
6	.743	1.0974	1.5604	1.4022	1.3546	1.3717	.9145
7	.6097	1.3717	1.4022	1.0745			.9145
8	.4287						
9	.1886						
10	.1886	.3772	.7164	.1734	.1886	.3772	.1829
11	.1886	.3772	.7164	.1715	.1886	.3772	.1829
12	.1886		.7164	.1696	.1886	.3772	.1829
13	.3772	.3772	.7164	.3277	.1886	.3772	.3658
14	.3772	.5601	.7164	.3429	.1886	.3772	.3658
15	.3772	.5601	.7164	.1829	.1886	.3772	.3658
16	.5601	.3772	.7164	.1524	.1886	.3772	.3658
17	.9145	.5601	.7164	.3467	.3772	.3772	.3658
18	1.2269	.7468		.8573	.9335	.7545	.724
19	1.2269	.9145		1.2136	1.0974	1.2536	1.0745
20	1.086	1.086	1.0745	1.0745	1.0974	1.2536	1.5432
21	.9145	.9145	1.0745	.9431	.9145	1.086	1.0745
22	.7316	.7468	.8954	.7545	.5601	.9145	1.0745
23	.5601	.7468	.905	.5601	.5601	.9145	1.0745
24	.1791	.5601	.7468	.8954	.5601	.5601	.905
Max	1.2269	1.3717	1.5604	1.4022	1.3546	1.3717	1.5432
Min	.1715	.3772	.7164	.1524	.1886	.3772	.1829
Avg	.5162	.6927	.8815	.7130	.5714	.6964	.6993

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134008 / ANWA 33 KV S/S

Feeder No / Name : 204 / KALYANI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.3772	.3772	.1867	.2801		.3772
2	.1715	.3772	.3772	.1867	.3658		.3772
3	.1715	.3772	.3772	.1867	.3048		.3772
4	.1753	.3772	.5658	.1867	.3048		.3772
5	.3429	.5601	.5658	.5601	.5144		.5601
6	.5373	.7392	.7468	.5601	.7468		.5601
7	.5201	.7468	.7468	.5487			.5601
8	.5487						
9	.3772						
10	.3772	.1886	.1867	.1715	.3772	.1886	.1829
11	.3772	.1886	.1867		.3772	.1886	.1829
12	.3772	.3772	.1867	.3429	.3772	.1886	.1829
13	.3772	.1886	.1867	.1715		.1886	.1829
14	.1886	.1886	.1867	.1524		.1886	.1829
15	.1886	.3772	.3734	.1524	.1886	.1886	.1829
16	.1886	.1886	.3734	.1543	.1886	.1886	.1829
17	.3772	.1886	.3734	.1734	.1715	.3772	.1829
18	.5601	.3772		.1753	.5601	.3772	
19	.5601	.5658		.4668	.5601	.3772	.5487
20	.5601	.5658	.3658	.3734		.5601	.7316
21	.3734	.5658	.1829	.3658		.5601	.5487
22	.3772	.3772	.1829	.3658		.3772	.5487
23	.3772	.3772	.1829	.3658		.3772	.3658
24	.1734	.3772	.3772	.1867	.2801		.3772
Max	.5601	.7468	.7468	.5601	.7468	.5601	.7316
Min	.1715	.1886	.1829	.1524	.1715	.1886	.1829
Avg	.3521	.3931	.3551	.2873	.3732	.3090	.3701

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134008 / ANWA 33 KV S/S

Feeder No / Name : 205 / HISODA BK

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.5601	.5658	.1867	.5487	.5601	.3772
2	.5601	.5601	.5658	.1867	.5144	.5601	.3772
3	.5487	.5601	.5658	.1867	.6097	.5601	.5601
4	.5373	.5601	.7468	.1867	.6097	.5601	.7468
5	.6935	.7316	.9145	.3658	.7716	.7316	.9145
6	1.0174	.7392	.9145	.3658	.9145	.7316	1.0974
7		.7468	1.086		.9145	.7316	1.086
8		.7316	1.086		.4572	.7316	.7468
9	.7316		.9145	1.0745	.9145		.3772
10	.7316		.7316	.5144	.5601	.3772	.1829
11	.7316			.3429		.3772	.1829
12	.7316	.3772		.3391	.5601	.3772	.1829
13	.7316	.3772	.5487	.3048		.3772	.1829
14	.7316	.3772	.5487	.4915	.5601	.3772	.1829
15	.7316		.5487	.5144		.3772	.1829
16	.7316		.5487	.463	.5601	.3772	.1829
17	.7316		.5487	.463	.5601	.5658	.3658
18	.7316	.3772		.5201	.5601	.7545	.5487
19	.9145	1.086			.7316	.9335	.5487
20	.7316	.9145	.3582	.7468	.905	1.086	.8954
21	.9145	.7468	.3658	.7468	.7545	.5601	.7164
22	.7316	.7468	.3658	.7468		.7468	.7164
23	.7316	.5658	.3658	.7468		.7468	.5487
24	.5601	.5601	.3772	.1867	.5487	.5601	.3772
Max	1.0174	1.086	1.086	1.0745	.9145	1.086	1.0974
Min	.5373	.3772	.3582	.1867	.4572	.3772	.1829
Avg	.7190	.6288	.6334	.4610	.6608	.5983	.5117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134015 / HASNABAD

Feeder No / Name : 201 / HASNABAD

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3391	.547	.3391	.5121	.2263	.3391	.2561
2	.5087	.547		.5121	.1494	.3391	.2561
3	.5935	.5658	.5087	.5121	.2263		.2926
4	.6783	.6036	.5935	.5487	.2452	.6443	.3292
5	.763	.7167	.763	.6584	.2801	.6783	.3658
6	.763	.9431		.7316	.3734	.6584	.439
7	.763	.9054		.8596		.5487	.4755
8	.763	.7922		.7865	.3961	.5121	.439
9	.5765	.7545	.4748	.7133	.3361	.4024	.3475
10	.3361	.6783	.2561	.2987	.6161	.6219	.5658
11		.6783	.3292	.3921	.4239	.5487	.4527
12		.407	.3658	.3734	.4578	.5121	.4481
13		.6783	.439	.3395		.5121	.415
14			.4024	.2926	.4748	.4755	.3772
15			.4024	.3292	.5087	.4755	.4481
16	.4207		.4024	.3361	.5087	.5121	.4904
17	.4294	.407	.439	.3772	.3052	.5487	.6036
18	.7545	.6783	.7865	.7356	.5935	.6584	.6036
19	.7733	.763	.8596	.8299	.6783	.8962	.7733
20	.7545	.763		.8299	.3391	.8413	.8299
21	.7545	.4239		.7468	.5087	.6584	.7545
22	.6413	.5087	.7316	.6413	.5087	.5853	.547
23	.5658	.5087	.5853	.6036	.3391	.5487	.547
24	.2883	.547	.4748	.5487	.4108	.3391	.2561
Max	.7733	.9431	.8596	.8596	.6783	.8962	.8299
Min	.2883	.407	.2561	.2926	.1494	.3391	.2561
Avg	.6035	.6389	.5085	.5629	.4048	.5590	.4714

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134015 / HASNABAD

Feeder No / Name : 202 / LATIFPUR

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3391	.2829	.3391	.2926	.1494	.1696	.1463
2	.3391	.2829	.3391	.2926	.1509	.1696	.1463
3	.3391	.3018	.5087	.2926	.1494	.1696	.1646
4	.5087	.3018	.5087	.3292	.168	.2035	.2195
5	.5935	.4715	.5935	.439	.2241	.2035	.2926
6	.5935	.5847		.5487	.415	.2926	.3841
7	.407	.5281		.6219		.439	.4938
8	.407	.4668		.5249	.5228	.5487	.439
9	.2713	.3961		.3658	.5093	.3292	.3475
10	.2241	.2543	.2561	.1867	.2075	.2195	.2263
11		.2543	.3292	.2829	.1696	.1829	.1886
12		.3052	.3658	.2641	.1865	.1463	.168
13		.2883	.439	.2987		.1463	
14			.3658	.2743		.1829	.2075
15			.2926	.2195	.1696	.2195	.2263
16	.3292		.2926	.2801	.1865	.2561	.2641
17	.3734	.3052	.3292	.2987	.3391	.2926	.2641
18	.3961	.3391	.4755	.3772	.4239	.439	.5281
19	.4715	.373	.567	.5415	.4239	.567	.7356
20	.4904	.4748		.5788	.2713	.5121	.8299
21	.4527	.3391		.4904	.3052	.439	.679
22	.3395	.3391	.439	.3734	.2713	.3292	.4527
23	.3206	.2883	.3292	.3361	.2883	.2926	.4338
24	.2713	.2829	.2713	.3292	.5093	.1696	.1463
Max	.5935	.5847	.5935	.6219	.5228	.567	.8299
Min	.2241	.2543	.2561	.1867	.1494	.1463	.1463
Avg	.3930	.3552	.3912	.3683	.2877	.2883	.3471

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134015 / HASNABAD

Feeder No / Name : 203 / BORGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3391	.2012			.415	.2035	.3658
2	.3391	.2195			.4108	.2543	.3658
3	.5087	.3174	.5087		.3921		.3658
4	.5087	.2614	.5087		.4481	.3391	.439
5	.6783	.3395	.6783		.5975	.3391	.5121
6	.6554	.4108			1.0642	.5121	.7865
7	.6783	.8413				.7499	.7316
8	.6783	.6401	.3391		.7922	.695	.6584
9	.3391	.5121		.6036	.5041	.439	.5487
10	.3018	.3391		.3018	.5847	.2561	.1886
11				.1886	.5087	.2561	.2829
12		.1696		.2452	.5087	.2926	.2241
13		.1696		.2829		.2926	.2241
14				.2452		.2561	.2427
15				.2829	.4239	.2561	.2801
16			.439	.3206	.4239	.2561	.2987
17	.3584	.3391	.5487	.4527	.3391	.2926	.3018
18	.6036	.5935	.7499	.5847	.5935	.3841	.4527
19	.7545	.6783	.8596	.8775	.6783	.8413	.6602
20	.5658	.6783		.8029	.1696	.7316	.9997
21	.4904	.3391		.6722	.3052	.5487	.7922
22	.4338	.3391	.567	.5281	.2035	.439	.4715
23	.3772	.3391	.3658	.5041	.1865	.3841	.4338
24	.1526	.2054	.2543		.9431	.3391	.3658
Max	.7545	.8413	.8596	.8775	1.0642	.8413	.9997
Min	.1526	.1696	.2543	.1886	.1696	.2035	.1886
Avg	.4868	.3967	.5290	.4595	.4997	.4069	.4580

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134015 / HASNABAD

Feeder No / Name : 204 / NIMGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1187	.2743	.3391	.2195	.3018	.2035	.2926
2	.1357	.2743	.3391	.2195	.3018	.2543	.2926
3	.1357	.2801	.3391	.2195	.3018	.5087	.2926
4	.1526	.2987	.3391	.2561	.3772	.5087	.3292
5	.1696	.415	.4239	.2561	.4854	.6783	.4755
6	.1865	.6161		.2926	.7356	.5121	.7316
7	.1357	.5853		.3292		.567	.8779
8	.1187	.5487		.2926	.4668	.5121	.6584
9	.3391	.439	.3391	.4024	.3395	.2926	.5121
10	.1886	.3391		.2263	.3174		.1509
11		.1696		.1886	.2713		.1509
12		.2543		.1698	.2883		.1886
13		.2374		.1886			.1867
14				.1698			.1867
15				.1886	.2543	.2195	.1867
16	.2829		.2561	.2452	.2883	.2561	.1867
17	.3921	.2883	.3658	.3018		.2561	.2075
18	.4715	.373	.5487	.3584	.5087	.2926	.3395
19	.6413	.4239	.5853	.5658	.5087	.567	.4904
20	.4904	.5087		.5601	.3391	.6584	.6602
21	.415	.3391		.415	.3391	.439	.5281
22	.3772	.3391	.4755	.3734	.3391	.3658	.3206
23	.3584	.3052	.3658	.3206		.2926	.3018
24		.2801	.2035	.2195	.3174		.2926
Max	.6413	.6161	.5853	.5658	.7356	.6783	.8779
Min	.1187	.1696	.2035	.1698	.2543	.2035	.1509
Avg	.2839	.3614	.3785	.2908	.3727	.4102	.3684

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134015 / HASNABAD

Feeder No / Name : 205 / KHADKI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1696	.1867	.1696	.1829	.4715	.2035	.4755
2	.1696	.2075	.1696	.1829	.4668	.1638	.4755
3	.2035		.2543	.1829	.1509	.2035	.4755
4	.2543	.2263	.3391	.1829	.4904	.2543	.5487
5	.2713	.2614	.3391	.2195	.5975	.3052	.695
6	.3052	.3547	.3391	.3292	.9335	.439	.8413
7	.5087	.5487		.567	1.0185	.7865	.9328
8	.5087	.5487	.6783	.4887	.8215	.7316	
9	.4239	.5121	.4239	.3658		.6219	
10	.4854			.415	.547	.1829	.1867
11				.3206	.4578	.2561	.2054
12		.5087		.2829	.4748	.3109	.2987
13		.3391		.2829	.4239	.2926	.2801
14				.3584	.4239	.2926	
15			.2926	.3772	.4239	.2926	.2241
16	.4668		.439	.3772	.4239	.3292	.2801
17	.5601	.5087	.6584	.4527	.5935	.4024	.3174
18	.7733	.5087	.9511	.5847	.6783	.5121	.7356
19	.8215	.5935	.9145	.8402	.763	.8596	.7356
20	.811	.6783		.8589	.4748	.9694	.8676
21	.7545	.4748		.7468	.3052	.6584	.7545
22	.5847	.4239	.6584	.5847	.2883	.5853	.547
23	.547	.4748	.567	.547	.3391	.5121	.5093
24	.1867	.5281	.1357	.1829	.4904	.3052	.4755
Max	.8215	.6783	.9511	.8589	1.0185	.9694	.9328
Min	.1696	.1867	.1357	.1829	.1509	.1638	.1867
Avg	.4635	.4380	.4581	.4131	.5243	.4363	.5172

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134015 / HASNABAD

Feeder No / Name : 206 / RAJALA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3391	.3292		.3658		.1696	.1829
2	.3391	.3206		.3658	.1698	.1696	.1829
3	.3391			.3658	.1698		.1829
4	.4915	.4108			.1886	.2035	.2195
5	.6783	.4108			.2641	.2035	.2926
6	.6783	.5415			.4294	.2926	.3841
7	.5087	.439				.439	.4755
8	.5087	.415	.3391		.4481	.2561	.3658
9	.3052	.2543			.3584	.2561	.2743
10	.1867	.2883		.1867	.1509	.1829	.1886
11		.3052	.2561	.1886		.1097	.1509
12		.2035	.3658	.2241	.1357	.0732	.1132
13		.2035	.2926	.2054	.0848	.0732	.1132
14			.2561	.2195	.0848	.0732	.1132
15			.1463	.2427	.0848	.0732	.1509
16	.3174		.1829	.2427	.1017	.0914	.1698
17	.2801	.2035	.2195	.2641	.3391	.1097	.1886
18	.415	.373	.4572	.2829	.5087	.3292	.3772
19	.5658	.4239	.567	.3772	.5087	.5304	.4527
20	.4715	.4748		.3206	.3391	.439	.6224
21	.415	.3391		.415	.3391	.4024	.4904
22	.3772	.3391	.5121	.3734	.4748	.3658	.4527
23	.3395	.3391	.439	.3174	.2035	.3658	.415
24	.3052	.3395	.3391	.3658	.5281	.2035	.1829
Max	.6783	.5415	.567	.415	.5281	.5304	.6224
Min	.1867	.2035	.1463	.1867	.0848	.0732	.1132
Avg	.4138	.3477	.3364	.2958	.2815	.2353	.2809

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134018 / DHAWDA

Feeder No / Name : 201 / DHAWDA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6001	.6859		.6516	.6859	.6516
2	.6516	.6859	.7202		.6859	.6516	.6173
3	.6687	.6687	.6687		.6687	.6173	.583
4	.6859	.8916	.8573		.8573	.6516	.6859
5	.8916	1.0631	.9431		.8916	.6859	.8916
6	1.046	.9602	.8916		.9431	.2743	.9602
7	.8916	.8916	.8745		.9602	.3429	.9259
8	.8573	.7716	.8745		.8573	.823	.8573
9	.823	.7202			.7202	.8402	.7716
10	.7545	.4287			.3772	.3429	.6859
11	.7888	.3429			.4287	.3772	.5144
12	.3258	.3258			.3772	.3429	.5487
13	.3086	.2915		.3429	.4115	.2915	.3429
14	.2915	.3601			.3429	.3086	.2915
15	.3086				.3429	.3258	.2572
16	.3086				.4115	.3258	.3429
17					.4801	.3429	.3772
18					.5487	.8573	.823
19	.9774				.8059	.9088	.8573
20	.9774				.9431	.8573	.9431
21					.8573	.7545	.8573
22						.6859	.823
23	.6859					.6687	.6859
24	.6344	.6687	.6173		.7202	.703	.6516
Max	1.046	1.0631	.9431	.3429	.9602	.9088	.9602
Min	.2915	.2915	.6173	.3429	.3429	.2743	.2572
Avg	.6782	.6447	.7926	.3429	.6492	.5694	.6644

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134018 / DHAWDA

Feeder No / Name : 202 / WALSAWANGI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.583	.6516		.6859	.6516	.583
2	.5658	.6173	.7716		.7716	.6859	.5144
3	.583		.8573		.8573	.7202	.4801
4	.6173		.9259		.9431	.7545	.5144
5	.8573	1.046	.9602		.9945	.7716	.5487
6	.8916	1.4746	.9774		1.0288	.8059	.583
7	.8573	1.5775	1.2346		1.3203	.6859	.6001
8	.9259	1.3717	1.2689		1.2346	.5144	.6173
9	.8916	1.286			1.1145	.5316	.5144
10	.8916	.9431			.9774	.583	.5144
11		.8573			.8916	.6173	.7545
12		.7888				.6859	.7202
13	.5144	.823		.3772	.7716	.823	.7202
14	.5316	.7888			.7202	.8573	.703
15	.5487					.5487	.7716
16	.583					.9602	.6859
17	.6173				1.286	1.0288	.7716
18	1.6975				1.7661	1.3717	1.4918
19	1.4575				1.7661	1.6461	1.5432
20	1.4575				1.5604	1.0974	1.6118
21	.7716				1.5432	1.0288	1.5432
22	.583					.9431	1.4403
23	.6859					.8573	1.1145
24	.5316	.6687	1.0974		.6001	.583	.583
Max	1.6975	1.5775	1.2689	.3772	1.7661	1.6461	1.6118
Min	.5144	.583	.6516	.3772	.6001	.5144	.4801
Avg	.8004	.9866	.9717	.3772	1.0965	.8231	.8302

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134018 / DHAWDA

Feeder No / Name : 203 / BHORKHEDA FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1029	.12		.1029	.0514	.0686
2	.12	.12	.1543		.1372	.0514	.0686
3	.1372	.12	.2058		.1372	.0514	.0686
4	.1715	.1372	.2401		.1372	.0686	.0857
5	.2058	.1372	.2401		.1543	.0686	.0857
6	.2229	.1029	.2743		.2058	.0686	.0857
7	.2572	.1543	.3429		.3429	.0514	.1029
8	.2401	.2058	.1886		.2058	.0686	.1029
9	.2572	.1715			.2401	.0857	.0686
10	.2058	.0343			.0514	.0686	
11	.2058	.0343			.0514	.0686	.0514
12	.0686	.0514			.0343	.0514	.0514
13	.0686	.0686		.0514		.0514	
14	.0686	.0686			.0343	.0686	.0514
15	.0686				.0343	.0686	.0514
16	.0686				.0514	.0686	.0514
17	.0857				.0343	.0686	.0686
18	.1715				.1372	.1715	.12
19	.1715				.1372	.2229	.1372
20	.1715				.0686	.1715	.1886
21					.0686	.1372	.1886
22	.1372						.1715
23	.1029					.1029	.1715
24	.0857	.0686	.0857		.1029	.0514	.0686
Max	.2572	.2058	.3429	.0514	.3429	.2229	.1886
Min	.0686	.0343	.0857	.0514	.0343	.0514	.0514
Avg	.1476	.1052	.2058	.0514	.1176	.0842	.0959

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134018 / DHAWDA

Feeder No / Name : 204 / JAIDEVWADI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3944	.3772	.3429		.3772	.3429	.3429
2	.3772	.4458	.3429		.4458	.3772	.3772
3	.3944	.5144	.4458		.5144	.4458	.4115
4	.4458	.583	.583		.4115	.5144	.4458
5	.5487	.6173	.6173		.6516	.5487	.5144
6	.703	.8059	.703		.703	.6173	.6687
7	.6173	.6859	.6687		.6516	.5658	.6516
8	.5144	.583	.583		.5144	.5144	.6001
9	.4458	.5144			.3772		.4801
10	.3429	.1886			.2572	.1886	.2058
11	.2229	.2058			.3086	.1715	.1715
12	.2401	.2572			.2572	.1715	.1715
13	.2229	.2058		.1715	.2572	.1715	.2058
14	.2058	.2401			.2401	.1543	.1715
15	.2229				.2401	.1372	.1543
16	.2401				.2572	.1029	.1715
17	.2572				.2572	.1543	.2058
18	.6173				.6344	.5144	.4458
19	.6173				.6344	.6344	.5144
20	.6173				.5487	.5144	.6344
21					.5144	.4801	.5144
22	.463					.4287	
23	.4458					.4115	.4458
24	.3772	.3944	.4115		.4115	.3772	.3944
Max	.703	.8059	.703	.1715	.703	.6344	.6687
Min	.2058	.1886	.3429	.1715	.2401	.1029	.1543
Avg	.4145	.4413	.5220	.1715	.4302	.3713	.3869

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134029 / PIMPALGAON (R) 33 KV

Feeder No / Name : 201 / Relgaon

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.5335	.5182	.381	.5335		.3353
2	.4268	.5792	.5792	.4115	.5335		.3201
3	.4877	.6097	.6401	.442	.7621		
4	.5182	.6401	.7316	.4572	.8383		.3963
5	.5487	.6859	.7773	.4725	.9145		.4268
6	.4572	.7164	1.0059	.4877	.945		
7	.3201	.6859	.5944		.884		
8	.2743	.5792	.4268	.503	.7926		
9	.2439	.5335	.3353	.4268	.2134		
10			.3658	.1829	.1981		
11			.3506	.2134	.1829		
12			.381				
13	.4877		.4115				
14	.5182		.381	.3048			
15			.4268	.3353	.381		
16		.503	.442	.381	.4572		.2743
17	.3506	.4877		.4115	.5487		.2896
18	.4572	.4572		.6859	.6859	.4877	.3048
19	.5487	.4725		.7926	.8078	.5182	.3201
20	.5487	.4268		.6859		.5335	.3353
21	.5639	.442	.4268	.5944		.5487	.3048
22	.5335	.4572	.381	.5335		.5792	.3201
23	.4572	.4877	.4268	.4572		.4877	.3353
24	.2439	.4572	.4572		.2896	.4572	.2896
Max	.5639	.7164	1.0059	.7926	.945	.5792	.4268
Min	.2439	.4268	.3353	.1829	.1829	.4572	.2743
Avg	.4404	.5419	.5030	.4580	.5864	.5160	.3271

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134029 / PIMPALGAON (R) 33 KV

Feeder No / Name : 202 / Pimpalgaon R

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2439	.2743	.2743	.4268	.5335		.4268
2	.2591	.3048	.3048	.381	.6097		.381
3	.2591	.3506	.3353	.3963	.6859		.4572
4	.2743	.381	.3658	.4268	.7621		.5335
5	.2743	.381	.3506	.4725	.945		.5182
6	.3048	.3963	.3658	.5639	.9907		.5182
7	.381	.3658	.5335	.6401	.7926		.5487
8	.4572	.3353	.5944	.7621	.7011		.5639
9	.4572		.6097	.8535			.4572
10	.4268		.6401				
11			.6401	.3201	.381		
12	.503	.5335		.2743			
13	.5335	.5182	.5182	.2286			
14	.5487		.4877				.2743
15				.3353	.442		.3048
16		.4725		.3048	.4115	.8383	.3353
17	.5792	.6249		.2591	.381	.884	.3658
18		.6097				.9145	.4268
19	.5487	.5792		.823	.9145	.8993	.4572
20	.7621	.5335				.8383	.4725
21	.6859	.4877	.4877	.7468		.8535	.4268
22	.6097	.4572	.4572	.7316		.7621	.442
23	.5792	.5182	.4877	.6706		.7316	.381
24	.1981	.1981	.442		.6249	.6401	.3658
Max	.7621	.6249	.6401	.8535	.9907	.9145	.5639
Min	.1981	.1981	.2743	.2286	.381	.6401	.2743
Avg	.4443	.4380	.4644	.5062	.6554	.8180	.4329

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134029 / PIMPALGAON (R) 33 KV

Feeder No / Name : 203 / LEHA/SHELUD FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.381	.4268	.4877	.6401		.7316
2	.3658	.4572	.4572	.5182	.6859		.7621
3	.381	.4268	.4725	.5792	.7621		.823
4	.4268		.4572	.6401	.9145		.8688
5	.4572		.4725	.7316	.9907		
6	.6097		.4877	.8078	1.0669		
7	.6859		.5487	.7316	.9602		
8	.7011		.5944	.6249	.8993		
9	.7164				.7621		
10	.381			.4572	.6706		
11	.4268			.6249	.6401		
12	.3658	.2743	.2591	.6859			
13	.381		.3506	.7468			
14	.3963			.6554			
15				.5792	.7773		.6097
16			.381	.5944			.6401
17		.5792		.6249	.9297		
18	.4115	.5335		.7621		.9907	.6554
19		.5182		.7926	1.0364	.9145	.6401
20	.6859	.5335		.8383		.9297	.6097
21	.7316	.5487	.4268	.8688		.0884	.5792
22	.6706	.5335	.442	.7926		.8383	.5487
23	.6097	.5182	.4268	.6554		.7773	.4877
24	.3353	.4877	.4725		.6249	.7621	.4572
Max	.7316	.5792	.5944	.8688	1.0669	.9907	.8688
Min	.3353	.2743	.2591	.4572	.6249	.0884	.4572
Avg	.5037	.4827	.4451	.6727	.8241	.7573	.6472

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134029 / PIMPALGAON (R) 33 KV

Feeder No / Name : 204 / PARADH

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7316	.6401	.823		.5792		.4877
2	.7621	.6859	.884		.6097		.5182
3	.8383	.7316	.9907		.6859		.5792
4	.9145		1.0212		.7621		.6097
5	.945		1.0364		.7926		.6401
6	.945	1.0364	1.0669		.8078		.6706
7	.945	.9755	.9297		.884		.6554
8	.9145	.8688	.8993		.945		.7316
9		.8383	.6706	.4572	.6859		
10	.3048		.6859	.503	.5639		.6859
11	.3201		.7011	.5335	.4572		.6249
12	.5182	.8383	.8383	.5487			.4572
13	.5335	.884	.884	.5792			.5182
14	.5639		.823	.6097			.3353
15			.8383	.6401	.6554		.4268
16		.0762	.8535	.6554	.6859		.4725
17	.6706	.823		.6706	.7011		.4877
18	.6401			.7621	.7621		.4572
19	.5944	.7621		.9145	.8688	.442	.4725
20	.7621	.7773		.9297		.5182	
21	.7316	.7316		.9297		.5792	.442
22	.8383	.7621		.884		.6097	.4572
23	.7621	.7468		.823		.6401	.4268
24	.7316	.7468			.5487	.6706	.3658
Max	.945	1.0364	1.0669	.9297	.945	.6706	.7316
Min	.3048	.0762	.6706	.4572	.4572	.442	.3353
Avg	.7127	.7603	.8716	.6960	.7056	.5766	.5238

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134029 / PIMPALGAON (R) 33 KV

Feeder No / Name : 205 / Awghadrao sawangi

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381		.381		.2286		.4268
2	.4572		.4268		.2743		.3353
3	.5335		.4572		.3353		.3048
4	.6097		.4268		.3506		.3658
5	.6859		.4572		.3658		.381
6	.7164		.4877		.3658		
7	.7621		.4725		.3963		
8	.6401		.4572	.3506	.4268		
9	.5487	.3048	.2743	.3353	.4115		
10	.2286		.2591	.381			
11	.2439		.2743	.4268	.381		.2591
12	.2134	.2896		.4115			.3048
13	.2286	.2743	.2743	.3658			.2743
14	.2439			.3506			.2896
15				.3506	.4268		.3048
16		.3048		.381	.5335	.4877	.2743
17		.3963		.442		.4725	.2896
18		.381		.6859	.8383	.4572	.2896
19		.3353		.7926		.5335	.3048
20	.5335	.3201		.7164		.5792	.3048
21	.6097	.4572		.6401		.6097	.3353
22		.4572		.5792		.6249	
23		.4572		.5335		.6401	.3201
24	.442				.1981	.5335	.3048
Max	.7621	.4572	.4877	.7926	.8383	.6401	.4268
Min	.2134	.2743	.2591	.3353	.1981	.4572	.2591
Avg	.4752	.3616	.3874	.4839	.3952	.5487	.3150

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134035 / 33 KV KEDERKHEDA S/S

Feeder No / Name : 201 / KEDARKHEDA ag1

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1021	.0251			
2		.1315	.0255			
3	.2286	.1315	.0255			
4		.1623	.04			
5		.1623	.0695			
6		.2115	.1614			
7		.2115				
8		.2115	.0133	.0762		
9	.1715	.2115	.013			
10				.0762	.2494	.1158
11					.2408	
12					.1957	
13					.2347	.1524
14					.2054	.1715
15			.2286		.208	.1524
16					.2229	.2667
17					.1614	.3048
23	.1021					
24			.0248			
Max	.2286	.2115	.2286	.0762	.2494	.3048
Min	.1021	.1021	.013	.0762	.1614	.1158
Avg	.1674	.1706	.0627	.0762	.2148	.1939

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134035 / 33 KV KEDERKHEDA S/S

Feeder No / Name : 202 / DEOLGAON TAD AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2858	.2096		.2315	.1905	
2		.3239	.2096		.2315	.1715	
3	.2667	.3239	.2286		.2688		
4		.381			.2688	.2096	
5		.381			.4024	.2858	
6		.4954			.415	.2785	
7		.5525			.4287	.2713	
8		.362		.2286	.4973	.2515	.1905
9		.2858			.3391	.1966	
10		.2858	.2286	.1905	.2286	.1143	
11		.3311	.2858	.1852			
12		.3353		.216			
13		.2591			.0953	.0953	
14					.1334	.1143	
15			.3239	.2401	.1715	.1715	
16			.4001	.2401	.1715	.1905	
17		.1981	.2667	.4049	.1905	.2286	
18	.2286	.2096		.2286	.2096	.2667	
19	.2286	.2286	.3048	.2286	.3048	.3048	
20	.2286	.3048		.2477	.3048		
21	.2286	.2477		.2477	.2286		
22	.1905	.2286		.2286	.2096		
23	.1905	.2096	.2286	.2286	.1905		
24			.2096			.1905	
Max	.2667	.5525	.4001	.4049	.4973	.3048	.1905
Min	.1905	.1981	.2096	.1852	.0953	.0953	.1905
Avg	.2232	.3115	.2633	.2396	.2629	.2078	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134035 / 33 KV KEDERKHEDA S/S

Feeder No / Name : 203 / KEDARKHEDA AG 2

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0381	.0293			
2		.0381	.0293			
3	.0762	.0762	.0297			
4		.0762	.0305			
5		.0953	.0457			
6		.1143	.0602			
7		.1334	.0762			
8		.0953	.0903	.0381		
9	.0762	.1715	.0892			
10				.0381	.0953	.0305
11					.0762	
12					.1677	
13					.1067	.0572
14					.0903	.0762
15					.0903	.0762
16					.0903	.0762
17					.0914	.1143
23	.0381					
24			.029			
Max	.0762	.1715	.0903	.0381	.1677	.1143
Min	.0381	.0381	.029	.0381	.0762	.0305
Avg	.0635	.0932	.0509	.0381	.1010	.0718

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134035 / 33 KV KEDERKHEDA S/S

Feeder No / Name : 204 / DEOLGAON TAD G

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1334		.1905	.0953	
2		.2477	.1334		.3239	.0953	
3	.1715	.2477	.1715		.4191		
4		.2858	.2096		.4763	.1334	
5		.2858	.381		.4763	.2096	
6		.381	.6097		.5144	.3048	
7		.4954	.4382		.4382	.3239	
8		.8402	.3239	.2286	.362	.3048	.2286
9	.1905	.2858	.2286		.2096	.2286	
10		.1524	.1524	.1905	.1524	.0953	
11		.1143	.1334	.1524	.0953		
12		.1143		.1143	.0953		
13		.1143			.0953	.0762	
14					.1143	.1334	
15			.1143	.1524	.1524	.1143	
16	.2096		.2286	.1524	.1715	.1715	
17	.2096	.1905	.1143	.1524	.2096	.1905	
18	.2096	.2667		.1905	.2858	.2096	
19	.1905	.381	.1905	.1905	.4191	.2286	
20	.1905	.381		.2096	.2477		
21	.1715	.2096		.2096	.2096		
22	.1715	.1334		.1334	.1715		
23	.1334	.1524	.1905	.1334	.1143		
24			.1334			.0953	
Max	.2096	.8402	.6097	.2286	.5144	.3239	.2286
Min	.1334	.1143	.1143	.1143	.0953	.0762	.2286
Avg	.1848	.2779	.2286	.17	.2585	.1771	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134035 / 33 KV KEDERKHEDA S/S

Feeder No / Name : 205 / KEDARKHEDA G

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4763	.4572		.6287	.5335	
2		.6287	.4572		.6668	.5335	
3	.4763	.6668	.5144		.8764		
4		.7282	.7049		1.0829	.5716	
5		.8589	1.0669		1.1763	.8573	
6		.9511	1.1812		1.251	1.086	
7		1.0242	.9717		.9694		
8			.9717	.8573	.9054	.8002	.8573
9		.6668	.6859		.6097	.7621	
10		.4382		.5716	.5716	.5144	
11		.4572	.2858	.4763	.4001		
12		.4572		.3429	.362		
13		.4572			.4191	.5335	
14					.362	.381	
15			.381	.4191	.3429	.4191	
16	.6097		.4763	.4191	.362	.3429	
17		.5716	.2858	.4763	.4382	.381	
18		.2858		.4763	.8573	.4191	
19	.6668	.381	.4954	.5335	.9907	.4191	
20	.6668	.6287		.6287	.9907		
21	.6287	.5906		.7049	.6478		
22	.5716	.5906		.5716	.5906		
23	.4382	.4572	.4763	.4763	.5716		
24			.4572			.5716	
Max	.6668	1.0242	1.1812	.8573	1.251	1.086	.8573
Min	.4382	.2858	.2858	.3429	.3429	.3429	.8573
Avg	.5797	.5956	.6168	.5349	.6988	.5704	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134044 / DANAPUR 33 KV S/S

Feeder No / Name : 201 / Surangli AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.1543			.1543		.1715
2	.2743	.2058			.1886		.1715
3	.3086	.1886			.1886		.1543
4	.3429	.2572					
5	.3772	.2915					
6	.4801	.3944					
7	.4973	.3429					
8	.3258	.4287	.6344	.1029			
9	.4287	.3086	.2572				
10					.4287		.1715
11					.4801		.1543
12					.463	.0686	.1372
13					.3944	.0686	.12
14					.3429	.1543	.1372
15					.3429	.1372	.12
16	.0343	.0686			.3944	.2058	.1372
17	.2058	.0686		.0857	.3944	.2058	.1543
18	.3086	.0857			.2572	.2058	.1886
19	.2572	.0857		.1715	.2572	.2229	.2058
20	.2058	.2915		.2572		.1715	.1715
21	.1543	.1886		.2401		.3086	.1886
22	.1543	.1543		.1886		.1715	.1715
23	.1372	.1372		.1372		.1372	.1715
24	.12	.1543	.1886		.1372		.12
Max	.4973	.4287	.6344	.2572	.4801	.3086	.2058
Min	.0343	.0686	.1886	.0857	.1372	.0686	.12
Avg	.2677	.2115	.3601	.1690	.3160	.1715	.1581

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134044 / DANAPUR 33 KV S/S

Feeder No / Name : 202 / KATHORA BAZAR GFSS

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3206	.3584	.3772	.3395	.3395		.3395
2	.2915	.3772	.3772	.3584	.3584		.3584
3	.3395	.415	.3772	.3772	.3584		.3772
4	.3772	.7167	.3772	.415	.3772		.3395
5	.4715	.6224	.3772	.5281	.5658		.2401
6	.5658	.6036	.5658	.5144	.7545		.3772
7	.5093	.679	.7356	.4715	.8676		.4715
8	.5847	.547	.7167	.5093			.5093
9	.4527	.415	.415	.4715	.7356		.415
10	.3018	.3772	.3206	.2641	.3395		.3772
11	.2829	.3258	.2829	.3018	.2829		.3395
12	.2452	.3018	.3018	.2452	.3018	.2829	.2641
13	.2829	.3206	.3018	.2452	.2641	.3018	
14	.3395		.3018	.2641	.3584	.2641	
15		.3206	.3772	.3018		.2829	
16	.5658	.3772		.2401	.3772	.415	
17	.5658	.5658		.4338	.5281	.5658	.3772
18	.7733	.6979			.7545	.5658	.6602
19	.5658	.7545		.811	.6224	.6602	.7545
20	.415	.5658	.4904	.8488		.679	.7545
21	.3772	.4904	.4338	.5658		.5487	
22	.3772	.4527	.3961	.4338		.4287	.3772
23	.3772	.4338	.3772	.3772		.3584	.3395
24	.3395	.3772	.3772	.3584	.3584		
Max	.7733	.7545	.7356	.8488	.8676	.679	.7545
Min	.2452	.3018	.2829	.2401	.2641	.2641	.2401
Avg	.4227	.4824	.4140	.4207	.4747	.4461	.4262

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134044 / DANAPUR 33 KV S/S

Feeder No / Name : 203 / Dagadwadi Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0857	.0686	.0514	.1543		.1029
2	.0686	.0686	.0686	.0514	.1715		.0686
3	.0857	.0514	.0686	.0686	.1715		.0857
4					.1715		.1029
5					.2572		.1372
6					.2401		.1372
7					.2743		.1543
8						.1372	.1543
9					.1886	.1715	.1715
10	.1543	.1886	.2572	.2572			
11	.1886	.1372	.2058	.1715			
12	.1886	.1715	.1715	.1543			
13	.2229	.1715	.2572	.1543			
14	.1715		.1372	.1715			
15		.1715	.1543	.1886			
16	.1372	.1543		.2058	.0514	.0343	
17	.1543	.1715		.1715	.0686	.0686	.0686
18	.0686	.0686		.1029	.0686	.0686	.0686
19	.0686	.1029		.0686	.0686	.0857	.0686
20	.0857	.1029	.0686	.1029		.0686	.0686
21	.0686	.12	.0686	.0857		.12	.0857
22	.0686	.0686	.0686	.0686		.0686	.0857
23	.0686	.0686	.0686	.0857	.0343	.0686	.0686
24	.0686	.0514	.0686	.0686	.1372		
Max	.2229	.1886	.2572	.2572	.2743	.1715	.1715
Min	.0686	.0514	.0686	.0514	.0343	.0343	.0686
Avg	.1140	.1150	.1237	.1238	.1470	.0892	.1018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134044 / DANAPUR 33 KV S/S

Feeder No / Name : 204 / Express Water Supply Only one consumer of WW with HT-IV
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8				.0343		.0343	.0343
9							.0343
10					.0343		.0343
11	.0343	.0343	.0343				.0343
12		.0343	.0343	.0343			.0343
13	.0514	.0343	.0343		.0343		.0343
14	.0343			.0343			.0343
15		.0343		.0343			.0343
16	.0343	.0343		.0343			.0343
17		.0343		.0343	.0343		.0343
18	.0343	.0343					.0343
19	.0343	.0343					.0343
20	.0343						.0343
21							.0343
22							.0343
23							.0343
24			.0343				
Max	.0514	.0343	.0343	.0343	.0343	.0343	.0343
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.0367	.0343	.0343	.0343	.0343	.0343	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134044 / DANAPUR 33 KV S/S

Feeder No / Name : 205 / Danapur GFSS

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3206	.3206	.3018	.3395	.3206		.3395
2	.3395	.2743	.3206	.3206	.2829		.3395
3	.3206	.3772	.3395	.3772	.3018		.3772
4	.3772	.5658	.3206	.5281	.2829		.3772
5	.3772	.7356	.3584	.6224	.3772		.3395
6	.7545	.7922	.5658	.6413	.5847	.547	.3772
7	.8865	.7545		.6036	.6602	.6602	.5658
8	.7167	.679	.6224	.5847	.7545	.415	.6602
9	.5658	.4338	.415	.415	.7167	.2452	.5658
10	.3584		.3395	.2829	.2641	.3395	.3772
11	.2829	.3772	.2263	.3018	.2452	.2641	.3395
12	.2829	.3206	.1886	.2641	.2263	.2452	.2641
13	.2263	.3395	.2075		.2829	.2075	.2075
14	.2075		.1886	.2829	.3018	.2452	.1886
15		.3584	.2263	.3206		.2075	.3206
16	.3018	.3584		.3018	.3395	.3395	.3018
17	.3584	.415		.3961	.3395	.5281	.3772
18	.7922	.4904		.6979	.3772	.6602	.5658
19	.547	.5658		.811	.6979	.7545	.7545
20	.5093	.5281	.5847		.6224	.5847	.7545
21	.4527	.415	.4715	.6602		.6602	.463
22	.3772	.3772	.415	.4527		.5281	.415
23	.3086	.3206	.3961	.3772	.3018	.4527	.3772
24	.3206	.2915	.3018	.3584	.2829		.3086
Max	.8865	.7922	.6224	.811	.7545	.7545	.7545
Min	.2075	.2743	.1886	.2641	.2263	.2075	.1886
Avg	.4341	.4587	.3574	.4518	.4078	.4380	.4149

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134044 / DANAPUR 33 KV S/S

Feeder No / Name : 206 / GODRI AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.1715		.1715
2					.2058		.1886
3					.3086		.2058
4					.3086		.0857
5					.3429		.1715
6	.0343				.4801		.1715
7					.6516		
8					.6687	.1715	
9					.6516	.1543	
10	.4287		.5316				
11	.3429		.5316				
12	.3601	.3429	.3429				
13	.3258	.1715	.4115				
14	.2743			.3429			
15		.4115	.3258	.4801			
16	.2229	.4115		.463			
17				.4115			
24					.1372		.12
Max	.4287	.4115	.5316	.4801	.6687	.1715	.2058
Min	.0343	.1715	.3258	.3429	.1372	.1543	.0857
Avg	.2841	.3344	.4287	.4244	.3927	.1629	.1592

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134044 / DANAPUR 33 KV S/S

Feeder No / Name : 207 / KARKHANA AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0857		.0686
2					.0686		.0686
3					.0686		.0857
4					.0686		.0686
5					.0857		.0686
6					.0857		.1372
7					.1372		.1029
8					.1372	.1372	.0857
9					.1372	.12	.1372
10	.12	.1886	.2401	.12			
11	.1715	.1886	.2229	.12			
12	.2058	.1715	.1543	.1029			
13	.1543	.1372	.1372				
14	.12			.12			
15		.1372	.1372	.1372			
16		.1372		.12			
17				.12			
24					.0686		.0686
Max	.2058	.1886	.2401	.1372	.1372	.1372	.1372
Min	.12	.1372	.1372	.1029	.0686	.12	.0686
Avg	.1543	.1601	.1783	.1200	.0943	.1286	.0892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134044 / DANAPUR 33 KV S/S

Feeder No / Name : 208 / KATHORA BAZAR AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	.3429	.5487	.5144	.3944	.6516	.3429	.2743
11	.5144	.4458	.6001		.6859	.3601	.2743
12	.6001	.5144	.583	.3429	.7202	.2401	.2743
13	.5144		.6687		.6001	.3258	.3258
14	.4801		.6173	.2401	.4801	.2743	.2743
15		.4115	.463	.3429	.5316	.3086	.3429
16	.2915	.5144			.6001	.4287	.3429
17		.4115		.5144	.6859	.3429	
21					.5316		
Max	.6001	.5487	.6687	.5144	.7202	.4287	.3429
Min	.2915	.4115	.463	.2401	.4801	.2401	.2743
Avg	.4572	.4744	.5744	.3669	.6097	.3279	.3013

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134060 / NALNI

Feeder No / Name : 201 / NALNI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3277	.2785	.3605	.3277	.3277	.2949	.2458
2	.3277	.2949	.3768	.3277	.3277	.2949	.2458
3	.3277	.3277	.3768	.3277	.3277	.3113	.2785
4	.4915	.3441	.4096		.3605	.3277	.2949
5	.6226	.3441	.4915		.6226	.4096	.3277
6	.6554	.5243	.6554		.8029	.4915	.4096
7	.7537	.6882	.7373		.9175	.6554	.4588
8	.6554	.5735	.6554		.9831	.639	.4588
9	.6226	.6226	.4096		.852	.4915	.4096
10	.639	.3605	.5898	.3932	.3605	.3605	.5243
11	.639	.3932	.5735	.4424	.3277	.3277	.3277
12	.6062	.4096	.5243	.3768	.2785		.213
13	.5243	.4096	.5243	.4588	.2949		.2294
14	.5407	.3768	.5243	.4588	.3113		.2294
15	.5735	.3605	.5407	.4915	.3113		.2294
16	.5571	.4096	.5571	.4752	.3277	.2785	.2294
17		.4915	.5735	.5079	.2785	.2949	.2949
18		.4915	.3605	.3768	.426	.4096	.3605
19	.4752	.5735	.5243	.5735	.5243	.4915	.5571
20	.426	.6554	.4915	.6718	.5735	.5735	.5898
21	.3277	.5735	.426	.5407	.4424	.4588	
22	.2949	.4915	.3768	.3605	.3932	.4096	
23	.2458	.3768	.3768	.3605	.3605	.3441	
24	.3768	.2622	.3605	.3441	.3277	.3277	.3277
Max	.7537	.6882	.7373	.6718	.9831	.6554	.5898
Min	.2458	.2622	.3605	.3277	.2785	.2785	.213
Avg	.5005	.4431	.4915	.4342	.4608	.4096	.3449

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134060 / NALNI

Feeder No / Name : 202 / PIMPALGAON BARAV

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3277	.2949	.3605		.4915	.3277	.3605
2	.3277	.2949	.3605		.4752	.3441	.3277
3	.3277	.3113	.3605		.4424	.3441	.3277
4	.4096	.3113	.4096		.4424	.3768	.3768
5	.4915	.3113	.4424		.4752	.4096	.4096
6	.5735	.4096	.4915		.4915	.4424	.4096
7	.7373	.5407	.5735		.4915	.4588	.4915
8	.6554	.5243	.4915			.3605	.4588
9	.6554	.5079	.4915		.2785	.3277	.4096
10			.2949	.3277	.7209	.3441	.3277
11		.1638	.213	.3113	.6554	.3605	.3113
12	.2949	.213		.1638	.5735	.3605	.2785
13	.3768	.2458	.3277	.2458	.5735	.4096	.3277
14	.3605		.3277	.2622	.4915	.4096	.3113
15	.3605		.3277	.2294	.5735	.4096	.2622
16	.3441		.2458	.2622	.5735	.4588	.2622
17	.3932		.2949	.3113	.7373	.3277	.2949
18	.5079		.3277	.3932	.3277	.4915	.2949
19	.6554	.5571	.5735	.5243	.4096	.5735	.3768
20	.6554	.7373		.7045	.4915	.5735	.6062
21	.5243	.6554		.6226	.3932	.4915	.4752
22	.5571	.6554		.5243	.3768	.4915	.4588
23	.5571	.5735		.4915	.3441	.4915	.4096
24	.3277	.2949	.3441		.4915	.3277	.4096
Max	.7373	.7373	.5735	.7045	.7373	.5735	.6062
Min	.2949	.1638	.213	.1638	.2785	.3277	.2622
Avg	.4737	.4224	.3820	.3839	.4922	.4130	.3741

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134060 / NALNI

Feeder No / Name : 203 / KHAPERKHEDA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1311	.1311	.1311		.213		.1966
2	.1638	.1147	.1311		.1966		.1966
3	.1638	.1638	.1475		.1802		.1966
4	.2458	.1966	.1802		.1966		.2294
5	.3277	.213	.2458		.2458		.2622
6	.4096	.3277	.3277		.2622		.2949
7	.5735	.3768	.4915		.2622		.2949
8	.5735	.3768	.4424		.2785		.2949
9	.4915	.3932	.4096	.0983	.1802		.1966
10	.1311	.1147	.1311	.1147	.3605		.1638
11	.1475	.1311	.1311	.0492	.3932	.2458	.1475
12	.1311	.1311	.1311	.0492	.4096	.2458	.1311
13	.1475	.1475	.1311	.0492	.4424	.2622	.1475
14	.1638		.1311	.0492	.426	.2949	.1802
15	.1475		.1311	.0492	.4915	.2949	.1966
16	.1475		.1311	.0655	.4752	.2949	.1802
17			.1311	.0983	.4588	.0983	.2622
18			.1966	.1802	.1966	.2458	.1311
19		.2622	.3277	.2294		.3277	.2949
20	.2458	.3277	.2458	.2458		.2949	.0983
21	.2294	.2785		.2622		.2458	.2622
22	.2294	.2458		.2458		.1966	.2458
23	.213	.1802		.1802		.1966	.2294
24	.0983	.0983	.1311		.1802		.1966
Max	.5735	.3932	.4915	.2622	.4915	.3277	.2949
Min	.0983	.0983	.1311	.0492	.1802	.0983	.0983
Avg	.2434	.2216	.2122	.1311	.3079	.2496	.2096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134064 / 33 kv Pimpalgaon KO

Feeder No / Name : 201 / Pimpalgaon Ko

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.7316	.6554	.6401	.3048		.3353
2	.6859	.7164	.6401	.6401	.381		.3506
3	.7621	.7621	.6859	.6859	.4115		.381
4	.8383	.8383	.7926	.7621	.4572		.4115
5	.9907	1.0212	1.0059	.8535	.5335		.5182
6	1.0212	1.0517		.9907	.6859		.7621
7	1.0517	1.0669			.5792		.7773
8	.9297	.945	.884		.5487		
9	.7926	.8535			.4877		.5335
10	.3506	.3353	.3963		.5487		.5792
11	.3353	.381	.3658				.3048
12	.3048	.381		.0914			
13	.3201	.4115	.381	.0762			
14	.3048	.2439	.3963	.0762			.4115
15	.2896	.2896	.3048	.1067			.3963
16	.2896	.4115	.381	.4115		.3353	.4572
17		.381	.4572	.4725	.5639	.5792	.381
18	.6859	.823	.7926	.7621		.6706	.5182
19	.9907	1.0059	1.0212	.9755	1.0517	1.0364	1.0364
20	.823	1.0364	.945	1.0364		1.0669	.884
21	.7468	.823	.7621	.9145			.6859
22	.7621	.7164	.6706	.7926		.7164	.6859
23	.7621	.7011	.6249	.7926		.6706	.5335
24	.6554	.7316	.6706	.6554	.2591		.2743
Max	1.0517	1.0669	1.0212	1.0364	1.0517	1.0669	1.0364
Min	.2896	.2439	.3048	.0762	.2591	.3353	.2743
Avg	.6667	.6941	.6417	.6177	.5241	.7251	.5342

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134064 / 33 kv Pimpalgaon KO

Feeder No / Name : 203 / Vazirkheda

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219	.1067	.1219	.1219	.3048		.2896
2	.1219	.1219	.1372	.1372	.3353		.3048
3	.1524	.1524	.1524	.1372	.4115		.3353
4	.1829	.1829	.1829	.1524	.4725		.3658
5	.2134	.2286	.2439	.1829	.6097		.5487
6	.2743	.3048		.2134	.7773		.6859
7	.3963	.4572		.2743	.7164		.823
8	.4725		.3963	.3201	.7316		
9	.381	.4115	.3658	.3048	.5487		
10	.3048	.2134	.2286	.4268	.3201		
11	.2896	.1372	.2286	.3048	.3201		
12	.2286	.1524			.2439		
13	.2286	.1372	.2743	.2134	.2439	.1219	.1067
14	.2439		.2591	.2743	.2591	.1524	
15	.2591	.2286	.2286	.2439	.2134	.2286	.1067
16	.2439	.2591	.2286	.2591	.1981	.1677	
17	.2591	.3353	.3506	.2591	.2439	.1829	.1677
18	.4115	.4572	.4572	.4877		.3048	.2439
19	.5335	.5182	.5182	.4572	.5182	.4572	.4572
20	.5487	.5944				.7316	.7164
21	.381	.3963	.3353	.4572		.4877	.4725
22	.3201	.3353	.3048	.3658		.381	.381
23	.3048	.3048	.2743	.2896		.2743	.3506
24	.1219	.1067	.1219	.1219	.2896		.2743
Max	.5487	.5944	.5182	.4877	.7773	.7316	.823
Min	.1219	.1067	.1219	.1219	.1981	.1219	.1067
Avg	.2915	.2792	.2705	.2730	.4083	.3173	.3900

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134065 / MALKHEDA

Feeder No / Name : 201 / AVANA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	.6036	1.0974	.9431	.3772		.5487
2	1.1584	.6036	1.1403	.9242	.3772		.6516
3	1.2357	.7167	1.2127	.9431	.3772		.7522
4	1.3253	.7545	1.2536	.9242	.3772		.985
5	1.379	.9054	1.2894	1.0374	.4338		1.0208
6	1.4148		1.4148	1.1694	.7545		1.0745
7				1.226	.9431		
8					.7545		
9	.7392	.7167		.2452	.547		.1829
10	.6979	.5792	.2829	.1792	.7167		
11	.6036	.5792	.2452	.5658	.5847		.7733
12	.4904	.6335	.6036	.6036	.5847	.3326	
13	.5281	.4887	.4715	.3018	.6413	.3961	
14	.3961		.4904	.3772	.6036	.6979	.7356
15	.3772			.4338	.7167	.6979	.7167
16	.547	.5014	.5658	.4338	.6602	.7356	.6979
17	.5093	.5729		.5093	.7167	.8299	.7167
18	1.0185	.9055		.7922		.9425	1.0374
19	1.0562	1.0349		.9431		1.3306	1.1317
20	.9054	1.46	.9431	1.0374		1.46	1.0374
21	.8299	1.4415	.9431	.8676		1.4449	.9619
22	.7922	1.4045	.9431	.7922		1.4266	.9431
23	.7167	1.3306	.9808	.7545		1.3306	.8488
24	1.2752	.6036	1.2071	.9431	.3772		.5121
Max	1.4148	1.46	1.4148	1.226	.9431	1.46	1.1317
Min	.3772	.4887	.2452	.1792	.3772	.3326	.1829
Avg	.8679	.8335	.8873	.7368	.5858	.9688	.8068

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134065 / MALKHEDA

Feeder No / Name : 203 / IBRAHIMPUR

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.2829	.2561	.2641	.6224	.5281	.5544
2	.394	.3395	.2896	.2641	.6224	.5281	.6584
3	.4835	.3961	.3439	.2829	.6413	.5658	.724
4	.6516	.4527	.4119	.3206	.6602		.9492
5	.724	.4527	.5138	.415	.6602		1.0745
6	.7701	.6979	.6805	.4715	1.1317		1.379
7	.7602	.679	.7343	.5281	1.1883		
8	.6335	.7167	.6697	.7356	1.1317		1.2308
9	.5611	.6224	.5973	.5847	.7922		.9328
10	.3584	.4163	.4715	.4973	.5658		.2829
11		.3077	.2829	.3772	.5658		.2829
12		.3258	.3206	.3395	.3395	.2772	.2829
13		.3077	.3206	.3961	.3395	.2829	.2452
14			.3584	.415	.3395	.3206	.2263
15		.2896	.3772	.4527	.3772	.3395	.2263
16		.3403		.4338	.3584	.3018	.2829
17		.4805		.5281	.3772	.3772	.3206
18		.6653		.6036	.4904	.4435	.4904
19	1.0185	.924	.9431	.9431	.8676	.7762	.8676
20	.811	.8501	.8865	.9431		.9979	.8488
21	.7167	.7392	.8488	.7545		.8316	.811
22	.679	.5914	.7545	.6602	.7167	.7133	.7545
23	.6413	.5544	.7167	.6224	.5658	.6653	.679
24	.2587	.2641	.1829	.2452	.6224	.5658	.6335
Max	1.0185	.924	.9431	.9431	1.1883	.9979	1.379
Min	.2587	.2641	.1829	.2452	.3395	.2772	.2263
Avg	.6119	.5085	.5219	.5033	.6353	.5322	.6408

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134001 / 33KV JAFRABAD

Feeder No / Name : 201 / ALAND

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.703	1.004	.9717	.4049	.3563	.2915	.3239
2	.7499	1.0526	1.0526	.4534	.3725	.2591	.3563
3	.9488	1.1336	1.1336	.4858	.4049		.4049
4	1.0957	1.2146	1.166	.4858	.4858		.4858
5	1.448	1.2955	1.3441	.5668	.4858	.4144	.5668
6	1.5699	1.3603	1.4575	.6154	.6802	.6478	.6802
7	1.5546	1.2955	1.3927	.4858	.6802	.5668	.4858
8	1.5851	1.3441	1.3927	.3725	.3315	.4534	.5801
9	1.6194	1.3927	1.3927	.2591	.2439	.2896	.4049
10		.2012	.2753	.9482	1.1294	1.0235	.4534
11		.1341	.2105	1.0987	1.46	1.0848	.4858
12		.1174		1.2041	1.4266	.9957	.4049
13		.1509	.2429	1.2191	1.4148	1.0084	.4372
14		.1296	.1781	1.1145	1.4413	1.1336	.4049
15		.1943	.2429	1.1174	1.5384	1.1336	.4214
16	.4515	.2267	.2591	1.1822	1.4089	1.166	.4666
17	.5312	.4049	.3725		1.4251	1.1498	.4816
18	.502	.5506	.5992	.3725	.4049	.4534	.4572
19	.5992	.5182		.3725	.6964	.6133	.5312
20	.502	.5182		.4534		.5182	.4696
21	.4858	.4807	.5344	.502	.4696	.4049	.3725
22	.4534	.4049	.4858	.4858	.4372	.3725	.3725
23	.4049	.4049	.4049	.4049	.3725	.3401	.3563
24	1.1717	.9717	.9717	.4049	.4049	.3239	.3239
Max	1.6194	1.3927	1.4575	1.2191	1.5384	1.166	.6802
Min	.4049	.1174	.1781	.2591	.2439	.2591	.3239
Avg	.9098	.6876	.7658	.6526	.7857	.6657	.4470

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134001 / 33KV JAFRABAD

Feeder No / Name : 202 / JANEFAL

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4144	.2486	.2486		.1658		.0166
2	.4475	.2984	.2652		.1989		
3	.6299	.3315	.3149		.2486		.0166
4	.7293	.4144	.4144		.3315		.0166
5	.8619	.4973	.5801		.4144		.0166
6	.9779	.6299	.8288		.5636		.0166
7			.6299		.5636		.0166
8					.8453	.4973	
9				.4475	.8288	.4144	.0166
10	.5636	.5304	.4144	.2486	.2155	.2984	.0166
11	.6299	.3315		.1492	.1989	.1658	.0166
12	.3647	.3149	.4807	.116	.1492	.1658	.0166
13	.3315	.3149	.3149	.116	.1492	.1823	.0166
14	.3315	.2321	.2652	.1357	.1658	.1658	.0166
15	.2984	.2818	.2984	.1326	.1823	.1658	
16		.2486	.4475	.1658	.1989		
17		.2984	.4475	.2155	.2652	.1658	
18		.4475	.4807	.1326	.4641		
19		.3978		.4144	.5801	.0166	.2486
20	.3481	.4475		.4807		.0166	.2652
21	.3315	.3978		.3978		.0166	.2155
22	.3315			.2818		.0166	.1658
23	.2984	.3149		.2486		.0166	.1492
24	.2652	.2486	.2486		.1492		.0166
Max	.9779	.6299	.8288	.4807	.8453	.4973	.2652
Min	.2652	.2321	.2486	.116	.1492	.0166	.0166
Avg	.4797	.3613	.4175	.2455	.3439	.1646	.0700

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134001 / 33KV JAFRABAD

Feeder No / Name : 203 / BHARAJ

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4641	.2984	.3315	.3315	.3315	.2486	.2984
2	.4973	.3315	.3647	.3647	.3315	.2486	.3315
3	.5304	.4144	.4144	.4144	.3647		.4144
4	.6299	.4641	.4973	.4475	.3978		.4641
5	.779	.5138	.5801	.4641	.4475		.4973
6	.779	.6299	.6464	.4973	.4973	.5967	.5801
7	.9116	.7127	.7127	.3315	.4144	.4144	.5801
8	.8951	.7127	.5801	.2984	.2486	.3315	.5304
9	.7459	.547	.5967	.1658	.2486	.3481	.431
10	.0995	.1865	.2486	.3647	.5138	.3149	.4144
11	.0995	.2652	.2486	.4144	.7127	.2486	.3315
12	.0332	.2984	.2486	.5801	.779	.3481	.2486
13	.0995	.1823	.2818	.4321	.5138	.3647	.2155
14	.0995	.2652	.2652	.5636	.5967	.5967	.3315
15	.0995	.3978	.4807	.7293	.5138	.5967	.1823
16			.2652	.6299	.6133	.5967	.2818
17	.2984	.2652	.3315	.7127	.7127	.4973	.3481
18	.4641	.2321	.4144	.3978	.5636	.4144	.2984
19	.4475			.5801	.4641	.5138	.3978
20	.2818	.2818		.431		.4973	.3481
21	.3315	.2984	.3481	.3978	.3315		.3481
22	.3481		.3315	.3315	.2984	.3315	.3315
23	.3149	.2818	.3149	.2984	.2486	.2984	.3481
24	.3647	.2984	.2486	.3149	.3481	.1989	.3149
Max	.9116	.7127	.7127	.7293	.779	.5967	.5801
Min	.0332	.1823	.2486	.1658	.2486	.1989	.1823
Avg	.418	.3751	.3978	.4372	.4562	.4003	.3695

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134001 / 33KV JAFRABAD

Feeder No / Name : 204 / ASAI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3149	.3315	.3315		.2486	.2984	
2	.3481	.3812	.3647		.2652	.2486	
3	.3978	.4475	.4144		.2984		
4	.431	.5304	.4475		.3315		
5	.4807	.6299	.5801		.3315		
6	.5304	.9448	.7459		.3812		
7			.6299		.7625		
8			.4973		.7459		
9			.3315		.6133		
10	.2984	.1823	.2984		.1989		
11	.3315	.2652	.3647		.1823		
12	.2818	.2486	.3149		.1658		
13	.3315	.3149	.2486		.1823		
14	.3149	.2486	.2321		.2321		
15	.4641	.2652	.2652		.2321		
16		.2818	.3647		.2155		
17	.2486	.2818	.3315	.2984	.3149		
18		.4973	.5801	.3647	.5304		
19	.663			.4973	.7293		.4973
20	.5801	.5967		.3812	.6464		.431
21	.4973	.5801		.6464	.6133		.3315
22	.4161			.4641	.2984		.2818
23	.3647	.4144		.4144	.2486		.2321
24	.3481	.3315	.3315		.2321	.2652	
Max	.663	.9448	.7459	.6464	.7625	.2984	.4973
Min	.2486	.1823	.2321	.2984	.1658	.2486	.2321
Avg	.4023	.4091	.4039	.4381	.3750	.2707	.3547

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134001 / 33KV JAFRABAD

Feeder No / Name : 205 / TEMBHURNI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.2286	.2858	.1334	.0953	.0953	.081
2	.362	.2477	.3429	.1334	.0953	.1143	.0829
3	.4001	.2858	.381	.1334	.1334		.1334
4	.5335	.3429	.5144	.1905	.1905		.1905
5	.6097	.4763	.5716	.2286	.2286	.2096	.2858
6	.7049	.6668	.6478	.2477	.2858	.1524	
7			.4954	.2477	.381	.2477	
8			.381	.2286	.381	.2477	.0191
9			.1715	.2286	.3239	.2096	
10	.1905	.2286	.2096	.1698	.1905	.1905	
11	.2286	.1905	.2286	.1509	.1524	.1524	
12	.2286	.2286	.2477	.1334	.1524	.1326	
13	.2477	.2096	.2286	.1334	.1524	.1143	
14	.2096	.1524	.2667	.1143	.1524	.116	
15	.2096	.2096	.2286	.1524	.1905	.116	
16	.1524	.2096	.2286	.0572	.2096	.0995	
17	.1524	.1715	.2286	.0762	.2667	.1989	
18	.5906	.5716	.3048	.1524	.4382	.3149	
19	.5525	.381		.5716	.6287	.5138	
20	.5144	.5525		.5335	.5906	.4807	.0953
21	.4763	.4191	.4954	.4382	.5144	.3812	.0762
22	.3429		.0953	.3429	.0953	.381	.0572
23	.2858	.3239	.1334	.2858	.0953	.3239	.0381
24	.2858	.2858	.2858	.1334	.0663	.0953	.0953
Max	.7049	.6668	.6478	.5716	.6287	.5138	.2858
Min	.1524	.1524	.0953	.0572	.0663	.0953	.0191
Avg	.3620	.3191	.3170	.2174	.2504	.2222	.1050

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134001 / 33KV JAFRABAD

Feeder No / Name : 206 / JAFRABAD

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2012	1.2136	1.251	1.3443	1.2136	.9945	1.1203
2	1.2012	1.2696	1.2136	1.4003	1.1603	1.1576	1.1576
3	1.2567	1.307	1.307	1.4563	1.3443		1.2136
4	1.3676	1.3817	1.3443	1.4003	1.4003		1.2696
5	1.4415	1.4563	1.4003	1.4377	1.4563	1.251	1.307
6	1.46	1.531	1.4563	1.419	1.4937	1.587	1.4003
7	1.4969	1.587	1.5497	1.307	1.6244	1.5497	1.4003
8	1.5708	1.5123	1.587	1.2136	1.587	1.587	1.643
9	1.531	1.6263	1.5684	1.4969	1.5708	1.3443	1.6057
10	1.3923	1.6078	1.531	1.6244	1.3676	1.5123	1.4937
11	1.4937	1.6448	1.475	1.3121	.8215	1.5154	1.2929
12	1.5123	1.4083	1.4003	1.2936	.8402	1.419	1.419
13	1.2696	1.4632	1.363	1.2883	1.419	1.3121	1.4003
14	1.307	1.3443	1.307	1.2382	1.3817	1.3817	1.251
15	1.2266	1.4003	1.363	1.307	1.419	1.3817	1.2012
16		1.4937	1.6244	1.1389	1.4563	1.4003	1.419
17	1.9605	1.8484	1.9044	1.7177	1.6617	1.7177	1.6817
18	1.9231	1.8298	1.9231	1.8671	1.7364	1.8111	1.6263
19	1.4937	1.4937		1.587	1.475	1.7551	1.5524
20	1.5684	1.5684		1.6991	1.4377	1.6057	1.7002
21	1.4937	1.4003	1.587	1.4563	1.363	1.4937	1.4003
22	1.2431		1.531	1.4003	1.307	1.4003	1.307
23	1.307	1.307	1.4937	1.3443	1.2136	1.2136	1.1949
24	1.2382	1.2136	1.1271	1.307	1.1763	1.1576	1.1203
Max	1.9605	1.8484	1.9231	1.8671	1.7364	1.8111	1.7002
Min	1.2012	1.2136	1.1271	1.1389	.8215	.9945	1.1203
Avg	1.4329	1.4743	1.4685	1.4190	1.3719	1.4340	1.3824

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134021 / 33KV TEMBHURNI

Feeder No / Name : 201 / TEMBHURNI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.381	.381	.381	.7621	.7621	.7621
2	.3429	.4191	.4001	.4191	.724		.7621
3	.4382	.4572	.4382	.4191	.724		.9717
4	.4382	.5335	.4572	.4572	.8002		1.1431
5	.5144	.5716	.5144	.4572	.8002		1.1431
6	.5335	.5906	.5144	.4954	.9145		1.086
7	.5525	.5716	.5716	.5335	1.086	1.2955	1.086
8	.5335	.5716	.5906	.5525	1.0479	1.0288	1.0098
9	.4763	.4954	.5716	.4954	.9145	1.0479	.8573
10	.6668	.4954	.4763	.3429	.4763	.5716	.381
11	.7621	.4763	.5716		.4763	.4763	.4001
12	.6668	.4954	.6668		.4572	.4191	.4191
13	.7811	.4382	.6859	.2667	.4382	.4191	.4001
14	.743	.4382		.2667	.4191	.381	.381
15	.724	.4001		.2667	.381	.4763	.381
16		.381		.2858	.381	.4763	.4382
17	.9335	.4763	.9145	.2858	.381		.6668
18	.9907	.724	.8573	.381	.8573	.8002	.8002
19	1.0669	.8002		.9145	1.0288	.9145	.9145
20	.9717	.8002		1.105		1.1812	.8573
21	.9145	.724	.7621	1.0669	1.0098	1.1431	.8764
22	.8573	.5144	.7621	.9145	.8573	1.105	.8573
23	.6668	.381	.8192	.5716	.8002	.9145	.7621
24	.3429	.381	.362	.4001	.5144	.7621	.8002
Max	1.0669	.8002	.9145	1.105	1.086	1.2955	1.1431
Min	.3429	.381	.362	.2667	.381	.381	.381
Avg	.6635	.5216	.5956	.5127	.7066	.7875	.7565

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134021 / 33KV TEMBHURNI

Feeder No / Name : 202 / AKOLADEO

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.4763	.4763		.3429	.381	.2286
2	.3429	.5335	.4763		.3429		.2667
3	.3429	.5716	.4763		.381		.2667
4	.381	.6668	.5144		.381		.2858
5	.4382	.724	.5906		.4382		.2858
6	.5144	.8002	.724		.4763		.2858
7	.724	.6668	.7621		.5335	.4763	.3239
8	.6859	.5525	.724		.5716	.4954	.3429
9	.6668	.4763	.6668		.5525	.4763	.2858
10	.4763	.381	.3429		.2286	.1905	.1524
11	.5716	.3429	.381		.2286	.1715	.1715
12	.6668	.381	.4191		.2286	.1905	.1905
13	.6478	.4001	.4763		.2477		.1905
14	.6287	.3429	.4191		.2477		.1905
15	.6097	.3239	.362		.2286		.2286
16		.3239	.381	.381	.2286	.2286	.2477
17	.4191	.3239	.381	.4954	.4382		.2858
18	.4763	.2286	.3429	.3429	.4572	.5335	.3048
19	.5335	.2286		.3429	.6287	.5716	.5906
20	.5525	.2858		.381			.5716
21	.4763	.3239		.4191	.4191	.5716	.5335
22	.4572	.3429		.4191	.381	.5716	.4763
23	.4572	.3429		.4191	.381	.5716	.4572
24	.3239	.4382	.3429		.381	.3429	.3429
Max	.724	.8002	.7621	.4954	.6287	.5716	.5906
Min	.3239	.2286	.3429	.3429	.2286	.1715	.1524
Avg	.5103	.4366	.4873	.4001	.3802	.4124	.3128

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134021 / 33KV TEMBHURNI

Feeder No / Name : 203 / PAPAL

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2667	.2858		.1524	.2286	.2286
2		.3048	.2858		.1905		.2667
3		.3429	.3429		.2286		.2667
4		.381	.3429				.2286
5		.4001	.4001				.2858
6		.4191	.5144		.381		.2858
7		.4763	.6859		.5144	.3048	
8	.3429	.5144	.6478	.4572	.4763	.3429	
9		.3429	.5716	.362	.5144	.362	.1524
10	.2286	.2858	.1905	.3048	.1715	.2286	.1143
11	.2667	.2858	.2096	.2858	.1715	.2858	.1143
12	.2858	.3048	.2286	.2858	.1715	.2096	.2286
13	.3048	.3048	.2477	.2477	.1715	.1905	.2477
14	.3048	.3239	.2286	.2286	.1715	.1143	.1334
15	.3048	.2858	.2477	.2477	.2286	.0953	.1524
16		.2667	.2858	.2477	.3429	.1143	.1715
17		.3239	.362	.2286	.4572		.2286
18		.1524	.3239	.2858	.5335		.3048
19	.4954	.1905		.2858	.5716		.5335
20	.4001	.2286		.3239		.4382	.381
21	.381	.2286		.3048	.2858	.381	.3239
22	.3429	.2477		.2858	.2858	.381	.2858
23	.3048	.2286		.2858	.2667	.381	.2667
24		.2477	.2286		.1524	.2477	.2286
Max	.4954	.5144	.6859	.4572	.5716	.4382	.5335
Min	.2286	.1524	.1905	.2286	.1524	.0953	.1143
Avg	.3302	.3064	.3490	.2917	.3066	.2691	.2468

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134021 / 33KV TEMBHURNI

Feeder No / Name : 204 / BHATODI FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3048			.4763	.5335	.5335
2	.3429	.3429	.2858		.4382	.5335	.4763
3	.4001	.4191	.3239		.5335		.4763
4	.4382	.4572	.3429		.5716		.5716
5	.5144	.5335	.381		.5716		.6097
6	.5716	.5716	.5144		.724		.6668
7	.6097	.6097	.6859		.9907	.9717	.6668
8	.5906	.6668	.6478		.9145	.8764	.5906
9	.5716	.5716	.6097	.5716	.8002	.5906	.4763
10	.381	.1905	.2858	.3429	.743	.4191	.1905
11	.381	.2286	.2858	.3048	.6668	.381	.2096
12		.2858	.3048	.3429	.6287	.3048	.2286
13		.2858	.3239	.3239	.5716	.3429	.2477
14		.2858	.3429	.3048	.5716	.362	.2667
15		.3048	.362	.3239	.4763	.3429	.3048
16		.3048	.4763	.3239	.4763	.3429	.3429
17	.8002	.2858	.5716	.3048	.5335		.4763
18	.7621	.2858	.5335	.4572	.6668	.6668	.5906
19	.7621	.3239		.4954	.8383	.7621	.8573
20	.6859	.381		.4954		.8383	.7621
21	.5716	.4001		.4954	.6287	.724	.6287
22	.5335	.381		.4763	.5716	.6668	.5335
23	.4763	.3429		.4763	.5335	.5716	.4763
24	.3239	.2858	.2858		.4763	.4763	.5335
Max	.8002	.6668	.6859	.5716	.9907	.9717	.8573
Min	.3239	.1905	.2858	.3048	.4382	.3048	.1905
Avg	.5295	.3771	.4202	.4026	.6262	.5635	.4882

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134021 / 33KV TEMBHURNI

Feeder No / Name : 205 / AMBEGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2286	.0762	.2477	.1143	.1905	.0953
2	.2286	.2286	.0762	.2667	.1143		.0953
3	.2286	.2667	.0953	.2858	.1143		.1143
4	.2667	.3429	.0953	.2858	.1524		.1143
5	.2858	.4001	.0953	.3048	.2286		.1334
6	.3239	.4763	.0762	.3048	.2286		.1143
7	.4191	.381	.0953	.3048	.2858		.1143
8	.3429	.2667	.0953	.2286	.1905		.1143
9	.3048	.1905	.0762	.1334	.2286		.0191
10	.1524	.1524		.1334	.0953		.0191
11	.1905	.1334		.1143	.0953		.0191
12	.1905	.1334		.0953	.0953		.0381
13	.2096	.1143	.1524	.0953	.0953		.0381
14	.1905		.1715	.0762	.0953		.0381
15	.1905		.1905	.0762	.0953	.0953	.0572
16			.1905	.0953	.1524	.1143	.0762
17	.0953		.1905	.0953	.2667		.0953
18	.1905	.0572	.2286	.0762	.3239		.1334
19	.2667	.0572		.0762	.3239		.2477
20	.2477	.0762		.0953		.3429	.2477
21	.2477	.0762	.3429	.0953	.3048	.3429	.2477
22	.2477	.0572	.3048	.0953	.2858	.2858	.1905
23	.2286	.0762	.2858	.0953	.2667	.2858	.1905
24	.2286	.2286	.0762	.2477	.1143	.1905	.1143
Max	.4191	.4763	.3429	.3048	.3239	.3429	.2477
Min	.0953	.0572	.0762	.0762	.0953	.0953	.0191
Avg	.2377	.1972	.1534	.1635	.1856	.231	.1112

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134021 / 33KV TEMBHURNI

Feeder No / Name : 206 / DAWARGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.4001	.8002	.8002	.9526	.7621
2	.381	.4763	.4382	.8383	.8002		.7621
3	.3429	.5335	.4763	.8573	.9526		.9145
4	.381	.5716	.5144	.9717	.9526		.9145
5	.4001	.6668	.5716	1.086	1.1241		.9907
6	.4382	.7621	.724	1.086	1.4861		1.1431
7	.4763	.8383	.8383	.362	1.2765	1.2955	1.1812
8	.4382	.6859	.8383	.1143	1.2384	1.0479	1.086
9	.4191	.4954	.7621	.1143	1.086		.8573
10	.5716	.3429	.4954	.2286	.8383		.2858
11	.6668	.362	.3429	.2667	.8002		.3429
12		.381	.362	.2858	.7621		.362
13		.4382		.2477	.724	.4191	.3429
14		.3239		.2286	.5716	.4763	.3429
15		.3048		.3239	.5716	.5335	.4191
16		.2858	.5716	.4763	.5716	.4763	.4572
17	1.1622	.4763	.7621	.724	.5335		.5335
18	1.105	.4763	.8002	.9717			.6668
19	1.0288	.5144		1.105	1.2765		1.086
20	1.0288	.724		.9145		1.2003	.9526
21	.9145	.724	.8954	.8764	1.086	1.1431	.8573
22	.8573	.6668	.8573	.8573	1.0479	1.1431	.7621
23	.7621	.6668	.8383	.7621	.9145	.9526	.724
24	.381	.2858	.381	.7621	.7621	.8573	.9526
Max	1.1622	.8383	.8954	1.105	1.4861	1.2955	1.1812
Min	.3429	.2858	.3429	.1143	.5335	.4191	.2858
Avg	.6387	.5160	.6247	.6359	.9171	.8748	.7375

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134022 / WARUD 33/11 KV S.S

Feeder No / Name : 201 / WARUD

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4908	.5228	.4287	.1402	.2507	.2572	.2572
2	.5258	.5415	.4801	.1753	.2507		.2572
3	.5609	.5788	.5197	.2103	.2658		.3086
4	.583	.5975	.547	.2103	.3012		.3086
5	.6001	.6653	.6036	.2454	.333		
6	.7522	.7682	.7712	.2804	.4115		
7	.631	.6838	.6962	.3155	.4191	.3429	
8	.4207	.6099	.6036	.3012	.3561	.3429	.3772
9	.3772		.4748	.2804	.3121	.3086	.3772
10	.1629	.2915	.2507	.4435	.39	.2229	.2957
11	.2481	.3086	.3224		.39	.1715	.4066
12	.2804	.2915	.2865		.373	.2743	.3696
13	.3121	.2743	.2454		.3772	.3772	.3511
14	.2835	.2743	.2279	.462	.3601	.3944	.381
15	.2835	.2743	.2103	.462	.3601	.3944	.3881
16	.2303		.2507	.5175	.3601		.4066
17	.2328	.2572	.1753	.462	.4287		.4251
18	.5914	.1715	.5201	.5175	.503		.499
19	.6283	.4801		.5175	.5365		.499
20	.6161	.6001	.631	.7207	.5868		.7865
21	.5975		.5731	.6908	.5596		.6099
22	.5601		.5609	.6722	.5256		.5914
23	.5914		.4908	.5975	.5087		.5601
24	.5373	.5415	.5144	.2103	.2303	.3429	.2149
Max	.7522	.7682	.7712	.7207	.5868	.3944	.7865
Min	.1629	.1715	.1753	.1402	.2303	.1715	.2149
Avg	.4624	.4596	.4515	.4015	.3912	.3117	.4129

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134022 / WARUD 33/11 KV S.S

Feeder No / Name : 202 / ADHA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4207	.4161	.3772	.964	1.0099	.9221	.9835
2	.4557	.4458	.4458		1.0277		1.0004
3	.4801	.5144	.4694	.8413	1.0517		1.0174
4	.5258	.57	.503	.8764	1.0867		1.0395
5	.5784	.6299	.5636	.9313	1.1218		
6	.6173	.6299	.5967	.964	1.1919		
7	.5201	.5636	.4024	1.1568	1.1043	.8764	
8	.5784	.4527	.503	.9114	.8775	.9114	.8886
9	.4801	.4287	.5087	.7888		.6588	.8886
10	.5611	.4801	.591		.4239	.2774	.3506
11	.5014	.4973	.5194	.5144	.4115	.2427	
12	.5014	.4801	.4733	.4641	.4115	.3086	
13	.5194	.463	.4908	.4144	.3944	.3944	.3681
14	.5121	.4458	.5083	.4475	.3944	.4287	.3506
15	.5487		.5083	.431	.4115	.5144	.3467
16			.5373	.431	.3944		.3772
17	.8238		.5609	.4973	.5087		.3521
18	.9745	.8288	.9313	.8596	.6706		.7701
19	.9745	.8916		1.0277	1.0159		1.0277
20	1.0166	1.0117	1.1393	1.1043	1.1336		1.2757
21	1.0166		1.1283	1.1218			1.1568
22	.9991		1.0867	1.0692			1.1393
23	.9745		1.0166	1.0631			1.1218
24	.4115	.4115	.4287	1.0166	1.0277	.9012	
Max	1.0166	1.0117	1.1393	1.1568	1.1919	.9221	1.2757
Min	.4115	.4115	.3772	.4144	.3944	.2427	.3467
Avg	.6518	.5645	.6213	.8135	.7835	.5851	.8030

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134022 / WARUD 33/11 KV S.S

Feeder No / Name : 203 / WANKHEDA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1402	.128	.1372	.1402	.1463		.1372
2	.1372	.1463	.1402	.1402	.1829		.1715
3	.1543	.1448	.1402	.1052	.1829		.1715
4	.1543	.1629	.1715	.1227	.2172		.1715
5	.2103	.181	.1715	.1433	.2835		
6	.3155	.2686	.3353	.2103	.3506		
7	.2401	.3506	.3353	.2804	.3681		
8	.2058	.2835	.1715	.2454	.2658		.1715
9	.1715	.1463	.1715	.2804	.2195		.1715
10	.181	.1029	.1227	.2601	.1791		.128
11	.2658	.1029	.1052	.2774	.1433	.1052	.1143
12	.1448			.2103	.1254	.1402	.1143
13	.128	.1029		.181	.1075	.1753	.1143
14	.128	.1029	.0701	.1829	.1433	.1715	.1307
15		.1029	.0876	.181	.1402	.1715	.1307
16	.0953	.1715	.1433	.1463	.1753		.3258
17	.0953	.1715	.2058	.2835	.1753		.1463
18	.0572	.1715	.3506	.3601	.1753		.2149
19	.0572	.1715		.3681	.1753		.3582
20	.181		.2629	.2686	.1753		.2715
21	.1829		.2103	.2172			.2195
22	.1478		.2103	.181			.1829
23	.1294		.1402	.1829			.3641
24	.1402	.128	.1715	.1433	.1829		.1715
Max	.3155	.3506	.3506	.3681	.3681	.1753	.3641
Min	.0572	.1029	.0701	.1052	.1075	.1052	.1143
Avg	.1593	.1653	.1836	.2130	.1960	.1527	.1896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134022 / WARUD 33/11 KV S.S

Feeder No / Name : 204 / KOLEGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2804	.2858	.1029	.1227	.2149	.2058	.2058
2	.3155	.3048	.1029	.1227	.2328		.2229
3	.3086	.3429	.12	.1402	.2303		.2401
4	.3506	.381	.12	.1402	.2481		.2572
5	.4115	.4527	.1372	.1753	.3189		
6	.5487	.5228	.1372	.1753	.4207		
7	.463	.5041	.1254	.2103	.3681		
8	.4031	.4668	.1075		.3294		
9	.3601	.2667	.1097	.0549	.3121	.0857	
10	.2126	.2058	.0701	.0572	.1578		.362
11	.2149	.1715	.0876	.1646	.1578		
12	.2835	.2058	.0701	.2279	.1543		.1905
13	.2303	.2229	.0701	.1949	.1526		.2477
14	.2149	.2229	.0537	.2103	.1638		.2667
15	.2328	.2229	.0526	.1791	.1658	.2401	.2858
16			.0537	.2149	.1619		.3239
17	.2149		.0526	.1991	.2915		.2667
18	.4481	.1029	.0876	.3881	.3812		.381
19	.381	.1029		.4435	.426		.5788
20	.381	.1029	.2629	.4805	.4578		.5914
21	.3429		.2454	.362			.4572
22	.2858		.2103	.3429			.4382
23	.2858		.1402	.3048			.4001
24	.2804	.2667	.1402	.1402	.2149	.2058	.2058
Max	.5487	.5228	.2629	.4805	.4578	.2401	.5914
Min	.2126	.1029	.0526	.0549	.1526	.0857	.1905
Avg	.3239	.2818	.1156	.2196	.2648	.1844	.3290

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134022 / WARUD 33/11 KV S.S

Feeder No / Name : 205 / KONAD

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1753	.2481	.2058	.2103	.2858		.2686
2	.1791	.2481	.2401	.2454	.3048		.2865
3	.2058	.2658	.2058	.2454	.3048		.2865
4	.2401	.3155	.2401	.3155	.3429		.3224
5	.2629	.3429	.2683	.3155	.4191		
6	.2865	.4191	.3018	.4207	.7095		
7	.3155	.4527	.3052	.5258	.6535		
8	.3086	.4475	.3772	.5083	.4904		
9	.2572	.4641	.5304	.333	.3429		
10	.2286	.3429	.2103	.2774	.3401	.0857	
11	.1715		.1402	.2915	.3277	.0857	.0762
12	.1524	.1372		.2427	.2778	.0857	.0572
13	.1715	.1372		.2279	.2656	.0857	.0572
14	.1715	.1372	.1612	.1772	.2623	.1029	.0572
15	.1715	.1543	.2328	.2279	.2949	.1029	.0953
16			.2279	.3086	.3315		.0953
17	.4001	.1715	.2454	.2947	.3688		.1143
18	.4954	.2572	.3582	.381	.39		.2286
19	.4001	.2915		.499	.373		.3961
20	.3429	.3258	.3681	.4481			.4191
21	.3429		.3224	.3429			.2667
22	.2858		.2804	.3048			.2286
23	.2858		.2629	.2858			.2096
24	.2149	.2303	.2229	.2103	.2858	.2401	.1715
Max	.4954	.4641	.5304	.5258	.7095	.2401	.4191
Min	.1524	.1372	.1402	.1772	.2623	.0857	.0572
Avg	.2637	.2836	.2718	.3183	.3686	.1127	.2021

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134022 / WARUD 33/11 KV S.S

Feeder No / Name : 206 / BHARADKHEDA FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5258	.5533	.4239	.6135	.724	.6706	.788
2	.5609		.4458	.631	.7602		.8238
3	.5487		.4359	.6661	.8238		.8413
4	.6516		.4694	.7011	.9214		.8764
5	.7716		.4973	.964	1.0277		
6	1.1104		.5304	.7888	1.1043		
7	.9945		.4973	1.2269	.9568		
8	1.0288		.7293	.8413	.8775		
9	.8916		.6962	.5258	.6697		
10	.4435	.4287	.4908	.5868	.68		
11	.381	.4287	.3856	.639	.6405	.2743	
12	.4763	.4458	.3681	.6554	.6249	.2743	.4382
13	.5335	.4801	.3856	.6554	.6009	.2915	.4854
14	.4954	.4801	.4207	.6554	.6554		.5533
15	.4954	.4801	.4031	.5304	.6796		.5365
16			.4119	.6718	.6802		.5967
17			.6135	.6554	.78		.6962
18			.8916	.7164	.8402		.6697
19				1.0099	.6554		.985
20		.4973	.8413	.9313	.5401		.724
21	.8059		.7362	.8596			.6584
22	.7343		.8063	.8059			.6036
23	.7059		.7362	.7164			.6401
24	.5144	.5487	.6173	.631	.6805	.503	.4458
Max	1.1104	.5533	.8916	1.2269	1.1043	.6706	.985
Min	.381	.4287	.3681	.5258	.5401	.2743	.4382
Avg	.6668	.4825	.5580	.7366	.7582	.4027	.6684

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134032 / MAHORA 33/11 KV SUBSTATION

Feeder No / Name : 201 / 11 KV PIMPALGAON KAD Single Phasing Feeders

FEEDER Feeder KV- 11 /
OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.4854		.5144		.6859
2	.4287	.4287	.6762		.6001		.8573
3	.5144	.5144	.6935		.6859		.9431
4	.6516	.6001	.7282		.823		1.0288
5	.7545	.7716	.7628		.8573		1.1145
6	.8402	.823	.7975		.823		1.3546
7	1.0288	.8573	.8669		.8402		.6687
8	.8916	.6859	.7802		.8745		.9431
9	.6859	.6687	.6588	.3155	.5487		.823
10	.4973	.3086		.4801	.6762		.2601
11	.3944	.2915	.3155	.4801	.6935		.2865
12		.2572		.4973	.5375	.3086	.2629
13	.3258	.3086	.3012	.4973	.5028	.3086	.2601
14	.3429	.3121	.3189	.5144	.5375	.4115	.2601
15	.3429	.2947	.3366	.6001	.6935	.4287	.2658
16		.2947	.4607	.6859	.7108	.4287	.2804
17	.3258	.3988	.7011	.7373	.7802	.4458	.3121
18	.5144	.6588	.9391	.6859	.8322	.4458	.5258
19	.7716	.8322		.6687		.8059	.5258
20	.8573	1.0056		.9602		.7716	
21	.8573	.8495		.8573		.8402	
22	.7716	.7455		.823		.8573	
23	.6859	.6588		.7716		.8573	
24	.3086	.5144			.6859		.7716
Max	1.0288	1.0056	.9391	.9602	.8745	.8573	1.3546
Min	.3086	.2572	.3012	.3155	.5028	.3086	.2601
Avg	.5970	.5593	.6139	.6383	.6956	.5758	.6215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134032 / MAHORA 33/11 KV SUBSTATION

Feeder No / Name : 202 / 11 KV MAHORA FEEDER Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.3429	.6068		.3086		.3086
2	.7716	.4287	.6588		.3429		.3429
3	.8573	.5144	.7628		.4287		.3772
4	.9431	.6687	.7802		.5144		.3944
5	1.0288	.823	1.0056		.6001		.4287
6	1.1145	.9431	1.1789		.6344		
7	1.0288	.9945	1.1096		.6687		
8	.9259	.8573	.9362		.6344		
9	.8916	.7373	.6935	.4961	.6001		.3086
10	.5144		.4031	.3429	.6068	.3258	.4508
11	.5144		.3721	.3086	.5201	.2915	.3856
12	.4801			.2743	.5375	.2915	.3012
13	.4287		.3814	.2401	.5375	.3429	.3121
14	.3944	.3121	.3681	.3429	.5375	.583	.5548
15	.3601	.2947	.3506	.4287	.5375	.583	.5609
16		.2601		.6001	.5721	.6001	.5493
17	.3258	.2774	.333	.6687	.6588	.6859	.6626
18	.2229	.4334	.8939	.7716	.8149	.7545	.8589
19	1.0802	1.0749		.9774		.8916	.8869
20	.9945	.9882		.9774		.8573	
21	.6859	.7282		.9431		.7716	
22	.6001	.6588		.823		.6687	
23	.6001	.6588		.6001		.583	
24	.583	.5658	.5375		.3429		.3258
Max	1.1145	1.0749	1.1789	.9774	.8149	.8916	.8869
Min	.2229	.2601	.333	.2401	.3086	.2915	.3012
Avg	.6970	.6281	.6689	.5863	.5473	.5879	.4711

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134032 / MAHORA 33/11 KV SUBSTATION

Feeder No / Name : 203 / 11 KV WADALA FEEDER Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3086	.3467		.5144		.8573
2	.4115	.3258	.4161		.6001		1.0288
3	.4801	.3429	.5201		.6859		1.0288
4	.5144	.5144	.6068		.7716		1.046
5	.5487	.6001	.6935		.9431		1.0631
6	.6001	.6859	.8322		.9774		1.0802
7	.8059	.7545	.9709		.9945		.8573
8	.823	.7716	.7108		.9088		.6859
9	.5658	.6859	.6241	.2454	.6344		.5144
10	.3258	.3429	.3506	.3772	.7282		.104
11	.3086	.3086	.3155	.4287	.6068		.0876
12	.2743	.2743		.4287	.5028	.4115	.2279
13	.3086	.2915	.3155	.4801	.4681	.4287	
14	.3429	.3121	.3506	.5144	.3294	.4458	.2774
15	.3601	.3121	.3898	.5316	.3814	.5144	.298
16		.3121	.4252	.5316	.4508	.583	.3155
17	.6859	.5895	.8413	.5316	.5201	.6516	.3721
18	.9259	.9536	.9816	.7716	.7628	.7202	.7362
19	.823	1.0923		.9774		.823	.8413
20	.823	.9536		.9431		.7716	
21	.6859	.7455		.8573		.6859	
22	.6859	.6241		.823		.6001	
23	.6001	.5721		.6001		.6173	
24	.2572	.5316	.2947		.4973		.5487
Max	.9259	1.0923	.9816	.9774	.9945	.823	1.0802
Min	.2572	.2743	.2947	.2454	.3294	.4115	.0876
Avg	.5420	.5502	.5548	.6028	.6462	.6044	.6300

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134032 / MAHORA 33/11 KV SUBSTATION

Feeder No / Name : 204 / 11KV MHASARUL FEEDER Single Phasing Feeders
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144		.5201		.2743		.3258
2	.5658		.6588		.3086		.3258
3	.583		.7628		.3429		.3429
4	.6516		.7802		.4287		.3601
5	.7888		.7975		.5144		.3772
6	1.0631		.8495		.6001		.3772
7	1.0288		.9015		.6859		.3086
8	.8402		.7282		.6859		.2915
9			.5028	.1753	.4458		.2058
10		.156	.1949	.1029	.3641		.4508
11	.3258	.156	.2481	.12	.2947		.3544
12	.2915	.156		.12	.2601		.2601
13	.2743	.156	.1753	.12	.2601		
14	.2743	.1387	.1907	.2229	.3121	.3086	
15	.2743	.1387	.2481	.2743		.3258	.2804
16		.156	.2804	.3086		.3429	.3189
17		.1734	.2629	.3429		.5144	.3856
18		.7282	.567	.6001		.6001	.5959
19		.6935		.8745		.8402	
20		.6762		.8745		.7716	
21		.5201		.823		.6001	
22		.4508		.6859		.5144	
23		.4161		.6001		.5144	
24	.463		.3988		.4801		.3086
Max	1.0631	.7282	.9015	.8745	.6859	.8402	.5959
Min	.2743	.1387	.1753	.1029	.2601	.3086	.2058
Avg	.5671	.3368	.5038	.4163	.4172	.5333	.3453

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134032 / MAHORA 33/11 KV SUBSTATION

Feeder No / Name : 205 / 11KV BELORA FEEDER Single Phasing Feeders
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.3429	.4854		.2743		.0343
2	.5144	.3944	.6241		.2915		.0343
3	.583	.4287	.6935		.3086		.0514
4	.6859	.5144	.8322		.3258		.0514
5	.9259	.6687	.9362		.3429		.0514
6	1.046	.7716	.9882		.4115		.0514
7	.8402	.8573	.7108		.4458		.0857
8	.7202	.7202	.5201		.463		.0857
9	.5144	.4801	.5028	.298	.3944		.0686
10	.4287	.2915	.3366	.2401	.2601		.052
11	.3086	.3086	.298	.2229	.2774		.0347
12	.2915	.3601		.2058	.2427		.0354
13	.3086	.3601	.2804	.1886	.2601	.1029	
14	.2743	.2427	.3189	.2572	.2601	.1372	
15	.2743	.2774	.3121	.3429	.2601	.0514	
16	.2743	.3294	.3366	.4287	.2774	.0514	
17	.2915	.3467	.4252	.463	.4334	.12	
18	.8059	.7975	.631	.6001	.7455	.1372	
19	.6173	.8669		.7202		.2915	
20	.583	.7108		.6859		.2572	
21	.6001	.5548		.6859		.2401	
22	.5144	.4681		.6001		.2058	
23	.5487	.3988		.5144		.1543	
24	.3601	.4115			.3258		.1029
Max	1.046	.8669	.9882	.7202	.7455	.2915	.1029
Min	.2743	.2427	.2804	.1886	.2427	.0514	.0343
Avg	.5315	.4960	.5431	.4303	.3474	.159	.0569

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134032 / MAHORA 33/11 KV SUBSTATION

Feeder No / Name : 206 / 11KV INDUSTRIAL FEEDER SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0171	.0173		.0171		.0171
2	.0171	.0171	.0173		.0171		.0171
3	.0171	.0171	.0173		.0171		.0171
4	.0171	.0171	.0173		.0171		.0171
5	.0343	.0171	.0173		.0171		.0171
6	.0171	.0171	.0173		.0171		.0171
7	.0171	.0171	.0173		.0171		.0171
8	.0171	.0171	.0173		.0171		.0171
9	.0171	.0173	.0173		.0171		.0171
10	.0171	.0173	.0175	.0171	.0173	.0171	.0173
11	.0171	.0173	.0175	.0171	.0173	.0171	.0175
12	.0171	.0173		.0171	.0173	.0171	.0177
13	.0171	.0171	.0179	.0171	.0173	.0171	.0175
14	.0171	.0173	.0179	.0171	.0173	.0171	
15	.0171	.0173	.0179	.0171	.0173	.0171	
16		.0173	.0179	.0171	.0173	.0171	.0181
17	.0171	.0173	.0179	.0171	.0173	.0171	.0181
18	.0171	.0173	.0175	.0171	.0173	.0171	
19	.0171	.0173		.0171		.0171	.0179
20	.0171	.0173		.0171		.0171	
21	.0171	.0173		.0171		.0171	
22	.0171	.0173		.0171		.0171	
23	.0171	.0173		.0171		.0171	
24	.0171	.0171	.0173		.0171		.0171
Max	.0343	.0173	.0179	.0171	.0173	.0171	.0181
Min	.0171	.0171	.0173	.0171	.0171	.0171	.0171
Avg	.0178	.0172	.0175	.0171	.0172	.0171	.0174

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134047 / 33 KV DONGAON

Feeder No / Name : 201 / POKHRI - AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2315	.1543	.1543		.0772		.0772
2	.2315	.1543	.1543		.0772		.0772
3	.2315	.1543	.1543		.0772		.0772
4	.2315	.1543	.1543		.0772		.0772
5	.2315	.2315	.1543		.0772		.0772
6	.3858	.3858	.2315		.0926		.0772
7	.6173	.5401	.3858				
8	.5401	.5401	.3086				
9	.463	.463	.463				
10					.463		.0463
11					.6173		.2315
12					.463	.1543	.2469
13					.463	.2315	.2469
14					.463	.3086	.2315
15					.3858	.3858	.3086
16		.0772	.0772	.0772	.463	.3858	.3086
17	.0772	.0772		.0772	.3858	.3086	.2778
18	.0772	.0772		.0772	.0772	.0772	.0463
19	.0926			.0772	.0772	.0926	.0772
20	.0926	.0772		.0772		.0926	.0772
21	.0926	.0772		.0772		.0926	.0772
22	.0772	.0772		.0772		.0926	.0926
23	.0772	.0772		.0772		.0926	.0926
24	.2315	.1543	.1543		.0772		.0772
Max	.6173	.5401	.463	.0772	.6173	.3858	.3086
Min	.0772	.0772	.0772	.0772	.0772	.0772	.0463
Avg	.2342	.2043	.2174	.0772	.2597	.1929	.1382

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134047 / 33 KV DONGAON

Feeder No / Name : 203 / NIVDUNGA - AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0937	.0781	.0781	.0781	.1562		.0781
2	.1094	.0781	.0781	.0781	.1562		.0781
3	.125	.0781	.0781	.0781	.1562		.0781
4	.125	.0781	.0781	.0781	.1562		.0937
5	.125	.0937	.0781	.0781	.1562		.0937
6	.1562	.125	.0781	.0781	.3906		
7					.4687		
8					.5468		
9					.3125		
10	.2343	.2343	.3125	.2343			
11	.4687	.3906	.3906	.3906			
12	.3906	.4687	.3906	.3125			
13	.3906	.3125	.3906	.3125			
14	.3906	.3125	.3125	.3125			
15	.3125	.3906	.3906	.3125			
16		.3125	.3906	.3906	.0781		.1562
17	.2343	.3125	.3906	.4374	.0781		.1562
18	.0781	.0781	.0781	.0781	.0781	.0781	
19	.0937	.0781		.0781	.0781	.125	
20	.125	.0781		.1562		.125	.1562
21	.125	.0781	.0781	.1562		.0937	.1562
22	.0937	1.3279	.0781	.1562		.0937	.1562
23	.0937	.0781	.0781	.1562		.0937	.1562
24	.1562	.0937	.0781	.0781	.1562		.0937
Max	.4687	1.3279	.3906	.4374	.5468	.125	.1562
Min	.0781	.0781	.0781	.0781	.0781	.0781	.0781
Avg	.1961	.2418	.2015	.1919	.2120	.1015	.1211

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134047 / 33 KV DONGAON

Feeder No / Name : 204 / NIVADUNGA GAOTHAN
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2427	.1886	.1698	.2452	.2263	.2427
2	.2263	.2427	.1886	.168	.2241		.2427
3	.2641	.2614	.1886	.168	.2614		.2614
4	.3206	.3109	.2075	.2054	.3174		.2926
5	.3584	.3292	.2641	.2402	.3772		.3258
6	.4481	.4298	.2829	.2561	.4481		.2561
7	.415	.3475	.2263	.2195	.4294		.2012
8	.3696	.2926	.2054	.1829	.3142	.3547	.4108
9	.2614	.2587	.112	.1646	.2587	.2801	.2427
10	.1307	.2054	.0747	.128	.168	.168	.1867
11	.112	.1478	.0549	.1294	.0943		.1307
12	.1307	.1494	.0549	.1448	.112	.112	.1109
13	.112	.1132	.0543	.1075		.112	
14	.1307	.1307	.0549	.1097			.1097
15	.168	.1494	.0732	.1294	.1307		.0924
16		.1478	.1109	.1646	.1294		.128
17	.2241	.2614	.128	.2195	.112		.1791
18	.3174	.2614	.1646	.3292	.2801	.2427	
19	.3361	.3395		.3326	.3772	.3292	
20	.3361	.547		.3547		.3841	.4854
21	.2801	.3961	.1848	.2987	.1886	.3142	.3174
22	.2801	.2829	.1867	.2801	.2452	.2987	.2829
23	.2427	.2641	.1494	.2801	.2263	.2801	.2829
24	.2263	.2427	.2452	.1509	.2614	.2263	.2614
Max	.4481	.547	.2829	.3547	.4481	.3841	.4854
Min	.112	.1132	.0543	.1075	.0943	.112	.0924
Avg	.2573	.2648	.1546	.2056	.2477	.2560	.2402

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134047 / 33 KV DONGAON

Feeder No / Name : 205 / POKHARI GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075	.2054	.1132		.1886		.2614
2	.2075	.2241	.1132		.2075		.2427
3	.2263	.2241	.1132		.2263		.2987
4	.2829	.2987	.1132		.2641		.4066
5	.3961	.3801	.132		.3772		.4572
6	.5847	.5068	.1509		.5847		
7	.4904	.4572	.0943		.4904		
8	.415	.3511	.0566		.3772		
9	.2641	.2987	.112		.2801		
10	.1132	.1494	.1109		.132		.1867
11	.112	.1829	.1463		.1494		.1494
12	.168	.168	.1267		.1307	.112	.0633
13	.112	.1867	.1075	.2427	.1494	.168	.0857
14	.1867		.1086	.2481	.1307	.1867	.0867
15	.2241		.1448	.1829	.1307	.1867	.1417
16			.1646	.2103	.1663	.1867	.1075
17	.2987			.298	.2054	.1867	.1578
18	.3734			.3142	.3547	.2427	.2507
19	.3361			.4119	.9054	.3841	.3696
20	.2987	.1698		.3921		.3658	.3734
21	.2614	.132		.2987		.2957	.3174
22	.2241	.1132		.2641		.2427	.2641
23	.2054	.1132		.2263		.2241	.2263
24	.2075	.2054	.1132		.2075		.2427
Max	.5847	.5068	.1646	.4119	.9054	.3841	.4572
Min	.112	.1132	.0566	.1829	.1307	.112	.0633
Avg	.2694	.2426	.1189	.2808	.2829	.2318	.2345

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134067 / BORGAON (M) 33 KV S/S

Feeder No / Name : 201 / BORAGAON MATH

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7316	.587		.5935		.4607
2		.7682	.587		.4917		.4904
3		.7682	.6472		.407		.535
4		.7964	.7074		.4917		.5498
5		.8596	.7676		.4409		.5796
6		.9145	.8278		.4409		
7	1.1462		.8579				
8	.9671	.6062	.888				
9	.7701	.503	.7225				
10	.4938	.2709	.5014		.6104		
11	.4191	.286	.394		.6706		
12	.4578	.3161	.394		.6554	.3121	.3864
13	.4801	.3311	.394		.6706	.3418	.3715
14	.426	.4064	.3224		.5921	.3864	.431
15	.4801	.4666	.4477	.4161	.583	.4161	.4755
16		.5569	.4656	.4961	.6539	.4161	.4012
17	.8779	.6321	.6447	.5921	.6882	.431	.3567
18	.9709	.6773	.9671	.6882	.9145	.4458	.4012
19	.9694	.6622	.8954	.5921	1.1523		.3567
20	.8402	.6472		.5121			.4458
21	.8779	.6472	.4607	.7042			.3715
22	.8215	.6472	.4119	.5921			.431
23	.7316	.5944	.4207	.5121		.5201	.4161
24	.4656	.7522	.5719	.5121			.3567
Max	1.1462	.9145	.9671	.7042	1.1523	.5201	.5796
Min	.4191	.2709	.3224	.4161	.407	.3121	.3567
Avg	.7174	.6018	.6036	.5617	.6285	.4087	.4343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134067 / BORGAON (M) 33 KV S/S

Feeder No / Name : 202 / PASODI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4298	.3018			.1715		.1638
2	.4119	.3361			.2229		.1802
3	.3582				.1886		.2458
4	.394				.1543		.3277
5	.3761				.1886		.3441
6	.4298				.2058		
7	.4477				.1715		
8	.3403				.2229		
9	.2328						
10	.2035	.1614			.0857		
11	.2035	.176			.0934		
12	.1844	.176			.0943	.1638	
13	.2058	.1907			.0943	.1802	
14	.2035	.1907		.1907	.1307	.1802	
15	.2229	.1614		.156	.1132	.1966	
16				.1734	.0934	.213	
17			.1075	.1387	.1494	.213	
18			.1612	.156	.1886	.2294	.213
19	.4294		.1612	.208	.415		.2458
20	.3921			.1734		.2785	.2949
21	.3921		.2328	.1907		.2949	.1966
22	.3584		.2328	.156		.3113	.1475
23	.3395		.197	.156		.1802	.1966
24	.2715	.2926		.0867			.1638
Max	.4477	.3361	.2328	.208	.415	.3113	.3441
Min	.1844	.1614	.1075	.0867	.0857	.1638	.1475
Avg	.3251	.2207	.1821	.1623	.1658	.2219	.2267

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134067 / BORGAON (M) 33 KV S/S

Feeder No / Name : 203 / KHASAGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3224	.2829	.2652		.1326		.2515
2	.3045	.2829	.2652		.116		.285
3	.3224	.3395	.2984		.1492		.3185
4	.3403	.3395	.3481		.116		.3521
5	.3582	.3772	.3978		.1492		.3856
6	.3582	.415	.431		.1658		.3856
7	.4656		.3481		.116		.3521
8	.4298	.2829	.2984		.1823		.3353
9	.3582	.2829	.2818		.1326		.2347
10	.2572		.2149		.1989		.1677
11	.2572	.1823	.197		.2263		.1341
12	.2804	.1989	.1791		.2263		.1509
13	.3086	.1989	.1791		.1886		.1174
14	.2572	.2321	.1433	.1341	.2263		.1677
15	.3086	.2818	.1612	.1174	.1886		.1509
16		.3149	.1433	.1509	.1867		.1844
17		.3315	.1254	.1174	.1886	.4359	.1677
18		.3647	.1433	.1006	.3772	.3856	.1509
19	.415	.3647	.1612	.1174	.3772	.3521	.1677
20	.2829	.3481		.1341		.3353	.2012
21	.2829	.3481	.1433	.1174		.3185	.1509
22	.2829	.3315	.1433	.1006		.285	.1174
23	.2829	.3315	.2126	.1174		.2347	.0838
24	.3224	.2829	.2652	.1509			.1006
Max	.4656	.415	.431	.1509	.3772	.4359	.3856
Min	.2572	.1823	.1254	.1006	.116	.2347	.0838
Avg	.3237	.3052	.2324	.1235	.1918	.3353	.2131

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 201 / 11 KV RAM MANDIR FEEDER Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6535				.6697		
2	.6161				.6516		
3					.6335		
4					.6878		
5					.7421		
6	.8775				.7783		
7	.9149				.8326		
8	.8145	.8029			.7783		
9	.8402				.8029	.8507	
10	.7468				.8029		1.0164
11	.6535				.8029		
12	.6535				.7842		
13					.7655		
14	.6535				.7468		
15					.7468		
16		.5975					
17	.7682	.6767					
18	.7865						
19	.8059						
20	.7682						
21	.7468	.7468					
22			.7468			.8589	
23				.7602		.7468	
24	.6516				.7059		.6535
Max	.9149	.8029	.7468	.7602	.8326	.8589	1.0164
Min	.6161	.5975	.7468	.7602	.6335	.7468	.6535
Avg	.7470	.7060	.7468	.7602	.7457	.8188	.8350

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 202 / MEDICAL COMPLEX

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9335				.905		
2	.9335				.8145		
3					.8145		
4	.9335				.8145		
5	.9335				.905		
6	1.1203				.9955		
7	1.2136				1.086		
8	1.1203	.1238			.9955		
9	1.1203				1.0269	.9955	
10	1.0269				.9335		
11	.9335				.8402		
12					.8402		
13					.8215		
14					.8402		
15					.8402		
16		.9335					
17	1.0269	.9709					
18	1.1317	1.0374					
19	1.226						
20	1.3203						
21	.12	1.1694	1.226				
22			1.1317			.1105	
23				.9955		1.0374	
24	.905				.905		.9808
Max	1.3203	1.1694	1.226	.9955	1.086	1.0374	.9808
Min	.12	.1238	1.1317	.9955	.8145	.1105	.9808
Avg	.9999	.847	1.1789	.9955	.8986	.7145	.9808

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 203 / SATELLITE

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8145				.8145		
2	.8145				.8145		
3					.8145		
4	.724				.8145		
5	.8145				.8145		
6	.905				.905		
7	.905				.905		
8	.905	.8402			.9335		
9						.8145	
11					.7468		
12					.7468		
13					.9335		
14					.8402		
15					.7468		
16		.7842					
17	.8779	.8402					
18	.8962	.8059					
19	.9335	.9335					
20	.9335	.9145					
21	.8775	.8402					
22			.9335			.9145	
23				.905		.8775	
24	.905				.8145		.823
Max	.9335	.9335	.9335	.905	.9335	.9145	.823
Min	.724	.7842	.9335	.905	.7468	.8145	.823
Avg	.8697	.8512	.9335	.905	.8318	.8688	.823

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 205 / MEDICAL EXPRESS
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905				.0905		
2	.0905				.0905		
3					.0905		
4	.0905				.0905		
5	.0905				.0905		
6	.0905				.0905		
7	.0905				.0905		
8	.0905	.0895			.0905		
9					.0934	.0905	
10					.0934		
11					.0934		
12					.2801		
13					.2801		
14					.2801		
15					.2801		
16		.2801					
17	.1433	.1791					
18	.1075	.0895					
19	.0895	.0895					
20	.0905	.0895					
21	.0895	.0895					
22			.0895			.0895	
23				.0905		.0895	
24	.0905				.0905		.0914
Max	.1433	.2801	.0895	.0905	.2801	.0905	.0914
Min	.0895	.0895	.0895	.0905	.0905	.0895	.0914
Avg	.0957	.1295	.0895	.0905	.1384	.0898	.0914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 206 / COLLECTOR OFFICE (EXP)
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0362		
2					.0362		
3					.0362		
4					.0362		
5					.0362		
6					.0362		
7					.0362		
8		.0179			.0362		
9					.056	.0362	
10					.1307		
11					.1307		
12					.1494		
13					.1494		
14					.1494		
15					.1494		
16		.1307					
17	.1254						
18	.1254						
19	.0716						
20	.0358						
21	.0358	.0537					
22			.0358			.0537	
23				.0362		.0358	
24	.0362				.0362		.0179
Max	.1254	.1307	.0358	.0362	.1494	.0537	.0179
Min	.0358	.0179	.0358	.0362	.0362	.0358	.0179
Avg	.0717	.0674	.0358	.0362	.0776	.0419	.0179

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 208 / Railway station Express HV Express Feeder
feeder Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0543		
2					.0543		
3					.0543		
4					.0543		
5					.0543		
6					.0543		
7					.0543		
8		.0716			.0543		
9					.056	.0543	
10					.056		
11					.056		
12					.056		
13					.056		
14					.0747		
15					.0747		
16		.056			.0747		
17	.0716						
18	.0716						
19	.0716						
20	.0716						
21	.0537	.0716					
22			.0716			.0716	
23				.0543		.0716	
24	.0543				.0543		.0716
Max	.0716	.0716	.0716	.0543	.0747	.0716	.0716
Min	.0537	.056	.0716	.0543	.0543	.0543	.0716
Avg	.0657	.0664	.0716	.0543	.0584	.0658	.0716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 209 / 11 KV SAMRTH NAGAR FEEDER Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.8145		
2					.7602		
3					.7059		
4					.6697		
5					.7059		
6					.7421		
7					.7602		
8		.7602			.7783		
9					.7468	.6154	.7095
10					.7095		.6535
11					.6535		.6535
12					.6535		.6348
13					.7468		.6161
14							.6161
15					.7842		.7095
16		.7842					
17	.8059						
18	.7701						
19	.823						
20	.8059						
21	.7701	.8059					
22			.7164			.8954	
23				.905		.8596	
24	.8507				.8507		.8059
Max	.8507	.8059	.7164	.905	.8507	.8954	.8059
Min	.7701	.7602	.7164	.905	.6535	.6154	.6161
Avg	.8043	.7834	.7164	.905	.7388	.7901	.6749

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 210 / 11 KV TV centre New Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.181		
2					.1629		
3					.181		
4					.1991		
5					.2353		
6					.2715		
7					.3439		
8		.3582			.3077		
9					.2801	.2715	
10					.2614		
11					.2427		
12					.2427		
13					.2241		
16		.2241					
17	.2686						
18	.3045						
19	.3045						
20	.3224						
21	.2686	.2328					
22			.2328			.2149	
23				.2172		.2328	
24	.1991				.181		.2149
Max	.3224	.3582	.2328	.2172	.3439	.2715	.2149
Min	.1991	.2241	.2328	.2172	.1629	.2149	.2149
Avg	.2780	.2717	.2328	.2172	.2367	.2397	.2149

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 213 / 11 KV YOGESH NAGAR
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5973				.5973		
2	.5792				.5611		
3					.5792		
4	.6335				.6335		
5	.6697				.6878		
6	.7421				.7421		
7	.8507				.8145		
8	.8145	.7701			.7421		
9					.7468	.8145	
10					.7468		
11					.7095		
12					.7023		
14					.5975		
15					.5601		
16		.5601			.5975		
17	.6268	.591					
18	.6805	.7522					
19	.7164	.7522					
20	.8059	.8059					
21	.7522	.7783					
22			.6805				
23				.6878		.7164	
24	.6335				.6335		.6767
Max	.8507	.8059	.6805	.6878	.8145	.8145	.6767
Min	.5792	.5601	.6805	.6878	.5601	.7164	.6767
Avg	.7002	.7157	.6805	.6878	.6657	.7655	.6767

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134030 / Pole Factory Sub-station

Feeder No / Name : 201 / 11KV Industrial, Pole factory Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.5544	.5281	.415	.5658	.3772	.5658
2	.4904	.5658	.5281	.415	.5281	.3772	.5658
3	.4904	.5658	.5281	.415	.5093	.3772	.5658
4	.4904	.6036	.5281	.4527	.5281	.3772	.5658
5	.5281	.6036	.5658	4.5268	.5658	.415	.5658
6	.5281	.5658	.6036	.4904	.5847	.4527	.6036
7	.6283	.5658	.679	.4904	.6224	.4904	.4904
8	.7023	.6413	.4904	.4904		.5281	.7545
9	.8676	.9431	.4527	.6036	.5847	.7922	.9054
10	1.0751	1.0751	1.226	.8299	.6413	.7167	1.0185
11	1.2071	1.1317	1.3203	.8299	.6413	.7545	1.2449
12		1.1317	.9431	.8299	.6224	.7545	1.1317
13	1.1694	.9431	.9431	.7922	.5658	.8676	
14	1.0185	.9431	1.0185	.7922	.6036	.9431	1.1317
15	1.0374	1.1694	1.094	.7922	.6224	1.0374	1.0562
16	1.094	1.2071	1.2071	.7922	.5847	1.1317	1.0185
17	.9808	1.1317	1.226	.9054	.5658	1.1694	.9808
18	.9808	.9619	.8865	.8299		1.1317	.8299
19	.9054	.9054	.6036	.811	.4904	.8488	.8299
20	.6413	.6602	.6036	.6602	.4338	.6413	
21	.6413	.5847	.4904	.5847	.415	.5658	
22	.679	.6224	.5093	.4904	.4527	.5093	
23	.6602	.5281		.6036	.4338	.5281	
24	.4904	.5658	.5281	.415	.5847	.4338	.5093
Max	1.2071	1.2071	1.3203	4.5268	.6413	1.1694	1.2449
Min	.4904	.5281	.4527	.415	.415	.3772	.4904
Avg	.7738	.7988	.7610	.8024	.5521	.6759	.8071

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134030 / Pole Factory Sub-station

Feeder No / Name : 202 / 11 KV AGRESAN FEEDER Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6653	.6283	.5914	.4435	.5544	.5544	.5175
2	.6653	.6283	.5914	.5544	.5544	.5544	.5175
3	.6653	.6283	.5914	.5544	.5359	.5544	.5175
4	.6653	.6653	.5914	.5544	.5359	.5544	.5175
5	.6283	.5914	.5544	.5175	.5544	.5544	.5175
6	.5544	.4805	.4805	.4435	.499	.4805	.4805
7	.5544	.5175	.4805	.4805	.4805	.4805	.4805
8	.5175	.4805	.4805	.4805		.4805	.4435
9	.5175	.4805	.4435	.4435	.499	.5175	.4435
10	.5281	.4904	.4527	.4435	.462	.2957	.4066
11	.5093	.4904	.4527	.4435	.462	.3696	.4066
12		.4527	.415	.4435	.4435	.4066	.4066
13	.5093		.415	.4435	.462	.4066	.4066
14	.3961	.4527	.4527	.4435	.4805	.4435	.4066
15	.3961	.4527	.4715	.4435	.5175	.4805	.4066
16	.415	.4715	.5093	.4435	.5175	.4805	.4435
17	.5281	.4715	.5281	.4435	.5359	.5175	.4435
18	.4805	.4435	.4805	.4805		.4805	.4066
19	.5544	.499	.4066	.4805	.5544	.5175	.4435
20	.5729	.5359	.5544	.5544	.5914	.5359	
21	.5729	.5359	.7392	.5544	.5544	.5729	
22	.5359	.5658	.5359	.5544	.5729	.5729	
23	5.9877	.5729		.5729	.5914	.5914	
24	.6653	.6283	.5729	.5544	.5914	.5729	.5729
Max	5.9877	.6653	.7392	.5729	.5914	.5914	.5729
Min	.3961	.4435	.4066	.4435	.4435	.2957	.4066
Avg	.7863	.5289	.5127	.4905	.5250	.4990	.4593

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 201 / RLY STN

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6651	1.6651	1.6651	1.6278	1.9044		
2	1.6289	1.647	1.647	1.5912	1.7741		
3		1.6289	1.6289	1.4998	1.7002		
4	1.6289	1.6108	1.6108	1.4661	1.4784		
5	1.647	1.6108	1.6095	1.4632	1.5154		
6	1.6651	1.6289	1.5746	1.4998	1.5893		
7	1.6651	1.647	1.5927	1.5181	1.7551		
8	1.647	1.647	1.6108	1.5181	1.8111		
9	1.6461	1.5364		1.6263			1.5729
10	1.4632	1.4632		1.6461	1.5181		1.5684
11	1.4632	1.3717		1.6057			1.6095
12		1.3717		1.6263			1.307
13				1.5364			1.4045
14				1.5154			1.4632
15				1.7372			1.6057
16		1.2803		1.7558			1.643
17				1.7741			1.5927
18				1.8298			1.5912
19			1.6651	2.0698			1.6644
20			1.7194	2.0851			
21			1.8461	2.1216			
22			1.6832	1.9387			
23		1.7924	1.6827	1.9791	1.9791		
24	1.7375	1.7737	1.7013	1.6461	1.9959	1.8671	1.2803
Max	1.7375	1.7924	1.8461	2.1216	1.9959	1.8671	1.6644
Min	1.4632	1.2803	1.5746	1.4632	1.4784	1.8671	1.2803
Avg	1.6234	1.5783	1.6598	1.6949	1.7292	1.8671	1.5252

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 202 / BUS STAND

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.905	.905	.905	.7316	.9335		
2	.8145		.8145	.7316	.7392		
3		.724	.8145	.7316			
4	.724	.724	.724	.6401	.5601		
5	.8145	.8145	.8145	.6401	.5544		
6	.8145	.8145	.8145	.6335	.6468		
7	.8145	.8145	.8145	.6401	.7468		
8	.724	.8145	.8145	.6335	.8402		
9	.9145	.9145		.823			.6468
10	1.0974	1.1888		1.0164	1.0059		1.0164
11	1.2803	1.2803		1.1203			1.1203
12		1.2803		1.0974			
13				1.1088			1.2012
14				1.2012			1.0974
15				1.1088			1.1088
16				1.0269			1.2136
17				1.0269			1.1765
18				1.0974			1.5384
19			1.6289	1.2012			1.5546
20			1.7194	1.2936			
21			1.4632	1.2936			
22			.9955	1.1088			
23		.9955	.9145	1.0269	1.2936		
24	.9955	.9955	.905	.823	.924	.8402	.9145
Max	1.2803	1.2803	1.7194	1.2936	1.2936	.8402	1.5546
Min	.724	.724	.724	.6335	.5544	.8402	.6468
Avg	.8999	.9435	1.0102	.9482	.8245	.8402	1.1444

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 203 / KADRABAD

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8326	.905	.8145	.724			
2	.8145	.8145	.7964	.7133	.7392		
3		.8145	.7783	.695	.6219		
4	.7783	.8145	.7602	.6697	.5853		
5	.7602	.8145	.724	.6584	.6653		
6	.8145	.8145	.7421	.6584	.695		
7	.8145	.8145	.7602	.6584	.7762		
8	.7602	.8145		.6584	.7762		
9	.7316	.8048		.7023			.8501
10	.7316	.7682		.695			.7468
11		.7316		.6584			.7468
12		.7499		.7392			.7023
13				.7762			.7392
14				.8131			.7316
15				.7762			.695
16				.7522			.6348
17				.7762			.695
18				.7762			.724
19			.9328	1.0082			.7682
20			.9328	1.0349			
21			.905	1.0082			
22			.8962	1.0082			
23		.8507	.823	.961	.7964		
24	.8507	.9955	.8326	.7421	.8501	.7842	
Max	.8507	.9955	.9328	1.0349	.8501	.7842	.8501
Min	.7316	.7316	.724	.6584	.5853	.7842	.6348
Avg	.7889	.8219	.8229	.7776	.7228	.7842	.7303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 204 / 11KV PWW FEEDER

Only one consumer of WW with HT-IV

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905	.0905	.0905	.0914	.0934		
2	.0905	.0905	.0905	.0914	.0924		
3		.0905	.0905	.0914	.0924		
4	.0905		.0905	.0914	.0924		
5	.0905	.0905	.0905	.0914	.0934		
6	.0905	.0905	.0905	.0914	.0905		
7	.0905	.0905	.0905	.0905	.0924		
8	.0905	.0905	.0905	.0914	.0934		
9	.0914	.0905		.0934			.0934
10	.0914	.0914		.0924	.0914		.0924
11		.0914		.0924			.0934
12		.0914		.0934			.0924
13		.0914		.0924			.0934
14				.0934			1.4937
15				.0934			.0934
16				.0914			.0914
17				.0934			.0914
18				.0924			.0914
19			.0905	.0934			.0905
20			.0914	.0924			
21			.0914	.0934			
22			.0905	.0934			
23		.0905	.0914	.0924	.0924		
24	.0905	.0905	.0905	.0914	.0934	.0924	.0914
Max	.0914	.0914	.0914	.0934	.0934	.0924	1.4937
Min	.0905	.0905	.0905	.0905	.0905	.0924	.0905
Avg	.0907	.0908	.0907	.0923	.0925	.0924	.2090

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 205 / JINDAL COMPLEX INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905	.0905	.0905	.0905	.0914		
2	.0905	.0905	.0905		.1294		
3		.0905	.0905	.0914	.0924		
4	.0905	.0905	.0905	.0914	.0934		
5	.0905	.0905	.0914	.0905	.0924		
6	.0905	.0905	.0905	.0914	.0924		
7	.0905	.0905	.0905	.0914	.0924		
8	.0905	.0905	.0905	.0919	.0924		
9	.0914	.0914		.0914			.0924
10	.0914	.0914		.0924	.0905		.0914
11		.0914		.0924			.0914
12		.0914		.0934			.0934
13				.1663			.0934
14				.0914			.0914
15				.0934			.0914
16				.0924			.0924
17				.0924			.0905
18				.0914			.0914
19			.0905	.0924			.0905
20			.0914	.0924			
21			.0914	.0934			
22			.0905	.0914			
23		.0905	.0905	.0924	.0914		
24	.0905	.0905	.0905	.0914	.0924	.0924	.0914
Max	.0914	.0914	.0914	.1663	.1294	.0924	.0934
Min	.0905	.0905	.0905	.0905	.0905	.0924	.0905
Avg	.0907	.0908	.0907	.0952	.0955	.0924	.0918

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 206 / Mangal Bazar

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0498	1.1041	1.0136	1.1888	1.134		
2	1.0317	1.086	.9774	1.262	1.0974		
3		1.1222	.9593	1.3169	1.0349		
4	1.0498	1.086	.985	1.3535	.961		
5	1.1403	1.1222	1.0317	1.3756	.9979		
6	1.2489	1.1584	1.086	1.3937	1.0974		
7	1.2489	1.2308		1.4118	1.2437		
8	1.3032	1.2851		1.4118	1.3676		
9	1.2803	1.2803		1.5154			1.531
10	1.1706	1.2803		1.4563			1.2197
11				1.1706	1.1706		1.2567
12				1.134			.695
13				1.0719			.9511
14				.8215			.8871
15				1.0242			.9145
16				1.0829			.961
17				1.1458			1.134
18				1.3817			1.3575
19			1.5203	1.4563			1.3756
20			1.4998	1.4784			
21			1.4632	1.4784			
22			1.2489	1.4045			
23		1.2127	1.1523	1.2936	1.4937		
24	1.0679	1.1222	1.0317	1.0791	1.1458	1.0456	.9877
Max	1.3032	1.2851	1.5203	1.5154	1.4937	1.0456	1.531
Min	1.0317	1.086	.9593	.8215	.961	1.0456	.695
Avg	1.1591	1.1742	1.1641	1.2795	1.1585	1.0456	1.1059

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 207 / NARIMAN NAGAR FEEDER Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.543	.5249	.543	.5304	.5544		
2	.5249	.5068	.5083	.5121	.5041		
3		.4887	.5068	.4938	.4668		
4		.4887	.4887	.4755	.4251		
5	.4887	.4887	.4887	.4887	.439		
6	.4887	.4887	.5068	.4938	.5041		
7	.4887	.5068	.5249	.4755	.5175		
8	.5249	.5068	.543	.4755	.5601		
9	.4938	.439		.5359			.4435
10	.4572	.439		.5544	.4755		.4805
11		.4024		.5121			.5359
12		.4024		.5175			.4481
13				.4805			.4572
14				.9979			.1307
15				.499			.4294
16				.5359			.4805
17				.5544			.4887
18				.567			.5068
19			.5611	.5853			.5068
20			.5792	.6348			
21			.5973	.5914			
22			.5611	.5729			
23		.5792	.567	.567	.4515		
24	.5611	.543		.543	.5853	.5359	
Max	.5611	.5792	.5973	.9979	.5853	.5359	.5359
Min	.4572	.4024	.4887	.4755	.4251	.5359	.1307
Avg	.5079	.4861	.5366	.5498	.4985	.5359	.4462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 208 / TULJABHWANI NAGAR FEEDER Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1629	.1629	.1448	.1463	.1829		
2	.1448	.1448	.1267	.1448	.128		
3		.1267	.1267	.1448	.1097		
4		.0905	.128	.1463	.1109		
5		.1086	.1267	.128	.1109		
6	.1448	.1086	.1267	.1267	.1294		
7	.1448	.1086	.1448	.128	.1478		
8	.1086	.1086	.1267	.128	.1663		
9	.128	.128		.1463			.1294
10	.128	.128		.1307	.1086		.1109
11		.128		.1097			.1294
12		.128		.1294			.1097
13				.1663			.112
14				.1646			.128
15				.1494			.1109
16				.1494			.1478
17				.1478			.1448
18				.1646			.128
19			.1433	.128			.1086
20			.1448	.1494			
21			.1646	1.4998			
22			.1629	.112			
23		.1629	.1646	.1478	.1478		
24	.1629	.181	.1629	.1629	.1867	.1478	.0914
Max	.1629	.181	.1646	1.4998	.1867	.1478	.1478
Min	.1086	.0905	.1267	.1097	.1086	.1478	.0914
Avg	.1406	.1297	.1424	.1980	.139	.1478	.1209

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 209 / 11 KV SAMHAJI NAGAR8 Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.4299	1.3394	1.3535	1.4784		
2	1.448	1.4118	1.3032	1.3352	1.4415		
3		1.3937	1.267	1.3032	1.2936		
4	1.3575	1.3756	1.262	1.2803	1.2437		
5	1.3394	1.3032	1.2308	1.3169	1.2803		
6	1.3394	1.448	1.2127	1.3352	1.3817		
7		1.448	1.267	1.3535	1.419		
8	1.4299	1.4506		1.3535	1.4937		
9		1.39		1.5729			1.3817
10	1.1706	1.2803		1.4784	1.2308		1.3169
11				1.307			1.3676
12				1.2567			1.2936
13				1.2197			1.2437
14				1.1827			1.2197
15				1.2696			1.2567
16				1.3443			1.2803
17				1.4784			1.3032
18				1.5524			1.3394
19				1.6263			1.4299
20			1.4842	1.5729			
21			1.4632	1.531			
22			1.3937	1.4937			
23		1.448	1.3717	1.4784	1.5154		
24	1.5203	1.448	1.3756	1.3535	1.531	1.3306	.9877
Max	1.5203	1.4506	1.4842	1.6263	1.531	1.3306	1.4299
Min	1.1706	1.2803	1.2127	1.1827	1.2308	1.3306	.9877
Avg	1.3722	1.4023	1.3309	1.3896	1.3917	1.3306	1.2850

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134036 / 33/11 KV Rohanwadi

Substaion

Feeder No / Name : 201 / 11 kv Sarswati Feeder

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7421	.7783	.7602	.724	.724	.6878	.6878
2	.724	.7602	.7421	.6878	.6878	.6516	.6878
3	.6878	.724	.724	.6516	.6878	.6516	.6516
4	.6878	.724	.724	.6878	.724	.6878	.6154
5	.7783	.7602	.7602	.724	.724	.7421	.6154
6	.8145	.8688	.7602	.7783	.7421	.7602	.724
7	.8507	.9231	.7783	.7783	.7602	.8145	.8145
8	.8507	.8688	.8869	.905	.7059	.8688	.7059
9	.8869	.8145	.8507	.8145	.7059	.8507	.6697
10	.7964	.6516	.8145	.7783	.7421	.6697	.5611
11	.7602	.724	.7783	.5611	.724	.5792	.5792
12	.7059	.7602	.7421	.6154	.724	.5611	.6154
13	.6878	.7421	.724	.6335	.7059	.5611	.5792
14	.6697	.7783	.724	.6154	.7059	.5611	.5792
15	.6878	.724	.7421	.6335	.724	.5792	.5611
16	.7059	.7602		.6878	.7602	.5973	.5792
17	.7964	.7964	.724	.724	.7421	.6154	.6878
18	.8326	.8507		.7421	.7602	.6516	.6516
19	.6697	.8507	.7421	.7421	.7602	.7602	.6697
20	.6516	.9412	.8145	.9231	.6516	.8145	.7964
21	.8869	.905	.8326	.8326	.6335	.7783	.724
22	.9412	.8688	.7964	.8145	.724	.7602	.7059
23		.8507	.7783	.7783	.7059	.6878	.7059
24	.7602	.8145	.7964	.7421	.7059	.6878	.6878
Max	.9412	.9412	.8869	.9231	.7602	.8688	.8145
Min	.6516	.6516	.724	.5611	.6335	.5611	.5611
Avg	.7641	.8017	.7725	.7323	.7180	.6908	.6607

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134036 / 33/11 KV Rohanwadi

Substaion

Feeder No / Name : 202 / 11 KV Bholeshwar Feeder Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5154	1.4969	1.4661	1.4784	1.448	1.4415	1.4118
2	1.4784	1.4415	1.448	1.4415	1.4118	1.423	1.4118
3	1.4415	1.386	1.4118	1.386	1.4118	1.4415	1.448
4	1.46	1.5524	1.3575	1.46	1.448		1.5023
5	1.5893	1.6263	1.448	1.5154	1.4842		1.3213
6	1.6632	1.7187	1.5384	1.6078	1.5384		1.448
7	1.7187	1.7741	1.6108	1.7002	1.6651	1.7926	
8	1.848	1.7556	1.7737	1.8296	1.7375	1.7372	
9	1.6817	1.7556	1.6832	1.7002	1.6289	1.6448	1.6108
10	1.4969	1.4842	1.5524	1.5565	1.6078	1.1946	1.3676
11	1.4784	1.448	1.5708	1.3937	1.5524	1.3575	1.3306
12	1.3937	1.3575	1.4784	1.4118	1.4969	.6878	1.2567
13	1.386	1.2489	1.386	1.3213	1.4415	1.267	1.2382
14	1.3491	1.2489	1.3676	1.267	1.423	1.1946	1.2197
15	1.4045	1.267	1.423	1.3213	1.4969	1.1946	
16	1.5524	1.3937	1.6632	1.448	1.5524	1.3032	
17	1.7926	1.7194	1.9404	1.5384	1.8111	1.5565	
18	2.1253	1.828		1.8461	1.922	1.7194	2.2546
19	1.9774	1.8099	2.1253	1.8823	1.922	1.9004	2.1068
20	1.7556	1.8461	1.8111	1.9366	1.8111	2.0452	2.1437
21	1.848	1.7918	1.46	1.5927	1.7556	1.6832	1.885
22	1.8111	1.647	1.5154	1.7194	1.6817	1.6289	1.8111
23	1.6632	1.5746	1.4969	1.6289	1.5893	1.5203	1.7372
24	1.5524	1.5339	1.4661	1.4784	1.448	1.4784	1.448
Max	2.1253	1.8461	2.1253	1.9366	1.922	2.0452	2.2546
Min	1.3491	1.2489	1.3575	1.267	1.4118	.6878	1.2197
Avg	1.6243	1.5711	1.5650	1.5609	1.5952	1.4863	1.5765

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134045 / 33/11 KV Motibag Substaion

Feeder No / Name : 201 / 11 KV Gokulnagari feeder Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6316	.6303	.6667	.6488	.668	.5556	.6488
2		.6117	.6296	.6488	.668	.5556	.6303
3		.6117	.6296	.6303	.668	.5556	.6303
4	.6316	.6117	.6296	.6303	.6309	.5556	.6303
5	.6687	.6303	.6667	.6303	.668	.6296	.6488
6	.7059	.6488	.7037	.6859	.7052	.7037	.6674
7	.743	.6674	.7037	.6674	.6866	.7037	.6674
8	.6873	.7044	.7037	.7044		.7037	.6303
9	.6303	.6667	.6674	.6303		.5932	.5932
10	.6117	.6296	.6674	.6309		.5747	
11	.6303		.6674	.668		.5747	.5938
12	.6303	.6296	.6303	.5938		.5932	.5196
13	.5932	.6296	.6303	.5567		.5561	.5561
14	.5561		.6117	.5561		.5561	.5191
15	.6117	.5926	.5932	.5932	.7037	.5561	.5567
16	.6303	.5926	.5932	.6117	.7778	.5747	.5561
17	.6674	.5926	.6674		.7407	.6117	.5932
18	.7044	.6296	.7415	.8165	.7778		.6674
19	.7044	.7407	.7786	.723	.8148	.6303	.7415
20	.8157	.7778	.7786		.8519	.7786	.7794
21	.7786	.7778	.7415	.8165	.7407	.7786	
22	.7415	.7423	.7044	.7423	.5926	.7786	
23	.6303	.7407	.7044		.5567	.7415	
24	.6687	.6303	.6667	.6674	.7052	.5926	.6674
Max	.8157	.7778	.7786	.8165	.8519	.7786	.7794
Min	.5561	.5926	.5932	.5561	.5567	.5556	.5191
Avg	.6670	.6586	.6741	.6596	.7033	.6284	.6249

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134045 / 33/11 KV Motibag Substaion

Feeder No / Name : 202 / 11 KV Dukhi Nagar Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4861	1.7647	1.6701	1.5975	1.4845	1.5959	1.6718
2		1.6718	1.6701	1.5975	1.4845	1.5588	1.6347
3		1.6718	1.633	1.5604	1.4845	1.5588	1.6347
4		1.6718	1.6701	1.5604	1.4845	1.5216	1.5975
5	1.5232	1.6904	1.7072	1.5604	1.5588	1.5588	1.5975
6	1.5604	1.7275	1.7443	1.6347	1.6701	1.633	1.5975
7	1.709	1.7833	1.7778	1.7647	1.8	1.7443	1.6347
8	1.9319	1.969	1.8928	1.8576		1.7814	
9	2.0062	2.1155	1.8947	1.8947		1.8576	2.2105
10	1.8947	1.967	2.1176	1.7814		1.8204	
11	1.8576	1.8928	2.1362	1.7072		1.8018	1.8186
12	1.7647	1.9259	1.7275	1.7443		1.6718	1.7814
13	1.839	1.8186	1.7461	1.6701		1.6347	1.6347
14	1.8576		1.709	1.7833		1.5975	1.5604
15	1.8947	1.7072	1.7833	1.7833	2.4866	1.6347	1.5959
16	1.969	1.8928	1.969	1.8576	2.2268	1.8204	1.7461
17	2.2291	2.1155	2.2662		2.5608	2.0062	
18	2.3034	2.2639	2.3405	2.1526	2.5979		.3344
19	2.0433	2.1526	2.3034	2.2662	2.3381	2.0248	2.0433
20	2.322	2.2639	2.0805		2.301	2.0433	2.3381
21	2.1176	2.1111	1.9319	2.0783	2.0412	2.1176	
22	2.0248	2.0041	1.9319	2.0041	1.967	2.0062	
23		1.8928	1.7833		1.8186	1.9319	
24	1.6718	1.9504	1.7814	1.6718	1.7443	1.7072	1.709
Max	2.322	2.2639	2.3405	2.2662	2.5979	2.1176	2.3381
Min	1.4861	1.6718	1.633	1.5604	1.4845	1.5216	.3344
Avg	1.9003	1.9141	1.8862	1.7871	1.9441	1.7665	1.6745

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134045 / 33/11 KV Motibag Substaion

Feeder No / Name : 203 / 11 KV BACHAT BHAVAN FEEDER Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2595	.2222	.2225	.2412	.1852	.2225
2		.241	.2222	.2225	.2227	.1483	.2225
3		.241	.2407	.2225	.1856	.1481	.2225
4	.2043	.241	.2412	.2225	.1856	.1481	.2225
5	.2229	.2595	.2593	.2225	.2227	.1852	.2225
6	.2415	.2595	.2593	.2225	.2227	.2222	.2225
7	.2601	.2781	.2593	.2412	.2412	.2222	.2225
8	.2229	.2225	.2593	.2598	.2227	.1852	.2595
9	.2227	.2593	.2227	.2227		.1856	.2225
10	.2412	.2407	.2227	.2227		.2227	
11	.2412	.2963	.2598	.1856		.2227	.1856
12	.2598	.2963	.2598	.2227		.2041	.1856
13	.2598	.2593	.2412	.1856		.2227	.2227
14	.2227		.2227	.1856		.2041	.2227
15	.2598	.2593	.2598	.2227	.3333	.1856	.2227
16	.2598	.2593	.2598	.1856	.2963	.2227	.1856
17	.2598	.2963	.2783	.2227	.2593	.2595	.2412
18	.2783	.2593	.2783	.2227	.2963		.2227
19	.2412	.2593	.2412	.2598	.2593	.2039	.2227
20	.2783	.2963	.2227		.2593	.2595	.2598
21	.2783	.2963	.2783	.2598	.2593	.2595	
22	.2969	.2598	.2783	.2598		.241	
23	.2598	.2593	.2595		.1485	.2225	
24	.2415	.2595	.2407	.2225	.2227	.1852	.2225
Max	.2969	.2963	.2783	.2598	.3333	.2595	.2598
Min	.2043	.2225	.2222	.1856	.1485	.1481	.1856
Avg	.2489	.2634	.2496	.2235	.2399	.2063	.2217

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134007 / NER 33/11 KV SUB-STATION

Feeder No / Name : 201 / NER Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	02-JUN-17
HR	Load (MW)
21	.0486
Max	.0486
Min	.0486
Avg	.0486

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134019 / RAMNAGAR 33/11 KV S/S

Feeder No / Name : 201 / SAWRGAON AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	03-JUN-17	04-JUN-17	05-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.1715
2			.1715
3			.1715
4			.1715
5			.3429
6			.3429
7			.4287
8			.4287
9			.4287
10	.3429	.3429	
11	.4287	.3429	
12	.3429		
13	.3429		
14	.3429	.3429	
15	.3429	.3429	
16	.2572	.3429	
17	.2572	.3429	
24			.1715
Max	.4287	.3429	.4287
Min	.2572	.3429	.1715
Avg	.3322	.3429	.2829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134019 / RAMNAGAR 33/11 KV S/S

Feeder No / Name : 202 / RAMNAGAR

Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	03-JUN-17	04-JUN-17	05-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2572		
2	.2572		
3	.2572		
4	.2572		
5	.2572		
6	.3429	.3429	
7	.5144	.3429	
8	.5144	.4287	
9	.5144	.4287	
10			.1715
24	.2572		
Max	.5144	.4287	.1715
Min	.2572	.3429	.1715
Avg	.3429	.3858	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134019 / RAMNAGAR 33/11 KV S/S

Feeder No / Name : 203 / EX-D'RAJA
Feeder KV- 11 / OUTGOING

HV Non-Express Feeder

DATE	03-JUN-17	04-JUN-17	05-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1715		
3	.1715		
4	.1715		.1715
5	.2572	.1715	.1715
6	.2572	.1715	.1715
7	.2572	.1715	.1715
8		.2572	.2572
9		.2572	.2572
16	.1715		
17	.1715		
18	.1715	.1715	
19	.2572	.2572	
20	.2572	.2572	
21	.1715	.2572	
22	.1715	.1715	
23		.1715	
24	.1715		
Max	.2572	.2572	.2572
Min	.1715	.1715	.1715
Avg	.2021	.2105	.2001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134019 / RAMNAGAR 33/11 KV S/S

Feeder No / Name : 205 / BHATEPURI GAOTHAN
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	03-JUN-17	04-JUN-17	05-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2572		.3429
2	.2572		.3429
3	.2572		.3429
4	.2572		.3429
5	.4287		.5144
6	.5144		.6859
7	.6859		.8573
8	.6859		.6859
9	.5144		.6001
10	.3429		.5144
11	.3429		
12	.2572		
13	.2572		
14	.2572	.3429	
15	.2572	.3429	
16	.2572	.3429	
17	.3429	.3429	
18		.6859	
19	.5144	.8573	
20	.5144	.8573	
21	.3429	.6859	
22	.3429	.6001	
23		.5144	
24	.2572		.3429
Max	.6859	.8573	.8573
Min	.2572	.3429	.3429
Avg	.3702	.5573	.5066

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134019 / RAMNAGAR 33/11 KV S/S

Feeder No / Name : 206 / RAMNAGAR GAOTHAN
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	03-JUN-17	04-JUN-17	05-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.6001	.5144	.5144
2	.6001	.5144	.5144
3	.6001	.5144	.5144
4	.6001	.5144	.5144
5	.6859	.5144	.6859
6	.8573	.6859	.8573
7	1.0288	.8573	1.0288
8	.9431	.8573	.9431
9	.8573	.6859	.9431
10	.8573	.6859	.8573
11	.6859	.6001	
12	.6001	.6001	
13	.5144	.5144	
14	.5144	.5144	
15	.5144	.5144	
16	.5144	.5144	
17	.6859	.6001	
18	.8573	.9431	
19	.9431	.9431	
20	.8573	.8573	
21	.8573	.8573	
22	.6859	.7716	
23	.6859	.6859	
24	.6001	.6001	.5144
Max	1.0288	.9431	1.0288
Min	.5144	.5144	.5144
Avg	.7144	.6609	.7170

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134019 / RAMNAGAR 33/11 KV S/S

Feeder No / Name : 207 / Bajiumrad
Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	03-JUN-17	04-JUN-17	05-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2572	
2	.3429	.2572	
3	.3429	.2572	
4	.3429	.2572	
5	.3429	.2572	
6	.5144	.2572	
7	.7716	.2572	
8	.6859	.3429	
9	.6859	.4287	
10			.3429
24	.3429	.2572	
Max	.7716	.4287	.3429
Min	.3429	.2572	.3429
Avg	.4715	.2829	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134019 / RAMNAGAR 33/11 KV S/S

Feeder No / Name : 209 / SALEGAON AG
Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	03-JUN-17	04-JUN-17	05-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.2572
2			.2572
3			.2572
4			.2572
5			.3429
6			.4287
7			.5144
8			.5144
9			.5144
10	.3429	.3429	
11	.3429	.5144	
12	.5144		
13	.5144		
14	.5144	.3429	
15	.3429	.5144	
16	.3429	.5144	
17	.3429	.5144	
24			.2572
Max	.5144	.5144	.5144
Min	.3429	.3429	.2572
Avg	.4072	.4572	.3601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134025 / GOLAPANGRI

Feeder No / Name : 202 / KAJALA

Feeder KV- 11 / OUTGOING

AG Feeder with SDT

DATE	02-JUN-17
HR	Load (MW)
13	.1219
Max	.1219
Min	.1219
Avg	.1219

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134025 / GOLAPANGRI

Feeder No / Name : 203 / BATHAN AG FEEDER
Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	03-JUN-17
HR	Load (MW)
5	.1219
Max	.1219
Min	.1219
Avg	.1219

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134025 / GOLAPANGRI

Feeder No / Name : 204 / GOLAPANGHRI

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.8573	.7316		.4572		.7316
2	.6859	.8573	.7316		.4572		.7316
3	.7621	.8573	.7316		.5335		.7316
4	.7926	.9526	.7621		.6097		.7621
5	.8383	1.1431	.8383		.6859		.8383
6	.9145	1.1431	.9145		.7621		.884
7	.9907	1.2498	.9907		.8383		.9145
8	.9145	1.1888	.9907		.7621		
9	.884	.9145	.9145		.6859		
10	.9907	.884			.6859		
11	.945	.7621	.9145		.6001		
12	.9145	.884	.8383		.4572		
13	.9602	.9145	.7621	.5335	.4572		
14	.9145	.8383		.4572	.4572	.6859	
15	.9297			.381	.4572	.7621	
16	.9145		.4572	.3048	.4572	.7926	
17	.9907			.4572	.5335	.8383	
18	1.2003			.5335	.6097	.9145	
19	1.3032			.6859	.9145	.9907	
20	1.0669			.6859		.945	
21	.9907	.7621		.6097	.6668	.8383	
22	1.1431	.7316		.5792		.7621	
23	1.0479	.7316		.5335		.7316	
24	.6859	.9526			.5335		
Max	1.3032	1.2498	.9907	.6859	.9145	.9907	.9145
Min	.6859	.7316	.4572	.3048	.4572	.6859	.7316
Avg	.9361	.9236	.8137	.5238	.6010	.8261	.7991

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134025 / GOLAPANGRI

Feeder No / Name : 205 / mali pimpalgaon

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.4763	.381		.381	.381	.3353
2	.381	.4763	.381		.381	.381	.3353
3	.4268	.4763	.381		.4268	.4954	.3353
4	.5335	.5144	.5335		.4572	.7621	.381
5	.6859	.6668	.6859		.7621	.8573	.4572
6	.9145	.7621	1.1888		1.0669	1.0288	.7316
7	.9907	1.2193	1.2193		.9907	.8383	.7621
8	.9145	1.0974	1.2498		.9145	.7621	
9	.7621	.8383	1.2498		.7621	.6097	
10	.6859	.6859	.6097		.5144	.3201	
11	.5335	.5335	.9145		.5144	.4572	
12	.4572	.4572	.5335		.381	.381	
13	.381	.381	.5792		.381	.381	
14	.3963				.381	.4268	
15	.3658			.3048	.3048	.4572	
16	.4572		.3048	.381	.381	.4877	
17	.5335		.381	.3048	.4572	.5335	
18	.7716			.6097	.6097	.6097	
19	.9431			.9145	.7621	.6859	
20	.9526			.9907		.6401	
21	.8573	.6097		.9145	.4763	.5335	
22	.6668	.5335		.6097	.4763	.4572	
23	.5716	.381		.4572	.4763	.381	
24	.381	.4763			.381	.381	
Max	.9907	1.2193	1.2498	.9907	1.0669	1.0288	.7621
Min	.3658	.381	.3048	.3048	.3048	.3201	.3353
Avg	.6227	.6227	.7062	.6097	.5495	.5520	.4768

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134025 / GOLAPANGRI

Feeder No / Name : 206 / kajala GFS

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	06-JUN-17
HR	Load (MW)
21	.1219
Max	.1219
Min	.1219
Avg	.1219

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134025 / GOLAPANGRI

Feeder No / Name : 207 / ROHANWDI GAOTHAN
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2439	.3429	.3201		.2743		
2	.2439	.3429	.3201		.2743		.2286
3	.2743	.381	.3201		.3048		.2896
4	.3048	.381	.381		.3353		.3048
5	.381	.4001	.4268		.381		.381
6	.4115	.3963	.4877		.4115		.4268
7	.3963	.4725	.4572		.381		
8	.4268	.3506	.4115		.381		
9	.3658	.4115	.3353		.2896		
10		.3353	.3048		.2439		
11	.3353	.2743	.2591		.2915	.2286	
12	.3048	.2743	.2743		.2286	.2591	
13	.2896	.2896	.2591		.1829	.1372	
14	.3048	.2743					
15	.3353					.2134	
16	.3048		.2286	.2134	.1524	.2286	
17	.3353		.2743	.1981	.503	.2286	
18	.4287			.4115	.5182		
19	.4973			.4877	.4572	.3353	
20	.4763			.4572		.381	
21	.4382	.3353		.381		.3353	
22	.4191	.3353		.3353		.3048	
23	.381	.3201		.3201		.2896	
24	.3201	.381			.3048		.2286
Max	.4973	.4725	.4877	.4877	.5182	.381	.4268
Min	.2439	.2743	.2286	.1981	.1524	.1372	.2286
Avg	.3573	.3499	.3373	.3505	.3286	.2674	.3099

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134033 / 33KV HIWRA ROSHANGAON

Feeder No / Name : 201 / PIMPRI D - AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.2858	.2096	
2	.1829	.2096	.2286	
3	.1829	.2096	.2858	.2572
4	.2743	.2096	.2858	.2572
5	.3658	.2096	.2858	.2572
6	.5304	.4191	.2477	.2572
7	.6401	.4191	.6668	.3429
8	.7133	.4191		.3429
9	.439	.2096	.2286	.3086
10	.1524			
24	.1829	.2858	.2096	.1886
Max	.7133	.4191	.6668	.3429
Min	.1524	.2096	.2096	.1886
Avg	.3497	.2877	.2943	.2765

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134033 / 33KV HIWRA ROSHANGAON

Feeder No / Name : 202 / HIVRAROSHANGAON-AG Ag dominated/Pure Ag
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658				.4572
2	.3658				.4572
3	.3658				.4572
4	.5487				.5487
5	.6401				.7316
6	.7316				.823
7	.7316				.823
8	.6401		.4191		.7316
9	.5487		.4763		.5487
10	.7621		.6859		
11	.8573	.6668	.7716		
12	1.0479		.7716		
13	1.0479	.8573	.6859		
14	1.0479	1.0479	.6859		
15	1.0479	1.0479	.6859		
16	1.0479	.8573	.7716		
17		1.0479	.8916	.5487	
18				.6401	
19				.823	
20				.7316	
21				.7316	
22				.6401	
23				.5487	
24	.3658				.4572
Max	1.0479	1.0479	.8916	.823	.823
Min	.3658	.6668	.4191	.5487	.4572
Avg	.7155	.9209	.6845	.6663	.6035

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134033 / 33KV HIWRA ROSHANGAON

Feeder No / Name : 203 / HIWARA ROSHANGAON GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	02-JUN-17	03-JUN-17
HR	Load (MW)	Load (MW)
1	.2096	
2	.2096	
3	.2096	
7		.2858
8		.4191
11	.2096	
15	.2096	
16	.2096	
17	.2096	
18	.2096	
19	.2286	
20	.4191	
21	.4191	
22	.4191	
23	.4191	
Max	.4191	.4191
Min	.2096	.2858
Avg	.2755	.3525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134033 / 33KV HIWRA ROSHANGAON

Feeder No / Name : 204 / BAPKAL AG Ag dominated/Pure Ag
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.2096	.2096	.0857
2	.1829	.2096	.2858	.0857
3	.1829	.2096	.2858	.0857
4	.1829	.2096	.2858	.0857
5	.1829	.2667	.3048	.0857
6	.1829	.2096	.4191	.0857
7	.2743	.2096	.2858	.0857
8	.2743	.2096	.2858	.0857
9	.1829	.2096	.4763	.0857
11		.2096		
12	.2096			
24	.1829	.2096	.2096	.0857
Max	.2743	.2667	.4763	.0857
Min	.1829	.2096	.2096	.0857
Avg	.2019	.2148	.3048	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134033 / 33KV HIWRA ROSHANGAON

Feeder No / Name : 205 / PIMPRI GAOTHAN Gaothan Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829		.2858	.2229	.1829
2	.1829		.3239	.2229	.1829
3	.2743		.4763	.2229	.2743
4	.3658		.2858	.2229	.2743
5	.3658		.2858	.3258	.3658
6	.3841		.4191	.3429	.3658
7	.4024		.4191	.2401	.4572
8	.4024		.4763	.2058	.4572
9	.2926		.2286	.1715	.3292
10	.2096		.2401	.1829	
11	.2096		.1886	.1829	
12	.2096	.2096	.1886		
13	.2096	.2096	.1715		
14	.2096	.2096	.1715	.1829	
15	.2096	.2096	.1715	.1829	
16	.2096	.2096	.1715	.1829	
17		.2096	.2915	.1829	
18		.2096	.4458	.2195	
19		.2096	.4458	.2743	
20	.2096	.2096	.4458		
21	.2096	.2096	.2401	.3658	
22	.2096	.2096	.2229	.3658	
23	.2096	.2096	.2058	.2743	
24	.1829		.2858	.2229	.1829
Max	.4024	.2096	.4763	.3658	.4572
Min	.1829	.2096	.1715	.1715	.1829
Avg	.2544	.2096	.2953	.2380	.3073

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134033 / 33KV HIWRA ROSHANGAON

Feeder No / Name : 206 / SOLGAVAN AG Ag dominated/Pure Ag
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0914
2					.0914
3					.0914
4					.0914
5					.1829
6					.1829
7					.1829
8					.1829
9					.1829
10	.2096	.2096	.2058	.1829	
11	.2096	.2096	.2058		
12		.2096	.2058		
13		.2096	.2058		
14	.2096	.2096	.2058		
15	.2667	.2096	.1715		
16	.2096	.2096	.2058		
17	.2096	.2096	.2058	.1829	
18		.2096			
24					.0914
Max	.2667	.2096	.2058	.1829	.1829
Min	.2096	.2096	.1715	.1829	.0914
Avg	.2191	.2096	.2015	.1829	.1372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134037 / HISWAN

Feeder No / Name : 201 / HISWAN-AG AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1619	.081	.081				.081
2	.1619	.081	.081				.081
3	.1619	.1619	.081				.081
4	.1619	.1619	.081				
5	.2429	.2429	.1619				
6	.2429	.1677	.3239				
7	.3239	.3239	.3239				
8	.3239	.3239	.3239				
9	.4049	.4049	.3239				
10					.2429	.081	
11					.2429	.2429	
12					.2429	.2429	
13					.3239		
14					.2429		
15					.2429		
16					.2429		
17					.2429	.2429	
19	.0324	.0486				.081	
20	.0486	.081				.081	
21	.0324	.0486		.081		.081	
22	.0324	.0486				.081	
23	.0324	.0492				.081	
24	.1619		.081		.081		.081
Max	.4049	.4049	.3239	.081	.3239	.2429	.081
Min	.0324	.0486	.081	.081	.081	.081	.081
Avg	.1684	.1589	.1863	.081	.2339	.1350	.081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134037 / HISWAN

Feeder No / Name : 202 / TANDULWADI AG FEEDER
Feeder KV- 11 / OUTGOING

AG Feeder with SDT

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4858		.3239				.1619
2	.5668		.3239				.1619
3	.5668		.3239				.1619
4	.6478		.3239				
5	.7287		.4858				
6	.6478		.6478				
7	.7287		.8097				
8	.8907		.6478				
9	.9717		.6478				
10					.4858	.3239	
11					.4858		
12					.4858	.4858	
13					.4858		
14					.4858		
15					.4858		
17						.4858	
19	.2429	.2429				.1619	
20	.2429	.2429				.1619	
21	.2429	.2429		.1619		.1619	
22	.2429	.2429				.1619	
23	.2429	.2429				.1619	
24	.2429		.3239		.1619		.1619
Max	.9717	.2429	.8097	.1619	.4858	.4858	.1619
Min	.2429	.2429	.3239	.1619	.1619	.1619	.1619
Avg	.5128	.2429	.4858	.1619	.4395	.2631	.1619

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134037 / HISWAN

Feeder No / Name : 203 / PUNEGAON

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1619	.1619	.0486			.1619	.3239
2	.1619	.1619	.0486			.1619	.3239
3	.1619	.1619	.0486			.1619	.3239
4						.1619	.4049
5						.1619	.4049
6						.2429	.4534
7						.4049	.4049
8						.4049	
9					.3239		
10	.3239	.2429					
12	.4858	.3239					
13	.4858	.3239					
14	.4858	.4049					
15	.4049	.4049					
16	.4049	.3239					
17		.3239					
19	.1619	.1619				.1619	
20	.1619	.1619				.1619	
21	.1619	.1619		.1619		.1619	
22	.1619	.1619				.1619	
23	.1619	.013				.1619	
24	.1619		.081		.3239	.1619	.3239
Max	.4858	.4049	.081	.1619	.3239	.4049	.4534
Min	.1619	.013	.0486	.1619	.3239	.1619	.3239
Avg	.2699	.2330	.0567	.1619	.3239	.2024	.3705

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134037 / HISWAN

Feeder No / Name : 205 / PUNEGAON GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4858	.4858	.5668			.1619	.4858
2	.4858	.4858	.5668			.1619	.4858
3	.5668	.4858	.5668			.2429	.4858
4	.4858	.5668	.6478			.2429	.5668
5	.4858	.5668	.6478			.2429	.6154
6	.4049	.5668	.6478			.2429	.6478
7	.4049		.6478			.2429	
8	.4858	.5668	.6478			.3239	
9	.4858	.4858	.4858		.1619		
10	.4858	.4858			.081	.4049	
11					.0486	.3239	
12		.3239			.0486	.3239	
13	.4049	.3239			.0486		
14	.3239	.2429			.0486		
15	.3239	.2429			.0486		
16	.3239	.2429					
17		.3239				.3239	
18	.4858	.5668				.4858	
19	.6478	.6478				.5668	
20	.5668	.6478				.5182	
21	.4858	.4858		.1619		.4858	
22	.4858	.4858				.4858	
23	.4858	.4858				.4534	
24	.5668		.4858		.081	.1619	.3239
Max	.6478	.6478	.6478	.1619	.1619	.5668	.6478
Min	.3239	.2429	.4858	.1619	.0486	.1619	.3239
Avg	.4704	.4627	.5911	.1619	.0709	.3367	.5159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134037 / HISWAN

Feeder No / Name : 206 / GADE SAWARGAON

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.081	.081	.081			.081	.081
2	.081	.081	.081			.081	.081
3	.081	.081	.081			.081	.081
4		.081					
10	.3239	.2429			.1619	.1619	
11	.3239				.2429	.1943	
12	.2429	.2429			.2429	.1619	
13	.2429	.2429			.2429		
14	.2429	.2429			.2429		
15	.2429	.2429			.2429		
16	.2429	.2429					
17		.2429				.1619	
19	.081	.081					
20	.081	.081				.081	
21	.081	.081		.1619		.081	
22	.081	.081				.081	
23	.081	.081				.081	
24	.081		.081		.081	.081	.081
Max	.3239	.2429	.081	.1619	.2429	.1943	.081
Min	.081	.081	.081	.1619	.081	.081	.081
Avg	.1620	.1518	.081	.1619	.2082	.1107	.081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134040 / 33KV GONDEGAON

Feeder No / Name : 201 / DHALDI - AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.443	.2715	.4287	.1677	.5373	.3429	.5316
2	.4477	.2715	.4287		.5316	.3429	.5316
3	.4477	.2715	.4287	.1619	.5373	.3429	.5316
4	.4477	.2715	.4287	.1581	.6201		.6201
5	.5373	.2715	.6859	.2286	.7087	.5144	
6	.7087	.362	.8573	.2315	.8669	.6001	
7	.7087	.362	.8573	.3125	1.1145	.6001	
8	.6201	.2715	.5144	.3163	1.0288	.6001	
9	.5373	.2715	.4287	.4191	.9431	.6001	
10	.8859	.1715	.7116	.362	.4287	.4477	
11	.905		.9012	.2715	.4287		.362
12	.7973	.6859	.8592	.2686	.4287		
13	.7087	.8573	.8488		.4287		
14	.7973	.8573	.7716	.5373	.3429		
15	.7087	.7716	.5401	.6201			
16	.6201	.7716	.6249	.7973		.362	.5544
17	.8669	.7716	.6112	.6201		.362	.443
18	.4477	.4287				.5373	
19	.7087	.823	.4191	.6201		.6201	
20	.7973	.6001	.3125	.7087	.3429	.7087	.6268
21	.6201	.6001	.3353	.6201	.4287	.6201	.5316
22	.5373	.5144		.5316	.4287	.6201	.4477
23	.2715	.4287	.3353	.6201	.3429	.5316	.443
24	.4477	.2715	.4287	.2343	.5373	.3429	.5316
Max	.905	.8573	.9012	.7973	1.1145	.7087	.6268
Min	.2715	.1715	.3125	.1581	.3429	.3429	.362
Avg	.6258	.4860	.5799	.4194	.5803	.5053	.5129

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134040 / 33KV GONDEGAON

Feeder No / Name : 202 / WANJAR UMRAD

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.1848	.1715	.1734	.1848		
2	.1848	.1848	.1715	.1638	.1848		
3	.1848	.1848	.1715		.1848		
4	.2715	.1848	.1715		.1848		
5	.4477	.2715	.2058		.2743		
6	.7087	.2715		.1715	.2715		
7	.7973	.2715		.3315	.2715		
8		.6201	.2572	.3239	.2715		
9	.7973	.6201	.6001	.2429			
10	.1848	.1715	.1638	.1848	.2572		
11	.1848			.1848	.6001		
12	.0934	.1715		.1848	.6001		
13	.0934	.1715		.4477	.6001		
14	.0934	.1715		.4477	.6001		
15	.0934	.0857	.1734	.1848			
16	.0934	.0857	.181	.1848			
17	.0934	.1715	.1696	.1848			.4477
18	.1848	.1715		.1848			
19	.2743	.2572	.1696	.1848			
20	.1848	.1715	.1638	.1848		.0934	.362
21	.1848	.1715	.1619	.1848		.0934	.2715
22	.2715	.1715	.1638	.1848		.0934	.2715
23	.2715	.1715	.1677	.1848		.0934	.1848
24	.1848	.1848	.1715	.1734	.5373		
Max	.7973	.6201	.6001	.4477	.6001	.0934	.4477
Min	.0934	.0857	.1619	.1638	.1848	.0934	.1848
Avg	.2636	.2227	.2021	.2235	.3588	.0934	.3075

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134040 / 33KV GONDEGAON

Feeder No / Name : 203 / WAGHRUL (J)

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.1848	.1715	.1638	.1848	
2	.1848	.1848	.1715	.1638	.1848	
3	.1848	.1848	.1715	.1619	.1848	
4	.1848	.1848	.1715	.1562	.1848	
5	.2772	.1848	.2572	.2343	.1848	
6	.5373	.362		.2372	.1848	
7	.6201	.6268	.1715	.3277	.2715	
8	.6201	.5373	.2572	.3163	.2743	
9	.4477	.4477	.2572	.1638	.1715	
10		.1715	.1696	.1848	.1715	
11	.0934	.1715	.1696	.1848	.3429	
12	.0934	.1715	.1677	.1848	.3429	
13	.0934	.0857	.1696		.3429	
14	.0934	.0857	.1619		.2572	
15	.0934	.0857	.1715	.1848		
16	.0934	.0857	.1696	.1848		
17	.0934	.1715	.1753	.1848		
18	.1848	.1715		.1848		
19	.1848	.1715	.1619	.1848		
20	.1848	.1715	.1696	.1848		.362
21	.1848	.1715	.16	.1848		.2715
22	.1848	.1715	.1677	.1848		.1848
23	.1848	.1715	.1715	.1848		.1848
24	.1848	.1848	.1715	.1638	.1848	
Max	.6201	.6268	.2572	.3277	.3429	.362
Min	.0934	.0857	.16	.1562	.1715	.1848
Avg	.2256	.2142	.1812	.1957	.2312	.2508

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134040 / 33KV GONDEGAON

Feeder No / Name : 204 / WAGHUL GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.1848	.1848	.1875	.1848	.1848	.1848
2	.1848	.1848	.1848	.1871	.1848	.1848	.1848
3	.1848	.1848	.1848	.1867	.1848	.1848	.1848
4	.1848	.1848	.2772	.1871	.1848	.1848	.1848
5	.2715	.2715	.462	.2795	.2715	.2772	.2743
6	.3582	.362	.462	.3727	.362	.462	
7	.3582	.362	.3696	.4644	.362	.462	
8	.2715	.3582	.462	.2789	.362	.3696	
9	.2715	.2715	.2772	.2815	.2772	.2218	
10	.1848	.2218	.2804	.2715	.2772	.2715	
11	.1867	.1848	.1877	.1848	.2772	.1848	
12	.1848	.1848	.1873	.1848		.1848	
13	.1848	.1848	.1858	.1848	.1848	.1848	
14	.1848	.0924	.1852	.1848	.0924	.1848	
15	.1848	.0924	.1858	.1848		.1848	
16	.1848	.0924	.1871	.1848	.0924	.1848	
17		.1848	.1871	.1848	.0924	.1848	
18		.2772		.2715		.2715	
19		.3696	.2824	.362		.362	
20		.3696	.3749	.362	.3696	.362	.2715
21		.3658	.3746	.2715	.2772	.2743	.2715
22	.1848	.2772	.2818	.1848	.2772	.2743	.2715
23	.1848	.1848	.2821	.1848	.1848	.1848	.1848
24	.1848	.1848	.1848	.188	.1848	.1848	.1848
Max	.3582	.3696	.462	.4644	.3696	.462	.2743
Min	.1848	.0924	.1848	.1848	.0924	.1848	.1848
Avg	.2168	.2347	.2709	.2423	.2342	.2504	.2198

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407]

BU 2721

Substation No/ Name :- 134040 / 33KV GONDEGAON

Feeder No / Name : 205 / WANJAR UMRAD GAOTHAN
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.1848	.1829	.1882	.1848	.1829	.1848
2	.1848	.1848	.1829	.1882	.1848	.1829	
3	.1848	.1848	.1829	.1873	.1848	.1829	.1848
4	.1848	.1848	.1829	.1869	.1848	.1829	.1848
5	.1848	.1848	.2743	.2801	.1848	.2743	.1848
6	.2715	.1848	.2743	.2795	.2743	.2743	.1848
7	.1848	.2715	.2743	.3715	.2743	.3658	.1848
8		.1848	.2743	.2824	.1848	.2743	.2715
9	.1848	.1848	.1829	.1871	.1829	.1829	.1848
10	.0934	.1829	.1879	.1848	.1829	.1848	.1848
11	.1848		.1877	.0934	.1829		
12	.0934	.0914	.1879	.0934	.1829		
13	.0934	.0914	.1877	.0934	.0914		
14	.0934	.0914		.0934	.0914		
15	.0934	.0914	.0939	.0934			
16	.0934	.0914	.1882	.0934	.0953		
17	.0934	.1829	.1877	.0934			.0934
18	.1848	.1829		.1848			
19	.2743	.2195	.1871	.1848			
20	.1848	.1715	.1873	.1848	.1829	.1848	.1848
21	.1848	.1829	.1869	.1848	.1829	.1848	.1848
22	.1848	.1829	.1869	.1848	.1829	.1848	.1848
23	.1848	.1829	.1884	.1848	.1829	.1848	.1848
24	.1848	.1848	.1829	.1877	.1848	.1829	.1848
Max	.2743	.2715	.2743	.3715	.2743	.3658	.2715
Min	.0934	.0914	.0939	.0934	.0914	.1829	.0934
Avg	.1646	.1687	.1978	.1786	.1792	.2140	.1845

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134043 / DHARKALYAN

Feeder No / Name : 201 / KADVANCHI Sheddable Rural/Mix Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.362	.3772		.7545	.3582
2	.5658	.362	.3772		.7545	.3582
3	.5658	.3582	.3772		.7545	.3582
4	.5658	.3582	.3772		.7545	
5	.5658	.3582	.3772		1.0374	.362
6	.6602	.4525	.4715		1.1317	.362
7	.7545	.4477	.4715		1.1317	
8	.6602	.4477	.5658		.6602	
9	1.2803	.3582	.3772		.5658	.3582
10	1.1145	.362			.5658	1.0631
11	1.1269					1.0402
12	1.0402	.362				.7802
13	1.0517	.3582	.3772	.6602		1.0517
14	.964	.362		.6602		
15	.8764			.5658		
16	.3506	.7087				.3544
17	.3582			.5658		.5316
18	.4477			.6602	.5658	
19	.5373			.6602		.362
20	1.1145			.5658		
21				.5658		
22			.3772	.5658		
23			.3772	.5658		
24	.5658	.362	.362		.8488	.3582
Max	1.2803	.7087	.5658	.6602	1.1317	1.0631
Min	.3506	.3582	.362	.5658	.5658	.3544
Avg	.7491	.4013	.4050	.6036	.7938	.5499

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134043 / DHARKALYAN

Feeder No / Name : 202 / NAVHA

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.6201	.7545		.3772	.3582
2	.5658	.6201	.7545		.3772	.3582
3	.5658	.5316	.6602		.3772	.3544
4	.5658	.5316	.6602	.3772	.3772	.3544
5	.6602	.6201	.6602	.4715	.3772	.3544
6	.7545	.7011	.7545	.5658	.5658	.3506
7	.7545	.7802	.8488	.7545	.5658	.3582
8	.6602	.4334	.4715		.7545	.3582
9	.5658	.3582	.3772		.7545	.3582
10	.3582	.3582		.7545	.7545	
11	.3582			.7545	.8488	.3582
12	.3582	.8954		.7545	.8488	.3582
13	.362	.8954	.3772	.7545		.3582
14	.362	.3582	.3772	.6602		.3582
15	.362	.3582	.3772	.6602		.3582
16	.7164	.3582	.3772	.5658	.6602	.7973
17	.7087		.3772	.5658	.5658	.7973
18	.7973		.3772	.5658	.5658	
19	.7973	.6201		.6602		
20				.6602		
21				.6602		
22			.3772	.5658		
23			.3772	.4715		
24	.7545	.7087	.362		.3772	.3582
Max	.7973	.8954	.8488	.7545	.8488	.7973
Min	.3582	.3582	.362	.3772	.3772	.3506
Avg	.5797	.5735	.5178	.6235	.5717	.4087

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134043 / DHARKALYAN

Feeder No / Name : 203 / BORKHEDI Ag dominated/Pure Ag
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	.3544	.5658		.9431	.5316
2	.6602	.3544	.4715		.9431	.443
3	.6602	.3544	.4715		.9431	.443
4	.6602	.3582	.4715		1.1317	.3544
5	.7545	.5258	.5658		1.1317	.3544
6	.8488	.5258	.5658		1.4146	
7	.8488	.5258	.5658		1.226	
8	.7545	.3506	.5658		.7545	
9	1.4146	.3506	.3772		.5658	
10	1.1736				.5658	
11	1.0898				.5658	
12	1.1022	.3506		.5658		
13	1.0174	.3544	.3772			
14	1.0174	.3506	.3772			
15	.8478	.3544	.3772			
16	.3467	.7087			.6602	.8859
17	.5258			.7545	.6602	1.0288
18				.7545		
19	.6859			.8488		
20				.8488		
21				.7545		
22			.7545	.6602		
23			.7545	.6602		
24	.6602	.3544	.5144		.9431	.5316
Max	1.4146	.7087	.7545	.8488	1.4146	1.0288
Min	.3467	.3506	.3772	.5658	.5658	.3544
Avg	.8278	.4115	.5184	.7309	.8892	.5716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134043 / DHARKALYAN

Feeder No / Name : 204 / KOTHARI EXP

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	05-JUN-17
HR	Load (MW)	Load (MW)
1	.0698	.0566
2	.0679	.0547
3	.066	.0509
4	.066	.0509
5	.0679	.0377
6	.0622	.0321
7	.0622	.0302
8	.0585	.0321
9	.0717	.0358
10		.0396
11		.0415
12		.0396
16		.0396
17		.0472
24	.0717	.0604
Max	.0717	.0604
Min	.0585	.0302
Avg	.0664	.0433

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134043 / DHARKALYAN

Feeder No / Name : 205 / GAWALI POKHARI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.4477	.5658		.5658	.4477
2	.7545	.4477	.5658		.5658	.3582
3	.7545	.6135	.5658		.5658	
4	.8488	.6135	.6602		.5658	
5	.8488	.7087	.6602		.7545	
6	.9431	.7087	.6602		.9431	
7	1.1317	.724	.7545		.7545	
8	.4715	.7087	.7545		.6602	
9	.5658	.7973	.7545		.5658	
10	.5014		.8488		.5658	
11	.5014		.8488		.5658	
12	.4477	.6201	.7545			
13	.4525	.6201	.7545			
14	.5014	.6201				
15	.5014	.5316	.7545			
16	.5068	.5373			.6602	
17	.4525	.7087		.9431	.9431	
18	.4477			1.0374		
19	.3582			1.0374		
20		.6268		.9431		
21				.9431		
22			.3772	.7545		
23			.3772	.7545		
24	.7545	.443	.5316		.6602	.5373
Max	1.1317	.7973	.8488	1.0374	.9431	.5373
Min	.3582	.443	.3772	.7545	.5658	.3582
Avg	.6249	.6163	.6582	.9162	.6669	.4477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134043 / DHARKALYAN

Feeder No / Name : 206 / PIRKALYAN

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.443		.1463
2		.3544		.1448
3		.3544		.1448
4		.4477		.181
5		.443		.181
6		.4477		.181
7		.443		.181
8		.4477		.181
9		.6201		.181
10	.181			.181
11	.181			.181
12	.181	.7973		.181
13	.181	.8859		.181
14	.181	.7973		
15		.7087		
16	.1791	.2658		.181
17	.181	.2126		
18	.181	.2172		.4525
19	.1829	.2481		.4477
20				1.0387
21				.443
24		.443	.3544	.1463
Max	.1829	.8859	.3544	1.0387
Min	.1791	.2126	.3544	.1448
Avg	.181	.4765	.3544	.2608

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134059 / DAMBRI

Feeder No / Name : 201 / VIREGAON Sheddable Rural/Mix Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4144	.4144	.4973	.4191	.4144
2	.4144	.4144	.4973	.4191	.4144
3	.4144	.4144	.4973	.4191	.4144
4	.4973	.4973	.5801	.4191	.4973
5	.4973	.4973	.663	.4191	.5801
6	.5801	.4973	.663		.5801
7	.663	.4973	.7459	.5868	.9116
8	.7459	.5801	.663	.5868	.8288
9	.8288		.6706	.5868	.7459
10		.4144	.5868	.503	
11		.3315	.503	.4973	.5868
12		.3315	.503	.4973	
13	.3315	.3315	.503	.4973	
14	.3315	.3315	.503	.4973	
15	.3315	.4144	.503	.4641	
16	.4191	.4144	.503		
17	.503	.4973	.5868	.4973	
18	.5868	.5801		.5801	
19	.6706	.663	.7545	.663	
20	.5868	.663	.6706	.663	
21	.5868	.663		.663	
22	.5868	.5801	.5868	.663	
23		.5801	.503	.5801	
24	.4144	.4144	.4973	.4191	.5801
Max	.8288	.663	.7545	.663	.9116
Min	.3315	.3315	.4973	.4191	.4144
Avg	.5202	.4792	.5764	.5246	.5958

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134059 / DAMBRI

Feeder No / Name : 202 / PIMPALGAON Ag dominated/Pure Ag
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.663		.5801	.3353	.4973
2	.663		.5801	.3353	.4973
3	.7459		.5801	.3353	.4973
4	.7459		.663	.3353	.663
5	.9116		.7459	.4191	.9116
6	1.0774		.9945	.6706	.9116
7	1.1603		.9116	.5868	.9116
8	.9945	.3315	.8288	.503	.8288
9	.8288		.5868	.503	.7459
10	.663	.5801	.503	.4191	.5801
11	.663	.5801	.503	.5801	.503
12	.6299	.6299	.503	.663	
13	.5801	.663	.503	.5801	
14	.5801	.663	.503	.5801	
15	.5801	.5801	.503	.5801	
16	.6706	.4973		.5801	
17	.6706	.7459		.663	
18	.6706	.8288		.7459	
19	.9221	.9116	.5868	.7459	
20	.9221	.9116	.503	.8288	
21	.8383	.8288	.4191	.9116	
22	.6706	.7459	.4191	.9116	
23		.7459	.4191	.663	
24	.7459		.5801	.4191	.4144
Max	1.1603	.9116	.9945	.9116	.9116
Min	.5801	.3315	.4191	.3353	.4144
Avg	.7651	.6829	.5912	.5790	.6635

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134059 / DAMBRI

Feeder No / Name : 203 / DAMBRI

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1658	.0829	.0829	.0838	.1658
2	.1658	.0829	.0829	.0838	.1658
3	.1658	.0829	.0829	.0838	.1658
4	.1658	.0829	.1326	.0838	.1658
5	.1658	.0829	.1658	.0838	.1658
6	.1658	.0829	.1658	.1677	.2486
7	.1658	.1658	.1658	.1677	.2486
8	.1658	.1658	.1658	.1677	.2486
9	.1823	.1658	.1677	.1677	.1658
10	.1989	.1658	.1677	.1677	.1658
11	.1658	.1658	.1677	.1658	.1677
12	.1658	.1658	.0838	.1658	
13	.1658	.1658	.0838	.1658	
14	.1658	.1658	.0838	.1658	
15	.1658	.1326	.1677	.1658	
16	.1677	.1326	.1677	.1658	
17	.2515	.1326	.2515	.1658	
18	.2515	.1326		.1658	
19	.1677	.1326	.2515	.2486	
20	.1677	.1326	.2515	.2486	
21	.1677	.1326	.2515	.1658	
22	.1677	.1326	.2515	.1658	
23		.1326	.1677	.1658	
24	.1658	.0829	.0829	.0838	.1658
Max	.2515	.1658	.2515	.2486	.2486
Min	.1658	.0829	.0829	.0838	.1658
Avg	.1758	.1292	.1584	.1526	.1867

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134062 / MANEGAON

Feeder No / Name : 202 / PAREGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	02-JUN-17	03-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1905		.1524
2		.1905		.1524
3		.2096		.1524
4				.1715
5				.1905
6				.2286
7				.2667
8				.3429
9				.362
19	.2477		.2286	.1905
20	.2286			.2096
21	.2286		.3048	
22	.2096		.1905	.1905
23	.1905		.1524	.1905
24	.1905			.1524
Max	.2477	.2096	.3048	.362
Min	.1905	.1905	.1524	.1524
Avg	.2159	.1969	.2191	.2109

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134062 / MANEGAON

Feeder No / Name : 203 / SAWANGI FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3429	.3429		.2667
2		.3429	.3429		.2667
3		.4191	.4572		.2667
4					.2858
5					.3048
6					.3429
7					.381
8					.4763
9					.381
10		.381			
13	.5335				
14	.5716				
15	.6097				
16	.5716				
17	.5906				
18	.3429				
19	.5525	.5335		.381	.5906
20	.362	.4763		.3429	.4763
21	.3429	.381		.3429	.381
22	.3429	.3429		.3239	.362
23	.3048			.3048	.3429
24	.2858		.3048		.2858
Max	.6097	.5335	.4572	.381	.5906
Min	.2858	.3429	.3048	.3048	.2667
Avg	.4509	.4025	.3620	.3391	.3607